LORP Synopsis for September 2014

Compliance Comments:
Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting and increased sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

Here are the flow changes during the month:

LORP Intake decreased from 60 cfs to 55 cfs on September 23rd, 2014.
LORP Intake decreased from 55 cfs to 50 cfs on September 26th, 2014.

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2014-15)
The runoff forecast for runoff year 2014-15 is 50%, so the waterfowl acreage goal for this year is 250 acres.

On April 7th the Thibaut Waterfowl Area inflow was turned off for the summer.

On April 16th the spring flows were set and the inflows to Drew were increased to 4.9 cfs. When the wetted perimeter was measured with GPS in the middle of the spring season, the wetted area was 309 acres for Drew.

On May 29th the summer flows were set and the inflows to Drew were decreased to 4.7 cfs. When the wetted perimeter was measured with GPS in the middle of the summer season, the wetted area was 278 acres for Drew.

On August 16th the fall flows were set and the inflows to Drew were decreased to 4.1 cfs. When the wetted perimeter was measured with GPS in the middle of the fall season, the wetted area was 270 acres for Drew.

Drew Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
4.9 cfs	4/16/14	309	5/8/14
4.7 cfs	5/29/14	278	7/8/14
4.1 cfs	8/16/14	270	9/16/14

Waggoner Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
N/A		N/A	

Winterton Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
N/A		N/A	

Thibaut Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
0	4/7/14	N/A	

SEPTEMBER 2014 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes
At Mazourka Canyon Road	9/17/2014	53.07	64.31	62.32	-10	gage height 4.50
At Reinhackle Springs	9/17/2014	48.9	59.33	61.69	-12	gage height 4.08
LORP Intake	9/18/2014	63.61	59.5	60.5	4	gage height 5.50

Month: September
Year: 2014

	Intake			Blackrock Ditch Return		Goose Lake Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge				
Date	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date	Lange-mann Release to Delta	Weir to Delta	**River Daily Avg**
09/01/14	64	65	15	1	1	1	1	1.3	1	53	58	15	0	0	0	0	48	58	15	0	0	52	65	15	44	44	8	0	**54**
09/02/14	62	64	15	1	1	1	1	1.3	1	53	57	15	0	0	0	0	46	56	15	0	0	50	63	15	43	44	7	0	**53**
09/03/14	64	63	15	1	1	1	1	1.3	1	53	57	15	0	0	0	0	47	55	15	0	0	49	61	15	42	43	7	0	**53**
09/04/14	62	62	15	1	1	1	1	1.3	1	54	56	15	0	0	0	0	46	54	15	0	0	45	59	15	37	42	8	0	**52**
09/05/14	61	62	15	2	1	1	1	1.3	1	55	56	15	0	0	0	0	46	53	15	0	0	49	58	15	40	41	8	1	**53**
09/06/14	61	62	15	2	1	1	1	1.3	1	55	55	15	0	0	0	0	46	52	15	0	0	45	56	15	37	41	8	0	**52**
09/07/14	61	62	15	1	1	1	1	1.3	1	54	55	15	0	0	0	0	46	51	15	0	0	43	54	15	35	40	8	0	**51**
09/08/14	62	62	15	1	1	1	1	1.3	1	54	54	15	0	0	0	0	47	50	15	0	0	43	52	15	35	39	8	0	**52**
09/09/14	63	62	15	1	1	1	1	1.2	1	54	54	15	0	0	0	0	48	49	15	0	0	43	51	15	35	39	8	0	**52**
09/10/14	61	62	15	2	1	1	1	1.1	1	55	54	15	0	0	0	0	48	49	15	0	0	43	50	15	35	38	8	0	**52**
09/11/14	64	62	15	1	1	1	1	1.0	1	55	54	15	0	0	0	0	49	49	15	0	0	43	49	15	35	38	8	0	**53**
09/12/14	63	62	15	1	1	1	1	1.0	1	55	54	15	0	0	0	0	48	48	15	0	0	42	47	15	35	38	7	0	**52**
09/13/14	61	62	15	2	1	1	1	1.0	1	55	54	15	0	0	0	0	48	48	15	0	0	44	46	15	36	38	8	0	**52**
09/14/14	62	62	15	2	1	1	1	1.1	1	55	54	15	0	0	0	0	50	48	15	0	0	40	46	15	28	37	8	4	**52**
09/15/14	62	62	15	2	1	1	1	1.1	1	56	54	15	0	0	0	0	50	48	15	0	0	47	45	15	27	36	8	12	**54**
09/16/14	62	62	15	1	1	1	1	1.1	1	56	55	15	0	0	0	0	50	48	15	0	0	43	45	15	28	36	15	0	**53**
09/17/14	62	62	15	1	1	1	1	1.1	1	53	55	15	0	0	0	0	49	48	15	0	0	43	44	15	29	35	14	0	**52**
09/18/14	63	62	15	1	1	1	1	1.1	1	53	55	15	0	0	0	0	48	48	15	0	0	43	44	15	35	35	8	0	**52**
09/19/14	63	62	15	1	1	1	1	1.1	1	52	54	15	0	0	0	0	49	48	15	0	0	42	44	15	34	35	8	0	**52**
09/20/14	63	62	15	1	1	1	1	1.0	1	52	54	15	0	0	0	0	49	48	15	0	0	42	43	15	34	35	8	0	**52**
09/21/14	63	62	15	1	1	1	1	1.1	1	53	54	15	0	0	0	0	50	49	15	0	0	41	43	15	33	35	8	0	**52**
09/22/14	65	63	15	1	1	1	1	1.2	1	54	54	15	0	0	0	0	49	49	15	0	0	43	43	15	35	35	8	0	**53**
09/23/14	62	63	15	1	1	1	1	1.2	1	54	54	15	0	0	0	0	50	49	15	0	0	45	43	15	37	35	8	0	**53**
09/24/14	60	62	15	1	1	1	1	1.2	1	54	54	15	0	0	0	0	49	49	15	0	0	46	43	15	38	35	8	0	**52**
09/25/14	59	62	15	1	1	1	1	1.2	1	52	54	15	0	0	0	0	47	49	15	0	0	47	43	15	39	35	8	0	**51**
09/26/14	56	62	15	1	1	1	1	1.2	1	51	54	15	0	0	0	0	46	49	15	0	0	44	43	15	36	35	8	0	**49**
09/27/14	54	61	15	1	1	1	1	1.3	1	50	53	15	0	0	0	0	48	49	15	0	0	43	44	15	35	35	8	0	**49**
09/28/14	53	61	15	1	1	1	1	1.3	1	49	53	15	0	0	0	0	49	49	15	0	0	41	43	15	34	35	7	0	**48**
09/29/14	53	60	15	1	1	1	1	1.3	1	48	52	15	0	0	0	0	49	49	15	0	0	42	43	15	35	35	7	0	**48**
09/30/14	52	59	15	1	1	1	1	1.3	1	47	52	15	0	0	0	0	48	49	15	0	0	44	43	15	36	35	8	0	**48**

Lower Owens River Project Flow Report for 09/01/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**64**	**65**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**53**	**58**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**58**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**52**	**65**	15
Pump Station			44	46	
Langemann Gate to Delta			8	8	
Weir to Delta			0	11	
LORP In Channel Average Flow [2]			**54**	**62**	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/02/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**62**	**64**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**53**	**57**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**56**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**63**	15
Pump Station			43	46	
Langemann Gate to Delta			7	8	
Weir to Delta			0	9	
LORP In Channel Average Flow [2]			**53**	**60**	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/03/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**64**	**63**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**53**	**57**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**47**	**55**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**49**	**61**	15
Pump Station			42	46	
Langemann Gate to Delta			7	8	
Weir to Delta			0	7	
LORP In Channel Average Flow [2]			**53**	**59**	

Pump Station Month-to-Date Average Flow 43 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/04/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**54**	**56**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**54**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**45**	**59**	15
Pump Station			37	45	
Langemann Gate to Delta			8	8	
Weir to Delta			0	6	
LORP In Channel Average Flow [2]			**52**	**58**	

Pump Station Month-to-Date Average Flow 42 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/05/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**61**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**55**	**56**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**53**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**49**	**58**	15
Pump Station			40	45	
Langemann Gate to Delta			8	8	
Weir to Delta			1	5	
LORP In Channel Average Flow [2]			**53**	**57**	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/06/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**61**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**55**	**55**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**52**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**45**	**56**	15
Pump Station			37	44	
Langemann Gate to Delta			8	8	
Weir to Delta			0	4	
LORP In Channel Average Flow [2]			**52**	**56**	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/07/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**61**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**54**	**55**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**51**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**54**	15
Pump Station			35	43	
Langemann Gate to Delta			8	8	
Weir to Delta			0	3	
LORP In Channel Average Flow [2]			**51**	**56**	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/08/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**54**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**47**	**50**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**52**	15
Pump Station			35	43	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow [2]			**52**	**55**	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/09/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**63**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**54**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**51**	15
Pump Station			35	42	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow [2]			**52**	**54**	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 8/27/2014)
Lower Twin Lake Gage Read	2.19 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/10/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**61**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**55**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**50**	15
Pump Station			35	41	
Langemann Gate to Delta			8	8	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**54**	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/11/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**64**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			**55**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**49**	15
Pump Station			35	40	
Langemann Gate to Delta			8	8	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**53**	**54**	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/12/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**63**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			**55**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**42**	**47**	15
Pump Station			35	39	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow [2]			**52**	**53**	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/13/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**61**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			**55**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**44**	**46**	15
Pump Station			36	39	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow [2]			**52**	**53**	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/14/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**55**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**50**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**40**	**46**	15
Pump Station			28	37	
Langemann Gate to Delta			8 [e]	8	
Weir to Delta			4 [e]	0	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flows estimated at Langemann Gate to Delta and Weir to Delta due to a level sensor failure.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/15/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**56**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**50**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**47**	**45**	15
Pump Station			27	36	
Langemann Gate to Delta			8 [e]	8	
Weir to Delta			12 [e]	1	
LORP In Channel Average Flow [2]			**54**	**52**	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flows estimated at Langemann Gate to Delta and Weir to Delta due to a level sensor failure.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/16/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**56**	**55**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**50**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**45**	15
Pump Station			28	35	
Langemann Gate to Delta			15 [e]	8	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**53**	**52**	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Langemann Gate to Delta due to controller malfunction.
1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.
Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/17/2014

LORP Measuring Station	Augmenting Flows Daily Avg Flow(cfs)	Augmenting Flows 15 Day Avg Flow(cfs)	Owens River Flows Daily Avg Flow(cfs)	Owens River Flows 15 Day Avg Flow(cfs)	Owens River Flows # Days of last 15 at 40+ cfs
Below River Intake			**62**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**53**	**55**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**44**	15
Pump Station			29	34	
Langemann Gate to Delta			14 [e]	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Langemann Gate to Delta due to controller malfunction.
1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.
Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/18/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**63**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**53**	**55**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**44**	15
Pump Station			35	34	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/19/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**63**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**52**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**42**	**44**	15
Pump Station			34	34	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/20/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**63** [e]	**62**	15
Blackrock Ditch Return (augmentation)	1 [e]	1			
Goose Lake Return (return flow)	1 [e]	1			
Billy Lake Return (augmentation)	1 [e]	1			
Mazourka Canyon Road			**52** [e]	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49** [e]	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**42**	**43**	15
Pump Station			34 [e]	33	
Langemann Gate to Delta			8 [e]	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flows estimated due to communication outage related to lightning.
1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.
Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/21/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**63**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**53**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**50**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**41**	**43**	15
Pump Station			33	33	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/22/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**65**	**63**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**54**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**43**	15
Pump Station			35	33	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**53**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/23/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**62**	**63**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**54**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**50**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**45**	**43**	15
Pump Station			37	33	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**53**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.42 ft	(Last Collected: 9/10/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/24/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**60**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**54**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**46**	**43**	15
Pump Station			38	33	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**52**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/25/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**59**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**52**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**47**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**47**	**43**	15
Pump Station			39	34	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**51**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/26/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**56**	**62**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**51**	**54**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**44**	**43**	15
Pump Station			36	34	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**49**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/27/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**54**	**61**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**50**	**53**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**43**	**44**	15
Pump Station			35	34	
Langemann Gate to Delta			8	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**49**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/28/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**53**	**61**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**49**	**53**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**41**	**43**	15
Pump Station			34	33	
Langemann Gate to Delta			7	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**48**	**52**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/29/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**53**	**60**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**48**	**52**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**49**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**42**	**43**	15
Pump Station			35	34	
Langemann Gate to Delta			7	9	
Weir to Delta			0	1	
LORP In Channel Average Flow [2]			**48**	**51**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 09/30/2014

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**52**	**59**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**47**	**52**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**48**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**44**	**43**	15
Pump Station			36	35	
Langemann Gate to Delta			8	9	
Weir to Delta			0	0	
LORP In Channel Average Flow [2]			**48**	**51**	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	270 Acres	09/16/2014	4.1 cfs	08/16/2014
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	270 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.49 ft	(Last Collected: 9/24/2014)
Lower Twin Lake Gage Read	2.25 ft	
Goose Lake Gage Read	2.56 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Robert Turner/Larry Benbrook/Todd Bunn/Mark Wilder/David Tait

DATE: Monday, September 22nd, 2014

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: September 23rd, 2014 TIME: Anytime

CHANGE FLOW FROM: 60 cfs TO 55 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Clarence Martin
Robert Prendergast
Charlotte Rodrigues
Steve Butler
Jim Campbell
William Jones
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Robert Turner/Larry Benbrook/Todd Bunn/Mark Wilder/David Tait

DATE: Thursday, September 25th, 2014

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: September 26th, 2014 TIME: Anytime

CHANGE FLOW FROM: 55 cfs TO 50 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Clarence Martin
Robert Prendergast
Charlotte Rodrigues
Steve Butler
Jim Campbell
William Jones
Ben Butler

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.
Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information	
File Name	070706.ORABR.LOR.WAD
Start Date and Time	2007/07/06 07:48:17

Site Details	
Site Name	ORABR
Operator(s)	DJT

System Information	
Sensor Type	FlowTracker
Serial #	P1685
CPU Firmware Version	3.2
Software Ver	2.11

Units	(English Units)
Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Summary			
Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	**44.3025**

Discharge Uncertainty		
Category	**ISO**	**Stats**
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	**2.1%**	**1.8%**

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	*08:12*	*40.00*	*0.2/0.8*	*1.490*	*0.2*	*1.192*	*0.8245*	*1.00*	*0.6321*	*2.980*	*1.8837*	*4.3*
13	*08:13*	*40.00*	*0.2/0.8*	*1.490*	*0.8*	*0.298*	*0.4396*					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

SonTek FlowTracker v2.11

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD







Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek FlowTracker ... | 2:44 PM

SonTek FlowTracker v2.11

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD







Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



- Noise level check - Pass
- SNR check - Pass
- Peak location check - Pass
- Peak shape check - Pass

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek FlowTracker ... | 2:44 PM

SonTek Argonaut Data Processing - [FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)]

File Edit View Processing Argonaut Config Window Help

FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz
File	BROR_070801_a
File Size	65.18 kB
Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:

V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:

V Beam (m)	0.426
Stage (m)	1.304 V
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:

SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek Argonaut Dat... | 2:49 PM

Station Number: 0088 Meas. No: 009

Station Name: OWENS RIVER BELOW INTAKE SPILLGATES Date: 09/18/2014

Party: BJA/KSL	Width: 27.1 ft	Processed by: BJA/KSL
Boat/Motor:	Area: 160 ft²	Mean Velocity: 0.399 ft/s
Gage Height: 6.29 ft	G.H.Change: 0.000 ft	Discharge: 63.6 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 1.32 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 7.00 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 5.89 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 72.81	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 69.7 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 140918 INTAKE @ LOR000r.m

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
001	R	2	2	35	5.62	45.1	7.98	0.565	3.18	62.4	27	156	08:41	08:42	0.62	0.40	9	0
005	R	2	2	33	5.69	46.7	7.49	1.31	2.72	63.9	27	159	08:46	08:46	0.76	0.40	6	0
007	R	2	2	34	5.58	45.8	7.45	0.989	3.14	62.9	27	160	08:48	08:48	0.67	0.39	9	0
009	R	2	2	32	5.83	47.8	7.66	1.02	3.04	65.3	28	164	08:51	08:51	0.78	0.40	6	0
Mean		2	2	33	5.68	46.4	7.65	0.971	3.02	63.6	27	160	**Total**	00:09	0.71	0.40	7	0
SDev		0	0	1	0.109	1.16	0.242	0.306	0.209	1.27	0.4	3.0			0.08	0.00		
SD/M		0.00	0.00	0.04	0.02	0.02	0.03	0.31	0.07	0.02	0.02	0.02			0.11	0.01		

Remarks:

Discharge Measurement Summary

Date Generated: Wed Sep 3 2014

File Information

File Name	140903BR.RTN.WAD
Start Date and Time	2014/09/03 08:52:30

Site Details

Site Name	BLACK ROCK RTN
Operator(s)	BJA

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.8%	2.6%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	**6.5%**	**2.8%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	10.8 dB	Total Area	6.178
Mean Temp	65.40 °F	Mean Depth	1.040
Disch. Equation	Mid-Section	Mean Velocity	0.2056
		Total Discharge	**1.2700**

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:52	0.00	None	1.040	0.0	0.0	0.0000	1.00	0.2051	0.260	0.0533	4.2
1	08:52	0.50	0.6	1.040	0.6	0.416	0.2051	1.00	0.2051	0.520	0.1066	8.4
2	08:53	1.00	0.6	1.040	0.6	0.416	0.1788	1.00	0.1788	0.780	0.1395	11.0
3	*08:55*	*2.00*	*0.6*	*1.040*	*0.6*	*0.416*	*0.2201*	*1.00*	*0.2201*	*1.040*	*0.2290*	*18.0*
4	08:56	3.00	0.6	1.040	0.6	0.416	0.2267	1.00	0.2267	1.040	0.2358	18.6
5	08:57	4.00	0.6	1.040	0.6	0.416	0.2057	1.00	0.2057	1.040	0.2139	16.8
6	08:58	5.00	0.6	1.040	0.6	0.416	0.2031	1.00	0.2031	0.780	0.1584	12.5
7	08:59	5.50	0.6	1.040	0.6	0.416	0.1860	1.00	0.1860	0.489	0.0909	7.2
8	08:59	5.94	None	1.040	0.0	0.0	0.0000	1.00	0.1860	0.229	0.0426	3.4

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Wed Sep 3 2014

File Information	
File Name	140903BR.RTN.WAD
Start Date and Time	2014/09/03 08:52:30

Site Details	
Site Name	BLACK ROCK RTN
Operator(s)	BJA







Discharge Measurement Summary

Date Generated: Wed Sep 3 2014

File Information

File Name	140903BR.RTN.WAD
Start Date and Time	2014/09/03 08:52:30

Site Details

Site Name	BLACK ROCK RTN
Operator(s)	BJA

Quality Control

St	Loc	%Dep	Message
3	2.00	0.6	High SNR variation during measurement: 6.5,6.0
		0.6	Boundary QC is Good; possible boundary interference

Discharge Measurement Summary

Date Generated: Wed Sep 3 2014

File Information		Site Details	
File Name	140903BR.RTN.WAD	Site Name	BLACK ROCK RTN
Start Date and Time	2014/09/03 08:52:30	Operator(s)	BJA

Automatic Quality Control Test (BeamCheck)



- Noise level check - Pass
- SNR check - Pass
- Peak location check - Pass
- Peak shape check - Pass

Discharge Measurement Summary

Date Generated: Wed Sep 10 2014

File Information

File Name	140910BR.BRD.WAD
Start Date and Time	2014/09/10 08:49:39

Site Details

Site Name	BLK ROCK DITCH
Operator(s)	KSL

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.5%	2.5%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	**6.5%**	**2.7%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	11.7 dB	Total Area	6.297
Mean Temp	61.98 °F	Mean Depth	1.060
Disch. Equation	Mid-Section	Mean Velocity	0.2372
		Total Discharge	**1.4935**

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:49	0.00	None	1.060	0.0	0.0	0.0000	1.00	0.2247	0.265	0.0596	4.0
1	08:49	0.50	0.6	1.060	0.6	0.424	0.2247	1.00	0.2247	0.530	0.1191	8.0
2	08:51	1.00	0.6	1.060	0.6	0.424	0.2375	1.00	0.2375	0.795	0.1888	12.6
3	08:52	2.00	0.6	1.060	0.6	0.424	0.2441	1.00	0.2441	1.060	0.2587	17.3
4	08:54	3.00	0.6	1.060	0.6	0.424	0.2493	1.00	0.2493	1.060	0.2643	17.7
5	08:55	4.00	0.6	1.060	0.6	0.424	0.2743	1.00	0.2743	1.060	0.2907	19.5
6	08:56	5.00	0.6	1.060	0.6	0.424	0.2142	1.00	0.2142	0.795	0.1703	11.4
7	08:58	5.50	0.6	1.060	0.6	0.424	0.1939	1.00	0.1939	0.498	0.0966	6.5
8	08:58	5.94	None	1.060	0.0	0.0	0.0000	1.00	0.1939	0.233	0.0452	3.0

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Wed Sep 10 2014

File Information		Site Details	
File Name	140910BR.BRD.WAD	Site Name	BLK ROCK DITCH
Start Date and Time	2014/09/10 08:49:39	Operator(s)	KSL







Discharge Measurement Summary

Date Generated: Wed Sep 10 2014

File Information	
File Name	140910BR.BRD.WAD
Start Date and Time	2014/09/10 08:49:39

Site Details	
Site Name	BLK ROCK DITCH
Operator(s)	KSL

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Wed Sep 10 2014

File Information		Site Details	
File Name	140910BR.BRD.WAD	Site Name	BLK ROCK DITCH
Start Date and Time	2014/09/10 08:49:39	Operator(s)	KSL

Automatic Quality Control Test (BeamCheck)



- Noise level check - Pass
- SNR check - Pass
- Peak location check - Pass
- Peak shape check - Pass

Discharge Measurement Summary

Date Generated: Wed Sep 17 2014

File Information

File Name	140917BR.RTR.WAD
Start Date and Time	2014/09/17 09:12:41

Site Details

Site Name	BLK RCK RTN
Operator(s)	MKH

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.6%	2.1%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	**6.5%**	**2.3%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	9.9 dB	Total Area	6.059
Mean Temp	67.62 °F	Mean Depth	1.020
Disch. Equation	Mid-Section	Mean Velocity	0.2071
		Total Discharge	**1.2548**

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Wed Sep 17 09:11:57 PDT 2014	0.000	1.020		
2	Wed Sep 17 09:20:23 PDT 2014	5.940	1.020		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:12	0.00	None	1.020	0.0	0.0	0.0000	1.00	0.1837	0.255	0.0469	3.7
1	09:12	0.50	0.6	1.020	0.6	0.408	0.1837	1.00	0.1837	0.510	0.0937	7.5
2	09:13	1.00	0.6	1.020	0.6	0.408	0.1995	1.00	0.1995	0.765	0.1526	12.2
3	09:14	2.00	0.6	1.020	0.6	0.408	0.2077	1.00	0.2077	1.020	0.2118	16.9
4	09:15	3.00	0.6	1.020	0.6	0.408	0.2382	1.00	0.2382	1.020	0.2430	19.4
5	09:16	4.00	0.6	1.020	0.6	0.408	0.2346	1.00	0.2346	1.020	0.2393	19.1
6	09:18	5.00	0.6	1.020	0.6	0.408	0.2037	1.00	0.2037	0.765	0.1559	12.4
7	09:19	5.50	0.6	1.020	0.6	0.408	0.1588	1.00	0.1588	0.479	0.0761	6.1
8	09:19	5.94	None	1.020	0.0	0.0	0.0000	1.00	0.1588	0.224	0.0356	2.8

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Wed Sep 17 2014

File Information	
File Name	140917BR.RTR.WAD
Start Date and Time	2014/09/17 09:12:41

Site Details	
Site Name	BLK RCK RTN
Operator(s)	MKH







Discharge Measurement Summary

Date Generated: Wed Sep 17 2014

File Information	
File Name	140917BR.RTR.WAD
Start Date and Time	2014/09/17 09:12:41

Site Details	
Site Name	BLK RCK RTN
Operator(s)	MKH

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Thu Sep 25 2014

File Information

File Name	140924BL.RTN.WAD
Start Date and Time	2014/09/24 09:26:45

Site Details

Site Name	BLACK ROCK RTN
Operator(s)	BJA

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.5%	4.3%
Width	0.2%	0.2%
Method	2.9%	-
# Stations	5.8%	-
Overall	**6.5%**	**4.4%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	10.1 dB	Total Area	6.117
Mean Temp	60.76 °F	Mean Depth	1.030
Disch. Equation	Mid-Section	Mean Velocity	0.2087
		Total Discharge	**1.2769**

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:26	0.00	None	1.030	0.0	0.0	0.0000	1.00	0.2103	0.257	0.0541	4.2
1	09:26	0.50	0.6	1.030	0.6	0.412	0.2103	1.00	0.2103	0.515	0.1083	8.5
2	09:27	1.00	0.6	1.030	0.6	0.412	0.1736	1.00	0.1736	0.772	0.1341	10.5
3	*09:28*	*2.00*	*0.6*	*1.030*	*0.6*	*0.412*	*0.2398*	*1.00*	*0.2398*	*1.030*	*0.2470*	*19.3*
4	*09:29*	*3.00*	*0.6*	*1.030*	*0.6*	*0.412*	*0.2356*	*1.00*	*0.2356*	*1.030*	*0.2426*	*19.0*
5	09:30	4.00	0.6	1.030	0.6	0.412	0.2431	1.00	0.2431	1.030	0.2504	19.6
6	09:31	5.00	0.6	1.030	0.6	0.412	0.1824	1.00	0.1824	0.772	0.1409	11.0
7	09:32	5.50	0.6	1.030	0.6	0.412	0.1401	1.00	0.1401	0.484	0.0678	5.3
8	09:32	5.94	None	1.030	0.0	0.0	0.0000	1.00	0.1401	0.227	0.0317	2.5

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Thu Sep 25 2014

File Information	
File Name	140924BL.RTN.WAD
Start Date and Time	2014/09/24 09:26:45

Site Details	
Site Name	BLACK ROCK RTN
Operator(s)	BJA







Discharge Measurement Summary

Date Generated: Thu Sep 25 2014

File Information

File Name	140924BL.RTN.WAD
Start Date and Time	2014/09/24 09:26:45

Site Details

Site Name	BLACK ROCK RTN
Operator(s)	BJA

Quality Control

St	Loc	%Dep	Message
3	2.00	0.6	Boundary QC is Fair; possible boundary interference
4	3.00	0.6	High SNR variation during measurement: 5.6,5.6

Discharge Measurement Summary

Date Generated: Thu Sep 25 2014

File Information		Site Details	
File Name	140924BL.RTN.WAD	Site Name	BLACK ROCK RTN
Start Date and Time	2014/09/24 09:26:45	Operator(s)	BJA

Automatic Quality Control Test (BeamCheck)



- Noise level check - Pass
- SNR check - Pass
- Peak location check - Pass
- Peak shape check - Pass

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	0	2	18	0.236	-0.01	0.778	0.033	0.03	0	48.6	47.3	71.4	144	140	0	31	30
2014	9	1	0	12	18	0.246	-0.039	0.778	0.033	0.03	0	48.2	47.7	71.8	143	140	0	31	29
2014	9	1	0	22	18	0.233	0.03	0.778	0.033	0.03	0	47.7	46.4	72.2	142	138	0	31	30
2014	9	1	0	32	18	0.249	0	0.778	0.033	0.03	0	46.4	45.6	73.1	138	136	0	30	30
2014	9	1	0	42	18	0.207	-0.023	0.778	0.039	0.036	0	45.2	45.2	74	136	135	0	31	30
2014	9	1	0	52	18	0.233	0	0.781	0.039	0.036	0	44.7	43.4	74.4	135	131	0	31	30
2014	9	1	1	2	18	0.269	0.01	0.781	0.039	0.036	0	43	43.9	74	132	132	0	32	30
2014	9	1	1	12	18	0.197	-0.039	0.781	0.03	0.026	0	43.4	43	74.8	132	130	0	31	30
2014	9	1	1	22	18	0.223	-0.046	0.781	0.033	0.03	0	44.7	44.3	72.7	134	132	0	30	29
2014	9	1	1	32	18	0.253	-0.036	0.781	0.03	0.03	0	44.3	43.9	74.4	133	132	0	30	30
2014	9	1	1	42	18	0.203	-0.049	0.781	0.036	0.033	0	43	43.4	74.8	132	131	0	32	30
2014	9	1	1	52	18	0.197	0.049	0.781	0.039	0.036	0	43.9	43.4	74.4	133	131	0	31	30
2014	9	1	2	2	18	0.256	-0.023	0.781	0.036	0.033	0	43	43	74	132	130	0	32	30
2014	9	1	2	12	18	0.223	-0.023	0.781	0.033	0.03	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	1	2	22	18	0.256	-0.039	0.781	0.036	0.033	0	43.4	43.4	74.4	132	131	0	31	30
2014	9	1	2	32	18	0.21	-0.01	0.781	0.033	0.03	0	43.4	42.6	74.8	132	130	0	31	31
2014	9	1	2	42	18	0.184	-0.056	0.781	0.033	0.03	0	43	43.9	74	131	132	0	31	30
2014	9	1	2	52	18	0.285	-0.016	0.781	0.039	0.036	0	43.9	43	74.4	133	130	0	31	30
2014	9	1	3	2	18	0.197	-0.03	0.781	0.036	0.033	0	43.4	43.4	73.5	132	131	0	31	30
2014	9	1	3	12	18	0.21	-0.062	0.781	0.033	0.03	0	43.9	43	73.1	133	130	0	31	30
2014	9	1	3	22	18	0.256	0.023	0.781	0.036	0.033	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	1	3	32	18	0.285	-0.003	0.781	0.033	0.03	0	43	43	73.1	132	131	0	32	31
2014	9	1	3	42	18	0.23	0.033	0.781	0.033	0.03	0	43.4	43.9	74	132	132	0	31	30
2014	9	1	3	52	18	0.272	-0.039	0.781	0.039	0.039	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	1	4	2	18	0.184	0	0.781	0.033	0.03	0	43	42.6	73.1	131	130	0	31	31
2014	9	1	4	12	18	0.167	-0.039	0.781	0.033	0.03	0	43	43.4	73.1	132	131	0	32	30
2014	9	1	4	22	18	0.243	-0.036	0.781	0.039	0.036	0	44.3	43.4	73.1	134	131	0	31	30
2014	9	1	4	32	18	0.171	-0.01	0.781	0.036	0.033	0	43.9	43	73.5	133	131	0	31	31
2014	9	1	4	42	18	0.223	0.013	0.781	0.036	0.033	0	43	43	73.1	132	130	0	32	30
2014	9	1	4	52	18	0.213	-0.036	0.781	0.043	0.039	0	43.9	43	72.7	133	130	0	31	30
2014	9	1	5	2	18	0.279	-0.007	0.781	0.036	0.033	0	43.9	43.4	72.7	132	131	0	30	30
2014	9	1	5	12	18	0.171	0.003	0.781	0.036	0.033	0	43.9	43.4	72.2	133	131	0	31	30
2014	9	1	5	22	18	0.203	0	0.781	0.036	0.033	0	44.3	43.4	71.8	134	131	0	31	30
2014	9	1	5	32	18	0.295	-0.016	0.781	0.046	0.043	0	43.9	43.4	72.7	133	131	0	31	30
2014	9	1	5	42	18	0.226	-0.02	0.781	0.039	0.039	0	43.4	43	72.2	133	131	0	32	31
2014	9	1	5	52	18	0.213	-0.033	0.781	0.039	0.036	0	43.9	43	72.7	132	131	0	30	31
2014	9	1	6	2	18	0.259	-0.033	0.781	0.039	0.039	0	43.9	43	72.2	133	130	0	31	30
2014	9	1	6	12	18	0.249	0.013	0.781	0.033	0.03	0	42.6	42.1	73.1	131	129	0	32	31
2014	9	1	6	22	18	0.272	-0.023	0.781	0.033	0.03	0	43.9	43.4	72.7	133	131	0	31	30
2014	9	1	6	32	18	0.246	-0.052	0.781	0.036	0.033	0	42.6	42.1	73.5	130	128	0	31	30
2014	9	1	6	42	18	0.246	0.003	0.781	0.036	0.033	0	42.6	41.3	73.1	129	127	0	30	31
2014	9	1	6	52	18	0.292	-0.066	0.781	0.033	0.03	0	41.3	40.9	74.4	128	126	0	32	31
2014	9	1	7	2	18	0.22	-0.026	0.781	0.036	0.033	0	42.1	42.1	73.5	130	128	0	32	30
2014	9	1	7	12	18	0.223	0.013	0.781	0.039	0.036	0	41.7	40.9	74	128	125	0	31	30
2014	9	1	7	22	18	0.213	-0.043	0.781	0.039	0.036	0	41.3	41.3	74	127	127	0	31	31
2014	9	1	7	32	18	0.157	-0.003	0.778	0.039	0.039	0	42.6	41.7	73.5	130	127	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	7	42	18	0.177	0.046	0.778	0.036	0.033	0	45.2	43.9	72.2	136	132	0	31	30
2014	9	1	7	52	18	0.256	0	0.778	0.036	0.033	0	45.2	45.2	72.2	136	135	0	31	30
2014	9	1	8	2	18	0.295	0.03	0.778	0.043	0.043	0	48.6	47.7	71	144	141	0	31	30
2014	9	1	8	12	18	0.177	0.023	0.778	0.033	0.03	0	46.4	45.6	72.2	139	136	0	31	30
2014	9	1	8	22	18	0.203	0	0.778	0.039	0.039	0	44.3	43.4	74	134	131	0	31	30
2014	9	1	8	32	18	0.246	0.098	0.774	0.039	0.036	0	43.4	43	74.4	132	131	0	31	31
2014	9	1	8	42	18	0.246	-0.01	0.774	0.036	0.033	0	43.4	43	74.4	132	130	0	31	30
2014	9	1	8	52	18	0.177	-0.03	0.774	0.033	0.03	0	43	43	75.3	131	130	0	31	30
2014	9	1	9	2	18	0.262	-0.026	0.774	0.036	0.033	0	42.6	42.6	75.7	131	130	0	32	31
2014	9	1	9	12	18	0.259	-0.069	0.774	0.033	0.03	0	42.6	43	75.7	130	130	0	31	30
2014	9	1	9	22	18	0.272	-0.036	0.774	0.039	0.036	0	42.1	43.4	75.3	130	131	0	32	30
2014	9	1	9	32	18	0.23	0.043	0.774	0.039	0.036	0	43.9	43.9	75.7	134	132	0	32	30
2014	9	1	9	42	18	0.135	0.089	0.774	0.03	0.03	0	43.9	45.2	77	133	135	0	31	30
2014	9	1	9	52	18	0.213	-0.033	0.771	0.036	0.033	0	44.3	46	76.1	134	137	0	31	30
2014	9	1	10	2	18	0.22	0.026	0.774	0.033	0.03	0	45.2	47.3	75.3	137	140	0	32	30
2014	9	1	10	12	18	0.207	0	0.771	0.03	0.03	0	44.7	45.6	75.3	135	136	0	31	30
2014	9	1	10	22	18	0.276	0.01	0.771	0.033	0.03	0	45.6	47.3	75.3	138	140	0	32	30
2014	9	1	10	32	18	0.203	0.036	0.771	0.033	0.03	0	45.6	46.4	75.3	137	138	0	31	30
2014	9	1	10	42	18	0.184	0	0.768	0.033	0.03	0	46	46.9	74	139	139	0	32	30
2014	9	1	10	52	18	0.23	-0.095	0.771	0.033	0.03	0	47.3	48.6	73.5	141	144	0	31	31
2014	9	1	11	2	18	0.233	0	0.768	0.033	0.03	0	47.3	49	73.1	141	144	0	31	30
2014	9	1	11	12	18	0.161	0.039	0.768	0.039	0.036	0	46.9	49	74.4	140	145	0	31	31
2014	9	1	11	22	18	0.23	-0.036	0.764	0.036	0.033	0	47.3	49.5	72.7	142	145	0	32	30
2014	9	1	11	32	18	0.194	0.01	0.764	0.033	0.03	0	47.3	49	72.2	141	144	0	31	30
2014	9	1	11	42	18	0.177	0	0.764	0.033	0.03	0	47.7	49.9	71.8	141	146	0	30	30
2014	9	1	11	52	18	0.194	-0.036	0.764	0.03	0.03	0	48.2	49.9	72.7	143	146	0	31	30
2014	9	1	12	2	18	0.207	0.039	0.764	0.03	0.03	0	47.7	49.9	71.4	143	146	0	32	30
2014	9	1	12	12	18	0.243	0.036	0.761	0.033	0.03	0	48.2	50.3	71	143	147	0	31	30
2014	9	1	12	22	18	0.24	0.052	0.761	0.033	0.03	0	48.6	49.9	70.1	144	146	0	31	30
2014	9	1	12	32	18	0.24	0.016	0.761	0.033	0.03	0	49.5	49.9	69.7	145	146	0	30	30
2014	9	1	12	42	18	0.233	0.052	0.761	0.03	0.03	0	48.2	49.5	70.1	143	145	0	31	30
2014	9	1	12	52	18	0.223	0.056	0.758	0.033	0.03	0	47.3	49.5	68.8	141	145	0	31	30
2014	9	1	13	2	18	0.22	0	0.755	0.033	0.03	0	47.3	49.9	69.7	141	146	0	31	30
2014	9	1	13	12	18	0.223	0.03	0.755	0.033	0.03	0	46.4	47.3	71	139	141	0	31	31
2014	9	1	13	22	18	0.151	0	0.751	0.033	0.03	0	46.9	49	71	140	144	0	31	30
2014	9	1	13	32	18	0.2	0.036	0.748	0.03	0.03	0	48.2	49.5	70.5	143	145	0	31	30
2014	9	1	13	42	18	0.203	-0.003	0.748	0.033	0.03	0	45.2	47.7	71	136	140	0	31	29
2014	9	1	13	52	18	0.18	0.052	0.748	0.033	0.03	0	46.4	48.2	71	138	141	0	30	29
2014	9	1	14	2	18	0.184	0.02	0.748	0.033	0.03	0	46	47.7	71.8	137	140	0	30	29
2014	9	1	14	12	18	0.253	0	0.748	0.033	0.03	0	45.2	46.4	72.2	135	138	0	30	30
2014	9	1	14	22	18	0.243	0.072	0.748	0.033	0.03	0	44.7	46.9	72.7	135	138	0	31	29
2014	9	1	14	32	18	0.151	-0.03	0.745	0.033	0.03	0	45.2	47.3	72.7	135	139	0	30	29
2014	9	1	14	42	18	0.236	-0.03	0.745	0.036	0.033	0	45.6	46.9	73.5	136	139	0	30	30
2014	9	1	14	52	18	0.246	0.069	0.745	0.033	0.03	0	45.6	46.9	73.1	136	139	0	30	30
2014	9	1	15	2	18	0.177	0.01	0.745	0.033	0.03	0	45.6	46.4	74	136	137	0	30	29
2014	9	1	15	12	18	0.226	0.023	0.745	0.03	0.026	0	45.6	46	74.4	136	137	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	15	22	18	0.151	0.033	0.745	0.036	0.033	0	44.3	46.4	74.4	133	138	0	30	30
2014	9	1	15	32	18	0.187	0.043	0.745	0.036	0.033	0	44.7	45.6	73.5	134	136	0	30	30
2014	9	1	15	42	18	0.282	0.03	0.745	0.039	0.036	0	44.3	45.6	74	133	136	0	30	30
2014	9	1	15	52	18	0.151	0.049	0.745	0.033	0.03	0	45.2	46	75.3	135	136	0	30	29
2014	9	1	16	2	18	0.203	0.007	0.741	0.036	0.033	0	44.3	46	74	133	137	0	30	30
2014	9	1	16	12	18	0.246	0.062	0.741	0.033	0.03	0	43.4	46	76.1	132	137	0	31	30
2014	9	1	16	22	18	0.197	0.095	0.741	0.033	0.03	0	43	44.7	75.3	131	133	0	31	29
2014	9	1	16	32	18	0.262	0.059	0.741	0.039	0.039	0	44.7	44.7	74.4	134	133	0	30	29
2014	9	1	16	42	18	0.19	0.013	0.741	0.036	0.033	0	43.4	44.3	75.3	131	132	0	30	29
2014	9	1	16	52	18	0.266	-0.013	0.741	0.036	0.033	0	43.9	45.2	74.8	132	134	0	30	29
2014	9	1	17	2	18	0.236	-0.007	0.741	0.036	0.033	0	43.4	43.9	75.7	131	131	0	30	29
2014	9	1	17	12	18	0.243	0.092	0.741	0.039	0.036	0	42.6	43	75.7	130	129	0	31	29
2014	9	1	17	22	18	0.194	-0.026	0.741	0.039	0.036	0	43	42.1	74.8	130	127	0	30	29
2014	9	1	17	32	18	0.174	0.043	0.741	0.039	0.036	0	42.1	41.3	75.3	127	126	0	29	30
2014	9	1	17	42	18	0.22	0.062	0.738	0.036	0.033	0	42.1	41.7	74.8	128	126	0	30	29
2014	9	1	17	52	18	0.151	0.049	0.741	0.043	0.039	0	40.9	40	76.1	125	123	0	30	30
2014	9	1	18	2	18	0.164	0.016	0.738	0.036	0.033	0	41.3	41.3	75.3	127	125	0	31	29
2014	9	1	18	12	18	0.226	0	0.738	0.039	0.036	0	40.9	40.9	74.8	125	124	0	30	29
2014	9	1	18	22	18	0.187	0.049	0.738	0.036	0.033	0	41.3	40.9	75.3	127	124	0	31	29
2014	9	1	18	32	18	0.217	0.026	0.738	0.036	0.033	0	41.7	40.9	74.4	127	124	0	30	29
2014	9	1	18	42	18	0.187	-0.01	0.738	0.036	0.033	0	41.7	41.3	75.3	127	125	0	30	29
2014	9	1	18	52	18	0.19	-0.003	0.738	0.039	0.036	0	42.1	41.3	74.8	127	125	0	29	29
2014	9	1	19	2	18	0.253	0.039	0.738	0.039	0.036	0	41.7	41.3	75.3	127	125	0	30	29
2014	9	1	19	12	18	0.171	-0.066	0.738	0.036	0.033	0	40.9	41.7	74.8	126	126	0	31	29
2014	9	1	19	22	18	0.131	0.046	0.738	0.039	0.036	0	43	41.3	74.4	130	126	0	30	30
2014	9	1	19	32	18	0.161	0.003	0.738	0.036	0.033	0	42.6	41.7	74.8	129	127	0	30	30
2014	9	1	19	42	18	0.112	-0.023	0.738	0.039	0.036	0	43	43	73.5	130	129	0	30	29
2014	9	1	19	52	18	0.249	0.075	0.738	0.039	0.036	0	42.1	42.1	75.3	129	127	0	31	29
2014	9	1	20	2	18	0.236	0.039	0.738	0.033	0.03	0	43.4	42.1	75.3	131	128	0	30	30
2014	9	1	20	12	18	0.164	0.007	0.738	0.033	0.03	0	43	42.1	75.3	130	128	0	30	30
2014	9	1	20	22	18	0.197	0	0.738	0.036	0.033	0	43	43	74.8	130	129	0	30	29
2014	9	1	20	32	18	0.138	-0.026	0.738	0.033	0.03	0	43.9	43	74.8	132	129	0	30	29
2014	9	1	20	42	18	0.177	0.036	0.738	0.036	0.033	0	44.3	43.9	74.4	133	132	0	30	30
2014	9	1	20	52	18	0.141	-0.069	0.735	0.033	0.03	0	45.6	44.3	71.4	136	133	0	30	30
2014	9	1	21	2	18	0.174	-0.013	0.738	0.039	0.036	0	45.6	43.9	73.5	136	131	0	30	29
2014	9	1	21	12	18	0.194	-0.003	0.738	0.033	0.03	0	46	45.2	73.5	138	135	0	31	30
2014	9	1	21	22	18	0.194	0.01	0.738	0.033	0.03	0	46.4	45.2	73.5	138	134	0	30	29
2014	9	1	21	32	18	0.18	0.016	0.738	0.036	0.033	0	45.2	44.3	74.8	135	133	0	30	30
2014	9	1	21	42	18	0.223	-0.056	0.738	0.033	0.03	0	43.4	43.4	74.4	131	130	0	30	29
2014	9	1	21	52	18	0.259	0.049	0.738	0.039	0.036	0	43.9	43.4	74.4	132	130	0	30	29
2014	9	1	22	2	18	0.197	-0.046	0.738	0.033	0.03	0	43.4	43.4	75.7	131	130	0	30	29
2014	9	1	22	12	18	0.108	0	0.738	0.036	0.033	0	43.9	43	74.8	133	130	0	31	30
2014	9	1	22	22	18	0.23	-0.039	0.738	0.036	0.033	0	43.9	43.9	75.3	133	132	0	31	30
2014	9	1	22	32	18	0.197	-0.023	0.738	0.036	0.033	0	43.4	44.3	74.8	132	132	0	31	29
2014	9	1	22	42	18	0.21	-0.049	0.738	0.033	0.03	0	44.7	43.9	75.3	134	132	0	30	30
2014	9	1	22	52	18	0.22	-0.039	0.738	0.033	0.03	0	44.7	43.4	75.3	134	131	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	23	2	18	0.184	-0.023	0.738	0.033	0.03	0	44.7	44.3	75.7	134	132	0	30	29
2014	9	1	23	12	18	0.217	-0.003	0.738	0.033	0.03	0	44.7	44.3	75.3	134	133	0	30	30
2014	9	1	23	22	18	0.18	0	0.738	0.033	0.03	0	44.7	44.7	75.3	134	134	0	30	30
2014	9	1	23	32	18	0.171	-0.026	0.738	0.033	0.03	0	44.7	43.9	75.7	134	132	0	30	30
2014	9	1	23	42	18	0.18	0.075	0.738	0.033	0.03	0	45.6	43.9	74.8	136	132	0	30	30
2014	9	1	23	52	18	0.164	0.066	0.738	0.036	0.033	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	2	0	2	18	0.207	0.046	0.735	0.039	0.036	0	45.2	45.2	75.3	135	135	0	30	30
2014	9	2	0	12	18	0.141	-0.02	0.738	0.036	0.033	0	44.7	44.7	75.7	134	134	0	30	30
2014	9	2	0	22	18	0.18	-0.026	0.735	0.033	0.03	0	45.2	45.2	74.8	136	135	0	31	30
2014	9	2	0	32	18	0.151	0.013	0.735	0.03	0.03	0	44.7	44.7	75.7	135	134	0	31	30
2014	9	2	0	42	18	0.18	-0.01	0.735	0.036	0.033	0	45.6	45.2	75.3	136	135	0	30	30
2014	9	2	0	52	18	0.18	-0.072	0.735	0.036	0.033	0	44.7	44.7	75.3	135	134	0	31	30
2014	9	2	1	2	18	0.135	0	0.735	0.036	0.033	0	44.3	45.2	75.3	134	134	0	31	29
2014	9	2	1	12	18	0.131	-0.066	0.735	0.033	0.03	0	43.9	44.3	75.7	133	133	0	31	30
2014	9	2	1	22	18	0.148	-0.066	0.735	0.039	0.036	0	44.7	44.7	75.3	134	134	0	30	30
2014	9	2	1	32	18	0.18	-0.02	0.735	0.033	0.03	0	43.9	44.3	75.3	133	133	0	31	30
2014	9	2	1	42	18	0.18	-0.023	0.735	0.033	0.03	0	44.3	43.9	74.8	134	132	0	31	30
2014	9	2	1	52	18	0.171	-0.072	0.735	0.033	0.03	0	45.2	44.3	74.8	136	133	0	31	30
2014	9	2	2	2	18	0.174	-0.02	0.735	0.033	0.03	0	44.3	44.7	74.4	134	135	0	31	31
2014	9	2	2	12	18	0.164	-0.003	0.735	0.033	0.03	0	45.2	44.7	74.8	136	134	0	31	30
2014	9	2	2	22	18	0.125	-0.059	0.735	0.039	0.036	0	45.2	45.2	74.4	135	134	0	30	29
2014	9	2	2	32	18	0.23	-0.02	0.735	0.039	0.036	0	44.3	43.9	74.8	134	132	0	31	30
2014	9	2	2	42	18	0.085	-0.003	0.735	0.033	0.03	0	43.9	43.9	74.8	133	131	0	31	29
2014	9	2	2	52	18	0.213	-0.03	0.735	0.033	0.03	0	43	43	74.8	131	130	0	31	30
2014	9	2	3	2	18	0.128	0	0.735	0.033	0.03	0	43.9	42.6	75.3	133	129	0	31	30
2014	9	2	3	12	18	0.194	-0.066	0.735	0.033	0.03	0	43.9	43	75.3	133	130	0	31	30
2014	9	2	3	22	18	0.19	-0.046	0.735	0.033	0.03	0	43.4	43	74.8	131	130	0	30	30
2014	9	2	3	32	18	0.066	-0.046	0.735	0.039	0.036	0	43.4	42.1	75.7	132	128	0	31	30
2014	9	2	3	42	18	0.098	-0.066	0.735	0.033	0.03	0	43.4	42.6	75.7	132	130	0	31	31
2014	9	2	3	52	18	0.167	-0.016	0.735	0.036	0.033	0	43.9	43.4	74.8	133	132	0	31	31
2014	9	2	4	2	18	0.161	-0.072	0.735	0.039	0.036	0	44.7	43.9	75.3	135	132	0	31	30
2014	9	2	4	12	18	0.141	-0.036	0.735	0.036	0.033	0	43.9	43.9	75.7	134	132	0	32	30
2014	9	2	4	22	18	0.194	-0.033	0.735	0.036	0.033	0	43.4	41.7	74.8	131	128	0	30	31
2014	9	2	4	32	18	0.098	0.003	0.735	0.033	0.03	0	43.9	43	75.3	133	131	0	31	31
2014	9	2	4	42	18	0.102	-0.016	0.735	0.033	0.03	0	43	43	74.8	130	130	0	30	30
2014	9	2	4	52	18	0.138	-0.043	0.732	0.033	0.03	0	43.9	43.4	74.8	132	131	0	30	30
2014	9	2	5	2	18	0.141	-0.03	0.732	0.043	0.039	0	43	43	74.8	131	130	0	31	30
2014	9	2	5	12	18	0.144	0	0.732	0.033	0.03	0	43	43	74.4	132	131	0	32	31
2014	9	2	5	22	18	0.157	-0.066	0.732	0.033	0.03	0	43	43.4	75.3	131	131	0	31	30
2014	9	2	5	32	18	0.203	0.026	0.732	0.039	0.039	0	42.6	43	75.3	130	130	0	31	30
2014	9	2	5	42	18	0.24	0	0.732	0.033	0.03	0	43	42.6	75.3	131	130	0	31	31
2014	9	2	5	52	18	0.174	-0.052	0.732	0.033	0.03	0	43.4	42.6	74.4	132	129	0	31	30
2014	9	2	6	2	18	0.18	0.066	0.732	0.036	0.033	0	42.6	42.6	75.3	130	129	0	31	30
2014	9	2	6	12	18	0.144	-0.013	0.732	0.039	0.036	0	43.4	43.9	73.5	132	131	0	31	29
2014	9	2	6	22	18	0.157	0	0.732	0.036	0.033	0	42.1	41.3	75.7	129	126	0	31	30
2014	9	2	6	32	18	0.098	-0.082	0.732	0.033	0.03	0	42.1	42.6	75.3	130	129	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	6	42	18	0.128	-0.056	0.732	0.033	0.03	0	41.7	40.4	76.1	128	125	0	31	31
2014	9	2	6	52	18	0.184	-0.039	0.732	0.043	0.039	0	40.9	40.9	76.5	126	125	0	31	30
2014	9	2	7	2	18	0.174	0.016	0.732	0.033	0.03	0	42.1	41.3	76.1	129	126	0	31	30
2014	9	2	7	12	18	0.151	-0.023	0.732	0.033	0.03	0	40.9	41.3	75.3	126	126	0	31	30
2014	9	2	7	22	18	0.141	0.003	0.732	0.036	0.033	0	41.3	40	76.1	126	124	0	30	31
2014	9	2	7	32	18	0.22	0	0.732	0.036	0.033	0	41.7	41.3	75.3	128	127	0	31	31
2014	9	2	7	42	18	0.161	-0.036	0.732	0.033	0.03	0	39.6	40.4	76.5	124	124	0	32	30
2014	9	2	7	52	18	0.22	-0.049	0.732	0.033	0.03	0	42.1	42.1	76.1	129	128	0	31	30
2014	9	2	8	2	18	0.177	-0.062	0.732	0.03	0.03	0	42.1	42.1	75.7	129	128	0	31	30
2014	9	2	8	12	18	0.19	0	0.732	0.033	0.03	0	41.7	41.7	76.1	128	127	0	31	30
2014	9	2	8	22	18	0.18	-0.043	0.732	0.033	0.03	0	41.3	41.7	76.1	127	127	0	31	30
2014	9	2	8	32	18	0.177	-0.023	0.732	0.033	0.03	0	40.9	41.7	76.1	126	127	0	31	30
2014	9	2	8	42	18	0.112	0	0.732	0.036	0.033	0	41.7	40.9	76.1	128	126	0	31	31
2014	9	2	8	52	18	0.249	0	0.732	0.033	0.03	0	41.3	40.9	75.7	127	125	0	31	30
2014	9	2	9	2	18	0.19	-0.036	0.732	0.043	0.039	0	41.3	40	75.3	127	124	0	31	31
2014	9	2	9	12	18	0.131	0	0.732	0.033	0.03	0	41.7	41.7	75.7	128	127	0	31	30
2014	9	2	9	22	18	0.187	0.003	0.732	0.036	0.033	0	41.7	40.9	75.3	128	126	0	31	31
2014	9	2	9	32	18	0.115	0.01	0.732	0.033	0.03	0	43.4	44.3	74	132	133	0	31	30
2014	9	2	9	42	18	0.18	0.01	0.732	0.036	0.033	0	43	44.7	74.8	132	134	0	32	30
2014	9	2	9	52	18	0.24	-0.007	0.728	0.033	0.03	0	43.9	44.3	74.4	133	133	0	31	30
2014	9	2	10	2	18	0.154	0.036	0.728	0.036	0.033	0	43.9	45.6	74.4	133	136	0	31	30
2014	9	2	10	12	18	0.141	-0.007	0.732	0.033	0.033	0	43	45.2	74.8	131	135	0	31	30
2014	9	2	10	22	18	0.19	-0.023	0.728	0.033	0.03	0	43.9	45.2	73.5	132	135	0	30	30
2014	9	2	10	32	18	0.203	0.01	0.728	0.033	0.033	0	43.4	45.2	73.5	132	136	0	31	31
2014	9	2	10	42	18	0.197	-0.02	0.728	0.033	0.03	0	45.2	46	72.7	136	138	0	31	31
2014	9	2	10	52	18	0.197	0.075	0.732	0.036	0.033	0	43.9	45.6	72.7	134	136	0	32	30
2014	9	2	11	2	18	0.177	-0.079	0.728	0.036	0.033	0	43.9	46	73.5	133	137	0	31	30
2014	9	2	11	12	18	0.112	-0.007	0.728	0.033	0.03	0	44.7	46.4	73.5	135	138	0	31	30
2014	9	2	11	22	18	0.141	0.01	0.728	0.033	0.03	0	44.7	46.4	73.5	136	138	0	32	30
2014	9	2	11	32	18	0.22	0.075	0.732	0.033	0.03	0	46.4	47.3	74	139	140	0	31	30
2014	9	2	11	42	18	0.177	0.016	0.732	0.033	0.03	0	46.4	47.7	73.5	139	142	0	31	31
2014	9	2	11	52	18	0.233	-0.013	0.732	0.033	0.03	0	46	47.3	74	138	141	0	31	31
2014	9	2	12	2	18	0.233	0	0.735	0.033	0.03	0	46.4	47.7	74	139	141	0	31	30
2014	9	2	12	12	18	0.151	0.023	0.735	0.036	0.033	0	46.9	48.6	73.5	140	144	0	31	31
2014	9	2	12	22	18	0.19	0.016	0.735	0.039	0.036	0	46.9	47.7	74	139	141	0	30	30
2014	9	2	12	32	18	0.154	0.043	0.738	0.033	0.03	0	46.4	48.2	74	138	143	0	30	31
2014	9	2	12	42	18	0.22	0.026	0.738	0.033	0.03	0	46	47.3	74	137	140	0	30	30
2014	9	2	12	52	18	0.19	0.016	0.738	0.033	0.03	0	45.6	47.7	73.1	137	141	0	31	30
2014	9	2	13	2	18	0.19	0.03	0.738	0.033	0.03	0	45.6	48.2	74.4	137	141	0	31	29
2014	9	2	13	12	18	0.207	0.069	0.741	0.036	0.033	0	46	47.7	73.5	138	141	0	31	30
2014	9	2	13	22	18	0.105	0.085	0.741	0.036	0.033	0	47.3	48.6	72.2	141	143	0	31	30
2014	9	2	13	32	18	0.223	-0.03	0.741	0.033	0.03	0	46.9	48.2	72.7	139	142	0	30	30
2014	9	2	13	42	18	0.207	-0.007	0.741	0.03	0.03	0	46	47.3	72.2	138	140	0	31	30
2014	9	2	13	52	18	0.226	0.01	0.745	0.033	0.03	0	46	47.3	71.8	138	140	0	31	30
2014	9	2	14	2	18	0.276	0.144	0.745	0.033	0.03	0	46.9	47.7	72.2	140	141	0	31	30
2014	9	2	14	12	18	0.243	0.075	0.745	0.039	0.036	0	46.4	47.3	71.4	138	140	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	14	22	18	0.128	0.043	0.748	0.036	0.033	0	46.4	48.2	71.4	138	141	0	30	29
2014	9	2	14	32	18	0.243	0.052	0.748	0.043	0.039	0	45.6	46.9	71.8	136	139	0	30	30
2014	9	2	14	42	18	0.272	0.092	0.748	0.033	0.03	0	46.9	47.3	70.5	139	139	0	30	29
2014	9	2	14	52	18	0.256	0.112	0.748	0.033	0.03	0	46	46.4	70.5	137	138	0	30	30
2014	9	2	15	2	18	0.249	0.128	0.751	0.033	0.03	0	46.9	47.3	70.5	139	139	0	30	29
2014	9	2	15	12	18	0.262	0.144	0.751	0.033	0.03	0	46.4	46.4	70.1	138	138	0	30	30
2014	9	2	15	22	18	0.217	0.121	0.755	0.036	0.033	0	46	46.4	70.5	137	138	0	30	30
2014	9	2	15	32	18	0.249	0.092	0.758	0.036	0.033	0	46	46.9	69.7	137	139	0	30	30
2014	9	2	15	42	18	0.305	0.112	0.764	0.033	0.03	0	46	45.6	70.1	137	136	0	30	30
2014	9	2	15	52	18	0.226	0.069	0.761	0.036	0.033	0	47.7	46.9	69.2	141	139	0	30	30
2014	9	2	16	2	18	0.285	0.075	0.768	0.039	0.036	0	45.2	46.9	71	135	138	0	30	29
2014	9	2	16	12	18	0.226	0.033	0.768	0.033	0.03	0	45.6	46	70.1	136	137	0	30	30
2014	9	2	16	22	18	0.279	0.089	0.771	0.033	0.03	0	45.6	45.2	71.8	136	135	0	30	30
2014	9	2	16	32	18	0.282	0.092	0.771	0.036	0.033	0	45.2	46	71	135	136	0	30	29
2014	9	2	16	42	18	0.24	0.033	0.771	0.036	0.033	0	45.6	45.6	71.4	136	136	0	30	30
2014	9	2	16	52	18	0.217	0.167	0.771	0.033	0.03	0	45.6	46	71	136	136	0	30	29
2014	9	2	17	2	18	0.335	0.148	0.774	0.039	0.036	0	44.3	45.2	71.8	133	134	0	30	29
2014	9	2	17	12	18	0.217	0.098	0.774	0.039	0.036	0	44.7	43.9	72.2	134	132	0	30	30
2014	9	2	17	22	18	0.259	0.187	0.774	0.039	0.036	0	43.9	43.9	73.1	132	131	0	30	29
2014	9	2	17	32	18	0.292	0.167	0.774	0.033	0.03	0	43.9	42.6	73.1	132	129	0	30	30
2014	9	2	17	42	18	0.226	0.207	0.778	0.033	0.03	0	43.4	43	74.4	131	129	0	30	29
2014	9	2	17	52	18	0.253	0.062	0.778	0.036	0.033	0	43	42.1	74.4	130	128	0	30	30
2014	9	2	18	2	18	0.207	0.089	0.778	0.033	0.03	0	43	42.1	74.8	130	127	0	30	29
2014	9	2	18	12	18	0.24	0.115	0.778	0.036	0.033	0	43.4	42.6	74.8	131	128	0	30	29
2014	9	2	18	22	18	0.21	0.105	0.778	0.033	0.03	0	44.3	43	74.8	132	129	0	29	29
2014	9	2	18	32	18	0.223	0.161	0.781	0.033	0.03	0	42.1	41.3	76.1	128	126	0	30	30
2014	9	2	18	42	18	0.282	0.036	0.781	0.039	0.039	0	42.1	40.9	76.1	128	125	0	30	30
2014	9	2	18	52	18	0.197	0.036	0.781	0.033	0.03	0	43.4	42.6	77	131	129	0	30	30
2014	9	2	19	2	18	0.24	0.059	0.781	0.036	0.033	0	42.1	41.7	76.5	128	126	0	30	29
2014	9	2	19	12	18	0.223	0.016	0.781	0.033	0.03	0	42.1	41.7	76.5	128	127	0	30	30
2014	9	2	19	22	18	0.217	-0.003	0.781	0.03	0.03	0	43	42.6	77	130	128	0	30	29
2014	9	2	19	32	18	0.22	0.016	0.781	0.033	0.03	0	43	42.6	75.7	130	129	0	30	30
2014	9	2	19	42	18	0.243	0.023	0.781	0.033	0.03	0	44.3	43.4	76.1	133	130	0	30	29
2014	9	2	19	52	18	0.207	-0.036	0.784	0.039	0.036	0	43	41.7	75.7	130	127	0	30	30
2014	9	2	20	2	18	0.233	0.01	0.784	0.039	0.036	0	43	43	75.7	131	130	0	31	30
2014	9	2	20	12	18	0.171	0.043	0.784	0.036	0.033	0	43	43.4	75.7	131	130	0	31	29
2014	9	2	20	22	18	0.197	0.016	0.784	0.033	0.03	0	43.4	42.1	75.3	131	128	0	30	30
2014	9	2	20	32	18	0.256	-0.003	0.784	0.036	0.033	0	43.9	43.4	74.8	132	131	0	30	30
2014	9	2	20	42	18	0.285	-0.056	0.784	0.033	0.03	0	44.7	44.3	74.4	135	132	0	31	29
2014	9	2	20	52	18	0.259	0.039	0.784	0.033	0.03	0	43.4	43.4	74.8	132	130	0	31	29
2014	9	2	21	2	18	0.187	0	0.787	0.033	0.03	0	43.9	43.9	74	133	132	0	31	30
2014	9	2	21	12	18	0.164	0.03	0.787	0.033	0.03	0	43.9	43.4	74	132	131	0	30	30
2014	9	2	21	22	18	0.262	-0.036	0.787	0.036	0.033	0	43.9	43.9	74	132	131	0	30	29
2014	9	2	21	32	18	0.315	-0.125	0.787	0.033	0.03	0	43.4	43.9	74	132	131	0	31	29
2014	9	2	21	42	18	0.213	0.016	0.787	0.033	0.03	0	44.3	43	72.7	134	130	0	31	30
2014	9	2	21	52	18	0.187	-0.072	0.787	0.033	0.03	0	43.9	42.6	74	132	129	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	22	2	18	0.236	-0.02	0.787	0.03	0.03	0	43.4	43.4	72.7	131	130	0	30	29
2014	9	2	22	12	18	0.325	0.079	0.787	0.036	0.033	0	42.1	41.7	73.5	129	127	0	31	30
2014	9	2	22	22	18	0.282	-0.003	0.787	0.033	0.03	0	43.4	43.4	73.1	131	130	0	30	29
2014	9	2	22	32	18	0.236	-0.089	0.791	0.039	0.039	0	43.9	43.4	72.7	132	131	0	30	30
2014	9	2	22	42	18	0.292	-0.013	0.787	0.039	0.036	0	43.4	43.9	71.8	132	131	0	31	29
2014	9	2	22	52	18	0.292	-0.007	0.787	0.036	0.033	0	43	43.4	72.2	131	130	0	31	29
2014	9	2	23	2	18	0.289	-0.036	0.791	0.033	0.03	0	43.9	42.6	72.7	132	129	0	30	30
2014	9	2	23	12	18	0.259	0.003	0.791	0.036	0.033	0	42.6	42.6	72.2	130	129	0	31	30
2014	9	2	23	22	18	0.276	0	0.794	0.033	0.03	0	43.4	42.6	71.8	132	129	0	31	30
2014	9	2	23	32	18	0.374	0.049	0.794	0.033	0.03	0	43	43	72.2	131	130	0	31	30
2014	9	2	23	42	18	0.325	-0.03	0.797	0.033	0.03	0	43.9	43.4	71.8	132	131	0	30	30
2014	9	2	23	52	18	0.203	0.003	0.797	0.033	0.03	0	43.9	43.9	71.8	132	131	0	30	29
2014	9	3	0	2	18	0.24	-0.036	0.797	0.033	0.03	0	43.9	43.4	72.7	132	131	0	30	30
2014	9	3	0	12	18	0.233	-0.03	0.794	0.033	0.03	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	3	0	22	18	0.151	-0.02	0.791	0.039	0.036	0	43	43	71.4	131	129	0	31	29
2014	9	3	0	32	18	0.243	0.049	0.791	0.036	0.033	0	43	43	71.8	130	130	0	30	30
2014	9	3	0	42	18	0.246	-0.007	0.791	0.036	0.033	0	43.4	43.4	71.8	132	131	0	31	30
2014	9	3	0	52	18	0.328	-0.036	0.791	0.039	0.036	0	43	43	72.2	131	130	0	31	30
2014	9	3	1	2	18	0.262	-0.039	0.794	0.039	0.036	0	43.4	42.1	71	132	129	0	31	31
2014	9	3	1	12	18	0.207	0	0.794	0.033	0.03	0	43	42.6	71.8	131	129	0	31	30
2014	9	3	1	22	18	0.266	-0.026	0.794	0.033	0.03	0	43.4	43.4	71.8	132	131	0	31	30
2014	9	3	1	32	18	0.269	-0.02	0.797	0.036	0.033	0	43.4	43.4	71	132	131	0	31	30
2014	9	3	1	42	18	0.197	-0.039	0.801	0.036	0.033	0	43.9	43.4	71	133	131	0	31	30
2014	9	3	1	52	18	0.213	-0.023	0.801	0.033	0.03	0	43	43	71.8	131	130	0	31	30
2014	9	3	2	2	18	0.21	0.026	0.801	0.036	0.033	0	43	43	72.2	131	130	0	31	30
2014	9	3	2	12	18	0.269	0.052	0.801	0.043	0.039	0	43.9	42.6	72.7	133	130	0	31	31
2014	9	3	2	22	18	0.233	-0.066	0.801	0.036	0.033	0	44.3	43.9	72.7	133	132	0	30	30
2014	9	3	2	32	18	0.22	-0.003	0.801	0.039	0.036	0	43.9	43.9	71.4	133	132	0	31	30
2014	9	3	2	42	18	0.249	0.052	0.801	0.036	0.033	0	43.9	43.4	72.2	132	131	0	30	30
2014	9	3	2	52	18	0.236	-0.016	0.801	0.033	0.03	0	43	43.4	72.2	131	131	0	31	30
2014	9	3	3	2	18	0.246	0.007	0.801	0.036	0.033	0	43.9	43	72.7	133	131	0	31	31
2014	9	3	3	12	18	0.23	0	0.801	0.033	0.03	0	43	43.4	72.2	131	131	0	31	30
2014	9	3	3	22	18	0.223	-0.069	0.801	0.033	0.03	0	43.9	43	72.7	133	130	0	31	30
2014	9	3	3	32	18	0.217	-0.052	0.801	0.033	0.03	0	43.9	43.9	72.2	134	132	0	32	30
2014	9	3	3	42	18	0.269	-0.016	0.801	0.033	0.03	0	44.7	43.9	72.2	134	132	0	30	30
2014	9	3	3	52	18	0.19	-0.079	0.801	0.03	0.03	0	44.7	44.7	71.4	135	134	0	31	30
2014	9	3	4	2	18	0.249	-0.02	0.801	0.033	0.03	0	44.7	43.9	71.8	135	132	0	31	30
2014	9	3	4	12	18	0.259	0	0.797	0.039	0.036	0	46	45.6	71.4	138	136	0	31	30
2014	9	3	4	22	18	0.246	-0.023	0.794	0.039	0.036	0	47.3	46.4	68.8	141	139	0	31	31
2014	9	3	4	32	18	0.22	0.049	0.794	0.033	0.03	0	46	45.6	69.2	138	136	0	31	30
2014	9	3	4	42	18	0.249	-0.026	0.794	0.033	0.03	0	45.2	44.7	70.1	136	134	0	31	30
2014	9	3	4	52	18	0.295	-0.023	0.794	0.036	0.033	0	44.3	44.3	71.4	134	133	0	31	30
2014	9	3	5	2	18	0.312	0.007	0.794	0.039	0.036	0	43.4	43.4	71.4	132	131	0	31	30
2014	9	3	5	12	18	0.272	-0.036	0.794	0.033	0.03	0	43	43.9	71.8	132	132	0	32	30
2014	9	3	5	22	18	0.233	0.039	0.797	0.036	0.033	0	43	43	71.4	131	130	0	31	30
2014	9	3	5	32	18	0.282	-0.033	0.794	0.039	0.036	0	43.4	43	71.8	132	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	5	42	18	0.256	0.03	0.794	0.033	0.03	0	43.9	43.4	71.8	133	132	0	31	31
2014	9	3	5	52	18	0.282	0.016	0.797	0.033	0.03	0	43.4	43	71.4	132	130	0	31	30
2014	9	3	6	2	18	0.22	-0.026	0.797	0.033	0.03	0	42.6	43	71.8	130	130	0	31	30
2014	9	3	6	12	18	0.269	-0.033	0.794	0.036	0.033	0	43	43	71.4	131	130	0	31	30
2014	9	3	6	22	18	0.21	-0.052	0.797	0.036	0.033	0	42.6	42.1	72.2	130	128	0	31	30
2014	9	3	6	32	18	0.21	0.026	0.797	0.039	0.039	0	43	42.1	72.2	130	128	0	30	30
2014	9	3	6	42	18	0.285	0	0.797	0.033	0.033	0	41.7	42.1	73.1	128	128	0	31	30
2014	9	3	6	52	18	0.177	-0.013	0.797	0.039	0.036	0	41.3	40.9	72.7	127	125	0	31	30
2014	9	3	7	2	18	0.243	-0.052	0.797	0.036	0.033	0	40.4	40.9	72.7	125	125	0	31	30
2014	9	3	7	12	18	0.161	0.023	0.797	0.033	0.03	0	41.3	40.9	74	127	126	0	31	31
2014	9	3	7	22	18	0.23	0.003	0.797	0.033	0.03	0	40	40	73.1	125	123	0	32	30
2014	9	3	7	32	18	0.223	0.03	0.797	0.033	0.03	0	41.3	41.7	73.1	127	127	0	31	30
2014	9	3	7	42	18	0.302	-0.02	0.797	0.033	0.03	0	41.3	40.9	73.1	127	126	0	31	31
2014	9	3	7	52	18	0.236	0.059	0.797	0.039	0.036	0	41.3	40.4	73.1	127	125	0	31	31
2014	9	3	8	2	18	0.24	-0.036	0.797	0.039	0.036	0	41.7	42.6	72.7	128	129	0	31	30
2014	9	3	8	12	18	0.312	0.013	0.794	0.036	0.033	0	41.7	41.7	72.2	128	127	0	31	30
2014	9	3	8	22	18	0.21	-0.01	0.797	0.033	0.03	0	41.3	40.9	72.7	127	125	0	31	30
2014	9	3	8	32	18	0.289	0.007	0.797	0.033	0.033	0	40.9	41.7	72.7	126	127	0	31	30
2014	9	3	8	42	18	0.295	-0.013	0.794	0.033	0.03	0	42.1	41.3	72.2	129	126	0	31	30
2014	9	3	8	52	18	0.243	-0.016	0.794	0.033	0.03	0	42.1	40.9	72.2	129	126	0	31	31
2014	9	3	9	2	18	0.203	-0.036	0.794	0.036	0.033	0	41.7	41.7	72.2	128	127	0	31	30
2014	9	3	9	12	18	0.194	0.046	0.787	0.039	0.036	0	50.7	50.3	51.2	151	148	0	33	31
2014	9	3	9	22	18	0.262	-0.03	0.801	0.033	0.03	0	45.2	44.3	71.8	136	134	0	31	31
2014	9	3	9	32	18	0.19	-0.016	0.801	0.033	0.03	0	47.3	46.9	71	141	139	0	31	30
2014	9	3	9	42	18	0.197	-0.036	0.801	0.033	0.03	0	47.3	46.9	71.8	141	140	0	31	31
2014	9	3	9	52	18	0.21	-0.016	0.801	0.033	0.03	0	46.9	47.7	71.8	140	141	0	31	30
2014	9	3	10	2	18	0.285	0.016	0.797	0.033	0.03	0	47.3	47.7	71	141	141	0	31	30
2014	9	3	10	12	18	0.269	0.02	0.797	0.033	0.03	0	48.6	48.6	70.1	144	144	0	31	31
2014	9	3	10	22	18	0.233	0.049	0.797	0.033	0.03	0	48.6	49	70.5	144	145	0	31	31
2014	9	3	10	32	18	0.285	-0.016	0.794	0.039	0.036	0	49	49.9	69.7	145	146	0	31	30
2014	9	3	10	42	18	0.23	-0.013	0.791	0.033	0.03	0	50.3	50.3	69.7	148	147	0	31	30
2014	9	3	10	52	18	0.246	0.01	0.791	0.033	0.03	0	49.9	50.3	69.7	147	147	0	31	30
2014	9	3	11	2	18	0.272	-0.007	0.787	0.033	0.03	0	50.3	50.7	68.8	148	148	0	31	30
2014	9	3	11	12	18	0.23	0.02	0.784	0.033	0.03	0	50.7	51.2	69.7	149	149	0	31	30
2014	9	3	11	22	18	0.213	0	0.784	0.036	0.033	0	50.3	51.6	69.7	147	150	0	30	30
2014	9	3	11	32	18	0.226	0.082	0.781	0.036	0.033	0	51.6	52.5	70.1	151	152	0	31	30
2014	9	3	11	42	18	0.305	0.072	0.781	0.033	0.03	0	51.6	52.5	69.7	151	152	0	31	30
2014	9	3	11	52	18	0.289	-0.03	0.781	0.039	0.036	0	51.6	51.6	69.7	151	151	0	31	31
2014	9	3	12	2	18	0.341	0.095	0.781	0.033	0.03	0	52.9	53.3	70.1	154	154	0	31	30
2014	9	3	12	12	18	0.243	0.049	0.781	0.036	0.033	0	53.3	53.8	67.9	155	155	0	31	30
2014	9	3	12	22	18	0.269	0.079	0.781	0.033	0.03	0	53.3	53.8	68.8	155	155	0	31	30
2014	9	3	12	32	18	0.253	0.069	0.781	0.033	0.03	0	53.8	53.8	69.2	156	155	0	31	30
2014	9	3	12	42	18	0.279	0.112	0.781	0.033	0.03	0	54.6	54.6	69.2	157	157	0	30	30
2014	9	3	12	52	18	0.292	0.148	0.781	0.036	0.033	0	54.2	53.8	70.1	156	155	0	30	30
2014	9	3	13	2	18	0.272	0.069	0.778	0.033	0.03	0	53.3	52.9	71	155	153	0	31	30
2014	9	3	13	12	18	0.331	0.01	0.781	0.033	0.03	0	52.9	52	70.5	154	152	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	13	22	18	0.312	0.066	0.778	0.033	0.03	0	52.5	53.3	72.2	153	154	0	31	30
2014	9	3	13	32	18	0.292	0.023	0.778	0.036	0.033	0	52.5	52.9	72.2	152	152	0	30	29
2014	9	3	13	42	18	0.259	0.043	0.778	0.036	0.033	0	53.8	52.9	71	155	153	0	30	30
2014	9	3	13	52	18	0.256	0.049	0.778	0.033	0.03	0	52.5	52.9	71	152	152	0	30	29
2014	9	3	14	2	18	0.256	0.072	0.778	0.03	0.03	0	51.2	52	71.4	150	151	0	31	30
2014	9	3	14	12	18	0.262	0.023	0.778	0.033	0.03	0	51.6	51.2	71.8	151	149	0	31	30
2014	9	3	14	22	18	0.233	0.075	0.778	0.033	0.03	0	52.5	52.9	72.7	153	152	0	31	29
2014	9	3	14	32	18	0.253	0.089	0.778	0.033	0.03	0	52.5	52	71.4	152	151	0	30	30
2014	9	3	14	42	18	0.243	0.069	0.778	0.033	0.03	0	52.9	51.6	72.2	153	150	0	30	30
2014	9	3	14	52	18	0.259	0.089	0.778	0.033	0.03	0	52.9	52.9	71	153	153	0	30	30
2014	9	3	15	2	18	0.276	0.056	0.778	0.033	0.03	0	49.9	51.6	71.8	147	149	0	31	29
2014	9	3	15	12	18	0.331	0.039	0.774	0.03	0.03	0	51.6	52	71	150	150	0	30	29
2014	9	3	15	22	18	0.246	0.039	0.774	0.033	0.03	0	51.2	50.7	72.2	149	148	0	30	30
2014	9	3	15	32	18	0.295	0.066	0.774	0.039	0.039	0	50.3	50.7	71.4	147	147	0	30	29
2014	9	3	15	42	18	0.246	0.023	0.774	0.036	0.033	0	51.6	51.2	70.5	150	148	0	30	29
2014	9	3	15	52	18	0.23	0.023	0.774	0.033	0.03	0	52	51.2	69.2	151	148	0	30	29
2014	9	3	16	2	18	0.18	0.039	0.774	0.033	0.03	0	52	52	70.5	151	150	0	30	29
2014	9	3	16	12	18	0.217	0.043	0.774	0.033	0.03	0	50.3	50.7	71	148	147	0	31	29
2014	9	3	16	22	18	0.213	0.007	0.771	0.033	0.03	0	50.7	50.7	70.5	148	147	0	30	29
2014	9	3	16	32	18	0.256	0.059	0.771	0.033	0.03	0	50.7	50.3	69.7	148	146	0	30	29
2014	9	3	16	42	18	0.223	0.049	0.771	0.033	0.03	0	50.7	51.6	70.1	148	149	0	30	29
2014	9	3	16	52	18	0.289	0.049	0.771	0.033	0.03	0	50.7	49.9	70.1	147	145	0	29	29
2014	9	3	17	2	18	0.213	0.102	0.771	0.033	0.03	0	49.9	50.3	68.8	146	146	0	30	29
2014	9	3	17	12	18	0.22	0	0.771	0.033	0.03	0	51.2	49.5	68.8	149	144	0	30	29
2014	9	3	17	22	18	0.171	0.059	0.768	0.036	0.033	0	49	48.2	69.2	144	141	0	30	29
2014	9	3	17	32	18	0.256	0.033	0.771	0.033	0.03	0	48.6	46.9	71	143	138	0	30	29
2014	9	3	17	42	18	0.24	0.01	0.771	0.036	0.033	0	46	44.7	71	138	132	0	31	28
2014	9	3	17	52	18	0.266	0.033	0.768	0.039	0.036	0	43.4	42.1	71.8	132	127	0	31	29
2014	9	3	18	2	18	0.243	0.062	0.768	0.039	0.036	0	43	42.6	71.8	130	128	0	30	29
2014	9	3	18	12	18	0.279	0.049	0.768	0.039	0.039	0	42.6	42.1	71.8	129	127	0	30	29
2014	9	3	18	22	18	0.207	0.03	0.768	0.033	0.03	0	42.1	41.7	72.7	128	126	0	30	29
2014	9	3	18	32	18	0.194	0.036	0.768	0.033	0.03	0	40.9	41.7	72.7	126	125	0	31	28
2014	9	3	18	42	18	0.23	-0.03	0.768	0.033	0.03	0	40.9	40.4	73.1	125	124	0	30	30
2014	9	3	18	52	18	0.21	0.036	0.768	0.036	0.033	0	40.9	40.4	73.1	125	123	0	30	29
2014	9	3	19	2	18	0.24	0.115	0.768	0.039	0.039	0	40.9	39.6	73.1	125	121	0	30	29
2014	9	3	19	12	18	0.256	-0.01	0.768	0.033	0.03	0	44.3	43.4	71.8	133	130	0	30	29
2014	9	3	19	22	18	0.226	0.003	0.768	0.036	0.033	0	42.1	42.6	72.2	129	128	0	31	29
2014	9	3	19	32	18	0.213	-0.039	0.768	0.039	0.036	0	41.3	41.3	73.1	127	126	0	31	30
2014	9	3	19	42	18	0.164	-0.02	0.768	0.039	0.036	0	41.7	40.9	73.1	127	125	0	30	30
2014	9	3	19	52	18	0.177	0.01	0.768	0.036	0.033	0	42.1	42.6	72.7	129	128	0	31	29
2014	9	3	20	2	18	0.207	0	0.768	0.033	0.03	0	42.6	43	72.7	130	129	0	31	29
2014	9	3	20	12	18	0.243	0.01	0.768	0.039	0.036	0	43	43	72.7	130	129	0	30	29
2014	9	3	20	22	18	0.187	0.02	0.768	0.033	0.033	0	43.9	42.6	71.8	132	129	0	30	30
2014	9	3	20	32	18	0.203	0	0.768	0.033	0.03	0	43.4	42.6	72.7	131	129	0	30	30
2014	9	3	20	42	18	0.164	0.023	0.768	0.036	0.033	0	42.6	42.1	72.2	130	128	0	31	30
2014	9	3	20	52	18	0.256	0.026	0.768	0.033	0.03	0	43	42.1	72.2	130	128	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	21	2	18	0.236	-0.03	0.768	0.036	0.033	0	43.4	42.6	72.7	131	129	0	30	30
2014	9	3	21	12	18	0.21	-0.02	0.771	0.033	0.03	0	43	42.6	72.7	131	129	0	31	30
2014	9	3	21	22	18	0.292	-0.023	0.771	0.039	0.036	0	43.4	43	73.5	131	130	0	30	30
2014	9	3	21	32	18	0.24	0.02	0.771	0.039	0.036	0	44.7	43	73.5	134	129	0	30	29
2014	9	3	21	42	18	0.184	-0.02	0.771	0.033	0.03	0	44.3	43	73.1	133	130	0	30	30
2014	9	3	21	52	18	0.246	0.036	0.771	0.039	0.039	0	45.2	44.3	72.7	135	132	0	30	29
2014	9	3	22	2	18	0.266	0	0.771	0.036	0.033	0	43.9	43	74	132	130	0	30	30
2014	9	3	22	12	18	0.299	0.043	0.771	0.033	0.03	0	43.4	43.9	74	131	131	0	30	29
2014	9	3	22	22	18	0.282	0.049	0.771	0.036	0.033	0	43.9	43.4	74	132	130	0	30	29
2014	9	3	22	32	18	0.223	-0.02	0.771	0.033	0.03	0	43	43.9	74	130	131	0	30	29
2014	9	3	22	42	18	0.236	-0.072	0.771	0.033	0.03	0	43.4	43	75.3	131	129	0	30	29
2014	9	3	22	52	18	0.299	0	0.771	0.033	0.03	0	42.6	42.6	74.4	130	129	0	31	30
2014	9	3	23	2	18	0.217	-0.033	0.774	0.033	0.033	0	43.4	42.6	75.7	131	129	0	30	30
2014	9	3	23	12	18	0.21	0.026	0.774	0.036	0.033	0	43	42.6	75.3	130	129	0	30	30
2014	9	3	23	22	18	0.282	0.016	0.774	0.033	0.03	0	44.3	44.3	75.3	134	132	0	31	29
2014	9	3	23	32	18	0.243	-0.049	0.774	0.033	0.03	0	43	42.6	76.1	131	129	0	31	30
2014	9	3	23	42	18	0.194	-0.026	0.774	0.033	0.03	0	43.4	43.4	76.1	131	131	0	30	30
2014	9	3	23	52	18	0.18	-0.023	0.774	0.036	0.033	0	43.4	42.6	76.1	131	129	0	30	30
2014	9	4	0	2	18	0.184	0.069	0.774	0.039	0.036	0	43.9	42.6	75.3	132	129	0	30	30
2014	9	4	0	12	18	0.236	0.013	0.778	0.033	0.03	0	43.4	43.9	76.5	131	131	0	30	29
2014	9	4	0	22	18	0.161	0.052	0.778	0.036	0.033	0	42.6	41.7	76.5	129	127	0	30	30
2014	9	4	0	32	18	0.246	-0.03	0.778	0.036	0.033	0	42.1	42.1	76.5	128	128	0	30	30
2014	9	4	0	42	18	0.157	-0.036	0.778	0.039	0.036	0	43	42.1	75.7	131	128	0	31	30
2014	9	4	0	52	18	0.217	0.01	0.778	0.036	0.033	0	42.1	42.1	76.1	129	128	0	31	30
2014	9	4	1	2	18	0.256	-0.013	0.778	0.033	0.03	0	43.4	44.3	75.7	133	132	0	32	29
2014	9	4	1	12	18	0.253	-0.069	0.781	0.033	0.03	0	43	42.6	75.7	131	129	0	31	30
2014	9	4	1	22	18	0.213	0.013	0.781	0.03	0.03	0	43.4	43	76.1	132	130	0	31	30
2014	9	4	1	32	18	0.272	0.069	0.781	0.033	0.03	0	42.1	43.9	75.7	129	131	0	31	29
2014	9	4	1	42	18	0.302	-0.023	0.781	0.033	0.03	0	43	43.9	74.4	131	132	0	31	30
2014	9	4	1	52	18	0.292	0.036	0.781	0.039	0.036	0	43.4	43	74.4	132	130	0	31	30
2014	9	4	2	2	18	0.236	-0.02	0.781	0.033	0.03	0	42.1	42.6	74	129	129	0	31	30
2014	9	4	2	12	18	0.285	0.052	0.781	0.036	0.033	0	41.7	42.1	74.4	128	128	0	31	30
2014	9	4	2	22	18	0.207	-0.046	0.784	0.033	0.03	0	42.6	43	74.4	130	130	0	31	30
2014	9	4	2	32	18	0.223	0	0.784	0.036	0.033	0	43	43.4	73.1	130	131	0	30	30
2014	9	4	2	42	18	0.177	-0.049	0.784	0.033	0.03	0	44.3	43.9	71.8	134	132	0	31	30
2014	9	4	2	52	18	0.318	0.062	0.784	0.033	0.03	0	43.4	43	73.1	131	130	0	30	30
2014	9	4	3	2	18	0.328	-0.007	0.784	0.039	0.036	0	42.1	42.1	73.1	129	128	0	31	30
2014	9	4	3	12	18	0.243	-0.01	0.787	0.033	0.03	0	42.6	43.4	72.2	130	131	0	31	30
2014	9	4	3	22	18	0.203	0.02	0.787	0.033	0.03	0	43.4	43	72.2	131	130	0	30	30
2014	9	4	3	32	18	0.236	0	0.787	0.036	0.033	0	43	42.6	71.8	131	129	0	31	30
2014	9	4	3	42	18	0.269	0.043	0.791	0.039	0.036	0	43	43.4	71.8	131	131	0	31	30
2014	9	4	3	52	18	0.233	0	0.791	0.033	0.03	0	43.4	43	71	131	130	0	30	30
2014	9	4	4	2	18	0.253	-0.039	0.794	0.033	0.03	0	43	43	71.8	131	130	0	31	30
2014	9	4	4	12	18	0.243	0.033	0.794	0.033	0.033	0	43	42.1	71.8	131	128	0	31	30
2014	9	4	4	22	18	0.154	-0.003	0.797	0.036	0.033	0	43	42.6	71	130	130	0	30	31
2014	9	4	4	32	18	0.276	-0.033	0.797	0.033	0.03	0	43	43	71.4	131	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	4	42	18	0.226	0.043	0.797	0.033	0.03	0	43.9	43.4	70.5	133	131	0	31	30
2014	9	4	4	52	18	0.24	-0.007	0.797	0.033	0.03	0	43.9	43.4	70.5	133	131	0	31	30
2014	9	4	5	2	18	0.269	0.016	0.797	0.036	0.033	0	43.4	43	71	133	131	0	32	31
2014	9	4	5	12	18	0.217	-0.046	0.801	0.039	0.039	0	43.9	43.9	71.4	133	132	0	31	30
2014	9	4	5	22	18	0.322	0.052	0.801	0.036	0.033	0	43.9	43.4	72.2	133	131	0	31	30
2014	9	4	5	32	18	0.21	0.01	0.801	0.033	0.03	0	43.9	43.4	71.4	133	132	0	31	31
2014	9	4	5	42	18	0.164	-0.066	0.801	0.039	0.039	0	44.3	43.9	71.8	133	132	0	30	30
2014	9	4	5	52	18	0.233	-0.072	0.801	0.039	0.036	0	45.2	44.3	71	136	134	0	31	31
2014	9	4	6	2	18	0.23	0.003	0.801	0.039	0.036	0	47.3	46	69.7	141	137	0	31	30
2014	9	4	6	12	18	0.276	-0.121	0.801	0.039	0.036	0	46.4	46	70.1	139	137	0	31	30
2014	9	4	6	22	18	0.266	-0.003	0.801	0.043	0.039	0	49	48.2	67.5	145	142	0	31	30
2014	9	4	6	32	18	0.23	-0.089	0.801	0.036	0.033	0	46.4	45.2	69.2	139	136	0	31	31
2014	9	4	6	42	18	0.285	-0.036	0.801	0.036	0.033	0	46.4	45.6	70.1	140	136	0	32	30
2014	9	4	6	52	18	0.226	0.036	0.801	0.033	0.03	0	45.2	44.7	71	136	134	0	31	30
2014	9	4	7	2	18	0.246	-0.059	0.801	0.033	0.03	0	43.9	43.4	71.8	133	131	0	31	30
2014	9	4	7	12	18	0.207	-0.056	0.801	0.036	0.033	0	43	43	71.8	131	130	0	31	30
2014	9	4	7	22	18	0.289	0.023	0.801	0.033	0.03	0	43.4	43	71	133	131	0	32	31
2014	9	4	7	32	18	0.187	-0.02	0.801	0.033	0.03	0	43.4	43.9	72.2	132	132	0	31	30
2014	9	4	7	42	18	0.302	0.043	0.801	0.036	0.033	0	45.2	44.3	70.1	136	134	0	31	31
2014	9	4	7	52	18	0.262	-0.069	0.801	0.033	0.03	0	45.2	44.3	69.2	136	134	0	31	31
2014	9	4	8	2	18	0.262	0.089	0.801	0.036	0.033	0	45.2	44.3	69.2	137	134	0	32	31
2014	9	4	8	12	18	0.262	0.01	0.801	0.036	0.033	0	45.2	44.7	70.1	136	135	0	31	31
2014	9	4	8	22	18	0.292	0	0.801	0.033	0.03	0	45.2	44.7	70.1	136	134	0	31	30
2014	9	4	8	32	18	0.282	0.013	0.801	0.033	0.03	0	44.3	44.7	71	134	135	0	31	31
2014	9	4	8	42	18	0.21	0.013	0.801	0.033	0.03	0	44.3	44.7	70.1	135	134	0	32	30
2014	9	4	8	52	18	0.144	0.049	0.797	0.039	0.036	0	45.2	45.2	70.1	136	135	0	31	30
2014	9	4	9	2	18	0.21	0.013	0.797	0.033	0.03	0	46.4	46.4	68.8	139	138	0	31	30
2014	9	4	9	12	18	0.295	0.039	0.801	0.036	0.033	0	46	46	69.7	138	137	0	31	30
2014	9	4	9	22	18	0.23	0.069	0.797	0.036	0.033	0	47.3	46.9	66.2	141	140	0	31	31
2014	9	4	9	32	18	0.272	0.072	0.797	0.039	0.036	0	47.3	46.9	67.5	142	140	0	32	31
2014	9	4	9	42	18	0.285	0.059	0.797	0.033	0.03	0	47.7	47.7	67.1	142	141	0	31	30
2014	9	4	9	52	18	0.177	0.089	0.797	0.039	0.036	0	47.7	47.7	68.4	142	142	0	31	31
2014	9	4	10	2	18	0.249	0.062	0.797	0.036	0.033	0	48.2	48.2	67.5	143	142	0	31	30
2014	9	4	10	12	18	0.299	0.069	0.797	0.033	0.03	0	47.7	48.6	69.7	142	143	0	31	30
2014	9	4	10	22	18	0.226	0.052	0.797	0.033	0.03	0	47.7	47.7	67.9	142	142	0	31	31
2014	9	4	10	32	18	0.253	0.026	0.797	0.033	0.03	0	47.7	49	69.7	142	144	0	31	30
2014	9	4	10	42	18	0.289	0.03	0.797	0.033	0.03	0	48.2	48.6	68.8	143	144	0	31	31
2014	9	4	10	52	18	0.312	0.089	0.797	0.033	0.03	0	47.7	48.6	70.5	142	144	0	31	31
2014	9	4	11	2	18	0.21	0.01	0.797	0.03	0.026	0	47.3	49.9	70.5	142	146	0	32	30
2014	9	4	11	12	18	0.279	-0.007	0.794	0.039	0.036	0	47.7	48.2	69.7	142	143	0	31	31
2014	9	4	11	22	18	0.292	0.049	0.794	0.033	0.03	0	49	49.9	69.2	145	146	0	31	30
2014	9	4	11	32	18	0.269	0.016	0.794	0.036	0.033	0	47.7	49.9	67.9	143	147	0	32	31
2014	9	4	11	42	18	0.256	0.138	0.791	0.033	0.03	0	49.9	52	68.4	148	151	0	32	30
2014	9	4	11	52	18	0.259	0.115	0.791	0.033	0.03	0	51.2	51.6	68.4	150	150	0	31	30
2014	9	4	12	2	18	0.325	0.052	0.791	0.033	0.03	0	51.6	52.5	66.7	151	152	0	31	30
2014	9	4	12	12	18	0.302	0.128	0.791	0.033	0.03	0	52	52.5	67.9	152	153	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	12	22	18	0.259	0.105	0.791	0.033	0.03	0	51.6	52.9	67.1	151	153	0	31	30
2014	9	4	12	32	18	0.262	0.072	0.787	0.036	0.033	0	51.6	52.9	67.9	151	153	0	31	30
2014	9	4	12	42	18	0.272	0.135	0.787	0.033	0.03	0	51.2	52.5	68.4	150	152	0	31	30
2014	9	4	12	52	18	0.417	0.105	0.787	0.03	0.03	0	50.3	50.7	68.4	148	148	0	31	30
2014	9	4	13	2	18	0.325	0.089	0.787	0.039	0.036	0	49.9	50.7	68.8	147	149	0	31	31
2014	9	4	13	12	18	0.325	0.092	0.787	0.039	0.036	0	48.6	49.9	68.8	144	146	0	31	30
2014	9	4	13	22	18	0.285	0.095	0.787	0.033	0.03	0	49	51.2	69.2	145	149	0	31	30
2014	9	4	13	32	18	0.351	0.016	0.787	0.033	0.03	0	48.6	50.3	69.2	144	147	0	31	30
2014	9	4	13	42	18	0.308	-0.003	0.787	0.033	0.03	0	48.2	49.9	69.7	143	146	0	31	30
2014	9	4	13	52	18	0.348	0.075	0.787	0.03	0.03	0	48.2	49.9	69.7	143	145	0	31	29
2014	9	4	14	2	18	0.249	0.115	0.784	0.033	0.03	0	48.6	49.5	71	143	144	0	30	29
2014	9	4	14	12	18	0.285	0.052	0.784	0.036	0.033	0	47.3	49	70.5	141	144	0	31	30
2014	9	4	14	22	18	0.299	0.069	0.784	0.039	0.036	0	46.4	48.2	70.5	139	142	0	31	30
2014	9	4	14	32	18	0.299	0.059	0.784	0.03	0.03	0	47.7	49	71	141	144	0	30	30
2014	9	4	14	42	18	0.351	0.082	0.784	0.033	0.03	0	47.7	49.5	71.4	141	145	0	30	30
2014	9	4	14	52	18	0.341	0.112	0.784	0.036	0.033	0	46.9	48.6	71.4	140	143	0	31	30
2014	9	4	15	2	18	0.322	0.059	0.784	0.036	0.033	0	46.4	48.2	72.7	139	142	0	31	30
2014	9	4	15	12	18	0.315	0.102	0.784	0.036	0.033	0	46	48.6	72.2	138	143	0	31	30
2014	9	4	15	22	18	0.308	0.112	0.784	0.033	0.03	0	46.4	48.2	71.8	139	142	0	31	30
2014	9	4	15	32	18	0.292	0.079	0.784	0.033	0.03	0	47.3	49	72.7	140	143	0	30	29
2014	9	4	15	42	18	0.282	0.075	0.784	0.03	0.03	0	46.9	48.6	73.1	139	143	0	30	30
2014	9	4	15	52	18	0.299	0.089	0.784	0.036	0.033	0	46.4	48.2	72.7	138	142	0	30	30
2014	9	4	16	2	18	0.292	0.072	0.784	0.033	0.03	0	46	47.7	73.1	137	141	0	30	30
2014	9	4	16	12	18	0.282	0.033	0.784	0.033	0.03	0	46.4	47.7	74.4	138	141	0	30	30
2014	9	4	16	22	18	0.305	0.01	0.784	0.039	0.039	0	46.9	49	73.5	139	143	0	30	29
2014	9	4	16	32	18	0.144	0.033	0.784	0.033	0.03	0	46.4	47.7	73.5	138	141	0	30	30
2014	9	4	16	42	18	0.282	0.112	0.784	0.039	0.039	0	46	46.9	74.8	137	139	0	30	30
2014	9	4	16	52	18	0.262	0.016	0.784	0.033	0.03	0	46	46.4	74	137	137	0	30	29
2014	9	4	17	2	18	0.272	0.026	0.784	0.033	0.03	0	44.3	45.2	75.3	133	135	0	30	30
2014	9	4	17	12	18	0.279	0.033	0.784	0.033	0.03	0	45.2	44.7	74.4	135	134	0	30	30
2014	9	4	17	22	18	0.217	0.098	0.784	0.039	0.036	0	43.4	42.6	75.7	131	128	0	30	29
2014	9	4	17	32	18	0.272	0.052	0.784	0.039	0.039	0	41.3	41.3	76.1	126	125	0	30	29
2014	9	4	17	42	18	0.295	0.115	0.784	0.033	0.03	0	41.3	40.4	75.7	126	123	0	30	29
2014	9	4	17	52	18	0.305	0.052	0.784	0.033	0.033	0	41.3	40.9	76.1	126	124	0	30	29
2014	9	4	18	2	18	0.272	0.003	0.784	0.036	0.033	0	40.9	40.4	75.7	125	124	0	30	30
2014	9	4	18	12	18	0.246	-0.023	0.784	0.039	0.036	0	42.1	41.3	75.7	128	125	0	30	29
2014	9	4	18	22	18	0.203	0.062	0.784	0.043	0.043	0	40.9	40.9	75.7	125	124	0	30	29
2014	9	4	18	32	18	0.21	0.049	0.784	0.033	0.033	0	41.3	40.9	76.1	126	124	0	30	29
2014	9	4	18	42	18	0.233	0.033	0.784	0.033	0.03	0	41.3	40.4	75.7	126	123	0	30	29
2014	9	4	18	52	18	0.243	0.066	0.784	0.036	0.033	0	40	40	75.7	124	123	0	31	30
2014	9	4	19	2	18	0.243	0.026	0.784	0.03	0.03	0	40.9	40	76.1	125	123	0	30	30
2014	9	4	19	12	18	0.233	-0.016	0.784	0.033	0.03	0	41.3	40.9	75.7	126	124	0	30	29
2014	9	4	19	22	18	0.262	-0.03	0.784	0.039	0.036	0	42.6	41.3	75.7	129	126	0	30	30
2014	9	4	19	32	18	0.269	-0.03	0.784	0.036	0.033	0	41.7	41.7	75.7	127	126	0	30	29
2014	9	4	19	42	18	0.289	0.016	0.784	0.033	0.03	0	41.3	40.9	75.7	127	125	0	31	30
2014	9	4	19	52	18	0.249	-0.016	0.784	0.036	0.033	0	42.1	41.3	74.8	128	126	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	20	2	18	0.276	0.03	0.784	0.033	0.03	0	43.4	42.6	75.3	131	129	0	30	30
2014	9	4	20	12	18	0.19	-0.007	0.784	0.039	0.036	0	43.4	43.4	74.4	132	130	0	31	29
2014	9	4	20	22	18	0.24	-0.013	0.784	0.036	0.033	0	43.9	43	74	132	129	0	30	29
2014	9	4	20	32	18	0.279	0.02	0.784	0.039	0.036	0	43.4	42.1	74.4	131	128	0	30	30
2014	9	4	20	42	18	0.276	0.056	0.784	0.033	0.03	0	43	42.1	74.4	130	128	0	30	30
2014	9	4	20	52	18	0.305	-0.003	0.784	0.033	0.03	0	43	42.1	74.4	131	128	0	31	30
2014	9	4	21	2	18	0.272	0.01	0.784	0.036	0.033	0	43	43	74	130	129	0	30	29
2014	9	4	21	12	18	0.279	-0.026	0.784	0.033	0.03	0	42.1	42.6	74	129	128	0	31	29
2014	9	4	21	22	18	0.184	0.03	0.784	0.036	0.033	0	42.6	43	72.7	129	130	0	30	30
2014	9	4	21	32	18	0.256	-0.033	0.787	0.036	0.033	0	43	42.1	74	131	128	0	31	30
2014	9	4	21	42	18	0.249	-0.003	0.784	0.039	0.039	0	43	43	73.5	131	130	0	31	30
2014	9	4	21	52	18	0.226	0.069	0.784	0.049	0.046	0	42.1	42.1	73.5	129	128	0	31	30
2014	9	4	22	2	18	0.161	-0.02	0.787	0.043	0.039	0	43	42.6	73.1	131	129	0	31	30
2014	9	4	22	12	18	0.302	0.03	0.784	0.033	0.033	0	42.6	43	73.5	130	129	0	31	29
2014	9	4	22	22	18	0.315	0.01	0.787	0.033	0.03	0	43	42.1	72.7	131	128	0	31	30
2014	9	4	22	32	18	0.272	0.026	0.787	0.033	0.03	0	43	42.1	73.1	130	128	0	30	30
2014	9	4	22	42	18	0.197	-0.075	0.787	0.033	0.03	0	43	42.6	73.5	130	129	0	30	30
2014	9	4	22	52	18	0.302	-0.079	0.787	0.036	0.033	0	42.6	42.6	72.7	130	129	0	31	30
2014	9	4	23	2	18	0.262	-0.007	0.787	0.036	0.033	0	43	42.6	72.7	131	129	0	31	30
2014	9	4	23	12	18	0.236	0	0.787	0.039	0.036	0	42.1	42.1	73.1	129	129	0	31	31
2014	9	4	23	22	18	0.256	-0.013	0.787	0.039	0.036	0	42.6	42.6	73.1	129	129	0	30	30
2014	9	4	23	32	18	0.285	-0.052	0.787	0.03	0.03	0	43.4	42.1	73.1	132	128	0	31	30
2014	9	4	23	42	18	0.253	-0.033	0.787	0.036	0.033	0	43.4	43	73.5	132	130	0	31	30
2014	9	4	23	52	18	0.325	0.059	0.787	0.036	0.033	0	43.4	43.4	71.4	132	131	0	31	30
2014	9	5	0	2	18	0.322	0.016	0.791	0.039	0.036	0	44.3	44.3	71.4	134	133	0	31	30
2014	9	5	0	12	18	0.217	0.069	0.791	0.036	0.033	0	45.6	44.7	70.1	137	135	0	31	31
2014	9	5	0	22	18	0.197	0	0.791	0.036	0.033	0	47.3	46.4	69.7	140	138	0	30	30
2014	9	5	0	32	18	0.22	0.026	0.794	0.033	0.03	0	45.2	45.6	71	136	136	0	31	30
2014	9	5	0	42	18	0.269	0.013	0.791	0.036	0.033	0	44.3	43.4	71.8	134	131	0	31	30
2014	9	5	0	52	18	0.289	-0.033	0.794	0.036	0.033	0	43	43.4	71.4	132	131	0	32	30
2014	9	5	1	2	18	0.312	0	0.794	0.036	0.033	0	43.4	43.4	71.4	132	131	0	31	30
2014	9	5	1	12	18	0.226	-0.02	0.794	0.033	0.03	0	43.4	43.9	72.2	132	132	0	31	30
2014	9	5	1	22	18	0.233	-0.03	0.794	0.033	0.03	0	43	43.4	71.8	131	130	0	31	29
2014	9	5	1	32	18	0.308	-0.01	0.794	0.033	0.03	0	43	43.4	71.8	131	131	0	31	30
2014	9	5	1	42	18	0.262	-0.03	0.797	0.036	0.033	0	43.4	43.4	71.8	132	131	0	31	30
2014	9	5	1	52	18	0.253	-0.01	0.797	0.033	0.03	0	42.1	42.6	71.8	129	129	0	31	30
2014	9	5	2	2	18	0.233	-0.016	0.797	0.036	0.033	0	42.6	42.1	72.2	130	128	0	31	30
2014	9	5	2	12	18	0.194	-0.02	0.797	0.036	0.033	0	43	42.6	71.4	131	129	0	31	30
2014	9	5	2	22	18	0.289	-0.023	0.797	0.033	0.03	0	42.6	42.6	71.8	130	129	0	31	30
2014	9	5	2	32	18	0.22	-0.066	0.801	0.033	0.03	0	43.9	43.4	72.7	132	131	0	30	30
2014	9	5	2	42	18	0.322	0.007	0.801	0.033	0.03	0	43	42.6	71.8	131	129	0	31	30
2014	9	5	2	52	18	0.233	0.016	0.801	0.039	0.036	0	42.6	43	73.1	130	130	0	31	30
2014	9	5	3	2	18	0.259	-0.003	0.801	0.033	0.03	0	42.6	43	73.1	130	130	0	31	30
2014	9	5	3	12	18	0.194	-0.02	0.801	0.033	0.03	0	43	43.9	73.1	131	132	0	31	30
2014	9	5	3	22	18	0.289	-0.023	0.801	0.039	0.036	0	42.6	42.6	72.7	130	129	0	31	30
2014	9	5	3	32	18	0.22	0.016	0.801	0.033	0.03	0	43.4	43.4	73.1	132	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	3	42	18	0.282	-0.036	0.801	0.033	0.03	0	43.4	43.9	72.7	132	132	0	31	30
2014	9	5	3	52	18	0.276	0.066	0.801	0.036	0.033	0	42.6	43	73.5	130	130	0	31	30
2014	9	5	4	2	18	0.23	-0.036	0.804	0.036	0.033	0	43	42.6	73.1	131	129	0	31	30
2014	9	5	4	12	18	0.253	0.033	0.804	0.039	0.036	0	43	43.4	73.5	131	131	0	31	30
2014	9	5	4	22	18	0.243	-0.01	0.804	0.033	0.03	0	44.7	43.4	73.5	135	131	0	31	30
2014	9	5	4	32	18	0.23	-0.092	0.804	0.036	0.033	0	43	43.4	74	131	131	0	31	30
2014	9	5	4	42	18	0.226	-0.082	0.804	0.033	0.03	0	43	43.4	74.4	131	131	0	31	30
2014	9	5	4	52	18	0.295	-0.03	0.804	0.03	0.03	0	43.9	44.3	73.5	134	133	0	32	30
2014	9	5	5	2	18	0.171	-0.026	0.804	0.033	0.03	0	44.3	43.4	74	133	132	0	30	31
2014	9	5	5	12	18	0.269	0.003	0.804	0.033	0.03	0	44.3	43.4	74	134	132	0	31	31
2014	9	5	5	22	18	0.21	-0.026	0.804	0.033	0.03	0	43.4	43.9	74.4	133	132	0	32	30
2014	9	5	5	32	18	0.23	-0.016	0.804	0.033	0.03	0	44.3	43.9	74.8	134	133	0	31	31
2014	9	5	5	42	18	0.207	-0.016	0.807	0.036	0.033	0	43.9	43.4	74.8	133	132	0	31	31
2014	9	5	5	52	18	0.213	-0.075	0.807	0.033	0.03	0	42.6	43.9	75.3	131	132	0	32	30
2014	9	5	6	2	18	0.177	-0.049	0.807	0.039	0.036	0	43	43.4	74.8	131	131	0	31	30
2014	9	5	6	12	18	0.262	-0.052	0.807	0.036	0.033	0	43.4	43.4	75.7	132	131	0	31	30
2014	9	5	6	22	18	0.269	-0.066	0.807	0.039	0.039	0	42.1	43	75.3	130	130	0	32	30
2014	9	5	6	32	18	0.226	-0.056	0.807	0.036	0.033	0	41.7	42.1	76.1	129	128	0	32	30
2014	9	5	6	42	18	0.174	-0.052	0.807	0.039	0.036	0	41.7	42.1	76.1	129	128	0	32	30
2014	9	5	6	52	18	0.19	0	0.807	0.039	0.036	0	48.6	47.3	71.4	144	140	0	31	30
2014	9	5	7	2	18	0.279	0.043	0.807	0.036	0.033	0	47.3	45.2	72.7	141	136	0	31	31
2014	9	5	7	12	18	0.351	-0.082	0.807	0.039	0.036	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	5	7	22	18	0.262	-0.056	0.807	0.036	0.033	0	42.6	42.6	76.1	130	129	0	31	30
2014	9	5	7	32	18	0.256	-0.013	0.807	0.039	0.036	0	42.1	42.6	77	129	129	0	31	30
2014	9	5	7	42	18	0.2	-0.007	0.807	0.036	0.033	0	42.6	42.6	76.5	130	129	0	31	30
2014	9	5	7	52	18	0.259	-0.02	0.807	0.033	0.03	0	41.7	41.7	77	128	127	0	31	30
2014	9	5	8	2	18	0.299	-0.013	0.807	0.033	0.03	0	40.9	41.7	77.4	128	127	0	33	30
2014	9	5	8	12	18	0.197	-0.036	0.807	0.033	0.03	0	41.7	41.7	77.4	128	128	0	31	31
2014	9	5	8	22	18	0.269	-0.052	0.807	0.033	0.03	0	40.9	41.3	77.8	126	126	0	31	30
2014	9	5	8	32	18	0.243	0	0.807	0.039	0.039	0	41.3	41.3	77.4	127	126	0	31	30
2014	9	5	8	42	18	0.266	-0.095	0.807	0.046	0.043	0	41.3	42.1	76.5	127	128	0	31	30
2014	9	5	8	52	18	0.226	0	0.807	0.033	0.03	0	40.9	42.1	76.5	127	128	0	32	30
2014	9	5	9	2	18	0.285	-0.003	0.807	0.039	0.036	0	41.7	42.6	76.5	128	129	0	31	30
2014	9	5	9	12	18	0.2	-0.007	0.807	0.036	0.033	0	42.6	42.1	77.4	130	128	0	31	30
2014	9	5	9	22	18	0.276	-0.026	0.807	0.033	0.03	0	42.1	42.6	76.1	129	130	0	31	31
2014	9	5	9	32	18	0.305	0.023	0.807	0.036	0.033	0	42.6	42.6	77.4	131	130	0	32	31
2014	9	5	9	42	18	0.315	-0.007	0.807	0.039	0.039	0	42.6	44.3	76.1	130	133	0	31	30
2014	9	5	9	52	18	0.24	0.016	0.807	0.033	0.03	0	43.9	45.2	75.7	134	135	0	32	30
2014	9	5	10	2	18	0.335	0.052	0.807	0.033	0.03	0	44.3	46	75.3	134	138	0	31	31
2014	9	5	10	12	18	0.226	0	0.807	0.036	0.033	0	43.9	44.7	76.1	133	135	0	31	31
2014	9	5	10	22	18	0.282	-0.046	0.807	0.033	0.03	0	44.3	45.2	74.8	134	136	0	31	31
2014	9	5	10	32	18	0.253	-0.052	0.807	0.033	0.03	0	45.6	47.3	74.8	137	140	0	31	30
2014	9	5	10	42	18	0.276	-0.036	0.807	0.039	0.036	0	44.7	46.9	75.3	135	139	0	31	30
2014	9	5	10	52	18	0.276	-0.01	0.807	0.033	0.03	0	45.2	46	74.4	137	138	0	32	31
2014	9	5	11	2	18	0.292	0	0.804	0.033	0.03	0	45.2	46.9	74.4	137	139	0	32	30
2014	9	5	11	12	18	0.197	0.043	0.804	0.033	0.03	0	46.4	48.6	74	139	143	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	11	22	18	0.276	0.049	0.804	0.033	0.03	0	46.9	49	72.2	140	145	0	31	31
2014	9	5	11	32	18	0.279	0.007	0.804	0.033	0.03	0	47.7	49.5	71.4	142	145	0	31	30
2014	9	5	11	42	18	0.226	0.059	0.804	0.033	0.03	0	47.3	49	71.8	141	144	0	31	30
2014	9	5	11	52	18	0.276	0.043	0.804	0.039	0.039	0	47.3	48.6	72.2	141	144	0	31	31
2014	9	5	12	2	18	0.269	0	0.804	0.033	0.03	0	48.2	50.3	71.4	143	147	0	31	30
2014	9	5	12	12	18	0.256	0.039	0.804	0.033	0.03	0	47.3	49.5	70.5	141	146	0	31	31
2014	9	5	12	22	18	0.24	0.079	0.804	0.039	0.036	0	48.2	50.3	70.5	143	147	0	31	30
2014	9	5	12	32	18	0.269	0.007	0.801	0.033	0.03	0	48.6	50.3	70.1	143	147	0	30	30
2014	9	5	12	42	18	0.256	0.085	0.804	0.033	0.03	0	48.6	50.7	69.7	144	148	0	31	30
2014	9	5	12	52	18	0.322	0.036	0.801	0.033	0.03	0	47.7	49.5	70.1	142	145	0	31	30
2014	9	5	13	2	18	0.292	0.105	0.801	0.033	0.03	0	48.2	50.3	70.5	143	147	0	31	30
2014	9	5	13	12	18	0.21	0.01	0.801	0.039	0.036	0	47.7	50.3	69.2	142	147	0	31	30
2014	9	5	13	22	18	0.253	0.033	0.797	0.033	0.03	0	48.6	50.3	68.4	144	148	0	31	31
2014	9	5	13	32	18	0.312	0.069	0.797	0.033	0.03	0	49.5	50.7	69.2	146	148	0	31	30
2014	9	5	13	42	18	0.256	0.118	0.794	0.039	0.036	0	48.2	50.3	69.2	143	147	0	31	30
2014	9	5	13	52	18	0.328	0.135	0.794	0.033	0.03	0	49.5	51.6	68.8	146	150	0	31	30
2014	9	5	14	2	18	0.308	0.085	0.791	0.033	0.03	0	50.3	51.2	67.5	148	149	0	31	30
2014	9	5	14	12	18	0.276	0.128	0.791	0.039	0.036	0	49.9	51.2	67.9	147	149	0	31	30
2014	9	5	14	22	18	0.377	0.082	0.791	0.036	0.033	0	49.9	51.2	67.5	148	149	0	32	30
2014	9	5	14	32	18	0.269	0.118	0.791	0.033	0.03	0	49	50.3	69.2	144	146	0	30	29
2014	9	5	14	42	18	0.249	0.049	0.787	0.036	0.033	0	49.9	51.6	69.2	146	149	0	30	29
2014	9	5	14	52	18	0.351	0.089	0.787	0.036	0.033	0	48.6	50.3	69.2	144	147	0	31	30
2014	9	5	15	2	18	0.315	0.056	0.787	0.039	0.036	0	48.6	49.9	69.2	143	145	0	30	29
2014	9	5	15	12	18	0.226	0.089	0.787	0.033	0.03	0	47.7	49.5	69.7	142	145	0	31	30
2014	9	5	15	22	18	0.292	0.079	0.787	0.033	0.03	0	47.7	49	71.4	141	144	0	30	30
2014	9	5	15	32	18	0.266	0.01	0.787	0.036	0.033	0	47.3	48.2	72.2	140	142	0	30	30
2014	9	5	15	42	18	0.308	0.023	0.787	0.033	0.03	0	47.7	49.5	71.4	141	144	0	30	29
2014	9	5	15	52	18	0.335	0.079	0.787	0.046	0.043	0	46.9	48.6	71.8	140	142	0	31	29
2014	9	5	16	2	18	0.325	0.036	0.787	0.036	0.033	0	46	47.3	72.7	137	139	0	30	29
2014	9	5	16	12	18	0.279	0.01	0.787	0.033	0.03	0	47.7	47.7	71.8	141	141	0	30	30
2014	9	5	16	22	18	0.285	0.062	0.787	0.033	0.03	0	46.4	48.2	71.4	138	142	0	30	30
2014	9	5	16	32	18	0.259	0.069	0.784	0.039	0.036	0	46.4	46.9	72.2	138	139	0	30	30
2014	9	5	16	42	18	0.315	0.046	0.784	0.033	0.03	0	45.6	46.4	72.7	136	138	0	30	30
2014	9	5	16	52	18	0.272	0.098	0.784	0.033	0.03	0	44.7	45.2	73.1	134	134	0	30	29
2014	9	5	17	2	18	0.266	0.161	0.784	0.036	0.033	0	45.6	45.6	73.5	136	135	0	30	29
2014	9	5	17	12	18	0.259	0.085	0.784	0.033	0.03	0	44.7	43.9	72.7	134	132	0	30	30
2014	9	5	17	22	18	0.302	0.148	0.784	0.039	0.036	0	43.4	43.4	74	131	130	0	30	29
2014	9	5	17	32	18	0.315	0.135	0.784	0.036	0.033	0	42.6	41.7	74.4	129	128	0	30	31
2014	9	5	17	42	18	0.223	0.052	0.784	0.033	0.03	0	43	42.1	74.4	130	127	0	30	29
2014	9	5	17	52	18	0.259	0.082	0.784	0.036	0.033	0	42.1	41.7	74.8	128	126	0	30	29
2014	9	5	18	2	18	0.259	-0.013	0.784	0.036	0.033	0	42.1	40.4	74.4	128	124	0	30	30
2014	9	5	18	12	18	0.22	0.135	0.784	0.039	0.036	0	41.7	40.9	75.3	127	124	0	30	29
2014	9	5	18	22	18	0.276	0.007	0.784	0.039	0.036	0	40.9	40.4	75.3	126	124	0	31	30
2014	9	5	18	32	18	0.246	0.085	0.784	0.036	0.033	0	41.3	40.9	75.7	126	124	0	30	29
2014	9	5	18	42	18	0.19	0.052	0.784	0.043	0.043	0	40.4	40.4	75.7	124	124	0	30	30
2014	9	5	18	52	18	0.22	0.069	0.784	0.033	0.03	0	40.9	40.4	75.7	125	123	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	19	2	18	0.331	0.089	0.784	0.033	0.03	0	41.3	41.3	75.7	126	125	0	30	29
2014	9	5	19	12	18	0.187	0.03	0.784	0.036	0.033	0	41.3	40.4	75.7	126	124	0	30	30
2014	9	5	19	22	18	0.285	0.03	0.784	0.036	0.033	0	41.7	41.3	75.3	127	126	0	30	30
2014	9	5	19	32	18	0.135	0.052	0.784	0.033	0.03	0	42.1	41.7	75.3	128	126	0	30	29
2014	9	5	19	42	18	0.243	-0.02	0.784	0.036	0.033	0	42.6	42.1	75.7	129	127	0	30	29
2014	9	5	19	52	18	0.295	-0.026	0.784	0.033	0.03	0	42.1	43	74.8	129	129	0	31	29
2014	9	5	20	2	18	0.315	0.01	0.784	0.036	0.033	0	42.1	41.3	74.8	128	126	0	30	30
2014	9	5	20	12	18	0.299	-0.016	0.784	0.039	0.036	0	42.1	41.7	74.8	128	127	0	30	30
2014	9	5	20	22	18	0.285	-0.03	0.784	0.033	0.03	0	43	41.7	74.8	130	127	0	30	30
2014	9	5	20	32	18	0.282	0.016	0.784	0.046	0.043	0	44.3	43.4	73.1	133	130	0	30	29
2014	9	5	20	42	18	0.157	0.016	0.784	0.036	0.033	0	43	43	73.5	130	130	0	30	30
2014	9	5	20	52	18	0.243	0.043	0.784	0.033	0.03	0	43.9	42.6	74.4	132	129	0	30	30
2014	9	5	21	2	18	0.276	-0.016	0.784	0.033	0.03	0	43.4	43.9	74.4	132	131	0	31	29
2014	9	5	21	12	18	0.223	0.108	0.784	0.036	0.033	0	43	42.6	73.5	130	129	0	30	30
2014	9	5	21	22	18	0.269	0.052	0.784	0.036	0.033	0	43.4	43.4	73.5	132	130	0	31	29
2014	9	5	21	32	18	0.292	0.007	0.784	0.036	0.033	0	43	42.6	73.5	131	129	0	31	30
2014	9	5	21	42	18	0.312	0	0.784	0.043	0.039	0	43	42.6	73.1	131	129	0	31	30
2014	9	5	21	52	18	0.272	-0.026	0.784	0.043	0.039	0	43.4	42.1	74.4	131	128	0	30	30
2014	9	5	22	2	18	0.246	-0.013	0.784	0.036	0.033	0	43.4	43	72.7	131	130	0	30	30
2014	9	5	22	12	18	0.249	-0.003	0.784	0.036	0.033	0	43.4	43.4	71.8	132	131	0	31	30
2014	9	5	22	22	18	0.246	-0.02	0.784	0.039	0.036	0	43	42.1	73.1	131	128	0	31	30
2014	9	5	22	32	18	0.187	-0.01	0.787	0.039	0.036	0	43	42.1	72.7	131	128	0	31	30
2014	9	5	22	42	18	0.233	0.036	0.784	0.033	0.03	0	44.3	44.3	72.2	134	133	0	31	30
2014	9	5	22	52	18	0.236	-0.01	0.787	0.033	0.03	0	43	43.9	72.7	131	132	0	31	30
2014	9	5	23	2	18	0.243	0.016	0.787	0.036	0.033	0	42.6	43.9	72.2	130	132	0	31	30
2014	9	5	23	12	18	0.2	0.062	0.787	0.036	0.033	0	43.4	42.6	72.7	132	129	0	31	30
2014	9	5	23	22	18	0.259	-0.043	0.787	0.033	0.03	0	43	43	71.8	131	131	0	31	31
2014	9	5	23	32	18	0.197	-0.02	0.787	0.039	0.036	0	43	42.1	72.2	131	129	0	31	31
2014	9	5	23	42	18	0.22	-0.125	0.787	0.033	0.03	0	43.4	43.4	71.8	131	131	0	30	30
2014	9	5	23	52	18	0.194	-0.026	0.787	0.03	0.03	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	6	0	2	18	0.276	-0.016	0.787	0.033	0.03	0	43.4	43.4	71.8	131	131	0	30	30
2014	9	6	0	12	18	0.217	-0.036	0.787	0.036	0.033	0	42.6	43.4	71.8	131	131	0	32	30
2014	9	6	0	22	18	0.256	0	0.787	0.033	0.03	0	43.9	43.4	71.4	133	131	0	31	30
2014	9	6	0	32	18	0.328	-0.039	0.787	0.036	0.033	0	43.4	43	71.8	132	130	0	31	30
2014	9	6	0	42	18	0.308	-0.059	0.791	0.036	0.033	0	43	42.6	71.8	131	130	0	31	31
2014	9	6	0	52	18	0.213	-0.059	0.787	0.039	0.036	0	44.7	43.9	70.1	135	132	0	31	30
2014	9	6	1	2	18	0.292	-0.033	0.791	0.033	0.03	0	43.4	43	70.5	132	130	0	31	30
2014	9	6	1	12	18	0.276	0.016	0.791	0.039	0.039	0	42.1	42.6	72.2	129	129	0	31	30
2014	9	6	1	22	18	0.285	-0.049	0.791	0.039	0.036	0	46.4	45.2	69.7	138	135	0	30	30
2014	9	6	1	32	18	0.174	0.039	0.791	0.033	0.03	0	47.3	46.4	68.4	141	138	0	31	30
2014	9	6	1	42	18	0.233	-0.016	0.794	0.039	0.036	0	46	45.6	69.7	138	136	0	31	30
2014	9	6	1	52	18	0.23	-0.003	0.794	0.043	0.039	0	45.6	44.3	70.1	137	134	0	31	31
2014	9	6	2	2	18	0.272	0.046	0.797	0.033	0.03	0	45.2	44.3	71	136	133	0	31	30
2014	9	6	2	12	18	0.312	0.033	0.797	0.039	0.036	0	44.3	44.3	71	134	133	0	31	30
2014	9	6	2	22	18	0.322	-0.069	0.797	0.036	0.033	0	43.9	44.7	71.8	133	134	0	31	30
2014	9	6	2	32	18	0.249	0.085	0.794	0.033	0.03	0	43	43.9	71.4	131	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	2	42	18	0.23	0.013	0.797	0.036	0.033	0	43	42.6	72.7	131	129	0	31	30
2014	9	6	2	52	18	0.246	-0.049	0.797	0.039	0.036	0	43.4	43	71.4	132	130	0	31	30
2014	9	6	3	2	18	0.236	0.003	0.797	0.036	0.033	0	43	43.4	72.7	131	131	0	31	30
2014	9	6	3	12	18	0.262	0	0.797	0.033	0.03	0	43.4	43	71.4	132	131	0	31	31
2014	9	6	3	22	18	0.23	0.049	0.797	0.036	0.033	0	43	43	71.4	131	130	0	31	30
2014	9	6	3	32	18	0.243	0.016	0.797	0.036	0.033	0	43	43.4	71	132	131	0	32	30
2014	9	6	3	42	18	0.246	-0.033	0.797	0.033	0.03	0	43.9	42.6	71.4	133	129	0	31	30
2014	9	6	3	52	18	0.213	-0.043	0.797	0.039	0.036	0	43.9	43.9	71	133	132	0	31	30
2014	9	6	4	2	18	0.269	0.069	0.794	0.033	0.03	0	43.9	43.4	71.4	133	131	0	31	30
2014	9	6	4	12	18	0.249	-0.007	0.797	0.033	0.03	0	43.9	43.9	72.2	133	132	0	31	30
2014	9	6	4	22	18	0.305	-0.007	0.794	0.039	0.039	0	48.2	47.3	67.1	144	140	0	32	30
2014	9	6	4	32	18	0.256	0.056	0.794	0.033	0.03	0	47.7	46.9	68.8	142	139	0	31	30
2014	9	6	4	42	18	0.256	0.072	0.794	0.033	0.03	0	47.7	46	69.2	141	138	0	30	31
2014	9	6	4	52	18	0.226	-0.02	0.794	0.033	0.03	0	46.4	45.6	69.7	139	137	0	31	31
2014	9	6	5	2	18	0.21	0.016	0.794	0.033	0.03	0	45.6	45.2	70.5	137	136	0	31	31
2014	9	6	5	12	18	0.226	-0.01	0.794	0.033	0.03	0	46.4	45.6	70.1	139	136	0	31	30
2014	9	6	5	22	18	0.217	-0.079	0.794	0.03	0.03	0	44.7	44.3	71	135	134	0	31	31
2014	9	6	5	32	18	0.259	-0.003	0.794	0.033	0.03	0	44.3	44.7	71	134	134	0	31	30
2014	9	6	5	42	18	0.24	-0.023	0.791	0.033	0.03	0	43.9	43	71.4	133	131	0	31	31
2014	9	6	5	52	18	0.154	-0.026	0.791	0.036	0.033	0	43.9	43.9	70.5	133	132	0	31	30
2014	9	6	6	2	18	0.213	-0.036	0.791	0.033	0.03	0	43.4	43.9	71.4	133	133	0	32	31
2014	9	6	6	12	18	0.226	-0.059	0.791	0.033	0.03	0	44.3	43	71.4	134	131	0	31	31
2014	9	6	6	22	18	0.279	0.013	0.791	0.043	0.039	0	43	43.4	71.4	132	131	0	32	30
2014	9	6	6	32	18	0.282	0.007	0.791	0.036	0.033	0	42.6	42.6	71.8	130	129	0	31	30
2014	9	6	6	42	18	0.279	-0.023	0.787	0.033	0.03	0	42.1	42.1	71.8	129	129	0	31	31
2014	9	6	6	52	18	0.259	-0.069	0.791	0.033	0.03	0	42.1	41.7	71	129	127	0	31	30
2014	9	6	7	2	18	0.223	-0.056	0.787	0.033	0.03	0	42.1	41.3	71.8	129	127	0	31	31
2014	9	6	7	12	18	0.272	-0.013	0.787	0.039	0.039	0	41.7	41.7	72.2	129	127	0	32	30
2014	9	6	7	22	18	0.22	-0.033	0.787	0.033	0.03	0	41.3	41.3	72.2	128	126	0	32	30
2014	9	6	7	32	18	0.249	0.023	0.787	0.039	0.036	0	40.9	41.7	72.2	127	127	0	32	30
2014	9	6	7	42	18	0.266	0.03	0.787	0.033	0.03	0	41.7	41.7	72.2	129	127	0	32	30
2014	9	6	7	52	18	0.217	0	0.784	0.039	0.036	0	42.1	41.3	72.2	129	127	0	31	31
2014	9	6	8	2	18	0.171	0	0.784	0.039	0.036	0	42.1	42.1	72.7	129	129	0	31	31
2014	9	6	8	12	18	0.269	-0.033	0.784	0.033	0.03	0	41.7	41.7	72.2	129	127	0	32	30
2014	9	6	8	22	18	0.249	0.013	0.784	0.033	0.03	0	41.7	41.7	73.1	128	128	0	31	31
2014	9	6	8	32	18	0.197	-0.082	0.781	0.033	0.03	0	41.7	42.1	72.7	129	129	0	32	31
2014	9	6	8	42	18	0.292	-0.03	0.781	0.046	0.043	0	41.7	40.9	72.7	129	126	0	32	31
2014	9	6	8	52	18	0.243	-0.03	0.781	0.036	0.033	0	41.7	41.7	72.2	129	127	0	32	30
2014	9	6	9	2	18	0.226	-0.016	0.781	0.039	0.036	0	41.3	41.7	73.5	128	127	0	32	30
2014	9	6	9	12	18	0.223	-0.059	0.781	0.033	0.03	0	42.1	41.7	73.1	129	128	0	31	31
2014	9	6	9	22	18	0.233	-0.052	0.781	0.036	0.033	0	43	42.6	72.7	131	130	0	31	31
2014	9	6	9	32	18	0.207	-0.039	0.781	0.036	0.033	0	42.1	43	73.1	130	131	0	32	31
2014	9	6	9	42	18	0.253	0.043	0.781	0.043	0.039	0	43	43.9	73.1	132	133	0	32	31
2014	9	6	9	52	18	0.289	0.023	0.781	0.033	0.03	0	43.9	44.7	72.2	134	135	0	32	31
2014	9	6	10	2	18	0.23	-0.049	0.781	0.033	0.03	0	46.4	46.9	71.8	139	140	0	31	31
2014	9	6	10	12	18	0.279	-0.007	0.781	0.033	0.03	0	45.6	46.4	72.2	137	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	10	22	18	0.236	0.026	0.778	0.036	0.033	0	46	46.9	72.2	138	140	0	31	31
2014	9	6	10	32	18	0.2	0.046	0.778	0.033	0.03	0	45.2	47.3	72.2	137	140	0	32	30
2014	9	6	10	42	18	0.226	-0.043	0.781	0.033	0.03	0	46	47.7	72.2	138	142	0	31	31
2014	9	6	10	52	18	0.21	-0.046	0.778	0.043	0.039	0	45.6	47.3	71.8	138	141	0	32	31
2014	9	6	11	2	18	0.21	-0.052	0.778	0.036	0.033	0	45.6	48.6	72.2	138	143	0	32	30
2014	9	6	11	12	18	0.223	0.03	0.778	0.033	0.03	0	46	48.2	71.8	138	142	0	31	30
2014	9	6	11	22	18	0.24	0	0.778	0.033	0.03	0	47.3	49.9	71.4	142	146	0	32	30
2014	9	6	11	32	18	0.22	0.036	0.778	0.03	0.03	0	47.7	49	71.8	142	145	0	31	31
2014	9	6	11	42	18	0.243	0.066	0.778	0.033	0.03	0	49	49.9	71.8	146	146	0	32	30
2014	9	6	11	52	18	0.226	0.079	0.778	0.033	0.03	0	47.3	49.5	72.7	141	145	0	31	30
2014	9	6	12	2	18	0.236	0.02	0.778	0.039	0.036	0	47.3	49.9	72.7	141	146	0	31	30
2014	9	6	12	12	18	0.289	0.03	0.778	0.033	0.03	0	46.4	49.9	73.1	139	146	0	31	30
2014	9	6	12	22	18	0.289	0	0.778	0.036	0.033	0	48.2	49	73.1	143	144	0	31	30
2014	9	6	12	32	18	0.269	0.085	0.778	0.033	0.03	0	48.6	50.3	72.2	144	147	0	31	30
2014	9	6	12	42	18	0.249	0.03	0.778	0.033	0.03	0	47.7	49.5	73.5	141	145	0	30	30
2014	9	6	12	52	18	0.256	-0.007	0.778	0.039	0.036	0	47.3	49.5	72.7	141	145	0	31	30
2014	9	6	13	2	18	0.249	0.092	0.774	0.033	0.03	0	48.2	49.9	73.1	143	146	0	31	30
2014	9	6	13	12	18	0.171	0.003	0.774	0.039	0.036	0	47.7	49	73.1	143	145	0	32	31
2014	9	6	13	22	18	0.213	0.007	0.774	0.033	0.03	0	47.3	48.6	74.8	141	144	0	31	31
2014	9	6	13	32	18	0.272	0.056	0.778	0.036	0.033	0	46.9	49	74	139	144	0	30	30
2014	9	6	13	42	18	0.246	0	0.778	0.036	0.033	0	48.2	49.5	74.8	142	145	0	30	30
2014	9	6	13	52	18	0.266	0.066	0.774	0.033	0.03	0	47.7	49.5	74	142	145	0	31	30
2014	9	6	14	2	18	0.272	0.125	0.774	0.033	0.03	0	46.9	49	74	140	144	0	31	30
2014	9	6	14	12	18	0.295	0.033	0.774	0.036	0.033	0	47.7	49.9	73.1	142	145	0	31	29
2014	9	6	14	22	18	0.299	0.066	0.774	0.033	0.03	0	47.7	49	73.1	142	144	0	31	30
2014	9	6	14	32	18	0.276	0.066	0.774	0.033	0.03	0	48.2	49	72.7	143	144	0	31	30
2014	9	6	14	42	18	0.292	0.131	0.774	0.033	0.03	0	49	50.3	72.2	144	147	0	30	30
2014	9	6	14	52	18	0.358	0.135	0.774	0.033	0.03	0	48.6	49.9	71.4	144	145	0	31	29
2014	9	6	15	2	18	0.312	0.069	0.771	0.033	0.03	0	49	49.9	71.4	144	146	0	30	30
2014	9	6	15	12	18	0.276	0.125	0.774	0.033	0.033	0	49	49.9	71.4	144	146	0	30	30
2014	9	6	15	22	18	0.335	0.112	0.771	0.033	0.03	0	47.7	48.2	72.2	141	142	0	30	30
2014	9	6	15	32	18	0.335	0.072	0.771	0.033	0.03	0	46.4	48.6	71.4	139	143	0	31	30
2014	9	6	15	42	18	0.279	0.052	0.771	0.036	0.033	0	46.4	48.2	71	138	142	0	30	30
2014	9	6	15	52	18	0.23	0.125	0.771	0.033	0.03	0	46	47.7	71.8	138	140	0	31	29
2014	9	6	16	2	18	0.236	0.056	0.771	0.039	0.036	0	46.9	48.2	72.2	139	141	0	30	29
2014	9	6	16	12	18	0.223	-0.02	0.771	0.036	0.033	0	46	47.3	72.2	137	140	0	30	30
2014	9	6	16	22	18	0.187	0.059	0.768	0.03	0.03	0	46	48.2	71.8	137	141	0	30	29
2014	9	6	16	32	18	0.223	0.059	0.768	0.036	0.033	0	45.2	46.9	72.2	135	138	0	30	29
2014	9	6	16	42	18	0.226	0.049	0.768	0.036	0.033	0	44.3	46	71.8	133	136	0	30	29
2014	9	6	16	52	18	0.276	-0.013	0.768	0.039	0.036	0	44.7	45.6	71.8	135	135	0	31	29
2014	9	6	17	2	18	0.24	0.115	0.768	0.033	0.03	0	44.3	44.7	71.8	134	134	0	31	30
2014	9	6	17	12	18	0.276	0	0.768	0.039	0.036	0	43.9	43.9	71.8	132	132	0	30	30
2014	9	6	17	22	18	0.262	0.072	0.768	0.046	0.043	0	42.6	43	72.2	129	130	0	30	30
2014	9	6	17	32	18	0.217	0.072	0.768	0.039	0.036	0	43	42.1	72.2	130	127	0	30	29
2014	9	6	17	42	18	0.187	-0.02	0.764	0.033	0.03	0	43.4	42.1	71	131	127	0	30	29
2014	9	6	17	52	18	0.19	0.036	0.768	0.039	0.039	0	41.7	40.9	72.2	127	124	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	18	2	18	0.24	0.043	0.764	0.046	0.043	0	43	42.1	71.8	130	128	0	30	30
2014	9	6	18	12	18	0.285	0.203	0.764	0.039	0.039	0	46.9	45.6	69.2	139	136	0	30	30
2014	9	6	18	22	18	0.262	0.213	0.764	0.039	0.036	0	46.9	45.6	68.8	139	136	0	30	30
2014	9	6	18	32	18	0.302	0.269	0.761	0.039	0.036	0	46	44.7	70.1	137	134	0	30	30
2014	9	6	18	42	18	0.213	0.148	0.761	0.039	0.036	0	45.2	44.7	70.1	135	133	0	30	29
2014	9	6	18	52	18	0.23	0.128	0.764	0.033	0.03	0	44.7	43	70.5	134	130	0	30	30
2014	9	6	19	2	18	0.203	0.108	0.764	0.039	0.039	0	43	42.6	71	130	129	0	30	30
2014	9	6	19	12	18	0.203	0.03	0.764	0.033	0.03	0	42.6	41.7	71.8	129	127	0	30	30
2014	9	6	19	22	18	0.243	0.003	0.764	0.033	0.03	0	42.1	41.3	71.8	129	125	0	31	29
2014	9	6	19	32	18	0.223	0.085	0.764	0.036	0.033	0	42.6	41.7	71.8	129	127	0	30	30
2014	9	6	19	42	18	0.161	0.075	0.764	0.039	0.036	0	42.1	41.7	71.8	129	127	0	31	30
2014	9	6	19	52	18	0.259	0.026	0.761	0.036	0.033	0	42.6	41.7	71.8	129	127	0	30	30
2014	9	6	20	2	18	0.197	-0.007	0.764	0.043	0.039	0	42.1	41.3	71.8	129	126	0	31	30
2014	9	6	20	12	18	0.135	-0.062	0.764	0.033	0.03	0	42.6	41.7	71.8	129	127	0	30	30
2014	9	6	20	22	18	0.259	0.043	0.764	0.046	0.043	0	43.4	42.6	71.8	131	128	0	30	29
2014	9	6	20	32	18	0.184	0.003	0.764	0.033	0.03	0	43	42.6	71.8	130	128	0	30	29
2014	9	6	20	42	18	0.184	-0.02	0.764	0.033	0.03	0	43	42.6	71.8	130	129	0	30	30
2014	9	6	20	52	18	0.164	-0.007	0.764	0.036	0.033	0	43.4	42.1	72.2	131	128	0	30	30
2014	9	6	21	2	18	0.174	0.03	0.764	0.036	0.033	0	42.6	43.4	72.2	130	130	0	31	29
2014	9	6	21	12	18	0.148	0.033	0.764	0.039	0.039	0	43	42.1	71.4	130	128	0	30	30
2014	9	6	21	22	18	0.236	-0.039	0.764	0.043	0.043	0	43	43	71.8	130	130	0	30	30
2014	9	6	21	32	18	0.249	0.033	0.764	0.033	0.03	0	43.4	43	71.8	132	130	0	31	30
2014	9	6	21	42	18	0.207	-0.023	0.764	0.036	0.033	0	43.9	42.6	71.4	132	129	0	30	30
2014	9	6	21	52	18	0.246	0	0.764	0.033	0.03	0	43.4	42.6	72.7	131	129	0	30	30
2014	9	6	22	2	18	0.177	0.02	0.764	0.036	0.033	0	43	43	72.2	130	129	0	30	29
2014	9	6	22	12	18	0.22	-0.056	0.764	0.033	0.03	0	43	42.1	72.7	130	128	0	30	30
2014	9	6	22	22	18	0.184	0	0.764	0.033	0.03	0	43	42.6	72.7	130	129	0	30	30
2014	9	6	22	32	18	0.19	-0.056	0.764	0.033	0.03	0	43	41.7	73.5	130	127	0	30	30
2014	9	6	22	42	18	0.157	0	0.764	0.033	0.03	0	44.7	43.4	73.1	134	131	0	30	30
2014	9	6	22	52	18	0.223	0.046	0.764	0.033	0.03	0	43	42.6	71.8	131	129	0	31	30
2014	9	6	23	2	18	0.24	-0.052	0.764	0.033	0.03	0	43.4	43.9	71.8	133	132	0	32	30
2014	9	6	23	12	18	0.2	0.052	0.764	0.033	0.03	0	43	42.6	72.7	131	129	0	31	30
2014	9	6	23	22	18	0.174	0.007	0.764	0.036	0.033	0	43.9	43.4	72.2	133	131	0	31	30
2014	9	6	23	32	18	0.22	-0.052	0.764	0.033	0.03	0	43	42.6	72.7	131	129	0	31	30
2014	9	6	23	42	18	0.233	-0.036	0.764	0.036	0.033	0	43.4	43	73.1	132	130	0	31	30
2014	9	6	23	52	18	0.23	-0.039	0.764	0.039	0.036	0	42.1	43	73.1	129	130	0	31	30
2014	9	7	0	2	18	0.194	0.026	0.764	0.033	0.03	0	43	41.7	73.5	130	127	0	30	30
2014	9	7	0	12	18	0.18	-0.036	0.764	0.033	0.03	0	42.6	42.6	73.5	130	129	0	31	30
2014	9	7	0	22	18	0.223	-0.013	0.764	0.033	0.03	0	42.6	42.6	72.7	130	130	0	31	31
2014	9	7	0	32	18	0.18	0.013	0.764	0.033	0.03	0	43	42.6	73.5	130	129	0	30	30
2014	9	7	0	42	18	0.18	-0.02	0.764	0.043	0.043	0	42.6	43	73.1	130	130	0	31	30
2014	9	7	0	52	18	0.144	-0.049	0.764	0.036	0.033	0	43	42.1	72.7	130	128	0	30	30
2014	9	7	1	2	18	0.157	-0.036	0.764	0.033	0.03	0	41.7	42.1	73.5	128	128	0	31	30
2014	9	7	1	12	18	0.243	-0.082	0.764	0.033	0.03	0	43	43	73.5	131	130	0	31	30
2014	9	7	1	22	18	0.18	-0.066	0.764	0.033	0.03	0	43	43	73.5	131	130	0	31	30
2014	9	7	1	32	18	0.2	-0.036	0.764	0.036	0.033	0	42.6	43	73.1	130	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	1	42	18	0.253	0.02	0.764	0.033	0.03	0	42.6	43	73.5	130	130	0	31	30
2014	9	7	1	52	18	0.19	0.007	0.764	0.039	0.036	0	42.6	42.6	74	130	129	0	31	30
2014	9	7	2	2	18	0.24	-0.03	0.768	0.036	0.033	0	43.4	42.6	74	132	129	0	31	30
2014	9	7	2	12	18	0.157	-0.016	0.768	0.033	0.03	0	43	43.4	74	131	131	0	31	30
2014	9	7	2	22	18	0.177	-0.069	0.768	0.039	0.036	0	42.6	42.6	75.3	130	129	0	31	30
2014	9	7	2	32	18	0.2	0	0.768	0.036	0.033	0	43	43	74.8	131	131	0	31	31
2014	9	7	2	42	18	0.18	-0.089	0.771	0.033	0.03	0	42.6	43	74.4	130	131	0	31	31
2014	9	7	2	52	18	0.246	0	0.771	0.033	0.03	0	43.4	43	75.7	132	131	0	31	31
2014	9	7	3	2	18	0.213	-0.01	0.771	0.043	0.043	0	42.6	43	75.7	130	130	0	31	30
2014	9	7	3	12	18	0.19	-0.056	0.771	0.03	0.03	0	43	41.7	75.3	131	128	0	31	31
2014	9	7	3	22	18	0.2	-0.023	0.771	0.036	0.033	0	42.1	43	76.1	129	130	0	31	30
2014	9	7	3	32	18	0.256	0.007	0.771	0.036	0.033	0	43	43.4	77	130	131	0	30	30
2014	9	7	3	42	18	0.246	0.026	0.774	0.039	0.036	0	43	43.4	76.5	131	130	0	31	29
2014	9	7	3	52	18	0.23	0.003	0.774	0.036	0.033	0	43	43.4	76.1	132	131	0	32	30
2014	9	7	4	2	18	0.2	0.013	0.774	0.033	0.03	0	43.4	43	76.1	132	131	0	31	31
2014	9	7	4	12	18	0.19	0	0.774	0.039	0.039	0	43.4	42.6	76.1	132	129	0	31	30
2014	9	7	4	22	18	0.2	-0.013	0.774	0.033	0.03	0	43	43.4	76.1	131	131	0	31	30
2014	9	7	4	32	18	0.197	-0.066	0.774	0.036	0.033	0	43.4	42.1	75.7	132	129	0	31	31
2014	9	7	4	42	18	0.207	0	0.778	0.03	0.03	0	43.9	44.3	75.7	133	133	0	31	30
2014	9	7	4	52	18	0.164	-0.043	0.778	0.039	0.036	0	42.6	42.6	74.4	131	130	0	32	31
2014	9	7	5	2	18	0.282	-0.03	0.778	0.039	0.036	0	43	43.4	74.4	132	131	0	32	30
2014	9	7	5	12	18	0.223	0	0.778	0.033	0.03	0	43	43.4	74.8	131	131	0	31	30
2014	9	7	5	22	18	0.282	-0.026	0.778	0.036	0.033	0	42.6	43	74	130	130	0	31	30
2014	9	7	5	32	18	0.194	-0.056	0.778	0.033	0.03	0	44.3	43.9	74	134	132	0	31	30
2014	9	7	5	42	18	0.171	-0.056	0.781	0.039	0.036	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	7	5	52	18	0.213	-0.036	0.781	0.033	0.03	0	43.9	43.9	72.7	134	132	0	32	30
2014	9	7	6	2	18	0.167	-0.036	0.781	0.036	0.033	0	43.9	43.4	72.7	133	131	0	31	30
2014	9	7	6	12	18	0.272	-0.052	0.781	0.033	0.03	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	7	6	22	18	0.226	-0.069	0.781	0.039	0.039	0	42.6	42.1	73.5	130	128	0	31	30
2014	9	7	6	32	18	0.236	-0.043	0.784	0.036	0.033	0	42.1	41.7	73.5	129	127	0	31	30
2014	9	7	6	42	18	0.21	-0.079	0.784	0.039	0.036	0	42.1	42.6	73.5	129	129	0	31	30
2014	9	7	6	52	18	0.253	-0.026	0.784	0.036	0.033	0	42.1	41.3	71.8	130	127	0	32	31
2014	9	7	7	2	18	0.21	-0.039	0.787	0.039	0.036	0	41.3	40.9	72.2	128	125	0	32	30
2014	9	7	7	12	18	0.21	-0.003	0.791	0.036	0.033	0	41.7	41.7	72.2	128	127	0	31	30
2014	9	7	7	22	18	0.22	-0.043	0.794	0.036	0.033	0	41.3	40.9	72.2	128	126	0	32	31
2014	9	7	7	32	18	0.213	-0.059	0.794	0.033	0.03	0	41.7	41.7	72.7	128	128	0	31	31
2014	9	7	7	42	18	0.226	-0.046	0.797	0.033	0.03	0	41.7	41.7	73.1	128	127	0	31	30
2014	9	7	7	52	18	0.279	-0.01	0.797	0.033	0.03	0	41.3	41.3	72.7	127	127	0	31	31
2014	9	7	8	2	18	0.259	-0.052	0.797	0.039	0.039	0	42.1	41.3	73.1	129	127	0	31	31
2014	9	7	8	12	18	0.223	0	0.797	0.033	0.03	0	42.1	41.7	73.1	129	127	0	31	30
2014	9	7	8	22	18	0.259	-0.03	0.797	0.033	0.03	0	42.1	41.3	74	129	127	0	31	31
2014	9	7	8	32	18	0.203	-0.059	0.797	0.033	0.03	0	41.7	42.1	73.1	129	128	0	32	30
2014	9	7	8	42	18	0.246	0.003	0.801	0.033	0.03	0	42.1	41.7	73.1	129	128	0	31	31
2014	9	7	8	52	18	0.226	0	0.801	0.039	0.036	0	42.6	41.7	74	130	128	0	31	31
2014	9	7	9	2	18	0.272	-0.062	0.801	0.036	0.033	0	42.6	42.6	74	130	129	0	31	30
2014	9	7	9	12	18	0.226	-0.039	0.801	0.033	0.03	0	42.1	42.6	74	130	130	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	9	22	18	0.253	-0.052	0.801	0.036	0.033	0	43	43.4	74	131	131	0	31	30
2014	9	7	9	32	18	0.312	0.069	0.801	0.033	0.03	0	43.4	43.9	74	132	133	0	31	31
2014	9	7	9	42	18	0.266	-0.007	0.801	0.033	0.03	0	43.9	45.2	73.1	133	136	0	31	31
2014	9	7	9	52	18	0.18	0	0.801	0.033	0.03	0	43.9	45.2	72.7	134	135	0	32	30
2014	9	7	10	2	18	0.282	0.046	0.801	0.039	0.036	0	44.3	45.2	74	134	136	0	31	31
2014	9	7	10	12	18	0.276	0.036	0.801	0.033	0.033	0	45.2	46.4	71.8	136	138	0	31	30
2014	9	7	10	22	18	0.233	0.033	0.804	0.036	0.033	0	45.2	46.9	72.2	136	139	0	31	30
2014	9	7	10	32	18	0.325	0.066	0.804	0.033	0.03	0	45.6	47.3	72.7	137	140	0	31	30
2014	9	7	10	42	18	0.305	0.033	0.804	0.03	0.03	0	46	46.9	73.5	138	139	0	31	30
2014	9	7	10	52	18	0.217	0.016	0.801	0.033	0.03	0	46.9	47.7	71.8	140	141	0	31	30
2014	9	7	11	2	18	0.259	0.049	0.801	0.033	0.033	0	47.7	48.6	71.4	142	143	0	31	30
2014	9	7	11	12	18	0.282	0.03	0.801	0.036	0.033	0	47.7	48.2	71.4	142	143	0	31	31
2014	9	7	11	22	18	0.243	0.115	0.801	0.033	0.03	0	48.6	50.3	71	144	147	0	31	30
2014	9	7	11	32	18	0.272	0.062	0.801	0.033	0.03	0	49	49.9	71	145	146	0	31	30
2014	9	7	11	42	18	0.272	0.072	0.801	0.033	0.03	0	48.2	50.3	70.1	144	147	0	32	30
2014	9	7	11	52	18	0.322	0.062	0.801	0.033	0.03	0	49.9	50.7	69.7	147	148	0	31	30
2014	9	7	12	2	18	0.308	0.115	0.801	0.039	0.039	0	51.2	52	67.9	150	151	0	31	30
2014	9	7	12	12	18	0.289	0.112	0.801	0.036	0.033	0	52	52.5	67.1	152	152	0	31	30
2014	9	7	12	22	18	0.292	0.075	0.801	0.039	0.036	0	51.6	52.5	67.1	151	153	0	31	31
2014	9	7	12	32	18	0.269	0.184	0.801	0.033	0.03	0	51.6	52.5	67.5	151	152	0	31	30
2014	9	7	12	42	18	0.351	0.121	0.801	0.036	0.033	0	51.2	51.6	67.1	150	151	0	31	31
2014	9	7	12	52	18	0.308	0.226	0.801	0.033	0.03	0	51.6	52.5	66.2	151	152	0	31	30
2014	9	7	13	2	18	0.331	0.131	0.801	0.033	0.03	0	51.6	52.5	67.1	151	152	0	31	30
2014	9	7	13	12	18	0.266	0.18	0.801	0.039	0.039	0	52	52.5	65.8	152	152	0	31	30
2014	9	7	13	22	18	0.299	0.121	0.801	0.036	0.033	0	51.6	52.5	66.2	151	152	0	31	30
2014	9	7	13	32	18	0.292	0.144	0.797	0.036	0.033	0	52.9	52.9	65.8	153	153	0	30	30
2014	9	7	13	42	18	0.328	0.174	0.797	0.039	0.039	0	53.3	53.3	66.2	154	154	0	30	30
2014	9	7	13	52	18	0.315	0.22	0.797	0.039	0.039	0	52	52.5	64.9	151	152	0	30	30
2014	9	7	14	2	18	0.341	0.184	0.797	0.036	0.033	0	52.5	52.5	67.1	153	152	0	31	30
2014	9	7	14	12	18	0.322	0.18	0.794	0.033	0.03	0	51.6	51.2	66.2	150	149	0	30	30
2014	9	7	14	22	18	0.282	0.21	0.794	0.036	0.033	0	51.2	51.6	66.7	150	150	0	31	30
2014	9	7	14	32	18	0.331	0.2	0.794	0.033	0.03	0	51.2	51.6	67.9	149	150	0	30	30
2014	9	7	14	42	18	0.351	0.125	0.794	0.033	0.03	0	50.3	51.6	68.8	148	149	0	31	29
2014	9	7	14	52	18	0.348	0.089	0.794	0.039	0.036	0	50.3	51.6	67.1	147	149	0	30	29
2014	9	7	15	2	18	0.262	0.095	0.794	0.03	0.03	0	49.5	52	67.1	146	150	0	31	29
2014	9	7	15	12	18	0.328	0.066	0.794	0.033	0.03	0	49	51.6	68.4	145	149	0	31	29
2014	9	7	15	22	18	0.331	0.089	0.794	0.03	0.03	0	48.6	48.6	70.1	143	143	0	30	30
2014	9	7	15	32	18	0.23	0.108	0.791	0.033	0.03	0	47.7	49	70.5	141	144	0	30	30
2014	9	7	15	42	18	0.272	0.066	0.791	0.033	0.03	0	49	50.7	71	144	148	0	30	30
2014	9	7	15	52	18	0.243	0.128	0.791	0.033	0.03	0	48.2	50.3	71.4	142	146	0	30	29
2014	9	7	16	2	18	0.233	0.082	0.791	0.033	0.03	0	45.6	46	71.8	136	136	0	30	29
2014	9	7	16	12	18	0.262	0	0.791	0.033	0.03	0	44.7	46.4	72.2	134	137	0	30	29
2014	9	7	16	22	18	0.279	0.082	0.791	0.039	0.036	0	48.6	49.9	71.4	143	146	0	30	30
2014	9	7	16	32	18	0.282	0.075	0.791	0.036	0.033	0	46.9	47.7	71.4	139	141	0	30	30
2014	9	7	16	42	18	0.361	0.121	0.791	0.036	0.033	0	49.9	49.9	69.2	146	146	0	30	30
2014	9	7	16	52	18	0.299	0.203	0.791	0.036	0.033	0	48.6	47.7	67.9	143	140	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	17	2	18	0.308	0.223	0.791	0.039	0.036	0	48.2	47.3	69.2	142	139	0	30	29
2014	9	7	17	12	18	0.364	0.184	0.791	0.033	0.03	0	48.6	48.2	69.7	143	142	0	30	30
2014	9	7	17	22	18	0.279	0.197	0.791	0.033	0.03	0	46.4	44.7	70.1	138	134	0	30	30
2014	9	7	17	32	18	0.302	0.253	0.791	0.039	0.036	0	46	44.3	70.5	137	133	0	30	30
2014	9	7	17	42	18	0.292	0.18	0.791	0.039	0.036	0	45.2	44.7	71	136	133	0	31	29
2014	9	7	17	52	18	0.299	0.285	0.791	0.036	0.033	0	44.7	43.4	70.5	134	131	0	30	30
2014	9	7	18	2	18	0.302	0.253	0.794	0.036	0.033	0	44.7	43	71	134	130	0	30	30
2014	9	7	18	12	18	0.302	0.253	0.794	0.039	0.039	0	45.2	43.9	71	135	132	0	30	30
2014	9	7	18	22	18	0.318	0.21	0.794	0.039	0.036	0	44.7	43.4	71	135	130	0	31	29
2014	9	7	18	32	18	0.315	0.253	0.794	0.039	0.036	0	44.7	43.9	71	134	132	0	30	30
2014	9	7	18	42	18	0.299	0.2	0.797	0.039	0.036	0	44.7	43.9	71.8	134	131	0	30	29
2014	9	7	18	52	18	0.276	0.174	0.797	0.033	0.03	0	44.3	43.9	71.4	133	131	0	30	29
2014	9	7	19	2	18	0.279	0.194	0.797	0.036	0.033	0	43.9	42.6	71.4	132	129	0	30	30
2014	9	7	19	12	18	0.24	0.138	0.797	0.033	0.03	0	43.9	43	71.8	133	129	0	31	29
2014	9	7	19	22	18	0.344	0.089	0.797	0.039	0.036	0	44.3	43.4	70.5	133	131	0	30	30
2014	9	7	19	32	18	0.305	-0.003	0.794	0.039	0.039	0	50.3	49	63.6	147	143	0	30	29
2014	9	7	19	42	18	0.233	0.01	0.794	0.033	0.03	0	46.4	46	67.5	139	136	0	31	29
2014	9	7	19	52	18	0.272	-0.016	0.801	0.039	0.036	0	46.9	45.2	69.2	139	135	0	30	30
2014	9	7	20	2	18	0.276	0.007	0.804	0.033	0.03	0	46	45.6	69.7	138	135	0	31	29
2014	9	7	20	12	18	0.276	-0.013	0.804	0.033	0.03	0	46	46	70.1	138	136	0	31	29
2014	9	7	20	22	18	0.335	0.049	0.804	0.036	0.033	0	46	45.6	69.7	138	136	0	31	30
2014	9	7	20	32	18	0.243	0	0.804	0.039	0.036	0	46.4	46.4	71	138	137	0	30	29
2014	9	7	20	42	18	0.22	0.023	0.804	0.039	0.036	0	46.4	46.4	70.1	139	137	0	31	29
2014	9	7	20	52	18	0.226	0.082	0.804	0.033	0.03	0	46	45.2	71	137	135	0	30	30
2014	9	7	21	2	18	0.312	0.089	0.807	0.046	0.043	0	46	45.2	71.8	137	135	0	30	30
2014	9	7	21	12	18	0.213	0.046	0.807	0.036	0.033	0	45.6	43.9	71.8	136	132	0	30	30
2014	9	7	21	22	18	0.246	0.056	0.807	0.036	0.033	0	45.2	44.7	72.7	135	133	0	30	29
2014	9	7	21	32	18	0.302	0.072	0.807	0.033	0.03	0	44.3	45.2	72.7	134	134	0	31	29
2014	9	7	21	42	18	0.299	0.049	0.807	0.043	0.039	0	45.6	44.3	72.7	136	133	0	30	30
2014	9	7	21	52	18	0.233	-0.02	0.807	0.043	0.043	0	45.2	45.6	72.7	135	135	0	30	29
2014	9	7	22	2	18	0.266	-0.036	0.807	0.033	0.03	0	45.2	44.3	72.7	135	133	0	30	30
2014	9	7	22	12	18	0.276	-0.023	0.807	0.039	0.036	0	45.2	44.3	73.1	135	133	0	30	30
2014	9	7	22	22	18	0.217	0.02	0.807	0.036	0.033	0	44.3	43.9	72.7	134	132	0	31	30
2014	9	7	22	32	18	0.266	0.02	0.807	0.036	0.033	0	45.2	44.3	73.5	135	133	0	30	30
2014	9	7	22	42	18	0.285	-0.023	0.807	0.033	0.03	0	45.6	44.7	74	136	134	0	30	30
2014	9	7	22	52	18	0.295	0.03	0.807	0.036	0.033	0	44.7	45.2	73.5	135	134	0	31	29
2014	9	7	23	2	18	0.302	0.033	0.807	0.033	0.03	0	43.9	44.3	73.5	132	132	0	30	29
2014	9	7	23	12	18	0.207	0.013	0.81	0.033	0.03	0	44.7	44.7	73.1	134	134	0	30	30
2014	9	7	23	22	18	0.289	0.033	0.81	0.033	0.03	0	43.9	44.3	74	133	132	0	31	29
2014	9	7	23	32	18	0.285	0.023	0.81	0.036	0.033	0	44.7	44.3	74.4	134	133	0	30	30
2014	9	7	23	42	18	0.276	-0.003	0.81	0.039	0.039	0	43.9	43.4	74.4	132	131	0	30	30
2014	9	7	23	52	18	0.328	-0.046	0.81	0.033	0.03	0	43	43	74.4	131	130	0	31	30
2014	9	8	0	2	18	0.236	0.039	0.81	0.033	0.033	0	44.3	43.9	74.8	133	132	0	30	30
2014	9	8	0	12	18	0.217	-0.052	0.81	0.036	0.033	0	45.2	44.3	75.7	135	133	0	30	30
2014	9	8	0	22	18	0.269	-0.046	0.81	0.033	0.03	0	44.7	44.7	74.8	135	134	0	31	30
2014	9	8	0	32	18	0.22	0.066	0.81	0.039	0.036	0	44.3	44.7	74.8	134	133	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	0	42	18	0.262	-0.072	0.81	0.036	0.033	0	44.3	43.9	75.3	133	132	0	30	30
2014	9	8	0	52	18	0.24	-0.007	0.81	0.033	0.03	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	8	1	2	18	0.226	-0.056	0.81	0.036	0.033	0	44.3	43.9	75.3	134	132	0	31	30
2014	9	8	1	12	18	0.207	-0.013	0.81	0.033	0.03	0	43.9	43.9	75.3	133	131	0	31	29
2014	9	8	1	22	18	0.289	0.033	0.81	0.033	0.03	0	43.9	43.4	74.8	132	131	0	30	30
2014	9	8	1	32	18	0.272	0.033	0.81	0.033	0.03	0	44.3	43.4	75.7	133	131	0	30	30
2014	9	8	1	42	18	0.292	0	0.81	0.036	0.033	0	43.4	43	75.3	132	130	0	31	30
2014	9	8	1	52	18	0.299	-0.056	0.81	0.039	0.036	0	43.4	43.9	74.8	132	131	0	31	29
2014	9	8	2	2	18	0.279	-0.03	0.81	0.033	0.03	0	43.4	43	74.8	132	130	0	31	30
2014	9	8	2	12	18	0.305	0.02	0.81	0.033	0.03	0	46	45.2	73.1	137	135	0	30	30
2014	9	8	2	22	18	0.325	-0.052	0.807	0.039	0.036	0	47.7	47.3	71	141	140	0	30	30
2014	9	8	2	32	18	0.282	0.033	0.807	0.033	0.03	0	48.2	46.9	70.5	143	139	0	31	30
2014	9	8	2	42	18	0.354	0.02	0.807	0.039	0.039	0	49.5	48.2	70.1	145	142	0	30	30
2014	9	8	2	52	18	0.272	0.026	0.807	0.033	0.03	0	48.6	48.2	70.5	144	142	0	31	30
2014	9	8	3	2	18	0.315	-0.003	0.807	0.039	0.036	0	48.6	48.2	71.4	144	142	0	31	30
2014	9	8	3	12	18	0.381	0.026	0.807	0.036	0.033	0	47.7	46.4	71.4	141	139	0	30	31
2014	9	8	3	22	18	0.308	0.069	0.807	0.039	0.036	0	47.3	45.6	71.4	141	137	0	31	31
2014	9	8	3	32	18	0.289	0.052	0.807	0.039	0.036	0	46	45.2	72.2	138	135	0	31	30
2014	9	8	3	42	18	0.236	0.049	0.807	0.033	0.03	0	45.6	44.3	73.1	137	134	0	31	31
2014	9	8	3	52	18	0.233	0.092	0.807	0.033	0.03	0	45.2	45.2	73.1	136	134	0	31	29
2014	9	8	4	2	18	0.292	0.033	0.807	0.033	0.03	0	45.6	44.7	72.7	137	134	0	31	30
2014	9	8	4	12	18	0.2	0.095	0.807	0.033	0.03	0	45.6	45.2	72.7	137	134	0	31	29
2014	9	8	4	22	18	0.253	0.052	0.804	0.033	0.03	0	45.6	46	71.8	137	137	0	31	30
2014	9	8	4	32	18	0.19	0.023	0.804	0.049	0.046	0	49	49	69.7	144	144	0	30	30
2014	9	8	4	42	18	0.24	0.033	0.804	0.039	0.036	0	50.3	49.9	67.9	147	146	0	30	30
2014	9	8	4	52	18	0.23	0.016	0.804	0.033	0.03	0	50.7	49.9	67.9	149	146	0	31	30
2014	9	8	5	2	18	0.272	0.079	0.804	0.033	0.03	0	52	51.2	67.5	151	149	0	30	30
2014	9	8	5	12	18	0.253	0.072	0.804	0.036	0.033	0	52	51.6	66.7	152	149	0	31	29
2014	9	8	5	22	18	0.312	0.072	0.804	0.033	0.03	0	52.5	50.7	66.7	152	148	0	30	30
2014	9	8	5	32	18	0.21	0.072	0.804	0.036	0.033	0	51.6	50.7	66.7	151	148	0	31	30
2014	9	8	5	42	18	0.266	0.187	0.804	0.036	0.033	0	51.6	49.9	66.2	150	146	0	30	30
2014	9	8	5	52	18	0.322	0.115	0.804	0.039	0.036	0	50.3	49	66.7	148	144	0	31	30
2014	9	8	6	2	18	0.308	0.121	0.804	0.036	0.033	0	49.5	48.6	67.9	146	142	0	31	29
2014	9	8	6	12	18	0.341	0.148	0.804	0.039	0.036	0	49.9	48.2	68.8	146	142	0	30	30
2014	9	8	6	22	18	0.354	0.154	0.804	0.033	0.03	0	49	47.3	68.4	144	140	0	30	30
2014	9	8	6	32	18	0.364	0.108	0.804	0.039	0.036	0	48.2	47.3	69.2	143	140	0	31	30
2014	9	8	6	42	18	0.269	0.18	0.804	0.036	0.033	0	47.3	46.4	70.5	141	138	0	31	30
2014	9	8	6	52	18	0.318	0.112	0.804	0.033	0.03	0	46.9	46	70.5	140	137	0	31	30
2014	9	8	7	2	18	0.325	0.141	0.801	0.033	0.03	0	47.3	46	68.4	140	138	0	30	31
2014	9	8	7	12	18	0.253	0.157	0.804	0.036	0.033	0	47.3	45.6	70.5	140	136	0	30	30
2014	9	8	7	22	18	0.364	0.082	0.804	0.036	0.033	0	46.9	45.6	71.4	140	136	0	31	30
2014	9	8	7	32	18	0.325	0.043	0.804	0.033	0.03	0	46.9	46	71	139	136	0	30	29
2014	9	8	7	42	18	0.285	0.033	0.801	0.039	0.036	0	46.9	45.2	71	140	135	0	31	30
2014	9	8	7	52	18	0.276	0.115	0.801	0.036	0.033	0	46	45.2	70.5	138	135	0	31	30
2014	9	8	8	2	18	0.269	0.049	0.801	0.033	0.03	0	46	45.2	71	137	136	0	30	31
2014	9	8	8	12	18	0.302	0.089	0.801	0.036	0.033	0	45.6	44.7	71.4	137	134	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	8	22	18	0.299	0.092	0.801	0.033	0.03	0	44.7	44.7	71.4	135	134	0	31	30
2014	9	8	8	32	18	0.299	0.138	0.797	0.039	0.036	0	49	48.2	67.1	145	142	0	31	30
2014	9	8	8	42	18	0.259	0.098	0.801	0.036	0.033	0	48.2	46	69.7	142	138	0	30	31
2014	9	8	8	52	18	0.302	0.105	0.801	0.033	0.03	0	49	48.6	69.2	145	143	0	31	30
2014	9	8	9	2	18	0.249	0.131	0.797	0.033	0.03	0	49.9	49	67.9	147	145	0	31	31
2014	9	8	9	12	18	0.246	0.184	0.801	0.039	0.039	0	50.3	49.9	66.2	149	146	0	32	30
2014	9	8	9	22	18	0.289	0.184	0.797	0.039	0.036	0	50.7	49.5	67.1	149	145	0	31	30
2014	9	8	9	32	18	0.341	0.157	0.797	0.033	0.03	0	50.7	50.7	66.7	149	147	0	31	29
2014	9	8	9	42	18	0.285	0.141	0.797	0.036	0.033	0	51.2	50.7	66.2	150	148	0	31	30
2014	9	8	9	52	18	0.259	0.164	0.797	0.036	0.033	0	50.3	49.9	66.7	148	146	0	31	30
2014	9	8	10	2	18	0.312	0.105	0.797	0.036	0.033	0	49.5	49	68.8	146	144	0	31	30
2014	9	8	10	12	18	0.276	0.138	0.791	0.03	0.026	0	51.6	50.7	65.4	151	148	0	31	30
2014	9	8	10	22	18	0.217	0.213	0.797	0.033	0.03	0	52.9	51.6	64.9	153	150	0	30	30
2014	9	8	10	32	18	0.305	0.141	0.797	0.036	0.033	0	54.6	54.6	63.6	158	157	0	31	30
2014	9	8	10	42	18	0.295	0.118	0.797	0.039	0.036	0	55.9	55	62.8	160	158	0	30	30
2014	9	8	10	52	18	0.305	0.177	0.794	0.033	0.03	0	56.3	55.5	60.6	162	159	0	31	30
2014	9	8	11	2	18	0.344	0.167	0.794	0.036	0.033	0	55.9	55.5	60.2	161	159	0	31	30
2014	9	8	11	12	18	0.351	0.249	0.791	0.036	0.033	0	55.9	55.9	61.5	161	159	0	31	29
2014	9	8	11	22	18	0.285	0.259	0.791	0.036	0.033	0	55	54.6	61.5	159	157	0	31	30
2014	9	8	11	32	18	0.367	0.207	0.791	0.043	0.039	0	55	54.6	61.5	159	157	0	31	30
2014	9	8	11	42	18	0.308	0.236	0.787	0.036	0.033	0	55	54.2	62.8	158	156	0	30	30
2014	9	8	11	52	18	0.292	0.226	0.787	0.036	0.033	0	54.2	53.8	63.2	157	155	0	31	30
2014	9	8	12	2	18	0.338	0.203	0.787	0.039	0.039	0	54.2	53.3	62.4	157	154	0	31	30
2014	9	8	12	12	18	0.341	0.184	0.787	0.036	0.033	0	54.2	53.3	63.2	157	154	0	31	30
2014	9	8	12	22	18	0.358	0.23	0.787	0.036	0.033	0	53.3	54.2	63.6	155	156	0	31	30
2014	9	8	12	32	18	0.285	0.285	0.787	0.033	0.03	0	52.9	52.9	64.1	154	153	0	31	30
2014	9	8	12	42	18	0.322	0.331	0.784	0.036	0.033	0	53.3	52.9	64.9	155	153	0	31	30
2014	9	8	12	52	18	0.39	0.272	0.784	0.03	0.03	0	53.8	53.8	65.4	155	154	0	30	29
2014	9	8	13	2	18	0.433	0.338	0.784	0.039	0.036	0	50.7	49.5	65.4	148	145	0	30	30
2014	9	8	13	12	18	0.322	0.18	0.781	0.033	0.03	0	56.8	56.3	61.9	163	161	0	31	30
2014	9	8	13	22	18	0.308	0.282	0.784	0.036	0.033	0	55.9	55.9	62.8	161	160	0	31	30
2014	9	8	13	32	18	0.331	0.259	0.784	0.039	0.036	0	55	53.8	63.6	158	155	0	30	30
2014	9	8	13	42	18	0.348	0.322	0.784	0.036	0.033	0	56.3	55.5	63.2	161	158	0	30	29
2014	9	8	13	52	18	0.371	0.236	0.784	0.036	0.033	0	55.9	55.5	62.4	161	158	0	31	29
2014	9	8	14	2	18	0.328	0.312	0.784	0.036	0.033	0	54.2	53.8	63.6	157	154	0	31	29
2014	9	8	14	12	18	0.423	0.374	0.784	0.039	0.036	0	54.6	54.2	64.5	158	155	0	31	29
2014	9	8	14	22	18	0.325	0.374	0.784	0.043	0.039	0	54.2	53.3	65.4	157	154	0	31	30
2014	9	8	14	32	18	0.407	0.312	0.784	0.039	0.036	0	54.2	54.6	64.9	157	156	0	31	29
2014	9	8	14	42	18	0.312	0.43	0.784	0.039	0.039	0	53.8	53.3	65.8	156	154	0	31	30
2014	9	8	14	52	18	0.367	0.328	0.784	0.033	0.03	0	54.2	53.3	65.8	156	154	0	30	30
2014	9	8	15	2	18	0.331	0.377	0.784	0.039	0.036	0	52.5	51.2	67.5	152	149	0	30	30
2014	9	8	15	12	18	0.276	0.351	0.781	0.039	0.036	0	52	51.6	67.5	151	149	0	30	29
2014	9	8	15	22	18	0.351	0.312	0.781	0.033	0.03	0	52	51.6	67.5	151	150	0	30	30
2014	9	8	15	32	18	0.289	0.367	0.784	0.039	0.036	0	51.2	50.3	68.8	149	146	0	30	29
2014	9	8	15	42	18	0.377	0.266	0.781	0.03	0.03	0	52.5	52.5	68.4	152	151	0	30	29
2014	9	8	15	52	18	0.436	0.253	0.784	0.033	0.03	0	52	52	67.9	151	150	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	16	2	18	0.381	0.312	0.781	0.039	0.036	0	50.7	50.7	68.8	149	148	0	31	30
2014	9	8	16	12	18	0.331	0.299	0.781	0.039	0.036	0	51.6	51.6	68.8	150	150	0	30	30
2014	9	8	16	22	18	0.348	0.299	0.781	0.036	0.033	0	51.6	51.2	69.7	150	148	0	30	29
2014	9	8	16	32	18	0.384	0.351	0.781	0.033	0.03	0	49.9	49.9	70.5	147	146	0	31	30
2014	9	8	16	42	18	0.279	0.427	0.784	0.043	0.039	0	48.6	47.3	71.8	143	139	0	30	29
2014	9	8	16	52	18	0.322	0.384	0.781	0.043	0.039	0	47.3	46	72.2	140	136	0	30	29
2014	9	8	17	2	18	0.335	0.476	0.784	0.036	0.033	0	47.3	46	71.8	140	136	0	30	29
2014	9	8	17	12	18	0.308	0.285	0.781	0.036	0.033	0	48.6	47.7	70.1	143	140	0	30	29
2014	9	8	17	22	18	0.377	0.295	0.784	0.039	0.039	0	48.2	46.9	71	142	138	0	30	29
2014	9	8	17	32	18	0.299	0.253	0.784	0.033	0.03	0	48.2	47.3	71.8	142	140	0	30	30
2014	9	8	17	42	18	0.358	0.292	0.781	0.039	0.036	0	48.2	47.7	72.7	142	140	0	30	29
2014	9	8	17	52	18	0.243	0.318	0.784	0.039	0.036	0	47.7	46.4	72.2	142	138	0	31	30
2014	9	8	18	2	18	0.292	0.292	0.784	0.036	0.033	0	47.7	46	71.8	141	136	0	30	29
2014	9	8	18	12	18	0.292	0.269	0.781	0.039	0.039	0	46.9	44.7	73.1	139	134	0	30	30
2014	9	8	18	22	18	0.24	0.187	0.784	0.033	0.03	0	45.6	44.3	72.7	137	133	0	31	30
2014	9	8	18	32	18	0.299	0.243	0.784	0.046	0.043	0	46	44.3	73.5	137	132	0	30	29
2014	9	8	18	42	18	0.279	0.233	0.784	0.039	0.036	0	45.6	43.9	74.4	136	132	0	30	30
2014	9	8	18	52	18	0.259	0.207	0.784	0.033	0.03	0	44.7	43.9	74.4	134	131	0	30	29
2014	9	8	19	2	18	0.256	0.115	0.784	0.036	0.033	0	44.7	44.7	74	134	133	0	30	29
2014	9	8	19	12	18	0.246	0.135	0.784	0.039	0.036	0	45.2	44.3	74.4	135	132	0	30	29
2014	9	8	19	22	18	0.262	0.135	0.784	0.039	0.036	0	43.9	43.4	75.3	132	130	0	30	29
2014	9	8	19	32	18	0.308	0.069	0.784	0.033	0.03	0	44.3	43	74.8	133	129	0	30	29
2014	9	8	19	42	18	0.249	0.059	0.784	0.036	0.033	0	44.3	43	75.3	133	129	0	30	29
2014	9	8	19	52	18	0.203	0.023	0.784	0.033	0.03	0	44.3	43.4	75.3	133	131	0	30	30
2014	9	8	20	2	18	0.259	0.023	0.784	0.033	0.03	0	44.3	43.9	75.3	133	131	0	30	29
2014	9	8	20	12	18	0.233	0.043	0.784	0.036	0.033	0	43.9	43.4	74.8	133	131	0	31	30
2014	9	8	20	22	18	0.236	0.036	0.784	0.033	0.03	0	44.3	43.9	74	133	131	0	30	29
2014	9	8	20	32	18	0.269	-0.02	0.784	0.033	0.03	0	44.3	43	74.4	133	129	0	30	29
2014	9	8	20	42	18	0.266	0.066	0.784	0.033	0.03	0	43.4	43	74.8	132	130	0	31	30
2014	9	8	20	52	18	0.2	0.033	0.784	0.033	0.03	0	44.3	43	74.4	133	129	0	30	29
2014	9	8	21	2	18	0.266	0.01	0.784	0.039	0.036	0	44.7	44.3	73.1	134	132	0	30	29
2014	9	8	21	12	18	0.203	0	0.784	0.039	0.039	0	45.2	43.4	73.5	135	131	0	30	30
2014	9	8	21	22	18	0.223	-0.036	0.784	0.033	0.03	0	43.9	43	74	132	130	0	30	30
2014	9	8	21	32	18	0.243	-0.003	0.784	0.03	0.03	0	46.4	45.6	71.8	138	135	0	30	29
2014	9	8	21	42	18	0.351	0	0.784	0.039	0.039	0	46	45.6	71.8	137	136	0	30	30
2014	9	8	21	52	18	0.184	0.056	0.784	0.039	0.036	0	46	45.2	72.2	138	135	0	31	30
2014	9	8	22	2	18	0.24	-0.01	0.784	0.039	0.036	0	46	44.7	71.8	137	133	0	30	29
2014	9	8	22	12	18	0.21	-0.072	0.784	0.036	0.033	0	45.6	44.7	73.5	136	133	0	30	29
2014	9	8	22	22	18	0.197	-0.013	0.784	0.036	0.033	0	44.7	43.9	73.1	134	132	0	30	30
2014	9	8	22	32	18	0.276	-0.03	0.784	0.033	0.03	0	45.6	43.9	73.1	137	132	0	31	30
2014	9	8	22	42	18	0.217	-0.043	0.784	0.039	0.036	0	45.2	44.7	72.7	136	134	0	31	30
2014	9	8	22	52	18	0.217	-0.01	0.784	0.039	0.036	0	44.7	44.7	72.2	134	133	0	30	29
2014	9	8	23	2	18	0.272	0.049	0.784	0.033	0.03	0	45.2	45.2	72.2	135	134	0	30	29
2014	9	8	23	12	18	0.253	0.039	0.784	0.036	0.033	0	45.6	44.3	72.7	136	133	0	30	30
2014	9	8	23	22	18	0.24	0	0.784	0.036	0.033	0	45.6	45.2	71.4	137	135	0	31	30
2014	9	8	23	32	18	0.207	0.013	0.784	0.036	0.033	0	45.2	45.2	71.4	136	134	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	23	42	18	0.144	-0.026	0.784	0.033	0.03	0	45.6	44.3	71	137	133	0	31	30
2014	9	8	23	52	18	0.325	-0.069	0.784	0.039	0.036	0	45.6	45.2	70.1	137	135	0	31	30
2014	9	9	0	2	18	0.256	0	0.787	0.039	0.036	0	45.6	45.6	69.7	137	136	0	31	30
2014	9	9	0	12	18	0.276	-0.049	0.787	0.036	0.033	0	46	45.6	71	137	136	0	30	30
2014	9	9	0	22	18	0.213	0.016	0.787	0.036	0.033	0	46	45.2	71	137	135	0	30	30
2014	9	9	0	32	18	0.233	0	0.787	0.039	0.036	0	46.4	45.6	70.1	138	136	0	30	30
2014	9	9	0	42	18	0.279	0.016	0.784	0.033	0.03	0	46	45.2	70.1	138	135	0	31	30
2014	9	9	0	52	18	0.285	0.016	0.787	0.036	0.033	0	45.2	44.7	71	136	134	0	31	30
2014	9	9	1	2	18	0.246	0.039	0.787	0.039	0.036	0	46	45.2	70.1	137	135	0	30	30
2014	9	9	1	12	18	0.259	0.026	0.787	0.046	0.043	0	46.4	45.6	68.8	139	137	0	31	31
2014	9	9	1	22	18	0.256	0.016	0.791	0.036	0.033	0	47.3	46.4	69.2	141	138	0	31	30
2014	9	9	1	32	18	0.285	-0.023	0.791	0.033	0.03	0	46.9	46	68.8	140	137	0	31	30
2014	9	9	1	42	18	0.279	-0.007	0.787	0.039	0.036	0	49	48.2	67.9	145	142	0	31	30
2014	9	9	1	52	18	0.194	0.043	0.791	0.039	0.039	0	49.5	48.2	66.7	146	142	0	31	30
2014	9	9	2	2	18	0.249	0.059	0.791	0.039	0.039	0	49.5	48.6	65.8	146	143	0	31	30
2014	9	9	2	12	18	0.276	0.02	0.794	0.039	0.036	0	48.6	47.7	67.1	143	141	0	30	30
2014	9	9	2	22	18	0.2	0.039	0.794	0.036	0.033	0	47.7	46	68.8	142	137	0	31	30
2014	9	9	2	32	18	0.259	-0.033	0.794	0.036	0.033	0	46.4	46	68.8	139	137	0	31	30
2014	9	9	2	42	18	0.299	0.013	0.794	0.036	0.033	0	46	45.2	70.1	138	135	0	31	30
2014	9	9	2	52	18	0.259	0.01	0.797	0.033	0.03	0	45.2	44.7	71	136	134	0	31	30
2014	9	9	3	2	18	0.249	0.059	0.797	0.036	0.033	0	45.2	44.7	70.1	136	134	0	31	30
2014	9	9	3	12	18	0.276	0.02	0.797	0.033	0.03	0	45.6	44.7	70.1	137	134	0	31	30
2014	9	9	3	22	18	0.249	-0.036	0.797	0.036	0.033	0	45.2	44.3	69.7	136	133	0	31	30
2014	9	9	3	32	18	0.223	0.023	0.797	0.036	0.033	0	43.9	43.9	71	133	132	0	31	30
2014	9	9	3	42	18	0.249	-0.023	0.797	0.036	0.033	0	44.3	44.3	71.8	134	133	0	31	30
2014	9	9	3	52	18	0.184	-0.052	0.797	0.039	0.036	0	44.3	43	71.8	134	131	0	31	31
2014	9	9	4	2	18	0.253	-0.036	0.797	0.033	0.03	0	43.9	43.4	71.8	133	131	0	31	30
2014	9	9	4	12	18	0.226	-0.02	0.797	0.033	0.03	0	44.3	43	71	134	131	0	31	31
2014	9	9	4	22	18	0.256	-0.013	0.797	0.033	0.03	0	46	44.7	70.1	138	134	0	31	30
2014	9	9	4	32	18	0.213	-0.049	0.797	0.039	0.036	0	46	45.2	70.1	138	135	0	31	30
2014	9	9	4	42	18	0.246	0.023	0.797	0.033	0.03	0	45.2	44.7	70.5	136	134	0	31	30
2014	9	9	4	52	18	0.233	-0.039	0.797	0.033	0.03	0	44.7	44.3	70.5	135	134	0	31	31
2014	9	9	5	2	18	0.203	0	0.797	0.036	0.033	0	45.6	44.3	71.4	137	134	0	31	31
2014	9	9	5	12	18	0.302	0	0.797	0.036	0.033	0	45.2	44.3	71.4	136	134	0	31	31
2014	9	9	5	22	18	0.282	-0.052	0.797	0.033	0.03	0	45.6	44.3	71	137	134	0	31	31
2014	9	9	5	32	18	0.217	-0.016	0.797	0.039	0.036	0	44.7	44.7	72.2	135	134	0	31	30
2014	9	9	5	42	18	0.177	-0.102	0.801	0.036	0.033	0	44.7	45.2	72.2	135	135	0	31	30
2014	9	9	5	52	18	0.243	0.016	0.801	0.033	0.03	0	45.6	45.2	70.5	136	135	0	30	30
2014	9	9	6	2	18	0.226	-0.036	0.797	0.036	0.033	0	46	45.2	68.4	137	135	0	30	30
2014	9	9	6	12	18	0.266	-0.072	0.801	0.033	0.03	0	45.2	44.7	71.4	137	134	0	32	30
2014	9	9	6	22	18	0.22	-0.01	0.801	0.033	0.03	0	45.2	44.7	71.4	136	135	0	31	31
2014	9	9	6	32	18	0.269	0.01	0.801	0.039	0.039	0	45.2	44.3	71.4	137	133	0	32	30
2014	9	9	6	42	18	0.213	0.003	0.801	0.036	0.033	0	44.3	43.9	73.1	135	132	0	32	30
2014	9	9	6	52	18	0.236	-0.02	0.801	0.036	0.033	0	43.4	43.4	73.5	133	131	0	32	30
2014	9	9	7	2	18	0.171	0	0.801	0.039	0.036	0	43.9	43	74	133	130	0	31	30
2014	9	9	7	12	18	0.331	-0.01	0.804	0.033	0.03	0	43.9	43	74	133	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	7	22	18	0.259	0.007	0.804	0.033	0.03	0	43.4	42.1	74.4	132	128	0	31	30
2014	9	9	7	32	18	0.279	0.013	0.804	0.036	0.033	0	43	42.6	74	132	130	0	32	31
2014	9	9	7	42	18	0.174	0.069	0.804	0.036	0.033	0	43	42.6	74.8	131	130	0	31	31
2014	9	9	7	52	18	0.144	0.007	0.804	0.033	0.03	0	43.4	43.4	74	132	132	0	31	31
2014	9	9	8	2	18	0.194	0	0.804	0.036	0.033	0	42.6	43.4	74	131	131	0	32	30
2014	9	9	8	12	18	0.266	0.007	0.804	0.036	0.033	0	43	43.4	74	132	131	0	32	30
2014	9	9	8	22	18	0.19	0.01	0.804	0.039	0.036	0	43.4	43	73.5	133	131	0	32	31
2014	9	9	8	32	18	0.217	-0.013	0.804	0.039	0.039	0	43.9	43.9	73.1	134	133	0	32	31
2014	9	9	8	42	18	0.23	0.016	0.804	0.036	0.033	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	9	8	52	18	0.226	-0.007	0.804	0.039	0.036	0	45.2	44.7	73.5	136	135	0	31	31
2014	9	9	9	2	18	0.18	-0.072	0.804	0.039	0.036	0	43.9	44.7	72.7	134	134	0	32	30
2014	9	9	9	12	18	0.269	0	0.804	0.033	0.03	0	44.7	44.7	72.2	136	134	0	32	30
2014	9	9	9	22	18	0.233	0.066	0.807	0.033	0.03	0	45.2	45.6	73.1	136	136	0	31	30
2014	9	9	9	32	18	0.272	0.03	0.807	0.033	0.03	0	46.4	45.6	72.2	139	137	0	31	31
2014	9	9	9	42	18	0.312	0.03	0.807	0.036	0.033	0	46	46	73.1	138	138	0	31	31
2014	9	9	9	52	18	0.279	-0.016	0.807	0.033	0.03	0	45.6	46.4	73.5	138	137	0	32	29
2014	9	9	10	2	18	0.295	0.036	0.807	0.036	0.033	0	46	46.9	72.2	139	140	0	32	31
2014	9	9	10	12	18	0.262	0.026	0.807	0.033	0.03	0	47.3	47.3	71.8	141	141	0	31	31
2014	9	9	10	22	18	0.171	0.03	0.807	0.033	0.03	0	46.9	48.6	71.8	140	143	0	31	30
2014	9	9	10	32	18	0.243	0.072	0.807	0.033	0.03	0	47.3	48.6	72.2	141	143	0	31	30
2014	9	9	10	42	18	0.236	0.069	0.807	0.033	0.03	0	47.7	48.2	72.2	142	142	0	31	30
2014	9	9	10	52	18	0.269	0.043	0.807	0.033	0.03	0	48.2	49.5	71.8	143	145	0	31	30
2014	9	9	11	2	18	0.322	0.033	0.807	0.036	0.033	0	49	48.6	71.8	145	144	0	31	31
2014	9	9	11	12	18	0.299	0.072	0.807	0.039	0.036	0	47.7	49.9	72.2	143	147	0	32	31
2014	9	9	11	22	18	0.282	0.066	0.807	0.033	0.03	0	48.2	49.9	71.8	144	147	0	32	31
2014	9	9	11	32	18	0.272	0.023	0.807	0.033	0.03	0	48.6	49.9	71.8	145	147	0	32	31
2014	9	9	11	42	18	0.302	-0.043	0.807	0.033	0.03	0	49.9	49.5	71.8	147	146	0	31	31
2014	9	9	11	52	18	0.226	0.069	0.807	0.033	0.03	0	49.9	50.7	72.2	147	148	0	31	30
2014	9	9	12	2	18	0.236	0.036	0.81	0.033	0.03	0	49.5	51.2	71.8	147	149	0	32	30
2014	9	9	12	12	18	0.272	0.016	0.807	0.036	0.033	0	50.7	51.6	72.2	149	150	0	31	30
2014	9	9	12	22	18	0.305	0.062	0.81	0.033	0.03	0	50.3	51.6	71.4	148	150	0	31	30
2014	9	9	12	32	18	0.302	0.085	0.81	0.033	0.03	0	50.7	52.5	71	150	152	0	32	30
2014	9	9	12	42	18	0.315	0.115	0.81	0.033	0.03	0	50.7	52	71	149	151	0	31	30
2014	9	9	12	52	18	0.308	0.092	0.81	0.033	0.03	0	51.6	53.3	72.2	151	154	0	31	30
2014	9	9	13	2	18	0.322	0.075	0.807	0.03	0.03	0	52.9	53.8	69.2	154	155	0	31	30
2014	9	9	13	12	18	0.331	0.115	0.81	0.039	0.036	0	51.6	52.5	70.5	151	152	0	31	30
2014	9	9	13	22	18	0.226	0.154	0.81	0.033	0.03	0	50.3	51.6	71.8	148	151	0	31	31
2014	9	9	13	32	18	0.246	0.089	0.81	0.036	0.033	0	50.3	51.6	72.7	147	150	0	30	30
2014	9	9	13	42	18	0.354	0.01	0.81	0.033	0.03	0	49.9	51.6	71.8	147	151	0	31	31
2014	9	9	13	52	18	0.262	0.013	0.81	0.039	0.036	0	49	51.2	72.7	145	149	0	31	30
2014	9	9	14	2	18	0.322	0.02	0.81	0.033	0.033	0	50.3	52	71.8	147	151	0	30	30
2014	9	9	14	12	18	0.302	0	0.81	0.033	0.03	0	49	51.2	72.2	145	148	0	31	29
2014	9	9	14	22	18	0.21	0.016	0.81	0.033	0.03	0	48.6	50.7	71.8	144	148	0	31	30
2014	9	9	14	32	18	0.312	0.079	0.81	0.039	0.036	0	49	51.2	72.2	145	149	0	31	30
2014	9	9	14	42	18	0.272	0.069	0.81	0.033	0.03	0	48.2	50.3	71.8	143	147	0	31	30
2014	9	9	14	52	18	0.266	0.092	0.81	0.036	0.033	0	49.5	50.7	71.8	146	148	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	15	2	18	0.272	0.079	0.81	0.036	0.033	0	49	51.2	71.4	145	148	0	31	29
2014	9	9	15	12	18	0.308	0.079	0.81	0.036	0.033	0	50.3	51.2	70.5	147	149	0	30	30
2014	9	9	15	22	18	0.243	0.016	0.81	0.036	0.033	0	49.5	50.7	71.4	145	148	0	30	30
2014	9	9	15	32	18	0.266	0.089	0.81	0.033	0.03	0	49.9	51.2	71.8	146	149	0	30	30
2014	9	9	15	42	18	0.269	0.056	0.81	0.036	0.033	0	49.5	50.3	71	145	148	0	30	31
2014	9	9	15	52	18	0.259	0.016	0.81	0.033	0.03	0	48.6	50.7	71.8	144	147	0	31	29
2014	9	9	16	2	18	0.262	0.092	0.81	0.036	0.033	0	48.2	49	71.8	142	144	0	30	30
2014	9	9	16	12	18	0.295	0.016	0.81	0.033	0.033	0	46.4	49	73.1	139	143	0	31	29
2014	9	9	16	22	18	0.312	0.049	0.81	0.033	0.03	0	46.9	48.2	73.5	140	142	0	31	30
2014	9	9	16	32	18	0.285	-0.007	0.81	0.033	0.03	0	46.4	47.3	72.2	139	140	0	31	30
2014	9	9	16	42	18	0.269	0.056	0.81	0.036	0.033	0	45.6	46.9	74	137	139	0	31	30
2014	9	9	16	52	18	0.285	-0.007	0.81	0.033	0.03	0	45.2	46	74.4	136	137	0	31	30
2014	9	9	17	2	18	0.236	0.046	0.81	0.036	0.033	0	44.3	44.7	74	134	134	0	31	30
2014	9	9	17	12	18	0.328	0.016	0.81	0.036	0.033	0	43.9	43.9	74.8	133	131	0	31	29
2014	9	9	17	22	18	0.253	0.089	0.81	0.033	0.03	0	43	42.6	74.8	131	129	0	31	30
2014	9	9	17	32	18	0.259	0	0.81	0.033	0.03	0	42.6	42.6	75.3	129	128	0	30	29
2014	9	9	17	42	18	0.259	0.03	0.81	0.036	0.033	0	42.1	40.9	75.7	128	124	0	30	29
2014	9	9	17	52	18	0.256	0.003	0.81	0.039	0.036	0	42.6	40.4	75.7	129	124	0	30	30
2014	9	9	18	2	18	0.266	0.059	0.81	0.033	0.03	0	41.3	40.4	76.1	126	124	0	30	30
2014	9	9	18	12	18	0.259	0.01	0.81	0.033	0.03	0	40.9	40	75.7	126	123	0	31	30
2014	9	9	18	22	18	0.279	0.046	0.81	0.039	0.036	0	40.4	40.4	75.7	125	124	0	31	30
2014	9	9	18	32	18	0.279	-0.016	0.814	0.033	0.03	0	40.9	40.4	76.1	126	124	0	31	30
2014	9	9	18	42	18	0.256	0.026	0.81	0.033	0.033	0	41.3	40.4	76.1	126	123	0	30	29
2014	9	9	18	52	18	0.292	-0.02	0.814	0.039	0.036	0	41.3	40	76.1	126	123	0	30	30
2014	9	9	19	2	18	0.213	0.052	0.814	0.039	0.036	0	41.7	40.9	76.1	127	124	0	30	29
2014	9	9	19	12	18	0.171	0.059	0.814	0.033	0.03	0	41.3	41.7	76.5	127	126	0	31	29
2014	9	9	19	22	18	0.302	0	0.814	0.033	0.03	0	41.7	41.3	75.3	127	126	0	30	30
2014	9	9	19	32	18	0.256	-0.023	0.814	0.033	0.03	0	42.1	42.1	77	128	127	0	30	29
2014	9	9	19	42	18	0.266	0.01	0.814	0.033	0.033	0	41.3	42.1	76.5	127	127	0	31	29
2014	9	9	19	52	18	0.207	0.039	0.814	0.033	0.03	0	42.6	42.6	76.1	130	129	0	31	30
2014	9	9	20	2	18	0.272	-0.046	0.814	0.036	0.033	0	42.6	42.6	76.5	129	129	0	30	30
2014	9	9	20	12	18	0.285	-0.02	0.814	0.033	0.03	0	42.6	42.6	76.5	130	129	0	31	30
2014	9	9	20	22	18	0.21	0	0.814	0.036	0.033	0	42.6	43	76.5	130	130	0	31	30
2014	9	9	20	32	18	0.272	-0.056	0.814	0.033	0.03	0	43	42.6	77	130	129	0	30	30
2014	9	9	20	42	18	0.249	0.059	0.814	0.043	0.039	0	42.1	42.6	77	130	129	0	32	30
2014	9	9	20	52	18	0.246	0.039	0.814	0.033	0.03	0	42.6	43.4	76.1	130	131	0	31	30
2014	9	9	21	2	18	0.203	0.069	0.814	0.036	0.033	0	43.4	43	76.1	132	129	0	31	29
2014	9	9	21	12	18	0.299	-0.02	0.814	0.039	0.039	0	43.9	42.6	76.5	132	129	0	30	30
2014	9	9	21	22	18	0.272	-0.046	0.814	0.036	0.033	0	42.6	42.6	76.5	131	129	0	32	30
2014	9	9	21	32	18	0.233	-0.049	0.814	0.039	0.036	0	45.6	45.2	74.8	138	135	0	32	30
2014	9	9	21	42	18	0.269	0.023	0.814	0.036	0.033	0	48.2	47.7	72.2	143	141	0	31	30
2014	9	9	21	52	18	0.269	0.052	0.814	0.033	0.03	0	45.2	44.3	76.1	135	134	0	30	31
2014	9	9	22	2	18	0.256	-0.036	0.814	0.036	0.033	0	43.9	43.4	76.5	133	131	0	31	30
2014	9	9	22	12	18	0.312	-0.052	0.814	0.036	0.033	0	43.9	43.9	76.1	132	132	0	30	30
2014	9	9	22	22	18	0.259	-0.033	0.814	0.033	0.03	0	43.9	43.4	76.5	133	131	0	31	30
2014	9	9	22	32	18	0.161	0	0.814	0.039	0.039	0	43.4	42.1	75.7	132	129	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	22	42	18	0.194	-0.026	0.81	0.033	0.03	0	45.6	43.9	73.1	136	132	0	30	30
2014	9	9	22	52	18	0.246	-0.003	0.814	0.033	0.03	0	44.7	44.3	75.3	134	133	0	30	30
2014	9	9	23	2	18	0.322	-0.023	0.814	0.033	0.03	0	43.9	43.4	76.1	133	131	0	31	30
2014	9	9	23	12	18	0.282	-0.01	0.814	0.039	0.036	0	43.4	43.9	76.5	132	132	0	31	30
2014	9	9	23	22	18	0.269	-0.059	0.814	0.033	0.03	0	43.4	43.9	76.5	132	132	0	31	30
2014	9	9	23	32	18	0.272	0.016	0.814	0.036	0.033	0	43	43.4	76.5	131	131	0	31	30
2014	9	9	23	42	18	0.246	-0.075	0.814	0.033	0.03	0	43.4	43.4	75.3	132	131	0	31	30
2014	9	9	23	52	18	0.302	-0.049	0.814	0.036	0.033	0	43.9	43.4	76.1	133	131	0	31	30
2014	9	10	0	2	18	0.282	-0.056	0.814	0.033	0.03	0	44.3	43.4	75.7	133	131	0	30	30
2014	9	10	0	12	18	0.315	-0.026	0.814	0.033	0.03	0	43.9	43	76.5	133	130	0	31	30
2014	9	10	0	22	18	0.266	-0.039	0.814	0.039	0.036	0	43.4	42.6	75.7	131	129	0	30	30
2014	9	10	0	32	18	0.259	-0.052	0.814	0.033	0.03	0	43	43	76.1	131	130	0	31	30
2014	9	10	0	42	18	0.282	0.003	0.814	0.033	0.03	0	43	43	75.7	131	131	0	31	31
2014	9	10	0	52	18	0.285	-0.043	0.814	0.033	0.03	0	43	43	75.7	132	131	0	32	31
2014	9	10	1	2	18	0.292	0.026	0.814	0.036	0.033	0	43.4	43	75.7	132	130	0	31	30
2014	9	10	1	12	18	0.236	-0.098	0.814	0.036	0.033	0	42.6	42.1	75.7	130	128	0	31	30
2014	9	10	1	22	18	0.302	-0.003	0.814	0.039	0.039	0	43.4	42.6	75.7	132	129	0	31	30
2014	9	10	1	32	18	0.318	0.016	0.814	0.03	0.03	0	43.4	43	76.1	132	130	0	31	30
2014	9	10	1	42	18	0.272	-0.007	0.814	0.033	0.03	0	43	42.6	74.8	131	130	0	31	31
2014	9	10	1	52	18	0.217	0.007	0.814	0.033	0.03	0	43.4	42.6	75.7	132	129	0	31	30
2014	9	10	2	2	18	0.23	-0.026	0.814	0.039	0.036	0	43	42.1	75.7	131	129	0	31	31
2014	9	10	2	12	18	0.262	0.013	0.814	0.033	0.03	0	43	42.1	75.3	131	129	0	31	31
2014	9	10	2	22	18	0.276	-0.033	0.814	0.039	0.036	0	43	43	74.8	132	130	0	32	30
2014	9	10	2	32	18	0.282	0.039	0.814	0.039	0.036	0	42.1	42.1	75.7	130	129	0	32	31
2014	9	10	2	42	18	0.223	-0.036	0.814	0.033	0.03	0	43	43	75.7	131	130	0	31	30
2014	9	10	2	52	18	0.259	-0.016	0.814	0.039	0.036	0	43	43.4	75.7	132	131	0	32	30
2014	9	10	3	2	18	0.266	-0.095	0.814	0.033	0.03	0	42.6	42.6	75.3	130	129	0	31	30
2014	9	10	3	12	18	0.24	-0.069	0.814	0.046	0.043	0	42.6	43	74.8	130	130	0	31	30
2014	9	10	3	22	18	0.249	-0.056	0.814	0.036	0.033	0	42.1	43	74.8	130	130	0	32	30
2014	9	10	3	32	18	0.259	-0.023	0.817	0.033	0.03	0	43.4	42.6	75.3	132	130	0	31	31
2014	9	10	3	42	18	0.18	-0.01	0.814	0.039	0.036	0	44.3	42.6	74.8	134	130	0	31	31
2014	9	10	3	52	18	0.285	0.033	0.814	0.036	0.033	0	42.6	43.4	74.4	131	131	0	32	30
2014	9	10	4	2	18	0.259	0.016	0.814	0.033	0.03	0	43.9	43	75.3	133	130	0	31	30
2014	9	10	4	12	18	0.295	0.036	0.817	0.039	0.036	0	43	42.6	74.8	131	130	0	31	31
2014	9	10	4	22	18	0.354	-0.023	0.817	0.033	0.03	0	42.6	42.6	74.4	130	130	0	31	31
2014	9	10	4	32	18	0.266	-0.013	0.814	0.033	0.03	0	42.6	43	74.4	131	131	0	32	31
2014	9	10	4	42	18	0.295	-0.036	0.814	0.033	0.03	0	43	43	74.4	131	130	0	31	30
2014	9	10	4	52	18	0.272	0.007	0.817	0.033	0.03	0	43.4	43.9	75.3	132	132	0	31	30
2014	9	10	5	2	18	0.282	-0.069	0.814	0.036	0.033	0	43.4	43.4	74	132	131	0	31	30
2014	9	10	5	12	18	0.328	-0.013	0.814	0.039	0.036	0	43.4	43	74.4	133	131	0	32	31
2014	9	10	5	22	18	0.249	0	0.817	0.033	0.03	0	43.4	43.9	74.4	132	132	0	31	30
2014	9	10	5	32	18	0.249	-0.007	0.814	0.036	0.033	0	44.3	43.4	74.4	134	132	0	31	31
2014	9	10	5	42	18	0.328	0.036	0.814	0.033	0.03	0	43.4	44.3	74	132	133	0	31	30
2014	9	10	5	52	18	0.276	-0.03	0.814	0.033	0.03	0	43.9	43.4	74	133	132	0	31	31
2014	9	10	6	2	18	0.24	0	0.814	0.036	0.033	0	43.4	43.4	74	132	132	0	31	31
2014	9	10	6	12	18	0.308	-0.02	0.814	0.033	0.03	0	43.4	43	74.4	132	131	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	6	22	18	0.328	-0.01	0.814	0.036	0.033	0	43.4	42.6	74.4	132	130	0	31	31
2014	9	10	6	32	18	0.328	-0.023	0.814	0.033	0.03	0	42.1	41.7	74	130	128	0	32	31
2014	9	10	6	42	18	0.285	-0.066	0.814	0.033	0.03	0	43.4	42.6	74.8	132	129	0	31	30
2014	9	10	6	52	18	0.249	-0.016	0.814	0.036	0.033	0	41.3	41.7	75.3	127	128	0	31	31
2014	9	10	7	2	18	0.256	0.007	0.814	0.039	0.036	0	42.1	41.7	74.4	129	128	0	31	31
2014	9	10	7	12	18	0.272	-0.046	0.814	0.036	0.033	0	41.3	40.9	74.8	128	126	0	32	31
2014	9	10	7	22	18	0.335	-0.098	0.814	0.036	0.033	0	41.3	40.9	74.8	128	125	0	32	30
2014	9	10	7	32	18	0.39	-0.026	0.814	0.033	0.03	0	41.3	41.7	74.4	128	128	0	32	31
2014	9	10	7	42	18	0.18	-0.059	0.814	0.039	0.039	0	41.7	40.9	75.3	129	127	0	32	32
2014	9	10	7	52	18	0.243	0	0.814	0.033	0.03	0	42.1	42.6	74.8	130	129	0	32	30
2014	9	10	8	2	18	0.325	-0.049	0.814	0.039	0.036	0	41.7	42.6	74.8	128	129	0	31	30
2014	9	10	8	12	18	0.24	-0.072	0.814	0.036	0.033	0	41.7	41.7	75.3	129	128	0	32	31
2014	9	10	8	22	18	0.197	-0.01	0.814	0.033	0.03	0	41.7	41.7	74.8	128	128	0	31	31
2014	9	10	8	32	18	0.292	0.033	0.814	0.036	0.033	0	41.3	41.7	75.7	128	128	0	32	31
2014	9	10	8	42	18	0.259	-0.056	0.814	0.036	0.033	0	42.1	42.1	75.7	130	129	0	32	31
2014	9	10	8	52	18	0.305	0.007	0.814	0.039	0.036	0	42.1	42.6	75.3	129	129	0	31	30
2014	9	10	9	2	18	0.187	-0.072	0.814	0.036	0.033	0	40.9	41.7	76.1	127	128	0	32	31
2014	9	10	9	12	18	0.24	0.023	0.81	0.036	0.033	0	56.3	54.2	47.3	162	156	0	31	30
2014	9	10	9	22	18	0.223	-0.036	0.817	0.03	0.03	0	42.1	43.4	70.1	130	132	0	32	31
2014	9	10	9	32	18	0.243	-0.095	0.817	0.036	0.033	0	43.9	43.9	72.7	133	133	0	31	31
2014	9	10	9	42	18	0.233	0	0.817	0.043	0.043	0	44.7	44.7	73.1	135	135	0	31	31
2014	9	10	9	52	18	0.203	-0.016	0.817	0.036	0.033	0	45.2	45.6	73.5	136	137	0	31	31
2014	9	10	10	2	18	0.272	0	0.814	0.036	0.033	0	44.7	46.9	72.7	136	139	0	32	30
2014	9	10	10	12	18	0.276	0.02	0.814	0.033	0.03	0	45.6	47.3	73.1	138	140	0	32	30
2014	9	10	10	22	18	0.243	0.039	0.814	0.036	0.033	0	46.4	48.2	73.1	139	142	0	31	30
2014	9	10	10	32	18	0.289	0.013	0.814	0.036	0.033	0	46.9	47.3	73.5	141	141	0	32	31
2014	9	10	10	42	18	0.262	0.01	0.814	0.033	0.03	0	46.9	49	72.2	141	145	0	32	31
2014	9	10	10	52	18	0.305	-0.007	0.814	0.033	0.03	0	47.3	49.5	73.1	142	146	0	32	31
2014	9	10	11	2	18	0.24	0.043	0.814	0.039	0.036	0	46.9	49	73.1	141	145	0	32	31
2014	9	10	11	12	18	0.262	-0.049	0.814	0.033	0.03	0	48.2	49.9	72.7	144	147	0	32	31
2014	9	10	11	22	18	0.302	0.043	0.814	0.03	0.03	0	49	50.3	72.2	146	148	0	32	31
2014	9	10	11	32	18	0.259	0.075	0.81	0.039	0.036	0	49.5	50.3	71.8	147	147	0	32	30
2014	9	10	11	42	18	0.341	0.052	0.81	0.033	0.03	0	51.2	51.6	71.8	150	151	0	31	31
2014	9	10	11	52	18	0.315	0.066	0.814	0.033	0.03	0	51.6	52.5	70.1	151	153	0	31	31
2014	9	10	12	2	18	0.354	0.079	0.81	0.039	0.036	0	51.6	52	70.5	151	152	0	31	31
2014	9	10	12	12	18	0.322	0.079	0.81	0.036	0.033	0	50.3	52.5	70.1	149	152	0	32	30
2014	9	10	12	22	18	0.315	0.049	0.81	0.033	0.03	0	49.9	52	71.8	147	151	0	31	30
2014	9	10	12	32	18	0.364	0.098	0.81	0.033	0.03	0	51.6	52.5	71.4	150	153	0	30	31
2014	9	10	12	42	18	0.299	0.082	0.814	0.03	0.03	0	51.6	52.5	71.4	151	153	0	31	31
2014	9	10	12	52	18	0.24	0.085	0.81	0.033	0.03	0	49.5	51.2	72.7	146	149	0	31	30
2014	9	10	13	2	18	0.262	0.118	0.81	0.033	0.03	0	49.5	51.6	74	146	150	0	31	30
2014	9	10	13	12	18	0.276	0.049	0.81	0.033	0.03	0	49	51.2	74	146	149	0	32	30
2014	9	10	13	22	18	0.305	0.102	0.81	0.033	0.03	0	49	50.7	73.1	145	148	0	31	30
2014	9	10	13	32	18	0.322	0.013	0.814	0.033	0.03	0	50.3	52	72.2	148	151	0	31	30
2014	9	10	13	42	18	0.289	0.112	0.81	0.039	0.036	0	49.5	49.9	73.5	145	146	0	30	30
2014	9	10	13	52	18	0.315	0.131	0.81	0.033	0.03	0	49.5	51.6	72.7	146	149	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	14	2	18	0.282	0.059	0.81	0.039	0.036	0	49	51.2	74	145	149	0	31	30
2014	9	10	14	12	18	0.269	0.056	0.81	0.033	0.03	0	48.2	50.3	73.5	143	147	0	31	30
2014	9	10	14	22	18	0.302	0.052	0.81	0.039	0.036	0	49.5	51.6	72.7	146	150	0	31	30
2014	9	10	14	32	18	0.272	0.01	0.81	0.033	0.03	0	48.6	50.3	73.1	144	147	0	31	30
2014	9	10	14	42	18	0.292	0.056	0.81	0.039	0.036	0	49	50.3	73.1	145	147	0	31	30
2014	9	10	14	52	18	0.315	-0.033	0.81	0.033	0.03	0	48.2	49.9	73.5	143	146	0	31	30
2014	9	10	15	2	18	0.302	0.03	0.81	0.039	0.039	0	48.2	50.7	73.1	143	148	0	31	30
2014	9	10	15	12	18	0.292	-0.016	0.81	0.036	0.033	0	47.7	49.9	72.7	141	146	0	30	30
2014	9	10	15	22	18	0.279	0.033	0.81	0.036	0.033	0	47.3	49.9	72.7	141	145	0	31	29
2014	9	10	15	32	18	0.282	0.036	0.81	0.033	0.03	0	48.6	50.7	73.1	144	147	0	31	29
2014	9	10	15	42	18	0.246	0.069	0.807	0.033	0.03	0	48.2	50.7	72.2	143	148	0	31	30
2014	9	10	15	52	18	0.305	0.052	0.81	0.033	0.03	0	48.2	49.5	72.2	142	145	0	30	30
2014	9	10	16	2	18	0.295	0.049	0.807	0.033	0.03	0	49	49.9	73.1	145	146	0	31	30
2014	9	10	16	12	18	0.312	0.066	0.807	0.033	0.03	0	47.3	48.2	72.7	140	142	0	30	30
2014	9	10	16	22	18	0.308	0.089	0.807	0.033	0.03	0	48.2	48.6	72.2	142	143	0	30	30
2014	9	10	16	32	18	0.305	0.089	0.807	0.033	0.03	0	48.2	48.2	71.4	142	142	0	30	30
2014	9	10	16	42	18	0.276	0.187	0.807	0.033	0.03	0	47.7	49.5	71.4	142	144	0	31	29
2014	9	10	16	52	18	0.272	0.098	0.807	0.033	0.03	0	47.3	47.3	71.8	141	140	0	31	30
2014	9	10	17	2	18	0.295	0.052	0.807	0.033	0.03	0	46	46.4	72.2	137	138	0	30	30
2014	9	10	17	12	18	0.315	0.023	0.807	0.033	0.03	0	45.6	46	72.7	137	137	0	31	30
2014	9	10	17	22	18	0.377	0.089	0.807	0.033	0.03	0	45.2	45.2	72.2	135	135	0	30	30
2014	9	10	17	32	18	0.308	0.151	0.807	0.033	0.03	0	45.2	43.9	72.2	135	131	0	30	29
2014	9	10	17	42	18	0.259	0.177	0.807	0.033	0.03	0	44.3	43	71.8	134	130	0	31	30
2014	9	10	17	52	18	0.266	0.128	0.807	0.036	0.033	0	44.7	43	71.8	135	131	0	31	31
2014	9	10	18	2	18	0.259	0.154	0.807	0.033	0.03	0	43.4	42.1	73.1	132	128	0	31	30
2014	9	10	18	12	18	0.266	0.075	0.807	0.039	0.039	0	43.9	42.1	73.1	132	128	0	30	30
2014	9	10	18	22	18	0.253	0.046	0.807	0.036	0.033	0	43	42.1	72.7	131	127	0	31	29
2014	9	10	18	32	18	0.253	0.095	0.807	0.039	0.036	0	42.6	41.7	73.5	129	127	0	30	30
2014	9	10	18	42	18	0.308	0.164	0.807	0.036	0.033	0	41.7	41.3	73.1	127	126	0	30	30
2014	9	10	18	52	18	0.295	0.036	0.807	0.036	0.033	0	41.3	41.3	74	127	125	0	31	29
2014	9	10	19	2	18	0.315	0.066	0.807	0.036	0.033	0	42.1	41.3	73.5	128	126	0	30	30
2014	9	10	19	12	18	0.295	0	0.807	0.036	0.033	0	41.7	40.9	73.5	128	125	0	31	30
2014	9	10	19	22	18	0.266	0.049	0.807	0.036	0.033	0	41.3	41.7	73.1	127	126	0	31	29
2014	9	10	19	32	18	0.226	0	0.807	0.036	0.033	0	42.1	41.3	73.5	129	126	0	31	30
2014	9	10	19	42	18	0.266	-0.036	0.804	0.036	0.033	0	42.1	42.1	73.5	129	128	0	31	30
2014	9	10	19	52	18	0.272	-0.036	0.807	0.039	0.036	0	43	42.1	73.5	130	128	0	30	30
2014	9	10	20	2	18	0.354	-0.01	0.804	0.036	0.033	0	42.6	42.6	73.5	130	129	0	31	30
2014	9	10	20	12	18	0.213	0.052	0.804	0.033	0.03	0	43.9	43.9	73.5	132	131	0	30	29
2014	9	10	20	22	18	0.233	0.003	0.807	0.036	0.033	0	43.9	42.6	73.5	132	129	0	30	30
2014	9	10	20	32	18	0.269	0.079	0.807	0.036	0.033	0	43	42.6	73.1	131	129	0	31	30
2014	9	10	20	42	18	0.272	-0.003	0.807	0.033	0.03	0	43	42.6	73.5	131	129	0	31	30
2014	9	10	20	52	18	0.259	0	0.807	0.039	0.036	0	43.9	42.6	73.5	132	129	0	30	30
2014	9	10	21	2	18	0.269	0.007	0.807	0.043	0.039	0	43	43.4	74.4	131	130	0	31	29
2014	9	10	21	12	18	0.233	0.016	0.807	0.033	0.03	0	42.6	42.1	73.5	130	128	0	31	30
2014	9	10	21	22	18	0.236	-0.043	0.807	0.036	0.033	0	43	42.6	74	131	129	0	31	30
2014	9	10	21	32	18	0.246	0	0.807	0.03	0.03	0	43	43	74	131	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	21	42	18	0.282	-0.026	0.807	0.036	0.033	0	43.4	43	73.5	132	130	0	31	30
2014	9	10	21	52	18	0.246	-0.069	0.807	0.033	0.03	0	44.3	43.4	73.1	133	131	0	30	30
2014	9	10	22	2	18	0.289	-0.062	0.807	0.036	0.033	0	43.4	43	74	131	130	0	30	30
2014	9	10	22	12	18	0.272	-0.062	0.807	0.033	0.03	0	43.9	43.4	73.5	132	131	0	30	30
2014	9	10	22	22	18	0.243	-0.039	0.807	0.033	0.03	0	42.6	42.1	74.4	130	128	0	31	30
2014	9	10	22	32	18	0.269	0.023	0.807	0.033	0.03	0	43.4	42.6	74	132	130	0	31	31
2014	9	10	22	42	18	0.305	-0.023	0.807	0.036	0.033	0	43.9	45.2	73.5	134	135	0	32	30
2014	9	10	22	52	18	0.213	-0.049	0.807	0.033	0.03	0	44.7	44.3	74	134	133	0	30	30
2014	9	10	23	2	18	0.243	-0.02	0.807	0.033	0.03	0	46.4	45.2	72.2	139	135	0	31	30
2014	9	10	23	12	18	0.272	0.03	0.807	0.036	0.033	0	49	47.3	70.5	144	141	0	30	31
2014	9	10	23	22	18	0.233	0.039	0.804	0.039	0.036	0	47.7	47.7	71	143	141	0	32	30
2014	9	10	23	32	18	0.269	0.03	0.807	0.036	0.033	0	46.9	46.9	71.8	140	139	0	31	30
2014	9	10	23	42	18	0.253	0.108	0.807	0.033	0.03	0	46.4	46.4	72.7	139	138	0	31	30
2014	9	10	23	52	18	0.213	0.023	0.804	0.039	0.036	0	45.6	45.2	72.2	138	136	0	32	31
2014	9	11	0	2	18	0.253	0.026	0.807	0.036	0.033	0	44.3	44.3	74	135	133	0	32	30
2014	9	11	0	12	18	0.2	-0.013	0.807	0.033	0.03	0	44.3	43.9	74	134	132	0	31	30
2014	9	11	0	22	18	0.24	0.007	0.807	0.033	0.03	0	43.9	43.9	74.4	133	132	0	31	30
2014	9	11	0	32	18	0.24	0.007	0.807	0.039	0.036	0	43.9	43.4	74.4	133	131	0	31	30
2014	9	11	0	42	18	0.249	-0.033	0.804	0.036	0.033	0	43.9	44.7	73.5	133	134	0	31	30
2014	9	11	0	52	18	0.213	-0.013	0.807	0.039	0.036	0	43.9	43.9	74.4	133	132	0	31	30
2014	9	11	1	2	18	0.233	-0.039	0.804	0.036	0.033	0	43.4	43	74.4	132	130	0	31	30
2014	9	11	1	12	18	0.266	0	0.807	0.03	0.03	0	43.9	43.4	74	133	131	0	31	30
2014	9	11	1	22	18	0.295	0.056	0.804	0.036	0.033	0	43.4	43	74	132	130	0	31	30
2014	9	11	1	32	18	0.262	-0.046	0.804	0.033	0.03	0	43.4	43.9	74	132	132	0	31	30
2014	9	11	1	42	18	0.22	-0.089	0.804	0.039	0.036	0	43	43	74.4	132	130	0	32	30
2014	9	11	1	52	18	0.203	0.016	0.804	0.033	0.033	0	43.9	43	74.8	133	130	0	31	30
2014	9	11	2	2	18	0.289	-0.056	0.804	0.033	0.03	0	41.7	42.6	74.8	128	130	0	31	31
2014	9	11	2	12	18	0.269	-0.016	0.804	0.033	0.03	0	43	42.6	74.4	131	130	0	31	31
2014	9	11	2	22	18	0.335	0.033	0.804	0.033	0.03	0	43.4	43.4	74.4	132	131	0	31	30
2014	9	11	2	32	18	0.203	0.003	0.804	0.039	0.036	0	43	43.4	74.8	131	131	0	31	30
2014	9	11	2	42	18	0.292	-0.075	0.804	0.033	0.03	0	43	43	74.8	131	131	0	31	31
2014	9	11	2	52	18	0.226	-0.036	0.804	0.033	0.03	0	45.6	44.7	72.7	137	134	0	31	30
2014	9	11	3	2	18	0.243	-0.01	0.804	0.033	0.03	0	45.2	45.2	72.7	136	135	0	31	30
2014	9	11	3	12	18	0.285	-0.066	0.804	0.039	0.036	0	46	44.7	72.2	138	135	0	31	31
2014	9	11	3	22	18	0.249	-0.046	0.804	0.033	0.03	0	45.6	44.3	73.5	137	133	0	31	30
2014	9	11	3	32	18	0.217	0.039	0.804	0.036	0.033	0	44.3	43.9	73.5	135	133	0	32	31
2014	9	11	3	42	18	0.266	0	0.804	0.033	0.03	0	44.7	43.9	73.5	135	133	0	31	31
2014	9	11	3	52	18	0.282	0.039	0.804	0.033	0.03	0	43.9	44.3	72.7	133	133	0	31	30
2014	9	11	4	2	18	0.282	0.033	0.804	0.036	0.033	0	44.7	43.9	73.5	135	133	0	31	31
2014	9	11	4	12	18	0.253	0.033	0.804	0.039	0.036	0	44.7	43.9	73.5	134	132	0	30	30
2014	9	11	4	22	18	0.246	-0.052	0.804	0.036	0.033	0	44.3	43.9	73.1	134	131	0	31	29
2014	9	11	4	32	18	0.194	0.033	0.804	0.033	0.03	0	43.4	43.4	73.1	132	131	0	31	30
2014	9	11	4	42	18	0.289	-0.007	0.804	0.033	0.03	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	11	4	52	18	0.279	-0.01	0.804	0.033	0.03	0	43.4	43.9	73.5	133	132	0	32	30
2014	9	11	5	2	18	0.21	-0.026	0.801	0.036	0.033	0	43.4	43.4	73.5	132	132	0	31	31
2014	9	11	5	12	18	0.276	0.026	0.801	0.033	0.03	0	43.9	43.4	73.1	133	132	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	5	22	18	0.243	-0.003	0.801	0.036	0.033	0	43	43	72.7	131	131	0	31	31
2014	9	11	5	32	18	0.19	0	0.801	0.033	0.03	0	43.9	43	73.5	133	130	0	31	30
2014	9	11	5	42	18	0.207	0.013	0.801	0.033	0.03	0	43.4	43	73.5	133	130	0	32	30
2014	9	11	5	52	18	0.315	0.007	0.801	0.033	0.03	0	44.7	43.4	73.5	135	132	0	31	31
2014	9	11	6	2	18	0.233	-0.069	0.801	0.033	0.033	0	43.4	43	74	132	130	0	31	30
2014	9	11	6	12	18	0.217	-0.023	0.801	0.033	0.03	0	44.3	43.9	73.5	134	132	0	31	30
2014	9	11	6	22	18	0.22	-0.003	0.801	0.033	0.03	0	43	43	73.1	132	131	0	32	31
2014	9	11	6	32	18	0.249	-0.013	0.801	0.036	0.033	0	42.6	42.1	74	130	129	0	31	31
2014	9	11	6	42	18	0.276	-0.059	0.801	0.033	0.03	0	41.7	42.1	74	129	128	0	32	30
2014	9	11	6	52	18	0.24	0.066	0.801	0.033	0.03	0	42.6	42.1	74	130	129	0	31	31
2014	9	11	7	2	18	0.236	-0.049	0.801	0.033	0.03	0	40.9	41.3	73.5	127	127	0	32	31
2014	9	11	7	12	18	0.249	0.013	0.801	0.039	0.036	0	41.7	40.9	74	128	126	0	31	31
2014	9	11	7	22	18	0.171	-0.036	0.801	0.043	0.043	0	41.7	41.3	74.4	128	127	0	31	31
2014	9	11	7	32	18	0.22	-0.049	0.801	0.033	0.03	0	41.7	40.9	74.4	128	126	0	31	31
2014	9	11	7	42	18	0.246	-0.016	0.801	0.033	0.03	0	42.1	42.1	74	129	128	0	31	30
2014	9	11	7	52	18	0.256	-0.023	0.801	0.033	0.03	0	40.9	41.3	74.4	127	127	0	32	31
2014	9	11	8	2	18	0.302	-0.026	0.797	0.033	0.03	0	42.1	41.7	74.4	129	128	0	31	31
2014	9	11	8	12	18	0.276	0.003	0.801	0.033	0.03	0	41.7	41.3	74.4	128	127	0	31	31
2014	9	11	8	22	18	0.262	-0.02	0.797	0.036	0.033	0	40.9	41.3	74.4	127	127	0	32	31
2014	9	11	8	32	18	0.259	-0.039	0.797	0.036	0.033	0	41.3	41.3	74	128	126	0	32	30
2014	9	11	8	42	18	0.276	-0.052	0.797	0.033	0.03	0	42.1	42.1	73.1	129	128	0	31	30
2014	9	11	8	52	18	0.292	-0.03	0.797	0.036	0.033	0	41.7	41.3	73.5	129	127	0	32	31
2014	9	11	9	2	18	0.243	-0.036	0.797	0.033	0.03	0	42.1	41.3	74	129	127	0	31	31
2014	9	11	9	12	18	0.213	-0.066	0.797	0.039	0.039	0	41.7	42.1	72.7	129	129	0	32	31
2014	9	11	9	22	18	0.184	0.016	0.797	0.033	0.03	0	43	43	72.7	131	131	0	31	31
2014	9	11	9	32	18	0.282	-0.046	0.797	0.033	0.03	0	42.6	43	71.8	131	131	0	32	31
2014	9	11	9	42	18	0.223	-0.016	0.797	0.036	0.033	0	43.4	43	72.7	132	131	0	31	31
2014	9	11	9	52	18	0.187	-0.052	0.797	0.036	0.033	0	43.4	44.7	72.2	134	134	0	33	30
2014	9	11	10	2	18	0.262	-0.003	0.794	0.033	0.03	0	44.3	45.2	71.4	135	137	0	32	32
2014	9	11	10	12	18	0.217	0.049	0.794	0.043	0.039	0	45.2	46.4	71.4	136	139	0	31	31
2014	9	11	10	22	18	0.22	0.036	0.794	0.03	0.03	0	46.4	48.2	71.4	139	143	0	31	31
2014	9	11	10	32	18	0.21	-0.013	0.794	0.033	0.03	0	46	48.2	71.8	140	143	0	33	31
2014	9	11	10	42	18	0.256	0.049	0.791	0.033	0.03	0	47.3	48.2	71.8	141	143	0	31	31
2014	9	11	10	52	18	0.331	0.003	0.791	0.033	0.03	0	47.3	48.6	71	141	143	0	31	30
2014	9	11	11	2	18	0.197	0.049	0.791	0.03	0.03	0	47.3	50.3	71.4	141	147	0	31	30
2014	9	11	11	12	18	0.19	0.016	0.787	0.033	0.03	0	47.7	50.3	71	143	148	0	32	31
2014	9	11	11	22	18	0.253	0.02	0.787	0.033	0.03	0	47.7	49.5	71.4	142	146	0	31	31
2014	9	11	11	32	18	0.19	0.023	0.784	0.036	0.033	0	46.9	49	69.7	141	145	0	32	31
2014	9	11	11	42	18	0.184	0.007	0.784	0.033	0.03	0	47.3	49.5	69.7	141	146	0	31	31
2014	9	11	11	52	18	0.272	-0.016	0.784	0.033	0.03	0	47.7	50.3	70.1	142	147	0	31	30
2014	9	11	12	2	18	0.259	-0.003	0.784	0.036	0.033	0	48.2	49.9	70.1	144	147	0	32	31
2014	9	11	12	12	18	0.243	0.036	0.784	0.033	0.03	0	47.3	50.3	70.5	142	147	0	32	30
2014	9	11	12	22	18	0.328	0.046	0.784	0.033	0.03	0	48.2	50.3	71	143	147	0	31	30
2014	9	11	12	32	18	0.315	0.01	0.784	0.033	0.03	0	48.6	50.3	71	144	147	0	31	30
2014	9	11	12	42	18	0.269	0.033	0.784	0.03	0.026	0	49	50.3	71.8	145	147	0	31	30
2014	9	11	12	52	18	0.295	0.085	0.784	0.033	0.03	0	48.2	49.9	71.4	143	146	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	13	2	18	0.21	0.085	0.784	0.036	0.033	0	46.4	48.2	71.4	139	143	0	31	31
2014	9	11	13	12	18	0.256	0.072	0.784	0.036	0.033	0	47.7	49.9	71.8	141	146	0	30	30
2014	9	11	13	22	18	0.19	0.039	0.784	0.033	0.03	0	47.3	49	71	141	144	0	31	30
2014	9	11	13	32	18	0.292	0.003	0.784	0.036	0.033	0	47.3	49.9	72.2	141	146	0	31	30
2014	9	11	13	42	18	0.328	-0.023	0.784	0.033	0.03	0	46	49	72.7	138	144	0	31	30
2014	9	11	13	52	18	0.236	0.016	0.784	0.03	0.03	0	46	49	72.7	138	144	0	31	30
2014	9	11	14	2	18	0.276	0.092	0.784	0.036	0.033	0	46	49	73.1	138	143	0	31	29
2014	9	11	14	12	18	0.289	0.066	0.784	0.033	0.03	0	48.2	49.5	71.8	143	145	0	31	30
2014	9	11	14	22	18	0.213	0.072	0.784	0.039	0.036	0	45.6	47.7	72.7	137	141	0	31	30
2014	9	11	14	32	18	0.338	0.036	0.784	0.033	0.03	0	46.9	48.6	73.5	139	143	0	30	30
2014	9	11	14	42	18	0.269	0.056	0.784	0.033	0.03	0	46.9	48.2	71.8	139	142	0	30	30
2014	9	11	14	52	18	0.302	-0.039	0.787	0.033	0.03	0	46.4	48.6	71.8	138	143	0	30	30
2014	9	11	15	2	18	0.318	-0.02	0.787	0.03	0.03	0	46.9	47.7	73.1	139	141	0	30	30
2014	9	11	15	12	18	0.282	0.082	0.787	0.036	0.033	0	46.4	48.6	71.8	138	143	0	30	30
2014	9	11	15	22	18	0.226	0.072	0.787	0.033	0.03	0	46.4	49	72.7	138	143	0	30	29
2014	9	11	15	32	18	0.259	0.036	0.787	0.03	0.03	0	47.7	50.3	72.2	142	147	0	31	30
2014	9	11	15	42	18	0.246	0	0.787	0.033	0.03	0	45.6	48.6	72.7	137	143	0	31	30
2014	9	11	15	52	18	0.272	0.043	0.787	0.03	0.03	0	47.7	49.9	71.8	141	145	0	30	29
2014	9	11	16	2	18	0.253	0.046	0.787	0.033	0.03	0	46	47.7	71.4	137	141	0	30	30
2014	9	11	16	12	18	0.285	0.085	0.791	0.033	0.03	0	45.2	48.2	72.2	136	141	0	31	29
2014	9	11	16	22	18	0.259	0.01	0.791	0.03	0.026	0	46.4	47.7	71.8	138	141	0	30	30
2014	9	11	16	32	18	0.272	0.052	0.791	0.03	0.03	0	45.6	48.2	71.8	137	141	0	31	29
2014	9	11	16	42	18	0.272	0.075	0.794	0.033	0.03	0	45.2	46.9	72.7	136	138	0	31	29
2014	9	11	16	52	18	0.308	0.016	0.797	0.033	0.03	0	45.2	45.6	71.4	135	136	0	30	30
2014	9	11	17	2	18	0.194	0.082	0.797	0.033	0.03	0	43.9	44.7	72.2	133	133	0	31	29
2014	9	11	17	12	18	0.289	0.016	0.801	0.033	0.03	0	43.9	44.3	72.2	132	133	0	30	30
2014	9	11	17	22	18	0.269	0.016	0.801	0.039	0.036	0	42.1	42.6	71.8	129	129	0	31	30
2014	9	11	17	32	18	0.236	0.079	0.801	0.036	0.033	0	42.6	41.7	72.7	129	127	0	30	30
2014	9	11	17	42	18	0.322	0.115	0.804	0.033	0.03	0	41.7	41.7	73.1	127	126	0	30	29
2014	9	11	17	52	18	0.256	0.033	0.804	0.033	0.03	0	42.6	41.7	71.4	129	127	0	30	30
2014	9	11	18	2	18	0.282	0.072	0.807	0.039	0.036	0	41.7	40.4	73.1	127	124	0	30	30
2014	9	11	18	12	18	0.331	0.108	0.807	0.036	0.033	0	42.6	41.7	73.5	129	127	0	30	30
2014	9	11	18	22	18	0.243	0.092	0.807	0.036	0.033	0	41.7	40.4	73.5	127	124	0	30	30
2014	9	11	18	32	18	0.272	0.043	0.807	0.036	0.033	0	42.1	42.1	73.5	128	127	0	30	29
2014	9	11	18	42	18	0.361	0.01	0.807	0.033	0.03	0	41.3	41.3	74.4	126	125	0	30	29
2014	9	11	18	52	18	0.226	0.082	0.81	0.033	0.03	0	41.3	40.4	74.4	127	124	0	31	30
2014	9	11	19	2	18	0.262	-0.013	0.81	0.039	0.036	0	40.9	40.4	75.7	126	124	0	31	30
2014	9	11	19	12	18	0.279	-0.02	0.81	0.043	0.043	0	41.3	40.9	74.8	126	124	0	30	29
2014	9	11	19	22	18	0.184	-0.039	0.81	0.033	0.03	0	42.1	40.9	74.8	128	125	0	30	30
2014	9	11	19	32	18	0.299	0	0.81	0.036	0.033	0	40.9	40.9	75.3	126	125	0	31	30
2014	9	11	19	42	18	0.217	-0.02	0.81	0.039	0.039	0	42.1	42.1	75.3	129	128	0	31	30
2014	9	11	19	52	18	0.256	-0.026	0.81	0.036	0.033	0	43	42.1	75.7	130	128	0	30	30
2014	9	11	20	2	18	0.236	-0.003	0.81	0.039	0.036	0	43.4	43.4	75.7	131	130	0	30	29
2014	9	11	20	12	18	0.256	-0.013	0.814	0.036	0.033	0	41.7	42.6	74.8	128	129	0	31	30
2014	9	11	20	22	18	0.295	-0.003	0.814	0.033	0.03	0	43.9	42.6	74.8	132	129	0	30	30
2014	9	11	20	32	18	0.285	-0.039	0.814	0.039	0.036	0	43.4	43	76.5	131	129	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	20	42	18	0.256	0	0.814	0.039	0.039	0	44.7	43.4	74.8	134	131	0	30	30
2014	9	11	20	52	18	0.249	-0.016	0.814	0.033	0.03	0	43.4	43	76.1	131	130	0	30	30
2014	9	11	21	2	18	0.236	-0.056	0.814	0.039	0.036	0	43	42.6	76.5	131	129	0	31	30
2014	9	11	21	12	18	0.256	-0.043	0.814	0.039	0.036	0	43	43	76.1	131	130	0	31	30
2014	9	11	21	22	18	0.289	-0.026	0.814	0.039	0.036	0	43.4	42.6	76.5	131	129	0	30	30
2014	9	11	21	32	18	0.266	0.01	0.814	0.033	0.03	0	43	42.6	77	131	129	0	31	30
2014	9	11	21	42	18	0.335	-0.007	0.814	0.033	0.03	0	43	42.6	76.5	131	129	0	31	30
2014	9	11	21	52	18	0.305	-0.003	0.814	0.039	0.036	0	42.6	42.1	76.5	130	128	0	31	30
2014	9	11	22	2	18	0.302	-0.03	0.814	0.039	0.036	0	43	43.4	75.7	131	131	0	31	30
2014	9	11	22	12	18	0.269	-0.066	0.814	0.036	0.033	0	43.9	43	76.1	133	130	0	31	30
2014	9	11	22	22	18	0.262	-0.013	0.814	0.033	0.03	0	43.4	43	76.5	132	130	0	31	30
2014	9	11	22	32	18	0.243	0.003	0.817	0.039	0.039	0	43.4	43.4	76.5	131	131	0	30	30
2014	9	11	22	42	18	0.305	-0.026	0.817	0.033	0.03	0	43	43	76.1	131	130	0	31	30
2014	9	11	22	52	18	0.312	-0.013	0.817	0.033	0.03	0	43.9	43.4	76.1	133	131	0	31	30
2014	9	11	23	2	18	0.292	0	0.817	0.033	0.03	0	42.6	43.4	76.5	130	131	0	31	30
2014	9	11	23	12	18	0.348	-0.02	0.817	0.036	0.033	0	43.4	43.9	76.1	132	131	0	31	29
2014	9	11	23	22	18	0.272	0.056	0.817	0.033	0.03	0	43	43	77	131	130	0	31	30
2014	9	11	23	32	18	0.256	-0.02	0.817	0.039	0.036	0	43.4	43.4	76.1	132	131	0	31	30
2014	9	11	23	42	18	0.249	0.049	0.817	0.036	0.033	0	43	43	76.1	131	130	0	31	30
2014	9	11	23	52	18	0.318	-0.02	0.817	0.03	0.03	0	43	43	76.1	131	130	0	31	30
2014	9	12	0	2	18	0.282	-0.039	0.817	0.036	0.033	0	43.9	43.9	74.8	133	132	0	31	30
2014	9	12	0	12	18	0.243	-0.01	0.817	0.033	0.03	0	43	42.6	74.4	132	129	0	32	30
2014	9	12	0	22	18	0.315	0	0.82	0.033	0.03	0	42.6	42.1	75.3	130	129	0	31	31
2014	9	12	0	32	18	0.289	-0.036	0.82	0.03	0.03	0	43.4	43.4	74.8	132	131	0	31	30
2014	9	12	0	42	18	0.312	-0.089	0.82	0.033	0.03	0	42.1	43	74.8	129	130	0	31	30
2014	9	12	0	52	18	0.322	-0.023	0.82	0.033	0.03	0	43.9	43	73.1	133	130	0	31	30
2014	9	12	1	2	18	0.226	0.059	0.82	0.036	0.033	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	12	1	12	18	0.272	0	0.82	0.036	0.033	0	43.4	43.4	73.5	132	131	0	31	30
2014	9	12	1	22	18	0.315	0.003	0.82	0.033	0.03	0	43	42.6	74	131	130	0	31	31
2014	9	12	1	32	18	0.289	-0.007	0.82	0.036	0.033	0	43.4	42.6	73.5	132	129	0	31	30
2014	9	12	1	42	18	0.322	-0.089	0.823	0.036	0.033	0	43	43	73.1	131	130	0	31	30
2014	9	12	1	52	18	0.266	0	0.823	0.039	0.036	0	43.9	43	72.7	133	130	0	31	30
2014	9	12	2	2	18	0.299	-0.056	0.823	0.033	0.03	0	43	43	72.7	131	130	0	31	30
2014	9	12	2	12	18	0.269	-0.075	0.823	0.039	0.036	0	42.6	42.6	72.2	130	129	0	31	30
2014	9	12	2	22	18	0.266	-0.056	0.823	0.036	0.033	0	42.6	42.1	71.4	131	128	0	32	30
2014	9	12	2	32	18	0.266	0.02	0.827	0.036	0.033	0	42.6	43	72.2	130	130	0	31	30
2014	9	12	2	42	18	0.233	-0.023	0.827	0.039	0.036	0	43.4	42.6	73.1	132	130	0	31	31
2014	9	12	2	52	18	0.279	-0.007	0.83	0.033	0.03	0	42.6	42.6	72.2	130	130	0	31	31
2014	9	12	3	2	18	0.226	0.01	0.83	0.036	0.033	0	43.4	42.6	71.8	132	130	0	31	31
2014	9	12	3	12	18	0.279	-0.03	0.833	0.033	0.03	0	43	42.6	71.8	131	129	0	31	30
2014	9	12	3	22	18	0.295	-0.036	0.837	0.033	0.03	0	43	43.4	71.8	131	131	0	31	30
2014	9	12	3	32	18	0.299	-0.016	0.837	0.039	0.036	0	42.6	42.6	72.2	129	129	0	30	30
2014	9	12	3	42	18	0.302	0.01	0.837	0.039	0.039	0	44.3	44.3	71.8	134	133	0	31	30
2014	9	12	3	52	18	0.253	-0.066	0.837	0.039	0.036	0	44.7	44.7	71.4	136	134	0	32	30
2014	9	12	4	2	18	0.325	-0.02	0.837	0.039	0.036	0	44.3	43.9	72.7	134	132	0	31	30
2014	9	12	4	12	18	0.348	-0.026	0.84	0.036	0.033	0	44.3	44.3	73.5	134	132	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	4	22	18	0.354	0	0.84	0.033	0.03	0	47.7	46.9	70.1	142	139	0	31	30
2014	9	12	4	32	18	0.299	-0.003	0.84	0.033	0.03	0	46.4	45.6	71.4	139	137	0	31	31
2014	9	12	4	42	18	0.305	0.023	0.84	0.039	0.036	0	46.9	46	71.4	140	137	0	31	30
2014	9	12	4	52	18	0.302	-0.02	0.84	0.039	0.039	0	46.9	45.2	71.4	139	136	0	30	31
2014	9	12	5	2	18	0.295	0.03	0.84	0.039	0.036	0	45.6	45.2	71.8	138	135	0	32	30
2014	9	12	5	12	18	0.272	-0.007	0.84	0.033	0.03	0	46	45.2	72.7	138	135	0	31	30
2014	9	12	5	22	18	0.282	0.026	0.84	0.039	0.036	0	45.2	44.7	73.1	136	135	0	31	31
2014	9	12	5	32	18	0.354	0.013	0.84	0.036	0.033	0	44.7	44.7	74	135	135	0	31	31
2014	9	12	5	42	18	0.344	0.016	0.843	0.033	0.03	0	45.2	44.7	73.5	136	135	0	31	31
2014	9	12	5	52	18	0.282	-0.013	0.843	0.033	0.03	0	45.2	44.3	74	136	134	0	31	31
2014	9	12	6	2	18	0.282	0.046	0.843	0.036	0.033	0	44.3	44.3	74.4	135	134	0	32	31
2014	9	12	6	12	18	0.344	-0.013	0.843	0.033	0.03	0	43.9	44.7	74.4	134	134	0	32	30
2014	9	12	6	22	18	0.282	0.013	0.843	0.033	0.03	0	43.9	44.7	74.4	134	134	0	32	30
2014	9	12	6	32	18	0.249	0	0.843	0.033	0.03	0	43.4	43.4	75.3	133	131	0	32	30
2014	9	12	6	42	18	0.266	-0.013	0.843	0.033	0.03	0	42.6	43	76.1	131	131	0	32	31
2014	9	12	6	52	18	0.259	-0.016	0.843	0.033	0.03	0	42.6	42.6	76.1	131	130	0	32	31
2014	9	12	7	2	18	0.318	-0.026	0.843	0.036	0.033	0	42.6	42.1	75.3	130	128	0	31	30
2014	9	12	7	12	18	0.285	-0.033	0.843	0.033	0.03	0	42.1	41.3	75.7	129	127	0	31	31
2014	9	12	7	22	18	0.223	-0.085	0.843	0.036	0.033	0	41.3	41.3	77	127	126	0	31	30
2014	9	12	7	32	18	0.312	0	0.843	0.036	0.033	0	41.7	41.3	75.7	128	127	0	31	31
2014	9	12	7	42	18	0.295	-0.052	0.843	0.039	0.036	0	41.7	41.7	77	128	128	0	31	31
2014	9	12	7	52	18	0.305	-0.007	0.843	0.033	0.03	0	41.7	42.1	77	129	129	0	32	31
2014	9	12	8	2	18	0.233	-0.036	0.843	0.033	0.03	0	42.1	41.7	77	129	127	0	31	30
2014	9	12	8	12	18	0.325	0.003	0.843	0.033	0.03	0	41.7	41.3	77.4	128	126	0	31	30
2014	9	12	8	22	18	0.279	-0.01	0.843	0.036	0.033	0	41.7	41.3	77	129	127	0	32	31
2014	9	12	8	32	18	0.249	0.016	0.843	0.036	0.033	0	41.3	40.9	77.4	128	126	0	32	31
2014	9	12	8	42	18	0.236	-0.043	0.843	0.033	0.03	0	41.7	41.7	77.4	129	128	0	32	31
2014	9	12	8	52	18	0.305	0	0.843	0.033	0.03	0	42.1	41.3	77.4	129	127	0	31	31
2014	9	12	9	2	18	0.249	0.023	0.843	0.033	0.03	0	41.3	42.1	77	127	128	0	31	30
2014	9	12	9	12	18	0.338	-0.03	0.843	0.036	0.033	0	42.6	42.6	76.5	130	129	0	31	30
2014	9	12	9	22	18	0.318	0.043	0.843	0.039	0.039	0	43	43	76.5	131	131	0	31	31
2014	9	12	9	32	18	0.282	0.007	0.843	0.033	0.03	0	43.4	44.3	76.1	133	134	0	32	31
2014	9	12	9	42	18	0.289	-0.013	0.843	0.033	0.03	0	42.6	43.9	76.5	131	133	0	32	31
2014	9	12	9	52	18	0.259	-0.059	0.843	0.033	0.03	0	44.3	44.7	76.1	133	134	0	30	30
2014	9	12	10	2	18	0.292	-0.01	0.843	0.033	0.03	0	44.3	46	76.1	134	137	0	31	30
2014	9	12	10	12	18	0.354	-0.03	0.843	0.039	0.036	0	44.7	45.6	76.1	136	136	0	32	30
2014	9	12	10	22	18	0.289	0.023	0.843	0.033	0.03	0	44.3	46.4	75.7	134	138	0	31	30
2014	9	12	10	32	18	0.243	0.03	0.843	0.039	0.036	0	45.2	47.3	75.3	136	140	0	31	30
2014	9	12	10	42	18	0.341	0.033	0.843	0.036	0.033	0	44.7	46.9	74.4	136	140	0	32	31
2014	9	12	10	52	18	0.295	0.023	0.843	0.033	0.03	0	44.3	46.9	74.8	135	140	0	32	31
2014	9	12	11	2	18	0.279	-0.033	0.843	0.036	0.033	0	44.3	47.3	74.8	135	141	0	32	31
2014	9	12	11	12	18	0.259	0.026	0.843	0.036	0.033	0	46	47.7	74	138	142	0	31	31
2014	9	12	11	22	18	0.279	0	0.843	0.033	0.03	0	46	47.3	75.3	138	140	0	31	30
2014	9	12	11	32	18	0.341	-0.033	0.843	0.03	0.03	0	46.9	48.6	74.4	140	143	0	31	30
2014	9	12	11	42	18	0.335	-0.043	0.843	0.033	0.03	0	46	48.2	74.8	139	143	0	32	31
2014	9	12	11	52	18	0.289	0.033	0.843	0.03	0.026	0	46.9	48.2	74.4	140	143	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	12	2	18	0.302	0.075	0.843	0.03	0.03	0	48.2	49	73.1	142	144	0	30	30
2014	9	12	12	12	18	0.325	0.059	0.843	0.033	0.03	0	46.4	48.6	72.7	140	143	0	32	30
2014	9	12	12	22	18	0.328	0.069	0.843	0.033	0.03	0	46.9	49.5	72.7	140	145	0	31	30
2014	9	12	12	32	18	0.328	0	0.843	0.033	0.03	0	47.7	49.5	72.7	142	145	0	31	30
2014	9	12	12	42	18	0.285	0.026	0.843	0.036	0.033	0	47.7	49.5	72.2	142	145	0	31	30
2014	9	12	12	52	18	0.338	0.066	0.84	0.03	0.03	0	47.3	49	71.8	142	145	0	32	31
2014	9	12	13	2	18	0.23	0.072	0.843	0.036	0.033	0	46	49.5	72.2	139	145	0	32	30
2014	9	12	13	12	18	0.302	0.052	0.843	0.033	0.03	0	47.3	49	71.8	141	144	0	31	30
2014	9	12	13	22	18	0.325	0.02	0.84	0.036	0.033	0	48.2	49.5	71.8	142	145	0	30	30
2014	9	12	13	32	18	0.295	0.069	0.843	0.036	0.033	0	46.9	49.5	71.4	140	145	0	31	30
2014	9	12	13	42	18	0.341	0.066	0.84	0.033	0.033	0	47.7	49.9	70.5	142	146	0	31	30
2014	9	12	13	52	18	0.308	0.026	0.84	0.033	0.03	0	47.7	49	71.8	142	145	0	31	31
2014	9	12	14	2	18	0.341	0	0.84	0.033	0.03	0	46.9	49	71.8	140	144	0	31	30
2014	9	12	14	12	18	0.295	0.013	0.84	0.033	0.03	0	46.9	48.6	72.2	140	143	0	31	30
2014	9	12	14	22	18	0.312	0.052	0.84	0.033	0.03	0	46.4	48.6	71	139	143	0	31	30
2014	9	12	14	32	18	0.325	-0.03	0.84	0.036	0.033	0	46.9	48.6	71	140	143	0	31	30
2014	9	12	14	42	18	0.328	0.052	0.84	0.033	0.03	0	47.3	49	71.8	141	144	0	31	30
2014	9	12	14	52	18	0.325	0.039	0.84	0.036	0.033	0	46	48.2	71	138	142	0	31	30
2014	9	12	15	2	18	0.292	0.062	0.837	0.036	0.033	0	47.7	50.3	70.1	142	147	0	31	30
2014	9	12	15	12	18	0.364	0.016	0.837	0.039	0.036	0	46.9	49.5	70.5	139	144	0	30	29
2014	9	12	15	22	18	0.302	0.085	0.837	0.033	0.03	0	47.3	49	70.1	141	144	0	31	30
2014	9	12	15	32	18	0.305	0.059	0.837	0.033	0.03	0	46.4	49	71	139	144	0	31	30
2014	9	12	15	42	18	0.328	0.013	0.837	0.036	0.033	0	46.4	48.6	71	139	142	0	31	29
2014	9	12	15	52	18	0.315	0.128	0.837	0.033	0.03	0	46	47.3	70.5	138	140	0	31	30
2014	9	12	16	2	18	0.308	0.016	0.833	0.036	0.033	0	45.2	47.7	71.4	136	140	0	31	29
2014	9	12	16	12	18	0.282	0.049	0.833	0.033	0.03	0	45.2	46.9	71	136	139	0	31	30
2014	9	12	16	22	18	0.331	0.079	0.837	0.033	0.03	0	45.6	46.4	71.4	137	138	0	31	30
2014	9	12	16	32	18	0.325	0.046	0.833	0.033	0.033	0	43.9	44.7	72.2	133	134	0	31	30
2014	9	12	16	42	18	0.272	0.052	0.833	0.033	0.03	0	43.4	43.9	71.8	131	132	0	30	30
2014	9	12	16	52	18	0.302	0.023	0.833	0.039	0.036	0	43	43.9	72.7	131	132	0	31	30
2014	9	12	17	2	18	0.299	0.066	0.833	0.033	0.03	0	42.6	43.4	72.2	129	130	0	30	29
2014	9	12	17	12	18	0.295	0.016	0.833	0.033	0.03	0	42.1	41.7	72.2	129	127	0	31	30
2014	9	12	17	22	18	0.289	0.049	0.83	0.036	0.033	0	42.1	41.3	73.5	128	125	0	30	29
2014	9	12	17	32	18	0.299	0.082	0.833	0.033	0.03	0	41.3	40.4	73.5	126	124	0	30	30
2014	9	12	17	42	18	0.361	0.105	0.833	0.036	0.033	0	40.4	40	73.1	125	123	0	31	30
2014	9	12	17	52	18	0.335	0.049	0.833	0.039	0.039	0	42.6	41.3	73.1	129	125	0	30	29
2014	9	12	18	2	18	0.354	0.075	0.833	0.033	0.03	0	41.3	40.9	73.1	127	124	0	31	29
2014	9	12	18	12	18	0.285	0.095	0.833	0.039	0.036	0	41.3	40.9	73.5	126	125	0	30	30
2014	9	12	18	22	18	0.249	0.043	0.833	0.039	0.036	0	40.9	40.9	73.5	126	125	0	31	30
2014	9	12	18	32	18	0.302	0.03	0.833	0.039	0.036	0	41.3	40.9	73.1	126	124	0	30	29
2014	9	12	18	42	18	0.351	0.03	0.833	0.036	0.033	0	41.3	40	73.5	126	123	0	30	30
2014	9	12	18	52	18	0.315	0	0.833	0.033	0.03	0	41.7	40.4	73.1	127	124	0	30	30
2014	9	12	19	2	18	0.266	0.02	0.837	0.033	0.03	0	41.7	40.4	73.1	128	125	0	31	31
2014	9	12	19	12	18	0.374	0.007	0.833	0.033	0.03	0	42.1	41.3	73.1	128	126	0	30	30
2014	9	12	19	22	18	0.367	0.023	0.833	0.033	0.03	0	42.1	41.3	72.7	128	126	0	30	30
2014	9	12	19	32	18	0.256	0	0.837	0.033	0.03	0	42.1	42.1	73.1	129	128	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	19	42	18	0.361	0.026	0.837	0.033	0.03	0	43.4	42.6	72.7	131	128	0	30	29
2014	9	12	19	52	18	0.344	0.049	0.837	0.036	0.033	0	43	43	72.7	130	129	0	30	29
2014	9	12	20	2	18	0.305	-0.049	0.837	0.033	0.03	0	42.6	42.6	72.7	130	128	0	31	29
2014	9	12	20	12	18	0.243	-0.01	0.84	0.033	0.03	0	43.4	43	72.7	131	129	0	30	29
2014	9	12	20	22	18	0.23	0	0.84	0.039	0.039	0	43.4	43	72.7	131	130	0	30	30
2014	9	12	20	32	18	0.299	-0.016	0.84	0.036	0.033	0	43.9	42.6	72.7	132	129	0	30	30
2014	9	12	20	42	18	0.292	-0.052	0.84	0.036	0.033	0	46	45.6	70.5	138	135	0	31	29
2014	9	12	20	52	18	0.249	-0.02	0.84	0.036	0.033	0	43.4	43.4	72.7	132	131	0	31	30
2014	9	12	21	2	18	0.318	-0.02	0.843	0.036	0.033	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	12	21	12	18	0.226	-0.059	0.843	0.036	0.033	0	43.9	43	72.2	133	130	0	31	30
2014	9	12	21	22	18	0.269	0.007	0.843	0.039	0.036	0	43.4	43	72.7	132	130	0	31	30
2014	9	12	21	32	18	0.236	0.01	0.843	0.033	0.03	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	12	21	42	18	0.312	-0.02	0.843	0.033	0.03	0	43.4	42.6	74.4	131	129	0	30	30
2014	9	12	21	52	18	0.325	0	0.843	0.033	0.03	0	43.4	43	73.1	132	130	0	31	30
2014	9	12	22	2	18	0.312	0	0.843	0.039	0.036	0	43.4	43.4	73.1	132	131	0	31	30
2014	9	12	22	12	18	0.315	0.003	0.843	0.036	0.033	0	43.4	43.4	73.5	132	131	0	31	30
2014	9	12	22	22	18	0.23	-0.013	0.843	0.039	0.036	0	44.7	43.9	72.2	135	132	0	31	30
2014	9	12	22	32	18	0.315	0	0.843	0.033	0.03	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	12	22	42	18	0.305	0.02	0.843	0.036	0.033	0	43.4	43	74	132	130	0	31	30
2014	9	12	22	52	18	0.289	-0.036	0.843	0.036	0.033	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	12	23	2	18	0.289	-0.052	0.843	0.033	0.03	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	12	23	12	18	0.341	0.01	0.843	0.036	0.033	0	44.3	43.4	74.4	133	131	0	30	30
2014	9	12	23	22	18	0.328	0	0.843	0.033	0.03	0	43.4	44.3	73.5	132	133	0	31	30
2014	9	12	23	32	18	0.256	0	0.843	0.033	0.03	0	43	43	74.4	131	131	0	31	31
2014	9	12	23	42	18	0.335	-0.007	0.843	0.036	0.033	0	43	43	74.8	131	130	0	31	30
2014	9	12	23	52	18	0.308	-0.036	0.843	0.033	0.03	0	43.9	44.3	74	133	133	0	31	30
2014	9	13	0	2	18	0.305	-0.049	0.843	0.043	0.039	0	44.3	42.6	74	133	130	0	30	31
2014	9	13	0	12	18	0.338	0.026	0.843	0.033	0.03	0	44.7	43.4	73.5	135	131	0	31	30
2014	9	13	0	22	18	0.266	0.01	0.843	0.033	0.03	0	44.3	43	73.5	134	131	0	31	31
2014	9	13	0	32	18	0.338	0.036	0.843	0.033	0.03	0	43.9	43	74	133	130	0	31	30
2014	9	13	0	42	18	0.249	-0.023	0.843	0.046	0.043	0	43.4	43.4	74	132	131	0	31	30
2014	9	13	0	52	18	0.295	-0.039	0.843	0.033	0.03	0	43.4	43	74	132	130	0	31	30
2014	9	13	1	2	18	0.285	0.023	0.843	0.033	0.03	0	43.4	43.4	74.8	132	131	0	31	30
2014	9	13	1	12	18	0.295	0.013	0.843	0.039	0.036	0	43.4	43.9	74	132	132	0	31	30
2014	9	13	1	22	18	0.331	-0.043	0.843	0.039	0.039	0	43	43.4	74.8	131	131	0	31	30
2014	9	13	1	32	18	0.305	-0.016	0.843	0.033	0.03	0	43.9	43.4	74.4	134	131	0	32	30
2014	9	13	1	42	18	0.305	-0.03	0.843	0.036	0.033	0	43.4	43	74.8	133	131	0	32	31
2014	9	13	1	52	18	0.318	0.023	0.843	0.033	0.03	0	43.4	42.6	74.8	132	130	0	31	31
2014	9	13	2	2	18	0.299	-0.003	0.843	0.036	0.033	0	43.4	43	74.8	132	130	0	31	30
2014	9	13	2	12	18	0.269	0.036	0.843	0.033	0.03	0	43.4	43.9	75.3	132	132	0	31	30
2014	9	13	2	22	18	0.325	-0.033	0.843	0.033	0.03	0	44.7	43.9	75.3	134	132	0	30	30
2014	9	13	2	32	18	0.295	-0.023	0.843	0.039	0.036	0	44.3	44.7	74.4	134	133	0	31	29
2014	9	13	2	42	18	0.302	0.016	0.843	0.033	0.03	0	43.4	43	75.7	132	130	0	31	30
2014	9	13	2	52	18	0.338	-0.016	0.843	0.036	0.033	0	43.9	43.4	74.8	133	131	0	31	30
2014	9	13	3	2	18	0.318	-0.095	0.843	0.033	0.03	0	43.4	43	74.8	132	131	0	31	31
2014	9	13	3	12	18	0.308	0.003	0.843	0.033	0.03	0	43.4	43.4	75.3	132	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	3	22	18	0.289	-0.072	0.843	0.039	0.036	0	42.6	42.6	75.3	131	129	0	32	30
2014	9	13	3	32	18	0.282	-0.003	0.843	0.049	0.046	0	43.4	43.4	75.3	132	131	0	31	30
2014	9	13	3	42	18	0.282	-0.056	0.843	0.039	0.036	0	43.4	43.4	75.3	132	131	0	31	30
2014	9	13	3	52	18	0.266	0.062	0.843	0.036	0.033	0	43	42.6	75.7	131	130	0	31	31
2014	9	13	4	2	18	0.302	-0.016	0.843	0.033	0.03	0	44.3	43.4	75.3	134	131	0	31	30
2014	9	13	4	12	18	0.262	-0.036	0.843	0.033	0.03	0	44.3	43.4	74.4	134	131	0	31	30
2014	9	13	4	22	18	0.318	0	0.846	0.033	0.03	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	13	4	32	18	0.279	0	0.843	0.039	0.036	0	44.7	44.7	75.3	135	134	0	31	30
2014	9	13	4	42	18	0.299	-0.043	0.843	0.036	0.033	0	44.7	43.4	75.3	135	132	0	31	31
2014	9	13	4	52	18	0.285	-0.043	0.843	0.036	0.033	0	44.3	43.9	74.8	134	133	0	31	31
2014	9	13	5	2	18	0.266	-0.03	0.843	0.033	0.03	0	43.9	43.4	74.8	134	132	0	32	31
2014	9	13	5	12	18	0.341	0.01	0.846	0.033	0.03	0	43.9	43.4	75.7	133	131	0	31	30
2014	9	13	5	22	18	0.289	-0.03	0.846	0.039	0.036	0	43.4	43.9	75.7	132	133	0	31	31
2014	9	13	5	32	18	0.249	-0.013	0.846	0.039	0.036	0	43.4	43	74.8	132	131	0	31	31
2014	9	13	5	42	18	0.308	-0.026	0.846	0.036	0.033	0	44.3	43	76.1	133	131	0	30	31
2014	9	13	5	52	18	0.285	-0.003	0.843	0.043	0.039	0	44.7	44.3	75.3	135	133	0	31	30
2014	9	13	6	2	18	0.279	-0.062	0.843	0.033	0.033	0	44.3	43.4	75.7	133	131	0	30	30
2014	9	13	6	12	18	0.246	0.049	0.846	0.03	0.03	0	43.4	43.4	74.8	132	132	0	31	31
2014	9	13	6	22	18	0.348	-0.02	0.846	0.033	0.03	0	43.4	43	76.1	132	130	0	31	30
2014	9	13	6	32	18	0.351	-0.003	0.846	0.036	0.033	0	42.6	42.6	76.1	130	129	0	31	30
2014	9	13	6	42	18	0.338	-0.023	0.846	0.033	0.03	0	42.1	42.1	77	130	128	0	32	30
2014	9	13	6	52	18	0.335	-0.069	0.846	0.036	0.033	0	41.3	41.3	77	127	127	0	31	31
2014	9	13	7	2	18	0.354	-0.046	0.846	0.036	0.033	0	40.9	40.9	77.4	127	126	0	32	31
2014	9	13	7	12	18	0.328	-0.072	0.846	0.036	0.033	0	41.7	41.7	77.4	128	128	0	31	31
2014	9	13	7	22	18	0.243	-0.016	0.846	0.03	0.03	0	40.9	40.9	77.4	127	126	0	32	31
2014	9	13	7	32	18	0.279	-0.072	0.846	0.033	0.03	0	41.3	41.3	77.4	128	126	0	32	30
2014	9	13	7	42	18	0.285	-0.033	0.846	0.036	0.033	0	41.7	41.7	77.8	129	128	0	32	31
2014	9	13	7	52	18	0.236	0.036	0.846	0.036	0.033	0	42.1	42.1	77	129	129	0	31	31
2014	9	13	8	2	18	0.24	-0.003	0.846	0.033	0.03	0	42.1	42.1	77	130	129	0	32	31
2014	9	13	8	12	18	0.312	-0.082	0.846	0.033	0.03	0	41.7	41.7	77	129	127	0	32	30
2014	9	13	8	22	18	0.387	-0.062	0.846	0.033	0.03	0	42.1	41.3	77.4	129	127	0	31	31
2014	9	13	8	32	18	0.259	-0.013	0.846	0.039	0.036	0	42.1	41.7	77.4	130	128	0	32	31
2014	9	13	8	42	18	0.262	-0.052	0.846	0.039	0.036	0	41.7	42.1	77.8	129	128	0	32	30
2014	9	13	8	52	18	0.338	-0.013	0.846	0.033	0.03	0	41.7	41.3	77.4	128	127	0	31	31
2014	9	13	9	2	18	0.315	-0.056	0.846	0.039	0.036	0	41.3	41.3	77	128	127	0	32	31
2014	9	13	9	12	18	0.315	-0.03	0.846	0.033	0.03	0	42.1	42.6	77.4	129	130	0	31	31
2014	9	13	9	22	18	0.328	0.016	0.846	0.036	0.033	0	42.6	43	77.8	131	130	0	32	30
2014	9	13	9	32	18	0.259	-0.013	0.846	0.033	0.03	0	42.6	43	76.5	131	131	0	32	31
2014	9	13	9	42	18	0.295	0.046	0.846	0.039	0.036	0	43.9	44.3	76.5	133	133	0	31	30
2014	9	13	9	52	18	0.236	0.003	0.846	0.033	0.03	0	44.3	44.7	76.5	134	135	0	31	31
2014	9	13	10	2	18	0.328	0.033	0.846	0.039	0.036	0	45.2	45.6	75.7	136	136	0	31	30
2014	9	13	10	12	18	0.384	-0.016	0.846	0.036	0.033	0	44.3	45.6	75.7	134	136	0	31	30
2014	9	13	10	22	18	0.318	0.01	0.846	0.033	0.03	0	44.7	46.4	76.1	136	138	0	32	30
2014	9	13	10	32	18	0.328	0.016	0.846	0.039	0.036	0	44.7	46.9	76.5	135	139	0	31	30
2014	9	13	10	42	18	0.325	0	0.843	0.033	0.03	0	45.2	46.4	76.1	136	138	0	31	30
2014	9	13	10	52	18	0.322	0.066	0.843	0.039	0.036	0	45.2	47.7	75.3	136	141	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	11	2	18	0.302	0.033	0.843	0.036	0.033	0	45.6	47.7	75.7	138	141	0	32	30
2014	9	13	11	12	18	0.318	-0.003	0.843	0.039	0.039	0	46	47.7	75.3	138	142	0	31	31
2014	9	13	11	22	18	0.305	0.013	0.843	0.036	0.033	0	45.2	46.9	74.8	137	140	0	32	31
2014	9	13	11	32	18	0.292	-0.003	0.843	0.033	0.03	0	46	47.7	74	138	141	0	31	30
2014	9	13	11	42	18	0.315	-0.01	0.843	0.033	0.033	0	46	47.7	74.4	138	141	0	31	30
2014	9	13	11	52	18	0.308	-0.033	0.843	0.033	0.03	0	46.9	48.6	73.1	140	144	0	31	31
2014	9	13	12	2	18	0.354	0	0.843	0.033	0.03	0	46.9	49	73.1	140	144	0	31	30
2014	9	13	12	12	18	0.328	0.069	0.843	0.033	0.03	0	46.9	48.6	73.1	140	143	0	31	30
2014	9	13	12	22	18	0.361	-0.016	0.843	0.033	0.03	0	46.4	49	72.7	139	144	0	31	30
2014	9	13	12	32	18	0.295	0.039	0.843	0.033	0.03	0	46.9	48.2	72.7	140	142	0	31	30
2014	9	13	12	42	18	0.354	0.095	0.843	0.03	0.03	0	47.3	49	72.7	141	145	0	31	31
2014	9	13	12	52	18	0.328	0.03	0.843	0.033	0.03	0	46.4	49	72.7	139	144	0	31	30
2014	9	13	13	2	18	0.299	0.085	0.843	0.033	0.03	0	45.6	47.7	73.1	137	142	0	31	31
2014	9	13	13	12	18	0.384	0.069	0.843	0.033	0.03	0	46.4	47.7	72.2	139	141	0	31	30
2014	9	13	13	22	18	0.377	0.092	0.843	0.033	0.03	0	46.9	49.5	71.4	140	145	0	31	30
2014	9	13	13	32	18	0.351	0.056	0.843	0.033	0.03	0	47.3	49.9	71.8	141	145	0	31	29
2014	9	13	13	42	18	0.322	0.105	0.84	0.033	0.03	0	48.6	49.5	71.4	144	145	0	31	30
2014	9	13	13	52	18	0.331	0.121	0.84	0.039	0.036	0	49	50.3	70.5	145	147	0	31	30
2014	9	13	14	2	18	0.341	0.121	0.84	0.036	0.033	0	48.2	49.5	70.1	143	145	0	31	30
2014	9	13	14	12	18	0.312	0.062	0.84	0.036	0.033	0	46.9	47.7	71.4	140	141	0	31	30
2014	9	13	14	22	18	0.397	0.013	0.84	0.03	0.03	0	46	47.3	71	138	141	0	31	31
2014	9	13	14	32	18	0.387	0.02	0.84	0.036	0.033	0	46	48.6	71.4	138	143	0	31	30
2014	9	13	14	42	18	0.328	0.016	0.84	0.033	0.03	0	46.9	49	71.4	140	144	0	31	30
2014	9	13	14	52	18	0.289	0.043	0.84	0.033	0.03	0	43.9	46	71.8	133	137	0	31	30
2014	9	13	15	2	18	0.285	0.039	0.837	0.033	0.033	0	46	48.6	71	137	143	0	30	30
2014	9	13	15	12	18	0.335	0.023	0.837	0.03	0.026	0	47.3	49.5	70.5	141	145	0	31	30
2014	9	13	15	22	18	0.335	0.046	0.837	0.033	0.03	0	47.3	49.5	70.5	141	145	0	31	30
2014	9	13	15	32	18	0.318	0.013	0.837	0.036	0.033	0	46.4	48.2	70.5	139	142	0	31	30
2014	9	13	15	42	18	0.315	0.092	0.833	0.036	0.033	0	45.2	47.7	72.2	137	141	0	32	30
2014	9	13	15	52	18	0.384	0.059	0.833	0.036	0.033	0	47.3	48.6	70.5	141	143	0	31	30
2014	9	13	16	2	18	0.279	0.039	0.833	0.033	0.03	0	44.3	44.7	72.2	133	134	0	30	30
2014	9	13	16	12	18	0.344	0.003	0.833	0.03	0.03	0	44.7	46.4	71.4	135	138	0	31	30
2014	9	13	16	22	18	0.318	0.046	0.83	0.036	0.033	0	43	43.4	72.7	130	131	0	30	30
2014	9	13	16	32	18	0.315	0.105	0.83	0.033	0.03	0	45.6	46.4	71.8	136	138	0	30	30
2014	9	13	16	42	18	0.322	0.082	0.83	0.036	0.033	0	47.3	46.4	70.1	140	138	0	30	30
2014	9	13	16	52	18	0.315	0.22	0.83	0.036	0.033	0	47.7	46.4	70.1	141	138	0	30	30
2014	9	13	17	2	18	0.354	0.171	0.827	0.039	0.039	0	48.2	48.2	69.7	142	142	0	30	30
2014	9	13	17	12	18	0.292	0.18	0.827	0.036	0.033	0	47.7	47.3	69.7	142	140	0	31	30
2014	9	13	17	22	18	0.351	0.213	0.827	0.039	0.036	0	47.7	46.9	70.1	142	139	0	31	30
2014	9	13	17	32	18	0.341	0.213	0.827	0.046	0.043	0	47.7	46	69.7	141	137	0	30	30
2014	9	13	17	42	18	0.322	0.282	0.827	0.039	0.036	0	46	44.7	70.5	138	134	0	31	30
2014	9	13	17	52	18	0.354	0.164	0.827	0.039	0.036	0	44.7	43.9	71.4	135	132	0	31	30
2014	9	13	18	2	18	0.338	0.308	0.827	0.033	0.03	0	43.9	43	71.4	133	130	0	31	30
2014	9	13	18	12	18	0.262	0.262	0.827	0.036	0.033	0	43.4	42.6	71.8	132	129	0	31	30
2014	9	13	18	22	18	0.24	0.197	0.827	0.039	0.036	0	42.6	42.1	72.2	129	128	0	30	30
2014	9	13	18	32	18	0.299	0.144	0.83	0.036	0.033	0	43	41.3	73.1	130	126	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	18	42	18	0.302	0.157	0.83	0.039	0.036	0	41.7	41.7	73.1	128	127	0	31	30
2014	9	13	18	52	18	0.289	0.18	0.83	0.039	0.036	0	40.9	41.7	73.1	126	127	0	31	30
2014	9	13	19	2	18	0.259	0.01	0.83	0.036	0.033	0	41.3	41.7	73.1	127	127	0	31	30
2014	9	13	19	12	18	0.213	0.03	0.83	0.033	0.03	0	41.3	41.3	72.7	127	126	0	31	30
2014	9	13	19	22	18	0.315	0.125	0.83	0.039	0.036	0	44.3	43.9	71.8	134	132	0	31	30
2014	9	13	19	32	18	0.351	0.144	0.827	0.039	0.036	0	46.4	45.2	71.4	139	135	0	31	30
2014	9	13	19	42	18	0.348	0.177	0.83	0.039	0.036	0	46.4	45.6	70.1	139	136	0	31	30
2014	9	13	19	52	18	0.384	0.174	0.83	0.036	0.033	0	45.6	45.2	71	136	134	0	30	29
2014	9	13	20	2	18	0.292	0.148	0.83	0.036	0.033	0	44.7	44.7	70.5	135	134	0	31	30
2014	9	13	20	12	18	0.341	0.013	0.83	0.039	0.039	0	44.7	43.9	71.4	135	132	0	31	30
2014	9	13	20	22	18	0.276	0.026	0.83	0.033	0.03	0	44.3	43.4	71.4	133	131	0	30	30
2014	9	13	20	32	18	0.256	-0.046	0.83	0.036	0.033	0	45.2	44.7	70.5	136	133	0	31	29
2014	9	13	20	42	18	0.299	0.01	0.83	0.036	0.033	0	45.6	44.7	70.1	137	134	0	31	30
2014	9	13	20	52	18	0.308	0.049	0.833	0.039	0.036	0	45.6	43.9	70.1	136	132	0	30	30
2014	9	13	21	2	18	0.361	0.066	0.833	0.036	0.033	0	46	44.7	71.4	137	134	0	30	30
2014	9	13	21	12	18	0.256	0.079	0.833	0.043	0.039	0	44.7	44.7	70.5	135	134	0	31	30
2014	9	13	21	22	18	0.285	0.016	0.833	0.039	0.036	0	45.2	43.9	71.4	136	132	0	31	30
2014	9	13	21	32	18	0.276	-0.003	0.837	0.039	0.039	0	43.9	44.3	71.8	134	133	0	32	30
2014	9	13	21	42	18	0.285	0.013	0.837	0.033	0.03	0	43.4	43.4	72.7	132	131	0	31	30
2014	9	13	21	52	18	0.253	-0.036	0.837	0.033	0.03	0	43.4	43.9	72.2	132	131	0	31	29
2014	9	13	22	2	18	0.266	-0.016	0.837	0.036	0.033	0	43.9	43.9	71.4	133	132	0	31	30
2014	9	13	22	12	18	0.322	0.026	0.837	0.033	0.03	0	43.9	43.4	71.8	133	131	0	31	30
2014	9	13	22	22	18	0.276	-0.003	0.833	0.039	0.036	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	13	22	32	18	0.253	-0.02	0.833	0.033	0.033	0	43.9	43	72.2	133	130	0	31	30
2014	9	13	22	42	18	0.351	-0.056	0.833	0.033	0.03	0	43.4	43	71.8	132	130	0	31	30
2014	9	13	22	52	18	0.331	-0.033	0.837	0.043	0.039	0	43.9	43.4	72.7	132	131	0	30	30
2014	9	13	23	2	18	0.279	0	0.837	0.039	0.036	0	43.4	43.9	72.2	132	132	0	31	30
2014	9	13	23	12	18	0.262	-0.072	0.833	0.033	0.03	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	13	23	22	18	0.269	0.016	0.837	0.036	0.033	0	43.4	43	72.2	132	131	0	31	31
2014	9	13	23	32	18	0.328	-0.007	0.833	0.033	0.03	0	46	46.4	69.7	139	138	0	32	30
2014	9	13	23	42	18	0.249	0.131	0.83	0.039	0.039	0	50.7	50.3	65.8	149	147	0	31	30
2014	9	13	23	52	18	0.279	0.085	0.83	0.039	0.039	0	50.7	49.5	66.7	148	145	0	30	30
2014	9	14	0	2	18	0.302	0.141	0.83	0.033	0.03	0	48.6	47.7	67.5	144	141	0	31	30
2014	9	14	0	12	18	0.299	0.131	0.83	0.036	0.033	0	47.7	46.4	68.8	142	138	0	31	30
2014	9	14	0	22	18	0.338	0.194	0.83	0.033	0.03	0	46.4	45.6	70.1	139	136	0	31	30
2014	9	14	0	32	18	0.285	0.075	0.833	0.039	0.036	0	45.2	44.3	71.4	136	133	0	31	30
2014	9	14	0	42	18	0.325	0.02	0.833	0.033	0.03	0	44.7	43.4	71.4	135	132	0	31	31
2014	9	14	0	52	18	0.24	-0.007	0.83	0.039	0.036	0	43.4	43.9	71.4	132	132	0	31	30
2014	9	14	1	2	18	0.312	-0.069	0.83	0.033	0.03	0	43.4	43	71.8	132	131	0	31	31
2014	9	14	1	12	18	0.305	-0.016	0.83	0.036	0.033	0	43.4	43	72.2	132	130	0	31	30
2014	9	14	1	22	18	0.285	-0.013	0.83	0.036	0.033	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	14	1	32	18	0.276	0.02	0.83	0.033	0.03	0	43.9	43.4	71.4	133	131	0	31	30
2014	9	14	1	42	18	0.279	-0.046	0.83	0.036	0.033	0	43	43	72.2	132	130	0	32	30
2014	9	14	1	52	18	0.243	-0.01	0.83	0.039	0.039	0	43.4	42.6	72.2	132	130	0	31	31
2014	9	14	2	2	18	0.387	-0.043	0.827	0.036	0.033	0	43.4	43	71.8	132	130	0	31	30
2014	9	14	2	12	18	0.331	-0.036	0.827	0.039	0.036	0	42.6	43	72.7	130	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	2	22	18	0.266	-0.105	0.827	0.033	0.03	0	43	42.6	72.7	131	130	0	31	31
2014	9	14	2	32	18	0.236	-0.052	0.827	0.036	0.033	0	44.7	43.9	71.4	135	132	0	31	30
2014	9	14	2	42	18	0.292	-0.016	0.827	0.039	0.036	0	43	43.9	72.2	132	132	0	32	30
2014	9	14	2	52	18	0.279	-0.052	0.827	0.039	0.036	0	43.9	42.6	71.8	133	130	0	31	31
2014	9	14	3	2	18	0.282	0.039	0.827	0.039	0.036	0	43.9	42.6	72.7	133	129	0	31	30
2014	9	14	3	12	18	0.21	-0.016	0.827	0.036	0.033	0	42.6	43	72.2	131	130	0	32	30
2014	9	14	3	22	18	0.292	-0.02	0.827	0.039	0.036	0	43.4	42.6	71.8	131	129	0	30	30
2014	9	14	3	32	18	0.246	-0.036	0.827	0.036	0.033	0	43	43	72.2	131	130	0	31	30
2014	9	14	3	42	18	0.351	-0.085	0.823	0.036	0.033	0	43	43	72.2	131	130	0	31	30
2014	9	14	3	52	18	0.315	-0.003	0.827	0.036	0.033	0	43.4	42.6	71.8	132	129	0	31	30
2014	9	14	4	2	18	0.259	0	0.823	0.036	0.033	0	43.4	43.4	72.7	132	131	0	31	30
2014	9	14	4	12	18	0.351	0.03	0.827	0.033	0.03	0	42.6	42.6	72.2	131	129	0	32	30
2014	9	14	4	22	18	0.253	-0.01	0.827	0.039	0.036	0	43.4	43	72.7	132	130	0	31	30
2014	9	14	4	32	18	0.285	-0.01	0.827	0.033	0.03	0	42.6	43.4	72.2	131	131	0	32	30
2014	9	14	4	42	18	0.217	0.016	0.823	0.03	0.03	0	43	42.1	72.7	131	129	0	31	31
2014	9	14	4	52	18	0.292	-0.01	0.827	0.036	0.033	0	43.4	43.9	72.7	132	132	0	31	30
2014	9	14	5	2	18	0.308	-0.033	0.827	0.036	0.033	0	42.6	43	72.7	131	130	0	32	30
2014	9	14	5	12	18	0.236	-0.016	0.823	0.033	0.03	0	43.4	42.6	71.8	132	130	0	31	31
2014	9	14	5	22	18	0.259	-0.059	0.827	0.036	0.033	0	43	43.4	71.8	131	131	0	31	30
2014	9	14	5	32	18	0.299	-0.033	0.823	0.033	0.03	0	43	43	71.8	131	131	0	31	31
2014	9	14	5	42	18	0.256	0	0.823	0.033	0.03	0	43	43.4	71.8	131	131	0	31	30
2014	9	14	5	52	18	0.236	-0.082	0.823	0.033	0.03	0	43.4	43	71.8	132	130	0	31	30
2014	9	14	6	2	18	0.276	-0.02	0.823	0.033	0.03	0	43.4	42.6	71.4	132	130	0	31	31
2014	9	14	6	12	18	0.295	0	0.823	0.043	0.043	0	43	43.4	71.4	131	131	0	31	30
2014	9	14	6	22	18	0.299	0.046	0.823	0.036	0.033	0	42.6	43	72.2	130	130	0	31	30
2014	9	14	6	32	18	0.23	-0.033	0.823	0.033	0.03	0	42.1	42.6	72.2	129	129	0	31	30
2014	9	14	6	42	18	0.236	0.049	0.827	0.036	0.033	0	42.1	42.1	72.2	129	128	0	31	30
2014	9	14	6	52	18	0.24	-0.072	0.823	0.03	0.03	0	41.7	41.3	73.1	128	127	0	31	31
2014	9	14	7	2	18	0.328	-0.085	0.823	0.036	0.033	0	40.9	40.4	72.7	127	125	0	32	31
2014	9	14	7	12	18	0.217	-0.03	0.823	0.033	0.03	0	40.9	41.7	73.1	126	127	0	31	30
2014	9	14	7	22	18	0.279	0.016	0.823	0.039	0.036	0	40.9	40.4	73.1	127	125	0	32	31
2014	9	14	7	32	18	0.292	-0.043	0.823	0.036	0.033	0	40.9	41.3	72.7	126	126	0	31	30
2014	9	14	7	42	18	0.259	-0.069	0.823	0.033	0.033	0	40.9	41.3	73.5	126	126	0	31	30
2014	9	14	7	52	18	0.295	-0.023	0.823	0.036	0.033	0	40.4	40.9	73.1	125	125	0	31	30
2014	9	14	8	2	18	0.259	-0.013	0.823	0.033	0.03	0	40.4	40	73.5	126	124	0	32	31
2014	9	14	8	12	18	0.246	-0.016	0.823	0.033	0.03	0	40.4	41.3	73.1	126	127	0	32	31
2014	9	14	8	22	18	0.305	-0.085	0.823	0.036	0.033	0	40.9	41.3	74	126	126	0	31	30
2014	9	14	8	32	18	0.282	-0.121	0.823	0.033	0.03	0	40.4	40.9	73.1	126	126	0	32	31
2014	9	14	8	42	18	0.23	-0.059	0.823	0.033	0.03	0	40	40.4	73.5	125	125	0	32	31
2014	9	14	8	52	18	0.256	-0.052	0.82	0.039	0.036	0	40.4	40.4	74	125	124	0	31	30
2014	9	14	9	2	18	0.266	-0.039	0.823	0.036	0.033	0	40.9	41.3	73.5	126	126	0	31	30
2014	9	14	9	12	18	0.292	-0.016	0.82	0.036	0.033	0	41.3	41.7	73.5	127	128	0	31	31
2014	9	14	9	22	18	0.312	-0.046	0.82	0.036	0.033	0	41.3	41.7	74	127	128	0	31	31
2014	9	14	9	32	18	0.285	-0.026	0.82	0.033	0.03	0	41.7	42.6	74	129	130	0	32	31
2014	9	14	9	42	18	0.226	0.003	0.82	0.036	0.033	0	43	43	73.1	131	131	0	31	31
2014	9	14	9	52	18	0.285	-0.049	0.82	0.036	0.033	0	41.3	42.6	73.5	127	129	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	10	2	18	0.256	-0.007	0.82	0.033	0.03	0	42.6	43	73.1	130	130	0	31	30
2014	9	14	10	12	18	0.312	0.072	0.82	0.033	0.03	0	42.6	43.9	73.1	130	133	0	31	31
2014	9	14	10	22	18	0.243	-0.033	0.82	0.033	0.03	0	43.9	46	72.7	134	137	0	32	30
2014	9	14	10	32	18	0.351	0.056	0.82	0.033	0.03	0	44.3	46.9	73.1	135	139	0	32	30
2014	9	14	10	42	18	0.279	0.013	0.82	0.033	0.03	0	45.2	46.4	73.1	136	138	0	31	30
2014	9	14	10	52	18	0.331	0.02	0.82	0.033	0.03	0	45.2	47.7	72.7	137	141	0	32	30
2014	9	14	11	2	18	0.335	-0.016	0.82	0.033	0.03	0	45.6	47.3	72.7	137	141	0	31	31
2014	9	14	11	12	18	0.302	0.049	0.817	0.03	0.03	0	46	47.7	73.5	138	141	0	31	30
2014	9	14	11	22	18	0.315	0.01	0.82	0.033	0.03	0	46.4	48.2	71.8	139	143	0	31	31
2014	9	14	11	32	18	0.308	-0.01	0.82	0.033	0.03	0	46.4	48.2	72.7	139	142	0	31	30
2014	9	14	11	42	18	0.256	0.023	0.82	0.033	0.03	0	46.9	48.6	73.1	140	143	0	31	30
2014	9	14	11	52	18	0.285	-0.033	0.817	0.033	0.03	0	45.6	47.3	74.4	137	140	0	31	30
2014	9	14	12	2	18	0.259	0.01	0.817	0.03	0.03	0	45.2	47.3	74	136	140	0	31	30
2014	9	14	12	12	18	0.305	0.013	0.817	0.033	0.03	0	46.4	47.3	73.1	139	141	0	31	31
2014	9	14	12	22	18	0.302	0.033	0.817	0.033	0.03	0	46	48.2	72.7	138	142	0	31	30
2014	9	14	12	32	18	0.305	0.039	0.817	0.033	0.03	0	44.3	46.4	73.5	134	138	0	31	30
2014	9	14	12	42	18	0.348	0.033	0.817	0.033	0.03	0	45.6	48.2	73.1	137	142	0	31	30
2014	9	14	12	52	18	0.269	0.085	0.817	0.033	0.03	0	46.4	47.7	73.1	139	141	0	31	30
2014	9	14	13	2	18	0.318	0.03	0.817	0.033	0.03	0	46	47.3	73.1	138	140	0	31	30
2014	9	14	13	12	18	0.322	0.026	0.817	0.03	0.026	0	46	46.9	74.4	138	140	0	31	31
2014	9	14	13	22	18	0.318	0.03	0.817	0.039	0.039	0	45.6	47.3	74	136	140	0	30	30
2014	9	14	13	32	18	0.407	0.007	0.817	0.036	0.033	0	46.4	48.6	74	139	143	0	31	30
2014	9	14	13	42	18	0.318	0.013	0.817	0.033	0.03	0	45.2	47.7	73.5	136	141	0	31	30
2014	9	14	13	52	18	0.269	-0.023	0.817	0.033	0.03	0	46	47.3	74	138	141	0	31	31
2014	9	14	14	2	18	0.289	0.013	0.817	0.033	0.03	0	47.3	49	74	141	144	0	31	30
2014	9	14	14	12	18	0.331	0.069	0.817	0.036	0.033	0	45.6	49	74.4	138	144	0	32	30
2014	9	14	14	22	18	0.325	0.033	0.817	0.033	0.03	0	45.6	48.6	75.3	137	142	0	31	29
2014	9	14	14	32	18	0.328	0.003	0.817	0.039	0.036	0	47.3	49.5	74.4	141	145	0	31	30
2014	9	14	14	42	18	0.348	0.013	0.817	0.033	0.03	0	46	48.2	75.7	138	142	0	31	30
2014	9	14	14	52	18	0.269	0.023	0.817	0.036	0.033	0	46	47.7	75.3	138	141	0	31	30
2014	9	14	15	2	18	0.305	0.049	0.817	0.036	0.033	0	45.2	46.9	75.7	136	139	0	31	30
2014	9	14	15	12	18	0.328	0.026	0.817	0.036	0.033	0	43.9	45.2	74.8	133	135	0	31	30
2014	9	14	15	22	18	0.344	0.069	0.817	0.03	0.03	0	46	46.4	74.8	137	138	0	30	30
2014	9	14	15	32	18	0.325	0.062	0.817	0.033	0.03	0	46	47.3	75.3	138	140	0	31	30
2014	9	14	15	42	18	0.279	0	0.817	0.033	0.03	0	47.3	48.6	74.8	140	143	0	30	30
2014	9	14	15	52	18	0.289	0.036	0.817	0.03	0.03	0	44.3	45.6	76.5	134	136	0	31	30
2014	9	14	16	2	18	0.289	0.016	0.817	0.036	0.033	0	46.9	48.6	74	140	143	0	31	30
2014	9	14	16	12	18	0.253	0.023	0.814	0.033	0.03	0	46	48.2	76.1	138	141	0	31	29
2014	9	14	16	22	18	0.256	0.043	0.817	0.036	0.033	0	40.9	41.3	76.5	127	126	0	32	30
2014	9	14	16	32	18	0.213	0.056	0.817	0.033	0.03	0	40.9	40.4	77	125	124	0	30	30
2014	9	14	16	42	18	0.318	0.105	0.817	0.039	0.036	0	40.9	40.4	77	125	124	0	30	30
2014	9	14	16	52	18	0.328	0.095	0.817	0.036	0.033	0	42.1	41.7	76.1	129	127	0	31	30
2014	9	14	17	2	18	0.279	0.03	0.817	0.033	0.03	0	42.6	42.1	77	130	128	0	31	30
2014	9	14	17	12	18	0.364	0.046	0.817	0.033	0.03	0	42.1	41.7	76.5	129	127	0	31	30
2014	9	14	17	22	18	0.341	0.089	0.817	0.033	0.03	0	43	41.7	76.5	130	127	0	30	30
2014	9	14	17	32	18	0.308	0.039	0.817	0.036	0.033	0	42.1	41.3	77.4	129	126	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	17	42	18	0.243	0.043	0.817	0.039	0.036	0	40.9	40.4	77.4	126	124	0	31	30
2014	9	14	17	52	18	0.344	0.033	0.817	0.043	0.039	0	40.4	40.9	77.4	125	124	0	31	29
2014	9	14	18	2	18	0.256	0.007	0.817	0.036	0.033	0	40.9	40	78.3	125	123	0	30	30
2014	9	14	18	12	18	0.354	0.026	0.817	0.039	0.036	0	40.4	39.6	77.8	125	122	0	31	30
2014	9	14	18	22	18	0.292	0.039	0.817	0.039	0.036	0	40	39.6	77.8	124	122	0	31	30
2014	9	14	18	32	18	0.256	0.033	0.817	0.039	0.036	0	39.6	40	77.8	123	122	0	31	29
2014	9	14	18	42	18	0.174	-0.03	0.817	0.033	0.03	0	40	40.4	77.8	124	124	0	31	30
2014	9	14	18	52	18	0.256	0.007	0.817	0.033	0.03	0	40.9	40.4	78.3	125	124	0	30	30
2014	9	14	19	2	18	0.285	0.085	0.817	0.039	0.036	0	40.9	40.4	77.8	126	125	0	31	31
2014	9	14	19	12	18	0.226	-0.01	0.817	0.036	0.033	0	41.3	40.4	78.3	127	125	0	31	31
2014	9	14	19	22	18	0.24	0.013	0.817	0.036	0.033	0	41.7	41.3	77.8	127	126	0	30	30
2014	9	14	19	32	18	0.23	0	0.817	0.039	0.036	0	42.1	41.7	77.4	128	127	0	30	30
2014	9	14	19	42	18	0.262	0.007	0.817	0.033	0.03	0	42.1	41.7	77	128	127	0	30	30
2014	9	14	19	52	18	0.243	-0.003	0.817	0.039	0.036	0	41.7	42.6	77.4	128	129	0	31	30
2014	9	14	20	2	18	0.256	-0.046	0.817	0.033	0.03	0	41.7	41.3	77.8	128	126	0	31	30
2014	9	14	20	12	18	0.24	-0.023	0.817	0.043	0.039	0	42.6	42.6	76.5	130	128	0	31	29
2014	9	14	20	22	18	0.262	0.069	0.817	0.033	0.03	0	42.6	41.3	77.4	130	127	0	31	31
2014	9	14	20	32	18	0.289	-0.02	0.817	0.039	0.036	0	43	43	76.1	130	129	0	30	29
2014	9	14	20	42	18	0.279	-0.013	0.817	0.036	0.033	0	43.4	42.1	76.1	132	129	0	31	31
2014	9	14	20	52	18	0.213	0.013	0.817	0.033	0.03	0	43.4	43	77	131	130	0	30	30
2014	9	14	21	2	18	0.24	-0.007	0.817	0.033	0.03	0	43	42.6	76.5	131	129	0	31	30
2014	9	14	21	12	18	0.226	-0.043	0.817	0.039	0.036	0	44.3	42.6	76.5	133	129	0	30	30
2014	9	14	21	22	18	0.312	-0.013	0.817	0.036	0.033	0	43.4	43.4	76.1	131	131	0	30	30
2014	9	14	21	32	18	0.335	0.007	0.817	0.033	0.03	0	43	43	76.5	131	130	0	31	30
2014	9	14	21	42	18	0.262	-0.062	0.817	0.039	0.036	0	43.4	43.4	76.1	132	131	0	31	30
2014	9	14	21	52	18	0.322	-0.062	0.817	0.036	0.033	0	44.3	43.4	75.3	133	131	0	30	30
2014	9	14	22	2	18	0.276	-0.043	0.814	0.036	0.033	0	45.2	44.3	74.4	136	133	0	31	30
2014	9	14	22	12	18	0.253	0	0.817	0.033	0.03	0	44.7	43	76.1	134	130	0	30	30
2014	9	14	22	22	18	0.285	0.023	0.817	0.039	0.036	0	44.7	43.9	75.3	135	132	0	31	30
2014	9	14	22	32	18	0.262	-0.056	0.817	0.036	0.033	0	44.7	43.9	76.1	135	132	0	31	30
2014	9	14	22	42	18	0.289	-0.03	0.814	0.033	0.03	0	46	45.6	73.5	138	136	0	31	30
2014	9	14	22	52	18	0.233	-0.02	0.814	0.039	0.036	0	47.3	46.9	72.7	141	139	0	31	30
2014	9	14	23	2	18	0.302	0	0.814	0.039	0.036	0	46.9	46	73.5	140	137	0	31	30
2014	9	14	23	12	18	0.253	-0.026	0.814	0.036	0.033	0	45.2	44.7	74.4	136	134	0	31	30
2014	9	14	23	22	18	0.24	-0.046	0.817	0.039	0.039	0	44.7	44.3	75.7	134	133	0	30	30
2014	9	14	23	32	18	0.246	-0.007	0.817	0.039	0.036	0	45.6	44.7	74.4	137	134	0	31	30
2014	9	14	23	42	18	0.272	0.016	0.814	0.036	0.033	0	45.2	43.9	74.8	135	132	0	30	30
2014	9	14	23	52	18	0.249	-0.039	0.814	0.033	0.03	0	45.6	44.7	74.4	137	135	0	31	31
2014	9	15	0	2	18	0.233	-0.03	0.814	0.033	0.03	0	46.4	45.6	73.5	139	136	0	31	30
2014	9	15	0	12	18	0.276	-0.066	0.814	0.033	0.03	0	44.7	44.3	74.8	135	133	0	31	30
2014	9	15	0	22	18	0.23	-0.105	0.817	0.033	0.03	0	43.9	44.3	75.7	133	133	0	31	30
2014	9	15	0	32	18	0.302	0.056	0.817	0.033	0.03	0	44.3	43.9	74.4	134	132	0	31	30
2014	9	15	0	42	18	0.279	-0.036	0.817	0.036	0.033	0	44.7	43.9	74.8	135	132	0	31	30
2014	9	15	0	52	18	0.246	-0.039	0.817	0.033	0.03	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	15	1	2	18	0.305	-0.046	0.814	0.036	0.033	0	43.9	43.9	74.8	133	132	0	31	30
2014	9	15	1	12	18	0.381	0	0.817	0.039	0.036	0	44.3	43.4	74.8	134	132	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	1	22	18	0.308	-0.016	0.817	0.036	0.033	0	44.3	43.4	75.7	134	131	0	31	30
2014	9	15	1	32	18	0.2	-0.089	0.817	0.033	0.03	0	43	44.3	75.3	131	132	0	31	29
2014	9	15	1	42	18	0.269	-0.003	0.817	0.036	0.033	0	43	43.4	75.7	132	131	0	32	30
2014	9	15	1	52	18	0.246	-0.052	0.814	0.036	0.033	0	43.9	42.6	75.3	133	129	0	31	30
2014	9	15	2	2	18	0.348	0.059	0.817	0.036	0.033	0	43.4	43	74.8	132	131	0	31	31
2014	9	15	2	12	18	0.259	0.01	0.817	0.036	0.033	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	15	2	22	18	0.194	0.023	0.817	0.036	0.033	0	43.9	43.4	74.8	133	132	0	31	31
2014	9	15	2	32	18	0.249	-0.016	0.817	0.036	0.033	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	15	2	42	18	0.318	-0.016	0.817	0.036	0.033	0	43	43	74.8	132	131	0	32	31
2014	9	15	2	52	18	0.282	-0.016	0.817	0.033	0.03	0	44.3	43	75.3	133	131	0	30	31
2014	9	15	3	2	18	0.24	0.033	0.817	0.036	0.033	0	43.4	43	75.3	132	131	0	31	31
2014	9	15	3	12	18	0.256	-0.062	0.817	0.036	0.033	0	43.9	43	74.8	133	131	0	31	31
2014	9	15	3	22	18	0.217	0	0.817	0.036	0.033	0	43.9	43	75.7	133	130	0	31	30
2014	9	15	3	32	18	0.295	-0.046	0.817	0.033	0.03	0	42.6	43	74.4	131	130	0	32	30
2014	9	15	3	42	18	0.246	0.003	0.817	0.039	0.036	0	42.6	43.4	75.3	131	131	0	32	30
2014	9	15	3	52	18	0.312	0	0.817	0.033	0.03	0	43.9	43.4	74.4	133	132	0	31	31
2014	9	15	4	2	18	0.259	-0.026	0.817	0.033	0.03	0	43.4	43.4	74.8	133	131	0	32	30
2014	9	15	4	12	18	0.207	0.033	0.817	0.033	0.03	0	43.9	43.4	75.7	133	131	0	31	30
2014	9	15	4	22	18	0.266	-0.023	0.817	0.036	0.033	0	43	43.4	75.3	131	131	0	31	30
2014	9	15	4	32	18	0.272	-0.013	0.817	0.036	0.033	0	43.4	43	75.3	133	130	0	32	30
2014	9	15	4	42	18	0.262	-0.062	0.817	0.039	0.036	0	43	42.6	75.7	131	130	0	31	31
2014	9	15	4	52	18	0.236	-0.02	0.814	0.039	0.039	0	43	43	74.8	131	131	0	31	31
2014	9	15	5	2	18	0.194	-0.013	0.814	0.033	0.03	0	43.4	43.4	75.3	132	131	0	31	30
2014	9	15	5	12	18	0.302	0.01	0.814	0.039	0.036	0	43.9	43.4	75.3	133	132	0	31	31
2014	9	15	5	22	18	0.276	0.01	0.814	0.039	0.036	0	43.4	43	75.3	132	130	0	31	30
2014	9	15	5	32	18	0.295	-0.062	0.814	0.033	0.03	0	43.4	43	74.8	132	131	0	31	31
2014	9	15	5	42	18	0.243	-0.043	0.814	0.033	0.033	0	43	43.9	75.3	132	132	0	32	30
2014	9	15	5	52	18	0.315	0	0.814	0.03	0.03	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	15	6	2	18	0.253	0.01	0.814	0.033	0.03	0	44.3	43.4	74.8	134	131	0	31	30
2014	9	15	6	12	18	0.348	-0.01	0.814	0.033	0.03	0	43.4	43.4	74.4	133	132	0	32	31
2014	9	15	6	22	18	0.259	-0.069	0.814	0.036	0.033	0	43.4	43.4	74.4	132	131	0	31	30
2014	9	15	6	32	18	0.249	-0.089	0.814	0.039	0.036	0	42.6	42.6	75.3	131	129	0	32	30
2014	9	15	6	42	18	0.266	-0.046	0.814	0.033	0.03	0	42.1	42.1	75.7	130	129	0	32	31
2014	9	15	6	52	18	0.259	-0.085	0.814	0.036	0.033	0	41.7	41.3	75.3	128	127	0	31	31
2014	9	15	7	2	18	0.243	-0.007	0.814	0.033	0.03	0	40.9	41.3	75.7	127	126	0	32	30
2014	9	15	7	12	18	0.207	-0.036	0.814	0.039	0.036	0	40.9	40.9	75.3	126	126	0	31	31
2014	9	15	7	22	18	0.318	-0.033	0.814	0.03	0.03	0	40.9	40.9	76.1	126	126	0	31	31
2014	9	15	7	32	18	0.285	-0.01	0.814	0.033	0.03	0	40	40.4	76.5	125	125	0	32	31
2014	9	15	7	42	18	0.246	-0.003	0.814	0.033	0.03	0	40.4	40.9	76.1	125	125	0	31	30
2014	9	15	7	52	18	0.259	0	0.814	0.039	0.039	0	40.4	40	76.1	126	124	0	32	31
2014	9	15	8	2	18	0.302	-0.01	0.814	0.033	0.03	0	40.9	41.3	76.1	127	127	0	32	31
2014	9	15	8	12	18	0.269	-0.033	0.814	0.03	0.03	0	41.3	41.3	76.1	127	126	0	31	30
2014	9	15	8	22	18	0.144	-0.023	0.814	0.036	0.033	0	40.9	40	76.1	126	124	0	31	31
2014	9	15	8	32	18	0.331	0.016	0.814	0.033	0.03	0	40.9	40.9	76.5	126	126	0	31	31
2014	9	15	8	42	18	0.279	0.026	0.814	0.036	0.033	0	40.4	40.9	76.5	126	125	0	32	30
2014	9	15	8	52	18	0.203	-0.026	0.814	0.033	0.03	0	40	40.4	76.1	125	125	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	9	2	18	0.187	0.003	0.814	0.039	0.036	0	40.9	40.9	76.5	127	126	0	32	31
2014	9	15	9	12	18	0.279	0.003	0.814	0.033	0.03	0	40.4	40.4	76.5	126	125	0	32	31
2014	9	15	9	22	18	0.207	-0.03	0.814	0.033	0.03	0	40	41.7	75.7	125	127	0	32	30
2014	9	15	9	32	18	0.276	0.033	0.814	0.036	0.033	0	41.7	42.1	76.5	129	129	0	32	31
2014	9	15	9	42	18	0.233	0.007	0.814	0.033	0.03	0	43.4	43	76.1	132	131	0	31	31
2014	9	15	9	52	18	0.312	0	0.814	0.033	0.03	0	42.6	43.9	76.1	131	133	0	32	31
2014	9	15	10	2	18	0.279	-0.013	0.814	0.033	0.03	0	42.6	44.7	75.7	131	135	0	32	31
2014	9	15	10	12	18	0.22	0	0.814	0.033	0.03	0	43.9	45.6	76.5	133	136	0	31	30
2014	9	15	10	22	18	0.285	0.01	0.814	0.03	0.03	0	44.3	45.2	76.1	134	136	0	31	31
2014	9	15	10	32	18	0.292	-0.075	0.814	0.039	0.036	0	43.4	45.2	76.1	133	135	0	32	30
2014	9	15	10	42	18	0.21	-0.03	0.81	0.033	0.03	0	45.6	47.7	75.3	138	141	0	32	30
2014	9	15	10	52	18	0.282	-0.016	0.81	0.033	0.03	0	45.2	47.3	75.3	137	141	0	32	31
2014	9	15	11	2	18	0.22	-0.026	0.81	0.039	0.039	0	45.6	47.3	76.1	137	141	0	31	31
2014	9	15	11	12	18	0.282	0.036	0.81	0.033	0.03	0	45.6	46.9	75.7	138	140	0	32	31
2014	9	15	11	22	18	0.194	-0.039	0.81	0.033	0.03	0	46	47.7	74.4	139	141	0	32	30
2014	9	15	11	32	18	0.266	-0.016	0.81	0.033	0.03	0	46	48.2	75.3	138	142	0	31	30
2014	9	15	11	42	18	0.295	-0.03	0.81	0.033	0.03	0	46	47.3	75.3	138	140	0	31	30
2014	9	15	11	52	18	0.318	0.013	0.81	0.033	0.03	0	44.7	46.4	75.3	136	138	0	32	30
2014	9	15	12	2	18	0.243	0.026	0.81	0.033	0.03	0	47.7	49	74	142	144	0	31	30
2014	9	15	12	12	18	0.236	-0.036	0.81	0.033	0.03	0	45.2	46.9	75.3	136	139	0	31	30
2014	9	15	12	22	18	0.302	0.013	0.81	0.03	0.03	0	46.9	48.6	75.3	140	143	0	31	30
2014	9	15	12	32	18	0.262	0.03	0.81	0.033	0.03	0	48.6	49.9	74.4	144	146	0	31	30
2014	9	15	12	42	18	0.272	0.007	0.81	0.033	0.03	0	46.9	49	74.8	140	144	0	31	30
2014	9	15	12	52	18	0.266	0.089	0.81	0.033	0.033	0	46.9	49	74.4	140	144	0	31	30
2014	9	15	13	2	18	0.285	0.052	0.807	0.033	0.03	0	46.4	48.6	74.4	139	143	0	31	30
2014	9	15	13	12	18	0.315	0.036	0.807	0.039	0.036	0	47.3	48.2	72.7	141	142	0	31	30
2014	9	15	13	22	18	0.302	0.023	0.807	0.036	0.033	0	46.4	48.2	72.7	140	142	0	32	30
2014	9	15	13	32	18	0.236	0.059	0.807	0.033	0.03	0	46.9	48.6	71.4	140	143	0	31	30
2014	9	15	13	42	18	0.305	0.016	0.807	0.033	0.03	0	46.9	48.2	71.4	140	142	0	31	30
2014	9	15	13	52	18	0.289	-0.02	0.804	0.036	0.033	0	46.4	48.2	71.4	139	142	0	31	30
2014	9	15	14	2	18	0.292	0.066	0.804	0.036	0.033	0	46.4	49.5	71	139	144	0	31	29
2014	9	15	14	12	18	0.312	0.056	0.804	0.03	0.03	0	46.4	48.6	71.8	139	142	0	31	29
2014	9	15	14	22	18	0.266	0.059	0.804	0.033	0.03	0	45.6	47.3	71.4	137	140	0	31	30
2014	9	15	14	32	18	0.285	0	0.804	0.033	0.03	0	46.4	47.7	71.4	138	141	0	30	30
2014	9	15	14	42	18	0.312	0.033	0.801	0.033	0.03	0	46.9	48.2	71	140	142	0	31	30
2014	9	15	14	52	18	0.279	0.089	0.801	0.033	0.03	0	46.4	47.7	70.1	138	141	0	30	30
2014	9	15	15	2	18	0.295	0.121	0.797	0.033	0.03	0	46.9	48.2	69.7	140	142	0	31	30
2014	9	15	15	12	18	0.338	0.026	0.794	0.033	0.03	0	45.6	47.7	70.5	137	141	0	31	30
2014	9	15	15	22	18	0.312	0.003	0.794	0.039	0.039	0	44.7	47.3	70.5	135	140	0	31	30
2014	9	15	15	32	18	0.24	0.095	0.794	0.033	0.03	0	46.4	46.9	71.4	139	139	0	31	30
2014	9	15	15	42	18	0.217	0.01	0.791	0.033	0.03	0	44.7	45.6	72.7	134	135	0	30	29
2014	9	15	15	52	18	0.335	0.039	0.791	0.039	0.036	0	41.7	42.1	73.5	128	128	0	31	30
2014	9	15	16	2	18	0.276	0.069	0.791	0.036	0.033	0	42.1	42.1	73.5	128	127	0	30	29
2014	9	15	16	12	18	0.315	0.062	0.791	0.033	0.03	0	42.1	43.4	73.5	129	130	0	31	29
2014	9	15	16	22	18	0.236	0.046	0.791	0.039	0.039	0	43	43	73.1	131	129	0	31	29
2014	9	15	16	32	18	0.282	0.043	0.791	0.033	0.03	0	41.3	40.4	74	127	124	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	16	42	18	0.299	0.079	0.787	0.039	0.039	0	40.4	40	74	125	123	0	31	30
2014	9	15	16	52	18	0.295	0.016	0.787	0.033	0.03	0	41.3	42.1	74	127	128	0	31	30
2014	9	15	17	2	18	0.276	0.125	0.787	0.033	0.03	0	41.3	41.3	74	126	126	0	30	30
2014	9	15	17	12	18	0.256	0.075	0.787	0.033	0.03	0	40.9	41.7	74.8	126	126	0	31	29
2014	9	15	17	22	18	0.305	0.098	0.787	0.033	0.03	0	42.1	41.3	74.4	129	126	0	31	30
2014	9	15	17	32	18	0.24	0.003	0.787	0.039	0.036	0	41.3	40.4	74	127	124	0	31	30
2014	9	15	17	42	18	0.289	0.066	0.787	0.036	0.033	0	40	40	75.3	124	123	0	31	30
2014	9	15	17	52	18	0.259	0.033	0.787	0.033	0.03	0	40.4	40.4	75.7	124	123	0	30	29
2014	9	15	18	2	18	0.243	0.069	0.787	0.039	0.036	0	40.4	39.1	74.8	124	121	0	30	30
2014	9	15	18	12	18	0.269	-0.085	0.787	0.039	0.036	0	40	40	74.8	124	122	0	31	29
2014	9	15	18	22	18	0.187	0.036	0.787	0.039	0.036	0	39.6	39.6	75.3	123	122	0	31	30
2014	9	15	18	32	18	0.272	-0.02	0.787	0.036	0.033	0	40.9	41.3	76.1	125	125	0	30	29
2014	9	15	18	42	18	0.161	0	0.787	0.036	0.033	0	40	40.4	75.3	124	123	0	31	29
2014	9	15	18	52	18	0.249	-0.003	0.787	0.036	0.033	0	40.4	40.4	75.7	124	123	0	30	29
2014	9	15	19	2	18	0.299	-0.007	0.784	0.033	0.03	0	40.4	40.4	75.3	125	124	0	31	30
2014	9	15	19	12	18	0.259	0.013	0.787	0.039	0.036	0	41.3	40.4	75.3	126	124	0	30	30
2014	9	15	19	22	18	0.299	0.003	0.784	0.036	0.033	0	41.7	41.7	75.3	128	127	0	31	30
2014	9	15	19	32	18	0.23	0	0.784	0.033	0.03	0	42.6	41.7	74.8	129	127	0	30	30
2014	9	15	19	42	18	0.256	0.003	0.784	0.033	0.03	0	43	41.7	74.8	130	127	0	30	30
2014	9	15	19	52	18	0.223	0	0.784	0.033	0.03	0	42.1	42.6	74.4	128	128	0	30	29
2014	9	15	20	2	18	0.236	-0.052	0.784	0.036	0.033	0	42.1	42.1	74.4	129	128	0	31	30
2014	9	15	20	12	18	0.279	-0.007	0.784	0.036	0.033	0	43	42.1	74	130	128	0	30	30
2014	9	15	20	22	18	0.246	-0.013	0.784	0.036	0.033	0	43.4	43.4	74	132	131	0	31	30
2014	9	15	20	32	18	0.213	-0.02	0.784	0.036	0.033	0	43.4	43	74	131	129	0	30	29
2014	9	15	20	42	18	0.161	-0.01	0.784	0.039	0.039	0	43	42.1	74	131	128	0	31	30
2014	9	15	20	52	18	0.272	0.007	0.784	0.033	0.03	0	42.6	42.6	74.8	130	128	0	31	29
2014	9	15	21	2	18	0.236	-0.03	0.784	0.033	0.03	0	43.4	42.6	73.5	132	129	0	31	30
2014	9	15	21	12	18	0.197	-0.036	0.784	0.039	0.036	0	43	43.4	73.5	131	130	0	31	29
2014	9	15	21	22	18	0.282	-0.043	0.784	0.039	0.039	0	43.4	42.6	72.2	131	129	0	30	30
2014	9	15	21	32	18	0.282	-0.026	0.784	0.039	0.036	0	44.3	43	72.2	133	130	0	30	30
2014	9	15	21	42	18	0.233	-0.085	0.784	0.033	0.03	0	42.6	42.6	73.1	130	129	0	31	30
2014	9	15	21	52	18	0.272	0.01	0.784	0.039	0.036	0	42.6	43	73.1	129	129	0	30	29
2014	9	15	22	2	18	0.174	0	0.784	0.033	0.03	0	42.6	42.1	72.7	130	128	0	31	30
2014	9	15	22	12	18	0.243	-0.049	0.784	0.033	0.03	0	43.4	43.9	73.1	132	132	0	31	30
2014	9	15	22	22	18	0.266	-0.033	0.784	0.033	0.03	0	43.4	43	73.1	132	130	0	31	30
2014	9	15	22	32	18	0.24	-0.036	0.784	0.039	0.036	0	43	43.4	73.5	131	131	0	31	30
2014	9	15	22	42	18	0.22	0.016	0.781	0.043	0.043	0	48.6	47.3	69.2	144	140	0	31	30
2014	9	15	22	52	18	0.272	-0.059	0.784	0.036	0.033	0	46.4	45.2	70.5	139	135	0	31	30
2014	9	15	23	2	18	0.282	-0.049	0.784	0.033	0.03	0	46.9	45.6	69.7	140	136	0	31	30
2014	9	15	23	12	18	0.174	-0.072	0.784	0.036	0.033	0	46	44.7	71.8	137	134	0	30	30
2014	9	15	23	22	18	0.21	-0.016	0.784	0.036	0.033	0	46.4	45.2	70.5	139	135	0	31	30
2014	9	15	23	32	18	0.249	-0.033	0.784	0.039	0.036	0	48.2	46.9	69.2	143	139	0	31	30
2014	9	15	23	42	18	0.266	-0.043	0.784	0.036	0.033	0	47.3	46	70.1	141	136	0	31	29
2014	9	15	23	52	18	0.154	-0.072	0.784	0.033	0.03	0	47.7	45.6	70.1	141	136	0	30	30
2014	9	16	0	2	18	0.197	0.02	0.784	0.033	0.03	0	46.9	46	70.1	139	138	0	30	31
2014	9	16	0	12	18	0.285	0.016	0.784	0.033	0.03	0	47.3	46	70.5	141	137	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	0	22	18	0.19	0.056	0.784	0.039	0.036	0	47.3	46.4	70.1	141	139	0	31	31
2014	9	16	0	32	18	0.269	-0.043	0.784	0.033	0.03	0	45.6	44.7	70.5	137	134	0	31	30
2014	9	16	0	42	18	0.246	0	0.784	0.033	0.03	0	44.7	44.3	71.8	135	133	0	31	30
2014	9	16	0	52	18	0.246	-0.02	0.784	0.033	0.03	0	45.2	45.2	71.4	136	135	0	31	30
2014	9	16	1	2	18	0.22	-0.02	0.784	0.033	0.03	0	46.9	45.6	70.5	140	137	0	31	31
2014	9	16	1	12	18	0.249	0.052	0.781	0.033	0.03	0	46.4	46	71.4	139	137	0	31	30
2014	9	16	1	22	18	0.266	-0.059	0.781	0.039	0.036	0	48.6	47.7	68.4	144	141	0	31	30
2014	9	16	1	32	18	0.22	0.003	0.781	0.036	0.033	0	48.2	46.9	69.2	143	139	0	31	30
2014	9	16	1	42	18	0.197	-0.03	0.781	0.039	0.036	0	47.3	45.6	70.5	141	136	0	31	30
2014	9	16	1	52	18	0.18	0.016	0.784	0.033	0.03	0	44.7	43.9	72.2	135	132	0	31	30
2014	9	16	2	2	18	0.282	-0.049	0.781	0.039	0.036	0	46.4	45.6	71	138	136	0	30	30
2014	9	16	2	12	18	0.177	0.039	0.784	0.039	0.039	0	43.9	43.9	73.1	133	132	0	31	30
2014	9	16	2	22	18	0.203	-0.036	0.784	0.033	0.03	0	43.9	43	73.1	133	130	0	31	30
2014	9	16	2	32	18	0.184	0.036	0.781	0.039	0.036	0	44.7	44.3	71.8	135	133	0	31	30
2014	9	16	2	42	18	0.197	0.01	0.781	0.033	0.03	0	47.7	46.9	69.7	142	139	0	31	30
2014	9	16	2	52	18	0.21	-0.102	0.781	0.039	0.036	0	46	45.6	71.4	138	136	0	31	30
2014	9	16	3	2	18	0.22	-0.036	0.781	0.039	0.039	0	48.6	47.3	68.4	144	140	0	31	30
2014	9	16	3	12	18	0.21	-0.026	0.781	0.036	0.033	0	47.7	46.4	70.5	142	138	0	31	30
2014	9	16	3	22	18	0.256	-0.046	0.781	0.036	0.033	0	48.2	46.4	69.7	143	139	0	31	31
2014	9	16	3	32	18	0.187	-0.02	0.781	0.039	0.036	0	47.3	46.4	71	142	138	0	32	30
2014	9	16	3	42	18	0.262	-0.03	0.781	0.039	0.036	0	46	45.2	71	139	136	0	32	31
2014	9	16	3	52	18	0.171	-0.043	0.781	0.039	0.039	0	49	47.3	69.2	144	140	0	30	30
2014	9	16	4	2	18	0.226	0.016	0.781	0.039	0.039	0	46	44.7	70.5	138	134	0	31	30
2014	9	16	4	12	18	0.24	-0.023	0.781	0.049	0.046	0	45.2	43.4	73.1	136	132	0	31	31
2014	9	16	4	22	18	0.246	-0.03	0.781	0.033	0.03	0	43.9	43.9	73.5	133	132	0	31	30
2014	9	16	4	32	18	0.21	-0.043	0.781	0.03	0.03	0	43.9	43.9	73.5	133	132	0	31	30
2014	9	16	4	42	18	0.203	-0.036	0.781	0.036	0.033	0	45.2	44.3	71.4	136	133	0	31	30
2014	9	16	4	52	18	0.236	-0.043	0.781	0.036	0.033	0	45.6	44.7	72.2	137	135	0	31	31
2014	9	16	5	2	18	0.249	0.007	0.781	0.036	0.033	0	45.2	44.3	72.7	136	133	0	31	30
2014	9	16	5	12	18	0.23	-0.056	0.781	0.039	0.036	0	45.2	44.7	72.2	136	134	0	31	30
2014	9	16	5	22	18	0.197	-0.02	0.781	0.03	0.03	0	44.7	43.9	72.7	135	132	0	31	30
2014	9	16	5	32	18	0.272	0.161	0.778	0.039	0.039	0	52.5	50.7	67.1	152	148	0	30	30
2014	9	16	5	42	18	0.266	0.112	0.778	0.033	0.03	0	52	50.7	66.7	152	148	0	31	30
2014	9	16	5	52	18	0.299	0.161	0.778	0.039	0.036	0	49.9	49.9	67.9	147	146	0	31	30
2014	9	16	6	2	18	0.285	0.154	0.778	0.039	0.036	0	48.6	48.6	69.2	144	143	0	31	30
2014	9	16	6	12	18	0.279	0.056	0.778	0.039	0.036	0	47.7	47.3	70.1	142	140	0	31	30
2014	9	16	6	22	18	0.259	0.148	0.778	0.03	0.03	0	47.3	46.4	71.4	141	138	0	31	30
2014	9	16	6	32	18	0.226	0.079	0.778	0.046	0.043	0	47.7	46.9	70.5	142	139	0	31	30
2014	9	16	6	42	18	0.266	0.052	0.778	0.036	0.033	0	45.6	45.2	71.4	138	135	0	32	30
2014	9	16	6	52	18	0.197	0.066	0.778	0.036	0.033	0	44.7	44.7	72.7	135	134	0	31	30
2014	9	16	7	2	18	0.272	0.016	0.778	0.043	0.039	0	46	45.2	71	138	135	0	31	30
2014	9	16	7	12	18	0.246	-0.033	0.778	0.033	0.03	0	48.2	46.4	70.1	143	139	0	31	31
2014	9	16	7	22	18	0.262	-0.013	0.778	0.039	0.036	0	45.2	43.4	71.8	136	132	0	31	31
2014	9	16	7	32	18	0.272	0	0.778	0.039	0.036	0	44.7	43.4	72.7	135	131	0	31	30
2014	9	16	7	42	18	0.217	0.033	0.778	0.036	0.033	0	43.4	43.4	73.1	132	131	0	31	30
2014	9	16	7	52	18	0.21	0.01	0.778	0.033	0.03	0	44.3	43.4	73.5	134	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	8	2	18	0.262	0.033	0.778	0.033	0.03	0	43	42.6	74.4	131	130	0	31	31
2014	9	16	8	12	18	0.21	0.016	0.778	0.036	0.033	0	43	42.1	75.3	131	129	0	31	31
2014	9	16	8	22	18	0.207	0.039	0.778	0.033	0.03	0	42.1	42.6	74.4	130	129	0	32	30
2014	9	16	8	32	18	0.253	0.003	0.778	0.033	0.03	0	42.1	42.1	75.3	129	129	0	31	31
2014	9	16	8	42	18	0.213	0.01	0.778	0.033	0.03	0	41.7	41.3	75.3	128	127	0	31	31
2014	9	16	8	52	18	0.262	0.098	0.778	0.036	0.033	0	41.7	42.1	74.4	129	128	0	32	30
2014	9	16	9	2	18	0.226	0.03	0.778	0.039	0.036	0	42.6	41.3	74.4	130	127	0	31	31
2014	9	16	9	12	18	0.21	-0.052	0.778	0.033	0.03	0	42.1	42.6	74.8	129	129	0	31	30
2014	9	16	9	22	18	0.177	-0.016	0.778	0.033	0.03	0	42.1	41.7	75.7	129	128	0	31	31
2014	9	16	9	32	18	0.233	0.039	0.778	0.036	0.033	0	43	43.9	74.8	131	132	0	31	30
2014	9	16	9	42	18	0.276	0.059	0.778	0.036	0.033	0	43.9	46	74	133	137	0	31	30
2014	9	16	9	52	18	0.23	-0.03	0.778	0.03	0.026	0	44.7	45.6	75.3	136	137	0	32	31
2014	9	16	10	2	18	0.203	-0.036	0.778	0.033	0.03	0	45.6	47.3	74.8	137	140	0	31	30
2014	9	16	10	12	18	0.269	-0.049	0.778	0.033	0.03	0	46	46.9	75.3	138	139	0	31	30
2014	9	16	10	22	18	0.171	0.003	0.778	0.033	0.03	0	45.2	46.9	74.8	136	139	0	31	30
2014	9	16	10	32	18	0.285	-0.003	0.778	0.033	0.03	0	44.7	46	74.4	135	137	0	31	30
2014	9	16	10	42	18	0.21	-0.01	0.778	0.03	0.03	0	46.4	49	74.4	139	144	0	31	30
2014	9	16	10	52	18	0.213	0.075	0.778	0.033	0.03	0	45.6	47.7	74.8	137	141	0	31	30
2014	9	16	11	2	18	0.266	0	0.778	0.033	0.03	0	46.4	48.6	74	139	143	0	31	30
2014	9	16	11	12	18	0.269	-0.016	0.774	0.033	0.03	0	46.4	47.3	74.4	139	141	0	31	31
2014	9	16	11	22	18	0.249	0.049	0.774	0.033	0.03	0	46	48.2	74.8	138	142	0	31	30
2014	9	16	11	32	18	0.272	0.039	0.774	0.033	0.03	0	45.6	48.6	74.4	138	143	0	32	30
2014	9	16	11	42	18	0.21	0.052	0.774	0.043	0.043	0	46.9	48.2	74.4	139	142	0	30	30
2014	9	16	11	52	18	0.243	0.043	0.774	0.039	0.039	0	46	47.3	74	137	140	0	30	30
2014	9	16	12	2	18	0.272	0.023	0.774	0.036	0.033	0	46.4	49	74.4	139	144	0	31	30
2014	9	16	12	12	18	0.226	0.026	0.774	0.033	0.03	0	46.9	48.2	74.4	140	142	0	31	30
2014	9	16	12	22	18	0.315	-0.003	0.774	0.033	0.03	0	47.3	48.2	74.8	141	142	0	31	30
2014	9	16	12	32	18	0.262	-0.023	0.774	0.03	0.03	0	47.3	49	74.4	140	144	0	30	30
2014	9	16	12	42	18	0.2	-0.013	0.774	0.03	0.03	0	47.3	49	74	141	144	0	31	30
2014	9	16	12	52	18	0.341	0.03	0.774	0.033	0.03	0	46	48.6	74.4	138	143	0	31	30
2014	9	16	13	2	18	0.203	0	0.774	0.033	0.03	0	46.4	48.6	74.4	139	143	0	31	30
2014	9	16	13	12	18	0.21	-0.039	0.774	0.039	0.036	0	46.9	48.6	75.3	140	143	0	31	30
2014	9	16	13	22	18	0.262	0.013	0.774	0.03	0.03	0	46.9	49	76.1	140	144	0	31	30
2014	9	16	13	32	18	0.285	0.03	0.774	0.033	0.03	0	46.9	48.6	74	140	143	0	31	30
2014	9	16	13	42	18	0.292	0.016	0.774	0.033	0.03	0	47.3	49	74.8	141	144	0	31	30
2014	9	16	13	52	18	0.279	0.033	0.774	0.033	0.03	0	47.3	48.6	74.8	140	143	0	30	30
2014	9	16	14	2	18	0.203	0.049	0.774	0.033	0.03	0	46	47.7	73.5	138	140	0	31	29
2014	9	16	14	12	18	0.19	0	0.774	0.036	0.033	0	47.3	47.7	72.7	140	141	0	30	30
2014	9	16	14	22	18	0.22	0.072	0.774	0.033	0.03	0	46	49	74.4	138	143	0	31	29
2014	9	16	14	32	18	0.23	-0.013	0.771	0.039	0.036	0	44.7	46	74.4	134	137	0	30	30
2014	9	16	14	42	18	0.249	0.026	0.774	0.039	0.036	0	45.6	46.9	73.1	136	139	0	30	30
2014	9	16	14	52	18	0.292	0.013	0.771	0.033	0.03	0	45.6	48.2	75.3	137	142	0	31	30
2014	9	16	15	2	18	0.269	0.023	0.771	0.033	0.03	0	44.7	47.3	73.5	135	139	0	31	29
2014	9	16	15	12	18	0.249	0.016	0.771	0.033	0.03	0	46	48.2	73.1	137	141	0	30	29
2014	9	16	15	22	18	0.223	0.039	0.771	0.03	0.026	0	47.3	49.5	72.2	140	145	0	30	30
2014	9	16	15	32	18	0.351	0.075	0.771	0.033	0.03	0	47.3	49	72.7	141	143	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	15	42	18	0.331	0.072	0.771	0.033	0.03	0	46.9	47.3	71	139	140	0	30	30
2014	9	16	15	52	18	0.246	0.062	0.771	0.033	0.03	0	46.4	47.7	72.2	138	140	0	30	29
2014	9	16	16	2	18	0.24	0.052	0.768	0.039	0.036	0	45.2	47.3	71.8	136	139	0	31	29
2014	9	16	16	12	18	0.259	0	0.771	0.033	0.03	0	44.3	46.4	71.8	134	137	0	31	29
2014	9	16	16	22	18	0.246	0	0.771	0.033	0.03	0	46.4	47.7	71.8	138	141	0	30	30
2014	9	16	16	32	18	0.262	0.03	0.768	0.033	0.03	0	46	48.2	71.8	138	141	0	31	29
2014	9	16	16	42	18	0.249	-0.02	0.768	0.033	0.03	0	45.2	45.6	71.8	135	136	0	30	30
2014	9	16	16	52	18	0.223	-0.02	0.768	0.033	0.03	0	42.6	42.1	73.1	129	128	0	30	30
2014	9	16	17	2	18	0.302	0.003	0.768	0.033	0.03	0	40.4	40.4	74	124	124	0	30	30
2014	9	16	17	12	18	0.187	0.056	0.768	0.033	0.03	0	41.7	40.9	72.7	127	125	0	30	30
2014	9	16	17	22	18	0.167	-0.007	0.768	0.039	0.039	0	40.4	40.9	72.7	125	124	0	31	29
2014	9	16	17	32	18	0.207	0.102	0.768	0.033	0.03	0	41.3	40.9	72.7	126	124	0	30	29
2014	9	16	17	42	18	0.246	0.075	0.768	0.036	0.033	0	40.9	40.9	72.7	125	124	0	30	29
2014	9	16	17	52	18	0.22	0.013	0.768	0.039	0.036	0	40.4	39.6	72.7	125	122	0	31	30
2014	9	16	18	2	18	0.157	0.075	0.768	0.033	0.03	0	40	39.1	73.5	123	120	0	30	29
2014	9	16	18	12	18	0.223	-0.013	0.768	0.039	0.036	0	40.4	39.6	72.2	125	122	0	31	30
2014	9	16	18	22	18	0.167	0.01	0.768	0.039	0.039	0	40.4	39.1	74	124	121	0	30	30
2014	9	16	18	32	18	0.246	0.036	0.768	0.033	0.03	0	40.4	39.6	73.5	124	122	0	30	30
2014	9	16	18	42	18	0.233	-0.043	0.768	0.039	0.036	0	40.9	40.4	73.5	125	123	0	30	29
2014	9	16	18	52	18	0.18	-0.007	0.768	0.033	0.03	0	40	40.4	73.1	123	123	0	30	29
2014	9	16	19	2	18	0.24	0	0.768	0.039	0.036	0	41.7	40.4	72.7	127	123	0	30	29
2014	9	16	19	12	18	0.253	0.016	0.768	0.036	0.033	0	41.3	41.3	73.5	126	125	0	30	29
2014	9	16	19	22	18	0.207	-0.095	0.768	0.036	0.033	0	42.6	41.7	73.1	129	127	0	30	30
2014	9	16	19	32	18	0.21	0	0.768	0.033	0.03	0	43.4	43.9	72.7	132	131	0	31	29
2014	9	16	19	42	18	0.21	0.059	0.768	0.036	0.033	0	42.6	42.6	72.7	129	128	0	30	29
2014	9	16	19	52	18	0.21	0.003	0.768	0.039	0.036	0	44.3	42.6	73.1	133	129	0	30	30
2014	9	16	20	2	18	0.187	-0.049	0.768	0.039	0.039	0	44.3	43	72.7	132	130	0	29	30
2014	9	16	20	12	18	0.223	0.016	0.771	0.039	0.036	0	45.2	44.7	72.7	135	133	0	30	29
2014	9	16	20	22	18	0.203	-0.072	0.771	0.036	0.033	0	43	42.1	73.1	131	128	0	31	30
2014	9	16	20	32	18	0.269	-0.092	0.771	0.033	0.03	0	44.3	43.4	73.1	133	130	0	30	29
2014	9	16	20	42	18	0.164	0.072	0.771	0.036	0.033	0	44.7	43.9	73.1	134	131	0	30	29
2014	9	16	20	52	18	0.233	0.049	0.771	0.033	0.03	0	46.4	45.6	71.4	138	135	0	30	29
2014	9	16	21	2	18	0.213	0.023	0.771	0.033	0.03	0	46.4	45.6	71.4	139	136	0	31	30
2014	9	16	21	12	18	0.246	-0.023	0.771	0.039	0.036	0	46.9	46.4	70.5	140	137	0	31	29
2014	9	16	21	22	18	0.226	0.003	0.771	0.033	0.03	0	47.7	46.4	71	141	137	0	30	29
2014	9	16	21	32	18	0.285	-0.069	0.771	0.033	0.03	0	45.6	45.6	72.7	137	136	0	31	30
2014	9	16	21	42	18	0.213	-0.092	0.771	0.033	0.03	0	45.6	44.7	72.2	136	134	0	30	30
2014	9	16	21	52	18	0.22	0.049	0.771	0.033	0.03	0	45.2	44.3	73.1	135	133	0	30	30
2014	9	16	22	2	18	0.184	-0.049	0.771	0.033	0.03	0	44.7	44.3	73.1	134	132	0	30	29
2014	9	16	22	12	18	0.217	-0.003	0.771	0.039	0.036	0	44.7	43.9	73.5	135	132	0	31	30
2014	9	16	22	22	18	0.24	0.056	0.771	0.036	0.033	0	44.3	44.7	74	134	133	0	31	29
2014	9	16	22	32	18	0.197	0.056	0.771	0.033	0.03	0	44.3	44.3	74.4	133	132	0	30	29
2014	9	16	22	42	18	0.23	-0.013	0.771	0.036	0.033	0	45.2	44.3	73.5	135	133	0	30	30
2014	9	16	22	52	18	0.22	-0.016	0.771	0.033	0.03	0	44.3	44.7	73.5	134	133	0	31	29
2014	9	16	23	2	18	0.236	0	0.771	0.033	0.03	0	44.7	43.9	74	134	132	0	30	30
2014	9	16	23	12	18	0.256	-0.075	0.771	0.036	0.033	0	43.4	43	74.8	132	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	23	22	18	0.18	-0.039	0.771	0.036	0.033	0	43.4	43	74.8	132	130	0	31	30
2014	9	16	23	32	18	0.223	-0.03	0.771	0.036	0.033	0	44.3	43.4	74.8	133	131	0	30	30
2014	9	16	23	42	18	0.249	-0.066	0.771	0.036	0.033	0	44.3	44.3	74.4	133	132	0	30	29
2014	9	16	23	52	18	0.236	-0.066	0.771	0.036	0.033	0	43.9	43.4	74.4	133	131	0	31	30
2014	9	17	0	2	18	0.285	-0.036	0.771	0.036	0.033	0	43.9	44.3	74.8	133	133	0	31	30
2014	9	17	0	12	18	0.223	0.007	0.771	0.036	0.033	0	43.9	44.7	74.8	133	133	0	31	29
2014	9	17	0	22	18	0.197	-0.072	0.771	0.033	0.03	0	44.3	44.3	75.3	133	133	0	30	30
2014	9	17	0	32	18	0.184	-0.046	0.771	0.036	0.033	0	44.7	44.3	75.3	134	133	0	30	30
2014	9	17	0	42	18	0.21	0.016	0.771	0.03	0.03	0	45.6	44.7	74.8	136	134	0	30	30
2014	9	17	0	52	18	0.272	-0.052	0.771	0.036	0.033	0	43.9	43.9	74.4	133	132	0	31	30
2014	9	17	1	2	18	0.233	-0.036	0.771	0.039	0.036	0	42.6	42.6	74.8	130	129	0	31	30
2014	9	17	1	12	18	0.203	-0.033	0.771	0.033	0.03	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	17	1	22	18	0.194	-0.043	0.774	0.039	0.036	0	43.4	43.9	75.3	132	132	0	31	30
2014	9	17	1	32	18	0.217	0.016	0.771	0.033	0.03	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	17	1	42	18	0.289	-0.049	0.771	0.046	0.043	0	43.9	43	76.1	133	131	0	31	31
2014	9	17	1	52	18	0.22	-0.049	0.774	0.043	0.043	0	43.9	43.4	76.1	132	131	0	30	30
2014	9	17	2	2	18	0.233	-0.003	0.774	0.036	0.033	0	43.4	43.9	75.7	132	132	0	31	30
2014	9	17	2	12	18	0.207	-0.023	0.774	0.033	0.03	0	43.4	43.9	76.1	132	132	0	31	30
2014	9	17	2	22	18	0.197	0.016	0.774	0.036	0.033	0	43.9	43.4	76.1	132	131	0	30	30
2014	9	17	2	32	18	0.213	-0.023	0.774	0.036	0.033	0	44.7	43.9	75.3	134	132	0	30	30
2014	9	17	2	42	18	0.22	0.033	0.774	0.033	0.03	0	44.3	43.9	75.3	133	132	0	30	30
2014	9	17	2	52	18	0.174	-0.046	0.774	0.033	0.03	0	44.3	43.9	75.7	134	132	0	31	30
2014	9	17	3	2	18	0.269	0.003	0.774	0.036	0.033	0	45.2	43.4	75.7	135	131	0	30	30
2014	9	17	3	12	18	0.164	-0.016	0.774	0.036	0.033	0	43	43.9	76.5	132	132	0	32	30
2014	9	17	3	22	18	0.187	-0.026	0.774	0.033	0.03	0	43.9	43.4	76.5	134	132	0	32	31
2014	9	17	3	32	18	0.269	0.007	0.774	0.033	0.03	0	43	43.4	75.7	132	132	0	32	31
2014	9	17	3	42	18	0.23	-0.069	0.774	0.033	0.03	0	43.9	43	76.1	133	130	0	31	30
2014	9	17	3	52	18	0.18	-0.069	0.774	0.033	0.03	0	44.3	44.7	75.7	134	134	0	31	30
2014	9	17	4	2	18	0.266	0.033	0.774	0.043	0.039	0	42.6	42.6	76.1	130	130	0	31	31
2014	9	17	4	12	18	0.266	0	0.774	0.033	0.03	0	43.9	43.9	74.8	133	132	0	31	30
2014	9	17	4	22	18	0.272	-0.023	0.774	0.03	0.03	0	43.4	43.4	75.7	132	132	0	31	31
2014	9	17	4	32	18	0.154	-0.026	0.774	0.033	0.03	0	43.9	43.4	75.7	133	131	0	31	30
2014	9	17	4	42	18	0.305	-0.052	0.774	0.033	0.03	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	17	4	52	18	0.249	0.003	0.774	0.036	0.033	0	43.9	43.4	75.7	133	131	0	31	30
2014	9	17	5	2	18	0.236	-0.016	0.774	0.033	0.03	0	44.7	43.4	74.8	134	131	0	30	30
2014	9	17	5	12	18	0.236	-0.052	0.774	0.043	0.043	0	43.9	43.4	75.3	133	131	0	31	30
2014	9	17	5	22	18	0.24	0.023	0.774	0.036	0.033	0	44.3	43	76.1	134	131	0	31	31
2014	9	17	5	32	18	0.282	0.01	0.774	0.039	0.036	0	43.9	43.4	74.8	133	131	0	31	30
2014	9	17	5	42	18	0.243	0.003	0.774	0.036	0.033	0	44.3	43.4	75.3	134	131	0	31	30
2014	9	17	5	52	18	0.217	0	0.774	0.036	0.033	0	43.9	43.9	75.7	133	131	0	31	29
2014	9	17	6	2	18	0.187	-0.003	0.774	0.036	0.033	0	43.4	43	75.7	132	131	0	31	31
2014	9	17	6	12	18	0.213	-0.02	0.774	0.046	0.043	0	43.9	43.9	75.3	133	132	0	31	30
2014	9	17	6	22	18	0.24	-0.039	0.774	0.033	0.03	0	43.9	42.6	75.7	133	129	0	31	30
2014	9	17	6	32	18	0.213	-0.059	0.774	0.033	0.03	0	43	42.1	75.7	131	128	0	31	30
2014	9	17	6	42	18	0.207	-0.046	0.778	0.033	0.03	0	41.3	42.1	76.5	127	128	0	31	30
2014	9	17	6	52	18	0.213	-0.039	0.778	0.033	0.03	0	42.1	41.3	77	129	127	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	7	2	18	0.262	-0.062	0.774	0.036	0.033	0	41.3	41.7	77	127	127	0	31	30
2014	9	17	7	12	18	0.226	-0.059	0.778	0.036	0.033	0	40.9	40.9	77	126	125	0	31	30
2014	9	17	7	22	18	0.233	-0.039	0.778	0.033	0.03	0	40.9	40.4	77.4	125	124	0	30	30
2014	9	17	7	32	18	0.24	-0.02	0.778	0.043	0.043	0	41.3	41.3	76.5	127	126	0	31	30
2014	9	17	7	42	18	0.174	0.03	0.778	0.039	0.036	0	41.7	40.9	77.4	128	125	0	31	30
2014	9	17	7	52	18	0.322	-0.01	0.778	0.039	0.036	0	40.9	40.9	77.4	126	125	0	31	30
2014	9	17	8	2	18	0.164	0.003	0.774	0.033	0.03	0	40.4	40.4	77.4	125	124	0	31	30
2014	9	17	8	12	18	0.305	0.02	0.778	0.033	0.03	0	40.9	40	77.4	126	124	0	31	31
2014	9	17	8	22	18	0.184	-0.007	0.778	0.036	0.033	0	40.4	40.9	76.5	125	126	0	31	31
2014	9	17	8	32	18	0.2	0	0.778	0.039	0.036	0	41.3	40.9	77	127	125	0	31	30
2014	9	17	8	42	18	0.233	-0.023	0.778	0.036	0.033	0	41.3	40.9	77.4	127	125	0	31	30
2014	9	17	8	52	18	0.213	0.016	0.778	0.033	0.03	0	41.7	41.3	76.5	127	126	0	30	30
2014	9	17	9	2	18	0.197	-0.013	0.778	0.036	0.033	0	41.3	41.7	76.5	127	127	0	31	30
2014	9	17	9	12	18	0.24	-0.023	0.778	0.036	0.033	0	40.9	41.3	77.4	126	126	0	31	30
2014	9	17	9	22	18	0.18	-0.098	0.778	0.033	0.03	0	41.3	41.3	76.5	127	126	0	31	30
2014	9	17	9	32	18	0.144	0	0.778	0.033	0.03	0	42.6	42.1	74.8	130	128	0	31	30
2014	9	17	9	42	18	0.217	-0.02	0.778	0.039	0.036	0	43	42.6	75.3	131	130	0	31	31
2014	9	17	9	52	18	0.246	0	0.778	0.039	0.036	0	42.6	43.9	75.7	130	132	0	31	30
2014	9	17	10	2	18	0.259	0.003	0.778	0.033	0.03	0	43.9	44.3	75.3	133	133	0	31	30
2014	9	17	10	12	18	0.223	-0.036	0.778	0.033	0.03	0	43.9	45.2	75.7	133	135	0	31	30
2014	9	17	10	22	18	0.194	0.02	0.778	0.033	0.033	0	44.3	45.6	74.8	134	136	0	31	30
2014	9	17	10	32	18	0.259	0.059	0.778	0.033	0.03	0	44.7	46.4	74.8	135	138	0	31	30
2014	9	17	10	42	18	0.236	-0.016	0.778	0.033	0.03	0	44.3	46	74	134	137	0	31	30
2014	9	17	10	52	18	0.177	0	0.778	0.033	0.03	0	45.2	46.4	75.3	136	138	0	31	30
2014	9	17	11	2	18	0.213	0.036	0.778	0.033	0.03	0	45.2	46.9	74.8	136	139	0	31	30
2014	9	17	11	12	18	0.249	0.059	0.778	0.033	0.03	0	45.2	47.3	74.8	136	140	0	31	30
2014	9	17	11	22	18	0.157	-0.023	0.778	0.033	0.03	0	46	46.9	74.8	138	139	0	31	30
2014	9	17	11	32	18	0.2	-0.013	0.778	0.036	0.033	0	45.6	47.7	73.1	137	141	0	31	30
2014	9	17	11	42	18	0.259	0.066	0.778	0.036	0.033	0	46.9	48.2	74	139	142	0	30	30
2014	9	17	11	52	18	0.256	0.075	0.778	0.033	0.03	0	46.4	47.3	75.3	138	140	0	30	30
2014	9	17	12	2	18	0.243	0.01	0.778	0.036	0.033	0	46.4	48.6	74	138	143	0	30	30
2014	9	17	12	12	18	0.233	-0.003	0.778	0.033	0.03	0	45.6	47.7	74.8	137	141	0	31	30
2014	9	17	12	22	18	0.161	-0.003	0.778	0.036	0.033	0	46	48.6	74	138	143	0	31	30
2014	9	17	12	32	18	0.266	-0.036	0.778	0.033	0.03	0	46.4	47.3	74.8	139	140	0	31	30
2014	9	17	12	42	18	0.236	0.007	0.778	0.033	0.03	0	46	47.7	74.8	137	141	0	30	30
2014	9	17	12	52	18	0.276	0.069	0.778	0.033	0.03	0	46.4	48.2	74.4	139	142	0	31	30
2014	9	17	13	2	18	0.253	0.023	0.778	0.033	0.03	0	46.4	47.7	74.4	139	141	0	31	30
2014	9	17	13	12	18	0.236	0.059	0.778	0.036	0.033	0	46	47.7	74.8	138	141	0	31	30
2014	9	17	13	22	18	0.253	0.052	0.778	0.036	0.033	0	46	47.7	75.7	138	141	0	31	30
2014	9	17	13	32	18	0.164	0	0.778	0.033	0.03	0	46.4	47.3	74	139	140	0	31	30
2014	9	17	13	42	18	0.217	-0.016	0.778	0.033	0.03	0	45.6	47.3	74	136	140	0	30	30
2014	9	17	13	52	18	0.2	0.02	0.778	0.033	0.03	0	46	47.3	74.4	138	140	0	31	30
2014	9	17	14	2	18	0.318	0.016	0.778	0.033	0.03	0	46	47.7	72.7	137	141	0	30	30
2014	9	17	14	12	18	0.256	0.049	0.774	0.033	0.03	0	47.3	47.7	73.5	140	141	0	30	30
2014	9	17	14	22	18	0.292	0	0.774	0.033	0.03	0	46	47.3	74.8	138	140	0	31	30
2014	9	17	14	32	18	0.236	-0.013	0.774	0.033	0.03	0	46.9	47.7	74	139	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	14	42	18	0.259	0.007	0.774	0.033	0.03	0	44.7	46.4	74	135	138	0	31	30
2014	9	17	14	52	18	0.223	0.013	0.774	0.033	0.03	0	46.9	48.2	73.1	139	142	0	30	30
2014	9	17	15	2	18	0.295	0.059	0.774	0.036	0.033	0	47.7	48.6	71.4	141	143	0	30	30
2014	9	17	15	12	18	0.243	0.03	0.774	0.036	0.033	0	46.9	48.2	72.2	139	142	0	30	30
2014	9	17	15	22	18	0.269	0.069	0.774	0.036	0.033	0	47.7	48.2	72.7	141	142	0	30	30
2014	9	17	15	32	18	0.266	0.049	0.774	0.033	0.03	0	49	49.9	69.7	145	145	0	31	29
2014	9	17	15	42	18	0.249	0.02	0.771	0.036	0.033	0	48.6	49.5	70.1	143	144	0	30	29
2014	9	17	15	52	18	0.226	0.069	0.771	0.033	0.03	0	48.6	48.6	69.2	143	143	0	30	30
2014	9	17	16	2	18	0.23	-0.039	0.771	0.033	0.03	0	47.7	48.6	71	141	143	0	30	30
2014	9	17	16	12	18	0.259	0.069	0.771	0.036	0.033	0	48.6	48.2	69.7	143	142	0	30	30
2014	9	17	16	22	18	0.259	0.036	0.771	0.033	0.03	0	46	47.3	71.4	138	139	0	31	29
2014	9	17	16	32	18	0.312	0.052	0.771	0.033	0.03	0	47.3	47.7	71.8	140	141	0	30	30
2014	9	17	16	42	18	0.246	0.03	0.771	0.036	0.033	0	46.4	46.4	71.8	138	138	0	30	30
2014	9	17	16	52	18	0.315	0.036	0.771	0.036	0.033	0	45.6	46.4	71.4	136	137	0	30	29
2014	9	17	17	2	18	0.213	0.069	0.771	0.036	0.033	0	45.6	45.6	71.4	136	136	0	30	30
2014	9	17	17	12	18	0.253	-0.02	0.771	0.033	0.03	0	45.6	46.4	71.8	136	137	0	30	29
2014	9	17	17	22	18	0.253	0	0.771	0.033	0.03	0	43.9	44.7	71.8	132	133	0	30	29
2014	9	17	17	32	18	0.249	-0.043	0.771	0.033	0.03	0	43.4	42.6	72.7	131	128	0	30	29
2014	9	17	17	42	18	0.249	0.052	0.771	0.033	0.03	0	42.6	42.1	73.1	129	127	0	30	29
2014	9	17	17	52	18	0.223	0.049	0.771	0.036	0.033	0	42.1	40.9	73.5	128	125	0	30	30
2014	9	17	18	2	18	0.279	0.112	0.771	0.039	0.039	0	41.7	40.4	72.2	127	124	0	30	30
2014	9	17	18	12	18	0.236	0.052	0.771	0.033	0.03	0	41.3	41.3	73.1	127	125	0	31	29
2014	9	17	18	22	18	0.308	0.036	0.771	0.036	0.033	0	41.7	40.4	73.1	127	123	0	30	29
2014	9	17	18	32	18	0.243	0.052	0.771	0.036	0.033	0	41.3	40.4	74	126	124	0	30	30
2014	9	17	18	42	18	0.22	0.016	0.771	0.033	0.03	0	41.7	42.1	73.5	128	127	0	31	29
2014	9	17	18	52	18	0.187	0.082	0.771	0.036	0.033	0	42.1	40.9	73.5	128	125	0	30	30
2014	9	17	19	2	18	0.249	0.033	0.771	0.033	0.03	0	43	41.3	73.1	130	126	0	30	30
2014	9	17	19	12	18	0.23	0.013	0.771	0.036	0.033	0	42.6	42.6	73.1	129	128	0	30	29
2014	9	17	19	22	18	0.194	0.043	0.771	0.036	0.033	0	42.1	41.7	73.5	128	126	0	30	29
2014	9	17	19	32	18	0.22	-0.02	0.771	0.033	0.03	0	44.3	43.9	73.1	133	131	0	30	29
2014	9	17	19	42	18	0.187	-0.01	0.771	0.036	0.033	0	42.6	42.1	72.7	130	127	0	31	29
2014	9	17	19	52	18	0.223	0	0.771	0.036	0.033	0	43.9	43.4	73.5	133	131	0	31	30
2014	9	17	20	2	18	0.243	0	0.771	0.039	0.036	0	44.7	42.6	72.7	134	129	0	30	30
2014	9	17	20	12	18	0.151	0.007	0.771	0.039	0.039	0	42.6	42.1	72.7	129	127	0	30	29
2014	9	17	20	22	18	0.256	0.003	0.771	0.039	0.036	0	44.3	43.4	73.5	133	131	0	30	30
2014	9	17	20	32	18	0.318	-0.01	0.771	0.036	0.033	0	44.7	44.7	73.5	134	133	0	30	29
2014	9	17	20	42	18	0.22	-0.02	0.771	0.039	0.036	0	43.4	43.9	73.1	132	131	0	31	29
2014	9	17	20	52	18	0.233	-0.026	0.771	0.043	0.039	0	49	47.3	68.8	144	140	0	30	30
2014	9	17	21	2	18	0.194	-0.026	0.771	0.033	0.033	0	47.7	46.4	70.5	142	137	0	31	29
2014	9	17	21	12	18	0.148	-0.056	0.771	0.033	0.03	0	48.6	47.3	69.2	143	140	0	30	30
2014	9	17	21	22	18	0.22	-0.072	0.771	0.043	0.039	0	46.4	46	72.2	139	136	0	31	29
2014	9	17	21	32	18	0.256	-0.016	0.771	0.03	0.026	0	45.2	44.3	73.5	135	132	0	30	29
2014	9	17	21	42	18	0.157	-0.052	0.771	0.033	0.03	0	47.7	46	71.4	141	136	0	30	29
2014	9	17	21	52	18	0.249	-0.02	0.771	0.036	0.033	0	48.6	47.7	70.1	144	140	0	31	29
2014	9	17	22	2	18	0.217	-0.089	0.771	0.033	0.03	0	49	47.3	70.1	144	140	0	30	30
2014	9	17	22	12	18	0.2	0	0.771	0.036	0.033	0	46.9	46.4	71	140	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	22	22	18	0.22	-0.043	0.771	0.046	0.046	0	48.2	46.4	71.8	142	137	0	30	29
2014	9	17	22	32	18	0.259	-0.026	0.771	0.033	0.03	0	47.7	46.4	71.4	141	138	0	30	30
2014	9	17	22	42	18	0.154	-0.02	0.771	0.036	0.033	0	47.7	46.9	72.2	141	138	0	30	29
2014	9	17	22	52	18	0.285	-0.023	0.771	0.033	0.033	0	49.9	49	69.2	146	143	0	30	29
2014	9	17	23	2	18	0.203	0.036	0.771	0.036	0.033	0	48.2	46.9	70.5	143	139	0	31	30
2014	9	17	23	12	18	0.194	-0.112	0.771	0.036	0.033	0	45.2	44.3	73.1	135	133	0	30	30
2014	9	17	23	22	18	0.233	0.016	0.774	0.033	0.03	0	45.2	43.9	74.4	135	132	0	30	30
2014	9	17	23	32	18	0.24	0.016	0.771	0.033	0.03	0	44.7	43.4	74.4	134	131	0	30	30
2014	9	17	23	42	18	0.22	-0.01	0.771	0.039	0.036	0	45.2	44.3	74	136	133	0	31	30
2014	9	17	23	52	18	0.243	0.003	0.774	0.033	0.033	0	44.7	43.4	74.4	134	131	0	30	30
2014	9	18	0	2	18	0.184	-0.013	0.774	0.043	0.039	0	44.3	43.4	74.8	134	131	0	31	30
2014	9	18	0	12	18	0.2	0.049	0.771	0.036	0.033	0	46.4	46	73.5	139	137	0	31	30
2014	9	18	0	22	18	0.207	-0.007	0.771	0.036	0.033	0	47.7	46.4	72.2	142	138	0	31	30
2014	9	18	0	32	18	0.24	0.016	0.771	0.039	0.039	0	46	46	73.1	138	136	0	31	29
2014	9	18	0	42	18	0.207	-0.046	0.774	0.033	0.03	0	45.6	44.7	74	136	134	0	30	30
2014	9	18	0	52	18	0.246	-0.069	0.774	0.033	0.03	0	46	45.2	74	137	135	0	30	30
2014	9	18	1	2	18	0.18	-0.02	0.774	0.033	0.03	0	44.7	44.7	75.3	135	133	0	31	29
2014	9	18	1	12	18	0.197	-0.02	0.771	0.036	0.033	0	47.7	46.9	71.8	142	139	0	31	30
2014	9	18	1	22	18	0.197	-0.066	0.771	0.036	0.033	0	46	45.6	73.1	138	136	0	31	30
2014	9	18	1	32	18	0.256	0.039	0.771	0.039	0.036	0	47.3	46.4	72.7	141	137	0	31	29
2014	9	18	1	42	18	0.2	-0.052	0.771	0.039	0.039	0	49	47.3	71.4	145	140	0	31	30
2014	9	18	1	52	18	0.217	-0.02	0.771	0.033	0.03	0	47.7	46.9	73.1	142	139	0	31	30
2014	9	18	2	2	18	0.285	-0.02	0.771	0.036	0.033	0	46.9	46	73.5	140	137	0	31	30
2014	9	18	2	12	18	0.256	-0.03	0.771	0.036	0.033	0	46.4	45.6	74	138	135	0	30	29
2014	9	18	2	22	18	0.19	0.007	0.771	0.036	0.033	0	45.6	45.6	74.4	137	136	0	31	30
2014	9	18	2	32	18	0.233	0.016	0.771	0.033	0.03	0	45.2	44.3	74.4	136	133	0	31	30
2014	9	18	2	42	18	0.272	0	0.771	0.039	0.039	0	49.5	48.6	71.4	145	142	0	30	29
2014	9	18	2	52	18	0.236	-0.046	0.771	0.033	0.03	0	52.5	50.7	67.9	152	149	0	30	31
2014	9	18	3	2	18	0.174	0	0.771	0.043	0.039	0	51.6	49.9	69.7	150	146	0	30	30
2014	9	18	3	12	18	0.203	0.01	0.771	0.036	0.033	0	49.5	49	71	146	144	0	31	30
2014	9	18	3	22	18	0.253	-0.023	0.771	0.033	0.03	0	49	47.7	72.2	145	141	0	31	30
2014	9	18	3	32	18	0.279	-0.052	0.771	0.036	0.033	0	46.9	47.3	72.7	140	140	0	31	30
2014	9	18	3	42	18	0.157	0.052	0.771	0.039	0.039	0	48.2	47.7	70.5	142	141	0	30	30
2014	9	18	3	52	18	0.18	0	0.771	0.036	0.033	0	46.4	46	73.1	139	137	0	31	30
2014	9	18	4	2	18	0.184	-0.007	0.771	0.036	0.033	0	46.9	46	73.5	140	138	0	31	31
2014	9	18	4	12	18	0.253	0.01	0.771	0.033	0.03	0	51.6	50.3	68.8	151	147	0	31	30
2014	9	18	4	22	18	0.161	0.052	0.771	0.033	0.03	0	49.9	49	70.1	147	144	0	31	30
2014	9	18	4	32	18	0.253	0.023	0.771	0.033	0.03	0	51.6	50.3	69.7	151	147	0	31	30
2014	9	18	4	42	18	0.213	0.007	0.771	0.039	0.039	0	51.2	49.9	69.7	150	147	0	31	31
2014	9	18	4	52	18	0.302	0.03	0.771	0.033	0.03	0	50.3	49.5	69.7	147	145	0	30	30
2014	9	18	5	2	18	0.282	0.059	0.771	0.036	0.033	0	49	48.2	71	145	142	0	31	30
2014	9	18	5	12	18	0.19	0.046	0.771	0.036	0.033	0	49	46.9	71.8	144	140	0	30	31
2014	9	18	5	22	18	0.226	-0.026	0.771	0.033	0.03	0	46.9	46.9	72.7	140	139	0	31	30
2014	9	18	5	32	18	0.144	0.016	0.771	0.039	0.039	0	46.4	45.6	73.1	138	137	0	30	31
2014	9	18	5	42	18	0.262	0.085	0.771	0.043	0.039	0	46.4	46	72.7	140	137	0	32	30
2014	9	18	5	52	18	0.22	0.003	0.771	0.039	0.039	0	46	46	73.1	138	137	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	6	2	18	0.226	0.01	0.771	0.036	0.033	0	46	45.2	73.5	138	135	0	31	30
2014	9	18	6	12	18	0.279	-0.023	0.771	0.033	0.03	0	46	45.6	74	138	136	0	31	30
2014	9	18	6	22	18	0.141	0	0.771	0.033	0.03	0	45.2	44.3	74.4	136	133	0	31	30
2014	9	18	6	32	18	0.262	-0.046	0.771	0.036	0.033	0	44.3	44.3	75.3	134	133	0	31	30
2014	9	18	6	42	18	0.184	-0.013	0.771	0.036	0.033	0	43.4	43	74.4	132	130	0	31	30
2014	9	18	6	52	18	0.256	-0.079	0.771	0.036	0.033	0	43	42.6	74.8	131	129	0	31	30
2014	9	18	7	2	18	0.246	-0.059	0.771	0.043	0.039	0	43.4	43	74.8	132	130	0	31	30
2014	9	18	7	12	18	0.2	0.03	0.771	0.036	0.033	0	43	42.6	75.3	131	129	0	31	30
2014	9	18	7	22	18	0.19	0	0.771	0.036	0.033	0	42.1	42.1	76.1	130	128	0	32	30
2014	9	18	7	32	18	0.22	0.01	0.771	0.033	0.03	0	42.1	42.1	75.7	129	128	0	31	30
2014	9	18	7	42	18	0.246	0	0.771	0.033	0.03	0	42.1	42.6	76.1	129	129	0	31	30
2014	9	18	7	52	18	0.21	0	0.771	0.033	0.03	0	43	42.1	75.7	131	128	0	31	30
2014	9	18	8	2	18	0.207	-0.03	0.771	0.03	0.03	0	43.4	42.6	75.7	132	130	0	31	31
2014	9	18	8	12	18	0.187	0.059	0.768	0.036	0.033	0	41.7	43	76.1	128	130	0	31	30
2014	9	18	8	22	18	0.164	0.016	0.768	0.033	0.03	0	41.3	41.3	76.5	127	127	0	31	31
2014	9	18	8	32	18	0.187	-0.016	0.768	0.033	0.03	0	42.1	43	75.3	129	130	0	31	30
2014	9	18	8	42	18	0.164	-0.003	0.768	0.036	0.033	0	41.7	41.7	76.1	128	127	0	31	30
2014	9	18	8	52	18	0.213	-0.033	0.768	0.039	0.036	0	41.7	41.7	74.8	128	127	0	31	30
2014	9	18	9	2	18	0.282	-0.066	0.768	0.03	0.03	0	42.1	42.1	75.7	129	128	0	31	30
2014	9	18	9	12	18	0.21	-0.052	0.768	0.036	0.033	0	41.3	42.6	75.7	128	129	0	32	30
2014	9	18	9	22	18	0.243	0.016	0.768	0.039	0.039	0	42.1	43	75.7	129	131	0	31	31
2014	9	18	9	32	18	0.164	-0.016	0.768	0.033	0.03	0	42.6	43	75.3	130	130	0	31	30
2014	9	18	9	42	18	0.203	-0.01	0.768	0.036	0.033	0	43	43.4	75.3	131	132	0	31	31
2014	9	18	9	52	18	0.249	-0.03	0.768	0.036	0.033	0	43.9	46	73.1	133	137	0	31	30
2014	9	18	10	2	18	0.207	0.112	0.768	0.033	0.03	0	44.3	46	74	134	137	0	31	30
2014	9	18	10	12	18	0.22	-0.033	0.768	0.033	0.03	0	45.6	46.4	73.1	137	138	0	31	30
2014	9	18	10	22	18	0.197	-0.049	0.768	0.036	0.033	0	46.4	46.4	72.7	138	138	0	30	30
2014	9	18	10	32	18	0.151	0.007	0.768	0.033	0.033	0	46.9	47.7	72.2	140	141	0	31	30
2014	9	18	10	42	18	0.213	0	0.768	0.033	0.03	0	46	47.3	72.2	138	140	0	31	30
2014	9	18	10	52	18	0.213	-0.023	0.764	0.033	0.03	0	46.9	47.7	71.4	140	142	0	31	31
2014	9	18	11	2	18	0.217	0	0.764	0.033	0.03	0	47.3	48.6	70.1	141	143	0	31	30
2014	9	18	11	12	18	0.213	0.026	0.764	0.033	0.03	0	48.6	49.5	71	144	145	0	31	30
2014	9	18	11	22	18	0.23	0.046	0.764	0.033	0.03	0	48.2	48.6	70.1	143	143	0	31	30
2014	9	18	11	32	18	0.187	0.02	0.764	0.036	0.033	0	48.6	49.5	69.7	143	146	0	30	31
2014	9	18	11	42	18	0.141	0.066	0.764	0.033	0.03	0	48.2	49.9	70.5	143	146	0	31	30
2014	9	18	11	52	18	0.24	0.069	0.764	0.03	0.03	0	48.6	50.3	69.2	144	147	0	31	30
2014	9	18	12	2	18	0.226	0.049	0.764	0.033	0.033	0	48.6	50.3	71	144	147	0	31	30
2014	9	18	12	12	18	0.24	0.079	0.764	0.033	0.03	0	49.5	51.2	68.8	145	148	0	30	29
2014	9	18	12	22	18	0.135	0.072	0.761	0.033	0.03	0	49	51.2	69.2	145	149	0	31	30
2014	9	18	12	32	18	0.266	0.049	0.761	0.033	0.03	0	49.5	51.2	69.2	146	149	0	31	30
2014	9	18	12	42	18	0.194	0	0.761	0.036	0.033	0	49	50.7	68.8	145	148	0	31	30
2014	9	18	12	52	18	0.236	0.121	0.761	0.033	0.03	0	49	50.3	68.8	144	147	0	30	30
2014	9	18	13	2	18	0.213	0.085	0.758	0.033	0.03	0	49	50.3	68.8	145	147	0	31	30
2014	9	18	13	12	18	0.213	0.125	0.758	0.036	0.033	0	49.5	49.9	68.4	146	146	0	31	30
2014	9	18	13	22	18	0.18	0.072	0.758	0.03	0.03	0	48.2	49.5	68.8	143	145	0	31	30
2014	9	18	13	32	18	0.223	0.056	0.758	0.033	0.03	0	48.2	49	69.7	143	144	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	13	42	18	0.305	0	0.755	0.036	0.033	0	48.6	50.7	68.8	143	148	0	30	30
2014	9	18	13	52	18	0.177	0.052	0.755	0.033	0.03	0	46.9	49.9	70.1	140	146	0	31	30
2014	9	18	14	2	18	0.2	0	0.751	0.033	0.03	0	48.6	49.5	69.7	143	145	0	30	30
2014	9	18	14	12	18	0.184	0.039	0.751	0.036	0.033	0	47.7	49.9	70.1	142	146	0	31	30
2014	9	18	14	22	18	0.203	0.056	0.751	0.033	0.03	0	48.6	49.5	70.1	144	145	0	31	30
2014	9	18	14	32	18	0.23	0.007	0.748	0.03	0.03	0	49	51.2	70.5	145	149	0	31	30
2014	9	18	14	42	18	0.167	0.052	0.748	0.033	0.03	0	47.3	50.3	71	140	147	0	30	30
2014	9	18	14	52	18	0.197	-0.03	0.748	0.03	0.026	0	48.6	50.3	70.1	143	147	0	30	30
2014	9	18	15	2	18	0.233	0.082	0.748	0.036	0.033	0	48.6	50.7	71.4	144	148	0	31	30
2014	9	18	15	12	18	0.187	0.043	0.748	0.036	0.033	0	48.6	50.3	71	143	146	0	30	29
2014	9	18	15	22	18	0.236	0.046	0.748	0.036	0.033	0	48.6	50.7	71	144	148	0	31	30
2014	9	18	15	32	18	0.187	0.033	0.748	0.033	0.03	0	48.6	51.2	71.8	143	149	0	30	30
2014	9	18	15	42	18	0.226	0.033	0.745	0.033	0.03	0	49.5	51.2	72.2	145	148	0	30	29
2014	9	18	15	52	18	0.167	0.033	0.748	0.033	0.03	0	49	50.3	71.8	144	147	0	30	30
2014	9	18	16	2	18	0.223	0.059	0.745	0.036	0.033	0	48.2	49	71.8	142	144	0	30	30
2014	9	18	16	12	18	0.24	0.033	0.745	0.033	0.03	0	48.2	50.3	71.8	143	146	0	31	29
2014	9	18	16	22	18	0.23	0.007	0.745	0.033	0.03	0	47.3	49.9	72.7	140	145	0	30	29
2014	9	18	16	32	18	0.19	0.016	0.745	0.033	0.03	0	47.7	49	72.7	141	143	0	30	29
2014	9	18	16	42	18	0.266	-0.072	0.745	0.033	0.03	0	45.6	46.9	72.7	136	139	0	30	30
2014	9	18	16	52	18	0.144	-0.003	0.745	0.033	0.03	0	46	46.9	72.2	137	139	0	30	30
2014	9	18	17	2	18	0.223	0	0.745	0.033	0.03	0	46.4	47.7	74	138	140	0	30	29
2014	9	18	17	12	18	0.243	0.062	0.745	0.036	0.033	0	44.7	45.6	73.1	135	135	0	31	29
2014	9	18	17	22	18	0.167	0.082	0.745	0.036	0.033	0	43.4	44.3	74.4	132	132	0	31	29
2014	9	18	17	32	18	0.194	0.036	0.745	0.033	0.03	0	42.1	41.7	75.7	128	126	0	30	29
2014	9	18	17	42	18	0.18	0.023	0.745	0.039	0.039	0	41.7	40.9	74.8	127	124	0	30	29
2014	9	18	17	52	18	0.226	0.036	0.745	0.036	0.033	0	42.1	41.7	74.4	129	126	0	31	29
2014	9	18	18	2	18	0.226	-0.003	0.745	0.033	0.03	0	41.3	40	74.8	127	123	0	31	30
2014	9	18	18	12	18	0.187	0.023	0.745	0.039	0.039	0	40.9	40.4	77	125	123	0	30	29
2014	9	18	18	22	18	0.269	-0.023	0.745	0.043	0.039	0	40.9	40	75.7	125	122	0	30	29
2014	9	18	18	32	18	0.171	0.066	0.745	0.036	0.033	0	40.4	40.4	76.1	125	123	0	31	29
2014	9	18	18	42	18	0.164	-0.02	0.745	0.036	0.033	0	42.1	40.9	75.7	128	124	0	30	29
2014	9	18	18	52	18	0.174	-0.036	0.741	0.033	0.03	0	41.7	41.3	75.7	127	126	0	30	30
2014	9	18	19	2	18	0.22	-0.007	0.741	0.036	0.033	0	42.1	42.1	74.4	129	127	0	31	29
2014	9	18	19	12	18	0.174	-0.03	0.741	0.036	0.033	0	43.4	43	75.3	131	129	0	30	29
2014	9	18	19	22	18	0.167	-0.003	0.741	0.033	0.03	0	43.9	42.6	74.8	133	128	0	31	29
2014	9	18	19	32	18	0.2	-0.02	0.741	0.036	0.033	0	44.3	43	74	133	130	0	30	30
2014	9	18	19	42	18	0.151	-0.03	0.741	0.039	0.036	0	43.4	43	74.8	131	129	0	30	29
2014	9	18	19	52	18	0.135	-0.036	0.741	0.039	0.036	0	43.9	43	75.3	132	130	0	30	30
2014	9	18	20	2	18	0.226	-0.016	0.741	0.033	0.03	0	43.9	43	74.4	133	130	0	31	30
2014	9	18	20	12	18	0.217	0.01	0.741	0.033	0.03	0	43.9	43	74	132	130	0	30	30
2014	9	18	20	22	18	0.194	-0.043	0.741	0.033	0.03	0	43.9	43	75.3	132	130	0	30	30
2014	9	18	20	32	18	0.171	-0.036	0.741	0.033	0.03	0	46	44.7	72.7	138	134	0	31	30
2014	9	18	20	42	18	0.203	0.007	0.741	0.039	0.036	0	46	45.2	73.1	138	134	0	31	29
2014	9	18	20	52	18	0.167	-0.039	0.741	0.036	0.033	0	46.4	45.6	72.7	139	136	0	31	30
2014	9	18	21	2	18	0.21	-0.059	0.741	0.039	0.036	0	47.3	46	71.8	140	136	0	30	29
2014	9	18	21	12	18	0.19	-0.079	0.741	0.033	0.03	0	45.6	44.7	73.1	136	134	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	21	22	18	0.223	-0.023	0.741	0.039	0.036	0	45.6	44.7	73.1	136	134	0	30	30
2014	9	18	21	32	18	0.223	-0.066	0.741	0.039	0.036	0	44.3	44.3	73.1	134	133	0	31	30
2014	9	18	21	42	18	0.135	-0.062	0.741	0.039	0.036	0	46	44.7	74	137	134	0	30	30
2014	9	18	21	52	18	0.21	-0.049	0.741	0.036	0.033	0	46.4	46	73.1	138	136	0	30	29
2014	9	18	22	2	18	0.092	0.102	0.741	0.039	0.039	0	46.4	46	72.2	139	136	0	31	29
2014	9	18	22	12	18	0.177	0.033	0.741	0.036	0.033	0	46	45.2	73.1	137	135	0	30	30
2014	9	18	22	22	18	0.184	-0.056	0.741	0.036	0.033	0	45.6	45.2	73.1	137	134	0	31	29
2014	9	18	22	32	18	0.194	-0.043	0.741	0.036	0.033	0	44.7	44.7	72.2	135	133	0	31	29
2014	9	18	22	42	18	0.19	0.062	0.741	0.033	0.03	0	47.7	46.9	70.5	142	139	0	31	30
2014	9	18	22	52	18	0.203	0.003	0.741	0.036	0.033	0	46.9	46	71.4	139	137	0	30	30
2014	9	18	23	2	18	0.151	0	0.741	0.033	0.03	0	47.3	46.4	71.4	140	138	0	30	30
2014	9	18	23	12	18	0.23	0.016	0.741	0.033	0.03	0	47.3	46	71.8	140	137	0	30	30
2014	9	18	23	22	18	0.138	0.016	0.738	0.033	0.03	0	50.3	48.6	68.8	148	143	0	31	30
2014	9	18	23	32	18	0.151	0.056	0.738	0.036	0.033	0	49.5	49	69.7	146	143	0	31	29
2014	9	18	23	42	18	0.19	-0.013	0.738	0.033	0.03	0	51.2	50.7	70.1	150	148	0	31	30
2014	9	18	23	52	18	0.151	-0.013	0.738	0.03	0.03	0	49.9	49.5	71	147	145	0	31	30
2014	9	19	0	2	18	0.213	0.039	0.741	0.039	0.039	0	46.9	47.7	72.2	141	141	0	32	30
2014	9	19	0	12	18	0.19	0.039	0.741	0.033	0.03	0	46.9	46.4	72.7	140	138	0	31	30
2014	9	19	0	22	18	0.223	-0.023	0.738	0.033	0.03	0	46.9	46	71.4	140	137	0	31	30
2014	9	19	0	32	18	0.184	-0.013	0.738	0.039	0.036	0	46	45.6	71.4	139	137	0	32	31
2014	9	19	0	42	18	0.138	0.02	0.738	0.036	0.033	0	46.4	45.2	72.7	139	135	0	31	30
2014	9	19	0	52	18	0.19	0.023	0.738	0.039	0.036	0	47.7	47.3	71.4	142	140	0	31	30
2014	9	19	1	2	18	0.233	-0.036	0.738	0.03	0.03	0	48.6	47.3	70.5	144	140	0	31	30
2014	9	19	1	12	18	0.135	-0.03	0.738	0.039	0.039	0	49.5	48.2	70.5	146	142	0	31	30
2014	9	19	1	22	18	0.154	0.033	0.741	0.033	0.03	0	46	46.4	72.7	138	138	0	31	30
2014	9	19	1	32	18	0.177	0.02	0.738	0.039	0.036	0	47.3	46	71.4	140	138	0	30	31
2014	9	19	1	42	18	0.187	0.016	0.738	0.039	0.039	0	46	45.6	72.7	138	136	0	31	30
2014	9	19	1	52	18	0.203	-0.082	0.741	0.036	0.033	0	44.3	45.2	72.7	134	135	0	31	30
2014	9	19	2	2	18	0.141	-0.01	0.741	0.033	0.03	0	44.7	44.7	73.1	136	134	0	32	30
2014	9	19	2	12	18	0.157	-0.007	0.741	0.033	0.033	0	45.2	45.6	72.7	136	136	0	31	30
2014	9	19	2	22	18	0.187	0.003	0.738	0.033	0.03	0	44.3	44.3	72.7	134	134	0	31	31
2014	9	19	2	32	18	0.164	-0.01	0.738	0.03	0.03	0	44.7	44.7	73.1	135	135	0	31	31
2014	9	19	2	42	18	0.131	0.052	0.741	0.033	0.03	0	45.6	45.6	71.8	137	136	0	31	30
2014	9	19	2	52	18	0.22	0.026	0.741	0.033	0.03	0	45.6	44.7	71.8	137	134	0	31	30
2014	9	19	3	2	18	0.174	-0.046	0.738	0.033	0.03	0	46.4	46	72.2	138	137	0	30	30
2014	9	19	3	12	18	0.167	-0.007	0.738	0.046	0.043	0	45.6	45.6	71	137	136	0	31	30
2014	9	19	3	22	18	0.131	0.036	0.738	0.03	0.03	0	49.9	49	68.8	147	144	0	31	30
2014	9	19	3	32	18	0.141	0.052	0.738	0.039	0.039	0	46.9	46.4	70.5	141	138	0	32	30
2014	9	19	3	42	18	0.197	0.059	0.738	0.046	0.043	0	49	47.7	69.2	145	141	0	31	30
2014	9	19	3	52	18	0.23	0.003	0.738	0.039	0.039	0	48.2	46.9	70.1	143	139	0	31	30
2014	9	19	4	2	18	0.187	-0.016	0.738	0.036	0.033	0	46	45.6	71.8	138	137	0	31	31
2014	9	19	4	12	18	0.177	-0.039	0.738	0.03	0.03	0	46	45.6	71.8	138	137	0	31	31
2014	9	19	4	22	18	0.187	0	0.738	0.033	0.03	0	45.6	45.2	71.8	137	135	0	31	30
2014	9	19	4	32	18	0.2	0	0.738	0.033	0.03	0	45.6	46	73.1	138	137	0	32	30
2014	9	19	4	42	18	0.203	-0.01	0.738	0.039	0.036	0	44.7	45.2	72.7	135	135	0	31	30
2014	9	19	4	52	18	0.098	-0.01	0.738	0.033	0.03	0	44.3	45.2	72.7	134	136	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	5	2	18	0.157	0.033	0.738	0.033	0.03	0	44.3	44.3	73.1	135	134	0	32	31
2014	9	19	5	12	18	0.233	0.013	0.738	0.033	0.03	0	45.2	43.9	71.8	136	133	0	31	31
2014	9	19	5	22	18	0.213	-0.043	0.738	0.033	0.03	0	44.7	44.7	72.7	136	134	0	32	30
2014	9	19	5	32	18	0.203	0.01	0.738	0.033	0.03	0	43.9	43.4	72.2	134	132	0	32	31
2014	9	19	5	42	18	0.187	0.016	0.738	0.033	0.03	0	44.7	43.9	72.2	135	133	0	31	31
2014	9	19	5	52	18	0.161	-0.069	0.738	0.033	0.03	0	44.3	43.9	73.1	134	132	0	31	30
2014	9	19	6	2	18	0.157	0	0.738	0.039	0.039	0	44.3	43.4	71.8	134	131	0	31	30
2014	9	19	6	12	18	0.164	-0.089	0.738	0.039	0.036	0	44.3	43.4	73.1	133	132	0	30	31
2014	9	19	6	22	18	0.157	0.01	0.738	0.033	0.03	0	43.9	43.9	72.7	134	132	0	32	30
2014	9	19	6	32	18	0.22	-0.02	0.738	0.033	0.03	0	43	42.6	72.7	132	130	0	32	31
2014	9	19	6	42	18	0.135	0.046	0.738	0.033	0.03	0	42.1	42.6	73.1	130	129	0	32	30
2014	9	19	6	52	18	0.128	0	0.738	0.039	0.036	0	41.7	41.7	73.5	129	128	0	32	31
2014	9	19	7	2	18	0.157	0.03	0.738	0.033	0.03	0	41.3	40.9	73.5	128	126	0	32	31
2014	9	19	7	12	18	0.131	-0.016	0.738	0.033	0.033	0	42.1	41.3	74	129	126	0	31	30
2014	9	19	7	22	18	0.2	-0.03	0.738	0.033	0.03	0	40.4	40.9	74.8	126	125	0	32	30
2014	9	19	7	32	18	0.128	0	0.738	0.033	0.03	0	41.3	40.9	73.5	128	126	0	32	31
2014	9	19	7	42	18	0.19	-0.007	0.738	0.036	0.033	0	41.7	41.3	74.4	128	126	0	31	30
2014	9	19	7	52	18	0.157	0.003	0.738	0.033	0.03	0	41.3	42.1	74.8	127	128	0	31	30
2014	9	19	8	2	18	0.207	-0.026	0.738	0.036	0.033	0	42.1	41.7	74	129	127	0	31	30
2014	9	19	8	12	18	0.161	-0.007	0.738	0.033	0.03	0	42.1	43	73.1	129	130	0	31	30
2014	9	19	8	22	18	0.164	-0.033	0.738	0.036	0.033	0	41.7	43	73.1	129	130	0	32	30
2014	9	19	8	32	18	0.207	0.016	0.738	0.036	0.033	0	43.4	42.6	73.5	132	129	0	31	30
2014	9	19	8	42	18	0.157	-0.016	0.738	0.033	0.03	0	43.4	43	72.7	132	131	0	31	31
2014	9	19	8	52	18	0.131	0.036	0.738	0.036	0.033	0	43	43.9	72.7	131	133	0	31	31
2014	9	19	9	2	18	0.203	0.003	0.735	0.033	0.03	0	44.3	44.3	71.4	134	133	0	31	30
2014	9	19	9	12	18	0.197	0.026	0.735	0.036	0.033	0	43.9	44.3	72.2	133	134	0	31	31
2014	9	19	9	22	18	0.151	0.03	0.735	0.036	0.033	0	45.2	46	73.1	136	137	0	31	30
2014	9	19	9	32	18	0.164	0	0.735	0.033	0.03	0	46	46	73.1	138	138	0	31	31
2014	9	19	9	42	18	0.138	0.059	0.735	0.03	0.03	0	46.9	47.3	72.2	140	141	0	31	31
2014	9	19	9	52	18	0.157	-0.098	0.735	0.033	0.03	0	47.7	48.2	71.4	142	143	0	31	31
2014	9	19	10	2	18	0.144	0.056	0.735	0.036	0.033	0	48.6	49.9	71.4	144	146	0	31	30
2014	9	19	10	12	18	0.102	0.102	0.735	0.033	0.03	0	48.6	49.5	69.7	145	145	0	32	30
2014	9	19	10	22	18	0.23	0.085	0.735	0.03	0.03	0	47.7	50.3	71.4	143	147	0	32	30
2014	9	19	10	32	18	0.194	0.003	0.735	0.033	0.03	0	48.2	50.3	72.2	143	147	0	31	30
2014	9	19	10	42	18	0.207	0.007	0.735	0.033	0.03	0	47.7	49.5	71.8	143	145	0	32	30
2014	9	19	10	52	18	0.135	0.052	0.735	0.033	0.03	0	49	49.9	71.8	145	147	0	31	31
2014	9	19	11	2	18	0.167	0.052	0.735	0.033	0.03	0	48.2	49.5	72.7	143	146	0	31	31
2014	9	19	11	12	18	0.174	0.033	0.735	0.033	0.03	0	49.5	50.3	72.2	146	147	0	31	30
2014	9	19	11	22	18	0.21	-0.03	0.735	0.033	0.03	0	49	50.7	71.8	145	148	0	31	30
2014	9	19	11	32	18	0.197	0.059	0.738	0.033	0.03	0	48.6	50.3	71.8	145	147	0	32	30
2014	9	19	11	42	18	0.187	0.016	0.738	0.03	0.03	0	49.5	51.2	70.5	146	149	0	31	30
2014	9	19	11	52	18	0.197	0.092	0.738	0.033	0.03	0	49.9	51.6	71.4	147	150	0	31	30
2014	9	19	12	2	18	0.197	0.052	0.738	0.033	0.03	0	49	52.5	71	145	152	0	31	30
2014	9	19	12	12	18	0.197	0.02	0.738	0.03	0.03	0	49.5	52	71.4	146	151	0	31	30
2014	9	19	12	22	18	0.246	0.092	0.738	0.03	0.026	0	51.2	52.5	70.5	150	153	0	31	31
2014	9	19	12	32	18	0.174	0.079	0.741	0.026	0.023	0	51.6	53.8	71	151	155	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	12	42	18	0.197	0.007	0.741	0.026	0.023	0	52.5	54.6	70.1	153	157	0	31	30
2014	9	19	12	52	18	0.21	0.062	0.741	0.03	0.03	0	50.7	53.8	70.1	149	155	0	31	30
2014	9	19	13	2	18	0.164	0.036	0.745	0.03	0.03	0	50.3	51.6	70.5	148	150	0	31	30
2014	9	19	13	12	18	0.23	0.052	0.745	0.033	0.03	0	51.2	52	70.1	150	152	0	31	31
2014	9	19	13	22	18	0.197	0	0.748	0.03	0.03	0	51.2	53.3	69.7	150	154	0	31	30
2014	9	19	13	32	18	0.22	0.052	0.748	0.03	0.03	0	49	51.2	69.7	145	149	0	31	30
2014	9	19	13	42	18	0.177	0.128	0.748	0.03	0.03	0	49.5	50.7	69.2	146	149	0	31	31
2014	9	19	13	52	18	0.164	0.003	0.751	0.033	0.03	0	51.2	53.3	70.1	150	155	0	31	31
2014	9	19	14	2	18	0.164	0.03	0.758	0.033	0.03	0	48.6	50.3	70.1	144	147	0	31	30
2014	9	19	14	12	18	0.217	0.016	0.758	0.033	0.03	0	47.3	50.7	70.1	141	148	0	31	30
2014	9	19	14	22	18	0.21	0.043	0.758	0.033	0.03	0	49	50.7	68.8	144	148	0	30	30
2014	9	19	14	32	18	0.253	0.056	0.761	0.033	0.03	0	49	50.7	69.2	145	148	0	31	30
2014	9	19	14	42	18	0.184	0.125	0.764	0.03	0.03	0	49.5	51.2	68.8	146	149	0	31	30
2014	9	19	14	52	18	0.23	0.105	0.761	0.033	0.03	0	49	50.7	70.5	144	148	0	30	30
2014	9	19	15	2	18	0.154	0.075	0.764	0.036	0.033	0	49	50.3	69.2	144	147	0	30	30
2014	9	19	15	12	18	0.276	0.072	0.764	0.033	0.03	0	48.6	50.7	70.1	144	147	0	31	29
2014	9	19	15	22	18	0.266	0.02	0.768	0.033	0.03	0	48.2	49.9	70.5	143	146	0	31	30
2014	9	19	15	32	18	0.19	0.007	0.764	0.03	0.03	0	48.2	50.3	69.2	143	147	0	31	30
2014	9	19	15	42	18	0.243	0.033	0.768	0.033	0.03	0	49.5	50.7	69.2	145	148	0	30	30
2014	9	19	15	52	18	0.236	0.095	0.768	0.033	0.03	0	48.6	49.9	70.5	143	146	0	30	30
2014	9	19	16	2	18	0.21	0.033	0.768	0.033	0.03	0	48.2	49.5	70.1	143	145	0	31	30
2014	9	19	16	12	18	0.236	0.039	0.768	0.03	0.03	0	48.2	50.3	71.4	143	147	0	31	30
2014	9	19	16	22	18	0.18	0.062	0.768	0.033	0.033	0	47.7	49.9	71.8	142	145	0	31	29
2014	9	19	16	32	18	0.22	0.052	0.768	0.033	0.03	0	47.7	48.6	70.5	142	143	0	31	30
2014	9	19	16	42	18	0.279	0.095	0.771	0.033	0.03	0	47.7	48.2	72.2	142	142	0	31	30
2014	9	19	16	52	18	0.279	0.016	0.771	0.033	0.03	0	46.9	47.7	71.8	139	141	0	30	30
2014	9	19	17	2	18	0.272	0.033	0.771	0.033	0.033	0	45.6	46.4	73.1	137	138	0	31	30
2014	9	19	17	12	18	0.243	0.089	0.771	0.036	0.033	0	45.2	45.6	72.7	136	136	0	31	30
2014	9	19	17	22	18	0.167	0.026	0.774	0.033	0.03	0	43.9	43	74	133	130	0	31	30
2014	9	19	17	32	18	0.24	0.052	0.774	0.036	0.033	0	41.7	41.3	75.3	128	126	0	31	30
2014	9	19	17	42	18	0.249	0.075	0.774	0.039	0.036	0	42.1	40.4	75.7	128	124	0	30	30
2014	9	19	17	52	18	0.223	0.026	0.774	0.033	0.03	0	41.7	41.3	76.1	127	126	0	30	30
2014	9	19	18	2	18	0.23	0.062	0.774	0.036	0.033	0	41.3	40	76.5	126	123	0	30	30
2014	9	19	18	12	18	0.21	0.098	0.774	0.033	0.03	0	40.9	40.4	76.5	125	123	0	30	29
2014	9	19	18	22	18	0.2	0.115	0.778	0.036	0.033	0	40.9	40.4	76.5	126	124	0	31	30
2014	9	19	18	32	18	0.262	0.03	0.778	0.039	0.036	0	40.4	40.9	77	125	124	0	31	29
2014	9	19	18	42	18	0.249	0.052	0.778	0.033	0.03	0	40.4	40.9	77.4	125	125	0	31	30
2014	9	19	18	52	18	0.243	-0.003	0.778	0.039	0.036	0	42.6	41.7	77	129	127	0	30	30
2014	9	19	19	2	18	0.207	-0.03	0.778	0.033	0.03	0	42.1	42.1	75.7	129	128	0	31	30
2014	9	19	19	12	18	0.276	0.007	0.778	0.033	0.03	0	43	43.4	76.1	131	130	0	31	29
2014	9	19	19	22	18	0.194	-0.016	0.778	0.033	0.03	0	44.3	43	76.1	133	129	0	30	29
2014	9	19	19	32	18	0.236	-0.036	0.778	0.033	0.03	0	42.6	43.4	77.4	130	130	0	31	29
2014	9	19	19	42	18	0.243	-0.039	0.778	0.033	0.03	0	42.6	43	76.5	130	130	0	31	30
2014	9	19	19	52	18	0.22	-0.052	0.778	0.033	0.03	0	43.4	43	77	131	130	0	30	30
2014	9	19	20	2	18	0.217	-0.026	0.778	0.033	0.03	0	43.4	43	75.3	132	130	0	31	30
2014	9	19	20	12	18	0.22	-0.066	0.778	0.033	0.03	0	43.9	43.4	76.1	133	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	20	22	18	0.24	0.016	0.778	0.036	0.033	0	44.7	44.3	76.1	134	133	0	30	30
2014	9	19	20	32	18	0.217	0.016	0.778	0.036	0.033	0	43.4	43.4	76.5	132	131	0	31	30
2014	9	19	20	42	18	0.197	-0.102	0.778	0.036	0.033	0	43.9	43.4	76.1	133	131	0	31	30
2014	9	19	20	52	18	0.243	-0.02	0.778	0.033	0.03	0	43	43.4	75.7	130	130	0	30	29
2014	9	19	21	2	18	0.249	0.003	0.778	0.033	0.03	0	43.4	43.4	75.7	132	131	0	31	30
2014	9	19	21	12	18	0.171	-0.026	0.778	0.039	0.039	0	44.7	43.9	75.3	134	133	0	30	31
2014	9	19	21	22	18	0.233	0.043	0.778	0.033	0.03	0	43	42.1	76.1	131	128	0	31	30
2014	9	19	21	32	18	0.249	-0.033	0.778	0.033	0.03	0	46.4	46	72.7	139	137	0	31	30
2014	9	19	21	42	18	0.266	0.01	0.778	0.033	0.03	0	45.2	44.3	74.8	136	133	0	31	30
2014	9	19	21	52	18	0.24	0.013	0.778	0.033	0.03	0	47.7	46.4	71.8	142	138	0	31	30
2014	9	19	22	2	18	0.203	-0.026	0.778	0.036	0.033	0	45.2	44.7	74	136	134	0	31	30
2014	9	19	22	12	18	0.236	0.036	0.781	0.03	0.03	0	43.4	43.4	75.7	132	131	0	31	30
2014	9	19	22	22	18	0.292	-0.02	0.781	0.036	0.033	0	44.3	43.4	75.3	133	131	0	30	30
2014	9	19	22	32	18	0.253	0.056	0.781	0.036	0.033	0	43.4	43.9	75.3	132	132	0	31	30
2014	9	19	22	42	18	0.289	0.003	0.781	0.033	0.03	0	43.9	43.9	75.3	133	132	0	31	30
2014	9	19	22	52	18	0.289	-0.02	0.781	0.039	0.036	0	43.4	43.9	74.8	132	132	0	31	30
2014	9	19	23	2	18	0.223	0.03	0.781	0.039	0.036	0	43.4	43.9	76.1	131	132	0	30	30
2014	9	19	23	12	18	0.23	-0.056	0.781	0.033	0.03	0	43	41.7	74.4	131	128	0	31	31
2014	9	19	23	22	18	0.233	0	0.778	0.036	0.033	0	43.9	42.1	74.8	132	129	0	30	31
2014	9	19	23	32	18	0.167	0.007	0.778	0.039	0.036	0	43.9	43.4	74	133	131	0	31	30
2014	9	19	23	42	18	0.295	-0.062	0.781	0.033	0.03	0	42.6	43	74	130	130	0	31	30
2014	9	19	23	52	18	0.249	0.013	0.781	0.039	0.036	0	43	43	74.4	131	130	0	31	30
2014	9	20	0	2	18	0.226	-0.059	0.781	0.036	0.033	0	43.4	43.4	74.8	133	132	0	32	31
2014	9	20	0	12	18	0.217	-0.03	0.781	0.036	0.033	0	43.4	42.6	74.4	132	129	0	31	30
2014	9	20	0	22	18	0.213	-0.039	0.781	0.033	0.03	0	43	42.6	74.8	130	129	0	30	30
2014	9	20	0	32	18	0.253	0.016	0.778	0.033	0.03	0	43	42.6	74.8	131	130	0	31	31
2014	9	20	0	42	18	0.266	-0.062	0.781	0.039	0.036	0	42.6	42.6	73.1	130	129	0	31	30
2014	9	20	0	52	18	0.246	-0.036	0.778	0.036	0.033	0	43.4	43.4	74.4	132	131	0	31	30
2014	9	20	1	2	18	0.272	-0.085	0.778	0.033	0.03	0	43.9	43	74.4	133	131	0	31	31
2014	9	20	1	12	18	0.305	-0.016	0.778	0.03	0.03	0	43.4	43.4	74.8	131	131	0	30	30
2014	9	20	1	22	18	0.243	-0.043	0.781	0.033	0.033	0	43	43.9	74	131	132	0	31	30
2014	9	20	1	32	18	0.249	0.03	0.778	0.03	0.03	0	43	43.4	74.4	131	131	0	31	30
2014	9	20	1	42	18	0.184	-0.052	0.778	0.033	0.03	0	42.6	43	74	131	130	0	32	30
2014	9	20	1	52	18	0.2	0.016	0.778	0.033	0.03	0	43.4	43	74.4	132	130	0	31	30
2014	9	20	2	2	18	0.312	-0.052	0.778	0.036	0.033	0	43	42.1	74.8	131	128	0	31	30
2014	9	20	2	12	18	0.213	-0.049	0.778	0.033	0.03	0	43.4	43.4	74	132	131	0	31	30
2014	9	20	2	22	18	0.236	0.01	0.778	0.033	0.03	0	43.4	42.1	73.5	132	129	0	31	31
2014	9	20	2	32	18	0.246	-0.085	0.778	0.036	0.033	0	43	42.6	73.5	131	129	0	31	30
2014	9	20	2	42	18	0.259	0.033	0.778	0.033	0.03	0	43.9	43.9	74	133	132	0	31	30
2014	9	20	2	52	18	0.21	0.007	0.778	0.039	0.036	0	43.4	43.4	74	132	131	0	31	30
2014	9	20	3	2	18	0.233	0.062	0.778	0.033	0.03	0	43.9	43.4	73.5	134	131	0	32	30
2014	9	20	3	12	18	0.177	0	0.778	0.036	0.033	0	43	43.4	74.4	132	131	0	32	30
2014	9	20	3	22	18	0.23	-0.02	0.778	0.036	0.033	0	43.4	43	74.4	132	130	0	31	30
2014	9	20	3	32	18	0.262	-0.023	0.781	0.033	0.03	0	43	43	74	132	130	0	32	30
2014	9	20	3	42	18	0.226	-0.056	0.778	0.046	0.043	0	43	43.4	73.5	132	132	0	32	31
2014	9	20	3	52	18	0.256	-0.023	0.778	0.033	0.03	0	43	43.4	73.5	131	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	4	2	18	0.213	0.043	0.781	0.036	0.033	0	43	43	73.5	131	131	0	31	31
2014	9	20	4	12	18	0.141	-0.121	0.778	0.036	0.033	0	43.4	43.4	73.5	132	131	0	31	30
2014	9	20	4	22	18	0.253	-0.049	0.781	0.033	0.03	0	44.3	43	74	134	130	0	31	30
2014	9	20	4	32	18	0.207	-0.033	0.778	0.033	0.03	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	20	4	42	18	0.197	0.01	0.781	0.036	0.033	0	43.4	43.4	72.7	133	131	0	32	30
2014	9	20	4	52	18	0.249	-0.056	0.781	0.033	0.03	0	43.4	43	73.1	132	131	0	31	31
2014	9	20	5	2	18	0.19	-0.02	0.781	0.039	0.039	0	43.4	43	73.5	132	130	0	31	30
2014	9	20	5	12	18	0.233	-0.056	0.781	0.036	0.033	0	43.4	43	73.5	132	130	0	31	30
2014	9	20	5	22	18	0.187	-0.098	0.781	0.039	0.036	0	42.6	43	74	131	130	0	32	30
2014	9	20	5	32	18	0.243	0	0.781	0.033	0.03	0	43.4	43.9	73.1	132	132	0	31	30
2014	9	20	5	42	18	0.217	-0.102	0.781	0.033	0.033	0	43.4	43.9	73.5	133	132	0	32	30
2014	9	20	5	52	18	0.226	0.013	0.781	0.033	0.03	0	43	43	72.2	132	131	0	32	31
2014	9	20	6	2	18	0.207	-0.069	0.781	0.033	0.03	0	43.4	43.4	73.1	132	131	0	31	30
2014	9	20	6	12	18	0.217	0	0.781	0.039	0.036	0	43.4	43	73.1	132	131	0	31	31
2014	9	20	6	22	18	0.243	-0.036	0.781	0.036	0.033	0	42.6	43	72.7	131	131	0	32	31
2014	9	20	6	32	18	0.262	-0.033	0.781	0.036	0.033	0	42.6	42.6	72.7	131	130	0	32	31
2014	9	20	6	42	18	0.19	-0.02	0.781	0.033	0.03	0	43	42.1	72.7	132	129	0	32	31
2014	9	20	6	52	18	0.207	-0.066	0.781	0.036	0.033	0	42.1	41.7	72.7	129	127	0	31	30
2014	9	20	7	2	18	0.187	0.016	0.781	0.039	0.036	0	41.7	41.3	72.7	128	127	0	31	31
2014	9	20	7	12	18	0.24	-0.01	0.781	0.036	0.033	0	41.3	40.9	72.7	128	126	0	32	31
2014	9	20	7	22	18	0.171	-0.062	0.781	0.039	0.036	0	40.9	40.4	72.2	126	125	0	31	31
2014	9	20	7	32	18	0.177	-0.013	0.781	0.036	0.033	0	40.9	39.6	73.5	127	124	0	32	32
2014	9	20	7	42	18	0.213	-0.036	0.781	0.033	0.03	0	40.9	40	73.1	126	123	0	31	30
2014	9	20	7	52	18	0.174	-0.01	0.781	0.033	0.03	0	40.9	40	73.1	127	124	0	32	31
2014	9	20	8	2	18	0.184	-0.069	0.784	0.036	0.033	0	41.3	40.4	72.7	128	125	0	32	31
2014	9	20	8	12	18	0.177	-0.121	0.784	0.039	0.039	0	41.3	40.9	72.2	127	126	0	31	31
2014	9	20	8	22	18	0.213	-0.016	0.784	0.033	0.03	0	41.3	42.1	72.7	128	128	0	32	30
2014	9	20	8	32	18	0.226	-0.023	0.784	0.033	0.03	0	40.9	40.9	72.7	127	126	0	32	31
2014	9	20	8	42	18	0.213	0	0.784	0.033	0.033	0	41.3	40.4	72.7	127	125	0	31	31
2014	9	20	8	52	18	0.243	0.016	0.784	0.036	0.033	0	41.3	40.4	72.7	127	125	0	31	31
2014	9	20	9	2	18	0.167	0.056	0.784	0.033	0.03	0	41.7	41.3	72.7	128	126	0	31	30
2014	9	20	9	12	18	0.207	-0.049	0.784	0.033	0.03	0	41.3	40.9	72.7	128	126	0	32	31
2014	9	20	9	22	18	0.22	-0.069	0.784	0.036	0.033	0	41.3	42.1	72.2	128	128	0	32	30
2014	9	20	9	32	18	0.21	0	0.784	0.033	0.03	0	41.7	42.1	72.2	129	129	0	32	31
2014	9	20	9	42	18	0.259	-0.036	0.784	0.033	0.03	0	43.9	44.7	71.8	134	135	0	32	31
2014	9	20	9	52	18	0.213	0	0.784	0.036	0.033	0	45.2	46.4	71.8	137	138	0	32	30
2014	9	20	10	2	18	0.269	-0.043	0.784	0.033	0.033	0	44.7	47.3	70.5	136	141	0	32	31
2014	9	20	10	12	18	0.174	0.007	0.784	0.033	0.03	0	46.4	47.3	70.5	140	141	0	32	31
2014	9	20	10	22	18	0.161	0	0.784	0.033	0.03	0	46	49	70.5	139	144	0	32	30
2014	9	20	10	32	18	0.223	0.049	0.784	0.033	0.033	0	46.9	49.5	70.1	141	145	0	32	30
2014	9	20	10	42	18	0.233	0	0.781	0.033	0.03	0	47.3	49.9	70.1	142	147	0	32	31
2014	9	20	10	52	18	0.243	0.043	0.781	0.03	0.03	0	49	50.3	70.5	145	147	0	31	30
2014	9	20	11	2	18	0.223	0.079	0.781	0.036	0.033	0	47.3	49	70.5	141	145	0	31	31
2014	9	20	11	12	18	0.2	0	0.781	0.036	0.033	0	47.3	50.3	70.1	142	148	0	32	31
2014	9	20	11	22	18	0.243	0.02	0.781	0.033	0.03	0	48.6	51.2	70.1	144	150	0	31	31
2014	9	20	11	32	18	0.21	0.043	0.781	0.033	0.03	0	47.7	50.7	69.7	143	149	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	11	42	18	0.236	0.026	0.781	0.033	0.03	0	49.5	51.6	69.7	146	151	0	31	31
2014	9	20	11	52	18	0.292	-0.033	0.781	0.033	0.03	0	49.9	51.6	70.5	147	150	0	31	30
2014	9	20	12	2	18	0.24	0.03	0.781	0.033	0.03	0	50.7	52.5	68.4	149	153	0	31	31
2014	9	20	12	12	18	0.282	0.056	0.781	0.043	0.039	0	50.7	52	69.2	149	151	0	31	30
2014	9	20	12	22	18	0.23	0.043	0.781	0.03	0.03	0	49.9	51.6	70.1	148	151	0	32	31
2014	9	20	12	32	18	0.24	0.007	0.781	0.03	0.026	0	50.3	52.5	68.8	148	153	0	31	31
2014	9	20	12	42	18	0.246	0.102	0.781	0.036	0.033	0	50.7	51.6	69.7	149	151	0	31	31
2014	9	20	12	52	18	0.256	0.013	0.781	0.039	0.039	0	49.9	51.6	69.7	148	151	0	32	31
2014	9	20	13	2	18	0.259	0.003	0.781	0.033	0.03	0	50.7	52	69.2	149	151	0	31	30
2014	9	20	13	12	18	0.325	0.066	0.781	0.033	0.03	0	50.7	52.5	68.8	149	152	0	31	30
2014	9	20	13	22	18	0.213	0.082	0.781	0.039	0.036	0	49.9	50.7	70.5	146	148	0	30	30
2014	9	20	13	32	18	0.249	0.092	0.781	0.036	0.033	0	47.7	49	70.5	142	144	0	31	30
2014	9	20	13	42	18	0.266	0.059	0.781	0.033	0.033	0	49	50.3	70.1	144	147	0	30	30
2014	9	20	13	52	18	0.282	0.049	0.781	0.033	0.03	0	47.7	49.5	71	143	145	0	32	30
2014	9	20	14	2	18	0.272	0.141	0.781	0.033	0.03	0	49	50.3	71	145	147	0	31	30
2014	9	20	14	12	18	0.269	0.089	0.778	0.03	0.03	0	51.2	52.5	69.7	150	153	0	31	31
2014	9	20	14	22	18	0.233	0.128	0.778	0.033	0.03	0	51.2	52.9	69.2	150	153	0	31	30
2014	9	20	14	32	18	0.233	0.072	0.778	0.033	0.03	0	50.3	52	69.7	147	150	0	30	29
2014	9	20	14	42	18	0.305	0.072	0.778	0.033	0.03	0	50.7	52	71	149	151	0	31	30
2014	9	20	14	52	18	0.249	0.082	0.778	0.033	0.03	0	50.7	52	70.1	149	152	0	31	31
2014	9	20	15	2	18	0.249	0.066	0.778	0.039	0.036	0	49	51.2	72.2	145	149	0	31	30
2014	9	20	15	12	18	0.236	0.098	0.778	0.043	0.039	0	49.9	52.5	71.4	147	152	0	31	30
2014	9	20	15	22	18	0.223	0.046	0.778	0.033	0.03	0	50.3	52	72.2	147	151	0	30	30
2014	9	20	15	32	18	0.213	0.085	0.778	0.036	0.033	0	49.9	51.6	72.7	146	150	0	30	30
2014	9	20	15	42	18	0.272	0.033	0.778	0.033	0.03	0	49.9	52	72.7	147	151	0	31	30
2014	9	20	15	52	18	0.243	0.089	0.778	0.036	0.033	0	48.6	51.6	72.7	144	150	0	31	30
2014	9	20	16	2	18	0.213	0.052	0.781	0.033	0.03	0	50.3	51.6	71.4	148	150	0	31	30
2014	9	20	16	12	18	0.266	0.075	0.778	0.033	0.03	0	49.5	51.6	72.2	146	150	0	31	30
2014	9	20	16	22	18	0.279	0.151	0.781	0.036	0.033	0	44.3	43.9	74	134	132	0	31	30
2014	9	20	16	32	18	0.308	0.164	0.781	0.033	0.03	0	45.6	45.2	74.8	137	135	0	31	30
2014	9	20	16	42	18	0.295	0.161	0.781	0.039	0.036	0	46.9	46.4	73.1	140	138	0	31	30
2014	9	20	16	52	18	0.24	0.19	0.781	0.033	0.03	0	44.7	44.3	74.4	135	133	0	31	30
2014	9	20	17	2	18	0.285	0.22	0.781	0.036	0.033	0	44.3	43.4	74	133	131	0	30	30
2014	9	20	17	12	18	0.236	0.223	0.781	0.036	0.033	0	45.6	44.7	74	137	134	0	31	30
2014	9	20	17	22	18	0.236	0.167	0.781	0.033	0.03	0	45.6	44.7	73.5	137	134	0	31	30
2014	9	20	17	32	18	0.295	0.256	0.781	0.039	0.039	0	43.9	43	74.4	133	130	0	31	30
2014	9	20	17	42	18	0.315	0.154	0.781	0.039	0.039	0	43.4	42.6	74.8	132	129	0	31	30
2014	9	20	17	52	18	0.266	0.144	0.781	0.039	0.036	0	43	41.3	74.4	130	126	0	30	30
2014	9	20	18	2	18	0.23	0.135	0.781	0.036	0.033	0	42.6	41.7	75.3	130	127	0	31	30
2014	9	20	18	12	18	0.223	0.062	0.781	0.036	0.033	0	41.7	40.4	75.3	127	124	0	30	30
2014	9	20	18	22	18	0.203	0.082	0.781	0.039	0.036	0	40.9	40	76.1	126	123	0	31	30
2014	9	20	18	32	18	0.21	0.082	0.781	0.033	0.03	0	42.6	42.1	74.8	130	128	0	31	30
2014	9	20	18	42	18	0.282	0.098	0.781	0.033	0.03	0	41.7	40	76.5	127	123	0	30	30
2014	9	20	18	52	18	0.22	0.043	0.781	0.033	0.033	0	40.9	40.9	75.7	126	125	0	31	30
2014	9	20	19	2	18	0.243	0	0.781	0.033	0.03	0	41.7	41.7	75.3	127	127	0	30	30
2014	9	20	19	12	18	0.249	-0.016	0.781	0.039	0.036	0	41.3	40.9	75.3	127	125	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	19	22	18	0.256	0.016	0.781	0.033	0.03	0	41.7	41.7	75.7	128	127	0	31	30
2014	9	20	19	32	18	0.266	-0.016	0.781	0.033	0.03	0	42.6	42.1	76.5	129	128	0	30	30
2014	9	20	19	42	18	0.246	0	0.781	0.033	0.03	0	42.1	41.3	75.3	128	126	0	30	30
2014	9	20	19	52	18	0.253	0.03	0.781	0.039	0.036	0	42.6	42.6	74.8	129	129	0	30	30
2014	9	20	20	2	18	0.217	0.016	0.781	0.036	0.033	0	42.6	42.6	75.3	130	129	0	31	30
2014	9	20	20	12	18	0.2	0.016	0.781	0.043	0.043	0	43.4	42.6	75.7	131	129	0	30	30
2014	9	20	20	22	18	0.197	0.043	0.781	0.036	0.033	0	43.4	43.4	74.8	131	131	0	30	30
2014	9	20	20	32	18	0.233	0.007	0.778	0.03	0.03	0	47.3	46.4	71	141	138	0	31	30
2014	9	20	20	42	18	0.249	-0.043	0.781	0.033	0.03	0	46.4	45.6	72.7	139	136	0	31	30
2014	9	20	20	52	18	0.253	0.003	0.781	0.033	0.03	0	47.7	46	71.8	141	137	0	30	30
2014	9	20	21	2	18	0.262	-0.03	0.781	0.043	0.039	0	46.9	45.6	71.8	140	136	0	31	30
2014	9	20	21	12	18	0.207	0.016	0.781	0.036	0.033	0	46.9	46	71	140	137	0	31	30
2014	9	20	21	22	18	0.259	0.036	0.781	0.039	0.039	0	48.2	47.3	69.7	142	140	0	30	30
2014	9	20	21	32	18	0.161	0.128	0.778	0.043	0.043	0	51.6	50.3	67.1	151	147	0	31	30
2014	9	20	21	42	18	0.236	0.131	0.778	0.039	0.039	0	51.6	50.3	67.1	151	147	0	31	30
2014	9	20	21	52	18	0.23	0.161	0.781	0.043	0.039	0	49.5	48.2	69.7	146	142	0	31	30
2014	9	20	22	2	18	0.24	0.105	0.781	0.036	0.033	0	48.2	47.3	71.4	143	140	0	31	30
2014	9	20	22	12	18	0.262	0.079	0.781	0.033	0.03	0	47.3	46	71.4	141	138	0	31	31
2014	9	20	22	22	18	0.308	0.066	0.781	0.033	0.03	0	46.4	45.2	71.8	138	136	0	30	31
2014	9	20	22	32	18	0.177	-0.016	0.781	0.033	0.03	0	46	45.2	72.2	137	135	0	30	30
2014	9	20	22	42	18	0.256	0.03	0.781	0.033	0.03	0	44.3	43.9	72.2	135	132	0	32	30
2014	9	20	22	52	18	0.256	0.033	0.781	0.033	0.03	0	44.7	43.9	72.7	136	133	0	32	31
2014	9	20	23	2	18	0.236	-0.016	0.781	0.039	0.039	0	43.9	43	73.1	133	130	0	31	30
2014	9	20	23	12	18	0.266	0.003	0.781	0.03	0.03	0	44.3	44.3	72.7	134	133	0	31	30
2014	9	20	23	22	18	0.187	-0.066	0.781	0.03	0.03	0	43.9	44.3	74	133	134	0	31	31
2014	9	20	23	32	18	0.253	-0.003	0.781	0.039	0.039	0	43.4	42.1	73.1	132	129	0	31	31
2014	9	20	23	42	18	0.243	-0.016	0.781	0.036	0.033	0	43	43.4	73.1	132	131	0	32	30
2014	9	20	23	52	18	0.2	0.03	0.781	0.036	0.033	0	44.3	43	73.5	134	130	0	31	30
2014	9	21	0	2	18	0.236	-0.01	0.781	0.033	0.03	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	21	0	12	18	0.223	0.033	0.781	0.033	0.03	0	46	46	71.4	139	137	0	32	30
2014	9	21	0	22	18	0.292	-0.01	0.781	0.036	0.033	0	45.2	45.2	71.8	137	135	0	32	30
2014	9	21	0	32	18	0.243	-0.026	0.781	0.036	0.033	0	44.7	44.7	71.8	135	135	0	31	31
2014	9	21	0	42	18	0.249	-0.023	0.781	0.039	0.036	0	44.3	44.3	71.8	134	134	0	31	31
2014	9	21	0	52	18	0.236	0.052	0.781	0.036	0.033	0	45.6	45.2	71.8	137	135	0	31	30
2014	9	21	1	2	18	0.21	-0.016	0.781	0.033	0.03	0	45.2	44.7	72.2	136	134	0	31	30
2014	9	21	1	12	18	0.282	-0.036	0.781	0.033	0.03	0	45.2	44.7	72.2	136	134	0	31	30
2014	9	21	1	22	18	0.226	0.01	0.781	0.033	0.03	0	43.9	43.4	72.2	133	132	0	31	31
2014	9	21	1	32	18	0.279	-0.046	0.781	0.033	0.03	0	43.4	43	72.2	133	131	0	32	31
2014	9	21	1	42	18	0.217	-0.023	0.781	0.033	0.03	0	43.9	43.4	71.8	133	131	0	31	30
2014	9	21	1	52	18	0.246	-0.01	0.781	0.036	0.033	0	49.5	48.2	65.8	146	143	0	31	31
2014	9	21	2	2	18	0.253	-0.033	0.781	0.039	0.036	0	49	47.7	67.1	145	142	0	31	31
2014	9	21	2	12	18	0.289	0.072	0.781	0.036	0.033	0	50.3	49	66.2	148	144	0	31	30
2014	9	21	2	22	18	0.259	0.125	0.781	0.033	0.03	0	49.9	48.2	66.7	147	143	0	31	31
2014	9	21	2	32	18	0.24	0.184	0.781	0.039	0.039	0	48.6	47.3	67.9	144	141	0	31	31
2014	9	21	2	42	18	0.223	0.118	0.781	0.033	0.03	0	46.9	46.9	68.8	140	139	0	31	30
2014	9	21	2	52	18	0.236	0.069	0.781	0.039	0.039	0	46	45.6	68.8	138	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	3	2	18	0.262	-0.007	0.781	0.039	0.036	0	46.9	45.2	69.2	140	136	0	31	31
2014	9	21	3	12	18	0.302	0.049	0.781	0.039	0.039	0	46.4	45.6	70.1	139	137	0	31	31
2014	9	21	3	22	18	0.223	0.046	0.784	0.039	0.036	0	46	44.7	70.1	139	135	0	32	31
2014	9	21	3	32	18	0.262	0.082	0.784	0.036	0.033	0	46	45.2	70.1	138	135	0	31	30
2014	9	21	3	42	18	0.243	0.075	0.784	0.039	0.036	0	46	44.7	69.7	138	135	0	31	31
2014	9	21	3	52	18	0.187	0.003	0.784	0.033	0.03	0	46.9	45.6	67.9	140	137	0	31	31
2014	9	21	4	2	18	0.266	0.062	0.781	0.036	0.033	0	48.6	47.3	67.9	144	140	0	31	30
2014	9	21	4	12	18	0.259	0.069	0.781	0.039	0.036	0	47.3	46	68.8	141	137	0	31	30
2014	9	21	4	22	18	0.243	0.016	0.784	0.043	0.039	0	46.9	46	69.2	140	137	0	31	30
2014	9	21	4	32	18	0.243	-0.023	0.784	0.039	0.036	0	47.7	46.4	68.4	141	139	0	30	31
2014	9	21	4	42	18	0.315	-0.026	0.781	0.039	0.036	0	49.9	48.6	66.2	147	143	0	31	30
2014	9	21	4	52	18	0.295	0.039	0.784	0.036	0.033	0	50.7	49.5	66.2	149	145	0	31	30
2014	9	21	5	2	18	0.203	0.085	0.784	0.036	0.033	0	49	48.2	66.2	145	143	0	31	31
2014	9	21	5	12	18	0.19	0.049	0.787	0.039	0.036	0	47.3	47.3	67.1	142	140	0	32	30
2014	9	21	5	22	18	0.243	0.062	0.787	0.033	0.03	0	46.9	46.4	68.8	140	138	0	31	30
2014	9	21	5	32	18	0.24	-0.007	0.787	0.036	0.033	0	46.4	45.6	70.1	139	137	0	31	31
2014	9	21	5	42	18	0.21	-0.023	0.787	0.033	0.03	0	45.6	45.6	70.5	138	136	0	32	30
2014	9	21	5	52	18	0.226	-0.007	0.791	0.033	0.03	0	44.3	45.2	70.5	135	135	0	32	30
2014	9	21	6	2	18	0.19	-0.046	0.791	0.039	0.036	0	45.2	45.6	70.1	136	136	0	31	30
2014	9	21	6	12	18	0.197	-0.01	0.791	0.033	0.03	0	44.7	44.7	70.1	135	134	0	31	30
2014	9	21	6	22	18	0.213	-0.098	0.791	0.033	0.03	0	44.3	43.4	71	135	132	0	32	31
2014	9	21	6	32	18	0.226	0.02	0.791	0.033	0.03	0	44.3	43.4	71	134	131	0	31	30
2014	9	21	6	42	18	0.259	0.026	0.794	0.036	0.033	0	43.4	43.4	71	133	132	0	32	31
2014	9	21	6	52	18	0.259	-0.036	0.791	0.033	0.03	0	43.4	43.4	71	132	131	0	31	30
2014	9	21	7	2	18	0.171	-0.036	0.794	0.033	0.03	0	43.4	41.7	71	132	128	0	31	31
2014	9	21	7	12	18	0.276	0.003	0.794	0.039	0.036	0	42.1	41.7	71.8	129	128	0	31	31
2014	9	21	7	22	18	0.223	-0.039	0.794	0.039	0.036	0	41.7	42.6	71.8	129	129	0	32	30
2014	9	21	7	32	18	0.203	-0.02	0.794	0.036	0.033	0	41.7	41.3	71.8	129	127	0	32	31
2014	9	21	7	42	18	0.256	0.023	0.794	0.036	0.033	0	42.6	41.7	72.2	131	128	0	32	31
2014	9	21	7	52	18	0.266	-0.046	0.794	0.039	0.036	0	41.7	42.6	71.4	129	129	0	32	30
2014	9	21	8	2	18	0.24	0.016	0.794	0.036	0.033	0	42.6	42.6	72.7	130	130	0	31	31
2014	9	21	8	12	18	0.299	-0.089	0.794	0.036	0.033	0	42.1	41.7	72.7	129	127	0	31	30
2014	9	21	8	22	18	0.223	0	0.794	0.036	0.033	0	42.1	41.7	72.2	130	127	0	32	30
2014	9	21	8	32	18	0.259	-0.003	0.794	0.033	0.03	0	41.7	41.7	72.7	129	128	0	32	31
2014	9	21	8	42	18	0.207	0	0.794	0.039	0.036	0	42.6	41.3	72.7	131	126	0	32	30
2014	9	21	8	52	18	0.19	-0.02	0.794	0.03	0.03	0	42.6	42.1	72.2	131	129	0	32	31
2014	9	21	9	2	18	0.226	0.016	0.794	0.039	0.036	0	42.6	42.1	72.7	130	128	0	31	30
2014	9	21	9	12	18	0.226	-0.007	0.794	0.036	0.033	0	42.1	42.1	73.5	129	128	0	31	30
2014	9	21	9	22	18	0.243	0.043	0.794	0.036	0.033	0	42.6	42.1	71.8	131	129	0	32	31
2014	9	21	9	32	18	0.253	0.01	0.794	0.033	0.03	0	43.4	43.4	72.7	132	131	0	31	30
2014	9	21	9	42	18	0.194	0.046	0.794	0.036	0.033	0	43.4	45.2	71.4	133	136	0	32	31
2014	9	21	9	52	18	0.233	0.023	0.794	0.033	0.03	0	46	45.6	71	138	136	0	31	30
2014	9	21	10	2	18	0.187	-0.003	0.794	0.036	0.033	0	46.9	48.2	70.5	140	143	0	31	31
2014	9	21	10	12	18	0.243	0.016	0.794	0.039	0.036	0	46	48.6	71	139	144	0	32	31
2014	9	21	10	22	18	0.236	0.026	0.791	0.03	0.03	0	47.7	49.9	69.7	142	147	0	31	31
2014	9	21	10	32	18	0.236	0.016	0.791	0.036	0.033	0	46.9	49.5	70.5	141	145	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	10	42	18	0.276	0.036	0.791	0.033	0.03	0	48.2	50.7	70.1	144	149	0	32	31
2014	9	21	10	52	18	0.269	0.033	0.791	0.033	0.03	0	48.6	50.3	69.7	144	148	0	31	31
2014	9	21	11	2	18	0.282	0	0.791	0.033	0.03	0	49	51.2	70.1	146	149	0	32	30
2014	9	21	11	12	18	0.21	0.105	0.791	0.033	0.03	0	49.5	51.6	69.7	147	151	0	32	31
2014	9	21	11	22	18	0.269	0.016	0.791	0.033	0.03	0	49.9	52	68.8	147	151	0	31	30
2014	9	21	11	32	18	0.246	0.049	0.787	0.03	0.03	0	49.5	52.9	69.2	147	153	0	32	30
2014	9	21	11	42	18	0.279	0.007	0.787	0.033	0.03	0	51.2	52.5	69.2	150	153	0	31	31
2014	9	21	11	52	18	0.22	0.01	0.787	0.033	0.03	0	49.9	51.6	69.7	147	150	0	31	30
2014	9	21	12	2	18	0.194	0.049	0.787	0.036	0.033	0	52.5	53.8	68.8	153	155	0	31	30
2014	9	21	12	12	18	0.266	0.062	0.787	0.026	0.023	0	50.7	52.9	67.1	149	153	0	31	30
2014	9	21	12	22	18	0.213	0.036	0.784	0.036	0.033	0	50.3	52	68.4	149	152	0	32	31
2014	9	21	12	32	18	0.285	0.036	0.784	0.033	0.03	0	51.2	52	69.2	150	152	0	31	31
2014	9	21	12	42	18	0.338	0	0.784	0.036	0.033	0	50.3	52	69.2	148	152	0	31	31
2014	9	21	12	52	18	0.243	0.043	0.784	0.033	0.03	0	50.3	52	68.8	148	151	0	31	30
2014	9	21	13	2	18	0.269	0.016	0.784	0.03	0.03	0	47.7	49.9	70.5	142	146	0	31	30
2014	9	21	13	12	18	0.249	0	0.784	0.03	0.03	0	48.6	51.6	70.5	145	150	0	32	30
2014	9	21	13	22	18	0.256	0.079	0.784	0.033	0.03	0	50.7	53.3	68.8	149	154	0	31	30
2014	9	21	13	32	18	0.22	0.033	0.784	0.036	0.033	0	50.3	52.5	68.8	148	153	0	31	31
2014	9	21	13	42	18	0.207	0.085	0.784	0.043	0.039	0	49.9	51.6	69.2	147	151	0	31	31
2014	9	21	13	52	18	0.295	0.056	0.784	0.033	0.03	0	51.2	52.5	69.7	149	152	0	30	30
2014	9	21	14	2	18	0.276	0.082	0.784	0.036	0.033	0	49.5	52	68.8	147	151	0	32	30
2014	9	21	14	12	18	0.259	0.059	0.784	0.039	0.036	0	51.2	53.3	70.1	149	154	0	30	30
2014	9	21	14	22	18	0.282	0.059	0.784	0.033	0.03	0	49	49.9	70.5	144	146	0	30	30
2014	9	21	14	32	18	0.187	0.049	0.784	0.033	0.03	0	49	52	71	145	150	0	31	29
2014	9	21	14	42	18	0.285	0.007	0.784	0.033	0.03	0	49	50.7	71.8	144	148	0	30	30
2014	9	21	14	52	18	0.213	0.023	0.784	0.033	0.03	0	49.9	52	71	147	150	0	31	29
2014	9	21	15	2	18	0.246	0.072	0.784	0.033	0.03	0	49	50.3	70.5	144	147	0	30	30
2014	9	21	15	12	18	0.23	0.046	0.784	0.033	0.03	0	50.7	52.9	69.7	148	153	0	30	30
2014	9	21	15	22	18	0.194	-0.016	0.784	0.033	0.03	0	46.9	48.6	72.7	140	142	0	31	29
2014	9	21	15	32	18	0.256	0.016	0.781	0.03	0.03	0	49.5	51.6	71	146	150	0	31	30
2014	9	21	15	42	18	0.289	0.016	0.784	0.033	0.03	0	49.5	51.6	70.5	147	150	0	32	30
2014	9	21	15	52	18	0.226	0.059	0.781	0.033	0.03	0	49.9	52	71	147	151	0	31	30
2014	9	21	16	2	18	0.22	0.082	0.781	0.033	0.03	0	50.3	51.2	71.4	148	149	0	31	30
2014	9	21	16	12	18	0.266	0.01	0.781	0.039	0.036	0	49.5	51.2	70.5	146	149	0	31	30
2014	9	21	16	22	18	0.335	0.072	0.784	0.033	0.03	0	47.7	50.7	72.2	142	148	0	31	30
2014	9	21	16	32	18	0.295	0.046	0.781	0.039	0.039	0	48.6	50.7	72.7	143	147	0	30	29
2014	9	21	16	42	18	0.289	0.049	0.784	0.036	0.033	0	48.2	50.3	72.7	143	147	0	31	30
2014	9	21	16	52	18	0.285	0.089	0.781	0.033	0.033	0	46.9	47.7	73.1	139	141	0	30	30
2014	9	21	17	2	18	0.256	0.095	0.784	0.033	0.03	0	42.6	41.7	75.7	129	127	0	30	30
2014	9	21	17	12	18	0.22	0.125	0.784	0.036	0.033	0	41.3	41.7	75.7	126	126	0	30	29
2014	9	21	17	22	18	0.276	0.062	0.784	0.036	0.033	0	40.9	40.4	75.7	125	124	0	30	30
2014	9	21	17	32	18	0.322	0.043	0.784	0.039	0.036	0	40.9	40	76.5	125	122	0	30	29
2014	9	21	17	42	18	0.236	0.105	0.784	0.033	0.03	0	40.9	40	75.7	125	123	0	30	30
2014	9	21	17	52	18	0.259	0.075	0.784	0.039	0.039	0	40	39.6	75.7	123	122	0	30	30
2014	9	21	18	2	18	0.266	-0.01	0.784	0.036	0.033	0	40.4	39.6	75.7	124	121	0	30	29
2014	9	21	18	12	18	0.243	0.016	0.784	0.033	0.03	0	40.4	39.1	75.7	124	121	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	18	22	18	0.23	-0.013	0.784	0.033	0.03	0	39.6	38.3	75.7	123	119	0	31	30
2014	9	21	18	32	18	0.217	-0.033	0.784	0.03	0.03	0	40.4	40.4	75.7	124	123	0	30	29
2014	9	21	18	42	18	0.302	-0.02	0.784	0.033	0.03	0	40.4	39.1	75.7	124	121	0	30	30
2014	9	21	18	52	18	0.246	0.039	0.784	0.033	0.03	0	40.9	40.9	75.3	126	125	0	31	30
2014	9	21	19	2	18	0.285	-0.052	0.784	0.033	0.03	0	40.9	40.4	75.3	126	124	0	31	30
2014	9	21	19	12	18	0.207	-0.069	0.784	0.033	0.03	0	40.9	41.3	74.4	126	125	0	31	29
2014	9	21	19	22	18	0.276	0	0.784	0.033	0.03	0	41.3	41.3	75.3	127	126	0	31	30
2014	9	21	19	32	18	0.197	-0.03	0.784	0.033	0.03	0	42.1	42.1	75.7	129	128	0	31	30
2014	9	21	19	42	18	0.23	-0.02	0.784	0.036	0.033	0	43.9	43.4	74.4	132	131	0	30	30
2014	9	21	19	52	18	0.233	-0.033	0.784	0.033	0.03	0	42.6	42.6	74.8	130	129	0	31	30
2014	9	21	20	2	18	0.177	0.01	0.784	0.033	0.03	0	43	41.7	74	130	127	0	30	30
2014	9	21	20	12	18	0.24	-0.036	0.784	0.039	0.039	0	43	42.6	74	131	129	0	31	30
2014	9	21	20	22	18	0.262	0.033	0.784	0.039	0.036	0	46.4	45.2	71	138	135	0	30	30
2014	9	21	20	32	18	0.272	-0.01	0.784	0.039	0.039	0	44.7	43.9	72.2	135	132	0	31	30
2014	9	21	20	42	18	0.253	-0.01	0.784	0.036	0.033	0	44.3	43.4	71.4	133	131	0	30	30
2014	9	21	20	52	18	0.249	-0.016	0.784	0.039	0.036	0	44.7	43.4	72.2	135	131	0	31	30
2014	9	21	21	2	18	0.24	-0.039	0.784	0.036	0.033	0	46.9	45.6	70.5	139	136	0	30	30
2014	9	21	21	12	18	0.243	-0.003	0.784	0.036	0.033	0	46.9	46	70.1	141	137	0	32	30
2014	9	21	21	22	18	0.223	-0.02	0.784	0.039	0.039	0	47.7	46	69.2	141	136	0	30	29
2014	9	21	21	32	18	0.233	-0.036	0.784	0.033	0.03	0	46.9	45.2	70.1	139	135	0	30	30
2014	9	21	21	42	18	0.256	0	0.787	0.036	0.033	0	43.4	43	72.2	132	130	0	31	30
2014	9	21	21	52	18	0.243	-0.01	0.787	0.036	0.033	0	43.9	42.6	71.4	133	129	0	31	30
2014	9	21	22	2	18	0.253	0.059	0.787	0.033	0.03	0	43	43.4	71.8	131	131	0	31	30
2014	9	21	22	12	18	0.24	0.03	0.787	0.033	0.03	0	42.6	43	71.8	130	130	0	31	30
2014	9	21	22	22	18	0.22	0.01	0.787	0.033	0.03	0	43.9	44.3	71	133	133	0	31	30
2014	9	21	22	32	18	0.262	0.052	0.787	0.033	0.03	0	45.2	44.3	71	137	133	0	32	30
2014	9	21	22	42	18	0.249	-0.023	0.787	0.049	0.049	0	45.2	44.3	70.1	136	133	0	31	30
2014	9	21	22	52	18	0.213	0.007	0.787	0.039	0.036	0	46.9	45.2	69.2	140	135	0	31	30
2014	9	21	23	2	18	0.2	0.046	0.791	0.039	0.036	0	45.6	44.3	70.5	137	134	0	31	31
2014	9	21	23	12	18	0.292	-0.052	0.791	0.039	0.036	0	43.9	43.9	71.4	133	131	0	31	29
2014	9	21	23	22	18	0.279	-0.039	0.791	0.033	0.03	0	46.9	45.2	69.7	139	136	0	30	31
2014	9	21	23	32	18	0.23	0.026	0.791	0.039	0.036	0	46.4	45.6	69.2	140	137	0	32	31
2014	9	21	23	42	18	0.22	-0.026	0.791	0.039	0.036	0	45.6	44.7	70.5	136	134	0	30	30
2014	9	21	23	52	18	0.223	-0.046	0.791	0.036	0.033	0	46	45.6	69.2	139	136	0	32	30
2014	9	22	0	2	18	0.262	0	0.794	0.036	0.033	0	44.7	43.4	71.4	135	132	0	31	31
2014	9	22	0	12	18	0.328	-0.072	0.791	0.033	0.03	0	43.9	42.6	71.8	133	130	0	31	31
2014	9	22	0	22	18	0.246	-0.052	0.794	0.036	0.033	0	45.6	44.3	70.5	137	134	0	31	31
2014	9	22	0	32	18	0.328	0.046	0.791	0.033	0.03	0	44.3	43.4	71	134	131	0	31	30
2014	9	22	0	42	18	0.23	-0.052	0.791	0.033	0.03	0	43.9	43.9	71	134	132	0	32	30
2014	9	22	0	52	18	0.207	-0.03	0.791	0.033	0.03	0	43.4	43.4	71.8	132	132	0	31	31
2014	9	22	1	2	18	0.266	-0.069	0.791	0.033	0.03	0	43.4	42.6	72.2	132	129	0	31	30
2014	9	22	1	12	18	0.23	-0.039	0.791	0.033	0.03	0	43	43	72.2	131	130	0	31	30
2014	9	22	1	22	18	0.23	0	0.787	0.039	0.036	0	42.6	42.6	71.8	131	129	0	32	30
2014	9	22	1	32	18	0.243	0.003	0.787	0.033	0.03	0	43	42.6	71.8	131	129	0	31	30
2014	9	22	1	42	18	0.285	-0.016	0.787	0.036	0.033	0	42.6	41.7	72.7	130	127	0	31	30
2014	9	22	1	52	18	0.21	-0.089	0.787	0.036	0.033	0	42.1	42.1	71.8	130	129	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	2	2	18	0.233	-0.039	0.787	0.033	0.03	0	42.6	41.7	71.8	130	128	0	31	31
2014	9	22	2	12	18	0.22	-0.059	0.787	0.039	0.039	0	42.6	42.6	72.2	130	129	0	31	30
2014	9	22	2	22	18	0.18	-0.052	0.787	0.033	0.03	0	43	42.6	72.2	131	129	0	31	30
2014	9	22	2	32	18	0.272	0.016	0.784	0.033	0.03	0	43	43	72.2	131	130	0	31	30
2014	9	22	2	42	18	0.236	-0.016	0.784	0.039	0.039	0	42.1	42.1	72.7	130	128	0	32	30
2014	9	22	2	52	18	0.24	0.079	0.784	0.036	0.033	0	43	42.6	72.2	131	129	0	31	30
2014	9	22	3	2	18	0.243	-0.01	0.784	0.039	0.039	0	42.6	42.6	72.7	130	130	0	31	31
2014	9	22	3	12	18	0.194	-0.016	0.784	0.036	0.033	0	43.4	42.1	72.2	131	129	0	30	31
2014	9	22	3	22	18	0.256	0	0.784	0.039	0.036	0	41.7	42.6	72.7	129	129	0	32	30
2014	9	22	3	32	18	0.302	-0.052	0.784	0.033	0.03	0	42.1	41.7	72.2	129	128	0	31	31
2014	9	22	3	42	18	0.23	-0.036	0.784	0.049	0.046	0	42.6	42.1	72.7	130	129	0	31	31
2014	9	22	3	52	18	0.207	-0.013	0.784	0.033	0.03	0	42.1	43	73.1	129	130	0	31	30
2014	9	22	4	2	18	0.276	-0.036	0.784	0.039	0.036	0	43	42.1	72.7	131	129	0	31	31
2014	9	22	4	12	18	0.207	-0.016	0.784	0.033	0.03	0	43	42.1	72.7	131	128	0	31	30
2014	9	22	4	22	18	0.285	-0.033	0.781	0.039	0.036	0	42.6	42.6	72.7	131	130	0	32	31
2014	9	22	4	32	18	0.262	0.003	0.781	0.033	0.03	0	42.6	42.1	72.7	131	129	0	32	31
2014	9	22	4	42	18	0.217	-0.062	0.781	0.033	0.033	0	42.1	41.7	73.1	130	127	0	32	30
2014	9	22	4	52	18	0.276	-0.049	0.781	0.033	0.03	0	43	42.6	73.5	131	130	0	31	31
2014	9	22	5	2	18	0.184	0.007	0.781	0.033	0.03	0	42.1	41.3	73.1	130	127	0	32	31
2014	9	22	5	12	18	0.236	-0.026	0.781	0.033	0.03	0	43	42.6	72.2	131	129	0	31	30
2014	9	22	5	22	18	0.276	-0.049	0.781	0.033	0.03	0	43	42.1	73.1	132	129	0	32	31
2014	9	22	5	32	18	0.217	0.033	0.781	0.033	0.03	0	43	43	73.1	131	130	0	31	30
2014	9	22	5	42	18	0.187	0.02	0.781	0.036	0.033	0	43	42.6	73.1	131	129	0	31	30
2014	9	22	5	52	18	0.207	-0.016	0.781	0.033	0.03	0	42.6	43	72.7	131	130	0	32	30
2014	9	22	6	2	18	0.23	-0.043	0.781	0.039	0.039	0	42.6	43	73.1	130	130	0	31	30
2014	9	22	6	12	18	0.243	0.02	0.778	0.039	0.036	0	42.1	43	73.5	129	130	0	31	30
2014	9	22	6	22	18	0.213	-0.066	0.778	0.033	0.03	0	43	42.6	74	131	130	0	31	31
2014	9	22	6	32	18	0.249	0.03	0.778	0.043	0.043	0	42.6	42.6	73.5	130	129	0	31	30
2014	9	22	6	42	18	0.272	0.039	0.778	0.033	0.03	0	43	41.7	72.7	132	128	0	32	31
2014	9	22	6	52	18	0.259	0	0.778	0.033	0.03	0	43.4	42.6	73.5	132	129	0	31	30
2014	9	22	7	2	18	0.157	0.01	0.778	0.033	0.03	0	41.7	42.1	74	129	129	0	32	31
2014	9	22	7	12	18	0.18	-0.043	0.778	0.033	0.03	0	41.7	41.3	74.4	129	127	0	32	31
2014	9	22	7	22	18	0.21	0.046	0.778	0.033	0.03	0	44.7	43.9	72.2	136	133	0	32	31
2014	9	22	7	32	18	0.295	0.062	0.774	0.039	0.036	0	49	48.6	67.9	147	144	0	33	31
2014	9	22	7	42	18	0.266	0.062	0.774	0.036	0.033	0	50.7	49.5	67.5	149	146	0	31	31
2014	9	22	7	52	18	0.325	0.059	0.774	0.039	0.039	0	49.5	48.2	69.7	146	143	0	31	31
2014	9	22	8	2	18	0.236	0.098	0.774	0.039	0.036	0	47.7	46	70.5	142	138	0	31	31
2014	9	22	8	12	18	0.328	0.02	0.774	0.036	0.033	0	46.4	46	71	140	137	0	32	30
2014	9	22	8	22	18	0.279	0.01	0.778	0.039	0.036	0	45.2	44.3	71.8	137	133	0	32	30
2014	9	22	8	32	18	0.22	0.049	0.778	0.039	0.036	0	44.3	43.4	73.5	134	132	0	31	31
2014	9	22	8	42	18	0.233	-0.016	0.774	0.036	0.033	0	42.6	42.6	73.5	131	130	0	32	31
2014	9	22	8	52	18	0.259	0.056	0.778	0.036	0.033	0	42.1	42.1	74.4	130	129	0	32	31
2014	9	22	9	2	18	0.266	0.039	0.774	0.036	0.033	0	42.6	41.7	75.3	130	128	0	31	31
2014	9	22	9	12	18	0.194	-0.007	0.774	0.036	0.033	0	42.6	41.7	75.3	130	128	0	31	31
2014	9	22	9	22	18	0.226	-0.023	0.774	0.036	0.033	0	43	42.1	75.3	131	129	0	31	31
2014	9	22	9	32	18	0.249	0	0.774	0.033	0.03	0	43	42.6	74.8	132	130	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	9	42	18	0.223	0.033	0.774	0.033	0.03	0	43.4	43	74.8	133	131	0	32	31
2014	9	22	9	52	18	0.217	-0.023	0.774	0.036	0.033	0	46.4	46.4	74	139	139	0	31	31
2014	9	22	10	2	18	0.21	-0.016	0.774	0.033	0.03	0	47.3	49.5	73.5	141	145	0	31	30
2014	9	22	10	12	18	0.322	0.049	0.774	0.033	0.03	0	46.9	50.3	73.5	141	147	0	32	30
2014	9	22	10	22	18	0.256	0.049	0.774	0.033	0.033	0	48.6	50.7	72.7	144	148	0	31	30
2014	9	22	10	32	18	0.253	0.059	0.774	0.03	0.03	0	49	50.7	72.2	146	148	0	32	30
2014	9	22	10	42	18	0.223	0.03	0.774	0.033	0.03	0	49.5	51.2	72.2	146	149	0	31	30
2014	9	22	10	52	18	0.269	0.016	0.771	0.033	0.03	0	49.5	51.6	72.7	147	150	0	32	30
2014	9	22	11	2	18	0.207	0.016	0.774	0.036	0.033	0	49.9	51.2	72.2	147	150	0	31	31
2014	9	22	11	12	18	0.253	0.033	0.771	0.033	0.03	0	50.3	51.6	72.7	148	151	0	31	31
2014	9	22	11	22	18	0.256	0.046	0.774	0.03	0.03	0	50.3	52.5	71.4	148	152	0	31	30
2014	9	22	11	32	18	0.249	-0.013	0.774	0.039	0.036	0	49.9	51.6	71.8	148	150	0	32	30
2014	9	22	11	42	18	0.279	0	0.774	0.033	0.03	0	50.7	52.5	72.2	150	152	0	32	30
2014	9	22	11	52	18	0.295	0.095	0.771	0.033	0.03	0	50.7	52.9	71	150	153	0	32	30
2014	9	22	12	2	18	0.243	0.036	0.771	0.03	0.026	0	51.6	53.8	72.2	151	155	0	31	30
2014	9	22	12	12	18	0.236	0.016	0.771	0.039	0.036	0	51.2	53.8	70.5	151	155	0	32	30
2014	9	22	12	22	18	0.249	0.023	0.771	0.033	0.033	0	51.6	53.3	71	151	154	0	31	30
2014	9	22	12	32	18	0.246	0.02	0.774	0.033	0.03	0	52	53.8	71	152	155	0	31	30
2014	9	22	12	42	18	0.272	0.03	0.771	0.039	0.036	0	52.5	53.8	69.7	153	155	0	31	30
2014	9	22	12	52	18	0.18	0.059	0.771	0.033	0.03	0	51.6	52.9	69.7	151	153	0	31	30
2014	9	22	13	2	18	0.24	0.105	0.771	0.036	0.033	0	51.2	52.9	71.4	150	153	0	31	30
2014	9	22	13	12	18	0.272	0.039	0.771	0.033	0.03	0	51.2	53.3	71.8	150	154	0	31	30
2014	9	22	13	22	18	0.154	0.072	0.771	0.033	0.03	0	50.3	53.3	72.2	148	154	0	31	30
2014	9	22	13	32	18	0.226	0.052	0.771	0.036	0.033	0	51.2	52.9	71	150	153	0	31	30
2014	9	22	13	42	18	0.213	-0.039	0.771	0.039	0.036	0	50.7	52.5	71	149	153	0	31	31
2014	9	22	13	52	18	0.269	0.135	0.771	0.033	0.03	0	51.6	53.3	70.1	151	154	0	31	30
2014	9	22	14	2	18	0.253	0.016	0.771	0.033	0.03	0	51.6	53.3	70.1	151	154	0	31	30
2014	9	22	14	12	18	0.131	0.075	0.771	0.033	0.03	0	51.6	53.8	70.1	151	155	0	31	30
2014	9	22	14	22	18	0.21	0.033	0.768	0.033	0.03	0	50.7	53.3	71	149	154	0	31	30
2014	9	22	14	32	18	0.266	0.016	0.771	0.033	0.03	0	51.6	53.3	69.7	151	154	0	31	30
2014	9	22	14	42	18	0.226	0.066	0.768	0.033	0.033	0	51.2	53.3	71.4	150	153	0	31	29
2014	9	22	14	52	18	0.266	0.036	0.768	0.03	0.026	0	52	54.2	69.7	152	155	0	31	29
2014	9	22	15	2	18	0.22	0.072	0.768	0.033	0.03	0	51.2	53.8	70.1	150	155	0	31	30
2014	9	22	15	12	18	0.233	0.026	0.768	0.039	0.039	0	51.2	53.8	70.1	150	155	0	31	30
2014	9	22	15	22	18	0.272	0.052	0.768	0.033	0.03	0	50.7	52.9	69.7	148	153	0	30	30
2014	9	22	15	32	18	0.24	0.023	0.768	0.03	0.03	0	51.2	52.9	70.5	150	153	0	31	30
2014	9	22	15	42	18	0.23	0.023	0.764	0.033	0.03	0	52.5	52.5	68.8	152	153	0	30	31
2014	9	22	15	52	18	0.285	0.085	0.764	0.039	0.036	0	51.2	52.9	69.2	150	153	0	31	30
2014	9	22	16	2	18	0.233	0.049	0.764	0.039	0.039	0	49.9	52.5	69.7	147	151	0	31	29
2014	9	22	16	12	18	0.266	-0.033	0.764	0.033	0.03	0	49.5	51.2	69.7	146	149	0	31	30
2014	9	22	16	22	18	0.24	-0.016	0.764	0.036	0.033	0	48.6	50.7	69.7	144	147	0	31	29
2014	9	22	16	32	18	0.22	0.069	0.764	0.033	0.03	0	48.2	50.3	69.7	142	147	0	30	30
2014	9	22	16	42	18	0.2	0.023	0.764	0.033	0.03	0	48.2	49.9	70.1	142	146	0	30	30
2014	9	22	16	52	18	0.226	0	0.764	0.033	0.03	0	47.7	49	70.1	141	143	0	30	29
2014	9	22	17	2	18	0.217	-0.039	0.764	0.033	0.03	0	46.4	46.9	71.4	138	139	0	30	30
2014	9	22	17	12	18	0.272	0.036	0.764	0.033	0.03	0	44.3	45.2	71.8	134	135	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	17	22	18	0.226	0.02	0.764	0.033	0.03	0	42.1	41.7	72.2	129	127	0	31	30
2014	9	22	17	32	18	0.331	-0.02	0.764	0.033	0.03	0	42.1	40.9	71.8	129	125	0	31	30
2014	9	22	17	42	18	0.269	0.023	0.764	0.033	0.03	0	40.4	40.4	72.2	125	123	0	31	29
2014	9	22	17	52	18	0.207	-0.013	0.764	0.036	0.033	0	39.6	38.7	72.7	123	120	0	31	30
2014	9	22	18	2	18	0.207	0	0.764	0.039	0.036	0	40.4	39.1	72.7	124	121	0	30	30
2014	9	22	18	12	18	0.19	0.007	0.764	0.033	0.03	0	40	38.7	72.7	123	120	0	30	30
2014	9	22	18	22	18	0.18	-0.108	0.764	0.033	0.03	0	39.6	39.1	72.7	122	121	0	30	30
2014	9	22	18	32	18	0.187	-0.03	0.764	0.039	0.036	0	40.4	40	72.2	124	122	0	30	29
2014	9	22	18	42	18	0.164	0.01	0.764	0.033	0.03	0	40.9	40	73.1	125	123	0	30	30
2014	9	22	18	52	18	0.164	-0.003	0.764	0.033	0.03	0	41.7	40.9	72.2	127	125	0	30	30
2014	9	22	19	2	18	0.24	-0.049	0.764	0.033	0.03	0	40.9	41.3	72.7	125	126	0	30	30
2014	9	22	19	12	18	0.233	-0.075	0.764	0.036	0.033	0	42.1	41.7	72.7	128	127	0	30	30
2014	9	22	19	22	18	0.207	-0.013	0.764	0.039	0.036	0	42.6	41.7	73.1	129	126	0	30	29
2014	9	22	19	32	18	0.148	0.016	0.761	0.036	0.033	0	42.1	41.7	72.2	128	127	0	30	30
2014	9	22	19	42	18	0.246	-0.02	0.764	0.033	0.03	0	42.1	41.7	71.8	128	126	0	30	29
2014	9	22	19	52	18	0.184	-0.026	0.761	0.033	0.03	0	42.6	41.7	71.8	129	127	0	30	30
2014	9	22	20	2	18	0.24	0.016	0.761	0.033	0.03	0	45.6	43.4	70.1	136	131	0	30	30
2014	9	22	20	12	18	0.148	-0.049	0.764	0.036	0.033	0	45.6	43.9	70.1	136	132	0	30	30
2014	9	22	20	22	18	0.279	-0.02	0.764	0.033	0.03	0	44.7	44.3	71	134	132	0	30	29
2014	9	22	20	32	18	0.151	-0.085	0.764	0.036	0.033	0	44.7	43.4	70.5	135	131	0	31	30
2014	9	22	20	42	18	0.187	-0.016	0.764	0.03	0.03	0	43.9	43	71.4	133	130	0	31	30
2014	9	22	20	52	18	0.194	-0.056	0.761	0.043	0.039	0	46.4	45.2	68.8	139	136	0	31	31
2014	9	22	21	2	18	0.2	-0.02	0.761	0.033	0.03	0	46.9	45.6	68.8	140	135	0	31	29
2014	9	22	21	12	18	0.21	0.003	0.764	0.039	0.036	0	46.4	45.2	70.1	138	134	0	30	29
2014	9	22	21	22	18	0.19	-0.03	0.764	0.039	0.036	0	46.4	45.6	70.1	139	135	0	31	29
2014	9	22	21	32	18	0.167	-0.079	0.764	0.043	0.039	0	48.2	46.4	68.8	142	138	0	30	30
2014	9	22	21	42	18	0.171	0.01	0.764	0.033	0.03	0	47.3	46	69.2	141	137	0	31	30
2014	9	22	21	52	18	0.207	-0.151	0.764	0.033	0.03	0	47.7	46.4	68.8	142	138	0	31	30
2014	9	22	22	2	18	0.161	-0.02	0.764	0.033	0.03	0	47.7	46	69.7	141	136	0	30	29
2014	9	22	22	12	18	0.213	-0.062	0.764	0.036	0.033	0	45.2	43.9	72.2	136	132	0	31	30
2014	9	22	22	22	18	0.23	-0.036	0.764	0.033	0.03	0	44.3	43.4	72.7	134	131	0	31	30
2014	9	22	22	32	18	0.177	-0.036	0.764	0.03	0.03	0	43.9	44.3	72.7	133	133	0	31	30
2014	9	22	22	42	18	0.177	0.016	0.764	0.033	0.03	0	44.7	43.9	73.1	135	132	0	31	30
2014	9	22	22	52	18	0.197	0.007	0.764	0.033	0.03	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	22	23	2	18	0.23	-0.105	0.764	0.036	0.033	0	44.3	44.3	72.7	134	133	0	31	30
2014	9	22	23	12	18	0.23	-0.026	0.764	0.039	0.036	0	47.3	46.9	69.7	141	139	0	31	30
2014	9	22	23	22	18	0.217	0	0.764	0.033	0.03	0	45.2	43.9	72.2	136	132	0	31	30
2014	9	22	23	32	18	0.154	-0.026	0.764	0.036	0.033	0	43.4	43	73.1	133	131	0	32	31
2014	9	22	23	42	18	0.194	-0.079	0.764	0.033	0.03	0	46	45.6	70.5	138	136	0	31	30
2014	9	22	23	52	18	0.236	-0.036	0.764	0.039	0.036	0	46	45.2	70.5	139	135	0	32	30
2014	9	23	0	2	18	0.135	-0.052	0.764	0.039	0.036	0	44.7	43.4	72.2	135	131	0	31	30
2014	9	23	0	12	18	0.19	0	0.764	0.039	0.039	0	44.3	43.4	73.5	133	131	0	30	30
2014	9	23	0	22	18	0.19	-0.036	0.764	0.03	0.03	0	43.4	42.6	74	132	130	0	31	31
2014	9	23	0	32	18	0.167	-0.03	0.764	0.039	0.036	0	43.9	42.6	74	133	129	0	31	30
2014	9	23	0	42	18	0.213	-0.075	0.764	0.036	0.033	0	44.7	44.3	73.5	135	133	0	31	30
2014	9	23	0	52	18	0.184	-0.052	0.764	0.033	0.033	0	44.7	43.9	74.4	135	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	1	2	18	0.197	-0.003	0.764	0.033	0.03	0	44.3	43	73.5	135	130	0	32	30
2014	9	23	1	12	18	0.246	-0.039	0.764	0.039	0.036	0	43	42.6	73.5	132	130	0	32	31
2014	9	23	1	22	18	0.128	0.023	0.764	0.036	0.033	0	45.2	44.7	72.7	136	134	0	31	30
2014	9	23	1	32	18	0.19	-0.039	0.764	0.036	0.033	0	43.9	43.4	73.1	133	131	0	31	30
2014	9	23	1	42	18	0.174	-0.023	0.764	0.039	0.036	0	43.9	43.9	74	133	132	0	31	30
2014	9	23	1	52	18	0.157	-0.036	0.764	0.033	0.03	0	45.2	44.7	72.2	137	134	0	32	30
2014	9	23	2	2	18	0.249	-0.046	0.764	0.033	0.03	0	44.3	42.6	73.5	134	130	0	31	31
2014	9	23	2	12	18	0.24	-0.052	0.764	0.033	0.03	0	43	42.1	74	131	129	0	31	31
2014	9	23	2	22	18	0.197	-0.033	0.764	0.033	0.03	0	43.9	43.4	74.4	133	131	0	31	30
2014	9	23	2	32	18	0.197	-0.066	0.764	0.033	0.03	0	43.9	44.3	73.1	134	134	0	32	31
2014	9	23	2	42	18	0.194	-0.046	0.764	0.036	0.033	0	43.4	43.4	74	132	131	0	31	30
2014	9	23	2	52	18	0.161	-0.036	0.764	0.033	0.033	0	43.4	43.4	74.8	132	131	0	31	30
2014	9	23	3	2	18	0.174	-0.03	0.764	0.033	0.03	0	44.7	43.4	73.1	135	132	0	31	31
2014	9	23	3	12	18	0.19	-0.036	0.764	0.033	0.03	0	43.4	42.1	74.8	133	129	0	32	31
2014	9	23	3	22	18	0.154	-0.007	0.768	0.039	0.036	0	43	43	74.8	132	130	0	32	30
2014	9	23	3	32	18	0.207	0	0.764	0.039	0.039	0	43	43	74.4	132	130	0	32	30
2014	9	23	3	42	18	0.226	-0.036	0.764	0.033	0.03	0	43	43	74	132	131	0	32	31
2014	9	23	3	52	18	0.217	0.023	0.768	0.036	0.033	0	43.4	42.6	74.4	133	129	0	32	30
2014	9	23	4	2	18	0.154	-0.036	0.768	0.033	0.03	0	43.4	43.4	74.8	133	132	0	32	31
2014	9	23	4	12	18	0.22	-0.02	0.764	0.033	0.03	0	43.9	43	74.4	134	131	0	32	31
2014	9	23	4	22	18	0.19	-0.046	0.768	0.033	0.03	0	43	43	75.7	131	131	0	31	31
2014	9	23	4	32	18	0.131	-0.082	0.768	0.039	0.036	0	42.6	43	74.8	131	130	0	32	30
2014	9	23	4	42	18	0.144	-0.007	0.768	0.039	0.036	0	43.4	42.6	74.8	132	130	0	31	31
2014	9	23	4	52	18	0.213	0.02	0.768	0.039	0.039	0	43.9	43.4	74.8	134	131	0	32	30
2014	9	23	5	2	18	0.203	-0.026	0.768	0.033	0.03	0	43	43.4	75.7	131	131	0	31	30
2014	9	23	5	12	18	0.266	-0.069	0.768	0.036	0.033	0	42.1	43	76.1	129	130	0	31	30
2014	9	23	5	22	18	0.213	-0.075	0.768	0.033	0.03	0	43	42.1	75.7	132	129	0	32	31
2014	9	23	5	32	18	0.167	0	0.768	0.036	0.033	0	43	42.1	77	131	129	0	31	31
2014	9	23	5	42	18	0.18	0	0.771	0.036	0.033	0	42.6	43	76.1	131	130	0	32	30
2014	9	23	5	52	18	0.22	-0.01	0.771	0.036	0.033	0	42.6	42.1	76.5	130	129	0	31	31
2014	9	23	6	2	18	0.2	-0.069	0.771	0.033	0.03	0	42.6	43	75.7	130	130	0	31	30
2014	9	23	6	12	18	0.174	-0.026	0.771	0.036	0.033	0	42.6	42.1	76.1	131	129	0	32	31
2014	9	23	6	22	18	0.233	0	0.771	0.036	0.033	0	42.1	42.1	77	129	128	0	31	30
2014	9	23	6	32	18	0.276	-0.046	0.771	0.033	0.03	0	42.1	43	76.5	129	130	0	31	30
2014	9	23	6	42	18	0.154	-0.039	0.771	0.03	0.03	0	42.1	41.7	77	130	128	0	32	31
2014	9	23	6	52	18	0.24	-0.066	0.771	0.039	0.036	0	41.3	41.3	76.5	128	126	0	32	30
2014	9	23	7	2	18	0.256	-0.052	0.771	0.039	0.036	0	42.1	40.9	76.5	129	126	0	31	31
2014	9	23	7	12	18	0.19	-0.033	0.771	0.039	0.036	0	41.7	40.4	76.5	128	125	0	31	31
2014	9	23	7	22	18	0.233	-0.062	0.771	0.033	0.03	0	41.7	41.3	76.1	128	126	0	31	30
2014	9	23	7	32	18	0.23	-0.01	0.771	0.033	0.03	0	41.3	39.6	77	127	123	0	31	31
2014	9	23	7	42	18	0.197	-0.108	0.771	0.036	0.033	0	40.4	39.6	77	125	123	0	31	31
2014	9	23	7	52	18	0.213	-0.059	0.771	0.036	0.033	0	41.3	40.4	76.5	127	124	0	31	30
2014	9	23	8	2	18	0.19	-0.052	0.771	0.033	0.03	0	40	40	77	125	124	0	32	31
2014	9	23	8	12	18	0.21	-0.016	0.774	0.033	0.03	0	41.3	40.4	77	127	125	0	31	31
2014	9	23	8	22	18	0.23	-0.033	0.774	0.033	0.03	0	40	40	76.5	125	124	0	32	31
2014	9	23	8	32	18	0.194	-0.079	0.774	0.033	0.03	0	39.6	39.6	77	124	123	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	8	42	18	0.223	-0.036	0.774	0.033	0.03	0	40.9	40	76.5	127	124	0	32	31
2014	9	23	8	52	18	0.256	-0.066	0.774	0.033	0.03	0	41.3	40	76.5	127	123	0	31	30
2014	9	23	9	2	18	0.2	-0.102	0.774	0.033	0.03	0	40	39.6	76.1	125	123	0	32	31
2014	9	23	9	12	18	0.276	-0.013	0.774	0.039	0.036	0	40.4	40.4	75.7	125	125	0	31	31
2014	9	23	9	22	18	0.266	-0.033	0.774	0.033	0.03	0	40.4	40.9	76.5	126	125	0	32	30
2014	9	23	9	32	18	0.223	0.026	0.774	0.039	0.036	0	41.3	41.7	75.7	127	128	0	31	31
2014	9	23	9	42	18	0.184	-0.013	0.774	0.033	0.033	0	42.6	43	75.3	131	130	0	32	30
2014	9	23	9	52	18	0.174	-0.036	0.774	0.036	0.033	0	43.4	44.3	75.7	133	134	0	32	31
2014	9	23	10	2	18	0.23	-0.02	0.774	0.03	0.03	0	44.7	46	74.4	136	138	0	32	31
2014	9	23	10	12	18	0.226	-0.02	0.774	0.033	0.03	0	46.9	47.7	73.1	141	142	0	32	31
2014	9	23	10	22	18	0.243	-0.069	0.774	0.036	0.033	0	46.4	47.7	74	140	142	0	32	31
2014	9	23	10	32	18	0.233	-0.023	0.774	0.033	0.03	0	46.4	49	73.5	141	144	0	33	30
2014	9	23	10	42	18	0.19	0	0.774	0.036	0.033	0	46.9	49	71.8	141	144	0	32	30
2014	9	23	10	52	18	0.279	0.03	0.774	0.033	0.03	0	48.2	49.5	73.1	144	146	0	32	31
2014	9	23	11	2	18	0.21	0	0.774	0.033	0.03	0	48.2	50.7	71.8	144	149	0	32	31
2014	9	23	11	12	18	0.217	0.016	0.774	0.033	0.03	0	49.9	50.7	72.2	147	149	0	31	31
2014	9	23	11	22	18	0.217	0.056	0.774	0.033	0.03	0	49.5	50.7	71.4	146	148	0	31	30
2014	9	23	11	32	18	0.23	0.02	0.774	0.033	0.03	0	49.9	51.2	71.4	147	149	0	31	30
2014	9	23	11	54	10	0.266	0.095	0.774	0.036	0.033	0	50.3	52	71	149	152	0	32	31
2014	9	23	12	4	10	0.236	0.036	0.774	0.033	0.03	0	50.7	52	71	149	152	0	31	31
2014	9	23	12	14	10	0.223	0.046	0.774	0.036	0.033	0	50.3	51.6	70.5	148	151	0	31	31
2014	9	23	12	24	10	0.213	0	0.774	0.033	0.03	0	51.2	52.5	70.5	150	152	0	31	30
2014	9	23	12	34	10	0.279	-0.007	0.774	0.036	0.033	0	51.2	52.9	71	151	153	0	32	30
2014	9	23	12	44	10	0.256	0.033	0.774	0.033	0.03	0	51.2	52.9	71.4	150	153	0	31	30
2014	9	23	12	54	10	0.266	0.098	0.774	0.033	0.03	0	51.6	53.3	71.4	151	154	0	31	30
2014	9	23	13	4	10	0.213	-0.026	0.774	0.033	0.03	0	51.6	53.3	68.8	151	154	0	31	30
2014	9	23	13	14	10	0.233	0.033	0.774	0.033	0.03	0	51.2	53.3	70.5	150	154	0	31	30
2014	9	23	13	24	10	0.236	0.043	0.774	0.033	0.03	0	52	53.3	70.5	152	154	0	31	30
2014	9	23	13	34	10	0.233	0.043	0.774	0.03	0.03	0	51.2	52.5	71.8	151	152	0	32	30
2014	9	23	13	44	10	0.184	0.016	0.774	0.03	0.03	0	51.2	52.5	70.5	150	153	0	31	31
2014	9	23	13	54	10	0.226	0.069	0.774	0.033	0.03	0	52	53.8	70.5	152	155	0	31	30
2014	9	23	14	4	10	0.285	0.079	0.774	0.039	0.036	0	52.5	53.3	71	152	154	0	30	30
2014	9	23	14	14	10	0.177	0.059	0.774	0.039	0.036	0	52	52.9	71	152	153	0	31	30
2014	9	23	14	24	10	0.282	0.052	0.774	0.039	0.036	0	52.5	53.3	71.8	153	154	0	31	30
2014	9	23	14	34	10	0.223	0.039	0.774	0.033	0.03	0	51.6	53.3	70.5	151	154	0	31	30
2014	9	23	14	44	10	0.269	0.105	0.774	0.03	0.03	0	52	53.3	70.5	152	154	0	31	30
2014	9	23	14	54	10	0.246	0.016	0.774	0.033	0.03	0	51.6	53.3	71	150	154	0	30	30
2014	9	23	15	4	10	0.299	0.026	0.774	0.033	0.03	0	50.3	53.3	71.4	148	154	0	31	30
2014	9	23	15	14	10	0.262	0.062	0.771	0.033	0.03	0	51.2	52.5	71.4	149	152	0	30	30
2014	9	23	15	24	10	0.243	0.075	0.771	0.039	0.036	0	50.7	52.9	71.4	149	153	0	31	30
2014	9	23	15	34	10	0.289	0.049	0.771	0.03	0.03	0	52.5	52.9	68.4	153	153	0	31	30
2014	9	23	15	44	10	0.22	0.03	0.771	0.033	0.03	0	51.6	52.5	70.1	149	152	0	29	30
2014	9	23	15	54	10	0.236	0.049	0.774	0.033	0.03	0	51.2	52	71	149	151	0	30	30
2014	9	23	16	4	10	0.2	0.043	0.774	0.033	0.03	0	49.9	52	70.5	147	151	0	31	30
2014	9	23	16	14	10	0.243	0.026	0.774	0.033	0.03	0	50.7	51.2	71	148	149	0	30	30
2014	9	23	16	24	10	0.295	0.069	0.771	0.033	0.03	0	48.2	50.3	71.4	143	147	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	16	34	10	0.253	0.013	0.774	0.033	0.03	0	49.5	49	73.1	146	144	0	31	30
2014	9	23	16	44	10	0.203	0.089	0.774	0.036	0.033	0	47.3	49.5	71.4	141	144	0	31	29
2014	9	23	16	54	10	0.262	-0.03	0.774	0.033	0.03	0	47.3	47.7	73.1	141	141	0	31	30
2014	9	23	17	4	10	0.23	0.069	0.774	0.036	0.033	0	45.2	46.4	72.7	136	138	0	31	30
2014	9	23	17	14	10	0.184	-0.013	0.774	0.033	0.03	0	44.3	45.2	74.4	134	134	0	31	29
2014	9	23	17	24	10	0.21	0.052	0.774	0.033	0.03	0	42.1	41.3	74.8	129	126	0	31	30
2014	9	23	17	34	10	0.18	0.062	0.774	0.039	0.036	0	41.3	40	75.3	126	123	0	30	30
2014	9	23	17	44	10	0.167	0.056	0.774	0.036	0.033	0	40	40	75.7	124	123	0	31	30
2014	9	23	17	54	10	0.184	-0.036	0.774	0.033	0.03	0	40.9	40.4	75.7	126	124	0	31	30
2014	9	23	18	4	10	0.21	0.128	0.774	0.033	0.03	0	40.4	39.6	77	124	122	0	30	30
2014	9	23	18	14	10	0.2	0.033	0.774	0.036	0.033	0	40	39.6	77	123	121	0	30	29
2014	9	23	18	24	10	0.21	-0.02	0.774	0.036	0.033	0	39.6	38.7	76.5	123	121	0	31	31
2014	9	23	18	34	10	0.22	-0.01	0.774	0.033	0.03	0	42.1	41.3	76.1	128	126	0	30	30
2014	9	23	18	44	10	0.2	0.007	0.774	0.033	0.03	0	40.4	40.4	77	124	123	0	30	29
2014	9	23	18	54	10	0.213	0	0.774	0.043	0.039	0	40	40	77	124	123	0	31	30
2014	9	23	19	4	10	0.223	0	0.774	0.039	0.036	0	40.4	40.4	76.1	125	124	0	31	30
2014	9	23	19	14	10	0.161	0.016	0.774	0.036	0.033	0	41.7	40.9	77	127	125	0	30	30
2014	9	23	19	24	10	0.22	-0.036	0.774	0.033	0.03	0	41.3	41.3	76.1	127	126	0	31	30
2014	9	23	19	34	10	0.18	-0.036	0.774	0.039	0.036	0	42.1	42.1	76.1	128	128	0	30	30
2014	9	23	19	44	10	0.292	0	0.774	0.033	0.03	0	42.6	41.3	77	130	126	0	31	30
2014	9	23	19	54	10	0.23	-0.062	0.778	0.036	0.033	0	41.7	42.1	76.1	129	128	0	32	30
2014	9	23	20	4	10	0.2	-0.039	0.778	0.043	0.039	0	43.4	41.7	77	131	127	0	30	30
2014	9	23	20	14	10	0.23	0	0.774	0.033	0.03	0	44.3	43.9	75.7	134	132	0	31	30
2014	9	23	20	24	10	0.217	-0.007	0.778	0.043	0.043	0	43	43	75.7	131	130	0	31	30
2014	9	23	20	34	10	0.213	-0.062	0.778	0.033	0.03	0	42.6	43	77	130	130	0	31	30
2014	9	23	20	44	10	0.207	-0.013	0.778	0.033	0.03	0	43.9	43.4	75.7	132	131	0	30	30
2014	9	23	20	54	10	0.187	-0.059	0.778	0.033	0.03	0	43.4	43.4	76.1	132	131	0	31	30
2014	9	23	21	4	10	0.23	-0.02	0.778	0.036	0.033	0	42.6	42.6	76.1	130	129	0	31	30
2014	9	23	21	14	10	0.217	-0.039	0.778	0.036	0.033	0	43	42.6	76.1	130	129	0	30	30
2014	9	23	21	24	10	0.272	0.052	0.778	0.036	0.033	0	43	43.4	75.7	131	131	0	31	30
2014	9	23	21	34	10	0.217	0.039	0.778	0.036	0.033	0	43.4	43.4	75.7	132	131	0	31	30
2014	9	23	21	44	10	0.279	-0.102	0.778	0.039	0.039	0	44.7	43	75.3	134	130	0	30	30
2014	9	23	21	54	10	0.184	-0.046	0.778	0.033	0.03	0	43	43	76.1	131	130	0	31	30
2014	9	23	22	4	10	0.24	-0.039	0.774	0.036	0.033	0	44.3	43.9	75.3	134	132	0	31	30
2014	9	23	22	14	10	0.266	-0.046	0.774	0.036	0.033	0	47.3	46.4	72.2	141	138	0	31	30
2014	9	23	22	24	10	0.2	-0.013	0.774	0.036	0.033	0	46.4	46	73.1	139	137	0	31	30
2014	9	23	22	34	10	0.184	0.036	0.774	0.039	0.036	0	46.9	45.6	72.7	140	136	0	31	30
2014	9	23	22	44	10	0.203	0.075	0.774	0.039	0.036	0	47.3	46.4	71.8	141	138	0	31	30
2014	9	23	22	54	10	0.203	-0.026	0.774	0.036	0.033	0	47.7	46	71.8	141	137	0	30	30
2014	9	23	23	4	10	0.207	0.062	0.774	0.036	0.033	0	46.4	46	73.5	139	137	0	31	30
2014	9	23	23	14	10	0.213	0	0.774	0.039	0.036	0	46.9	46	72.7	140	137	0	31	30
2014	9	23	23	24	10	0.226	-0.007	0.774	0.033	0.03	0	46	44.7	73.5	137	134	0	30	30
2014	9	23	23	34	10	0.22	0.02	0.778	0.036	0.033	0	46.9	46	71.8	141	137	0	32	30
2014	9	23	23	44	10	0.285	0.033	0.774	0.046	0.043	0	50.3	48.6	68.8	148	144	0	31	31
2014	9	23	23	54	10	0.276	0.075	0.774	0.033	0.03	0	53.3	51.2	66.7	155	150	0	31	31
2014	9	24	0	4	10	0.24	0	0.774	0.033	0.03	0	50.7	49.5	68.8	150	145	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	0	14	10	0.23	0.02	0.774	0.033	0.03	0	48.2	46.9	71	143	139	0	31	30
2014	9	24	0	24	10	0.161	0	0.778	0.033	0.03	0	47.3	46.9	71.8	141	139	0	31	30
2014	9	24	0	34	10	0.233	0.03	0.778	0.033	0.03	0	47.7	46.4	72.2	142	138	0	31	30
2014	9	24	0	44	10	0.233	-0.046	0.778	0.039	0.036	0	46.4	45.2	71.4	140	136	0	32	31
2014	9	24	0	54	10	0.226	-0.036	0.778	0.03	0.026	0	45.2	44.3	73.1	136	134	0	31	31
2014	9	24	1	4	10	0.243	0.007	0.774	0.036	0.033	0	49	47.7	70.1	146	142	0	32	31
2014	9	24	1	14	10	0.243	0.033	0.774	0.039	0.036	0	49	47.7	69.7	145	142	0	31	31
2014	9	24	1	24	10	0.22	-0.026	0.774	0.033	0.03	0	46.4	45.6	71.4	140	137	0	32	31
2014	9	24	1	34	10	0.226	0.003	0.778	0.039	0.036	0	44.3	43.9	73.1	135	133	0	32	31
2014	9	24	1	44	10	0.262	0.043	0.774	0.043	0.039	0	48.2	46.9	69.7	144	140	0	32	31
2014	9	24	1	54	10	0.322	0.039	0.774	0.033	0.03	0	48.6	47.3	69.7	144	141	0	31	31
2014	9	24	2	4	10	0.236	0.016	0.778	0.039	0.039	0	47.7	46.4	70.5	142	139	0	31	31
2014	9	24	2	14	10	0.2	0.007	0.778	0.036	0.033	0	48.6	46.9	69.2	144	139	0	31	30
2014	9	24	2	24	10	0.24	0	0.778	0.039	0.039	0	48.2	46.9	69.7	144	140	0	32	31
2014	9	24	2	34	10	0.295	0.066	0.778	0.033	0.03	0	46	44.3	71.4	138	134	0	31	31
2014	9	24	2	44	10	0.282	0.039	0.778	0.036	0.033	0	46.9	45.6	71.4	140	137	0	31	31
2014	9	24	2	54	10	0.207	0.003	0.778	0.039	0.036	0	47.3	46.4	70.5	142	138	0	32	30
2014	9	24	3	4	10	0.246	-0.059	0.778	0.036	0.033	0	46	45.2	71.4	139	136	0	32	31
2014	9	24	3	14	10	0.24	-0.095	0.778	0.033	0.03	0	46.4	45.6	71	140	137	0	32	31
2014	9	24	3	24	10	0.213	0	0.778	0.036	0.033	0	46	45.6	71	139	137	0	32	31
2014	9	24	3	34	10	0.226	-0.03	0.778	0.039	0.039	0	45.2	43.4	72.2	136	131	0	31	30
2014	9	24	3	44	10	0.24	0.062	0.778	0.033	0.03	0	44.7	44.7	71	136	135	0	32	31
2014	9	24	3	54	10	0.246	-0.066	0.778	0.033	0.03	0	45.6	45.2	71.8	137	136	0	31	31
2014	9	24	4	4	10	0.213	-0.033	0.778	0.046	0.043	0	43	42.6	73.1	132	130	0	32	31
2014	9	24	4	14	10	0.203	-0.02	0.778	0.033	0.03	0	42.6	42.6	74	131	130	0	32	31
2014	9	24	4	24	10	0.331	-0.023	0.778	0.033	0.033	0	43	42.1	72.7	131	128	0	31	30
2014	9	24	4	34	10	0.21	0	0.778	0.039	0.036	0	42.6	42.6	73.5	130	129	0	31	30
2014	9	24	4	44	10	0.272	0	0.778	0.039	0.036	0	46.9	45.6	70.1	141	137	0	32	31
2014	9	24	4	54	10	0.187	0.03	0.778	0.033	0.03	0	45.2	44.3	71.8	136	133	0	31	30
2014	9	24	5	4	10	0.171	-0.046	0.778	0.036	0.033	0	43.4	43.4	72.2	133	132	0	32	31
2014	9	24	5	14	10	0.256	-0.066	0.778	0.036	0.033	0	44.7	43.4	71.8	135	133	0	31	32
2014	9	24	5	24	10	0.269	0.026	0.778	0.036	0.033	0	43	43	72.7	132	130	0	32	30
2014	9	24	5	34	10	0.24	-0.049	0.778	0.036	0.033	0	43.4	43	72.2	133	131	0	32	31
2014	9	24	5	44	10	0.276	-0.023	0.778	0.033	0.03	0	43	43.4	71.4	132	131	0	32	30
2014	9	24	5	54	10	0.177	-0.089	0.778	0.03	0.03	0	43.4	43	72.2	133	131	0	32	31
2014	9	24	6	4	10	0.272	0.016	0.781	0.033	0.03	0	42.6	42.6	72.2	130	130	0	31	31
2014	9	24	6	14	10	0.249	-0.069	0.778	0.039	0.036	0	43	41.7	71.8	132	128	0	32	31
2014	9	24	6	24	10	0.167	-0.052	0.778	0.033	0.03	0	42.6	42.1	72.7	131	129	0	32	31
2014	9	24	6	34	10	0.243	-0.085	0.778	0.033	0.03	0	42.1	42.6	73.1	130	129	0	32	30
2014	9	24	6	44	10	0.194	-0.052	0.781	0.036	0.033	0	42.1	41.3	72.2	129	127	0	31	31
2014	9	24	6	54	10	0.246	-0.069	0.781	0.036	0.033	0	40.9	40.4	72.7	127	125	0	32	31
2014	9	24	7	4	10	0.279	-0.01	0.781	0.033	0.03	0	40	40.4	72.7	125	125	0	32	31
2014	9	24	7	14	10	0.243	-0.085	0.781	0.033	0.03	0	40.4	40.9	72.2	125	126	0	31	31
2014	9	24	7	24	10	0.22	-0.039	0.781	0.033	0.03	0	40.4	39.1	72.7	126	122	0	32	31
2014	9	24	7	34	10	0.22	-0.026	0.781	0.033	0.03	0	39.6	39.1	72.7	124	122	0	32	31
2014	9	24	7	44	10	0.253	-0.013	0.781	0.033	0.03	0	40	40	72.7	125	124	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	7	54	10	0.236	-0.049	0.784	0.033	0.03	0	40	39.6	72.2	124	123	0	31	31
2014	9	24	8	4	10	0.299	0.033	0.784	0.033	0.03	0	41.3	40.9	72.7	127	126	0	31	31
2014	9	24	8	14	10	0.223	-0.016	0.784	0.039	0.036	0	40.4	40	73.1	126	124	0	32	31
2014	9	24	8	24	10	0.253	0	0.787	0.033	0.03	0	39.6	40.4	73.1	124	124	0	32	30
2014	9	24	8	34	10	0.259	0.016	0.787	0.039	0.036	0	40	40.4	72.7	126	124	0	33	30
2014	9	24	8	44	10	0.177	-0.049	0.787	0.036	0.033	0	40.4	40.9	72.7	126	126	0	32	31
2014	9	24	8	54	10	0.24	-0.036	0.791	0.039	0.036	0	40	40.9	72.2	125	126	0	32	31
2014	9	24	9	4	10	0.299	-0.046	0.791	0.033	0.03	0	40	40	72.7	125	124	0	32	31
2014	9	24	9	14	10	0.276	-0.062	0.791	0.033	0.03	0	39.6	40.4	72.2	125	124	0	33	30
2014	9	24	9	24	10	0.187	0	0.791	0.039	0.036	0	40	40.4	72.2	126	125	0	33	31
2014	9	24	9	34	10	0.259	-0.056	0.791	0.039	0.036	0	40	40.9	72.7	125	126	0	32	31
2014	9	24	9	44	10	0.197	-0.003	0.797	0.033	0.03	0	43	42.6	71.8	131	130	0	31	31
2014	9	24	9	54	10	0.23	-0.049	0.797	0.033	0.03	0	44.7	45.2	72.7	136	136	0	32	31
2014	9	24	10	4	10	0.292	0.03	0.797	0.036	0.033	0	47.3	46.4	70.1	142	139	0	32	31
2014	9	24	10	14	10	0.213	-0.01	0.801	0.033	0.03	0	46.4	46.9	73.5	140	140	0	32	31
2014	9	24	10	24	10	0.249	0.023	0.801	0.033	0.03	0	46.9	47.3	73.1	140	141	0	31	31
2014	9	24	10	34	10	0.217	-0.016	0.797	0.03	0.03	0	47.7	47.7	72.7	143	142	0	32	31
2014	9	24	10	44	10	0.302	0.01	0.797	0.033	0.03	0	48.6	47.3	71.8	144	141	0	31	31
2014	9	24	10	54	10	0.217	0.039	0.801	0.033	0.03	0	48.2	47.7	71.4	144	142	0	32	31
2014	9	24	11	4	10	0.226	0.03	0.801	0.033	0.03	0	49.5	49	70.5	146	144	0	31	30
2014	9	24	11	14	10	0.24	0.003	0.801	0.036	0.033	0	51.2	49.5	69.7	150	146	0	31	31
2014	9	24	11	24	10	0.22	0.026	0.801	0.033	0.03	0	49	49	71	146	145	0	32	31
2014	9	24	11	34	10	0.21	0.049	0.801	0.036	0.033	0	52.5	51.2	71	154	150	0	32	31
2014	9	24	11	44	10	0.272	0.016	0.801	0.033	0.03	0	51.2	51.6	70.5	150	151	0	31	31
2014	9	24	11	54	10	0.207	0.03	0.801	0.033	0.03	0	52	50.7	71	152	149	0	31	31
2014	9	24	12	4	10	0.236	0.052	0.801	0.039	0.036	0	52	50.7	69.7	153	150	0	32	32
2014	9	24	12	14	10	0.266	0.007	0.801	0.033	0.03	0	52	51.6	68.8	152	151	0	31	31
2014	9	24	12	24	10	0.236	0.092	0.801	0.033	0.03	0	51.2	52.5	69.2	150	152	0	31	30
2014	9	24	12	34	10	0.262	0.026	0.801	0.036	0.033	0	52.5	52.5	68.8	153	152	0	31	30
2014	9	24	12	44	10	0.279	0	0.801	0.033	0.03	0	52.5	52.9	68.8	153	153	0	31	30
2014	9	24	12	54	10	0.2	0.007	0.801	0.033	0.03	0	52.5	52.5	67.9	153	153	0	31	31
2014	9	24	13	4	10	0.262	0.033	0.797	0.033	0.03	0	53.3	53.3	66.7	155	155	0	31	31
2014	9	24	13	14	10	0.272	-0.03	0.801	0.033	0.03	0	52.9	52.9	67.9	154	154	0	31	31
2014	9	24	13	24	10	0.253	-0.003	0.797	0.033	0.03	0	53.3	53.3	66.7	155	154	0	31	30
2014	9	24	13	34	10	0.295	0.03	0.801	0.033	0.03	0	52.5	53.3	68.4	154	154	0	32	30
2014	9	24	13	44	10	0.295	0.007	0.797	0.033	0.033	0	52.5	53.3	67.1	153	154	0	31	30
2014	9	24	13	54	10	0.269	0.075	0.797	0.03	0.03	0	52	52.9	67.9	152	153	0	31	30
2014	9	24	14	4	10	0.256	0.079	0.794	0.043	0.043	0	53.3	53.3	67.9	154	154	0	30	30
2014	9	24	14	14	10	0.207	0.072	0.797	0.033	0.03	0	52.9	53.3	67.5	154	154	0	31	30
2014	9	24	14	24	10	0.266	0.059	0.797	0.033	0.03	0	53.3	52.5	68.4	155	152	0	31	30
2014	9	24	14	34	10	0.289	0.033	0.797	0.033	0.03	0	52.5	52.5	67.5	153	152	0	31	30
2014	9	24	14	44	10	0.253	0.01	0.794	0.033	0.03	0	52.9	53.3	69.2	153	154	0	30	30
2014	9	24	14	54	10	0.256	0.052	0.794	0.039	0.036	0	52.9	52.9	67.1	153	153	0	30	30
2014	9	24	15	4	10	0.269	0.102	0.794	0.033	0.03	0	52	52.9	68.8	152	153	0	31	30
2014	9	24	15	14	10	0.223	0.062	0.797	0.043	0.039	0	52.5	52	67.9	153	151	0	31	30
2014	9	24	15	24	10	0.305	0	0.797	0.036	0.033	0	52.5	52	67.9	152	151	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	15	34	10	0.246	0.072	0.794	0.036	0.033	0	52	52	67.1	152	151	0	31	30
2014	9	24	15	44	10	0.22	0.085	0.794	0.036	0.033	0	52	51.6	67.9	152	150	0	31	30
2014	9	24	15	54	10	0.292	0.026	0.794	0.039	0.036	0	52.5	51.6	68.4	153	150	0	31	30
2014	9	24	16	4	10	0.308	0.056	0.794	0.033	0.03	0	51.6	51.2	67.5	150	149	0	30	30
2014	9	24	16	14	10	0.295	0.033	0.794	0.033	0.03	0	50.7	49.5	67.9	150	146	0	32	31
2014	9	24	16	24	10	0.259	0.02	0.794	0.036	0.033	0	50.7	50.3	68.8	149	147	0	31	30
2014	9	24	16	34	10	0.256	0.085	0.794	0.033	0.03	0	49.9	48.2	68.8	147	142	0	31	30
2014	9	24	16	44	10	0.272	0.059	0.791	0.036	0.033	0	49	47.3	68.8	145	139	0	31	29
2014	9	24	16	54	10	0.246	0.085	0.794	0.033	0.03	0	49.9	47.3	69.7	147	140	0	31	30
2014	9	24	17	4	10	0.23	0.062	0.791	0.033	0.03	0	49	47.3	69.7	145	140	0	31	30
2014	9	24	17	14	10	0.246	0.062	0.794	0.036	0.033	0	48.2	46	69.7	143	137	0	31	30
2014	9	24	17	24	10	0.22	0.089	0.791	0.03	0.03	0	46	43.4	71	138	131	0	31	30
2014	9	24	17	34	10	0.256	0.079	0.791	0.036	0.033	0	43.4	43	71.4	132	130	0	31	30
2014	9	24	17	44	10	0.256	0.161	0.791	0.036	0.033	0	43	42.6	71.8	131	129	0	31	30
2014	9	24	17	54	10	0.223	0.102	0.791	0.043	0.039	0	42.6	41.3	71.8	130	126	0	31	30
2014	9	24	18	4	10	0.213	0.056	0.791	0.033	0.03	0	42.1	41.3	71.8	128	126	0	30	30
2014	9	24	18	14	10	0.289	0.105	0.791	0.036	0.033	0	42.1	41.7	72.2	128	127	0	30	30
2014	9	24	18	24	10	0.325	0.033	0.794	0.039	0.036	0	43.4	42.6	71.8	131	129	0	30	30
2014	9	24	18	34	10	0.246	0.036	0.794	0.036	0.033	0	41.3	42.1	72.2	127	128	0	31	30
2014	9	24	18	44	10	0.249	0.036	0.791	0.036	0.033	0	41.3	40.9	72.7	126	125	0	30	30
2014	9	24	18	54	10	0.289	-0.02	0.794	0.039	0.036	0	41.7	40.9	72.7	127	125	0	30	30
2014	9	24	19	4	10	0.24	0.03	0.794	0.033	0.03	0	41.3	41.3	72.7	127	125	0	31	29
2014	9	24	19	14	10	0.23	-0.03	0.794	0.033	0.03	0	41.7	41.3	72.7	128	126	0	31	30
2014	9	24	19	24	10	0.21	0.036	0.797	0.03	0.026	0	41.7	41.7	71.8	128	128	0	31	31
2014	9	24	19	34	10	0.253	-0.02	0.797	0.033	0.03	0	41.3	41.7	72.7	127	127	0	31	30
2014	9	24	19	44	10	0.253	0.066	0.801	0.033	0.03	0	42.1	42.6	71.8	129	129	0	31	30
2014	9	24	19	54	10	0.184	-0.007	0.801	0.036	0.033	0	41.7	42.1	72.7	128	128	0	31	30
2014	9	24	20	4	10	0.23	-0.056	0.801	0.033	0.03	0	42.6	42.1	72.2	130	128	0	31	30
2014	9	24	20	14	10	0.203	-0.003	0.801	0.033	0.03	0	45.2	43	72.2	135	130	0	30	30
2014	9	24	20	24	10	0.315	-0.01	0.801	0.036	0.033	0	44.7	43.4	71.8	134	131	0	30	30
2014	9	24	20	34	10	0.276	-0.01	0.801	0.039	0.036	0	44.7	43.4	72.2	135	131	0	31	30
2014	9	24	20	44	10	0.226	-0.049	0.801	0.036	0.033	0	45.6	44.7	71.4	137	134	0	31	30
2014	9	24	20	54	10	0.315	-0.069	0.801	0.033	0.03	0	45.2	44.3	71	136	133	0	31	30
2014	9	24	21	4	10	0.243	-0.052	0.801	0.036	0.033	0	44.3	43.4	71.8	134	131	0	31	30
2014	9	24	21	14	10	0.269	-0.049	0.801	0.039	0.036	0	45.6	45.2	71.4	136	135	0	30	30
2014	9	24	21	24	10	0.276	-0.033	0.801	0.036	0.033	0	46.4	45.6	71.4	139	136	0	31	30
2014	9	24	21	34	10	0.279	0.072	0.801	0.039	0.036	0	45.2	43.9	73.1	135	132	0	30	30
2014	9	24	21	44	10	0.217	0.007	0.801	0.046	0.043	0	46	45.6	71	138	136	0	31	30
2014	9	24	21	54	10	0.249	-0.007	0.801	0.039	0.036	0	46.4	46	70.1	139	137	0	31	30
2014	9	24	22	4	10	0.207	0	0.801	0.046	0.043	0	46.9	45.6	71	140	136	0	31	30
2014	9	24	22	14	10	0.246	-0.036	0.801	0.033	0.03	0	46	45.6	71.8	139	136	0	32	30
2014	9	24	22	24	10	0.344	0.016	0.801	0.039	0.039	0	46	44.7	72.2	138	134	0	31	30
2014	9	24	22	34	10	0.23	0.016	0.804	0.036	0.033	0	44.3	43	74	134	130	0	31	30
2014	9	24	22	44	10	0.272	-0.039	0.804	0.043	0.039	0	46	44.7	72.2	138	135	0	31	31
2014	9	24	22	54	10	0.249	-0.023	0.801	0.033	0.03	0	46.9	46.4	71	140	138	0	31	30
2014	9	24	23	4	10	0.21	-0.075	0.804	0.039	0.036	0	45.6	44.3	72.7	137	134	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	23	14	10	0.279	0.013	0.804	0.033	0.03	0	44.7	43.9	74.4	135	132	0	31	30
2014	9	24	23	24	10	0.2	-0.052	0.804	0.036	0.033	0	45.6	44.3	73.1	136	134	0	30	31
2014	9	24	23	34	10	0.22	-0.02	0.804	0.036	0.033	0	45.2	44.7	72.7	136	134	0	31	30
2014	9	24	23	44	10	0.259	-0.02	0.804	0.033	0.033	0	45.6	45.2	73.5	137	135	0	31	30
2014	9	24	23	54	10	0.22	-0.052	0.804	0.036	0.033	0	46.4	45.6	72.2	139	136	0	31	30
2014	9	25	0	4	10	0.266	-0.069	0.804	0.039	0.039	0	48.2	46.9	70.1	143	140	0	31	31
2014	9	25	0	14	10	0.249	-0.023	0.804	0.033	0.03	0	47.3	46	71	142	138	0	32	31
2014	9	25	0	24	10	0.299	0.023	0.804	0.033	0.03	0	46	44.7	72.2	138	135	0	31	31
2014	9	25	0	34	10	0.295	-0.052	0.804	0.033	0.03	0	47.7	46.9	71	142	139	0	31	30
2014	9	25	0	44	10	0.19	-0.059	0.804	0.039	0.036	0	45.2	44.3	73.1	136	134	0	31	31
2014	9	25	0	54	10	0.262	0.02	0.804	0.039	0.036	0	45.6	44.7	72.2	138	134	0	32	30
2014	9	25	1	4	10	0.24	-0.039	0.804	0.039	0.036	0	43.4	43	74.8	132	130	0	31	30
2014	9	25	1	14	10	0.325	-0.016	0.804	0.039	0.039	0	43.4	43	74.8	132	130	0	31	30
2014	9	25	1	24	10	0.243	0.052	0.804	0.036	0.033	0	43.9	43	74.4	133	131	0	31	31
2014	9	25	1	34	10	0.279	-0.02	0.804	0.036	0.033	0	44.7	43.4	73.1	135	133	0	31	32
2014	9	25	1	44	10	0.285	-0.049	0.804	0.039	0.039	0	47.7	46	70.1	142	138	0	31	31
2014	9	25	1	54	10	0.259	0	0.804	0.039	0.039	0	46.9	46	71.4	141	137	0	32	30
2014	9	25	2	4	10	0.226	0	0.804	0.039	0.036	0	48.6	47.7	70.1	144	141	0	31	30
2014	9	25	2	14	10	0.223	-0.079	0.804	0.039	0.036	0	46.4	45.6	71.8	140	137	0	32	31
2014	9	25	2	24	10	0.308	-0.036	0.804	0.039	0.036	0	49	47.7	70.5	145	142	0	31	31
2014	9	25	2	34	10	0.203	-0.02	0.804	0.043	0.039	0	49.9	48.6	69.7	147	144	0	31	31
2014	9	25	2	44	10	0.318	-0.02	0.807	0.036	0.033	0	47.7	46.9	71.8	142	139	0	31	30
2014	9	25	2	54	10	0.256	-0.007	0.804	0.039	0.036	0	49	47.7	70.5	146	142	0	32	31
2014	9	25	3	4	10	0.24	0	0.804	0.039	0.036	0	47.7	46.9	71.8	143	140	0	32	31
2014	9	25	3	14	10	0.292	-0.036	0.804	0.033	0.03	0	46.4	45.2	72.7	139	136	0	31	31
2014	9	25	3	24	10	0.226	0.016	0.807	0.039	0.039	0	45.6	44.7	74.8	137	134	0	31	30
2014	9	25	3	34	10	0.266	-0.036	0.804	0.039	0.039	0	50.7	49	68.4	150	145	0	32	31
2014	9	25	3	44	10	0.22	-0.003	0.807	0.036	0.033	0	47.7	46.9	71.8	143	140	0	32	31
2014	9	25	3	54	10	0.256	-0.003	0.807	0.039	0.036	0	44.7	43.9	74.8	136	133	0	32	31
2014	9	25	4	4	10	0.236	0.01	0.807	0.036	0.033	0	45.2	44.3	74.8	137	134	0	32	31
2014	9	25	4	14	10	0.187	-0.036	0.807	0.039	0.036	0	43.9	44.3	75.7	134	133	0	32	30
2014	9	25	4	24	10	0.259	-0.062	0.807	0.039	0.039	0	46	45.2	74	138	136	0	31	31
2014	9	25	4	34	10	0.292	-0.01	0.807	0.033	0.03	0	45.2	44.3	74.8	136	134	0	31	31
2014	9	25	4	44	10	0.243	0	0.807	0.039	0.036	0	43.9	43	75.3	133	131	0	31	31
2014	9	25	4	54	10	0.23	-0.033	0.807	0.036	0.033	0	43.4	42.6	76.1	132	129	0	31	30
2014	9	25	5	4	10	0.226	0.013	0.807	0.033	0.03	0	43.4	43	76.1	132	131	0	31	31
2014	9	25	5	14	10	0.167	0.03	0.807	0.036	0.033	0	43.4	43	75.7	133	131	0	32	31
2014	9	25	5	24	10	0.269	0.003	0.807	0.039	0.036	0	43	43	75.7	131	130	0	31	30
2014	9	25	5	34	10	0.223	0	0.807	0.039	0.036	0	43.4	42.1	76.5	132	129	0	31	31
2014	9	25	5	44	10	0.256	-0.085	0.807	0.033	0.03	0	42.6	42.6	76.5	130	129	0	31	30
2014	9	25	5	54	10	0.256	0.016	0.807	0.036	0.033	0	42.6	42.6	75.7	131	129	0	32	30
2014	9	25	6	4	10	0.223	-0.043	0.807	0.039	0.036	0	41.7	42.1	77	129	129	0	32	31
2014	9	25	6	14	10	0.302	0.02	0.807	0.033	0.03	0	42.1	42.1	76.1	129	129	0	31	31
2014	9	25	6	24	10	0.171	0.01	0.807	0.039	0.036	0	41.3	41.7	77	128	127	0	32	30
2014	9	25	6	34	10	0.256	-0.023	0.807	0.039	0.039	0	41.3	42.1	77.4	128	129	0	32	31
2014	9	25	6	44	10	0.233	-0.023	0.807	0.036	0.033	0	40.4	41.3	77.4	126	126	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	6	54	10	0.302	-0.069	0.807	0.036	0.033	0	41.3	40.4	77	127	125	0	31	31
2014	9	25	7	4	10	0.177	-0.079	0.807	0.033	0.03	0	40.4	39.6	77.8	125	123	0	31	31
2014	9	25	7	14	10	0.23	0.036	0.807	0.033	0.03	0	40.9	40.9	77.4	127	126	0	32	31
2014	9	25	7	24	10	0.23	0.102	0.807	0.036	0.033	0	40.4	40	77.4	125	123	0	31	30
2014	9	25	7	34	10	0.223	-0.059	0.807	0.033	0.03	0	40.4	40.4	77.4	126	124	0	32	30
2014	9	25	7	44	10	0.272	-0.043	0.807	0.039	0.036	0	40.4	40.4	77.8	126	125	0	32	31
2014	9	25	7	54	10	0.249	0	0.807	0.036	0.033	0	40	40.4	77.8	124	125	0	31	31
2014	9	25	8	4	10	0.233	0	0.807	0.033	0.03	0	40	40	77.4	125	124	0	32	31
2014	9	25	8	14	10	0.177	-0.062	0.807	0.033	0.03	0	40.4	40.4	77.8	126	125	0	32	31
2014	9	25	8	24	10	0.23	-0.01	0.807	0.036	0.033	0	39.6	40.4	77.8	124	125	0	32	31
2014	9	25	8	34	10	0.236	-0.007	0.807	0.036	0.033	0	40.4	40	77.8	125	124	0	31	31
2014	9	25	8	44	10	0.207	-0.082	0.807	0.033	0.033	0	40.4	40.4	77.4	125	125	0	31	31
2014	9	25	8	54	10	0.236	-0.007	0.807	0.036	0.033	0	40.9	40	77.4	126	124	0	31	31
2014	9	25	9	4	10	0.249	-0.023	0.807	0.036	0.033	0	41.7	41.3	77	128	127	0	31	31
2014	9	25	9	14	10	0.259	-0.039	0.804	0.033	0.03	0	42.6	42.1	74.8	131	129	0	32	31
2014	9	25	9	24	10	0.253	-0.052	0.804	0.036	0.033	0	44.3	43.9	72.2	135	133	0	32	31
2014	9	25	9	34	10	0.256	-0.046	0.804	0.036	0.033	0	47.3	47.3	69.2	141	141	0	31	31
2014	9	25	9	44	10	0.289	0.007	0.804	0.039	0.039	0	52.5	51.2	64.9	153	149	0	31	30
2014	9	25	9	54	10	0.308	-0.023	0.804	0.039	0.036	0	51.6	50.3	65.4	151	148	0	31	31
2014	9	25	10	4	10	0.236	0.043	0.804	0.039	0.036	0	53.8	52.5	61.9	156	153	0	31	31
2014	9	25	10	14	10	0.24	0	0.804	0.036	0.033	0	58.9	57.6	57.6	169	165	0	32	31
2014	9	25	10	24	10	0.292	0.033	0.801	0.049	0.046	0	57.2	55.9	59.3	164	161	0	31	31
2014	9	25	10	34	10	0.282	0.128	0.804	0.039	0.036	0	54.6	53.8	61.9	159	156	0	32	31
2014	9	25	10	44	10	0.259	0.03	0.804	0.036	0.033	0	54.2	53.8	60.6	157	155	0	31	30
2014	9	25	10	54	10	0.299	0.023	0.804	0.039	0.036	0	52.9	52.9	64.1	155	153	0	32	30
2014	9	25	11	4	10	0.256	0.03	0.804	0.033	0.03	0	55	54.2	61.9	160	157	0	32	31
2014	9	25	11	14	10	0.266	0.062	0.804	0.036	0.033	0	55.5	55.9	60.2	160	160	0	31	30
2014	9	25	11	24	10	0.269	-0.043	0.804	0.036	0.033	0	55.9	55.5	59.8	161	159	0	31	30
2014	9	25	11	34	10	0.289	0.033	0.804	0.036	0.033	0	57.2	56.3	61.5	164	162	0	31	31
2014	9	25	11	44	10	0.246	0.043	0.804	0.036	0.033	0	55	55	62.8	159	159	0	31	31
2014	9	25	11	54	10	0.381	0.026	0.801	0.033	0.03	0	55.9	55.5	59.3	161	160	0	31	31
2014	9	25	12	4	10	0.302	-0.003	0.804	0.039	0.039	0	54.6	55	63.6	158	158	0	31	30
2014	9	25	12	14	10	0.299	0.016	0.804	0.039	0.036	0	55	55	61.9	159	158	0	31	30
2014	9	25	12	24	10	0.272	0.128	0.801	0.033	0.03	0	55	54.6	61.1	159	158	0	31	31
2014	9	25	12	34	10	0.289	0.069	0.804	0.033	0.03	0	54.2	54.6	63.6	158	157	0	32	30
2014	9	25	12	44	10	0.335	0.02	0.801	0.033	0.03	0	55.9	55	61.1	161	158	0	31	30
2014	9	25	12	54	10	0.23	0.043	0.801	0.033	0.03	0	54.6	55	62.8	158	158	0	31	30
2014	9	25	13	4	10	0.236	0.108	0.801	0.033	0.03	0	54.6	55	63.2	158	158	0	31	30
2014	9	25	13	14	10	0.23	0.062	0.797	0.039	0.036	0	55.9	55.5	60.6	161	159	0	31	30
2014	9	25	13	24	10	0.305	0.135	0.797	0.039	0.036	0	55.9	55.5	60.6	162	159	0	32	30
2014	9	25	13	34	10	0.243	0.003	0.797	0.036	0.033	0	55.9	55.9	59.8	161	160	0	31	30
2014	9	25	13	44	10	0.259	0.036	0.794	0.036	0.033	0	56.3	55.9	60.2	162	161	0	31	31
2014	9	25	13	54	10	0.282	0.092	0.794	0.046	0.043	0	56.8	56.3	59.3	163	162	0	31	31
2014	9	25	14	4	10	0.354	0.115	0.797	0.033	0.03	0	54.6	55.5	61.9	159	159	0	32	30
2014	9	25	14	14	10	0.226	0.098	0.794	0.033	0.03	0	54.6	55.5	61.5	158	159	0	31	30
2014	9	25	14	24	10	0.285	0.092	0.791	0.036	0.033	0	55.9	55.5	61.5	161	159	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	14	34	10	0.233	0.141	0.794	0.033	0.03	0	55.5	55	61.5	159	158	0	30	30
2014	9	25	14	44	10	0.276	0.066	0.791	0.033	0.03	0	55.9	55.9	60.6	161	160	0	31	30
2014	9	25	14	54	10	0.249	0.085	0.791	0.039	0.036	0	55.5	55.5	60.6	160	159	0	31	30
2014	9	25	15	4	10	0.276	0.069	0.787	0.036	0.033	0	55.9	55.5	60.2	160	159	0	30	30
2014	9	25	15	14	10	0.289	0.095	0.791	0.033	0.03	0	55	54.6	61.1	159	157	0	31	30
2014	9	25	15	24	10	0.253	0.141	0.787	0.039	0.036	0	53.8	53.8	61.9	156	155	0	31	30
2014	9	25	15	34	10	0.262	0.105	0.787	0.033	0.03	0	54.2	54.6	63.6	157	156	0	31	29
2014	9	25	15	44	10	0.262	0.069	0.787	0.033	0.03	0	54.2	53.8	63.2	157	155	0	31	30
2014	9	25	15	54	10	0.279	0.141	0.784	0.033	0.03	0	53.3	52.9	63.2	155	154	0	31	31
2014	9	25	16	4	10	0.299	0.092	0.784	0.033	0.03	0	49.9	49	65.4	147	144	0	31	30
2014	9	25	16	14	10	0.269	0.144	0.784	0.036	0.033	0	52.9	52	64.5	154	151	0	31	30
2014	9	25	16	24	10	0.272	0.148	0.784	0.036	0.033	0	52.9	52.5	63.2	153	151	0	30	29
2014	9	25	16	34	10	0.276	0.115	0.784	0.033	0.03	0	50.7	50.3	64.9	149	147	0	31	30
2014	9	25	16	44	10	0.236	0.059	0.784	0.033	0.03	0	50.3	49	66.2	148	144	0	31	30
2014	9	25	16	54	10	0.24	0.105	0.784	0.039	0.036	0	49.5	48.2	67.5	146	142	0	31	30
2014	9	25	17	4	10	0.262	0.095	0.784	0.043	0.043	0	47.7	46.4	68.4	142	139	0	31	31
2014	9	25	17	14	10	0.24	0.046	0.784	0.036	0.033	0	46.4	45.6	68.8	139	136	0	31	30
2014	9	25	17	24	10	0.256	0.128	0.784	0.039	0.036	0	45.2	43.9	70.5	136	132	0	31	30
2014	9	25	17	34	10	0.259	0.171	0.781	0.039	0.036	0	45.2	43.4	70.1	135	131	0	30	30
2014	9	25	17	44	10	0.279	0.105	0.784	0.039	0.039	0	43.4	43.4	69.7	133	130	0	32	29
2014	9	25	17	54	10	0.226	0.036	0.784	0.036	0.033	0	45.2	44.7	70.1	136	134	0	31	30
2014	9	25	18	4	10	0.223	0.023	0.781	0.033	0.03	0	44.7	44.7	69.2	135	133	0	31	29
2014	9	25	18	14	10	0.249	0.003	0.784	0.039	0.036	0	45.2	43.9	69.2	136	132	0	31	30
2014	9	25	18	24	10	0.253	0.125	0.784	0.036	0.033	0	44.7	43.4	68.8	134	131	0	30	30
2014	9	25	18	34	10	0.272	0.003	0.784	0.039	0.036	0	44.7	43.4	68.8	134	131	0	30	30
2014	9	25	18	44	10	0.246	0.013	0.781	0.033	0.033	0	45.6	44.7	68.8	136	134	0	30	30
2014	9	25	18	54	10	0.322	0.036	0.781	0.036	0.033	0	45.2	44.3	69.7	136	133	0	31	30
2014	9	25	19	4	10	0.256	0.023	0.784	0.039	0.039	0	45.2	44.3	69.7	136	133	0	31	30
2014	9	25	19	14	10	0.266	0.026	0.781	0.043	0.039	0	44.7	44.3	70.1	135	133	0	31	30
2014	9	25	19	24	10	0.233	-0.062	0.784	0.036	0.033	0	43.9	43.4	70.1	133	132	0	31	31
2014	9	25	19	34	10	0.217	-0.007	0.784	0.039	0.036	0	44.3	43.4	71.4	133	131	0	30	30
2014	9	25	19	44	10	0.161	0.039	0.784	0.033	0.03	0	43.9	43	72.7	133	130	0	31	30
2014	9	25	19	54	10	0.194	0.026	0.784	0.033	0.03	0	43.9	43.9	72.2	133	132	0	31	30
2014	9	25	20	4	10	0.233	-0.02	0.784	0.033	0.03	0	44.3	42.6	72.7	133	129	0	30	30
2014	9	25	20	14	10	0.22	-0.043	0.784	0.039	0.036	0	47.7	46.4	70.1	142	138	0	31	30
2014	9	25	20	24	10	0.289	-0.013	0.784	0.036	0.033	0	48.2	46	67.9	143	138	0	31	31
2014	9	25	20	34	10	0.292	-0.026	0.784	0.033	0.03	0	47.7	46.9	68.4	142	139	0	31	30
2014	9	25	20	44	10	0.269	0	0.784	0.039	0.036	0	49	46.9	67.9	144	139	0	30	30
2014	9	25	20	54	10	0.259	-0.02	0.784	0.036	0.033	0	45.2	44.7	71	136	134	0	31	30
2014	9	25	21	4	10	0.213	-0.036	0.784	0.033	0.03	0	48.2	46.9	68.4	143	139	0	31	30
2014	9	25	21	14	10	0.256	0	0.784	0.036	0.033	0	49	47.3	67.5	145	140	0	31	30
2014	9	25	21	24	10	0.282	-0.082	0.784	0.036	0.033	0	49	47.7	67.9	145	141	0	31	30
2014	9	25	21	34	10	0.187	0.026	0.787	0.049	0.049	0	48.2	46.9	67.5	143	139	0	31	30
2014	9	25	21	44	10	0.174	0.03	0.787	0.039	0.036	0	48.2	46.9	67.9	143	139	0	31	30
2014	9	25	21	54	10	0.236	0.026	0.787	0.043	0.039	0	48.6	46.4	67.5	144	138	0	31	30
2014	9	25	22	4	10	0.21	0.033	0.791	0.036	0.033	0	47.7	45.6	69.2	142	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	22	14	10	0.266	-0.033	0.791	0.039	0.039	0	45.6	44.7	69.7	137	134	0	31	30
2014	9	25	22	24	10	0.233	-0.102	0.791	0.039	0.036	0	47.7	46.4	67.5	142	138	0	31	30
2014	9	25	22	34	10	0.249	-0.036	0.791	0.036	0.033	0	47.3	46	68.4	142	137	0	32	30
2014	9	25	22	44	10	0.187	-0.052	0.791	0.043	0.039	0	46.9	46.4	68.4	140	138	0	31	30
2014	9	25	22	54	10	0.19	-0.105	0.791	0.033	0.03	0	47.3	46	67.9	141	137	0	31	30
2014	9	25	23	4	10	0.233	-0.007	0.794	0.043	0.039	0	46	45.2	69.7	138	135	0	31	30
2014	9	25	23	14	10	0.262	-0.059	0.794	0.039	0.036	0	48.2	46.4	67.9	143	138	0	31	30
2014	9	25	23	24	10	0.23	0.016	0.794	0.033	0.03	0	47.3	46	68.8	141	138	0	31	31
2014	9	25	23	34	10	0.236	-0.049	0.797	0.039	0.039	0	46.9	46	69.2	140	137	0	31	30
2014	9	25	23	44	10	0.226	-0.043	0.794	0.036	0.033	0	46.9	46.4	69.2	140	138	0	31	30
2014	9	25	23	54	10	0.279	-0.03	0.794	0.039	0.036	0	47.7	46.4	67.9	142	138	0	31	30
2014	9	26	0	4	10	0.207	-0.066	0.794	0.036	0.033	0	47.3	45.6	69.2	141	136	0	31	30
2014	9	26	0	14	10	0.23	0.043	0.794	0.033	0.03	0	47.3	46.4	67.9	142	139	0	32	31
2014	9	26	0	24	10	0.285	0	0.794	0.039	0.039	0	46.9	45.2	68.8	140	136	0	31	31
2014	9	26	0	34	10	0.272	-0.056	0.797	0.033	0.03	0	46.9	45.6	69.2	140	137	0	31	31
2014	9	26	0	44	10	0.259	-0.059	0.797	0.046	0.043	0	47.7	46.9	68.4	142	139	0	31	30
2014	9	26	0	54	10	0.217	0.03	0.797	0.036	0.033	0	46.4	45.6	69.7	139	137	0	31	31
2014	9	26	1	4	10	0.282	-0.03	0.797	0.036	0.033	0	47.3	45.6	68.8	141	136	0	31	30
2014	9	26	1	14	10	0.322	-0.013	0.797	0.036	0.033	0	45.6	44.3	70.5	138	134	0	32	31
2014	9	26	1	24	10	0.203	-0.033	0.797	0.039	0.036	0	43.4	43.4	72.2	132	131	0	31	30
2014	9	26	1	34	10	0.184	-0.036	0.797	0.039	0.039	0	42.6	43	72.7	130	130	0	31	30
2014	9	26	1	44	10	0.161	-0.036	0.797	0.039	0.039	0	43	43	72.7	132	130	0	32	30
2014	9	26	1	54	10	0.187	0.043	0.797	0.036	0.033	0	46.9	46	69.7	140	138	0	31	31
2014	9	26	2	4	10	0.217	0	0.797	0.039	0.039	0	46.9	46.4	69.2	141	138	0	32	30
2014	9	26	2	14	10	0.341	0.085	0.797	0.039	0.036	0	46.9	45.6	70.1	140	137	0	31	31
2014	9	26	2	24	10	0.22	-0.003	0.797	0.039	0.039	0	45.2	44.7	71.4	137	135	0	32	31
2014	9	26	2	34	10	0.276	-0.016	0.797	0.039	0.039	0	47.3	46.9	69.7	141	139	0	31	30
2014	9	26	2	44	10	0.243	-0.016	0.797	0.046	0.043	0	49	47.3	68.4	145	141	0	31	31
2014	9	26	2	54	10	0.289	0.039	0.797	0.039	0.039	0	49.9	49.5	67.1	148	145	0	32	30
2014	9	26	3	4	10	0.256	0.023	0.797	0.033	0.03	0	51.2	49.5	66.7	150	146	0	31	31
2014	9	26	3	14	10	0.282	0.039	0.797	0.036	0.033	0	50.3	49	67.9	148	145	0	31	31
2014	9	26	3	24	10	0.253	-0.049	0.801	0.043	0.039	0	48.2	46.9	70.1	143	139	0	31	30
2014	9	26	3	34	10	0.154	-0.013	0.797	0.039	0.039	0	50.3	49	67.5	148	144	0	31	30
2014	9	26	3	44	10	0.269	-0.069	0.797	0.039	0.039	0	50.7	49.5	66.7	149	145	0	31	30
2014	9	26	3	54	10	0.22	0.016	0.801	0.043	0.039	0	49.9	48.2	69.2	148	142	0	32	30
2014	9	26	4	4	10	0.226	-0.007	0.801	0.039	0.036	0	49.5	47.7	67.9	146	142	0	31	31
2014	9	26	4	14	10	0.305	-0.062	0.797	0.039	0.039	0	47.7	47.7	69.2	142	141	0	31	30
2014	9	26	4	24	10	0.236	-0.052	0.801	0.039	0.036	0	47.3	45.6	71	141	137	0	31	31
2014	9	26	4	34	10	0.256	0.033	0.801	0.033	0.03	0	45.2	44.3	72.2	136	134	0	31	31
2014	9	26	4	44	10	0.243	0.013	0.801	0.046	0.043	0	43.4	43	73.5	133	131	0	32	31
2014	9	26	4	54	10	0.292	-0.01	0.801	0.033	0.03	0	43.4	42.6	73.5	133	130	0	32	31
2014	9	26	5	4	10	0.253	0	0.801	0.036	0.033	0	49.5	48.2	70.1	147	142	0	32	30
2014	9	26	5	14	10	0.22	-0.049	0.801	0.033	0.03	0	42.6	41.7	74.8	131	128	0	32	31
2014	9	26	5	24	10	0.18	0	0.801	0.036	0.033	0	43	41.7	74.4	131	128	0	31	31
2014	9	26	5	34	10	0.276	-0.121	0.801	0.036	0.033	0	42.6	43.4	74	131	131	0	32	30
2014	9	26	5	44	10	0.272	0.007	0.801	0.036	0.033	0	43	43	74.4	131	130	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	5	54	10	0.2	0	0.801	0.036	0.033	0	46	45.6	73.1	137	136	0	30	30
2014	9	26	6	4	10	0.223	-0.016	0.801	0.049	0.046	0	45.2	44.7	72.2	137	135	0	32	31
2014	9	26	6	14	10	0.207	0.043	0.801	0.036	0.033	0	46	45.2	72.7	138	136	0	31	31
2014	9	26	6	24	10	0.236	-0.003	0.801	0.039	0.036	0	44.3	44.3	73.5	135	133	0	32	30
2014	9	26	6	34	10	0.292	-0.046	0.801	0.036	0.033	0	47.3	46	71.4	141	138	0	31	31
2014	9	26	6	44	10	0.302	0.02	0.801	0.039	0.036	0	46.9	46	71.4	140	137	0	31	30
2014	9	26	6	54	10	0.18	0.066	0.801	0.036	0.033	0	45.2	43.9	74	137	133	0	32	31
2014	9	26	7	4	10	0.21	-0.016	0.801	0.033	0.03	0	43.4	42.6	74.8	132	130	0	31	31
2014	9	26	7	14	10	0.272	0.013	0.801	0.036	0.033	0	42.6	41.7	75.7	131	128	0	32	31
2014	9	26	7	24	10	0.197	-0.003	0.801	0.033	0.03	0	41.3	40	75.3	127	124	0	31	31
2014	9	26	7	34	10	0.197	-0.033	0.801	0.043	0.039	0	41.7	40.9	74.8	128	125	0	31	30
2014	9	26	7	44	10	0.262	-0.003	0.801	0.033	0.03	0	41.3	40.4	75.7	128	125	0	32	31
2014	9	26	7	54	10	0.233	-0.072	0.801	0.033	0.03	0	40.9	40.4	75.3	127	125	0	32	31
2014	9	26	8	4	10	0.184	-0.052	0.801	0.039	0.036	0	41.7	40	74.8	128	124	0	31	31
2014	9	26	8	14	10	0.23	-0.069	0.801	0.033	0.03	0	41.3	40.9	75.3	128	126	0	32	31
2014	9	26	8	24	10	0.223	-0.036	0.801	0.033	0.03	0	41.3	40	75.7	128	124	0	32	31
2014	9	26	8	34	10	0.22	-0.059	0.801	0.036	0.033	0	41.3	40.4	75.3	128	125	0	32	31
2014	9	26	8	44	10	0.161	0	0.801	0.036	0.033	0	41.3	41.3	75.3	127	126	0	31	30
2014	9	26	8	54	10	0.18	-0.033	0.801	0.039	0.036	0	40.4	40.4	75.3	126	124	0	32	30
2014	9	26	9	4	10	0.22	-0.043	0.801	0.039	0.036	0	41.3	40	75.3	127	124	0	31	31
2014	9	26	9	14	10	0.299	-0.023	0.801	0.033	0.03	0	40.4	40.9	75.7	126	126	0	32	31
2014	9	26	9	24	10	0.223	0.003	0.801	0.039	0.036	0	41.7	40.4	75.3	128	125	0	31	31
2014	9	26	9	34	10	0.236	0.016	0.801	0.039	0.036	0	41.3	41.3	75.3	127	127	0	31	31
2014	9	26	9	44	10	0.197	-0.043	0.801	0.039	0.036	0	40.9	42.1	74.4	127	129	0	32	31
2014	9	26	9	54	10	0.269	-0.01	0.801	0.036	0.033	0	41.7	42.6	74.8	129	130	0	32	31
2014	9	26	10	4	10	0.22	-0.003	0.801	0.033	0.03	0	43	43.9	74.8	132	133	0	32	31
2014	9	26	10	14	10	0.2	-0.062	0.801	0.039	0.036	0	43.9	43.4	73.5	133	132	0	31	31
2014	9	26	10	24	10	0.203	-0.01	0.801	0.039	0.036	0	43.9	43.4	74	133	132	0	31	31
2014	9	26	10	34	10	0.226	0.033	0.801	0.033	0.03	0	43	45.6	73.5	132	136	0	32	30
2014	9	26	10	44	10	0.256	-0.039	0.797	0.036	0.033	0	43.9	45.2	72.7	134	136	0	32	31
2014	9	26	10	54	10	0.24	-0.003	0.801	0.036	0.033	0	43.9	46	73.5	134	137	0	32	30
2014	9	26	11	4	10	0.24	-0.023	0.801	0.03	0.03	0	45.6	46.9	73.5	137	140	0	31	31
2014	9	26	11	14	10	0.285	0.016	0.801	0.036	0.033	0	45.6	46	73.1	138	138	0	32	31
2014	9	26	11	24	10	0.285	-0.059	0.801	0.036	0.033	0	45.2	47.3	72.7	136	141	0	31	31
2014	9	26	11	34	10	0.249	0.013	0.797	0.033	0.03	0	46.4	46.9	70.1	139	140	0	31	31
2014	9	26	11	44	10	0.213	0.033	0.797	0.033	0.03	0	47.7	49.5	68.4	143	146	0	32	31
2014	9	26	11	54	10	0.335	-0.003	0.797	0.036	0.033	0	48.6	49.5	67.1	145	146	0	32	31
2014	9	26	12	4	10	0.308	0.052	0.797	0.036	0.033	0	48.6	50.3	67.5	145	148	0	32	31
2014	9	26	12	14	10	0.285	0.033	0.794	0.036	0.033	0	49.5	50.3	63.2	147	148	0	32	31
2014	9	26	12	24	10	0.207	0.062	0.794	0.036	0.033	0	50.3	51.2	63.6	149	150	0	32	31
2014	9	26	12	34	10	0.285	0.049	0.794	0.033	0.03	0	52.5	52.5	63.2	153	152	0	31	30
2014	9	26	12	44	10	0.249	-0.016	0.794	0.036	0.033	0	51.6	52	62.8	151	151	0	31	30
2014	9	26	12	54	10	0.269	0.01	0.794	0.033	0.03	0	52	52.9	63.2	153	153	0	32	30
2014	9	26	13	4	10	0.226	0.026	0.794	0.036	0.033	0	51.6	52.9	62.8	151	153	0	31	30
2014	9	26	13	14	10	0.262	0.052	0.794	0.036	0.033	0	52	52	62.8	152	152	0	31	31
2014	9	26	13	24	10	0.315	0.049	0.791	0.033	0.03	0	52	53.3	61.9	153	154	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	13	34	10	0.299	0.02	0.787	0.033	0.033	0	54.6	54.6	60.2	157	157	0	30	30
2014	9	26	13	44	10	0.282	0.082	0.791	0.033	0.033	0	53.8	52.9	62.4	156	154	0	31	31
2014	9	26	13	54	10	0.328	0.085	0.787	0.033	0.03	0	52.5	53.3	61.1	154	155	0	32	31
2014	9	26	14	4	10	0.236	0.069	0.787	0.036	0.033	0	52.9	52.9	62.8	153	153	0	30	30
2014	9	26	14	14	10	0.233	0.056	0.787	0.036	0.033	0	53.8	54.6	62.8	156	157	0	31	30
2014	9	26	14	24	10	0.269	0.069	0.784	0.036	0.033	0	53.8	54.6	63.2	156	157	0	31	30
2014	9	26	14	34	10	0.262	0.105	0.784	0.039	0.036	0	53.3	53.8	62.8	155	155	0	31	30
2014	9	26	14	44	10	0.256	0.089	0.784	0.039	0.036	0	54.2	52.9	62.8	156	154	0	30	31
2014	9	26	14	54	10	0.24	0.039	0.781	0.033	0.03	0	54.2	54.6	62.4	157	157	0	31	30
2014	9	26	15	4	10	0.279	0.056	0.784	0.039	0.036	0	52.9	52.9	63.2	154	153	0	31	30
2014	9	26	15	14	10	0.213	0.092	0.781	0.039	0.036	0	53.3	53.8	62.8	155	155	0	31	30
2014	9	26	15	24	10	0.299	0.085	0.781	0.039	0.036	0	52.9	53.3	63.6	155	154	0	32	30
2014	9	26	15	34	10	0.22	0.069	0.778	0.036	0.033	0	55.5	55	60.6	160	158	0	31	30
2014	9	26	15	44	10	0.295	0.141	0.781	0.033	0.03	0	53.8	53.3	62.4	155	154	0	30	30
2014	9	26	15	54	10	0.262	0.03	0.781	0.039	0.036	0	53.3	53.8	64.1	155	155	0	31	30
2014	9	26	16	4	10	0.295	0.085	0.778	0.036	0.033	0	54.2	54.2	62.8	157	156	0	31	30
2014	9	26	16	14	10	0.203	0.069	0.781	0.039	0.036	0	52	52	64.9	152	152	0	31	31
2014	9	26	16	24	10	0.285	0.085	0.781	0.033	0.03	0	50.7	52.5	65.4	149	151	0	31	29
2014	9	26	16	34	10	0.266	0.049	0.778	0.036	0.033	0	51.6	51.2	64.5	151	149	0	31	30
2014	9	26	16	44	10	0.279	0.049	0.778	0.039	0.036	0	50.3	49.9	67.1	148	146	0	31	30
2014	9	26	16	54	10	0.203	0.069	0.781	0.036	0.033	0	48.2	48.2	66.7	143	142	0	31	30
2014	9	26	17	4	10	0.217	0.033	0.781	0.036	0.033	0	47.3	46.9	67.9	141	139	0	31	30
2014	9	26	17	14	10	0.266	0.105	0.778	0.036	0.033	0	47.3	46.9	67.5	141	139	0	31	30
2014	9	26	17	24	10	0.266	0.052	0.781	0.043	0.039	0	45.6	45.2	69.2	137	135	0	31	30
2014	9	26	17	34	10	0.24	0.072	0.781	0.036	0.033	0	45.2	43.4	70.5	136	132	0	31	31
2014	9	26	17	44	10	0.302	0.108	0.778	0.039	0.036	0	44.3	43.9	70.1	134	132	0	31	30
2014	9	26	17	54	10	0.246	0.095	0.781	0.036	0.033	0	43.4	43.4	71	132	131	0	31	30
2014	9	26	18	4	10	0.292	0.033	0.781	0.039	0.036	0	43	42.6	73.1	131	129	0	31	30
2014	9	26	18	14	10	0.243	0.066	0.778	0.039	0.039	0	43.4	42.1	73.1	132	128	0	31	30
2014	9	26	18	24	10	0.302	0.059	0.781	0.033	0.03	0	42.1	41.3	73.5	129	127	0	31	31
2014	9	26	18	34	10	0.266	0.089	0.778	0.049	0.049	0	43	42.6	71.4	131	129	0	31	30
2014	9	26	18	44	10	0.276	0.069	0.778	0.039	0.039	0	42.6	43	71	130	129	0	31	29
2014	9	26	18	54	10	0.203	0.003	0.778	0.033	0.03	0	43	43	72.7	131	130	0	31	30
2014	9	26	19	4	10	0.197	-0.016	0.778	0.033	0.03	0	42.6	42.1	72.2	130	128	0	31	30
2014	9	26	19	14	10	0.246	0.02	0.778	0.036	0.033	0	43.4	43	72.2	132	130	0	31	30
2014	9	26	19	24	10	0.249	0.007	0.778	0.039	0.036	0	43.4	43	72.2	132	131	0	31	31
2014	9	26	19	34	10	0.285	0.016	0.778	0.039	0.036	0	43	42.6	70.1	131	130	0	31	31
2014	9	26	19	44	10	0.203	0.02	0.781	0.039	0.036	0	43	43	73.5	131	130	0	31	30
2014	9	26	19	54	10	0.262	0.013	0.781	0.036	0.033	0	43.4	43	72.7	133	130	0	32	30
2014	9	26	20	4	10	0.315	0.013	0.778	0.033	0.03	0	44.7	43.4	72.7	135	132	0	31	31
2014	9	26	20	14	10	0.259	0.013	0.778	0.036	0.033	0	43.9	44.3	73.1	134	133	0	32	30
2014	9	26	20	24	10	0.236	0.033	0.781	0.036	0.033	0	43.9	43.4	73.1	133	132	0	31	31
2014	9	26	20	34	10	0.269	-0.075	0.781	0.043	0.039	0	46.4	45.2	71	138	135	0	30	30
2014	9	26	20	44	10	0.292	-0.02	0.781	0.039	0.036	0	46.4	44.7	70.5	139	135	0	31	31
2014	9	26	20	54	10	0.207	-0.02	0.781	0.043	0.039	0	45.6	44.7	70.1	138	134	0	32	30
2014	9	26	21	4	10	0.24	-0.039	0.781	0.039	0.039	0	46	44.3	69.7	138	134	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	21	14	10	0.246	0.02	0.781	0.033	0.03	0	46.4	45.6	68.8	140	136	0	32	30
2014	9	26	21	24	10	0.295	0.023	0.781	0.039	0.036	0	47.3	46.4	67.9	141	138	0	31	30
2014	9	26	21	34	10	0.187	-0.003	0.781	0.033	0.03	0	47.3	46	69.7	141	138	0	31	31
2014	9	26	21	44	10	0.272	-0.039	0.781	0.033	0.03	0	46.9	46	68.8	140	137	0	31	30
2014	9	26	21	54	10	0.259	-0.023	0.781	0.036	0.033	0	45.6	44.7	69.2	137	134	0	31	30
2014	9	26	22	4	10	0.184	-0.039	0.781	0.036	0.033	0	46.4	45.2	68.4	140	136	0	32	31
2014	9	26	22	14	10	0.256	-0.092	0.781	0.036	0.033	0	45.6	45.2	69.2	138	135	0	32	30
2014	9	26	22	24	10	0.249	-0.056	0.781	0.039	0.036	0	45.2	44.7	69.2	137	134	0	32	30
2014	9	26	22	34	10	0.24	-0.052	0.781	0.039	0.036	0	46.9	45.2	68.4	141	136	0	32	31
2014	9	26	22	44	10	0.253	0	0.781	0.046	0.043	0	47.7	46	67.9	143	138	0	32	31
2014	9	26	22	54	10	0.18	-0.059	0.784	0.039	0.036	0	44.7	43.9	69.7	136	133	0	32	31
2014	9	26	23	4	10	0.217	-0.033	0.784	0.036	0.033	0	46.9	45.2	67.9	141	136	0	32	31
2014	9	26	23	14	10	0.187	0.003	0.784	0.046	0.043	0	46.9	45.6	67.9	141	137	0	32	31
2014	9	26	23	24	10	0.23	-0.059	0.784	0.039	0.036	0	45.2	44.3	69.2	136	134	0	31	31
2014	9	26	23	34	10	0.236	-0.075	0.784	0.033	0.03	0	45.6	44.7	69.2	138	135	0	32	31
2014	9	26	23	44	10	0.226	-0.033	0.784	0.036	0.033	0	47.3	46	68.4	142	137	0	32	30
2014	9	26	23	54	10	0.246	0.026	0.784	0.039	0.036	0	45.6	44.7	68.8	138	135	0	32	31
2014	9	27	0	4	10	0.21	-0.023	0.784	0.039	0.036	0	46.9	46.4	67.9	141	139	0	32	31
2014	9	27	0	14	10	0.171	-0.046	0.784	0.033	0.03	0	46.4	44.7	68.4	140	135	0	32	31
2014	9	27	0	24	10	0.18	-0.016	0.784	0.039	0.036	0	48.6	46.9	67.1	144	140	0	31	31
2014	9	27	0	34	10	0.226	-0.033	0.787	0.039	0.036	0	46.4	44.7	68.8	139	135	0	31	31
2014	9	27	0	44	10	0.203	-0.049	0.784	0.033	0.03	0	47.3	46.4	67.5	142	139	0	32	31
2014	9	27	0	54	10	0.259	0	0.784	0.036	0.033	0	48.6	47.3	66.7	144	141	0	31	31
2014	9	27	1	4	10	0.21	-0.072	0.787	0.036	0.033	0	47.7	47.3	66.7	143	140	0	32	30
2014	9	27	1	14	10	0.253	-0.062	0.787	0.039	0.039	0	47.7	45.6	67.9	142	138	0	31	32
2014	9	27	1	24	10	0.22	-0.049	0.784	0.036	0.033	0	47.7	46.9	67.1	143	140	0	32	31
2014	9	27	1	34	10	0.253	-0.066	0.787	0.039	0.036	0	45.6	45.2	68.4	138	136	0	32	31
2014	9	27	1	44	10	0.243	-0.013	0.787	0.039	0.039	0	47.7	47.7	66.7	143	141	0	32	30
2014	9	27	1	54	10	0.233	-0.023	0.787	0.043	0.039	0	47.7	47.3	67.1	143	141	0	32	31
2014	9	27	2	4	10	0.154	-0.033	0.787	0.043	0.039	0	47.3	46	67.9	141	138	0	31	31
2014	9	27	2	14	10	0.233	-0.013	0.791	0.039	0.036	0	44.7	43.4	70.5	136	132	0	32	31
2014	9	27	2	24	10	0.269	-0.062	0.787	0.039	0.036	0	48.2	46.4	67.1	144	139	0	32	31
2014	9	27	2	34	10	0.315	-0.079	0.791	0.039	0.039	0	46.4	46	67.5	140	138	0	32	31
2014	9	27	2	44	10	0.223	-0.102	0.787	0.039	0.036	0	49	48.2	65.4	146	143	0	32	31
2014	9	27	2	54	10	0.184	-0.02	0.791	0.039	0.036	0	42.6	42.6	71.8	131	129	0	32	30
2014	9	27	3	4	10	0.256	-0.01	0.791	0.039	0.039	0	45.2	43.9	69.2	136	134	0	31	32
2014	9	27	3	14	10	0.24	-0.059	0.791	0.039	0.036	0	45.6	46	67.9	138	138	0	32	31
2014	9	27	3	24	10	0.184	-0.056	0.791	0.046	0.043	0	46.4	45.6	68.4	140	137	0	32	31
2014	9	27	3	34	10	0.161	-0.046	0.791	0.039	0.036	0	47.3	45.6	68.4	141	137	0	31	31
2014	9	27	3	44	10	0.246	-0.003	0.791	0.039	0.039	0	45.6	43.4	69.7	137	133	0	31	32
2014	9	27	3	54	10	0.266	-0.033	0.791	0.043	0.039	0	46	44.7	67.9	139	135	0	32	31
2014	9	27	4	4	10	0.226	-0.056	0.791	0.039	0.039	0	44.3	44.3	69.7	134	134	0	31	31
2014	9	27	4	14	10	0.226	0	0.791	0.036	0.033	0	43.4	43	69.7	133	131	0	32	31
2014	9	27	4	24	10	0.135	-0.023	0.791	0.036	0.033	0	43	43	69.7	132	131	0	32	31
2014	9	27	4	34	10	0.194	0.049	0.787	0.049	0.049	0	46.4	45.2	67.1	139	136	0	31	31
2014	9	27	4	44	10	0.21	-0.056	0.787	0.033	0.03	0	45.6	45.2	67.1	138	136	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	4	54	10	0.226	0	0.787	0.036	0.033	0	49	47.3	64.5	145	141	0	31	31
2014	9	27	5	4	10	0.233	-0.049	0.787	0.039	0.039	0	48.2	47.7	65.4	144	142	0	32	31
2014	9	27	5	14	10	0.22	-0.033	0.787	0.033	0.03	0	46	45.6	66.7	139	138	0	32	32
2014	9	27	5	24	10	0.217	0.056	0.791	0.036	0.033	0	46.9	46.4	65.8	141	139	0	32	31
2014	9	27	5	34	10	0.266	0.02	0.791	0.036	0.033	0	46	45.6	67.5	139	137	0	32	31
2014	9	27	5	44	10	0.233	0.069	0.791	0.039	0.036	0	45.6	44.7	66.7	138	135	0	32	31
2014	9	27	5	54	10	0.236	0.016	0.791	0.039	0.036	0	46	44.7	68.8	138	135	0	31	31
2014	9	27	6	4	10	0.236	-0.049	0.791	0.039	0.036	0	45.2	44.3	69.2	137	134	0	32	31
2014	9	27	6	14	10	0.171	-0.085	0.791	0.039	0.036	0	45.2	44.7	68.8	137	135	0	32	31
2014	9	27	6	24	10	0.131	0.03	0.791	0.039	0.036	0	44.3	44.3	68.4	135	134	0	32	31
2014	9	27	6	34	10	0.2	-0.016	0.791	0.033	0.03	0	44.7	44.7	68.4	137	135	0	33	31
2014	9	27	6	44	10	0.197	0.03	0.794	0.039	0.036	0	43.9	43	70.1	134	131	0	32	31
2014	9	27	6	54	10	0.213	-0.023	0.791	0.036	0.033	0	43	42.1	69.7	132	129	0	32	31
2014	9	27	7	4	10	0.262	0.02	0.791	0.039	0.039	0	42.6	42.6	70.5	131	130	0	32	31
2014	9	27	7	14	10	0.253	-0.033	0.794	0.039	0.036	0	42.6	41.7	71.4	131	128	0	32	31
2014	9	27	7	24	10	0.24	0.013	0.794	0.033	0.03	0	42.1	41.7	71.8	130	128	0	32	31
2014	9	27	7	34	10	0.223	-0.069	0.794	0.033	0.03	0	41.3	40.9	71	128	127	0	32	32
2014	9	27	7	44	10	0.262	0.013	0.794	0.039	0.039	0	41.3	42.1	69.2	129	129	0	33	31
2014	9	27	7	54	10	0.253	-0.023	0.791	0.039	0.036	0	42.1	42.6	68.8	130	130	0	32	31
2014	9	27	8	4	10	0.203	0.033	0.791	0.043	0.043	0	42.1	43	69.2	131	132	0	33	32
2014	9	27	8	14	10	0.23	-0.033	0.791	0.036	0.033	0	43.9	43.9	69.7	135	134	0	33	32
2014	9	27	8	24	10	0.171	0	0.794	0.033	0.03	0	43.9	43.4	69.7	134	132	0	32	31
2014	9	27	8	34	10	0.187	-0.039	0.791	0.039	0.036	0	44.7	43.9	68.8	136	134	0	32	32
2014	9	27	8	44	10	0.226	0	0.791	0.033	0.03	0	43.9	43	69.2	134	132	0	32	32
2014	9	27	8	54	10	0.197	0	0.794	0.036	0.033	0	43.9	43.4	71.4	134	132	0	32	31
2014	9	27	9	4	10	0.148	0.03	0.791	0.046	0.043	0	43.9	43	70.1	134	132	0	32	32
2014	9	27	9	14	10	0.19	-0.02	0.794	0.036	0.033	0	43	42.6	71	132	130	0	32	31
2014	9	27	9	24	10	0.217	-0.01	0.791	0.039	0.039	0	43	43	70.1	132	131	0	32	31
2014	9	27	9	34	10	0.161	0.023	0.791	0.039	0.036	0	42.6	43	70.5	132	132	0	33	32
2014	9	27	9	44	10	0.249	0.085	0.791	0.039	0.036	0	45.2	45.2	67.9	137	135	0	32	30
2014	9	27	9	54	10	0.194	0.039	0.791	0.033	0.03	0	44.7	45.2	68.4	137	136	0	33	31
2014	9	27	10	4	10	0.266	-0.003	0.791	0.036	0.033	0	45.6	46.4	68.8	138	139	0	32	31
2014	9	27	10	14	10	0.217	0.03	0.791	0.033	0.03	0	44.7	44.7	69.7	136	136	0	32	32
2014	9	27	10	24	10	0.223	0.062	0.794	0.033	0.03	0	44.3	46.4	69.7	136	139	0	33	31
2014	9	27	10	34	10	0.171	0.049	0.794	0.033	0.03	0	44.3	46.4	69.2	136	139	0	33	31
2014	9	27	10	44	10	0.249	0.03	0.791	0.036	0.033	0	45.6	47.3	69.7	138	141	0	32	31
2014	9	27	10	54	10	0.282	0.003	0.791	0.046	0.043	0	46	47.3	68.4	139	141	0	32	31
2014	9	27	11	4	10	0.23	0.007	0.791	0.039	0.036	0	46.4	47.7	67.5	140	142	0	32	31
2014	9	27	11	14	10	0.18	0.02	0.794	0.033	0.03	0	46.9	48.2	67.9	141	142	0	32	30
2014	9	27	11	24	10	0.299	0.036	0.791	0.039	0.036	0	46	48.2	68.4	140	143	0	33	31
2014	9	27	11	34	10	0.279	0.03	0.791	0.033	0.03	0	47.7	49	66.2	143	145	0	32	31
2014	9	27	11	44	10	0.253	0.089	0.791	0.036	0.033	0	48.2	49.5	66.2	144	146	0	32	31
2014	9	27	11	54	10	0.2	0.043	0.791	0.033	0.03	0	49.5	50.7	65.4	146	148	0	31	30
2014	9	27	12	4	10	0.282	0.03	0.791	0.036	0.033	0	48.6	50.3	65.8	146	148	0	33	31
2014	9	27	12	14	10	0.203	0.02	0.791	0.036	0.033	0	49	50.3	64.9	146	148	0	32	31
2014	9	27	12	24	10	0.207	0.052	0.791	0.039	0.039	0	49.5	50.7	65.4	147	149	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	12	34	10	0.197	-0.003	0.791	0.03	0.03	0	49.5	50.3	66.7	147	148	0	32	31
2014	9	27	12	44	10	0.236	0.043	0.791	0.033	0.03	0	49.5	50.7	65.8	147	149	0	32	31
2014	9	27	12	54	10	0.233	0.056	0.787	0.033	0.03	0	50.3	51.2	64.5	149	151	0	32	32
2014	9	27	13	4	10	0.217	0.089	0.784	0.033	0.03	0	51.2	52.5	62.4	151	153	0	32	31
2014	9	27	13	14	10	0.256	0.102	0.784	0.036	0.033	0	51.6	52.5	63.6	151	153	0	31	31
2014	9	27	13	24	10	0.269	0.082	0.784	0.033	0.03	0	51.2	52.5	62.4	151	153	0	32	31
2014	9	27	13	34	10	0.246	0.131	0.787	0.033	0.03	0	51.2	51.2	64.1	150	151	0	31	32
2014	9	27	13	44	10	0.23	0.102	0.784	0.033	0.03	0	52.5	52.9	61.9	153	154	0	31	31
2014	9	27	13	54	10	0.23	0.033	0.784	0.033	0.03	0	51.6	52.5	62.8	152	153	0	32	31
2014	9	27	14	4	10	0.177	0.007	0.787	0.033	0.03	0	50.7	50.7	66.2	150	149	0	32	31
2014	9	27	14	14	10	0.19	0.092	0.787	0.033	0.03	0	49.9	50.7	65.8	147	149	0	31	31
2014	9	27	14	24	10	0.154	0.089	0.787	0.033	0.03	0	49.9	50.7	68.4	148	149	0	32	31
2014	9	27	14	34	10	0.253	0.02	0.787	0.033	0.03	0	49	50.3	67.5	145	148	0	31	31
2014	9	27	14	44	10	0.203	0.092	0.787	0.033	0.03	0	48.6	49.5	67.9	145	145	0	32	30
2014	9	27	14	54	10	0.223	0.033	0.787	0.039	0.036	0	49.9	52	66.2	148	152	0	32	31
2014	9	27	15	4	10	0.223	0.131	0.787	0.036	0.033	0	47.7	49.5	68.8	142	146	0	31	31
2014	9	27	15	14	10	0.243	0.072	0.787	0.036	0.033	0	47.7	48.6	68.8	142	143	0	31	30
2014	9	27	15	24	10	0.308	0.062	0.787	0.033	0.03	0	48.2	49	67.9	143	145	0	31	31
2014	9	27	15	34	10	0.246	0.092	0.787	0.02	0.016	0	46.9	47.3	68.4	140	140	0	31	30
2014	9	27	15	44	10	0.256	0.135	0.787	0.039	0.039	0	43.9	44.3	69.7	134	133	0	32	30
2014	9	27	15	54	10	0.236	0.092	0.787	0.036	0.033	0	46.4	46.4	68.8	139	138	0	31	30
2014	9	27	16	4	10	0.295	0.131	0.787	0.033	0.03	0	44.7	45.2	69.7	136	135	0	32	30
2014	9	27	16	14	10	0.256	0.033	0.787	0.033	0.03	0	43.9	43.9	70.1	133	133	0	31	31
2014	9	27	16	24	10	0.236	0.075	0.787	0.043	0.039	0	43	43	71	132	131	0	32	31
2014	9	27	16	34	10	0.226	0.066	0.787	0.036	0.033	0	43.4	43	70.1	133	130	0	32	30
2014	9	27	16	44	10	0.197	-0.033	0.787	0.033	0.03	0	43.9	43.9	69.7	133	133	0	31	31
2014	9	27	16	54	10	0.22	0.013	0.791	0.036	0.033	0	42.1	41.3	71.8	129	127	0	31	31
2014	9	27	17	4	10	0.335	0.082	0.791	0.039	0.036	0	40.9	40.4	72.2	126	125	0	31	31
2014	9	27	17	14	10	0.194	0.118	0.791	0.033	0.03	0	40.9	40.4	71.8	126	125	0	31	31
2014	9	27	17	24	10	0.157	0.01	0.791	0.036	0.033	0	40	38.7	72.7	124	121	0	31	31
2014	9	27	17	34	10	0.223	0.043	0.791	0.033	0.03	0	41.3	41.7	71.8	127	127	0	31	30
2014	9	27	17	44	10	0.217	0.072	0.791	0.036	0.033	0	44.3	43.9	71.4	134	133	0	31	31
2014	9	27	17	54	10	0.289	0.046	0.791	0.033	0.03	0	43.4	43.4	71.4	133	132	0	32	31
2014	9	27	18	4	10	0.236	0.016	0.794	0.033	0.03	0	43	43.9	72.2	131	132	0	31	30
2014	9	27	18	14	10	0.276	-0.02	0.794	0.033	0.03	0	43.9	43	72.7	133	131	0	31	31
2014	9	27	18	24	10	0.269	0.052	0.794	0.033	0.03	0	42.1	42.6	71.8	129	129	0	31	30
2014	9	27	18	34	10	0.236	-0.003	0.794	0.036	0.033	0	42.1	42.1	72.7	129	128	0	31	30
2014	9	27	18	44	10	0.21	0.007	0.794	0.033	0.03	0	41.7	42.1	71.8	128	128	0	31	30
2014	9	27	18	54	10	0.246	-0.043	0.794	0.039	0.036	0	42.1	42.1	71.8	129	128	0	31	30
2014	9	27	19	4	10	0.272	0.066	0.794	0.039	0.036	0	41.7	41.7	71	129	128	0	32	31
2014	9	27	19	14	10	0.226	-0.03	0.794	0.033	0.03	0	40.9	41.3	71.8	127	127	0	32	31
2014	9	27	19	24	10	0.203	0.046	0.794	0.036	0.033	0	41.3	41.3	72.2	128	127	0	32	31
2014	9	27	19	34	10	0.187	0.013	0.794	0.033	0.03	0	41.3	41.3	72.7	128	127	0	32	31
2014	9	27	19	44	10	0.197	0.01	0.794	0.033	0.03	0	41.7	42.1	72.7	129	128	0	32	30
2014	9	27	19	54	10	0.19	-0.026	0.794	0.039	0.039	0	42.6	42.1	72.2	131	129	0	32	31
2014	9	27	20	4	10	0.233	-0.007	0.794	0.039	0.036	0	42.1	42.1	71.4	130	129	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	20	14	10	0.249	0	0.794	0.033	0.03	0	44.3	43.4	70.1	135	132	0	32	31
2014	9	27	20	24	10	0.154	0.039	0.797	0.036	0.033	0	42.6	42.6	73.1	131	130	0	32	31
2014	9	27	20	34	10	0.194	0.023	0.794	0.039	0.036	0	43.4	43.4	69.7	133	132	0	32	31
2014	9	27	20	44	10	0.223	0.003	0.794	0.039	0.036	0	43.9	43.4	70.5	133	132	0	31	31
2014	9	27	20	54	10	0.23	-0.059	0.794	0.036	0.033	0	45.2	44.3	67.9	136	135	0	31	32
2014	9	27	21	4	10	0.217	0.01	0.797	0.043	0.039	0	44.3	43.4	70.5	135	133	0	32	32
2014	9	27	21	14	10	0.285	0.056	0.794	0.039	0.036	0	46.9	46	68.4	141	137	0	32	30
2014	9	27	21	24	10	0.253	-0.023	0.797	0.036	0.033	0	45.6	44.7	70.1	138	135	0	32	31
2014	9	27	21	34	10	0.282	0.056	0.797	0.043	0.039	0	43.9	43.4	72.2	134	132	0	32	31
2014	9	27	21	44	10	0.233	-0.016	0.797	0.039	0.039	0	45.6	44.3	70.1	138	135	0	32	32
2014	9	27	21	54	10	0.213	0.033	0.797	0.036	0.033	0	43.4	43	72.2	133	131	0	32	31
2014	9	27	22	4	10	0.197	-0.085	0.797	0.039	0.036	0	44.7	43.9	72.2	136	133	0	32	31
2014	9	27	22	14	10	0.223	-0.01	0.797	0.046	0.043	0	43.4	43.4	71	133	132	0	32	31
2014	9	27	22	24	10	0.243	0	0.797	0.039	0.036	0	43.4	43.4	70.5	133	132	0	32	31
2014	9	27	22	34	10	0.233	-0.01	0.797	0.043	0.039	0	46	45.2	69.7	139	136	0	32	31
2014	9	27	22	44	10	0.279	-0.036	0.797	0.039	0.036	0	42.6	42.1	73.5	131	129	0	32	31
2014	9	27	22	54	10	0.233	0.003	0.797	0.039	0.036	0	44.3	43.9	72.7	135	133	0	32	31
2014	9	27	23	4	10	0.226	-0.016	0.797	0.039	0.036	0	41.3	41.3	74.4	129	127	0	33	31
2014	9	27	23	14	10	0.253	-0.046	0.797	0.039	0.036	0	45.2	44.3	71	138	134	0	33	31
2014	9	27	23	24	10	0.276	-0.03	0.797	0.039	0.039	0	44.3	43	73.1	134	131	0	31	31
2014	9	27	23	34	10	0.282	-0.03	0.797	0.033	0.03	0	43	42.1	74	131	130	0	31	32
2014	9	27	23	44	10	0.299	-0.089	0.797	0.036	0.033	0	46	44.7	72.2	138	135	0	31	31
2014	9	27	23	54	10	0.299	-0.082	0.797	0.039	0.036	0	46.9	46	71	141	138	0	32	31
2014	9	28	0	4	10	0.226	0.039	0.797	0.046	0.046	0	45.2	44.3	72.2	136	134	0	31	31
2014	9	28	0	14	10	0.282	0.013	0.797	0.039	0.039	0	43.4	42.6	74	133	130	0	32	31
2014	9	28	0	24	10	0.266	-0.02	0.797	0.036	0.033	0	44.7	43.9	72.7	136	133	0	32	31
2014	9	28	0	34	10	0.246	-0.069	0.797	0.039	0.036	0	43.9	43	73.5	134	131	0	32	31
2014	9	28	0	44	10	0.256	-0.066	0.797	0.043	0.039	0	46	44.7	71.8	139	135	0	32	31
2014	9	28	0	54	10	0.187	-0.066	0.797	0.039	0.036	0	41.7	41.7	75.7	129	128	0	32	31
2014	9	28	1	4	10	0.226	-0.013	0.797	0.039	0.036	0	44.7	43.9	72.7	136	133	0	32	31
2014	9	28	1	14	10	0.249	-0.066	0.797	0.039	0.036	0	47.3	45.6	71.8	142	137	0	32	31
2014	9	28	1	24	10	0.23	0.043	0.797	0.043	0.039	0	40	40.4	75.7	125	125	0	32	31
2014	9	28	1	34	10	0.197	-0.02	0.797	0.033	0.03	0	42.6	41.7	74.8	130	128	0	31	31
2014	9	28	1	44	10	0.285	-0.056	0.797	0.039	0.036	0	43.9	42.6	74	133	130	0	31	31
2014	9	28	1	54	10	0.246	-0.049	0.797	0.039	0.036	0	45.2	43.9	71.4	137	133	0	32	31
2014	9	28	2	4	10	0.269	-0.046	0.797	0.036	0.033	0	41.3	40.4	75.3	128	125	0	32	31
2014	9	28	2	14	10	0.299	-0.069	0.801	0.043	0.039	0	45.6	44.3	72.2	138	135	0	32	32
2014	9	28	2	24	10	0.262	-0.066	0.797	0.043	0.039	0	44.3	43	73.5	136	132	0	33	32
2014	9	28	2	34	10	0.164	-0.016	0.797	0.039	0.036	0	43.9	43.4	74	135	133	0	33	32
2014	9	28	2	44	10	0.253	0.007	0.797	0.039	0.039	0	44.7	44.3	73.1	137	134	0	33	31
2014	9	28	2	54	10	0.279	-0.052	0.797	0.036	0.033	0	42.6	41.3	75.3	131	128	0	32	32
2014	9	28	3	4	10	0.203	-0.03	0.801	0.033	0.03	0	40.4	41.7	76.1	127	127	0	33	30
2014	9	28	3	14	10	0.23	-0.052	0.801	0.033	0.03	0	42.1	41.7	75.3	130	128	0	32	31
2014	9	28	3	24	10	0.243	-0.013	0.797	0.039	0.036	0	47.3	46	71.4	142	139	0	32	32
2014	9	28	3	34	10	0.246	-0.082	0.801	0.036	0.033	0	44.7	43.4	74.4	136	132	0	32	31
2014	9	28	3	44	10	0.285	0	0.801	0.036	0.033	0	46.9	45.6	72.2	141	137	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	3	54	10	0.217	-0.052	0.801	0.033	0.03	0	43	42.6	75.3	131	130	0	31	31
2014	9	28	4	4	10	0.22	0	0.801	0.039	0.039	0	43	42.6	75.3	132	130	0	32	31
2014	9	28	4	14	10	0.279	-0.01	0.801	0.039	0.039	0	45.6	44.3	73.1	139	135	0	33	32
2014	9	28	4	24	10	0.19	-0.059	0.801	0.043	0.039	0	43	42.6	75.3	132	130	0	32	31
2014	9	28	4	34	10	0.226	-0.115	0.801	0.039	0.039	0	43.4	43	75.3	133	132	0	32	32
2014	9	28	4	44	10	0.23	-0.033	0.801	0.039	0.039	0	41.7	41.3	76.5	129	128	0	32	32
2014	9	28	4	54	10	0.266	-0.049	0.801	0.043	0.039	0	41.3	40	76.1	128	125	0	32	32
2014	9	28	5	4	10	0.24	-0.043	0.801	0.033	0.03	0	40.4	40.9	77	126	126	0	32	31
2014	9	28	5	14	10	0.2	-0.082	0.801	0.039	0.036	0	40.4	40.4	77	127	125	0	33	31
2014	9	28	5	24	10	0.266	-0.02	0.801	0.039	0.036	0	40.4	40.4	76.5	126	125	0	32	31
2014	9	28	5	34	10	0.213	-0.049	0.801	0.033	0.03	0	40.9	40.4	76.5	127	126	0	32	32
2014	9	28	5	44	10	0.223	-0.049	0.801	0.036	0.033	0	41.3	40	76.5	128	124	0	32	31
2014	9	28	5	54	10	0.295	-0.023	0.801	0.039	0.036	0	40.4	40.9	76.5	126	126	0	32	31
2014	9	28	6	4	10	0.246	0	0.801	0.039	0.036	0	41.7	41.7	76.5	129	128	0	32	31
2014	9	28	6	14	10	0.23	-0.098	0.801	0.039	0.036	0	40.4	41.3	76.1	127	127	0	33	31
2014	9	28	6	24	10	0.266	-0.01	0.801	0.039	0.039	0	42.6	41.7	76.1	130	128	0	31	31
2014	9	28	6	34	10	0.233	-0.098	0.801	0.039	0.036	0	41.3	41.3	76.5	128	127	0	32	31
2014	9	28	6	44	10	0.282	-0.052	0.801	0.036	0.033	0	41.3	40.9	76.1	128	127	0	32	32
2014	9	28	6	54	10	0.22	-0.039	0.801	0.039	0.039	0	39.1	39.6	77	124	123	0	33	31
2014	9	28	7	4	10	0.226	-0.036	0.801	0.033	0.03	0	39.1	40	76.5	124	124	0	33	31
2014	9	28	7	14	10	0.203	0	0.801	0.039	0.036	0	39.1	38.7	77	123	121	0	32	31
2014	9	28	7	24	10	0.197	-0.052	0.801	0.036	0.033	0	39.1	39.6	77.8	123	123	0	32	31
2014	9	28	7	34	10	0.325	-0.033	0.801	0.033	0.03	0	39.1	38.7	77.8	123	122	0	32	32
2014	9	28	7	44	10	0.177	-0.03	0.801	0.033	0.03	0	38.7	38.3	77.8	122	121	0	32	32
2014	9	28	7	54	10	0.128	0.039	0.801	0.036	0.033	0	39.6	38.7	77.8	124	122	0	32	32
2014	9	28	8	4	10	0.177	0.007	0.801	0.039	0.036	0	38.7	38.3	77.8	122	121	0	32	32
2014	9	28	8	14	10	0.213	0.007	0.801	0.033	0.03	0	38.7	38.7	77.4	122	121	0	32	31
2014	9	28	8	24	10	0.23	-0.049	0.801	0.033	0.03	0	38.3	39.1	77.4	121	122	0	32	31
2014	9	28	8	34	10	0.177	-0.003	0.801	0.036	0.033	0	40	40	77	125	124	0	32	31
2014	9	28	8	44	10	0.21	0.066	0.801	0.039	0.036	0	41.7	41.3	77	129	128	0	32	32
2014	9	28	8	54	10	0.272	0.125	0.801	0.043	0.039	0	42.1	42.6	75.7	131	130	0	33	31
2014	9	28	9	4	10	0.226	0.164	0.801	0.036	0.033	0	43.4	42.6	76.1	133	130	0	32	31
2014	9	28	9	14	10	0.21	0.157	0.801	0.036	0.033	0	42.6	42.6	75.3	132	130	0	33	31
2014	9	28	9	24	10	0.226	0.108	0.797	0.039	0.036	0	43.4	43	75.3	133	132	0	32	32
2014	9	28	9	34	10	0.223	0.092	0.801	0.043	0.039	0	43.4	43	75.7	133	132	0	32	32
2014	9	28	9	44	10	0.308	0.082	0.801	0.033	0.03	0	43	43.4	75.3	132	133	0	32	32
2014	9	28	9	54	10	0.272	-0.01	0.801	0.033	0.03	0	45.2	44.3	75.3	136	135	0	31	32
2014	9	28	10	4	10	0.305	0.085	0.801	0.033	0.03	0	44.7	44.7	74.4	136	136	0	32	32
2014	9	28	10	14	10	0.302	0.049	0.801	0.033	0.03	0	45.2	46.4	74.4	137	139	0	32	31
2014	9	28	10	24	10	0.318	0.079	0.801	0.036	0.033	0	45.2	46	74.8	137	138	0	32	31
2014	9	28	10	34	10	0.246	0.066	0.801	0.033	0.03	0	46	46.4	74.4	139	140	0	32	32
2014	9	28	10	44	10	0.322	0.112	0.797	0.036	0.033	0	47.7	48.2	73.1	143	143	0	32	31
2014	9	28	10	54	10	0.217	0.046	0.801	0.033	0.03	0	48.2	48.6	71.8	144	144	0	32	31
2014	9	28	11	4	10	0.305	0.141	0.797	0.033	0.03	0	47.3	48.2	72.2	142	143	0	32	31
2014	9	28	11	14	10	0.249	0.128	0.801	0.033	0.03	0	48.2	49	73.1	144	146	0	32	32
2014	9	28	11	24	10	0.308	0.095	0.801	0.033	0.03	0	46.9	48.6	73.1	141	144	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	11	34	10	0.253	0.03	0.801	0.03	0.03	0	46.9	50.3	73.5	141	147	0	32	30
2014	9	28	11	44	10	0.266	0.095	0.801	0.039	0.036	0	47.7	49.5	73.1	143	146	0	32	31
2014	9	28	11	54	10	0.282	-0.03	0.801	0.03	0.03	0	46.9	49.9	73.5	141	147	0	32	31
2014	9	28	12	4	10	0.266	0.049	0.801	0.03	0.03	0	47.7	49.9	73.5	143	147	0	32	31
2014	9	28	12	14	10	0.23	0.033	0.801	0.036	0.033	0	47.3	50.3	71.8	142	148	0	32	31
2014	9	28	12	24	10	0.256	0.016	0.801	0.033	0.03	0	47.7	49.9	73.1	143	147	0	32	31
2014	9	28	12	34	10	0.269	0	0.797	0.036	0.033	0	47.7	50.3	73.5	143	148	0	32	31
2014	9	28	12	44	10	0.289	0	0.801	0.033	0.033	0	49.5	50.7	71	146	149	0	31	31
2014	9	28	12	54	10	0.325	0.013	0.797	0.033	0.03	0	48.2	49.5	72.2	144	146	0	32	31
2014	9	28	13	4	10	0.256	0.092	0.797	0.036	0.033	0	50.3	51.2	71	148	150	0	31	31
2014	9	28	13	14	10	0.279	0.082	0.797	0.039	0.036	0	49.9	51.6	71	148	151	0	32	31
2014	9	28	13	24	10	0.259	0.056	0.797	0.033	0.03	0	49.9	51.6	70.5	147	151	0	31	31
2014	9	28	13	34	10	0.308	0.066	0.797	0.036	0.033	0	49	50.3	71	145	148	0	31	31
2014	9	28	13	44	10	0.21	0.089	0.797	0.036	0.033	0	48.6	50.7	71	145	148	0	32	30
2014	9	28	13	54	10	0.217	0.082	0.797	0.036	0.033	0	48.6	50.3	71.4	145	148	0	32	31
2014	9	28	14	4	10	0.24	0.007	0.797	0.036	0.033	0	49	52	70.5	146	151	0	32	30
2014	9	28	14	14	10	0.256	0.013	0.797	0.036	0.033	0	49	51.2	70.5	146	150	0	32	31
2014	9	28	14	24	10	0.292	0.026	0.797	0.033	0.03	0	49	50.7	70.5	145	148	0	31	30
2014	9	28	14	34	10	0.23	0.052	0.797	0.033	0.03	0	46.9	49.9	71.4	141	147	0	32	31
2014	9	28	14	44	10	0.187	0.023	0.797	0.033	0.03	0	49	49.9	71.4	146	148	0	32	32
2014	9	28	14	54	10	0.197	0.052	0.797	0.039	0.036	0	49	50.3	70.5	145	148	0	31	31
2014	9	28	15	4	10	0.272	-0.023	0.797	0.036	0.033	0	47.7	49.5	70.5	143	146	0	32	31
2014	9	28	15	14	10	0.246	-0.02	0.797	0.039	0.036	0	47.3	49	71.4	142	145	0	32	31
2014	9	28	15	24	10	0.243	0.03	0.797	0.033	0.03	0	45.6	47.7	72.7	138	141	0	32	30
2014	9	28	15	34	10	0.207	0.016	0.797	0.033	0.03	0	45.2	46	72.2	136	138	0	31	31
2014	9	28	15	44	10	0.256	0.023	0.797	0.036	0.033	0	45.6	48.2	72.2	138	143	0	32	31
2014	9	28	15	54	10	0.19	0.023	0.797	0.036	0.033	0	46.9	48.6	71.4	141	144	0	32	31
2014	9	28	16	4	10	0.213	0.036	0.797	0.033	0.03	0	46	47.3	72.2	138	141	0	31	31
2014	9	28	16	14	10	0.217	0.03	0.797	0.036	0.033	0	42.6	43	73.1	131	131	0	32	31
2014	9	28	16	24	10	0.259	0.079	0.797	0.03	0.03	0	46.4	48.6	70.1	140	143	0	32	30
2014	9	28	16	34	10	0.295	0	0.797	0.033	0.03	0	46	48.2	72.2	139	143	0	32	31
2014	9	28	16	44	10	0.223	0.023	0.797	0.033	0.03	0	45.6	47.3	72.2	137	141	0	31	31
2014	9	28	16	54	10	0.272	0.007	0.794	0.039	0.036	0	48.2	47.3	65.8	143	140	0	31	30
2014	9	28	17	4	10	0.266	0.007	0.794	0.036	0.033	0	47.3	47.3	67.9	141	140	0	31	30
2014	9	28	17	14	10	0.266	0.062	0.794	0.043	0.039	0	45.2	46	68.4	137	137	0	32	30
2014	9	28	17	24	10	0.21	0.039	0.794	0.043	0.043	0	44.3	43.9	69.7	134	133	0	31	31
2014	9	28	17	34	10	0.233	0.128	0.797	0.036	0.033	0	43.4	43.9	71	132	132	0	31	30
2014	9	28	17	44	10	0.23	0.108	0.797	0.039	0.036	0	42.6	42.1	70.1	130	128	0	31	30
2014	9	28	17	54	10	0.22	0.089	0.797	0.039	0.039	0	42.6	41.3	70.1	131	127	0	32	31
2014	9	28	18	4	10	0.279	0.125	0.797	0.043	0.039	0	41.3	40.9	71	128	126	0	32	31
2014	9	28	18	14	10	0.282	0.039	0.797	0.039	0.036	0	41.7	40.4	73.1	128	125	0	31	31
2014	9	28	18	24	10	0.22	0.052	0.797	0.033	0.03	0	41.3	40	74	127	124	0	31	31
2014	9	28	18	34	10	0.154	0.007	0.797	0.039	0.036	0	40.4	40	72.7	125	124	0	31	31
2014	9	28	18	44	10	0.249	0.039	0.797	0.033	0.03	0	40.9	39.1	73.5	126	122	0	31	31
2014	9	28	18	54	10	0.272	0.098	0.797	0.033	0.03	0	39.6	39.1	74.4	124	122	0	32	31
2014	9	28	19	4	10	0.207	-0.023	0.797	0.036	0.033	0	40.9	39.6	73.5	126	123	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	19	14	10	0.243	0	0.797	0.039	0.036	0	40.9	40	72.2	126	124	0	31	31
2014	9	28	19	24	10	0.223	-0.01	0.797	0.036	0.033	0	40	40	73.5	125	124	0	32	31
2014	9	28	19	34	10	0.223	-0.026	0.797	0.036	0.033	0	40.9	40.9	73.1	126	126	0	31	31
2014	9	28	19	44	10	0.292	-0.03	0.797	0.039	0.036	0	43.9	42.1	71.8	133	130	0	31	32
2014	9	28	19	54	10	0.308	0.013	0.797	0.039	0.039	0	44.3	43.9	70.5	134	133	0	31	31
2014	9	28	20	4	10	0.187	-0.039	0.797	0.036	0.033	0	42.6	42.1	72.7	130	129	0	31	31
2014	9	28	20	14	10	0.302	0.02	0.797	0.039	0.039	0	43.4	43	70.5	133	130	0	32	30
2014	9	28	20	24	10	0.203	0.013	0.797	0.039	0.039	0	44.7	43.9	70.1	136	133	0	32	31
2014	9	28	20	34	10	0.233	-0.016	0.797	0.039	0.036	0	43.9	43	71	134	131	0	32	31
2014	9	28	20	44	10	0.249	0	0.797	0.039	0.036	0	44.3	43.4	70.5	134	133	0	31	32
2014	9	28	20	54	10	0.236	-0.049	0.797	0.036	0.033	0	43	42.6	71	132	130	0	32	31
2014	9	28	21	4	10	0.285	0.056	0.797	0.036	0.033	0	43.9	43.4	72.7	133	132	0	31	31
2014	9	28	21	14	10	0.302	-0.062	0.797	0.039	0.039	0	44.3	43.4	71.8	134	132	0	31	31
2014	9	28	21	24	10	0.246	-0.016	0.797	0.036	0.033	0	43.4	43	72.2	133	131	0	32	31
2014	9	28	21	34	10	0.253	0.01	0.797	0.036	0.033	0	43	42.1	71.8	132	129	0	32	31
2014	9	28	21	44	10	0.213	0.066	0.797	0.033	0.03	0	43	42.6	71.4	132	130	0	32	31
2014	9	28	21	54	10	0.256	-0.049	0.797	0.039	0.036	0	46	44.7	70.1	139	135	0	32	31
2014	9	28	22	4	10	0.194	0.039	0.797	0.033	0.03	0	43.4	42.1	73.1	132	130	0	31	32
2014	9	28	22	14	10	0.23	0	0.801	0.036	0.033	0	44.3	43.4	74	134	132	0	31	31
2014	9	28	22	24	10	0.187	0	0.797	0.039	0.039	0	41.3	41.7	73.5	128	127	0	32	30
2014	9	28	22	34	10	0.19	-0.085	0.797	0.036	0.033	0	46.9	45.2	70.1	141	137	0	32	32
2014	9	28	22	44	10	0.226	-0.056	0.797	0.039	0.036	0	46.9	46	70.1	141	138	0	32	31
2014	9	28	22	54	10	0.308	-0.046	0.797	0.033	0.03	0	47.3	46.4	70.1	142	139	0	32	31
2014	9	28	23	4	10	0.233	-0.016	0.801	0.039	0.036	0	47.7	46.4	70.1	143	139	0	32	31
2014	9	28	23	14	10	0.19	0.033	0.797	0.036	0.033	0	44.3	43.4	71.8	135	132	0	32	31
2014	9	28	23	24	10	0.282	-0.043	0.801	0.036	0.033	0	41.3	40.9	75.3	128	126	0	32	31
2014	9	28	23	34	10	0.266	-0.049	0.801	0.036	0.033	0	40.4	40.9	75.3	126	126	0	32	31
2014	9	28	23	44	10	0.236	0.039	0.801	0.036	0.033	0	40	40	76.1	125	124	0	32	31
2014	9	28	23	54	10	0.295	0.036	0.801	0.039	0.036	0	40.9	40.4	75.7	127	126	0	32	32
2014	9	29	0	4	10	0.213	-0.02	0.801	0.039	0.036	0	40.4	40.4	76.1	125	124	0	31	30
2014	9	29	0	14	10	0.295	0.003	0.801	0.043	0.039	0	40.4	40	76.5	125	124	0	31	31
2014	9	29	0	24	10	0.282	-0.023	0.801	0.036	0.033	0	39.6	40.4	76.5	125	125	0	33	31
2014	9	29	0	34	10	0.279	-0.003	0.801	0.039	0.039	0	41.3	41.3	76.1	128	127	0	32	31
2014	9	29	0	44	10	0.233	-0.016	0.801	0.033	0.03	0	39.6	40	76.1	125	124	0	33	31
2014	9	29	0	54	10	0.203	-0.023	0.801	0.036	0.033	0	40	40.4	76.1	125	125	0	32	31
2014	9	29	1	4	10	0.213	-0.082	0.801	0.033	0.03	0	40	40.4	77	125	125	0	32	31
2014	9	29	1	14	10	0.24	-0.02	0.801	0.03	0.03	0	39.1	39.6	76.1	123	123	0	32	31
2014	9	29	1	24	10	0.243	-0.016	0.801	0.039	0.036	0	39.6	39.1	76.1	124	122	0	32	31
2014	9	29	1	34	10	0.22	-0.049	0.801	0.039	0.039	0	40	40	76.1	125	124	0	32	31
2014	9	29	1	44	10	0.223	0.036	0.801	0.039	0.036	0	40	40.4	75.7	125	125	0	32	31
2014	9	29	1	54	10	0.226	-0.023	0.801	0.036	0.033	0	40	40	76.1	125	125	0	32	32
2014	9	29	2	4	10	0.21	-0.013	0.801	0.039	0.039	0	40.4	40.9	76.1	126	126	0	32	31
2014	9	29	2	14	10	0.272	-0.066	0.801	0.039	0.036	0	40	40.9	76.1	126	126	0	33	31
2014	9	29	2	24	10	0.233	-0.046	0.801	0.039	0.039	0	40	39.1	76.1	125	123	0	32	32
2014	9	29	2	34	10	0.213	-0.043	0.801	0.039	0.039	0	40.4	40.9	76.1	126	126	0	32	31
2014	9	29	2	44	10	0.23	-0.033	0.801	0.036	0.033	0	40	40	76.1	125	124	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	2	54	10	0.243	-0.007	0.801	0.033	0.03	0	40.9	40.9	76.1	127	126	0	32	31
2014	9	29	3	4	10	0.213	0.02	0.801	0.033	0.03	0	41.3	40.9	76.1	127	126	0	31	31
2014	9	29	3	14	10	0.262	0	0.801	0.039	0.039	0	40.4	40.9	75.3	126	126	0	32	31
2014	9	29	3	24	10	0.23	0	0.801	0.039	0.036	0	40.9	40.4	75.7	127	125	0	32	31
2014	9	29	3	34	10	0.246	-0.03	0.801	0.039	0.039	0	40	40	76.1	125	125	0	32	32
2014	9	29	3	44	10	0.197	-0.062	0.801	0.039	0.036	0	40.4	40.4	74.4	126	125	0	32	31
2014	9	29	3	54	10	0.272	-0.075	0.801	0.036	0.033	0	40.4	40.9	75.3	127	126	0	33	31
2014	9	29	4	4	10	0.18	-0.026	0.801	0.043	0.039	0	40.9	41.3	75.7	128	128	0	33	32
2014	9	29	4	14	10	0.226	-0.016	0.801	0.033	0.03	0	40.4	41.3	76.1	126	127	0	32	31
2014	9	29	4	24	10	0.312	-0.013	0.801	0.036	0.033	0	40.9	40.4	75.3	127	125	0	32	31
2014	9	29	4	34	10	0.243	-0.079	0.801	0.036	0.033	0	40.9	40.4	75.3	127	125	0	32	31
2014	9	29	4	44	10	0.187	-0.131	0.801	0.036	0.033	0	40.4	40.9	74.4	126	126	0	32	31
2014	9	29	4	54	10	0.23	-0.033	0.801	0.036	0.033	0	40.9	40.9	75.3	127	126	0	32	31
2014	9	29	5	4	10	0.217	-0.069	0.801	0.039	0.036	0	40	41.7	76.5	126	129	0	33	32
2014	9	29	5	14	10	0.243	-0.066	0.801	0.039	0.039	0	40.9	40.4	75.7	128	125	0	33	31
2014	9	29	5	24	10	0.233	-0.059	0.801	0.033	0.03	0	40.9	40.4	75.3	127	125	0	32	31
2014	9	29	5	34	10	0.203	0.016	0.801	0.036	0.033	0	41.7	40.4	74.4	129	126	0	32	32
2014	9	29	5	44	10	0.276	0	0.801	0.033	0.03	0	40.4	41.3	76.5	127	127	0	33	31
2014	9	29	5	54	10	0.315	-0.052	0.801	0.039	0.039	0	41.3	40.9	75.7	128	126	0	32	31
2014	9	29	6	4	10	0.21	-0.059	0.801	0.036	0.033	0	40.9	40.9	76.1	128	126	0	33	31
2014	9	29	6	14	10	0.226	-0.013	0.801	0.039	0.036	0	40.9	41.3	74.8	127	127	0	32	31
2014	9	29	6	24	10	0.197	-0.016	0.801	0.036	0.033	0	40.9	40.4	75.3	127	126	0	32	32
2014	9	29	6	34	10	0.243	0.003	0.801	0.036	0.033	0	40.4	41.3	75.7	126	127	0	32	31
2014	9	29	6	44	10	0.213	-0.049	0.801	0.036	0.033	0	40.9	40.9	75.7	127	126	0	32	31
2014	9	29	6	54	10	0.226	-0.095	0.801	0.033	0.03	0	41.3	40.9	75.3	128	126	0	32	31
2014	9	29	7	4	10	0.174	-0.098	0.801	0.039	0.036	0	39.6	39.1	75.7	124	123	0	32	32
2014	9	29	7	14	10	0.213	-0.039	0.801	0.033	0.03	0	40	40	75.7	125	124	0	32	31
2014	9	29	7	24	10	0.279	0.016	0.801	0.033	0.03	0	39.6	39.6	75.3	124	123	0	32	31
2014	9	29	7	34	10	0.236	-0.049	0.801	0.033	0.03	0	41.7	42.1	75.3	130	129	0	33	31
2014	9	29	7	44	10	0.213	-0.013	0.801	0.039	0.036	0	41.3	40.9	77	129	126	0	33	31
2014	9	29	7	54	10	0.256	-0.069	0.801	0.039	0.039	0	47.3	46	71.4	142	139	0	32	32
2014	9	29	8	4	10	0.226	0.003	0.801	0.039	0.036	0	43.9	43	75.3	134	132	0	32	32
2014	9	29	8	14	10	0.253	0.039	0.801	0.039	0.036	0	41.7	41.3	75.7	130	128	0	33	32
2014	9	29	8	24	10	0.256	-0.043	0.801	0.039	0.036	0	43.4	43.4	74	133	132	0	32	31
2014	9	29	8	34	10	0.223	0.036	0.801	0.039	0.039	0	44.3	43.9	73.5	136	134	0	33	32
2014	9	29	8	44	10	0.305	0.043	0.801	0.039	0.036	0	43.9	43.9	74.8	135	133	0	33	31
2014	9	29	8	54	10	0.266	0	0.801	0.033	0.03	0	42.1	42.6	75.7	131	130	0	33	31
2014	9	29	9	4	10	0.318	0.007	0.801	0.033	0.03	0	41.3	41.3	76.1	128	128	0	32	32
2014	9	29	9	14	10	0.233	0.03	0.801	0.033	0.03	0	40.4	40.4	77	127	126	0	33	32
2014	9	29	9	24	10	0.194	-0.02	0.801	0.039	0.039	0	40	40.4	76.5	125	126	0	32	32
2014	9	29	9	34	10	0.177	0.066	0.801	0.039	0.036	0	40.4	40.9	77	127	127	0	33	32
2014	9	29	9	44	10	0.226	-0.023	0.801	0.039	0.036	0	40.9	40.9	76.5	127	127	0	32	32
2014	9	29	9	54	10	0.253	0.023	0.801	0.036	0.033	0	42.1	41.3	76.5	130	128	0	32	32
2014	9	29	10	4	10	0.289	-0.043	0.801	0.033	0.03	0	41.3	41.7	76.5	129	130	0	33	33
2014	9	29	10	14	10	0.269	0	0.801	0.033	0.03	0	43	43.4	77	132	133	0	32	32
2014	9	29	10	24	10	0.233	-0.01	0.801	0.036	0.033	0	43.4	45.6	77	133	137	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	10	34	10	0.236	0.062	0.801	0.033	0.03	0	43	45.2	76.1	133	137	0	33	32
2014	9	29	10	44	10	0.272	0.01	0.801	0.039	0.036	0	43.9	45.6	75.3	135	138	0	33	32
2014	9	29	10	54	10	0.253	0.013	0.801	0.033	0.03	0	46	46.4	74.4	139	140	0	32	32
2014	9	29	11	4	10	0.279	0	0.801	0.033	0.03	0	45.2	46.9	74.4	138	140	0	33	31
2014	9	29	11	14	10	0.289	0.026	0.801	0.033	0.03	0	46	47.3	74.4	139	141	0	32	31
2014	9	29	11	24	10	0.279	0	0.801	0.033	0.03	0	45.6	47.7	74.8	138	142	0	32	31
2014	9	29	11	34	10	0.272	0.046	0.801	0.033	0.03	0	46.9	46.9	74.4	141	141	0	32	32
2014	9	29	11	44	10	0.184	0.026	0.801	0.036	0.033	0	46.9	48.6	74.4	141	144	0	32	31
2014	9	29	11	54	10	0.282	0.046	0.801	0.033	0.033	0	48.2	49.5	73.5	144	146	0	32	31
2014	9	29	12	4	10	0.269	0.03	0.801	0.033	0.03	0	47.3	50.3	74	143	148	0	33	31
2014	9	29	12	14	10	0.266	0.075	0.801	0.033	0.03	0	48.6	50.7	72.7	145	148	0	32	30
2014	9	29	12	24	10	0.292	0.089	0.801	0.033	0.03	0	48.6	50.3	72.7	145	148	0	32	31
2014	9	29	12	34	10	0.256	0.059	0.801	0.036	0.033	0	49.5	51.6	70.5	147	151	0	32	31
2014	9	29	12	44	10	0.249	0.049	0.801	0.033	0.03	0	49.9	51.6	72.7	147	151	0	31	31
2014	9	29	12	54	10	0.285	0.066	0.801	0.033	0.03	0	49.9	51.6	71.8	148	151	0	32	31
2014	9	29	13	4	10	0.318	0.112	0.801	0.033	0.033	0	50.3	52	71.8	149	152	0	32	31
2014	9	29	13	14	10	0.285	0.046	0.801	0.033	0.03	0	50.7	52.5	71	150	153	0	32	31
2014	9	29	13	24	10	0.295	0.033	0.797	0.033	0.03	0	49.9	51.6	71.8	148	151	0	32	31
2014	9	29	13	34	10	0.295	0.01	0.797	0.039	0.036	0	49	51.6	70.5	146	151	0	32	31
2014	9	29	13	44	10	0.269	0.075	0.797	0.033	0.03	0	49.9	51.6	71.8	148	151	0	32	31
2014	9	29	13	54	10	0.305	0.033	0.801	0.03	0.03	0	49.9	51.6	70.5	147	152	0	31	32
2014	9	29	14	4	10	0.322	0.062	0.801	0.033	0.03	0	50.7	51.6	71.8	149	151	0	31	31
2014	9	29	14	14	10	0.292	0.016	0.801	0.033	0.033	0	49.5	52.5	70.1	146	153	0	31	31
2014	9	29	14	24	10	0.305	0.066	0.801	0.033	0.03	0	49.5	51.2	71.4	147	151	0	32	32
2014	9	29	14	34	10	0.325	0.016	0.801	0.033	0.03	0	49	52	71	146	151	0	32	30
2014	9	29	14	44	10	0.279	0.01	0.801	0.033	0.03	0	49.5	51.6	71.4	146	151	0	31	31
2014	9	29	14	54	10	0.335	0.036	0.801	0.03	0.03	0	49.5	52	70.1	146	151	0	31	30
2014	9	29	15	4	10	0.253	0.052	0.801	0.033	0.03	0	49.5	51.6	71	147	151	0	32	31
2014	9	29	15	14	10	0.325	0.066	0.801	0.033	0.03	0	50.3	51.6	71	148	151	0	31	31
2014	9	29	15	24	10	0.292	-0.033	0.801	0.03	0.03	0	49.5	51.2	71.4	146	150	0	31	31
2014	9	29	15	34	10	0.233	-0.036	0.801	0.033	0.033	0	49	50.3	71.8	146	148	0	32	31
2014	9	29	15	44	10	0.272	0	0.801	0.033	0.03	0	49.5	51.6	70.5	146	150	0	31	30
2014	9	29	15	54	10	0.279	0.075	0.801	0.033	0.03	0	48.6	50.7	70.5	144	149	0	31	31
2014	9	29	16	4	10	0.259	0.049	0.801	0.033	0.03	0	48.2	49.5	72.7	143	146	0	31	31
2014	9	29	16	14	10	0.295	-0.016	0.801	0.036	0.033	0	47.3	49.5	72.2	141	146	0	31	31
2014	9	29	16	24	10	0.295	0.016	0.801	0.033	0.03	0	46.4	48.2	72.7	139	142	0	31	30
2014	9	29	16	34	10	0.259	-0.033	0.801	0.033	0.03	0	46	47.3	72.7	138	141	0	31	31
2014	9	29	16	44	10	0.269	0.003	0.801	0.033	0.03	0	45.2	46.4	73.1	136	139	0	31	31
2014	9	29	16	54	10	0.243	-0.003	0.801	0.036	0.033	0	45.2	45.6	73.1	136	137	0	31	31
2014	9	29	17	4	10	0.24	0.03	0.801	0.033	0.033	0	44.7	45.2	73.5	135	135	0	31	30
2014	9	29	17	14	10	0.256	0.118	0.801	0.033	0.03	0	44.7	44.7	72.7	135	135	0	31	31
2014	9	29	17	24	10	0.328	0.092	0.801	0.039	0.036	0	44.7	44.7	73.1	135	134	0	31	30
2014	9	29	17	34	10	0.302	0.187	0.801	0.039	0.036	0	46	45.6	72.2	137	136	0	30	30
2014	9	29	17	44	10	0.289	0.19	0.801	0.033	0.03	0	45.6	44.7	72.2	137	134	0	31	30
2014	9	29	17	54	10	0.289	0.223	0.804	0.043	0.039	0	46	44.3	72.7	138	134	0	31	31
2014	9	29	18	4	10	0.325	0.223	0.804	0.039	0.039	0	45.2	43.9	72.2	136	133	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	18	14	10	0.331	0.226	0.804	0.036	0.033	0	44.7	43.4	73.1	135	132	0	31	31
2014	9	29	18	24	10	0.325	0.279	0.804	0.039	0.036	0	43	42.6	74.4	132	130	0	32	31
2014	9	29	18	34	10	0.318	0.131	0.804	0.033	0.03	0	43	41.7	74.4	131	128	0	31	31
2014	9	29	18	44	10	0.256	0.177	0.804	0.039	0.039	0	42.6	41.3	74.8	130	127	0	31	31
2014	9	29	18	54	10	0.279	0.108	0.804	0.036	0.033	0	43	42.1	74	132	129	0	32	31
2014	9	29	19	4	10	0.259	0.098	0.804	0.039	0.039	0	43	42.1	75.3	131	129	0	31	31
2014	9	29	19	14	10	0.249	0.167	0.804	0.033	0.03	0	43.9	43	74.8	133	130	0	31	30
2014	9	29	19	24	10	0.18	0.102	0.804	0.036	0.033	0	43.9	43	74.4	133	131	0	31	31
2014	9	29	19	34	10	0.236	0.102	0.804	0.039	0.039	0	44.3	44.3	74.4	135	133	0	32	30
2014	9	29	19	44	10	0.187	0.115	0.804	0.036	0.033	0	43.9	43.4	74.8	134	132	0	32	31
2014	9	29	19	54	10	0.305	0.039	0.804	0.039	0.036	0	44.3	43.4	74.4	134	131	0	31	30
2014	9	29	20	4	10	0.249	0.102	0.804	0.036	0.033	0	44.3	43.4	74.8	134	132	0	31	31
2014	9	29	20	14	10	0.285	0.069	0.804	0.039	0.036	0	45.2	43.9	74.4	136	133	0	31	31
2014	9	29	20	24	10	0.266	0.007	0.807	0.039	0.039	0	43.9	42.6	74.8	133	130	0	31	31
2014	9	29	20	34	10	0.308	0.01	0.804	0.033	0.03	0	44.7	44.7	74.4	136	134	0	32	30
2014	9	29	20	44	10	0.272	-0.033	0.807	0.033	0.03	0	44.7	43.4	76.1	134	131	0	30	30
2014	9	29	20	54	10	0.302	0.003	0.807	0.036	0.033	0	44.7	43.4	75.3	135	131	0	31	30
2014	9	29	21	4	10	0.223	0.039	0.807	0.039	0.039	0	42.6	42.1	75.7	130	128	0	31	30
2014	9	29	21	14	10	0.24	0.02	0.807	0.036	0.033	0	40.9	40.9	77	126	125	0	31	30
2014	9	29	21	24	10	0.249	-0.039	0.807	0.039	0.039	0	42.6	41.3	76.5	130	127	0	31	31
2014	9	29	21	34	10	0.272	-0.062	0.807	0.046	0.043	0	43.4	43	77	133	130	0	32	30
2014	9	29	21	44	10	0.279	-0.075	0.807	0.039	0.036	0	43	42.6	77	131	129	0	31	30
2014	9	29	21	54	10	0.253	0.052	0.807	0.039	0.036	0	43	42.1	77	132	129	0	32	31
2014	9	29	22	4	10	0.269	-0.01	0.807	0.036	0.033	0	41.7	41.7	77	129	128	0	32	31
2014	9	29	22	14	10	0.21	-0.013	0.807	0.039	0.036	0	41.3	40.4	77.4	129	125	0	33	31
2014	9	29	22	24	10	0.295	-0.033	0.807	0.036	0.033	0	43.4	42.6	76.5	132	129	0	31	30
2014	9	29	22	34	10	0.253	-0.098	0.807	0.033	0.03	0	41.7	41.3	77.8	128	127	0	31	31
2014	9	29	22	44	10	0.285	0.016	0.807	0.039	0.036	0	41.7	41.3	77	128	127	0	31	31
2014	9	29	22	54	10	0.305	-0.033	0.807	0.039	0.039	0	41.3	40.9	77.4	128	126	0	32	31
2014	9	29	23	4	10	0.289	-0.033	0.807	0.036	0.033	0	41.3	40.9	77.4	128	126	0	32	31
2014	9	29	23	14	10	0.276	-0.105	0.807	0.036	0.033	0	41.7	40.4	76.5	128	125	0	31	31
2014	9	29	23	24	10	0.236	-0.161	0.807	0.039	0.036	0	43	41.3	76.5	130	127	0	30	31
2014	9	29	23	34	10	0.299	-0.033	0.807	0.036	0.033	0	42.6	41.7	76.5	131	128	0	32	31
2014	9	29	23	44	10	0.259	-0.039	0.804	0.039	0.036	0	43.9	43.4	74.8	134	132	0	32	31
2014	9	29	23	54	10	0.203	-0.033	0.807	0.033	0.03	0	41.7	41.3	77.4	129	127	0	32	31
2014	9	30	0	4	10	0.276	-0.095	0.807	0.033	0.03	0	40.9	40.4	77.8	127	126	0	32	32
2014	9	30	0	14	10	0.279	-0.092	0.807	0.039	0.039	0	41.7	40	77.4	128	125	0	31	32
2014	9	30	0	24	10	0.194	-0.089	0.807	0.039	0.036	0	40.9	40.9	77.4	127	126	0	32	31
2014	9	30	0	34	10	0.269	-0.112	0.807	0.033	0.03	0	45.2	44.3	75.3	137	134	0	32	31
2014	9	30	0	44	10	0.315	-0.046	0.807	0.039	0.039	0	43	42.1	75.7	131	129	0	31	31
2014	9	30	0	54	10	0.233	-0.046	0.807	0.033	0.03	0	40.4	40.4	77.8	126	126	0	32	32
2014	9	30	1	4	10	0.253	-0.046	0.807	0.039	0.039	0	40.9	40	78.3	127	124	0	32	31
2014	9	30	1	14	10	0.184	-0.059	0.807	0.036	0.033	0	40.4	40.4	77	126	125	0	32	31
2014	9	30	1	24	10	0.21	0.016	0.804	0.033	0.03	0	41.3	40.9	77	128	127	0	32	32
2014	9	30	1	34	10	0.272	-0.059	0.804	0.043	0.039	0	43	42.6	75.7	132	130	0	32	31
2014	9	30	1	44	10	0.217	-0.023	0.804	0.036	0.033	0	43	42.1	75.7	132	129	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	1	54	10	0.223	-0.016	0.804	0.036	0.033	0	45.2	44.3	74.4	137	134	0	32	31
2014	9	30	2	4	10	0.207	-0.069	0.804	0.039	0.039	0	46.4	45.2	73.5	140	135	0	32	30
2014	9	30	2	14	10	0.249	-0.013	0.804	0.039	0.036	0	43.9	43.4	75.3	134	132	0	32	31
2014	9	30	2	24	10	0.217	-0.052	0.804	0.039	0.039	0	44.3	43.4	74.8	134	132	0	31	31
2014	9	30	2	34	10	0.194	-0.085	0.804	0.043	0.039	0	43.4	43	75.7	133	130	0	32	30
2014	9	30	2	44	10	0.295	-0.075	0.804	0.039	0.039	0	42.1	41.7	76.1	130	128	0	32	31
2014	9	30	2	54	10	0.259	-0.03	0.804	0.039	0.036	0	41.7	41.3	76.5	129	127	0	32	31
2014	9	30	3	4	10	0.2	-0.043	0.804	0.043	0.039	0	40.9	40.9	77	127	126	0	32	31
2014	9	30	3	14	10	0.276	0	0.804	0.033	0.03	0	40	40	77	125	125	0	32	32
2014	9	30	3	24	10	0.289	-0.135	0.804	0.036	0.033	0	40.9	40	77.8	127	124	0	32	31
2014	9	30	3	34	10	0.203	-0.098	0.804	0.039	0.039	0	40.9	40	77.4	127	124	0	32	31
2014	9	30	3	44	10	0.299	-0.033	0.804	0.033	0.03	0	40	39.1	77.8	125	122	0	32	31
2014	9	30	3	54	10	0.236	-0.016	0.804	0.033	0.03	0	40.4	39.1	77	126	122	0	32	31
2014	9	30	4	4	10	0.23	-0.072	0.804	0.036	0.033	0	40	39.6	77.8	125	123	0	32	31
2014	9	30	4	14	10	0.289	-0.026	0.804	0.036	0.033	0	40.4	40.9	77.4	126	126	0	32	31
2014	9	30	4	24	10	0.213	0.003	0.804	0.033	0.03	0	40.4	40.4	77	126	125	0	32	31
2014	9	30	4	34	10	0.161	-0.056	0.804	0.036	0.033	0	40.4	40.4	77.8	126	125	0	32	31
2014	9	30	4	44	10	0.213	-0.026	0.804	0.039	0.036	0	40.4	40.9	77	126	126	0	32	31
2014	9	30	4	54	10	0.2	0.013	0.804	0.039	0.036	0	40.4	40.4	77	127	125	0	33	31
2014	9	30	5	4	10	0.2	-0.151	0.804	0.039	0.036	0	40.9	40	76.5	127	124	0	32	31
2014	9	30	5	14	10	0.2	-0.046	0.804	0.033	0.03	0	40	40	77	125	124	0	32	31
2014	9	30	5	24	10	0.23	-0.016	0.804	0.039	0.036	0	40	39.6	77.4	125	123	0	32	31
2014	9	30	5	34	10	0.233	-0.016	0.804	0.033	0.03	0	40.9	40	77	127	125	0	32	32
2014	9	30	5	44	10	0.253	-0.062	0.804	0.036	0.033	0	40.9	40	77.4	127	125	0	32	32
2014	9	30	5	54	10	0.262	-0.043	0.804	0.033	0.03	0	40.9	40	77	127	124	0	32	31
2014	9	30	6	4	10	0.256	-0.092	0.804	0.036	0.033	0	40.9	41.3	77	127	127	0	32	31
2014	9	30	6	14	10	0.262	0	0.804	0.033	0.03	0	40	40.9	77	126	126	0	33	31
2014	9	30	6	24	10	0.167	-0.049	0.804	0.036	0.033	0	40.4	39.6	77	126	124	0	32	32
2014	9	30	6	34	10	0.236	-0.007	0.804	0.036	0.033	0	40.9	40	76.5	127	125	0	32	32
2014	9	30	6	44	10	0.279	-0.039	0.804	0.039	0.036	0	40	39.6	76.5	125	123	0	32	31
2014	9	30	6	54	10	0.19	-0.016	0.804	0.036	0.033	0	40	39.1	76.5	125	122	0	32	31
2014	9	30	7	4	10	0.249	0	0.804	0.033	0.03	0	39.1	38.3	77.4	124	121	0	33	32
2014	9	30	7	14	10	0.302	-0.013	0.804	0.033	0.03	0	39.1	38.3	77.8	123	120	0	32	31
2014	9	30	7	24	10	0.21	-0.052	0.804	0.039	0.039	0	39.1	38.7	77.4	123	122	0	32	32
2014	9	30	7	34	10	0.259	-0.046	0.804	0.033	0.033	0	39.1	38.7	77	124	121	0	33	31
2014	9	30	7	44	10	0.236	-0.046	0.804	0.039	0.036	0	38.3	38.7	77.8	122	121	0	33	31
2014	9	30	7	54	10	0.194	-0.023	0.804	0.039	0.036	0	39.1	38.7	77	123	121	0	32	31
2014	9	30	8	4	10	0.236	0	0.804	0.036	0.033	0	39.6	38.7	77.4	125	121	0	33	31
2014	9	30	8	14	10	0.194	-0.082	0.804	0.036	0.033	0	38.3	38.7	78.3	122	121	0	33	31
2014	9	30	8	24	10	0.302	-0.082	0.804	0.036	0.033	0	39.1	39.1	77.8	123	122	0	32	31
2014	9	30	8	34	10	0.194	0.026	0.804	0.033	0.033	0	37.8	38.3	77.8	121	121	0	33	32
2014	9	30	8	44	10	0.207	-0.033	0.804	0.036	0.033	0	39.1	38.7	77.8	123	121	0	32	31
2014	9	30	8	54	10	0.148	0.016	0.804	0.039	0.036	0	38.3	37.8	77.8	122	120	0	33	32
2014	9	30	9	4	10	0.292	-0.082	0.804	0.036	0.033	0	38.3	38.3	78.3	122	120	0	33	31
2014	9	30	9	14	10	0.223	-0.036	0.804	0.039	0.036	0	38.3	38.3	78.3	122	121	0	33	32
2014	9	30	9	24	10	0.21	-0.036	0.804	0.039	0.036	0	39.1	38.3	78.3	123	120	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	9	34	10	0.184	-0.098	0.804	0.036	0.033	0	39.6	39.6	77.4	124	123	0	32	31
2014	9	30	9	44	10	0.194	-0.036	0.804	0.039	0.039	0	40	40.4	77.4	125	125	0	32	31
2014	9	30	9	54	10	0.23	-0.056	0.804	0.033	0.03	0	40.9	40.9	77	127	127	0	32	32
2014	9	30	10	4	10	0.23	-0.072	0.804	0.036	0.033	0	40.9	42.1	77	128	129	0	33	31
2014	9	30	10	14	10	0.217	0.046	0.804	0.033	0.03	0	43.4	44.7	75.7	134	135	0	33	31
2014	9	30	10	24	10	0.322	0.01	0.801	0.036	0.033	0	43.4	44.7	76.1	134	135	0	33	31
2014	9	30	10	34	10	0.279	-0.112	0.801	0.033	0.03	0	43.9	45.2	75.7	134	137	0	32	32
2014	9	30	10	44	10	0.197	0.003	0.801	0.033	0.03	0	44.3	45.6	76.5	135	138	0	32	32
2014	9	30	10	54	10	0.266	0.01	0.801	0.033	0.03	0	44.7	47.3	75.7	137	141	0	33	31
2014	9	30	11	4	10	0.276	0.033	0.804	0.033	0.03	0	46.9	48.6	75.7	141	145	0	32	32
2014	9	30	11	14	10	0.249	0	0.804	0.033	0.03	0	45.6	48.2	74.8	138	144	0	32	32
2014	9	30	11	24	10	0.266	0.007	0.804	0.036	0.033	0	46.9	49	75.3	140	145	0	31	31
2014	9	30	11	34	10	0.138	0.049	0.804	0.033	0.03	0	48.6	50.3	73.5	144	148	0	31	31
2014	9	30	11	44	10	0.325	0.023	0.804	0.033	0.03	0	47.3	49.5	74	143	146	0	33	31
2014	9	30	11	54	10	0.249	0.023	0.804	0.03	0.03	0	47.7	49.5	75.3	142	146	0	31	31
2014	9	30	12	4	10	0.24	-0.01	0.804	0.033	0.03	0	47.3	49	74.8	142	146	0	32	32
2014	9	30	12	14	10	0.276	0.013	0.801	0.036	0.033	0	49.5	50.3	72.7	146	148	0	31	31
2014	9	30	12	24	10	0.233	0.059	0.801	0.033	0.03	0	48.2	50.7	74.4	144	149	0	32	31
2014	9	30	12	34	10	0.305	0.033	0.801	0.036	0.033	0	49.5	51.6	74	146	151	0	31	31
2014	9	30	12	44	10	0.217	0.016	0.801	0.036	0.033	0	48.6	50.7	72.7	145	149	0	32	31
2014	9	30	12	54	10	0.22	0.112	0.801	0.033	0.03	0	49.9	52	73.1	147	152	0	31	31
2014	9	30	13	4	10	0.243	0.062	0.801	0.036	0.033	0	49.9	52	72.7	148	152	0	32	31
2014	9	30	13	14	10	0.269	0.049	0.801	0.036	0.033	0	49.9	51.6	73.1	147	151	0	31	31
2014	9	30	13	24	10	0.22	0.085	0.801	0.036	0.033	0	49.5	52	71.4	147	152	0	32	31
2014	9	30	13	34	10	0.256	0.01	0.801	0.033	0.03	0	49.5	52	71.8	147	152	0	32	31
2014	9	30	13	44	10	0.318	0.043	0.801	0.033	0.033	0	50.3	52.5	71	149	153	0	32	31
2014	9	30	13	54	10	0.318	0.069	0.801	0.033	0.03	0	50.3	52	71.4	148	152	0	31	31
2014	9	30	14	4	10	0.249	0.049	0.801	0.039	0.036	0	49.5	51.6	71.4	147	151	0	32	31
2014	9	30	14	14	10	0.269	0.052	0.801	0.033	0.03	0	49.5	52	71.4	147	152	0	32	31
2014	9	30	14	24	10	0.236	0.082	0.801	0.033	0.03	0	49	51.6	69.7	146	151	0	32	31
2014	9	30	14	34	10	0.21	0.03	0.801	0.03	0.03	0	49.9	52	70.5	147	152	0	31	31
2014	9	30	14	44	10	0.262	-0.049	0.801	0.033	0.03	0	49.5	52.5	71.4	146	152	0	31	30
2014	9	30	14	54	10	0.243	0.003	0.801	0.033	0.03	0	49.5	51.2	70.5	147	150	0	32	31
2014	9	30	15	4	10	0.276	-0.02	0.801	0.033	0.03	0	49.5	51.6	71.4	147	150	0	32	30
2014	9	30	15	14	10	0.249	0	0.801	0.036	0.033	0	49	52	71	146	151	0	32	30
2014	9	30	15	24	10	0.295	0.01	0.797	0.036	0.033	0	49.5	52	69.7	146	151	0	31	30
2014	9	30	15	34	10	0.253	-0.016	0.801	0.033	0.03	0	49.9	52.5	70.1	147	153	0	31	31
2014	9	30	15	44	10	0.272	0	0.797	0.033	0.03	0	49.5	52	70.1	146	151	0	31	30
2014	9	30	15	54	10	0.276	0.049	0.801	0.033	0.03	0	49.5	51.2	69.7	146	150	0	31	31
2014	9	30	16	4	10	0.2	0.023	0.797	0.039	0.036	0	49.5	52	70.1	146	151	0	31	30
2014	9	30	16	14	10	0.2	0.016	0.797	0.033	0.03	0	49	51.2	71	145	149	0	31	30
2014	9	30	16	24	10	0.325	0.02	0.797	0.036	0.033	0	47.7	48.6	71	142	144	0	31	31
2014	9	30	16	34	10	0.285	0.036	0.797	0.033	0.03	0	46.9	49	70.1	140	144	0	31	30
2014	9	30	16	44	10	0.213	0.043	0.797	0.036	0.033	0	45.6	47.7	71	138	141	0	32	30
2014	9	30	16	54	10	0.243	0.082	0.797	0.039	0.036	0	45.6	45.6	72.2	137	137	0	31	31
2014	9	30	17	4	10	0.305	-0.016	0.797	0.039	0.036	0	43.4	43.9	73.1	132	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	17	14	10	0.249	0.013	0.797	0.046	0.046	0	41.7	41.3	73.5	128	127	0	31	31
2014	9	30	17	24	10	0.262	-0.003	0.797	0.033	0.03	0	40	40	74.4	125	123	0	32	30
2014	9	30	17	34	10	0.177	0.013	0.797	0.033	0.03	0	40	40	73.5	124	123	0	31	30
2014	9	30	17	44	10	0.266	0.112	0.797	0.036	0.033	0	39.6	39.1	73.5	123	122	0	31	31
2014	9	30	17	54	10	0.308	0.098	0.797	0.039	0.036	0	39.6	38.7	73.5	123	121	0	31	31
2014	9	30	18	4	10	0.223	0.039	0.797	0.039	0.036	0	38.7	38.3	74.4	121	120	0	31	31
2014	9	30	18	14	10	0.299	0.003	0.797	0.039	0.036	0	39.1	38.3	73.5	122	120	0	31	31
2014	9	30	18	24	10	0.272	-0.007	0.797	0.043	0.039	0	39.1	38.7	74	122	120	0	31	30
2014	9	30	18	34	10	0.243	0.007	0.797	0.039	0.039	0	39.1	37.8	74	122	119	0	31	31
2014	9	30	18	44	10	0.23	-0.033	0.797	0.039	0.036	0	39.1	39.1	74	122	121	0	31	30
2014	9	30	18	54	10	0.226	0.016	0.797	0.039	0.039	0	39.6	39.6	74	122	122	0	30	30
2014	9	30	19	4	10	0.262	-0.085	0.797	0.039	0.039	0	40	40	74	124	123	0	31	30
2014	9	30	19	14	10	0.285	-0.075	0.797	0.033	0.03	0	40.9	40	74	126	123	0	31	30
2014	9	30	19	24	10	0.246	-0.043	0.797	0.033	0.03	0	40.4	40.9	74	125	125	0	31	30
2014	9	30	19	34	10	0.21	0.003	0.797	0.033	0.03	0	40.4	40.4	74.8	125	124	0	31	30
2014	9	30	19	44	10	0.262	-0.043	0.797	0.033	0.03	0	40.9	40.9	73.5	126	126	0	31	31
2014	9	30	19	54	10	0.223	-0.082	0.797	0.039	0.036	0	40.9	40	74	126	124	0	31	31
2014	9	30	20	4	10	0.266	-0.046	0.797	0.036	0.033	0	41.7	41.3	73.5	129	127	0	32	31
2014	9	30	20	14	10	0.282	0.013	0.797	0.036	0.033	0	41.3	40.9	74	127	126	0	31	31
2014	9	30	20	24	10	0.318	0.125	0.797	0.039	0.036	0	42.6	41.7	72.7	131	128	0	32	31
2014	9	30	20	34	10	0.223	0.046	0.797	0.039	0.039	0	42.6	41.7	73.1	130	128	0	31	31
2014	9	30	20	44	10	0.256	0.072	0.797	0.033	0.03	0	43	41.7	72.7	132	128	0	32	31
2014	9	30	20	54	10	0.276	0	0.797	0.043	0.039	0	41.7	41.7	73.1	129	127	0	32	30
2014	9	30	21	4	10	0.2	0.016	0.797	0.033	0.03	0	41.7	40.9	74	129	126	0	32	31
2014	9	30	21	14	10	0.279	-0.059	0.797	0.039	0.039	0	41.7	40.4	74.4	127	125	0	30	31
2014	9	30	21	24	10	0.213	-0.016	0.797	0.036	0.033	0	40.4	40.9	74	125	125	0	31	30
2014	9	30	21	34	10	0.213	-0.016	0.797	0.039	0.036	0	40.4	40.4	74.4	126	125	0	32	31
2014	9	30	21	44	10	0.24	-0.069	0.797	0.036	0.033	0	40.9	40.4	74.8	126	124	0	31	30
2014	9	30	21	54	10	0.276	0.003	0.797	0.043	0.039	0	40.4	40.4	75.3	126	125	0	32	31
2014	9	30	22	4	10	0.262	-0.02	0.797	0.039	0.039	0	40.4	39.6	75.3	125	123	0	31	31
2014	9	30	22	14	10	0.24	-0.089	0.797	0.033	0.03	0	40.9	40	74.8	126	124	0	31	31
2014	9	30	22	24	10	0.289	-0.02	0.797	0.033	0.03	0	40.4	40	75.3	126	123	0	32	30
2014	9	30	22	34	10	0.292	-0.043	0.797	0.036	0.033	0	40	40	75.3	124	124	0	31	31
2014	9	30	22	44	10	0.22	-0.052	0.797	0.036	0.033	0	40.9	41.3	71.4	127	127	0	32	31
2014	9	30	22	54	10	0.249	-0.079	0.797	0.039	0.036	0	43.9	43.4	70.1	134	132	0	32	31
2014	9	30	23	4	10	0.187	-0.102	0.794	0.043	0.039	0	46	45.2	67.5	138	135	0	31	30
2014	9	30	23	14	10	0.213	0.02	0.794	0.043	0.039	0	46	44.7	67.5	138	134	0	31	30
2014	9	30	23	24	10	0.262	0.01	0.797	0.036	0.033	0	45.6	45.6	70.1	138	136	0	32	30
2014	9	30	23	34	10	0.236	0	0.797	0.039	0.039	0	48.2	46.9	65.8	144	140	0	32	31
2014	9	30	23	44	10	0.2	-0.023	0.794	0.036	0.033	0	48.6	47.3	65.8	144	141	0	31	31
2014	9	30	23	54	10	0.233	-0.056	0.797	0.036	0.033	0	45.6	44.7	70.1	137	135	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	0	2	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	1	0	12	18	31	0	0	0	0	0	0	0	69.12	0	0	12
2014	9	1	0	22	18	31	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	1	0	32	18	31	0	0	0	0	0	0	0	68.9	0	0	12
2014	9	1	0	42	18	31	0	0	0	0	0	0	0	68.79	0	0	12
2014	9	1	0	52	18	31	0	0	0	0	0	0	0	68.7	0	0	12
2014	9	1	1	2	18	31	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	1	1	12	18	31	0	0	0	0	0	0	0	68.49	0	0	12
2014	9	1	1	22	18	32	0	0	0	0	0	0	0	68.38	0	0	12
2014	9	1	1	32	18	31	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	1	1	42	18	31	0	0	0	0	0	0	0	68.18	0	0	12
2014	9	1	1	52	18	31	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	1	2	2	18	31	0	0	0	0	0	0	0	68	0	0	12
2014	9	1	2	12	18	32	0	0	0	0	0	0	0	67.89	0	0	12
2014	9	1	2	22	18	32	0	0	0	0	0	0	0	67.78	0	0	11.8
2014	9	1	2	32	18	31	0	0	0	0	0	0	0	67.68	0	0	12
2014	9	1	2	42	18	32	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	1	2	52	18	31	0	0	0	0	0	0	0	67.51	0	0	12
2014	9	1	3	2	18	32	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	1	3	12	18	32	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	1	3	22	18	31	0	0	0	0	0	0	0	67.26	0	0	11.8
2014	9	1	3	32	18	31	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	1	3	42	18	31	0	0	0	0	0	0	0	67.08	0	0	12
2014	9	1	3	52	18	32	0	0	0	0	0	0	0	66.99	0	0	12
2014	9	1	4	2	18	31	0	0	0	0	0	0	0	66.92	0	0	12
2014	9	1	4	12	18	32	0	0	0	0	0	0	0	66.87	0	0	12
2014	9	1	4	22	18	32	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	1	4	32	18	31	0	0	0	0	0	0	0	66.74	0	0	12
2014	9	1	4	42	18	31	0	0	0	0	0	0	0	66.69	0	0	12
2014	9	1	4	52	18	32	0	0	0	0	0	0	0	66.61	0	0	12
2014	9	1	5	2	18	32	0	0	0	0	0	0	0	66.54	0	0	12
2014	9	1	5	12	18	32	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	1	5	22	18	32	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	1	5	32	18	31	0	0	0	0	0	0	0	66.29	0	0	12
2014	9	1	5	42	18	31	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	1	5	52	18	32	0	0	0	0	0	0	0	66.11	0	0	12
2014	9	1	6	2	18	32	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	1	6	12	18	32	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	1	6	22	18	32	0	0	0	0	0	0	0	65.79	0	0	11.8
2014	9	1	6	32	18	31	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	1	6	42	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	1	6	52	18	31	0	0	0	0	0	0	0	65.52	0	0	12
2014	9	1	7	2	18	31	0	0	0	0	0	0	0	65.43	0	0	12
2014	9	1	7	12	18	32	0	0	0	0	0	0	0	65.34	0	0	12
2014	9	1	7	22	18	32	0	0	0	0	0	0	0	65.26	0	0	12
2014	9	1	7	32	18	33	0	0	0	0	0	0	0	65.19	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	7	42	18	33	0	0	0	0	0	0	0	65.14	0	0	12.6
2014	9	1	7	52	18	32	0	0	0	0	0	0	0	65.07	0	0	12.8
2014	9	1	8	2	18	31	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	1	8	12	18	31	0	0	0	0	0	0	0	65.01	0	0	13
2014	9	1	8	22	18	32	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	1	8	32	18	32	0	0	0	0	0	0	0	64.98	0	0	13.2
2014	9	1	8	42	18	33	0	0	0	0	0	0	0	64.96	0	0	13.2
2014	9	1	8	52	18	32	0	0	0	0	0	0	0	64.98	0	0	13.4
2014	9	1	9	2	18	32	0	0	0	0	0	0	0	65.5	0	0	13.4
2014	9	1	9	12	18	32	0	0	0	0	0	0	0	65.7	0	0	13.4
2014	9	1	9	22	18	32	0	0	0	0	0	0	0	65.82	0	0	13.2
2014	9	1	9	32	18	32	0	0	0	0	0	0	0	65.91	0	0	13.4
2014	9	1	9	42	18	31	0	0	0	0	0	0	0	66.04	0	0	13.4
2014	9	1	9	52	18	32	0	0	0	0	0	0	0	66.13	0	0	13.4
2014	9	1	10	2	18	32	0	0	0	0	0	0	0	66.24	0	0	13.4
2014	9	1	10	12	18	32	0	0	0	0	0	0	0	66.34	0	0	13.4
2014	9	1	10	22	18	32	0	0	0	0	0	0	0	66.52	0	0	13.2
2014	9	1	10	32	18	32	0	0	0	0	0	0	0	66.72	0	0	13.2
2014	9	1	10	42	18	32	0	0	0	0	0	0	0	66.85	0	0	13.2
2014	9	1	10	52	18	32	0	0	0	0	0	0	0	67.01	0	0	13.2
2014	9	1	11	2	18	32	0	0	0	0	0	0	0	66.42	0	0	13.2
2014	9	1	11	12	18	31	0	0	0	0	0	0	0	66.47	0	0	13.2
2014	9	1	11	22	18	32	0	0	0	0	0	0	0	66.69	0	0	13.2
2014	9	1	11	32	18	31	0	0	0	0	0	0	0	66.9	0	0	13.2
2014	9	1	11	42	18	31	0	0	0	0	0	0	0	67.15	0	0	13.2
2014	9	1	11	52	18	31	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	1	12	2	18	32	0	0	0	0	0	0	0	68.29	0	0	13.2
2014	9	1	12	12	18	32	0	0	0	0	0	0	0	68.92	0	0	13.2
2014	9	1	12	22	18	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2014	9	1	12	32	18	31	0	0	0	0	0	0	0	69.71	0	0	13.2
2014	9	1	12	42	18	32	0	0	0	0	0	0	0	70.05	0	0	13.2
2014	9	1	12	52	18	32	0	0	0	0	0	0	0	70.34	0	0	13.2
2014	9	1	13	2	18	31	0	0	0	0	0	0	0	70.72	0	0	13.2
2014	9	1	13	12	18	31	0	0	0	0	0	0	0	71.02	0	0	13.2
2014	9	1	13	22	18	31	0	0	0	0	0	0	0	71.38	0	0	13.2
2014	9	1	13	32	18	30	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	9	1	13	42	18	31	0	0	0	0	0	0	0	72.09	0	0	13.2
2014	9	1	13	52	18	32	0	0	0	0	0	0	0	72.43	0	0	13.2
2014	9	1	14	2	18	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2014	9	1	14	12	18	31	0	0	0	0	0	0	0	73.06	0	0	13.2
2014	9	1	14	22	18	31	0	0	0	0	0	0	0	73.36	0	0	13
2014	9	1	14	32	18	31	0	0	0	0	0	0	0	73.72	0	0	13.2
2014	9	1	14	42	18	31	0	0	0	0	0	0	0	74.03	0	0	13.2
2014	9	1	14	52	18	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2014	9	1	15	2	18	30	0	0	0	0	0	0	0	74.59	0	0	13.2
2014	9	1	15	12	18	30	0	0	0	0	0	0	0	74.86	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	15	22	18	30	0	0	0	0	0	0	0	75.11	0	0	13.2
2014	9	1	15	32	18	31	0	0	0	0	0	0	0	75.34	0	0	13.2
2014	9	1	15	42	18	31	0	0	0	0	0	0	0	75.54	0	0	13.2
2014	9	1	15	52	18	30	0	0	0	0	0	0	0	75.72	0	0	13
2014	9	1	16	2	18	31	0	0	0	0	0	0	0	75.9	0	0	13
2014	9	1	16	12	18	30	0	0	0	0	0	0	0	76.06	0	0	12.8
2014	9	1	16	22	18	31	0	0	0	0	0	0	0	76.19	0	0	12.8
2014	9	1	16	32	18	31	0	0	0	0	0	0	0	76.32	0	0	12.6
2014	9	1	16	42	18	31	0	0	0	0	0	0	0	76.42	0	0	12.6
2014	9	1	16	52	18	31	0	0	0	0	0	0	0	76.51	0	0	12.4
2014	9	1	17	2	18	31	0	0	0	0	0	0	0	76.59	0	0	12.4
2014	9	1	17	12	18	31	0	0	0	0	0	0	0	76.62	0	0	12.4
2014	9	1	17	22	18	31	0	0	0	0	0	0	0	76.55	0	0	12.2
2014	9	1	17	32	18	31	0	0	0	0	0	0	0	76.55	0	0	12.2
2014	9	1	17	42	18	30	0	0	0	0	0	0	0	76.53	0	0	12.2
2014	9	1	17	52	18	30	0	0	0	0	0	0	0	76.5	0	0	12.2
2014	9	1	18	2	18	30	0	0	0	0	0	0	0	76.46	0	0	12.2
2014	9	1	18	12	18	31	0	0	0	0	0	0	0	76.37	0	0	12.2
2014	9	1	18	22	18	30	0	0	0	0	0	0	0	76.35	0	0	12
2014	9	1	18	32	18	31	0	0	0	0	0	0	0	76.28	0	0	12.2
2014	9	1	18	42	18	30	0	0	0	0	0	0	0	76.19	0	0	12.2
2014	9	1	18	52	18	31	0	0	0	0	0	0	0	76.1	0	0	12.2
2014	9	1	19	2	18	30	0	0	0	0	0	0	0	76.01	0	0	12.2
2014	9	1	19	12	18	31	0	0	0	0	0	0	0	75.9	0	0	12.2
2014	9	1	19	22	18	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	9	1	19	32	18	31	0	0	0	0	0	0	0	75.65	0	0	12.2
2014	9	1	19	42	18	31	0	0	0	0	0	0	0	75.56	0	0	12.2
2014	9	1	19	52	18	31	0	0	0	0	0	0	0	75.45	0	0	12.2
2014	9	1	20	2	18	31	0	0	0	0	0	0	0	75.33	0	0	12.2
2014	9	1	20	12	18	30	0	0	0	0	0	0	0	75.2	0	0	12.2
2014	9	1	20	22	18	30	0	0	0	0	0	0	0	75.07	0	0	12
2014	9	1	20	32	18	31	0	0	0	0	0	0	0	74.93	0	0	12.2
2014	9	1	20	42	18	30	0	0	0	0	0	0	0	74.77	0	0	12.2
2014	9	1	20	52	18	31	0	0	0	0	0	0	0	74.61	0	0	12.2
2014	9	1	21	2	18	31	0	0	0	0	0	0	0	74.44	0	0	12.2
2014	9	1	21	12	18	30	0	0	0	0	0	0	0	74.23	0	0	12
2014	9	1	21	22	18	30	0	0	0	0	0	0	0	74.01	0	0	12
2014	9	1	21	32	18	30	0	0	0	0	0	0	0	73.8	0	0	12
2014	9	1	21	42	18	31	0	0	0	0	0	0	0	73.58	0	0	12
2014	9	1	21	52	18	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	9	1	22	2	18	31	0	0	0	0	0	0	0	73.08	0	0	12
2014	9	1	22	12	18	31	0	0	0	0	0	0	0	72.82	0	0	12
2014	9	1	22	22	18	31	0	0	0	0	0	0	0	72.55	0	0	12
2014	9	1	22	32	18	31	0	0	0	0	0	0	0	72.28	0	0	12
2014	9	1	22	42	18	31	0	0	0	0	0	0	0	72	0	0	12
2014	9	1	22	52	18	31	0	0	0	0	0	0	0	71.73	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	23	2	18	31	0	0	0	0	0	0	0	71.46	0	0	12
2014	9	1	23	12	18	31	0	0	0	0	0	0	0	71.19	0	0	12
2014	9	1	23	22	18	31	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	9	1	23	32	18	31	0	0	0	0	0	0	0	70.7	0	0	12
2014	9	1	23	42	18	32	0	0	0	0	0	0	0	70.47	0	0	12
2014	9	1	23	52	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	9	2	0	2	18	32	0	0	0	0	0	0	0	70	0	0	12
2014	9	2	0	12	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	9	2	0	22	18	31	0	0	0	0	0	0	0	69.58	0	0	12
2014	9	2	0	32	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	9	2	0	42	18	32	0	0	0	0	0	0	0	69.26	0	0	12
2014	9	2	0	52	18	31	0	0	0	0	0	0	0	69.1	0	0	12
2014	9	2	1	2	18	31	0	0	0	0	0	0	0	68.94	0	0	12
2014	9	2	1	12	18	31	0	0	0	0	0	0	0	68.79	0	0	12
2014	9	2	1	22	18	31	0	0	0	0	0	0	0	68.67	0	0	12
2014	9	2	1	32	18	32	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	2	1	42	18	31	0	0	0	0	0	0	0	68.41	0	0	12
2014	9	2	1	52	18	31	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	2	2	2	18	32	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	2	2	12	18	31	0	0	0	0	0	0	0	68.05	0	0	12
2014	9	2	2	22	18	32	0	0	0	0	0	0	0	67.93	0	0	11.8
2014	9	2	2	32	18	32	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	2	2	42	18	32	0	0	0	0	0	0	0	67.69	0	0	12
2014	9	2	2	52	18	32	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	2	3	2	18	32	0	0	0	0	0	0	0	67.5	0	0	12
2014	9	2	3	12	18	31	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	2	3	22	18	31	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	2	3	32	18	32	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	2	3	42	18	31	0	0	0	0	0	0	0	67.06	0	0	12
2014	9	2	3	52	18	32	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	2	4	2	18	32	0	0	0	0	0	0	0	66.85	0	0	12
2014	9	2	4	12	18	31	0	0	0	0	0	0	0	66.74	0	0	12
2014	9	2	4	22	18	32	0	0	0	0	0	0	0	66.65	0	0	11.8
2014	9	2	4	32	18	32	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	2	4	42	18	32	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	2	4	52	18	32	0	0	0	0	0	0	0	66.36	0	0	12
2014	9	2	5	2	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	2	5	12	18	32	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	2	5	22	18	32	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	2	5	32	18	32	0	0	0	0	0	0	0	66	0	0	12
2014	9	2	5	42	18	32	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	2	5	52	18	32	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	2	6	2	18	32	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	2	6	12	18	33	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	2	6	22	18	32	0	0	0	0	0	0	0	65.55	0	0	11.8
2014	9	2	6	32	18	31	0	0	0	0	0	0	0	65.48	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	6	42	18	31	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	2	6	52	18	32	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	2	7	2	18	31	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	2	7	12	18	32	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	2	7	22	18	31	0	0	0	0	0	0	0	65.08	0	0	12
2014	9	2	7	32	18	32	0	0	0	0	0	0	0	65.03	0	0	12.4
2014	9	2	7	42	18	32	0	0	0	0	0	0	0	64.96	0	0	12.8
2014	9	2	7	52	18	31	0	0	0	0	0	0	0	64.9	0	0	12.8
2014	9	2	8	2	18	32	0	0	0	0	0	0	0	64.9	0	0	13
2014	9	2	8	12	18	32	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	2	8	22	18	32	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	2	8	32	18	31	0	0	0	0	0	0	0	64.92	0	0	13.2
2014	9	2	8	42	18	32	0	0	0	0	0	0	0	64.94	0	0	13.4
2014	9	2	8	52	18	32	0	0	0	0	0	0	0	64.99	0	0	13.4
2014	9	2	9	2	18	32	0	0	0	0	0	0	0	65.41	0	0	13.4
2014	9	2	9	12	18	31	0	0	0	0	0	0	0	65.97	0	0	13.4
2014	9	2	9	22	18	32	0	0	0	0	0	0	0	66.2	0	0	13.4
2014	9	2	9	32	18	32	0	0	0	0	0	0	0	66.33	0	0	13.4
2014	9	2	9	42	18	32	0	0	0	0	0	0	0	66.51	0	0	13.4
2014	9	2	9	52	18	32	0	0	0	0	0	0	0	66.65	0	0	13.4
2014	9	2	10	2	18	31	0	0	0	0	0	0	0	66.87	0	0	13.4
2014	9	2	10	12	18	31	0	0	0	0	0	0	0	66.99	0	0	13.4
2014	9	2	10	22	18	32	0	0	0	0	0	0	0	67.24	0	0	13.2
2014	9	2	10	32	18	32	0	0	0	0	0	0	0	67.48	0	0	13.4
2014	9	2	10	42	18	33	0	0	0	0	0	0	0	67.59	0	0	13.4
2014	9	2	10	52	18	32	0	0	0	0	0	0	0	67.75	0	0	13.4
2014	9	2	11	2	18	32	0	0	0	0	0	0	0	66.96	0	0	13.4
2014	9	2	11	12	18	31	0	0	0	0	0	0	0	66.99	0	0	13.2
2014	9	2	11	22	18	31	0	0	0	0	0	0	0	67.15	0	0	13.2
2014	9	2	11	32	18	31	0	0	0	0	0	0	0	67.37	0	0	13.2
2014	9	2	11	42	18	32	0	0	0	0	0	0	0	67.6	0	0	13.4
2014	9	2	11	52	18	31	0	0	0	0	0	0	0	67.84	0	0	13.4
2014	9	2	12	2	18	31	0	0	0	0	0	0	0	68.9	0	0	13.4
2014	9	2	12	12	18	31	0	0	0	0	0	0	0	69.44	0	0	13.4
2014	9	2	12	22	18	31	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	9	2	12	32	18	31	0	0	0	0	0	0	0	70.07	0	0	13.4
2014	9	2	12	42	18	31	0	0	0	0	0	0	0	70.36	0	0	13.4
2014	9	2	12	52	18	31	0	0	0	0	0	0	0	70.7	0	0	13.4
2014	9	2	13	2	18	31	0	0	0	0	0	0	0	70.97	0	0	13.4
2014	9	2	13	12	18	31	0	0	0	0	0	0	0	71.26	0	0	13.4
2014	9	2	13	22	18	31	0	0	0	0	0	0	0	71.55	0	0	13.2
2014	9	2	13	32	18	31	0	0	0	0	0	0	0	71.83	0	0	13.2
2014	9	2	13	42	18	31	0	0	0	0	0	0	0	72.18	0	0	13.2
2014	9	2	13	52	18	31	0	0	0	0	0	0	0	72.52	0	0	13.2
2014	9	2	14	2	18	30	0	0	0	0	0	0	0	72.86	0	0	13.2
2014	9	2	14	12	18	31	0	0	0	0	0	0	0	73.18	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	14	22	18	31	0	0	0	0	0	0	0	73.49	0	0	13.2
2014	9	2	14	32	18	31	0	0	0	0	0	0	0	73.8	0	0	13.2
2014	9	2	14	42	18	31	0	0	0	0	0	0	0	74.1	0	0	13.2
2014	9	2	14	52	18	31	0	0	0	0	0	0	0	74.41	0	0	13.2
2014	9	2	15	2	18	31	0	0	0	0	0	0	0	74.66	0	0	13.2
2014	9	2	15	12	18	31	0	0	0	0	0	0	0	74.93	0	0	13.2
2014	9	2	15	22	18	30	0	0	0	0	0	0	0	75.2	0	0	13
2014	9	2	15	32	18	31	0	0	0	0	0	0	0	75.4	0	0	13.2
2014	9	2	15	42	18	31	0	0	0	0	0	0	0	75.61	0	0	13.2
2014	9	2	15	52	18	31	0	0	0	0	0	0	0	75.83	0	0	13.2
2014	9	2	16	2	18	31	0	0	0	0	0	0	0	75.99	0	0	13
2014	9	2	16	12	18	31	0	0	0	0	0	0	0	76.15	0	0	13
2014	9	2	16	22	18	30	0	0	0	0	0	0	0	76.26	0	0	12.6
2014	9	2	16	32	18	31	0	0	0	0	0	0	0	76.39	0	0	12.6
2014	9	2	16	42	18	30	0	0	0	0	0	0	0	76.48	0	0	12.6
2014	9	2	16	52	18	30	0	0	0	0	0	0	0	76.53	0	0	12.4
2014	9	2	17	2	18	31	0	0	0	0	0	0	0	76.59	0	0	12.4
2014	9	2	17	12	18	31	0	0	0	0	0	0	0	76.6	0	0	12.4
2014	9	2	17	22	18	30	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	9	2	17	32	18	31	0	0	0	0	0	0	0	76.44	0	0	12.2
2014	9	2	17	42	18	30	0	0	0	0	0	0	0	76.41	0	0	12.2
2014	9	2	17	52	18	31	0	0	0	0	0	0	0	76.35	0	0	12.2
2014	9	2	18	2	18	31	0	0	0	0	0	0	0	76.3	0	0	12.2
2014	9	2	18	12	18	31	0	0	0	0	0	0	0	76.24	0	0	12.2
2014	9	2	18	22	18	30	0	0	0	0	0	0	0	76.17	0	0	12
2014	9	2	18	32	18	31	0	0	0	0	0	0	0	76.08	0	0	12.2
2014	9	2	18	42	18	31	0	0	0	0	0	0	0	75.97	0	0	12.2
2014	9	2	18	52	18	30	0	0	0	0	0	0	0	75.85	0	0	12.2
2014	9	2	19	2	18	31	0	0	0	0	0	0	0	75.72	0	0	12.2
2014	9	2	19	12	18	31	0	0	0	0	0	0	0	75.61	0	0	12.2
2014	9	2	19	22	18	30	0	0	0	0	0	0	0	75.49	0	0	12.2
2014	9	2	19	32	18	31	0	0	0	0	0	0	0	75.33	0	0	12.2
2014	9	2	19	42	18	30	0	0	0	0	0	0	0	75.18	0	0	12.2
2014	9	2	19	52	18	31	0	0	0	0	0	0	0	75.02	0	0	12.2
2014	9	2	20	2	18	30	0	0	0	0	0	0	0	74.84	0	0	12.2
2014	9	2	20	12	18	30	0	0	0	0	0	0	0	74.64	0	0	12.2
2014	9	2	20	22	18	30	0	0	0	0	0	0	0	74.46	0	0	12
2014	9	2	20	32	18	30	0	0	0	0	0	0	0	74.26	0	0	12.2
2014	9	2	20	42	18	30	0	0	0	0	0	0	0	74.05	0	0	12.2
2014	9	2	20	52	18	31	0	0	0	0	0	0	0	73.8	0	0	12.2
2014	9	2	21	2	18	31	0	0	0	0	0	0	0	73.56	0	0	12.2
2014	9	2	21	12	18	31	0	0	0	0	0	0	0	73.29	0	0	12.2
2014	9	2	21	22	18	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	9	2	21	32	18	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	9	2	21	42	18	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	9	2	21	52	18	30	0	0	0	0	0	0	0	72.27	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	22	2	18	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	9	2	22	12	18	30	0	0	0	0	0	0	0	71.76	0	0	12
2014	9	2	22	22	18	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	9	2	22	32	18	31	0	0	0	0	0	0	0	71.28	0	0	12
2014	9	2	22	42	18	32	0	0	0	0	0	0	0	71.06	0	0	12
2014	9	2	22	52	18	31	0	0	0	0	0	0	0	70.88	0	0	12
2014	9	2	23	2	18	30	0	0	0	0	0	0	0	70.7	0	0	12
2014	9	2	23	12	18	31	0	0	0	0	0	0	0	70.56	0	0	12
2014	9	2	23	22	18	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	9	2	23	32	18	31	0	0	0	0	0	0	0	70.27	0	0	12
2014	9	2	23	42	18	31	0	0	0	0	0	0	0	70.16	0	0	12
2014	9	2	23	52	18	31	0	0	0	0	0	0	0	70.03	0	0	12
2014	9	3	0	2	18	31	0	0	0	0	0	0	0	69.93	0	0	12
2014	9	3	0	12	18	31	0	0	0	0	0	0	0	69.82	0	0	12
2014	9	3	0	22	18	32	0	0	0	0	0	0	0	69.71	0	0	11.8
2014	9	3	0	32	18	31	0	0	0	0	0	0	0	69.62	0	0	12
2014	9	3	0	42	18	31	0	0	0	0	0	0	0	69.51	0	0	12
2014	9	3	0	52	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	9	3	1	2	18	32	0	0	0	0	0	0	0	69.3	0	0	12
2014	9	3	1	12	18	31	0	0	0	0	0	0	0	69.19	0	0	12
2014	9	3	1	22	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	9	3	1	32	18	31	0	0	0	0	0	0	0	68.97	0	0	12
2014	9	3	1	42	18	32	0	0	0	0	0	0	0	68.88	0	0	12
2014	9	3	1	52	18	32	0	0	0	0	0	0	0	68.77	0	0	12
2014	9	3	2	2	18	31	0	0	0	0	0	0	0	68.68	0	0	12
2014	9	3	2	12	18	31	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	3	2	22	18	30	0	0	0	0	0	0	0	68.5	0	0	12
2014	9	3	2	32	18	32	0	0	0	0	0	0	0	68.41	0	0	12
2014	9	3	2	42	18	31	0	0	0	0	0	0	0	68.32	0	0	12
2014	9	3	2	52	18	31	0	0	0	0	0	0	0	68.22	0	0	12
2014	9	3	3	2	18	31	0	0	0	0	0	0	0	68.14	0	0	12
2014	9	3	3	12	18	31	0	0	0	0	0	0	0	68.05	0	0	12
2014	9	3	3	22	18	31	0	0	0	0	0	0	0	67.98	0	0	12
2014	9	3	3	32	18	31	0	0	0	0	0	0	0	67.89	0	0	12
2014	9	3	3	42	18	31	0	0	0	0	0	0	0	67.82	0	0	12
2014	9	3	3	52	18	32	0	0	0	0	0	0	0	67.73	0	0	12
2014	9	3	4	2	18	32	0	0	0	0	0	0	0	67.64	0	0	12
2014	9	3	4	12	18	31	0	0	0	0	0	0	0	67.57	0	0	12
2014	9	3	4	22	18	31	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	3	4	32	18	31	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	3	4	42	18	32	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	3	4	52	18	32	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	3	5	2	18	32	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	3	5	12	18	32	0	0	0	0	0	0	0	67.05	0	0	12
2014	9	3	5	22	18	32	0	0	0	0	0	0	0	66.96	0	0	11.8
2014	9	3	5	32	18	32	0	0	0	0	0	0	0	66.87	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	5	42	18	31	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	3	5	52	18	32	0	0	0	0	0	0	0	66.69	0	0	12
2014	9	3	6	2	18	32	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	3	6	12	18	32	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	3	6	22	18	31	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	3	6	32	18	31	0	0	0	0	0	0	0	66.25	0	0	12
2014	9	3	6	42	18	31	0	0	0	0	0	0	0	66.16	0	0	12
2014	9	3	6	52	18	32	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	3	7	2	18	32	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	3	7	12	18	31	0	0	0	0	0	0	0	65.86	0	0	12
2014	9	3	7	22	18	33	0	0	0	0	0	0	0	65.75	0	0	12.2
2014	9	3	7	32	18	32	0	0	0	0	0	0	0	65.68	0	0	12.4
2014	9	3	7	42	18	31	0	0	0	0	0	0	0	65.59	0	0	12.6
2014	9	3	7	52	18	32	0	0	0	0	0	0	0	65.52	0	0	12.8
2014	9	3	8	2	18	31	0	0	0	0	0	0	0	65.46	0	0	13
2014	9	3	8	12	18	32	0	0	0	0	0	0	0	65.44	0	0	13
2014	9	3	8	22	18	32	0	0	0	0	0	0	0	65.39	0	0	13
2014	9	3	8	32	18	32	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	3	8	42	18	32	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	3	8	52	18	32	0	0	0	0	0	0	0	65.37	0	0	13.4
2014	9	3	9	2	18	33	0	0	0	0	0	0	0	65.68	0	0	13.4
2014	9	3	9	12	18	32	0	0	0	0	0	0	0	65.77	0	0	13.4
2014	9	3	9	22	18	32	0	0	0	0	0	0	0	65.97	0	0	13.4
2014	9	3	9	32	18	32	0	0	0	0	0	0	0	66.06	0	0	13.4
2014	9	3	9	42	18	32	0	0	0	0	0	0	0	66.2	0	0	13.4
2014	9	3	9	52	18	31	0	0	0	0	0	0	0	66.33	0	0	13.4
2014	9	3	10	2	18	32	0	0	0	0	0	0	0	66.45	0	0	13.2
2014	9	3	10	12	18	32	0	0	0	0	0	0	0	66.56	0	0	13.2
2014	9	3	10	22	18	32	0	0	0	0	0	0	0	66.74	0	0	13.2
2014	9	3	10	32	18	32	0	0	0	0	0	0	0	66.92	0	0	13.2
2014	9	3	10	42	18	32	0	0	0	0	0	0	0	67.1	0	0	13.2
2014	9	3	10	52	18	32	0	0	0	0	0	0	0	67.08	0	0	13.2
2014	9	3	11	2	18	31	0	0	0	0	0	0	0	66.85	0	0	13.2
2014	9	3	11	12	18	31	0	0	0	0	0	0	0	66.99	0	0	13.2
2014	9	3	11	22	18	31	0	0	0	0	0	0	0	67.21	0	0	13.2
2014	9	3	11	32	18	32	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	3	11	42	18	31	0	0	0	0	0	0	0	67.71	0	0	13.2
2014	9	3	11	52	18	32	0	0	0	0	0	0	0	68.04	0	0	13.2
2014	9	3	12	2	18	31	0	0	0	0	0	0	0	68.86	0	0	13.2
2014	9	3	12	12	18	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2014	9	3	12	22	18	31	0	0	0	0	0	0	0	69.66	0	0	13
2014	9	3	12	32	18	31	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	9	3	12	42	18	31	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	9	3	12	52	18	31	0	0	0	0	0	0	0	70.68	0	0	13.2
2014	9	3	13	2	18	32	0	0	0	0	0	0	0	71.01	0	0	13.2
2014	9	3	13	12	18	32	0	0	0	0	0	0	0	71.4	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	13	22	18	30	0	0	0	0	0	0	0	71.74	0	0	13
2014	9	3	13	32	18	31	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	9	3	13	42	18	31	0	0	0	0	0	0	0	72.43	0	0	13.2
2014	9	3	13	52	18	31	0	0	0	0	0	0	0	72.81	0	0	13.2
2014	9	3	14	2	18	32	0	0	0	0	0	0	0	73.13	0	0	13.2
2014	9	3	14	12	18	31	0	0	0	0	0	0	0	73.44	0	0	13.2
2014	9	3	14	22	18	31	0	0	0	0	0	0	0	73.74	0	0	13
2014	9	3	14	32	18	31	0	0	0	0	0	0	0	74.08	0	0	13.2
2014	9	3	14	42	18	30	0	0	0	0	0	0	0	74.37	0	0	13.2
2014	9	3	14	52	18	31	0	0	0	0	0	0	0	74.66	0	0	13.2
2014	9	3	15	2	18	31	0	0	0	0	0	0	0	74.91	0	0	13.2
2014	9	3	15	12	18	31	0	0	0	0	0	0	0	75.16	0	0	13.2
2014	9	3	15	22	18	30	0	0	0	0	0	0	0	75.43	0	0	13.2
2014	9	3	15	32	18	31	0	0	0	0	0	0	0	75.63	0	0	13.2
2014	9	3	15	42	18	31	0	0	0	0	0	0	0	75.85	0	0	13.2
2014	9	3	15	52	18	31	0	0	0	0	0	0	0	76.01	0	0	13.2
2014	9	3	16	2	18	31	0	0	0	0	0	0	0	76.19	0	0	13
2014	9	3	16	12	18	31	0	0	0	0	0	0	0	76.33	0	0	13
2014	9	3	16	22	18	30	0	0	0	0	0	0	0	76.44	0	0	12.6
2014	9	3	16	32	18	31	0	0	0	0	0	0	0	76.55	0	0	12.6
2014	9	3	16	42	18	30	0	0	0	0	0	0	0	76.64	0	0	12.6
2014	9	3	16	52	18	31	0	0	0	0	0	0	0	76.69	0	0	12.4
2014	9	3	17	2	18	31	0	0	0	0	0	0	0	76.75	0	0	12.4
2014	9	3	17	12	18	31	0	0	0	0	0	0	0	76.75	0	0	12.4
2014	9	3	17	22	18	30	0	0	0	0	0	0	0	76.68	0	0	12.2
2014	9	3	17	32	18	30	0	0	0	0	0	0	0	76.62	0	0	12.2
2014	9	3	17	42	18	30	0	0	0	0	0	0	0	76.59	0	0	12.2
2014	9	3	17	52	18	30	0	0	0	0	0	0	0	76.53	0	0	12.2
2014	9	3	18	2	18	31	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	9	3	18	12	18	31	0	0	0	0	0	0	0	76.42	0	0	12.2
2014	9	3	18	22	18	30	0	0	0	0	0	0	0	76.33	0	0	12.2
2014	9	3	18	32	18	31	0	0	0	0	0	0	0	76.26	0	0	12.2
2014	9	3	18	42	18	30	0	0	0	0	0	0	0	76.15	0	0	12.2
2014	9	3	18	52	18	30	0	0	0	0	0	0	0	76.06	0	0	12.2
2014	9	3	19	2	18	31	0	0	0	0	0	0	0	75.92	0	0	12.2
2014	9	3	19	12	18	30	0	0	0	0	0	0	0	75.81	0	0	12.2
2014	9	3	19	22	18	30	0	0	0	0	0	0	0	75.67	0	0	12
2014	9	3	19	32	18	30	0	0	0	0	0	0	0	75.52	0	0	12.2
2014	9	3	19	42	18	31	0	0	0	0	0	0	0	75.4	0	0	12.2
2014	9	3	19	52	18	30	0	0	0	0	0	0	0	75.24	0	0	12.2
2014	9	3	20	2	18	31	0	0	0	0	0	0	0	75.09	0	0	12.2
2014	9	3	20	12	18	30	0	0	0	0	0	0	0	74.91	0	0	12.2
2014	9	3	20	22	18	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	9	3	20	32	18	31	0	0	0	0	0	0	0	74.57	0	0	12.2
2014	9	3	20	42	18	31	0	0	0	0	0	0	0	74.41	0	0	12.2
2014	9	3	20	52	18	31	0	0	0	0	0	0	0	74.21	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	21	2	18	31	0	0	0	0	0	0	0	73.99	0	0	12.2
2014	9	3	21	12	18	31	0	0	0	0	0	0	0	73.78	0	0	12
2014	9	3	21	22	18	30	0	0	0	0	0	0	0	73.54	0	0	12
2014	9	3	21	32	18	30	0	0	0	0	0	0	0	73.31	0	0	12
2014	9	3	21	42	18	31	0	0	0	0	0	0	0	73.08	0	0	12
2014	9	3	21	52	18	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	9	3	22	2	18	31	0	0	0	0	0	0	0	72.59	0	0	12
2014	9	3	22	12	18	31	0	0	0	0	0	0	0	72.36	0	0	12
2014	9	3	22	22	18	30	0	0	0	0	0	0	0	72.14	0	0	12
2014	9	3	22	32	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	9	3	22	42	18	31	0	0	0	0	0	0	0	71.71	0	0	12
2014	9	3	22	52	18	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	9	3	23	2	18	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	9	3	23	12	18	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	9	3	23	22	18	31	0	0	0	0	0	0	0	70.95	0	0	12
2014	9	3	23	32	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	9	3	23	42	18	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	9	3	23	52	18	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	9	4	0	2	18	32	0	0	0	0	0	0	0	70.36	0	0	12
2014	9	4	0	12	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	9	4	0	22	18	31	0	0	0	0	0	0	0	70.11	0	0	11.8
2014	9	4	0	32	18	31	0	0	0	0	0	0	0	69.96	0	0	12
2014	9	4	0	42	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	9	4	0	52	18	31	0	0	0	0	0	0	0	69.73	0	0	12
2014	9	4	1	2	18	32	0	0	0	0	0	0	0	69.64	0	0	12
2014	9	4	1	12	18	31	0	0	0	0	0	0	0	69.53	0	0	12
2014	9	4	1	22	18	30	0	0	0	0	0	0	0	69.44	0	0	12
2014	9	4	1	32	18	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	9	4	1	42	18	32	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	4	1	52	18	32	0	0	0	0	0	0	0	69.15	0	0	12
2014	9	4	2	2	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	9	4	2	12	18	31	0	0	0	0	0	0	0	68.99	0	0	12
2014	9	4	2	22	18	31	0	0	0	0	0	0	0	68.9	0	0	12
2014	9	4	2	32	18	31	0	0	0	0	0	0	0	68.81	0	0	12
2014	9	4	2	42	18	31	0	0	0	0	0	0	0	68.74	0	0	12
2014	9	4	2	52	18	31	0	0	0	0	0	0	0	68.67	0	0	12
2014	9	4	3	2	18	31	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	4	3	12	18	31	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	4	3	22	18	30	0	0	0	0	0	0	0	68.45	0	0	12
2014	9	4	3	32	18	31	0	0	0	0	0	0	0	68.36	0	0	12
2014	9	4	3	42	18	31	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	4	3	52	18	31	0	0	0	0	0	0	0	68.23	0	0	12
2014	9	4	4	2	18	31	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	4	4	12	18	31	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	4	4	22	18	31	0	0	0	0	0	0	0	68	0	0	12
2014	9	4	4	32	18	31	0	0	0	0	0	0	0	67.93	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	4	42	18	32	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	4	4	52	18	31	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	4	5	2	18	32	0	0	0	0	0	0	0	67.6	0	0	12
2014	9	4	5	12	18	31	0	0	0	0	0	0	0	67.5	0	0	12
2014	9	4	5	22	18	31	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	4	5	32	18	32	0	0	0	0	0	0	0	67.28	0	0	12
2014	9	4	5	42	18	31	0	0	0	0	0	0	0	67.15	0	0	12
2014	9	4	5	52	18	32	0	0	0	0	0	0	0	67.05	0	0	12
2014	9	4	6	2	18	31	0	0	0	0	0	0	0	66.92	0	0	12
2014	9	4	6	12	18	31	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	4	6	22	18	31	0	0	0	0	0	0	0	66.65	0	0	11.8
2014	9	4	6	32	18	32	0	0	0	0	0	0	0	66.51	0	0	12
2014	9	4	6	42	18	31	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	4	6	52	18	32	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	4	7	2	18	32	0	0	0	0	0	0	0	66.09	0	0	12
2014	9	4	7	12	18	31	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	4	7	22	18	32	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	4	7	32	18	31	0	0	0	0	0	0	0	65.66	0	0	12.4
2014	9	4	7	42	18	32	0	0	0	0	0	0	0	65.53	0	0	12.6
2014	9	4	7	52	18	32	0	0	0	0	0	0	0	65.39	0	0	12.8
2014	9	4	8	2	18	32	0	0	0	0	0	0	0	65.25	0	0	13
2014	9	4	8	12	18	32	0	0	0	0	0	0	0	65.14	0	0	13
2014	9	4	8	22	18	32	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	4	8	32	18	32	0	0	0	0	0	0	0	64.94	0	0	13.2
2014	9	4	8	42	18	32	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	4	8	52	18	32	0	0	0	0	0	0	0	64.81	0	0	13.2
2014	9	4	9	2	18	32	0	0	0	0	0	0	0	64.87	0	0	13.4
2014	9	4	9	12	18	32	0	0	0	0	0	0	0	65.19	0	0	13.4
2014	9	4	9	22	18	32	0	0	0	0	0	0	0	65.21	0	0	13.4
2014	9	4	9	32	18	32	0	0	0	0	0	0	0	65.28	0	0	13.6
2014	9	4	9	42	18	32	0	0	0	0	0	0	0	65.3	0	0	13.6
2014	9	4	9	52	18	32	0	0	0	0	0	0	0	65.3	0	0	13.6
2014	9	4	10	2	18	31	0	0	0	0	0	0	0	65.35	0	0	13.6
2014	9	4	10	12	18	31	0	0	0	0	0	0	0	65.41	0	0	13.6
2014	9	4	10	22	18	33	0	0	0	0	0	0	0	65.48	0	0	13.6
2014	9	4	10	32	18	32	0	0	0	0	0	0	0	65.61	0	0	13.6
2014	9	4	10	42	18	33	0	0	0	0	0	0	0	65.75	0	0	13.4
2014	9	4	10	52	18	31	0	0	0	0	0	0	0	65.5	0	0	13.4
2014	9	4	11	2	18	31	0	0	0	0	0	0	0	65.37	0	0	13.4
2014	9	4	11	12	18	32	0	0	0	0	0	0	0	65.5	0	0	13.4
2014	9	4	11	22	18	32	0	0	0	0	0	0	0	65.68	0	0	13.4
2014	9	4	11	32	18	33	0	0	0	0	0	0	0	65.91	0	0	13.4
2014	9	4	11	42	18	32	0	0	0	0	0	0	0	66.15	0	0	13.4
2014	9	4	11	52	18	31	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	9	4	12	2	18	32	0	0	0	0	0	0	0	67.28	0	0	13.2
2014	9	4	12	12	18	31	0	0	0	0	0	0	0	67.68	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	12	22	18	32	0	0	0	0	0	0	0	68.04	0	0	13.2
2014	9	4	12	32	18	31	0	0	0	0	0	0	0	68.36	0	0	13.2
2014	9	4	12	42	18	32	0	0	0	0	0	0	0	68.67	0	0	13.2
2014	9	4	12	52	18	32	0	0	0	0	0	0	0	68.97	0	0	13.2
2014	9	4	13	2	18	31	0	0	0	0	0	0	0	69.33	0	0	13.2
2014	9	4	13	12	18	32	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	9	4	13	22	18	31	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	9	4	13	32	18	32	0	0	0	0	0	0	0	70.34	0	0	13.2
2014	9	4	13	42	18	31	0	0	0	0	0	0	0	70.65	0	0	13.2
2014	9	4	13	52	18	31	0	0	0	0	0	0	0	70.99	0	0	13.2
2014	9	4	14	2	18	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	9	4	14	12	18	31	0	0	0	0	0	0	0	71.6	0	0	13.2
2014	9	4	14	22	18	31	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	9	4	14	32	18	31	0	0	0	0	0	0	0	72.23	0	0	13.2
2014	9	4	14	42	18	31	0	0	0	0	0	0	0	72.46	0	0	13.2
2014	9	4	14	52	18	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2014	9	4	15	2	18	31	0	0	0	0	0	0	0	72.99	0	0	13.2
2014	9	4	15	12	18	31	0	0	0	0	0	0	0	73.2	0	0	13.2
2014	9	4	15	22	18	31	0	0	0	0	0	0	0	73.45	0	0	13.2
2014	9	4	15	32	18	31	0	0	0	0	0	0	0	73.65	0	0	13.2
2014	9	4	15	42	18	31	0	0	0	0	0	0	0	73.85	0	0	13.2
2014	9	4	15	52	18	30	0	0	0	0	0	0	0	74.03	0	0	13.2
2014	9	4	16	2	18	31	0	0	0	0	0	0	0	74.19	0	0	13
2014	9	4	16	12	18	30	0	0	0	0	0	0	0	74.34	0	0	13
2014	9	4	16	22	18	31	0	0	0	0	0	0	0	74.46	0	0	12.8
2014	9	4	16	32	18	31	0	0	0	0	0	0	0	74.57	0	0	12.8
2014	9	4	16	42	18	30	0	0	0	0	0	0	0	74.66	0	0	12.6
2014	9	4	16	52	18	31	0	0	0	0	0	0	0	74.75	0	0	12.4
2014	9	4	17	2	18	30	0	0	0	0	0	0	0	74.8	0	0	12.4
2014	9	4	17	12	18	30	0	0	0	0	0	0	0	74.84	0	0	12.4
2014	9	4	17	22	18	30	0	0	0	0	0	0	0	74.79	0	0	12.2
2014	9	4	17	32	18	30	0	0	0	0	0	0	0	74.77	0	0	12.2
2014	9	4	17	42	18	30	0	0	0	0	0	0	0	74.73	0	0	12.2
2014	9	4	17	52	18	30	0	0	0	0	0	0	0	74.7	0	0	12.2
2014	9	4	18	2	18	31	0	0	0	0	0	0	0	74.62	0	0	12.2
2014	9	4	18	12	18	30	0	0	0	0	0	0	0	74.53	0	0	12.2
2014	9	4	18	22	18	31	0	0	0	0	0	0	0	74.43	0	0	12
2014	9	4	18	32	18	31	0	0	0	0	0	0	0	74.3	0	0	12.2
2014	9	4	18	42	18	32	0	0	0	0	0	0	0	74.19	0	0	12.2
2014	9	4	18	52	18	31	0	0	0	0	0	0	0	74.08	0	0	12.2
2014	9	4	19	2	18	31	0	0	0	0	0	0	0	73.96	0	0	12.2
2014	9	4	19	12	18	31	0	0	0	0	0	0	0	73.83	0	0	12.2
2014	9	4	19	22	18	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	9	4	19	32	18	31	0	0	0	0	0	0	0	73.54	0	0	12.2
2014	9	4	19	42	18	31	0	0	0	0	0	0	0	73.4	0	0	12.2
2014	9	4	19	52	18	31	0	0	0	0	0	0	0	73.24	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	20	2	18	31	0	0	0	0	0	0	0	73.08	0	0	12.2
2014	9	4	20	12	18	30	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	9	4	20	22	18	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	9	4	20	32	18	31	0	0	0	0	0	0	0	72.52	0	0	12.2
2014	9	4	20	42	18	31	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	9	4	20	52	18	31	0	0	0	0	0	0	0	72.07	0	0	12.2
2014	9	4	21	2	18	31	0	0	0	0	0	0	0	71.83	0	0	12
2014	9	4	21	12	18	31	0	0	0	0	0	0	0	71.6	0	0	12
2014	9	4	21	22	18	31	0	0	0	0	0	0	0	71.37	0	0	12
2014	9	4	21	32	18	30	0	0	0	0	0	0	0	71.11	0	0	12
2014	9	4	21	42	18	31	0	0	0	0	0	0	0	70.88	0	0	12
2014	9	4	21	52	18	31	0	0	0	0	0	0	0	70.65	0	0	12
2014	9	4	22	2	18	31	0	0	0	0	0	0	0	70.43	0	0	12
2014	9	4	22	12	18	31	0	0	0	0	0	0	0	70.21	0	0	12
2014	9	4	22	22	18	31	0	0	0	0	0	0	0	70.02	0	0	12
2014	9	4	22	32	18	31	0	0	0	0	0	0	0	69.82	0	0	12
2014	9	4	22	42	18	30	0	0	0	0	0	0	0	69.64	0	0	12
2014	9	4	22	52	18	31	0	0	0	0	0	0	0	69.46	0	0	12
2014	9	4	23	2	18	31	0	0	0	0	0	0	0	69.3	0	0	12
2014	9	4	23	12	18	31	0	0	0	0	0	0	0	69.13	0	0	12
2014	9	4	23	22	18	31	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	4	23	32	18	31	0	0	0	0	0	0	0	68.9	0	0	12
2014	9	4	23	42	18	30	0	0	0	0	0	0	0	68.79	0	0	12
2014	9	4	23	52	18	32	0	0	0	0	0	0	0	68.7	0	0	12
2014	9	5	0	2	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	5	0	12	18	31	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	5	0	22	18	32	0	0	0	0	0	0	0	68.45	0	0	12
2014	9	5	0	32	18	32	0	0	0	0	0	0	0	68.38	0	0	12
2014	9	5	0	42	18	31	0	0	0	0	0	0	0	68.31	0	0	12
2014	9	5	0	52	18	31	0	0	0	0	0	0	0	68.23	0	0	12
2014	9	5	1	2	18	33	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	5	1	12	18	31	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	5	1	22	18	32	0	0	0	0	0	0	0	68.02	0	0	11.8
2014	9	5	1	32	18	31	0	0	0	0	0	0	0	67.95	0	0	12
2014	9	5	1	42	18	32	0	0	0	0	0	0	0	67.89	0	0	12
2014	9	5	1	52	18	33	0	0	0	0	0	0	0	67.82	0	0	12
2014	9	5	2	2	18	31	0	0	0	0	0	0	0	67.73	0	0	12
2014	9	5	2	12	18	32	0	0	0	0	0	0	0	67.68	0	0	12
2014	9	5	2	22	18	32	0	0	0	0	0	0	0	67.59	0	0	11.8
2014	9	5	2	32	18	31	0	0	0	0	0	0	0	67.51	0	0	12
2014	9	5	2	42	18	32	0	0	0	0	0	0	0	67.46	0	0	12
2014	9	5	2	52	18	31	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	5	3	2	18	31	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	5	3	12	18	31	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	5	3	22	18	32	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	5	3	32	18	31	0	0	0	0	0	0	0	67.12	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	3	42	18	31	0	0	0	0	0	0	0	67.05	0	0	12
2014	9	5	3	52	18	32	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	5	4	2	18	32	0	0	0	0	0	0	0	66.87	0	0	12
2014	9	5	4	12	18	31	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	5	4	22	18	32	0	0	0	0	0	0	0	66.67	0	0	12
2014	9	5	4	32	18	31	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	5	4	42	18	31	0	0	0	0	0	0	0	66.49	0	0	12
2014	9	5	4	52	18	32	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	5	5	2	18	32	0	0	0	0	0	0	0	66.31	0	0	12
2014	9	5	5	12	18	32	0	0	0	0	0	0	0	66.22	0	0	12
2014	9	5	5	22	18	32	0	0	0	0	0	0	0	66.13	0	0	11.8
2014	9	5	5	32	18	32	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	5	5	42	18	32	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	5	5	52	18	32	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	5	6	2	18	32	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	5	6	12	18	31	0	0	0	0	0	0	0	65.59	0	0	12
2014	9	5	6	22	18	32	0	0	0	0	0	0	0	65.46	0	0	11.8
2014	9	5	6	32	18	32	0	0	0	0	0	0	0	65.35	0	0	12
2014	9	5	6	42	18	32	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	5	6	52	18	32	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	5	7	2	18	33	0	0	0	0	0	0	0	64.99	0	0	12
2014	9	5	7	12	18	32	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	5	7	22	18	32	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	5	7	32	18	32	0	0	0	0	0	0	0	64.67	0	0	12.4
2014	9	5	7	42	18	33	0	0	0	0	0	0	0	64.56	0	0	12.6
2014	9	5	7	52	18	33	0	0	0	0	0	0	0	64.47	0	0	12.8
2014	9	5	8	2	18	32	0	0	0	0	0	0	0	64.4	0	0	13
2014	9	5	8	12	18	31	0	0	0	0	0	0	0	64.33	0	0	13
2014	9	5	8	22	18	32	0	0	0	0	0	0	0	64.27	0	0	13
2014	9	5	8	32	18	32	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	5	8	42	18	32	0	0	0	0	0	0	0	64.22	0	0	13.2
2014	9	5	8	52	18	33	0	0	0	0	0	0	0	64.18	0	0	13.4
2014	9	5	9	2	18	33	0	0	0	0	0	0	0	64.24	0	0	13.4
2014	9	5	9	12	18	32	0	0	0	0	0	0	0	64.71	0	0	13.4
2014	9	5	9	22	18	32	0	0	0	0	0	0	0	64.83	0	0	13.4
2014	9	5	9	32	18	32	0	0	0	0	0	0	0	64.9	0	0	13.4
2014	9	5	9	42	18	32	0	0	0	0	0	0	0	65.01	0	0	13.4
2014	9	5	9	52	18	32	0	0	0	0	0	0	0	65.07	0	0	13.4
2014	9	5	10	2	18	32	0	0	0	0	0	0	0	65.16	0	0	13.4
2014	9	5	10	12	18	32	0	0	0	0	0	0	0	65.3	0	0	13.4
2014	9	5	10	22	18	32	0	0	0	0	0	0	0	65.43	0	0	13.4
2014	9	5	10	32	18	31	0	0	0	0	0	0	0	65.53	0	0	13.4
2014	9	5	10	42	18	31	0	0	0	0	0	0	0	65.71	0	0	13.4
2014	9	5	10	52	18	32	0	0	0	0	0	0	0	65.35	0	0	13.4
2014	9	5	11	2	18	31	0	0	0	0	0	0	0	65.34	0	0	13.4
2014	9	5	11	12	18	32	0	0	0	0	0	0	0	65.48	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	11	22	18	33	0	0	0	0	0	0	0	65.68	0	0	13.4
2014	9	5	11	32	18	32	0	0	0	0	0	0	0	65.89	0	0	13.4
2014	9	5	11	42	18	32	0	0	0	0	0	0	0	66.15	0	0	13.4
2014	9	5	11	52	18	31	0	0	0	0	0	0	0	66.58	0	0	13.4
2014	9	5	12	2	18	32	0	0	0	0	0	0	0	67.33	0	0	13.4
2014	9	5	12	12	18	32	0	0	0	0	0	0	0	67.75	0	0	13.4
2014	9	5	12	22	18	31	0	0	0	0	0	0	0	68.05	0	0	13.2
2014	9	5	12	32	18	32	0	0	0	0	0	0	0	68.38	0	0	13.4
2014	9	5	12	42	18	32	0	0	0	0	0	0	0	68.7	0	0	13.4
2014	9	5	12	52	18	31	0	0	0	0	0	0	0	68.99	0	0	13.4
2014	9	5	13	2	18	31	0	0	0	0	0	0	0	69.3	0	0	13.2
2014	9	5	13	12	18	32	0	0	0	0	0	0	0	69.64	0	0	13.2
2014	9	5	13	22	18	31	0	0	0	0	0	0	0	69.93	0	0	13.2
2014	9	5	13	32	18	31	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	9	5	13	42	18	31	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	9	5	13	52	18	31	0	0	0	0	0	0	0	70.83	0	0	13.2
2014	9	5	14	2	18	31	0	0	0	0	0	0	0	71.08	0	0	13.2
2014	9	5	14	12	18	31	0	0	0	0	0	0	0	71.37	0	0	13.2
2014	9	5	14	22	18	31	0	0	0	0	0	0	0	71.62	0	0	13.2
2014	9	5	14	32	18	31	0	0	0	0	0	0	0	71.87	0	0	13.2
2014	9	5	14	42	18	32	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	9	5	14	52	18	31	0	0	0	0	0	0	0	72.34	0	0	13.2
2014	9	5	15	2	18	32	0	0	0	0	0	0	0	72.57	0	0	13.2
2014	9	5	15	12	18	32	0	0	0	0	0	0	0	72.77	0	0	13.2
2014	9	5	15	22	18	31	0	0	0	0	0	0	0	72.97	0	0	13.2
2014	9	5	15	32	18	31	0	0	0	0	0	0	0	73.13	0	0	13.2
2014	9	5	15	42	18	31	0	0	0	0	0	0	0	73.27	0	0	13.2
2014	9	5	15	52	18	30	0	0	0	0	0	0	0	73.42	0	0	13.2
2014	9	5	16	2	18	31	0	0	0	0	0	0	0	73.54	0	0	13.2
2014	9	5	16	12	18	31	0	0	0	0	0	0	0	73.63	0	0	13
2014	9	5	16	22	18	31	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	9	5	16	32	18	30	0	0	0	0	0	0	0	73.8	0	0	12.8
2014	9	5	16	42	18	31	0	0	0	0	0	0	0	73.83	0	0	12.6
2014	9	5	16	52	18	31	0	0	0	0	0	0	0	73.87	0	0	12.4
2014	9	5	17	2	18	30	0	0	0	0	0	0	0	73.87	0	0	12.4
2014	9	5	17	12	18	31	0	0	0	0	0	0	0	73.85	0	0	12.4
2014	9	5	17	22	18	31	0	0	0	0	0	0	0	73.74	0	0	12.2
2014	9	5	17	32	18	31	0	0	0	0	0	0	0	73.67	0	0	12.2
2014	9	5	17	42	18	31	0	0	0	0	0	0	0	73.6	0	0	12.2
2014	9	5	17	52	18	31	0	0	0	0	0	0	0	73.53	0	0	12.2
2014	9	5	18	2	18	31	0	0	0	0	0	0	0	73.45	0	0	12.2
2014	9	5	18	12	18	31	0	0	0	0	0	0	0	73.38	0	0	12.2
2014	9	5	18	22	18	31	0	0	0	0	0	0	0	73.27	0	0	12.2
2014	9	5	18	32	18	31	0	0	0	0	0	0	0	73.18	0	0	12.2
2014	9	5	18	42	18	31	0	0	0	0	0	0	0	73.08	0	0	12.2
2014	9	5	18	52	18	30	0	0	0	0	0	0	0	72.97	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	19	2	18	32	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	9	5	19	12	18	31	0	0	0	0	0	0	0	72.72	0	0	12.2
2014	9	5	19	22	18	31	0	0	0	0	0	0	0	72.59	0	0	12
2014	9	5	19	32	18	31	0	0	0	0	0	0	0	72.45	0	0	12.2
2014	9	5	19	42	18	30	0	0	0	0	0	0	0	72.27	0	0	12.2
2014	9	5	19	52	18	31	0	0	0	0	0	0	0	72.1	0	0	12.2
2014	9	5	20	2	18	31	0	0	0	0	0	0	0	71.91	0	0	12.2
2014	9	5	20	12	18	31	0	0	0	0	0	0	0	71.73	0	0	12.2
2014	9	5	20	22	18	30	0	0	0	0	0	0	0	71.51	0	0	12
2014	9	5	20	32	18	32	0	0	0	0	0	0	0	71.29	0	0	12.2
2014	9	5	20	42	18	31	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	9	5	20	52	18	31	0	0	0	0	0	0	0	70.86	0	0	12
2014	9	5	21	2	18	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	9	5	21	12	18	31	0	0	0	0	0	0	0	70.39	0	0	12
2014	9	5	21	22	18	31	0	0	0	0	0	0	0	70.16	0	0	12
2014	9	5	21	32	18	30	0	0	0	0	0	0	0	69.91	0	0	12
2014	9	5	21	42	18	31	0	0	0	0	0	0	0	69.67	0	0	12
2014	9	5	21	52	18	30	0	0	0	0	0	0	0	69.44	0	0	12
2014	9	5	22	2	18	31	0	0	0	0	0	0	0	69.22	0	0	12
2014	9	5	22	12	18	32	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	5	22	22	18	32	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	5	22	32	18	31	0	0	0	0	0	0	0	68.67	0	0	12
2014	9	5	22	42	18	31	0	0	0	0	0	0	0	68.5	0	0	12
2014	9	5	22	52	18	31	0	0	0	0	0	0	0	68.34	0	0	12
2014	9	5	23	2	18	32	0	0	0	0	0	0	0	68.22	0	0	12
2014	9	5	23	12	18	31	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	5	23	22	18	31	0	0	0	0	0	0	0	67.98	0	0	12
2014	9	5	23	32	18	32	0	0	0	0	0	0	0	67.87	0	0	12
2014	9	5	23	42	18	32	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	5	23	52	18	31	0	0	0	0	0	0	0	67.69	0	0	12
2014	9	6	0	2	18	32	0	0	0	0	0	0	0	67.6	0	0	12
2014	9	6	0	12	18	31	0	0	0	0	0	0	0	67.51	0	0	12
2014	9	6	0	22	18	32	0	0	0	0	0	0	0	67.42	0	0	11.8
2014	9	6	0	32	18	32	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	6	0	42	18	32	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	6	0	52	18	32	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	6	1	2	18	32	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	6	1	12	18	31	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	6	1	22	18	32	0	0	0	0	0	0	0	66.87	0	0	12
2014	9	6	1	32	18	32	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	6	1	42	18	32	0	0	0	0	0	0	0	66.67	0	0	12
2014	9	6	1	52	18	31	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	6	2	2	18	32	0	0	0	0	0	0	0	66.49	0	0	12
2014	9	6	2	12	18	32	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	6	2	22	18	31	0	0	0	0	0	0	0	66.31	0	0	12
2014	9	6	2	32	18	32	0	0	0	0	0	0	0	66.22	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	2	42	18	30	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	6	2	52	18	32	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	6	3	2	18	31	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	6	3	12	18	32	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	6	3	22	18	32	0	0	0	0	0	0	0	65.79	0	0	11.8
2014	9	6	3	32	18	32	0	0	0	0	0	0	0	65.71	0	0	12
2014	9	6	3	42	18	32	0	0	0	0	0	0	0	65.64	0	0	12
2014	9	6	3	52	18	32	0	0	0	0	0	0	0	65.55	0	0	12
2014	9	6	4	2	18	32	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	6	4	12	18	31	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	6	4	22	18	32	0	0	0	0	0	0	0	65.3	0	0	11.8
2014	9	6	4	32	18	32	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	6	4	42	18	32	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	6	4	52	18	31	0	0	0	0	0	0	0	65.01	0	0	12
2014	9	6	5	2	18	31	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	6	5	12	18	32	0	0	0	0	0	0	0	64.83	0	0	12
2014	9	6	5	22	18	32	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	6	5	32	18	32	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	6	5	42	18	32	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	6	5	52	18	33	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	6	6	2	18	32	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	6	6	12	18	32	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	6	6	22	18	32	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	6	6	32	18	32	0	0	0	0	0	0	0	63.91	0	0	11.8
2014	9	6	6	42	18	32	0	0	0	0	0	0	0	63.81	0	0	11.8
2014	9	6	6	52	18	33	0	0	0	0	0	0	0	63.7	0	0	11.8
2014	9	6	7	2	18	32	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	6	7	12	18	32	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	6	7	22	18	33	0	0	0	0	0	0	0	63.36	0	0	11.8
2014	9	6	7	32	18	32	0	0	0	0	0	0	0	63.27	0	0	12.4
2014	9	6	7	42	18	32	0	0	0	0	0	0	0	63.18	0	0	12.8
2014	9	6	7	52	18	32	0	0	0	0	0	0	0	63.1	0	0	13
2014	9	6	8	2	18	31	0	0	0	0	0	0	0	63.05	0	0	13
2014	9	6	8	12	18	33	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	6	8	22	18	32	0	0	0	0	0	0	0	62.96	0	0	13.2
2014	9	6	8	32	18	32	0	0	0	0	0	0	0	62.94	0	0	13.2
2014	9	6	8	42	18	32	0	0	0	0	0	0	0	62.92	0	0	13.4
2014	9	6	8	52	18	33	0	0	0	0	0	0	0	62.92	0	0	13.4
2014	9	6	9	2	18	31	0	0	0	0	0	0	0	62.96	0	0	13.4
2014	9	6	9	12	18	32	0	0	0	0	0	0	0	63.52	0	0	13.6
2014	9	6	9	22	18	32	0	0	0	0	0	0	0	63.68	0	0	13.4
2014	9	6	9	32	18	32	0	0	0	0	0	0	0	63.79	0	0	13.4
2014	9	6	9	42	18	32	0	0	0	0	0	0	0	63.91	0	0	13.4
2014	9	6	9	52	18	33	0	0	0	0	0	0	0	64.09	0	0	13.4
2014	9	6	10	2	18	32	0	0	0	0	0	0	0	64.2	0	0	13.4
2014	9	6	10	12	18	32	0	0	0	0	0	0	0	64.35	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	10	22	18	32	0	0	0	0	0	0	0	64.53	0	0	13.2
2014	9	6	10	32	18	32	0	0	0	0	0	0	0	64.63	0	0	13.4
2014	9	6	10	42	18	32	0	0	0	0	0	0	0	64.81	0	0	13.4
2014	9	6	10	52	18	32	0	0	0	0	0	0	0	64.36	0	0	13.4
2014	9	6	11	2	18	32	0	0	0	0	0	0	0	64.38	0	0	13.4
2014	9	6	11	12	18	32	0	0	0	0	0	0	0	64.54	0	0	13.4
2014	9	6	11	22	18	32	0	0	0	0	0	0	0	64.74	0	0	13.4
2014	9	6	11	32	18	32	0	0	0	0	0	0	0	64.98	0	0	13.4
2014	9	6	11	42	18	32	0	0	0	0	0	0	0	65.26	0	0	13.4
2014	9	6	11	52	18	32	0	0	0	0	0	0	0	65.93	0	0	13.4
2014	9	6	12	2	18	32	0	0	0	0	0	0	0	66.56	0	0	13.4
2014	9	6	12	12	18	32	0	0	0	0	0	0	0	66.96	0	0	13.4
2014	9	6	12	22	18	32	0	0	0	0	0	0	0	67.3	0	0	13.2
2014	9	6	12	32	18	32	0	0	0	0	0	0	0	67.64	0	0	13.2
2014	9	6	12	42	18	32	0	0	0	0	0	0	0	67.93	0	0	13.2
2014	9	6	12	52	18	32	0	0	0	0	0	0	0	68.25	0	0	13.2
2014	9	6	13	2	18	31	0	0	0	0	0	0	0	68.58	0	0	13.2
2014	9	6	13	12	18	31	0	0	0	0	0	0	0	68.94	0	0	13.2
2014	9	6	13	22	18	31	0	0	0	0	0	0	0	69.26	0	0	13.2
2014	9	6	13	32	18	31	0	0	0	0	0	0	0	69.57	0	0	13.2
2014	9	6	13	42	18	31	0	0	0	0	0	0	0	69.91	0	0	13.2
2014	9	6	13	52	18	32	0	0	0	0	0	0	0	70.23	0	0	13.2
2014	9	6	14	2	18	32	0	0	0	0	0	0	0	70.56	0	0	13.2
2014	9	6	14	12	18	32	0	0	0	0	0	0	0	70.9	0	0	13.2
2014	9	6	14	22	18	32	0	0	0	0	0	0	0	71.17	0	0	13.2
2014	9	6	14	32	18	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2014	9	6	14	42	18	31	0	0	0	0	0	0	0	71.74	0	0	13.2
2014	9	6	14	52	18	31	0	0	0	0	0	0	0	72.01	0	0	13.2
2014	9	6	15	2	18	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	9	6	15	12	18	31	0	0	0	0	0	0	0	72.54	0	0	13.2
2014	9	6	15	22	18	32	0	0	0	0	0	0	0	72.7	0	0	13.2
2014	9	6	15	32	18	31	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	9	6	15	42	18	32	0	0	0	0	0	0	0	73.09	0	0	13.2
2014	9	6	15	52	18	32	0	0	0	0	0	0	0	73.26	0	0	13.2
2014	9	6	16	2	18	31	0	0	0	0	0	0	0	73.42	0	0	13
2014	9	6	16	12	18	31	0	0	0	0	0	0	0	73.54	0	0	13
2014	9	6	16	22	18	30	0	0	0	0	0	0	0	73.67	0	0	12.6
2014	9	6	16	32	18	31	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	9	6	16	42	18	31	0	0	0	0	0	0	0	73.85	0	0	12.6
2014	9	6	16	52	18	30	0	0	0	0	0	0	0	73.92	0	0	12.4
2014	9	6	17	2	18	30	0	0	0	0	0	0	0	73.96	0	0	12.4
2014	9	6	17	12	18	31	0	0	0	0	0	0	0	73.99	0	0	12.4
2014	9	6	17	22	18	30	0	0	0	0	0	0	0	73.94	0	0	12.2
2014	9	6	17	32	18	30	0	0	0	0	0	0	0	73.92	0	0	12.2
2014	9	6	17	42	18	31	0	0	0	0	0	0	0	73.92	0	0	12.2
2014	9	6	17	52	18	32	0	0	0	0	0	0	0	73.9	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	18	2	18	30	0	0	0	0	0	0	0	73.87	0	0	12.2
2014	9	6	18	12	18	31	0	0	0	0	0	0	0	73.81	0	0	12.2
2014	9	6	18	22	18	31	0	0	0	0	0	0	0	73.76	0	0	12.2
2014	9	6	18	32	18	30	0	0	0	0	0	0	0	73.69	0	0	12.2
2014	9	6	18	42	18	31	0	0	0	0	0	0	0	73.62	0	0	12.2
2014	9	6	18	52	18	31	0	0	0	0	0	0	0	73.54	0	0	12.2
2014	9	6	19	2	18	32	0	0	0	0	0	0	0	73.45	0	0	12.2
2014	9	6	19	12	18	31	0	0	0	0	0	0	0	73.36	0	0	12.2
2014	9	6	19	22	18	31	0	0	0	0	0	0	0	73.29	0	0	12
2014	9	6	19	32	18	31	0	0	0	0	0	0	0	73.18	0	0	12.2
2014	9	6	19	42	18	31	0	0	0	0	0	0	0	73.08	0	0	12.2
2014	9	6	19	52	18	31	0	0	0	0	0	0	0	72.97	0	0	12.2
2014	9	6	20	2	18	30	0	0	0	0	0	0	0	72.86	0	0	12.2
2014	9	6	20	12	18	31	0	0	0	0	0	0	0	72.72	0	0	12.2
2014	9	6	20	22	18	30	0	0	0	0	0	0	0	72.57	0	0	12
2014	9	6	20	32	18	31	0	0	0	0	0	0	0	72.41	0	0	12.2
2014	9	6	20	42	18	31	0	0	0	0	0	0	0	72.25	0	0	12.2
2014	9	6	20	52	18	31	0	0	0	0	0	0	0	72.07	0	0	12.2
2014	9	6	21	2	18	31	0	0	0	0	0	0	0	71.87	0	0	12
2014	9	6	21	12	18	31	0	0	0	0	0	0	0	71.67	0	0	12
2014	9	6	21	22	18	31	0	0	0	0	0	0	0	71.46	0	0	12
2014	9	6	21	32	18	31	0	0	0	0	0	0	0	71.26	0	0	12
2014	9	6	21	42	18	32	0	0	0	0	0	0	0	71.04	0	0	12
2014	9	6	21	52	18	31	0	0	0	0	0	0	0	70.83	0	0	12
2014	9	6	22	2	18	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	9	6	22	12	18	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	9	6	22	22	18	32	0	0	0	0	0	0	0	70.2	0	0	12
2014	9	6	22	32	18	31	0	0	0	0	0	0	0	70	0	0	12
2014	9	6	22	42	18	31	0	0	0	0	0	0	0	69.82	0	0	12
2014	9	6	22	52	18	31	0	0	0	0	0	0	0	69.66	0	0	12
2014	9	6	23	2	18	31	0	0	0	0	0	0	0	69.49	0	0	12
2014	9	6	23	12	18	31	0	0	0	0	0	0	0	69.37	0	0	12
2014	9	6	23	22	18	31	0	0	0	0	0	0	0	69.22	0	0	12
2014	9	6	23	32	18	32	0	0	0	0	0	0	0	69.1	0	0	12
2014	9	6	23	42	18	31	0	0	0	0	0	0	0	68.97	0	0	12
2014	9	6	23	52	18	31	0	0	0	0	0	0	0	68.86	0	0	12
2014	9	7	0	2	18	31	0	0	0	0	0	0	0	68.74	0	0	12
2014	9	7	0	12	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	7	0	22	18	32	0	0	0	0	0	0	0	68.52	0	0	11.8
2014	9	7	0	32	18	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	7	0	42	18	32	0	0	0	0	0	0	0	68.31	0	0	12
2014	9	7	0	52	18	32	0	0	0	0	0	0	0	68.2	0	0	12
2014	9	7	1	2	18	31	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	7	1	12	18	31	0	0	0	0	0	0	0	68	0	0	12
2014	9	7	1	22	18	31	0	0	0	0	0	0	0	67.91	0	0	12
2014	9	7	1	32	18	31	0	0	0	0	0	0	0	67.82	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	1	42	18	32	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	7	1	52	18	31	0	0	0	0	0	0	0	67.62	0	0	12
2014	9	7	2	2	18	31	0	0	0	0	0	0	0	67.55	0	0	12
2014	9	7	2	12	18	32	0	0	0	0	0	0	0	67.46	0	0	12
2014	9	7	2	22	18	31	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	7	2	32	18	32	0	0	0	0	0	0	0	67.28	0	0	12
2014	9	7	2	42	18	32	0	0	0	0	0	0	0	67.19	0	0	12
2014	9	7	2	52	18	32	0	0	0	0	0	0	0	67.1	0	0	12
2014	9	7	3	2	18	32	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	7	3	12	18	32	0	0	0	0	0	0	0	66.92	0	0	12
2014	9	7	3	22	18	33	0	0	0	0	0	0	0	66.85	0	0	11.8
2014	9	7	3	32	18	31	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	7	3	42	18	31	0	0	0	0	0	0	0	66.7	0	0	12
2014	9	7	3	52	18	31	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	7	4	2	18	32	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	7	4	12	18	31	0	0	0	0	0	0	0	66.51	0	0	12
2014	9	7	4	22	18	31	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	7	4	32	18	31	0	0	0	0	0	0	0	66.34	0	0	12
2014	9	7	4	42	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	7	4	52	18	32	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	7	5	2	18	31	0	0	0	0	0	0	0	66.11	0	0	12
2014	9	7	5	12	18	32	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	7	5	22	18	32	0	0	0	0	0	0	0	65.93	0	0	11.8
2014	9	7	5	32	18	31	0	0	0	0	0	0	0	65.84	0	0	12
2014	9	7	5	42	18	32	0	0	0	0	0	0	0	65.75	0	0	12
2014	9	7	5	52	18	33	0	0	0	0	0	0	0	65.66	0	0	12
2014	9	7	6	2	18	32	0	0	0	0	0	0	0	65.59	0	0	12
2014	9	7	6	12	18	32	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	7	6	22	18	31	0	0	0	0	0	0	0	65.43	0	0	11.8
2014	9	7	6	32	18	31	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	7	6	42	18	31	0	0	0	0	0	0	0	65.25	0	0	11.8
2014	9	7	6	52	18	32	0	0	0	0	0	0	0	65.17	0	0	12
2014	9	7	7	2	18	32	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	7	7	12	18	31	0	0	0	0	0	0	0	65.03	0	0	12
2014	9	7	7	22	18	32	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	7	7	32	18	32	0	0	0	0	0	0	0	64.89	0	0	12.4
2014	9	7	7	42	18	31	0	0	0	0	0	0	0	64.83	0	0	12.6
2014	9	7	7	52	18	32	0	0	0	0	0	0	0	64.78	0	0	12.8
2014	9	7	8	2	18	32	0	0	0	0	0	0	0	64.74	0	0	13
2014	9	7	8	12	18	32	0	0	0	0	0	0	0	64.72	0	0	13
2014	9	7	8	22	18	32	0	0	0	0	0	0	0	64.71	0	0	13
2014	9	7	8	32	18	32	0	0	0	0	0	0	0	64.71	0	0	13.2
2014	9	7	8	42	18	32	0	0	0	0	0	0	0	64.72	0	0	13.4
2014	9	7	8	52	18	31	0	0	0	0	0	0	0	64.74	0	0	13.4
2014	9	7	9	2	18	32	0	0	0	0	0	0	0	64.8	0	0	13.4
2014	9	7	9	12	18	32	0	0	0	0	0	0	0	65.3	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	9	22	18	32	0	0	0	0	0	0	0	65.46	0	0	13.4
2014	9	7	9	32	18	32	0	0	0	0	0	0	0	65.61	0	0	13.4
2014	9	7	9	42	18	32	0	0	0	0	0	0	0	65.73	0	0	13.4
2014	9	7	9	52	18	32	0	0	0	0	0	0	0	65.82	0	0	13.4
2014	9	7	10	2	18	31	0	0	0	0	0	0	0	65.97	0	0	13.4
2014	9	7	10	12	18	33	0	0	0	0	0	0	0	66.09	0	0	13.4
2014	9	7	10	22	18	32	0	0	0	0	0	0	0	66.25	0	0	13.4
2014	9	7	10	32	18	32	0	0	0	0	0	0	0	66.38	0	0	13.4
2014	9	7	10	42	18	31	0	0	0	0	0	0	0	66.52	0	0	13.4
2014	9	7	10	52	18	31	0	0	0	0	0	0	0	66.13	0	0	13.4
2014	9	7	11	2	18	32	0	0	0	0	0	0	0	66.18	0	0	13.4
2014	9	7	11	12	18	32	0	0	0	0	0	0	0	66.34	0	0	13.4
2014	9	7	11	22	18	32	0	0	0	0	0	0	0	66.56	0	0	13.4
2014	9	7	11	32	18	31	0	0	0	0	0	0	0	66.78	0	0	13.4
2014	9	7	11	42	18	31	0	0	0	0	0	0	0	67.05	0	0	13.4
2014	9	7	11	52	18	31	0	0	0	0	0	0	0	67.78	0	0	13.4
2014	9	7	12	2	18	31	0	0	0	0	0	0	0	68.23	0	0	13.4
2014	9	7	12	12	18	32	0	0	0	0	0	0	0	68.58	0	0	13.4
2014	9	7	12	22	18	31	0	0	0	0	0	0	0	68.88	0	0	13.2
2014	9	7	12	32	18	32	0	0	0	0	0	0	0	69.17	0	0	13.4
2014	9	7	12	42	18	31	0	0	0	0	0	0	0	69.51	0	0	13.4
2014	9	7	12	52	18	32	0	0	0	0	0	0	0	69.82	0	0	13.4
2014	9	7	13	2	18	32	0	0	0	0	0	0	0	70.16	0	0	13.2
2014	9	7	13	12	18	32	0	0	0	0	0	0	0	70.45	0	0	13.2
2014	9	7	13	22	18	31	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	9	7	13	32	18	31	0	0	0	0	0	0	0	71.11	0	0	13.2
2014	9	7	13	42	18	31	0	0	0	0	0	0	0	71.38	0	0	13.2
2014	9	7	13	52	18	31	0	0	0	0	0	0	0	71.67	0	0	13.2
2014	9	7	14	2	18	30	0	0	0	0	0	0	0	72	0	0	13.2
2014	9	7	14	12	18	32	0	0	0	0	0	0	0	72.23	0	0	13.2
2014	9	7	14	22	18	32	0	0	0	0	0	0	0	72.5	0	0	13.2
2014	9	7	14	32	18	31	0	0	0	0	0	0	0	72.63	0	0	13
2014	9	7	14	42	18	30	0	0	0	0	0	0	0	72.88	0	0	13
2014	9	7	14	52	18	31	0	0	0	0	0	0	0	73.24	0	0	13.2
2014	9	7	15	2	18	31	0	0	0	0	0	0	0	73.47	0	0	13.2
2014	9	7	15	12	18	31	0	0	0	0	0	0	0	73.69	0	0	13.2
2014	9	7	15	22	18	32	0	0	0	0	0	0	0	73.69	0	0	12.4
2014	9	7	15	32	18	30	0	0	0	0	0	0	0	74.07	0	0	13.2
2014	9	7	15	42	18	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2014	9	7	15	52	18	31	0	0	0	0	0	0	0	74.43	0	0	12.8
2014	9	7	16	2	18	30	0	0	0	0	0	0	0	74.46	0	0	12.6
2014	9	7	16	12	18	31	0	0	0	0	0	0	0	74.62	0	0	12.6
2014	9	7	16	22	18	30	0	0	0	0	0	0	0	74.79	0	0	12.6
2014	9	7	16	32	18	31	0	0	0	0	0	0	0	74.91	0	0	12.6
2014	9	7	16	42	18	30	0	0	0	0	0	0	0	75.02	0	0	12.6
2014	9	7	16	52	18	31	0	0	0	0	0	0	0	74.97	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	17	2	18	30	0	0	0	0	0	0	0	75.04	0	0	12.4
2014	9	7	17	12	18	30	0	0	0	0	0	0	0	75.09	0	0	12.4
2014	9	7	17	22	18	30	0	0	0	0	0	0	0	75.06	0	0	12.2
2014	9	7	17	32	18	31	0	0	0	0	0	0	0	75.09	0	0	12.2
2014	9	7	17	42	18	31	0	0	0	0	0	0	0	75.09	0	0	12.2
2014	9	7	17	52	18	30	0	0	0	0	0	0	0	75.09	0	0	12.2
2014	9	7	18	2	18	31	0	0	0	0	0	0	0	75.07	0	0	12.2
2014	9	7	18	12	18	30	0	0	0	0	0	0	0	75.06	0	0	12.2
2014	9	7	18	22	18	31	0	0	0	0	0	0	0	75.02	0	0	12.2
2014	9	7	18	32	18	31	0	0	0	0	0	0	0	74.95	0	0	12.2
2014	9	7	18	42	18	30	0	0	0	0	0	0	0	74.86	0	0	12.2
2014	9	7	18	52	18	31	0	0	0	0	0	0	0	74.77	0	0	12.2
2014	9	7	19	2	18	30	0	0	0	0	0	0	0	74.64	0	0	12.2
2014	9	7	19	12	18	30	0	0	0	0	0	0	0	74.52	0	0	12.2
2014	9	7	19	22	18	31	0	0	0	0	0	0	0	74.37	0	0	12.2
2014	9	7	19	32	18	31	0	0	0	0	0	0	0	74.21	0	0	12.2
2014	9	7	19	42	18	31	0	0	0	0	0	0	0	74.05	0	0	12.2
2014	9	7	19	52	18	31	0	0	0	0	0	0	0	73.87	0	0	12.2
2014	9	7	20	2	18	31	0	0	0	0	0	0	0	73.71	0	0	12.2
2014	9	7	20	12	18	31	0	0	0	0	0	0	0	73.53	0	0	12.2
2014	9	7	20	22	18	31	0	0	0	0	0	0	0	73.35	0	0	12
2014	9	7	20	32	18	31	0	0	0	0	0	0	0	73.17	0	0	12.2
2014	9	7	20	42	18	31	0	0	0	0	0	0	0	73	0	0	12.2
2014	9	7	20	52	18	31	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	9	7	21	2	18	30	0	0	0	0	0	0	0	72.64	0	0	12.2
2014	9	7	21	12	18	31	0	0	0	0	0	0	0	72.48	0	0	12.2
2014	9	7	21	22	18	31	0	0	0	0	0	0	0	72.32	0	0	12
2014	9	7	21	32	18	32	0	0	0	0	0	0	0	72.14	0	0	12
2014	9	7	21	42	18	31	0	0	0	0	0	0	0	71.98	0	0	12
2014	9	7	21	52	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	9	7	22	2	18	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	9	7	22	12	18	31	0	0	0	0	0	0	0	71.47	0	0	12
2014	9	7	22	22	18	31	0	0	0	0	0	0	0	71.33	0	0	12
2014	9	7	22	32	18	31	0	0	0	0	0	0	0	71.17	0	0	12
2014	9	7	22	42	18	31	0	0	0	0	0	0	0	71.04	0	0	12
2014	9	7	22	52	18	31	0	0	0	0	0	0	0	70.92	0	0	12
2014	9	7	23	2	18	32	0	0	0	0	0	0	0	70.79	0	0	12
2014	9	7	23	12	18	31	0	0	0	0	0	0	0	70.66	0	0	12
2014	9	7	23	22	18	31	0	0	0	0	0	0	0	70.57	0	0	12
2014	9	7	23	32	18	31	0	0	0	0	0	0	0	70.47	0	0	12
2014	9	7	23	42	18	31	0	0	0	0	0	0	0	70.39	0	0	12
2014	9	7	23	52	18	31	0	0	0	0	0	0	0	70.3	0	0	12
2014	9	8	0	2	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	9	8	0	12	18	30	0	0	0	0	0	0	0	70.16	0	0	12
2014	9	8	0	22	18	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	9	8	0	32	18	32	0	0	0	0	0	0	0	70.05	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	0	42	18	31	0	0	0	0	0	0	0	70.02	0	0	12
2014	9	8	0	52	18	31	0	0	0	0	0	0	0	69.96	0	0	12
2014	9	8	1	2	18	31	0	0	0	0	0	0	0	69.93	0	0	12
2014	9	8	1	12	18	31	0	0	0	0	0	0	0	69.87	0	0	12
2014	9	8	1	22	18	32	0	0	0	0	0	0	0	69.84	0	0	12
2014	9	8	1	32	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	9	8	1	42	18	32	0	0	0	0	0	0	0	69.76	0	0	12
2014	9	8	1	52	18	32	0	0	0	0	0	0	0	69.75	0	0	12
2014	9	8	2	2	18	32	0	0	0	0	0	0	0	69.73	0	0	12
2014	9	8	2	12	18	31	0	0	0	0	0	0	0	69.69	0	0	12
2014	9	8	2	22	18	31	0	0	0	0	0	0	0	69.66	0	0	12
2014	9	8	2	32	18	31	0	0	0	0	0	0	0	69.62	0	0	12
2014	9	8	2	42	18	32	0	0	0	0	0	0	0	69.58	0	0	12
2014	9	8	2	52	18	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	9	8	3	2	18	31	0	0	0	0	0	0	0	69.51	0	0	12
2014	9	8	3	12	18	31	0	0	0	0	0	0	0	69.48	0	0	12
2014	9	8	3	22	18	32	0	0	0	0	0	0	0	69.46	0	0	12
2014	9	8	3	32	18	32	0	0	0	0	0	0	0	69.46	0	0	12
2014	9	8	3	42	18	31	0	0	0	0	0	0	0	69.44	0	0	12
2014	9	8	3	52	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	9	8	4	2	18	31	0	0	0	0	0	0	0	69.4	0	0	12
2014	9	8	4	12	18	31	0	0	0	0	0	0	0	69.4	0	0	12
2014	9	8	4	22	18	31	0	0	0	0	0	0	0	69.37	0	0	11.8
2014	9	8	4	32	18	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	9	8	4	42	18	31	0	0	0	0	0	0	0	69.33	0	0	12
2014	9	8	4	52	18	31	0	0	0	0	0	0	0	69.3	0	0	12
2014	9	8	5	2	18	31	0	0	0	0	0	0	0	69.26	0	0	12
2014	9	8	5	12	18	31	0	0	0	0	0	0	0	69.22	0	0	12
2014	9	8	5	22	18	30	0	0	0	0	0	0	0	69.17	0	0	11.8
2014	9	8	5	32	18	31	0	0	0	0	0	0	0	69.12	0	0	12
2014	9	8	5	42	18	32	0	0	0	0	0	0	0	69.06	0	0	12
2014	9	8	5	52	18	31	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	8	6	2	18	31	0	0	0	0	0	0	0	68.95	0	0	12
2014	9	8	6	12	18	31	0	0	0	0	0	0	0	68.88	0	0	12
2014	9	8	6	22	18	32	0	0	0	0	0	0	0	68.81	0	0	12
2014	9	8	6	32	18	32	0	0	0	0	0	0	0	68.76	0	0	12
2014	9	8	6	42	18	31	0	0	0	0	0	0	0	68.68	0	0	12
2014	9	8	6	52	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	8	7	2	18	32	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	8	7	12	18	31	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	8	7	22	18	30	0	0	0	0	0	0	0	68.49	0	0	12
2014	9	8	7	32	18	31	0	0	0	0	0	0	0	68.43	0	0	12
2014	9	8	7	42	18	31	0	0	0	0	0	0	0	68.43	0	0	12.4
2014	9	8	7	52	18	32	0	0	0	0	0	0	0	68.43	0	0	12.8
2014	9	8	8	2	18	32	0	0	0	0	0	0	0	68.38	0	0	12.6
2014	9	8	8	12	18	32	0	0	0	0	0	0	0	68.4	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	8	22	18	31	0	0	0	0	0	0	0	68.31	0	0	12
2014	9	8	8	32	18	32	0	0	0	0	0	0	0	68.25	0	0	12.2
2014	9	8	8	42	18	32	0	0	0	0	0	0	0	68.25	0	0	12.2
2014	9	8	8	52	18	31	0	0	0	0	0	0	0	68.18	0	0	12.2
2014	9	8	9	2	18	31	0	0	0	0	0	0	0	68.16	0	0	13.2
2014	9	8	9	12	18	32	0	0	0	0	0	0	0	68.58	0	0	13.4
2014	9	8	9	22	18	31	0	0	0	0	0	0	0	68.63	0	0	13.2
2014	9	8	9	32	18	31	0	0	0	0	0	0	0	68.95	0	0	13.6
2014	9	8	9	42	18	32	0	0	0	0	0	0	0	68.92	0	0	13
2014	9	8	9	52	18	32	0	0	0	0	0	0	0	68.59	0	0	13
2014	9	8	10	2	18	31	0	0	0	0	0	0	0	68.59	0	0	12.6
2014	9	8	10	12	18	32	0	0	0	0	0	0	0	68.52	0	0	12.6
2014	9	8	10	22	18	31	0	0	0	0	0	0	0	68.76	0	0	12.8
2014	9	8	10	32	18	31	0	0	0	0	0	0	0	69.39	0	0	13.6
2014	9	8	10	42	18	31	0	0	0	0	0	0	0	69.35	0	0	13.6
2014	9	8	10	52	18	32	0	0	0	0	0	0	0	68.85	0	0	13.6
2014	9	8	11	2	18	32	0	0	0	0	0	0	0	68.88	0	0	13.6
2014	9	8	11	12	18	31	0	0	0	0	0	0	0	69.01	0	0	13.6
2014	9	8	11	22	18	31	0	0	0	0	0	0	0	69.19	0	0	13.4
2014	9	8	11	32	18	32	0	0	0	0	0	0	0	69.39	0	0	13.6
2014	9	8	11	42	18	32	0	0	0	0	0	0	0	69.64	0	0	13.6
2014	9	8	11	52	18	31	0	0	0	0	0	0	0	70.43	0	0	13.6
2014	9	8	12	2	18	31	0	0	0	0	0	0	0	70.81	0	0	13.4
2014	9	8	12	12	18	32	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	9	8	12	22	18	32	0	0	0	0	0	0	0	71.37	0	0	13.4
2014	9	8	12	32	18	31	0	0	0	0	0	0	0	71.62	0	0	13.4
2014	9	8	12	42	18	31	0	0	0	0	0	0	0	71.85	0	0	13.4
2014	9	8	12	52	18	31	0	0	0	0	0	0	0	72.05	0	0	13.2
2014	9	8	13	2	18	31	0	0	0	0	0	0	0	71.78	0	0	12.6
2014	9	8	13	12	18	31	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	9	8	13	22	18	31	0	0	0	0	0	0	0	72.63	0	0	13.4
2014	9	8	13	32	18	30	0	0	0	0	0	0	0	72.43	0	0	13.2
2014	9	8	13	42	18	31	0	0	0	0	0	0	0	72.93	0	0	13.6
2014	9	8	13	52	18	32	0	0	0	0	0	0	0	73.18	0	0	13.6
2014	9	8	14	2	18	31	0	0	0	0	0	0	0	72.97	0	0	12.8
2014	9	8	14	12	18	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2014	9	8	14	22	18	31	0	0	0	0	0	0	0	73.65	0	0	13.4
2014	9	8	14	32	18	31	0	0	0	0	0	0	0	73.92	0	0	13.4
2014	9	8	14	42	18	31	0	0	0	0	0	0	0	74.14	0	0	13.4
2014	9	8	14	52	18	31	0	0	0	0	0	0	0	74.37	0	0	13.4
2014	9	8	15	2	18	30	0	0	0	0	0	0	0	74.41	0	0	13.2
2014	9	8	15	12	18	31	0	0	0	0	0	0	0	74.46	0	0	12.8
2014	9	8	15	22	18	31	0	0	0	0	0	0	0	74.68	0	0	12.8
2014	9	8	15	32	18	31	0	0	0	0	0	0	0	74.82	0	0	13.2
2014	9	8	15	42	18	31	0	0	0	0	0	0	0	75.07	0	0	13.4
2014	9	8	15	52	18	31	0	0	0	0	0	0	0	75.24	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	16	2	18	31	0	0	0	0	0	0	0	75.31	0	0	13
2014	9	8	16	12	18	31	0	0	0	0	0	0	0	75.52	0	0	13.2
2014	9	8	16	22	18	31	0	0	0	0	0	0	0	75.56	0	0	12.8
2014	9	8	16	32	18	31	0	0	0	0	0	0	0	75.63	0	0	12.8
2014	9	8	16	42	18	30	0	0	0	0	0	0	0	75.54	0	0	12.4
2014	9	8	16	52	18	30	0	0	0	0	0	0	0	75.56	0	0	12.4
2014	9	8	17	2	18	30	0	0	0	0	0	0	0	75.58	0	0	12.4
2014	9	8	17	12	18	31	0	0	0	0	0	0	0	75.54	0	0	12.4
2014	9	8	17	22	18	32	0	0	0	0	0	0	0	75.54	0	0	12.2
2014	9	8	17	32	18	30	0	0	0	0	0	0	0	75.51	0	0	12.4
2014	9	8	17	42	18	30	0	0	0	0	0	0	0	75.47	0	0	12.2
2014	9	8	17	52	18	31	0	0	0	0	0	0	0	75.42	0	0	12.2
2014	9	8	18	2	18	30	0	0	0	0	0	0	0	75.43	0	0	12.2
2014	9	8	18	12	18	30	0	0	0	0	0	0	0	75.42	0	0	12.2
2014	9	8	18	22	18	31	0	0	0	0	0	0	0	75.36	0	0	12
2014	9	8	18	32	18	30	0	0	0	0	0	0	0	75.34	0	0	12.2
2014	9	8	18	42	18	30	0	0	0	0	0	0	0	75.29	0	0	12.2
2014	9	8	18	52	18	31	0	0	0	0	0	0	0	75.24	0	0	12.2
2014	9	8	19	2	18	31	0	0	0	0	0	0	0	75.15	0	0	12.2
2014	9	8	19	12	18	30	0	0	0	0	0	0	0	75.04	0	0	12.2
2014	9	8	19	22	18	30	0	0	0	0	0	0	0	74.95	0	0	12
2014	9	8	19	32	18	30	0	0	0	0	0	0	0	74.82	0	0	12.2
2014	9	8	19	42	18	31	0	0	0	0	0	0	0	74.7	0	0	12.2
2014	9	8	19	52	18	30	0	0	0	0	0	0	0	74.53	0	0	12.2
2014	9	8	20	2	18	30	0	0	0	0	0	0	0	74.39	0	0	12.2
2014	9	8	20	12	18	31	0	0	0	0	0	0	0	74.23	0	0	12.2
2014	9	8	20	22	18	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	9	8	20	32	18	31	0	0	0	0	0	0	0	73.89	0	0	12.2
2014	9	8	20	42	18	30	0	0	0	0	0	0	0	73.69	0	0	12.2
2014	9	8	20	52	18	31	0	0	0	0	0	0	0	73.53	0	0	12
2014	9	8	21	2	18	32	0	0	0	0	0	0	0	73.33	0	0	12
2014	9	8	21	12	18	30	0	0	0	0	0	0	0	73.11	0	0	12
2014	9	8	21	22	18	31	0	0	0	0	0	0	0	72.93	0	0	12
2014	9	8	21	32	18	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	9	8	21	42	18	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	9	8	21	52	18	31	0	0	0	0	0	0	0	72.32	0	0	12
2014	9	8	22	2	18	31	0	0	0	0	0	0	0	72.1	0	0	12
2014	9	8	22	12	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	9	8	22	22	18	30	0	0	0	0	0	0	0	71.71	0	0	12
2014	9	8	22	32	18	31	0	0	0	0	0	0	0	71.49	0	0	12
2014	9	8	22	42	18	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	9	8	22	52	18	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	9	8	23	2	18	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	9	8	23	12	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	9	8	23	22	18	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	9	8	23	32	18	32	0	0	0	0	0	0	0	70.47	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	23	42	18	31	0	0	0	0	0	0	0	70.32	0	0	12
2014	9	8	23	52	18	32	0	0	0	0	0	0	0	70.16	0	0	12
2014	9	9	0	2	18	32	0	0	0	0	0	0	0	70.02	0	0	12
2014	9	9	0	12	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	9	9	0	22	18	31	0	0	0	0	0	0	0	69.71	0	0	12
2014	9	9	0	32	18	32	0	0	0	0	0	0	0	69.57	0	0	12
2014	9	9	0	42	18	31	0	0	0	0	0	0	0	69.44	0	0	12
2014	9	9	0	52	18	31	0	0	0	0	0	0	0	69.3	0	0	12
2014	9	9	1	2	18	31	0	0	0	0	0	0	0	69.15	0	0	12
2014	9	9	1	12	18	31	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	9	1	22	18	32	0	0	0	0	0	0	0	68.86	0	0	12
2014	9	9	1	32	18	31	0	0	0	0	0	0	0	68.72	0	0	12
2014	9	9	1	42	18	31	0	0	0	0	0	0	0	68.58	0	0	12
2014	9	9	1	52	18	32	0	0	0	0	0	0	0	68.43	0	0	12
2014	9	9	2	2	18	32	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	9	2	12	18	31	0	0	0	0	0	0	0	68.14	0	0	12
2014	9	9	2	22	18	31	0	0	0	0	0	0	0	68	0	0	11.8
2014	9	9	2	32	18	32	0	0	0	0	0	0	0	67.86	0	0	12
2014	9	9	2	42	18	31	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	9	2	52	18	31	0	0	0	0	0	0	0	67.57	0	0	12
2014	9	9	3	2	18	32	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	9	3	12	18	31	0	0	0	0	0	0	0	67.28	0	0	12
2014	9	9	3	22	18	32	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	9	3	32	18	32	0	0	0	0	0	0	0	66.99	0	0	12
2014	9	9	3	42	18	31	0	0	0	0	0	0	0	66.85	0	0	12
2014	9	9	3	52	18	32	0	0	0	0	0	0	0	66.72	0	0	12
2014	9	9	4	2	18	32	0	0	0	0	0	0	0	66.61	0	0	12
2014	9	9	4	12	18	31	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	9	4	22	18	32	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	9	4	32	18	31	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	9	4	42	18	32	0	0	0	0	0	0	0	66.07	0	0	12
2014	9	9	4	52	18	32	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	9	5	2	18	32	0	0	0	0	0	0	0	65.79	0	0	12
2014	9	9	5	12	18	31	0	0	0	0	0	0	0	65.66	0	0	12
2014	9	9	5	22	18	32	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	9	5	32	18	32	0	0	0	0	0	0	0	65.37	0	0	12
2014	9	9	5	42	18	31	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	9	5	52	18	32	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	9	6	2	18	32	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	9	6	12	18	32	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	9	6	22	18	32	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	9	6	32	18	32	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	9	6	42	18	31	0	0	0	0	0	0	0	64.42	0	0	12
2014	9	9	6	52	18	32	0	0	0	0	0	0	0	64.29	0	0	12
2014	9	9	7	2	18	31	0	0	0	0	0	0	0	64.18	0	0	12
2014	9	9	7	12	18	32	0	0	0	0	0	0	0	64.04	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	7	22	18	31	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	9	7	32	18	32	0	0	0	0	0	0	0	63.81	0	0	12.4
2014	9	9	7	42	18	32	0	0	0	0	0	0	0	63.7	0	0	12.8
2014	9	9	7	52	18	32	0	0	0	0	0	0	0	63.61	0	0	12.8
2014	9	9	8	2	18	32	0	0	0	0	0	0	0	63.5	0	0	13
2014	9	9	8	12	18	32	0	0	0	0	0	0	0	63.41	0	0	13.2
2014	9	9	8	22	18	31	0	0	0	0	0	0	0	63.32	0	0	13.2
2014	9	9	8	32	18	32	0	0	0	0	0	0	0	63.23	0	0	13.2
2014	9	9	8	42	18	32	0	0	0	0	0	0	0	63.16	0	0	13.4
2014	9	9	8	52	18	33	0	0	0	0	0	0	0	63.1	0	0	13.4
2014	9	9	9	2	18	32	0	0	0	0	0	0	0	63.05	0	0	13.4
2014	9	9	9	12	18	32	0	0	0	0	0	0	0	63.3	0	0	13.6
2014	9	9	9	22	18	31	0	0	0	0	0	0	0	63.57	0	0	13.6
2014	9	9	9	32	18	33	0	0	0	0	0	0	0	63.66	0	0	13.6
2014	9	9	9	42	18	32	0	0	0	0	0	0	0	63.72	0	0	13.6
2014	9	9	9	52	18	32	0	0	0	0	0	0	0	63.77	0	0	13.6
2014	9	9	10	2	18	32	0	0	0	0	0	0	0	63.84	0	0	13.6
2014	9	9	10	12	18	32	0	0	0	0	0	0	0	63.93	0	0	13.6
2014	9	9	10	22	18	32	0	0	0	0	0	0	0	63.99	0	0	13.6
2014	9	9	10	32	18	31	0	0	0	0	0	0	0	64.09	0	0	13.6
2014	9	9	10	42	18	32	0	0	0	0	0	0	0	64.13	0	0	13.6
2014	9	9	10	52	18	32	0	0	0	0	0	0	0	63.68	0	0	13.6
2014	9	9	11	2	18	32	0	0	0	0	0	0	0	63.75	0	0	13.6
2014	9	9	11	12	18	33	0	0	0	0	0	0	0	63.88	0	0	13.6
2014	9	9	11	22	18	32	0	0	0	0	0	0	0	64.06	0	0	13.6
2014	9	9	11	32	18	33	0	0	0	0	0	0	0	64.26	0	0	13.6
2014	9	9	11	42	18	32	0	0	0	0	0	0	0	64.51	0	0	13.6
2014	9	9	11	52	18	32	0	0	0	0	0	0	0	65.37	0	0	13.6
2014	9	9	12	2	18	32	0	0	0	0	0	0	0	65.73	0	0	13.6
2014	9	9	12	12	18	33	0	0	0	0	0	0	0	66.06	0	0	13.6
2014	9	9	12	22	18	32	0	0	0	0	0	0	0	66.34	0	0	13.4
2014	9	9	12	32	18	32	0	0	0	0	0	0	0	66.69	0	0	13.4
2014	9	9	12	42	18	32	0	0	0	0	0	0	0	66.99	0	0	13.4
2014	9	9	12	52	18	32	0	0	0	0	0	0	0	67.32	0	0	13.4
2014	9	9	13	2	18	31	0	0	0	0	0	0	0	67.6	0	0	13.4
2014	9	9	13	12	18	32	0	0	0	0	0	0	0	67.93	0	0	13.4
2014	9	9	13	22	18	31	0	0	0	0	0	0	0	68.23	0	0	13.4
2014	9	9	13	32	18	32	0	0	0	0	0	0	0	68.58	0	0	13.4
2014	9	9	13	42	18	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2014	9	9	13	52	18	32	0	0	0	0	0	0	0	69.17	0	0	13.4
2014	9	9	14	2	18	31	0	0	0	0	0	0	0	69.46	0	0	13.4
2014	9	9	14	12	18	31	0	0	0	0	0	0	0	69.73	0	0	13.4
2014	9	9	14	22	18	32	0	0	0	0	0	0	0	70.03	0	0	13.2
2014	9	9	14	32	18	31	0	0	0	0	0	0	0	70.27	0	0	13.4
2014	9	9	14	42	18	31	0	0	0	0	0	0	0	70.5	0	0	13.4
2014	9	9	14	52	18	31	0	0	0	0	0	0	0	70.75	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	15	2	18	31	0	0	0	0	0	0	0	70.93	0	0	13.4
2014	9	9	15	12	18	31	0	0	0	0	0	0	0	71.15	0	0	13.4
2014	9	9	15	22	18	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	9	9	15	32	18	31	0	0	0	0	0	0	0	71.49	0	0	13.4
2014	9	9	15	42	18	32	0	0	0	0	0	0	0	71.65	0	0	13.2
2014	9	9	15	52	18	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	9	9	16	2	18	31	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	9	9	16	12	18	31	0	0	0	0	0	0	0	72.05	0	0	13
2014	9	9	16	22	18	30	0	0	0	0	0	0	0	72.18	0	0	12.8
2014	9	9	16	32	18	31	0	0	0	0	0	0	0	72.25	0	0	12.8
2014	9	9	16	42	18	31	0	0	0	0	0	0	0	72.32	0	0	12.6
2014	9	9	16	52	18	31	0	0	0	0	0	0	0	72.37	0	0	12.4
2014	9	9	17	2	18	31	0	0	0	0	0	0	0	72.41	0	0	12.4
2014	9	9	17	12	18	31	0	0	0	0	0	0	0	72.45	0	0	12.4
2014	9	9	17	22	18	32	0	0	0	0	0	0	0	72.43	0	0	12.2
2014	9	9	17	32	18	31	0	0	0	0	0	0	0	72.39	0	0	12.2
2014	9	9	17	42	18	31	0	0	0	0	0	0	0	72.37	0	0	12.2
2014	9	9	17	52	18	31	0	0	0	0	0	0	0	72.36	0	0	12.2
2014	9	9	18	2	18	31	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	9	9	18	12	18	31	0	0	0	0	0	0	0	72.25	0	0	12.2
2014	9	9	18	22	18	32	0	0	0	0	0	0	0	72.18	0	0	12.2
2014	9	9	18	32	18	31	0	0	0	0	0	0	0	72.09	0	0	12.2
2014	9	9	18	42	18	31	0	0	0	0	0	0	0	71.98	0	0	12.2
2014	9	9	18	52	18	31	0	0	0	0	0	0	0	71.85	0	0	12.2
2014	9	9	19	2	18	31	0	0	0	0	0	0	0	71.71	0	0	12.2
2014	9	9	19	12	18	31	0	0	0	0	0	0	0	71.56	0	0	12.2
2014	9	9	19	22	18	31	0	0	0	0	0	0	0	71.38	0	0	12.2
2014	9	9	19	32	18	31	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	9	9	19	42	18	30	0	0	0	0	0	0	0	71.04	0	0	12.2
2014	9	9	19	52	18	32	0	0	0	0	0	0	0	70.83	0	0	12.2
2014	9	9	20	2	18	32	0	0	0	0	0	0	0	70.61	0	0	12.2
2014	9	9	20	12	18	31	0	0	0	0	0	0	0	70.41	0	0	12.2
2014	9	9	20	22	18	31	0	0	0	0	0	0	0	70.18	0	0	12
2014	9	9	20	32	18	31	0	0	0	0	0	0	0	69.94	0	0	12
2014	9	9	20	42	18	31	0	0	0	0	0	0	0	69.73	0	0	12
2014	9	9	20	52	18	32	0	0	0	0	0	0	0	69.49	0	0	12
2014	9	9	21	2	18	32	0	0	0	0	0	0	0	69.26	0	0	12
2014	9	9	21	12	18	32	0	0	0	0	0	0	0	69.04	0	0	12
2014	9	9	21	22	18	32	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	9	21	32	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	9	21	42	18	31	0	0	0	0	0	0	0	68.41	0	0	12
2014	9	9	21	52	18	31	0	0	0	0	0	0	0	68.22	0	0	12
2014	9	9	22	2	18	31	0	0	0	0	0	0	0	68.02	0	0	12
2014	9	9	22	12	18	32	0	0	0	0	0	0	0	67.84	0	0	12
2014	9	9	22	22	18	31	0	0	0	0	0	0	0	67.68	0	0	12
2014	9	9	22	32	18	32	0	0	0	0	0	0	0	67.48	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	22	42	18	32	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	9	22	52	18	32	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	9	23	2	18	32	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	9	23	12	18	32	0	0	0	0	0	0	0	66.9	0	0	12
2014	9	9	23	22	18	32	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	9	23	32	18	32	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	9	23	42	18	32	0	0	0	0	0	0	0	66.54	0	0	12
2014	9	9	23	52	18	32	0	0	0	0	0	0	0	66.42	0	0	12
2014	9	10	0	2	18	32	0	0	0	0	0	0	0	66.31	0	0	12
2014	9	10	0	12	18	31	0	0	0	0	0	0	0	66.22	0	0	12
2014	9	10	0	22	18	32	0	0	0	0	0	0	0	66.09	0	0	12
2014	9	10	0	32	18	32	0	0	0	0	0	0	0	66	0	0	12
2014	9	10	0	42	18	33	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	10	0	52	18	31	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	10	1	2	18	32	0	0	0	0	0	0	0	65.71	0	0	12
2014	9	10	1	12	18	32	0	0	0	0	0	0	0	65.62	0	0	12
2014	9	10	1	22	18	32	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	10	1	32	18	32	0	0	0	0	0	0	0	65.44	0	0	12
2014	9	10	1	42	18	32	0	0	0	0	0	0	0	65.35	0	0	12
2014	9	10	1	52	18	32	0	0	0	0	0	0	0	65.28	0	0	12
2014	9	10	2	2	18	31	0	0	0	0	0	0	0	65.19	0	0	12
2014	9	10	2	12	18	32	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	10	2	22	18	32	0	0	0	0	0	0	0	65.01	0	0	12
2014	9	10	2	32	18	32	0	0	0	0	0	0	0	64.94	0	0	12
2014	9	10	2	42	18	32	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	10	2	52	18	32	0	0	0	0	0	0	0	64.78	0	0	12
2014	9	10	3	2	18	32	0	0	0	0	0	0	0	64.69	0	0	12
2014	9	10	3	12	18	32	0	0	0	0	0	0	0	64.6	0	0	12
2014	9	10	3	22	18	32	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	10	3	32	18	32	0	0	0	0	0	0	0	64.47	0	0	12
2014	9	10	3	42	18	32	0	0	0	0	0	0	0	64.38	0	0	12
2014	9	10	3	52	18	33	0	0	0	0	0	0	0	64.33	0	0	12
2014	9	10	4	2	18	31	0	0	0	0	0	0	0	64.26	0	0	12
2014	9	10	4	12	18	31	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	10	4	22	18	32	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	10	4	32	18	32	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	10	4	42	18	32	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	10	4	52	18	32	0	0	0	0	0	0	0	63.84	0	0	11.8
2014	9	10	5	2	18	32	0	0	0	0	0	0	0	63.75	0	0	11.8
2014	9	10	5	12	18	32	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	10	5	22	18	32	0	0	0	0	0	0	0	63.55	0	0	11.8
2014	9	10	5	32	18	32	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	10	5	42	18	32	0	0	0	0	0	0	0	63.37	0	0	11.8
2014	9	10	5	52	18	32	0	0	0	0	0	0	0	63.27	0	0	11.8
2014	9	10	6	2	18	32	0	0	0	0	0	0	0	63.18	0	0	11.8
2014	9	10	6	12	18	32	0	0	0	0	0	0	0	63.09	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	6	22	18	33	0	0	0	0	0	0	0	63.01	0	0	11.8
2014	9	10	6	32	18	32	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	10	6	42	18	32	0	0	0	0	0	0	0	62.83	0	0	11.8
2014	9	10	6	52	18	32	0	0	0	0	0	0	0	62.74	0	0	11.8
2014	9	10	7	2	18	32	0	0	0	0	0	0	0	62.64	0	0	11.8
2014	9	10	7	12	18	32	0	0	0	0	0	0	0	62.55	0	0	11.8
2014	9	10	7	22	18	32	0	0	0	0	0	0	0	62.44	0	0	11.8
2014	9	10	7	32	18	33	0	0	0	0	0	0	0	62.35	0	0	12.4
2014	9	10	7	42	18	32	0	0	0	0	0	0	0	62.26	0	0	12.8
2014	9	10	7	52	18	33	0	0	0	0	0	0	0	62.19	0	0	13
2014	9	10	8	2	18	33	0	0	0	0	0	0	0	62.11	0	0	13
2014	9	10	8	12	18	33	0	0	0	0	0	0	0	62.06	0	0	13.2
2014	9	10	8	22	18	34	0	0	0	0	0	0	0	62.02	0	0	13.2
2014	9	10	8	32	18	31	0	0	0	0	0	0	0	62.01	0	0	13.4
2014	9	10	8	42	18	32	0	0	0	0	0	0	0	61.99	0	0	13.4
2014	9	10	8	52	18	32	0	0	0	0	0	0	0	61.99	0	0	13.4
2014	9	10	9	2	18	32	0	0	0	0	0	0	0	62.01	0	0	13.4
2014	9	10	9	12	18	33	0	0	0	0	0	0	0	62.06	0	0	13.6
2014	9	10	9	22	18	32	0	0	0	0	0	0	0	62.44	0	0	13.6
2014	9	10	9	32	18	32	0	0	0	0	0	0	0	62.58	0	0	13.6
2014	9	10	9	42	18	32	0	0	0	0	0	0	0	62.67	0	0	13.6
2014	9	10	9	52	18	32	0	0	0	0	0	0	0	62.76	0	0	13.4
2014	9	10	10	2	18	33	0	0	0	0	0	0	0	62.87	0	0	13.4
2014	9	10	10	12	18	31	0	0	0	0	0	0	0	63	0	0	13.4
2014	9	10	10	22	18	32	0	0	0	0	0	0	0	63.12	0	0	13.4
2014	9	10	10	32	18	32	0	0	0	0	0	0	0	63.27	0	0	13.4
2014	9	10	10	42	18	33	0	0	0	0	0	0	0	63.18	0	0	13.4
2014	9	10	10	52	18	32	0	0	0	0	0	0	0	63.07	0	0	13.4
2014	9	10	11	2	18	32	0	0	0	0	0	0	0	63.21	0	0	13.4
2014	9	10	11	12	18	32	0	0	0	0	0	0	0	63.45	0	0	13.4
2014	9	10	11	22	18	32	0	0	0	0	0	0	0	63.66	0	0	13.2
2014	9	10	11	32	18	33	0	0	0	0	0	0	0	63.95	0	0	13.2
2014	9	10	11	42	18	32	0	0	0	0	0	0	0	64.31	0	0	13.2
2014	9	10	11	52	18	32	0	0	0	0	0	0	0	65.01	0	0	13.2
2014	9	10	12	2	18	32	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	10	12	12	18	32	0	0	0	0	0	0	0	65.71	0	0	13.2
2014	9	10	12	22	18	32	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	9	10	12	32	18	32	0	0	0	0	0	0	0	66.33	0	0	13.2
2014	9	10	12	42	18	32	0	0	0	0	0	0	0	66.69	0	0	13.2
2014	9	10	12	52	18	31	0	0	0	0	0	0	0	67.05	0	0	13.2
2014	9	10	13	2	18	31	0	0	0	0	0	0	0	67.37	0	0	13.2
2014	9	10	13	12	18	31	0	0	0	0	0	0	0	67.71	0	0	13.2
2014	9	10	13	22	18	32	0	0	0	0	0	0	0	68.07	0	0	13.2
2014	9	10	13	32	18	32	0	0	0	0	0	0	0	68.38	0	0	13.2
2014	9	10	13	42	18	32	0	0	0	0	0	0	0	68.7	0	0	13.2
2014	9	10	13	52	18	31	0	0	0	0	0	0	0	69.03	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	14	2	18	31	0	0	0	0	0	0	0	69.35	0	0	13.2
2014	9	10	14	12	18	31	0	0	0	0	0	0	0	69.64	0	0	13.2
2014	9	10	14	22	18	31	0	0	0	0	0	0	0	69.94	0	0	13.2
2014	9	10	14	32	18	32	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	9	10	14	42	18	32	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	9	10	14	52	18	31	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	9	10	15	2	18	31	0	0	0	0	0	0	0	71.06	0	0	13.2
2014	9	10	15	12	18	31	0	0	0	0	0	0	0	71.29	0	0	13.2
2014	9	10	15	22	18	31	0	0	0	0	0	0	0	71.51	0	0	13.2
2014	9	10	15	32	18	31	0	0	0	0	0	0	0	71.74	0	0	13.2
2014	9	10	15	42	18	32	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	9	10	15	52	18	31	0	0	0	0	0	0	0	72.12	0	0	13.2
2014	9	10	16	2	18	31	0	0	0	0	0	0	0	72.27	0	0	13
2014	9	10	16	12	18	31	0	0	0	0	0	0	0	72.43	0	0	13
2014	9	10	16	22	18	31	0	0	0	0	0	0	0	72.55	0	0	12.6
2014	9	10	16	32	18	31	0	0	0	0	0	0	0	72.66	0	0	12.6
2014	9	10	16	42	18	31	0	0	0	0	0	0	0	72.75	0	0	12.6
2014	9	10	16	52	18	31	0	0	0	0	0	0	0	72.82	0	0	12.4
2014	9	10	17	2	18	30	0	0	0	0	0	0	0	72.9	0	0	12.4
2014	9	10	17	12	18	31	0	0	0	0	0	0	0	72.93	0	0	12.4
2014	9	10	17	22	18	32	0	0	0	0	0	0	0	72.93	0	0	12.2
2014	9	10	17	32	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2
2014	9	10	17	42	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2
2014	9	10	17	52	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2
2014	9	10	18	2	18	30	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	9	10	18	12	18	31	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	9	10	18	22	18	31	0	0	0	0	0	0	0	72.79	0	0	12.2
2014	9	10	18	32	18	30	0	0	0	0	0	0	0	72.7	0	0	12.2
2014	9	10	18	42	18	31	0	0	0	0	0	0	0	72.61	0	0	12.2
2014	9	10	18	52	18	30	0	0	0	0	0	0	0	72.5	0	0	12.2
2014	9	10	19	2	18	31	0	0	0	0	0	0	0	72.37	0	0	12.2
2014	9	10	19	12	18	32	0	0	0	0	0	0	0	72.25	0	0	12.2
2014	9	10	19	22	18	32	0	0	0	0	0	0	0	72.07	0	0	12
2014	9	10	19	32	18	31	0	0	0	0	0	0	0	71.94	0	0	12.2
2014	9	10	19	42	18	31	0	0	0	0	0	0	0	71.76	0	0	12.2
2014	9	10	19	52	18	31	0	0	0	0	0	0	0	71.56	0	0	12.2
2014	9	10	20	2	18	32	0	0	0	0	0	0	0	71.37	0	0	12.2
2014	9	10	20	12	18	31	0	0	0	0	0	0	0	71.15	0	0	12
2014	9	10	20	22	18	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	9	10	20	32	18	32	0	0	0	0	0	0	0	70.72	0	0	12
2014	9	10	20	42	18	32	0	0	0	0	0	0	0	70.5	0	0	12
2014	9	10	20	52	18	32	0	0	0	0	0	0	0	70.27	0	0	12
2014	9	10	21	2	18	31	0	0	0	0	0	0	0	70.05	0	0	12
2014	9	10	21	12	18	31	0	0	0	0	0	0	0	69.84	0	0	12
2014	9	10	21	22	18	31	0	0	0	0	0	0	0	69.64	0	0	12
2014	9	10	21	32	18	31	0	0	0	0	0	0	0	69.44	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	21	42	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	10	21	52	18	32	0	0	0	0	0	0	0	69.06	0	0	12
2014	9	10	22	2	18	32	0	0	0	0	0	0	0	68.88	0	0	12
2014	9	10	22	12	18	31	0	0	0	0	0	0	0	68.68	0	0	12
2014	9	10	22	22	18	31	0	0	0	0	0	0	0	68.52	0	0	12
2014	9	10	22	32	18	32	0	0	0	0	0	0	0	68.36	0	0	12
2014	9	10	22	42	18	31	0	0	0	0	0	0	0	68.22	0	0	12
2014	9	10	22	52	18	31	0	0	0	0	0	0	0	68.07	0	0	12
2014	9	10	23	2	18	32	0	0	0	0	0	0	0	67.93	0	0	12
2014	9	10	23	12	18	32	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	10	23	22	18	31	0	0	0	0	0	0	0	67.66	0	0	12
2014	9	10	23	32	18	31	0	0	0	0	0	0	0	67.53	0	0	12
2014	9	10	23	42	18	32	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	10	23	52	18	32	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	11	0	2	18	32	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	11	0	12	18	31	0	0	0	0	0	0	0	67.1	0	0	12
2014	9	11	0	22	18	31	0	0	0	0	0	0	0	67.01	0	0	11.8
2014	9	11	0	32	18	32	0	0	0	0	0	0	0	66.9	0	0	12
2014	9	11	0	42	18	33	0	0	0	0	0	0	0	66.81	0	0	12
2014	9	11	0	52	18	32	0	0	0	0	0	0	0	66.7	0	0	12
2014	9	11	1	2	18	32	0	0	0	0	0	0	0	66.61	0	0	12
2014	9	11	1	12	18	32	0	0	0	0	0	0	0	66.51	0	0	12
2014	9	11	1	22	18	32	0	0	0	0	0	0	0	66.42	0	0	12
2014	9	11	1	32	18	32	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	11	1	42	18	32	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	11	1	52	18	31	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	11	2	2	18	32	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	11	2	12	18	32	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	11	2	22	18	31	0	0	0	0	0	0	0	65.86	0	0	12
2014	9	11	2	32	18	32	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	11	2	42	18	32	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	11	2	52	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	11	3	2	18	32	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	11	3	12	18	32	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	11	3	22	18	31	0	0	0	0	0	0	0	65.37	0	0	11.8
2014	9	11	3	32	18	32	0	0	0	0	0	0	0	65.3	0	0	12
2014	9	11	3	42	18	33	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	11	3	52	18	33	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	11	4	2	18	32	0	0	0	0	0	0	0	65.08	0	0	12
2014	9	11	4	12	18	32	0	0	0	0	0	0	0	65.01	0	0	12
2014	9	11	4	22	18	32	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	11	4	32	18	32	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	11	4	42	18	33	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	11	4	52	18	32	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	11	5	2	18	32	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	11	5	12	18	32	0	0	0	0	0	0	0	64.51	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	5	22	18	33	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	11	5	32	18	32	0	0	0	0	0	0	0	64.31	0	0	11.8
2014	9	11	5	42	18	31	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	11	5	52	18	32	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	11	6	2	18	32	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	11	6	12	18	32	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	11	6	22	18	33	0	0	0	0	0	0	0	63.86	0	0	11.8
2014	9	11	6	32	18	32	0	0	0	0	0	0	0	63.75	0	0	11.8
2014	9	11	6	42	18	32	0	0	0	0	0	0	0	63.68	0	0	11.8
2014	9	11	6	52	18	33	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	11	7	2	18	33	0	0	0	0	0	0	0	63.48	0	0	11.8
2014	9	11	7	12	18	33	0	0	0	0	0	0	0	63.39	0	0	11.8
2014	9	11	7	22	18	32	0	0	0	0	0	0	0	63.3	0	0	11.8
2014	9	11	7	32	18	33	0	0	0	0	0	0	0	63.23	0	0	12.4
2014	9	11	7	42	18	32	0	0	0	0	0	0	0	63.14	0	0	12.6
2014	9	11	7	52	18	32	0	0	0	0	0	0	0	63.07	0	0	12.8
2014	9	11	8	2	18	32	0	0	0	0	0	0	0	63.03	0	0	13
2014	9	11	8	12	18	32	0	0	0	0	0	0	0	62.98	0	0	13
2014	9	11	8	22	18	32	0	0	0	0	0	0	0	62.94	0	0	13
2014	9	11	8	32	18	32	0	0	0	0	0	0	0	62.94	0	0	13.2
2014	9	11	8	42	18	32	0	0	0	0	0	0	0	62.94	0	0	13.2
2014	9	11	8	52	18	32	0	0	0	0	0	0	0	62.92	0	0	13.4
2014	9	11	9	2	18	32	0	0	0	0	0	0	0	62.96	0	0	13.4
2014	9	11	9	12	18	32	0	0	0	0	0	0	0	63	0	0	13.4
2014	9	11	9	22	18	32	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	11	9	32	18	33	0	0	0	0	0	0	0	63.64	0	0	13.6
2014	9	11	9	42	18	32	0	0	0	0	0	0	0	63.72	0	0	13.4
2014	9	11	9	52	18	33	0	0	0	0	0	0	0	63.82	0	0	13.4
2014	9	11	10	2	18	33	0	0	0	0	0	0	0	63.95	0	0	13.4
2014	9	11	10	12	18	32	0	0	0	0	0	0	0	64.04	0	0	13.4
2014	9	11	10	22	18	32	0	0	0	0	0	0	0	64.18	0	0	13.4
2014	9	11	10	32	18	31	0	0	0	0	0	0	0	64.33	0	0	13.4
2014	9	11	10	42	18	32	0	0	0	0	0	0	0	64.08	0	0	13.4
2014	9	11	10	52	18	32	0	0	0	0	0	0	0	64	0	0	13.4
2014	9	11	11	2	18	31	0	0	0	0	0	0	0	64.15	0	0	13.4
2014	9	11	11	12	18	32	0	0	0	0	0	0	0	64.33	0	0	13.2
2014	9	11	11	22	18	32	0	0	0	0	0	0	0	64.54	0	0	13.2
2014	9	11	11	32	18	33	0	0	0	0	0	0	0	64.78	0	0	13.2
2014	9	11	11	42	18	33	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	11	11	52	18	32	0	0	0	0	0	0	0	65.97	0	0	13.2
2014	9	11	12	2	18	32	0	0	0	0	0	0	0	66.31	0	0	13.2
2014	9	11	12	12	18	32	0	0	0	0	0	0	0	66.6	0	0	13.2
2014	9	11	12	22	18	32	0	0	0	0	0	0	0	66.9	0	0	13.2
2014	9	11	12	32	18	32	0	0	0	0	0	0	0	67.21	0	0	13.2
2014	9	11	12	42	18	32	0	0	0	0	0	0	0	67.5	0	0	13.2
2014	9	11	12	52	18	32	0	0	0	0	0	0	0	67.84	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	13	2	18	32	0	0	0	0	0	0	0	68.14	0	0	13.2
2014	9	11	13	12	18	32	0	0	0	0	0	0	0	68.47	0	0	13.2
2014	9	11	13	22	18	32	0	0	0	0	0	0	0	68.77	0	0	13.2
2014	9	11	13	32	18	32	0	0	0	0	0	0	0	69.1	0	0	13.2
2014	9	11	13	42	18	32	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	9	11	13	52	18	31	0	0	0	0	0	0	0	69.71	0	0	13.2
2014	9	11	14	2	18	31	0	0	0	0	0	0	0	70.03	0	0	13.2
2014	9	11	14	12	18	32	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	9	11	14	22	18	31	0	0	0	0	0	0	0	70.65	0	0	13
2014	9	11	14	32	18	31	0	0	0	0	0	0	0	70.93	0	0	13.2
2014	9	11	14	42	18	32	0	0	0	0	0	0	0	71.24	0	0	13.2
2014	9	11	14	52	18	32	0	0	0	0	0	0	0	71.53	0	0	13.2
2014	9	11	15	2	18	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	9	11	15	12	18	32	0	0	0	0	0	0	0	72.05	0	0	13.2
2014	9	11	15	22	18	31	0	0	0	0	0	0	0	72.3	0	0	13
2014	9	11	15	32	18	31	0	0	0	0	0	0	0	72.54	0	0	13.2
2014	9	11	15	42	18	30	0	0	0	0	0	0	0	72.73	0	0	13.2
2014	9	11	15	52	18	31	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	9	11	16	2	18	31	0	0	0	0	0	0	0	73.11	0	0	13
2014	9	11	16	12	18	30	0	0	0	0	0	0	0	73.26	0	0	13
2014	9	11	16	22	18	31	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	9	11	16	32	18	31	0	0	0	0	0	0	0	73.53	0	0	12.6
2014	9	11	16	42	18	30	0	0	0	0	0	0	0	73.62	0	0	12.6
2014	9	11	16	52	18	31	0	0	0	0	0	0	0	73.71	0	0	12.4
2014	9	11	17	2	18	31	0	0	0	0	0	0	0	73.78	0	0	12.4
2014	9	11	17	12	18	30	0	0	0	0	0	0	0	73.83	0	0	12.4
2014	9	11	17	22	18	31	0	0	0	0	0	0	0	73.85	0	0	12.2
2014	9	11	17	32	18	31	0	0	0	0	0	0	0	73.83	0	0	12.2
2014	9	11	17	42	18	30	0	0	0	0	0	0	0	73.83	0	0	12.2
2014	9	11	17	52	18	31	0	0	0	0	0	0	0	73.8	0	0	12.2
2014	9	11	18	2	18	31	0	0	0	0	0	0	0	73.76	0	0	12.2
2014	9	11	18	12	18	30	0	0	0	0	0	0	0	73.71	0	0	12.2
2014	9	11	18	22	18	31	0	0	0	0	0	0	0	73.62	0	0	12.2
2014	9	11	18	32	18	31	0	0	0	0	0	0	0	73.53	0	0	12.2
2014	9	11	18	42	18	30	0	0	0	0	0	0	0	73.4	0	0	12.2
2014	9	11	18	52	18	31	0	0	0	0	0	0	0	73.27	0	0	12.2
2014	9	11	19	2	18	30	0	0	0	0	0	0	0	73.13	0	0	12.2
2014	9	11	19	12	18	31	0	0	0	0	0	0	0	72.97	0	0	12.2
2014	9	11	19	22	18	31	0	0	0	0	0	0	0	72.81	0	0	12
2014	9	11	19	32	18	31	0	0	0	0	0	0	0	72.63	0	0	12.2
2014	9	11	19	42	18	31	0	0	0	0	0	0	0	72.45	0	0	12.2
2014	9	11	19	52	18	30	0	0	0	0	0	0	0	72.23	0	0	12.2
2014	9	11	20	2	18	30	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	9	11	20	12	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	9	11	20	22	18	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	9	11	20	32	18	30	0	0	0	0	0	0	0	71.28	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	20	42	18	31	0	0	0	0	0	0	0	71.02	0	0	12
2014	9	11	20	52	18	31	0	0	0	0	0	0	0	70.75	0	0	12
2014	9	11	21	2	18	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	9	11	21	12	18	31	0	0	0	0	0	0	0	70.27	0	0	12
2014	9	11	21	22	18	31	0	0	0	0	0	0	0	70.03	0	0	12
2014	9	11	21	32	18	31	0	0	0	0	0	0	0	69.82	0	0	12
2014	9	11	21	42	18	31	0	0	0	0	0	0	0	69.6	0	0	12
2014	9	11	21	52	18	31	0	0	0	0	0	0	0	69.4	0	0	12
2014	9	11	22	2	18	32	0	0	0	0	0	0	0	69.21	0	0	12
2014	9	11	22	12	18	31	0	0	0	0	0	0	0	69.03	0	0	12
2014	9	11	22	22	18	31	0	0	0	0	0	0	0	68.85	0	0	12
2014	9	11	22	32	18	31	0	0	0	0	0	0	0	68.7	0	0	12
2014	9	11	22	42	18	32	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	11	22	52	18	32	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	11	23	2	18	31	0	0	0	0	0	0	0	68.27	0	0	12
2014	9	11	23	12	18	32	0	0	0	0	0	0	0	68.13	0	0	12
2014	9	11	23	22	18	31	0	0	0	0	0	0	0	68.02	0	0	11.8
2014	9	11	23	32	18	31	0	0	0	0	0	0	0	67.91	0	0	12
2014	9	11	23	42	18	31	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	11	23	52	18	31	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	12	0	2	18	32	0	0	0	0	0	0	0	67.62	0	0	12
2014	9	12	0	12	18	32	0	0	0	0	0	0	0	67.53	0	0	12
2014	9	12	0	22	18	31	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	12	0	32	18	32	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	12	0	42	18	32	0	0	0	0	0	0	0	67.28	0	0	12
2014	9	12	0	52	18	33	0	0	0	0	0	0	0	67.19	0	0	12
2014	9	12	1	2	18	32	0	0	0	0	0	0	0	67.12	0	0	12
2014	9	12	1	12	18	32	0	0	0	0	0	0	0	67.05	0	0	12
2014	9	12	1	22	18	31	0	0	0	0	0	0	0	66.97	0	0	11.8
2014	9	12	1	32	18	31	0	0	0	0	0	0	0	66.88	0	0	12
2014	9	12	1	42	18	32	0	0	0	0	0	0	0	66.81	0	0	12
2014	9	12	1	52	18	31	0	0	0	0	0	0	0	66.74	0	0	12
2014	9	12	2	2	18	32	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	12	2	12	18	32	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	12	2	22	18	33	0	0	0	0	0	0	0	66.49	0	0	11.8
2014	9	12	2	32	18	32	0	0	0	0	0	0	0	66.42	0	0	12
2014	9	12	2	42	18	32	0	0	0	0	0	0	0	66.34	0	0	12
2014	9	12	2	52	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	12	3	2	18	32	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	12	3	12	18	32	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	12	3	22	18	32	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	12	3	32	18	32	0	0	0	0	0	0	0	66	0	0	12
2014	9	12	3	42	18	31	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	12	3	52	18	32	0	0	0	0	0	0	0	65.86	0	0	12
2014	9	12	4	2	18	31	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	12	4	12	18	32	0	0	0	0	0	0	0	65.66	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	4	22	18	32	0	0	0	0	0	0	0	65.59	0	0	11.8
2014	9	12	4	32	18	31	0	0	0	0	0	0	0	65.5	0	0	11.8
2014	9	12	4	42	18	32	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	12	4	52	18	32	0	0	0	0	0	0	0	65.32	0	0	11.8
2014	9	12	5	2	18	32	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	12	5	12	18	32	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	12	5	22	18	32	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	12	5	32	18	31	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	12	5	42	18	32	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	12	5	52	18	32	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	12	6	2	18	32	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	12	6	12	18	32	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	12	6	22	18	32	0	0	0	0	0	0	0	64.35	0	0	11.8
2014	9	12	6	32	18	32	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	12	6	42	18	32	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	12	6	52	18	31	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	12	7	2	18	33	0	0	0	0	0	0	0	63.9	0	0	11.8
2014	9	12	7	12	18	32	0	0	0	0	0	0	0	63.75	0	0	11.8
2014	9	12	7	22	18	32	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	12	7	32	18	33	0	0	0	0	0	0	0	63.5	0	0	12.4
2014	9	12	7	42	18	32	0	0	0	0	0	0	0	63.39	0	0	12.6
2014	9	12	7	52	18	32	0	0	0	0	0	0	0	63.28	0	0	12.8
2014	9	12	8	2	18	32	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	12	8	12	18	32	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	12	8	22	18	32	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	12	8	32	18	33	0	0	0	0	0	0	0	63.05	0	0	13.2
2014	9	12	8	42	18	32	0	0	0	0	0	0	0	63.01	0	0	13.2
2014	9	12	8	52	18	31	0	0	0	0	0	0	0	63	0	0	13.4
2014	9	12	9	2	18	32	0	0	0	0	0	0	0	63	0	0	13.4
2014	9	12	9	12	18	33	0	0	0	0	0	0	0	63.01	0	0	13.4
2014	9	12	9	22	18	32	0	0	0	0	0	0	0	63.45	0	0	13.4
2014	9	12	9	32	18	32	0	0	0	0	0	0	0	63.55	0	0	13.4
2014	9	12	9	42	18	32	0	0	0	0	0	0	0	63.64	0	0	13.4
2014	9	12	9	52	18	32	0	0	0	0	0	0	0	63.75	0	0	13.4
2014	9	12	10	2	18	32	0	0	0	0	0	0	0	63.84	0	0	13.4
2014	9	12	10	12	18	31	0	0	0	0	0	0	0	63.95	0	0	13.4
2014	9	12	10	22	18	32	0	0	0	0	0	0	0	64.09	0	0	13.2
2014	9	12	10	32	18	32	0	0	0	0	0	0	0	64.2	0	0	13.2
2014	9	12	10	42	18	33	0	0	0	0	0	0	0	63.93	0	0	13.2
2014	9	12	10	52	18	32	0	0	0	0	0	0	0	63.97	0	0	13.2
2014	9	12	11	2	18	32	0	0	0	0	0	0	0	64.13	0	0	13.2
2014	9	12	11	12	18	32	0	0	0	0	0	0	0	64.31	0	0	13.2
2014	9	12	11	22	18	33	0	0	0	0	0	0	0	64.51	0	0	13.2
2014	9	12	11	32	18	31	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	12	11	42	18	32	0	0	0	0	0	0	0	65.43	0	0	13.2
2014	9	12	11	52	18	31	0	0	0	0	0	0	0	65.86	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	12	2	18	32	0	0	0	0	0	0	0	66.16	0	0	13.2
2014	9	12	12	12	18	32	0	0	0	0	0	0	0	66.45	0	0	13.2
2014	9	12	12	22	18	32	0	0	0	0	0	0	0	66.74	0	0	13.2
2014	9	12	12	32	18	32	0	0	0	0	0	0	0	67.06	0	0	13.2
2014	9	12	12	42	18	31	0	0	0	0	0	0	0	67.33	0	0	13.2
2014	9	12	12	52	18	32	0	0	0	0	0	0	0	67.66	0	0	13.2
2014	9	12	13	2	18	32	0	0	0	0	0	0	0	67.96	0	0	13.2
2014	9	12	13	12	18	31	0	0	0	0	0	0	0	68.27	0	0	13.2
2014	9	12	13	22	18	32	0	0	0	0	0	0	0	68.54	0	0	13
2014	9	12	13	32	18	32	0	0	0	0	0	0	0	68.83	0	0	13.2
2014	9	12	13	42	18	31	0	0	0	0	0	0	0	69.1	0	0	13.2
2014	9	12	13	52	18	31	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	9	12	14	2	18	31	0	0	0	0	0	0	0	69.66	0	0	13.2
2014	9	12	14	12	18	32	0	0	0	0	0	0	0	69.93	0	0	13.2
2014	9	12	14	22	18	32	0	0	0	0	0	0	0	70.2	0	0	13
2014	9	12	14	32	18	31	0	0	0	0	0	0	0	70.43	0	0	13.2
2014	9	12	14	42	18	31	0	0	0	0	0	0	0	70.68	0	0	13.2
2014	9	12	14	52	18	32	0	0	0	0	0	0	0	70.92	0	0	13.2
2014	9	12	15	2	18	31	0	0	0	0	0	0	0	71.13	0	0	13.2
2014	9	12	15	12	18	32	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	9	12	15	22	18	31	0	0	0	0	0	0	0	71.49	0	0	13
2014	9	12	15	32	18	31	0	0	0	0	0	0	0	71.67	0	0	13.2
2014	9	12	15	42	18	31	0	0	0	0	0	0	0	71.83	0	0	13.2
2014	9	12	15	52	18	31	0	0	0	0	0	0	0	71.96	0	0	13.2
2014	9	12	16	2	18	31	0	0	0	0	0	0	0	72.09	0	0	13
2014	9	12	16	12	18	31	0	0	0	0	0	0	0	72.18	0	0	13
2014	9	12	16	22	18	31	0	0	0	0	0	0	0	72.27	0	0	12.6
2014	9	12	16	32	18	31	0	0	0	0	0	0	0	72.34	0	0	12.6
2014	9	12	16	42	18	31	0	0	0	0	0	0	0	72.39	0	0	12.6
2014	9	12	16	52	18	31	0	0	0	0	0	0	0	72.43	0	0	12.4
2014	9	12	17	2	18	31	0	0	0	0	0	0	0	72.45	0	0	12.4
2014	9	12	17	12	18	31	0	0	0	0	0	0	0	72.45	0	0	12.4
2014	9	12	17	22	18	31	0	0	0	0	0	0	0	72.43	0	0	12.2
2014	9	12	17	32	18	31	0	0	0	0	0	0	0	72.36	0	0	12.2
2014	9	12	17	42	18	31	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	9	12	17	52	18	30	0	0	0	0	0	0	0	72.27	0	0	12.2
2014	9	12	18	2	18	31	0	0	0	0	0	0	0	72.21	0	0	12.2
2014	9	12	18	12	18	31	0	0	0	0	0	0	0	72.14	0	0	12.2
2014	9	12	18	22	18	31	0	0	0	0	0	0	0	72.05	0	0	12
2014	9	12	18	32	18	31	0	0	0	0	0	0	0	71.96	0	0	12.2
2014	9	12	18	42	18	31	0	0	0	0	0	0	0	71.85	0	0	12.2
2014	9	12	18	52	18	31	0	0	0	0	0	0	0	71.74	0	0	12.2
2014	9	12	19	2	18	31	0	0	0	0	0	0	0	71.62	0	0	12.2
2014	9	12	19	12	18	31	0	0	0	0	0	0	0	71.51	0	0	12.2
2014	9	12	19	22	18	31	0	0	0	0	0	0	0	71.37	0	0	12
2014	9	12	19	32	18	31	0	0	0	0	0	0	0	71.22	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	19	42	18	31	0	0	0	0	0	0	0	71.06	0	0	12.2
2014	9	12	19	52	18	31	0	0	0	0	0	0	0	70.9	0	0	12.2
2014	9	12	20	2	18	31	0	0	0	0	0	0	0	70.74	0	0	12.2
2014	9	12	20	12	18	31	0	0	0	0	0	0	0	70.54	0	0	12
2014	9	12	20	22	18	31	0	0	0	0	0	0	0	70.34	0	0	12
2014	9	12	20	32	18	31	0	0	0	0	0	0	0	70.16	0	0	12
2014	9	12	20	42	18	31	0	0	0	0	0	0	0	69.96	0	0	12
2014	9	12	20	52	18	30	0	0	0	0	0	0	0	69.76	0	0	12
2014	9	12	21	2	18	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	9	12	21	12	18	32	0	0	0	0	0	0	0	69.39	0	0	12
2014	9	12	21	22	18	31	0	0	0	0	0	0	0	69.21	0	0	12
2014	9	12	21	32	18	32	0	0	0	0	0	0	0	69.04	0	0	12
2014	9	12	21	42	18	31	0	0	0	0	0	0	0	68.88	0	0	12
2014	9	12	21	52	18	32	0	0	0	0	0	0	0	68.76	0	0	12
2014	9	12	22	2	18	32	0	0	0	0	0	0	0	68.61	0	0	12
2014	9	12	22	12	18	31	0	0	0	0	0	0	0	68.49	0	0	12
2014	9	12	22	22	18	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	12	22	32	18	32	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	12	22	42	18	31	0	0	0	0	0	0	0	68.2	0	0	12
2014	9	12	22	52	18	32	0	0	0	0	0	0	0	68.11	0	0	12
2014	9	12	23	2	18	31	0	0	0	0	0	0	0	68.04	0	0	12
2014	9	12	23	12	18	31	0	0	0	0	0	0	0	67.95	0	0	12
2014	9	12	23	22	18	32	0	0	0	0	0	0	0	67.87	0	0	12
2014	9	12	23	32	18	31	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	12	23	42	18	31	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	12	23	52	18	32	0	0	0	0	0	0	0	67.64	0	0	12
2014	9	13	0	2	18	32	0	0	0	0	0	0	0	67.57	0	0	12
2014	9	13	0	12	18	32	0	0	0	0	0	0	0	67.5	0	0	12
2014	9	13	0	22	18	32	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	13	0	32	18	33	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	13	0	42	18	32	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	13	0	52	18	33	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	13	1	2	18	32	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	13	1	12	18	32	0	0	0	0	0	0	0	67.12	0	0	12
2014	9	13	1	22	18	31	0	0	0	0	0	0	0	67.05	0	0	12
2014	9	13	1	32	18	31	0	0	0	0	0	0	0	66.97	0	0	12
2014	9	13	1	42	18	31	0	0	0	0	0	0	0	66.9	0	0	12
2014	9	13	1	52	18	32	0	0	0	0	0	0	0	66.83	0	0	12
2014	9	13	2	2	18	32	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	13	2	12	18	31	0	0	0	0	0	0	0	66.67	0	0	12
2014	9	13	2	22	18	32	0	0	0	0	0	0	0	66.6	0	0	11.8
2014	9	13	2	32	18	32	0	0	0	0	0	0	0	66.51	0	0	12
2014	9	13	2	42	18	31	0	0	0	0	0	0	0	66.42	0	0	12
2014	9	13	2	52	18	32	0	0	0	0	0	0	0	66.36	0	0	12
2014	9	13	3	2	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	13	3	12	18	31	0	0	0	0	0	0	0	66.18	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	3	22	18	32	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	13	3	32	18	32	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	13	3	42	18	31	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	13	3	52	18	32	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	13	4	2	18	32	0	0	0	0	0	0	0	65.75	0	0	12
2014	9	13	4	12	18	32	0	0	0	0	0	0	0	65.64	0	0	12
2014	9	13	4	22	18	32	0	0	0	0	0	0	0	65.55	0	0	11.8
2014	9	13	4	32	18	32	0	0	0	0	0	0	0	65.44	0	0	12
2014	9	13	4	42	18	32	0	0	0	0	0	0	0	65.34	0	0	12
2014	9	13	4	52	18	32	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	13	5	2	18	32	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	13	5	12	18	32	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	13	5	22	18	32	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	13	5	32	18	32	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	13	5	42	18	32	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	13	5	52	18	32	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	13	6	2	18	32	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	13	6	12	18	33	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	13	6	22	18	32	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	13	6	32	18	33	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	13	6	42	18	32	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	13	6	52	18	32	0	0	0	0	0	0	0	63.91	0	0	11.8
2014	9	13	7	2	18	32	0	0	0	0	0	0	0	63.81	0	0	11.8
2014	9	13	7	12	18	32	0	0	0	0	0	0	0	63.7	0	0	12
2014	9	13	7	22	18	32	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	13	7	32	18	32	0	0	0	0	0	0	0	63.5	0	0	12.4
2014	9	13	7	42	18	32	0	0	0	0	0	0	0	63.43	0	0	12.6
2014	9	13	7	52	18	32	0	0	0	0	0	0	0	63.34	0	0	12.8
2014	9	13	8	2	18	32	0	0	0	0	0	0	0	63.28	0	0	13
2014	9	13	8	12	18	32	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	13	8	22	18	32	0	0	0	0	0	0	0	63.18	0	0	13
2014	9	13	8	32	18	32	0	0	0	0	0	0	0	63.16	0	0	13.2
2014	9	13	8	42	18	32	0	0	0	0	0	0	0	63.14	0	0	13.2
2014	9	13	8	52	18	32	0	0	0	0	0	0	0	63.12	0	0	13.4
2014	9	13	9	2	18	32	0	0	0	0	0	0	0	63.12	0	0	13.4
2014	9	13	9	12	18	32	0	0	0	0	0	0	0	63.14	0	0	13.4
2014	9	13	9	22	18	31	0	0	0	0	0	0	0	63.57	0	0	13.2
2014	9	13	9	32	18	33	0	0	0	0	0	0	0	63.75	0	0	13.4
2014	9	13	9	42	18	33	0	0	0	0	0	0	0	63.84	0	0	13.4
2014	9	13	9	52	18	32	0	0	0	0	0	0	0	63.95	0	0	13.4
2014	9	13	10	2	18	32	0	0	0	0	0	0	0	64.04	0	0	13.4
2014	9	13	10	12	18	32	0	0	0	0	0	0	0	64.2	0	0	13.4
2014	9	13	10	22	18	32	0	0	0	0	0	0	0	64.29	0	0	13.4
2014	9	13	10	32	18	32	0	0	0	0	0	0	0	64.42	0	0	13.4
2014	9	13	10	42	18	32	0	0	0	0	0	0	0	64.11	0	0	13.4
2014	9	13	10	52	18	33	0	0	0	0	0	0	0	64.17	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	11	2	18	32	0	0	0	0	0	0	0	64.33	0	0	13.4
2014	9	13	11	12	18	32	0	0	0	0	0	0	0	64.53	0	0	13.4
2014	9	13	11	22	18	32	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	13	11	32	18	32	0	0	0	0	0	0	0	64.99	0	0	13.2
2014	9	13	11	42	18	32	0	0	0	0	0	0	0	65.73	0	0	13.2
2014	9	13	11	52	18	32	0	0	0	0	0	0	0	66.13	0	0	13.2
2014	9	13	12	2	18	32	0	0	0	0	0	0	0	66.51	0	0	13.2
2014	9	13	12	12	18	32	0	0	0	0	0	0	0	66.79	0	0	13.2
2014	9	13	12	22	18	32	0	0	0	0	0	0	0	67.01	0	0	13.2
2014	9	13	12	32	18	32	0	0	0	0	0	0	0	67.41	0	0	13.2
2014	9	13	12	42	18	32	0	0	0	0	0	0	0	67.64	0	0	13.2
2014	9	13	12	52	18	32	0	0	0	0	0	0	0	67.82	0	0	13.2
2014	9	13	13	2	18	31	0	0	0	0	0	0	0	67.93	0	0	13
2014	9	13	13	12	18	31	0	0	0	0	0	0	0	68.07	0	0	13
2014	9	13	13	22	18	32	0	0	0	0	0	0	0	68.5	0	0	13.2
2014	9	13	13	32	18	32	0	0	0	0	0	0	0	68.74	0	0	13.2
2014	9	13	13	42	18	31	0	0	0	0	0	0	0	69.01	0	0	13.2
2014	9	13	13	52	18	31	0	0	0	0	0	0	0	69.15	0	0	13.2
2014	9	13	14	2	18	32	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	9	13	14	12	18	31	0	0	0	0	0	0	0	69.51	0	0	13
2014	9	13	14	22	18	32	0	0	0	0	0	0	0	69.78	0	0	12.8
2014	9	13	14	32	18	32	0	0	0	0	0	0	0	69.98	0	0	12.8
2014	9	13	14	42	18	31	0	0	0	0	0	0	0	70.27	0	0	13.2
2014	9	13	14	52	18	32	0	0	0	0	0	0	0	70.3	0	0	12.8
2014	9	13	15	2	18	31	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	9	13	15	12	18	31	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	9	13	15	22	18	31	0	0	0	0	0	0	0	70.95	0	0	13
2014	9	13	15	32	18	32	0	0	0	0	0	0	0	71.08	0	0	13.2
2014	9	13	15	42	18	31	0	0	0	0	0	0	0	71.22	0	0	13.2
2014	9	13	15	52	18	31	0	0	0	0	0	0	0	71.37	0	0	13.2
2014	9	13	16	2	18	31	0	0	0	0	0	0	0	71.38	0	0	12.6
2014	9	13	16	12	18	32	0	0	0	0	0	0	0	71.47	0	0	12.6
2014	9	13	16	22	18	31	0	0	0	0	0	0	0	71.49	0	0	12.4
2014	9	13	16	32	18	31	0	0	0	0	0	0	0	71.6	0	0	12.6
2014	9	13	16	42	18	31	0	0	0	0	0	0	0	71.55	0	0	12.4
2014	9	13	16	52	18	31	0	0	0	0	0	0	0	71.58	0	0	12.4
2014	9	13	17	2	18	31	0	0	0	0	0	0	0	71.65	0	0	12.4
2014	9	13	17	12	18	31	0	0	0	0	0	0	0	71.64	0	0	12.4
2014	9	13	17	22	18	31	0	0	0	0	0	0	0	71.58	0	0	12.2
2014	9	13	17	32	18	32	0	0	0	0	0	0	0	71.55	0	0	12.2
2014	9	13	17	42	18	31	0	0	0	0	0	0	0	71.55	0	0	12.2
2014	9	13	17	52	18	32	0	0	0	0	0	0	0	71.53	0	0	12.2
2014	9	13	18	2	18	31	0	0	0	0	0	0	0	71.49	0	0	12.2
2014	9	13	18	12	18	32	0	0	0	0	0	0	0	71.46	0	0	12.2
2014	9	13	18	22	18	31	0	0	0	0	0	0	0	71.38	0	0	12
2014	9	13	18	32	18	31	0	0	0	0	0	0	0	71.31	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	18	42	18	31	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	9	13	18	52	18	31	0	0	0	0	0	0	0	71.11	0	0	12.2
2014	9	13	19	2	18	31	0	0	0	0	0	0	0	70.99	0	0	12.2
2014	9	13	19	12	18	31	0	0	0	0	0	0	0	70.88	0	0	12.2
2014	9	13	19	22	18	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	9	13	19	32	18	30	0	0	0	0	0	0	0	70.66	0	0	12.2
2014	9	13	19	42	18	31	0	0	0	0	0	0	0	70.54	0	0	12.2
2014	9	13	19	52	18	31	0	0	0	0	0	0	0	70.43	0	0	12.2
2014	9	13	20	2	18	31	0	0	0	0	0	0	0	70.29	0	0	12.2
2014	9	13	20	12	18	31	0	0	0	0	0	0	0	70.14	0	0	12.2
2014	9	13	20	22	18	31	0	0	0	0	0	0	0	70.02	0	0	12
2014	9	13	20	32	18	32	0	0	0	0	0	0	0	69.85	0	0	12
2014	9	13	20	42	18	31	0	0	0	0	0	0	0	69.71	0	0	12
2014	9	13	20	52	18	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	9	13	21	2	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	9	13	21	12	18	32	0	0	0	0	0	0	0	69.3	0	0	12
2014	9	13	21	22	18	31	0	0	0	0	0	0	0	69.17	0	0	12
2014	9	13	21	32	18	31	0	0	0	0	0	0	0	69.06	0	0	12
2014	9	13	21	42	18	31	0	0	0	0	0	0	0	68.94	0	0	12
2014	9	13	21	52	18	31	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	13	22	2	18	32	0	0	0	0	0	0	0	68.74	0	0	12
2014	9	13	22	12	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	13	22	22	18	31	0	0	0	0	0	0	0	68.52	0	0	12
2014	9	13	22	32	18	31	0	0	0	0	0	0	0	68.43	0	0	12
2014	9	13	22	42	18	32	0	0	0	0	0	0	0	68.34	0	0	12
2014	9	13	22	52	18	31	0	0	0	0	0	0	0	68.25	0	0	12
2014	9	13	23	2	18	32	0	0	0	0	0	0	0	68.18	0	0	12
2014	9	13	23	12	18	32	0	0	0	0	0	0	0	68.09	0	0	12
2014	9	13	23	22	18	31	0	0	0	0	0	0	0	68.02	0	0	12
2014	9	13	23	32	18	32	0	0	0	0	0	0	0	67.93	0	0	12
2014	9	13	23	42	18	31	0	0	0	0	0	0	0	67.86	0	0	12
2014	9	13	23	52	18	31	0	0	0	0	0	0	0	67.78	0	0	12
2014	9	14	0	2	18	32	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	14	0	12	18	32	0	0	0	0	0	0	0	67.64	0	0	12
2014	9	14	0	22	18	31	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	14	0	32	18	31	0	0	0	0	0	0	0	67.5	0	0	12
2014	9	14	0	42	18	32	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	14	0	52	18	31	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	14	1	2	18	32	0	0	0	0	0	0	0	67.3	0	0	12
2014	9	14	1	12	18	31	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	14	1	22	18	31	0	0	0	0	0	0	0	67.15	0	0	11.8
2014	9	14	1	32	18	32	0	0	0	0	0	0	0	67.08	0	0	12
2014	9	14	1	42	18	32	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	14	1	52	18	31	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	14	2	2	18	32	0	0	0	0	0	0	0	66.88	0	0	12
2014	9	14	2	12	18	31	0	0	0	0	0	0	0	66.81	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	2	22	18	31	0	0	0	0	0	0	0	66.72	0	0	11.8
2014	9	14	2	32	18	31	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	14	2	42	18	32	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	14	2	52	18	32	0	0	0	0	0	0	0	66.49	0	0	12
2014	9	14	3	2	18	31	0	0	0	0	0	0	0	66.43	0	0	12
2014	9	14	3	12	18	32	0	0	0	0	0	0	0	66.36	0	0	12
2014	9	14	3	22	18	32	0	0	0	0	0	0	0	66.27	0	0	11.8
2014	9	14	3	32	18	32	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	14	3	42	18	32	0	0	0	0	0	0	0	66.11	0	0	12
2014	9	14	3	52	18	32	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	14	4	2	18	31	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	14	4	12	18	32	0	0	0	0	0	0	0	65.86	0	0	12
2014	9	14	4	22	18	32	0	0	0	0	0	0	0	65.77	0	0	11.8
2014	9	14	4	32	18	32	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	14	4	42	18	32	0	0	0	0	0	0	0	65.59	0	0	12
2014	9	14	4	52	18	31	0	0	0	0	0	0	0	65.52	0	0	12
2014	9	14	5	2	18	32	0	0	0	0	0	0	0	65.41	0	0	12
2014	9	14	5	12	18	32	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	14	5	22	18	32	0	0	0	0	0	0	0	65.23	0	0	11.8
2014	9	14	5	32	18	32	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	14	5	42	18	31	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	14	5	52	18	32	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	14	6	2	18	33	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	14	6	12	18	33	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	14	6	22	18	32	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	14	6	32	18	32	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	14	6	42	18	33	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	14	6	52	18	32	0	0	0	0	0	0	0	64.44	0	0	12
2014	9	14	7	2	18	32	0	0	0	0	0	0	0	64.36	0	0	12
2014	9	14	7	12	18	32	0	0	0	0	0	0	0	64.31	0	0	12
2014	9	14	7	22	18	32	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	14	7	32	18	32	0	0	0	0	0	0	0	64.2	0	0	12.4
2014	9	14	7	42	18	32	0	0	0	0	0	0	0	64.15	0	0	12.6
2014	9	14	7	52	18	32	0	0	0	0	0	0	0	64.09	0	0	12.8
2014	9	14	8	2	18	32	0	0	0	0	0	0	0	64.06	0	0	13
2014	9	14	8	12	18	32	0	0	0	0	0	0	0	64.06	0	0	12.8
2014	9	14	8	22	18	32	0	0	0	0	0	0	0	64.02	0	0	13.2
2014	9	14	8	32	18	32	0	0	0	0	0	0	0	63.99	0	0	13.2
2014	9	14	8	42	18	32	0	0	0	0	0	0	0	63.99	0	0	12.8
2014	9	14	8	52	18	32	0	0	0	0	0	0	0	63.95	0	0	12.8
2014	9	14	9	2	18	33	0	0	0	0	0	0	0	63.93	0	0	12.8
2014	9	14	9	12	18	32	0	0	0	0	0	0	0	63.91	0	0	13.4
2014	9	14	9	22	18	32	0	0	0	0	0	0	0	64.33	0	0	13.2
2014	9	14	9	32	18	32	0	0	0	0	0	0	0	64.54	0	0	13.4
2014	9	14	9	42	18	33	0	0	0	0	0	0	0	64.69	0	0	13.4
2014	9	14	9	52	18	32	0	0	0	0	0	0	0	64.35	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	10	2	18	32	0	0	0	0	0	0	0	64.65	0	0	13.2
2014	9	14	10	12	18	31	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	14	10	22	18	32	0	0	0	0	0	0	0	65.12	0	0	13.4
2014	9	14	10	32	18	32	0	0	0	0	0	0	0	65.3	0	0	13.4
2014	9	14	10	42	18	31	0	0	0	0	0	0	0	64.8	0	0	13.4
2014	9	14	10	52	18	32	0	0	0	0	0	0	0	64.87	0	0	13.4
2014	9	14	11	2	18	32	0	0	0	0	0	0	0	65.03	0	0	13.4
2014	9	14	11	12	18	32	0	0	0	0	0	0	0	65.23	0	0	13.4
2014	9	14	11	22	18	33	0	0	0	0	0	0	0	65.48	0	0	13.2
2014	9	14	11	32	18	32	0	0	0	0	0	0	0	65.77	0	0	13.2
2014	9	14	11	42	18	32	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	14	11	52	18	31	0	0	0	0	0	0	0	66.88	0	0	13.2
2014	9	14	12	2	18	32	0	0	0	0	0	0	0	67.19	0	0	13.2
2014	9	14	12	12	18	32	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	14	12	22	18	32	0	0	0	0	0	0	0	67.73	0	0	13.2
2014	9	14	12	32	18	32	0	0	0	0	0	0	0	67.59	0	0	12.8
2014	9	14	12	42	18	32	0	0	0	0	0	0	0	67.78	0	0	12.8
2014	9	14	12	52	18	31	0	0	0	0	0	0	0	67.98	0	0	12.8
2014	9	14	13	2	18	32	0	0	0	0	0	0	0	68.13	0	0	12.8
2014	9	14	13	12	18	32	0	0	0	0	0	0	0	68.23	0	0	12.8
2014	9	14	13	22	18	32	0	0	0	0	0	0	0	68.43	0	0	12.8
2014	9	14	13	32	18	31	0	0	0	0	0	0	0	68.67	0	0	13
2014	9	14	13	42	18	32	0	0	0	0	0	0	0	68.67	0	0	12.6
2014	9	14	13	52	18	31	0	0	0	0	0	0	0	68.83	0	0	12.8
2014	9	14	14	2	18	32	0	0	0	0	0	0	0	69.39	0	0	13.4
2014	9	14	14	12	18	31	0	0	0	0	0	0	0	69.48	0	0	12.8
2014	9	14	14	22	18	32	0	0	0	0	0	0	0	69.82	0	0	13.2
2014	9	14	14	32	18	32	0	0	0	0	0	0	0	70.23	0	0	13.2
2014	9	14	14	42	18	31	0	0	0	0	0	0	0	70.3	0	0	12.8
2014	9	14	14	52	18	31	0	0	0	0	0	0	0	70.54	0	0	13
2014	9	14	15	2	18	32	0	0	0	0	0	0	0	70.68	0	0	12.6
2014	9	14	15	12	18	32	0	0	0	0	0	0	0	70.75	0	0	12.6
2014	9	14	15	22	18	32	0	0	0	0	0	0	0	70.88	0	0	12.6
2014	9	14	15	32	18	31	0	0	0	0	0	0	0	71.06	0	0	13
2014	9	14	15	42	18	31	0	0	0	0	0	0	0	71.17	0	0	13
2014	9	14	15	52	18	31	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	9	14	16	2	18	31	0	0	0	0	0	0	0	71.37	0	0	13.2
2014	9	14	16	12	18	30	0	0	0	0	0	0	0	71.4	0	0	12.8
2014	9	14	16	22	18	32	0	0	0	0	0	0	0	71.26	0	0	12.2
2014	9	14	16	32	18	32	0	0	0	0	0	0	0	71.28	0	0	12.4
2014	9	14	16	42	18	31	0	0	0	0	0	0	0	71.28	0	0	12.2
2014	9	14	16	52	18	31	0	0	0	0	0	0	0	71.29	0	0	12.4
2014	9	14	17	2	18	30	0	0	0	0	0	0	0	71.31	0	0	12.2
2014	9	14	17	12	18	31	0	0	0	0	0	0	0	71.26	0	0	12.2
2014	9	14	17	22	18	31	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	9	14	17	32	18	31	0	0	0	0	0	0	0	71.19	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	17	42	18	31	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	9	14	17	52	18	32	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	9	14	18	2	18	31	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	9	14	18	12	18	32	0	0	0	0	0	0	0	71.11	0	0	12.2
2014	9	14	18	22	18	31	0	0	0	0	0	0	0	71.08	0	0	12
2014	9	14	18	32	18	31	0	0	0	0	0	0	0	71.04	0	0	12.2
2014	9	14	18	42	18	31	0	0	0	0	0	0	0	70.95	0	0	12.2
2014	9	14	18	52	18	31	0	0	0	0	0	0	0	70.86	0	0	12.2
2014	9	14	19	2	18	31	0	0	0	0	0	0	0	70.75	0	0	12.2
2014	9	14	19	12	18	31	0	0	0	0	0	0	0	70.63	0	0	12.2
2014	9	14	19	22	18	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	9	14	19	32	18	32	0	0	0	0	0	0	0	70.34	0	0	12
2014	9	14	19	42	18	32	0	0	0	0	0	0	0	70.2	0	0	12
2014	9	14	19	52	18	31	0	0	0	0	0	0	0	70.03	0	0	12
2014	9	14	20	2	18	31	0	0	0	0	0	0	0	69.89	0	0	12
2014	9	14	20	12	18	32	0	0	0	0	0	0	0	69.75	0	0	12
2014	9	14	20	22	18	31	0	0	0	0	0	0	0	69.62	0	0	12
2014	9	14	20	32	18	32	0	0	0	0	0	0	0	69.48	0	0	12
2014	9	14	20	42	18	32	0	0	0	0	0	0	0	69.35	0	0	12
2014	9	14	20	52	18	31	0	0	0	0	0	0	0	69.21	0	0	12
2014	9	14	21	2	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	9	14	21	12	18	31	0	0	0	0	0	0	0	68.97	0	0	12
2014	9	14	21	22	18	32	0	0	0	0	0	0	0	68.86	0	0	12
2014	9	14	21	32	18	31	0	0	0	0	0	0	0	68.76	0	0	12
2014	9	14	21	42	18	31	0	0	0	0	0	0	0	68.65	0	0	12
2014	9	14	21	52	18	32	0	0	0	0	0	0	0	68.56	0	0	12
2014	9	14	22	2	18	32	0	0	0	0	0	0	0	68.47	0	0	12
2014	9	14	22	12	18	32	0	0	0	0	0	0	0	68.38	0	0	12
2014	9	14	22	22	18	32	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	14	22	32	18	31	0	0	0	0	0	0	0	68.2	0	0	12
2014	9	14	22	42	18	31	0	0	0	0	0	0	0	68.13	0	0	12
2014	9	14	22	52	18	31	0	0	0	0	0	0	0	68.04	0	0	12
2014	9	14	23	2	18	31	0	0	0	0	0	0	0	67.96	0	0	12
2014	9	14	23	12	18	31	0	0	0	0	0	0	0	67.87	0	0	12
2014	9	14	23	22	18	31	0	0	0	0	0	0	0	67.8	0	0	11.8
2014	9	14	23	32	18	32	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	14	23	42	18	32	0	0	0	0	0	0	0	67.64	0	0	12
2014	9	14	23	52	18	31	0	0	0	0	0	0	0	67.55	0	0	12
2014	9	15	0	2	18	32	0	0	0	0	0	0	0	67.48	0	0	12
2014	9	15	0	12	18	32	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	15	0	22	18	31	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	15	0	32	18	33	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	15	0	42	18	31	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	15	0	52	18	31	0	0	0	0	0	0	0	67.1	0	0	12
2014	9	15	1	2	18	32	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	15	1	12	18	32	0	0	0	0	0	0	0	66.96	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	1	22	18	32	0	0	0	0	0	0	0	66.9	0	0	11.8
2014	9	15	1	32	18	32	0	0	0	0	0	0	0	66.83	0	0	12
2014	9	15	1	42	18	31	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	15	1	52	18	32	0	0	0	0	0	0	0	66.7	0	0	12
2014	9	15	2	2	18	32	0	0	0	0	0	0	0	66.63	0	0	12
2014	9	15	2	12	18	32	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	15	2	22	18	32	0	0	0	0	0	0	0	66.51	0	0	11.8
2014	9	15	2	32	18	32	0	0	0	0	0	0	0	66.43	0	0	12
2014	9	15	2	42	18	31	0	0	0	0	0	0	0	66.36	0	0	12
2014	9	15	2	52	18	31	0	0	0	0	0	0	0	66.29	0	0	12
2014	9	15	3	2	18	32	0	0	0	0	0	0	0	66.22	0	0	12
2014	9	15	3	12	18	32	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	15	3	22	18	31	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	15	3	32	18	32	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	15	3	42	18	32	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	15	3	52	18	32	0	0	0	0	0	0	0	65.82	0	0	11.8
2014	9	15	4	2	18	32	0	0	0	0	0	0	0	65.75	0	0	11.8
2014	9	15	4	12	18	31	0	0	0	0	0	0	0	65.66	0	0	11.8
2014	9	15	4	22	18	32	0	0	0	0	0	0	0	65.59	0	0	11.8
2014	9	15	4	32	18	32	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	15	4	42	18	32	0	0	0	0	0	0	0	65.43	0	0	11.8
2014	9	15	4	52	18	32	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	15	5	2	18	32	0	0	0	0	0	0	0	65.25	0	0	11.8
2014	9	15	5	12	18	32	0	0	0	0	0	0	0	65.17	0	0	11.8
2014	9	15	5	22	18	32	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	15	5	32	18	32	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	15	5	42	18	32	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	15	5	52	18	32	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	15	6	2	18	32	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	15	6	12	18	33	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	15	6	22	18	32	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	15	6	32	18	32	0	0	0	0	0	0	0	64.38	0	0	11.8
2014	9	15	6	42	18	32	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	15	6	52	18	32	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	15	7	2	18	33	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	15	7	12	18	33	0	0	0	0	0	0	0	64	0	0	11.8
2014	9	15	7	22	18	32	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	15	7	32	18	32	0	0	0	0	0	0	0	63.84	0	0	12.2
2014	9	15	7	42	18	32	0	0	0	0	0	0	0	63.77	0	0	12.6
2014	9	15	7	52	18	32	0	0	0	0	0	0	0	63.72	0	0	12.8
2014	9	15	8	2	18	32	0	0	0	0	0	0	0	63.66	0	0	13
2014	9	15	8	12	18	32	0	0	0	0	0	0	0	63.64	0	0	13
2014	9	15	8	22	18	33	0	0	0	0	0	0	0	63.63	0	0	13
2014	9	15	8	32	18	32	0	0	0	0	0	0	0	63.63	0	0	13.2
2014	9	15	8	42	18	33	0	0	0	0	0	0	0	63.63	0	0	13.2
2014	9	15	8	52	18	33	0	0	0	0	0	0	0	63.63	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	9	2	18	33	0	0	0	0	0	0	0	63.66	0	0	13.4
2014	9	15	9	12	18	33	0	0	0	0	0	0	0	63.68	0	0	13.4
2014	9	15	9	22	18	33	0	0	0	0	0	0	0	64.04	0	0	13.4
2014	9	15	9	32	18	32	0	0	0	0	0	0	0	64.38	0	0	13.4
2014	9	15	9	42	18	32	0	0	0	0	0	0	0	64.53	0	0	13.4
2014	9	15	9	52	18	32	0	0	0	0	0	0	0	64.65	0	0	13.4
2014	9	15	10	2	18	32	0	0	0	0	0	0	0	64.78	0	0	13.4
2014	9	15	10	12	18	32	0	0	0	0	0	0	0	64.9	0	0	13.4
2014	9	15	10	22	18	32	0	0	0	0	0	0	0	65.01	0	0	13.2
2014	9	15	10	32	18	31	0	0	0	0	0	0	0	65.1	0	0	13.4
2014	9	15	10	42	18	33	0	0	0	0	0	0	0	64.67	0	0	13.4
2014	9	15	10	52	18	32	0	0	0	0	0	0	0	64.74	0	0	13.4
2014	9	15	11	2	18	32	0	0	0	0	0	0	0	64.92	0	0	13.4
2014	9	15	11	12	18	32	0	0	0	0	0	0	0	65.12	0	0	13.2
2014	9	15	11	22	18	33	0	0	0	0	0	0	0	65.34	0	0	13.2
2014	9	15	11	32	18	32	0	0	0	0	0	0	0	65.71	0	0	13.2
2014	9	15	11	42	18	32	0	0	0	0	0	0	0	66.52	0	0	13.2
2014	9	15	11	52	18	33	0	0	0	0	0	0	0	66.25	0	0	12.8
2014	9	15	12	2	18	32	0	0	0	0	0	0	0	67.15	0	0	13.2
2014	9	15	12	12	18	32	0	0	0	0	0	0	0	67.03	0	0	13.2
2014	9	15	12	22	18	31	0	0	0	0	0	0	0	67.57	0	0	13.2
2014	9	15	12	32	18	32	0	0	0	0	0	0	0	67.87	0	0	13.2
2014	9	15	12	42	18	31	0	0	0	0	0	0	0	68.18	0	0	13.2
2014	9	15	12	52	18	32	0	0	0	0	0	0	0	68.47	0	0	13.2
2014	9	15	13	2	18	31	0	0	0	0	0	0	0	68.77	0	0	13.2
2014	9	15	13	12	18	32	0	0	0	0	0	0	0	69.08	0	0	13.2
2014	9	15	13	22	18	32	0	0	0	0	0	0	0	69.35	0	0	13.2
2014	9	15	13	32	18	32	0	0	0	0	0	0	0	69.69	0	0	13.2
2014	9	15	13	42	18	31	0	0	0	0	0	0	0	70	0	0	13.2
2014	9	15	13	52	18	31	0	0	0	0	0	0	0	70.27	0	0	13.2
2014	9	15	14	2	18	31	0	0	0	0	0	0	0	70.56	0	0	13.2
2014	9	15	14	12	18	31	0	0	0	0	0	0	0	70.81	0	0	13.2
2014	9	15	14	22	18	31	0	0	0	0	0	0	0	71.06	0	0	13.2
2014	9	15	14	32	18	31	0	0	0	0	0	0	0	71.29	0	0	13.2
2014	9	15	14	42	18	31	0	0	0	0	0	0	0	71.53	0	0	13.2
2014	9	15	14	52	18	32	0	0	0	0	0	0	0	71.76	0	0	13.2
2014	9	15	15	2	18	32	0	0	0	0	0	0	0	71.96	0	0	13.2
2014	9	15	15	12	18	31	0	0	0	0	0	0	0	72.16	0	0	13.2
2014	9	15	15	22	18	31	0	0	0	0	0	0	0	72.37	0	0	13
2014	9	15	15	32	18	31	0	0	0	0	0	0	0	72.5	0	0	13
2014	9	15	15	42	18	30	0	0	0	0	0	0	0	72.59	0	0	12.8
2014	9	15	15	52	18	30	0	0	0	0	0	0	0	72.59	0	0	12.4
2014	9	15	16	2	18	30	0	0	0	0	0	0	0	72.7	0	0	12.4
2014	9	15	16	12	18	30	0	0	0	0	0	0	0	72.84	0	0	12.6
2014	9	15	16	22	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2
2014	9	15	16	32	18	31	0	0	0	0	0	0	0	72.9	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	16	42	18	31	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	9	15	16	52	18	31	0	0	0	0	0	0	0	73.02	0	0	12.4
2014	9	15	17	2	18	31	0	0	0	0	0	0	0	73	0	0	12.2
2014	9	15	17	12	18	31	0	0	0	0	0	0	0	73.06	0	0	12.2
2014	9	15	17	22	18	32	0	0	0	0	0	0	0	73.11	0	0	12.2
2014	9	15	17	32	18	31	0	0	0	0	0	0	0	73.09	0	0	12.2
2014	9	15	17	42	18	31	0	0	0	0	0	0	0	73.11	0	0	12.2
2014	9	15	17	52	18	31	0	0	0	0	0	0	0	73.11	0	0	12.2
2014	9	15	18	2	18	31	0	0	0	0	0	0	0	73.13	0	0	12.2
2014	9	15	18	12	18	32	0	0	0	0	0	0	0	73.09	0	0	12.2
2014	9	15	18	22	18	32	0	0	0	0	0	0	0	73.04	0	0	12
2014	9	15	18	32	18	30	0	0	0	0	0	0	0	72.99	0	0	12.2
2014	9	15	18	42	18	31	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	9	15	18	52	18	31	0	0	0	0	0	0	0	72.81	0	0	12.2
2014	9	15	19	2	18	31	0	0	0	0	0	0	0	72.7	0	0	12.2
2014	9	15	19	12	18	30	0	0	0	0	0	0	0	72.57	0	0	12.2
2014	9	15	19	22	18	30	0	0	0	0	0	0	0	72.43	0	0	12
2014	9	15	19	32	18	31	0	0	0	0	0	0	0	72.27	0	0	12.2
2014	9	15	19	42	18	31	0	0	0	0	0	0	0	72.12	0	0	12.2
2014	9	15	19	52	18	31	0	0	0	0	0	0	0	71.94	0	0	12.2
2014	9	15	20	2	18	31	0	0	0	0	0	0	0	71.8	0	0	12
2014	9	15	20	12	18	31	0	0	0	0	0	0	0	71.62	0	0	12
2014	9	15	20	22	18	31	0	0	0	0	0	0	0	71.44	0	0	12
2014	9	15	20	32	18	31	0	0	0	0	0	0	0	71.26	0	0	12
2014	9	15	20	42	18	31	0	0	0	0	0	0	0	71.08	0	0	12
2014	9	15	20	52	18	30	0	0	0	0	0	0	0	70.9	0	0	12
2014	9	15	21	2	18	31	0	0	0	0	0	0	0	70.72	0	0	12
2014	9	15	21	12	18	32	0	0	0	0	0	0	0	70.56	0	0	12
2014	9	15	21	22	18	32	0	0	0	0	0	0	0	70.38	0	0	12
2014	9	15	21	32	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	9	15	21	42	18	31	0	0	0	0	0	0	0	70.05	0	0	12
2014	9	15	21	52	18	32	0	0	0	0	0	0	0	69.91	0	0	12
2014	9	15	22	2	18	32	0	0	0	0	0	0	0	69.76	0	0	12
2014	9	15	22	12	18	30	0	0	0	0	0	0	0	69.62	0	0	12
2014	9	15	22	22	18	31	0	0	0	0	0	0	0	69.49	0	0	11.8
2014	9	15	22	32	18	31	0	0	0	0	0	0	0	69.37	0	0	12
2014	9	15	22	42	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	15	22	52	18	31	0	0	0	0	0	0	0	69.12	0	0	12
2014	9	15	23	2	18	32	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	15	23	12	18	31	0	0	0	0	0	0	0	68.9	0	0	12
2014	9	15	23	22	18	32	0	0	0	0	0	0	0	68.81	0	0	12
2014	9	15	23	32	18	32	0	0	0	0	0	0	0	68.72	0	0	12
2014	9	15	23	42	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	15	23	52	18	32	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	16	0	2	18	31	0	0	0	0	0	0	0	68.45	0	0	12
2014	9	16	0	12	18	31	0	0	0	0	0	0	0	68.38	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	0	22	18	31	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	16	0	32	18	32	0	0	0	0	0	0	0	68.23	0	0	12
2014	9	16	0	42	18	32	0	0	0	0	0	0	0	68.14	0	0	12
2014	9	16	0	52	18	32	0	0	0	0	0	0	0	68.07	0	0	12
2014	9	16	1	2	18	31	0	0	0	0	0	0	0	68.02	0	0	12
2014	9	16	1	12	18	31	0	0	0	0	0	0	0	67.95	0	0	12
2014	9	16	1	22	18	32	0	0	0	0	0	0	0	67.91	0	0	12
2014	9	16	1	32	18	32	0	0	0	0	0	0	0	67.84	0	0	12
2014	9	16	1	42	18	32	0	0	0	0	0	0	0	67.77	0	0	12
2014	9	16	1	52	18	32	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	16	2	2	18	32	0	0	0	0	0	0	0	67.66	0	0	12
2014	9	16	2	12	18	31	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	16	2	22	18	32	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	16	2	32	18	32	0	0	0	0	0	0	0	67.48	0	0	12
2014	9	16	2	42	18	32	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	16	2	52	18	32	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	16	3	2	18	32	0	0	0	0	0	0	0	67.3	0	0	12
2014	9	16	3	12	18	32	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	16	3	22	18	32	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	16	3	32	18	31	0	0	0	0	0	0	0	67.12	0	0	12
2014	9	16	3	42	18	31	0	0	0	0	0	0	0	67.06	0	0	12
2014	9	16	3	52	18	31	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	16	4	2	18	32	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	16	4	12	18	31	0	0	0	0	0	0	0	66.88	0	0	12
2014	9	16	4	22	18	31	0	0	0	0	0	0	0	66.83	0	0	11.8
2014	9	16	4	32	18	31	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	16	4	42	18	32	0	0	0	0	0	0	0	66.7	0	0	12
2014	9	16	4	52	18	32	0	0	0	0	0	0	0	66.63	0	0	12
2014	9	16	5	2	18	31	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	16	5	12	18	32	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	16	5	22	18	31	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	16	5	32	18	31	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	16	5	42	18	32	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	16	5	52	18	32	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	16	6	2	18	32	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	16	6	12	18	32	0	0	0	0	0	0	0	65.98	0	0	11.8
2014	9	16	6	22	18	31	0	0	0	0	0	0	0	65.91	0	0	11.8
2014	9	16	6	32	18	32	0	0	0	0	0	0	0	65.82	0	0	11.8
2014	9	16	6	42	18	32	0	0	0	0	0	0	0	65.75	0	0	11.8
2014	9	16	6	52	18	32	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	16	7	2	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	16	7	12	18	32	0	0	0	0	0	0	0	65.52	0	0	12
2014	9	16	7	22	18	33	0	0	0	0	0	0	0	65.44	0	0	11.8
2014	9	16	7	32	18	32	0	0	0	0	0	0	0	65.39	0	0	12.2
2014	9	16	7	42	18	32	0	0	0	0	0	0	0	65.3	0	0	12.6
2014	9	16	7	52	18	32	0	0	0	0	0	0	0	65.25	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	8	2	18	32	0	0	0	0	0	0	0	65.21	0	0	13
2014	9	16	8	12	18	31	0	0	0	0	0	0	0	65.17	0	0	13
2014	9	16	8	22	18	32	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	16	8	32	18	32	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	16	8	42	18	32	0	0	0	0	0	0	0	65.16	0	0	13.2
2014	9	16	8	52	18	32	0	0	0	0	0	0	0	65.16	0	0	13.2
2014	9	16	9	2	18	32	0	0	0	0	0	0	0	65.19	0	0	13.4
2014	9	16	9	12	18	32	0	0	0	0	0	0	0	65.23	0	0	13.4
2014	9	16	9	22	18	31	0	0	0	0	0	0	0	65.37	0	0	13.4
2014	9	16	9	32	18	32	0	0	0	0	0	0	0	65.97	0	0	13.4
2014	9	16	9	42	18	32	0	0	0	0	0	0	0	66.11	0	0	13.4
2014	9	16	9	52	18	32	0	0	0	0	0	0	0	66.27	0	0	13.4
2014	9	16	10	2	18	32	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	9	16	10	12	18	31	0	0	0	0	0	0	0	66.58	0	0	13.4
2014	9	16	10	22	18	32	0	0	0	0	0	0	0	66.7	0	0	13.4
2014	9	16	10	32	18	32	0	0	0	0	0	0	0	66.67	0	0	13.4
2014	9	16	10	42	18	32	0	0	0	0	0	0	0	66.24	0	0	13.4
2014	9	16	10	52	18	32	0	0	0	0	0	0	0	66.31	0	0	13.4
2014	9	16	11	2	18	32	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	9	16	11	12	18	32	0	0	0	0	0	0	0	66.63	0	0	13.4
2014	9	16	11	22	18	32	0	0	0	0	0	0	0	66.83	0	0	13.2
2014	9	16	11	32	18	31	0	0	0	0	0	0	0	67.46	0	0	13.4
2014	9	16	11	42	18	32	0	0	0	0	0	0	0	68.09	0	0	13.2
2014	9	16	11	52	18	32	0	0	0	0	0	0	0	68.4	0	0	13.2
2014	9	16	12	2	18	32	0	0	0	0	0	0	0	68.67	0	0	13.2
2014	9	16	12	12	18	31	0	0	0	0	0	0	0	68.94	0	0	13.2
2014	9	16	12	22	18	31	0	0	0	0	0	0	0	69.19	0	0	13.2
2014	9	16	12	32	18	31	0	0	0	0	0	0	0	69.46	0	0	13.2
2014	9	16	12	42	18	31	0	0	0	0	0	0	0	69.75	0	0	13.2
2014	9	16	12	52	18	32	0	0	0	0	0	0	0	70.03	0	0	13.2
2014	9	16	13	2	18	31	0	0	0	0	0	0	0	70.29	0	0	13.2
2014	9	16	13	12	18	31	0	0	0	0	0	0	0	70.59	0	0	13.2
2014	9	16	13	22	18	31	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	9	16	13	32	18	32	0	0	0	0	0	0	0	71.15	0	0	13.2
2014	9	16	13	42	18	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2014	9	16	13	52	18	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	9	16	14	2	18	31	0	0	0	0	0	0	0	72.03	0	0	13.2
2014	9	16	14	12	18	31	0	0	0	0	0	0	0	72.3	0	0	13.2
2014	9	16	14	22	18	32	0	0	0	0	0	0	0	72.57	0	0	13.2
2014	9	16	14	32	18	31	0	0	0	0	0	0	0	72.72	0	0	12.8
2014	9	16	14	42	18	32	0	0	0	0	0	0	0	72.99	0	0	13.2
2014	9	16	14	52	18	30	0	0	0	0	0	0	0	73.27	0	0	13.2
2014	9	16	15	2	18	31	0	0	0	0	0	0	0	73.53	0	0	13.2
2014	9	16	15	12	18	31	0	0	0	0	0	0	0	73.74	0	0	13.2
2014	9	16	15	22	18	31	0	0	0	0	0	0	0	73.94	0	0	13
2014	9	16	15	32	18	30	0	0	0	0	0	0	0	74.17	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	15	42	18	30	0	0	0	0	0	0	0	74.35	0	0	13
2014	9	16	15	52	18	30	0	0	0	0	0	0	0	74.53	0	0	13
2014	9	16	16	2	18	31	0	0	0	0	0	0	0	74.7	0	0	13
2014	9	16	16	12	18	31	0	0	0	0	0	0	0	74.84	0	0	12.8
2014	9	16	16	22	18	31	0	0	0	0	0	0	0	74.98	0	0	12.6
2014	9	16	16	32	18	31	0	0	0	0	0	0	0	75.11	0	0	12.6
2014	9	16	16	42	18	31	0	0	0	0	0	0	0	75.18	0	0	12.4
2014	9	16	16	52	18	31	0	0	0	0	0	0	0	75.2	0	0	12.4
2014	9	16	17	2	18	30	0	0	0	0	0	0	0	75.24	0	0	12.2
2014	9	16	17	12	18	30	0	0	0	0	0	0	0	75.29	0	0	12.4
2014	9	16	17	22	18	31	0	0	0	0	0	0	0	75.29	0	0	12.2
2014	9	16	17	32	18	31	0	0	0	0	0	0	0	75.33	0	0	12.2
2014	9	16	17	42	18	31	0	0	0	0	0	0	0	75.33	0	0	12.2
2014	9	16	17	52	18	31	0	0	0	0	0	0	0	75.31	0	0	12.2
2014	9	16	18	2	18	31	0	0	0	0	0	0	0	75.29	0	0	12.2
2014	9	16	18	12	18	32	0	0	0	0	0	0	0	75.27	0	0	12.2
2014	9	16	18	22	18	30	0	0	0	0	0	0	0	75.25	0	0	12
2014	9	16	18	32	18	30	0	0	0	0	0	0	0	75.22	0	0	12.2
2014	9	16	18	42	18	30	0	0	0	0	0	0	0	75.18	0	0	12.2
2014	9	16	18	52	18	31	0	0	0	0	0	0	0	75.13	0	0	12.2
2014	9	16	19	2	18	30	0	0	0	0	0	0	0	75.04	0	0	12.2
2014	9	16	19	12	18	30	0	0	0	0	0	0	0	74.95	0	0	12.2
2014	9	16	19	22	18	31	0	0	0	0	0	0	0	74.86	0	0	12
2014	9	16	19	32	18	31	0	0	0	0	0	0	0	74.75	0	0	12.2
2014	9	16	19	42	18	31	0	0	0	0	0	0	0	74.62	0	0	12.2
2014	9	16	19	52	18	30	0	0	0	0	0	0	0	74.48	0	0	12.2
2014	9	16	20	2	18	30	0	0	0	0	0	0	0	74.34	0	0	12.2
2014	9	16	20	12	18	31	0	0	0	0	0	0	0	74.17	0	0	12.2
2014	9	16	20	22	18	30	0	0	0	0	0	0	0	74.01	0	0	12
2014	9	16	20	32	18	31	0	0	0	0	0	0	0	73.83	0	0	12.2
2014	9	16	20	42	18	30	0	0	0	0	0	0	0	73.65	0	0	12
2014	9	16	20	52	18	31	0	0	0	0	0	0	0	73.47	0	0	12
2014	9	16	21	2	18	31	0	0	0	0	0	0	0	73.29	0	0	12
2014	9	16	21	12	18	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	9	16	21	22	18	32	0	0	0	0	0	0	0	72.9	0	0	12
2014	9	16	21	32	18	31	0	0	0	0	0	0	0	72.7	0	0	12
2014	9	16	21	42	18	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	9	16	21	52	18	31	0	0	0	0	0	0	0	72.3	0	0	12
2014	9	16	22	2	18	31	0	0	0	0	0	0	0	72.1	0	0	12
2014	9	16	22	12	18	32	0	0	0	0	0	0	0	71.91	0	0	12
2014	9	16	22	22	18	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	9	16	22	32	18	30	0	0	0	0	0	0	0	71.51	0	0	12
2014	9	16	22	42	18	32	0	0	0	0	0	0	0	71.33	0	0	12
2014	9	16	22	52	18	31	0	0	0	0	0	0	0	71.19	0	0	12
2014	9	16	23	2	18	31	0	0	0	0	0	0	0	71.01	0	0	12
2014	9	16	23	12	18	31	0	0	0	0	0	0	0	70.86	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	23	22	18	31	0	0	0	0	0	0	0	70.72	0	0	12
2014	9	16	23	32	18	31	0	0	0	0	0	0	0	70.57	0	0	12
2014	9	16	23	42	18	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	9	16	23	52	18	31	0	0	0	0	0	0	0	70.3	0	0	12
2014	9	17	0	2	18	31	0	0	0	0	0	0	0	70.18	0	0	12
2014	9	17	0	12	18	32	0	0	0	0	0	0	0	70.05	0	0	12
2014	9	17	0	22	18	31	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	9	17	0	32	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	9	17	0	42	18	31	0	0	0	0	0	0	0	69.69	0	0	12
2014	9	17	0	52	18	32	0	0	0	0	0	0	0	69.58	0	0	12
2014	9	17	1	2	18	31	0	0	0	0	0	0	0	69.51	0	0	12
2014	9	17	1	12	18	32	0	0	0	0	0	0	0	69.4	0	0	12
2014	9	17	1	22	18	32	0	0	0	0	0	0	0	69.33	0	0	12
2014	9	17	1	32	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	17	1	42	18	31	0	0	0	0	0	0	0	69.17	0	0	12
2014	9	17	1	52	18	31	0	0	0	0	0	0	0	69.1	0	0	12
2014	9	17	2	2	18	31	0	0	0	0	0	0	0	69.03	0	0	12
2014	9	17	2	12	18	31	0	0	0	0	0	0	0	68.95	0	0	12
2014	9	17	2	22	18	31	0	0	0	0	0	0	0	68.88	0	0	11.8
2014	9	17	2	32	18	32	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	17	2	42	18	32	0	0	0	0	0	0	0	68.76	0	0	12
2014	9	17	2	52	18	31	0	0	0	0	0	0	0	68.7	0	0	12
2014	9	17	3	2	18	32	0	0	0	0	0	0	0	68.67	0	0	12
2014	9	17	3	12	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	9	17	3	22	18	31	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	17	3	32	18	31	0	0	0	0	0	0	0	68.56	0	0	12
2014	9	17	3	42	18	31	0	0	0	0	0	0	0	68.52	0	0	12
2014	9	17	3	52	18	31	0	0	0	0	0	0	0	68.5	0	0	12
2014	9	17	4	2	18	31	0	0	0	0	0	0	0	68.47	0	0	12
2014	9	17	4	12	18	31	0	0	0	0	0	0	0	68.43	0	0	12
2014	9	17	4	22	18	32	0	0	0	0	0	0	0	68.4	0	0	11.8
2014	9	17	4	32	18	31	0	0	0	0	0	0	0	68.36	0	0	12
2014	9	17	4	42	18	31	0	0	0	0	0	0	0	68.34	0	0	12
2014	9	17	4	52	18	31	0	0	0	0	0	0	0	68.32	0	0	12
2014	9	17	5	2	18	32	0	0	0	0	0	0	0	68.31	0	0	12
2014	9	17	5	12	18	32	0	0	0	0	0	0	0	68.27	0	0	12
2014	9	17	5	22	18	31	0	0	0	0	0	0	0	68.25	0	0	11.8
2014	9	17	5	32	18	32	0	0	0	0	0	0	0	68.22	0	0	12
2014	9	17	5	42	18	31	0	0	0	0	0	0	0	68.2	0	0	12
2014	9	17	5	52	18	32	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	17	6	2	18	31	0	0	0	0	0	0	0	68.13	0	0	12
2014	9	17	6	12	18	32	0	0	0	0	0	0	0	68.07	0	0	12
2014	9	17	6	22	18	32	0	0	0	0	0	0	0	68.02	0	0	11.8
2014	9	17	6	32	18	32	0	0	0	0	0	0	0	67.95	0	0	12
2014	9	17	6	42	18	31	0	0	0	0	0	0	0	67.89	0	0	12
2014	9	17	6	52	18	32	0	0	0	0	0	0	0	67.82	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	7	2	18	32	0	0	0	0	0	0	0	67.75	0	0	12
2014	9	17	7	12	18	31	0	0	0	0	0	0	0	67.68	0	0	12
2014	9	17	7	22	18	31	0	0	0	0	0	0	0	67.6	0	0	11.8
2014	9	17	7	32	18	32	0	0	0	0	0	0	0	67.55	0	0	12.2
2014	9	17	7	42	18	31	0	0	0	0	0	0	0	67.5	0	0	12.6
2014	9	17	7	52	18	31	0	0	0	0	0	0	0	67.46	0	0	12.8
2014	9	17	8	2	18	32	0	0	0	0	0	0	0	67.42	0	0	12.8
2014	9	17	8	12	18	31	0	0	0	0	0	0	0	67.42	0	0	13
2014	9	17	8	22	18	32	0	0	0	0	0	0	0	67.41	0	0	13
2014	9	17	8	32	18	32	0	0	0	0	0	0	0	67.41	0	0	13.2
2014	9	17	8	42	18	31	0	0	0	0	0	0	0	67.41	0	0	13.2
2014	9	17	8	52	18	32	0	0	0	0	0	0	0	67.42	0	0	13.2
2014	9	17	9	2	18	32	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	17	9	12	18	31	0	0	0	0	0	0	0	67.5	0	0	13.4
2014	9	17	9	22	18	32	0	0	0	0	0	0	0	67.55	0	0	13.2
2014	9	17	9	32	18	32	0	0	0	0	0	0	0	68.16	0	0	13.4
2014	9	17	9	42	18	32	0	0	0	0	0	0	0	68.31	0	0	13.4
2014	9	17	9	52	18	32	0	0	0	0	0	0	0	68.5	0	0	13.4
2014	9	17	10	2	18	31	0	0	0	0	0	0	0	68.65	0	0	13.4
2014	9	17	10	12	18	31	0	0	0	0	0	0	0	68.74	0	0	13.4
2014	9	17	10	22	18	31	0	0	0	0	0	0	0	68.85	0	0	13.2
2014	9	17	10	32	18	31	0	0	0	0	0	0	0	68.58	0	0	13.4
2014	9	17	10	42	18	32	0	0	0	0	0	0	0	68.34	0	0	13.4
2014	9	17	10	52	18	32	0	0	0	0	0	0	0	68.41	0	0	13.4
2014	9	17	11	2	18	31	0	0	0	0	0	0	0	68.54	0	0	13.4
2014	9	17	11	12	18	31	0	0	0	0	0	0	0	68.68	0	0	13.4
2014	9	17	11	22	18	32	0	0	0	0	0	0	0	68.85	0	0	13.2
2014	9	17	11	32	18	32	0	0	0	0	0	0	0	69.58	0	0	13.2
2014	9	17	11	42	18	32	0	0	0	0	0	0	0	70	0	0	13.2
2014	9	17	11	52	18	30	0	0	0	0	0	0	0	70.27	0	0	13.2
2014	9	17	12	2	18	31	0	0	0	0	0	0	0	70.5	0	0	13.2
2014	9	17	12	12	18	31	0	0	0	0	0	0	0	70.75	0	0	13.2
2014	9	17	12	22	18	31	0	0	0	0	0	0	0	71.01	0	0	13.2
2014	9	17	12	32	18	31	0	0	0	0	0	0	0	71.24	0	0	13.2
2014	9	17	12	42	18	31	0	0	0	0	0	0	0	71.47	0	0	13.2
2014	9	17	12	52	18	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	9	17	13	2	18	31	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	9	17	13	12	18	31	0	0	0	0	0	0	0	72.19	0	0	13.2
2014	9	17	13	22	18	31	0	0	0	0	0	0	0	72.46	0	0	13.2
2014	9	17	13	32	18	31	0	0	0	0	0	0	0	72.72	0	0	13.2
2014	9	17	13	42	18	31	0	0	0	0	0	0	0	72.97	0	0	13.2
2014	9	17	13	52	18	31	0	0	0	0	0	0	0	73.2	0	0	13.2
2014	9	17	14	2	18	31	0	0	0	0	0	0	0	73.45	0	0	13.2
2014	9	17	14	12	18	31	0	0	0	0	0	0	0	73.69	0	0	13.2
2014	9	17	14	22	18	30	0	0	0	0	0	0	0	73.9	0	0	13.2
2014	9	17	14	32	18	30	0	0	0	0	0	0	0	74.16	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	14	42	18	31	0	0	0	0	0	0	0	74.16	0	0	12.8
2014	9	17	14	52	18	31	0	0	0	0	0	0	0	74.48	0	0	13.2
2014	9	17	15	2	18	31	0	0	0	0	0	0	0	74.66	0	0	13
2014	9	17	15	12	18	30	0	0	0	0	0	0	0	74.84	0	0	13.2
2014	9	17	15	22	18	30	0	0	0	0	0	0	0	75	0	0	13.2
2014	9	17	15	32	18	31	0	0	0	0	0	0	0	75.15	0	0	13.2
2014	9	17	15	42	18	31	0	0	0	0	0	0	0	75.25	0	0	13.2
2014	9	17	15	52	18	30	0	0	0	0	0	0	0	75.38	0	0	13.2
2014	9	17	16	2	18	31	0	0	0	0	0	0	0	75.51	0	0	13
2014	9	17	16	12	18	31	0	0	0	0	0	0	0	75.58	0	0	13
2014	9	17	16	22	18	31	0	0	0	0	0	0	0	75.65	0	0	12.6
2014	9	17	16	32	18	31	0	0	0	0	0	0	0	75.74	0	0	12.8
2014	9	17	16	42	18	30	0	0	0	0	0	0	0	75.81	0	0	12.6
2014	9	17	16	52	18	30	0	0	0	0	0	0	0	75.83	0	0	12.6
2014	9	17	17	2	18	31	0	0	0	0	0	0	0	75.88	0	0	12.4
2014	9	17	17	12	18	30	0	0	0	0	0	0	0	75.9	0	0	12.4
2014	9	17	17	22	18	30	0	0	0	0	0	0	0	75.88	0	0	12.2
2014	9	17	17	32	18	30	0	0	0	0	0	0	0	75.85	0	0	12.4
2014	9	17	17	42	18	31	0	0	0	0	0	0	0	75.81	0	0	12.2
2014	9	17	17	52	18	30	0	0	0	0	0	0	0	75.76	0	0	12.2
2014	9	17	18	2	18	32	0	0	0	0	0	0	0	75.72	0	0	12.2
2014	9	17	18	12	18	30	0	0	0	0	0	0	0	75.67	0	0	12.2
2014	9	17	18	22	18	31	0	0	0	0	0	0	0	75.58	0	0	12.2
2014	9	17	18	32	18	30	0	0	0	0	0	0	0	75.52	0	0	12.2
2014	9	17	18	42	18	30	0	0	0	0	0	0	0	75.45	0	0	12.2
2014	9	17	18	52	18	30	0	0	0	0	0	0	0	75.36	0	0	12.2
2014	9	17	19	2	18	31	0	0	0	0	0	0	0	75.27	0	0	12.2
2014	9	17	19	12	18	31	0	0	0	0	0	0	0	75.2	0	0	12.2
2014	9	17	19	22	18	31	0	0	0	0	0	0	0	75.11	0	0	12
2014	9	17	19	32	18	31	0	0	0	0	0	0	0	75.02	0	0	12.2
2014	9	17	19	42	18	31	0	0	0	0	0	0	0	74.93	0	0	12.2
2014	9	17	19	52	18	31	0	0	0	0	0	0	0	74.82	0	0	12.2
2014	9	17	20	2	18	32	0	0	0	0	0	0	0	74.7	0	0	12.2
2014	9	17	20	12	18	31	0	0	0	0	0	0	0	74.55	0	0	12.2
2014	9	17	20	22	18	30	0	0	0	0	0	0	0	74.41	0	0	12
2014	9	17	20	32	18	31	0	0	0	0	0	0	0	74.26	0	0	12.2
2014	9	17	20	42	18	31	0	0	0	0	0	0	0	74.1	0	0	12.2
2014	9	17	20	52	18	31	0	0	0	0	0	0	0	73.94	0	0	12.2
2014	9	17	21	2	18	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	9	17	21	12	18	32	0	0	0	0	0	0	0	73.56	0	0	12
2014	9	17	21	22	18	31	0	0	0	0	0	0	0	73.36	0	0	12
2014	9	17	21	32	18	31	0	0	0	0	0	0	0	73.17	0	0	12
2014	9	17	21	42	18	31	0	0	0	0	0	0	0	72.97	0	0	12
2014	9	17	21	52	18	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	9	17	22	2	18	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	9	17	22	12	18	31	0	0	0	0	0	0	0	72.32	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	22	22	18	32	0	0	0	0	0	0	0	72.12	0	0	12
2014	9	17	22	32	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	9	17	22	42	18	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	9	17	22	52	18	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	9	17	23	2	18	31	0	0	0	0	0	0	0	71.35	0	0	12
2014	9	17	23	12	18	31	0	0	0	0	0	0	0	71.19	0	0	12
2014	9	17	23	22	18	31	0	0	0	0	0	0	0	71.02	0	0	12
2014	9	17	23	32	18	31	0	0	0	0	0	0	0	70.88	0	0	12
2014	9	17	23	42	18	31	0	0	0	0	0	0	0	70.74	0	0	12
2014	9	17	23	52	18	31	0	0	0	0	0	0	0	70.61	0	0	12
2014	9	18	0	2	18	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	9	18	0	12	18	31	0	0	0	0	0	0	0	70.36	0	0	12
2014	9	18	0	22	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	9	18	0	32	18	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	9	18	0	42	18	31	0	0	0	0	0	0	0	70.03	0	0	12
2014	9	18	0	52	18	31	0	0	0	0	0	0	0	69.94	0	0	12
2014	9	18	1	2	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	9	18	1	12	18	31	0	0	0	0	0	0	0	69.78	0	0	12
2014	9	18	1	22	18	32	0	0	0	0	0	0	0	69.71	0	0	12
2014	9	18	1	32	18	31	0	0	0	0	0	0	0	69.62	0	0	12
2014	9	18	1	42	18	31	0	0	0	0	0	0	0	69.55	0	0	12
2014	9	18	1	52	18	31	0	0	0	0	0	0	0	69.48	0	0	12
2014	9	18	2	2	18	31	0	0	0	0	0	0	0	69.39	0	0	12
2014	9	18	2	12	18	31	0	0	0	0	0	0	0	69.31	0	0	12
2014	9	18	2	22	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	9	18	2	32	18	31	0	0	0	0	0	0	0	69.15	0	0	12
2014	9	18	2	42	18	31	0	0	0	0	0	0	0	69.06	0	0	12
2014	9	18	2	52	18	31	0	0	0	0	0	0	0	68.97	0	0	12
2014	9	18	3	2	18	32	0	0	0	0	0	0	0	68.9	0	0	12
2014	9	18	3	12	18	32	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	18	3	22	18	31	0	0	0	0	0	0	0	68.74	0	0	11.8
2014	9	18	3	32	18	32	0	0	0	0	0	0	0	68.67	0	0	12
2014	9	18	3	42	18	31	0	0	0	0	0	0	0	68.61	0	0	12
2014	9	18	3	52	18	31	0	0	0	0	0	0	0	68.54	0	0	12
2014	9	18	4	2	18	32	0	0	0	0	0	0	0	68.47	0	0	12
2014	9	18	4	12	18	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	18	4	22	18	31	0	0	0	0	0	0	0	68.31	0	0	11.8
2014	9	18	4	32	18	31	0	0	0	0	0	0	0	68.25	0	0	12
2014	9	18	4	42	18	31	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	18	4	52	18	32	0	0	0	0	0	0	0	68.07	0	0	12
2014	9	18	5	2	18	32	0	0	0	0	0	0	0	68	0	0	12
2014	9	18	5	12	18	31	0	0	0	0	0	0	0	67.91	0	0	12
2014	9	18	5	22	18	32	0	0	0	0	0	0	0	67.82	0	0	11.8
2014	9	18	5	32	18	31	0	0	0	0	0	0	0	67.73	0	0	12
2014	9	18	5	42	18	32	0	0	0	0	0	0	0	67.66	0	0	12
2014	9	18	5	52	18	32	0	0	0	0	0	0	0	67.57	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	6	2	18	31	0	0	0	0	0	0	0	67.48	0	0	12
2014	9	18	6	12	18	31	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	18	6	22	18	31	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	18	6	32	18	31	0	0	0	0	0	0	0	67.21	0	0	12
2014	9	18	6	42	18	32	0	0	0	0	0	0	0	67.1	0	0	12
2014	9	18	6	52	18	32	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	18	7	2	18	31	0	0	0	0	0	0	0	66.92	0	0	12
2014	9	18	7	12	18	32	0	0	0	0	0	0	0	66.83	0	0	12
2014	9	18	7	22	18	32	0	0	0	0	0	0	0	66.74	0	0	11.8
2014	9	18	7	32	18	31	0	0	0	0	0	0	0	66.65	0	0	12.2
2014	9	18	7	42	18	31	0	0	0	0	0	0	0	66.58	0	0	12.6
2014	9	18	7	52	18	32	0	0	0	0	0	0	0	66.49	0	0	12.8
2014	9	18	8	2	18	32	0	0	0	0	0	0	0	66.45	0	0	13
2014	9	18	8	12	18	31	0	0	0	0	0	0	0	66.42	0	0	13.2
2014	9	18	8	22	18	32	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	18	8	32	18	32	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	18	8	42	18	32	0	0	0	0	0	0	0	66.4	0	0	13.4
2014	9	18	8	52	18	32	0	0	0	0	0	0	0	66.4	0	0	13.4
2014	9	18	9	2	18	31	0	0	0	0	0	0	0	66.43	0	0	13.4
2014	9	18	9	12	18	31	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	9	18	9	22	18	32	0	0	0	0	0	0	0	66.51	0	0	13.4
2014	9	18	9	32	18	31	0	0	0	0	0	0	0	67.21	0	0	13.4
2014	9	18	9	42	18	31	0	0	0	0	0	0	0	67.46	0	0	13.4
2014	9	18	9	52	18	32	0	0	0	0	0	0	0	67.6	0	0	13.4
2014	9	18	10	2	18	31	0	0	0	0	0	0	0	67.71	0	0	13.4
2014	9	18	10	12	18	32	0	0	0	0	0	0	0	67.86	0	0	13.4
2014	9	18	10	22	18	32	0	0	0	0	0	0	0	67.93	0	0	13.4
2014	9	18	10	32	18	32	0	0	0	0	0	0	0	67.42	0	0	13.4
2014	9	18	10	42	18	32	0	0	0	0	0	0	0	67.23	0	0	13.4
2014	9	18	10	52	18	32	0	0	0	0	0	0	0	67.28	0	0	13.4
2014	9	18	11	2	18	32	0	0	0	0	0	0	0	67.39	0	0	13.4
2014	9	18	11	12	18	32	0	0	0	0	0	0	0	67.53	0	0	13.4
2014	9	18	11	22	18	31	0	0	0	0	0	0	0	67.69	0	0	13.4
2014	9	18	11	32	18	32	0	0	0	0	0	0	0	68.56	0	0	13.4
2014	9	18	11	42	18	31	0	0	0	0	0	0	0	68.97	0	0	13.4
2014	9	18	11	52	18	32	0	0	0	0	0	0	0	69.21	0	0	13.4
2014	9	18	12	2	18	31	0	0	0	0	0	0	0	69.4	0	0	13.4
2014	9	18	12	12	18	31	0	0	0	0	0	0	0	69.66	0	0	13.4
2014	9	18	12	22	18	32	0	0	0	0	0	0	0	69.84	0	0	13.2
2014	9	18	12	32	18	31	0	0	0	0	0	0	0	70.05	0	0	13.4
2014	9	18	12	42	18	31	0	0	0	0	0	0	0	70.27	0	0	13.4
2014	9	18	12	52	18	31	0	0	0	0	0	0	0	70.54	0	0	13.4
2014	9	18	13	2	18	31	0	0	0	0	0	0	0	70.74	0	0	13.4
2014	9	18	13	12	18	32	0	0	0	0	0	0	0	70.97	0	0	13.4
2014	9	18	13	22	18	32	0	0	0	0	0	0	0	71.22	0	0	13.2
2014	9	18	13	32	18	31	0	0	0	0	0	0	0	71.47	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	13	42	18	32	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	9	18	13	52	18	31	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	9	18	14	2	18	31	0	0	0	0	0	0	0	72.14	0	0	13.2
2014	9	18	14	12	18	30	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	9	18	14	22	18	31	0	0	0	0	0	0	0	72.59	0	0	13.2
2014	9	18	14	32	18	31	0	0	0	0	0	0	0	72.84	0	0	13.2
2014	9	18	14	42	18	31	0	0	0	0	0	0	0	73.04	0	0	13.2
2014	9	18	14	52	18	32	0	0	0	0	0	0	0	73.24	0	0	13.2
2014	9	18	15	2	18	31	0	0	0	0	0	0	0	73.42	0	0	13.2
2014	9	18	15	12	18	31	0	0	0	0	0	0	0	73.62	0	0	13.2
2014	9	18	15	22	18	31	0	0	0	0	0	0	0	73.78	0	0	13
2014	9	18	15	32	18	30	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	9	18	15	42	18	31	0	0	0	0	0	0	0	74.1	0	0	13.2
2014	9	18	15	52	18	31	0	0	0	0	0	0	0	74.23	0	0	13.2
2014	9	18	16	2	18	31	0	0	0	0	0	0	0	74.39	0	0	13
2014	9	18	16	12	18	30	0	0	0	0	0	0	0	74.5	0	0	13
2014	9	18	16	22	18	31	0	0	0	0	0	0	0	74.59	0	0	12.8
2014	9	18	16	32	18	31	0	0	0	0	0	0	0	74.68	0	0	12.6
2014	9	18	16	42	18	31	0	0	0	0	0	0	0	74.77	0	0	12.6
2014	9	18	16	52	18	31	0	0	0	0	0	0	0	74.82	0	0	12.4
2014	9	18	17	2	18	30	0	0	0	0	0	0	0	74.86	0	0	12.4
2014	9	18	17	12	18	31	0	0	0	0	0	0	0	74.89	0	0	12.2
2014	9	18	17	22	18	31	0	0	0	0	0	0	0	74.89	0	0	12.2
2014	9	18	17	32	18	30	0	0	0	0	0	0	0	74.88	0	0	12.2
2014	9	18	17	42	18	31	0	0	0	0	0	0	0	74.88	0	0	12.2
2014	9	18	17	52	18	30	0	0	0	0	0	0	0	74.86	0	0	12.2
2014	9	18	18	2	18	31	0	0	0	0	0	0	0	74.84	0	0	12.2
2014	9	18	18	12	18	30	0	0	0	0	0	0	0	74.8	0	0	12.2
2014	9	18	18	22	18	30	0	0	0	0	0	0	0	74.77	0	0	12
2014	9	18	18	32	18	30	0	0	0	0	0	0	0	74.71	0	0	12.2
2014	9	18	18	42	18	31	0	0	0	0	0	0	0	74.66	0	0	12.2
2014	9	18	18	52	18	30	0	0	0	0	0	0	0	74.59	0	0	12.2
2014	9	18	19	2	18	31	0	0	0	0	0	0	0	74.48	0	0	12.2
2014	9	18	19	12	18	31	0	0	0	0	0	0	0	74.37	0	0	12.2
2014	9	18	19	22	18	31	0	0	0	0	0	0	0	74.26	0	0	12
2014	9	18	19	32	18	31	0	0	0	0	0	0	0	74.16	0	0	12.2
2014	9	18	19	42	18	30	0	0	0	0	0	0	0	74.03	0	0	12.2
2014	9	18	19	52	18	31	0	0	0	0	0	0	0	73.9	0	0	12.2
2014	9	18	20	2	18	31	0	0	0	0	0	0	0	73.76	0	0	12.2
2014	9	18	20	12	18	31	0	0	0	0	0	0	0	73.6	0	0	12.2
2014	9	18	20	22	18	30	0	0	0	0	0	0	0	73.45	0	0	12
2014	9	18	20	32	18	31	0	0	0	0	0	0	0	73.29	0	0	12.2
2014	9	18	20	42	18	31	0	0	0	0	0	0	0	73.11	0	0	12
2014	9	18	20	52	18	31	0	0	0	0	0	0	0	72.91	0	0	12
2014	9	18	21	2	18	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	9	18	21	12	18	30	0	0	0	0	0	0	0	72.54	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	21	22	18	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	9	18	21	32	18	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	9	18	21	42	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	9	18	21	52	18	31	0	0	0	0	0	0	0	71.67	0	0	12
2014	9	18	22	2	18	31	0	0	0	0	0	0	0	71.46	0	0	12
2014	9	18	22	12	18	31	0	0	0	0	0	0	0	71.22	0	0	12
2014	9	18	22	22	18	31	0	0	0	0	0	0	0	70.97	0	0	12
2014	9	18	22	32	18	32	0	0	0	0	0	0	0	70.74	0	0	12
2014	9	18	22	42	18	32	0	0	0	0	0	0	0	70.5	0	0	12
2014	9	18	22	52	18	32	0	0	0	0	0	0	0	70.25	0	0	12
2014	9	18	23	2	18	31	0	0	0	0	0	0	0	70.02	0	0	12
2014	9	18	23	12	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	9	18	23	22	18	31	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	9	18	23	32	18	31	0	0	0	0	0	0	0	69.39	0	0	12
2014	9	18	23	42	18	31	0	0	0	0	0	0	0	69.19	0	0	12
2014	9	18	23	52	18	31	0	0	0	0	0	0	0	69.01	0	0	12
2014	9	19	0	2	18	31	0	0	0	0	0	0	0	68.83	0	0	12
2014	9	19	0	12	18	31	0	0	0	0	0	0	0	68.65	0	0	12
2014	9	19	0	22	18	32	0	0	0	0	0	0	0	68.45	0	0	12
2014	9	19	0	32	18	32	0	0	0	0	0	0	0	68.29	0	0	12
2014	9	19	0	42	18	31	0	0	0	0	0	0	0	68.11	0	0	12
2014	9	19	0	52	18	31	0	0	0	0	0	0	0	67.96	0	0	12
2014	9	19	1	2	18	31	0	0	0	0	0	0	0	67.8	0	0	12
2014	9	19	1	12	18	32	0	0	0	0	0	0	0	67.62	0	0	12
2014	9	19	1	22	18	32	0	0	0	0	0	0	0	67.48	0	0	12
2014	9	19	1	32	18	32	0	0	0	0	0	0	0	67.32	0	0	12
2014	9	19	1	42	18	32	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	19	1	52	18	32	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	19	2	2	18	31	0	0	0	0	0	0	0	66.9	0	0	12
2014	9	19	2	12	18	32	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	19	2	22	18	31	0	0	0	0	0	0	0	66.63	0	0	11.8
2014	9	19	2	32	18	32	0	0	0	0	0	0	0	66.51	0	0	12
2014	9	19	2	42	18	32	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	19	2	52	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	19	3	2	18	31	0	0	0	0	0	0	0	66.16	0	0	12
2014	9	19	3	12	18	32	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	19	3	22	18	32	0	0	0	0	0	0	0	65.93	0	0	11.8
2014	9	19	3	32	18	32	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	19	3	42	18	32	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	19	3	52	18	32	0	0	0	0	0	0	0	65.62	0	0	12
2014	9	19	4	2	18	31	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	19	4	12	18	32	0	0	0	0	0	0	0	65.43	0	0	12
2014	9	19	4	22	18	33	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	19	4	32	18	32	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	19	4	42	18	32	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	19	4	52	18	32	0	0	0	0	0	0	0	65.08	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	5	2	18	32	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	19	5	12	18	32	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	19	5	22	18	31	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	19	5	32	18	32	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	19	5	42	18	32	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	5	52	18	31	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	19	6	2	18	32	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	19	6	12	18	32	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	19	6	22	18	32	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	19	6	32	18	33	0	0	0	0	0	0	0	64.29	0	0	11.8
2014	9	19	6	42	18	32	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	19	6	52	18	32	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	19	7	2	18	33	0	0	0	0	0	0	0	64.24	0	0	12
2014	9	19	7	12	18	32	0	0	0	0	0	0	0	64.24	0	0	12
2014	9	19	7	22	18	31	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	19	7	32	18	33	0	0	0	0	0	0	0	64.18	0	0	12
2014	9	19	7	42	18	33	0	0	0	0	0	0	0	64.18	0	0	12.2
2014	9	19	7	52	18	32	0	0	0	0	0	0	0	64.17	0	0	12.4
2014	9	19	8	2	18	32	0	0	0	0	0	0	0	64.17	0	0	12.6
2014	9	19	8	12	18	33	0	0	0	0	0	0	0	64.18	0	0	12.6
2014	9	19	8	22	18	32	0	0	0	0	0	0	0	64.22	0	0	12.8
2014	9	19	8	32	18	32	0	0	0	0	0	0	0	64.22	0	0	13
2014	9	19	8	42	18	32	0	0	0	0	0	0	0	64.24	0	0	13
2014	9	19	8	52	18	32	0	0	0	0	0	0	0	64.24	0	0	13
2014	9	19	9	2	18	33	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	19	9	12	18	32	0	0	0	0	0	0	0	64.31	0	0	13.2
2014	9	19	9	22	18	32	0	0	0	0	0	0	0	64.38	0	0	13
2014	9	19	9	32	18	32	0	0	0	0	0	0	0	64.6	0	0	13.2
2014	9	19	9	42	18	32	0	0	0	0	0	0	0	64.87	0	0	13.4
2014	9	19	9	52	18	32	0	0	0	0	0	0	0	64.99	0	0	13.4
2014	9	19	10	2	18	31	0	0	0	0	0	0	0	65.1	0	0	13.4
2014	9	19	10	12	18	32	0	0	0	0	0	0	0	65.17	0	0	13.6
2014	9	19	10	22	18	32	0	0	0	0	0	0	0	65.35	0	0	13.6
2014	9	19	10	32	18	31	0	0	0	0	0	0	0	65.08	0	0	13.6
2014	9	19	10	42	18	32	0	0	0	0	0	0	0	65.08	0	0	13.6
2014	9	19	10	52	18	32	0	0	0	0	0	0	0	65.17	0	0	13.6
2014	9	19	11	2	18	32	0	0	0	0	0	0	0	65.28	0	0	13.6
2014	9	19	11	12	18	32	0	0	0	0	0	0	0	65.43	0	0	13.6
2014	9	19	11	22	18	32	0	0	0	0	0	0	0	65.61	0	0	13.4
2014	9	19	11	32	18	31	0	0	0	0	0	0	0	66.16	0	0	13.6
2014	9	19	11	42	18	32	0	0	0	0	0	0	0	66.42	0	0	13.6
2014	9	19	11	52	18	32	0	0	0	0	0	0	0	66.65	0	0	13.4
2014	9	19	12	2	18	32	0	0	0	0	0	0	0	66.88	0	0	13.4
2014	9	19	12	12	18	32	0	0	0	0	0	0	0	67.12	0	0	13.4
2014	9	19	12	22	18	32	0	0	0	0	0	0	0	67.32	0	0	13.4
2014	9	19	12	32	18	31	0	0	0	0	0	0	0	67.57	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	12	42	18	32	0	0	0	0	0	0	0	67.8	0	0	13.4
2014	9	19	12	52	18	32	0	0	0	0	0	0	0	68.04	0	0	13.4
2014	9	19	13	2	18	32	0	0	0	0	0	0	0	68.31	0	0	13.2
2014	9	19	13	12	18	32	0	0	0	0	0	0	0	68.5	0	0	13.2
2014	9	19	13	22	18	31	0	0	0	0	0	0	0	68.76	0	0	13.2
2014	9	19	13	32	18	32	0	0	0	0	0	0	0	69.01	0	0	13.2
2014	9	19	13	42	18	32	0	0	0	0	0	0	0	69.26	0	0	13.2
2014	9	19	13	52	18	32	0	0	0	0	0	0	0	69.53	0	0	13.2
2014	9	19	14	2	18	31	0	0	0	0	0	0	0	69.84	0	0	13.2
2014	9	19	14	12	18	30	0	0	0	0	0	0	0	70.05	0	0	13.2
2014	9	19	14	22	18	32	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	9	19	14	32	18	32	0	0	0	0	0	0	0	70.59	0	0	13.2
2014	9	19	14	42	18	32	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	9	19	14	52	18	31	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	9	19	15	2	18	31	0	0	0	0	0	0	0	71.26	0	0	13.2
2014	9	19	15	12	18	31	0	0	0	0	0	0	0	71.42	0	0	13.2
2014	9	19	15	22	18	31	0	0	0	0	0	0	0	71.64	0	0	13.2
2014	9	19	15	32	18	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	9	19	15	42	18	32	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	9	19	15	52	18	30	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	9	19	16	2	18	31	0	0	0	0	0	0	0	72.25	0	0	13.2
2014	9	19	16	12	18	31	0	0	0	0	0	0	0	72.37	0	0	13
2014	9	19	16	22	18	31	0	0	0	0	0	0	0	72.5	0	0	12.6
2014	9	19	16	32	18	31	0	0	0	0	0	0	0	72.61	0	0	12.6
2014	9	19	16	42	18	31	0	0	0	0	0	0	0	72.68	0	0	12.6
2014	9	19	16	52	18	31	0	0	0	0	0	0	0	72.75	0	0	12.4
2014	9	19	17	2	18	31	0	0	0	0	0	0	0	72.81	0	0	12.4
2014	9	19	17	12	18	32	0	0	0	0	0	0	0	72.84	0	0	12.4
2014	9	19	17	22	18	32	0	0	0	0	0	0	0	72.86	0	0	12.2
2014	9	19	17	32	18	31	0	0	0	0	0	0	0	72.86	0	0	12.2
2014	9	19	17	42	18	31	0	0	0	0	0	0	0	72.88	0	0	12.2
2014	9	19	17	52	18	31	0	0	0	0	0	0	0	72.88	0	0	12.2
2014	9	19	18	2	18	31	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	9	19	18	12	18	31	0	0	0	0	0	0	0	72.88	0	0	12.2
2014	9	19	18	22	18	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	9	19	18	32	18	30	0	0	0	0	0	0	0	72.79	0	0	12.2
2014	9	19	18	42	18	31	0	0	0	0	0	0	0	72.72	0	0	12.2
2014	9	19	18	52	18	30	0	0	0	0	0	0	0	72.63	0	0	12.2
2014	9	19	19	2	18	32	0	0	0	0	0	0	0	72.52	0	0	12.2
2014	9	19	19	12	18	32	0	0	0	0	0	0	0	72.39	0	0	12.2
2014	9	19	19	22	18	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	9	19	19	32	18	31	0	0	0	0	0	0	0	72.12	0	0	12.2
2014	9	19	19	42	18	31	0	0	0	0	0	0	0	71.96	0	0	12.2
2014	9	19	19	52	18	31	0	0	0	0	0	0	0	71.8	0	0	12.2
2014	9	19	20	2	18	32	0	0	0	0	0	0	0	71.65	0	0	12
2014	9	19	20	12	18	31	0	0	0	0	0	0	0	71.46	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	20	22	18	31	0	0	0	0	0	0	0	71.28	0	0	12
2014	9	19	20	32	18	30	0	0	0	0	0	0	0	71.1	0	0	12
2014	9	19	20	42	18	32	0	0	0	0	0	0	0	70.9	0	0	12
2014	9	19	20	52	18	31	0	0	0	0	0	0	0	70.66	0	0	12
2014	9	19	21	2	18	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	9	19	21	12	18	31	0	0	0	0	0	0	0	70.21	0	0	12
2014	9	19	21	22	18	32	0	0	0	0	0	0	0	69.96	0	0	12
2014	9	19	21	32	18	32	0	0	0	0	0	0	0	69.73	0	0	12
2014	9	19	21	42	18	31	0	0	0	0	0	0	0	69.49	0	0	12
2014	9	19	21	52	18	31	0	0	0	0	0	0	0	69.26	0	0	12
2014	9	19	22	2	18	31	0	0	0	0	0	0	0	69.03	0	0	12
2014	9	19	22	12	18	31	0	0	0	0	0	0	0	68.79	0	0	12
2014	9	19	22	22	18	32	0	0	0	0	0	0	0	68.58	0	0	12
2014	9	19	22	32	18	31	0	0	0	0	0	0	0	68.38	0	0	12
2014	9	19	22	42	18	32	0	0	0	0	0	0	0	68.16	0	0	12
2014	9	19	22	52	18	32	0	0	0	0	0	0	0	67.98	0	0	12
2014	9	19	23	2	18	31	0	0	0	0	0	0	0	67.77	0	0	12
2014	9	19	23	12	18	32	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	19	23	22	18	31	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	19	23	32	18	32	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	19	23	42	18	32	0	0	0	0	0	0	0	67.08	0	0	12
2014	9	19	23	52	18	32	0	0	0	0	0	0	0	66.94	0	0	12
2014	9	20	0	2	18	31	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	20	0	12	18	32	0	0	0	0	0	0	0	66.63	0	0	12
2014	9	20	0	22	18	31	0	0	0	0	0	0	0	66.51	0	0	11.8
2014	9	20	0	32	18	31	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	20	0	42	18	32	0	0	0	0	0	0	0	66.27	0	0	12
2014	9	20	0	52	18	32	0	0	0	0	0	0	0	66.16	0	0	12
2014	9	20	1	2	18	32	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	20	1	12	18	32	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	20	1	22	18	32	0	0	0	0	0	0	0	65.88	0	0	12
2014	9	20	1	32	18	31	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	20	1	42	18	32	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	20	1	52	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	20	2	2	18	32	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	20	2	12	18	31	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	20	2	22	18	33	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	20	2	32	18	32	0	0	0	0	0	0	0	65.3	0	0	12
2014	9	20	2	42	18	31	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	20	2	52	18	32	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	20	3	2	18	31	0	0	0	0	0	0	0	65.08	0	0	12
2014	9	20	3	12	18	32	0	0	0	0	0	0	0	64.99	0	0	12
2014	9	20	3	22	18	32	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	20	3	32	18	32	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	20	3	42	18	32	0	0	0	0	0	0	0	64.8	0	0	12
2014	9	20	3	52	18	32	0	0	0	0	0	0	0	64.72	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	4	2	18	32	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	20	4	12	18	32	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	20	4	22	18	33	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	20	4	32	18	32	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	20	4	42	18	33	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	20	4	52	18	32	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	20	5	2	18	32	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	20	5	12	18	32	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	20	5	22	18	32	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	20	5	32	18	32	0	0	0	0	0	0	0	63.95	0	0	11.8
2014	9	20	5	42	18	32	0	0	0	0	0	0	0	63.86	0	0	11.8
2014	9	20	5	52	18	32	0	0	0	0	0	0	0	63.77	0	0	11.8
2014	9	20	6	2	18	32	0	0	0	0	0	0	0	63.7	0	0	11.8
2014	9	20	6	12	18	32	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	20	6	22	18	32	0	0	0	0	0	0	0	63.48	0	0	11.8
2014	9	20	6	32	18	32	0	0	0	0	0	0	0	63.41	0	0	11.8
2014	9	20	6	42	18	32	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	20	6	52	18	32	0	0	0	0	0	0	0	63.21	0	0	11.8
2014	9	20	7	2	18	32	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	20	7	12	18	32	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	20	7	22	18	33	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	20	7	32	18	32	0	0	0	0	0	0	0	62.85	0	0	12
2014	9	20	7	42	18	32	0	0	0	0	0	0	0	62.78	0	0	12.6
2014	9	20	7	52	18	33	0	0	0	0	0	0	0	62.71	0	0	12.8
2014	9	20	8	2	18	32	0	0	0	0	0	0	0	62.65	0	0	13
2014	9	20	8	12	18	32	0	0	0	0	0	0	0	62.62	0	0	13
2014	9	20	8	22	18	32	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	20	8	32	18	32	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	20	8	42	18	33	0	0	0	0	0	0	0	62.55	0	0	13.4
2014	9	20	8	52	18	32	0	0	0	0	0	0	0	62.56	0	0	13.4
2014	9	20	9	2	18	32	0	0	0	0	0	0	0	62.6	0	0	13.6
2014	9	20	9	12	18	33	0	0	0	0	0	0	0	62.62	0	0	13.6
2014	9	20	9	22	18	32	0	0	0	0	0	0	0	62.65	0	0	13.6
2014	9	20	9	32	18	32	0	0	0	0	0	0	0	63.1	0	0	13.4
2014	9	20	9	42	18	33	0	0	0	0	0	0	0	63.43	0	0	13.6
2014	9	20	9	52	18	32	0	0	0	0	0	0	0	63.66	0	0	13.6
2014	9	20	10	2	18	33	0	0	0	0	0	0	0	63.86	0	0	13.4
2014	9	20	10	12	18	32	0	0	0	0	0	0	0	63.97	0	0	13.4
2014	9	20	10	22	18	32	0	0	0	0	0	0	0	64.06	0	0	13.2
2014	9	20	10	32	18	32	0	0	0	0	0	0	0	63.55	0	0	13.4
2014	9	20	10	42	18	32	0	0	0	0	0	0	0	63.57	0	0	13.4
2014	9	20	10	52	18	32	0	0	0	0	0	0	0	63.64	0	0	13.4
2014	9	20	11	2	18	32	0	0	0	0	0	0	0	63.79	0	0	13.4
2014	9	20	11	12	18	33	0	0	0	0	0	0	0	63.97	0	0	13.2
2014	9	20	11	22	18	32	0	0	0	0	0	0	0	64.35	0	0	13.2
2014	9	20	11	32	18	32	0	0	0	0	0	0	0	65.14	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	11	42	18	32	0	0	0	0	0	0	0	65.44	0	0	13.4
2014	9	20	11	52	18	31	0	0	0	0	0	0	0	65.73	0	0	13.2
2014	9	20	12	2	18	33	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	9	20	12	12	18	32	0	0	0	0	0	0	0	66.29	0	0	13.2
2014	9	20	12	22	18	32	0	0	0	0	0	0	0	66.6	0	0	13.2
2014	9	20	12	32	18	32	0	0	0	0	0	0	0	66.85	0	0	13.2
2014	9	20	12	42	18	32	0	0	0	0	0	0	0	67.12	0	0	13.2
2014	9	20	12	52	18	32	0	0	0	0	0	0	0	67.39	0	0	13.2
2014	9	20	13	2	18	32	0	0	0	0	0	0	0	67.64	0	0	13.2
2014	9	20	13	12	18	32	0	0	0	0	0	0	0	67.98	0	0	13.2
2014	9	20	13	22	18	32	0	0	0	0	0	0	0	68.09	0	0	13.2
2014	9	20	13	32	18	32	0	0	0	0	0	0	0	68.09	0	0	12.8
2014	9	20	13	42	18	32	0	0	0	0	0	0	0	68.29	0	0	12.8
2014	9	20	13	52	18	32	0	0	0	0	0	0	0	68.38	0	0	12.6
2014	9	20	14	2	18	32	0	0	0	0	0	0	0	68.54	0	0	12.8
2014	9	20	14	12	18	32	0	0	0	0	0	0	0	68.94	0	0	13.4
2014	9	20	14	22	18	31	0	0	0	0	0	0	0	69.06	0	0	13
2014	9	20	14	32	18	32	0	0	0	0	0	0	0	69.19	0	0	13
2014	9	20	14	42	18	31	0	0	0	0	0	0	0	69.37	0	0	13.2
2014	9	20	14	52	18	32	0	0	0	0	0	0	0	69.69	0	0	13.4
2014	9	20	15	2	18	31	0	0	0	0	0	0	0	69.89	0	0	13.2
2014	9	20	15	12	18	31	0	0	0	0	0	0	0	70.14	0	0	13.4
2014	9	20	15	22	18	31	0	0	0	0	0	0	0	70.36	0	0	13.2
2014	9	20	15	32	18	31	0	0	0	0	0	0	0	70.57	0	0	13.2
2014	9	20	15	42	18	31	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	9	20	15	52	18	31	0	0	0	0	0	0	0	70.99	0	0	13.2
2014	9	20	16	2	18	31	0	0	0	0	0	0	0	71.15	0	0	13.2
2014	9	20	16	12	18	32	0	0	0	0	0	0	0	71.28	0	0	12.8
2014	9	20	16	22	18	32	0	0	0	0	0	0	0	71.22	0	0	12.4
2014	9	20	16	32	18	31	0	0	0	0	0	0	0	71.24	0	0	12.4
2014	9	20	16	42	18	31	0	0	0	0	0	0	0	71.33	0	0	12.4
2014	9	20	16	52	18	31	0	0	0	0	0	0	0	71.26	0	0	12.4
2014	9	20	17	2	18	31	0	0	0	0	0	0	0	71.2	0	0	12.2
2014	9	20	17	12	18	31	0	0	0	0	0	0	0	71.17	0	0	12.4
2014	9	20	17	22	18	31	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	9	20	17	32	18	31	0	0	0	0	0	0	0	71.06	0	0	12.2
2014	9	20	17	42	18	31	0	0	0	0	0	0	0	70.99	0	0	12.2
2014	9	20	17	52	18	32	0	0	0	0	0	0	0	70.9	0	0	12.2
2014	9	20	18	2	18	32	0	0	0	0	0	0	0	70.84	0	0	12.2
2014	9	20	18	12	18	32	0	0	0	0	0	0	0	70.77	0	0	12.2
2014	9	20	18	22	18	31	0	0	0	0	0	0	0	70.68	0	0	12
2014	9	20	18	32	18	31	0	0	0	0	0	0	0	70.59	0	0	12.2
2014	9	20	18	42	18	31	0	0	0	0	0	0	0	70.5	0	0	12.2
2014	9	20	18	52	18	31	0	0	0	0	0	0	0	70.39	0	0	12.2
2014	9	20	19	2	18	32	0	0	0	0	0	0	0	70.3	0	0	12.2
2014	9	20	19	12	18	32	0	0	0	0	0	0	0	70.21	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	19	22	18	31	0	0	0	0	0	0	0	70.11	0	0	12
2014	9	20	19	32	18	31	0	0	0	0	0	0	0	70	0	0	12.2
2014	9	20	19	42	18	32	0	0	0	0	0	0	0	69.91	0	0	12
2014	9	20	19	52	18	32	0	0	0	0	0	0	0	69.82	0	0	12
2014	9	20	20	2	18	32	0	0	0	0	0	0	0	69.71	0	0	12
2014	9	20	20	12	18	31	0	0	0	0	0	0	0	69.58	0	0	12
2014	9	20	20	22	18	31	0	0	0	0	0	0	0	69.46	0	0	12
2014	9	20	20	32	18	32	0	0	0	0	0	0	0	69.31	0	0	12
2014	9	20	20	42	18	31	0	0	0	0	0	0	0	69.15	0	0	12
2014	9	20	20	52	18	32	0	0	0	0	0	0	0	68.95	0	0	12
2014	9	20	21	2	18	31	0	0	0	0	0	0	0	68.77	0	0	12
2014	9	20	21	12	18	32	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	20	21	22	18	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	20	21	32	18	32	0	0	0	0	0	0	0	68.2	0	0	12
2014	9	20	21	42	18	31	0	0	0	0	0	0	0	68.02	0	0	12
2014	9	20	21	52	18	31	0	0	0	0	0	0	0	67.84	0	0	12
2014	9	20	22	2	18	31	0	0	0	0	0	0	0	67.68	0	0	12
2014	9	20	22	12	18	32	0	0	0	0	0	0	0	67.51	0	0	12
2014	9	20	22	22	18	32	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	20	22	32	18	32	0	0	0	0	0	0	0	67.24	0	0	12
2014	9	20	22	42	18	31	0	0	0	0	0	0	0	67.12	0	0	12
2014	9	20	22	52	18	32	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	20	23	2	18	31	0	0	0	0	0	0	0	66.92	0	0	12
2014	9	20	23	12	18	32	0	0	0	0	0	0	0	66.81	0	0	12
2014	9	20	23	22	18	32	0	0	0	0	0	0	0	66.74	0	0	12
2014	9	20	23	32	18	31	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	20	23	42	18	32	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	20	23	52	18	32	0	0	0	0	0	0	0	66.47	0	0	12
2014	9	21	0	2	18	32	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	21	0	12	18	32	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	21	0	22	18	31	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	21	0	32	18	32	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	21	0	42	18	32	0	0	0	0	0	0	0	66.13	0	0	12
2014	9	21	0	52	18	32	0	0	0	0	0	0	0	66.07	0	0	12
2014	9	21	1	2	18	31	0	0	0	0	0	0	0	66	0	0	12
2014	9	21	1	12	18	32	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	21	1	22	18	32	0	0	0	0	0	0	0	65.89	0	0	11.8
2014	9	21	1	32	18	32	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	21	1	42	18	32	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	21	1	52	18	32	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	21	2	2	18	32	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	21	2	12	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	21	2	22	18	32	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	21	2	32	18	31	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	21	2	42	18	32	0	0	0	0	0	0	0	65.5	0	0	12
2014	9	21	2	52	18	32	0	0	0	0	0	0	0	65.44	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	3	2	18	32	0	0	0	0	0	0	0	65.41	0	0	12
2014	9	21	3	12	18	31	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	21	3	22	18	32	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	9	21	3	32	18	32	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	21	3	42	18	32	0	0	0	0	0	0	0	65.28	0	0	12
2014	9	21	3	52	18	32	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	21	4	2	18	32	0	0	0	0	0	0	0	65.17	0	0	12
2014	9	21	4	12	18	32	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	21	4	22	18	33	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	21	4	32	18	32	0	0	0	0	0	0	0	64.96	0	0	12
2014	9	21	4	42	18	32	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	21	4	52	18	31	0	0	0	0	0	0	0	64.83	0	0	12
2014	9	21	5	2	18	32	0	0	0	0	0	0	0	64.76	0	0	12
2014	9	21	5	12	18	32	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	21	5	22	18	33	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	21	5	32	18	32	0	0	0	0	0	0	0	64.53	0	0	12
2014	9	21	5	42	18	32	0	0	0	0	0	0	0	64.44	0	0	12
2014	9	21	5	52	18	32	0	0	0	0	0	0	0	64.36	0	0	12
2014	9	21	6	2	18	32	0	0	0	0	0	0	0	64.29	0	0	12
2014	9	21	6	12	18	32	0	0	0	0	0	0	0	64.24	0	0	12
2014	9	21	6	22	18	32	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	21	6	32	18	32	0	0	0	0	0	0	0	64.08	0	0	11.8
2014	9	21	6	42	18	32	0	0	0	0	0	0	0	64.02	0	0	12
2014	9	21	6	52	18	32	0	0	0	0	0	0	0	63.93	0	0	12
2014	9	21	7	2	18	33	0	0	0	0	0	0	0	63.86	0	0	12
2014	9	21	7	12	18	32	0	0	0	0	0	0	0	63.79	0	0	12
2014	9	21	7	22	18	32	0	0	0	0	0	0	0	63.72	0	0	11.8
2014	9	21	7	32	18	33	0	0	0	0	0	0	0	63.64	0	0	12
2014	9	21	7	42	18	32	0	0	0	0	0	0	0	63.59	0	0	12.4
2014	9	21	7	52	18	33	0	0	0	0	0	0	0	63.54	0	0	12.4
2014	9	21	8	2	18	32	0	0	0	0	0	0	0	63.48	0	0	12.6
2014	9	21	8	12	18	32	0	0	0	0	0	0	0	63.45	0	0	13
2014	9	21	8	22	18	33	0	0	0	0	0	0	0	63.43	0	0	13
2014	9	21	8	32	18	32	0	0	0	0	0	0	0	63.41	0	0	13.2
2014	9	21	8	42	18	32	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	21	8	52	18	32	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	21	9	2	18	32	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	21	9	12	18	31	0	0	0	0	0	0	0	63.41	0	0	13.4
2014	9	21	9	22	18	32	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	21	9	32	18	32	0	0	0	0	0	0	0	63.75	0	0	13.4
2014	9	21	9	42	18	32	0	0	0	0	0	0	0	64.24	0	0	13.6
2014	9	21	9	52	18	32	0	0	0	0	0	0	0	64.38	0	0	13.6
2014	9	21	10	2	18	32	0	0	0	0	0	0	0	64.56	0	0	13.6
2014	9	21	10	12	18	32	0	0	0	0	0	0	0	64.65	0	0	13.6
2014	9	21	10	22	18	32	0	0	0	0	0	0	0	64.78	0	0	13.4
2014	9	21	10	32	18	32	0	0	0	0	0	0	0	64.13	0	0	13.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	10	42	18	32	0	0	0	0	0	0	0	64.13	0	0	13.6
2014	9	21	10	52	18	33	0	0	0	0	0	0	0	64.22	0	0	13.6
2014	9	21	11	2	18	32	0	0	0	0	0	0	0	64.36	0	0	13.4
2014	9	21	11	12	18	31	0	0	0	0	0	0	0	64.54	0	0	13.4
2014	9	21	11	22	18	32	0	0	0	0	0	0	0	65.16	0	0	13.4
2014	9	21	11	32	18	32	0	0	0	0	0	0	0	65.79	0	0	13.4
2014	9	21	11	42	18	33	0	0	0	0	0	0	0	66.13	0	0	13.4
2014	9	21	11	52	18	31	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	9	21	12	2	18	32	0	0	0	0	0	0	0	66.79	0	0	13.4
2014	9	21	12	12	18	32	0	0	0	0	0	0	0	66.97	0	0	13.4
2014	9	21	12	22	18	32	0	0	0	0	0	0	0	67.23	0	0	13.2
2014	9	21	12	32	18	32	0	0	0	0	0	0	0	67.19	0	0	13.2
2014	9	21	12	42	18	32	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	21	12	52	18	31	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	21	13	2	18	31	0	0	0	0	0	0	0	67.51	0	0	12.8
2014	9	21	13	12	18	32	0	0	0	0	0	0	0	67.75	0	0	12.8
2014	9	21	13	22	18	32	0	0	0	0	0	0	0	68.4	0	0	13.4
2014	9	21	13	32	18	31	0	0	0	0	0	0	0	68.72	0	0	13.4
2014	9	21	13	42	18	31	0	0	0	0	0	0	0	68.9	0	0	13.2
2014	9	21	13	52	18	32	0	0	0	0	0	0	0	69.24	0	0	13.4
2014	9	21	14	2	18	31	0	0	0	0	0	0	0	69.44	0	0	13.4
2014	9	21	14	12	18	31	0	0	0	0	0	0	0	69.89	0	0	13.4
2014	9	21	14	22	18	33	0	0	0	0	0	0	0	69.82	0	0	12.8
2014	9	21	14	32	18	31	0	0	0	0	0	0	0	70.2	0	0	13
2014	9	21	14	42	18	31	0	0	0	0	0	0	0	70.21	0	0	13
2014	9	21	14	52	18	32	0	0	0	0	0	0	0	70.5	0	0	13.2
2014	9	21	15	2	18	32	0	0	0	0	0	0	0	70.57	0	0	13.2
2014	9	21	15	12	18	31	0	0	0	0	0	0	0	70.84	0	0	13.2
2014	9	21	15	22	18	31	0	0	0	0	0	0	0	70.79	0	0	12.6
2014	9	21	15	32	18	31	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	9	21	15	42	18	31	0	0	0	0	0	0	0	71.31	0	0	13.4
2014	9	21	15	52	18	31	0	0	0	0	0	0	0	71.42	0	0	13.2
2014	9	21	16	2	18	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	9	21	16	12	18	31	0	0	0	0	0	0	0	71.71	0	0	13
2014	9	21	16	22	18	31	0	0	0	0	0	0	0	71.73	0	0	12.6
2014	9	21	16	32	18	31	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	9	21	16	42	18	31	0	0	0	0	0	0	0	71.85	0	0	12.6
2014	9	21	16	52	18	31	0	0	0	0	0	0	0	71.85	0	0	12.4
2014	9	21	17	2	18	31	0	0	0	0	0	0	0	71.78	0	0	12.4
2014	9	21	17	12	18	31	0	0	0	0	0	0	0	71.73	0	0	12.2
2014	9	21	17	22	18	31	0	0	0	0	0	0	0	71.74	0	0	12.2
2014	9	21	17	32	18	30	0	0	0	0	0	0	0	71.69	0	0	12.2
2014	9	21	17	42	18	31	0	0	0	0	0	0	0	71.64	0	0	12.2
2014	9	21	17	52	18	31	0	0	0	0	0	0	0	71.58	0	0	12.2
2014	9	21	18	2	18	31	0	0	0	0	0	0	0	71.55	0	0	12.2
2014	9	21	18	12	18	31	0	0	0	0	0	0	0	71.47	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	18	22	18	31	0	0	0	0	0	0	0	71.44	0	0	12
2014	9	21	18	32	18	31	0	0	0	0	0	0	0	71.38	0	0	12.2
2014	9	21	18	42	18	31	0	0	0	0	0	0	0	71.31	0	0	12.2
2014	9	21	18	52	18	32	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	9	21	19	2	18	31	0	0	0	0	0	0	0	71.11	0	0	12.2
2014	9	21	19	12	18	32	0	0	0	0	0	0	0	71.02	0	0	12.2
2014	9	21	19	22	18	31	0	0	0	0	0	0	0	70.92	0	0	12
2014	9	21	19	32	18	30	0	0	0	0	0	0	0	70.77	0	0	12
2014	9	21	19	42	18	31	0	0	0	0	0	0	0	70.65	0	0	12
2014	9	21	19	52	18	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	9	21	20	2	18	31	0	0	0	0	0	0	0	70.36	0	0	12
2014	9	21	20	12	18	31	0	0	0	0	0	0	0	70.21	0	0	12
2014	9	21	20	22	18	31	0	0	0	0	0	0	0	70.05	0	0	12
2014	9	21	20	32	18	31	0	0	0	0	0	0	0	69.87	0	0	12
2014	9	21	20	42	18	32	0	0	0	0	0	0	0	69.71	0	0	12
2014	9	21	20	52	18	31	0	0	0	0	0	0	0	69.53	0	0	12
2014	9	21	21	2	18	32	0	0	0	0	0	0	0	69.35	0	0	12
2014	9	21	21	12	18	31	0	0	0	0	0	0	0	69.15	0	0	12
2014	9	21	21	22	18	32	0	0	0	0	0	0	0	68.95	0	0	12
2014	9	21	21	32	18	32	0	0	0	0	0	0	0	68.77	0	0	12
2014	9	21	21	42	18	31	0	0	0	0	0	0	0	68.59	0	0	12
2014	9	21	21	52	18	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	9	21	22	2	18	31	0	0	0	0	0	0	0	68.23	0	0	12
2014	9	21	22	12	18	32	0	0	0	0	0	0	0	68.05	0	0	12
2014	9	21	22	22	18	31	0	0	0	0	0	0	0	67.89	0	0	12
2014	9	21	22	32	18	31	0	0	0	0	0	0	0	67.75	0	0	12
2014	9	21	22	42	18	32	0	0	0	0	0	0	0	67.59	0	0	12
2014	9	21	22	52	18	32	0	0	0	0	0	0	0	67.46	0	0	12
2014	9	21	23	2	18	32	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	21	23	12	18	32	0	0	0	0	0	0	0	67.21	0	0	12
2014	9	21	23	22	18	32	0	0	0	0	0	0	0	67.08	0	0	12
2014	9	21	23	32	18	32	0	0	0	0	0	0	0	66.97	0	0	12
2014	9	21	23	42	18	32	0	0	0	0	0	0	0	66.87	0	0	12
2014	9	21	23	52	18	32	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	22	0	2	18	32	0	0	0	0	0	0	0	66.67	0	0	12
2014	9	22	0	12	18	32	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	22	0	22	18	32	0	0	0	0	0	0	0	66.51	0	0	11.8
2014	9	22	0	32	18	32	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	22	0	42	18	32	0	0	0	0	0	0	0	66.31	0	0	12
2014	9	22	0	52	18	32	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	22	1	2	18	32	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	22	1	12	18	31	0	0	0	0	0	0	0	66.09	0	0	12
2014	9	22	1	22	18	32	0	0	0	0	0	0	0	66.02	0	0	11.8
2014	9	22	1	32	18	32	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	22	1	42	18	31	0	0	0	0	0	0	0	65.88	0	0	12
2014	9	22	1	52	18	32	0	0	0	0	0	0	0	65.8	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	2	2	18	32	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	22	2	12	18	32	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	22	2	22	18	32	0	0	0	0	0	0	0	65.59	0	0	11.8
2014	9	22	2	32	18	32	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	22	2	42	18	31	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	22	2	52	18	32	0	0	0	0	0	0	0	65.41	0	0	12
2014	9	22	3	2	18	32	0	0	0	0	0	0	0	65.35	0	0	12
2014	9	22	3	12	18	32	0	0	0	0	0	0	0	65.28	0	0	12
2014	9	22	3	22	18	32	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	22	3	32	18	32	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	22	3	42	18	32	0	0	0	0	0	0	0	65.05	0	0	12
2014	9	22	3	52	18	31	0	0	0	0	0	0	0	64.98	0	0	12
2014	9	22	4	2	18	32	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	22	4	12	18	32	0	0	0	0	0	0	0	64.81	0	0	12
2014	9	22	4	22	18	32	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	22	4	32	18	32	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	22	4	42	18	32	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	22	4	52	18	32	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	22	5	2	18	32	0	0	0	0	0	0	0	64.38	0	0	11.8
2014	9	22	5	12	18	32	0	0	0	0	0	0	0	64.31	0	0	11.8
2014	9	22	5	22	18	32	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	22	5	32	18	32	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	22	5	42	18	32	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	22	5	52	18	32	0	0	0	0	0	0	0	63.95	0	0	11.8
2014	9	22	6	2	18	32	0	0	0	0	0	0	0	63.86	0	0	11.8
2014	9	22	6	12	18	32	0	0	0	0	0	0	0	63.75	0	0	11.8
2014	9	22	6	22	18	31	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	22	6	32	18	32	0	0	0	0	0	0	0	63.55	0	0	11.8
2014	9	22	6	42	18	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	6	52	18	32	0	0	0	0	0	0	0	63.36	0	0	11.8
2014	9	22	7	2	18	32	0	0	0	0	0	0	0	63.28	0	0	11.8
2014	9	22	7	12	18	32	0	0	0	0	0	0	0	63.19	0	0	11.8
2014	9	22	7	22	18	32	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	22	7	32	18	32	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	22	7	42	18	32	0	0	0	0	0	0	0	62.96	0	0	12.4
2014	9	22	7	52	18	32	0	0	0	0	0	0	0	62.91	0	0	12.8
2014	9	22	8	2	18	32	0	0	0	0	0	0	0	62.85	0	0	13
2014	9	22	8	12	18	32	0	0	0	0	0	0	0	62.82	0	0	13
2014	9	22	8	22	18	33	0	0	0	0	0	0	0	62.78	0	0	13
2014	9	22	8	32	18	32	0	0	0	0	0	0	0	62.76	0	0	13.2
2014	9	22	8	42	18	32	0	0	0	0	0	0	0	62.74	0	0	13.2
2014	9	22	8	52	18	32	0	0	0	0	0	0	0	62.74	0	0	13.4
2014	9	22	9	2	18	32	0	0	0	0	0	0	0	62.76	0	0	13.4
2014	9	22	9	12	18	32	0	0	0	0	0	0	0	62.78	0	0	13.4
2014	9	22	9	22	18	32	0	0	0	0	0	0	0	62.83	0	0	13.4
2014	9	22	9	32	18	32	0	0	0	0	0	0	0	62.94	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	9	42	18	33	0	0	0	0	0	0	0	63.66	0	0	13.4
2014	9	22	9	52	18	33	0	0	0	0	0	0	0	63.88	0	0	13.4
2014	9	22	10	2	18	32	0	0	0	0	0	0	0	64	0	0	13.4
2014	9	22	10	12	18	32	0	0	0	0	0	0	0	64.15	0	0	13.4
2014	9	22	10	22	18	32	0	0	0	0	0	0	0	64.17	0	0	13.4
2014	9	22	10	32	18	32	0	0	0	0	0	0	0	63.57	0	0	13.4
2014	9	22	10	42	18	32	0	0	0	0	0	0	0	63.59	0	0	13.4
2014	9	22	10	52	18	32	0	0	0	0	0	0	0	63.68	0	0	13.4
2014	9	22	11	2	18	32	0	0	0	0	0	0	0	63.82	0	0	13.4
2014	9	22	11	12	18	32	0	0	0	0	0	0	0	64	0	0	13.4
2014	9	22	11	22	18	33	0	0	0	0	0	0	0	64.83	0	0	13.2
2014	9	22	11	32	18	32	0	0	0	0	0	0	0	65.34	0	0	13.4
2014	9	22	11	42	18	32	0	0	0	0	0	0	0	65.64	0	0	13.4
2014	9	22	11	52	18	32	0	0	0	0	0	0	0	65.91	0	0	13.4
2014	9	22	12	2	18	31	0	0	0	0	0	0	0	66.11	0	0	13.4
2014	9	22	12	12	18	32	0	0	0	0	0	0	0	66.33	0	0	13.4
2014	9	22	12	22	18	32	0	0	0	0	0	0	0	66.6	0	0	13.4
2014	9	22	12	32	18	31	0	0	0	0	0	0	0	66.83	0	0	13.4
2014	9	22	12	42	18	33	0	0	0	0	0	0	0	67.06	0	0	13.4
2014	9	22	12	52	18	32	0	0	0	0	0	0	0	67.33	0	0	13.4
2014	9	22	13	2	18	31	0	0	0	0	0	0	0	67.59	0	0	13.4
2014	9	22	13	12	18	31	0	0	0	0	0	0	0	67.87	0	0	13.4
2014	9	22	13	22	18	31	0	0	0	0	0	0	0	68.13	0	0	13.2
2014	9	22	13	32	18	32	0	0	0	0	0	0	0	68.4	0	0	13.4
2014	9	22	13	42	18	32	0	0	0	0	0	0	0	68.67	0	0	13.4
2014	9	22	13	52	18	32	0	0	0	0	0	0	0	68.92	0	0	13.4
2014	9	22	14	2	18	31	0	0	0	0	0	0	0	69.15	0	0	13.4
2014	9	22	14	12	18	32	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	9	22	14	22	18	31	0	0	0	0	0	0	0	69.62	0	0	13.2
2014	9	22	14	32	18	31	0	0	0	0	0	0	0	69.87	0	0	13.2
2014	9	22	14	42	18	31	0	0	0	0	0	0	0	70.09	0	0	13.2
2014	9	22	14	52	18	31	0	0	0	0	0	0	0	70.3	0	0	13.2
2014	9	22	15	2	18	31	0	0	0	0	0	0	0	70.5	0	0	13.2
2014	9	22	15	12	18	32	0	0	0	0	0	0	0	70.68	0	0	13.2
2014	9	22	15	22	18	32	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	9	22	15	32	18	31	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	9	22	15	42	18	31	0	0	0	0	0	0	0	71.2	0	0	13.2
2014	9	22	15	52	18	31	0	0	0	0	0	0	0	71.37	0	0	13.2
2014	9	22	16	2	18	31	0	0	0	0	0	0	0	71.49	0	0	13
2014	9	22	16	12	18	32	0	0	0	0	0	0	0	71.6	0	0	13
2014	9	22	16	22	18	31	0	0	0	0	0	0	0	71.73	0	0	12.6
2014	9	22	16	32	18	31	0	0	0	0	0	0	0	71.82	0	0	12.6
2014	9	22	16	42	18	31	0	0	0	0	0	0	0	71.89	0	0	12.6
2014	9	22	16	52	18	31	0	0	0	0	0	0	0	71.96	0	0	12.4
2014	9	22	17	2	18	30	0	0	0	0	0	0	0	72	0	0	12.4
2014	9	22	17	12	18	31	0	0	0	0	0	0	0	72.03	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	17	22	18	31	0	0	0	0	0	0	0	72.05	0	0	12.2
2014	9	22	17	32	18	31	0	0	0	0	0	0	0	72.03	0	0	12.2
2014	9	22	17	42	18	31	0	0	0	0	0	0	0	72.03	0	0	12.2
2014	9	22	17	52	18	31	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	9	22	18	2	18	31	0	0	0	0	0	0	0	72	0	0	12.2
2014	9	22	18	12	18	32	0	0	0	0	0	0	0	71.98	0	0	12.2
2014	9	22	18	22	18	32	0	0	0	0	0	0	0	71.92	0	0	12
2014	9	22	18	32	18	32	0	0	0	0	0	0	0	71.87	0	0	12.2
2014	9	22	18	42	18	31	0	0	0	0	0	0	0	71.83	0	0	12.2
2014	9	22	18	52	18	32	0	0	0	0	0	0	0	71.74	0	0	12.2
2014	9	22	19	2	18	31	0	0	0	0	0	0	0	71.69	0	0	12.2
2014	9	22	19	12	18	30	0	0	0	0	0	0	0	71.6	0	0	12.2
2014	9	22	19	22	18	30	0	0	0	0	0	0	0	71.49	0	0	12
2014	9	22	19	32	18	30	0	0	0	0	0	0	0	71.38	0	0	12.2
2014	9	22	19	42	18	32	0	0	0	0	0	0	0	71.28	0	0	12.2
2014	9	22	19	52	18	31	0	0	0	0	0	0	0	71.17	0	0	12.2
2014	9	22	20	2	18	32	0	0	0	0	0	0	0	71.02	0	0	12.2
2014	9	22	20	12	18	32	0	0	0	0	0	0	0	70.88	0	0	12
2014	9	22	20	22	18	31	0	0	0	0	0	0	0	70.74	0	0	12
2014	9	22	20	32	18	31	0	0	0	0	0	0	0	70.59	0	0	12
2014	9	22	20	42	18	31	0	0	0	0	0	0	0	70.43	0	0	12
2014	9	22	20	52	18	31	0	0	0	0	0	0	0	70.25	0	0	12
2014	9	22	21	2	18	32	0	0	0	0	0	0	0	70.05	0	0	12
2014	9	22	21	12	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	9	22	21	22	18	31	0	0	0	0	0	0	0	69.64	0	0	12
2014	9	22	21	32	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	9	22	21	42	18	32	0	0	0	0	0	0	0	69.21	0	0	12
2014	9	22	21	52	18	32	0	0	0	0	0	0	0	68.99	0	0	12
2014	9	22	22	2	18	33	0	0	0	0	0	0	0	68.77	0	0	12
2014	9	22	22	12	18	31	0	0	0	0	0	0	0	68.56	0	0	12
2014	9	22	22	22	18	31	0	0	0	0	0	0	0	68.34	0	0	12
2014	9	22	22	32	18	33	0	0	0	0	0	0	0	68.13	0	0	12
2014	9	22	22	42	18	31	0	0	0	0	0	0	0	67.93	0	0	12
2014	9	22	22	52	18	32	0	0	0	0	0	0	0	67.69	0	0	12
2014	9	22	23	2	18	31	0	0	0	0	0	0	0	67.51	0	0	12
2014	9	22	23	12	18	32	0	0	0	0	0	0	0	67.3	0	0	12
2014	9	22	23	22	18	32	0	0	0	0	0	0	0	67.12	0	0	12
2014	9	22	23	32	18	32	0	0	0	0	0	0	0	66.94	0	0	12
2014	9	22	23	42	18	32	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	22	23	52	18	32	0	0	0	0	0	0	0	66.6	0	0	12
2014	9	23	0	2	18	32	0	0	0	0	0	0	0	66.45	0	0	12
2014	9	23	0	12	18	32	0	0	0	0	0	0	0	66.29	0	0	12
2014	9	23	0	22	18	32	0	0	0	0	0	0	0	66.16	0	0	12
2014	9	23	0	32	18	31	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	23	0	42	18	32	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	23	0	52	18	31	0	0	0	0	0	0	0	65.79	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	1	2	18	31	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	23	1	12	18	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	23	1	22	18	32	0	0	0	0	0	0	0	65.5	0	0	11.8
2014	9	23	1	32	18	32	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	23	1	42	18	31	0	0	0	0	0	0	0	65.3	0	0	12
2014	9	23	1	52	18	33	0	0	0	0	0	0	0	65.19	0	0	12
2014	9	23	2	2	18	32	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	23	2	12	18	32	0	0	0	0	0	0	0	65.01	0	0	12
2014	9	23	2	22	18	32	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	23	2	32	18	32	0	0	0	0	0	0	0	64.81	0	0	12
2014	9	23	2	42	18	32	0	0	0	0	0	0	0	64.74	0	0	12
2014	9	23	2	52	18	32	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	23	3	2	18	33	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	23	3	12	18	32	0	0	0	0	0	0	0	64.47	0	0	12
2014	9	23	3	22	18	32	0	0	0	0	0	0	0	64.4	0	0	11.8
2014	9	23	3	32	18	32	0	0	0	0	0	0	0	64.31	0	0	12
2014	9	23	3	42	18	32	0	0	0	0	0	0	0	64.24	0	0	12
2014	9	23	3	52	18	32	0	0	0	0	0	0	0	64.17	0	0	12
2014	9	23	4	2	18	32	0	0	0	0	0	0	0	64.09	0	0	12
2014	9	23	4	12	18	32	0	0	0	0	0	0	0	64.02	0	0	12
2014	9	23	4	22	18	32	0	0	0	0	0	0	0	63.95	0	0	11.8
2014	9	23	4	32	18	32	0	0	0	0	0	0	0	63.88	0	0	12
2014	9	23	4	42	18	32	0	0	0	0	0	0	0	63.81	0	0	11.8
2014	9	23	4	52	18	33	0	0	0	0	0	0	0	63.73	0	0	11.8
2014	9	23	5	2	18	32	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	23	5	12	18	32	0	0	0	0	0	0	0	63.57	0	0	11.8
2014	9	23	5	22	18	32	0	0	0	0	0	0	0	63.48	0	0	11.8
2014	9	23	5	32	18	31	0	0	0	0	0	0	0	63.41	0	0	11.8
2014	9	23	5	42	18	32	0	0	0	0	0	0	0	63.34	0	0	11.8
2014	9	23	5	52	18	32	0	0	0	0	0	0	0	63.25	0	0	11.8
2014	9	23	6	2	18	33	0	0	0	0	0	0	0	63.18	0	0	11.8
2014	9	23	6	12	18	33	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	23	6	22	18	32	0	0	0	0	0	0	0	63.01	0	0	11.8
2014	9	23	6	32	18	32	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	23	6	42	18	32	0	0	0	0	0	0	0	62.85	0	0	11.8
2014	9	23	6	52	18	32	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	23	7	2	18	32	0	0	0	0	0	0	0	62.71	0	0	11.8
2014	9	23	7	12	18	32	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	7	22	18	32	0	0	0	0	0	0	0	62.56	0	0	11.8
2014	9	23	7	32	18	32	0	0	0	0	0	0	0	62.49	0	0	11.8
2014	9	23	7	42	18	32	0	0	0	0	0	0	0	62.44	0	0	12.6
2014	9	23	7	52	18	32	0	0	0	0	0	0	0	62.38	0	0	12.8
2014	9	23	8	2	18	32	0	0	0	0	0	0	0	62.35	0	0	13
2014	9	23	8	12	18	32	0	0	0	0	0	0	0	62.33	0	0	13.2
2014	9	23	8	22	18	32	0	0	0	0	0	0	0	62.29	0	0	13
2014	9	23	8	32	18	32	0	0	0	0	0	0	0	62.29	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	8	42	18	33	0	0	0	0	0	0	0	62.31	0	0	13.4
2014	9	23	8	52	18	32	0	0	0	0	0	0	0	62.33	0	0	13.4
2014	9	23	9	2	18	33	0	0	0	0	0	0	0	62.37	0	0	13.4
2014	9	23	9	12	18	33	0	0	0	0	0	0	0	62.4	0	0	13.6
2014	9	23	9	22	18	32	0	0	0	0	0	0	0	62.47	0	0	13.4
2014	9	23	9	32	18	33	0	0	0	0	0	0	0	62.55	0	0	13.6
2014	9	23	9	42	18	33	0	0	0	0	0	0	0	63.36	0	0	13.6
2014	9	23	9	52	18	32	0	0	0	0	0	0	0	63.57	0	0	13.6
2014	9	23	10	2	18	32	0	0	0	0	0	0	0	63.77	0	0	13.6
2014	9	23	10	12	18	33	0	0	0	0	0	0	0	63.9	0	0	13.6
2014	9	23	10	22	18	32	0	0	0	0	0	0	0	63.72	0	0	13.4
2014	9	23	10	32	18	31	0	0	0	0	0	0	0	63.3	0	0	13.4
2014	9	23	10	42	18	33	0	0	0	0	0	0	0	63.34	0	0	13.4
2014	9	23	10	52	18	32	0	0	0	0	0	0	0	63.45	0	0	13.4
2014	9	23	11	2	18	32	0	0	0	0	0	0	0	63.59	0	0	13.4
2014	9	23	11	12	18	32	0	0	0	0	0	0	0	63.77	0	0	13.4
2014	9	23	11	22	18	33	0	0	0	0	0	0	0	64.69	0	0	13.4
2014	9	23	11	32	18	33	0	0	0	0	0	0	0	65.1	0	0	13.4
2014	9	23	11	54	10	32	0	0	0	0	0	0	0	65.62	0	0	13.4
2014	9	23	12	4	10	33	0	0	0	0	0	0	0	65.84	0	0	13.4
2014	9	23	12	14	10	32	0	0	0	0	0	0	0	66.04	0	0	13.4
2014	9	23	12	24	10	32	0	0	0	0	0	0	0	66.27	0	0	13.4
2014	9	23	12	34	10	33	0	0	0	0	0	0	0	66.49	0	0	13.4
2014	9	23	12	44	10	32	0	0	0	0	0	0	0	66.74	0	0	13.4
2014	9	23	12	54	10	31	0	0	0	0	0	0	0	67.03	0	0	13.4
2014	9	23	13	4	10	32	0	0	0	0	0	0	0	67.28	0	0	13.4
2014	9	23	13	14	10	32	0	0	0	0	0	0	0	67.57	0	0	13.4
2014	9	23	13	24	10	32	0	0	0	0	0	0	0	67.8	0	0	13.4
2014	9	23	13	34	10	31	0	0	0	0	0	0	0	68.07	0	0	13.4
2014	9	23	13	44	10	32	0	0	0	0	0	0	0	68.31	0	0	13.4
2014	9	23	13	54	10	31	0	0	0	0	0	0	0	68.58	0	0	13.4
2014	9	23	14	4	10	31	0	0	0	0	0	0	0	68.79	0	0	13.4
2014	9	23	14	14	10	32	0	0	0	0	0	0	0	69.01	0	0	13.4
2014	9	23	14	24	10	32	0	0	0	0	0	0	0	69.24	0	0	13.2
2014	9	23	14	34	10	32	0	0	0	0	0	0	0	69.46	0	0	13.2
2014	9	23	14	44	10	32	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	9	23	14	54	10	31	0	0	0	0	0	0	0	69.87	0	0	13.2
2014	9	23	15	4	10	32	0	0	0	0	0	0	0	70.05	0	0	13.2
2014	9	23	15	14	10	31	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	9	23	15	24	10	32	0	0	0	0	0	0	0	70.43	0	0	13
2014	9	23	15	34	10	32	0	0	0	0	0	0	0	70.57	0	0	13.2
2014	9	23	15	44	10	31	0	0	0	0	0	0	0	70.75	0	0	13.2
2014	9	23	15	54	10	31	0	0	0	0	0	0	0	70.86	0	0	13.2
2014	9	23	16	4	10	31	0	0	0	0	0	0	0	70.97	0	0	13
2014	9	23	16	14	10	32	0	0	0	0	0	0	0	71.08	0	0	13
2014	9	23	16	24	10	31	0	0	0	0	0	0	0	71.17	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	16	34	10	31	0	0	0	0	0	0	0	71.22	0	0	12.6
2014	9	23	16	44	10	32	0	0	0	0	0	0	0	71.28	0	0	12.6
2014	9	23	16	54	10	31	0	0	0	0	0	0	0	71.31	0	0	12.4
2014	9	23	17	4	10	31	0	0	0	0	0	0	0	71.33	0	0	12.4
2014	9	23	17	14	10	32	0	0	0	0	0	0	0	71.33	0	0	12.2
2014	9	23	17	24	10	31	0	0	0	0	0	0	0	71.35	0	0	12.2
2014	9	23	17	34	10	32	0	0	0	0	0	0	0	71.31	0	0	12.2
2014	9	23	17	44	10	31	0	0	0	0	0	0	0	71.26	0	0	12.2
2014	9	23	17	54	10	32	0	0	0	0	0	0	0	71.24	0	0	12.2
2014	9	23	18	4	10	31	0	0	0	0	0	0	0	71.2	0	0	12.2
2014	9	23	18	14	10	31	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	9	23	18	24	10	32	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	9	23	18	34	10	31	0	0	0	0	0	0	0	71.01	0	0	12.2
2014	9	23	18	44	10	31	0	0	0	0	0	0	0	70.92	0	0	12.2
2014	9	23	18	54	10	31	0	0	0	0	0	0	0	70.81	0	0	12.2
2014	9	23	19	4	10	32	0	0	0	0	0	0	0	70.7	0	0	12.2
2014	9	23	19	14	10	32	0	0	0	0	0	0	0	70.57	0	0	12.2
2014	9	23	19	24	10	32	0	0	0	0	0	0	0	70.45	0	0	12
2014	9	23	19	34	10	32	0	0	0	0	0	0	0	70.3	0	0	12.2
2014	9	23	19	44	10	31	0	0	0	0	0	0	0	70.16	0	0	12.2
2014	9	23	19	54	10	31	0	0	0	0	0	0	0	70	0	0	12.2
2014	9	23	20	4	10	31	0	0	0	0	0	0	0	69.84	0	0	12.2
2014	9	23	20	14	10	32	0	0	0	0	0	0	0	69.69	0	0	12.2
2014	9	23	20	24	10	32	0	0	0	0	0	0	0	69.51	0	0	12
2014	9	23	20	34	10	31	0	0	0	0	0	0	0	69.33	0	0	12
2014	9	23	20	44	10	31	0	0	0	0	0	0	0	69.12	0	0	12
2014	9	23	20	54	10	32	0	0	0	0	0	0	0	68.92	0	0	12
2014	9	23	21	4	10	32	0	0	0	0	0	0	0	68.7	0	0	12
2014	9	23	21	14	10	32	0	0	0	0	0	0	0	68.47	0	0	12
2014	9	23	21	24	10	32	0	0	0	0	0	0	0	68.23	0	0	12
2014	9	23	21	34	10	32	0	0	0	0	0	0	0	68	0	0	12
2014	9	23	21	44	10	31	0	0	0	0	0	0	0	67.73	0	0	12
2014	9	23	21	54	10	31	0	0	0	0	0	0	0	67.5	0	0	12
2014	9	23	22	4	10	31	0	0	0	0	0	0	0	67.26	0	0	12
2014	9	23	22	14	10	32	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	23	22	24	10	32	0	0	0	0	0	0	0	66.79	0	0	12
2014	9	23	22	34	10	32	0	0	0	0	0	0	0	66.6	0	0	12
2014	9	23	22	44	10	32	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	23	22	54	10	32	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	23	23	4	10	31	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	23	23	14	10	31	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	23	23	24	10	32	0	0	0	0	0	0	0	65.62	0	0	12
2014	9	23	23	34	10	31	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	23	23	44	10	32	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	23	23	54	10	32	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	24	0	4	10	32	0	0	0	0	0	0	0	65.01	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	0	14	10	32	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	24	0	24	10	32	0	0	0	0	0	0	0	64.72	0	0	12
2014	9	24	0	34	10	31	0	0	0	0	0	0	0	64.6	0	0	12
2014	9	24	0	44	10	33	0	0	0	0	0	0	0	64.47	0	0	12
2014	9	24	0	54	10	32	0	0	0	0	0	0	0	64.36	0	0	12
2014	9	24	1	4	10	31	0	0	0	0	0	0	0	64.24	0	0	12
2014	9	24	1	14	10	33	0	0	0	0	0	0	0	64.13	0	0	12
2014	9	24	1	24	10	33	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	24	1	34	10	32	0	0	0	0	0	0	0	63.91	0	0	12
2014	9	24	1	44	10	32	0	0	0	0	0	0	0	63.81	0	0	12
2014	9	24	1	54	10	33	0	0	0	0	0	0	0	63.72	0	0	12
2014	9	24	2	4	10	31	0	0	0	0	0	0	0	63.63	0	0	12
2014	9	24	2	14	10	33	0	0	0	0	0	0	0	63.54	0	0	12
2014	9	24	2	24	10	32	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	24	2	34	10	33	0	0	0	0	0	0	0	63.39	0	0	12
2014	9	24	2	44	10	32	0	0	0	0	0	0	0	63.3	0	0	12
2014	9	24	2	54	10	32	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	24	3	4	10	32	0	0	0	0	0	0	0	63.14	0	0	12
2014	9	24	3	14	10	31	0	0	0	0	0	0	0	63.07	0	0	12
2014	9	24	3	24	10	32	0	0	0	0	0	0	0	62.98	0	0	12
2014	9	24	3	34	10	32	0	0	0	0	0	0	0	62.92	0	0	12
2014	9	24	3	44	10	33	0	0	0	0	0	0	0	62.85	0	0	12
2014	9	24	3	54	10	32	0	0	0	0	0	0	0	62.78	0	0	12
2014	9	24	4	4	10	32	0	0	0	0	0	0	0	62.71	0	0	12
2014	9	24	4	14	10	31	0	0	0	0	0	0	0	62.62	0	0	12
2014	9	24	4	24	10	33	0	0	0	0	0	0	0	62.55	0	0	11.8
2014	9	24	4	34	10	33	0	0	0	0	0	0	0	62.46	0	0	12
2014	9	24	4	44	10	32	0	0	0	0	0	0	0	62.38	0	0	11.8
2014	9	24	4	54	10	32	0	0	0	0	0	0	0	62.29	0	0	11.8
2014	9	24	5	4	10	32	0	0	0	0	0	0	0	62.2	0	0	11.8
2014	9	24	5	14	10	33	0	0	0	0	0	0	0	62.1	0	0	11.8
2014	9	24	5	24	10	32	0	0	0	0	0	0	0	62.01	0	0	11.8
2014	9	24	5	34	10	31	0	0	0	0	0	0	0	61.92	0	0	11.8
2014	9	24	5	44	10	33	0	0	0	0	0	0	0	61.81	0	0	11.8
2014	9	24	5	54	10	33	0	0	0	0	0	0	0	61.7	0	0	11.8
2014	9	24	6	4	10	32	0	0	0	0	0	0	0	61.63	0	0	11.8
2014	9	24	6	14	10	33	0	0	0	0	0	0	0	61.52	0	0	11.8
2014	9	24	6	24	10	32	0	0	0	0	0	0	0	61.41	0	0	11.8
2014	9	24	6	34	10	32	0	0	0	0	0	0	0	61.32	0	0	11.8
2014	9	24	6	44	10	32	0	0	0	0	0	0	0	61.23	0	0	11.8
2014	9	24	6	54	10	32	0	0	0	0	0	0	0	61.16	0	0	11.8
2014	9	24	7	4	10	33	0	0	0	0	0	0	0	61.05	0	0	11.8
2014	9	24	7	14	10	33	0	0	0	0	0	0	0	60.94	0	0	11.8
2014	9	24	7	24	10	33	0	0	0	0	0	0	0	60.85	0	0	11.8
2014	9	24	7	34	10	32	0	0	0	0	0	0	0	60.76	0	0	11.8
2014	9	24	7	44	10	33	0	0	0	0	0	0	0	60.67	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	7	54	10	33	0	0	0	0	0	0	0	60.6	0	0	12.8
2014	9	24	8	4	10	32	0	0	0	0	0	0	0	60.55	0	0	13
2014	9	24	8	14	10	32	0	0	0	0	0	0	0	60.51	0	0	13.2
2014	9	24	8	24	10	32	0	0	0	0	0	0	0	60.46	0	0	13.2
2014	9	24	8	34	10	33	0	0	0	0	0	0	0	60.44	0	0	13.4
2014	9	24	8	44	10	33	0	0	0	0	0	0	0	60.44	0	0	13.4
2014	9	24	8	54	10	33	0	0	0	0	0	0	0	60.46	0	0	13.4
2014	9	24	9	4	10	33	0	0	0	0	0	0	0	60.48	0	0	13.6
2014	9	24	9	14	10	33	0	0	0	0	0	0	0	60.51	0	0	13.6
2014	9	24	9	24	10	33	0	0	0	0	0	0	0	60.55	0	0	13.6
2014	9	24	9	34	10	32	0	0	0	0	0	0	0	60.6	0	0	13.6
2014	9	24	9	44	10	33	0	0	0	0	0	0	0	61.12	0	0	13.4
2014	9	24	9	54	10	32	0	0	0	0	0	0	0	61.48	0	0	13.4
2014	9	24	10	4	10	32	0	0	0	0	0	0	0	61.63	0	0	13.4
2014	9	24	10	14	10	32	0	0	0	0	0	0	0	61.83	0	0	13.4
2014	9	24	10	24	10	33	0	0	0	0	0	0	0	61.41	0	0	13.4
2014	9	24	10	34	10	33	0	0	0	0	0	0	0	61.29	0	0	13.4
2014	9	24	10	44	10	33	0	0	0	0	0	0	0	61.36	0	0	13.4
2014	9	24	10	54	10	32	0	0	0	0	0	0	0	61.5	0	0	13.4
2014	9	24	11	4	10	32	0	0	0	0	0	0	0	61.68	0	0	13.4
2014	9	24	11	14	10	32	0	0	0	0	0	0	0	61.9	0	0	13.4
2014	9	24	11	24	10	33	0	0	0	0	0	0	0	62.82	0	0	13.2
2014	9	24	11	34	10	33	0	0	0	0	0	0	0	63.14	0	0	13.4
2014	9	24	11	44	10	31	0	0	0	0	0	0	0	63.39	0	0	13.4
2014	9	24	11	54	10	32	0	0	0	0	0	0	0	63.63	0	0	13.4
2014	9	24	12	4	10	32	0	0	0	0	0	0	0	63.86	0	0	13.4
2014	9	24	12	14	10	32	0	0	0	0	0	0	0	64.11	0	0	13.4
2014	9	24	12	24	10	32	0	0	0	0	0	0	0	64.29	0	0	13.2
2014	9	24	12	34	10	32	0	0	0	0	0	0	0	64.58	0	0	13.4
2014	9	24	12	44	10	32	0	0	0	0	0	0	0	64.83	0	0	13.4
2014	9	24	12	54	10	32	0	0	0	0	0	0	0	65.07	0	0	13.4
2014	9	24	13	4	10	32	0	0	0	0	0	0	0	65.37	0	0	13.4
2014	9	24	13	14	10	32	0	0	0	0	0	0	0	65.62	0	0	13.4
2014	9	24	13	24	10	31	0	0	0	0	0	0	0	65.88	0	0	13.2
2014	9	24	13	34	10	31	0	0	0	0	0	0	0	66.16	0	0	13.4
2014	9	24	13	44	10	32	0	0	0	0	0	0	0	66.42	0	0	13.2
2014	9	24	13	54	10	31	0	0	0	0	0	0	0	66.7	0	0	13.2
2014	9	24	14	4	10	31	0	0	0	0	0	0	0	66.96	0	0	13.2
2014	9	24	14	14	10	32	0	0	0	0	0	0	0	67.21	0	0	13.2
2014	9	24	14	24	10	31	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	24	14	34	10	32	0	0	0	0	0	0	0	67.69	0	0	13.2
2014	9	24	14	44	10	31	0	0	0	0	0	0	0	67.91	0	0	13.2
2014	9	24	14	54	10	32	0	0	0	0	0	0	0	68.13	0	0	13.2
2014	9	24	15	4	10	31	0	0	0	0	0	0	0	68.32	0	0	13.2
2014	9	24	15	14	10	31	0	0	0	0	0	0	0	68.5	0	0	13.2
2014	9	24	15	24	10	32	0	0	0	0	0	0	0	68.65	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	15	34	10	31	0	0	0	0	0	0	0	68.79	0	0	13.2
2014	9	24	15	44	10	31	0	0	0	0	0	0	0	68.92	0	0	13.2
2014	9	24	15	54	10	31	0	0	0	0	0	0	0	69.03	0	0	13.2
2014	9	24	16	4	10	31	0	0	0	0	0	0	0	69.12	0	0	13
2014	9	24	16	14	10	31	0	0	0	0	0	0	0	69.21	0	0	13
2014	9	24	16	24	10	31	0	0	0	0	0	0	0	69.26	0	0	12.6
2014	9	24	16	34	10	31	0	0	0	0	0	0	0	69.31	0	0	12.6
2014	9	24	16	44	10	32	0	0	0	0	0	0	0	69.37	0	0	12.6
2014	9	24	16	54	10	32	0	0	0	0	0	0	0	69.37	0	0	12.4
2014	9	24	17	4	10	31	0	0	0	0	0	0	0	69.39	0	0	12.4
2014	9	24	17	14	10	32	0	0	0	0	0	0	0	69.39	0	0	12.2
2014	9	24	17	24	10	32	0	0	0	0	0	0	0	69.37	0	0	12.2
2014	9	24	17	34	10	31	0	0	0	0	0	0	0	69.31	0	0	12.2
2014	9	24	17	44	10	31	0	0	0	0	0	0	0	69.28	0	0	12.2
2014	9	24	17	54	10	31	0	0	0	0	0	0	0	69.22	0	0	12.2
2014	9	24	18	4	10	32	0	0	0	0	0	0	0	69.19	0	0	12.2
2014	9	24	18	14	10	30	0	0	0	0	0	0	0	69.12	0	0	12.2
2014	9	24	18	24	10	31	0	0	0	0	0	0	0	69.06	0	0	12
2014	9	24	18	34	10	31	0	0	0	0	0	0	0	68.97	0	0	12.2
2014	9	24	18	44	10	31	0	0	0	0	0	0	0	68.9	0	0	12.2
2014	9	24	18	54	10	31	0	0	0	0	0	0	0	68.79	0	0	12.2
2014	9	24	19	4	10	31	0	0	0	0	0	0	0	68.67	0	0	12.2
2014	9	24	19	14	10	31	0	0	0	0	0	0	0	68.58	0	0	12.2
2014	9	24	19	24	10	31	0	0	0	0	0	0	0	68.45	0	0	12
2014	9	24	19	34	10	31	0	0	0	0	0	0	0	68.32	0	0	12.2
2014	9	24	19	44	10	32	0	0	0	0	0	0	0	68.2	0	0	12.2
2014	9	24	19	54	10	32	0	0	0	0	0	0	0	68.04	0	0	12.2
2014	9	24	20	4	10	31	0	0	0	0	0	0	0	67.87	0	0	12.2
2014	9	24	20	14	10	31	0	0	0	0	0	0	0	67.71	0	0	12
2014	9	24	20	24	10	31	0	0	0	0	0	0	0	67.53	0	0	12
2014	9	24	20	34	10	31	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	24	20	44	10	31	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	24	20	54	10	31	0	0	0	0	0	0	0	66.94	0	0	12
2014	9	24	21	4	10	32	0	0	0	0	0	0	0	66.74	0	0	12
2014	9	24	21	14	10	31	0	0	0	0	0	0	0	66.52	0	0	12
2014	9	24	21	24	10	31	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	24	21	34	10	31	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	24	21	44	10	32	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	24	21	54	10	32	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	24	22	4	10	32	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	24	22	14	10	31	0	0	0	0	0	0	0	65.44	0	0	12
2014	9	24	22	24	10	31	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	24	22	34	10	32	0	0	0	0	0	0	0	65.17	0	0	12
2014	9	24	22	44	10	32	0	0	0	0	0	0	0	65.05	0	0	12
2014	9	24	22	54	10	32	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	24	23	4	10	32	0	0	0	0	0	0	0	64.8	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	23	14	10	31	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	24	23	24	10	32	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	24	23	34	10	32	0	0	0	0	0	0	0	64.45	0	0	12
2014	9	24	23	44	10	31	0	0	0	0	0	0	0	64.35	0	0	12
2014	9	24	23	54	10	32	0	0	0	0	0	0	0	64.27	0	0	12
2014	9	25	0	4	10	32	0	0	0	0	0	0	0	64.2	0	0	12
2014	9	25	0	14	10	32	0	0	0	0	0	0	0	64.11	0	0	12
2014	9	25	0	24	10	32	0	0	0	0	0	0	0	64.04	0	0	12
2014	9	25	0	34	10	32	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	25	0	44	10	32	0	0	0	0	0	0	0	63.9	0	0	12
2014	9	25	0	54	10	33	0	0	0	0	0	0	0	63.81	0	0	12
2014	9	25	1	4	10	32	0	0	0	0	0	0	0	63.75	0	0	12
2014	9	25	1	14	10	32	0	0	0	0	0	0	0	63.68	0	0	12
2014	9	25	1	24	10	32	0	0	0	0	0	0	0	63.61	0	0	11.8
2014	9	25	1	34	10	32	0	0	0	0	0	0	0	63.55	0	0	12
2014	9	25	1	44	10	32	0	0	0	0	0	0	0	63.48	0	0	12
2014	9	25	1	54	10	32	0	0	0	0	0	0	0	63.45	0	0	12
2014	9	25	2	4	10	32	0	0	0	0	0	0	0	63.39	0	0	12
2014	9	25	2	14	10	32	0	0	0	0	0	0	0	63.36	0	0	12
2014	9	25	2	24	10	32	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	25	2	34	10	32	0	0	0	0	0	0	0	63.28	0	0	12
2014	9	25	2	44	10	32	0	0	0	0	0	0	0	63.27	0	0	12
2014	9	25	2	54	10	32	0	0	0	0	0	0	0	63.25	0	0	12
2014	9	25	3	4	10	32	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	3	14	10	32	0	0	0	0	0	0	0	63.19	0	0	12
2014	9	25	3	24	10	31	0	0	0	0	0	0	0	63.16	0	0	11.8
2014	9	25	3	34	10	33	0	0	0	0	0	0	0	63.12	0	0	12
2014	9	25	3	44	10	32	0	0	0	0	0	0	0	63.07	0	0	12
2014	9	25	3	54	10	31	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	25	4	4	10	31	0	0	0	0	0	0	0	62.94	0	0	12
2014	9	25	4	14	10	31	0	0	0	0	0	0	0	62.89	0	0	12
2014	9	25	4	24	10	32	0	0	0	0	0	0	0	62.82	0	0	11.8
2014	9	25	4	34	10	32	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	25	4	44	10	32	0	0	0	0	0	0	0	62.69	0	0	12
2014	9	25	4	54	10	32	0	0	0	0	0	0	0	62.64	0	0	12
2014	9	25	5	4	10	32	0	0	0	0	0	0	0	62.6	0	0	12
2014	9	25	5	14	10	32	0	0	0	0	0	0	0	62.53	0	0	12
2014	9	25	5	24	10	32	0	0	0	0	0	0	0	62.47	0	0	11.8
2014	9	25	5	34	10	32	0	0	0	0	0	0	0	62.42	0	0	12
2014	9	25	5	44	10	32	0	0	0	0	0	0	0	62.35	0	0	12
2014	9	25	5	54	10	33	0	0	0	0	0	0	0	62.28	0	0	12
2014	9	25	6	4	10	32	0	0	0	0	0	0	0	62.2	0	0	11.8
2014	9	25	6	14	10	33	0	0	0	0	0	0	0	62.11	0	0	11.8
2014	9	25	6	24	10	32	0	0	0	0	0	0	0	62.04	0	0	11.8
2014	9	25	6	34	10	32	0	0	0	0	0	0	0	61.95	0	0	11.8
2014	9	25	6	44	10	32	0	0	0	0	0	0	0	61.9	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	6	54	10	32	0	0	0	0	0	0	0	61.83	0	0	11.8
2014	9	25	7	4	10	32	0	0	0	0	0	0	0	61.75	0	0	11.8
2014	9	25	7	14	10	33	0	0	0	0	0	0	0	61.66	0	0	11.8
2014	9	25	7	24	10	33	0	0	0	0	0	0	0	61.59	0	0	11.8
2014	9	25	7	34	10	32	0	0	0	0	0	0	0	61.52	0	0	12
2014	9	25	7	44	10	32	0	0	0	0	0	0	0	61.47	0	0	12.4
2014	9	25	7	54	10	32	0	0	0	0	0	0	0	61.41	0	0	12.8
2014	9	25	8	4	10	33	0	0	0	0	0	0	0	61.38	0	0	13
2014	9	25	8	14	10	32	0	0	0	0	0	0	0	61.36	0	0	13
2014	9	25	8	24	10	32	0	0	0	0	0	0	0	61.34	0	0	13.2
2014	9	25	8	34	10	32	0	0	0	0	0	0	0	61.34	0	0	13.2
2014	9	25	8	44	10	33	0	0	0	0	0	0	0	61.36	0	0	13.2
2014	9	25	8	54	10	32	0	0	0	0	0	0	0	61.38	0	0	13.4
2014	9	25	9	4	10	32	0	0	0	0	0	0	0	61.41	0	0	13.4
2014	9	25	9	14	10	33	0	0	0	0	0	0	0	61.47	0	0	13.4
2014	9	25	9	24	10	32	0	0	0	0	0	0	0	61.5	0	0	13.4
2014	9	25	9	34	10	33	0	0	0	0	0	0	0	61.57	0	0	13.4
2014	9	25	9	44	10	33	0	0	0	0	0	0	0	62.17	0	0	13.4
2014	9	25	9	54	10	33	0	0	0	0	0	0	0	62.4	0	0	13.4
2014	9	25	10	4	10	32	0	0	0	0	0	0	0	62.53	0	0	13.4
2014	9	25	10	14	10	32	0	0	0	0	0	0	0	62.62	0	0	13.4
2014	9	25	10	24	10	32	0	0	0	0	0	0	0	62.22	0	0	13.2
2014	9	25	10	34	10	32	0	0	0	0	0	0	0	62.19	0	0	13.4
2014	9	25	10	44	10	33	0	0	0	0	0	0	0	62.26	0	0	13.4
2014	9	25	10	54	10	33	0	0	0	0	0	0	0	62.38	0	0	13.4
2014	9	25	11	4	10	32	0	0	0	0	0	0	0	62.55	0	0	13.4
2014	9	25	11	14	10	32	0	0	0	0	0	0	0	62.89	0	0	13.4
2014	9	25	11	24	10	32	0	0	0	0	0	0	0	63.57	0	0	13.4
2014	9	25	11	34	10	32	0	0	0	0	0	0	0	63.88	0	0	13.4
2014	9	25	11	44	10	32	0	0	0	0	0	0	0	64.15	0	0	13.4
2014	9	25	11	54	10	32	0	0	0	0	0	0	0	64.33	0	0	13.4
2014	9	25	12	4	10	32	0	0	0	0	0	0	0	64.6	0	0	13.4
2014	9	25	12	14	10	32	0	0	0	0	0	0	0	64.8	0	0	13.4
2014	9	25	12	24	10	31	0	0	0	0	0	0	0	65.01	0	0	13.2
2014	9	25	12	34	10	31	0	0	0	0	0	0	0	65.28	0	0	13.4
2014	9	25	12	44	10	31	0	0	0	0	0	0	0	65.5	0	0	13.4
2014	9	25	12	54	10	32	0	0	0	0	0	0	0	65.75	0	0	13.2
2014	9	25	13	4	10	32	0	0	0	0	0	0	0	65.95	0	0	13.4
2014	9	25	13	14	10	32	0	0	0	0	0	0	0	66.2	0	0	13.4
2014	9	25	13	24	10	31	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	25	13	34	10	31	0	0	0	0	0	0	0	66.63	0	0	13.2
2014	9	25	13	44	10	31	0	0	0	0	0	0	0	66.9	0	0	13.2
2014	9	25	13	54	10	32	0	0	0	0	0	0	0	67.21	0	0	13.2
2014	9	25	14	4	10	31	0	0	0	0	0	0	0	67.41	0	0	13.2
2014	9	25	14	14	10	31	0	0	0	0	0	0	0	67.66	0	0	13.2
2014	9	25	14	24	10	31	0	0	0	0	0	0	0	67.86	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	14	34	10	31	0	0	0	0	0	0	0	68.07	0	0	13.2
2014	9	25	14	44	10	31	0	0	0	0	0	0	0	68.27	0	0	13.2
2014	9	25	14	54	10	31	0	0	0	0	0	0	0	68.49	0	0	13.2
2014	9	25	15	4	10	31	0	0	0	0	0	0	0	68.65	0	0	13.2
2014	9	25	15	14	10	31	0	0	0	0	0	0	0	68.81	0	0	13.2
2014	9	25	15	24	10	32	0	0	0	0	0	0	0	68.97	0	0	13
2014	9	25	15	34	10	31	0	0	0	0	0	0	0	69.12	0	0	13.2
2014	9	25	15	44	10	31	0	0	0	0	0	0	0	69.24	0	0	13.2
2014	9	25	15	54	10	31	0	0	0	0	0	0	0	69.31	0	0	13
2014	9	25	16	4	10	31	0	0	0	0	0	0	0	69.3	0	0	12.6
2014	9	25	16	14	10	31	0	0	0	0	0	0	0	69.44	0	0	12.8
2014	9	25	16	24	10	32	0	0	0	0	0	0	0	69.51	0	0	12.6
2014	9	25	16	34	10	32	0	0	0	0	0	0	0	69.57	0	0	12.6
2014	9	25	16	44	10	31	0	0	0	0	0	0	0	69.58	0	0	12.4
2014	9	25	16	54	10	31	0	0	0	0	0	0	0	69.62	0	0	12.4
2014	9	25	17	4	10	31	0	0	0	0	0	0	0	69.64	0	0	12.4
2014	9	25	17	14	10	31	0	0	0	0	0	0	0	69.66	0	0	12.2
2014	9	25	17	24	10	31	0	0	0	0	0	0	0	69.64	0	0	12
2014	9	25	17	34	10	30	0	0	0	0	0	0	0	69.6	0	0	12.2
2014	9	25	17	44	10	32	0	0	0	0	0	0	0	69.57	0	0	12.2
2014	9	25	17	54	10	30	0	0	0	0	0	0	0	69.55	0	0	12.2
2014	9	25	18	4	10	31	0	0	0	0	0	0	0	69.49	0	0	12.2
2014	9	25	18	14	10	31	0	0	0	0	0	0	0	69.42	0	0	12.2
2014	9	25	18	24	10	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	9	25	18	34	10	31	0	0	0	0	0	0	0	69.26	0	0	12.2
2014	9	25	18	44	10	32	0	0	0	0	0	0	0	69.17	0	0	12.2
2014	9	25	18	54	10	31	0	0	0	0	0	0	0	69.06	0	0	12.2
2014	9	25	19	4	10	31	0	0	0	0	0	0	0	68.94	0	0	12.2
2014	9	25	19	14	10	32	0	0	0	0	0	0	0	68.81	0	0	12.2
2014	9	25	19	24	10	31	0	0	0	0	0	0	0	68.68	0	0	12
2014	9	25	19	34	10	31	0	0	0	0	0	0	0	68.54	0	0	12.2
2014	9	25	19	44	10	32	0	0	0	0	0	0	0	68.4	0	0	12.2
2014	9	25	19	54	10	31	0	0	0	0	0	0	0	68.27	0	0	12.2
2014	9	25	20	4	10	32	0	0	0	0	0	0	0	68.13	0	0	12.2
2014	9	25	20	14	10	31	0	0	0	0	0	0	0	67.98	0	0	12.2
2014	9	25	20	24	10	32	0	0	0	0	0	0	0	67.86	0	0	12
2014	9	25	20	34	10	32	0	0	0	0	0	0	0	67.69	0	0	12
2014	9	25	20	44	10	31	0	0	0	0	0	0	0	67.53	0	0	12
2014	9	25	20	54	10	32	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	25	21	4	10	31	0	0	0	0	0	0	0	67.21	0	0	12
2014	9	25	21	14	10	31	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	25	21	24	10	31	0	0	0	0	0	0	0	66.83	0	0	12
2014	9	25	21	34	10	31	0	0	0	0	0	0	0	66.67	0	0	12
2014	9	25	21	44	10	31	0	0	0	0	0	0	0	66.49	0	0	12
2014	9	25	21	54	10	31	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	25	22	4	10	31	0	0	0	0	0	0	0	66.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	22	14	10	32	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	25	22	24	10	31	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	25	22	34	10	31	0	0	0	0	0	0	0	65.66	0	0	12
2014	9	25	22	44	10	31	0	0	0	0	0	0	0	65.52	0	0	12
2014	9	25	22	54	10	32	0	0	0	0	0	0	0	65.37	0	0	12
2014	9	25	23	4	10	31	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	25	23	14	10	31	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	25	23	24	10	32	0	0	0	0	0	0	0	64.99	0	0	12
2014	9	25	23	34	10	31	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	25	23	44	10	31	0	0	0	0	0	0	0	64.78	0	0	12
2014	9	25	23	54	10	32	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	26	0	4	10	31	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	26	0	14	10	32	0	0	0	0	0	0	0	64.47	0	0	12
2014	9	26	0	24	10	32	0	0	0	0	0	0	0	64.38	0	0	12
2014	9	26	0	34	10	32	0	0	0	0	0	0	0	64.27	0	0	12
2014	9	26	0	44	10	31	0	0	0	0	0	0	0	64.18	0	0	12
2014	9	26	0	54	10	33	0	0	0	0	0	0	0	64.13	0	0	12
2014	9	26	1	4	10	32	0	0	0	0	0	0	0	64.04	0	0	12
2014	9	26	1	14	10	32	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	26	1	24	10	32	0	0	0	0	0	0	0	63.9	0	0	11.8
2014	9	26	1	34	10	32	0	0	0	0	0	0	0	63.82	0	0	12
2014	9	26	1	44	10	33	0	0	0	0	0	0	0	63.77	0	0	12
2014	9	26	1	54	10	32	0	0	0	0	0	0	0	63.7	0	0	12
2014	9	26	2	4	10	32	0	0	0	0	0	0	0	63.63	0	0	12
2014	9	26	2	14	10	32	0	0	0	0	0	0	0	63.59	0	0	12
2014	9	26	2	24	10	31	0	0	0	0	0	0	0	63.54	0	0	11.8
2014	9	26	2	34	10	32	0	0	0	0	0	0	0	63.48	0	0	12
2014	9	26	2	44	10	32	0	0	0	0	0	0	0	63.43	0	0	12
2014	9	26	2	54	10	32	0	0	0	0	0	0	0	63.36	0	0	12
2014	9	26	3	4	10	32	0	0	0	0	0	0	0	63.28	0	0	12
2014	9	26	3	14	10	32	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	26	3	24	10	32	0	0	0	0	0	0	0	63.18	0	0	11.8
2014	9	26	3	34	10	32	0	0	0	0	0	0	0	63.09	0	0	12
2014	9	26	3	44	10	32	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	26	3	54	10	31	0	0	0	0	0	0	0	62.96	0	0	12
2014	9	26	4	4	10	32	0	0	0	0	0	0	0	62.91	0	0	12
2014	9	26	4	14	10	32	0	0	0	0	0	0	0	62.85	0	0	12
2014	9	26	4	24	10	32	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	26	4	34	10	32	0	0	0	0	0	0	0	62.71	0	0	12
2014	9	26	4	44	10	32	0	0	0	0	0	0	0	62.64	0	0	12
2014	9	26	4	54	10	32	0	0	0	0	0	0	0	62.56	0	0	12
2014	9	26	5	4	10	31	0	0	0	0	0	0	0	62.49	0	0	12
2014	9	26	5	14	10	32	0	0	0	0	0	0	0	62.4	0	0	12
2014	9	26	5	24	10	32	0	0	0	0	0	0	0	62.31	0	0	11.8
2014	9	26	5	34	10	32	0	0	0	0	0	0	0	62.22	0	0	12
2014	9	26	5	44	10	32	0	0	0	0	0	0	0	62.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	5	54	10	32	0	0	0	0	0	0	0	62.06	0	0	12
2014	9	26	6	4	10	32	0	0	0	0	0	0	0	61.97	0	0	11.8
2014	9	26	6	14	10	32	0	0	0	0	0	0	0	61.88	0	0	11.8
2014	9	26	6	24	10	32	0	0	0	0	0	0	0	61.77	0	0	11.8
2014	9	26	6	34	10	32	0	0	0	0	0	0	0	61.68	0	0	11.8
2014	9	26	6	44	10	32	0	0	0	0	0	0	0	61.59	0	0	11.8
2014	9	26	6	54	10	31	0	0	0	0	0	0	0	61.52	0	0	11.8
2014	9	26	7	4	10	32	0	0	0	0	0	0	0	61.43	0	0	11.8
2014	9	26	7	14	10	31	0	0	0	0	0	0	0	61.36	0	0	12
2014	9	26	7	24	10	33	0	0	0	0	0	0	0	61.29	0	0	11.8
2014	9	26	7	34	10	33	0	0	0	0	0	0	0	61.23	0	0	12
2014	9	26	7	44	10	32	0	0	0	0	0	0	0	61.18	0	0	12.4
2014	9	26	7	54	10	33	0	0	0	0	0	0	0	61.12	0	0	12.8
2014	9	26	8	4	10	33	0	0	0	0	0	0	0	61.07	0	0	13
2014	9	26	8	14	10	32	0	0	0	0	0	0	0	61.05	0	0	13
2014	9	26	8	24	10	32	0	0	0	0	0	0	0	61.02	0	0	13
2014	9	26	8	34	10	33	0	0	0	0	0	0	0	61	0	0	13.2
2014	9	26	8	44	10	32	0	0	0	0	0	0	0	60.98	0	0	13.2
2014	9	26	8	54	10	33	0	0	0	0	0	0	0	60.96	0	0	13.4
2014	9	26	9	4	10	32	0	0	0	0	0	0	0	60.98	0	0	13.4
2014	9	26	9	14	10	31	0	0	0	0	0	0	0	61	0	0	13.4
2014	9	26	9	24	10	33	0	0	0	0	0	0	0	61.02	0	0	13.4
2014	9	26	9	34	10	32	0	0	0	0	0	0	0	61.05	0	0	13.6
2014	9	26	9	44	10	32	0	0	0	0	0	0	0	61.5	0	0	13.6
2014	9	26	9	54	10	32	0	0	0	0	0	0	0	61.81	0	0	13.6
2014	9	26	10	4	10	32	0	0	0	0	0	0	0	61.83	0	0	13.6
2014	9	26	10	14	10	33	0	0	0	0	0	0	0	62.13	0	0	13.6
2014	9	26	10	24	10	33	0	0	0	0	0	0	0	61.59	0	0	13.4
2014	9	26	10	34	10	32	0	0	0	0	0	0	0	61.54	0	0	13.6
2014	9	26	10	44	10	32	0	0	0	0	0	0	0	61.61	0	0	13.6
2014	9	26	10	54	10	32	0	0	0	0	0	0	0	61.74	0	0	13.6
2014	9	26	11	4	10	32	0	0	0	0	0	0	0	61.88	0	0	13.6
2014	9	26	11	14	10	32	0	0	0	0	0	0	0	62.47	0	0	13.4
2014	9	26	11	24	10	32	0	0	0	0	0	0	0	63.01	0	0	13.4
2014	9	26	11	34	10	32	0	0	0	0	0	0	0	63.23	0	0	13.6
2014	9	26	11	44	10	31	0	0	0	0	0	0	0	63.45	0	0	13.6
2014	9	26	11	54	10	32	0	0	0	0	0	0	0	63.57	0	0	13.6
2014	9	26	12	4	10	32	0	0	0	0	0	0	0	63.77	0	0	13.6
2014	9	26	12	14	10	32	0	0	0	0	0	0	0	63.99	0	0	13.4
2014	9	26	12	24	10	32	0	0	0	0	0	0	0	64.17	0	0	13.4
2014	9	26	12	34	10	32	0	0	0	0	0	0	0	64.33	0	0	13.4
2014	9	26	12	44	10	32	0	0	0	0	0	0	0	64.53	0	0	13.4
2014	9	26	12	54	10	32	0	0	0	0	0	0	0	64.72	0	0	13.4
2014	9	26	13	4	10	31	0	0	0	0	0	0	0	64.9	0	0	13.4
2014	9	26	13	14	10	33	0	0	0	0	0	0	0	65.14	0	0	13.4
2014	9	26	13	24	10	32	0	0	0	0	0	0	0	65.3	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	13	34	10	31	0	0	0	0	0	0	0	65.48	0	0	13.4
2014	9	26	13	44	10	31	0	0	0	0	0	0	0	65.66	0	0	13.4
2014	9	26	13	54	10	32	0	0	0	0	0	0	0	65.88	0	0	13.4
2014	9	26	14	4	10	32	0	0	0	0	0	0	0	66.04	0	0	13.4
2014	9	26	14	14	10	31	0	0	0	0	0	0	0	66.2	0	0	13.4
2014	9	26	14	24	10	32	0	0	0	0	0	0	0	66.38	0	0	13.4
2014	9	26	14	34	10	31	0	0	0	0	0	0	0	66.56	0	0	13.4
2014	9	26	14	44	10	32	0	0	0	0	0	0	0	66.69	0	0	13.4
2014	9	26	14	54	10	32	0	0	0	0	0	0	0	66.81	0	0	13.4
2014	9	26	15	4	10	31	0	0	0	0	0	0	0	66.96	0	0	13.4
2014	9	26	15	14	10	31	0	0	0	0	0	0	0	66.99	0	0	13.4
2014	9	26	15	24	10	32	0	0	0	0	0	0	0	67.1	0	0	13.4
2014	9	26	15	34	10	31	0	0	0	0	0	0	0	67.15	0	0	13.4
2014	9	26	15	44	10	32	0	0	0	0	0	0	0	67.23	0	0	13.4
2014	9	26	15	54	10	31	0	0	0	0	0	0	0	67.26	0	0	13.4
2014	9	26	16	4	10	31	0	0	0	0	0	0	0	67.28	0	0	13.2
2014	9	26	16	14	10	32	0	0	0	0	0	0	0	67.32	0	0	13
2014	9	26	16	24	10	31	0	0	0	0	0	0	0	67.32	0	0	12.8
2014	9	26	16	34	10	32	0	0	0	0	0	0	0	67.3	0	0	12.8
2014	9	26	16	44	10	32	0	0	0	0	0	0	0	67.28	0	0	12.6
2014	9	26	16	54	10	31	0	0	0	0	0	0	0	67.24	0	0	12.4
2014	9	26	17	4	10	32	0	0	0	0	0	0	0	67.19	0	0	12.4
2014	9	26	17	14	10	32	0	0	0	0	0	0	0	67.14	0	0	12.2
2014	9	26	17	24	10	32	0	0	0	0	0	0	0	67.08	0	0	12.2
2014	9	26	17	34	10	31	0	0	0	0	0	0	0	66.97	0	0	12.2
2014	9	26	17	44	10	31	0	0	0	0	0	0	0	66.92	0	0	12.2
2014	9	26	17	54	10	32	0	0	0	0	0	0	0	66.81	0	0	12.2
2014	9	26	18	4	10	32	0	0	0	0	0	0	0	66.72	0	0	12.2
2014	9	26	18	14	10	31	0	0	0	0	0	0	0	66.63	0	0	12.2
2014	9	26	18	24	10	32	0	0	0	0	0	0	0	66.52	0	0	12
2014	9	26	18	34	10	32	0	0	0	0	0	0	0	66.42	0	0	12.2
2014	9	26	18	44	10	32	0	0	0	0	0	0	0	66.29	0	0	12.2
2014	9	26	18	54	10	31	0	0	0	0	0	0	0	66.15	0	0	12.2
2014	9	26	19	4	10	32	0	0	0	0	0	0	0	65.98	0	0	12.2
2014	9	26	19	14	10	32	0	0	0	0	0	0	0	65.86	0	0	12.2
2014	9	26	19	24	10	31	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	26	19	34	10	32	0	0	0	0	0	0	0	65.5	0	0	12.2
2014	9	26	19	44	10	32	0	0	0	0	0	0	0	65.32	0	0	12.2
2014	9	26	19	54	10	32	0	0	0	0	0	0	0	65.14	0	0	12.2
2014	9	26	20	4	10	32	0	0	0	0	0	0	0	64.98	0	0	12
2014	9	26	20	14	10	31	0	0	0	0	0	0	0	64.81	0	0	12
2014	9	26	20	24	10	31	0	0	0	0	0	0	0	64.62	0	0	12
2014	9	26	20	34	10	32	0	0	0	0	0	0	0	64.44	0	0	12
2014	9	26	20	44	10	31	0	0	0	0	0	0	0	64.26	0	0	12
2014	9	26	20	54	10	32	0	0	0	0	0	0	0	64.06	0	0	12
2014	9	26	21	4	10	33	0	0	0	0	0	0	0	63.86	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	21	14	10	32	0	0	0	0	0	0	0	63.66	0	0	12
2014	9	26	21	24	10	32	0	0	0	0	0	0	0	63.46	0	0	12
2014	9	26	21	34	10	32	0	0	0	0	0	0	0	63.25	0	0	12
2014	9	26	21	44	10	32	0	0	0	0	0	0	0	63.05	0	0	12
2014	9	26	21	54	10	32	0	0	0	0	0	0	0	62.85	0	0	12
2014	9	26	22	4	10	32	0	0	0	0	0	0	0	62.67	0	0	12
2014	9	26	22	14	10	32	0	0	0	0	0	0	0	62.47	0	0	12
2014	9	26	22	24	10	32	0	0	0	0	0	0	0	62.29	0	0	12
2014	9	26	22	34	10	32	0	0	0	0	0	0	0	62.11	0	0	12
2014	9	26	22	44	10	32	0	0	0	0	0	0	0	61.95	0	0	12
2014	9	26	22	54	10	32	0	0	0	0	0	0	0	61.81	0	0	12
2014	9	26	23	4	10	32	0	0	0	0	0	0	0	61.63	0	0	12
2014	9	26	23	14	10	33	0	0	0	0	0	0	0	61.5	0	0	12
2014	9	26	23	24	10	32	0	0	0	0	0	0	0	61.36	0	0	12
2014	9	26	23	34	10	32	0	0	0	0	0	0	0	61.23	0	0	12
2014	9	26	23	44	10	32	0	0	0	0	0	0	0	61.11	0	0	12
2014	9	26	23	54	10	33	0	0	0	0	0	0	0	61	0	0	12
2014	9	27	0	4	10	32	0	0	0	0	0	0	0	60.91	0	0	12
2014	9	27	0	14	10	33	0	0	0	0	0	0	0	60.8	0	0	12
2014	9	27	0	24	10	32	0	0	0	0	0	0	0	60.71	0	0	11.8
2014	9	27	0	34	10	32	0	0	0	0	0	0	0	60.62	0	0	12
2014	9	27	0	44	10	32	0	0	0	0	0	0	0	60.53	0	0	12
2014	9	27	0	54	10	32	0	0	0	0	0	0	0	60.46	0	0	12
2014	9	27	1	4	10	33	0	0	0	0	0	0	0	60.33	0	0	12
2014	9	27	1	14	10	32	0	0	0	0	0	0	0	60.26	0	0	12
2014	9	27	1	24	10	32	0	0	0	0	0	0	0	60.17	0	0	12
2014	9	27	1	34	10	33	0	0	0	0	0	0	0	60.1	0	0	12
2014	9	27	1	44	10	33	0	0	0	0	0	0	0	60.03	0	0	12
2014	9	27	1	54	10	32	0	0	0	0	0	0	0	59.95	0	0	12
2014	9	27	2	4	10	33	0	0	0	0	0	0	0	59.9	0	0	12
2014	9	27	2	14	10	32	0	0	0	0	0	0	0	59.85	0	0	12
2014	9	27	2	24	10	32	0	0	0	0	0	0	0	59.79	0	0	11.8
2014	9	27	2	34	10	33	0	0	0	0	0	0	0	59.76	0	0	12
2014	9	27	2	44	10	33	0	0	0	0	0	0	0	59.74	0	0	12
2014	9	27	2	54	10	33	0	0	0	0	0	0	0	59.7	0	0	12
2014	9	27	3	4	10	32	0	0	0	0	0	0	0	59.67	0	0	12
2014	9	27	3	14	10	33	0	0	0	0	0	0	0	59.63	0	0	12
2014	9	27	3	24	10	33	0	0	0	0	0	0	0	59.59	0	0	11.8
2014	9	27	3	34	10	32	0	0	0	0	0	0	0	59.56	0	0	12
2014	9	27	3	44	10	33	0	0	0	0	0	0	0	59.5	0	0	12
2014	9	27	3	54	10	33	0	0	0	0	0	0	0	59.47	0	0	12
2014	9	27	4	4	10	32	0	0	0	0	0	0	0	59.43	0	0	12
2014	9	27	4	14	10	33	0	0	0	0	0	0	0	59.4	0	0	12
2014	9	27	4	24	10	33	0	0	0	0	0	0	0	59.36	0	0	11.8
2014	9	27	4	34	10	32	0	0	0	0	0	0	0	59.31	0	0	12
2014	9	27	4	44	10	31	0	0	0	0	0	0	0	59.23	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	4	54	10	32	0	0	0	0	0	0	0	59.16	0	0	12
2014	9	27	5	4	10	32	0	0	0	0	0	0	0	59.09	0	0	12
2014	9	27	5	14	10	33	0	0	0	0	0	0	0	59	0	0	12
2014	9	27	5	24	10	33	0	0	0	0	0	0	0	58.91	0	0	11.8
2014	9	27	5	34	10	32	0	0	0	0	0	0	0	58.82	0	0	11.8
2014	9	27	5	44	10	33	0	0	0	0	0	0	0	58.73	0	0	11.8
2014	9	27	5	54	10	32	0	0	0	0	0	0	0	58.64	0	0	11.8
2014	9	27	6	4	10	33	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	27	6	14	10	32	0	0	0	0	0	0	0	58.46	0	0	11.8
2014	9	27	6	24	10	33	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	27	6	34	10	33	0	0	0	0	0	0	0	58.26	0	0	11.8
2014	9	27	6	44	10	33	0	0	0	0	0	0	0	58.17	0	0	11.8
2014	9	27	6	54	10	33	0	0	0	0	0	0	0	58.08	0	0	11.8
2014	9	27	7	4	10	33	0	0	0	0	0	0	0	58.01	0	0	11.8
2014	9	27	7	14	10	31	0	0	0	0	0	0	0	57.9	0	0	11.8
2014	9	27	7	24	10	33	0	0	0	0	0	0	0	57.81	0	0	11.8
2014	9	27	7	34	10	33	0	0	0	0	0	0	0	57.74	0	0	11.8
2014	9	27	7	44	10	33	0	0	0	0	0	0	0	57.63	0	0	12.4
2014	9	27	7	54	10	33	0	0	0	0	0	0	0	57.54	0	0	12.8
2014	9	27	8	4	10	33	0	0	0	0	0	0	0	57.45	0	0	13
2014	9	27	8	14	10	32	0	0	0	0	0	0	0	57.36	0	0	13
2014	9	27	8	24	10	33	0	0	0	0	0	0	0	57.29	0	0	13.2
2014	9	27	8	34	10	33	0	0	0	0	0	0	0	57.22	0	0	13.2
2014	9	27	8	44	10	33	0	0	0	0	0	0	0	57.16	0	0	13.4
2014	9	27	8	54	10	32	0	0	0	0	0	0	0	57.11	0	0	13.4
2014	9	27	9	4	10	33	0	0	0	0	0	0	0	57.07	0	0	13.4
2014	9	27	9	14	10	33	0	0	0	0	0	0	0	57.04	0	0	13.6
2014	9	27	9	24	10	34	0	0	0	0	0	0	0	57.02	0	0	13.6
2014	9	27	9	34	10	33	0	0	0	0	0	0	0	57.02	0	0	13.8
2014	9	27	9	44	10	33	0	0	0	0	0	0	0	57.29	0	0	13.8
2014	9	27	9	54	10	33	0	0	0	0	0	0	0	57.74	0	0	13.8
2014	9	27	10	4	10	32	0	0	0	0	0	0	0	57.85	0	0	13.8
2014	9	27	10	14	10	33	0	0	0	0	0	0	0	57.96	0	0	13.8
2014	9	27	10	24	10	34	0	0	0	0	0	0	0	57.36	0	0	13.6
2014	9	27	10	34	10	33	0	0	0	0	0	0	0	57.31	0	0	13.8
2014	9	27	10	44	10	32	0	0	0	0	0	0	0	57.36	0	0	13.8
2014	9	27	10	54	10	33	0	0	0	0	0	0	0	57.47	0	0	13.8
2014	9	27	11	4	10	33	0	0	0	0	0	0	0	57.58	0	0	13.8
2014	9	27	11	14	10	33	0	0	0	0	0	0	0	58.32	0	0	13.8
2014	9	27	11	24	10	32	0	0	0	0	0	0	0	58.69	0	0	13.8
2014	9	27	11	34	10	32	0	0	0	0	0	0	0	58.89	0	0	13.8
2014	9	27	11	44	10	33	0	0	0	0	0	0	0	59.11	0	0	13.8
2014	9	27	11	54	10	33	0	0	0	0	0	0	0	59.29	0	0	13.8
2014	9	27	12	4	10	33	0	0	0	0	0	0	0	59.49	0	0	13.8
2014	9	27	12	14	10	32	0	0	0	0	0	0	0	59.65	0	0	13.8
2014	9	27	12	24	10	33	0	0	0	0	0	0	0	59.86	0	0	13.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	12	34	10	32	0	0	0	0	0	0	0	60.06	0	0	13.8
2014	9	27	12	44	10	33	0	0	0	0	0	0	0	60.3	0	0	13.8
2014	9	27	12	54	10	33	0	0	0	0	0	0	0	60.51	0	0	13.8
2014	9	27	13	4	10	32	0	0	0	0	0	0	0	60.73	0	0	13.8
2014	9	27	13	14	10	32	0	0	0	0	0	0	0	60.96	0	0	13.8
2014	9	27	13	24	10	32	0	0	0	0	0	0	0	61.2	0	0	13.6
2014	9	27	13	34	10	32	0	0	0	0	0	0	0	61.29	0	0	13.6
2014	9	27	13	44	10	33	0	0	0	0	0	0	0	61.66	0	0	13.8
2014	9	27	13	54	10	32	0	0	0	0	0	0	0	61.95	0	0	13.8
2014	9	27	14	4	10	32	0	0	0	0	0	0	0	61.86	0	0	13.2
2014	9	27	14	14	10	33	0	0	0	0	0	0	0	62.01	0	0	13
2014	9	27	14	24	10	32	0	0	0	0	0	0	0	62.15	0	0	13
2014	9	27	14	34	10	32	0	0	0	0	0	0	0	62.19	0	0	13
2014	9	27	14	44	10	33	0	0	0	0	0	0	0	62.28	0	0	12.8
2014	9	27	14	54	10	32	0	0	0	0	0	0	0	62.51	0	0	13.4
2014	9	27	15	4	10	32	0	0	0	0	0	0	0	62.49	0	0	13
2014	9	27	15	14	10	32	0	0	0	0	0	0	0	62.53	0	0	12.8
2014	9	27	15	24	10	32	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	27	15	34	10	32	0	0	0	0	0	0	0	62.65	0	0	12.6
2014	9	27	15	44	10	32	0	0	0	0	0	0	0	62.67	0	0	12.4
2014	9	27	15	54	10	32	0	0	0	0	0	0	0	62.71	0	0	12.4
2014	9	27	16	4	10	32	0	0	0	0	0	0	0	62.73	0	0	12.4
2014	9	27	16	14	10	32	0	0	0	0	0	0	0	62.74	0	0	12.2
2014	9	27	16	24	10	32	0	0	0	0	0	0	0	62.74	0	0	12.2
2014	9	27	16	34	10	33	0	0	0	0	0	0	0	62.82	0	0	12.2
2014	9	27	16	44	10	32	0	0	0	0	0	0	0	62.8	0	0	12.2
2014	9	27	16	54	10	31	0	0	0	0	0	0	0	62.78	0	0	12.2
2014	9	27	17	4	10	32	0	0	0	0	0	0	0	62.76	0	0	12.2
2014	9	27	17	14	10	32	0	0	0	0	0	0	0	62.78	0	0	12.2
2014	9	27	17	24	10	33	0	0	0	0	0	0	0	62.74	0	0	12.2
2014	9	27	17	34	10	32	0	0	0	0	0	0	0	62.71	0	0	12.2
2014	9	27	17	44	10	32	0	0	0	0	0	0	0	62.67	0	0	12.2
2014	9	27	17	54	10	32	0	0	0	0	0	0	0	62.62	0	0	12.2
2014	9	27	18	4	10	31	0	0	0	0	0	0	0	62.55	0	0	12.2
2014	9	27	18	14	10	32	0	0	0	0	0	0	0	62.46	0	0	12.2
2014	9	27	18	24	10	32	0	0	0	0	0	0	0	62.35	0	0	12
2014	9	27	18	34	10	32	0	0	0	0	0	0	0	62.24	0	0	12
2014	9	27	18	44	10	32	0	0	0	0	0	0	0	62.11	0	0	12
2014	9	27	18	54	10	33	0	0	0	0	0	0	0	61.97	0	0	12
2014	9	27	19	4	10	33	0	0	0	0	0	0	0	61.81	0	0	12
2014	9	27	19	14	10	32	0	0	0	0	0	0	0	61.65	0	0	12
2014	9	27	19	24	10	32	0	0	0	0	0	0	0	61.48	0	0	12
2014	9	27	19	34	10	32	0	0	0	0	0	0	0	61.3	0	0	12
2014	9	27	19	44	10	32	0	0	0	0	0	0	0	61.14	0	0	12
2014	9	27	19	54	10	32	0	0	0	0	0	0	0	60.96	0	0	12
2014	9	27	20	4	10	33	0	0	0	0	0	0	0	60.8	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	20	14	10	32	0	0	0	0	0	0	0	60.66	0	0	12
2014	9	27	20	24	10	32	0	0	0	0	0	0	0	60.51	0	0	12
2014	9	27	20	34	10	32	0	0	0	0	0	0	0	60.37	0	0	12
2014	9	27	20	44	10	32	0	0	0	0	0	0	0	60.22	0	0	12
2014	9	27	20	54	10	33	0	0	0	0	0	0	0	60.06	0	0	12
2014	9	27	21	4	10	33	0	0	0	0	0	0	0	59.92	0	0	12
2014	9	27	21	14	10	33	0	0	0	0	0	0	0	59.77	0	0	12
2014	9	27	21	24	10	33	0	0	0	0	0	0	0	59.63	0	0	12
2014	9	27	21	34	10	32	0	0	0	0	0	0	0	59.49	0	0	12
2014	9	27	21	44	10	33	0	0	0	0	0	0	0	59.34	0	0	12
2014	9	27	21	54	10	33	0	0	0	0	0	0	0	59.2	0	0	12
2014	9	27	22	4	10	32	0	0	0	0	0	0	0	59.05	0	0	12
2014	9	27	22	14	10	33	0	0	0	0	0	0	0	58.93	0	0	12
2014	9	27	22	24	10	33	0	0	0	0	0	0	0	58.8	0	0	11.8
2014	9	27	22	34	10	33	0	0	0	0	0	0	0	58.66	0	0	12
2014	9	27	22	44	10	32	0	0	0	0	0	0	0	58.55	0	0	12
2014	9	27	22	54	10	33	0	0	0	0	0	0	0	58.42	0	0	12
2014	9	27	23	4	10	33	0	0	0	0	0	0	0	58.3	0	0	12
2014	9	27	23	14	10	33	0	0	0	0	0	0	0	58.19	0	0	12
2014	9	27	23	24	10	33	0	0	0	0	0	0	0	58.08	0	0	11.8
2014	9	27	23	34	10	32	0	0	0	0	0	0	0	57.97	0	0	12
2014	9	27	23	44	10	32	0	0	0	0	0	0	0	57.88	0	0	12
2014	9	27	23	54	10	33	0	0	0	0	0	0	0	57.79	0	0	12
2014	9	28	0	4	10	33	0	0	0	0	0	0	0	57.7	0	0	12
2014	9	28	0	14	10	33	0	0	0	0	0	0	0	57.61	0	0	12
2014	9	28	0	24	10	32	0	0	0	0	0	0	0	57.52	0	0	12
2014	9	28	0	34	10	33	0	0	0	0	0	0	0	57.45	0	0	12
2014	9	28	0	44	10	33	0	0	0	0	0	0	0	57.4	0	0	12
2014	9	28	0	54	10	33	0	0	0	0	0	0	0	57.33	0	0	12
2014	9	28	1	4	10	33	0	0	0	0	0	0	0	57.27	0	0	12
2014	9	28	1	14	10	32	0	0	0	0	0	0	0	57.2	0	0	12
2014	9	28	1	24	10	33	0	0	0	0	0	0	0	57.16	0	0	11.8
2014	9	28	1	34	10	33	0	0	0	0	0	0	0	57.11	0	0	12
2014	9	28	1	44	10	33	0	0	0	0	0	0	0	57.09	0	0	12
2014	9	28	1	54	10	33	0	0	0	0	0	0	0	57.04	0	0	12
2014	9	28	2	4	10	34	0	0	0	0	0	0	0	57	0	0	12
2014	9	28	2	14	10	34	0	0	0	0	0	0	0	56.98	0	0	11.8
2014	9	28	2	24	10	33	0	0	0	0	0	0	0	56.97	0	0	11.8
2014	9	28	2	34	10	33	0	0	0	0	0	0	0	56.95	0	0	11.8
2014	9	28	2	44	10	33	0	0	0	0	0	0	0	56.93	0	0	11.8
2014	9	28	2	54	10	33	0	0	0	0	0	0	0	56.91	0	0	11.8
2014	9	28	3	4	10	33	0	0	0	0	0	0	0	56.91	0	0	11.8
2014	9	28	3	14	10	33	0	0	0	0	0	0	0	56.89	0	0	11.8
2014	9	28	3	24	10	33	0	0	0	0	0	0	0	56.88	0	0	11.8
2014	9	28	3	34	10	32	0	0	0	0	0	0	0	56.84	0	0	11.8
2014	9	28	3	44	10	33	0	0	0	0	0	0	0	56.82	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	3	54	10	33	0	0	0	0	0	0	0	56.8	0	0	11.8
2014	9	28	4	4	10	33	0	0	0	0	0	0	0	56.79	0	0	11.8
2014	9	28	4	14	10	33	0	0	0	0	0	0	0	56.75	0	0	11.8
2014	9	28	4	24	10	33	0	0	0	0	0	0	0	56.73	0	0	11.8
2014	9	28	4	34	10	33	0	0	0	0	0	0	0	56.7	0	0	11.8
2014	9	28	4	44	10	32	0	0	0	0	0	0	0	56.68	0	0	11.8
2014	9	28	4	54	10	33	0	0	0	0	0	0	0	56.64	0	0	11.8
2014	9	28	5	4	10	33	0	0	0	0	0	0	0	56.62	0	0	11.8
2014	9	28	5	14	10	33	0	0	0	0	0	0	0	56.61	0	0	11.8
2014	9	28	5	24	10	33	0	0	0	0	0	0	0	56.57	0	0	11.8
2014	9	28	5	34	10	33	0	0	0	0	0	0	0	56.53	0	0	11.8
2014	9	28	5	44	10	32	0	0	0	0	0	0	0	56.5	0	0	11.8
2014	9	28	5	54	10	33	0	0	0	0	0	0	0	56.48	0	0	11.8
2014	9	28	6	4	10	33	0	0	0	0	0	0	0	56.44	0	0	11.8
2014	9	28	6	14	10	33	0	0	0	0	0	0	0	56.39	0	0	11.8
2014	9	28	6	24	10	33	0	0	0	0	0	0	0	56.35	0	0	11.6
2014	9	28	6	34	10	33	0	0	0	0	0	0	0	56.32	0	0	11.8
2014	9	28	6	44	10	33	0	0	0	0	0	0	0	56.28	0	0	11.8
2014	9	28	6	54	10	32	0	0	0	0	0	0	0	56.25	0	0	11.8
2014	9	28	7	4	10	33	0	0	0	0	0	0	0	56.23	0	0	11.8
2014	9	28	7	14	10	33	0	0	0	0	0	0	0	56.19	0	0	11.8
2014	9	28	7	24	10	33	0	0	0	0	0	0	0	56.17	0	0	11.8
2014	9	28	7	34	10	33	0	0	0	0	0	0	0	56.19	0	0	12
2014	9	28	7	44	10	33	0	0	0	0	0	0	0	56.19	0	0	12
2014	9	28	7	54	10	33	0	0	0	0	0	0	0	56.16	0	0	12.4
2014	9	28	8	4	10	32	0	0	0	0	0	0	0	56.16	0	0	12.2
2014	9	28	8	14	10	34	0	0	0	0	0	0	0	56.17	0	0	12.2
2014	9	28	8	24	10	33	0	0	0	0	0	0	0	56.23	0	0	12.4
2014	9	28	8	34	10	33	0	0	0	0	0	0	0	56.26	0	0	12.8
2014	9	28	8	44	10	33	0	0	0	0	0	0	0	56.3	0	0	13
2014	9	28	8	54	10	33	0	0	0	0	0	0	0	56.3	0	0	13.2
2014	9	28	9	4	10	33	0	0	0	0	0	0	0	56.26	0	0	13.2
2014	9	28	9	14	10	33	0	0	0	0	0	0	0	56.28	0	0	12.8
2014	9	28	9	24	10	33	0	0	0	0	0	0	0	56.37	0	0	12.6
2014	9	28	9	34	10	33	0	0	0	0	0	0	0	56.43	0	0	12.6
2014	9	28	9	44	10	33	0	0	0	0	0	0	0	56.55	0	0	13.2
2014	9	28	9	54	10	33	0	0	0	0	0	0	0	56.75	0	0	13
2014	9	28	10	4	10	32	0	0	0	0	0	0	0	56.98	0	0	13.4
2014	9	28	10	14	10	33	0	0	0	0	0	0	0	57.27	0	0	13.4
2014	9	28	10	24	10	33	0	0	0	0	0	0	0	56.71	0	0	13.6
2014	9	28	10	34	10	33	0	0	0	0	0	0	0	56.73	0	0	13.6
2014	9	28	10	44	10	33	0	0	0	0	0	0	0	56.84	0	0	13.6
2014	9	28	10	54	10	34	0	0	0	0	0	0	0	56.98	0	0	13.6
2014	9	28	11	4	10	34	0	0	0	0	0	0	0	57.15	0	0	13.6
2014	9	28	11	14	10	33	0	0	0	0	0	0	0	58.05	0	0	13.6
2014	9	28	11	24	10	33	0	0	0	0	0	0	0	58.42	0	0	13.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	11	34	10	32	0	0	0	0	0	0	0	58.69	0	0	13.6
2014	9	28	11	44	10	32	0	0	0	0	0	0	0	58.95	0	0	13.6
2014	9	28	11	54	10	33	0	0	0	0	0	0	0	59.18	0	0	13.6
2014	9	28	12	4	10	32	0	0	0	0	0	0	0	59.41	0	0	13.6
2014	9	28	12	14	10	33	0	0	0	0	0	0	0	59.59	0	0	13.6
2014	9	28	12	24	10	32	0	0	0	0	0	0	0	59.85	0	0	13.4
2014	9	28	12	34	10	32	0	0	0	0	0	0	0	59.94	0	0	13.4
2014	9	28	12	44	10	33	0	0	0	0	0	0	0	60.33	0	0	13.4
2014	9	28	12	54	10	32	0	0	0	0	0	0	0	60.13	0	0	13
2014	9	28	13	4	10	33	0	0	0	0	0	0	0	60.58	0	0	13.6
2014	9	28	13	14	10	32	0	0	0	0	0	0	0	60.93	0	0	13.6
2014	9	28	13	24	10	32	0	0	0	0	0	0	0	61.12	0	0	13.4
2014	9	28	13	34	10	33	0	0	0	0	0	0	0	61.03	0	0	13
2014	9	28	13	44	10	33	0	0	0	0	0	0	0	61.2	0	0	13
2014	9	28	13	54	10	32	0	0	0	0	0	0	0	61.34	0	0	13
2014	9	28	14	4	10	32	0	0	0	0	0	0	0	61.61	0	0	13.2
2014	9	28	14	14	10	32	0	0	0	0	0	0	0	61.74	0	0	13
2014	9	28	14	24	10	33	0	0	0	0	0	0	0	61.9	0	0	12.8
2014	9	28	14	34	10	32	0	0	0	0	0	0	0	61.97	0	0	12.8
2014	9	28	14	44	10	32	0	0	0	0	0	0	0	62.15	0	0	12.8
2014	9	28	14	54	10	32	0	0	0	0	0	0	0	62.29	0	0	12.8
2014	9	28	15	4	10	32	0	0	0	0	0	0	0	62.44	0	0	12.8
2014	9	28	15	14	10	32	0	0	0	0	0	0	0	62.51	0	0	12.6
2014	9	28	15	24	10	32	0	0	0	0	0	0	0	62.62	0	0	12.6
2014	9	28	15	34	10	32	0	0	0	0	0	0	0	62.69	0	0	12.4
2014	9	28	15	44	10	32	0	0	0	0	0	0	0	62.87	0	0	12.4
2014	9	28	15	54	10	32	0	0	0	0	0	0	0	63	0	0	12.6
2014	9	28	16	4	10	32	0	0	0	0	0	0	0	63.05	0	0	12.4
2014	9	28	16	14	10	33	0	0	0	0	0	0	0	63.09	0	0	12.4
2014	9	28	16	24	10	32	0	0	0	0	0	0	0	63.25	0	0	12.4
2014	9	28	16	34	10	31	0	0	0	0	0	0	0	63.36	0	0	12.4
2014	9	28	16	44	10	32	0	0	0	0	0	0	0	63.37	0	0	12.4
2014	9	28	16	54	10	32	0	0	0	0	0	0	0	63.39	0	0	12.4
2014	9	28	17	4	10	32	0	0	0	0	0	0	0	63.39	0	0	12.2
2014	9	28	17	14	10	32	0	0	0	0	0	0	0	63.3	0	0	12.2
2014	9	28	17	24	10	32	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	28	17	34	10	32	0	0	0	0	0	0	0	63.14	0	0	12.2
2014	9	28	17	44	10	32	0	0	0	0	0	0	0	63.03	0	0	12.2
2014	9	28	17	54	10	32	0	0	0	0	0	0	0	62.91	0	0	12.2
2014	9	28	18	4	10	32	0	0	0	0	0	0	0	62.78	0	0	12.2
2014	9	28	18	14	10	32	0	0	0	0	0	0	0	62.64	0	0	12.2
2014	9	28	18	24	10	32	0	0	0	0	0	0	0	62.51	0	0	12
2014	9	28	18	34	10	32	0	0	0	0	0	0	0	62.37	0	0	12
2014	9	28	18	44	10	33	0	0	0	0	0	0	0	62.24	0	0	12
2014	9	28	18	54	10	32	0	0	0	0	0	0	0	62.11	0	0	12
2014	9	28	19	4	10	32	0	0	0	0	0	0	0	61.99	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	19	14	10	33	0	0	0	0	0	0	0	61.86	0	0	12
2014	9	28	19	24	10	33	0	0	0	0	0	0	0	61.74	0	0	12
2014	9	28	19	34	10	32	0	0	0	0	0	0	0	61.61	0	0	12
2014	9	28	19	44	10	33	0	0	0	0	0	0	0	61.48	0	0	12
2014	9	28	19	54	10	33	0	0	0	0	0	0	0	61.34	0	0	12
2014	9	28	20	4	10	32	0	0	0	0	0	0	0	61.2	0	0	12
2014	9	28	20	14	10	32	0	0	0	0	0	0	0	61.07	0	0	12
2014	9	28	20	24	10	32	0	0	0	0	0	0	0	60.91	0	0	12
2014	9	28	20	34	10	32	0	0	0	0	0	0	0	60.76	0	0	12
2014	9	28	20	44	10	32	0	0	0	0	0	0	0	60.6	0	0	12
2014	9	28	20	54	10	31	0	0	0	0	0	0	0	60.46	0	0	12
2014	9	28	21	4	10	32	0	0	0	0	0	0	0	60.3	0	0	12
2014	9	28	21	14	10	32	0	0	0	0	0	0	0	60.15	0	0	12
2014	9	28	21	24	10	32	0	0	0	0	0	0	0	59.99	0	0	12
2014	9	28	21	34	10	33	0	0	0	0	0	0	0	59.83	0	0	12
2014	9	28	21	44	10	32	0	0	0	0	0	0	0	59.7	0	0	12
2014	9	28	21	54	10	33	0	0	0	0	0	0	0	59.56	0	0	12
2014	9	28	22	4	10	32	0	0	0	0	0	0	0	59.43	0	0	12
2014	9	28	22	14	10	32	0	0	0	0	0	0	0	59.31	0	0	12
2014	9	28	22	24	10	34	0	0	0	0	0	0	0	59.2	0	0	12
2014	9	28	22	34	10	32	0	0	0	0	0	0	0	59.11	0	0	12
2014	9	28	22	44	10	32	0	0	0	0	0	0	0	59	0	0	12
2014	9	28	22	54	10	32	0	0	0	0	0	0	0	58.91	0	0	12
2014	9	28	23	4	10	32	0	0	0	0	0	0	0	58.82	0	0	12
2014	9	28	23	14	10	33	0	0	0	0	0	0	0	58.73	0	0	12
2014	9	28	23	24	10	33	0	0	0	0	0	0	0	58.64	0	0	11.8
2014	9	28	23	34	10	33	0	0	0	0	0	0	0	58.55	0	0	12
2014	9	28	23	44	10	32	0	0	0	0	0	0	0	58.46	0	0	12
2014	9	28	23	54	10	33	0	0	0	0	0	0	0	58.37	0	0	12
2014	9	29	0	4	10	32	0	0	0	0	0	0	0	58.3	0	0	12
2014	9	29	0	14	10	33	0	0	0	0	0	0	0	58.21	0	0	12
2014	9	29	0	24	10	33	0	0	0	0	0	0	0	58.14	0	0	11.8
2014	9	29	0	34	10	32	0	0	0	0	0	0	0	58.08	0	0	12
2014	9	29	0	44	10	33	0	0	0	0	0	0	0	58.03	0	0	12
2014	9	29	0	54	10	33	0	0	0	0	0	0	0	57.97	0	0	12
2014	9	29	1	4	10	32	0	0	0	0	0	0	0	57.92	0	0	12
2014	9	29	1	14	10	33	0	0	0	0	0	0	0	57.88	0	0	12
2014	9	29	1	24	10	33	0	0	0	0	0	0	0	57.85	0	0	11.8
2014	9	29	1	34	10	32	0	0	0	0	0	0	0	57.79	0	0	12
2014	9	29	1	44	10	33	0	0	0	0	0	0	0	57.74	0	0	12
2014	9	29	1	54	10	33	0	0	0	0	0	0	0	57.7	0	0	12
2014	9	29	2	4	10	32	0	0	0	0	0	0	0	57.65	0	0	12
2014	9	29	2	14	10	32	0	0	0	0	0	0	0	57.6	0	0	11.8
2014	9	29	2	24	10	32	0	0	0	0	0	0	0	57.56	0	0	11.8
2014	9	29	2	34	10	33	0	0	0	0	0	0	0	57.51	0	0	11.8
2014	9	29	2	44	10	33	0	0	0	0	0	0	0	57.43	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	2	54	10	32	0	0	0	0	0	0	0	57.4	0	0	11.8
2014	9	29	3	4	10	32	0	0	0	0	0	0	0	57.36	0	0	11.8
2014	9	29	3	14	10	33	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	29	3	24	10	33	0	0	0	0	0	0	0	57.24	0	0	11.8
2014	9	29	3	34	10	33	0	0	0	0	0	0	0	57.18	0	0	11.8
2014	9	29	3	44	10	33	0	0	0	0	0	0	0	57.13	0	0	11.8
2014	9	29	3	54	10	33	0	0	0	0	0	0	0	57.06	0	0	11.8
2014	9	29	4	4	10	33	0	0	0	0	0	0	0	57	0	0	11.8
2014	9	29	4	14	10	33	0	0	0	0	0	0	0	56.95	0	0	11.8
2014	9	29	4	24	10	33	0	0	0	0	0	0	0	56.86	0	0	11.8
2014	9	29	4	34	10	33	0	0	0	0	0	0	0	56.79	0	0	11.8
2014	9	29	4	44	10	32	0	0	0	0	0	0	0	56.71	0	0	11.8
2014	9	29	4	54	10	33	0	0	0	0	0	0	0	56.62	0	0	11.8
2014	9	29	5	4	10	33	0	0	0	0	0	0	0	56.55	0	0	11.8
2014	9	29	5	14	10	33	0	0	0	0	0	0	0	56.44	0	0	11.8
2014	9	29	5	24	10	33	0	0	0	0	0	0	0	56.35	0	0	11.8
2014	9	29	5	34	10	33	0	0	0	0	0	0	0	56.28	0	0	11.8
2014	9	29	5	44	10	32	0	0	0	0	0	0	0	56.19	0	0	11.8
2014	9	29	5	54	10	33	0	0	0	0	0	0	0	56.12	0	0	11.8
2014	9	29	6	4	10	33	0	0	0	0	0	0	0	56.03	0	0	11.8
2014	9	29	6	14	10	33	0	0	0	0	0	0	0	55.94	0	0	11.8
2014	9	29	6	24	10	33	0	0	0	0	0	0	0	55.87	0	0	11.8
2014	9	29	6	34	10	33	0	0	0	0	0	0	0	55.76	0	0	11.8
2014	9	29	6	44	10	32	0	0	0	0	0	0	0	55.65	0	0	11.8
2014	9	29	6	54	10	34	0	0	0	0	0	0	0	55.58	0	0	11.8
2014	9	29	7	4	10	33	0	0	0	0	0	0	0	55.49	0	0	11.8
2014	9	29	7	14	10	33	0	0	0	0	0	0	0	55.4	0	0	11.8
2014	9	29	7	24	10	33	0	0	0	0	0	0	0	55.31	0	0	11.8
2014	9	29	7	34	10	33	0	0	0	0	0	0	0	55.22	0	0	11.8
2014	9	29	7	44	10	32	0	0	0	0	0	0	0	55.15	0	0	12.4
2014	9	29	7	54	10	34	0	0	0	0	0	0	0	55.06	0	0	12.8
2014	9	29	8	4	10	32	0	0	0	0	0	0	0	54.99	0	0	13
2014	9	29	8	14	10	33	0	0	0	0	0	0	0	54.95	0	0	13.2
2014	9	29	8	24	10	33	0	0	0	0	0	0	0	54.9	0	0	13.2
2014	9	29	8	34	10	34	0	0	0	0	0	0	0	54.86	0	0	13.2
2014	9	29	8	44	10	33	0	0	0	0	0	0	0	54.84	0	0	13.4
2014	9	29	8	54	10	33	0	0	0	0	0	0	0	54.84	0	0	13.4
2014	9	29	9	4	10	33	0	0	0	0	0	0	0	54.86	0	0	13.4
2014	9	29	9	14	10	33	0	0	0	0	0	0	0	54.86	0	0	13.6
2014	9	29	9	24	10	33	0	0	0	0	0	0	0	54.88	0	0	13.6
2014	9	29	9	34	10	33	0	0	0	0	0	0	0	54.93	0	0	13.6
2014	9	29	9	44	10	33	0	0	0	0	0	0	0	54.99	0	0	13.8
2014	9	29	9	54	10	33	0	0	0	0	0	0	0	55.76	0	0	13.8
2014	9	29	10	4	10	33	0	0	0	0	0	0	0	55.96	0	0	13.8
2014	9	29	10	14	10	33	0	0	0	0	0	0	0	55.89	0	0	13.6
2014	9	29	10	24	10	32	0	0	0	0	0	0	0	55.42	0	0	13.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	10	34	10	33	0	0	0	0	0	0	0	55.45	0	0	13.6
2014	9	29	10	44	10	33	0	0	0	0	0	0	0	55.56	0	0	13.6
2014	9	29	10	54	10	34	0	0	0	0	0	0	0	55.69	0	0	13.6
2014	9	29	11	4	10	33	0	0	0	0	0	0	0	55.89	0	0	13.6
2014	9	29	11	14	10	33	0	0	0	0	0	0	0	56.79	0	0	13.8
2014	9	29	11	24	10	33	0	0	0	0	0	0	0	57.07	0	0	13.6
2014	9	29	11	34	10	33	0	0	0	0	0	0	0	57.33	0	0	13.6
2014	9	29	11	44	10	33	0	0	0	0	0	0	0	57.56	0	0	13.6
2014	9	29	11	54	10	33	0	0	0	0	0	0	0	57.79	0	0	13.6
2014	9	29	12	4	10	33	0	0	0	0	0	0	0	58.05	0	0	13.6
2014	9	29	12	14	10	32	0	0	0	0	0	0	0	58.24	0	0	13.6
2014	9	29	12	24	10	33	0	0	0	0	0	0	0	58.48	0	0	13.6
2014	9	29	12	34	10	34	0	0	0	0	0	0	0	58.75	0	0	13.6
2014	9	29	12	44	10	32	0	0	0	0	0	0	0	59	0	0	13.6
2014	9	29	12	54	10	32	0	0	0	0	0	0	0	59.25	0	0	13.6
2014	9	29	13	4	10	33	0	0	0	0	0	0	0	59.54	0	0	13.6
2014	9	29	13	14	10	33	0	0	0	0	0	0	0	59.83	0	0	13.6
2014	9	29	13	24	10	32	0	0	0	0	0	0	0	60.12	0	0	13.4
2014	9	29	13	34	10	33	0	0	0	0	0	0	0	60.39	0	0	13.6
2014	9	29	13	44	10	32	0	0	0	0	0	0	0	60.66	0	0	13.6
2014	9	29	13	54	10	33	0	0	0	0	0	0	0	60.93	0	0	13.4
2014	9	29	14	4	10	32	0	0	0	0	0	0	0	61.2	0	0	13.4
2014	9	29	14	14	10	32	0	0	0	0	0	0	0	61.47	0	0	13.4
2014	9	29	14	24	10	32	0	0	0	0	0	0	0	61.75	0	0	13.2
2014	9	29	14	34	10	32	0	0	0	0	0	0	0	61.99	0	0	13.4
2014	9	29	14	44	10	32	0	0	0	0	0	0	0	62.26	0	0	13.4
2014	9	29	14	54	10	32	0	0	0	0	0	0	0	62.51	0	0	13.4
2014	9	29	15	4	10	32	0	0	0	0	0	0	0	62.73	0	0	13.4
2014	9	29	15	14	10	32	0	0	0	0	0	0	0	62.94	0	0	13.4
2014	9	29	15	24	10	32	0	0	0	0	0	0	0	63.14	0	0	13.2
2014	9	29	15	34	10	32	0	0	0	0	0	0	0	63.32	0	0	13.4
2014	9	29	15	44	10	32	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	29	15	54	10	32	0	0	0	0	0	0	0	63.68	0	0	13.2
2014	9	29	16	4	10	32	0	0	0	0	0	0	0	63.84	0	0	13
2014	9	29	16	14	10	32	0	0	0	0	0	0	0	63.97	0	0	13
2014	9	29	16	24	10	32	0	0	0	0	0	0	0	64.09	0	0	12.6
2014	9	29	16	34	10	33	0	0	0	0	0	0	0	64.2	0	0	12.6
2014	9	29	16	44	10	32	0	0	0	0	0	0	0	64.31	0	0	12.4
2014	9	29	16	54	10	32	0	0	0	0	0	0	0	64.4	0	0	12.4
2014	9	29	17	4	10	31	0	0	0	0	0	0	0	64.47	0	0	12.4
2014	9	29	17	14	10	32	0	0	0	0	0	0	0	64.53	0	0	12.2
2014	9	29	17	24	10	32	0	0	0	0	0	0	0	64.58	0	0	12.2
2014	9	29	17	34	10	32	0	0	0	0	0	0	0	64.62	0	0	12.2
2014	9	29	17	44	10	31	0	0	0	0	0	0	0	64.63	0	0	12.2
2014	9	29	17	54	10	32	0	0	0	0	0	0	0	64.65	0	0	12.2
2014	9	29	18	4	10	32	0	0	0	0	0	0	0	64.65	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	18	14	10	32	0	0	0	0	0	0	0	64.63	0	0	12.2
2014	9	29	18	24	10	32	0	0	0	0	0	0	0	64.6	0	0	12
2014	9	29	18	34	10	32	0	0	0	0	0	0	0	64.54	0	0	12.2
2014	9	29	18	44	10	32	0	0	0	0	0	0	0	64.47	0	0	12.2
2014	9	29	18	54	10	33	0	0	0	0	0	0	0	64.36	0	0	12.2
2014	9	29	19	4	10	31	0	0	0	0	0	0	0	64.26	0	0	12.2
2014	9	29	19	14	10	32	0	0	0	0	0	0	0	64.15	0	0	12.2
2014	9	29	19	24	10	32	0	0	0	0	0	0	0	64	0	0	12
2014	9	29	19	34	10	32	0	0	0	0	0	0	0	63.88	0	0	12.2
2014	9	29	19	44	10	31	0	0	0	0	0	0	0	63.72	0	0	12.2
2014	9	29	19	54	10	32	0	0	0	0	0	0	0	63.57	0	0	12.2
2014	9	29	20	4	10	32	0	0	0	0	0	0	0	63.41	0	0	12
2014	9	29	20	14	10	32	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	29	20	24	10	32	0	0	0	0	0	0	0	63.07	0	0	12
2014	9	29	20	34	10	32	0	0	0	0	0	0	0	62.91	0	0	12
2014	9	29	20	44	10	32	0	0	0	0	0	0	0	62.71	0	0	12
2014	9	29	20	54	10	31	0	0	0	0	0	0	0	62.53	0	0	12
2014	9	29	21	4	10	32	0	0	0	0	0	0	0	62.33	0	0	12
2014	9	29	21	14	10	33	0	0	0	0	0	0	0	62.13	0	0	12
2014	9	29	21	24	10	32	0	0	0	0	0	0	0	61.95	0	0	12
2014	9	29	21	34	10	31	0	0	0	0	0	0	0	61.75	0	0	12
2014	9	29	21	44	10	32	0	0	0	0	0	0	0	61.57	0	0	12
2014	9	29	21	54	10	32	0	0	0	0	0	0	0	61.39	0	0	12
2014	9	29	22	4	10	32	0	0	0	0	0	0	0	61.21	0	0	12
2014	9	29	22	14	10	33	0	0	0	0	0	0	0	61.05	0	0	12
2014	9	29	22	24	10	32	0	0	0	0	0	0	0	60.89	0	0	12
2014	9	29	22	34	10	32	0	0	0	0	0	0	0	60.75	0	0	12
2014	9	29	22	44	10	33	0	0	0	0	0	0	0	60.6	0	0	12
2014	9	29	22	54	10	32	0	0	0	0	0	0	0	60.48	0	0	12
2014	9	29	23	4	10	32	0	0	0	0	0	0	0	60.35	0	0	12
2014	9	29	23	14	10	33	0	0	0	0	0	0	0	60.26	0	0	12
2014	9	29	23	24	10	33	0	0	0	0	0	0	0	60.13	0	0	11.8
2014	9	29	23	34	10	32	0	0	0	0	0	0	0	60.04	0	0	12
2014	9	29	23	44	10	32	0	0	0	0	0	0	0	59.94	0	0	12
2014	9	29	23	54	10	31	0	0	0	0	0	0	0	59.85	0	0	12
2014	9	30	0	4	10	32	0	0	0	0	0	0	0	59.76	0	0	12
2014	9	30	0	14	10	32	0	0	0	0	0	0	0	59.67	0	0	12
2014	9	30	0	24	10	32	0	0	0	0	0	0	0	59.59	0	0	11.8
2014	9	30	0	34	10	31	0	0	0	0	0	0	0	59.5	0	0	12
2014	9	30	0	44	10	33	0	0	0	0	0	0	0	59.43	0	0	12
2014	9	30	0	54	10	33	0	0	0	0	0	0	0	59.36	0	0	12
2014	9	30	1	4	10	32	0	0	0	0	0	0	0	59.29	0	0	12
2014	9	30	1	14	10	33	0	0	0	0	0	0	0	59.22	0	0	12
2014	9	30	1	24	10	33	0	0	0	0	0	0	0	59.14	0	0	12
2014	9	30	1	34	10	32	0	0	0	0	0	0	0	59.07	0	0	12
2014	9	30	1	44	10	33	0	0	0	0	0	0	0	59	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	1	54	10	32	0	0	0	0	0	0	0	58.93	0	0	12
2014	9	30	2	4	10	33	0	0	0	0	0	0	0	58.87	0	0	12
2014	9	30	2	14	10	33	0	0	0	0	0	0	0	58.8	0	0	12
2014	9	30	2	24	10	33	0	0	0	0	0	0	0	58.75	0	0	12
2014	9	30	2	34	10	32	0	0	0	0	0	0	0	58.68	0	0	12
2014	9	30	2	44	10	33	0	0	0	0	0	0	0	58.62	0	0	12
2014	9	30	2	54	10	33	0	0	0	0	0	0	0	58.55	0	0	12
2014	9	30	3	4	10	33	0	0	0	0	0	0	0	58.48	0	0	12
2014	9	30	3	14	10	33	0	0	0	0	0	0	0	58.42	0	0	12
2014	9	30	3	24	10	32	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	30	3	34	10	33	0	0	0	0	0	0	0	58.32	0	0	12
2014	9	30	3	44	10	32	0	0	0	0	0	0	0	58.24	0	0	12
2014	9	30	3	54	10	33	0	0	0	0	0	0	0	58.17	0	0	11.8
2014	9	30	4	4	10	32	0	0	0	0	0	0	0	58.08	0	0	11.8
2014	9	30	4	14	10	32	0	0	0	0	0	0	0	58.03	0	0	11.8
2014	9	30	4	24	10	33	0	0	0	0	0	0	0	57.96	0	0	11.8
2014	9	30	4	34	10	32	0	0	0	0	0	0	0	57.87	0	0	11.8
2014	9	30	4	44	10	33	0	0	0	0	0	0	0	57.79	0	0	11.8
2014	9	30	4	54	10	33	0	0	0	0	0	0	0	57.72	0	0	11.8
2014	9	30	5	4	10	33	0	0	0	0	0	0	0	57.63	0	0	11.8
2014	9	30	5	14	10	33	0	0	0	0	0	0	0	57.54	0	0	11.8
2014	9	30	5	24	10	33	0	0	0	0	0	0	0	57.45	0	0	11.8
2014	9	30	5	34	10	33	0	0	0	0	0	0	0	57.34	0	0	11.8
2014	9	30	5	44	10	32	0	0	0	0	0	0	0	57.27	0	0	11.8
2014	9	30	5	54	10	33	0	0	0	0	0	0	0	57.18	0	0	11.8
2014	9	30	6	4	10	33	0	0	0	0	0	0	0	57.09	0	0	11.8
2014	9	30	6	14	10	33	0	0	0	0	0	0	0	56.98	0	0	11.8
2014	9	30	6	24	10	33	0	0	0	0	0	0	0	56.89	0	0	11.6
2014	9	30	6	34	10	33	0	0	0	0	0	0	0	56.8	0	0	11.8
2014	9	30	6	44	10	33	0	0	0	0	0	0	0	56.73	0	0	11.8
2014	9	30	6	54	10	33	0	0	0	0	0	0	0	56.64	0	0	11.8
2014	9	30	7	4	10	32	0	0	0	0	0	0	0	56.57	0	0	11.8
2014	9	30	7	14	10	32	0	0	0	0	0	0	0	56.5	0	0	11.8
2014	9	30	7	24	10	33	0	0	0	0	0	0	0	56.43	0	0	11.8
2014	9	30	7	34	10	34	0	0	0	0	0	0	0	56.35	0	0	11.8
2014	9	30	7	44	10	33	0	0	0	0	0	0	0	56.32	0	0	12.4
2014	9	30	7	54	10	33	0	0	0	0	0	0	0	56.25	0	0	12.8
2014	9	30	8	4	10	33	0	0	0	0	0	0	0	56.21	0	0	13
2014	9	30	8	14	10	32	0	0	0	0	0	0	0	56.17	0	0	13.2
2014	9	30	8	24	10	33	0	0	0	0	0	0	0	56.14	0	0	13.2
2014	9	30	8	34	10	33	0	0	0	0	0	0	0	56.12	0	0	13.4
2014	9	30	8	44	10	33	0	0	0	0	0	0	0	56.12	0	0	13.4
2014	9	30	8	54	10	33	0	0	0	0	0	0	0	56.12	0	0	13.4
2014	9	30	9	4	10	32	0	0	0	0	0	0	0	56.14	0	0	13.6
2014	9	30	9	14	10	33	0	0	0	0	0	0	0	56.17	0	0	13.6
2014	9	30	9	24	10	32	0	0	0	0	0	0	0	56.21	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	9	34	10	33	0	0	0	0	0	0	0	56.26	0	0	13.6
2014	9	30	9	44	10	33	0	0	0	0	0	0	0	56.32	0	0	13.6
2014	9	30	9	54	10	33	0	0	0	0	0	0	0	57.06	0	0	13.6
2014	9	30	10	4	10	33	0	0	0	0	0	0	0	57.25	0	0	13.6
2014	9	30	10	14	10	33	0	0	0	0	0	0	0	57	0	0	13.6
2014	9	30	10	24	10	33	0	0	0	0	0	0	0	56.75	0	0	13.6
2014	9	30	10	34	10	33	0	0	0	0	0	0	0	56.8	0	0	13.6
2014	9	30	10	44	10	32	0	0	0	0	0	0	0	56.91	0	0	13.6
2014	9	30	10	54	10	33	0	0	0	0	0	0	0	57.06	0	0	13.6
2014	9	30	11	4	10	33	0	0	0	0	0	0	0	57.42	0	0	13.6
2014	9	30	11	14	10	33	0	0	0	0	0	0	0	58.19	0	0	13.6
2014	9	30	11	24	10	33	0	0	0	0	0	0	0	58.46	0	0	13.4
2014	9	30	11	34	10	33	0	0	0	0	0	0	0	58.71	0	0	13.4
2014	9	30	11	44	10	33	0	0	0	0	0	0	0	58.93	0	0	13.4
2014	9	30	11	54	10	32	0	0	0	0	0	0	0	59.14	0	0	13.4
2014	9	30	12	4	10	32	0	0	0	0	0	0	0	59.38	0	0	13.4
2014	9	30	12	14	10	33	0	0	0	0	0	0	0	59.63	0	0	13.4
2014	9	30	12	24	10	32	0	0	0	0	0	0	0	59.85	0	0	13.4
2014	9	30	12	34	10	32	0	0	0	0	0	0	0	60.08	0	0	13.4
2014	9	30	12	44	10	33	0	0	0	0	0	0	0	60.33	0	0	13.4
2014	9	30	12	54	10	32	0	0	0	0	0	0	0	60.57	0	0	13.4
2014	9	30	13	4	10	32	0	0	0	0	0	0	0	60.84	0	0	13.4
2014	9	30	13	14	10	32	0	0	0	0	0	0	0	61.09	0	0	13.4
2014	9	30	13	24	10	32	0	0	0	0	0	0	0	61.36	0	0	13.4
2014	9	30	13	34	10	32	0	0	0	0	0	0	0	61.65	0	0	13.4
2014	9	30	13	44	10	33	0	0	0	0	0	0	0	61.92	0	0	13.4
2014	9	30	13	54	10	32	0	0	0	0	0	0	0	62.19	0	0	13.4
2014	9	30	14	4	10	33	0	0	0	0	0	0	0	62.44	0	0	13.4
2014	9	30	14	14	10	32	0	0	0	0	0	0	0	62.67	0	0	13.4
2014	9	30	14	24	10	32	0	0	0	0	0	0	0	62.94	0	0	13.4
2014	9	30	14	34	10	32	0	0	0	0	0	0	0	63.18	0	0	13.4
2014	9	30	14	44	10	31	0	0	0	0	0	0	0	63.39	0	0	13.4
2014	9	30	14	54	10	33	0	0	0	0	0	0	0	63.63	0	0	13.4
2014	9	30	15	4	10	32	0	0	0	0	0	0	0	63.82	0	0	13.4
2014	9	30	15	14	10	32	0	0	0	0	0	0	0	64.04	0	0	13.4
2014	9	30	15	24	10	32	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	30	15	34	10	32	0	0	0	0	0	0	0	64.42	0	0	13.4
2014	9	30	15	44	10	32	0	0	0	0	0	0	0	64.58	0	0	13.4
2014	9	30	15	54	10	32	0	0	0	0	0	0	0	64.74	0	0	13.2
2014	9	30	16	4	10	32	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	30	16	14	10	31	0	0	0	0	0	0	0	64.99	0	0	13
2014	9	30	16	24	10	32	0	0	0	0	0	0	0	65.08	0	0	12.6
2014	9	30	16	34	10	32	0	0	0	0	0	0	0	65.17	0	0	12.6
2014	9	30	16	44	10	32	0	0	0	0	0	0	0	65.25	0	0	12.4
2014	9	30	16	54	10	32	0	0	0	0	0	0	0	65.32	0	0	12.4
2014	9	30	17	4	10	32	0	0	0	0	0	0	0	65.35	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	17	14	10	32	0	0	0	0	0	0	0	65.39	0	0	12.2
2014	9	30	17	24	10	31	0	0	0	0	0	0	0	65.39	0	0	12.2
2014	9	30	17	34	10	31	0	0	0	0	0	0	0	65.39	0	0	12.2
2014	9	30	17	44	10	32	0	0	0	0	0	0	0	65.37	0	0	12.2
2014	9	30	17	54	10	32	0	0	0	0	0	0	0	65.37	0	0	12.2
2014	9	30	18	4	10	31	0	0	0	0	0	0	0	65.35	0	0	12.2
2014	9	30	18	14	10	32	0	0	0	0	0	0	0	65.34	0	0	12.2
2014	9	30	18	24	10	32	0	0	0	0	0	0	0	65.28	0	0	12
2014	9	30	18	34	10	32	0	0	0	0	0	0	0	65.23	0	0	12.2
2014	9	30	18	44	10	32	0	0	0	0	0	0	0	65.16	0	0	12.2
2014	9	30	18	54	10	32	0	0	0	0	0	0	0	65.08	0	0	12.2
2014	9	30	19	4	10	32	0	0	0	0	0	0	0	64.98	0	0	12.2
2014	9	30	19	14	10	31	0	0	0	0	0	0	0	64.87	0	0	12.2
2014	9	30	19	24	10	32	0	0	0	0	0	0	0	64.74	0	0	12
2014	9	30	19	34	10	31	0	0	0	0	0	0	0	64.6	0	0	12.2
2014	9	30	19	44	10	32	0	0	0	0	0	0	0	64.45	0	0	12.2
2014	9	30	19	54	10	32	0	0	0	0	0	0	0	64.29	0	0	12.2
2014	9	30	20	4	10	32	0	0	0	0	0	0	0	64.13	0	0	12
2014	9	30	20	14	10	31	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	30	20	24	10	32	0	0	0	0	0	0	0	63.79	0	0	12
2014	9	30	20	34	10	32	0	0	0	0	0	0	0	63.59	0	0	12
2014	9	30	20	44	10	32	0	0	0	0	0	0	0	63.39	0	0	12
2014	9	30	20	54	10	32	0	0	0	0	0	0	0	63.18	0	0	12
2014	9	30	21	4	10	32	0	0	0	0	0	0	0	62.98	0	0	12
2014	9	30	21	14	10	31	0	0	0	0	0	0	0	62.78	0	0	12
2014	9	30	21	24	10	32	0	0	0	0	0	0	0	62.56	0	0	12
2014	9	30	21	34	10	32	0	0	0	0	0	0	0	62.38	0	0	12
2014	9	30	21	44	10	32	0	0	0	0	0	0	0	62.2	0	0	12
2014	9	30	21	54	10	32	0	0	0	0	0	0	0	62.02	0	0	12
2014	9	30	22	4	10	32	0	0	0	0	0	0	0	61.84	0	0	12
2014	9	30	22	14	10	32	0	0	0	0	0	0	0	61.68	0	0	12
2014	9	30	22	24	10	32	0	0	0	0	0	0	0	61.54	0	0	12
2014	9	30	22	34	10	32	0	0	0	0	0	0	0	61.39	0	0	12
2014	9	30	22	44	10	33	0	0	0	0	0	0	0	61.25	0	0	12
2014	9	30	22	54	10	32	0	0	0	0	0	0	0	61.12	0	0	12
2014	9	30	23	4	10	33	0	0	0	0	0	0	0	61	0	0	12
2014	9	30	23	14	10	32	0	0	0	0	0	0	0	60.89	0	0	12
2014	9	30	23	24	10	32	0	0	0	0	0	0	0	60.78	0	0	11.8
2014	9	30	23	34	10	32	0	0	0	0	0	0	0	60.69	0	0	12
2014	9	30	23	44	10	33	0	0	0	0	0	0	0	60.62	0	0	12
2014	9	30	23	54	10	32	0	0	0	0	0	0	0	60.53	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	0	2	18	0.3	1	0.24	92.4	5.9445	1.2342
2014	9	1	0	12	18	0.3	1	0.25	99.1	5.9445	1.2857
2014	9	1	0	22	18	0.3	1	0.23	82.8	5.9445	1.2171
2014	9	1	0	32	18	0.3	1	0.25	90	5.9445	1.3028
2014	9	1	0	42	18	0.3	1	0.21	96.3	5.9445	1.08
2014	9	1	0	52	18	0.3	1	0.23	90	5.9638	1.2214
2014	9	1	1	2	18	0.3	1	0.27	87.9	5.9638	1.4106
2014	9	1	1	12	18	0.3	1	0.2	101.3	5.9638	1.0321
2014	9	1	1	22	18	0.3	1	0.23	101.6	5.9638	1.1698
2014	9	1	1	32	18	0.3	1	0.26	98.1	5.9638	1.3246
2014	9	1	1	42	18	0.3	1	0.21	103.6	5.9638	1.0665
2014	9	1	1	52	18	0.3	1	0.2	76	5.9638	1.0321
2014	9	1	2	2	18	0.3	1	0.26	95.1	5.9638	1.3418
2014	9	1	2	12	18	0.3	1	0.22	95.9	5.9638	1.1698
2014	9	1	2	22	18	0.3	1	0.26	98.7	5.9638	1.3418
2014	9	1	2	32	18	0.3	1	0.21	92.7	5.9638	1.101
2014	9	1	2	42	18	0.3	1	0.19	106.9	5.9638	0.9633
2014	9	1	2	52	18	0.3	1	0.29	93.3	5.9638	1.4966
2014	9	1	3	2	18	0.3	1	0.2	98.5	5.9638	1.0322
2014	9	1	3	12	18	0.3	1	0.22	106.5	5.9638	1.101
2014	9	1	3	22	18	0.3	1	0.26	84.9	5.9638	1.3418
2014	9	1	3	32	18	0.3	1	0.29	90.7	5.9638	1.4966
2014	9	1	3	42	18	0.3	1	0.23	81.9	5.9638	1.2042
2014	9	1	3	52	18	0.3	1	0.28	98.2	5.9638	1.4278
2014	9	1	4	2	18	0.3	1	0.18	90	5.9638	0.9634
2014	9	1	4	12	18	0.3	1	0.17	103.2	5.9638	0.8773
2014	9	1	4	22	18	0.3	1	0.25	98.5	5.9638	1.273
2014	9	1	4	32	18	0.3	1	0.17	93.3	5.9638	0.8945
2014	9	1	4	42	18	0.3	1	0.22	86.6	5.9638	1.1698
2014	9	1	4	52	18	0.3	1	0.22	99.6	5.9638	1.1182
2014	9	1	5	2	18	0.3	1	0.28	91.3	5.9638	1.4622
2014	9	1	5	12	18	0.3	1	0.17	88.9	5.9638	0.8945
2014	9	1	5	22	18	0.3	1	0.2	90	5.9638	1.0666
2014	9	1	5	32	18	0.3	1	0.3	93.2	5.9638	1.5483
2014	9	1	5	42	18	0.3	1	0.23	95	5.9638	1.187
2014	9	1	5	52	18	0.3	1	0.22	98.7	5.9638	1.1182
2014	9	1	6	2	18	0.3	1	0.26	97.2	5.9638	1.359
2014	9	1	6	12	18	0.3	1	0.25	87	5.9638	1.3074
2014	9	1	6	22	18	0.3	1	0.27	94.8	5.9638	1.4278
2014	9	1	6	32	18	0.3	1	0.25	102	5.9638	1.2902
2014	9	1	6	42	18	0.3	1	0.25	89.2	5.9638	1.2902
2014	9	1	6	52	18	0.3	1	0.3	102.7	5.9638	1.5311
2014	9	1	7	2	18	0.3	1	0.22	96.8	5.9638	1.1526
2014	9	1	7	12	18	0.3	1	0.22	86.6	5.9638	1.1698
2014	9	1	7	22	18	0.3	1	0.22	101.3	5.9638	1.1182
2014	9	1	7	32	18	0.3	1	0.16	91.2	5.9445	0.8229

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	7	42	18	0.3	1	0.18	75.5	5.9445	0.9257
2014	9	1	7	52	18	0.3	1	0.26	90	5.9445	1.3372
2014	9	1	8	2	18	0.3	1	0.3	84.3	5.9445	1.5429
2014	9	1	8	12	18	0.3	1	0.18	82.6	5.9445	0.9257
2014	9	1	8	22	18	0.3	1	0.2	90	5.9445	1.0629
2014	9	1	8	32	18	0.3	1	0.27	68.2	5.9251	1.2812
2014	9	1	8	42	18	0.3	1	0.25	92.3	5.9251	1.2812
2014	9	1	8	52	18	0.3	1	0.18	99.5	5.9251	0.9225
2014	9	1	9	2	18	0.3	1	0.26	95.7	5.9251	1.3666
2014	9	1	9	12	18	0.3	1	0.27	104.9	5.9251	1.3496
2014	9	1	9	22	18	0.3	1	0.27	97.5	5.9251	1.4179
2014	9	1	9	32	18	0.3	1	0.23	79.5	5.9251	1.1958
2014	9	1	9	42	18	0.3	1	0.16	56.6	5.9251	0.7004
2014	9	1	9	52	18	0.3	1	0.22	98.7	5.9057	1.1065
2014	9	1	10	2	18	0.3	1	0.22	83.2	5.9251	1.1445
2014	9	1	10	12	18	0.3	1	0.21	90	5.9057	1.0724
2014	9	1	10	22	18	0.3	1	0.28	88	5.9057	1.4299
2014	9	1	10	32	18	0.3	1	0.21	79.9	5.9057	1.0554
2014	9	1	10	42	18	0.3	1	0.18	90	5.8864	0.9499
2014	9	1	10	52	18	0.3	1	0.25	112.5	5.9057	1.1916
2014	9	1	11	2	18	0.3	1	0.23	90	5.8864	1.2044
2014	9	1	11	12	18	0.3	1	0.17	76.2	5.8864	0.8312
2014	9	1	11	22	18	0.3	1	0.23	98.9	5.867	1.1832
2014	9	1	11	32	18	0.3	1	0.19	87.1	5.867	0.9973
2014	9	1	11	42	18	0.3	1	0.18	90	5.867	0.9127
2014	9	1	11	52	18	0.3	1	0.2	100.6	5.867	0.9972
2014	9	1	12	2	18	0.3	1	0.21	79.2	5.867	1.0648
2014	9	1	12	12	18	0.3	1	0.25	81.5	5.8477	1.2463
2014	9	1	12	22	18	0.3	1	0.25	77.6	5.8477	1.2295
2014	9	1	12	32	18	0.3	1	0.24	86.1	5.8477	1.2295
2014	9	1	12	42	18	0.3	1	0.24	77.3	5.8477	1.1958
2014	9	1	12	52	18	0.3	1	0.23	76	5.8283	1.1412
2014	9	1	13	2	18	0.3	1	0.22	90	5.809	1.1204
2014	9	1	13	12	18	0.3	1	0.23	82.5	5.809	1.1371
2014	9	1	13	22	18	0.3	1	0.15	90	5.7896	0.7664
2014	9	1	13	32	18	0.3	1	0.2	79.8	5.7702	1.0127
2014	9	1	13	42	18	0.3	1	0.2	90.9	5.7702	1.0293
2014	9	1	13	52	18	0.3	1	0.19	73.8	5.7702	0.9131
2014	9	1	14	2	18	0.3	1	0.18	83.9	5.7702	0.9297
2014	9	1	14	12	18	0.3	1	0.25	90	5.7702	1.2783
2014	9	1	14	22	18	0.3	1	0.25	73.4	5.7702	1.2285
2014	9	1	14	32	18	0.3	1	0.15	101.1	5.7509	0.7609
2014	9	1	14	42	18	0.3	1	0.24	97.1	5.7509	1.191
2014	9	1	14	52	18	0.3	1	0.26	74.4	5.7509	1.2406
2014	9	1	15	2	18	0.3	1	0.18	86.8	5.7509	0.8932
2014	9	1	15	12	18	0.3	1	0.23	84.2	5.7509	1.1413

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	15	22	18	0.3	1	0.15	77.7	5.7509	0.7609
2014	9	1	15	32	18	0.3	1	0.19	77.2	5.7509	0.9428
2014	9	1	15	42	18	0.3	1	0.28	84	5.7509	1.4225
2014	9	1	15	52	18	0.3	1	0.16	71.9	5.7509	0.7609
2014	9	1	16	2	18	0.3	1	0.2	88.2	5.7315	1.0218
2014	9	1	16	12	18	0.3	1	0.25	75.8	5.7315	1.2361
2014	9	1	16	22	18	0.3	1	0.22	64.2	5.7315	0.9889
2014	9	1	16	32	18	0.3	1	0.27	77.3	5.7315	1.3185
2014	9	1	16	42	18	0.3	1	0.19	86.1	5.7315	0.9559
2014	9	1	16	52	18	0.3	1	0.27	92.8	5.7315	1.335
2014	9	1	17	2	18	0.3	1	0.24	91.6	5.7315	1.1866
2014	9	1	17	12	18	0.3	1	0.26	69.3	5.7315	1.2196
2014	9	1	17	22	18	0.3	1	0.2	97.7	5.7315	0.9724
2014	9	1	17	32	18	0.3	1	0.18	76.2	5.7315	0.8735
2014	9	1	17	42	18	0.3	1	0.23	74.2	5.7122	1.1002
2014	9	1	17	52	18	0.3	1	0.16	71.9	5.7315	0.7581
2014	9	1	18	2	18	0.3	1	0.16	84.3	5.7122	0.8211
2014	9	1	18	12	18	0.3	1	0.23	90	5.7122	1.1331
2014	9	1	18	22	18	0.3	1	0.19	75.3	5.7122	0.936
2014	9	1	18	32	18	0.3	1	0.22	83.1	5.7122	1.0838
2014	9	1	18	42	18	0.3	1	0.19	93	5.7122	0.936
2014	9	1	18	52	18	0.3	1	0.19	91	5.7122	0.9524
2014	9	1	19	2	18	0.3	1	0.26	81.1	5.7122	1.2644
2014	9	1	19	12	18	0.3	1	0.18	111	5.7122	0.8539
2014	9	1	19	22	18	0.3	1	0.14	70.7	5.7122	0.6569
2014	9	1	19	32	18	0.3	1	0.16	88.8	5.7122	0.8046
2014	9	1	19	42	18	0.3	1	0.11	101.6	5.7122	0.5583
2014	9	1	19	52	18	0.3	1	0.26	73.2	5.7122	1.248
2014	9	1	20	2	18	0.3	1	0.24	80.5	5.7122	1.1823
2014	9	1	20	12	18	0.3	1	0.16	87.7	5.7122	0.8211
2014	9	1	20	22	18	0.3	1	0.2	90	5.7122	0.9853
2014	9	1	20	32	18	0.3	1	0.14	100.8	5.7122	0.6897
2014	9	1	20	42	18	0.3	1	0.18	78.5	5.7122	0.8868
2014	9	1	20	52	18	0.3	1	0.16	116	5.6928	0.7036
2014	9	1	21	2	18	0.3	1	0.17	94.3	5.7122	0.8703
2014	9	1	21	12	18	0.3	1	0.19	91	5.7122	0.9689
2014	9	1	21	22	18	0.3	1	0.19	87.1	5.7122	0.9689
2014	9	1	21	32	18	0.3	1	0.18	84.8	5.7122	0.9032
2014	9	1	21	42	18	0.3	1	0.23	104	5.7122	1.1167
2014	9	1	21	52	18	0.3	1	0.26	79.2	5.7122	1.2973
2014	9	1	22	2	18	0.3	1	0.2	103.1	5.7122	0.9853
2014	9	1	22	12	18	0.3	1	0.11	90	5.7122	0.5419
2014	9	1	22	22	18	0.3	1	0.23	99.7	5.7122	1.1495
2014	9	1	22	32	18	0.3	1	0.2	96.7	5.7122	0.9853
2014	9	1	22	42	18	0.3	1	0.22	103.2	5.7122	1.051
2014	9	1	22	52	18	0.3	1	0.22	100.2	5.7122	1.1003

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	23	2	18	0.3	1	0.19	97.1	5.7122	0.9196
2014	9	1	23	12	18	0.3	1	0.22	90.9	5.7122	1.0839
2014	9	1	23	22	18	0.3	1	0.18	90	5.7122	0.9032
2014	9	1	23	32	18	0.3	1	0.17	98.7	5.7122	0.854
2014	9	1	23	42	18	0.3	1	0.2	67.3	5.7122	0.9032
2014	9	1	23	52	18	0.3	1	0.18	68.2	5.7122	0.8211
2014	9	2	0	2	18	0.3	1	0.21	77.5	5.6928	1.0308
2014	9	2	0	12	18	0.3	1	0.14	97.9	5.7122	0.7062
2014	9	2	0	22	18	0.3	1	0.18	98.3	5.6928	0.8999
2014	9	2	0	32	18	0.3	1	0.15	85	5.6928	0.7527
2014	9	2	0	42	18	0.3	1	0.18	93.1	5.6928	0.9
2014	9	2	0	52	18	0.3	1	0.19	111.8	5.6928	0.9
2014	9	2	1	2	18	0.3	1	0.13	90	5.6928	0.6709
2014	9	2	1	12	18	0.3	1	0.15	116.6	5.6928	0.6545
2014	9	2	1	22	18	0.3	1	0.16	114	5.6928	0.7363
2014	9	2	1	32	18	0.3	1	0.18	96.2	5.6928	0.9
2014	9	2	1	42	18	0.3	1	0.18	97.3	5.6928	0.9
2014	9	2	1	52	18	0.3	1	0.19	112.9	5.6928	0.8509
2014	9	2	2	2	18	0.3	1	0.17	96.5	5.6928	0.8672
2014	9	2	2	12	18	0.3	1	0.16	91.1	5.6928	0.8181
2014	9	2	2	22	18	0.3	1	0.14	115.3	5.6928	0.6218
2014	9	2	2	32	18	0.3	1	0.23	94.9	5.6928	1.1454
2014	9	2	2	42	18	0.3	1	0.09	92.2	5.6928	0.4254
2014	9	2	2	52	18	0.3	1	0.22	97.9	5.6928	1.0636
2014	9	2	3	2	18	0.3	1	0.13	90	5.6928	0.6382
2014	9	2	3	12	18	0.3	1	0.2	108.7	5.6928	0.9654
2014	9	2	3	22	18	0.3	1	0.2	103.6	5.6928	0.9491
2014	9	2	3	32	18	0.3	1	0.08	125	5.6928	0.3273
2014	9	2	3	42	18	0.3	1	0.12	123.7	5.6928	0.4909
2014	9	2	3	52	18	0.3	1	0.17	95.6	5.6928	0.8345
2014	9	2	4	2	18	0.3	1	0.18	114.2	5.6928	0.8018
2014	9	2	4	12	18	0.3	1	0.15	104.3	5.6928	0.7036
2014	9	2	4	22	18	0.3	1	0.2	99.6	5.6928	0.9654
2014	9	2	4	32	18	0.3	1	0.1	88.1	5.6928	0.4909
2014	9	2	4	42	18	0.3	1	0.1	99.2	5.6928	0.5073
2014	9	2	4	52	18	0.3	1	0.14	107.2	5.6735	0.6847
2014	9	2	5	2	18	0.3	1	0.14	101.8	5.6735	0.7011
2014	9	2	5	12	18	0.3	1	0.14	90	5.6735	0.7174
2014	9	2	5	22	18	0.3	1	0.17	112.6	5.6735	0.7826
2014	9	2	5	32	18	0.3	1	0.21	82.6	5.6735	1.0108
2014	9	2	5	42	18	0.3	1	0.24	90	5.6735	1.1902
2014	9	2	5	52	18	0.3	1	0.18	106.8	5.6735	0.8641
2014	9	2	6	2	18	0.3	1	0.19	70	5.6735	0.8967
2014	9	2	6	12	18	0.3	1	0.14	95.2	5.6735	0.7174
2014	9	2	6	22	18	0.3	1	0.16	90	5.6735	0.7826
2014	9	2	6	32	18	0.3	1	0.13	129.8	5.6735	0.4891

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	6	42	18	0.3	1	0.14	113.6	5.6735	0.6358
2014	9	2	6	52	18	0.3	1	0.19	102.1	5.6735	0.913
2014	9	2	7	2	18	0.3	1	0.17	84.6	5.6735	0.8641
2014	9	2	7	12	18	0.3	1	0.15	98.7	5.6735	0.75
2014	9	2	7	22	18	0.3	1	0.14	88.7	5.6735	0.7011
2014	9	2	7	32	18	0.3	1	0.22	90	5.6735	1.0924
2014	9	2	7	42	18	0.3	1	0.16	102.7	5.6735	0.7989
2014	9	2	7	52	18	0.3	1	0.23	102.6	5.6735	1.0924
2014	9	2	8	2	18	0.3	1	0.19	109.4	5.6735	0.8804
2014	9	2	8	12	18	0.3	1	0.19	90	5.6735	0.9456
2014	9	2	8	22	18	0.3	1	0.19	103.3	5.6735	0.8967
2014	9	2	8	32	18	0.3	1	0.18	97.4	5.6735	0.8804
2014	9	2	8	42	18	0.3	1	0.11	90	5.6735	0.5543
2014	9	2	8	52	18	0.3	1	0.25	90	5.6735	1.2391
2014	9	2	9	2	18	0.3	1	0.19	100.7	5.6735	0.9456
2014	9	2	9	12	18	0.3	1	0.13	90	5.6735	0.6521
2014	9	2	9	22	18	0.3	1	0.19	89	5.6735	0.9293
2014	9	2	9	32	18	0.3	1	0.12	85.1	5.6735	0.5706
2014	9	2	9	42	18	0.3	1	0.18	86.9	5.6735	0.8967
2014	9	2	9	52	18	0.3	1	0.24	91.6	5.6541	1.1858
2014	9	2	10	2	18	0.3	1	0.16	76.8	5.6541	0.7634
2014	9	2	10	12	18	0.3	1	0.14	92.7	5.6735	0.701
2014	9	2	10	22	18	0.3	1	0.19	96.9	5.6541	0.9421
2014	9	2	10	32	18	0.3	1	0.2	87.2	5.6541	1.0071
2014	9	2	10	42	18	0.3	1	0.2	95.7	5.6541	0.9746
2014	9	2	10	52	18	0.3	1	0.21	69	5.6735	0.9782
2014	9	2	11	2	18	0.3	1	0.19	114	5.6541	0.8771
2014	9	2	11	12	18	0.3	1	0.11	93.4	5.6541	0.5523
2014	9	2	11	22	18	0.3	1	0.14	86	5.6541	0.6985
2014	9	2	11	32	18	0.3	1	0.23	71.1	5.6735	1.0923
2014	9	2	11	42	18	0.3	1	0.18	84.7	5.6735	0.8804
2014	9	2	11	52	18	0.3	1	0.23	93.2	5.6735	1.1575
2014	9	2	12	2	18	0.3	1	0.23	90	5.6928	1.1618
2014	9	2	12	12	18	0.3	1	0.15	81.3	5.6928	0.7527
2014	9	2	12	22	18	0.3	1	0.19	85.1	5.6928	0.949
2014	9	2	12	32	18	0.3	1	0.16	74.5	5.7122	0.7719
2014	9	2	12	42	18	0.3	1	0.22	83.2	5.7122	1.1003
2014	9	2	12	52	18	0.3	1	0.19	85.1	5.7122	0.9525
2014	9	2	13	2	18	0.3	1	0.19	81.2	5.7122	0.9525
2014	9	2	13	12	18	0.3	1	0.22	71.6	5.7315	1.0384
2014	9	2	13	22	18	0.3	1	0.14	50.9	5.7315	0.5274
2014	9	2	13	32	18	0.3	1	0.23	97.5	5.7315	1.1208
2014	9	2	13	42	18	0.3	1	0.21	91.8	5.7315	1.0384
2014	9	2	13	52	18	0.3	1	0.23	87.5	5.7509	1.1414
2014	9	2	14	2	18	0.3	1	0.31	62.4	5.7509	1.3895
2014	9	2	14	12	18	0.3	1	0.25	72.7	5.7509	1.2241

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	14	22	18	0.3	1	0.13	71.6	5.7702	0.6475
2014	9	2	14	32	18	0.3	1	0.25	77.8	5.7702	1.2285
2014	9	2	14	42	18	0.3	1	0.29	71.4	5.7702	1.3779
2014	9	2	14	52	18	0.3	1	0.28	66.4	5.7702	1.2949
2014	9	2	15	2	18	0.3	1	0.28	62.8	5.7896	1.2663
2014	9	2	15	12	18	0.3	1	0.3	61.2	5.7896	1.3329
2014	9	2	15	22	18	0.3	1	0.25	60.7	5.809	1.1036
2014	9	2	15	32	18	0.3	1	0.27	69.8	5.8283	1.2754
2014	9	2	15	42	18	0.3	1	0.32	69.9	5.867	1.5718
2014	9	2	15	52	18	0.3	1	0.24	73.1	5.8477	1.162
2014	9	2	16	2	18	0.3	1	0.3	75.2	5.8864	1.4756
2014	9	2	16	12	18	0.3	1	0.23	81.8	5.8864	1.1703
2014	9	2	16	22	18	0.3	1	0.29	72.4	5.9057	1.4468
2014	9	2	16	32	18	0.3	1	0.3	72	5.9057	1.4638
2014	9	2	16	42	18	0.3	1	0.24	82.2	5.9057	1.2425
2014	9	2	16	52	18	0.3	1	0.27	52.3	5.9057	1.1234
2014	9	2	17	2	18	0.3	1	0.37	66.2	5.9251	1.7422
2014	9	2	17	12	18	0.3	1	0.24	65.6	5.9251	1.1273
2014	9	2	17	22	18	0.3	1	0.32	54.2	5.9251	1.3494
2014	9	2	17	32	18	0.3	1	0.34	60.2	5.9251	1.5202
2014	9	2	17	42	18	0.3	1	0.31	47.6	5.9445	1.1827
2014	9	2	17	52	18	0.3	1	0.26	76.1	5.9445	1.3198
2014	9	2	18	2	18	0.3	1	0.22	66.8	5.9445	1.0799
2014	9	2	18	12	18	0.3	1	0.27	64.4	5.9445	1.2513
2014	9	2	18	22	18	0.3	1	0.23	63.4	5.9445	1.097
2014	9	2	18	32	18	0.3	1	0.27	54.2	5.9638	1.1697
2014	9	2	18	42	18	0.3	1	0.28	82.7	5.9638	1.4793
2014	9	2	18	52	18	0.3	1	0.2	79.6	5.9638	1.032
2014	9	2	19	2	18	0.3	1	0.25	76.1	5.9638	1.2557
2014	9	2	19	12	18	0.3	1	0.22	85.8	5.9638	1.1697
2014	9	2	19	22	18	0.3	1	0.22	90.9	5.9638	1.1353
2014	9	2	19	32	18	0.3	1	0.22	85.7	5.9638	1.1525
2014	9	2	19	42	18	0.3	1	0.24	84.6	5.9638	1.2729
2014	9	2	19	52	18	0.3	1	0.21	99.9	5.9832	1.0874
2014	9	2	20	2	18	0.3	1	0.23	87.6	5.9832	1.2255
2014	9	2	20	12	18	0.3	1	0.18	76	5.9832	0.8976
2014	9	2	20	22	18	0.3	1	0.2	85.2	5.9832	1.0357
2014	9	2	20	32	18	0.3	1	0.26	90.7	5.9832	1.3464
2014	9	2	20	42	18	0.3	1	0.29	101.1	5.9832	1.5017
2014	9	2	20	52	18	0.3	1	0.26	81.4	5.9832	1.3636
2014	9	2	21	2	18	0.3	1	0.19	90	6.0025	0.9873
2014	9	2	21	12	18	0.3	1	0.17	79.8	6.0025	0.8661
2014	9	2	21	22	18	0.3	1	0.26	97.8	6.0025	1.3857
2014	9	2	21	32	18	0.3	1	0.34	111.6	6.0025	1.6629
2014	9	2	21	42	18	0.3	1	0.21	85.6	6.0025	1.1259
2014	9	2	21	52	18	0.3	1	0.2	111.1	6.0025	0.9873

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	22	2	18	0.3	1	0.24	94.8	6.0025	1.2472
2014	9	2	22	12	18	0.3	1	0.33	76.4	6.0025	1.7149
2014	9	2	22	22	18	0.3	1	0.28	90.7	6.0025	1.4897
2014	9	2	22	32	18	0.3	1	0.25	110.6	6.0219	1.2515
2014	9	2	22	42	18	0.3	1	0.29	92.6	6.0025	1.5416
2014	9	2	22	52	18	0.3	1	0.29	91.3	6.0025	1.5417
2014	9	2	23	2	18	0.3	1	0.29	97.1	6.0219	1.5296
2014	9	2	23	12	18	0.3	1	0.26	89.3	6.0219	1.3732
2014	9	2	23	22	18	0.3	1	0.28	90	6.0412	1.4651
2014	9	2	23	32	18	0.3	1	0.38	82.5	6.0412	1.9884
2014	9	2	23	42	18	0.3	1	0.33	95.2	6.0606	1.7327
2014	9	2	23	52	18	0.3	1	0.2	89.1	6.0606	1.0851
2014	9	3	0	2	18	0.3	1	0.24	98.6	6.0606	1.2777
2014	9	3	0	12	18	0.3	1	0.23	97.2	6.0412	1.2384
2014	9	3	0	22	18	0.3	1	0.15	97.4	6.0219	0.7996
2014	9	3	0	32	18	0.3	1	0.25	78.5	6.0219	1.2863
2014	9	3	0	42	18	0.3	1	0.25	91.5	6.0219	1.3037
2014	9	3	0	52	18	0.3	1	0.33	96.3	6.0219	1.7382
2014	9	3	1	2	18	0.3	1	0.27	98.5	6.0412	1.3954
2014	9	3	1	12	18	0.3	1	0.21	90	6.0412	1.0989
2014	9	3	1	22	18	0.3	1	0.27	95.6	6.0412	1.4128
2014	9	3	1	32	18	0.3	1	0.27	94.2	6.0606	1.4352
2014	9	3	1	42	18	0.3	1	0.2	101.3	6.08	1.0538
2014	9	3	1	52	18	0.3	1	0.21	96.1	6.08	1.1416
2014	9	3	2	2	18	0.3	1	0.21	82.9	6.08	1.124
2014	9	3	2	12	18	0.3	1	0.27	79	6.08	1.4401
2014	9	3	2	22	18	0.3	1	0.24	105.7	6.08	1.247
2014	9	3	2	32	18	0.3	1	0.22	90.9	6.08	1.1767
2014	9	3	2	42	18	0.3	1	0.25	78.1	6.08	1.3348
2014	9	3	2	52	18	0.3	1	0.24	94	6.08	1.2645
2014	9	3	3	2	18	0.3	1	0.25	88.5	6.08	1.3172
2014	9	3	3	12	18	0.3	1	0.23	90	6.08	1.2294
2014	9	3	3	22	18	0.3	1	0.23	107.2	6.08	1.1943
2014	9	3	3	32	18	0.3	1	0.22	103.6	6.08	1.1591
2014	9	3	3	42	18	0.3	1	0.27	93.5	6.08	1.4402
2014	9	3	3	52	18	0.3	1	0.21	112.5	6.08	1.0186
2014	9	3	4	2	18	0.3	1	0.25	94.5	6.08	1.3348
2014	9	3	4	12	18	0.3	1	0.26	90	6.0606	1.3827
2014	9	3	4	22	18	0.3	1	0.25	95.3	6.0412	1.3082
2014	9	3	4	32	18	0.3	1	0.23	77.4	6.0412	1.1687
2014	9	3	4	42	18	0.3	1	0.25	96	6.0412	1.3257
2014	9	3	4	52	18	0.3	1	0.3	94.4	6.0412	1.5699
2014	9	3	5	2	18	0.3	1	0.31	88.8	6.0412	1.6571
2014	9	3	5	12	18	0.3	1	0.27	97.5	6.0412	1.4478
2014	9	3	5	22	18	0.3	1	0.24	80.4	6.0606	1.2427
2014	9	3	5	32	18	0.3	1	0.28	96.6	6.0412	1.5001

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	5	42	18	0.3	1	0.26	83.4	6.0412	1.3605
2014	9	3	5	52	18	0.3	1	0.28	86.7	6.0606	1.5053
2014	9	3	6	2	18	0.3	1	0.22	96.8	6.0606	1.1727
2014	9	3	6	12	18	0.3	1	0.27	97	6.0412	1.4303
2014	9	3	6	22	18	0.3	1	0.22	104	6.0606	1.1202
2014	9	3	6	32	18	0.3	1	0.21	82.9	6.0606	1.1202
2014	9	3	6	42	18	0.3	1	0.29	90	6.0606	1.5228
2014	9	3	6	52	18	0.3	1	0.18	94.2	6.0606	0.9452
2014	9	3	7	2	18	0.3	1	0.25	102.2	6.0606	1.2952
2014	9	3	7	12	18	0.3	1	0.16	81.9	6.0606	0.8577
2014	9	3	7	22	18	0.3	1	0.23	89.2	6.0606	1.2252
2014	9	3	7	32	18	0.3	1	0.23	82.5	6.0606	1.1902
2014	9	3	7	42	18	0.3	1	0.3	93.7	6.0606	1.6103
2014	9	3	7	52	18	0.3	1	0.24	76	6.0606	1.2602
2014	9	3	8	2	18	0.3	1	0.24	98.6	6.0606	1.2777
2014	9	3	8	12	18	0.3	1	0.31	87.6	6.0412	1.6571
2014	9	3	8	22	18	0.3	1	0.21	92.7	6.0606	1.1202
2014	9	3	8	32	18	0.3	1	0.29	88.7	6.0606	1.5403
2014	9	3	8	42	18	0.3	1	0.3	92.5	6.0412	1.5699
2014	9	3	8	52	18	0.3	1	0.24	93.9	6.0412	1.2908
2014	9	3	9	2	18	0.3	1	0.21	100.1	6.0412	1.0815
2014	9	3	9	12	18	0.3	1	0.2	76.7	6.0025	1.0221
2014	9	3	9	22	18	0.3	1	0.26	96.4	6.08	1.4051
2014	9	3	9	32	18	0.3	1	0.19	94.9	6.08	1.0187
2014	9	3	9	42	18	0.3	1	0.2	100.4	6.08	1.0538
2014	9	3	9	52	18	0.3	1	0.21	94.5	6.08	1.124
2014	9	3	10	2	18	0.3	1	0.29	86.7	6.0606	1.5228
2014	9	3	10	12	18	0.3	1	0.27	85.8	6.0606	1.4353
2014	9	3	10	22	18	0.3	1	0.24	78.1	6.0606	1.2427
2014	9	3	10	32	18	0.3	1	0.29	93.3	6.0412	1.5175
2014	9	3	10	42	18	0.3	1	0.23	93.3	6.0219	1.2168
2014	9	3	10	52	18	0.3	1	0.25	87.7	6.0219	1.3037
2014	9	3	11	2	18	0.3	1	0.27	91.4	6.0025	1.4378
2014	9	3	11	12	18	0.3	1	0.23	85.1	5.9832	1.2084
2014	9	3	11	22	18	0.3	1	0.21	90	5.9832	1.1221
2014	9	3	11	32	18	0.3	1	0.24	70.1	5.9638	1.187
2014	9	3	11	42	18	0.3	1	0.31	76.7	5.9638	1.5998
2014	9	3	11	52	18	0.3	1	0.29	95.8	5.9638	1.5138
2014	9	3	12	2	18	0.3	1	0.35	74.4	5.9638	1.789
2014	9	3	12	12	18	0.3	1	0.25	78.5	5.9638	1.273
2014	9	3	12	22	18	0.3	1	0.28	73.7	5.9638	1.4106
2014	9	3	12	32	18	0.3	1	0.26	74.7	5.9638	1.3246
2014	9	3	12	42	18	0.3	1	0.3	68.2	5.9638	1.4622
2014	9	3	12	52	18	0.3	1	0.33	63.2	5.9638	1.531
2014	9	3	13	2	18	0.3	1	0.28	75.8	5.9445	1.4228
2014	9	3	13	12	18	0.3	1	0.33	88.3	5.9638	1.7374

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	13	22	18	0.3	1	0.32	78.1	5.9445	1.6285
2014	9	3	13	32	18	0.3	1	0.29	85.5	5.9445	1.5256
2014	9	3	13	42	18	0.3	1	0.26	80.7	5.9445	1.3542
2014	9	3	13	52	18	0.3	1	0.26	79.1	5.9445	1.337
2014	9	3	14	2	18	0.3	1	0.27	74.2	5.9445	1.337
2014	9	3	14	12	18	0.3	1	0.26	85	5.9445	1.3713
2014	9	3	14	22	18	0.3	1	0.24	72.1	5.9445	1.217
2014	9	3	14	32	18	0.3	1	0.27	70.7	5.9445	1.3199
2014	9	3	14	42	18	0.3	1	0.25	74.2	5.9445	1.2684
2014	9	3	14	52	18	0.3	1	0.27	71.1	5.9445	1.3541
2014	9	3	15	2	18	0.3	1	0.28	78.6	5.9445	1.4398
2014	9	3	15	12	18	0.3	1	0.33	83.2	5.9251	1.7252
2014	9	3	15	22	18	0.3	1	0.25	80.9	5.9251	1.2811
2014	9	3	15	32	18	0.3	1	0.3	77.5	5.9251	1.5373
2014	9	3	15	42	18	0.3	1	0.25	84.7	5.9251	1.2811
2014	9	3	15	52	18	0.3	1	0.23	84.3	5.9251	1.1957
2014	9	3	16	2	18	0.3	1	0.18	77.7	5.9251	0.9394
2014	9	3	16	12	18	0.3	1	0.22	78.9	5.9251	1.1273
2014	9	3	16	22	18	0.3	1	0.21	88.2	5.9057	1.1063
2014	9	3	16	32	18	0.3	1	0.26	77	5.9057	1.3276
2014	9	3	16	42	18	0.3	1	0.23	77.6	5.9057	1.1574
2014	9	3	16	52	18	0.3	1	0.29	80.3	5.9057	1.4978
2014	9	3	17	2	18	0.3	1	0.24	64.5	5.9057	1.1063
2014	9	3	17	12	18	0.3	1	0.22	90	5.9057	1.1404
2014	9	3	17	22	18	0.3	1	0.18	70.9	5.8864	0.882
2014	9	3	17	32	18	0.3	1	0.26	82.7	5.9057	1.3276
2014	9	3	17	42	18	0.3	1	0.24	87.6	5.9057	1.2425
2014	9	3	17	52	18	0.3	1	0.27	83	5.8864	1.3738
2014	9	3	18	2	18	0.3	1	0.25	75.6	5.8864	1.2551
2014	9	3	18	12	18	0.3	1	0.28	80	5.8864	1.4417
2014	9	3	18	22	18	0.3	1	0.21	81.9	5.8864	1.0685
2014	9	3	18	32	18	0.3	1	0.2	79.4	5.8864	1.0007
2014	9	3	18	42	18	0.3	1	0.23	97.3	5.8864	1.1872
2014	9	3	18	52	18	0.3	1	0.21	80.2	5.8864	1.0855
2014	9	3	19	2	18	0.3	1	0.27	64.4	5.8864	1.2381
2014	9	3	19	12	18	0.3	1	0.26	92.2	5.8864	1.3229
2014	9	3	19	22	18	0.3	1	0.23	89.2	5.8864	1.1703
2014	9	3	19	32	18	0.3	1	0.22	100.5	5.8864	1.1025
2014	9	3	19	42	18	0.3	1	0.17	96.8	5.8864	0.848
2014	9	3	19	52	18	0.3	1	0.18	86.8	5.8864	0.9159
2014	9	3	20	2	18	0.3	1	0.21	90	5.8864	1.0685
2014	9	3	20	12	18	0.3	1	0.24	87.7	5.8864	1.2551
2014	9	3	20	22	18	0.3	1	0.19	84	5.8864	0.9668
2014	9	3	20	32	18	0.3	1	0.2	90	5.8864	1.0516
2014	9	3	20	42	18	0.3	1	0.17	82	5.8864	0.8481
2014	9	3	20	52	18	0.3	1	0.26	84.1	5.8864	1.323

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	21	2	18	0.3	1	0.24	97.1	5.8864	1.2212
2014	9	3	21	12	18	0.3	1	0.21	95.4	5.9057	1.0894
2014	9	3	21	22	18	0.3	1	0.29	94.5	5.9057	1.5149
2014	9	3	21	32	18	0.3	1	0.24	85.3	5.9057	1.2426
2014	9	3	21	42	18	0.3	1	0.18	96.1	5.9057	0.9532
2014	9	3	21	52	18	0.3	1	0.25	81.7	5.9057	1.2766
2014	9	3	22	2	18	0.3	1	0.27	90	5.9057	1.3787
2014	9	3	22	12	18	0.3	1	0.3	81.9	5.9057	1.549
2014	9	3	22	22	18	0.3	1	0.29	80.1	5.9057	1.4639
2014	9	3	22	32	18	0.3	1	0.22	95	5.9057	1.1575
2014	9	3	22	42	18	0.3	1	0.25	107	5.9057	1.2256
2014	9	3	22	52	18	0.3	1	0.3	90	5.9057	1.549
2014	9	3	23	2	18	0.3	1	0.22	98.6	5.9251	1.1274
2014	9	3	23	12	18	0.3	1	0.21	82.9	5.9251	1.0932
2014	9	3	23	22	18	0.3	1	0.28	86.7	5.9251	1.469
2014	9	3	23	32	18	0.3	1	0.25	101.5	5.9251	1.2641
2014	9	3	23	42	18	0.3	1	0.2	97.7	5.9251	1.0078
2014	9	3	23	52	18	0.3	1	0.18	97.3	5.9251	0.9395
2014	9	4	0	2	18	0.3	1	0.2	69.4	5.9251	0.9566
2014	9	4	0	12	18	0.3	1	0.24	86.8	5.9445	1.2342
2014	9	4	0	22	18	0.3	1	0.17	71.9	5.9445	0.84
2014	9	4	0	32	18	0.3	1	0.25	96.8	5.9445	1.2856
2014	9	4	0	42	18	0.3	1	0.16	102.9	5.9445	0.8228
2014	9	4	0	52	18	0.3	1	0.22	87.4	5.9445	1.1314
2014	9	4	1	2	18	0.3	1	0.26	92.9	5.9445	1.3371
2014	9	4	1	12	18	0.3	1	0.26	105.3	5.9638	1.3246
2014	9	4	1	22	18	0.3	1	0.21	86.5	5.9638	1.1181
2014	9	4	1	32	18	0.3	1	0.28	75.8	5.9638	1.4278
2014	9	4	1	42	18	0.3	1	0.3	94.4	5.9638	1.5826
2014	9	4	1	52	18	0.3	1	0.29	83	5.9638	1.531
2014	9	4	2	2	18	0.3	1	0.24	94.8	5.9638	1.2386
2014	9	4	2	12	18	0.3	1	0.29	79.6	5.9638	1.4966
2014	9	4	2	22	18	0.3	1	0.21	102.5	5.9832	1.0875
2014	9	4	2	32	18	0.3	1	0.22	90	5.9832	1.1738
2014	9	4	2	42	18	0.3	1	0.18	105.5	5.9832	0.9322
2014	9	4	2	52	18	0.3	1	0.32	78.9	5.9832	1.6744
2014	9	4	3	2	18	0.3	1	0.33	91.1	5.9832	1.7262
2014	9	4	3	12	18	0.3	1	0.24	92.3	6.0025	1.2819
2014	9	4	3	22	18	0.3	1	0.2	84.5	6.0025	1.074
2014	9	4	3	32	18	0.3	1	0.24	90	6.0025	1.2472
2014	9	4	3	42	18	0.3	1	0.27	81	6.0219	1.4254
2014	9	4	3	52	18	0.3	1	0.23	90	6.0219	1.2342
2014	9	4	4	2	18	0.3	1	0.26	98.9	6.0412	1.3431
2014	9	4	4	12	18	0.3	1	0.24	82.3	6.0412	1.2908
2014	9	4	4	22	18	0.3	1	0.15	91.2	6.0606	0.8226
2014	9	4	4	32	18	0.3	1	0.28	96.8	6.0606	1.4702

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	4	42	18	0.3	1	0.23	79.3	6.0606	1.2077
2014	9	4	4	52	18	0.3	1	0.24	91.6	6.0606	1.2777
2014	9	4	5	2	18	0.3	1	0.27	86.5	6.0606	1.4352
2014	9	4	5	12	18	0.3	1	0.22	102	6.08	1.1592
2014	9	4	5	22	18	0.3	1	0.33	80.7	6.08	1.7212
2014	9	4	5	32	18	0.3	1	0.21	87.3	6.08	1.124
2014	9	4	5	42	18	0.3	1	0.18	111.8	6.08	0.8782
2014	9	4	5	52	18	0.3	1	0.24	107.2	6.08	1.247
2014	9	4	6	2	18	0.3	1	0.23	89.2	6.08	1.2294
2014	9	4	6	12	18	0.3	1	0.3	113.8	6.08	1.4753
2014	9	4	6	22	18	0.3	1	0.27	90.7	6.08	1.4226
2014	9	4	6	32	18	0.3	1	0.25	111.1	6.08	1.2294
2014	9	4	6	42	18	0.3	1	0.29	97.2	6.08	1.528
2014	9	4	6	52	18	0.3	1	0.23	80.9	6.08	1.2119
2014	9	4	7	2	18	0.3	1	0.25	103.5	6.08	1.3172
2014	9	4	7	12	18	0.3	1	0.21	105.1	6.08	1.1065
2014	9	4	7	22	18	0.3	1	0.29	85.5	6.08	1.5456
2014	9	4	7	32	18	0.3	1	0.19	96	6.08	1.0011
2014	9	4	7	42	18	0.3	1	0.3	82	6.08	1.6158
2014	9	4	7	52	18	0.3	1	0.27	104.7	6.08	1.4051
2014	9	4	8	2	18	0.3	1	0.28	71.4	6.08	1.4051
2014	9	4	8	12	18	0.3	1	0.26	87.9	6.08	1.4051
2014	9	4	8	22	18	0.3	1	0.29	90	6.08	1.5632
2014	9	4	8	32	18	0.3	1	0.28	87.3	6.08	1.5105
2014	9	4	8	42	18	0.3	1	0.21	86.4	6.08	1.1241
2014	9	4	8	52	18	0.3	1	0.15	71.2	6.0606	0.7702
2014	9	4	9	2	18	0.3	1	0.21	86.4	6.0606	1.1202
2014	9	4	9	12	18	0.3	1	0.3	82.4	6.08	1.5807
2014	9	4	9	22	18	0.3	1	0.24	73.3	6.0606	1.2252
2014	9	4	9	32	18	0.3	1	0.28	75.2	6.0606	1.4528
2014	9	4	9	42	18	0.3	1	0.29	78.3	6.0606	1.5228
2014	9	4	9	52	18	0.3	1	0.2	63.4	6.0606	0.9452
2014	9	4	10	2	18	0.3	1	0.26	76	6.0606	1.3303
2014	9	4	10	12	18	0.3	1	0.31	77	6.0606	1.5928
2014	9	4	10	22	18	0.3	1	0.23	76.9	6.0606	1.2077
2014	9	4	10	32	18	0.3	1	0.25	84.1	6.0606	1.3478
2014	9	4	10	42	18	0.3	1	0.29	84.2	6.0606	1.5403
2014	9	4	10	52	18	0.3	1	0.32	74.1	6.0606	1.6628
2014	9	4	11	2	18	0.3	1	0.21	87.3	6.0606	1.1202
2014	9	4	11	12	18	0.3	1	0.28	91.3	6.0412	1.4827
2014	9	4	11	22	18	0.3	1	0.3	80.4	6.0412	1.5524
2014	9	4	11	32	18	0.3	1	0.27	86.5	6.0412	1.4303
2014	9	4	11	42	18	0.3	1	0.29	61.7	6.0219	1.3559
2014	9	4	11	52	18	0.3	1	0.28	66.1	6.0219	1.3733
2014	9	4	12	2	18	0.3	1	0.33	80.8	6.0219	1.7209
2014	9	4	12	12	18	0.3	1	0.33	67	6.0219	1.5992

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	12	22	18	0.3	1	0.28	67.9	6.0219	1.3732
2014	9	4	12	32	18	0.3	1	0.27	74.6	6.0025	1.3858
2014	9	4	12	42	18	0.3	1	0.3	63.7	6.0025	1.4378
2014	9	4	12	52	18	0.3	1	0.43	75.9	6.0025	2.1999
2014	9	4	13	2	18	0.3	1	0.34	74.7	6.0025	1.7149
2014	9	4	13	12	18	0.3	1	0.34	74.2	6.0025	1.7149
2014	9	4	13	22	18	0.3	1	0.3	71.6	6.0025	1.507
2014	9	4	13	32	18	0.3	1	0.35	87.3	6.0025	1.8535
2014	9	4	13	42	18	0.3	1	0.31	90.6	6.0025	1.6283
2014	9	4	13	52	18	0.3	1	0.36	77.8	6.0025	1.8361
2014	9	4	14	2	18	0.3	1	0.27	65.3	5.9832	1.3119
2014	9	4	14	12	18	0.3	1	0.29	79.6	5.9832	1.5018
2014	9	4	14	22	18	0.3	1	0.31	77	5.9832	1.5708
2014	9	4	14	32	18	0.3	1	0.3	78.8	5.9832	1.5708
2014	9	4	14	42	18	0.3	1	0.36	76.8	5.9832	1.847
2014	9	4	14	52	18	0.3	1	0.36	71.9	5.9832	1.7952
2014	9	4	15	2	18	0.3	1	0.33	79.6	5.9832	1.6916
2014	9	4	15	12	18	0.3	1	0.33	72.1	5.9832	1.6571
2014	9	4	15	22	18	0.3	1	0.33	70.1	5.9832	1.6226
2014	9	4	15	32	18	0.3	1	0.3	74.9	5.9832	1.5363
2014	9	4	15	42	18	0.3	1	0.29	75	5.9832	1.4845
2014	9	4	15	52	18	0.3	1	0.31	73.5	5.9832	1.5708
2014	9	4	16	2	18	0.3	1	0.3	76.1	5.9832	1.5362
2014	9	4	16	12	18	0.3	1	0.28	83.4	5.9832	1.4845
2014	9	4	16	22	18	0.3	1	0.31	88.2	5.9832	1.6053
2014	9	4	16	32	18	0.3	1	0.15	77.2	5.9832	0.7595
2014	9	4	16	42	18	0.3	1	0.3	68.4	5.9832	1.4845
2014	9	4	16	52	18	0.3	1	0.26	86.4	5.9832	1.3809
2014	9	4	17	2	18	0.3	1	0.27	84.5	5.9832	1.4327
2014	9	4	17	12	18	0.3	1	0.28	83.3	5.9832	1.4672
2014	9	4	17	22	18	0.3	1	0.24	65.6	5.9832	1.1392
2014	9	4	17	32	18	0.3	1	0.28	79.1	5.9832	1.4327
2014	9	4	17	42	18	0.3	1	0.32	68.7	5.9832	1.5535
2014	9	4	17	52	18	0.3	1	0.31	80.2	5.9832	1.6053
2014	9	4	18	2	18	0.3	1	0.27	89.3	5.9832	1.4327
2014	9	4	18	12	18	0.3	1	0.25	95.3	5.9832	1.2946
2014	9	4	18	22	18	0.3	1	0.21	73	5.9832	1.0702
2014	9	4	18	32	18	0.3	1	0.22	76.8	5.9832	1.1047
2014	9	4	18	42	18	0.3	1	0.24	82	5.9832	1.2255
2014	9	4	18	52	18	0.3	1	0.25	74.9	5.9832	1.2773
2014	9	4	19	2	18	0.3	1	0.24	83.8	5.9832	1.2773
2014	9	4	19	12	18	0.3	1	0.23	94	5.9832	1.2255
2014	9	4	19	22	18	0.3	1	0.26	96.4	5.9832	1.3809
2014	9	4	19	32	18	0.3	1	0.27	96.3	5.9832	1.4154
2014	9	4	19	42	18	0.3	1	0.29	86.7	5.9832	1.519
2014	9	4	19	52	18	0.3	1	0.25	93.8	5.9832	1.3119

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	20	2	18	0.3	1	0.28	83.9	5.9832	1.45
2014	9	4	20	12	18	0.3	1	0.19	92	5.9832	1.0012
2014	9	4	20	22	18	0.3	1	0.24	93.1	5.9832	1.2601
2014	9	4	20	32	18	0.3	1	0.28	86	5.9832	1.4672
2014	9	4	20	42	18	0.3	1	0.28	78.6	5.9832	1.45
2014	9	4	20	52	18	0.3	1	0.31	90.6	5.9832	1.6053
2014	9	4	21	2	18	0.3	1	0.27	87.9	5.9832	1.4327
2014	9	4	21	12	18	0.3	1	0.28	95.4	5.9832	1.4672
2014	9	4	21	22	18	0.3	1	0.19	80.9	5.9832	0.9667
2014	9	4	21	32	18	0.3	1	0.26	97.3	6.0025	1.3511
2014	9	4	21	42	18	0.3	1	0.25	90.8	5.9832	1.3119
2014	9	4	21	52	18	0.3	1	0.24	73.1	5.9832	1.1911
2014	9	4	22	2	18	0.3	1	0.16	97	6.0025	0.8488
2014	9	4	22	12	18	0.3	1	0.3	84.4	5.9832	1.5881
2014	9	4	22	22	18	0.3	1	0.32	88.2	6.0025	1.6629
2014	9	4	22	32	18	0.3	1	0.27	84.5	6.0025	1.4377
2014	9	4	22	42	18	0.3	1	0.21	111	6.0025	1.0393
2014	9	4	22	52	18	0.3	1	0.31	104.6	6.0025	1.5936
2014	9	4	23	2	18	0.3	1	0.26	91.4	6.0025	1.3858
2014	9	4	23	12	18	0.3	1	0.24	90	6.0025	1.2472
2014	9	4	23	22	18	0.3	1	0.26	92.9	6.0025	1.3511
2014	9	4	23	32	18	0.3	1	0.29	100.4	6.0025	1.507
2014	9	4	23	42	18	0.3	1	0.25	97.4	6.0025	1.3338
2014	9	4	23	52	18	0.3	1	0.33	79.7	6.0025	1.7149
2014	9	5	0	2	18	0.3	1	0.32	87.1	6.0219	1.7035
2014	9	5	0	12	18	0.3	1	0.23	72.3	6.0219	1.1472
2014	9	5	0	22	18	0.3	1	0.2	90	6.0219	1.0429
2014	9	5	0	32	18	0.3	1	0.22	83.2	6.0412	1.1687
2014	9	5	0	42	18	0.3	1	0.27	87.2	6.0219	1.4254
2014	9	5	0	52	18	0.3	1	0.29	96.5	6.0412	1.535
2014	9	5	1	2	18	0.3	1	0.31	90	6.0412	1.6571
2014	9	5	1	12	18	0.3	1	0.23	95	6.0412	1.2035
2014	9	5	1	22	18	0.3	1	0.23	97.2	6.0412	1.2384
2014	9	5	1	32	18	0.3	1	0.31	91.8	6.0412	1.6396
2014	9	5	1	42	18	0.3	1	0.26	96.4	6.0606	1.4002
2014	9	5	1	52	18	0.3	1	0.25	92.2	6.0606	1.3477
2014	9	5	2	2	18	0.3	1	0.23	94	6.0606	1.2427
2014	9	5	2	12	18	0.3	1	0.19	95.8	6.0606	1.0327
2014	9	5	2	22	18	0.3	1	0.29	94.5	6.0606	1.5402
2014	9	5	2	32	18	0.3	1	0.23	106.6	6.08	1.1767
2014	9	5	2	42	18	0.3	1	0.32	88.8	6.08	1.7212
2014	9	5	2	52	18	0.3	1	0.23	86	6.08	1.247
2014	9	5	3	2	18	0.3	1	0.26	90.7	6.08	1.3875
2014	9	5	3	12	18	0.3	1	0.19	95.8	6.08	1.0362
2014	9	5	3	22	18	0.3	1	0.29	94.5	6.08	1.5455
2014	9	5	3	32	18	0.3	1	0.22	85.7	6.08	1.1767

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	3	42	18	0.3	1	0.28	97.3	6.08	1.5104
2014	9	5	3	52	18	0.3	1	0.28	76.6	6.08	1.4753
2014	9	5	4	2	18	0.3	1	0.23	98.9	6.0993	1.2336
2014	9	5	4	12	18	0.3	1	0.25	82.6	6.0993	1.357
2014	9	5	4	22	18	0.3	1	0.24	92.3	6.0993	1.3041
2014	9	5	4	32	18	0.3	1	0.25	111.8	6.0993	1.2336
2014	9	5	4	42	18	0.3	1	0.24	109.9	6.0993	1.216
2014	9	5	4	52	18	0.3	1	0.3	95.7	6.0993	1.5861
2014	9	5	5	2	18	0.3	1	0.17	98.7	6.0993	0.9164
2014	9	5	5	12	18	0.3	1	0.27	89.3	6.0993	1.4451
2014	9	5	5	22	18	0.3	1	0.21	97.1	6.0993	1.1279
2014	9	5	5	32	18	0.3	1	0.23	94.1	6.0993	1.2336
2014	9	5	5	42	18	0.3	1	0.21	94.5	6.1187	1.1141
2014	9	5	5	52	18	0.3	1	0.23	109.5	6.1187	1.1494
2014	9	5	6	2	18	0.3	1	0.18	105.5	6.1187	0.9549
2014	9	5	6	12	18	0.3	1	0.27	101.3	6.1187	1.4147
2014	9	5	6	22	18	0.3	1	0.28	103.7	6.1187	1.4501
2014	9	5	6	32	18	0.3	1	0.23	103.8	6.1187	1.2202
2014	9	5	6	42	18	0.3	1	0.18	106.8	6.1187	0.9372
2014	9	5	6	52	18	0.3	1	0.19	90	6.1187	1.0257
2014	9	5	7	2	18	0.3	1	0.28	81.3	6.1187	1.5031
2014	9	5	7	12	18	0.3	1	0.36	103.2	6.1187	1.8922
2014	9	5	7	22	18	0.3	1	0.27	102	6.1187	1.4147
2014	9	5	7	32	18	0.3	1	0.26	92.9	6.1187	1.3793
2014	9	5	7	42	18	0.3	1	0.2	91.9	6.1187	1.0787
2014	9	5	7	52	18	0.3	1	0.26	94.3	6.1187	1.397
2014	9	5	8	2	18	0.3	1	0.3	92.5	6.1187	1.6092
2014	9	5	8	12	18	0.3	1	0.2	100.4	6.1187	1.061
2014	9	5	8	22	18	0.3	1	0.27	101	6.1187	1.4501
2014	9	5	8	32	18	0.3	1	0.24	90	6.1187	1.3086
2014	9	5	8	42	18	0.3	1	0.28	109.7	6.1187	1.4324
2014	9	5	8	52	18	0.3	1	0.23	90	6.1187	1.2202
2014	9	5	9	2	18	0.3	1	0.29	90.7	6.1187	1.5385
2014	9	5	9	12	18	0.3	1	0.2	91.9	6.1187	1.0787
2014	9	5	9	22	18	0.3	1	0.28	95.4	6.1187	1.4854
2014	9	5	9	32	18	0.3	1	0.31	85.7	6.1187	1.6446
2014	9	5	9	42	18	0.3	1	0.32	91.2	6.1187	1.6976
2014	9	5	9	52	18	0.3	1	0.24	86.1	6.1187	1.2909
2014	9	5	10	2	18	0.3	1	0.34	81.1	6.1187	1.8037
2014	9	5	10	12	18	0.3	1	0.23	90	6.1187	1.2202
2014	9	5	10	22	18	0.3	1	0.29	99.2	6.1187	1.5208
2014	9	5	10	32	18	0.3	1	0.26	101.7	6.1187	1.3616
2014	9	5	10	42	18	0.3	1	0.28	97.5	6.1187	1.4854
2014	9	5	10	52	18	0.3	1	0.28	92	6.1187	1.4854
2014	9	5	11	2	18	0.3	1	0.29	90	6.0993	1.5685
2014	9	5	11	12	18	0.3	1	0.2	77.8	6.0993	1.0574

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	11	22	18	0.3	1	0.28	79.9	6.0993	1.4804
2014	9	5	11	32	18	0.3	1	0.28	88.7	6.0993	1.498
2014	9	5	11	42	18	0.3	1	0.23	75.4	6.0993	1.216
2014	9	5	11	52	18	0.3	1	0.28	81.2	6.0993	1.4804
2014	9	5	12	2	18	0.3	1	0.27	90	6.0993	1.4451
2014	9	5	12	12	18	0.3	1	0.26	81.3	6.0993	1.3746
2014	9	5	12	22	18	0.3	1	0.25	71.8	6.0993	1.2865
2014	9	5	12	32	18	0.3	1	0.27	88.6	6.08	1.4401
2014	9	5	12	42	18	0.3	1	0.27	71.6	6.0993	1.3746
2014	9	5	12	52	18	0.3	1	0.32	83.6	6.08	1.7211
2014	9	5	13	2	18	0.3	1	0.31	70.2	6.08	1.5631
2014	9	5	13	12	18	0.3	1	0.21	87.3	6.08	1.124
2014	9	5	13	22	18	0.3	1	0.25	82.6	6.0606	1.3477
2014	9	5	13	32	18	0.3	1	0.32	77.5	6.0606	1.6627
2014	9	5	13	42	18	0.3	1	0.28	65.2	6.0412	1.3605
2014	9	5	13	52	18	0.3	1	0.35	67.7	6.0412	1.7442
2014	9	5	14	2	18	0.3	1	0.32	74.5	6.0219	1.6339
2014	9	5	14	12	18	0.3	1	0.3	65.1	6.0219	1.4601
2014	9	5	14	22	18	0.3	1	0.39	77.7	6.0219	1.9989
2014	9	5	14	32	18	0.3	1	0.29	66.3	6.0219	1.4253
2014	9	5	14	42	18	0.3	1	0.25	78.8	6.0025	1.3164
2014	9	5	14	52	18	0.3	1	0.36	75.8	6.0025	1.8534
2014	9	5	15	2	18	0.3	1	0.32	80	6.0025	1.6629
2014	9	5	15	12	18	0.3	1	0.24	68.6	6.0025	1.1952
2014	9	5	15	22	18	0.3	1	0.3	74.9	6.0025	1.5416
2014	9	5	15	32	18	0.3	1	0.27	87.9	6.0025	1.403
2014	9	5	15	42	18	0.3	1	0.31	85.7	6.0025	1.6282
2014	9	5	15	52	18	0.3	1	0.34	76.8	6.0025	1.7668
2014	9	5	16	2	18	0.3	1	0.33	83.7	6.0025	1.7148
2014	9	5	16	12	18	0.3	1	0.28	88	6.0025	1.4723
2014	9	5	16	22	18	0.3	1	0.29	77.7	6.0025	1.507
2014	9	5	16	32	18	0.3	1	0.27	75.1	5.9832	1.3636
2014	9	5	16	42	18	0.3	1	0.32	81.7	5.9832	1.6571
2014	9	5	16	52	18	0.3	1	0.29	70.1	5.9832	1.4327
2014	9	5	17	2	18	0.3	1	0.31	58.8	5.9832	1.3982
2014	9	5	17	12	18	0.3	1	0.27	71.8	5.9832	1.3636
2014	9	5	17	22	18	0.3	1	0.34	63.9	5.9832	1.588
2014	9	5	17	32	18	0.3	1	0.34	66.9	5.9832	1.6571
2014	9	5	17	42	18	0.3	1	0.23	76.8	5.9832	1.1738
2014	9	5	17	52	18	0.3	1	0.27	72.4	5.9832	1.3636
2014	9	5	18	2	18	0.3	1	0.26	92.9	5.9832	1.3636
2014	9	5	18	12	18	0.3	1	0.26	58.5	5.9832	1.1565
2014	9	5	18	22	18	0.3	1	0.28	88.6	5.9832	1.45
2014	9	5	18	32	18	0.3	1	0.26	70.9	5.9832	1.2946
2014	9	5	18	42	18	0.3	1	0.2	74.6	5.9832	1.0012
2014	9	5	18	52	18	0.3	1	0.23	72.6	5.9832	1.1565

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	19	2	18	0.3	1	0.34	75	5.9832	1.7434
2014	9	5	19	12	18	0.3	1	0.19	81	5.9832	0.9839
2014	9	5	19	22	18	0.3	1	0.29	84.1	5.9832	1.5018
2014	9	5	19	32	18	0.3	1	0.14	68.7	5.9832	0.7077
2014	9	5	19	42	18	0.3	1	0.24	94.6	5.9832	1.2774
2014	9	5	19	52	18	0.3	1	0.3	95.1	5.9832	1.5535
2014	9	5	20	2	18	0.3	1	0.32	88.2	5.9832	1.6571
2014	9	5	20	12	18	0.3	1	0.3	93.1	5.9832	1.5708
2014	9	5	20	22	18	0.3	1	0.29	95.9	5.9832	1.5018
2014	9	5	20	32	18	0.3	1	0.28	86.7	5.9832	1.4845
2014	9	5	20	42	18	0.3	1	0.16	84.1	5.9832	0.8286
2014	9	5	20	52	18	0.3	1	0.25	80	5.9832	1.2774
2014	9	5	21	2	18	0.3	1	0.28	93.4	5.9832	1.45
2014	9	5	21	12	18	0.3	1	0.25	64.1	5.9832	1.1738
2014	9	5	21	22	18	0.3	1	0.27	79	5.9832	1.4155
2014	9	5	21	32	18	0.3	1	0.29	88.7	5.9832	1.5363
2014	9	5	21	42	18	0.3	1	0.31	90	5.9832	1.6399
2014	9	5	21	52	18	0.3	1	0.27	95.5	5.9832	1.4328
2014	9	5	22	2	18	0.3	1	0.25	93.1	5.9832	1.2947
2014	9	5	22	12	18	0.3	1	0.25	90.8	5.9832	1.3119
2014	9	5	22	22	18	0.3	1	0.25	94.6	5.9832	1.2947
2014	9	5	22	32	18	0.3	1	0.19	93	6.0025	0.9874
2014	9	5	22	42	18	0.3	1	0.24	81.2	5.9832	1.2256
2014	9	5	22	52	18	0.3	1	0.24	92.4	6.0025	1.2472
2014	9	5	23	2	18	0.3	1	0.24	86.1	6.0025	1.2819
2014	9	5	23	12	18	0.3	1	0.21	72.7	6.0025	1.0567
2014	9	5	23	22	18	0.3	1	0.26	99.3	6.0025	1.3685
2014	9	5	23	32	18	0.3	1	0.2	95.7	6.0025	1.0394
2014	9	5	23	42	18	0.3	1	0.25	119.6	6.0025	1.1606
2014	9	5	23	52	18	0.3	1	0.2	97.7	6.0025	1.022
2014	9	6	0	2	18	0.3	1	0.28	93.4	6.0025	1.4551
2014	9	6	0	12	18	0.3	1	0.22	99.5	6.0025	1.1433
2014	9	6	0	22	18	0.3	1	0.26	90	6.0025	1.3512
2014	9	6	0	32	18	0.3	1	0.33	96.8	6.0025	1.7323
2014	9	6	0	42	18	0.3	1	0.31	100.8	6.0219	1.634
2014	9	6	0	52	18	0.3	1	0.22	105.5	6.0025	1.126
2014	9	6	1	2	18	0.3	1	0.29	96.4	6.0219	1.5471
2014	9	6	1	12	18	0.3	1	0.28	86.6	6.0219	1.4602
2014	9	6	1	22	18	0.3	1	0.29	99.8	6.0219	1.5123
2014	9	6	1	32	18	0.3	1	0.18	77.2	6.0219	0.9213
2014	9	6	1	42	18	0.3	1	0.23	94	6.0412	1.2385
2014	9	6	1	52	18	0.3	1	0.23	90.8	6.0412	1.221
2014	9	6	2	2	18	0.3	1	0.28	80.4	6.0606	1.4528
2014	9	6	2	12	18	0.3	1	0.31	84	6.0606	1.6628
2014	9	6	2	22	18	0.3	1	0.33	102.1	6.0606	1.7153
2014	9	6	2	32	18	0.3	1	0.26	71.1	6.0412	1.3257

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	2	42	18	0.3	1	0.23	86.7	6.0606	1.2252
2014	9	6	2	52	18	0.3	1	0.25	101.3	6.0606	1.3127
2014	9	6	3	2	18	0.3	1	0.24	89.2	6.0606	1.2602
2014	9	6	3	12	18	0.3	1	0.26	90	6.0606	1.4003
2014	9	6	3	22	18	0.3	1	0.23	77.9	6.0606	1.2252
2014	9	6	3	32	18	0.3	1	0.24	86.1	6.0606	1.2952
2014	9	6	3	42	18	0.3	1	0.25	97.6	6.0606	1.3127
2014	9	6	3	52	18	0.3	1	0.22	101.3	6.0606	1.1377
2014	9	6	4	2	18	0.3	1	0.28	75.6	6.0412	1.4303
2014	9	6	4	12	18	0.3	1	0.25	91.5	6.0606	1.3303
2014	9	6	4	22	18	0.3	1	0.31	91.2	6.0412	1.6222
2014	9	6	4	32	18	0.3	1	0.26	77.7	6.0412	1.3606
2014	9	6	4	42	18	0.3	1	0.27	74.2	6.0412	1.3606
2014	9	6	4	52	18	0.3	1	0.23	95	6.0412	1.2036
2014	9	6	5	2	18	0.3	1	0.21	85.5	6.0412	1.1164
2014	9	6	5	12	18	0.3	1	0.23	92.5	6.0412	1.2036
2014	9	6	5	22	18	0.3	1	0.23	110	6.0412	1.1513
2014	9	6	5	32	18	0.3	1	0.26	90.7	6.0412	1.378
2014	9	6	5	42	18	0.3	1	0.24	95.5	6.0219	1.269
2014	9	6	5	52	18	0.3	1	0.16	99.7	6.0219	0.817
2014	9	6	6	2	18	0.3	1	0.22	99.6	6.0219	1.1299
2014	9	6	6	12	18	0.3	1	0.23	104.6	6.0219	1.1995
2014	9	6	6	22	18	0.3	1	0.28	87.3	6.0219	1.4776
2014	9	6	6	32	18	0.3	1	0.28	88.7	6.0219	1.495
2014	9	6	6	42	18	0.3	1	0.28	94.7	6.0025	1.4725
2014	9	6	6	52	18	0.3	1	0.27	104.9	6.0219	1.3733
2014	9	6	7	2	18	0.3	1	0.23	104	6.0025	1.178
2014	9	6	7	12	18	0.3	1	0.27	92.8	6.0025	1.4379
2014	9	6	7	22	18	0.3	1	0.22	98.5	6.0025	1.1607
2014	9	6	7	32	18	0.3	1	0.25	84.7	6.0025	1.3166
2014	9	6	7	42	18	0.3	1	0.27	83.7	6.0025	1.4032
2014	9	6	7	52	18	0.3	1	0.22	90	5.9832	1.1394
2014	9	6	8	2	18	0.3	1	0.17	90	5.9832	0.8977
2014	9	6	8	12	18	0.3	1	0.27	97	5.9832	1.4156
2014	9	6	8	22	18	0.3	1	0.25	87	5.9832	1.312
2014	9	6	8	32	18	0.3	1	0.21	112.6	5.9638	1.0322
2014	9	6	8	42	18	0.3	1	0.29	95.8	5.9638	1.5311
2014	9	6	8	52	18	0.3	1	0.24	96.9	5.9638	1.2731
2014	9	6	9	2	18	0.3	1	0.23	94.1	5.9638	1.187
2014	9	6	9	12	18	0.3	1	0.23	104.8	5.9638	1.1698
2014	9	6	9	22	18	0.3	1	0.24	102.7	5.9638	1.2214
2014	9	6	9	32	18	0.3	1	0.21	100.8	5.9638	1.0838
2014	9	6	9	42	18	0.3	1	0.26	80.4	5.9638	1.3247
2014	9	6	9	52	18	0.3	1	0.29	85.5	5.9638	1.5139
2014	9	6	10	2	18	0.3	1	0.23	102.1	5.9638	1.2042
2014	9	6	10	12	18	0.3	1	0.28	91.3	5.9638	1.4623

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	10	22	18	0.3	1	0.24	83.7	5.9445	1.2343
2014	9	6	10	32	18	0.3	1	0.21	77.1	5.9445	1.0457
2014	9	6	10	42	18	0.3	1	0.23	100.7	5.9638	1.187
2014	9	6	10	52	18	0.3	1	0.21	102.3	5.9445	1.0972
2014	9	6	11	2	18	0.3	1	0.22	104	5.9445	1.0972
2014	9	6	11	12	18	0.3	1	0.23	82.5	5.9445	1.1657
2014	9	6	11	22	18	0.3	1	0.24	90	5.9445	1.2515
2014	9	6	11	32	18	0.3	1	0.22	80.7	5.9445	1.1486
2014	9	6	11	42	18	0.3	1	0.25	74.9	5.9445	1.2686
2014	9	6	11	52	18	0.3	1	0.24	70.8	5.9445	1.1829
2014	9	6	12	2	18	0.3	1	0.24	85.2	5.9445	1.2343
2014	9	6	12	12	18	0.3	1	0.29	84.2	5.9445	1.5086
2014	9	6	12	22	18	0.3	1	0.29	90	5.9445	1.5085
2014	9	6	12	32	18	0.3	1	0.28	72.4	5.9445	1.4057
2014	9	6	12	42	18	0.3	1	0.25	83.2	5.9445	1.3028
2014	9	6	12	52	18	0.3	1	0.26	91.5	5.9445	1.3371
2014	9	6	13	2	18	0.3	1	0.27	69.8	5.9251	1.2983
2014	9	6	13	12	18	0.3	1	0.17	88.9	5.9251	0.8883
2014	9	6	13	22	18	0.3	1	0.21	88.2	5.9251	1.1103
2014	9	6	13	32	18	0.3	1	0.28	78.4	5.9445	1.4228
2014	9	6	13	42	18	0.3	1	0.25	90	5.9445	1.2857
2014	9	6	13	52	18	0.3	1	0.27	76.1	5.9251	1.3836
2014	9	6	14	2	18	0.3	1	0.3	65.4	5.9251	1.4178
2014	9	6	14	12	18	0.3	1	0.3	83.7	5.9251	1.5374
2014	9	6	14	22	18	0.3	1	0.31	77.6	5.9251	1.5544
2014	9	6	14	32	18	0.3	1	0.28	76.6	5.9251	1.4349
2014	9	6	14	42	18	0.3	1	0.32	65.8	5.9251	1.5203
2014	9	6	14	52	18	0.3	1	0.38	69.4	5.9251	1.8619
2014	9	6	15	2	18	0.3	1	0.32	77.5	5.9057	1.617
2014	9	6	15	12	18	0.3	1	0.3	65.7	5.9251	1.4348
2014	9	6	15	22	18	0.3	1	0.35	71.6	5.9057	1.7362
2014	9	6	15	32	18	0.3	1	0.34	77.8	5.9057	1.7362
2014	9	6	15	42	18	0.3	1	0.28	79.3	5.9057	1.4468
2014	9	6	15	52	18	0.3	1	0.26	61.5	5.9057	1.1915
2014	9	6	16	2	18	0.3	1	0.24	76.7	5.9057	1.2255
2014	9	6	16	12	18	0.3	1	0.22	95	5.9057	1.1574
2014	9	6	16	22	18	0.3	1	0.2	72.5	5.8864	0.9668
2014	9	6	16	32	18	0.3	1	0.23	75.2	5.8864	1.1534
2014	9	6	16	42	18	0.3	1	0.23	77.7	5.8864	1.1703
2014	9	6	16	52	18	0.3	1	0.28	92.7	5.8864	1.4247
2014	9	6	17	2	18	0.3	1	0.27	64.4	5.8864	1.2382
2014	9	6	17	12	18	0.3	1	0.28	90	5.8864	1.4247
2014	9	6	17	22	18	0.3	1	0.27	74.6	5.8864	1.3569
2014	9	6	17	32	18	0.3	1	0.23	71.6	5.8864	1.1194
2014	9	6	17	42	18	0.3	1	0.19	96	5.867	0.9634
2014	9	6	17	52	18	0.3	1	0.19	79.3	5.8864	0.9837

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	18	2	18	0.3	1	0.24	79.9	5.867	1.2338
2014	9	6	18	12	18	0.3	1	0.35	54.5	5.867	1.4704
2014	9	6	18	22	18	0.3	1	0.34	50.9	5.867	1.3521
2014	9	6	18	32	18	0.3	1	0.4	48.3	5.8477	1.5494
2014	9	6	18	42	18	0.3	1	0.26	55.3	5.8477	1.0947
2014	9	6	18	52	18	0.3	1	0.26	60.9	5.867	1.1831
2014	9	6	19	2	18	0.3	1	0.23	62	5.867	1.0479
2014	9	6	19	12	18	0.3	1	0.21	81.7	5.867	1.0479
2014	9	6	19	22	18	0.3	1	0.24	89.2	5.867	1.2507
2014	9	6	19	32	18	0.3	1	0.24	69.1	5.867	1.1493
2014	9	6	19	42	18	0.3	1	0.18	64.9	5.867	0.8282
2014	9	6	19	52	18	0.3	1	0.26	84.2	5.8477	1.3305
2014	9	6	20	2	18	0.3	1	0.2	91.9	5.867	1.0141
2014	9	6	20	12	18	0.3	1	0.15	114.9	5.867	0.693
2014	9	6	20	22	18	0.3	1	0.26	80.7	5.867	1.3352
2014	9	6	20	32	18	0.3	1	0.18	89	5.867	0.9465
2014	9	6	20	42	18	0.3	1	0.18	96.1	5.867	0.9465
2014	9	6	20	52	18	0.3	1	0.16	92.3	5.867	0.8451
2014	9	6	21	2	18	0.3	1	0.18	80.4	5.867	0.8958
2014	9	6	21	12	18	0.3	1	0.15	77.5	5.867	0.7606
2014	9	6	21	22	18	0.3	1	0.24	99.5	5.867	1.2169
2014	9	6	21	32	18	0.3	1	0.25	82.5	5.867	1.2845
2014	9	6	21	42	18	0.3	1	0.21	96.3	5.867	1.0648
2014	9	6	21	52	18	0.3	1	0.25	90	5.867	1.2676
2014	9	6	22	2	18	0.3	1	0.18	83.7	5.867	0.9127
2014	9	6	22	12	18	0.3	1	0.23	104.2	5.867	1.1324
2014	9	6	22	22	18	0.3	1	0.18	90	5.867	0.9465
2014	9	6	22	32	18	0.3	1	0.2	106.3	5.867	0.9803
2014	9	6	22	42	18	0.3	1	0.16	90	5.867	0.8113
2014	9	6	22	52	18	0.3	1	0.23	78.4	5.867	1.1493
2014	9	6	23	2	18	0.3	1	0.25	102.4	5.867	1.2339
2014	9	6	23	12	18	0.3	1	0.21	75.3	5.867	1.031
2014	9	6	23	22	18	0.3	1	0.17	87.8	5.867	0.8958
2014	9	6	23	32	18	0.3	1	0.23	103.4	5.867	1.1324
2014	9	6	23	42	18	0.3	1	0.24	98.8	5.867	1.2001
2014	9	6	23	52	18	0.3	1	0.23	99.7	5.867	1.1832
2014	9	7	0	2	18	0.3	1	0.2	82.3	5.867	0.9972
2014	9	7	0	12	18	0.3	1	0.18	101.3	5.867	0.9296
2014	9	7	0	22	18	0.3	1	0.22	93.4	5.867	1.1494
2014	9	7	0	32	18	0.3	1	0.18	85.8	5.867	0.9296
2014	9	7	0	42	18	0.3	1	0.18	96.2	5.867	0.9296
2014	9	7	0	52	18	0.3	1	0.15	108.8	5.867	0.7437
2014	9	7	1	2	18	0.3	1	0.16	102.9	5.867	0.8113
2014	9	7	1	12	18	0.3	1	0.26	108.7	5.867	1.2508
2014	9	7	1	22	18	0.3	1	0.19	110	5.867	0.9296
2014	9	7	1	32	18	0.3	1	0.2	100.2	5.867	1.031

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	1	42	18	0.3	1	0.25	85.5	5.867	1.3015
2014	9	7	1	52	18	0.3	1	0.19	88	5.867	0.9803
2014	9	7	2	2	18	0.3	1	0.24	97	5.8864	1.2383
2014	9	7	2	12	18	0.3	1	0.16	95.9	5.8864	0.8142
2014	9	7	2	22	18	0.3	1	0.19	111.3	5.8864	0.916
2014	9	7	2	32	18	0.3	1	0.2	90	5.8864	1.0347
2014	9	7	2	42	18	0.3	1	0.2	116.1	5.9057	0.9362
2014	9	7	2	52	18	0.3	1	0.25	90	5.9057	1.2767
2014	9	7	3	2	18	0.3	1	0.21	92.6	5.9057	1.1065
2014	9	7	3	12	18	0.3	1	0.2	106.3	5.9057	0.9873
2014	9	7	3	22	18	0.3	1	0.2	96.5	5.9057	1.0384
2014	9	7	3	32	18	0.3	1	0.26	88.5	5.9057	1.3278
2014	9	7	3	42	18	0.3	1	0.25	83.9	5.9251	1.2812
2014	9	7	3	52	18	0.3	1	0.23	89.2	5.9251	1.1958
2014	9	7	4	2	18	0.3	1	0.2	86.2	5.9251	1.042
2014	9	7	4	12	18	0.3	1	0.19	90	5.9251	0.9908
2014	9	7	4	22	18	0.3	1	0.2	93.8	5.9251	1.042
2014	9	7	4	32	18	0.3	1	0.21	108.4	5.9251	1.025
2014	9	7	4	42	18	0.3	1	0.21	90	5.9445	1.08
2014	9	7	4	52	18	0.3	1	0.17	104.6	5.9445	0.8571
2014	9	7	5	2	18	0.3	1	0.28	96	5.9445	1.4743
2014	9	7	5	12	18	0.3	1	0.22	90	5.9445	1.1657
2014	9	7	5	22	18	0.3	1	0.28	95.3	5.9445	1.4743
2014	9	7	5	32	18	0.3	1	0.2	106.1	5.9445	1.0114
2014	9	7	5	42	18	0.3	1	0.18	108.1	5.9638	0.8946
2014	9	7	5	52	18	0.3	1	0.22	99.6	5.9638	1.1182
2014	9	7	6	2	18	0.3	1	0.17	102.2	5.9638	0.8774
2014	9	7	6	12	18	0.3	1	0.28	100.9	5.9638	1.4279
2014	9	7	6	22	18	0.3	1	0.24	106.9	5.9638	1.187
2014	9	7	6	32	18	0.3	1	0.24	100.2	5.9832	1.2429
2014	9	7	6	42	18	0.3	1	0.22	110.6	5.9832	1.1048
2014	9	7	6	52	18	0.3	1	0.25	95.9	5.9832	1.3293
2014	9	7	7	2	18	0.3	1	0.21	100.6	6.0025	1.1087
2014	9	7	7	12	18	0.3	1	0.21	90.9	6.0219	1.1125
2014	9	7	7	22	18	0.3	1	0.22	101	6.0412	1.1687
2014	9	7	7	32	18	0.3	1	0.22	105.5	6.0412	1.1338
2014	9	7	7	42	18	0.3	1	0.23	101.5	6.0606	1.2077
2014	9	7	7	52	18	0.3	1	0.28	92	6.0606	1.4878
2014	9	7	8	2	18	0.3	1	0.26	101.4	6.0606	1.3828
2014	9	7	8	12	18	0.3	1	0.22	90	6.0606	1.1902
2014	9	7	8	22	18	0.3	1	0.26	96.5	6.0606	1.3828
2014	9	7	8	32	18	0.3	1	0.21	106.2	6.0606	1.0852
2014	9	7	8	42	18	0.3	1	0.25	89.2	6.08	1.3173
2014	9	7	8	52	18	0.3	1	0.23	90	6.08	1.2119
2014	9	7	9	2	18	0.3	1	0.28	102.9	6.08	1.4578
2014	9	7	9	12	18	0.3	1	0.23	99.9	6.08	1.2119

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	9	22	18	0.3	1	0.26	101.7	6.08	1.3524
2014	9	7	9	32	18	0.3	1	0.32	77.5	6.08	1.6685
2014	9	7	9	42	18	0.3	1	0.27	91.4	6.08	1.4226
2014	9	7	9	52	18	0.3	1	0.18	90	6.08	0.966
2014	9	7	10	2	18	0.3	1	0.29	80.8	6.08	1.5104
2014	9	7	10	12	18	0.3	1	0.28	82.5	6.08	1.4753
2014	9	7	10	22	18	0.3	1	0.24	82	6.0993	1.2513
2014	9	7	10	32	18	0.3	1	0.33	78.6	6.0993	1.7447
2014	9	7	10	42	18	0.3	1	0.31	83.9	6.0993	1.639
2014	9	7	10	52	18	0.3	1	0.22	85.7	6.08	1.1592
2014	9	7	11	2	18	0.3	1	0.26	79.2	6.08	1.3875
2014	9	7	11	12	18	0.3	1	0.28	84	6.08	1.5104
2014	9	7	11	22	18	0.3	1	0.27	64.7	6.08	1.2997
2014	9	7	11	32	18	0.3	1	0.28	77.1	6.08	1.4577
2014	9	7	11	42	18	0.3	1	0.28	75.2	6.08	1.4577
2014	9	7	11	52	18	0.3	1	0.33	79	6.08	1.7212
2014	9	7	12	2	18	0.3	1	0.33	69.6	6.08	1.6509
2014	9	7	12	12	18	0.3	1	0.31	68.9	6.08	1.5455
2014	9	7	12	22	18	0.3	1	0.3	75.5	6.08	1.5631
2014	9	7	12	32	18	0.3	1	0.33	55.7	6.08	1.4401
2014	9	7	12	42	18	0.3	1	0.37	70.9	6.08	1.8792
2014	9	7	12	52	18	0.3	1	0.38	53.7	6.08	1.6509
2014	9	7	13	2	18	0.3	1	0.36	68.4	6.08	1.7738
2014	9	7	13	12	18	0.3	1	0.32	55.8	6.08	1.4225
2014	9	7	13	22	18	0.3	1	0.32	67.9	6.08	1.5982
2014	9	7	13	32	18	0.3	1	0.33	63.7	6.0606	1.5577
2014	9	7	13	42	18	0.3	1	0.37	62.1	6.0606	1.7502
2014	9	7	13	52	18	0.3	1	0.38	55.1	6.0606	1.6802
2014	9	7	14	2	18	0.3	1	0.39	61.7	6.0606	1.8202
2014	9	7	14	12	18	0.3	1	0.37	60.7	6.0412	1.7093
2014	9	7	14	22	18	0.3	1	0.35	53.3	6.0412	1.5
2014	9	7	14	32	18	0.3	1	0.39	58.9	6.0412	1.7616
2014	9	7	14	42	18	0.3	1	0.37	70.4	6.0412	1.8663
2014	9	7	14	52	18	0.3	1	0.36	75.7	6.0412	1.8488
2014	9	7	15	2	18	0.3	1	0.28	70.1	6.0412	1.3953
2014	9	7	15	12	18	0.3	1	0.33	78.7	6.0412	1.7441
2014	9	7	15	22	18	0.3	1	0.34	75	6.0412	1.7616
2014	9	7	15	32	18	0.3	1	0.25	64.8	6.0219	1.2167
2014	9	7	15	42	18	0.3	1	0.28	76.5	6.0219	1.4426
2014	9	7	15	52	18	0.3	1	0.27	62.2	6.0219	1.2862
2014	9	7	16	2	18	0.3	1	0.25	70.6	6.0219	1.2341
2014	9	7	16	12	18	0.3	1	0.26	90	6.0219	1.3905
2014	9	7	16	22	18	0.3	1	0.29	73.6	6.0219	1.4774
2014	9	7	16	32	18	0.3	1	0.29	75	6.0219	1.4948
2014	9	7	16	42	18	0.3	1	0.38	71.4	6.0219	1.9119
2014	9	7	16	52	18	0.3	1	0.36	55.7	6.0219	1.5817

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	17	2	18	0.3	1	0.38	54.1	6.0219	1.6338
2014	9	7	17	12	18	0.3	1	0.41	63.2	6.0219	1.9293
2014	9	7	17	22	18	0.3	1	0.34	54.8	6.0219	1.4774
2014	9	7	17	32	18	0.3	1	0.39	50.1	6.0219	1.5991
2014	9	7	17	42	18	0.3	1	0.34	58.3	6.0219	1.5469
2014	9	7	17	52	18	0.3	1	0.41	46.3	6.0219	1.5817
2014	9	7	18	2	18	0.3	1	0.39	50.1	6.0412	1.6046
2014	9	7	18	12	18	0.3	1	0.39	50.1	6.0412	1.6046
2014	9	7	18	22	18	0.3	1	0.38	56.6	6.0412	1.6918
2014	9	7	18	32	18	0.3	1	0.4	51.3	6.0412	1.6744
2014	9	7	18	42	18	0.3	1	0.36	56.2	6.0606	1.5926
2014	9	7	18	52	18	0.3	1	0.33	57.8	6.0606	1.4701
2014	9	7	19	2	18	0.3	1	0.34	55.2	6.0606	1.4876
2014	9	7	19	12	18	0.3	1	0.28	60.1	6.0606	1.2776
2014	9	7	19	22	18	0.3	1	0.36	75.6	6.0606	1.8376
2014	9	7	19	32	18	0.3	1	0.31	90.6	6.0412	1.622
2014	9	7	19	42	18	0.3	1	0.23	87.6	6.0412	1.2383
2014	9	7	19	52	18	0.3	1	0.27	93.4	6.08	1.4576
2014	9	7	20	2	18	0.3	1	0.28	88.6	6.0993	1.4802
2014	9	7	20	12	18	0.3	1	0.28	92.7	6.0993	1.4802
2014	9	7	20	22	18	0.3	1	0.34	81.6	6.0993	1.7974
2014	9	7	20	32	18	0.3	1	0.24	90	6.0993	1.304
2014	9	7	20	42	18	0.3	1	0.22	84	6.0993	1.1807
2014	9	7	20	52	18	0.3	1	0.24	70.1	6.0993	1.2159
2014	9	7	21	2	18	0.3	1	0.32	74.1	6.1187	1.6798
2014	9	7	21	12	18	0.3	1	0.22	77.8	6.1187	1.1493
2014	9	7	21	22	18	0.3	1	0.25	77.2	6.1187	1.3262
2014	9	7	21	32	18	0.3	1	0.31	76.6	6.1187	1.6268
2014	9	7	21	42	18	0.3	1	0.3	80.6	6.1187	1.6091
2014	9	7	21	52	18	0.3	1	0.23	94.8	6.1187	1.2554
2014	9	7	22	2	18	0.3	1	0.27	97.7	6.1187	1.4323
2014	9	7	22	12	18	0.3	1	0.28	94.8	6.1187	1.4853
2014	9	7	22	22	18	0.3	1	0.22	84.8	6.1187	1.167
2014	9	7	22	32	18	0.3	1	0.27	85.8	6.1187	1.4323
2014	9	7	22	42	18	0.3	1	0.29	94.6	6.1187	1.5384
2014	9	7	22	52	18	0.3	1	0.3	84.3	6.1187	1.5914
2014	9	7	23	2	18	0.3	1	0.3	83.8	6.1187	1.6268
2014	9	7	23	12	18	0.3	1	0.21	86.4	6.138	1.1178
2014	9	7	23	22	18	0.3	1	0.29	83.5	6.138	1.5613
2014	9	7	23	32	18	0.3	1	0.29	85.4	6.138	1.5436
2014	9	7	23	42	18	0.3	1	0.28	90.7	6.138	1.4904
2014	9	7	23	52	18	0.3	1	0.33	98	6.138	1.7743
2014	9	8	0	2	18	0.3	1	0.24	80.5	6.138	1.2775
2014	9	8	0	12	18	0.3	1	0.22	103.6	6.138	1.171
2014	9	8	0	22	18	0.3	1	0.27	99.7	6.138	1.4549
2014	9	8	0	32	18	0.3	1	0.23	73.4	6.138	1.1888

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	0	42	18	0.3	1	0.27	105.4	6.138	1.4194
2014	9	8	0	52	18	0.3	1	0.24	91.6	6.138	1.2952
2014	9	8	1	2	18	0.3	1	0.23	103.8	6.138	1.2242
2014	9	8	1	12	18	0.3	1	0.21	93.6	6.138	1.1178
2014	9	8	1	22	18	0.3	1	0.29	83.5	6.138	1.5614
2014	9	8	1	32	18	0.3	1	0.27	83.1	6.138	1.4726
2014	9	8	1	42	18	0.3	1	0.29	90	6.138	1.5791
2014	9	8	1	52	18	0.3	1	0.3	100.6	6.138	1.6146
2014	9	8	2	2	18	0.3	1	0.28	96	6.138	1.5081
2014	9	8	2	12	18	0.3	1	0.31	86.3	6.138	1.6501
2014	9	8	2	22	18	0.3	1	0.33	99.2	6.1187	1.7506
2014	9	8	2	32	18	0.3	1	0.28	83.4	6.1187	1.5207
2014	9	8	2	42	18	0.3	1	0.35	86.8	6.1187	1.9097
2014	9	8	2	52	18	0.3	1	0.27	84.5	6.1187	1.4677
2014	9	8	3	2	18	0.3	1	0.31	90.6	6.1187	1.6975
2014	9	8	3	12	18	0.3	1	0.38	86.1	6.1187	2.0512
2014	9	8	3	22	18	0.3	1	0.32	77.4	6.1187	1.6622
2014	9	8	3	32	18	0.3	1	0.29	79.7	6.1187	1.5561
2014	9	8	3	42	18	0.3	1	0.24	78.2	6.1187	1.2732
2014	9	8	3	52	18	0.3	1	0.25	68.5	6.1187	1.2555
2014	9	8	4	2	18	0.3	1	0.29	83.6	6.1187	1.5738
2014	9	8	4	12	18	0.3	1	0.22	64.6	6.1187	1.0786
2014	9	8	4	22	18	0.3	1	0.26	78.3	6.0993	1.3569
2014	9	8	4	32	18	0.3	1	0.19	83.1	6.0993	1.0221
2014	9	8	4	42	18	0.3	1	0.24	82.2	6.0993	1.2865
2014	9	8	4	52	18	0.3	1	0.23	85.9	6.0993	1.2336
2014	9	8	5	2	18	0.3	1	0.28	73.9	6.0993	1.4627
2014	9	8	5	12	18	0.3	1	0.26	74.1	6.0993	1.3569
2014	9	8	5	22	18	0.3	1	0.32	77	6.0993	1.6742
2014	9	8	5	32	18	0.3	1	0.22	71	6.0993	1.1279
2014	9	8	5	42	18	0.3	1	0.32	54.9	6.0993	1.4274
2014	9	8	5	52	18	0.3	1	0.34	70.3	6.0993	1.727
2014	9	8	6	2	18	0.3	1	0.33	68.5	6.0993	1.6565
2014	9	8	6	12	18	0.3	1	0.37	66.6	6.0993	1.8328
2014	9	8	6	22	18	0.3	1	0.39	66.5	6.0993	1.9033
2014	9	8	6	32	18	0.3	1	0.38	73.4	6.0993	1.9561
2014	9	8	6	42	18	0.3	1	0.32	56.1	6.0993	1.4451
2014	9	8	6	52	18	0.3	1	0.34	70.7	6.0993	1.7094
2014	9	8	7	2	18	0.3	1	0.35	66.5	6.08	1.7387
2014	9	8	7	12	18	0.3	1	0.3	58.1	6.0993	1.357
2014	9	8	7	22	18	0.3	1	0.37	77.3	6.0993	1.9561
2014	9	8	7	32	18	0.3	1	0.33	82.5	6.0993	1.7447
2014	9	8	7	42	18	0.3	1	0.29	83.4	6.08	1.528
2014	9	8	7	52	18	0.3	1	0.3	67.4	6.08	1.4753
2014	9	8	8	2	18	0.3	1	0.27	79.6	6.08	1.4401
2014	9	8	8	12	18	0.3	1	0.31	73.6	6.08	1.6158

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	8	22	18	0.3	1	0.31	72.9	6.08	1.5982
2014	9	8	8	32	18	0.3	1	0.33	65.2	6.0606	1.5927
2014	9	8	8	42	18	0.3	1	0.28	69.2	6.08	1.3875
2014	9	8	8	52	18	0.3	1	0.32	70.8	6.08	1.6158
2014	9	8	9	2	18	0.3	1	0.28	62.2	6.0606	1.3302
2014	9	8	9	12	18	0.3	1	0.31	53.3	6.08	1.3172
2014	9	8	9	22	18	0.3	1	0.34	57.5	6.0606	1.5402
2014	9	8	9	32	18	0.3	1	0.38	65.2	6.0606	1.8203
2014	9	8	9	42	18	0.3	1	0.32	63.7	6.0606	1.5227
2014	9	8	9	52	18	0.3	1	0.31	57.7	6.0606	1.3827
2014	9	8	10	2	18	0.3	1	0.33	71.4	6.0606	1.6627
2014	9	8	10	12	18	0.3	1	0.31	63.4	6.0219	1.4601
2014	9	8	10	22	18	0.3	1	0.3	45.4	6.0606	1.1552
2014	9	8	10	32	18	0.3	1	0.34	65.2	6.0606	1.6277
2014	9	8	10	42	18	0.3	1	0.32	68.2	6.0606	1.5752
2014	9	8	10	52	18	0.3	1	0.35	59.9	6.0412	1.6222
2014	9	8	11	2	18	0.3	1	0.38	64.1	6.0412	1.8315
2014	9	8	11	12	18	0.3	1	0.43	54.6	6.0219	1.8599
2014	9	8	11	22	18	0.3	1	0.39	47.8	6.0219	1.5123
2014	9	8	11	32	18	0.3	1	0.42	60.6	6.0219	1.9468
2014	9	8	11	42	18	0.3	1	0.39	52.5	6.0025	1.6283
2014	9	8	11	52	18	0.3	1	0.37	52.2	6.0025	1.5417
2014	9	8	12	2	18	0.3	1	0.39	59	6.0025	1.7842
2014	9	8	12	12	18	0.3	1	0.39	61.7	6.0025	1.8015
2014	9	8	12	22	18	0.3	1	0.43	57.3	6.0025	1.8881
2014	9	8	12	32	18	0.3	1	0.4	45	6.0025	1.507
2014	9	8	12	42	18	0.3	1	0.46	44.1	5.9832	1.6916
2014	9	8	12	52	18	0.3	1	0.48	55.1	5.9832	2.0541
2014	9	8	13	2	18	0.3	1	0.55	52	5.9832	2.2785
2014	9	8	13	12	18	0.3	1	0.37	60.7	5.9638	1.6858
2014	9	8	13	22	18	0.3	1	0.42	47.5	5.9832	1.6226
2014	9	8	13	32	18	0.3	1	0.42	52	5.9832	1.7434
2014	9	8	13	42	18	0.3	1	0.47	47.2	5.9832	1.8297
2014	9	8	13	52	18	0.3	1	0.44	57.5	5.9832	1.9505
2014	9	8	14	2	18	0.3	1	0.45	46.5	5.9832	1.7261
2014	9	8	14	12	18	0.3	1	0.56	48.5	5.9832	2.2267
2014	9	8	14	22	18	0.3	1	0.5	41	5.9832	1.7089
2014	9	8	14	32	18	0.3	1	0.51	52.5	5.9832	2.1404
2014	9	8	14	42	18	0.3	1	0.53	35.9	5.9832	1.6398
2014	9	8	14	52	18	0.3	1	0.49	48.2	5.9832	1.9332
2014	9	8	15	2	18	0.3	1	0.5	41.3	5.9832	1.7434
2014	9	8	15	12	18	0.3	1	0.45	38.1	5.9638	1.4449
2014	9	8	15	22	18	0.3	1	0.47	48.4	5.9638	1.8405
2014	9	8	15	32	18	0.3	1	0.47	38.2	5.9832	1.519
2014	9	8	15	42	18	0.3	1	0.46	54.8	5.9638	1.9781
2014	9	8	15	52	18	0.3	1	0.5	59.9	5.9832	2.2957

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	16	2	18	0.3	1	0.49	50.7	5.9638	1.9953
2014	9	8	16	12	18	0.3	1	0.45	48	5.9638	1.7373
2014	9	8	16	22	18	0.3	1	0.46	49.4	5.9638	1.8233
2014	9	8	16	32	18	0.3	1	0.52	47.6	5.9638	2.0125
2014	9	8	16	42	18	0.3	1	0.51	33.2	5.9832	1.4672
2014	9	8	16	52	18	0.3	1	0.5	39.9	5.9638	1.6857
2014	9	8	17	2	18	0.3	1	0.58	35.1	5.9832	1.7606
2014	9	8	17	12	18	0.3	1	0.42	47.2	5.9638	1.6169
2014	9	8	17	22	18	0.3	1	0.48	52	5.9832	1.985
2014	9	8	17	32	18	0.3	1	0.39	49.8	5.9832	1.5707
2014	9	8	17	42	18	0.3	1	0.46	50.8	5.9638	1.8749
2014	9	8	17	52	18	0.3	1	0.4	37.3	5.9832	1.2773
2014	9	8	18	2	18	0.3	1	0.41	45	5.9832	1.5362
2014	9	8	18	12	18	0.3	1	0.4	47.3	5.9638	1.5309
2014	9	8	18	22	18	0.3	1	0.3	52	5.9832	1.26
2014	9	8	18	32	18	0.3	1	0.38	50.9	5.9832	1.5707
2014	9	8	18	42	18	0.3	1	0.36	50.1	5.9832	1.4672
2014	9	8	18	52	18	0.3	1	0.33	51.4	5.9832	1.3636
2014	9	8	19	2	18	0.3	1	0.28	65.8	5.9832	1.3464
2014	9	8	19	12	18	0.3	1	0.28	61.3	5.9832	1.2946
2014	9	8	19	22	18	0.3	1	0.29	62.9	5.9832	1.3809
2014	9	8	19	32	18	0.3	1	0.32	77.4	5.9832	1.6225
2014	9	8	19	42	18	0.3	1	0.26	76.7	5.9832	1.3118
2014	9	8	19	52	18	0.3	1	0.2	83.6	5.9832	1.0702
2014	9	8	20	2	18	0.3	1	0.26	84.9	5.9832	1.3636
2014	9	8	20	12	18	0.3	1	0.24	79.6	5.9832	1.2255
2014	9	8	20	22	18	0.3	1	0.24	81.3	5.9832	1.2428
2014	9	8	20	32	18	0.3	1	0.27	94.2	5.9832	1.4154
2014	9	8	20	42	18	0.3	1	0.27	76.1	5.9832	1.3982
2014	9	8	20	52	18	0.3	1	0.2	80.7	5.9832	1.0529
2014	9	8	21	2	18	0.3	1	0.27	87.9	5.9832	1.3982
2014	9	8	21	12	18	0.3	1	0.2	90	5.9832	1.0702
2014	9	8	21	22	18	0.3	1	0.23	99.2	5.9832	1.1738
2014	9	8	21	32	18	0.3	1	0.24	90.8	5.9832	1.2773
2014	9	8	21	42	18	0.3	1	0.35	90	5.9832	1.847
2014	9	8	21	52	18	0.3	1	0.19	73.1	5.9832	0.9666
2014	9	8	22	2	18	0.3	1	0.24	92.4	5.9832	1.2601
2014	9	8	22	12	18	0.3	1	0.22	109	5.9832	1.1047
2014	9	8	22	22	18	0.3	1	0.2	93.8	5.9832	1.0357
2014	9	8	22	32	18	0.3	1	0.28	96.1	5.9832	1.45
2014	9	8	22	42	18	0.3	1	0.22	101.1	5.9832	1.1393
2014	9	8	22	52	18	0.3	1	0.22	92.6	5.9832	1.1393
2014	9	8	23	2	18	0.3	1	0.28	79.8	5.9832	1.4327
2014	9	8	23	12	18	0.3	1	0.26	81.1	5.9832	1.3292
2014	9	8	23	22	18	0.3	1	0.24	90	5.9832	1.2601
2014	9	8	23	32	18	0.3	1	0.21	86.4	5.9832	1.0875

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	23	42	18	0.3	1	0.15	100.3	5.9832	0.7595
2014	9	8	23	52	18	0.3	1	0.33	102	5.9832	1.7089
2014	9	9	0	2	18	0.3	1	0.26	90	6.0025	1.3511
2014	9	9	0	12	18	0.3	1	0.28	100.1	6.0025	1.4551
2014	9	9	0	22	18	0.3	1	0.21	85.6	6.0025	1.1259
2014	9	9	0	32	18	0.3	1	0.23	90	6.0025	1.2299
2014	9	9	0	42	18	0.3	1	0.28	86.6	5.9832	1.4673
2014	9	9	0	52	18	0.3	1	0.29	86.7	6.0025	1.507
2014	9	9	1	2	18	0.3	1	0.25	80.9	6.0025	1.2992
2014	9	9	1	12	18	0.3	1	0.26	84.2	6.0025	1.3685
2014	9	9	1	22	18	0.3	1	0.26	86.3	6.0219	1.3558
2014	9	9	1	32	18	0.3	1	0.29	94.6	6.0219	1.5123
2014	9	9	1	42	18	0.3	1	0.28	91.3	6.0025	1.4724
2014	9	9	1	52	18	0.3	1	0.2	77.6	6.0219	1.0256
2014	9	9	2	2	18	0.3	1	0.26	76.7	6.0219	1.3211
2014	9	9	2	12	18	0.3	1	0.28	85.9	6.0412	1.4652
2014	9	9	2	22	18	0.3	1	0.2	78.9	6.0412	1.064
2014	9	9	2	32	18	0.3	1	0.26	97.2	6.0412	1.378
2014	9	9	2	42	18	0.3	1	0.3	87.5	6.0412	1.5873
2014	9	9	2	52	18	0.3	1	0.26	87.8	6.0606	1.3827
2014	9	9	3	2	18	0.3	1	0.26	76.7	6.0606	1.3302
2014	9	9	3	12	18	0.3	1	0.28	85.9	6.0606	1.4702
2014	9	9	3	22	18	0.3	1	0.25	98.2	6.0606	1.3302
2014	9	9	3	32	18	0.3	1	0.22	84.1	6.0606	1.1902
2014	9	9	3	42	18	0.3	1	0.25	95.3	6.0606	1.3302
2014	9	9	3	52	18	0.3	1	0.19	105.9	6.0606	0.9802
2014	9	9	4	2	18	0.3	1	0.26	98.1	6.0606	1.3477
2014	9	9	4	12	18	0.3	1	0.23	95	6.0606	1.2077
2014	9	9	4	22	18	0.3	1	0.26	92.9	6.0606	1.3652
2014	9	9	4	32	18	0.3	1	0.22	103	6.0606	1.1377
2014	9	9	4	42	18	0.3	1	0.25	84.7	6.0606	1.3127
2014	9	9	4	52	18	0.3	1	0.24	99.6	6.0606	1.2427
2014	9	9	5	2	18	0.3	1	0.2	90	6.0606	1.0852
2014	9	9	5	12	18	0.3	1	0.3	90	6.0606	1.6103
2014	9	9	5	22	18	0.3	1	0.29	100.5	6.0606	1.5053
2014	9	9	5	32	18	0.3	1	0.22	94.3	6.0606	1.1552
2014	9	9	5	42	18	0.3	1	0.2	119.9	6.08	0.9484
2014	9	9	5	52	18	0.3	1	0.24	86.1	6.08	1.2997
2014	9	9	6	2	18	0.3	1	0.23	99.1	6.0606	1.2077
2014	9	9	6	12	18	0.3	1	0.28	105.2	6.08	1.4226
2014	9	9	6	22	18	0.3	1	0.22	92.6	6.08	1.1768
2014	9	9	6	32	18	0.3	1	0.27	87.9	6.08	1.4402
2014	9	9	6	42	18	0.3	1	0.21	89.1	6.08	1.1416
2014	9	9	6	52	18	0.3	1	0.24	94.8	6.08	1.2646
2014	9	9	7	2	18	0.3	1	0.17	90	6.08	0.9133
2014	9	9	7	12	18	0.3	1	0.33	91.7	6.0993	1.78

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	7	22	18	0.3	1	0.26	88.5	6.0993	1.3923
2014	9	9	7	32	18	0.3	1	0.28	87.3	6.0993	1.498
2014	9	9	7	42	18	0.3	1	0.19	68.4	6.0993	0.9341
2014	9	9	7	52	18	0.3	1	0.14	87.4	6.0993	0.7755
2014	9	9	8	2	18	0.3	1	0.19	90	6.0993	1.0398
2014	9	9	8	12	18	0.3	1	0.27	88.6	6.0993	1.4275
2014	9	9	8	22	18	0.3	1	0.19	87	6.0993	1.0222
2014	9	9	8	32	18	0.3	1	0.22	93.5	6.0993	1.1632
2014	9	9	8	42	18	0.3	1	0.23	85.9	6.0993	1.2337
2014	9	9	8	52	18	0.3	1	0.23	91.7	6.0993	1.2161
2014	9	9	9	2	18	0.3	1	0.19	111.8	6.0993	0.9693
2014	9	9	9	12	18	0.3	1	0.27	90	6.0993	1.4452
2014	9	9	9	22	18	0.3	1	0.24	74.3	6.1187	1.2556
2014	9	9	9	32	18	0.3	1	0.27	83.8	6.1187	1.4678
2014	9	9	9	42	18	0.3	1	0.31	84.6	6.1187	1.68
2014	9	9	9	52	18	0.3	1	0.28	93.4	6.1187	1.5031
2014	9	9	10	2	18	0.3	1	0.3	83	6.1187	1.5916
2014	9	9	10	12	18	0.3	1	0.26	84.3	6.1187	1.4147
2014	9	9	10	22	18	0.3	1	0.17	80.2	6.1187	0.9196
2014	9	9	10	32	18	0.3	1	0.25	73.4	6.1187	1.3086
2014	9	9	10	42	18	0.3	1	0.25	73.7	6.1187	1.2732
2014	9	9	10	52	18	0.3	1	0.27	81	6.1187	1.4501
2014	9	9	11	2	18	0.3	1	0.32	84.2	6.1187	1.733
2014	9	9	11	12	18	0.3	1	0.31	76.4	6.1187	1.6092
2014	9	9	11	22	18	0.3	1	0.29	76.9	6.1187	1.5208
2014	9	9	11	32	18	0.3	1	0.27	85.2	6.1187	1.4678
2014	9	9	11	42	18	0.3	1	0.3	98	6.1187	1.6269
2014	9	9	11	52	18	0.3	1	0.24	73.1	6.1187	1.2202
2014	9	9	12	2	18	0.3	1	0.24	81.3	6.138	1.2775
2014	9	9	12	12	18	0.3	1	0.27	86.6	6.1187	1.4677
2014	9	9	12	22	18	0.3	1	0.31	78.5	6.138	1.6501
2014	9	9	12	32	18	0.3	1	0.31	74.2	6.138	1.6324
2014	9	9	12	42	18	0.3	1	0.34	70	6.138	1.7034
2014	9	9	12	52	18	0.3	1	0.32	73.4	6.138	1.6679
2014	9	9	13	2	18	0.3	1	0.33	76.8	6.1187	1.7329
2014	9	9	13	12	18	0.3	1	0.35	70.9	6.138	1.7921
2014	9	9	13	22	18	0.3	1	0.27	55.7	6.138	1.2243
2014	9	9	13	32	18	0.3	1	0.26	70.2	6.138	1.3307
2014	9	9	13	42	18	0.3	1	0.35	88.4	6.138	1.9162
2014	9	9	13	52	18	0.3	1	0.26	87.1	6.138	1.4194
2014	9	9	14	2	18	0.3	1	0.32	86.5	6.138	1.7388
2014	9	9	14	12	18	0.3	1	0.3	90	6.138	1.6323
2014	9	9	14	22	18	0.3	1	0.21	85.5	6.138	1.1355
2014	9	9	14	32	18	0.3	1	0.32	75.8	6.138	1.6856
2014	9	9	14	42	18	0.3	1	0.28	75.8	6.138	1.4726
2014	9	9	14	52	18	0.3	1	0.28	70.9	6.138	1.4371

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	15	2	18	0.3	1	0.28	73.9	6.138	1.4726
2014	9	9	15	12	18	0.3	1	0.32	75.7	6.138	1.6678
2014	9	9	15	22	18	0.3	1	0.24	86.1	6.138	1.3129
2014	9	9	15	32	18	0.3	1	0.28	71.6	6.138	1.4371
2014	9	9	15	42	18	0.3	1	0.27	78.3	6.138	1.4549
2014	9	9	15	52	18	0.3	1	0.26	86.4	6.138	1.4016
2014	9	9	16	2	18	0.3	1	0.28	70.7	6.138	1.4194
2014	9	9	16	12	18	0.3	1	0.3	86.8	6.138	1.5968
2014	9	9	16	22	18	0.3	1	0.32	81	6.138	1.6855
2014	9	9	16	32	18	0.3	1	0.29	91.3	6.138	1.5436
2014	9	9	16	42	18	0.3	1	0.27	78.3	6.138	1.4549
2014	9	9	16	52	18	0.3	1	0.29	91.3	6.138	1.5436
2014	9	9	17	2	18	0.3	1	0.24	79	6.138	1.2774
2014	9	9	17	12	18	0.3	1	0.33	87.1	6.138	1.7742
2014	9	9	17	22	18	0.3	1	0.27	70.7	6.138	1.3661
2014	9	9	17	32	18	0.3	1	0.26	90	6.138	1.4016
2014	9	9	17	42	18	0.3	1	0.26	83.5	6.138	1.4016
2014	9	9	17	52	18	0.3	1	0.26	89.3	6.138	1.3839
2014	9	9	18	2	18	0.3	1	0.27	77.5	6.138	1.4371
2014	9	9	18	12	18	0.3	1	0.26	87.8	6.138	1.4016
2014	9	9	18	22	18	0.3	1	0.28	80.6	6.138	1.5081
2014	9	9	18	32	18	0.3	1	0.28	93.4	6.1574	1.5132
2014	9	9	18	42	18	0.3	1	0.26	84.1	6.138	1.3839
2014	9	9	18	52	18	0.3	1	0.29	93.9	6.1574	1.5844
2014	9	9	19	2	18	0.3	1	0.22	76.2	6.1574	1.1572
2014	9	9	19	12	18	0.3	1	0.18	70.9	6.1574	0.9257
2014	9	9	19	22	18	0.3	1	0.3	90	6.1574	1.6378
2014	9	9	19	32	18	0.3	1	0.26	95.1	6.1574	1.3886
2014	9	9	19	42	18	0.3	1	0.27	87.9	6.1574	1.442
2014	9	9	19	52	18	0.3	1	0.21	79.2	6.1574	1.1216
2014	9	9	20	2	18	0.3	1	0.28	99.6	6.1574	1.4776
2014	9	9	20	12	18	0.3	1	0.29	93.9	6.1574	1.5488
2014	9	9	20	22	18	0.3	1	0.21	90	6.1574	1.1394
2014	9	9	20	32	18	0.3	1	0.28	101.6	6.1574	1.4776
2014	9	9	20	42	18	0.3	1	0.26	76.7	6.1574	1.353
2014	9	9	20	52	18	0.3	1	0.25	80.9	6.1574	1.3352
2014	9	9	21	2	18	0.3	1	0.21	71.3	6.1574	1.1038
2014	9	9	21	12	18	0.3	1	0.3	93.8	6.1574	1.6201
2014	9	9	21	22	18	0.3	1	0.28	99.6	6.1574	1.4777
2014	9	9	21	32	18	0.3	1	0.24	101.9	6.1574	1.264
2014	9	9	21	42	18	0.3	1	0.27	85.1	6.1574	1.4599
2014	9	9	21	52	18	0.3	1	0.27	79	6.1574	1.4599
2014	9	9	22	2	18	0.3	1	0.26	98	6.1574	1.3887
2014	9	9	22	12	18	0.3	1	0.32	99.6	6.1574	1.6913
2014	9	9	22	22	18	0.3	1	0.26	97.2	6.1574	1.4065
2014	9	9	22	32	18	0.3	1	0.16	90	6.1574	0.8724

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	22	42	18	0.3	1	0.2	97.7	6.138	1.0469
2014	9	9	22	52	18	0.3	1	0.25	90.8	6.1574	1.3353
2014	9	9	23	2	18	0.3	1	0.32	94.1	6.1574	1.7447
2014	9	9	23	12	18	0.3	1	0.28	92	6.1574	1.5311
2014	9	9	23	22	18	0.3	1	0.28	102.4	6.1574	1.4599
2014	9	9	23	32	18	0.3	1	0.27	86.6	6.1574	1.4777
2014	9	9	23	42	18	0.3	1	0.26	107	6.1574	1.3353
2014	9	9	23	52	18	0.3	1	0.31	99.3	6.1574	1.6379
2014	9	10	0	2	18	0.3	1	0.29	101.2	6.1574	1.5311
2014	9	10	0	12	18	0.3	1	0.32	94.8	6.1574	1.7092
2014	9	10	0	22	18	0.3	1	0.27	98.4	6.1574	1.4421
2014	9	10	0	32	18	0.3	1	0.26	101.4	6.1574	1.4065
2014	9	10	0	42	18	0.3	1	0.28	89.3	6.1574	1.5311
2014	9	10	0	52	18	0.3	1	0.29	98.5	6.1574	1.5489
2014	9	10	1	2	18	0.3	1	0.29	84.9	6.1574	1.5845
2014	9	10	1	12	18	0.3	1	0.26	112.6	6.1574	1.2819
2014	9	10	1	22	18	0.3	1	0.3	90.6	6.1574	1.638
2014	9	10	1	32	18	0.3	1	0.32	87	6.1574	1.727
2014	9	10	1	42	18	0.3	1	0.27	91.4	6.1574	1.4777
2014	9	10	1	52	18	0.3	1	0.22	88.3	6.1574	1.1751
2014	9	10	2	2	18	0.3	1	0.23	96.5	6.1574	1.2463
2014	9	10	2	12	18	0.3	1	0.26	87.1	6.1574	1.4243
2014	9	10	2	22	18	0.3	1	0.28	96.8	6.1574	1.4955
2014	9	10	2	32	18	0.3	1	0.28	82.1	6.1574	1.5311
2014	9	10	2	42	18	0.3	1	0.23	99.2	6.1574	1.2107
2014	9	10	2	52	18	0.3	1	0.26	93.6	6.1574	1.4065
2014	9	10	3	2	18	0.3	1	0.28	109.7	6.1574	1.4421
2014	9	10	3	12	18	0.3	1	0.25	106	6.1574	1.2997
2014	9	10	3	22	18	0.3	1	0.26	102.6	6.1574	1.3531
2014	9	10	3	32	18	0.3	1	0.26	95.1	6.1767	1.4113
2014	9	10	3	42	18	0.3	1	0.18	93.1	6.1574	0.9792
2014	9	10	3	52	18	0.3	1	0.29	83.4	6.1574	1.549
2014	9	10	4	2	18	0.3	1	0.26	86.4	6.1574	1.4065
2014	9	10	4	12	18	0.3	1	0.3	83	6.1767	1.6078
2014	9	10	4	22	18	0.3	1	0.36	93.7	6.1767	1.9293
2014	9	10	4	32	18	0.3	1	0.27	92.8	6.1574	1.4421
2014	9	10	4	42	18	0.3	1	0.3	97	6.1574	1.6024
2014	9	10	4	52	18	0.3	1	0.27	88.6	6.1767	1.4827
2014	9	10	5	2	18	0.3	1	0.29	103.7	6.1574	1.5312
2014	9	10	5	12	18	0.3	1	0.33	92.3	6.1574	1.7804
2014	9	10	5	22	18	0.3	1	0.25	90	6.1767	1.3577
2014	9	10	5	32	18	0.3	1	0.25	91.5	6.1574	1.3531
2014	9	10	5	42	18	0.3	1	0.33	83.7	6.1574	1.7804
2014	9	10	5	52	18	0.3	1	0.28	96.1	6.1574	1.4956
2014	9	10	6	2	18	0.3	1	0.24	90	6.1574	1.2997
2014	9	10	6	12	18	0.3	1	0.31	93.7	6.1574	1.6736

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	6	22	18	0.3	1	0.33	91.7	6.1574	1.7804
2014	9	10	6	32	18	0.3	1	0.33	94	6.1574	1.7804
2014	9	10	6	42	18	0.3	1	0.29	102.9	6.1574	1.549
2014	9	10	6	52	18	0.3	1	0.25	93.8	6.1574	1.3531
2014	9	10	7	2	18	0.3	1	0.26	88.5	6.1574	1.3888
2014	9	10	7	12	18	0.3	1	0.28	99.6	6.1574	1.4778
2014	9	10	7	22	18	0.3	1	0.35	106.4	6.1574	1.8161
2014	9	10	7	32	18	0.3	1	0.39	93.8	6.1574	2.1188
2014	9	10	7	42	18	0.3	1	0.19	108.1	6.1574	0.9793
2014	9	10	7	52	18	0.3	1	0.24	90	6.1574	1.3175
2014	9	10	8	2	18	0.3	1	0.33	98.6	6.1574	1.7627
2014	9	10	8	12	18	0.3	1	0.25	106.8	6.1574	1.2997
2014	9	10	8	22	18	0.3	1	0.2	92.9	6.1574	1.0683
2014	9	10	8	32	18	0.3	1	0.29	83.6	6.1574	1.5846
2014	9	10	8	42	18	0.3	1	0.27	102.1	6.1574	1.4066
2014	9	10	8	52	18	0.3	1	0.31	88.8	6.1574	1.6558
2014	9	10	9	2	18	0.3	1	0.2	111.1	6.1574	1.0149
2014	9	10	9	12	18	0.3	1	0.24	84.5	6.138	1.2954
2014	9	10	9	22	18	0.3	1	0.23	99.2	6.1767	1.2148
2014	9	10	9	32	18	0.3	1	0.26	111.4	6.1767	1.322
2014	9	10	9	42	18	0.3	1	0.23	90	6.1767	1.2684
2014	9	10	9	52	18	0.3	1	0.2	94.6	6.1767	1.1076
2014	9	10	10	2	18	0.3	1	0.27	90	6.1574	1.4778
2014	9	10	10	12	18	0.3	1	0.28	85.9	6.1574	1.4956
2014	9	10	10	22	18	0.3	1	0.25	80.8	6.1574	1.3175
2014	9	10	10	32	18	0.3	1	0.29	87.4	6.1574	1.5668
2014	9	10	10	42	18	0.3	1	0.26	87.9	6.1574	1.4244
2014	9	10	10	52	18	0.3	1	0.31	91.2	6.1574	1.6558
2014	9	10	11	2	18	0.3	1	0.24	79.9	6.1574	1.2997
2014	9	10	11	12	18	0.3	1	0.27	100.6	6.1574	1.4243
2014	9	10	11	22	18	0.3	1	0.3	82	6.1574	1.638
2014	9	10	11	32	18	0.3	1	0.27	73.8	6.138	1.4018
2014	9	10	11	42	18	0.3	1	0.35	81.3	6.138	1.8454
2014	9	10	11	52	18	0.3	1	0.32	78.2	6.1574	1.7092
2014	9	10	12	2	18	0.3	1	0.36	77.5	6.138	1.9163
2014	9	10	12	12	18	0.3	1	0.33	76.2	6.138	1.7389
2014	9	10	12	22	18	0.3	1	0.32	81.1	6.138	1.7034
2014	9	10	12	32	18	0.3	1	0.38	74.9	6.138	1.9695
2014	9	10	12	42	18	0.3	1	0.31	74.6	6.1574	1.6201
2014	9	10	12	52	18	0.3	1	0.25	70.4	6.138	1.2953
2014	9	10	13	2	18	0.3	1	0.29	65.8	6.138	1.4195
2014	9	10	13	12	18	0.3	1	0.28	79.9	6.138	1.4904
2014	9	10	13	22	18	0.3	1	0.32	71.6	6.138	1.6501
2014	9	10	13	32	18	0.3	1	0.32	87.7	6.1574	1.7447
2014	9	10	13	42	18	0.3	1	0.31	68.9	6.138	1.5614
2014	9	10	13	52	18	0.3	1	0.34	67.4	6.138	1.7033

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	14	2	18	0.3	1	0.29	78.2	6.138	1.5259
2014	9	10	14	12	18	0.3	1	0.27	78.3	6.138	1.4549
2014	9	10	14	22	18	0.3	1	0.31	80.1	6.138	1.6323
2014	9	10	14	32	18	0.3	1	0.27	87.9	6.138	1.4726
2014	9	10	14	42	18	0.3	1	0.3	79.2	6.138	1.5791
2014	9	10	14	52	18	0.3	1	0.32	95.9	6.138	1.7033
2014	9	10	15	2	18	0.3	1	0.3	84.4	6.138	1.6323
2014	9	10	15	12	18	0.3	1	0.29	93.2	6.138	1.5791
2014	9	10	15	22	18	0.3	1	0.28	83.3	6.138	1.5081
2014	9	10	15	32	18	0.3	1	0.28	82.7	6.138	1.5258
2014	9	10	15	42	18	0.3	1	0.26	74.4	6.1187	1.3262
2014	9	10	15	52	18	0.3	1	0.31	80.2	6.138	1.65
2014	9	10	16	2	18	0.3	1	0.3	80.5	6.1187	1.5914
2014	9	10	16	12	18	0.3	1	0.32	78.1	6.1187	1.6798
2014	9	10	16	22	18	0.3	1	0.32	74	6.1187	1.6621
2014	9	10	16	32	18	0.3	1	0.32	73.8	6.1187	1.6444
2014	9	10	16	42	18	0.3	1	0.33	55.8	6.1187	1.4853
2014	9	10	16	52	18	0.3	1	0.29	70.1	6.1187	1.4676
2014	9	10	17	2	18	0.3	1	0.3	79.9	6.1187	1.5914
2014	9	10	17	12	18	0.3	1	0.32	85.8	6.1187	1.6975
2014	9	10	17	22	18	0.3	1	0.39	76.8	6.1187	2.0334
2014	9	10	17	32	18	0.3	1	0.34	63.9	6.1187	1.6621
2014	9	10	17	42	18	0.3	1	0.31	55.6	6.1187	1.3969
2014	9	10	17	52	18	0.3	1	0.29	64.3	6.1187	1.4322
2014	9	10	18	2	18	0.3	1	0.3	59.3	6.1187	1.3969
2014	9	10	18	12	18	0.3	1	0.28	74.1	6.1187	1.4322
2014	9	10	18	22	18	0.3	1	0.26	79.7	6.1187	1.3615
2014	9	10	18	32	18	0.3	1	0.27	69.4	6.1187	1.3615
2014	9	10	18	42	18	0.3	1	0.35	62	6.1187	1.6621
2014	9	10	18	52	18	0.3	1	0.3	83	6.1187	1.5914
2014	9	10	19	2	18	0.3	1	0.32	78.2	6.1187	1.6975
2014	9	10	19	12	18	0.3	1	0.3	90	6.1187	1.5914
2014	9	10	19	22	18	0.3	1	0.27	79.5	6.1187	1.4323
2014	9	10	19	32	18	0.3	1	0.23	90	6.1187	1.2201
2014	9	10	19	42	18	0.3	1	0.27	97.7	6.0993	1.4274
2014	9	10	19	52	18	0.3	1	0.27	97.5	6.1187	1.4676
2014	9	10	20	2	18	0.3	1	0.35	91.6	6.0993	1.9032
2014	9	10	20	12	18	0.3	1	0.22	76.2	6.0993	1.1454
2014	9	10	20	22	18	0.3	1	0.23	89.2	6.1187	1.2554
2014	9	10	20	32	18	0.3	1	0.28	73.7	6.1187	1.45
2014	9	10	20	42	18	0.3	1	0.27	90.7	6.1187	1.4676
2014	9	10	20	52	18	0.3	1	0.26	90	6.1187	1.3969
2014	9	10	21	2	18	0.3	1	0.27	88.6	6.1187	1.45
2014	9	10	21	12	18	0.3	1	0.23	86	6.1187	1.2555
2014	9	10	21	22	18	0.3	1	0.24	100.2	6.1187	1.2732
2014	9	10	21	32	18	0.3	1	0.25	90	6.1187	1.3262

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	21	42	18	0.3	1	0.28	95.3	6.1187	1.5207
2014	9	10	21	52	18	0.3	1	0.26	105.6	6.1187	1.3262
2014	9	10	22	2	18	0.3	1	0.3	102.2	6.1187	1.5561
2014	9	10	22	12	18	0.3	1	0.28	102.9	6.1187	1.4677
2014	9	10	22	22	18	0.3	1	0.25	99.2	6.1187	1.3085
2014	9	10	22	32	18	0.3	1	0.27	85.1	6.1187	1.45
2014	9	10	22	42	18	0.3	1	0.31	94.3	6.1187	1.6445
2014	9	10	22	52	18	0.3	1	0.22	103	6.1187	1.1494
2014	9	10	23	2	18	0.3	1	0.24	94.6	6.1187	1.3085
2014	9	10	23	12	18	0.3	1	0.27	83.8	6.1187	1.4677
2014	9	10	23	22	18	0.3	1	0.24	80.4	6.0993	1.2512
2014	9	10	23	32	18	0.3	1	0.27	83.7	6.1187	1.45
2014	9	10	23	42	18	0.3	1	0.27	66.8	6.1187	1.3616
2014	9	10	23	52	18	0.3	1	0.21	83.9	6.0993	1.1455
2014	9	11	0	2	18	0.3	1	0.25	84.1	6.1187	1.3616
2014	9	11	0	12	18	0.3	1	0.2	93.8	6.1187	1.0787
2014	9	11	0	22	18	0.3	1	0.24	88.4	6.1187	1.2909
2014	9	11	0	32	18	0.3	1	0.24	88.4	6.1187	1.2909
2014	9	11	0	42	18	0.3	1	0.25	97.5	6.0993	1.3394
2014	9	11	0	52	18	0.3	1	0.21	93.5	6.1187	1.1494
2014	9	11	1	2	18	0.3	1	0.24	99.6	6.0993	1.2513
2014	9	11	1	12	18	0.3	1	0.27	90	6.1187	1.4324
2014	9	11	1	22	18	0.3	1	0.3	79.3	6.0993	1.5861
2014	9	11	1	32	18	0.3	1	0.27	99.9	6.0993	1.4099
2014	9	11	1	42	18	0.3	1	0.24	111.9	6.0993	1.1808
2014	9	11	1	52	18	0.3	1	0.2	85.4	6.0993	1.0926
2014	9	11	2	2	18	0.3	1	0.29	100.9	6.0993	1.5509
2014	9	11	2	12	18	0.3	1	0.27	93.5	6.0993	1.4451
2014	9	11	2	22	18	0.3	1	0.34	84.4	6.0993	1.7976
2014	9	11	2	32	18	0.3	1	0.2	89.1	6.0993	1.0927
2014	9	11	2	42	18	0.3	1	0.3	104.5	6.0993	1.5685
2014	9	11	2	52	18	0.3	1	0.23	99.1	6.0993	1.216
2014	9	11	3	2	18	0.3	1	0.24	92.3	6.0993	1.3041
2014	9	11	3	12	18	0.3	1	0.29	102.9	6.0993	1.5332
2014	9	11	3	22	18	0.3	1	0.25	100.4	6.0993	1.3394
2014	9	11	3	32	18	0.3	1	0.22	79.7	6.0993	1.1632
2014	9	11	3	42	18	0.3	1	0.27	90	6.0993	1.4275
2014	9	11	3	52	18	0.3	1	0.28	82.1	6.0993	1.5156
2014	9	11	4	2	18	0.3	1	0.28	83.4	6.0993	1.5156
2014	9	11	4	12	18	0.3	1	0.25	82.6	6.0993	1.357
2014	9	11	4	22	18	0.3	1	0.25	102	6.0993	1.3218
2014	9	11	4	32	18	0.3	1	0.2	80.4	6.0993	1.0398
2014	9	11	4	42	18	0.3	1	0.29	91.3	6.0993	1.5509
2014	9	11	4	52	18	0.3	1	0.28	92	6.0993	1.498
2014	9	11	5	2	18	0.3	1	0.21	97.1	6.08	1.1241
2014	9	11	5	12	18	0.3	1	0.28	84.6	6.08	1.4753

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	5	22	18	0.3	1	0.24	90.8	6.08	1.2997
2014	9	11	5	32	18	0.3	1	0.19	90	6.08	1.0187
2014	9	11	5	42	18	0.3	1	0.21	86.4	6.08	1.1065
2014	9	11	5	52	18	0.3	1	0.32	88.8	6.08	1.6861
2014	9	11	6	2	18	0.3	1	0.24	106.5	6.08	1.247
2014	9	11	6	12	18	0.3	1	0.22	96.1	6.08	1.1592
2014	9	11	6	22	18	0.3	1	0.22	90.9	6.08	1.1768
2014	9	11	6	32	18	0.3	1	0.25	93	6.08	1.3349
2014	9	11	6	42	18	0.3	1	0.28	102.1	6.08	1.4754
2014	9	11	6	52	18	0.3	1	0.25	74.7	6.08	1.2822
2014	9	11	7	2	18	0.3	1	0.24	101.8	6.08	1.2646
2014	9	11	7	12	18	0.3	1	0.25	87	6.08	1.3349
2014	9	11	7	22	18	0.3	1	0.17	101.9	6.08	0.9133
2014	9	11	7	32	18	0.3	1	0.23	102.6	6.08	1.1768
2014	9	11	7	42	18	0.3	1	0.25	93.8	6.08	1.3173
2014	9	11	7	52	18	0.3	1	0.26	95.1	6.08	1.37
2014	9	11	8	2	18	0.3	1	0.3	95	6.0606	1.6104
2014	9	11	8	12	18	0.3	1	0.28	89.3	6.08	1.4754
2014	9	11	8	22	18	0.3	1	0.26	94.3	6.0606	1.4003
2014	9	11	8	32	18	0.3	1	0.26	98.6	6.0606	1.3828
2014	9	11	8	42	18	0.3	1	0.28	100.8	6.0606	1.4703
2014	9	11	8	52	18	0.3	1	0.29	95.8	6.0606	1.5579
2014	9	11	9	2	18	0.3	1	0.25	98.5	6.0606	1.2953
2014	9	11	9	12	18	0.3	1	0.22	107.1	6.0606	1.1378
2014	9	11	9	22	18	0.3	1	0.18	84.9	6.0606	0.9802
2014	9	11	9	32	18	0.3	1	0.29	99.2	6.0606	1.5053
2014	9	11	9	42	18	0.3	1	0.22	94.2	6.0606	1.1903
2014	9	11	9	52	18	0.3	1	0.19	105.7	6.0606	0.9977
2014	9	11	10	2	18	0.3	1	0.26	90.7	6.0412	1.3955
2014	9	11	10	12	18	0.3	1	0.22	77.2	6.0412	1.1513
2014	9	11	10	22	18	0.3	1	0.22	80.7	6.0412	1.1687
2014	9	11	10	32	18	0.3	1	0.21	93.6	6.0412	1.1164
2014	9	11	10	42	18	0.3	1	0.26	79.1	6.0219	1.3559
2014	9	11	10	52	18	0.3	1	0.33	89.4	6.0219	1.7557
2014	9	11	11	2	18	0.3	1	0.2	76	6.0219	1.043
2014	9	11	11	12	18	0.3	1	0.19	85.1	6.0025	1.0048
2014	9	11	11	22	18	0.3	1	0.25	85.5	6.0025	1.3339
2014	9	11	11	32	18	0.3	1	0.19	83.1	5.9832	1.0013
2014	9	11	11	42	18	0.3	1	0.18	88	5.9832	0.9667
2014	9	11	11	52	18	0.3	1	0.27	93.4	5.9832	1.4328
2014	9	11	12	2	18	0.3	1	0.26	90.7	5.9832	1.3638
2014	9	11	12	12	18	0.3	1	0.25	81.5	5.9832	1.2774
2014	9	11	12	22	18	0.3	1	0.33	82	5.9832	1.7263
2014	9	11	12	32	18	0.3	1	0.32	88.2	5.9832	1.6572
2014	9	11	12	42	18	0.3	1	0.27	83	5.9832	1.4155
2014	9	11	12	52	18	0.3	1	0.31	73.9	5.9832	1.5536

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	13	2	18	0.3	1	0.23	67.9	5.9832	1.1048
2014	9	11	13	12	18	0.3	1	0.27	74.2	5.9832	1.3465
2014	9	11	13	22	18	0.3	1	0.19	78.3	5.9832	1.0012
2014	9	11	13	32	18	0.3	1	0.29	89.4	5.9832	1.5363
2014	9	11	13	42	18	0.3	1	0.33	94	5.9832	1.7262
2014	9	11	13	52	18	0.3	1	0.24	86	5.9832	1.2429
2014	9	11	14	2	18	0.3	1	0.29	71.6	5.9832	1.45
2014	9	11	14	12	18	0.3	1	0.3	77.2	5.9832	1.5191
2014	9	11	14	22	18	0.3	1	0.23	71.3	5.9832	1.122
2014	9	11	14	32	18	0.3	1	0.34	83.9	5.9832	1.778
2014	9	11	14	42	18	0.3	1	0.27	78.3	5.9832	1.4155
2014	9	11	14	52	18	0.3	1	0.3	97.4	6.0025	1.5936
2014	9	11	15	2	18	0.3	1	0.32	93.5	6.0025	1.6802
2014	9	11	15	12	18	0.3	1	0.29	73.8	6.0025	1.4897
2014	9	11	15	22	18	0.3	1	0.24	72.3	6.0025	1.1952
2014	9	11	15	32	18	0.3	1	0.26	82.1	6.0025	1.3684
2014	9	11	15	42	18	0.3	1	0.25	90	6.0025	1.2991
2014	9	11	15	52	18	0.3	1	0.28	81.1	6.0025	1.4377
2014	9	11	16	2	18	0.3	1	0.26	79.7	6.0025	1.3338
2014	9	11	16	12	18	0.3	1	0.3	73.4	6.0219	1.5122
2014	9	11	16	22	18	0.3	1	0.26	87.8	6.0219	1.3731
2014	9	11	16	32	18	0.3	1	0.28	79.1	6.0219	1.4427
2014	9	11	16	42	18	0.3	1	0.28	74.5	6.0412	1.4476
2014	9	11	16	52	18	0.3	1	0.31	87	6.0606	1.6451
2014	9	11	17	2	18	0.3	1	0.21	67	6.0606	1.0326
2014	9	11	17	12	18	0.3	1	0.29	86.7	6.08	1.5454
2014	9	11	17	22	18	0.3	1	0.27	86.5	6.08	1.44
2014	9	11	17	32	18	0.3	1	0.25	71.6	6.08	1.2644
2014	9	11	17	42	18	0.3	1	0.34	70.3	6.0993	1.7269
2014	9	11	17	52	18	0.3	1	0.26	82.7	6.0993	1.3745
2014	9	11	18	2	18	0.3	1	0.29	75.7	6.1187	1.5206
2014	9	11	18	12	18	0.3	1	0.35	71.9	6.1187	1.7859
2014	9	11	18	22	18	0.3	1	0.26	69.3	6.1187	1.3085
2014	9	11	18	32	18	0.3	1	0.28	81.1	6.1187	1.4676
2014	9	11	18	42	18	0.3	1	0.36	88.4	6.1187	1.945
2014	9	11	18	52	18	0.3	1	0.24	70.1	6.138	1.2242
2014	9	11	19	2	18	0.3	1	0.26	92.9	6.138	1.4194
2014	9	11	19	12	18	0.3	1	0.28	94	6.138	1.5081
2014	9	11	19	22	18	0.3	1	0.19	102.1	6.138	0.9936
2014	9	11	19	32	18	0.3	1	0.3	90	6.138	1.6145
2014	9	11	19	42	18	0.3	1	0.22	95.2	6.138	1.171
2014	9	11	19	52	18	0.3	1	0.26	95.9	6.138	1.3839
2014	9	11	20	2	18	0.3	1	0.24	90.8	6.138	1.2774
2014	9	11	20	12	18	0.3	1	0.26	92.9	6.1574	1.3886
2014	9	11	20	22	18	0.3	1	0.3	90.6	6.1574	1.6022
2014	9	11	20	32	18	0.3	1	0.29	97.9	6.1574	1.5488

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	20	42	18	0.3	1	0.26	90	6.1574	1.3886
2014	9	11	20	52	18	0.3	1	0.25	93.8	6.1574	1.353
2014	9	11	21	2	18	0.3	1	0.24	103.3	6.1574	1.2818
2014	9	11	21	12	18	0.3	1	0.26	99.5	6.1574	1.3886
2014	9	11	21	22	18	0.3	1	0.29	95.2	6.1574	1.5666
2014	9	11	21	32	18	0.3	1	0.27	87.9	6.1574	1.442
2014	9	11	21	42	18	0.3	1	0.33	91.1	6.1574	1.8159
2014	9	11	21	52	18	0.3	1	0.31	90.6	6.1574	1.6557
2014	9	11	22	2	18	0.3	1	0.3	95.6	6.1574	1.6379
2014	9	11	22	12	18	0.3	1	0.28	103.7	6.1574	1.4598
2014	9	11	22	22	18	0.3	1	0.26	92.9	6.1574	1.4242
2014	9	11	22	32	18	0.3	1	0.24	89.2	6.1767	1.3219
2014	9	11	22	42	18	0.3	1	0.31	94.9	6.1767	1.6613
2014	9	11	22	52	18	0.3	1	0.31	92.4	6.1767	1.697
2014	9	11	23	2	18	0.3	1	0.29	90	6.1767	1.5898
2014	9	11	23	12	18	0.3	1	0.35	93.2	6.1767	1.8935
2014	9	11	23	22	18	0.3	1	0.28	78.4	6.1767	1.4827
2014	9	11	23	32	18	0.3	1	0.26	94.4	6.1767	1.3933
2014	9	11	23	42	18	0.3	1	0.25	78.8	6.1767	1.3576
2014	9	11	23	52	18	0.3	1	0.32	93.5	6.1767	1.7328
2014	9	12	0	2	18	0.3	1	0.28	97.9	6.1767	1.5363
2014	9	12	0	12	18	0.3	1	0.24	92.3	6.1767	1.3219
2014	9	12	0	22	18	0.3	1	0.31	90	6.1961	1.7207
2014	9	12	0	32	18	0.3	1	0.29	97.1	6.1961	1.5773
2014	9	12	0	42	18	0.3	1	0.32	105.9	6.1961	1.7028
2014	9	12	0	52	18	0.3	1	0.32	94.1	6.1961	1.7565
2014	9	12	1	2	18	0.3	1	0.23	75.4	6.1961	1.2367
2014	9	12	1	12	18	0.3	1	0.27	90	6.1961	1.4877
2014	9	12	1	22	18	0.3	1	0.31	89.4	6.1961	1.7207
2014	9	12	1	32	18	0.3	1	0.29	91.3	6.1961	1.5773
2014	9	12	1	42	18	0.3	1	0.33	105.4	6.2154	1.7624
2014	9	12	1	52	18	0.3	1	0.27	90	6.2154	1.4567
2014	9	12	2	2	18	0.3	1	0.3	100.6	6.2154	1.6365
2014	9	12	2	12	18	0.3	1	0.28	105.7	6.2154	1.4747
2014	9	12	2	22	18	0.3	1	0.27	101.9	6.2154	1.4567
2014	9	12	2	32	18	0.3	1	0.27	85.8	6.2348	1.4616
2014	9	12	2	42	18	0.3	1	0.23	95.6	6.2348	1.2811
2014	9	12	2	52	18	0.3	1	0.28	91.3	6.2542	1.5389
2014	9	12	3	2	18	0.3	1	0.23	87.5	6.2542	1.2492
2014	9	12	3	12	18	0.3	1	0.28	96	6.2735	1.544
2014	9	12	3	22	18	0.3	1	0.3	97	6.2929	1.6402
2014	9	12	3	32	18	0.3	1	0.3	93.1	6.2929	1.6585
2014	9	12	3	42	18	0.3	1	0.3	88.1	6.2929	1.6767
2014	9	12	3	52	18	0.3	1	0.26	104.6	6.2929	1.4033
2014	9	12	4	2	18	0.3	1	0.33	93.5	6.2929	1.8043
2014	9	12	4	12	18	0.3	1	0.35	94.3	6.3122	1.9382

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	4	22	18	0.3	1	0.35	90	6.3122	1.9748
2014	9	12	4	32	18	0.3	1	0.3	90.6	6.3122	1.664
2014	9	12	4	42	18	0.3	1	0.31	85.7	6.3122	1.7005
2014	9	12	4	52	18	0.3	1	0.3	93.7	6.3122	1.6822
2014	9	12	5	2	18	0.3	1	0.3	84.3	6.3122	1.6457
2014	9	12	5	12	18	0.3	1	0.27	91.4	6.3122	1.5177
2014	9	12	5	22	18	0.3	1	0.28	84.7	6.3122	1.5725
2014	9	12	5	32	18	0.3	1	0.35	87.9	6.3122	1.9748
2014	9	12	5	42	18	0.3	1	0.34	87.3	6.3316	1.9263
2014	9	12	5	52	18	0.3	1	0.28	92.7	6.3316	1.5777
2014	9	12	6	2	18	0.3	1	0.29	80.8	6.3316	1.5777
2014	9	12	6	12	18	0.3	1	0.34	92.2	6.3316	1.9263
2014	9	12	6	22	18	0.3	1	0.28	87.3	6.3316	1.5777
2014	9	12	6	32	18	0.3	1	0.25	90	6.3316	1.3943
2014	9	12	6	42	18	0.3	1	0.27	92.8	6.3316	1.486
2014	9	12	6	52	18	0.3	1	0.26	93.6	6.3316	1.4493
2014	9	12	7	2	18	0.3	1	0.32	94.7	6.3316	1.7795
2014	9	12	7	12	18	0.3	1	0.29	96.6	6.3316	1.5961
2014	9	12	7	22	18	0.3	1	0.24	110.9	6.3316	1.2475
2014	9	12	7	32	18	0.3	1	0.31	90	6.3316	1.7429
2014	9	12	7	42	18	0.3	1	0.3	100.1	6.3316	1.6511
2014	9	12	7	52	18	0.3	1	0.31	91.2	6.3316	1.7062
2014	9	12	8	2	18	0.3	1	0.24	98.8	6.3316	1.3026
2014	9	12	8	12	18	0.3	1	0.32	89.4	6.3316	1.8163
2014	9	12	8	22	18	0.3	1	0.28	92	6.3316	1.5594
2014	9	12	8	32	18	0.3	1	0.25	86.2	6.3316	1.3943
2014	9	12	8	42	18	0.3	1	0.24	100.2	6.3316	1.3209
2014	9	12	8	52	18	0.3	1	0.31	90	6.3316	1.7062
2014	9	12	9	2	18	0.3	1	0.25	84.7	6.3316	1.3943
2014	9	12	9	12	18	0.3	1	0.34	95	6.3316	1.8896
2014	9	12	9	22	18	0.3	1	0.32	82.4	6.3316	1.7796
2014	9	12	9	32	18	0.3	1	0.28	88.7	6.3316	1.5777
2014	9	12	9	42	18	0.3	1	0.29	92.6	6.3316	1.6144
2014	9	12	9	52	18	0.3	1	0.27	102.8	6.3316	1.4493
2014	9	12	10	2	18	0.3	1	0.29	91.9	6.3316	1.6328
2014	9	12	10	12	18	0.3	1	0.36	94.8	6.3316	1.9813
2014	9	12	10	22	18	0.3	1	0.29	85.5	6.3316	1.6144
2014	9	12	10	32	18	0.3	1	0.24	83.1	6.3316	1.3576
2014	9	12	10	42	18	0.3	1	0.34	84.5	6.3316	1.908
2014	9	12	10	52	18	0.3	1	0.3	85.6	6.3316	1.6511
2014	9	12	11	2	18	0.3	1	0.28	96.7	6.3316	1.5594
2014	9	12	11	12	18	0.3	1	0.26	84.2	6.3316	1.4493
2014	9	12	11	22	18	0.3	1	0.28	90	6.3316	1.5594
2014	9	12	11	32	18	0.3	1	0.34	95.5	6.3316	1.9079
2014	9	12	11	42	18	0.3	1	0.34	97.3	6.3316	1.8712
2014	9	12	11	52	18	0.3	1	0.29	83.5	6.3316	1.6144

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	12	2	18	0.3	1	0.31	76	6.3316	1.6878
2014	9	12	12	12	18	0.3	1	0.33	79.7	6.3316	1.8162
2014	9	12	12	22	18	0.3	1	0.34	78.1	6.3316	1.8345
2014	9	12	12	32	18	0.3	1	0.33	90	6.3316	1.8345
2014	9	12	12	42	18	0.3	1	0.29	84.7	6.3316	1.596
2014	9	12	12	52	18	0.3	1	0.34	79	6.3122	1.8833
2014	9	12	13	2	18	0.3	1	0.24	72.6	6.3316	1.2841
2014	9	12	13	12	18	0.3	1	0.31	80.1	6.3316	1.6877
2014	9	12	13	22	18	0.3	1	0.33	86.5	6.3122	1.8102
2014	9	12	13	32	18	0.3	1	0.3	76.9	6.3316	1.651
2014	9	12	13	42	18	0.3	1	0.35	79.1	6.3122	1.9016
2014	9	12	13	52	18	0.3	1	0.31	85.1	6.3122	1.7187
2014	9	12	14	2	18	0.3	1	0.34	90	6.3122	1.9016
2014	9	12	14	12	18	0.3	1	0.3	87.5	6.3122	1.6456
2014	9	12	14	22	18	0.3	1	0.32	80.4	6.3122	1.737
2014	9	12	14	32	18	0.3	1	0.33	95.2	6.3122	1.8101
2014	9	12	14	42	18	0.3	1	0.33	80.9	6.3122	1.8284
2014	9	12	14	52	18	0.3	1	0.33	83.1	6.3122	1.8101
2014	9	12	15	2	18	0.3	1	0.3	77.9	6.2929	1.6219
2014	9	12	15	12	18	0.3	1	0.36	87.4	6.2929	2.0228
2014	9	12	15	22	18	0.3	1	0.31	74.2	6.2929	1.6766
2014	9	12	15	32	18	0.3	1	0.31	79	6.2929	1.6948
2014	9	12	15	42	18	0.3	1	0.33	87.7	6.2929	1.8224
2014	9	12	15	52	18	0.3	1	0.34	67.9	6.2929	1.7495
2014	9	12	16	2	18	0.3	1	0.31	87	6.2735	1.7074
2014	9	12	16	12	18	0.3	1	0.29	80.1	6.2735	1.562
2014	9	12	16	22	18	0.3	1	0.34	76.6	6.2929	1.8406
2014	9	12	16	32	18	0.3	1	0.33	82	6.2735	1.7982
2014	9	12	16	42	18	0.3	1	0.28	79.1	6.2735	1.5076
2014	9	12	16	52	18	0.3	1	0.3	85.6	6.2735	1.671
2014	9	12	17	2	18	0.3	1	0.31	77.6	6.2735	1.6529
2014	9	12	17	12	18	0.3	1	0.3	86.8	6.2735	1.6347
2014	9	12	17	22	18	0.3	1	0.29	80.3	6.2542	1.5931
2014	9	12	17	32	18	0.3	1	0.31	74.6	6.2735	1.6529
2014	9	12	17	42	18	0.3	1	0.38	73.8	6.2735	1.998
2014	9	12	17	52	18	0.3	1	0.34	81.6	6.2735	1.8527
2014	9	12	18	2	18	0.3	1	0.36	78	6.2735	1.9616
2014	9	12	18	12	18	0.3	1	0.3	71.6	6.2735	1.5802
2014	9	12	18	22	18	0.3	1	0.25	80.3	6.2735	1.3804
2014	9	12	18	32	18	0.3	1	0.3	84.4	6.2735	1.671
2014	9	12	18	42	18	0.3	1	0.35	85.2	6.2735	1.9435
2014	9	12	18	52	18	0.3	1	0.31	90	6.2735	1.7437
2014	9	12	19	2	18	0.3	1	0.27	85.8	6.2929	1.4761
2014	9	12	19	12	18	0.3	1	0.37	89	6.2735	2.0706
2014	9	12	19	22	18	0.3	1	0.37	86.4	6.2735	2.0343
2014	9	12	19	32	18	0.3	1	0.26	90	6.2929	1.4214

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	19	42	18	0.3	1	0.36	85.8	6.2929	2.0046
2014	9	12	19	52	18	0.3	1	0.35	81.9	6.2929	1.9135
2014	9	12	20	2	18	0.3	1	0.31	99.2	6.2929	1.6948
2014	9	12	20	12	18	0.3	1	0.24	92.3	6.3122	1.353
2014	9	12	20	22	18	0.3	1	0.23	90	6.3122	1.2799
2014	9	12	20	32	18	0.3	1	0.3	93.1	6.3122	1.6639
2014	9	12	20	42	18	0.3	1	0.3	100.2	6.3122	1.6273
2014	9	12	20	52	18	0.3	1	0.25	94.5	6.3122	1.3896
2014	9	12	21	2	18	0.3	1	0.32	93.5	6.3316	1.7794
2014	9	12	21	12	18	0.3	1	0.23	104.6	6.3316	1.2658
2014	9	12	21	22	18	0.3	1	0.27	88.6	6.3316	1.5043
2014	9	12	21	32	18	0.3	1	0.24	87.6	6.3316	1.3208
2014	9	12	21	42	18	0.3	1	0.31	93.6	6.3316	1.7427
2014	9	12	21	52	18	0.3	1	0.32	90	6.3316	1.8161
2014	9	12	22	2	18	0.3	1	0.31	90	6.3316	1.7427
2014	9	12	22	12	18	0.3	1	0.31	89.4	6.3316	1.7611
2014	9	12	22	22	18	0.3	1	0.23	93.3	6.3316	1.2841
2014	9	12	22	32	18	0.3	1	0.31	90	6.3316	1.7611
2014	9	12	22	42	18	0.3	1	0.31	86.3	6.3316	1.7061
2014	9	12	22	52	18	0.3	1	0.29	97.1	6.3316	1.6143
2014	9	12	23	2	18	0.3	1	0.29	100.3	6.3316	1.6143
2014	9	12	23	12	18	0.3	1	0.34	88.3	6.3316	1.9079
2014	9	12	23	22	18	0.3	1	0.33	90	6.3316	1.8345
2014	9	12	23	32	18	0.3	1	0.26	90	6.3316	1.4309
2014	9	12	23	42	18	0.3	1	0.33	91.1	6.3316	1.8712
2014	9	12	23	52	18	0.3	1	0.31	96.7	6.3316	1.7244
2014	9	13	0	2	18	0.3	1	0.31	99.2	6.3316	1.7061
2014	9	13	0	12	18	0.3	1	0.34	85.6	6.3316	1.8895
2014	9	13	0	22	18	0.3	1	0.27	87.9	6.3316	1.4859
2014	9	13	0	32	18	0.3	1	0.34	83.9	6.3316	1.8895
2014	9	13	0	42	18	0.3	1	0.25	95.3	6.3316	1.3942
2014	9	13	0	52	18	0.3	1	0.3	97.6	6.3316	1.6511
2014	9	13	1	2	18	0.3	1	0.29	85.4	6.3316	1.596
2014	9	13	1	12	18	0.3	1	0.3	87.5	6.3316	1.6511
2014	9	13	1	22	18	0.3	1	0.33	97.3	6.3316	1.8529
2014	9	13	1	32	18	0.3	1	0.31	93.1	6.3316	1.7061
2014	9	13	1	42	18	0.3	1	0.31	95.5	6.3316	1.7061
2014	9	13	1	52	18	0.3	1	0.32	85.9	6.3316	1.7795
2014	9	13	2	2	18	0.3	1	0.3	90.6	6.3316	1.6694
2014	9	13	2	12	18	0.3	1	0.27	82.4	6.3316	1.5043
2014	9	13	2	22	18	0.3	1	0.33	95.8	6.3316	1.8162
2014	9	13	2	32	18	0.3	1	0.3	94.4	6.3316	1.6511
2014	9	13	2	42	18	0.3	1	0.3	86.9	6.3316	1.6878
2014	9	13	2	52	18	0.3	1	0.34	92.8	6.3316	1.8896
2014	9	13	3	2	18	0.3	1	0.33	106.6	6.3316	1.7795
2014	9	13	3	12	18	0.3	1	0.31	89.4	6.3316	1.7245

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	3	22	18	0.3	1	0.3	104	6.3316	1.6144
2014	9	13	3	32	18	0.3	1	0.28	90.7	6.3316	1.5777
2014	9	13	3	42	18	0.3	1	0.29	101.2	6.3316	1.5777
2014	9	13	3	52	18	0.3	1	0.27	76.8	6.3316	1.486
2014	9	13	4	2	18	0.3	1	0.3	93.1	6.3316	1.6878
2014	9	13	4	12	18	0.3	1	0.26	97.8	6.3316	1.4676
2014	9	13	4	22	18	0.3	1	0.32	90	6.3509	1.7853
2014	9	13	4	32	18	0.3	1	0.28	90	6.3316	1.5594
2014	9	13	4	42	18	0.3	1	0.3	98.1	6.3316	1.6694
2014	9	13	4	52	18	0.3	1	0.29	98.5	6.3316	1.5961
2014	9	13	5	2	18	0.3	1	0.27	96.3	6.3316	1.486
2014	9	13	5	12	18	0.3	1	0.34	88.3	6.3509	1.9142
2014	9	13	5	22	18	0.3	1	0.29	95.8	6.3509	1.6197
2014	9	13	5	32	18	0.3	1	0.25	93	6.3509	1.3988
2014	9	13	5	42	18	0.3	1	0.31	94.9	6.3509	1.7302
2014	9	13	5	52	18	0.3	1	0.29	90.7	6.3316	1.5961
2014	9	13	6	2	18	0.3	1	0.29	102.6	6.3316	1.5594
2014	9	13	6	12	18	0.3	1	0.25	78.7	6.3509	1.3804
2014	9	13	6	22	18	0.3	1	0.35	93.2	6.3509	1.951
2014	9	13	6	32	18	0.3	1	0.35	90.5	6.3509	1.9694
2014	9	13	6	42	18	0.3	1	0.34	93.9	6.3509	1.8958
2014	9	13	6	52	18	0.3	1	0.34	101.6	6.3509	1.8774
2014	9	13	7	2	18	0.3	1	0.36	97.4	6.3509	1.9879
2014	9	13	7	12	18	0.3	1	0.34	102.4	6.3509	1.8406
2014	9	13	7	22	18	0.3	1	0.24	93.9	6.3509	1.3621
2014	9	13	7	32	18	0.3	1	0.29	104.5	6.3509	1.5645
2014	9	13	7	42	18	0.3	1	0.29	96.6	6.3509	1.6013
2014	9	13	7	52	18	0.3	1	0.24	81.3	6.3509	1.3252
2014	9	13	8	2	18	0.3	1	0.24	90.8	6.3509	1.3437
2014	9	13	8	12	18	0.3	1	0.32	104.7	6.3509	1.7486
2014	9	13	8	22	18	0.3	1	0.39	99.1	6.3509	2.1719
2014	9	13	8	32	18	0.3	1	0.26	92.9	6.3509	1.4541
2014	9	13	8	42	18	0.3	1	0.27	101.3	6.3509	1.4725
2014	9	13	8	52	18	0.3	1	0.34	92.2	6.3509	1.8958
2014	9	13	9	2	18	0.3	1	0.32	100	6.3509	1.767
2014	9	13	9	12	18	0.3	1	0.32	95.4	6.3509	1.767
2014	9	13	9	22	18	0.3	1	0.33	87.1	6.3509	1.8406
2014	9	13	9	32	18	0.3	1	0.26	92.9	6.3509	1.4541
2014	9	13	9	42	18	0.3	1	0.3	81.2	6.3509	1.6565
2014	9	13	9	52	18	0.3	1	0.24	89.2	6.3509	1.3252
2014	9	13	10	2	18	0.3	1	0.33	84.3	6.3509	1.8406
2014	9	13	10	12	18	0.3	1	0.38	92.4	6.3509	2.1535
2014	9	13	10	22	18	0.3	1	0.32	88.2	6.3509	1.7854
2014	9	13	10	32	18	0.3	1	0.33	87.1	6.3509	1.8406
2014	9	13	10	42	18	0.3	1	0.32	90	6.3316	1.8162
2014	9	13	10	52	18	0.3	1	0.33	78.5	6.3316	1.7979

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	11	2	18	0.3	1	0.3	83.8	6.3316	1.6878
2014	9	13	11	12	18	0.3	1	0.32	90.6	6.3316	1.7795
2014	9	13	11	22	18	0.3	1	0.31	87.5	6.3316	1.7061
2014	9	13	11	32	18	0.3	1	0.29	90.6	6.3316	1.6328
2014	9	13	11	42	18	0.3	1	0.32	91.8	6.3316	1.7612
2014	9	13	11	52	18	0.3	1	0.31	96.1	6.3316	1.7245
2014	9	13	12	2	18	0.3	1	0.35	90	6.3316	1.9813
2014	9	13	12	12	18	0.3	1	0.34	78.1	6.3316	1.8345
2014	9	13	12	22	18	0.3	1	0.36	92.6	6.3316	2.018
2014	9	13	12	32	18	0.3	1	0.3	82.4	6.3316	1.651
2014	9	13	12	42	18	0.3	1	0.37	75	6.3316	1.9813
2014	9	13	12	52	18	0.3	1	0.33	84.9	6.3316	1.8345
2014	9	13	13	2	18	0.3	1	0.31	74.1	6.3316	1.6694
2014	9	13	13	12	18	0.3	1	0.39	79.8	6.3316	2.1463
2014	9	13	13	22	18	0.3	1	0.39	76.3	6.3316	2.1096
2014	9	13	13	32	18	0.3	1	0.36	81	6.3316	1.9629
2014	9	13	13	42	18	0.3	1	0.34	71.9	6.3122	1.7919
2014	9	13	13	52	18	0.3	1	0.35	69.9	6.3122	1.8467
2014	9	13	14	2	18	0.3	1	0.36	70.4	6.3122	1.9016
2014	9	13	14	12	18	0.3	1	0.32	78.7	6.3122	1.737
2014	9	13	14	22	18	0.3	1	0.4	88.1	6.3122	2.2124
2014	9	13	14	32	18	0.3	1	0.39	87.1	6.3122	2.1575
2014	9	13	14	42	18	0.3	1	0.33	87.1	6.3122	1.8284
2014	9	13	14	52	18	0.3	1	0.29	81.6	6.3122	1.609
2014	9	13	15	2	18	0.3	1	0.29	82.1	6.2929	1.5855
2014	9	13	15	12	18	0.3	1	0.34	86.1	6.2929	1.8588
2014	9	13	15	22	18	0.3	1	0.34	82.2	6.2929	1.8588
2014	9	13	15	32	18	0.3	1	0.32	87.6	6.2929	1.7677
2014	9	13	15	42	18	0.3	1	0.33	73.7	6.2735	1.7437
2014	9	13	15	52	18	0.3	1	0.39	81.3	6.2735	2.1251
2014	9	13	16	2	18	0.3	1	0.28	82	6.2735	1.5439
2014	9	13	16	12	18	0.3	1	0.34	89.5	6.2735	1.9072
2014	9	13	16	22	18	0.3	1	0.32	81.8	6.2542	1.756
2014	9	13	16	32	18	0.3	1	0.33	71.6	6.2542	1.7379
2014	9	13	16	42	18	0.3	1	0.33	75.7	6.2542	1.7741
2014	9	13	16	52	18	0.3	1	0.38	55.1	6.2542	1.7379
2014	9	13	17	2	18	0.3	1	0.39	64.3	6.2348	1.9487
2014	9	13	17	12	18	0.3	1	0.34	58.3	6.2348	1.6058
2014	9	13	17	22	18	0.3	1	0.41	58.7	6.2348	1.9306
2014	9	13	17	32	18	0.3	1	0.4	58	6.2348	1.8765
2014	9	13	17	42	18	0.3	1	0.43	48.7	6.2348	1.7682
2014	9	13	17	52	18	0.3	1	0.39	65.2	6.2348	1.9487
2014	9	13	18	2	18	0.3	1	0.46	47.6	6.2348	1.8584
2014	9	13	18	12	18	0.3	1	0.37	45	6.2348	1.4434
2014	9	13	18	22	18	0.3	1	0.31	50.6	6.2348	1.3171
2014	9	13	18	32	18	0.3	1	0.33	64.2	6.2542	1.6474

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	18	42	18	0.3	1	0.34	62.4	6.2542	1.6655
2014	9	13	18	52	18	0.3	1	0.34	58	6.2542	1.5931
2014	9	13	19	2	18	0.3	1	0.26	87.8	6.2542	1.4302
2014	9	13	19	12	18	0.3	1	0.22	82.1	6.2542	1.1767
2014	9	13	19	22	18	0.3	1	0.34	68.4	6.2542	1.7379
2014	9	13	19	32	18	0.3	1	0.38	67.6	6.2348	1.9306
2014	9	13	19	42	18	0.3	1	0.39	63	6.2542	1.919
2014	9	13	19	52	18	0.3	1	0.42	65.6	6.2542	2.1181
2014	9	13	20	2	18	0.3	1	0.33	63.2	6.2542	1.6112
2014	9	13	20	12	18	0.3	1	0.34	87.8	6.2542	1.8828
2014	9	13	20	22	18	0.3	1	0.28	84.6	6.2542	1.5207
2014	9	13	20	32	18	0.3	1	0.26	100.2	6.2542	1.4121
2014	9	13	20	42	18	0.3	1	0.3	88.1	6.2542	1.6474
2014	9	13	20	52	18	0.3	1	0.31	80.9	6.2735	1.7074
2014	9	13	21	2	18	0.3	1	0.37	79.7	6.2735	1.998
2014	9	13	21	12	18	0.3	1	0.27	72.9	6.2735	1.4168
2014	9	13	21	22	18	0.3	1	0.29	86.7	6.2735	1.5803
2014	9	13	21	32	18	0.3	1	0.28	90.7	6.2929	1.5308
2014	9	13	21	42	18	0.3	1	0.29	87.4	6.2929	1.5855
2014	9	13	21	52	18	0.3	1	0.26	98.1	6.2929	1.4033
2014	9	13	22	2	18	0.3	1	0.27	93.5	6.2929	1.4762
2014	9	13	22	12	18	0.3	1	0.32	85.3	6.2929	1.786
2014	9	13	22	22	18	0.3	1	0.28	90.7	6.2735	1.5258
2014	9	13	22	32	18	0.3	1	0.25	94.5	6.2735	1.3986
2014	9	13	22	42	18	0.3	1	0.36	99	6.2735	1.9436
2014	9	13	22	52	18	0.3	1	0.33	95.7	6.2929	1.8407
2014	9	13	23	2	18	0.3	1	0.28	90	6.2929	1.5491
2014	9	13	23	12	18	0.3	1	0.27	105.4	6.2735	1.4531
2014	9	13	23	22	18	0.3	1	0.27	86.5	6.2929	1.4944
2014	9	13	23	32	18	0.3	1	0.33	91.1	6.2735	1.8164
2014	9	13	23	42	18	0.3	1	0.28	62.2	6.2542	1.3759
2014	9	13	23	52	18	0.3	1	0.29	73	6.2542	1.5388
2014	9	14	0	2	18	0.3	1	0.33	64.9	6.2542	1.6656
2014	9	14	0	12	18	0.3	1	0.33	66.3	6.2542	1.6475
2014	9	14	0	22	18	0.3	1	0.39	60.2	6.2542	1.8647
2014	9	14	0	32	18	0.3	1	0.3	75.2	6.2735	1.5803
2014	9	14	0	42	18	0.3	1	0.33	86.5	6.2735	1.7983
2014	9	14	0	52	18	0.3	1	0.24	91.6	6.2542	1.3216
2014	9	14	1	2	18	0.3	1	0.32	102.5	6.2542	1.7199
2014	9	14	1	12	18	0.3	1	0.31	93.1	6.2542	1.6837
2014	9	14	1	22	18	0.3	1	0.29	92.6	6.2542	1.5751
2014	9	14	1	32	18	0.3	1	0.28	85.9	6.2542	1.5208
2014	9	14	1	42	18	0.3	1	0.28	99.4	6.2542	1.5389
2014	9	14	1	52	18	0.3	1	0.24	92.3	6.2542	1.3397
2014	9	14	2	2	18	0.3	1	0.39	96.3	6.2348	2.1292
2014	9	14	2	12	18	0.3	1	0.33	96.2	6.2348	1.8225

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	2	22	18	0.3	1	0.29	111.6	6.2348	1.4616
2014	9	14	2	32	18	0.3	1	0.24	102.5	6.2348	1.2992
2014	9	14	2	42	18	0.3	1	0.29	93.2	6.2348	1.6059
2014	9	14	2	52	18	0.3	1	0.28	100.7	6.2348	1.5338
2014	9	14	3	2	18	0.3	1	0.28	82.1	6.2348	1.5518
2014	9	14	3	12	18	0.3	1	0.21	94.5	6.2348	1.1548
2014	9	14	3	22	18	0.3	1	0.29	93.9	6.2348	1.6059
2014	9	14	3	32	18	0.3	1	0.25	98.3	6.2348	1.3533
2014	9	14	3	42	18	0.3	1	0.36	103.7	6.2154	1.9243
2014	9	14	3	52	18	0.3	1	0.31	90.6	6.2348	1.7323
2014	9	14	4	2	18	0.3	1	0.26	90	6.2154	1.4208
2014	9	14	4	12	18	0.3	1	0.35	85.2	6.2348	1.9307
2014	9	14	4	22	18	0.3	1	0.25	92.2	6.2348	1.3894
2014	9	14	4	32	18	0.3	1	0.29	92	6.2348	1.5699
2014	9	14	4	42	18	0.3	1	0.22	85.7	6.2154	1.187
2014	9	14	4	52	18	0.3	1	0.29	91.9	6.2348	1.606
2014	9	14	5	2	18	0.3	1	0.31	96.1	6.2348	1.6962
2014	9	14	5	12	18	0.3	1	0.24	94	6.2154	1.2949
2014	9	14	5	22	18	0.3	1	0.27	102.8	6.2348	1.4255
2014	9	14	5	32	18	0.3	1	0.3	96.3	6.2154	1.6366
2014	9	14	5	42	18	0.3	1	0.26	90	6.2154	1.4028
2014	9	14	5	52	18	0.3	1	0.25	109.1	6.2154	1.2949
2014	9	14	6	2	18	0.3	1	0.28	94.1	6.2154	1.5107
2014	9	14	6	12	18	0.3	1	0.3	90	6.2154	1.6186
2014	9	14	6	22	18	0.3	1	0.3	81.3	6.2154	1.6366
2014	9	14	6	32	18	0.3	1	0.23	98.1	6.2154	1.2589
2014	9	14	6	42	18	0.3	1	0.24	78.2	6.2348	1.2992
2014	9	14	6	52	18	0.3	1	0.25	106.8	6.2154	1.3129
2014	9	14	7	2	18	0.3	1	0.34	104.6	6.2154	1.7985
2014	9	14	7	12	18	0.3	1	0.22	97.8	6.2154	1.187
2014	9	14	7	22	18	0.3	1	0.28	86.6	6.2154	1.5287
2014	9	14	7	32	18	0.3	1	0.3	98.3	6.2154	1.6006
2014	9	14	7	42	18	0.3	1	0.27	104.9	6.2154	1.4208
2014	9	14	7	52	18	0.3	1	0.3	94.4	6.2154	1.6186
2014	9	14	8	2	18	0.3	1	0.26	92.9	6.2154	1.4208
2014	9	14	8	12	18	0.3	1	0.25	93.8	6.2154	1.3488
2014	9	14	8	22	18	0.3	1	0.32	105.6	6.2154	1.6726
2014	9	14	8	32	18	0.3	1	0.31	113.3	6.2154	1.5467
2014	9	14	8	42	18	0.3	1	0.24	104.4	6.2154	1.2589
2014	9	14	8	52	18	0.3	1	0.26	101.6	6.1961	1.3981
2014	9	14	9	2	18	0.3	1	0.27	98.4	6.2154	1.4568
2014	9	14	9	12	18	0.3	1	0.29	93.2	6.1961	1.5953
2014	9	14	9	22	18	0.3	1	0.32	98.4	6.1961	1.7028
2014	9	14	9	32	18	0.3	1	0.29	95.3	6.1961	1.5594
2014	9	14	9	42	18	0.3	1	0.23	89.2	6.1961	1.2368
2014	9	14	9	52	18	0.3	1	0.29	99.8	6.1961	1.5594

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	10	2	18	0.3	1	0.26	91.5	6.1961	1.3981
2014	9	14	10	12	18	0.3	1	0.32	77	6.1961	1.7028
2014	9	14	10	22	18	0.3	1	0.24	97.7	6.1961	1.3264
2014	9	14	10	32	18	0.3	1	0.36	81	6.1961	1.9179
2014	9	14	10	42	18	0.3	1	0.28	87.3	6.1961	1.5236
2014	9	14	10	52	18	0.3	1	0.33	86.6	6.1961	1.8104
2014	9	14	11	2	18	0.3	1	0.34	92.8	6.1961	1.8283
2014	9	14	11	12	18	0.3	1	0.31	80.7	6.1767	1.6435
2014	9	14	11	22	18	0.3	1	0.32	88.2	6.1961	1.7207
2014	9	14	11	32	18	0.3	1	0.31	91.8	6.1961	1.6849
2014	9	14	11	42	18	0.3	1	0.26	84.9	6.1961	1.3981
2014	9	14	11	52	18	0.3	1	0.29	96.6	6.1767	1.5541
2014	9	14	12	2	18	0.3	1	0.26	87.8	6.1767	1.4112
2014	9	14	12	12	18	0.3	1	0.31	87.5	6.1767	1.6613
2014	9	14	12	22	18	0.3	1	0.3	83.8	6.1767	1.6434
2014	9	14	12	32	18	0.3	1	0.31	82.6	6.1767	1.6613
2014	9	14	12	42	18	0.3	1	0.35	84.6	6.1767	1.8935
2014	9	14	12	52	18	0.3	1	0.28	72.4	6.1767	1.4648
2014	9	14	13	2	18	0.3	1	0.32	84.7	6.1767	1.7327
2014	9	14	13	12	18	0.3	1	0.32	85.3	6.1767	1.7506
2014	9	14	13	22	18	0.3	1	0.32	84.7	6.1767	1.7327
2014	9	14	13	32	18	0.3	1	0.41	89.1	6.1767	2.215
2014	9	14	13	42	18	0.3	1	0.32	87.6	6.1767	1.7327
2014	9	14	13	52	18	0.3	1	0.27	94.9	6.1767	1.4648
2014	9	14	14	2	18	0.3	1	0.29	87.4	6.1767	1.572
2014	9	14	14	12	18	0.3	1	0.34	78.3	6.1767	1.8042
2014	9	14	14	22	18	0.3	1	0.33	84.2	6.1767	1.7684
2014	9	14	14	32	18	0.3	1	0.33	89.4	6.1767	1.7863
2014	9	14	14	42	18	0.3	1	0.35	87.8	6.1767	1.8935
2014	9	14	14	52	18	0.3	1	0.27	85.1	6.1767	1.4648
2014	9	14	15	2	18	0.3	1	0.31	80.8	6.1767	1.6612
2014	9	14	15	12	18	0.3	1	0.33	85.4	6.1767	1.7863
2014	9	14	15	22	18	0.3	1	0.35	78.7	6.1767	1.8756
2014	9	14	15	32	18	0.3	1	0.33	79.1	6.1767	1.7684
2014	9	14	15	42	18	0.3	1	0.28	90	6.1767	1.5183
2014	9	14	15	52	18	0.3	1	0.29	82.9	6.1767	1.5719
2014	9	14	16	2	18	0.3	1	0.29	86.7	6.1767	1.5719
2014	9	14	16	12	18	0.3	1	0.25	84.8	6.1574	1.3708
2014	9	14	16	22	18	0.3	1	0.26	80.5	6.1767	1.3933
2014	9	14	16	32	18	0.3	1	0.22	75.3	6.1767	1.1611
2014	9	14	16	42	18	0.3	1	0.34	71.7	6.1767	1.7327
2014	9	14	16	52	18	0.3	1	0.34	73.8	6.1767	1.7863
2014	9	14	17	2	18	0.3	1	0.28	84	6.1767	1.5183
2014	9	14	17	12	18	0.3	1	0.37	82.8	6.1767	1.9828
2014	9	14	17	22	18	0.3	1	0.35	75.4	6.1767	1.8577
2014	9	14	17	32	18	0.3	1	0.31	82.7	6.1767	1.6791

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	17	42	18	0.3	1	0.25	80	6.1767	1.3218
2014	9	14	17	52	18	0.3	1	0.35	84.6	6.1767	1.8756
2014	9	14	18	2	18	0.3	1	0.26	88.5	6.1767	1.3933
2014	9	14	18	12	18	0.3	1	0.36	85.8	6.1767	1.9292
2014	9	14	18	22	18	0.3	1	0.29	82.3	6.1767	1.5898
2014	9	14	18	32	18	0.3	1	0.26	82.7	6.1767	1.3933
2014	9	14	18	42	18	0.3	1	0.18	99.6	6.1767	0.9467
2014	9	14	18	52	18	0.3	1	0.26	88.5	6.1767	1.3933
2014	9	14	19	2	18	0.3	1	0.3	73.4	6.1767	1.5541
2014	9	14	19	12	18	0.3	1	0.23	92.5	6.1767	1.2325
2014	9	14	19	22	18	0.3	1	0.24	86.9	6.1767	1.304
2014	9	14	19	32	18	0.3	1	0.23	90	6.1767	1.2504
2014	9	14	19	42	18	0.3	1	0.26	88.6	6.1767	1.429
2014	9	14	19	52	18	0.3	1	0.24	90.8	6.1767	1.3219
2014	9	14	20	2	18	0.3	1	0.26	100.2	6.1767	1.3933
2014	9	14	20	12	18	0.3	1	0.24	95.5	6.1767	1.304
2014	9	14	20	22	18	0.3	1	0.27	75.3	6.1767	1.429
2014	9	14	20	32	18	0.3	1	0.29	93.9	6.1767	1.572
2014	9	14	20	42	18	0.3	1	0.28	92.7	6.1767	1.5184
2014	9	14	20	52	18	0.3	1	0.21	86.5	6.1767	1.1611
2014	9	14	21	2	18	0.3	1	0.24	91.6	6.1767	1.304
2014	9	14	21	12	18	0.3	1	0.23	100.7	6.1767	1.2326
2014	9	14	21	22	18	0.3	1	0.31	92.4	6.1767	1.697
2014	9	14	21	32	18	0.3	1	0.33	88.9	6.1767	1.8221
2014	9	14	21	42	18	0.3	1	0.27	103.4	6.1767	1.4291
2014	9	14	21	52	18	0.3	1	0.33	101	6.1767	1.7506
2014	9	14	22	2	18	0.3	1	0.28	98.8	6.1574	1.4955
2014	9	14	22	12	18	0.3	1	0.25	90	6.1767	1.3755
2014	9	14	22	22	18	0.3	1	0.29	85.4	6.1767	1.5541
2014	9	14	22	32	18	0.3	1	0.27	102	6.1767	1.4291
2014	9	14	22	42	18	0.3	1	0.29	95.8	6.1574	1.5667
2014	9	14	22	52	18	0.3	1	0.23	94.8	6.1574	1.264
2014	9	14	23	2	18	0.3	1	0.3	90	6.1574	1.6379
2014	9	14	23	12	18	0.3	1	0.25	95.9	6.1574	1.3709
2014	9	14	23	22	18	0.3	1	0.24	100.9	6.1767	1.304
2014	9	14	23	32	18	0.3	1	0.25	91.5	6.1767	1.3398
2014	9	14	23	42	18	0.3	1	0.27	86.6	6.1574	1.4777
2014	9	14	23	52	18	0.3	1	0.25	99	6.1574	1.3531
2014	9	15	0	2	18	0.3	1	0.23	97.2	6.1574	1.264
2014	9	15	0	12	18	0.3	1	0.28	103.4	6.1574	1.4955
2014	9	15	0	22	18	0.3	1	0.25	114.6	6.1767	1.2504
2014	9	15	0	32	18	0.3	1	0.31	79.5	6.1767	1.6434
2014	9	15	0	42	18	0.3	1	0.28	97.4	6.1767	1.5184
2014	9	15	0	52	18	0.3	1	0.25	99.1	6.1767	1.3398
2014	9	15	1	2	18	0.3	1	0.31	98.6	6.1574	1.6557
2014	9	15	1	12	18	0.3	1	0.38	90	6.1767	2.0722

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	1	22	18	0.3	1	0.31	93	6.1767	1.6792
2014	9	15	1	32	18	0.3	1	0.22	113.9	6.1767	1.0897
2014	9	15	1	42	18	0.3	1	0.27	90.7	6.1767	1.4648
2014	9	15	1	52	18	0.3	1	0.25	102	6.1574	1.3353
2014	9	15	2	2	18	0.3	1	0.35	80.4	6.1767	1.8936
2014	9	15	2	12	18	0.3	1	0.26	87.8	6.1767	1.4112
2014	9	15	2	22	18	0.3	1	0.19	83.2	6.1767	1.054
2014	9	15	2	32	18	0.3	1	0.25	93.8	6.1767	1.3576
2014	9	15	2	42	18	0.3	1	0.32	93	6.1767	1.7328
2014	9	15	2	52	18	0.3	1	0.28	93.3	6.1767	1.5363
2014	9	15	3	2	18	0.3	1	0.24	82.2	6.1767	1.3041
2014	9	15	3	12	18	0.3	1	0.26	103.7	6.1767	1.3934
2014	9	15	3	22	18	0.3	1	0.22	90	6.1767	1.179
2014	9	15	3	32	18	0.3	1	0.3	98.8	6.1767	1.6077
2014	9	15	3	42	18	0.3	1	0.25	89.2	6.1767	1.3398
2014	9	15	3	52	18	0.3	1	0.31	90	6.1767	1.6971
2014	9	15	4	2	18	0.3	1	0.26	95.8	6.1767	1.4113
2014	9	15	4	12	18	0.3	1	0.21	81	6.1767	1.1254
2014	9	15	4	22	18	0.3	1	0.27	94.9	6.1767	1.447
2014	9	15	4	32	18	0.3	1	0.27	92.8	6.1767	1.4827
2014	9	15	4	42	18	0.3	1	0.27	103.4	6.1767	1.4291
2014	9	15	4	52	18	0.3	1	0.24	94.8	6.1574	1.2819
2014	9	15	5	2	18	0.3	1	0.19	93.9	6.1574	1.0504
2014	9	15	5	12	18	0.3	1	0.3	88.1	6.1574	1.638
2014	9	15	5	22	18	0.3	1	0.28	88	6.1574	1.4955
2014	9	15	5	32	18	0.3	1	0.3	101.9	6.1574	1.6024
2014	9	15	5	42	18	0.3	1	0.25	100	6.1574	1.3175
2014	9	15	5	52	18	0.3	1	0.31	90	6.1574	1.7092
2014	9	15	6	2	18	0.3	1	0.25	87.8	6.1574	1.3709
2014	9	15	6	12	18	0.3	1	0.35	91.6	6.1574	1.8872
2014	9	15	6	22	18	0.3	1	0.27	104.9	6.1574	1.4065
2014	9	15	6	32	18	0.3	1	0.26	109.6	6.1574	1.3531
2014	9	15	6	42	18	0.3	1	0.27	99.8	6.1574	1.4421
2014	9	15	6	52	18	0.3	1	0.27	108.2	6.1574	1.4065
2014	9	15	7	2	18	0.3	1	0.24	91.5	6.1574	1.3175
2014	9	15	7	12	18	0.3	1	0.21	99.9	6.1574	1.1217
2014	9	15	7	22	18	0.3	1	0.32	95.9	6.1574	1.727
2014	9	15	7	32	18	0.3	1	0.29	92	6.1574	1.549
2014	9	15	7	42	18	0.3	1	0.25	90.8	6.1574	1.3353
2014	9	15	7	52	18	0.3	1	0.26	90	6.1574	1.4065
2014	9	15	8	2	18	0.3	1	0.3	91.9	6.1574	1.638
2014	9	15	8	12	18	0.3	1	0.27	97	6.1574	1.46
2014	9	15	8	22	18	0.3	1	0.15	99	6.1574	0.7834
2014	9	15	8	32	18	0.3	1	0.33	87.2	6.1574	1.7982
2014	9	15	8	42	18	0.3	1	0.28	84.6	6.1574	1.5134
2014	9	15	8	52	18	0.3	1	0.21	97.4	6.1574	1.1039

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	9	2	18	0.3	1	0.19	89	6.1574	1.0148
2014	9	15	9	12	18	0.3	1	0.28	89.3	6.1574	1.5134
2014	9	15	9	22	18	0.3	1	0.21	98.1	6.1574	1.1217
2014	9	15	9	32	18	0.3	1	0.28	83.2	6.1574	1.4955
2014	9	15	9	42	18	0.3	1	0.23	88.4	6.1574	1.2641
2014	9	15	9	52	18	0.3	1	0.31	90	6.1574	1.6914
2014	9	15	10	2	18	0.3	1	0.28	92.7	6.1574	1.5133
2014	9	15	10	12	18	0.3	1	0.22	90	6.1574	1.1929
2014	9	15	10	22	18	0.3	1	0.29	88	6.1574	1.5489
2014	9	15	10	32	18	0.3	1	0.3	104.5	6.1574	1.5846
2014	9	15	10	42	18	0.3	1	0.21	98	6.138	1.1356
2014	9	15	10	52	18	0.3	1	0.28	93.3	6.138	1.526
2014	9	15	11	2	18	0.3	1	0.22	96.8	6.138	1.1888
2014	9	15	11	12	18	0.3	1	0.28	82.7	6.138	1.526
2014	9	15	11	22	18	0.3	1	0.2	101.5	6.138	1.0469
2014	9	15	11	32	18	0.3	1	0.27	93.5	6.138	1.4372
2014	9	15	11	42	18	0.3	1	0.3	95.7	6.138	1.5969
2014	9	15	11	52	18	0.3	1	0.32	87.6	6.138	1.7211
2014	9	15	12	2	18	0.3	1	0.24	83.8	6.138	1.313
2014	9	15	12	12	18	0.3	1	0.24	98.7	6.138	1.2775
2014	9	15	12	22	18	0.3	1	0.3	87.5	6.138	1.6324
2014	9	15	12	32	18	0.3	1	0.26	83.6	6.138	1.4195
2014	9	15	12	42	18	0.3	1	0.27	88.6	6.138	1.4727
2014	9	15	12	52	18	0.3	1	0.28	71.6	6.138	1.4372
2014	9	15	13	2	18	0.3	1	0.29	79.6	6.1187	1.5384
2014	9	15	13	12	18	0.3	1	0.32	83.5	6.1187	1.6975
2014	9	15	13	22	18	0.3	1	0.3	85.6	6.1187	1.6268
2014	9	15	13	32	18	0.3	1	0.24	76	6.1187	1.2732
2014	9	15	13	42	18	0.3	1	0.31	86.9	6.1187	1.6445
2014	9	15	13	52	18	0.3	1	0.29	93.9	6.0993	1.5508
2014	9	15	14	2	18	0.3	1	0.3	77.3	6.0993	1.5684
2014	9	15	14	12	18	0.3	1	0.32	79.9	6.0993	1.6741
2014	9	15	14	22	18	0.3	1	0.27	77.5	6.0993	1.4274
2014	9	15	14	32	18	0.3	1	0.29	90	6.0993	1.5331
2014	9	15	14	42	18	0.3	1	0.31	84	6.08	1.6684
2014	9	15	14	52	18	0.3	1	0.29	72.4	6.08	1.4928
2014	9	15	15	2	18	0.3	1	0.32	67.7	6.0606	1.5752
2014	9	15	15	12	18	0.3	1	0.34	85.6	6.0412	1.7965
2014	9	15	15	22	18	0.3	1	0.31	89.4	6.0412	1.657
2014	9	15	15	32	18	0.3	1	0.26	68.3	6.0412	1.2732
2014	9	15	15	42	18	0.3	1	0.22	87.4	6.0219	1.1472
2014	9	15	15	52	18	0.3	1	0.34	83.3	6.0219	1.7729
2014	9	15	16	2	18	0.3	1	0.28	76	6.0219	1.4601
2014	9	15	16	12	18	0.3	1	0.32	78.8	6.0219	1.6686
2014	9	15	16	22	18	0.3	1	0.24	79	6.0219	1.2515
2014	9	15	16	32	18	0.3	1	0.29	81.4	6.0219	1.4948

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	16	42	18	0.3	1	0.31	75.2	6.0025	1.5763
2014	9	15	16	52	18	0.3	1	0.3	86.8	6.0025	1.5589
2014	9	15	17	2	18	0.3	1	0.3	65.7	6.0025	1.455
2014	9	15	17	12	18	0.3	1	0.27	73.6	6.0025	1.3511
2014	9	15	17	22	18	0.3	1	0.32	72.1	6.0025	1.6109
2014	9	15	17	32	18	0.3	1	0.24	89.2	6.0025	1.2645
2014	9	15	17	42	18	0.3	1	0.3	77.2	6.0025	1.5243
2014	9	15	17	52	18	0.3	1	0.26	82.8	6.0025	1.3684
2014	9	15	18	2	18	0.3	1	0.25	74.2	6.0025	1.2818
2014	9	15	18	12	18	0.3	1	0.28	107.6	6.0025	1.4204
2014	9	15	18	22	18	0.3	1	0.19	79.1	6.0025	0.9873
2014	9	15	18	32	18	0.3	1	0.27	94.1	6.0025	1.4377
2014	9	15	18	42	18	0.3	1	0.16	90	6.0025	0.8488
2014	9	15	18	52	18	0.3	1	0.25	90.8	6.0025	1.3164
2014	9	15	19	2	18	0.3	1	0.3	91.3	5.9832	1.5708
2014	9	15	19	12	18	0.3	1	0.26	87.1	6.0025	1.3684
2014	9	15	19	22	18	0.3	1	0.3	89.4	5.9832	1.5708
2014	9	15	19	32	18	0.3	1	0.23	90	5.9832	1.2083
2014	9	15	19	42	18	0.3	1	0.26	89.3	5.9832	1.3464
2014	9	15	19	52	18	0.3	1	0.22	90	5.9832	1.1738
2014	9	15	20	2	18	0.3	1	0.24	102.5	5.9832	1.2428
2014	9	15	20	12	18	0.3	1	0.28	91.3	5.9832	1.4672
2014	9	15	20	22	18	0.3	1	0.25	93.1	5.9832	1.2946
2014	9	15	20	32	18	0.3	1	0.21	95.3	5.9832	1.122
2014	9	15	20	42	18	0.3	1	0.16	93.5	5.9832	0.8458
2014	9	15	20	52	18	0.3	1	0.27	88.6	5.9832	1.4327
2014	9	15	21	2	18	0.3	1	0.24	97.1	5.9832	1.2429
2014	9	15	21	12	18	0.3	1	0.2	100.4	5.9832	1.0357
2014	9	15	21	22	18	0.3	1	0.29	98.6	5.9832	1.4845
2014	9	15	21	32	18	0.3	1	0.28	95.3	5.9832	1.4845
2014	9	15	21	42	18	0.3	1	0.25	110.1	5.9832	1.2256
2014	9	15	21	52	18	0.3	1	0.27	87.9	5.9832	1.4328
2014	9	15	22	2	18	0.3	1	0.17	90	5.9832	0.9149
2014	9	15	22	12	18	0.3	1	0.25	101.5	5.9832	1.2774
2014	9	15	22	22	18	0.3	1	0.27	97	5.9832	1.3982
2014	9	15	22	32	18	0.3	1	0.24	98.6	5.9832	1.2601
2014	9	15	22	42	18	0.3	1	0.22	85.7	5.9638	1.1525
2014	9	15	22	52	18	0.3	1	0.28	102.2	5.9832	1.4328
2014	9	15	23	2	18	0.3	1	0.29	99.9	5.9832	1.4846
2014	9	15	23	12	18	0.3	1	0.19	112.5	5.9832	0.9149
2014	9	15	23	22	18	0.3	1	0.21	94.5	5.9832	1.1048
2014	9	15	23	32	18	0.3	1	0.25	97.5	5.9832	1.3119
2014	9	15	23	42	18	0.3	1	0.27	99.1	5.9832	1.3983
2014	9	15	23	52	18	0.3	1	0.17	115.1	5.9832	0.8113
2014	9	16	0	2	18	0.3	1	0.2	84.3	5.9832	1.0357
2014	9	16	0	12	18	0.3	1	0.29	86.7	5.9832	1.5018

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	0	22	18	0.3	1	0.2	73.7	5.9832	1.0012
2014	9	16	0	32	18	0.3	1	0.27	99	5.9832	1.4155
2014	9	16	0	42	18	0.3	1	0.25	90	5.9832	1.2947
2014	9	16	0	52	18	0.3	1	0.25	94.6	5.9832	1.2947
2014	9	16	1	2	18	0.3	1	0.22	95.1	5.9832	1.1566
2014	9	16	1	12	18	0.3	1	0.25	78.1	5.9638	1.3074
2014	9	16	1	22	18	0.3	1	0.27	102.5	5.9638	1.3934
2014	9	16	1	32	18	0.3	1	0.22	89.1	5.9638	1.1526
2014	9	16	1	42	18	0.3	1	0.2	98.5	5.9638	1.0322
2014	9	16	1	52	18	0.3	1	0.18	84.8	5.9832	0.9494
2014	9	16	2	2	18	0.3	1	0.29	99.9	5.9638	1.4794
2014	9	16	2	12	18	0.3	1	0.18	77.5	5.9832	0.9322
2014	9	16	2	22	18	0.3	1	0.21	100.1	5.9832	1.0703
2014	9	16	2	32	18	0.3	1	0.19	78.9	5.9638	0.9633
2014	9	16	2	42	18	0.3	1	0.2	87.1	5.9638	1.0322
2014	9	16	2	52	18	0.3	1	0.23	115.8	5.9638	1.101
2014	9	16	3	2	18	0.3	1	0.22	99.3	5.9638	1.1526
2014	9	16	3	12	18	0.3	1	0.21	97.1	5.9638	1.101
2014	9	16	3	22	18	0.3	1	0.26	100.2	5.9638	1.3418
2014	9	16	3	32	18	0.3	1	0.19	96	5.9638	0.9806
2014	9	16	3	42	18	0.3	1	0.26	96.4	5.9638	1.3762
2014	9	16	3	52	18	0.3	1	0.18	104	5.9638	0.8945
2014	9	16	4	2	18	0.3	1	0.23	85.9	5.9638	1.187
2014	9	16	4	12	18	0.3	1	0.24	95.5	5.9638	1.2558
2014	9	16	4	22	18	0.3	1	0.25	96.8	5.9638	1.2902
2014	9	16	4	32	18	0.3	1	0.21	101.5	5.9638	1.101
2014	9	16	4	42	18	0.3	1	0.21	100.1	5.9638	1.0666
2014	9	16	4	52	18	0.3	1	0.24	100.2	5.9638	1.2386
2014	9	16	5	2	18	0.3	1	0.25	88.5	5.9638	1.3074
2014	9	16	5	12	18	0.3	1	0.24	103.7	5.9638	1.2042
2014	9	16	5	22	18	0.3	1	0.2	95.7	5.9638	1.0322
2014	9	16	5	32	18	0.3	1	0.32	59.4	5.9445	1.4229
2014	9	16	5	42	18	0.3	1	0.29	67.2	5.9445	1.3886
2014	9	16	5	52	18	0.3	1	0.34	61.7	5.9445	1.56
2014	9	16	6	2	18	0.3	1	0.32	61.6	5.9445	1.4914
2014	9	16	6	12	18	0.3	1	0.28	78.7	5.9445	1.4571
2014	9	16	6	22	18	0.3	1	0.3	60.3	5.9445	1.3543
2014	9	16	6	32	18	0.3	1	0.24	70.8	5.9445	1.1829
2014	9	16	6	42	18	0.3	1	0.27	78.8	5.9445	1.3886
2014	9	16	6	52	18	0.3	1	0.21	71.6	5.9445	1.0286
2014	9	16	7	2	18	0.3	1	0.27	86.6	5.9445	1.4229
2014	9	16	7	12	18	0.3	1	0.25	97.6	5.9445	1.2857
2014	9	16	7	22	18	0.3	1	0.26	92.9	5.9445	1.3714
2014	9	16	7	32	18	0.3	1	0.27	90	5.9445	1.4229
2014	9	16	7	42	18	0.3	1	0.22	81.4	5.9445	1.1314
2014	9	16	7	52	18	0.3	1	0.21	87.3	5.9445	1.0972

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	8	2	18	0.3	1	0.26	82.9	5.9445	1.3714
2014	9	16	8	12	18	0.3	1	0.21	85.5	5.9445	1.0972
2014	9	16	8	22	18	0.3	1	0.21	79.2	5.9445	1.08
2014	9	16	8	32	18	0.3	1	0.25	89.3	5.9445	1.32
2014	9	16	8	42	18	0.3	1	0.21	87.4	5.9445	1.1143
2014	9	16	8	52	18	0.3	1	0.28	69.4	5.9445	1.3714
2014	9	16	9	2	18	0.3	1	0.23	82.6	5.9445	1.1829
2014	9	16	9	12	18	0.3	1	0.22	104	5.9445	1.0972
2014	9	16	9	22	18	0.3	1	0.18	95.3	5.9445	0.9257
2014	9	16	9	32	18	0.3	1	0.24	80.4	5.9445	1.2171
2014	9	16	9	42	18	0.3	1	0.28	77.9	5.9445	1.44
2014	9	16	9	52	18	0.3	1	0.23	97.3	5.9445	1.2
2014	9	16	10	2	18	0.3	1	0.21	100.1	5.9445	1.0629
2014	9	16	10	12	18	0.3	1	0.27	100.4	5.9445	1.4057
2014	9	16	10	22	18	0.3	1	0.17	88.9	5.9445	0.8914
2014	9	16	10	32	18	0.3	1	0.29	90.7	5.9445	1.4914
2014	9	16	10	42	18	0.3	1	0.21	92.7	5.9445	1.0971
2014	9	16	10	52	18	0.3	1	0.23	70.5	5.9445	1.1143
2014	9	16	11	2	18	0.3	1	0.27	90	5.9445	1.3886
2014	9	16	11	12	18	0.3	1	0.27	93.5	5.9251	1.4008
2014	9	16	11	22	18	0.3	1	0.25	78.8	5.9251	1.2983
2014	9	16	11	32	18	0.3	1	0.28	81.8	5.9251	1.4178
2014	9	16	11	42	18	0.3	1	0.22	76	5.9251	1.0933
2014	9	16	11	52	18	0.3	1	0.25	80	5.9251	1.2641
2014	9	16	12	2	18	0.3	1	0.27	85.2	5.9251	1.4178
2014	9	16	12	12	18	0.3	1	0.23	83.4	5.9251	1.1787
2014	9	16	12	22	18	0.3	1	0.31	90.6	5.9251	1.6399
2014	9	16	12	32	18	0.3	1	0.26	95	5.9251	1.3666
2014	9	16	12	42	18	0.3	1	0.2	93.8	5.9251	1.042
2014	9	16	12	52	18	0.3	1	0.34	85.1	5.9251	1.7765
2014	9	16	13	2	18	0.3	1	0.2	90	5.9251	1.0591
2014	9	16	13	12	18	0.3	1	0.21	100.6	5.9251	1.0932
2014	9	16	13	22	18	0.3	1	0.26	87.1	5.9251	1.3665
2014	9	16	13	32	18	0.3	1	0.29	84.1	5.9251	1.4861
2014	9	16	13	42	18	0.3	1	0.29	86.8	5.9251	1.5203
2014	9	16	13	52	18	0.3	1	0.28	83.3	5.9251	1.4519
2014	9	16	14	2	18	0.3	1	0.21	76.4	5.9251	1.0591
2014	9	16	14	12	18	0.3	1	0.19	90	5.9251	0.9907
2014	9	16	14	22	18	0.3	1	0.23	71.8	5.9251	1.1445
2014	9	16	14	32	18	0.3	1	0.23	93.3	5.9057	1.1915
2014	9	16	14	42	18	0.3	1	0.25	84	5.9251	1.2982
2014	9	16	14	52	18	0.3	1	0.29	87.4	5.9057	1.5149
2014	9	16	15	2	18	0.3	1	0.27	85.1	5.9057	1.3957
2014	9	16	15	12	18	0.3	1	0.25	86.2	5.9057	1.2936
2014	9	16	15	22	18	0.3	1	0.23	80	5.9057	1.1574
2014	9	16	15	32	18	0.3	1	0.36	77.9	5.9057	1.8213

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	15	42	18	0.3	1	0.34	77.7	5.9057	1.7191
2014	9	16	15	52	18	0.3	1	0.25	75.8	5.9057	1.2766
2014	9	16	16	2	18	0.3	1	0.25	77.6	5.8864	1.2382
2014	9	16	16	12	18	0.3	1	0.26	90	5.9057	1.3447
2014	9	16	16	22	18	0.3	1	0.25	90	5.9057	1.2766
2014	9	16	16	32	18	0.3	1	0.26	83.6	5.8864	1.3569
2014	9	16	16	42	18	0.3	1	0.25	94.5	5.8864	1.289
2014	9	16	16	52	18	0.3	1	0.22	95	5.8864	1.1533
2014	9	16	17	2	18	0.3	1	0.3	89.4	5.8864	1.5604
2014	9	16	17	12	18	0.3	1	0.2	73.4	5.8864	0.9668
2014	9	16	17	22	18	0.3	1	0.17	92.2	5.8864	0.865
2014	9	16	17	32	18	0.3	1	0.23	63.8	5.8864	1.0685
2014	9	16	17	42	18	0.3	1	0.26	73	5.8864	1.2721
2014	9	16	17	52	18	0.3	1	0.22	86.6	5.8864	1.1364
2014	9	16	18	2	18	0.3	1	0.17	64.4	5.8864	0.8141
2014	9	16	18	12	18	0.3	1	0.22	93.4	5.8864	1.1533
2014	9	16	18	22	18	0.3	1	0.17	86.6	5.8864	0.865
2014	9	16	18	32	18	0.3	1	0.25	81.7	5.8864	1.2721
2014	9	16	18	42	18	0.3	1	0.24	100.4	5.8864	1.2042
2014	9	16	18	52	18	0.3	1	0.18	92.1	5.8864	0.9328
2014	9	16	19	2	18	0.3	1	0.24	90	5.8864	1.2381
2014	9	16	19	12	18	0.3	1	0.25	86.3	5.8864	1.306
2014	9	16	19	22	18	0.3	1	0.23	114.7	5.8864	1.0685
2014	9	16	19	32	18	0.3	1	0.21	90	5.8864	1.0855
2014	9	16	19	42	18	0.3	1	0.22	74.3	5.8864	1.0855
2014	9	16	19	52	18	0.3	1	0.21	89.1	5.8864	1.0855
2014	9	16	20	2	18	0.3	1	0.19	104.7	5.8864	0.9668
2014	9	16	20	12	18	0.3	1	0.22	85.8	5.9057	1.1574
2014	9	16	20	22	18	0.3	1	0.22	109.5	5.9057	1.0553
2014	9	16	20	32	18	0.3	1	0.28	108.9	5.9057	1.3957
2014	9	16	20	42	18	0.3	1	0.18	66.3	5.9057	0.8511
2014	9	16	20	52	18	0.3	1	0.24	78.1	5.9057	1.2085
2014	9	16	21	2	18	0.3	1	0.21	83.9	5.9057	1.1064
2014	9	16	21	12	18	0.3	1	0.25	95.3	5.9057	1.2766
2014	9	16	21	22	18	0.3	1	0.23	89.2	5.9057	1.1745
2014	9	16	21	32	18	0.3	1	0.29	103.6	5.9057	1.4809
2014	9	16	21	42	18	0.3	1	0.23	113.3	5.9057	1.1064
2014	9	16	21	52	18	0.3	1	0.23	77.4	5.9057	1.1404
2014	9	16	22	2	18	0.3	1	0.19	105	5.9057	0.9532
2014	9	16	22	12	18	0.3	1	0.22	90.9	5.9057	1.1234
2014	9	16	22	22	18	0.3	1	0.25	76.9	5.9057	1.2426
2014	9	16	22	32	18	0.3	1	0.2	74.2	5.9057	1.0213
2014	9	16	22	42	18	0.3	1	0.23	93.3	5.9057	1.1915
2014	9	16	22	52	18	0.3	1	0.22	94.3	5.9057	1.1405
2014	9	16	23	2	18	0.3	1	0.24	90	5.9057	1.2256
2014	9	16	23	12	18	0.3	1	0.27	106.4	5.9057	1.3277

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	23	22	18	0.3	1	0.18	102.3	5.9057	0.9362
2014	9	16	23	32	18	0.3	1	0.23	97.5	5.9057	1.1575
2014	9	16	23	42	18	0.3	1	0.26	104.7	5.9057	1.2937
2014	9	16	23	52	18	0.3	1	0.25	105.5	5.9057	1.2256
2014	9	17	0	2	18	0.3	1	0.29	97.2	5.9057	1.4809
2014	9	17	0	12	18	0.3	1	0.22	88.3	5.9057	1.1575
2014	9	17	0	22	18	0.3	1	0.21	110.1	5.9057	1.0213
2014	9	17	0	32	18	0.3	1	0.19	104	5.9057	0.9532
2014	9	17	0	42	18	0.3	1	0.21	85.5	5.9057	1.0894
2014	9	17	0	52	18	0.3	1	0.28	100.9	5.9057	1.4128
2014	9	17	1	2	18	0.3	1	0.24	98.8	5.9057	1.2086
2014	9	17	1	12	18	0.3	1	0.21	99.2	5.9057	1.0554
2014	9	17	1	22	18	0.3	1	0.2	102.4	5.9251	1.0078
2014	9	17	1	32	18	0.3	1	0.22	85.7	5.9057	1.1235
2014	9	17	1	42	18	0.3	1	0.29	99.7	5.9057	1.4979
2014	9	17	1	52	18	0.3	1	0.23	102.6	5.9251	1.1445
2014	9	17	2	2	18	0.3	1	0.23	90.8	5.9251	1.2128
2014	9	17	2	12	18	0.3	1	0.21	96.3	5.9251	1.0762
2014	9	17	2	22	18	0.3	1	0.2	85.2	5.9251	1.0249
2014	9	17	2	32	18	0.3	1	0.21	96.1	5.9251	1.1103
2014	9	17	2	42	18	0.3	1	0.22	81.5	5.9251	1.1445
2014	9	17	2	52	18	0.3	1	0.18	104.8	5.9251	0.9054
2014	9	17	3	2	18	0.3	1	0.27	89.3	5.9251	1.4007
2014	9	17	3	12	18	0.3	1	0.16	95.7	5.9251	0.8541
2014	9	17	3	22	18	0.3	1	0.19	98	5.9251	0.9737
2014	9	17	3	32	18	0.3	1	0.27	88.6	5.9251	1.4007
2014	9	17	3	42	18	0.3	1	0.24	106.7	5.9251	1.1958
2014	9	17	3	52	18	0.3	1	0.19	110.9	5.9251	0.9395
2014	9	17	4	2	18	0.3	1	0.27	83	5.9251	1.3837
2014	9	17	4	12	18	0.3	1	0.27	90	5.9251	1.3837
2014	9	17	4	22	18	0.3	1	0.27	94.8	5.9251	1.4178
2014	9	17	4	32	18	0.3	1	0.16	99.7	5.9251	0.8029
2014	9	17	4	42	18	0.3	1	0.31	99.8	5.9251	1.5887
2014	9	17	4	52	18	0.3	1	0.25	89.2	5.9251	1.2983
2014	9	17	5	2	18	0.3	1	0.24	94	5.9251	1.2299
2014	9	17	5	12	18	0.3	1	0.24	102.5	5.9251	1.2299
2014	9	17	5	22	18	0.3	1	0.24	84.5	5.9251	1.247
2014	9	17	5	32	18	0.3	1	0.28	88	5.9251	1.4691
2014	9	17	5	42	18	0.3	1	0.24	89.2	5.9251	1.2641
2014	9	17	5	52	18	0.3	1	0.22	90	5.9251	1.1274
2014	9	17	6	2	18	0.3	1	0.19	91	5.9251	0.9737
2014	9	17	6	12	18	0.3	1	0.21	95.3	5.9251	1.1104
2014	9	17	6	22	18	0.3	1	0.24	99.3	5.9251	1.247
2014	9	17	6	32	18	0.3	1	0.22	105.5	5.9251	1.1104
2014	9	17	6	42	18	0.3	1	0.21	102.5	5.9445	1.08
2014	9	17	6	52	18	0.3	1	0.22	100.5	5.9445	1.1143

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	7	2	18	0.3	1	0.27	103.4	5.9251	1.3666
2014	9	17	7	12	18	0.3	1	0.23	104.6	5.9445	1.1828
2014	9	17	7	22	18	0.3	1	0.24	99.6	5.9445	1.2171
2014	9	17	7	32	18	0.3	1	0.24	94.7	5.9445	1.2514
2014	9	17	7	42	18	0.3	1	0.18	80.4	5.9445	0.9086
2014	9	17	7	52	18	0.3	1	0.32	91.8	5.9445	1.68
2014	9	17	8	2	18	0.3	1	0.16	88.9	5.9251	0.8541
2014	9	17	8	12	18	0.3	1	0.31	86.3	5.9445	1.5943
2014	9	17	8	22	18	0.3	1	0.18	92	5.9445	0.96
2014	9	17	8	32	18	0.3	1	0.2	90	5.9445	1.0457
2014	9	17	8	42	18	0.3	1	0.23	95.6	5.9445	1.2171
2014	9	17	8	52	18	0.3	1	0.21	85.6	5.9445	1.1143
2014	9	17	9	2	18	0.3	1	0.2	93.8	5.9445	1.0286
2014	9	17	9	12	18	0.3	1	0.24	95.5	5.9445	1.2514
2014	9	17	9	22	18	0.3	1	0.21	118.6	5.9445	0.9428
2014	9	17	9	32	18	0.3	1	0.14	90	5.9445	0.7543
2014	9	17	9	42	18	0.3	1	0.22	95.2	5.9445	1.1314
2014	9	17	9	52	18	0.3	1	0.25	90	5.9445	1.2857
2014	9	17	10	2	18	0.3	1	0.26	89.3	5.9445	1.3542
2014	9	17	10	12	18	0.3	1	0.23	99.2	5.9445	1.1657
2014	9	17	10	22	18	0.3	1	0.19	84.2	5.9445	1.0114
2014	9	17	10	32	18	0.3	1	0.27	77.2	5.9445	1.3542
2014	9	17	10	42	18	0.3	1	0.24	94	5.9445	1.2342
2014	9	17	10	52	18	0.3	1	0.18	90	5.9445	0.9257
2014	9	17	11	2	18	0.3	1	0.22	80.4	5.9445	1.1142
2014	9	17	11	12	18	0.3	1	0.26	76.7	5.9445	1.3028
2014	9	17	11	22	18	0.3	1	0.16	98.3	5.9445	0.8228
2014	9	17	11	32	18	0.3	1	0.2	93.8	5.9445	1.0457
2014	9	17	11	42	18	0.3	1	0.27	75.8	5.9445	1.3542
2014	9	17	11	52	18	0.3	1	0.27	73.6	5.9445	1.3371
2014	9	17	12	2	18	0.3	1	0.24	87.7	5.9445	1.2685
2014	9	17	12	12	18	0.3	1	0.23	90.8	5.9445	1.2171
2014	9	17	12	22	18	0.3	1	0.16	91.2	5.9445	0.8399
2014	9	17	12	32	18	0.3	1	0.27	97.7	5.9445	1.3885
2014	9	17	12	42	18	0.3	1	0.24	88.4	5.9445	1.2342
2014	9	17	12	52	18	0.3	1	0.28	76	5.9445	1.4399
2014	9	17	13	2	18	0.3	1	0.25	84.8	5.9445	1.3199
2014	9	17	13	12	18	0.3	1	0.24	76	5.9445	1.2342
2014	9	17	13	22	18	0.3	1	0.26	78.3	5.9445	1.3199
2014	9	17	13	32	18	0.3	1	0.16	90	5.9445	0.8571
2014	9	17	13	42	18	0.3	1	0.22	94.3	5.9445	1.1313
2014	9	17	13	52	18	0.3	1	0.2	84.4	5.9445	1.0456
2014	9	17	14	2	18	0.3	1	0.32	87	5.9445	1.6627
2014	9	17	14	12	18	0.3	1	0.26	79.1	5.9251	1.3323
2014	9	17	14	22	18	0.3	1	0.29	90	5.9251	1.5202
2014	9	17	14	32	18	0.3	1	0.24	93.2	5.9251	1.2298

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	14	42	18	0.3	1	0.26	88.5	5.9251	1.3494
2014	9	17	14	52	18	0.3	1	0.22	86.6	5.9251	1.1615
2014	9	17	15	2	18	0.3	1	0.3	78.7	5.9251	1.5373
2014	9	17	15	12	18	0.3	1	0.24	83.1	5.9251	1.264
2014	9	17	15	22	18	0.3	1	0.28	75.6	5.9251	1.4006
2014	9	17	15	32	18	0.3	1	0.27	79.5	5.9251	1.3836
2014	9	17	15	42	18	0.3	1	0.25	85.5	5.9057	1.2936
2014	9	17	15	52	18	0.3	1	0.24	73.1	5.9057	1.1744
2014	9	17	16	2	18	0.3	1	0.23	99.7	5.9057	1.1915
2014	9	17	16	12	18	0.3	1	0.27	75.1	5.9057	1.3446
2014	9	17	16	22	18	0.3	1	0.26	82.1	5.9057	1.3446
2014	9	17	16	32	18	0.3	1	0.32	80.4	5.9057	1.617
2014	9	17	16	42	18	0.3	1	0.25	83.2	5.9057	1.2766
2014	9	17	16	52	18	0.3	1	0.32	83.5	5.9057	1.634
2014	9	17	17	2	18	0.3	1	0.22	72.1	5.9057	1.1063
2014	9	17	17	12	18	0.3	1	0.25	94.5	5.9057	1.3106
2014	9	17	17	22	18	0.3	1	0.25	90	5.9057	1.3106
2014	9	17	17	32	18	0.3	1	0.25	99.7	5.9057	1.2936
2014	9	17	17	42	18	0.3	1	0.25	78.1	5.9057	1.2936
2014	9	17	17	52	18	0.3	1	0.23	77.6	5.9057	1.1574
2014	9	17	18	2	18	0.3	1	0.3	68.2	5.9057	1.4468
2014	9	17	18	12	18	0.3	1	0.24	77.5	5.9057	1.2255
2014	9	17	18	22	18	0.3	1	0.31	83.3	5.9057	1.6
2014	9	17	18	32	18	0.3	1	0.25	77.8	5.9057	1.2595
2014	9	17	18	42	18	0.3	1	0.22	85.7	5.9057	1.1404
2014	9	17	18	52	18	0.3	1	0.2	66.3	5.9057	0.9702
2014	9	17	19	2	18	0.3	1	0.25	82.5	5.9057	1.2936
2014	9	17	19	12	18	0.3	1	0.23	86.7	5.9057	1.1915
2014	9	17	19	22	18	0.3	1	0.2	77.6	5.9057	1.0042
2014	9	17	19	32	18	0.3	1	0.22	95.1	5.9057	1.1404
2014	9	17	19	42	18	0.3	1	0.19	93	5.9057	0.9702
2014	9	17	19	52	18	0.3	1	0.22	90	5.9057	1.1574
2014	9	17	20	2	18	0.3	1	0.24	90	5.9057	1.2596
2014	9	17	20	12	18	0.3	1	0.15	87.5	5.9057	0.783
2014	9	17	20	22	18	0.3	1	0.26	89.3	5.9057	1.3276
2014	9	17	20	32	18	0.3	1	0.32	91.8	5.9057	1.651
2014	9	17	20	42	18	0.3	1	0.22	95.1	5.9057	1.1404
2014	9	17	20	52	18	0.3	1	0.23	96.4	5.9057	1.2085
2014	9	17	21	2	18	0.3	1	0.2	97.7	5.9057	1.0042
2014	9	17	21	12	18	0.3	1	0.16	110.7	5.9057	0.766
2014	9	17	21	22	18	0.3	1	0.23	108.2	5.9057	1.1404
2014	9	17	21	32	18	0.3	1	0.26	93.7	5.9057	1.3277
2014	9	17	21	42	18	0.3	1	0.17	108.4	5.9057	0.817
2014	9	17	21	52	18	0.3	1	0.25	94.5	5.9057	1.2936
2014	9	17	22	2	18	0.3	1	0.23	112.2	5.9057	1.1234
2014	9	17	22	12	18	0.3	1	0.2	90	5.9057	1.0383

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	22	22	18	0.3	1	0.22	101	5.9057	1.1404
2014	9	17	22	32	18	0.3	1	0.26	95.8	5.9057	1.3447
2014	9	17	22	42	18	0.3	1	0.16	97.3	5.9057	0.8
2014	9	17	22	52	18	0.3	1	0.29	94.6	5.9057	1.4809
2014	9	17	23	2	18	0.3	1	0.21	79.9	5.9057	1.0553
2014	9	17	23	12	18	0.3	1	0.22	120	5.9057	1.0043
2014	9	17	23	22	18	0.3	1	0.23	86	5.9251	1.2128
2014	9	17	23	32	18	0.3	1	0.24	86.1	5.9057	1.2426
2014	9	17	23	42	18	0.3	1	0.22	92.6	5.9057	1.1405
2014	9	17	23	52	18	0.3	1	0.24	89.2	5.9251	1.2641
2014	9	18	0	2	18	0.3	1	0.18	94.1	5.9251	0.9566
2014	9	18	0	12	18	0.3	1	0.21	76.2	5.9057	1.0383
2014	9	18	0	22	18	0.3	1	0.21	91.8	5.9057	1.0724
2014	9	18	0	32	18	0.3	1	0.24	86.1	5.9057	1.2426
2014	9	18	0	42	18	0.3	1	0.21	102.5	5.9251	1.0762
2014	9	18	0	52	18	0.3	1	0.26	105.6	5.9251	1.2811
2014	9	18	1	2	18	0.3	1	0.18	96.2	5.9251	0.9395
2014	9	18	1	12	18	0.3	1	0.2	95.7	5.9057	1.0213
2014	9	18	1	22	18	0.3	1	0.21	108.4	5.9057	1.0213
2014	9	18	1	32	18	0.3	1	0.26	81.3	5.9057	1.3277
2014	9	18	1	42	18	0.3	1	0.21	104.7	5.9057	1.0383
2014	9	18	1	52	18	0.3	1	0.22	95.2	5.9057	1.1235
2014	9	18	2	2	18	0.3	1	0.29	93.9	5.9057	1.4809
2014	9	18	2	12	18	0.3	1	0.26	96.6	5.9057	1.3277
2014	9	18	2	22	18	0.3	1	0.19	88	5.9057	0.9873
2014	9	18	2	32	18	0.3	1	0.23	86	5.9057	1.2086
2014	9	18	2	42	18	0.3	1	0.27	90	5.9057	1.4128
2014	9	18	2	52	18	0.3	1	0.24	101	5.9057	1.2256
2014	9	18	3	2	18	0.3	1	0.17	90	5.9057	0.9022
2014	9	18	3	12	18	0.3	1	0.2	87.2	5.9057	1.0554
2014	9	18	3	22	18	0.3	1	0.25	95.2	5.9057	1.3107
2014	9	18	3	32	18	0.3	1	0.28	100.7	5.9057	1.4469
2014	9	18	3	42	18	0.3	1	0.17	71.6	5.9057	0.8171
2014	9	18	3	52	18	0.3	1	0.18	90	5.9057	0.9362
2014	9	18	4	2	18	0.3	1	0.18	92	5.9057	0.9532
2014	9	18	4	12	18	0.3	1	0.25	87.8	5.9057	1.3107
2014	9	18	4	22	18	0.3	1	0.17	71.9	5.9057	0.8341
2014	9	18	4	32	18	0.3	1	0.25	84.8	5.9057	1.3107
2014	9	18	4	42	18	0.3	1	0.21	88.2	5.9057	1.1065
2014	9	18	4	52	18	0.3	1	0.3	84.4	5.9057	1.5661
2014	9	18	5	2	18	0.3	1	0.29	78.2	5.9057	1.4639
2014	9	18	5	12	18	0.3	1	0.2	76.4	5.9057	0.9873
2014	9	18	5	22	18	0.3	1	0.23	96.6	5.9057	1.1745
2014	9	18	5	32	18	0.3	1	0.15	83.5	5.9057	0.749
2014	9	18	5	42	18	0.3	1	0.28	72	5.9057	1.3618
2014	9	18	5	52	18	0.3	1	0.22	89.1	5.9057	1.1405

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	6	2	18	0.3	1	0.23	87.5	5.9057	1.1746
2014	9	18	6	12	18	0.3	1	0.28	94.7	5.9057	1.4469
2014	9	18	6	22	18	0.3	1	0.14	90	5.9057	0.732
2014	9	18	6	32	18	0.3	1	0.27	99.9	5.9057	1.3618
2014	9	18	6	42	18	0.3	1	0.18	94.1	5.9057	0.9533
2014	9	18	6	52	18	0.3	1	0.27	107.1	5.9057	1.3278
2014	9	18	7	2	18	0.3	1	0.25	103.5	5.9057	1.2767
2014	9	18	7	12	18	0.3	1	0.2	81.6	5.9057	1.0384
2014	9	18	7	22	18	0.3	1	0.19	90	5.9057	0.9873
2014	9	18	7	32	18	0.3	1	0.22	87.4	5.9057	1.1405
2014	9	18	7	42	18	0.3	1	0.25	90	5.9057	1.2767
2014	9	18	7	52	18	0.3	1	0.21	90	5.9057	1.0895
2014	9	18	8	2	18	0.3	1	0.21	98.1	5.9057	1.0724
2014	9	18	8	12	18	0.3	1	0.2	72.5	5.8864	0.9669
2014	9	18	8	22	18	0.3	1	0.16	84.3	5.8864	0.8481
2014	9	18	8	32	18	0.3	1	0.19	95	5.8864	0.9669
2014	9	18	8	42	18	0.3	1	0.16	91.1	5.8864	0.8481
2014	9	18	8	52	18	0.3	1	0.22	98.7	5.8864	1.1026
2014	9	18	9	2	18	0.3	1	0.29	103.1	5.8864	1.4588
2014	9	18	9	12	18	0.3	1	0.22	104	5.8864	1.0856
2014	9	18	9	22	18	0.3	1	0.24	86.1	5.8864	1.2552
2014	9	18	9	32	18	0.3	1	0.16	95.7	5.8864	0.8481
2014	9	18	9	42	18	0.3	1	0.2	92.8	5.8864	1.0517
2014	9	18	9	52	18	0.3	1	0.25	96.8	5.8864	1.2891
2014	9	18	10	2	18	0.3	1	0.23	61.6	5.8864	1.0686
2014	9	18	10	12	18	0.3	1	0.22	98.5	5.8864	1.1365
2014	9	18	10	22	18	0.3	1	0.2	104	5.8864	1.0177
2014	9	18	10	32	18	0.3	1	0.15	87.5	5.8864	0.7803
2014	9	18	10	42	18	0.3	1	0.21	90	5.8864	1.1026
2014	9	18	10	52	18	0.3	1	0.21	96.1	5.867	1.0987
2014	9	18	11	2	18	0.3	1	0.22	90	5.867	1.1156
2014	9	18	11	12	18	0.3	1	0.21	83	5.867	1.0987
2014	9	18	11	22	18	0.3	1	0.23	78.7	5.867	1.1832
2014	9	18	11	32	18	0.3	1	0.19	84	5.867	0.9634
2014	9	18	11	42	18	0.3	1	0.16	65.1	5.867	0.7268
2014	9	18	11	52	18	0.3	1	0.25	74	5.867	1.2339
2014	9	18	12	2	18	0.3	1	0.23	77.7	5.867	1.1662
2014	9	18	12	12	18	0.3	1	0.25	71.8	5.867	1.2339
2014	9	18	12	22	18	0.3	1	0.15	61.8	5.8477	0.6905
2014	9	18	12	32	18	0.3	1	0.27	79.5	5.8477	1.3642
2014	9	18	12	42	18	0.3	1	0.19	90	5.8477	0.9937
2014	9	18	12	52	18	0.3	1	0.27	62.8	5.8477	1.2126
2014	9	18	13	2	18	0.3	1	0.23	68.2	5.8283	1.0908
2014	9	18	13	12	18	0.3	1	0.25	59.7	5.8283	1.0908
2014	9	18	13	22	18	0.3	1	0.19	68.2	5.8283	0.923
2014	9	18	13	32	18	0.3	1	0.23	76	5.8283	1.1412

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	13	42	18	0.3	1	0.31	90	5.809	1.5551
2014	9	18	13	52	18	0.3	1	0.18	73.5	5.809	0.903
2014	9	18	14	2	18	0.3	1	0.2	90	5.7896	1.0164
2014	9	18	14	12	18	0.3	1	0.19	77.9	5.7896	0.9331
2014	9	18	14	22	18	0.3	1	0.21	74.7	5.7896	1.033
2014	9	18	14	32	18	0.3	1	0.23	88.4	5.7702	1.1621
2014	9	18	14	42	18	0.3	1	0.18	72.6	5.7702	0.8467
2014	9	18	14	52	18	0.3	1	0.2	98.5	5.7702	0.9961
2014	9	18	15	2	18	0.3	1	0.25	70.6	5.7702	1.1787
2014	9	18	15	12	18	0.3	1	0.19	77.2	5.7702	0.9463
2014	9	18	15	22	18	0.3	1	0.24	79	5.7702	1.1953
2014	9	18	15	32	18	0.3	1	0.19	80	5.7702	0.9463
2014	9	18	15	42	18	0.3	1	0.23	81.8	5.7509	1.1414
2014	9	18	15	52	18	0.3	1	0.17	78.9	5.7702	0.8467
2014	9	18	16	2	18	0.3	1	0.23	75.2	5.7509	1.1248
2014	9	18	16	12	18	0.3	1	0.24	82.2	5.7509	1.2075
2014	9	18	16	22	18	0.3	1	0.23	88.4	5.7509	1.1579
2014	9	18	16	32	18	0.3	1	0.19	85.1	5.7509	0.9594
2014	9	18	16	42	18	0.3	1	0.28	105.2	5.7509	1.3398
2014	9	18	16	52	18	0.3	1	0.14	91.3	5.7509	0.7278
2014	9	18	17	2	18	0.3	1	0.22	90	5.7509	1.1248
2014	9	18	17	12	18	0.3	1	0.25	75.6	5.7509	1.2241
2014	9	18	17	22	18	0.3	1	0.19	63.9	5.7509	0.8436
2014	9	18	17	32	18	0.3	1	0.2	79.4	5.7509	0.9759
2014	9	18	17	42	18	0.3	1	0.18	82.7	5.7509	0.9098
2014	9	18	17	52	18	0.3	1	0.23	80.9	5.7509	1.1413
2014	9	18	18	2	18	0.3	1	0.23	90.8	5.7509	1.1414
2014	9	18	18	12	18	0.3	1	0.19	83	5.7509	0.9429
2014	9	18	18	22	18	0.3	1	0.27	94.9	5.7509	1.3564
2014	9	18	18	32	18	0.3	1	0.18	69	5.7509	0.8601
2014	9	18	18	42	18	0.3	1	0.17	96.8	5.7509	0.8271
2014	9	18	18	52	18	0.3	1	0.18	101.7	5.7315	0.8735
2014	9	18	19	2	18	0.3	1	0.22	91.7	5.7315	1.1043
2014	9	18	19	12	18	0.3	1	0.18	99.6	5.7315	0.8735
2014	9	18	19	22	18	0.3	1	0.17	91.1	5.7315	0.8406
2014	9	18	19	32	18	0.3	1	0.2	95.6	5.7315	1.0054
2014	9	18	19	42	18	0.3	1	0.15	101.1	5.7315	0.7582
2014	9	18	19	52	18	0.3	1	0.14	105	5.7315	0.6757
2014	9	18	20	2	18	0.3	1	0.23	94.1	5.7315	1.1372
2014	9	18	20	12	18	0.3	1	0.22	87.4	5.7315	1.0878
2014	9	18	20	22	18	0.3	1	0.2	102.4	5.7315	0.9724
2014	9	18	20	32	18	0.3	1	0.17	101.9	5.7315	0.857
2014	9	18	20	42	18	0.3	1	0.2	88.2	5.7315	1.0219
2014	9	18	20	52	18	0.3	1	0.17	103.2	5.7315	0.8406
2014	9	18	21	2	18	0.3	1	0.22	105.7	5.7315	1.0548
2014	9	18	21	12	18	0.3	1	0.21	112.5	5.7315	0.9559

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	21	22	18	0.3	1	0.22	95.9	5.7315	1.1208
2014	9	18	21	32	18	0.3	1	0.23	106.4	5.7315	1.1208
2014	9	18	21	42	18	0.3	1	0.15	114.9	5.7315	0.6758
2014	9	18	21	52	18	0.3	1	0.22	103.2	5.7315	1.0548
2014	9	18	22	2	18	0.3	1	0.14	42.1	5.7315	0.4615
2014	9	18	22	12	18	0.3	1	0.18	79.5	5.7315	0.89
2014	9	18	22	22	18	0.3	1	0.19	106.9	5.7315	0.923
2014	9	18	22	32	18	0.3	1	0.2	102.4	5.7315	0.9725
2014	9	18	22	42	18	0.3	1	0.2	71.9	5.7315	0.956
2014	9	18	22	52	18	0.3	1	0.2	89.1	5.7315	1.0219
2014	9	18	23	2	18	0.3	1	0.15	90	5.7315	0.7582
2014	9	18	23	12	18	0.3	1	0.23	85.9	5.7315	1.1538
2014	9	18	23	22	18	0.3	1	0.14	83.2	5.7122	0.6897
2014	9	18	23	32	18	0.3	1	0.16	69.7	5.7122	0.7554
2014	9	18	23	42	18	0.3	1	0.19	93.9	5.7122	0.9525
2014	9	18	23	52	18	0.3	1	0.15	95	5.7122	0.7554
2014	9	19	0	2	18	0.3	1	0.22	79.5	5.7315	1.0714
2014	9	19	0	12	18	0.3	1	0.19	78.3	5.7315	0.956
2014	9	19	0	22	18	0.3	1	0.22	95.9	5.7122	1.1168
2014	9	19	0	32	18	0.3	1	0.18	94.1	5.7122	0.9197
2014	9	19	0	42	18	0.3	1	0.14	81.9	5.7122	0.6898
2014	9	19	0	52	18	0.3	1	0.19	83.1	5.7122	0.9525
2014	9	19	1	2	18	0.3	1	0.24	98.8	5.7122	1.166
2014	9	19	1	12	18	0.3	1	0.14	102.4	5.7122	0.6733
2014	9	19	1	22	18	0.3	1	0.16	78	5.7315	0.7747
2014	9	19	1	32	18	0.3	1	0.18	83.7	5.7122	0.8868
2014	9	19	1	42	18	0.3	1	0.19	85	5.7122	0.9361
2014	9	19	1	52	18	0.3	1	0.22	112	5.7315	1.0219
2014	9	19	2	2	18	0.3	1	0.14	94	5.7315	0.7088
2014	9	19	2	12	18	0.3	1	0.16	92.4	5.7315	0.7912
2014	9	19	2	22	18	0.3	1	0.19	89	5.7122	0.9361
2014	9	19	2	32	18	0.3	1	0.16	93.4	5.7122	0.8212
2014	9	19	2	42	18	0.3	1	0.14	68.2	5.7315	0.6593
2014	9	19	2	52	18	0.3	1	0.22	83.2	5.7315	1.1044
2014	9	19	3	2	18	0.3	1	0.18	104.8	5.7122	0.8704
2014	9	19	3	12	18	0.3	1	0.17	92.2	5.7122	0.8376
2014	9	19	3	22	18	0.3	1	0.14	74.6	5.7122	0.6569
2014	9	19	3	32	18	0.3	1	0.15	69.6	5.7122	0.7062
2014	9	19	3	42	18	0.3	1	0.21	73.3	5.7122	0.9854
2014	9	19	3	52	18	0.3	1	0.23	89.2	5.7122	1.1496
2014	9	19	4	2	18	0.3	1	0.19	95	5.7122	0.9361
2014	9	19	4	12	18	0.3	1	0.18	102.5	5.7122	0.8869
2014	9	19	4	22	18	0.3	1	0.19	90	5.7122	0.9361
2014	9	19	4	32	18	0.3	1	0.2	90	5.7122	1.0018
2014	9	19	4	42	18	0.3	1	0.2	92.8	5.7122	1.0183
2014	9	19	4	52	18	0.3	1	0.1	95.7	5.7122	0.4927

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	5	2	18	0.3	1	0.16	78.2	5.7122	0.7883
2014	9	19	5	12	18	0.3	1	0.23	86.8	5.7122	1.1661
2014	9	19	5	22	18	0.3	1	0.22	101.3	5.7122	1.0675
2014	9	19	5	32	18	0.3	1	0.2	87.2	5.7122	1.0183
2014	9	19	5	42	18	0.3	1	0.19	85	5.7122	0.9361
2014	9	19	5	52	18	0.3	1	0.17	113.2	5.7122	0.8048
2014	9	19	6	2	18	0.3	1	0.16	90	5.7122	0.7883
2014	9	19	6	12	18	0.3	1	0.19	118.4	5.7122	0.8212
2014	9	19	6	22	18	0.3	1	0.16	86.4	5.7122	0.7883
2014	9	19	6	32	18	0.3	1	0.22	95.1	5.7122	1.1004
2014	9	19	6	42	18	0.3	1	0.14	71.1	5.7122	0.6734
2014	9	19	6	52	18	0.3	1	0.13	90	5.7122	0.6405
2014	9	19	7	2	18	0.3	1	0.16	79.4	5.7122	0.7883
2014	9	19	7	12	18	0.3	1	0.13	97.1	5.7122	0.6569
2014	9	19	7	22	18	0.3	1	0.2	98.4	5.7122	1.0018
2014	9	19	7	32	18	0.3	1	0.13	90	5.7122	0.6405
2014	9	19	7	42	18	0.3	1	0.19	92	5.7122	0.9526
2014	9	19	7	52	18	0.3	1	0.16	88.8	5.7122	0.7883
2014	9	19	8	2	18	0.3	1	0.21	97.2	5.7122	1.0347
2014	9	19	8	12	18	0.3	1	0.16	92.3	5.7122	0.8048
2014	9	19	8	22	18	0.3	1	0.17	101.3	5.7122	0.8212
2014	9	19	8	32	18	0.3	1	0.21	85.5	5.7122	1.0347
2014	9	19	8	42	18	0.3	1	0.16	95.9	5.7122	0.7883
2014	9	19	8	52	18	0.3	1	0.14	74.6	5.7122	0.6569
2014	9	19	9	2	18	0.3	1	0.2	89.1	5.6928	1.0146
2014	9	19	9	12	18	0.3	1	0.2	82.4	5.6928	0.9818
2014	9	19	9	22	18	0.3	1	0.15	78.9	5.6928	0.7527
2014	9	19	9	32	18	0.3	1	0.16	90	5.6928	0.8182
2014	9	19	9	42	18	0.3	1	0.15	66.8	5.6928	0.6873
2014	9	19	9	52	18	0.3	1	0.19	122	5.6928	0.7855
2014	9	19	10	2	18	0.3	1	0.15	68.9	5.6928	0.72
2014	9	19	10	12	18	0.3	1	0.14	45	5.6928	0.5073
2014	9	19	10	22	18	0.3	1	0.24	69.6	5.6928	1.1455
2014	9	19	10	32	18	0.3	1	0.19	89	5.6928	0.9655
2014	9	19	10	42	18	0.3	1	0.21	88.2	5.6928	1.0309
2014	9	19	10	52	18	0.3	1	0.14	68.7	5.6928	0.6709
2014	9	19	11	2	18	0.3	1	0.18	72.6	5.6928	0.8345
2014	9	19	11	12	18	0.3	1	0.18	79.3	5.6928	0.8673
2014	9	19	11	22	18	0.3	1	0.21	98	5.6928	1.0473
2014	9	19	11	32	18	0.3	1	0.21	73.3	5.7122	0.9854
2014	9	19	11	42	18	0.3	1	0.19	85	5.7122	0.9361
2014	9	19	11	52	18	0.3	1	0.22	65	5.7122	0.9854
2014	9	19	12	2	18	0.3	1	0.2	75.1	5.7122	0.9854
2014	9	19	12	12	18	0.3	1	0.2	84.3	5.7122	0.9854
2014	9	19	12	22	18	0.3	1	0.26	69.5	5.7122	1.2317
2014	9	19	12	32	18	0.3	1	0.19	65.6	5.7315	0.8736

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	12	42	18	0.3	1	0.2	88.1	5.7315	0.989
2014	9	19	12	52	18	0.3	1	0.22	73.5	5.7315	1.0549
2014	9	19	13	2	18	0.3	1	0.17	77.6	5.7509	0.8271
2014	9	19	13	12	18	0.3	1	0.24	77.1	5.7509	1.158
2014	9	19	13	22	18	0.3	1	0.2	90	5.7702	0.9961
2014	9	19	13	32	18	0.3	1	0.23	76.6	5.7702	1.1124
2014	9	19	13	42	18	0.3	1	0.22	54.2	5.7702	0.8965
2014	9	19	13	52	18	0.3	1	0.16	88.9	5.7896	0.8331
2014	9	19	14	2	18	0.3	1	0.17	79.8	5.8283	0.8391
2014	9	19	14	12	18	0.3	1	0.22	85.7	5.8283	1.1076
2014	9	19	14	22	18	0.3	1	0.21	78.5	5.8283	1.074
2014	9	19	14	32	18	0.3	1	0.26	77.6	5.8477	1.2968
2014	9	19	14	42	18	0.3	1	0.22	55.8	5.867	0.9465
2014	9	19	14	52	18	0.3	1	0.25	65.4	5.8477	1.1789
2014	9	19	15	2	18	0.3	1	0.17	63.9	5.867	0.7944
2014	9	19	15	12	18	0.3	1	0.28	75.3	5.867	1.4197
2014	9	19	15	22	18	0.3	1	0.27	85.8	5.8864	1.3739
2014	9	19	15	32	18	0.3	1	0.19	88	5.867	0.9803
2014	9	19	15	42	18	0.3	1	0.24	82.3	5.8864	1.2552
2014	9	19	15	52	18	0.3	1	0.25	68.1	5.8864	1.2212
2014	9	19	16	2	18	0.3	1	0.21	81.1	5.8864	1.0855
2014	9	19	16	12	18	0.3	1	0.24	80.5	5.8864	1.2212
2014	9	19	16	22	18	0.3	1	0.19	70.9	5.8864	0.9329
2014	9	19	16	32	18	0.3	1	0.23	76.6	5.8864	1.1364
2014	9	19	16	42	18	0.3	1	0.29	71.2	5.9057	1.4468
2014	9	19	16	52	18	0.3	1	0.28	86.6	5.9057	1.4468
2014	9	19	17	2	18	0.3	1	0.27	83.1	5.9057	1.4128
2014	9	19	17	12	18	0.3	1	0.26	70	5.9057	1.2596
2014	9	19	17	22	18	0.3	1	0.17	81.1	5.9251	0.8711
2014	9	19	17	32	18	0.3	1	0.25	77.6	5.9251	1.2469
2014	9	19	17	42	18	0.3	1	0.26	73.2	5.9251	1.2982
2014	9	19	17	52	18	0.3	1	0.22	83.3	5.9251	1.1615
2014	9	19	18	2	18	0.3	1	0.24	74.8	5.9251	1.1957
2014	9	19	18	12	18	0.3	1	0.23	64.9	5.9251	1.0932
2014	9	19	18	22	18	0.3	1	0.23	60.2	5.9445	1.0456
2014	9	19	18	32	18	0.3	1	0.26	83.6	5.9445	1.3713
2014	9	19	18	42	18	0.3	1	0.25	78.1	5.9445	1.3027
2014	9	19	18	52	18	0.3	1	0.24	90.8	5.9445	1.2685
2014	9	19	19	2	18	0.3	1	0.21	98.1	5.9445	1.0799
2014	9	19	19	12	18	0.3	1	0.28	88.6	5.9445	1.4399
2014	9	19	19	22	18	0.3	1	0.19	94.8	5.9445	1.0113
2014	9	19	19	32	18	0.3	1	0.24	98.7	5.9445	1.2342
2014	9	19	19	42	18	0.3	1	0.25	99.2	5.9445	1.2685
2014	9	19	19	52	18	0.3	1	0.23	103.4	5.9445	1.1485
2014	9	19	20	2	18	0.3	1	0.22	96.9	5.9445	1.1313
2014	9	19	20	12	18	0.3	1	0.23	106.6	5.9445	1.1485

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	20	22	18	0.3	1	0.24	86.1	5.9445	1.2513
2014	9	19	20	32	18	0.3	1	0.22	85.7	5.9445	1.1314
2014	9	19	20	42	18	0.3	1	0.22	117.3	5.9445	1.0285
2014	9	19	20	52	18	0.3	1	0.24	94.6	5.9445	1.2685
2014	9	19	21	2	18	0.3	1	0.25	89.2	5.9445	1.3028
2014	9	19	21	12	18	0.3	1	0.17	98.7	5.9445	0.8914
2014	9	19	21	22	18	0.3	1	0.24	79.6	5.9445	1.2171
2014	9	19	21	32	18	0.3	1	0.25	97.5	5.9445	1.3028
2014	9	19	21	42	18	0.3	1	0.27	87.9	5.9445	1.3885
2014	9	19	21	52	18	0.3	1	0.24	86.9	5.9445	1.2514
2014	9	19	22	2	18	0.3	1	0.21	97.4	5.9445	1.0628
2014	9	19	22	12	18	0.3	1	0.24	81.3	5.9638	1.2386
2014	9	19	22	22	18	0.3	1	0.29	93.9	5.9638	1.531
2014	9	19	22	32	18	0.3	1	0.26	77.6	5.9638	1.3246
2014	9	19	22	42	18	0.3	1	0.29	89.3	5.9638	1.5138
2014	9	19	22	52	18	0.3	1	0.29	93.9	5.9638	1.5138
2014	9	19	23	2	18	0.3	1	0.23	82.5	5.9638	1.1698
2014	9	19	23	12	18	0.3	1	0.24	103.7	5.9638	1.2042
2014	9	19	23	22	18	0.3	1	0.23	90	5.9445	1.2171
2014	9	19	23	32	18	0.3	1	0.17	87.8	5.9445	0.8743
2014	9	19	23	42	18	0.3	1	0.3	101.9	5.9638	1.5482
2014	9	19	23	52	18	0.3	1	0.25	87	5.9638	1.3074
2014	9	20	0	2	18	0.3	1	0.23	104.6	5.9638	1.187
2014	9	20	0	12	18	0.3	1	0.22	97.8	5.9638	1.1354
2014	9	20	0	22	18	0.3	1	0.22	100.5	5.9638	1.1182
2014	9	20	0	32	18	0.3	1	0.25	86.3	5.9445	1.32
2014	9	20	0	42	18	0.3	1	0.27	103.2	5.9638	1.3934
2014	9	20	0	52	18	0.3	1	0.25	98.3	5.9445	1.2857
2014	9	20	1	2	18	0.3	1	0.29	107.4	5.9445	1.4229
2014	9	20	1	12	18	0.3	1	0.31	93.1	5.9445	1.5943
2014	9	20	1	22	18	0.3	1	0.25	100	5.9638	1.273
2014	9	20	1	32	18	0.3	1	0.25	83.2	5.9445	1.3029
2014	9	20	1	42	18	0.3	1	0.19	105.9	5.9445	0.96
2014	9	20	1	52	18	0.3	1	0.2	85.3	5.9445	1.0457
2014	9	20	2	2	18	0.3	1	0.32	99.6	5.9445	1.6286
2014	9	20	2	12	18	0.3	1	0.22	103	5.9445	1.1143
2014	9	20	2	22	18	0.3	1	0.24	87.6	5.9445	1.2343
2014	9	20	2	32	18	0.3	1	0.26	109.1	5.9445	1.2857
2014	9	20	2	42	18	0.3	1	0.26	82.8	5.9445	1.3543
2014	9	20	2	52	18	0.3	1	0.21	88.2	5.9445	1.0972
2014	9	20	3	2	18	0.3	1	0.24	75	5.9445	1.2172
2014	9	20	3	12	18	0.3	1	0.18	90	5.9445	0.9257
2014	9	20	3	22	18	0.3	1	0.23	94.9	5.9445	1.2
2014	9	20	3	32	18	0.3	1	0.26	95	5.9638	1.3763
2014	9	20	3	42	18	0.3	1	0.23	103.8	5.9445	1.1829
2014	9	20	3	52	18	0.3	1	0.26	95.1	5.9445	1.3372

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	4	2	18	0.3	1	0.22	78.7	5.9638	1.1182
2014	9	20	4	12	18	0.3	1	0.19	130.7	5.9445	0.7372
2014	9	20	4	22	18	0.3	1	0.26	101	5.9638	1.3247
2014	9	20	4	32	18	0.3	1	0.21	99	5.9445	1.08
2014	9	20	4	42	18	0.3	1	0.2	87.1	5.9638	1.0322
2014	9	20	4	52	18	0.3	1	0.26	102.6	5.9638	1.3075
2014	9	20	5	2	18	0.3	1	0.19	95.9	5.9638	0.9978
2014	9	20	5	12	18	0.3	1	0.24	103.5	5.9638	1.2214
2014	9	20	5	22	18	0.3	1	0.21	117.8	5.9638	0.9806
2014	9	20	5	32	18	0.3	1	0.24	90	5.9638	1.2731
2014	9	20	5	42	18	0.3	1	0.24	115.2	5.9638	1.1354
2014	9	20	5	52	18	0.3	1	0.23	86.7	5.9638	1.187
2014	9	20	6	2	18	0.3	1	0.22	108.4	5.9638	1.0838
2014	9	20	6	12	18	0.3	1	0.22	90	5.9638	1.1354
2014	9	20	6	22	18	0.3	1	0.25	98.5	5.9638	1.2731
2014	9	20	6	32	18	0.3	1	0.26	97.1	5.9638	1.3763
2014	9	20	6	42	18	0.3	1	0.19	95.9	5.9638	0.9978
2014	9	20	6	52	18	0.3	1	0.22	107.6	5.9638	1.0838
2014	9	20	7	2	18	0.3	1	0.19	85	5.9638	0.9806
2014	9	20	7	12	18	0.3	1	0.24	92.4	5.9638	1.2559
2014	9	20	7	22	18	0.3	1	0.18	110.1	5.9638	0.8946
2014	9	20	7	32	18	0.3	1	0.18	94.2	5.9638	0.929
2014	9	20	7	42	18	0.3	1	0.22	99.6	5.9638	1.1182
2014	9	20	7	52	18	0.3	1	0.17	93.2	5.9638	0.9118
2014	9	20	8	2	18	0.3	1	0.2	110.6	5.9832	0.9668
2014	9	20	8	12	18	0.3	1	0.21	124.4	5.9832	0.9322
2014	9	20	8	22	18	0.3	1	0.21	94.4	5.9832	1.1221
2014	9	20	8	32	18	0.3	1	0.23	95.8	5.9832	1.1912
2014	9	20	8	42	18	0.3	1	0.21	90	5.9832	1.1221
2014	9	20	8	52	18	0.3	1	0.24	86.1	5.9832	1.2775
2014	9	20	9	2	18	0.3	1	0.18	71.6	5.9832	0.8805
2014	9	20	9	12	18	0.3	1	0.21	103.4	5.9832	1.0876
2014	9	20	9	22	18	0.3	1	0.23	107.4	5.9832	1.1567
2014	9	20	9	32	18	0.3	1	0.21	90	5.9832	1.1049
2014	9	20	9	42	18	0.3	1	0.26	97.9	5.9832	1.3638
2014	9	20	9	52	18	0.3	1	0.21	90	5.9832	1.1221
2014	9	20	10	2	18	0.3	1	0.27	99	5.9832	1.4156
2014	9	20	10	12	18	0.3	1	0.17	87.8	5.9832	0.915
2014	9	20	10	22	18	0.3	1	0.16	90	5.9832	0.8459
2014	9	20	10	32	18	0.3	1	0.23	77.6	5.9832	1.1739
2014	9	20	10	42	18	0.3	1	0.23	90	5.9638	1.2214
2014	9	20	10	52	18	0.3	1	0.25	80	5.9638	1.2731
2014	9	20	11	2	18	0.3	1	0.24	70.6	5.9638	1.1698
2014	9	20	11	12	18	0.3	1	0.2	90	5.9638	1.0494
2014	9	20	11	22	18	0.3	1	0.24	85.4	5.9638	1.273
2014	9	20	11	32	18	0.3	1	0.21	78.5	5.9638	1.101

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	11	42	18	0.3	1	0.24	83.7	5.9638	1.2386
2014	9	20	11	52	18	0.3	1	0.29	96.4	5.9638	1.5311
2014	9	20	12	2	18	0.3	1	0.24	83	5.9638	1.2558
2014	9	20	12	12	18	0.3	1	0.29	78.8	5.9638	1.4794
2014	9	20	12	22	18	0.3	1	0.23	79.5	5.9638	1.2042
2014	9	20	12	32	18	0.3	1	0.24	88.4	5.9638	1.2558
2014	9	20	12	42	18	0.3	1	0.27	67.5	5.9638	1.2902
2014	9	20	12	52	18	0.3	1	0.26	87.1	5.9638	1.3418
2014	9	20	13	2	18	0.3	1	0.26	89.3	5.9638	1.359
2014	9	20	13	12	18	0.3	1	0.33	78.6	5.9638	1.703
2014	9	20	13	22	18	0.3	1	0.23	69	5.9638	1.1182
2014	9	20	13	32	18	0.3	1	0.27	69.8	5.9638	1.3074
2014	9	20	13	42	18	0.3	1	0.27	77.5	5.9638	1.3934
2014	9	20	13	52	18	0.3	1	0.29	80.1	5.9638	1.4794
2014	9	20	14	2	18	0.3	1	0.31	62.6	5.9638	1.4278
2014	9	20	14	12	18	0.3	1	0.28	71.8	5.9445	1.4057
2014	9	20	14	22	18	0.3	1	0.27	61.2	5.9445	1.2171
2014	9	20	14	32	18	0.3	1	0.24	72.8	5.9445	1.2171
2014	9	20	14	42	18	0.3	1	0.31	76.7	5.9445	1.5942
2014	9	20	14	52	18	0.3	1	0.26	71.8	5.9445	1.3028
2014	9	20	15	2	18	0.3	1	0.26	75.3	5.9445	1.3028
2014	9	20	15	12	18	0.3	1	0.26	67.4	5.9445	1.2342
2014	9	20	15	22	18	0.3	1	0.23	78.4	5.9445	1.1657
2014	9	20	15	32	18	0.3	1	0.23	68.2	5.9445	1.1142
2014	9	20	15	42	18	0.3	1	0.27	83.1	5.9445	1.4228
2014	9	20	15	52	18	0.3	1	0.26	70	5.9445	1.2685
2014	9	20	16	2	18	0.3	1	0.22	76.2	5.9638	1.1181
2014	9	20	16	12	18	0.3	1	0.28	74.1	5.9445	1.3885
2014	9	20	16	22	18	0.3	1	0.32	61.6	5.9638	1.4621
2014	9	20	16	32	18	0.3	1	0.35	62	5.9638	1.617
2014	9	20	16	42	18	0.3	1	0.34	61.4	5.9638	1.5482
2014	9	20	16	52	18	0.3	1	0.31	51.5	5.9638	1.2557
2014	9	20	17	2	18	0.3	1	0.36	52.4	5.9638	1.4966
2014	9	20	17	12	18	0.3	1	0.32	46.6	5.9638	1.2385
2014	9	20	17	22	18	0.3	1	0.29	54.7	5.9638	1.2385
2014	9	20	17	32	18	0.3	1	0.39	49.1	5.9638	1.5482
2014	9	20	17	42	18	0.3	1	0.35	63.9	5.9638	1.6514
2014	9	20	17	52	18	0.3	1	0.3	61.5	5.9638	1.3933
2014	9	20	18	2	18	0.3	1	0.27	59.6	5.9638	1.2041
2014	9	20	18	12	18	0.3	1	0.23	74.4	5.9638	1.1697
2014	9	20	18	22	18	0.3	1	0.22	68	5.9638	1.0665
2014	9	20	18	32	18	0.3	1	0.23	68.7	5.9638	1.1009
2014	9	20	18	42	18	0.3	1	0.3	70.8	5.9638	1.4794
2014	9	20	18	52	18	0.3	1	0.22	79	5.9638	1.1525
2014	9	20	19	2	18	0.3	1	0.24	90	5.9638	1.2729
2014	9	20	19	12	18	0.3	1	0.25	93.8	5.9638	1.3073

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	19	22	18	0.3	1	0.26	86.3	5.9638	1.3418
2014	9	20	19	32	18	0.3	1	0.27	93.5	5.9638	1.3934
2014	9	20	19	42	18	0.3	1	0.25	90	5.9638	1.2902
2014	9	20	19	52	18	0.3	1	0.25	83.3	5.9638	1.3246
2014	9	20	20	2	18	0.3	1	0.22	85.7	5.9638	1.1353
2014	9	20	20	12	18	0.3	1	0.2	85.3	5.9638	1.0493
2014	9	20	20	22	18	0.3	1	0.2	77.8	5.9638	1.0321
2014	9	20	20	32	18	0.3	1	0.23	88.4	5.9445	1.2171
2014	9	20	20	42	18	0.3	1	0.25	99.7	5.9638	1.3074
2014	9	20	20	52	18	0.3	1	0.25	89.3	5.9638	1.3246
2014	9	20	21	2	18	0.3	1	0.26	96.4	5.9638	1.3762
2014	9	20	21	12	18	0.3	1	0.21	85.5	5.9638	1.0837
2014	9	20	21	22	18	0.3	1	0.26	82.1	5.9638	1.359
2014	9	20	21	32	18	0.3	1	0.21	51.5	5.9445	0.84
2014	9	20	21	42	18	0.3	1	0.27	60.9	5.9445	1.2343
2014	9	20	21	52	18	0.3	1	0.28	55	5.9638	1.2042
2014	9	20	22	2	18	0.3	1	0.26	66.3	5.9638	1.2558
2014	9	20	22	12	18	0.3	1	0.27	73.3	5.9638	1.3762
2014	9	20	22	22	18	0.3	1	0.32	78	5.9638	1.617
2014	9	20	22	32	18	0.3	1	0.18	95.3	5.9638	0.9289
2014	9	20	22	42	18	0.3	1	0.26	83.4	5.9638	1.3418
2014	9	20	22	52	18	0.3	1	0.26	82.7	5.9638	1.3418
2014	9	20	23	2	18	0.3	1	0.24	94	5.9638	1.2386
2014	9	20	23	12	18	0.3	1	0.27	89.3	5.9638	1.3934
2014	9	20	23	22	18	0.3	1	0.2	109.3	5.9638	0.9806
2014	9	20	23	32	18	0.3	1	0.25	90.7	5.9638	1.3246
2014	9	20	23	42	18	0.3	1	0.24	93.9	5.9638	1.273
2014	9	20	23	52	18	0.3	1	0.2	81.6	5.9638	1.0494
2014	9	21	0	2	18	0.3	1	0.24	92.4	5.9638	1.2386
2014	9	21	0	12	18	0.3	1	0.23	81.6	5.9638	1.1698
2014	9	21	0	22	18	0.3	1	0.29	91.9	5.9638	1.5311
2014	9	21	0	32	18	0.3	1	0.24	96.2	5.9638	1.273
2014	9	21	0	42	18	0.3	1	0.25	95.3	5.9638	1.3074
2014	9	21	0	52	18	0.3	1	0.24	77.5	5.9638	1.2386
2014	9	21	1	2	18	0.3	1	0.21	94.5	5.9638	1.101
2014	9	21	1	12	18	0.3	1	0.28	97.3	5.9638	1.4795
2014	9	21	1	22	18	0.3	1	0.23	87.5	5.9638	1.187
2014	9	21	1	32	18	0.3	1	0.28	99.4	5.9638	1.4623
2014	9	21	1	42	18	0.3	1	0.22	96.1	5.9638	1.1354
2014	9	21	1	52	18	0.3	1	0.25	92.3	5.9638	1.2902
2014	9	21	2	2	18	0.3	1	0.25	97.4	5.9638	1.3246
2014	9	21	2	12	18	0.3	1	0.3	76	5.9638	1.5139
2014	9	21	2	22	18	0.3	1	0.29	64.3	5.9638	1.359
2014	9	21	2	32	18	0.3	1	0.3	52.5	5.9638	1.2558
2014	9	21	2	42	18	0.3	1	0.25	62.1	5.9638	1.1698
2014	9	21	2	52	18	0.3	1	0.25	73.7	5.9638	1.2386

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	3	2	18	0.3	1	0.26	91.4	5.9638	1.3762
2014	9	21	3	12	18	0.3	1	0.31	80.7	5.9638	1.5827
2014	9	21	3	22	18	0.3	1	0.23	78.4	5.9832	1.1739
2014	9	21	3	32	18	0.3	1	0.27	72.6	5.9832	1.381
2014	9	21	3	42	18	0.3	1	0.25	72.7	5.9832	1.2775
2014	9	21	3	52	18	0.3	1	0.19	89	5.9832	0.984
2014	9	21	4	2	18	0.3	1	0.27	76.8	5.9638	1.3935
2014	9	21	4	12	18	0.3	1	0.27	75.1	5.9638	1.359
2014	9	21	4	22	18	0.3	1	0.24	86.1	5.9832	1.2775
2014	9	21	4	32	18	0.3	1	0.24	95.4	5.9832	1.2775
2014	9	21	4	42	18	0.3	1	0.32	94.8	5.9638	1.6515
2014	9	21	4	52	18	0.3	1	0.3	82.4	5.9832	1.5537
2014	9	21	5	2	18	0.3	1	0.22	67.2	5.9832	1.0703
2014	9	21	5	12	18	0.3	1	0.2	75.5	6.0025	1.0048
2014	9	21	5	22	18	0.3	1	0.25	75.6	6.0025	1.2819
2014	9	21	5	32	18	0.3	1	0.24	91.6	6.0025	1.2646
2014	9	21	5	42	18	0.3	1	0.21	96.2	6.0025	1.1087
2014	9	21	5	52	18	0.3	1	0.23	91.7	6.0219	1.1995
2014	9	21	6	2	18	0.3	1	0.2	103.6	6.0219	1.0082
2014	9	21	6	12	18	0.3	1	0.2	92.9	6.0219	1.043
2014	9	21	6	22	18	0.3	1	0.23	114.8	6.0219	1.1299
2014	9	21	6	32	18	0.3	1	0.23	85	6.0219	1.1995
2014	9	21	6	42	18	0.3	1	0.26	84.2	6.0412	1.378
2014	9	21	6	52	18	0.3	1	0.26	97.9	6.0219	1.3733
2014	9	21	7	2	18	0.3	1	0.17	101.9	6.0412	0.9071
2014	9	21	7	12	18	0.3	1	0.28	89.3	6.0412	1.4653
2014	9	21	7	22	18	0.3	1	0.23	100	6.0412	1.1862
2014	9	21	7	32	18	0.3	1	0.2	95.5	6.0412	1.0815
2014	9	21	7	42	18	0.3	1	0.26	84.9	6.0412	1.3606
2014	9	21	7	52	18	0.3	1	0.27	99.8	6.0412	1.4129
2014	9	21	8	2	18	0.3	1	0.24	86.1	6.0412	1.2734
2014	9	21	8	12	18	0.3	1	0.31	106.5	6.0412	1.5874
2014	9	21	8	22	18	0.3	1	0.22	90	6.0412	1.1862
2014	9	21	8	32	18	0.3	1	0.26	90.7	6.0412	1.3781
2014	9	21	8	42	18	0.3	1	0.21	90	6.0412	1.099
2014	9	21	8	52	18	0.3	1	0.19	95.9	6.0412	1.0117
2014	9	21	9	2	18	0.3	1	0.23	85.9	6.0412	1.2036
2014	9	21	9	12	18	0.3	1	0.23	91.7	6.0412	1.2036
2014	9	21	9	22	18	0.3	1	0.25	80	6.0412	1.2908
2014	9	21	9	32	18	0.3	1	0.25	87.8	6.0412	1.3432
2014	9	21	9	42	18	0.3	1	0.2	76.7	6.0412	1.0292
2014	9	21	9	52	18	0.3	1	0.23	84.4	6.0412	1.2385
2014	9	21	10	2	18	0.3	1	0.19	91	6.0412	0.9943
2014	9	21	10	12	18	0.3	1	0.24	86.1	6.0412	1.2908
2014	9	21	10	22	18	0.3	1	0.24	83.7	6.0219	1.2516
2014	9	21	10	32	18	0.3	1	0.24	86	6.0219	1.2516

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	10	42	18	0.3	1	0.28	82.5	6.0219	1.4602
2014	9	21	10	52	18	0.3	1	0.27	83	6.0219	1.4254
2014	9	21	11	2	18	0.3	1	0.28	90	6.0219	1.495
2014	9	21	11	12	18	0.3	1	0.23	63.4	6.0219	1.1125
2014	9	21	11	22	18	0.3	1	0.27	86.5	6.0219	1.4254
2014	9	21	11	32	18	0.3	1	0.25	78.7	6.0025	1.2992
2014	9	21	11	42	18	0.3	1	0.28	88.7	6.0025	1.4725
2014	9	21	11	52	18	0.3	1	0.22	87.4	6.0025	1.1606
2014	9	21	12	2	18	0.3	1	0.2	75.7	6.0025	1.022
2014	9	21	12	12	18	0.3	1	0.27	76.8	6.0025	1.4031
2014	9	21	12	22	18	0.3	1	0.22	80.4	5.9832	1.1221
2014	9	21	12	32	18	0.3	1	0.29	82.8	5.9832	1.5019
2014	9	21	12	42	18	0.3	1	0.34	90	5.9832	1.778
2014	9	21	12	52	18	0.3	1	0.25	80	5.9832	1.2774
2014	9	21	13	2	18	0.3	1	0.27	86.5	5.9832	1.4155
2014	9	21	13	12	18	0.3	1	0.25	90	5.9832	1.312
2014	9	21	13	22	18	0.3	1	0.27	72.9	5.9832	1.3465
2014	9	21	13	32	18	0.3	1	0.22	81.5	5.9832	1.1566
2014	9	21	13	42	18	0.3	1	0.22	67.6	5.9832	1.0875
2014	9	21	13	52	18	0.3	1	0.3	79.3	5.9832	1.5536
2014	9	21	14	2	18	0.3	1	0.29	73.4	5.9832	1.45
2014	9	21	14	12	18	0.3	1	0.27	77.2	5.9832	1.3637
2014	9	21	14	22	18	0.3	1	0.29	78.2	5.9832	1.4845
2014	9	21	14	32	18	0.3	1	0.19	75.3	5.9832	0.9839
2014	9	21	14	42	18	0.3	1	0.29	88.7	5.9832	1.5018
2014	9	21	14	52	18	0.3	1	0.21	83.9	5.9832	1.122
2014	9	21	15	2	18	0.3	1	0.26	73.7	5.9832	1.2946
2014	9	21	15	12	18	0.3	1	0.23	78.7	5.9832	1.2083
2014	9	21	15	22	18	0.3	1	0.19	94.8	5.9832	1.0185
2014	9	21	15	32	18	0.3	1	0.26	86.3	5.9638	1.3417
2014	9	21	15	42	18	0.3	1	0.29	86.7	5.9832	1.519
2014	9	21	15	52	18	0.3	1	0.23	75.4	5.9638	1.1869
2014	9	21	16	2	18	0.3	1	0.23	69.5	5.9638	1.1525
2014	9	21	16	12	18	0.3	1	0.27	87.9	5.9638	1.3933
2014	9	21	16	22	18	0.3	1	0.34	77.8	5.9832	1.7607
2014	9	21	16	32	18	0.3	1	0.3	81.2	5.9638	1.5481
2014	9	21	16	42	18	0.3	1	0.29	80.3	5.9832	1.519
2014	9	21	16	52	18	0.3	1	0.3	72.8	5.9638	1.4965
2014	9	21	17	2	18	0.3	1	0.27	69.6	5.9832	1.3464
2014	9	21	17	12	18	0.3	1	0.25	60.4	5.9832	1.1565
2014	9	21	17	22	18	0.3	1	0.28	77.3	5.9832	1.45
2014	9	21	17	32	18	0.3	1	0.32	82.4	5.9832	1.6916
2014	9	21	17	42	18	0.3	1	0.26	66	5.9832	1.2428
2014	9	21	17	52	18	0.3	1	0.27	73.8	5.9832	1.3637
2014	9	21	18	2	18	0.3	1	0.27	92.1	5.9832	1.3982
2014	9	21	18	12	18	0.3	1	0.24	86.1	5.9832	1.2774

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	18	22	18	0.3	1	0.23	93.3	5.9832	1.2083
2014	9	21	18	32	18	0.3	1	0.22	98.6	5.9832	1.1393
2014	9	21	18	42	18	0.3	1	0.3	93.7	5.9832	1.5881
2014	9	21	18	52	18	0.3	1	0.25	80.9	5.9832	1.2946
2014	9	21	19	2	18	0.3	1	0.29	100.4	5.9832	1.5018
2014	9	21	19	12	18	0.3	1	0.22	108.4	5.9832	1.0875
2014	9	21	19	22	18	0.3	1	0.28	90	5.9832	1.45
2014	9	21	19	32	18	0.3	1	0.2	98.5	5.9832	1.0357
2014	9	21	19	42	18	0.3	1	0.23	94.9	5.9832	1.2083
2014	9	21	19	52	18	0.3	1	0.24	98	5.9832	1.2256
2014	9	21	20	2	18	0.3	1	0.18	86.8	5.9832	0.9321
2014	9	21	20	12	18	0.3	1	0.24	98.6	5.9832	1.2601
2014	9	21	20	22	18	0.3	1	0.26	82.9	5.9832	1.381
2014	9	21	20	32	18	0.3	1	0.27	92.1	5.9832	1.4328
2014	9	21	20	42	18	0.3	1	0.25	92.2	5.9832	1.3292
2014	9	21	20	52	18	0.3	1	0.25	93.8	5.9832	1.3119
2014	9	21	21	2	18	0.3	1	0.24	99.3	5.9832	1.2601
2014	9	21	21	12	18	0.3	1	0.24	90.8	5.9832	1.2774
2014	9	21	21	22	18	0.3	1	0.22	95	5.9832	1.1738
2014	9	21	21	32	18	0.3	1	0.24	98.8	5.9832	1.2256
2014	9	21	21	42	18	0.3	1	0.26	90	6.0025	1.3511
2014	9	21	21	52	18	0.3	1	0.24	92.3	6.0025	1.2819
2014	9	21	22	2	18	0.3	1	0.26	76.8	6.0025	1.3338
2014	9	21	22	12	18	0.3	1	0.24	83	6.0025	1.2645
2014	9	21	22	22	18	0.3	1	0.22	87.4	6.0025	1.1606
2014	9	21	22	32	18	0.3	1	0.27	78.7	6.0025	1.3858
2014	9	21	22	42	18	0.3	1	0.25	95.3	6.0025	1.3165
2014	9	21	22	52	18	0.3	1	0.21	88.2	6.0025	1.126
2014	9	21	23	2	18	0.3	1	0.21	77.1	6.0219	1.0603
2014	9	21	23	12	18	0.3	1	0.3	100.2	6.0219	1.5471
2014	9	21	23	22	18	0.3	1	0.28	98	6.0219	1.4775
2014	9	21	23	32	18	0.3	1	0.23	83.5	6.0219	1.2168
2014	9	21	23	42	18	0.3	1	0.22	96.8	6.0219	1.1647
2014	9	21	23	52	18	0.3	1	0.23	101.6	6.0219	1.182
2014	9	22	0	2	18	0.3	1	0.26	90	6.0412	1.3954
2014	9	22	0	12	18	0.3	1	0.34	102.4	6.0219	1.7383
2014	9	22	0	22	18	0.3	1	0.25	102	6.0412	1.3082
2014	9	22	0	32	18	0.3	1	0.33	82	6.0219	1.7383
2014	9	22	0	42	18	0.3	1	0.24	102.9	6.0219	1.2168
2014	9	22	0	52	18	0.3	1	0.21	98.1	6.0219	1.0951
2014	9	22	1	2	18	0.3	1	0.27	104.5	6.0219	1.408
2014	9	22	1	12	18	0.3	1	0.23	99.7	6.0219	1.2168
2014	9	22	1	22	18	0.3	1	0.23	90	6.0025	1.2126
2014	9	22	1	32	18	0.3	1	0.24	89.2	6.0025	1.2819
2014	9	22	1	42	18	0.3	1	0.29	93.3	6.0025	1.5071
2014	9	22	1	52	18	0.3	1	0.23	112.9	6.0025	1.1087

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	2	2	18	0.3	1	0.24	99.6	6.0025	1.2299
2014	9	22	2	12	18	0.3	1	0.23	105	6.0025	1.1606
2014	9	22	2	22	18	0.3	1	0.19	106.2	6.0025	0.9528
2014	9	22	2	32	18	0.3	1	0.27	86.6	5.9832	1.4328
2014	9	22	2	42	18	0.3	1	0.24	94	5.9832	1.2429
2014	9	22	2	52	18	0.3	1	0.25	71.8	5.9832	1.2602
2014	9	22	3	2	18	0.3	1	0.24	92.3	5.9832	1.2775
2014	9	22	3	12	18	0.3	1	0.19	94.8	5.9832	1.0185
2014	9	22	3	22	18	0.3	1	0.26	90	5.9832	1.3465
2014	9	22	3	32	18	0.3	1	0.31	99.9	5.9832	1.5882
2014	9	22	3	42	18	0.3	1	0.23	98.9	5.9832	1.2084
2014	9	22	3	52	18	0.3	1	0.21	93.6	5.9832	1.0876
2014	9	22	4	2	18	0.3	1	0.28	97.5	5.9832	1.4501
2014	9	22	4	12	18	0.3	1	0.21	94.5	5.9832	1.0876
2014	9	22	4	22	18	0.3	1	0.29	96.6	5.9638	1.4967
2014	9	22	4	32	18	0.3	1	0.26	89.3	5.9638	1.3763
2014	9	22	4	42	18	0.3	1	0.23	106.1	5.9638	1.1354
2014	9	22	4	52	18	0.3	1	0.28	100.1	5.9638	1.4451
2014	9	22	5	2	18	0.3	1	0.18	88	5.9638	0.9634
2014	9	22	5	12	18	0.3	1	0.24	96.3	5.9638	1.2386
2014	9	22	5	22	18	0.3	1	0.28	100.1	5.9638	1.4451
2014	9	22	5	32	18	0.3	1	0.22	81.4	5.9638	1.1354
2014	9	22	5	42	18	0.3	1	0.19	84	5.9638	0.9806
2014	9	22	5	52	18	0.3	1	0.21	94.5	5.9638	1.0838
2014	9	22	6	2	18	0.3	1	0.23	100.5	5.9638	1.2042
2014	9	22	6	12	18	0.3	1	0.24	85.4	5.9445	1.2686
2014	9	22	6	22	18	0.3	1	0.22	107.1	5.9445	1.1143
2014	9	22	6	32	18	0.3	1	0.25	83.2	5.9445	1.3029
2014	9	22	6	42	18	0.3	1	0.28	81.8	5.9445	1.4229
2014	9	22	6	52	18	0.3	1	0.26	90	5.9445	1.3543
2014	9	22	7	2	18	0.3	1	0.16	86.4	5.9445	0.8229
2014	9	22	7	12	18	0.3	1	0.19	103.3	5.9445	0.9429
2014	9	22	7	22	18	0.3	1	0.21	77.7	5.9445	1.0972
2014	9	22	7	32	18	0.3	1	0.3	78.1	5.9251	1.5375
2014	9	22	7	42	18	0.3	1	0.27	76.8	5.9251	1.3838
2014	9	22	7	52	18	0.3	1	0.33	79.7	5.9251	1.6913
2014	9	22	8	2	18	0.3	1	0.26	67.4	5.9251	1.23
2014	9	22	8	12	18	0.3	1	0.33	86.6	5.9251	1.7084
2014	9	22	8	22	18	0.3	1	0.28	88	5.9445	1.4572
2014	9	22	8	32	18	0.3	1	0.23	77.4	5.9445	1.1486
2014	9	22	8	42	18	0.3	1	0.23	94	5.9251	1.2129
2014	9	22	8	52	18	0.3	1	0.27	77.9	5.9445	1.3543
2014	9	22	9	2	18	0.3	1	0.27	81.6	5.9251	1.3838
2014	9	22	9	12	18	0.3	1	0.19	91.9	5.9251	1.0079
2014	9	22	9	22	18	0.3	1	0.23	95.8	5.9251	1.1788
2014	9	22	9	32	18	0.3	1	0.25	90	5.9251	1.2984

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	9	42	18	0.3	1	0.23	81.6	5.9251	1.1617
2014	9	22	9	52	18	0.3	1	0.22	96.1	5.9251	1.1275
2014	9	22	10	2	18	0.3	1	0.21	94.5	5.9251	1.0933
2014	9	22	10	12	18	0.3	1	0.33	81.3	5.9251	1.6742
2014	9	22	10	22	18	0.3	1	0.26	79.1	5.9251	1.3325
2014	9	22	10	32	18	0.3	1	0.26	76.8	5.9251	1.3154
2014	9	22	10	42	18	0.3	1	0.23	82.5	5.9251	1.1617
2014	9	22	10	52	18	0.3	1	0.27	86.5	5.9057	1.3959
2014	9	22	11	2	18	0.3	1	0.21	85.5	5.9251	1.0763
2014	9	22	11	12	18	0.3	1	0.25	82.6	5.9057	1.3108
2014	9	22	11	22	18	0.3	1	0.26	79.8	5.9251	1.3325
2014	9	22	11	32	18	0.3	1	0.25	93	5.9251	1.2983
2014	9	22	11	42	18	0.3	1	0.28	90	5.9251	1.4521
2014	9	22	11	52	18	0.3	1	0.31	72.1	5.9057	1.5321
2014	9	22	12	2	18	0.3	1	0.25	81.5	5.9057	1.2597
2014	9	22	12	12	18	0.3	1	0.24	86	5.9057	1.2256
2014	9	22	12	22	18	0.3	1	0.25	84.7	5.9057	1.2937
2014	9	22	12	32	18	0.3	1	0.25	85.4	5.9251	1.2812
2014	9	22	12	42	18	0.3	1	0.27	83.8	5.9057	1.4129
2014	9	22	12	52	18	0.3	1	0.19	71.9	5.9057	0.9362
2014	9	22	13	2	18	0.3	1	0.26	66.3	5.9057	1.2426
2014	9	22	13	12	18	0.3	1	0.28	81.8	5.9057	1.4129
2014	9	22	13	22	18	0.3	1	0.17	64.9	5.9057	0.8001
2014	9	22	13	32	18	0.3	1	0.23	76.9	5.9057	1.1745
2014	9	22	13	42	18	0.3	1	0.22	100.5	5.9057	1.1064
2014	9	22	13	52	18	0.3	1	0.3	63.4	5.9057	1.3958
2014	9	22	14	2	18	0.3	1	0.25	86.3	5.9057	1.3107
2014	9	22	14	12	18	0.3	1	0.15	60.1	5.9057	0.6809
2014	9	22	14	22	18	0.3	1	0.21	81.1	5.8864	1.0856
2014	9	22	14	32	18	0.3	1	0.27	86.5	5.9057	1.3788
2014	9	22	14	42	18	0.3	1	0.24	73.8	5.8864	1.1704
2014	9	22	14	52	18	0.3	1	0.27	82.3	5.8864	1.3739
2014	9	22	15	2	18	0.3	1	0.23	71.8	5.8864	1.1364
2014	9	22	15	12	18	0.3	1	0.23	83.6	5.8864	1.2043
2014	9	22	15	22	18	0.3	1	0.28	79.1	5.8864	1.4078
2014	9	22	15	32	18	0.3	1	0.24	84.5	5.8864	1.2382
2014	9	22	15	42	18	0.3	1	0.23	84.3	5.867	1.1831
2014	9	22	15	52	18	0.3	1	0.3	73.4	5.867	1.4704
2014	9	22	16	2	18	0.3	1	0.24	78.1	5.867	1.2
2014	9	22	16	12	18	0.3	1	0.27	97	5.867	1.369
2014	9	22	16	22	18	0.3	1	0.24	93.9	5.867	1.2338
2014	9	22	16	32	18	0.3	1	0.23	72.6	5.867	1.1324
2014	9	22	16	42	18	0.3	1	0.2	83.5	5.867	1.031
2014	9	22	16	52	18	0.3	1	0.23	90	5.867	1.1662
2014	9	22	17	2	18	0.3	1	0.22	100.3	5.867	1.1155
2014	9	22	17	12	18	0.3	1	0.27	82.5	5.867	1.4028

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	17	22	18	0.3	1	0.23	85	5.867	1.1662
2014	9	22	17	32	18	0.3	1	0.33	93.4	5.867	1.7071
2014	9	22	17	42	18	0.3	1	0.27	85.1	5.867	1.3859
2014	9	22	17	52	18	0.3	1	0.21	93.6	5.867	1.0648
2014	9	22	18	2	18	0.3	1	0.21	90	5.867	1.0648
2014	9	22	18	12	18	0.3	1	0.19	88	5.867	0.9803
2014	9	22	18	22	18	0.3	1	0.21	121	5.867	0.9296
2014	9	22	18	32	18	0.3	1	0.19	99	5.867	0.9634
2014	9	22	18	42	18	0.3	1	0.16	86.6	5.867	0.8451
2014	9	22	18	52	18	0.3	1	0.16	91.1	5.867	0.8451
2014	9	22	19	2	18	0.3	1	0.24	101.6	5.867	1.2338
2014	9	22	19	12	18	0.3	1	0.24	107.9	5.867	1.2
2014	9	22	19	22	18	0.3	1	0.21	93.6	5.867	1.0648
2014	9	22	19	32	18	0.3	1	0.15	83.7	5.8477	0.7579
2014	9	22	19	42	18	0.3	1	0.25	94.6	5.867	1.2676
2014	9	22	19	52	18	0.3	1	0.19	98.1	5.8477	0.9431
2014	9	22	20	2	18	0.3	1	0.24	86.1	5.8477	1.2295
2014	9	22	20	12	18	0.3	1	0.16	108.4	5.867	0.7606
2014	9	22	20	22	18	0.3	1	0.28	94	5.867	1.4367
2014	9	22	20	32	18	0.3	1	0.17	119.5	5.867	0.7775
2014	9	22	20	42	18	0.3	1	0.19	95	5.867	0.9634
2014	9	22	20	52	18	0.3	1	0.2	106.1	5.8477	0.9937
2014	9	22	21	2	18	0.3	1	0.2	95.6	5.8477	1.0274
2014	9	22	21	12	18	0.3	1	0.21	89.1	5.867	1.0817
2014	9	22	21	22	18	0.3	1	0.19	98.8	5.867	0.9803
2014	9	22	21	32	18	0.3	1	0.18	115.2	5.867	0.862
2014	9	22	21	42	18	0.3	1	0.17	86.7	5.867	0.8789
2014	9	22	21	52	18	0.3	1	0.26	126.1	5.867	1.0648
2014	9	22	22	2	18	0.3	1	0.16	97	5.867	0.8282
2014	9	22	22	12	18	0.3	1	0.22	106.3	5.867	1.0986
2014	9	22	22	22	18	0.3	1	0.23	98.9	5.867	1.1832
2014	9	22	22	32	18	0.3	1	0.18	101.5	5.867	0.9127
2014	9	22	22	42	18	0.3	1	0.18	84.7	5.867	0.9127
2014	9	22	22	52	18	0.3	1	0.2	88.1	5.867	1.0141
2014	9	22	23	2	18	0.3	1	0.25	114.6	5.867	1.1832
2014	9	22	23	12	18	0.3	1	0.23	96.5	5.867	1.1832
2014	9	22	23	22	18	0.3	1	0.22	90	5.867	1.1156
2014	9	22	23	32	18	0.3	1	0.16	99.7	5.867	0.7944
2014	9	22	23	42	18	0.3	1	0.21	112.1	5.867	0.9973
2014	9	22	23	52	18	0.3	1	0.24	98.7	5.867	1.217
2014	9	23	0	2	18	0.3	1	0.14	111.3	5.867	0.693
2014	9	23	0	12	18	0.3	1	0.19	90	5.867	0.9804
2014	9	23	0	22	18	0.3	1	0.19	100.7	5.867	0.9804
2014	9	23	0	32	18	0.3	1	0.17	100	5.867	0.862
2014	9	23	0	42	18	0.3	1	0.23	109.5	5.867	1.0987
2014	9	23	0	52	18	0.3	1	0.19	105.9	5.867	0.9466

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	1	2	18	0.3	1	0.2	91	5.867	1.0142
2014	9	23	1	12	18	0.3	1	0.25	99.1	5.867	1.2677
2014	9	23	1	22	18	0.3	1	0.13	79.8	5.867	0.6592
2014	9	23	1	32	18	0.3	1	0.19	101.7	5.867	0.9804
2014	9	23	1	42	18	0.3	1	0.18	97.5	5.867	0.8959
2014	9	23	1	52	18	0.3	1	0.16	102.9	5.867	0.8113
2014	9	23	2	2	18	0.3	1	0.25	100.4	5.867	1.2846
2014	9	23	2	12	18	0.3	1	0.25	102.4	5.867	1.2339
2014	9	23	2	22	18	0.3	1	0.2	99.5	5.867	1.0142
2014	9	23	2	32	18	0.3	1	0.21	108.4	5.867	1.0142
2014	9	23	2	42	18	0.3	1	0.2	103.3	5.867	0.9973
2014	9	23	2	52	18	0.3	1	0.16	102.7	5.867	0.8283
2014	9	23	3	2	18	0.3	1	0.18	99.6	5.867	0.8959
2014	9	23	3	12	18	0.3	1	0.19	100.7	5.867	0.9804
2014	9	23	3	22	18	0.3	1	0.15	92.4	5.8864	0.7973
2014	9	23	3	32	18	0.3	1	0.21	90	5.867	1.0649
2014	9	23	3	42	18	0.3	1	0.23	99.1	5.867	1.1663
2014	9	23	3	52	18	0.3	1	0.22	83.9	5.8864	1.1196
2014	9	23	4	2	18	0.3	1	0.16	103.2	5.8864	0.7973
2014	9	23	4	12	18	0.3	1	0.22	95.1	5.867	1.1325
2014	9	23	4	22	18	0.3	1	0.2	103.6	5.8864	0.9839
2014	9	23	4	32	18	0.3	1	0.15	122	5.8864	0.6785
2014	9	23	4	42	18	0.3	1	0.14	92.6	5.8864	0.7464
2014	9	23	4	52	18	0.3	1	0.21	84.7	5.8864	1.1026
2014	9	23	5	2	18	0.3	1	0.21	97.4	5.8864	1.0517
2014	9	23	5	12	18	0.3	1	0.27	104.5	5.8864	1.374
2014	9	23	5	22	18	0.3	1	0.23	109.5	5.8864	1.1026
2014	9	23	5	32	18	0.3	1	0.17	90	5.8864	0.8651
2014	9	23	5	42	18	0.3	1	0.18	90	5.9057	0.9363
2014	9	23	5	52	18	0.3	1	0.22	92.6	5.9057	1.1406
2014	9	23	6	2	18	0.3	1	0.21	109	5.9057	1.0384
2014	9	23	6	12	18	0.3	1	0.18	98.6	5.9057	0.9022
2014	9	23	6	22	18	0.3	1	0.23	90	5.9057	1.2087
2014	9	23	6	32	18	0.3	1	0.28	99.5	5.9057	1.43
2014	9	23	6	42	18	0.3	1	0.16	104.3	5.9057	0.8001
2014	9	23	6	52	18	0.3	1	0.25	105.3	5.9057	1.2427
2014	9	23	7	2	18	0.3	1	0.26	101.6	5.9057	1.3278
2014	9	23	7	12	18	0.3	1	0.19	99.8	5.9057	0.9874
2014	9	23	7	22	18	0.3	1	0.24	105	5.9057	1.2087
2014	9	23	7	32	18	0.3	1	0.23	92.5	5.9057	1.1917
2014	9	23	7	42	18	0.3	1	0.22	118.8	5.9057	1.0214
2014	9	23	7	52	18	0.3	1	0.22	105.5	5.9057	1.1065
2014	9	23	8	2	18	0.3	1	0.2	105.4	5.9057	0.9874
2014	9	23	8	12	18	0.3	1	0.21	94.5	5.9251	1.0934
2014	9	23	8	22	18	0.3	1	0.23	98.1	5.9251	1.1959
2014	9	23	8	32	18	0.3	1	0.21	112.1	5.9251	1.0079

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	8	42	18	0.3	1	0.23	99.2	5.9251	1.1617
2014	9	23	8	52	18	0.3	1	0.26	104.4	5.9251	1.3325
2014	9	23	9	2	18	0.3	1	0.22	116.9	5.9251	1.0421
2014	9	23	9	12	18	0.3	1	0.28	92.7	5.9251	1.435
2014	9	23	9	22	18	0.3	1	0.27	97	5.9251	1.3838
2014	9	23	9	32	18	0.3	1	0.22	83.3	5.9251	1.1617
2014	9	23	9	42	18	0.3	1	0.18	94.1	5.9251	0.9567
2014	9	23	9	52	18	0.3	1	0.18	101.7	5.9251	0.9054
2014	9	23	10	2	18	0.3	1	0.23	94.9	5.9251	1.1958
2014	9	23	10	12	18	0.3	1	0.23	95	5.9251	1.1788
2014	9	23	10	22	18	0.3	1	0.25	105.8	5.9251	1.2642
2014	9	23	10	32	18	0.3	1	0.23	95.6	5.9251	1.2129
2014	9	23	10	42	18	0.3	1	0.19	90	5.9251	0.9908
2014	9	23	10	52	18	0.3	1	0.28	84	5.9251	1.4521
2014	9	23	11	2	18	0.3	1	0.21	90	5.9251	1.0933
2014	9	23	11	12	18	0.3	1	0.22	85.7	5.9251	1.1275
2014	9	23	11	22	18	0.3	1	0.22	75.6	5.9251	1.1275
2014	9	23	11	32	18	0.3	1	0.23	85.1	5.9251	1.1958
2014	9	23	11	54	10	0.3	1	0.28	70.3	5.9251	1.3837
2014	9	23	12	4	10	0.3	1	0.24	81.3	5.9251	1.23
2014	9	23	12	14	10	0.3	1	0.23	78.4	5.9251	1.1616
2014	9	23	12	24	10	0.3	1	0.21	90	5.9251	1.1104
2014	9	23	12	34	10	0.3	1	0.28	91.3	5.9251	1.452
2014	9	23	12	44	10	0.3	1	0.26	82.7	5.9251	1.3325
2014	9	23	12	54	10	0.3	1	0.28	69.7	5.9251	1.3837
2014	9	23	13	4	10	0.3	1	0.21	97	5.9251	1.1104
2014	9	23	13	14	10	0.3	1	0.24	82	5.9251	1.2129
2014	9	23	13	24	10	0.3	1	0.24	79.8	5.9251	1.2299
2014	9	23	13	34	10	0.3	1	0.24	79.6	5.9251	1.2128
2014	9	23	13	44	10	0.3	1	0.18	84.9	5.9251	0.9566
2014	9	23	13	54	10	0.3	1	0.24	73.1	5.9251	1.1787
2014	9	23	14	4	10	0.3	1	0.3	74.6	5.9251	1.4862
2014	9	23	14	14	10	0.3	1	0.19	71.6	5.9251	0.9224
2014	9	23	14	24	10	0.3	1	0.29	79.5	5.9251	1.4691
2014	9	23	14	34	10	0.3	1	0.23	80	5.9251	1.1616
2014	9	23	14	44	10	0.3	1	0.29	68.7	5.9251	1.4007
2014	9	23	14	54	10	0.3	1	0.25	86.2	5.9251	1.2811
2014	9	23	15	4	10	0.3	1	0.3	85	5.9251	1.5545
2014	9	23	15	14	10	0.3	1	0.27	76.6	5.9057	1.3618
2014	9	23	15	24	10	0.3	1	0.25	72.7	5.9057	1.2596
2014	9	23	15	34	10	0.3	1	0.29	80.3	5.9057	1.4979
2014	9	23	15	44	10	0.3	1	0.22	82.3	5.9057	1.1405
2014	9	23	15	54	10	0.3	1	0.24	78.2	5.9251	1.2299
2014	9	23	16	4	10	0.3	1	0.2	78	5.9251	1.042
2014	9	23	16	14	10	0.3	1	0.24	83.8	5.9251	1.264
2014	9	23	16	24	10	0.3	1	0.3	76.9	5.9057	1.532

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	16	34	10	0.3	1	0.25	87	5.9251	1.3153
2014	9	23	16	44	10	0.3	1	0.22	66.5	5.9251	1.0591
2014	9	23	16	54	10	0.3	1	0.26	96.4	5.9251	1.3665
2014	9	23	17	4	10	0.3	1	0.24	73.3	5.9251	1.1957
2014	9	23	17	14	10	0.3	1	0.18	94.1	5.9251	0.9566
2014	9	23	17	24	10	0.3	1	0.22	76	5.9251	1.0932
2014	9	23	17	34	10	0.3	1	0.19	70.9	5.9251	0.9395
2014	9	23	17	44	10	0.3	1	0.18	71.6	5.9251	0.8712
2014	9	23	17	54	10	0.3	1	0.19	101.1	5.9251	0.9566
2014	9	23	18	4	10	0.3	1	0.25	58.6	5.9251	1.0932
2014	9	23	18	14	10	0.3	1	0.2	80.7	5.9251	1.042
2014	9	23	18	24	10	0.3	1	0.21	95.4	5.9251	1.0932
2014	9	23	18	34	10	0.3	1	0.22	92.6	5.9251	1.1445
2014	9	23	18	44	10	0.3	1	0.2	88.1	5.9251	1.042
2014	9	23	18	54	10	0.3	1	0.21	90	5.9251	1.1103
2014	9	23	19	4	10	0.3	1	0.22	90	5.9251	1.1616
2014	9	23	19	14	10	0.3	1	0.16	84.2	5.9251	0.837
2014	9	23	19	24	10	0.3	1	0.22	99.3	5.9251	1.1445
2014	9	23	19	34	10	0.3	1	0.18	101.3	5.9251	0.9395
2014	9	23	19	44	10	0.3	1	0.29	90	5.9251	1.5203
2014	9	23	19	54	10	0.3	1	0.24	105.2	5.9445	1.1999
2014	9	23	20	4	10	0.3	1	0.2	101.1	5.9445	1.0457
2014	9	23	20	14	10	0.3	1	0.23	90	5.9251	1.1957
2014	9	23	20	24	10	0.3	1	0.22	91.7	5.9445	1.1314
2014	9	23	20	34	10	0.3	1	0.22	106.3	5.9445	1.1142
2014	9	23	20	44	10	0.3	1	0.21	93.6	5.9445	1.08
2014	9	23	20	54	10	0.3	1	0.2	107.5	5.9445	0.9771
2014	9	23	21	4	10	0.3	1	0.23	94.9	5.9445	1.2
2014	9	23	21	14	10	0.3	1	0.22	100.3	5.9445	1.1314
2014	9	23	21	24	10	0.3	1	0.28	79.1	5.9445	1.4228
2014	9	23	21	34	10	0.3	1	0.22	79.7	5.9445	1.1314
2014	9	23	21	44	10	0.3	1	0.3	110	5.9445	1.4571
2014	9	23	21	54	10	0.3	1	0.19	104	5.9445	0.96
2014	9	23	22	4	10	0.3	1	0.24	99.3	5.9251	1.247
2014	9	23	22	14	10	0.3	1	0.27	99.8	5.9251	1.3837
2014	9	23	22	24	10	0.3	1	0.2	93.8	5.9251	1.042
2014	9	23	22	34	10	0.3	1	0.19	78.9	5.9251	0.9566
2014	9	23	22	44	10	0.3	1	0.22	69.6	5.9251	1.0591
2014	9	23	22	54	10	0.3	1	0.21	97.4	5.9251	1.0591
2014	9	23	23	4	10	0.3	1	0.22	73.2	5.9251	1.0762
2014	9	23	23	14	10	0.3	1	0.21	90	5.9251	1.1104
2014	9	23	23	24	10	0.3	1	0.23	91.7	5.9251	1.1787
2014	9	23	23	34	10	0.3	1	0.22	84.9	5.9445	1.1486
2014	9	23	23	44	10	0.3	1	0.29	83.4	5.9251	1.4862
2014	9	23	23	54	10	0.3	1	0.29	74.7	5.9251	1.435
2014	9	24	0	4	10	0.3	1	0.24	90	5.9251	1.2471

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	0	14	10	0.3	1	0.23	85.1	5.9251	1.1958
2014	9	24	0	24	10	0.3	1	0.16	90	5.9445	0.84
2014	9	24	0	34	10	0.3	1	0.23	82.8	5.9445	1.2172
2014	9	24	0	44	10	0.3	1	0.24	101.2	5.9445	1.2172
2014	9	24	0	54	10	0.3	1	0.23	99.1	5.9445	1.1829
2014	9	24	1	4	10	0.3	1	0.24	88.5	5.9251	1.2642
2014	9	24	1	14	10	0.3	1	0.24	82.3	5.9251	1.2642
2014	9	24	1	24	10	0.3	1	0.22	96.8	5.9251	1.1446
2014	9	24	1	34	10	0.3	1	0.23	89.2	5.9445	1.1829
2014	9	24	1	44	10	0.3	1	0.27	80.8	5.9251	1.3667
2014	9	24	1	54	10	0.3	1	0.32	83	5.9251	1.6742
2014	9	24	2	4	10	0.3	1	0.24	86	5.9445	1.2343
2014	9	24	2	14	10	0.3	1	0.2	88.1	5.9445	1.0458
2014	9	24	2	24	10	0.3	1	0.24	90	5.9445	1.2515
2014	9	24	2	34	10	0.3	1	0.3	77.5	5.9445	1.5429
2014	9	24	2	44	10	0.3	1	0.28	82.1	5.9445	1.4743
2014	9	24	2	54	10	0.3	1	0.21	89.1	5.9445	1.08
2014	9	24	3	4	10	0.3	1	0.25	103.5	5.9445	1.2858
2014	9	24	3	14	10	0.3	1	0.26	111.7	5.9445	1.2515
2014	9	24	3	24	10	0.3	1	0.21	90	5.9445	1.1143
2014	9	24	3	34	10	0.3	1	0.23	97.4	5.9445	1.1829
2014	9	24	3	44	10	0.3	1	0.25	75.4	5.9445	1.2515
2014	9	24	3	54	10	0.3	1	0.25	104.9	5.9445	1.2858
2014	9	24	4	4	10	0.3	1	0.22	98.7	5.9445	1.1143
2014	9	24	4	14	10	0.3	1	0.2	95.5	5.9445	1.0629
2014	9	24	4	24	10	0.3	1	0.33	94	5.9445	1.7315
2014	9	24	4	34	10	0.3	1	0.21	90	5.9445	1.0972
2014	9	24	4	44	10	0.3	1	0.27	90	5.9445	1.4229
2014	9	24	4	54	10	0.3	1	0.19	81	5.9445	0.9772
2014	9	24	5	4	10	0.3	1	0.18	105.1	5.9445	0.8915
2014	9	24	5	14	10	0.3	1	0.26	104.4	5.9445	1.3372
2014	9	24	5	24	10	0.3	1	0.27	84.4	5.9445	1.4058
2014	9	24	5	34	10	0.3	1	0.24	101.6	5.9445	1.2515
2014	9	24	5	44	10	0.3	1	0.28	94.8	5.9445	1.4401
2014	9	24	5	54	10	0.3	1	0.2	116.6	5.9445	0.9258
2014	9	24	6	4	10	0.3	1	0.27	86.6	5.9638	1.4279
2014	9	24	6	14	10	0.3	1	0.26	105.4	5.9445	1.3029
2014	9	24	6	24	10	0.3	1	0.18	107.4	5.9445	0.8743
2014	9	24	6	34	10	0.3	1	0.26	109.4	5.9445	1.2687
2014	9	24	6	44	10	0.3	1	0.2	105.2	5.9638	1.015
2014	9	24	6	54	10	0.3	1	0.26	105.6	5.9638	1.2903
2014	9	24	7	4	10	0.3	1	0.28	92	5.9638	1.4623
2014	9	24	7	14	10	0.3	1	0.26	109.4	5.9638	1.2731
2014	9	24	7	24	10	0.3	1	0.22	100.2	5.9638	1.1527
2014	9	24	7	34	10	0.3	1	0.22	96.8	5.9638	1.1527
2014	9	24	7	44	10	0.3	1	0.25	93	5.9638	1.3247

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	7	54	10	0.3	1	0.24	101.8	5.9832	1.243
2014	9	24	8	4	10	0.3	1	0.3	83.7	5.9832	1.571
2014	9	24	8	14	10	0.3	1	0.22	94.2	5.9832	1.174
2014	9	24	8	24	10	0.3	1	0.25	90	6.0025	1.334
2014	9	24	8	34	10	0.3	1	0.26	86.4	6.0025	1.3686
2014	9	24	8	44	10	0.3	1	0.18	105.5	6.0025	0.9355
2014	9	24	8	54	10	0.3	1	0.24	98.6	6.0219	1.2691
2014	9	24	9	4	10	0.3	1	0.3	98.7	6.0219	1.582
2014	9	24	9	14	10	0.3	1	0.28	102.7	6.0219	1.4603
2014	9	24	9	24	10	0.3	1	0.19	90	6.0219	0.9909
2014	9	24	9	34	10	0.3	1	0.27	102.1	6.0219	1.3734
2014	9	24	9	44	10	0.3	1	0.2	91	6.0606	1.0503
2014	9	24	9	54	10	0.3	1	0.23	102.1	6.0606	1.2253
2014	9	24	10	4	10	0.3	1	0.29	84.2	6.0606	1.5579
2014	9	24	10	14	10	0.3	1	0.21	92.6	6.08	1.1417
2014	9	24	10	24	10	0.3	1	0.25	84.7	6.08	1.3349
2014	9	24	10	34	10	0.3	1	0.22	94.3	6.0606	1.1553
2014	9	24	10	44	10	0.3	1	0.3	88.1	6.0606	1.6104
2014	9	24	10	54	10	0.3	1	0.22	79.7	6.08	1.1592
2014	9	24	11	4	10	0.3	1	0.23	82.6	6.08	1.2119
2014	9	24	11	14	10	0.3	1	0.24	89.2	6.08	1.2822
2014	9	24	11	24	10	0.3	1	0.22	83.2	6.08	1.1768
2014	9	24	11	34	10	0.3	1	0.22	76.8	6.08	1.1241
2014	9	24	11	44	10	0.3	1	0.27	86.6	6.08	1.4578
2014	9	24	11	54	10	0.3	1	0.21	81.9	6.08	1.1065
2014	9	24	12	4	10	0.3	1	0.24	77.5	6.08	1.2646
2014	9	24	12	14	10	0.3	1	0.27	88.6	6.08	1.4227
2014	9	24	12	24	10	0.3	1	0.25	68.7	6.08	1.2646
2014	9	24	12	34	10	0.3	1	0.26	84.3	6.08	1.4051
2014	9	24	12	44	10	0.3	1	0.28	90	6.08	1.4929
2014	9	24	12	54	10	0.3	1	0.2	88.1	6.08	1.0714
2014	9	24	13	4	10	0.3	1	0.26	82.9	6.0606	1.4003
2014	9	24	13	14	10	0.3	1	0.27	96.2	6.08	1.4578
2014	9	24	13	24	10	0.3	1	0.25	90.7	6.0606	1.3477
2014	9	24	13	34	10	0.3	1	0.3	84.3	6.08	1.5807
2014	9	24	13	44	10	0.3	1	0.3	88.7	6.0606	1.5753
2014	9	24	13	54	10	0.3	1	0.28	74.3	6.0606	1.4352
2014	9	24	14	4	10	0.3	1	0.27	72.9	6.0412	1.3605
2014	9	24	14	14	10	0.3	1	0.22	70.8	6.0606	1.1027
2014	9	24	14	24	10	0.3	1	0.27	77.5	6.0606	1.4177
2014	9	24	14	34	10	0.3	1	0.29	83.5	6.0606	1.5402
2014	9	24	14	44	10	0.3	1	0.25	87.8	6.0412	1.3431
2014	9	24	14	54	10	0.3	1	0.26	78.4	6.0412	1.3605
2014	9	24	15	4	10	0.3	1	0.29	69.3	6.0412	1.4303
2014	9	24	15	14	10	0.3	1	0.23	74.4	6.0606	1.1902
2014	9	24	15	24	10	0.3	1	0.31	90	6.0606	1.6277

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	15	34	10	0.3	1	0.26	73.7	6.0412	1.3082
2014	9	24	15	44	10	0.3	1	0.24	68.8	6.0412	1.1686
2014	9	24	15	54	10	0.3	1	0.29	84.9	6.0412	1.5524
2014	9	24	16	4	10	0.3	1	0.31	79.7	6.0412	1.6396
2014	9	24	16	14	10	0.3	1	0.3	83.7	6.0412	1.5698
2014	9	24	16	24	10	0.3	1	0.26	85.7	6.0412	1.3779
2014	9	24	16	34	10	0.3	1	0.27	71.6	6.0412	1.3605
2014	9	24	16	44	10	0.3	1	0.28	77.8	6.0219	1.4427
2014	9	24	16	54	10	0.3	1	0.26	70.9	6.0412	1.3082
2014	9	24	17	4	10	0.3	1	0.24	74.8	6.0219	1.2168
2014	9	24	17	14	10	0.3	1	0.25	75.8	6.0412	1.3082
2014	9	24	17	24	10	0.3	1	0.24	68.1	6.0219	1.1646
2014	9	24	17	34	10	0.3	1	0.27	72.9	6.0219	1.3558
2014	9	24	17	44	10	0.3	1	0.3	57.9	6.0219	1.3558
2014	9	24	17	54	10	0.3	1	0.25	65.5	6.0219	1.182
2014	9	24	18	4	10	0.3	1	0.22	75.3	6.0219	1.1299
2014	9	24	18	14	10	0.3	1	0.31	70	6.0219	1.5296
2014	9	24	18	24	10	0.3	1	0.33	84.2	6.0412	1.7268
2014	9	24	18	34	10	0.3	1	0.25	81.7	6.0412	1.3082
2014	9	24	18	44	10	0.3	1	0.25	81.8	6.0219	1.3211
2014	9	24	18	54	10	0.3	1	0.29	93.9	6.0412	1.5349
2014	9	24	19	4	10	0.3	1	0.24	83	6.0412	1.2733
2014	9	24	19	14	10	0.3	1	0.23	97.3	6.0412	1.221
2014	9	24	19	24	10	0.3	1	0.21	80.2	6.0606	1.1202
2014	9	24	19	34	10	0.3	1	0.25	94.5	6.0606	1.3477
2014	9	24	19	44	10	0.3	1	0.26	75.4	6.08	1.3523
2014	9	24	19	54	10	0.3	1	0.18	92	6.08	0.9835
2014	9	24	20	4	10	0.3	1	0.24	103.7	6.08	1.2294
2014	9	24	20	14	10	0.3	1	0.2	90.9	6.08	1.0889
2014	9	24	20	24	10	0.3	1	0.32	91.8	6.08	1.686
2014	9	24	20	34	10	0.3	1	0.28	92	6.08	1.4753
2014	9	24	20	44	10	0.3	1	0.23	102.3	6.08	1.2118
2014	9	24	20	54	10	0.3	1	0.32	102.3	6.08	1.6861
2014	9	24	21	4	10	0.3	1	0.25	102.2	6.08	1.2997
2014	9	24	21	14	10	0.3	1	0.27	100.4	6.08	1.4402
2014	9	24	21	24	10	0.3	1	0.28	96.8	6.08	1.4753
2014	9	24	21	34	10	0.3	1	0.29	75.5	6.08	1.4929
2014	9	24	21	44	10	0.3	1	0.22	88.3	6.08	1.1592
2014	9	24	21	54	10	0.3	1	0.25	91.5	6.08	1.3348
2014	9	24	22	4	10	0.3	1	0.21	90	6.08	1.1065
2014	9	24	22	14	10	0.3	1	0.25	98.3	6.08	1.3173
2014	9	24	22	24	10	0.3	1	0.34	87.3	6.08	1.8442
2014	9	24	22	34	10	0.3	1	0.23	85.9	6.0993	1.2337
2014	9	24	22	44	10	0.3	1	0.28	98.2	6.0993	1.4628
2014	9	24	22	54	10	0.3	1	0.25	95.3	6.08	1.3348
2014	9	24	23	4	10	0.3	1	0.22	109.8	6.0993	1.1279

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	23	14	10	0.3	1	0.28	87.3	6.0993	1.498
2014	9	24	23	24	10	0.3	1	0.21	104.7	6.0993	1.075
2014	9	24	23	34	10	0.3	1	0.22	95.1	6.0993	1.1808
2014	9	24	23	44	10	0.3	1	0.26	94.3	6.0993	1.3923
2014	9	24	23	54	10	0.3	1	0.23	103.4	6.0993	1.1808
2014	9	25	0	4	10	0.3	1	0.27	104.5	6.0993	1.4275
2014	9	25	0	14	10	0.3	1	0.25	95.3	6.0993	1.3394
2014	9	25	0	24	10	0.3	1	0.3	85.6	6.0993	1.6038
2014	9	25	0	34	10	0.3	1	0.3	100.1	6.0993	1.5861
2014	9	25	0	44	10	0.3	1	0.2	107.2	6.0993	1.0222
2014	9	25	0	54	10	0.3	1	0.26	85.7	6.0993	1.4099
2014	9	25	1	4	10	0.3	1	0.24	99.3	6.0993	1.2865
2014	9	25	1	14	10	0.3	1	0.33	92.9	6.0993	1.7448
2014	9	25	1	24	10	0.3	1	0.25	77.8	6.0993	1.3042
2014	9	25	1	34	10	0.3	1	0.28	94	6.0993	1.498
2014	9	25	1	44	10	0.3	1	0.29	99.8	6.0993	1.5333
2014	9	25	1	54	10	0.3	1	0.26	90	6.0993	1.3923
2014	9	25	2	4	10	0.3	1	0.23	90	6.0993	1.2161
2014	9	25	2	14	10	0.3	1	0.24	109.4	6.0993	1.1984
2014	9	25	2	24	10	0.3	1	0.31	96.7	6.0993	1.6567
2014	9	25	2	34	10	0.3	1	0.2	95.5	6.0993	1.0927
2014	9	25	2	44	10	0.3	1	0.32	93.5	6.1187	1.7154
2014	9	25	2	54	10	0.3	1	0.26	91.5	6.0993	1.3747
2014	9	25	3	4	10	0.3	1	0.24	90	6.0993	1.2866
2014	9	25	3	14	10	0.3	1	0.29	97	6.0993	1.5685
2014	9	25	3	24	10	0.3	1	0.23	85.9	6.1187	1.2202
2014	9	25	3	34	10	0.3	1	0.27	97.7	6.0993	1.4276
2014	9	25	3	44	10	0.3	1	0.22	90.9	6.1187	1.1848
2014	9	25	3	54	10	0.3	1	0.26	90.7	6.1187	1.3794
2014	9	25	4	4	10	0.3	1	0.24	87.6	6.1187	1.2733
2014	9	25	4	14	10	0.3	1	0.19	100.9	6.1187	1.008
2014	9	25	4	24	10	0.3	1	0.27	103.5	6.1187	1.3971
2014	9	25	4	34	10	0.3	1	0.29	91.9	6.1187	1.5739
2014	9	25	4	44	10	0.3	1	0.24	90	6.1187	1.3086
2014	9	25	4	54	10	0.3	1	0.23	98.1	6.1187	1.2379
2014	9	25	5	4	10	0.3	1	0.23	86.7	6.1187	1.2202
2014	9	25	5	14	10	0.3	1	0.17	80	6.1187	0.9019
2014	9	25	5	24	10	0.3	1	0.27	89.3	6.1187	1.4501
2014	9	25	5	34	10	0.3	1	0.22	90	6.1187	1.2025
2014	9	25	5	44	10	0.3	1	0.27	108.4	6.1187	1.3794
2014	9	25	5	54	10	0.3	1	0.26	86.3	6.1187	1.3794
2014	9	25	6	4	10	0.3	1	0.23	100.8	6.1187	1.2025
2014	9	25	6	14	10	0.3	1	0.3	86.3	6.1187	1.627
2014	9	25	6	24	10	0.3	1	0.17	86.7	6.1187	0.9196
2014	9	25	6	34	10	0.3	1	0.26	95.1	6.1187	1.3794
2014	9	25	6	44	10	0.3	1	0.23	95.6	6.1187	1.2556

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	6	54	10	0.3	1	0.31	102.9	6.1187	1.627
2014	9	25	7	4	10	0.3	1	0.19	114	6.1187	0.955
2014	9	25	7	14	10	0.3	1	0.23	81.1	6.1187	1.2379
2014	9	25	7	24	10	0.3	1	0.25	66.1	6.1187	1.2379
2014	9	25	7	34	10	0.3	1	0.23	104.8	6.1187	1.2026
2014	9	25	7	44	10	0.3	1	0.28	98.9	6.1187	1.4678
2014	9	25	7	54	10	0.3	1	0.25	90	6.1187	1.344
2014	9	25	8	4	10	0.3	1	0.23	90	6.1187	1.2556
2014	9	25	8	14	10	0.3	1	0.19	109.4	6.1187	0.955
2014	9	25	8	24	10	0.3	1	0.23	92.5	6.1187	1.2379
2014	9	25	8	34	10	0.3	1	0.24	91.6	6.1187	1.2733
2014	9	25	8	44	10	0.3	1	0.22	111.6	6.1187	1.1141
2014	9	25	8	54	10	0.3	1	0.24	91.6	6.1187	1.2733
2014	9	25	9	4	10	0.3	1	0.25	95.3	6.1187	1.344
2014	9	25	9	14	10	0.3	1	0.26	98.6	6.0993	1.3923
2014	9	25	9	24	10	0.3	1	0.26	101.7	6.0993	1.3571
2014	9	25	9	34	10	0.3	1	0.26	100.2	6.0993	1.3747
2014	9	25	9	44	10	0.3	1	0.29	88.7	6.0993	1.5509
2014	9	25	9	54	10	0.3	1	0.31	94.3	6.0993	1.6567
2014	9	25	10	4	10	0.3	1	0.24	79.8	6.0993	1.2689
2014	9	25	10	14	10	0.3	1	0.24	90	6.0993	1.2866
2014	9	25	10	24	10	0.3	1	0.29	83.6	6.08	1.5632
2014	9	25	10	34	10	0.3	1	0.31	65.6	6.0993	1.5157
2014	9	25	10	44	10	0.3	1	0.26	83.5	6.0993	1.3923
2014	9	25	10	54	10	0.3	1	0.3	85.6	6.0993	1.6038
2014	9	25	11	4	10	0.3	1	0.26	83.4	6.0993	1.3747
2014	9	25	11	14	10	0.3	1	0.27	76.8	6.0993	1.4276
2014	9	25	11	24	10	0.3	1	0.27	99	6.0993	1.4452
2014	9	25	11	34	10	0.3	1	0.29	83.5	6.0993	1.5509
2014	9	25	11	44	10	0.3	1	0.25	80.2	6.0993	1.3218
2014	9	25	11	54	10	0.3	1	0.38	86.1	6.08	2.0374
2014	9	25	12	4	10	0.3	1	0.3	90.6	6.0993	1.6214
2014	9	25	12	14	10	0.3	1	0.3	86.9	6.0993	1.6038
2014	9	25	12	24	10	0.3	1	0.3	64.8	6.08	1.4578
2014	9	25	12	34	10	0.3	1	0.3	76.6	6.0993	1.5509
2014	9	25	12	44	10	0.3	1	0.34	86.6	6.08	1.7915
2014	9	25	12	54	10	0.3	1	0.23	79.5	6.08	1.2294
2014	9	25	13	4	10	0.3	1	0.26	65.4	6.08	1.2646
2014	9	25	13	14	10	0.3	1	0.24	74.8	6.0606	1.2252
2014	9	25	13	24	10	0.3	1	0.33	66.2	6.0606	1.6278
2014	9	25	13	34	10	0.3	1	0.24	89.2	6.0606	1.2952
2014	9	25	13	44	10	0.3	1	0.26	82.1	6.0412	1.378
2014	9	25	13	54	10	0.3	1	0.3	72	6.0412	1.5001
2014	9	25	14	4	10	0.3	1	0.37	72	6.0606	1.8903
2014	9	25	14	14	10	0.3	1	0.25	66.5	6.0412	1.2035
2014	9	25	14	24	10	0.3	1	0.3	72.2	6.0219	1.5123

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	14	34	10	0.3	1	0.27	58.8	6.0412	1.2384
2014	9	25	14	44	10	0.3	1	0.28	76.6	6.0219	1.4601
2014	9	25	14	54	10	0.3	1	0.26	71.1	6.0219	1.3211
2014	9	25	15	4	10	0.3	1	0.28	76	6.0025	1.4551
2014	9	25	15	14	10	0.3	1	0.3	71.8	6.0219	1.5297
2014	9	25	15	24	10	0.3	1	0.29	60.8	6.0025	1.3338
2014	9	25	15	34	10	0.3	1	0.28	68.2	6.0025	1.3858
2014	9	25	15	44	10	0.3	1	0.27	75.3	6.0025	1.3858
2014	9	25	15	54	10	0.3	1	0.31	63.2	5.9832	1.4673
2014	9	25	16	4	10	0.3	1	0.31	72.9	5.9832	1.5709
2014	9	25	16	14	10	0.3	1	0.31	61.8	5.9832	1.4155
2014	9	25	16	24	10	0.3	1	0.31	61.5	5.9832	1.4328
2014	9	25	16	34	10	0.3	1	0.3	67.4	5.9832	1.45
2014	9	25	16	44	10	0.3	1	0.24	76	5.9832	1.2429
2014	9	25	16	54	10	0.3	1	0.26	66.3	5.9832	1.2601
2014	9	25	17	4	10	0.3	1	0.28	70.1	5.9832	1.381
2014	9	25	17	14	10	0.3	1	0.24	79.1	5.9832	1.2601
2014	9	25	17	24	10	0.3	1	0.29	63.4	5.9832	1.3464
2014	9	25	17	34	10	0.3	1	0.31	56.6	5.9638	1.359
2014	9	25	17	44	10	0.3	1	0.3	69.4	5.9832	1.4673
2014	9	25	17	54	10	0.3	1	0.23	80.9	5.9832	1.1911
2014	9	25	18	4	10	0.3	1	0.22	84.1	5.9638	1.1697
2014	9	25	18	14	10	0.3	1	0.25	89.2	5.9832	1.3119
2014	9	25	18	24	10	0.3	1	0.28	63.7	5.9832	1.3292
2014	9	25	18	34	10	0.3	1	0.27	89.3	5.9832	1.4328
2014	9	25	18	44	10	0.3	1	0.25	86.9	5.9638	1.2902
2014	9	25	18	54	10	0.3	1	0.32	83.6	5.9638	1.6858
2014	9	25	19	4	10	0.3	1	0.26	84.9	5.9832	1.3465
2014	9	25	19	14	10	0.3	1	0.27	84.4	5.9638	1.3934
2014	9	25	19	24	10	0.3	1	0.24	105	5.9832	1.2256
2014	9	25	19	34	10	0.3	1	0.22	91.7	5.9832	1.1393
2014	9	25	19	44	10	0.3	1	0.17	76.2	5.9832	0.8459
2014	9	25	19	54	10	0.3	1	0.2	82.3	5.9832	1.0185
2014	9	25	20	4	10	0.3	1	0.23	94.8	5.9832	1.2256
2014	9	25	20	14	10	0.3	1	0.22	101	5.9832	1.1566
2014	9	25	20	24	10	0.3	1	0.29	92.6	5.9832	1.5191
2014	9	25	20	34	10	0.3	1	0.29	95.1	5.9832	1.5364
2014	9	25	20	44	10	0.3	1	0.27	90	5.9832	1.4155
2014	9	25	20	54	10	0.3	1	0.26	94.3	5.9832	1.3637
2014	9	25	21	4	10	0.3	1	0.22	99.6	5.9832	1.1221
2014	9	25	21	14	10	0.3	1	0.26	90	5.9832	1.3465
2014	9	25	21	24	10	0.3	1	0.29	106.2	5.9832	1.4846
2014	9	25	21	34	10	0.3	1	0.19	82	6.0025	0.9874
2014	9	25	21	44	10	0.3	1	0.18	80.4	6.0025	0.9181
2014	9	25	21	54	10	0.3	1	0.24	83.7	6.0025	1.2473
2014	9	25	22	4	10	0.3	1	0.21	81.1	6.0219	1.1125

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	22	14	10	0.3	1	0.27	97	6.0219	1.408
2014	9	25	22	24	10	0.3	1	0.25	113.6	6.0219	1.2342
2014	9	25	22	34	10	0.3	1	0.25	98.2	6.0219	1.3211
2014	9	25	22	44	10	0.3	1	0.19	105.7	6.0219	0.9908
2014	9	25	22	54	10	0.3	1	0.22	118.9	6.0219	1.0082
2014	9	25	23	4	10	0.3	1	0.23	91.6	6.0412	1.2385
2014	9	25	23	14	10	0.3	1	0.27	102.7	6.0412	1.3955
2014	9	25	23	24	10	0.3	1	0.23	85.9	6.0412	1.221
2014	9	25	23	34	10	0.3	1	0.24	101.8	6.0606	1.2602
2014	9	25	23	44	10	0.3	1	0.23	100.7	6.0412	1.2036
2014	9	25	23	54	10	0.3	1	0.28	96	6.0412	1.4827
2014	9	26	0	4	10	0.3	1	0.22	107.6	6.0412	1.0989
2014	9	26	0	14	10	0.3	1	0.23	79.5	6.0412	1.221
2014	9	26	0	24	10	0.3	1	0.29	90	6.0412	1.5176
2014	9	26	0	34	10	0.3	1	0.28	101.6	6.0606	1.4528
2014	9	26	0	44	10	0.3	1	0.27	102.8	6.0606	1.3828
2014	9	26	0	54	10	0.3	1	0.22	82.2	6.0606	1.1552
2014	9	26	1	4	10	0.3	1	0.28	96	6.0606	1.5053
2014	9	26	1	14	10	0.3	1	0.32	92.3	6.0606	1.7154
2014	9	26	1	24	10	0.3	1	0.21	99.2	6.0606	1.0852
2014	9	26	1	34	10	0.3	1	0.19	101.1	6.0606	0.9802
2014	9	26	1	44	10	0.3	1	0.16	102.7	6.0606	0.8577
2014	9	26	1	54	10	0.3	1	0.19	77.2	6.0606	0.9977
2014	9	26	2	4	10	0.3	1	0.22	90	6.0606	1.1552
2014	9	26	2	14	10	0.3	1	0.35	76	6.0606	1.8204
2014	9	26	2	24	10	0.3	1	0.22	90.9	6.0606	1.1728
2014	9	26	2	34	10	0.3	1	0.28	93.4	6.0606	1.4703
2014	9	26	2	44	10	0.3	1	0.24	93.9	6.0606	1.2953
2014	9	26	2	54	10	0.3	1	0.29	82.2	6.0606	1.5403
2014	9	26	3	4	10	0.3	1	0.26	84.9	6.0606	1.3653
2014	9	26	3	14	10	0.3	1	0.28	82.1	6.0606	1.5053
2014	9	26	3	24	10	0.3	1	0.26	101	6.08	1.3524
2014	9	26	3	34	10	0.3	1	0.15	94.9	6.0606	0.8227
2014	9	26	3	44	10	0.3	1	0.28	104.4	6.0606	1.4353
2014	9	26	3	54	10	0.3	1	0.22	85.7	6.08	1.1768
2014	9	26	4	4	10	0.3	1	0.23	91.7	6.08	1.2119
2014	9	26	4	14	10	0.3	1	0.31	101.5	6.0606	1.6279
2014	9	26	4	24	10	0.3	1	0.24	102.5	6.08	1.2646
2014	9	26	4	34	10	0.3	1	0.26	82.7	6.08	1.37
2014	9	26	4	44	10	0.3	1	0.24	86.9	6.08	1.2997
2014	9	26	4	54	10	0.3	1	0.29	91.9	6.08	1.5632
2014	9	26	5	4	10	0.3	1	0.25	90	6.08	1.3524
2014	9	26	5	14	10	0.3	1	0.23	102.6	6.08	1.1768
2014	9	26	5	24	10	0.3	1	0.18	90	6.08	0.966
2014	9	26	5	34	10	0.3	1	0.3	113.8	6.08	1.4754
2014	9	26	5	44	10	0.3	1	0.27	88.6	6.08	1.4578

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	5	54	10	0.3	1	0.2	90	6.08	1.0714
2014	9	26	6	4	10	0.3	1	0.22	94.2	6.08	1.1944
2014	9	26	6	14	10	0.3	1	0.21	78.3	6.08	1.1065
2014	9	26	6	24	10	0.3	1	0.24	90.8	6.08	1.2646
2014	9	26	6	34	10	0.3	1	0.3	98.9	6.08	1.5632
2014	9	26	6	44	10	0.3	1	0.3	86.3	6.08	1.6159
2014	9	26	6	54	10	0.3	1	0.19	70	6.08	0.966
2014	9	26	7	4	10	0.3	1	0.21	94.5	6.08	1.1241
2014	9	26	7	14	10	0.3	1	0.27	87.2	6.08	1.4578
2014	9	26	7	24	10	0.3	1	0.2	91	6.08	1.0539
2014	9	26	7	34	10	0.3	1	0.2	99.5	6.08	1.0539
2014	9	26	7	44	10	0.3	1	0.26	90.7	6.08	1.4052
2014	9	26	7	54	10	0.3	1	0.24	107.2	6.08	1.2471
2014	9	26	8	4	10	0.3	1	0.19	105.9	6.08	0.9836
2014	9	26	8	14	10	0.3	1	0.24	106.7	6.08	1.2295
2014	9	26	8	24	10	0.3	1	0.23	99.2	6.08	1.1944
2014	9	26	8	34	10	0.3	1	0.23	105	6.08	1.1768
2014	9	26	8	44	10	0.3	1	0.16	90	6.08	0.8607
2014	9	26	8	54	10	0.3	1	0.18	100.3	6.08	0.966
2014	9	26	9	4	10	0.3	1	0.22	101	6.08	1.1768
2014	9	26	9	14	10	0.3	1	0.3	94.4	6.08	1.5984
2014	9	26	9	24	10	0.3	1	0.22	89.2	6.08	1.1944
2014	9	26	9	34	10	0.3	1	0.24	86	6.08	1.2646
2014	9	26	9	44	10	0.3	1	0.2	102.2	6.08	1.0539
2014	9	26	9	54	10	0.3	1	0.27	92.1	6.08	1.4403
2014	9	26	10	4	10	0.3	1	0.22	90.9	6.08	1.1768
2014	9	26	10	14	10	0.3	1	0.21	107.3	6.08	1.0714
2014	9	26	10	24	10	0.3	1	0.2	92.8	6.08	1.089
2014	9	26	10	34	10	0.3	1	0.23	81.8	6.08	1.2119
2014	9	26	10	44	10	0.3	1	0.26	98.7	6.0606	1.3653
2014	9	26	10	54	10	0.3	1	0.24	90.8	6.08	1.2822
2014	9	26	11	4	10	0.3	1	0.24	95.5	6.08	1.2822
2014	9	26	11	14	10	0.3	1	0.29	86.7	6.08	1.5281
2014	9	26	11	24	10	0.3	1	0.29	101.7	6.08	1.5281
2014	9	26	11	34	10	0.3	1	0.25	87	6.0606	1.3303
2014	9	26	11	44	10	0.3	1	0.22	81.3	6.0606	1.1377
2014	9	26	11	54	10	0.3	1	0.33	90.6	6.0606	1.7854
2014	9	26	12	4	10	0.3	1	0.31	80.3	6.0606	1.6454
2014	9	26	12	14	10	0.3	1	0.29	83.4	6.0412	1.5176
2014	9	26	12	24	10	0.3	1	0.22	73.2	6.0412	1.0989
2014	9	26	12	34	10	0.3	1	0.29	80.2	6.0412	1.5176
2014	9	26	12	44	10	0.3	1	0.25	93.8	6.0412	1.3257
2014	9	26	12	54	10	0.3	1	0.27	87.9	6.0412	1.4304
2014	9	26	13	4	10	0.3	1	0.23	83.4	6.0412	1.2036
2014	9	26	13	14	10	0.3	1	0.27	78.7	6.0412	1.3955
2014	9	26	13	24	10	0.3	1	0.32	81.1	6.0219	1.6688

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	13	34	10	0.3	1	0.3	86.2	6.0025	1.5764
2014	9	26	13	44	10	0.3	1	0.29	73.8	6.0219	1.4949
2014	9	26	13	54	10	0.3	1	0.34	75.4	6.0025	1.7323
2014	9	26	14	4	10	0.3	1	0.25	73.7	6.0025	1.2473
2014	9	26	14	14	10	0.3	1	0.24	76.5	6.0025	1.2299
2014	9	26	14	24	10	0.3	1	0.28	75.6	5.9832	1.4156
2014	9	26	14	34	10	0.3	1	0.28	68.2	5.9832	1.381
2014	9	26	14	44	10	0.3	1	0.27	70.9	5.9832	1.3465
2014	9	26	14	54	10	0.3	1	0.24	80.7	5.9638	1.2558
2014	9	26	15	4	10	0.3	1	0.28	78.7	5.9832	1.4673
2014	9	26	15	14	10	0.3	1	0.23	66.7	5.9638	1.1182
2014	9	26	15	24	10	0.3	1	0.31	74.1	5.9638	1.5654
2014	9	26	15	34	10	0.3	1	0.23	72.6	5.9445	1.1486
2014	9	26	15	44	10	0.3	1	0.33	64.5	5.9638	1.5482
2014	9	26	15	54	10	0.3	1	0.26	83.6	5.9638	1.3762
2014	9	26	16	4	10	0.3	1	0.31	73.9	5.9445	1.5428
2014	9	26	16	14	10	0.3	1	0.21	71.3	5.9638	1.0666
2014	9	26	16	24	10	0.3	1	0.3	73.4	5.9638	1.4966
2014	9	26	16	34	10	0.3	1	0.27	79.5	5.9445	1.3885
2014	9	26	16	44	10	0.3	1	0.28	80	5.9445	1.4571
2014	9	26	16	54	10	0.3	1	0.21	71.3	5.9638	1.0666
2014	9	26	17	4	10	0.3	1	0.22	81.4	5.9638	1.1354
2014	9	26	17	14	10	0.3	1	0.29	68.4	5.9445	1.3886
2014	9	26	17	24	10	0.3	1	0.27	78.8	5.9638	1.3934
2014	9	26	17	34	10	0.3	1	0.25	73.2	5.9638	1.2558
2014	9	26	17	44	10	0.3	1	0.32	70.3	5.9445	1.5771
2014	9	26	17	54	10	0.3	1	0.26	68.9	5.9638	1.2902
2014	9	26	18	4	10	0.3	1	0.29	83.6	5.9638	1.531
2014	9	26	18	14	10	0.3	1	0.25	74.9	5.9445	1.2686
2014	9	26	18	24	10	0.3	1	0.31	78.9	5.9638	1.5827
2014	9	26	18	34	10	0.3	1	0.28	71.6	5.9445	1.3886
2014	9	26	18	44	10	0.3	1	0.28	76	5.9445	1.44
2014	9	26	18	54	10	0.3	1	0.2	89.1	5.9445	1.0629
2014	9	26	19	4	10	0.3	1	0.2	94.8	5.9445	1.0286
2014	9	26	19	14	10	0.3	1	0.25	85.4	5.9445	1.2857
2014	9	26	19	24	10	0.3	1	0.25	88.5	5.9445	1.3029
2014	9	26	19	34	10	0.3	1	0.29	86.7	5.9445	1.4914
2014	9	26	19	44	10	0.3	1	0.2	84.5	5.9638	1.0666
2014	9	26	19	54	10	0.3	1	0.26	87.1	5.9638	1.3762
2014	9	26	20	4	10	0.3	1	0.32	87.6	5.9445	1.6457
2014	9	26	20	14	10	0.3	1	0.26	87.1	5.9445	1.3543
2014	9	26	20	24	10	0.3	1	0.24	82.1	5.9638	1.2386
2014	9	26	20	34	10	0.3	1	0.28	105.7	5.9638	1.4107
2014	9	26	20	44	10	0.3	1	0.29	93.9	5.9638	1.5311
2014	9	26	20	54	10	0.3	1	0.21	95.4	5.9638	1.0838
2014	9	26	21	4	10	0.3	1	0.24	99.3	5.9638	1.2558

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	21	14	10	0.3	1	0.25	85.4	5.9638	1.2903
2014	9	26	21	24	10	0.3	1	0.3	85.6	5.9638	1.5483
2014	9	26	21	34	10	0.3	1	0.19	91	5.9638	0.9806
2014	9	26	21	44	10	0.3	1	0.28	98.2	5.9638	1.4279
2014	9	26	21	54	10	0.3	1	0.26	95.1	5.9638	1.3591
2014	9	26	22	4	10	0.3	1	0.19	102.1	5.9638	0.9634
2014	9	26	22	14	10	0.3	1	0.27	109.7	5.9638	1.3419
2014	9	26	22	24	10	0.3	1	0.26	102.6	5.9638	1.3075
2014	9	26	22	34	10	0.3	1	0.25	102.4	5.9638	1.2559
2014	9	26	22	44	10	0.3	1	0.25	90	5.9638	1.3247
2014	9	26	22	54	10	0.3	1	0.19	108.1	5.9832	0.9495
2014	9	26	23	4	10	0.3	1	0.22	98.6	5.9832	1.1394
2014	9	26	23	14	10	0.3	1	0.19	89	5.9832	0.984
2014	9	26	23	24	10	0.3	1	0.24	104.4	5.9832	1.2085
2014	9	26	23	34	10	0.3	1	0.25	107.7	5.9832	1.243
2014	9	26	23	44	10	0.3	1	0.23	98.2	5.9832	1.1912
2014	9	26	23	54	10	0.3	1	0.25	83.9	5.9832	1.2948
2014	9	27	0	4	10	0.3	1	0.21	96.2	5.9832	1.1049
2014	9	27	0	14	10	0.3	1	0.18	105.1	5.9832	0.8977
2014	9	27	0	24	10	0.3	1	0.18	95.2	5.9832	0.9495
2014	9	27	0	34	10	0.3	1	0.23	98.2	6.0025	1.1954
2014	9	27	0	44	10	0.3	1	0.21	103.6	5.9832	1.0704
2014	9	27	0	54	10	0.3	1	0.26	90	5.9832	1.3639
2014	9	27	1	4	10	0.3	1	0.22	109	6.0025	1.1088
2014	9	27	1	14	10	0.3	1	0.26	103.9	6.0025	1.334
2014	9	27	1	24	10	0.3	1	0.23	102.6	5.9832	1.1567
2014	9	27	1	34	10	0.3	1	0.26	104.6	6.0025	1.334
2014	9	27	1	44	10	0.3	1	0.24	93.1	6.0025	1.282
2014	9	27	1	54	10	0.3	1	0.23	95.6	6.0025	1.23
2014	9	27	2	4	10	0.3	1	0.16	102	6.0025	0.8143
2014	9	27	2	14	10	0.3	1	0.23	93.2	6.0219	1.2343
2014	9	27	2	24	10	0.3	1	0.28	103	6.0025	1.4206
2014	9	27	2	34	10	0.3	1	0.32	104	6.0219	1.6689
2014	9	27	2	44	10	0.3	1	0.25	114.5	6.0025	1.1781
2014	9	27	2	54	10	0.3	1	0.18	96.1	6.0219	0.9735
2014	9	27	3	4	10	0.3	1	0.26	92.2	6.0219	1.356
2014	9	27	3	14	10	0.3	1	0.25	103.9	6.0219	1.2691
2014	9	27	3	24	10	0.3	1	0.19	106.9	6.0219	0.9735
2014	9	27	3	34	10	0.3	1	0.17	105.9	6.0219	0.8518
2014	9	27	3	44	10	0.3	1	0.25	90.8	6.0219	1.3038
2014	9	27	3	54	10	0.3	1	0.27	97	6.0219	1.4082
2014	9	27	4	4	10	0.3	1	0.23	103.8	6.0219	1.1995
2014	9	27	4	14	10	0.3	1	0.23	90	6.0219	1.1995
2014	9	27	4	24	10	0.3	1	0.14	99.7	6.0219	0.7128
2014	9	27	4	34	10	0.3	1	0.2	75.7	6.0025	1.0222
2014	9	27	4	44	10	0.3	1	0.22	104.9	6.0025	1.1088

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	4	54	10	0.3	1	0.23	90	6.0025	1.1954
2014	9	27	5	4	10	0.3	1	0.24	101.9	6.0025	1.2301
2014	9	27	5	14	10	0.3	1	0.22	98.5	6.0025	1.1608
2014	9	27	5	24	10	0.3	1	0.22	75.6	6.0219	1.1474
2014	9	27	5	34	10	0.3	1	0.27	85.8	6.0219	1.4082
2014	9	27	5	44	10	0.3	1	0.24	73.5	6.0219	1.2343
2014	9	27	5	54	10	0.3	1	0.24	86	6.0219	1.2517
2014	9	27	6	4	10	0.3	1	0.24	101.8	6.0219	1.2517
2014	9	27	6	14	10	0.3	1	0.19	116.6	6.0219	0.904
2014	9	27	6	24	10	0.3	1	0.13	77.3	6.0219	0.6954
2014	9	27	6	34	10	0.3	1	0.2	94.7	6.0219	1.0605
2014	9	27	6	44	10	0.3	1	0.2	81.5	6.0412	1.0467
2014	9	27	6	54	10	0.3	1	0.21	96.1	6.0219	1.13
2014	9	27	7	4	10	0.3	1	0.26	85.7	6.0219	1.3908
2014	9	27	7	14	10	0.3	1	0.25	97.4	6.0412	1.3433
2014	9	27	7	24	10	0.3	1	0.24	86.9	6.0412	1.2735
2014	9	27	7	34	10	0.3	1	0.23	107.2	6.0412	1.1863
2014	9	27	7	44	10	0.3	1	0.26	87.1	6.0412	1.3956
2014	9	27	7	54	10	0.3	1	0.25	95.2	6.0219	1.3387
2014	9	27	8	4	10	0.3	1	0.21	80.8	6.0219	1.0779
2014	9	27	8	14	10	0.3	1	0.23	98.1	6.0219	1.217
2014	9	27	8	24	10	0.3	1	0.17	90	6.0412	0.9072
2014	9	27	8	34	10	0.3	1	0.19	101.9	6.0219	0.991
2014	9	27	8	44	10	0.3	1	0.23	90	6.0219	1.1996
2014	9	27	8	54	10	0.3	1	0.2	90	6.0412	1.0467
2014	9	27	9	4	10	0.3	1	0.15	78.7	6.0219	0.7823
2014	9	27	9	14	10	0.3	1	0.19	95.9	6.0412	1.0118
2014	9	27	9	24	10	0.3	1	0.22	92.6	6.0219	1.1474
2014	9	27	9	34	10	0.3	1	0.16	81.9	6.0219	0.8519
2014	9	27	9	44	10	0.3	1	0.26	71.1	6.0219	1.3213
2014	9	27	9	54	10	0.3	1	0.2	78.5	6.0219	1.0257
2014	9	27	10	4	10	0.3	1	0.27	90.7	6.0219	1.4082
2014	9	27	10	14	10	0.3	1	0.22	82.2	6.0219	1.1474
2014	9	27	10	24	10	0.3	1	0.23	74.4	6.0412	1.1863
2014	9	27	10	34	10	0.3	1	0.18	73.9	6.0412	0.9072
2014	9	27	10	44	10	0.3	1	0.25	83.2	6.0219	1.3213
2014	9	27	10	54	10	0.3	1	0.28	89.3	6.0219	1.4951
2014	9	27	11	4	10	0.3	1	0.23	88.4	6.0219	1.217
2014	9	27	11	14	10	0.3	1	0.18	83.8	6.0412	0.9595
2014	9	27	11	24	10	0.3	1	0.3	83.1	6.0219	1.582
2014	9	27	11	34	10	0.3	1	0.28	84	6.0219	1.4777
2014	9	27	11	44	10	0.3	1	0.27	70.7	6.0219	1.3386
2014	9	27	11	54	10	0.3	1	0.2	78	6.0219	1.0605
2014	9	27	12	4	10	0.3	1	0.28	84	6.0219	1.4951
2014	9	27	12	14	10	0.3	1	0.2	84.5	6.0219	1.0778
2014	9	27	12	24	10	0.3	1	0.21	75.7	6.0219	1.0952

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	12	34	10	0.3	1	0.2	91	6.0219	1.0431
2014	9	27	12	44	10	0.3	1	0.24	79.8	6.0219	1.2517
2014	9	27	12	54	10	0.3	1	0.24	76.5	6.0025	1.23
2014	9	27	13	4	10	0.3	1	0.23	67.8	5.9832	1.1394
2014	9	27	13	14	10	0.3	1	0.28	68.3	5.9832	1.3466
2014	9	27	13	24	10	0.3	1	0.28	73	5.9832	1.4157
2014	9	27	13	34	10	0.3	1	0.28	61.9	6.0025	1.2993
2014	9	27	13	44	10	0.3	1	0.25	66.1	5.9832	1.2085
2014	9	27	13	54	10	0.3	1	0.23	81.9	5.9832	1.2085
2014	9	27	14	4	10	0.3	1	0.18	87.9	6.0025	0.9355
2014	9	27	14	14	10	0.3	1	0.21	64.2	6.0025	1.0048
2014	9	27	14	24	10	0.3	1	0.18	60.1	6.0025	0.8142
2014	9	27	14	34	10	0.3	1	0.25	85.5	6.0025	1.3339
2014	9	27	14	44	10	0.3	1	0.22	65.7	6.0025	1.0741
2014	9	27	14	54	10	0.3	1	0.23	81.6	6.0025	1.178
2014	9	27	15	4	10	0.3	1	0.26	59.5	6.0025	1.178
2014	9	27	15	14	10	0.3	1	0.25	73.4	6.0025	1.282
2014	9	27	15	24	10	0.3	1	0.31	78.6	6.0025	1.6284
2014	9	27	15	34	10	0.3	1	0.26	69.5	6.0025	1.2993
2014	9	27	15	44	10	0.3	1	0.29	62.3	6.0025	1.3513
2014	9	27	15	54	10	0.3	1	0.25	68.7	6.0025	1.2473
2014	9	27	16	4	10	0.3	1	0.32	66	6.0025	1.5591
2014	9	27	16	14	10	0.3	1	0.26	82.7	6.0025	1.3513
2014	9	27	16	24	10	0.3	1	0.25	72.3	6.0025	1.2473
2014	9	27	16	34	10	0.3	1	0.24	73.8	6.0025	1.1953
2014	9	27	16	44	10	0.3	1	0.2	99.5	6.0025	1.0394
2014	9	27	16	54	10	0.3	1	0.22	86.6	6.0219	1.1647
2014	9	27	17	4	10	0.3	1	0.34	76.2	6.0219	1.7731
2014	9	27	17	14	10	0.3	1	0.23	58.6	6.0219	1.0256
2014	9	27	17	24	10	0.3	1	0.16	86.4	6.0219	0.8344
2014	9	27	17	34	10	0.3	1	0.23	79.2	6.0219	1.1821
2014	9	27	17	44	10	0.3	1	0.23	71.6	6.0219	1.1473
2014	9	27	17	54	10	0.3	1	0.29	81	6.0219	1.5298
2014	9	27	18	4	10	0.3	1	0.24	86	6.0412	1.256
2014	9	27	18	14	10	0.3	1	0.28	94.1	6.0412	1.4653
2014	9	27	18	24	10	0.3	1	0.27	79	6.0412	1.4304
2014	9	27	18	34	10	0.3	1	0.24	90.8	6.0412	1.256
2014	9	27	18	44	10	0.3	1	0.21	88.2	6.0412	1.1164
2014	9	27	18	54	10	0.3	1	0.25	99.8	6.0412	1.3083
2014	9	27	19	4	10	0.3	1	0.28	76.5	6.0412	1.4479
2014	9	27	19	14	10	0.3	1	0.23	97.4	6.0412	1.2036
2014	9	27	19	24	10	0.3	1	0.21	77.3	6.0412	1.0815
2014	9	27	19	34	10	0.3	1	0.19	86	6.0412	0.9943
2014	9	27	19	44	10	0.3	1	0.2	87.1	6.0412	1.0467
2014	9	27	19	54	10	0.3	1	0.19	97.9	6.0412	1.0118
2014	9	27	20	4	10	0.3	1	0.23	91.6	6.0412	1.2386

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	20	14	10	0.3	1	0.25	90	6.0412	1.3258
2014	9	27	20	24	10	0.3	1	0.16	75.7	6.0606	0.8227
2014	9	27	20	34	10	0.3	1	0.19	83.2	6.0412	1.0292
2014	9	27	20	44	10	0.3	1	0.22	89.2	6.0412	1.1862
2014	9	27	20	54	10	0.3	1	0.24	104.4	6.0412	1.2211
2014	9	27	21	4	10	0.3	1	0.22	87.4	6.0606	1.1553
2014	9	27	21	14	10	0.3	1	0.29	78.9	6.0412	1.5177
2014	9	27	21	24	10	0.3	1	0.25	95.2	6.0606	1.3479
2014	9	27	21	34	10	0.3	1	0.29	78.8	6.0606	1.5054
2014	9	27	21	44	10	0.3	1	0.23	94	6.0606	1.2428
2014	9	27	21	54	10	0.3	1	0.22	81.3	6.0606	1.1378
2014	9	27	22	4	10	0.3	1	0.21	113.4	6.0606	1.0503
2014	9	27	22	14	10	0.3	1	0.22	92.5	6.0606	1.1903
2014	9	27	22	24	10	0.3	1	0.24	90	6.0606	1.2954
2014	9	27	22	34	10	0.3	1	0.23	92.4	6.0606	1.2429
2014	9	27	22	44	10	0.3	1	0.28	97.4	6.0606	1.4879
2014	9	27	22	54	10	0.3	1	0.23	89.2	6.0606	1.2429
2014	9	27	23	4	10	0.3	1	0.23	94.1	6.0606	1.2079
2014	9	27	23	14	10	0.3	1	0.26	100.3	6.0606	1.3479
2014	9	27	23	24	10	0.3	1	0.28	96.1	6.0606	1.4704
2014	9	27	23	34	10	0.3	1	0.28	96	6.0606	1.5054
2014	9	27	23	44	10	0.3	1	0.31	106.5	6.0606	1.593
2014	9	27	23	54	10	0.3	1	0.31	105.4	6.0606	1.593
2014	9	28	0	4	10	0.3	1	0.23	80.1	6.0606	1.2079
2014	9	28	0	14	10	0.3	1	0.28	87.3	6.0606	1.5055
2014	9	28	0	24	10	0.3	1	0.27	94.2	6.0606	1.4179
2014	9	28	0	34	10	0.3	1	0.26	105.6	6.0606	1.3129
2014	9	28	0	44	10	0.3	1	0.26	104.4	6.0606	1.3654
2014	9	28	0	54	10	0.3	1	0.2	109.3	6.0606	0.9978
2014	9	28	1	4	10	0.3	1	0.23	93.3	6.0606	1.2079
2014	9	28	1	14	10	0.3	1	0.26	104.7	6.0606	1.3304
2014	9	28	1	24	10	0.3	1	0.23	79.5	6.0606	1.2254
2014	9	28	1	34	10	0.3	1	0.2	95.7	6.0606	1.0503
2014	9	28	1	44	10	0.3	1	0.29	101.1	6.0606	1.523
2014	9	28	1	54	10	0.3	1	0.25	101.3	6.0606	1.3129
2014	9	28	2	4	10	0.3	1	0.27	99.7	6.0606	1.4354
2014	9	28	2	14	10	0.3	1	0.31	103	6.08	1.5985
2014	9	28	2	24	10	0.3	1	0.27	104	6.0606	1.4004
2014	9	28	2	34	10	0.3	1	0.16	95.7	6.0606	0.8753
2014	9	28	2	44	10	0.3	1	0.25	88.5	6.0606	1.3479
2014	9	28	2	54	10	0.3	1	0.28	100.7	6.0606	1.488
2014	9	28	3	4	10	0.3	1	0.21	98.3	6.08	1.0891
2014	9	28	3	14	10	0.3	1	0.24	102.9	6.08	1.2296
2014	9	28	3	24	10	0.3	1	0.24	93.1	6.0606	1.2954
2014	9	28	3	34	10	0.3	1	0.26	108.4	6.08	1.3174
2014	9	28	3	44	10	0.3	1	0.29	90	6.08	1.5282

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	3	54	10	0.3	1	0.22	103.6	6.08	1.1593
2014	9	28	4	4	10	0.3	1	0.22	90	6.08	1.1769
2014	9	28	4	14	10	0.3	1	0.28	92	6.08	1.4931
2014	9	28	4	24	10	0.3	1	0.2	107.2	6.08	1.0188
2014	9	28	4	34	10	0.3	1	0.25	116.9	6.08	1.212
2014	9	28	4	44	10	0.3	1	0.23	98.1	6.08	1.2296
2014	9	28	4	54	10	0.3	1	0.27	100.5	6.08	1.4228
2014	9	28	5	4	10	0.3	1	0.24	100.1	6.08	1.2823
2014	9	28	5	14	10	0.3	1	0.22	112.3	6.08	1.0715
2014	9	28	5	24	10	0.3	1	0.27	94.2	6.08	1.4228
2014	9	28	5	34	10	0.3	1	0.22	103	6.08	1.1418
2014	9	28	5	44	10	0.3	1	0.23	102.4	6.08	1.1945
2014	9	28	5	54	10	0.3	1	0.3	94.4	6.08	1.5809
2014	9	28	6	4	10	0.3	1	0.25	90	6.08	1.3174
2014	9	28	6	14	10	0.3	1	0.25	113.2	6.08	1.2296
2014	9	28	6	24	10	0.3	1	0.27	92.1	6.08	1.4228
2014	9	28	6	34	10	0.3	1	0.25	112.9	6.08	1.2472
2014	9	28	6	44	10	0.3	1	0.29	100.5	6.08	1.5107
2014	9	28	6	54	10	0.3	1	0.22	100.2	6.08	1.1769
2014	9	28	7	4	10	0.3	1	0.23	99.1	6.08	1.212
2014	9	28	7	14	10	0.3	1	0.2	90	6.08	1.0891
2014	9	28	7	24	10	0.3	1	0.2	104.9	6.08	1.0539
2014	9	28	7	34	10	0.3	1	0.33	95.8	6.08	1.739
2014	9	28	7	44	10	0.3	1	0.18	99.5	6.08	0.9486
2014	9	28	7	54	10	0.3	1	0.13	72.9	6.08	0.6851
2014	9	28	8	4	10	0.3	1	0.18	87.9	6.08	0.9486
2014	9	28	8	14	10	0.3	1	0.21	88.2	6.08	1.1418
2014	9	28	8	24	10	0.3	1	0.23	102.1	6.08	1.2296
2014	9	28	8	34	10	0.3	1	0.18	91.1	6.08	0.9485
2014	9	28	8	44	10	0.3	1	0.22	72.6	6.08	1.1242
2014	9	28	8	54	10	0.3	1	0.3	65.4	6.08	1.458
2014	9	28	9	4	10	0.3	1	0.28	54.1	6.08	1.212
2014	9	28	9	14	10	0.3	1	0.26	53.1	6.08	1.1242
2014	9	28	9	24	10	0.3	1	0.25	64.4	6.0606	1.2079
2014	9	28	9	34	10	0.3	1	0.24	67.6	6.08	1.1945
2014	9	28	9	44	10	0.3	1	0.32	75.1	6.08	1.6512
2014	9	28	9	54	10	0.3	1	0.27	92.1	6.08	1.4579
2014	9	28	10	4	10	0.3	1	0.32	74.4	6.08	1.6336
2014	9	28	10	14	10	0.3	1	0.31	80.7	6.08	1.616
2014	9	28	10	24	10	0.3	1	0.33	76.1	6.08	1.7039
2014	9	28	10	34	10	0.3	1	0.25	75.1	6.08	1.3174
2014	9	28	10	44	10	0.3	1	0.34	70.9	6.0606	1.7155
2014	9	28	10	54	10	0.3	1	0.22	78	6.08	1.1593
2014	9	28	11	4	10	0.3	1	0.34	65.2	6.0606	1.628
2014	9	28	11	14	10	0.3	1	0.28	62.8	6.08	1.335
2014	9	28	11	24	10	0.3	1	0.32	72.9	6.08	1.6511

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	11	34	10	0.3	1	0.25	83.3	6.08	1.3525
2014	9	28	11	44	10	0.3	1	0.28	70.3	6.08	1.4228
2014	9	28	11	54	10	0.3	1	0.28	96	6.08	1.5106
2014	9	28	12	4	10	0.3	1	0.27	79.5	6.08	1.4228
2014	9	28	12	14	10	0.3	1	0.23	81.9	6.08	1.2295
2014	9	28	12	24	10	0.3	1	0.26	86.3	6.08	1.3701
2014	9	28	12	34	10	0.3	1	0.27	90	6.0606	1.4354
2014	9	28	12	44	10	0.3	1	0.29	90	6.08	1.5457
2014	9	28	12	54	10	0.3	1	0.33	87.7	6.0606	1.733
2014	9	28	13	4	10	0.3	1	0.27	70.3	6.0606	1.3654
2014	9	28	13	14	10	0.3	1	0.29	73.6	6.0606	1.4879
2014	9	28	13	24	10	0.3	1	0.27	77.9	6.0606	1.3828
2014	9	28	13	34	10	0.3	1	0.32	78	6.0606	1.6454
2014	9	28	13	44	10	0.3	1	0.23	67.1	6.0606	1.1203
2014	9	28	13	54	10	0.3	1	0.23	69.3	6.0606	1.1553
2014	9	28	14	4	10	0.3	1	0.24	88.4	6.0606	1.2778
2014	9	28	14	14	10	0.3	1	0.26	87.1	6.0606	1.3653
2014	9	28	14	24	10	0.3	1	0.29	84.9	6.0606	1.5579
2014	9	28	14	34	10	0.3	1	0.24	77.1	6.0606	1.2253
2014	9	28	14	44	10	0.3	1	0.19	83	6.0606	0.9977
2014	9	28	14	54	10	0.3	1	0.2	75.1	6.0606	1.0502
2014	9	28	15	4	10	0.3	1	0.27	94.8	6.0606	1.4528
2014	9	28	15	14	10	0.3	1	0.25	94.6	6.0606	1.3128
2014	9	28	15	24	10	0.3	1	0.24	83.1	6.0606	1.2953
2014	9	28	15	34	10	0.3	1	0.21	85.5	6.0606	1.1028
2014	9	28	15	44	10	0.3	1	0.26	84.9	6.0606	1.3653
2014	9	28	15	54	10	0.3	1	0.19	83.1	6.0606	1.0152
2014	9	28	16	4	10	0.3	1	0.22	80.4	6.0606	1.1378
2014	9	28	16	14	10	0.3	1	0.22	82.2	6.0606	1.1553
2014	9	28	16	24	10	0.3	1	0.27	73.1	6.0606	1.3828
2014	9	28	16	34	10	0.3	1	0.3	90	6.0606	1.5753
2014	9	28	16	44	10	0.3	1	0.22	84.1	6.0606	1.1903
2014	9	28	16	54	10	0.3	1	0.27	88.6	6.0412	1.4478
2014	9	28	17	4	10	0.3	1	0.27	88.6	6.0412	1.4129
2014	9	28	17	14	10	0.3	1	0.27	76.8	6.0412	1.4129
2014	9	28	17	24	10	0.3	1	0.21	79.4	6.0412	1.1164
2014	9	28	17	34	10	0.3	1	0.27	61.2	6.0606	1.2428
2014	9	28	17	44	10	0.3	1	0.25	64.8	6.0606	1.2253
2014	9	28	17	54	10	0.3	1	0.24	68.1	6.0606	1.1728
2014	9	28	18	4	10	0.3	1	0.31	65.9	6.0606	1.4878
2014	9	28	18	14	10	0.3	1	0.28	82.1	6.0606	1.5053
2014	9	28	18	24	10	0.3	1	0.23	76.6	6.0606	1.1728
2014	9	28	18	34	10	0.3	1	0.15	87.6	6.0606	0.8227
2014	9	28	18	44	10	0.3	1	0.25	81	6.0606	1.3303
2014	9	28	18	54	10	0.3	1	0.29	70.1	6.0606	1.4528
2014	9	28	19	4	10	0.3	1	0.21	96.3	6.0606	1.1028

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	19	14	10	0.3	1	0.24	90	6.0606	1.2953
2014	9	28	19	24	10	0.3	1	0.22	92.5	6.0606	1.1903
2014	9	28	19	34	10	0.3	1	0.22	96.7	6.0606	1.1903
2014	9	28	19	44	10	0.3	1	0.29	95.8	6.0606	1.5579
2014	9	28	19	54	10	0.3	1	0.31	87.6	6.0606	1.6454
2014	9	28	20	4	10	0.3	1	0.19	101.9	6.0606	0.9977
2014	9	28	20	14	10	0.3	1	0.3	86.3	6.0606	1.6104
2014	9	28	20	24	10	0.3	1	0.2	86.3	6.0606	1.0853
2014	9	28	20	34	10	0.3	1	0.23	94	6.0606	1.2428
2014	9	28	20	44	10	0.3	1	0.25	90	6.0606	1.3303
2014	9	28	20	54	10	0.3	1	0.24	101.8	6.0606	1.2603
2014	9	28	21	4	10	0.3	1	0.29	78.9	6.0606	1.5229
2014	9	28	21	14	10	0.3	1	0.31	101.7	6.0606	1.6104
2014	9	28	21	24	10	0.3	1	0.25	93.8	6.0606	1.3128
2014	9	28	21	34	10	0.3	1	0.25	87.8	6.0606	1.3479
2014	9	28	21	44	10	0.3	1	0.22	72.9	6.0606	1.1378
2014	9	28	21	54	10	0.3	1	0.26	100.9	6.0606	1.3654
2014	9	28	22	4	10	0.3	1	0.2	78.5	6.0606	1.0328
2014	9	28	22	14	10	0.3	1	0.23	90	6.08	1.2295
2014	9	28	22	24	10	0.3	1	0.19	90	6.0606	0.9978
2014	9	28	22	34	10	0.3	1	0.21	114.1	6.0606	1.0153
2014	9	28	22	44	10	0.3	1	0.23	103.8	6.0606	1.2078
2014	9	28	22	54	10	0.3	1	0.31	98.5	6.0606	1.6455
2014	9	28	23	4	10	0.3	1	0.23	94	6.08	1.2471
2014	9	28	23	14	10	0.3	1	0.19	80.2	6.0606	1.0153
2014	9	28	23	24	10	0.3	1	0.29	98.6	6.08	1.5106
2014	9	28	23	34	10	0.3	1	0.27	100.5	6.08	1.4228
2014	9	28	23	44	10	0.3	1	0.24	80.5	6.08	1.2647
2014	9	28	23	54	10	0.3	1	0.3	83	6.08	1.5809
2014	9	29	0	4	10	0.3	1	0.21	95.3	6.08	1.1417
2014	9	29	0	14	10	0.3	1	0.3	89.4	6.08	1.5809
2014	9	29	0	24	10	0.3	1	0.28	94.7	6.08	1.5106
2014	9	29	0	34	10	0.3	1	0.28	90.7	6.08	1.493
2014	9	29	0	44	10	0.3	1	0.23	94	6.08	1.2471
2014	9	29	0	54	10	0.3	1	0.2	96.4	6.08	1.089
2014	9	29	1	4	10	0.3	1	0.23	111	6.08	1.1417
2014	9	29	1	14	10	0.3	1	0.24	94.7	6.08	1.2823
2014	9	29	1	24	10	0.3	1	0.24	93.9	6.08	1.2998
2014	9	29	1	34	10	0.3	1	0.23	102.6	6.08	1.1769
2014	9	29	1	44	10	0.3	1	0.23	80.8	6.08	1.1944
2014	9	29	1	54	10	0.3	1	0.23	95.8	6.08	1.212
2014	9	29	2	4	10	0.3	1	0.21	93.6	6.08	1.1242
2014	9	29	2	14	10	0.3	1	0.28	103.5	6.08	1.4579
2014	9	29	2	24	10	0.3	1	0.24	101.2	6.08	1.2471
2014	9	29	2	34	10	0.3	1	0.22	101.3	6.08	1.1418
2014	9	29	2	44	10	0.3	1	0.23	98.1	6.08	1.2296

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	2	54	10	0.3	1	0.24	91.5	6.08	1.2998
2014	9	29	3	4	10	0.3	1	0.21	84.7	6.08	1.1418
2014	9	29	3	14	10	0.3	1	0.26	90	6.08	1.4052
2014	9	29	3	24	10	0.3	1	0.23	90	6.08	1.2296
2014	9	29	3	34	10	0.3	1	0.25	96.8	6.08	1.3174
2014	9	29	3	44	10	0.3	1	0.21	107.6	6.08	1.0539
2014	9	29	3	54	10	0.3	1	0.28	105.5	6.08	1.4579
2014	9	29	4	4	10	0.3	1	0.18	98.3	6.08	0.9661
2014	9	29	4	14	10	0.3	1	0.23	94.1	6.08	1.212
2014	9	29	4	24	10	0.3	1	0.31	92.4	6.08	1.6687
2014	9	29	4	34	10	0.3	1	0.26	108	6.08	1.2999
2014	9	29	4	44	10	0.3	1	0.23	125.1	6.08	1.0012
2014	9	29	4	54	10	0.3	1	0.23	98.1	6.08	1.2296
2014	9	29	5	4	10	0.3	1	0.23	107.7	6.08	1.1593
2014	9	29	5	14	10	0.3	1	0.25	105.1	6.08	1.2999
2014	9	29	5	24	10	0.3	1	0.24	104.2	6.08	1.2472
2014	9	29	5	34	10	0.3	1	0.2	85.4	6.08	1.0891
2014	9	29	5	44	10	0.3	1	0.28	90	6.08	1.4755
2014	9	29	5	54	10	0.3	1	0.32	99.5	6.08	1.6863
2014	9	29	6	4	10	0.3	1	0.22	105.7	6.08	1.1242
2014	9	29	6	14	10	0.3	1	0.23	93.3	6.08	1.212
2014	9	29	6	24	10	0.3	1	0.2	94.8	6.08	1.054
2014	9	29	6	34	10	0.3	1	0.24	89.2	6.08	1.2999
2014	9	29	6	44	10	0.3	1	0.22	103	6.08	1.1418
2014	9	29	6	54	10	0.3	1	0.25	112.8	6.08	1.212
2014	9	29	7	4	10	0.3	1	0.2	119.5	6.08	0.931
2014	9	29	7	14	10	0.3	1	0.22	100.5	6.08	1.1418
2014	9	29	7	24	10	0.3	1	0.28	86.6	6.08	1.4931
2014	9	29	7	34	10	0.3	1	0.24	101.8	6.08	1.2648
2014	9	29	7	44	10	0.3	1	0.21	93.5	6.08	1.1418
2014	9	29	7	54	10	0.3	1	0.27	105.1	6.08	1.3702
2014	9	29	8	4	10	0.3	1	0.23	89.2	6.08	1.2121
2014	9	29	8	14	10	0.3	1	0.26	81.1	6.08	1.3526
2014	9	29	8	24	10	0.3	1	0.26	99.5	6.08	1.3702
2014	9	29	8	34	10	0.3	1	0.23	80.8	6.08	1.1945
2014	9	29	8	44	10	0.3	1	0.31	82	6.08	1.6336
2014	9	29	8	54	10	0.3	1	0.27	90	6.08	1.4229
2014	9	29	9	4	10	0.3	1	0.32	88.8	6.08	1.7039
2014	9	29	9	14	10	0.3	1	0.23	82.8	6.08	1.2472
2014	9	29	9	24	10	0.3	1	0.19	95.8	6.08	1.0364
2014	9	29	9	34	10	0.3	1	0.19	69.7	6.08	0.9486
2014	9	29	9	44	10	0.3	1	0.23	95.8	6.08	1.2121
2014	9	29	9	54	10	0.3	1	0.25	84.8	6.08	1.3526
2014	9	29	10	4	10	0.3	1	0.29	98.4	6.08	1.5458
2014	9	29	10	14	10	0.3	1	0.27	90	6.08	1.4404
2014	9	29	10	24	10	0.3	1	0.23	92.4	6.08	1.2472

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	10	34	10	0.3	1	0.24	75.2	6.08	1.2647
2014	9	29	10	44	10	0.3	1	0.27	87.9	6.08	1.458
2014	9	29	10	54	10	0.3	1	0.25	87	6.08	1.3526
2014	9	29	11	4	10	0.3	1	0.28	90	6.08	1.4931
2014	9	29	11	14	10	0.3	1	0.29	84.8	6.08	1.5458
2014	9	29	11	24	10	0.3	1	0.28	90	6.08	1.4931
2014	9	29	11	34	10	0.3	1	0.28	80.4	6.08	1.4579
2014	9	29	11	44	10	0.3	1	0.19	81.9	6.08	0.9837
2014	9	29	11	54	10	0.3	1	0.29	80.8	6.08	1.5106
2014	9	29	12	4	10	0.3	1	0.27	83.7	6.08	1.4404
2014	9	29	12	14	10	0.3	1	0.28	74.1	6.08	1.4228
2014	9	29	12	24	10	0.3	1	0.31	73.1	6.08	1.5633
2014	9	29	12	34	10	0.3	1	0.26	77	6.08	1.3701
2014	9	29	12	44	10	0.3	1	0.25	78.8	6.08	1.3349
2014	9	29	12	54	10	0.3	1	0.29	77.1	6.08	1.5282
2014	9	29	13	4	10	0.3	1	0.34	70.7	6.08	1.7038
2014	9	29	13	14	10	0.3	1	0.29	80.9	6.08	1.5281
2014	9	29	13	24	10	0.3	1	0.3	83.7	6.0606	1.5754
2014	9	29	13	34	10	0.3	1	0.3	88.1	6.0606	1.5754
2014	9	29	13	44	10	0.3	1	0.28	74.3	6.0606	1.4354
2014	9	29	13	54	10	0.3	1	0.31	83.9	6.08	1.6335
2014	9	29	14	4	10	0.3	1	0.33	79	6.08	1.7213
2014	9	29	14	14	10	0.3	1	0.29	86.8	6.08	1.5632
2014	9	29	14	24	10	0.3	1	0.31	77.9	6.08	1.6335
2014	9	29	14	34	10	0.3	1	0.33	87.1	6.08	1.7389
2014	9	29	14	44	10	0.3	1	0.28	88	6.08	1.493
2014	9	29	14	54	10	0.3	1	0.34	83.8	6.08	1.7915
2014	9	29	15	4	10	0.3	1	0.26	78.3	6.08	1.3524
2014	9	29	15	14	10	0.3	1	0.33	78.6	6.08	1.7388
2014	9	29	15	24	10	0.3	1	0.29	96.4	6.08	1.5632
2014	9	29	15	34	10	0.3	1	0.24	98.8	6.08	1.247
2014	9	29	15	44	10	0.3	1	0.27	90	6.08	1.4578
2014	9	29	15	54	10	0.3	1	0.29	74.9	6.08	1.4929
2014	9	29	16	4	10	0.3	1	0.26	79.2	6.08	1.3875
2014	9	29	16	14	10	0.3	1	0.3	93.2	6.08	1.5807
2014	9	29	16	24	10	0.3	1	0.3	86.8	6.08	1.5807
2014	9	29	16	34	10	0.3	1	0.26	97.2	6.08	1.3875
2014	9	29	16	44	10	0.3	1	0.27	89.3	6.08	1.4402
2014	9	29	16	54	10	0.3	1	0.24	90.8	6.08	1.2997
2014	9	29	17	4	10	0.3	1	0.24	83	6.08	1.2821
2014	9	29	17	14	10	0.3	1	0.28	65.2	6.08	1.37
2014	9	29	17	24	10	0.3	1	0.34	74.4	6.08	1.7564
2014	9	29	17	34	10	0.3	1	0.36	58.2	6.08	1.6159
2014	9	29	17	44	10	0.3	1	0.35	56.6	6.08	1.5456
2014	9	29	17	54	10	0.3	1	0.36	52.3	6.0993	1.5509
2014	9	29	18	4	10	0.3	1	0.39	55.5	6.0993	1.7447

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	18	14	10	0.3	1	0.4	55.7	6.0993	1.78
2014	9	29	18	24	10	0.3	1	0.43	49.4	6.0993	1.7447
2014	9	29	18	34	10	0.3	1	0.34	67.6	6.0993	1.7095
2014	9	29	18	44	10	0.3	1	0.31	55.3	6.0993	1.3747
2014	9	29	18	54	10	0.3	1	0.3	68.8	6.0993	1.498
2014	9	29	19	4	10	0.3	1	0.28	69.2	6.0993	1.3923
2014	9	29	19	14	10	0.3	1	0.3	56.1	6.0993	1.3394
2014	9	29	19	24	10	0.3	1	0.21	60.6	6.0993	0.9693
2014	9	29	19	34	10	0.3	1	0.26	66.7	6.0993	1.2689
2014	9	29	19	44	10	0.3	1	0.22	58.4	6.0993	1.0046
2014	9	29	19	54	10	0.3	1	0.31	82.6	6.0993	1.639
2014	9	29	20	4	10	0.3	1	0.27	67.8	6.0993	1.3394
2014	9	29	20	14	10	0.3	1	0.29	76.4	6.0993	1.5333
2014	9	29	20	24	10	0.3	1	0.27	88.6	6.1187	1.4324
2014	9	29	20	34	10	0.3	1	0.31	88.2	6.0993	1.6567
2014	9	29	20	44	10	0.3	1	0.27	96.9	6.1187	1.4678
2014	9	29	20	54	10	0.3	1	0.3	89.4	6.1187	1.627
2014	9	29	21	4	10	0.3	1	0.23	80	6.1187	1.2025
2014	9	29	21	14	10	0.3	1	0.24	85.3	6.1187	1.291
2014	9	29	21	24	10	0.3	1	0.25	99	6.1187	1.344
2014	9	29	21	34	10	0.3	1	0.28	102.9	6.1187	1.4678
2014	9	29	21	44	10	0.3	1	0.29	105.1	6.1187	1.5032
2014	9	29	21	54	10	0.3	1	0.26	78.3	6.1187	1.3617
2014	9	29	22	4	10	0.3	1	0.27	92.1	6.1187	1.4501
2014	9	29	22	14	10	0.3	1	0.21	93.6	6.1187	1.1318
2014	9	29	22	24	10	0.3	1	0.3	96.3	6.1187	1.5916
2014	9	29	22	34	10	0.3	1	0.27	111.3	6.1187	1.3617
2014	9	29	22	44	10	0.3	1	0.29	86.7	6.1187	1.5386
2014	9	29	22	54	10	0.3	1	0.31	96.1	6.1187	1.6447
2014	9	29	23	4	10	0.3	1	0.29	96.5	6.1187	1.5563
2014	9	29	23	14	10	0.3	1	0.29	110.9	6.1187	1.4855
2014	9	29	23	24	10	0.3	1	0.29	124.2	6.1187	1.2733
2014	9	29	23	34	10	0.3	1	0.3	96.3	6.1187	1.6093
2014	9	29	23	44	10	0.3	1	0.26	98.6	6.0993	1.3924
2014	9	29	23	54	10	0.3	1	0.21	99.2	6.1187	1.0965
2014	9	30	0	4	10	0.3	1	0.29	109	6.1187	1.4855
2014	9	30	0	14	10	0.3	1	0.29	108.2	6.1187	1.5032
2014	9	30	0	24	10	0.3	1	0.21	114.6	6.1187	1.0434
2014	9	30	0	34	10	0.3	1	0.29	112.5	6.1187	1.4502
2014	9	30	0	44	10	0.3	1	0.32	98.3	6.1187	1.6978
2014	9	30	0	54	10	0.3	1	0.24	101.2	6.1187	1.2556
2014	9	30	1	4	10	0.3	1	0.26	100.3	6.1187	1.3618
2014	9	30	1	14	10	0.3	1	0.19	107.8	6.1187	0.9904
2014	9	30	1	24	10	0.3	1	0.21	85.5	6.0993	1.128
2014	9	30	1	34	10	0.3	1	0.28	102.2	6.0993	1.4629
2014	9	30	1	44	10	0.3	1	0.22	96.1	6.0993	1.1633

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	1	54	10	0.3	1	0.22	94.2	6.0993	1.1985
2014	9	30	2	4	10	0.3	1	0.22	108.4	6.0993	1.1104
2014	9	30	2	14	10	0.3	1	0.25	93	6.0993	1.3395
2014	9	30	2	24	10	0.3	1	0.22	103.6	6.0993	1.1633
2014	9	30	2	34	10	0.3	1	0.21	113.8	6.0993	1.0399
2014	9	30	2	44	10	0.3	1	0.3	104.3	6.0993	1.5863
2014	9	30	2	54	10	0.3	1	0.26	96.5	6.0993	1.3924
2014	9	30	3	4	10	0.3	1	0.2	102	6.0993	1.0751
2014	9	30	3	14	10	0.3	1	0.28	90	6.0993	1.4805
2014	9	30	3	24	10	0.3	1	0.32	115	6.0993	1.551
2014	9	30	3	34	10	0.3	1	0.23	115.8	6.0993	1.0928
2014	9	30	3	44	10	0.3	1	0.3	96.3	6.0993	1.6039
2014	9	30	3	54	10	0.3	1	0.24	94	6.0993	1.269
2014	9	30	4	4	10	0.3	1	0.24	107.4	6.0993	1.2338
2014	9	30	4	14	10	0.3	1	0.29	95.2	6.0993	1.551
2014	9	30	4	24	10	0.3	1	0.21	89.1	6.0993	1.1457
2014	9	30	4	34	10	0.3	1	0.17	109.1	6.0993	0.8636
2014	9	30	4	44	10	0.3	1	0.21	97	6.0993	1.1457
2014	9	30	4	54	10	0.3	1	0.2	86.2	6.0993	1.0752
2014	9	30	5	4	10	0.3	1	0.25	127	6.0993	1.0752
2014	9	30	5	14	10	0.3	1	0.21	102.9	6.0993	1.0752
2014	9	30	5	24	10	0.3	1	0.23	94.1	6.0993	1.2338
2014	9	30	5	34	10	0.3	1	0.23	94	6.0993	1.2514
2014	9	30	5	44	10	0.3	1	0.26	103.9	6.0993	1.3572
2014	9	30	5	54	10	0.3	1	0.27	99.2	6.0993	1.41
2014	9	30	6	4	10	0.3	1	0.27	109.7	6.0993	1.3748
2014	9	30	6	14	10	0.3	1	0.26	90	6.0993	1.4101
2014	9	30	6	24	10	0.3	1	0.17	106.4	6.0993	0.8989
2014	9	30	6	34	10	0.3	1	0.24	91.6	6.0993	1.269
2014	9	30	6	44	10	0.3	1	0.28	98	6.0993	1.4982
2014	9	30	6	54	10	0.3	1	0.19	94.9	6.0993	1.0223
2014	9	30	7	4	10	0.3	1	0.25	90	6.0993	1.3396
2014	9	30	7	14	10	0.3	1	0.3	92.5	6.0993	1.6216
2014	9	30	7	24	10	0.3	1	0.22	104	6.0993	1.1281
2014	9	30	7	34	10	0.3	1	0.26	100	6.0993	1.3924
2014	9	30	7	44	10	0.3	1	0.24	101	6.0993	1.2691
2014	9	30	7	54	10	0.3	1	0.19	96.8	6.0993	1.0399
2014	9	30	8	4	10	0.3	1	0.24	90	6.0993	1.2691
2014	9	30	8	14	10	0.3	1	0.21	113	6.0993	1.0399
2014	9	30	8	24	10	0.3	1	0.31	105.2	6.0993	1.6216
2014	9	30	8	34	10	0.3	1	0.2	82.3	6.0993	1.0399
2014	9	30	8	44	10	0.3	1	0.21	99	6.0993	1.1104
2014	9	30	8	54	10	0.3	1	0.15	83.7	6.0993	0.7932
2014	9	30	9	4	10	0.3	1	0.3	105.7	6.0993	1.5687
2014	9	30	9	14	10	0.3	1	0.23	99.2	6.0993	1.1986
2014	9	30	9	24	10	0.3	1	0.21	99.8	6.0993	1.1281

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	9	34	10	0.3	1	0.21	118.2	6.0993	0.987
2014	9	30	9	44	10	0.3	1	0.2	100.6	6.0993	1.0399
2014	9	30	9	54	10	0.3	1	0.24	103.7	6.0993	1.2338
2014	9	30	10	4	10	0.3	1	0.24	107.4	6.0993	1.2338
2014	9	30	10	14	10	0.3	1	0.22	78	6.0993	1.1633
2014	9	30	10	24	10	0.3	1	0.32	88.2	6.08	1.7214
2014	9	30	10	34	10	0.3	1	0.3	111.8	6.08	1.4931
2014	9	30	10	44	10	0.3	1	0.2	89	6.08	1.0539
2014	9	30	10	54	10	0.3	1	0.27	87.9	6.08	1.4228
2014	9	30	11	4	10	0.3	1	0.28	83.2	6.0993	1.4805
2014	9	30	11	14	10	0.3	1	0.25	90	6.0993	1.3395
2014	9	30	11	24	10	0.3	1	0.27	88.6	6.0993	1.4276
2014	9	30	11	34	10	0.3	1	0.15	70.3	6.0993	0.7403
2014	9	30	11	44	10	0.3	1	0.33	86	6.0993	1.7449
2014	9	30	11	54	10	0.3	1	0.25	84.7	6.0993	1.3395
2014	9	30	12	4	10	0.3	1	0.24	92.4	6.0993	1.2866
2014	9	30	12	14	10	0.3	1	0.28	87.3	6.08	1.4754
2014	9	30	12	24	10	0.3	1	0.24	75.8	6.08	1.2471
2014	9	30	12	34	10	0.3	1	0.31	83.9	6.08	1.6335
2014	9	30	12	44	10	0.3	1	0.22	85.7	6.08	1.1593
2014	9	30	12	54	10	0.3	1	0.25	63.1	6.08	1.1768
2014	9	30	13	4	10	0.3	1	0.25	75.6	6.08	1.2998
2014	9	30	13	14	10	0.3	1	0.27	79.6	6.08	1.4403
2014	9	30	13	24	10	0.3	1	0.24	68.8	6.08	1.1768
2014	9	30	13	34	10	0.3	1	0.26	87.8	6.08	1.37
2014	9	30	13	44	10	0.3	1	0.32	82.4	6.08	1.7037
2014	9	30	13	54	10	0.3	1	0.33	77.8	6.08	1.7037
2014	9	30	14	4	10	0.3	1	0.25	78.8	6.08	1.3349
2014	9	30	14	14	10	0.3	1	0.27	79	6.08	1.4403
2014	9	30	14	24	10	0.3	1	0.25	70.9	6.08	1.2646
2014	9	30	14	34	10	0.3	1	0.21	82	6.08	1.1241
2014	9	30	14	44	10	0.3	1	0.27	100.6	6.08	1.4051
2014	9	30	14	54	10	0.3	1	0.24	89.2	6.08	1.2997
2014	9	30	15	4	10	0.3	1	0.28	94.1	6.08	1.4754
2014	9	30	15	14	10	0.3	1	0.25	90	6.08	1.3348
2014	9	30	15	24	10	0.3	1	0.3	88.1	6.0606	1.5753
2014	9	30	15	34	10	0.3	1	0.25	93.7	6.08	1.3524
2014	9	30	15	44	10	0.3	1	0.27	90	6.0606	1.4528
2014	9	30	15	54	10	0.3	1	0.28	79.9	6.08	1.4753
2014	9	30	16	4	10	0.3	1	0.2	83.5	6.0606	1.0677
2014	9	30	16	14	10	0.3	1	0.2	85.3	6.0606	1.0677
2014	9	30	16	24	10	0.3	1	0.33	86.5	6.0606	1.7328
2014	9	30	16	34	10	0.3	1	0.29	82.8	6.0606	1.5228
2014	9	30	16	44	10	0.3	1	0.22	78.7	6.0606	1.1377
2014	9	30	16	54	10	0.3	1	0.26	71.3	6.0606	1.2952
2014	9	30	17	4	10	0.3	1	0.31	93.1	6.0606	1.6278

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	17	14	10	0.3	1	0.25	87	6.0606	1.3303
2014	9	30	17	24	10	0.3	1	0.26	90.7	6.0606	1.4003
2014	9	30	17	34	10	0.3	1	0.18	85.8	6.0606	0.9452
2014	9	30	17	44	10	0.3	1	0.29	67.2	6.0606	1.4178
2014	9	30	17	54	10	0.3	1	0.32	72.3	6.0606	1.6453
2014	9	30	18	4	10	0.3	1	0.23	80	6.0606	1.1902
2014	9	30	18	14	10	0.3	1	0.3	89.4	6.0606	1.5928
2014	9	30	18	24	10	0.3	1	0.27	91.4	6.0606	1.4528
2014	9	30	18	34	10	0.3	1	0.24	88.5	6.0606	1.2953
2014	9	30	18	44	10	0.3	1	0.23	98.1	6.0606	1.2252
2014	9	30	18	54	10	0.3	1	0.23	85.9	6.0606	1.2077
2014	9	30	19	4	10	0.3	1	0.28	108	6.0606	1.4003
2014	9	30	19	14	10	0.3	1	0.3	104.8	6.0606	1.5228
2014	9	30	19	24	10	0.3	1	0.25	99.8	6.0606	1.3128
2014	9	30	19	34	10	0.3	1	0.21	89.1	6.0606	1.1202
2014	9	30	19	44	10	0.3	1	0.27	99.2	6.0606	1.4003
2014	9	30	19	54	10	0.3	1	0.24	110.2	6.0606	1.1902
2014	9	30	20	4	10	0.3	1	0.27	99.8	6.0606	1.4178
2014	9	30	20	14	10	0.3	1	0.28	87.3	6.0606	1.5053
2014	9	30	20	24	10	0.3	1	0.34	68.6	6.0606	1.6979
2014	9	30	20	34	10	0.3	1	0.23	78.4	6.0606	1.1903
2014	9	30	20	44	10	0.3	1	0.27	74.2	6.0606	1.3653
2014	9	30	20	54	10	0.3	1	0.28	90	6.0606	1.4703
2014	9	30	21	4	10	0.3	1	0.2	85.3	6.0606	1.0677
2014	9	30	21	14	10	0.3	1	0.29	102	6.0606	1.4878
2014	9	30	21	24	10	0.3	1	0.21	94.4	6.0606	1.1378
2014	9	30	21	34	10	0.3	1	0.21	94.4	6.0606	1.1378
2014	9	30	21	44	10	0.3	1	0.25	106	6.0606	1.2778
2014	9	30	21	54	10	0.3	1	0.28	89.3	6.0606	1.4703
2014	9	30	22	4	10	0.3	1	0.26	94.3	6.0606	1.4003
2014	9	30	22	14	10	0.3	1	0.26	110.3	6.0606	1.2778
2014	9	30	22	24	10	0.3	1	0.29	93.9	6.0606	1.5404
2014	9	30	22	34	10	0.3	1	0.3	98.3	6.0606	1.5579
2014	9	30	22	44	10	0.3	1	0.23	103.4	6.0606	1.1728
2014	9	30	22	54	10	0.3	1	0.26	107.5	6.0606	1.3303
2014	9	30	23	4	10	0.3	1	0.21	118.5	6.0412	0.9943
2014	9	30	23	14	10	0.3	1	0.21	84.7	6.0412	1.1339
2014	9	30	23	24	10	0.3	1	0.26	87.9	6.0606	1.4004
2014	9	30	23	34	10	0.3	1	0.24	90	6.0606	1.2603
2014	9	30	23	44	10	0.3	1	0.2	96.5	6.0412	1.0641
2014	9	30	23	54	10	0.3	1	0.24	103.5	6.0606	1.2428

Goose Lake Return
Station 0367

Date	Flow (cfs)
9/1/2014	1.072
9/2/2014	1.06
9/3/2014	1.034
9/4/2014	1.023
9/5/2014	1.001
9/6/2014	1.008
9/7/2014	1.025
9/8/2014	1.089
9/9/2014	1.124
9/10/2014	1.098
9/11/2014	1.07
9/12/2014	0.999
9/13/2014	0.936
9/14/2014	0.922
9/15/2014	0.907
9/16/2014	0.902
9/17/2014	0.895
9/18/2014	0.906
9/19/2014	0.952
9/20/2014	1.052
9/21/2014	1.125
9/22/2014	1.168
9/23/2014	1.158
9/24/2014	1.143
9/25/2014	1.07
9/26/2014	0.996
9/27/2014	0.923
9/28/2014	0.929
9/29/2014	1.077
9/30/2014	1.192

Goose Lake Return Gage

DATE	TIME	GAGE
9/1/2014	12:00:00 AM	0.43
9/1/2014	12:15:00 AM	0.43
9/1/2014	12:30:00 AM	0.43
9/1/2014	12:45:00 AM	0.43
9/1/2014	1:00:00 AM	0.43
9/1/2014	1:15:00 AM	0.43
9/1/2014	1:30:00 AM	0.43
9/1/2014	1:45:00 AM	0.43
9/1/2014	2:00:00 AM	0.44
9/1/2014	2:15:00 AM	0.43
9/1/2014	2:30:00 AM	0.43
9/1/2014	2:45:00 AM	0.43
9/1/2014	3:00:00 AM	0.43
9/1/2014	3:15:00 AM	0.43
9/1/2014	3:30:00 AM	0.43
9/1/2014	3:45:00 AM	0.44
9/1/2014	4:00:00 AM	0.44
9/1/2014	4:15:00 AM	0.44
9/1/2014	4:30:00 AM	0.44
9/1/2014	4:45:00 AM	0.44
9/1/2014	5:00:00 AM	0.44
9/1/2014	5:15:00 AM	0.44
9/1/2014	5:30:00 AM	0.44
9/1/2014	5:45:00 AM	0.44
9/1/2014	6:00:00 AM	0.44
9/1/2014	6:15:00 AM	0.44
9/1/2014	6:30:00 AM	0.44
9/1/2014	6:45:00 AM	0.44
9/1/2014	7:00:00 AM	0.44
9/1/2014	7:15:00 AM	0.44
9/1/2014	7:30:00 AM	0.44
9/1/2014	7:45:00 AM	0.44
9/1/2014	8:00:00 AM	0.44
9/1/2014	8:15:00 AM	0.44
9/1/2014	8:30:00 AM	0.44
9/1/2014	8:45:00 AM	0.44
9/1/2014	9:00:00 AM	0.44
9/1/2014	9:15:00 AM	0.44
9/1/2014	9:30:00 AM	0.44
9/1/2014	9:45:00 AM	0.44
9/1/2014	10:00:00 AM	0.44
9/1/2014	10:15:00 AM	0.44
9/1/2014	10:30:00 AM	0.44
9/1/2014	10:45:00 AM	0.44
9/1/2014	11:00:00 AM	0.44
9/1/2014	11:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/1/2014	11:30:00 AM	0.44
9/1/2014	11:45:00 AM	0.44
9/1/2014	12:00:00 PM	0.44
9/1/2014	12:15:00 PM	0.44
9/1/2014	12:30:00 PM	0.44
9/1/2014	12:45:00 PM	0.44
9/1/2014	1:00:00 PM	0.44
9/1/2014	1:15:00 PM	0.44
9/1/2014	1:30:00 PM	0.44
9/1/2014	1:45:00 PM	0.44
9/1/2014	2:00:00 PM	0.44
9/1/2014	2:15:00 PM	0.44
9/1/2014	2:30:00 PM	0.44
9/1/2014	2:45:00 PM	0.43
9/1/2014	3:00:00 PM	0.43
9/1/2014	3:15:00 PM	0.42
9/1/2014	3:30:00 PM	0.42
9/1/2014	3:45:00 PM	0.42
9/1/2014	4:00:00 PM	0.42
9/1/2014	4:15:00 PM	0.42
9/1/2014	4:30:00 PM	0.42
9/1/2014	4:45:00 PM	0.42
9/1/2014	5:00:00 PM	0.42
9/1/2014	5:15:00 PM	0.42
9/1/2014	5:30:00 PM	0.42
9/1/2014	5:45:00 PM	0.42
9/1/2014	6:00:00 PM	0.42
9/1/2014	6:15:00 PM	0.42
9/1/2014	6:30:00 PM	0.42
9/1/2014	6:45:00 PM	0.42
9/1/2014	7:00:00 PM	0.42
9/1/2014	7:15:00 PM	0.42
9/1/2014	7:30:00 PM	0.42
9/1/2014	7:45:00 PM	0.42
9/1/2014	8:00:00 PM	0.42
9/1/2014	8:15:00 PM	0.42
9/1/2014	8:30:00 PM	0.42
9/1/2014	8:45:00 PM	0.42
9/1/2014	9:00:00 PM	0.42
9/1/2014	9:15:00 PM	0.42
9/1/2014	9:30:00 PM	0.42
9/1/2014	9:45:00 PM	0.42
9/1/2014	10:00:00 PM	0.42
9/1/2014	10:15:00 PM	0.42
9/1/2014	10:30:00 PM	0.43
9/1/2014	10:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/1/2014	11:00:00 PM	0.42
9/1/2014	11:15:00 PM	0.42
9/1/2014	11:30:00 PM	0.42
9/1/2014	11:45:00 PM	0.42
9/2/2014	12:00:00 AM	0.42
9/2/2014	12:15:00 AM	0.42
9/2/2014	12:30:00 AM	0.42
9/2/2014	12:45:00 AM	0.42
9/2/2014	1:00:00 AM	0.43
9/2/2014	1:15:00 AM	0.43
9/2/2014	1:30:00 AM	0.43
9/2/2014	1:45:00 AM	0.43
9/2/2014	2:00:00 AM	0.43
9/2/2014	2:15:00 AM	0.43
9/2/2014	2:30:00 AM	0.44
9/2/2014	2:45:00 AM	0.44
9/2/2014	3:00:00 AM	0.44
9/2/2014	3:15:00 AM	0.44
9/2/2014	3:30:00 AM	0.44
9/2/2014	3:45:00 AM	0.44
9/2/2014	4:00:00 AM	0.44
9/2/2014	4:15:00 AM	0.44
9/2/2014	4:30:00 AM	0.44
9/2/2014	4:45:00 AM	0.44
9/2/2014	5:00:00 AM	0.44
9/2/2014	5:15:00 AM	0.44
9/2/2014	5:30:00 AM	0.44
9/2/2014	5:45:00 AM	0.44
9/2/2014	6:00:00 AM	0.44
9/2/2014	6:15:00 AM	0.44
9/2/2014	6:30:00 AM	0.44
9/2/2014	6:45:00 AM	0.44
9/2/2014	7:00:00 AM	0.44
9/2/2014	7:15:00 AM	0.44
9/2/2014	7:30:00 AM	0.44
9/2/2014	7:45:00 AM	0.44
9/2/2014	8:00:00 AM	0.44
9/2/2014	8:15:00 AM	0.44
9/2/2014	8:30:00 AM	0.44
9/2/2014	8:45:00 AM	0.44
9/2/2014	9:00:00 AM	0.44
9/2/2014	9:15:00 AM	0.44
9/2/2014	9:30:00 AM	0.44
9/2/2014	9:45:00 AM	0.44
9/2/2014	10:00:00 AM	0.44
9/2/2014	10:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/2/2014	10:30:00 AM	0.44
9/2/2014	10:45:00 AM	0.44
9/2/2014	11:00:00 AM	0.44
9/2/2014	11:15:00 AM	0.44
9/2/2014	11:30:00 AM	0.44
9/2/2014	11:45:00 AM	0.44
9/2/2014	12:00:00 PM	0.43
9/2/2014	12:15:00 PM	0.43
9/2/2014	12:30:00 PM	0.43
9/2/2014	12:45:00 PM	0.43
9/2/2014	1:00:00 PM	0.43
9/2/2014	1:15:00 PM	0.43
9/2/2014	1:30:00 PM	0.42
9/2/2014	1:45:00 PM	0.42
9/2/2014	2:00:00 PM	0.42
9/2/2014	2:15:00 PM	0.42
9/2/2014	2:30:00 PM	0.42
9/2/2014	2:45:00 PM	0.42
9/2/2014	3:00:00 PM	0.42
9/2/2014	3:15:00 PM	0.42
9/2/2014	3:30:00 PM	0.42
9/2/2014	3:45:00 PM	0.42
9/2/2014	4:00:00 PM	0.42
9/2/2014	4:15:00 PM	0.42
9/2/2014	4:30:00 PM	0.42
9/2/2014	4:45:00 PM	0.42
9/2/2014	5:00:00 PM	0.42
9/2/2014	5:15:00 PM	0.42
9/2/2014	5:30:00 PM	0.42
9/2/2014	5:45:00 PM	0.42
9/2/2014	6:00:00 PM	0.41
9/2/2014	6:15:00 PM	0.41
9/2/2014	6:30:00 PM	0.41
9/2/2014	6:45:00 PM	0.41
9/2/2014	7:00:00 PM	0.41
9/2/2014	7:15:00 PM	0.41
9/2/2014	7:30:00 PM	0.41
9/2/2014	7:45:00 PM	0.41
9/2/2014	8:00:00 PM	0.41
9/2/2014	8:15:00 PM	0.41
9/2/2014	8:30:00 PM	0.41
9/2/2014	8:45:00 PM	0.41
9/2/2014	9:00:00 PM	0.42
9/2/2014	9:15:00 PM	0.42
9/2/2014	9:30:00 PM	0.42
9/2/2014	9:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/2/2014	10:00:00 PM	0.42
9/2/2014	10:15:00 PM	0.42
9/2/2014	10:30:00 PM	0.42
9/2/2014	10:45:00 PM	0.42
9/2/2014	11:00:00 PM	0.42
9/2/2014	11:15:00 PM	0.42
9/2/2014	11:30:00 PM	0.42
9/2/2014	11:45:00 PM	0.42
9/3/2014	12:00:00 AM	0.42
9/3/2014	12:15:00 AM	0.42
9/3/2014	12:30:00 AM	0.42
9/3/2014	12:45:00 AM	0.42
9/3/2014	1:00:00 AM	0.42
9/3/2014	1:15:00 AM	0.42
9/3/2014	1:30:00 AM	0.42
9/3/2014	1:45:00 AM	0.42
9/3/2014	2:00:00 AM	0.42
9/3/2014	2:15:00 AM	0.42
9/3/2014	2:30:00 AM	0.42
9/3/2014	2:45:00 AM	0.42
9/3/2014	3:00:00 AM	0.42
9/3/2014	3:15:00 AM	0.42
9/3/2014	3:30:00 AM	0.42
9/3/2014	3:45:00 AM	0.42
9/3/2014	4:00:00 AM	0.42
9/3/2014	4:15:00 AM	0.42
9/3/2014	4:30:00 AM	0.42
9/3/2014	4:45:00 AM	0.42
9/3/2014	5:00:00 AM	0.42
9/3/2014	5:15:00 AM	0.42
9/3/2014	5:30:00 AM	0.42
9/3/2014	5:45:00 AM	0.42
9/3/2014	6:00:00 AM	0.42
9/3/2014	6:15:00 AM	0.42
9/3/2014	6:30:00 AM	0.42
9/3/2014	6:45:00 AM	0.42
9/3/2014	7:00:00 AM	0.42
9/3/2014	7:15:00 AM	0.43
9/3/2014	7:30:00 AM	0.43
9/3/2014	7:45:00 AM	0.43
9/3/2014	8:00:00 AM	0.43
9/3/2014	8:15:00 AM	0.43
9/3/2014	8:30:00 AM	0.43
9/3/2014	8:45:00 AM	0.43
9/3/2014	9:00:00 AM	0.43
9/3/2014	9:15:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
9/3/2014	9:30:00 AM	0.43
9/3/2014	9:45:00 AM	0.44
9/3/2014	10:00:00 AM	0.44
9/3/2014	10:15:00 AM	0.44
9/3/2014	10:30:00 AM	0.44
9/3/2014	10:45:00 AM	0.44
9/3/2014	11:00:00 AM	0.44
9/3/2014	11:15:00 AM	0.43
9/3/2014	11:30:00 AM	0.43
9/3/2014	11:45:00 AM	0.43
9/3/2014	12:00:00 PM	0.42
9/3/2014	12:15:00 PM	0.42
9/3/2014	12:30:00 PM	0.42
9/3/2014	12:45:00 PM	0.42
9/3/2014	1:00:00 PM	0.42
9/3/2014	1:15:00 PM	0.42
9/3/2014	1:30:00 PM	0.42
9/3/2014	1:45:00 PM	0.42
9/3/2014	2:00:00 PM	0.42
9/3/2014	2:15:00 PM	0.42
9/3/2014	2:30:00 PM	0.42
9/3/2014	2:45:00 PM	0.42
9/3/2014	3:00:00 PM	0.42
9/3/2014	3:15:00 PM	0.42
9/3/2014	3:30:00 PM	0.42
9/3/2014	3:45:00 PM	0.42
9/3/2014	4:00:00 PM	0.42
9/3/2014	4:15:00 PM	0.42
9/3/2014	4:30:00 PM	0.42
9/3/2014	4:45:00 PM	0.41
9/3/2014	5:00:00 PM	0.42
9/3/2014	5:15:00 PM	0.42
9/3/2014	5:30:00 PM	0.42
9/3/2014	5:45:00 PM	0.42
9/3/2014	6:00:00 PM	0.42
9/3/2014	6:15:00 PM	0.42
9/3/2014	6:30:00 PM	0.42
9/3/2014	6:45:00 PM	0.42
9/3/2014	7:00:00 PM	0.42
9/3/2014	7:15:00 PM	0.41
9/3/2014	7:30:00 PM	0.41
9/3/2014	7:45:00 PM	0.41
9/3/2014	8:00:00 PM	0.41
9/3/2014	8:15:00 PM	0.41
9/3/2014	8:30:00 PM	0.41
9/3/2014	8:45:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
9/3/2014	9:00:00 PM	0.41
9/3/2014	9:15:00 PM	0.41
9/3/2014	9:30:00 PM	0.41
9/3/2014	9:45:00 PM	0.41
9/3/2014	10:00:00 PM	0.41
9/3/2014	10:15:00 PM	0.42
9/3/2014	10:30:00 PM	0.42
9/3/2014	10:45:00 PM	0.42
9/3/2014	11:00:00 PM	0.42
9/3/2014	11:15:00 PM	0.42
9/3/2014	11:30:00 PM	0.42
9/3/2014	11:45:00 PM	0.42
9/4/2014	12:00:00 AM	0.42
9/4/2014	12:15:00 AM	0.42
9/4/2014	12:30:00 AM	0.42
9/4/2014	12:45:00 AM	0.42
9/4/2014	1:00:00 AM	0.42
9/4/2014	1:15:00 AM	0.42
9/4/2014	1:30:00 AM	0.42
9/4/2014	1:45:00 AM	0.42
9/4/2014	2:00:00 AM	0.42
9/4/2014	2:15:00 AM	0.42
9/4/2014	2:30:00 AM	0.42
9/4/2014	2:45:00 AM	0.42
9/4/2014	3:00:00 AM	0.42
9/4/2014	3:15:00 AM	0.42
9/4/2014	3:30:00 AM	0.42
9/4/2014	3:45:00 AM	0.42
9/4/2014	4:00:00 AM	0.42
9/4/2014	4:15:00 AM	0.42
9/4/2014	4:30:00 AM	0.43
9/4/2014	4:45:00 AM	0.43
9/4/2014	5:00:00 AM	0.43
9/4/2014	5:15:00 AM	0.43
9/4/2014	5:30:00 AM	0.43
9/4/2014	5:45:00 AM	0.43
9/4/2014	6:00:00 AM	0.43
9/4/2014	6:15:00 AM	0.43
9/4/2014	6:30:00 AM	0.43
9/4/2014	6:45:00 AM	0.43
9/4/2014	7:00:00 AM	0.43
9/4/2014	7:15:00 AM	0.43
9/4/2014	7:30:00 AM	0.43
9/4/2014	7:45:00 AM	0.43
9/4/2014	8:00:00 AM	0.43
9/4/2014	8:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/4/2014	8:30:00 AM	0.43
9/4/2014	8:45:00 AM	0.43
9/4/2014	9:00:00 AM	0.43
9/4/2014	9:15:00 AM	0.44
9/4/2014	9:30:00 AM	0.44
9/4/2014	9:45:00 AM	0.44
9/4/2014	10:00:00 AM	0.43
9/4/2014	10:15:00 AM	0.43
9/4/2014	10:30:00 AM	0.43
9/4/2014	10:45:00 AM	0.42
9/4/2014	11:00:00 AM	0.42
9/4/2014	11:15:00 AM	0.42
9/4/2014	11:30:00 AM	0.43
9/4/2014	11:45:00 AM	0.42
9/4/2014	12:00:00 PM	0.42
9/4/2014	12:15:00 PM	0.42
9/4/2014	12:30:00 PM	0.42
9/4/2014	12:45:00 PM	0.42
9/4/2014	1:00:00 PM	0.42
9/4/2014	1:15:00 PM	0.42
9/4/2014	1:30:00 PM	0.42
9/4/2014	1:45:00 PM	0.42
9/4/2014	2:00:00 PM	0.42
9/4/2014	2:15:00 PM	0.42
9/4/2014	2:30:00 PM	0.42
9/4/2014	2:45:00 PM	0.42
9/4/2014	3:00:00 PM	0.42
9/4/2014	3:15:00 PM	0.42
9/4/2014	3:30:00 PM	0.42
9/4/2014	3:45:00 PM	0.42
9/4/2014	4:00:00 PM	0.41
9/4/2014	4:15:00 PM	0.41
9/4/2014	4:30:00 PM	0.41
9/4/2014	4:45:00 PM	0.41
9/4/2014	5:00:00 PM	0.41
9/4/2014	5:15:00 PM	0.41
9/4/2014	5:30:00 PM	0.41
9/4/2014	5:45:00 PM	0.41
9/4/2014	6:00:00 PM	0.41
9/4/2014	6:15:00 PM	0.4
9/4/2014	6:30:00 PM	0.4
9/4/2014	6:45:00 PM	0.4
9/4/2014	7:00:00 PM	0.4
9/4/2014	7:15:00 PM	0.4
9/4/2014	7:30:00 PM	0.4
9/4/2014	7:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/4/2014	8:00:00 PM	0.4
9/4/2014	8:15:00 PM	0.4
9/4/2014	8:30:00 PM	0.4
9/4/2014	8:45:00 PM	0.4
9/4/2014	9:00:00 PM	0.4
9/4/2014	9:15:00 PM	0.4
9/4/2014	9:30:00 PM	0.4
9/4/2014	9:45:00 PM	0.4
9/4/2014	10:00:00 PM	0.4
9/4/2014	10:15:00 PM	0.41
9/4/2014	10:30:00 PM	0.41
9/4/2014	10:45:00 PM	0.41
9/4/2014	11:00:00 PM	0.41
9/4/2014	11:15:00 PM	0.41
9/4/2014	11:30:00 PM	0.41
9/4/2014	11:45:00 PM	0.41
9/5/2014	12:00:00 AM	0.41
9/5/2014	12:15:00 AM	0.41
9/5/2014	12:30:00 AM	0.41
9/5/2014	12:45:00 AM	0.41
9/5/2014	1:00:00 AM	0.42
9/5/2014	1:15:00 AM	0.42
9/5/2014	1:30:00 AM	0.42
9/5/2014	1:45:00 AM	0.42
9/5/2014	2:00:00 AM	0.42
9/5/2014	2:15:00 AM	0.42
9/5/2014	2:30:00 AM	0.42
9/5/2014	2:45:00 AM	0.42
9/5/2014	3:00:00 AM	0.42
9/5/2014	3:15:00 AM	0.42
9/5/2014	3:30:00 AM	0.42
9/5/2014	3:45:00 AM	0.42
9/5/2014	4:00:00 AM	0.42
9/5/2014	4:15:00 AM	0.42
9/5/2014	4:30:00 AM	0.42
9/5/2014	4:45:00 AM	0.42
9/5/2014	5:00:00 AM	0.42
9/5/2014	5:15:00 AM	0.42
9/5/2014	5:30:00 AM	0.42
9/5/2014	5:45:00 AM	0.42
9/5/2014	6:00:00 AM	0.42
9/5/2014	6:15:00 AM	0.42
9/5/2014	6:30:00 AM	0.42
9/5/2014	6:45:00 AM	0.42
9/5/2014	7:00:00 AM	0.42
9/5/2014	7:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/5/2014	7:30:00 AM	0.42
9/5/2014	7:45:00 AM	0.42
9/5/2014	8:00:00 AM	0.42
9/5/2014	8:15:00 AM	0.42
9/5/2014	8:30:00 AM	0.42
9/5/2014	8:45:00 AM	0.42
9/5/2014	9:00:00 AM	0.42
9/5/2014	9:15:00 AM	0.42
9/5/2014	9:30:00 AM	0.42
9/5/2014	9:45:00 AM	0.42
9/5/2014	10:00:00 AM	0.42
9/5/2014	10:15:00 AM	0.42
9/5/2014	10:30:00 AM	0.42
9/5/2014	10:45:00 AM	0.42
9/5/2014	11:00:00 AM	0.42
9/5/2014	11:15:00 AM	0.42
9/5/2014	11:30:00 AM	0.42
9/5/2014	11:45:00 AM	0.42
9/5/2014	12:00:00 PM	0.42
9/5/2014	12:15:00 PM	0.42
9/5/2014	12:30:00 PM	0.42
9/5/2014	12:45:00 PM	0.42
9/5/2014	1:00:00 PM	0.42
9/5/2014	1:15:00 PM	0.42
9/5/2014	1:30:00 PM	0.42
9/5/2014	1:45:00 PM	0.42
9/5/2014	2:00:00 PM	0.41
9/5/2014	2:15:00 PM	0.41
9/5/2014	2:30:00 PM	0.42
9/5/2014	2:45:00 PM	0.41
9/5/2014	3:00:00 PM	0.4
9/5/2014	3:15:00 PM	0.41
9/5/2014	3:30:00 PM	0.41
9/5/2014	3:45:00 PM	0.41
9/5/2014	4:00:00 PM	0.4
9/5/2014	4:15:00 PM	0.4
9/5/2014	4:30:00 PM	0.4
9/5/2014	4:45:00 PM	0.4
9/5/2014	5:00:00 PM	0.4
9/5/2014	5:15:00 PM	0.4
9/5/2014	5:30:00 PM	0.4
9/5/2014	5:45:00 PM	0.4
9/5/2014	6:00:00 PM	0.4
9/5/2014	6:15:00 PM	0.4
9/5/2014	6:30:00 PM	0.4
9/5/2014	6:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/5/2014	7:00:00 PM	0.4
9/5/2014	7:15:00 PM	0.4
9/5/2014	7:30:00 PM	0.4
9/5/2014	7:45:00 PM	0.4
9/5/2014	8:00:00 PM	0.4
9/5/2014	8:15:00 PM	0.4
9/5/2014	8:30:00 PM	0.4
9/5/2014	8:45:00 PM	0.4
9/5/2014	9:00:00 PM	0.4
9/5/2014	9:15:00 PM	0.4
9/5/2014	9:30:00 PM	0.4
9/5/2014	9:45:00 PM	0.4
9/5/2014	10:00:00 PM	0.4
9/5/2014	10:15:00 PM	0.4
9/5/2014	10:30:00 PM	0.4
9/5/2014	10:45:00 PM	0.4
9/5/2014	11:00:00 PM	0.4
9/5/2014	11:15:00 PM	0.4
9/5/2014	11:30:00 PM	0.41
9/5/2014	11:45:00 PM	0.42
9/6/2014	12:00:00 AM	0.42
9/6/2014	12:15:00 AM	0.42
9/6/2014	12:30:00 AM	0.42
9/6/2014	12:45:00 AM	0.42
9/6/2014	1:00:00 AM	0.42
9/6/2014	1:15:00 AM	0.42
9/6/2014	1:30:00 AM	0.41
9/6/2014	1:45:00 AM	0.42
9/6/2014	2:00:00 AM	0.42
9/6/2014	2:15:00 AM	0.42
9/6/2014	2:30:00 AM	0.42
9/6/2014	2:45:00 AM	0.42
9/6/2014	3:00:00 AM	0.42
9/6/2014	3:15:00 AM	0.42
9/6/2014	3:30:00 AM	0.42
9/6/2014	3:45:00 AM	0.42
9/6/2014	4:00:00 AM	0.42
9/6/2014	4:15:00 AM	0.42
9/6/2014	4:30:00 AM	0.42
9/6/2014	4:45:00 AM	0.42
9/6/2014	5:00:00 AM	0.42
9/6/2014	5:15:00 AM	0.42
9/6/2014	5:30:00 AM	0.42
9/6/2014	5:45:00 AM	0.42
9/6/2014	6:00:00 AM	0.42
9/6/2014	6:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/6/2014	6:30:00 AM	0.42
9/6/2014	6:45:00 AM	0.42
9/6/2014	7:00:00 AM	0.42
9/6/2014	7:15:00 AM	0.42
9/6/2014	7:30:00 AM	0.42
9/6/2014	7:45:00 AM	0.42
9/6/2014	8:00:00 AM	0.42
9/6/2014	8:15:00 AM	0.42
9/6/2014	8:30:00 AM	0.43
9/6/2014	8:45:00 AM	0.43
9/6/2014	9:00:00 AM	0.43
9/6/2014	9:15:00 AM	0.43
9/6/2014	9:30:00 AM	0.43
9/6/2014	9:45:00 AM	0.43
9/6/2014	10:00:00 AM	0.43
9/6/2014	10:15:00 AM	0.43
9/6/2014	10:30:00 AM	0.43
9/6/2014	10:45:00 AM	0.43
9/6/2014	11:00:00 AM	0.43
9/6/2014	11:15:00 AM	0.42
9/6/2014	11:30:00 AM	0.42
9/6/2014	11:45:00 AM	0.42
9/6/2014	12:00:00 PM	0.42
9/6/2014	12:15:00 PM	0.42
9/6/2014	12:30:00 PM	0.42
9/6/2014	12:45:00 PM	0.42
9/6/2014	1:00:00 PM	0.42
9/6/2014	1:15:00 PM	0.42
9/6/2014	1:30:00 PM	0.42
9/6/2014	1:45:00 PM	0.42
9/6/2014	2:00:00 PM	0.42
9/6/2014	2:15:00 PM	0.42
9/6/2014	2:30:00 PM	0.41
9/6/2014	2:45:00 PM	0.42
9/6/2014	3:00:00 PM	0.42
9/6/2014	3:15:00 PM	0.41
9/6/2014	3:30:00 PM	0.41
9/6/2014	3:45:00 PM	0.4
9/6/2014	4:00:00 PM	0.4
9/6/2014	4:15:00 PM	0.4
9/6/2014	4:30:00 PM	0.4
9/6/2014	4:45:00 PM	0.4
9/6/2014	5:00:00 PM	0.4
9/6/2014	5:15:00 PM	0.4
9/6/2014	5:30:00 PM	0.4
9/6/2014	5:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/6/2014	6:00:00 PM	0.4
9/6/2014	6:15:00 PM	0.4
9/6/2014	6:30:00 PM	0.4
9/6/2014	6:45:00 PM	0.4
9/6/2014	7:00:00 PM	0.4
9/6/2014	7:15:00 PM	0.4
9/6/2014	7:30:00 PM	0.4
9/6/2014	7:45:00 PM	0.4
9/6/2014	8:00:00 PM	0.4
9/6/2014	8:15:00 PM	0.4
9/6/2014	8:30:00 PM	0.4
9/6/2014	8:45:00 PM	0.4
9/6/2014	9:00:00 PM	0.4
9/6/2014	9:15:00 PM	0.4
9/6/2014	9:30:00 PM	0.4
9/6/2014	9:45:00 PM	0.4
9/6/2014	10:00:00 PM	0.4
9/6/2014	10:15:00 PM	0.4
9/6/2014	10:30:00 PM	0.4
9/6/2014	10:45:00 PM	0.4
9/6/2014	11:00:00 PM	0.41
9/6/2014	11:15:00 PM	0.41
9/6/2014	11:30:00 PM	0.41
9/6/2014	11:45:00 PM	0.41
9/7/2014	12:00:00 AM	0.41
9/7/2014	12:15:00 AM	0.42
9/7/2014	12:30:00 AM	0.42
9/7/2014	12:45:00 AM	0.42
9/7/2014	1:00:00 AM	0.42
9/7/2014	1:15:00 AM	0.42
9/7/2014	1:30:00 AM	0.42
9/7/2014	1:45:00 AM	0.42
9/7/2014	2:00:00 AM	0.42
9/7/2014	2:15:00 AM	0.42
9/7/2014	2:30:00 AM	0.42
9/7/2014	2:45:00 AM	0.42
9/7/2014	3:00:00 AM	0.42
9/7/2014	3:15:00 AM	0.42
9/7/2014	3:30:00 AM	0.42
9/7/2014	3:45:00 AM	0.42
9/7/2014	4:00:00 AM	0.42
9/7/2014	4:15:00 AM	0.42
9/7/2014	4:30:00 AM	0.42
9/7/2014	4:45:00 AM	0.42
9/7/2014	5:00:00 AM	0.42
9/7/2014	5:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/7/2014	5:30:00 AM	0.42
9/7/2014	5:45:00 AM	0.42
9/7/2014	6:00:00 AM	0.42
9/7/2014	6:15:00 AM	0.42
9/7/2014	6:30:00 AM	0.42
9/7/2014	6:45:00 AM	0.42
9/7/2014	7:00:00 AM	0.42
9/7/2014	7:15:00 AM	0.42
9/7/2014	7:30:00 AM	0.42
9/7/2014	7:45:00 AM	0.42
9/7/2014	8:00:00 AM	0.42
9/7/2014	8:15:00 AM	0.43
9/7/2014	8:30:00 AM	0.43
9/7/2014	8:45:00 AM	0.43
9/7/2014	9:00:00 AM	0.43
9/7/2014	9:15:00 AM	0.43
9/7/2014	9:30:00 AM	0.43
9/7/2014	9:45:00 AM	0.43
9/7/2014	10:00:00 AM	0.43
9/7/2014	10:15:00 AM	0.43
9/7/2014	10:30:00 AM	0.43
9/7/2014	10:45:00 AM	0.43
9/7/2014	11:00:00 AM	0.43
9/7/2014	11:15:00 AM	0.43
9/7/2014	11:30:00 AM	0.43
9/7/2014	11:45:00 AM	0.43
9/7/2014	12:00:00 PM	0.42
9/7/2014	12:15:00 PM	0.42
9/7/2014	12:30:00 PM	0.42
9/7/2014	12:45:00 PM	0.42
9/7/2014	1:00:00 PM	0.42
9/7/2014	1:15:00 PM	0.42
9/7/2014	1:30:00 PM	0.42
9/7/2014	1:45:00 PM	0.42
9/7/2014	2:00:00 PM	0.42
9/7/2014	2:15:00 PM	0.42
9/7/2014	2:30:00 PM	0.42
9/7/2014	2:45:00 PM	0.42
9/7/2014	3:00:00 PM	0.42
9/7/2014	3:15:00 PM	0.41
9/7/2014	3:30:00 PM	0.42
9/7/2014	3:45:00 PM	0.42
9/7/2014	4:00:00 PM	0.42
9/7/2014	4:15:00 PM	0.41
9/7/2014	4:30:00 PM	0.41
9/7/2014	4:45:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
9/7/2014	5:00:00 PM	0.41
9/7/2014	5:15:00 PM	0.41
9/7/2014	5:30:00 PM	0.4
9/7/2014	5:45:00 PM	0.4
9/7/2014	6:00:00 PM	0.4
9/7/2014	6:15:00 PM	0.4
9/7/2014	6:30:00 PM	0.4
9/7/2014	6:45:00 PM	0.4
9/7/2014	7:00:00 PM	0.41
9/7/2014	7:15:00 PM	0.41
9/7/2014	7:30:00 PM	0.41
9/7/2014	7:45:00 PM	0.41
9/7/2014	8:00:00 PM	0.41
9/7/2014	8:15:00 PM	0.41
9/7/2014	8:30:00 PM	0.41
9/7/2014	8:45:00 PM	0.42
9/7/2014	9:00:00 PM	0.42
9/7/2014	9:15:00 PM	0.42
9/7/2014	9:30:00 PM	0.42
9/7/2014	9:45:00 PM	0.42
9/7/2014	10:00:00 PM	0.42
9/7/2014	10:15:00 PM	0.41
9/7/2014	10:30:00 PM	0.42
9/7/2014	10:45:00 PM	0.42
9/7/2014	11:00:00 PM	0.42
9/7/2014	11:15:00 PM	0.42
9/7/2014	11:30:00 PM	0.42
9/7/2014	11:45:00 PM	0.42
9/8/2014	12:00:00 AM	0.42
9/8/2014	12:15:00 AM	0.42
9/8/2014	12:30:00 AM	0.42
9/8/2014	12:45:00 AM	0.42
9/8/2014	1:00:00 AM	0.42
9/8/2014	1:15:00 AM	0.42
9/8/2014	1:30:00 AM	0.42
9/8/2014	1:45:00 AM	0.42
9/8/2014	2:00:00 AM	0.42
9/8/2014	2:15:00 AM	0.42
9/8/2014	2:30:00 AM	0.43
9/8/2014	2:45:00 AM	0.43
9/8/2014	3:00:00 AM	0.43
9/8/2014	3:15:00 AM	0.43
9/8/2014	3:30:00 AM	0.43
9/8/2014	3:45:00 AM	0.43
9/8/2014	4:00:00 AM	0.43
9/8/2014	4:15:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
9/8/2014	4:30:00 AM	0.43
9/8/2014	4:45:00 AM	0.43
9/8/2014	5:00:00 AM	0.43
9/8/2014	5:15:00 AM	0.43
9/8/2014	5:30:00 AM	0.43
9/8/2014	5:45:00 AM	0.43
9/8/2014	6:00:00 AM	0.44
9/8/2014	6:15:00 AM	0.44
9/8/2014	6:30:00 AM	0.44
9/8/2014	6:45:00 AM	0.44
9/8/2014	7:00:00 AM	0.44
9/8/2014	7:15:00 AM	0.44
9/8/2014	7:30:00 AM	0.44
9/8/2014	7:45:00 AM	0.44
9/8/2014	8:00:00 AM	0.44
9/8/2014	8:15:00 AM	0.44
9/8/2014	8:30:00 AM	0.44
9/8/2014	8:45:00 AM	0.44
9/8/2014	9:00:00 AM	0.44
9/8/2014	9:15:00 AM	0.44
9/8/2014	9:30:00 AM	0.44
9/8/2014	9:45:00 AM	0.44
9/8/2014	10:00:00 AM	0.44
9/8/2014	10:15:00 AM	0.44
9/8/2014	10:30:00 AM	0.44
9/8/2014	10:45:00 AM	0.44
9/8/2014	11:00:00 AM	0.44
9/8/2014	11:15:00 AM	0.44
9/8/2014	11:30:00 AM	0.44
9/8/2014	11:45:00 AM	0.44
9/8/2014	12:00:00 PM	0.44
9/8/2014	12:15:00 PM	0.44
9/8/2014	12:30:00 PM	0.44
9/8/2014	12:45:00 PM	0.44
9/8/2014	1:00:00 PM	0.44
9/8/2014	1:15:00 PM	0.44
9/8/2014	1:30:00 PM	0.44
9/8/2014	1:45:00 PM	0.44
9/8/2014	2:00:00 PM	0.44
9/8/2014	2:15:00 PM	0.44
9/8/2014	2:30:00 PM	0.44
9/8/2014	2:45:00 PM	0.44
9/8/2014	3:00:00 PM	0.44
9/8/2014	3:15:00 PM	0.43
9/8/2014	3:30:00 PM	0.43
9/8/2014	3:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
9/8/2014	4:00:00 PM	0.43
9/8/2014	4:15:00 PM	0.43
9/8/2014	4:30:00 PM	0.44
9/8/2014	4:45:00 PM	0.44
9/8/2014	5:00:00 PM	0.43
9/8/2014	5:15:00 PM	0.44
9/8/2014	5:30:00 PM	0.44
9/8/2014	5:45:00 PM	0.44
9/8/2014	6:00:00 PM	0.43
9/8/2014	6:15:00 PM	0.43
9/8/2014	6:30:00 PM	0.43
9/8/2014	6:45:00 PM	0.43
9/8/2014	7:00:00 PM	0.43
9/8/2014	7:15:00 PM	0.44
9/8/2014	7:30:00 PM	0.44
9/8/2014	7:45:00 PM	0.44
9/8/2014	8:00:00 PM	0.44
9/8/2014	8:15:00 PM	0.44
9/8/2014	8:30:00 PM	0.44
9/8/2014	8:45:00 PM	0.44
9/8/2014	9:00:00 PM	0.44
9/8/2014	9:15:00 PM	0.44
9/8/2014	9:30:00 PM	0.44
9/8/2014	9:45:00 PM	0.44
9/8/2014	10:00:00 PM	0.44
9/8/2014	10:15:00 PM	0.44
9/8/2014	10:30:00 PM	0.44
9/8/2014	10:45:00 PM	0.44
9/8/2014	11:00:00 PM	0.44
9/8/2014	11:15:00 PM	0.44
9/8/2014	11:30:00 PM	0.44
9/8/2014	11:45:00 PM	0.44
9/9/2014	12:00:00 AM	0.44
9/9/2014	12:15:00 AM	0.44
9/9/2014	12:30:00 AM	0.44
9/9/2014	12:45:00 AM	0.44
9/9/2014	1:00:00 AM	0.44
9/9/2014	1:15:00 AM	0.44
9/9/2014	1:30:00 AM	0.44
9/9/2014	1:45:00 AM	0.44
9/9/2014	2:00:00 AM	0.44
9/9/2014	2:15:00 AM	0.44
9/9/2014	2:30:00 AM	0.44
9/9/2014	2:45:00 AM	0.45
9/9/2014	3:00:00 AM	0.45
9/9/2014	3:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
9/9/2014	3:30:00 AM	0.45
9/9/2014	3:45:00 AM	0.45
9/9/2014	4:00:00 AM	0.44
9/9/2014	4:15:00 AM	0.44
9/9/2014	4:30:00 AM	0.45
9/9/2014	4:45:00 AM	0.45
9/9/2014	5:00:00 AM	0.45
9/9/2014	5:15:00 AM	0.45
9/9/2014	5:30:00 AM	0.45
9/9/2014	5:45:00 AM	0.45
9/9/2014	6:00:00 AM	0.45
9/9/2014	6:15:00 AM	0.45
9/9/2014	6:30:00 AM	0.45
9/9/2014	6:45:00 AM	0.45
9/9/2014	7:00:00 AM	0.45
9/9/2014	7:15:00 AM	0.45
9/9/2014	7:30:00 AM	0.45
9/9/2014	7:45:00 AM	0.45
9/9/2014	8:00:00 AM	0.45
9/9/2014	8:15:00 AM	0.45
9/9/2014	8:30:00 AM	0.45
9/9/2014	8:45:00 AM	0.45
9/9/2014	9:00:00 AM	0.46
9/9/2014	9:15:00 AM	0.46
9/9/2014	9:30:00 AM	0.46
9/9/2014	9:45:00 AM	0.46
9/9/2014	10:00:00 AM	0.45
9/9/2014	10:15:00 AM	0.45
9/9/2014	10:30:00 AM	0.45
9/9/2014	10:45:00 AM	0.45
9/9/2014	11:00:00 AM	0.45
9/9/2014	11:15:00 AM	0.45
9/9/2014	11:30:00 AM	0.46
9/9/2014	11:45:00 AM	0.45
9/9/2014	12:00:00 PM	0.45
9/9/2014	12:15:00 PM	0.45
9/9/2014	12:30:00 PM	0.44
9/9/2014	12:45:00 PM	0.44
9/9/2014	1:00:00 PM	0.44
9/9/2014	1:15:00 PM	0.44
9/9/2014	1:30:00 PM	0.44
9/9/2014	1:45:00 PM	0.44
9/9/2014	2:00:00 PM	0.44
9/9/2014	2:15:00 PM	0.44
9/9/2014	2:30:00 PM	0.44
9/9/2014	2:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/9/2014	3:00:00 PM	0.44
9/9/2014	3:15:00 PM	0.44
9/9/2014	3:30:00 PM	0.44
9/9/2014	3:45:00 PM	0.44
9/9/2014	4:00:00 PM	0.44
9/9/2014	4:15:00 PM	0.44
9/9/2014	4:30:00 PM	0.44
9/9/2014	4:45:00 PM	0.44
9/9/2014	5:00:00 PM	0.44
9/9/2014	5:15:00 PM	0.44
9/9/2014	5:30:00 PM	0.44
9/9/2014	5:45:00 PM	0.44
9/9/2014	6:00:00 PM	0.44
9/9/2014	6:15:00 PM	0.44
9/9/2014	6:30:00 PM	0.44
9/9/2014	6:45:00 PM	0.44
9/9/2014	7:00:00 PM	0.44
9/9/2014	7:15:00 PM	0.44
9/9/2014	7:30:00 PM	0.44
9/9/2014	7:45:00 PM	0.44
9/9/2014	8:00:00 PM	0.44
9/9/2014	8:15:00 PM	0.44
9/9/2014	8:30:00 PM	0.44
9/9/2014	8:45:00 PM	0.44
9/9/2014	9:00:00 PM	0.44
9/9/2014	9:15:00 PM	0.44
9/9/2014	9:30:00 PM	0.44
9/9/2014	9:45:00 PM	0.44
9/9/2014	10:00:00 PM	0.44
9/9/2014	10:15:00 PM	0.44
9/9/2014	10:30:00 PM	0.44
9/9/2014	10:45:00 PM	0.44
9/9/2014	11:00:00 PM	0.44
9/9/2014	11:15:00 PM	0.44
9/9/2014	11:30:00 PM	0.44
9/9/2014	11:45:00 PM	0.44
9/10/2014	12:00:00 AM	0.44
9/10/2014	12:15:00 AM	0.44
9/10/2014	12:30:00 AM	0.44
9/10/2014	12:45:00 AM	0.44
9/10/2014	1:00:00 AM	0.44
9/10/2014	1:15:00 AM	0.44
9/10/2014	1:30:00 AM	0.44
9/10/2014	1:45:00 AM	0.44
9/10/2014	2:00:00 AM	0.44
9/10/2014	2:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/10/2014	2:30:00 AM	0.44
9/10/2014	2:45:00 AM	0.44
9/10/2014	3:00:00 AM	0.44
9/10/2014	3:15:00 AM	0.44
9/10/2014	3:30:00 AM	0.44
9/10/2014	3:45:00 AM	0.44
9/10/2014	4:00:00 AM	0.44
9/10/2014	4:15:00 AM	0.44
9/10/2014	4:30:00 AM	0.44
9/10/2014	4:45:00 AM	0.44
9/10/2014	5:00:00 AM	0.44
9/10/2014	5:15:00 AM	0.44
9/10/2014	5:30:00 AM	0.44
9/10/2014	5:45:00 AM	0.44
9/10/2014	6:00:00 AM	0.44
9/10/2014	6:15:00 AM	0.45
9/10/2014	6:30:00 AM	0.44
9/10/2014	6:45:00 AM	0.45
9/10/2014	7:00:00 AM	0.45
9/10/2014	7:15:00 AM	0.45
9/10/2014	7:30:00 AM	0.45
9/10/2014	7:45:00 AM	0.45
9/10/2014	8:00:00 AM	0.45
9/10/2014	8:15:00 AM	0.45
9/10/2014	8:30:00 AM	0.45
9/10/2014	8:45:00 AM	0.45
9/10/2014	9:00:00 AM	0.45
9/10/2014	9:15:00 AM	0.45
9/10/2014	9:30:00 AM	0.45
9/10/2014	9:45:00 AM	0.45
9/10/2014	10:00:00 AM	0.45
9/10/2014	10:15:00 AM	0.45
9/10/2014	10:30:00 AM	0.45
9/10/2014	10:45:00 AM	0.45
9/10/2014	11:00:00 AM	0.45
9/10/2014	11:15:00 AM	0.45
9/10/2014	11:30:00 AM	0.45
9/10/2014	11:45:00 AM	0.45
9/10/2014	12:00:00 PM	0.44
9/10/2014	12:15:00 PM	0.44
9/10/2014	12:30:00 PM	0.44
9/10/2014	12:45:00 PM	0.44
9/10/2014	1:00:00 PM	0.44
9/10/2014	1:15:00 PM	0.44
9/10/2014	1:30:00 PM	0.44
9/10/2014	1:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/10/2014	2:00:00 PM	0.44
9/10/2014	2:15:00 PM	0.44
9/10/2014	2:30:00 PM	0.44
9/10/2014	2:45:00 PM	0.44
9/10/2014	3:00:00 PM	0.44
9/10/2014	3:15:00 PM	0.44
9/10/2014	3:30:00 PM	0.44
9/10/2014	3:45:00 PM	0.43
9/10/2014	4:00:00 PM	0.43
9/10/2014	4:15:00 PM	0.43
9/10/2014	4:30:00 PM	0.43
9/10/2014	4:45:00 PM	0.43
9/10/2014	5:00:00 PM	0.43
9/10/2014	5:15:00 PM	0.43
9/10/2014	5:30:00 PM	0.43
9/10/2014	5:45:00 PM	0.43
9/10/2014	6:00:00 PM	0.42
9/10/2014	6:15:00 PM	0.42
9/10/2014	6:30:00 PM	0.42
9/10/2014	6:45:00 PM	0.42
9/10/2014	7:00:00 PM	0.42
9/10/2014	7:15:00 PM	0.42
9/10/2014	7:30:00 PM	0.42
9/10/2014	7:45:00 PM	0.42
9/10/2014	8:00:00 PM	0.42
9/10/2014	8:15:00 PM	0.42
9/10/2014	8:30:00 PM	0.43
9/10/2014	8:45:00 PM	0.43
9/10/2014	9:00:00 PM	0.43
9/10/2014	9:15:00 PM	0.43
9/10/2014	9:30:00 PM	0.43
9/10/2014	9:45:00 PM	0.43
9/10/2014	10:00:00 PM	0.43
9/10/2014	10:15:00 PM	0.43
9/10/2014	10:30:00 PM	0.43
9/10/2014	10:45:00 PM	0.43
9/10/2014	11:00:00 PM	0.43
9/10/2014	11:15:00 PM	0.43
9/10/2014	11:30:00 PM	0.43
9/10/2014	11:45:00 PM	0.43
9/11/2014	12:00:00 AM	0.44
9/11/2014	12:15:00 AM	0.44
9/11/2014	12:30:00 AM	0.44
9/11/2014	12:45:00 AM	0.44
9/11/2014	1:00:00 AM	0.44
9/11/2014	1:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/11/2014	1:30:00 AM	0.44
9/11/2014	1:45:00 AM	0.44
9/11/2014	2:00:00 AM	0.44
9/11/2014	2:15:00 AM	0.44
9/11/2014	2:30:00 AM	0.44
9/11/2014	2:45:00 AM	0.44
9/11/2014	3:00:00 AM	0.44
9/11/2014	3:15:00 AM	0.44
9/11/2014	3:30:00 AM	0.44
9/11/2014	3:45:00 AM	0.44
9/11/2014	4:00:00 AM	0.44
9/11/2014	4:15:00 AM	0.44
9/11/2014	4:30:00 AM	0.44
9/11/2014	4:45:00 AM	0.44
9/11/2014	5:00:00 AM	0.44
9/11/2014	5:15:00 AM	0.44
9/11/2014	5:30:00 AM	0.44
9/11/2014	5:45:00 AM	0.44
9/11/2014	6:00:00 AM	0.44
9/11/2014	6:15:00 AM	0.44
9/11/2014	6:30:00 AM	0.44
9/11/2014	6:45:00 AM	0.44
9/11/2014	7:00:00 AM	0.44
9/11/2014	7:15:00 AM	0.44
9/11/2014	7:30:00 AM	0.44
9/11/2014	7:45:00 AM	0.44
9/11/2014	8:00:00 AM	0.44
9/11/2014	8:15:00 AM	0.44
9/11/2014	8:30:00 AM	0.44
9/11/2014	8:45:00 AM	0.44
9/11/2014	9:00:00 AM	0.44
9/11/2014	9:15:00 AM	0.44
9/11/2014	9:30:00 AM	0.44
9/11/2014	9:45:00 AM	0.44
9/11/2014	10:00:00 AM	0.44
9/11/2014	10:15:00 AM	0.44
9/11/2014	10:30:00 AM	0.44
9/11/2014	10:45:00 AM	0.44
9/11/2014	11:00:00 AM	0.44
9/11/2014	11:15:00 AM	0.44
9/11/2014	11:30:00 AM	0.44
9/11/2014	11:45:00 AM	0.44
9/11/2014	12:00:00 PM	0.44
9/11/2014	12:15:00 PM	0.44
9/11/2014	12:30:00 PM	0.43
9/11/2014	12:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
9/11/2014	1:00:00 PM	0.43
9/11/2014	1:15:00 PM	0.42
9/11/2014	1:30:00 PM	0.42
9/11/2014	1:45:00 PM	0.42
9/11/2014	2:00:00 PM	0.42
9/11/2014	2:15:00 PM	0.42
9/11/2014	2:30:00 PM	0.42
9/11/2014	2:45:00 PM	0.42
9/11/2014	3:00:00 PM	0.42
9/11/2014	3:15:00 PM	0.42
9/11/2014	3:30:00 PM	0.42
9/11/2014	3:45:00 PM	0.42
9/11/2014	4:00:00 PM	0.42
9/11/2014	4:15:00 PM	0.42
9/11/2014	4:30:00 PM	0.42
9/11/2014	4:45:00 PM	0.42
9/11/2014	5:00:00 PM	0.42
9/11/2014	5:15:00 PM	0.42
9/11/2014	5:30:00 PM	0.42
9/11/2014	5:45:00 PM	0.42
9/11/2014	6:00:00 PM	0.42
9/11/2014	6:15:00 PM	0.42
9/11/2014	6:30:00 PM	0.42
9/11/2014	6:45:00 PM	0.42
9/11/2014	7:00:00 PM	0.42
9/11/2014	7:15:00 PM	0.42
9/11/2014	7:30:00 PM	0.42
9/11/2014	7:45:00 PM	0.42
9/11/2014	8:00:00 PM	0.42
9/11/2014	8:15:00 PM	0.42
9/11/2014	8:30:00 PM	0.42
9/11/2014	8:45:00 PM	0.42
9/11/2014	9:00:00 PM	0.42
9/11/2014	9:15:00 PM	0.42
9/11/2014	9:30:00 PM	0.42
9/11/2014	9:45:00 PM	0.42
9/11/2014	10:00:00 PM	0.42
9/11/2014	10:15:00 PM	0.42
9/11/2014	10:30:00 PM	0.42
9/11/2014	10:45:00 PM	0.42
9/11/2014	11:00:00 PM	0.42
9/11/2014	11:15:00 PM	0.42
9/11/2014	11:30:00 PM	0.42
9/11/2014	11:45:00 PM	0.42
9/12/2014	12:00:00 AM	0.42
9/12/2014	12:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/12/2014	12:30:00 AM	0.42
9/12/2014	12:45:00 AM	0.42
9/12/2014	1:00:00 AM	0.42
9/12/2014	1:15:00 AM	0.42
9/12/2014	1:30:00 AM	0.42
9/12/2014	1:45:00 AM	0.42
9/12/2014	2:00:00 AM	0.42
9/12/2014	2:15:00 AM	0.42
9/12/2014	2:30:00 AM	0.42
9/12/2014	2:45:00 AM	0.42
9/12/2014	3:00:00 AM	0.42
9/12/2014	3:15:00 AM	0.42
9/12/2014	3:30:00 AM	0.42
9/12/2014	3:45:00 AM	0.42
9/12/2014	4:00:00 AM	0.42
9/12/2014	4:15:00 AM	0.42
9/12/2014	4:30:00 AM	0.42
9/12/2014	4:45:00 AM	0.42
9/12/2014	5:00:00 AM	0.42
9/12/2014	5:15:00 AM	0.42
9/12/2014	5:30:00 AM	0.42
9/12/2014	5:45:00 AM	0.42
9/12/2014	6:00:00 AM	0.42
9/12/2014	6:15:00 AM	0.42
9/12/2014	6:30:00 AM	0.42
9/12/2014	6:45:00 AM	0.42
9/12/2014	7:00:00 AM	0.42
9/12/2014	7:15:00 AM	0.42
9/12/2014	7:30:00 AM	0.42
9/12/2014	7:45:00 AM	0.42
9/12/2014	8:00:00 AM	0.42
9/12/2014	8:15:00 AM	0.42
9/12/2014	8:30:00 AM	0.42
9/12/2014	8:45:00 AM	0.42
9/12/2014	9:00:00 AM	0.42
9/12/2014	9:15:00 AM	0.42
9/12/2014	9:30:00 AM	0.42
9/12/2014	9:45:00 AM	0.42
9/12/2014	10:00:00 AM	0.42
9/12/2014	10:15:00 AM	0.42
9/12/2014	10:30:00 AM	0.42
9/12/2014	10:45:00 AM	0.42
9/12/2014	11:00:00 AM	0.42
9/12/2014	11:15:00 AM	0.42
9/12/2014	11:30:00 AM	0.42
9/12/2014	11:45:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/12/2014	12:00:00 PM	0.42
9/12/2014	12:15:00 PM	0.42
9/12/2014	12:30:00 PM	0.42
9/12/2014	12:45:00 PM	0.42
9/12/2014	1:00:00 PM	0.42
9/12/2014	1:15:00 PM	0.42
9/12/2014	1:30:00 PM	0.42
9/12/2014	1:45:00 PM	0.41
9/12/2014	2:00:00 PM	0.4
9/12/2014	2:15:00 PM	0.41
9/12/2014	2:30:00 PM	0.41
9/12/2014	2:45:00 PM	0.41
9/12/2014	3:00:00 PM	0.4
9/12/2014	3:15:00 PM	0.4
9/12/2014	3:30:00 PM	0.4
9/12/2014	3:45:00 PM	0.4
9/12/2014	4:00:00 PM	0.4
9/12/2014	4:15:00 PM	0.4
9/12/2014	4:30:00 PM	0.4
9/12/2014	4:45:00 PM	0.4
9/12/2014	5:00:00 PM	0.4
9/12/2014	5:15:00 PM	0.4
9/12/2014	5:30:00 PM	0.4
9/12/2014	5:45:00 PM	0.4
9/12/2014	6:00:00 PM	0.4
9/12/2014	6:15:00 PM	0.4
9/12/2014	6:30:00 PM	0.4
9/12/2014	6:45:00 PM	0.4
9/12/2014	7:00:00 PM	0.4
9/12/2014	7:15:00 PM	0.4
9/12/2014	7:30:00 PM	0.4
9/12/2014	7:45:00 PM	0.4
9/12/2014	8:00:00 PM	0.4
9/12/2014	8:15:00 PM	0.4
9/12/2014	8:30:00 PM	0.4
9/12/2014	8:45:00 PM	0.4
9/12/2014	9:00:00 PM	0.4
9/12/2014	9:15:00 PM	0.4
9/12/2014	9:30:00 PM	0.4
9/12/2014	9:45:00 PM	0.4
9/12/2014	10:00:00 PM	0.4
9/12/2014	10:15:00 PM	0.4
9/12/2014	10:30:00 PM	0.4
9/12/2014	10:45:00 PM	0.4
9/12/2014	11:00:00 PM	0.4
9/12/2014	11:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/12/2014	11:30:00 PM	0.4
9/12/2014	11:45:00 PM	0.4
9/13/2014	12:00:00 AM	0.4
9/13/2014	12:15:00 AM	0.4
9/13/2014	12:30:00 AM	0.4
9/13/2014	12:45:00 AM	0.4
9/13/2014	1:00:00 AM	0.4
9/13/2014	1:15:00 AM	0.4
9/13/2014	1:30:00 AM	0.4
9/13/2014	1:45:00 AM	0.4
9/13/2014	2:00:00 AM	0.4
9/13/2014	2:15:00 AM	0.4
9/13/2014	2:30:00 AM	0.4
9/13/2014	2:45:00 AM	0.4
9/13/2014	3:00:00 AM	0.4
9/13/2014	3:15:00 AM	0.4
9/13/2014	3:30:00 AM	0.4
9/13/2014	3:45:00 AM	0.4
9/13/2014	4:00:00 AM	0.4
9/13/2014	4:15:00 AM	0.41
9/13/2014	4:30:00 AM	0.41
9/13/2014	4:45:00 AM	0.41
9/13/2014	5:00:00 AM	0.4
9/13/2014	5:15:00 AM	0.4
9/13/2014	5:30:00 AM	0.4
9/13/2014	5:45:00 AM	0.4
9/13/2014	6:00:00 AM	0.4
9/13/2014	6:15:00 AM	0.4
9/13/2014	6:30:00 AM	0.4
9/13/2014	6:45:00 AM	0.4
9/13/2014	7:00:00 AM	0.4
9/13/2014	7:15:00 AM	0.4
9/13/2014	7:30:00 AM	0.4
9/13/2014	7:45:00 AM	0.4
9/13/2014	8:00:00 AM	0.4
9/13/2014	8:15:00 AM	0.4
9/13/2014	8:30:00 AM	0.4
9/13/2014	8:45:00 AM	0.4
9/13/2014	9:00:00 AM	0.4
9/13/2014	9:15:00 AM	0.4
9/13/2014	9:30:00 AM	0.41
9/13/2014	9:45:00 AM	0.41
9/13/2014	10:00:00 AM	0.4
9/13/2014	10:15:00 AM	0.4
9/13/2014	10:30:00 AM	0.4
9/13/2014	10:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/13/2014	11:00:00 AM	0.4
9/13/2014	11:15:00 AM	0.4
9/13/2014	11:30:00 AM	0.4
9/13/2014	11:45:00 AM	0.4
9/13/2014	12:00:00 PM	0.4
9/13/2014	12:15:00 PM	0.4
9/13/2014	12:30:00 PM	0.4
9/13/2014	12:45:00 PM	0.4
9/13/2014	1:00:00 PM	0.4
9/13/2014	1:15:00 PM	0.4
9/13/2014	1:30:00 PM	0.4
9/13/2014	1:45:00 PM	0.4
9/13/2014	2:00:00 PM	0.4
9/13/2014	2:15:00 PM	0.4
9/13/2014	2:30:00 PM	0.4
9/13/2014	2:45:00 PM	0.39
9/13/2014	3:00:00 PM	0.4
9/13/2014	3:15:00 PM	0.4
9/13/2014	3:30:00 PM	0.4
9/13/2014	3:45:00 PM	0.4
9/13/2014	4:00:00 PM	0.39
9/13/2014	4:15:00 PM	0.39
9/13/2014	4:30:00 PM	0.38
9/13/2014	4:45:00 PM	0.38
9/13/2014	5:00:00 PM	0.38
9/13/2014	5:15:00 PM	0.38
9/13/2014	5:30:00 PM	0.38
9/13/2014	5:45:00 PM	0.38
9/13/2014	6:00:00 PM	0.38
9/13/2014	6:15:00 PM	0.38
9/13/2014	6:30:00 PM	0.38
9/13/2014	6:45:00 PM	0.38
9/13/2014	7:00:00 PM	0.38
9/13/2014	7:15:00 PM	0.38
9/13/2014	7:30:00 PM	0.38
9/13/2014	7:45:00 PM	0.38
9/13/2014	8:00:00 PM	0.38
9/13/2014	8:15:00 PM	0.38
9/13/2014	8:30:00 PM	0.38
9/13/2014	8:45:00 PM	0.38
9/13/2014	9:00:00 PM	0.38
9/13/2014	9:15:00 PM	0.38
9/13/2014	9:30:00 PM	0.39
9/13/2014	9:45:00 PM	0.39
9/13/2014	10:00:00 PM	0.38
9/13/2014	10:15:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
9/13/2014	10:30:00 PM	0.39
9/13/2014	10:45:00 PM	0.39
9/13/2014	11:00:00 PM	0.39
9/13/2014	11:15:00 PM	0.39
9/13/2014	11:30:00 PM	0.39
9/13/2014	11:45:00 PM	0.4
9/14/2014	12:00:00 AM	0.39
9/14/2014	12:15:00 AM	0.4
9/14/2014	12:30:00 AM	0.4
9/14/2014	12:45:00 AM	0.4
9/14/2014	1:00:00 AM	0.4
9/14/2014	1:15:00 AM	0.4
9/14/2014	1:30:00 AM	0.4
9/14/2014	1:45:00 AM	0.4
9/14/2014	2:00:00 AM	0.4
9/14/2014	2:15:00 AM	0.4
9/14/2014	2:30:00 AM	0.4
9/14/2014	2:45:00 AM	0.4
9/14/2014	3:00:00 AM	0.4
9/14/2014	3:15:00 AM	0.4
9/14/2014	3:30:00 AM	0.4
9/14/2014	3:45:00 AM	0.4
9/14/2014	4:00:00 AM	0.4
9/14/2014	4:15:00 AM	0.4
9/14/2014	4:30:00 AM	0.4
9/14/2014	4:45:00 AM	0.4
9/14/2014	5:00:00 AM	0.4
9/14/2014	5:15:00 AM	0.4
9/14/2014	5:30:00 AM	0.4
9/14/2014	5:45:00 AM	0.4
9/14/2014	6:00:00 AM	0.4
9/14/2014	6:15:00 AM	0.4
9/14/2014	6:30:00 AM	0.4
9/14/2014	6:45:00 AM	0.4
9/14/2014	7:00:00 AM	0.4
9/14/2014	7:15:00 AM	0.4
9/14/2014	7:30:00 AM	0.4
9/14/2014	7:45:00 AM	0.4
9/14/2014	8:00:00 AM	0.4
9/14/2014	8:15:00 AM	0.4
9/14/2014	8:30:00 AM	0.4
9/14/2014	8:45:00 AM	0.4
9/14/2014	9:00:00 AM	0.4
9/14/2014	9:15:00 AM	0.4
9/14/2014	9:30:00 AM	0.4
9/14/2014	9:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/14/2014	10:00:00 AM	0.4
9/14/2014	10:15:00 AM	0.4
9/14/2014	10:30:00 AM	0.4
9/14/2014	10:45:00 AM	0.4
9/14/2014	11:00:00 AM	0.4
9/14/2014	11:15:00 AM	0.4
9/14/2014	11:30:00 AM	0.4
9/14/2014	11:45:00 AM	0.4
9/14/2014	12:00:00 PM	0.4
9/14/2014	12:15:00 PM	0.4
9/14/2014	12:30:00 PM	0.4
9/14/2014	12:45:00 PM	0.4
9/14/2014	1:00:00 PM	0.4
9/14/2014	1:15:00 PM	0.39
9/14/2014	1:30:00 PM	0.39
9/14/2014	1:45:00 PM	0.39
9/14/2014	2:00:00 PM	0.38
9/14/2014	2:15:00 PM	0.38
9/14/2014	2:30:00 PM	0.38
9/14/2014	2:45:00 PM	0.38
9/14/2014	3:00:00 PM	0.38
9/14/2014	3:15:00 PM	0.38
9/14/2014	3:30:00 PM	0.38
9/14/2014	3:45:00 PM	0.38
9/14/2014	4:00:00 PM	0.38
9/14/2014	4:15:00 PM	0.38
9/14/2014	4:30:00 PM	0.38
9/14/2014	4:45:00 PM	0.38
9/14/2014	5:00:00 PM	0.38
9/14/2014	5:15:00 PM	0.38
9/14/2014	5:30:00 PM	0.38
9/14/2014	5:45:00 PM	0.38
9/14/2014	6:00:00 PM	0.38
9/14/2014	6:15:00 PM	0.38
9/14/2014	6:30:00 PM	0.38
9/14/2014	6:45:00 PM	0.38
9/14/2014	7:00:00 PM	0.38
9/14/2014	7:15:00 PM	0.38
9/14/2014	7:30:00 PM	0.38
9/14/2014	7:45:00 PM	0.38
9/14/2014	8:00:00 PM	0.38
9/14/2014	8:15:00 PM	0.38
9/14/2014	8:30:00 PM	0.38
9/14/2014	8:45:00 PM	0.38
9/14/2014	9:00:00 PM	0.38
9/14/2014	9:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
9/14/2014	9:30:00 PM	0.38
9/14/2014	9:45:00 PM	0.38
9/14/2014	10:00:00 PM	0.38
9/14/2014	10:15:00 PM	0.38
9/14/2014	10:30:00 PM	0.38
9/14/2014	10:45:00 PM	0.38
9/14/2014	11:00:00 PM	0.38
9/14/2014	11:15:00 PM	0.38
9/14/2014	11:30:00 PM	0.38
9/14/2014	11:45:00 PM	0.38
9/15/2014	12:00:00 AM	0.38
9/15/2014	12:15:00 AM	0.38
9/15/2014	12:30:00 AM	0.38
9/15/2014	12:45:00 AM	0.38
9/15/2014	1:00:00 AM	0.38
9/15/2014	1:15:00 AM	0.38
9/15/2014	1:30:00 AM	0.39
9/15/2014	1:45:00 AM	0.39
9/15/2014	2:00:00 AM	0.39
9/15/2014	2:15:00 AM	0.39
9/15/2014	2:30:00 AM	0.39
9/15/2014	2:45:00 AM	0.39
9/15/2014	3:00:00 AM	0.39
9/15/2014	3:15:00 AM	0.39
9/15/2014	3:30:00 AM	0.39
9/15/2014	3:45:00 AM	0.39
9/15/2014	4:00:00 AM	0.39
9/15/2014	4:15:00 AM	0.39
9/15/2014	4:30:00 AM	0.39
9/15/2014	4:45:00 AM	0.4
9/15/2014	5:00:00 AM	0.39
9/15/2014	5:15:00 AM	0.39
9/15/2014	5:30:00 AM	0.39
9/15/2014	5:45:00 AM	0.39
9/15/2014	6:00:00 AM	0.39
9/15/2014	6:15:00 AM	0.39
9/15/2014	6:30:00 AM	0.39
9/15/2014	6:45:00 AM	0.39
9/15/2014	7:00:00 AM	0.39
9/15/2014	7:15:00 AM	0.39
9/15/2014	7:30:00 AM	0.4
9/15/2014	7:45:00 AM	0.4
9/15/2014	8:00:00 AM	0.4
9/15/2014	8:15:00 AM	0.4
9/15/2014	8:30:00 AM	0.4
9/15/2014	8:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/15/2014	9:00:00 AM	0.4
9/15/2014	9:15:00 AM	0.4
9/15/2014	9:30:00 AM	0.4
9/15/2014	9:45:00 AM	0.4
9/15/2014	10:00:00 AM	0.4
9/15/2014	10:15:00 AM	0.4
9/15/2014	10:30:00 AM	0.4
9/15/2014	10:45:00 AM	0.4
9/15/2014	11:00:00 AM	0.4
9/15/2014	11:15:00 AM	0.4
9/15/2014	11:30:00 AM	0.4
9/15/2014	11:45:00 AM	0.4
9/15/2014	12:00:00 PM	0.4
9/15/2014	12:15:00 PM	0.39
9/15/2014	12:30:00 PM	0.39
9/15/2014	12:45:00 PM	0.39
9/15/2014	1:00:00 PM	0.38
9/15/2014	1:15:00 PM	0.38
9/15/2014	1:30:00 PM	0.38
9/15/2014	1:45:00 PM	0.38
9/15/2014	2:00:00 PM	0.38
9/15/2014	2:15:00 PM	0.38
9/15/2014	2:30:00 PM	0.38
9/15/2014	2:45:00 PM	0.38
9/15/2014	3:00:00 PM	0.38
9/15/2014	3:15:00 PM	0.38
9/15/2014	3:30:00 PM	0.38
9/15/2014	3:45:00 PM	0.38
9/15/2014	4:00:00 PM	0.38
9/15/2014	4:15:00 PM	0.38
9/15/2014	4:30:00 PM	0.38
9/15/2014	4:45:00 PM	0.38
9/15/2014	5:00:00 PM	0.38
9/15/2014	5:15:00 PM	0.38
9/15/2014	5:30:00 PM	0.38
9/15/2014	5:45:00 PM	0.38
9/15/2014	6:00:00 PM	0.38
9/15/2014	6:15:00 PM	0.38
9/15/2014	6:30:00 PM	0.38
9/15/2014	6:45:00 PM	0.38
9/15/2014	7:00:00 PM	0.38
9/15/2014	7:15:00 PM	0.38
9/15/2014	7:30:00 PM	0.38
9/15/2014	7:45:00 PM	0.38
9/15/2014	8:00:00 PM	0.38
9/15/2014	8:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
9/15/2014	8:30:00 PM	0.38
9/15/2014	8:45:00 PM	0.38
9/15/2014	9:00:00 PM	0.38
9/15/2014	9:15:00 PM	0.38
9/15/2014	9:30:00 PM	0.38
9/15/2014	9:45:00 PM	0.38
9/15/2014	10:00:00 PM	0.38
9/15/2014	10:15:00 PM	0.38
9/15/2014	10:30:00 PM	0.38
9/15/2014	10:45:00 PM	0.38
9/15/2014	11:00:00 PM	0.38
9/15/2014	11:15:00 PM	0.38
9/15/2014	11:30:00 PM	0.38
9/15/2014	11:45:00 PM	0.38
9/16/2014	12:00:00 AM	0.38
9/16/2014	12:15:00 AM	0.38
9/16/2014	12:30:00 AM	0.38
9/16/2014	12:45:00 AM	0.38
9/16/2014	1:00:00 AM	0.38
9/16/2014	1:15:00 AM	0.38
9/16/2014	1:30:00 AM	0.38
9/16/2014	1:45:00 AM	0.38
9/16/2014	2:00:00 AM	0.38
9/16/2014	2:15:00 AM	0.39
9/16/2014	2:30:00 AM	0.39
9/16/2014	2:45:00 AM	0.39
9/16/2014	3:00:00 AM	0.39
9/16/2014	3:15:00 AM	0.39
9/16/2014	3:30:00 AM	0.39
9/16/2014	3:45:00 AM	0.39
9/16/2014	4:00:00 AM	0.39
9/16/2014	4:15:00 AM	0.39
9/16/2014	4:30:00 AM	0.39
9/16/2014	4:45:00 AM	0.39
9/16/2014	5:00:00 AM	0.39
9/16/2014	5:15:00 AM	0.39
9/16/2014	5:30:00 AM	0.39
9/16/2014	5:45:00 AM	0.39
9/16/2014	6:00:00 AM	0.39
9/16/2014	6:15:00 AM	0.39
9/16/2014	6:30:00 AM	0.39
9/16/2014	6:45:00 AM	0.39
9/16/2014	7:00:00 AM	0.39
9/16/2014	7:15:00 AM	0.39
9/16/2014	7:30:00 AM	0.4
9/16/2014	7:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/16/2014	8:00:00 AM	0.4
9/16/2014	8:15:00 AM	0.4
9/16/2014	8:30:00 AM	0.4
9/16/2014	8:45:00 AM	0.4
9/16/2014	9:00:00 AM	0.4
9/16/2014	9:15:00 AM	0.4
9/16/2014	9:30:00 AM	0.4
9/16/2014	9:45:00 AM	0.4
9/16/2014	10:00:00 AM	0.4
9/16/2014	10:15:00 AM	0.4
9/16/2014	10:30:00 AM	0.4
9/16/2014	10:45:00 AM	0.4
9/16/2014	11:00:00 AM	0.4
9/16/2014	11:15:00 AM	0.4
9/16/2014	11:30:00 AM	0.4
9/16/2014	11:45:00 AM	0.4
9/16/2014	12:00:00 PM	0.39
9/16/2014	12:15:00 PM	0.39
9/16/2014	12:30:00 PM	0.38
9/16/2014	12:45:00 PM	0.39
9/16/2014	1:00:00 PM	0.39
9/16/2014	1:15:00 PM	0.39
9/16/2014	1:30:00 PM	0.38
9/16/2014	1:45:00 PM	0.38
9/16/2014	2:00:00 PM	0.38
9/16/2014	2:15:00 PM	0.38
9/16/2014	2:30:00 PM	0.38
9/16/2014	2:45:00 PM	0.38
9/16/2014	3:00:00 PM	0.38
9/16/2014	3:15:00 PM	0.38
9/16/2014	3:30:00 PM	0.38
9/16/2014	3:45:00 PM	0.38
9/16/2014	4:00:00 PM	0.38
9/16/2014	4:15:00 PM	0.38
9/16/2014	4:30:00 PM	0.38
9/16/2014	4:45:00 PM	0.38
9/16/2014	5:00:00 PM	0.38
9/16/2014	5:15:00 PM	0.38
9/16/2014	5:30:00 PM	0.37
9/16/2014	5:45:00 PM	0.38
9/16/2014	6:00:00 PM	0.37
9/16/2014	6:15:00 PM	0.37
9/16/2014	6:30:00 PM	0.37
9/16/2014	6:45:00 PM	0.37
9/16/2014	7:00:00 PM	0.38
9/16/2014	7:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
9/16/2014	7:30:00 PM	0.38
9/16/2014	7:45:00 PM	0.37
9/16/2014	8:00:00 PM	0.37
9/16/2014	8:15:00 PM	0.38
9/16/2014	8:30:00 PM	0.38
9/16/2014	8:45:00 PM	0.38
9/16/2014	9:00:00 PM	0.38
9/16/2014	9:15:00 PM	0.38
9/16/2014	9:30:00 PM	0.38
9/16/2014	9:45:00 PM	0.38
9/16/2014	10:00:00 PM	0.38
9/16/2014	10:15:00 PM	0.38
9/16/2014	10:30:00 PM	0.38
9/16/2014	10:45:00 PM	0.38
9/16/2014	11:00:00 PM	0.38
9/16/2014	11:15:00 PM	0.38
9/16/2014	11:30:00 PM	0.38
9/16/2014	11:45:00 PM	0.38
9/17/2014	12:00:00 AM	0.38
9/17/2014	12:15:00 AM	0.38
9/17/2014	12:30:00 AM	0.38
9/17/2014	12:45:00 AM	0.38
9/17/2014	1:00:00 AM	0.38
9/17/2014	1:15:00 AM	0.38
9/17/2014	1:30:00 AM	0.38
9/17/2014	1:45:00 AM	0.38
9/17/2014	2:00:00 AM	0.38
9/17/2014	2:15:00 AM	0.38
9/17/2014	2:30:00 AM	0.38
9/17/2014	2:45:00 AM	0.38
9/17/2014	3:00:00 AM	0.38
9/17/2014	3:15:00 AM	0.38
9/17/2014	3:30:00 AM	0.39
9/17/2014	3:45:00 AM	0.39
9/17/2014	4:00:00 AM	0.39
9/17/2014	4:15:00 AM	0.39
9/17/2014	4:30:00 AM	0.39
9/17/2014	4:45:00 AM	0.39
9/17/2014	5:00:00 AM	0.39
9/17/2014	5:15:00 AM	0.38
9/17/2014	5:30:00 AM	0.38
9/17/2014	5:45:00 AM	0.38
9/17/2014	6:00:00 AM	0.39
9/17/2014	6:15:00 AM	0.39
9/17/2014	6:30:00 AM	0.39
9/17/2014	6:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/17/2014	7:00:00 AM	0.4
9/17/2014	7:15:00 AM	0.4
9/17/2014	7:30:00 AM	0.4
9/17/2014	7:45:00 AM	0.4
9/17/2014	8:00:00 AM	0.4
9/17/2014	8:15:00 AM	0.4
9/17/2014	8:30:00 AM	0.4
9/17/2014	8:45:00 AM	0.4
9/17/2014	9:00:00 AM	0.4
9/17/2014	9:15:00 AM	0.4
9/17/2014	9:30:00 AM	0.4
9/17/2014	9:45:00 AM	0.4
9/17/2014	10:00:00 AM	0.4
9/17/2014	10:15:00 AM	0.4
9/17/2014	10:30:00 AM	0.4
9/17/2014	10:45:00 AM	0.4
9/17/2014	11:00:00 AM	0.4
9/17/2014	11:15:00 AM	0.39
9/17/2014	11:30:00 AM	0.39
9/17/2014	11:45:00 AM	0.39
9/17/2014	12:00:00 PM	0.38
9/17/2014	12:15:00 PM	0.38
9/17/2014	12:30:00 PM	0.38
9/17/2014	12:45:00 PM	0.38
9/17/2014	1:00:00 PM	0.38
9/17/2014	1:15:00 PM	0.38
9/17/2014	1:30:00 PM	0.38
9/17/2014	1:45:00 PM	0.38
9/17/2014	2:00:00 PM	0.38
9/17/2014	2:15:00 PM	0.38
9/17/2014	2:30:00 PM	0.38
9/17/2014	2:45:00 PM	0.38
9/17/2014	3:00:00 PM	0.38
9/17/2014	3:15:00 PM	0.38
9/17/2014	3:30:00 PM	0.38
9/17/2014	3:45:00 PM	0.38
9/17/2014	4:00:00 PM	0.38
9/17/2014	4:15:00 PM	0.38
9/17/2014	4:30:00 PM	0.37
9/17/2014	4:45:00 PM	0.37
9/17/2014	5:00:00 PM	0.37
9/17/2014	5:15:00 PM	0.37
9/17/2014	5:30:00 PM	0.37
9/17/2014	5:45:00 PM	0.38
9/17/2014	6:00:00 PM	0.38
9/17/2014	6:15:00 PM	0.37

Goose Lake Return Gage

DATE	TIME	GAGE
9/17/2014	6:30:00 PM	0.37
9/17/2014	6:45:00 PM	0.37
9/17/2014	7:00:00 PM	0.37
9/17/2014	7:15:00 PM	0.37
9/17/2014	7:30:00 PM	0.37
9/17/2014	7:45:00 PM	0.37
9/17/2014	8:00:00 PM	0.37
9/17/2014	8:15:00 PM	0.38
9/17/2014	8:30:00 PM	0.38
9/17/2014	8:45:00 PM	0.38
9/17/2014	9:00:00 PM	0.38
9/17/2014	9:15:00 PM	0.38
9/17/2014	9:30:00 PM	0.38
9/17/2014	9:45:00 PM	0.38
9/17/2014	10:00:00 PM	0.38
9/17/2014	10:15:00 PM	0.38
9/17/2014	10:30:00 PM	0.38
9/17/2014	10:45:00 PM	0.38
9/17/2014	11:00:00 PM	0.38
9/17/2014	11:15:00 PM	0.38
9/17/2014	11:30:00 PM	0.38
9/17/2014	11:45:00 PM	0.38
9/18/2014	12:00:00 AM	0.38
9/18/2014	12:15:00 AM	0.38
9/18/2014	12:30:00 AM	0.38
9/18/2014	12:45:00 AM	0.38
9/18/2014	1:00:00 AM	0.38
9/18/2014	1:15:00 AM	0.38
9/18/2014	1:30:00 AM	0.38
9/18/2014	1:45:00 AM	0.38
9/18/2014	2:00:00 AM	0.38
9/18/2014	2:15:00 AM	0.38
9/18/2014	2:30:00 AM	0.38
9/18/2014	2:45:00 AM	0.38
9/18/2014	3:00:00 AM	0.38
9/18/2014	3:15:00 AM	0.38
9/18/2014	3:30:00 AM	0.39
9/18/2014	3:45:00 AM	0.39
9/18/2014	4:00:00 AM	0.39
9/18/2014	4:15:00 AM	0.39
9/18/2014	4:30:00 AM	0.39
9/18/2014	4:45:00 AM	0.39
9/18/2014	5:00:00 AM	0.39
9/18/2014	5:15:00 AM	0.39
9/18/2014	5:30:00 AM	0.39
9/18/2014	5:45:00 AM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
9/18/2014	6:00:00 AM	0.39
9/18/2014	6:15:00 AM	0.4
9/18/2014	6:30:00 AM	0.4
9/18/2014	6:45:00 AM	0.4
9/18/2014	7:00:00 AM	0.4
9/18/2014	7:15:00 AM	0.4
9/18/2014	7:30:00 AM	0.4
9/18/2014	7:45:00 AM	0.4
9/18/2014	8:00:00 AM	0.4
9/18/2014	8:15:00 AM	0.4
9/18/2014	8:30:00 AM	0.4
9/18/2014	8:45:00 AM	0.4
9/18/2014	9:00:00 AM	0.4
9/18/2014	9:15:00 AM	0.4
9/18/2014	9:30:00 AM	0.4
9/18/2014	9:45:00 AM	0.4
9/18/2014	10:00:00 AM	0.4
9/18/2014	10:15:00 AM	0.4
9/18/2014	10:30:00 AM	0.4
9/18/2014	10:45:00 AM	0.4
9/18/2014	11:00:00 AM	0.4
9/18/2014	11:15:00 AM	0.4
9/18/2014	11:30:00 AM	0.4
9/18/2014	11:45:00 AM	0.4
9/18/2014	12:00:00 PM	0.39
9/18/2014	12:15:00 PM	0.39
9/18/2014	12:30:00 PM	0.39
9/18/2014	12:45:00 PM	0.39
9/18/2014	1:00:00 PM	0.39
9/18/2014	1:15:00 PM	0.39
9/18/2014	1:30:00 PM	0.39
9/18/2014	1:45:00 PM	0.39
9/18/2014	2:00:00 PM	0.38
9/18/2014	2:15:00 PM	0.38
9/18/2014	2:30:00 PM	0.38
9/18/2014	2:45:00 PM	0.38
9/18/2014	3:00:00 PM	0.38
9/18/2014	3:15:00 PM	0.38
9/18/2014	3:30:00 PM	0.38
9/18/2014	3:45:00 PM	0.38
9/18/2014	4:00:00 PM	0.38
9/18/2014	4:15:00 PM	0.38
9/18/2014	4:30:00 PM	0.38
9/18/2014	4:45:00 PM	0.38
9/18/2014	5:00:00 PM	0.38
9/18/2014	5:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
9/18/2014	5:30:00 PM	0.38
9/18/2014	5:45:00 PM	0.38
9/18/2014	6:00:00 PM	0.38
9/18/2014	6:15:00 PM	0.38
9/18/2014	6:30:00 PM	0.38
9/18/2014	6:45:00 PM	0.38
9/18/2014	7:00:00 PM	0.38
9/18/2014	7:15:00 PM	0.38
9/18/2014	7:30:00 PM	0.38
9/18/2014	7:45:00 PM	0.38
9/18/2014	8:00:00 PM	0.38
9/18/2014	8:15:00 PM	0.38
9/18/2014	8:30:00 PM	0.38
9/18/2014	8:45:00 PM	0.38
9/18/2014	9:00:00 PM	0.38
9/18/2014	9:15:00 PM	0.38
9/18/2014	9:30:00 PM	0.38
9/18/2014	9:45:00 PM	0.38
9/18/2014	10:00:00 PM	0.38
9/18/2014	10:15:00 PM	0.38
9/18/2014	10:30:00 PM	0.38
9/18/2014	10:45:00 PM	0.38
9/18/2014	11:00:00 PM	0.38
9/18/2014	11:15:00 PM	0.38
9/18/2014	11:30:00 PM	0.38
9/18/2014	11:45:00 PM	0.38
9/19/2014	12:00:00 AM	0.38
9/19/2014	12:15:00 AM	0.38
9/19/2014	12:30:00 AM	0.39
9/19/2014	12:45:00 AM	0.39
9/19/2014	1:00:00 AM	0.39
9/19/2014	1:15:00 AM	0.39
9/19/2014	1:30:00 AM	0.4
9/19/2014	1:45:00 AM	0.4
9/19/2014	2:00:00 AM	0.4
9/19/2014	2:15:00 AM	0.4
9/19/2014	2:30:00 AM	0.4
9/19/2014	2:45:00 AM	0.4
9/19/2014	3:00:00 AM	0.4
9/19/2014	3:15:00 AM	0.4
9/19/2014	3:30:00 AM	0.4
9/19/2014	3:45:00 AM	0.4
9/19/2014	4:00:00 AM	0.4
9/19/2014	4:15:00 AM	0.4
9/19/2014	4:30:00 AM	0.4
9/19/2014	4:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/19/2014	5:00:00 AM	0.4
9/19/2014	5:15:00 AM	0.4
9/19/2014	5:30:00 AM	0.4
9/19/2014	5:45:00 AM	0.4
9/19/2014	6:00:00 AM	0.4
9/19/2014	6:15:00 AM	0.4
9/19/2014	6:30:00 AM	0.4
9/19/2014	6:45:00 AM	0.4
9/19/2014	7:00:00 AM	0.4
9/19/2014	7:15:00 AM	0.4
9/19/2014	7:30:00 AM	0.4
9/19/2014	7:45:00 AM	0.4
9/19/2014	8:00:00 AM	0.4
9/19/2014	8:15:00 AM	0.4
9/19/2014	8:30:00 AM	0.4
9/19/2014	8:45:00 AM	0.4
9/19/2014	9:00:00 AM	0.4
9/19/2014	9:15:00 AM	0.4
9/19/2014	9:30:00 AM	0.4
9/19/2014	9:45:00 AM	0.4
9/19/2014	10:00:00 AM	0.4
9/19/2014	10:15:00 AM	0.4
9/19/2014	10:30:00 AM	0.4
9/19/2014	10:45:00 AM	0.4
9/19/2014	11:00:00 AM	0.4
9/19/2014	11:15:00 AM	0.4
9/19/2014	11:30:00 AM	0.4
9/19/2014	11:45:00 AM	0.4
9/19/2014	12:00:00 PM	0.4
9/19/2014	12:15:00 PM	0.4
9/19/2014	12:30:00 PM	0.4
9/19/2014	12:45:00 PM	0.4
9/19/2014	1:00:00 PM	0.4
9/19/2014	1:15:00 PM	0.4
9/19/2014	1:30:00 PM	0.4
9/19/2014	1:45:00 PM	0.4
9/19/2014	2:00:00 PM	0.4
9/19/2014	2:15:00 PM	0.4
9/19/2014	2:30:00 PM	0.4
9/19/2014	2:45:00 PM	0.4
9/19/2014	3:00:00 PM	0.4
9/19/2014	3:15:00 PM	0.4
9/19/2014	3:30:00 PM	0.4
9/19/2014	3:45:00 PM	0.4
9/19/2014	4:00:00 PM	0.4
9/19/2014	4:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/19/2014	4:30:00 PM	0.4
9/19/2014	4:45:00 PM	0.4
9/19/2014	5:00:00 PM	0.4
9/19/2014	5:15:00 PM	0.4
9/19/2014	5:30:00 PM	0.4
9/19/2014	5:45:00 PM	0.4
9/19/2014	6:00:00 PM	0.4
9/19/2014	6:15:00 PM	0.4
9/19/2014	6:30:00 PM	0.4
9/19/2014	6:45:00 PM	0.4
9/19/2014	7:00:00 PM	0.4
9/19/2014	7:15:00 PM	0.4
9/19/2014	7:30:00 PM	0.4
9/19/2014	7:45:00 PM	0.4
9/19/2014	8:00:00 PM	0.4
9/19/2014	8:15:00 PM	0.4
9/19/2014	8:30:00 PM	0.4
9/19/2014	8:45:00 PM	0.4
9/19/2014	9:00:00 PM	0.4
9/19/2014	9:15:00 PM	0.4
9/19/2014	9:30:00 PM	0.4
9/19/2014	9:45:00 PM	0.4
9/19/2014	10:00:00 PM	0.4
9/19/2014	10:15:00 PM	0.4
9/19/2014	10:30:00 PM	0.4
9/19/2014	10:45:00 PM	0.4
9/19/2014	11:00:00 PM	0.4
9/19/2014	11:15:00 PM	0.4
9/19/2014	11:30:00 PM	0.4
9/19/2014	11:45:00 PM	0.41
9/20/2014	12:00:00 AM	0.41
9/20/2014	12:15:00 AM	0.41
9/20/2014	12:30:00 AM	0.41
9/20/2014	12:45:00 AM	0.41
9/20/2014	1:00:00 AM	0.41
9/20/2014	1:15:00 AM	0.41
9/20/2014	1:30:00 AM	0.41
9/20/2014	1:45:00 AM	0.41
9/20/2014	2:00:00 AM	0.42
9/20/2014	2:15:00 AM	0.42
9/20/2014	2:30:00 AM	0.42
9/20/2014	2:45:00 AM	0.42
9/20/2014	3:00:00 AM	0.42
9/20/2014	3:15:00 AM	0.42
9/20/2014	3:30:00 AM	0.42
9/20/2014	3:45:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/20/2014	4:00:00 AM	0.42
9/20/2014	4:15:00 AM	0.42
9/20/2014	4:30:00 AM	0.42
9/20/2014	4:45:00 AM	0.42
9/20/2014	5:00:00 AM	0.42
9/20/2014	5:15:00 AM	0.42
9/20/2014	5:30:00 AM	0.42
9/20/2014	5:45:00 AM	0.42
9/20/2014	6:00:00 AM	0.42
9/20/2014	6:15:00 AM	0.42
9/20/2014	6:30:00 AM	0.42
9/20/2014	6:45:00 AM	0.43
9/20/2014	7:00:00 AM	0.43
9/20/2014	7:15:00 AM	0.43
9/20/2014	7:30:00 AM	0.43
9/20/2014	7:45:00 AM	0.43
9/20/2014	8:00:00 AM	0.43
9/20/2014	8:15:00 AM	0.43
9/20/2014	8:30:00 AM	0.43
9/20/2014	8:45:00 AM	0.43
9/20/2014	9:00:00 AM	0.43
9/20/2014	9:15:00 AM	0.43
9/20/2014	9:30:00 AM	0.44
9/20/2014	9:45:00 AM	0.44
9/20/2014	10:00:00 AM	0.44
9/20/2014	10:15:00 AM	0.44
9/20/2014	10:30:00 AM	0.44
9/20/2014	10:45:00 AM	0.44
9/20/2014	11:00:00 AM	0.44
9/20/2014	11:15:00 AM	0.44
9/20/2014	11:30:00 AM	0.44
9/20/2014	11:45:00 AM	0.43
9/20/2014	12:00:00 PM	0.44
9/20/2014	12:15:00 PM	0.43
9/20/2014	12:30:00 PM	0.43
9/20/2014	12:45:00 PM	0.43
9/20/2014	1:00:00 PM	0.42
9/20/2014	1:15:00 PM	0.42
9/20/2014	1:30:00 PM	0.42
9/20/2014	1:45:00 PM	0.42
9/20/2014	2:00:00 PM	0.42
9/20/2014	2:15:00 PM	0.42
9/20/2014	2:30:00 PM	0.42
9/20/2014	2:45:00 PM	0.42
9/20/2014	3:00:00 PM	0.43
9/20/2014	3:15:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/20/2014	3:30:00 PM	0.42
9/20/2014	3:45:00 PM	0.42
9/20/2014	4:00:00 PM	0.42
9/20/2014	4:15:00 PM	0.42
9/20/2014	4:30:00 PM	0.43
9/20/2014	4:45:00 PM	0.43
9/20/2014	5:00:00 PM	0.42
9/20/2014	5:15:00 PM	0.42
9/20/2014	5:30:00 PM	0.42
9/20/2014	5:45:00 PM	0.42
9/20/2014	6:00:00 PM	0.42
9/20/2014	6:15:00 PM	0.42
9/20/2014	6:30:00 PM	0.42
9/20/2014	6:45:00 PM	0.42
9/20/2014	7:00:00 PM	0.42
9/20/2014	7:15:00 PM	0.43
9/20/2014	7:30:00 PM	0.43
9/20/2014	7:45:00 PM	0.43
9/20/2014	8:00:00 PM	0.43
9/20/2014	8:15:00 PM	0.43
9/20/2014	8:30:00 PM	0.43
9/20/2014	8:45:00 PM	0.43
9/20/2014	9:00:00 PM	0.43
9/20/2014	9:15:00 PM	0.43
9/20/2014	9:30:00 PM	0.43
9/20/2014	9:45:00 PM	0.43
9/20/2014	10:00:00 PM	0.44
9/20/2014	10:15:00 PM	0.44
9/20/2014	10:30:00 PM	0.44
9/20/2014	10:45:00 PM	0.44
9/20/2014	11:00:00 PM	0.44
9/20/2014	11:15:00 PM	0.43
9/20/2014	11:30:00 PM	0.43
9/20/2014	11:45:00 PM	0.44
9/21/2014	12:00:00 AM	0.44
9/21/2014	12:15:00 AM	0.44
9/21/2014	12:30:00 AM	0.44
9/21/2014	12:45:00 AM	0.44
9/21/2014	1:00:00 AM	0.44
9/21/2014	1:15:00 AM	0.44
9/21/2014	1:30:00 AM	0.44
9/21/2014	1:45:00 AM	0.44
9/21/2014	2:00:00 AM	0.44
9/21/2014	2:15:00 AM	0.44
9/21/2014	2:30:00 AM	0.44
9/21/2014	2:45:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/21/2014	3:00:00 AM	0.44
9/21/2014	3:15:00 AM	0.44
9/21/2014	3:30:00 AM	0.44
9/21/2014	3:45:00 AM	0.44
9/21/2014	4:00:00 AM	0.44
9/21/2014	4:15:00 AM	0.44
9/21/2014	4:30:00 AM	0.44
9/21/2014	4:45:00 AM	0.44
9/21/2014	5:00:00 AM	0.44
9/21/2014	5:15:00 AM	0.44
9/21/2014	5:30:00 AM	0.44
9/21/2014	5:45:00 AM	0.44
9/21/2014	6:00:00 AM	0.44
9/21/2014	6:15:00 AM	0.44
9/21/2014	6:30:00 AM	0.45
9/21/2014	6:45:00 AM	0.45
9/21/2014	7:00:00 AM	0.45
9/21/2014	7:15:00 AM	0.45
9/21/2014	7:30:00 AM	0.45
9/21/2014	7:45:00 AM	0.45
9/21/2014	8:00:00 AM	0.45
9/21/2014	8:15:00 AM	0.45
9/21/2014	8:30:00 AM	0.45
9/21/2014	8:45:00 AM	0.45
9/21/2014	9:00:00 AM	0.45
9/21/2014	9:15:00 AM	0.45
9/21/2014	9:30:00 AM	0.45
9/21/2014	9:45:00 AM	0.45
9/21/2014	10:00:00 AM	0.45
9/21/2014	10:15:00 AM	0.45
9/21/2014	10:30:00 AM	0.45
9/21/2014	10:45:00 AM	0.45
9/21/2014	11:00:00 AM	0.45
9/21/2014	11:15:00 AM	0.45
9/21/2014	11:30:00 AM	0.45
9/21/2014	11:45:00 AM	0.45
9/21/2014	12:00:00 PM	0.45
9/21/2014	12:15:00 PM	0.45
9/21/2014	12:30:00 PM	0.45
9/21/2014	12:45:00 PM	0.45
9/21/2014	1:00:00 PM	0.45
9/21/2014	1:15:00 PM	0.45
9/21/2014	1:30:00 PM	0.45
9/21/2014	1:45:00 PM	0.45
9/21/2014	2:00:00 PM	0.44
9/21/2014	2:15:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/21/2014	2:30:00 PM	0.44
9/21/2014	2:45:00 PM	0.44
9/21/2014	3:00:00 PM	0.44
9/21/2014	3:15:00 PM	0.44
9/21/2014	3:30:00 PM	0.44
9/21/2014	3:45:00 PM	0.44
9/21/2014	4:00:00 PM	0.44
9/21/2014	4:15:00 PM	0.44
9/21/2014	4:30:00 PM	0.44
9/21/2014	4:45:00 PM	0.44
9/21/2014	5:00:00 PM	0.44
9/21/2014	5:15:00 PM	0.44
9/21/2014	5:30:00 PM	0.44
9/21/2014	5:45:00 PM	0.44
9/21/2014	6:00:00 PM	0.44
9/21/2014	6:15:00 PM	0.44
9/21/2014	6:30:00 PM	0.44
9/21/2014	6:45:00 PM	0.44
9/21/2014	7:00:00 PM	0.44
9/21/2014	7:15:00 PM	0.44
9/21/2014	7:30:00 PM	0.44
9/21/2014	7:45:00 PM	0.44
9/21/2014	8:00:00 PM	0.44
9/21/2014	8:15:00 PM	0.44
9/21/2014	8:30:00 PM	0.45
9/21/2014	8:45:00 PM	0.45
9/21/2014	9:00:00 PM	0.45
9/21/2014	9:15:00 PM	0.45
9/21/2014	9:30:00 PM	0.45
9/21/2014	9:45:00 PM	0.45
9/21/2014	10:00:00 PM	0.45
9/21/2014	10:15:00 PM	0.45
9/21/2014	10:30:00 PM	0.45
9/21/2014	10:45:00 PM	0.45
9/21/2014	11:00:00 PM	0.45
9/21/2014	11:15:00 PM	0.45
9/21/2014	11:30:00 PM	0.45
9/21/2014	11:45:00 PM	0.45
9/22/2014	12:00:00 AM	0.45
9/22/2014	12:15:00 AM	0.45
9/22/2014	12:30:00 AM	0.45
9/22/2014	12:45:00 AM	0.46
9/22/2014	1:00:00 AM	0.46
9/22/2014	1:15:00 AM	0.46
9/22/2014	1:30:00 AM	0.46
9/22/2014	1:45:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/22/2014	2:00:00 AM	0.46
9/22/2014	2:15:00 AM	0.46
9/22/2014	2:30:00 AM	0.46
9/22/2014	2:45:00 AM	0.46
9/22/2014	3:00:00 AM	0.46
9/22/2014	3:15:00 AM	0.46
9/22/2014	3:30:00 AM	0.46
9/22/2014	3:45:00 AM	0.46
9/22/2014	4:00:00 AM	0.46
9/22/2014	4:15:00 AM	0.46
9/22/2014	4:30:00 AM	0.46
9/22/2014	4:45:00 AM	0.46
9/22/2014	5:00:00 AM	0.46
9/22/2014	5:15:00 AM	0.46
9/22/2014	5:30:00 AM	0.46
9/22/2014	5:45:00 AM	0.46
9/22/2014	6:00:00 AM	0.46
9/22/2014	6:15:00 AM	0.46
9/22/2014	6:30:00 AM	0.46
9/22/2014	6:45:00 AM	0.46
9/22/2014	7:00:00 AM	0.46
9/22/2014	7:15:00 AM	0.46
9/22/2014	7:30:00 AM	0.46
9/22/2014	7:45:00 AM	0.46
9/22/2014	8:00:00 AM	0.46
9/22/2014	8:15:00 AM	0.46
9/22/2014	8:30:00 AM	0.46
9/22/2014	8:45:00 AM	0.46
9/22/2014	9:00:00 AM	0.46
9/22/2014	9:15:00 AM	0.46
9/22/2014	9:30:00 AM	0.46
9/22/2014	9:45:00 AM	0.46
9/22/2014	10:00:00 AM	0.46
9/22/2014	10:15:00 AM	0.46
9/22/2014	10:30:00 AM	0.46
9/22/2014	10:45:00 AM	0.46
9/22/2014	11:00:00 AM	0.46
9/22/2014	11:15:00 AM	0.46
9/22/2014	11:30:00 AM	0.46
9/22/2014	11:45:00 AM	0.46
9/22/2014	12:00:00 PM	0.46
9/22/2014	12:15:00 PM	0.46
9/22/2014	12:30:00 PM	0.46
9/22/2014	12:45:00 PM	0.46
9/22/2014	1:00:00 PM	0.46
9/22/2014	1:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/22/2014	1:30:00 PM	0.46
9/22/2014	1:45:00 PM	0.45
9/22/2014	2:00:00 PM	0.45
9/22/2014	2:15:00 PM	0.46
9/22/2014	2:30:00 PM	0.46
9/22/2014	2:45:00 PM	0.46
9/22/2014	3:00:00 PM	0.45
9/22/2014	3:15:00 PM	0.45
9/22/2014	3:30:00 PM	0.45
9/22/2014	3:45:00 PM	0.45
9/22/2014	4:00:00 PM	0.45
9/22/2014	4:15:00 PM	0.45
9/22/2014	4:30:00 PM	0.44
9/22/2014	4:45:00 PM	0.45
9/22/2014	5:00:00 PM	0.44
9/22/2014	5:15:00 PM	0.44
9/22/2014	5:30:00 PM	0.44
9/22/2014	5:45:00 PM	0.45
9/22/2014	6:00:00 PM	0.45
9/22/2014	6:15:00 PM	0.45
9/22/2014	6:30:00 PM	0.45
9/22/2014	6:45:00 PM	0.45
9/22/2014	7:00:00 PM	0.45
9/22/2014	7:15:00 PM	0.44
9/22/2014	7:30:00 PM	0.45
9/22/2014	7:45:00 PM	0.45
9/22/2014	8:00:00 PM	0.45
9/22/2014	8:15:00 PM	0.45
9/22/2014	8:30:00 PM	0.45
9/22/2014	8:45:00 PM	0.45
9/22/2014	9:00:00 PM	0.45
9/22/2014	9:15:00 PM	0.45
9/22/2014	9:30:00 PM	0.45
9/22/2014	9:45:00 PM	0.45
9/22/2014	10:00:00 PM	0.45
9/22/2014	10:15:00 PM	0.45
9/22/2014	10:30:00 PM	0.45
9/22/2014	10:45:00 PM	0.45
9/22/2014	11:00:00 PM	0.45
9/22/2014	11:15:00 PM	0.46
9/22/2014	11:30:00 PM	0.46
9/22/2014	11:45:00 PM	0.46
9/23/2014	12:00:00 AM	0.46
9/23/2014	12:15:00 AM	0.46
9/23/2014	12:30:00 AM	0.46
9/23/2014	12:45:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/23/2014	1:00:00 AM	0.46
9/23/2014	1:15:00 AM	0.46
9/23/2014	1:30:00 AM	0.46
9/23/2014	1:45:00 AM	0.46
9/23/2014	2:00:00 AM	0.46
9/23/2014	2:15:00 AM	0.46
9/23/2014	2:30:00 AM	0.46
9/23/2014	2:45:00 AM	0.46
9/23/2014	3:00:00 AM	0.46
9/23/2014	3:15:00 AM	0.46
9/23/2014	3:30:00 AM	0.46
9/23/2014	3:45:00 AM	0.46
9/23/2014	4:00:00 AM	0.46
9/23/2014	4:15:00 AM	0.46
9/23/2014	4:30:00 AM	0.46
9/23/2014	4:45:00 AM	0.46
9/23/2014	5:00:00 AM	0.46
9/23/2014	5:15:00 AM	0.46
9/23/2014	5:30:00 AM	0.46
9/23/2014	5:45:00 AM	0.46
9/23/2014	6:00:00 AM	0.46
9/23/2014	6:15:00 AM	0.46
9/23/2014	6:30:00 AM	0.46
9/23/2014	6:45:00 AM	0.46
9/23/2014	7:00:00 AM	0.46
9/23/2014	7:15:00 AM	0.46
9/23/2014	7:30:00 AM	0.46
9/23/2014	7:45:00 AM	0.46
9/23/2014	8:00:00 AM	0.46
9/23/2014	8:15:00 AM	0.46
9/23/2014	8:30:00 AM	0.46
9/23/2014	8:45:00 AM	0.46
9/23/2014	9:00:00 AM	0.46
9/23/2014	9:15:00 AM	0.46
9/23/2014	9:30:00 AM	0.46
9/23/2014	9:45:00 AM	0.46
9/23/2014	10:00:00 AM	0.46
9/23/2014	10:15:00 AM	0.46
9/23/2014	10:30:00 AM	0.46
9/23/2014	10:45:00 AM	0.46
9/23/2014	11:00:00 AM	0.46
9/23/2014	11:15:00 AM	0.46
9/23/2014	11:30:00 AM	0.46
9/23/2014	11:45:00 AM	0.46
9/23/2014	12:00:00 PM	0.46
9/23/2014	12:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/23/2014	12:30:00 PM	0.46
9/23/2014	12:45:00 PM	0.46
9/23/2014	1:00:00 PM	0.46
9/23/2014	1:15:00 PM	0.45
9/23/2014	1:30:00 PM	0.45
9/23/2014	1:45:00 PM	0.45
9/23/2014	2:00:00 PM	0.45
9/23/2014	2:15:00 PM	0.45
9/23/2014	2:30:00 PM	0.44
9/23/2014	2:45:00 PM	0.45
9/23/2014	3:00:00 PM	0.44
9/23/2014	3:15:00 PM	0.44
9/23/2014	3:30:00 PM	0.44
9/23/2014	3:45:00 PM	0.44
9/23/2014	4:00:00 PM	0.44
9/23/2014	4:15:00 PM	0.44
9/23/2014	4:30:00 PM	0.44
9/23/2014	4:45:00 PM	0.44
9/23/2014	5:00:00 PM	0.44
9/23/2014	5:15:00 PM	0.44
9/23/2014	5:30:00 PM	0.44
9/23/2014	5:45:00 PM	0.44
9/23/2014	6:00:00 PM	0.44
9/23/2014	6:15:00 PM	0.44
9/23/2014	6:30:00 PM	0.44
9/23/2014	6:45:00 PM	0.44
9/23/2014	7:00:00 PM	0.44
9/23/2014	7:15:00 PM	0.44
9/23/2014	7:30:00 PM	0.44
9/23/2014	7:45:00 PM	0.44
9/23/2014	8:00:00 PM	0.44
9/23/2014	8:15:00 PM	0.44
9/23/2014	8:30:00 PM	0.44
9/23/2014	8:45:00 PM	0.45
9/23/2014	9:00:00 PM	0.45
9/23/2014	9:15:00 PM	0.45
9/23/2014	9:30:00 PM	0.45
9/23/2014	9:45:00 PM	0.45
9/23/2014	10:00:00 PM	0.45
9/23/2014	10:15:00 PM	0.45
9/23/2014	10:30:00 PM	0.45
9/23/2014	10:45:00 PM	0.45
9/23/2014	11:00:00 PM	0.45
9/23/2014	11:15:00 PM	0.45
9/23/2014	11:30:00 PM	0.45
9/23/2014	11:45:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
9/24/2014	12:00:00 AM	0.45
9/24/2014	12:15:00 AM	0.45
9/24/2014	12:30:00 AM	0.45
9/24/2014	12:45:00 AM	0.45
9/24/2014	1:00:00 AM	0.45
9/24/2014	1:15:00 AM	0.45
9/24/2014	1:30:00 AM	0.45
9/24/2014	1:45:00 AM	0.45
9/24/2014	2:00:00 AM	0.45
9/24/2014	2:15:00 AM	0.45
9/24/2014	2:30:00 AM	0.45
9/24/2014	2:45:00 AM	0.45
9/24/2014	3:00:00 AM	0.45
9/24/2014	3:15:00 AM	0.45
9/24/2014	3:30:00 AM	0.45
9/24/2014	3:45:00 AM	0.45
9/24/2014	4:00:00 AM	0.45
9/24/2014	4:15:00 AM	0.45
9/24/2014	4:30:00 AM	0.45
9/24/2014	4:45:00 AM	0.45
9/24/2014	5:00:00 AM	0.46
9/24/2014	5:15:00 AM	0.46
9/24/2014	5:30:00 AM	0.46
9/24/2014	5:45:00 AM	0.46
9/24/2014	6:00:00 AM	0.46
9/24/2014	6:15:00 AM	0.46
9/24/2014	6:30:00 AM	0.46
9/24/2014	6:45:00 AM	0.46
9/24/2014	7:00:00 AM	0.46
9/24/2014	7:15:00 AM	0.46
9/24/2014	7:30:00 AM	0.46
9/24/2014	7:45:00 AM	0.46
9/24/2014	8:00:00 AM	0.46
9/24/2014	8:15:00 AM	0.46
9/24/2014	8:30:00 AM	0.46
9/24/2014	8:45:00 AM	0.46
9/24/2014	9:00:00 AM	0.46
9/24/2014	9:15:00 AM	0.46
9/24/2014	9:30:00 AM	0.46
9/24/2014	9:45:00 AM	0.46
9/24/2014	10:00:00 AM	0.46
9/24/2014	10:15:00 AM	0.46
9/24/2014	10:30:00 AM	0.46
9/24/2014	10:45:00 AM	0.46
9/24/2014	11:00:00 AM	0.46
9/24/2014	11:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/24/2014	11:30:00 AM	0.46
9/24/2014	11:45:00 AM	0.46
9/24/2014	12:00:00 PM	0.46
9/24/2014	12:15:00 PM	0.46
9/24/2014	12:30:00 PM	0.46
9/24/2014	12:45:00 PM	0.46
9/24/2014	1:00:00 PM	0.45
9/24/2014	1:15:00 PM	0.45
9/24/2014	1:30:00 PM	0.45
9/24/2014	1:45:00 PM	0.45
9/24/2014	2:00:00 PM	0.45
9/24/2014	2:15:00 PM	0.45
9/24/2014	2:30:00 PM	0.44
9/24/2014	2:45:00 PM	0.44
9/24/2014	3:00:00 PM	0.44
9/24/2014	3:15:00 PM	0.44
9/24/2014	3:30:00 PM	0.44
9/24/2014	3:45:00 PM	0.44
9/24/2014	4:00:00 PM	0.44
9/24/2014	4:15:00 PM	0.44
9/24/2014	4:30:00 PM	0.44
9/24/2014	4:45:00 PM	0.44
9/24/2014	5:00:00 PM	0.44
9/24/2014	5:15:00 PM	0.44
9/24/2014	5:30:00 PM	0.44
9/24/2014	5:45:00 PM	0.44
9/24/2014	6:00:00 PM	0.44
9/24/2014	6:15:00 PM	0.44
9/24/2014	6:30:00 PM	0.44
9/24/2014	6:45:00 PM	0.44
9/24/2014	7:00:00 PM	0.44
9/24/2014	7:15:00 PM	0.44
9/24/2014	7:30:00 PM	0.44
9/24/2014	7:45:00 PM	0.44
9/24/2014	8:00:00 PM	0.44
9/24/2014	8:15:00 PM	0.44
9/24/2014	8:30:00 PM	0.44
9/24/2014	8:45:00 PM	0.44
9/24/2014	9:00:00 PM	0.44
9/24/2014	9:15:00 PM	0.44
9/24/2014	9:30:00 PM	0.44
9/24/2014	9:45:00 PM	0.44
9/24/2014	10:00:00 PM	0.44
9/24/2014	10:15:00 PM	0.44
9/24/2014	10:30:00 PM	0.44
9/24/2014	10:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/24/2014	11:00:00 PM	0.44
9/24/2014	11:15:00 PM	0.44
9/24/2014	11:30:00 PM	0.44
9/24/2014	11:45:00 PM	0.44
9/25/2014	12:00:00 AM	0.44
9/25/2014	12:15:00 AM	0.44
9/25/2014	12:30:00 AM	0.44
9/25/2014	12:45:00 AM	0.44
9/25/2014	1:00:00 AM	0.44
9/25/2014	1:15:00 AM	0.44
9/25/2014	1:30:00 AM	0.44
9/25/2014	1:45:00 AM	0.44
9/25/2014	2:00:00 AM	0.44
9/25/2014	2:15:00 AM	0.44
9/25/2014	2:30:00 AM	0.44
9/25/2014	2:45:00 AM	0.44
9/25/2014	3:00:00 AM	0.44
9/25/2014	3:15:00 AM	0.44
9/25/2014	3:30:00 AM	0.44
9/25/2014	3:45:00 AM	0.44
9/25/2014	4:00:00 AM	0.44
9/25/2014	4:15:00 AM	0.44
9/25/2014	4:30:00 AM	0.44
9/25/2014	4:45:00 AM	0.44
9/25/2014	5:00:00 AM	0.44
9/25/2014	5:15:00 AM	0.44
9/25/2014	5:30:00 AM	0.44
9/25/2014	5:45:00 AM	0.44
9/25/2014	6:00:00 AM	0.44
9/25/2014	6:15:00 AM	0.44
9/25/2014	6:30:00 AM	0.44
9/25/2014	6:45:00 AM	0.44
9/25/2014	7:00:00 AM	0.44
9/25/2014	7:15:00 AM	0.44
9/25/2014	7:30:00 AM	0.44
9/25/2014	7:45:00 AM	0.44
9/25/2014	8:00:00 AM	0.44
9/25/2014	8:15:00 AM	0.44
9/25/2014	8:30:00 AM	0.44
9/25/2014	8:45:00 AM	0.44
9/25/2014	9:00:00 AM	0.45
9/25/2014	9:15:00 AM	0.44
9/25/2014	9:30:00 AM	0.45
9/25/2014	9:45:00 AM	0.44
9/25/2014	10:00:00 AM	0.44
9/25/2014	10:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/25/2014	10:30:00 AM	0.44
9/25/2014	10:45:00 AM	0.44
9/25/2014	11:00:00 AM	0.44
9/25/2014	11:15:00 AM	0.44
9/25/2014	11:30:00 AM	0.44
9/25/2014	11:45:00 AM	0.44
9/25/2014	12:00:00 PM	0.44
9/25/2014	12:15:00 PM	0.44
9/25/2014	12:30:00 PM	0.43
9/25/2014	12:45:00 PM	0.42
9/25/2014	1:00:00 PM	0.42
9/25/2014	1:15:00 PM	0.42
9/25/2014	1:30:00 PM	0.42
9/25/2014	1:45:00 PM	0.42
9/25/2014	2:00:00 PM	0.42
9/25/2014	2:15:00 PM	0.42
9/25/2014	2:30:00 PM	0.42
9/25/2014	2:45:00 PM	0.42
9/25/2014	3:00:00 PM	0.42
9/25/2014	3:15:00 PM	0.42
9/25/2014	3:30:00 PM	0.42
9/25/2014	3:45:00 PM	0.42
9/25/2014	4:00:00 PM	0.42
9/25/2014	4:15:00 PM	0.42
9/25/2014	4:30:00 PM	0.42
9/25/2014	4:45:00 PM	0.42
9/25/2014	5:00:00 PM	0.42
9/25/2014	5:15:00 PM	0.42
9/25/2014	5:30:00 PM	0.42
9/25/2014	5:45:00 PM	0.42
9/25/2014	6:00:00 PM	0.42
9/25/2014	6:15:00 PM	0.42
9/25/2014	6:30:00 PM	0.42
9/25/2014	6:45:00 PM	0.42
9/25/2014	7:00:00 PM	0.42
9/25/2014	7:15:00 PM	0.42
9/25/2014	7:30:00 PM	0.42
9/25/2014	7:45:00 PM	0.42
9/25/2014	8:00:00 PM	0.42
9/25/2014	8:15:00 PM	0.42
9/25/2014	8:30:00 PM	0.42
9/25/2014	8:45:00 PM	0.42
9/25/2014	9:00:00 PM	0.42
9/25/2014	9:15:00 PM	0.42
9/25/2014	9:30:00 PM	0.42
9/25/2014	9:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/25/2014	10:00:00 PM	0.42
9/25/2014	10:15:00 PM	0.42
9/25/2014	10:30:00 PM	0.42
9/25/2014	10:45:00 PM	0.42
9/25/2014	11:00:00 PM	0.42
9/25/2014	11:15:00 PM	0.42
9/25/2014	11:30:00 PM	0.42
9/25/2014	11:45:00 PM	0.42
9/26/2014	12:00:00 AM	0.42
9/26/2014	12:15:00 AM	0.42
9/26/2014	12:30:00 AM	0.42
9/26/2014	12:45:00 AM	0.42
9/26/2014	1:00:00 AM	0.42
9/26/2014	1:15:00 AM	0.42
9/26/2014	1:30:00 AM	0.42
9/26/2014	1:45:00 AM	0.42
9/26/2014	2:00:00 AM	0.42
9/26/2014	2:15:00 AM	0.42
9/26/2014	2:30:00 AM	0.42
9/26/2014	2:45:00 AM	0.42
9/26/2014	3:00:00 AM	0.42
9/26/2014	3:15:00 AM	0.42
9/26/2014	3:30:00 AM	0.42
9/26/2014	3:45:00 AM	0.42
9/26/2014	4:00:00 AM	0.42
9/26/2014	4:15:00 AM	0.42
9/26/2014	4:30:00 AM	0.42
9/26/2014	4:45:00 AM	0.42
9/26/2014	5:00:00 AM	0.42
9/26/2014	5:15:00 AM	0.42
9/26/2014	5:30:00 AM	0.42
9/26/2014	5:45:00 AM	0.42
9/26/2014	6:00:00 AM	0.42
9/26/2014	6:15:00 AM	0.42
9/26/2014	6:30:00 AM	0.42
9/26/2014	6:45:00 AM	0.42
9/26/2014	7:00:00 AM	0.42
9/26/2014	7:15:00 AM	0.42
9/26/2014	7:30:00 AM	0.42
9/26/2014	7:45:00 AM	0.42
9/26/2014	8:00:00 AM	0.42
9/26/2014	8:15:00 AM	0.42
9/26/2014	8:30:00 AM	0.42
9/26/2014	8:45:00 AM	0.42
9/26/2014	9:00:00 AM	0.42
9/26/2014	9:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/26/2014	9:30:00 AM	0.42
9/26/2014	9:45:00 AM	0.42
9/26/2014	10:00:00 AM	0.42
9/26/2014	10:15:00 AM	0.42
9/26/2014	10:30:00 AM	0.42
9/26/2014	10:45:00 AM	0.42
9/26/2014	11:00:00 AM	0.42
9/26/2014	11:15:00 AM	0.42
9/26/2014	11:30:00 AM	0.42
9/26/2014	11:45:00 AM	0.42
9/26/2014	12:00:00 PM	0.42
9/26/2014	12:15:00 PM	0.42
9/26/2014	12:30:00 PM	0.42
9/26/2014	12:45:00 PM	0.42
9/26/2014	1:00:00 PM	0.42
9/26/2014	1:15:00 PM	0.41
9/26/2014	1:30:00 PM	0.41
9/26/2014	1:45:00 PM	0.41
9/26/2014	2:00:00 PM	0.4
9/26/2014	2:15:00 PM	0.4
9/26/2014	2:30:00 PM	0.4
9/26/2014	2:45:00 PM	0.4
9/26/2014	3:00:00 PM	0.4
9/26/2014	3:15:00 PM	0.4
9/26/2014	3:30:00 PM	0.4
9/26/2014	3:45:00 PM	0.4
9/26/2014	4:00:00 PM	0.4
9/26/2014	4:15:00 PM	0.4
9/26/2014	4:30:00 PM	0.4
9/26/2014	4:45:00 PM	0.4
9/26/2014	5:00:00 PM	0.4
9/26/2014	5:15:00 PM	0.4
9/26/2014	5:30:00 PM	0.4
9/26/2014	5:45:00 PM	0.4
9/26/2014	6:00:00 PM	0.39
9/26/2014	6:15:00 PM	0.4
9/26/2014	6:30:00 PM	0.4
9/26/2014	6:45:00 PM	0.39
9/26/2014	7:00:00 PM	0.4
9/26/2014	7:15:00 PM	0.4
9/26/2014	7:30:00 PM	0.4
9/26/2014	7:45:00 PM	0.4
9/26/2014	8:00:00 PM	0.4
9/26/2014	8:15:00 PM	0.4
9/26/2014	8:30:00 PM	0.4
9/26/2014	8:45:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
9/26/2014	9:00:00 PM	0.4
9/26/2014	9:15:00 PM	0.4
9/26/2014	9:30:00 PM	0.4
9/26/2014	9:45:00 PM	0.4
9/26/2014	10:00:00 PM	0.4
9/26/2014	10:15:00 PM	0.4
9/26/2014	10:30:00 PM	0.4
9/26/2014	10:45:00 PM	0.4
9/26/2014	11:00:00 PM	0.4
9/26/2014	11:15:00 PM	0.4
9/26/2014	11:30:00 PM	0.4
9/26/2014	11:45:00 PM	0.4
9/27/2014	12:00:00 AM	0.4
9/27/2014	12:15:00 AM	0.4
9/27/2014	12:30:00 AM	0.4
9/27/2014	12:45:00 AM	0.4
9/27/2014	1:00:00 AM	0.4
9/27/2014	1:15:00 AM	0.4
9/27/2014	1:30:00 AM	0.4
9/27/2014	1:45:00 AM	0.4
9/27/2014	2:00:00 AM	0.4
9/27/2014	2:15:00 AM	0.4
9/27/2014	2:30:00 AM	0.4
9/27/2014	2:45:00 AM	0.4
9/27/2014	3:00:00 AM	0.4
9/27/2014	3:15:00 AM	0.4
9/27/2014	3:30:00 AM	0.4
9/27/2014	3:45:00 AM	0.4
9/27/2014	4:00:00 AM	0.4
9/27/2014	4:15:00 AM	0.4
9/27/2014	4:30:00 AM	0.4
9/27/2014	4:45:00 AM	0.4
9/27/2014	5:00:00 AM	0.4
9/27/2014	5:15:00 AM	0.4
9/27/2014	5:30:00 AM	0.4
9/27/2014	5:45:00 AM	0.4
9/27/2014	6:00:00 AM	0.4
9/27/2014	6:15:00 AM	0.4
9/27/2014	6:30:00 AM	0.4
9/27/2014	6:45:00 AM	0.4
9/27/2014	7:00:00 AM	0.4
9/27/2014	7:15:00 AM	0.4
9/27/2014	7:30:00 AM	0.4
9/27/2014	7:45:00 AM	0.4
9/27/2014	8:00:00 AM	0.4
9/27/2014	8:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/27/2014	8:30:00 AM	0.4
9/27/2014	8:45:00 AM	0.4
9/27/2014	9:00:00 AM	0.4
9/27/2014	9:15:00 AM	0.4
9/27/2014	9:30:00 AM	0.4
9/27/2014	9:45:00 AM	0.4
9/27/2014	10:00:00 AM	0.4
9/27/2014	10:15:00 AM	0.4
9/27/2014	10:30:00 AM	0.4
9/27/2014	10:45:00 AM	0.4
9/27/2014	11:00:00 AM	0.4
9/27/2014	11:15:00 AM	0.4
9/27/2014	11:30:00 AM	0.4
9/27/2014	11:45:00 AM	0.4
9/27/2014	12:00:00 PM	0.4
9/27/2014	12:15:00 PM	0.4
9/27/2014	12:30:00 PM	0.4
9/27/2014	12:45:00 PM	0.39
9/27/2014	1:00:00 PM	0.39
9/27/2014	1:15:00 PM	0.39
9/27/2014	1:30:00 PM	0.39
9/27/2014	1:45:00 PM	0.39
9/27/2014	2:00:00 PM	0.39
9/27/2014	2:15:00 PM	0.39
9/27/2014	2:30:00 PM	0.39
9/27/2014	2:45:00 PM	0.38
9/27/2014	3:00:00 PM	0.38
9/27/2014	3:15:00 PM	0.38
9/27/2014	3:30:00 PM	0.38
9/27/2014	3:45:00 PM	0.38
9/27/2014	4:00:00 PM	0.38
9/27/2014	4:15:00 PM	0.38
9/27/2014	4:30:00 PM	0.38
9/27/2014	4:45:00 PM	0.38
9/27/2014	5:00:00 PM	0.38
9/27/2014	5:15:00 PM	0.38
9/27/2014	5:30:00 PM	0.38
9/27/2014	5:45:00 PM	0.38
9/27/2014	6:00:00 PM	0.38
9/27/2014	6:15:00 PM	0.38
9/27/2014	6:30:00 PM	0.38
9/27/2014	6:45:00 PM	0.38
9/27/2014	7:00:00 PM	0.38
9/27/2014	7:15:00 PM	0.38
9/27/2014	7:30:00 PM	0.38
9/27/2014	7:45:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
9/27/2014	8:00:00 PM	0.38
9/27/2014	8:15:00 PM	0.38
9/27/2014	8:30:00 PM	0.38
9/27/2014	8:45:00 PM	0.38
9/27/2014	9:00:00 PM	0.38
9/27/2014	9:15:00 PM	0.38
9/27/2014	9:30:00 PM	0.38
9/27/2014	9:45:00 PM	0.38
9/27/2014	10:00:00 PM	0.38
9/27/2014	10:15:00 PM	0.38
9/27/2014	10:30:00 PM	0.38
9/27/2014	10:45:00 PM	0.38
9/27/2014	11:00:00 PM	0.38
9/27/2014	11:15:00 PM	0.38
9/27/2014	11:30:00 PM	0.38
9/27/2014	11:45:00 PM	0.38
9/28/2014	12:00:00 AM	0.38
9/28/2014	12:15:00 AM	0.38
9/28/2014	12:30:00 AM	0.38
9/28/2014	12:45:00 AM	0.38
9/28/2014	1:00:00 AM	0.38
9/28/2014	1:15:00 AM	0.39
9/28/2014	1:30:00 AM	0.39
9/28/2014	1:45:00 AM	0.39
9/28/2014	2:00:00 AM	0.39
9/28/2014	2:15:00 AM	0.39
9/28/2014	2:30:00 AM	0.39
9/28/2014	2:45:00 AM	0.39
9/28/2014	3:00:00 AM	0.39
9/28/2014	3:15:00 AM	0.39
9/28/2014	3:30:00 AM	0.39
9/28/2014	3:45:00 AM	0.39
9/28/2014	4:00:00 AM	0.39
9/28/2014	4:15:00 AM	0.39
9/28/2014	4:30:00 AM	0.39
9/28/2014	4:45:00 AM	0.39
9/28/2014	5:00:00 AM	0.39
9/28/2014	5:15:00 AM	0.39
9/28/2014	5:30:00 AM	0.39
9/28/2014	5:45:00 AM	0.39
9/28/2014	6:00:00 AM	0.39
9/28/2014	6:15:00 AM	0.39
9/28/2014	6:30:00 AM	0.39
9/28/2014	6:45:00 AM	0.39
9/28/2014	7:00:00 AM	0.39
9/28/2014	7:15:00 AM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
9/28/2014	7:30:00 AM	0.39
9/28/2014	7:45:00 AM	0.39
9/28/2014	8:00:00 AM	0.39
9/28/2014	8:15:00 AM	0.39
9/28/2014	8:30:00 AM	0.39
9/28/2014	8:45:00 AM	0.39
9/28/2014	9:00:00 AM	0.39
9/28/2014	9:15:00 AM	0.39
9/28/2014	9:30:00 AM	0.39
9/28/2014	9:45:00 AM	0.39
9/28/2014	10:00:00 AM	0.39
9/28/2014	10:15:00 AM	0.39
9/28/2014	10:30:00 AM	0.39
9/28/2014	10:45:00 AM	0.39
9/28/2014	11:00:00 AM	0.39
9/28/2014	11:15:00 AM	0.39
9/28/2014	11:30:00 AM	0.39
9/28/2014	11:45:00 AM	0.39
9/28/2014	12:00:00 PM	0.39
9/28/2014	12:15:00 PM	0.39
9/28/2014	12:30:00 PM	0.39
9/28/2014	12:45:00 PM	0.39
9/28/2014	1:00:00 PM	0.39
9/28/2014	1:15:00 PM	0.39
9/28/2014	1:30:00 PM	0.39
9/28/2014	1:45:00 PM	0.4
9/28/2014	2:00:00 PM	0.4
9/28/2014	2:15:00 PM	0.39
9/28/2014	2:30:00 PM	0.39
9/28/2014	2:45:00 PM	0.39
9/28/2014	3:00:00 PM	0.39
9/28/2014	3:15:00 PM	0.39
9/28/2014	3:30:00 PM	0.39
9/28/2014	3:45:00 PM	0.39
9/28/2014	4:00:00 PM	0.39
9/28/2014	4:15:00 PM	0.4
9/28/2014	4:30:00 PM	0.4
9/28/2014	4:45:00 PM	0.4
9/28/2014	5:00:00 PM	0.4
9/28/2014	5:15:00 PM	0.4
9/28/2014	5:30:00 PM	0.4
9/28/2014	5:45:00 PM	0.4
9/28/2014	6:00:00 PM	0.4
9/28/2014	6:15:00 PM	0.4
9/28/2014	6:30:00 PM	0.4
9/28/2014	6:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
9/28/2014	7:00:00 PM	0.4
9/28/2014	7:15:00 PM	0.4
9/28/2014	7:30:00 PM	0.4
9/28/2014	7:45:00 PM	0.4
9/28/2014	8:00:00 PM	0.4
9/28/2014	8:15:00 PM	0.4
9/28/2014	8:30:00 PM	0.4
9/28/2014	8:45:00 PM	0.4
9/28/2014	9:00:00 PM	0.4
9/28/2014	9:15:00 PM	0.4
9/28/2014	9:30:00 PM	0.4
9/28/2014	9:45:00 PM	0.4
9/28/2014	10:00:00 PM	0.4
9/28/2014	10:15:00 PM	0.4
9/28/2014	10:30:00 PM	0.4
9/28/2014	10:45:00 PM	0.4
9/28/2014	11:00:00 PM	0.4
9/28/2014	11:15:00 PM	0.4
9/28/2014	11:30:00 PM	0.4
9/28/2014	11:45:00 PM	0.4
9/29/2014	12:00:00 AM	0.41
9/29/2014	12:15:00 AM	0.41
9/29/2014	12:30:00 AM	0.41
9/29/2014	12:45:00 AM	0.41
9/29/2014	1:00:00 AM	0.41
9/29/2014	1:15:00 AM	0.41
9/29/2014	1:30:00 AM	0.42
9/29/2014	1:45:00 AM	0.42
9/29/2014	2:00:00 AM	0.42
9/29/2014	2:15:00 AM	0.42
9/29/2014	2:30:00 AM	0.42
9/29/2014	2:45:00 AM	0.42
9/29/2014	3:00:00 AM	0.42
9/29/2014	3:15:00 AM	0.42
9/29/2014	3:30:00 AM	0.42
9/29/2014	3:45:00 AM	0.42
9/29/2014	4:00:00 AM	0.42
9/29/2014	4:15:00 AM	0.42
9/29/2014	4:30:00 AM	0.42
9/29/2014	4:45:00 AM	0.42
9/29/2014	5:00:00 AM	0.42
9/29/2014	5:15:00 AM	0.42
9/29/2014	5:30:00 AM	0.42
9/29/2014	5:45:00 AM	0.42
9/29/2014	6:00:00 AM	0.42
9/29/2014	6:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
9/29/2014	6:30:00 AM	0.42
9/29/2014	6:45:00 AM	0.42
9/29/2014	7:00:00 AM	0.42
9/29/2014	7:15:00 AM	0.42
9/29/2014	7:30:00 AM	0.42
9/29/2014	7:45:00 AM	0.42
9/29/2014	8:00:00 AM	0.42
9/29/2014	8:15:00 AM	0.43
9/29/2014	8:30:00 AM	0.43
9/29/2014	8:45:00 AM	0.43
9/29/2014	9:00:00 AM	0.43
9/29/2014	9:15:00 AM	0.44
9/29/2014	9:30:00 AM	0.44
9/29/2014	9:45:00 AM	0.44
9/29/2014	10:00:00 AM	0.44
9/29/2014	10:15:00 AM	0.44
9/29/2014	10:30:00 AM	0.44
9/29/2014	10:45:00 AM	0.43
9/29/2014	11:00:00 AM	0.44
9/29/2014	11:15:00 AM	0.44
9/29/2014	11:30:00 AM	0.44
9/29/2014	11:45:00 AM	0.44
9/29/2014	12:00:00 PM	0.44
9/29/2014	12:15:00 PM	0.44
9/29/2014	12:30:00 PM	0.44
9/29/2014	12:45:00 PM	0.44
9/29/2014	1:00:00 PM	0.44
9/29/2014	1:15:00 PM	0.44
9/29/2014	1:30:00 PM	0.44
9/29/2014	1:45:00 PM	0.44
9/29/2014	2:00:00 PM	0.44
9/29/2014	2:15:00 PM	0.44
9/29/2014	2:30:00 PM	0.44
9/29/2014	2:45:00 PM	0.44
9/29/2014	3:00:00 PM	0.44
9/29/2014	3:15:00 PM	0.44
9/29/2014	3:30:00 PM	0.44
9/29/2014	3:45:00 PM	0.44
9/29/2014	4:00:00 PM	0.44
9/29/2014	4:15:00 PM	0.44
9/29/2014	4:30:00 PM	0.44
9/29/2014	4:45:00 PM	0.44
9/29/2014	5:00:00 PM	0.44
9/29/2014	5:15:00 PM	0.44
9/29/2014	5:30:00 PM	0.44
9/29/2014	5:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
9/29/2014	6:00:00 PM	0.44
9/29/2014	6:15:00 PM	0.44
9/29/2014	6:30:00 PM	0.44
9/29/2014	6:45:00 PM	0.44
9/29/2014	7:00:00 PM	0.44
9/29/2014	7:15:00 PM	0.44
9/29/2014	7:30:00 PM	0.44
9/29/2014	7:45:00 PM	0.44
9/29/2014	8:00:00 PM	0.44
9/29/2014	8:15:00 PM	0.44
9/29/2014	8:30:00 PM	0.44
9/29/2014	8:45:00 PM	0.44
9/29/2014	9:00:00 PM	0.44
9/29/2014	9:15:00 PM	0.44
9/29/2014	9:30:00 PM	0.44
9/29/2014	9:45:00 PM	0.44
9/29/2014	10:00:00 PM	0.44
9/29/2014	10:15:00 PM	0.44
9/29/2014	10:30:00 PM	0.44
9/29/2014	10:45:00 PM	0.44
9/29/2014	11:00:00 PM	0.44
9/29/2014	11:15:00 PM	0.44
9/29/2014	11:30:00 PM	0.45
9/29/2014	11:45:00 PM	0.45
9/30/2014	12:00:00 AM	0.45
9/30/2014	12:15:00 AM	0.45
9/30/2014	12:30:00 AM	0.45
9/30/2014	12:45:00 AM	0.45
9/30/2014	1:00:00 AM	0.45
9/30/2014	1:15:00 AM	0.45
9/30/2014	1:30:00 AM	0.45
9/30/2014	1:45:00 AM	0.45
9/30/2014	2:00:00 AM	0.45
9/30/2014	2:15:00 AM	0.45
9/30/2014	2:30:00 AM	0.45
9/30/2014	2:45:00 AM	0.45
9/30/2014	3:00:00 AM	0.45
9/30/2014	3:15:00 AM	0.45
9/30/2014	3:30:00 AM	0.45
9/30/2014	3:45:00 AM	0.46
9/30/2014	4:00:00 AM	0.46
9/30/2014	4:15:00 AM	0.46
9/30/2014	4:30:00 AM	0.46
9/30/2014	4:45:00 AM	0.46
9/30/2014	5:00:00 AM	0.46
9/30/2014	5:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/30/2014	5:30:00 AM	0.46
9/30/2014	5:45:00 AM	0.46
9/30/2014	6:00:00 AM	0.46
9/30/2014	6:15:00 AM	0.46
9/30/2014	6:30:00 AM	0.46
9/30/2014	6:45:00 AM	0.46
9/30/2014	7:00:00 AM	0.46
9/30/2014	7:15:00 AM	0.46
9/30/2014	7:30:00 AM	0.46
9/30/2014	7:45:00 AM	0.46
9/30/2014	8:00:00 AM	0.46
9/30/2014	8:15:00 AM	0.46
9/30/2014	8:30:00 AM	0.46
9/30/2014	8:45:00 AM	0.46
9/30/2014	9:00:00 AM	0.46
9/30/2014	9:15:00 AM	0.46
9/30/2014	9:30:00 AM	0.46
9/30/2014	9:45:00 AM	0.47
9/30/2014	10:00:00 AM	0.47
9/30/2014	10:15:00 AM	0.47
9/30/2014	10:30:00 AM	0.47
9/30/2014	10:45:00 AM	0.47
9/30/2014	11:00:00 AM	0.47
9/30/2014	11:15:00 AM	0.47
9/30/2014	11:30:00 AM	0.47
9/30/2014	11:45:00 AM	0.47
9/30/2014	12:00:00 PM	0.47
9/30/2014	12:15:00 PM	0.47
9/30/2014	12:30:00 PM	0.47
9/30/2014	12:45:00 PM	0.47
9/30/2014	1:00:00 PM	0.46
9/30/2014	1:15:00 PM	0.46
9/30/2014	1:30:00 PM	0.46
9/30/2014	1:45:00 PM	0.46
9/30/2014	2:00:00 PM	0.46
9/30/2014	2:15:00 PM	0.46
9/30/2014	2:30:00 PM	0.46
9/30/2014	2:45:00 PM	0.46
9/30/2014	3:00:00 PM	0.46
9/30/2014	3:15:00 PM	0.46
9/30/2014	3:30:00 PM	0.46
9/30/2014	3:45:00 PM	0.46
9/30/2014	4:00:00 PM	0.46
9/30/2014	4:15:00 PM	0.46
9/30/2014	4:30:00 PM	0.46
9/30/2014	4:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
9/30/2014	5:00:00 PM	0.46
9/30/2014	5:15:00 PM	0.46
9/30/2014	5:30:00 PM	0.46
9/30/2014	5:45:00 PM	0.46
9/30/2014	6:00:00 PM	0.46
9/30/2014	6:15:00 PM	0.46
9/30/2014	6:30:00 PM	0.46
9/30/2014	6:45:00 PM	0.46
9/30/2014	7:00:00 PM	0.46
9/30/2014	7:15:00 PM	0.46
9/30/2014	7:30:00 PM	0.46
9/30/2014	7:45:00 PM	0.46
9/30/2014	8:00:00 PM	0.46
9/30/2014	8:15:00 PM	0.46
9/30/2014	8:30:00 PM	0.47
9/30/2014	8:45:00 PM	0.47
9/30/2014	9:00:00 PM	0.47
9/30/2014	9:15:00 PM	0.47
9/30/2014	9:30:00 PM	0.47
9/30/2014	9:45:00 PM	0.47
9/30/2014	10:00:00 PM	0.47
9/30/2014	10:15:00 PM	0.47
9/30/2014	10:30:00 PM	0.47
9/30/2014	10:45:00 PM	0.47
9/30/2014	11:00:00 PM	0.47
9/30/2014	11:15:00 PM	0.47
9/30/2014	11:30:00 PM	0.48
9/30/2014	11:45:00 PM	0.48
10/1/2014	12:00:00 AM	0.48

Billy Lake Return
Station 0213

Date	Flow (cfs)
9/1/2014	1.357
9/2/2014	1.368
9/3/2014	1.368
9/4/2014	1.368
9/5/2014	1.368
9/6/2014	1.368
9/7/2014	1.35
9/8/2014	1.349
9/9/2014	1.308
9/10/2014	1.144
9/11/2014	0.992
9/12/2014	0.992
9/13/2014	1.059
9/14/2014	1.112
9/15/2014	1.112
9/16/2014	1.12
9/17/2014	1.132
9/18/2014	1.112
9/19/2014	1.112
9/20/2014	1.13
9/21/2014	1.153
9/22/2014	1.233
9/23/2014	1.238
9/24/2014	1.255
9/25/2014	1.256
9/26/2014	1.256
9/27/2014	1.291
9/28/2014	1.302
9/29/2014	1.302
9/30/2014	1.302

Billy Lake Return Gage

DATE	TIME	GAGE
9/1/2014	12:00:00 AM	0.31
9/1/2014	12:15:00 AM	0.31
9/1/2014	12:30:00 AM	0.31
9/1/2014	12:45:00 AM	0.31
9/1/2014	1:00:00 AM	0.31
9/1/2014	1:15:00 AM	0.31
9/1/2014	1:30:00 AM	0.31
9/1/2014	1:45:00 AM	0.31
9/1/2014	2:00:00 AM	0.31
9/1/2014	2:15:00 AM	0.31
9/1/2014	2:30:00 AM	0.31
9/1/2014	2:45:00 AM	0.31
9/1/2014	3:00:00 AM	0.31
9/1/2014	3:15:00 AM	0.31
9/1/2014	3:30:00 AM	0.31
9/1/2014	3:45:00 AM	0.31
9/1/2014	4:00:00 AM	0.31
9/1/2014	4:15:00 AM	0.32
9/1/2014	4:30:00 AM	0.32
9/1/2014	4:45:00 AM	0.32
9/1/2014	5:00:00 AM	0.32
9/1/2014	5:15:00 AM	0.32
9/1/2014	5:30:00 AM	0.32
9/1/2014	5:45:00 AM	0.32
9/1/2014	6:00:00 AM	0.32
9/1/2014	6:15:00 AM	0.32
9/1/2014	6:30:00 AM	0.32
9/1/2014	6:45:00 AM	0.32
9/1/2014	7:00:00 AM	0.32
9/1/2014	7:15:00 AM	0.32
9/1/2014	7:30:00 AM	0.32
9/1/2014	7:45:00 AM	0.32
9/1/2014	8:00:00 AM	0.32
9/1/2014	8:15:00 AM	0.32
9/1/2014	8:30:00 AM	0.32
9/1/2014	8:45:00 AM	0.32
9/1/2014	9:00:00 AM	0.32
9/1/2014	9:15:00 AM	0.32
9/1/2014	9:30:00 AM	0.32
9/1/2014	9:45:00 AM	0.32
9/1/2014	10:00:00 AM	0.32
9/1/2014	10:15:00 AM	0.32
9/1/2014	10:30:00 AM	0.32
9/1/2014	10:45:00 AM	0.32
9/1/2014	11:00:00 AM	0.32
9/1/2014	11:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/1/2014	11:30:00 AM	0.32
9/1/2014	11:45:00 AM	0.32
9/1/2014	12:00:00 PM	0.32
9/1/2014	12:15:00 PM	0.32
9/1/2014	12:30:00 PM	0.32
9/1/2014	12:45:00 PM	0.32
9/1/2014	1:00:00 PM	0.32
9/1/2014	1:15:00 PM	0.32
9/1/2014	1:30:00 PM	0.32
9/1/2014	1:45:00 PM	0.32
9/1/2014	2:00:00 PM	0.32
9/1/2014	2:15:00 PM	0.32
9/1/2014	2:30:00 PM	0.32
9/1/2014	2:45:00 PM	0.32
9/1/2014	3:00:00 PM	0.32
9/1/2014	3:15:00 PM	0.32
9/1/2014	3:30:00 PM	0.32
9/1/2014	3:45:00 PM	0.32
9/1/2014	4:00:00 PM	0.32
9/1/2014	4:15:00 PM	0.32
9/1/2014	4:30:00 PM	0.32
9/1/2014	4:45:00 PM	0.32
9/1/2014	5:00:00 PM	0.32
9/1/2014	5:15:00 PM	0.32
9/1/2014	5:30:00 PM	0.32
9/1/2014	5:45:00 PM	0.32
9/1/2014	6:00:00 PM	0.32
9/1/2014	6:15:00 PM	0.32
9/1/2014	6:30:00 PM	0.32
9/1/2014	6:45:00 PM	0.32
9/1/2014	7:00:00 PM	0.32
9/1/2014	7:15:00 PM	0.32
9/1/2014	7:30:00 PM	0.32
9/1/2014	7:45:00 PM	0.32
9/1/2014	8:00:00 PM	0.32
9/1/2014	8:15:00 PM	0.32
9/1/2014	8:30:00 PM	0.32
9/1/2014	8:45:00 PM	0.32
9/1/2014	9:00:00 PM	0.32
9/1/2014	9:15:00 PM	0.32
9/1/2014	9:30:00 PM	0.32
9/1/2014	9:45:00 PM	0.32
9/1/2014	10:00:00 PM	0.32
9/1/2014	10:15:00 PM	0.32
9/1/2014	10:30:00 PM	0.32
9/1/2014	10:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/1/2014	11:00:00 PM	0.32
9/1/2014	11:15:00 PM	0.32
9/1/2014	11:30:00 PM	0.32
9/1/2014	11:45:00 PM	0.32
9/2/2014	12:00:00 AM	0.32
9/2/2014	12:15:00 AM	0.32
9/2/2014	12:30:00 AM	0.32
9/2/2014	12:45:00 AM	0.32
9/2/2014	1:00:00 AM	0.32
9/2/2014	1:15:00 AM	0.32
9/2/2014	1:30:00 AM	0.32
9/2/2014	1:45:00 AM	0.32
9/2/2014	2:00:00 AM	0.32
9/2/2014	2:15:00 AM	0.32
9/2/2014	2:30:00 AM	0.32
9/2/2014	2:45:00 AM	0.32
9/2/2014	3:00:00 AM	0.32
9/2/2014	3:15:00 AM	0.32
9/2/2014	3:30:00 AM	0.32
9/2/2014	3:45:00 AM	0.32
9/2/2014	4:00:00 AM	0.32
9/2/2014	4:15:00 AM	0.32
9/2/2014	4:30:00 AM	0.32
9/2/2014	4:45:00 AM	0.32
9/2/2014	5:00:00 AM	0.32
9/2/2014	5:15:00 AM	0.32
9/2/2014	5:30:00 AM	0.32
9/2/2014	5:45:00 AM	0.32
9/2/2014	6:00:00 AM	0.32
9/2/2014	6:15:00 AM	0.32
9/2/2014	6:30:00 AM	0.32
9/2/2014	6:45:00 AM	0.32
9/2/2014	7:00:00 AM	0.32
9/2/2014	7:15:00 AM	0.32
9/2/2014	7:30:00 AM	0.32
9/2/2014	7:45:00 AM	0.32
9/2/2014	8:00:00 AM	0.32
9/2/2014	8:15:00 AM	0.32
9/2/2014	8:30:00 AM	0.32
9/2/2014	8:45:00 AM	0.32
9/2/2014	9:00:00 AM	0.32
9/2/2014	9:15:00 AM	0.32
9/2/2014	9:30:00 AM	0.32
9/2/2014	9:45:00 AM	0.32
9/2/2014	10:00:00 AM	0.32
9/2/2014	10:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/2/2014	10:30:00 AM	0.32
9/2/2014	10:45:00 AM	0.32
9/2/2014	11:00:00 AM	0.32
9/2/2014	11:15:00 AM	0.32
9/2/2014	11:30:00 AM	0.32
9/2/2014	11:45:00 AM	0.32
9/2/2014	12:00:00 PM	0.32
9/2/2014	12:15:00 PM	0.32
9/2/2014	12:30:00 PM	0.32
9/2/2014	12:45:00 PM	0.32
9/2/2014	1:00:00 PM	0.32
9/2/2014	1:15:00 PM	0.32
9/2/2014	1:30:00 PM	0.32
9/2/2014	1:45:00 PM	0.32
9/2/2014	2:00:00 PM	0.32
9/2/2014	2:15:00 PM	0.32
9/2/2014	2:30:00 PM	0.32
9/2/2014	2:45:00 PM	0.32
9/2/2014	3:00:00 PM	0.32
9/2/2014	3:15:00 PM	0.32
9/2/2014	3:30:00 PM	0.32
9/2/2014	3:45:00 PM	0.32
9/2/2014	4:00:00 PM	0.32
9/2/2014	4:15:00 PM	0.32
9/2/2014	4:30:00 PM	0.32
9/2/2014	4:45:00 PM	0.32
9/2/2014	5:00:00 PM	0.32
9/2/2014	5:15:00 PM	0.32
9/2/2014	5:30:00 PM	0.32
9/2/2014	5:45:00 PM	0.32
9/2/2014	6:00:00 PM	0.32
9/2/2014	6:15:00 PM	0.32
9/2/2014	6:30:00 PM	0.32
9/2/2014	6:45:00 PM	0.32
9/2/2014	7:00:00 PM	0.32
9/2/2014	7:15:00 PM	0.32
9/2/2014	7:30:00 PM	0.32
9/2/2014	7:45:00 PM	0.32
9/2/2014	8:00:00 PM	0.32
9/2/2014	8:15:00 PM	0.32
9/2/2014	8:30:00 PM	0.32
9/2/2014	8:45:00 PM	0.32
9/2/2014	9:00:00 PM	0.32
9/2/2014	9:15:00 PM	0.32
9/2/2014	9:30:00 PM	0.32
9/2/2014	9:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/2/2014	10:00:00 PM	0.32
9/2/2014	10:15:00 PM	0.32
9/2/2014	10:30:00 PM	0.32
9/2/2014	10:45:00 PM	0.32
9/2/2014	11:00:00 PM	0.32
9/2/2014	11:15:00 PM	0.32
9/2/2014	11:30:00 PM	0.32
9/2/2014	11:45:00 PM	0.32
9/3/2014	12:00:00 AM	0.32
9/3/2014	12:15:00 AM	0.32
9/3/2014	12:30:00 AM	0.32
9/3/2014	12:45:00 AM	0.32
9/3/2014	1:00:00 AM	0.32
9/3/2014	1:15:00 AM	0.32
9/3/2014	1:30:00 AM	0.32
9/3/2014	1:45:00 AM	0.32
9/3/2014	2:00:00 AM	0.32
9/3/2014	2:15:00 AM	0.32
9/3/2014	2:30:00 AM	0.32
9/3/2014	2:45:00 AM	0.32
9/3/2014	3:00:00 AM	0.32
9/3/2014	3:15:00 AM	0.32
9/3/2014	3:30:00 AM	0.32
9/3/2014	3:45:00 AM	0.32
9/3/2014	4:00:00 AM	0.32
9/3/2014	4:15:00 AM	0.32
9/3/2014	4:30:00 AM	0.32
9/3/2014	4:45:00 AM	0.32
9/3/2014	5:00:00 AM	0.32
9/3/2014	5:15:00 AM	0.32
9/3/2014	5:30:00 AM	0.32
9/3/2014	5:45:00 AM	0.32
9/3/2014	6:00:00 AM	0.32
9/3/2014	6:15:00 AM	0.32
9/3/2014	6:30:00 AM	0.32
9/3/2014	6:45:00 AM	0.32
9/3/2014	7:00:00 AM	0.32
9/3/2014	7:15:00 AM	0.32
9/3/2014	7:30:00 AM	0.32
9/3/2014	7:45:00 AM	0.32
9/3/2014	8:00:00 AM	0.32
9/3/2014	8:15:00 AM	0.32
9/3/2014	8:30:00 AM	0.32
9/3/2014	8:45:00 AM	0.32
9/3/2014	9:00:00 AM	0.32
9/3/2014	9:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/3/2014	9:30:00 AM	0.32
9/3/2014	9:45:00 AM	0.32
9/3/2014	10:00:00 AM	0.32
9/3/2014	10:15:00 AM	0.32
9/3/2014	10:30:00 AM	0.32
9/3/2014	10:45:00 AM	0.32
9/3/2014	11:00:00 AM	0.32
9/3/2014	11:15:00 AM	0.32
9/3/2014	11:30:00 AM	0.32
9/3/2014	11:45:00 AM	0.32
9/3/2014	12:00:00 PM	0.32
9/3/2014	12:15:00 PM	0.32
9/3/2014	12:30:00 PM	0.32
9/3/2014	12:45:00 PM	0.32
9/3/2014	1:00:00 PM	0.32
9/3/2014	1:15:00 PM	0.32
9/3/2014	1:30:00 PM	0.32
9/3/2014	1:45:00 PM	0.32
9/3/2014	2:00:00 PM	0.32
9/3/2014	2:15:00 PM	0.32
9/3/2014	2:30:00 PM	0.32
9/3/2014	2:45:00 PM	0.32
9/3/2014	3:00:00 PM	0.32
9/3/2014	3:15:00 PM	0.32
9/3/2014	3:30:00 PM	0.32
9/3/2014	3:45:00 PM	0.32
9/3/2014	4:00:00 PM	0.32
9/3/2014	4:15:00 PM	0.32
9/3/2014	4:30:00 PM	0.32
9/3/2014	4:45:00 PM	0.32
9/3/2014	5:00:00 PM	0.32
9/3/2014	5:15:00 PM	0.32
9/3/2014	5:30:00 PM	0.32
9/3/2014	5:45:00 PM	0.32
9/3/2014	6:00:00 PM	0.32
9/3/2014	6:15:00 PM	0.32
9/3/2014	6:30:00 PM	0.32
9/3/2014	6:45:00 PM	0.32
9/3/2014	7:00:00 PM	0.32
9/3/2014	7:15:00 PM	0.32
9/3/2014	7:30:00 PM	0.32
9/3/2014	7:45:00 PM	0.32
9/3/2014	8:00:00 PM	0.32
9/3/2014	8:15:00 PM	0.32
9/3/2014	8:30:00 PM	0.32
9/3/2014	8:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/3/2014	9:00:00 PM	0.32
9/3/2014	9:15:00 PM	0.32
9/3/2014	9:30:00 PM	0.32
9/3/2014	9:45:00 PM	0.32
9/3/2014	10:00:00 PM	0.32
9/3/2014	10:15:00 PM	0.32
9/3/2014	10:30:00 PM	0.32
9/3/2014	10:45:00 PM	0.32
9/3/2014	11:00:00 PM	0.32
9/3/2014	11:15:00 PM	0.32
9/3/2014	11:30:00 PM	0.32
9/3/2014	11:45:00 PM	0.32
9/4/2014	12:00:00 AM	0.32
9/4/2014	12:15:00 AM	0.32
9/4/2014	12:30:00 AM	0.32
9/4/2014	12:45:00 AM	0.32
9/4/2014	1:00:00 AM	0.32
9/4/2014	1:15:00 AM	0.32
9/4/2014	1:30:00 AM	0.32
9/4/2014	1:45:00 AM	0.32
9/4/2014	2:00:00 AM	0.32
9/4/2014	2:15:00 AM	0.32
9/4/2014	2:30:00 AM	0.32
9/4/2014	2:45:00 AM	0.32
9/4/2014	3:00:00 AM	0.32
9/4/2014	3:15:00 AM	0.32
9/4/2014	3:30:00 AM	0.32
9/4/2014	3:45:00 AM	0.32
9/4/2014	4:00:00 AM	0.32
9/4/2014	4:15:00 AM	0.32
9/4/2014	4:30:00 AM	0.32
9/4/2014	4:45:00 AM	0.32
9/4/2014	5:00:00 AM	0.32
9/4/2014	5:15:00 AM	0.32
9/4/2014	5:30:00 AM	0.32
9/4/2014	5:45:00 AM	0.32
9/4/2014	6:00:00 AM	0.32
9/4/2014	6:15:00 AM	0.32
9/4/2014	6:30:00 AM	0.32
9/4/2014	6:45:00 AM	0.32
9/4/2014	7:00:00 AM	0.32
9/4/2014	7:15:00 AM	0.32
9/4/2014	7:30:00 AM	0.32
9/4/2014	7:45:00 AM	0.32
9/4/2014	8:00:00 AM	0.32
9/4/2014	8:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/4/2014	8:30:00 AM	0.32
9/4/2014	8:45:00 AM	0.32
9/4/2014	9:00:00 AM	0.32
9/4/2014	9:15:00 AM	0.32
9/4/2014	9:30:00 AM	0.32
9/4/2014	9:45:00 AM	0.32
9/4/2014	10:00:00 AM	0.32
9/4/2014	10:15:00 AM	0.32
9/4/2014	10:30:00 AM	0.32
9/4/2014	10:45:00 AM	0.32
9/4/2014	11:00:00 AM	0.32
9/4/2014	11:15:00 AM	0.32
9/4/2014	11:30:00 AM	0.32
9/4/2014	11:45:00 AM	0.32
9/4/2014	12:00:00 PM	0.32
9/4/2014	12:15:00 PM	0.32
9/4/2014	12:30:00 PM	0.32
9/4/2014	12:45:00 PM	0.32
9/4/2014	1:00:00 PM	0.32
9/4/2014	1:15:00 PM	0.32
9/4/2014	1:30:00 PM	0.32
9/4/2014	1:45:00 PM	0.32
9/4/2014	2:00:00 PM	0.32
9/4/2014	2:15:00 PM	0.32
9/4/2014	2:30:00 PM	0.32
9/4/2014	2:45:00 PM	0.32
9/4/2014	3:00:00 PM	0.32
9/4/2014	3:15:00 PM	0.32
9/4/2014	3:30:00 PM	0.32
9/4/2014	3:45:00 PM	0.32
9/4/2014	4:00:00 PM	0.32
9/4/2014	4:15:00 PM	0.32
9/4/2014	4:30:00 PM	0.32
9/4/2014	4:45:00 PM	0.32
9/4/2014	5:00:00 PM	0.32
9/4/2014	5:15:00 PM	0.32
9/4/2014	5:30:00 PM	0.32
9/4/2014	5:45:00 PM	0.32
9/4/2014	6:00:00 PM	0.32
9/4/2014	6:15:00 PM	0.32
9/4/2014	6:30:00 PM	0.32
9/4/2014	6:45:00 PM	0.32
9/4/2014	7:00:00 PM	0.32
9/4/2014	7:15:00 PM	0.32
9/4/2014	7:30:00 PM	0.32
9/4/2014	7:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/4/2014	8:00:00 PM	0.32
9/4/2014	8:15:00 PM	0.32
9/4/2014	8:30:00 PM	0.32
9/4/2014	8:45:00 PM	0.32
9/4/2014	9:00:00 PM	0.32
9/4/2014	9:15:00 PM	0.32
9/4/2014	9:30:00 PM	0.32
9/4/2014	9:45:00 PM	0.32
9/4/2014	10:00:00 PM	0.32
9/4/2014	10:15:00 PM	0.32
9/4/2014	10:30:00 PM	0.32
9/4/2014	10:45:00 PM	0.32
9/4/2014	11:00:00 PM	0.32
9/4/2014	11:15:00 PM	0.32
9/4/2014	11:30:00 PM	0.32
9/4/2014	11:45:00 PM	0.32
9/5/2014	12:00:00 AM	0.32
9/5/2014	12:15:00 AM	0.32
9/5/2014	12:30:00 AM	0.32
9/5/2014	12:45:00 AM	0.32
9/5/2014	1:00:00 AM	0.32
9/5/2014	1:15:00 AM	0.32
9/5/2014	1:30:00 AM	0.32
9/5/2014	1:45:00 AM	0.32
9/5/2014	2:00:00 AM	0.32
9/5/2014	2:15:00 AM	0.32
9/5/2014	2:30:00 AM	0.32
9/5/2014	2:45:00 AM	0.32
9/5/2014	3:00:00 AM	0.32
9/5/2014	3:15:00 AM	0.32
9/5/2014	3:30:00 AM	0.32
9/5/2014	3:45:00 AM	0.32
9/5/2014	4:00:00 AM	0.32
9/5/2014	4:15:00 AM	0.32
9/5/2014	4:30:00 AM	0.32
9/5/2014	4:45:00 AM	0.32
9/5/2014	5:00:00 AM	0.32
9/5/2014	5:15:00 AM	0.32
9/5/2014	5:30:00 AM	0.32
9/5/2014	5:45:00 AM	0.32
9/5/2014	6:00:00 AM	0.32
9/5/2014	6:15:00 AM	0.32
9/5/2014	6:30:00 AM	0.32
9/5/2014	6:45:00 AM	0.32
9/5/2014	7:00:00 AM	0.32
9/5/2014	7:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/5/2014	7:30:00 AM	0.32
9/5/2014	7:45:00 AM	0.32
9/5/2014	8:00:00 AM	0.32
9/5/2014	8:15:00 AM	0.32
9/5/2014	8:30:00 AM	0.32
9/5/2014	8:45:00 AM	0.32
9/5/2014	9:00:00 AM	0.32
9/5/2014	9:15:00 AM	0.32
9/5/2014	9:30:00 AM	0.32
9/5/2014	9:45:00 AM	0.32
9/5/2014	10:00:00 AM	0.32
9/5/2014	10:15:00 AM	0.32
9/5/2014	10:30:00 AM	0.32
9/5/2014	10:45:00 AM	0.32
9/5/2014	11:00:00 AM	0.32
9/5/2014	11:15:00 AM	0.32
9/5/2014	11:30:00 AM	0.32
9/5/2014	11:45:00 AM	0.32
9/5/2014	12:00:00 PM	0.32
9/5/2014	12:15:00 PM	0.32
9/5/2014	12:30:00 PM	0.32
9/5/2014	12:45:00 PM	0.32
9/5/2014	1:00:00 PM	0.32
9/5/2014	1:15:00 PM	0.32
9/5/2014	1:30:00 PM	0.32
9/5/2014	1:45:00 PM	0.32
9/5/2014	2:00:00 PM	0.32
9/5/2014	2:15:00 PM	0.32
9/5/2014	2:30:00 PM	0.32
9/5/2014	2:45:00 PM	0.32
9/5/2014	3:00:00 PM	0.32
9/5/2014	3:15:00 PM	0.32
9/5/2014	3:30:00 PM	0.32
9/5/2014	3:45:00 PM	0.32
9/5/2014	4:00:00 PM	0.32
9/5/2014	4:15:00 PM	0.32
9/5/2014	4:30:00 PM	0.32
9/5/2014	4:45:00 PM	0.32
9/5/2014	5:00:00 PM	0.32
9/5/2014	5:15:00 PM	0.32
9/5/2014	5:30:00 PM	0.32
9/5/2014	5:45:00 PM	0.32
9/5/2014	6:00:00 PM	0.32
9/5/2014	6:15:00 PM	0.32
9/5/2014	6:30:00 PM	0.32
9/5/2014	6:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/5/2014	7:00:00 PM	0.32
9/5/2014	7:15:00 PM	0.32
9/5/2014	7:30:00 PM	0.32
9/5/2014	7:45:00 PM	0.32
9/5/2014	8:00:00 PM	0.32
9/5/2014	8:15:00 PM	0.32
9/5/2014	8:30:00 PM	0.32
9/5/2014	8:45:00 PM	0.32
9/5/2014	9:00:00 PM	0.32
9/5/2014	9:15:00 PM	0.32
9/5/2014	9:30:00 PM	0.32
9/5/2014	9:45:00 PM	0.32
9/5/2014	10:00:00 PM	0.32
9/5/2014	10:15:00 PM	0.32
9/5/2014	10:30:00 PM	0.32
9/5/2014	10:45:00 PM	0.32
9/5/2014	11:00:00 PM	0.32
9/5/2014	11:15:00 PM	0.32
9/5/2014	11:30:00 PM	0.32
9/5/2014	11:45:00 PM	0.32
9/6/2014	12:00:00 AM	0.32
9/6/2014	12:15:00 AM	0.32
9/6/2014	12:30:00 AM	0.32
9/6/2014	12:45:00 AM	0.32
9/6/2014	1:00:00 AM	0.32
9/6/2014	1:15:00 AM	0.32
9/6/2014	1:30:00 AM	0.32
9/6/2014	1:45:00 AM	0.32
9/6/2014	2:00:00 AM	0.32
9/6/2014	2:15:00 AM	0.32
9/6/2014	2:30:00 AM	0.32
9/6/2014	2:45:00 AM	0.32
9/6/2014	3:00:00 AM	0.32
9/6/2014	3:15:00 AM	0.32
9/6/2014	3:30:00 AM	0.32
9/6/2014	3:45:00 AM	0.32
9/6/2014	4:00:00 AM	0.32
9/6/2014	4:15:00 AM	0.32
9/6/2014	4:30:00 AM	0.32
9/6/2014	4:45:00 AM	0.32
9/6/2014	5:00:00 AM	0.32
9/6/2014	5:15:00 AM	0.32
9/6/2014	5:30:00 AM	0.32
9/6/2014	5:45:00 AM	0.32
9/6/2014	6:00:00 AM	0.32
9/6/2014	6:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/6/2014	6:30:00 AM	0.32
9/6/2014	6:45:00 AM	0.32
9/6/2014	7:00:00 AM	0.32
9/6/2014	7:15:00 AM	0.32
9/6/2014	7:30:00 AM	0.32
9/6/2014	7:45:00 AM	0.32
9/6/2014	8:00:00 AM	0.32
9/6/2014	8:15:00 AM	0.32
9/6/2014	8:30:00 AM	0.32
9/6/2014	8:45:00 AM	0.32
9/6/2014	9:00:00 AM	0.32
9/6/2014	9:15:00 AM	0.32
9/6/2014	9:30:00 AM	0.32
9/6/2014	9:45:00 AM	0.32
9/6/2014	10:00:00 AM	0.32
9/6/2014	10:15:00 AM	0.32
9/6/2014	10:30:00 AM	0.32
9/6/2014	10:45:00 AM	0.32
9/6/2014	11:00:00 AM	0.32
9/6/2014	11:15:00 AM	0.32
9/6/2014	11:30:00 AM	0.32
9/6/2014	11:45:00 AM	0.32
9/6/2014	12:00:00 PM	0.32
9/6/2014	12:15:00 PM	0.32
9/6/2014	12:30:00 PM	0.32
9/6/2014	12:45:00 PM	0.32
9/6/2014	1:00:00 PM	0.32
9/6/2014	1:15:00 PM	0.32
9/6/2014	1:30:00 PM	0.32
9/6/2014	1:45:00 PM	0.32
9/6/2014	2:00:00 PM	0.32
9/6/2014	2:15:00 PM	0.32
9/6/2014	2:30:00 PM	0.32
9/6/2014	2:45:00 PM	0.32
9/6/2014	3:00:00 PM	0.32
9/6/2014	3:15:00 PM	0.32
9/6/2014	3:30:00 PM	0.32
9/6/2014	3:45:00 PM	0.32
9/6/2014	4:00:00 PM	0.32
9/6/2014	4:15:00 PM	0.32
9/6/2014	4:30:00 PM	0.32
9/6/2014	4:45:00 PM	0.32
9/6/2014	5:00:00 PM	0.32
9/6/2014	5:15:00 PM	0.32
9/6/2014	5:30:00 PM	0.32
9/6/2014	5:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/6/2014	6:00:00 PM	0.32
9/6/2014	6:15:00 PM	0.32
9/6/2014	6:30:00 PM	0.32
9/6/2014	6:45:00 PM	0.32
9/6/2014	7:00:00 PM	0.32
9/6/2014	7:15:00 PM	0.32
9/6/2014	7:30:00 PM	0.32
9/6/2014	7:45:00 PM	0.32
9/6/2014	8:00:00 PM	0.32
9/6/2014	8:15:00 PM	0.32
9/6/2014	8:30:00 PM	0.32
9/6/2014	8:45:00 PM	0.32
9/6/2014	9:00:00 PM	0.32
9/6/2014	9:15:00 PM	0.32
9/6/2014	9:30:00 PM	0.32
9/6/2014	9:45:00 PM	0.32
9/6/2014	10:00:00 PM	0.32
9/6/2014	10:15:00 PM	0.32
9/6/2014	10:30:00 PM	0.32
9/6/2014	10:45:00 PM	0.32
9/6/2014	11:00:00 PM	0.32
9/6/2014	11:15:00 PM	0.32
9/6/2014	11:30:00 PM	0.32
9/6/2014	11:45:00 PM	0.32
9/7/2014	12:00:00 AM	0.32
9/7/2014	12:15:00 AM	0.32
9/7/2014	12:30:00 AM	0.32
9/7/2014	12:45:00 AM	0.32
9/7/2014	1:00:00 AM	0.32
9/7/2014	1:15:00 AM	0.32
9/7/2014	1:30:00 AM	0.32
9/7/2014	1:45:00 AM	0.32
9/7/2014	2:00:00 AM	0.32
9/7/2014	2:15:00 AM	0.32
9/7/2014	2:30:00 AM	0.32
9/7/2014	2:45:00 AM	0.32
9/7/2014	3:00:00 AM	0.32
9/7/2014	3:15:00 AM	0.32
9/7/2014	3:30:00 AM	0.32
9/7/2014	3:45:00 AM	0.32
9/7/2014	4:00:00 AM	0.32
9/7/2014	4:15:00 AM	0.32
9/7/2014	4:30:00 AM	0.32
9/7/2014	4:45:00 AM	0.32
9/7/2014	5:00:00 AM	0.32
9/7/2014	5:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/7/2014	5:30:00 AM	0.32
9/7/2014	5:45:00 AM	0.32
9/7/2014	6:00:00 AM	0.32
9/7/2014	6:15:00 AM	0.32
9/7/2014	6:30:00 AM	0.32
9/7/2014	6:45:00 AM	0.32
9/7/2014	7:00:00 AM	0.32
9/7/2014	7:15:00 AM	0.32
9/7/2014	7:30:00 AM	0.32
9/7/2014	7:45:00 AM	0.32
9/7/2014	8:00:00 AM	0.32
9/7/2014	8:15:00 AM	0.32
9/7/2014	8:30:00 AM	0.32
9/7/2014	8:45:00 AM	0.32
9/7/2014	9:00:00 AM	0.32
9/7/2014	9:15:00 AM	0.32
9/7/2014	9:30:00 AM	0.32
9/7/2014	9:45:00 AM	0.32
9/7/2014	10:00:00 AM	0.32
9/7/2014	10:15:00 AM	0.32
9/7/2014	10:30:00 AM	0.32
9/7/2014	10:45:00 AM	0.32
9/7/2014	11:00:00 AM	0.32
9/7/2014	11:15:00 AM	0.32
9/7/2014	11:30:00 AM	0.32
9/7/2014	11:45:00 AM	0.32
9/7/2014	12:00:00 PM	0.32
9/7/2014	12:15:00 PM	0.32
9/7/2014	12:30:00 PM	0.32
9/7/2014	12:45:00 PM	0.32
9/7/2014	1:00:00 PM	0.32
9/7/2014	1:15:00 PM	0.32
9/7/2014	1:30:00 PM	0.32
9/7/2014	1:45:00 PM	0.32
9/7/2014	2:00:00 PM	0.32
9/7/2014	2:15:00 PM	0.32
9/7/2014	2:30:00 PM	0.32
9/7/2014	2:45:00 PM	0.32
9/7/2014	3:00:00 PM	0.32
9/7/2014	3:15:00 PM	0.32
9/7/2014	3:30:00 PM	0.32
9/7/2014	3:45:00 PM	0.32
9/7/2014	4:00:00 PM	0.32
9/7/2014	4:15:00 PM	0.32
9/7/2014	4:30:00 PM	0.32
9/7/2014	4:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/7/2014	5:00:00 PM	0.32
9/7/2014	5:15:00 PM	0.32
9/7/2014	5:30:00 PM	0.31
9/7/2014	5:45:00 PM	0.31
9/7/2014	6:00:00 PM	0.31
9/7/2014	6:15:00 PM	0.31
9/7/2014	6:30:00 PM	0.31
9/7/2014	6:45:00 PM	0.31
9/7/2014	7:00:00 PM	0.31
9/7/2014	7:15:00 PM	0.31
9/7/2014	7:30:00 PM	0.31
9/7/2014	7:45:00 PM	0.31
9/7/2014	8:00:00 PM	0.31
9/7/2014	8:15:00 PM	0.31
9/7/2014	8:30:00 PM	0.31
9/7/2014	8:45:00 PM	0.31
9/7/2014	9:00:00 PM	0.31
9/7/2014	9:15:00 PM	0.31
9/7/2014	9:30:00 PM	0.31
9/7/2014	9:45:00 PM	0.31
9/7/2014	10:00:00 PM	0.31
9/7/2014	10:15:00 PM	0.31
9/7/2014	10:30:00 PM	0.31
9/7/2014	10:45:00 PM	0.31
9/7/2014	11:00:00 PM	0.31
9/7/2014	11:15:00 PM	0.31
9/7/2014	11:30:00 PM	0.31
9/7/2014	11:45:00 PM	0.31
9/8/2014	12:00:00 AM	0.31
9/8/2014	12:15:00 AM	0.31
9/8/2014	12:30:00 AM	0.31
9/8/2014	12:45:00 AM	0.31
9/8/2014	1:00:00 AM	0.31
9/8/2014	1:15:00 AM	0.31
9/8/2014	1:30:00 AM	0.31
9/8/2014	1:45:00 AM	0.31
9/8/2014	2:00:00 AM	0.31
9/8/2014	2:15:00 AM	0.31
9/8/2014	2:30:00 AM	0.31
9/8/2014	2:45:00 AM	0.31
9/8/2014	3:00:00 AM	0.31
9/8/2014	3:15:00 AM	0.31
9/8/2014	3:30:00 AM	0.31
9/8/2014	3:45:00 AM	0.32
9/8/2014	4:00:00 AM	0.32
9/8/2014	4:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/8/2014	4:30:00 AM	0.32
9/8/2014	4:45:00 AM	0.32
9/8/2014	5:00:00 AM	0.32
9/8/2014	5:15:00 AM	0.32
9/8/2014	5:30:00 AM	0.32
9/8/2014	5:45:00 AM	0.32
9/8/2014	6:00:00 AM	0.32
9/8/2014	6:15:00 AM	0.32
9/8/2014	6:30:00 AM	0.32
9/8/2014	6:45:00 AM	0.32
9/8/2014	7:00:00 AM	0.32
9/8/2014	7:15:00 AM	0.32
9/8/2014	7:30:00 AM	0.32
9/8/2014	7:45:00 AM	0.32
9/8/2014	8:00:00 AM	0.32
9/8/2014	8:15:00 AM	0.32
9/8/2014	8:30:00 AM	0.32
9/8/2014	8:45:00 AM	0.32
9/8/2014	9:00:00 AM	0.32
9/8/2014	9:15:00 AM	0.32
9/8/2014	9:30:00 AM	0.32
9/8/2014	9:45:00 AM	0.32
9/8/2014	10:00:00 AM	0.32
9/8/2014	10:15:00 AM	0.32
9/8/2014	10:30:00 AM	0.32
9/8/2014	10:45:00 AM	0.32
9/8/2014	11:00:00 AM	0.32
9/8/2014	11:15:00 AM	0.32
9/8/2014	11:30:00 AM	0.32
9/8/2014	11:45:00 AM	0.32
9/8/2014	12:00:00 PM	0.32
9/8/2014	12:15:00 PM	0.32
9/8/2014	12:30:00 PM	0.32
9/8/2014	12:45:00 PM	0.32
9/8/2014	1:00:00 PM	0.32
9/8/2014	1:15:00 PM	0.32
9/8/2014	1:30:00 PM	0.32
9/8/2014	1:45:00 PM	0.32
9/8/2014	2:00:00 PM	0.32
9/8/2014	2:15:00 PM	0.32
9/8/2014	2:30:00 PM	0.32
9/8/2014	2:45:00 PM	0.32
9/8/2014	3:00:00 PM	0.32
9/8/2014	3:15:00 PM	0.32
9/8/2014	3:30:00 PM	0.32
9/8/2014	3:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
9/8/2014	4:00:00 PM	0.32
9/8/2014	4:15:00 PM	0.32
9/8/2014	4:30:00 PM	0.32
9/8/2014	4:45:00 PM	0.32
9/8/2014	5:00:00 PM	0.32
9/8/2014	5:15:00 PM	0.32
9/8/2014	5:30:00 PM	0.32
9/8/2014	5:45:00 PM	0.32
9/8/2014	6:00:00 PM	0.32
9/8/2014	6:15:00 PM	0.32
9/8/2014	6:30:00 PM	0.32
9/8/2014	6:45:00 PM	0.32
9/8/2014	7:00:00 PM	0.32
9/8/2014	7:15:00 PM	0.32
9/8/2014	7:30:00 PM	0.32
9/8/2014	7:45:00 PM	0.32
9/8/2014	8:00:00 PM	0.32
9/8/2014	8:15:00 PM	0.32
9/8/2014	8:30:00 PM	0.32
9/8/2014	8:45:00 PM	0.31
9/8/2014	9:00:00 PM	0.31
9/8/2014	9:15:00 PM	0.31
9/8/2014	9:30:00 PM	0.31
9/8/2014	9:45:00 PM	0.31
9/8/2014	10:00:00 PM	0.31
9/8/2014	10:15:00 PM	0.31
9/8/2014	10:30:00 PM	0.31
9/8/2014	10:45:00 PM	0.31
9/8/2014	11:00:00 PM	0.31
9/8/2014	11:15:00 PM	0.31
9/8/2014	11:30:00 PM	0.31
9/8/2014	11:45:00 PM	0.31
9/9/2014	12:00:00 AM	0.31
9/9/2014	12:15:00 AM	0.31
9/9/2014	12:30:00 AM	0.31
9/9/2014	12:45:00 AM	0.31
9/9/2014	1:00:00 AM	0.31
9/9/2014	1:15:00 AM	0.31
9/9/2014	1:30:00 AM	0.31
9/9/2014	1:45:00 AM	0.31
9/9/2014	2:00:00 AM	0.31
9/9/2014	2:15:00 AM	0.31
9/9/2014	2:30:00 AM	0.31
9/9/2014	2:45:00 AM	0.31
9/9/2014	3:00:00 AM	0.31
9/9/2014	3:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/9/2014	3:30:00 AM	0.31
9/9/2014	3:45:00 AM	0.31
9/9/2014	4:00:00 AM	0.31
9/9/2014	4:15:00 AM	0.31
9/9/2014	4:30:00 AM	0.31
9/9/2014	4:45:00 AM	0.31
9/9/2014	5:00:00 AM	0.31
9/9/2014	5:15:00 AM	0.31
9/9/2014	5:30:00 AM	0.31
9/9/2014	5:45:00 AM	0.31
9/9/2014	6:00:00 AM	0.31
9/9/2014	6:15:00 AM	0.31
9/9/2014	6:30:00 AM	0.31
9/9/2014	6:45:00 AM	0.31
9/9/2014	7:00:00 AM	0.31
9/9/2014	7:15:00 AM	0.31
9/9/2014	7:30:00 AM	0.31
9/9/2014	7:45:00 AM	0.31
9/9/2014	8:00:00 AM	0.31
9/9/2014	8:15:00 AM	0.31
9/9/2014	8:30:00 AM	0.31
9/9/2014	8:45:00 AM	0.31
9/9/2014	9:00:00 AM	0.31
9/9/2014	9:15:00 AM	0.31
9/9/2014	9:30:00 AM	0.31
9/9/2014	9:45:00 AM	0.31
9/9/2014	10:00:00 AM	0.31
9/9/2014	10:15:00 AM	0.31
9/9/2014	10:30:00 AM	0.32
9/9/2014	10:45:00 AM	0.32
9/9/2014	11:00:00 AM	0.32
9/9/2014	11:15:00 AM	0.32
9/9/2014	11:30:00 AM	0.32
9/9/2014	11:45:00 AM	0.32
9/9/2014	12:00:00 PM	0.32
9/9/2014	12:15:00 PM	0.32
9/9/2014	12:30:00 PM	0.31
9/9/2014	12:45:00 PM	0.31
9/9/2014	1:00:00 PM	0.31
9/9/2014	1:15:00 PM	0.31
9/9/2014	1:30:00 PM	0.31
9/9/2014	1:45:00 PM	0.31
9/9/2014	2:00:00 PM	0.31
9/9/2014	2:15:00 PM	0.31
9/9/2014	2:30:00 PM	0.31
9/9/2014	2:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/9/2014	3:00:00 PM	0.31
9/9/2014	3:15:00 PM	0.31
9/9/2014	3:30:00 PM	0.31
9/9/2014	3:45:00 PM	0.31
9/9/2014	4:00:00 PM	0.31
9/9/2014	4:15:00 PM	0.31
9/9/2014	4:30:00 PM	0.31
9/9/2014	4:45:00 PM	0.31
9/9/2014	5:00:00 PM	0.31
9/9/2014	5:15:00 PM	0.31
9/9/2014	5:30:00 PM	0.31
9/9/2014	5:45:00 PM	0.31
9/9/2014	6:00:00 PM	0.31
9/9/2014	6:15:00 PM	0.31
9/9/2014	6:30:00 PM	0.31
9/9/2014	6:45:00 PM	0.31
9/9/2014	7:00:00 PM	0.31
9/9/2014	7:15:00 PM	0.31
9/9/2014	7:30:00 PM	0.31
9/9/2014	7:45:00 PM	0.31
9/9/2014	8:00:00 PM	0.31
9/9/2014	8:15:00 PM	0.31
9/9/2014	8:30:00 PM	0.31
9/9/2014	8:45:00 PM	0.31
9/9/2014	9:00:00 PM	0.31
9/9/2014	9:15:00 PM	0.31
9/9/2014	9:30:00 PM	0.31
9/9/2014	9:45:00 PM	0.31
9/9/2014	10:00:00 PM	0.31
9/9/2014	10:15:00 PM	0.31
9/9/2014	10:30:00 PM	0.31
9/9/2014	10:45:00 PM	0.31
9/9/2014	11:00:00 PM	0.31
9/9/2014	11:15:00 PM	0.31
9/9/2014	11:30:00 PM	0.31
9/9/2014	11:45:00 PM	0.31
9/10/2014	12:00:00 AM	0.31
9/10/2014	12:15:00 AM	0.31
9/10/2014	12:30:00 AM	0.31
9/10/2014	12:45:00 AM	0.31
9/10/2014	1:00:00 AM	0.31
9/10/2014	1:15:00 AM	0.31
9/10/2014	1:30:00 AM	0.31
9/10/2014	1:45:00 AM	0.31
9/10/2014	2:00:00 AM	0.31
9/10/2014	2:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/10/2014	2:30:00 AM	0.31
9/10/2014	2:45:00 AM	0.31
9/10/2014	3:00:00 AM	0.31
9/10/2014	3:15:00 AM	0.31
9/10/2014	3:30:00 AM	0.31
9/10/2014	3:45:00 AM	0.31
9/10/2014	4:00:00 AM	0.31
9/10/2014	4:15:00 AM	0.31
9/10/2014	4:30:00 AM	0.31
9/10/2014	4:45:00 AM	0.31
9/10/2014	5:00:00 AM	0.31
9/10/2014	5:15:00 AM	0.31
9/10/2014	5:30:00 AM	0.31
9/10/2014	5:45:00 AM	0.31
9/10/2014	6:00:00 AM	0.31
9/10/2014	6:15:00 AM	0.31
9/10/2014	6:30:00 AM	0.31
9/10/2014	6:45:00 AM	0.31
9/10/2014	7:00:00 AM	0.31
9/10/2014	7:15:00 AM	0.31
9/10/2014	7:30:00 AM	0.31
9/10/2014	7:45:00 AM	0.31
9/10/2014	8:00:00 AM	0.31
9/10/2014	8:15:00 AM	0.31
9/10/2014	8:30:00 AM	0.31
9/10/2014	8:45:00 AM	0.31
9/10/2014	9:00:00 AM	0.31
9/10/2014	9:15:00 AM	0.31
9/10/2014	9:30:00 AM	0.31
9/10/2014	9:45:00 AM	0.31
9/10/2014	10:00:00 AM	0.31
9/10/2014	10:15:00 AM	0.31
9/10/2014	10:30:00 AM	0.31
9/10/2014	10:45:00 AM	0.28
9/10/2014	11:00:00 AM	0.28
9/10/2014	11:15:00 AM	0.28
9/10/2014	11:30:00 AM	0.28
9/10/2014	11:45:00 AM	0.27
9/10/2014	12:00:00 PM	0.27
9/10/2014	12:15:00 PM	0.27
9/10/2014	12:30:00 PM	0.27
9/10/2014	12:45:00 PM	0.27
9/10/2014	1:00:00 PM	0.27
9/10/2014	1:15:00 PM	0.27
9/10/2014	1:30:00 PM	0.27
9/10/2014	1:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
9/10/2014	2:00:00 PM	0.27
9/10/2014	2:15:00 PM	0.27
9/10/2014	2:30:00 PM	0.27
9/10/2014	2:45:00 PM	0.27
9/10/2014	3:00:00 PM	0.27
9/10/2014	3:15:00 PM	0.27
9/10/2014	3:30:00 PM	0.27
9/10/2014	3:45:00 PM	0.26
9/10/2014	4:00:00 PM	0.26
9/10/2014	4:15:00 PM	0.26
9/10/2014	4:30:00 PM	0.26
9/10/2014	4:45:00 PM	0.26
9/10/2014	5:00:00 PM	0.26
9/10/2014	5:15:00 PM	0.26
9/10/2014	5:30:00 PM	0.26
9/10/2014	5:45:00 PM	0.26
9/10/2014	6:00:00 PM	0.26
9/10/2014	6:15:00 PM	0.26
9/10/2014	6:30:00 PM	0.26
9/10/2014	6:45:00 PM	0.26
9/10/2014	7:00:00 PM	0.26
9/10/2014	7:15:00 PM	0.26
9/10/2014	7:30:00 PM	0.26
9/10/2014	7:45:00 PM	0.26
9/10/2014	8:00:00 PM	0.26
9/10/2014	8:15:00 PM	0.26
9/10/2014	8:30:00 PM	0.26
9/10/2014	8:45:00 PM	0.26
9/10/2014	9:00:00 PM	0.26
9/10/2014	9:15:00 PM	0.26
9/10/2014	9:30:00 PM	0.26
9/10/2014	9:45:00 PM	0.26
9/10/2014	10:00:00 PM	0.26
9/10/2014	10:15:00 PM	0.26
9/10/2014	10:30:00 PM	0.26
9/10/2014	10:45:00 PM	0.26
9/10/2014	11:00:00 PM	0.26
9/10/2014	11:15:00 PM	0.26
9/10/2014	11:30:00 PM	0.26
9/10/2014	11:45:00 PM	0.26
9/11/2014	12:00:00 AM	0.26
9/11/2014	12:15:00 AM	0.26
9/11/2014	12:30:00 AM	0.26
9/11/2014	12:45:00 AM	0.26
9/11/2014	1:00:00 AM	0.26
9/11/2014	1:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
9/11/2014	1:30:00 AM	0.26
9/11/2014	1:45:00 AM	0.26
9/11/2014	2:00:00 AM	0.26
9/11/2014	2:15:00 AM	0.26
9/11/2014	2:30:00 AM	0.26
9/11/2014	2:45:00 AM	0.26
9/11/2014	3:00:00 AM	0.26
9/11/2014	3:15:00 AM	0.26
9/11/2014	3:30:00 AM	0.26
9/11/2014	3:45:00 AM	0.26
9/11/2014	4:00:00 AM	0.26
9/11/2014	4:15:00 AM	0.26
9/11/2014	4:30:00 AM	0.26
9/11/2014	4:45:00 AM	0.26
9/11/2014	5:00:00 AM	0.26
9/11/2014	5:15:00 AM	0.26
9/11/2014	5:30:00 AM	0.26
9/11/2014	5:45:00 AM	0.26
9/11/2014	6:00:00 AM	0.26
9/11/2014	6:15:00 AM	0.26
9/11/2014	6:30:00 AM	0.26
9/11/2014	6:45:00 AM	0.26
9/11/2014	7:00:00 AM	0.26
9/11/2014	7:15:00 AM	0.26
9/11/2014	7:30:00 AM	0.26
9/11/2014	7:45:00 AM	0.26
9/11/2014	8:00:00 AM	0.26
9/11/2014	8:15:00 AM	0.26
9/11/2014	8:30:00 AM	0.26
9/11/2014	8:45:00 AM	0.26
9/11/2014	9:00:00 AM	0.26
9/11/2014	9:15:00 AM	0.26
9/11/2014	9:30:00 AM	0.26
9/11/2014	9:45:00 AM	0.26
9/11/2014	10:00:00 AM	0.26
9/11/2014	10:15:00 AM	0.26
9/11/2014	10:30:00 AM	0.26
9/11/2014	10:45:00 AM	0.26
9/11/2014	11:00:00 AM	0.26
9/11/2014	11:15:00 AM	0.26
9/11/2014	11:30:00 AM	0.26
9/11/2014	11:45:00 AM	0.26
9/11/2014	12:00:00 PM	0.26
9/11/2014	12:15:00 PM	0.26
9/11/2014	12:30:00 PM	0.26
9/11/2014	12:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
9/11/2014	1:00:00 PM	0.26
9/11/2014	1:15:00 PM	0.26
9/11/2014	1:30:00 PM	0.26
9/11/2014	1:45:00 PM	0.26
9/11/2014	2:00:00 PM	0.26
9/11/2014	2:15:00 PM	0.26
9/11/2014	2:30:00 PM	0.26
9/11/2014	2:45:00 PM	0.26
9/11/2014	3:00:00 PM	0.26
9/11/2014	3:15:00 PM	0.26
9/11/2014	3:30:00 PM	0.26
9/11/2014	3:45:00 PM	0.26
9/11/2014	4:00:00 PM	0.26
9/11/2014	4:15:00 PM	0.26
9/11/2014	4:30:00 PM	0.26
9/11/2014	4:45:00 PM	0.26
9/11/2014	5:00:00 PM	0.26
9/11/2014	5:15:00 PM	0.26
9/11/2014	5:30:00 PM	0.26
9/11/2014	5:45:00 PM	0.26
9/11/2014	6:00:00 PM	0.26
9/11/2014	6:15:00 PM	0.26
9/11/2014	6:30:00 PM	0.26
9/11/2014	6:45:00 PM	0.26
9/11/2014	7:00:00 PM	0.26
9/11/2014	7:15:00 PM	0.26
9/11/2014	7:30:00 PM	0.26
9/11/2014	7:45:00 PM	0.26
9/11/2014	8:00:00 PM	0.26
9/11/2014	8:15:00 PM	0.26
9/11/2014	8:30:00 PM	0.26
9/11/2014	8:45:00 PM	0.26
9/11/2014	9:00:00 PM	0.26
9/11/2014	9:15:00 PM	0.26
9/11/2014	9:30:00 PM	0.26
9/11/2014	9:45:00 PM	0.26
9/11/2014	10:00:00 PM	0.26
9/11/2014	10:15:00 PM	0.26
9/11/2014	10:30:00 PM	0.26
9/11/2014	10:45:00 PM	0.26
9/11/2014	11:00:00 PM	0.26
9/11/2014	11:15:00 PM	0.26
9/11/2014	11:30:00 PM	0.26
9/11/2014	11:45:00 PM	0.26
9/12/2014	12:00:00 AM	0.26
9/12/2014	12:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
9/12/2014	12:30:00 AM	0.26
9/12/2014	12:45:00 AM	0.26
9/12/2014	1:00:00 AM	0.26
9/12/2014	1:15:00 AM	0.26
9/12/2014	1:30:00 AM	0.26
9/12/2014	1:45:00 AM	0.26
9/12/2014	2:00:00 AM	0.26
9/12/2014	2:15:00 AM	0.26
9/12/2014	2:30:00 AM	0.26
9/12/2014	2:45:00 AM	0.26
9/12/2014	3:00:00 AM	0.26
9/12/2014	3:15:00 AM	0.26
9/12/2014	3:30:00 AM	0.26
9/12/2014	3:45:00 AM	0.26
9/12/2014	4:00:00 AM	0.26
9/12/2014	4:15:00 AM	0.26
9/12/2014	4:30:00 AM	0.26
9/12/2014	4:45:00 AM	0.26
9/12/2014	5:00:00 AM	0.26
9/12/2014	5:15:00 AM	0.26
9/12/2014	5:30:00 AM	0.26
9/12/2014	5:45:00 AM	0.26
9/12/2014	6:00:00 AM	0.26
9/12/2014	6:15:00 AM	0.26
9/12/2014	6:30:00 AM	0.26
9/12/2014	6:45:00 AM	0.26
9/12/2014	7:00:00 AM	0.26
9/12/2014	7:15:00 AM	0.26
9/12/2014	7:30:00 AM	0.26
9/12/2014	7:45:00 AM	0.26
9/12/2014	8:00:00 AM	0.26
9/12/2014	8:15:00 AM	0.26
9/12/2014	8:30:00 AM	0.26
9/12/2014	8:45:00 AM	0.26
9/12/2014	9:00:00 AM	0.26
9/12/2014	9:15:00 AM	0.26
9/12/2014	9:30:00 AM	0.26
9/12/2014	9:45:00 AM	0.26
9/12/2014	10:00:00 AM	0.26
9/12/2014	10:15:00 AM	0.26
9/12/2014	10:30:00 AM	0.26
9/12/2014	10:45:00 AM	0.26
9/12/2014	11:00:00 AM	0.26
9/12/2014	11:15:00 AM	0.26
9/12/2014	11:30:00 AM	0.26
9/12/2014	11:45:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
9/12/2014	12:00:00 PM	0.26
9/12/2014	12:15:00 PM	0.26
9/12/2014	12:30:00 PM	0.26
9/12/2014	12:45:00 PM	0.26
9/12/2014	1:00:00 PM	0.26
9/12/2014	1:15:00 PM	0.26
9/12/2014	1:30:00 PM	0.26
9/12/2014	1:45:00 PM	0.26
9/12/2014	2:00:00 PM	0.26
9/12/2014	2:15:00 PM	0.26
9/12/2014	2:30:00 PM	0.26
9/12/2014	2:45:00 PM	0.26
9/12/2014	3:00:00 PM	0.26
9/12/2014	3:15:00 PM	0.26
9/12/2014	3:30:00 PM	0.26
9/12/2014	3:45:00 PM	0.26
9/12/2014	4:00:00 PM	0.26
9/12/2014	4:15:00 PM	0.26
9/12/2014	4:30:00 PM	0.26
9/12/2014	4:45:00 PM	0.26
9/12/2014	5:00:00 PM	0.26
9/12/2014	5:15:00 PM	0.26
9/12/2014	5:30:00 PM	0.26
9/12/2014	5:45:00 PM	0.26
9/12/2014	6:00:00 PM	0.26
9/12/2014	6:15:00 PM	0.26
9/12/2014	6:30:00 PM	0.26
9/12/2014	6:45:00 PM	0.26
9/12/2014	7:00:00 PM	0.26
9/12/2014	7:15:00 PM	0.26
9/12/2014	7:30:00 PM	0.26
9/12/2014	7:45:00 PM	0.26
9/12/2014	8:00:00 PM	0.26
9/12/2014	8:15:00 PM	0.26
9/12/2014	8:30:00 PM	0.26
9/12/2014	8:45:00 PM	0.26
9/12/2014	9:00:00 PM	0.26
9/12/2014	9:15:00 PM	0.26
9/12/2014	9:30:00 PM	0.26
9/12/2014	9:45:00 PM	0.26
9/12/2014	10:00:00 PM	0.26
9/12/2014	10:15:00 PM	0.26
9/12/2014	10:30:00 PM	0.26
9/12/2014	10:45:00 PM	0.26
9/12/2014	11:00:00 PM	0.26
9/12/2014	11:15:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
9/12/2014	11:30:00 PM	0.26
9/12/2014	11:45:00 PM	0.26
9/13/2014	12:00:00 AM	0.26
9/13/2014	12:15:00 AM	0.26
9/13/2014	12:30:00 AM	0.26
9/13/2014	12:45:00 AM	0.26
9/13/2014	1:00:00 AM	0.26
9/13/2014	1:15:00 AM	0.26
9/13/2014	1:30:00 AM	0.27
9/13/2014	1:45:00 AM	0.27
9/13/2014	2:00:00 AM	0.27
9/13/2014	2:15:00 AM	0.27
9/13/2014	2:30:00 AM	0.27
9/13/2014	2:45:00 AM	0.27
9/13/2014	3:00:00 AM	0.27
9/13/2014	3:15:00 AM	0.27
9/13/2014	3:30:00 AM	0.27
9/13/2014	3:45:00 AM	0.27
9/13/2014	4:00:00 AM	0.27
9/13/2014	4:15:00 AM	0.27
9/13/2014	4:30:00 AM	0.27
9/13/2014	4:45:00 AM	0.27
9/13/2014	5:00:00 AM	0.27
9/13/2014	5:15:00 AM	0.27
9/13/2014	5:30:00 AM	0.27
9/13/2014	5:45:00 AM	0.27
9/13/2014	6:00:00 AM	0.27
9/13/2014	6:15:00 AM	0.27
9/13/2014	6:30:00 AM	0.27
9/13/2014	6:45:00 AM	0.27
9/13/2014	7:00:00 AM	0.27
9/13/2014	7:15:00 AM	0.27
9/13/2014	7:30:00 AM	0.27
9/13/2014	7:45:00 AM	0.27
9/13/2014	8:00:00 AM	0.27
9/13/2014	8:15:00 AM	0.27
9/13/2014	8:30:00 AM	0.27
9/13/2014	8:45:00 AM	0.27
9/13/2014	9:00:00 AM	0.27
9/13/2014	9:15:00 AM	0.27
9/13/2014	9:30:00 AM	0.27
9/13/2014	9:45:00 AM	0.27
9/13/2014	10:00:00 AM	0.27
9/13/2014	10:15:00 AM	0.27
9/13/2014	10:30:00 AM	0.27
9/13/2014	10:45:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
9/13/2014	11:00:00 AM	0.27
9/13/2014	11:15:00 AM	0.27
9/13/2014	11:30:00 AM	0.27
9/13/2014	11:45:00 AM	0.27
9/13/2014	12:00:00 PM	0.27
9/13/2014	12:15:00 PM	0.27
9/13/2014	12:30:00 PM	0.27
9/13/2014	12:45:00 PM	0.27
9/13/2014	1:00:00 PM	0.27
9/13/2014	1:15:00 PM	0.27
9/13/2014	1:30:00 PM	0.27
9/13/2014	1:45:00 PM	0.27
9/13/2014	2:00:00 PM	0.27
9/13/2014	2:15:00 PM	0.27
9/13/2014	2:30:00 PM	0.27
9/13/2014	2:45:00 PM	0.27
9/13/2014	3:00:00 PM	0.27
9/13/2014	3:15:00 PM	0.27
9/13/2014	3:30:00 PM	0.27
9/13/2014	3:45:00 PM	0.27
9/13/2014	4:00:00 PM	0.27
9/13/2014	4:15:00 PM	0.27
9/13/2014	4:30:00 PM	0.27
9/13/2014	4:45:00 PM	0.27
9/13/2014	5:00:00 PM	0.27
9/13/2014	5:15:00 PM	0.27
9/13/2014	5:30:00 PM	0.27
9/13/2014	5:45:00 PM	0.27
9/13/2014	6:00:00 PM	0.27
9/13/2014	6:15:00 PM	0.27
9/13/2014	6:30:00 PM	0.27
9/13/2014	6:45:00 PM	0.27
9/13/2014	7:00:00 PM	0.27
9/13/2014	7:15:00 PM	0.27
9/13/2014	7:30:00 PM	0.27
9/13/2014	7:45:00 PM	0.28
9/13/2014	8:00:00 PM	0.28
9/13/2014	8:15:00 PM	0.28
9/13/2014	8:30:00 PM	0.28
9/13/2014	8:45:00 PM	0.28
9/13/2014	9:00:00 PM	0.28
9/13/2014	9:15:00 PM	0.28
9/13/2014	9:30:00 PM	0.28
9/13/2014	9:45:00 PM	0.28
9/13/2014	10:00:00 PM	0.28
9/13/2014	10:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/13/2014	10:30:00 PM	0.28
9/13/2014	10:45:00 PM	0.28
9/13/2014	11:00:00 PM	0.28
9/13/2014	11:15:00 PM	0.28
9/13/2014	11:30:00 PM	0.28
9/13/2014	11:45:00 PM	0.28
9/14/2014	12:00:00 AM	0.28
9/14/2014	12:15:00 AM	0.28
9/14/2014	12:30:00 AM	0.28
9/14/2014	12:45:00 AM	0.28
9/14/2014	1:00:00 AM	0.28
9/14/2014	1:15:00 AM	0.28
9/14/2014	1:30:00 AM	0.28
9/14/2014	1:45:00 AM	0.28
9/14/2014	2:00:00 AM	0.28
9/14/2014	2:15:00 AM	0.28
9/14/2014	2:30:00 AM	0.28
9/14/2014	2:45:00 AM	0.28
9/14/2014	3:00:00 AM	0.28
9/14/2014	3:15:00 AM	0.28
9/14/2014	3:30:00 AM	0.28
9/14/2014	3:45:00 AM	0.28
9/14/2014	4:00:00 AM	0.28
9/14/2014	4:15:00 AM	0.28
9/14/2014	4:30:00 AM	0.28
9/14/2014	4:45:00 AM	0.28
9/14/2014	5:00:00 AM	0.28
9/14/2014	5:15:00 AM	0.28
9/14/2014	5:30:00 AM	0.28
9/14/2014	5:45:00 AM	0.28
9/14/2014	6:00:00 AM	0.28
9/14/2014	6:15:00 AM	0.28
9/14/2014	6:30:00 AM	0.28
9/14/2014	6:45:00 AM	0.28
9/14/2014	7:00:00 AM	0.28
9/14/2014	7:15:00 AM	0.28
9/14/2014	7:30:00 AM	0.28
9/14/2014	7:45:00 AM	0.28
9/14/2014	8:00:00 AM	0.28
9/14/2014	8:15:00 AM	0.28
9/14/2014	8:30:00 AM	0.28
9/14/2014	8:45:00 AM	0.28
9/14/2014	9:00:00 AM	0.28
9/14/2014	9:15:00 AM	0.28
9/14/2014	9:30:00 AM	0.28
9/14/2014	9:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/14/2014	10:00:00 AM	0.28
9/14/2014	10:15:00 AM	0.28
9/14/2014	10:30:00 AM	0.28
9/14/2014	10:45:00 AM	0.28
9/14/2014	11:00:00 AM	0.28
9/14/2014	11:15:00 AM	0.28
9/14/2014	11:30:00 AM	0.28
9/14/2014	11:45:00 AM	0.28
9/14/2014	12:00:00 PM	0.28
9/14/2014	12:15:00 PM	0.28
9/14/2014	12:30:00 PM	0.28
9/14/2014	12:45:00 PM	0.28
9/14/2014	1:00:00 PM	0.28
9/14/2014	1:15:00 PM	0.28
9/14/2014	1:30:00 PM	0.28
9/14/2014	1:45:00 PM	0.28
9/14/2014	2:00:00 PM	0.28
9/14/2014	2:15:00 PM	0.28
9/14/2014	2:30:00 PM	0.28
9/14/2014	2:45:00 PM	0.28
9/14/2014	3:00:00 PM	0.28
9/14/2014	3:15:00 PM	0.28
9/14/2014	3:30:00 PM	0.28
9/14/2014	3:45:00 PM	0.28
9/14/2014	4:00:00 PM	0.28
9/14/2014	4:15:00 PM	0.28
9/14/2014	4:30:00 PM	0.28
9/14/2014	4:45:00 PM	0.28
9/14/2014	5:00:00 PM	0.28
9/14/2014	5:15:00 PM	0.28
9/14/2014	5:30:00 PM	0.28
9/14/2014	5:45:00 PM	0.28
9/14/2014	6:00:00 PM	0.28
9/14/2014	6:15:00 PM	0.28
9/14/2014	6:30:00 PM	0.28
9/14/2014	6:45:00 PM	0.28
9/14/2014	7:00:00 PM	0.28
9/14/2014	7:15:00 PM	0.28
9/14/2014	7:30:00 PM	0.28
9/14/2014	7:45:00 PM	0.28
9/14/2014	8:00:00 PM	0.28
9/14/2014	8:15:00 PM	0.28
9/14/2014	8:30:00 PM	0.28
9/14/2014	8:45:00 PM	0.28
9/14/2014	9:00:00 PM	0.28
9/14/2014	9:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/14/2014	9:30:00 PM	0.28
9/14/2014	9:45:00 PM	0.28
9/14/2014	10:00:00 PM	0.28
9/14/2014	10:15:00 PM	0.28
9/14/2014	10:30:00 PM	0.28
9/14/2014	10:45:00 PM	0.28
9/14/2014	11:00:00 PM	0.28
9/14/2014	11:15:00 PM	0.28
9/14/2014	11:30:00 PM	0.28
9/14/2014	11:45:00 PM	0.28
9/15/2014	12:00:00 AM	0.28
9/15/2014	12:15:00 AM	0.28
9/15/2014	12:30:00 AM	0.28
9/15/2014	12:45:00 AM	0.28
9/15/2014	1:00:00 AM	0.28
9/15/2014	1:15:00 AM	0.28
9/15/2014	1:30:00 AM	0.28
9/15/2014	1:45:00 AM	0.28
9/15/2014	2:00:00 AM	0.28
9/15/2014	2:15:00 AM	0.28
9/15/2014	2:30:00 AM	0.28
9/15/2014	2:45:00 AM	0.28
9/15/2014	3:00:00 AM	0.28
9/15/2014	3:15:00 AM	0.28
9/15/2014	3:30:00 AM	0.28
9/15/2014	3:45:00 AM	0.28
9/15/2014	4:00:00 AM	0.28
9/15/2014	4:15:00 AM	0.28
9/15/2014	4:30:00 AM	0.28
9/15/2014	4:45:00 AM	0.28
9/15/2014	5:00:00 AM	0.28
9/15/2014	5:15:00 AM	0.28
9/15/2014	5:30:00 AM	0.28
9/15/2014	5:45:00 AM	0.28
9/15/2014	6:00:00 AM	0.28
9/15/2014	6:15:00 AM	0.28
9/15/2014	6:30:00 AM	0.28
9/15/2014	6:45:00 AM	0.28
9/15/2014	7:00:00 AM	0.28
9/15/2014	7:15:00 AM	0.28
9/15/2014	7:30:00 AM	0.28
9/15/2014	7:45:00 AM	0.28
9/15/2014	8:00:00 AM	0.28
9/15/2014	8:15:00 AM	0.28
9/15/2014	8:30:00 AM	0.28
9/15/2014	8:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/15/2014	9:00:00 AM	0.28
9/15/2014	9:15:00 AM	0.28
9/15/2014	9:30:00 AM	0.28
9/15/2014	9:45:00 AM	0.28
9/15/2014	10:00:00 AM	0.28
9/15/2014	10:15:00 AM	0.28
9/15/2014	10:30:00 AM	0.28
9/15/2014	10:45:00 AM	0.28
9/15/2014	11:00:00 AM	0.28
9/15/2014	11:15:00 AM	0.28
9/15/2014	11:30:00 AM	0.28
9/15/2014	11:45:00 AM	0.28
9/15/2014	12:00:00 PM	0.28
9/15/2014	12:15:00 PM	0.28
9/15/2014	12:30:00 PM	0.28
9/15/2014	12:45:00 PM	0.28
9/15/2014	1:00:00 PM	0.28
9/15/2014	1:15:00 PM	0.28
9/15/2014	1:30:00 PM	0.28
9/15/2014	1:45:00 PM	0.28
9/15/2014	2:00:00 PM	0.28
9/15/2014	2:15:00 PM	0.28
9/15/2014	2:30:00 PM	0.28
9/15/2014	2:45:00 PM	0.28
9/15/2014	3:00:00 PM	0.28
9/15/2014	3:15:00 PM	0.28
9/15/2014	3:30:00 PM	0.28
9/15/2014	3:45:00 PM	0.28
9/15/2014	4:00:00 PM	0.28
9/15/2014	4:15:00 PM	0.28
9/15/2014	4:30:00 PM	0.28
9/15/2014	4:45:00 PM	0.28
9/15/2014	5:00:00 PM	0.28
9/15/2014	5:15:00 PM	0.28
9/15/2014	5:30:00 PM	0.28
9/15/2014	5:45:00 PM	0.28
9/15/2014	6:00:00 PM	0.28
9/15/2014	6:15:00 PM	0.28
9/15/2014	6:30:00 PM	0.28
9/15/2014	6:45:00 PM	0.28
9/15/2014	7:00:00 PM	0.28
9/15/2014	7:15:00 PM	0.28
9/15/2014	7:30:00 PM	0.28
9/15/2014	7:45:00 PM	0.28
9/15/2014	8:00:00 PM	0.28
9/15/2014	8:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/15/2014	8:30:00 PM	0.28
9/15/2014	8:45:00 PM	0.28
9/15/2014	9:00:00 PM	0.28
9/15/2014	9:15:00 PM	0.28
9/15/2014	9:30:00 PM	0.28
9/15/2014	9:45:00 PM	0.28
9/15/2014	10:00:00 PM	0.28
9/15/2014	10:15:00 PM	0.28
9/15/2014	10:30:00 PM	0.28
9/15/2014	10:45:00 PM	0.28
9/15/2014	11:00:00 PM	0.28
9/15/2014	11:15:00 PM	0.28
9/15/2014	11:30:00 PM	0.28
9/15/2014	11:45:00 PM	0.28
9/16/2014	12:00:00 AM	0.28
9/16/2014	12:15:00 AM	0.28
9/16/2014	12:30:00 AM	0.28
9/16/2014	12:45:00 AM	0.28
9/16/2014	1:00:00 AM	0.28
9/16/2014	1:15:00 AM	0.28
9/16/2014	1:30:00 AM	0.28
9/16/2014	1:45:00 AM	0.28
9/16/2014	2:00:00 AM	0.28
9/16/2014	2:15:00 AM	0.28
9/16/2014	2:30:00 AM	0.28
9/16/2014	2:45:00 AM	0.28
9/16/2014	3:00:00 AM	0.28
9/16/2014	3:15:00 AM	0.28
9/16/2014	3:30:00 AM	0.28
9/16/2014	3:45:00 AM	0.28
9/16/2014	4:00:00 AM	0.28
9/16/2014	4:15:00 AM	0.28
9/16/2014	4:30:00 AM	0.28
9/16/2014	4:45:00 AM	0.28
9/16/2014	5:00:00 AM	0.28
9/16/2014	5:15:00 AM	0.28
9/16/2014	5:30:00 AM	0.28
9/16/2014	5:45:00 AM	0.28
9/16/2014	6:00:00 AM	0.28
9/16/2014	6:15:00 AM	0.28
9/16/2014	6:30:00 AM	0.28
9/16/2014	6:45:00 AM	0.28
9/16/2014	7:00:00 AM	0.28
9/16/2014	7:15:00 AM	0.28
9/16/2014	7:30:00 AM	0.28
9/16/2014	7:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/16/2014	8:00:00 AM	0.28
9/16/2014	8:15:00 AM	0.28
9/16/2014	8:30:00 AM	0.28
9/16/2014	8:45:00 AM	0.28
9/16/2014	9:00:00 AM	0.28
9/16/2014	9:15:00 AM	0.28
9/16/2014	9:30:00 AM	0.28
9/16/2014	9:45:00 AM	0.28
9/16/2014	10:00:00 AM	0.28
9/16/2014	10:15:00 AM	0.28
9/16/2014	10:30:00 AM	0.28
9/16/2014	10:45:00 AM	0.28
9/16/2014	11:00:00 AM	0.28
9/16/2014	11:15:00 AM	0.28
9/16/2014	11:30:00 AM	0.28
9/16/2014	11:45:00 AM	0.28
9/16/2014	12:00:00 PM	0.29
9/16/2014	12:15:00 PM	0.29
9/16/2014	12:30:00 PM	0.29
9/16/2014	12:45:00 PM	0.29
9/16/2014	1:00:00 PM	0.29
9/16/2014	1:15:00 PM	0.29
9/16/2014	1:30:00 PM	0.29
9/16/2014	1:45:00 PM	0.29
9/16/2014	2:00:00 PM	0.29
9/16/2014	2:15:00 PM	0.29
9/16/2014	2:30:00 PM	0.29
9/16/2014	2:45:00 PM	0.29
9/16/2014	3:00:00 PM	0.28
9/16/2014	3:15:00 PM	0.28
9/16/2014	3:30:00 PM	0.28
9/16/2014	3:45:00 PM	0.28
9/16/2014	4:00:00 PM	0.28
9/16/2014	4:15:00 PM	0.28
9/16/2014	4:30:00 PM	0.28
9/16/2014	4:45:00 PM	0.28
9/16/2014	5:00:00 PM	0.28
9/16/2014	5:15:00 PM	0.28
9/16/2014	5:30:00 PM	0.28
9/16/2014	5:45:00 PM	0.28
9/16/2014	6:00:00 PM	0.28
9/16/2014	6:15:00 PM	0.28
9/16/2014	6:30:00 PM	0.28
9/16/2014	6:45:00 PM	0.28
9/16/2014	7:00:00 PM	0.28
9/16/2014	7:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/16/2014	7:30:00 PM	0.28
9/16/2014	7:45:00 PM	0.28
9/16/2014	8:00:00 PM	0.28
9/16/2014	8:15:00 PM	0.28
9/16/2014	8:30:00 PM	0.28
9/16/2014	8:45:00 PM	0.28
9/16/2014	9:00:00 PM	0.28
9/16/2014	9:15:00 PM	0.28
9/16/2014	9:30:00 PM	0.28
9/16/2014	9:45:00 PM	0.28
9/16/2014	10:00:00 PM	0.28
9/16/2014	10:15:00 PM	0.28
9/16/2014	10:30:00 PM	0.28
9/16/2014	10:45:00 PM	0.28
9/16/2014	11:00:00 PM	0.28
9/16/2014	11:15:00 PM	0.28
9/16/2014	11:30:00 PM	0.28
9/16/2014	11:45:00 PM	0.28
9/17/2014	12:00:00 AM	0.28
9/17/2014	12:15:00 AM	0.28
9/17/2014	12:30:00 AM	0.28
9/17/2014	12:45:00 AM	0.28
9/17/2014	1:00:00 AM	0.28
9/17/2014	1:15:00 AM	0.28
9/17/2014	1:30:00 AM	0.28
9/17/2014	1:45:00 AM	0.28
9/17/2014	2:00:00 AM	0.28
9/17/2014	2:15:00 AM	0.28
9/17/2014	2:30:00 AM	0.28
9/17/2014	2:45:00 AM	0.28
9/17/2014	3:00:00 AM	0.28
9/17/2014	3:15:00 AM	0.28
9/17/2014	3:30:00 AM	0.28
9/17/2014	3:45:00 AM	0.28
9/17/2014	4:00:00 AM	0.28
9/17/2014	4:15:00 AM	0.28
9/17/2014	4:30:00 AM	0.28
9/17/2014	4:45:00 AM	0.28
9/17/2014	5:00:00 AM	0.29
9/17/2014	5:15:00 AM	0.29
9/17/2014	5:30:00 AM	0.29
9/17/2014	5:45:00 AM	0.29
9/17/2014	6:00:00 AM	0.29
9/17/2014	6:15:00 AM	0.29
9/17/2014	6:30:00 AM	0.29
9/17/2014	6:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
9/17/2014	7:00:00 AM	0.29
9/17/2014	7:15:00 AM	0.29
9/17/2014	7:30:00 AM	0.29
9/17/2014	7:45:00 AM	0.29
9/17/2014	8:00:00 AM	0.29
9/17/2014	8:15:00 AM	0.29
9/17/2014	8:30:00 AM	0.29
9/17/2014	8:45:00 AM	0.29
9/17/2014	9:00:00 AM	0.29
9/17/2014	9:15:00 AM	0.29
9/17/2014	9:30:00 AM	0.29
9/17/2014	9:45:00 AM	0.29
9/17/2014	10:00:00 AM	0.29
9/17/2014	10:15:00 AM	0.29
9/17/2014	10:30:00 AM	0.29
9/17/2014	10:45:00 AM	0.29
9/17/2014	11:00:00 AM	0.29
9/17/2014	11:15:00 AM	0.29
9/17/2014	11:30:00 AM	0.29
9/17/2014	11:45:00 AM	0.29
9/17/2014	12:00:00 PM	0.29
9/17/2014	12:15:00 PM	0.29
9/17/2014	12:30:00 PM	0.29
9/17/2014	12:45:00 PM	0.28
9/17/2014	1:00:00 PM	0.28
9/17/2014	1:15:00 PM	0.28
9/17/2014	1:30:00 PM	0.28
9/17/2014	1:45:00 PM	0.28
9/17/2014	2:00:00 PM	0.28
9/17/2014	2:15:00 PM	0.28
9/17/2014	2:30:00 PM	0.28
9/17/2014	2:45:00 PM	0.28
9/17/2014	3:00:00 PM	0.28
9/17/2014	3:15:00 PM	0.28
9/17/2014	3:30:00 PM	0.28
9/17/2014	3:45:00 PM	0.28
9/17/2014	4:00:00 PM	0.28
9/17/2014	4:15:00 PM	0.28
9/17/2014	4:30:00 PM	0.28
9/17/2014	4:45:00 PM	0.28
9/17/2014	5:00:00 PM	0.28
9/17/2014	5:15:00 PM	0.28
9/17/2014	5:30:00 PM	0.28
9/17/2014	5:45:00 PM	0.28
9/17/2014	6:00:00 PM	0.28
9/17/2014	6:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/17/2014	6:30:00 PM	0.28
9/17/2014	6:45:00 PM	0.28
9/17/2014	7:00:00 PM	0.28
9/17/2014	7:15:00 PM	0.28
9/17/2014	7:30:00 PM	0.28
9/17/2014	7:45:00 PM	0.28
9/17/2014	8:00:00 PM	0.28
9/17/2014	8:15:00 PM	0.28
9/17/2014	8:30:00 PM	0.28
9/17/2014	8:45:00 PM	0.28
9/17/2014	9:00:00 PM	0.28
9/17/2014	9:15:00 PM	0.28
9/17/2014	9:30:00 PM	0.28
9/17/2014	9:45:00 PM	0.28
9/17/2014	10:00:00 PM	0.28
9/17/2014	10:15:00 PM	0.28
9/17/2014	10:30:00 PM	0.28
9/17/2014	10:45:00 PM	0.28
9/17/2014	11:00:00 PM	0.28
9/17/2014	11:15:00 PM	0.28
9/17/2014	11:30:00 PM	0.28
9/17/2014	11:45:00 PM	0.28
9/18/2014	12:00:00 AM	0.28
9/18/2014	12:15:00 AM	0.28
9/18/2014	12:30:00 AM	0.28
9/18/2014	12:45:00 AM	0.28
9/18/2014	1:00:00 AM	0.28
9/18/2014	1:15:00 AM	0.28
9/18/2014	1:30:00 AM	0.28
9/18/2014	1:45:00 AM	0.28
9/18/2014	2:00:00 AM	0.28
9/18/2014	2:15:00 AM	0.28
9/18/2014	2:30:00 AM	0.28
9/18/2014	2:45:00 AM	0.28
9/18/2014	3:00:00 AM	0.28
9/18/2014	3:15:00 AM	0.28
9/18/2014	3:30:00 AM	0.28
9/18/2014	3:45:00 AM	0.28
9/18/2014	4:00:00 AM	0.28
9/18/2014	4:15:00 AM	0.28
9/18/2014	4:30:00 AM	0.28
9/18/2014	4:45:00 AM	0.28
9/18/2014	5:00:00 AM	0.28
9/18/2014	5:15:00 AM	0.28
9/18/2014	5:30:00 AM	0.28
9/18/2014	5:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/18/2014	6:00:00 AM	0.28
9/18/2014	6:15:00 AM	0.28
9/18/2014	6:30:00 AM	0.28
9/18/2014	6:45:00 AM	0.28
9/18/2014	7:00:00 AM	0.28
9/18/2014	7:15:00 AM	0.28
9/18/2014	7:30:00 AM	0.28
9/18/2014	7:45:00 AM	0.28
9/18/2014	8:00:00 AM	0.28
9/18/2014	8:15:00 AM	0.28
9/18/2014	8:30:00 AM	0.28
9/18/2014	8:45:00 AM	0.28
9/18/2014	9:00:00 AM	0.28
9/18/2014	9:15:00 AM	0.28
9/18/2014	9:30:00 AM	0.28
9/18/2014	9:45:00 AM	0.28
9/18/2014	10:00:00 AM	0.28
9/18/2014	10:15:00 AM	0.28
9/18/2014	10:30:00 AM	0.28
9/18/2014	10:45:00 AM	0.28
9/18/2014	11:00:00 AM	0.28
9/18/2014	11:15:00 AM	0.28
9/18/2014	11:30:00 AM	0.28
9/18/2014	11:45:00 AM	0.28
9/18/2014	12:00:00 PM	0.28
9/18/2014	12:15:00 PM	0.28
9/18/2014	12:30:00 PM	0.28
9/18/2014	12:45:00 PM	0.28
9/18/2014	1:00:00 PM	0.28
9/18/2014	1:15:00 PM	0.28
9/18/2014	1:30:00 PM	0.28
9/18/2014	1:45:00 PM	0.28
9/18/2014	2:00:00 PM	0.28
9/18/2014	2:15:00 PM	0.28
9/18/2014	2:30:00 PM	0.28
9/18/2014	2:45:00 PM	0.28
9/18/2014	3:00:00 PM	0.28
9/18/2014	3:15:00 PM	0.28
9/18/2014	3:30:00 PM	0.28
9/18/2014	3:45:00 PM	0.28
9/18/2014	4:00:00 PM	0.28
9/18/2014	4:15:00 PM	0.28
9/18/2014	4:30:00 PM	0.28
9/18/2014	4:45:00 PM	0.28
9/18/2014	5:00:00 PM	0.28
9/18/2014	5:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/18/2014	5:30:00 PM	0.28
9/18/2014	5:45:00 PM	0.28
9/18/2014	6:00:00 PM	0.28
9/18/2014	6:15:00 PM	0.28
9/18/2014	6:30:00 PM	0.28
9/18/2014	6:45:00 PM	0.28
9/18/2014	7:00:00 PM	0.28
9/18/2014	7:15:00 PM	0.28
9/18/2014	7:30:00 PM	0.28
9/18/2014	7:45:00 PM	0.28
9/18/2014	8:00:00 PM	0.28
9/18/2014	8:15:00 PM	0.28
9/18/2014	8:30:00 PM	0.28
9/18/2014	8:45:00 PM	0.28
9/18/2014	9:00:00 PM	0.28
9/18/2014	9:15:00 PM	0.28
9/18/2014	9:30:00 PM	0.28
9/18/2014	9:45:00 PM	0.28
9/18/2014	10:00:00 PM	0.28
9/18/2014	10:15:00 PM	0.28
9/18/2014	10:30:00 PM	0.28
9/18/2014	10:45:00 PM	0.28
9/18/2014	11:00:00 PM	0.28
9/18/2014	11:15:00 PM	0.28
9/18/2014	11:30:00 PM	0.28
9/18/2014	11:45:00 PM	0.28
9/19/2014	12:00:00 AM	0.28
9/19/2014	12:15:00 AM	0.28
9/19/2014	12:30:00 AM	0.28
9/19/2014	12:45:00 AM	0.28
9/19/2014	1:00:00 AM	0.28
9/19/2014	1:15:00 AM	0.28
9/19/2014	1:30:00 AM	0.28
9/19/2014	1:45:00 AM	0.28
9/19/2014	2:00:00 AM	0.28
9/19/2014	2:15:00 AM	0.28
9/19/2014	2:30:00 AM	0.28
9/19/2014	2:45:00 AM	0.28
9/19/2014	3:00:00 AM	0.28
9/19/2014	3:15:00 AM	0.28
9/19/2014	3:30:00 AM	0.28
9/19/2014	3:45:00 AM	0.28
9/19/2014	4:00:00 AM	0.28
9/19/2014	4:15:00 AM	0.28
9/19/2014	4:30:00 AM	0.28
9/19/2014	4:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/19/2014	5:00:00 AM	0.28
9/19/2014	5:15:00 AM	0.28
9/19/2014	5:30:00 AM	0.28
9/19/2014	5:45:00 AM	0.28
9/19/2014	6:00:00 AM	0.28
9/19/2014	6:15:00 AM	0.28
9/19/2014	6:30:00 AM	0.28
9/19/2014	6:45:00 AM	0.28
9/19/2014	7:00:00 AM	0.28
9/19/2014	7:15:00 AM	0.28
9/19/2014	7:30:00 AM	0.28
9/19/2014	7:45:00 AM	0.28
9/19/2014	8:00:00 AM	0.28
9/19/2014	8:15:00 AM	0.28
9/19/2014	8:30:00 AM	0.28
9/19/2014	8:45:00 AM	0.28
9/19/2014	9:00:00 AM	0.28
9/19/2014	9:15:00 AM	0.28
9/19/2014	9:30:00 AM	0.28
9/19/2014	9:45:00 AM	0.28
9/19/2014	10:00:00 AM	0.28
9/19/2014	10:15:00 AM	0.28
9/19/2014	10:30:00 AM	0.28
9/19/2014	10:45:00 AM	0.28
9/19/2014	11:00:00 AM	0.28
9/19/2014	11:15:00 AM	0.28
9/19/2014	11:30:00 AM	0.28
9/19/2014	11:45:00 AM	0.28
9/19/2014	12:00:00 PM	0.28
9/19/2014	12:15:00 PM	0.28
9/19/2014	12:30:00 PM	0.28
9/19/2014	12:45:00 PM	0.28
9/19/2014	1:00:00 PM	0.28
9/19/2014	1:15:00 PM	0.28
9/19/2014	1:30:00 PM	0.28
9/19/2014	1:45:00 PM	0.28
9/19/2014	2:00:00 PM	0.28
9/19/2014	2:15:00 PM	0.28
9/19/2014	2:30:00 PM	0.28
9/19/2014	2:45:00 PM	0.28
9/19/2014	3:00:00 PM	0.28
9/19/2014	3:15:00 PM	0.28
9/19/2014	3:30:00 PM	0.28
9/19/2014	3:45:00 PM	0.28
9/19/2014	4:00:00 PM	0.28
9/19/2014	4:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/19/2014	4:30:00 PM	0.28
9/19/2014	4:45:00 PM	0.28
9/19/2014	5:00:00 PM	0.28
9/19/2014	5:15:00 PM	0.28
9/19/2014	5:30:00 PM	0.28
9/19/2014	5:45:00 PM	0.28
9/19/2014	6:00:00 PM	0.28
9/19/2014	6:15:00 PM	0.28
9/19/2014	6:30:00 PM	0.28
9/19/2014	6:45:00 PM	0.28
9/19/2014	7:00:00 PM	0.28
9/19/2014	7:15:00 PM	0.28
9/19/2014	7:30:00 PM	0.28
9/19/2014	7:45:00 PM	0.28
9/19/2014	8:00:00 PM	0.28
9/19/2014	8:15:00 PM	0.28
9/19/2014	8:30:00 PM	0.28
9/19/2014	8:45:00 PM	0.28
9/19/2014	9:00:00 PM	0.28
9/19/2014	9:15:00 PM	0.28
9/19/2014	9:30:00 PM	0.28
9/19/2014	9:45:00 PM	0.28
9/19/2014	10:00:00 PM	0.28
9/19/2014	10:15:00 PM	0.28
9/19/2014	10:30:00 PM	0.28
9/19/2014	10:45:00 PM	0.28
9/19/2014	11:00:00 PM	0.28
9/19/2014	11:15:00 PM	0.28
9/19/2014	11:30:00 PM	0.28
9/19/2014	11:45:00 PM	0.28
9/20/2014	12:00:00 AM	0.28
9/20/2014	12:15:00 AM	0.28
9/20/2014	12:30:00 AM	0.28
9/20/2014	12:45:00 AM	0.28
9/20/2014	1:00:00 AM	0.28
9/20/2014	1:15:00 AM	0.28
9/20/2014	1:30:00 AM	0.28
9/20/2014	1:45:00 AM	0.28
9/20/2014	2:00:00 AM	0.28
9/20/2014	2:15:00 AM	0.28
9/20/2014	2:30:00 AM	0.28
9/20/2014	2:45:00 AM	0.28
9/20/2014	3:00:00 AM	0.28
9/20/2014	3:15:00 AM	0.28
9/20/2014	3:30:00 AM	0.28
9/20/2014	3:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/20/2014	4:00:00 AM	0.28
9/20/2014	4:15:00 AM	0.28
9/20/2014	4:30:00 AM	0.28
9/20/2014	4:45:00 AM	0.28
9/20/2014	5:00:00 AM	0.28
9/20/2014	5:15:00 AM	0.28
9/20/2014	5:30:00 AM	0.28
9/20/2014	5:45:00 AM	0.28
9/20/2014	6:00:00 AM	0.28
9/20/2014	6:15:00 AM	0.28
9/20/2014	6:30:00 AM	0.28
9/20/2014	6:45:00 AM	0.28
9/20/2014	7:00:00 AM	0.28
9/20/2014	7:15:00 AM	0.28
9/20/2014	7:30:00 AM	0.28
9/20/2014	7:45:00 AM	0.28
9/20/2014	8:00:00 AM	0.28
9/20/2014	8:15:00 AM	0.28
9/20/2014	8:30:00 AM	0.28
9/20/2014	8:45:00 AM	0.28
9/20/2014	9:00:00 AM	0.28
9/20/2014	9:15:00 AM	0.28
9/20/2014	9:30:00 AM	0.28
9/20/2014	9:45:00 AM	0.28
9/20/2014	10:00:00 AM	0.28
9/20/2014	10:15:00 AM	0.28
9/20/2014	10:30:00 AM	0.28
9/20/2014	10:45:00 AM	0.28
9/20/2014	11:00:00 AM	0.28
9/20/2014	11:15:00 AM	0.28
9/20/2014	11:30:00 AM	0.28
9/20/2014	11:45:00 AM	0.28
9/20/2014	12:00:00 PM	0.29
9/20/2014	12:15:00 PM	0.29
9/20/2014	12:30:00 PM	0.29
9/20/2014	12:45:00 PM	0.29
9/20/2014	1:00:00 PM	0.29
9/20/2014	1:15:00 PM	0.29
9/20/2014	1:30:00 PM	0.29
9/20/2014	1:45:00 PM	0.29
9/20/2014	2:00:00 PM	0.29
9/20/2014	2:15:00 PM	0.29
9/20/2014	2:30:00 PM	0.29
9/20/2014	2:45:00 PM	0.29
9/20/2014	3:00:00 PM	0.29
9/20/2014	3:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
9/20/2014	3:30:00 PM	0.29
9/20/2014	3:45:00 PM	0.29
9/20/2014	4:00:00 PM	0.29
9/20/2014	4:15:00 PM	0.29
9/20/2014	4:30:00 PM	0.29
9/20/2014	4:45:00 PM	0.29
9/20/2014	5:00:00 PM	0.29
9/20/2014	5:15:00 PM	0.29
9/20/2014	5:30:00 PM	0.29
9/20/2014	5:45:00 PM	0.29
9/20/2014	6:00:00 PM	0.29
9/20/2014	6:15:00 PM	0.29
9/20/2014	6:30:00 PM	0.29
9/20/2014	6:45:00 PM	0.28
9/20/2014	7:00:00 PM	0.28
9/20/2014	7:15:00 PM	0.28
9/20/2014	7:30:00 PM	0.28
9/20/2014	7:45:00 PM	0.28
9/20/2014	8:00:00 PM	0.28
9/20/2014	8:15:00 PM	0.28
9/20/2014	8:30:00 PM	0.28
9/20/2014	8:45:00 PM	0.28
9/20/2014	9:00:00 PM	0.28
9/20/2014	9:15:00 PM	0.28
9/20/2014	9:30:00 PM	0.28
9/20/2014	9:45:00 PM	0.28
9/20/2014	10:00:00 PM	0.28
9/20/2014	10:15:00 PM	0.28
9/20/2014	10:30:00 PM	0.28
9/20/2014	10:45:00 PM	0.28
9/20/2014	11:00:00 PM	0.28
9/20/2014	11:15:00 PM	0.28
9/20/2014	11:30:00 PM	0.28
9/20/2014	11:45:00 PM	0.28
9/21/2014	12:00:00 AM	0.28
9/21/2014	12:15:00 AM	0.28
9/21/2014	12:30:00 AM	0.28
9/21/2014	12:45:00 AM	0.28
9/21/2014	1:00:00 AM	0.28
9/21/2014	1:15:00 AM	0.28
9/21/2014	1:30:00 AM	0.28
9/21/2014	1:45:00 AM	0.28
9/21/2014	2:00:00 AM	0.28
9/21/2014	2:15:00 AM	0.28
9/21/2014	2:30:00 AM	0.28
9/21/2014	2:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
9/21/2014	3:00:00 AM	0.28
9/21/2014	3:15:00 AM	0.28
9/21/2014	3:30:00 AM	0.28
9/21/2014	3:45:00 AM	0.28
9/21/2014	4:00:00 AM	0.28
9/21/2014	4:15:00 AM	0.28
9/21/2014	4:30:00 AM	0.28
9/21/2014	4:45:00 AM	0.28
9/21/2014	5:00:00 AM	0.28
9/21/2014	5:15:00 AM	0.28
9/21/2014	5:30:00 AM	0.28
9/21/2014	5:45:00 AM	0.28
9/21/2014	6:00:00 AM	0.28
9/21/2014	6:15:00 AM	0.28
9/21/2014	6:30:00 AM	0.28
9/21/2014	6:45:00 AM	0.28
9/21/2014	7:00:00 AM	0.28
9/21/2014	7:15:00 AM	0.28
9/21/2014	7:30:00 AM	0.28
9/21/2014	7:45:00 AM	0.28
9/21/2014	8:00:00 AM	0.28
9/21/2014	8:15:00 AM	0.29
9/21/2014	8:30:00 AM	0.29
9/21/2014	8:45:00 AM	0.29
9/21/2014	9:00:00 AM	0.29
9/21/2014	9:15:00 AM	0.29
9/21/2014	9:30:00 AM	0.29
9/21/2014	9:45:00 AM	0.29
9/21/2014	10:00:00 AM	0.29
9/21/2014	10:15:00 AM	0.29
9/21/2014	10:30:00 AM	0.29
9/21/2014	10:45:00 AM	0.29
9/21/2014	11:00:00 AM	0.29
9/21/2014	11:15:00 AM	0.29
9/21/2014	11:30:00 AM	0.29
9/21/2014	11:45:00 AM	0.29
9/21/2014	12:00:00 PM	0.29
9/21/2014	12:15:00 PM	0.29
9/21/2014	12:30:00 PM	0.29
9/21/2014	12:45:00 PM	0.29
9/21/2014	1:00:00 PM	0.29
9/21/2014	1:15:00 PM	0.29
9/21/2014	1:30:00 PM	0.29
9/21/2014	1:45:00 PM	0.29
9/21/2014	2:00:00 PM	0.29
9/21/2014	2:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
9/21/2014	2:30:00 PM	0.29
9/21/2014	2:45:00 PM	0.29
9/21/2014	3:00:00 PM	0.29
9/21/2014	3:15:00 PM	0.29
9/21/2014	3:30:00 PM	0.29
9/21/2014	3:45:00 PM	0.29
9/21/2014	4:00:00 PM	0.29
9/21/2014	4:15:00 PM	0.29
9/21/2014	4:30:00 PM	0.29
9/21/2014	4:45:00 PM	0.29
9/21/2014	5:00:00 PM	0.29
9/21/2014	5:15:00 PM	0.29
9/21/2014	5:30:00 PM	0.29
9/21/2014	5:45:00 PM	0.29
9/21/2014	6:00:00 PM	0.29
9/21/2014	6:15:00 PM	0.29
9/21/2014	6:30:00 PM	0.29
9/21/2014	6:45:00 PM	0.29
9/21/2014	7:00:00 PM	0.29
9/21/2014	7:15:00 PM	0.29
9/21/2014	7:30:00 PM	0.29
9/21/2014	7:45:00 PM	0.29
9/21/2014	8:00:00 PM	0.29
9/21/2014	8:15:00 PM	0.29
9/21/2014	8:30:00 PM	0.29
9/21/2014	8:45:00 PM	0.29
9/21/2014	9:00:00 PM	0.29
9/21/2014	9:15:00 PM	0.29
9/21/2014	9:30:00 PM	0.29
9/21/2014	9:45:00 PM	0.29
9/21/2014	10:00:00 PM	0.29
9/21/2014	10:15:00 PM	0.29
9/21/2014	10:30:00 PM	0.29
9/21/2014	10:45:00 PM	0.29
9/21/2014	11:00:00 PM	0.29
9/21/2014	11:15:00 PM	0.29
9/21/2014	11:30:00 PM	0.29
9/21/2014	11:45:00 PM	0.29
9/22/2014	12:00:00 AM	0.29
9/22/2014	12:15:00 AM	0.29
9/22/2014	12:30:00 AM	0.29
9/22/2014	12:45:00 AM	0.29
9/22/2014	1:00:00 AM	0.29
9/22/2014	1:15:00 AM	0.29
9/22/2014	1:30:00 AM	0.29
9/22/2014	1:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/22/2014	2:00:00 AM	0.3
9/22/2014	2:15:00 AM	0.3
9/22/2014	2:30:00 AM	0.3
9/22/2014	2:45:00 AM	0.3
9/22/2014	3:00:00 AM	0.3
9/22/2014	3:15:00 AM	0.3
9/22/2014	3:30:00 AM	0.3
9/22/2014	3:45:00 AM	0.3
9/22/2014	4:00:00 AM	0.3
9/22/2014	4:15:00 AM	0.3
9/22/2014	4:30:00 AM	0.3
9/22/2014	4:45:00 AM	0.3
9/22/2014	5:00:00 AM	0.3
9/22/2014	5:15:00 AM	0.3
9/22/2014	5:30:00 AM	0.3
9/22/2014	5:45:00 AM	0.3
9/22/2014	6:00:00 AM	0.3
9/22/2014	6:15:00 AM	0.3
9/22/2014	6:30:00 AM	0.3
9/22/2014	6:45:00 AM	0.3
9/22/2014	7:00:00 AM	0.3
9/22/2014	7:15:00 AM	0.3
9/22/2014	7:30:00 AM	0.3
9/22/2014	7:45:00 AM	0.3
9/22/2014	8:00:00 AM	0.3
9/22/2014	8:15:00 AM	0.3
9/22/2014	8:30:00 AM	0.3
9/22/2014	8:45:00 AM	0.3
9/22/2014	9:00:00 AM	0.3
9/22/2014	9:15:00 AM	0.3
9/22/2014	9:30:00 AM	0.3
9/22/2014	9:45:00 AM	0.3
9/22/2014	10:00:00 AM	0.3
9/22/2014	10:15:00 AM	0.3
9/22/2014	10:30:00 AM	0.3
9/22/2014	10:45:00 AM	0.3
9/22/2014	11:00:00 AM	0.3
9/22/2014	11:15:00 AM	0.3
9/22/2014	11:30:00 AM	0.3
9/22/2014	11:45:00 AM	0.3
9/22/2014	12:00:00 PM	0.3
9/22/2014	12:15:00 PM	0.3
9/22/2014	12:30:00 PM	0.3
9/22/2014	12:45:00 PM	0.3
9/22/2014	1:00:00 PM	0.3
9/22/2014	1:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/22/2014	1:30:00 PM	0.3
9/22/2014	1:45:00 PM	0.3
9/22/2014	2:00:00 PM	0.3
9/22/2014	2:15:00 PM	0.3
9/22/2014	2:30:00 PM	0.3
9/22/2014	2:45:00 PM	0.3
9/22/2014	3:00:00 PM	0.3
9/22/2014	3:15:00 PM	0.3
9/22/2014	3:30:00 PM	0.3
9/22/2014	3:45:00 PM	0.3
9/22/2014	4:00:00 PM	0.3
9/22/2014	4:15:00 PM	0.3
9/22/2014	4:30:00 PM	0.3
9/22/2014	4:45:00 PM	0.3
9/22/2014	5:00:00 PM	0.3
9/22/2014	5:15:00 PM	0.3
9/22/2014	5:30:00 PM	0.3
9/22/2014	5:45:00 PM	0.3
9/22/2014	6:00:00 PM	0.3
9/22/2014	6:15:00 PM	0.3
9/22/2014	6:30:00 PM	0.3
9/22/2014	6:45:00 PM	0.3
9/22/2014	7:00:00 PM	0.3
9/22/2014	7:15:00 PM	0.3
9/22/2014	7:30:00 PM	0.3
9/22/2014	7:45:00 PM	0.3
9/22/2014	8:00:00 PM	0.3
9/22/2014	8:15:00 PM	0.3
9/22/2014	8:30:00 PM	0.3
9/22/2014	8:45:00 PM	0.3
9/22/2014	9:00:00 PM	0.3
9/22/2014	9:15:00 PM	0.3
9/22/2014	9:30:00 PM	0.3
9/22/2014	9:45:00 PM	0.3
9/22/2014	10:00:00 PM	0.3
9/22/2014	10:15:00 PM	0.3
9/22/2014	10:30:00 PM	0.3
9/22/2014	10:45:00 PM	0.3
9/22/2014	11:00:00 PM	0.3
9/22/2014	11:15:00 PM	0.3
9/22/2014	11:30:00 PM	0.3
9/22/2014	11:45:00 PM	0.3
9/23/2014	12:00:00 AM	0.3
9/23/2014	12:15:00 AM	0.3
9/23/2014	12:30:00 AM	0.3
9/23/2014	12:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/23/2014	1:00:00 AM	0.3
9/23/2014	1:15:00 AM	0.3
9/23/2014	1:30:00 AM	0.3
9/23/2014	1:45:00 AM	0.3
9/23/2014	2:00:00 AM	0.3
9/23/2014	2:15:00 AM	0.3
9/23/2014	2:30:00 AM	0.3
9/23/2014	2:45:00 AM	0.3
9/23/2014	3:00:00 AM	0.3
9/23/2014	3:15:00 AM	0.3
9/23/2014	3:30:00 AM	0.3
9/23/2014	3:45:00 AM	0.3
9/23/2014	4:00:00 AM	0.3
9/23/2014	4:15:00 AM	0.3
9/23/2014	4:30:00 AM	0.3
9/23/2014	4:45:00 AM	0.3
9/23/2014	5:00:00 AM	0.3
9/23/2014	5:15:00 AM	0.3
9/23/2014	5:30:00 AM	0.3
9/23/2014	5:45:00 AM	0.3
9/23/2014	6:00:00 AM	0.3
9/23/2014	6:15:00 AM	0.3
9/23/2014	6:30:00 AM	0.3
9/23/2014	6:45:00 AM	0.3
9/23/2014	7:00:00 AM	0.3
9/23/2014	7:15:00 AM	0.3
9/23/2014	7:30:00 AM	0.3
9/23/2014	7:45:00 AM	0.3
9/23/2014	8:00:00 AM	0.3
9/23/2014	8:15:00 AM	0.3
9/23/2014	8:30:00 AM	0.3
9/23/2014	8:45:00 AM	0.3
9/23/2014	9:00:00 AM	0.3
9/23/2014	9:15:00 AM	0.3
9/23/2014	9:30:00 AM	0.3
9/23/2014	9:45:00 AM	0.3
9/23/2014	10:00:00 AM	0.3
9/23/2014	10:15:00 AM	0.3
9/23/2014	10:30:00 AM	0.3
9/23/2014	10:45:00 AM	0.3
9/23/2014	11:00:00 AM	0.3
9/23/2014	11:15:00 AM	0.3
9/23/2014	11:30:00 AM	0.3
9/23/2014	11:45:00 AM	0.3
9/23/2014	12:00:00 PM	0.3
9/23/2014	12:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/23/2014	12:30:00 PM	0.3
9/23/2014	12:45:00 PM	0.3
9/23/2014	1:00:00 PM	0.3
9/23/2014	1:15:00 PM	0.3
9/23/2014	1:30:00 PM	0.3
9/23/2014	1:45:00 PM	0.3
9/23/2014	2:00:00 PM	0.3
9/23/2014	2:15:00 PM	0.3
9/23/2014	2:30:00 PM	0.3
9/23/2014	2:45:00 PM	0.3
9/23/2014	3:00:00 PM	0.3
9/23/2014	3:15:00 PM	0.3
9/23/2014	3:30:00 PM	0.3
9/23/2014	3:45:00 PM	0.3
9/23/2014	4:00:00 PM	0.3
9/23/2014	4:15:00 PM	0.3
9/23/2014	4:30:00 PM	0.3
9/23/2014	4:45:00 PM	0.3
9/23/2014	5:00:00 PM	0.3
9/23/2014	5:15:00 PM	0.3
9/23/2014	5:30:00 PM	0.3
9/23/2014	5:45:00 PM	0.3
9/23/2014	6:00:00 PM	0.3
9/23/2014	6:15:00 PM	0.3
9/23/2014	6:30:00 PM	0.3
9/23/2014	6:45:00 PM	0.3
9/23/2014	7:00:00 PM	0.3
9/23/2014	7:15:00 PM	0.3
9/23/2014	7:30:00 PM	0.3
9/23/2014	7:45:00 PM	0.3
9/23/2014	8:00:00 PM	0.3
9/23/2014	8:15:00 PM	0.3
9/23/2014	8:30:00 PM	0.3
9/23/2014	8:45:00 PM	0.3
9/23/2014	9:00:00 PM	0.3
9/23/2014	9:15:00 PM	0.3
9/23/2014	9:30:00 PM	0.3
9/23/2014	9:45:00 PM	0.3
9/23/2014	10:00:00 PM	0.3
9/23/2014	10:15:00 PM	0.3
9/23/2014	10:30:00 PM	0.3
9/23/2014	10:45:00 PM	0.3
9/23/2014	11:00:00 PM	0.3
9/23/2014	11:15:00 PM	0.3
9/23/2014	11:30:00 PM	0.3
9/23/2014	11:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/24/2014	12:00:00 AM	0.3
9/24/2014	12:15:00 AM	0.3
9/24/2014	12:30:00 AM	0.3
9/24/2014	12:45:00 AM	0.3
9/24/2014	1:00:00 AM	0.3
9/24/2014	1:15:00 AM	0.3
9/24/2014	1:30:00 AM	0.3
9/24/2014	1:45:00 AM	0.3
9/24/2014	2:00:00 AM	0.3
9/24/2014	2:15:00 AM	0.3
9/24/2014	2:30:00 AM	0.3
9/24/2014	2:45:00 AM	0.3
9/24/2014	3:00:00 AM	0.3
9/24/2014	3:15:00 AM	0.3
9/24/2014	3:30:00 AM	0.3
9/24/2014	3:45:00 AM	0.3
9/24/2014	4:00:00 AM	0.3
9/24/2014	4:15:00 AM	0.3
9/24/2014	4:30:00 AM	0.3
9/24/2014	4:45:00 AM	0.3
9/24/2014	5:00:00 AM	0.3
9/24/2014	5:15:00 AM	0.3
9/24/2014	5:30:00 AM	0.3
9/24/2014	5:45:00 AM	0.3
9/24/2014	6:00:00 AM	0.3
9/24/2014	6:15:00 AM	0.3
9/24/2014	6:30:00 AM	0.3
9/24/2014	6:45:00 AM	0.3
9/24/2014	7:00:00 AM	0.3
9/24/2014	7:15:00 AM	0.3
9/24/2014	7:30:00 AM	0.3
9/24/2014	7:45:00 AM	0.3
9/24/2014	8:00:00 AM	0.3
9/24/2014	8:15:00 AM	0.3
9/24/2014	8:30:00 AM	0.3
9/24/2014	8:45:00 AM	0.3
9/24/2014	9:00:00 AM	0.3
9/24/2014	9:15:00 AM	0.31
9/24/2014	9:30:00 AM	0.31
9/24/2014	9:45:00 AM	0.31
9/24/2014	10:00:00 AM	0.31
9/24/2014	10:15:00 AM	0.31
9/24/2014	10:30:00 AM	0.31
9/24/2014	10:45:00 AM	0.31
9/24/2014	11:00:00 AM	0.31
9/24/2014	11:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/24/2014	11:30:00 AM	0.31
9/24/2014	11:45:00 AM	0.31
9/24/2014	12:00:00 PM	0.31
9/24/2014	12:15:00 PM	0.31
9/24/2014	12:30:00 PM	0.31
9/24/2014	12:45:00 PM	0.31
9/24/2014	1:00:00 PM	0.31
9/24/2014	1:15:00 PM	0.31
9/24/2014	1:30:00 PM	0.31
9/24/2014	1:45:00 PM	0.31
9/24/2014	2:00:00 PM	0.31
9/24/2014	2:15:00 PM	0.31
9/24/2014	2:30:00 PM	0.31
9/24/2014	2:45:00 PM	0.31
9/24/2014	3:00:00 PM	0.31
9/24/2014	3:15:00 PM	0.31
9/24/2014	3:30:00 PM	0.31
9/24/2014	3:45:00 PM	0.3
9/24/2014	4:00:00 PM	0.3
9/24/2014	4:15:00 PM	0.3
9/24/2014	4:30:00 PM	0.3
9/24/2014	4:45:00 PM	0.3
9/24/2014	5:00:00 PM	0.3
9/24/2014	5:15:00 PM	0.3
9/24/2014	5:30:00 PM	0.3
9/24/2014	5:45:00 PM	0.3
9/24/2014	6:00:00 PM	0.3
9/24/2014	6:15:00 PM	0.3
9/24/2014	6:30:00 PM	0.3
9/24/2014	6:45:00 PM	0.3
9/24/2014	7:00:00 PM	0.3
9/24/2014	7:15:00 PM	0.3
9/24/2014	7:30:00 PM	0.3
9/24/2014	7:45:00 PM	0.3
9/24/2014	8:00:00 PM	0.3
9/24/2014	8:15:00 PM	0.3
9/24/2014	8:30:00 PM	0.3
9/24/2014	8:45:00 PM	0.3
9/24/2014	9:00:00 PM	0.3
9/24/2014	9:15:00 PM	0.3
9/24/2014	9:30:00 PM	0.3
9/24/2014	9:45:00 PM	0.3
9/24/2014	10:00:00 PM	0.3
9/24/2014	10:15:00 PM	0.3
9/24/2014	10:30:00 PM	0.3
9/24/2014	10:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/24/2014	11:00:00 PM	0.3
9/24/2014	11:15:00 PM	0.3
9/24/2014	11:30:00 PM	0.3
9/24/2014	11:45:00 PM	0.3
9/25/2014	12:00:00 AM	0.3
9/25/2014	12:15:00 AM	0.3
9/25/2014	12:30:00 AM	0.3
9/25/2014	12:45:00 AM	0.3
9/25/2014	1:00:00 AM	0.3
9/25/2014	1:15:00 AM	0.3
9/25/2014	1:30:00 AM	0.3
9/25/2014	1:45:00 AM	0.3
9/25/2014	2:00:00 AM	0.3
9/25/2014	2:15:00 AM	0.3
9/25/2014	2:30:00 AM	0.3
9/25/2014	2:45:00 AM	0.3
9/25/2014	3:00:00 AM	0.3
9/25/2014	3:15:00 AM	0.3
9/25/2014	3:30:00 AM	0.3
9/25/2014	3:45:00 AM	0.3
9/25/2014	4:00:00 AM	0.3
9/25/2014	4:15:00 AM	0.31
9/25/2014	4:30:00 AM	0.31
9/25/2014	4:45:00 AM	0.31
9/25/2014	5:00:00 AM	0.31
9/25/2014	5:15:00 AM	0.31
9/25/2014	5:30:00 AM	0.31
9/25/2014	5:45:00 AM	0.31
9/25/2014	6:00:00 AM	0.31
9/25/2014	6:15:00 AM	0.31
9/25/2014	6:30:00 AM	0.31
9/25/2014	6:45:00 AM	0.31
9/25/2014	7:00:00 AM	0.31
9/25/2014	7:15:00 AM	0.31
9/25/2014	7:30:00 AM	0.31
9/25/2014	7:45:00 AM	0.31
9/25/2014	8:00:00 AM	0.31
9/25/2014	8:15:00 AM	0.31
9/25/2014	8:30:00 AM	0.31
9/25/2014	8:45:00 AM	0.31
9/25/2014	9:00:00 AM	0.31
9/25/2014	9:15:00 AM	0.31
9/25/2014	9:30:00 AM	0.31
9/25/2014	9:45:00 AM	0.31
9/25/2014	10:00:00 AM	0.31
9/25/2014	10:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/25/2014	10:30:00 AM	0.31
9/25/2014	10:45:00 AM	0.31
9/25/2014	11:00:00 AM	0.3
9/25/2014	11:15:00 AM	0.3
9/25/2014	11:30:00 AM	0.3
9/25/2014	11:45:00 AM	0.3
9/25/2014	12:00:00 PM	0.3
9/25/2014	12:15:00 PM	0.3
9/25/2014	12:30:00 PM	0.3
9/25/2014	12:45:00 PM	0.3
9/25/2014	1:00:00 PM	0.3
9/25/2014	1:15:00 PM	0.3
9/25/2014	1:30:00 PM	0.3
9/25/2014	1:45:00 PM	0.3
9/25/2014	2:00:00 PM	0.3
9/25/2014	2:15:00 PM	0.3
9/25/2014	2:30:00 PM	0.3
9/25/2014	2:45:00 PM	0.3
9/25/2014	3:00:00 PM	0.3
9/25/2014	3:15:00 PM	0.3
9/25/2014	3:30:00 PM	0.3
9/25/2014	3:45:00 PM	0.3
9/25/2014	4:00:00 PM	0.3
9/25/2014	4:15:00 PM	0.3
9/25/2014	4:30:00 PM	0.3
9/25/2014	4:45:00 PM	0.3
9/25/2014	5:00:00 PM	0.3
9/25/2014	5:15:00 PM	0.3
9/25/2014	5:30:00 PM	0.3
9/25/2014	5:45:00 PM	0.3
9/25/2014	6:00:00 PM	0.3
9/25/2014	6:15:00 PM	0.3
9/25/2014	6:30:00 PM	0.3
9/25/2014	6:45:00 PM	0.3
9/25/2014	7:00:00 PM	0.3
9/25/2014	7:15:00 PM	0.3
9/25/2014	7:30:00 PM	0.3
9/25/2014	7:45:00 PM	0.3
9/25/2014	8:00:00 PM	0.3
9/25/2014	8:15:00 PM	0.3
9/25/2014	8:30:00 PM	0.3
9/25/2014	8:45:00 PM	0.3
9/25/2014	9:00:00 PM	0.3
9/25/2014	9:15:00 PM	0.3
9/25/2014	9:30:00 PM	0.3
9/25/2014	9:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/25/2014	10:00:00 PM	0.3
9/25/2014	10:15:00 PM	0.3
9/25/2014	10:30:00 PM	0.3
9/25/2014	10:45:00 PM	0.3
9/25/2014	11:00:00 PM	0.3
9/25/2014	11:15:00 PM	0.3
9/25/2014	11:30:00 PM	0.3
9/25/2014	11:45:00 PM	0.3
9/26/2014	12:00:00 AM	0.3
9/26/2014	12:15:00 AM	0.3
9/26/2014	12:30:00 AM	0.3
9/26/2014	12:45:00 AM	0.3
9/26/2014	1:00:00 AM	0.3
9/26/2014	1:15:00 AM	0.3
9/26/2014	1:30:00 AM	0.3
9/26/2014	1:45:00 AM	0.3
9/26/2014	2:00:00 AM	0.3
9/26/2014	2:15:00 AM	0.3
9/26/2014	2:30:00 AM	0.3
9/26/2014	2:45:00 AM	0.3
9/26/2014	3:00:00 AM	0.3
9/26/2014	3:15:00 AM	0.3
9/26/2014	3:30:00 AM	0.3
9/26/2014	3:45:00 AM	0.3
9/26/2014	4:00:00 AM	0.3
9/26/2014	4:15:00 AM	0.3
9/26/2014	4:30:00 AM	0.3
9/26/2014	4:45:00 AM	0.3
9/26/2014	5:00:00 AM	0.3
9/26/2014	5:15:00 AM	0.3
9/26/2014	5:30:00 AM	0.31
9/26/2014	5:45:00 AM	0.31
9/26/2014	6:00:00 AM	0.31
9/26/2014	6:15:00 AM	0.31
9/26/2014	6:30:00 AM	0.31
9/26/2014	6:45:00 AM	0.31
9/26/2014	7:00:00 AM	0.31
9/26/2014	7:15:00 AM	0.31
9/26/2014	7:30:00 AM	0.31
9/26/2014	7:45:00 AM	0.31
9/26/2014	8:00:00 AM	0.31
9/26/2014	8:15:00 AM	0.31
9/26/2014	8:30:00 AM	0.31
9/26/2014	8:45:00 AM	0.31
9/26/2014	9:00:00 AM	0.31
9/26/2014	9:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/26/2014	9:30:00 AM	0.31
9/26/2014	9:45:00 AM	0.31
9/26/2014	10:00:00 AM	0.31
9/26/2014	10:15:00 AM	0.31
9/26/2014	10:30:00 AM	0.31
9/26/2014	10:45:00 AM	0.31
9/26/2014	11:00:00 AM	0.31
9/26/2014	11:15:00 AM	0.31
9/26/2014	11:30:00 AM	0.31
9/26/2014	11:45:00 AM	0.31
9/26/2014	12:00:00 PM	0.31
9/26/2014	12:15:00 PM	0.3
9/26/2014	12:30:00 PM	0.3
9/26/2014	12:45:00 PM	0.3
9/26/2014	1:00:00 PM	0.3
9/26/2014	1:15:00 PM	0.3
9/26/2014	1:30:00 PM	0.3
9/26/2014	1:45:00 PM	0.3
9/26/2014	2:00:00 PM	0.3
9/26/2014	2:15:00 PM	0.3
9/26/2014	2:30:00 PM	0.3
9/26/2014	2:45:00 PM	0.3
9/26/2014	3:00:00 PM	0.3
9/26/2014	3:15:00 PM	0.3
9/26/2014	3:30:00 PM	0.3
9/26/2014	3:45:00 PM	0.3
9/26/2014	4:00:00 PM	0.3
9/26/2014	4:15:00 PM	0.3
9/26/2014	4:30:00 PM	0.3
9/26/2014	4:45:00 PM	0.3
9/26/2014	5:00:00 PM	0.3
9/26/2014	5:15:00 PM	0.3
9/26/2014	5:30:00 PM	0.3
9/26/2014	5:45:00 PM	0.3
9/26/2014	6:00:00 PM	0.3
9/26/2014	6:15:00 PM	0.3
9/26/2014	6:30:00 PM	0.3
9/26/2014	6:45:00 PM	0.3
9/26/2014	7:00:00 PM	0.3
9/26/2014	7:15:00 PM	0.3
9/26/2014	7:30:00 PM	0.3
9/26/2014	7:45:00 PM	0.3
9/26/2014	8:00:00 PM	0.3
9/26/2014	8:15:00 PM	0.3
9/26/2014	8:30:00 PM	0.3
9/26/2014	8:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
9/26/2014	9:00:00 PM	0.3
9/26/2014	9:15:00 PM	0.3
9/26/2014	9:30:00 PM	0.3
9/26/2014	9:45:00 PM	0.3
9/26/2014	10:00:00 PM	0.3
9/26/2014	10:15:00 PM	0.3
9/26/2014	10:30:00 PM	0.3
9/26/2014	10:45:00 PM	0.3
9/26/2014	11:00:00 PM	0.3
9/26/2014	11:15:00 PM	0.3
9/26/2014	11:30:00 PM	0.3
9/26/2014	11:45:00 PM	0.3
9/27/2014	12:00:00 AM	0.3
9/27/2014	12:15:00 AM	0.3
9/27/2014	12:30:00 AM	0.3
9/27/2014	12:45:00 AM	0.3
9/27/2014	1:00:00 AM	0.3
9/27/2014	1:15:00 AM	0.3
9/27/2014	1:30:00 AM	0.3
9/27/2014	1:45:00 AM	0.3
9/27/2014	2:00:00 AM	0.3
9/27/2014	2:15:00 AM	0.3
9/27/2014	2:30:00 AM	0.3
9/27/2014	2:45:00 AM	0.3
9/27/2014	3:00:00 AM	0.3
9/27/2014	3:15:00 AM	0.3
9/27/2014	3:30:00 AM	0.3
9/27/2014	3:45:00 AM	0.3
9/27/2014	4:00:00 AM	0.3
9/27/2014	4:15:00 AM	0.3
9/27/2014	4:30:00 AM	0.31
9/27/2014	4:45:00 AM	0.31
9/27/2014	5:00:00 AM	0.31
9/27/2014	5:15:00 AM	0.31
9/27/2014	5:30:00 AM	0.31
9/27/2014	5:45:00 AM	0.31
9/27/2014	6:00:00 AM	0.31
9/27/2014	6:15:00 AM	0.31
9/27/2014	6:30:00 AM	0.31
9/27/2014	6:45:00 AM	0.31
9/27/2014	7:00:00 AM	0.31
9/27/2014	7:15:00 AM	0.31
9/27/2014	7:30:00 AM	0.31
9/27/2014	7:45:00 AM	0.31
9/27/2014	8:00:00 AM	0.31
9/27/2014	8:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/27/2014	8:30:00 AM	0.31
9/27/2014	8:45:00 AM	0.31
9/27/2014	9:00:00 AM	0.31
9/27/2014	9:15:00 AM	0.31
9/27/2014	9:30:00 AM	0.31
9/27/2014	9:45:00 AM	0.31
9/27/2014	10:00:00 AM	0.31
9/27/2014	10:15:00 AM	0.31
9/27/2014	10:30:00 AM	0.31
9/27/2014	10:45:00 AM	0.31
9/27/2014	11:00:00 AM	0.31
9/27/2014	11:15:00 AM	0.31
9/27/2014	11:30:00 AM	0.31
9/27/2014	11:45:00 AM	0.31
9/27/2014	12:00:00 PM	0.31
9/27/2014	12:15:00 PM	0.31
9/27/2014	12:30:00 PM	0.31
9/27/2014	12:45:00 PM	0.31
9/27/2014	1:00:00 PM	0.31
9/27/2014	1:15:00 PM	0.31
9/27/2014	1:30:00 PM	0.31
9/27/2014	1:45:00 PM	0.31
9/27/2014	2:00:00 PM	0.31
9/27/2014	2:15:00 PM	0.31
9/27/2014	2:30:00 PM	0.31
9/27/2014	2:45:00 PM	0.31
9/27/2014	3:00:00 PM	0.31
9/27/2014	3:15:00 PM	0.31
9/27/2014	3:30:00 PM	0.31
9/27/2014	3:45:00 PM	0.31
9/27/2014	4:00:00 PM	0.31
9/27/2014	4:15:00 PM	0.31
9/27/2014	4:30:00 PM	0.31
9/27/2014	4:45:00 PM	0.31
9/27/2014	5:00:00 PM	0.31
9/27/2014	5:15:00 PM	0.31
9/27/2014	5:30:00 PM	0.31
9/27/2014	5:45:00 PM	0.31
9/27/2014	6:00:00 PM	0.31
9/27/2014	6:15:00 PM	0.31
9/27/2014	6:30:00 PM	0.31
9/27/2014	6:45:00 PM	0.31
9/27/2014	7:00:00 PM	0.31
9/27/2014	7:15:00 PM	0.31
9/27/2014	7:30:00 PM	0.31
9/27/2014	7:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/27/2014	8:00:00 PM	0.31
9/27/2014	8:15:00 PM	0.31
9/27/2014	8:30:00 PM	0.31
9/27/2014	8:45:00 PM	0.31
9/27/2014	9:00:00 PM	0.31
9/27/2014	9:15:00 PM	0.31
9/27/2014	9:30:00 PM	0.31
9/27/2014	9:45:00 PM	0.31
9/27/2014	10:00:00 PM	0.31
9/27/2014	10:15:00 PM	0.31
9/27/2014	10:30:00 PM	0.31
9/27/2014	10:45:00 PM	0.31
9/27/2014	11:00:00 PM	0.31
9/27/2014	11:15:00 PM	0.31
9/27/2014	11:30:00 PM	0.31
9/27/2014	11:45:00 PM	0.31
9/28/2014	12:00:00 AM	0.31
9/28/2014	12:15:00 AM	0.31
9/28/2014	12:30:00 AM	0.31
9/28/2014	12:45:00 AM	0.31
9/28/2014	1:00:00 AM	0.31
9/28/2014	1:15:00 AM	0.31
9/28/2014	1:30:00 AM	0.31
9/28/2014	1:45:00 AM	0.31
9/28/2014	2:00:00 AM	0.31
9/28/2014	2:15:00 AM	0.31
9/28/2014	2:30:00 AM	0.31
9/28/2014	2:45:00 AM	0.31
9/28/2014	3:00:00 AM	0.31
9/28/2014	3:15:00 AM	0.31
9/28/2014	3:30:00 AM	0.31
9/28/2014	3:45:00 AM	0.31
9/28/2014	4:00:00 AM	0.31
9/28/2014	4:15:00 AM	0.31
9/28/2014	4:30:00 AM	0.31
9/28/2014	4:45:00 AM	0.31
9/28/2014	5:00:00 AM	0.31
9/28/2014	5:15:00 AM	0.31
9/28/2014	5:30:00 AM	0.31
9/28/2014	5:45:00 AM	0.31
9/28/2014	6:00:00 AM	0.31
9/28/2014	6:15:00 AM	0.31
9/28/2014	6:30:00 AM	0.31
9/28/2014	6:45:00 AM	0.31
9/28/2014	7:00:00 AM	0.31
9/28/2014	7:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/28/2014	7:30:00 AM	0.31
9/28/2014	7:45:00 AM	0.31
9/28/2014	8:00:00 AM	0.31
9/28/2014	8:15:00 AM	0.31
9/28/2014	8:30:00 AM	0.31
9/28/2014	8:45:00 AM	0.31
9/28/2014	9:00:00 AM	0.31
9/28/2014	9:15:00 AM	0.31
9/28/2014	9:30:00 AM	0.31
9/28/2014	9:45:00 AM	0.31
9/28/2014	10:00:00 AM	0.31
9/28/2014	10:15:00 AM	0.31
9/28/2014	10:30:00 AM	0.31
9/28/2014	10:45:00 AM	0.31
9/28/2014	11:00:00 AM	0.31
9/28/2014	11:15:00 AM	0.31
9/28/2014	11:30:00 AM	0.31
9/28/2014	11:45:00 AM	0.31
9/28/2014	12:00:00 PM	0.31
9/28/2014	12:15:00 PM	0.31
9/28/2014	12:30:00 PM	0.31
9/28/2014	12:45:00 PM	0.31
9/28/2014	1:00:00 PM	0.31
9/28/2014	1:15:00 PM	0.31
9/28/2014	1:30:00 PM	0.31
9/28/2014	1:45:00 PM	0.31
9/28/2014	2:00:00 PM	0.31
9/28/2014	2:15:00 PM	0.31
9/28/2014	2:30:00 PM	0.31
9/28/2014	2:45:00 PM	0.31
9/28/2014	3:00:00 PM	0.31
9/28/2014	3:15:00 PM	0.31
9/28/2014	3:30:00 PM	0.31
9/28/2014	3:45:00 PM	0.31
9/28/2014	4:00:00 PM	0.31
9/28/2014	4:15:00 PM	0.31
9/28/2014	4:30:00 PM	0.31
9/28/2014	4:45:00 PM	0.31
9/28/2014	5:00:00 PM	0.31
9/28/2014	5:15:00 PM	0.31
9/28/2014	5:30:00 PM	0.31
9/28/2014	5:45:00 PM	0.31
9/28/2014	6:00:00 PM	0.31
9/28/2014	6:15:00 PM	0.31
9/28/2014	6:30:00 PM	0.31
9/28/2014	6:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/28/2014	7:00:00 PM	0.31
9/28/2014	7:15:00 PM	0.31
9/28/2014	7:30:00 PM	0.31
9/28/2014	7:45:00 PM	0.31
9/28/2014	8:00:00 PM	0.31
9/28/2014	8:15:00 PM	0.31
9/28/2014	8:30:00 PM	0.31
9/28/2014	8:45:00 PM	0.31
9/28/2014	9:00:00 PM	0.31
9/28/2014	9:15:00 PM	0.31
9/28/2014	9:30:00 PM	0.31
9/28/2014	9:45:00 PM	0.31
9/28/2014	10:00:00 PM	0.31
9/28/2014	10:15:00 PM	0.31
9/28/2014	10:30:00 PM	0.31
9/28/2014	10:45:00 PM	0.31
9/28/2014	11:00:00 PM	0.31
9/28/2014	11:15:00 PM	0.31
9/28/2014	11:30:00 PM	0.31
9/28/2014	11:45:00 PM	0.31
9/29/2014	12:00:00 AM	0.31
9/29/2014	12:15:00 AM	0.31
9/29/2014	12:30:00 AM	0.31
9/29/2014	12:45:00 AM	0.31
9/29/2014	1:00:00 AM	0.31
9/29/2014	1:15:00 AM	0.31
9/29/2014	1:30:00 AM	0.31
9/29/2014	1:45:00 AM	0.31
9/29/2014	2:00:00 AM	0.31
9/29/2014	2:15:00 AM	0.31
9/29/2014	2:30:00 AM	0.31
9/29/2014	2:45:00 AM	0.31
9/29/2014	3:00:00 AM	0.31
9/29/2014	3:15:00 AM	0.31
9/29/2014	3:30:00 AM	0.31
9/29/2014	3:45:00 AM	0.31
9/29/2014	4:00:00 AM	0.31
9/29/2014	4:15:00 AM	0.31
9/29/2014	4:30:00 AM	0.31
9/29/2014	4:45:00 AM	0.31
9/29/2014	5:00:00 AM	0.31
9/29/2014	5:15:00 AM	0.31
9/29/2014	5:30:00 AM	0.31
9/29/2014	5:45:00 AM	0.31
9/29/2014	6:00:00 AM	0.31
9/29/2014	6:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/29/2014	6:30:00 AM	0.31
9/29/2014	6:45:00 AM	0.31
9/29/2014	7:00:00 AM	0.31
9/29/2014	7:15:00 AM	0.31
9/29/2014	7:30:00 AM	0.31
9/29/2014	7:45:00 AM	0.31
9/29/2014	8:00:00 AM	0.31
9/29/2014	8:15:00 AM	0.31
9/29/2014	8:30:00 AM	0.31
9/29/2014	8:45:00 AM	0.31
9/29/2014	9:00:00 AM	0.31
9/29/2014	9:15:00 AM	0.31
9/29/2014	9:30:00 AM	0.31
9/29/2014	9:45:00 AM	0.31
9/29/2014	10:00:00 AM	0.31
9/29/2014	10:15:00 AM	0.31
9/29/2014	10:30:00 AM	0.31
9/29/2014	10:45:00 AM	0.31
9/29/2014	11:00:00 AM	0.31
9/29/2014	11:15:00 AM	0.31
9/29/2014	11:30:00 AM	0.31
9/29/2014	11:45:00 AM	0.31
9/29/2014	12:00:00 PM	0.31
9/29/2014	12:15:00 PM	0.31
9/29/2014	12:30:00 PM	0.31
9/29/2014	12:45:00 PM	0.31
9/29/2014	1:00:00 PM	0.31
9/29/2014	1:15:00 PM	0.31
9/29/2014	1:30:00 PM	0.31
9/29/2014	1:45:00 PM	0.31
9/29/2014	2:00:00 PM	0.31
9/29/2014	2:15:00 PM	0.31
9/29/2014	2:30:00 PM	0.31
9/29/2014	2:45:00 PM	0.31
9/29/2014	3:00:00 PM	0.31
9/29/2014	3:15:00 PM	0.31
9/29/2014	3:30:00 PM	0.31
9/29/2014	3:45:00 PM	0.31
9/29/2014	4:00:00 PM	0.31
9/29/2014	4:15:00 PM	0.31
9/29/2014	4:30:00 PM	0.31
9/29/2014	4:45:00 PM	0.31
9/29/2014	5:00:00 PM	0.31
9/29/2014	5:15:00 PM	0.31
9/29/2014	5:30:00 PM	0.31
9/29/2014	5:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/29/2014	6:00:00 PM	0.31
9/29/2014	6:15:00 PM	0.31
9/29/2014	6:30:00 PM	0.31
9/29/2014	6:45:00 PM	0.31
9/29/2014	7:00:00 PM	0.31
9/29/2014	7:15:00 PM	0.31
9/29/2014	7:30:00 PM	0.31
9/29/2014	7:45:00 PM	0.31
9/29/2014	8:00:00 PM	0.31
9/29/2014	8:15:00 PM	0.31
9/29/2014	8:30:00 PM	0.31
9/29/2014	8:45:00 PM	0.31
9/29/2014	9:00:00 PM	0.31
9/29/2014	9:15:00 PM	0.31
9/29/2014	9:30:00 PM	0.31
9/29/2014	9:45:00 PM	0.31
9/29/2014	10:00:00 PM	0.31
9/29/2014	10:15:00 PM	0.31
9/29/2014	10:30:00 PM	0.31
9/29/2014	10:45:00 PM	0.31
9/29/2014	11:00:00 PM	0.31
9/29/2014	11:15:00 PM	0.31
9/29/2014	11:30:00 PM	0.31
9/29/2014	11:45:00 PM	0.31
9/30/2014	12:00:00 AM	0.31
9/30/2014	12:15:00 AM	0.31
9/30/2014	12:30:00 AM	0.31
9/30/2014	12:45:00 AM	0.31
9/30/2014	1:00:00 AM	0.31
9/30/2014	1:15:00 AM	0.31
9/30/2014	1:30:00 AM	0.31
9/30/2014	1:45:00 AM	0.31
9/30/2014	2:00:00 AM	0.31
9/30/2014	2:15:00 AM	0.31
9/30/2014	2:30:00 AM	0.31
9/30/2014	2:45:00 AM	0.31
9/30/2014	3:00:00 AM	0.31
9/30/2014	3:15:00 AM	0.31
9/30/2014	3:30:00 AM	0.31
9/30/2014	3:45:00 AM	0.31
9/30/2014	4:00:00 AM	0.31
9/30/2014	4:15:00 AM	0.31
9/30/2014	4:30:00 AM	0.31
9/30/2014	4:45:00 AM	0.31
9/30/2014	5:00:00 AM	0.31
9/30/2014	5:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/30/2014	5:30:00 AM	0.31
9/30/2014	5:45:00 AM	0.31
9/30/2014	6:00:00 AM	0.31
9/30/2014	6:15:00 AM	0.31
9/30/2014	6:30:00 AM	0.31
9/30/2014	6:45:00 AM	0.31
9/30/2014	7:00:00 AM	0.31
9/30/2014	7:15:00 AM	0.31
9/30/2014	7:30:00 AM	0.31
9/30/2014	7:45:00 AM	0.31
9/30/2014	8:00:00 AM	0.31
9/30/2014	8:15:00 AM	0.31
9/30/2014	8:30:00 AM	0.31
9/30/2014	8:45:00 AM	0.31
9/30/2014	9:00:00 AM	0.31
9/30/2014	9:15:00 AM	0.31
9/30/2014	9:30:00 AM	0.31
9/30/2014	9:45:00 AM	0.31
9/30/2014	10:00:00 AM	0.31
9/30/2014	10:15:00 AM	0.31
9/30/2014	10:30:00 AM	0.31
9/30/2014	10:45:00 AM	0.31
9/30/2014	11:00:00 AM	0.31
9/30/2014	11:15:00 AM	0.31
9/30/2014	11:30:00 AM	0.31
9/30/2014	11:45:00 AM	0.31
9/30/2014	12:00:00 PM	0.31
9/30/2014	12:15:00 PM	0.31
9/30/2014	12:30:00 PM	0.31
9/30/2014	12:45:00 PM	0.31
9/30/2014	1:00:00 PM	0.31
9/30/2014	1:15:00 PM	0.31
9/30/2014	1:30:00 PM	0.31
9/30/2014	1:45:00 PM	0.31
9/30/2014	2:00:00 PM	0.31
9/30/2014	2:15:00 PM	0.31
9/30/2014	2:30:00 PM	0.31
9/30/2014	2:45:00 PM	0.31
9/30/2014	3:00:00 PM	0.31
9/30/2014	3:15:00 PM	0.31
9/30/2014	3:30:00 PM	0.31
9/30/2014	3:45:00 PM	0.31
9/30/2014	4:00:00 PM	0.31
9/30/2014	4:15:00 PM	0.31
9/30/2014	4:30:00 PM	0.31
9/30/2014	4:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
9/30/2014	5:00:00 PM	0.31
9/30/2014	5:15:00 PM	0.31
9/30/2014	5:30:00 PM	0.31
9/30/2014	5:45:00 PM	0.31
9/30/2014	6:00:00 PM	0.31
9/30/2014	6:15:00 PM	0.31
9/30/2014	6:30:00 PM	0.31
9/30/2014	6:45:00 PM	0.31
9/30/2014	7:00:00 PM	0.31
9/30/2014	7:15:00 PM	0.31
9/30/2014	7:30:00 PM	0.31
9/30/2014	7:45:00 PM	0.31
9/30/2014	8:00:00 PM	0.31
9/30/2014	8:15:00 PM	0.31
9/30/2014	8:30:00 PM	0.31
9/30/2014	8:45:00 PM	0.31
9/30/2014	9:00:00 PM	0.31
9/30/2014	9:15:00 PM	0.31
9/30/2014	9:30:00 PM	0.31
9/30/2014	9:45:00 PM	0.31
9/30/2014	10:00:00 PM	0.31
9/30/2014	10:15:00 PM	0.31
9/30/2014	10:30:00 PM	0.31
9/30/2014	10:45:00 PM	0.31
9/30/2014	11:00:00 PM	0.31
9/30/2014	11:15:00 PM	0.31
9/30/2014	11:30:00 PM	0.31
9/30/2014	11:45:00 PM	0.31
10/1/2014	12:00:00 AM	0.31

Station Number: 0354 Meas. No: 004

Station Name: LOR @ MAZOURKA Date: 09/17/2014

Party: BJA/KSL	Width: 19.4 ft	Processed by: BJA/KSL
Boat/Motor:	Area: 80.4 ft²	Mean Velocity: 0.662 ft/s
Gage Height: 4.50 ft	G.H.Change: 0.000 ft	Discharge: 53.1 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 1.77 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 8.37 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 4.15 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 67.45	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 67.2 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 140917 LOR @ MAZOURKA00

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	33	6.22	34.7	5.30	2.15	2.26	50.6	19	76	07:13	07:13	0.53	0.67	6	0
001	R	2	2	34	6.46	36.1	5.51	2.15	2.30	52.4	19	76	07:13	07:14	0.52	0.69	6	0
002	L	2	2	34	6.29	35.4	9.82	2.08	2.05	55.7	20	87	07:14	07:15	0.52	0.64	6	0
003	R	2	2	33	6.67	37.3	6.75	2.12	2.12	54.9	20	84	07:15	07:16	0.57	0.66	6	0
004	L	2	2	33	6.39	35.8	5.44	2.22	2.15	52.0	20	80	07:16	07:17	0.51	0.65	6	0
Mean		2	2	33	6.41	35.8	6.56	2.15	2.18	53.1	19	80	**Total**	00:04	0.53	0.66	6	0
SDev		0	0	1	0.178	0.950	1.91	0.052	0.102	2.10	0.5	4.8			0.02	0.02		
SD/M		0.00	0.00	0.02	0.03	0.03	0.29	0.02	0.05	0.04	0.03	0.06			0.04	0.03		

Remarks:

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	0	3	21	0.764	-0.095	4.157	0.013	0.01	0	44.3	41.3	73.1	138	130	0	35	34
2014	9	1	0	13	21	0.745	-0.102	4.157	0.01	0.007	0	44.3	41.7	73.5	138	130	0	35	33
2014	9	1	0	23	21	0.768	-0.079	4.157	0.01	0.007	0	45.2	42.1	73.5	140	131	0	35	33
2014	9	1	0	33	21	0.745	-0.085	4.157	0.01	0.007	0	44.7	41.7	74	139	130	0	35	33
2014	9	1	0	43	21	0.751	-0.039	4.157	0.01	0.007	0	44.3	40.9	73.5	138	129	0	35	34
2014	9	1	0	53	21	0.758	-0.095	4.157	0.01	0.007	0	44.7	40.9	73.5	138	129	0	34	34
2014	9	1	1	3	21	0.722	-0.069	4.157	0.013	0.01	0	44.7	41.3	73.1	138	130	0	34	34
2014	9	1	1	13	21	0.735	-0.079	4.157	0.01	0.007	0	44.7	41.3	72.7	139	130	0	35	34
2014	9	1	1	23	21	0.735	-0.082	4.157	0.01	0.007	0	44.7	41.7	73.1	138	130	0	34	33
2014	9	1	1	33	21	0.748	-0.085	4.157	0.01	0.007	0	44.3	41.3	73.1	137	129	0	34	33
2014	9	1	1	43	21	0.728	-0.098	4.157	0.013	0.01	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	1	1	53	21	0.725	-0.072	4.16	0.013	0.01	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	1	2	3	21	0.745	-0.105	4.157	0.013	0.01	0	44.3	41.3	72.2	138	130	0	35	34
2014	9	1	2	13	21	0.732	-0.082	4.157	0.01	0.007	0	43.9	40.4	71.8	136	128	0	34	34
2014	9	1	2	23	21	0.755	-0.095	4.157	0.013	0.01	0	43.9	40.9	72.2	137	128	0	35	33
2014	9	1	2	33	21	0.722	-0.082	4.157	0.016	0.016	0	43.4	40.9	71.8	136	128	0	35	33
2014	9	1	2	43	21	0.738	-0.069	4.16	0.013	0.01	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	1	2	53	21	0.725	-0.052	4.16	0.013	0.01	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	1	3	3	21	0.741	-0.105	4.16	0.016	0.013	0	44.3	40.4	71.4	137	128	0	34	34
2014	9	1	3	13	21	0.719	-0.095	4.16	0.013	0.01	0	44.7	41.7	69.7	139	130	0	35	33
2014	9	1	3	23	21	0.735	-0.079	4.16	0.01	0.007	0	44.3	40.9	71.4	137	128	0	34	33
2014	9	1	3	33	21	0.741	-0.079	4.16	0.01	0.007	0	45.2	41.7	71	139	130	0	34	33
2014	9	1	3	43	21	0.745	-0.079	4.16	0.01	0.007	0	43.4	40	71	136	127	0	35	34
2014	9	1	3	55	14	0.751	-0.079	4.167	0.01	0.007	0	43.4	40.9	69.7	136	128	0	35	33
2014	9	1	4	5	14	0.699	-0.069	4.17	0.01	0.007	0	43.9	40.4	71	136	128	0	34	34
2014	9	1	4	15	14	0.741	-0.062	4.17	0.01	0.007	0	43.9	40.9	71.4	137	129	0	35	34
2014	9	1	4	25	14	0.741	-0.082	4.173	0.013	0.01	0	43.4	40.4	71.4	136	128	0	35	34
2014	9	1	4	35	14	0.758	-0.082	4.173	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	1	4	45	14	0.715	-0.066	4.173	0.013	0.01	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	1	4	55	14	0.738	-0.075	4.173	0.013	0.01	0	44.3	41.7	72.2	138	130	0	35	33
2014	9	1	5	5	14	0.719	-0.079	4.173	0.01	0.007	0	44.3	41.3	72.2	138	129	0	35	33
2014	9	1	5	15	14	0.748	-0.095	4.173	0.01	0.007	0	43.9	41.3	72.2	137	129	0	35	33
2014	9	1	5	25	14	0.722	-0.082	4.173	0.01	0.007	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	1	5	35	14	0.715	-0.085	4.177	0.013	0.01	0	44.7	40.9	73.1	138	130	0	34	35
2014	9	1	5	45	14	0.725	-0.075	4.177	0.01	0.007	0	45.6	41.7	72.7	140	131	0	34	34
2014	9	1	5	55	14	0.741	-0.069	4.177	0.013	0.01	0	44.7	42.1	73.5	139	131	0	35	33
2014	9	1	6	5	14	0.758	-0.085	4.177	0.01	0.007	0	45.2	41.7	72.7	140	131	0	35	34
2014	9	1	6	15	14	0.745	-0.082	4.177	0.01	0.007	0	44.7	41.7	72.7	139	130	0	35	33
2014	9	1	6	25	14	0.751	-0.095	4.177	0.01	0.007	0	45.2	41.7	73.5	140	131	0	35	34
2014	9	1	6	35	14	0.748	-0.092	4.177	0.01	0.007	0	45.2	42.1	73.5	140	131	0	35	33
2014	9	1	6	45	14	0.741	-0.079	4.177	0.01	0.007	0	44.3	41.7	74.4	138	130	0	35	33
2014	9	1	6	55	14	0.741	-0.108	4.177	0.01	0.007	0	44.7	41.7	74.4	139	130	0	35	33
2014	9	1	7	5	14	0.719	-0.072	4.177	0.01	0.007	0	45.2	42.1	74	140	132	0	35	34
2014	9	1	7	15	14	0.722	-0.066	4.177	0.01	0.007	0	45.2	42.1	74.4	139	131	0	34	33
2014	9	1	7	25	14	0.728	-0.079	4.177	0.01	0.007	0	43.9	40	74.8	136	127	0	34	34
2014	9	1	7	35	14	0.771	-0.092	4.177	0.01	0.007	0	43	39.6	74.8	135	127	0	35	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	7	45	14	0.712	-0.128	4.177	0.013	0.01	0	43	40.4	74.8	135	127	0	35	33
2014	9	1	7	55	14	0.738	-0.066	4.177	0.013	0.01	0	43	40	75.7	135	127	0	35	34
2014	9	1	8	5	14	0.748	-0.118	4.18	0.01	0.007	0	43	40	75.3	135	127	0	35	34
2014	9	1	8	15	14	0.781	-0.069	4.177	0.013	0.01	0	43	39.6	74.4	135	127	0	35	35
2014	9	1	8	25	14	0.732	-0.082	4.177	0.01	0.007	0	43.4	40	74.8	135	127	0	34	34
2014	9	1	8	35	14	0.761	-0.095	4.177	0.01	0.007	0	43	40.4	75.3	135	127	0	35	33
2014	9	1	8	45	14	0.755	-0.102	4.177	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	1	8	55	14	0.732	-0.112	4.177	0.01	0.007	0	42.6	40	65.4	134	127	0	35	34
2014	9	1	9	5	14	0.764	-0.108	4.177	0.01	0.007	0	43	40	74.8	135	127	0	35	34
2014	9	1	9	15	14	0.738	-0.102	4.177	0.016	0.013	0	43	40.4	74	135	127	0	35	33
2014	9	1	9	25	14	0.732	-0.098	4.177	0.01	0.007	0	43	40	74.8	135	127	0	35	34
2014	9	1	9	35	14	0.778	-0.112	4.177	0.01	0.007	0	43.4	40.4	74.8	135	127	0	34	33
2014	9	1	9	45	14	0.735	-0.082	4.177	0.01	0.007	0	43	40	74.4	135	127	0	35	34
2014	9	1	9	55	14	0.748	-0.085	4.177	0.016	0.013	0	43	40	73.5	135	126	0	35	33
2014	9	1	10	5	14	0.741	-0.118	4.177	0.013	0.01	0	43	40	74.8	135	126	0	35	33
2014	9	1	10	15	14	0.755	-0.098	4.177	0.013	0.01	0	43	40	73.5	135	127	0	35	34
2014	9	1	10	25	14	0.751	-0.115	4.177	0.01	0.007	0	43	39.6	73.5	134	126	0	34	34
2014	9	1	10	35	14	0.784	-0.115	4.177	0.01	0.007	0	43	40.4	73.1	135	127	0	35	33
2014	9	1	10	45	14	0.745	-0.138	4.177	0.01	0.007	0	42.6	40	73.1	134	126	0	35	33
2014	9	1	10	55	14	0.768	-0.072	4.177	0.01	0.007	0	42.6	39.6	73.5	134	126	0	35	34
2014	9	1	11	5	14	0.755	-0.102	4.177	0.013	0.01	0	42.6	40	72.7	134	126	0	35	33
2014	9	1	11	15	14	0.751	-0.138	4.177	0.01	0.007	0	43.4	40.4	73.1	135	127	0	34	33
2014	9	1	11	25	14	0.738	-0.128	4.177	0.013	0.01	0	43.4	40	73.1	135	126	0	34	33
2014	9	1	11	35	14	0.761	-0.131	4.177	0.01	0.007	0	43.4	39.6	73.1	135	126	0	34	34
2014	9	1	11	45	14	0.764	-0.112	4.173	0.01	0.007	0	43	40	72.7	135	127	0	35	34
2014	9	1	11	55	14	0.751	-0.128	4.173	0.01	0.007	0	42.6	39.6	72.2	134	126	0	35	34
2014	9	1	12	5	14	0.784	-0.148	4.167	0.013	0.01	0	42.6	39.6	64.5	134	125	0	35	33
2014	9	1	12	15	14	0.768	-0.138	4.173	0.01	0.007	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	1	12	25	14	0.732	-0.128	4.17	0.01	0.007	0	42.6	39.6	71.8	134	125	0	35	33
2014	9	1	12	35	14	0.768	-0.128	4.167	0.01	0.007	0	43	40	71.4	135	126	0	35	33
2014	9	1	12	45	14	0.745	-0.112	4.163	0.01	0.007	0	42.6	40	71.8	134	126	0	35	33
2014	9	1	12	55	14	0.741	-0.154	4.163	0.01	0.007	0	43	39.1	64.5	134	125	0	34	34
2014	9	1	13	5	14	0.764	-0.141	4.163	0.01	0.007	0	43	39.1	64.1	134	125	0	34	34
2014	9	1	13	15	14	0.764	-0.135	4.16	0.01	0.007	0	42.6	39.1	68.4	134	125	0	35	34
2014	9	1	13	25	14	0.735	-0.138	4.16	0.01	0.007	0	43.4	39.6	59.3	135	126	0	34	34
2014	9	1	13	35	14	0.778	-0.121	4.16	0.01	0.007	0	43	39.6	55.9	135	126	0	35	34
2014	9	1	13	45	14	0.741	-0.144	4.16	0.01	0.007	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	1	13	55	14	0.751	-0.121	4.16	0.013	0.01	0	43	39.6	65.8	134	126	0	34	34
2014	9	1	14	5	14	0.755	-0.108	4.16	0.016	0.013	0	43	39.6	53.3	135	126	0	35	34
2014	9	1	14	15	14	0.751	-0.177	4.157	0.01	0.007	0	42.6	39.1	64.1	133	125	0	34	34
2014	9	1	14	25	14	0.748	-0.128	4.157	0.01	0.007	0	43	39.6	60.6	135	126	0	35	34
2014	9	1	14	35	14	0.732	-0.161	4.157	0.013	0.01	0	43.4	40	55.9	135	126	0	34	33
2014	9	1	14	45	14	0.725	-0.135	4.157	0.013	0.01	0	42.6	39.1	68.8	134	125	0	35	34
2014	9	1	14	55	14	0.741	-0.161	4.157	0.013	0.01	0	43	40	64.9	134	126	0	34	33
2014	9	1	15	5	14	0.738	-0.151	4.157	0.013	0.01	0	43	40.4	55	135	127	0	35	33
2014	9	1	15	15	14	0.755	-0.167	4.157	0.01	0.007	0	42.6	40	61.5	134	126	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	15	25	14	0.751	-0.105	4.157	0.01	0.007	0	43	40	67.1	135	127	0	35	34
2014	9	1	15	35	14	0.735	-0.154	4.157	0.013	0.01	0	42.6	39.6	62.4	134	126	0	35	34
2014	9	1	15	45	14	0.738	-0.125	4.157	0.016	0.013	0	42.6	39.6	64.9	134	126	0	35	34
2014	9	1	15	55	14	0.751	-0.131	4.154	0.01	0.007	0	42.6	40	62.4	134	126	0	35	33
2014	9	1	16	5	14	0.761	-0.161	4.157	0.01	0.007	0	43.9	40	52.9	136	127	0	34	34
2014	9	1	16	15	14	0.755	-0.102	4.157	0.013	0.01	0	43.4	40.9	55.9	136	128	0	35	33
2014	9	1	16	25	14	0.738	-0.092	4.154	0.013	0.01	0	42.6	40	62.8	134	127	0	35	34
2014	9	1	16	35	14	0.732	-0.19	4.154	0.01	0.007	0	43.9	40.4	57.2	136	128	0	34	34
2014	9	1	16	45	14	0.761	-0.115	4.157	0.013	0.01	0	43	40	55	135	127	0	35	34
2014	9	1	16	55	14	0.761	-0.135	4.154	0.01	0.007	0	43.4	40.4	55.5	135	127	0	34	33
2014	9	1	17	5	14	0.774	-0.115	4.157	0.013	0.01	0	43.4	40.4	53.3	136	128	0	35	34
2014	9	1	17	15	14	0.725	-0.141	4.157	0.016	0.013	0	43	40	53.3	135	127	0	35	34
2014	9	1	17	25	14	0.751	-0.098	4.157	0.01	0.007	0	43	40.4	51.2	135	127	0	35	33
2014	9	1	17	35	14	0.738	-0.161	4.157	0.01	0.007	0	43	39.1	52.5	134	125	0	34	34
2014	9	1	17	45	14	0.748	-0.141	4.154	0.01	0.007	0	42.6	40	58	134	126	0	35	33
2014	9	1	17	55	14	0.741	-0.115	4.154	0.013	0.01	0	43	39.6	56.3	134	126	0	34	34
2014	9	1	18	5	14	0.728	-0.138	4.154	0.013	0.01	0	42.6	40	57.6	134	126	0	35	33
2014	9	1	18	15	14	0.748	-0.128	4.154	0.01	0.007	0	42.6	39.6	60.2	134	126	0	35	34
2014	9	1	18	25	14	0.748	-0.128	4.154	0.01	0.007	0	42.6	39.6	55	134	125	0	35	33
2014	9	1	18	35	14	0.741	-0.141	4.157	0.01	0.007	0	42.6	40	64.1	134	126	0	35	33
2014	9	1	18	45	14	0.741	-0.141	4.157	0.01	0.007	0	42.6	39.1	61.5	134	125	0	35	34
2014	9	1	18	55	14	0.745	-0.095	4.154	0.01	0.007	0	42.6	39.6	62.8	134	126	0	35	34
2014	9	1	19	5	14	0.741	-0.108	4.154	0.01	0.007	0	43	40	63.6	134	126	0	34	33
2014	9	1	19	15	14	0.741	-0.082	4.157	0.01	0.007	0	43	40	61.1	135	127	0	35	34
2014	9	1	19	25	14	0.735	-0.095	4.157	0.013	0.01	0	43	40.4	65.4	135	127	0	35	33
2014	9	1	19	35	14	0.764	-0.075	4.157	0.016	0.013	0	43.4	40.4	68.8	136	128	0	35	34
2014	9	1	19	45	14	0.755	-0.075	4.157	0.01	0.007	0	43.9	40.9	73.1	137	129	0	35	34
2014	9	1	19	55	14	0.758	-0.089	4.157	0.01	0.007	0	44.7	42.1	72.2	139	131	0	35	33
2014	9	1	20	5	14	0.728	-0.066	4.157	0.01	0.007	0	44.7	41.7	71.8	139	131	0	35	34
2014	9	1	20	15	14	0.761	-0.112	4.157	0.01	0.007	0	44.7	41.7	69.2	138	130	0	34	33
2014	9	1	20	25	14	0.778	-0.069	4.157	0.01	0.007	0	44.7	41.3	72.7	139	130	0	35	34
2014	9	1	20	35	14	0.771	-0.082	4.16	0.01	0.007	0	44.7	41.7	73.1	139	131	0	35	34
2014	9	1	20	45	14	0.728	-0.066	4.16	0.01	0.007	0	44.7	41.7	73.1	139	131	0	35	34
2014	9	1	20	55	14	0.728	-0.115	4.16	0.01	0.007	0	44.7	42.1	73.1	138	131	0	34	33
2014	9	1	21	5	14	0.728	-0.079	4.16	0.01	0.007	0	44.7	42.1	72.7	139	131	0	35	33
2014	9	1	21	15	14	0.761	-0.105	4.16	0.01	0.007	0	43.9	41.7	72.7	137	130	0	35	33
2014	9	1	21	25	14	0.722	-0.069	4.16	0.01	0.007	0	43.9	40.9	72.2	137	129	0	35	34
2014	9	1	21	35	14	0.745	-0.105	4.16	0.01	0.007	0	43.9	40.4	71.8	137	129	0	35	35
2014	9	1	21	45	14	0.741	-0.062	4.163	0.013	0.01	0	43.9	40.9	71.8	136	129	0	34	34
2014	9	1	21	55	14	0.761	-0.095	4.163	0.01	0.007	0	43.9	40	72.2	137	128	0	35	35
2014	9	1	22	5	14	0.781	-0.079	4.163	0.01	0.007	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	1	22	15	14	0.732	-0.085	4.163	0.01	0.007	0	44.3	41.3	71.8	138	129	0	35	33
2014	9	1	22	25	14	0.745	-0.075	4.167	0.01	0.007	0	44.3	41.3	71.8	138	129	0	35	33
2014	9	1	22	35	14	0.755	-0.092	4.163	0.013	0.01	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	1	22	45	14	0.728	-0.079	4.167	0.01	0.007	0	44.7	41.3	71.8	139	130	0	35	34
2014	9	1	22	55	14	0.761	-0.059	4.167	0.01	0.007	0	44.7	40.9	70.5	139	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	23	5	14	0.764	-0.075	4.167	0.01	0.007	0	44.3	41.3	69.7	138	129	0	35	33
2014	9	1	23	15	14	0.764	-0.062	4.167	0.013	0.01	0	45.6	41.7	71.4	140	130	0	34	33
2014	9	1	23	25	14	0.758	-0.089	4.17	0.013	0.01	0	44.7	41.3	71	139	129	0	35	33
2014	9	1	23	35	14	0.751	-0.089	4.17	0.01	0.007	0	45.2	41.3	71	139	129	0	34	33
2014	9	1	23	45	14	0.751	-0.105	4.173	0.013	0.01	0	43.9	40	70.5	137	127	0	35	34
2014	9	1	23	55	14	0.748	-0.092	4.173	0.01	0.007	0	44.7	40.4	71.4	138	128	0	34	34
2014	9	2	0	5	14	0.719	-0.066	4.177	0.01	0.007	0	45.2	40.9	71.8	139	129	0	34	34
2014	9	2	0	15	14	0.741	-0.046	4.177	0.01	0.007	0	44.7	40.9	72.2	139	128	0	35	33
2014	9	2	0	25	14	0.741	-0.079	4.177	0.01	0.007	0	44.7	40.4	71.4	139	128	0	35	34
2014	9	2	0	35	14	0.741	-0.089	4.177	0.013	0.01	0	44.7	40.4	71.4	139	128	0	35	34
2014	9	2	0	45	14	0.745	-0.092	4.177	0.01	0.007	0	44.3	40.4	72.2	137	127	0	34	33
2014	9	2	0	55	14	0.728	-0.079	4.177	0.01	0.007	0	43.9	40	72.7	137	127	0	35	34
2014	9	2	1	5	14	0.725	-0.072	4.18	0.013	0.01	0	44.3	40.9	72.7	138	128	0	35	33
2014	9	2	1	15	14	0.758	-0.072	4.18	0.013	0.01	0	43.9	40.9	72.7	137	128	0	35	33
2014	9	2	1	25	14	0.728	-0.082	4.18	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	2	1	35	14	0.748	-0.102	4.18	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	2	1	45	14	0.728	-0.092	4.18	0.01	0.007	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	2	1	55	14	0.745	-0.098	4.18	0.013	0.01	0	43.9	40.4	73.5	137	127	0	35	33
2014	9	2	2	5	14	0.751	-0.066	4.18	0.013	0.01	0	44.7	40.9	74	139	129	0	35	34
2014	9	2	2	15	14	0.738	-0.108	4.183	0.01	0.007	0	43.9	40.9	74	137	128	0	35	33
2014	9	2	2	25	14	0.738	-0.085	4.183	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	2	2	35	14	0.732	-0.052	4.183	0.01	0.007	0	43.9	40.4	74	137	127	0	35	33
2014	9	2	2	45	14	0.738	-0.082	4.18	0.01	0.007	0	44.7	40.4	74	139	128	0	35	34
2014	9	2	2	55	14	0.738	-0.075	4.183	0.01	0.007	0	45.6	41.3	74.4	140	129	0	34	33
2014	9	2	3	5	14	0.748	-0.085	4.183	0.01	0.007	0	45.6	41.3	74	140	130	0	34	34
2014	9	2	3	15	14	0.761	-0.062	4.183	0.01	0.007	0	45.2	40.9	74.8	139	128	0	34	33
2014	9	2	3	25	14	0.761	-0.082	4.183	0.01	0.007	0	44.3	40.9	74.8	138	128	0	35	33
2014	9	2	3	35	14	0.748	-0.082	4.183	0.01	0.007	0	44.3	40.9	74.8	138	128	0	35	33
2014	9	2	3	45	14	0.758	-0.089	4.183	0.01	0.007	0	44.7	40	75.3	138	127	0	34	34
2014	9	2	3	55	14	0.755	-0.092	4.183	0.01	0.007	0	44.7	40.4	75.3	138	128	0	34	34
2014	9	2	4	5	14	0.748	-0.075	4.183	0.01	0.007	0	44.7	40.9	74.4	139	128	0	35	33
2014	9	2	4	15	14	0.725	-0.085	4.183	0.01	0.007	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	2	4	25	14	0.751	-0.082	4.186	0.01	0.007	0	43.9	40	75.7	137	127	0	35	34
2014	9	2	4	35	14	0.755	-0.095	4.186	0.01	0.007	0	44.3	40	73.5	137	127	0	34	34
2014	9	2	4	45	14	0.735	-0.082	4.186	0.01	0.007	0	44.3	40.4	75.3	137	127	0	34	33
2014	9	2	4	55	14	0.728	-0.049	4.186	0.01	0.007	0	44.3	40	75.3	137	127	0	34	34
2014	9	2	5	5	14	0.745	-0.072	4.186	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	2	5	15	14	0.741	-0.059	4.186	0.01	0.007	0	43.9	40	75.3	137	127	0	35	34
2014	9	2	5	25	14	0.745	-0.079	4.186	0.013	0.01	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	2	5	35	14	0.771	-0.108	4.19	0.013	0.01	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	2	5	45	14	0.771	-0.092	4.19	0.01	0.007	0	43.9	40.4	74.4	137	127	0	35	33
2014	9	2	5	55	14	0.745	-0.082	4.19	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	2	6	5	14	0.719	-0.079	4.19	0.013	0.01	0	46.4	42.6	73.1	142	133	0	34	34
2014	9	2	6	15	14	0.751	-0.079	4.19	0.01	0.007	0	44.7	41.3	73.1	139	130	0	35	34
2014	9	2	6	25	14	0.725	-0.079	4.19	0.013	0.01	0	44.7	40.9	73.5	138	129	0	34	34
2014	9	2	6	35	14	0.722	-0.098	4.19	0.01	0.007	0	45.2	41.3	73.1	140	130	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	6	45	14	0.741	-0.072	4.193	0.013	0.01	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	2	6	55	14	0.732	-0.049	4.193	0.013	0.01	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	2	7	5	14	0.748	-0.069	4.193	0.01	0.007	0	43	39.6	73.5	135	126	0	35	34
2014	9	2	7	15	14	0.699	-0.066	4.193	0.01	0.007	0	42.6	39.6	73.5	134	126	0	35	34
2014	9	2	7	25	14	0.751	-0.066	4.193	0.01	0.007	0	42.6	39.6	73.5	134	126	0	35	34
2014	9	2	7	35	14	0.771	-0.095	4.193	0.01	0.007	0	43	39.6	73.5	134	126	0	34	34
2014	9	2	7	45	14	0.755	-0.089	4.193	0.01	0.007	0	42.1	39.1	73.5	133	125	0	35	34
2014	9	2	7	55	14	0.732	-0.052	4.193	0.01	0.007	0	42.6	39.1	73.5	134	125	0	35	34
2014	9	2	8	5	14	0.735	-0.062	4.193	0.01	0.007	0	43	39.6	73.1	134	126	0	34	34
2014	9	2	8	15	14	0.745	-0.098	4.193	0.01	0.007	0	43	40	73.5	134	126	0	34	33
2014	9	2	8	25	14	0.768	-0.079	4.193	0.01	0.007	0	42.6	39.1	74	134	125	0	35	34
2014	9	2	8	35	14	0.758	-0.082	4.193	0.01	0.007	0	42.1	39.1	73.5	133	125	0	35	34
2014	9	2	8	45	14	0.758	-0.085	4.193	0.01	0.007	0	42.6	39.1	73.5	134	125	0	35	34
2014	9	2	8	55	14	0.768	-0.115	4.193	0.01	0.007	0	42.1	39.6	74	133	125	0	35	33
2014	9	2	9	5	14	0.748	-0.075	4.193	0.013	0.01	0	42.6	39.6	73.1	133	125	0	34	33
2014	9	2	9	15	14	0.755	-0.082	4.193	0.01	0.007	0	42.1	39.6	73.1	133	125	0	35	33
2014	9	2	9	25	14	0.725	-0.089	4.193	0.01	0.007	0	42.1	39.1	74	133	125	0	35	34
2014	9	2	9	35	14	0.748	-0.128	4.193	0.01	0.007	0	42.1	39.6	74	133	125	0	35	33
2014	9	2	9	45	14	0.745	-0.098	4.193	0.013	0.01	0	42.6	39.1	74	133	125	0	34	34
2014	9	2	9	55	14	0.778	-0.098	4.19	0.01	0.007	0	42.1	39.1	74.4	133	125	0	35	34
2014	9	2	10	5	14	0.755	-0.148	4.193	0.01	0.007	0	41.7	38.7	74	132	124	0	35	34
2014	9	2	10	15	14	0.732	-0.135	4.193	0.01	0.007	0	42.1	39.1	71.8	133	124	0	35	33
2014	9	2	10	25	14	0.758	-0.144	4.19	0.01	0.007	0	41.7	38.7	74	132	124	0	35	34
2014	9	2	10	35	14	0.748	-0.118	4.19	0.013	0.01	0	41.7	38.3	64.5	132	123	0	35	34
2014	9	2	10	45	14	0.755	-0.128	4.19	0.013	0.01	0	41.7	39.1	67.9	132	124	0	35	33
2014	9	2	10	55	14	0.738	-0.135	4.19	0.01	0.007	0	41.7	39.1	64.5	132	125	0	35	34
2014	9	2	11	5	14	0.741	-0.125	4.19	0.01	0.007	0	41.7	38.7	72.7	132	124	0	35	34
2014	9	2	11	15	14	0.719	-0.148	4.19	0.01	0.007	0	41.3	38.7	71	131	123	0	35	33
2014	9	2	11	25	14	0.745	-0.154	4.19	0.013	0.01	0	41.3	38.7	73.5	131	124	0	35	34
2014	9	2	11	35	14	0.784	-0.131	4.19	0.01	0.007	0	41.3	38.3	64.1	131	123	0	35	34
2014	9	2	11	45	14	0.755	-0.128	4.19	0.01	0.007	0	41.3	38.3	57.2	131	123	0	35	34
2014	9	2	11	55	14	0.738	-0.141	4.19	0.01	0.007	0	41.3	38.7	61.5	131	124	0	35	34
2014	9	2	12	5	14	0.732	-0.135	4.19	0.013	0.01	0	41.7	39.1	57.2	131	124	0	34	33
2014	9	2	12	15	14	0.741	-0.177	4.19	0.013	0.01	0	41.3	38.7	56.8	131	124	0	35	34
2014	9	2	12	25	14	0.745	-0.128	4.19	0.013	0.01	0	41.3	39.1	61.5	131	124	0	35	33
2014	9	2	12	35	14	0.689	-0.148	4.19	0.013	0.01	0	41.3	39.1	52.9	131	124	0	35	33
2014	9	2	12	45	14	0.738	-0.108	4.19	0.013	0.01	0	40.9	39.1	55.5	131	124	0	36	33
2014	9	2	12	55	14	0.764	-0.112	4.19	0.01	0.007	0	41.7	39.6	52.9	131	125	0	34	33
2014	9	2	13	5	14	0.735	-0.148	4.19	0.01	0.007	0	42.1	39.6	50.3	132	125	0	34	33
2014	9	2	13	15	14	0.728	-0.115	4.186	0.013	0.01	0	42.1	39.6	51.2	132	125	0	34	33
2014	9	2	13	25	14	0.732	-0.135	4.186	0.013	0.01	0	42.1	39.6	52	132	125	0	34	33
2014	9	2	13	35	14	0.712	-0.131	4.186	0.016	0.013	0	41.7	39.1	49	132	125	0	35	34
2014	9	2	13	45	14	0.738	-0.167	4.186	0.013	0.01	0	41.7	39.1	49.9	132	125	0	35	34
2014	9	2	13	55	14	0.728	-0.161	4.186	0.013	0.01	0	41.7	39.1	49	132	125	0	35	34
2014	9	2	14	5	14	0.728	-0.161	4.186	0.01	0.007	0	41.7	39.6	50.7	132	126	0	35	34
2014	9	2	14	15	14	0.761	-0.154	4.183	0.01	0.007	0	42.1	39.6	50.7	132	126	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	14	25	14	0.719	-0.18	4.183	0.013	0.01	0	42.6	39.1	52	133	125	0	34	34
2014	9	2	14	35	14	0.735	-0.187	4.18	0.01	0.007	0	43.4	40	51.2	136	126	0	35	33
2014	9	2	14	45	14	0.715	-0.148	4.183	0.01	0.007	0	43.4	39.6	49.9	136	126	0	35	34
2014	9	2	14	55	14	0.715	-0.148	4.183	0.01	0.007	0	43.4	39.6	52.5	136	126	0	35	34
2014	9	2	15	5	14	0.745	-0.164	4.18	0.013	0.01	0	43.9	40.9	50.3	137	128	0	35	33
2014	9	2	15	15	14	0.738	-0.157	4.18	0.01	0.007	0	43.9	40.9	49.9	137	128	0	35	33
2014	9	2	15	25	14	0.755	-0.141	4.18	0.01	0.007	0	43.9	40	52.9	136	127	0	34	34
2014	9	2	15	35	14	0.748	-0.151	4.18	0.01	0.007	0	43.9	40.4	50.7	136	127	0	34	33
2014	9	2	15	45	14	0.735	-0.089	4.177	0.01	0.007	0	43.4	40	51.2	136	127	0	35	34
2014	9	2	15	55	14	0.732	-0.148	4.18	0.01	0.007	0	43.9	40.9	50.3	137	129	0	35	34
2014	9	2	16	5	14	0.741	-0.167	4.177	0.01	0.007	0	43.4	40.4	49.9	136	128	0	35	34
2014	9	2	16	15	14	0.728	-0.085	4.177	0.01	0.007	0	43.9	40.4	52	136	128	0	34	34
2014	9	2	16	25	14	0.728	-0.138	4.177	0.013	0.01	0	43.9	40	48.2	136	127	0	34	34
2014	9	2	16	35	14	0.712	-0.138	4.177	0.013	0.01	0	43.9	40.9	49.5	137	129	0	35	34
2014	9	2	16	45	14	0.741	-0.112	4.177	0.01	0.007	0	44.3	40.4	52	137	128	0	34	34
2014	9	2	16	55	14	0.735	-0.131	4.177	0.01	0.007	0	43.9	40.4	49	137	128	0	35	34
2014	9	2	17	5	14	0.755	-0.135	4.177	0.013	0.01	0	44.3	40.4	49.9	137	128	0	34	34
2014	9	2	17	15	14	0.758	-0.112	4.177	0.01	0.007	0	43.9	40	51.2	136	127	0	34	34
2014	9	2	17	25	14	0.761	-0.144	4.177	0.01	0.007	0	43.4	40.4	49.9	136	127	0	35	33
2014	9	2	17	35	14	0.738	-0.118	4.177	0.013	0.01	0	43.9	40	52	136	127	0	34	34
2014	9	2	17	45	14	0.725	-0.135	4.173	0.01	0.007	0	43.4	40.4	51.6	136	127	0	35	33
2014	9	2	17	55	14	0.774	-0.154	4.177	0.016	0.013	0	43.4	40	49.5	136	127	0	35	34
2014	9	2	18	5	14	0.745	-0.128	4.173	0.01	0.007	0	43.9	40.4	50.7	137	128	0	35	34
2014	9	2	18	15	14	0.774	-0.112	4.177	0.013	0.01	0	43.4	40.4	51.2	136	127	0	35	33
2014	9	2	18	25	14	0.771	-0.141	4.173	0.01	0.007	0	48.2	45.2	55	147	138	0	35	33
2014	9	2	18	35	14	0.741	-0.128	4.177	0.016	0.013	0	43	40	51.2	135	127	0	35	34
2014	9	2	18	45	14	0.758	-0.131	4.177	0.01	0.007	0	43	40	55.9	135	127	0	35	34
2014	9	2	18	55	14	0.745	-0.082	4.18	0.01	0.007	0	43	40	55.5	135	127	0	35	34
2014	9	2	19	5	14	0.751	-0.082	4.18	0.01	0.007	0	43.4	40.9	60.6	136	128	0	35	33
2014	9	2	19	15	14	0.771	-0.095	4.18	0.016	0.013	0	43.9	40.9	62.4	136	128	0	34	33
2014	9	2	19	25	14	0.722	-0.102	4.18	0.01	0.007	0	43.9	40.4	66.7	137	128	0	35	34
2014	9	2	19	35	14	0.741	-0.105	4.18	0.013	0.01	0	43.9	41.3	72.2	137	129	0	35	33
2014	9	2	19	45	14	0.771	-0.092	4.18	0.01	0.007	0	44.3	41.3	72.7	138	130	0	35	34
2014	9	2	19	55	14	0.745	-0.072	4.18	0.016	0.013	0	43.9	41.3	71.8	137	130	0	35	34
2014	9	2	20	5	14	0.748	-0.112	4.183	0.01	0.007	0	44.7	41.7	73.5	139	131	0	35	34
2014	9	2	20	15	14	0.738	-0.059	4.183	0.013	0.01	0	44.3	41.3	74	138	130	0	35	34
2014	9	2	20	25	14	0.748	-0.085	4.183	0.01	0.007	0	45.2	41.3	74.4	139	130	0	34	34
2014	9	2	20	35	14	0.738	-0.082	4.183	0.01	0.007	0	44.3	41.3	74.4	138	129	0	35	33
2014	9	2	20	45	14	0.728	-0.092	4.183	0.016	0.016	0	43.9	41.7	74.4	137	130	0	35	33
2014	9	2	20	55	14	0.748	-0.108	4.183	0.013	0.01	0	44.3	40.9	74	138	129	0	35	34
2014	9	2	21	5	14	0.725	-0.079	4.183	0.01	0.007	0	43.9	41.3	74.8	137	129	0	35	33
2014	9	2	21	15	14	0.764	-0.095	4.186	0.01	0.007	0	45.6	41.7	75.3	140	130	0	34	33
2014	9	2	21	25	14	0.728	-0.079	4.183	0.016	0.013	0	45.6	42.1	74.8	140	131	0	34	33
2014	9	2	21	35	14	0.748	-0.075	4.186	0.01	0.007	0	44.3	41.3	74.8	138	130	0	35	34
2014	9	2	21	45	14	0.741	-0.062	4.186	0.01	0.007	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	2	21	55	14	0.751	-0.089	4.186	0.01	0.007	0	43.9	40.4	75.3	136	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	22	5	14	0.712	-0.062	4.186	0.01	0.007	0	44.7	41.3	75.3	138	129	0	34	33
2014	9	2	22	15	14	0.712	-0.075	4.186	0.016	0.013	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	2	22	25	14	0.728	-0.066	4.186	0.01	0.007	0	44.3	40.9	75.7	138	129	0	35	34
2014	9	2	22	35	14	0.745	-0.089	4.186	0.016	0.013	0	44.7	40.9	75.7	138	129	0	34	34
2014	9	2	22	45	14	0.728	-0.066	4.186	0.01	0.007	0	44.3	40.9	75.7	138	129	0	35	34
2014	9	2	22	55	14	0.745	-0.102	4.186	0.01	0.007	0	44.7	40.4	76.1	139	129	0	35	35
2014	9	2	23	5	14	0.778	-0.112	4.19	0.01	0.007	0	44.7	40.4	76.5	138	128	0	34	34
2014	9	2	23	15	14	0.725	-0.079	4.186	0.01	0.007	0	44.3	40.9	75.7	138	128	0	35	33
2014	9	2	23	25	14	0.748	-0.092	4.19	0.01	0.007	0	44.7	40.4	76.1	139	128	0	35	34
2014	9	2	23	35	14	0.748	-0.075	4.19	0.013	0.01	0	44.3	41.3	76.1	138	129	0	35	33
2014	9	2	23	45	14	0.755	-0.069	4.19	0.01	0.007	0	44.7	41.3	76.1	139	129	0	35	33
2014	9	2	23	55	14	0.738	-0.082	4.19	0.01	0.007	0	44.7	40.9	76.1	139	129	0	35	34
2014	9	3	0	5	14	0.745	-0.072	4.19	0.01	0.007	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	3	0	15	14	0.771	-0.102	4.19	0.01	0.007	0	45.6	41.7	74	141	131	0	35	34
2014	9	3	0	25	14	0.761	-0.062	4.19	0.01	0.007	0	43.9	40.4	74.8	137	128	0	35	34
2014	9	3	0	35	14	0.745	-0.092	4.19	0.01	0.007	0	45.2	41.3	75.7	140	130	0	35	34
2014	9	3	0	45	14	0.745	-0.062	4.19	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	3	0	55	14	0.705	-0.052	4.19	0.016	0.013	0	44.7	40.9	75.3	138	128	0	34	33
2014	9	3	1	5	14	0.738	-0.092	4.19	0.01	0.007	0	43	40	74	135	126	0	35	33
2014	9	3	1	15	14	0.728	-0.079	4.19	0.01	0.007	0	45.2	41.3	73.1	140	129	0	35	33
2014	9	3	1	25	14	0.732	-0.092	4.19	0.01	0.007	0	44.3	41.3	74.8	138	128	0	35	32
2014	9	3	1	35	14	0.725	-0.079	4.19	0.01	0.007	0	44.3	40.4	74.4	137	127	0	34	33
2014	9	3	1	45	14	0.738	-0.069	4.19	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	3	1	55	14	0.761	-0.085	4.19	0.016	0.016	0	44.3	40.4	74.8	138	127	0	35	33
2014	9	3	2	5	14	0.738	-0.069	4.19	0.013	0.01	0	43.9	40.4	74.4	138	127	0	36	33
2014	9	3	2	15	14	0.741	-0.082	4.19	0.013	0.01	0	43.9	40.4	74	137	127	0	35	33
2014	9	3	2	25	14	0.745	-0.089	4.19	0.01	0.007	0	44.3	40.9	74	138	128	0	35	33
2014	9	3	2	35	14	0.725	-0.072	4.193	0.01	0.007	0	44.3	40	73.5	137	127	0	34	34
2014	9	3	2	45	14	0.732	-0.112	4.193	0.01	0.007	0	43.9	40.4	74.4	137	127	0	35	33
2014	9	3	2	55	14	0.758	-0.095	4.193	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	3	3	5	14	0.758	-0.056	4.193	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	3	3	15	14	0.748	-0.085	4.193	0.01	0.007	0	43.4	40	73.1	136	126	0	35	33
2014	9	3	3	25	14	0.755	-0.108	4.196	0.013	0.01	0	43.4	40	74	136	126	0	35	33
2014	9	3	3	35	14	0.768	-0.089	4.193	0.01	0.007	0	44.3	40	73.1	137	127	0	34	34
2014	9	3	3	45	14	0.741	-0.098	4.193	0.013	0.01	0	43.9	40	74	137	127	0	35	34
2014	9	3	3	55	14	0.728	-0.072	4.193	0.01	0.007	0	43.4	39.6	73.5	136	126	0	35	34
2014	9	3	4	5	14	0.761	-0.079	4.193	0.01	0.007	0	43.9	40.4	74	137	127	0	35	33
2014	9	3	4	15	14	0.745	-0.082	4.196	0.01	0.007	0	44.3	40.4	71.4	137	127	0	34	33
2014	9	3	4	25	14	0.732	-0.066	4.196	0.01	0.007	0	44.3	40	73.1	138	127	0	35	34
2014	9	3	4	35	14	0.755	-0.085	4.196	0.01	0.007	0	44.3	40.4	68.4	138	127	0	35	33
2014	9	3	4	45	14	0.761	-0.082	4.196	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	3	4	55	14	0.758	-0.085	4.196	0.013	0.01	0	44.7	40.4	72.7	138	127	0	34	33
2014	9	3	5	5	14	0.745	-0.095	4.196	0.01	0.007	0	44.3	40	72.2	138	127	0	35	34
2014	9	3	5	15	14	0.725	-0.066	4.196	0.01	0.007	0	45.6	40.9	71.8	140	129	0	34	34
2014	9	3	5	25	14	0.745	-0.089	4.196	0.01	0.007	0	44.7	40.9	71.8	139	128	0	35	33
2014	9	3	5	35	14	0.719	-0.089	4.196	0.013	0.01	0	47.3	42.6	70.5	144	133	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	5	45	14	0.725	-0.056	4.199	0.016	0.013	0	46.9	43	69.7	144	134	0	35	34
2014	9	3	5	55	14	0.745	-0.095	4.199	0.01	0.007	0	45.6	42.1	70.5	141	132	0	35	34
2014	9	3	6	5	14	0.748	-0.066	4.199	0.01	0.007	0	44.7	40.9	71	139	129	0	35	34
2014	9	3	6	15	14	0.738	-0.049	4.199	0.01	0.007	0	45.6	41.7	69.7	141	131	0	35	34
2014	9	3	6	25	14	0.755	-0.059	4.199	0.01	0.007	0	46	42.6	68.8	142	133	0	35	34
2014	9	3	6	35	14	0.748	-0.052	4.199	0.01	0.007	0	44.7	40.9	70.5	139	129	0	35	34
2014	9	3	6	45	14	0.745	-0.105	4.203	0.01	0.007	0	45.2	40.9	71	139	129	0	34	34
2014	9	3	6	55	14	0.712	-0.105	4.203	0.01	0.007	0	44.3	41.3	70.1	138	129	0	35	33
2014	9	3	7	5	14	0.755	-0.085	4.206	0.013	0.01	0	43.9	40.4	71	137	127	0	35	33
2014	9	3	7	15	14	0.751	-0.062	4.206	0.01	0.007	0	44.3	40	71.4	137	127	0	34	34
2014	9	3	7	25	14	0.732	-0.059	4.206	0.01	0.007	0	43	39.6	71	135	126	0	35	34
2014	9	3	7	35	14	0.745	-0.089	4.209	0.01	0.007	0	42.6	39.6	71.8	134	125	0	35	33
2014	9	3	7	45	14	0.745	-0.098	4.209	0.013	0.01	0	43	39.1	72.2	135	125	0	35	34
2014	9	3	7	55	14	0.748	-0.052	4.209	0.013	0.01	0	43.4	39.1	72.7	135	125	0	34	34
2014	9	3	8	5	14	0.755	-0.108	4.209	0.016	0.013	0	43	39.6	72.2	134	125	0	34	33
2014	9	3	8	15	14	0.755	-0.095	4.209	0.01	0.007	0	43	39.1	72.2	135	125	0	35	34
2014	9	3	8	25	14	0.741	-0.102	4.209	0.01	0.007	0	43	39.1	72.7	135	125	0	35	34
2014	9	3	8	35	14	0.738	-0.052	4.209	0.01	0.007	0	42.6	39.1	72.2	135	125	0	36	34
2014	9	3	8	45	14	0.751	-0.098	4.206	0.01	0.007	0	43	39.6	71.8	135	125	0	35	33
2014	9	3	8	55	14	0.758	-0.092	4.206	0.013	0.01	0	43	38.7	72.2	134	124	0	34	34
2014	9	3	9	5	14	0.738	-0.098	4.206	0.01	0.007	0	43	39.1	72.2	135	125	0	35	34
2014	9	3	9	15	14	0.758	-0.079	4.203	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	3	9	25	14	0.735	-0.095	4.199	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	3	9	35	14	0.725	-0.095	4.199	0.01	0.007	0	42.6	39.6	72.2	134	125	0	35	33
2014	9	3	9	45	14	0.741	-0.079	4.199	0.013	0.01	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	3	9	55	14	0.748	-0.128	4.199	0.01	0.007	0	42.6	39.6	72.2	134	125	0	35	33
2014	9	3	10	5	14	0.758	-0.089	4.199	0.01	0.007	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	3	10	15	14	0.768	-0.089	4.199	0.01	0.007	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	3	10	25	14	0.748	-0.092	4.199	0.01	0.007	0	43.4	39.1	72.7	135	125	0	34	34
2014	9	3	10	35	14	0.764	-0.085	4.199	0.013	0.01	0	42.6	39.1	73.1	134	125	0	35	34
2014	9	3	10	45	14	0.745	-0.115	4.199	0.01	0.007	0	42.6	39.1	73.1	134	125	0	35	34
2014	9	3	10	55	14	0.771	-0.125	4.199	0.01	0.007	0	42.1	38.7	73.5	133	124	0	35	34
2014	9	3	11	5	14	0.778	-0.128	4.196	0.016	0.013	0	42.6	38.7	74	133	124	0	34	34
2014	9	3	11	15	14	0.748	-0.128	4.196	0.016	0.013	0	42.6	38.7	73.1	134	124	0	35	34
2014	9	3	11	25	14	0.748	-0.085	4.196	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	3	11	35	14	0.738	-0.092	4.196	0.013	0.01	0	43.4	40	74	135	126	0	34	33
2014	9	3	11	45	14	0.741	-0.098	4.196	0.013	0.01	0	43	39.6	70.5	135	126	0	35	34
2014	9	3	11	55	14	0.761	-0.105	4.196	0.013	0.01	0	43.4	40	73.5	135	126	0	34	33
2014	9	3	12	5	14	0.712	-0.128	4.196	0.016	0.013	0	43	39.6	73.1	134	125	0	34	33
2014	9	3	12	15	14	0.751	-0.105	4.193	0.013	0.01	0	42.6	39.1	74	134	125	0	35	34
2014	9	3	12	25	14	0.741	-0.098	4.196	0.013	0.01	0	43	39.6	73.5	134	125	0	34	33
2014	9	3	12	35	14	0.751	-0.128	4.196	0.01	0.007	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	3	12	45	14	0.755	-0.141	4.193	0.01	0.007	0	42.6	38.7	74.8	133	124	0	34	34
2014	9	3	12	55	14	0.774	-0.128	4.193	0.01	0.007	0	42.6	39.1	75.3	133	125	0	34	34
2014	9	3	13	5	14	0.745	-0.128	4.193	0.013	0.01	0	42.1	39.1	72.2	133	124	0	35	33
2014	9	3	13	15	14	0.745	-0.138	4.193	0.01	0.007	0	43	39.6	67.1	134	126	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	13	25	14	0.732	-0.128	4.193	0.01	0.007	0	42.1	39.1	64.1	133	125	0	35	34
2014	9	3	13	35	14	0.722	-0.102	4.193	0.01	0.007	0	48.2	45.6	50.3	147	139	0	35	33
2014	9	3	13	45	14	0.702	-0.138	4.193	0.01	0.007	0	45.6	42.1	63.6	141	132	0	35	34
2014	9	3	13	55	14	0.728	-0.164	4.19	0.01	0.007	0	41.3	39.1	59.8	132	124	0	36	33
2014	9	3	14	5	14	0.732	-0.167	4.19	0.01	0.007	0	42.6	38.7	66.2	133	124	0	34	34
2014	9	3	14	15	14	0.741	-0.138	4.19	0.01	0.007	0	41.7	39.1	72.7	132	124	0	35	33
2014	9	3	14	25	14	0.748	-0.157	4.193	0.01	0.007	0	42.6	38.7	54.6	133	124	0	34	34
2014	9	3	14	35	14	0.728	-0.177	4.19	0.01	0.007	0	42.1	39.1	54.6	133	124	0	35	33
2014	9	3	14	45	14	0.745	-0.128	4.19	0.013	0.01	0	42.6	39.6	55.5	134	125	0	35	33
2014	9	3	14	55	14	0.738	-0.148	4.19	0.01	0.007	0	42.6	40	55	134	126	0	35	33
2014	9	3	15	5	14	0.738	-0.148	4.19	0.01	0.007	0	42.6	40	57.6	134	126	0	35	33
2014	9	3	15	15	14	0.738	-0.128	4.186	0.01	0.007	0	43	40.4	56.3	135	127	0	35	33
2014	9	3	15	25	14	0.745	-0.154	4.186	0.013	0.01	0	43	40.4	55	135	127	0	35	33
2014	9	3	15	35	14	0.758	-0.128	4.186	0.01	0.007	0	43.4	40	57.2	135	126	0	34	33
2014	9	3	15	45	14	0.741	-0.187	4.186	0.01	0.007	0	43	39.6	53.8	134	126	0	34	34
2014	9	3	15	55	14	0.755	-0.151	4.186	0.01	0.007	0	43	40	52	135	127	0	35	34
2014	9	3	16	5	14	0.728	-0.118	4.186	0.01	0.007	0	43	40	52	135	126	0	35	33
2014	9	3	16	15	14	0.712	-0.161	4.186	0.01	0.007	0	43.4	40.4	51.2	136	128	0	35	34
2014	9	3	16	25	14	0.712	-0.177	4.186	0.01	0.007	0	43	40.4	51.2	135	127	0	35	33
2014	9	3	16	35	14	0.741	-0.131	4.186	0.01	0.007	0	43.9	40.4	49.9	136	127	0	34	33
2014	9	3	16	45	14	0.755	-0.157	4.186	0.013	0.01	0	43	40.4	49.9	135	128	0	35	34
2014	9	3	16	55	14	0.722	-0.125	4.186	0.01	0.007	0	42.6	39.6	52.5	135	126	0	36	34
2014	9	3	17	5	14	0.758	-0.161	4.183	0.01	0.007	0	43.4	40.4	52	135	127	0	34	33
2014	9	3	17	15	14	0.725	-0.148	4.183	0.013	0.01	0	43	40	51.6	135	126	0	35	33
2014	9	3	17	25	14	0.741	-0.167	4.183	0.013	0.01	0	43	39.6	51.6	135	126	0	35	34
2014	9	3	17	35	14	0.745	-0.131	4.183	0.01	0.007	0	42.6	40	54.6	134	126	0	35	33
2014	9	3	17	45	14	0.764	-0.144	4.186	0.013	0.01	0	42.6	39.6	58.9	134	126	0	35	34
2014	9	3	17	55	14	0.751	-0.138	4.183	0.01	0.007	0	42.6	39.1	55.5	134	125	0	35	34
2014	9	3	18	5	14	0.738	-0.098	4.186	0.01	0.007	0	42.6	39.6	62.8	134	125	0	35	33
2014	9	3	18	15	14	0.751	-0.121	4.183	0.013	0.01	0	42.6	39.1	55.9	134	125	0	35	34
2014	9	3	18	25	14	0.745	-0.141	4.183	0.01	0.007	0	42.1	39.6	60.2	133	125	0	35	33
2014	9	3	18	35	14	0.774	-0.144	4.186	0.01	0.007	0	42.1	39.1	67.9	134	125	0	36	34
2014	9	3	18	45	14	0.725	-0.082	4.186	0.013	0.01	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	3	18	55	14	0.741	-0.095	4.186	0.01	0.007	0	43.4	40.4	74	136	127	0	35	33
2014	9	3	19	5	14	0.732	-0.112	4.186	0.013	0.01	0	43.4	40.4	74.4	136	127	0	35	33
2014	9	3	19	15	14	0.728	-0.089	4.186	0.013	0.01	0	43.4	40	74.8	136	127	0	35	34
2014	9	3	19	25	14	0.748	-0.079	4.186	0.013	0.01	0	43.9	40	75.7	137	127	0	35	34
2014	9	3	19	35	14	0.745	-0.092	4.186	0.013	0.01	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	3	19	45	14	0.768	-0.079	4.186	0.013	0.01	0	44.3	40.9	76.1	138	129	0	35	34
2014	9	3	19	55	14	0.741	-0.095	4.186	0.016	0.013	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	3	20	5	14	0.751	-0.105	4.186	0.013	0.01	0	44.3	40.9	74	138	128	0	35	33
2014	9	3	20	15	14	0.728	-0.098	4.186	0.01	0.007	0	44.3	40.9	74	138	129	0	35	34
2014	9	3	20	25	14	0.728	-0.079	4.19	0.013	0.01	0	44.7	41.7	76.1	139	130	0	35	33
2014	9	3	20	35	14	0.751	-0.095	4.19	0.013	0.01	0	44.7	41.3	75.7	139	130	0	35	34
2014	9	3	20	45	14	0.755	-0.095	4.19	0.01	0.007	0	44.7	41.7	74	139	130	0	35	33
2014	9	3	20	55	14	0.745	-0.059	4.19	0.01	0.007	0	44.7	40.4	75.3	138	128	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	21	5	14	0.722	-0.098	4.19	0.01	0.007	0	44.7	41.3	74.8	139	130	0	35	34
2014	9	3	21	15	14	0.751	-0.089	4.19	0.01	0.007	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	3	21	25	14	0.751	-0.056	4.19	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	3	21	35	14	0.738	-0.059	4.19	0.01	0.007	0	44.7	41.7	76.5	139	130	0	35	33
2014	9	3	21	45	14	0.764	-0.085	4.19	0.01	0.007	0	44.7	41.3	76.1	139	130	0	35	34
2014	9	3	21	55	14	0.741	-0.079	4.19	0.016	0.013	0	45.2	40.9	75.7	139	129	0	34	34
2014	9	3	22	5	14	0.732	-0.098	4.19	0.01	0.007	0	45.2	41.3	75.7	139	129	0	34	33
2014	9	3	22	15	14	0.738	-0.082	4.19	0.01	0.007	0	44.7	41.3	75.7	139	129	0	35	33
2014	9	3	22	25	14	0.741	-0.056	4.19	0.01	0.007	0	45.6	41.3	75.7	140	130	0	34	34
2014	9	3	22	35	14	0.735	-0.066	4.19	0.01	0.007	0	45.2	41.3	75.3	140	130	0	35	34
2014	9	3	22	45	14	0.738	-0.069	4.19	0.013	0.01	0	44.7	40.9	75.7	138	128	0	34	33
2014	9	3	22	55	14	0.761	-0.062	4.19	0.013	0.01	0	43.9	40.4	75.7	138	128	0	36	34
2014	9	3	23	5	14	0.715	-0.085	4.19	0.01	0.007	0	44.7	40.4	75.3	139	128	0	35	34
2014	9	3	23	15	14	0.735	-0.082	4.19	0.01	0.007	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	3	23	25	14	0.732	-0.092	4.193	0.01	0.007	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	3	23	35	14	0.764	-0.049	4.193	0.01	0.007	0	44.3	40.4	75.3	137	127	0	34	33
2014	9	3	23	45	14	0.745	-0.066	4.193	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	3	23	55	14	0.735	-0.062	4.193	0.016	0.013	0	44.3	40	75.3	138	127	0	35	34
2014	9	4	0	5	14	0.748	-0.095	4.19	0.01	0.007	0	44.7	40.4	67.9	138	128	0	34	34
2014	9	4	0	15	14	0.764	-0.098	4.193	0.01	0.007	0	44.7	41.3	74.8	139	129	0	35	33
2014	9	4	0	25	14	0.735	-0.072	4.193	0.01	0.007	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	4	0	35	14	0.735	-0.079	4.193	0.013	0.01	0	44.7	40.9	75.7	139	128	0	35	33
2014	9	4	0	45	14	0.728	-0.052	4.193	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	4	0	55	14	0.764	-0.049	4.193	0.013	0.01	0	44.7	40.9	74.4	138	128	0	34	33
2014	9	4	1	5	14	0.781	-0.066	4.193	0.013	0.01	0	44.3	40.4	74.8	138	127	0	35	33
2014	9	4	1	15	14	0.761	-0.085	4.193	0.01	0.007	0	44.3	40.9	74.8	138	128	0	35	33
2014	9	4	1	25	14	0.755	-0.092	4.193	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	4	1	35	14	0.735	-0.089	4.193	0.01	0.007	0	45.2	40.4	74	138	128	0	33	34
2014	9	4	1	45	14	0.748	-0.092	4.193	0.013	0.01	0	43.9	40.4	74.4	137	127	0	35	33
2014	9	4	1	55	14	0.761	-0.095	4.193	0.013	0.01	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	4	2	5	14	0.748	-0.072	4.193	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	4	2	15	14	0.751	-0.049	4.193	0.01	0.007	0	45.2	41.3	74	140	130	0	35	34
2014	9	4	2	25	14	0.761	-0.082	4.193	0.01	0.007	0	44.7	40.9	73.1	139	129	0	35	34
2014	9	4	2	35	14	0.745	-0.049	4.193	0.01	0.007	0	46.4	43.4	74	143	134	0	35	33
2014	9	4	2	45	14	0.764	-0.085	4.193	0.013	0.01	0	44.7	40.9	74	139	129	0	35	34
2014	9	4	2	55	14	0.728	-0.082	4.193	0.01	0.007	0	44.7	40.9	74	139	129	0	35	34
2014	9	4	3	5	14	0.751	-0.033	4.193	0.01	0.007	0	44.3	40.4	74	138	128	0	35	34
2014	9	4	3	15	14	0.771	-0.095	4.196	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	4	3	25	14	0.758	-0.095	4.193	0.01	0.007	0	44.3	40.4	66.2	137	127	0	34	33
2014	9	4	3	35	14	0.745	-0.089	4.196	0.013	0.01	0	43.9	40	73.5	137	127	0	35	34
2014	9	4	3	45	14	0.755	-0.095	4.196	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	4	3	55	14	0.758	-0.079	4.196	0.01	0.007	0	44.3	39.6	74	137	126	0	34	34
2014	9	4	4	5	14	0.771	-0.092	4.196	0.01	0.007	0	43.9	39.6	73.1	137	126	0	35	34
2014	9	4	4	15	14	0.755	-0.085	4.196	0.01	0.007	0	43.9	40.4	72.7	137	127	0	35	33
2014	9	4	4	25	14	0.761	-0.092	4.199	0.01	0.007	0	44.3	40	73.1	138	127	0	35	34
2014	9	4	4	35	14	0.768	-0.089	4.196	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	4	45	14	0.774	-0.079	4.199	0.013	0.01	0	44.3	40.9	71.8	138	128	0	35	33
2014	9	4	4	55	14	0.761	-0.112	4.199	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	4	5	5	14	0.748	-0.092	4.199	0.01	0.007	0	44.3	40	72.2	138	127	0	35	34
2014	9	4	5	15	14	0.748	-0.092	4.199	0.013	0.01	0	44.3	40.4	71.8	138	127	0	35	33
2014	9	4	5	25	14	0.758	-0.098	4.203	0.013	0.01	0	45.6	41.3	66.7	140	130	0	34	34
2014	9	4	5	35	14	0.751	-0.066	4.199	0.01	0.007	0	44.7	40.9	71.4	139	128	0	35	33
2014	9	4	5	45	14	0.755	-0.085	4.199	0.013	0.01	0	45.2	40.9	71	140	129	0	35	34
2014	9	4	5	55	14	0.758	-0.049	4.199	0.01	0.007	0	44.3	40.4	71	138	128	0	35	34
2014	9	4	6	5	14	0.745	-0.085	4.203	0.013	0.01	0	45.6	41.7	71.4	141	130	0	35	33
2014	9	4	6	15	14	0.745	-0.082	4.203	0.01	0.007	0	46.4	42.6	70.1	143	132	0	35	33
2014	9	4	6	25	14	0.748	-0.082	4.203	0.01	0.007	0	44.7	41.3	71	140	130	0	36	34
2014	9	4	6	35	14	0.735	-0.066	4.203	0.013	0.01	0	44.7	41.3	71.8	139	129	0	35	33
2014	9	4	6	45	14	0.755	-0.082	4.203	0.013	0.01	0	44.7	40.9	71	139	129	0	35	34
2014	9	4	6	55	14	0.732	-0.102	4.203	0.013	0.01	0	44.7	40.9	70.5	138	128	0	34	33
2014	9	4	7	5	14	0.741	-0.056	4.203	0.01	0.007	0	44.3	40.9	70.5	138	128	0	35	33
2014	9	4	7	15	14	0.728	-0.105	4.203	0.013	0.01	0	43.9	40.4	69.7	137	127	0	35	33
2014	9	4	7	25	14	0.732	-0.069	4.203	0.01	0.007	0	43.4	40	71.4	136	126	0	35	33
2014	9	4	7	35	14	0.735	-0.095	4.206	0.013	0.01	0	43.9	40	71.4	136	126	0	34	33
2014	9	4	7	45	14	0.741	-0.079	4.206	0.01	0.007	0	43.4	39.6	71	136	126	0	35	34
2014	9	4	7	55	14	0.751	-0.115	4.206	0.01	0.007	0	43	40	71	135	126	0	35	33
2014	9	4	8	5	14	0.758	-0.082	4.206	0.01	0.007	0	43.4	39.6	70.1	136	126	0	35	34
2014	9	4	8	15	14	0.732	-0.075	4.206	0.013	0.01	0	43	39.6	67.5	135	125	0	35	33
2014	9	4	8	25	14	0.745	-0.089	4.206	0.01	0.007	0	43	39.6	59.8	135	125	0	35	33
2014	9	4	8	35	14	0.732	-0.059	4.203	0.016	0.013	0	43.4	39.6	58	136	126	0	35	34
2014	9	4	8	45	14	0.761	-0.089	4.206	0.01	0.007	0	43	39.6	58	135	126	0	35	34
2014	9	4	8	55	14	0.741	-0.108	4.203	0.01	0.007	0	43	39.6	60.6	135	126	0	35	34
2014	9	4	9	5	14	0.719	-0.089	4.206	0.01	0.007	0	43	39.6	71	135	126	0	35	34
2014	9	4	9	15	14	0.741	-0.082	4.203	0.01	0.007	0	43	40	71	135	126	0	35	33
2014	9	4	9	25	14	0.758	-0.095	4.203	0.013	0.01	0	43.4	40	71.4	136	126	0	35	33
2014	9	4	9	35	14	0.745	-0.082	4.199	0.01	0.007	0	43	39.6	71.4	135	126	0	35	34
2014	9	4	9	45	14	0.761	-0.105	4.199	0.013	0.01	0	43.4	40	71.4	136	126	0	35	33
2014	9	4	9	55	14	0.722	-0.115	4.199	0.013	0.01	0	43.4	40	71.4	135	126	0	34	33
2014	9	4	10	5	14	0.784	-0.098	4.199	0.01	0.007	0	43	40	71.4	135	126	0	35	33
2014	9	4	10	15	14	0.761	-0.112	4.199	0.01	0.007	0	43	39.1	58.9	135	125	0	35	34
2014	9	4	10	25	14	0.751	-0.098	4.199	0.01	0.007	0	43.9	39.6	71.4	136	126	0	34	34
2014	9	4	10	35	14	0.764	-0.135	4.199	0.013	0.01	0	43	39.1	70.1	134	125	0	34	34
2014	9	4	10	45	14	0.761	-0.089	4.199	0.016	0.013	0	43	40	72.2	135	126	0	35	33
2014	9	4	10	55	14	0.755	-0.112	4.199	0.01	0.007	0	43	40	72.2	135	126	0	35	33
2014	9	4	11	5	14	0.758	-0.131	4.199	0.013	0.01	0	42.6	39.1	73.5	134	125	0	35	34
2014	9	4	11	15	14	0.761	-0.121	4.199	0.01	0.007	0	42.1	39.6	74	134	125	0	36	33
2014	9	4	11	25	14	0.751	-0.115	4.199	0.01	0.007	0	42.6	39.6	73.1	134	126	0	35	34
2014	9	4	11	35	14	0.735	-0.082	4.199	0.01	0.007	0	43	39.6	71	134	125	0	34	33
2014	9	4	11	45	14	0.745	-0.138	4.199	0.01	0.007	0	42.6	40.4	74	134	126	0	35	32
2014	9	4	11	55	14	0.741	-0.148	4.199	0.01	0.007	0	42.1	39.1	69.2	133	125	0	35	34
2014	9	4	12	5	14	0.745	-0.108	4.199	0.01	0.007	0	42.6	39.6	69.7	133	125	0	34	33
2014	9	4	12	15	14	0.764	-0.144	4.196	0.013	0.01	0	42.6	39.6	73.1	133	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	12	25	14	0.732	-0.213	4.196	0.013	0.01	0	42.1	38.7	73.1	132	124	0	34	34
2014	9	4	12	35	14	0.741	-0.177	4.196	0.01	0.007	0	41.3	39.1	63.6	131	124	0	35	33
2014	9	4	12	45	14	0.745	-0.118	4.196	0.01	0.007	0	42.1	39.1	71	132	125	0	34	34
2014	9	4	12	55	14	0.728	-0.18	4.196	0.01	0.007	0	41.3	38.7	66.2	131	124	0	35	34
2014	9	4	13	5	14	0.764	-0.161	4.196	0.013	0.01	0	41.7	39.6	62.8	131	125	0	34	33
2014	9	4	13	15	14	0.738	-0.141	4.196	0.013	0.01	0	41.3	39.1	61.1	130	124	0	34	33
2014	9	4	13	25	14	0.755	-0.164	4.196	0.01	0.007	0	40.9	38.7	69.2	130	124	0	35	34
2014	9	4	13	35	14	0.712	-0.184	4.196	0.013	0.01	0	40.9	38.7	58	130	124	0	35	34
2014	9	4	13	45	14	0.712	-0.197	4.193	0.01	0.007	0	41.3	39.1	61.9	130	124	0	34	33
2014	9	4	13	55	14	0.758	-0.138	4.193	0.013	0.01	0	40.9	39.1	64.5	130	124	0	35	33
2014	9	4	14	5	14	0.761	-0.164	4.196	0.01	0.007	0	41.7	39.1	75.7	131	125	0	34	34
2014	9	4	14	15	14	0.732	-0.174	4.193	0.016	0.016	0	41.7	39.6	56.8	131	125	0	34	33
2014	9	4	14	25	14	0.725	-0.197	4.193	0.013	0.01	0	41.3	39.1	53.3	131	125	0	35	34
2014	9	4	14	35	14	0.738	-0.18	4.193	0.01	0.007	0	41.7	39.6	52	132	126	0	35	34
2014	9	4	14	45	14	0.732	-0.167	4.193	0.01	0.007	0	41.7	39.6	61.5	131	126	0	34	34
2014	9	4	14	55	14	0.725	-0.203	4.193	0.01	0.007	0	41.3	39.1	63.6	131	125	0	35	34
2014	9	4	15	5	14	0.725	-0.18	4.193	0.01	0.007	0	42.1	40	55.9	133	127	0	35	34
2014	9	4	15	15	14	0.719	-0.194	4.193	0.01	0.007	0	41.7	40	52.5	132	126	0	35	33
2014	9	4	15	25	14	0.719	-0.177	4.193	0.016	0.013	0	42.6	40.4	56.3	133	127	0	34	33
2014	9	4	15	35	14	0.738	-0.161	4.19	0.01	0.007	0	42.6	40	58.5	133	127	0	34	34
2014	9	4	15	45	14	0.738	-0.135	4.193	0.01	0.007	0	42.1	40.4	53.3	133	127	0	35	33
2014	9	4	15	55	14	0.722	-0.18	4.19	0.01	0.007	0	42.1	40.4	54.6	133	127	0	35	33
2014	9	4	16	5	14	0.712	-0.125	4.193	0.01	0.007	0	42.1	40	62.8	133	126	0	35	33
2014	9	4	16	15	14	0.722	-0.141	4.19	0.01	0.007	0	42.1	40.4	58.5	133	127	0	35	33
2014	9	4	16	25	14	0.712	-0.148	4.19	0.01	0.007	0	41.7	39.6	52	132	126	0	35	34
2014	9	4	16	35	14	0.709	-0.171	4.19	0.01	0.007	0	42.6	40.4	53.3	134	127	0	35	33
2014	9	4	16	45	14	0.728	-0.144	4.19	0.01	0.007	0	43	40.4	55	134	128	0	34	34
2014	9	4	16	55	14	0.719	-0.154	4.19	0.01	0.007	0	42.6	40.4	52	134	127	0	35	33
2014	9	4	17	5	14	0.705	-0.148	4.19	0.013	0.01	0	42.1	40	54.2	133	127	0	35	34
2014	9	4	17	15	14	0.728	-0.154	4.19	0.01	0.007	0	41.7	40	64.1	132	126	0	35	33
2014	9	4	17	25	14	0.735	-0.161	4.19	0.01	0.007	0	41.3	39.6	60.6	131	125	0	35	33
2014	9	4	17	35	14	0.735	-0.131	4.19	0.013	0.01	0	41.7	39.6	69.2	131	125	0	34	33
2014	9	4	17	45	14	0.755	-0.108	4.19	0.01	0.007	0	42.1	39.6	61.1	132	125	0	34	33
2014	9	4	17	55	14	0.761	-0.125	4.19	0.01	0.007	0	41.7	38.7	59.3	131	124	0	34	34
2014	9	4	18	5	14	0.778	-0.125	4.19	0.01	0.007	0	41.3	39.1	67.1	131	125	0	35	34
2014	9	4	18	15	14	0.735	-0.121	4.19	0.013	0.01	0	41.7	39.1	64.9	132	125	0	35	34
2014	9	4	18	25	14	0.741	-0.18	4.19	0.013	0.01	0	42.1	39.6	72.7	132	125	0	34	33
2014	9	4	18	35	14	0.778	-0.121	4.19	0.013	0.01	0	41.7	40	71	132	126	0	35	33
2014	9	4	18	45	14	0.761	-0.131	4.193	0.013	0.01	0	42.1	39.6	68.8	132	125	0	34	33
2014	9	4	18	55	14	0.728	-0.098	4.19	0.01	0.007	0	42.1	39.6	74.8	133	126	0	35	34
2014	9	4	19	5	14	0.771	-0.108	4.19	0.01	0.007	0	42.1	40	74.8	133	126	0	35	33
2014	9	4	19	15	14	0.732	-0.118	4.193	0.013	0.01	0	42.6	39.6	74.8	134	126	0	35	34
2014	9	4	19	25	14	0.728	-0.092	4.193	0.01	0.007	0	43	40.4	74.4	135	127	0	35	33
2014	9	4	19	35	14	0.745	-0.082	4.193	0.01	0.007	0	43.9	41.3	74.4	137	129	0	35	33
2014	9	4	19	45	14	0.728	-0.069	4.193	0.01	0.007	0	43.9	40.9	74.4	137	129	0	35	34
2014	9	4	19	55	14	0.732	-0.102	4.193	0.01	0.007	0	44.3	41.3	74	137	129	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	20	5	14	0.755	-0.069	4.193	0.01	0.007	0	44.7	41.7	74	138	130	0	34	33
2014	9	4	20	15	14	0.761	-0.062	4.193	0.01	0.007	0	45.6	42.1	74	141	131	0	35	33
2014	9	4	20	25	14	0.761	-0.052	4.193	0.01	0.007	0	45.6	41.7	74	141	130	0	35	33
2014	9	4	20	35	14	0.741	-0.079	4.193	0.01	0.007	0	45.2	41.3	74.4	139	129	0	34	33
2014	9	4	20	45	14	0.732	-0.082	4.193	0.01	0.007	0	44.7	41.3	74	139	129	0	35	33
2014	9	4	20	55	14	0.768	-0.112	4.196	0.01	0.007	0	45.2	41.3	74.4	140	129	0	35	33
2014	9	4	21	5	14	0.751	-0.082	4.196	0.01	0.007	0	44.7	40.9	74.4	139	128	0	35	33
2014	9	4	21	15	14	0.768	-0.066	4.196	0.01	0.007	0	44.7	41.3	73.5	139	129	0	35	33
2014	9	4	21	25	14	0.725	-0.066	4.196	0.013	0.01	0	45.2	41.3	74	139	129	0	34	33
2014	9	4	21	35	14	0.715	-0.072	4.196	0.01	0.007	0	44.7	40.4	74	138	127	0	34	33
2014	9	4	21	45	14	0.745	-0.082	4.196	0.013	0.01	0	44.7	40.4	59.8	138	127	0	34	33
2014	9	4	21	55	14	0.764	-0.085	4.196	0.01	0.007	0	43.4	40	73.1	136	126	0	35	33
2014	9	4	22	5	14	0.741	-0.039	4.196	0.01	0.007	0	44.3	40	73.5	138	127	0	35	34
2014	9	4	22	15	14	0.719	-0.079	4.196	0.01	0.007	0	44.7	40.4	73.5	138	127	0	34	33
2014	9	4	22	25	14	0.778	-0.069	4.196	0.016	0.013	0	43.9	40	72.7	137	127	0	35	34
2014	9	4	22	35	14	0.741	-0.049	4.196	0.013	0.01	0	44.3	40	73.5	137	127	0	34	34
2014	9	4	22	45	14	0.778	-0.075	4.199	0.01	0.007	0	43.9	40.4	73.1	137	127	0	35	33
2014	9	4	22	55	14	0.732	-0.098	4.199	0.01	0.007	0	43.4	39.6	72.7	136	126	0	35	34
2014	9	4	23	5	14	0.755	-0.092	4.199	0.01	0.007	0	44.3	40	73.1	137	127	0	34	34
2014	9	4	23	15	14	0.764	-0.082	4.199	0.016	0.013	0	44.3	40	73.5	138	127	0	35	34
2014	9	4	23	25	14	0.764	-0.098	4.199	0.013	0.01	0	43.9	40	73.1	137	126	0	35	33
2014	9	4	23	35	14	0.738	-0.092	4.199	0.01	0.007	0	43.9	39.6	73.1	137	126	0	35	34
2014	9	4	23	45	14	0.741	-0.062	4.199	0.01	0.007	0	44.3	39.6	72.2	137	126	0	34	34
2014	9	4	23	55	14	0.755	-0.082	4.199	0.01	0.007	0	44.7	40.4	72.2	138	127	0	34	33
2014	9	5	0	5	14	0.778	-0.069	4.199	0.01	0.007	0	43.9	39.6	72.2	137	126	0	35	34
2014	9	5	0	15	14	0.748	-0.072	4.199	0.013	0.01	0	44.3	39.6	72.2	137	126	0	34	34
2014	9	5	0	25	14	0.784	-0.089	4.199	0.01	0.007	0	44.3	40	72.2	137	126	0	34	33
2014	9	5	0	35	14	0.768	-0.082	4.199	0.01	0.007	0	43.9	40	72.2	137	126	0	35	33
2014	9	5	0	45	14	0.748	-0.062	4.203	0.013	0.01	0	43.9	39.6	71.4	137	126	0	35	34
2014	9	5	0	55	14	0.761	-0.092	4.203	0.013	0.01	0	43.4	40	72.2	136	126	0	35	33
2014	9	5	1	5	14	0.755	-0.092	4.203	0.013	0.01	0	44.3	39.6	71.8	137	126	0	34	34
2014	9	5	1	15	14	0.722	-0.108	4.203	0.013	0.01	0	43.4	39.6	71.8	136	126	0	35	34
2014	9	5	1	25	14	0.745	-0.092	4.203	0.01	0.007	0	43.4	39.6	71.8	136	126	0	35	34
2014	9	5	1	35	14	0.741	-0.095	4.203	0.013	0.01	0	43.4	40	71.8	136	126	0	35	33
2014	9	5	1	45	14	0.768	-0.105	4.203	0.013	0.01	0	43.9	39.6	71.4	136	126	0	34	34
2014	9	5	1	55	14	0.758	-0.115	4.203	0.013	0.01	0	43.9	40	70.5	137	127	0	35	34
2014	9	5	2	5	14	0.771	-0.082	4.206	0.01	0.007	0	44.3	40.4	71.4	137	127	0	34	33
2014	9	5	2	15	14	0.761	-0.052	4.206	0.01	0.007	0	43.9	40.4	70.5	137	127	0	35	33
2014	9	5	2	25	14	0.741	-0.062	4.213	0.01	0.007	0	43.4	39.6	71.8	136	126	0	35	34
2014	9	5	2	35	14	0.719	-0.089	4.213	0.016	0.013	0	43.4	39.6	71.8	136	125	0	35	33
2014	9	5	2	45	14	0.791	-0.089	4.216	0.01	0.007	0	43.4	39.6	72.2	136	125	0	35	33
2014	9	5	2	55	14	0.758	-0.066	4.216	0.01	0.007	0	44.3	40	72.7	137	127	0	34	34
2014	9	5	3	5	14	0.758	-0.072	4.216	0.01	0.007	0	43.9	40	74	136	126	0	34	33
2014	9	5	3	15	14	0.761	-0.075	4.216	0.01	0.007	0	43.4	39.6	74.4	136	125	0	35	33
2014	9	5	3	25	14	0.745	-0.079	4.216	0.01	0.007	0	43.4	39.1	63.2	136	125	0	35	34
2014	9	5	3	35	14	0.732	-0.069	4.216	0.013	0.01	0	44.7	41.3	71	139	129	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	3	45	14	0.761	-0.069	4.219	0.01	0.007	0	44.3	40.4	74.4	138	127	0	35	33
2014	9	5	3	55	14	0.761	-0.098	4.219	0.013	0.01	0	44.3	40	74.8	137	126	0	34	33
2014	9	5	4	5	14	0.758	-0.089	4.219	0.013	0.01	0	43.4	39.6	75.7	136	126	0	35	34
2014	9	5	4	15	14	0.745	-0.079	4.219	0.01	0.007	0	44.3	39.6	74.4	137	126	0	34	34
2014	9	5	4	25	14	0.758	-0.098	4.219	0.013	0.01	0	43.9	40	74	136	126	0	34	33
2014	9	5	4	35	14	0.748	-0.082	4.219	0.013	0.01	0	44.3	40	73.5	137	126	0	34	33
2014	9	5	4	45	14	0.755	-0.092	4.219	0.013	0.01	0	44.3	40.9	71.4	138	128	0	35	33
2014	9	5	4	55	14	0.722	-0.125	4.219	0.013	0.01	0	42.6	40.4	73.5	134	127	0	35	33
2014	9	5	5	5	14	0.764	-0.095	4.219	0.01	0.007	0	43.9	39.6	61.5	137	126	0	35	34
2014	9	5	5	15	14	0.732	-0.075	4.219	0.01	0.007	0	44.3	40	74	138	127	0	35	34
2014	9	5	5	25	14	0.751	-0.082	4.219	0.01	0.007	0	45.2	41.3	74.4	140	129	0	35	33
2014	9	5	5	35	14	0.741	-0.095	4.219	0.01	0.007	0	45.2	40.9	74.4	140	129	0	35	34
2014	9	5	5	45	14	0.764	-0.108	4.222	0.013	0.01	0	45.2	40.9	74.4	139	129	0	34	34
2014	9	5	5	55	14	0.761	-0.095	4.222	0.01	0.007	0	45.2	40.9	75.3	140	129	0	35	34
2014	9	5	6	5	14	0.758	-0.075	4.222	0.01	0.007	0	45.2	40.4	75.7	139	128	0	34	34
2014	9	5	6	15	14	0.768	-0.095	4.222	0.01	0.007	0	45.2	41.3	75.7	140	130	0	35	34
2014	9	5	6	25	14	0.791	-0.092	4.222	0.013	0.01	0	46	42.6	75.3	142	132	0	35	33
2014	9	5	6	35	14	0.755	-0.082	4.222	0.013	0.01	0	45.6	41.3	75.3	141	130	0	35	34
2014	9	5	6	45	14	0.735	-0.089	4.222	0.01	0.007	0	45.2	41.3	75.7	140	129	0	35	33
2014	9	5	6	55	14	0.758	-0.085	4.222	0.01	0.007	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	5	7	5	14	0.741	-0.089	4.222	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	5	7	15	14	0.774	-0.075	4.222	0.01	0.007	0	44.3	40	76.5	137	127	0	34	34
2014	9	5	7	25	14	0.745	-0.056	4.222	0.01	0.007	0	43.9	40	76.1	137	127	0	35	34
2014	9	5	7	35	14	0.761	-0.072	4.222	0.013	0.01	0	44.7	40.4	76.1	139	128	0	35	34
2014	9	5	7	45	14	0.758	-0.082	4.222	0.013	0.01	0	43.9	40	75.7	137	127	0	35	34
2014	9	5	7	55	14	0.761	-0.066	4.222	0.01	0.007	0	43.9	40	75.7	137	127	0	35	34
2014	9	5	8	5	14	0.738	-0.085	4.226	0.016	0.013	0	43.9	39.6	76.1	137	126	0	35	34
2014	9	5	8	15	14	0.745	-0.079	4.226	0.01	0.007	0	44.3	40.4	77	137	127	0	34	33
2014	9	5	8	25	14	0.791	-0.095	4.226	0.01	0.007	0	43.4	40	76.5	136	126	0	35	33
2014	9	5	8	35	14	0.774	-0.069	4.226	0.01	0.007	0	43.9	40.4	76.5	137	127	0	35	33
2014	9	5	8	45	14	0.738	-0.059	4.226	0.01	0.007	0	43.4	40	76.5	136	126	0	35	33
2014	9	5	8	55	14	0.768	-0.072	4.222	0.01	0.007	0	43.4	39.6	76.1	136	126	0	35	34
2014	9	5	9	5	14	0.761	-0.105	4.222	0.013	0.01	0	43.4	39.6	76.5	136	126	0	35	34
2014	9	5	9	15	14	0.725	-0.082	4.222	0.01	0.007	0	43.4	39.6	74.4	136	126	0	35	34
2014	9	5	9	25	14	0.804	-0.112	4.226	0.01	0.007	0	43.4	39.1	74	135	125	0	34	34
2014	9	5	9	35	14	0.728	-0.105	4.222	0.013	0.01	0	43.4	40	56.8	136	126	0	35	33
2014	9	5	9	45	14	0.748	-0.095	4.222	0.013	0.01	0	43	40	60.6	135	126	0	35	33
2014	9	5	9	55	14	0.768	-0.112	4.222	0.013	0.01	0	43.4	39.1	66.7	135	125	0	34	34
2014	9	5	10	5	14	0.755	-0.102	4.222	0.01	0.007	0	43	40	63.2	135	126	0	35	33
2014	9	5	10	15	14	0.764	-0.118	4.222	0.01	0.007	0	43	39.6	64.5	135	125	0	35	33
2014	9	5	10	25	14	0.758	-0.112	4.222	0.01	0.007	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	5	10	35	14	0.741	-0.125	4.222	0.01	0.007	0	42.1	38.7	70.5	133	124	0	35	34
2014	9	5	10	45	14	0.791	-0.115	4.222	0.013	0.01	0	42.6	39.1	66.2	134	125	0	35	34
2014	9	5	10	55	14	0.735	-0.131	4.222	0.01	0.007	0	42.1	39.1	58.9	133	124	0	35	33
2014	9	5	11	5	14	0.761	-0.144	4.222	0.01	0.007	0	42.1	39.6	60.6	133	125	0	35	33
2014	9	5	11	15	14	0.755	-0.157	4.222	0.016	0.013	0	42.1	39.1	74	133	124	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	11	25	14	0.755	-0.125	4.222	0.01	0.007	0	42.6	39.6	62.8	134	125	0	35	33
2014	9	5	11	35	14	0.774	-0.128	4.222	0.013	0.01	0	43	39.6	63.6	135	126	0	35	34
2014	9	5	11	45	14	0.781	-0.112	4.222	0.01	0.007	0	43	39.6	63.6	135	126	0	35	34
2014	9	5	11	55	14	0.761	-0.144	4.219	0.016	0.013	0	42.6	39.6	60.2	134	125	0	35	33
2014	9	5	12	5	14	0.725	-0.138	4.222	0.016	0.013	0	42.1	38.7	70.5	133	124	0	35	34
2014	9	5	12	15	14	0.755	-0.112	4.219	0.01	0.007	0	42.6	39.1	61.5	134	125	0	35	34
2014	9	5	12	25	14	0.751	-0.131	4.219	0.01	0.007	0	42.1	39.1	64.9	133	125	0	35	34
2014	9	5	12	35	14	0.758	-0.148	4.219	0.01	0.007	0	42.1	38.7	56.8	133	124	0	35	34
2014	9	5	12	45	14	0.771	-0.135	4.219	0.01	0.007	0	41.7	38.7	56.3	132	124	0	35	34
2014	9	5	12	55	14	0.741	-0.174	4.219	0.013	0.01	0	42.1	39.1	52.5	133	124	0	35	33
2014	9	5	13	5	14	0.761	-0.105	4.216	0.013	0.01	0	42.1	39.1	52.9	133	125	0	35	34
2014	9	5	13	15	14	0.755	-0.184	4.216	0.01	0.007	0	42.6	39.1	50.3	133	125	0	34	34
2014	9	5	13	25	14	0.738	-0.18	4.213	0.01	0.007	0	42.1	39.1	49.9	133	125	0	35	34
2014	9	5	13	35	14	0.741	-0.18	4.213	0.016	0.013	0	42.6	39.6	50.7	133	125	0	34	33
2014	9	5	13	45	14	0.738	-0.157	4.213	0.01	0.007	0	42.6	39.1	51.2	134	125	0	35	34
2014	9	5	13	55	14	0.725	-0.174	4.216	0.01	0.007	0	43	39.6	51.6	134	126	0	34	34
2014	9	5	14	5	14	0.745	-0.131	4.213	0.01	0.007	0	43	39.6	51.2	134	126	0	34	34
2014	9	5	14	15	14	0.748	-0.174	4.213	0.01	0.007	0	43	39.6	51.2	134	126	0	34	34
2014	9	5	14	25	14	0.722	-0.161	4.213	0.013	0.01	0	43	39.6	51.6	134	126	0	34	34
2014	9	5	14	35	14	0.761	-0.144	4.209	0.013	0.01	0	42.6	39.6	49.9	134	126	0	35	34
2014	9	5	14	45	14	0.774	-0.131	4.209	0.01	0.007	0	43	39.6	52.5	135	126	0	35	34
2014	9	5	14	55	14	0.761	-0.171	4.209	0.013	0.01	0	43	39.6	51.6	134	126	0	34	34
2014	9	5	15	5	14	0.768	-0.138	4.206	0.013	0.01	0	42.6	39.6	53.3	134	126	0	35	34
2014	9	5	15	15	14	0.728	-0.148	4.209	0.013	0.01	0	43	40	49	134	126	0	34	33
2014	9	5	15	25	14	0.722	-0.174	4.209	0.01	0.007	0	43	40	51.6	135	127	0	35	34
2014	9	5	15	35	14	0.758	-0.161	4.206	0.01	0.007	0	43.9	40.4	50.7	136	127	0	34	33
2014	9	5	15	45	14	0.738	-0.184	4.209	0.016	0.013	0	43.4	40.4	50.3	136	128	0	35	34
2014	9	5	15	55	14	0.748	-0.128	4.209	0.01	0.007	0	43	40	50.7	135	127	0	35	34
2014	9	5	16	5	14	0.761	-0.131	4.206	0.01	0.007	0	43.4	40.4	50.7	136	128	0	35	34
2014	9	5	16	15	14	0.725	-0.089	4.206	0.013	0.01	0	43.4	40.4	52.5	136	128	0	35	34
2014	9	5	16	25	14	0.751	-0.161	4.206	0.01	0.007	0	43.4	40.4	49	136	128	0	35	34
2014	9	5	16	35	14	0.764	-0.128	4.206	0.01	0.007	0	43.9	40	49.9	136	127	0	34	34
2014	9	5	16	45	14	0.781	-0.174	4.206	0.013	0.01	0	43.4	40	51.6	136	127	0	35	34
2014	9	5	16	55	14	0.778	-0.138	4.206	0.01	0.007	0	43.4	40.4	50.3	136	128	0	35	34
2014	9	5	17	5	14	0.748	-0.118	4.206	0.01	0.007	0	43.4	40.9	49.9	136	128	0	35	33
2014	9	5	17	15	14	0.758	-0.154	4.206	0.01	0.007	0	43	40	49.5	135	127	0	35	34
2014	9	5	17	25	14	0.764	-0.135	4.203	0.01	0.007	0	43.4	39.6	51.6	135	126	0	34	34
2014	9	5	17	35	14	0.735	-0.131	4.206	0.016	0.013	0	43	40	51.2	135	126	0	35	33
2014	9	5	17	45	14	0.774	-0.131	4.206	0.01	0.007	0	43	40	50.3	135	126	0	35	33
2014	9	5	17	55	14	0.755	-0.128	4.203	0.01	0.007	0	43	39.1	54.6	134	125	0	34	34
2014	9	5	18	5	14	0.774	-0.144	4.203	0.01	0.007	0	42.6	39.1	54.2	134	125	0	35	34
2014	9	5	18	15	14	0.758	-0.135	4.199	0.01	0.007	0	42.6	39.1	65.4	134	125	0	35	34
2014	9	5	18	25	14	0.751	-0.128	4.203	0.01	0.007	0	43	39.6	51.6	135	126	0	35	34
2014	9	5	18	35	14	0.755	-0.102	4.203	0.013	0.01	0	43	40	55	135	126	0	35	33
2014	9	5	18	45	14	0.761	-0.112	4.203	0.01	0.007	0	43	40	67.1	135	126	0	35	33
2014	9	5	18	55	14	0.745	-0.092	4.203	0.01	0.007	0	43.4	40	56.8	136	126	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	19	5	14	0.774	-0.095	4.203	0.01	0.007	0	43.4	40	58.5	136	127	0	35	34
2014	9	5	19	15	14	0.735	-0.095	4.203	0.01	0.007	0	43.4	40	62.8	136	127	0	35	34
2014	9	5	19	25	14	0.764	-0.108	4.203	0.013	0.01	0	43.4	39.6	63.2	136	126	0	35	34
2014	9	5	19	35	14	0.758	-0.102	4.203	0.016	0.013	0	43.9	40.4	61.9	137	128	0	35	34
2014	9	5	19	45	14	0.745	-0.098	4.203	0.01	0.007	0	43.9	40.4	61.9	137	128	0	35	34
2014	9	5	19	55	14	0.787	-0.102	4.203	0.013	0.01	0	44.7	40.9	55.9	138	129	0	34	34
2014	9	5	20	5	14	0.761	-0.062	4.206	0.013	0.01	0	45.6	41.3	54.6	140	130	0	34	34
2014	9	5	20	15	14	0.774	-0.085	4.206	0.01	0.007	0	44.7	41.3	52.5	139	129	0	35	33
2014	9	5	20	25	14	0.748	-0.075	4.209	0.01	0.007	0	45.6	42.1	52	141	132	0	35	34
2014	9	5	20	35	14	0.755	-0.066	4.206	0.01	0.007	0	45.2	41.3	51.6	140	130	0	35	34
2014	9	5	20	45	14	0.745	-0.066	4.209	0.01	0.007	0	44.7	41.3	52.5	139	130	0	35	34
2014	9	5	20	55	14	0.771	-0.102	4.206	0.013	0.01	0	44.3	41.3	55.5	138	129	0	35	33
2014	9	5	21	5	14	0.732	-0.059	4.213	0.013	0.01	0	45.2	41.3	71	139	130	0	34	34
2014	9	5	21	15	14	0.728	-0.092	4.213	0.013	0.01	0	44.7	41.3	71	139	130	0	35	34
2014	9	5	21	25	14	0.755	-0.085	4.213	0.01	0.007	0	44.7	40.9	71	138	129	0	34	34
2014	9	5	21	35	14	0.728	-0.069	4.213	0.016	0.013	0	45.2	41.3	70.5	139	130	0	34	34
2014	9	5	21	45	14	0.774	-0.072	4.213	0.01	0.007	0	45.2	41.3	71	139	130	0	34	34
2014	9	5	21	55	14	0.755	-0.082	4.213	0.013	0.01	0	45.2	41.3	70.1	139	130	0	34	34
2014	9	5	22	5	14	0.761	-0.112	4.216	0.013	0.01	0	45.2	41.7	71.4	140	130	0	35	33
2014	9	5	22	15	14	0.735	-0.098	4.216	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	5	22	25	14	0.761	-0.085	4.213	0.01	0.007	0	44.3	41.3	58.9	138	129	0	35	33
2014	9	5	22	35	14	0.761	-0.062	4.216	0.01	0.007	0	45.2	41.3	69.2	140	130	0	35	34
2014	9	5	22	45	14	0.738	-0.082	4.216	0.01	0.007	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	5	22	55	14	0.778	-0.069	4.216	0.01	0.007	0	44.7	40.4	71	138	128	0	34	34
2014	9	5	23	5	14	0.774	-0.082	4.216	0.013	0.01	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	5	23	15	14	0.761	-0.092	4.216	0.01	0.007	0	44.7	40.9	72.2	138	128	0	34	33
2014	9	5	23	25	14	0.755	-0.095	4.216	0.01	0.007	0	44.3	41.3	72.2	138	129	0	35	33
2014	9	5	23	35	14	0.748	-0.082	4.219	0.01	0.007	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	5	23	45	14	0.774	-0.095	4.219	0.013	0.01	0	44.7	40.4	72.2	138	128	0	34	34
2014	9	5	23	55	14	0.771	-0.095	4.219	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	6	0	5	14	0.748	-0.052	4.219	0.013	0.01	0	44.3	41.3	72.7	138	129	0	35	33
2014	9	6	0	15	14	0.771	-0.075	4.219	0.01	0.007	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	6	0	25	14	0.745	-0.052	4.219	0.013	0.01	0	45.2	40.9	73.1	139	129	0	34	34
2014	9	6	0	35	14	0.728	-0.115	4.219	0.01	0.007	0	44.7	40.4	73.5	139	128	0	35	34
2014	9	6	0	45	14	0.741	-0.072	4.219	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	6	0	55	14	0.748	-0.102	4.219	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	6	1	5	14	0.719	-0.049	4.219	0.01	0.007	0	43.9	40.4	74	137	127	0	35	33
2014	9	6	1	15	14	0.764	-0.092	4.219	0.01	0.007	0	43.9	40.4	74.4	137	128	0	35	34
2014	9	6	1	25	14	0.735	-0.082	4.219	0.013	0.01	0	44.3	40.4	74.4	138	127	0	35	33
2014	9	6	1	35	14	0.755	-0.075	4.219	0.013	0.01	0	44.3	40.4	74	138	128	0	35	34
2014	9	6	1	45	14	0.751	-0.105	4.222	0.01	0.007	0	44.7	40.9	74.8	138	128	0	34	33
2014	9	6	1	55	14	0.755	-0.082	4.219	0.01	0.007	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	6	2	5	14	0.741	-0.072	4.222	0.01	0.007	0	43.9	40.4	75.3	137	127	0	35	33
2014	9	6	2	15	14	0.738	-0.069	4.222	0.01	0.007	0	44.3	40	75.7	137	127	0	34	34
2014	9	6	2	25	14	0.741	-0.082	4.222	0.01	0.007	0	44.7	40.4	75.3	138	128	0	34	34
2014	9	6	2	35	14	0.764	-0.092	4.222	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	2	45	14	0.748	-0.082	4.222	0.01	0.007	0	44.7	40	75.3	138	127	0	34	34
2014	9	6	2	55	14	0.745	-0.075	4.222	0.016	0.013	0	43.9	40.4	75.7	137	127	0	35	33
2014	9	6	3	5	14	0.771	-0.112	4.222	0.016	0.013	0	44.3	40.4	75.3	137	127	0	34	33
2014	9	6	3	15	14	0.768	-0.072	4.222	0.01	0.007	0	44.3	40.4	75.7	137	127	0	34	33
2014	9	6	3	25	14	0.755	-0.089	4.222	0.01	0.007	0	43.4	40	75.3	136	126	0	35	33
2014	9	6	3	35	14	0.761	-0.089	4.222	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	6	3	45	14	0.771	-0.089	4.222	0.01	0.007	0	43.4	39.6	75.7	136	125	0	35	33
2014	9	6	3	55	14	0.748	-0.066	4.222	0.016	0.013	0	43.9	40	75.7	136	126	0	34	33
2014	9	6	4	5	14	0.768	-0.082	4.222	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34
2014	9	6	4	15	14	0.741	-0.092	4.222	0.01	0.007	0	43	40	75.7	136	126	0	36	33
2014	9	6	4	25	14	0.764	-0.052	4.222	0.01	0.007	0	43.4	39.6	75.3	136	126	0	35	34
2014	9	6	4	35	14	0.764	-0.082	4.222	0.01	0.007	0	43.9	40	75.7	137	127	0	35	34
2014	9	6	4	45	14	0.748	-0.075	4.222	0.01	0.007	0	43.9	39.6	74.8	136	126	0	34	34
2014	9	6	4	55	14	0.787	-0.089	4.222	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	6	5	5	14	0.741	-0.112	4.222	0.013	0.01	0	43.9	40.4	74.8	137	127	0	35	33
2014	9	6	5	15	14	0.755	-0.082	4.222	0.013	0.01	0	43.4	40.4	74.8	137	127	0	36	33
2014	9	6	5	25	14	0.741	-0.075	4.222	0.013	0.01	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	6	5	35	14	0.764	-0.095	4.222	0.01	0.007	0	44.7	41.3	74.8	139	129	0	35	33
2014	9	6	5	45	14	0.764	-0.069	4.222	0.01	0.007	0	45.2	41.3	74.4	140	130	0	35	34
2014	9	6	5	55	14	0.764	-0.085	4.222	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	6	6	5	14	0.781	-0.092	4.222	0.01	0.007	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	6	6	15	14	0.764	-0.062	4.222	0.01	0.007	0	43.9	40.4	75.3	137	127	0	35	33
2014	9	6	6	25	14	0.745	-0.082	4.222	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	6	6	35	14	0.761	-0.079	4.222	0.01	0.007	0	45.2	41.3	74.8	139	129	0	34	33
2014	9	6	6	45	14	0.751	-0.102	4.222	0.01	0.007	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	6	6	55	14	0.751	-0.108	4.222	0.01	0.007	0	43.9	40	75.3	136	126	0	34	33
2014	9	6	7	5	14	0.751	-0.092	4.222	0.01	0.007	0	43.4	40	74	136	127	0	35	34
2014	9	6	7	15	14	0.781	-0.075	4.222	0.01	0.007	0	43.9	39.6	74.4	137	127	0	35	35
2014	9	6	7	25	14	0.761	-0.115	4.222	0.01	0.007	0	44.3	40.9	74	139	129	0	36	34
2014	9	6	7	35	14	0.771	-0.069	4.222	0.01	0.007	0	44.7	41.3	74	139	129	0	35	33
2014	9	6	7	45	14	0.771	-0.079	4.222	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	6	7	55	14	0.748	-0.102	4.222	0.013	0.01	0	44.3	40.4	74	138	128	0	35	34
2014	9	6	8	5	14	0.771	-0.079	4.222	0.01	0.007	0	43.9	40	74	137	128	0	35	35
2014	9	6	8	15	14	0.748	-0.085	4.222	0.013	0.01	0	43.4	40	74	136	127	0	35	34
2014	9	6	8	25	14	0.784	-0.095	4.222	0.01	0.007	0	44.3	40	74	137	127	0	34	34
2014	9	6	8	35	14	0.755	-0.082	4.222	0.013	0.01	0	43.4	40	74.4	136	127	0	35	34
2014	9	6	8	45	14	0.768	-0.105	4.222	0.01	0.007	0	43	40	74.8	136	127	0	36	34
2014	9	6	8	55	14	0.748	-0.052	4.222	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	6	9	5	14	0.758	-0.079	4.222	0.01	0.007	0	43	39.6	74.4	135	126	0	35	34
2014	9	6	9	15	14	0.797	-0.075	4.222	0.013	0.01	0	43.4	39.6	74.4	136	126	0	35	34
2014	9	6	9	25	14	0.738	-0.075	4.222	0.01	0.007	0	43.4	39.6	74.8	136	126	0	35	34
2014	9	6	9	35	14	0.761	-0.089	4.222	0.01	0.007	0	43.4	39.6	75.7	136	126	0	35	34
2014	9	6	9	45	14	0.755	-0.105	4.222	0.013	0.01	0	43.4	39.6	74.4	135	126	0	34	34
2014	9	6	9	55	14	0.781	-0.079	4.222	0.01	0.007	0	43	39.6	75.3	135	126	0	35	34
2014	9	6	10	5	14	0.761	-0.105	4.222	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	6	10	15	14	0.787	-0.131	4.222	0.01	0.007	0	42.6	39.6	75.7	134	125	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	10	25	14	0.768	-0.144	4.222	0.01	0.007	0	42.1	38.7	74	133	124	0	35	34
2014	9	6	10	35	14	0.774	-0.125	4.219	0.016	0.013	0	42.6	39.1	65.4	134	125	0	35	34
2014	9	6	10	45	14	0.758	-0.112	4.219	0.01	0.007	0	43.4	40	71.8	135	126	0	34	33
2014	9	6	10	55	14	0.745	-0.112	4.222	0.01	0.007	0	42.6	39.1	75.3	134	125	0	35	34
2014	9	6	11	5	14	0.771	-0.138	4.219	0.013	0.01	0	42.6	39.1	63.2	134	125	0	35	34
2014	9	6	11	15	14	0.751	-0.098	4.219	0.01	0.007	0	43	39.6	58.5	135	126	0	35	34
2014	9	6	11	25	14	0.758	-0.141	4.219	0.01	0.007	0	43	39.1	53.8	135	125	0	35	34
2014	9	6	11	35	14	0.801	-0.138	4.219	0.01	0.007	0	42.6	39.1	56.8	134	125	0	35	34
2014	9	6	11	45	14	0.761	-0.171	4.219	0.01	0.007	0	42.6	38.7	61.1	134	124	0	35	34
2014	9	6	11	55	14	0.758	-0.2	4.219	0.01	0.007	0	42.6	38.7	53.8	134	124	0	35	34
2014	9	6	12	5	14	0.725	-0.128	4.219	0.01	0.007	0	43	39.6	66.2	135	126	0	35	34
2014	9	6	12	15	14	0.758	-0.167	4.219	0.013	0.01	0	43	39.6	48.6	135	126	0	35	34
2014	9	6	12	25	14	0.738	-0.115	4.219	0.01	0.007	0	42.6	39.6	54.2	134	126	0	35	34
2014	9	6	12	35	14	0.787	-0.118	4.219	0.013	0.01	0	43	40.4	54.2	135	127	0	35	33
2014	9	6	12	45	14	0.738	-0.138	4.216	0.01	0.007	0	43	39.6	51.6	135	126	0	35	34
2014	9	6	12	55	14	0.741	-0.151	4.216	0.01	0.007	0	42.6	40	59.3	135	126	0	36	33
2014	9	6	13	5	14	0.755	-0.144	4.216	0.01	0.007	0	43.4	39.6	51.6	135	126	0	34	34
2014	9	6	13	15	14	0.745	-0.148	4.213	0.013	0.01	0	42.6	39.1	48.6	134	125	0	35	34
2014	9	6	13	25	14	0.735	-0.161	4.216	0.01	0.007	0	43	39.6	50.3	135	126	0	35	34
2014	9	6	13	35	14	0.755	-0.144	4.216	0.01	0.007	0	43.4	40	51.6	135	127	0	34	34
2014	9	6	13	45	14	0.751	-0.161	4.213	0.01	0.007	0	43	40	49.5	135	127	0	35	34
2014	9	6	13	55	14	0.768	-0.177	4.213	0.01	0.007	0	43.4	40.4	52	136	127	0	35	33
2014	9	6	14	5	14	0.758	-0.144	4.213	0.01	0.007	0	43.4	40	50.3	136	127	0	35	34
2014	9	6	14	15	14	0.738	-0.144	4.213	0.01	0.007	0	43.4	40.4	49.9	136	127	0	35	33
2014	9	6	14	25	14	0.732	-0.108	4.213	0.013	0.01	0	44.3	40.9	51.2	138	129	0	35	34
2014	9	6	14	35	14	0.722	-0.154	4.209	0.01	0.007	0	43.9	41.3	49.9	137	129	0	35	33
2014	9	6	14	45	14	0.751	-0.154	4.209	0.01	0.007	0	44.3	40.4	48.6	138	129	0	35	35
2014	9	6	14	55	14	0.738	-0.18	4.209	0.01	0.007	0	44.3	40.9	50.3	137	128	0	34	33
2014	9	6	15	5	14	0.764	-0.141	4.209	0.01	0.007	0	43.9	40.9	50.7	137	129	0	35	34
2014	9	6	15	15	14	0.725	-0.19	4.206	0.01	0.007	0	43.9	40.9	49.9	137	129	0	35	34
2014	9	6	15	25	14	0.755	-0.131	4.209	0.01	0.007	0	44.3	40.9	49	138	129	0	35	34
2014	9	6	15	35	14	0.781	-0.135	4.206	0.01	0.007	0	44.3	40.9	50.7	137	128	0	34	33
2014	9	6	15	45	14	0.745	-0.138	4.206	0.01	0.007	0	43.9	40.4	49.9	137	128	0	35	34
2014	9	6	15	55	14	0.748	-0.151	4.203	0.01	0.007	0	43.9	40.4	50.3	137	128	0	35	34
2014	9	6	16	5	14	0.751	-0.131	4.206	0.01	0.007	0	43.9	41.3	52.5	137	129	0	35	33
2014	9	6	16	15	14	0.768	-0.144	4.206	0.013	0.01	0	44.3	40.4	51.6	137	128	0	34	34
2014	9	6	16	25	14	0.738	-0.115	4.206	0.013	0.01	0	43.9	41.3	49.9	137	129	0	35	33
2014	9	6	16	35	14	0.741	-0.082	4.203	0.013	0.01	0	44.3	40.4	52	137	128	0	34	34
2014	9	6	16	45	14	0.761	-0.144	4.203	0.01	0.007	0	44.3	40.4	47.3	137	128	0	34	34
2014	9	6	16	55	14	0.774	-0.118	4.203	0.01	0.007	0	43.9	40.4	49	137	128	0	35	34
2014	9	6	17	5	14	0.774	-0.118	4.203	0.013	0.01	0	43.4	40.4	50.7	136	127	0	35	33
2014	9	6	17	15	14	0.738	-0.154	4.203	0.01	0.007	0	43.4	40	49.5	136	127	0	35	34
2014	9	6	17	25	14	0.745	-0.154	4.203	0.01	0.007	0	43.4	40	49	136	126	0	35	33
2014	9	6	17	35	14	0.768	-0.128	4.199	0.013	0.01	0	43	39.6	51.2	135	126	0	35	34
2014	9	6	17	45	14	0.745	-0.144	4.203	0.01	0.007	0	43.4	39.6	53.8	136	126	0	35	34
2014	9	6	17	55	14	0.738	-0.112	4.203	0.01	0.007	0	43	39.6	52.9	135	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	18	5	14	0.774	-0.157	4.203	0.01	0.007	0	43.4	39.1	49	135	125	0	34	34
2014	9	6	18	15	14	0.771	-0.128	4.203	0.016	0.013	0	43.4	39.6	52	136	126	0	35	34
2014	9	6	18	25	14	0.748	-0.128	4.199	0.01	0.007	0	43	40	52.9	135	126	0	35	33
2014	9	6	18	35	14	0.787	-0.144	4.203	0.01	0.007	0	43.4	39.6	61.5	136	126	0	35	34
2014	9	6	18	45	14	0.774	-0.125	4.203	0.01	0.007	0	43.4	39.6	67.1	135	126	0	34	34
2014	9	6	18	55	14	0.771	-0.128	4.203	0.013	0.01	0	43	39.6	54.2	135	126	0	35	34
2014	9	6	19	5	14	0.755	-0.082	4.203	0.013	0.01	0	43.4	40	52	136	127	0	35	34
2014	9	6	19	15	14	0.738	-0.069	4.203	0.01	0.007	0	43.9	40.4	52.5	137	128	0	35	34
2014	9	6	19	25	14	0.787	-0.115	4.203	0.016	0.016	0	43.4	40.4	50.7	136	127	0	35	33
2014	9	6	19	35	14	0.787	-0.082	4.203	0.01	0.007	0	43.9	40.9	49	137	128	0	35	33
2014	9	6	19	45	14	0.774	-0.066	4.206	0.01	0.007	0	44.7	40.9	52.5	139	129	0	35	34
2014	9	6	19	55	14	0.764	-0.069	4.206	0.013	0.01	0	45.2	41.3	52.5	140	130	0	35	34
2014	9	6	20	5	14	0.761	-0.066	4.206	0.016	0.013	0	44.7	40.9	51.2	139	129	0	35	34
2014	9	6	20	15	14	0.741	-0.082	4.206	0.01	0.007	0	45.2	41.3	49.9	140	130	0	35	34
2014	9	6	20	25	14	0.755	-0.095	4.206	0.01	0.007	0	46	41.3	51.6	141	131	0	34	35
2014	9	6	20	35	14	0.768	-0.062	4.206	0.01	0.007	0	45.2	41.3	52	140	130	0	35	34
2014	9	6	20	45	14	0.755	-0.102	4.206	0.013	0.01	0	44.7	41.3	51.6	139	130	0	35	34
2014	9	6	20	55	14	0.761	-0.115	4.206	0.01	0.007	0	44.7	41.3	51.2	139	130	0	35	34
2014	9	6	21	5	14	0.761	-0.082	4.206	0.01	0.007	0	45.2	41.3	55.9	139	130	0	34	34
2014	9	6	21	15	14	0.764	-0.092	4.213	0.01	0.007	0	44.3	40.4	71.4	138	128	0	35	34
2014	9	6	21	25	14	0.781	-0.092	4.209	0.01	0.007	0	44.7	40.9	64.5	139	129	0	35	34
2014	9	6	21	35	14	0.761	-0.089	4.213	0.01	0.007	0	44.3	40.4	65.8	138	128	0	35	34
2014	9	6	21	45	14	0.804	-0.075	4.213	0.013	0.01	0	44.3	41.3	71	138	129	0	35	33
2014	9	6	21	55	14	0.787	-0.085	4.209	0.01	0.007	0	43.9	40.4	58.9	137	128	0	35	34
2014	9	6	22	5	14	0.761	-0.112	4.209	0.01	0.007	0	43.4	40	56.8	137	127	0	36	34
2014	9	6	22	15	14	0.745	-0.098	4.209	0.013	0.01	0	44.7	41.3	52.9	138	129	0	34	33
2014	9	6	22	25	14	0.755	-0.105	4.209	0.013	0.01	0	44.3	40.4	54.2	138	128	0	35	34
2014	9	6	22	35	14	0.741	-0.082	4.209	0.01	0.007	0	44.7	40.9	60.2	138	129	0	34	34
2014	9	6	22	45	14	0.761	-0.072	4.209	0.01	0.007	0	45.2	41.3	54.2	140	130	0	35	34
2014	9	6	22	55	14	0.774	-0.095	4.213	0.01	0.007	0	44.3	40.9	65.4	138	129	0	35	34
2014	9	6	23	5	14	0.751	-0.072	4.213	0.013	0.01	0	44.3	40.4	72.7	138	128	0	35	34
2014	9	6	23	15	14	0.768	-0.079	4.213	0.01	0.007	0	44.7	41.3	72.7	139	130	0	35	34
2014	9	6	23	25	14	0.774	-0.079	4.213	0.01	0.007	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	6	23	35	14	0.741	-0.066	4.216	0.016	0.013	0	44.7	41.3	72.7	139	130	0	35	34
2014	9	6	23	45	14	0.748	-0.095	4.216	0.013	0.01	0	44.3	41.3	73.5	138	129	0	35	33
2014	9	6	23	55	14	0.801	-0.062	4.216	0.013	0.01	0	44.3	40.9	72.7	138	128	0	35	33
2014	9	7	0	5	14	0.751	-0.098	4.216	0.01	0.007	0	45.6	42.6	72.2	141	132	0	35	33
2014	9	7	0	15	14	0.738	-0.069	4.216	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	7	0	25	14	0.751	-0.095	4.216	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	7	0	35	14	0.751	-0.089	4.216	0.013	0.01	0	43.9	40	72.7	137	127	0	35	34
2014	9	7	0	45	14	0.761	-0.089	4.216	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	7	0	55	14	0.751	-0.105	4.216	0.013	0.01	0	43.9	40	72.7	136	127	0	34	34
2014	9	7	1	5	14	0.787	-0.108	4.216	0.013	0.01	0	43.4	40	72.2	136	127	0	35	34
2014	9	7	1	15	14	0.741	-0.066	4.216	0.013	0.01	0	43.4	40	71.8	136	127	0	35	34
2014	9	7	1	25	14	0.774	-0.062	4.216	0.013	0.01	0	43.9	40	73.5	136	127	0	34	34
2014	9	7	1	35	14	0.764	-0.108	4.216	0.013	0.01	0	43.9	40	73.1	137	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	1	45	14	0.755	-0.066	4.216	0.013	0.01	0	43.4	40.4	73.1	136	127	0	35	33
2014	9	7	1	55	14	0.741	-0.066	4.216	0.01	0.007	0	43.4	40.4	73.1	136	127	0	35	33
2014	9	7	2	5	14	0.764	-0.102	4.216	0.01	0.007	0	43	39.6	74	136	126	0	36	34
2014	9	7	2	15	14	0.745	-0.062	4.216	0.01	0.007	0	43	40	74	136	126	0	36	33
2014	9	7	2	25	14	0.755	-0.085	4.216	0.01	0.007	0	43.4	40	74	136	127	0	35	34
2014	9	7	2	35	14	0.768	-0.066	4.216	0.01	0.007	0	43.4	40	74	136	127	0	35	34
2014	9	7	2	45	14	0.755	-0.095	4.219	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	7	2	55	14	0.741	-0.069	4.216	0.013	0.01	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	7	3	5	14	0.755	-0.092	4.219	0.013	0.01	0	43.4	39.6	73.1	136	126	0	35	34
2014	9	7	3	15	14	0.784	-0.089	4.216	0.01	0.007	0	44.7	40.9	73.5	139	129	0	35	34
2014	9	7	3	25	14	0.728	-0.062	4.219	0.01	0.007	0	43.4	40.4	73.5	136	127	0	35	33
2014	9	7	3	35	14	0.758	-0.062	4.219	0.01	0.007	0	44.3	40.4	74	137	128	0	34	34
2014	9	7	3	45	14	0.748	-0.075	4.219	0.01	0.007	0	43.9	40.4	74.8	136	127	0	34	33
2014	9	7	3	55	14	0.787	-0.085	4.219	0.013	0.01	0	43.9	40.4	74	136	127	0	34	33
2014	9	7	4	5	14	0.732	-0.069	4.219	0.01	0.007	0	43	40	74.8	135	126	0	35	33
2014	9	7	4	15	14	0.755	-0.075	4.219	0.01	0.007	0	43	39.6	74	135	126	0	35	34
2014	9	7	4	25	14	0.758	-0.112	4.219	0.01	0.007	0	43	39.1	74.8	134	125	0	34	34
2014	9	7	4	35	14	0.751	-0.082	4.219	0.01	0.007	0	43	39.6	74.8	135	126	0	35	34
2014	9	7	4	45	14	0.764	-0.082	4.219	0.01	0.007	0	43.9	40	75.7	136	126	0	34	33
2014	9	7	4	55	14	0.761	-0.072	4.219	0.013	0.01	0	43.4	39.6	75.7	136	126	0	35	34
2014	9	7	5	5	14	0.758	-0.082	4.219	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	7	5	15	14	0.764	-0.085	4.219	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	7	5	25	14	0.771	-0.062	4.219	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	7	5	35	14	0.784	-0.079	4.219	0.01	0.007	0	44.7	40.4	75.3	139	128	0	35	34
2014	9	7	5	45	14	0.745	-0.066	4.219	0.016	0.013	0	44.7	40.9	75.7	139	128	0	35	33
2014	9	7	5	55	14	0.741	-0.082	4.219	0.01	0.007	0	44.3	40.9	75.7	138	128	0	35	33
2014	9	7	6	5	14	0.748	-0.075	4.219	0.01	0.007	0	44.3	40	75.7	138	127	0	35	34
2014	9	7	6	15	14	0.735	-0.089	4.219	0.01	0.007	0	44.3	39.6	76.1	137	126	0	34	34
2014	9	7	6	25	14	0.764	-0.062	4.219	0.01	0.007	0	44.3	40	76.1	138	127	0	35	34
2014	9	7	6	35	14	0.758	-0.085	4.219	0.01	0.007	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	7	6	45	14	0.778	-0.095	4.219	0.013	0.01	0	45.2	40.9	75.3	140	129	0	35	34
2014	9	7	6	55	14	0.771	-0.062	4.219	0.013	0.01	0	44.3	40	74.4	138	128	0	35	35
2014	9	7	7	5	14	0.768	-0.066	4.219	0.013	0.01	0	44.7	40.9	74.8	139	128	0	35	33
2014	9	7	7	15	14	0.761	-0.079	4.219	0.01	0.007	0	43.9	40	75.7	137	127	0	35	34
2014	9	7	7	25	14	0.745	-0.082	4.219	0.013	0.01	0	43.9	40.4	75.7	137	127	0	35	33
2014	9	7	7	35	14	0.741	-0.092	4.219	0.01	0.007	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	7	7	45	14	0.774	-0.085	4.219	0.01	0.007	0	43.4	40	75.7	137	126	0	36	33
2014	9	7	7	55	14	0.758	-0.075	4.219	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	7	8	5	14	0.784	-0.079	4.219	0.013	0.01	0	43.4	39.6	76.1	136	126	0	35	34
2014	9	7	8	15	14	0.745	-0.112	4.219	0.01	0.007	0	43.9	39.6	75.7	137	126	0	35	34
2014	9	7	8	25	14	0.751	-0.072	4.219	0.013	0.01	0	43.4	40	75.7	136	127	0	35	34
2014	9	7	8	35	14	0.768	-0.092	4.219	0.013	0.01	0	43.9	39.6	76.1	136	126	0	34	34
2014	9	7	8	45	14	0.735	-0.066	4.219	0.016	0.016	0	43.4	40	76.1	136	126	0	35	33
2014	9	7	8	55	14	0.764	-0.069	4.219	0.01	0.007	0	43	39.6	76.1	135	126	0	35	34
2014	9	7	9	5	14	0.761	-0.105	4.219	0.01	0.007	0	43	39.6	76.5	135	126	0	35	34
2014	9	7	9	15	14	0.801	-0.098	4.219	0.01	0.007	0	43	39.6	75.7	135	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	9	25	14	0.764	-0.082	4.219	0.01	0.007	0	43	39.6	75.7	135	126	0	35	34
2014	9	7	9	35	14	0.794	-0.115	4.219	0.013	0.01	0	43.9	39.6	75.7	136	126	0	34	34
2014	9	7	9	45	14	0.745	-0.128	4.219	0.01	0.007	0	43	39.1	75.7	135	125	0	35	34
2014	9	7	9	55	14	0.751	-0.115	4.216	0.013	0.01	0	43	39.6	75.3	135	125	0	35	33
2014	9	7	10	5	14	0.732	-0.102	4.216	0.01	0.007	0	42.6	39.1	75.7	134	125	0	35	34
2014	9	7	10	15	14	0.771	-0.108	4.216	0.013	0.01	0	43.4	39.6	74.8	136	126	0	35	34
2014	9	7	10	25	14	0.768	-0.082	4.216	0.01	0.007	0	43.4	39.6	74	136	126	0	35	34
2014	9	7	10	35	14	0.771	-0.095	4.216	0.01	0.007	0	43	39.6	74.8	135	125	0	35	33
2014	9	7	10	45	14	0.764	-0.144	4.216	0.01	0.007	0	43	39.1	73.5	135	125	0	35	34
2014	9	7	10	55	14	0.741	-0.128	4.216	0.01	0.007	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	7	11	5	14	0.764	-0.135	4.216	0.01	0.007	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	7	11	15	14	0.794	-0.112	4.216	0.01	0.007	0	43.4	40	67.5	135	126	0	34	33
2014	9	7	11	25	14	0.758	-0.118	4.213	0.01	0.007	0	43.9	39.6	64.1	136	126	0	34	34
2014	9	7	11	35	14	0.771	-0.121	4.213	0.013	0.01	0	43	40	61.1	135	126	0	35	33
2014	9	7	11	45	14	0.768	-0.112	4.213	0.01	0.007	0	43.4	39.6	61.1	135	126	0	34	34
2014	9	7	11	55	14	0.761	-0.115	4.209	0.01	0.007	0	42.6	39.1	57.6	134	125	0	35	34
2014	9	7	12	5	14	0.768	-0.138	4.213	0.013	0.01	0	42.6	39.6	66.2	134	125	0	35	33
2014	9	7	12	15	14	0.755	-0.135	4.209	0.013	0.01	0	43	39.1	52	135	125	0	35	34
2014	9	7	12	25	14	0.787	-0.144	4.206	0.01	0.007	0	43	39.6	58	135	126	0	35	34
2014	9	7	12	35	14	0.748	-0.174	4.206	0.01	0.007	0	43.4	39.6	49.9	135	126	0	34	34
2014	9	7	12	45	14	0.745	-0.089	4.206	0.01	0.007	0	43	39.6	51.2	135	126	0	35	34
2014	9	7	12	55	14	0.764	-0.102	4.203	0.01	0.007	0	43.4	39.6	50.7	135	126	0	34	34
2014	9	7	13	5	14	0.764	-0.167	4.203	0.01	0.007	0	43	39.6	49.9	135	126	0	35	34
2014	9	7	13	15	14	0.728	-0.098	4.206	0.013	0.01	0	43.4	40.4	49	136	127	0	35	33
2014	9	7	13	25	14	0.755	-0.141	4.199	0.01	0.007	0	43.4	40.9	50.7	136	128	0	35	33
2014	9	7	13	35	14	0.738	-0.141	4.203	0.01	0.007	0	43.4	40	49	136	127	0	35	34
2014	9	7	13	45	14	0.725	-0.157	4.203	0.01	0.007	0	43.4	40.4	51.2	136	127	0	35	33
2014	9	7	13	55	14	0.758	-0.079	4.199	0.01	0.007	0	44.3	40.4	53.3	137	128	0	34	34
2014	9	7	14	5	14	0.722	-0.131	4.199	0.01	0.007	0	43.9	40	51.6	137	127	0	35	34
2014	9	7	14	15	14	0.732	-0.144	4.199	0.01	0.007	0	43.9	40.9	50.7	137	128	0	35	33
2014	9	7	14	25	14	0.738	-0.154	4.196	0.01	0.007	0	43.9	40	52.5	136	127	0	34	34
2014	9	7	14	35	14	0.755	-0.164	4.196	0.01	0.007	0	43.4	40	50.3	136	127	0	35	34
2014	9	7	14	45	14	0.758	-0.174	4.193	0.01	0.007	0	45.2	42.1	56.3	139	130	0	34	32
2014	9	7	14	55	14	0.755	-0.144	4.196	0.01	0.007	0	43.9	40.4	49.5	137	128	0	35	34
2014	9	7	15	5	14	0.755	-0.174	4.193	0.016	0.013	0	43.4	40	51.2	136	127	0	35	34
2014	9	7	15	15	14	0.722	-0.164	4.193	0.01	0.007	0	43.4	40.4	60.2	136	127	0	35	33
2014	9	7	15	25	14	0.761	-0.148	4.193	0.01	0.007	0	43.4	40	52	136	127	0	35	34
2014	9	7	15	35	14	0.755	-0.141	4.193	0.013	0.01	0	43.9	40	52	136	127	0	34	34
2014	9	7	15	45	14	0.764	-0.141	4.19	0.01	0.007	0	43.9	40	60.2	137	127	0	35	34
2014	9	7	15	55	14	0.735	-0.138	4.193	0.01	0.007	0	43	40	54.2	135	126	0	35	33
2014	9	7	16	5	14	0.758	-0.19	4.19	0.01	0.007	0	43.4	40	68.8	136	126	0	35	33
2014	9	7	16	15	14	0.741	-0.141	4.19	0.013	0.01	0	43.4	40	55	136	127	0	35	34
2014	9	7	16	25	14	0.755	-0.144	4.19	0.013	0.01	0	43.4	40.4	59.8	136	127	0	35	33
2014	9	7	16	35	14	0.761	-0.128	4.19	0.01	0.007	0	43.4	40	63.6	136	127	0	35	34
2014	9	7	16	45	14	0.771	-0.125	4.19	0.01	0.007	0	43.9	40	61.1	136	127	0	34	34
2014	9	7	16	55	14	0.774	-0.161	4.19	0.01	0.007	0	43	39.6	64.5	135	125	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	17	5	14	0.768	-0.112	4.19	0.01	0.007	0	43.9	39.6	67.9	136	126	0	34	34
2014	9	7	17	15	14	0.764	-0.102	4.19	0.01	0.007	0	43.9	39.6	74	136	126	0	34	34
2014	9	7	17	25	14	0.761	-0.115	4.19	0.01	0.007	0	43.4	39.6	61.1	136	126	0	35	34
2014	9	7	17	35	14	0.738	-0.118	4.19	0.013	0.01	0	43.4	40.4	73.5	136	127	0	35	33
2014	9	7	17	45	14	0.794	-0.138	4.186	0.013	0.01	0	43.4	40.4	57.6	136	127	0	35	33
2014	9	7	17	55	14	0.738	-0.141	4.19	0.013	0.01	0	43.4	39.6	54.2	135	126	0	34	34
2014	9	7	18	5	14	0.787	-0.138	4.186	0.01	0.007	0	43.4	39.6	65.8	136	126	0	35	34
2014	9	7	18	15	14	0.745	-0.112	4.19	0.01	0.007	0	43.4	40	55.9	136	126	0	35	33
2014	9	7	18	25	14	0.745	-0.105	4.19	0.01	0.007	0	43.4	39.6	52.5	136	126	0	35	34
2014	9	7	18	35	14	0.741	-0.098	4.19	0.01	0.007	0	43.4	40	50.7	136	127	0	35	34
2014	9	7	18	45	14	0.774	-0.102	4.19	0.01	0.007	0	43.9	40	49.5	137	127	0	35	34
2014	9	7	18	55	14	0.768	-0.089	4.19	0.01	0.007	0	44.3	40.9	53.3	138	128	0	35	33
2014	9	7	19	5	14	0.741	-0.079	4.19	0.01	0.007	0	43.9	40.4	53.3	137	128	0	35	34
2014	9	7	19	15	14	0.725	-0.098	4.186	0.01	0.007	0	44.7	41.3	50.7	139	129	0	35	33
2014	9	7	19	25	14	0.741	-0.092	4.183	0.013	0.01	0	47.7	44.3	47.3	146	136	0	35	33
2014	9	7	19	35	14	0.755	-0.075	4.193	0.013	0.01	0	49.5	45.6	48.6	150	140	0	35	34
2014	9	7	19	45	14	0.725	-0.105	4.193	0.01	0.007	0	49	45.6	48.6	149	139	0	35	33
2014	9	7	19	55	14	0.728	-0.072	4.19	0.01	0.007	0	49	45.2	47.3	149	139	0	35	34
2014	9	7	20	5	14	0.732	-0.082	4.19	0.013	0.01	0	48.2	44.7	47.7	147	138	0	35	34
2014	9	7	20	15	14	0.761	-0.098	4.196	0.01	0.007	0	48.2	45.2	46.9	147	138	0	35	33
2014	9	7	20	25	14	0.735	-0.112	4.193	0.016	0.013	0	48.2	43.9	47.3	147	136	0	35	34
2014	9	7	20	35	14	0.771	-0.092	4.19	0.01	0.007	0	47.7	43.9	48.6	146	136	0	35	34
2014	9	7	20	45	14	0.745	-0.095	4.193	0.01	0.007	0	48.6	44.7	52	147	136	0	34	32
2014	9	7	20	55	14	0.755	-0.089	4.193	0.01	0.007	0	47.3	43.4	50.7	145	134	0	35	33
2014	9	7	21	5	14	0.745	-0.082	4.193	0.01	0.007	0	47.3	43	51.2	144	134	0	34	34
2014	9	7	21	15	14	0.748	-0.082	4.193	0.01	0.007	0	46.4	42.6	53.3	143	133	0	35	34
2014	9	7	21	25	14	0.761	-0.098	4.193	0.01	0.007	0	46.4	42.6	52	143	132	0	35	33
2014	9	7	21	35	14	0.761	-0.105	4.193	0.013	0.01	0	46.4	42.1	55	143	132	0	35	34
2014	9	7	21	45	14	0.735	-0.089	4.193	0.01	0.007	0	47.3	43.4	64.1	145	134	0	35	33
2014	9	7	21	55	14	0.751	-0.072	4.193	0.01	0.007	0	46	42.6	54.6	142	132	0	35	33
2014	9	7	22	5	14	0.764	-0.075	4.193	0.01	0.007	0	46.4	42.6	58.5	143	133	0	35	34
2014	9	7	22	15	14	0.774	-0.102	4.19	0.013	0.01	0	46	42.1	62.8	142	131	0	35	33
2014	9	7	22	25	14	0.778	-0.069	4.193	0.01	0.007	0	45.6	41.3	68.4	140	130	0	34	34
2014	9	7	22	35	14	0.745	-0.085	4.193	0.01	0.007	0	45.6	42.1	72.7	141	131	0	35	33
2014	9	7	22	45	14	0.761	-0.075	4.193	0.013	0.01	0	45.2	40.9	73.5	140	129	0	35	34
2014	9	7	22	55	14	0.748	-0.069	4.193	0.01	0.007	0	44.7	40.9	74	139	129	0	35	34
2014	9	7	23	5	14	0.748	-0.059	4.193	0.01	0.007	0	45.2	40.9	74	139	129	0	34	34
2014	9	7	23	15	14	0.761	-0.105	4.193	0.013	0.01	0	45.2	41.3	74	139	129	0	34	33
2014	9	7	23	25	14	0.768	-0.089	4.193	0.01	0.007	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	7	23	35	14	0.761	-0.095	4.193	0.013	0.01	0	44.7	41.7	72.7	139	130	0	35	33
2014	9	7	23	45	14	0.751	-0.079	4.193	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	7	23	55	14	0.741	-0.089	4.193	0.01	0.007	0	45.6	41.7	72.7	141	131	0	35	34
2014	9	8	0	5	14	0.774	-0.095	4.193	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	8	0	15	14	0.761	-0.059	4.193	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	8	0	25	14	0.761	-0.082	4.193	0.016	0.013	0	44.3	40.9	57.6	138	128	0	35	33
2014	9	8	0	35	14	0.725	-0.098	4.193	0.01	0.007	0	43.4	40	59.3	136	126	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	0	45	14	0.761	-0.112	4.193	0.01	0.007	0	43.4	40	73.1	136	126	0	35	33
2014	9	8	0	55	14	0.732	-0.059	4.193	0.01	0.007	0	44.3	40.9	74	137	128	0	34	33
2014	9	8	1	5	14	0.745	-0.098	4.193	0.01	0.007	0	43.9	40.4	73.1	138	128	0	36	34
2014	9	8	1	15	14	0.738	-0.092	4.193	0.01	0.007	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	8	1	25	14	0.732	-0.098	4.193	0.016	0.013	0	44.7	40.4	73.5	139	128	0	35	34
2014	9	8	1	35	14	0.761	-0.108	4.193	0.013	0.01	0	44.7	40.4	74	138	128	0	34	34
2014	9	8	1	45	14	0.748	-0.095	4.193	0.013	0.01	0	42.6	40	74	134	127	0	35	34
2014	9	8	1	55	14	0.764	-0.095	4.193	0.01	0.007	0	44.3	40.4	66.2	138	127	0	35	33
2014	9	8	2	5	14	0.761	-0.069	4.193	0.01	0.007	0	44.3	40	67.9	138	127	0	35	34
2014	9	8	2	15	14	0.771	-0.075	4.193	0.01	0.007	0	44.7	40.4	60.2	139	128	0	35	34
2014	9	8	2	25	14	0.755	-0.069	4.193	0.013	0.01	0	45.2	40.9	72.2	139	128	0	34	33
2014	9	8	2	35	14	0.745	-0.072	4.193	0.01	0.007	0	44.7	40.4	69.2	138	127	0	34	33
2014	9	8	2	45	14	0.728	-0.075	4.193	0.01	0.007	0	44.7	40.9	70.1	139	128	0	35	33
2014	9	8	2	55	14	0.745	-0.072	4.193	0.01	0.007	0	44.3	40.9	69.7	138	128	0	35	33
2014	9	8	3	5	14	0.768	-0.098	4.196	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	8	3	15	14	0.732	-0.082	4.196	0.013	0.01	0	44.3	40.9	71	138	128	0	35	33
2014	9	8	3	25	14	0.771	-0.095	4.196	0.013	0.01	0	43.9	40	71.4	137	127	0	35	34
2014	9	8	3	35	14	0.732	-0.108	4.196	0.01	0.007	0	43.9	39.6	71.4	137	126	0	35	34
2014	9	8	3	45	14	0.741	-0.062	4.196	0.01	0.007	0	44.3	40	72.2	138	127	0	35	34
2014	9	8	3	55	14	0.755	-0.092	4.196	0.01	0.007	0	43.9	40.4	72.2	137	127	0	35	33
2014	9	8	4	5	14	0.761	-0.095	4.196	0.01	0.007	0	44.7	40.4	73.1	139	128	0	35	34
2014	9	8	4	15	14	0.768	-0.079	4.196	0.01	0.007	0	44.3	40.4	72.7	138	127	0	35	33
2014	9	8	4	25	14	0.755	-0.075	4.196	0.01	0.007	0	44.3	40.4	64.1	138	127	0	35	33
2014	9	8	4	35	14	0.755	-0.095	4.196	0.01	0.007	0	44.3	40.9	62.4	138	128	0	35	33
2014	9	8	4	45	14	0.771	-0.092	4.196	0.013	0.01	0	44.3	40.4	73.1	138	127	0	35	33
2014	9	8	4	55	14	0.748	-0.112	4.196	0.013	0.01	0	46.9	43.4	71.8	144	134	0	35	33
2014	9	8	5	5	14	0.745	-0.098	4.196	0.013	0.01	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	8	5	15	14	0.748	-0.082	4.196	0.013	0.01	0	44.3	40	72.2	138	127	0	35	34
2014	9	8	5	25	14	0.732	-0.098	4.196	0.01	0.007	0	44.7	41.3	69.2	138	129	0	34	33
2014	9	8	5	35	14	0.774	-0.108	4.196	0.013	0.01	0	44.7	40.9	61.1	138	129	0	34	34
2014	9	8	5	45	14	0.778	-0.095	4.196	0.01	0.007	0	43.9	40.9	61.9	137	129	0	35	34
2014	9	8	5	55	14	0.758	-0.082	4.196	0.01	0.007	0	44.7	41.7	66.2	139	130	0	35	33
2014	9	8	6	5	14	0.732	-0.102	4.196	0.01	0.007	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	8	6	15	14	0.771	-0.095	4.196	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	8	6	25	14	0.751	-0.066	4.196	0.01	0.007	0	45.2	41.7	71.4	140	131	0	35	34
2014	9	8	6	35	14	0.755	-0.075	4.196	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	8	6	45	14	0.748	-0.069	4.196	0.013	0.01	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	8	6	55	14	0.768	-0.072	4.196	0.01	0.007	0	44.7	41.3	70.1	139	130	0	35	34
2014	9	8	7	5	14	0.748	-0.069	4.196	0.01	0.007	0	44.7	41.3	72.2	139	130	0	35	34
2014	9	8	7	15	14	0.768	-0.095	4.196	0.01	0.007	0	44.7	41.3	71.4	139	130	0	35	34
2014	9	8	7	25	14	0.787	-0.085	4.196	0.01	0.007	0	43.4	40.4	72.2	136	127	0	35	33
2014	9	8	7	35	14	0.751	-0.079	4.196	0.01	0.007	0	43.4	40	72.2	135	126	0	34	33
2014	9	8	7	45	14	0.755	-0.075	4.196	0.01	0.007	0	43	39.6	72.2	135	126	0	35	34
2014	9	8	7	55	14	0.755	-0.082	4.196	0.01	0.007	0	43.9	40	72.7	136	127	0	34	34
2014	9	8	8	5	14	0.755	-0.095	4.196	0.01	0.007	0	43.4	40.4	72.2	136	127	0	35	33
2014	9	8	8	15	14	0.748	-0.066	4.196	0.013	0.01	0	43	40	68.8	135	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	8	25	14	0.748	-0.095	4.199	0.013	0.01	0	43	40.4	65.8	135	127	0	35	33
2014	9	8	8	35	14	0.764	-0.082	4.196	0.013	0.01	0	42.6	39.6	58	134	126	0	35	34
2014	9	8	8	45	14	0.755	-0.085	4.196	0.013	0.01	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	8	8	55	14	0.764	-0.095	4.196	0.016	0.013	0	42.6	39.6	72.7	134	126	0	35	34
2014	9	8	9	5	14	0.768	-0.144	4.196	0.01	0.007	0	42.1	39.6	56.8	133	125	0	35	33
2014	9	8	9	15	14	0.751	-0.148	4.196	0.01	0.007	0	42.6	39.1	59.3	133	124	0	34	33
2014	9	8	9	25	14	0.741	-0.105	4.196	0.01	0.007	0	43	39.1	66.7	134	124	0	34	33
2014	9	8	9	35	14	0.761	-0.144	4.196	0.016	0.013	0	42.6	39.1	61.1	133	124	0	34	33
2014	9	8	9	45	14	0.732	-0.128	4.199	0.016	0.013	0	41.7	38.7	73.1	133	124	0	36	34
2014	9	8	9	55	14	0.764	-0.151	4.196	0.01	0.007	0	42.6	39.1	63.6	134	125	0	35	34
2014	9	8	10	5	14	0.728	-0.105	4.196	0.01	0.007	0	42.1	39.6	70.5	133	125	0	35	33
2014	9	8	10	15	14	0.722	-0.135	4.196	0.01	0.007	0	42.6	39.1	64.9	133	124	0	34	33
2014	9	8	10	25	14	0.794	-0.141	4.196	0.01	0.007	0	42.1	38.7	72.7	133	124	0	35	34
2014	9	8	10	35	14	0.755	-0.112	4.196	0.01	0.007	0	43	39.1	70.5	134	125	0	34	34
2014	9	8	10	45	14	0.758	-0.121	4.196	0.013	0.01	0	43	39.6	66.2	134	126	0	34	34
2014	9	8	10	55	14	0.741	-0.148	4.196	0.01	0.007	0	42.1	38.7	67.1	133	124	0	35	34
2014	9	8	11	5	14	0.758	-0.115	4.196	0.016	0.013	0	42.6	38.7	55.5	133	124	0	34	34
2014	9	8	11	16	47	0.771	-0.112	4.196	0.01	0.007	0	43	39.6	58.5	134	125	0	34	33
2014	9	8	11	26	47	0.768	-0.112	4.199	0.01	0.007	0	43	40.4	54.2	135	127	0	35	33
2014	9	8	11	36	47	0.764	-0.128	4.199	0.01	0.007	0	43	39.6	52.5	134	125	0	34	33
2014	9	8	11	46	47	0.748	-0.148	4.193	0.013	0.01	0	42.1	38.7	58	133	124	0	35	34
2014	9	8	11	56	47	0.764	-0.125	4.196	0.01	0.007	0	42.6	39.6	52.5	134	125	0	35	33
2014	9	8	12	6	47	0.745	-0.144	4.196	0.01	0.007	0	42.6	39.6	51.6	134	126	0	35	34
2014	9	8	12	16	47	0.712	-0.174	4.196	0.01	0.007	0	42.6	39.6	49.9	134	126	0	35	34
2014	9	8	12	26	47	0.748	-0.128	4.196	0.01	0.007	0	42.6	39.6	52	134	125	0	35	33
2014	9	8	12	36	47	0.728	-0.108	4.196	0.013	0.01	0	43.4	40	51.6	135	126	0	34	33
2014	9	8	12	46	47	0.751	-0.115	4.196	0.013	0.01	0	43.4	39.6	52	135	126	0	34	34
2014	9	8	12	56	47	0.732	-0.141	4.196	0.01	0.007	0	43	40	53.8	135	126	0	35	33
2014	9	8	13	6	47	0.758	-0.115	4.193	0.013	0.01	0	43	40.4	53.8	135	127	0	35	33
2014	9	8	13	16	47	0.728	-0.161	4.193	0.01	0.007	0	43	39.6	67.1	135	126	0	35	34
2014	9	8	13	26	47	0.797	-0.125	4.193	0.01	0.007	0	43.9	40.9	60.2	137	128	0	35	33
2014	9	8	13	36	47	0.732	-0.082	4.193	0.01	0.007	0	43.9	40.9	58	137	129	0	35	34
2014	9	8	13	46	47	0.764	-0.112	4.193	0.013	0.01	0	43.4	40.4	76.1	136	127	0	35	33
2014	9	8	13	56	47	0.764	-0.095	4.193	0.01	0.007	0	43.4	40.9	71	136	128	0	35	33
2014	9	8	14	6	47	0.781	-0.115	4.193	0.013	0.01	0	43	40	74.8	135	127	0	35	34
2014	9	8	14	16	47	0.768	-0.112	4.193	0.01	0.007	0	43.4	40.4	54.2	136	127	0	35	33
2014	9	8	14	26	47	0.784	-0.105	4.193	0.01	0.007	0	43	40.4	55.9	135	127	0	35	33
2014	9	8	14	36	47	0.745	-0.125	4.193	0.01	0.007	0	43.9	40	54.6	136	127	0	34	34
2014	9	8	14	46	47	0.781	-0.131	4.193	0.013	0.01	0	43	40.4	74	135	127	0	35	33
2014	9	8	14	56	47	0.738	-0.151	4.19	0.01	0.007	0	43.4	39.6	50.7	135	126	0	34	34
2014	9	8	15	6	47	0.781	-0.128	4.19	0.013	0.01	0	43.9	40.4	54.6	136	127	0	34	33
2014	9	8	15	16	47	0.771	-0.118	4.193	0.01	0.007	0	43	40.4	71.8	135	127	0	35	33
2014	9	8	15	26	47	0.784	-0.115	4.19	0.01	0.007	0	43.4	40.4	61.1	136	127	0	35	33
2014	9	8	15	36	47	0.778	-0.112	4.19	0.01	0.007	0	43.4	40	71.4	135	127	0	34	34
2014	9	8	15	46	47	0.735	-0.082	4.19	0.013	0.01	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	8	15	56	47	0.745	-0.066	4.19	0.016	0.016	0	44.3	40.4	76.1	137	128	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	16	6	47	0.797	-0.125	4.19	0.01	0.007	0	43	40	77.4	135	127	0	35	34
2014	9	8	16	16	47	0.751	-0.095	4.19	0.013	0.01	0	43.9	40.9	75.7	136	128	0	34	33
2014	9	8	16	26	47	0.748	-0.105	4.19	0.013	0.01	0	43.4	40	75.7	135	127	0	34	34
2014	9	8	16	36	47	0.751	-0.098	4.19	0.01	0.007	0	43.9	40.4	75.3	136	128	0	34	34
2014	9	8	16	46	47	0.751	-0.082	4.19	0.016	0.013	0	43.4	40.9	76.1	136	128	0	35	33
2014	9	8	16	56	47	0.751	-0.105	4.19	0.01	0.007	0	43.4	40	76.1	135	127	0	34	34
2014	9	8	17	6	47	0.735	-0.089	4.19	0.013	0.01	0	43.9	40.4	71.8	136	127	0	34	33
2014	9	8	17	16	47	0.755	-0.102	4.19	0.01	0.007	0	43.9	40.9	56.3	137	128	0	35	33
2014	9	8	17	26	47	0.778	-0.092	4.19	0.01	0.007	0	43.9	40.9	55.9	137	129	0	35	34
2014	9	8	17	36	47	0.768	-0.066	4.19	0.01	0.007	0	44.3	40.9	59.8	138	129	0	35	34
2014	9	8	17	46	47	0.735	-0.089	4.19	0.013	0.01	0	44.7	41.3	71.8	139	130	0	35	34
2014	9	8	17	56	47	0.761	-0.085	4.19	0.016	0.013	0	44.7	41.7	75.3	139	130	0	35	33
2014	9	8	18	6	47	0.732	-0.082	4.19	0.01	0.007	0	44.3	41.3	74	138	129	0	35	33
2014	9	8	18	16	47	0.738	-0.092	4.19	0.01	0.007	0	43.9	40.9	74.8	137	128	0	35	33
2014	9	8	18	26	47	0.755	-0.092	4.19	0.01	0.007	0	43.9	40.4	76.1	137	128	0	35	34
2014	9	8	18	36	47	0.787	-0.085	4.19	0.01	0.007	0	44.3	40.9	76.5	137	128	0	34	33
2014	9	8	18	46	47	0.751	-0.075	4.19	0.013	0.01	0	43.9	40.9	76.1	137	128	0	35	33
2014	9	8	18	56	47	0.755	-0.085	4.19	0.01	0.007	0	43.9	40.9	76.5	136	128	0	34	33
2014	9	8	19	6	47	0.748	-0.082	4.19	0.01	0.007	0	43.9	40.9	76.1	137	128	0	35	33
2014	9	8	19	16	47	0.748	-0.072	4.19	0.01	0.007	0	43.9	40.9	76.5	136	128	0	34	33
2014	9	8	19	26	47	0.751	-0.095	4.193	0.01	0.007	0	43.9	40.9	76.1	137	128	0	35	33
2014	9	8	19	36	47	0.748	-0.095	4.19	0.013	0.01	0	43.9	41.3	76.1	137	129	0	35	33
2014	9	8	19	46	47	0.758	-0.079	4.193	0.01	0.007	0	44.3	40.9	75.7	137	129	0	34	34
2014	9	8	19	56	47	0.748	-0.079	4.193	0.01	0.007	0	44.7	41.3	75.7	138	129	0	34	33
2014	9	8	20	6	47	0.748	-0.079	4.193	0.01	0.007	0	44.3	41.3	74.8	137	129	0	34	33
2014	9	8	20	16	47	0.755	-0.092	4.193	0.016	0.013	0	44.3	41.3	75.3	137	129	0	34	33
2014	9	8	20	26	47	0.768	-0.069	4.193	0.01	0.007	0	43.4	40.9	72.2	136	128	0	35	33
2014	9	8	20	36	47	0.784	-0.105	4.193	0.01	0.007	0	44.3	41.3	75.3	138	130	0	35	34
2014	9	8	20	46	47	0.755	-0.069	4.193	0.01	0.007	0	43.9	40.9	75.3	137	129	0	35	34
2014	9	8	20	56	47	0.735	-0.105	4.193	0.016	0.013	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	8	21	6	47	0.758	-0.066	4.193	0.01	0.007	0	43.9	40.4	76.5	137	128	0	35	34
2014	9	8	21	16	47	0.758	-0.082	4.193	0.013	0.01	0	43.9	40.9	75.3	137	129	0	35	34
2014	9	8	21	26	47	0.751	-0.072	4.193	0.016	0.013	0	44.7	41.3	75.7	138	129	0	34	33
2014	9	8	21	36	47	0.755	-0.043	4.193	0.013	0.01	0	44.3	40.9	75.3	137	128	0	34	33
2014	9	8	21	46	47	0.745	-0.059	4.193	0.01	0.007	0	43.9	40.9	74	137	128	0	35	33
2014	9	8	21	56	47	0.774	-0.115	4.193	0.013	0.01	0	43.9	40.4	76.1	137	128	0	35	34
2014	9	8	22	6	47	0.748	-0.098	4.193	0.01	0.007	0	43.9	40.4	75.7	137	128	0	35	34
2014	9	8	22	16	47	0.758	-0.066	4.193	0.01	0.007	0	44.3	40.9	75.3	137	128	0	34	33
2014	9	8	22	26	47	0.817	-0.085	4.193	0.01	0.007	0	44.3	40.9	75.7	137	128	0	34	33
2014	9	8	22	36	47	0.771	-0.092	4.193	0.01	0.007	0	44.3	40.4	74.8	137	128	0	34	34
2014	9	8	22	46	47	0.748	-0.062	4.193	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	8	22	56	47	0.732	-0.082	4.193	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	8	23	6	47	0.761	-0.066	4.193	0.013	0.01	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	8	23	16	47	0.745	-0.085	4.193	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	8	23	26	47	0.755	-0.066	4.196	0.01	0.007	0	44.3	40.4	63.2	138	128	0	35	34
2014	9	8	23	36	47	0.768	-0.056	4.193	0.013	0.01	0	44.3	40.4	74.4	137	128	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	23	46	47	0.738	-0.085	4.193	0.01	0.007	0	45.2	40.9	63.6	139	128	0	34	33
2014	9	8	23	56	47	0.751	-0.075	4.193	0.013	0.01	0	44.3	40.9	62.8	138	128	0	35	33
2014	9	9	0	6	47	0.761	-0.052	4.193	0.016	0.013	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	9	0	16	47	0.732	-0.098	4.193	0.01	0.007	0	43.9	40	74	137	127	0	35	34
2014	9	9	0	26	47	0.751	-0.062	4.193	0.01	0.007	0	44.7	40.9	74.8	138	128	0	34	33
2014	9	9	0	36	47	0.764	-0.066	4.196	0.013	0.01	0	44.3	40	74.4	137	127	0	34	34
2014	9	9	0	46	47	0.771	-0.092	4.196	0.013	0.01	0	44.7	40.4	74	138	128	0	34	34
2014	9	9	0	56	47	0.758	-0.098	4.196	0.01	0.007	0	44.3	40.4	74.4	138	127	0	35	33
2014	9	9	1	6	47	0.781	-0.138	4.196	0.01	0.007	0	44.3	40.4	73.5	137	128	0	34	34
2014	9	9	1	16	47	0.735	-0.075	4.196	0.01	0.007	0	44.3	41.3	68.8	138	129	0	35	33
2014	9	9	1	26	47	0.745	-0.082	4.193	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	9	1	36	47	0.751	-0.066	4.196	0.01	0.007	0	45.2	41.3	72.7	139	129	0	34	33
2014	9	9	1	46	47	0.761	-0.098	4.196	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	9	1	56	47	0.751	-0.079	4.196	0.01	0.007	0	44.3	40.9	69.7	138	128	0	35	33
2014	9	9	2	6	47	0.764	-0.085	4.196	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	9	2	16	47	0.787	-0.079	4.196	0.01	0.007	0	43.9	40.4	74	137	127	0	35	33
2014	9	9	2	26	47	0.764	-0.079	4.196	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	9	2	36	47	0.761	-0.069	4.196	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	9	2	46	47	0.751	-0.082	4.196	0.013	0.01	0	44.3	40	72.2	137	127	0	34	34
2014	9	9	2	56	47	0.745	-0.102	4.196	0.01	0.007	0	43.9	40.4	67.1	137	127	0	35	33
2014	9	9	3	6	47	0.751	-0.085	4.196	0.01	0.007	0	43.9	40	62.4	137	127	0	35	34
2014	9	9	3	16	47	0.722	-0.102	4.196	0.01	0.007	0	44.7	40.9	70.1	138	128	0	34	33
2014	9	9	3	26	47	0.758	-0.066	4.196	0.01	0.007	0	44.3	40.9	68.4	137	128	0	34	33
2014	9	9	3	36	47	0.778	-0.125	4.196	0.01	0.007	0	43.9	40	58.5	137	127	0	35	34
2014	9	9	3	46	47	0.748	-0.095	4.196	0.01	0.007	0	43.9	40.4	69.2	137	128	0	35	34
2014	9	9	3	56	47	0.764	-0.121	4.196	0.01	0.007	0	43.9	40	69.7	137	127	0	35	34
2014	9	9	4	6	47	0.738	-0.066	4.196	0.01	0.007	0	44.7	40.9	70.1	139	129	0	35	34
2014	9	9	4	16	47	0.764	-0.098	4.196	0.01	0.007	0	44.3	40.9	69.7	137	128	0	34	33
2014	9	9	4	26	47	0.771	-0.069	4.196	0.013	0.01	0	44.7	40.9	72.2	139	129	0	35	34
2014	9	9	4	36	47	0.764	-0.062	4.196	0.01	0.007	0	43.9	40.9	73.5	137	128	0	35	33
2014	9	9	4	46	47	0.758	-0.098	4.196	0.01	0.007	0	44.7	41.3	69.2	139	130	0	35	34
2014	9	9	4	56	47	0.738	-0.085	4.196	0.01	0.007	0	45.2	41.7	71	140	131	0	35	34
2014	9	9	5	6	47	0.751	-0.066	4.196	0.01	0.007	0	44.3	41.3	73.5	138	129	0	35	33
2014	9	9	5	16	47	0.741	-0.082	4.196	0.01	0.007	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	9	5	26	47	0.764	-0.121	4.196	0.013	0.01	0	45.2	41.7	73.5	139	130	0	34	33
2014	9	9	5	36	47	0.761	-0.059	4.196	0.013	0.01	0	44.3	40.9	73.1	137	128	0	34	33
2014	9	9	5	46	47	0.764	-0.082	4.196	0.01	0.007	0	44.3	41.3	72.7	138	129	0	35	33
2014	9	9	5	56	47	0.758	-0.105	4.196	0.013	0.01	0	44.7	41.7	69.7	139	130	0	35	33
2014	9	9	6	6	47	0.758	-0.072	4.196	0.01	0.007	0	45.6	42.1	73.1	141	131	0	35	33
2014	9	9	6	16	47	0.755	-0.085	4.196	0.01	0.007	0	45.2	42.1	72.7	140	131	0	35	33
2014	9	9	6	26	47	0.748	-0.075	4.196	0.013	0.01	0	46.9	43	72.2	143	133	0	34	33
2014	9	9	6	36	47	0.748	-0.118	4.196	0.01	0.007	0	46.9	43.4	72.2	144	134	0	35	33
2014	9	9	6	46	47	0.748	-0.082	4.196	0.01	0.007	0	46	43	71.8	142	133	0	35	33
2014	9	9	6	56	47	0.728	-0.069	4.196	0.016	0.013	0	45.2	41.7	72.7	140	131	0	35	34
2014	9	9	7	6	47	0.771	-0.085	4.196	0.013	0.01	0	45.6	42.1	72.2	141	131	0	35	33
2014	9	9	7	16	47	0.761	-0.062	4.196	0.016	0.013	0	45.6	41.7	72.7	140	131	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	7	26	47	0.784	-0.066	4.196	0.01	0.007	0	45.2	42.1	72.7	140	131	0	35	33
2014	9	9	7	36	47	0.781	-0.085	4.196	0.01	0.007	0	44.3	40.9	72.7	137	128	0	34	33
2014	9	9	7	46	47	0.755	-0.092	4.196	0.01	0.007	0	43.9	40	73.1	136	127	0	34	34
2014	9	9	7	56	47	0.751	-0.082	4.196	0.01	0.007	0	43.4	40	73.1	136	127	0	35	34
2014	9	9	8	6	47	0.722	-0.108	4.196	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	9	8	16	47	0.751	-0.072	4.196	0.013	0.01	0	43.4	40	73.1	135	127	0	34	34
2014	9	9	8	26	47	0.781	-0.085	4.196	0.01	0.007	0	43	40	73.1	135	127	0	35	34
2014	9	9	8	36	47	0.774	-0.062	4.196	0.01	0.007	0	43	39.6	73.1	135	126	0	35	34
2014	9	9	8	46	47	0.728	-0.095	4.196	0.01	0.007	0	43.4	40.4	73.5	136	127	0	35	33
2014	9	9	8	56	47	0.774	-0.102	4.196	0.01	0.007	0	43.4	39.6	72.2	135	126	0	34	34
2014	9	9	9	6	47	0.761	-0.118	4.196	0.01	0.007	0	43	40	68.8	135	126	0	35	33
2014	9	9	9	16	47	0.735	-0.082	4.196	0.013	0.01	0	43.4	40.4	70.5	135	127	0	34	33
2014	9	9	9	26	47	0.745	-0.082	4.196	0.013	0.01	0	43.9	40	72.2	136	127	0	34	34
2014	9	9	9	36	47	0.778	-0.141	4.196	0.013	0.01	0	43	40	67.9	135	126	0	35	33
2014	9	9	9	46	47	0.761	-0.092	4.196	0.01	0.007	0	43	40	68.8	135	126	0	35	33
2014	9	9	9	56	47	0.764	-0.092	4.196	0.01	0.007	0	43	40	74	135	127	0	35	34
2014	9	9	10	6	47	0.732	-0.092	4.196	0.013	0.01	0	43.4	40	72.7	135	127	0	34	34
2014	9	9	10	16	47	0.761	-0.092	4.196	0.01	0.007	0	43	40	74.4	135	127	0	35	34
2014	9	9	10	26	47	0.771	-0.128	4.196	0.01	0.007	0	43	39.6	75.3	135	126	0	35	34
2014	9	9	10	36	47	0.774	-0.115	4.196	0.01	0.007	0	43.4	40	75.3	135	126	0	34	33
2014	9	9	10	46	47	0.751	-0.082	4.193	0.013	0.01	0	43.4	40.4	74.4	136	128	0	35	34
2014	9	9	10	56	47	0.778	-0.092	4.196	0.016	0.013	0	43.9	40	73.1	136	127	0	34	34
2014	9	9	11	6	47	0.771	-0.069	4.193	0.01	0.007	0	43	40.4	68.8	135	127	0	35	33
2014	9	9	11	16	47	0.761	-0.082	4.193	0.01	0.007	0	43.9	40	58.5	136	127	0	34	34
2014	9	9	11	26	47	0.797	-0.085	4.193	0.01	0.007	0	43.4	40.4	61.9	136	128	0	35	34
2014	9	9	11	36	47	0.748	-0.082	4.193	0.01	0.007	0	44.3	40.4	64.1	137	128	0	34	34
2014	9	9	11	46	47	0.778	-0.095	4.193	0.01	0.007	0	43.9	40.4	72.7	136	128	0	34	34
2014	9	9	11	56	47	0.751	-0.079	4.193	0.016	0.013	0	43.4	40.4	71	136	128	0	35	34
2014	9	9	12	6	47	0.771	-0.062	4.193	0.01	0.007	0	43.9	40.9	67.1	137	129	0	35	34
2014	9	9	12	16	47	0.748	-0.082	4.193	0.013	0.01	0	43.9	40.9	72.7	137	128	0	35	33
2014	9	9	12	26	47	0.748	-0.095	4.193	0.01	0.007	0	43.9	41.3	72.7	137	129	0	35	33
2014	9	9	12	36	47	0.755	-0.112	4.193	0.016	0.013	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	9	12	46	47	0.748	-0.095	4.19	0.01	0.007	0	43.4	40.4	75.3	136	128	0	35	34
2014	9	9	12	56	47	0.732	-0.098	4.19	0.01	0.007	0	43.9	40.9	77	136	128	0	34	33
2014	9	9	13	6	47	0.764	-0.082	4.19	0.01	0.007	0	44.3	41.3	76.5	137	129	0	34	33
2014	9	9	13	16	47	0.764	-0.089	4.19	0.01	0.007	0	43.9	40.9	75.7	137	128	0	35	33
2014	9	9	13	26	47	0.764	-0.092	4.19	0.01	0.007	0	43.4	40.4	76.5	136	128	0	35	34
2014	9	9	13	36	47	0.768	-0.066	4.19	0.013	0.01	0	43.9	40.9	75.3	137	128	0	35	33
2014	9	9	13	46	47	0.764	-0.098	4.19	0.013	0.01	0	43.9	40.9	74.8	137	128	0	35	33
2014	9	9	13	56	47	0.764	-0.082	4.19	0.013	0.01	0	43.9	40.9	75.7	137	128	0	35	33
2014	9	9	14	6	47	0.725	-0.082	4.19	0.01	0.007	0	43.9	40.9	75.3	137	129	0	35	34
2014	9	9	14	16	47	0.797	-0.095	4.19	0.01	0.007	0	43.9	40.4	74.4	137	128	0	35	34
2014	9	9	14	26	47	0.794	-0.092	4.19	0.01	0.007	0	44.7	40.9	74	138	129	0	34	34
2014	9	9	14	36	47	0.797	-0.082	4.186	0.013	0.01	0	44.3	40.4	74.4	137	128	0	34	34
2014	9	9	14	46	47	0.755	-0.075	4.186	0.01	0.007	0	44.7	40.9	74	138	129	0	34	34
2014	9	9	14	56	47	0.755	-0.085	4.186	0.013	0.01	0	44.3	40.9	74.4	137	128	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	15	6	47	0.748	-0.089	4.186	0.01	0.007	0	44.3	40.4	75.7	137	128	0	34	34
2014	9	9	15	16	47	0.764	-0.095	4.186	0.01	0.007	0	43.9	40.9	74	137	129	0	35	34
2014	9	9	15	26	47	0.768	-0.105	4.186	0.013	0.01	0	44.3	40.9	76.5	137	128	0	34	33
2014	9	9	15	36	47	0.761	-0.125	4.186	0.013	0.01	0	43.4	40.9	76.1	136	128	0	35	33
2014	9	9	15	46	47	0.781	-0.098	4.186	0.013	0.01	0	43.4	40.4	75.7	136	127	0	35	33
2014	9	9	15	56	47	0.745	-0.082	4.186	0.01	0.007	0	44.3	40.9	76.1	137	129	0	34	34
2014	9	9	16	6	47	0.748	-0.056	4.186	0.01	0.007	0	43.9	40.9	74.4	137	129	0	35	34
2014	9	9	16	16	47	0.764	-0.102	4.186	0.01	0.007	0	43.9	40.9	74	137	128	0	35	33
2014	9	9	16	26	47	0.755	-0.108	4.186	0.01	0.007	0	43.9	40.9	75.7	137	128	0	35	33
2014	9	9	16	36	47	0.764	-0.138	4.186	0.01	0.007	0	43.9	40.4	67.1	136	127	0	34	33
2014	9	9	16	46	47	0.781	-0.108	4.186	0.01	0.007	0	43.9	40.9	74.8	136	128	0	34	33
2014	9	9	16	56	47	0.778	-0.112	4.186	0.01	0.007	0	43.9	40.4	76.5	136	127	0	34	33
2014	9	9	17	6	47	0.741	-0.082	4.186	0.01	0.007	0	43.4	40	74	136	127	0	35	34
2014	9	9	17	16	47	0.758	-0.095	4.186	0.01	0.007	0	43	40	75.3	135	127	0	35	34
2014	9	9	17	26	47	0.774	-0.079	4.186	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	9	17	36	47	0.771	-0.112	4.186	0.01	0.007	0	43	40.4	74	135	127	0	35	33
2014	9	9	17	46	47	0.751	-0.079	4.186	0.01	0.007	0	43	40	75.7	135	127	0	35	34
2014	9	9	17	56	47	0.738	-0.112	4.186	0.01	0.007	0	43.4	39.6	72.7	135	126	0	34	34
2014	9	9	18	6	47	0.755	-0.102	4.186	0.01	0.007	0	43.4	40	75.7	135	126	0	34	33
2014	9	9	18	16	47	0.768	-0.115	4.186	0.016	0.013	0	43.4	40	75.7	135	126	0	34	33
2014	9	9	18	26	47	0.735	-0.095	4.186	0.01	0.007	0	43.4	39.6	75.3	135	126	0	34	34
2014	9	9	18	36	47	0.741	-0.112	4.186	0.01	0.007	0	43.4	40.4	75.7	136	127	0	35	33
2014	9	9	18	46	47	0.791	-0.072	4.186	0.016	0.013	0	43	40	76.1	135	127	0	35	34
2014	9	9	18	56	47	0.761	-0.095	4.186	0.01	0.007	0	43.4	40	75.7	136	127	0	35	34
2014	9	9	19	6	47	0.725	-0.066	4.186	0.01	0.007	0	44.3	40.9	75.3	137	128	0	34	33
2014	9	9	19	16	47	0.764	-0.085	4.186	0.01	0.007	0	44.3	40.9	76.1	138	129	0	35	34
2014	9	9	19	26	47	0.735	-0.082	4.186	0.016	0.013	0	45.2	41.3	75.7	139	130	0	34	34
2014	9	9	19	36	47	0.761	-0.085	4.19	0.01	0.007	0	44.3	41.7	76.1	138	130	0	35	33
2014	9	9	19	46	47	0.755	-0.036	4.19	0.013	0.01	0	45.2	41.7	75.7	139	130	0	34	33
2014	9	9	19	56	47	0.755	-0.075	4.19	0.013	0.01	0	44.7	41.3	75.3	139	130	0	35	34
2014	9	9	20	6	47	0.778	-0.075	4.19	0.01	0.007	0	44.3	41.3	75.3	138	130	0	35	34
2014	9	9	20	16	47	0.761	-0.092	4.19	0.013	0.01	0	45.2	41.7	75.3	139	130	0	34	33
2014	9	9	20	26	47	0.768	-0.089	4.19	0.013	0.01	0	45.6	41.3	74.8	140	130	0	34	34
2014	9	9	20	36	47	0.732	-0.105	4.19	0.01	0.007	0	45.6	41.7	75.7	141	130	0	35	33
2014	9	9	20	46	47	0.751	-0.079	4.19	0.01	0.007	0	45.2	40.9	77	140	129	0	35	34
2014	9	9	20	56	47	0.774	-0.079	4.19	0.01	0.007	0	45.6	41.3	76.5	140	129	0	34	33
2014	9	9	21	6	47	0.758	-0.115	4.19	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	9	21	16	47	0.725	-0.095	4.19	0.01	0.007	0	44.7	40.9	76.5	139	129	0	35	34
2014	9	9	21	26	47	0.755	-0.075	4.19	0.013	0.01	0	44.7	40.9	75.7	139	128	0	35	33
2014	9	9	21	36	47	0.758	-0.112	4.19	0.01	0.007	0	44.3	40.4	76.5	138	128	0	35	34
2014	9	9	21	46	47	0.751	-0.082	4.19	0.016	0.013	0	44.3	40.4	77	138	128	0	35	34
2014	9	9	21	56	47	0.715	-0.089	4.19	0.01	0.007	0	44.7	40.9	77.4	138	128	0	34	33
2014	9	9	22	6	47	0.745	-0.098	4.19	0.01	0.007	0	44.7	40.9	76.5	139	129	0	35	34
2014	9	9	22	16	47	0.732	-0.066	4.19	0.01	0.007	0	43.9	40.4	77	137	128	0	35	34
2014	9	9	22	26	47	0.764	-0.098	4.19	0.01	0.007	0	44.3	40.9	77.4	138	128	0	35	33
2014	9	9	22	36	47	0.745	-0.069	4.19	0.013	0.01	0	43.9	40	76.5	137	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	22	46	47	0.761	-0.062	4.19	0.01	0.007	0	43.9	40.4	77	137	127	0	35	33
2014	9	9	22	56	47	0.732	-0.059	4.19	0.01	0.007	0	43.9	40.4	77.4	137	128	0	35	34
2014	9	9	23	6	47	0.751	-0.056	4.19	0.01	0.007	0	44.7	41.7	76.1	139	130	0	35	33
2014	9	9	23	16	47	0.761	-0.069	4.19	0.01	0.007	0	44.7	40.4	77	138	128	0	34	34
2014	9	9	23	26	47	0.771	-0.062	4.19	0.01	0.007	0	44.3	40.9	76.1	137	128	0	34	33
2014	9	9	23	36	47	0.748	-0.082	4.19	0.01	0.007	0	44.3	41.3	75.7	138	129	0	35	33
2014	9	9	23	46	47	0.745	-0.075	4.19	0.01	0.007	0	43.9	40	76.1	137	127	0	35	34
2014	9	9	23	56	47	0.764	-0.095	4.19	0.01	0.007	0	44.3	40	75.7	137	127	0	34	34
2014	9	10	0	6	47	0.764	-0.082	4.19	0.01	0.007	0	43.4	40.4	76.1	136	127	0	35	33
2014	9	10	0	16	47	0.768	-0.089	4.19	0.01	0.007	0	43.9	40.4	76.1	137	127	0	35	33
2014	9	10	0	26	47	0.764	-0.049	4.19	0.01	0.007	0	43.9	40.4	75.7	137	128	0	35	34
2014	9	10	0	36	47	0.741	-0.089	4.19	0.013	0.01	0	44.7	40.9	75.3	138	129	0	34	34
2014	9	10	0	46	47	0.778	-0.089	4.19	0.013	0.01	0	43.9	40.9	74.8	137	128	0	35	33
2014	9	10	0	56	47	0.748	-0.082	4.19	0.01	0.007	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	10	1	6	47	0.774	-0.089	4.19	0.013	0.01	0	43.4	40.4	76.1	136	127	0	35	33
2014	9	10	1	16	47	0.755	-0.043	4.19	0.013	0.01	0	43.4	40	76.1	136	127	0	35	34
2014	9	10	1	26	47	0.761	-0.075	4.19	0.01	0.007	0	43.4	40.9	75.7	136	128	0	35	33
2014	9	10	1	36	47	0.735	-0.062	4.19	0.01	0.007	0	43.4	40	75.7	136	127	0	35	34
2014	9	10	1	46	47	0.741	-0.089	4.19	0.013	0.01	0	43.4	40	75.3	136	127	0	35	34
2014	9	10	1	56	47	0.761	-0.098	4.19	0.01	0.007	0	43	40	75.3	135	127	0	35	34
2014	9	10	2	6	47	0.764	-0.085	4.19	0.01	0.007	0	43.4	40	75.7	135	127	0	34	34
2014	9	10	2	16	47	0.768	-0.095	4.19	0.013	0.01	0	43.4	40.4	72.7	136	128	0	35	34
2014	9	10	2	26	47	0.745	-0.075	4.19	0.01	0.007	0	44.7	41.3	75.3	138	130	0	34	34
2014	9	10	2	36	47	0.715	-0.085	4.19	0.01	0.007	0	44.3	40.9	74	137	129	0	34	34
2014	9	10	2	46	47	0.745	-0.082	4.193	0.01	0.007	0	43.4	40.4	74	136	127	0	35	33
2014	9	10	2	56	47	0.748	-0.095	4.193	0.01	0.007	0	43.9	40.4	74.4	136	127	0	34	33
2014	9	10	3	6	47	0.758	-0.102	4.193	0.01	0.007	0	43.4	40.9	73.5	136	128	0	35	33
2014	9	10	3	16	47	0.791	-0.079	4.193	0.01	0.007	0	43.9	40.4	74	136	127	0	34	33
2014	9	10	3	26	47	0.748	-0.085	4.193	0.016	0.016	0	43.4	40.4	74	136	127	0	35	33
2014	9	10	3	36	47	0.751	-0.062	4.193	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	10	3	46	47	0.755	-0.066	4.193	0.01	0.007	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	10	3	56	47	0.748	-0.085	4.193	0.01	0.007	0	43.9	40.9	72.7	136	128	0	34	33
2014	9	10	4	6	47	0.774	-0.092	4.193	0.01	0.007	0	43	40	71.8	135	127	0	35	34
2014	9	10	4	16	47	0.738	-0.066	4.193	0.013	0.01	0	43.4	40.9	72.2	136	128	0	35	33
2014	9	10	4	26	47	0.761	-0.066	4.196	0.01	0.007	0	43	39.6	71.4	135	126	0	35	34
2014	9	10	4	36	47	0.741	-0.079	4.196	0.01	0.007	0	43.4	40.4	72.2	136	127	0	35	33
2014	9	10	4	46	47	0.755	-0.095	4.196	0.01	0.007	0	43	40	71.8	135	127	0	35	34
2014	9	10	4	56	47	0.771	-0.072	4.196	0.016	0.013	0	43.4	40	67.1	136	127	0	35	34
2014	9	10	5	6	47	0.728	-0.095	4.196	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	10	5	16	47	0.738	-0.069	4.196	0.01	0.007	0	43.9	40.9	71.4	137	128	0	35	33
2014	9	10	5	26	47	0.797	-0.079	4.196	0.01	0.007	0	44.3	41.3	71	137	129	0	34	33
2014	9	10	5	36	47	0.748	-0.092	4.196	0.01	0.007	0	43.4	40.4	71	136	127	0	35	33
2014	9	10	5	46	47	0.771	-0.062	4.196	0.01	0.007	0	43.4	40	71.4	136	127	0	35	34
2014	9	10	5	56	47	0.761	-0.082	4.196	0.013	0.01	0	43	40.4	71.8	135	127	0	35	33
2014	9	10	6	6	47	0.732	-0.066	4.196	0.013	0.01	0	43	40	71.4	136	128	0	36	35
2014	9	10	6	16	47	0.755	-0.085	4.196	0.01	0.007	0	45.2	41.7	71	140	131	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	6	26	47	0.758	-0.075	4.196	0.01	0.007	0	46	43	71.4	142	133	0	35	33
2014	9	10	6	36	47	0.751	-0.105	4.196	0.01	0.007	0	45.6	42.1	70.5	141	132	0	35	34
2014	9	10	6	46	47	0.741	-0.092	4.199	0.01	0.007	0	45.2	41.7	71	140	131	0	35	34
2014	9	10	6	56	47	0.771	-0.075	4.199	0.01	0.007	0	45.2	42.6	71	140	132	0	35	33
2014	9	10	7	6	47	0.741	-0.098	4.203	0.01	0.007	0	44.3	41.7	71.4	138	130	0	35	33
2014	9	10	7	16	47	0.761	-0.079	4.203	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	10	7	26	47	0.748	-0.075	4.203	0.013	0.01	0	43	40	72.2	135	127	0	35	34
2014	9	10	7	36	47	0.761	-0.066	4.203	0.013	0.01	0	43	40	71.8	135	126	0	35	33
2014	9	10	7	46	47	0.761	-0.089	4.203	0.01	0.007	0	42.1	39.6	71.8	134	126	0	36	34
2014	9	10	7	56	47	0.735	-0.112	4.203	0.013	0.01	0	42.6	39.1	71.4	134	125	0	35	34
2014	9	10	8	6	47	0.745	-0.072	4.203	0.013	0.01	0	42.1	39.6	71.4	134	126	0	36	34
2014	9	10	8	16	47	0.751	-0.112	4.203	0.01	0.007	0	42.6	39.6	71.8	134	126	0	35	34
2014	9	10	8	26	47	0.722	-0.095	4.203	0.013	0.01	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	10	8	36	47	0.781	-0.095	4.203	0.013	0.01	0	42.6	40	71.4	134	126	0	35	33
2014	9	10	8	46	47	0.768	-0.062	4.199	0.01	0.007	0	42.6	39.6	71	134	126	0	35	34
2014	9	10	8	56	47	0.758	-0.075	4.199	0.01	0.007	0	42.6	39.6	71	134	126	0	35	34
2014	9	10	9	6	47	0.761	-0.066	4.196	0.01	0.007	0	42.6	39.6	71	134	126	0	35	34
2014	9	10	9	16	47	0.751	-0.095	4.196	0.016	0.013	0	42.6	40	71	134	127	0	35	34
2014	9	10	9	26	47	0.761	-0.079	4.196	0.013	0.01	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	10	9	36	47	0.748	-0.112	4.196	0.01	0.007	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	10	9	46	47	0.741	-0.075	4.196	0.013	0.01	0	42.6	40	71.8	134	126	0	35	33
2014	9	10	9	56	47	0.751	-0.092	4.193	0.01	0.007	0	43	39.6	71.8	134	126	0	34	34
2014	9	10	10	6	47	0.781	-0.108	4.193	0.013	0.01	0	42.1	39.6	71.4	134	126	0	36	34
2014	9	10	10	16	47	0.787	-0.092	4.193	0.016	0.013	0	42.6	39.6	71.8	134	126	0	35	34
2014	9	10	10	26	47	0.774	-0.049	4.193	0.01	0.007	0	42.6	40	71.4	134	127	0	35	34
2014	9	10	10	36	47	0.774	-0.075	4.193	0.01	0.007	0	43.4	40	72.2	135	127	0	34	34
2014	9	10	10	46	47	0.748	-0.105	4.193	0.016	0.013	0	42.6	40	72.7	134	126	0	35	33
2014	9	10	10	56	47	0.751	-0.079	4.19	0.01	0.007	0	42.6	40	73.1	134	127	0	35	34
2014	9	10	11	6	47	0.771	-0.105	4.19	0.013	0.01	0	42.6	40	73.1	134	126	0	35	33
2014	9	10	11	16	47	0.745	-0.082	4.19	0.01	0.007	0	43	40.4	73.1	135	127	0	35	33
2014	9	10	11	26	47	0.738	-0.089	4.19	0.01	0.007	0	43	40	73.1	135	127	0	35	34
2014	9	10	11	36	47	0.797	-0.102	4.19	0.01	0.007	0	43.4	40	73.1	135	127	0	34	34
2014	9	10	11	46	47	0.778	-0.154	4.19	0.01	0.007	0	42.1	39.1	73.1	133	125	0	35	34
2014	9	10	11	56	47	0.751	-0.157	4.19	0.01	0.007	0	42.6	39.1	74.8	133	125	0	34	34
2014	9	10	12	6	47	0.761	-0.112	4.19	0.013	0.01	0	42.1	39.6	74.4	133	126	0	35	34
2014	9	10	12	16	47	0.758	-0.125	4.19	0.013	0.01	0	43	40.4	74.4	135	127	0	35	33
2014	9	10	12	26	47	0.771	-0.128	4.186	0.016	0.013	0	43	40	66.2	135	127	0	35	34
2014	9	10	12	36	47	0.768	-0.092	4.19	0.01	0.007	0	43	40	74.4	135	127	0	35	34
2014	9	10	12	46	47	0.748	-0.167	4.186	0.013	0.01	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	10	12	56	47	0.768	-0.144	4.186	0.01	0.007	0	42.6	39.6	74.8	134	126	0	35	34
2014	9	10	13	6	47	0.794	-0.115	4.186	0.01	0.007	0	42.6	40	60.2	134	127	0	35	34
2014	9	10	13	16	47	0.768	-0.128	4.186	0.01	0.007	0	42.6	40	59.8	134	126	0	35	33
2014	9	10	13	26	47	0.774	-0.157	4.186	0.01	0.007	0	42.6	39.6	68.8	134	126	0	35	34
2014	9	10	13	36	47	0.755	-0.112	4.186	0.013	0.01	0	43	39.6	74	134	126	0	34	34
2014	9	10	13	46	47	0.791	-0.102	4.186	0.01	0.007	0	43	39.1	65.4	134	126	0	34	35
2014	9	10	13	56	47	0.761	-0.154	4.186	0.01	0.007	0	43	39.6	65.4	134	126	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	14	6	47	0.755	-0.089	4.186	0.01	0.007	0	43	40	70.5	135	127	0	35	34
2014	9	10	14	16	47	0.764	-0.128	4.183	0.013	0.01	0	43	39.6	61.1	134	126	0	34	34
2014	9	10	14	26	47	0.774	-0.102	4.183	0.01	0.007	0	42.6	39.6	61.1	134	126	0	35	34
2014	9	10	14	36	47	0.758	-0.108	4.183	0.013	0.01	0	43	40	70.5	135	127	0	35	34
2014	9	10	14	46	47	0.768	-0.089	4.183	0.01	0.007	0	42.6	39.6	68.8	134	126	0	35	34
2014	9	10	14	56	47	0.764	-0.118	4.183	0.013	0.01	0	42.6	39.6	61.9	134	127	0	35	35
2014	9	10	15	6	47	0.751	-0.092	4.183	0.01	0.007	0	43	40	59.8	135	127	0	35	34
2014	9	10	15	16	47	0.768	-0.131	4.183	0.01	0.007	0	42.6	39.6	76.5	133	126	0	34	34
2014	9	10	15	26	47	0.764	-0.125	4.183	0.01	0.007	0	42.6	39.6	70.5	134	126	0	35	34
2014	9	10	15	36	47	0.764	-0.118	4.183	0.01	0.007	0	42.6	40	71.8	134	127	0	35	34
2014	9	10	15	46	47	0.791	-0.102	4.183	0.01	0.007	0	43	40	70.1	135	127	0	35	34
2014	9	10	15	56	47	0.768	-0.092	4.18	0.01	0.007	0	43.4	41.3	58.9	136	129	0	35	33
2014	9	10	16	6	47	0.801	-0.121	4.18	0.01	0.007	0	43	40.9	75.7	135	128	0	35	33
2014	9	10	16	16	47	0.751	-0.128	4.18	0.016	0.013	0	43	40.4	68.8	135	128	0	35	34
2014	9	10	16	26	47	0.755	-0.128	4.18	0.01	0.007	0	43	40	75.3	135	127	0	35	34
2014	9	10	16	36	47	0.748	-0.108	4.183	0.01	0.007	0	43	40.4	72.2	135	128	0	35	34
2014	9	10	16	46	47	0.784	-0.128	4.18	0.013	0.01	0	43.4	40.4	75.7	136	128	0	35	34
2014	9	10	16	56	47	0.738	-0.161	4.18	0.01	0.007	0	43.9	40.4	62.8	136	128	0	34	34
2014	9	10	17	6	47	0.781	-0.102	4.183	0.01	0.007	0	43	39.6	75.3	135	126	0	35	34
2014	9	10	17	16	47	0.751	-0.121	4.18	0.01	0.007	0	43.4	40.4	71.4	135	127	0	34	33
2014	9	10	17	26	47	0.791	-0.085	4.18	0.01	0.007	0	43	40	72.7	135	127	0	35	34
2014	9	10	17	36	47	0.764	-0.102	4.183	0.01	0.007	0	43	39.6	75.7	135	126	0	35	34
2014	9	10	17	46	47	0.755	-0.079	4.18	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	10	17	56	47	0.745	-0.105	4.183	0.013	0.01	0	43	40.4	73.5	135	127	0	35	33
2014	9	10	18	6	47	0.768	-0.128	4.18	0.01	0.007	0	42.6	39.6	74.4	134	126	0	35	34
2014	9	10	18	16	47	0.774	-0.125	4.18	0.01	0.007	0	43	39.6	72.7	135	126	0	35	34
2014	9	10	18	26	47	0.784	-0.095	4.18	0.013	0.01	0	43.4	40	74	136	127	0	35	34
2014	9	10	18	36	47	0.735	-0.072	4.18	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	10	18	46	47	0.758	-0.075	4.183	0.01	0.007	0	43	40	76.1	135	127	0	35	34
2014	9	10	18	56	47	0.761	-0.066	4.18	0.01	0.007	0	43.4	40.4	71.8	136	128	0	35	34
2014	9	10	19	6	47	0.751	-0.079	4.18	0.013	0.01	0	43.9	40.9	74.8	137	129	0	35	34
2014	9	10	19	16	47	0.735	-0.082	4.183	0.013	0.01	0	43.9	41.3	74.4	137	129	0	35	33
2014	9	10	19	26	47	0.755	-0.112	4.183	0.01	0.007	0	43.4	40.4	74.4	136	128	0	35	34
2014	9	10	19	36	47	0.745	-0.095	4.18	0.01	0.007	0	44.7	41.7	74	139	131	0	35	34
2014	9	10	19	46	47	0.751	-0.102	4.18	0.01	0.007	0	44.7	41.7	74.8	139	131	0	35	34
2014	9	10	19	56	47	0.751	-0.085	4.183	0.013	0.01	0	44.3	41.7	74	138	130	0	35	33
2014	9	10	20	6	47	0.738	-0.082	4.183	0.013	0.01	0	43.9	41.3	74.4	137	129	0	35	33
2014	9	10	20	16	47	0.764	-0.085	4.183	0.01	0.007	0	45.2	42.1	74.4	140	132	0	35	34
2014	9	10	20	26	47	0.778	-0.121	4.183	0.01	0.007	0	43.9	40.4	74	137	129	0	35	35
2014	9	10	20	36	47	0.761	-0.079	4.183	0.013	0.01	0	43.9	40.9	74.4	137	129	0	35	34
2014	9	10	20	46	47	0.771	-0.082	4.183	0.01	0.007	0	43.4	40.4	73.5	136	128	0	35	34
2014	9	10	20	56	47	0.781	-0.085	4.183	0.01	0.007	0	43.4	40.4	73.5	136	128	0	35	34
2014	9	10	21	6	47	0.768	-0.102	4.183	0.01	0.007	0	43.9	40.9	70.5	137	129	0	35	34
2014	9	10	21	16	47	0.758	-0.075	4.183	0.01	0.007	0	43.4	40.9	73.1	136	128	0	35	33
2014	9	10	21	26	47	0.751	-0.085	4.183	0.01	0.007	0	43.9	41.3	69.2	137	129	0	35	33
2014	9	10	21	36	47	0.761	-0.089	4.183	0.013	0.01	0	43.4	40.4	73.5	136	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	21	46	47	0.761	-0.115	4.183	0.013	0.01	0	43	40.9	72.7	135	128	0	35	33
2014	9	10	21	56	47	0.738	-0.085	4.183	0.013	0.01	0	43.9	40.9	73.1	137	129	0	35	34
2014	9	10	22	6	47	0.764	-0.102	4.183	0.01	0.007	0	43.4	40.9	74.8	136	128	0	35	33
2014	9	10	22	16	47	0.761	-0.089	4.183	0.01	0.007	0	43.9	40.9	74.4	136	128	0	34	33
2014	9	10	22	26	47	0.761	-0.066	4.183	0.01	0.007	0	43.4	40.4	74.8	136	128	0	35	34
2014	9	10	22	36	47	0.755	-0.089	4.183	0.01	0.007	0	44.3	40.9	74	137	129	0	34	34
2014	9	10	22	46	47	0.755	-0.079	4.183	0.01	0.007	0	43.9	41.3	74	137	129	0	35	33
2014	9	10	22	56	47	0.771	-0.098	4.183	0.01	0.007	0	43.4	40.9	74	136	128	0	35	33
2014	9	10	23	6	47	0.768	-0.112	4.183	0.01	0.007	0	43.4	40.4	74	136	128	0	35	34
2014	9	10	23	16	47	0.741	-0.079	4.183	0.01	0.007	0	43	40.4	74.4	135	128	0	35	34
2014	9	10	23	26	47	0.735	-0.095	4.183	0.013	0.01	0	43	40.4	74	135	127	0	35	33
2014	9	10	23	36	47	0.771	-0.049	4.186	0.01	0.007	0	43	40.9	74	135	128	0	35	33
2014	9	10	23	46	47	0.768	-0.095	4.186	0.01	0.007	0	43.4	40.9	74	136	129	0	35	34
2014	9	10	23	56	47	0.748	-0.085	4.186	0.01	0.007	0	43.4	40.9	73.1	136	128	0	35	33
2014	9	11	0	6	47	0.761	-0.089	4.186	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	11	0	16	47	0.735	-0.112	4.186	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	11	0	26	47	0.778	-0.072	4.186	0.013	0.01	0	43.9	40	73.5	137	127	0	35	34
2014	9	11	0	36	47	0.758	-0.102	4.186	0.013	0.01	0	43.9	40.4	74	137	128	0	35	34
2014	9	11	0	46	47	0.784	-0.112	4.186	0.01	0.007	0	43.9	40.9	74	137	128	0	35	33
2014	9	11	0	56	47	0.741	-0.079	4.186	0.01	0.007	0	44.3	40.9	74	138	128	0	35	33
2014	9	11	1	6	47	0.764	-0.102	4.186	0.01	0.007	0	44.3	40.4	74	138	128	0	35	34
2014	9	11	1	16	47	0.764	-0.095	4.186	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	11	1	26	47	0.748	-0.098	4.186	0.013	0.01	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	11	1	36	47	0.745	-0.072	4.186	0.01	0.007	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	11	1	46	47	0.768	-0.089	4.186	0.01	0.007	0	44.7	40.4	73.5	138	128	0	34	34
2014	9	11	1	56	47	0.761	-0.072	4.186	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	11	2	6	47	0.735	-0.098	4.186	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	11	2	16	47	0.745	-0.089	4.186	0.013	0.01	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	11	2	26	47	0.761	-0.089	4.186	0.013	0.01	0	43.9	40	72.7	136	127	0	34	34
2014	9	11	2	36	47	0.764	-0.112	4.186	0.01	0.007	0	44.3	40.4	73.1	137	127	0	34	33
2014	9	11	2	46	47	0.764	-0.108	4.186	0.01	0.007	0	43.9	40.4	70.5	136	127	0	34	33
2014	9	11	2	56	47	0.784	-0.092	4.186	0.01	0.007	0	43.4	40.4	72.7	136	127	0	35	33
2014	9	11	3	6	47	0.741	-0.079	4.186	0.01	0.007	0	43.9	40.4	72.2	137	128	0	35	34
2014	9	11	3	16	47	0.761	-0.112	4.186	0.01	0.007	0	43.9	40.4	72.2	137	128	0	35	34
2014	9	11	3	26	47	0.751	-0.069	4.186	0.01	0.007	0	44.3	40.4	72.7	138	128	0	35	34
2014	9	11	3	36	47	0.764	-0.079	4.19	0.01	0.007	0	44.7	41.7	71.8	139	130	0	35	33
2014	9	11	3	46	47	0.774	-0.085	4.19	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	11	3	56	47	0.719	-0.079	4.19	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	11	4	6	47	0.751	-0.092	4.19	0.01	0.007	0	43.4	40	71.8	136	127	0	35	34
2014	9	11	4	16	47	0.738	-0.079	4.19	0.01	0.007	0	43.4	40.4	71.8	136	127	0	35	33
2014	9	11	4	26	47	0.758	-0.052	4.19	0.01	0.007	0	43.4	40	72.2	136	127	0	35	34
2014	9	11	4	36	47	0.732	-0.079	4.193	0.01	0.007	0	43.9	40.4	72.2	137	128	0	35	34
2014	9	11	4	46	47	0.732	-0.059	4.19	0.01	0.007	0	44.3	41.3	71.4	138	129	0	35	33
2014	9	11	4	56	47	0.771	-0.095	4.19	0.01	0.007	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	11	5	6	47	0.791	-0.069	4.19	0.01	0.007	0	43.4	40	71	136	127	0	35	34
2014	9	11	5	16	47	0.741	-0.108	4.19	0.01	0.007	0	43.9	41.3	70.5	138	129	0	36	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	5	26	47	0.751	-0.075	4.19	0.01	0.007	0	44.3	40.9	70.5	138	129	0	35	34
2014	9	11	5	36	47	0.768	-0.075	4.19	0.01	0.007	0	45.2	40.9	70.5	139	129	0	34	34
2014	9	11	5	46	47	0.774	-0.102	4.19	0.01	0.007	0	44.7	40.9	71	139	129	0	35	34
2014	9	11	5	56	47	0.755	-0.105	4.193	0.01	0.007	0	45.2	41.3	69.7	140	130	0	35	34
2014	9	11	6	6	47	0.745	-0.066	4.19	0.016	0.016	0	43.9	40.4	70.5	137	128	0	35	34
2014	9	11	6	16	47	0.735	-0.092	4.193	0.01	0.007	0	43.9	40.4	70.5	137	127	0	35	33
2014	9	11	6	26	47	0.751	-0.069	4.196	0.01	0.007	0	45.2	42.1	69.2	140	131	0	35	33
2014	9	11	6	36	47	0.758	-0.092	4.196	0.01	0.007	0	45.2	41.3	71	140	131	0	35	35
2014	9	11	6	46	47	0.764	-0.079	4.196	0.01	0.007	0	44.7	41.7	70.5	140	130	0	36	33
2014	9	11	6	56	47	0.764	-0.072	4.196	0.01	0.007	0	45.2	41.3	71	140	130	0	35	34
2014	9	11	7	6	47	0.774	-0.079	4.199	0.013	0.01	0	46.4	42.6	71	142	132	0	34	33
2014	9	11	7	16	47	0.745	-0.095	4.199	0.01	0.007	0	43.4	39.6	71.4	136	126	0	35	34
2014	9	11	7	26	47	0.787	-0.092	4.199	0.013	0.01	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	11	7	36	47	0.738	-0.056	4.199	0.013	0.01	0	43.4	40	71.8	136	127	0	35	34
2014	9	11	7	46	47	0.791	-0.105	4.199	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	11	7	56	47	0.761	-0.092	4.199	0.01	0.007	0	43.4	39.6	72.2	135	125	0	34	33
2014	9	11	8	6	47	0.761	-0.079	4.199	0.013	0.01	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	11	8	16	47	0.761	-0.095	4.199	0.01	0.007	0	42.6	39.6	72.2	134	125	0	35	33
2014	9	11	8	26	47	0.764	-0.115	4.199	0.01	0.007	0	42.6	39.1	72.7	134	125	0	35	34
2014	9	11	8	36	47	0.745	-0.082	4.199	0.01	0.007	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	11	8	46	47	0.755	-0.095	4.199	0.01	0.007	0	42.6	38.7	72.7	134	124	0	35	34
2014	9	11	8	56	47	0.781	-0.089	4.199	0.01	0.007	0	42.6	38.7	72.7	134	125	0	35	35
2014	9	11	9	6	47	0.751	-0.095	4.199	0.01	0.007	0	42.1	39.1	72.7	133	125	0	35	34
2014	9	11	9	16	47	0.761	-0.092	4.199	0.01	0.007	0	42.6	38.7	73.1	134	125	0	35	35
2014	9	11	9	26	47	0.758	-0.108	4.199	0.013	0.01	0	42.6	38.7	71.8	134	124	0	35	34
2014	9	11	9	36	47	0.745	-0.095	4.199	0.01	0.007	0	42.1	38.7	72.2	133	124	0	35	34
2014	9	11	9	46	47	0.758	-0.112	4.196	0.01	0.007	0	42.1	38.7	72.2	133	124	0	35	34
2014	9	11	9	56	47	0.761	-0.115	4.196	0.01	0.007	0	42.1	39.1	71.8	133	124	0	35	33
2014	9	11	10	6	47	0.794	-0.079	4.196	0.01	0.007	0	41.7	39.1	72.2	133	124	0	36	33
2014	9	11	10	16	47	0.755	-0.056	4.193	0.01	0.007	0	42.1	39.1	71.8	133	125	0	35	34
2014	9	11	10	26	47	0.755	-0.098	4.193	0.01	0.007	0	42.1	39.1	70.5	133	124	0	35	33
2014	9	11	10	36	47	0.741	-0.092	4.19	0.013	0.01	0	42.1	39.1	71.8	133	125	0	35	34
2014	9	11	10	46	47	0.755	-0.105	4.19	0.01	0.007	0	42.6	39.1	71.4	134	125	0	35	34
2014	9	11	10	56	47	0.761	-0.105	4.19	0.01	0.007	0	42.1	39.1	72.2	133	125	0	35	34
2014	9	11	11	6	47	0.774	-0.108	4.186	0.01	0.007	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	11	11	16	47	0.794	-0.108	4.186	0.013	0.01	0	43	39.6	72.7	135	126	0	35	34
2014	9	11	11	26	47	0.758	-0.095	4.186	0.01	0.007	0	42.1	39.6	72.7	134	125	0	36	33
2014	9	11	11	36	47	0.771	-0.089	4.186	0.01	0.007	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	11	11	46	47	0.761	-0.079	4.186	0.013	0.01	0	42.6	39.6	72.7	134	125	0	35	33
2014	9	11	11	56	47	0.768	-0.095	4.186	0.01	0.007	0	41.7	38.7	72.7	133	124	0	36	34
2014	9	11	12	6	47	0.745	-0.128	4.183	0.01	0.007	0	42.1	38.7	72.7	133	124	0	35	34
2014	9	11	12	16	47	0.774	-0.112	4.186	0.01	0.007	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	11	12	26	47	0.778	-0.141	4.183	0.01	0.007	0	42.1	39.1	69.7	133	124	0	35	33
2014	9	11	12	36	47	0.768	-0.151	4.183	0.01	0.007	0	41.7	37.8	71.4	132	123	0	35	35
2014	9	11	12	46	47	0.755	-0.157	4.183	0.013	0.01	0	42.1	38.7	72.7	133	124	0	35	34
2014	9	11	12	56	47	0.771	-0.108	4.183	0.01	0.007	0	43	39.6	68.4	135	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	13	6	47	0.771	-0.121	4.183	0.01	0.007	0	41.7	38.7	72.7	132	124	0	35	34
2014	9	11	13	16	47	0.761	-0.157	4.183	0.013	0.01	0	41.7	38.7	74.8	132	124	0	35	34
2014	9	11	13	26	47	0.768	-0.118	4.183	0.013	0.01	0	42.1	39.1	63.2	133	124	0	35	33
2014	9	11	13	36	47	0.758	-0.151	4.183	0.01	0.007	0	42.1	38.7	70.1	133	124	0	35	34
2014	9	11	13	46	47	0.764	-0.141	4.18	0.013	0.01	0	42.6	39.1	73.1	134	125	0	35	34
2014	9	11	13	56	47	0.781	-0.141	4.18	0.013	0.01	0	43	39.1	74	135	126	0	35	35
2014	9	11	14	6	47	0.748	-0.098	4.18	0.013	0.01	0	43.4	39.6	66.2	136	126	0	35	34
2014	9	11	14	16	47	0.761	-0.141	4.18	0.01	0.007	0	42.6	39.1	62.8	135	125	0	36	34
2014	9	11	14	26	47	0.751	-0.157	4.18	0.013	0.01	0	42.6	39.1	66.2	135	125	0	36	34
2014	9	11	14	36	47	0.774	-0.171	4.18	0.016	0.013	0	43.4	39.1	66.2	135	125	0	34	34
2014	9	11	14	46	47	0.774	-0.144	4.18	0.01	0.007	0	43.4	40	65.4	136	126	0	35	33
2014	9	11	14	56	47	0.741	-0.141	4.18	0.01	0.007	0	43.4	39.6	71.8	136	126	0	35	34
2014	9	11	15	6	47	0.781	-0.148	4.18	0.013	0.01	0	43.4	39.6	71	136	126	0	35	34
2014	9	11	15	16	47	0.774	-0.144	4.177	0.01	0.007	0	43	39.6	67.5	135	126	0	35	34
2014	9	11	15	26	47	0.761	-0.131	4.177	0.01	0.007	0	43.4	39.1	74.8	136	126	0	35	35
2014	9	11	15	36	47	0.791	-0.115	4.177	0.01	0.007	0	43.4	39.6	74.8	136	126	0	35	34
2014	9	11	15	46	47	0.791	-0.138	4.177	0.016	0.013	0	43	39.1	74.8	135	125	0	35	34
2014	9	11	15	56	47	0.774	-0.128	4.177	0.013	0.01	0	43.4	39.6	63.2	136	126	0	35	34
2014	9	11	16	6	47	0.781	-0.154	4.177	0.013	0.01	0	43.4	40	74	136	126	0	35	33
2014	9	11	16	16	47	0.771	-0.095	4.177	0.01	0.007	0	44.3	40.9	74	138	128	0	35	33
2014	9	11	16	26	47	0.761	-0.135	4.177	0.01	0.007	0	43.4	40	72.2	136	127	0	35	34
2014	9	11	16	36	47	0.791	-0.108	4.177	0.01	0.007	0	43.9	40	69.2	137	127	0	35	34
2014	9	11	16	46	47	0.761	-0.121	4.177	0.01	0.007	0	43.9	40	67.5	137	127	0	35	34
2014	9	11	16	56	47	0.764	-0.131	4.177	0.016	0.013	0	43.9	40	73.5	137	127	0	35	34
2014	9	11	17	6	47	0.784	-0.092	4.177	0.016	0.013	0	43.4	39.6	74	136	126	0	35	34
2014	9	11	17	16	47	0.751	-0.118	4.177	0.01	0.007	0	43.4	39.6	74.4	136	126	0	35	34
2014	9	11	17	26	47	0.771	-0.115	4.177	0.01	0.007	0	43.4	39.1	74	136	125	0	35	34
2014	9	11	17	36	47	0.768	-0.108	4.177	0.013	0.01	0	43	39.6	74	136	125	0	36	33
2014	9	11	17	46	47	0.791	-0.121	4.177	0.01	0.007	0	43.4	39.6	63.6	136	126	0	35	34
2014	9	11	17	56	47	0.751	-0.095	4.177	0.016	0.013	0	43.4	40	74.4	136	126	0	35	33
2014	9	11	18	6	47	0.784	-0.102	4.177	0.01	0.007	0	43.9	39.6	74	137	126	0	35	34
2014	9	11	18	16	47	0.751	-0.092	4.18	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	11	18	26	47	0.761	-0.105	4.177	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	11	18	36	47	0.732	-0.098	4.18	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	11	18	46	47	0.745	-0.108	4.18	0.01	0.007	0	43.9	40	74	137	127	0	35	34
2014	9	11	18	56	47	0.778	-0.112	4.18	0.013	0.01	0	43.9	40	74.4	137	127	0	35	34
2014	9	11	19	6	47	0.771	-0.066	4.18	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	11	19	16	47	0.774	-0.095	4.18	0.016	0.016	0	44.3	40	74	138	127	0	35	34
2014	9	11	19	26	47	0.755	-0.072	4.18	0.01	0.007	0	44.7	40.4	73.5	139	128	0	35	34
2014	9	11	19	36	47	0.771	-0.066	4.18	0.01	0.007	0	44.7	40.4	72.7	139	128	0	35	34
2014	9	11	19	46	47	0.768	-0.092	4.18	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	11	19	56	47	0.741	-0.075	4.18	0.01	0.007	0	44.3	41.3	74	139	129	0	36	33
2014	9	11	20	6	47	0.771	-0.095	4.18	0.01	0.007	0	44.7	40.4	74.4	139	128	0	35	34
2014	9	11	20	16	47	0.745	-0.062	4.18	0.016	0.013	0	45.2	40.9	73.5	140	129	0	35	34
2014	9	11	20	26	47	0.761	-0.085	4.183	0.013	0.01	0	43.9	40.4	73.5	138	128	0	36	34
2014	9	11	20	36	47	0.771	-0.056	4.18	0.013	0.01	0	44.7	40.9	73.1	139	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	20	46	47	0.764	-0.108	4.18	0.013	0.01	0	44.7	40.4	73.1	139	128	0	35	34
2014	9	11	20	56	47	0.778	-0.112	4.18	0.01	0.007	0	44.3	40.4	69.2	138	128	0	35	34
2014	9	11	21	6	47	0.741	-0.079	4.183	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	11	21	16	47	0.748	-0.108	4.183	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	11	21	26	47	0.751	-0.059	4.183	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	11	21	36	47	0.761	-0.079	4.183	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	11	21	46	47	0.771	-0.062	4.183	0.01	0.007	0	44.7	40.4	74	138	128	0	34	34
2014	9	11	21	56	47	0.771	-0.082	4.183	0.01	0.007	0	44.3	40	73.5	138	128	0	35	35
2014	9	11	22	6	47	0.764	-0.095	4.183	0.013	0.01	0	43.9	40.4	73.5	137	127	0	35	33
2014	9	11	22	16	47	0.764	-0.108	4.183	0.02	0.016	0	44.7	40.9	73.1	139	129	0	35	34
2014	9	11	22	26	47	0.801	-0.092	4.183	0.01	0.007	0	44.3	40.9	72.7	138	128	0	35	33
2014	9	11	22	36	47	0.764	-0.079	4.183	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	11	22	46	47	0.735	-0.075	4.183	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	11	22	56	47	0.774	-0.085	4.183	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	11	23	6	47	0.745	-0.112	4.183	0.016	0.013	0	44.3	40	72.7	137	127	0	34	34
2014	9	11	23	16	47	0.791	-0.095	4.183	0.013	0.01	0	44.3	40	72.7	138	127	0	35	34
2014	9	11	23	26	47	0.761	-0.082	4.183	0.01	0.007	0	44.3	40.4	72.7	138	128	0	35	34
2014	9	11	23	36	47	0.728	-0.095	4.183	0.013	0.01	0	43.9	40.4	72.7	137	127	0	35	33
2014	9	11	23	46	47	0.781	-0.089	4.183	0.013	0.01	0	43.9	40.4	72.2	137	127	0	35	33
2014	9	11	23	56	47	0.771	-0.089	4.183	0.01	0.007	0	43.9	40.4	71.8	137	127	0	35	33
2014	9	12	0	6	47	0.774	-0.059	4.183	0.01	0.007	0	44.3	40	72.2	138	127	0	35	34
2014	9	12	0	16	47	0.781	-0.062	4.186	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	12	0	26	47	0.761	-0.095	4.186	0.013	0.01	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	12	0	36	47	0.791	-0.102	4.186	0.01	0.007	0	43.4	40.4	71.8	137	127	0	36	33
2014	9	12	0	46	47	0.764	-0.098	4.186	0.013	0.01	0	44.3	40	71	138	126	0	35	33
2014	9	12	0	56	47	0.761	-0.079	4.186	0.01	0.007	0	44.3	40.9	71.4	138	128	0	35	33
2014	9	12	1	6	47	0.751	-0.095	4.186	0.01	0.007	0	44.7	40.4	71.4	138	128	0	34	34
2014	9	12	1	16	47	0.768	-0.108	4.186	0.013	0.01	0	43.9	40.4	71.8	138	128	0	36	34
2014	9	12	1	26	47	0.787	-0.089	4.186	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	12	1	36	47	0.732	-0.079	4.186	0.01	0.007	0	43.9	40	71.8	137	126	0	35	33
2014	9	12	1	46	47	0.748	-0.079	4.186	0.013	0.01	0	44.3	40	71	138	127	0	35	34
2014	9	12	1	56	47	0.751	-0.085	4.186	0.013	0.01	0	44.3	40	71	137	127	0	34	34
2014	9	12	2	6	47	0.758	-0.069	4.186	0.01	0.007	0	44.7	40.4	71.4	139	128	0	35	34
2014	9	12	2	16	47	0.768	-0.095	4.186	0.01	0.007	0	43.9	39.6	69.7	138	127	0	36	35
2014	9	12	2	26	47	0.771	-0.095	4.19	0.01	0.007	0	43.9	40	71.4	137	127	0	35	34
2014	9	12	2	36	47	0.778	-0.098	4.19	0.01	0.007	0	43.9	40.4	70.5	137	127	0	35	33
2014	9	12	2	46	47	0.761	-0.082	4.19	0.01	0.007	0	43.9	40	71	137	127	0	35	34
2014	9	12	2	56	47	0.774	-0.092	4.19	0.01	0.007	0	43.9	40	70.1	137	127	0	35	34
2014	9	12	3	6	47	0.764	-0.079	4.19	0.013	0.01	0	43.9	40	70.5	137	127	0	35	34
2014	9	12	3	16	47	0.761	-0.082	4.19	0.01	0.007	0	43.9	40.4	70.5	137	127	0	35	33
2014	9	12	3	26	47	0.755	-0.108	4.19	0.01	0.007	0	43.9	40.4	70.5	137	128	0	35	34
2014	9	12	3	36	47	0.761	-0.079	4.193	0.01	0.007	0	44.3	41.3	70.1	138	129	0	35	33
2014	9	12	3	46	47	0.751	-0.092	4.193	0.01	0.007	0	43.9	40.4	70.5	138	128	0	36	34
2014	9	12	3	56	47	0.801	-0.125	4.196	0.013	0.01	0	43.9	40.4	70.5	138	128	0	36	34
2014	9	12	4	6	47	0.787	-0.079	4.196	0.013	0.01	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	12	4	16	47	0.751	-0.069	4.196	0.016	0.013	0	43.9	40	70.1	137	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	4	26	47	0.774	-0.112	4.196	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	12	4	36	47	0.778	-0.102	4.199	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	12	4	46	47	0.761	-0.079	4.199	0.013	0.01	0	43.9	40	70.5	137	127	0	35	34
2014	9	12	4	56	47	0.751	-0.079	4.199	0.013	0.01	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	12	5	6	47	0.771	-0.079	4.199	0.01	0.007	0	43.4	40	71	136	126	0	35	33
2014	9	12	5	16	47	0.748	-0.095	4.199	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	12	5	26	47	0.778	-0.092	4.199	0.01	0.007	0	44.3	40	71.8	137	127	0	34	34
2014	9	12	5	36	47	0.768	-0.085	4.199	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	12	5	46	47	0.751	-0.075	4.203	0.01	0.007	0	44.3	40.4	72.7	138	128	0	35	34
2014	9	12	5	56	47	0.735	-0.118	4.203	0.01	0.007	0	44.7	40.9	66.7	139	129	0	35	34
2014	9	12	6	6	47	0.781	-0.108	4.203	0.01	0.007	0	45.6	41.7	72.2	141	131	0	35	34
2014	9	12	6	16	47	0.771	-0.072	4.203	0.013	0.01	0	45.6	41.7	72.2	141	131	0	35	34
2014	9	12	6	26	47	0.768	-0.095	4.203	0.013	0.01	0	44.7	40.9	72.2	139	129	0	35	34
2014	9	12	6	36	47	0.761	-0.075	4.203	0.01	0.007	0	44.7	40.9	73.5	139	129	0	35	34
2014	9	12	6	46	47	0.771	-0.105	4.203	0.01	0.007	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	12	6	56	47	0.787	-0.082	4.203	0.013	0.01	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	12	7	6	47	0.748	-0.095	4.203	0.016	0.013	0	44.7	40.4	73.5	138	128	0	34	34
2014	9	12	7	16	47	0.751	-0.079	4.203	0.01	0.007	0	43.4	39.6	74	136	126	0	35	34
2014	9	12	7	26	47	0.761	-0.075	4.203	0.01	0.007	0	43.4	39.6	74	136	126	0	35	34
2014	9	12	7	36	47	0.758	-0.072	4.203	0.01	0.007	0	43.9	39.6	74.4	136	126	0	34	34
2014	9	12	7	46	47	0.761	-0.066	4.203	0.01	0.007	0	43	39.6	74.4	135	126	0	35	34
2014	9	12	7	56	47	0.751	-0.079	4.203	0.01	0.007	0	42.6	39.1	74.8	135	125	0	36	34
2014	9	12	8	6	47	0.758	-0.092	4.206	0.01	0.007	0	43	39.1	74.4	135	125	0	35	34
2014	9	12	8	16	47	0.764	-0.079	4.203	0.01	0.007	0	43	39.6	74.4	135	126	0	35	34
2014	9	12	8	26	47	0.771	-0.085	4.206	0.01	0.007	0	42.6	39.6	74.4	135	126	0	36	34
2014	9	12	8	36	47	0.761	-0.085	4.206	0.013	0.01	0	42.6	39.1	74.8	134	125	0	35	34
2014	9	12	8	46	47	0.745	-0.095	4.203	0.013	0.01	0	43	39.1	74.4	135	125	0	35	34
2014	9	12	8	56	47	0.748	-0.079	4.203	0.01	0.007	0	42.6	39.1	74	134	125	0	35	34
2014	9	12	9	6	47	0.764	-0.089	4.203	0.01	0.007	0	43	38.7	74	135	125	0	35	35
2014	9	12	9	16	47	0.771	-0.095	4.203	0.013	0.01	0	43	39.6	74	135	126	0	35	34
2014	9	12	9	26	47	0.768	-0.092	4.203	0.01	0.007	0	42.6	39.6	73.5	134	125	0	35	33
2014	9	12	9	36	47	0.751	-0.085	4.203	0.013	0.01	0	42.6	39.1	73.1	135	125	0	36	34
2014	9	12	9	46	47	0.774	-0.075	4.206	0.01	0.007	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	12	9	56	47	0.807	-0.115	4.203	0.01	0.007	0	42.6	39.1	74	135	125	0	36	34
2014	9	12	10	6	47	0.745	-0.095	4.203	0.01	0.007	0	43	39.6	74	135	125	0	35	33
2014	9	12	10	16	47	0.814	-0.089	4.203	0.01	0.007	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	12	10	26	47	0.761	-0.108	4.203	0.01	0.007	0	42.1	39.1	74	133	125	0	35	34
2014	9	12	10	36	47	0.791	-0.118	4.203	0.013	0.01	0	42.1	38.7	66.2	133	124	0	35	34
2014	9	12	10	46	47	0.761	-0.095	4.203	0.013	0.01	0	42.1	38.3	68.4	133	123	0	35	34
2014	9	12	10	56	47	0.755	-0.128	4.203	0.01	0.007	0	42.1	38.3	71.8	133	123	0	35	34
2014	9	12	11	6	47	0.758	-0.108	4.203	0.01	0.007	0	42.1	38.7	73.1	133	124	0	35	34
2014	9	12	11	16	47	0.764	-0.115	4.203	0.013	0.01	0	42.1	38.7	72.7	133	124	0	35	34
2014	9	12	11	26	47	0.787	-0.121	4.203	0.01	0.007	0	42.1	38.3	71.8	133	123	0	35	34
2014	9	12	11	36	47	0.774	-0.128	4.199	0.013	0.01	0	42.1	38.7	72.2	133	124	0	35	34
2014	9	12	11	46	47	0.781	-0.115	4.199	0.01	0.007	0	42.1	38.7	67.1	133	124	0	35	34
2014	9	12	11	56	47	0.758	-0.157	4.199	0.01	0.007	0	42.6	39.1	72.2	134	125	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	12	6	47	0.778	-0.128	4.199	0.013	0.01	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	12	12	16	47	0.784	-0.125	4.196	0.013	0.01	0	42.1	38.7	71.4	134	124	0	36	34
2014	9	12	12	26	47	0.778	-0.157	4.196	0.01	0.007	0	42.6	38.7	72.2	133	124	0	34	34
2014	9	12	12	36	47	0.771	-0.108	4.193	0.01	0.007	0	43	39.6	58.9	135	126	0	35	34
2014	9	12	12	46	47	0.791	-0.115	4.193	0.01	0.007	0	42.6	39.1	61.5	134	125	0	35	34
2014	9	12	12	56	47	0.791	-0.151	4.19	0.01	0.007	0	42.1	38.7	64.1	133	124	0	35	34
2014	9	12	13	6	47	0.738	-0.154	4.19	0.01	0.007	0	42.1	38.7	59.8	133	124	0	35	34
2014	9	12	13	16	47	0.774	-0.144	4.186	0.016	0.013	0	42.1	38.7	69.2	133	124	0	35	34
2014	9	12	13	26	47	0.768	-0.118	4.19	0.01	0.007	0	43	39.1	52	135	125	0	35	34
2014	9	12	13	36	47	0.774	-0.118	4.186	0.013	0.01	0	42.1	39.1	60.6	133	125	0	35	34
2014	9	12	13	46	47	0.784	-0.108	4.186	0.016	0.013	0	42.6	39.1	54.2	134	125	0	35	34
2014	9	12	13	56	47	0.761	-0.157	4.186	0.01	0.007	0	42.1	39.6	69.2	133	125	0	35	33
2014	9	12	14	6	47	0.791	-0.125	4.186	0.01	0.007	0	43	39.6	52	135	126	0	35	34
2014	9	12	14	16	47	0.778	-0.141	4.183	0.01	0.007	0	42.6	38.7	72.7	134	124	0	35	34
2014	9	12	14	26	47	0.787	-0.154	4.183	0.01	0.007	0	42.6	39.1	64.5	134	125	0	35	34
2014	9	12	14	36	47	0.774	-0.151	4.183	0.01	0.007	0	42.6	39.6	66.2	134	125	0	35	33
2014	9	12	14	46	47	0.764	-0.125	4.183	0.01	0.007	0	42.6	39.1	55.5	134	125	0	35	34
2014	9	12	14	56	47	0.778	-0.138	4.183	0.01	0.007	0	43	39.1	63.2	135	125	0	35	34
2014	9	12	15	6	47	0.787	-0.108	4.183	0.01	0.007	0	43	39.1	63.2	135	125	0	35	34
2014	9	12	15	16	47	0.761	-0.141	4.183	0.01	0.007	0	43	39.6	72.7	135	126	0	35	34
2014	9	12	15	26	47	0.791	-0.128	4.18	0.013	0.01	0	43.4	39.6	56.8	136	126	0	35	34
2014	9	12	15	36	47	0.778	-0.148	4.183	0.01	0.007	0	42.6	39.1	55.5	134	125	0	35	34
2014	9	12	15	46	47	0.771	-0.089	4.183	0.01	0.007	0	43	39.6	65.4	135	126	0	35	34
2014	9	12	15	56	47	0.797	-0.131	4.183	0.013	0.01	0	42.6	40	55.5	135	126	0	36	33
2014	9	12	16	6	47	0.774	-0.125	4.183	0.01	0.007	0	43	39.6	62.4	135	126	0	35	34
2014	9	12	16	16	47	0.778	-0.128	4.18	0.013	0.01	0	43.4	40	66.7	136	127	0	35	34
2014	9	12	16	26	47	0.755	-0.138	4.18	0.01	0.007	0	43.4	40.4	65.4	136	127	0	35	33
2014	9	12	16	36	47	0.768	-0.125	4.18	0.01	0.007	0	43.4	40	62.4	136	127	0	35	34
2014	9	12	16	46	47	0.761	-0.128	4.183	0.01	0.007	0	43.4	39.6	67.9	136	126	0	35	34
2014	9	12	16	56	47	0.761	-0.128	4.18	0.01	0.007	0	44.3	40.4	64.5	137	127	0	34	33
2014	9	12	17	6	47	0.778	-0.148	4.18	0.01	0.007	0	43.4	39.6	63.6	136	126	0	35	34
2014	9	12	17	16	47	0.758	-0.108	4.183	0.013	0.01	0	43.4	39.6	62.4	135	126	0	34	34
2014	9	12	17	26	47	0.774	-0.108	4.183	0.013	0.01	0	43	39.1	56.8	135	125	0	35	34
2014	9	12	17	36	47	0.787	-0.131	4.183	0.01	0.007	0	43	39.1	69.2	135	125	0	35	34
2014	9	12	17	46	47	0.804	-0.148	4.183	0.01	0.007	0	43	39.1	67.1	135	125	0	35	34
2014	9	12	17	56	47	0.784	-0.157	4.18	0.013	0.01	0	43.9	39.6	66.2	136	126	0	34	34
2014	9	12	18	6	47	0.774	-0.141	4.183	0.013	0.01	0	43	39.1	60.6	135	125	0	35	34
2014	9	12	18	16	47	0.784	-0.125	4.183	0.01	0.007	0	43.4	39.6	61.5	136	126	0	35	34
2014	9	12	18	26	47	0.774	-0.125	4.183	0.01	0.007	0	43.4	39.6	64.9	136	126	0	35	34
2014	9	12	18	36	47	0.778	-0.121	4.183	0.013	0.01	0	43.9	39.6	69.2	137	127	0	35	35
2014	9	12	18	46	47	0.778	-0.098	4.183	0.013	0.01	0	43.4	39.6	72.2	136	126	0	35	34
2014	9	12	18	56	47	0.791	-0.112	4.183	0.013	0.01	0	44.3	40.4	72.7	137	127	0	34	33
2014	9	12	19	6	47	0.787	-0.082	4.183	0.01	0.007	0	44.3	40.9	73.1	138	128	0	35	33
2014	9	12	19	16	47	0.791	-0.062	4.183	0.01	0.007	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	12	19	26	47	0.761	-0.089	4.183	0.013	0.01	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	12	19	36	47	0.738	-0.098	4.186	0.01	0.007	0	45.2	40.9	72.7	139	129	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	19	46	47	0.778	-0.095	4.186	0.01	0.007	0	45.6	41.3	72.7	140	130	0	34	34
2014	9	12	19	56	47	0.771	-0.095	4.186	0.01	0.007	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	12	20	6	47	0.748	-0.079	4.186	0.01	0.007	0	44.7	40.9	57.2	139	129	0	35	34
2014	9	12	20	16	47	0.778	-0.079	4.186	0.01	0.007	0	44.3	40.4	54.6	138	128	0	35	34
2014	9	12	20	26	47	0.778	-0.098	4.186	0.01	0.007	0	44.3	40.4	57.2	138	128	0	35	34
2014	9	12	20	36	47	0.771	-0.089	4.186	0.01	0.007	0	44.7	40.9	61.1	139	129	0	35	34
2014	9	12	20	46	47	0.751	-0.079	4.186	0.01	0.007	0	44.7	40.9	61.5	139	129	0	35	34
2014	9	12	20	56	47	0.751	-0.079	4.186	0.013	0.01	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	12	21	6	47	0.778	-0.082	4.186	0.01	0.007	0	44.7	40.4	71.4	138	128	0	34	34
2014	9	12	21	16	47	0.745	-0.082	4.186	0.01	0.007	0	44.3	40.9	71.8	138	128	0	35	33
2014	9	12	21	26	47	0.778	-0.095	4.186	0.01	0.007	0	44.3	40.9	71.4	138	128	0	35	33
2014	9	12	21	36	47	0.738	-0.082	4.186	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	12	21	46	47	0.774	-0.095	4.19	0.01	0.007	0	43.9	40.4	71.8	137	127	0	35	33
2014	9	12	21	56	47	0.794	-0.098	4.19	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	12	22	6	47	0.755	-0.105	4.19	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	12	22	16	47	0.768	-0.033	4.19	0.01	0.007	0	43.9	40	71.4	137	127	0	35	34
2014	9	12	22	26	47	0.787	-0.059	4.19	0.01	0.007	0	43.9	40.4	71.4	137	127	0	35	33
2014	9	12	22	36	47	0.768	-0.112	4.19	0.013	0.01	0	43.9	40.4	71	137	127	0	35	33
2014	9	12	22	46	47	0.745	-0.098	4.19	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	12	22	56	47	0.797	-0.079	4.193	0.01	0.007	0	44.3	40.9	70.1	138	128	0	35	33
2014	9	12	23	6	47	0.755	-0.095	4.199	0.01	0.007	0	44.3	40.9	71	138	128	0	35	33
2014	9	12	23	16	47	0.761	-0.079	4.199	0.01	0.007	0	43.9	40.9	71	137	128	0	35	33
2014	9	12	23	26	47	0.764	-0.082	4.199	0.01	0.007	0	43.9	40	71	137	127	0	35	34
2014	9	12	23	36	47	0.755	-0.121	4.203	0.01	0.007	0	43.9	40	71	137	127	0	35	34
2014	9	12	23	46	47	0.751	-0.072	4.203	0.01	0.007	0	43.9	40.4	71	138	128	0	36	34
2014	9	12	23	56	47	0.771	-0.066	4.203	0.01	0.007	0	43.9	40.4	71	137	128	0	35	34
2014	9	13	0	6	47	0.761	-0.062	4.203	0.01	0.007	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	13	0	16	47	0.728	-0.089	4.203	0.01	0.007	0	44.3	40.4	72.2	137	127	0	34	33
2014	9	13	0	26	47	0.758	-0.085	4.203	0.01	0.007	0	43.9	40.9	72.2	137	128	0	35	33
2014	9	13	0	36	47	0.751	-0.075	4.203	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	13	0	46	47	0.748	-0.085	4.206	0.013	0.01	0	43.9	40	71.4	137	127	0	35	34
2014	9	13	0	56	47	0.751	-0.089	4.206	0.01	0.007	0	44.3	40	71.8	138	127	0	35	34
2014	9	13	1	6	47	0.771	-0.062	4.206	0.013	0.01	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	13	1	16	47	0.755	-0.082	4.206	0.013	0.01	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	13	1	26	47	0.781	-0.085	4.206	0.01	0.007	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	13	1	36	47	0.778	-0.095	4.206	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	13	1	46	47	0.758	-0.069	4.206	0.013	0.01	0	43.9	40	73.1	137	127	0	35	34
2014	9	13	1	56	47	0.774	-0.069	4.206	0.013	0.01	0	43.9	40.9	72.2	137	128	0	35	33
2014	9	13	2	6	47	0.778	-0.095	4.206	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	13	2	16	47	0.797	-0.089	4.206	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	13	2	26	47	0.764	-0.082	4.206	0.01	0.007	0	43.9	40.4	73.5	137	127	0	35	33
2014	9	13	2	36	47	0.778	-0.098	4.206	0.01	0.007	0	44.3	40.4	73.5	137	128	0	34	34
2014	9	13	2	46	47	0.758	-0.085	4.206	0.01	0.007	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	13	2	56	47	0.764	-0.085	4.209	0.01	0.007	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	13	3	6	47	0.781	-0.085	4.209	0.01	0.007	0	44.3	40.4	72.7	138	128	0	35	34
2014	9	13	3	16	47	0.751	-0.085	4.209	0.01	0.007	0	43.9	40.4	70.5	137	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	3	26	47	0.732	-0.098	4.209	0.013	0.01	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	13	3	36	47	0.764	-0.095	4.209	0.01	0.007	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	13	3	46	47	0.774	-0.075	4.209	0.01	0.007	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	13	3	56	47	0.778	-0.108	4.209	0.01	0.007	0	43.9	40.4	73.1	137	127	0	35	33
2014	9	13	4	6	47	0.778	-0.095	4.209	0.01	0.007	0	44.3	40	74.4	137	127	0	34	34
2014	9	13	4	16	47	0.761	-0.095	4.209	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	13	4	26	47	0.774	-0.102	4.209	0.01	0.007	0	43.9	40	74	137	127	0	35	34
2014	9	13	4	36	47	0.791	-0.092	4.209	0.013	0.01	0	43.4	40.4	74	136	127	0	35	33
2014	9	13	4	46	47	0.771	-0.079	4.209	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	13	4	56	47	0.768	-0.079	4.209	0.01	0.007	0	43.4	39.6	69.2	136	126	0	35	34
2014	9	13	5	6	47	0.768	-0.085	4.209	0.01	0.007	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	13	5	16	47	0.764	-0.072	4.209	0.01	0.007	0	45.2	41.7	73.5	140	130	0	35	33
2014	9	13	5	26	47	0.758	-0.092	4.213	0.013	0.01	0	43.9	40	74.8	137	127	0	35	34
2014	9	13	5	36	47	0.751	-0.075	4.213	0.01	0.007	0	44.3	40.9	74.4	138	129	0	35	34
2014	9	13	5	46	47	0.771	-0.082	4.213	0.01	0.007	0	44.7	40.9	74	139	129	0	35	34
2014	9	13	5	56	47	0.745	-0.108	4.213	0.01	0.007	0	44.7	41.3	72.7	139	129	0	35	33
2014	9	13	6	6	47	0.761	-0.072	4.213	0.01	0.007	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	13	6	16	47	0.778	-0.089	4.213	0.01	0.007	0	43.9	40	74	137	127	0	35	34
2014	9	13	6	26	47	0.771	-0.089	4.213	0.01	0.007	0	45.6	42.1	73.5	141	132	0	35	34
2014	9	13	6	36	47	0.735	-0.092	4.213	0.013	0.01	0	45.2	41.3	74	140	130	0	35	34
2014	9	13	6	46	47	0.797	-0.092	4.213	0.01	0.007	0	45.2	41.3	74	140	130	0	35	34
2014	9	13	6	56	47	0.778	-0.085	4.213	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	13	7	6	47	0.781	-0.095	4.213	0.013	0.01	0	43	39.6	73.5	135	126	0	35	34
2014	9	13	7	16	47	0.748	-0.079	4.213	0.01	0.007	0	43.9	40.4	74.4	137	127	0	35	33
2014	9	13	7	26	47	0.774	-0.069	4.213	0.01	0.007	0	42.6	39.1	74	135	125	0	36	34
2014	9	13	7	36	47	0.778	-0.075	4.213	0.01	0.007	0	42.1	39.1	74.4	134	125	0	36	34
2014	9	13	7	46	47	0.764	-0.095	4.213	0.01	0.007	0	43	39.1	74.8	134	125	0	34	34
2014	9	13	7	56	47	0.748	-0.079	4.213	0.013	0.01	0	42.6	39.1	74	134	125	0	35	34
2014	9	13	8	6	47	0.774	-0.089	4.213	0.01	0.007	0	42.6	39.1	74.4	134	125	0	35	34
2014	9	13	8	16	47	0.768	-0.079	4.213	0.013	0.01	0	43	39.1	74.4	134	125	0	34	34
2014	9	13	8	26	47	0.764	-0.079	4.213	0.01	0.007	0	43	38.3	74.8	134	124	0	34	35
2014	9	13	8	36	47	0.755	-0.115	4.213	0.013	0.01	0	41.7	38.7	74.4	133	124	0	36	34
2014	9	13	8	46	47	0.755	-0.098	4.213	0.01	0.007	0	42.6	38.7	74.4	134	124	0	35	34
2014	9	13	8	56	47	0.745	-0.095	4.213	0.01	0.007	0	42.6	39.1	74.4	134	124	0	35	33
2014	9	13	9	6	47	0.764	-0.108	4.213	0.01	0.007	0	43	39.1	74	134	124	0	34	33
2014	9	13	9	16	47	0.784	-0.079	4.213	0.01	0.007	0	42.1	39.6	75.3	133	125	0	35	33
2014	9	13	9	26	47	0.774	-0.075	4.213	0.01	0.007	0	42.1	38.7	74.8	133	124	0	35	34
2014	9	13	9	36	47	0.755	-0.098	4.213	0.01	0.007	0	42.6	39.1	75.7	134	125	0	35	34
2014	9	13	9	46	47	0.774	-0.075	4.213	0.01	0.007	0	42.1	39.1	76.1	133	124	0	35	33
2014	9	13	9	56	47	0.781	-0.082	4.213	0.01	0.007	0	42.6	38.7	76.1	134	124	0	35	34
2014	9	13	10	6	47	0.794	-0.098	4.213	0.01	0.007	0	42.6	39.1	75.7	134	125	0	35	34
2014	9	13	10	16	47	0.784	-0.108	4.213	0.013	0.01	0	42.6	39.6	76.1	134	125	0	35	33
2014	9	13	10	26	47	0.748	-0.089	4.213	0.013	0.01	0	42.1	39.1	75.7	134	125	0	36	34
2014	9	13	10	36	47	0.807	-0.141	4.213	0.01	0.007	0	42.1	38.7	76.1	133	124	0	35	34
2014	9	13	10	46	47	0.787	-0.105	4.213	0.01	0.007	0	42.1	38.7	76.1	133	124	0	35	34
2014	9	13	10	56	47	0.761	-0.131	4.209	0.01	0.007	0	41.7	38.3	73.5	132	123	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	11	6	47	0.768	-0.102	4.209	0.01	0.007	0	42.1	39.1	75.3	133	125	0	35	34
2014	9	13	11	16	47	0.751	-0.125	4.209	0.013	0.01	0	41.7	39.1	75.3	132	125	0	35	34
2014	9	13	11	26	47	0.771	-0.089	4.209	0.01	0.007	0	42.1	39.1	74.8	133	125	0	35	34
2014	9	13	11	36	47	0.814	-0.115	4.209	0.01	0.007	0	42.1	39.1	72.7	133	125	0	35	34
2014	9	13	11	46	47	0.755	-0.128	4.209	0.013	0.01	0	42.1	38.7	73.5	133	124	0	35	34
2014	9	13	11	56	47	0.764	-0.151	4.209	0.013	0.01	0	41.7	38.3	65.8	132	124	0	35	35
2014	9	13	12	6	47	0.748	-0.131	4.206	0.01	0.007	0	41.7	39.1	55	132	124	0	35	33
2014	9	13	12	16	47	0.781	-0.105	4.206	0.01	0.007	0	42.1	38.7	58	133	124	0	35	34
2014	9	13	12	26	47	0.778	-0.151	4.206	0.01	0.007	0	41.7	38.7	64.1	132	123	0	35	33
2014	9	13	12	36	47	0.751	-0.144	4.206	0.013	0.01	0	41.7	38.7	60.6	132	124	0	35	34
2014	9	13	12	46	47	0.768	-0.118	4.203	0.01	0.007	0	41.7	39.1	51.6	132	124	0	35	33
2014	9	13	12	56	47	0.751	-0.157	4.203	0.016	0.013	0	42.1	38.3	54.6	132	123	0	34	34
2014	9	13	13	6	47	0.791	-0.125	4.199	0.016	0.013	0	41.7	39.1	58.5	132	125	0	35	34
2014	9	13	13	16	47	0.791	-0.161	4.199	0.013	0.01	0	41.7	39.1	59.8	132	125	0	35	34
2014	9	13	13	26	47	0.741	-0.128	4.203	0.01	0.007	0	41.7	38.7	63.2	133	124	0	36	34
2014	9	13	13	36	47	0.778	-0.138	4.196	0.01	0.007	0	42.1	39.1	57.6	133	125	0	35	34
2014	9	13	13	46	47	0.771	-0.131	4.199	0.01	0.007	0	42.1	39.6	52.9	133	125	0	35	33
2014	9	13	13	56	47	0.764	-0.135	4.199	0.016	0.013	0	41.7	39.1	55.9	132	124	0	35	33
2014	9	13	14	6	47	0.764	-0.131	4.199	0.01	0.007	0	42.6	39.1	51.6	134	125	0	35	34
2014	9	13	14	16	47	0.748	-0.112	4.193	0.01	0.007	0	42.6	39.6	69.2	134	126	0	35	34
2014	9	13	14	26	47	0.774	-0.161	4.193	0.01	0.007	0	41.7	38.7	61.1	132	124	0	35	34
2014	9	13	14	36	47	0.764	-0.121	4.193	0.01	0.007	0	42.1	39.1	65.8	133	125	0	35	34
2014	9	13	14	46	47	0.794	-0.148	4.19	0.01	0.007	0	42.1	39.6	64.5	133	125	0	35	33
2014	9	13	14	56	47	0.784	-0.118	4.193	0.013	0.01	0	42.1	39.1	67.9	133	125	0	35	34
2014	9	13	15	6	47	0.787	-0.128	4.19	0.013	0.01	0	42.1	39.1	56.3	133	125	0	35	34
2014	9	13	15	16	47	0.768	-0.151	4.19	0.01	0.007	0	43	40	51.6	135	127	0	35	34
2014	9	13	15	26	47	0.755	-0.148	4.19	0.01	0.007	0	42.6	39.6	64.1	134	126	0	35	34
2014	9	13	15	36	47	0.748	-0.115	4.19	0.013	0.01	0	43.9	40.9	56.8	137	129	0	35	34
2014	9	13	15	46	47	0.738	-0.089	4.186	0.013	0.01	0	51.2	47.7	40.9	154	145	0	35	34
2014	9	13	15	58	29	0.732	-0.112	4.19	0.016	0.013	0	48.6	43.9	44.3	147	135	0	34	33
2014	9	13	16	8	29	0.804	-0.148	4.193	0.013	0.01	0	43.4	40	60.2	136	127	0	35	34
2014	9	13	16	18	29	0.764	-0.135	4.19	0.01	0.007	0	43	40.4	48.6	135	127	0	35	33
2014	9	13	16	28	29	0.774	-0.135	4.19	0.01	0.007	0	42.6	40	71	134	127	0	35	34
2014	9	13	16	38	29	0.81	-0.115	4.19	0.01	0.007	0	43	40.4	72.7	135	127	0	35	33
2014	9	13	16	48	29	0.781	-0.069	4.19	0.01	0.007	0	43	40	71.8	135	127	0	35	34
2014	9	13	16	58	29	0.797	-0.108	4.19	0.01	0.007	0	43	40	72.7	135	127	0	35	34
2014	9	13	17	8	29	0.748	-0.118	4.19	0.01	0.007	0	43	40	72.2	135	127	0	35	34
2014	9	13	17	18	29	0.755	-0.089	4.19	0.01	0.007	0	43.4	40.4	72.2	136	128	0	35	34
2014	9	13	17	28	29	0.764	-0.102	4.19	0.01	0.007	0	43.4	40	72.7	135	127	0	34	34
2014	9	13	17	38	29	0.755	-0.098	4.193	0.01	0.007	0	42.6	39.6	72.7	134	126	0	35	34
2014	9	13	17	48	29	0.764	-0.102	4.193	0.01	0.007	0	43	39.6	72.2	135	126	0	35	34
2014	9	13	17	58	29	0.745	-0.098	4.19	0.01	0.007	0	43	40	71.8	135	127	0	35	34
2014	9	13	18	8	29	0.745	-0.098	4.19	0.01	0.007	0	43	40	69.2	135	127	0	35	34
2014	9	13	18	18	29	0.761	-0.072	4.193	0.013	0.01	0	43	39.6	69.2	135	127	0	35	35
2014	9	13	18	28	29	0.778	-0.072	4.19	0.013	0.01	0	43	40	64.9	135	127	0	35	34
2014	9	13	18	38	29	0.764	-0.079	4.19	0.01	0.007	0	43	40	70.1	135	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	18	48	29	0.774	-0.085	4.19	0.013	0.01	0	43	40	70.5	135	127	0	35	34
2014	9	13	18	58	29	0.774	-0.069	4.19	0.01	0.007	0	43.4	40.4	71.4	136	128	0	35	34
2014	9	13	19	8	29	0.781	-0.079	4.19	0.01	0.007	0	43.9	40.4	71	137	128	0	35	34
2014	9	13	19	18	29	0.768	-0.075	4.19	0.013	0.01	0	43.4	40.4	71	136	128	0	35	34
2014	9	13	19	28	29	0.761	-0.079	4.19	0.01	0.007	0	43.9	41.3	71.4	137	129	0	35	33
2014	9	13	19	38	29	0.768	-0.085	4.19	0.01	0.007	0	45.2	42.6	69.7	140	133	0	35	34
2014	9	13	19	48	29	0.768	-0.102	4.19	0.01	0.007	0	43.9	41.3	69.2	138	130	0	36	34
2014	9	13	19	58	29	0.751	-0.079	4.19	0.01	0.007	0	45.2	41.3	71	139	130	0	34	34
2014	9	13	20	8	29	0.794	-0.092	4.19	0.01	0.007	0	44.7	41.3	71.4	139	130	0	35	34
2014	9	13	20	18	29	0.741	-0.092	4.193	0.01	0.007	0	45.2	41.7	71	140	131	0	35	34
2014	9	13	20	28	29	0.758	-0.052	4.193	0.01	0.007	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	13	20	38	29	0.768	-0.095	4.193	0.01	0.007	0	44.7	41.7	71	139	131	0	35	34
2014	9	13	20	48	29	0.791	-0.085	4.193	0.01	0.007	0	44.3	40.9	68.8	138	129	0	35	34
2014	9	13	20	58	29	0.771	-0.066	4.196	0.01	0.007	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	13	21	8	29	0.751	-0.072	4.193	0.016	0.013	0	44.7	41.3	70.5	139	130	0	35	34
2014	9	13	21	18	29	0.771	-0.089	4.196	0.01	0.007	0	44.3	41.3	70.1	138	129	0	35	33
2014	9	13	21	28	29	0.751	-0.066	4.196	0.01	0.007	0	44.3	41.3	71.4	138	130	0	35	34
2014	9	13	21	38	29	0.768	-0.075	4.199	0.01	0.007	0	43.9	40.9	70.1	137	129	0	35	34
2014	9	13	21	48	29	0.758	-0.079	4.199	0.013	0.01	0	44.3	41.3	71	138	129	0	35	33
2014	9	13	21	58	29	0.758	-0.079	4.199	0.01	0.007	0	44.3	41.3	71.4	138	129	0	35	33
2014	9	13	22	8	29	0.771	-0.115	4.199	0.01	0.007	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	13	22	18	29	0.768	-0.085	4.203	0.016	0.013	0	43.9	41.3	71	137	129	0	35	33
2014	9	13	22	28	29	0.755	-0.098	4.199	0.01	0.007	0	43.9	40.4	66.7	137	128	0	35	34
2014	9	13	22	38	29	0.755	-0.095	4.203	0.016	0.013	0	44.3	41.3	71.4	138	129	0	35	33
2014	9	13	22	48	29	0.758	-0.075	4.206	0.01	0.007	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	13	22	58	29	0.751	-0.089	4.203	0.01	0.007	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	13	23	8	29	0.784	-0.069	4.203	0.01	0.007	0	44.7	40.9	71	138	129	0	34	34
2014	9	13	23	18	29	0.781	-0.085	4.203	0.013	0.01	0	44.7	41.3	71.4	138	129	0	34	33
2014	9	13	23	28	29	0.774	-0.085	4.206	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	13	23	38	29	0.768	-0.056	4.206	0.013	0.01	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	13	23	48	29	0.735	-0.089	4.206	0.01	0.007	0	44.3	40.4	72.2	137	128	0	34	34
2014	9	13	23	58	29	0.761	-0.098	4.206	0.013	0.01	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	14	0	8	29	0.735	-0.072	4.206	0.01	0.007	0	43.9	40.4	72.7	136	128	0	34	34
2014	9	14	0	18	29	0.751	-0.069	4.206	0.013	0.01	0	43.9	40.9	72.7	137	128	0	35	33
2014	9	14	0	28	29	0.768	-0.075	4.206	0.01	0.007	0	43.9	41.3	72.7	137	129	0	35	33
2014	9	14	0	38	29	0.784	-0.102	4.206	0.01	0.007	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	14	0	48	29	0.768	-0.089	4.206	0.01	0.007	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	14	0	58	29	0.751	-0.079	4.206	0.013	0.01	0	44.3	40.9	72.7	137	129	0	34	34
2014	9	14	1	8	29	0.755	-0.079	4.206	0.01	0.007	0	43.9	40.4	72.7	137	128	0	35	34
2014	9	14	1	18	29	0.741	-0.085	4.206	0.01	0.007	0	43.9	41.3	72.7	137	130	0	35	34
2014	9	14	1	28	29	0.778	-0.062	4.206	0.01	0.007	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	14	1	38	29	0.758	-0.102	4.206	0.013	0.01	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	14	1	48	29	0.771	-0.095	4.206	0.01	0.007	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	14	1	58	29	0.748	-0.095	4.209	0.01	0.007	0	43.9	40.9	73.1	136	128	0	34	33
2014	9	14	2	8	29	0.745	-0.072	4.209	0.01	0.007	0	44.3	40.9	73.1	137	128	0	34	33
2014	9	14	2	18	29	0.784	-0.085	4.209	0.01	0.007	0	43.9	40.9	74	137	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	2	28	29	0.761	-0.066	4.209	0.013	0.01	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	14	2	38	29	0.738	-0.066	4.209	0.01	0.007	0	43.9	40.4	74	137	128	0	35	34
2014	9	14	2	48	29	0.758	-0.075	4.209	0.01	0.007	0	44.3	41.3	74	138	130	0	35	34
2014	9	14	2	58	29	0.755	-0.105	4.209	0.01	0.007	0	43.9	40.9	73.5	138	129	0	36	34
2014	9	14	3	8	29	0.774	-0.092	4.209	0.01	0.007	0	43.9	40.9	73.5	137	129	0	35	34
2014	9	14	3	18	29	0.801	-0.062	4.209	0.013	0.01	0	43.4	40.4	74	136	127	0	35	33
2014	9	14	3	28	29	0.768	-0.108	4.209	0.01	0.007	0	44.3	40.9	74	137	129	0	34	34
2014	9	14	3	38	29	0.758	-0.112	4.209	0.01	0.007	0	44.3	40.9	73.5	138	129	0	35	34
2014	9	14	3	48	29	0.761	-0.098	4.209	0.01	0.007	0	43.9	40.9	74.4	138	129	0	36	34
2014	9	14	3	58	29	0.751	-0.046	4.209	0.01	0.007	0	44.3	41.3	74.4	138	130	0	35	34
2014	9	14	4	8	29	0.751	-0.085	4.209	0.01	0.007	0	44.7	41.7	74.4	138	130	0	34	33
2014	9	14	4	18	29	0.784	-0.085	4.209	0.01	0.007	0	44.3	40.9	74	138	129	0	35	34
2014	9	14	4	28	29	0.745	-0.062	4.209	0.016	0.013	0	44.3	41.3	74.4	138	130	0	35	34
2014	9	14	4	38	29	0.738	-0.082	4.209	0.016	0.013	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	14	4	48	29	0.771	-0.098	4.209	0.01	0.007	0	44.7	40.9	63.2	138	129	0	34	34
2014	9	14	4	58	29	0.764	-0.098	4.213	0.01	0.007	0	44.7	41.7	74.4	139	131	0	35	34
2014	9	14	5	8	29	0.787	-0.092	4.213	0.01	0.007	0	46.4	43.9	74.4	143	135	0	35	33
2014	9	14	5	18	29	0.774	-0.092	4.213	0.013	0.01	0	45.6	41.7	75.7	141	131	0	35	34
2014	9	14	5	28	29	0.764	-0.079	4.213	0.01	0.007	0	45.2	41.3	75.3	140	130	0	35	34
2014	9	14	5	38	29	0.748	-0.092	4.216	0.01	0.007	0	44.3	40.9	76.5	139	129	0	36	34
2014	9	14	5	48	29	0.781	-0.079	4.216	0.01	0.007	0	44.7	40.4	75.3	139	128	0	35	34
2014	9	14	5	58	29	0.781	-0.075	4.213	0.01	0.007	0	44.7	41.3	71	140	130	0	36	34
2014	9	14	6	8	29	0.761	-0.089	4.216	0.01	0.007	0	44.3	40	76.5	138	127	0	35	34
2014	9	14	6	18	29	0.768	-0.075	4.216	0.01	0.007	0	46	41.3	76.1	142	131	0	35	35
2014	9	14	6	28	29	0.764	-0.079	4.216	0.01	0.007	0	46.4	42.6	75.7	143	133	0	35	34
2014	9	14	6	38	29	0.755	-0.105	4.216	0.01	0.007	0	46	41.7	75.3	142	131	0	35	34
2014	9	14	6	48	29	0.764	-0.069	4.216	0.01	0.007	0	45.6	41.3	75.3	141	130	0	35	34
2014	9	14	6	58	29	0.764	-0.082	4.216	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	14	7	8	29	0.781	-0.066	4.216	0.01	0.007	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	14	7	18	29	0.768	-0.062	4.216	0.013	0.01	0	43.9	40	75.7	137	127	0	35	34
2014	9	14	7	28	29	0.732	-0.102	4.216	0.01	0.007	0	43.9	40	75.7	137	127	0	35	34
2014	9	14	7	38	29	0.781	-0.105	4.216	0.016	0.013	0	43.4	40	74.8	137	127	0	36	34
2014	9	14	7	48	29	0.758	-0.079	4.213	0.01	0.007	0	44.3	40	75.7	137	127	0	34	34
2014	9	14	7	58	29	0.764	-0.095	4.216	0.01	0.007	0	43.9	39.6	76.1	137	127	0	35	35
2014	9	14	8	8	29	0.768	-0.102	4.216	0.01	0.007	0	44.3	39.6	75.7	137	126	0	34	34
2014	9	14	8	18	29	0.751	-0.095	4.216	0.01	0.007	0	43.9	40	76.1	137	127	0	35	34
2014	9	14	8	28	29	0.761	-0.072	4.216	0.01	0.007	0	43.9	40	76.1	137	127	0	35	34
2014	9	14	8	38	29	0.768	-0.075	4.216	0.013	0.01	0	43.4	39.6	75.7	136	126	0	35	34
2014	9	14	8	48	29	0.741	-0.085	4.216	0.013	0.01	0	43.9	40	76.1	137	127	0	35	34
2014	9	14	8	58	29	0.738	-0.098	4.216	0.01	0.007	0	43.4	40	75.7	136	127	0	35	34
2014	9	14	9	8	29	0.748	-0.082	4.216	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34
2014	9	14	9	18	29	0.771	-0.089	4.216	0.016	0.016	0	43.9	40	76.1	137	127	0	35	34
2014	9	14	9	28	29	0.748	-0.049	4.213	0.013	0.01	0	43.9	40	75.7	137	127	0	35	34
2014	9	14	9	38	29	0.771	-0.095	4.213	0.01	0.007	0	43.9	39.6	73.1	137	127	0	35	35
2014	9	14	9	48	29	0.768	-0.092	4.216	0.01	0.007	0	44.3	40	75.7	138	127	0	35	34
2014	9	14	9	58	29	0.774	-0.092	4.216	0.01	0.007	0	43	39.6	75.7	136	126	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	10	8	29	0.768	-0.125	4.213	0.013	0.01	0	43.9	40	76.1	137	127	0	35	34
2014	9	14	10	18	29	0.748	-0.079	4.213	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	14	10	28	29	0.764	-0.102	4.213	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	14	10	38	29	0.791	-0.118	4.213	0.013	0.01	0	43	39.1	69.7	135	125	0	35	34
2014	9	14	10	48	29	0.781	-0.112	4.213	0.016	0.013	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	14	10	58	29	0.761	-0.131	4.213	0.01	0.007	0	43	39.1	74.8	135	125	0	35	34
2014	9	14	11	8	29	0.764	-0.157	4.213	0.01	0.007	0	43	38.7	71.4	135	124	0	35	34
2014	9	14	11	18	29	0.755	-0.089	4.209	0.013	0.01	0	43.4	39.6	67.9	136	126	0	35	34
2014	9	14	11	28	29	0.781	-0.102	4.209	0.01	0.007	0	43.4	40	72.7	136	127	0	35	34
2014	9	14	11	38	29	0.774	-0.112	4.209	0.01	0.007	0	43.4	39.6	65.4	135	126	0	34	34
2014	9	14	11	48	29	0.755	-0.148	4.209	0.01	0.007	0	43	40	62.4	135	126	0	35	33
2014	9	14	11	58	29	0.768	-0.161	4.209	0.01	0.007	0	42.6	39.1	63.6	134	124	0	35	33
2014	9	14	12	8	29	0.764	-0.171	4.209	0.01	0.007	0	42.6	39.1	72.2	134	124	0	35	33
2014	9	14	12	18	29	0.804	-0.125	4.206	0.01	0.007	0	42.1	39.1	57.6	134	125	0	36	34
2014	9	14	12	28	29	0.771	-0.171	4.203	0.01	0.007	0	42.6	39.1	51.2	134	125	0	35	34
2014	9	14	12	38	29	0.768	-0.092	4.203	0.01	0.007	0	43.9	40.4	56.8	136	127	0	34	33
2014	9	14	12	48	29	0.771	-0.141	4.206	0.013	0.01	0	43.4	40.4	66.2	136	127	0	35	33
2014	9	14	12	58	29	0.771	-0.098	4.203	0.01	0.007	0	43.9	40.4	61.5	137	128	0	35	34
2014	9	14	13	8	29	0.787	-0.098	4.199	0.01	0.007	0	44.7	40.4	50.7	138	128	0	34	34
2014	9	14	13	18	29	0.797	-0.118	4.203	0.013	0.01	0	44.3	40.4	53.3	138	128	0	35	34
2014	9	14	13	28	29	0.771	-0.105	4.203	0.016	0.013	0	44.3	40.9	63.2	138	129	0	35	34
2014	9	14	13	38	29	0.774	-0.079	4.199	0.013	0.01	0	44.3	40.4	67.5	138	128	0	35	34
2014	9	14	13	48	29	0.771	-0.095	4.196	0.013	0.01	0	44.3	40.9	63.6	138	128	0	35	33
2014	9	14	13	58	29	0.801	-0.118	4.199	0.01	0.007	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	14	14	8	29	0.755	-0.089	4.199	0.01	0.007	0	44.3	41.3	71	138	129	0	35	33
2014	9	14	14	18	29	0.784	-0.138	4.196	0.01	0.007	0	43.4	40.4	71.8	136	127	0	35	33
2014	9	14	14	28	29	0.755	-0.082	4.196	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	14	14	38	29	0.768	-0.095	4.196	0.01	0.007	0	44.7	40.9	71	138	129	0	34	34
2014	9	14	14	48	29	0.774	-0.135	4.193	0.01	0.007	0	44.7	40.4	72.2	138	128	0	34	34
2014	9	14	14	58	29	0.768	-0.079	4.193	0.013	0.01	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	14	15	8	29	0.751	-0.118	4.193	0.01	0.007	0	43.4	40	71.4	136	127	0	35	34
2014	9	14	15	18	29	0.755	-0.148	4.193	0.01	0.007	0	43.4	40	58.5	136	126	0	35	33
2014	9	14	15	28	29	0.758	-0.108	4.193	0.01	0.007	0	44.7	40.4	60.6	138	128	0	34	34
2014	9	14	15	38	29	0.768	-0.135	4.193	0.013	0.01	0	44.3	40	71.8	137	127	0	34	34
2014	9	14	15	48	29	0.768	-0.151	4.193	0.013	0.01	0	43.4	40	71.8	136	127	0	35	34
2014	9	14	15	58	29	0.735	-0.131	4.193	0.01	0.007	0	44.7	40	73.1	138	128	0	34	35
2014	9	14	16	8	29	0.761	-0.141	4.19	0.01	0.007	0	43.9	40	55.5	137	127	0	35	34
2014	9	14	16	18	29	0.758	-0.144	4.193	0.01	0.007	0	43.9	40.4	62.4	137	127	0	35	33
2014	9	14	16	28	29	0.764	-0.108	4.19	0.01	0.007	0	43.9	40	66.2	137	127	0	35	34
2014	9	14	16	38	29	0.764	-0.092	4.19	0.013	0.01	0	44.3	40	68.4	137	127	0	34	34
2014	9	14	16	48	29	0.781	-0.115	4.193	0.013	0.01	0	43.9	40	73.1	137	127	0	35	34
2014	9	14	16	58	29	0.764	-0.108	4.19	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	14	17	8	29	0.764	-0.095	4.193	0.01	0.007	0	44.3	40.4	71	138	128	0	35	34
2014	9	14	17	18	29	0.728	-0.079	4.193	0.01	0.007	0	43.9	40.4	71.8	138	128	0	36	34
2014	9	14	17	28	29	0.764	-0.102	4.193	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2014	9	14	17	38	29	0.748	-0.069	4.193	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	17	48	29	0.748	-0.079	4.196	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	14	17	58	29	0.751	-0.082	4.196	0.013	0.01	0	44.3	40.4	71.4	138	128	0	35	34
2014	9	14	18	8	29	0.758	-0.059	4.193	0.01	0.007	0	44.3	40.4	68.4	138	128	0	35	34
2014	9	14	18	18	29	0.781	-0.069	4.196	0.01	0.007	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	14	18	28	29	0.781	-0.069	4.196	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	14	18	38	29	0.751	-0.069	4.196	0.016	0.013	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	14	18	48	29	0.768	-0.098	4.196	0.01	0.007	0	44.7	41.3	71.8	139	129	0	35	33
2014	9	14	18	58	29	0.748	-0.092	4.196	0.01	0.007	0	44.3	40.4	70.1	138	128	0	35	34
2014	9	14	19	8	29	0.735	-0.089	4.196	0.016	0.013	0	44.7	40.9	71	139	129	0	35	34
2014	9	14	19	18	29	0.764	-0.079	4.196	0.01	0.007	0	44.7	41.7	71.4	139	130	0	35	33
2014	9	14	19	28	29	0.741	-0.102	4.196	0.01	0.007	0	46.9	42.6	70.5	143	133	0	34	34
2014	9	14	19	38	29	0.758	-0.102	4.199	0.01	0.007	0	45.2	41.3	71.4	140	130	0	35	34
2014	9	14	19	48	29	0.751	-0.079	4.199	0.01	0.007	0	45.6	41.3	71	140	130	0	34	34
2014	9	14	19	58	29	0.751	-0.066	4.203	0.01	0.007	0	45.6	41.7	70.5	141	131	0	35	34
2014	9	14	20	8	29	0.768	-0.039	4.203	0.01	0.007	0	45.2	41.3	71.4	140	130	0	35	34
2014	9	14	20	18	29	0.748	-0.102	4.206	0.013	0.01	0	44.7	41.3	71	139	130	0	35	34
2014	9	14	20	28	29	0.781	-0.079	4.206	0.01	0.007	0	44.7	41.7	71.8	139	130	0	35	33
2014	9	14	20	38	29	0.751	-0.072	4.206	0.01	0.007	0	45.2	41.7	71	140	131	0	35	34
2014	9	14	20	48	29	0.774	-0.043	4.206	0.01	0.007	0	44.7	40.9	72.2	139	129	0	35	34
2014	9	14	20	58	29	0.748	-0.085	4.206	0.01	0.007	0	44.7	41.3	71.8	139	130	0	35	34
2014	9	14	21	8	29	0.751	-0.089	4.206	0.01	0.007	0	44.7	41.3	71.8	139	129	0	35	33
2014	9	14	21	18	29	0.784	-0.062	4.206	0.01	0.007	0	44.7	40.9	72.7	139	129	0	35	34
2014	9	14	21	28	29	0.768	-0.105	4.209	0.013	0.01	0	44.7	41.3	73.1	139	130	0	35	34
2014	9	14	21	38	29	0.764	-0.092	4.209	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	14	21	48	29	0.771	-0.062	4.209	0.01	0.007	0	44.7	40.9	72.7	138	129	0	34	34
2014	9	14	21	58	29	0.764	-0.075	4.209	0.01	0.007	0	43.9	40	74	137	128	0	35	35
2014	9	14	22	8	29	0.768	-0.056	4.209	0.01	0.007	0	44.3	41.3	72.7	138	129	0	35	33
2014	9	14	22	18	29	0.758	-0.075	4.209	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	14	22	28	29	0.751	-0.095	4.213	0.01	0.007	0	44.7	40.9	74	139	129	0	35	34
2014	9	14	22	38	29	0.755	-0.056	4.213	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	14	22	48	29	0.768	-0.089	4.213	0.01	0.007	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	14	22	58	29	0.761	-0.095	4.213	0.013	0.01	0	44.3	40.9	73.5	138	129	0	35	34
2014	9	14	23	8	29	0.755	-0.066	4.213	0.01	0.007	0	45.2	41.3	70.1	139	130	0	34	34
2014	9	14	23	18	29	0.761	-0.098	4.213	0.01	0.007	0	44.3	41.3	74.8	139	129	0	36	33
2014	9	14	23	28	29	0.738	-0.089	4.213	0.01	0.007	0	44.7	41.3	75.7	139	129	0	35	33
2014	9	14	23	38	29	0.764	-0.085	4.213	0.013	0.01	0	44.7	41.7	70.5	139	130	0	35	33
2014	9	14	23	48	29	0.768	-0.095	4.213	0.01	0.007	0	43.9	40.4	75.7	138	128	0	36	34
2014	9	14	23	58	29	0.781	-0.075	4.213	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	15	0	8	29	0.761	-0.079	4.216	0.01	0.007	0	44.3	40.4	76.1	137	128	0	34	34
2014	9	15	0	18	29	0.784	-0.082	4.216	0.01	0.007	0	44.3	40.9	76.5	138	128	0	35	33
2014	9	15	0	28	29	0.771	-0.089	4.216	0.013	0.01	0	44.3	40.9	76.1	138	129	0	35	34
2014	9	15	0	38	29	0.784	-0.066	4.216	0.01	0.007	0	43.9	40.4	76.1	137	128	0	35	34
2014	9	15	0	48	29	0.735	-0.112	4.216	0.01	0.007	0	44.3	40.9	76.1	138	128	0	35	33
2014	9	15	0	58	29	0.751	-0.079	4.216	0.01	0.007	0	45.2	40.9	76.5	139	129	0	34	34
2014	9	15	1	8	29	0.778	-0.079	4.216	0.01	0.007	0	44.7	41.3	75.7	139	129	0	35	33
2014	9	15	1	18	29	0.768	-0.098	4.216	0.01	0.007	0	44.7	40.4	77	139	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	1	28	29	0.735	-0.062	4.216	0.01	0.007	0	45.2	40.9	77	139	129	0	34	34
2014	9	15	1	38	29	0.784	-0.098	4.216	0.01	0.007	0	44.3	40.9	77	138	128	0	35	33
2014	9	15	1	48	29	0.758	-0.059	4.216	0.01	0.007	0	44.7	40.4	77	138	128	0	34	34
2014	9	15	1	58	29	0.755	-0.085	4.216	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	15	2	8	29	0.764	-0.079	4.216	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	15	2	18	29	0.761	-0.105	4.216	0.013	0.01	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	15	2	28	29	0.755	-0.066	4.216	0.013	0.01	0	44.7	41.3	76.1	139	129	0	35	33
2014	9	15	2	38	29	0.794	-0.092	4.216	0.01	0.007	0	44.7	40.4	76.5	138	128	0	34	34
2014	9	15	2	48	29	0.764	-0.062	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	15	2	58	29	0.784	-0.085	4.216	0.013	0.01	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	15	3	8	29	0.751	-0.095	4.216	0.01	0.007	0	44.3	40.4	76.5	138	128	0	35	34
2014	9	15	3	18	29	0.751	-0.082	4.216	0.016	0.016	0	44.3	40.9	76.5	138	128	0	35	33
2014	9	15	3	28	29	0.758	-0.092	4.216	0.01	0.007	0	44.3	40.4	76.1	138	128	0	35	34
2014	9	15	3	38	29	0.774	-0.075	4.216	0.013	0.01	0	44.3	40.4	76.5	138	128	0	35	34
2014	9	15	3	48	29	0.751	-0.075	4.216	0.01	0.007	0	45.2	41.7	71.4	140	130	0	35	33
2014	9	15	3	58	29	0.751	-0.108	4.216	0.01	0.007	0	45.6	41.7	76.1	140	130	0	34	33
2014	9	15	4	8	29	0.751	-0.115	4.216	0.016	0.013	0	44.7	40.9	76.5	139	129	0	35	34
2014	9	15	4	18	29	0.771	-0.075	4.219	0.01	0.007	0	44.7	40.9	77	139	129	0	35	34
2014	9	15	4	28	29	0.768	-0.062	4.219	0.01	0.007	0	45.2	40.9	76.1	139	129	0	34	34
2014	9	15	4	38	29	0.748	-0.095	4.216	0.01	0.007	0	44.7	40.9	76.1	139	129	0	35	34
2014	9	15	4	48	55	0.781	-0.079	4.219	0.01	0.007	0	44.7	40.4	77	139	128	0	35	34
2014	9	15	4	58	55	0.787	-0.072	4.219	0.01	0.007	0	44.3	40.9	77	138	129	0	35	34
2014	9	15	5	8	55	0.778	-0.066	4.219	0.01	0.007	0	44.7	41.3	76.5	139	129	0	35	33
2014	9	15	5	18	55	0.735	-0.079	4.219	0.01	0.007	0	44.7	41.3	77	139	129	0	35	33
2014	9	15	5	28	55	0.741	-0.092	4.219	0.01	0.007	0	44.3	40.9	76.1	138	128	0	35	33
2014	9	15	5	38	55	0.787	-0.079	4.219	0.01	0.007	0	47.7	43.9	71.4	146	136	0	35	34
2014	9	15	5	48	55	0.784	-0.085	4.219	0.013	0.01	0	45.6	41.7	75.3	141	131	0	35	34
2014	9	15	5	58	55	0.797	-0.095	4.219	0.01	0.007	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	15	6	8	55	0.787	-0.089	4.219	0.013	0.01	0	45.6	41.3	75.3	140	130	0	34	34
2014	9	15	6	18	55	0.771	-0.082	4.219	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	15	6	28	55	0.778	-0.089	4.219	0.01	0.007	0	45.2	41.3	75.3	140	130	0	35	34
2014	9	15	6	38	55	0.801	-0.052	4.219	0.016	0.013	0	46.4	43	74.8	143	134	0	35	34
2014	9	15	6	48	55	0.784	-0.102	4.219	0.01	0.007	0	45.6	42.6	74	141	132	0	35	33
2014	9	15	6	58	55	0.774	-0.062	4.219	0.01	0.007	0	45.6	42.6	73.5	142	132	0	36	33
2014	9	15	7	8	55	0.771	-0.066	4.219	0.016	0.013	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	15	7	18	55	0.781	-0.079	4.219	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	15	7	28	55	0.764	-0.079	4.219	0.01	0.007	0	43.9	40.4	74.8	137	128	0	35	34
2014	9	15	7	38	55	0.751	-0.092	4.219	0.013	0.01	0	43.9	40	74.4	137	127	0	35	34
2014	9	15	7	48	55	0.774	-0.062	4.219	0.01	0.007	0	43.9	40	75.3	137	127	0	35	34
2014	9	15	7	58	55	0.764	-0.082	4.219	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	15	8	8	55	0.764	-0.095	4.219	0.01	0.007	0	43.4	40	70.1	136	127	0	35	34
2014	9	15	8	18	55	0.791	-0.095	4.219	0.013	0.01	0	43.9	39.6	75.3	137	127	0	35	35
2014	9	15	8	28	55	0.768	-0.085	4.219	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	15	8	38	55	0.764	-0.112	4.219	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	15	8	48	55	0.764	-0.095	4.219	0.01	0.007	0	43.4	40.4	74.8	136	127	0	35	33
2014	9	15	8	58	55	0.771	-0.082	4.219	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	9	8	55	0.774	-0.118	4.219	0.016	0.016	0	43	39.6	75.7	135	126	0	35	34
2014	9	15	9	18	55	0.781	-0.105	4.219	0.01	0.007	0	43	39.6	76.1	135	126	0	35	34
2014	9	15	9	28	55	0.787	-0.098	4.219	0.016	0.013	0	43.4	40	75.7	136	126	0	35	33
2014	9	15	9	38	55	0.764	-0.085	4.219	0.016	0.013	0	43.9	39.6	76.1	136	126	0	34	34
2014	9	15	9	48	55	0.755	-0.082	4.219	0.01	0.007	0	43.9	40	76.5	136	127	0	34	34
2014	9	15	9	58	55	0.771	-0.098	4.219	0.01	0.007	0	43.9	40	75.7	136	127	0	34	34
2014	9	15	10	8	55	0.778	-0.066	4.219	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34
2014	9	15	10	18	55	0.784	-0.082	4.219	0.01	0.007	0	43.4	39.6	76.1	136	126	0	35	34
2014	9	15	10	28	55	0.787	-0.131	4.219	0.01	0.007	0	43	39.6	76.1	135	126	0	35	34
2014	9	15	10	38	55	0.764	-0.085	4.219	0.01	0.007	0	43.4	40	76.1	136	126	0	35	33
2014	9	15	10	48	55	0.768	-0.072	4.219	0.013	0.01	0	43.4	40	76.5	136	127	0	35	34
2014	9	15	10	58	55	0.771	-0.141	4.219	0.01	0.007	0	43.4	39.6	76.1	136	126	0	35	34
2014	9	15	11	8	55	0.764	-0.135	4.219	0.01	0.007	0	43.4	39.6	76.5	135	126	0	34	34
2014	9	15	11	18	55	0.774	-0.118	4.219	0.013	0.01	0	43	40	76.1	135	126	0	35	33
2014	9	15	11	28	55	0.774	-0.141	4.219	0.01	0.007	0	42.6	39.6	73.1	134	125	0	35	33
2014	9	15	11	38	55	0.758	-0.118	4.216	0.013	0.01	0	43	39.6	65.8	135	126	0	35	34
2014	9	15	11	48	55	0.755	-0.131	4.216	0.01	0.007	0	42.6	39.1	70.5	134	125	0	35	34
2014	9	15	11	58	55	0.784	-0.135	4.216	0.01	0.007	0	43	39.6	73.1	135	126	0	35	34
2014	9	15	12	11	2	0.804	-0.092	4.216	0.01	0.007	0	43.4	39.6	54.6	136	126	0	35	34
2014	9	15	12	21	2	0.771	-0.112	4.216	0.013	0.01	0	42.1	39.6	73.1	134	126	0	36	34
2014	9	15	12	31	2	0.771	-0.118	4.216	0.013	0.01	0	43	39.6	64.1	135	126	0	35	34
2014	9	15	12	41	2	0.768	-0.105	4.216	0.01	0.007	0	42.6	40	70.1	135	126	0	36	33
2014	9	15	12	51	2	0.761	-0.171	4.216	0.01	0.007	0	42.6	39.6	71.8	134	125	0	35	33
2014	9	15	13	1	2	0.771	-0.118	4.216	0.013	0.01	0	43	39.6	69.2	135	126	0	35	34
2014	9	15	13	11	2	0.758	-0.174	4.213	0.01	0.007	0	43	39.6	61.1	135	126	0	35	34
2014	9	15	13	21	2	0.755	-0.161	4.213	0.016	0.013	0	43	40	61.1	135	126	0	35	33
2014	9	15	13	31	2	0.787	-0.138	4.213	0.01	0.007	0	43.4	39.6	56.3	135	126	0	34	34
2014	9	15	13	41	2	0.791	-0.102	4.209	0.016	0.013	0	43.4	40	52.5	136	127	0	35	34
2014	9	15	13	51	2	0.784	-0.171	4.209	0.013	0.01	0	43	39.6	58.9	135	126	0	35	34
2014	9	15	14	1	2	0.768	-0.171	4.206	0.01	0.007	0	43.4	39.6	52	136	126	0	35	34
2014	9	15	14	11	2	0.761	-0.098	4.209	0.01	0.007	0	43.4	39.6	51.2	136	127	0	35	35
2014	9	15	14	21	2	0.738	-0.161	4.206	0.01	0.007	0	43.4	40	50.3	136	127	0	35	34
2014	9	15	14	31	2	0.768	-0.174	4.206	0.01	0.007	0	43.4	40.4	49.9	136	127	0	35	33
2014	9	15	14	41	2	0.764	-0.125	4.206	0.016	0.013	0	43.9	40.9	51.2	137	128	0	35	33
2014	9	15	14	51	2	0.784	-0.095	4.206	0.016	0.013	0	43.9	40.9	52.9	137	127	0	35	32
2014	9	15	15	1	2	0.797	-0.174	4.203	0.01	0.007	0	41.7	40.9	55.9	132	128	0	35	33
2014	9	15	15	11	2	0.758	-0.144	4.203	0.01	0.007	0	43	40.4	56.8	135	128	0	35	34
2014	9	15	15	21	2	0.794	-0.148	4.203	0.013	0.01	0	43.4	40.9	60.2	136	128	0	35	33
2014	9	15	15	31	2	0.774	-0.135	4.203	0.01	0.007	0	43.4	40.9	59.8	136	128	0	35	33
2014	9	15	15	41	2	0.758	-0.135	4.203	0.01	0.007	0	43.9	40.9	57.6	136	129	0	34	34
2014	9	15	15	51	2	0.758	-0.141	4.203	0.013	0.01	0	43.9	40.9	54.6	137	129	0	35	34
2014	9	15	16	1	2	0.784	-0.154	4.203	0.01	0.007	0	43.4	40.9	65.8	136	129	0	35	34
2014	9	15	16	11	2	0.761	-0.161	4.203	0.01	0.007	0	44.7	40.9	51.2	139	129	0	35	34
2014	9	15	16	21	2	0.735	-0.161	4.203	0.01	0.007	0	44.7	40.9	53.8	139	129	0	35	34
2014	9	15	16	31	2	0.768	-0.138	4.199	0.01	0.007	0	43.9	40.4	58	137	128	0	35	34
2014	9	15	16	41	2	0.787	-0.128	4.199	0.016	0.013	0	43.9	40	61.5	137	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	16	51	2	0.774	-0.144	4.199	0.01	0.007	0	44.3	41.3	55.9	138	129	0	35	33
2014	9	15	17	1	2	0.778	-0.154	4.199	0.01	0.007	0	44.3	40.4	52.9	138	128	0	35	34
2014	9	15	17	11	2	0.784	-0.112	4.203	0.01	0.007	0	43.9	40.4	54.2	137	128	0	35	34
2014	9	15	17	21	2	0.758	-0.108	4.203	0.01	0.007	0	44.3	40	51.6	137	127	0	34	34
2014	9	15	17	31	2	0.784	-0.121	4.203	0.013	0.01	0	44.3	40.4	52.5	137	128	0	34	34
2014	9	15	17	41	2	0.784	-0.082	4.199	0.01	0.007	0	43.9	40.4	53.8	137	127	0	35	33
2014	9	15	17	51	2	0.764	-0.128	4.199	0.01	0.007	0	43.9	40.4	56.3	137	127	0	35	33
2014	9	15	18	1	2	0.751	-0.108	4.199	0.01	0.007	0	43.9	40.4	61.5	137	128	0	35	34
2014	9	15	18	11	2	0.784	-0.095	4.199	0.01	0.007	0	43.9	40.4	64.1	137	128	0	35	34
2014	9	15	18	21	2	0.784	-0.102	4.203	0.01	0.007	0	43.9	40	67.1	137	127	0	35	34
2014	9	15	18	31	2	0.728	-0.072	4.203	0.01	0.007	0	43.9	40	71.4	137	127	0	35	34
2014	9	15	18	41	2	0.758	-0.095	4.206	0.013	0.01	0	43.9	40	71.4	137	127	0	35	34
2014	9	15	18	51	2	0.771	-0.105	4.206	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	15	19	1	2	0.755	-0.095	4.206	0.01	0.007	0	44.3	41.3	71.4	138	129	0	35	33
2014	9	15	19	11	2	0.797	-0.085	4.206	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	15	19	21	2	0.771	-0.095	4.206	0.01	0.007	0	44.7	41.3	71	139	130	0	35	34
2014	9	15	19	31	2	0.764	-0.085	4.206	0.013	0.01	0	45.6	41.7	70.5	140	130	0	34	33
2014	9	15	19	41	2	0.764	-0.082	4.206	0.01	0.007	0	44.7	42.1	71	140	131	0	36	33
2014	9	15	19	51	2	0.771	-0.098	4.206	0.013	0.01	0	45.6	42.1	71	141	131	0	35	33
2014	9	15	20	1	2	0.745	-0.082	4.209	0.01	0.007	0	45.6	42.6	71	141	132	0	35	33
2014	9	15	20	11	2	0.764	-0.092	4.209	0.01	0.007	0	44.7	41.7	71	140	130	0	36	33
2014	9	15	20	21	2	0.751	-0.072	4.209	0.01	0.007	0	44.7	41.3	71.4	139	129	0	35	33
2014	9	15	20	31	2	0.771	-0.089	4.209	0.01	0.007	0	45.2	41.3	71.4	140	130	0	35	34
2014	9	15	20	41	2	0.745	-0.089	4.209	0.01	0.007	0	45.6	41.7	67.1	141	131	0	35	34
2014	9	15	20	51	2	0.748	-0.095	4.209	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	15	21	1	2	0.751	-0.115	4.213	0.013	0.01	0	45.2	41.3	72.2	140	130	0	35	34
2014	9	15	21	11	2	0.787	-0.069	4.213	0.016	0.013	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	15	21	21	2	0.771	-0.085	4.213	0.013	0.01	0	43.9	41.3	71	138	129	0	36	33
2014	9	15	21	31	2	0.778	-0.095	4.213	0.01	0.007	0	44.3	40.9	71.8	137	128	0	34	33
2014	9	15	21	41	2	0.791	-0.066	4.213	0.01	0.007	0	44.3	40.4	72.2	138	128	0	35	34
2014	9	15	21	51	2	0.817	-0.072	4.213	0.01	0.007	0	44.3	40.4	62.8	138	128	0	35	34
2014	9	15	22	1	2	0.751	-0.066	4.213	0.01	0.007	0	43.9	40.9	72.7	138	129	0	36	34
2014	9	15	22	11	2	0.771	-0.095	4.213	0.01	0.007	0	44.3	41.3	68.4	138	129	0	35	33
2014	9	15	22	21	2	0.771	-0.082	4.213	0.01	0.007	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	15	22	31	2	0.778	-0.112	4.213	0.01	0.007	0	44.3	40.4	72.7	137	128	0	34	34
2014	9	15	22	41	2	0.761	-0.095	4.213	0.01	0.007	0	44.7	40.4	72.7	138	128	0	34	34
2014	9	15	22	51	2	0.755	-0.075	4.213	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	15	23	1	2	0.784	-0.082	4.213	0.01	0.007	0	44.3	40.4	72.7	137	128	0	34	34
2014	9	15	23	11	2	0.741	-0.059	4.216	0.01	0.007	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	15	23	21	2	0.758	-0.075	4.213	0.013	0.01	0	45.2	40.9	72.7	139	129	0	34	34
2014	9	15	23	31	2	0.741	-0.085	4.213	0.01	0.007	0	44.7	41.3	72.2	139	129	0	35	33
2014	9	15	23	41	2	0.755	-0.089	4.216	0.013	0.01	0	44.7	41.3	72.7	138	129	0	34	33
2014	9	15	23	51	2	0.764	-0.085	4.216	0.01	0.007	0	44.7	40.9	72.2	138	129	0	34	34
2014	9	16	0	1	2	0.761	-0.062	4.216	0.01	0.007	0	44.3	41.3	72.7	138	129	0	35	33
2014	9	16	0	11	2	0.768	-0.072	4.213	0.01	0.007	0	44.3	41.3	72.7	138	129	0	35	33
2014	9	16	0	21	2	0.797	-0.085	4.216	0.01	0.007	0	43.9	40.4	72.7	137	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	0	31	2	0.791	-0.085	4.216	0.01	0.007	0	44.3	40.9	72.7	138	128	0	35	33
2014	9	16	0	41	2	0.755	-0.075	4.216	0.01	0.007	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	16	0	51	2	0.774	-0.062	4.216	0.013	0.01	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	16	1	1	2	0.758	-0.062	4.216	0.01	0.007	0	44.3	40.4	73.1	137	128	0	34	34
2014	9	16	1	11	2	0.774	-0.112	4.216	0.013	0.01	0	44.3	40.4	73.1	138	127	0	35	33
2014	9	16	1	21	2	0.741	-0.069	4.216	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	16	1	31	2	0.774	-0.092	4.216	0.01	0.007	0	44.3	40	72.2	137	127	0	34	34
2014	9	16	1	41	2	0.791	-0.108	4.216	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	16	1	51	2	0.794	-0.079	4.216	0.01	0.007	0	44.3	40.4	72.7	137	128	0	34	34
2014	9	16	2	1	2	0.781	-0.095	4.216	0.01	0.007	0	44.3	40.9	73.1	138	128	0	35	33
2014	9	16	2	11	2	0.751	-0.098	4.216	0.01	0.007	0	44.7	41.3	72.7	139	129	0	35	33
2014	9	16	2	21	2	0.771	-0.059	4.216	0.01	0.007	0	44.3	40.9	73.1	138	128	0	35	33
2014	9	16	2	31	2	0.738	-0.085	4.216	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	16	2	41	2	0.784	-0.089	4.216	0.016	0.016	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	16	2	51	2	0.755	-0.082	4.216	0.013	0.01	0	44.3	40.4	74	138	128	0	35	34
2014	9	16	3	1	2	0.748	-0.102	4.216	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	16	3	11	2	0.761	-0.072	4.216	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	16	3	21	2	0.791	-0.095	4.216	0.01	0.007	0	43.9	40.9	74.4	137	128	0	35	33
2014	9	16	3	31	2	0.764	-0.095	4.216	0.01	0.007	0	43.9	40.9	74.4	137	128	0	35	33
2014	9	16	3	41	2	0.794	-0.082	4.216	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	16	3	51	2	0.801	-0.098	4.216	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	16	4	1	2	0.745	-0.066	4.219	0.01	0.007	0	44.3	40.4	74.4	137	128	0	34	34
2014	9	16	4	11	2	0.774	-0.092	4.216	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	16	4	21	2	0.771	-0.098	4.216	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	16	4	31	2	0.784	-0.049	4.216	0.01	0.007	0	43.9	40.9	74.4	137	128	0	35	33
2014	9	16	4	41	2	0.781	-0.069	4.216	0.01	0.007	0	44.3	40.9	74	138	128	0	35	33
2014	9	16	4	51	2	0.748	-0.095	4.219	0.013	0.01	0	45.2	40.9	74.8	139	129	0	34	34
2014	9	16	5	1	2	0.755	-0.085	4.219	0.013	0.01	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	16	5	11	2	0.771	-0.075	4.219	0.01	0.007	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	16	5	21	2	0.755	-0.095	4.219	0.016	0.013	0	45.2	40.9	72.7	139	129	0	34	34
2014	9	16	5	31	2	0.755	-0.059	4.222	0.01	0.007	0	47.7	43.9	74.8	145	135	0	34	33
2014	9	16	5	41	2	0.755	-0.066	4.222	0.016	0.013	0	45.2	41.7	74	140	131	0	35	34
2014	9	16	5	51	2	0.745	-0.079	4.222	0.013	0.01	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	16	6	1	2	0.768	-0.112	4.222	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	16	6	11	2	0.768	-0.089	4.222	0.013	0.01	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	16	6	21	2	0.778	-0.066	4.222	0.01	0.007	0	44.7	40.9	74.8	138	129	0	34	34
2014	9	16	6	31	2	0.751	-0.105	4.222	0.01	0.007	0	45.2	41.7	74.4	140	130	0	35	33
2014	9	16	6	41	2	0.787	-0.059	4.222	0.01	0.007	0	44.7	41.3	74.4	139	130	0	35	34
2014	9	16	6	51	2	0.768	-0.089	4.222	0.013	0.01	0	45.2	41.3	74.4	140	130	0	35	34
2014	9	16	7	1	2	0.751	-0.089	4.222	0.01	0.007	0	44.7	41.3	74	139	130	0	35	34
2014	9	16	7	11	2	0.774	-0.085	4.222	0.01	0.007	0	44.3	40.9	74	138	129	0	35	34
2014	9	16	7	21	2	0.758	-0.062	4.222	0.01	0.007	0	43.9	39.6	74.8	137	126	0	35	34
2014	9	16	7	31	2	0.784	-0.079	4.222	0.01	0.007	0	43.9	40.4	74.8	136	127	0	34	33
2014	9	16	7	41	2	0.764	-0.069	4.226	0.01	0.007	0	43.4	40.4	74.8	136	127	0	35	33
2014	9	16	7	51	2	0.804	-0.056	4.222	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	16	8	1	2	0.787	-0.098	4.222	0.016	0.013	0	43.9	39.6	75.3	136	126	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	8	11	2	0.771	-0.089	4.222	0.013	0.01	0	43	39.6	74.4	135	126	0	35	34
2014	9	16	8	21	2	0.771	-0.098	4.222	0.013	0.01	0	43.4	40	75.3	136	127	0	35	34
2014	9	16	8	31	2	0.764	-0.075	4.222	0.013	0.01	0	43.4	39.6	75.3	135	126	0	34	34
2014	9	16	8	41	2	0.784	-0.072	4.222	0.013	0.01	0	43.4	40	74.8	136	127	0	35	34
2014	9	16	8	51	2	0.761	-0.072	4.222	0.01	0.007	0	43.4	39.1	75.3	136	126	0	35	35
2014	9	16	9	1	2	0.764	-0.082	4.222	0.01	0.007	0	43	40	74.8	135	126	0	35	33
2014	9	16	9	11	2	0.758	-0.102	4.222	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	16	9	21	2	0.751	-0.089	4.222	0.013	0.01	0	43.4	40	74.8	136	127	0	35	34
2014	9	16	9	31	2	0.768	-0.072	4.222	0.016	0.013	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	16	9	41	2	0.784	-0.105	4.222	0.01	0.007	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	16	9	51	2	0.787	-0.079	4.222	0.013	0.01	0	43.4	40.4	75.7	136	127	0	35	33
2014	9	16	10	1	2	0.768	-0.082	4.222	0.016	0.013	0	43.4	40	75.3	136	127	0	35	34
2014	9	16	10	11	2	0.771	-0.082	4.222	0.013	0.01	0	43.4	40.4	75.7	136	128	0	35	34
2014	9	16	10	21	2	0.745	-0.105	4.222	0.01	0.007	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	16	10	31	2	0.787	-0.125	4.222	0.01	0.007	0	43	39.6	75.7	135	126	0	35	34
2014	9	16	10	41	2	0.771	-0.105	4.222	0.013	0.01	0	43	40.4	76.1	135	127	0	35	33
2014	9	16	10	51	2	0.794	-0.095	4.222	0.01	0.007	0	43.4	40	76.1	135	126	0	34	33
2014	9	16	11	1	2	0.771	-0.115	4.222	0.016	0.013	0	43	40	76.5	135	127	0	35	34
2014	9	16	11	11	2	0.804	-0.141	4.222	0.01	0.007	0	43	39.6	74	135	126	0	35	34
2014	9	16	11	21	2	0.801	-0.105	4.222	0.01	0.007	0	43	39.6	71	135	126	0	35	34
2014	9	16	11	31	2	0.774	-0.135	4.219	0.016	0.013	0	43.4	40	76.1	135	127	0	34	34
2014	9	16	11	41	2	0.745	-0.131	4.219	0.01	0.007	0	42.6	39.6	75.3	134	126	0	35	34
2014	9	16	11	51	2	0.778	-0.144	4.219	0.01	0.007	0	43.4	40	71.8	136	127	0	35	34
2014	9	16	12	1	2	0.784	-0.115	4.219	0.01	0.007	0	43	39.6	64.9	135	126	0	35	34
2014	9	16	12	11	2	0.774	-0.157	4.219	0.01	0.007	0	43	40	61.1	135	126	0	35	33
2014	9	16	12	21	2	0.774	-0.144	4.216	0.01	0.007	0	42.6	39.1	55.5	134	125	0	35	34
2014	9	16	12	31	2	0.787	-0.131	4.216	0.01	0.007	0	43.4	40.4	55.5	136	127	0	35	33
2014	9	16	12	41	2	0.787	-0.108	4.216	0.01	0.007	0	43.9	40.4	54.2	136	128	0	34	34
2014	9	16	12	51	2	0.774	-0.157	4.213	0.013	0.01	0	43.4	40.4	50.7	135	127	0	34	33
2014	9	16	13	1	2	0.778	-0.131	4.213	0.013	0.01	0	43.9	40.4	52.9	136	128	0	34	34
2014	9	16	13	11	2	0.774	-0.141	4.213	0.01	0.007	0	43.9	40.4	50.3	136	127	0	34	33
2014	9	16	13	21	2	0.758	-0.157	4.209	0.01	0.007	0	43.4	39.6	52	136	126	0	35	34
2014	9	16	13	31	2	0.732	-0.135	4.209	0.013	0.01	0	43.4	40	51.6	136	127	0	35	34
2014	9	16	13	41	2	0.755	-0.102	4.213	0.013	0.01	0	43.9	40.9	71	137	128	0	35	33
2014	9	16	13	51	2	0.778	-0.121	4.209	0.01	0.007	0	44.3	40.9	51.6	138	129	0	35	34
2014	9	16	14	1	2	0.784	-0.121	4.213	0.01	0.007	0	43.4	40.4	69.2	136	127	0	35	33
2014	9	16	14	11	2	0.794	-0.154	4.206	0.01	0.007	0	45.2	42.1	58.9	140	131	0	35	33
2014	9	16	14	21	2	0.768	-0.089	4.206	0.01	0.007	0	44.3	40.9	56.8	137	128	0	34	33
2014	9	16	14	31	2	0.771	-0.144	4.206	0.01	0.007	0	43.4	40.4	70.5	136	128	0	35	34
2014	9	16	14	41	2	0.732	-0.141	4.203	0.01	0.007	0	44.3	40.9	70.5	137	128	0	34	33
2014	9	16	14	51	2	0.768	-0.098	4.203	0.013	0.01	0	44.7	40.9	52.5	138	129	0	34	34
2014	9	16	15	1	2	0.758	-0.174	4.203	0.01	0.007	0	43.4	40.4	54.2	136	128	0	35	34
2014	9	16	15	11	2	0.771	-0.157	4.203	0.01	0.007	0	44.3	40.4	53.3	137	128	0	34	34
2014	9	16	15	21	2	0.764	-0.144	4.199	0.01	0.007	0	43.9	40.4	55.5	137	128	0	35	34
2014	9	16	15	31	2	0.784	-0.187	4.203	0.01	0.007	0	44.3	41.3	52.9	138	129	0	35	33
2014	9	16	15	41	2	0.764	-0.144	4.203	0.016	0.013	0	43.9	40.4	51.2	137	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	15	51	2	0.768	-0.128	4.199	0.01	0.007	0	43.9	40.9	55.9	137	129	0	35	34
2014	9	16	16	1	2	0.774	-0.131	4.199	0.013	0.01	0	43.4	40.9	52.5	137	128	0	36	33
2014	9	16	16	11	2	0.732	-0.151	4.199	0.01	0.007	0	44.3	41.3	52.9	138	129	0	35	33
2014	9	16	16	21	2	0.755	-0.161	4.196	0.013	0.01	0	44.3	40.9	54.2	138	129	0	35	34
2014	9	16	16	31	2	0.761	-0.148	4.196	0.01	0.007	0	44.3	40.9	54.2	138	129	0	35	34
2014	9	16	16	41	2	0.751	-0.121	4.199	0.01	0.007	0	44.7	40.9	52.9	138	129	0	34	34
2014	9	16	16	51	2	0.774	-0.115	4.196	0.01	0.007	0	44.3	40.9	62.4	138	129	0	35	34
2014	9	16	17	1	2	0.771	-0.108	4.199	0.01	0.007	0	44.3	40.9	53.3	138	129	0	35	34
2014	9	16	17	11	2	0.774	-0.148	4.196	0.01	0.007	0	43.9	40.4	57.6	137	128	0	35	34
2014	9	16	17	21	2	0.755	-0.128	4.199	0.01	0.007	0	44.3	40.4	52.5	138	128	0	35	34
2014	9	16	17	31	2	0.761	-0.171	4.196	0.013	0.01	0	43.4	40	62.4	136	127	0	35	34
2014	9	16	17	41	2	0.774	-0.128	4.196	0.013	0.01	0	43.4	40	57.2	136	127	0	35	34
2014	9	16	17	51	2	0.774	-0.157	4.196	0.01	0.007	0	43.9	39.6	58.5	136	126	0	34	34
2014	9	16	18	1	2	0.774	-0.128	4.199	0.01	0.007	0	43.9	40.4	49.5	137	128	0	35	34
2014	9	16	18	11	2	0.751	-0.105	4.196	0.013	0.01	0	43.9	40.4	58.5	137	128	0	35	34
2014	9	16	18	21	2	0.774	-0.105	4.196	0.01	0.007	0	44.3	40.4	60.6	138	128	0	35	34
2014	9	16	18	31	2	0.758	-0.072	4.196	0.01	0.007	0	44.3	40.9	71	138	128	0	35	33
2014	9	16	18	41	2	0.791	-0.095	4.196	0.01	0.007	0	44.3	40.9	69.7	138	128	0	35	33
2014	9	16	18	51	2	0.781	-0.095	4.196	0.01	0.007	0	44.7	40.4	70.5	138	128	0	34	34
2014	9	16	19	1	2	0.774	-0.082	4.196	0.01	0.007	0	45.2	41.3	71	139	129	0	34	33
2014	9	16	19	11	2	0.791	-0.089	4.196	0.01	0.007	0	44.7	41.3	64.1	139	130	0	35	34
2014	9	16	19	21	2	0.774	-0.079	4.196	0.01	0.007	0	45.2	41.7	65.8	140	131	0	35	34
2014	9	16	19	31	2	0.797	-0.085	4.196	0.01	0.007	0	45.6	41.7	64.5	140	131	0	34	34
2014	9	16	19	41	2	0.768	-0.095	4.196	0.013	0.01	0	44.7	41.7	64.1	139	131	0	35	34
2014	9	16	19	51	2	0.781	-0.092	4.196	0.01	0.007	0	45.2	41.7	63.6	140	131	0	35	34
2014	9	16	20	1	2	0.774	-0.085	4.196	0.016	0.013	0	45.6	41.7	59.8	140	131	0	34	34
2014	9	16	20	11	2	0.774	-0.095	4.199	0.01	0.007	0	46	42.6	53.8	142	133	0	35	34
2014	9	16	20	21	2	0.787	-0.092	4.199	0.01	0.007	0	44.7	41.7	53.3	139	130	0	35	33
2014	9	16	20	31	2	0.774	-0.115	4.199	0.01	0.007	0	44.7	41.3	55	139	130	0	35	34
2014	9	16	20	41	2	0.768	-0.082	4.196	0.01	0.007	0	44.7	41.3	62.4	139	130	0	35	34
2014	9	16	20	51	2	0.778	-0.066	4.196	0.01	0.007	0	45.2	41.7	65.8	140	130	0	35	33
2014	9	16	21	1	2	0.768	-0.105	4.199	0.013	0.01	0	44.7	41.3	72.2	138	129	0	34	33
2014	9	16	21	11	2	0.758	-0.089	4.199	0.01	0.007	0	44.7	40.9	71.4	138	129	0	34	34
2014	9	16	21	21	2	0.764	-0.095	4.199	0.01	0.007	0	44.3	41.3	58.9	138	129	0	35	33
2014	9	16	21	31	2	0.794	-0.079	4.199	0.016	0.013	0	43.9	41.3	59.8	138	129	0	36	33
2014	9	16	21	41	2	0.764	-0.069	4.199	0.01	0.007	0	44.3	40.4	61.5	138	128	0	35	34
2014	9	16	21	51	2	0.784	-0.112	4.199	0.013	0.01	0	43.9	40.4	57.6	137	128	0	35	34
2014	9	16	22	1	2	0.751	-0.089	4.199	0.01	0.007	0	44.3	40.9	61.5	138	129	0	35	34
2014	9	16	22	11	2	0.774	-0.072	4.199	0.01	0.007	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	16	22	21	2	0.774	-0.098	4.199	0.013	0.01	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	16	22	31	2	0.751	-0.079	4.199	0.013	0.01	0	44.7	41.7	72.2	139	130	0	35	33
2014	9	16	22	41	2	0.745	-0.066	4.199	0.01	0.007	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	16	22	51	2	0.761	-0.095	4.199	0.01	0.007	0	44.3	41.3	71.8	138	129	0	35	33
2014	9	16	23	1	2	0.771	-0.075	4.199	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	16	23	11	2	0.748	-0.079	4.203	0.016	0.013	0	44.3	41.3	71.4	138	129	0	35	33
2014	9	16	23	21	2	0.778	-0.108	4.199	0.013	0.01	0	44.3	41.3	72.2	138	129	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	23	31	2	0.801	-0.056	4.203	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	16	23	41	2	0.784	-0.082	4.203	0.01	0.007	0	44.3	40.9	71.8	137	128	0	34	33
2014	9	16	23	51	2	0.787	-0.079	4.203	0.01	0.007	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	17	0	1	2	0.755	-0.085	4.199	0.016	0.016	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	17	0	11	2	0.741	-0.098	4.199	0.01	0.007	0	44.7	40.9	69.7	138	129	0	34	34
2014	9	17	0	21	2	0.781	-0.062	4.199	0.01	0.007	0	44.3	40.4	71.4	138	128	0	35	34
2014	9	17	0	31	2	0.768	-0.062	4.203	0.016	0.013	0	44.7	40.9	71	138	129	0	34	34
2014	9	17	0	41	2	0.771	-0.049	4.203	0.01	0.007	0	44.3	40.4	71.4	137	128	0	34	34
2014	9	17	0	51	2	0.781	-0.062	4.203	0.013	0.01	0	43.9	40.4	70.5	137	128	0	35	34
2014	9	17	1	1	2	0.778	-0.108	4.203	0.01	0.007	0	44.7	40.4	63.6	138	128	0	34	34
2014	9	17	1	11	2	0.778	-0.098	4.203	0.01	0.007	0	44.3	40.9	71.4	138	128	0	35	33
2014	9	17	1	21	2	0.761	-0.085	4.203	0.01	0.007	0	44.3	40.9	71	137	128	0	34	33
2014	9	17	1	31	2	0.751	-0.056	4.203	0.01	0.007	0	43.9	40.9	70.1	137	128	0	35	33
2014	9	17	1	41	2	0.787	-0.069	4.203	0.013	0.01	0	44.3	40.4	71	137	128	0	34	34
2014	9	17	1	51	2	0.741	-0.079	4.203	0.01	0.007	0	44.3	41.3	68.4	138	129	0	35	33
2014	9	17	2	1	2	0.794	-0.066	4.203	0.01	0.007	0	44.3	40.4	65.4	137	128	0	34	34
2014	9	17	2	11	2	0.761	-0.069	4.203	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	17	2	21	2	0.774	-0.112	4.203	0.013	0.01	0	43.4	40.4	58.5	136	127	0	35	33
2014	9	17	2	31	2	0.778	-0.108	4.203	0.01	0.007	0	43.4	39.6	62.8	135	126	0	34	34
2014	9	17	2	41	2	0.784	-0.095	4.203	0.01	0.007	0	43.9	40.4	70.5	137	128	0	35	34
2014	9	17	2	51	2	0.745	-0.082	4.206	0.01	0.007	0	44.3	40.9	71	137	128	0	34	33
2014	9	17	3	1	2	0.738	-0.082	4.206	0.013	0.01	0	44.3	40.4	68.8	137	128	0	34	34
2014	9	17	3	11	2	0.804	-0.075	4.206	0.013	0.01	0	44.3	40.4	71	137	128	0	34	34
2014	9	17	3	21	2	0.768	-0.066	4.206	0.01	0.007	0	44.3	40.9	71	138	129	0	35	34
2014	9	17	3	31	2	0.794	-0.095	4.206	0.01	0.007	0	43.9	40.4	62.8	137	128	0	35	34
2014	9	17	3	41	2	0.784	-0.079	4.206	0.01	0.007	0	43.9	40.9	61.5	137	128	0	35	33
2014	9	17	3	51	2	0.755	-0.095	4.209	0.01	0.007	0	44.3	40.9	70.5	137	128	0	34	33
2014	9	17	4	1	2	0.764	-0.082	4.209	0.01	0.007	0	44.3	40.9	70.5	138	129	0	35	34
2014	9	17	4	11	2	0.761	-0.075	4.206	0.01	0.007	0	44.7	40.9	62.8	138	129	0	34	34
2014	9	17	4	21	2	0.774	-0.072	4.206	0.013	0.01	0	45.6	42.1	60.2	140	131	0	34	33
2014	9	17	4	31	2	0.787	-0.092	4.209	0.01	0.007	0	44.3	40.9	68.4	138	129	0	35	34
2014	9	17	4	41	2	0.778	-0.102	4.206	0.013	0.01	0	43.9	40.9	58.9	137	128	0	35	33
2014	9	17	4	51	2	0.778	-0.082	4.213	0.01	0.007	0	44.3	41.3	70.5	138	129	0	35	33
2014	9	17	5	1	2	0.787	-0.092	4.213	0.013	0.01	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	17	5	11	2	0.758	-0.095	4.216	0.013	0.01	0	44.7	40.9	72.7	138	129	0	34	34
2014	9	17	5	21	2	0.761	-0.072	4.213	0.013	0.01	0	44.7	41.7	71.4	139	130	0	35	33
2014	9	17	5	31	2	0.741	-0.072	4.216	0.01	0.007	0	44.7	41.7	72.7	139	130	0	35	33
2014	9	17	5	41	2	0.751	-0.112	4.213	0.01	0.007	0	45.2	41.7	71	139	130	0	34	33
2014	9	17	5	51	2	0.787	-0.075	4.206	0.01	0.007	0	45.6	42.1	70.1	141	132	0	35	34
2014	9	17	6	1	2	0.745	-0.089	4.203	0.01	0.007	0	46	42.1	70.5	141	132	0	34	34
2014	9	17	6	11	2	0.778	-0.079	4.199	0.01	0.007	0	45.2	41.3	71.4	139	130	0	34	34
2014	9	17	6	21	2	0.761	-0.082	4.203	0.01	0.007	0	45.2	41.7	70.5	140	131	0	35	34
2014	9	17	6	31	2	0.778	-0.079	4.203	0.01	0.007	0	46.4	43	71	142	133	0	34	33
2014	9	17	6	41	2	0.761	-0.069	4.203	0.013	0.01	0	46.9	43.4	71	143	134	0	34	33
2014	9	17	6	51	2	0.784	-0.089	4.203	0.016	0.013	0	44.3	41.3	71.8	138	129	0	35	33
2014	9	17	7	1	2	0.764	-0.108	4.199	0.01	0.007	0	44.7	41.7	71	139	130	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	7	11	2	0.748	-0.075	4.199	0.01	0.007	0	43.9	40.4	63.2	137	128	0	35	34
2014	9	17	7	21	2	0.768	-0.082	4.199	0.013	0.01	0	44.3	40.4	71.4	137	128	0	34	34
2014	9	17	7	31	2	0.778	-0.075	4.199	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	17	7	41	2	0.774	-0.095	4.199	0.01	0.007	0	44.3	40.9	71.8	137	128	0	34	33
2014	9	17	7	51	2	0.761	-0.095	4.199	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	17	8	1	2	0.745	-0.072	4.199	0.01	0.007	0	43.9	40.9	72.2	137	128	0	35	33
2014	9	17	8	11	2	0.748	-0.085	4.199	0.01	0.007	0	43.9	40.9	72.2	137	129	0	35	34
2014	9	17	8	21	2	0.751	-0.115	4.199	0.013	0.01	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	17	8	31	2	0.794	-0.079	4.199	0.01	0.007	0	43.9	40.9	72.2	137	128	0	35	33
2014	9	17	8	41	2	0.781	-0.085	4.199	0.01	0.007	0	44.3	40.9	72.2	137	128	0	34	33
2014	9	17	8	51	2	0.778	-0.095	4.199	0.01	0.007	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	17	9	1	2	0.764	-0.095	4.199	0.01	0.007	0	44.3	40.4	72.7	137	128	0	34	34
2014	9	17	9	11	2	0.748	-0.066	4.199	0.01	0.007	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	17	9	21	2	0.807	-0.128	4.199	0.01	0.007	0	43.4	40.4	70.5	136	127	0	35	33
2014	9	17	9	31	2	0.778	-0.138	4.199	0.01	0.007	0	43	39.6	59.3	135	126	0	35	34
2014	9	17	9	41	2	0.778	-0.138	4.199	0.01	0.007	0	43.9	40	55.9	136	127	0	34	34
2014	9	17	9	51	2	0.787	-0.151	4.196	0.013	0.01	0	43.4	40	59.8	135	126	0	34	33
2014	9	17	10	1	2	0.787	-0.141	4.196	0.01	0.007	0	43	39.6	64.1	135	125	0	35	33
2014	9	17	10	11	2	0.768	-0.115	4.196	0.01	0.007	0	43.9	40.4	61.9	136	128	0	34	34
2014	9	17	10	21	2	0.794	-0.102	4.196	0.01	0.007	0	43.4	40.4	59.8	136	127	0	35	33
2014	9	17	10	31	2	0.774	-0.157	4.196	0.01	0.007	0	43.4	39.6	58.5	135	126	0	34	34
2014	9	17	10	41	2	0.761	-0.161	4.196	0.013	0.01	0	43.4	40	63.2	136	127	0	35	34
2014	9	17	10	51	2	0.794	-0.135	4.196	0.013	0.01	0	43.4	40.4	67.9	136	127	0	35	33
2014	9	17	11	1	2	0.807	-0.105	4.196	0.013	0.01	0	43.4	40.4	58.5	136	128	0	35	34
2014	9	17	11	11	2	0.784	-0.131	4.196	0.01	0.007	0	43.4	40.4	52.9	136	127	0	35	33
2014	9	17	11	21	2	0.738	-0.141	4.193	0.016	0.013	0	43	39.6	60.6	135	126	0	35	34
2014	9	17	11	31	2	0.764	-0.128	4.193	0.01	0.007	0	43.4	40.4	59.3	136	127	0	35	33
2014	9	17	11	41	2	0.771	-0.128	4.193	0.013	0.01	0	43.9	40.9	58.9	136	128	0	34	33
2014	9	17	11	51	2	0.771	-0.112	4.193	0.016	0.013	0	43.4	40	63.2	136	127	0	35	34
2014	9	17	12	1	2	0.774	-0.115	4.193	0.013	0.01	0	43.4	40	69.7	136	127	0	35	34
2014	9	17	12	11	2	0.774	-0.128	4.193	0.01	0.007	0	43.4	40.9	72.7	136	128	0	35	33
2014	9	17	12	21	2	0.784	-0.115	4.193	0.01	0.007	0	43.4	40	61.5	136	127	0	35	34
2014	9	17	12	31	2	0.764	-0.125	4.193	0.013	0.01	0	43.9	40.9	64.1	136	128	0	34	33
2014	9	17	12	41	2	0.774	-0.161	4.193	0.013	0.01	0	43	40.4	55.9	135	127	0	35	33
2014	9	17	12	51	2	0.794	-0.112	4.193	0.013	0.01	0	43.9	40.9	57.2	137	128	0	35	33
2014	9	17	13	1	2	0.771	-0.131	4.193	0.01	0.007	0	43.4	40.9	56.3	136	128	0	35	33
2014	9	17	13	11	2	0.764	-0.177	4.193	0.013	0.01	0	43.4	40	52.5	136	127	0	35	34
2014	9	17	13	21	2	0.751	-0.154	4.19	0.013	0.01	0	43.4	40.4	51.6	136	128	0	35	34
2014	9	17	13	31	2	0.768	-0.144	4.19	0.016	0.013	0	43.9	40.4	52	137	128	0	35	34
2014	9	17	13	41	2	0.758	-0.131	4.19	0.01	0.007	0	44.3	41.3	51.2	138	129	0	35	33
2014	9	17	13	51	2	0.784	-0.082	4.19	0.01	0.007	0	45.2	41.7	51.6	139	131	0	34	34
2014	9	17	14	1	2	0.774	-0.161	4.186	0.013	0.01	0	44.7	41.7	50.7	139	130	0	35	33
2014	9	17	14	11	2	0.761	-0.164	4.19	0.01	0.007	0	44.7	41.7	49	139	131	0	35	34
2014	9	17	14	21	2	0.764	-0.118	4.19	0.01	0.007	0	45.2	41.7	50.7	140	131	0	35	34
2014	9	17	14	31	2	0.778	-0.112	4.186	0.013	0.01	0	46	42.1	49.9	141	132	0	34	34
2014	9	17	14	41	2	0.758	-0.098	4.183	0.013	0.01	0	45.2	41.7	48.6	140	131	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	14	51	2	0.755	-0.174	4.186	0.013	0.01	0	45.6	42.1	49.9	141	132	0	35	34
2014	9	17	15	1	2	0.755	-0.157	4.186	0.01	0.007	0	45.6	42.1	50.3	141	132	0	35	34
2014	9	17	15	11	2	0.738	-0.112	4.186	0.01	0.007	0	45.6	42.1	49.9	141	132	0	35	34
2014	9	17	15	21	2	0.761	-0.108	4.183	0.01	0.007	0	45.6	42.1	48.6	140	132	0	34	34
2014	9	17	15	31	2	0.768	-0.112	4.183	0.01	0.007	0	46	42.6	51.6	142	133	0	35	34
2014	9	17	15	41	2	0.738	-0.131	4.183	0.01	0.007	0	45.6	43	50.3	141	133	0	35	33
2014	9	17	15	51	2	0.751	-0.138	4.183	0.016	0.013	0	46	43.4	50.7	142	134	0	35	33
2014	9	17	16	1	2	0.758	-0.105	4.186	0.013	0.01	0	45.2	43	50.3	140	132	0	35	32
2014	9	17	16	11	2	0.741	-0.18	4.183	0.016	0.013	0	45.2	42.1	52.5	140	131	0	35	33
2014	9	17	16	21	2	0.758	-0.128	4.183	0.01	0.007	0	45.2	41.7	51.6	140	131	0	35	34
2014	9	17	16	31	2	0.764	-0.131	4.18	0.013	0.01	0	45.6	41.7	51.6	140	131	0	34	34
2014	9	17	16	41	2	0.748	-0.098	4.18	0.01	0.007	0	45.2	41.7	51.2	140	131	0	35	34
2014	9	17	16	51	2	0.758	-0.121	4.183	0.01	0.007	0	45.2	42.1	52.9	139	131	0	34	33
2014	9	17	17	1	2	0.758	-0.121	4.183	0.01	0.007	0	45.2	41.7	50.7	139	130	0	34	33
2014	9	17	17	11	2	0.771	-0.118	4.18	0.01	0.007	0	44.7	42.1	51.2	139	131	0	35	33
2014	9	17	17	21	2	0.784	-0.105	4.18	0.013	0.01	0	45.2	41.7	50.3	139	130	0	34	33
2014	9	17	17	31	2	0.768	-0.082	4.183	0.013	0.01	0	44.7	41.3	52.5	139	130	0	35	34
2014	9	17	17	41	2	0.778	-0.118	4.18	0.013	0.01	0	44.3	41.7	49.9	138	130	0	35	33
2014	9	17	17	51	2	0.797	-0.079	4.18	0.016	0.013	0	44.7	41.7	51.6	139	130	0	35	33
2014	9	17	18	1	2	0.774	-0.066	4.18	0.01	0.007	0	44.7	41.7	51.2	139	131	0	35	34
2014	9	17	18	11	2	0.778	-0.102	4.18	0.01	0.007	0	44.7	41.7	52	139	130	0	35	33
2014	9	17	18	21	2	0.768	-0.115	4.18	0.01	0.007	0	44.3	40.9	51.6	138	129	0	35	34
2014	9	17	18	31	2	0.745	-0.066	4.18	0.01	0.007	0	44.7	41.3	52	139	130	0	35	34
2014	9	17	18	41	2	0.748	-0.066	4.18	0.013	0.01	0	44.7	41.7	51.6	139	130	0	35	33
2014	9	17	18	51	2	0.774	-0.098	4.18	0.01	0.007	0	44.7	41.7	52.5	139	130	0	35	33
2014	9	17	19	1	2	0.774	-0.095	4.18	0.01	0.007	0	45.2	41.7	56.3	139	130	0	34	33
2014	9	17	19	11	2	0.771	-0.085	4.183	0.01	0.007	0	44.7	41.3	72.7	138	129	0	34	33
2014	9	17	19	21	2	0.755	-0.108	4.183	0.01	0.007	0	44.7	41.3	56.8	138	130	0	34	34
2014	9	17	19	31	2	0.761	-0.082	4.18	0.016	0.013	0	45.6	42.1	54.2	140	131	0	34	33
2014	9	17	19	41	2	0.758	-0.089	4.18	0.013	0.01	0	46	42.6	51.6	141	132	0	34	33
2014	9	17	19	51	2	0.761	-0.125	4.183	0.013	0.01	0	45.6	41.7	54.6	140	131	0	34	34
2014	9	17	20	1	2	0.794	-0.092	4.183	0.01	0.007	0	44.7	41.7	69.7	139	130	0	35	33
2014	9	17	20	11	2	0.758	-0.089	4.183	0.01	0.007	0	45.6	41.7	71.4	140	131	0	34	34
2014	9	17	20	21	2	0.764	-0.092	4.183	0.013	0.01	0	45.2	42.6	72.7	140	132	0	35	33
2014	9	17	20	31	2	0.764	-0.102	4.186	0.01	0.007	0	44.7	41.7	71.4	139	130	0	35	33
2014	9	17	20	41	2	0.768	-0.066	4.186	0.01	0.007	0	44.3	41.3	74	138	129	0	35	33
2014	9	17	20	51	2	0.764	-0.079	4.186	0.01	0.007	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	17	21	1	2	0.787	-0.069	4.186	0.01	0.007	0	44.7	40.9	74	138	129	0	34	34
2014	9	17	21	11	2	0.755	-0.059	4.186	0.013	0.01	0	44.3	41.3	73.1	138	129	0	35	33
2014	9	17	21	21	2	0.787	-0.079	4.186	0.013	0.01	0	45.2	41.3	72.7	139	129	0	34	33
2014	9	17	21	31	2	0.768	-0.108	4.186	0.01	0.007	0	44.3	41.3	73.5	138	129	0	35	33
2014	9	17	21	41	2	0.781	-0.056	4.186	0.013	0.01	0	44.7	40.9	71.8	138	129	0	34	34
2014	9	17	21	51	2	0.761	-0.102	4.186	0.013	0.01	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	17	22	1	2	0.768	-0.075	4.186	0.013	0.01	0	44.3	40.4	69.2	137	128	0	34	34
2014	9	17	22	11	2	0.761	-0.092	4.186	0.016	0.013	0	44.3	40.9	71.4	138	129	0	35	34
2014	9	17	22	21	2	0.741	-0.062	4.186	0.01	0.007	0	43.4	40.9	66.7	136	128	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	22	31	2	0.761	-0.066	4.186	0.01	0.007	0	43.4	40.4	70.5	136	127	0	35	33
2014	9	17	22	41	2	0.784	-0.089	4.186	0.01	0.007	0	43.4	40.4	74.4	135	127	0	34	33
2014	9	17	22	51	2	0.761	-0.069	4.186	0.01	0.007	0	43.9	40.4	71.8	136	128	0	34	34
2014	9	17	23	1	2	0.738	-0.089	4.186	0.01	0.007	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	17	23	11	2	0.781	-0.066	4.186	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	17	23	21	2	0.771	-0.092	4.186	0.01	0.007	0	43	40.4	58.9	135	127	0	35	33
2014	9	17	23	31	2	0.764	-0.095	4.186	0.01	0.007	0	43.4	40	67.9	136	127	0	35	34
2014	9	17	23	41	2	0.758	-0.095	4.186	0.01	0.007	0	43.4	40	71.4	136	127	0	35	34
2014	9	17	23	51	2	0.741	-0.079	4.186	0.01	0.007	0	43.9	40.9	74	137	128	0	35	33
2014	9	18	0	1	2	0.781	-0.102	4.186	0.01	0.007	0	43.9	40.9	73.5	137	128	0	35	33
2014	9	18	0	11	2	0.784	-0.095	4.19	0.016	0.016	0	43.9	40.9	73.5	137	128	0	35	33
2014	9	18	0	21	2	0.755	-0.066	4.19	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	18	0	31	2	0.774	-0.082	4.19	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	18	0	41	2	0.764	-0.082	4.19	0.013	0.01	0	43.9	40.4	74.4	136	127	0	34	33
2014	9	18	0	51	2	0.801	-0.092	4.186	0.013	0.01	0	43.9	40.9	74.4	137	128	0	35	33
2014	9	18	1	1	2	0.797	-0.072	4.19	0.013	0.01	0	43	39.6	73.1	135	126	0	35	34
2014	9	18	1	11	2	0.751	-0.082	4.186	0.013	0.01	0	43.9	40.9	60.6	137	128	0	35	33
2014	9	18	1	21	2	0.787	-0.079	4.19	0.016	0.013	0	43.4	40.4	68.4	135	127	0	34	33
2014	9	18	1	31	2	0.787	-0.049	4.19	0.016	0.013	0	43.4	40.4	62.4	136	127	0	35	33
2014	9	18	1	41	2	0.751	-0.098	4.19	0.01	0.007	0	43	40.4	74.8	135	127	0	35	33
2014	9	18	1	51	2	0.791	-0.095	4.19	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	18	2	1	2	0.784	-0.112	4.19	0.013	0.01	0	44.3	40.4	74.8	137	128	0	34	34
2014	9	18	2	11	2	0.768	-0.085	4.19	0.01	0.007	0	43.9	40.9	75.3	137	128	0	35	33
2014	9	18	2	21	2	0.774	-0.072	4.19	0.01	0.007	0	43.9	40.4	74	136	127	0	34	33
2014	9	18	2	31	2	0.758	-0.089	4.19	0.01	0.007	0	44.3	40.4	74.4	137	128	0	34	34
2014	9	18	2	41	2	0.774	-0.115	4.19	0.013	0.01	0	44.3	40.9	74.4	137	128	0	34	33
2014	9	18	2	51	2	0.758	-0.089	4.19	0.01	0.007	0	44.3	40.4	74.8	137	128	0	34	34
2014	9	18	3	1	2	0.741	-0.066	4.19	0.01	0.007	0	43.4	40.4	75.3	136	128	0	35	34
2014	9	18	3	11	2	0.758	-0.072	4.19	0.01	0.007	0	44.3	40.9	75.3	137	128	0	34	33
2014	9	18	3	21	2	0.797	-0.072	4.19	0.01	0.007	0	43.9	40.9	75.3	137	128	0	35	33
2014	9	18	3	31	2	0.768	-0.056	4.19	0.01	0.007	0	43.9	40.9	71.4	137	128	0	35	33
2014	9	18	3	41	2	0.784	-0.082	4.19	0.01	0.007	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	18	3	51	2	0.791	-0.082	4.19	0.01	0.007	0	43.4	40	74.4	136	127	0	35	34
2014	9	18	4	1	2	0.768	-0.075	4.19	0.01	0.007	0	43.9	40.4	75.3	137	128	0	35	34
2014	9	18	4	11	2	0.761	-0.092	4.19	0.01	0.007	0	44.3	40.4	75.7	137	128	0	34	34
2014	9	18	4	21	2	0.738	-0.082	4.19	0.01	0.007	0	43.4	40.4	75.7	137	128	0	36	34
2014	9	18	4	31	2	0.761	-0.092	4.19	0.01	0.007	0	44.3	40.9	75.7	138	129	0	35	34
2014	9	18	4	41	2	0.735	-0.079	4.19	0.01	0.007	0	44.3	40.9	76.1	137	128	0	34	33
2014	9	18	4	51	2	0.761	-0.075	4.193	0.01	0.007	0	44.3	40.9	75.7	137	128	0	34	33
2014	9	18	5	1	2	0.771	-0.092	4.193	0.013	0.01	0	43.9	40.9	75.7	137	128	0	35	33
2014	9	18	5	11	2	0.764	-0.066	4.193	0.01	0.007	0	43.9	40.9	76.1	137	129	0	35	34
2014	9	18	5	21	2	0.758	-0.089	4.193	0.01	0.007	0	45.6	42.6	75.3	141	132	0	35	33
2014	9	18	5	31	2	0.748	-0.079	4.193	0.016	0.013	0	45.2	41.3	75.7	139	130	0	34	34
2014	9	18	5	41	2	0.764	-0.112	4.193	0.01	0.007	0	43.9	41.3	75.3	137	129	0	35	33
2014	9	18	5	51	2	0.748	-0.102	4.193	0.01	0.007	0	43.9	40.9	74.8	137	128	0	35	33
2014	9	18	6	1	2	0.764	-0.085	4.193	0.016	0.016	0	44.3	40.9	74.8	137	128	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	6	11	2	0.735	-0.079	4.196	0.01	0.007	0	44.7	41.3	74.8	138	129	0	34	33
2014	9	18	6	21	2	0.748	-0.108	4.196	0.01	0.007	0	45.6	42.6	74.8	141	132	0	35	33
2014	9	18	6	31	2	0.751	-0.056	4.196	0.01	0.007	0	46.9	43.9	74.4	144	135	0	35	33
2014	9	18	6	41	2	0.781	-0.095	4.196	0.013	0.01	0	46	42.6	74	141	132	0	34	33
2014	9	18	6	51	2	0.764	-0.075	4.196	0.013	0.01	0	45.6	42.1	73.5	140	131	0	34	33
2014	9	18	7	1	2	0.764	-0.085	4.196	0.01	0.007	0	45.6	42.1	74	140	131	0	34	33
2014	9	18	7	11	2	0.745	-0.069	4.196	0.01	0.007	0	45.2	40.9	74.4	139	129	0	34	34
2014	9	18	7	21	2	0.751	-0.072	4.196	0.01	0.007	0	44.7	40.9	74.4	138	129	0	34	34
2014	9	18	7	31	2	0.778	-0.095	4.196	0.013	0.01	0	44.3	41.3	74.4	138	129	0	35	33
2014	9	18	7	41	2	0.761	-0.082	4.193	0.013	0.01	0	43.4	40.4	74.8	136	128	0	35	34
2014	9	18	7	51	2	0.761	-0.075	4.196	0.01	0.007	0	43.4	40.4	74.8	136	128	0	35	34
2014	9	18	8	1	2	0.781	-0.082	4.196	0.01	0.007	0	43.9	40.4	74.8	136	128	0	34	34
2014	9	18	8	11	2	0.781	-0.062	4.196	0.01	0.007	0	43.4	40.9	74.8	136	128	0	35	33
2014	9	18	8	21	2	0.774	-0.121	4.196	0.01	0.007	0	43.9	40.9	74.8	136	128	0	34	33
2014	9	18	8	31	2	0.732	-0.066	4.196	0.01	0.007	0	43.4	40	74.8	136	127	0	35	34
2014	9	18	8	41	2	0.804	-0.112	4.196	0.01	0.007	0	43.9	40.4	75.3	136	127	0	34	33
2014	9	18	8	51	2	0.797	-0.079	4.193	0.01	0.007	0	43	40.4	72.7	135	127	0	35	33
2014	9	18	9	1	2	0.768	-0.138	4.193	0.016	0.013	0	43	40.4	76.1	135	127	0	35	33
2014	9	18	9	11	2	0.771	-0.092	4.193	0.01	0.007	0	43.4	40	71	136	127	0	35	34
2014	9	18	9	21	2	0.764	-0.138	4.193	0.01	0.007	0	43.4	40.4	66.7	135	127	0	34	33
2014	9	18	9	31	2	0.774	-0.154	4.193	0.013	0.01	0	43	40	63.2	135	126	0	35	33
2014	9	18	9	41	2	0.748	-0.118	4.193	0.013	0.01	0	42.6	40	55.5	134	126	0	35	33
2014	9	18	9	51	2	0.774	-0.144	4.193	0.01	0.007	0	43	39.6	59.8	135	126	0	35	34
2014	9	18	10	1	2	0.778	-0.112	4.193	0.01	0.007	0	43	40	58	135	127	0	35	34
2014	9	18	10	11	2	0.791	-0.105	4.193	0.016	0.013	0	43	40	57.6	135	126	0	35	33
2014	9	18	10	21	2	0.774	-0.115	4.19	0.013	0.01	0	43	40	52.9	135	126	0	35	33
2014	9	18	10	31	2	0.797	-0.151	4.193	0.01	0.007	0	43.4	40.4	55.5	135	127	0	34	33
2014	9	18	10	41	2	0.764	-0.148	4.19	0.01	0.007	0	43	39.6	66.2	135	126	0	35	34
2014	9	18	10	51	2	0.781	-0.135	4.19	0.013	0.01	0	43.4	40.9	55.9	136	128	0	35	33
2014	9	18	11	1	2	0.764	-0.154	4.19	0.01	0.007	0	43	40	59.3	135	127	0	35	34
2014	9	18	11	11	2	0.784	-0.144	4.19	0.01	0.007	0	43.9	40.9	50.3	136	128	0	34	33
2014	9	18	11	21	2	0.761	-0.118	4.19	0.01	0.007	0	43.9	40.4	52.5	136	128	0	34	34
2014	9	18	11	31	2	0.771	-0.131	4.186	0.01	0.007	0	43.4	40.4	53.8	136	128	0	35	34
2014	9	18	11	41	2	0.761	-0.135	4.19	0.01	0.007	0	43.4	40.9	66.2	136	128	0	35	33
2014	9	18	11	51	2	0.781	-0.105	4.186	0.016	0.013	0	43.9	40.4	52.5	136	128	0	34	34
2014	9	18	12	1	2	0.761	-0.151	4.186	0.01	0.007	0	43.4	40.4	54.2	135	127	0	34	33
2014	9	18	12	11	2	0.781	-0.164	4.183	0.01	0.007	0	43.4	40.4	53.3	135	127	0	34	33
2014	9	18	12	21	2	0.784	-0.148	4.183	0.013	0.01	0	43.9	40.4	56.3	136	128	0	34	34
2014	9	18	12	31	2	0.761	-0.19	4.183	0.01	0.007	0	43	40.4	51.2	135	127	0	35	33
2014	9	18	12	41	2	0.741	-0.161	4.183	0.01	0.007	0	43.9	40.4	52.9	137	128	0	35	34
2014	9	18	12	51	2	0.768	-0.131	4.183	0.01	0.007	0	43.9	40.9	49.9	136	128	0	34	33
2014	9	18	13	1	2	0.741	-0.177	4.18	0.013	0.01	0	43.9	41.3	50.7	137	129	0	35	33
2014	9	18	13	11	2	0.748	-0.112	4.18	0.01	0.007	0	44.3	40.9	49.5	137	129	0	34	34
2014	9	18	13	21	2	0.728	-0.135	4.177	0.016	0.013	0	44.3	41.7	51.6	138	130	0	35	33
2014	9	18	13	31	2	0.741	-0.131	4.177	0.013	0.01	0	44.7	41.7	52.5	139	130	0	35	33
2014	9	18	13	41	2	0.764	-0.177	4.177	0.01	0.007	0	44.3	40.9	51.6	138	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	13	51	2	0.755	-0.125	4.177	0.013	0.01	0	44.3	40.9	49.5	138	129	0	35	34
2014	9	18	14	1	2	0.732	-0.164	4.173	0.01	0.007	0	44.3	41.7	50.7	138	130	0	35	33
2014	9	18	14	11	2	0.784	-0.135	4.173	0.016	0.013	0	44.3	41.3	50.3	138	130	0	35	34
2014	9	18	14	21	2	0.735	-0.112	4.173	0.01	0.007	0	45.2	41.7	49.9	139	131	0	34	34
2014	9	18	14	31	2	0.738	-0.075	4.17	0.01	0.007	0	44.7	42.1	51.6	139	131	0	35	33
2014	9	18	14	41	2	0.741	-0.112	4.17	0.01	0.007	0	45.2	42.1	50.3	140	132	0	35	34
2014	9	18	14	51	2	0.738	-0.18	4.17	0.013	0.01	0	45.6	42.1	49.9	140	132	0	34	34
2014	9	18	15	1	2	0.719	-0.167	4.17	0.01	0.007	0	45.2	42.1	51.6	140	132	0	35	34
2014	9	18	15	11	2	0.758	-0.131	4.167	0.013	0.01	0	44.7	41.7	51.2	139	131	0	35	34
2014	9	18	15	21	2	0.751	-0.121	4.167	0.013	0.01	0	45.6	42.1	51.6	140	132	0	34	34
2014	9	18	15	31	2	0.764	-0.148	4.167	0.01	0.007	0	45.2	42.1	51.6	140	131	0	35	33
2014	9	18	15	41	2	0.791	-0.112	4.167	0.01	0.007	0	45.2	42.6	49.9	140	132	0	35	33
2014	9	18	15	51	2	0.761	-0.112	4.167	0.01	0.007	0	45.6	43	51.2	141	133	0	35	33
2014	9	18	16	1	2	0.781	-0.151	4.167	0.01	0.007	0	45.2	41.7	49.9	139	131	0	34	34
2014	9	18	16	11	2	0.764	-0.144	4.167	0.01	0.007	0	44.7	41.7	50.3	139	131	0	35	34
2014	9	18	16	21	2	0.758	-0.131	4.167	0.013	0.01	0	45.2	42.1	50.7	139	131	0	34	33
2014	9	18	16	31	2	0.771	-0.102	4.167	0.01	0.007	0	45.2	41.7	52	139	131	0	34	34
2014	9	18	16	41	2	0.761	-0.151	4.167	0.01	0.007	0	44.7	42.1	49.9	139	131	0	35	33
2014	9	18	16	51	2	0.748	-0.141	4.167	0.01	0.007	0	44.3	41.3	51.6	138	130	0	35	34
2014	9	18	17	1	2	0.781	-0.138	4.167	0.01	0.007	0	44.7	42.1	49.5	139	131	0	35	33
2014	9	18	17	11	2	0.801	-0.115	4.167	0.01	0.007	0	44.3	40.9	49.9	138	129	0	35	34
2014	9	18	17	21	2	0.764	-0.115	4.167	0.013	0.01	0	44.7	41.7	49.5	138	130	0	34	33
2014	9	18	17	31	2	0.755	-0.118	4.163	0.01	0.007	0	44.7	40.4	50.7	138	129	0	34	35
2014	9	18	17	41	2	0.771	-0.118	4.167	0.013	0.01	0	44.7	40.9	50.3	138	129	0	34	34
2014	9	18	17	51	2	0.764	-0.072	4.167	0.01	0.007	0	45.2	41.3	49.9	139	130	0	34	34
2014	9	18	18	1	2	0.725	-0.066	4.163	0.01	0.007	0	45.2	41.3	52	139	130	0	34	34
2014	9	18	18	11	2	0.748	-0.079	4.167	0.01	0.007	0	44.7	41.3	52	138	130	0	34	34
2014	9	18	18	21	2	0.768	-0.085	4.167	0.01	0.007	0	44.3	41.7	49.5	138	130	0	35	33
2014	9	18	18	31	2	0.768	-0.092	4.167	0.013	0.01	0	45.2	41.7	50.7	139	130	0	34	33
2014	9	18	18	41	2	0.781	-0.095	4.167	0.013	0.01	0	44.7	41.7	50.3	139	131	0	35	34
2014	9	18	18	51	2	0.761	-0.069	4.167	0.01	0.007	0	44.7	41.7	51.6	139	131	0	35	34
2014	9	18	19	1	2	0.751	-0.066	4.167	0.013	0.01	0	44.7	41.7	50.3	139	131	0	35	34
2014	9	18	19	11	2	0.787	-0.108	4.163	0.01	0.007	0	45.2	42.1	52	140	132	0	35	34
2014	9	18	19	21	2	0.768	-0.102	4.167	0.01	0.007	0	45.2	41.7	52.9	139	131	0	34	34
2014	9	18	19	31	2	0.768	-0.066	4.163	0.016	0.013	0	45.2	41.7	51.2	140	131	0	35	34
2014	9	18	19	41	2	0.741	-0.098	4.16	0.01	0.007	0	45.6	42.1	62.4	140	131	0	34	33
2014	9	18	19	51	2	0.778	-0.102	4.163	0.016	0.013	0	46	43	63.2	141	133	0	34	33
2014	9	18	20	1	2	0.761	-0.098	4.163	0.013	0.01	0	45.2	41.7	61.1	140	131	0	35	34
2014	9	18	20	11	2	0.768	-0.072	4.163	0.013	0.01	0	44.7	42.1	72.2	139	131	0	35	33
2014	9	18	20	21	2	0.751	-0.079	4.163	0.01	0.007	0	45.6	41.7	72.7	140	131	0	34	34
2014	9	18	20	31	2	0.735	-0.066	4.163	0.016	0.013	0	45.2	42.1	72.2	140	131	0	35	33
2014	9	18	20	41	2	0.764	-0.082	4.163	0.01	0.007	0	45.2	41.7	73.1	139	130	0	34	33
2014	9	18	20	51	2	0.784	-0.079	4.163	0.013	0.01	0	44.3	41.7	72.7	138	130	0	35	33
2014	9	18	21	1	2	0.768	-0.098	4.163	0.01	0.007	0	45.2	42.1	73.5	140	131	0	35	33
2014	9	18	21	11	2	0.738	-0.069	4.163	0.01	0.007	0	45.6	41.7	71	140	131	0	34	34
2014	9	18	21	21	2	0.748	-0.066	4.163	0.013	0.01	0	45.6	41.7	71	140	131	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	21	31	2	0.758	-0.082	4.163	0.01	0.007	0	44.7	41.3	73.1	138	130	0	34	34
2014	9	18	21	41	2	0.758	-0.082	4.167	0.016	0.013	0	44.7	41.7	72.2	139	130	0	35	33
2014	9	18	21	51	2	0.758	-0.062	4.167	0.013	0.01	0	44.3	41.7	73.1	138	130	0	35	33
2014	9	18	22	1	2	0.778	-0.092	4.167	0.016	0.013	0	44.7	41.3	72.7	138	130	0	34	34
2014	9	18	22	11	2	0.755	-0.092	4.163	0.016	0.013	0	44.7	41.7	72.7	138	130	0	34	33
2014	9	18	22	21	2	0.748	-0.098	4.163	0.01	0.007	0	44.3	40.9	64.1	138	129	0	35	34
2014	9	18	22	31	2	0.751	-0.089	4.167	0.01	0.007	0	44.3	41.3	68.4	138	129	0	35	33
2014	9	18	22	41	2	0.764	-0.095	4.163	0.01	0.007	0	44.3	41.3	63.6	138	130	0	35	34
2014	9	18	22	51	2	0.768	-0.095	4.163	0.01	0.007	0	43.9	40.9	64.9	137	129	0	35	34
2014	9	18	23	1	2	0.768	-0.079	4.167	0.013	0.01	0	44.7	41.3	69.7	138	129	0	34	33
2014	9	18	23	11	2	0.768	-0.121	4.167	0.013	0.01	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	18	23	21	2	0.751	-0.062	4.167	0.01	0.007	0	46	42.1	72.2	141	132	0	34	34
2014	9	18	23	31	2	0.761	-0.131	4.167	0.013	0.01	0	44.7	41.3	71.8	138	129	0	34	33
2014	9	18	23	41	2	0.748	-0.095	4.167	0.013	0.01	0	44.3	41.3	72.2	137	129	0	34	33
2014	9	18	23	51	2	0.778	-0.118	4.167	0.013	0.01	0	44.3	40.9	71.8	137	129	0	34	34
2014	9	19	0	1	2	0.751	-0.085	4.167	0.013	0.01	0	43.9	40.9	71.8	137	129	0	35	34
2014	9	19	0	11	2	0.745	-0.066	4.167	0.013	0.01	0	43.9	40.9	71.8	137	129	0	35	34
2014	9	19	0	21	2	0.751	-0.066	4.167	0.01	0.007	0	44.7	41.3	71.8	138	129	0	34	33
2014	9	19	0	31	2	0.764	-0.089	4.167	0.01	0.007	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	19	0	41	2	0.735	-0.075	4.167	0.01	0.007	0	44.3	40.9	71	137	129	0	34	34
2014	9	19	0	51	2	0.768	-0.095	4.167	0.01	0.007	0	44.3	40.9	71.4	137	128	0	34	33
2014	9	19	1	1	2	0.745	-0.036	4.167	0.01	0.007	0	44.7	40.9	71.4	138	129	0	34	34
2014	9	19	1	11	2	0.774	-0.049	4.167	0.013	0.01	0	43.9	41.3	71.4	137	129	0	35	33
2014	9	19	1	21	2	0.755	-0.069	4.167	0.01	0.007	0	44.3	40.9	71.4	137	128	0	34	33
2014	9	19	1	31	2	0.748	-0.072	4.167	0.01	0.007	0	43.9	40.4	71	137	128	0	35	34
2014	9	19	1	41	2	0.751	-0.085	4.167	0.013	0.01	0	43.9	40.9	71.4	137	128	0	35	33
2014	9	19	1	51	2	0.755	-0.092	4.17	0.013	0.01	0	43.4	40.4	71.4	136	128	0	35	34
2014	9	19	2	1	2	0.748	-0.082	4.17	0.01	0.007	0	44.7	40.9	71.4	138	128	0	34	33
2014	9	19	2	11	2	0.751	-0.066	4.17	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	19	2	21	2	0.735	-0.066	4.173	0.016	0.013	0	44.3	40.9	70.5	137	128	0	34	33
2014	9	19	2	31	2	0.764	-0.102	4.173	0.016	0.013	0	44.3	40.4	71.4	137	128	0	34	34
2014	9	19	2	41	2	0.751	-0.026	4.173	0.01	0.007	0	43.9	40.9	71.4	137	128	0	35	33
2014	9	19	2	51	2	0.774	-0.072	4.173	0.01	0.007	0	44.3	40.9	71.8	137	128	0	34	33
2014	9	19	3	1	2	0.745	-0.102	4.177	0.01	0.007	0	43.9	40.9	71.8	136	128	0	34	33
2014	9	19	3	11	2	0.764	-0.075	4.177	0.01	0.007	0	43.9	40.9	71.4	137	129	0	35	34
2014	9	19	3	21	2	0.758	-0.072	4.177	0.01	0.007	0	43.9	41.3	71	137	129	0	35	33
2014	9	19	3	31	2	0.761	-0.082	4.177	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	19	3	41	2	0.748	-0.082	4.177	0.01	0.007	0	44.3	40.4	71.4	137	128	0	34	34
2014	9	19	3	51	2	0.764	-0.082	4.177	0.013	0.01	0	43.9	40.9	71.8	137	128	0	35	33
2014	9	19	4	1	2	0.781	-0.085	4.177	0.01	0.007	0	44.3	40.4	71.8	137	128	0	34	34
2014	9	19	4	11	2	0.768	-0.066	4.177	0.01	0.007	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	19	4	21	2	0.748	-0.082	4.177	0.01	0.007	0	44.3	40.4	71.8	137	128	0	34	34
2014	9	19	4	31	2	0.758	-0.062	4.177	0.01	0.007	0	44.7	41.3	72.2	139	130	0	35	34
2014	9	19	4	41	2	0.778	-0.105	4.177	0.013	0.01	0	45.2	41.3	70.5	139	129	0	34	33
2014	9	19	4	51	2	0.732	-0.085	4.177	0.016	0.013	0	44.3	40.9	71	138	129	0	35	34
2014	9	19	5	1	2	0.761	-0.062	4.177	0.01	0.007	0	44.3	41.3	71	138	129	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	5	11	2	0.745	-0.072	4.177	0.013	0.01	0	44.3	41.3	72.2	138	129	0	35	33
2014	9	19	5	21	2	0.771	-0.069	4.177	0.01	0.007	0	44.3	41.3	71.8	138	129	0	35	33
2014	9	19	5	31	2	0.761	-0.095	4.177	0.01	0.007	0	45.6	42.6	71.8	141	132	0	35	33
2014	9	19	5	41	2	0.745	-0.075	4.177	0.01	0.007	0	44.7	42.1	68.4	139	131	0	35	33
2014	9	19	5	51	2	0.728	-0.095	4.18	0.01	0.007	0	45.6	43	72.2	141	133	0	35	33
2014	9	19	6	1	2	0.745	-0.069	4.18	0.01	0.007	0	48.2	45.2	71.4	147	138	0	35	33
2014	9	19	6	11	2	0.761	-0.069	4.18	0.013	0.01	0	45.6	42.1	72.2	141	132	0	35	34
2014	9	19	6	21	2	0.745	-0.098	4.18	0.013	0.01	0	45.6	41.7	72.7	140	131	0	34	34
2014	9	19	6	31	2	0.751	-0.079	4.18	0.013	0.01	0	46.9	43.4	72.2	144	135	0	35	34
2014	9	19	6	41	2	0.81	-0.082	4.18	0.01	0.007	0	46.4	43.4	71.4	143	134	0	35	33
2014	9	19	6	51	2	0.771	-0.075	4.18	0.01	0.007	0	46.4	42.6	72.7	142	133	0	34	34
2014	9	19	7	1	2	0.761	-0.079	4.18	0.013	0.01	0	45.6	41.7	72.7	140	131	0	34	34
2014	9	19	7	11	2	0.771	-0.069	4.18	0.016	0.013	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	19	7	21	2	0.774	-0.089	4.18	0.013	0.01	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	19	7	31	2	0.758	-0.095	4.18	0.01	0.007	0	44.3	40.9	73.1	137	128	0	34	33
2014	9	19	7	41	2	0.758	-0.089	4.18	0.013	0.01	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	19	7	51	2	0.735	-0.066	4.18	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	19	8	1	2	0.748	-0.095	4.18	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	9	19	8	11	2	0.778	-0.082	4.18	0.01	0.007	0	43.9	40.9	71.8	137	129	0	35	34
2014	9	19	8	21	2	0.768	-0.066	4.18	0.01	0.007	0	43.9	40.9	70.1	137	129	0	35	34
2014	9	19	8	31	2	0.764	-0.062	4.177	0.013	0.01	0	44.3	40.9	69.2	138	129	0	35	34
2014	9	19	8	41	2	0.755	-0.092	4.177	0.013	0.01	0	44.7	40.9	63.6	138	129	0	34	34
2014	9	19	8	51	2	0.774	-0.056	4.177	0.01	0.007	0	44.7	41.3	57.6	139	130	0	35	34
2014	9	19	9	1	2	0.787	-0.079	4.177	0.01	0.007	0	44.7	40.9	54.2	139	130	0	35	35
2014	9	19	9	11	2	0.751	-0.082	4.177	0.01	0.007	0	45.2	41.7	52.5	140	131	0	35	34
2014	9	19	9	21	2	0.732	-0.043	4.177	0.013	0.01	0	45.6	42.6	54.6	141	133	0	35	34
2014	9	19	9	31	2	0.748	-0.066	4.173	0.013	0.01	0	46	43	56.8	141	133	0	34	33
2014	9	19	9	41	2	0.755	-0.085	4.173	0.01	0.007	0	45.6	42.6	52.5	141	133	0	35	34
2014	9	19	9	51	2	0.745	-0.062	4.173	0.01	0.007	0	46	42.6	52	141	133	0	34	34
2014	9	19	10	1	2	0.774	-0.092	4.17	0.01	0.007	0	46	42.6	52.5	141	133	0	34	34
2014	9	19	10	11	2	0.751	-0.082	4.173	0.016	0.013	0	45.6	42.6	51.6	141	133	0	35	34
2014	9	19	10	21	2	0.768	-0.082	4.17	0.01	0.007	0	46	42.6	52	141	133	0	34	34
2014	9	19	10	31	2	0.771	-0.062	4.167	0.013	0.01	0	45.6	42.6	52	141	132	0	35	33
2014	9	19	10	41	2	0.781	-0.069	4.167	0.01	0.007	0	45.6	43	53.3	141	133	0	35	33
2014	9	19	10	51	2	0.768	-0.066	4.167	0.01	0.007	0	45.2	42.1	53.8	140	132	0	35	34
2014	9	19	11	1	2	0.774	-0.062	4.167	0.01	0.007	0	45.2	42.1	52.9	140	132	0	35	34
2014	9	19	11	11	2	0.784	-0.072	4.163	0.01	0.007	0	45.2	42.1	58	140	132	0	35	34
2014	9	19	11	21	2	0.758	-0.082	4.163	0.01	0.007	0	44.7	41.7	58.5	139	131	0	35	34
2014	9	19	11	31	2	0.758	-0.062	4.16	0.01	0.007	0	44.7	42.1	67.5	139	131	0	35	33
2014	9	19	11	41	2	0.761	-0.092	4.16	0.01	0.007	0	44.7	41.7	67.9	139	131	0	35	34
2014	9	19	11	51	2	0.745	-0.072	4.16	0.01	0.007	0	44.7	42.1	67.1	139	131	0	35	33
2014	9	19	12	1	2	0.751	-0.079	4.16	0.013	0.01	0	44.7	41.3	70.5	138	130	0	34	34
2014	9	19	12	11	2	0.784	-0.095	4.16	0.01	0.007	0	44.3	41.3	71	138	130	0	35	34
2014	9	19	12	21	2	0.755	-0.069	4.16	0.01	0.007	0	44.7	41.7	70.5	139	130	0	35	33
2014	9	19	12	31	2	0.751	-0.095	4.157	0.01	0.007	0	44.7	42.1	69.7	139	131	0	35	33
2014	9	19	12	41	2	0.778	-0.085	4.157	0.013	0.01	0	44.7	41.7	71	139	131	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	12	51	2	0.755	-0.082	4.157	0.01	0.007	0	44.3	41.3	73.1	138	130	0	35	34
2014	9	19	13	1	2	0.761	-0.095	4.157	0.01	0.007	0	43.9	41.3	74	137	129	0	35	33
2014	9	19	13	11	2	0.794	-0.118	4.157	0.013	0.01	0	44.7	41.7	73.5	139	130	0	35	33
2014	9	19	13	21	2	0.764	-0.095	4.157	0.01	0.007	0	44.3	42.1	66.7	138	131	0	35	33
2014	9	19	13	31	2	0.758	-0.062	4.157	0.016	0.016	0	44.7	42.1	72.2	138	131	0	34	33
2014	9	19	13	41	2	0.764	-0.102	4.154	0.013	0.01	0	44.7	41.7	67.9	138	130	0	34	33
2014	9	19	13	51	2	0.791	-0.098	4.154	0.01	0.007	0	44.3	41.7	62.4	138	130	0	35	33
2014	9	19	14	1	2	0.738	-0.082	4.154	0.01	0.007	0	44.7	42.1	66.7	139	131	0	35	33
2014	9	19	14	11	2	0.761	-0.075	4.154	0.013	0.01	0	44.7	42.1	75.3	139	131	0	35	33
2014	9	19	14	21	2	0.748	-0.095	4.154	0.01	0.007	0	44.7	42.1	69.2	139	131	0	35	33
2014	9	19	14	31	2	0.732	-0.085	4.154	0.01	0.007	0	44.7	42.1	72.2	139	131	0	35	33
2014	9	19	14	41	2	0.755	-0.082	4.154	0.016	0.013	0	45.2	42.1	75.7	139	131	0	34	33
2014	9	19	14	51	2	0.761	-0.095	4.154	0.013	0.01	0	45.2	41.7	74.8	139	131	0	34	34
2014	9	19	15	1	2	0.761	-0.144	4.154	0.013	0.01	0	45.2	42.1	75.3	139	131	0	34	33
2014	9	19	15	11	2	0.761	-0.108	4.15	0.016	0.013	0	44.7	41.3	65.8	138	130	0	34	34
2014	9	19	15	21	2	0.784	-0.131	4.15	0.016	0.013	0	44.7	42.1	53.8	138	131	0	34	33
2014	9	19	15	31	2	0.755	-0.095	4.154	0.016	0.013	0	44.7	41.7	59.8	139	131	0	35	34
2014	9	19	15	41	2	0.794	-0.095	4.154	0.01	0.007	0	45.2	41.7	75.3	139	131	0	34	34
2014	9	19	15	51	2	0.758	-0.095	4.15	0.01	0.007	0	43.9	41.3	69.2	137	130	0	35	34
2014	9	19	16	1	2	0.758	-0.105	4.15	0.01	0.007	0	44.3	41.7	70.5	138	130	0	35	33
2014	9	19	16	11	2	0.761	-0.098	4.15	0.013	0.01	0	44.3	41.3	76.1	138	130	0	35	34
2014	9	19	16	21	2	0.745	-0.112	4.15	0.01	0.007	0	45.2	42.1	57.2	139	131	0	34	33
2014	9	19	16	31	2	0.771	-0.112	4.15	0.01	0.007	0	44.3	41.7	74	138	130	0	35	33
2014	9	19	16	41	2	0.745	-0.092	4.15	0.01	0.007	0	44.3	42.1	76.5	138	131	0	35	33
2014	9	19	16	51	2	0.758	-0.112	4.15	0.013	0.01	0	44.3	41.7	74.8	138	130	0	35	33
2014	9	19	17	1	2	0.794	-0.128	4.15	0.01	0.007	0	44.3	41.7	75.7	138	130	0	35	33
2014	9	19	17	11	2	0.758	-0.079	4.15	0.01	0.007	0	44.7	41.3	74.4	138	130	0	34	34
2014	9	19	17	21	2	0.741	-0.128	4.15	0.01	0.007	0	43.9	40.9	64.1	137	129	0	35	34
2014	9	19	17	31	2	0.781	-0.069	4.15	0.013	0.01	0	44.3	41.3	75.7	137	129	0	34	33
2014	9	19	17	41	2	0.774	-0.098	4.15	0.013	0.01	0	43.9	40.9	74.4	137	129	0	35	34
2014	9	19	17	51	2	0.755	-0.085	4.15	0.01	0.007	0	44.3	41.3	75.7	138	130	0	35	34
2014	9	19	18	1	2	0.761	-0.046	4.15	0.013	0.01	0	44.7	41.3	75.7	138	129	0	34	33
2014	9	19	18	11	2	0.755	-0.075	4.15	0.016	0.013	0	43.9	40.9	74.4	137	129	0	35	34
2014	9	19	18	21	2	0.794	-0.085	4.15	0.016	0.013	0	44.3	41.3	75.3	138	130	0	35	34
2014	9	19	18	31	2	0.748	-0.075	4.15	0.01	0.007	0	44.3	41.3	75.7	138	130	0	35	34
2014	9	19	18	41	2	0.774	-0.066	4.15	0.013	0.01	0	44.7	41.7	75.3	138	130	0	34	33
2014	9	19	18	51	2	0.758	-0.112	4.15	0.013	0.01	0	44.7	40.9	75.3	138	129	0	34	34
2014	9	19	19	1	2	0.745	-0.095	4.15	0.01	0.007	0	44.3	41.3	75.7	138	130	0	35	34
2014	9	19	19	11	2	0.761	-0.092	4.15	0.01	0.007	0	44.3	40.9	63.6	138	129	0	35	34
2014	9	19	19	21	2	0.758	-0.072	4.154	0.01	0.007	0	45.2	41.3	53.8	139	130	0	34	34
2014	9	19	19	31	2	0.794	-0.075	4.15	0.01	0.007	0	44.7	42.1	55.5	139	131	0	35	33
2014	9	19	19	41	2	0.771	-0.118	4.15	0.01	0.007	0	44.3	41.7	61.9	138	130	0	35	33
2014	9	19	19	51	2	0.761	-0.089	4.15	0.013	0.01	0	44.7	42.1	67.9	139	131	0	35	33
2014	9	19	20	1	2	0.764	-0.102	4.15	0.01	0.007	0	45.2	42.6	71	140	132	0	35	33
2014	9	19	20	11	2	0.735	-0.089	4.154	0.01	0.007	0	44.7	42.1	74.8	139	131	0	35	33
2014	9	19	20	21	2	0.781	-0.092	4.154	0.01	0.007	0	45.2	42.6	71	140	132	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	20	31	2	0.745	-0.098	4.154	0.01	0.007	0	44.7	41.3	73.5	139	130	0	35	34
2014	9	19	20	41	2	0.781	-0.069	4.154	0.01	0.007	0	45.2	41.7	72.2	139	131	0	34	34
2014	9	19	20	51	2	0.764	-0.082	4.154	0.01	0.007	0	44.7	42.1	74	139	131	0	35	33
2014	9	19	21	1	2	0.778	-0.059	4.154	0.01	0.007	0	44.7	41.7	73.1	139	131	0	35	34
2014	9	19	21	11	2	0.761	-0.072	4.154	0.01	0.007	0	44.7	41.7	73.5	139	131	0	35	34
2014	9	19	21	21	2	0.758	-0.066	4.154	0.01	0.007	0	44.3	41.7	74	138	130	0	35	33
2014	9	19	21	31	2	0.774	-0.072	4.154	0.01	0.007	0	44.7	41.7	74.4	139	131	0	35	34
2014	9	19	21	41	2	0.755	-0.085	4.154	0.01	0.007	0	44.7	42.1	74	139	131	0	35	33
2014	9	19	21	51	2	0.784	-0.079	4.154	0.013	0.01	0	44.3	40.9	74.4	138	129	0	35	34
2014	9	19	22	1	2	0.738	-0.085	4.154	0.013	0.01	0	44.3	41.3	74	138	130	0	35	34
2014	9	19	22	11	2	0.768	-0.066	4.154	0.01	0.007	0	44.3	41.7	74	138	130	0	35	33
2014	9	19	22	21	2	0.728	-0.098	4.154	0.01	0.007	0	44.7	41.7	74.4	138	130	0	34	33
2014	9	19	22	31	2	0.755	-0.052	4.154	0.01	0.007	0	44.7	41.7	74	138	130	0	34	33
2014	9	19	22	41	2	0.774	-0.082	4.154	0.01	0.007	0	44.7	41.3	74.4	138	130	0	34	34
2014	9	19	22	51	2	0.745	-0.059	4.154	0.01	0.007	0	44.3	41.3	73.5	138	130	0	35	34
2014	9	19	23	1	2	0.778	-0.095	4.154	0.013	0.01	0	44.7	40.9	73.5	138	129	0	34	34
2014	9	19	23	11	2	0.751	-0.095	4.157	0.01	0.007	0	43.9	40.9	73.1	137	129	0	35	34
2014	9	19	23	21	2	0.761	-0.089	4.154	0.01	0.007	0	44.3	41.3	73.5	138	130	0	35	34
2014	9	19	23	31	2	0.761	-0.072	4.157	0.01	0.007	0	44.7	41.3	74	138	130	0	34	34
2014	9	19	23	41	2	0.745	-0.066	4.157	0.01	0.007	0	44.3	41.7	74	138	130	0	35	33
2014	9	19	23	51	2	0.778	-0.066	4.157	0.013	0.01	0	44.3	41.3	74	138	129	0	35	33
2014	9	20	0	1	2	0.735	-0.066	4.157	0.01	0.007	0	44.7	42.1	73.1	139	131	0	35	33
2014	9	20	0	11	2	0.774	-0.098	4.157	0.013	0.01	0	43.9	40.9	73.5	137	129	0	35	34
2014	9	20	0	21	2	0.784	-0.089	4.157	0.013	0.01	0	43.9	41.3	73.1	137	129	0	35	33
2014	9	20	0	31	2	0.732	-0.066	4.157	0.016	0.013	0	44.3	41.7	73.1	138	130	0	35	33
2014	9	20	0	41	2	0.745	-0.089	4.157	0.013	0.01	0	44.3	41.3	72.7	138	130	0	35	34
2014	9	20	0	51	2	0.781	-0.092	4.157	0.01	0.007	0	43.4	40.9	73.1	136	128	0	35	33
2014	9	20	1	1	2	0.755	-0.092	4.157	0.013	0.01	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	20	1	11	2	0.778	-0.075	4.157	0.01	0.007	0	43.4	40.9	72.7	136	129	0	35	34
2014	9	20	1	21	2	0.745	-0.082	4.157	0.01	0.007	0	43.9	41.3	71.8	137	129	0	35	33
2014	9	20	1	31	2	0.745	-0.075	4.157	0.01	0.007	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	20	1	41	2	0.771	-0.082	4.157	0.01	0.007	0	43.9	41.3	72.7	137	129	0	35	33
2014	9	20	1	51	2	0.758	-0.062	4.157	0.016	0.013	0	43.4	40.9	69.2	136	128	0	35	33
2014	9	20	2	1	2	0.774	-0.079	4.157	0.013	0.01	0	44.3	40.9	72.7	137	129	0	34	34
2014	9	20	2	11	2	0.761	-0.059	4.157	0.01	0.007	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	20	2	21	2	0.761	-0.066	4.157	0.01	0.007	0	43.9	40.9	72.7	137	129	0	35	34
2014	9	20	2	31	2	0.741	-0.102	4.157	0.01	0.007	0	44.7	40.9	71	138	129	0	34	34
2014	9	20	2	41	2	0.768	-0.095	4.157	0.013	0.01	0	43.9	40.9	68.4	137	129	0	35	34
2014	9	20	2	51	2	0.764	-0.092	4.157	0.016	0.013	0	43.9	40.9	72.2	137	129	0	35	34
2014	9	20	3	1	2	0.758	-0.102	4.157	0.016	0.013	0	43.9	41.3	72.2	137	130	0	35	34
2014	9	20	3	11	2	0.764	-0.102	4.16	0.013	0.01	0	43.9	40.9	71.8	137	129	0	35	34
2014	9	20	3	21	2	0.735	-0.072	4.16	0.013	0.01	0	44.7	40.9	70.1	138	130	0	34	35
2014	9	20	3	31	2	0.755	-0.098	4.157	0.01	0.007	0	43.9	41.3	71.4	137	129	0	35	33
2014	9	20	3	41	2	0.745	-0.095	4.16	0.013	0.01	0	44.3	41.3	71.8	138	130	0	35	34
2014	9	20	3	51	2	0.787	-0.059	4.16	0.01	0.007	0	43.9	40.9	71	137	129	0	35	34
2014	9	20	4	1	2	0.781	-0.102	4.16	0.01	0.007	0	43.9	40.9	71.4	137	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	4	11	2	0.761	-0.062	4.16	0.01	0.007	0	44.3	40.9	71.8	137	129	0	34	34
2014	9	20	4	21	2	0.741	-0.089	4.16	0.01	0.007	0	43.9	40.9	71	136	129	0	34	34
2014	9	20	4	31	2	0.741	-0.085	4.16	0.01	0.007	0	43.9	40.9	69.7	137	129	0	35	34
2014	9	20	4	41	2	0.745	-0.062	4.163	0.016	0.013	0	44.7	41.7	71	138	130	0	34	33
2014	9	20	4	51	2	0.751	-0.082	4.167	0.01	0.007	0	43.9	41.3	71	137	129	0	35	33
2014	9	20	5	1	2	0.771	-0.082	4.17	0.013	0.01	0	43.9	40.9	71.4	137	129	0	35	34
2014	9	20	5	11	2	0.761	-0.105	4.17	0.01	0.007	0	45.2	41.7	71.4	139	130	0	34	33
2014	9	20	5	21	2	0.741	-0.075	4.17	0.01	0.007	0	44.3	41.7	71.4	137	130	0	34	33
2014	9	20	5	31	2	0.771	-0.095	4.173	0.013	0.01	0	44.3	40.9	72.2	137	129	0	34	34
2014	9	20	5	41	2	0.761	-0.079	4.173	0.013	0.01	0	44.3	41.7	73.1	138	130	0	35	33
2014	9	20	5	51	2	0.755	-0.079	4.173	0.01	0.007	0	44.7	42.1	72.2	139	131	0	35	33
2014	9	20	6	1	2	0.787	-0.121	4.173	0.013	0.01	0	44.3	41.3	65.8	138	129	0	35	33
2014	9	20	6	11	2	0.771	-0.069	4.173	0.016	0.013	0	44.3	41.3	73.1	138	130	0	35	34
2014	9	20	6	21	2	0.758	-0.092	4.173	0.01	0.007	0	45.2	41.7	73.5	140	131	0	35	34
2014	9	20	6	31	2	0.732	-0.075	4.177	0.01	0.007	0	46.9	44.3	73.1	143	136	0	34	33
2014	9	20	6	41	2	0.755	-0.072	4.173	0.01	0.007	0	46	42.6	73.5	142	133	0	35	34
2014	9	20	6	51	2	0.794	-0.089	4.177	0.013	0.01	0	44.7	42.1	73.5	139	131	0	35	33
2014	9	20	7	1	2	0.751	-0.062	4.177	0.013	0.01	0	44.7	41.7	74.4	139	131	0	35	34
2014	9	20	7	11	2	0.722	-0.089	4.177	0.016	0.016	0	44.3	41.7	74.4	138	130	0	35	33
2014	9	20	7	21	2	0.801	-0.079	4.177	0.01	0.007	0	43.9	40.4	74.8	137	128	0	35	34
2014	9	20	7	31	2	0.761	-0.095	4.177	0.013	0.01	0	43.9	40.9	75.7	137	129	0	35	34
2014	9	20	7	41	2	0.781	-0.098	4.177	0.01	0.007	0	44.3	41.3	75.3	137	129	0	34	33
2014	9	20	7	51	2	0.751	-0.082	4.177	0.01	0.007	0	43.4	40.4	75.3	136	128	0	35	34
2014	9	20	8	1	2	0.768	-0.079	4.177	0.016	0.013	0	43.4	40.4	75.3	136	128	0	35	34
2014	9	20	8	11	2	0.797	-0.069	4.177	0.01	0.007	0	43.4	40.4	75.3	136	128	0	35	34
2014	9	20	8	21	2	0.761	-0.072	4.177	0.013	0.01	0	43.4	40.4	76.1	136	128	0	35	34
2014	9	20	8	31	2	0.761	-0.082	4.177	0.01	0.007	0	43.4	40.9	75.7	136	128	0	35	33
2014	9	20	8	41	2	0.761	-0.072	4.177	0.013	0.01	0	43.4	40	74.8	136	127	0	35	34
2014	9	20	8	51	2	0.758	-0.108	4.173	0.016	0.013	0	44.7	40.9	75.3	138	129	0	34	34
2014	9	20	9	1	2	0.801	-0.112	4.177	0.016	0.013	0	44.3	40.9	74.8	138	129	0	35	34
2014	9	20	9	11	2	0.768	-0.089	4.177	0.01	0.007	0	44.3	41.3	75.3	138	129	0	35	33
2014	9	20	9	21	2	0.761	-0.089	4.177	0.013	0.01	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	20	9	31	2	0.774	-0.085	4.173	0.01	0.007	0	44.7	40.9	74.8	138	129	0	34	34
2014	9	20	9	41	2	0.784	-0.066	4.177	0.01	0.007	0	44.3	41.3	75.7	138	129	0	35	33
2014	9	20	9	51	2	0.735	-0.112	4.177	0.01	0.007	0	43.9	40.9	75.7	138	129	0	36	34
2014	9	20	10	1	2	0.764	-0.085	4.173	0.01	0.007	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	20	10	11	2	0.771	-0.098	4.173	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	20	10	21	2	0.787	-0.072	4.173	0.013	0.01	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	20	10	31	2	0.761	-0.089	4.173	0.01	0.007	0	44.7	41.3	73.1	139	130	0	35	34
2014	9	20	10	41	2	0.751	-0.115	4.173	0.016	0.016	0	43.9	40.4	74	137	128	0	35	34
2014	9	20	10	51	2	0.771	-0.075	4.173	0.01	0.007	0	43.9	40.9	70.5	137	128	0	35	33
2014	9	20	11	1	2	0.745	-0.112	4.173	0.01	0.007	0	43	40	73.5	135	127	0	35	34
2014	9	20	11	11	2	0.758	-0.151	4.17	0.01	0.007	0	43.4	40	69.2	136	127	0	35	34
2014	9	20	11	21	2	0.768	-0.135	4.17	0.013	0.01	0	43.4	40	69.7	136	127	0	35	34
2014	9	20	11	31	2	0.768	-0.095	4.17	0.01	0.007	0	43.9	40.4	64.9	137	128	0	35	34
2014	9	20	11	41	2	0.761	-0.128	4.17	0.013	0.01	0	43.4	40.4	67.5	136	127	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	11	51	2	0.758	-0.144	4.17	0.013	0.01	0	43.9	40.4	73.5	136	128	0	34	34
2014	9	20	12	1	2	0.774	-0.135	4.17	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	20	12	11	2	0.787	-0.128	4.17	0.01	0.007	0	44.7	40.4	72.2	138	128	0	34	34
2014	9	20	12	21	2	0.745	-0.112	4.17	0.01	0.007	0	44.7	41.3	71.8	139	130	0	35	34
2014	9	20	12	31	2	0.764	-0.128	4.167	0.01	0.007	0	44.3	40.9	72.2	137	129	0	34	34
2014	9	20	12	41	2	0.771	-0.098	4.167	0.01	0.007	0	44.7	41.3	72.2	139	130	0	35	34
2014	9	20	12	51	2	0.758	-0.102	4.163	0.01	0.007	0	44.3	40.9	52.9	138	129	0	35	34
2014	9	20	13	1	2	0.764	-0.118	4.16	0.01	0.007	0	44.3	40.9	56.8	138	129	0	35	34
2014	9	20	13	11	2	0.758	-0.128	4.163	0.01	0.007	0	43.9	40.4	52.9	137	128	0	35	34
2014	9	20	13	21	2	0.784	-0.151	4.16	0.01	0.007	0	43.9	41.3	65.4	137	129	0	35	33
2014	9	20	13	31	2	0.768	-0.105	4.157	0.01	0.007	0	43.9	41.3	52.5	137	129	0	35	33
2014	9	20	13	41	2	0.761	-0.128	4.16	0.013	0.01	0	43.9	40	52	137	127	0	35	34
2014	9	20	13	51	2	0.774	-0.141	4.157	0.013	0.01	0	44.7	40.9	65.8	138	129	0	34	34
2014	9	20	14	1	2	0.787	-0.089	4.157	0.01	0.007	0	44.7	41.3	72.2	139	129	0	35	33
2014	9	20	14	11	2	0.778	-0.121	4.157	0.013	0.01	0	44.3	40.9	63.2	138	129	0	35	34
2014	9	20	14	21	2	0.768	-0.118	4.157	0.013	0.01	0	44.3	40.9	52	138	129	0	35	34
2014	9	20	14	31	2	0.791	-0.112	4.154	0.01	0.007	0	44.7	41.3	61.9	139	130	0	35	34
2014	9	20	14	41	2	0.761	-0.128	4.154	0.01	0.007	0	44.3	41.3	68.4	138	129	0	35	33
2014	9	20	14	51	2	0.768	-0.121	4.154	0.01	0.007	0	43.9	40.9	62.4	137	129	0	35	34
2014	9	20	15	1	2	0.751	-0.128	4.157	0.01	0.007	0	44.3	41.3	52.5	137	129	0	34	33
2014	9	20	15	11	2	0.748	-0.135	4.154	0.01	0.007	0	43.9	41.3	61.5	137	129	0	35	33
2014	9	20	15	21	2	0.784	-0.131	4.154	0.01	0.007	0	44.3	41.3	61.1	138	130	0	35	34
2014	9	20	15	31	2	0.791	-0.108	4.157	0.013	0.01	0	44.7	41.3	52.9	138	129	0	34	33
2014	9	20	15	41	2	0.778	-0.112	4.154	0.01	0.007	0	44.3	41.3	67.1	137	129	0	34	33
2014	9	20	15	51	2	0.771	-0.138	4.154	0.01	0.007	0	44.3	41.3	52.9	138	129	0	35	33
2014	9	20	16	1	2	0.764	-0.151	4.15	0.01	0.007	0	43.9	40.9	59.3	137	129	0	35	34
2014	9	20	16	11	2	0.771	-0.079	4.154	0.013	0.01	0	44.7	41.3	56.8	139	130	0	35	34
2014	9	20	16	21	2	0.748	-0.118	4.15	0.013	0.01	0	44.7	41.3	61.1	139	130	0	35	34
2014	9	20	16	31	2	0.771	-0.112	4.154	0.01	0.007	0	44.3	40.9	62.4	138	129	0	35	34
2014	9	20	16	41	2	0.768	-0.138	4.15	0.01	0.007	0	43.9	40.4	55	137	128	0	35	34
2014	9	20	16	51	2	0.741	-0.112	4.15	0.01	0.007	0	44.7	41.3	59.3	138	129	0	34	33
2014	9	20	17	1	2	0.768	-0.118	4.154	0.013	0.01	0	43.9	40.4	53.8	137	128	0	35	34
2014	9	20	17	11	2	0.774	-0.095	4.15	0.01	0.007	0	43.9	40.4	57.6	137	128	0	35	34
2014	9	20	17	21	2	0.801	-0.105	4.154	0.01	0.007	0	43.9	40.9	70.5	137	128	0	35	33
2014	9	20	17	31	2	0.771	-0.095	4.154	0.016	0.013	0	43.9	40.4	71.4	137	128	0	35	34
2014	9	20	17	41	2	0.791	-0.108	4.154	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	20	17	51	2	0.787	-0.121	4.154	0.01	0.007	0	43.4	40.4	72.7	136	127	0	35	33
2014	9	20	18	1	2	0.761	-0.098	4.154	0.013	0.01	0	43.9	40.4	73.5	137	128	0	35	34
2014	9	20	18	11	2	0.768	-0.072	4.15	0.01	0.007	0	44.3	40.9	61.1	138	129	0	35	34
2014	9	20	18	21	2	0.745	-0.082	4.154	0.01	0.007	0	44.3	40.9	56.3	138	129	0	35	34
2014	9	20	18	31	2	0.745	-0.072	4.154	0.01	0.007	0	44.7	41.3	55.9	139	130	0	35	34
2014	9	20	18	41	2	0.738	-0.121	4.154	0.01	0.007	0	44.7	41.3	66.7	139	130	0	35	34
2014	9	20	18	51	2	0.774	-0.059	4.154	0.013	0.01	0	45.2	41.3	57.2	140	130	0	35	34
2014	9	20	19	1	2	0.758	-0.112	4.154	0.013	0.01	0	44.7	41.7	64.5	139	130	0	35	33
2014	9	20	19	11	2	0.748	-0.075	4.154	0.01	0.007	0	45.2	41.3	65.4	140	130	0	35	34
2014	9	20	19	21	2	0.751	-0.082	4.154	0.01	0.007	0	46	42.6	64.9	142	132	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	19	31	2	0.755	-0.066	4.154	0.01	0.007	0	46	41.7	71.8	141	131	0	34	34
2014	9	20	19	41	2	0.764	-0.102	4.157	0.013	0.01	0	44.7	41.3	50.7	139	130	0	35	34
2014	9	20	19	51	2	0.758	-0.059	4.157	0.013	0.01	0	46.4	42.6	51.2	142	133	0	34	34
2014	9	20	20	1	2	0.761	-0.098	4.157	0.01	0.007	0	44.7	41.3	49.5	139	130	0	35	34
2014	9	20	20	11	2	0.755	-0.148	4.157	0.013	0.01	0	43.9	40.9	49.9	137	128	0	35	33
2014	9	20	20	21	2	0.784	-0.082	4.157	0.01	0.007	0	46.9	43	51.2	144	134	0	35	34
2014	9	20	20	31	2	0.758	-0.082	4.154	0.013	0.01	0	48.6	45.2	56.8	148	139	0	35	34
2014	9	20	20	41	2	0.761	-0.095	4.157	0.013	0.01	0	48.6	45.2	54.6	148	138	0	35	33
2014	9	20	20	51	2	0.771	-0.112	4.157	0.013	0.01	0	47.7	44.3	70.5	146	136	0	35	33
2014	9	20	21	1	2	0.748	-0.085	4.16	0.01	0.007	0	47.3	43.9	69.7	145	136	0	35	34
2014	9	20	21	11	2	0.745	-0.066	4.16	0.01	0.007	0	46	42.6	63.6	142	133	0	35	34
2014	9	20	21	21	2	0.751	-0.082	4.16	0.01	0.007	0	46	42.6	65.8	142	133	0	35	34
2014	9	20	21	31	2	0.751	-0.082	4.16	0.013	0.01	0	46	42.1	62.4	142	132	0	35	34
2014	9	20	21	41	2	0.758	-0.056	4.163	0.01	0.007	0	45.6	42.6	70.1	141	132	0	35	33
2014	9	20	21	51	2	0.784	-0.112	4.163	0.01	0.007	0	46	42.1	71	141	132	0	34	34
2014	9	20	22	1	2	0.771	-0.079	4.163	0.01	0.007	0	45.2	41.3	67.1	140	130	0	35	34
2014	9	20	22	11	2	0.751	-0.095	4.167	0.01	0.007	0	45.6	41.7	70.1	141	131	0	35	34
2014	9	20	22	21	2	0.738	-0.112	4.163	0.01	0.007	0	45.6	41.7	56.8	141	131	0	35	34
2014	9	20	22	31	2	0.755	-0.085	4.167	0.016	0.013	0	45.6	41.7	71.4	141	131	0	35	34
2014	9	20	22	41	2	0.758	-0.085	4.167	0.01	0.007	0	45.6	42.1	72.2	141	131	0	35	33
2014	9	20	22	51	2	0.751	-0.092	4.167	0.01	0.007	0	46	42.1	71.8	141	132	0	34	34
2014	9	20	23	1	2	0.761	-0.115	4.167	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	20	23	11	2	0.787	-0.092	4.163	0.01	0.007	0	45.6	42.1	58	141	131	0	35	33
2014	9	20	23	21	2	0.755	-0.082	4.163	0.01	0.007	0	44.3	40.4	57.2	137	128	0	34	34
2014	9	20	23	31	2	0.771	-0.108	4.17	0.013	0.01	0	44.7	40.9	73.1	138	129	0	34	34
2014	9	20	23	41	2	0.748	-0.059	4.17	0.01	0.007	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	20	23	51	2	0.761	-0.112	4.17	0.01	0.007	0	45.2	41.7	72.7	140	131	0	35	34
2014	9	21	0	1	2	0.774	-0.092	4.17	0.013	0.01	0	44.7	41.3	72.7	139	130	0	35	34
2014	9	21	0	11	2	0.764	-0.059	4.17	0.01	0.007	0	44.3	40.9	72.2	138	129	0	35	34
2014	9	21	0	21	2	0.741	-0.066	4.17	0.01	0.007	0	45.2	41.7	72.7	140	131	0	35	34
2014	9	21	0	31	2	0.758	-0.062	4.17	0.01	0.007	0	45.2	41.7	73.5	140	131	0	35	34
2014	9	21	0	41	2	0.774	-0.102	4.173	0.013	0.01	0	44.7	41.7	73.5	139	130	0	35	33
2014	9	21	0	51	2	0.778	-0.072	4.173	0.013	0.01	0	44.7	41.3	73.5	138	129	0	34	33
2014	9	21	1	1	2	0.738	-0.069	4.173	0.01	0.007	0	44.3	41.3	74	138	129	0	35	33
2014	9	21	1	11	2	0.768	-0.105	4.173	0.01	0.007	0	44.3	40.9	74	138	129	0	35	34
2014	9	21	1	21	2	0.758	-0.049	4.173	0.013	0.01	0	44.7	40.9	74	139	129	0	35	34
2014	9	21	1	31	2	0.761	-0.098	4.173	0.01	0.007	0	44.3	40.9	74	138	129	0	35	34
2014	9	21	1	41	2	0.748	-0.052	4.173	0.01	0.007	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	21	1	51	2	0.738	-0.079	4.173	0.013	0.01	0	44.7	41.3	70.1	139	130	0	35	34
2014	9	21	2	1	2	0.771	-0.085	4.173	0.01	0.007	0	44.7	41.7	68.8	139	131	0	35	34
2014	9	21	2	11	2	0.755	-0.075	4.173	0.01	0.007	0	44.7	41.3	61.1	139	130	0	35	34
2014	9	21	2	21	2	0.768	-0.095	4.173	0.01	0.007	0	44.7	41.3	55.9	139	129	0	35	33
2014	9	21	2	31	2	0.774	-0.069	4.173	0.01	0.007	0	45.2	41.7	72.2	140	130	0	35	33
2014	9	21	2	41	2	0.761	-0.121	4.173	0.013	0.01	0	44.3	41.3	65.4	139	130	0	36	34
2014	9	21	2	51	2	0.778	-0.112	4.173	0.01	0.007	0	44.3	40.9	71	138	129	0	35	34
2014	9	21	3	1	2	0.761	-0.072	4.177	0.016	0.013	0	44.3	41.3	58.5	138	130	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	3	11	2	0.768	-0.115	4.177	0.013	0.01	0	44.3	40.9	73.1	138	129	0	35	34
2014	9	21	3	21	2	0.771	-0.089	4.177	0.01	0.007	0	44.7	41.7	74	139	130	0	35	33
2014	9	21	3	31	2	0.755	-0.095	4.177	0.013	0.01	0	44.3	40.9	74	138	129	0	35	34
2014	9	21	3	41	2	0.761	-0.072	4.177	0.01	0.007	0	44.7	41.3	74	138	129	0	34	33
2014	9	21	3	51	2	0.758	-0.085	4.177	0.013	0.01	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	21	4	1	2	0.751	-0.079	4.177	0.013	0.01	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	21	4	11	2	0.781	-0.079	4.177	0.01	0.007	0	44.3	40.9	74.4	138	129	0	35	34
2014	9	21	4	21	2	0.787	-0.085	4.177	0.01	0.007	0	44.3	40.9	74.4	138	129	0	35	34
2014	9	21	4	31	2	0.761	-0.098	4.177	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	21	4	41	2	0.755	-0.105	4.177	0.013	0.01	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	21	4	51	2	0.738	-0.072	4.177	0.01	0.007	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	21	5	1	2	0.771	-0.121	4.177	0.016	0.016	0	43.9	40.9	74.8	137	128	0	35	33
2014	9	21	5	11	2	0.774	-0.059	4.177	0.01	0.007	0	44.7	41.7	75.3	139	130	0	35	33
2014	9	21	5	21	2	0.745	-0.089	4.177	0.01	0.007	0	44.7	41.7	75.3	139	130	0	35	33
2014	9	21	5	31	2	0.784	-0.062	4.177	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	21	5	41	2	0.755	-0.069	4.177	0.01	0.007	0	44.3	41.7	73.1	139	130	0	36	33
2014	9	21	5	51	2	0.781	-0.118	4.177	0.013	0.01	0	44.7	41.7	76.1	138	130	0	34	33
2014	9	21	6	1	2	0.768	-0.092	4.177	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	21	6	11	2	0.764	-0.092	4.177	0.01	0.007	0	46.4	42.6	75.7	143	133	0	35	34
2014	9	21	6	21	2	0.774	-0.102	4.177	0.013	0.01	0	46.9	43.4	75.3	144	135	0	35	34
2014	9	21	6	31	2	0.761	-0.089	4.177	0.01	0.007	0	46.4	43	74.4	143	134	0	35	34
2014	9	21	6	41	2	0.764	-0.079	4.18	0.01	0.007	0	46.4	42.6	74.8	143	133	0	35	34
2014	9	21	6	51	2	0.781	-0.069	4.177	0.01	0.007	0	45.2	42.1	75.3	140	131	0	35	33
2014	9	21	7	1	2	0.755	-0.095	4.177	0.01	0.007	0	44.7	41.3	75.7	139	130	0	35	34
2014	9	21	7	11	2	0.768	-0.108	4.177	0.01	0.007	0	44.3	40.9	75.7	138	129	0	35	34
2014	9	21	7	21	2	0.781	-0.069	4.18	0.01	0.007	0	43.9	40.4	76.1	137	128	0	35	34
2014	9	21	7	31	2	0.735	-0.049	4.177	0.013	0.01	0	44.3	40.9	75.3	138	129	0	35	34
2014	9	21	7	41	2	0.771	-0.059	4.177	0.01	0.007	0	43.4	40	75.7	136	127	0	35	34
2014	9	21	7	51	2	0.755	-0.089	4.18	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34
2014	9	21	8	1	2	0.768	-0.062	4.177	0.01	0.007	0	43.4	40	77	136	127	0	35	34
2014	9	21	8	11	2	0.768	-0.049	4.177	0.01	0.007	0	43	39.6	76.1	135	126	0	35	34
2014	9	21	8	21	2	0.705	-0.082	4.177	0.01	0.007	0	43.4	39.6	77	135	126	0	34	34
2014	9	21	8	31	2	0.748	-0.069	4.177	0.01	0.007	0	43.4	39.6	76.5	135	126	0	34	34
2014	9	21	8	41	2	0.768	-0.112	4.177	0.01	0.007	0	43	40	76.5	135	127	0	35	34
2014	9	21	8	51	2	0.755	-0.098	4.177	0.01	0.007	0	43.4	40	76.1	136	127	0	35	34
2014	9	21	9	1	2	0.751	-0.082	4.177	0.013	0.01	0	43	40	76.5	135	126	0	35	33
2014	9	21	9	11	2	0.764	-0.102	4.177	0.016	0.013	0	43	40	76.5	135	127	0	35	34
2014	9	21	9	21	2	0.764	-0.118	4.177	0.01	0.007	0	43	40.4	74.8	135	127	0	35	33
2014	9	21	9	31	2	0.781	-0.118	4.177	0.01	0.007	0	43	40	75.7	135	127	0	35	34
2014	9	21	9	41	2	0.751	-0.125	4.177	0.016	0.013	0	43	40	72.7	135	127	0	35	34
2014	9	21	9	51	2	0.771	-0.112	4.177	0.013	0.01	0	43.4	39.6	63.2	136	126	0	35	34
2014	9	21	10	1	2	0.774	-0.085	4.177	0.01	0.007	0	43.9	40	60.6	137	127	0	35	34
2014	9	21	10	11	2	0.771	-0.089	4.177	0.01	0.007	0	43.9	40	71.8	137	127	0	35	34
2014	9	21	10	21	2	0.764	-0.092	4.177	0.01	0.007	0	43.9	40.4	74.8	137	127	0	35	33
2014	9	21	10	31	2	0.768	-0.128	4.177	0.01	0.007	0	43.4	40.4	75.3	136	127	0	35	33
2014	9	21	10	41	2	0.761	-0.072	4.177	0.01	0.007	0	43.9	40.4	75.3	137	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	10	51	2	0.755	-0.098	4.177	0.01	0.007	0	43.9	40.4	74.8	137	127	0	35	33
2014	9	21	11	1	2	0.761	-0.095	4.177	0.013	0.01	0	43.9	39.6	74.4	137	127	0	35	35
2014	9	21	11	11	2	0.787	-0.085	4.177	0.01	0.007	0	44.3	40.4	75.7	137	128	0	34	34
2014	9	21	11	21	2	0.751	-0.102	4.177	0.01	0.007	0	44.3	40.4	75.7	138	128	0	35	34
2014	9	21	11	31	2	0.774	-0.079	4.177	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	21	11	41	2	0.771	-0.112	4.177	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	21	11	51	2	0.761	-0.161	4.173	0.013	0.01	0	42.6	39.1	68.8	134	125	0	35	34
2014	9	21	12	1	2	0.761	-0.128	4.173	0.01	0.007	0	43.4	40	73.1	136	127	0	35	34
2014	9	21	12	11	2	0.755	-0.115	4.173	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	21	12	21	2	0.771	-0.138	4.173	0.013	0.01	0	43.4	40	74.4	136	127	0	35	34
2014	9	21	12	31	2	0.764	-0.095	4.173	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	21	12	41	2	0.784	-0.144	4.173	0.01	0.007	0	43	39.6	73.5	135	126	0	35	34
2014	9	21	12	51	2	0.781	-0.092	4.173	0.01	0.007	0	43.4	40	75.3	136	127	0	35	34
2014	9	21	13	1	2	0.778	-0.128	4.17	0.01	0.007	0	43.9	40	66.2	136	127	0	34	34
2014	9	21	13	11	2	0.801	-0.115	4.17	0.01	0.007	0	43.9	40	67.1	137	127	0	35	34
2014	9	21	13	21	2	0.778	-0.148	4.167	0.013	0.01	0	43.4	39.6	56.8	135	126	0	34	34
2014	9	21	13	31	2	0.768	-0.112	4.17	0.01	0.007	0	44.3	40	61.9	137	127	0	34	34
2014	9	21	13	41	2	0.751	-0.112	4.17	0.01	0.007	0	43.9	40	72.7	137	127	0	35	34
2014	9	21	13	51	2	0.764	-0.144	4.167	0.01	0.007	0	43.4	40	56.8	136	127	0	35	34
2014	9	21	14	1	2	0.764	-0.118	4.167	0.01	0.007	0	43.9	40.9	52	137	128	0	35	33
2014	9	21	14	11	2	0.738	-0.115	4.167	0.01	0.007	0	43.9	40.4	60.2	137	128	0	35	34
2014	9	21	14	21	2	0.778	-0.112	4.167	0.01	0.007	0	43.9	40.4	60.2	137	128	0	35	34
2014	9	21	14	31	2	0.781	-0.128	4.167	0.016	0.016	0	43.9	40	51.2	137	127	0	35	34
2014	9	21	14	41	2	0.771	-0.112	4.167	0.013	0.01	0	43.4	40.4	66.7	136	127	0	35	33
2014	9	21	14	51	2	0.764	-0.161	4.167	0.01	0.007	0	43.9	40	60.6	136	127	0	34	34
2014	9	21	15	1	2	0.771	-0.138	4.163	0.01	0.007	0	43.9	40.9	56.8	137	128	0	35	33
2014	9	21	15	11	2	0.751	-0.151	4.167	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	21	15	21	2	0.801	-0.125	4.163	0.01	0.007	0	43.9	40.9	64.1	137	128	0	35	33
2014	9	21	15	31	2	0.768	-0.085	4.16	0.01	0.007	0	44.7	41.3	64.5	139	130	0	35	34
2014	9	21	15	41	2	0.81	-0.079	4.163	0.013	0.01	0	44.3	41.7	63.2	139	130	0	36	33
2014	9	21	15	51	2	0.787	-0.121	4.163	0.01	0.007	0	44.7	41.3	60.2	138	129	0	34	33
2014	9	21	16	1	2	0.748	-0.125	4.163	0.01	0.007	0	43.9	40.9	57.2	137	128	0	35	33
2014	9	21	16	11	2	0.751	-0.128	4.163	0.013	0.01	0	44.3	41.3	54.2	138	129	0	35	33
2014	9	21	16	21	2	0.764	-0.157	4.163	0.01	0.007	0	43.9	40	59.8	137	127	0	35	34
2014	9	21	16	31	2	0.764	-0.141	4.163	0.013	0.01	0	43.4	40	52	136	127	0	35	34
2014	9	21	16	41	2	0.771	-0.105	4.163	0.01	0.007	0	44.3	40.4	63.6	137	128	0	34	34
2014	9	21	16	51	2	0.784	-0.089	4.163	0.013	0.01	0	43.9	40.9	60.6	137	128	0	35	33
2014	9	21	17	1	2	0.748	-0.128	4.163	0.016	0.016	0	43.9	40.4	61.5	137	128	0	35	34
2014	9	21	17	11	2	0.764	-0.141	4.163	0.013	0.01	0	43.9	40	66.2	137	127	0	35	34
2014	9	21	17	21	2	0.745	-0.121	4.16	0.01	0.007	0	43.4	40.4	60.6	136	127	0	35	33
2014	9	21	17	31	2	0.797	-0.118	4.163	0.01	0.007	0	43.4	39.6	66.7	136	126	0	35	34
2014	9	21	17	41	2	0.784	-0.115	4.163	0.01	0.007	0	43.4	40.4	61.9	136	127	0	35	33
2014	9	21	17	51	2	0.761	-0.112	4.167	0.01	0.007	0	43.9	40	67.5	137	127	0	35	34
2014	9	21	18	1	2	0.771	-0.112	4.167	0.01	0.007	0	43.9	40	66.7	136	127	0	34	34
2014	9	21	18	11	2	0.768	-0.092	4.167	0.013	0.01	0	43.9	40	64.5	137	127	0	35	34
2014	9	21	18	21	2	0.781	-0.075	4.17	0.01	0.007	0	44.3	40.4	71.4	138	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	18	31	2	0.768	-0.072	4.17	0.01	0.007	0	44.3	40.9	71.8	138	128	0	35	33
2014	9	21	18	41	2	0.758	-0.059	4.17	0.013	0.01	0	44.7	40.9	71.8	139	129	0	35	34
2014	9	21	18	51	2	0.787	-0.072	4.17	0.016	0.013	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	21	19	1	2	0.787	-0.082	4.17	0.01	0.007	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	21	19	11	2	0.758	-0.092	4.17	0.01	0.007	0	44.7	40.9	73.1	139	129	0	35	34
2014	9	21	19	21	2	0.728	-0.072	4.17	0.01	0.007	0	45.2	41.7	71.8	140	130	0	35	33
2014	9	21	19	31	2	0.797	-0.059	4.17	0.013	0.01	0	45.2	41.3	71.8	140	130	0	35	34
2014	9	21	19	41	2	0.748	-0.069	4.17	0.01	0.007	0	45.6	42.1	72.2	141	131	0	35	33
2014	9	21	19	51	2	0.758	-0.052	4.173	0.01	0.007	0	45.6	41.7	72.2	141	131	0	35	34
2014	9	21	20	1	2	0.764	-0.075	4.173	0.01	0.007	0	46.4	43	71.8	143	133	0	35	33
2014	9	21	20	11	2	0.751	-0.066	4.173	0.01	0.007	0	45.6	41.7	72.7	141	131	0	35	34
2014	9	21	20	21	2	0.771	-0.079	4.173	0.016	0.013	0	46	42.1	72.2	142	132	0	35	34
2014	9	21	20	31	2	0.774	-0.095	4.173	0.01	0.007	0	45.6	41.3	73.1	140	130	0	34	34
2014	9	21	20	41	2	0.778	-0.049	4.173	0.01	0.007	0	45.6	41.7	73.1	141	131	0	35	34
2014	9	21	20	51	2	0.764	-0.062	4.173	0.013	0.01	0	45.2	41.3	72.7	140	130	0	35	34
2014	9	21	21	1	2	0.784	-0.072	4.177	0.01	0.007	0	45.2	41.3	73.5	140	130	0	35	34
2014	9	21	21	11	2	0.794	-0.092	4.177	0.01	0.007	0	45.6	41.3	74	140	130	0	34	34
2014	9	21	21	21	2	0.771	-0.075	4.177	0.01	0.007	0	45.6	41.3	66.2	140	130	0	34	34
2014	9	21	21	31	2	0.784	-0.089	4.177	0.016	0.013	0	44.7	41.3	74	139	129	0	35	33
2014	9	21	21	41	2	0.771	-0.066	4.177	0.013	0.01	0	45.2	41.3	74	140	130	0	35	34
2014	9	21	21	51	2	0.774	-0.069	4.177	0.01	0.007	0	44.7	41.3	73.5	139	129	0	35	33
2014	9	21	22	1	2	0.801	-0.082	4.177	0.01	0.007	0	44.3	40.4	74	138	128	0	35	34
2014	9	21	22	11	2	0.774	-0.102	4.177	0.013	0.01	0	44.7	41.3	74.4	139	130	0	35	34
2014	9	21	22	21	2	0.804	-0.062	4.177	0.013	0.01	0	44.7	41.3	74.4	139	129	0	35	33
2014	9	21	22	31	2	0.748	-0.112	4.177	0.01	0.007	0	44.7	41.7	74.4	139	130	0	35	33
2014	9	21	22	41	2	0.738	-0.062	4.177	0.01	0.007	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	21	22	51	2	0.784	-0.095	4.177	0.01	0.007	0	45.2	40.9	74.4	139	129	0	34	34
2014	9	21	23	1	2	0.755	-0.069	4.177	0.016	0.016	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	21	23	11	2	0.771	-0.062	4.18	0.01	0.007	0	45.2	40.9	73.1	139	129	0	34	34
2014	9	21	23	21	2	0.755	-0.079	4.18	0.016	0.013	0	44.7	41.3	74	139	129	0	35	33
2014	9	21	23	31	2	0.748	-0.102	4.18	0.01	0.007	0	45.2	40.9	75.3	139	129	0	34	34
2014	9	21	23	41	2	0.755	-0.098	4.18	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	21	23	51	2	0.738	-0.079	4.18	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	22	0	1	2	0.755	-0.082	4.18	0.01	0.007	0	44.7	40.9	75.7	140	130	0	36	35
2014	9	22	0	11	2	0.735	-0.082	4.18	0.01	0.007	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	22	0	21	2	0.764	-0.092	4.18	0.016	0.013	0	45.2	41.3	75.7	139	129	0	34	33
2014	9	22	0	31	2	0.768	-0.079	4.18	0.013	0.01	0	44.3	41.3	76.1	139	129	0	36	33
2014	9	22	0	41	2	0.774	-0.079	4.18	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	22	0	51	2	0.768	-0.056	4.18	0.013	0.01	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	22	1	1	2	0.758	-0.085	4.18	0.01	0.007	0	44.7	40.9	76.1	139	129	0	35	34
2014	9	22	1	11	2	0.781	-0.079	4.18	0.013	0.01	0	44.3	40.4	75.7	138	129	0	35	35
2014	9	22	1	21	2	0.771	-0.089	4.18	0.013	0.01	0	44.7	40.9	75.7	139	129	0	35	34
2014	9	22	1	31	2	0.764	-0.069	4.18	0.013	0.01	0	45.6	41.3	75.7	140	130	0	34	34
2014	9	22	1	41	2	0.784	-0.089	4.18	0.013	0.01	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	22	1	51	2	0.738	-0.085	4.18	0.013	0.01	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	22	2	1	2	0.778	-0.089	4.18	0.01	0.007	0	45.6	41.3	74.8	140	130	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	2	11	2	0.778	-0.112	4.18	0.01	0.007	0	44.7	40.4	75.3	139	128	0	35	34
2014	9	22	2	21	2	0.774	-0.108	4.18	0.013	0.01	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	22	2	31	2	0.784	-0.108	4.18	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	22	2	41	2	0.774	-0.095	4.18	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	22	2	51	2	0.748	-0.075	4.18	0.01	0.007	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	22	3	1	2	0.784	-0.069	4.18	0.01	0.007	0	44.3	40.9	74.8	138	128	0	35	33
2014	9	22	3	11	2	0.768	-0.089	4.18	0.01	0.007	0	44.3	40.9	73.1	138	128	0	35	33
2014	9	22	3	21	2	0.774	-0.079	4.18	0.01	0.007	0	44.3	40	74.8	138	128	0	35	35
2014	9	22	3	31	2	0.771	-0.079	4.183	0.01	0.007	0	44.3	41.3	74.4	138	128	0	35	32
2014	9	22	3	41	2	0.781	-0.075	4.18	0.01	0.007	0	44.7	40.4	74.4	139	128	0	35	34
2014	9	22	3	51	2	0.764	-0.079	4.183	0.013	0.01	0	44.3	41.3	74	139	129	0	36	33
2014	9	22	4	1	2	0.778	-0.089	4.183	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	22	4	11	2	0.764	-0.092	4.183	0.01	0.007	0	44.3	40.4	74	138	128	0	35	34
2014	9	22	4	21	2	0.761	-0.089	4.183	0.01	0.007	0	44.3	40.9	74	139	129	0	36	34
2014	9	22	4	31	2	0.751	-0.079	4.183	0.013	0.01	0	44.3	41.3	74	138	129	0	35	33
2014	9	22	4	41	2	0.758	-0.095	4.183	0.01	0.007	0	45.2	40.9	73.1	139	129	0	34	34
2014	9	22	4	51	2	0.774	-0.085	4.183	0.01	0.007	0	45.2	41.3	73.5	140	130	0	35	34
2014	9	22	5	1	2	0.751	-0.095	4.183	0.013	0.01	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	22	5	11	2	0.794	-0.082	4.183	0.01	0.007	0	46.9	42.6	70.1	144	133	0	35	34
2014	9	22	5	21	2	0.761	-0.082	4.183	0.013	0.01	0	45.2	41.7	73.5	140	130	0	35	33
2014	9	22	5	31	2	0.764	-0.079	4.183	0.01	0.007	0	45.2	41.7	72.7	140	130	0	35	33
2014	9	22	5	41	2	0.764	-0.112	4.186	0.01	0.007	0	46.9	43	71.8	144	134	0	35	34
2014	9	22	5	51	2	0.787	-0.079	4.186	0.013	0.01	0	46.4	42.6	71.8	143	133	0	35	34
2014	9	22	6	1	2	0.774	-0.069	4.186	0.016	0.013	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	22	6	11	2	0.764	-0.092	4.19	0.013	0.01	0	45.6	41.3	67.1	141	130	0	35	34
2014	9	22	6	21	2	0.751	-0.085	4.186	0.01	0.007	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	22	6	31	2	0.748	-0.089	4.19	0.01	0.007	0	43.9	40.4	71.4	138	128	0	36	34
2014	9	22	6	41	2	0.771	-0.082	4.19	0.01	0.007	0	45.6	41.3	71	141	130	0	35	34
2014	9	22	6	51	2	0.735	-0.092	4.19	0.01	0.007	0	46.4	42.6	70.1	143	132	0	35	33
2014	9	22	7	1	2	0.761	-0.082	4.19	0.01	0.007	0	46	42.6	69.7	143	133	0	36	34
2014	9	22	7	11	2	0.748	-0.079	4.19	0.01	0.007	0	44.7	40.9	70.5	139	129	0	35	34
2014	9	22	7	21	2	0.745	-0.115	4.19	0.01	0.007	0	43.9	40.4	71.4	137	127	0	35	33
2014	9	22	7	31	2	0.794	-0.089	4.19	0.01	0.007	0	43.9	39.6	71	137	127	0	35	35
2014	9	22	7	41	2	0.768	-0.092	4.19	0.01	0.007	0	43.9	39.6	71.4	137	126	0	35	34
2014	9	22	7	51	2	0.755	-0.095	4.193	0.01	0.007	0	43.4	40	71	136	127	0	35	34
2014	9	22	8	1	2	0.768	-0.112	4.193	0.013	0.01	0	43.4	39.6	71.4	136	126	0	35	34
2014	9	22	8	11	2	0.758	-0.069	4.193	0.01	0.007	0	43.9	40.4	71.4	137	127	0	35	33
2014	9	22	8	21	2	0.745	-0.095	4.19	0.01	0.007	0	43.9	40	71	137	127	0	35	34
2014	9	22	8	31	2	0.794	-0.098	4.19	0.013	0.01	0	43.9	40	71	137	127	0	35	34
2014	9	22	8	41	2	0.764	-0.079	4.19	0.016	0.013	0	43.9	40	71	137	127	0	35	34
2014	9	22	8	51	2	0.774	-0.085	4.19	0.01	0.007	0	43.9	40	71.4	136	127	0	34	34
2014	9	22	9	1	2	0.751	-0.108	4.19	0.01	0.007	0	43.9	40	71.4	137	127	0	35	34
2014	9	22	9	11	2	0.748	-0.079	4.19	0.01	0.007	0	43.9	40	71	137	127	0	35	34
2014	9	22	9	21	2	0.787	-0.046	4.19	0.01	0.007	0	43.9	40	71.4	137	127	0	35	34
2014	9	22	9	31	2	0.787	-0.082	4.19	0.013	0.01	0	43.9	40	71	137	127	0	35	34
2014	9	22	9	41	2	0.784	-0.102	4.19	0.01	0.007	0	43.4	39.6	70.1	136	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	9	51	2	0.758	-0.095	4.19	0.01	0.007	0	43.9	40.4	71.8	136	127	0	34	33
2014	9	22	10	1	2	0.725	-0.075	4.19	0.013	0.01	0	43.9	40	72.2	137	127	0	35	34
2014	9	22	10	11	2	0.764	-0.125	4.19	0.01	0.007	0	43	40	72.2	136	127	0	36	34
2014	9	22	10	21	2	0.771	-0.072	4.19	0.01	0.007	0	43.9	40	72.2	137	127	0	35	34
2014	9	22	10	31	2	0.801	-0.092	4.19	0.01	0.007	0	43.4	40	70.5	136	127	0	35	34
2014	9	22	10	41	2	0.774	-0.125	4.19	0.01	0.007	0	43	40	72.7	135	126	0	35	33
2014	9	22	10	51	2	0.764	-0.154	4.19	0.01	0.007	0	43.4	39.1	71.4	135	125	0	34	34
2014	9	22	11	1	2	0.751	-0.112	4.19	0.01	0.007	0	43.4	40	72.7	136	127	0	35	34
2014	9	22	11	11	2	0.774	-0.128	4.186	0.01	0.007	0	43.4	40	61.1	136	127	0	35	34
2014	9	22	11	21	2	0.787	-0.141	4.186	0.01	0.007	0	43.4	39.6	71	136	126	0	35	34
2014	9	22	11	31	2	0.768	-0.125	4.19	0.016	0.013	0	43.4	40	73.1	136	127	0	35	34
2014	9	22	11	41	2	0.771	-0.131	4.186	0.013	0.01	0	43.4	39.6	63.6	135	126	0	34	34
2014	9	22	11	51	2	0.735	-0.135	4.186	0.01	0.007	0	43.4	40	71.8	136	127	0	35	34
2014	9	22	12	1	2	0.791	-0.112	4.186	0.016	0.013	0	43	40	57.2	135	126	0	35	33
2014	9	22	12	11	2	0.797	-0.118	4.186	0.01	0.007	0	43.4	40	55.5	136	127	0	35	34
2014	9	22	12	21	2	0.814	-0.144	4.186	0.013	0.01	0	43.4	39.6	59.3	135	126	0	34	34
2014	9	22	12	31	2	0.774	-0.151	4.186	0.01	0.007	0	43.4	40	62.4	136	126	0	35	33
2014	9	22	12	41	2	0.771	-0.164	4.186	0.01	0.007	0	43	40	57.2	135	126	0	35	33
2014	9	22	12	51	2	0.794	-0.098	4.19	0.01	0.007	0	43.4	40	52.5	136	127	0	35	34
2014	9	22	13	1	2	0.755	-0.138	4.186	0.013	0.01	0	43.4	40	53.8	136	127	0	35	34
2014	9	22	13	11	2	0.771	-0.171	4.186	0.01	0.007	0	43.4	39.6	52.9	136	126	0	35	34
2014	9	22	13	21	2	0.771	-0.171	4.183	0.01	0.007	0	43.9	40.9	56.8	137	128	0	35	33
2014	9	22	13	31	2	0.761	-0.128	4.186	0.01	0.007	0	43.9	40.4	55	137	128	0	35	34
2014	9	22	13	41	2	0.751	-0.157	4.183	0.013	0.01	0	43.9	40.9	58.9	137	129	0	35	34
2014	9	22	13	51	2	0.758	-0.177	4.183	0.013	0.01	0	43.9	40	58.5	137	127	0	35	34
2014	9	22	14	1	2	0.791	-0.092	4.183	0.01	0.007	0	43.9	40.9	58	137	128	0	35	33
2014	9	22	14	11	2	0.778	-0.121	4.183	0.01	0.007	0	44.7	41.3	55.9	139	130	0	35	34
2014	9	22	14	21	2	0.781	-0.135	4.183	0.01	0.007	0	43.9	40.4	68.4	137	128	0	35	34
2014	9	22	14	31	2	0.748	-0.151	4.183	0.01	0.007	0	43.4	40.4	57.6	137	128	0	36	34
2014	9	22	14	41	2	0.761	-0.154	4.183	0.01	0.007	0	43.9	40.9	62.4	137	128	0	35	33
2014	9	22	14	51	2	0.781	-0.112	4.183	0.016	0.013	0	44.3	40.9	71	137	128	0	34	33
2014	9	22	15	1	2	0.761	-0.128	4.183	0.01	0.007	0	43.9	40.9	61.5	138	129	0	36	34
2014	9	22	15	11	2	0.758	-0.167	4.18	0.01	0.007	0	43.9	40.4	61.9	137	128	0	35	34
2014	9	22	15	21	2	0.781	-0.128	4.183	0.01	0.007	0	43.9	40.4	62.8	137	128	0	35	34
2014	9	22	15	31	2	0.778	-0.128	4.183	0.01	0.007	0	43.9	40.9	58.5	137	128	0	35	33
2014	9	22	15	41	2	0.781	-0.174	4.183	0.01	0.007	0	44.3	40.4	63.6	137	128	0	34	34
2014	9	22	15	51	2	0.741	-0.125	4.183	0.016	0.013	0	44.7	40.9	61.5	138	129	0	34	34
2014	9	22	16	1	2	0.774	-0.118	4.183	0.01	0.007	0	43.9	40.4	62.4	137	128	0	35	34
2014	9	22	16	11	2	0.774	-0.161	4.183	0.01	0.007	0	44.3	40.9	51.2	138	129	0	35	34
2014	9	22	16	21	2	0.801	-0.125	4.183	0.01	0.007	0	43.9	40.4	62.4	137	128	0	35	34
2014	9	22	16	31	2	0.768	-0.128	4.183	0.01	0.007	0	44.3	40.4	57.6	138	128	0	35	34
2014	9	22	16	41	2	0.768	-0.128	4.183	0.01	0.007	0	44.3	40.9	63.2	138	129	0	35	34
2014	9	22	16	51	2	0.764	-0.125	4.183	0.01	0.007	0	43.9	40.9	66.2	137	128	0	35	33
2014	9	22	17	1	2	0.768	-0.102	4.183	0.01	0.007	0	44.3	40.9	63.2	138	129	0	35	34
2014	9	22	17	11	2	0.761	-0.121	4.183	0.01	0.007	0	43.9	40.4	57.2	137	127	0	35	33
2014	9	22	17	21	2	0.771	-0.148	4.183	0.01	0.007	0	43.9	40.9	56.8	137	128	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	17	31	2	0.791	-0.128	4.183	0.01	0.007	0	43.9	40.4	67.5	137	127	0	35	33
2014	9	22	17	41	2	0.758	-0.118	4.183	0.01	0.007	0	43.4	40.4	56.8	137	128	0	36	34
2014	9	22	17	51	2	0.778	-0.121	4.183	0.013	0.01	0	43.9	40	55.9	137	127	0	35	34
2014	9	22	18	1	2	0.787	-0.105	4.183	0.013	0.01	0	44.3	40	66.7	137	128	0	34	35
2014	9	22	18	11	2	0.784	-0.095	4.183	0.01	0.007	0	44.3	40.4	58.5	138	128	0	35	34
2014	9	22	18	21	2	0.768	-0.085	4.183	0.01	0.007	0	44.7	40	67.5	138	128	0	34	35
2014	9	22	18	31	2	0.81	-0.089	4.183	0.01	0.007	0	43.9	40.4	70.1	137	128	0	35	34
2014	9	22	18	41	2	0.804	-0.121	4.183	0.013	0.01	0	43.9	40.4	60.6	137	128	0	35	34
2014	9	22	18	51	2	0.791	-0.102	4.183	0.01	0.007	0	44.3	40.4	57.6	137	128	0	34	34
2014	9	22	19	1	2	0.787	-0.144	4.183	0.01	0.007	0	44.3	40.4	59.8	137	128	0	34	34
2014	9	22	19	11	2	0.787	-0.089	4.183	0.01	0.007	0	44.3	40.4	61.1	138	128	0	35	34
2014	9	22	19	21	2	0.814	-0.125	4.186	0.01	0.007	0	44.3	40.4	58.9	138	128	0	35	34
2014	9	22	19	31	2	0.781	-0.095	4.186	0.01	0.007	0	44.3	41.3	55	138	129	0	35	33
2014	9	22	19	41	2	0.797	-0.075	4.186	0.01	0.007	0	44.3	41.7	54.2	139	130	0	36	33
2014	9	22	19	51	2	0.768	-0.125	4.186	0.01	0.007	0	44.3	40.9	52	138	129	0	35	34
2014	9	22	20	1	2	0.751	-0.095	4.186	0.01	0.007	0	44.7	40.9	55.5	139	129	0	35	34
2014	9	22	20	11	2	0.758	-0.112	4.186	0.01	0.007	0	44.7	41.3	55.5	139	130	0	35	34
2014	9	22	20	21	2	0.764	-0.102	4.186	0.01	0.007	0	44.7	41.3	58	139	130	0	35	34
2014	9	22	20	31	2	0.755	-0.079	4.186	0.01	0.007	0	45.2	41.3	61.5	140	130	0	35	34
2014	9	22	20	41	2	0.778	-0.121	4.19	0.01	0.007	0	44.7	40.9	60.6	139	129	0	35	34
2014	9	22	20	51	2	0.771	-0.085	4.19	0.01	0.007	0	44.7	40.9	56.8	139	129	0	35	34
2014	9	22	21	1	2	0.781	-0.108	4.19	0.01	0.007	0	44.7	40.9	57.2	139	128	0	35	33
2014	9	22	21	11	2	0.778	-0.089	4.19	0.01	0.007	0	44.7	40.9	59.3	139	129	0	35	34
2014	9	22	21	21	2	0.774	-0.085	4.19	0.01	0.007	0	44.7	40.9	61.9	139	129	0	35	34
2014	9	22	21	31	2	0.794	-0.089	4.193	0.01	0.007	0	45.2	41.7	71.8	139	130	0	34	33
2014	9	22	21	41	2	0.784	-0.072	4.19	0.01	0.007	0	45.2	41.3	71.4	140	130	0	35	34
2014	9	22	21	51	2	0.787	-0.112	4.193	0.01	0.007	0	44.3	40.9	72.7	138	129	0	35	34
2014	9	22	22	1	2	0.768	-0.095	4.193	0.01	0.007	0	45.2	40.9	70.5	139	129	0	34	34
2014	9	22	22	11	2	0.791	-0.075	4.193	0.01	0.007	0	44.7	40.9	72.2	139	129	0	35	34
2014	9	22	22	21	2	0.751	-0.092	4.193	0.01	0.007	0	45.2	40.9	71.8	140	129	0	35	34
2014	9	22	22	31	2	0.764	-0.075	4.193	0.01	0.007	0	45.2	40.9	71.8	139	129	0	34	34
2014	9	22	22	41	2	0.787	-0.069	4.193	0.01	0.007	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	22	22	51	2	0.761	-0.079	4.193	0.01	0.007	0	44.7	41.3	71.4	139	129	0	35	33
2014	9	22	23	1	2	0.761	-0.095	4.193	0.01	0.007	0	44.7	41.3	71.4	139	130	0	35	34
2014	9	22	23	11	2	0.794	-0.089	4.193	0.01	0.007	0	44.7	41.3	71	139	129	0	35	33
2014	9	22	23	21	2	0.781	-0.075	4.196	0.01	0.007	0	45.6	41.3	71	140	130	0	34	34
2014	9	22	23	31	2	0.758	-0.069	4.196	0.01	0.007	0	44.7	40.9	71	139	129	0	35	34
2014	9	22	23	41	2	0.778	-0.082	4.196	0.01	0.007	0	44.7	41.3	70.1	139	129	0	35	33
2014	9	22	23	51	2	0.735	-0.079	4.199	0.01	0.007	0	44.7	40.9	70.5	139	129	0	35	34
2014	9	23	0	1	2	0.755	-0.082	4.199	0.01	0.007	0	44.7	40.9	70.5	139	129	0	35	34
2014	9	23	0	11	2	0.748	-0.059	4.203	0.01	0.007	0	44.3	40.4	70.5	138	128	0	35	34
2014	9	23	0	21	2	0.761	-0.072	4.203	0.013	0.01	0	44.7	40.9	70.5	139	129	0	35	34
2014	9	23	0	31	2	0.755	-0.066	4.203	0.01	0.007	0	44.7	40.4	71	139	128	0	35	34
2014	9	23	0	41	2	0.778	-0.105	4.203	0.01	0.007	0	44.7	40.9	71	139	128	0	35	33
2014	9	23	0	51	2	0.781	-0.079	4.206	0.016	0.013	0	44.3	41.3	70.5	138	129	0	35	33
2014	9	23	1	1	2	0.748	-0.059	4.206	0.01	0.007	0	44.3	40.4	71	138	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	1	11	2	0.771	-0.079	4.209	0.01	0.007	0	45.6	41.3	70.5	140	130	0	34	34
2014	9	23	1	21	2	0.761	-0.082	4.209	0.01	0.007	0	44.7	40.4	71	139	128	0	35	34
2014	9	23	1	31	2	0.771	-0.089	4.209	0.01	0.007	0	44.7	41.3	71.4	139	129	0	35	33
2014	9	23	1	41	2	0.745	-0.066	4.209	0.016	0.013	0	45.2	41.3	71.4	140	129	0	35	33
2014	9	23	1	51	2	0.751	-0.092	4.209	0.013	0.01	0	44.3	40.9	71.8	138	129	0	35	34
2014	9	23	2	1	2	0.797	-0.043	4.209	0.01	0.007	0	45.2	41.3	71.8	140	130	0	35	34
2014	9	23	2	11	2	0.83	-0.069	4.209	0.013	0.01	0	45.2	40.9	72.2	139	129	0	34	34
2014	9	23	2	21	2	0.768	-0.092	4.209	0.01	0.007	0	44.7	40.9	72.2	139	129	0	35	34
2014	9	23	2	31	2	0.774	-0.085	4.209	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	23	2	41	2	0.755	-0.098	4.209	0.016	0.013	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	23	2	51	2	0.741	-0.079	4.209	0.013	0.01	0	45.2	40.4	73.1	139	128	0	34	34
2014	9	23	3	1	2	0.751	-0.066	4.209	0.013	0.01	0	44.7	40.9	72.7	139	129	0	35	34
2014	9	23	3	11	2	0.784	-0.069	4.209	0.01	0.007	0	45.2	41.3	73.5	140	129	0	35	33
2014	9	23	3	21	2	0.774	-0.075	4.209	0.01	0.007	0	44.7	40.4	73.5	139	128	0	35	34
2014	9	23	3	31	2	0.771	-0.072	4.213	0.01	0.007	0	45.2	40.9	73.5	139	129	0	34	34
2014	9	23	3	41	2	0.771	-0.089	4.213	0.016	0.013	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	23	3	51	2	0.791	-0.059	4.213	0.013	0.01	0	44.3	40.4	74	138	128	0	35	34
2014	9	23	4	1	2	0.761	-0.046	4.213	0.016	0.013	0	44.7	40.9	74	139	129	0	35	34
2014	9	23	4	11	2	0.758	-0.079	4.213	0.01	0.007	0	45.2	40.4	74	139	128	0	34	34
2014	9	23	4	21	2	0.758	-0.075	4.213	0.013	0.01	0	44.3	40.4	70.1	138	128	0	35	34
2014	9	23	4	31	2	0.768	-0.079	4.213	0.01	0.007	0	44.7	40.9	74	139	128	0	35	33
2014	9	23	4	41	2	0.778	-0.072	4.213	0.01	0.007	0	44.3	40	74.4	138	127	0	35	34
2014	9	23	4	51	2	0.758	-0.079	4.213	0.01	0.007	0	44.7	40.4	75.3	138	128	0	34	34
2014	9	23	5	1	2	0.761	-0.082	4.216	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	23	5	11	2	0.755	-0.072	4.216	0.01	0.007	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	23	5	21	2	0.741	-0.052	4.216	0.013	0.01	0	45.2	40.9	74.8	139	129	0	34	34
2014	9	23	5	31	2	0.761	-0.089	4.216	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	23	5	41	2	0.741	-0.098	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	23	5	51	2	0.771	-0.072	4.216	0.01	0.007	0	46	41.7	71.4	142	131	0	35	34
2014	9	23	6	1	2	0.761	-0.098	4.216	0.01	0.007	0	45.6	41.7	70.1	141	131	0	35	34
2014	9	23	6	11	2	0.764	-0.075	4.219	0.01	0.007	0	45.2	41.3	74.8	140	130	0	35	34
2014	9	23	6	21	2	0.784	-0.102	4.219	0.016	0.013	0	45.6	41.7	74.8	141	131	0	35	34
2014	9	23	6	31	2	0.764	-0.062	4.219	0.01	0.007	0	45.6	41.3	74.4	141	130	0	35	34
2014	9	23	6	41	2	0.784	-0.069	4.219	0.01	0.007	0	45.2	41.7	74.4	140	130	0	35	33
2014	9	23	6	51	2	0.794	-0.102	4.219	0.013	0.01	0	46	42.1	74.4	142	132	0	35	34
2014	9	23	7	1	2	0.764	-0.082	4.219	0.01	0.007	0	44.7	40.4	74.4	139	128	0	35	34
2014	9	23	7	11	2	0.768	-0.085	4.219	0.01	0.007	0	44.3	40.4	74.4	138	127	0	35	33
2014	9	23	7	21	2	0.791	-0.075	4.219	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	23	7	31	2	0.771	-0.108	4.219	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	23	7	41	2	0.778	-0.095	4.219	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	23	7	51	2	0.781	-0.105	4.219	0.01	0.007	0	43.9	40	73.5	137	127	0	35	34
2014	9	23	8	1	2	0.761	-0.112	4.219	0.01	0.007	0	43.9	40	74	137	127	0	35	34
2014	9	23	8	11	2	0.771	-0.066	4.219	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	23	8	21	2	0.768	-0.075	4.219	0.013	0.01	0	44.3	40.4	73.5	137	128	0	34	34
2014	9	23	8	31	2	0.771	-0.089	4.219	0.01	0.007	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	23	8	41	2	0.781	-0.079	4.219	0.01	0.007	0	43.9	40.4	74.8	137	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	8	51	2	0.741	-0.095	4.219	0.013	0.01	0	43.9	40.4	74.8	137	128	0	35	34
2014	9	23	9	1	2	0.778	-0.072	4.219	0.01	0.007	0	44.3	40	74.4	137	128	0	34	35
2014	9	23	9	11	2	0.791	-0.085	4.219	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	23	9	21	2	0.791	-0.075	4.219	0.01	0.007	0	43.9	40.4	74.4	137	128	0	35	34
2014	9	23	9	31	2	0.797	-0.089	4.219	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	23	9	41	2	0.781	-0.121	4.219	0.01	0.007	0	43.9	40	74.8	137	127	0	35	34
2014	9	23	9	51	2	0.778	-0.102	4.219	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	23	10	1	2	0.755	-0.121	4.219	0.013	0.01	0	43.9	40	74.4	137	127	0	35	34
2014	9	23	10	11	2	0.797	-0.105	4.216	0.01	0.007	0	43.9	40.4	74.4	137	127	0	35	33
2014	9	23	10	21	2	0.791	-0.108	4.219	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	23	10	31	2	0.794	-0.108	4.216	0.01	0.007	0	43	40	72.2	136	127	0	36	34
2014	9	23	10	41	2	0.778	-0.118	4.216	0.01	0.007	0	43.9	40.9	72.7	137	128	0	35	33
2014	9	23	10	51	2	0.764	-0.128	4.216	0.01	0.007	0	43.9	40.9	72.7	137	128	0	35	33
2014	9	23	11	1	2	0.768	-0.108	4.216	0.013	0.01	0	43.4	40	73.1	136	127	0	35	34
2014	9	23	11	11	2	0.761	-0.098	4.216	0.013	0.01	0	43.4	40	68.8	136	127	0	35	34
2014	9	23	11	21	2	0.797	-0.079	4.216	0.01	0.007	0	43.4	40	64.9	136	127	0	35	34
2014	9	23	11	31	2	0.797	-0.128	4.216	0.01	0.007	0	43.4	40.4	60.6	136	127	0	35	33
2014	9	23	11	41	2	0.827	-0.121	4.216	0.01	0.007	0	43.4	40	58	136	127	0	35	34
2014	9	23	11	51	2	0.761	-0.105	4.216	0.01	0.007	0	43.9	40.4	55	137	128	0	35	34
2014	9	23	12	1	2	0.761	-0.154	4.216	0.01	0.007	0	43.4	39.6	61.1	136	126	0	35	34
2014	9	23	12	11	2	0.761	-0.194	4.216	0.013	0.01	0	43	39.6	49.9	135	126	0	35	34
2014	9	23	12	21	2	0.761	-0.128	4.216	0.01	0.007	0	43	40	56.3	135	126	0	35	33
2014	9	23	12	31	2	0.768	-0.128	4.216	0.01	0.007	0	43.4	40.4	53.8	136	127	0	35	33
2014	9	23	12	41	2	0.771	-0.174	4.216	0.01	0.007	0	43.4	40	52	136	127	0	35	34
2014	9	23	12	51	2	0.771	-0.171	4.213	0.01	0.007	0	43.9	40.4	50.3	136	127	0	34	33
2014	9	23	13	1	2	0.764	-0.154	4.213	0.01	0.007	0	43.4	40	51.2	136	127	0	35	34
2014	9	23	13	11	2	0.784	-0.194	4.213	0.01	0.007	0	43.4	39.6	55.9	136	126	0	35	34
2014	9	23	13	21	2	0.761	-0.154	4.213	0.01	0.007	0	43.9	40.4	62.4	137	127	0	35	33
2014	9	23	13	31	2	0.768	-0.141	4.213	0.01	0.007	0	43.4	40	55.5	137	127	0	36	34
2014	9	23	13	41	2	0.764	-0.157	4.213	0.01	0.007	0	43.4	40.4	56.3	137	128	0	36	34
2014	9	23	13	51	2	0.774	-0.102	4.213	0.016	0.013	0	44.3	40.9	51.2	138	128	0	35	33
2014	9	23	14	1	2	0.778	-0.19	4.213	0.01	0.007	0	43.9	40	57.6	137	127	0	35	34
2014	9	23	14	11	2	0.768	-0.174	4.209	0.01	0.007	0	43.9	40.9	54.2	137	128	0	35	33
2014	9	23	14	21	2	0.781	-0.157	4.209	0.01	0.007	0	43.9	40.4	49	137	128	0	35	34
2014	9	23	14	31	2	0.764	-0.154	4.209	0.01	0.007	0	44.3	40.9	52.9	138	128	0	35	33
2014	9	23	14	41	2	0.768	-0.141	4.209	0.013	0.01	0	44.3	40.4	49.9	138	128	0	35	34
2014	9	23	14	51	2	0.761	-0.161	4.206	0.016	0.013	0	44.3	40.4	49	137	128	0	34	34
2014	9	23	15	1	2	0.787	-0.131	4.209	0.01	0.007	0	44.3	40.9	52.9	138	128	0	35	33
2014	9	23	15	11	2	0.787	-0.164	4.209	0.01	0.007	0	44.3	40.4	51.2	138	128	0	35	34
2014	9	23	15	21	2	0.764	-0.131	4.206	0.01	0.007	0	44.3	40.9	51.2	138	128	0	35	33
2014	9	23	15	31	2	0.794	-0.121	4.206	0.01	0.007	0	44.3	40.9	50.7	138	129	0	35	34
2014	9	23	15	41	2	0.764	-0.157	4.206	0.013	0.01	0	44.3	40.9	52.5	138	128	0	35	33
2014	9	23	15	51	2	0.814	-0.118	4.206	0.01	0.007	0	44.7	41.3	50.7	139	129	0	35	33
2014	9	23	16	1	2	0.771	-0.131	4.206	0.01	0.007	0	44.3	40.9	46	138	129	0	35	34
2014	9	23	16	11	2	0.761	-0.138	4.206	0.01	0.007	0	44.7	40.4	53.3	138	128	0	34	34
2014	9	23	16	21	2	0.807	-0.102	4.206	0.01	0.007	0	44.3	40.4	53.3	138	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	16	31	2	0.758	-0.092	4.206	0.01	0.007	0	44.3	40	51.6	138	128	0	35	35
2014	9	23	16	41	2	0.781	-0.141	4.206	0.01	0.007	0	43.9	40.4	49	137	128	0	35	34
2014	9	23	16	51	2	0.781	-0.135	4.206	0.013	0.01	0	44.7	40.9	48.6	138	129	0	34	34
2014	9	23	17	1	2	0.791	-0.128	4.206	0.01	0.007	0	43.9	40.4	60.2	137	128	0	35	34
2014	9	23	17	11	2	0.778	-0.131	4.206	0.013	0.01	0	43.9	40.4	55.5	137	128	0	35	34
2014	9	23	17	21	2	0.804	-0.115	4.209	0.01	0.007	0	43.9	40.9	65.4	137	128	0	35	33
2014	9	23	17	31	2	0.787	-0.098	4.206	0.013	0.01	0	44.3	40.4	60.6	138	128	0	35	34
2014	9	23	17	41	2	0.778	-0.115	4.206	0.01	0.007	0	44.3	40.9	54.2	137	128	0	34	33
2014	9	23	17	51	2	0.764	-0.131	4.209	0.016	0.013	0	43.4	40.4	55.5	137	128	0	36	34
2014	9	23	18	1	2	0.768	-0.118	4.206	0.01	0.007	0	43.9	40.9	59.3	137	128	0	35	33
2014	9	23	18	11	2	0.781	-0.138	4.209	0.01	0.007	0	43.4	40	66.7	136	127	0	35	34
2014	9	23	18	21	2	0.781	-0.141	4.209	0.01	0.007	0	43.4	40	67.5	136	127	0	35	34
2014	9	23	18	31	2	0.784	-0.112	4.209	0.01	0.007	0	43.4	40.4	63.6	136	127	0	35	33
2014	9	23	18	41	2	0.797	-0.108	4.209	0.01	0.007	0	43.4	40	67.5	136	127	0	35	34
2014	9	23	18	51	2	0.797	-0.112	4.209	0.01	0.007	0	43.9	40.4	61.5	137	128	0	35	34
2014	9	23	19	1	2	0.771	-0.115	4.209	0.01	0.007	0	43.9	40.4	58.5	137	128	0	35	34
2014	9	23	19	11	2	0.755	-0.089	4.209	0.01	0.007	0	44.7	41.3	58.5	139	130	0	35	34
2014	9	23	19	21	2	0.781	-0.105	4.209	0.01	0.007	0	44.3	41.3	54.2	138	129	0	35	33
2014	9	23	19	31	2	0.797	-0.128	4.209	0.016	0.013	0	43.9	40.9	61.5	137	129	0	35	34
2014	9	23	19	41	2	0.781	-0.112	4.209	0.01	0.007	0	46	41.7	63.6	141	131	0	34	34
2014	9	23	19	51	2	0.801	-0.118	4.209	0.013	0.01	0	45.2	41.3	60.6	139	129	0	34	33
2014	9	23	20	1	2	0.781	-0.059	4.209	0.01	0.007	0	45.2	41.3	57.2	140	130	0	35	34
2014	9	23	20	11	2	0.797	-0.102	4.213	0.01	0.007	0	44.7	40.9	68.4	139	129	0	35	34
2014	9	23	20	21	2	0.781	-0.118	4.213	0.01	0.007	0	45.2	40.9	74.4	140	129	0	35	34
2014	9	23	20	31	2	0.768	-0.085	4.213	0.01	0.007	0	45.2	41.3	74.4	140	129	0	35	33
2014	9	23	20	41	2	0.768	-0.075	4.213	0.01	0.007	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	23	20	51	2	0.751	-0.066	4.213	0.01	0.007	0	44.7	41.3	73.5	139	129	0	35	33
2014	9	23	21	1	2	0.774	-0.102	4.213	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	23	21	11	2	0.755	-0.072	4.216	0.013	0.01	0	45.2	41.7	74.8	140	130	0	35	33
2014	9	23	21	21	2	0.787	-0.098	4.216	0.01	0.007	0	45.6	40.9	75.7	140	129	0	34	34
2014	9	23	21	31	2	0.771	-0.082	4.216	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	23	21	41	2	0.755	-0.062	4.216	0.013	0.01	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	23	21	51	2	0.761	-0.062	4.216	0.01	0.007	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	23	22	1	2	0.755	-0.062	4.216	0.01	0.007	0	45.2	40.9	74.8	140	129	0	35	34
2014	9	23	22	11	2	0.764	-0.112	4.216	0.01	0.007	0	44.7	40.4	74.4	139	128	0	35	34
2014	9	23	22	21	2	0.768	-0.069	4.216	0.013	0.01	0	44.7	40.9	74.8	139	129	0	35	34
2014	9	23	22	31	2	0.778	-0.072	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	23	22	41	2	0.719	-0.075	4.216	0.013	0.01	0	45.2	41.3	74.8	139	129	0	34	33
2014	9	23	22	51	2	0.768	-0.069	4.216	0.01	0.007	0	44.3	40.4	74.8	138	128	0	35	34
2014	9	23	23	1	2	0.807	-0.092	4.216	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34
2014	9	23	23	11	2	0.738	-0.089	4.216	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	23	23	21	2	0.774	-0.069	4.216	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	23	23	31	2	0.768	-0.049	4.216	0.01	0.007	0	44.7	40.4	75.7	139	128	0	35	34
2014	9	23	23	41	2	0.784	-0.062	4.216	0.013	0.01	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	23	23	51	2	0.794	-0.072	4.216	0.013	0.01	0	44.3	40.4	75.3	138	128	0	35	34
2014	9	24	0	1	2	0.751	-0.069	4.216	0.01	0.007	0	44.7	40.9	75.3	139	129	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	0	11	2	0.764	-0.075	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	24	0	21	2	0.738	-0.095	4.216	0.01	0.007	0	44.7	40.4	74.8	139	128	0	35	34
2014	9	24	0	31	2	0.764	-0.082	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	24	0	41	2	0.778	-0.089	4.216	0.01	0.007	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	24	0	51	2	0.787	-0.105	4.219	0.01	0.007	0	44.3	40.4	74.4	138	128	0	35	34
2014	9	24	1	1	2	0.764	-0.079	4.216	0.013	0.01	0	44.7	40.4	74	139	128	0	35	34
2014	9	24	1	11	2	0.797	-0.092	4.219	0.01	0.007	0	43.9	40.9	74.8	138	128	0	36	33
2014	9	24	1	21	2	0.791	-0.079	4.219	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	24	1	31	2	0.745	-0.082	4.219	0.01	0.007	0	44.3	40.9	74	138	128	0	35	33
2014	9	24	1	41	2	0.745	-0.072	4.219	0.013	0.01	0	44.7	40.9	74.4	139	129	0	35	34
2014	9	24	1	51	2	0.768	-0.079	4.219	0.01	0.007	0	43.9	40	74.4	137	127	0	35	34
2014	9	24	2	1	2	0.755	-0.098	4.219	0.013	0.01	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	24	2	11	2	0.755	-0.079	4.219	0.01	0.007	0	44.3	40.9	73.5	138	128	0	35	33
2014	9	24	2	21	2	0.778	-0.092	4.219	0.01	0.007	0	44.3	40	73.5	138	127	0	35	34
2014	9	24	2	31	2	0.784	-0.085	4.219	0.01	0.007	0	44.7	40.9	72.7	139	129	0	35	34
2014	9	24	2	41	2	0.764	-0.079	4.219	0.01	0.007	0	44.7	40.4	73.5	138	128	0	34	34
2014	9	24	2	51	2	0.764	-0.095	4.219	0.01	0.007	0	44.3	40.4	74	138	128	0	35	34
2014	9	24	3	1	2	0.758	-0.043	4.219	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	24	3	11	2	0.774	-0.075	4.219	0.01	0.007	0	43.9	40.4	73.1	137	127	0	35	33
2014	9	24	3	21	2	0.797	-0.105	4.219	0.016	0.013	0	44.3	40.4	73.5	138	128	0	35	34
2014	9	24	3	31	2	0.794	-0.069	4.219	0.013	0.01	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	24	3	41	2	0.774	-0.095	4.219	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	24	3	51	2	0.745	-0.075	4.219	0.01	0.007	0	44.7	40.9	72.7	139	129	0	35	34
2014	9	24	4	1	2	0.768	-0.079	4.219	0.01	0.007	0	44.3	40.4	73.1	138	128	0	35	34
2014	9	24	4	11	2	0.755	-0.066	4.219	0.01	0.007	0	43.9	40	73.1	137	127	0	35	34
2014	9	24	4	21	2	0.768	-0.052	4.219	0.01	0.007	0	43.9	40.4	73.1	137	127	0	35	33
2014	9	24	4	31	2	0.778	-0.082	4.219	0.01	0.007	0	43.9	40.4	73.1	137	127	0	35	33
2014	9	24	4	41	2	0.764	-0.072	4.219	0.01	0.007	0	43.9	40	72.7	137	127	0	35	34
2014	9	24	4	51	2	0.758	-0.085	4.219	0.016	0.013	0	43.9	40.4	72.2	138	128	0	36	34
2014	9	24	5	1	2	0.748	-0.072	4.219	0.013	0.01	0	44.3	40.4	71.8	138	128	0	35	34
2014	9	24	5	11	2	0.801	-0.095	4.219	0.01	0.007	0	44.3	40	71.4	138	127	0	35	34
2014	9	24	5	21	2	0.761	-0.085	4.222	0.01	0.007	0	44.7	40.9	71	139	129	0	35	34
2014	9	24	5	31	2	0.758	-0.095	4.222	0.01	0.007	0	44.7	40.9	71.4	139	129	0	35	34
2014	9	24	5	41	2	0.784	-0.075	4.222	0.013	0.01	0	43.9	40.4	68.8	138	128	0	36	34
2014	9	24	5	51	2	0.755	-0.095	4.226	0.01	0.007	0	45.2	41.7	70.5	140	130	0	35	33
2014	9	24	6	1	2	0.758	-0.085	4.226	0.01	0.007	0	44.3	40.9	67.9	138	129	0	35	34
2014	9	24	6	11	2	0.771	-0.089	4.226	0.013	0.01	0	49	44.7	67.1	149	138	0	35	34
2014	9	24	6	21	2	0.761	-0.066	4.229	0.01	0.007	0	45.6	41.3	70.1	140	130	0	34	34
2014	9	24	6	31	2	0.751	-0.079	4.232	0.01	0.007	0	43.9	40.9	71	138	129	0	36	34
2014	9	24	6	41	2	0.774	-0.066	4.229	0.01	0.007	0	44.7	41.3	71	139	130	0	35	34
2014	9	24	6	51	2	0.728	-0.092	4.232	0.013	0.01	0	45.2	41.7	70.1	140	130	0	35	33
2014	9	24	7	1	2	0.735	-0.066	4.232	0.013	0.01	0	44.3	40.4	71.4	138	128	0	35	34
2014	9	24	7	11	2	0.764	-0.098	4.232	0.01	0.007	0	43.9	39.6	71.4	137	127	0	35	35
2014	9	24	7	21	2	0.771	-0.089	4.232	0.013	0.01	0	43	39.1	71.8	135	125	0	35	34
2014	9	24	7	31	2	0.758	-0.092	4.232	0.01	0.007	0	42.6	38.7	71.4	134	125	0	35	35
2014	9	24	7	41	2	0.787	-0.092	4.232	0.013	0.01	0	43	39.6	71.8	135	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	7	51	2	0.784	-0.062	4.232	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	24	8	1	2	0.787	-0.075	4.232	0.01	0.007	0	43.4	39.6	72.2	135	126	0	34	34
2014	9	24	8	11	2	0.778	-0.092	4.232	0.01	0.007	0	42.6	39.1	72.2	135	125	0	36	34
2014	9	24	8	21	2	0.787	-0.092	4.232	0.01	0.007	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	24	8	31	2	0.784	-0.075	4.232	0.01	0.007	0	43	39.1	71.8	135	125	0	35	34
2014	9	24	8	41	2	0.768	-0.069	4.232	0.013	0.01	0	42.6	39.6	72.2	135	126	0	36	34
2014	9	24	8	51	2	0.774	-0.069	4.232	0.01	0.007	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	24	9	1	2	0.761	-0.079	4.232	0.01	0.007	0	43	39.1	72.2	135	125	0	35	34
2014	9	24	9	11	2	0.771	-0.095	4.229	0.01	0.007	0	42.6	39.1	71.4	134	125	0	35	34
2014	9	24	9	21	2	0.784	-0.102	4.232	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	9	31	2	0.784	-0.069	4.229	0.01	0.007	0	42.6	39.6	72.2	134	125	0	35	33
2014	9	24	9	41	2	0.774	-0.062	4.229	0.01	0.007	0	43	39.1	71.8	134	125	0	34	34
2014	9	24	9	51	2	0.771	-0.089	4.226	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	10	1	2	0.774	-0.089	4.222	0.013	0.01	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	10	11	2	0.778	-0.112	4.222	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	10	21	2	0.787	-0.121	4.222	0.01	0.007	0	42.1	39.1	70.1	133	124	0	35	33
2014	9	24	10	31	2	0.787	-0.115	4.222	0.013	0.01	0	42.1	39.1	70.1	133	125	0	35	34
2014	9	24	10	41	2	0.791	-0.082	4.219	0.01	0.007	0	42.6	39.1	64.9	134	125	0	35	34
2014	9	24	10	51	2	0.774	-0.115	4.219	0.01	0.007	0	42.6	38.7	64.9	134	125	0	35	35
2014	9	24	11	1	2	0.787	-0.144	4.219	0.01	0.007	0	42.6	38.3	59.3	133	124	0	34	35
2014	9	24	11	11	2	0.823	-0.108	4.219	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	11	21	2	0.794	-0.125	4.219	0.01	0.007	0	42.1	38.3	59.8	133	124	0	35	35
2014	9	24	11	31	2	0.774	-0.108	4.219	0.01	0.007	0	42.6	39.1	56.8	134	125	0	35	34
2014	9	24	11	41	2	0.797	-0.121	4.219	0.01	0.007	0	42.1	38.7	73.5	133	124	0	35	34
2014	9	24	11	51	2	0.761	-0.112	4.219	0.01	0.007	0	43	39.6	61.9	135	126	0	35	34
2014	9	24	12	1	2	0.804	-0.121	4.216	0.01	0.007	0	43	39.6	63.2	135	126	0	35	34
2014	9	24	12	11	2	0.758	-0.115	4.219	0.01	0.007	0	42.1	39.1	54.2	133	125	0	35	34
2014	9	24	12	21	2	0.774	-0.151	4.216	0.01	0.007	0	42.1	38.7	68.4	133	124	0	35	34
2014	9	24	12	31	2	0.771	-0.141	4.216	0.013	0.01	0	42.1	38.7	57.6	133	124	0	35	34
2014	9	24	12	41	2	0.781	-0.115	4.216	0.01	0.007	0	42.1	38.7	52.9	133	124	0	35	34
2014	9	24	12	51	2	0.778	-0.157	4.216	0.01	0.007	0	42.1	38.7	58	133	124	0	35	34
2014	9	24	13	1	2	0.794	-0.2	4.216	0.01	0.007	0	41.7	38.7	65.4	133	124	0	36	34
2014	9	24	13	11	2	0.787	-0.108	4.216	0.013	0.01	0	42.1	39.6	56.3	134	125	0	36	33
2014	9	24	13	21	2	0.784	-0.141	4.213	0.01	0.007	0	42.6	39.1	71.8	134	125	0	35	34
2014	9	24	13	31	2	0.774	-0.112	4.216	0.01	0.007	0	43	39.6	75.3	135	126	0	35	34
2014	9	24	13	41	2	0.791	-0.125	4.213	0.01	0.007	0	42.6	39.1	56.8	134	125	0	35	34
2014	9	24	13	51	2	0.801	-0.108	4.213	0.01	0.007	0	42.1	39.1	60.2	134	125	0	36	34
2014	9	24	14	1	2	0.794	-0.128	4.213	0.01	0.007	0	42.6	39.1	73.1	134	125	0	35	34
2014	9	24	14	11	2	0.761	-0.144	4.213	0.01	0.007	0	42.6	39.1	54.6	134	125	0	35	34
2014	9	24	14	21	2	0.751	-0.167	4.213	0.01	0.007	0	42.6	39.1	53.8	135	125	0	36	34
2014	9	24	14	31	2	0.751	-0.184	4.213	0.01	0.007	0	42.6	39.1	52.5	134	125	0	35	34
2014	9	24	14	41	2	0.771	-0.131	4.213	0.01	0.007	0	42.6	39.6	52.9	134	126	0	35	34
2014	9	24	14	51	2	0.791	-0.141	4.213	0.01	0.007	0	43	39.6	52.9	135	126	0	35	34
2014	9	24	15	1	2	0.787	-0.148	4.209	0.013	0.01	0	43	39.6	49	135	126	0	35	34
2014	9	24	15	11	2	0.771	-0.157	4.209	0.01	0.007	0	43.4	39.6	52	136	127	0	35	35
2014	9	24	15	21	2	0.797	-0.157	4.209	0.01	0.007	0	43.4	40	49	136	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	15	31	2	0.781	-0.154	4.209	0.01	0.007	0	43.4	40	51.2	136	127	0	35	34
2014	9	24	15	41	2	0.794	-0.118	4.209	0.01	0.007	0	43.4	40.4	49	136	127	0	35	33
2014	9	24	15	51	2	0.768	-0.118	4.206	0.013	0.01	0	43.9	40.4	52	137	128	0	35	34
2014	9	24	16	1	2	0.774	-0.125	4.209	0.01	0.007	0	43.4	40	55	136	127	0	35	34
2014	9	24	16	11	2	0.778	-0.144	4.209	0.01	0.007	0	43.9	40.4	53.3	137	128	0	35	34
2014	9	24	16	21	2	0.771	-0.148	4.206	0.01	0.007	0	42.1	40.4	50.7	133	128	0	35	34
2014	9	24	16	31	2	0.764	-0.138	4.206	0.01	0.007	0	42.1	40	50.3	133	127	0	35	34
2014	9	24	16	41	2	0.755	-0.141	4.206	0.01	0.007	0	42.1	40.4	49	133	128	0	35	34
2014	9	24	16	51	2	0.784	-0.151	4.206	0.013	0.01	0	42.1	40.4	51.6	134	128	0	36	34
2014	9	24	17	1	2	0.768	-0.128	4.206	0.01	0.007	0	42.1	40	52.5	133	128	0	35	35
2014	9	24	17	11	2	0.801	-0.128	4.206	0.013	0.01	0	41.7	40.4	51.2	132	127	0	35	33
2014	9	24	17	21	2	0.771	-0.108	4.206	0.01	0.007	0	42.1	40.4	50.3	133	128	0	35	34
2014	9	24	17	31	2	0.738	-0.089	4.206	0.01	0.007	0	42.1	40.4	50.7	133	128	0	35	34
2014	9	24	17	41	2	0.771	-0.118	4.206	0.01	0.007	0	42.1	40.4	52.9	133	128	0	35	34
2014	9	24	17	51	2	0.751	-0.144	4.203	0.01	0.007	0	42.1	40.4	49.5	133	128	0	35	34
2014	9	24	18	1	2	0.771	-0.131	4.206	0.01	0.007	0	42.1	40	49.5	133	127	0	35	34
2014	9	24	18	11	2	0.755	-0.098	4.206	0.01	0.007	0	42.6	40.4	51.2	134	128	0	35	34
2014	9	24	18	21	2	0.787	-0.115	4.206	0.013	0.01	0	42.1	40	52.5	133	127	0	35	34
2014	9	24	18	31	2	0.764	-0.089	4.206	0.013	0.01	0	43.4	41.3	58.9	136	130	0	35	34
2014	9	24	18	41	2	0.768	-0.095	4.206	0.01	0.007	0	42.1	40	61.1	133	127	0	35	34
2014	9	24	18	51	2	0.784	-0.135	4.206	0.013	0.01	0	42.1	40.4	58.5	133	128	0	35	34
2014	9	24	19	1	2	0.758	-0.085	4.206	0.01	0.007	0	42.6	40.9	52.9	134	129	0	35	34
2014	9	24	19	11	2	0.771	-0.089	4.206	0.01	0.007	0	42.1	40.4	54.6	133	128	0	35	34
2014	9	24	19	21	2	0.768	-0.125	4.206	0.01	0.007	0	43	40.9	56.3	135	129	0	35	34
2014	9	24	19	31	2	0.778	-0.102	4.206	0.01	0.007	0	43	41.3	54.6	135	130	0	35	34
2014	9	24	19	41	2	0.755	-0.082	4.206	0.01	0.007	0	42.6	41.3	52.9	135	130	0	36	34
2014	9	24	19	51	2	0.758	-0.108	4.206	0.01	0.007	0	43	40.9	52.9	135	129	0	35	34
2014	9	24	20	1	2	0.771	-0.131	4.206	0.01	0.007	0	42.6	40.9	56.3	135	129	0	36	34
2014	9	24	20	11	2	0.787	-0.105	4.206	0.013	0.01	0	43.4	41.7	54.2	137	131	0	36	34
2014	9	24	20	21	2	0.741	-0.092	4.206	0.01	0.007	0	43	40.9	54.6	135	129	0	35	34
2014	9	24	20	31	2	0.755	-0.108	4.206	0.01	0.007	0	42.6	40.4	53.8	134	129	0	35	35
2014	9	24	20	41	2	0.755	-0.105	4.209	0.01	0.007	0	43	40.9	53.8	135	129	0	35	34
2014	9	24	20	51	2	0.761	-0.095	4.206	0.01	0.007	0	42.1	41.3	57.2	134	129	0	36	33
2014	9	24	21	1	2	0.801	-0.108	4.209	0.01	0.007	0	42.6	40.4	61.9	134	128	0	35	34
2014	9	24	21	11	2	0.801	-0.125	4.209	0.01	0.007	0	42.1	40.4	60.2	133	128	0	35	34
2014	9	24	21	21	2	0.741	-0.085	4.209	0.01	0.007	0	42.6	40.4	61.1	134	128	0	35	34
2014	9	24	21	31	2	0.758	-0.095	4.209	0.01	0.007	0	42.1	40.4	55	134	128	0	36	34
2014	9	24	21	41	2	0.781	-0.095	4.209	0.01	0.007	0	42.6	40.4	55.9	134	128	0	35	34
2014	9	24	21	51	2	0.774	-0.089	4.209	0.016	0.016	0	42.6	40.9	57.6	134	128	0	35	33
2014	9	24	22	1	2	0.807	-0.121	4.206	0.01	0.007	0	42.6	40.4	51.6	134	128	0	35	34
2014	9	24	22	11	2	0.751	-0.125	4.209	0.01	0.007	0	42.6	40	52.9	133	127	0	34	34
2014	9	24	22	21	2	0.758	-0.118	4.209	0.01	0.007	0	42.1	40.4	74.4	133	128	0	35	34
2014	9	24	22	31	2	0.794	-0.108	4.209	0.013	0.01	0	42.6	40.9	58.9	134	128	0	35	33
2014	9	24	22	41	2	0.758	-0.108	4.209	0.01	0.007	0	42.6	40.9	55.9	134	129	0	35	34
2014	9	24	22	51	2	0.774	-0.141	4.209	0.01	0.007	0	42.6	40.4	64.1	134	128	0	35	34
2014	9	24	23	1	2	0.738	-0.105	4.209	0.01	0.007	0	42.6	40.4	62.8	134	128	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	23	11	2	0.774	-0.121	4.209	0.013	0.01	0	42.1	40.9	62.4	134	129	0	36	34
2014	9	24	23	21	2	0.778	-0.141	4.209	0.01	0.007	0	42.1	40	67.1	133	127	0	35	34
2014	9	24	23	31	2	0.761	-0.108	4.209	0.01	0.007	0	41.7	40.4	57.2	133	128	0	36	34
2014	9	24	23	41	2	0.728	-0.118	4.209	0.01	0.007	0	43	40.4	74.4	135	128	0	35	34
2014	9	24	23	51	2	0.735	-0.151	4.209	0.016	0.013	0	43	40.9	76.1	135	128	0	35	33
2014	9	25	0	1	2	0.741	-0.066	4.209	0.01	0.007	0	42.6	40.9	56.3	135	129	0	36	34
2014	9	25	0	11	2	0.745	-0.125	4.209	0.016	0.013	0	42.6	40.4	72.7	134	128	0	35	34
2014	9	25	0	21	2	0.774	-0.151	4.209	0.01	0.007	0	42.1	40	55.5	133	127	0	35	34
2014	9	25	0	31	2	0.758	-0.112	4.209	0.01	0.007	0	42.1	40.4	67.9	134	128	0	36	34
2014	9	25	0	41	2	0.745	-0.128	4.213	0.01	0.007	0	43.4	41.3	75.3	135	129	0	34	33
2014	9	25	0	51	2	0.725	-0.161	4.213	0.013	0.01	0	43	40.4	73.5	135	128	0	35	34
2014	9	25	1	1	2	0.702	-0.108	4.209	0.016	0.013	0	42.6	40.4	68.4	134	128	0	35	34
2014	9	25	1	11	2	0.781	-0.089	4.209	0.01	0.007	0	41.7	39.6	48.2	132	127	0	35	35
2014	9	25	1	21	2	0.787	-0.125	4.209	0.013	0.01	0	42.1	40	49	133	127	0	35	34
2014	9	25	1	31	2	0.751	-0.102	4.209	0.01	0.007	0	43	41.3	49.9	135	129	0	35	33
2014	9	25	1	41	2	0.738	-0.066	4.209	0.01	0.007	0	43.4	41.3	59.8	136	130	0	35	34
2014	9	25	1	51	2	0.741	-0.125	4.209	0.01	0.007	0	43	40.9	70.1	135	129	0	35	34
2014	9	25	2	1	2	0.715	-0.148	4.209	0.013	0.01	0	43	40.9	74.8	136	129	0	36	34
2014	9	25	2	11	2	0.696	-0.161	4.209	0.01	0.007	0	43.4	41.3	75.3	136	130	0	35	34
2014	9	25	2	21	2	0.712	-0.177	4.213	0.01	0.007	0	42.6	40.9	75.3	135	129	0	36	34
2014	9	25	2	31	2	0.699	-0.112	4.213	0.01	0.007	0	43	40.9	73.1	135	129	0	35	34
2014	9	25	2	41	2	0.745	-0.102	4.209	0.01	0.007	0	43	41.3	60.6	136	130	0	36	34
2014	9	25	2	51	2	0.745	-0.095	4.209	0.01	0.007	0	43.9	41.7	60.2	137	131	0	35	34
2014	9	25	3	1	2	0.715	-0.131	4.209	0.01	0.007	0	43	40.9	75.3	135	129	0	35	34
2014	9	25	3	11	2	0.722	-0.125	4.209	0.01	0.007	0	43	40.9	75.7	135	129	0	35	34
2014	9	25	3	21	2	0.741	-0.112	4.209	0.01	0.007	0	42.6	40.4	75.7	134	128	0	35	34
2014	9	25	3	31	2	0.715	-0.154	4.209	0.01	0.007	0	42.6	40.4	74	134	128	0	35	34
2014	9	25	3	41	2	0.748	-0.108	4.209	0.016	0.013	0	42.6	40.9	69.2	134	129	0	35	34
2014	9	25	3	51	2	0.735	-0.125	4.209	0.01	0.007	0	42.1	40.4	67.5	133	128	0	35	34
2014	9	25	4	1	2	0.725	-0.115	4.209	0.01	0.007	0	42.6	40.4	75.7	134	128	0	35	34
2014	9	25	4	11	2	0.741	-0.102	4.209	0.01	0.007	0	42.1	40	75.7	133	127	0	35	34
2014	9	25	4	21	2	0.761	-0.092	4.209	0.01	0.007	0	42.6	40.4	60.6	134	128	0	35	34
2014	9	25	4	31	2	0.732	-0.108	4.209	0.01	0.007	0	43	40.9	75.7	135	129	0	35	34
2014	9	25	4	41	2	0.741	-0.112	4.209	0.01	0.007	0	43	40.9	76.1	135	129	0	35	34
2014	9	25	4	51	2	0.758	-0.135	4.209	0.013	0.01	0	42.6	40.4	75.7	134	128	0	35	34
2014	9	25	5	1	2	0.728	-0.144	4.209	0.013	0.01	0	42.6	41.3	75.7	134	129	0	35	33
2014	9	25	5	11	2	0.732	-0.115	4.209	0.01	0.007	0	42.6	40.4	74.4	134	128	0	35	34
2014	9	25	5	21	2	0.745	-0.102	4.213	0.013	0.01	0	42.1	40	58.5	133	127	0	35	34
2014	9	25	5	31	2	0.768	-0.118	4.213	0.013	0.01	0	41.7	40	56.8	132	127	0	35	34
2014	9	25	5	41	2	0.778	-0.095	4.213	0.016	0.013	0	43.9	40.4	56.3	137	128	0	35	34
2014	9	25	5	51	2	0.787	-0.157	4.213	0.01	0.007	0	45.2	42.1	51.6	140	132	0	35	34
2014	9	25	6	1	2	0.758	-0.095	4.209	0.01	0.007	0	44.7	41.3	60.2	139	130	0	35	34
2014	9	25	6	11	2	0.784	-0.112	4.213	0.01	0.007	0	45.2	41.7	55.5	140	131	0	35	34
2014	9	25	6	21	2	0.758	-0.102	4.213	0.01	0.007	0	44.7	41.3	55	139	130	0	35	34
2014	9	25	6	31	2	0.771	-0.092	4.213	0.01	0.007	0	43.9	40.9	73.1	138	129	0	36	34
2014	9	25	6	41	2	0.771	-0.095	4.213	0.01	0.007	0	44.3	40.4	59.3	137	128	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	6	51	2	0.771	-0.089	4.213	0.01	0.007	0	43.9	40.4	73.1	137	128	0	35	34
2014	9	25	7	1	2	0.784	-0.108	4.213	0.01	0.007	0	43.4	40	73.5	136	127	0	35	34
2014	9	25	7	11	2	0.774	-0.062	4.213	0.01	0.007	0	43.4	40.4	52.9	136	127	0	35	33
2014	9	25	7	21	2	0.771	-0.105	4.213	0.01	0.007	0	43	39.1	54.2	135	126	0	35	35
2014	9	25	7	31	2	0.758	-0.102	4.213	0.01	0.007	0	43	40	53.3	135	126	0	35	33
2014	9	25	7	41	2	0.771	-0.135	4.213	0.01	0.007	0	42.6	40	50.7	135	126	0	36	33
2014	9	25	7	51	2	0.758	-0.072	4.213	0.013	0.01	0	43.4	40	49.9	136	127	0	35	34
2014	9	25	8	1	2	0.761	-0.079	4.213	0.01	0.007	0	43.4	40.4	51.2	137	128	0	36	34
2014	9	25	8	11	2	0.787	-0.098	4.213	0.01	0.007	0	43.9	40.9	49.9	137	128	0	35	33
2014	9	25	8	21	2	0.764	-0.089	4.216	0.016	0.013	0	44.3	40.9	50.7	138	129	0	35	34
2014	9	25	8	31	2	0.758	-0.082	4.213	0.01	0.007	0	45.2	42.1	50.3	140	132	0	35	34
2014	9	25	8	41	2	0.774	-0.098	4.209	0.01	0.007	0	46.4	43	50.3	143	134	0	35	34
2014	9	25	8	51	2	0.728	-0.092	4.206	0.013	0.01	0	46.9	43.4	48.2	144	135	0	35	34
2014	9	25	9	1	2	0.784	-0.062	4.213	0.013	0.01	0	48.6	45.6	46.4	148	140	0	35	34
2014	9	25	9	11	2	0.748	-0.072	4.203	0.01	0.007	0	49	46	46.4	149	141	0	35	34
2014	9	25	9	21	2	0.768	-0.075	4.213	0.01	0.007	0	50.3	46.4	48.2	152	143	0	35	35
2014	9	25	9	31	2	0.745	-0.102	4.209	0.013	0.01	0	50.3	46.9	46	152	143	0	35	34
2014	9	25	9	41	2	0.732	-0.089	4.203	0.01	0.007	0	50.3	47.3	47.3	153	144	0	36	34
2014	9	25	9	51	2	0.725	-0.043	4.203	0.01	0.007	0	51.2	48.2	46	154	146	0	35	34
2014	9	25	10	1	2	0.738	-0.072	4.203	0.013	0.01	0	51.6	48.2	44.3	155	146	0	35	34
2014	9	25	10	11	2	0.741	-0.082	4.203	0.016	0.013	0	51.2	48.2	46	154	146	0	35	34
2014	9	25	10	21	2	0.761	-0.062	4.203	0.013	0.01	0	51.2	48.2	47.3	154	146	0	35	34
2014	9	25	10	31	2	0.715	-0.079	4.199	0.013	0.01	0	50.3	47.3	46.9	152	144	0	35	34
2014	9	25	10	41	2	0.748	-0.072	4.209	0.01	0.007	0	50.3	46.9	46.4	152	143	0	35	34
2014	9	25	10	51	2	0.745	-0.062	4.206	0.01	0.007	0	51.6	47.7	46	154	145	0	34	34
2014	9	25	11	1	2	0.758	-0.108	4.199	0.016	0.016	0	49.9	46.9	45.2	151	143	0	35	34
2014	9	25	11	11	2	0.732	-0.079	4.206	0.013	0.01	0	49.5	46.9	45.6	151	143	0	36	34
2014	9	25	11	21	2	0.738	-0.072	4.199	0.016	0.013	0	49.9	47.3	46	152	144	0	36	34
2014	9	25	11	31	2	0.741	-0.108	4.203	0.01	0.007	0	49.9	46.9	46.4	151	143	0	35	34
2014	9	25	11	41	2	0.774	-0.089	4.199	0.01	0.007	0	49.5	46.4	46.4	150	142	0	35	34
2014	9	25	11	51	2	0.732	-0.049	4.199	0.013	0.01	0	49.5	46.4	46.9	150	142	0	35	34
2014	9	25	12	1	2	0.791	-0.105	4.199	0.01	0.007	0	49.5	46	48.2	149	141	0	34	34
2014	9	25	12	11	2	0.758	-0.095	4.196	0.013	0.01	0	49	46	48.2	149	141	0	35	34
2014	9	25	12	21	2	0.791	-0.085	4.206	0.013	0.01	0	49	46	48.2	149	141	0	35	34
2014	9	25	12	31	2	0.735	-0.079	4.203	0.01	0.007	0	48.6	45.6	49	148	140	0	35	34
2014	9	25	12	41	2	0.758	-0.095	4.199	0.01	0.007	0	48.2	45.2	48.6	147	139	0	35	34
2014	9	25	12	51	2	0.748	-0.062	4.203	0.01	0.007	0	48.2	45.2	45.6	147	139	0	35	34
2014	9	25	13	1	2	0.781	-0.082	4.199	0.01	0.007	0	48.2	45.2	48.6	147	139	0	35	34
2014	9	25	13	11	2	0.781	-0.072	4.199	0.016	0.016	0	47.7	44.7	49	146	138	0	35	34
2014	9	25	13	21	2	0.761	-0.082	4.199	0.01	0.007	0	47.3	44.3	48.6	145	137	0	35	34
2014	9	25	13	31	2	0.768	-0.092	4.193	0.013	0.01	0	46.9	43.9	47.3	144	136	0	35	34
2014	9	25	13	41	2	0.771	-0.115	4.199	0.016	0.013	0	46.4	43.9	47.7	143	136	0	35	34
2014	9	25	13	51	2	0.738	-0.039	4.196	0.01	0.007	0	46.9	43.9	47.3	144	136	0	35	34
2014	9	25	14	1	2	0.761	-0.079	4.196	0.01	0.007	0	46.9	44.3	48.2	144	136	0	35	33
2014	9	25	14	11	2	0.735	-0.092	4.193	0.016	0.013	0	47.3	43.9	48.2	144	136	0	34	34
2014	9	25	14	21	2	0.741	-0.092	4.196	0.01	0.007	0	46.4	43.4	46.4	143	135	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	14	31	2	0.764	-0.056	4.186	0.01	0.007	0	46.4	43.4	48.2	143	135	0	35	34
2014	9	25	14	41	2	0.745	-0.072	4.196	0.01	0.007	0	45.6	42.6	50.3	141	133	0	35	34
2014	9	25	14	51	2	0.728	-0.125	4.186	0.01	0.007	0	45.2	42.6	47.7	140	133	0	35	34
2014	9	25	15	1	2	0.696	-0.135	4.186	0.01	0.007	0	45.6	41.7	45.6	140	131	0	34	34
2014	9	25	15	11	2	0.741	-0.171	4.193	0.01	0.007	0	44.7	42.1	48.2	140	132	0	36	34
2014	9	25	15	21	2	0.728	-0.105	4.193	0.01	0.007	0	45.2	41.7	48.2	140	131	0	35	34
2014	9	25	15	31	2	0.774	-0.095	4.19	0.013	0.01	0	45.2	42.1	49	140	132	0	35	34
2014	9	25	15	41	2	0.768	-0.102	4.193	0.01	0.007	0	45.2	42.1	50.3	140	132	0	35	34
2014	9	25	15	51	2	0.751	-0.066	4.186	0.01	0.007	0	44.7	41.7	49	139	131	0	35	34
2014	9	25	16	1	2	0.758	-0.079	4.186	0.013	0.01	0	44.3	41.7	48.2	139	131	0	36	34
2014	9	25	16	11	2	0.761	-0.112	4.193	0.01	0.007	0	45.2	42.1	48.2	140	132	0	35	34
2014	9	25	16	21	2	0.755	-0.108	4.186	0.01	0.007	0	44.3	41.3	50.7	138	130	0	35	34
2014	9	25	16	31	2	0.735	-0.125	4.183	0.01	0.007	0	44.3	41.3	49.5	138	130	0	35	34
2014	9	25	16	41	2	0.761	-0.115	4.183	0.01	0.007	0	44.3	42.1	49.5	138	131	0	35	33
2014	9	25	16	51	2	0.745	-0.095	4.186	0.016	0.013	0	44.3	41.3	49	138	130	0	35	34
2014	9	25	17	1	2	0.758	-0.118	4.183	0.01	0.007	0	44.3	41.7	49.5	138	130	0	35	33
2014	9	25	17	11	2	0.764	-0.128	4.186	0.01	0.007	0	43.9	40.4	49.5	137	129	0	35	35
2014	9	25	17	21	2	0.774	-0.098	4.186	0.01	0.007	0	44.3	40.9	49	138	129	0	35	34
2014	9	25	17	31	2	0.732	-0.072	4.183	0.01	0.007	0	44.7	41.3	49.9	138	130	0	34	34
2014	9	25	17	41	2	0.732	-0.085	4.19	0.01	0.007	0	44.3	41.3	49.5	138	130	0	35	34
2014	9	25	17	51	2	0.745	-0.066	4.186	0.01	0.007	0	44.7	42.6	49	140	132	0	36	33
2014	9	25	18	1	2	0.761	-0.105	4.183	0.01	0.007	0	44.3	41.3	49.5	138	130	0	35	34
2014	9	25	18	11	2	0.774	-0.105	4.186	0.013	0.01	0	44.7	41.7	50.3	139	131	0	35	34
2014	9	25	18	21	2	0.748	-0.079	4.186	0.01	0.007	0	44.7	41.3	48.2	139	130	0	35	34
2014	9	25	18	31	2	0.738	-0.072	4.186	0.01	0.007	0	45.2	41.7	47.7	140	131	0	35	34
2014	9	25	18	41	2	0.745	-0.105	4.19	0.013	0.01	0	44.3	40.9	49.5	138	129	0	35	34
2014	9	25	18	51	2	0.732	-0.072	4.186	0.01	0.007	0	44.7	41.7	49.9	139	131	0	35	34
2014	9	25	19	1	2	0.751	-0.066	4.186	0.013	0.01	0	44.3	41.3	48.2	138	130	0	35	34
2014	9	25	19	11	2	0.748	-0.062	4.183	0.01	0.007	0	45.2	42.6	51.6	141	133	0	36	34
2014	9	25	19	21	2	0.774	-0.075	4.186	0.016	0.013	0	45.2	41.7	49.5	140	131	0	35	34
2014	9	25	19	31	2	0.719	-0.066	4.186	0.01	0.007	0	45.6	42.1	48.6	141	132	0	35	34
2014	9	25	19	41	2	0.738	-0.049	4.183	0.013	0.01	0	45.6	42.6	47.7	141	133	0	35	34
2014	9	25	19	51	2	0.732	-0.066	4.186	0.01	0.007	0	46	43	46.9	142	134	0	35	34
2014	9	25	20	1	2	0.751	-0.079	4.18	0.016	0.013	0	46	43	49.9	142	134	0	35	34
2014	9	25	20	11	2	0.751	-0.118	4.186	0.01	0.007	0	45.6	42.6	49	141	133	0	35	34
2014	9	25	20	21	2	0.741	-0.069	4.183	0.01	0.007	0	45.2	41.7	49.5	140	131	0	35	34
2014	9	25	20	31	2	0.745	-0.066	4.186	0.01	0.007	0	45.2	42.1	47.7	140	132	0	35	34
2014	9	25	20	41	2	0.764	-0.056	4.186	0.013	0.01	0	45.2	42.1	49.9	140	132	0	35	34
2014	9	25	20	51	2	0.745	-0.059	4.186	0.01	0.007	0	45.6	41.7	48.2	141	131	0	35	34
2014	9	25	21	1	2	0.771	-0.062	4.193	0.01	0.007	0	46	41.7	49.9	143	132	0	36	35
2014	9	25	21	11	2	0.735	-0.075	4.186	0.01	0.007	0	46	42.1	48.6	142	132	0	35	34
2014	9	25	21	21	2	0.771	-0.072	4.186	0.01	0.007	0	46	42.1	49.5	142	132	0	35	34
2014	9	25	21	31	2	0.748	-0.052	4.183	0.01	0.007	0	45.6	41.7	48.6	141	131	0	35	34
2014	9	25	21	41	2	0.758	-0.085	4.186	0.01	0.007	0	46	41.7	51.2	142	131	0	35	34
2014	9	25	21	51	2	0.758	-0.079	4.19	0.01	0.007	0	45.6	41.7	50.7	141	131	0	35	34
2014	9	25	22	1	2	0.781	-0.072	4.186	0.016	0.013	0	45.6	42.1	47.7	142	132	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	22	11	2	0.748	-0.105	4.19	0.01	0.007	0	45.6	41.3	49.9	141	131	0	35	35
2014	9	25	22	21	2	0.748	-0.095	4.193	0.01	0.007	0	45.2	41.3	48.6	140	130	0	35	34
2014	9	25	22	31	2	0.755	-0.105	4.19	0.01	0.007	0	44.7	41.7	51.2	140	130	0	36	33
2014	9	25	22	41	2	0.751	-0.059	4.19	0.01	0.007	0	45.6	41.7	49.9	141	131	0	35	34
2014	9	25	22	51	2	0.748	-0.098	4.19	0.01	0.007	0	45.2	41.3	50.7	140	130	0	35	34
2014	9	25	23	1	2	0.722	-0.089	4.19	0.01	0.007	0	45.2	41.7	50.3	140	131	0	35	34
2014	9	25	23	11	2	0.732	-0.085	4.19	0.013	0.01	0	45.2	41.3	49	140	130	0	35	34
2014	9	25	23	21	2	0.794	-0.079	4.193	0.01	0.007	0	44.7	40.9	48.6	138	129	0	34	34
2014	9	25	23	31	2	0.768	-0.085	4.186	0.013	0.01	0	44.3	40.4	49.9	138	128	0	35	34
2014	9	25	23	41	2	0.741	-0.085	4.19	0.01	0.007	0	45.6	42.1	50.7	141	131	0	35	33
2014	9	25	23	51	2	0.781	-0.089	4.186	0.01	0.007	0	44.7	41.3	51.6	139	129	0	35	33
2014	9	26	0	1	2	0.745	-0.102	4.19	0.01	0.007	0	45.2	40.9	49	140	129	0	35	34
2014	9	26	0	11	2	0.748	-0.066	4.19	0.016	0.013	0	44.7	40.9	50.3	140	129	0	36	34
2014	9	26	0	21	2	0.748	-0.069	4.193	0.01	0.007	0	44.7	40.9	50.7	139	129	0	35	34
2014	9	26	0	31	2	0.771	-0.072	4.186	0.01	0.007	0	44.3	40	50.7	138	128	0	35	35
2014	9	26	0	41	2	0.741	-0.118	4.183	0.01	0.007	0	44.3	40.4	49	138	128	0	35	34
2014	9	26	0	51	2	0.715	-0.095	4.19	0.013	0.01	0	44.3	40.4	51.2	139	129	0	36	35
2014	9	26	1	1	2	0.761	-0.092	4.186	0.01	0.007	0	45.6	42.6	49.9	141	132	0	35	33
2014	9	26	1	11	2	0.768	-0.092	4.19	0.01	0.007	0	45.2	41.7	48.2	140	131	0	35	34
2014	9	26	1	21	2	0.741	-0.079	4.19	0.01	0.007	0	44.7	41.3	50.7	139	130	0	35	34
2014	9	26	1	31	2	0.758	-0.075	4.19	0.01	0.007	0	45.6	41.7	49.5	141	131	0	35	34
2014	9	26	1	41	2	0.732	-0.085	4.193	0.01	0.007	0	46.4	42.6	49.9	142	133	0	34	34
2014	9	26	1	51	2	0.748	-0.059	4.19	0.01	0.007	0	44.7	41.3	49	139	130	0	35	34
2014	9	26	2	1	2	0.738	-0.079	4.193	0.01	0.007	0	44.7	41.3	49	139	130	0	35	34
2014	9	26	2	11	2	0.748	-0.079	4.19	0.01	0.007	0	44.7	41.3	48.6	139	130	0	35	34
2014	9	26	2	21	2	0.741	-0.079	4.196	0.01	0.007	0	44.7	41.3	49.9	139	130	0	35	34
2014	9	26	2	31	2	0.745	-0.082	4.19	0.01	0.007	0	44.7	40.9	50.7	139	129	0	35	34
2014	9	26	2	41	2	0.791	-0.095	4.193	0.01	0.007	0	44.7	41.3	49.5	139	130	0	35	34
2014	9	26	2	51	2	0.771	-0.082	4.196	0.013	0.01	0	44.7	41.3	50.7	139	130	0	35	34
2014	9	26	3	1	2	0.751	-0.108	4.193	0.01	0.007	0	44.7	41.3	51.6	139	130	0	35	34
2014	9	26	3	11	2	0.771	-0.072	4.193	0.013	0.01	0	43.9	41.3	52.9	138	129	0	36	33
2014	9	26	3	21	2	0.751	-0.075	4.196	0.01	0.007	0	44.7	40.9	49.5	138	129	0	34	34
2014	9	26	3	31	2	0.764	-0.105	4.193	0.01	0.007	0	43.9	40.4	52.5	137	128	0	35	34
2014	9	26	3	41	2	0.787	-0.082	4.193	0.01	0.007	0	44.3	40.9	49.5	138	128	0	35	33
2014	9	26	3	51	2	0.761	-0.095	4.196	0.01	0.007	0	43.9	40	49.9	137	128	0	35	35
2014	9	26	4	1	2	0.748	-0.066	4.196	0.01	0.007	0	44.7	40.9	48.6	139	129	0	35	34
2014	9	26	4	11	2	0.748	-0.082	4.196	0.01	0.007	0	44.3	40.4	48.6	138	129	0	35	35
2014	9	26	4	21	2	0.748	-0.089	4.196	0.01	0.007	0	44.3	40.9	50.3	138	129	0	35	34
2014	9	26	4	31	2	0.764	-0.082	4.196	0.01	0.007	0	44.7	41.3	49	139	130	0	35	34
2014	9	26	4	41	2	0.745	-0.112	4.196	0.01	0.007	0	45.6	42.1	49	141	132	0	35	34
2014	9	26	4	51	2	0.768	-0.095	4.193	0.01	0.007	0	43.4	40.9	50.7	137	129	0	36	34
2014	9	26	5	1	2	0.791	-0.102	4.196	0.01	0.007	0	44.3	40.9	51.2	138	129	0	35	34
2014	9	26	5	11	2	0.781	-0.089	4.193	0.01	0.007	0	43.9	40.4	52.9	137	128	0	35	34
2014	9	26	5	21	2	0.758	-0.102	4.196	0.01	0.007	0	44.3	40.4	50.3	138	128	0	35	34
2014	9	26	5	31	2	0.755	-0.089	4.193	0.01	0.007	0	43.9	40.9	49.5	137	129	0	35	34
2014	9	26	5	41	2	0.758	-0.069	4.196	0.01	0.007	0	44.7	41.3	50.7	139	130	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	5	51	2	0.778	-0.079	4.193	0.01	0.007	0	44.3	40.9	49.9	138	128	0	35	33
2014	9	26	6	1	2	0.761	-0.095	4.193	0.013	0.01	0	44.3	40.9	51.2	138	129	0	35	34
2014	9	26	6	11	2	0.774	-0.105	4.196	0.01	0.007	0	45.2	42.1	61.9	140	131	0	35	33
2014	9	26	6	21	2	0.764	-0.072	4.196	0.01	0.007	0	44.7	41.3	55.5	139	130	0	35	34
2014	9	26	6	31	2	0.768	-0.079	4.193	0.01	0.007	0	44.3	40.9	58	138	129	0	35	34
2014	9	26	6	41	2	0.728	-0.085	4.193	0.013	0.01	0	44.3	40.9	52.5	138	129	0	35	34
2014	9	26	6	51	2	0.745	-0.066	4.193	0.01	0.007	0	43.9	40	54.6	137	127	0	35	34
2014	9	26	7	1	2	0.761	-0.098	4.193	0.013	0.01	0	43	39.6	51.6	135	126	0	35	34
2014	9	26	7	11	2	0.728	-0.046	4.196	0.01	0.007	0	43.9	40.4	49	137	127	0	35	33
2014	9	26	7	21	2	0.774	-0.095	4.193	0.01	0.007	0	43	40	51.6	135	126	0	35	33
2014	9	26	7	31	2	0.761	-0.092	4.196	0.013	0.01	0	43	39.6	51.6	135	126	0	35	34
2014	9	26	7	41	2	0.755	-0.072	4.196	0.01	0.007	0	43	39.6	51.6	135	126	0	35	34
2014	9	26	7	51	2	0.748	-0.072	4.193	0.01	0.007	0	43.4	39.6	52.5	136	126	0	35	34
2014	9	26	8	1	2	0.758	-0.079	4.193	0.01	0.007	0	43.4	39.6	55	135	126	0	34	34
2014	9	26	8	11	2	0.755	-0.049	4.193	0.013	0.01	0	43	39.6	55.5	135	126	0	35	34
2014	9	26	8	21	2	0.758	-0.085	4.193	0.01	0.007	0	42.6	39.6	55	134	125	0	35	33
2014	9	26	8	31	2	0.755	-0.115	4.193	0.01	0.007	0	42.6	39.6	50.3	134	126	0	35	34
2014	9	26	8	41	2	0.768	-0.095	4.19	0.01	0.007	0	42.6	39.6	50.3	135	126	0	36	34
2014	9	26	8	51	2	0.758	-0.075	4.193	0.01	0.007	0	42.1	39.6	49.9	134	126	0	36	34
2014	9	26	9	1	2	0.741	-0.102	4.193	0.01	0.007	0	42.6	40	49.9	134	126	0	35	33
2014	9	26	9	11	2	0.728	-0.112	4.196	0.013	0.01	0	43	39.6	49.9	135	126	0	35	34
2014	9	26	9	21	2	0.722	-0.072	4.193	0.01	0.007	0	43	40	48.2	135	127	0	35	34
2014	9	26	9	31	2	0.801	-0.095	4.186	0.01	0.007	0	43	40	50.7	135	126	0	35	33
2014	9	26	9	41	2	0.722	-0.098	4.19	0.01	0.007	0	43	40	49.9	135	127	0	35	34
2014	9	26	9	51	2	0.748	-0.089	4.19	0.01	0.007	0	43	39.6	49	135	126	0	35	34
2014	9	26	10	1	2	0.745	-0.079	4.186	0.01	0.007	0	42.6	39.6	50.3	134	126	0	35	34
2014	9	26	10	11	2	0.755	-0.056	4.186	0.01	0.007	0	43	39.6	52	135	126	0	35	34
2014	9	26	10	21	2	0.748	-0.121	4.186	0.01	0.007	0	43.4	39.6	51.2	135	126	0	34	34
2014	9	26	10	31	2	0.748	-0.128	4.183	0.01	0.007	0	42.6	39.1	49	134	125	0	35	34
2014	9	26	10	41	2	0.761	-0.095	4.18	0.01	0.007	0	43.4	40.4	49.5	136	128	0	35	34
2014	9	26	10	51	2	0.787	-0.108	4.18	0.01	0.007	0	44.3	40.9	48.6	138	129	0	35	34
2014	9	26	11	1	2	0.738	-0.072	4.177	0.01	0.007	0	44.3	41.3	48.6	138	130	0	35	34
2014	9	26	11	11	2	0.719	-0.079	4.183	0.01	0.007	0	44.3	41.3	48.6	138	130	0	35	34
2014	9	26	11	21	2	0.741	-0.069	4.177	0.01	0.007	0	45.6	42.6	49	141	133	0	35	34
2014	9	26	11	31	2	0.755	-0.066	4.183	0.01	0.007	0	45.2	42.1	49.5	141	132	0	36	34
2014	9	26	11	41	2	0.748	-0.066	4.177	0.01	0.007	0	46	43	47.7	142	134	0	35	34
2014	9	26	11	51	2	0.748	-0.079	4.177	0.01	0.007	0	46.9	44.3	45.6	144	136	0	35	33
2014	9	26	12	1	2	0.715	-0.112	4.177	0.01	0.007	0	46.9	43	49	143	134	0	34	34
2014	9	26	12	11	2	0.735	-0.095	4.173	0.01	0.007	0	46.4	43	47.3	143	134	0	35	34
2014	9	26	12	21	2	0.755	-0.072	4.173	0.013	0.01	0	46.4	43	47.3	143	134	0	35	34
2014	9	26	12	31	2	0.748	-0.049	4.173	0.01	0.007	0	47.7	44.3	46.9	146	137	0	35	34
2014	9	26	12	41	2	0.722	-0.089	4.173	0.016	0.013	0	48.2	45.2	47.3	147	139	0	35	34
2014	9	26	12	51	2	0.745	-0.082	4.18	0.01	0.007	0	48.2	44.7	48.2	147	138	0	35	34
2014	9	26	13	1	2	0.748	-0.075	4.173	0.01	0.007	0	47.7	44.3	49	146	138	0	35	35
2014	9	26	13	11	2	0.719	-0.085	4.17	0.013	0.01	0	48.6	44.7	45.6	147	138	0	34	34
2014	9	26	13	21	2	0.732	-0.079	4.167	0.013	0.01	0	48.2	45.2	48.2	147	138	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	13	31	2	0.748	-0.066	4.173	0.013	0.01	0	47.7	44.7	47.7	146	138	0	35	34
2014	9	26	13	41	2	0.741	-0.079	4.17	0.01	0.007	0	47.7	44.7	49.5	146	138	0	35	34
2014	9	26	13	51	2	0.735	-0.079	4.167	0.01	0.007	0	48.2	45.2	47.3	147	139	0	35	34
2014	9	26	14	1	2	0.719	-0.069	4.163	0.013	0.01	0	48.2	45.6	46.4	148	140	0	36	34
2014	9	26	14	11	2	0.748	-0.105	4.167	0.013	0.01	0	48.2	44.7	49.9	147	138	0	35	34
2014	9	26	14	21	2	0.722	-0.062	4.167	0.01	0.007	0	47.7	45.2	46	146	138	0	35	33
2014	9	26	14	31	2	0.738	-0.082	4.167	0.013	0.01	0	48.2	45.2	48.2	147	139	0	35	34
2014	9	26	14	41	2	0.715	-0.046	4.167	0.01	0.007	0	47.7	44.3	49	146	137	0	35	34
2014	9	26	14	51	2	0.715	-0.062	4.163	0.01	0.007	0	47.7	44.3	49.5	146	138	0	35	35
2014	9	26	15	1	2	0.715	-0.052	4.16	0.01	0.007	0	47.3	44.3	47.7	145	137	0	35	34
2014	9	26	15	11	2	0.755	-0.066	4.163	0.01	0.007	0	47.3	44.7	47.7	146	138	0	36	34
2014	9	26	15	21	2	0.751	-0.059	4.16	0.01	0.007	0	47.3	44.3	47.3	145	137	0	35	34
2014	9	26	15	31	2	0.709	-0.052	4.157	0.01	0.007	0	47.7	44.3	48.2	146	137	0	35	34
2014	9	26	15	41	2	0.732	-0.069	4.157	0.013	0.01	0	47.3	43.9	47.7	145	136	0	35	34
2014	9	26	15	51	2	0.745	-0.059	4.157	0.01	0.007	0	47.7	44.3	48.6	146	137	0	35	34
2014	9	26	16	1	2	0.705	-0.049	4.16	0.013	0.01	0	47.3	44.3	47.7	145	137	0	35	34
2014	9	26	16	11	2	0.771	-0.056	4.154	0.01	0.007	0	46	43.9	47.3	143	135	0	36	33
2014	9	26	16	21	2	0.732	-0.079	4.154	0.01	0.007	0	46.4	43.4	49	143	135	0	35	34
2014	9	26	16	31	2	0.728	-0.075	4.163	0.01	0.007	0	46.4	43	48.2	143	134	0	35	34
2014	9	26	16	41	2	0.745	-0.092	4.157	0.01	0.007	0	46	43	49.5	142	134	0	35	34
2014	9	26	16	51	2	0.732	-0.062	4.157	0.01	0.007	0	46.4	43	48.6	143	134	0	35	34
2014	9	26	17	1	2	0.735	-0.066	4.157	0.013	0.01	0	46	42.6	49	142	133	0	35	34
2014	9	26	17	11	2	0.712	-0.056	4.15	0.016	0.013	0	45.6	42.1	49.9	141	132	0	35	34
2014	9	26	17	21	2	0.728	-0.056	4.157	0.013	0.01	0	45.2	42.1	50.3	140	132	0	35	34
2014	9	26	17	31	2	0.732	-0.079	4.15	0.016	0.013	0	45.2	41.7	49.5	140	131	0	35	34
2014	9	26	17	41	2	0.709	-0.085	4.15	0.016	0.016	0	44.7	41.3	49	139	130	0	35	34
2014	9	26	17	51	2	0.738	-0.098	4.15	0.01	0.007	0	44.3	41.3	49.9	139	130	0	36	34
2014	9	26	18	1	2	0.761	-0.079	4.15	0.01	0.007	0	44.3	40.9	48.6	138	129	0	35	34
2014	9	26	18	11	2	0.751	-0.075	4.147	0.01	0.007	0	44.3	40.9	49.5	138	129	0	35	34
2014	9	26	18	21	2	0.732	-0.072	4.157	0.01	0.007	0	44.3	40.9	48.2	138	129	0	35	34
2014	9	26	18	31	2	0.748	-0.062	4.154	0.01	0.007	0	44.3	41.3	49.9	138	129	0	35	33
2014	9	26	18	41	2	0.735	-0.046	4.15	0.01	0.007	0	44.7	40.9	49.9	139	129	0	35	34
2014	9	26	18	51	2	0.709	-0.069	4.147	0.01	0.007	0	43.9	41.3	51.6	138	130	0	36	34
2014	9	26	19	1	2	0.728	-0.043	4.154	0.01	0.007	0	45.2	41.7	49.5	140	131	0	35	34
2014	9	26	19	11	2	0.751	-0.079	4.15	0.013	0.01	0	45.2	41.7	49.5	140	131	0	35	34
2014	9	26	19	21	2	0.725	-0.043	4.154	0.01	0.007	0	44.7	41.3	50.7	139	130	0	35	34
2014	9	26	19	31	2	0.715	-0.066	4.154	0.01	0.007	0	46.4	42.6	47.7	142	132	0	34	33
2014	9	26	19	41	2	0.728	-0.059	4.15	0.013	0.01	0	46	43	50.3	142	133	0	35	33
2014	9	26	19	51	2	0.751	-0.052	4.147	0.01	0.007	0	45.6	42.6	47.3	141	133	0	35	34
2014	9	26	20	1	2	0.738	-0.082	4.15	0.01	0.007	0	45.6	42.1	49.9	141	132	0	35	34
2014	9	26	20	11	2	0.735	-0.069	4.15	0.013	0.01	0	45.6	42.1	49.5	141	132	0	35	34
2014	9	26	20	21	2	0.728	-0.066	4.147	0.01	0.007	0	46.9	43	48.6	144	134	0	35	34
2014	9	26	20	31	2	0.722	-0.072	4.15	0.013	0.01	0	46	42.1	49	142	133	0	35	35
2014	9	26	20	41	2	0.712	-0.085	4.154	0.01	0.007	0	46.4	42.6	49.5	142	133	0	34	34
2014	9	26	20	51	2	0.728	-0.075	4.154	0.01	0.007	0	45.2	42.6	48.2	141	133	0	36	34
2014	9	26	21	1	2	0.741	-0.052	4.14	0.01	0.007	0	46	43	47.3	142	133	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	21	11	2	0.728	-0.059	4.147	0.01	0.007	0	45.6	42.1	49	141	132	0	35	34
2014	9	26	21	21	2	0.748	-0.095	4.15	0.016	0.013	0	46	42.6	48.6	142	133	0	35	34
2014	9	26	21	31	2	0.755	-0.056	4.15	0.01	0.007	0	46.4	43	46.4	143	134	0	35	34
2014	9	26	21	41	2	0.722	-0.066	4.154	0.01	0.007	0	46.4	43	49.9	143	134	0	35	34
2014	9	26	21	51	2	0.735	-0.059	4.147	0.01	0.007	0	46.4	43	47.7	143	134	0	35	34
2014	9	26	22	1	2	0.732	-0.066	4.15	0.01	0.007	0	46.4	43.4	49.5	143	134	0	35	33
2014	9	26	22	11	2	0.715	-0.079	4.147	0.01	0.007	0	45.2	41.7	48.6	140	132	0	35	35
2014	9	26	22	21	2	0.732	-0.115	4.15	0.01	0.007	0	44.7	41.7	50.7	139	131	0	35	34
2014	9	26	22	31	2	0.778	-0.118	4.15	0.013	0.01	0	44.3	40.9	51.2	138	129	0	35	34
2014	9	26	22	41	2	0.735	-0.092	4.144	0.01	0.007	0	44.7	41.3	54.6	139	130	0	35	34
2014	9	26	22	51	2	0.741	-0.092	4.144	0.013	0.01	0	44.3	40.9	56.8	138	129	0	35	34
2014	9	26	23	1	2	0.728	-0.121	4.147	0.013	0.01	0	44.3	40.9	54.6	138	129	0	35	34
2014	9	26	23	11	2	0.748	-0.105	4.147	0.016	0.013	0	44.3	40.9	54.6	138	129	0	35	34
2014	9	26	23	21	2	0.758	-0.115	4.147	0.01	0.007	0	43.9	40.9	50.7	137	128	0	35	33
2014	9	26	23	31	2	0.751	-0.108	4.144	0.01	0.007	0	44.3	40.9	55.5	138	129	0	35	34
2014	9	26	23	41	2	0.732	-0.072	4.144	0.013	0.01	0	43.9	40.4	54.6	137	128	0	35	34
2014	9	26	23	51	2	0.741	-0.112	4.147	0.013	0.01	0	44.3	41.3	52	138	129	0	35	33
2014	9	27	0	1	2	0.735	-0.095	4.147	0.01	0.007	0	43.9	40.4	51.6	137	128	0	35	34
2014	9	27	0	11	2	0.751	-0.069	4.147	0.01	0.007	0	43.9	40.4	50.7	137	128	0	35	34
2014	9	27	0	21	2	0.748	-0.108	4.147	0.01	0.007	0	43.4	40	51.2	136	127	0	35	34
2014	9	27	0	31	2	0.741	-0.121	4.144	0.013	0.01	0	43	39.6	57.2	135	126	0	35	34
2014	9	27	0	41	2	0.761	-0.095	4.144	0.01	0.007	0	43.4	41.3	52.5	137	129	0	36	33
2014	9	27	0	51	2	0.764	-0.089	4.144	0.01	0.007	0	44.3	40.4	57.6	138	129	0	35	35
2014	9	27	1	1	2	0.748	-0.105	4.144	0.013	0.01	0	43.9	40.4	71	137	128	0	35	34
2014	9	27	1	11	2	0.722	-0.115	4.144	0.01	0.007	0	43	39.6	59.3	135	126	0	35	34
2014	9	27	1	21	2	0.732	-0.082	4.147	0.01	0.007	0	42.6	39.6	50.7	135	126	0	36	34
2014	9	27	1	31	2	0.761	-0.069	4.144	0.01	0.007	0	43	39.6	70.1	135	126	0	35	34
2014	9	27	1	41	2	0.741	-0.062	4.144	0.01	0.007	0	43	40	71.8	135	127	0	35	34
2014	9	27	1	51	2	0.764	-0.079	4.144	0.013	0.01	0	43.4	40	72.2	136	127	0	35	34
2014	9	27	2	1	2	0.725	-0.079	4.144	0.013	0.01	0	42.6	39.6	71.8	134	126	0	35	34
2014	9	27	2	11	2	0.735	-0.075	4.144	0.01	0.007	0	43.4	40	72.2	136	127	0	35	34
2014	9	27	2	21	2	0.758	-0.105	4.144	0.013	0.01	0	43.4	39.6	72.2	135	126	0	34	34
2014	9	27	2	31	2	0.735	-0.095	4.144	0.016	0.013	0	43	40	72.7	135	127	0	35	34
2014	9	27	2	41	2	0.715	-0.095	4.14	0.013	0.01	0	44.3	41.3	72.2	137	129	0	34	33
2014	9	27	2	51	2	0.735	-0.079	4.144	0.013	0.01	0	42.6	40	72.2	135	127	0	36	34
2014	9	27	3	1	2	0.745	-0.079	4.14	0.01	0.007	0	43	39.6	71	135	126	0	35	34
2014	9	27	3	11	2	0.732	-0.089	4.14	0.016	0.013	0	42.6	40	71	134	126	0	35	33
2014	9	27	3	21	2	0.702	-0.066	4.14	0.01	0.007	0	43	39.6	72.2	135	126	0	35	34
2014	9	27	3	31	2	0.771	-0.095	4.14	0.013	0.01	0	42.6	39.1	72.2	134	125	0	35	34
2014	9	27	3	41	2	0.748	-0.108	4.14	0.013	0.01	0	43	39.6	71.4	135	126	0	35	34
2014	9	27	3	51	2	0.751	-0.079	4.14	0.01	0.007	0	43	39.6	71.8	135	126	0	35	34
2014	9	27	4	1	2	0.725	-0.098	4.14	0.01	0.007	0	43.9	40.4	71.8	137	128	0	35	34
2014	9	27	4	11	2	0.748	-0.095	4.14	0.013	0.01	0	43.4	39.6	71.8	135	126	0	34	34
2014	9	27	4	21	2	0.722	-0.095	4.14	0.01	0.007	0	42.6	39.6	71.4	135	126	0	36	34
2014	9	27	4	31	2	0.751	-0.085	4.14	0.01	0.007	0	43.9	40.4	69.7	137	128	0	35	34
2014	9	27	4	41	2	0.738	-0.079	4.14	0.01	0.007	0	43	40	56.3	135	126	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	4	51	2	0.755	-0.079	4.14	0.013	0.01	0	43.9	40.4	51.6	137	128	0	35	34
2014	9	27	5	1	2	0.755	-0.102	4.144	0.01	0.007	0	43.9	40.9	49.9	138	129	0	36	34
2014	9	27	5	11	2	0.751	-0.085	4.14	0.013	0.01	0	45.2	41.7	51.6	140	131	0	35	34
2014	9	27	5	21	2	0.768	-0.059	4.144	0.01	0.007	0	45.2	41.7	49	140	131	0	35	34
2014	9	27	5	31	2	0.738	-0.079	4.14	0.01	0.007	0	46	43	50.3	142	134	0	35	34
2014	9	27	5	41	2	0.741	-0.056	4.14	0.01	0.007	0	46	43	50.3	142	134	0	35	34
2014	9	27	5	51	2	0.732	-0.089	4.14	0.013	0.01	0	45.6	42.1	51.6	141	132	0	35	34
2014	9	27	6	1	2	0.774	-0.082	4.14	0.013	0.01	0	45.2	41.7	51.6	140	131	0	35	34
2014	9	27	6	11	2	0.738	-0.075	4.144	0.01	0.007	0	44.3	40.9	50.7	138	129	0	35	34
2014	9	27	6	21	2	0.732	-0.072	4.14	0.013	0.01	0	44.3	40.9	51.6	138	129	0	35	34
2014	9	27	6	31	2	0.768	-0.075	4.14	0.01	0.007	0	43.9	40.4	53.3	137	129	0	35	35
2014	9	27	6	41	2	0.725	-0.072	4.14	0.01	0.007	0	44.3	41.3	49.5	138	129	0	35	33
2014	9	27	6	51	2	0.745	-0.095	4.14	0.01	0.007	0	43.4	40	49.9	136	127	0	35	34
2014	9	27	7	1	2	0.764	-0.062	4.14	0.01	0.007	0	43.4	40.4	49.5	135	127	0	34	33
2014	9	27	7	11	2	0.751	-0.062	4.14	0.01	0.007	0	42.6	39.6	51.2	135	126	0	36	34
2014	9	27	7	21	2	0.751	-0.069	4.144	0.016	0.013	0	42.6	39.6	51.2	134	126	0	35	34
2014	9	27	7	31	2	0.722	-0.036	4.14	0.013	0.01	0	42.6	39.6	51.2	134	126	0	35	34
2014	9	27	7	41	2	0.732	-0.056	4.14	0.01	0.007	0	42.1	39.6	50.3	134	126	0	36	34
2014	9	27	7	51	2	0.748	-0.092	4.14	0.01	0.007	0	42.1	39.1	50.7	133	125	0	35	34
2014	9	27	8	1	2	0.745	-0.079	4.14	0.01	0.007	0	43	40	49.9	135	127	0	35	34
2014	9	27	8	11	2	0.741	-0.079	4.14	0.01	0.007	0	43	40	50.7	135	127	0	35	34
2014	9	27	8	21	2	0.735	-0.095	4.14	0.013	0.01	0	43.9	40.4	48.6	137	128	0	35	34
2014	9	27	8	31	2	0.735	-0.098	4.14	0.01	0.007	0	43.9	40.9	52	137	129	0	35	34
2014	9	27	8	41	2	0.741	-0.089	4.137	0.01	0.007	0	43.9	40	50.7	137	128	0	35	35
2014	9	27	8	51	2	0.761	-0.092	4.137	0.013	0.01	0	43.9	40.9	51.6	137	129	0	35	34
2014	9	27	9	1	2	0.764	-0.079	4.137	0.013	0.01	0	43.9	40.9	51.6	138	129	0	36	34
2014	9	27	9	11	2	0.751	-0.072	4.137	0.013	0.01	0	43.9	40.9	51.6	137	129	0	35	34
2014	9	27	9	21	2	0.748	-0.092	4.134	0.016	0.013	0	43.9	41.3	50.3	137	130	0	35	34
2014	9	27	9	31	2	0.758	-0.079	4.134	0.013	0.01	0	43.9	41.3	50.3	138	130	0	36	34
2014	9	27	9	41	2	0.728	-0.059	4.134	0.01	0.007	0	44.3	41.7	52.5	139	131	0	36	34
2014	9	27	9	51	2	0.751	-0.098	4.134	0.013	0.01	0	44.7	41.7	50.3	139	131	0	35	34
2014	9	27	10	1	2	0.732	-0.062	4.134	0.013	0.01	0	44.7	41.7	52.5	139	131	0	35	34
2014	9	27	10	11	2	0.751	-0.098	4.134	0.013	0.01	0	44.3	41.3	50.7	138	130	0	35	34
2014	9	27	10	21	2	0.719	-0.089	4.134	0.01	0.007	0	43.9	41.3	49.9	138	130	0	36	34
2014	9	27	10	31	2	0.741	-0.072	4.131	0.01	0.007	0	44.3	41.3	51.2	138	130	0	35	34
2014	9	27	10	41	2	0.745	-0.095	4.131	0.01	0.007	0	43.9	40.4	51.2	137	129	0	35	35
2014	9	27	10	51	2	0.735	-0.095	4.131	0.01	0.007	0	43.4	40	52.5	136	128	0	35	35
2014	9	27	11	1	2	0.745	-0.075	4.127	0.01	0.007	0	42.6	40.4	52.5	135	127	0	36	33
2014	9	27	11	11	2	0.755	-0.095	4.127	0.01	0.007	0	43	40	53.3	135	127	0	35	34
2014	9	27	11	21	2	0.741	-0.082	4.127	0.013	0.01	0	43	40	52.5	135	127	0	35	34
2014	9	27	11	31	2	0.774	-0.108	4.127	0.01	0.007	0	42.6	39.6	52.9	134	126	0	35	34
2014	9	27	11	41	2	0.755	-0.092	4.127	0.016	0.013	0	42.6	39.6	52	134	126	0	35	34
2014	9	27	11	51	2	0.755	-0.095	4.127	0.016	0.013	0	42.1	39.1	53.3	134	126	0	36	35
2014	9	27	12	1	2	0.738	-0.075	4.124	0.013	0.01	0	43	40	52.9	135	127	0	35	34
2014	9	27	12	11	2	0.715	-0.079	4.124	0.01	0.007	0	42.6	40	51.2	135	127	0	36	34
2014	9	27	12	21	2	0.738	-0.075	4.124	0.01	0.007	0	43.4	40	50.3	136	128	0	35	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	12	31	2	0.768	-0.069	4.121	0.01	0.007	0	43	40	51.2	135	127	0	35	34
2014	9	27	12	41	2	0.741	-0.072	4.121	0.01	0.007	0	43.4	40.4	50.7	136	128	0	35	34
2014	9	27	12	51	2	0.722	-0.105	4.124	0.01	0.007	0	43.9	40.9	50.7	137	129	0	35	34
2014	9	27	13	1	2	0.709	-0.072	4.117	0.01	0.007	0	43.9	40.9	50.7	137	129	0	35	34
2014	9	27	13	11	2	0.741	-0.066	4.117	0.01	0.007	0	43.9	40.4	48.6	137	129	0	35	35
2014	9	27	13	21	2	0.735	-0.095	4.114	0.016	0.013	0	43.4	40.9	49.9	137	129	0	36	34
2014	9	27	13	31	2	0.735	-0.079	4.117	0.013	0.01	0	43.9	41.3	50.3	137	130	0	35	34
2014	9	27	13	41	2	0.738	-0.075	4.114	0.01	0.007	0	43.9	41.3	49.5	138	130	0	36	34
2014	9	27	13	51	2	0.712	-0.043	4.114	0.013	0.01	0	44.3	42.1	49.5	139	132	0	36	34
2014	9	27	14	1	2	0.748	-0.066	4.114	0.01	0.007	0	44.3	41.7	49.9	139	131	0	36	34
2014	9	27	14	11	2	0.735	-0.085	4.114	0.013	0.01	0	44.7	41.7	48.6	139	131	0	35	34
2014	9	27	14	21	2	0.725	-0.066	4.111	0.01	0.007	0	43.9	41.7	49.5	138	131	0	36	34
2014	9	27	14	31	2	0.732	-0.082	4.111	0.013	0.01	0	43.9	41.3	49.5	138	130	0	36	34
2014	9	27	14	41	2	0.768	-0.072	4.111	0.01	0.007	0	43.9	40.9	50.3	137	129	0	35	34
2014	9	27	14	51	2	0.719	-0.095	4.114	0.01	0.007	0	43	40.4	50.7	136	128	0	36	34
2014	9	27	15	1	2	0.735	-0.095	4.111	0.01	0.007	0	42.6	39.6	53.8	134	126	0	35	34
2014	9	27	15	11	2	0.719	-0.095	4.111	0.01	0.007	0	42.6	39.6	57.6	134	126	0	35	34
2014	9	27	15	21	2	0.728	-0.079	4.108	0.013	0.01	0	42.6	39.6	54.6	134	126	0	35	34
2014	9	27	15	31	2	0.735	-0.098	4.111	0.01	0.007	0	42.1	40	60.2	133	126	0	35	33
2014	9	27	15	41	2	0.689	-0.046	4.108	0.01	0.007	0	42.1	39.1	57.6	133	125	0	35	34
2014	9	27	15	51	2	0.735	-0.092	4.108	0.01	0.007	0	42.1	39.1	58	133	125	0	35	34
2014	9	27	16	1	2	0.748	-0.079	4.108	0.01	0.007	0	42.1	39.1	54.6	133	125	0	35	34
2014	9	27	16	11	2	0.751	-0.072	4.104	0.01	0.007	0	41.3	38.3	52.9	132	124	0	36	35
2014	9	27	16	21	2	0.735	-0.079	4.108	0.016	0.013	0	41.3	38.7	56.8	132	124	0	36	34
2014	9	27	16	31	2	0.732	-0.085	4.104	0.013	0.01	0	41.7	38.7	61.5	132	124	0	35	34
2014	9	27	16	41	2	0.728	-0.075	4.104	0.01	0.007	0	41.7	38.3	52	132	124	0	35	35
2014	9	27	16	51	2	0.748	-0.079	4.108	0.01	0.007	0	41.7	38.7	50.7	132	124	0	35	34
2014	9	27	17	1	2	0.751	-0.079	4.104	0.01	0.007	0	41.3	38.7	50.7	132	124	0	36	34
2014	9	27	17	11	2	0.715	-0.079	4.104	0.01	0.007	0	41.3	38.7	53.3	132	124	0	36	34
2014	9	27	17	21	2	0.745	-0.098	4.104	0.01	0.007	0	41.3	38.3	67.9	131	123	0	35	34
2014	9	27	17	31	2	0.748	-0.079	4.104	0.013	0.01	0	41.3	38.3	67.9	131	123	0	35	34
2014	9	27	17	41	2	0.725	-0.079	4.101	0.013	0.01	0	41.7	38.7	70.1	132	124	0	35	34
2014	9	27	17	51	2	0.728	-0.075	4.101	0.01	0.007	0	41.7	39.1	70.1	132	125	0	35	34
2014	9	27	18	1	2	0.755	-0.079	4.101	0.013	0.01	0	41.7	38.7	64.1	132	124	0	35	34
2014	9	27	18	11	2	0.751	-0.079	4.101	0.013	0.01	0	41.7	39.1	71	132	124	0	35	33
2014	9	27	18	21	2	0.725	-0.105	4.101	0.01	0.007	0	41.7	38.7	71.4	132	124	0	35	34
2014	9	27	18	31	2	0.712	-0.102	4.101	0.01	0.007	0	41.7	38.3	67.9	132	124	0	35	35
2014	9	27	18	41	2	0.709	-0.082	4.098	0.013	0.01	0	41.3	38.3	71.4	131	123	0	35	34
2014	9	27	18	51	2	0.715	-0.095	4.098	0.01	0.007	0	41.7	38.7	71.8	132	124	0	35	34
2014	9	27	19	1	2	0.732	-0.075	4.098	0.016	0.013	0	41.3	38.7	71.8	132	124	0	36	34
2014	9	27	19	11	2	0.738	-0.079	4.094	0.013	0.01	0	42.1	38.3	71.4	133	124	0	35	35
2014	9	27	19	21	2	0.738	-0.092	4.098	0.013	0.01	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	27	19	31	2	0.725	-0.066	4.094	0.01	0.007	0	42.6	39.6	71.8	134	126	0	35	34
2014	9	27	19	41	2	0.755	-0.092	4.098	0.016	0.013	0	43	40	71.8	135	127	0	35	34
2014	9	27	19	51	2	0.764	-0.102	4.094	0.01	0.007	0	42.6	39.6	71.8	134	126	0	35	34
2014	9	27	20	1	2	0.768	-0.089	4.098	0.013	0.01	0	42.6	39.1	71.8	134	125	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	20	11	2	0.705	-0.069	4.094	0.01	0.007	0	41.7	38.7	71.4	132	124	0	35	34
2014	9	27	20	21	2	0.735	-0.072	4.094	0.013	0.01	0	41.7	39.1	71.8	133	125	0	36	34
2014	9	27	20	31	2	0.719	-0.082	4.094	0.01	0.007	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	27	20	41	2	0.715	-0.075	4.094	0.01	0.007	0	42.1	39.1	68.4	133	125	0	35	34
2014	9	27	20	51	2	0.722	-0.069	4.098	0.013	0.01	0	42.1	39.1	68.4	133	125	0	35	34
2014	9	27	21	1	2	0.741	-0.082	4.098	0.01	0.007	0	41.7	39.6	69.7	133	126	0	36	34
2014	9	27	21	11	2	0.728	-0.075	4.098	0.01	0.007	0	42.1	39.1	54.6	133	125	0	35	34
2014	9	27	21	21	2	0.741	-0.072	4.094	0.01	0.007	0	42.6	40	61.9	134	127	0	35	34
2014	9	27	21	31	2	0.735	-0.079	4.098	0.013	0.01	0	42.6	39.6	63.2	134	126	0	35	34
2014	9	27	21	41	2	0.696	-0.059	4.094	0.01	0.007	0	42.6	39.6	67.5	134	126	0	35	34
2014	9	27	21	51	2	0.712	-0.069	4.098	0.01	0.007	0	42.1	39.1	69.2	134	126	0	36	35
2014	9	27	22	1	2	0.735	-0.079	4.098	0.01	0.007	0	42.1	39.6	68.8	134	126	0	36	34
2014	9	27	22	11	2	0.741	-0.072	4.094	0.01	0.007	0	42.1	38.7	70.1	133	125	0	35	35
2014	9	27	22	21	2	0.712	-0.092	4.094	0.01	0.007	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	27	22	31	2	0.728	-0.085	4.094	0.01	0.007	0	41.7	39.1	71	133	126	0	36	35
2014	9	27	22	41	2	0.715	-0.108	4.098	0.013	0.01	0	42.1	39.1	71	133	125	0	35	34
2014	9	27	22	51	2	0.705	-0.075	4.098	0.013	0.01	0	42.6	39.6	70.1	134	126	0	35	34
2014	9	27	23	1	2	0.732	-0.075	4.098	0.013	0.01	0	42.6	39.6	70.5	134	126	0	35	34
2014	9	27	23	11	2	0.745	-0.102	4.098	0.013	0.01	0	42.1	39.6	71	133	126	0	35	34
2014	9	27	23	21	2	0.741	-0.072	4.098	0.01	0.007	0	42.1	39.1	71.4	133	125	0	35	34
2014	9	27	23	31	2	0.719	-0.089	4.101	0.016	0.013	0	42.6	40	71.8	134	127	0	35	34
2014	9	27	23	41	2	0.741	-0.095	4.104	0.01	0.007	0	42.1	39.6	72.7	133	126	0	35	34
2014	9	27	23	51	2	0.719	-0.082	4.101	0.01	0.007	0	42.1	38.7	72.2	133	125	0	35	35
2014	9	28	0	1	2	0.725	-0.072	4.101	0.01	0.007	0	41.3	39.1	72.2	132	125	0	36	34
2014	9	28	0	11	2	0.735	-0.089	4.101	0.01	0.007	0	41.3	38.3	71.4	132	124	0	36	35
2014	9	28	0	21	2	0.738	-0.108	4.101	0.013	0.01	0	41.7	39.1	71.4	133	125	0	36	34
2014	9	28	0	31	2	0.755	-0.095	4.101	0.01	0.007	0	42.1	39.6	69.7	134	126	0	36	34
2014	9	28	0	41	2	0.741	-0.089	4.104	0.01	0.007	0	41.7	39.1	72.2	132	125	0	35	34
2014	9	28	0	51	2	0.745	-0.052	4.101	0.01	0.007	0	43.4	40	71	136	128	0	35	35
2014	9	28	1	1	2	0.745	-0.069	4.098	0.01	0.007	0	42.6	40	71	135	127	0	36	34
2014	9	28	1	11	2	0.745	-0.062	4.094	0.01	0.007	0	42.6	39.6	71.4	134	126	0	35	34
2014	9	28	1	21	2	0.738	-0.102	4.094	0.01	0.007	0	41.7	39.1	70.5	133	125	0	36	34
2014	9	28	1	31	2	0.709	-0.089	4.094	0.01	0.007	0	41.7	39.1	71	132	125	0	35	34
2014	9	28	1	41	2	0.722	-0.102	4.091	0.016	0.013	0	42.1	38.7	70.5	133	125	0	35	35
2014	9	28	1	51	2	0.738	-0.095	4.091	0.01	0.007	0	41.7	39.1	71.8	132	125	0	35	34
2014	9	28	2	1	2	0.787	-0.095	4.094	0.01	0.007	0	41.7	38.3	72.2	132	124	0	35	35
2014	9	28	2	11	2	0.732	-0.085	4.094	0.013	0.01	0	41.3	39.1	72.2	132	125	0	36	34
2014	9	28	2	21	2	0.755	-0.079	4.091	0.01	0.007	0	41.3	38.7	72.2	131	124	0	35	34
2014	9	28	2	31	2	0.738	-0.102	4.094	0.01	0.007	0	42.1	38.7	72.7	133	125	0	35	35
2014	9	28	2	41	2	0.741	-0.082	4.094	0.01	0.007	0	41.7	38.7	72.7	132	124	0	35	34
2014	9	28	2	51	2	0.728	-0.066	4.091	0.01	0.007	0	42.1	39.6	67.1	133	125	0	35	33
2014	9	28	3	1	2	0.738	-0.075	4.091	0.013	0.01	0	42.1	39.1	72.2	133	125	0	35	34
2014	9	28	3	11	2	0.715	-0.079	4.091	0.01	0.007	0	41.7	39.1	71.8	133	125	0	36	34
2014	9	28	3	21	2	0.761	-0.121	4.091	0.016	0.013	0	41.7	38.7	71.8	132	124	0	35	34
2014	9	28	3	31	2	0.705	-0.075	4.091	0.01	0.007	0	41.7	38.3	71.8	132	124	0	35	35
2014	9	28	3	41	2	0.741	-0.095	4.091	0.016	0.013	0	41.7	38.7	72.2	132	124	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	3	51	2	0.728	-0.102	4.091	0.013	0.01	0	41.3	38.3	72.2	131	123	0	35	34
2014	9	28	4	1	2	0.712	-0.108	4.091	0.01	0.007	0	41.3	38.7	72.2	132	124	0	36	34
2014	9	28	4	11	2	0.732	-0.102	4.094	0.01	0.007	0	41.3	38.3	72.7	132	124	0	36	35
2014	9	28	4	21	2	0.709	-0.072	4.091	0.016	0.013	0	41.7	39.6	71.4	133	125	0	36	33
2014	9	28	4	31	2	0.719	-0.089	4.094	0.013	0.01	0	41.7	38.7	71.4	132	124	0	35	34
2014	9	28	4	41	2	0.728	-0.089	4.094	0.01	0.007	0	41.3	38.7	71.4	131	124	0	35	34
2014	9	28	4	51	2	0.748	-0.046	4.098	0.016	0.013	0	41.3	38.7	71.8	132	124	0	36	34
2014	9	28	5	1	2	0.722	-0.108	4.101	0.01	0.007	0	40.4	38.3	71.8	130	123	0	36	34
2014	9	28	5	11	2	0.712	-0.095	4.098	0.013	0.01	0	40.9	37.4	64.5	131	122	0	36	35
2014	9	28	5	21	2	0.745	-0.098	4.098	0.013	0.01	0	41.3	38.3	66.2	132	124	0	36	35
2014	9	28	5	31	2	0.738	-0.075	4.101	0.01	0.007	0	41.7	39.1	72.7	132	125	0	35	34
2014	9	28	5	41	2	0.748	-0.121	4.101	0.01	0.007	0	42.1	39.6	67.9	134	126	0	36	34
2014	9	28	5	51	2	0.728	-0.079	4.101	0.01	0.007	0	42.1	40	71.8	133	127	0	35	34
2014	9	28	6	1	2	0.728	-0.095	4.101	0.01	0.007	0	43.4	41.3	72.2	137	130	0	36	34
2014	9	28	6	11	2	0.725	-0.085	4.101	0.01	0.007	0	43.4	40.9	71.4	136	129	0	35	34
2014	9	28	6	21	2	0.722	-0.098	4.101	0.01	0.007	0	42.6	40	72.2	134	128	0	35	35
2014	9	28	6	31	2	0.732	-0.075	4.101	0.013	0.01	0	43.4	40.4	71.8	136	128	0	35	34
2014	9	28	6	41	2	0.751	-0.082	4.101	0.013	0.01	0	41.3	39.1	72.2	132	125	0	36	34
2014	9	28	6	51	2	0.745	-0.082	4.101	0.01	0.007	0	40.9	38.7	72.2	131	124	0	36	34
2014	9	28	7	1	2	0.705	-0.092	4.101	0.013	0.01	0	43.4	40.9	72.2	136	129	0	35	34
2014	9	28	7	11	2	0.751	-0.069	4.101	0.01	0.007	0	40.9	38.3	72.2	131	124	0	36	35
2014	9	28	7	21	2	0.755	-0.082	4.098	0.013	0.01	0	40	37.8	71.8	129	122	0	36	34
2014	9	28	7	31	2	0.738	-0.095	4.101	0.013	0.01	0	39.1	37.4	73.1	127	121	0	36	34
2014	9	28	7	41	2	0.722	-0.082	4.098	0.01	0.007	0	38.7	37	73.1	126	120	0	36	34
2014	9	28	7	51	2	0.751	-0.085	4.098	0.01	0.007	0	38.7	37	72.7	126	120	0	36	34
2014	9	28	8	1	2	0.722	-0.059	4.098	0.013	0.01	0	39.6	37	72.7	127	121	0	35	35
2014	9	28	8	11	2	0.751	-0.075	4.098	0.013	0.01	0	39.1	37	72.7	126	120	0	35	34
2014	9	28	8	21	2	0.751	-0.089	4.098	0.01	0.007	0	39.1	36.1	72.7	126	119	0	35	35
2014	9	28	8	31	2	0.784	-0.102	4.098	0.01	0.007	0	39.1	37	72.2	126	120	0	35	34
2014	9	28	8	41	2	0.745	-0.121	4.094	0.01	0.007	0	39.6	37	70.5	127	121	0	35	35
2014	9	28	8	51	2	0.722	-0.108	4.094	0.016	0.013	0	39.1	37	71.4	126	120	0	35	34
2014	9	28	9	1	2	0.719	-0.098	4.094	0.013	0.01	0	38.7	37	71.4	126	120	0	36	34
2014	9	28	9	11	2	0.722	-0.098	4.091	0.016	0.013	0	39.1	36.5	69.7	126	120	0	35	35
2014	9	28	9	21	2	0.712	-0.095	4.088	0.01	0.007	0	38.7	36.5	70.1	126	120	0	36	35
2014	9	28	9	31	2	0.751	-0.112	4.088	0.01	0.007	0	38.7	36.5	62.8	125	119	0	35	34
2014	9	28	9	41	2	0.709	-0.112	4.088	0.01	0.007	0	38.7	36.5	58.9	125	119	0	35	34
2014	9	28	9	51	2	0.758	-0.095	4.088	0.016	0.013	0	38.7	36.5	66.2	125	119	0	35	34
2014	9	28	10	1	2	0.728	-0.098	4.088	0.013	0.01	0	38.3	36.5	61.5	125	119	0	36	34
2014	9	28	10	11	2	0.755	-0.141	4.088	0.01	0.007	0	38.3	35.7	71.4	124	118	0	35	35
2014	9	28	10	21	2	0.755	-0.128	4.085	0.013	0.01	0	38.7	36.1	58.9	125	119	0	35	35
2014	9	28	10	31	2	0.751	-0.115	4.085	0.01	0.007	0	38.3	36.5	67.1	125	119	0	36	34
2014	9	28	10	41	2	0.755	-0.135	4.085	0.013	0.01	0	38.3	36.1	70.5	124	119	0	35	35
2014	9	28	10	51	2	0.758	-0.112	4.085	0.01	0.007	0	38.7	37	71.8	126	120	0	36	34
2014	9	28	11	1	2	0.741	-0.128	4.085	0.013	0.01	0	38.3	36.5	60.2	125	119	0	36	34
2014	9	28	11	11	2	0.755	-0.105	4.085	0.01	0.007	0	38.3	36.5	64.9	124	119	0	35	34
2014	9	28	11	21	2	0.761	-0.141	4.085	0.013	0.01	0	37.4	35.3	70.1	123	117	0	36	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	11	31	2	0.748	-0.102	4.085	0.013	0.01	0	38.7	36.1	62.4	125	119	0	35	35
2014	9	28	11	41	2	0.728	-0.095	4.085	0.01	0.007	0	38.3	36.5	59.3	125	120	0	36	35
2014	9	28	11	51	2	0.755	-0.098	4.085	0.01	0.007	0	38.7	37	55.5	125	120	0	35	34
2014	9	28	12	1	2	0.751	-0.115	4.085	0.013	0.01	0	38.3	36.1	67.5	124	118	0	35	34
2014	9	28	12	11	2	0.741	-0.079	4.085	0.01	0.007	0	38.3	36.5	69.2	125	119	0	36	34
2014	9	28	12	21	2	0.722	-0.151	4.081	0.016	0.013	0	37.8	35.7	60.2	124	118	0	36	35
2014	9	28	12	31	2	0.728	-0.115	4.081	0.01	0.007	0	38.7	36.1	57.6	125	119	0	35	35
2014	9	28	12	41	2	0.741	-0.105	4.081	0.01	0.007	0	38.7	36.5	58.5	125	119	0	35	34
2014	9	28	12	51	2	0.738	-0.105	4.081	0.01	0.007	0	38.7	36.5	55.5	125	119	0	35	34
2014	9	28	13	1	2	0.738	-0.115	4.081	0.01	0.007	0	38.3	36.5	71.8	125	119	0	36	34
2014	9	28	13	11	2	0.732	-0.138	4.081	0.01	0.007	0	38.3	36.5	53.8	125	119	0	36	34
2014	9	28	13	21	2	0.755	-0.131	4.081	0.01	0.007	0	38.3	36.5	58.9	124	119	0	35	34
2014	9	28	13	31	2	0.764	-0.102	4.081	0.01	0.007	0	37.8	36.1	54.6	124	118	0	36	34
2014	9	28	13	41	2	0.741	-0.138	4.081	0.01	0.007	0	37.8	36.5	56.3	124	119	0	36	34
2014	9	28	13	51	2	0.784	-0.105	4.078	0.013	0.01	0	37.8	36.1	67.5	124	118	0	36	34
2014	9	28	14	1	2	0.745	-0.108	4.078	0.01	0.007	0	37.8	36.5	67.5	124	119	0	36	34
2014	9	28	14	11	2	0.738	-0.098	4.081	0.013	0.01	0	38.7	37	65.8	126	120	0	36	34
2014	9	28	14	21	2	0.728	-0.098	4.078	0.01	0.007	0	38.3	36.5	72.2	125	120	0	36	35
2014	9	28	14	31	2	0.758	-0.121	4.078	0.01	0.007	0	38.7	36.5	56.3	125	119	0	35	34
2014	9	28	14	41	2	0.722	-0.161	4.078	0.01	0.007	0	38.3	36.1	55.9	124	118	0	35	34
2014	9	28	14	51	2	0.738	-0.154	4.078	0.01	0.007	0	38.7	37	53.8	125	120	0	35	34
2014	9	28	15	1	2	0.768	-0.144	4.078	0.01	0.007	0	38.7	36.5	60.2	125	119	0	35	34
2014	9	28	15	11	2	0.741	-0.121	4.078	0.01	0.007	0	39.1	36.5	52.9	126	120	0	35	35
2014	9	28	15	21	2	0.735	-0.131	4.078	0.01	0.007	0	38.3	36.5	58.5	125	120	0	36	35
2014	9	28	15	31	2	0.761	-0.121	4.078	0.01	0.007	0	38.7	37	58	126	120	0	36	34
2014	9	28	15	41	2	0.761	-0.125	4.078	0.01	0.007	0	39.1	37	55	127	120	0	36	34
2014	9	28	15	51	2	0.705	-0.138	4.078	0.01	0.007	0	39.6	37.8	56.8	128	122	0	36	34
2014	9	28	16	1	2	0.722	-0.121	4.078	0.013	0.01	0	39.1	37	54.6	126	120	0	35	34
2014	9	28	16	11	2	0.748	-0.138	4.078	0.01	0.007	0	39.1	37	58	126	120	0	35	34
2014	9	28	16	21	2	0.735	-0.138	4.078	0.01	0.007	0	38.3	36.5	65.4	125	120	0	36	35
2014	9	28	16	31	2	0.725	-0.112	4.078	0.016	0.013	0	38.3	37	58.9	125	120	0	36	34
2014	9	28	16	41	2	0.709	-0.095	4.078	0.013	0.01	0	38.7	37	57.2	126	120	0	36	34
2014	9	28	16	51	2	0.728	-0.148	4.078	0.016	0.013	0	38.7	37	59.8	125	120	0	35	34
2014	9	28	17	1	2	0.732	-0.121	4.081	0.01	0.007	0	39.1	36.1	50.3	126	119	0	35	35
2014	9	28	17	11	2	0.712	-0.105	4.081	0.01	0.007	0	38.7	36.5	50.7	126	120	0	36	35
2014	9	28	17	21	2	0.755	-0.108	4.078	0.01	0.007	0	38.7	36.1	57.2	125	119	0	35	35
2014	9	28	17	31	2	0.751	-0.072	4.081	0.016	0.013	0	38.3	36.1	67.5	125	119	0	36	35
2014	9	28	17	41	2	0.705	-0.069	4.081	0.01	0.007	0	39.1	37.4	52.9	127	121	0	36	34
2014	9	28	17	51	2	0.709	-0.079	4.081	0.01	0.007	0	40	38.3	52.9	128	123	0	35	34
2014	9	28	18	1	2	0.732	-0.085	4.081	0.013	0.01	0	40	37.4	52	128	122	0	35	35
2014	9	28	18	11	2	0.732	-0.085	4.081	0.01	0.007	0	40	38.3	51.6	129	123	0	36	34
2014	9	28	18	21	2	0.758	-0.092	4.081	0.01	0.007	0	40.4	38.3	52	130	124	0	36	35
2014	9	28	18	31	2	0.735	-0.082	4.081	0.01	0.007	0	40	37.8	51.6	129	123	0	36	35
2014	9	28	18	41	2	0.732	-0.092	4.081	0.013	0.01	0	40	38.3	55	129	123	0	36	34
2014	9	28	18	51	2	0.748	-0.062	4.081	0.01	0.007	0	40	38.3	55.9	129	123	0	36	34
2014	9	28	19	1	2	0.722	-0.098	4.081	0.013	0.01	0	40	38.3	58.9	129	124	0	36	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	19	11	2	0.735	-0.095	4.081	0.01	0.007	0	40.9	38.7	61.9	130	124	0	35	34
2014	9	28	19	21	2	0.705	-0.095	4.081	0.01	0.007	0	41.3	39.1	58.9	131	125	0	35	34
2014	9	28	19	31	2	0.722	-0.046	4.081	0.01	0.007	0	40.9	38.7	54.6	131	125	0	36	35
2014	9	28	19	41	2	0.728	-0.095	4.081	0.01	0.007	0	40.9	39.6	51.6	131	126	0	36	34
2014	9	28	19	51	2	0.725	-0.095	4.081	0.01	0.007	0	40.9	39.6	51.2	131	126	0	36	34
2014	9	28	20	1	2	0.738	-0.095	4.081	0.01	0.007	0	41.3	38.7	52.5	131	125	0	35	35
2014	9	28	20	11	2	0.728	-0.062	4.081	0.013	0.01	0	41.3	39.6	49.9	132	126	0	36	34
2014	9	28	20	21	2	0.712	-0.089	4.081	0.01	0.007	0	42.6	40.4	49	134	128	0	35	34
2014	9	28	20	31	2	0.738	-0.059	4.085	0.013	0.01	0	41.3	40	49	132	127	0	36	34
2014	9	28	20	41	2	0.705	-0.095	4.085	0.01	0.007	0	42.1	40.4	49.5	134	128	0	36	34
2014	9	28	20	51	2	0.699	-0.085	4.085	0.01	0.007	0	42.1	40	50.3	133	127	0	35	34
2014	9	28	21	1	2	0.705	-0.082	4.085	0.01	0.007	0	42.6	40.4	52	134	128	0	35	34
2014	9	28	21	11	2	0.719	-0.066	4.085	0.013	0.01	0	42.1	39.6	52.5	133	127	0	35	35
2014	9	28	21	21	2	0.741	-0.079	4.081	0.01	0.007	0	41.7	39.6	56.8	132	126	0	35	34
2014	9	28	21	31	2	0.735	-0.066	4.085	0.01	0.007	0	40.9	38.7	51.2	131	125	0	36	35
2014	9	28	21	41	2	0.719	-0.075	4.085	0.013	0.01	0	41.7	38.7	49	132	125	0	35	35
2014	9	28	21	51	2	0.738	-0.066	4.088	0.013	0.01	0	41.7	39.6	48.6	132	126	0	35	34
2014	9	28	22	1	2	0.735	-0.098	4.088	0.01	0.007	0	42.1	40	50.3	133	127	0	35	34
2014	9	28	22	11	2	0.735	-0.118	4.081	0.013	0.01	0	42.1	40	64.1	133	127	0	35	34
2014	9	28	22	21	2	0.738	-0.075	4.085	0.01	0.007	0	41.3	39.6	52.5	132	126	0	36	34
2014	9	28	22	31	2	0.748	-0.135	4.085	0.01	0.007	0	41.7	39.6	51.2	132	126	0	35	34
2014	9	28	22	41	2	0.738	-0.072	4.085	0.013	0.01	0	41.7	39.1	52	132	126	0	35	35
2014	9	28	22	51	2	0.725	-0.112	4.085	0.01	0.007	0	40.9	39.1	54.2	131	125	0	36	34
2014	9	28	23	1	2	0.719	-0.089	4.085	0.016	0.016	0	41.7	40	53.8	133	127	0	36	34
2014	9	28	23	11	2	0.719	-0.105	4.088	0.01	0.007	0	41.3	39.6	50.7	132	126	0	36	34
2014	9	28	23	21	2	0.722	-0.085	4.085	0.01	0.007	0	41.3	39.1	52.9	131	126	0	35	35
2014	9	28	23	31	2	0.722	-0.059	4.085	0.01	0.007	0	40.9	39.6	55.5	131	126	0	36	34
2014	9	28	23	41	2	0.719	-0.089	4.085	0.01	0.007	0	41.3	39.6	61.9	131	126	0	35	34
2014	9	28	23	51	2	0.738	-0.095	4.085	0.01	0.007	0	40.9	38.7	70.1	130	125	0	35	35
2014	9	29	0	1	2	0.735	-0.082	4.085	0.01	0.007	0	40.9	39.1	71.4	130	125	0	35	34
2014	9	29	0	11	2	0.755	-0.092	4.085	0.01	0.007	0	40	38.3	64.5	129	124	0	36	35
2014	9	29	0	21	2	0.738	-0.092	4.085	0.01	0.007	0	40.9	38.3	71	130	124	0	35	35
2014	9	29	0	31	2	0.745	-0.115	4.085	0.01	0.007	0	40.4	38.3	67.5	130	124	0	36	35
2014	9	29	0	41	2	0.722	-0.098	4.085	0.01	0.007	0	40.9	39.1	63.6	130	125	0	35	34
2014	9	29	0	51	2	0.722	-0.085	4.088	0.01	0.007	0	41.3	38.7	67.5	131	125	0	35	35
2014	9	29	1	1	2	0.741	-0.085	4.088	0.01	0.007	0	40.4	38.7	71	130	124	0	36	34
2014	9	29	1	11	2	0.741	-0.085	4.088	0.016	0.013	0	40.4	37.8	71.4	129	123	0	35	35
2014	9	29	1	21	2	0.738	-0.095	4.088	0.01	0.007	0	40	38.7	71.8	129	123	0	36	33
2014	9	29	1	31	2	0.735	-0.072	4.088	0.01	0.007	0	40	38.7	71.8	129	124	0	36	34
2014	9	29	1	41	2	0.748	-0.075	4.088	0.013	0.01	0	40.4	39.1	55.5	131	125	0	37	34
2014	9	29	1	51	2	0.725	-0.085	4.088	0.01	0.007	0	41.3	39.1	70.5	131	125	0	35	34
2014	9	29	2	1	2	0.709	-0.085	4.088	0.01	0.007	0	40.4	38.3	71	130	124	0	36	35
2014	9	29	2	11	2	0.745	-0.092	4.088	0.016	0.013	0	40	38.3	70.5	129	123	0	36	34
2014	9	29	2	21	2	0.728	-0.108	4.088	0.01	0.007	0	40.4	37.8	67.9	129	123	0	35	35
2014	9	29	2	31	2	0.741	-0.092	4.088	0.01	0.007	0	40	38.3	65.4	129	123	0	36	34
2014	9	29	2	41	2	0.741	-0.079	4.088	0.01	0.007	0	40.4	38.3	61.5	129	123	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	2	51	2	0.725	-0.075	4.091	0.01	0.007	0	40.4	38.3	69.7	130	124	0	36	35
2014	9	29	3	1	2	0.732	-0.095	4.091	0.01	0.007	0	40	38.3	70.1	129	123	0	36	34
2014	9	29	3	11	2	0.741	-0.085	4.091	0.01	0.007	0	40	37.8	67.1	128	122	0	35	34
2014	9	29	3	21	2	0.715	-0.085	4.088	0.013	0.01	0	40.9	38.7	64.1	130	125	0	35	35
2014	9	29	3	31	2	0.751	-0.069	4.091	0.01	0.007	0	40.4	38.7	62.8	129	124	0	35	34
2014	9	29	3	41	2	0.751	-0.059	4.091	0.01	0.007	0	40.4	38.3	62.8	129	123	0	35	34
2014	9	29	3	51	2	0.735	-0.102	4.091	0.01	0.007	0	40	38.3	69.7	129	123	0	36	34
2014	9	29	4	1	2	0.719	-0.072	4.091	0.01	0.007	0	40.4	38.3	69.2	129	123	0	35	34
2014	9	29	4	11	2	0.735	-0.092	4.091	0.01	0.007	0	40.4	38.3	60.2	129	123	0	35	34
2014	9	29	4	21	2	0.735	-0.059	4.091	0.013	0.01	0	39.6	37.4	67.9	128	122	0	36	35
2014	9	29	4	31	2	0.712	-0.092	4.094	0.013	0.01	0	39.6	38.3	69.7	128	123	0	36	34
2014	9	29	4	41	2	0.725	-0.102	4.094	0.013	0.01	0	39.6	38.3	68.8	128	123	0	36	34
2014	9	29	4	51	2	0.722	-0.108	4.094	0.013	0.01	0	39.6	38.3	61.9	128	123	0	36	34
2014	9	29	5	1	2	0.732	-0.105	4.098	0.01	0.007	0	40.9	39.1	64.1	130	125	0	35	34
2014	9	29	5	11	2	0.725	-0.092	4.098	0.01	0.007	0	40	38.3	68.4	128	123	0	35	34
2014	9	29	5	21	2	0.715	-0.092	4.098	0.013	0.01	0	40.9	38.7	68.4	130	124	0	35	34
2014	9	29	5	31	2	0.745	-0.056	4.098	0.016	0.013	0	39.6	37.4	71.8	128	122	0	36	35
2014	9	29	5	41	2	0.702	-0.115	4.101	0.013	0.01	0	40	37.8	73.5	129	123	0	36	35
2014	9	29	5	51	2	0.712	-0.098	4.101	0.01	0.007	0	40	38.7	71	129	124	0	36	34
2014	9	29	6	1	2	0.725	-0.095	4.098	0.01	0.007	0	39.6	38.3	67.1	128	123	0	36	34
2014	9	29	6	11	2	0.715	-0.085	4.098	0.01	0.007	0	42.1	39.6	63.2	133	127	0	35	35
2014	9	29	6	21	2	0.725	-0.079	4.101	0.013	0.01	0	40.9	38.7	68.4	131	125	0	36	35
2014	9	29	6	31	2	0.728	-0.066	4.101	0.013	0.01	0	40.9	38.3	67.1	130	124	0	35	35
2014	9	29	6	41	2	0.732	-0.108	4.101	0.01	0.007	0	40.9	39.6	64.5	131	126	0	36	34
2014	9	29	6	51	2	0.748	-0.079	4.101	0.016	0.013	0	39.6	37.8	70.1	129	123	0	37	35
2014	9	29	7	1	2	0.722	-0.092	4.098	0.01	0.007	0	40.4	37.8	73.1	129	123	0	35	35
2014	9	29	7	11	2	0.732	-0.092	4.101	0.01	0.007	0	40	37.8	71.4	128	122	0	35	34
2014	9	29	7	21	2	0.735	-0.092	4.101	0.01	0.007	0	39.1	37.4	73.1	126	121	0	35	34
2014	9	29	7	31	2	0.732	-0.079	4.101	0.01	0.007	0	39.1	37	73.5	126	120	0	35	34
2014	9	29	7	41	2	0.745	-0.102	4.098	0.01	0.007	0	39.6	37.4	73.5	127	121	0	35	34
2014	9	29	7	51	2	0.771	-0.115	4.098	0.01	0.007	0	38.7	37	74	126	120	0	36	34
2014	9	29	8	1	2	0.738	-0.082	4.098	0.013	0.01	0	39.1	36.5	72.7	126	120	0	35	35
2014	9	29	8	11	2	0.722	-0.082	4.098	0.01	0.007	0	38.7	36.5	73.1	125	120	0	35	35
2014	9	29	8	21	2	0.758	-0.079	4.098	0.01	0.007	0	38.7	36.1	71.4	125	119	0	35	35
2014	9	29	8	31	2	0.728	-0.098	4.098	0.013	0.01	0	38.3	37	59.8	125	120	0	36	34
2014	9	29	8	41	2	0.725	-0.085	4.098	0.01	0.007	0	38.3	36.5	69.2	125	119	0	36	34
2014	9	29	8	51	2	0.719	-0.085	4.098	0.01	0.007	0	38.7	37	64.5	125	120	0	35	34
2014	9	29	9	1	2	0.755	-0.125	4.098	0.013	0.01	0	38.7	36.1	74	125	119	0	35	35
2014	9	29	9	11	2	0.732	-0.125	4.098	0.01	0.007	0	38.3	36.5	74.4	124	119	0	35	34
2014	9	29	9	21	2	0.732	-0.121	4.098	0.01	0.007	0	37.8	36.1	74.4	124	119	0	36	35
2014	9	29	9	31	2	0.715	-0.066	4.098	0.01	0.007	0	38.7	37	73.5	125	120	0	35	34
2014	9	29	9	41	2	0.715	-0.108	4.098	0.016	0.013	0	38.3	36.5	71.8	124	119	0	35	34
2014	9	29	9	51	2	0.709	-0.079	4.098	0.01	0.007	0	37.8	36.1	73.5	124	119	0	36	35
2014	9	29	10	1	2	0.722	-0.115	4.098	0.01	0.007	0	37.8	36.1	74	124	118	0	36	34
2014	9	29	10	11	2	0.725	-0.135	4.098	0.01	0.007	0	37.4	35.7	72.7	123	118	0	36	35
2014	9	29	10	21	2	0.732	-0.082	4.098	0.01	0.007	0	38.7	36.5	73.1	125	120	0	35	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	10	31	2	0.745	-0.095	4.098	0.013	0.01	0	38.7	37	73.1	125	120	0	35	34
2014	9	29	10	41	2	0.735	-0.112	4.094	0.01	0.007	0	37.8	36.1	61.9	124	119	0	36	35
2014	9	29	10	51	2	0.712	-0.098	4.091	0.01	0.007	0	37.8	36.1	52.9	124	119	0	36	35
2014	9	29	11	1	2	0.751	-0.167	4.094	0.01	0.007	0	37.4	35.7	68.4	123	117	0	36	34
2014	9	29	11	11	2	0.719	-0.125	4.094	0.013	0.01	0	38.3	36.1	73.1	125	119	0	36	35
2014	9	29	11	21	2	0.709	-0.095	4.094	0.01	0.007	0	37.8	36.5	73.1	124	119	0	36	34
2014	9	29	11	31	2	0.705	-0.108	4.094	0.01	0.007	0	38.3	36.5	71	124	119	0	35	34
2014	9	29	11	41	2	0.719	-0.092	4.094	0.01	0.007	0	38.3	36.1	72.2	124	119	0	35	35
2014	9	29	11	51	2	0.719	-0.112	4.091	0.01	0.007	0	38.7	36.1	71.4	125	119	0	35	35
2014	9	29	12	1	2	0.728	-0.075	4.091	0.01	0.007	0	38.3	36.1	70.5	124	119	0	35	35
2014	9	29	12	11	2	0.722	-0.108	4.088	0.01	0.007	0	37.8	35.7	70.1	124	118	0	36	35
2014	9	29	12	21	2	0.719	-0.135	4.088	0.01	0.007	0	37.8	36.1	71.8	123	118	0	35	34
2014	9	29	12	31	2	0.715	-0.085	4.085	0.01	0.007	0	37.8	36.1	72.2	124	118	0	36	34
2014	9	29	12	41	2	0.709	-0.108	4.085	0.01	0.007	0	37.8	36.1	71.4	124	119	0	36	35
2014	9	29	12	51	2	0.748	-0.121	4.085	0.013	0.01	0	38.3	36.5	72.7	124	119	0	35	34
2014	9	29	13	1	2	0.719	-0.108	4.081	0.013	0.01	0	37.8	36.1	72.7	124	119	0	36	35
2014	9	29	13	11	2	0.728	-0.098	4.081	0.01	0.007	0	37.8	36.5	71	124	119	0	36	34
2014	9	29	13	21	2	0.709	-0.128	4.081	0.01	0.007	0	38.3	36.1	72.7	124	119	0	35	35
2014	9	29	13	31	2	0.728	-0.108	4.081	0.01	0.007	0	37.8	36.1	71.8	124	119	0	36	35
2014	9	29	13	41	2	0.735	-0.095	4.081	0.01	0.007	0	38.3	36.1	73.1	124	119	0	35	35
2014	9	29	13	51	2	0.725	-0.085	4.081	0.01	0.007	0	37.8	36.1	72.2	123	119	0	35	35
2014	9	29	14	1	2	0.719	-0.069	4.081	0.013	0.01	0	37.8	37	69.2	124	120	0	36	34
2014	9	29	14	11	2	0.761	-0.089	4.081	0.01	0.007	0	37.8	36.5	64.5	124	119	0	36	34
2014	9	29	14	21	2	0.748	-0.108	4.081	0.016	0.013	0	37.4	36.1	74	123	118	0	36	34
2014	9	29	14	31	2	0.709	-0.075	4.081	0.016	0.013	0	38.3	37.4	73.1	125	121	0	36	34
2014	9	29	14	41	2	0.758	-0.105	4.078	0.01	0.007	0	37.4	36.5	56.3	123	119	0	36	34
2014	9	29	14	51	2	0.722	-0.098	4.078	0.01	0.007	0	37.8	35.7	71.4	123	118	0	35	35
2014	9	29	15	1	2	0.725	-0.102	4.078	0.01	0.007	0	37.8	36.5	68.8	124	119	0	36	34
2014	9	29	15	11	2	0.738	-0.075	4.078	0.01	0.007	0	38.3	36.5	67.9	125	120	0	36	35
2014	9	29	15	21	2	0.728	-0.089	4.078	0.013	0.01	0	37.8	36.1	56.8	124	119	0	36	35
2014	9	29	15	31	2	0.751	-0.105	4.078	0.01	0.007	0	37.4	36.5	67.9	123	119	0	36	34
2014	9	29	15	41	2	0.709	-0.102	4.078	0.01	0.007	0	37.8	36.5	66.2	124	119	0	36	34
2014	9	29	15	51	2	0.722	-0.089	4.078	0.01	0.007	0	38.3	37	67.1	124	119	0	35	33
2014	9	29	16	1	2	0.738	-0.138	4.078	0.01	0.007	0	38.3	35.7	73.1	124	118	0	35	35
2014	9	29	16	11	2	0.719	-0.118	4.075	0.01	0.007	0	38.3	37	59.8	124	120	0	35	34
2014	9	29	16	21	2	0.735	-0.118	4.078	0.01	0.007	0	37.8	36.5	74	125	120	0	37	35
2014	9	29	16	31	2	0.712	-0.115	4.075	0.01	0.007	0	37.4	35.7	61.9	123	118	0	36	35
2014	9	29	16	41	2	0.705	-0.115	4.075	0.01	0.007	0	37.8	36.1	61.5	124	119	0	36	35
2014	9	29	16	51	2	0.732	-0.112	4.075	0.016	0.013	0	38.3	36.5	67.1	124	119	0	35	34
2014	9	29	17	1	2	0.758	-0.092	4.075	0.01	0.007	0	37.8	36.5	63.2	124	119	0	36	34
2014	9	29	17	11	2	0.719	-0.115	4.078	0.013	0.01	0	38.7	36.5	74.4	125	119	0	35	34
2014	9	29	17	21	2	0.728	-0.148	4.078	0.01	0.007	0	37.4	35.7	69.7	123	118	0	36	35
2014	9	29	17	31	2	0.748	-0.164	4.078	0.013	0.01	0	37.8	36.1	73.5	124	118	0	36	34
2014	9	29	17	41	2	0.699	-0.135	4.078	0.013	0.01	0	38.3	35.7	74.8	124	118	0	35	35
2014	9	29	17	51	2	0.696	-0.108	4.078	0.013	0.01	0	38.3	36.1	74.8	124	118	0	35	34
2014	9	29	18	1	2	0.702	-0.118	4.078	0.013	0.01	0	37.8	35.7	75.3	124	118	0	36	35

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	18	11	2	0.705	-0.105	4.078	0.013	0.01	0	37.8	36.1	74.8	124	118	0	36	34
2014	9	29	18	21	2	0.702	-0.102	4.078	0.01	0.007	0	38.3	36.5	74.8	125	119	0	36	34
2014	9	29	18	31	2	0.709	-0.118	4.078	0.01	0.007	0	38.3	35.7	74.8	124	118	0	35	35
2014	9	29	18	41	2	0.745	-0.115	4.078	0.01	0.007	0	38.3	36.1	75.7	125	119	0	36	35
2014	9	29	18	51	2	0.715	-0.128	4.078	0.013	0.01	0	38.7	37	75.7	125	119	0	35	33
2014	9	29	19	1	2	0.732	-0.105	4.078	0.01	0.007	0	38.3	37	75.3	125	120	0	36	34
2014	9	29	19	11	2	0.679	-0.082	4.078	0.01	0.007	0	38.7	37.4	73.1	126	121	0	36	34
2014	9	29	19	21	2	0.728	-0.072	4.075	0.013	0.01	0	40.4	38.3	74.4	129	123	0	35	34
2014	9	29	19	31	2	0.725	-0.075	4.078	0.013	0.01	0	40	38.3	74.8	128	123	0	35	34
2014	9	29	19	41	2	0.709	-0.112	4.078	0.016	0.016	0	40	38.3	74.4	129	124	0	36	35
2014	9	29	19	51	2	0.702	-0.079	4.078	0.01	0.007	0	39.6	38.3	75.3	128	123	0	36	34
2014	9	29	20	1	2	0.719	-0.115	4.078	0.01	0.007	0	39.6	37.8	72.7	128	123	0	36	35
2014	9	29	20	11	2	0.735	-0.095	4.078	0.01	0.007	0	40.4	38.3	74.4	129	124	0	35	35
2014	9	29	20	21	2	0.719	-0.062	4.078	0.01	0.007	0	40	38.7	74.4	129	124	0	36	34
2014	9	29	20	31	2	0.679	-0.092	4.078	0.01	0.007	0	40	38.3	74.4	129	123	0	36	34
2014	9	29	20	41	2	0.715	-0.108	4.078	0.016	0.013	0	40.4	38.3	73.5	129	124	0	35	35
2014	9	29	20	51	2	0.709	-0.108	4.078	0.01	0.007	0	40	38.3	75.3	128	123	0	35	34
2014	9	29	21	1	2	0.705	-0.098	4.078	0.01	0.007	0	40	38.3	74.4	129	123	0	36	34
2014	9	29	21	11	2	0.699	-0.079	4.075	0.01	0.007	0	40	38.7	74	129	124	0	36	34
2014	9	29	21	21	2	0.745	-0.105	4.078	0.01	0.007	0	40.4	38.7	74	129	124	0	35	34
2014	9	29	21	31	2	0.732	-0.102	4.078	0.01	0.007	0	40.4	38.3	74.4	130	124	0	36	35
2014	9	29	21	41	2	0.719	-0.062	4.078	0.01	0.007	0	40	38.3	74.8	129	123	0	36	34
2014	9	29	21	51	2	0.722	-0.105	4.075	0.016	0.013	0	40	38.3	74	129	124	0	36	35
2014	9	29	22	1	2	0.722	-0.108	4.078	0.01	0.007	0	40	38.3	74	129	124	0	36	35
2014	9	29	22	11	2	0.738	-0.105	4.078	0.013	0.01	0	40	38.3	73.5	129	124	0	36	35
2014	9	29	22	21	2	0.692	-0.112	4.078	0.01	0.007	0	40.4	38.3	74	129	123	0	35	34
2014	9	29	22	31	2	0.722	-0.115	4.078	0.01	0.007	0	40.4	38.7	73.5	129	124	0	35	34
2014	9	29	22	41	2	0.692	-0.092	4.078	0.01	0.007	0	40.4	38.3	74	129	124	0	35	35
2014	9	29	22	51	2	0.748	-0.112	4.078	0.013	0.01	0	40.4	38.3	73.5	130	124	0	36	35
2014	9	29	23	1	2	0.719	-0.098	4.075	0.01	0.007	0	40	38.7	73.5	129	124	0	36	34
2014	9	29	23	11	2	0.705	-0.112	4.075	0.016	0.013	0	40	38.7	74	129	124	0	36	34
2014	9	29	23	21	2	0.715	-0.095	4.075	0.01	0.007	0	40.4	38.3	73.5	129	124	0	35	35
2014	9	29	23	31	2	0.722	-0.075	4.078	0.013	0.01	0	40	38.7	72.2	129	124	0	36	34
2014	9	29	23	41	2	0.712	-0.089	4.078	0.01	0.007	0	39.6	38.7	73.5	129	124	0	37	34
2014	9	29	23	51	2	0.705	-0.089	4.075	0.013	0.01	0	40	38.7	73.5	129	124	0	36	34
2014	9	30	0	1	2	0.699	-0.095	4.078	0.013	0.01	0	40.4	38.7	74	129	124	0	35	34
2014	9	30	0	11	2	0.712	-0.066	4.075	0.013	0.01	0	40.4	39.1	73.5	130	125	0	36	34
2014	9	30	0	21	2	0.719	-0.112	4.078	0.01	0.007	0	39.6	37.8	74.4	128	123	0	36	35
2014	9	30	0	31	2	0.735	-0.095	4.075	0.01	0.007	0	39.6	38.3	74.8	128	123	0	36	34
2014	9	30	0	41	2	0.712	-0.066	4.075	0.01	0.007	0	39.6	37.8	74.4	128	123	0	36	35
2014	9	30	0	51	2	0.709	-0.085	4.075	0.013	0.01	0	40	38.3	74.4	128	123	0	35	34
2014	9	30	1	1	2	0.725	-0.095	4.075	0.01	0.007	0	40.4	38.3	74	129	123	0	35	34
2014	9	30	1	11	2	0.709	-0.069	4.075	0.013	0.01	0	39.6	38.3	74.8	128	123	0	36	34
2014	9	30	1	21	2	0.696	-0.066	4.075	0.01	0.007	0	40.4	38.7	74	129	124	0	35	34
2014	9	30	1	31	2	0.722	-0.121	4.078	0.01	0.007	0	39.6	38.3	74.4	128	123	0	36	34
2014	9	30	1	41	2	0.732	-0.105	4.075	0.01	0.007	0	40	38.7	73.5	129	124	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	1	51	2	0.692	-0.118	4.075	0.01	0.007	0	40	38.3	74.4	129	123	0	36	34
2014	9	30	2	1	2	0.712	-0.089	4.075	0.013	0.01	0	39.6	37.8	74.4	128	123	0	36	35
2014	9	30	2	11	2	0.728	-0.092	4.075	0.01	0.007	0	40	37.8	74	128	123	0	35	35
2014	9	30	2	21	2	0.699	-0.085	4.075	0.01	0.007	0	39.6	37.8	74.4	128	123	0	36	35
2014	9	30	2	31	2	0.702	-0.049	4.075	0.013	0.01	0	40	38.3	74	129	124	0	36	35
2014	9	30	2	41	2	0.692	-0.118	4.075	0.016	0.013	0	40.4	38.3	73.5	129	123	0	35	34
2014	9	30	2	51	2	0.692	-0.079	4.075	0.01	0.007	0	39.6	37.8	73.1	127	122	0	35	34
2014	9	30	3	1	2	0.715	-0.072	4.075	0.013	0.01	0	39.6	37.8	73.5	128	122	0	36	34
2014	9	30	3	11	2	0.702	-0.079	4.075	0.01	0.007	0	39.1	37.8	73.5	127	122	0	36	34
2014	9	30	3	21	2	0.682	-0.075	4.075	0.016	0.013	0	39.6	37.4	73.5	128	122	0	36	35
2014	9	30	3	31	2	0.715	-0.092	4.075	0.013	0.01	0	40	38.3	74	129	124	0	36	35
2014	9	30	3	41	2	0.699	-0.118	4.075	0.013	0.01	0	39.6	37.8	74	128	123	0	36	35
2014	9	30	3	51	2	0.748	-0.105	4.075	0.016	0.013	0	39.6	37.4	73.5	128	122	0	36	35
2014	9	30	4	1	2	0.705	-0.089	4.075	0.013	0.01	0	40	37.8	73.5	128	123	0	35	35
2014	9	30	4	11	2	0.702	-0.092	4.075	0.01	0.007	0	39.6	37.8	73.1	128	123	0	36	35
2014	9	30	4	21	2	0.715	-0.105	4.075	0.01	0.007	0	39.6	37.8	66.7	128	122	0	36	34
2014	9	30	4	31	2	0.709	-0.112	4.075	0.01	0.007	0	39.6	37.8	73.1	128	123	0	36	35
2014	9	30	4	41	2	0.725	-0.128	4.075	0.01	0.007	0	39.1	37.8	72.7	127	122	0	36	34
2014	9	30	4	51	2	0.682	-0.112	4.075	0.01	0.007	0	40.4	37.8	72.2	129	123	0	35	35
2014	9	30	5	1	2	0.682	-0.118	4.072	0.016	0.013	0	39.6	37.8	71.8	129	123	0	37	35
2014	9	30	5	11	2	0.719	-0.085	4.075	0.01	0.007	0	39.1	37.4	71.8	127	122	0	36	35
2014	9	30	5	21	2	0.696	-0.144	4.075	0.01	0.007	0	38.7	37.4	71.8	127	122	0	37	35
2014	9	30	5	31	2	0.712	-0.092	4.075	0.01	0.007	0	39.1	37.4	72.7	127	122	0	36	35
2014	9	30	5	41	2	0.728	-0.079	4.075	0.01	0.007	0	40.4	38.3	71	129	123	0	35	34
2014	9	30	5	51	2	0.715	-0.108	4.075	0.01	0.007	0	39.6	37.4	72.2	127	121	0	35	34
2014	9	30	6	1	2	0.735	-0.105	4.075	0.013	0.01	0	40.4	39.1	71.4	130	125	0	36	34
2014	9	30	6	11	2	0.712	-0.075	4.075	0.01	0.007	0	41.3	40	71.4	132	127	0	36	34
2014	9	30	6	21	2	0.699	-0.105	4.075	0.01	0.007	0	40.4	38.3	71.4	129	124	0	35	35
2014	9	30	6	31	2	0.719	-0.075	4.075	0.01	0.007	0	39.6	37.8	72.7	128	123	0	36	35
2014	9	30	6	41	2	0.722	-0.098	4.078	0.01	0.007	0	40	38.3	72.2	129	124	0	36	35
2014	9	30	6	51	2	0.728	-0.128	4.075	0.01	0.007	0	39.1	37.8	71.8	127	122	0	36	34
2014	9	30	7	1	2	0.725	-0.075	4.075	0.01	0.007	0	38.7	37	71.8	126	121	0	36	35
2014	9	30	7	11	2	0.715	-0.121	4.078	0.01	0.007	0	38.7	37	71.8	126	121	0	36	35
2014	9	30	7	21	2	0.719	-0.079	4.078	0.013	0.01	0	38.7	37	72.2	125	120	0	35	34
2014	9	30	7	31	2	0.705	-0.092	4.075	0.013	0.01	0	37.8	36.5	72.2	124	119	0	36	34
2014	9	30	7	41	2	0.696	-0.089	4.075	0.01	0.007	0	37.8	36.1	72.2	124	119	0	36	35
2014	9	30	7	51	2	0.696	-0.082	4.075	0.01	0.007	0	38.3	36.1	73.1	124	119	0	35	35
2014	9	30	8	1	2	0.712	-0.121	4.075	0.01	0.007	0	37.8	36.1	72.2	124	119	0	36	35
2014	9	30	8	11	2	0.702	-0.118	4.075	0.01	0.007	0	37.8	36.1	72.2	124	119	0	36	35
2014	9	30	8	21	2	0.715	-0.075	4.075	0.01	0.007	0	38.3	36.1	72.2	124	119	0	35	35
2014	9	30	8	31	2	0.722	-0.092	4.075	0.01	0.007	0	38.3	36.1	72.7	124	119	0	35	35
2014	9	30	8	41	2	0.705	-0.098	4.075	0.01	0.007	0	37.8	36.5	72.7	124	119	0	36	34
2014	9	30	8	51	2	0.725	-0.059	4.075	0.01	0.007	0	37.8	36.5	72.7	124	119	0	36	34
2014	9	30	9	1	2	0.719	-0.095	4.075	0.01	0.007	0	37.8	36.5	73.5	124	119	0	36	34
2014	9	30	9	11	2	0.719	-0.095	4.075	0.01	0.007	0	37.8	36.1	73.1	124	119	0	36	35
2014	9	30	9	21	2	0.735	-0.095	4.075	0.01	0.007	0	37.4	36.5	73.5	124	119	0	37	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	9	31	2	0.719	-0.085	4.075	0.013	0.01	0	37.4	36.5	73.5	124	119	0	37	34
2014	9	30	9	41	2	0.751	-0.095	4.072	0.01	0.007	0	37.8	35.7	73.1	124	118	0	36	35
2014	9	30	9	51	2	0.702	-0.095	4.072	0.013	0.01	0	38.3	36.5	73.1	124	119	0	35	34
2014	9	30	10	1	2	0.725	-0.108	4.072	0.016	0.013	0	38.3	36.1	73.1	124	119	0	35	35
2014	9	30	10	11	2	0.712	-0.079	4.072	0.01	0.007	0	37.4	36.1	73.5	123	118	0	36	34
2014	9	30	10	21	2	0.719	-0.095	4.072	0.01	0.007	0	37.4	35.7	73.5	123	118	0	36	35
2014	9	30	10	31	2	0.735	-0.095	4.072	0.01	0.007	0	37.4	36.1	73.1	123	118	0	36	34
2014	9	30	10	41	2	0.689	-0.108	4.072	0.013	0.01	0	37.8	35.7	73.5	124	118	0	36	35
2014	9	30	10	51	2	0.732	-0.062	4.072	0.01	0.007	0	37.8	36.1	74.4	124	118	0	36	34
2014	9	30	11	1	2	0.728	-0.112	4.072	0.01	0.007	0	37.4	36.1	74	123	118	0	36	34
2014	9	30	11	11	2	0.728	-0.135	4.072	0.013	0.01	0	37.8	36.5	74.8	123	119	0	35	34
2014	9	30	11	21	2	0.725	-0.092	4.068	0.013	0.01	0	37.8	36.1	74.4	124	119	0	36	35
2014	9	30	11	31	2	0.712	-0.092	4.068	0.01	0.007	0	37.8	36.5	74.8	124	119	0	36	34
2014	9	30	11	41	2	0.728	-0.128	4.068	0.01	0.007	0	37.4	36.1	74.4	123	118	0	36	34
2014	9	30	11	51	2	0.712	-0.118	4.068	0.01	0.007	0	37.4	36.1	63.6	122	118	0	35	34
2014	9	30	12	1	2	0.735	-0.121	4.068	0.013	0.01	0	37	36.1	64.5	122	118	0	36	34
2014	9	30	12	11	2	0.751	-0.128	4.068	0.01	0.007	0	37.4	35.7	64.1	122	118	0	35	35
2014	9	30	12	21	2	0.722	-0.115	4.065	0.013	0.01	0	37	36.1	56.3	122	118	0	36	34
2014	9	30	12	31	2	0.719	-0.118	4.065	0.016	0.013	0	37.4	36.1	62.4	122	118	0	35	34
2014	9	30	12	41	2	0.722	-0.164	4.065	0.01	0.007	0	37	35.3	52.5	121	116	0	35	34
2014	9	30	12	51	2	0.719	-0.112	4.065	0.013	0.01	0	37.4	36.1	58.9	123	119	0	36	35
2014	9	30	13	1	2	0.725	-0.138	4.065	0.01	0.007	0	36.5	36.1	52.9	122	118	0	37	34
2014	9	30	13	11	2	0.738	-0.121	4.065	0.013	0.01	0	37.4	35.7	57.2	123	118	0	36	35
2014	9	30	13	21	2	0.741	-0.102	4.062	0.01	0.007	0	37.4	36.1	52	123	119	0	36	35
2014	9	30	13	31	2	0.741	-0.095	4.065	0.01	0.007	0	37.4	36.5	55.5	123	119	0	36	34
2014	9	30	13	41	2	0.709	-0.167	4.062	0.01	0.007	0	36.5	35.7	49.5	121	117	0	36	34
2014	9	30	13	51	2	0.705	-0.141	4.062	0.01	0.007	0	37.4	36.5	62.4	123	119	0	36	34
2014	9	30	14	1	2	0.722	-0.138	4.062	0.01	0.007	0	37	35.7	60.2	122	118	0	36	35
2014	9	30	14	11	2	0.715	-0.121	4.062	0.013	0.01	0	37	36.5	55	122	119	0	36	34
2014	9	30	14	21	2	0.725	-0.154	4.058	0.01	0.007	0	37	35.7	54.6	122	118	0	36	35
2014	9	30	14	31	2	0.719	-0.138	4.058	0.01	0.007	0	37	36.1	55.9	122	118	0	36	34
2014	9	30	14	41	2	0.712	-0.141	4.058	0.01	0.007	0	37	35.7	56.3	122	118	0	36	35
2014	9	30	14	51	2	0.732	-0.148	4.058	0.01	0.007	0	37.4	35.7	56.8	122	118	0	35	35
2014	9	30	15	1	2	0.735	-0.128	4.058	0.01	0.007	0	37	36.5	54.6	122	119	0	36	34
2014	9	30	15	11	2	0.735	-0.121	4.055	0.013	0.01	0	37	36.5	50.7	122	119	0	36	34
2014	9	30	15	21	2	0.725	-0.121	4.055	0.01	0.007	0	37.4	36.1	50.7	122	119	0	35	35
2014	9	30	15	31	2	0.679	-0.154	4.055	0.01	0.007	0	37	35.7	50.3	122	118	0	36	35
2014	9	30	15	41	2	0.732	-0.141	4.055	0.01	0.007	0	37.4	36.1	53.3	122	118	0	35	34
2014	9	30	15	51	2	0.696	-0.141	4.052	0.016	0.013	0	37.4	37	51.2	123	120	0	36	34
2014	9	30	16	1	2	0.702	-0.154	4.052	0.01	0.007	0	37.8	37	48.2	124	121	0	36	35
2014	9	30	16	11	2	0.719	-0.167	4.055	0.01	0.007	0	37	36.5	52.9	122	119	0	36	34
2014	9	30	16	21	2	0.732	-0.108	4.052	0.01	0.007	0	38.3	37	49.5	124	121	0	35	35
2014	9	30	16	31	2	0.712	-0.144	4.052	0.01	0.007	0	37.8	37	49.5	123	120	0	35	34
2014	9	30	16	41	2	0.699	-0.121	4.049	0.016	0.013	0	37.8	36.5	49.9	123	120	0	35	35
2014	9	30	16	51	2	0.689	-0.131	4.052	0.01	0.007	0	37.4	37	49	123	120	0	36	34
2014	9	30	17	1	2	0.725	-0.167	4.049	0.01	0.007	0	37	36.1	50.3	122	118	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	17	11	2	0.738	-0.148	4.049	0.016	0.013	0	37.8	37	51.6	123	120	0	35	34
2014	9	30	17	21	2	0.725	-0.154	4.049	0.013	0.01	0	37	36.5	48.6	122	119	0	36	34
2014	9	30	17	31	2	0.682	-0.141	4.049	0.013	0.01	0	37	36.1	54.2	122	119	0	36	35
2014	9	30	17	41	2	0.761	-0.112	4.049	0.01	0.007	0	37	36.1	55.5	122	119	0	36	35
2014	9	30	17	51	2	0.728	-0.138	4.049	0.01	0.007	0	38.3	37	59.8	124	120	0	35	34
2014	9	30	18	1	2	0.705	-0.082	4.049	0.01	0.007	0	37.4	37	58.9	123	120	0	36	34
2014	9	30	18	11	2	0.702	-0.112	4.052	0.013	0.01	0	37.8	37	71.8	123	120	0	35	34
2014	9	30	18	21	2	0.741	-0.102	4.052	0.01	0.007	0	37.8	37.4	72.2	124	121	0	36	34
2014	9	30	18	31	2	0.738	-0.075	4.052	0.01	0.007	0	37.8	37	71.4	124	121	0	36	35
2014	9	30	18	41	2	0.732	-0.082	4.052	0.01	0.007	0	38.3	37	71.4	124	121	0	35	35
2014	9	30	18	51	2	0.712	-0.092	4.049	0.01	0.007	0	38.7	37.4	71.4	125	122	0	35	35
2014	9	30	19	1	2	0.732	-0.072	4.049	0.01	0.007	0	38.7	37.4	70.5	126	122	0	36	35
2014	9	30	19	11	2	0.741	-0.105	4.049	0.013	0.01	0	39.1	37.8	70.5	126	122	0	35	34
2014	9	30	19	21	2	0.709	-0.092	4.049	0.01	0.007	0	40	38.3	71	128	123	0	35	34
2014	9	30	19	31	2	0.712	-0.108	4.049	0.013	0.01	0	39.6	38.3	71	128	123	0	36	34
2014	9	30	19	41	2	0.732	-0.125	4.049	0.01	0.007	0	39.6	37.8	71.8	127	123	0	35	35
2014	9	30	19	51	2	0.709	-0.108	4.049	0.01	0.007	0	40.4	38.7	71	130	125	0	36	35
2014	9	30	20	1	2	0.719	-0.075	4.045	0.013	0.01	0	40.9	39.6	71	130	126	0	35	34
2014	9	30	20	11	2	0.719	-0.102	4.042	0.01	0.007	0	41.3	39.6	71	131	127	0	35	35
2014	9	30	20	21	2	0.712	-0.089	4.042	0.01	0.007	0	40.4	39.1	71	129	125	0	35	34
2014	9	30	20	31	2	0.722	-0.092	4.042	0.01	0.007	0	40	38.3	71	128	124	0	35	35
2014	9	30	20	41	2	0.709	-0.092	4.042	0.01	0.007	0	40	38.7	70.5	129	125	0	36	35
2014	9	30	20	51	2	0.719	-0.062	4.042	0.013	0.01	0	39.6	38.7	71.4	128	124	0	36	34
2014	9	30	21	1	2	0.709	-0.085	4.042	0.01	0.007	0	39.6	37.8	71	128	123	0	36	35
2014	9	30	21	11	2	0.702	-0.075	4.042	0.01	0.007	0	39.6	38.7	70.5	128	124	0	36	34
2014	9	30	21	21	2	0.732	-0.085	4.042	0.01	0.007	0	39.6	38.3	71.8	128	123	0	36	34
2014	9	30	21	31	2	0.709	-0.102	4.045	0.013	0.01	0	40	38.3	72.2	128	123	0	35	34
2014	9	30	21	41	2	0.755	-0.075	4.045	0.01	0.007	0	39.6	38.7	72.7	128	124	0	36	34
2014	9	30	21	51	2	0.745	-0.075	4.045	0.013	0.01	0	40	38.7	72.7	129	125	0	36	35
2014	9	30	22	1	2	0.699	-0.075	4.049	0.01	0.007	0	40	38.7	73.5	129	125	0	36	35
2014	9	30	22	11	2	0.725	-0.108	4.045	0.01	0.007	0	40	38.3	73.1	129	124	0	36	35
2014	9	30	22	21	2	0.686	-0.092	4.045	0.013	0.01	0	40	38.3	72.2	128	124	0	35	35
2014	9	30	22	31	2	0.692	-0.079	4.042	0.01	0.007	0	40	38.3	72.7	128	124	0	35	35
2014	9	30	22	41	2	0.732	-0.092	4.045	0.016	0.013	0	40	39.1	73.1	129	125	0	36	34
2014	9	30	22	51	2	0.709	-0.095	4.045	0.013	0.01	0	40	38.7	73.1	129	124	0	36	34
2014	9	30	23	1	2	0.699	-0.092	4.042	0.013	0.01	0	40	38.3	72.2	128	124	0	35	35
2014	9	30	23	11	2	0.722	-0.092	4.042	0.01	0.007	0	39.6	38.7	73.1	128	124	0	36	34
2014	9	30	23	21	2	0.722	-0.089	4.042	0.013	0.01	0	39.6	38.3	52.5	128	124	0	36	35
2014	9	30	23	31	2	0.682	-0.092	4.042	0.01	0.007	0	40.9	39.6	66.2	130	126	0	35	34
2014	9	30	23	41	2	0.722	-0.066	4.042	0.013	0.01	0	40.4	39.1	53.8	129	125	0	35	34
2014	9	30	23	51	2	0.715	-0.085	4.042	0.01	0.007	0	40.4	39.1	49.5	130	125	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	0	3	21	35	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	1	0	13	21	36	0	0	0	0	0	0	0	66.27	0	0	11.6
2014	9	1	0	23	21	35	0	0	0	0	0	0	0	66.27	0	0	11.6
2014	9	1	0	33	21	34	0	0	0	0	0	0	0	66.25	0	0	11.4
2014	9	1	0	43	21	35	0	0	0	0	0	0	0	66.25	0	0	11.2
2014	9	1	0	53	21	35	0	0	0	0	0	0	0	66.22	0	0	11.2
2014	9	1	1	3	21	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	1	1	13	21	36	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	1	1	23	21	35	0	0	0	0	0	0	0	66.16	0	0	11.2
2014	9	1	1	33	21	35	0	0	0	0	0	0	0	66.13	0	0	11.2
2014	9	1	1	43	21	35	0	0	0	0	0	0	0	66.11	0	0	11.2
2014	9	1	1	53	21	35	0	0	0	0	0	0	0	66.07	0	0	11.2
2014	9	1	2	3	21	35	0	0	0	0	0	0	0	66.04	0	0	11.2
2014	9	1	2	13	21	35	0	0	0	0	0	0	0	66	0	0	11
2014	9	1	2	23	21	35	0	0	0	0	0	0	0	65.97	0	0	11
2014	9	1	2	33	21	35	0	0	0	0	0	0	0	65.93	0	0	11
2014	9	1	2	43	21	34	0	0	0	0	0	0	0	65.91	0	0	10.8
2014	9	1	2	53	21	35	0	0	0	0	0	0	0	65.88	0	0	11
2014	9	1	3	3	21	35	0	0	0	0	0	0	0	65.84	0	0	11
2014	9	1	3	13	21	34	0	0	0	0	0	0	0	65.8	0	0	11
2014	9	1	3	23	21	35	0	0	0	0	0	0	0	65.77	0	0	11
2014	9	1	3	33	21	35	0	0	0	0	0	0	0	65.73	0	0	11
2014	9	1	3	43	21	34	0	0	0	0	0	0	0	65.71	0	0	11
2014	9	1	3	55	14	35	0	0	0	0	0	0	0	65.68	0	0	11.2
2014	9	1	4	5	14	35	0	0	0	0	0	0	0	65.66	0	0	11.2
2014	9	1	4	15	14	35	0	0	0	0	0	0	0	65.62	0	0	11.2
2014	9	1	4	25	14	35	0	0	0	0	0	0	0	65.61	0	0	11.2
2014	9	1	4	35	14	36	0	0	0	0	0	0	0	65.57	0	0	11.2
2014	9	1	4	45	14	35	0	0	0	0	0	0	0	65.55	0	0	11.8
2014	9	1	4	55	14	35	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	1	5	5	14	35	0	0	0	0	0	0	0	65.5	0	0	11.8
2014	9	1	5	15	14	35	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	9	1	5	25	14	35	0	0	0	0	0	0	0	65.44	0	0	11.8
2014	9	1	5	35	14	34	0	0	0	0	0	0	0	65.43	0	0	11.8
2014	9	1	5	45	14	35	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	1	5	55	14	34	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	9	1	6	5	14	35	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	1	6	15	14	36	0	0	0	0	0	0	0	65.32	0	0	11.8
2014	9	1	6	25	14	35	0	0	0	0	0	0	0	65.28	0	0	11.8
2014	9	1	6	35	14	35	0	0	0	0	0	0	0	65.26	0	0	11.8
2014	9	1	6	45	14	35	0	0	0	0	0	0	0	65.23	0	0	11.8
2014	9	1	6	55	14	35	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	1	7	5	14	35	0	0	0	0	0	0	0	65.17	0	0	11.8
2014	9	1	7	15	14	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	1	7	25	14	36	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	1	7	35	14	35	0	0	0	0	0	0	0	65.12	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	7	45	14	35	0	0	0	0	0	0	0	65.08	0	0	12.4
2014	9	1	7	55	14	35	0	0	0	0	0	0	0	65.1	0	0	12.4
2014	9	1	8	5	14	35	0	0	0	0	0	0	0	65.12	0	0	12.6
2014	9	1	8	15	14	35	0	0	0	0	0	0	0	65.14	0	0	12.6
2014	9	1	8	25	14	35	0	0	0	0	0	0	0	65.16	0	0	12.8
2014	9	1	8	35	14	35	0	0	0	0	0	0	0	65.19	0	0	12.8
2014	9	1	8	45	14	34	0	0	0	0	0	0	0	65.19	0	0	12.8
2014	9	1	8	55	14	35	0	0	0	0	0	0	0	65.25	0	0	13
2014	9	1	9	5	14	35	0	0	0	0	0	0	0	65.26	0	0	13.2
2014	9	1	9	15	14	35	0	0	0	0	0	0	0	65.3	0	0	13.2
2014	9	1	9	25	14	35	0	0	0	0	0	0	0	65.34	0	0	13.2
2014	9	1	9	35	14	35	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	1	9	45	14	35	0	0	0	0	0	0	0	65.41	0	0	13.2
2014	9	1	9	55	14	35	0	0	0	0	0	0	0	65.46	0	0	13
2014	9	1	10	5	14	34	0	0	0	0	0	0	0	65.5	0	0	13
2014	9	1	10	15	14	36	0	0	0	0	0	0	0	65.55	0	0	13
2014	9	1	10	25	14	35	0	0	0	0	0	0	0	65.61	0	0	13
2014	9	1	10	35	14	35	0	0	0	0	0	0	0	65.64	0	0	13
2014	9	1	10	45	14	35	0	0	0	0	0	0	0	65.7	0	0	12.8
2014	9	1	10	55	14	35	0	0	0	0	0	0	0	65.73	0	0	13
2014	9	1	11	5	14	35	0	0	0	0	0	0	0	65.79	0	0	13
2014	9	1	11	15	14	35	0	0	0	0	0	0	0	65.82	0	0	13
2014	9	1	11	25	14	35	0	0	0	0	0	0	0	65.8	0	0	13
2014	9	1	11	35	14	35	0	0	0	0	0	0	0	65.79	0	0	13
2014	9	1	11	45	14	34	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	1	11	55	14	35	0	0	0	0	0	0	0	65.88	0	0	13
2014	9	1	12	5	14	34	0	0	0	0	0	0	0	65.91	0	0	13
2014	9	1	12	15	14	35	0	0	0	0	0	0	0	65.93	0	0	13
2014	9	1	12	25	14	35	0	0	0	0	0	0	0	65.98	0	0	13
2014	9	1	12	35	14	35	0	0	0	0	0	0	0	66	0	0	13
2014	9	1	12	45	14	35	0	0	0	0	0	0	0	66.04	0	0	13
2014	9	1	12	55	14	35	0	0	0	0	0	0	0	66.07	0	0	13
2014	9	1	13	5	14	35	0	0	0	0	0	0	0	66.09	0	0	13
2014	9	1	13	15	14	35	0	0	0	0	0	0	0	66.11	0	0	13
2014	9	1	13	25	14	35	0	0	0	0	0	0	0	66.11	0	0	13
2014	9	1	13	35	14	35	0	0	0	0	0	0	0	66.15	0	0	13
2014	9	1	13	45	14	35	0	0	0	0	0	0	0	66.18	0	0	13
2014	9	1	13	55	14	35	0	0	0	0	0	0	0	66.2	0	0	13
2014	9	1	14	5	14	36	0	0	0	0	0	0	0	66.18	0	0	13
2014	9	1	14	15	14	34	0	0	0	0	0	0	0	66.22	0	0	13
2014	9	1	14	25	14	36	0	0	0	0	0	0	0	66.16	0	0	13
2014	9	1	14	35	14	35	0	0	0	0	0	0	0	66.18	0	0	13
2014	9	1	14	45	14	34	0	0	0	0	0	0	0	66.16	0	0	12.8
2014	9	1	14	55	14	35	0	0	0	0	0	0	0	66.16	0	0	12.8
2014	9	1	15	5	14	35	0	0	0	0	0	0	0	66.15	0	0	12.8
2014	9	1	15	15	14	35	0	0	0	0	0	0	0	66.15	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	15	25	14	35	0	0	0	0	0	0	0	66.11	0	0	12.8
2014	9	1	15	35	14	35	0	0	0	0	0	0	0	66.09	0	0	12.8
2014	9	1	15	45	14	35	0	0	0	0	0	0	0	66.09	0	0	12.8
2014	9	1	15	55	14	35	0	0	0	0	0	0	0	66.06	0	0	12.8
2014	9	1	16	5	14	35	0	0	0	0	0	0	0	66.06	0	0	12.8
2014	9	1	16	15	14	35	0	0	0	0	0	0	0	66.04	0	0	12.8
2014	9	1	16	25	14	35	0	0	0	0	0	0	0	66.04	0	0	12.8
2014	9	1	16	35	14	35	0	0	0	0	0	0	0	65.98	0	0	12.8
2014	9	1	16	45	14	35	0	0	0	0	0	0	0	65.95	0	0	12.8
2014	9	1	16	55	14	36	0	0	0	0	0	0	0	65.97	0	0	12.8
2014	9	1	17	5	14	35	0	0	0	0	0	0	0	65.98	0	0	12.8
2014	9	1	17	15	14	35	0	0	0	0	0	0	0	65.97	0	0	12.4
2014	9	1	17	25	14	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	1	17	35	14	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	1	17	45	14	34	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	1	17	55	14	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	1	18	5	14	35	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	1	18	15	14	35	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	1	18	25	14	35	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	1	18	35	14	36	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	1	18	45	14	34	0	0	0	0	0	0	0	65.91	0	0	12
2014	9	1	18	55	14	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	1	19	5	14	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	1	19	15	14	34	0	0	0	0	0	0	0	65.95	0	0	11.8
2014	9	1	19	25	14	35	0	0	0	0	0	0	0	65.97	0	0	11.8
2014	9	1	19	35	14	35	0	0	0	0	0	0	0	65.98	0	0	11.8
2014	9	1	19	45	14	35	0	0	0	0	0	0	0	66	0	0	11.8
2014	9	1	19	55	14	35	0	0	0	0	0	0	0	66.02	0	0	11.8
2014	9	1	20	5	14	35	0	0	0	0	0	0	0	66.06	0	0	11.8
2014	9	1	20	15	14	35	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	1	20	25	14	35	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	1	20	35	14	35	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	1	20	45	14	35	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	1	20	55	14	35	0	0	0	0	0	0	0	66.13	0	0	11.8
2014	9	1	21	5	14	35	0	0	0	0	0	0	0	66.15	0	0	11.8
2014	9	1	21	15	14	35	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	1	21	25	14	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	1	21	35	14	36	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	1	21	45	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	1	21	55	14	35	0	0	0	0	0	0	0	66.24	0	0	11.4
2014	9	1	22	5	14	35	0	0	0	0	0	0	0	66.24	0	0	11.4
2014	9	1	22	15	14	35	0	0	0	0	0	0	0	66.25	0	0	11.4
2014	9	1	22	25	14	35	0	0	0	0	0	0	0	66.25	0	0	11.4
2014	9	1	22	35	14	34	0	0	0	0	0	0	0	66.27	0	0	11.4
2014	9	1	22	45	14	35	0	0	0	0	0	0	0	66.27	0	0	11.8
2014	9	1	22	55	14	35	0	0	0	0	0	0	0	66.27	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	23	5	14	35	0	0	0	0	0	0	0	66.29	0	0	11.8
2014	9	1	23	15	14	34	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	1	23	25	14	35	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	1	23	35	14	35	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	1	23	45	14	35	0	0	0	0	0	0	0	66.29	0	0	11
2014	9	1	23	55	14	35	0	0	0	0	0	0	0	66.29	0	0	11
2014	9	2	0	5	14	34	0	0	0	0	0	0	0	66.29	0	0	11
2014	9	2	0	15	14	34	0	0	0	0	0	0	0	66.27	0	0	11
2014	9	2	0	25	14	35	0	0	0	0	0	0	0	66.27	0	0	11
2014	9	2	0	35	14	35	0	0	0	0	0	0	0	66.27	0	0	11
2014	9	2	0	45	14	35	0	0	0	0	0	0	0	66.27	0	0	11
2014	9	2	0	55	14	35	0	0	0	0	0	0	0	66.25	0	0	11
2014	9	2	1	5	14	35	0	0	0	0	0	0	0	66.25	0	0	11
2014	9	2	1	15	14	35	0	0	0	0	0	0	0	66.24	0	0	10.8
2014	9	2	1	25	14	34	0	0	0	0	0	0	0	66.22	0	0	10.8
2014	9	2	1	35	14	35	0	0	0	0	0	0	0	66.22	0	0	10.8
2014	9	2	1	45	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	2	1	55	14	35	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	2	2	5	14	35	0	0	0	0	0	0	0	66.15	0	0	11.2
2014	9	2	2	15	14	35	0	0	0	0	0	0	0	66.15	0	0	11.2
2014	9	2	2	25	14	35	0	0	0	0	0	0	0	66.11	0	0	11.2
2014	9	2	2	35	14	35	0	0	0	0	0	0	0	66.09	0	0	11.2
2014	9	2	2	45	14	35	0	0	0	0	0	0	0	66.06	0	0	11.6
2014	9	2	2	55	14	35	0	0	0	0	0	0	0	66.04	0	0	11.6
2014	9	2	3	5	14	35	0	0	0	0	0	0	0	66	0	0	11.6
2014	9	2	3	15	14	35	0	0	0	0	0	0	0	65.97	0	0	11.6
2014	9	2	3	25	14	35	0	0	0	0	0	0	0	65.95	0	0	11.6
2014	9	2	3	35	14	35	0	0	0	0	0	0	0	65.91	0	0	11.6
2014	9	2	3	45	14	35	0	0	0	0	0	0	0	65.88	0	0	11
2014	9	2	3	55	14	35	0	0	0	0	0	0	0	65.86	0	0	11
2014	9	2	4	5	14	35	0	0	0	0	0	0	0	65.82	0	0	11
2014	9	2	4	15	14	35	0	0	0	0	0	0	0	65.8	0	0	11
2014	9	2	4	25	14	35	0	0	0	0	0	0	0	65.79	0	0	11
2014	9	2	4	35	14	34	0	0	0	0	0	0	0	65.75	0	0	11
2014	9	2	4	45	14	35	0	0	0	0	0	0	0	65.71	0	0	11
2014	9	2	4	55	14	35	0	0	0	0	0	0	0	65.7	0	0	11
2014	9	2	5	5	14	35	0	0	0	0	0	0	0	65.66	0	0	11.2
2014	9	2	5	15	14	35	0	0	0	0	0	0	0	65.64	0	0	11.2
2014	9	2	5	25	14	35	0	0	0	0	0	0	0	65.61	0	0	11.2
2014	9	2	5	35	14	35	0	0	0	0	0	0	0	65.57	0	0	11
2014	9	2	5	45	14	35	0	0	0	0	0	0	0	65.53	0	0	11.2
2014	9	2	5	55	14	35	0	0	0	0	0	0	0	65.52	0	0	11.2
2014	9	2	6	5	14	35	0	0	0	0	0	0	0	65.5	0	0	11
2014	9	2	6	15	14	35	0	0	0	0	0	0	0	65.46	0	0	11
2014	9	2	6	25	14	35	0	0	0	0	0	0	0	65.43	0	0	11
2014	9	2	6	35	14	35	0	0	0	0	0	0	0	65.43	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	6	45	14	36	0	0	0	0	0	0	0	65.39	0	0	11.4
2014	9	2	6	55	14	34	0	0	0	0	0	0	0	65.37	0	0	11.4
2014	9	2	7	5	14	35	0	0	0	0	0	0	0	65.34	0	0	11.2
2014	9	2	7	15	14	35	0	0	0	0	0	0	0	65.3	0	0	11.8
2014	9	2	7	25	14	35	0	0	0	0	0	0	0	65.28	0	0	12.4
2014	9	2	7	35	14	35	0	0	0	0	0	0	0	65.26	0	0	12.8
2014	9	2	7	45	14	35	0	0	0	0	0	0	0	65.23	0	0	12.6
2014	9	2	7	55	14	35	0	0	0	0	0	0	0	65.26	0	0	12.6
2014	9	2	8	5	14	36	0	0	0	0	0	0	0	65.28	0	0	12.8
2014	9	2	8	15	14	35	0	0	0	0	0	0	0	65.28	0	0	13
2014	9	2	8	25	14	35	0	0	0	0	0	0	0	65.32	0	0	13
2014	9	2	8	35	14	35	0	0	0	0	0	0	0	65.34	0	0	13.2
2014	9	2	8	45	14	35	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	2	8	55	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	2	9	5	14	36	0	0	0	0	0	0	0	65.43	0	0	13
2014	9	2	9	15	14	36	0	0	0	0	0	0	0	65.46	0	0	13.2
2014	9	2	9	25	14	35	0	0	0	0	0	0	0	65.48	0	0	13
2014	9	2	9	35	14	34	0	0	0	0	0	0	0	65.52	0	0	13
2014	9	2	9	45	14	35	0	0	0	0	0	0	0	65.57	0	0	13
2014	9	2	9	55	14	35	0	0	0	0	0	0	0	65.61	0	0	13
2014	9	2	10	5	14	35	0	0	0	0	0	0	0	65.66	0	0	13
2014	9	2	10	15	14	35	0	0	0	0	0	0	0	65.7	0	0	13
2014	9	2	10	25	14	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	2	10	35	14	35	0	0	0	0	0	0	0	65.8	0	0	13
2014	9	2	10	45	14	36	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	2	10	55	14	35	0	0	0	0	0	0	0	65.88	0	0	13
2014	9	2	11	5	14	35	0	0	0	0	0	0	0	65.93	0	0	13
2014	9	2	11	15	14	36	0	0	0	0	0	0	0	65.98	0	0	13
2014	9	2	11	25	14	35	0	0	0	0	0	0	0	66.02	0	0	13
2014	9	2	11	35	14	35	0	0	0	0	0	0	0	66.07	0	0	13
2014	9	2	11	45	14	35	0	0	0	0	0	0	0	66.11	0	0	13
2014	9	2	11	55	14	35	0	0	0	0	0	0	0	66.16	0	0	13
2014	9	2	12	5	14	35	0	0	0	0	0	0	0	66.18	0	0	13
2014	9	2	12	15	14	35	0	0	0	0	0	0	0	66.24	0	0	13
2014	9	2	12	25	14	35	0	0	0	0	0	0	0	66.27	0	0	13
2014	9	2	12	35	14	35	0	0	0	0	0	0	0	66.31	0	0	13
2014	9	2	12	45	14	35	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	2	12	55	14	35	0	0	0	0	0	0	0	66.34	0	0	13
2014	9	2	13	5	14	36	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	2	13	15	14	35	0	0	0	0	0	0	0	66.4	0	0	13
2014	9	2	13	25	14	34	0	0	0	0	0	0	0	66.42	0	0	13
2014	9	2	13	35	14	36	0	0	0	0	0	0	0	66.42	0	0	13
2014	9	2	13	45	14	35	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	2	13	55	14	36	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	2	14	5	14	35	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	2	14	15	14	35	0	0	0	0	0	0	0	66.42	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	14	25	14	35	0	0	0	0	0	0	0	66.42	0	0	13
2014	9	2	14	35	14	35	0	0	0	0	0	0	0	66.49	0	0	13
2014	9	2	14	45	14	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	2	14	55	14	35	0	0	0	0	0	0	0	66.52	0	0	13
2014	9	2	15	5	14	35	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	2	15	15	14	35	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	2	15	25	14	35	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	2	15	35	14	34	0	0	0	0	0	0	0	66.29	0	0	13
2014	9	2	15	45	14	35	0	0	0	0	0	0	0	66.29	0	0	13
2014	9	2	15	55	14	35	0	0	0	0	0	0	0	66.27	0	0	13
2014	9	2	16	5	14	35	0	0	0	0	0	0	0	66.13	0	0	13
2014	9	2	16	15	14	35	0	0	0	0	0	0	0	66.09	0	0	13
2014	9	2	16	25	14	36	0	0	0	0	0	0	0	66.07	0	0	13
2014	9	2	16	35	14	35	0	0	0	0	0	0	0	66.04	0	0	13
2014	9	2	16	45	14	35	0	0	0	0	0	0	0	66.02	0	0	13
2014	9	2	16	55	14	35	0	0	0	0	0	0	0	66.02	0	0	13
2014	9	2	17	5	14	35	0	0	0	0	0	0	0	66.02	0	0	13
2014	9	2	17	15	14	35	0	0	0	0	0	0	0	66	0	0	12.4
2014	9	2	17	25	14	35	0	0	0	0	0	0	0	65.98	0	0	12.2
2014	9	2	17	35	14	35	0	0	0	0	0	0	0	66	0	0	12
2014	9	2	17	45	14	35	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	2	17	55	14	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	2	18	5	14	34	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	2	18	15	14	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	2	18	25	14	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	2	18	35	14	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	2	18	45	14	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	2	18	55	14	34	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	2	19	5	14	35	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	2	19	15	14	35	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	2	19	25	14	34	0	0	0	0	0	0	0	66	0	0	12
2014	9	2	19	35	14	35	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	2	19	45	14	35	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	2	19	55	14	35	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	2	20	5	14	36	0	0	0	0	0	0	0	66.07	0	0	12
2014	9	2	20	15	14	34	0	0	0	0	0	0	0	66.09	0	0	12
2014	9	2	20	25	14	35	0	0	0	0	0	0	0	66.11	0	0	12
2014	9	2	20	35	14	35	0	0	0	0	0	0	0	66.13	0	0	12
2014	9	2	20	45	14	35	0	0	0	0	0	0	0	66.15	0	0	11.8
2014	9	2	20	55	14	35	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	2	21	5	14	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	2	21	15	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	2	21	25	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	2	21	35	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	2	21	45	14	35	0	0	0	0	0	0	0	66.24	0	0	11.2
2014	9	2	21	55	14	35	0	0	0	0	0	0	0	66.25	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	22	5	14	36	0	0	0	0	0	0	0	66.27	0	0	11.2
2014	9	2	22	15	14	35	0	0	0	0	0	0	0	66.27	0	0	11.2
2014	9	2	22	25	14	35	0	0	0	0	0	0	0	66.29	0	0	11.2
2014	9	2	22	35	14	35	0	0	0	0	0	0	0	66.31	0	0	11.2
2014	9	2	22	45	14	35	0	0	0	0	0	0	0	66.31	0	0	11.2
2014	9	2	22	55	14	35	0	0	0	0	0	0	0	66.31	0	0	11
2014	9	2	23	5	14	34	0	0	0	0	0	0	0	66.33	0	0	11
2014	9	2	23	15	14	34	0	0	0	0	0	0	0	66.31	0	0	11
2014	9	2	23	25	14	35	0	0	0	0	0	0	0	66.33	0	0	11
2014	9	2	23	35	14	35	0	0	0	0	0	0	0	66.33	0	0	11
2014	9	2	23	45	14	35	0	0	0	0	0	0	0	66.33	0	0	11.6
2014	9	2	23	55	14	35	0	0	0	0	0	0	0	66.33	0	0	11.6
2014	9	3	0	5	14	35	0	0	0	0	0	0	0	66.33	0	0	11.6
2014	9	3	0	15	14	35	0	0	0	0	0	0	0	66.33	0	0	11.6
2014	9	3	0	25	14	35	0	0	0	0	0	0	0	66.33	0	0	11.4
2014	9	3	0	35	14	35	0	0	0	0	0	0	0	66.33	0	0	11
2014	9	3	0	45	14	35	0	0	0	0	0	0	0	66.33	0	0	11.4
2014	9	3	0	55	14	35	0	0	0	0	0	0	0	66.31	0	0	11.2
2014	9	3	1	5	14	35	0	0	0	0	0	0	0	66.29	0	0	11.2
2014	9	3	1	15	14	34	0	0	0	0	0	0	0	66.25	0	0	11.2
2014	9	3	1	25	14	35	0	0	0	0	0	0	0	66.25	0	0	11.2
2014	9	3	1	35	14	35	0	0	0	0	0	0	0	66.24	0	0	11.2
2014	9	3	1	45	14	35	0	0	0	0	0	0	0	66.22	0	0	11
2014	9	3	1	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	3	2	5	14	34	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	3	2	15	14	34	0	0	0	0	0	0	0	66.16	0	0	11
2014	9	3	2	25	14	35	0	0	0	0	0	0	0	66.15	0	0	11
2014	9	3	2	35	14	35	0	0	0	0	0	0	0	66.13	0	0	11
2014	9	3	2	45	14	34	0	0	0	0	0	0	0	66.11	0	0	11
2014	9	3	2	55	14	36	0	0	0	0	0	0	0	66.09	0	0	11
2014	9	3	3	5	14	34	0	0	0	0	0	0	0	66.07	0	0	11
2014	9	3	3	15	14	36	0	0	0	0	0	0	0	66.06	0	0	11
2014	9	3	3	25	14	35	0	0	0	0	0	0	0	66.02	0	0	11
2014	9	3	3	35	14	35	0	0	0	0	0	0	0	66.02	0	0	11
2014	9	3	3	45	14	35	0	0	0	0	0	0	0	65.98	0	0	11
2014	9	3	3	55	14	35	0	0	0	0	0	0	0	65.97	0	0	11
2014	9	3	4	5	14	34	0	0	0	0	0	0	0	65.93	0	0	11.2
2014	9	3	4	15	14	35	0	0	0	0	0	0	0	65.91	0	0	11
2014	9	3	4	25	14	35	0	0	0	0	0	0	0	65.88	0	0	11
2014	9	3	4	35	14	36	0	0	0	0	0	0	0	65.88	0	0	11
2014	9	3	4	45	14	36	0	0	0	0	0	0	0	65.84	0	0	11
2014	9	3	4	55	14	35	0	0	0	0	0	0	0	65.82	0	0	11
2014	9	3	5	5	14	35	0	0	0	0	0	0	0	65.79	0	0	11
2014	9	3	5	15	14	35	0	0	0	0	0	0	0	65.77	0	0	11
2014	9	3	5	25	14	35	0	0	0	0	0	0	0	65.75	0	0	11.2
2014	9	3	5	35	14	35	0	0	0	0	0	0	0	65.73	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	5	45	14	36	0	0	0	0	0	0	0	65.71	0	0	11.2
2014	9	3	5	55	14	35	0	0	0	0	0	0	0	65.7	0	0	11.2
2014	9	3	6	5	14	34	0	0	0	0	0	0	0	65.68	0	0	11
2014	9	3	6	15	14	35	0	0	0	0	0	0	0	65.64	0	0	11
2014	9	3	6	25	14	36	0	0	0	0	0	0	0	65.62	0	0	11.2
2014	9	3	6	35	14	35	0	0	0	0	0	0	0	65.62	0	0	11.2
2014	9	3	6	45	14	34	0	0	0	0	0	0	0	65.59	0	0	11.6
2014	9	3	6	55	14	35	0	0	0	0	0	0	0	65.57	0	0	11.6
2014	9	3	7	5	14	35	0	0	0	0	0	0	0	65.53	0	0	11.6
2014	9	3	7	15	14	35	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	3	7	25	14	35	0	0	0	0	0	0	0	65.5	0	0	12.2
2014	9	3	7	35	14	35	0	0	0	0	0	0	0	65.48	0	0	12.4
2014	9	3	7	45	14	35	0	0	0	0	0	0	0	65.46	0	0	12.8
2014	9	3	7	55	14	35	0	0	0	0	0	0	0	65.5	0	0	12.8
2014	9	3	8	5	14	35	0	0	0	0	0	0	0	65.5	0	0	12.8
2014	9	3	8	15	14	35	0	0	0	0	0	0	0	65.52	0	0	13
2014	9	3	8	25	14	34	0	0	0	0	0	0	0	65.53	0	0	13
2014	9	3	8	35	14	35	0	0	0	0	0	0	0	65.55	0	0	13
2014	9	3	8	45	14	35	0	0	0	0	0	0	0	65.59	0	0	13
2014	9	3	8	55	14	35	0	0	0	0	0	0	0	65.62	0	0	13
2014	9	3	9	5	14	35	0	0	0	0	0	0	0	65.64	0	0	13
2014	9	3	9	15	14	35	0	0	0	0	0	0	0	65.68	0	0	13
2014	9	3	9	25	14	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	3	9	35	14	35	0	0	0	0	0	0	0	65.77	0	0	13
2014	9	3	9	45	14	36	0	0	0	0	0	0	0	65.8	0	0	13
2014	9	3	9	55	14	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	3	10	5	14	35	0	0	0	0	0	0	0	65.89	0	0	13
2014	9	3	10	15	14	35	0	0	0	0	0	0	0	65.93	0	0	13
2014	9	3	10	25	14	35	0	0	0	0	0	0	0	66	0	0	13
2014	9	3	10	35	14	35	0	0	0	0	0	0	0	66.04	0	0	13
2014	9	3	10	45	14	35	0	0	0	0	0	0	0	66.11	0	0	13
2014	9	3	10	55	14	35	0	0	0	0	0	0	0	66.15	0	0	13
2014	9	3	11	5	14	35	0	0	0	0	0	0	0	66.18	0	0	13
2014	9	3	11	15	14	35	0	0	0	0	0	0	0	66.24	0	0	13
2014	9	3	11	25	14	35	0	0	0	0	0	0	0	66.27	0	0	13
2014	9	3	11	35	14	35	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	3	11	45	14	35	0	0	0	0	0	0	0	66.4	0	0	13
2014	9	3	11	55	14	35	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	3	12	5	14	35	0	0	0	0	0	0	0	66.51	0	0	13
2014	9	3	12	15	14	35	0	0	0	0	0	0	0	66.51	0	0	13
2014	9	3	12	25	14	36	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	3	12	35	14	35	0	0	0	0	0	0	0	66.58	0	0	13
2014	9	3	12	45	14	35	0	0	0	0	0	0	0	66.6	0	0	13
2014	9	3	12	55	14	35	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	3	13	5	14	35	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	3	13	15	14	35	0	0	0	0	0	0	0	66.67	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	13	25	14	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	3	13	35	14	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	3	13	45	14	34	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	3	13	55	14	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	3	14	5	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	3	14	15	14	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	3	14	25	14	35	0	0	0	0	0	0	0	66.72	0	0	13
2014	9	3	14	35	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	3	14	45	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	3	14	55	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	3	15	5	14	35	0	0	0	0	0	0	0	66.67	0	0	13
2014	9	3	15	15	14	35	0	0	0	0	0	0	0	66.65	0	0	13
2014	9	3	15	25	14	35	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	3	15	35	14	35	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	3	15	45	14	35	0	0	0	0	0	0	0	66.58	0	0	13
2014	9	3	15	55	14	35	0	0	0	0	0	0	0	66.56	0	0	13
2014	9	3	16	5	14	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	3	16	15	14	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	3	16	25	14	35	0	0	0	0	0	0	0	66.52	0	0	13
2014	9	3	16	35	14	35	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	3	16	45	14	35	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	3	16	55	14	35	0	0	0	0	0	0	0	66.45	0	0	13
2014	9	3	17	5	14	35	0	0	0	0	0	0	0	66.43	0	0	12.8
2014	9	3	17	15	14	35	0	0	0	0	0	0	0	66.43	0	0	12.4
2014	9	3	17	25	14	35	0	0	0	0	0	0	0	66.42	0	0	12.2
2014	9	3	17	35	14	35	0	0	0	0	0	0	0	66.42	0	0	12
2014	9	3	17	45	14	35	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	3	17	55	14	35	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	3	18	5	14	35	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	3	18	15	14	35	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	3	18	25	14	35	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	3	18	35	14	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	3	18	45	14	35	0	0	0	0	0	0	0	66.38	0	0	12
2014	9	3	18	55	14	36	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	3	19	5	14	35	0	0	0	0	0	0	0	66.4	0	0	12
2014	9	3	19	15	14	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	3	19	25	14	34	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	3	19	35	14	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	3	19	45	14	34	0	0	0	0	0	0	0	66.47	0	0	11.8
2014	9	3	19	55	14	35	0	0	0	0	0	0	0	66.49	0	0	11.8
2014	9	3	20	5	14	35	0	0	0	0	0	0	0	66.51	0	0	11.8
2014	9	3	20	15	14	36	0	0	0	0	0	0	0	66.52	0	0	11.8
2014	9	3	20	25	14	34	0	0	0	0	0	0	0	66.54	0	0	11.8
2014	9	3	20	35	14	35	0	0	0	0	0	0	0	66.56	0	0	11.8
2014	9	3	20	45	14	36	0	0	0	0	0	0	0	66.58	0	0	11.8
2014	9	3	20	55	14	34	0	0	0	0	0	0	0	66.6	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	21	5	14	34	0	0	0	0	0	0	0	66.61	0	0	11.8
2014	9	3	21	15	14	35	0	0	0	0	0	0	0	66.61	0	0	11.8
2014	9	3	21	25	14	35	0	0	0	0	0	0	0	66.63	0	0	11.8
2014	9	3	21	35	14	35	0	0	0	0	0	0	0	66.65	0	0	11.8
2014	9	3	21	45	14	35	0	0	0	0	0	0	0	66.67	0	0	11.8
2014	9	3	21	55	14	35	0	0	0	0	0	0	0	66.67	0	0	11.8
2014	9	3	22	5	14	35	0	0	0	0	0	0	0	66.69	0	0	11.8
2014	9	3	22	15	14	35	0	0	0	0	0	0	0	66.7	0	0	11.6
2014	9	3	22	25	14	35	0	0	0	0	0	0	0	66.7	0	0	11.6
2014	9	3	22	35	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	3	22	45	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	3	22	55	14	34	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	3	23	5	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	3	23	15	14	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	3	23	25	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	3	23	35	14	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	3	23	45	14	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	3	23	55	14	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	4	0	5	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	4	0	15	14	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	4	0	25	14	35	0	0	0	0	0	0	0	66.7	0	0	11.6
2014	9	4	0	35	14	35	0	0	0	0	0	0	0	66.7	0	0	11.6
2014	9	4	0	45	14	34	0	0	0	0	0	0	0	66.69	0	0	11.8
2014	9	4	0	55	14	35	0	0	0	0	0	0	0	66.67	0	0	11.8
2014	9	4	1	5	14	35	0	0	0	0	0	0	0	66.65	0	0	11.8
2014	9	4	1	15	14	35	0	0	0	0	0	0	0	66.65	0	0	11.8
2014	9	4	1	25	14	34	0	0	0	0	0	0	0	66.61	0	0	11.8
2014	9	4	1	35	14	36	0	0	0	0	0	0	0	66.6	0	0	11.8
2014	9	4	1	45	14	35	0	0	0	0	0	0	0	66.58	0	0	11.8
2014	9	4	1	55	14	35	0	0	0	0	0	0	0	66.56	0	0	11.8
2014	9	4	2	5	14	35	0	0	0	0	0	0	0	66.54	0	0	11.8
2014	9	4	2	15	14	35	0	0	0	0	0	0	0	66.51	0	0	11.8
2014	9	4	2	25	14	36	0	0	0	0	0	0	0	66.49	0	0	11.8
2014	9	4	2	35	14	35	0	0	0	0	0	0	0	66.47	0	0	11.8
2014	9	4	2	45	14	34	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	4	2	55	14	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	4	3	5	14	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	4	3	15	14	35	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	4	3	25	14	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	4	3	35	14	35	0	0	0	0	0	0	0	66.31	0	0	11.8
2014	9	4	3	45	14	35	0	0	0	0	0	0	0	66.29	0	0	11.8
2014	9	4	3	55	14	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	4	4	5	14	35	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	4	4	15	14	36	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	4	4	25	14	34	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	4	4	35	14	34	0	0	0	0	0	0	0	66.13	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	4	45	14	35	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	4	4	55	14	35	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	9	4	5	5	14	35	0	0	0	0	0	0	0	66.06	0	0	11.8
2014	9	4	5	15	14	35	0	0	0	0	0	0	0	66.04	0	0	11.8
2014	9	4	5	25	14	35	0	0	0	0	0	0	0	66	0	0	11.8
2014	9	4	5	35	14	34	0	0	0	0	0	0	0	65.98	0	0	11.8
2014	9	4	5	45	14	35	0	0	0	0	0	0	0	65.97	0	0	11.8
2014	9	4	5	55	14	35	0	0	0	0	0	0	0	65.95	0	0	11.8
2014	9	4	6	5	14	35	0	0	0	0	0	0	0	65.93	0	0	11.8
2014	9	4	6	15	14	35	0	0	0	0	0	0	0	65.91	0	0	11.8
2014	9	4	6	25	14	35	0	0	0	0	0	0	0	65.88	0	0	11.8
2014	9	4	6	35	14	34	0	0	0	0	0	0	0	65.86	0	0	11.8
2014	9	4	6	45	14	35	0	0	0	0	0	0	0	65.84	0	0	11.8
2014	9	4	6	55	14	35	0	0	0	0	0	0	0	65.82	0	0	11.8
2014	9	4	7	5	14	35	0	0	0	0	0	0	0	65.8	0	0	11.8
2014	9	4	7	15	14	35	0	0	0	0	0	0	0	65.79	0	0	11.8
2014	9	4	7	25	14	35	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	4	7	35	14	35	0	0	0	0	0	0	0	65.77	0	0	12.2
2014	9	4	7	45	14	35	0	0	0	0	0	0	0	65.77	0	0	12.4
2014	9	4	7	55	14	35	0	0	0	0	0	0	0	65.79	0	0	12.4
2014	9	4	8	5	14	35	0	0	0	0	0	0	0	65.82	0	0	12.6
2014	9	4	8	15	14	35	0	0	0	0	0	0	0	65.84	0	0	12.6
2014	9	4	8	25	14	35	0	0	0	0	0	0	0	65.86	0	0	12.8
2014	9	4	8	35	14	35	0	0	0	0	0	0	0	65.88	0	0	12.8
2014	9	4	8	45	14	35	0	0	0	0	0	0	0	65.91	0	0	12.8
2014	9	4	8	55	14	35	0	0	0	0	0	0	0	65.93	0	0	12.8
2014	9	4	9	5	14	35	0	0	0	0	0	0	0	65.97	0	0	13
2014	9	4	9	15	14	35	0	0	0	0	0	0	0	66	0	0	13
2014	9	4	9	25	14	35	0	0	0	0	0	0	0	66.02	0	0	13.4
2014	9	4	9	35	14	35	0	0	0	0	0	0	0	66.06	0	0	13.4
2014	9	4	9	45	14	35	0	0	0	0	0	0	0	66.09	0	0	13.2
2014	9	4	9	55	14	35	0	0	0	0	0	0	0	66.13	0	0	13.2
2014	9	4	10	5	14	35	0	0	0	0	0	0	0	66.16	0	0	13.2
2014	9	4	10	15	14	36	0	0	0	0	0	0	0	66.22	0	0	13.2
2014	9	4	10	25	14	36	0	0	0	0	0	0	0	66.25	0	0	13.2
2014	9	4	10	35	14	35	0	0	0	0	0	0	0	66.33	0	0	13.2
2014	9	4	10	45	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	4	10	55	14	35	0	0	0	0	0	0	0	66.4	0	0	13.2
2014	9	4	11	5	14	36	0	0	0	0	0	0	0	66.43	0	0	13.2
2014	9	4	11	15	14	35	0	0	0	0	0	0	0	66.47	0	0	13.2
2014	9	4	11	25	14	35	0	0	0	0	0	0	0	66.49	0	0	13.2
2014	9	4	11	35	14	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	4	11	45	14	35	0	0	0	0	0	0	0	66.58	0	0	13
2014	9	4	11	55	14	34	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	4	12	5	14	35	0	0	0	0	0	0	0	66.67	0	0	13
2014	9	4	12	15	14	35	0	0	0	0	0	0	0	66.7	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	12	25	14	35	0	0	0	0	0	0	0	66.72	0	0	13
2014	9	4	12	35	14	35	0	0	0	0	0	0	0	66.78	0	0	13
2014	9	4	12	45	14	35	0	0	0	0	0	0	0	66.78	0	0	13
2014	9	4	12	55	14	35	0	0	0	0	0	0	0	66.81	0	0	13
2014	9	4	13	5	14	35	0	0	0	0	0	0	0	66.85	0	0	13
2014	9	4	13	15	14	35	0	0	0	0	0	0	0	66.88	0	0	13
2014	9	4	13	25	14	35	0	0	0	0	0	0	0	66.9	0	0	13
2014	9	4	13	35	14	35	0	0	0	0	0	0	0	66.9	0	0	13
2014	9	4	13	45	14	36	0	0	0	0	0	0	0	66.9	0	0	13
2014	9	4	13	55	14	35	0	0	0	0	0	0	0	66.9	0	0	13
2014	9	4	14	5	14	35	0	0	0	0	0	0	0	66.92	0	0	13
2014	9	4	14	15	14	34	0	0	0	0	0	0	0	66.92	0	0	13
2014	9	4	14	25	14	34	0	0	0	0	0	0	0	66.92	0	0	13
2014	9	4	14	35	14	35	0	0	0	0	0	0	0	66.88	0	0	13
2014	9	4	14	45	14	35	0	0	0	0	0	0	0	66.87	0	0	13
2014	9	4	14	55	14	35	0	0	0	0	0	0	0	66.87	0	0	13
2014	9	4	15	5	14	35	0	0	0	0	0	0	0	66.85	0	0	13
2014	9	4	15	15	14	35	0	0	0	0	0	0	0	66.83	0	0	13
2014	9	4	15	25	14	35	0	0	0	0	0	0	0	66.81	0	0	13
2014	9	4	15	35	14	35	0	0	0	0	0	0	0	66.78	0	0	13
2014	9	4	15	45	14	35	0	0	0	0	0	0	0	66.76	0	0	13
2014	9	4	15	55	14	34	0	0	0	0	0	0	0	66.74	0	0	13
2014	9	4	16	5	14	35	0	0	0	0	0	0	0	66.72	0	0	13
2014	9	4	16	15	14	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	4	16	25	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	4	16	35	14	35	0	0	0	0	0	0	0	66.65	0	0	13
2014	9	4	16	45	14	35	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	4	16	55	14	35	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	4	17	5	14	34	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	4	17	15	14	35	0	0	0	0	0	0	0	66.61	0	0	12.4
2014	9	4	17	25	14	35	0	0	0	0	0	0	0	66.6	0	0	12.2
2014	9	4	17	35	14	35	0	0	0	0	0	0	0	66.6	0	0	12
2014	9	4	17	45	14	35	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	4	17	55	14	35	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	4	18	5	14	34	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	4	18	15	14	35	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	4	18	25	14	35	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	4	18	35	14	35	0	0	0	0	0	0	0	66.56	0	0	12
2014	9	4	18	45	14	35	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	4	18	55	14	35	0	0	0	0	0	0	0	66.58	0	0	12
2014	9	4	19	5	14	35	0	0	0	0	0	0	0	66.61	0	0	12
2014	9	4	19	15	14	35	0	0	0	0	0	0	0	66.61	0	0	12
2014	9	4	19	25	14	36	0	0	0	0	0	0	0	66.63	0	0	12
2014	9	4	19	35	14	35	0	0	0	0	0	0	0	66.65	0	0	12
2014	9	4	19	45	14	35	0	0	0	0	0	0	0	66.67	0	0	11.8
2014	9	4	19	55	14	35	0	0	0	0	0	0	0	66.69	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	20	5	14	35	0	0	0	0	0	0	0	66.69	0	0	11.8
2014	9	4	20	15	14	35	0	0	0	0	0	0	0	66.7	0	0	11.8
2014	9	4	20	25	14	35	0	0	0	0	0	0	0	66.72	0	0	11.8
2014	9	4	20	35	14	35	0	0	0	0	0	0	0	66.74	0	0	11.8
2014	9	4	20	45	14	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	4	20	55	14	34	0	0	0	0	0	0	0	66.76	0	0	11.6
2014	9	4	21	5	14	34	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	4	21	15	14	35	0	0	0	0	0	0	0	66.79	0	0	11.6
2014	9	4	21	25	14	35	0	0	0	0	0	0	0	66.81	0	0	11.6
2014	9	4	21	35	14	35	0	0	0	0	0	0	0	66.81	0	0	11.6
2014	9	4	21	45	14	35	0	0	0	0	0	0	0	66.83	0	0	11.2
2014	9	4	21	55	14	35	0	0	0	0	0	0	0	66.83	0	0	11.2
2014	9	4	22	5	14	35	0	0	0	0	0	0	0	66.85	0	0	11.2
2014	9	4	22	15	14	35	0	0	0	0	0	0	0	66.85	0	0	11.2
2014	9	4	22	25	14	35	0	0	0	0	0	0	0	66.87	0	0	11.2
2014	9	4	22	35	14	35	0	0	0	0	0	0	0	66.87	0	0	11.2
2014	9	4	22	45	14	35	0	0	0	0	0	0	0	66.88	0	0	11.2
2014	9	4	22	55	14	35	0	0	0	0	0	0	0	66.88	0	0	11
2014	9	4	23	5	14	35	0	0	0	0	0	0	0	66.88	0	0	11.2
2014	9	4	23	15	14	34	0	0	0	0	0	0	0	66.88	0	0	11.2
2014	9	4	23	25	14	35	0	0	0	0	0	0	0	66.87	0	0	11
2014	9	4	23	35	14	35	0	0	0	0	0	0	0	66.88	0	0	11
2014	9	4	23	45	14	35	0	0	0	0	0	0	0	66.87	0	0	11
2014	9	4	23	55	14	35	0	0	0	0	0	0	0	66.87	0	0	11
2014	9	5	0	5	14	35	0	0	0	0	0	0	0	66.85	0	0	11
2014	9	5	0	15	14	35	0	0	0	0	0	0	0	66.85	0	0	11
2014	9	5	0	25	14	35	0	0	0	0	0	0	0	66.85	0	0	11
2014	9	5	0	35	14	35	0	0	0	0	0	0	0	66.83	0	0	11
2014	9	5	0	45	14	35	0	0	0	0	0	0	0	66.81	0	0	11
2014	9	5	0	55	14	35	0	0	0	0	0	0	0	66.81	0	0	11
2014	9	5	1	5	14	35	0	0	0	0	0	0	0	66.79	0	0	11
2014	9	5	1	15	14	35	0	0	0	0	0	0	0	66.76	0	0	11
2014	9	5	1	25	14	34	0	0	0	0	0	0	0	66.74	0	0	11
2014	9	5	1	35	14	35	0	0	0	0	0	0	0	66.72	0	0	11
2014	9	5	1	45	14	35	0	0	0	0	0	0	0	66.7	0	0	11
2014	9	5	1	55	14	35	0	0	0	0	0	0	0	66.67	0	0	10.8
2014	9	5	2	5	14	34	0	0	0	0	0	0	0	66.63	0	0	11
2014	9	5	2	15	14	35	0	0	0	0	0	0	0	66.61	0	0	11
2014	9	5	2	25	14	35	0	0	0	0	0	0	0	66.6	0	0	11
2014	9	5	2	35	14	35	0	0	0	0	0	0	0	66.56	0	0	11
2014	9	5	2	45	14	34	0	0	0	0	0	0	0	66.52	0	0	10.8
2014	9	5	2	55	14	35	0	0	0	0	0	0	0	66.51	0	0	10.8
2014	9	5	3	5	14	35	0	0	0	0	0	0	0	66.47	0	0	10.8
2014	9	5	3	15	14	34	0	0	0	0	0	0	0	66.45	0	0	10.8
2014	9	5	3	25	14	34	0	0	0	0	0	0	0	66.4	0	0	10.8
2014	9	5	3	35	14	35	0	0	0	0	0	0	0	66.38	0	0	10.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	3	45	14	35	0	0	0	0	0	0	0	66.34	0	0	11.2
2014	9	5	3	55	14	35	0	0	0	0	0	0	0	66.31	0	0	11.4
2014	9	5	4	5	14	35	0	0	0	0	0	0	0	66.29	0	0	11.4
2014	9	5	4	15	14	35	0	0	0	0	0	0	0	66.24	0	0	11.4
2014	9	5	4	25	14	34	0	0	0	0	0	0	0	66.2	0	0	11.4
2014	9	5	4	35	14	35	0	0	0	0	0	0	0	66.16	0	0	11.4
2014	9	5	4	45	14	35	0	0	0	0	0	0	0	66.13	0	0	11.4
2014	9	5	4	55	14	35	0	0	0	0	0	0	0	66.09	0	0	11.4
2014	9	5	5	5	14	35	0	0	0	0	0	0	0	66.06	0	0	11.4
2014	9	5	5	15	14	35	0	0	0	0	0	0	0	66.02	0	0	11.4
2014	9	5	5	25	14	35	0	0	0	0	0	0	0	66	0	0	11.4
2014	9	5	5	35	14	35	0	0	0	0	0	0	0	65.97	0	0	11.6
2014	9	5	5	45	14	35	0	0	0	0	0	0	0	65.93	0	0	11.6
2014	9	5	5	55	14	35	0	0	0	0	0	0	0	65.91	0	0	11.6
2014	9	5	6	5	14	35	0	0	0	0	0	0	0	65.88	0	0	11.6
2014	9	5	6	15	14	34	0	0	0	0	0	0	0	65.84	0	0	11.6
2014	9	5	6	25	14	35	0	0	0	0	0	0	0	65.8	0	0	11.6
2014	9	5	6	35	14	35	0	0	0	0	0	0	0	65.77	0	0	11.6
2014	9	5	6	45	14	35	0	0	0	0	0	0	0	65.73	0	0	11.6
2014	9	5	6	55	14	34	0	0	0	0	0	0	0	65.7	0	0	11.6
2014	9	5	7	5	14	34	0	0	0	0	0	0	0	65.66	0	0	11.6
2014	9	5	7	15	14	34	0	0	0	0	0	0	0	65.62	0	0	11.6
2014	9	5	7	25	14	35	0	0	0	0	0	0	0	65.61	0	0	12.2
2014	9	5	7	35	14	35	0	0	0	0	0	0	0	65.59	0	0	12.4
2014	9	5	7	45	14	35	0	0	0	0	0	0	0	65.57	0	0	12.6
2014	9	5	7	55	14	36	0	0	0	0	0	0	0	65.59	0	0	12.8
2014	9	5	8	5	14	35	0	0	0	0	0	0	0	65.57	0	0	13
2014	9	5	8	15	14	34	0	0	0	0	0	0	0	65.59	0	0	13
2014	9	5	8	25	14	35	0	0	0	0	0	0	0	65.59	0	0	13.2
2014	9	5	8	35	14	35	0	0	0	0	0	0	0	65.59	0	0	13.4
2014	9	5	8	45	14	35	0	0	0	0	0	0	0	65.61	0	0	13.4
2014	9	5	8	55	14	36	0	0	0	0	0	0	0	65.61	0	0	13.2
2014	9	5	9	5	14	35	0	0	0	0	0	0	0	65.62	0	0	13.2
2014	9	5	9	15	14	35	0	0	0	0	0	0	0	65.66	0	0	13.2
2014	9	5	9	25	14	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	5	9	35	14	36	0	0	0	0	0	0	0	65.73	0	0	13.2
2014	9	5	9	45	14	35	0	0	0	0	0	0	0	65.77	0	0	13.2
2014	9	5	9	55	14	34	0	0	0	0	0	0	0	65.79	0	0	13.2
2014	9	5	10	5	14	35	0	0	0	0	0	0	0	65.82	0	0	13.2
2014	9	5	10	15	14	35	0	0	0	0	0	0	0	65.84	0	0	13.2
2014	9	5	10	25	14	35	0	0	0	0	0	0	0	65.86	0	0	13.2
2014	9	5	10	35	14	35	0	0	0	0	0	0	0	65.89	0	0	13.2
2014	9	5	10	45	14	35	0	0	0	0	0	0	0	65.93	0	0	13.2
2014	9	5	10	55	14	35	0	0	0	0	0	0	0	65.98	0	0	13.2
2014	9	5	11	5	14	35	0	0	0	0	0	0	0	66	0	0	13.2
2014	9	5	11	15	14	35	0	0	0	0	0	0	0	66.04	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	11	25	14	35	0	0	0	0	0	0	0	66.09	0	0	13.2
2014	9	5	11	35	14	35	0	0	0	0	0	0	0	66.09	0	0	13.2
2014	9	5	11	45	14	36	0	0	0	0	0	0	0	66.13	0	0	13.2
2014	9	5	11	55	14	34	0	0	0	0	0	0	0	66.16	0	0	13.2
2014	9	5	12	5	14	36	0	0	0	0	0	0	0	66.2	0	0	13.2
2014	9	5	12	15	14	35	0	0	0	0	0	0	0	66.24	0	0	13.2
2014	9	5	12	25	14	35	0	0	0	0	0	0	0	66.25	0	0	13.2
2014	9	5	12	35	14	34	0	0	0	0	0	0	0	66.31	0	0	13.2
2014	9	5	12	45	14	35	0	0	0	0	0	0	0	66.31	0	0	13.2
2014	9	5	12	55	14	35	0	0	0	0	0	0	0	66.34	0	0	13.2
2014	9	5	13	5	14	36	0	0	0	0	0	0	0	66.34	0	0	13.2
2014	9	5	13	15	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	13	25	14	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	5	13	35	14	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	5	13	45	14	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	5	13	55	14	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	5	14	5	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	14	15	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	14	25	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	14	35	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	14	45	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	5	14	55	14	35	0	0	0	0	0	0	0	66.33	0	0	13.2
2014	9	5	15	5	14	35	0	0	0	0	0	0	0	66.31	0	0	13.2
2014	9	5	15	15	14	35	0	0	0	0	0	0	0	66.29	0	0	13.2
2014	9	5	15	25	14	35	0	0	0	0	0	0	0	66.27	0	0	13
2014	9	5	15	35	14	35	0	0	0	0	0	0	0	66.25	0	0	13
2014	9	5	15	45	14	35	0	0	0	0	0	0	0	66.22	0	0	13
2014	9	5	15	55	14	35	0	0	0	0	0	0	0	66.2	0	0	13
2014	9	5	16	5	14	34	0	0	0	0	0	0	0	66.16	0	0	13
2014	9	5	16	15	14	35	0	0	0	0	0	0	0	66.15	0	0	13.2
2014	9	5	16	25	14	35	0	0	0	0	0	0	0	66.13	0	0	13.2
2014	9	5	16	35	14	35	0	0	0	0	0	0	0	66.09	0	0	13.2
2014	9	5	16	45	14	35	0	0	0	0	0	0	0	66.09	0	0	13
2014	9	5	16	55	14	35	0	0	0	0	0	0	0	66.06	0	0	13
2014	9	5	17	5	14	35	0	0	0	0	0	0	0	66.04	0	0	13
2014	9	5	17	15	14	35	0	0	0	0	0	0	0	66.02	0	0	12.4
2014	9	5	17	25	14	35	0	0	0	0	0	0	0	66.02	0	0	12.2
2014	9	5	17	35	14	35	0	0	0	0	0	0	0	66	0	0	12.2
2014	9	5	17	45	14	35	0	0	0	0	0	0	0	66	0	0	12
2014	9	5	17	55	14	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	5	18	5	14	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	5	18	15	14	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	5	18	25	14	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	5	18	35	14	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	5	18	45	14	34	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	5	18	55	14	35	0	0	0	0	0	0	0	65.98	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	19	5	14	35	0	0	0	0	0	0	0	66	0	0	12
2014	9	5	19	15	14	35	0	0	0	0	0	0	0	66	0	0	12
2014	9	5	19	25	14	35	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	5	19	35	14	35	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	5	19	45	14	35	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	5	19	55	14	35	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	5	20	5	14	35	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	5	20	15	14	35	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	5	20	25	14	35	0	0	0	0	0	0	0	66.07	0	0	12
2014	9	5	20	35	14	35	0	0	0	0	0	0	0	66.09	0	0	12
2014	9	5	20	45	14	34	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	9	5	20	55	14	35	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	5	21	5	14	35	0	0	0	0	0	0	0	66.13	0	0	11.8
2014	9	5	21	15	14	35	0	0	0	0	0	0	0	66.15	0	0	11.8
2014	9	5	21	25	14	35	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	5	21	35	14	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	5	21	45	14	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	5	21	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	5	22	5	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	5	22	15	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	22	25	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	22	35	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	22	45	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	22	55	14	35	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	5	23	5	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	23	15	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	23	25	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	23	35	14	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	5	23	45	14	36	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	5	23	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	6	0	5	14	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	6	0	15	14	35	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	6	0	25	14	35	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	6	0	35	14	35	0	0	0	0	0	0	0	66.15	0	0	11.8
2014	9	6	0	45	14	35	0	0	0	0	0	0	0	66.13	0	0	11.2
2014	9	6	0	55	14	35	0	0	0	0	0	0	0	66.09	0	0	11.2
2014	9	6	1	5	14	35	0	0	0	0	0	0	0	66.07	0	0	11.2
2014	9	6	1	15	14	35	0	0	0	0	0	0	0	66.06	0	0	11.2
2014	9	6	1	25	14	35	0	0	0	0	0	0	0	66.02	0	0	11.2
2014	9	6	1	35	14	35	0	0	0	0	0	0	0	66	0	0	11.2
2014	9	6	1	45	14	35	0	0	0	0	0	0	0	65.98	0	0	11.4
2014	9	6	1	55	14	35	0	0	0	0	0	0	0	65.95	0	0	11.4
2014	9	6	2	5	14	35	0	0	0	0	0	0	0	65.93	0	0	11.4
2014	9	6	2	15	14	35	0	0	0	0	0	0	0	65.89	0	0	11.4
2014	9	6	2	25	14	35	0	0	0	0	0	0	0	65.86	0	0	11.4
2014	9	6	2	35	14	35	0	0	0	0	0	0	0	65.84	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	2	45	14	35	0	0	0	0	0	0	0	65.8	0	0	11.4
2014	9	6	2	55	14	35	0	0	0	0	0	0	0	65.77	0	0	11.4
2014	9	6	3	5	14	35	0	0	0	0	0	0	0	65.73	0	0	11.4
2014	9	6	3	15	14	35	0	0	0	0	0	0	0	65.7	0	0	11.4
2014	9	6	3	25	14	35	0	0	0	0	0	0	0	65.68	0	0	11.4
2014	9	6	3	35	14	35	0	0	0	0	0	0	0	65.62	0	0	11.4
2014	9	6	3	45	14	35	0	0	0	0	0	0	0	65.59	0	0	11.4
2014	9	6	3	55	14	35	0	0	0	0	0	0	0	65.55	0	0	11.4
2014	9	6	4	5	14	35	0	0	0	0	0	0	0	65.52	0	0	11.4
2014	9	6	4	15	14	35	0	0	0	0	0	0	0	65.48	0	0	11.4
2014	9	6	4	25	14	35	0	0	0	0	0	0	0	65.43	0	0	11.4
2014	9	6	4	35	14	35	0	0	0	0	0	0	0	65.39	0	0	11.4
2014	9	6	4	45	14	36	0	0	0	0	0	0	0	65.35	0	0	11.4
2014	9	6	4	55	14	35	0	0	0	0	0	0	0	65.3	0	0	11.4
2014	9	6	5	5	14	35	0	0	0	0	0	0	0	65.25	0	0	11.4
2014	9	6	5	15	14	35	0	0	0	0	0	0	0	65.23	0	0	11.4
2014	9	6	5	25	14	35	0	0	0	0	0	0	0	65.17	0	0	11.4
2014	9	6	5	35	14	35	0	0	0	0	0	0	0	65.14	0	0	11.4
2014	9	6	5	45	14	35	0	0	0	0	0	0	0	65.08	0	0	11.4
2014	9	6	5	55	14	36	0	0	0	0	0	0	0	65.05	0	0	11.4
2014	9	6	6	5	14	35	0	0	0	0	0	0	0	65.01	0	0	11.4
2014	9	6	6	15	14	35	0	0	0	0	0	0	0	64.98	0	0	11.4
2014	9	6	6	25	14	35	0	0	0	0	0	0	0	64.92	0	0	11.4
2014	9	6	6	35	14	35	0	0	0	0	0	0	0	64.89	0	0	11.4
2014	9	6	6	45	14	35	0	0	0	0	0	0	0	64.85	0	0	11.4
2014	9	6	6	55	14	34	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	6	7	5	14	35	0	0	0	0	0	0	0	64.78	0	0	11.4
2014	9	6	7	15	14	35	0	0	0	0	0	0	0	64.72	0	0	11.4
2014	9	6	7	25	14	36	0	0	0	0	0	0	0	64.69	0	0	12.4
2014	9	6	7	35	14	36	0	0	0	0	0	0	0	64.65	0	0	12.8
2014	9	6	7	45	14	35	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	6	7	55	14	35	0	0	0	0	0	0	0	64.62	0	0	13
2014	9	6	8	5	14	36	0	0	0	0	0	0	0	64.62	0	0	13.2
2014	9	6	8	15	14	35	0	0	0	0	0	0	0	64.62	0	0	13.2
2014	9	6	8	25	14	35	0	0	0	0	0	0	0	64.6	0	0	13.2
2014	9	6	8	35	14	35	0	0	0	0	0	0	0	64.62	0	0	13.4
2014	9	6	8	45	14	35	0	0	0	0	0	0	0	64.63	0	0	13.4
2014	9	6	8	55	14	35	0	0	0	0	0	0	0	64.63	0	0	13.4
2014	9	6	9	5	14	36	0	0	0	0	0	0	0	64.65	0	0	13.4
2014	9	6	9	15	14	36	0	0	0	0	0	0	0	64.67	0	0	13.4
2014	9	6	9	25	14	35	0	0	0	0	0	0	0	64.69	0	0	13.4
2014	9	6	9	35	14	34	0	0	0	0	0	0	0	64.72	0	0	13.2
2014	9	6	9	45	14	35	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	6	9	55	14	35	0	0	0	0	0	0	0	64.78	0	0	13.2
2014	9	6	10	5	14	36	0	0	0	0	0	0	0	64.81	0	0	13.2
2014	9	6	10	15	14	35	0	0	0	0	0	0	0	64.83	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	10	25	14	35	0	0	0	0	0	0	0	64.89	0	0	13.2
2014	9	6	10	35	14	35	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	6	10	45	14	35	0	0	0	0	0	0	0	64.96	0	0	13.2
2014	9	6	10	55	14	36	0	0	0	0	0	0	0	64.99	0	0	13.2
2014	9	6	11	5	14	35	0	0	0	0	0	0	0	65.03	0	0	13.2
2014	9	6	11	15	14	34	0	0	0	0	0	0	0	65.07	0	0	13.2
2014	9	6	11	25	14	35	0	0	0	0	0	0	0	65.1	0	0	13.2
2014	9	6	11	35	14	35	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	6	11	45	14	34	0	0	0	0	0	0	0	65.16	0	0	13.2
2014	9	6	11	55	14	35	0	0	0	0	0	0	0	65.17	0	0	13.2
2014	9	6	12	5	14	35	0	0	0	0	0	0	0	65.23	0	0	13.2
2014	9	6	12	15	14	35	0	0	0	0	0	0	0	65.25	0	0	13.2
2014	9	6	12	25	14	35	0	0	0	0	0	0	0	65.26	0	0	13.2
2014	9	6	12	35	14	35	0	0	0	0	0	0	0	65.3	0	0	13.2
2014	9	6	12	45	14	35	0	0	0	0	0	0	0	65.32	0	0	13.2
2014	9	6	12	55	14	35	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	6	13	5	14	35	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	6	13	15	14	35	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	6	13	25	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	13	35	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	13	45	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	13	55	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	14	5	14	35	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	14	15	14	36	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	14	25	14	36	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	6	14	35	14	35	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	9	6	14	45	14	36	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	6	14	55	14	35	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	6	15	5	14	35	0	0	0	0	0	0	0	65.34	0	0	13.2
2014	9	6	15	15	14	34	0	0	0	0	0	0	0	65.32	0	0	13.2
2014	9	6	15	25	14	35	0	0	0	0	0	0	0	65.3	0	0	13.2
2014	9	6	15	35	14	35	0	0	0	0	0	0	0	65.3	0	0	13.2
2014	9	6	15	45	14	35	0	0	0	0	0	0	0	65.26	0	0	13
2014	9	6	15	55	14	35	0	0	0	0	0	0	0	65.25	0	0	13
2014	9	6	16	5	14	35	0	0	0	0	0	0	0	65.23	0	0	13
2014	9	6	16	15	14	35	0	0	0	0	0	0	0	65.21	0	0	13
2014	9	6	16	25	14	35	0	0	0	0	0	0	0	65.21	0	0	13
2014	9	6	16	35	14	35	0	0	0	0	0	0	0	65.17	0	0	13
2014	9	6	16	45	14	35	0	0	0	0	0	0	0	65.17	0	0	13
2014	9	6	16	55	14	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	6	17	5	14	34	0	0	0	0	0	0	0	65.14	0	0	12.8
2014	9	6	17	15	14	35	0	0	0	0	0	0	0	65.14	0	0	12.4
2014	9	6	17	25	14	35	0	0	0	0	0	0	0	65.12	0	0	12.2
2014	9	6	17	35	14	35	0	0	0	0	0	0	0	65.12	0	0	12.2
2014	9	6	17	45	14	35	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	6	17	55	14	35	0	0	0	0	0	0	0	65.1	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	18	5	14	35	0	0	0	0	0	0	0	65.08	0	0	12
2014	9	6	18	15	14	35	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	6	18	25	14	35	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	6	18	35	14	35	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	6	18	45	14	35	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	6	18	55	14	35	0	0	0	0	0	0	0	65.14	0	0	12
2014	9	6	19	5	14	35	0	0	0	0	0	0	0	65.14	0	0	12
2014	9	6	19	15	14	36	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	6	19	25	14	35	0	0	0	0	0	0	0	65.17	0	0	12
2014	9	6	19	35	14	35	0	0	0	0	0	0	0	65.19	0	0	12
2014	9	6	19	45	14	35	0	0	0	0	0	0	0	65.21	0	0	12
2014	9	6	19	55	14	34	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	6	20	5	14	35	0	0	0	0	0	0	0	65.26	0	0	12
2014	9	6	20	15	14	35	0	0	0	0	0	0	0	65.28	0	0	12
2014	9	6	20	25	14	35	0	0	0	0	0	0	0	65.3	0	0	12
2014	9	6	20	35	14	35	0	0	0	0	0	0	0	65.34	0	0	12
2014	9	6	20	45	14	35	0	0	0	0	0	0	0	65.37	0	0	12
2014	9	6	20	55	14	36	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	6	21	5	14	35	0	0	0	0	0	0	0	65.43	0	0	12
2014	9	6	21	15	14	36	0	0	0	0	0	0	0	65.44	0	0	12
2014	9	6	21	25	14	35	0	0	0	0	0	0	0	65.46	0	0	11.8
2014	9	6	21	35	14	35	0	0	0	0	0	0	0	65.5	0	0	12
2014	9	6	21	45	14	35	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	6	21	55	14	36	0	0	0	0	0	0	0	65.55	0	0	12
2014	9	6	22	5	14	35	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	6	22	15	14	35	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	6	22	25	14	35	0	0	0	0	0	0	0	65.62	0	0	11.8
2014	9	6	22	35	14	36	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	6	22	45	14	34	0	0	0	0	0	0	0	65.66	0	0	11.8
2014	9	6	22	55	14	35	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	6	23	5	14	35	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	6	23	15	14	35	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	6	23	25	14	34	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	6	23	35	14	35	0	0	0	0	0	0	0	65.75	0	0	11.8
2014	9	6	23	45	14	35	0	0	0	0	0	0	0	65.75	0	0	11.2
2014	9	6	23	55	14	36	0	0	0	0	0	0	0	65.75	0	0	11.2
2014	9	7	0	5	14	35	0	0	0	0	0	0	0	65.77	0	0	11.2
2014	9	7	0	15	14	36	0	0	0	0	0	0	0	65.77	0	0	11.2
2014	9	7	0	25	14	36	0	0	0	0	0	0	0	65.77	0	0	11.2
2014	9	7	0	35	14	35	0	0	0	0	0	0	0	65.77	0	0	11.2
2014	9	7	0	45	14	34	0	0	0	0	0	0	0	65.77	0	0	11.2
2014	9	7	0	55	14	35	0	0	0	0	0	0	0	65.75	0	0	11.2
2014	9	7	1	5	14	35	0	0	0	0	0	0	0	65.73	0	0	11.2
2014	9	7	1	15	14	35	0	0	0	0	0	0	0	65.73	0	0	11.2
2014	9	7	1	25	14	35	0	0	0	0	0	0	0	65.71	0	0	11.2
2014	9	7	1	35	14	35	0	0	0	0	0	0	0	65.7	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	1	45	14	35	0	0	0	0	0	0	0	65.68	0	0	11.4
2014	9	7	1	55	14	35	0	0	0	0	0	0	0	65.66	0	0	11.4
2014	9	7	2	5	14	34	0	0	0	0	0	0	0	65.64	0	0	11.2
2014	9	7	2	15	14	35	0	0	0	0	0	0	0	65.62	0	0	11.2
2014	9	7	2	25	14	35	0	0	0	0	0	0	0	65.61	0	0	11.2
2014	9	7	2	35	14	35	0	0	0	0	0	0	0	65.59	0	0	11.2
2014	9	7	2	45	14	35	0	0	0	0	0	0	0	65.57	0	0	11.4
2014	9	7	2	55	14	35	0	0	0	0	0	0	0	65.53	0	0	11.4
2014	9	7	3	5	14	36	0	0	0	0	0	0	0	65.53	0	0	11.4
2014	9	7	3	15	14	35	0	0	0	0	0	0	0	65.5	0	0	11.4
2014	9	7	3	25	14	35	0	0	0	0	0	0	0	65.48	0	0	11.4
2014	9	7	3	35	14	35	0	0	0	0	0	0	0	65.44	0	0	11.4
2014	9	7	3	45	14	35	0	0	0	0	0	0	0	65.43	0	0	11.4
2014	9	7	3	55	14	36	0	0	0	0	0	0	0	65.39	0	0	11.4
2014	9	7	4	5	14	35	0	0	0	0	0	0	0	65.37	0	0	11.4
2014	9	7	4	15	14	35	0	0	0	0	0	0	0	65.34	0	0	11.4
2014	9	7	4	25	14	35	0	0	0	0	0	0	0	65.32	0	0	11.4
2014	9	7	4	35	14	36	0	0	0	0	0	0	0	65.28	0	0	11.4
2014	9	7	4	45	14	35	0	0	0	0	0	0	0	65.26	0	0	11.2
2014	9	7	4	55	14	35	0	0	0	0	0	0	0	65.25	0	0	11.2
2014	9	7	5	5	14	35	0	0	0	0	0	0	0	65.21	0	0	11.2
2014	9	7	5	15	14	35	0	0	0	0	0	0	0	65.19	0	0	11.2
2014	9	7	5	25	14	35	0	0	0	0	0	0	0	65.16	0	0	11.2
2014	9	7	5	35	14	35	0	0	0	0	0	0	0	65.14	0	0	11.2
2014	9	7	5	45	14	35	0	0	0	0	0	0	0	65.12	0	0	11.2
2014	9	7	5	55	14	35	0	0	0	0	0	0	0	65.08	0	0	11.2
2014	9	7	6	5	14	36	0	0	0	0	0	0	0	65.05	0	0	11.2
2014	9	7	6	15	14	35	0	0	0	0	0	0	0	65.03	0	0	11.2
2014	9	7	6	25	14	34	0	0	0	0	0	0	0	64.99	0	0	11.2
2014	9	7	6	35	14	35	0	0	0	0	0	0	0	64.98	0	0	11.2
2014	9	7	6	45	14	36	0	0	0	0	0	0	0	64.94	0	0	11.4
2014	9	7	6	55	14	35	0	0	0	0	0	0	0	64.9	0	0	11.4
2014	9	7	7	5	14	36	0	0	0	0	0	0	0	64.89	0	0	11.4
2014	9	7	7	15	14	35	0	0	0	0	0	0	0	64.85	0	0	11.4
2014	9	7	7	25	14	35	0	0	0	0	0	0	0	64.83	0	0	12.4
2014	9	7	7	35	14	35	0	0	0	0	0	0	0	64.81	0	0	12.6
2014	9	7	7	45	14	35	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	7	7	55	14	36	0	0	0	0	0	0	0	64.81	0	0	12.8
2014	9	7	8	5	14	35	0	0	0	0	0	0	0	64.81	0	0	13
2014	9	7	8	15	14	35	0	0	0	0	0	0	0	64.81	0	0	13
2014	9	7	8	25	14	35	0	0	0	0	0	0	0	64.83	0	0	13.2
2014	9	7	8	35	14	35	0	0	0	0	0	0	0	64.85	0	0	13.2
2014	9	7	8	45	14	35	0	0	0	0	0	0	0	64.85	0	0	13.4
2014	9	7	8	55	14	35	0	0	0	0	0	0	0	64.89	0	0	13.2
2014	9	7	9	5	14	34	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	7	9	15	14	35	0	0	0	0	0	0	0	64.92	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	9	25	14	35	0	0	0	0	0	0	0	64.96	0	0	13.2
2014	9	7	9	35	14	35	0	0	0	0	0	0	0	64.98	0	0	13.2
2014	9	7	9	45	14	35	0	0	0	0	0	0	0	65.01	0	0	13.2
2014	9	7	9	55	14	35	0	0	0	0	0	0	0	65.05	0	0	13.2
2014	9	7	10	5	14	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	7	10	15	14	35	0	0	0	0	0	0	0	65.12	0	0	13
2014	9	7	10	25	14	36	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	7	10	35	14	35	0	0	0	0	0	0	0	65.21	0	0	13
2014	9	7	10	45	14	35	0	0	0	0	0	0	0	65.25	0	0	13
2014	9	7	10	55	14	35	0	0	0	0	0	0	0	65.28	0	0	13
2014	9	7	11	5	14	35	0	0	0	0	0	0	0	65.34	0	0	13
2014	9	7	11	15	14	35	0	0	0	0	0	0	0	65.37	0	0	13
2014	9	7	11	25	14	35	0	0	0	0	0	0	0	65.41	0	0	13
2014	9	7	11	35	14	35	0	0	0	0	0	0	0	65.44	0	0	13
2014	9	7	11	45	14	35	0	0	0	0	0	0	0	65.5	0	0	13
2014	9	7	11	55	14	35	0	0	0	0	0	0	0	65.52	0	0	13
2014	9	7	12	5	14	35	0	0	0	0	0	0	0	65.53	0	0	13
2014	9	7	12	15	14	35	0	0	0	0	0	0	0	65.57	0	0	13
2014	9	7	12	25	14	35	0	0	0	0	0	0	0	65.59	0	0	13
2014	9	7	12	35	14	35	0	0	0	0	0	0	0	65.62	0	0	13
2014	9	7	12	45	14	35	0	0	0	0	0	0	0	65.64	0	0	13
2014	9	7	12	55	14	35	0	0	0	0	0	0	0	65.66	0	0	13
2014	9	7	13	5	14	34	0	0	0	0	0	0	0	65.68	0	0	13
2014	9	7	13	15	14	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	7	13	25	14	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	7	13	35	14	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	7	13	45	14	35	0	0	0	0	0	0	0	65.73	0	0	13
2014	9	7	13	55	14	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	7	14	5	14	35	0	0	0	0	0	0	0	65.77	0	0	13
2014	9	7	14	15	14	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	7	14	25	14	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	7	14	35	14	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	7	14	45	14	35	0	0	0	0	0	0	0	65.7	0	0	13
2014	9	7	14	55	14	35	0	0	0	0	0	0	0	65.68	0	0	13
2014	9	7	15	5	14	35	0	0	0	0	0	0	0	65.7	0	0	13
2014	9	7	15	15	14	35	0	0	0	0	0	0	0	65.68	0	0	13
2014	9	7	15	25	14	35	0	0	0	0	0	0	0	65.66	0	0	12.8
2014	9	7	15	35	14	35	0	0	0	0	0	0	0	65.66	0	0	12.8
2014	9	7	15	45	14	35	0	0	0	0	0	0	0	65.62	0	0	13
2014	9	7	15	55	14	35	0	0	0	0	0	0	0	65.57	0	0	12.4
2014	9	7	16	5	14	35	0	0	0	0	0	0	0	65.55	0	0	13
2014	9	7	16	15	14	36	0	0	0	0	0	0	0	65.52	0	0	12.6
2014	9	7	16	25	14	35	0	0	0	0	0	0	0	65.55	0	0	13
2014	9	7	16	35	14	34	0	0	0	0	0	0	0	65.53	0	0	13
2014	9	7	16	45	14	35	0	0	0	0	0	0	0	65.53	0	0	13
2014	9	7	16	55	14	35	0	0	0	0	0	0	0	65.5	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	17	5	14	35	0	0	0	0	0	0	0	65.5	0	0	12.2
2014	9	7	17	15	14	35	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	7	17	25	14	36	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	17	35	14	35	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	17	45	14	36	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	17	55	14	35	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	7	18	5	14	35	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	7	18	15	14	35	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	18	25	14	35	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	18	35	14	35	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	7	18	45	14	35	0	0	0	0	0	0	0	65.5	0	0	11.8
2014	9	7	18	55	14	35	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	7	19	5	14	35	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	7	19	15	14	35	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	7	19	25	14	35	0	0	0	0	0	0	0	65.55	0	0	11.8
2014	9	7	19	35	14	34	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	7	19	45	14	35	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	7	19	55	14	35	0	0	0	0	0	0	0	65.62	0	0	11.8
2014	9	7	20	5	14	35	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	7	20	15	14	35	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	7	20	25	14	35	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	7	20	35	14	35	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	7	20	45	14	35	0	0	0	0	0	0	0	65.75	0	0	11.8
2014	9	7	20	55	14	35	0	0	0	0	0	0	0	65.77	0	0	11.8
2014	9	7	21	5	14	35	0	0	0	0	0	0	0	65.8	0	0	11.8
2014	9	7	21	15	14	35	0	0	0	0	0	0	0	65.82	0	0	11.6
2014	9	7	21	25	14	35	0	0	0	0	0	0	0	65.86	0	0	11.6
2014	9	7	21	35	14	35	0	0	0	0	0	0	0	65.88	0	0	11.6
2014	9	7	21	45	14	35	0	0	0	0	0	0	0	65.91	0	0	11.6
2014	9	7	21	55	14	35	0	0	0	0	0	0	0	65.93	0	0	11.6
2014	9	7	22	5	14	35	0	0	0	0	0	0	0	65.97	0	0	11.6
2014	9	7	22	15	14	35	0	0	0	0	0	0	0	65.98	0	0	11.6
2014	9	7	22	25	14	35	0	0	0	0	0	0	0	66	0	0	11.4
2014	9	7	22	35	14	35	0	0	0	0	0	0	0	66.04	0	0	11.4
2014	9	7	22	45	14	35	0	0	0	0	0	0	0	66.06	0	0	11
2014	9	7	22	55	14	35	0	0	0	0	0	0	0	66.07	0	0	11
2014	9	7	23	5	14	35	0	0	0	0	0	0	0	66.09	0	0	11
2014	9	7	23	15	14	34	0	0	0	0	0	0	0	66.11	0	0	11.2
2014	9	7	23	25	14	35	0	0	0	0	0	0	0	66.11	0	0	11.4
2014	9	7	23	35	14	36	0	0	0	0	0	0	0	66.13	0	0	11.2
2014	9	7	23	45	14	35	0	0	0	0	0	0	0	66.15	0	0	11.4
2014	9	7	23	55	14	35	0	0	0	0	0	0	0	66.16	0	0	11.4
2014	9	8	0	5	14	35	0	0	0	0	0	0	0	66.16	0	0	11.4
2014	9	8	0	15	14	35	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	8	0	25	14	35	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	8	0	35	14	35	0	0	0	0	0	0	0	66.18	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	0	45	14	34	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	0	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	1	5	14	36	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	1	15	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	1	25	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	1	35	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	1	45	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	1	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	5	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	15	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	25	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	35	14	36	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	45	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	2	55	14	35	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	3	5	14	34	0	0	0	0	0	0	0	66.2	0	0	11
2014	9	8	3	15	14	36	0	0	0	0	0	0	0	66.2	0	0	10.8
2014	9	8	3	25	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	3	35	14	36	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	3	45	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	3	55	14	36	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	4	5	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	4	15	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	4	25	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	4	35	14	35	0	0	0	0	0	0	0	66.18	0	0	11.2
2014	9	8	4	45	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	4	55	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	5	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	15	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	25	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	35	14	35	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	45	14	36	0	0	0	0	0	0	0	66.18	0	0	11
2014	9	8	5	55	14	35	0	0	0	0	0	0	0	66.18	0	0	11.4
2014	9	8	6	5	14	35	0	0	0	0	0	0	0	66.2	0	0	11.4
2014	9	8	6	15	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	6	25	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	6	35	14	35	0	0	0	0	0	0	0	66.2	0	0	11.2
2014	9	8	6	45	14	35	0	0	0	0	0	0	0	66.2	0	0	11.4
2014	9	8	6	55	14	35	0	0	0	0	0	0	0	66.22	0	0	11.4
2014	9	8	7	5	14	34	0	0	0	0	0	0	0	66.2	0	0	11.4
2014	9	8	7	15	14	35	0	0	0	0	0	0	0	66.22	0	0	11.6
2014	9	8	7	25	14	35	0	0	0	0	0	0	0	66.24	0	0	11.6
2014	9	8	7	35	14	35	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	8	7	45	14	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	8	7	55	14	35	0	0	0	0	0	0	0	66.29	0	0	12.8
2014	9	8	8	5	14	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2014	9	8	8	15	14	35	0	0	0	0	0	0	0	66.4	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	8	25	14	35	0	0	0	0	0	0	0	66.4	0	0	13
2014	9	8	8	35	14	35	0	0	0	0	0	0	0	66.38	0	0	12.2
2014	9	8	8	45	14	35	0	0	0	0	0	0	0	66.36	0	0	12
2014	9	8	8	55	14	35	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	9	8	9	5	14	35	0	0	0	0	0	0	0	66.56	0	0	13.2
2014	9	8	9	15	14	34	0	0	0	0	0	0	0	66.61	0	0	13.2
2014	9	8	9	25	14	35	0	0	0	0	0	0	0	66.56	0	0	12.8
2014	9	8	9	35	14	35	0	0	0	0	0	0	0	66.58	0	0	13.2
2014	9	8	9	45	14	34	0	0	0	0	0	0	0	66.65	0	0	12.8
2014	9	8	9	55	14	35	0	0	0	0	0	0	0	66.65	0	0	13
2014	9	8	10	5	14	35	0	0	0	0	0	0	0	66.69	0	0	13
2014	9	8	10	15	14	34	0	0	0	0	0	0	0	66.78	0	0	13
2014	9	8	10	25	14	35	0	0	0	0	0	0	0	66.78	0	0	12.8
2014	9	8	10	35	14	35	0	0	0	0	0	0	0	66.85	0	0	13.2
2014	9	8	10	45	14	35	0	0	0	0	0	0	0	66.83	0	0	13
2014	9	8	10	55	14	35	0	0	0	0	0	0	0	66.92	0	0	13.2
2014	9	8	11	5	14	36	0	0	0	0	0	0	0	66.97	0	0	13
2014	9	8	11	16	47	35	0	0	0	0	0	0	0	67.05	0	0	13.2
2014	9	8	11	26	47	35	0	0	0	0	0	0	0	67.08	0	0	13.2
2014	9	8	11	36	47	35	0	0	0	0	0	0	0	67.1	0	0	13
2014	9	8	11	46	47	35	0	0	0	0	0	0	0	66.9	0	0	12.4
2014	9	8	11	56	47	35	0	0	0	0	0	0	0	67.05	0	0	13.2
2014	9	8	12	6	47	35	0	0	0	0	0	0	0	67.06	0	0	12.8
2014	9	8	12	16	47	35	0	0	0	0	0	0	0	67.1	0	0	13
2014	9	8	12	26	47	35	0	0	0	0	0	0	0	67.19	0	0	12.8
2014	9	8	12	36	47	35	0	0	0	0	0	0	0	67.21	0	0	13
2014	9	8	12	46	47	34	0	0	0	0	0	0	0	67.26	0	0	13
2014	9	8	12	56	47	35	0	0	0	0	0	0	0	67.32	0	0	13.2
2014	9	8	13	6	47	35	0	0	0	0	0	0	0	67.08	0	0	13
2014	9	8	13	16	47	35	0	0	0	0	0	0	0	66.96	0	0	12.4
2014	9	8	13	26	47	34	0	0	0	0	0	0	0	66.94	0	0	13
2014	9	8	13	36	47	35	0	0	0	0	0	0	0	67.03	0	0	13.2
2014	9	8	13	46	47	35	0	0	0	0	0	0	0	67.15	0	0	13.2
2014	9	8	13	56	47	35	0	0	0	0	0	0	0	67.15	0	0	13.2
2014	9	8	14	6	47	35	0	0	0	0	0	0	0	67.08	0	0	13.2
2014	9	8	14	16	47	35	0	0	0	0	0	0	0	67.24	0	0	13
2014	9	8	14	26	47	34	0	0	0	0	0	0	0	67.28	0	0	13
2014	9	8	14	36	47	35	0	0	0	0	0	0	0	67.28	0	0	13
2014	9	8	14	46	47	34	0	0	0	0	0	0	0	67.32	0	0	13
2014	9	8	14	56	47	35	0	0	0	0	0	0	0	67.3	0	0	13
2014	9	8	15	6	47	35	0	0	0	0	0	0	0	67.32	0	0	13
2014	9	8	15	16	47	35	0	0	0	0	0	0	0	67.32	0	0	13
2014	9	8	15	26	47	34	0	0	0	0	0	0	0	67.28	0	0	12.8
2014	9	8	15	36	47	35	0	0	0	0	0	0	0	67.3	0	0	12.8
2014	9	8	15	46	47	35	0	0	0	0	0	0	0	67.28	0	0	12.8
2014	9	8	15	56	47	35	0	0	0	0	0	0	0	67.15	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	16	6	47	35	0	0	0	0	0	0	0	67.15	0	0	13
2014	9	8	16	16	47	35	0	0	0	0	0	0	0	67.23	0	0	13
2014	9	8	16	26	47	35	0	0	0	0	0	0	0	67.23	0	0	12.8
2014	9	8	16	36	47	35	0	0	0	0	0	0	0	67.21	0	0	12.8
2014	9	8	16	46	47	35	0	0	0	0	0	0	0	67.21	0	0	12.6
2014	9	8	16	56	47	35	0	0	0	0	0	0	0	67.15	0	0	12
2014	9	8	17	6	47	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	17	16	47	34	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	17	26	47	35	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	8	17	36	47	35	0	0	0	0	0	0	0	67.17	0	0	11.8
2014	9	8	17	46	47	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	17	56	47	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	18	6	47	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	18	16	47	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	8	18	26	47	35	0	0	0	0	0	0	0	67.15	0	0	11.8
2014	9	8	18	36	47	34	0	0	0	0	0	0	0	67.15	0	0	11.8
2014	9	8	18	46	47	35	0	0	0	0	0	0	0	67.17	0	0	11.8
2014	9	8	18	56	47	35	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	8	19	6	47	35	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	8	19	16	47	35	0	0	0	0	0	0	0	67.21	0	0	11.6
2014	9	8	19	26	47	35	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	8	19	36	47	34	0	0	0	0	0	0	0	67.24	0	0	11.6
2014	9	8	19	46	47	35	0	0	0	0	0	0	0	67.26	0	0	11.6
2014	9	8	19	56	47	34	0	0	0	0	0	0	0	67.28	0	0	11.6
2014	9	8	20	6	47	35	0	0	0	0	0	0	0	67.3	0	0	11.6
2014	9	8	20	16	47	35	0	0	0	0	0	0	0	67.3	0	0	11.8
2014	9	8	20	26	47	35	0	0	0	0	0	0	0	67.32	0	0	11.6
2014	9	8	20	36	47	36	0	0	0	0	0	0	0	67.33	0	0	11.8
2014	9	8	20	46	47	35	0	0	0	0	0	0	0	67.33	0	0	11.6
2014	9	8	20	56	47	35	0	0	0	0	0	0	0	67.35	0	0	11.6
2014	9	8	21	6	47	34	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	8	21	16	47	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	8	21	26	47	35	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	8	21	36	47	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	8	21	46	47	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	8	21	56	47	34	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	22	6	47	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	22	16	47	35	0	0	0	0	0	0	0	67.42	0	0	11.8
2014	9	8	22	26	47	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	22	36	47	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	22	46	47	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	22	56	47	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	8	23	6	47	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	8	23	16	47	34	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	8	23	26	47	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	8	23	36	47	35	0	0	0	0	0	0	0	67.39	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	23	46	47	35	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	8	23	56	47	34	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	9	0	6	47	35	0	0	0	0	0	0	0	67.35	0	0	11.8
2014	9	9	0	16	47	35	0	0	0	0	0	0	0	67.35	0	0	11.6
2014	9	9	0	26	47	34	0	0	0	0	0	0	0	67.33	0	0	11.6
2014	9	9	0	36	47	35	0	0	0	0	0	0	0	67.33	0	0	11.8
2014	9	9	0	46	47	35	0	0	0	0	0	0	0	67.32	0	0	11.8
2014	9	9	0	56	47	34	0	0	0	0	0	0	0	67.32	0	0	11.8
2014	9	9	1	6	47	35	0	0	0	0	0	0	0	67.32	0	0	11.8
2014	9	9	1	16	47	35	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	9	1	26	47	35	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	9	1	36	47	35	0	0	0	0	0	0	0	67.26	0	0	11.8
2014	9	9	1	46	47	35	0	0	0	0	0	0	0	67.24	0	0	11.8
2014	9	9	1	56	47	35	0	0	0	0	0	0	0	67.23	0	0	11.8
2014	9	9	2	6	47	35	0	0	0	0	0	0	0	67.23	0	0	11.8
2014	9	9	2	16	47	35	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	9	2	26	47	35	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	9	2	36	47	35	0	0	0	0	0	0	0	67.17	0	0	11.8
2014	9	9	2	46	47	35	0	0	0	0	0	0	0	67.14	0	0	11.6
2014	9	9	2	56	47	35	0	0	0	0	0	0	0	67.12	0	0	11.6
2014	9	9	3	6	47	35	0	0	0	0	0	0	0	67.1	0	0	11.4
2014	9	9	3	16	47	35	0	0	0	0	0	0	0	67.06	0	0	11.6
2014	9	9	3	26	47	36	0	0	0	0	0	0	0	67.05	0	0	11.6
2014	9	9	3	36	47	34	0	0	0	0	0	0	0	67.01	0	0	11.6
2014	9	9	3	46	47	34	0	0	0	0	0	0	0	66.99	0	0	11.6
2014	9	9	3	56	47	35	0	0	0	0	0	0	0	66.97	0	0	11.6
2014	9	9	4	6	47	35	0	0	0	0	0	0	0	66.94	0	0	11.6
2014	9	9	4	16	47	35	0	0	0	0	0	0	0	66.92	0	0	11.6
2014	9	9	4	26	47	35	0	0	0	0	0	0	0	66.9	0	0	11.6
2014	9	9	4	36	47	35	0	0	0	0	0	0	0	66.87	0	0	11.6
2014	9	9	4	46	47	35	0	0	0	0	0	0	0	66.85	0	0	11.6
2014	9	9	4	56	47	35	0	0	0	0	0	0	0	66.83	0	0	11.6
2014	9	9	5	6	47	35	0	0	0	0	0	0	0	66.79	0	0	11.6
2014	9	9	5	16	47	36	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	9	5	26	47	35	0	0	0	0	0	0	0	66.76	0	0	11.4
2014	9	9	5	36	47	35	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	9	5	46	47	35	0	0	0	0	0	0	0	66.69	0	0	11.4
2014	9	9	5	56	47	35	0	0	0	0	0	0	0	66.67	0	0	11.4
2014	9	9	6	6	47	35	0	0	0	0	0	0	0	66.63	0	0	11.4
2014	9	9	6	16	47	35	0	0	0	0	0	0	0	66.61	0	0	11.4
2014	9	9	6	26	47	35	0	0	0	0	0	0	0	66.58	0	0	11.4
2014	9	9	6	36	47	35	0	0	0	0	0	0	0	66.52	0	0	11.4
2014	9	9	6	46	47	36	0	0	0	0	0	0	0	66.51	0	0	11.4
2014	9	9	6	56	47	35	0	0	0	0	0	0	0	66.45	0	0	11.4
2014	9	9	7	6	47	35	0	0	0	0	0	0	0	66.42	0	0	11.4
2014	9	9	7	16	47	35	0	0	0	0	0	0	0	66.38	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	7	26	47	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	9	7	36	47	35	0	0	0	0	0	0	0	66.33	0	0	12
2014	9	9	7	46	47	35	0	0	0	0	0	0	0	66.29	0	0	12.4
2014	9	9	7	56	47	35	0	0	0	0	0	0	0	66.29	0	0	12.4
2014	9	9	8	6	47	35	0	0	0	0	0	0	0	66.29	0	0	12.6
2014	9	9	8	16	47	36	0	0	0	0	0	0	0	66.27	0	0	12.6
2014	9	9	8	26	47	35	0	0	0	0	0	0	0	66.27	0	0	12.8
2014	9	9	8	36	47	35	0	0	0	0	0	0	0	66.27	0	0	12.8
2014	9	9	8	46	47	35	0	0	0	0	0	0	0	66.27	0	0	12.8
2014	9	9	8	56	47	35	0	0	0	0	0	0	0	66.29	0	0	13
2014	9	9	9	6	47	35	0	0	0	0	0	0	0	66.31	0	0	13
2014	9	9	9	16	47	35	0	0	0	0	0	0	0	66.31	0	0	13
2014	9	9	9	26	47	35	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	9	9	36	47	35	0	0	0	0	0	0	0	66.34	0	0	13
2014	9	9	9	46	47	34	0	0	0	0	0	0	0	66.36	0	0	13
2014	9	9	9	56	47	34	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	9	10	6	47	35	0	0	0	0	0	0	0	66.42	0	0	13
2014	9	9	10	16	47	35	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	9	10	26	47	34	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	9	10	36	47	35	0	0	0	0	0	0	0	66.51	0	0	13
2014	9	9	10	46	47	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	9	10	56	47	35	0	0	0	0	0	0	0	66.56	0	0	13
2014	9	9	11	6	47	34	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	9	11	16	47	36	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	9	11	26	47	35	0	0	0	0	0	0	0	66.67	0	0	13
2014	9	9	11	36	47	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	9	11	46	47	35	0	0	0	0	0	0	0	66.74	0	0	13
2014	9	9	11	56	47	34	0	0	0	0	0	0	0	66.76	0	0	13
2014	9	9	12	6	47	35	0	0	0	0	0	0	0	66.81	0	0	13
2014	9	9	12	16	47	35	0	0	0	0	0	0	0	66.83	0	0	13
2014	9	9	12	26	47	35	0	0	0	0	0	0	0	66.87	0	0	13
2014	9	9	12	36	47	35	0	0	0	0	0	0	0	66.88	0	0	13
2014	9	9	12	46	47	35	0	0	0	0	0	0	0	66.9	0	0	13
2014	9	9	12	56	47	34	0	0	0	0	0	0	0	66.94	0	0	13
2014	9	9	13	6	47	35	0	0	0	0	0	0	0	66.96	0	0	13
2014	9	9	13	16	47	36	0	0	0	0	0	0	0	66.96	0	0	13
2014	9	9	13	26	47	35	0	0	0	0	0	0	0	66.97	0	0	13
2014	9	9	13	36	47	35	0	0	0	0	0	0	0	66.99	0	0	13
2014	9	9	13	46	47	35	0	0	0	0	0	0	0	67.01	0	0	13
2014	9	9	13	56	47	35	0	0	0	0	0	0	0	67.01	0	0	13
2014	9	9	14	6	47	35	0	0	0	0	0	0	0	67.03	0	0	13
2014	9	9	14	16	47	35	0	0	0	0	0	0	0	67.03	0	0	13
2014	9	9	14	26	47	35	0	0	0	0	0	0	0	67.03	0	0	13
2014	9	9	14	36	47	34	0	0	0	0	0	0	0	67.01	0	0	12.8
2014	9	9	14	46	47	35	0	0	0	0	0	0	0	67.03	0	0	12.8
2014	9	9	14	56	47	34	0	0	0	0	0	0	0	67.01	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	15	6	47	35	0	0	0	0	0	0	0	66.99	0	0	12.8
2014	9	9	15	16	47	35	0	0	0	0	0	0	0	66.99	0	0	12.8
2014	9	9	15	26	47	35	0	0	0	0	0	0	0	66.99	0	0	12.8
2014	9	9	15	36	47	35	0	0	0	0	0	0	0	66.96	0	0	12.8
2014	9	9	15	46	47	34	0	0	0	0	0	0	0	66.96	0	0	12.8
2014	9	9	15	56	47	35	0	0	0	0	0	0	0	66.94	0	0	12.6
2014	9	9	16	6	47	35	0	0	0	0	0	0	0	66.94	0	0	12.8
2014	9	9	16	16	47	35	0	0	0	0	0	0	0	66.92	0	0	12.8
2014	9	9	16	26	47	35	0	0	0	0	0	0	0	66.88	0	0	12.8
2014	9	9	16	36	47	35	0	0	0	0	0	0	0	66.88	0	0	12.8
2014	9	9	16	46	47	35	0	0	0	0	0	0	0	66.87	0	0	12.6
2014	9	9	16	56	47	34	0	0	0	0	0	0	0	66.85	0	0	12.8
2014	9	9	17	6	47	35	0	0	0	0	0	0	0	66.83	0	0	12.6
2014	9	9	17	16	47	35	0	0	0	0	0	0	0	66.83	0	0	12
2014	9	9	17	26	47	35	0	0	0	0	0	0	0	66.81	0	0	12
2014	9	9	17	36	47	35	0	0	0	0	0	0	0	66.81	0	0	11.8
2014	9	9	17	46	47	35	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	9	17	56	47	35	0	0	0	0	0	0	0	66.78	0	0	12
2014	9	9	18	6	47	35	0	0	0	0	0	0	0	66.76	0	0	11.8
2014	9	9	18	16	47	35	0	0	0	0	0	0	0	66.76	0	0	12
2014	9	9	18	26	47	35	0	0	0	0	0	0	0	66.76	0	0	11.8
2014	9	9	18	36	47	34	0	0	0	0	0	0	0	66.76	0	0	11.8
2014	9	9	18	46	47	34	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	18	56	47	35	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	19	6	47	35	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	19	16	47	35	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	19	26	47	35	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	19	36	47	35	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	9	19	46	47	35	0	0	0	0	0	0	0	66.79	0	0	11.6
2014	9	9	19	56	47	35	0	0	0	0	0	0	0	66.78	0	0	11.8
2014	9	9	20	6	47	34	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	9	20	16	47	35	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	9	20	26	47	34	0	0	0	0	0	0	0	66.79	0	0	11.8
2014	9	9	20	36	47	35	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	9	20	46	47	34	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	9	20	56	47	35	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	9	21	6	47	35	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	9	21	16	47	35	0	0	0	0	0	0	0	66.76	0	0	11.8
2014	9	9	21	26	47	35	0	0	0	0	0	0	0	66.76	0	0	11.8
2014	9	9	21	36	47	35	0	0	0	0	0	0	0	66.74	0	0	11.8
2014	9	9	21	46	47	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	9	21	56	47	34	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	9	22	6	47	34	0	0	0	0	0	0	0	66.72	0	0	11.6
2014	9	9	22	16	47	35	0	0	0	0	0	0	0	66.7	0	0	11.6
2014	9	9	22	26	47	35	0	0	0	0	0	0	0	66.69	0	0	11.6
2014	9	9	22	36	47	35	0	0	0	0	0	0	0	66.67	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	22	46	47	34	0	0	0	0	0	0	0	66.67	0	0	11.6
2014	9	9	22	56	47	34	0	0	0	0	0	0	0	66.63	0	0	11.6
2014	9	9	23	6	47	35	0	0	0	0	0	0	0	66.61	0	0	11.6
2014	9	9	23	16	47	34	0	0	0	0	0	0	0	66.6	0	0	11.6
2014	9	9	23	26	47	35	0	0	0	0	0	0	0	66.58	0	0	11.6
2014	9	9	23	36	47	36	0	0	0	0	0	0	0	66.54	0	0	11.6
2014	9	9	23	46	47	35	0	0	0	0	0	0	0	66.52	0	0	11.6
2014	9	9	23	56	47	34	0	0	0	0	0	0	0	66.49	0	0	11.4
2014	9	10	0	6	47	35	0	0	0	0	0	0	0	66.47	0	0	11.4
2014	9	10	0	16	47	35	0	0	0	0	0	0	0	66.43	0	0	11.4
2014	9	10	0	26	47	36	0	0	0	0	0	0	0	66.4	0	0	11.4
2014	9	10	0	36	47	35	0	0	0	0	0	0	0	66.38	0	0	11.4
2014	9	10	0	46	47	35	0	0	0	0	0	0	0	66.34	0	0	11.4
2014	9	10	0	56	47	35	0	0	0	0	0	0	0	66.29	0	0	11.4
2014	9	10	1	6	47	34	0	0	0	0	0	0	0	66.25	0	0	11.4
2014	9	10	1	16	47	35	0	0	0	0	0	0	0	66.22	0	0	11.4
2014	9	10	1	26	47	35	0	0	0	0	0	0	0	66.18	0	0	11.4
2014	9	10	1	36	47	35	0	0	0	0	0	0	0	66.13	0	0	11.6
2014	9	10	1	46	47	35	0	0	0	0	0	0	0	66.09	0	0	11.4
2014	9	10	1	56	47	35	0	0	0	0	0	0	0	66.04	0	0	11.4
2014	9	10	2	6	47	35	0	0	0	0	0	0	0	65.98	0	0	11.6
2014	9	10	2	16	47	35	0	0	0	0	0	0	0	65.95	0	0	11.4
2014	9	10	2	26	47	35	0	0	0	0	0	0	0	65.89	0	0	11.4
2014	9	10	2	36	47	35	0	0	0	0	0	0	0	65.86	0	0	11.6
2014	9	10	2	46	47	36	0	0	0	0	0	0	0	65.8	0	0	11.4
2014	9	10	2	56	47	35	0	0	0	0	0	0	0	65.75	0	0	11.4
2014	9	10	3	6	47	35	0	0	0	0	0	0	0	65.7	0	0	11.6
2014	9	10	3	16	47	35	0	0	0	0	0	0	0	65.66	0	0	11.4
2014	9	10	3	26	47	34	0	0	0	0	0	0	0	65.61	0	0	11.4
2014	9	10	3	36	47	35	0	0	0	0	0	0	0	65.57	0	0	11.4
2014	9	10	3	46	47	35	0	0	0	0	0	0	0	65.52	0	0	11.4
2014	9	10	3	56	47	36	0	0	0	0	0	0	0	65.46	0	0	11.4
2014	9	10	4	6	47	35	0	0	0	0	0	0	0	65.43	0	0	11.4
2014	9	10	4	16	47	35	0	0	0	0	0	0	0	65.39	0	0	11.4
2014	9	10	4	26	47	35	0	0	0	0	0	0	0	65.34	0	0	11.4
2014	9	10	4	36	47	35	0	0	0	0	0	0	0	65.28	0	0	11.4
2014	9	10	4	46	47	35	0	0	0	0	0	0	0	65.23	0	0	11.4
2014	9	10	4	56	47	36	0	0	0	0	0	0	0	65.19	0	0	11.4
2014	9	10	5	6	47	35	0	0	0	0	0	0	0	65.14	0	0	11.4
2014	9	10	5	16	47	35	0	0	0	0	0	0	0	65.08	0	0	11.4
2014	9	10	5	26	47	35	0	0	0	0	0	0	0	65.01	0	0	11.4
2014	9	10	5	36	47	35	0	0	0	0	0	0	0	64.98	0	0	11.4
2014	9	10	5	46	47	36	0	0	0	0	0	0	0	64.92	0	0	11.2
2014	9	10	5	56	47	35	0	0	0	0	0	0	0	64.87	0	0	11.4
2014	9	10	6	6	47	35	0	0	0	0	0	0	0	64.83	0	0	11.2
2014	9	10	6	16	47	35	0	0	0	0	0	0	0	64.8	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	6	26	47	35	0	0	0	0	0	0	0	64.74	0	0	11.6
2014	9	10	6	36	47	36	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	10	6	46	47	35	0	0	0	0	0	0	0	64.63	0	0	11.4
2014	9	10	6	56	47	35	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	10	7	6	47	35	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	10	7	16	47	35	0	0	0	0	0	0	0	64.49	0	0	11.6
2014	9	10	7	26	47	35	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	10	7	36	47	35	0	0	0	0	0	0	0	64.42	0	0	12
2014	9	10	7	46	47	36	0	0	0	0	0	0	0	64.38	0	0	12.2
2014	9	10	7	56	47	36	0	0	0	0	0	0	0	64.36	0	0	12.4
2014	9	10	8	6	47	35	0	0	0	0	0	0	0	64.35	0	0	12.6
2014	9	10	8	16	47	35	0	0	0	0	0	0	0	64.35	0	0	12.6
2014	9	10	8	26	47	35	0	0	0	0	0	0	0	64.33	0	0	12.8
2014	9	10	8	36	47	35	0	0	0	0	0	0	0	64.33	0	0	13
2014	9	10	8	46	47	35	0	0	0	0	0	0	0	64.33	0	0	13
2014	9	10	8	56	47	35	0	0	0	0	0	0	0	64.33	0	0	13.2
2014	9	10	9	6	47	35	0	0	0	0	0	0	0	64.33	0	0	13.2
2014	9	10	9	16	47	35	0	0	0	0	0	0	0	64.35	0	0	13.2
2014	9	10	9	26	47	34	0	0	0	0	0	0	0	64.36	0	0	13.2
2014	9	10	9	36	47	35	0	0	0	0	0	0	0	64.36	0	0	13.2
2014	9	10	9	46	47	35	0	0	0	0	0	0	0	64.38	0	0	13
2014	9	10	9	56	47	35	0	0	0	0	0	0	0	64.42	0	0	13
2014	9	10	10	6	47	36	0	0	0	0	0	0	0	64.45	0	0	13
2014	9	10	10	16	47	36	0	0	0	0	0	0	0	64.47	0	0	13
2014	9	10	10	26	47	36	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	10	10	36	47	35	0	0	0	0	0	0	0	64.53	0	0	13
2014	9	10	10	46	47	35	0	0	0	0	0	0	0	64.56	0	0	13
2014	9	10	10	56	47	35	0	0	0	0	0	0	0	64.6	0	0	12.8
2014	9	10	11	6	47	35	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	10	11	16	47	35	0	0	0	0	0	0	0	64.67	0	0	13
2014	9	10	11	26	47	35	0	0	0	0	0	0	0	64.69	0	0	13
2014	9	10	11	36	47	35	0	0	0	0	0	0	0	64.72	0	0	13
2014	9	10	11	46	47	36	0	0	0	0	0	0	0	64.76	0	0	13
2014	9	10	11	56	47	34	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	10	12	6	47	35	0	0	0	0	0	0	0	64.81	0	0	13
2014	9	10	12	16	47	35	0	0	0	0	0	0	0	64.83	0	0	12.8
2014	9	10	12	26	47	35	0	0	0	0	0	0	0	64.85	0	0	13
2014	9	10	12	36	47	35	0	0	0	0	0	0	0	64.87	0	0	13
2014	9	10	12	46	47	35	0	0	0	0	0	0	0	64.9	0	0	13
2014	9	10	12	56	47	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	10	13	6	47	35	0	0	0	0	0	0	0	64.94	0	0	12.8
2014	9	10	13	16	47	35	0	0	0	0	0	0	0	64.96	0	0	13
2014	9	10	13	26	47	35	0	0	0	0	0	0	0	64.96	0	0	13
2014	9	10	13	36	47	36	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	10	13	46	47	35	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	10	13	56	47	35	0	0	0	0	0	0	0	64.99	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	14	6	47	35	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	10	14	16	47	35	0	0	0	0	0	0	0	64.99	0	0	12.8
2014	9	10	14	26	47	35	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	10	14	36	47	35	0	0	0	0	0	0	0	64.98	0	0	12.6
2014	9	10	14	46	47	35	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	10	14	56	47	35	0	0	0	0	0	0	0	64.96	0	0	12.6
2014	9	10	15	6	47	35	0	0	0	0	0	0	0	64.94	0	0	12.8
2014	9	10	15	16	47	34	0	0	0	0	0	0	0	64.92	0	0	12.8
2014	9	10	15	26	47	36	0	0	0	0	0	0	0	64.92	0	0	12.8
2014	9	10	15	36	47	35	0	0	0	0	0	0	0	64.89	0	0	12.8
2014	9	10	15	46	47	35	0	0	0	0	0	0	0	64.87	0	0	12.8
2014	9	10	15	56	47	35	0	0	0	0	0	0	0	64.85	0	0	12.8
2014	9	10	16	6	47	35	0	0	0	0	0	0	0	64.83	0	0	12.6
2014	9	10	16	16	47	35	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	10	16	26	47	35	0	0	0	0	0	0	0	64.78	0	0	12.8
2014	9	10	16	36	47	35	0	0	0	0	0	0	0	64.76	0	0	12.8
2014	9	10	16	46	47	35	0	0	0	0	0	0	0	64.74	0	0	12.8
2014	9	10	16	56	47	34	0	0	0	0	0	0	0	64.72	0	0	12.8
2014	9	10	17	6	47	35	0	0	0	0	0	0	0	64.71	0	0	12.4
2014	9	10	17	16	47	35	0	0	0	0	0	0	0	64.69	0	0	12.2
2014	9	10	17	26	47	36	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	10	17	36	47	35	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	10	17	46	47	36	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	10	17	56	47	35	0	0	0	0	0	0	0	64.63	0	0	12
2014	9	10	18	6	47	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	10	18	16	47	35	0	0	0	0	0	0	0	64.62	0	0	11.6
2014	9	10	18	26	47	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	10	18	36	47	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	10	18	46	47	34	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	10	18	56	47	36	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	6	47	35	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	16	47	36	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	26	47	35	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	36	47	36	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	46	47	34	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	10	19	56	47	35	0	0	0	0	0	0	0	64.63	0	0	12
2014	9	10	20	6	47	35	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	10	20	16	47	35	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	10	20	26	47	35	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	10	20	36	47	35	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	10	20	46	47	35	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	10	20	56	47	35	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	10	21	6	47	35	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	10	21	16	47	35	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	10	21	26	47	35	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	10	21	36	47	34	0	0	0	0	0	0	0	64.69	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	21	46	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	21	56	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	22	6	47	34	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	22	16	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	22	26	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	22	36	47	35	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	10	22	46	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	22	56	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	23	6	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	23	16	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	23	26	47	35	0	0	0	0	0	0	0	64.71	0	0	11.6
2014	9	10	23	36	47	35	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	10	23	46	47	35	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	10	23	56	47	35	0	0	0	0	0	0	0	64.67	0	0	11.6
2014	9	11	0	6	47	35	0	0	0	0	0	0	0	64.65	0	0	11.6
2014	9	11	0	16	47	35	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	11	0	26	47	35	0	0	0	0	0	0	0	64.62	0	0	11.6
2014	9	11	0	36	47	35	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	11	0	46	47	34	0	0	0	0	0	0	0	64.58	0	0	11.6
2014	9	11	0	56	47	35	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	11	1	6	47	35	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	11	1	16	47	35	0	0	0	0	0	0	0	64.51	0	0	11.4
2014	9	11	1	26	47	35	0	0	0	0	0	0	0	64.49	0	0	11.4
2014	9	11	1	36	47	35	0	0	0	0	0	0	0	64.45	0	0	11.4
2014	9	11	1	46	47	35	0	0	0	0	0	0	0	64.42	0	0	11.4
2014	9	11	1	56	47	34	0	0	0	0	0	0	0	64.4	0	0	11.4
2014	9	11	2	6	47	35	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	11	2	16	47	36	0	0	0	0	0	0	0	64.33	0	0	11.6
2014	9	11	2	26	47	36	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	11	2	36	47	35	0	0	0	0	0	0	0	64.26	0	0	11.4
2014	9	11	2	46	47	35	0	0	0	0	0	0	0	64.22	0	0	11.4
2014	9	11	2	56	47	35	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	11	3	6	47	35	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	11	3	16	47	35	0	0	0	0	0	0	0	64.09	0	0	11.6
2014	9	11	3	26	47	35	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	11	3	36	47	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	11	3	46	47	35	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	11	3	56	47	35	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	11	4	6	47	35	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	11	4	16	47	36	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	11	4	26	47	35	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	11	4	36	47	35	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	11	4	46	47	35	0	0	0	0	0	0	0	63.73	0	0	11.4
2014	9	11	4	56	47	35	0	0	0	0	0	0	0	63.7	0	0	11.4
2014	9	11	5	6	47	35	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	11	5	16	47	35	0	0	0	0	0	0	0	63.63	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	5	26	47	35	0	0	0	0	0	0	0	63.57	0	0	11.4
2014	9	11	5	36	47	35	0	0	0	0	0	0	0	63.54	0	0	11.4
2014	9	11	5	46	47	35	0	0	0	0	0	0	0	63.48	0	0	11.4
2014	9	11	5	56	47	35	0	0	0	0	0	0	0	63.43	0	0	11.4
2014	9	11	6	6	47	35	0	0	0	0	0	0	0	63.41	0	0	11.4
2014	9	11	6	16	47	36	0	0	0	0	0	0	0	63.36	0	0	11.4
2014	9	11	6	26	47	35	0	0	0	0	0	0	0	63.32	0	0	11.4
2014	9	11	6	36	47	35	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	11	6	46	47	36	0	0	0	0	0	0	0	63.27	0	0	11.4
2014	9	11	6	56	47	35	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	11	7	6	47	35	0	0	0	0	0	0	0	63.19	0	0	11.4
2014	9	11	7	16	47	36	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	11	7	26	47	35	0	0	0	0	0	0	0	63.12	0	0	11.6
2014	9	11	7	36	47	35	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	11	7	46	47	36	0	0	0	0	0	0	0	63.05	0	0	12
2014	9	11	7	56	47	35	0	0	0	0	0	0	0	63.05	0	0	12.4
2014	9	11	8	6	47	35	0	0	0	0	0	0	0	63.05	0	0	12.4
2014	9	11	8	16	47	36	0	0	0	0	0	0	0	63.05	0	0	12.6
2014	9	11	8	26	47	35	0	0	0	0	0	0	0	63.05	0	0	12.8
2014	9	11	8	36	47	35	0	0	0	0	0	0	0	63.05	0	0	12.8
2014	9	11	8	46	47	35	0	0	0	0	0	0	0	63.05	0	0	12.8
2014	9	11	8	56	47	36	0	0	0	0	0	0	0	63.07	0	0	13
2014	9	11	9	6	47	35	0	0	0	0	0	0	0	63.07	0	0	13
2014	9	11	9	16	47	35	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	11	9	26	47	36	0	0	0	0	0	0	0	63.12	0	0	13
2014	9	11	9	36	47	36	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	11	9	46	47	35	0	0	0	0	0	0	0	63.18	0	0	13
2014	9	11	9	56	47	35	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	11	10	6	47	35	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	11	10	16	47	35	0	0	0	0	0	0	0	63.27	0	0	13
2014	9	11	10	26	47	36	0	0	0	0	0	0	0	63.28	0	0	13
2014	9	11	10	36	47	35	0	0	0	0	0	0	0	63.32	0	0	13
2014	9	11	10	46	47	36	0	0	0	0	0	0	0	63.37	0	0	13
2014	9	11	10	56	47	35	0	0	0	0	0	0	0	63.41	0	0	12.8
2014	9	11	11	6	47	35	0	0	0	0	0	0	0	63.43	0	0	13
2014	9	11	11	16	47	35	0	0	0	0	0	0	0	63.45	0	0	13
2014	9	11	11	26	47	35	0	0	0	0	0	0	0	63.46	0	0	13
2014	9	11	11	36	47	35	0	0	0	0	0	0	0	63.5	0	0	12.8
2014	9	11	11	46	47	35	0	0	0	0	0	0	0	63.54	0	0	12.8
2014	9	11	11	56	47	36	0	0	0	0	0	0	0	63.55	0	0	12.8
2014	9	11	12	6	47	35	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	11	12	16	47	36	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	11	12	26	47	36	0	0	0	0	0	0	0	63.61	0	0	12.8
2014	9	11	12	36	47	35	0	0	0	0	0	0	0	63.63	0	0	12.8
2014	9	11	12	46	47	35	0	0	0	0	0	0	0	63.64	0	0	12.8
2014	9	11	12	56	47	35	0	0	0	0	0	0	0	63.66	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	13	6	47	36	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	11	13	16	47	35	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	11	13	26	47	35	0	0	0	0	0	0	0	63.7	0	0	12.8
2014	9	11	13	36	47	36	0	0	0	0	0	0	0	63.7	0	0	12.8
2014	9	11	13	46	47	35	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	11	13	56	47	35	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	11	14	6	47	35	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	11	14	16	47	36	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	11	14	26	47	35	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	11	14	36	47	35	0	0	0	0	0	0	0	63.64	0	0	12.8
2014	9	11	14	46	47	35	0	0	0	0	0	0	0	63.63	0	0	12.8
2014	9	11	14	56	47	35	0	0	0	0	0	0	0	63.61	0	0	12.6
2014	9	11	15	6	47	35	0	0	0	0	0	0	0	63.59	0	0	12.6
2014	9	11	15	16	47	36	0	0	0	0	0	0	0	63.57	0	0	12.6
2014	9	11	15	26	47	35	0	0	0	0	0	0	0	63.55	0	0	12.6
2014	9	11	15	36	47	35	0	0	0	0	0	0	0	63.54	0	0	12.6
2014	9	11	15	46	47	35	0	0	0	0	0	0	0	63.5	0	0	12.6
2014	9	11	15	56	47	35	0	0	0	0	0	0	0	63.48	0	0	12.6
2014	9	11	16	6	47	36	0	0	0	0	0	0	0	63.46	0	0	12.6
2014	9	11	16	16	47	36	0	0	0	0	0	0	0	63.45	0	0	12.6
2014	9	11	16	26	47	36	0	0	0	0	0	0	0	63.41	0	0	12.6
2014	9	11	16	36	47	35	0	0	0	0	0	0	0	63.41	0	0	12.6
2014	9	11	16	46	47	35	0	0	0	0	0	0	0	63.39	0	0	12.4
2014	9	11	16	56	47	35	0	0	0	0	0	0	0	63.37	0	0	12.4
2014	9	11	17	6	47	35	0	0	0	0	0	0	0	63.36	0	0	12.4
2014	9	11	17	16	47	35	0	0	0	0	0	0	0	63.36	0	0	11.8
2014	9	11	17	26	47	35	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	11	17	36	47	36	0	0	0	0	0	0	0	63.34	0	0	11.4
2014	9	11	17	46	47	35	0	0	0	0	0	0	0	63.34	0	0	11.8
2014	9	11	17	56	47	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	11	18	6	47	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	11	18	16	47	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	11	18	26	47	35	0	0	0	0	0	0	0	63.34	0	0	11.8
2014	9	11	18	36	47	34	0	0	0	0	0	0	0	63.36	0	0	11.8
2014	9	11	18	46	47	36	0	0	0	0	0	0	0	63.36	0	0	11.8
2014	9	11	18	56	47	35	0	0	0	0	0	0	0	63.37	0	0	11.8
2014	9	11	19	6	47	35	0	0	0	0	0	0	0	63.37	0	0	11.6
2014	9	11	19	16	47	35	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	11	19	26	47	35	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	11	19	36	47	35	0	0	0	0	0	0	0	63.41	0	0	11.8
2014	9	11	19	46	47	36	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	11	19	56	47	35	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	11	20	6	47	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	11	20	16	47	35	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	11	20	26	47	35	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	11	20	36	47	34	0	0	0	0	0	0	0	63.5	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	20	46	47	35	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	11	20	56	47	35	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	11	21	6	47	35	0	0	0	0	0	0	0	63.54	0	0	11.8
2014	9	11	21	16	47	35	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	11	21	26	47	36	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	11	21	36	47	35	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	11	21	46	47	35	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	11	21	56	47	36	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	11	22	6	47	35	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	11	22	16	47	35	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	11	22	26	47	36	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	11	22	36	47	35	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	11	22	46	47	35	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	11	22	56	47	36	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	11	23	6	47	35	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	11	23	16	47	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	11	23	26	47	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	11	23	36	47	35	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	11	23	46	47	35	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	11	23	56	47	36	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	12	0	6	47	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	12	0	16	47	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	12	0	26	47	36	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	12	0	36	47	36	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	12	0	46	47	35	0	0	0	0	0	0	0	63.64	0	0	11.4
2014	9	12	0	56	47	36	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	12	1	6	47	36	0	0	0	0	0	0	0	63.61	0	0	11.4
2014	9	12	1	16	47	35	0	0	0	0	0	0	0	63.59	0	0	11.4
2014	9	12	1	26	47	35	0	0	0	0	0	0	0	63.59	0	0	11.4
2014	9	12	1	36	47	35	0	0	0	0	0	0	0	63.59	0	0	11.4
2014	9	12	1	46	47	35	0	0	0	0	0	0	0	63.57	0	0	11.4
2014	9	12	1	56	47	35	0	0	0	0	0	0	0	63.55	0	0	11.4
2014	9	12	2	6	47	35	0	0	0	0	0	0	0	63.54	0	0	11.4
2014	9	12	2	16	47	35	0	0	0	0	0	0	0	63.52	0	0	11.4
2014	9	12	2	26	47	35	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	12	2	36	47	36	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	12	2	46	47	35	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	12	2	56	47	35	0	0	0	0	0	0	0	63.43	0	0	11.4
2014	9	12	3	6	47	35	0	0	0	0	0	0	0	63.39	0	0	11.4
2014	9	12	3	16	47	35	0	0	0	0	0	0	0	63.37	0	0	11.4
2014	9	12	3	26	47	35	0	0	0	0	0	0	0	63.34	0	0	11.6
2014	9	12	3	36	47	35	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	12	3	46	47	35	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	12	3	56	47	35	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	12	4	6	47	35	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	12	4	16	47	36	0	0	0	0	0	0	0	63.21	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	4	26	47	36	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	12	4	36	47	35	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	12	4	46	47	35	0	0	0	0	0	0	0	63.14	0	0	11.6
2014	9	12	4	56	47	35	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	12	5	6	47	36	0	0	0	0	0	0	0	63.07	0	0	11.6
2014	9	12	5	16	47	35	0	0	0	0	0	0	0	63.05	0	0	11.6
2014	9	12	5	26	47	35	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	12	5	36	47	35	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	12	5	46	47	36	0	0	0	0	0	0	0	62.98	0	0	11.6
2014	9	12	5	56	47	35	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	12	6	6	47	35	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	12	6	16	47	36	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	12	6	26	47	35	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	12	6	36	47	35	0	0	0	0	0	0	0	62.85	0	0	11.6
2014	9	12	6	46	47	35	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	12	6	56	47	35	0	0	0	0	0	0	0	62.8	0	0	11.6
2014	9	12	7	6	47	35	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	12	7	16	47	35	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	12	7	26	47	35	0	0	0	0	0	0	0	62.74	0	0	11.8
2014	9	12	7	36	47	35	0	0	0	0	0	0	0	62.73	0	0	12
2014	9	12	7	46	47	36	0	0	0	0	0	0	0	62.69	0	0	12.2
2014	9	12	7	56	47	35	0	0	0	0	0	0	0	62.71	0	0	12.4
2014	9	12	8	6	47	35	0	0	0	0	0	0	0	62.73	0	0	12.6
2014	9	12	8	16	47	35	0	0	0	0	0	0	0	62.74	0	0	12.8
2014	9	12	8	26	47	35	0	0	0	0	0	0	0	62.74	0	0	12.8
2014	9	12	8	36	47	35	0	0	0	0	0	0	0	62.76	0	0	12.8
2014	9	12	8	46	47	35	0	0	0	0	0	0	0	62.76	0	0	13
2014	9	12	8	56	47	35	0	0	0	0	0	0	0	62.8	0	0	13
2014	9	12	9	6	47	35	0	0	0	0	0	0	0	62.82	0	0	13.2
2014	9	12	9	16	47	35	0	0	0	0	0	0	0	62.85	0	0	13.2
2014	9	12	9	26	47	36	0	0	0	0	0	0	0	62.89	0	0	13.2
2014	9	12	9	36	47	35	0	0	0	0	0	0	0	62.92	0	0	13.2
2014	9	12	9	46	47	35	0	0	0	0	0	0	0	62.96	0	0	13.2
2014	9	12	9	56	47	35	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	12	10	6	47	35	0	0	0	0	0	0	0	63.03	0	0	13.2
2014	9	12	10	16	47	35	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	12	10	26	47	36	0	0	0	0	0	0	0	63.12	0	0	13
2014	9	12	10	36	47	35	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	12	10	46	47	36	0	0	0	0	0	0	0	63.18	0	0	13
2014	9	12	10	56	47	35	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	12	11	6	47	35	0	0	0	0	0	0	0	63.25	0	0	13
2014	9	12	11	16	47	35	0	0	0	0	0	0	0	63.28	0	0	13
2014	9	12	11	26	47	35	0	0	0	0	0	0	0	63.34	0	0	13
2014	9	12	11	36	47	35	0	0	0	0	0	0	0	63.36	0	0	13
2014	9	12	11	46	47	35	0	0	0	0	0	0	0	63.41	0	0	13
2014	9	12	11	56	47	36	0	0	0	0	0	0	0	63.43	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	12	6	47	35	0	0	0	0	0	0	0	63.46	0	0	13
2014	9	12	12	16	47	35	0	0	0	0	0	0	0	63.5	0	0	13
2014	9	12	12	26	47	35	0	0	0	0	0	0	0	63.54	0	0	13
2014	9	12	12	36	47	35	0	0	0	0	0	0	0	63.55	0	0	13
2014	9	12	12	46	47	35	0	0	0	0	0	0	0	63.59	0	0	13
2014	9	12	12	56	47	36	0	0	0	0	0	0	0	63.59	0	0	13
2014	9	12	13	6	47	35	0	0	0	0	0	0	0	63.64	0	0	13
2014	9	12	13	16	47	35	0	0	0	0	0	0	0	63.66	0	0	13
2014	9	12	13	26	47	35	0	0	0	0	0	0	0	63.68	0	0	13
2014	9	12	13	36	47	36	0	0	0	0	0	0	0	63.68	0	0	13
2014	9	12	13	46	47	35	0	0	0	0	0	0	0	63.68	0	0	13
2014	9	12	13	56	47	35	0	0	0	0	0	0	0	63.7	0	0	13
2014	9	12	14	6	47	36	0	0	0	0	0	0	0	63.72	0	0	13
2014	9	12	14	16	47	35	0	0	0	0	0	0	0	63.72	0	0	13
2014	9	12	14	26	47	35	0	0	0	0	0	0	0	63.7	0	0	13
2014	9	12	14	36	47	35	0	0	0	0	0	0	0	63.73	0	0	13
2014	9	12	14	46	47	35	0	0	0	0	0	0	0	63.72	0	0	13
2014	9	12	14	56	47	35	0	0	0	0	0	0	0	63.72	0	0	13
2014	9	12	15	6	47	35	0	0	0	0	0	0	0	63.72	0	0	12.8
2014	9	12	15	16	47	35	0	0	0	0	0	0	0	63.7	0	0	12.8
2014	9	12	15	26	47	35	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	12	15	36	47	35	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	12	15	46	47	35	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	12	15	56	47	35	0	0	0	0	0	0	0	63.64	0	0	12.8
2014	9	12	16	6	47	36	0	0	0	0	0	0	0	63.64	0	0	12.8
2014	9	12	16	16	47	35	0	0	0	0	0	0	0	63.63	0	0	12.8
2014	9	12	16	26	47	36	0	0	0	0	0	0	0	63.61	0	0	12.8
2014	9	12	16	36	47	35	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	12	16	46	47	36	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	12	16	56	47	35	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	12	17	6	47	36	0	0	0	0	0	0	0	63.57	0	0	12.6
2014	9	12	17	16	47	35	0	0	0	0	0	0	0	63.59	0	0	12.2
2014	9	12	17	26	47	35	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	17	36	47	35	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	17	46	47	35	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	17	56	47	35	0	0	0	0	0	0	0	63.55	0	0	12
2014	9	12	18	6	47	36	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	18	16	47	35	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	18	26	47	36	0	0	0	0	0	0	0	63.57	0	0	12
2014	9	12	18	36	47	36	0	0	0	0	0	0	0	63.59	0	0	12
2014	9	12	18	46	47	36	0	0	0	0	0	0	0	63.63	0	0	12
2014	9	12	18	56	47	35	0	0	0	0	0	0	0	63.64	0	0	12
2014	9	12	19	6	47	35	0	0	0	0	0	0	0	63.66	0	0	12
2014	9	12	19	16	47	36	0	0	0	0	0	0	0	63.68	0	0	12
2014	9	12	19	26	47	35	0	0	0	0	0	0	0	63.7	0	0	12
2014	9	12	19	36	47	35	0	0	0	0	0	0	0	63.72	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	19	46	47	35	0	0	0	0	0	0	0	63.73	0	0	12
2014	9	12	19	56	47	34	0	0	0	0	0	0	0	63.75	0	0	12
2014	9	12	20	6	47	35	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	12	20	16	47	34	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	12	20	26	47	35	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	12	20	36	47	35	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	12	20	46	47	35	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	12	20	56	47	35	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	12	21	6	47	35	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	12	21	16	47	35	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	12	21	26	47	36	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	12	21	36	47	35	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	12	21	46	47	35	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	12	21	56	47	36	0	0	0	0	0	0	0	64	0	0	11.6
2014	9	12	22	6	47	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	12	22	16	47	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	12	22	26	47	35	0	0	0	0	0	0	0	64.04	0	0	11.4
2014	9	12	22	36	47	35	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	12	22	46	47	35	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	12	22	56	47	36	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	12	23	6	47	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	12	23	16	47	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	12	23	26	47	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	12	23	36	47	35	0	0	0	0	0	0	0	64.08	0	0	11.4
2014	9	12	23	46	47	35	0	0	0	0	0	0	0	64.09	0	0	11.6
2014	9	12	23	56	47	36	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	13	0	6	47	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	13	0	16	47	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	13	0	26	47	34	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	13	0	36	47	35	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	13	0	46	47	35	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	13	0	56	47	35	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	13	1	6	47	35	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	13	1	16	47	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	13	1	26	47	35	0	0	0	0	0	0	0	64	0	0	11.6
2014	9	13	1	36	47	35	0	0	0	0	0	0	0	64	0	0	11.4
2014	9	13	1	46	47	35	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	13	1	56	47	36	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	13	2	6	47	35	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	13	2	16	47	35	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	13	2	26	47	35	0	0	0	0	0	0	0	63.91	0	0	11.8
2014	9	13	2	36	47	35	0	0	0	0	0	0	0	63.9	0	0	11.8
2014	9	13	2	46	47	35	0	0	0	0	0	0	0	63.88	0	0	11.8
2014	9	13	2	56	47	36	0	0	0	0	0	0	0	63.86	0	0	11.8
2014	9	13	3	6	47	36	0	0	0	0	0	0	0	63.84	0	0	11.8
2014	9	13	3	16	47	36	0	0	0	0	0	0	0	63.82	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	3	26	47	35	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	13	3	36	47	35	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	13	3	46	47	35	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	13	3	56	47	35	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	13	4	6	47	35	0	0	0	0	0	0	0	63.7	0	0	11.4
2014	9	13	4	16	47	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	13	4	26	47	35	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	13	4	36	47	35	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	13	4	46	47	35	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	13	4	56	47	35	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	13	5	6	47	35	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	13	5	16	47	35	0	0	0	0	0	0	0	63.54	0	0	11.4
2014	9	13	5	26	47	34	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	13	5	36	47	35	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	13	5	46	47	36	0	0	0	0	0	0	0	63.46	0	0	11.4
2014	9	13	5	56	47	36	0	0	0	0	0	0	0	63.45	0	0	11.4
2014	9	13	6	6	47	35	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	13	6	16	47	35	0	0	0	0	0	0	0	63.39	0	0	11.4
2014	9	13	6	26	47	35	0	0	0	0	0	0	0	63.37	0	0	11.6
2014	9	13	6	36	47	35	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	13	6	46	47	36	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	13	6	56	47	35	0	0	0	0	0	0	0	63.3	0	0	11.4
2014	9	13	7	6	47	36	0	0	0	0	0	0	0	63.28	0	0	11.4
2014	9	13	7	16	47	35	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	13	7	26	47	35	0	0	0	0	0	0	0	63.25	0	0	12
2014	9	13	7	36	47	36	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	13	7	46	47	35	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	13	7	56	47	35	0	0	0	0	0	0	0	63.23	0	0	12.2
2014	9	13	8	6	47	35	0	0	0	0	0	0	0	63.25	0	0	12.4
2014	9	13	8	16	47	35	0	0	0	0	0	0	0	63.27	0	0	12.6
2014	9	13	8	26	47	35	0	0	0	0	0	0	0	63.28	0	0	12.8
2014	9	13	8	36	47	35	0	0	0	0	0	0	0	63.28	0	0	12.6
2014	9	13	8	46	47	35	0	0	0	0	0	0	0	63.3	0	0	12.8
2014	9	13	8	56	47	36	0	0	0	0	0	0	0	63.34	0	0	13
2014	9	13	9	6	47	36	0	0	0	0	0	0	0	63.37	0	0	13
2014	9	13	9	16	47	35	0	0	0	0	0	0	0	63.41	0	0	13
2014	9	13	9	26	47	35	0	0	0	0	0	0	0	63.45	0	0	13
2014	9	13	9	36	47	35	0	0	0	0	0	0	0	63.48	0	0	13.2
2014	9	13	9	46	47	35	0	0	0	0	0	0	0	63.52	0	0	13
2014	9	13	9	56	47	35	0	0	0	0	0	0	0	63.57	0	0	13
2014	9	13	10	6	47	36	0	0	0	0	0	0	0	63.61	0	0	13
2014	9	13	10	16	47	36	0	0	0	0	0	0	0	63.64	0	0	13
2014	9	13	10	26	47	36	0	0	0	0	0	0	0	63.7	0	0	13
2014	9	13	10	36	47	35	0	0	0	0	0	0	0	63.73	0	0	12.8
2014	9	13	10	46	47	35	0	0	0	0	0	0	0	63.79	0	0	12.6
2014	9	13	10	56	47	35	0	0	0	0	0	0	0	63.82	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	11	6	47	35	0	0	0	0	0	0	0	63.84	0	0	12.8
2014	9	13	11	16	47	35	0	0	0	0	0	0	0	63.86	0	0	12.8
2014	9	13	11	26	47	35	0	0	0	0	0	0	0	63.91	0	0	12.8
2014	9	13	11	36	47	35	0	0	0	0	0	0	0	63.91	0	0	12.8
2014	9	13	11	46	47	35	0	0	0	0	0	0	0	63.97	0	0	12.8
2014	9	13	11	56	47	35	0	0	0	0	0	0	0	64.02	0	0	12.8
2014	9	13	12	6	47	35	0	0	0	0	0	0	0	64.04	0	0	12.8
2014	9	13	12	16	47	36	0	0	0	0	0	0	0	64.09	0	0	12.8
2014	9	13	12	26	47	36	0	0	0	0	0	0	0	64.11	0	0	12.8
2014	9	13	12	36	47	36	0	0	0	0	0	0	0	64.13	0	0	12.8
2014	9	13	12	46	47	36	0	0	0	0	0	0	0	64.15	0	0	12.8
2014	9	13	12	56	47	36	0	0	0	0	0	0	0	64.18	0	0	12.8
2014	9	13	13	6	47	35	0	0	0	0	0	0	0	64.15	0	0	12.8
2014	9	13	13	16	47	35	0	0	0	0	0	0	0	64.08	0	0	12.8
2014	9	13	13	26	47	36	0	0	0	0	0	0	0	63.97	0	0	12.8
2014	9	13	13	36	47	35	0	0	0	0	0	0	0	64.18	0	0	12.8
2014	9	13	13	46	47	35	0	0	0	0	0	0	0	64.22	0	0	12.8
2014	9	13	13	56	47	35	0	0	0	0	0	0	0	64.22	0	0	12.8
2014	9	13	14	6	47	35	0	0	0	0	0	0	0	64.24	0	0	12.8
2014	9	13	14	16	47	35	0	0	0	0	0	0	0	64.2	0	0	12.8
2014	9	13	14	26	47	35	0	0	0	0	0	0	0	64.24	0	0	12.8
2014	9	13	14	36	47	35	0	0	0	0	0	0	0	64.24	0	0	12.8
2014	9	13	14	46	47	35	0	0	0	0	0	0	0	64.22	0	0	12.6
2014	9	13	14	56	47	36	0	0	0	0	0	0	0	64.09	0	0	12.6
2014	9	13	15	6	47	35	0	0	0	0	0	0	0	64.17	0	0	12.6
2014	9	13	15	16	47	36	0	0	0	0	0	0	0	64.18	0	0	12.6
2014	9	13	15	26	47	35	0	0	0	0	0	0	0	64.17	0	0	12.6
2014	9	13	15	36	47	35	0	0	0	0	0	0	0	64.11	0	0	12.8
2014	9	13	15	46	47	35	0	0	0	0	0	0	0	64.09	0	0	12.6
2014	9	13	15	58	29	35	0	0	0	0	0	0	0	64.06	0	0	12.8
2014	9	13	16	8	29	35	0	0	0	0	0	0	0	64.02	0	0	12.8
2014	9	13	16	18	29	35	0	0	0	0	0	0	0	64.02	0	0	12.6
2014	9	13	16	28	29	35	0	0	0	0	0	0	0	64.02	0	0	12.8
2014	9	13	16	38	29	35	0	0	0	0	0	0	0	64.02	0	0	12.4
2014	9	13	16	48	29	35	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	13	16	58	29	34	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	13	17	8	29	35	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	13	17	18	29	35	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	13	17	28	29	35	0	0	0	0	0	0	0	63.93	0	0	12
2014	9	13	17	38	29	35	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	13	17	48	29	35	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	13	17	58	29	35	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	13	18	8	29	36	0	0	0	0	0	0	0	63.99	0	0	11.8
2014	9	13	18	18	29	35	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	13	18	28	29	36	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	13	18	38	29	35	0	0	0	0	0	0	0	64	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	18	48	29	36	0	0	0	0	0	0	0	64	0	0	11.8
2014	9	13	18	58	29	35	0	0	0	0	0	0	0	64.02	0	0	12
2014	9	13	19	8	29	35	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	13	19	18	29	36	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	13	19	28	29	35	0	0	0	0	0	0	0	64.08	0	0	11.8
2014	9	13	19	38	29	35	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	13	19	48	29	36	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	13	19	58	29	35	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	13	20	8	29	35	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	13	20	18	29	35	0	0	0	0	0	0	0	64.17	0	0	11.8
2014	9	13	20	28	29	35	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	13	20	38	29	35	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	13	20	48	29	35	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	13	20	58	29	35	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	13	21	8	29	36	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	13	21	18	29	35	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	13	21	28	29	35	0	0	0	0	0	0	0	64.29	0	0	11.8
2014	9	13	21	38	29	35	0	0	0	0	0	0	0	64.31	0	0	11.8
2014	9	13	21	48	29	35	0	0	0	0	0	0	0	64.33	0	0	11.8
2014	9	13	21	58	29	35	0	0	0	0	0	0	0	64.35	0	0	11.8
2014	9	13	22	8	29	35	0	0	0	0	0	0	0	64.35	0	0	11.8
2014	9	13	22	18	29	35	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	13	22	28	29	35	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	13	22	38	29	35	0	0	0	0	0	0	0	64.38	0	0	11.6
2014	9	13	22	48	29	35	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	13	22	58	29	35	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	13	23	8	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	13	23	18	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	13	23	28	29	36	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	13	23	38	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	13	23	48	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	13	23	58	29	35	0	0	0	0	0	0	0	64.44	0	0	11.6
2014	9	14	0	8	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	14	0	18	29	34	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	14	0	28	29	35	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	14	0	38	29	36	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	14	0	48	29	35	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	14	0	58	29	35	0	0	0	0	0	0	0	64.38	0	0	11.6
2014	9	14	1	8	29	35	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	14	1	18	29	35	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	14	1	28	29	34	0	0	0	0	0	0	0	64.35	0	0	11.6
2014	9	14	1	38	29	35	0	0	0	0	0	0	0	64.35	0	0	11.6
2014	9	14	1	48	29	35	0	0	0	0	0	0	0	64.33	0	0	11.6
2014	9	14	1	58	29	35	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	14	2	8	29	35	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	14	2	18	29	34	0	0	0	0	0	0	0	64.27	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	2	28	29	36	0	0	0	0	0	0	0	64.26	0	0	11.6
2014	9	14	2	38	29	35	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	14	2	48	29	35	0	0	0	0	0	0	0	64.24	0	0	11.6
2014	9	14	2	58	29	35	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	14	3	8	29	35	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	14	3	18	29	35	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	14	3	28	29	35	0	0	0	0	0	0	0	64.17	0	0	11.8
2014	9	14	3	38	29	35	0	0	0	0	0	0	0	64.15	0	0	11.6
2014	9	14	3	48	29	35	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	14	3	58	29	35	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	14	4	8	29	35	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	14	4	18	29	36	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	14	4	28	29	34	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	14	4	38	29	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	14	4	48	29	35	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	14	4	58	29	35	0	0	0	0	0	0	0	64	0	0	11.8
2014	9	14	5	8	29	35	0	0	0	0	0	0	0	63.99	0	0	11.8
2014	9	14	5	18	29	35	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	14	5	28	29	36	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	14	5	38	29	35	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	14	5	48	29	35	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	14	5	58	29	35	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	14	6	8	29	35	0	0	0	0	0	0	0	63.86	0	0	11.4
2014	9	14	6	18	29	35	0	0	0	0	0	0	0	63.86	0	0	11.4
2014	9	14	6	28	29	35	0	0	0	0	0	0	0	63.84	0	0	11.4
2014	9	14	6	38	29	35	0	0	0	0	0	0	0	63.81	0	0	11.4
2014	9	14	6	48	29	35	0	0	0	0	0	0	0	63.79	0	0	11.4
2014	9	14	6	58	29	35	0	0	0	0	0	0	0	63.77	0	0	11.4
2014	9	14	7	8	29	35	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	14	7	18	29	35	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	14	7	28	29	35	0	0	0	0	0	0	0	63.73	0	0	11.8
2014	9	14	7	38	29	36	0	0	0	0	0	0	0	63.72	0	0	12
2014	9	14	7	48	29	35	0	0	0	0	0	0	0	63.7	0	0	12.2
2014	9	14	7	58	29	35	0	0	0	0	0	0	0	63.7	0	0	12.2
2014	9	14	8	8	29	36	0	0	0	0	0	0	0	63.72	0	0	12.4
2014	9	14	8	18	29	36	0	0	0	0	0	0	0	63.75	0	0	12.6
2014	9	14	8	28	29	35	0	0	0	0	0	0	0	63.77	0	0	12.4
2014	9	14	8	38	29	35	0	0	0	0	0	0	0	63.72	0	0	12
2014	9	14	8	48	29	35	0	0	0	0	0	0	0	63.77	0	0	12.6
2014	9	14	8	58	29	36	0	0	0	0	0	0	0	63.81	0	0	12.8
2014	9	14	9	8	29	35	0	0	0	0	0	0	0	63.86	0	0	13
2014	9	14	9	18	29	35	0	0	0	0	0	0	0	63.88	0	0	13
2014	9	14	9	28	29	35	0	0	0	0	0	0	0	63.93	0	0	13
2014	9	14	9	38	29	35	0	0	0	0	0	0	0	63.95	0	0	12.8
2014	9	14	9	48	29	35	0	0	0	0	0	0	0	64.02	0	0	13
2014	9	14	9	58	29	35	0	0	0	0	0	0	0	64.09	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	10	8	29	35	0	0	0	0	0	0	0	64.06	0	0	13
2014	9	14	10	18	29	35	0	0	0	0	0	0	0	64.06	0	0	12.8
2014	9	14	10	28	29	36	0	0	0	0	0	0	0	64.17	0	0	12.8
2014	9	14	10	38	29	35	0	0	0	0	0	0	0	64.2	0	0	12.8
2014	9	14	10	48	29	35	0	0	0	0	0	0	0	64.27	0	0	12.8
2014	9	14	10	58	29	36	0	0	0	0	0	0	0	64.27	0	0	12.8
2014	9	14	11	8	29	35	0	0	0	0	0	0	0	64.33	0	0	12.8
2014	9	14	11	18	29	35	0	0	0	0	0	0	0	64.38	0	0	12.8
2014	9	14	11	28	29	35	0	0	0	0	0	0	0	64.42	0	0	12.8
2014	9	14	11	38	29	35	0	0	0	0	0	0	0	64.4	0	0	12.8
2014	9	14	11	48	29	36	0	0	0	0	0	0	0	64.45	0	0	12.8
2014	9	14	11	58	29	35	0	0	0	0	0	0	0	64.51	0	0	12.6
2014	9	14	12	8	29	35	0	0	0	0	0	0	0	64.29	0	0	12.4
2014	9	14	12	18	29	35	0	0	0	0	0	0	0	64.26	0	0	12.4
2014	9	14	12	28	29	35	0	0	0	0	0	0	0	64.22	0	0	12.2
2014	9	14	12	38	29	35	0	0	0	0	0	0	0	64.22	0	0	12.2
2014	9	14	12	48	29	35	0	0	0	0	0	0	0	64.24	0	0	12.6
2014	9	14	12	58	29	35	0	0	0	0	0	0	0	64.45	0	0	13
2014	9	14	13	8	29	35	0	0	0	0	0	0	0	64.6	0	0	13
2014	9	14	13	18	29	35	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	14	13	28	29	35	0	0	0	0	0	0	0	64.65	0	0	12.8
2014	9	14	13	38	29	35	0	0	0	0	0	0	0	64.63	0	0	12.4
2014	9	14	13	48	29	35	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	14	13	58	29	35	0	0	0	0	0	0	0	64.67	0	0	13
2014	9	14	14	8	29	35	0	0	0	0	0	0	0	64.71	0	0	12.8
2014	9	14	14	18	29	35	0	0	0	0	0	0	0	64.69	0	0	12.8
2014	9	14	14	28	29	36	0	0	0	0	0	0	0	64.69	0	0	12.8
2014	9	14	14	38	29	36	0	0	0	0	0	0	0	64.69	0	0	12.8
2014	9	14	14	48	29	35	0	0	0	0	0	0	0	64.65	0	0	12.8
2014	9	14	14	58	29	35	0	0	0	0	0	0	0	64.65	0	0	12.8
2014	9	14	15	8	29	35	0	0	0	0	0	0	0	64.63	0	0	12.6
2014	9	14	15	18	29	35	0	0	0	0	0	0	0	64.6	0	0	12.6
2014	9	14	15	28	29	35	0	0	0	0	0	0	0	64.63	0	0	12.6
2014	9	14	15	38	29	36	0	0	0	0	0	0	0	64.63	0	0	12.6
2014	9	14	15	48	29	36	0	0	0	0	0	0	0	64.62	0	0	12.6
2014	9	14	15	58	29	35	0	0	0	0	0	0	0	64.63	0	0	12.8
2014	9	14	16	8	29	35	0	0	0	0	0	0	0	64.58	0	0	12.8
2014	9	14	16	18	29	35	0	0	0	0	0	0	0	64.58	0	0	12.8
2014	9	14	16	28	29	35	0	0	0	0	0	0	0	64.58	0	0	12.8
2014	9	14	16	38	29	35	0	0	0	0	0	0	0	64.54	0	0	12
2014	9	14	16	48	29	34	0	0	0	0	0	0	0	64.51	0	0	12
2014	9	14	16	58	29	35	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	14	17	8	29	35	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	14	17	18	29	35	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	14	17	28	29	35	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	14	17	38	29	35	0	0	0	0	0	0	0	64.49	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	17	48	29	36	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	14	17	58	29	35	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	14	18	8	29	35	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	14	18	18	29	35	0	0	0	0	0	0	0	64.54	0	0	12
2014	9	14	18	28	29	35	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	14	18	38	29	36	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	14	18	48	29	35	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	14	18	58	29	35	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	14	19	8	29	35	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	14	19	18	29	35	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	14	19	28	29	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	14	19	38	29	35	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	14	19	48	29	35	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	14	19	58	29	36	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	14	20	8	29	35	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	14	20	18	29	36	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	14	20	28	29	35	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	14	20	38	29	35	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	14	20	48	29	35	0	0	0	0	0	0	0	64.72	0	0	11.6
2014	9	14	20	58	29	36	0	0	0	0	0	0	0	64.74	0	0	11.6
2014	9	14	21	8	29	35	0	0	0	0	0	0	0	64.76	0	0	11.6
2014	9	14	21	18	29	35	0	0	0	0	0	0	0	64.78	0	0	11.6
2014	9	14	21	28	29	35	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	14	21	38	29	35	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	14	21	48	29	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	14	21	58	29	35	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	14	22	8	29	35	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	14	22	18	29	35	0	0	0	0	0	0	0	64.85	0	0	11.8
2014	9	14	22	28	29	35	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	14	22	38	29	35	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	14	22	48	29	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	14	22	58	29	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	14	23	8	29	34	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	14	23	18	29	36	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	14	23	28	29	34	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	14	23	38	29	35	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	14	23	48	29	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	14	23	58	29	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	15	0	8	29	35	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	15	0	18	29	35	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	15	0	28	29	34	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	15	0	38	29	35	0	0	0	0	0	0	0	64.9	0	0	11.4
2014	9	15	0	48	29	35	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	15	0	58	29	34	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	15	1	8	29	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	15	1	18	29	35	0	0	0	0	0	0	0	64.85	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	1	28	29	35	0	0	0	0	0	0	0	64.85	0	0	11.8
2014	9	15	1	38	29	35	0	0	0	0	0	0	0	64.85	0	0	11.8
2014	9	15	1	48	29	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	15	1	58	29	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	15	2	8	29	35	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	15	2	18	29	35	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	15	2	28	29	36	0	0	0	0	0	0	0	64.76	0	0	11.6
2014	9	15	2	38	29	35	0	0	0	0	0	0	0	64.74	0	0	11.6
2014	9	15	2	48	29	35	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	15	2	58	29	35	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	15	3	8	29	35	0	0	0	0	0	0	0	64.67	0	0	11.6
2014	9	15	3	18	29	35	0	0	0	0	0	0	0	64.65	0	0	11.6
2014	9	15	3	28	29	35	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	15	3	38	29	35	0	0	0	0	0	0	0	64.62	0	0	11.6
2014	9	15	3	48	29	35	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	15	3	58	29	35	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	15	4	8	29	35	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	15	4	18	29	35	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	15	4	28	29	35	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	15	4	38	29	36	0	0	0	0	0	0	0	64.49	0	0	11.6
2014	9	15	4	48	55	35	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	15	4	58	55	34	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	15	5	8	55	36	0	0	0	0	0	0	0	64.44	0	0	11.8
2014	9	15	5	18	55	35	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	15	5	28	55	34	0	0	0	0	0	0	0	64.38	0	0	11.8
2014	9	15	5	38	55	35	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	15	5	48	55	35	0	0	0	0	0	0	0	64.35	0	0	11.8
2014	9	15	5	58	55	35	0	0	0	0	0	0	0	64.33	0	0	11.8
2014	9	15	6	8	55	35	0	0	0	0	0	0	0	64.31	0	0	11.8
2014	9	15	6	18	55	35	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	15	6	28	55	35	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	15	6	38	55	35	0	0	0	0	0	0	0	64.24	0	0	11.6
2014	9	15	6	48	55	36	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	15	6	58	55	35	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	15	7	8	55	35	0	0	0	0	0	0	0	64.17	0	0	11.8
2014	9	15	7	18	55	36	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	15	7	28	55	35	0	0	0	0	0	0	0	64.13	0	0	12
2014	9	15	7	38	55	36	0	0	0	0	0	0	0	64.11	0	0	12.2
2014	9	15	7	48	55	35	0	0	0	0	0	0	0	64.09	0	0	12.4
2014	9	15	7	58	55	36	0	0	0	0	0	0	0	64.11	0	0	12.6
2014	9	15	8	8	55	35	0	0	0	0	0	0	0	64.11	0	0	12.8
2014	9	15	8	18	55	35	0	0	0	0	0	0	0	64.15	0	0	12.8
2014	9	15	8	28	55	35	0	0	0	0	0	0	0	64.15	0	0	12.8
2014	9	15	8	38	55	35	0	0	0	0	0	0	0	64.15	0	0	13
2014	9	15	8	48	55	35	0	0	0	0	0	0	0	64.18	0	0	13
2014	9	15	8	58	55	34	0	0	0	0	0	0	0	64.22	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	9	8	55	35	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	15	9	18	55	35	0	0	0	0	0	0	0	64.26	0	0	13.2
2014	9	15	9	28	55	35	0	0	0	0	0	0	0	64.29	0	0	13.2
2014	9	15	9	38	55	35	0	0	0	0	0	0	0	64.33	0	0	13.2
2014	9	15	9	48	55	34	0	0	0	0	0	0	0	64.36	0	0	13.2
2014	9	15	9	58	55	36	0	0	0	0	0	0	0	64.4	0	0	13.2
2014	9	15	10	8	55	35	0	0	0	0	0	0	0	64.44	0	0	13.2
2014	9	15	10	18	55	35	0	0	0	0	0	0	0	64.49	0	0	13
2014	9	15	10	28	55	35	0	0	0	0	0	0	0	64.53	0	0	13
2014	9	15	10	38	55	35	0	0	0	0	0	0	0	64.56	0	0	13
2014	9	15	10	48	55	35	0	0	0	0	0	0	0	64.6	0	0	13
2014	9	15	10	58	55	36	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	15	11	8	55	35	0	0	0	0	0	0	0	64.69	0	0	13
2014	9	15	11	18	55	34	0	0	0	0	0	0	0	64.72	0	0	13
2014	9	15	11	28	55	35	0	0	0	0	0	0	0	64.76	0	0	13
2014	9	15	11	38	55	35	0	0	0	0	0	0	0	64.81	0	0	13
2014	9	15	11	48	55	35	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	15	11	58	55	35	0	0	0	0	0	0	0	64.85	0	0	13
2014	9	15	12	11	2	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	15	12	21	2	36	0	0	0	0	0	0	0	64.96	0	0	13
2014	9	15	12	31	2	35	0	0	0	0	0	0	0	64.99	0	0	13
2014	9	15	12	41	2	35	0	0	0	0	0	0	0	65.01	0	0	13
2014	9	15	12	51	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	15	13	1	2	35	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	15	13	11	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	15	13	21	2	35	0	0	0	0	0	0	0	65.12	0	0	13
2014	9	15	13	31	2	35	0	0	0	0	0	0	0	65.12	0	0	13
2014	9	15	13	41	2	35	0	0	0	0	0	0	0	65.14	0	0	13
2014	9	15	13	51	2	35	0	0	0	0	0	0	0	65.14	0	0	13
2014	9	15	14	1	2	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	15	14	11	2	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	15	14	21	2	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	15	14	31	2	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	15	14	41	2	35	0	0	0	0	0	0	0	65.16	0	0	13
2014	9	15	14	51	2	34	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	15	1	2	35	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	15	11	2	35	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	15	21	2	35	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	15	31	2	36	0	0	0	0	0	0	0	65.12	0	0	13
2014	9	15	15	41	2	36	0	0	0	0	0	0	0	65.14	0	0	13
2014	9	15	15	51	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	15	16	1	2	35	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	16	11	2	34	0	0	0	0	0	0	0	65.1	0	0	13
2014	9	15	16	21	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	15	16	31	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	15	16	41	2	35	0	0	0	0	0	0	0	65.07	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	16	51	2	35	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	15	17	1	2	36	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	15	17	11	2	35	0	0	0	0	0	0	0	65.07	0	0	12.4
2014	9	15	17	21	2	35	0	0	0	0	0	0	0	65.07	0	0	12.2
2014	9	15	17	31	2	35	0	0	0	0	0	0	0	65.08	0	0	12.2
2014	9	15	17	41	2	35	0	0	0	0	0	0	0	65.07	0	0	12.2
2014	9	15	17	51	2	35	0	0	0	0	0	0	0	65.08	0	0	12.2
2014	9	15	18	1	2	35	0	0	0	0	0	0	0	65.08	0	0	12.2
2014	9	15	18	11	2	35	0	0	0	0	0	0	0	65.1	0	0	12
2014	9	15	18	21	2	34	0	0	0	0	0	0	0	65.12	0	0	12
2014	9	15	18	31	2	35	0	0	0	0	0	0	0	65.14	0	0	12
2014	9	15	18	41	2	35	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	15	18	51	2	35	0	0	0	0	0	0	0	65.16	0	0	12
2014	9	15	19	1	2	35	0	0	0	0	0	0	0	65.19	0	0	12
2014	9	15	19	11	2	35	0	0	0	0	0	0	0	65.21	0	0	12
2014	9	15	19	21	2	35	0	0	0	0	0	0	0	65.23	0	0	12
2014	9	15	19	31	2	36	0	0	0	0	0	0	0	65.25	0	0	12
2014	9	15	19	41	2	35	0	0	0	0	0	0	0	65.26	0	0	12
2014	9	15	19	51	2	35	0	0	0	0	0	0	0	65.3	0	0	12
2014	9	15	20	1	2	35	0	0	0	0	0	0	0	65.32	0	0	12
2014	9	15	20	11	2	35	0	0	0	0	0	0	0	65.34	0	0	12
2014	9	15	20	21	2	35	0	0	0	0	0	0	0	65.35	0	0	12
2014	9	15	20	31	2	35	0	0	0	0	0	0	0	65.37	0	0	12
2014	9	15	20	41	2	35	0	0	0	0	0	0	0	65.41	0	0	12
2014	9	15	20	51	2	35	0	0	0	0	0	0	0	65.43	0	0	12
2014	9	15	21	1	2	35	0	0	0	0	0	0	0	65.44	0	0	12
2014	9	15	21	11	2	35	0	0	0	0	0	0	0	65.46	0	0	12
2014	9	15	21	21	2	35	0	0	0	0	0	0	0	65.48	0	0	12
2014	9	15	21	31	2	35	0	0	0	0	0	0	0	65.5	0	0	12
2014	9	15	21	41	2	35	0	0	0	0	0	0	0	65.53	0	0	12
2014	9	15	21	51	2	35	0	0	0	0	0	0	0	65.55	0	0	12
2014	9	15	22	1	2	35	0	0	0	0	0	0	0	65.55	0	0	12
2014	9	15	22	11	2	35	0	0	0	0	0	0	0	65.59	0	0	12
2014	9	15	22	21	2	35	0	0	0	0	0	0	0	65.61	0	0	12
2014	9	15	22	31	2	35	0	0	0	0	0	0	0	65.62	0	0	12
2014	9	15	22	41	2	35	0	0	0	0	0	0	0	65.64	0	0	12
2014	9	15	22	51	2	35	0	0	0	0	0	0	0	65.66	0	0	12
2014	9	15	23	1	2	35	0	0	0	0	0	0	0	65.66	0	0	12
2014	9	15	23	11	2	35	0	0	0	0	0	0	0	65.68	0	0	12
2014	9	15	23	21	2	35	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	15	23	31	2	35	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	15	23	41	2	35	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	15	23	51	2	35	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	16	0	1	2	34	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	16	0	11	2	34	0	0	0	0	0	0	0	65.7	0	0	12
2014	9	16	0	21	2	35	0	0	0	0	0	0	0	65.7	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	0	31	2	35	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	16	0	41	2	34	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	16	0	51	2	35	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	16	1	1	2	35	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	16	1	11	2	35	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	16	1	21	2	35	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	16	1	31	2	35	0	0	0	0	0	0	0	65.66	0	0	11.8
2014	9	16	1	41	2	35	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	16	1	51	2	35	0	0	0	0	0	0	0	65.64	0	0	11.6
2014	9	16	2	1	2	35	0	0	0	0	0	0	0	65.62	0	0	11.6
2014	9	16	2	11	2	35	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	16	2	21	2	35	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	16	2	31	2	34	0	0	0	0	0	0	0	65.59	0	0	11.8
2014	9	16	2	41	2	35	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	16	2	51	2	35	0	0	0	0	0	0	0	65.55	0	0	11.8
2014	9	16	3	1	2	34	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	16	3	11	2	35	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	16	3	21	2	35	0	0	0	0	0	0	0	65.5	0	0	11.8
2014	9	16	3	31	2	35	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	9	16	3	41	2	36	0	0	0	0	0	0	0	65.44	0	0	11.8
2014	9	16	3	51	2	35	0	0	0	0	0	0	0	65.43	0	0	11.8
2014	9	16	4	1	2	35	0	0	0	0	0	0	0	65.41	0	0	11.8
2014	9	16	4	11	2	35	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	16	4	21	2	35	0	0	0	0	0	0	0	65.37	0	0	11.8
2014	9	16	4	31	2	35	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	9	16	4	41	2	35	0	0	0	0	0	0	0	65.32	0	0	11.8
2014	9	16	4	51	2	35	0	0	0	0	0	0	0	65.3	0	0	11.8
2014	9	16	5	1	2	35	0	0	0	0	0	0	0	65.28	0	0	11.8
2014	9	16	5	11	2	35	0	0	0	0	0	0	0	65.26	0	0	11.8
2014	9	16	5	21	2	35	0	0	0	0	0	0	0	65.23	0	0	11.8
2014	9	16	5	31	2	35	0	0	0	0	0	0	0	65.21	0	0	11.8
2014	9	16	5	41	2	35	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	16	5	51	2	36	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	16	6	1	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	16	6	11	2	35	0	0	0	0	0	0	0	65.12	0	0	11.8
2014	9	16	6	21	2	35	0	0	0	0	0	0	0	65.1	0	0	11.8
2014	9	16	6	31	2	35	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	16	6	41	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	16	6	51	2	35	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	16	7	1	2	35	0	0	0	0	0	0	0	65.01	0	0	11.8
2014	9	16	7	11	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	16	7	21	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	16	7	31	2	35	0	0	0	0	0	0	0	64.96	0	0	12
2014	9	16	7	41	2	35	0	0	0	0	0	0	0	64.94	0	0	12.2
2014	9	16	7	51	2	35	0	0	0	0	0	0	0	64.94	0	0	12.4
2014	9	16	8	1	2	35	0	0	0	0	0	0	0	64.94	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	8	11	2	35	0	0	0	0	0	0	0	64.96	0	0	12.6
2014	9	16	8	21	2	35	0	0	0	0	0	0	0	64.96	0	0	12.8
2014	9	16	8	31	2	35	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	16	8	41	2	35	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	16	8	51	2	34	0	0	0	0	0	0	0	65.01	0	0	13
2014	9	16	9	1	2	36	0	0	0	0	0	0	0	65.03	0	0	13
2014	9	16	9	11	2	35	0	0	0	0	0	0	0	65.05	0	0	13.2
2014	9	16	9	21	2	35	0	0	0	0	0	0	0	65.08	0	0	13.2
2014	9	16	9	31	2	35	0	0	0	0	0	0	0	65.1	0	0	13.2
2014	9	16	9	41	2	35	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	16	9	51	2	35	0	0	0	0	0	0	0	65.17	0	0	13.2
2014	9	16	10	1	2	35	0	0	0	0	0	0	0	65.19	0	0	13.2
2014	9	16	10	11	2	35	0	0	0	0	0	0	0	65.25	0	0	13
2014	9	16	10	21	2	35	0	0	0	0	0	0	0	65.28	0	0	13
2014	9	16	10	31	2	35	0	0	0	0	0	0	0	65.32	0	0	13
2014	9	16	10	41	2	35	0	0	0	0	0	0	0	65.35	0	0	13
2014	9	16	10	51	2	35	0	0	0	0	0	0	0	65.39	0	0	13
2014	9	16	11	1	2	35	0	0	0	0	0	0	0	65.43	0	0	13
2014	9	16	11	11	2	35	0	0	0	0	0	0	0	65.46	0	0	13
2014	9	16	11	21	2	35	0	0	0	0	0	0	0	65.48	0	0	13
2014	9	16	11	31	2	35	0	0	0	0	0	0	0	65.52	0	0	13
2014	9	16	11	41	2	35	0	0	0	0	0	0	0	65.55	0	0	13
2014	9	16	11	51	2	35	0	0	0	0	0	0	0	65.59	0	0	13
2014	9	16	12	1	2	35	0	0	0	0	0	0	0	65.62	0	0	13
2014	9	16	12	11	2	35	0	0	0	0	0	0	0	65.64	0	0	13
2014	9	16	12	21	2	35	0	0	0	0	0	0	0	65.68	0	0	13
2014	9	16	12	31	2	35	0	0	0	0	0	0	0	65.7	0	0	13
2014	9	16	12	41	2	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	16	12	51	2	35	0	0	0	0	0	0	0	65.75	0	0	13
2014	9	16	13	1	2	35	0	0	0	0	0	0	0	65.77	0	0	13
2014	9	16	13	11	2	35	0	0	0	0	0	0	0	65.77	0	0	13
2014	9	16	13	21	2	34	0	0	0	0	0	0	0	65.8	0	0	13
2014	9	16	13	31	2	35	0	0	0	0	0	0	0	65.8	0	0	13
2014	9	16	13	41	2	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	16	13	51	2	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	16	14	1	2	35	0	0	0	0	0	0	0	65.86	0	0	13
2014	9	16	14	11	2	35	0	0	0	0	0	0	0	65.86	0	0	13
2014	9	16	14	21	2	34	0	0	0	0	0	0	0	65.86	0	0	13
2014	9	16	14	31	2	35	0	0	0	0	0	0	0	65.86	0	0	13
2014	9	16	14	41	2	35	0	0	0	0	0	0	0	65.86	0	0	13
2014	9	16	14	51	2	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	16	15	1	2	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	16	15	11	2	35	0	0	0	0	0	0	0	65.84	0	0	13
2014	9	16	15	21	2	35	0	0	0	0	0	0	0	65.82	0	0	13
2014	9	16	15	31	2	35	0	0	0	0	0	0	0	65.82	0	0	13
2014	9	16	15	41	2	35	0	0	0	0	0	0	0	65.8	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	15	51	2	35	0	0	0	0	0	0	0	65.79	0	0	13
2014	9	16	16	1	2	35	0	0	0	0	0	0	0	65.79	0	0	13
2014	9	16	16	11	2	35	0	0	0	0	0	0	0	65.77	0	0	13
2014	9	16	16	21	2	36	0	0	0	0	0	0	0	65.75	0	0	12.8
2014	9	16	16	31	2	35	0	0	0	0	0	0	0	65.7	0	0	12.2
2014	9	16	16	41	2	35	0	0	0	0	0	0	0	65.71	0	0	13
2014	9	16	16	51	2	35	0	0	0	0	0	0	0	65.73	0	0	13
2014	9	16	17	1	2	35	0	0	0	0	0	0	0	65.73	0	0	13
2014	9	16	17	11	2	35	0	0	0	0	0	0	0	65.73	0	0	12.6
2014	9	16	17	21	2	35	0	0	0	0	0	0	0	65.73	0	0	12.4
2014	9	16	17	31	2	35	0	0	0	0	0	0	0	65.73	0	0	12.2
2014	9	16	17	41	2	35	0	0	0	0	0	0	0	65.73	0	0	12.2
2014	9	16	17	51	2	35	0	0	0	0	0	0	0	65.75	0	0	12.2
2014	9	16	18	1	2	35	0	0	0	0	0	0	0	65.75	0	0	12.2
2014	9	16	18	11	2	35	0	0	0	0	0	0	0	65.77	0	0	12
2014	9	16	18	21	2	35	0	0	0	0	0	0	0	65.79	0	0	12
2014	9	16	18	31	2	35	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	16	18	41	2	35	0	0	0	0	0	0	0	65.8	0	0	12
2014	9	16	18	51	2	35	0	0	0	0	0	0	0	65.82	0	0	12
2014	9	16	19	1	2	35	0	0	0	0	0	0	0	65.84	0	0	12
2014	9	16	19	11	2	35	0	0	0	0	0	0	0	65.88	0	0	12
2014	9	16	19	21	2	35	0	0	0	0	0	0	0	65.89	0	0	12
2014	9	16	19	31	2	34	0	0	0	0	0	0	0	65.91	0	0	11.8
2014	9	16	19	41	2	35	0	0	0	0	0	0	0	65.93	0	0	12
2014	9	16	19	51	2	35	0	0	0	0	0	0	0	65.95	0	0	12
2014	9	16	20	1	2	35	0	0	0	0	0	0	0	65.98	0	0	11.8
2014	9	16	20	11	2	35	0	0	0	0	0	0	0	66.02	0	0	12
2014	9	16	20	21	2	35	0	0	0	0	0	0	0	66.04	0	0	12
2014	9	16	20	31	2	35	0	0	0	0	0	0	0	66.06	0	0	12
2014	9	16	20	41	2	34	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	9	16	20	51	2	34	0	0	0	0	0	0	0	66.11	0	0	12
2014	9	16	21	1	2	35	0	0	0	0	0	0	0	66.15	0	0	12
2014	9	16	21	11	2	36	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	16	21	21	2	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	16	21	31	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	16	21	41	2	34	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	16	21	51	2	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	16	22	1	2	35	0	0	0	0	0	0	0	66.29	0	0	11.8
2014	9	16	22	11	2	34	0	0	0	0	0	0	0	66.31	0	0	11.8
2014	9	16	22	21	2	35	0	0	0	0	0	0	0	66.33	0	0	11.8
2014	9	16	22	31	2	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	16	22	41	2	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	16	22	51	2	35	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	16	23	1	2	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	16	23	11	2	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	16	23	21	2	34	0	0	0	0	0	0	0	66.43	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	23	31	2	35	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	16	23	41	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	16	23	51	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	1	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	11	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	21	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	31	2	36	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	41	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	0	51	2	35	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	1	1	2	35	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	17	1	11	2	34	0	0	0	0	0	0	0	66.45	0	0	11.8
2014	9	17	1	21	2	35	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	17	1	31	2	36	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	17	1	41	2	35	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	17	1	51	2	35	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	9	17	2	1	2	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	17	2	11	2	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	17	2	21	2	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	17	2	31	2	35	0	0	0	0	0	0	0	66.42	0	0	11.8
2014	9	17	2	41	2	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	17	2	51	2	36	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	17	3	1	2	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	17	3	11	2	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	17	3	21	2	35	0	0	0	0	0	0	0	66.4	0	0	11.8
2014	9	17	3	31	2	35	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	17	3	41	2	35	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	17	3	51	2	34	0	0	0	0	0	0	0	66.38	0	0	11.8
2014	9	17	4	1	2	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	17	4	11	2	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	17	4	21	2	35	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	9	17	4	31	2	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	17	4	41	2	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	17	4	51	2	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	17	5	1	2	35	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	17	5	11	2	34	0	0	0	0	0	0	0	66.34	0	0	11.8
2014	9	17	5	21	2	35	0	0	0	0	0	0	0	66.33	0	0	11.8
2014	9	17	5	31	2	34	0	0	0	0	0	0	0	66.33	0	0	11.8
2014	9	17	5	41	2	35	0	0	0	0	0	0	0	66.33	0	0	11.8
2014	9	17	5	51	2	35	0	0	0	0	0	0	0	66.31	0	0	11.8
2014	9	17	6	1	2	35	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	17	6	11	2	35	0	0	0	0	0	0	0	66.29	0	0	11.8
2014	9	17	6	21	2	35	0	0	0	0	0	0	0	66.27	0	0	11.6
2014	9	17	6	31	2	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	17	6	41	2	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	17	6	51	2	35	0	0	0	0	0	0	0	66.25	0	0	11.8
2014	9	17	7	1	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	7	11	2	36	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	17	7	21	2	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	17	7	31	2	35	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	17	7	41	2	35	0	0	0	0	0	0	0	66.16	0	0	12.2
2014	9	17	7	51	2	35	0	0	0	0	0	0	0	66.16	0	0	12.4
2014	9	17	8	1	2	34	0	0	0	0	0	0	0	66.18	0	0	12.4
2014	9	17	8	11	2	35	0	0	0	0	0	0	0	66.2	0	0	12.6
2014	9	17	8	21	2	35	0	0	0	0	0	0	0	66.22	0	0	12.6
2014	9	17	8	31	2	35	0	0	0	0	0	0	0	66.22	0	0	12.8
2014	9	17	8	41	2	34	0	0	0	0	0	0	0	66.24	0	0	12.8
2014	9	17	8	51	2	35	0	0	0	0	0	0	0	66.27	0	0	12.8
2014	9	17	9	1	2	35	0	0	0	0	0	0	0	66.29	0	0	13
2014	9	17	9	11	2	35	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	17	9	21	2	35	0	0	0	0	0	0	0	66.36	0	0	13
2014	9	17	9	31	2	35	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	17	9	41	2	34	0	0	0	0	0	0	0	66.42	0	0	13
2014	9	17	9	51	2	35	0	0	0	0	0	0	0	66.45	0	0	13
2014	9	17	10	1	2	35	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	17	10	11	2	35	0	0	0	0	0	0	0	66.51	0	0	13
2014	9	17	10	21	2	35	0	0	0	0	0	0	0	66.56	0	0	13
2014	9	17	10	31	2	35	0	0	0	0	0	0	0	66.6	0	0	13
2014	9	17	10	41	2	35	0	0	0	0	0	0	0	66.63	0	0	13
2014	9	17	10	51	2	35	0	0	0	0	0	0	0	66.67	0	0	13
2014	9	17	11	1	2	35	0	0	0	0	0	0	0	66.7	0	0	13
2014	9	17	11	11	2	35	0	0	0	0	0	0	0	66.74	0	0	13.2
2014	9	17	11	21	2	35	0	0	0	0	0	0	0	66.76	0	0	13.2
2014	9	17	11	31	2	35	0	0	0	0	0	0	0	66.81	0	0	13.2
2014	9	17	11	41	2	35	0	0	0	0	0	0	0	66.85	0	0	13.2
2014	9	17	11	51	2	34	0	0	0	0	0	0	0	66.87	0	0	13.2
2014	9	17	12	1	2	35	0	0	0	0	0	0	0	66.9	0	0	13.2
2014	9	17	12	11	2	35	0	0	0	0	0	0	0	66.92	0	0	13.2
2014	9	17	12	21	2	34	0	0	0	0	0	0	0	66.96	0	0	13
2014	9	17	12	31	2	35	0	0	0	0	0	0	0	66.99	0	0	13
2014	9	17	12	41	2	35	0	0	0	0	0	0	0	67.03	0	0	13
2014	9	17	12	51	2	34	0	0	0	0	0	0	0	67.05	0	0	13
2014	9	17	13	1	2	35	0	0	0	0	0	0	0	67.06	0	0	13
2014	9	17	13	11	2	35	0	0	0	0	0	0	0	67.1	0	0	13
2014	9	17	13	21	2	35	0	0	0	0	0	0	0	67.1	0	0	13
2014	9	17	13	31	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	13	41	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	13	51	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	14	1	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	14	11	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	14	21	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	17	14	31	2	36	0	0	0	0	0	0	0	67.1	0	0	13
2014	9	17	14	41	2	35	0	0	0	0	0	0	0	67.06	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	14	51	2	35	0	0	0	0	0	0	0	66.94	0	0	13
2014	9	17	15	1	2	35	0	0	0	0	0	0	0	66.99	0	0	13.2
2014	9	17	15	11	2	35	0	0	0	0	0	0	0	66.99	0	0	13
2014	9	17	15	21	2	36	0	0	0	0	0	0	0	66.97	0	0	13.2
2014	9	17	15	31	2	34	0	0	0	0	0	0	0	66.96	0	0	13.2
2014	9	17	15	41	2	35	0	0	0	0	0	0	0	66.97	0	0	13
2014	9	17	15	51	2	35	0	0	0	0	0	0	0	66.96	0	0	13.2
2014	9	17	16	1	2	35	0	0	0	0	0	0	0	66.92	0	0	13.2
2014	9	17	16	11	2	34	0	0	0	0	0	0	0	66.92	0	0	12.6
2014	9	17	16	21	2	35	0	0	0	0	0	0	0	66.96	0	0	13.2
2014	9	17	16	31	2	34	0	0	0	0	0	0	0	66.9	0	0	12.2
2014	9	17	16	41	2	35	0	0	0	0	0	0	0	66.92	0	0	12.8
2014	9	17	16	51	2	35	0	0	0	0	0	0	0	66.94	0	0	13.2
2014	9	17	17	1	2	35	0	0	0	0	0	0	0	66.94	0	0	13
2014	9	17	17	11	2	34	0	0	0	0	0	0	0	66.94	0	0	12.6
2014	9	17	17	21	2	34	0	0	0	0	0	0	0	66.94	0	0	12.2
2014	9	17	17	31	2	35	0	0	0	0	0	0	0	66.94	0	0	12.2
2014	9	17	17	41	2	35	0	0	0	0	0	0	0	66.94	0	0	12
2014	9	17	17	51	2	35	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	17	18	1	2	35	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	17	18	11	2	34	0	0	0	0	0	0	0	66.96	0	0	12
2014	9	17	18	21	2	35	0	0	0	0	0	0	0	66.97	0	0	12
2014	9	17	18	31	2	35	0	0	0	0	0	0	0	66.97	0	0	12
2014	9	17	18	41	2	35	0	0	0	0	0	0	0	66.99	0	0	12
2014	9	17	18	51	2	34	0	0	0	0	0	0	0	67.01	0	0	12
2014	9	17	19	1	2	35	0	0	0	0	0	0	0	67.03	0	0	12
2014	9	17	19	11	2	35	0	0	0	0	0	0	0	67.06	0	0	12
2014	9	17	19	21	2	35	0	0	0	0	0	0	0	67.08	0	0	12
2014	9	17	19	31	2	35	0	0	0	0	0	0	0	67.1	0	0	12
2014	9	17	19	41	2	35	0	0	0	0	0	0	0	67.14	0	0	12
2014	9	17	19	51	2	35	0	0	0	0	0	0	0	67.15	0	0	12
2014	9	17	20	1	2	35	0	0	0	0	0	0	0	67.17	0	0	12
2014	9	17	20	11	2	35	0	0	0	0	0	0	0	67.21	0	0	12
2014	9	17	20	21	2	36	0	0	0	0	0	0	0	67.23	0	0	12
2014	9	17	20	31	2	35	0	0	0	0	0	0	0	67.26	0	0	12
2014	9	17	20	41	2	34	0	0	0	0	0	0	0	67.28	0	0	12
2014	9	17	20	51	2	34	0	0	0	0	0	0	0	67.3	0	0	12
2014	9	17	21	1	2	34	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	17	21	11	2	35	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	17	21	21	2	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	17	21	31	2	34	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	17	21	41	2	36	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	17	21	51	2	35	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	17	22	1	2	35	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	17	22	11	2	35	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	17	22	21	2	35	0	0	0	0	0	0	0	67.46	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	22	31	2	35	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	17	22	41	2	34	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	17	22	51	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	17	23	1	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	17	23	11	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	17	23	21	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	17	23	31	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	17	23	41	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	17	23	51	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	0	1	2	35	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	18	0	11	2	34	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	0	21	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	0	31	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	0	41	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	0	51	2	34	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	18	1	1	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	18	1	11	2	36	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	18	1	21	2	35	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	18	1	31	2	35	0	0	0	0	0	0	0	67.46	0	0	11.8
2014	9	18	1	41	2	35	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	18	1	51	2	34	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	18	2	1	2	35	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	18	2	11	2	34	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	18	2	21	2	35	0	0	0	0	0	0	0	67.42	0	0	11.8
2014	9	18	2	31	2	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	18	2	41	2	35	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	18	2	51	2	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	18	3	1	2	35	0	0	0	0	0	0	0	67.39	0	0	11.8
2014	9	18	3	11	2	35	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	18	3	21	2	35	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	18	3	31	2	35	0	0	0	0	0	0	0	67.35	0	0	11.8
2014	9	18	3	41	2	35	0	0	0	0	0	0	0	67.33	0	0	11.8
2014	9	18	3	51	2	35	0	0	0	0	0	0	0	67.32	0	0	11.8
2014	9	18	4	1	2	35	0	0	0	0	0	0	0	67.3	0	0	11.8
2014	9	18	4	11	2	35	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	18	4	21	2	35	0	0	0	0	0	0	0	67.26	0	0	11.8
2014	9	18	4	31	2	35	0	0	0	0	0	0	0	67.24	0	0	11.8
2014	9	18	4	41	2	34	0	0	0	0	0	0	0	67.23	0	0	11.8
2014	9	18	4	51	2	35	0	0	0	0	0	0	0	67.21	0	0	11.8
2014	9	18	5	1	2	35	0	0	0	0	0	0	0	67.19	0	0	11.8
2014	9	18	5	11	2	34	0	0	0	0	0	0	0	67.17	0	0	11.8
2014	9	18	5	21	2	35	0	0	0	0	0	0	0	67.15	0	0	11.8
2014	9	18	5	31	2	35	0	0	0	0	0	0	0	67.12	0	0	11.8
2014	9	18	5	41	2	35	0	0	0	0	0	0	0	67.12	0	0	11.8
2014	9	18	5	51	2	35	0	0	0	0	0	0	0	67.08	0	0	11.8
2014	9	18	6	1	2	35	0	0	0	0	0	0	0	67.06	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	6	11	2	35	0	0	0	0	0	0	0	67.05	0	0	11.8
2014	9	18	6	21	2	34	0	0	0	0	0	0	0	67.01	0	0	11.8
2014	9	18	6	31	2	35	0	0	0	0	0	0	0	66.99	0	0	11.8
2014	9	18	6	41	2	35	0	0	0	0	0	0	0	66.97	0	0	11.8
2014	9	18	6	51	2	35	0	0	0	0	0	0	0	66.96	0	0	11.8
2014	9	18	7	1	2	35	0	0	0	0	0	0	0	66.94	0	0	11.8
2014	9	18	7	11	2	35	0	0	0	0	0	0	0	66.9	0	0	11.8
2014	9	18	7	21	2	35	0	0	0	0	0	0	0	66.88	0	0	11.8
2014	9	18	7	31	2	35	0	0	0	0	0	0	0	66.85	0	0	12
2014	9	18	7	41	2	35	0	0	0	0	0	0	0	66.85	0	0	12.2
2014	9	18	7	51	2	35	0	0	0	0	0	0	0	66.83	0	0	12.4
2014	9	18	8	1	2	35	0	0	0	0	0	0	0	66.85	0	0	12.6
2014	9	18	8	11	2	35	0	0	0	0	0	0	0	66.87	0	0	12.8
2014	9	18	8	21	2	35	0	0	0	0	0	0	0	66.87	0	0	12.8
2014	9	18	8	31	2	35	0	0	0	0	0	0	0	66.87	0	0	12.8
2014	9	18	8	41	2	35	0	0	0	0	0	0	0	66.88	0	0	13
2014	9	18	8	51	2	35	0	0	0	0	0	0	0	66.92	0	0	13
2014	9	18	9	1	2	34	0	0	0	0	0	0	0	66.94	0	0	13
2014	9	18	9	11	2	35	0	0	0	0	0	0	0	66.97	0	0	13
2014	9	18	9	21	2	35	0	0	0	0	0	0	0	66.99	0	0	13
2014	9	18	9	31	2	35	0	0	0	0	0	0	0	67.03	0	0	13
2014	9	18	9	41	2	35	0	0	0	0	0	0	0	67.06	0	0	13
2014	9	18	9	51	2	35	0	0	0	0	0	0	0	67.08	0	0	13
2014	9	18	10	1	2	35	0	0	0	0	0	0	0	67.12	0	0	13
2014	9	18	10	11	2	34	0	0	0	0	0	0	0	67.15	0	0	13
2014	9	18	10	21	2	36	0	0	0	0	0	0	0	67.19	0	0	13.2
2014	9	18	10	31	2	35	0	0	0	0	0	0	0	67.23	0	0	13.2
2014	9	18	10	41	2	35	0	0	0	0	0	0	0	67.24	0	0	13.2
2014	9	18	10	51	2	35	0	0	0	0	0	0	0	67.26	0	0	13.2
2014	9	18	11	1	2	35	0	0	0	0	0	0	0	67.32	0	0	13.2
2014	9	18	11	11	2	35	0	0	0	0	0	0	0	67.32	0	0	13.2
2014	9	18	11	21	2	35	0	0	0	0	0	0	0	67.37	0	0	13.2
2014	9	18	11	31	2	35	0	0	0	0	0	0	0	67.41	0	0	13.2
2014	9	18	11	41	2	35	0	0	0	0	0	0	0	67.42	0	0	13.2
2014	9	18	11	51	2	35	0	0	0	0	0	0	0	67.46	0	0	13.2
2014	9	18	12	1	2	35	0	0	0	0	0	0	0	67.48	0	0	13.2
2014	9	18	12	11	2	35	0	0	0	0	0	0	0	67.5	0	0	13.2
2014	9	18	12	21	2	34	0	0	0	0	0	0	0	67.51	0	0	13.2
2014	9	18	12	31	2	35	0	0	0	0	0	0	0	67.55	0	0	13.2
2014	9	18	12	41	2	35	0	0	0	0	0	0	0	67.57	0	0	13.2
2014	9	18	12	51	2	35	0	0	0	0	0	0	0	67.59	0	0	13.2
2014	9	18	13	1	2	35	0	0	0	0	0	0	0	67.59	0	0	13.2
2014	9	18	13	11	2	36	0	0	0	0	0	0	0	67.6	0	0	13.2
2014	9	18	13	21	2	34	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	18	13	31	2	35	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	18	13	41	2	35	0	0	0	0	0	0	0	67.62	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	13	51	2	35	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	18	14	1	2	35	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	18	14	11	2	35	0	0	0	0	0	0	0	67.62	0	0	13.2
2014	9	18	14	21	2	35	0	0	0	0	0	0	0	67.6	0	0	13.2
2014	9	18	14	31	2	34	0	0	0	0	0	0	0	67.59	0	0	13.2
2014	9	18	14	41	2	35	0	0	0	0	0	0	0	67.59	0	0	13
2014	9	18	14	51	2	34	0	0	0	0	0	0	0	67.57	0	0	13
2014	9	18	15	1	2	35	0	0	0	0	0	0	0	67.55	0	0	13
2014	9	18	15	11	2	35	0	0	0	0	0	0	0	67.55	0	0	13
2014	9	18	15	21	2	35	0	0	0	0	0	0	0	67.53	0	0	13
2014	9	18	15	31	2	36	0	0	0	0	0	0	0	67.51	0	0	13
2014	9	18	15	41	2	35	0	0	0	0	0	0	0	67.53	0	0	13
2014	9	18	15	51	2	35	0	0	0	0	0	0	0	67.53	0	0	13
2014	9	18	16	1	2	35	0	0	0	0	0	0	0	67.51	0	0	13
2014	9	18	16	11	2	35	0	0	0	0	0	0	0	67.51	0	0	13
2014	9	18	16	21	2	34	0	0	0	0	0	0	0	67.5	0	0	13
2014	9	18	16	31	2	35	0	0	0	0	0	0	0	67.48	0	0	13
2014	9	18	16	41	2	35	0	0	0	0	0	0	0	67.44	0	0	13
2014	9	18	16	51	2	35	0	0	0	0	0	0	0	67.44	0	0	13
2014	9	18	17	1	2	35	0	0	0	0	0	0	0	67.42	0	0	12.8
2014	9	18	17	11	2	35	0	0	0	0	0	0	0	67.41	0	0	12.2
2014	9	18	17	21	2	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	18	17	31	2	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	18	17	41	2	35	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	17	51	2	34	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	18	1	2	34	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	18	11	2	34	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	18	21	2	35	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	18	18	31	2	35	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	18	18	41	2	35	0	0	0	0	0	0	0	67.33	0	0	12
2014	9	18	18	51	2	35	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	19	1	2	34	0	0	0	0	0	0	0	67.35	0	0	12
2014	9	18	19	11	2	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	18	19	21	2	35	0	0	0	0	0	0	0	67.37	0	0	12
2014	9	18	19	31	2	35	0	0	0	0	0	0	0	67.39	0	0	12
2014	9	18	19	41	2	35	0	0	0	0	0	0	0	67.41	0	0	12
2014	9	18	19	51	2	35	0	0	0	0	0	0	0	67.42	0	0	12
2014	9	18	20	1	2	35	0	0	0	0	0	0	0	67.44	0	0	12
2014	9	18	20	11	2	35	0	0	0	0	0	0	0	67.46	0	0	12
2014	9	18	20	21	2	35	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	18	20	31	2	35	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	18	20	41	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	18	20	51	2	36	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	18	21	1	2	34	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	18	21	11	2	35	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	18	21	21	2	34	0	0	0	0	0	0	0	67.53	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	21	31	2	35	0	0	0	0	0	0	0	67.55	0	0	11.8
2014	9	18	21	41	2	35	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	21	51	2	34	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	22	1	2	35	0	0	0	0	0	0	0	67.59	0	0	11.8
2014	9	18	22	11	2	35	0	0	0	0	0	0	0	67.59	0	0	11.8
2014	9	18	22	21	2	34	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	22	31	2	35	0	0	0	0	0	0	0	67.59	0	0	11.8
2014	9	18	22	41	2	34	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	22	51	2	34	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	23	1	2	35	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	23	11	2	35	0	0	0	0	0	0	0	67.57	0	0	11.8
2014	9	18	23	21	2	34	0	0	0	0	0	0	0	67.55	0	0	11.8
2014	9	18	23	31	2	35	0	0	0	0	0	0	0	67.55	0	0	11.8
2014	9	18	23	41	2	34	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	18	23	51	2	35	0	0	0	0	0	0	0	67.53	0	0	11.8
2014	9	19	0	1	2	35	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	9	19	0	11	2	35	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	9	19	0	21	2	35	0	0	0	0	0	0	0	67.48	0	0	11.8
2014	9	19	0	31	2	35	0	0	0	0	0	0	0	67.44	0	0	11.8
2014	9	19	0	41	2	35	0	0	0	0	0	0	0	67.42	0	0	11.8
2014	9	19	0	51	2	34	0	0	0	0	0	0	0	67.41	0	0	11.8
2014	9	19	1	1	2	35	0	0	0	0	0	0	0	67.37	0	0	11.8
2014	9	19	1	11	2	35	0	0	0	0	0	0	0	67.35	0	0	11.8
2014	9	19	1	21	2	35	0	0	0	0	0	0	0	67.32	0	0	11.8
2014	9	19	1	31	2	35	0	0	0	0	0	0	0	67.28	0	0	11.8
2014	9	19	1	41	2	35	0	0	0	0	0	0	0	67.24	0	0	11.8
2014	9	19	1	51	2	35	0	0	0	0	0	0	0	67.21	0	0	11.8
2014	9	19	2	1	2	35	0	0	0	0	0	0	0	67.17	0	0	11.8
2014	9	19	2	11	2	35	0	0	0	0	0	0	0	67.14	0	0	11.8
2014	9	19	2	21	2	35	0	0	0	0	0	0	0	67.08	0	0	11.8
2014	9	19	2	31	2	35	0	0	0	0	0	0	0	67.05	0	0	11.8
2014	9	19	2	41	2	35	0	0	0	0	0	0	0	67.01	0	0	11.8
2014	9	19	2	51	2	34	0	0	0	0	0	0	0	66.97	0	0	11.8
2014	9	19	3	1	2	34	0	0	0	0	0	0	0	66.94	0	0	11.8
2014	9	19	3	11	2	35	0	0	0	0	0	0	0	66.9	0	0	11.8
2014	9	19	3	21	2	35	0	0	0	0	0	0	0	66.85	0	0	11.6
2014	9	19	3	31	2	35	0	0	0	0	0	0	0	66.81	0	0	11.6
2014	9	19	3	41	2	35	0	0	0	0	0	0	0	66.78	0	0	11.6
2014	9	19	3	51	2	35	0	0	0	0	0	0	0	66.74	0	0	11.6
2014	9	19	4	1	2	35	0	0	0	0	0	0	0	66.69	0	0	11.6
2014	9	19	4	11	2	35	0	0	0	0	0	0	0	66.67	0	0	11.6
2014	9	19	4	21	2	34	0	0	0	0	0	0	0	66.63	0	0	11.6
2014	9	19	4	31	2	35	0	0	0	0	0	0	0	66.58	0	0	11.6
2014	9	19	4	41	2	36	0	0	0	0	0	0	0	66.54	0	0	11.6
2014	9	19	4	51	2	35	0	0	0	0	0	0	0	66.51	0	0	11.6
2014	9	19	5	1	2	35	0	0	0	0	0	0	0	66.47	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	5	11	2	35	0	0	0	0	0	0	0	66.43	0	0	11.6
2014	9	19	5	21	2	36	0	0	0	0	0	0	0	66.4	0	0	11.6
2014	9	19	5	31	2	35	0	0	0	0	0	0	0	66.36	0	0	11.6
2014	9	19	5	41	2	35	0	0	0	0	0	0	0	66.33	0	0	11.6
2014	9	19	5	51	2	34	0	0	0	0	0	0	0	66.29	0	0	11.6
2014	9	19	6	1	2	35	0	0	0	0	0	0	0	66.25	0	0	11.6
2014	9	19	6	11	2	35	0	0	0	0	0	0	0	66.24	0	0	11.6
2014	9	19	6	21	2	35	0	0	0	0	0	0	0	66.2	0	0	11.6
2014	9	19	6	31	2	35	0	0	0	0	0	0	0	66.16	0	0	11.6
2014	9	19	6	41	2	36	0	0	0	0	0	0	0	66.13	0	0	11.6
2014	9	19	6	51	2	35	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	9	19	7	1	2	35	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	19	7	11	2	35	0	0	0	0	0	0	0	66.04	0	0	11.8
2014	9	19	7	21	2	35	0	0	0	0	0	0	0	66.02	0	0	11.8
2014	9	19	7	31	2	35	0	0	0	0	0	0	0	66	0	0	11.8
2014	9	19	7	41	2	35	0	0	0	0	0	0	0	65.98	0	0	12
2014	9	19	7	51	2	35	0	0	0	0	0	0	0	65.97	0	0	12
2014	9	19	8	1	2	35	0	0	0	0	0	0	0	65.97	0	0	12.2
2014	9	19	8	11	2	35	0	0	0	0	0	0	0	65.97	0	0	12.4
2014	9	19	8	21	2	35	0	0	0	0	0	0	0	65.95	0	0	12.4
2014	9	19	8	31	2	35	0	0	0	0	0	0	0	65.97	0	0	12.6
2014	9	19	8	41	2	35	0	0	0	0	0	0	0	65.97	0	0	12.6
2014	9	19	8	51	2	35	0	0	0	0	0	0	0	65.98	0	0	12.8
2014	9	19	9	1	2	35	0	0	0	0	0	0	0	66	0	0	12.8
2014	9	19	9	11	2	36	0	0	0	0	0	0	0	66	0	0	13
2014	9	19	9	21	2	35	0	0	0	0	0	0	0	66	0	0	13
2014	9	19	9	31	2	36	0	0	0	0	0	0	0	66.02	0	0	13
2014	9	19	9	41	2	35	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	9	19	9	51	2	35	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	9	19	10	1	2	35	0	0	0	0	0	0	0	66.06	0	0	13.4
2014	9	19	10	11	2	35	0	0	0	0	0	0	0	66.09	0	0	13.4
2014	9	19	10	21	2	35	0	0	0	0	0	0	0	66.13	0	0	13.4
2014	9	19	10	31	2	35	0	0	0	0	0	0	0	66.15	0	0	13.2
2014	9	19	10	41	2	34	0	0	0	0	0	0	0	66.16	0	0	13.2
2014	9	19	10	51	2	35	0	0	0	0	0	0	0	66.18	0	0	13.2
2014	9	19	11	1	2	35	0	0	0	0	0	0	0	66.24	0	0	13.2
2014	9	19	11	11	2	35	0	0	0	0	0	0	0	66.29	0	0	13.2
2014	9	19	11	21	2	35	0	0	0	0	0	0	0	66.34	0	0	13.2
2014	9	19	11	31	2	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2014	9	19	11	41	2	35	0	0	0	0	0	0	0	66.4	0	0	13.2
2014	9	19	11	51	2	34	0	0	0	0	0	0	0	66.43	0	0	13.2
2014	9	19	12	1	2	35	0	0	0	0	0	0	0	66.47	0	0	13.2
2014	9	19	12	11	2	34	0	0	0	0	0	0	0	66.47	0	0	13.2
2014	9	19	12	21	2	34	0	0	0	0	0	0	0	66.51	0	0	13.2
2014	9	19	12	31	2	35	0	0	0	0	0	0	0	66.52	0	0	13.2
2014	9	19	12	41	2	36	0	0	0	0	0	0	0	66.54	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	12	51	2	35	0	0	0	0	0	0	0	66.56	0	0	13.2
2014	9	19	13	1	2	35	0	0	0	0	0	0	0	66.56	0	0	13.2
2014	9	19	13	11	2	35	0	0	0	0	0	0	0	66.58	0	0	13.2
2014	9	19	13	21	2	36	0	0	0	0	0	0	0	66.6	0	0	13.2
2014	9	19	13	31	2	35	0	0	0	0	0	0	0	66.61	0	0	13.2
2014	9	19	13	41	2	35	0	0	0	0	0	0	0	66.63	0	0	13.2
2014	9	19	13	51	2	35	0	0	0	0	0	0	0	66.63	0	0	13.2
2014	9	19	14	1	2	35	0	0	0	0	0	0	0	66.63	0	0	13.2
2014	9	19	14	11	2	35	0	0	0	0	0	0	0	66.63	0	0	13.2
2014	9	19	14	21	2	35	0	0	0	0	0	0	0	66.61	0	0	13
2014	9	19	14	31	2	36	0	0	0	0	0	0	0	66.6	0	0	13
2014	9	19	14	41	2	35	0	0	0	0	0	0	0	66.58	0	0	13
2014	9	19	14	51	2	35	0	0	0	0	0	0	0	66.56	0	0	13
2014	9	19	15	1	2	35	0	0	0	0	0	0	0	66.54	0	0	13
2014	9	19	15	11	2	35	0	0	0	0	0	0	0	66.52	0	0	13
2014	9	19	15	21	2	34	0	0	0	0	0	0	0	66.51	0	0	13
2014	9	19	15	31	2	35	0	0	0	0	0	0	0	66.47	0	0	13
2014	9	19	15	41	2	35	0	0	0	0	0	0	0	66.45	0	0	13
2014	9	19	15	51	2	35	0	0	0	0	0	0	0	66.43	0	0	13
2014	9	19	16	1	2	35	0	0	0	0	0	0	0	66.4	0	0	13
2014	9	19	16	11	2	35	0	0	0	0	0	0	0	66.38	0	0	13
2014	9	19	16	21	2	35	0	0	0	0	0	0	0	66.36	0	0	13
2014	9	19	16	31	2	34	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	19	16	41	2	34	0	0	0	0	0	0	0	66.33	0	0	13
2014	9	19	16	51	2	35	0	0	0	0	0	0	0	66.29	0	0	13
2014	9	19	17	1	2	35	0	0	0	0	0	0	0	66.27	0	0	12.6
2014	9	19	17	11	2	35	0	0	0	0	0	0	0	66.25	0	0	12.4
2014	9	19	17	21	2	35	0	0	0	0	0	0	0	66.24	0	0	12.2
2014	9	19	17	31	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	17	41	2	35	0	0	0	0	0	0	0	66.22	0	0	12
2014	9	19	17	51	2	35	0	0	0	0	0	0	0	66.22	0	0	12
2014	9	19	18	1	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	18	11	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	18	21	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	18	31	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	18	41	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	18	51	2	35	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	19	19	1	2	35	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	19	19	11	2	36	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	19	19	21	2	35	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	19	19	31	2	34	0	0	0	0	0	0	0	66.18	0	0	12
2014	9	19	19	41	2	34	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	19	51	2	35	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	20	1	2	36	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	20	11	2	34	0	0	0	0	0	0	0	66.2	0	0	12
2014	9	19	20	21	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	20	31	2	36	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	19	20	41	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	19	20	51	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	21	1	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	21	11	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	21	21	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	21	31	2	35	0	0	0	0	0	0	0	66.24	0	0	12
2014	9	19	21	41	2	35	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	19	21	51	2	35	0	0	0	0	0	0	0	66.24	0	0	11.8
2014	9	19	22	1	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	19	22	11	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	19	22	21	2	35	0	0	0	0	0	0	0	66.22	0	0	11.8
2014	9	19	22	31	2	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	19	22	41	2	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	19	22	51	2	35	0	0	0	0	0	0	0	66.2	0	0	11.8
2014	9	19	23	1	2	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	19	23	11	2	35	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	9	19	23	21	2	36	0	0	0	0	0	0	0	66.16	0	0	11.8
2014	9	19	23	31	2	35	0	0	0	0	0	0	0	66.15	0	0	11.8
2014	9	19	23	41	2	34	0	0	0	0	0	0	0	66.13	0	0	11.8
2014	9	19	23	51	2	34	0	0	0	0	0	0	0	66.11	0	0	11.8
2014	9	20	0	1	2	35	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	9	20	0	11	2	35	0	0	0	0	0	0	0	66.07	0	0	11.8
2014	9	20	0	21	2	35	0	0	0	0	0	0	0	66.06	0	0	11.8
2014	9	20	0	31	2	35	0	0	0	0	0	0	0	66.02	0	0	11.8
2014	9	20	0	41	2	36	0	0	0	0	0	0	0	66	0	0	11.8
2014	9	20	0	51	2	35	0	0	0	0	0	0	0	65.97	0	0	11.8
2014	9	20	1	1	2	35	0	0	0	0	0	0	0	65.95	0	0	11.8
2014	9	20	1	11	2	35	0	0	0	0	0	0	0	65.93	0	0	11.8
2014	9	20	1	21	2	36	0	0	0	0	0	0	0	65.89	0	0	11.8
2014	9	20	1	31	2	35	0	0	0	0	0	0	0	65.86	0	0	11.8
2014	9	20	1	41	2	34	0	0	0	0	0	0	0	65.82	0	0	11.8
2014	9	20	1	51	2	35	0	0	0	0	0	0	0	65.79	0	0	11.8
2014	9	20	2	1	2	35	0	0	0	0	0	0	0	65.75	0	0	11.8
2014	9	20	2	11	2	34	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	20	2	21	2	35	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	20	2	31	2	34	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	20	2	41	2	35	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	20	2	51	2	34	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	20	3	1	2	35	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	20	3	11	2	35	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	9	20	3	21	2	35	0	0	0	0	0	0	0	65.46	0	0	11.8
2014	9	20	3	31	2	35	0	0	0	0	0	0	0	65.41	0	0	11.8
2014	9	20	3	41	2	35	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	20	3	51	2	35	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	20	4	1	2	35	0	0	0	0	0	0	0	65.32	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	4	11	2	34	0	0	0	0	0	0	0	65.26	0	0	11.8
2014	9	20	4	21	2	35	0	0	0	0	0	0	0	65.25	0	0	11.8
2014	9	20	4	31	2	35	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	20	4	41	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	4	51	2	35	0	0	0	0	0	0	0	65.1	0	0	11.8
2014	9	20	5	1	2	35	0	0	0	0	0	0	0	65.08	0	0	11.6
2014	9	20	5	11	2	35	0	0	0	0	0	0	0	65.05	0	0	11.6
2014	9	20	5	21	2	35	0	0	0	0	0	0	0	65.01	0	0	11.6
2014	9	20	5	31	2	35	0	0	0	0	0	0	0	64.98	0	0	11.6
2014	9	20	5	41	2	35	0	0	0	0	0	0	0	64.94	0	0	11.6
2014	9	20	5	51	2	35	0	0	0	0	0	0	0	64.9	0	0	11.6
2014	9	20	6	1	2	35	0	0	0	0	0	0	0	64.85	0	0	11.6
2014	9	20	6	11	2	35	0	0	0	0	0	0	0	64.83	0	0	11.6
2014	9	20	6	21	2	35	0	0	0	0	0	0	0	64.8	0	0	11.6
2014	9	20	6	31	2	35	0	0	0	0	0	0	0	64.76	0	0	11.6
2014	9	20	6	41	2	35	0	0	0	0	0	0	0	64.72	0	0	11.6
2014	9	20	6	51	2	35	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	20	7	1	2	35	0	0	0	0	0	0	0	64.65	0	0	11.6
2014	9	20	7	11	2	35	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	20	7	21	2	35	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	20	7	31	2	35	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	20	7	41	2	36	0	0	0	0	0	0	0	64.53	0	0	12.2
2014	9	20	7	51	2	35	0	0	0	0	0	0	0	64.49	0	0	12.2
2014	9	20	8	1	2	35	0	0	0	0	0	0	0	64.49	0	0	12.2
2014	9	20	8	11	2	36	0	0	0	0	0	0	0	64.49	0	0	12.6
2014	9	20	8	21	2	35	0	0	0	0	0	0	0	64.49	0	0	12.8
2014	9	20	8	31	2	35	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	20	8	41	2	35	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	20	8	51	2	35	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	20	9	1	2	36	0	0	0	0	0	0	0	64.53	0	0	13.2
2014	9	20	9	11	2	35	0	0	0	0	0	0	0	64.54	0	0	13.2
2014	9	20	9	21	2	35	0	0	0	0	0	0	0	64.58	0	0	13.2
2014	9	20	9	31	2	35	0	0	0	0	0	0	0	64.6	0	0	13.2
2014	9	20	9	41	2	35	0	0	0	0	0	0	0	64.65	0	0	13.2
2014	9	20	9	51	2	35	0	0	0	0	0	0	0	64.67	0	0	13.2
2014	9	20	10	1	2	35	0	0	0	0	0	0	0	64.67	0	0	13.2
2014	9	20	10	11	2	35	0	0	0	0	0	0	0	64.69	0	0	13
2014	9	20	10	21	2	35	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	20	10	31	2	35	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	20	10	41	2	35	0	0	0	0	0	0	0	64.81	0	0	13
2014	9	20	10	51	2	36	0	0	0	0	0	0	0	64.89	0	0	13
2014	9	20	11	1	2	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	20	11	11	2	35	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	20	11	21	2	35	0	0	0	0	0	0	0	64.78	0	0	12.6
2014	9	20	11	31	2	34	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	20	11	41	2	35	0	0	0	0	0	0	0	64.76	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	11	51	2	35	0	0	0	0	0	0	0	64.81	0	0	12.8
2014	9	20	12	1	2	35	0	0	0	0	0	0	0	64.78	0	0	12.6
2014	9	20	12	11	2	35	0	0	0	0	0	0	0	64.76	0	0	12.8
2014	9	20	12	21	2	36	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	20	12	31	2	35	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	20	12	41	2	35	0	0	0	0	0	0	0	64.85	0	0	13.2
2014	9	20	12	51	2	35	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	20	13	1	2	35	0	0	0	0	0	0	0	65.07	0	0	13.2
2014	9	20	13	11	2	35	0	0	0	0	0	0	0	65.17	0	0	13.2
2014	9	20	13	21	2	35	0	0	0	0	0	0	0	65.08	0	0	13.2
2014	9	20	13	31	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	20	13	41	2	36	0	0	0	0	0	0	0	64.96	0	0	13.2
2014	9	20	13	51	2	35	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	20	14	1	2	35	0	0	0	0	0	0	0	64.89	0	0	13.2
2014	9	20	14	11	2	35	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	20	14	21	2	35	0	0	0	0	0	0	0	64.99	0	0	13.2
2014	9	20	14	31	2	35	0	0	0	0	0	0	0	64.99	0	0	13.2
2014	9	20	14	41	2	35	0	0	0	0	0	0	0	64.98	0	0	13.2
2014	9	20	14	51	2	35	0	0	0	0	0	0	0	64.98	0	0	13.2
2014	9	20	15	1	2	36	0	0	0	0	0	0	0	65.05	0	0	13.2
2014	9	20	15	11	2	35	0	0	0	0	0	0	0	65.1	0	0	13.2
2014	9	20	15	21	2	35	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	20	15	31	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	20	15	41	2	35	0	0	0	0	0	0	0	65.07	0	0	13
2014	9	20	15	51	2	35	0	0	0	0	0	0	0	64.99	0	0	13
2014	9	20	16	1	2	35	0	0	0	0	0	0	0	64.94	0	0	13
2014	9	20	16	11	2	35	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	20	16	21	2	35	0	0	0	0	0	0	0	64.94	0	0	13
2014	9	20	16	31	2	35	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	20	16	41	2	35	0	0	0	0	0	0	0	64.94	0	0	12.2
2014	9	20	16	51	2	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	20	17	1	2	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	20	17	11	2	36	0	0	0	0	0	0	0	64.9	0	0	12.2
2014	9	20	17	21	2	35	0	0	0	0	0	0	0	64.87	0	0	12.2
2014	9	20	17	31	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	20	17	41	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	20	17	51	2	34	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	20	18	1	2	35	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	20	18	11	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	20	18	21	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	20	18	31	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	20	18	41	2	35	0	0	0	0	0	0	0	64.9	0	0	12
2014	9	20	18	51	2	35	0	0	0	0	0	0	0	64.9	0	0	12
2014	9	20	19	1	2	34	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	20	19	11	2	35	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	20	19	21	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	19	31	2	35	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	20	19	41	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	20	19	51	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	20	20	1	2	36	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	20	20	11	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	20	20	21	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	20	20	31	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	20	20	41	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	20	20	51	2	35	0	0	0	0	0	0	0	65.01	0	0	11.8
2014	9	20	21	1	2	34	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	20	21	11	2	35	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	20	21	21	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	20	21	31	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	20	21	41	2	35	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	20	21	51	2	35	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	20	22	1	2	34	0	0	0	0	0	0	0	65.1	0	0	11.8
2014	9	20	22	11	2	35	0	0	0	0	0	0	0	65.1	0	0	11.8
2014	9	20	22	21	2	36	0	0	0	0	0	0	0	65.12	0	0	11.8
2014	9	20	22	31	2	35	0	0	0	0	0	0	0	65.12	0	0	11.8
2014	9	20	22	41	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	20	22	51	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	20	23	1	2	34	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	23	11	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	23	21	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	23	31	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	23	41	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	20	23	51	2	34	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	21	0	1	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	21	0	11	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	21	0	21	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	21	0	31	2	35	0	0	0	0	0	0	0	65.16	0	0	11.8
2014	9	21	0	41	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	21	0	51	2	35	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	9	21	1	1	2	35	0	0	0	0	0	0	0	65.12	0	0	11.8
2014	9	21	1	11	2	35	0	0	0	0	0	0	0	65.1	0	0	11.8
2014	9	21	1	21	2	35	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	21	1	31	2	35	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	21	1	41	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	21	1	51	2	36	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	21	2	1	2	35	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	21	2	11	2	35	0	0	0	0	0	0	0	65.01	0	0	11.6
2014	9	21	2	21	2	36	0	0	0	0	0	0	0	65.01	0	0	11.6
2014	9	21	2	31	2	34	0	0	0	0	0	0	0	64.98	0	0	11.6
2014	9	21	2	41	2	36	0	0	0	0	0	0	0	64.98	0	0	11.6
2014	9	21	2	51	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	3	1	2	34	0	0	0	0	0	0	0	64.96	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	3	11	2	35	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	21	3	21	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	3	31	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	3	41	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	3	51	2	35	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	21	4	1	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	21	4	11	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	21	4	21	2	35	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	21	4	31	2	36	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	21	4	41	2	34	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	21	4	51	2	35	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	21	5	1	2	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	21	5	11	2	35	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	21	5	21	2	36	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	21	5	31	2	35	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	21	5	41	2	35	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	21	5	51	2	35	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	21	6	1	2	35	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	21	6	11	2	35	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	21	6	21	2	35	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	21	6	31	2	36	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	21	6	41	2	36	0	0	0	0	0	0	0	64.65	0	0	11.6
2014	9	21	6	51	2	35	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	21	7	1	2	35	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	21	7	11	2	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	21	7	21	2	35	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	21	7	31	2	35	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	21	7	41	2	36	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	21	7	51	2	35	0	0	0	0	0	0	0	64.56	0	0	12.2
2014	9	21	8	1	2	35	0	0	0	0	0	0	0	64.56	0	0	12.4
2014	9	21	8	11	2	35	0	0	0	0	0	0	0	64.54	0	0	12.2
2014	9	21	8	21	2	34	0	0	0	0	0	0	0	64.53	0	0	12.2
2014	9	21	8	31	2	35	0	0	0	0	0	0	0	64.56	0	0	12.6
2014	9	21	8	41	2	35	0	0	0	0	0	0	0	64.58	0	0	12.8
2014	9	21	8	51	2	35	0	0	0	0	0	0	0	64.6	0	0	13
2014	9	21	9	1	2	35	0	0	0	0	0	0	0	64.62	0	0	13
2014	9	21	9	11	2	35	0	0	0	0	0	0	0	64.65	0	0	13
2014	9	21	9	21	2	34	0	0	0	0	0	0	0	64.67	0	0	13.2
2014	9	21	9	31	2	35	0	0	0	0	0	0	0	64.69	0	0	13.2
2014	9	21	9	41	2	35	0	0	0	0	0	0	0	64.72	0	0	13.2
2014	9	21	9	51	2	34	0	0	0	0	0	0	0	64.74	0	0	13.2
2014	9	21	10	1	2	35	0	0	0	0	0	0	0	64.81	0	0	13.2
2014	9	21	10	11	2	35	0	0	0	0	0	0	0	64.83	0	0	13.2
2014	9	21	10	21	2	36	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	21	10	31	2	34	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	21	10	41	2	35	0	0	0	0	0	0	0	64.92	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	10	51	2	36	0	0	0	0	0	0	0	64.98	0	0	13
2014	9	21	11	1	2	35	0	0	0	0	0	0	0	65.01	0	0	13
2014	9	21	11	11	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	21	11	21	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	21	11	31	2	35	0	0	0	0	0	0	0	65.12	0	0	13.2
2014	9	21	11	41	2	36	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	21	11	51	2	36	0	0	0	0	0	0	0	65.16	0	0	13.2
2014	9	21	12	1	2	35	0	0	0	0	0	0	0	65.08	0	0	13
2014	9	21	12	11	2	35	0	0	0	0	0	0	0	65.19	0	0	13.2
2014	9	21	12	21	2	35	0	0	0	0	0	0	0	65.23	0	0	13.2
2014	9	21	12	31	2	35	0	0	0	0	0	0	0	65.19	0	0	13
2014	9	21	12	41	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	21	12	51	2	34	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	21	13	1	2	35	0	0	0	0	0	0	0	65.05	0	0	13
2014	9	21	13	11	2	35	0	0	0	0	0	0	0	64.94	0	0	13.2
2014	9	21	13	21	2	36	0	0	0	0	0	0	0	64.94	0	0	13.2
2014	9	21	13	31	2	34	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	21	13	41	2	35	0	0	0	0	0	0	0	64.89	0	0	13.2
2014	9	21	13	51	2	35	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	21	14	1	2	35	0	0	0	0	0	0	0	64.92	0	0	13.2
2014	9	21	14	11	2	35	0	0	0	0	0	0	0	64.89	0	0	13.2
2014	9	21	14	21	2	34	0	0	0	0	0	0	0	65.08	0	0	13.2
2014	9	21	14	31	2	35	0	0	0	0	0	0	0	65.14	0	0	13.2
2014	9	21	14	41	2	35	0	0	0	0	0	0	0	65.1	0	0	13.2
2014	9	21	14	51	2	35	0	0	0	0	0	0	0	65.08	0	0	13.2
2014	9	21	15	1	2	35	0	0	0	0	0	0	0	65.12	0	0	13.2
2014	9	21	15	11	2	35	0	0	0	0	0	0	0	65.03	0	0	13
2014	9	21	15	21	2	35	0	0	0	0	0	0	0	64.92	0	0	13
2014	9	21	15	31	2	35	0	0	0	0	0	0	0	64.9	0	0	13
2014	9	21	15	41	2	35	0	0	0	0	0	0	0	64.87	0	0	13
2014	9	21	15	51	2	35	0	0	0	0	0	0	0	64.87	0	0	12.8
2014	9	21	16	1	2	36	0	0	0	0	0	0	0	64.85	0	0	12.8
2014	9	21	16	11	2	35	0	0	0	0	0	0	0	64.92	0	0	13.2
2014	9	21	16	21	2	35	0	0	0	0	0	0	0	64.92	0	0	13.2
2014	9	21	16	31	2	36	0	0	0	0	0	0	0	64.92	0	0	13.2
2014	9	21	16	41	2	35	0	0	0	0	0	0	0	64.9	0	0	13.2
2014	9	21	16	51	2	35	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	21	17	1	2	35	0	0	0	0	0	0	0	64.87	0	0	13
2014	9	21	17	11	2	35	0	0	0	0	0	0	0	64.87	0	0	12.4
2014	9	21	17	21	2	35	0	0	0	0	0	0	0	64.85	0	0	12.2
2014	9	21	17	31	2	35	0	0	0	0	0	0	0	64.83	0	0	12
2014	9	21	17	41	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	21	17	51	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	21	18	1	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	21	18	11	2	34	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	21	18	21	2	35	0	0	0	0	0	0	0	64.85	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	18	31	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	21	18	41	2	35	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	21	18	51	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	21	19	1	2	35	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	21	19	11	2	34	0	0	0	0	0	0	0	64.89	0	0	12
2014	9	21	19	21	2	35	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	21	19	31	2	36	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	21	19	41	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	19	51	2	35	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	21	20	1	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	20	11	2	34	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	20	21	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	20	31	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	20	41	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	20	51	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	1	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	11	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	21	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	31	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	41	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	21	51	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	1	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	11	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	21	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	31	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	41	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	21	22	51	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	21	23	1	2	35	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	21	23	11	2	36	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	21	23	21	2	35	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	21	23	31	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	23	41	2	36	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	21	23	51	2	35	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	22	0	1	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	22	0	11	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	22	0	21	2	35	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	9	22	0	31	2	35	0	0	0	0	0	0	0	64.85	0	0	11.8
2014	9	22	0	41	2	35	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	22	0	51	2	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	22	1	1	2	35	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	22	1	11	2	34	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	22	1	21	2	35	0	0	0	0	0	0	0	64.74	0	0	11.8
2014	9	22	1	31	2	35	0	0	0	0	0	0	0	64.72	0	0	11.8
2014	9	22	1	41	2	35	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	22	1	51	2	36	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	22	2	1	2	35	0	0	0	0	0	0	0	64.63	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	2	11	2	35	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	22	2	21	2	35	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	22	2	31	2	35	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	22	2	41	2	35	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	22	2	51	2	35	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	22	3	1	2	35	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	22	3	11	2	35	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	22	3	21	2	35	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	22	3	31	2	35	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	22	3	41	2	35	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	22	3	51	2	35	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	22	4	1	2	35	0	0	0	0	0	0	0	64.35	0	0	11.6
2014	9	22	4	11	2	35	0	0	0	0	0	0	0	64.33	0	0	11.6
2014	9	22	4	21	2	35	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	22	4	31	2	35	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	22	4	41	2	35	0	0	0	0	0	0	0	64.24	0	0	11.6
2014	9	22	4	51	2	35	0	0	0	0	0	0	0	64.22	0	0	11.6
2014	9	22	5	1	2	35	0	0	0	0	0	0	0	64.2	0	0	11.6
2014	9	22	5	11	2	35	0	0	0	0	0	0	0	64.17	0	0	11.6
2014	9	22	5	21	2	35	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	22	5	31	2	35	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	22	5	41	2	35	0	0	0	0	0	0	0	64.09	0	0	11.6
2014	9	22	5	51	2	36	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	22	6	1	2	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	22	6	11	2	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	22	6	21	2	35	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	22	6	31	2	35	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	22	6	41	2	35	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	22	6	51	2	35	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	22	7	1	2	36	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	22	7	11	2	36	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	22	7	21	2	35	0	0	0	0	0	0	0	63.84	0	0	11.4
2014	9	22	7	31	2	35	0	0	0	0	0	0	0	63.82	0	0	12
2014	9	22	7	41	2	35	0	0	0	0	0	0	0	63.81	0	0	12.4
2014	9	22	7	51	2	36	0	0	0	0	0	0	0	63.79	0	0	12.6
2014	9	22	8	1	2	36	0	0	0	0	0	0	0	63.77	0	0	13
2014	9	22	8	11	2	35	0	0	0	0	0	0	0	63.79	0	0	13.2
2014	9	22	8	21	2	35	0	0	0	0	0	0	0	63.79	0	0	13.2
2014	9	22	8	31	2	35	0	0	0	0	0	0	0	63.81	0	0	13.4
2014	9	22	8	41	2	35	0	0	0	0	0	0	0	63.82	0	0	13.4
2014	9	22	8	51	2	35	0	0	0	0	0	0	0	63.84	0	0	13.4
2014	9	22	9	1	2	35	0	0	0	0	0	0	0	63.88	0	0	13.4
2014	9	22	9	11	2	36	0	0	0	0	0	0	0	63.91	0	0	13.4
2014	9	22	9	21	2	35	0	0	0	0	0	0	0	63.93	0	0	13.2
2014	9	22	9	31	2	36	0	0	0	0	0	0	0	63.97	0	0	13.2
2014	9	22	9	41	2	35	0	0	0	0	0	0	0	64	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	9	51	2	35	0	0	0	0	0	0	0	64.04	0	0	13.2
2014	9	22	10	1	2	35	0	0	0	0	0	0	0	64.06	0	0	13.2
2014	9	22	10	11	2	35	0	0	0	0	0	0	0	64.13	0	0	13.2
2014	9	22	10	21	2	35	0	0	0	0	0	0	0	64.17	0	0	13.2
2014	9	22	10	31	2	36	0	0	0	0	0	0	0	64.2	0	0	13.2
2014	9	22	10	41	2	36	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	22	10	51	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	22	11	1	2	35	0	0	0	0	0	0	0	64.33	0	0	13
2014	9	22	11	11	2	35	0	0	0	0	0	0	0	64.38	0	0	13.2
2014	9	22	11	21	2	34	0	0	0	0	0	0	0	64.42	0	0	13.2
2014	9	22	11	31	2	36	0	0	0	0	0	0	0	64.47	0	0	13.2
2014	9	22	11	41	2	34	0	0	0	0	0	0	0	64.49	0	0	13
2014	9	22	11	51	2	35	0	0	0	0	0	0	0	64.54	0	0	13
2014	9	22	12	1	2	35	0	0	0	0	0	0	0	64.56	0	0	13.2
2014	9	22	12	11	2	35	0	0	0	0	0	0	0	64.62	0	0	13.2
2014	9	22	12	21	2	35	0	0	0	0	0	0	0	64.63	0	0	13.2
2014	9	22	12	31	2	34	0	0	0	0	0	0	0	64.67	0	0	13.2
2014	9	22	12	41	2	36	0	0	0	0	0	0	0	64.69	0	0	13.2
2014	9	22	12	51	2	36	0	0	0	0	0	0	0	64.71	0	0	13.2
2014	9	22	13	1	2	35	0	0	0	0	0	0	0	64.72	0	0	13.2
2014	9	22	13	11	2	35	0	0	0	0	0	0	0	64.74	0	0	13.2
2014	9	22	13	21	2	35	0	0	0	0	0	0	0	64.74	0	0	13.2
2014	9	22	13	31	2	36	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	22	13	41	2	35	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	22	13	51	2	35	0	0	0	0	0	0	0	64.78	0	0	13.2
2014	9	22	14	1	2	35	0	0	0	0	0	0	0	64.78	0	0	13.2
2014	9	22	14	11	2	35	0	0	0	0	0	0	0	64.78	0	0	13.2
2014	9	22	14	21	2	35	0	0	0	0	0	0	0	64.8	0	0	13.2
2014	9	22	14	31	2	35	0	0	0	0	0	0	0	64.8	0	0	13.2
2014	9	22	14	41	2	35	0	0	0	0	0	0	0	64.8	0	0	13.2
2014	9	22	14	51	2	35	0	0	0	0	0	0	0	64.8	0	0	13.2
2014	9	22	15	1	2	35	0	0	0	0	0	0	0	64.8	0	0	13
2014	9	22	15	11	2	35	0	0	0	0	0	0	0	64.78	0	0	13
2014	9	22	15	21	2	35	0	0	0	0	0	0	0	64.78	0	0	13
2014	9	22	15	31	2	35	0	0	0	0	0	0	0	64.78	0	0	13
2014	9	22	15	41	2	35	0	0	0	0	0	0	0	64.74	0	0	13
2014	9	22	15	51	2	35	0	0	0	0	0	0	0	64.74	0	0	13
2014	9	22	16	1	2	35	0	0	0	0	0	0	0	64.72	0	0	13
2014	9	22	16	11	2	35	0	0	0	0	0	0	0	64.71	0	0	13
2014	9	22	16	21	2	35	0	0	0	0	0	0	0	64.71	0	0	13
2014	9	22	16	31	2	35	0	0	0	0	0	0	0	64.69	0	0	13
2014	9	22	16	41	2	35	0	0	0	0	0	0	0	64.69	0	0	13
2014	9	22	16	51	2	34	0	0	0	0	0	0	0	64.67	0	0	13
2014	9	22	17	1	2	34	0	0	0	0	0	0	0	64.67	0	0	12.6
2014	9	22	17	11	2	36	0	0	0	0	0	0	0	64.65	0	0	12.2
2014	9	22	17	21	2	36	0	0	0	0	0	0	0	64.63	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	17	31	2	35	0	0	0	0	0	0	0	64.63	0	0	12
2014	9	22	17	41	2	35	0	0	0	0	0	0	0	64.63	0	0	12
2014	9	22	17	51	2	35	0	0	0	0	0	0	0	64.63	0	0	12
2014	9	22	18	1	2	35	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	22	18	11	2	35	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	22	18	21	2	35	0	0	0	0	0	0	0	64.67	0	0	12
2014	9	22	18	31	2	34	0	0	0	0	0	0	0	64.69	0	0	12
2014	9	22	18	41	2	36	0	0	0	0	0	0	0	64.69	0	0	12
2014	9	22	18	51	2	36	0	0	0	0	0	0	0	64.71	0	0	12
2014	9	22	19	1	2	35	0	0	0	0	0	0	0	64.72	0	0	12
2014	9	22	19	11	2	35	0	0	0	0	0	0	0	64.74	0	0	12
2014	9	22	19	21	2	35	0	0	0	0	0	0	0	64.76	0	0	12
2014	9	22	19	31	2	34	0	0	0	0	0	0	0	64.78	0	0	12
2014	9	22	19	41	2	34	0	0	0	0	0	0	0	64.8	0	0	12
2014	9	22	19	51	2	35	0	0	0	0	0	0	0	64.81	0	0	12
2014	9	22	20	1	2	35	0	0	0	0	0	0	0	64.83	0	0	12
2014	9	22	20	11	2	35	0	0	0	0	0	0	0	64.85	0	0	12
2014	9	22	20	21	2	36	0	0	0	0	0	0	0	64.87	0	0	12
2014	9	22	20	31	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8
2014	9	22	20	41	2	35	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	22	20	51	2	35	0	0	0	0	0	0	0	64.94	0	0	12
2014	9	22	21	1	2	35	0	0	0	0	0	0	0	64.96	0	0	11.8
2014	9	22	21	11	2	35	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	22	21	21	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	22	21	31	2	35	0	0	0	0	0	0	0	65.01	0	0	11.8
2014	9	22	21	41	2	35	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	22	21	51	2	35	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	22	22	1	2	35	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	22	22	11	2	35	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	22	22	21	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	22	31	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	22	41	2	34	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	22	51	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	23	1	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	23	11	2	35	0	0	0	0	0	0	0	65.07	0	0	11.8
2014	9	22	23	21	2	35	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	22	23	31	2	35	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	22	23	41	2	36	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	22	23	51	2	35	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	23	0	1	2	35	0	0	0	0	0	0	0	65.01	0	0	11.8
2014	9	23	0	11	2	35	0	0	0	0	0	0	0	64.99	0	0	11.8
2014	9	23	0	21	2	36	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	23	0	31	2	35	0	0	0	0	0	0	0	64.96	0	0	11.6
2014	9	23	0	41	2	34	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	23	0	51	2	35	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	23	1	1	2	35	0	0	0	0	0	0	0	64.89	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	1	11	2	35	0	0	0	0	0	0	0	64.85	0	0	11.8
2014	9	23	1	21	2	35	0	0	0	0	0	0	0	64.83	0	0	11.8
2014	9	23	1	31	2	35	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	23	1	41	2	35	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	23	1	51	2	35	0	0	0	0	0	0	0	64.74	0	0	11.8
2014	9	23	2	1	2	34	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	23	2	11	2	35	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	23	2	21	2	35	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	23	2	31	2	34	0	0	0	0	0	0	0	64.6	0	0	11.8
2014	9	23	2	41	2	36	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	23	2	51	2	35	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	23	3	1	2	35	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	23	3	11	2	35	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	23	3	21	2	35	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	23	3	31	2	35	0	0	0	0	0	0	0	64.38	0	0	11.6
2014	9	23	3	41	2	35	0	0	0	0	0	0	0	64.36	0	0	11.4
2014	9	23	3	51	2	35	0	0	0	0	0	0	0	64.33	0	0	11.6
2014	9	23	4	1	2	35	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	23	4	11	2	35	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	23	4	21	2	35	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	23	4	31	2	35	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	23	4	41	2	36	0	0	0	0	0	0	0	64.17	0	0	11.6
2014	9	23	4	51	2	35	0	0	0	0	0	0	0	64.15	0	0	11.6
2014	9	23	5	1	2	35	0	0	0	0	0	0	0	64.11	0	0	11.6
2014	9	23	5	11	2	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	23	5	21	2	35	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	23	5	31	2	35	0	0	0	0	0	0	0	64	0	0	11.6
2014	9	23	5	41	2	34	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	23	5	51	2	35	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	23	6	1	2	35	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	23	6	11	2	35	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	23	6	21	2	35	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	23	6	31	2	35	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	23	6	41	2	35	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	23	6	51	2	35	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	23	7	1	2	35	0	0	0	0	0	0	0	63.72	0	0	11.6
2014	9	23	7	11	2	35	0	0	0	0	0	0	0	63.7	0	0	11.6
2014	9	23	7	21	2	35	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	23	7	31	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	23	7	41	2	36	0	0	0	0	0	0	0	63.61	0	0	12.2
2014	9	23	7	51	2	35	0	0	0	0	0	0	0	63.57	0	0	12.4
2014	9	23	8	1	2	35	0	0	0	0	0	0	0	63.57	0	0	12.6
2014	9	23	8	11	2	36	0	0	0	0	0	0	0	63.57	0	0	12.8
2014	9	23	8	21	2	35	0	0	0	0	0	0	0	63.55	0	0	13
2014	9	23	8	31	2	35	0	0	0	0	0	0	0	63.57	0	0	13
2014	9	23	8	41	2	35	0	0	0	0	0	0	0	63.57	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	8	51	2	35	0	0	0	0	0	0	0	63.61	0	0	13.2
2014	9	23	9	1	2	36	0	0	0	0	0	0	0	63.63	0	0	13.2
2014	9	23	9	11	2	35	0	0	0	0	0	0	0	63.64	0	0	13.2
2014	9	23	9	21	2	35	0	0	0	0	0	0	0	63.66	0	0	13.2
2014	9	23	9	31	2	36	0	0	0	0	0	0	0	63.68	0	0	13.2
2014	9	23	9	41	2	36	0	0	0	0	0	0	0	63.72	0	0	13.2
2014	9	23	9	51	2	35	0	0	0	0	0	0	0	63.73	0	0	13.2
2014	9	23	10	1	2	35	0	0	0	0	0	0	0	63.77	0	0	13.2
2014	9	23	10	11	2	36	0	0	0	0	0	0	0	63.81	0	0	13.2
2014	9	23	10	21	2	35	0	0	0	0	0	0	0	63.84	0	0	13.2
2014	9	23	10	31	2	36	0	0	0	0	0	0	0	63.88	0	0	13.2
2014	9	23	10	41	2	36	0	0	0	0	0	0	0	63.9	0	0	13.2
2014	9	23	10	51	2	35	0	0	0	0	0	0	0	63.95	0	0	13.2
2014	9	23	11	1	2	35	0	0	0	0	0	0	0	63.99	0	0	13.2
2014	9	23	11	11	2	35	0	0	0	0	0	0	0	64.02	0	0	13.2
2014	9	23	11	21	2	35	0	0	0	0	0	0	0	64.06	0	0	13.2
2014	9	23	11	31	2	36	0	0	0	0	0	0	0	64.08	0	0	13.2
2014	9	23	11	41	2	35	0	0	0	0	0	0	0	64.09	0	0	13.2
2014	9	23	11	51	2	35	0	0	0	0	0	0	0	64.11	0	0	13.2
2014	9	23	12	1	2	35	0	0	0	0	0	0	0	64.15	0	0	13.2
2014	9	23	12	11	2	35	0	0	0	0	0	0	0	64.17	0	0	13.2
2014	9	23	12	21	2	35	0	0	0	0	0	0	0	64.2	0	0	13.2
2014	9	23	12	31	2	35	0	0	0	0	0	0	0	64.26	0	0	13.2
2014	9	23	12	41	2	35	0	0	0	0	0	0	0	64.26	0	0	13.2
2014	9	23	12	51	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	13	1	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	13	11	2	35	0	0	0	0	0	0	0	64.29	0	0	13.2
2014	9	23	13	21	2	36	0	0	0	0	0	0	0	64.29	0	0	13.2
2014	9	23	13	31	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	13	41	2	35	0	0	0	0	0	0	0	64.29	0	0	13.2
2014	9	23	13	51	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	14	1	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	14	11	2	35	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	23	14	21	2	35	0	0	0	0	0	0	0	64.26	0	0	13.2
2014	9	23	14	31	2	35	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	23	14	41	2	35	0	0	0	0	0	0	0	64.22	0	0	13
2014	9	23	14	51	2	35	0	0	0	0	0	0	0	64.22	0	0	13
2014	9	23	15	1	2	36	0	0	0	0	0	0	0	64.2	0	0	13
2014	9	23	15	11	2	36	0	0	0	0	0	0	0	64.18	0	0	13
2014	9	23	15	21	2	35	0	0	0	0	0	0	0	64.17	0	0	13
2014	9	23	15	31	2	35	0	0	0	0	0	0	0	64.11	0	0	13
2014	9	23	15	41	2	35	0	0	0	0	0	0	0	64.09	0	0	13
2014	9	23	15	51	2	35	0	0	0	0	0	0	0	64.09	0	0	13
2014	9	23	16	1	2	35	0	0	0	0	0	0	0	64.08	0	0	13
2014	9	23	16	11	2	35	0	0	0	0	0	0	0	64.06	0	0	13
2014	9	23	16	21	2	35	0	0	0	0	0	0	0	64.04	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	16	31	2	35	0	0	0	0	0	0	0	64.02	0	0	13
2014	9	23	16	41	2	36	0	0	0	0	0	0	0	64.02	0	0	13
2014	9	23	16	51	2	36	0	0	0	0	0	0	0	64	0	0	13
2014	9	23	17	1	2	35	0	0	0	0	0	0	0	63.99	0	0	12.6
2014	9	23	17	11	2	35	0	0	0	0	0	0	0	63.99	0	0	12.2
2014	9	23	17	21	2	36	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	23	17	31	2	35	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	23	17	41	2	35	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	23	17	51	2	35	0	0	0	0	0	0	0	63.93	0	0	12
2014	9	23	18	1	2	35	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	23	18	11	2	36	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	23	18	21	2	35	0	0	0	0	0	0	0	63.95	0	0	12
2014	9	23	18	31	2	35	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	23	18	41	2	36	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	23	18	51	2	35	0	0	0	0	0	0	0	63.97	0	0	12
2014	9	23	19	1	2	35	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	23	19	11	2	36	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	23	19	21	2	35	0	0	0	0	0	0	0	64	0	0	12
2014	9	23	19	31	2	35	0	0	0	0	0	0	0	64.02	0	0	12
2014	9	23	19	41	2	35	0	0	0	0	0	0	0	64.02	0	0	12
2014	9	23	19	51	2	35	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	23	20	1	2	35	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	23	20	11	2	35	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	23	20	21	2	35	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	23	20	31	2	35	0	0	0	0	0	0	0	64.08	0	0	11.8
2014	9	23	20	41	2	35	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	23	20	51	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	1	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	11	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	21	2	34	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	31	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	41	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	21	51	2	35	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	23	22	1	2	36	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	23	22	11	2	36	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	22	21	2	35	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	22	31	2	36	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	23	22	41	2	35	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	23	22	51	2	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	23	23	1	2	35	0	0	0	0	0	0	0	64.09	0	0	11.6
2014	9	23	23	11	2	35	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	23	23	21	2	36	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	23	23	31	2	34	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	23	23	41	2	35	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	23	23	51	2	35	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	24	0	1	2	35	0	0	0	0	0	0	0	63.99	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	0	11	2	36	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	24	0	21	2	35	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	24	0	31	2	35	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	24	0	41	2	35	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	24	0	51	2	35	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	24	1	1	2	36	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	24	1	11	2	35	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	24	1	21	2	34	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	24	1	31	2	35	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	24	1	41	2	35	0	0	0	0	0	0	0	63.72	0	0	11.4
2014	9	24	1	51	2	35	0	0	0	0	0	0	0	63.68	0	0	11.4
2014	9	24	2	1	2	36	0	0	0	0	0	0	0	63.64	0	0	11.4
2014	9	24	2	11	2	36	0	0	0	0	0	0	0	63.61	0	0	11.4
2014	9	24	2	21	2	36	0	0	0	0	0	0	0	63.57	0	0	11.4
2014	9	24	2	31	2	36	0	0	0	0	0	0	0	63.54	0	0	11.4
2014	9	24	2	41	2	36	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	24	2	51	2	35	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	24	3	1	2	35	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	24	3	11	2	36	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	24	3	21	2	35	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	24	3	31	2	36	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	24	3	41	2	36	0	0	0	0	0	0	0	63.27	0	0	11.4
2014	9	24	3	51	2	35	0	0	0	0	0	0	0	63.25	0	0	11.4
2014	9	24	4	1	2	35	0	0	0	0	0	0	0	63.21	0	0	11.4
2014	9	24	4	11	2	35	0	0	0	0	0	0	0	63.18	0	0	11.4
2014	9	24	4	21	2	35	0	0	0	0	0	0	0	63.14	0	0	11.4
2014	9	24	4	31	2	35	0	0	0	0	0	0	0	63.1	0	0	11.4
2014	9	24	4	41	2	35	0	0	0	0	0	0	0	63.09	0	0	11.2
2014	9	24	4	51	2	35	0	0	0	0	0	0	0	63.05	0	0	11.2
2014	9	24	5	1	2	35	0	0	0	0	0	0	0	63	0	0	11.2
2014	9	24	5	11	2	36	0	0	0	0	0	0	0	62.98	0	0	11.2
2014	9	24	5	21	2	35	0	0	0	0	0	0	0	62.96	0	0	11.2
2014	9	24	5	31	2	35	0	0	0	0	0	0	0	62.92	0	0	11.2
2014	9	24	5	41	2	36	0	0	0	0	0	0	0	62.89	0	0	11.2
2014	9	24	5	51	2	35	0	0	0	0	0	0	0	62.85	0	0	11.2
2014	9	24	6	1	2	36	0	0	0	0	0	0	0	62.83	0	0	11.2
2014	9	24	6	11	2	35	0	0	0	0	0	0	0	62.78	0	0	11.2
2014	9	24	6	21	2	35	0	0	0	0	0	0	0	62.74	0	0	11.2
2014	9	24	6	31	2	35	0	0	0	0	0	0	0	62.73	0	0	11.2
2014	9	24	6	41	2	35	0	0	0	0	0	0	0	62.67	0	0	11.2
2014	9	24	6	51	2	36	0	0	0	0	0	0	0	62.64	0	0	11.2
2014	9	24	7	1	2	35	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	24	7	11	2	35	0	0	0	0	0	0	0	62.58	0	0	11.4
2014	9	24	7	21	2	35	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	24	7	31	2	35	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	24	7	41	2	35	0	0	0	0	0	0	0	62.46	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	7	51	2	35	0	0	0	0	0	0	0	62.44	0	0	13
2014	9	24	8	1	2	35	0	0	0	0	0	0	0	62.42	0	0	13
2014	9	24	8	11	2	35	0	0	0	0	0	0	0	62.42	0	0	13.2
2014	9	24	8	21	2	35	0	0	0	0	0	0	0	62.4	0	0	13.2
2014	9	24	8	31	2	36	0	0	0	0	0	0	0	62.38	0	0	13.4
2014	9	24	8	41	2	35	0	0	0	0	0	0	0	62.4	0	0	13.4
2014	9	24	8	51	2	35	0	0	0	0	0	0	0	62.42	0	0	13.4
2014	9	24	9	1	2	35	0	0	0	0	0	0	0	62.44	0	0	13.4
2014	9	24	9	11	2	36	0	0	0	0	0	0	0	62.44	0	0	13.4
2014	9	24	9	21	2	36	0	0	0	0	0	0	0	62.47	0	0	13.2
2014	9	24	9	31	2	35	0	0	0	0	0	0	0	62.49	0	0	13.2
2014	9	24	9	41	2	36	0	0	0	0	0	0	0	62.51	0	0	13.2
2014	9	24	9	51	2	35	0	0	0	0	0	0	0	62.55	0	0	13.2
2014	9	24	10	1	2	35	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	24	10	11	2	36	0	0	0	0	0	0	0	62.6	0	0	13.2
2014	9	24	10	21	2	35	0	0	0	0	0	0	0	62.64	0	0	13.2
2014	9	24	10	31	2	35	0	0	0	0	0	0	0	62.65	0	0	13.2
2014	9	24	10	41	2	35	0	0	0	0	0	0	0	62.71	0	0	13.2
2014	9	24	10	51	2	36	0	0	0	0	0	0	0	62.74	0	0	13.2
2014	9	24	11	1	2	35	0	0	0	0	0	0	0	62.8	0	0	13.2
2014	9	24	11	11	2	35	0	0	0	0	0	0	0	62.83	0	0	13.2
2014	9	24	11	21	2	35	0	0	0	0	0	0	0	62.83	0	0	13.2
2014	9	24	11	31	2	35	0	0	0	0	0	0	0	62.89	0	0	13.2
2014	9	24	11	41	2	35	0	0	0	0	0	0	0	62.91	0	0	13.2
2014	9	24	11	51	2	35	0	0	0	0	0	0	0	62.96	0	0	13.2
2014	9	24	12	1	2	36	0	0	0	0	0	0	0	62.98	0	0	13.2
2014	9	24	12	11	2	36	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	24	12	21	2	36	0	0	0	0	0	0	0	63	0	0	13
2014	9	24	12	31	2	36	0	0	0	0	0	0	0	63.03	0	0	13
2014	9	24	12	41	2	35	0	0	0	0	0	0	0	63.05	0	0	13
2014	9	24	12	51	2	35	0	0	0	0	0	0	0	63.05	0	0	13
2014	9	24	13	1	2	35	0	0	0	0	0	0	0	63.07	0	0	13
2014	9	24	13	11	2	35	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	24	13	21	2	34	0	0	0	0	0	0	0	63.07	0	0	13
2014	9	24	13	31	2	35	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	24	13	41	2	35	0	0	0	0	0	0	0	63.09	0	0	13.2
2014	9	24	13	51	2	35	0	0	0	0	0	0	0	63.1	0	0	13
2014	9	24	14	1	2	36	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	24	14	11	2	36	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	24	14	21	2	35	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	24	14	31	2	35	0	0	0	0	0	0	0	63.07	0	0	13
2014	9	24	14	41	2	35	0	0	0	0	0	0	0	63.05	0	0	13
2014	9	24	14	51	2	35	0	0	0	0	0	0	0	63.03	0	0	13
2014	9	24	15	1	2	35	0	0	0	0	0	0	0	63.01	0	0	13
2014	9	24	15	11	2	35	0	0	0	0	0	0	0	63	0	0	13
2014	9	24	15	21	2	36	0	0	0	0	0	0	0	63	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	15	31	2	35	0	0	0	0	0	0	0	62.96	0	0	13
2014	9	24	15	41	2	35	0	0	0	0	0	0	0	62.94	0	0	13
2014	9	24	15	51	2	35	0	0	0	0	0	0	0	62.92	0	0	13
2014	9	24	16	1	2	35	0	0	0	0	0	0	0	62.91	0	0	13
2014	9	24	16	11	2	35	0	0	0	0	0	0	0	62.89	0	0	13
2014	9	24	16	21	2	35	0	0	0	0	0	0	0	62.87	0	0	13
2014	9	24	16	31	2	35	0	0	0	0	0	0	0	62.83	0	0	13
2014	9	24	16	41	2	35	0	0	0	0	0	0	0	62.82	0	0	13
2014	9	24	16	51	2	35	0	0	0	0	0	0	0	62.8	0	0	13
2014	9	24	17	1	2	35	0	0	0	0	0	0	0	62.78	0	0	12.8
2014	9	24	17	11	2	35	0	0	0	0	0	0	0	62.78	0	0	12.2
2014	9	24	17	21	2	35	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	24	17	31	2	35	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	24	17	41	2	35	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	24	17	51	2	35	0	0	0	0	0	0	0	62.74	0	0	12
2014	9	24	18	1	2	35	0	0	0	0	0	0	0	62.74	0	0	12
2014	9	24	18	11	2	35	0	0	0	0	0	0	0	62.74	0	0	12
2014	9	24	18	21	2	35	0	0	0	0	0	0	0	62.74	0	0	12
2014	9	24	18	31	2	35	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	24	18	41	2	35	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	24	18	51	2	35	0	0	0	0	0	0	0	62.78	0	0	12
2014	9	24	19	1	2	36	0	0	0	0	0	0	0	62.78	0	0	12
2014	9	24	19	11	2	35	0	0	0	0	0	0	0	62.8	0	0	12
2014	9	24	19	21	2	36	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	24	19	31	2	36	0	0	0	0	0	0	0	62.82	0	0	11.8
2014	9	24	19	41	2	35	0	0	0	0	0	0	0	62.83	0	0	11.8
2014	9	24	19	51	2	35	0	0	0	0	0	0	0	62.85	0	0	11.8
2014	9	24	20	1	2	35	0	0	0	0	0	0	0	62.87	0	0	11.8
2014	9	24	20	11	2	35	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	24	20	21	2	35	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	24	20	31	2	36	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	24	20	41	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	24	20	51	2	35	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	24	21	1	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	24	21	11	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	24	21	21	2	36	0	0	0	0	0	0	0	63	0	0	11.8
2014	9	24	21	31	2	36	0	0	0	0	0	0	0	63.01	0	0	11.8
2014	9	24	21	41	2	35	0	0	0	0	0	0	0	63.03	0	0	11.8
2014	9	24	21	51	2	35	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	24	22	1	2	36	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	24	22	11	2	36	0	0	0	0	0	0	0	63.07	0	0	11.8
2014	9	24	22	21	2	35	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	24	22	31	2	35	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	24	22	41	2	35	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	24	22	51	2	36	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	24	23	1	2	36	0	0	0	0	0	0	0	63.12	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	23	11	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	24	23	21	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	24	23	31	2	36	0	0	0	0	0	0	0	63.14	0	0	11.8
2014	9	24	23	41	2	36	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	24	23	51	2	35	0	0	0	0	0	0	0	63.14	0	0	11.8
2014	9	25	0	1	2	35	0	0	0	0	0	0	0	63.14	0	0	11.8
2014	9	25	0	11	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	25	0	21	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	25	0	31	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	25	0	41	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	25	0	51	2	35	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	25	1	1	2	36	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	25	1	11	2	35	0	0	0	0	0	0	0	63.07	0	0	11.8
2014	9	25	1	21	2	35	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	25	1	31	2	35	0	0	0	0	0	0	0	63.03	0	0	11.8
2014	9	25	1	41	2	34	0	0	0	0	0	0	0	63.01	0	0	11.8
2014	9	25	1	51	2	35	0	0	0	0	0	0	0	63	0	0	11.8
2014	9	25	2	1	2	36	0	0	0	0	0	0	0	63	0	0	11.8
2014	9	25	2	11	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	25	2	21	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	25	2	31	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	25	2	41	2	36	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	25	2	51	2	35	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	25	3	1	2	36	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	25	3	11	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	25	3	21	2	36	0	0	0	0	0	0	0	62.91	0	0	11.8
2014	9	25	3	31	2	35	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	25	3	41	2	36	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	25	3	51	2	35	0	0	0	0	0	0	0	62.87	0	0	11.8
2014	9	25	4	1	2	35	0	0	0	0	0	0	0	62.85	0	0	11.8
2014	9	25	4	11	2	35	0	0	0	0	0	0	0	62.85	0	0	11.8
2014	9	25	4	21	2	35	0	0	0	0	0	0	0	62.83	0	0	11.8
2014	9	25	4	31	2	35	0	0	0	0	0	0	0	62.82	0	0	11.8
2014	9	25	4	41	2	35	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	25	4	51	2	35	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	25	5	1	2	35	0	0	0	0	0	0	0	62.76	0	0	11.8
2014	9	25	5	11	2	36	0	0	0	0	0	0	0	62.74	0	0	11.8
2014	9	25	5	21	2	36	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	25	5	31	2	35	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	25	5	41	2	35	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	25	5	51	2	36	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	25	6	1	2	36	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	25	6	11	2	35	0	0	0	0	0	0	0	62.65	0	0	11.6
2014	9	25	6	21	2	36	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	25	6	31	2	35	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	25	6	41	2	35	0	0	0	0	0	0	0	62.62	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	6	51	2	35	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	25	7	1	2	35	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	25	7	11	2	35	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	25	7	21	2	35	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	25	7	31	2	35	0	0	0	0	0	0	0	62.6	0	0	11.8
2014	9	25	7	41	2	36	0	0	0	0	0	0	0	62.6	0	0	12.2
2014	9	25	7	51	2	35	0	0	0	0	0	0	0	62.6	0	0	12.4
2014	9	25	8	1	2	36	0	0	0	0	0	0	0	62.6	0	0	12.6
2014	9	25	8	11	2	35	0	0	0	0	0	0	0	62.62	0	0	12.6
2014	9	25	8	21	2	35	0	0	0	0	0	0	0	62.62	0	0	12.8
2014	9	25	8	31	2	35	0	0	0	0	0	0	0	62.64	0	0	12.8
2014	9	25	8	41	2	36	0	0	0	0	0	0	0	62.65	0	0	13
2014	9	25	8	51	2	36	0	0	0	0	0	0	0	62.67	0	0	13
2014	9	25	9	1	2	35	0	0	0	0	0	0	0	62.67	0	0	13
2014	9	25	9	11	2	36	0	0	0	0	0	0	0	62.69	0	0	13.2
2014	9	25	9	21	2	35	0	0	0	0	0	0	0	62.69	0	0	13.2
2014	9	25	9	31	2	35	0	0	0	0	0	0	0	62.71	0	0	13.2
2014	9	25	9	41	2	35	0	0	0	0	0	0	0	62.73	0	0	13.2
2014	9	25	9	51	2	35	0	0	0	0	0	0	0	62.73	0	0	13.2
2014	9	25	10	1	2	35	0	0	0	0	0	0	0	62.73	0	0	13.2
2014	9	25	10	11	2	35	0	0	0	0	0	0	0	62.74	0	0	13
2014	9	25	10	21	2	36	0	0	0	0	0	0	0	62.74	0	0	13
2014	9	25	10	31	2	35	0	0	0	0	0	0	0	62.78	0	0	13.2
2014	9	25	10	41	2	36	0	0	0	0	0	0	0	62.82	0	0	13.2
2014	9	25	10	51	2	34	0	0	0	0	0	0	0	62.83	0	0	13.2
2014	9	25	11	1	2	35	0	0	0	0	0	0	0	62.85	0	0	13.2
2014	9	25	11	11	2	35	0	0	0	0	0	0	0	62.89	0	0	13.2
2014	9	25	11	21	2	35	0	0	0	0	0	0	0	62.91	0	0	13.2
2014	9	25	11	31	2	35	0	0	0	0	0	0	0	62.96	0	0	13.2
2014	9	25	11	41	2	35	0	0	0	0	0	0	0	62.98	0	0	13.2
2014	9	25	11	51	2	35	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	25	12	1	2	36	0	0	0	0	0	0	0	63.05	0	0	13.2
2014	9	25	12	11	2	35	0	0	0	0	0	0	0	63.05	0	0	13.2
2014	9	25	12	21	2	35	0	0	0	0	0	0	0	63.09	0	0	13.2
2014	9	25	12	31	2	35	0	0	0	0	0	0	0	63.1	0	0	13.2
2014	9	25	12	41	2	35	0	0	0	0	0	0	0	63.14	0	0	13.2
2014	9	25	12	51	2	35	0	0	0	0	0	0	0	63.18	0	0	13.2
2014	9	25	13	1	2	35	0	0	0	0	0	0	0	63.19	0	0	13.2
2014	9	25	13	11	2	36	0	0	0	0	0	0	0	63.23	0	0	13.2
2014	9	25	13	21	2	36	0	0	0	0	0	0	0	63.27	0	0	13.2
2014	9	25	13	31	2	36	0	0	0	0	0	0	0	63.28	0	0	13.2
2014	9	25	13	41	2	35	0	0	0	0	0	0	0	63.3	0	0	13.2
2014	9	25	13	51	2	35	0	0	0	0	0	0	0	63.34	0	0	13.2
2014	9	25	14	1	2	35	0	0	0	0	0	0	0	63.34	0	0	13.2
2014	9	25	14	11	2	35	0	0	0	0	0	0	0	63.36	0	0	13.2
2014	9	25	14	21	2	36	0	0	0	0	0	0	0	63.36	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	14	31	2	35	0	0	0	0	0	0	0	63.36	0	0	13.2
2014	9	25	14	41	2	34	0	0	0	0	0	0	0	63.37	0	0	13.2
2014	9	25	14	51	2	35	0	0	0	0	0	0	0	63.36	0	0	13.2
2014	9	25	15	1	2	35	0	0	0	0	0	0	0	63.34	0	0	12.8
2014	9	25	15	11	2	36	0	0	0	0	0	0	0	63.34	0	0	13.2
2014	9	25	15	21	2	35	0	0	0	0	0	0	0	63.34	0	0	13.2
2014	9	25	15	31	2	36	0	0	0	0	0	0	0	63.32	0	0	12.8
2014	9	25	15	41	2	35	0	0	0	0	0	0	0	63.32	0	0	13.2
2014	9	25	15	51	2	36	0	0	0	0	0	0	0	63.32	0	0	13.2
2014	9	25	16	1	2	36	0	0	0	0	0	0	0	63.3	0	0	13.2
2014	9	25	16	11	2	35	0	0	0	0	0	0	0	63.3	0	0	13.2
2014	9	25	16	21	2	35	0	0	0	0	0	0	0	63.28	0	0	13.2
2014	9	25	16	31	2	35	0	0	0	0	0	0	0	63.27	0	0	13.2
2014	9	25	16	41	2	36	0	0	0	0	0	0	0	63.27	0	0	13.2
2014	9	25	16	51	2	35	0	0	0	0	0	0	0	63.25	0	0	13.2
2014	9	25	17	1	2	36	0	0	0	0	0	0	0	63.25	0	0	12.8
2014	9	25	17	11	2	36	0	0	0	0	0	0	0	63.25	0	0	12.2
2014	9	25	17	21	2	35	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	25	17	31	2	35	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	17	41	2	35	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	17	51	2	35	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	18	1	2	35	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	18	11	2	36	0	0	0	0	0	0	0	63.21	0	0	12
2014	9	25	18	21	2	35	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	25	18	31	2	36	0	0	0	0	0	0	0	63.23	0	0	12
2014	9	25	18	41	2	36	0	0	0	0	0	0	0	63.25	0	0	12
2014	9	25	18	51	2	35	0	0	0	0	0	0	0	63.25	0	0	12
2014	9	25	19	1	2	35	0	0	0	0	0	0	0	63.27	0	0	12
2014	9	25	19	11	2	35	0	0	0	0	0	0	0	63.27	0	0	12
2014	9	25	19	21	2	36	0	0	0	0	0	0	0	63.28	0	0	12
2014	9	25	19	31	2	35	0	0	0	0	0	0	0	63.3	0	0	12
2014	9	25	19	41	2	35	0	0	0	0	0	0	0	63.32	0	0	12
2014	9	25	19	51	2	35	0	0	0	0	0	0	0	63.34	0	0	12
2014	9	25	20	1	2	35	0	0	0	0	0	0	0	63.36	0	0	12
2014	9	25	20	11	2	35	0	0	0	0	0	0	0	63.37	0	0	11.8
2014	9	25	20	21	2	35	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	25	20	31	2	36	0	0	0	0	0	0	0	63.43	0	0	11.8
2014	9	25	20	41	2	35	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	25	20	51	2	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	25	21	1	2	35	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	25	21	11	2	35	0	0	0	0	0	0	0	63.5	0	0	11.8
2014	9	25	21	21	2	36	0	0	0	0	0	0	0	63.52	0	0	11.8
2014	9	25	21	31	2	35	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	25	21	41	2	35	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	25	21	51	2	35	0	0	0	0	0	0	0	63.55	0	0	11.8
2014	9	25	22	1	2	36	0	0	0	0	0	0	0	63.57	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	22	11	2	36	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	25	22	21	2	36	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	25	22	31	2	35	0	0	0	0	0	0	0	63.61	0	0	11.8
2014	9	25	22	41	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	25	22	51	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	25	23	1	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	25	23	11	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	25	23	21	2	35	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	25	23	31	2	35	0	0	0	0	0	0	0	63.66	0	0	11.8
2014	9	25	23	41	2	36	0	0	0	0	0	0	0	63.66	0	0	11.8
2014	9	25	23	51	2	35	0	0	0	0	0	0	0	63.66	0	0	11.8
2014	9	26	0	1	2	35	0	0	0	0	0	0	0	63.66	0	0	11.8
2014	9	26	0	11	2	35	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	26	0	21	2	35	0	0	0	0	0	0	0	63.66	0	0	11.8
2014	9	26	0	31	2	34	0	0	0	0	0	0	0	63.64	0	0	11.8
2014	9	26	0	41	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	26	0	51	2	35	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	26	1	1	2	35	0	0	0	0	0	0	0	63.61	0	0	11.8
2014	9	26	1	11	2	36	0	0	0	0	0	0	0	63.61	0	0	11.8
2014	9	26	1	21	2	35	0	0	0	0	0	0	0	63.59	0	0	11.8
2014	9	26	1	31	2	35	0	0	0	0	0	0	0	63.57	0	0	11.8
2014	9	26	1	41	2	35	0	0	0	0	0	0	0	63.55	0	0	11.8
2014	9	26	1	51	2	35	0	0	0	0	0	0	0	63.55	0	0	11.8
2014	9	26	2	1	2	35	0	0	0	0	0	0	0	63.52	0	0	11.8
2014	9	26	2	11	2	36	0	0	0	0	0	0	0	63.52	0	0	11.8
2014	9	26	2	21	2	35	0	0	0	0	0	0	0	63.5	0	0	11.8
2014	9	26	2	31	2	35	0	0	0	0	0	0	0	63.48	0	0	11.8
2014	9	26	2	41	2	35	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	26	2	51	2	35	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	26	3	1	2	35	0	0	0	0	0	0	0	63.43	0	0	11.8
2014	9	26	3	11	2	35	0	0	0	0	0	0	0	63.41	0	0	11.8
2014	9	26	3	21	2	35	0	0	0	0	0	0	0	63.39	0	0	11.8
2014	9	26	3	31	2	35	0	0	0	0	0	0	0	63.39	0	0	11.8
2014	9	26	3	41	2	35	0	0	0	0	0	0	0	63.37	0	0	11.8
2014	9	26	3	51	2	35	0	0	0	0	0	0	0	63.37	0	0	11.8
2014	9	26	4	1	2	36	0	0	0	0	0	0	0	63.34	0	0	11.8
2014	9	26	4	11	2	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	26	4	21	2	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	26	4	31	2	35	0	0	0	0	0	0	0	63.32	0	0	11.8
2014	9	26	4	41	2	36	0	0	0	0	0	0	0	63.3	0	0	11.8
2014	9	26	4	51	2	36	0	0	0	0	0	0	0	63.28	0	0	11.8
2014	9	26	5	1	2	36	0	0	0	0	0	0	0	63.27	0	0	11.8
2014	9	26	5	11	2	35	0	0	0	0	0	0	0	63.27	0	0	11.8
2014	9	26	5	21	2	36	0	0	0	0	0	0	0	63.25	0	0	11.8
2014	9	26	5	31	2	35	0	0	0	0	0	0	0	63.25	0	0	11.8
2014	9	26	5	41	2	36	0	0	0	0	0	0	0	63.23	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	5	51	2	36	0	0	0	0	0	0	0	63.19	0	0	11.8
2014	9	26	6	1	2	36	0	0	0	0	0	0	0	63.16	0	0	11.8
2014	9	26	6	11	2	35	0	0	0	0	0	0	0	63.16	0	0	11.8
2014	9	26	6	21	2	35	0	0	0	0	0	0	0	63.18	0	0	11.8
2014	9	26	6	31	2	35	0	0	0	0	0	0	0	63.16	0	0	11.8
2014	9	26	6	41	2	36	0	0	0	0	0	0	0	63.14	0	0	11.8
2014	9	26	6	51	2	36	0	0	0	0	0	0	0	63.14	0	0	11.8
2014	9	26	7	1	2	35	0	0	0	0	0	0	0	63.12	0	0	11.8
2014	9	26	7	11	2	35	0	0	0	0	0	0	0	63.1	0	0	11.8
2014	9	26	7	21	2	36	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	26	7	31	2	35	0	0	0	0	0	0	0	63.09	0	0	11.8
2014	9	26	7	41	2	35	0	0	0	0	0	0	0	63.07	0	0	12.2
2014	9	26	7	51	2	35	0	0	0	0	0	0	0	63.09	0	0	12.4
2014	9	26	8	1	2	35	0	0	0	0	0	0	0	63.09	0	0	12.6
2014	9	26	8	11	2	35	0	0	0	0	0	0	0	63.1	0	0	12.8
2014	9	26	8	21	2	35	0	0	0	0	0	0	0	63.12	0	0	12.8
2014	9	26	8	31	2	35	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	26	8	41	2	35	0	0	0	0	0	0	0	63.18	0	0	13
2014	9	26	8	51	2	35	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	26	9	1	2	35	0	0	0	0	0	0	0	63.21	0	0	13.2
2014	9	26	9	11	2	35	0	0	0	0	0	0	0	63.23	0	0	13.2
2014	9	26	9	21	2	35	0	0	0	0	0	0	0	63.25	0	0	13.2
2014	9	26	9	31	2	35	0	0	0	0	0	0	0	63.28	0	0	13.4
2014	9	26	9	41	2	35	0	0	0	0	0	0	0	63.28	0	0	13.4
2014	9	26	9	51	2	35	0	0	0	0	0	0	0	63.32	0	0	13.4
2014	9	26	10	1	2	35	0	0	0	0	0	0	0	63.36	0	0	13.4
2014	9	26	10	11	2	35	0	0	0	0	0	0	0	63.36	0	0	13.4
2014	9	26	10	21	2	35	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	26	10	31	2	35	0	0	0	0	0	0	0	63.43	0	0	13.2
2014	9	26	10	41	2	36	0	0	0	0	0	0	0	63.46	0	0	13.4
2014	9	26	10	51	2	36	0	0	0	0	0	0	0	63.48	0	0	13.4
2014	9	26	11	1	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	11	11	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	11	21	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	11	31	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	11	41	2	35	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	26	11	51	2	35	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	26	12	1	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	12	11	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	12	21	2	36	0	0	0	0	0	0	0	63.54	0	0	13.4
2014	9	26	12	31	2	36	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	26	12	41	2	35	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	12	51	2	36	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	26	13	1	2	35	0	0	0	0	0	0	0	63.48	0	0	13.4
2014	9	26	13	11	2	36	0	0	0	0	0	0	0	63.48	0	0	13.4
2014	9	26	13	21	2	35	0	0	0	0	0	0	0	63.46	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	13	31	2	36	0	0	0	0	0	0	0	63.48	0	0	13.4
2014	9	26	13	41	2	35	0	0	0	0	0	0	0	63.48	0	0	13.2
2014	9	26	13	51	2	35	0	0	0	0	0	0	0	63.46	0	0	13.2
2014	9	26	14	1	2	36	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	26	14	11	2	35	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	26	14	21	2	35	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	26	14	31	2	35	0	0	0	0	0	0	0	63.43	0	0	13.2
2014	9	26	14	41	2	35	0	0	0	0	0	0	0	63.43	0	0	13.2
2014	9	26	14	51	2	35	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	26	15	1	2	35	0	0	0	0	0	0	0	63.37	0	0	13.2
2014	9	26	15	11	2	36	0	0	0	0	0	0	0	63.36	0	0	13.2
2014	9	26	15	21	2	36	0	0	0	0	0	0	0	63.34	0	0	13.2
2014	9	26	15	31	2	35	0	0	0	0	0	0	0	63.32	0	0	13.2
2014	9	26	15	41	2	36	0	0	0	0	0	0	0	63.3	0	0	13.2
2014	9	26	15	51	2	35	0	0	0	0	0	0	0	63.27	0	0	13.2
2014	9	26	16	1	2	35	0	0	0	0	0	0	0	63.25	0	0	13.2
2014	9	26	16	11	2	36	0	0	0	0	0	0	0	63.25	0	0	13.2
2014	9	26	16	21	2	35	0	0	0	0	0	0	0	63.21	0	0	13.2
2014	9	26	16	31	2	35	0	0	0	0	0	0	0	63.19	0	0	13.2
2014	9	26	16	41	2	35	0	0	0	0	0	0	0	63.18	0	0	13.2
2014	9	26	16	51	2	36	0	0	0	0	0	0	0	63.16	0	0	13.2
2014	9	26	17	1	2	35	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	26	17	11	2	35	0	0	0	0	0	0	0	63.1	0	0	12.4
2014	9	26	17	21	2	35	0	0	0	0	0	0	0	63.09	0	0	12.2
2014	9	26	17	31	2	36	0	0	0	0	0	0	0	63.07	0	0	12
2014	9	26	17	41	2	35	0	0	0	0	0	0	0	63.05	0	0	12
2014	9	26	17	51	2	35	0	0	0	0	0	0	0	63.05	0	0	12
2014	9	26	18	1	2	35	0	0	0	0	0	0	0	63.03	0	0	12
2014	9	26	18	11	2	35	0	0	0	0	0	0	0	63.03	0	0	12
2014	9	26	18	21	2	35	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	26	18	31	2	35	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	26	18	41	2	35	0	0	0	0	0	0	0	63	0	0	12
2014	9	26	18	51	2	35	0	0	0	0	0	0	0	63	0	0	12
2014	9	26	19	1	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	19	11	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	19	21	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	19	31	2	36	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	19	41	2	36	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	19	51	2	35	0	0	0	0	0	0	0	62.96	0	0	12
2014	9	26	20	1	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	20	11	2	35	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	20	21	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	20	31	2	36	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	20	41	2	34	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	26	20	51	2	36	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	21	1	2	35	0	0	0	0	0	0	0	62.96	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	21	11	2	36	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	26	21	21	2	35	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	26	21	31	2	36	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	26	21	41	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	21	51	2	36	0	0	0	0	0	0	0	62.94	0	0	11.8
2014	9	26	22	1	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	22	11	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	22	21	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	22	31	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	22	41	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	22	51	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	23	1	2	35	0	0	0	0	0	0	0	62.92	0	0	11.8
2014	9	26	23	11	2	35	0	0	0	0	0	0	0	62.91	0	0	11.8
2014	9	26	23	21	2	36	0	0	0	0	0	0	0	62.91	0	0	11.8
2014	9	26	23	31	2	36	0	0	0	0	0	0	0	62.91	0	0	11.8
2014	9	26	23	41	2	35	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	26	23	51	2	36	0	0	0	0	0	0	0	62.87	0	0	11.8
2014	9	27	0	1	2	35	0	0	0	0	0	0	0	62.87	0	0	11.8
2014	9	27	0	11	2	35	0	0	0	0	0	0	0	62.85	0	0	11.8
2014	9	27	0	21	2	35	0	0	0	0	0	0	0	62.83	0	0	11.8
2014	9	27	0	31	2	36	0	0	0	0	0	0	0	62.83	0	0	11.8
2014	9	27	0	41	2	35	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	27	0	51	2	36	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	27	1	1	2	35	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	27	1	11	2	35	0	0	0	0	0	0	0	62.76	0	0	11.8
2014	9	27	1	21	2	36	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	27	1	31	2	35	0	0	0	0	0	0	0	62.69	0	0	11.8
2014	9	27	1	41	2	36	0	0	0	0	0	0	0	62.69	0	0	11.8
2014	9	27	1	51	2	35	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	27	2	1	2	35	0	0	0	0	0	0	0	62.62	0	0	11.8
2014	9	27	2	11	2	35	0	0	0	0	0	0	0	62.6	0	0	11.8
2014	9	27	2	21	2	35	0	0	0	0	0	0	0	62.56	0	0	11.8
2014	9	27	2	31	2	35	0	0	0	0	0	0	0	62.53	0	0	11.8
2014	9	27	2	41	2	35	0	0	0	0	0	0	0	62.49	0	0	11.8
2014	9	27	2	51	2	35	0	0	0	0	0	0	0	62.47	0	0	11.8
2014	9	27	3	1	2	35	0	0	0	0	0	0	0	62.42	0	0	11.8
2014	9	27	3	11	2	36	0	0	0	0	0	0	0	62.38	0	0	11.8
2014	9	27	3	21	2	35	0	0	0	0	0	0	0	62.35	0	0	11.8
2014	9	27	3	31	2	36	0	0	0	0	0	0	0	62.33	0	0	11.8
2014	9	27	3	41	2	35	0	0	0	0	0	0	0	62.29	0	0	11.8
2014	9	27	3	51	2	35	0	0	0	0	0	0	0	62.26	0	0	11.8
2014	9	27	4	1	2	35	0	0	0	0	0	0	0	62.22	0	0	11.8
2014	9	27	4	11	2	35	0	0	0	0	0	0	0	62.19	0	0	11.6
2014	9	27	4	21	2	35	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	27	4	31	2	35	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	27	4	41	2	35	0	0	0	0	0	0	0	62.1	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	4	51	2	35	0	0	0	0	0	0	0	62.04	0	0	11.6
2014	9	27	5	1	2	36	0	0	0	0	0	0	0	62.01	0	0	11.6
2014	9	27	5	11	2	35	0	0	0	0	0	0	0	61.97	0	0	11.6
2014	9	27	5	21	2	36	0	0	0	0	0	0	0	61.93	0	0	11.6
2014	9	27	5	31	2	36	0	0	0	0	0	0	0	61.88	0	0	11.6
2014	9	27	5	41	2	35	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	27	5	51	2	36	0	0	0	0	0	0	0	61.83	0	0	11.6
2014	9	27	6	1	2	35	0	0	0	0	0	0	0	61.79	0	0	11.6
2014	9	27	6	11	2	36	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	27	6	21	2	35	0	0	0	0	0	0	0	61.72	0	0	11.6
2014	9	27	6	31	2	35	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	27	6	41	2	36	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	27	6	51	2	36	0	0	0	0	0	0	0	61.63	0	0	11.6
2014	9	27	7	1	2	36	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	27	7	11	2	35	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	27	7	21	2	35	0	0	0	0	0	0	0	61.56	0	0	11.6
2014	9	27	7	31	2	36	0	0	0	0	0	0	0	61.54	0	0	11.6
2014	9	27	7	41	2	36	0	0	0	0	0	0	0	61.5	0	0	11.6
2014	9	27	7	51	2	35	0	0	0	0	0	0	0	61.48	0	0	11.8
2014	9	27	8	1	2	35	0	0	0	0	0	0	0	61.45	0	0	12.2
2014	9	27	8	11	2	36	0	0	0	0	0	0	0	61.47	0	0	12.6
2014	9	27	8	21	2	36	0	0	0	0	0	0	0	61.45	0	0	12.8
2014	9	27	8	31	2	35	0	0	0	0	0	0	0	61.45	0	0	13
2014	9	27	8	41	2	36	0	0	0	0	0	0	0	61.39	0	0	12.4
2014	9	27	8	51	2	35	0	0	0	0	0	0	0	61.39	0	0	13
2014	9	27	9	1	2	35	0	0	0	0	0	0	0	61.41	0	0	13.2
2014	9	27	9	11	2	35	0	0	0	0	0	0	0	61.43	0	0	13.4
2014	9	27	9	21	2	35	0	0	0	0	0	0	0	61.43	0	0	13.4
2014	9	27	9	31	2	36	0	0	0	0	0	0	0	61.45	0	0	13.6
2014	9	27	9	41	2	35	0	0	0	0	0	0	0	61.43	0	0	13.6
2014	9	27	9	51	2	36	0	0	0	0	0	0	0	61.45	0	0	13.6
2014	9	27	10	1	2	35	0	0	0	0	0	0	0	61.45	0	0	13.6
2014	9	27	10	11	2	35	0	0	0	0	0	0	0	61.47	0	0	13.6
2014	9	27	10	21	2	36	0	0	0	0	0	0	0	61.48	0	0	13.6
2014	9	27	10	31	2	36	0	0	0	0	0	0	0	61.48	0	0	13.6
2014	9	27	10	41	2	35	0	0	0	0	0	0	0	61.5	0	0	13.6
2014	9	27	10	51	2	36	0	0	0	0	0	0	0	61.52	0	0	13.6
2014	9	27	11	1	2	35	0	0	0	0	0	0	0	61.56	0	0	13.6
2014	9	27	11	11	2	35	0	0	0	0	0	0	0	61.56	0	0	13.6
2014	9	27	11	21	2	36	0	0	0	0	0	0	0	61.57	0	0	13.6
2014	9	27	11	31	2	35	0	0	0	0	0	0	0	61.59	0	0	13.6
2014	9	27	11	41	2	36	0	0	0	0	0	0	0	61.63	0	0	13.6
2014	9	27	11	51	2	35	0	0	0	0	0	0	0	61.63	0	0	13.6
2014	9	27	12	1	2	35	0	0	0	0	0	0	0	61.65	0	0	13.6
2014	9	27	12	11	2	35	0	0	0	0	0	0	0	61.65	0	0	13.6
2014	9	27	12	21	2	36	0	0	0	0	0	0	0	61.66	0	0	13.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	12	31	2	35	0	0	0	0	0	0	0	61.66	0	0	13.6
2014	9	27	12	41	2	35	0	0	0	0	0	0	0	61.66	0	0	13.4
2014	9	27	12	51	2	36	0	0	0	0	0	0	0	61.66	0	0	13.4
2014	9	27	13	1	2	35	0	0	0	0	0	0	0	61.66	0	0	13.4
2014	9	27	13	11	2	36	0	0	0	0	0	0	0	61.65	0	0	13.4
2014	9	27	13	21	2	35	0	0	0	0	0	0	0	61.63	0	0	13.4
2014	9	27	13	31	2	35	0	0	0	0	0	0	0	61.63	0	0	13.4
2014	9	27	13	41	2	36	0	0	0	0	0	0	0	61.61	0	0	13.4
2014	9	27	13	51	2	35	0	0	0	0	0	0	0	61.57	0	0	13.4
2014	9	27	14	1	2	36	0	0	0	0	0	0	0	61.57	0	0	13.4
2014	9	27	14	11	2	35	0	0	0	0	0	0	0	61.48	0	0	13.4
2014	9	27	14	21	2	36	0	0	0	0	0	0	0	61.48	0	0	13.4
2014	9	27	14	31	2	35	0	0	0	0	0	0	0	61.41	0	0	13.4
2014	9	27	14	41	2	35	0	0	0	0	0	0	0	61.3	0	0	13.4
2014	9	27	14	51	2	35	0	0	0	0	0	0	0	61.23	0	0	12.8
2014	9	27	15	1	2	36	0	0	0	0	0	0	0	61.16	0	0	12.4
2014	9	27	15	11	2	35	0	0	0	0	0	0	0	61.12	0	0	12.2
2014	9	27	15	21	2	35	0	0	0	0	0	0	0	61.11	0	0	13.6
2014	9	27	15	31	2	35	0	0	0	0	0	0	0	61.07	0	0	13
2014	9	27	15	41	2	36	0	0	0	0	0	0	0	61.03	0	0	12.2
2014	9	27	15	51	2	37	0	0	0	0	0	0	0	61	0	0	12.2
2014	9	27	16	1	2	35	0	0	0	0	0	0	0	60.96	0	0	12.2
2014	9	27	16	11	2	36	0	0	0	0	0	0	0	60.94	0	0	12
2014	9	27	16	21	2	36	0	0	0	0	0	0	0	60.93	0	0	12
2014	9	27	16	31	2	35	0	0	0	0	0	0	0	60.89	0	0	12
2014	9	27	16	41	2	35	0	0	0	0	0	0	0	60.87	0	0	12
2014	9	27	16	51	2	36	0	0	0	0	0	0	0	60.85	0	0	12
2014	9	27	17	1	2	36	0	0	0	0	0	0	0	60.82	0	0	12
2014	9	27	17	11	2	36	0	0	0	0	0	0	0	60.82	0	0	12
2014	9	27	17	21	2	36	0	0	0	0	0	0	0	60.8	0	0	12
2014	9	27	17	31	2	35	0	0	0	0	0	0	0	60.78	0	0	12
2014	9	27	17	41	2	35	0	0	0	0	0	0	0	60.78	0	0	12
2014	9	27	17	51	2	35	0	0	0	0	0	0	0	60.78	0	0	12
2014	9	27	18	1	2	36	0	0	0	0	0	0	0	60.76	0	0	12
2014	9	27	18	11	2	36	0	0	0	0	0	0	0	60.78	0	0	12
2014	9	27	18	21	2	36	0	0	0	0	0	0	0	60.76	0	0	12
2014	9	27	18	31	2	36	0	0	0	0	0	0	0	60.75	0	0	12
2014	9	27	18	41	2	35	0	0	0	0	0	0	0	60.75	0	0	12
2014	9	27	18	51	2	36	0	0	0	0	0	0	0	60.75	0	0	12
2014	9	27	19	1	2	36	0	0	0	0	0	0	0	60.75	0	0	12
2014	9	27	19	11	2	36	0	0	0	0	0	0	0	60.75	0	0	11.8
2014	9	27	19	21	2	35	0	0	0	0	0	0	0	60.75	0	0	11.8
2014	9	27	19	31	2	35	0	0	0	0	0	0	0	60.75	0	0	11.8
2014	9	27	19	41	2	35	0	0	0	0	0	0	0	60.75	0	0	11.8
2014	9	27	19	51	2	35	0	0	0	0	0	0	0	60.73	0	0	11.8
2014	9	27	20	1	2	36	0	0	0	0	0	0	0	60.73	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	20	11	2	36	0	0	0	0	0	0	0	60.73	0	0	11.8
2014	9	27	20	21	2	36	0	0	0	0	0	0	0	60.71	0	0	11.8
2014	9	27	20	31	2	35	0	0	0	0	0	0	0	60.71	0	0	11.8
2014	9	27	20	41	2	35	0	0	0	0	0	0	0	60.71	0	0	11.8
2014	9	27	20	51	2	36	0	0	0	0	0	0	0	60.69	0	0	11.8
2014	9	27	21	1	2	36	0	0	0	0	0	0	0	60.69	0	0	11.8
2014	9	27	21	11	2	35	0	0	0	0	0	0	0	60.67	0	0	11.8
2014	9	27	21	21	2	35	0	0	0	0	0	0	0	60.67	0	0	11.8
2014	9	27	21	31	2	36	0	0	0	0	0	0	0	60.66	0	0	11.8
2014	9	27	21	41	2	36	0	0	0	0	0	0	0	60.64	0	0	11.8
2014	9	27	21	51	2	35	0	0	0	0	0	0	0	60.64	0	0	11.8
2014	9	27	22	1	2	35	0	0	0	0	0	0	0	60.62	0	0	11.8
2014	9	27	22	11	2	35	0	0	0	0	0	0	0	60.6	0	0	11.8
2014	9	27	22	21	2	35	0	0	0	0	0	0	0	60.6	0	0	11.8
2014	9	27	22	31	2	36	0	0	0	0	0	0	0	60.58	0	0	11.8
2014	9	27	22	41	2	35	0	0	0	0	0	0	0	60.57	0	0	11.8
2014	9	27	22	51	2	35	0	0	0	0	0	0	0	60.53	0	0	11.8
2014	9	27	23	1	2	36	0	0	0	0	0	0	0	60.53	0	0	11.8
2014	9	27	23	11	2	35	0	0	0	0	0	0	0	60.49	0	0	11.8
2014	9	27	23	21	2	35	0	0	0	0	0	0	0	60.48	0	0	11.8
2014	9	27	23	31	2	35	0	0	0	0	0	0	0	60.46	0	0	11.8
2014	9	27	23	41	2	35	0	0	0	0	0	0	0	60.44	0	0	11.8
2014	9	27	23	51	2	36	0	0	0	0	0	0	0	60.4	0	0	11.8
2014	9	28	0	1	2	35	0	0	0	0	0	0	0	60.39	0	0	11.8
2014	9	28	0	11	2	36	0	0	0	0	0	0	0	60.35	0	0	11.8
2014	9	28	0	21	2	36	0	0	0	0	0	0	0	60.33	0	0	11.8
2014	9	28	0	31	2	36	0	0	0	0	0	0	0	60.3	0	0	11.8
2014	9	28	0	41	2	35	0	0	0	0	0	0	0	60.26	0	0	11.8
2014	9	28	0	51	2	35	0	0	0	0	0	0	0	60.24	0	0	11.8
2014	9	28	1	1	2	36	0	0	0	0	0	0	0	60.21	0	0	11.8
2014	9	28	1	11	2	35	0	0	0	0	0	0	0	60.17	0	0	11.8
2014	9	28	1	21	2	36	0	0	0	0	0	0	0	60.15	0	0	11.8
2014	9	28	1	31	2	36	0	0	0	0	0	0	0	60.1	0	0	11.8
2014	9	28	1	41	2	36	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	28	1	51	2	36	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	28	2	1	2	36	0	0	0	0	0	0	0	60.01	0	0	11.8
2014	9	28	2	11	2	35	0	0	0	0	0	0	0	59.97	0	0	11.8
2014	9	28	2	21	2	35	0	0	0	0	0	0	0	59.95	0	0	11.8
2014	9	28	2	31	2	35	0	0	0	0	0	0	0	59.92	0	0	11.8
2014	9	28	2	41	2	36	0	0	0	0	0	0	0	59.86	0	0	11.6
2014	9	28	2	51	2	35	0	0	0	0	0	0	0	59.86	0	0	11.6
2014	9	28	3	1	2	36	0	0	0	0	0	0	0	59.83	0	0	11.6
2014	9	28	3	11	2	37	0	0	0	0	0	0	0	59.77	0	0	11.6
2014	9	28	3	21	2	36	0	0	0	0	0	0	0	59.76	0	0	11.6
2014	9	28	3	31	2	36	0	0	0	0	0	0	0	59.74	0	0	11.6
2014	9	28	3	41	2	35	0	0	0	0	0	0	0	59.7	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	3	51	2	35	0	0	0	0	0	0	0	59.67	0	0	11.6
2014	9	28	4	1	2	35	0	0	0	0	0	0	0	59.63	0	0	11.6
2014	9	28	4	11	2	35	0	0	0	0	0	0	0	59.59	0	0	11.6
2014	9	28	4	21	2	37	0	0	0	0	0	0	0	59.56	0	0	11.6
2014	9	28	4	31	2	36	0	0	0	0	0	0	0	59.52	0	0	11.6
2014	9	28	4	41	2	36	0	0	0	0	0	0	0	59.5	0	0	11.6
2014	9	28	4	51	2	35	0	0	0	0	0	0	0	59.47	0	0	11.6
2014	9	28	5	1	2	36	0	0	0	0	0	0	0	59.43	0	0	11.6
2014	9	28	5	11	2	35	0	0	0	0	0	0	0	59.4	0	0	11.6
2014	9	28	5	21	2	36	0	0	0	0	0	0	0	59.36	0	0	11.6
2014	9	28	5	31	2	36	0	0	0	0	0	0	0	59.32	0	0	11.6
2014	9	28	5	41	2	35	0	0	0	0	0	0	0	59.29	0	0	11.6
2014	9	28	5	51	2	36	0	0	0	0	0	0	0	59.25	0	0	11.6
2014	9	28	6	1	2	36	0	0	0	0	0	0	0	59.23	0	0	11.6
2014	9	28	6	11	2	36	0	0	0	0	0	0	0	59.2	0	0	11.6
2014	9	28	6	21	2	36	0	0	0	0	0	0	0	59.16	0	0	11.6
2014	9	28	6	31	2	36	0	0	0	0	0	0	0	59.13	0	0	11.6
2014	9	28	6	41	2	36	0	0	0	0	0	0	0	59.09	0	0	11.6
2014	9	28	6	51	2	36	0	0	0	0	0	0	0	59.07	0	0	11.6
2014	9	28	7	1	2	36	0	0	0	0	0	0	0	59.04	0	0	11.6
2014	9	28	7	11	2	36	0	0	0	0	0	0	0	59.02	0	0	11.6
2014	9	28	7	21	2	36	0	0	0	0	0	0	0	59	0	0	11.6
2014	9	28	7	31	2	36	0	0	0	0	0	0	0	58.96	0	0	11.6
2014	9	28	7	41	2	36	0	0	0	0	0	0	0	58.95	0	0	11.6
2014	9	28	7	51	2	36	0	0	0	0	0	0	0	58.93	0	0	11.8
2014	9	28	8	1	2	35	0	0	0	0	0	0	0	58.91	0	0	12.4
2014	9	28	8	11	2	35	0	0	0	0	0	0	0	58.91	0	0	12
2014	9	28	8	21	2	35	0	0	0	0	0	0	0	58.91	0	0	12.6
2014	9	28	8	31	2	36	0	0	0	0	0	0	0	58.93	0	0	13
2014	9	28	8	41	2	36	0	0	0	0	0	0	0	58.93	0	0	13.2
2014	9	28	8	51	2	35	0	0	0	0	0	0	0	58.93	0	0	13.2
2014	9	28	9	1	2	35	0	0	0	0	0	0	0	58.95	0	0	13
2014	9	28	9	11	2	36	0	0	0	0	0	0	0	58.96	0	0	13.4
2014	9	28	9	21	2	36	0	0	0	0	0	0	0	59	0	0	13.4
2014	9	28	9	31	2	36	0	0	0	0	0	0	0	59.05	0	0	13
2014	9	28	9	41	2	35	0	0	0	0	0	0	0	58.96	0	0	12.6
2014	9	28	9	51	2	36	0	0	0	0	0	0	0	58.96	0	0	12.8
2014	9	28	10	1	2	36	0	0	0	0	0	0	0	59.04	0	0	13.6
2014	9	28	10	11	2	36	0	0	0	0	0	0	0	59.05	0	0	12.8
2014	9	28	10	21	2	35	0	0	0	0	0	0	0	59.09	0	0	13.4
2014	9	28	10	31	2	36	0	0	0	0	0	0	0	59.14	0	0	13.4
2014	9	28	10	41	2	35	0	0	0	0	0	0	0	59.18	0	0	13.4
2014	9	28	10	51	2	36	0	0	0	0	0	0	0	59.22	0	0	13.4
2014	9	28	11	1	2	35	0	0	0	0	0	0	0	59.25	0	0	13.4
2014	9	28	11	11	2	36	0	0	0	0	0	0	0	59.29	0	0	13.4
2014	9	28	11	21	2	36	0	0	0	0	0	0	0	59.29	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	11	31	2	36	0	0	0	0	0	0	0	59.31	0	0	13.4
2014	9	28	11	41	2	36	0	0	0	0	0	0	0	59.34	0	0	13.4
2014	9	28	11	51	2	36	0	0	0	0	0	0	0	59.36	0	0	13.4
2014	9	28	12	1	2	35	0	0	0	0	0	0	0	59.38	0	0	13.4
2014	9	28	12	11	2	35	0	0	0	0	0	0	0	59.4	0	0	13.4
2014	9	28	12	21	2	35	0	0	0	0	0	0	0	59.43	0	0	13.4
2014	9	28	12	31	2	36	0	0	0	0	0	0	0	59.49	0	0	13.4
2014	9	28	12	41	2	36	0	0	0	0	0	0	0	59.43	0	0	13.2
2014	9	28	12	51	2	36	0	0	0	0	0	0	0	59.5	0	0	13.2
2014	9	28	13	1	2	35	0	0	0	0	0	0	0	59.49	0	0	13.2
2014	9	28	13	11	2	36	0	0	0	0	0	0	0	59.5	0	0	13.2
2014	9	28	13	21	2	35	0	0	0	0	0	0	0	59.52	0	0	13.2
2014	9	28	13	31	2	36	0	0	0	0	0	0	0	59.43	0	0	13.2
2014	9	28	13	41	2	36	0	0	0	0	0	0	0	59.34	0	0	13
2014	9	28	13	51	2	36	0	0	0	0	0	0	0	59.27	0	0	13
2014	9	28	14	1	2	36	0	0	0	0	0	0	0	59.22	0	0	13.2
2014	9	28	14	11	2	35	0	0	0	0	0	0	0	59.2	0	0	13.2
2014	9	28	14	21	2	35	0	0	0	0	0	0	0	59.2	0	0	13.2
2014	9	28	14	31	2	36	0	0	0	0	0	0	0	59.27	0	0	13.2
2014	9	28	14	41	2	36	0	0	0	0	0	0	0	59.29	0	0	13.2
2014	9	28	14	51	2	36	0	0	0	0	0	0	0	59.25	0	0	13.2
2014	9	28	15	1	2	36	0	0	0	0	0	0	0	59.22	0	0	13.2
2014	9	28	15	11	2	36	0	0	0	0	0	0	0	59.25	0	0	13.2
2014	9	28	15	21	2	36	0	0	0	0	0	0	0	59.23	0	0	13.2
2014	9	28	15	31	2	35	0	0	0	0	0	0	0	59.18	0	0	13.2
2014	9	28	15	41	2	35	0	0	0	0	0	0	0	59.16	0	0	13.2
2014	9	28	15	51	2	36	0	0	0	0	0	0	0	59.18	0	0	13.2
2014	9	28	16	1	2	36	0	0	0	0	0	0	0	59.16	0	0	13.2
2014	9	28	16	11	2	36	0	0	0	0	0	0	0	59.14	0	0	13
2014	9	28	16	21	2	35	0	0	0	0	0	0	0	59.11	0	0	13.2
2014	9	28	16	31	2	36	0	0	0	0	0	0	0	59.11	0	0	13.4
2014	9	28	16	41	2	36	0	0	0	0	0	0	0	59.13	0	0	13.4
2014	9	28	16	51	2	36	0	0	0	0	0	0	0	59.14	0	0	13.4
2014	9	28	17	1	2	36	0	0	0	0	0	0	0	59.11	0	0	12
2014	9	28	17	11	2	36	0	0	0	0	0	0	0	59.09	0	0	12.2
2014	9	28	17	21	2	35	0	0	0	0	0	0	0	59.07	0	0	12
2014	9	28	17	31	2	36	0	0	0	0	0	0	0	59.05	0	0	12
2014	9	28	17	41	2	36	0	0	0	0	0	0	0	59.05	0	0	12
2014	9	28	17	51	2	36	0	0	0	0	0	0	0	59.05	0	0	12
2014	9	28	18	1	2	36	0	0	0	0	0	0	0	59.04	0	0	12
2014	9	28	18	11	2	36	0	0	0	0	0	0	0	59.04	0	0	12
2014	9	28	18	21	2	35	0	0	0	0	0	0	0	59.02	0	0	12
2014	9	28	18	31	2	36	0	0	0	0	0	0	0	59	0	0	12
2014	9	28	18	41	2	36	0	0	0	0	0	0	0	59	0	0	12
2014	9	28	18	51	2	35	0	0	0	0	0	0	0	59	0	0	12
2014	9	28	19	1	2	36	0	0	0	0	0	0	0	59	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	19	11	2	35	0	0	0	0	0	0	0	59	0	0	12
2014	9	28	19	21	2	36	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	19	31	2	35	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	19	41	2	37	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	19	51	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	1	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	11	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	21	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	31	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	41	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	20	51	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	21	1	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	21	11	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	21	21	2	34	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	21	31	2	35	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	21	41	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	21	51	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	22	1	2	36	0	0	0	0	0	0	0	59.02	0	0	11.8
2014	9	28	22	11	2	36	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	22	21	2	36	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	22	31	2	36	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	22	41	2	36	0	0	0	0	0	0	0	59	0	0	11.8
2014	9	28	22	51	2	35	0	0	0	0	0	0	0	58.98	0	0	11.8
2014	9	28	23	1	2	35	0	0	0	0	0	0	0	58.98	0	0	11.8
2014	9	28	23	11	2	36	0	0	0	0	0	0	0	58.96	0	0	11.8
2014	9	28	23	21	2	36	0	0	0	0	0	0	0	58.96	0	0	11.8
2014	9	28	23	31	2	36	0	0	0	0	0	0	0	58.95	0	0	11.8
2014	9	28	23	41	2	36	0	0	0	0	0	0	0	58.95	0	0	11.8
2014	9	28	23	51	2	35	0	0	0	0	0	0	0	58.95	0	0	11.8
2014	9	29	0	1	2	35	0	0	0	0	0	0	0	58.93	0	0	11.8
2014	9	29	0	11	2	36	0	0	0	0	0	0	0	58.93	0	0	11.8
2014	9	29	0	21	2	36	0	0	0	0	0	0	0	58.91	0	0	11.8
2014	9	29	0	31	2	36	0	0	0	0	0	0	0	58.89	0	0	11.8
2014	9	29	0	41	2	36	0	0	0	0	0	0	0	58.87	0	0	11.8
2014	9	29	0	51	2	36	0	0	0	0	0	0	0	58.87	0	0	11.8
2014	9	29	1	1	2	35	0	0	0	0	0	0	0	58.84	0	0	11.8
2014	9	29	1	11	2	36	0	0	0	0	0	0	0	58.84	0	0	11.8
2014	9	29	1	21	2	35	0	0	0	0	0	0	0	58.8	0	0	11.8
2014	9	29	1	31	2	36	0	0	0	0	0	0	0	58.8	0	0	11.8
2014	9	29	1	41	2	36	0	0	0	0	0	0	0	58.78	0	0	11.8
2014	9	29	1	51	2	36	0	0	0	0	0	0	0	58.75	0	0	11.8
2014	9	29	2	1	2	36	0	0	0	0	0	0	0	58.75	0	0	11.8
2014	9	29	2	11	2	35	0	0	0	0	0	0	0	58.73	0	0	11.8
2014	9	29	2	21	2	36	0	0	0	0	0	0	0	58.69	0	0	11.8
2014	9	29	2	31	2	36	0	0	0	0	0	0	0	58.68	0	0	11.8
2014	9	29	2	41	2	36	0	0	0	0	0	0	0	58.64	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	2	51	2	35	0	0	0	0	0	0	0	58.62	0	0	11.8
2014	9	29	3	1	2	35	0	0	0	0	0	0	0	58.6	0	0	11.8
2014	9	29	3	11	2	36	0	0	0	0	0	0	0	58.59	0	0	11.8
2014	9	29	3	21	2	35	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	29	3	31	2	36	0	0	0	0	0	0	0	58.53	0	0	11.6
2014	9	29	3	41	2	36	0	0	0	0	0	0	0	58.5	0	0	11.6
2014	9	29	3	51	2	36	0	0	0	0	0	0	0	58.48	0	0	11.6
2014	9	29	4	1	2	36	0	0	0	0	0	0	0	58.46	0	0	11.6
2014	9	29	4	11	2	36	0	0	0	0	0	0	0	58.42	0	0	11.6
2014	9	29	4	21	2	35	0	0	0	0	0	0	0	58.41	0	0	11.6
2014	9	29	4	31	2	35	0	0	0	0	0	0	0	58.39	0	0	11.6
2014	9	29	4	41	2	36	0	0	0	0	0	0	0	58.37	0	0	11.6
2014	9	29	4	51	2	36	0	0	0	0	0	0	0	58.33	0	0	11.6
2014	9	29	5	1	2	35	0	0	0	0	0	0	0	58.3	0	0	11.6
2014	9	29	5	11	2	36	0	0	0	0	0	0	0	58.28	0	0	11.6
2014	9	29	5	21	2	36	0	0	0	0	0	0	0	58.26	0	0	11.6
2014	9	29	5	31	2	36	0	0	0	0	0	0	0	58.23	0	0	11.6
2014	9	29	5	41	2	35	0	0	0	0	0	0	0	58.21	0	0	11.6
2014	9	29	5	51	2	36	0	0	0	0	0	0	0	58.19	0	0	11.6
2014	9	29	6	1	2	36	0	0	0	0	0	0	0	58.17	0	0	11.6
2014	9	29	6	11	2	36	0	0	0	0	0	0	0	58.14	0	0	11.6
2014	9	29	6	21	2	36	0	0	0	0	0	0	0	58.12	0	0	11.6
2014	9	29	6	31	2	36	0	0	0	0	0	0	0	58.1	0	0	11.6
2014	9	29	6	41	2	36	0	0	0	0	0	0	0	58.06	0	0	11.6
2014	9	29	6	51	2	36	0	0	0	0	0	0	0	58.05	0	0	11.6
2014	9	29	7	1	2	35	0	0	0	0	0	0	0	58.03	0	0	11.6
2014	9	29	7	11	2	36	0	0	0	0	0	0	0	57.99	0	0	11.6
2014	9	29	7	21	2	36	0	0	0	0	0	0	0	57.97	0	0	11.6
2014	9	29	7	31	2	35	0	0	0	0	0	0	0	57.96	0	0	11.6
2014	9	29	7	41	2	36	0	0	0	0	0	0	0	57.94	0	0	12.2
2014	9	29	7	51	2	35	0	0	0	0	0	0	0	57.9	0	0	12.4
2014	9	29	8	1	2	37	0	0	0	0	0	0	0	57.9	0	0	12.6
2014	9	29	8	11	2	36	0	0	0	0	0	0	0	57.9	0	0	12.8
2014	9	29	8	21	2	37	0	0	0	0	0	0	0	57.92	0	0	13
2014	9	29	8	31	2	36	0	0	0	0	0	0	0	57.92	0	0	13
2014	9	29	8	41	2	36	0	0	0	0	0	0	0	57.94	0	0	13.2
2014	9	29	8	51	2	36	0	0	0	0	0	0	0	57.94	0	0	13.2
2014	9	29	9	1	2	35	0	0	0	0	0	0	0	57.96	0	0	13.4
2014	9	29	9	11	2	36	0	0	0	0	0	0	0	57.97	0	0	13.4
2014	9	29	9	21	2	35	0	0	0	0	0	0	0	57.99	0	0	13.4
2014	9	29	9	31	2	36	0	0	0	0	0	0	0	58.01	0	0	13.4
2014	9	29	9	41	2	36	0	0	0	0	0	0	0	58.05	0	0	13.4
2014	9	29	9	51	2	35	0	0	0	0	0	0	0	58.05	0	0	13.4
2014	9	29	10	1	2	35	0	0	0	0	0	0	0	58.06	0	0	13.4
2014	9	29	10	11	2	36	0	0	0	0	0	0	0	58.08	0	0	13.4
2014	9	29	10	21	2	36	0	0	0	0	0	0	0	58.12	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	10	31	2	36	0	0	0	0	0	0	0	58.14	0	0	13.4
2014	9	29	10	41	2	36	0	0	0	0	0	0	0	58.15	0	0	13.4
2014	9	29	10	51	2	36	0	0	0	0	0	0	0	58.19	0	0	13.2
2014	9	29	11	1	2	36	0	0	0	0	0	0	0	58.21	0	0	13.4
2014	9	29	11	11	2	35	0	0	0	0	0	0	0	58.23	0	0	13.4
2014	9	29	11	21	2	35	0	0	0	0	0	0	0	58.24	0	0	13.4
2014	9	29	11	31	2	36	0	0	0	0	0	0	0	58.28	0	0	13.4
2014	9	29	11	41	2	35	0	0	0	0	0	0	0	58.32	0	0	13.4
2014	9	29	11	51	2	36	0	0	0	0	0	0	0	58.33	0	0	13.4
2014	9	29	12	1	2	36	0	0	0	0	0	0	0	58.35	0	0	13.4
2014	9	29	12	11	2	36	0	0	0	0	0	0	0	58.37	0	0	13.4
2014	9	29	12	21	2	36	0	0	0	0	0	0	0	58.39	0	0	13.4
2014	9	29	12	31	2	36	0	0	0	0	0	0	0	58.42	0	0	13.4
2014	9	29	12	41	2	35	0	0	0	0	0	0	0	58.44	0	0	13.4
2014	9	29	12	51	2	35	0	0	0	0	0	0	0	58.44	0	0	13.4
2014	9	29	13	1	2	36	0	0	0	0	0	0	0	58.46	0	0	13.4
2014	9	29	13	11	2	36	0	0	0	0	0	0	0	58.46	0	0	13.4
2014	9	29	13	21	2	36	0	0	0	0	0	0	0	58.48	0	0	13.4
2014	9	29	13	31	2	35	0	0	0	0	0	0	0	58.5	0	0	13.4
2014	9	29	13	41	2	36	0	0	0	0	0	0	0	58.5	0	0	13.4
2014	9	29	13	51	2	36	0	0	0	0	0	0	0	58.5	0	0	13.4
2014	9	29	14	1	2	35	0	0	0	0	0	0	0	58.5	0	0	13.2
2014	9	29	14	11	2	36	0	0	0	0	0	0	0	58.5	0	0	13.2
2014	9	29	14	21	2	36	0	0	0	0	0	0	0	58.5	0	0	13.2
2014	9	29	14	31	2	36	0	0	0	0	0	0	0	58.5	0	0	13.2
2014	9	29	14	41	2	36	0	0	0	0	0	0	0	58.48	0	0	13.2
2014	9	29	14	51	2	35	0	0	0	0	0	0	0	58.48	0	0	13.2
2014	9	29	15	1	2	37	0	0	0	0	0	0	0	58.46	0	0	13.2
2014	9	29	15	11	2	35	0	0	0	0	0	0	0	58.46	0	0	13.2
2014	9	29	15	21	2	36	0	0	0	0	0	0	0	58.44	0	0	13.2
2014	9	29	15	31	2	35	0	0	0	0	0	0	0	58.42	0	0	13.2
2014	9	29	15	41	2	35	0	0	0	0	0	0	0	58.41	0	0	13.2
2014	9	29	15	51	2	36	0	0	0	0	0	0	0	58.39	0	0	13.2
2014	9	29	16	1	2	36	0	0	0	0	0	0	0	58.37	0	0	13.2
2014	9	29	16	11	2	36	0	0	0	0	0	0	0	58.37	0	0	13.2
2014	9	29	16	21	2	36	0	0	0	0	0	0	0	58.33	0	0	13.2
2014	9	29	16	31	2	36	0	0	0	0	0	0	0	58.33	0	0	13.2
2014	9	29	16	41	2	35	0	0	0	0	0	0	0	58.32	0	0	13.2
2014	9	29	16	51	2	36	0	0	0	0	0	0	0	58.3	0	0	13.2
2014	9	29	17	1	2	36	0	0	0	0	0	0	0	58.3	0	0	12.6
2014	9	29	17	11	2	36	0	0	0	0	0	0	0	58.26	0	0	12.2
2014	9	29	17	21	2	36	0	0	0	0	0	0	0	58.24	0	0	12.2
2014	9	29	17	31	2	36	0	0	0	0	0	0	0	58.23	0	0	12
2014	9	29	17	41	2	36	0	0	0	0	0	0	0	58.23	0	0	12
2014	9	29	17	51	2	36	0	0	0	0	0	0	0	58.23	0	0	12
2014	9	29	18	1	2	35	0	0	0	0	0	0	0	58.23	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	18	11	2	36	0	0	0	0	0	0	0	58.23	0	0	12
2014	9	29	18	21	2	36	0	0	0	0	0	0	0	58.23	0	0	12
2014	9	29	18	31	2	36	0	0	0	0	0	0	0	58.24	0	0	12
2014	9	29	18	41	2	35	0	0	0	0	0	0	0	58.24	0	0	12
2014	9	29	18	51	2	35	0	0	0	0	0	0	0	58.26	0	0	12
2014	9	29	19	1	2	36	0	0	0	0	0	0	0	58.26	0	0	12
2014	9	29	19	11	2	36	0	0	0	0	0	0	0	58.26	0	0	12
2014	9	29	19	21	2	35	0	0	0	0	0	0	0	58.28	0	0	12
2014	9	29	19	31	2	36	0	0	0	0	0	0	0	58.3	0	0	12
2014	9	29	19	41	2	36	0	0	0	0	0	0	0	58.3	0	0	12
2014	9	29	19	51	2	35	0	0	0	0	0	0	0	58.3	0	0	12
2014	9	29	20	1	2	36	0	0	0	0	0	0	0	58.32	0	0	12
2014	9	29	20	11	2	36	0	0	0	0	0	0	0	58.33	0	0	12
2014	9	29	20	21	2	36	0	0	0	0	0	0	0	58.33	0	0	12
2014	9	29	20	31	2	36	0	0	0	0	0	0	0	58.35	0	0	12
2014	9	29	20	41	2	37	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	20	51	2	35	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	21	1	2	36	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	21	11	2	36	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	21	21	2	36	0	0	0	0	0	0	0	58.39	0	0	11.8
2014	9	29	21	31	2	36	0	0	0	0	0	0	0	58.39	0	0	11.8
2014	9	29	21	41	2	35	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	21	51	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	1	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	11	2	37	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	21	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	31	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	41	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	22	51	2	36	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	23	1	2	36	0	0	0	0	0	0	0	58.39	0	0	11.8
2014	9	29	23	11	2	35	0	0	0	0	0	0	0	58.41	0	0	11.8
2014	9	29	23	21	2	36	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	23	31	2	36	0	0	0	0	0	0	0	58.37	0	0	11.8
2014	9	29	23	41	2	36	0	0	0	0	0	0	0	58.35	0	0	11.8
2014	9	29	23	51	2	36	0	0	0	0	0	0	0	58.35	0	0	11.8
2014	9	30	0	1	2	36	0	0	0	0	0	0	0	58.33	0	0	11.8
2014	9	30	0	11	2	36	0	0	0	0	0	0	0	58.32	0	0	11.8
2014	9	30	0	21	2	36	0	0	0	0	0	0	0	58.3	0	0	11.8
2014	9	30	0	31	2	35	0	0	0	0	0	0	0	58.28	0	0	11.6
2014	9	30	0	41	2	35	0	0	0	0	0	0	0	58.26	0	0	11.6
2014	9	30	0	51	2	35	0	0	0	0	0	0	0	58.23	0	0	11.6
2014	9	30	1	1	2	36	0	0	0	0	0	0	0	58.21	0	0	11.6
2014	9	30	1	11	2	35	0	0	0	0	0	0	0	58.19	0	0	11.6
2014	9	30	1	21	2	36	0	0	0	0	0	0	0	58.15	0	0	11.6
2014	9	30	1	31	2	36	0	0	0	0	0	0	0	58.12	0	0	11.6
2014	9	30	1	41	2	36	0	0	0	0	0	0	0	58.1	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	1	51	2	35	0	0	0	0	0	0	0	58.06	0	0	11.6
2014	9	30	2	1	2	35	0	0	0	0	0	0	0	58.03	0	0	11.6
2014	9	30	2	11	2	36	0	0	0	0	0	0	0	58.01	0	0	11.6
2014	9	30	2	21	2	35	0	0	0	0	0	0	0	57.97	0	0	11.6
2014	9	30	2	31	2	36	0	0	0	0	0	0	0	57.94	0	0	11.6
2014	9	30	2	41	2	35	0	0	0	0	0	0	0	57.9	0	0	11.6
2014	9	30	2	51	2	36	0	0	0	0	0	0	0	57.88	0	0	11.6
2014	9	30	3	1	2	36	0	0	0	0	0	0	0	57.85	0	0	11.6
2014	9	30	3	11	2	36	0	0	0	0	0	0	0	57.81	0	0	11.6
2014	9	30	3	21	2	36	0	0	0	0	0	0	0	57.78	0	0	11.6
2014	9	30	3	31	2	36	0	0	0	0	0	0	0	57.74	0	0	11.6
2014	9	30	3	41	2	35	0	0	0	0	0	0	0	57.7	0	0	11.6
2014	9	30	3	51	2	36	0	0	0	0	0	0	0	57.67	0	0	11.6
2014	9	30	4	1	2	35	0	0	0	0	0	0	0	57.63	0	0	11.6
2014	9	30	4	11	2	36	0	0	0	0	0	0	0	57.61	0	0	11.6
2014	9	30	4	21	2	36	0	0	0	0	0	0	0	57.58	0	0	11.6
2014	9	30	4	31	2	36	0	0	0	0	0	0	0	57.54	0	0	11.6
2014	9	30	4	41	2	36	0	0	0	0	0	0	0	57.51	0	0	11.6
2014	9	30	4	51	2	36	0	0	0	0	0	0	0	57.49	0	0	11.6
2014	9	30	5	1	2	36	0	0	0	0	0	0	0	57.45	0	0	11.6
2014	9	30	5	11	2	36	0	0	0	0	0	0	0	57.42	0	0	11.6
2014	9	30	5	21	2	36	0	0	0	0	0	0	0	57.4	0	0	11.6
2014	9	30	5	31	2	35	0	0	0	0	0	0	0	57.36	0	0	11.4
2014	9	30	5	41	2	35	0	0	0	0	0	0	0	57.33	0	0	11.6
2014	9	30	5	51	2	36	0	0	0	0	0	0	0	57.29	0	0	11.6
2014	9	30	6	1	2	35	0	0	0	0	0	0	0	57.25	0	0	11.6
2014	9	30	6	11	2	36	0	0	0	0	0	0	0	57.24	0	0	11.6
2014	9	30	6	21	2	36	0	0	0	0	0	0	0	57.2	0	0	11.6
2014	9	30	6	31	2	35	0	0	0	0	0	0	0	57.16	0	0	11.6
2014	9	30	6	41	2	35	0	0	0	0	0	0	0	57.13	0	0	11.6
2014	9	30	6	51	2	36	0	0	0	0	0	0	0	57.11	0	0	11.6
2014	9	30	7	1	2	36	0	0	0	0	0	0	0	57.07	0	0	11.6
2014	9	30	7	11	2	36	0	0	0	0	0	0	0	57.04	0	0	11.6
2014	9	30	7	21	2	36	0	0	0	0	0	0	0	57.02	0	0	11.6
2014	9	30	7	31	2	36	0	0	0	0	0	0	0	57	0	0	11.6
2014	9	30	7	41	2	36	0	0	0	0	0	0	0	56.97	0	0	12
2014	9	30	7	51	2	35	0	0	0	0	0	0	0	56.95	0	0	12.4
2014	9	30	8	1	2	36	0	0	0	0	0	0	0	56.93	0	0	12.6
2014	9	30	8	11	2	36	0	0	0	0	0	0	0	56.91	0	0	12.8
2014	9	30	8	21	2	36	0	0	0	0	0	0	0	56.91	0	0	13
2014	9	30	8	31	2	36	0	0	0	0	0	0	0	56.93	0	0	13
2014	9	30	8	41	2	37	0	0	0	0	0	0	0	56.95	0	0	13.2
2014	9	30	8	51	2	36	0	0	0	0	0	0	0	56.95	0	0	13.2
2014	9	30	9	1	2	36	0	0	0	0	0	0	0	56.97	0	0	13.4
2014	9	30	9	11	2	36	0	0	0	0	0	0	0	57	0	0	13.4
2014	9	30	9	21	2	35	0	0	0	0	0	0	0	57.04	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	9	31	2	36	0	0	0	0	0	0	0	57.06	0	0	13.4
2014	9	30	9	41	2	36	0	0	0	0	0	0	0	57.09	0	0	13.4
2014	9	30	9	51	2	36	0	0	0	0	0	0	0	57.11	0	0	13.4
2014	9	30	10	1	2	35	0	0	0	0	0	0	0	57.15	0	0	13.4
2014	9	30	10	11	2	36	0	0	0	0	0	0	0	57.18	0	0	13.2
2014	9	30	10	21	2	36	0	0	0	0	0	0	0	57.22	0	0	13.4
2014	9	30	10	31	2	36	0	0	0	0	0	0	0	57.25	0	0	13.4
2014	9	30	10	41	2	37	0	0	0	0	0	0	0	57.27	0	0	13.2
2014	9	30	10	51	2	36	0	0	0	0	0	0	0	57.33	0	0	13.2
2014	9	30	11	1	2	36	0	0	0	0	0	0	0	57.36	0	0	13.2
2014	9	30	11	11	2	36	0	0	0	0	0	0	0	57.4	0	0	13.2
2014	9	30	11	21	2	36	0	0	0	0	0	0	0	57.43	0	0	13.2
2014	9	30	11	31	2	36	0	0	0	0	0	0	0	57.47	0	0	13.2
2014	9	30	11	41	2	36	0	0	0	0	0	0	0	57.49	0	0	13.2
2014	9	30	11	51	2	36	0	0	0	0	0	0	0	57.52	0	0	13.2
2014	9	30	12	1	2	36	0	0	0	0	0	0	0	57.56	0	0	13.2
2014	9	30	12	11	2	37	0	0	0	0	0	0	0	57.58	0	0	13.2
2014	9	30	12	21	2	35	0	0	0	0	0	0	0	57.61	0	0	13.2
2014	9	30	12	31	2	35	0	0	0	0	0	0	0	57.63	0	0	13.2
2014	9	30	12	41	2	36	0	0	0	0	0	0	0	57.65	0	0	13.2
2014	9	30	12	51	2	36	0	0	0	0	0	0	0	57.67	0	0	13.2
2014	9	30	13	1	2	36	0	0	0	0	0	0	0	57.7	0	0	13.2
2014	9	30	13	11	2	36	0	0	0	0	0	0	0	57.72	0	0	13.2
2014	9	30	13	21	2	35	0	0	0	0	0	0	0	57.74	0	0	13.2
2014	9	30	13	31	2	36	0	0	0	0	0	0	0	57.74	0	0	13.2
2014	9	30	13	41	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	13	51	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	14	1	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	14	11	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	14	21	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	14	31	2	36	0	0	0	0	0	0	0	57.76	0	0	13.2
2014	9	30	14	41	2	36	0	0	0	0	0	0	0	57.74	0	0	13.2
2014	9	30	14	51	2	36	0	0	0	0	0	0	0	57.74	0	0	13.2
2014	9	30	15	1	2	35	0	0	0	0	0	0	0	57.72	0	0	13.2
2014	9	30	15	11	2	36	0	0	0	0	0	0	0	57.7	0	0	13.2
2014	9	30	15	21	2	36	0	0	0	0	0	0	0	57.7	0	0	13.2
2014	9	30	15	31	2	35	0	0	0	0	0	0	0	57.69	0	0	13.2
2014	9	30	15	41	2	36	0	0	0	0	0	0	0	57.67	0	0	13.2
2014	9	30	15	51	2	35	0	0	0	0	0	0	0	57.63	0	0	13.2
2014	9	30	16	1	2	36	0	0	0	0	0	0	0	57.61	0	0	13.2
2014	9	30	16	11	2	36	0	0	0	0	0	0	0	57.6	0	0	13.2
2014	9	30	16	21	2	35	0	0	0	0	0	0	0	57.58	0	0	13.2
2014	9	30	16	31	2	36	0	0	0	0	0	0	0	57.56	0	0	13.2
2014	9	30	16	41	2	35	0	0	0	0	0	0	0	57.52	0	0	13.2
2014	9	30	16	51	2	36	0	0	0	0	0	0	0	57.52	0	0	13.2
2014	9	30	17	1	2	36	0	0	0	0	0	0	0	57.49	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	17	11	2	36	0	0	0	0	0	0	0	57.47	0	0	12.2
2014	9	30	17	21	2	35	0	0	0	0	0	0	0	57.43	0	0	12
2014	9	30	17	31	2	36	0	0	0	0	0	0	0	57.43	0	0	12
2014	9	30	17	41	2	35	0	0	0	0	0	0	0	57.42	0	0	12
2014	9	30	17	51	2	37	0	0	0	0	0	0	0	57.4	0	0	12
2014	9	30	18	1	2	35	0	0	0	0	0	0	0	57.4	0	0	12
2014	9	30	18	11	2	36	0	0	0	0	0	0	0	57.4	0	0	12
2014	9	30	18	21	2	35	0	0	0	0	0	0	0	57.42	0	0	12
2014	9	30	18	31	2	36	0	0	0	0	0	0	0	57.42	0	0	12
2014	9	30	18	41	2	36	0	0	0	0	0	0	0	57.43	0	0	12
2014	9	30	18	51	2	36	0	0	0	0	0	0	0	57.43	0	0	12
2014	9	30	19	1	2	36	0	0	0	0	0	0	0	57.43	0	0	12
2014	9	30	19	11	2	35	0	0	0	0	0	0	0	57.45	0	0	12
2014	9	30	19	21	2	36	0	0	0	0	0	0	0	57.47	0	0	12
2014	9	30	19	31	2	36	0	0	0	0	0	0	0	57.47	0	0	12
2014	9	30	19	41	2	36	0	0	0	0	0	0	0	57.49	0	0	12
2014	9	30	19	51	2	35	0	0	0	0	0	0	0	57.49	0	0	12
2014	9	30	20	1	2	36	0	0	0	0	0	0	0	57.51	0	0	12
2014	9	30	20	11	2	36	0	0	0	0	0	0	0	57.52	0	0	12
2014	9	30	20	21	2	36	0	0	0	0	0	0	0	57.52	0	0	11.8
2014	9	30	20	31	2	36	0	0	0	0	0	0	0	57.54	0	0	11.8
2014	9	30	20	41	2	36	0	0	0	0	0	0	0	57.56	0	0	11.8
2014	9	30	20	51	2	35	0	0	0	0	0	0	0	57.58	0	0	11.8
2014	9	30	21	1	2	36	0	0	0	0	0	0	0	57.6	0	0	11.8
2014	9	30	21	11	2	36	0	0	0	0	0	0	0	57.6	0	0	11.8
2014	9	30	21	21	2	36	0	0	0	0	0	0	0	57.6	0	0	11.8
2014	9	30	21	31	2	36	0	0	0	0	0	0	0	57.61	0	0	11.8
2014	9	30	21	41	2	36	0	0	0	0	0	0	0	57.61	0	0	11.8
2014	9	30	21	51	2	36	0	0	0	0	0	0	0	57.63	0	0	11.8
2014	9	30	22	1	2	36	0	0	0	0	0	0	0	57.63	0	0	11.8
2014	9	30	22	11	2	36	0	0	0	0	0	0	0	57.65	0	0	11.8
2014	9	30	22	21	2	36	0	0	0	0	0	0	0	57.65	0	0	11.8
2014	9	30	22	31	2	36	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	22	41	2	36	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	22	51	2	36	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	23	1	2	36	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	23	11	2	35	0	0	0	0	0	0	0	57.69	0	0	11.8
2014	9	30	23	21	2	35	0	0	0	0	0	0	0	57.69	0	0	11.8
2014	9	30	23	31	2	35	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	23	41	2	36	0	0	0	0	0	0	0	57.67	0	0	11.8
2014	9	30	23	51	2	35	0	0	0	0	0	0	0	57.67	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	0	3	21	0.3	3.9	0.77	97.1	89.1339	64.6079
2014	9	1	0	13	21	0.3	3.9	0.75	97.8	89.1339	62.9441
2014	9	1	0	23	21	0.3	3.9	0.77	95.9	89.1339	64.8852
2014	9	1	0	33	21	0.3	3.9	0.75	96.5	89.1339	62.9442
2014	9	1	0	43	21	0.3	3.9	0.75	93	89.1339	63.4987
2014	9	1	0	53	21	0.3	3.9	0.76	97.2	89.1339	64.0533
2014	9	1	1	3	21	0.3	3.9	0.73	95.5	89.1339	61.0032
2014	9	1	1	13	21	0.3	3.9	0.74	96.1	89.1339	62.1123
2014	9	1	1	23	21	0.3	3.9	0.74	96.4	89.1339	62.1123
2014	9	1	1	33	21	0.3	3.9	0.75	96.5	89.1339	63.2215
2014	9	1	1	43	21	0.3	3.9	0.73	97.7	89.1339	61.5578
2014	9	1	1	53	21	0.3	3.9	0.73	95.7	89.1995	61.3273
2014	9	1	2	3	21	0.3	3.9	0.75	98	89.1339	62.9442
2014	9	1	2	13	21	0.3	3.9	0.74	96.4	89.1339	61.8351
2014	9	1	2	23	21	0.3	3.9	0.76	97.2	89.1339	63.7761
2014	9	1	2	33	21	0.3	3.9	0.73	96.5	89.1339	61.0033
2014	9	1	2	43	21	0.3	3.9	0.74	95.3	89.1995	62.4373
2014	9	1	2	53	21	0.3	3.9	0.73	94.1	89.1995	61.3273
2014	9	1	3	3	21	0.3	3.9	0.75	98.1	89.1995	62.7149
2014	9	1	3	13	21	0.3	3.9	0.72	97.5	89.1995	60.7724
2014	9	1	3	23	21	0.3	3.9	0.74	96.1	89.1995	62.1599
2014	9	1	3	33	21	0.3	3.9	0.75	96.1	89.1995	62.7149
2014	9	1	3	43	21	0.3	3.9	0.75	96	89.1995	62.9924
2014	9	1	3	55	14	0.3	3.9	0.76	96	89.3307	63.6444
2014	9	1	4	5	14	0.3	3.9	0.7	95.6	89.3963	59.2427
2014	9	1	4	15	14	0.3	3.9	0.74	94.8	89.3963	62.8585
2014	9	1	4	25	14	0.3	3.9	0.75	96.3	89.462	62.9063
2014	9	1	4	35	14	0.3	3.9	0.76	96.2	89.462	64.2981
2014	9	1	4	45	14	0.3	3.9	0.72	95.2	89.462	60.6796
2014	9	1	4	55	14	0.3	3.9	0.74	95.8	89.462	62.628
2014	9	1	5	5	14	0.3	3.9	0.72	96.3	89.462	60.9579
2014	9	1	5	15	14	0.3	3.9	0.75	97.2	89.462	63.4631
2014	9	1	5	25	14	0.3	3.9	0.73	96.5	89.462	61.2363
2014	9	1	5	35	14	0.3	3.9	0.72	96.8	89.5276	60.7258
2014	9	1	5	45	14	0.3	3.9	0.73	95.9	89.5276	61.5615
2014	9	1	5	55	14	0.3	3.9	0.74	95.3	89.5276	62.9543
2014	9	1	6	5	14	0.3	3.9	0.76	96.4	89.5276	64.3471
2014	9	1	6	15	14	0.3	3.9	0.75	96.3	89.5276	63.2328
2014	9	1	6	25	14	0.3	3.9	0.76	97.2	89.5276	63.79
2014	9	1	6	35	14	0.3	3.9	0.75	97	89.5276	63.5114
2014	9	1	6	45	14	0.3	3.9	0.75	96.1	89.5276	62.9543
2014	9	1	6	55	14	0.3	3.9	0.75	98.3	89.5276	62.9543
2014	9	1	7	5	14	0.3	3.9	0.72	95.7	89.5276	61.0044
2014	9	1	7	15	14	0.3	3.9	0.72	95.2	89.5276	61.283
2014	9	1	7	25	14	0.3	3.9	0.73	96.2	89.5276	61.8401
2014	9	1	7	35	14	0.3	3.9	0.78	96.8	89.5276	65.4614

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	7	45	14	0.3	3.9	0.72	100.2	89.5276	60.4473
2014	9	1	7	55	14	0.3	3.9	0.74	95.1	89.5276	62.6758
2014	9	1	8	5	14	0.3	3.9	0.76	99	89.5932	63.5597
2014	9	1	8	15	14	0.3	3.9	0.78	95	89.5276	66.2971
2014	9	1	8	25	14	0.3	3.9	0.74	96.4	89.5276	62.1187
2014	9	1	8	35	14	0.3	3.9	0.77	97.1	89.5276	64.6257
2014	9	1	8	45	14	0.3	3.9	0.76	97.7	89.5276	64.0686
2014	9	1	8	55	14	0.3	3.9	0.74	98.7	89.5276	62.1186
2014	9	1	9	5	14	0.3	3.9	0.77	98.1	89.5276	64.9042
2014	9	1	9	15	14	0.3	3.9	0.75	97.8	89.5276	62.6757
2014	9	1	9	25	14	0.3	3.9	0.74	97.7	89.5276	62.1186
2014	9	1	9	35	14	0.3	3.9	0.79	98.2	89.5276	66.0184
2014	9	1	9	45	14	0.3	3.9	0.74	96.4	89.5276	62.3971
2014	9	1	9	55	14	0.3	3.9	0.75	96.5	89.5276	63.5114
2014	9	1	10	5	14	0.3	3.9	0.75	99.1	89.5276	62.9542
2014	9	1	10	15	14	0.3	3.9	0.76	97.4	89.5276	64.0684
2014	9	1	10	25	14	0.3	3.9	0.76	98.7	89.5276	63.7898
2014	9	1	10	35	14	0.3	3.9	0.79	98.3	89.5276	66.5754
2014	9	1	10	45	14	0.3	3.9	0.76	100.5	89.5276	63.2327
2014	9	1	10	55	14	0.3	3.9	0.77	95.4	89.5276	65.1826
2014	9	1	11	5	14	0.3	3.9	0.76	97.7	89.5276	64.0683
2014	9	1	11	15	14	0.3	3.9	0.76	100.4	89.5276	63.7898
2014	9	1	11	25	14	0.3	3.9	0.75	99.8	89.5276	62.6755
2014	9	1	11	35	14	0.3	3.9	0.77	99.8	89.5276	64.6255
2014	9	1	11	45	14	0.3	3.9	0.77	98.3	89.462	64.8547
2014	9	1	11	55	14	0.3	3.9	0.76	99.7	89.462	63.7413
2014	9	1	12	5	14	0.3	3.9	0.8	100.7	89.3307	66.4235
2014	9	1	12	15	14	0.3	3.9	0.78	100.2	89.462	65.133
2014	9	1	12	25	14	0.3	3.9	0.74	99.9	89.3963	62.0239
2014	9	1	12	35	14	0.3	3.9	0.78	99.5	89.3307	65.0339
2014	9	1	12	45	14	0.3	3.9	0.75	98.5	89.2651	63.0403
2014	9	1	12	55	14	0.3	3.9	0.76	101.7	89.2651	62.7626
2014	9	1	13	5	14	0.3	3.9	0.78	100.5	89.2651	64.7066
2014	9	1	13	15	14	0.3	3.9	0.78	100	89.1995	64.6572
2014	9	1	13	25	14	0.3	3.9	0.75	100.6	89.1995	62.1598
2014	9	1	13	35	14	0.3	3.9	0.79	98.9	89.1995	65.7672
2014	9	1	13	45	14	0.3	3.9	0.76	101	89.1995	62.7147
2014	9	1	13	55	14	0.3	3.9	0.76	99.2	89.1995	63.5472
2014	9	1	14	5	14	0.3	3.9	0.76	98.2	89.1995	63.8247
2014	9	1	14	15	14	0.3	3.9	0.77	103.3	89.1339	63.4987
2014	9	1	14	25	14	0.3	3.9	0.76	99.7	89.1339	63.2215
2014	9	1	14	35	14	0.3	3.9	0.75	102.4	89.1339	61.835
2014	9	1	14	45	14	0.3	3.9	0.74	100.5	89.1339	61.2805
2014	9	1	14	55	14	0.3	3.9	0.76	102.2	89.1339	62.6669
2014	9	1	15	5	14	0.3	3.9	0.75	101.6	89.1339	62.3896
2014	9	1	15	15	14	0.3	3.9	0.77	102.5	89.1339	63.7761

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	15	25	14	0.3	3.9	0.76	98	89.1339	63.4988
2014	9	1	15	35	14	0.3	3.9	0.75	101.8	89.1339	62.1124
2014	9	1	15	45	14	0.3	3.9	0.75	99.6	89.1339	62.3896
2014	9	1	15	55	14	0.3	3.9	0.76	99.9	89.0683	63.4503
2014	9	1	16	5	14	0.3	3.9	0.78	101.9	89.1339	64.3307
2014	9	1	16	15	14	0.3	3.9	0.76	97.7	89.1339	63.7761
2014	9	1	16	25	14	0.3	3.9	0.74	97.1	89.0683	62.342
2014	9	1	16	35	14	0.3	3.9	0.76	104.6	89.0683	61.7879
2014	9	1	16	45	14	0.3	3.9	0.77	98.6	89.1339	64.3307
2014	9	1	16	55	14	0.3	3.9	0.77	100	89.0683	64.2816
2014	9	1	17	5	14	0.3	3.9	0.78	98.4	89.1339	65.4398
2014	9	1	17	15	14	0.3	3.9	0.74	101	89.1339	61.2805
2014	9	1	17	25	14	0.3	3.9	0.76	97.5	89.1339	63.4988
2014	9	1	17	35	14	0.3	3.9	0.76	102.3	89.1339	62.3897
2014	9	1	17	45	14	0.3	3.9	0.76	100.7	89.0683	63.1733
2014	9	1	17	55	14	0.3	3.9	0.75	98.8	89.0683	62.6191
2014	9	1	18	5	14	0.3	3.9	0.74	100.7	89.0683	61.5108
2014	9	1	18	15	14	0.3	3.9	0.76	99.7	89.0683	63.1733
2014	9	1	18	25	14	0.3	3.9	0.76	99.7	89.0683	63.1733
2014	9	1	18	35	14	0.3	3.9	0.75	100.8	89.1339	62.667
2014	9	1	18	45	14	0.3	3.9	0.75	100.8	89.1339	62.667
2014	9	1	18	55	14	0.3	3.9	0.75	97.3	89.0683	62.8962
2014	9	1	19	5	14	0.3	3.9	0.75	98.3	89.0683	62.6191
2014	9	1	19	15	14	0.3	3.9	0.75	96.3	89.1339	62.667
2014	9	1	19	25	14	0.3	3.9	0.74	97.4	89.1339	62.1124
2014	9	1	19	35	14	0.3	3.9	0.77	95.6	89.1339	64.608
2014	9	1	19	45	14	0.3	3.9	0.76	95.7	89.1339	63.7761
2014	9	1	19	55	14	0.3	3.9	0.76	96.7	89.1339	64.0534
2014	9	1	20	5	14	0.3	3.9	0.73	95.1	89.1339	61.5578
2014	9	1	20	15	14	0.3	3.9	0.77	98.3	89.1339	64.3307
2014	9	1	20	25	14	0.3	3.9	0.78	95.1	89.1339	65.7171
2014	9	1	20	35	14	0.3	3.9	0.78	96.1	89.1995	65.2122
2014	9	1	20	45	14	0.3	3.9	0.73	95.1	89.1995	61.6048
2014	9	1	20	55	14	0.3	3.9	0.74	99	89.1995	61.6048
2014	9	1	21	5	14	0.3	3.9	0.73	96.2	89.1995	61.6048
2014	9	1	21	15	14	0.3	3.9	0.77	97.9	89.1995	64.3797
2014	9	1	21	25	14	0.3	3.9	0.73	95.5	89.1995	61.0497
2014	9	1	21	35	14	0.3	3.9	0.75	98	89.1995	62.9922
2014	9	1	21	45	14	0.3	3.9	0.74	94.8	89.2651	62.7626
2014	9	1	21	55	14	0.3	3.9	0.77	97.1	89.2651	64.4288
2014	9	1	22	5	14	0.3	3.9	0.78	95.8	89.2651	66.0951
2014	9	1	22	15	14	0.3	3.9	0.74	96.7	89.2651	61.9294
2014	9	1	22	25	14	0.3	3.9	0.75	95.8	89.3307	63.0883
2014	9	1	22	35	14	0.3	3.9	0.76	96.9	89.2651	63.8734
2014	9	1	22	45	14	0.3	3.9	0.73	96.2	89.3307	61.6987
2014	9	1	22	55	14	0.3	3.9	0.76	94.4	89.3307	64.4779

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	23	5	14	0.3	3.9	0.77	95.6	89.3307	64.7558
2014	9	1	23	15	14	0.3	3.9	0.77	94.7	89.3307	64.7558
2014	9	1	23	25	14	0.3	3.9	0.76	96.7	89.3963	64.2489
2014	9	1	23	35	14	0.3	3.9	0.76	96.7	89.3963	63.6926
2014	9	1	23	45	14	0.3	3.9	0.76	98	89.462	63.7411
2014	9	1	23	55	14	0.3	3.9	0.75	97	89.462	63.4628
2014	9	2	0	5	14	0.3	3.9	0.72	95.2	89.5276	61.004
2014	9	2	0	15	14	0.3	3.9	0.74	93.5	89.5276	62.9539
2014	9	2	0	25	14	0.3	3.9	0.75	96.1	89.5276	62.9539
2014	9	2	0	35	14	0.3	3.9	0.75	96.8	89.5276	62.9539
2014	9	2	0	45	14	0.3	3.9	0.75	97	89.5276	63.2325
2014	9	2	0	55	14	0.3	3.9	0.73	96.2	89.5276	61.8397
2014	9	2	1	5	14	0.3	3.9	0.73	95.7	89.5932	61.6079
2014	9	2	1	15	14	0.3	3.9	0.76	95.4	89.5932	64.3956
2014	9	2	1	25	14	0.3	3.9	0.73	96.4	89.5932	61.8867
2014	9	2	1	35	14	0.3	3.9	0.75	97.7	89.5932	63.5593
2014	9	2	1	45	14	0.3	3.9	0.73	97.2	89.5932	61.8867
2014	9	2	1	55	14	0.3	3.9	0.75	97.5	89.5932	63.2806
2014	9	2	2	5	14	0.3	3.9	0.75	95	89.5932	63.8381
2014	9	2	2	15	14	0.3	4.3	0.75	98.3	89.6588	62.7707
2014	9	2	2	25	14	0.3	4.3	0.74	96.6	89.6588	62.7707
2014	9	2	2	35	14	0.3	4.3	0.73	94.1	89.6588	62.2127
2014	9	2	2	45	14	0.3	3.9	0.74	96.3	89.5932	62.7231
2014	9	2	2	55	14	0.3	4.3	0.74	95.8	89.6588	62.7707
2014	9	2	3	5	14	0.3	4.3	0.75	96.5	89.6588	63.6077
2014	9	2	3	15	14	0.3	4.3	0.76	94.7	89.6588	64.7236
2014	9	2	3	25	14	0.3	4.3	0.77	96.2	89.6588	64.7236
2014	9	2	3	35	14	0.3	4.3	0.75	96.3	89.6588	63.6077
2014	9	2	3	45	14	0.3	4.3	0.76	96.7	89.6588	64.4447
2014	9	2	3	55	14	0.3	4.3	0.76	96.9	89.6588	64.1657
2014	9	2	4	5	14	0.3	4.3	0.75	95.8	89.6588	63.6078
2014	9	2	4	15	14	0.3	4.3	0.73	96.7	89.6588	61.6549
2014	9	2	4	25	14	0.3	4.3	0.76	96.2	89.7244	63.9352
2014	9	2	4	35	14	0.3	4.3	0.76	97.2	89.7244	64.2144
2014	9	2	4	45	14	0.3	4.3	0.74	96.4	89.7244	62.5393
2014	9	2	4	55	14	0.3	4.3	0.73	93.9	89.7244	61.9809
2014	9	2	5	5	14	0.3	4.3	0.75	95.5	89.7244	63.3769
2014	9	2	5	15	14	0.3	4.3	0.74	94.6	89.7244	63.0977
2014	9	2	5	25	14	0.3	4.3	0.75	96	89.7244	63.3769
2014	9	2	5	35	14	0.3	4.3	0.78	98	89.79	65.6602
2014	9	2	5	45	14	0.3	4.3	0.78	96.8	89.79	65.6602
2014	9	2	5	55	14	0.3	4.3	0.75	96.3	89.79	63.425
2014	9	2	6	5	14	0.3	4.3	0.72	96.3	89.79	61.1898
2014	9	2	6	15	14	0.3	4.3	0.76	96	89.79	63.9838
2014	9	2	6	25	14	0.3	4.3	0.73	96.2	89.79	61.7486
2014	9	2	6	35	14	0.3	4.3	0.73	97.8	89.79	61.4692

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	6	45	14	0.3	4.3	0.74	95.6	89.8556	63.1935
2014	9	2	6	55	14	0.3	4.3	0.73	93.8	89.8556	62.3546
2014	9	2	7	5	14	0.3	4.3	0.75	95.3	89.8556	63.7528
2014	9	2	7	15	14	0.3	4.3	0.7	95.4	89.8556	59.5585
2014	9	2	7	25	14	0.3	4.3	0.75	95	89.8556	64.0324
2014	9	2	7	35	14	0.3	4.3	0.78	97	89.8556	65.7101
2014	9	2	7	45	14	0.3	4.3	0.76	96.7	89.8556	64.312
2014	9	2	7	55	14	0.3	4.3	0.73	94.1	89.8556	62.3547
2014	9	2	8	5	14	0.3	4.3	0.74	94.8	89.8556	62.6343
2014	9	2	8	15	14	0.3	4.3	0.75	97.5	89.8556	63.4732
2014	9	2	8	25	14	0.3	4.3	0.77	95.9	89.8556	65.4305
2014	9	2	8	35	14	0.3	4.3	0.76	96.2	89.8556	64.5916
2014	9	2	8	45	14	0.3	4.3	0.76	96.4	89.8556	64.5916
2014	9	2	8	55	14	0.3	4.3	0.78	98.5	89.8556	65.4304
2014	9	2	9	5	14	0.3	4.3	0.75	95.8	89.8556	63.7527
2014	9	2	9	15	14	0.3	4.3	0.76	96.2	89.8556	64.3119
2014	9	2	9	25	14	0.3	4.3	0.73	97	89.8556	61.7954
2014	9	2	9	35	14	0.3	4.3	0.76	99.7	89.8556	63.7527
2014	9	2	9	45	14	0.3	4.3	0.75	97.5	89.8556	63.473
2014	9	2	9	55	14	0.3	4.3	0.78	97.2	89.79	66.219
2014	9	2	10	5	14	0.3	4.3	0.77	101.1	89.8556	64.3119
2014	9	2	10	15	14	0.3	4.3	0.74	100.4	89.8556	62.3545
2014	9	2	10	25	14	0.3	4.3	0.77	100.8	89.79	64.5425
2014	9	2	10	35	14	0.3	4.3	0.76	99	89.79	63.7043
2014	9	2	10	45	14	0.3	4.3	0.77	99.6	89.79	64.2631
2014	9	2	10	55	14	0.3	4.3	0.75	100.3	89.79	62.8661
2014	9	2	11	5	14	0.3	4.3	0.75	99.5	89.79	63.1455
2014	9	2	11	15	14	0.3	4.3	0.73	101.6	89.79	61.1896
2014	9	2	11	25	14	0.3	4.3	0.76	101.7	89.79	63.4248
2014	9	2	11	35	14	0.3	4.3	0.8	99.5	89.79	66.7776
2014	9	2	11	45	14	0.3	4.3	0.77	99.6	89.79	64.263
2014	9	2	11	55	14	0.3	4.3	0.75	100.8	89.79	62.866
2014	9	2	12	5	14	0.3	4.3	0.74	100.4	89.79	62.3071
2014	9	2	12	15	14	0.3	4.3	0.76	103.4	89.79	63.1453
2014	9	2	12	25	14	0.3	4.3	0.76	99.7	89.79	63.4247
2014	9	2	12	35	14	0.3	4.3	0.7	102.1	89.79	58.6748
2014	9	2	12	45	14	0.3	4.3	0.75	98.3	89.79	62.8659
2014	9	2	12	55	14	0.3	4.3	0.77	98.3	89.79	65.1011
2014	9	2	13	5	14	0.3	4.3	0.75	101.4	89.79	62.5865
2014	9	2	13	15	14	0.3	4.3	0.74	99	89.7244	61.9806
2014	9	2	13	25	14	0.3	4.3	0.74	100.4	89.7244	62.2598
2014	9	2	13	35	14	0.3	4.3	0.72	100.4	89.7244	60.5847
2014	9	2	13	45	14	0.3	4.3	0.76	102.8	89.7244	62.8182
2014	9	2	13	55	14	0.3	4.3	0.75	102.4	89.7244	61.9806
2014	9	2	14	5	14	0.3	4.3	0.75	102.4	89.7244	61.9806
2014	9	2	14	15	14	0.3	4.3	0.78	101.5	89.6588	64.7234

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	14	25	14	0.3	4.3	0.74	104.1	89.6588	61.0967
2014	9	2	14	35	14	0.3	3.9	0.76	104.3	89.5932	62.4441
2014	9	2	14	45	14	0.3	4.3	0.73	101.7	89.6588	60.8177
2014	9	2	14	55	14	0.3	4.3	0.73	101.7	89.6588	60.8177
2014	9	2	15	5	14	0.3	3.9	0.76	102.4	89.5932	63.2805
2014	9	2	15	15	14	0.3	3.9	0.75	102	89.5932	62.7229
2014	9	2	15	25	14	0.3	3.9	0.77	100.6	89.5932	64.1168
2014	9	2	15	35	14	0.3	3.9	0.76	101.4	89.5932	63.5593
2014	9	2	15	45	14	0.3	3.9	0.74	96.9	89.5276	62.3968
2014	9	2	15	55	14	0.3	3.9	0.75	101.4	89.5932	62.1655
2014	9	2	16	5	14	0.3	3.9	0.76	102.7	89.5276	62.954
2014	9	2	16	15	14	0.3	3.9	0.73	96.7	89.5276	61.8398
2014	9	2	16	25	14	0.3	3.9	0.74	100.7	89.5276	61.8398
2014	9	2	16	35	14	0.3	3.9	0.73	101	89.5276	60.447
2014	9	2	16	45	14	0.3	3.9	0.75	98.6	89.5276	62.954
2014	9	2	16	55	14	0.3	3.9	0.75	100.1	89.5276	62.3969
2014	9	2	17	5	14	0.3	3.9	0.77	100.1	89.5276	64.0683
2014	9	2	17	15	14	0.3	3.9	0.77	98.4	89.5276	64.3468
2014	9	2	17	25	14	0.3	3.9	0.77	100.7	89.5276	64.6254
2014	9	2	17	35	14	0.3	3.9	0.75	99.1	89.5276	62.6755
2014	9	2	17	45	14	0.3	3.9	0.74	100.5	89.462	61.5145
2014	9	2	17	55	14	0.3	3.9	0.79	101.3	89.5276	65.7396
2014	9	2	18	5	14	0.3	3.9	0.76	99.7	89.462	63.1845
2014	9	2	18	15	14	0.3	3.9	0.78	98.2	89.5276	65.7396
2014	9	2	18	25	14	0.3	3.9	0.78	100.4	89.462	65.4113
2014	9	2	18	35	14	0.3	3.9	0.75	99.8	89.5276	62.9541
2014	9	2	18	45	14	0.3	3.9	0.77	99.8	89.5276	64.3468
2014	9	2	18	55	14	0.3	3.9	0.75	96.3	89.5932	63.2806
2014	9	2	19	5	14	0.3	3.9	0.76	96.2	89.5932	63.8382
2014	9	2	19	15	14	0.3	3.9	0.78	97	89.5932	65.5108
2014	9	2	19	25	14	0.3	3.9	0.73	98	89.5932	61.3292
2014	9	2	19	35	14	0.3	3.9	0.75	98.1	89.5932	63.0019
2014	9	2	19	45	14	0.3	3.9	0.78	96.8	89.5932	65.5108
2014	9	2	19	55	14	0.3	3.9	0.75	95.5	89.5932	63.2806
2014	9	2	20	5	14	0.3	4.3	0.76	98.5	89.6588	63.6077
2014	9	2	20	15	14	0.3	4.3	0.74	94.6	89.6588	62.7707
2014	9	2	20	25	14	0.3	4.3	0.75	96.5	89.6588	63.6076
2014	9	2	20	35	14	0.3	4.3	0.74	96.3	89.6588	62.7707
2014	9	2	20	45	14	0.3	4.3	0.73	97.2	89.6588	61.9337
2014	9	2	20	55	14	0.3	4.3	0.76	98.2	89.6588	63.6076
2014	9	2	21	5	14	0.3	4.3	0.73	96.2	89.6588	61.6547
2014	9	2	21	15	14	0.3	4.3	0.77	97.1	89.7244	65.0518
2014	9	2	21	25	14	0.3	4.3	0.73	96.2	89.6588	61.9337
2014	9	2	21	35	14	0.3	4.3	0.75	95.8	89.7244	63.6559
2014	9	2	21	45	14	0.3	4.3	0.74	94.8	89.7244	63.0975
2014	9	2	21	55	14	0.3	4.3	0.76	96.7	89.7244	63.935

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	22	5	14	0.3	4.3	0.71	95	89.7244	60.5847
2014	9	2	22	15	14	0.3	4.3	0.72	96.1	89.7244	60.5847
2014	9	2	22	25	14	0.3	4.3	0.73	95.1	89.7244	61.9807
2014	9	2	22	35	14	0.3	4.3	0.75	96.8	89.7244	63.3766
2014	9	2	22	45	14	0.3	4.3	0.73	95.1	89.7244	61.9807
2014	9	2	22	55	14	0.3	4.3	0.75	97.8	89.7244	63.3766
2014	9	2	23	5	14	0.3	4.3	0.79	98.2	89.79	66.2187
2014	9	2	23	15	14	0.3	4.3	0.73	96.2	89.7244	61.7015
2014	9	2	23	25	14	0.3	4.3	0.75	97	89.79	63.7041
2014	9	2	23	35	14	0.3	4.3	0.75	95.8	89.79	63.7041
2014	9	2	23	45	14	0.3	4.3	0.76	95.2	89.79	64.2629
2014	9	2	23	55	14	0.3	4.3	0.74	96.3	89.79	62.8659
2014	9	3	0	5	14	0.3	4.3	0.75	95.5	89.79	63.4247
2014	9	3	0	15	14	0.3	4.3	0.78	97.5	89.79	65.6599
2014	9	3	0	25	14	0.3	4.3	0.76	94.7	89.79	64.8217
2014	9	3	0	35	14	0.3	4.3	0.75	97	89.79	63.4247
2014	9	3	0	45	14	0.3	4.3	0.75	94.8	89.79	63.4247
2014	9	3	0	55	14	0.3	4.3	0.71	94.3	89.79	60.0719
2014	9	3	1	5	14	0.3	4.3	0.74	97.1	89.79	62.8659
2014	9	3	1	15	14	0.3	4.3	0.73	96.2	89.79	62.0277
2014	9	3	1	25	14	0.3	4.3	0.74	97.2	89.79	62.3071
2014	9	3	1	35	14	0.3	4.3	0.73	96.2	89.79	61.7483
2014	9	3	1	45	14	0.3	4.3	0.74	95.3	89.79	62.8659
2014	9	3	1	55	14	0.3	4.3	0.77	96.4	89.79	64.8218
2014	9	3	2	5	14	0.3	4.3	0.74	95.3	89.79	62.8659
2014	9	3	2	15	14	0.3	4.3	0.75	96.3	89.79	63.1454
2014	9	3	2	25	14	0.3	4.3	0.75	96.8	89.79	63.4248
2014	9	3	2	35	14	0.3	4.3	0.73	95.7	89.8556	61.7951
2014	9	3	2	45	14	0.3	4.3	0.74	98.7	89.8556	62.3544
2014	9	3	2	55	14	0.3	4.3	0.76	97.2	89.8556	64.5913
2014	9	3	3	5	14	0.3	4.3	0.76	94.2	89.8556	64.5913
2014	9	3	3	15	14	0.3	4.3	0.75	96.5	89.8556	63.7525
2014	9	3	3	25	14	0.3	4.3	0.76	98.2	89.9213	64.3604
2014	9	3	3	35	14	0.3	4.3	0.77	96.6	89.8556	65.4302
2014	9	3	3	45	14	0.3	4.3	0.75	97.6	89.8556	63.1933
2014	9	3	3	55	14	0.3	4.3	0.73	95.7	89.8556	62.0748
2014	9	3	4	5	14	0.3	4.3	0.77	95.9	89.8556	64.871
2014	9	3	4	15	14	0.3	4.3	0.75	96.3	89.9213	63.521
2014	9	3	4	25	14	0.3	4.3	0.73	95.1	89.9213	62.4017
2014	9	3	4	35	14	0.3	4.3	0.76	96.4	89.9213	64.3605
2014	9	3	4	45	14	0.3	4.3	0.77	96.2	89.9213	64.9201
2014	9	3	4	55	14	0.3	4.3	0.76	96.4	89.9213	64.6403
2014	9	3	5	5	14	0.3	4.3	0.75	97.3	89.9213	63.521
2014	9	3	5	15	14	0.3	4.3	0.73	95.2	89.9213	61.8421
2014	9	3	5	25	14	0.3	4.3	0.75	96.8	89.9213	63.521
2014	9	3	5	35	14	0.3	4.3	0.72	97	89.9213	61.2824

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	5	45	14	0.3	4.3	0.73	94.4	89.9869	61.8889
2014	9	3	5	55	14	0.3	4.3	0.75	97.3	89.9869	63.5691
2014	9	3	6	5	14	0.3	4.3	0.75	95	89.9869	63.8492
2014	9	3	6	15	14	0.3	4.3	0.74	93.8	89.9869	63.0091
2014	9	3	6	25	14	0.3	4.3	0.76	94.5	89.9869	64.4093
2014	9	3	6	35	14	0.3	4.3	0.75	94	89.9869	63.8492
2014	9	3	6	45	14	0.3	4.3	0.75	98	90.0525	63.6172
2014	9	3	6	55	14	0.3	4.3	0.72	98.4	90.0525	60.8147
2014	9	3	7	5	14	0.3	4.3	0.76	96.4	90.1181	64.5067
2014	9	3	7	15	14	0.3	4.3	0.75	94.7	90.1181	64.2262
2014	9	3	7	25	14	0.3	4.3	0.73	94.6	90.1181	62.5435
2014	9	3	7	35	14	0.3	4.3	0.75	96.8	90.1837	63.7134
2014	9	3	7	45	14	0.3	4.3	0.75	97.5	90.1837	63.7134
2014	9	3	7	55	14	0.3	4.3	0.75	94	90.1837	63.9941
2014	9	3	8	5	14	0.3	4.3	0.76	98.2	90.1837	64.5554
2014	9	3	8	15	14	0.3	4.3	0.76	97.2	90.1837	64.5554
2014	9	3	8	25	14	0.3	4.3	0.75	97.8	90.1837	63.4327
2014	9	3	8	35	14	0.3	4.3	0.74	94.1	90.1837	63.152
2014	9	3	8	45	14	0.3	4.3	0.76	97.5	90.1181	64.2262
2014	9	3	8	55	14	0.3	4.3	0.76	96.9	90.1181	64.7871
2014	9	3	9	5	14	0.3	4.3	0.74	97.6	90.1181	63.1043
2014	9	3	9	15	14	0.3	4.3	0.76	95.9	90.0525	64.7382
2014	9	3	9	25	14	0.3	4.3	0.74	97.4	89.9869	62.729
2014	9	3	9	35	14	0.3	4.3	0.73	97.5	89.9869	61.8888
2014	9	3	9	45	14	0.3	4.3	0.75	96.1	89.9869	63.289
2014	9	3	9	55	14	0.3	4.3	0.76	99.7	89.9869	63.8491
2014	9	3	10	5	14	0.3	4.3	0.76	96.7	89.9869	64.6892
2014	9	3	10	15	14	0.3	4.3	0.77	96.6	89.9869	65.5293
2014	9	3	10	25	14	0.3	4.3	0.75	97	89.9869	63.849
2014	9	3	10	35	14	0.3	4.3	0.77	96.4	89.9869	65.2492
2014	9	3	10	45	14	0.3	4.3	0.75	98.8	89.9869	63.569
2014	9	3	10	55	14	0.3	4.3	0.78	99.2	89.9869	65.8093
2014	9	3	11	5	14	0.3	4.3	0.79	99.3	89.9213	66.3191
2014	9	3	11	15	14	0.3	4.3	0.76	99.7	89.9213	63.8007
2014	9	3	11	25	14	0.3	4.3	0.75	96.5	89.9213	63.8007
2014	9	3	11	35	14	0.3	4.3	0.74	97.1	89.9213	62.9612
2014	9	3	11	45	14	0.3	4.3	0.75	97.6	89.9213	63.241
2014	9	3	11	55	14	0.3	4.3	0.77	97.9	89.9213	64.9199
2014	9	3	12	5	14	0.3	4.3	0.72	100.2	89.9213	60.7225
2014	9	3	12	15	14	0.3	4.3	0.76	98	89.8556	64.0319
2014	9	3	12	25	14	0.3	4.3	0.75	97.6	89.9213	63.2409
2014	9	3	12	35	14	0.3	4.3	0.76	99.7	89.9213	64.0804
2014	9	3	12	45	14	0.3	4.3	0.77	100.6	89.8556	64.3115
2014	9	3	12	55	14	0.3	4.3	0.78	99.4	89.8556	65.9892
2014	9	3	13	5	14	0.3	4.3	0.76	99.7	89.8556	63.4726
2014	9	3	13	15	14	0.3	4.3	0.76	100.5	89.8556	63.4726

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	13	25	14	0.3	4.3	0.74	99.9	89.8556	62.3542
2014	9	3	13	35	14	0.3	4.3	0.73	98	89.8556	61.5153
2014	9	3	13	45	14	0.3	4.3	0.72	101.1	89.8556	59.8376
2014	9	3	13	55	14	0.3	4.3	0.75	102.7	89.79	62.0275
2014	9	3	14	5	14	0.3	4.3	0.75	102.9	89.79	62.307
2014	9	3	14	15	14	0.3	4.3	0.75	100.5	89.79	63.1452
2014	9	3	14	25	14	0.3	4.3	0.76	101.9	89.8556	63.7522
2014	9	3	14	35	14	0.3	4.3	0.75	103.7	89.79	62.0276
2014	9	3	14	45	14	0.3	4.3	0.76	99.7	89.79	63.4246
2014	9	3	14	55	14	0.3	4.3	0.75	101.3	89.79	62.8658
2014	9	3	15	5	14	0.3	4.3	0.75	101.3	89.79	62.8658
2014	9	3	15	15	14	0.3	4.3	0.75	99.8	89.7244	62.8181
2014	9	3	15	25	14	0.3	4.3	0.76	101.7	89.7244	63.3765
2014	9	3	15	35	14	0.3	4.3	0.77	99.6	89.7244	64.4933
2014	9	3	15	45	14	0.3	4.3	0.76	104.2	89.7244	63.0973
2014	9	3	15	55	14	0.3	4.3	0.77	101.3	89.7244	64.2141
2014	9	3	16	5	14	0.3	4.3	0.74	99.2	89.7244	61.9806
2014	9	3	16	15	14	0.3	4.3	0.73	102.7	89.7244	60.5846
2014	9	3	16	25	14	0.3	4.3	0.73	104	89.7244	60.5846
2014	9	3	16	35	14	0.3	4.3	0.75	100	89.7244	63.0974
2014	9	3	16	45	14	0.3	4.3	0.77	101.8	89.7244	64.2141
2014	9	3	16	55	14	0.3	4.3	0.73	99.8	89.7244	61.4222
2014	9	3	17	5	14	0.3	4.3	0.77	102	89.6588	64.4445
2014	9	3	17	15	14	0.3	4.3	0.74	101.5	89.6588	61.6547
2014	9	3	17	25	14	0.3	4.3	0.76	102.7	89.6588	63.0496
2014	9	3	17	35	14	0.3	4.3	0.76	100	89.6588	63.3285
2014	9	3	17	45	14	0.3	4.3	0.78	100.7	89.7244	65.0518
2014	9	3	17	55	14	0.3	4.3	0.76	100.4	89.6588	63.8865
2014	9	3	18	5	14	0.3	4.3	0.74	97.6	89.7244	62.8182
2014	9	3	18	15	14	0.3	4.3	0.76	99.2	89.6588	63.8865
2014	9	3	18	25	14	0.3	4.3	0.76	100.7	89.6588	63.3286
2014	9	3	18	35	14	0.3	4.3	0.79	100.6	89.7244	65.8893
2014	9	3	18	45	14	0.3	4.3	0.73	96.5	89.7244	61.7015
2014	9	3	18	55	14	0.3	4.3	0.75	97.3	89.7244	63.0974
2014	9	3	19	5	14	0.3	4.3	0.74	98.7	89.7244	62.2598
2014	9	3	19	15	14	0.3	4.3	0.73	96.9	89.7244	61.9806
2014	9	3	19	25	14	0.3	4.3	0.75	96	89.7244	63.6558
2014	9	3	19	35	14	0.3	4.3	0.75	97	89.7244	63.3766
2014	9	3	19	45	14	0.3	4.3	0.77	95.9	89.7244	65.3309
2014	9	3	19	55	14	0.3	4.3	0.75	97.3	89.7244	63.0974
2014	9	3	20	5	14	0.3	4.3	0.76	98	89.7244	63.9349
2014	9	3	20	15	14	0.3	4.3	0.73	97.7	89.7244	61.9806
2014	9	3	20	25	14	0.3	4.3	0.73	96.2	89.79	62.0276
2014	9	3	20	35	14	0.3	4.3	0.76	97.2	89.79	63.9834
2014	9	3	20	45	14	0.3	4.3	0.76	97.2	89.79	64.2628
2014	9	3	20	55	14	0.3	4.3	0.75	94.5	89.79	63.4246

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	21	5	14	0.3	4.3	0.73	97.8	89.79	61.4688
2014	9	3	21	15	14	0.3	4.3	0.76	96.7	89.79	63.9834
2014	9	3	21	25	14	0.3	4.3	0.75	94.2	89.79	63.9834
2014	9	3	21	35	14	0.3	4.3	0.74	94.6	89.79	62.8658
2014	9	3	21	45	14	0.3	4.3	0.77	96.4	89.79	65.101
2014	9	3	21	55	14	0.3	4.3	0.75	96.1	89.79	63.1452
2014	9	3	22	5	14	0.3	4.3	0.74	97.7	89.79	62.307
2014	9	3	22	15	14	0.3	4.3	0.74	96.3	89.79	62.8657
2014	9	3	22	25	14	0.3	4.3	0.74	94.3	89.79	63.1452
2014	9	3	22	35	14	0.3	4.3	0.74	95.1	89.79	62.5863
2014	9	3	22	45	14	0.3	4.3	0.74	95.3	89.79	62.8657
2014	9	3	22	55	14	0.3	4.3	0.76	94.7	89.79	64.8216
2014	9	3	23	5	14	0.3	4.3	0.72	96.8	89.79	60.9099
2014	9	3	23	15	14	0.3	4.3	0.74	96.4	89.79	62.5863
2014	9	3	23	25	14	0.3	4.3	0.74	97.2	89.8556	62.3541
2014	9	3	23	35	14	0.3	4.3	0.77	93.7	89.8556	65.1503
2014	9	3	23	45	14	0.3	4.3	0.75	95	89.8556	63.4726
2014	9	3	23	55	14	0.3	4.3	0.74	94.8	89.8556	62.6338
2014	9	4	0	5	14	0.3	4.3	0.75	97.2	89.79	63.704
2014	9	4	0	15	14	0.3	4.3	0.77	97.3	89.8556	65.1503
2014	9	4	0	25	14	0.3	4.3	0.74	95.6	89.8556	62.6338
2014	9	4	0	35	14	0.3	4.3	0.74	96.1	89.8556	62.6338
2014	9	4	0	45	14	0.3	4.3	0.73	94.1	89.8556	62.0745
2014	9	4	0	55	14	0.3	4.3	0.77	93.7	89.8556	65.1503
2014	9	4	1	5	14	0.3	4.3	0.78	94.8	89.8556	66.5484
2014	9	4	1	15	14	0.3	4.3	0.77	96.4	89.8556	64.8707
2014	9	4	1	25	14	0.3	4.3	0.76	96.9	89.8556	64.3115
2014	9	4	1	35	14	0.3	4.3	0.74	96.9	89.8556	62.6338
2014	9	4	1	45	14	0.3	4.3	0.75	97	89.8556	63.7523
2014	9	4	1	55	14	0.3	4.3	0.77	97.1	89.8556	64.8707
2014	9	4	2	5	14	0.3	4.3	0.75	95.5	89.8556	63.7523
2014	9	4	2	15	14	0.3	4.3	0.75	93.7	89.8556	64.0319
2014	9	4	2	25	14	0.3	4.3	0.77	96.2	89.8556	64.8708
2014	9	4	2	35	14	0.3	4.3	0.75	93.8	89.8556	63.4727
2014	9	4	2	45	14	0.3	4.3	0.77	96.4	89.8556	65.1504
2014	9	4	2	55	14	0.3	4.3	0.73	96.4	89.8556	62.0746
2014	9	4	3	5	14	0.3	4.3	0.75	92.5	89.8556	64.032
2014	9	4	3	15	14	0.3	4.3	0.78	97	89.9213	65.7594
2014	9	4	3	25	14	0.3	4.3	0.76	97.2	89.8556	64.5912
2014	9	4	3	35	14	0.3	4.3	0.75	96.8	89.9213	63.5208
2014	9	4	3	45	14	0.3	4.3	0.76	97.2	89.9213	64.3603
2014	9	4	3	55	14	0.3	4.3	0.76	95.9	89.9213	64.6402
2014	9	4	4	5	14	0.3	4.3	0.78	96.8	89.9213	65.7595
2014	9	4	4	15	14	0.3	4.3	0.76	96.4	89.9213	64.3603
2014	9	4	4	25	14	0.3	4.3	0.77	96.9	89.9869	64.9691
2014	9	4	4	35	14	0.3	4.3	0.77	96.6	89.9213	65.4797

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	4	45	14	0.3	4.3	0.78	95.8	89.9869	66.0893
2014	9	4	4	55	14	0.3	4.3	0.77	98.3	89.9869	64.9692
2014	9	4	5	5	14	0.3	4.3	0.75	97	89.9869	63.849
2014	9	4	5	15	14	0.3	4.3	0.75	97	89.9869	63.849
2014	9	4	5	25	14	0.3	4.3	0.76	97.4	90.0525	64.7381
2014	9	4	5	35	14	0.3	4.3	0.75	95	89.9869	64.1291
2014	9	4	5	45	14	0.3	4.3	0.76	96.4	89.9869	64.4091
2014	9	4	5	55	14	0.3	4.3	0.76	93.7	89.9869	64.6892
2014	9	4	6	5	14	0.3	4.3	0.75	96.5	90.0525	63.6171
2014	9	4	6	15	14	0.3	4.3	0.75	96.3	90.0525	63.6171
2014	9	4	6	25	14	0.3	4.3	0.75	96.3	90.0525	63.8974
2014	9	4	6	35	14	0.3	4.3	0.74	95.1	90.0525	62.7764
2014	9	4	6	45	14	0.3	4.3	0.76	96.2	90.0525	64.4579
2014	9	4	6	55	14	0.3	4.3	0.74	97.9	90.0525	62.4961
2014	9	4	7	5	14	0.3	4.3	0.74	94.3	90.0525	63.3369
2014	9	4	7	15	14	0.3	4.3	0.74	98.2	90.0525	62.2159
2014	9	4	7	25	14	0.3	4.3	0.73	95.4	90.0525	62.4961
2014	9	4	7	35	14	0.3	4.3	0.74	97.4	90.1181	62.8238
2014	9	4	7	45	14	0.3	4.3	0.75	96.1	90.1181	63.3848
2014	9	4	7	55	14	0.3	4.3	0.76	98.7	90.1181	64.2261
2014	9	4	8	5	14	0.3	4.3	0.76	96.2	90.1181	64.787
2014	9	4	8	15	14	0.3	4.3	0.74	95.9	90.1181	62.5433
2014	9	4	8	25	14	0.3	4.3	0.75	96.8	90.1181	63.6652
2014	9	4	8	35	14	0.3	4.3	0.73	94.6	90.0525	62.4961
2014	9	4	8	45	14	0.3	4.3	0.77	96.6	90.1181	65.0675
2014	9	4	8	55	14	0.3	4.3	0.75	98.3	90.0525	63.3368
2014	9	4	9	5	14	0.3	4.3	0.72	97	90.1181	61.4214
2014	9	4	9	15	14	0.3	4.3	0.75	96.3	90.0525	63.3368
2014	9	4	9	25	14	0.3	4.3	0.76	97.2	90.0525	64.7381
2014	9	4	9	35	14	0.3	4.3	0.75	96.3	89.9869	63.569
2014	9	4	9	45	14	0.3	4.3	0.77	97.9	89.9869	64.9692
2014	9	4	9	55	14	0.3	4.3	0.73	99	89.9869	61.6087
2014	9	4	10	5	14	0.3	4.3	0.79	97.2	89.9869	66.9294
2014	9	4	10	15	14	0.3	4.3	0.77	98.3	89.9869	64.9691
2014	9	4	10	25	14	0.3	4.3	0.76	97.5	89.9869	64.129
2014	9	4	10	35	14	0.3	4.3	0.78	100	89.9869	65.2491
2014	9	4	10	45	14	0.3	4.3	0.77	96.6	89.9869	64.9691
2014	9	4	10	55	14	0.3	4.3	0.76	98.4	89.9869	64.409
2014	9	4	11	5	14	0.3	4.3	0.77	99.8	89.9869	64.689
2014	9	4	11	15	14	0.3	4.3	0.77	99.1	89.9869	64.969
2014	9	4	11	25	14	0.3	4.3	0.76	98.7	89.9869	64.1289
2014	9	4	11	35	14	0.3	4.3	0.74	96.4	89.9869	62.7287
2014	9	4	11	45	14	0.3	4.3	0.76	100.5	89.9869	63.5688
2014	9	4	11	55	14	0.3	4.3	0.76	101.3	89.9869	63.2887
2014	9	4	12	5	14	0.3	4.3	0.75	98.3	89.9869	63.5687
2014	9	4	12	15	14	0.3	4.3	0.78	100.7	89.9213	65.1996

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	12	25	14	0.3	4.3	0.76	106.3	89.9213	62.4014
2014	9	4	12	35	14	0.3	4.3	0.76	103.4	89.9213	63.2408
2014	9	4	12	45	14	0.3	4.3	0.75	99	89.9213	63.5206
2014	9	4	12	55	14	0.3	4.3	0.75	103.9	89.9213	62.1215
2014	9	4	13	5	14	0.3	4.3	0.78	101.9	89.9213	65.1996
2014	9	4	13	15	14	0.3	4.3	0.75	100.8	89.9213	62.9609
2014	9	4	13	25	14	0.3	4.3	0.77	102.3	89.9213	64.3601
2014	9	4	13	35	14	0.3	4.3	0.74	104.5	89.9213	60.7223
2014	9	4	13	45	14	0.3	4.3	0.74	105.5	89.8556	60.6764
2014	9	4	13	55	14	0.3	4.3	0.77	100.3	89.8556	64.591
2014	9	4	14	5	14	0.3	4.3	0.78	102.2	89.9213	64.9197
2014	9	4	14	15	14	0.3	4.3	0.75	103.4	89.8556	62.3541
2014	9	4	14	25	14	0.3	4.3	0.75	105.2	89.8556	61.7948
2014	9	4	14	35	14	0.3	4.3	0.76	103.7	89.8556	62.9133
2014	9	4	14	45	14	0.3	4.3	0.75	102.9	89.8556	62.3541
2014	9	4	14	55	14	0.3	4.3	0.75	105.7	89.8556	61.7949
2014	9	4	15	5	14	0.3	4.3	0.75	104	89.8556	61.7949
2014	9	4	15	15	14	0.3	4.3	0.74	105.1	89.8556	61.2356
2014	9	4	15	25	14	0.3	4.3	0.74	103.9	89.8556	61.2356
2014	9	4	15	35	14	0.3	4.3	0.76	102.3	89.79	62.8657
2014	9	4	15	45	14	0.3	4.3	0.75	100.3	89.8556	62.9134
2014	9	4	15	55	14	0.3	4.3	0.74	104	89.79	61.4687
2014	9	4	16	5	14	0.3	4.3	0.72	99.9	89.8556	60.6765
2014	9	4	16	15	14	0.3	4.3	0.74	101.1	89.79	61.4687
2014	9	4	16	25	14	0.3	4.3	0.73	101.7	89.79	60.6305
2014	9	4	16	35	14	0.3	4.3	0.73	103.5	89.79	60.3511
2014	9	4	16	45	14	0.3	4.3	0.74	101.2	89.79	62.0276
2014	9	4	16	55	14	0.3	4.3	0.73	102.1	89.79	61.1894
2014	9	4	17	5	14	0.3	4.3	0.72	101.8	89.79	60.0718
2014	9	4	17	15	14	0.3	4.3	0.74	102	89.79	62.0276
2014	9	4	17	25	14	0.3	4.3	0.75	102.3	89.79	62.5864
2014	9	4	17	35	14	0.3	4.3	0.75	100.1	89.79	62.5864
2014	9	4	17	45	14	0.3	4.3	0.76	98.2	89.79	64.2628
2014	9	4	17	55	14	0.3	4.3	0.77	99.3	89.79	64.8216
2014	9	4	18	5	14	0.3	4.3	0.79	99.1	89.79	66.2187
2014	9	4	18	15	14	0.3	4.3	0.74	99.4	89.79	62.5864
2014	9	4	18	25	14	0.3	4.3	0.76	103.7	89.79	63.1452
2014	9	4	18	35	14	0.3	4.3	0.79	98.9	89.79	66.2187
2014	9	4	18	45	14	0.3	4.3	0.77	99.8	89.8556	64.8707
2014	9	4	18	55	14	0.3	4.3	0.73	97.7	89.79	62.0276
2014	9	4	19	5	14	0.3	4.3	0.78	98	89.79	65.6598
2014	9	4	19	15	14	0.3	4.3	0.74	99.2	89.8556	62.3542
2014	9	4	19	25	14	0.3	4.3	0.73	97.2	89.8556	62.0746
2014	9	4	19	35	14	0.3	4.3	0.75	96.3	89.8556	63.4726
2014	9	4	19	45	14	0.3	4.3	0.73	95.4	89.8556	62.0746
2014	9	4	19	55	14	0.3	4.3	0.74	97.9	89.8556	62.3542

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	20	5	14	0.3	4.3	0.76	95.2	89.8556	64.3115
2014	9	4	20	15	14	0.3	4.3	0.76	94.7	89.8556	64.8707
2014	9	4	20	25	14	0.3	4.3	0.76	93.9	89.8556	64.8707
2014	9	4	20	35	14	0.3	4.3	0.75	96.1	89.8556	63.193
2014	9	4	20	45	14	0.3	4.3	0.74	96.4	89.8556	62.3541
2014	9	4	20	55	14	0.3	4.3	0.78	98.3	89.9213	65.4794
2014	9	4	21	5	14	0.3	4.3	0.76	96.2	89.9213	64.0803
2014	9	4	21	15	14	0.3	4.3	0.77	94.9	89.9213	65.4794
2014	9	4	21	25	14	0.3	4.3	0.73	95.2	89.9213	61.8417
2014	9	4	21	35	14	0.3	4.3	0.72	95.8	89.9213	61.0022
2014	9	4	21	45	14	0.3	4.3	0.75	96.3	89.9213	63.5206
2014	9	4	21	55	14	0.3	4.3	0.77	96.4	89.9213	65.1996
2014	9	4	22	5	14	0.3	4.3	0.74	93	89.9213	63.2408
2014	9	4	22	15	14	0.3	4.3	0.72	96.3	89.9213	61.282
2014	9	4	22	25	14	0.3	4.3	0.78	95.1	89.9213	66.3189
2014	9	4	22	35	14	0.3	4.3	0.74	93.8	89.9213	63.2408
2014	9	4	22	45	14	0.3	4.3	0.78	95.5	89.9869	66.369
2014	9	4	22	55	14	0.3	4.3	0.74	97.7	89.9869	62.4485
2014	9	4	23	5	14	0.3	4.3	0.76	96.9	89.9869	64.4088
2014	9	4	23	15	14	0.3	4.3	0.77	96.1	89.9869	65.2489
2014	9	4	23	25	14	0.3	4.3	0.77	97.3	89.9869	65.2489
2014	9	4	23	35	14	0.3	4.3	0.74	97.1	89.9869	63.0086
2014	9	4	23	45	14	0.3	4.3	0.74	94.8	89.9869	63.2886
2014	9	4	23	55	14	0.3	4.3	0.76	96.2	89.9869	64.4088
2014	9	5	0	5	14	0.3	4.3	0.78	95.1	89.9869	66.3691
2014	9	5	0	15	14	0.3	4.3	0.75	95.5	89.9869	63.8487
2014	9	5	0	25	14	0.3	4.3	0.79	96.4	89.9869	66.9291
2014	9	5	0	35	14	0.3	4.3	0.77	96.1	89.9869	65.529
2014	9	5	0	45	14	0.3	4.3	0.75	94.8	90.0525	63.897
2014	9	5	0	55	14	0.3	4.3	0.77	96.9	90.0525	65.018
2014	9	5	1	5	14	0.3	4.3	0.76	96.9	90.0525	64.4575
2014	9	5	1	15	14	0.3	4.3	0.73	98.5	90.0525	61.655
2014	9	5	1	25	14	0.3	4.3	0.75	97	90.0525	63.6168
2014	9	5	1	35	14	0.3	4.3	0.75	97.3	90.0525	63.3366
2014	9	5	1	45	14	0.3	4.3	0.77	97.8	90.0525	65.5786
2014	9	5	1	55	14	0.3	4.3	0.77	98.6	90.0525	64.7378
2014	9	5	2	5	14	0.3	4.3	0.78	96.1	90.1181	65.9086
2014	9	5	2	15	14	0.3	4.3	0.76	93.9	90.1181	65.0672
2014	9	5	2	25	14	0.3	4.3	0.74	94.8	90.2494	63.4801
2014	9	5	2	35	14	0.3	4.3	0.72	97	90.2494	61.514
2014	9	5	2	45	14	0.3	4.3	0.8	96.4	90.315	67.7445
2014	9	5	2	55	14	0.3	4.3	0.76	94.9	90.315	64.9335
2014	9	5	3	5	14	0.3	4.3	0.76	95.4	90.315	64.9335
2014	9	5	3	15	14	0.3	4.3	0.76	95.7	90.315	65.2146
2014	9	5	3	25	14	0.3	4.3	0.75	96	90.315	63.8092
2014	9	5	3	35	14	0.3	4.3	0.73	95.4	90.315	62.6848

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	3	45	14	0.3	4.3	0.76	95.2	90.3806	65.2638
2014	9	5	3	55	14	0.3	4.3	0.77	97.4	90.3806	65.2638
2014	9	5	4	5	14	0.3	4.3	0.76	96.7	90.3806	64.9825
2014	9	5	4	15	14	0.3	4.3	0.75	96	90.3806	63.8573
2014	9	5	4	25	14	0.3	4.3	0.76	97.4	90.3806	64.9825
2014	9	5	4	35	14	0.3	4.3	0.75	96.3	90.3806	64.1386
2014	9	5	4	45	14	0.3	4.3	0.76	96.9	90.3806	64.7013
2014	9	5	4	55	14	0.3	4.3	0.73	99.8	90.3806	61.8882
2014	9	5	5	5	14	0.3	4.3	0.77	97.1	90.3806	65.5452
2014	9	5	5	15	14	0.3	4.3	0.74	95.9	90.3806	62.7321
2014	9	5	5	25	14	0.3	4.3	0.76	96.2	90.3806	64.42
2014	9	5	5	35	14	0.3	4.3	0.75	97.3	90.3806	63.5761
2014	9	5	5	45	14	0.3	4.3	0.77	98.1	90.4462	65.5946
2014	9	5	5	55	14	0.3	4.3	0.77	97.1	90.4462	65.3131
2014	9	5	6	5	14	0.3	4.3	0.76	95.7	90.4462	65.0316
2014	9	5	6	15	14	0.3	4.3	0.77	97.1	90.4462	65.8762
2014	9	5	6	25	14	0.3	4.3	0.8	96.6	90.4462	67.8468
2014	9	5	6	35	14	0.3	4.3	0.76	96.2	90.4462	64.7501
2014	9	5	6	45	14	0.3	4.3	0.74	96.9	90.4462	63.061
2014	9	5	6	55	14	0.3	4.3	0.76	96.4	90.4462	65.0317
2014	9	5	7	5	14	0.3	4.3	0.75	96.8	90.4462	63.6241
2014	9	5	7	15	14	0.3	4.3	0.78	95.6	90.4462	66.4393
2014	9	5	7	25	14	0.3	4.3	0.75	94.3	90.4462	63.9056
2014	9	5	7	35	14	0.3	4.3	0.76	95.4	90.4462	65.3132
2014	9	5	7	45	14	0.3	4.3	0.76	96.2	90.4462	65.0317
2014	9	5	7	55	14	0.3	4.3	0.76	94.9	90.4462	65.3132
2014	9	5	8	5	14	0.3	4.3	0.74	96.6	90.5118	63.3902
2014	9	5	8	15	14	0.3	4.3	0.75	96	90.5118	63.9537
2014	9	5	8	25	14	0.3	4.3	0.8	96.9	90.5118	67.8979
2014	9	5	8	35	14	0.3	4.3	0.78	95.1	90.5118	66.4893
2014	9	5	8	45	14	0.3	4.3	0.74	94.6	90.5118	63.3902
2014	9	5	8	55	14	0.3	4.3	0.77	95.4	90.4462	65.8763
2014	9	5	9	5	14	0.3	4.3	0.77	97.9	90.4462	65.3132
2014	9	5	9	15	14	0.3	4.3	0.73	96.5	90.4462	62.2164
2014	9	5	9	25	14	0.3	4.3	0.81	97.9	90.5118	69.0248
2014	9	5	9	35	14	0.3	4.3	0.74	98.2	90.4462	62.4979
2014	9	5	9	45	14	0.3	4.3	0.75	97.2	90.4462	64.1871
2014	9	5	9	55	14	0.3	4.3	0.78	98.3	90.4462	65.8762
2014	9	5	10	5	14	0.3	4.3	0.76	97.7	90.4462	64.7501
2014	9	5	10	15	14	0.3	4.3	0.77	98.8	90.4462	65.5947
2014	9	5	10	25	14	0.3	4.3	0.77	98.4	90.4462	65.0316
2014	9	5	10	35	14	0.3	4.3	0.75	99.5	90.4462	63.624
2014	9	5	10	45	14	0.3	4.3	0.8	98.3	90.4462	67.8468
2014	9	5	10	55	14	0.3	4.3	0.75	100.1	90.4462	63.0609
2014	9	5	11	5	14	0.3	4.3	0.77	100.7	90.4462	65.3131
2014	9	5	11	15	14	0.3	4.3	0.77	101.8	90.4462	64.75

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	11	25	14	0.3	4.3	0.76	99.4	90.4462	64.75
2014	9	5	11	35	14	0.3	4.3	0.78	99.4	90.4462	66.4391
2014	9	5	11	45	14	0.3	4.3	0.79	98.1	90.4462	67.0022
2014	9	5	11	55	14	0.3	4.3	0.77	100.7	90.3806	65.2639
2014	9	5	12	5	14	0.3	4.3	0.74	100.8	90.4462	62.2162
2014	9	5	12	15	14	0.3	4.3	0.76	98.4	90.3806	64.7012
2014	9	5	12	25	14	0.3	4.3	0.76	99.9	90.3806	64.4199
2014	9	5	12	35	14	0.3	4.3	0.77	101	90.3806	64.9825
2014	9	5	12	45	14	0.3	4.3	0.78	99.9	90.3806	66.1077
2014	9	5	12	55	14	0.3	4.3	0.76	103.2	90.3806	63.5759
2014	9	5	13	5	14	0.3	4.3	0.77	97.9	90.315	65.2147
2014	9	5	13	15	14	0.3	4.3	0.78	103.7	90.315	64.6525
2014	9	5	13	25	14	0.3	4.3	0.76	103.7	90.2494	63.1993
2014	9	5	13	35	14	0.3	4.3	0.76	103.7	90.2494	63.4802
2014	9	5	13	45	14	0.3	4.3	0.75	102	90.2494	63.1993
2014	9	5	13	55	14	0.3	4.3	0.75	103.5	90.315	62.1226
2014	9	5	14	5	14	0.3	4.3	0.76	100	90.2494	63.7611
2014	9	5	14	15	14	0.3	4.3	0.77	103.1	90.2494	64.042
2014	9	5	14	25	14	0.3	4.3	0.74	102.6	90.2494	61.7949
2014	9	5	14	35	14	0.3	4.3	0.77	100.7	90.1837	65.1164
2014	9	5	14	45	14	0.3	4.3	0.79	99.6	90.1837	66.2391
2014	9	5	14	55	14	0.3	4.3	0.78	102.6	90.1837	65.1164
2014	9	5	15	5	14	0.3	4.3	0.78	100.2	90.1181	65.6282
2014	9	5	15	15	14	0.3	4.3	0.74	101.5	90.1837	62.3097
2014	9	5	15	25	14	0.3	4.3	0.74	103.5	90.1837	61.7484
2014	9	5	15	35	14	0.3	4.3	0.77	102	90.1181	64.7869
2014	9	5	15	45	14	0.3	4.3	0.76	104	90.1837	63.1518
2014	9	5	15	55	14	0.3	4.3	0.76	99.7	90.1837	63.9938
2014	9	5	16	5	14	0.3	4.3	0.77	99.8	90.1181	65.0674
2014	9	5	16	15	14	0.3	4.3	0.73	97	90.1181	61.9823
2014	9	5	16	25	14	0.3	4.3	0.77	102.1	90.1181	64.226
2014	9	5	16	35	14	0.3	4.3	0.78	99.5	90.1181	65.3479
2014	9	5	16	45	14	0.3	4.3	0.8	102.6	90.1181	66.7502
2014	9	5	16	55	14	0.3	4.3	0.79	100	90.1181	66.4697
2014	9	5	17	5	14	0.3	4.3	0.76	99	90.1181	63.9456
2014	9	5	17	15	14	0.3	4.3	0.77	101.5	90.1181	64.787
2014	9	5	17	25	14	0.3	4.3	0.78	100	90.0525	65.2986
2014	9	5	17	35	14	0.3	4.3	0.75	100.1	90.1181	62.8237
2014	9	5	17	45	14	0.3	4.3	0.79	99.6	90.1181	66.1893
2014	9	5	17	55	14	0.3	4.3	0.77	99.6	90.0525	64.4578
2014	9	5	18	5	14	0.3	4.3	0.79	100.6	90.0525	66.1394
2014	9	5	18	15	14	0.3	4.3	0.77	100.1	89.9869	64.6892
2014	9	5	18	25	14	0.3	4.3	0.76	99.7	90.0525	64.1776
2014	9	5	18	35	14	0.3	4.3	0.76	97.7	90.0525	64.4578
2014	9	5	18	45	14	0.3	4.3	0.77	98.3	90.0525	65.0183
2014	9	5	18	55	14	0.3	4.3	0.75	97	90.0525	63.6171

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	19	5	14	0.3	4.3	0.78	97	90.0525	66.1393
2014	9	5	19	15	14	0.3	4.3	0.74	97.4	90.0525	62.7763
2014	9	5	19	25	14	0.3	4.3	0.77	98.1	90.0525	65.2986
2014	9	5	19	35	14	0.3	4.3	0.76	97.6	90.0525	64.7381
2014	9	5	19	45	14	0.3	4.3	0.75	97.5	90.0525	63.6171
2014	9	5	19	55	14	0.3	4.3	0.79	97.4	90.0525	67.2603
2014	9	5	20	5	14	0.3	4.3	0.76	94.7	90.1181	65.0674
2014	9	5	20	15	14	0.3	4.3	0.78	96.3	90.1181	66.1893
2014	9	5	20	25	14	0.3	4.3	0.75	95.8	90.1837	63.9938
2014	9	5	20	35	14	0.3	4.3	0.76	95	90.1181	64.5065
2014	9	5	20	45	14	0.3	4.3	0.75	95	90.1837	63.7132
2014	9	5	20	55	14	0.3	4.3	0.78	97.5	90.1181	65.9088
2014	9	5	21	5	14	0.3	4.3	0.73	94.6	90.2494	62.6377
2014	9	5	21	15	14	0.3	4.3	0.73	97.2	90.2494	62.3568
2014	9	5	21	25	14	0.3	4.3	0.76	96.4	90.2494	64.6039
2014	9	5	21	35	14	0.3	4.3	0.73	95.4	90.2494	62.3568
2014	9	5	21	45	14	0.3	4.3	0.78	95.3	90.2494	66.2892
2014	9	5	21	55	14	0.3	4.3	0.76	96.2	90.2494	64.6038
2014	9	5	22	5	14	0.3	4.3	0.77	98.3	90.315	65.2147
2014	9	5	22	15	14	0.3	4.3	0.74	97.6	90.315	62.9659
2014	9	5	22	25	14	0.3	4.3	0.77	96.4	90.2494	65.1656
2014	9	5	22	35	14	0.3	4.3	0.76	94.7	90.315	65.2147
2014	9	5	22	45	14	0.3	4.3	0.74	96.3	90.315	63.247
2014	9	5	22	55	14	0.3	4.3	0.78	95.1	90.315	66.6202
2014	9	5	23	5	14	0.3	4.3	0.78	96	90.315	66.3391
2014	9	5	23	15	14	0.3	4.3	0.77	96.9	90.315	65.2147
2014	9	5	23	25	14	0.3	4.3	0.76	97.2	90.315	64.6525
2014	9	5	23	35	14	0.3	4.3	0.75	96.3	90.3806	64.1386
2014	9	5	23	45	14	0.3	4.3	0.78	97	90.3806	66.3891
2014	9	5	23	55	14	0.3	4.3	0.78	97	90.3806	66.1078
2014	9	6	0	5	14	0.3	4.3	0.75	94	90.3806	64.1386
2014	9	6	0	15	14	0.3	4.3	0.77	95.6	90.3806	66.1078
2014	9	6	0	25	14	0.3	4.3	0.75	94	90.3806	63.8573
2014	9	6	0	35	14	0.3	4.3	0.74	99	90.3806	62.4508
2014	9	6	0	45	14	0.3	4.3	0.74	95.6	90.3806	63.576
2014	9	6	0	55	14	0.3	4.3	0.75	97.7	90.3806	64.1387
2014	9	6	1	5	14	0.3	4.3	0.72	93.9	90.3806	61.6069
2014	9	6	1	15	14	0.3	4.3	0.77	96.9	90.3806	65.5452
2014	9	6	1	25	14	0.3	4.3	0.74	96.4	90.3806	63.0134
2014	9	6	1	35	14	0.3	4.3	0.76	95.7	90.3806	64.7013
2014	9	6	1	45	14	0.3	4.3	0.76	98	90.4462	64.4685
2014	9	6	1	55	14	0.3	4.3	0.76	96.2	90.3806	64.7013
2014	9	6	2	5	14	0.3	4.3	0.74	95.6	90.4462	63.624
2014	9	6	2	15	14	0.3	4.3	0.74	95.3	90.4462	63.3424
2014	9	6	2	25	14	0.3	4.3	0.75	96.3	90.4462	63.624
2014	9	6	2	35	14	0.3	4.3	0.77	96.9	90.4462	65.5947

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	2	45	14	0.3	4.3	0.75	96.3	90.4462	64.1871
2014	9	6	2	55	14	0.3	4.3	0.75	95.8	90.4462	63.9055
2014	9	6	3	5	14	0.3	4.3	0.78	98.2	90.4462	66.1577
2014	9	6	3	15	14	0.3	4.3	0.77	95.4	90.4462	65.8762
2014	9	6	3	25	14	0.3	4.3	0.76	96.7	90.4462	64.7501
2014	9	6	3	35	14	0.3	4.3	0.77	96.6	90.4462	65.3132
2014	9	6	3	45	14	0.3	4.3	0.78	96.6	90.4462	66.1578
2014	9	6	3	55	14	0.3	4.3	0.75	95	90.4462	64.1872
2014	9	6	4	5	14	0.3	4.3	0.77	96.1	90.4462	65.8763
2014	9	6	4	15	14	0.3	4.3	0.75	97.1	90.4462	63.6241
2014	9	6	4	25	14	0.3	4.3	0.77	93.9	90.4462	65.5948
2014	9	6	4	35	14	0.3	4.3	0.77	96.1	90.4462	65.5948
2014	9	6	4	45	14	0.3	4.3	0.75	95.8	90.4462	64.1872
2014	9	6	4	55	14	0.3	4.3	0.79	96.4	90.4462	67.5655
2014	9	6	5	5	14	0.3	4.3	0.75	98.6	90.4462	63.6242
2014	9	6	5	15	14	0.3	4.3	0.76	96.2	90.4462	64.7503
2014	9	6	5	25	14	0.3	4.3	0.75	95.8	90.4462	63.6243
2014	9	6	5	35	14	0.3	4.3	0.77	97.1	90.4462	65.5949
2014	9	6	5	45	14	0.3	4.3	0.77	95.2	90.4462	65.5949
2014	9	6	5	55	14	0.3	4.3	0.77	96.4	90.4462	65.595
2014	9	6	6	5	14	0.3	4.3	0.79	96.7	90.4462	67.0026
2014	9	6	6	15	14	0.3	4.3	0.77	94.7	90.4462	65.595
2014	9	6	6	25	14	0.3	4.3	0.75	96.3	90.4462	63.9059
2014	9	6	6	35	14	0.3	4.3	0.77	95.9	90.4462	65.3135
2014	9	6	6	45	14	0.3	4.3	0.76	97.7	90.4462	64.4689
2014	9	6	6	55	14	0.3	4.3	0.76	98.2	90.4462	64.469
2014	9	6	7	5	14	0.3	4.3	0.76	97	90.4462	64.469
2014	9	6	7	15	14	0.3	4.3	0.78	95.5	90.4462	67.0027
2014	9	6	7	25	14	0.3	4.3	0.77	98.6	90.4462	65.3136
2014	9	6	7	35	14	0.3	4.3	0.77	95.1	90.4462	66.1582
2014	9	6	7	45	14	0.3	4.3	0.78	95.8	90.4462	66.1582
2014	9	6	7	55	14	0.3	4.3	0.75	97.7	90.4462	64.1875
2014	9	6	8	5	14	0.3	4.3	0.78	95.8	90.4462	66.1582
2014	9	6	8	15	14	0.3	4.3	0.75	96.5	90.4462	64.1875
2014	9	6	8	25	14	0.3	4.3	0.79	96.9	90.4462	67.2843
2014	9	6	8	35	14	0.3	4.3	0.76	96.2	90.4462	64.7506
2014	9	6	8	45	14	0.3	4.3	0.77	97.8	90.4462	65.8766
2014	9	6	8	55	14	0.3	4.3	0.75	94	90.4462	64.1875
2014	9	6	9	5	14	0.3	4.3	0.76	95.9	90.4462	65.0321
2014	9	6	9	15	14	0.3	4.3	0.8	95.4	90.4462	68.4104
2014	9	6	9	25	14	0.3	4.3	0.74	95.8	90.4462	63.3429
2014	9	6	9	35	14	0.3	4.3	0.77	96.6	90.4462	65.3136
2014	9	6	9	45	14	0.3	4.3	0.76	97.9	90.4462	64.7505
2014	9	6	9	55	14	0.3	4.3	0.78	95.8	90.4462	67.0027
2014	9	6	10	5	14	0.3	4.3	0.77	97.9	90.4462	65.3135
2014	9	6	10	15	14	0.3	4.3	0.8	99.5	90.4462	67.5657

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	10	25	14	0.3	4.3	0.78	100.6	90.4462	65.8765
2014	9	6	10	35	14	0.3	4.3	0.78	99.1	90.3806	66.3896
2014	9	6	10	45	14	0.3	4.3	0.77	98.4	90.3806	64.983
2014	9	6	10	55	14	0.3	4.3	0.75	98.5	90.4462	63.9058
2014	9	6	11	5	14	0.3	4.3	0.78	100.1	90.3806	66.1082
2014	9	6	11	15	14	0.3	4.3	0.76	97.5	90.3806	64.4204
2014	9	6	11	25	14	0.3	4.3	0.77	100.5	90.3806	64.983
2014	9	6	11	35	14	0.3	4.3	0.81	99.8	90.3806	68.64
2014	9	6	11	45	14	0.3	4.3	0.78	102.6	90.3806	65.2643
2014	9	6	11	55	14	0.3	4.3	0.78	104.8	90.3806	64.9829
2014	9	6	12	5	14	0.3	4.3	0.74	100	90.3806	62.1698
2014	9	6	12	15	14	0.3	4.3	0.78	102.4	90.3806	64.9829
2014	9	6	12	25	14	0.3	4.3	0.75	98.8	90.3806	63.295
2014	9	6	12	35	14	0.3	4.3	0.8	98.5	90.3806	67.5147
2014	9	6	12	45	14	0.3	4.3	0.75	100.6	90.315	63.2474
2014	9	6	12	55	14	0.3	4.3	0.76	101.5	90.315	63.5285
2014	9	6	13	5	14	0.3	4.3	0.77	100.8	90.315	64.6529
2014	9	6	13	15	14	0.3	4.3	0.76	101.2	90.2494	63.7615
2014	9	6	13	25	14	0.3	4.3	0.75	102.3	90.315	62.9663
2014	9	6	13	35	14	0.3	4.3	0.77	100.8	90.315	64.6528
2014	9	6	13	45	14	0.3	4.3	0.77	102.1	90.2494	64.3233
2014	9	6	13	55	14	0.3	4.3	0.79	103	90.2494	65.7277
2014	9	6	14	5	14	0.3	4.3	0.77	100.8	90.2494	64.885
2014	9	6	14	15	14	0.3	4.3	0.75	101.1	90.2494	63.1997
2014	9	6	14	25	14	0.3	4.3	0.74	98.4	90.2494	62.6379
2014	9	6	14	35	14	0.3	4.3	0.74	102.1	90.1837	61.7487
2014	9	6	14	45	14	0.3	4.3	0.77	101.6	90.1837	64.2748
2014	9	6	14	55	14	0.3	4.3	0.76	103.7	90.1837	63.1521
2014	9	6	15	5	14	0.3	4.3	0.78	100.5	90.1837	65.3975
2014	9	6	15	15	14	0.3	4.3	0.75	104.7	90.1181	61.9826
2014	9	6	15	25	14	0.3	4.3	0.77	99.9	90.1837	64.5555
2014	9	6	15	35	14	0.3	4.3	0.79	99.8	90.1181	66.7505
2014	9	6	15	45	14	0.3	4.3	0.76	100.5	90.1181	63.6654
2014	9	6	15	55	14	0.3	4.3	0.76	101.4	90.0525	63.8976
2014	9	6	16	5	14	0.3	4.3	0.76	99.9	90.1181	64.2263
2014	9	6	16	15	14	0.3	4.3	0.78	100.6	90.1181	65.6287
2014	9	6	16	25	14	0.3	4.3	0.75	98.8	90.1181	63.1045
2014	9	6	16	35	14	0.3	4.3	0.75	96.3	90.0525	63.3371
2014	9	6	16	45	14	0.3	4.3	0.77	100.7	90.0525	65.0187
2014	9	6	16	55	14	0.3	4.3	0.78	98.7	90.0525	66.1397
2014	9	6	17	5	14	0.3	4.3	0.78	98.7	90.0525	66.1397
2014	9	6	17	15	14	0.3	4.3	0.75	101.8	90.0525	63.0569
2014	9	6	17	25	14	0.3	4.3	0.76	101.7	90.0525	63.6174
2014	9	6	17	35	14	0.3	4.3	0.78	99.5	89.9869	65.5296
2014	9	6	17	45	14	0.3	4.3	0.76	101	90.0525	63.6174
2014	9	6	17	55	14	0.3	4.3	0.75	98.6	90.0525	63.0569

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	18	5	14	0.3	4.3	0.79	101.5	90.0525	66.1397
2014	9	6	18	15	14	0.3	4.3	0.78	99.4	90.0525	65.8594
2014	9	6	18	25	14	0.3	4.3	0.76	99.7	89.9869	63.8494
2014	9	6	18	35	14	0.3	4.3	0.8	100.4	90.0525	67.2607
2014	9	6	18	45	14	0.3	4.3	0.78	99.1	90.0525	66.1397
2014	9	6	18	55	14	0.3	4.3	0.78	99.4	90.0525	65.8594
2014	9	6	19	5	14	0.3	4.3	0.76	96.2	90.0525	64.4582
2014	9	6	19	15	14	0.3	4.3	0.74	95.3	90.0525	63.0569
2014	9	6	19	25	14	0.3	4.3	0.8	98.3	90.0525	67.2607
2014	9	6	19	35	14	0.3	4.3	0.79	95.9	90.0525	67.2607
2014	9	6	19	45	14	0.3	4.3	0.78	94.8	90.1181	66.1896
2014	9	6	19	55	14	0.3	4.3	0.77	95.2	90.1181	65.3482
2014	9	6	20	5	14	0.3	4.3	0.76	94.9	90.1181	65.0677
2014	9	6	20	15	14	0.3	4.3	0.75	96.3	90.1181	63.3849
2014	9	6	20	25	14	0.3	4.3	0.76	97.2	90.1181	64.5068
2014	9	6	20	35	14	0.3	4.3	0.77	94.6	90.1181	65.6286
2014	9	6	20	45	14	0.3	4.3	0.76	97.7	90.1181	64.5068
2014	9	6	20	55	14	0.3	4.3	0.77	98.6	90.1181	65.0677
2014	9	6	21	5	14	0.3	4.3	0.77	96.2	90.1181	65.0677
2014	9	6	21	15	14	0.3	4.3	0.77	96.9	90.2494	65.4468
2014	9	6	21	25	14	0.3	4.3	0.79	96.7	90.1837	66.8008
2014	9	6	21	35	14	0.3	4.3	0.77	96.6	90.2494	65.1659
2014	9	6	21	45	14	0.3	4.3	0.81	95.4	90.2494	68.8174
2014	9	6	21	55	14	0.3	4.3	0.79	96.2	90.1837	67.3622
2014	9	6	22	5	14	0.3	4.3	0.77	98.3	90.1837	65.1167
2014	9	6	22	15	14	0.3	4.3	0.75	97.5	90.1837	63.7133
2014	9	6	22	25	14	0.3	4.3	0.76	97.9	90.1837	64.5554
2014	9	6	22	35	14	0.3	4.3	0.75	96.3	90.1837	63.4327
2014	9	6	22	45	14	0.3	4.3	0.76	95.4	90.1837	65.1167
2014	9	6	22	55	14	0.3	4.3	0.78	97	90.2494	66.2894
2014	9	6	23	5	14	0.3	4.3	0.75	95.5	90.2494	64.3231
2014	9	6	23	15	14	0.3	4.3	0.77	95.9	90.2494	65.7276
2014	9	6	23	25	14	0.3	4.3	0.78	95.8	90.2494	66.2893
2014	9	6	23	35	14	0.3	4.3	0.74	95.1	90.315	63.5283
2014	9	6	23	45	14	0.3	4.3	0.75	97.2	90.315	64.0905
2014	9	6	23	55	14	0.3	4.3	0.8	94.5	90.315	68.5881
2014	9	7	0	5	14	0.3	4.3	0.76	97.5	90.315	64.3716
2014	9	7	0	15	14	0.3	4.3	0.74	95.3	90.315	63.2472
2014	9	7	0	25	14	0.3	4.3	0.76	97.2	90.315	64.3716
2014	9	7	0	35	14	0.3	4.3	0.76	96.7	90.315	64.3716
2014	9	7	0	45	14	0.3	4.3	0.77	96.6	90.315	65.2149
2014	9	7	0	55	14	0.3	4.3	0.76	98	90.315	64.3716
2014	9	7	1	5	14	0.3	4.3	0.79	97.8	90.315	67.4637
2014	9	7	1	15	14	0.3	4.3	0.74	95.1	90.315	63.5283
2014	9	7	1	25	14	0.3	4.3	0.78	94.6	90.315	66.3393
2014	9	7	1	35	14	0.3	4.3	0.77	98.1	90.315	65.496

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	1	45	14	0.3	4.3	0.76	95	90.315	64.6527
2014	9	7	1	55	14	0.3	4.3	0.74	95.1	90.315	63.5284
2014	9	7	2	5	14	0.3	4.3	0.77	97.6	90.315	65.496
2014	9	7	2	15	14	0.3	4.3	0.75	94.8	90.315	63.8095
2014	9	7	2	25	14	0.3	4.3	0.76	96.4	90.315	64.6528
2014	9	7	2	35	14	0.3	4.3	0.77	94.9	90.315	65.7772
2014	9	7	2	45	14	0.3	4.3	0.76	97.2	90.3806	64.7015
2014	9	7	2	55	14	0.3	4.3	0.74	95.3	90.315	63.5284
2014	9	7	3	5	14	0.3	4.3	0.76	96.9	90.3806	64.7015
2014	9	7	3	15	14	0.3	4.3	0.79	96.4	90.315	67.1827
2014	9	7	3	25	14	0.3	4.3	0.73	94.9	90.3806	62.451
2014	9	7	3	35	14	0.3	4.3	0.76	94.7	90.3806	64.9828
2014	9	7	3	45	14	0.3	4.3	0.75	95.8	90.3806	64.1389
2014	9	7	3	55	14	0.3	4.3	0.79	96.2	90.3806	67.5147
2014	9	7	4	5	14	0.3	4.3	0.73	95.4	90.3806	62.7324
2014	9	7	4	15	14	0.3	4.3	0.76	95.7	90.3806	64.7016
2014	9	7	4	25	14	0.3	4.3	0.77	98.4	90.3806	64.9829
2014	9	7	4	35	14	0.3	4.3	0.76	96.2	90.3806	64.4203
2014	9	7	4	45	14	0.3	4.3	0.77	96.1	90.3806	65.5455
2014	9	7	4	55	14	0.3	4.3	0.76	95.4	90.3806	65.2642
2014	9	7	5	5	14	0.3	4.3	0.76	96.2	90.3806	64.9829
2014	9	7	5	15	14	0.3	4.3	0.77	96.4	90.3806	65.5456
2014	9	7	5	25	14	0.3	4.3	0.77	94.6	90.3806	66.1082
2014	9	7	5	35	14	0.3	4.3	0.79	95.7	90.3806	67.2335
2014	9	7	5	45	14	0.3	4.3	0.75	95	90.3806	63.8577
2014	9	7	5	55	14	0.3	4.3	0.75	96.3	90.3806	63.5764
2014	9	7	6	5	14	0.3	4.3	0.75	95.8	90.3806	64.1391
2014	9	7	6	15	14	0.3	4.3	0.74	96.9	90.3806	63.0138
2014	9	7	6	25	14	0.3	4.3	0.77	94.7	90.3806	65.5456
2014	9	7	6	35	14	0.3	4.3	0.76	96.4	90.3806	64.983
2014	9	7	6	45	14	0.3	4.3	0.78	97	90.3806	66.6709
2014	9	7	6	55	14	0.3	4.3	0.77	94.6	90.3806	66.1083
2014	9	7	7	5	14	0.3	4.3	0.77	94.9	90.3806	65.827
2014	9	7	7	15	14	0.3	4.3	0.77	95.9	90.3806	65.2644
2014	9	7	7	25	14	0.3	4.3	0.75	96.3	90.3806	63.8578
2014	9	7	7	35	14	0.3	4.3	0.75	97.1	90.3806	63.5765
2014	9	7	7	45	14	0.3	4.3	0.78	96.3	90.3806	66.3897
2014	9	7	7	55	14	0.3	4.3	0.76	95.7	90.3806	64.9831
2014	9	7	8	5	14	0.3	4.3	0.79	95.7	90.3806	67.2336
2014	9	7	8	15	14	0.3	4.3	0.75	98.5	90.3806	63.8578
2014	9	7	8	25	14	0.3	4.3	0.75	95.5	90.3806	64.4205
2014	9	7	8	35	14	0.3	4.3	0.77	96.8	90.3806	65.827
2014	9	7	8	45	14	0.3	4.3	0.74	95.1	90.3806	63.0139
2014	9	7	8	55	14	0.3	4.3	0.77	95.2	90.3806	65.5457
2014	9	7	9	5	14	0.3	4.3	0.77	97.9	90.3806	65.2644
2014	9	7	9	15	14	0.3	4.3	0.81	97	90.3806	68.6401

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	9	25	14	0.3	4.3	0.77	96.1	90.3806	65.5457
2014	9	7	9	35	14	0.3	4.3	0.8	98.2	90.3806	68.0775
2014	9	7	9	45	14	0.3	4.3	0.76	99.7	90.3806	63.8578
2014	9	7	9	55	14	0.3	4.3	0.76	98.7	90.315	64.3719
2014	9	7	10	5	14	0.3	4.3	0.74	97.9	90.315	62.6853
2014	9	7	10	15	14	0.3	4.3	0.78	98	90.315	66.0584
2014	9	7	10	25	14	0.3	4.3	0.77	96.1	90.315	65.7773
2014	9	7	10	35	14	0.3	4.3	0.78	97	90.315	66.0584
2014	9	7	10	45	14	0.3	4.3	0.78	100.7	90.315	65.4962
2014	9	7	10	55	14	0.3	4.3	0.75	99.8	90.315	63.5285
2014	9	7	11	5	14	0.3	4.3	0.78	100	90.315	65.4962
2014	9	7	11	15	14	0.3	4.3	0.8	98	90.315	68.0261
2014	9	7	11	25	14	0.3	4.3	0.77	98.9	90.2494	64.885
2014	9	7	11	35	14	0.3	4.3	0.78	98.9	90.2494	66.0086
2014	9	7	11	45	14	0.3	4.3	0.78	98.3	90.2494	65.7277
2014	9	7	11	55	14	0.3	4.3	0.77	98.6	90.1837	65.1168
2014	9	7	12	5	14	0.3	4.3	0.78	100.2	90.2494	65.7276
2014	9	7	12	15	14	0.3	4.3	0.77	100.1	90.1837	64.5554
2014	9	7	12	25	14	0.3	4.3	0.8	100.4	90.1181	67.3113
2014	9	7	12	35	14	0.3	4.3	0.77	103.1	90.1181	63.9457
2014	9	7	12	45	14	0.3	4.3	0.75	96.8	90.1181	63.6653
2014	9	7	12	55	14	0.3	4.3	0.77	97.6	90.0525	65.2987
2014	9	7	13	5	14	0.3	4.3	0.78	102.3	90.0525	65.2987
2014	9	7	13	15	14	0.3	4.3	0.73	97.7	90.1181	62.2629
2014	9	7	13	25	14	0.3	4.3	0.77	100.6	89.9869	64.4092
2014	9	7	13	35	14	0.3	4.3	0.75	100.8	90.0525	63.0567
2014	9	7	13	45	14	0.3	4.3	0.74	102.3	90.0525	61.9357
2014	9	7	13	55	14	0.3	4.3	0.76	95.9	89.9869	64.6893
2014	9	7	14	5	14	0.3	4.3	0.73	100.3	89.9869	61.6088
2014	9	7	14	15	14	0.3	4.3	0.75	101.2	89.9869	62.4489
2014	9	7	14	25	14	0.3	4.3	0.75	101.8	89.9213	62.9614
2014	9	7	14	35	14	0.3	4.3	0.77	102.3	89.9213	64.3605
2014	9	7	14	45	14	0.3	4.3	0.78	102.9	89.8556	64.5915
2014	9	7	14	55	14	0.3	4.3	0.77	100.8	89.9213	64.3605
2014	9	7	15	5	14	0.3	4.3	0.77	103	89.8556	64.3118
2014	9	7	15	15	14	0.3	4.3	0.74	102.8	89.8556	61.5157
2014	9	7	15	25	14	0.3	4.3	0.78	101	89.8556	64.8711
2014	9	7	15	35	14	0.3	4.3	0.77	100.6	89.8556	64.3119
2014	9	7	15	45	14	0.3	4.3	0.78	100.5	89.79	65.1014
2014	9	7	15	55	14	0.3	4.3	0.75	100.6	89.8556	62.6342
2014	9	7	16	5	14	0.3	4.3	0.78	104.1	89.79	64.5426
2014	9	7	16	15	14	0.3	4.3	0.75	100.8	89.79	63.1456
2014	9	7	16	25	14	0.3	4.3	0.77	100.8	89.79	64.2632
2014	9	7	16	35	14	0.3	4.3	0.77	99.5	89.79	64.822
2014	9	7	16	45	14	0.3	4.3	0.78	99.2	89.79	65.6602
2014	9	7	16	55	14	0.3	4.3	0.79	101.7	89.79	65.9397

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	17	5	14	0.3	4.3	0.78	98.3	89.79	65.3809
2014	9	7	17	15	14	0.3	4.3	0.77	97.6	89.79	65.1015
2014	9	7	17	25	14	0.3	4.3	0.77	98.6	89.79	64.8221
2014	9	7	17	35	14	0.3	4.3	0.75	99.1	89.79	62.8662
2014	9	7	17	45	14	0.3	4.3	0.81	99.8	89.7244	67.5649
2014	9	7	17	55	14	0.3	4.3	0.75	100.8	89.79	62.8662
2014	9	7	18	5	14	0.3	4.3	0.8	99.9	89.7244	67.0065
2014	9	7	18	15	14	0.3	4.3	0.75	98.5	89.79	63.425
2014	9	7	18	25	14	0.3	4.3	0.75	98	89.79	63.425
2014	9	7	18	35	14	0.3	4.3	0.75	97.6	89.79	63.1456
2014	9	7	18	45	14	0.3	4.3	0.78	97.5	89.79	65.9397
2014	9	7	18	55	14	0.3	4.3	0.77	96.6	89.79	65.3808
2014	9	7	19	5	14	0.3	4.3	0.75	96.1	89.79	63.1456
2014	9	7	19	15	14	0.3	4.3	0.73	97.7	89.7244	61.7018
2014	9	7	19	25	14	0.3	4.3	0.75	97.1	89.6588	63.0499
2014	9	7	19	35	14	0.3	4.3	0.76	95.7	89.8556	64.3119
2014	9	7	19	45	14	0.3	4.3	0.73	98.2	89.8556	61.7953
2014	9	7	19	55	14	0.3	4.3	0.73	95.7	89.79	62.0279
2014	9	7	20	5	14	0.3	4.3	0.74	96.4	89.79	62.3073
2014	9	7	20	15	14	0.3	4.3	0.77	97.4	89.9213	64.9202
2014	9	7	20	25	14	0.3	4.3	0.74	98.6	89.8556	62.6341
2014	9	7	20	35	14	0.3	4.3	0.78	96.8	89.79	65.6602
2014	9	7	20	45	14	0.3	4.3	0.75	97.3	89.8556	63.473
2014	9	7	20	55	14	0.3	4.3	0.76	96.7	89.8556	64.3118
2014	9	7	21	5	14	0.3	4.3	0.75	96.3	89.8556	63.4729
2014	9	7	21	15	14	0.3	4.3	0.75	96.3	89.8556	63.7526
2014	9	7	21	25	14	0.3	4.3	0.77	97.4	89.8556	64.871
2014	9	7	21	35	14	0.3	4.3	0.77	97.9	89.8556	64.871
2014	9	7	21	45	14	0.3	4.3	0.74	96.9	89.8556	62.6341
2014	9	7	21	55	14	0.3	4.3	0.75	95.5	89.8556	64.0321
2014	9	7	22	5	14	0.3	4.3	0.77	95.6	89.8556	65.1506
2014	9	7	22	15	14	0.3	4.3	0.78	97.5	89.79	65.9395
2014	9	7	22	25	14	0.3	4.3	0.78	95.1	89.8556	66.269
2014	9	7	22	35	14	0.3	4.3	0.75	96.5	89.8556	63.4729
2014	9	7	22	45	14	0.3	4.3	0.76	95.7	89.8556	64.8709
2014	9	7	22	55	14	0.3	4.3	0.75	95.3	89.8556	63.7525
2014	9	7	23	5	14	0.3	4.3	0.75	94.5	89.8556	63.7525
2014	9	7	23	15	14	0.3	4.3	0.77	97.9	89.8556	64.8709
2014	9	7	23	25	14	0.3	4.3	0.77	96.6	89.8556	65.4301
2014	9	7	23	35	14	0.3	4.3	0.77	97.1	89.8556	64.8709
2014	9	7	23	45	14	0.3	4.3	0.76	96	89.8556	64.0321
2014	9	7	23	55	14	0.3	4.3	0.75	96.8	89.8556	63.1932
2014	9	8	0	5	14	0.3	4.3	0.78	97	89.8556	65.9894
2014	9	8	0	15	14	0.3	4.3	0.76	94.4	89.8556	64.8709
2014	9	8	0	25	14	0.3	4.3	0.77	96.2	89.8556	64.8709
2014	9	8	0	35	14	0.3	4.3	0.73	97.7	89.8556	61.7951

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	0	45	14	0.3	4.3	0.77	98.3	89.8556	64.8709
2014	9	8	0	55	14	0.3	4.3	0.73	94.6	89.8556	62.3543
2014	9	8	1	5	14	0.3	4.3	0.75	97.5	89.8556	63.4728
2014	9	8	1	15	14	0.3	4.3	0.74	97.1	89.8556	62.9136
2014	9	8	1	25	14	0.3	4.3	0.74	97.7	89.8556	62.3543
2014	9	8	1	35	14	0.3	4.3	0.77	98.1	89.8556	64.8709
2014	9	8	1	45	14	0.3	4.3	0.75	97.2	89.8556	63.7524
2014	9	8	1	55	14	0.3	4.3	0.77	97.1	89.8556	65.1505
2014	9	8	2	5	14	0.3	4.3	0.76	95.2	89.8556	64.8709
2014	9	8	2	15	14	0.3	4.3	0.77	95.6	89.8556	65.7097
2014	9	8	2	25	14	0.3	4.3	0.76	95.2	89.8556	64.3116
2014	9	8	2	35	14	0.3	4.3	0.75	95.5	89.8556	63.4728
2014	9	8	2	45	14	0.3	4.3	0.73	95.9	89.8556	62.0747
2014	9	8	2	55	14	0.3	4.3	0.75	95.5	89.8556	63.4728
2014	9	8	3	5	14	0.3	4.3	0.77	97.3	89.9213	65.4797
2014	9	8	3	15	14	0.3	4.3	0.74	96.4	89.9213	62.4016
2014	9	8	3	25	14	0.3	4.3	0.78	97	89.9213	65.7595
2014	9	8	3	35	14	0.3	4.3	0.74	98.4	89.9213	62.4016
2014	9	8	3	45	14	0.3	4.3	0.74	94.8	89.9213	63.241
2014	9	8	3	55	14	0.3	4.3	0.76	96.9	89.9213	64.3604
2014	9	8	4	5	14	0.3	4.3	0.77	97.1	89.9213	64.92
2014	9	8	4	15	14	0.3	4.3	0.77	95.9	89.9213	65.4797
2014	9	8	4	25	14	0.3	4.3	0.76	95.7	89.9213	64.3604
2014	9	8	4	35	14	0.3	4.3	0.76	97.2	89.9213	64.3604
2014	9	8	4	45	14	0.3	4.3	0.78	96.8	89.9213	65.7595
2014	9	8	4	55	14	0.3	4.3	0.76	98.5	89.9213	63.8007
2014	9	8	5	5	14	0.3	4.3	0.75	97.5	89.9213	63.5209
2014	9	8	5	15	14	0.3	4.3	0.75	96.3	89.9213	63.8007
2014	9	8	5	25	14	0.3	4.3	0.74	97.7	89.9213	62.4016
2014	9	8	5	35	14	0.3	4.3	0.78	98	89.9213	66.0393
2014	9	8	5	45	14	0.3	4.3	0.78	97	89.9213	66.3191
2014	9	8	5	55	14	0.3	4.3	0.76	96.2	89.9213	64.6402
2014	9	8	6	5	14	0.3	4.3	0.74	97.9	89.9213	62.4016
2014	9	8	6	15	14	0.3	4.3	0.78	97	89.9213	65.7595
2014	9	8	6	25	14	0.3	4.3	0.75	95	89.9213	64.0805
2014	9	8	6	35	14	0.3	4.3	0.76	95.7	89.9213	64.3603
2014	9	8	6	45	14	0.3	4.3	0.75	95.3	89.9213	63.8007
2014	9	8	6	55	14	0.3	4.3	0.77	95.4	89.9213	65.4796
2014	9	8	7	5	14	0.3	4.3	0.75	95.3	89.9213	63.8007
2014	9	8	7	15	14	0.3	4.3	0.77	97.1	89.9213	65.4796
2014	9	8	7	25	14	0.3	4.3	0.79	96.2	89.9213	67.1586
2014	9	8	7	35	14	0.3	4.3	0.76	96	89.9213	64.0805
2014	9	8	7	45	14	0.3	4.3	0.76	95.7	89.9213	64.3603
2014	9	8	7	55	14	0.3	4.3	0.76	96.2	89.9213	64.3603
2014	9	8	8	5	14	0.3	4.3	0.76	97.2	89.9213	64.3603
2014	9	8	8	15	14	0.3	4.3	0.75	95	89.9213	63.8006

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	8	25	14	0.3	4.3	0.75	97.2	89.9869	63.8489
2014	9	8	8	35	14	0.3	4.3	0.77	96.1	89.9213	65.1998
2014	9	8	8	45	14	0.3	4.3	0.76	96.4	89.9213	64.3603
2014	9	8	8	55	14	0.3	4.3	0.77	97.1	89.9213	65.1997
2014	9	8	9	5	14	0.3	4.3	0.78	100.6	89.9213	65.4795
2014	9	8	9	15	14	0.3	4.3	0.77	101.1	89.9213	64.0804
2014	9	8	9	25	14	0.3	4.3	0.75	98.1	89.9213	63.2409
2014	9	8	9	35	14	0.3	4.3	0.77	100.7	89.9213	64.9199
2014	9	8	9	45	14	0.3	4.3	0.74	99.9	89.9869	62.4486
2014	9	8	9	55	14	0.3	4.3	0.78	101.2	89.9213	65.1997
2014	9	8	10	5	14	0.3	4.3	0.74	98.2	89.9213	62.1215
2014	9	8	10	15	14	0.3	4.3	0.73	100.6	89.9213	61.5619
2014	9	8	10	25	14	0.3	4.3	0.81	100.1	89.9213	67.718
2014	9	8	10	35	14	0.3	4.3	0.76	98.4	89.9213	64.3601
2014	9	8	10	45	14	0.3	4.3	0.77	99.1	89.9213	64.6399
2014	9	8	10	55	14	0.3	4.3	0.76	101.3	89.9213	63.2408
2014	9	8	11	5	14	0.3	4.3	0.77	98.6	89.9213	64.6399
2014	9	8	11	16	47	0.3	4.3	0.78	98.2	89.9213	65.7592
2014	9	8	11	26	47	0.3	4.3	0.78	98.3	89.9869	65.5289
2014	9	8	11	36	47	0.3	4.3	0.78	99.5	89.9869	65.2488
2014	9	8	11	46	47	0.3	4.3	0.76	101.2	89.8556	63.7522
2014	9	8	11	56	47	0.3	4.3	0.77	99.3	89.9213	65.1995
2014	9	8	12	6	47	0.3	4.3	0.76	101	89.9213	63.5205
2014	9	8	12	16	47	0.3	4.3	0.73	103.7	89.9213	60.7223
2014	9	8	12	26	47	0.3	4.3	0.76	99.7	89.9213	63.8003
2014	9	8	12	36	47	0.3	4.3	0.74	98.5	89.9213	62.1214
2014	9	8	12	46	47	0.3	4.3	0.76	98.7	89.9213	64.0801
2014	9	8	12	56	47	0.3	4.3	0.75	100.9	89.9213	62.4011
2014	9	8	13	6	47	0.3	4.3	0.77	98.6	89.8556	64.5909
2014	9	8	13	16	47	0.3	4.3	0.75	102.4	89.8556	62.0744
2014	9	8	13	26	47	0.3	4.3	0.81	98.9	89.8556	67.9464
2014	9	8	13	36	47	0.3	4.3	0.74	96.4	89.8556	62.354
2014	9	8	13	46	47	0.3	4.3	0.77	98.3	89.8556	65.1501
2014	9	8	13	56	47	0.3	4.3	0.77	97.1	89.8556	65.1501
2014	9	8	14	6	47	0.3	4.3	0.79	98.4	89.8556	66.5482
2014	9	8	14	16	47	0.3	4.3	0.78	98.3	89.8556	65.4297
2014	9	8	14	26	47	0.3	4.3	0.79	97.6	89.8556	66.8278
2014	9	8	14	36	47	0.3	4.3	0.76	99.5	89.8556	63.4724
2014	9	8	14	46	47	0.3	4.3	0.79	99.5	89.8556	66.5481
2014	9	8	14	56	47	0.3	4.3	0.75	101.6	89.79	62.8655
2014	9	8	15	6	47	0.3	4.3	0.79	99.3	89.79	66.4978
2014	9	8	15	16	47	0.3	4.3	0.78	98.7	89.8556	65.7093
2014	9	8	15	26	47	0.3	4.3	0.79	98.3	89.79	66.7772
2014	9	8	15	36	47	0.3	4.3	0.79	98.2	89.79	66.2184
2014	9	8	15	46	47	0.3	4.3	0.74	96.4	89.79	62.5861
2014	9	8	15	56	47	0.3	4.3	0.75	95	89.79	63.4244

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	16	6	47	0.3	4.3	0.81	98.9	89.79	67.8948
2014	9	8	16	16	47	0.3	4.3	0.76	97.2	89.79	63.9832
2014	9	8	16	26	47	0.3	4.3	0.76	98	89.79	63.7038
2014	9	8	16	36	47	0.3	4.3	0.76	97.5	89.79	63.9832
2014	9	8	16	46	47	0.3	4.3	0.76	96.2	89.79	63.9832
2014	9	8	16	56	47	0.3	4.3	0.76	98	89.79	63.9832
2014	9	8	17	6	47	0.3	4.3	0.74	96.9	89.79	62.5862
2014	9	8	17	16	47	0.3	4.3	0.76	97.7	89.79	64.2626
2014	9	8	17	26	47	0.3	4.3	0.78	96.7	89.79	66.2184
2014	9	8	17	36	47	0.3	4.3	0.77	94.9	89.79	65.3802
2014	9	8	17	46	47	0.3	4.3	0.74	96.9	89.79	62.5862
2014	9	8	17	56	47	0.3	4.3	0.77	96.4	89.79	64.8214
2014	9	8	18	6	47	0.3	4.3	0.74	96.4	89.79	62.3068
2014	9	8	18	16	47	0.3	4.3	0.74	97.1	89.79	62.8656
2014	9	8	18	26	47	0.3	4.3	0.76	96.9	89.79	64.2626
2014	9	8	18	36	47	0.3	4.3	0.79	96.2	89.79	67.0566
2014	9	8	18	46	47	0.3	4.3	0.76	95.7	89.79	63.9832
2014	9	8	18	56	47	0.3	4.3	0.76	96.4	89.79	64.2626
2014	9	8	19	6	47	0.3	4.3	0.75	96.3	89.79	63.7038
2014	9	8	19	16	47	0.3	4.3	0.75	95.5	89.79	63.7038
2014	9	8	19	26	47	0.3	4.3	0.76	97.2	89.8556	64.0316
2014	9	8	19	36	47	0.3	4.3	0.75	97.2	89.79	63.7038
2014	9	8	19	46	47	0.3	4.3	0.76	95.9	89.8556	64.5909
2014	9	8	19	56	47	0.3	4.3	0.75	96	89.8556	63.752
2014	9	8	20	6	47	0.3	4.3	0.75	96	89.8556	63.752
2014	9	8	20	16	47	0.3	4.3	0.76	96.9	89.8556	64.3112
2014	9	8	20	26	47	0.3	4.3	0.77	95.1	89.8556	65.4297
2014	9	8	20	36	47	0.3	4.3	0.79	97.6	89.8556	66.8277
2014	9	8	20	46	47	0.3	4.3	0.76	95.2	89.8556	64.3112
2014	9	8	20	56	47	0.3	4.3	0.74	98.1	89.8556	62.6335
2014	9	8	21	6	47	0.3	4.3	0.76	94.9	89.8556	64.5908
2014	9	8	21	16	47	0.3	4.3	0.76	96.2	89.8556	64.5908
2014	9	8	21	26	47	0.3	4.3	0.75	95.5	89.8556	64.0316
2014	9	8	21	36	47	0.3	4.3	0.76	93.2	89.8556	64.3112
2014	9	8	21	46	47	0.3	4.3	0.75	94.5	89.8556	63.4724
2014	9	8	21	56	47	0.3	4.3	0.78	98.4	89.8556	65.9889
2014	9	8	22	6	47	0.3	4.3	0.75	97.5	89.8556	63.752
2014	9	8	22	16	47	0.3	4.3	0.76	94.9	89.8556	64.5908
2014	9	8	22	26	47	0.3	4.3	0.82	96	89.8556	69.6238
2014	9	8	22	36	47	0.3	4.3	0.78	96.8	89.8556	65.7093
2014	9	8	22	46	47	0.3	4.3	0.75	94.8	89.8556	63.752
2014	9	8	22	56	47	0.3	4.3	0.74	96.4	89.8556	62.3539
2014	9	8	23	6	47	0.3	4.3	0.76	94.9	89.8556	64.8704
2014	9	8	23	16	47	0.3	4.3	0.75	96.5	89.8556	63.4724
2014	9	8	23	26	47	0.3	4.3	0.76	95	89.9213	64.3599
2014	9	8	23	36	47	0.3	4.3	0.77	94.2	89.8556	65.4296

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	23	46	47	0.3	4.3	0.74	96.6	89.8556	62.9131
2014	9	8	23	56	47	0.3	4.3	0.76	95.7	89.8556	64.0316
2014	9	9	0	6	47	0.3	4.3	0.76	93.9	89.8556	64.8704
2014	9	9	0	16	47	0.3	4.3	0.74	97.7	89.8556	62.3539
2014	9	9	0	26	47	0.3	4.3	0.75	94.7	89.8556	64.0316
2014	9	9	0	36	47	0.3	4.3	0.77	94.9	89.9213	65.1994
2014	9	9	0	46	47	0.3	4.3	0.78	96.8	89.9213	65.759
2014	9	9	0	56	47	0.3	4.3	0.76	97.4	89.9213	64.6397
2014	9	9	1	6	47	0.3	4.3	0.79	100	89.9213	66.5985
2014	9	9	1	16	47	0.3	4.3	0.74	95.9	89.9213	62.681
2014	9	9	1	26	47	0.3	4.3	0.75	96.3	89.8556	63.4724
2014	9	9	1	36	47	0.3	4.3	0.75	95	89.9213	64.0801
2014	9	9	1	46	47	0.3	4.3	0.77	97.4	89.9213	64.9196
2014	9	9	1	56	47	0.3	4.3	0.76	96	89.9213	64.0801
2014	9	9	2	6	47	0.3	4.3	0.77	96.4	89.9213	65.1994
2014	9	9	2	16	47	0.3	4.3	0.79	95.7	89.9213	67.1582
2014	9	9	2	26	47	0.3	4.3	0.77	95.9	89.9213	65.1994
2014	9	9	2	36	47	0.3	4.3	0.76	95.2	89.9213	64.9196
2014	9	9	2	46	47	0.3	4.3	0.76	96.2	89.9213	64.0802
2014	9	9	2	56	47	0.3	4.3	0.75	97.8	89.9213	63.5205
2014	9	9	3	6	47	0.3	4.3	0.76	96.5	89.9213	64.0802
2014	9	9	3	16	47	0.3	4.3	0.73	98	89.9213	61.5617
2014	9	9	3	26	47	0.3	4.3	0.76	94.9	89.9213	64.6398
2014	9	9	3	36	47	0.3	4.3	0.79	99.1	89.9213	66.3188
2014	9	9	3	46	47	0.3	4.3	0.75	97.2	89.9213	63.8004
2014	9	9	3	56	47	0.3	4.3	0.77	99	89.9213	65.1995
2014	9	9	4	6	47	0.3	4.3	0.74	95.1	89.9213	62.9609
2014	9	9	4	16	47	0.3	4.3	0.77	97.3	89.9213	65.1996
2014	9	9	4	26	47	0.3	4.3	0.77	95.1	89.9213	65.7592
2014	9	9	4	36	47	0.3	4.3	0.77	94.7	89.9213	65.1996
2014	9	9	4	46	47	0.3	4.3	0.76	97.4	89.9213	64.6399
2014	9	9	4	56	47	0.3	4.3	0.74	96.6	89.9213	62.961
2014	9	9	5	6	47	0.3	4.3	0.75	95	89.9213	64.0803
2014	9	9	5	16	47	0.3	4.3	0.75	96.3	89.9213	63.2408
2014	9	9	5	26	47	0.3	4.3	0.77	99	89.9213	65.1996
2014	9	9	5	36	47	0.3	4.3	0.76	94.4	89.9213	64.9198
2014	9	9	5	46	47	0.3	4.3	0.77	96.1	89.9213	65.1996
2014	9	9	5	56	47	0.3	4.3	0.77	97.9	89.9213	64.64
2014	9	9	6	6	47	0.3	4.3	0.76	95.4	89.9213	64.64
2014	9	9	6	16	47	0.3	4.3	0.76	96.4	89.9213	64.3602
2014	9	9	6	26	47	0.3	4.3	0.75	95.8	89.9213	63.8005
2014	9	9	6	36	47	0.3	4.3	0.76	99	89.9213	63.8006
2014	9	9	6	46	47	0.3	4.3	0.75	96.3	89.9213	63.8006
2014	9	9	6	56	47	0.3	4.3	0.73	95.4	89.9213	62.1216
2014	9	9	7	6	47	0.3	4.3	0.78	96.3	89.9213	65.7594
2014	9	9	7	16	47	0.3	4.3	0.76	94.7	89.9213	64.9199

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	7	26	47	0.3	4.3	0.79	94.8	89.9213	66.8787
2014	9	9	7	36	47	0.3	4.3	0.79	96.2	89.9213	66.5989
2014	9	9	7	46	47	0.3	4.3	0.76	96.9	89.9213	64.3603
2014	9	9	7	56	47	0.3	4.3	0.76	96.2	89.9213	64.0805
2014	9	9	8	6	47	0.3	4.3	0.73	98.5	89.9213	61.562
2014	9	9	8	16	47	0.3	4.3	0.75	95.5	89.9213	64.0805
2014	9	9	8	26	47	0.3	4.3	0.79	96.2	89.9213	66.5989
2014	9	9	8	36	47	0.3	4.3	0.78	94.6	89.9213	66.0393
2014	9	9	8	46	47	0.3	4.3	0.73	97.4	89.9213	62.1217
2014	9	9	8	56	47	0.3	4.3	0.78	97.5	89.9213	66.0393
2014	9	9	9	6	47	0.3	4.3	0.77	98.8	89.9213	64.92
2014	9	9	9	16	47	0.3	4.3	0.74	96.4	89.9213	62.6813
2014	9	9	9	26	47	0.3	4.3	0.75	96.3	89.9213	63.5208
2014	9	9	9	36	47	0.3	4.3	0.79	100.3	89.9213	66.3191
2014	9	9	9	46	47	0.3	4.3	0.77	96.9	89.9213	64.9199
2014	9	9	9	56	47	0.3	4.3	0.77	96.9	89.9213	65.1998
2014	9	9	10	6	47	0.3	4.3	0.74	97.2	89.9213	62.4015
2014	9	9	10	16	47	0.3	4.3	0.77	96.9	89.9213	64.9199
2014	9	9	10	26	47	0.3	4.3	0.78	99.4	89.9213	65.7594
2014	9	9	10	36	47	0.3	4.3	0.78	98.4	89.9213	66.0392
2014	9	9	10	46	47	0.3	4.3	0.76	96.2	89.8556	64.0319
2014	9	9	10	56	47	0.3	4.3	0.78	96.7	89.9213	66.319
2014	9	9	11	6	47	0.3	4.3	0.77	95.1	89.8556	65.7096
2014	9	9	11	16	47	0.3	4.3	0.77	96.2	89.8556	64.8707
2014	9	9	11	26	47	0.3	4.3	0.8	96.1	89.8556	67.9465
2014	9	9	11	36	47	0.3	4.3	0.75	96.3	89.8556	63.7522
2014	9	9	11	46	47	0.3	4.3	0.78	97	89.8556	66.2687
2014	9	9	11	56	47	0.3	4.3	0.76	96	89.8556	64.0318
2014	9	9	12	6	47	0.3	4.3	0.77	94.6	89.8556	65.7095
2014	9	9	12	16	47	0.3	4.3	0.75	96.3	89.8556	63.7522
2014	9	9	12	26	47	0.3	4.3	0.75	97.2	89.8556	63.7522
2014	9	9	12	36	47	0.3	4.3	0.76	98.4	89.8556	64.3114
2014	9	9	12	46	47	0.3	4.3	0.75	97.2	89.79	63.7039
2014	9	9	12	56	47	0.3	4.3	0.74	97.7	89.79	62.3069
2014	9	9	13	6	47	0.3	4.3	0.77	96.1	89.79	65.1009
2014	9	9	13	16	47	0.3	4.3	0.77	96.6	89.79	65.1009
2014	9	9	13	26	47	0.3	4.3	0.77	96.9	89.79	65.1009
2014	9	9	13	36	47	0.3	4.3	0.77	94.9	89.79	65.3803
2014	9	9	13	46	47	0.3	4.3	0.77	97.3	89.79	65.1009
2014	9	9	13	56	47	0.3	4.3	0.77	96.1	89.79	65.1009
2014	9	9	14	6	47	0.3	4.3	0.73	96.5	89.79	61.748
2014	9	9	14	16	47	0.3	4.3	0.8	96.8	89.79	67.8949
2014	9	9	14	26	47	0.3	4.3	0.8	96.6	89.79	67.6155
2014	9	9	14	36	47	0.3	4.3	0.8	95.9	89.7244	67.8434
2014	9	9	14	46	47	0.3	4.3	0.76	95.7	89.7244	64.2139
2014	9	9	14	56	47	0.3	4.3	0.76	96.4	89.7244	64.2139

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	15	6	47	0.3	4.3	0.75	96.8	89.7244	63.6556
2014	9	9	15	16	47	0.3	4.3	0.77	97.1	89.7244	65.0515
2014	9	9	15	26	47	0.3	4.3	0.77	97.8	89.7244	65.3307
2014	9	9	15	36	47	0.3	4.3	0.77	99.3	89.7244	64.7723
2014	9	9	15	46	47	0.3	4.3	0.79	97.2	89.7244	66.4475
2014	9	9	15	56	47	0.3	4.3	0.75	96.3	89.7244	63.3764
2014	9	9	16	6	47	0.3	4.3	0.75	94.3	89.7244	63.6556
2014	9	9	16	16	47	0.3	4.3	0.77	97.6	89.7244	65.0516
2014	9	9	16	26	47	0.3	4.3	0.76	98.2	89.7244	64.214
2014	9	9	16	36	47	0.3	4.3	0.78	100.2	89.7244	65.0516
2014	9	9	16	46	47	0.3	4.3	0.79	97.9	89.7244	66.4475
2014	9	9	16	56	47	0.3	4.3	0.79	98.2	89.7244	66.1683
2014	9	9	17	6	47	0.3	4.3	0.75	96.3	89.7244	63.0972
2014	9	9	17	16	47	0.3	4.3	0.76	97.2	89.7244	64.4932
2014	9	9	17	26	47	0.3	4.3	0.78	95.8	89.7244	65.8892
2014	9	9	17	36	47	0.3	4.3	0.78	98.2	89.7244	65.61
2014	9	9	17	46	47	0.3	4.3	0.76	96	89.7244	63.9348
2014	9	9	17	56	47	0.3	4.3	0.75	98.6	89.7244	62.8181
2014	9	9	18	6	47	0.3	4.3	0.76	97.7	89.7244	64.214
2014	9	9	18	16	47	0.3	4.3	0.78	98.5	89.7244	65.3308
2014	9	9	18	26	47	0.3	4.3	0.74	97.4	89.7244	62.5389
2014	9	9	18	36	47	0.3	4.3	0.75	98.6	89.7244	63.0973
2014	9	9	18	46	47	0.3	4.3	0.79	95.2	89.7244	67.2851
2014	9	9	18	56	47	0.3	4.3	0.77	97.1	89.7244	64.7724
2014	9	9	19	6	47	0.3	4.3	0.73	95.2	89.7244	61.7013
2014	9	9	19	16	47	0.3	4.3	0.77	96.4	89.7244	65.0516
2014	9	9	19	26	47	0.3	4.3	0.74	96.4	89.7244	62.5389
2014	9	9	19	36	47	0.3	4.3	0.77	96.4	89.79	64.8215
2014	9	9	19	46	47	0.3	4.3	0.76	92.7	89.79	64.2627
2014	9	9	19	56	47	0.3	4.3	0.76	95.7	89.79	64.2627
2014	9	9	20	6	47	0.3	4.3	0.78	95.5	89.79	66.2186
2014	9	9	20	16	47	0.3	4.3	0.77	96.9	89.79	64.8215
2014	9	9	20	26	47	0.3	4.3	0.77	96.6	89.79	65.3803
2014	9	9	20	36	47	0.3	4.3	0.74	98.2	89.79	62.3069
2014	9	9	20	46	47	0.3	4.3	0.76	96	89.79	63.9833
2014	9	9	20	56	47	0.3	4.3	0.78	95.8	89.79	65.9392
2014	9	9	21	6	47	0.3	4.3	0.77	98.6	89.79	64.5421
2014	9	9	21	16	47	0.3	4.3	0.73	97.5	89.79	61.7481
2014	9	9	21	26	47	0.3	4.3	0.76	95.7	89.79	64.2627
2014	9	9	21	36	47	0.3	4.3	0.77	98.4	89.79	64.5422
2014	9	9	21	46	47	0.3	4.3	0.76	96.2	89.79	63.9834
2014	9	9	21	56	47	0.3	4.3	0.72	97.1	89.79	60.9099
2014	9	9	22	6	47	0.3	4.3	0.75	97.5	89.79	63.4245
2014	9	9	22	16	47	0.3	4.3	0.73	95.1	89.79	62.3069
2014	9	9	22	26	47	0.3	4.3	0.77	97.3	89.79	65.101
2014	9	9	22	36	47	0.3	4.3	0.75	95.3	89.79	63.4246

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	22	46	47	0.3	4.3	0.76	94.7	89.79	64.8216
2014	9	9	22	56	47	0.3	4.3	0.73	94.6	89.79	62.307
2014	9	9	23	6	47	0.3	4.3	0.75	94.2	89.79	63.9834
2014	9	9	23	16	47	0.3	4.3	0.76	95.2	89.79	64.8216
2014	9	9	23	26	47	0.3	4.3	0.77	94.6	89.79	65.6598
2014	9	9	23	36	47	0.3	4.3	0.75	96.3	89.79	63.704
2014	9	9	23	46	47	0.3	4.3	0.75	95.8	89.79	63.4246
2014	9	9	23	56	47	0.3	4.3	0.77	97.1	89.79	65.1011
2014	9	10	0	6	47	0.3	4.3	0.77	96.1	89.79	65.1011
2014	9	10	0	16	47	0.3	4.3	0.77	96.6	89.79	65.3805
2014	9	10	0	26	47	0.3	4.3	0.77	93.7	89.79	65.1011
2014	9	10	0	36	47	0.3	4.3	0.75	96.8	89.79	63.1453
2014	9	10	0	46	47	0.3	4.3	0.78	96.5	89.79	66.2187
2014	9	10	0	56	47	0.3	4.3	0.75	96.3	89.79	63.7041
2014	9	10	1	6	47	0.3	4.3	0.78	96.5	89.79	65.9394
2014	9	10	1	16	47	0.3	4.3	0.76	93.2	89.79	64.263
2014	9	10	1	26	47	0.3	4.3	0.76	95.7	89.79	64.8218
2014	9	10	1	36	47	0.3	4.3	0.74	94.8	89.79	62.5866
2014	9	10	1	46	47	0.3	4.3	0.75	96.8	89.79	63.1454
2014	9	10	1	56	47	0.3	4.3	0.77	97.4	89.79	64.8218
2014	9	10	2	6	47	0.3	4.3	0.77	96.4	89.79	65.1013
2014	9	10	2	16	47	0.3	4.3	0.77	97.1	89.79	65.3807
2014	9	10	2	26	47	0.3	4.3	0.75	95.8	89.79	63.4249
2014	9	10	2	36	47	0.3	4.3	0.72	96.8	89.79	60.9102
2014	9	10	2	46	47	0.3	4.3	0.75	96.3	89.8556	63.4729
2014	9	10	2	56	47	0.3	4.3	0.75	97.2	89.8556	63.7526
2014	9	10	3	6	47	0.3	4.3	0.76	97.6	89.8556	64.5915
2014	9	10	3	16	47	0.3	4.3	0.79	95.7	89.8556	67.3876
2014	9	10	3	26	47	0.3	4.3	0.75	96.5	89.8556	63.7526
2014	9	10	3	36	47	0.3	4.3	0.75	94.7	89.8556	64.0323
2014	9	10	3	46	47	0.3	4.3	0.76	95	89.8556	64.3119
2014	9	10	3	56	47	0.3	4.3	0.75	96.5	89.8556	63.7527
2014	9	10	4	6	47	0.3	4.3	0.78	96.8	89.8556	65.9896
2014	9	10	4	16	47	0.3	4.3	0.74	95.1	89.8556	62.9139
2014	9	10	4	26	47	0.3	4.3	0.76	94.9	89.9213	64.9203
2014	9	10	4	36	47	0.3	4.3	0.75	96.1	89.9213	63.2414
2014	9	10	4	46	47	0.3	4.3	0.76	97.2	89.9213	64.3607
2014	9	10	4	56	47	0.3	4.3	0.77	95.3	89.9213	65.7599
2014	9	10	5	6	47	0.3	4.3	0.73	97.4	89.9213	62.1221
2014	9	10	5	16	47	0.3	4.3	0.74	95.3	89.9213	62.9616
2014	9	10	5	26	47	0.3	4.3	0.8	95.6	89.9213	67.9986
2014	9	10	5	36	47	0.3	4.3	0.75	97	89.9213	63.8012
2014	9	10	5	46	47	0.3	4.3	0.77	94.6	89.9213	65.76
2014	9	10	5	56	47	0.3	4.3	0.77	96.2	89.9213	64.9205
2014	9	10	6	6	47	0.3	4.3	0.73	95.1	89.9213	62.4021
2014	9	10	6	16	47	0.3	4.3	0.76	96.4	89.9213	64.3609

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	6	26	47	0.3	4.3	0.76	95.7	89.9213	64.6407
2014	9	10	6	36	47	0.3	4.3	0.76	98	89.9213	64.0811
2014	9	10	6	46	47	0.3	4.3	0.75	97.1	89.9869	63.2895
2014	9	10	6	56	47	0.3	4.3	0.77	95.6	89.9869	65.8099
2014	9	10	7	6	47	0.3	4.3	0.75	97.6	90.0525	63.3374
2014	9	10	7	16	47	0.3	4.3	0.77	95.9	90.0525	65.0189
2014	9	10	7	26	47	0.3	4.3	0.75	95.8	90.0525	63.8979
2014	9	10	7	36	47	0.3	4.3	0.76	94.9	90.0525	65.019
2014	9	10	7	46	47	0.3	4.3	0.77	96.6	90.0525	65.019
2014	9	10	7	56	47	0.3	4.3	0.74	98.6	90.0525	62.7769
2014	9	10	8	6	47	0.3	4.3	0.75	95.5	90.0525	63.6177
2014	9	10	8	16	47	0.3	4.3	0.76	98.4	90.0525	64.1782
2014	9	10	8	26	47	0.3	4.3	0.73	97.5	90.0525	61.6559
2014	9	10	8	36	47	0.3	4.3	0.79	96.9	90.0525	66.7005
2014	9	10	8	46	47	0.3	4.3	0.77	94.6	89.9869	65.5299
2014	9	10	8	56	47	0.3	4.3	0.76	95.7	89.9869	64.6898
2014	9	10	9	6	47	0.3	4.3	0.76	94.9	89.9213	64.9207
2014	9	10	9	16	47	0.3	4.3	0.76	97.2	89.9213	64.0812
2014	9	10	9	26	47	0.3	4.3	0.77	95.9	89.9213	64.9207
2014	9	10	9	36	47	0.3	4.3	0.76	98.5	89.9213	63.8014
2014	9	10	9	46	47	0.3	4.3	0.75	95.8	89.9213	63.2417
2014	9	10	9	56	47	0.3	4.3	0.76	97	89.8556	64.0327
2014	9	10	10	6	47	0.3	4.3	0.79	97.9	89.8556	66.5493
2014	9	10	10	16	47	0.3	4.3	0.79	96.7	89.8556	67.1085
2014	9	10	10	26	47	0.3	4.3	0.78	93.6	89.8556	65.99
2014	9	10	10	36	47	0.3	4.3	0.78	95.6	89.8556	65.99
2014	9	10	10	46	47	0.3	4.3	0.76	98	89.8556	63.7531
2014	9	10	10	56	47	0.3	4.3	0.76	96	89.79	63.9842
2014	9	10	11	6	47	0.3	4.3	0.78	97.8	89.79	65.6606
2014	9	10	11	16	47	0.3	4.3	0.75	96.3	89.79	63.4253
2014	9	10	11	26	47	0.3	4.3	0.74	96.8	89.79	62.8665
2014	9	10	11	36	47	0.3	4.3	0.8	97.3	89.79	67.8958
2014	9	10	11	46	47	0.3	4.3	0.79	101.2	89.79	66.2194
2014	9	10	11	56	47	0.3	4.3	0.77	101.8	89.79	63.9841
2014	9	10	12	6	47	0.3	4.3	0.77	98.3	89.79	64.8223
2014	9	10	12	16	47	0.3	4.3	0.77	99.3	89.79	64.5429
2014	9	10	12	26	47	0.3	4.3	0.78	99.4	89.7244	65.6107
2014	9	10	12	36	47	0.3	4.3	0.77	96.8	89.79	65.3811
2014	9	10	12	46	47	0.3	4.3	0.77	102.6	89.7244	63.6564
2014	9	10	12	56	47	0.3	4.3	0.78	100.6	89.7244	65.3315
2014	9	10	13	6	47	0.3	4.3	0.8	98.2	89.7244	67.5651
2014	9	10	13	16	47	0.3	4.3	0.78	99.5	89.7244	65.3315
2014	9	10	13	26	47	0.3	4.3	0.79	101.5	89.7244	65.8899
2014	9	10	13	36	47	0.3	4.3	0.76	98.4	89.7244	64.2147
2014	9	10	13	46	47	0.3	4.3	0.8	97.3	89.7244	67.2859
2014	9	10	13	56	47	0.3	4.3	0.78	101.5	89.7244	64.7731

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	14	6	47	0.3	4.3	0.76	96.7	89.7244	64.2147
2014	9	10	14	16	47	0.3	4.3	0.78	99.5	89.6588	65.003
2014	9	10	14	26	47	0.3	4.3	0.78	97.5	89.6588	65.8399
2014	9	10	14	36	47	0.3	4.3	0.77	98.1	89.6588	64.445
2014	9	10	14	46	47	0.3	4.3	0.77	96.6	89.6588	65.282
2014	9	10	14	56	47	0.3	4.3	0.77	98.8	89.6588	65.003
2014	9	10	15	6	47	0.3	4.3	0.76	97	89.6588	63.8871
2014	9	10	15	16	47	0.3	4.3	0.78	99.7	89.6588	65.282
2014	9	10	15	26	47	0.3	4.3	0.77	99.3	89.6588	65.003
2014	9	10	15	36	47	0.3	4.3	0.77	98.8	89.6588	65.003
2014	9	10	15	46	47	0.3	4.3	0.8	97.3	89.6588	67.2349
2014	9	10	15	56	47	0.3	3.9	0.77	96.8	89.5932	65.2325
2014	9	10	16	6	47	0.3	3.9	0.81	98.6	89.5932	68.0202
2014	9	10	16	16	47	0.3	3.9	0.76	99.7	89.5932	63.8386
2014	9	10	16	26	47	0.3	3.9	0.77	99.6	89.5932	64.1174
2014	9	10	16	36	47	0.3	4.3	0.76	98.2	89.6588	63.6082
2014	9	10	16	46	47	0.3	3.9	0.79	99.3	89.5932	66.6264
2014	9	10	16	56	47	0.3	3.9	0.76	102.3	89.5932	62.7236
2014	9	10	17	6	47	0.3	4.3	0.79	97.4	89.6588	66.398
2014	9	10	17	16	47	0.3	3.9	0.76	99.2	89.5932	63.8387
2014	9	10	17	26	47	0.3	3.9	0.8	96.2	89.5932	67.1839
2014	9	10	17	36	47	0.3	4.3	0.77	97.6	89.6588	65.0031
2014	9	10	17	46	47	0.3	3.9	0.76	96	89.5932	64.1175
2014	9	10	17	56	47	0.3	4.3	0.75	98	89.6588	63.3292
2014	9	10	18	6	47	0.3	3.9	0.78	99.5	89.5932	65.2326
2014	9	10	18	16	47	0.3	3.9	0.78	99.1	89.5932	65.7901
2014	9	10	18	26	47	0.3	3.9	0.79	96.9	89.5932	66.6264
2014	9	10	18	36	47	0.3	3.9	0.74	95.6	89.5932	62.4449
2014	9	10	18	46	47	0.3	4.3	0.76	95.7	89.6588	64.4452
2014	9	10	18	56	47	0.3	3.9	0.76	94.9	89.5932	64.675
2014	9	10	19	6	47	0.3	3.9	0.76	96	89.5932	63.8387
2014	9	10	19	16	47	0.3	4.3	0.74	96.4	89.6588	62.4923
2014	9	10	19	26	47	0.3	4.3	0.76	98.4	89.6588	64.1662
2014	9	10	19	36	47	0.3	3.9	0.75	97.3	89.5932	63.2812
2014	9	10	19	46	47	0.3	3.9	0.76	97.7	89.5932	63.8387
2014	9	10	19	56	47	0.3	4.3	0.76	96.5	89.6588	63.8872
2014	9	10	20	6	47	0.3	4.3	0.74	96.3	89.6588	62.7712
2014	9	10	20	16	47	0.3	4.3	0.77	96.4	89.6588	65.0031
2014	9	10	20	26	47	0.3	4.3	0.79	98.9	89.6588	66.119
2014	9	10	20	36	47	0.3	4.3	0.77	95.9	89.6588	64.7241
2014	9	10	20	46	47	0.3	4.3	0.78	96.1	89.6588	65.5611
2014	9	10	20	56	47	0.3	4.3	0.79	96.2	89.6588	66.398
2014	9	10	21	6	47	0.3	4.3	0.77	97.5	89.6588	65.2821
2014	9	10	21	16	47	0.3	4.3	0.76	95.7	89.6588	64.4451
2014	9	10	21	26	47	0.3	4.3	0.76	96.5	89.6588	63.8872
2014	9	10	21	36	47	0.3	4.3	0.77	96.6	89.6588	64.7241

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	21	46	47	0.3	4.3	0.77	98.6	89.6588	64.7241
2014	9	10	21	56	47	0.3	4.3	0.74	96.6	89.6588	62.7712
2014	9	10	22	6	47	0.3	4.3	0.77	97.6	89.6588	65.0031
2014	9	10	22	16	47	0.3	4.3	0.77	96.6	89.6588	64.7241
2014	9	10	22	26	47	0.3	4.3	0.76	94.9	89.6588	64.7241
2014	9	10	22	36	47	0.3	4.3	0.76	96.7	89.6588	64.1661
2014	9	10	22	46	47	0.3	4.3	0.76	96	89.6588	64.1661
2014	9	10	22	56	47	0.3	4.3	0.78	97.3	89.6588	65.5611
2014	9	10	23	6	47	0.3	4.3	0.78	98.3	89.6588	65.2821
2014	9	10	23	16	47	0.3	4.3	0.75	96.1	89.6588	63.0502
2014	9	10	23	26	47	0.3	4.3	0.74	97.4	89.6588	62.4922
2014	9	10	23	36	47	0.3	4.3	0.77	93.7	89.7244	65.6108
2014	9	10	23	46	47	0.3	4.3	0.77	97.1	89.7244	65.3316
2014	9	10	23	56	47	0.3	4.3	0.75	96.5	89.7244	63.6565
2014	9	11	0	6	47	0.3	4.3	0.77	96.6	89.7244	64.7732
2014	9	11	0	16	47	0.3	4.3	0.74	98.6	89.7244	62.5397
2014	9	11	0	26	47	0.3	4.3	0.78	95.3	89.7244	66.1692
2014	9	11	0	36	47	0.3	4.3	0.76	97.6	89.7244	64.4941
2014	9	11	0	46	47	0.3	4.3	0.79	98.1	89.7244	66.7276
2014	9	11	0	56	47	0.3	4.3	0.75	96.1	89.7244	63.0981
2014	9	11	1	6	47	0.3	4.3	0.77	97.6	89.7244	65.0525
2014	9	11	1	16	47	0.3	4.3	0.77	97.1	89.7244	65.0525
2014	9	11	1	26	47	0.3	4.3	0.75	97.5	89.7244	63.6565
2014	9	11	1	36	47	0.3	4.3	0.75	95.5	89.7244	63.3773
2014	9	11	1	46	47	0.3	4.3	0.77	96.6	89.7244	65.3317
2014	9	11	1	56	47	0.3	4.3	0.76	95.4	89.7244	64.7733
2014	9	11	2	6	47	0.3	4.3	0.74	97.6	89.7244	62.5398
2014	9	11	2	16	47	0.3	4.3	0.75	96.8	89.7244	63.3774
2014	9	11	2	26	47	0.3	4.3	0.77	96.6	89.7244	64.7734
2014	9	11	2	36	47	0.3	4.3	0.77	98.3	89.7244	65.0526
2014	9	11	2	46	47	0.3	4.3	0.77	98.1	89.7244	65.0526
2014	9	11	2	56	47	0.3	4.3	0.79	96.7	89.7244	66.7278
2014	9	11	3	6	47	0.3	4.3	0.75	96.1	89.7244	63.0983
2014	9	11	3	16	47	0.3	4.3	0.77	98.3	89.7244	64.7735
2014	9	11	3	26	47	0.3	4.3	0.75	95.2	89.7244	63.9359
2014	9	11	3	36	47	0.3	4.3	0.77	95.9	89.79	65.102
2014	9	11	3	46	47	0.3	4.3	0.78	96.3	89.79	65.9403
2014	9	11	3	56	47	0.3	4.3	0.72	96.3	89.79	61.1904
2014	9	11	4	6	47	0.3	4.3	0.76	97	89.79	63.9845
2014	9	11	4	16	47	0.3	4.3	0.74	96.1	89.79	62.8668
2014	9	11	4	26	47	0.3	4.3	0.76	94	89.79	64.5433
2014	9	11	4	36	47	0.3	4.3	0.74	96.1	89.8556	62.3553
2014	9	11	4	46	47	0.3	4.3	0.73	94.6	89.79	62.3081
2014	9	11	4	56	47	0.3	4.3	0.78	97	89.79	65.661
2014	9	11	5	6	47	0.3	4.3	0.79	95	89.79	67.3374
2014	9	11	5	16	47	0.3	4.3	0.75	98.3	89.79	63.1463

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	5	26	47	0.3	4.3	0.76	95.7	89.79	63.9846
2014	9	11	5	36	47	0.3	4.3	0.77	95.6	89.79	65.3816
2014	9	11	5	46	47	0.3	4.3	0.78	97.5	89.79	65.9405
2014	9	11	5	56	47	0.3	4.3	0.76	97.9	89.8556	64.3127
2014	9	11	6	6	47	0.3	4.3	0.75	95	89.79	63.4258
2014	9	11	6	16	47	0.3	4.3	0.74	97.1	89.8556	62.635
2014	9	11	6	26	47	0.3	4.3	0.75	95.2	89.9213	64.0816
2014	9	11	6	36	47	0.3	4.3	0.76	96.9	89.9213	64.6413
2014	9	11	6	46	47	0.3	4.3	0.77	95.9	89.9213	65.201
2014	9	11	6	56	47	0.3	4.3	0.77	95.4	89.9213	65.201
2014	9	11	7	6	47	0.3	4.3	0.78	95.8	89.9869	66.0905
2014	9	11	7	16	47	0.3	4.3	0.75	97.3	89.9869	63.5701
2014	9	11	7	26	47	0.3	4.3	0.79	96.7	89.9869	67.2107
2014	9	11	7	36	47	0.3	4.3	0.74	94.3	89.9869	63.01
2014	9	11	7	46	47	0.3	4.3	0.8	97.6	89.9869	67.4908
2014	9	11	7	56	47	0.3	4.3	0.77	96.9	89.9869	64.9704
2014	9	11	8	6	47	0.3	4.3	0.77	95.9	89.9869	64.9704
2014	9	11	8	16	47	0.3	4.3	0.77	97.1	89.9869	64.9704
2014	9	11	8	26	47	0.3	4.3	0.77	98.5	89.9869	65.2504
2014	9	11	8	36	47	0.3	4.3	0.75	96.3	89.9869	63.5701
2014	9	11	8	46	47	0.3	4.3	0.76	97.2	89.9869	64.4103
2014	9	11	8	56	47	0.3	4.3	0.79	96.5	89.9869	66.6506
2014	9	11	9	6	47	0.3	4.3	0.76	97.2	89.9869	64.1302
2014	9	11	9	16	47	0.3	4.3	0.77	96.9	89.9869	64.9704
2014	9	11	9	26	47	0.3	4.3	0.77	98.1	89.9869	64.6903
2014	9	11	9	36	47	0.3	4.3	0.75	97.3	89.9869	63.5701
2014	9	11	9	46	47	0.3	4.3	0.77	98.4	89.9213	64.6414
2014	9	11	9	56	47	0.3	4.3	0.77	98.6	89.9213	64.9212
2014	9	11	10	6	47	0.3	4.3	0.8	95.7	89.9213	67.7195
2014	9	11	10	16	47	0.3	4.3	0.76	94.2	89.8556	64.3128
2014	9	11	10	26	47	0.3	4.3	0.76	97.4	89.8556	64.3128
2014	9	11	10	36	47	0.3	4.3	0.75	97.1	89.79	63.1465
2014	9	11	10	46	47	0.3	4.3	0.76	97.9	89.79	64.2641
2014	9	11	10	56	47	0.3	4.3	0.77	97.9	89.79	64.8229
2014	9	11	11	6	47	0.3	4.3	0.78	98	89.7244	65.8905
2014	9	11	11	16	47	0.3	4.3	0.8	97.8	89.7244	67.5657
2014	9	11	11	26	47	0.3	4.3	0.76	97.2	89.7244	64.4945
2014	9	11	11	36	47	0.3	4.3	0.78	96.6	89.7244	65.6113
2014	9	11	11	46	47	0.3	4.3	0.77	95.9	89.7244	64.7737
2014	9	11	11	56	47	0.3	4.3	0.77	97.1	89.7244	65.3321
2014	9	11	12	6	47	0.3	4.3	0.76	99.7	89.6588	63.3296
2014	9	11	12	16	47	0.3	4.3	0.78	98.2	89.7244	65.8904
2014	9	11	12	26	47	0.3	4.3	0.79	100.3	89.6588	66.1195
2014	9	11	12	36	47	0.3	4.3	0.78	101.1	89.6588	65.2825
2014	9	11	12	46	47	0.3	4.3	0.77	101.8	89.6588	64.1666
2014	9	11	12	56	47	0.3	4.3	0.78	98	89.6588	65.5615

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	13	6	47	0.3	4.3	0.78	98.9	89.6588	65.5615
2014	9	11	13	16	47	0.3	4.3	0.78	101.7	89.6588	64.7245
2014	9	11	13	26	47	0.3	4.3	0.78	98.7	89.6588	65.2825
2014	9	11	13	36	47	0.3	4.3	0.77	101.3	89.6588	64.4455
2014	9	11	13	46	47	0.3	3.9	0.78	100.5	89.5932	64.9542
2014	9	11	13	56	47	0.3	3.9	0.79	100.2	89.5932	66.3481
2014	9	11	14	6	47	0.3	3.9	0.75	97.5	89.5932	63.5603
2014	9	11	14	16	47	0.3	3.9	0.77	100.5	89.5932	64.6754
2014	9	11	14	26	47	0.3	3.9	0.77	101.8	89.5932	63.8391
2014	9	11	14	36	47	0.3	3.9	0.79	102.4	89.5932	65.7905
2014	9	11	14	46	47	0.3	3.9	0.79	100.6	89.5932	65.7905
2014	9	11	14	56	47	0.3	3.9	0.75	100.8	89.5932	63.0028
2014	9	11	15	6	47	0.3	3.9	0.79	100.7	89.5932	66.3481
2014	9	11	15	16	47	0.3	3.9	0.79	100.6	89.5276	65.7406
2014	9	11	15	26	47	0.3	3.9	0.77	99.8	89.5276	64.6263
2014	9	11	15	36	47	0.3	3.9	0.8	98.3	89.5276	67.1334
2014	9	11	15	46	47	0.3	3.9	0.8	99.9	89.5276	67.1334
2014	9	11	15	56	47	0.3	3.9	0.78	99.4	89.5276	65.7406
2014	9	11	16	6	47	0.3	3.9	0.8	101.2	89.5276	66.2978
2014	9	11	16	16	47	0.3	3.9	0.78	97	89.5276	65.4621
2014	9	11	16	26	47	0.3	3.9	0.77	100	89.5276	64.6264
2014	9	11	16	36	47	0.3	3.9	0.8	97.8	89.5276	67.1335
2014	9	11	16	46	47	0.3	3.9	0.77	99.1	89.5276	64.6264
2014	9	11	16	56	47	0.3	3.9	0.78	99.7	89.5276	64.905
2014	9	11	17	6	47	0.3	3.9	0.79	96.7	89.5276	66.5763
2014	9	11	17	16	47	0.3	3.9	0.76	98.9	89.5276	63.7907
2014	9	11	17	26	47	0.3	3.9	0.78	98.5	89.5276	65.4621
2014	9	11	17	36	47	0.3	3.9	0.78	98	89.5276	65.1835
2014	9	11	17	46	47	0.3	3.9	0.8	98.7	89.5276	67.1335
2014	9	11	17	56	47	0.3	3.9	0.76	97.2	89.5276	63.7907
2014	9	11	18	6	47	0.3	3.9	0.79	97.4	89.5276	66.5764
2014	9	11	18	16	47	0.3	3.9	0.76	97	89.5932	63.8392
2014	9	11	18	26	47	0.3	3.9	0.77	97.9	89.5276	64.6264
2014	9	11	18	36	47	0.3	3.9	0.74	97.7	89.5932	62.1666
2014	9	11	18	46	47	0.3	3.9	0.75	98.3	89.5932	63.2817
2014	9	11	18	56	47	0.3	3.9	0.79	98.2	89.5932	66.0694
2014	9	11	19	6	47	0.3	3.9	0.77	94.9	89.5932	65.5118
2014	9	11	19	16	47	0.3	3.9	0.78	97	89.5932	65.7906
2014	9	11	19	26	47	0.3	3.9	0.76	95.5	89.5932	64.118
2014	9	11	19	36	47	0.3	3.9	0.77	94.9	89.5932	65.5118
2014	9	11	19	46	47	0.3	3.9	0.77	96.8	89.5932	65.233
2014	9	11	19	56	47	0.3	3.9	0.75	95.8	89.5932	63.0028
2014	9	11	20	6	47	0.3	3.9	0.78	97	89.5932	65.5118
2014	9	11	20	16	47	0.3	3.9	0.75	94.8	89.5932	63.2816
2014	9	11	20	26	47	0.3	4.3	0.77	96.4	89.6588	64.7246
2014	9	11	20	36	47	0.3	3.9	0.77	94.1	89.5932	65.5118

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	20	46	47	0.3	3.9	0.77	98.1	89.5932	64.9542
2014	9	11	20	56	47	0.3	3.9	0.79	98.2	89.5932	66.0693
2014	9	11	21	6	47	0.3	4.3	0.75	96.1	89.6588	63.0507
2014	9	11	21	16	47	0.3	4.3	0.76	98.2	89.6588	63.6086
2014	9	11	21	26	47	0.3	4.3	0.75	94.5	89.6588	63.8876
2014	9	11	21	36	47	0.3	4.3	0.77	95.9	89.6588	64.7246
2014	9	11	21	46	47	0.3	4.3	0.77	94.6	89.6588	65.5615
2014	9	11	21	56	47	0.3	4.3	0.78	96.1	89.6588	65.5615
2014	9	11	22	6	47	0.3	4.3	0.77	97.1	89.6588	65.0035
2014	9	11	22	16	47	0.3	4.3	0.77	98.1	89.6588	65.0035
2014	9	11	22	26	47	0.3	4.3	0.81	96.5	89.6588	68.0724
2014	9	11	22	36	47	0.3	4.3	0.77	95.9	89.6588	65.0035
2014	9	11	22	46	47	0.3	4.3	0.74	95.9	89.6588	62.4927
2014	9	11	22	56	47	0.3	4.3	0.78	96.3	89.6588	65.8405
2014	9	11	23	6	47	0.3	4.3	0.75	98.5	89.6588	63.3296
2014	9	11	23	16	47	0.3	4.3	0.8	96.9	89.6588	67.2354
2014	9	11	23	26	47	0.3	4.3	0.77	96.2	89.6588	64.7245
2014	9	11	23	36	47	0.3	4.3	0.73	97.4	89.6588	61.9347
2014	9	11	23	46	47	0.3	4.3	0.79	96.5	89.6588	66.3984
2014	9	11	23	56	47	0.3	4.3	0.78	96.6	89.6588	65.5615
2014	9	12	0	6	47	0.3	4.3	0.78	94.4	89.6588	65.8405
2014	9	12	0	16	47	0.3	4.3	0.78	94.6	89.7244	66.4488
2014	9	12	0	26	47	0.3	4.3	0.77	97.1	89.7244	64.7736
2014	9	12	0	36	47	0.3	4.3	0.8	97.3	89.7244	67.2864
2014	9	12	0	46	47	0.3	4.3	0.77	97.3	89.7244	65.0528
2014	9	12	0	56	47	0.3	4.3	0.77	95.9	89.7244	64.7737
2014	9	12	1	6	47	0.3	4.3	0.76	97.2	89.7244	63.9361
2014	9	12	1	16	47	0.3	4.3	0.78	98	89.7244	65.3321
2014	9	12	1	26	47	0.3	4.3	0.79	96.4	89.7244	67.0072
2014	9	12	1	36	47	0.3	4.3	0.74	96.1	89.7244	62.2609
2014	9	12	1	46	47	0.3	4.3	0.75	96	89.7244	63.6569
2014	9	12	1	56	47	0.3	4.3	0.76	96.5	89.7244	63.9361
2014	9	12	2	6	47	0.3	4.3	0.76	95.2	89.7244	64.4945
2014	9	12	2	16	47	0.3	4.3	0.77	97.1	89.7244	65.3321
2014	9	12	2	26	47	0.3	4.3	0.78	97	89.79	65.6611
2014	9	12	2	36	47	0.3	4.3	0.78	97.2	89.79	66.2199
2014	9	12	2	46	47	0.3	4.3	0.77	96.2	89.79	64.8229
2014	9	12	2	56	47	0.3	4.3	0.78	96.8	89.79	65.9405
2014	9	12	3	6	47	0.3	4.3	0.77	95.9	89.79	65.1023
2014	9	12	3	16	47	0.3	4.3	0.77	96.2	89.79	64.8229
2014	9	12	3	26	47	0.3	4.3	0.76	98.2	89.79	64.2641
2014	9	12	3	36	47	0.3	4.3	0.77	95.9	89.8556	64.872
2014	9	12	3	46	47	0.3	4.3	0.76	97	89.8556	64.0332
2014	9	12	3	56	47	0.3	4.3	0.81	98.9	89.9213	68.2792
2014	9	12	4	6	47	0.3	4.3	0.79	95.7	89.9213	67.1598
2014	9	12	4	16	47	0.3	4.3	0.75	95.2	89.9213	64.0817

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	4	26	47	0.3	4.3	0.78	98.2	89.9213	66.0405
2014	9	12	4	36	47	0.3	4.3	0.78	97.5	89.9869	66.3705
2014	9	12	4	46	47	0.3	4.3	0.77	95.9	89.9869	64.9703
2014	9	12	4	56	47	0.3	4.3	0.76	96	89.9869	64.1302
2014	9	12	5	6	47	0.3	4.3	0.78	95.8	89.9869	65.8105
2014	9	12	5	16	47	0.3	4.3	0.75	97.2	89.9869	63.8502
2014	9	12	5	26	47	0.3	4.3	0.78	96.7	89.9869	66.3706
2014	9	12	5	36	47	0.3	4.3	0.77	96.3	89.9869	65.5305
2014	9	12	5	46	47	0.3	4.3	0.76	95.7	90.0525	64.1788
2014	9	12	5	56	47	0.3	4.3	0.74	99.1	90.0525	62.7775
2014	9	12	6	6	47	0.3	4.3	0.79	97.9	90.0525	66.7011
2014	9	12	6	16	47	0.3	4.3	0.77	95.3	90.0525	65.8603
2014	9	12	6	26	47	0.3	4.3	0.77	97.1	90.0525	65.5801
2014	9	12	6	36	47	0.3	4.3	0.76	95.7	90.0525	65.0196
2014	9	12	6	46	47	0.3	4.3	0.78	97.8	90.0525	65.8604
2014	9	12	6	56	47	0.3	4.3	0.79	95.9	90.0525	67.2617
2014	9	12	7	6	47	0.3	4.3	0.75	97.2	90.0525	63.8986
2014	9	12	7	16	47	0.3	4.3	0.76	96	90.0525	64.1789
2014	9	12	7	26	47	0.3	4.3	0.76	95.7	90.0525	65.0196
2014	9	12	7	36	47	0.3	4.3	0.76	95.4	90.0525	64.7394
2014	9	12	7	46	47	0.3	4.3	0.76	94.9	90.0525	65.0197
2014	9	12	7	56	47	0.3	4.3	0.76	96	90.0525	64.1789
2014	9	12	8	6	47	0.3	4.3	0.76	96.9	90.1181	64.7883
2014	9	12	8	16	47	0.3	4.3	0.77	95.9	90.0525	65.2999
2014	9	12	8	26	47	0.3	4.3	0.78	96.3	90.1181	65.9101
2014	9	12	8	36	47	0.3	4.3	0.77	96.4	90.1181	65.0687
2014	9	12	8	46	47	0.3	4.3	0.75	97.3	90.0525	63.6183
2014	9	12	8	56	47	0.3	4.3	0.75	96	90.0525	63.8986
2014	9	12	9	6	47	0.3	4.3	0.77	96.6	90.0525	65.2999
2014	9	12	9	16	47	0.3	4.3	0.78	97	90.0525	65.8604
2014	9	12	9	26	47	0.3	4.3	0.77	96.8	90.0525	65.5801
2014	9	12	9	36	47	0.3	4.3	0.76	96.5	90.0525	64.1788
2014	9	12	9	46	47	0.3	4.3	0.78	95.6	90.1181	66.1905
2014	9	12	9	56	47	0.3	4.3	0.82	98.1	90.0525	68.9431
2014	9	12	10	6	47	0.3	4.3	0.75	97.3	90.0525	63.6182
2014	9	12	10	16	47	0.3	4.3	0.82	96.2	90.0525	69.5036
2014	9	12	10	26	47	0.3	4.3	0.77	98.1	90.0525	65.0195
2014	9	12	10	36	47	0.3	4.3	0.8	98.5	90.0525	67.5418
2014	9	12	10	46	47	0.3	4.3	0.77	97.1	90.0525	65.0195
2014	9	12	10	56	47	0.3	4.3	0.77	99.6	90.0525	64.4589
2014	9	12	11	6	47	0.3	4.3	0.77	98.1	90.0525	64.7392
2014	9	12	11	16	47	0.3	4.3	0.77	98.5	90.0525	65.2997
2014	9	12	11	26	47	0.3	4.3	0.8	98.8	90.0525	67.2614
2014	9	12	11	36	47	0.3	4.3	0.78	99.4	89.9869	66.0904
2014	9	12	11	46	47	0.3	4.3	0.79	98.4	89.9869	66.6505
2014	9	12	11	56	47	0.3	4.3	0.77	101.7	89.9869	64.6902

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	12	6	47	0.3	4.3	0.79	99.3	89.9869	66.3704
2014	9	12	12	16	47	0.3	4.3	0.79	99	89.9213	66.8799
2014	9	12	12	26	47	0.3	4.3	0.79	101.4	89.9213	66.3202
2014	9	12	12	36	47	0.3	4.3	0.78	98	89.8556	65.7108
2014	9	12	12	46	47	0.3	4.3	0.8	98.3	89.8556	67.3885
2014	9	12	12	56	47	0.3	4.3	0.8	100.8	89.79	67.3375
2014	9	12	13	6	47	0.3	4.3	0.75	101.8	89.79	62.8669
2014	9	12	13	16	47	0.3	4.3	0.79	100.6	89.7244	65.8904
2014	9	12	13	26	47	0.3	4.3	0.78	98.7	89.79	65.3816
2014	9	12	13	36	47	0.3	4.3	0.78	98.7	89.7244	65.8904
2014	9	12	13	46	47	0.3	4.3	0.79	97.9	89.7244	66.728
2014	9	12	13	56	47	0.3	4.3	0.78	101.7	89.7244	64.7736
2014	9	12	14	6	47	0.3	4.3	0.8	99	89.7244	67.2864
2014	9	12	14	16	47	0.3	4.3	0.79	100.3	89.6588	66.1194
2014	9	12	14	26	47	0.3	4.3	0.8	101.1	89.6588	66.9564
2014	9	12	14	36	47	0.3	4.3	0.79	101	89.6588	65.8404
2014	9	12	14	46	47	0.3	4.3	0.77	99.3	89.6588	65.0035
2014	9	12	14	56	47	0.3	4.3	0.79	100	89.6588	66.1194
2014	9	12	15	6	47	0.3	4.3	0.79	97.8	89.6588	66.9564
2014	9	12	15	16	47	0.3	4.3	0.77	100.5	89.6588	64.7245
2014	9	12	15	26	47	0.3	3.9	0.8	99.2	89.5932	67.1844
2014	9	12	15	36	47	0.3	4.3	0.79	100.8	89.6588	66.1194
2014	9	12	15	46	47	0.3	4.3	0.78	96.6	89.6588	65.5615
2014	9	12	15	56	47	0.3	4.3	0.81	99.3	89.6588	67.7934
2014	9	12	16	6	47	0.3	4.3	0.78	99.1	89.6588	65.8405
2014	9	12	16	16	47	0.3	3.9	0.79	99.3	89.5932	66.0693
2014	9	12	16	26	47	0.3	3.9	0.77	100.3	89.5932	64.1179
2014	9	12	16	36	47	0.3	3.9	0.78	99.2	89.5932	65.233
2014	9	12	16	46	47	0.3	4.3	0.77	99.5	89.6588	64.7246
2014	9	12	16	56	47	0.3	3.9	0.77	99.5	89.5932	64.6754
2014	9	12	17	6	47	0.3	3.9	0.79	100.8	89.5932	66.0693
2014	9	12	17	16	47	0.3	4.3	0.77	98.1	89.6588	64.4456
2014	9	12	17	26	47	0.3	4.3	0.78	98	89.6588	65.8405
2014	9	12	17	36	47	0.3	4.3	0.8	99.5	89.6588	66.9564
2014	9	12	17	46	47	0.3	4.3	0.82	100.4	89.6588	68.3514
2014	9	12	17	56	47	0.3	3.9	0.8	101.4	89.5932	66.6269
2014	9	12	18	6	47	0.3	4.3	0.79	100.3	89.6588	65.8405
2014	9	12	18	16	47	0.3	4.3	0.79	99	89.6588	66.6775
2014	9	12	18	26	47	0.3	4.3	0.78	99.1	89.6588	65.8405
2014	9	12	18	36	47	0.3	4.3	0.79	98.9	89.6588	66.1195
2014	9	12	18	46	47	0.3	4.3	0.78	97.2	89.6588	66.1195
2014	9	12	18	56	47	0.3	4.3	0.8	98	89.6588	67.2354
2014	9	12	19	6	47	0.3	4.3	0.79	95.9	89.6588	66.9564
2014	9	12	19	16	47	0.3	4.3	0.79	94.5	89.6588	67.2354
2014	9	12	19	26	47	0.3	4.3	0.77	96.6	89.6588	64.7245
2014	9	12	19	36	47	0.3	4.3	0.74	97.6	89.7244	62.8192

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	19	46	47	0.3	4.3	0.78	97	89.7244	66.1696
2014	9	12	19	56	47	0.3	4.3	0.78	97	89.7244	65.6112
2014	9	12	20	6	47	0.3	4.3	0.75	96	89.7244	63.6568
2014	9	12	20	16	47	0.3	4.3	0.78	95.8	89.7244	66.1696
2014	9	12	20	26	47	0.3	4.3	0.78	97.2	89.7244	66.1696
2014	9	12	20	36	47	0.3	4.3	0.78	96.6	89.7244	65.6112
2014	9	12	20	46	47	0.3	4.3	0.76	96	89.7244	63.936
2014	9	12	20	56	47	0.3	4.3	0.76	96	89.7244	63.936
2014	9	12	21	6	47	0.3	4.3	0.78	96	89.7244	66.1695
2014	9	12	21	16	47	0.3	4.3	0.75	96.3	89.7244	63.3776
2014	9	12	21	26	47	0.3	4.3	0.78	97	89.7244	66.1695
2014	9	12	21	36	47	0.3	4.3	0.74	96.3	89.7244	62.8191
2014	9	12	21	46	47	0.3	4.3	0.78	97	89.79	65.9403
2014	9	12	21	56	47	0.3	4.3	0.8	97.1	89.79	67.6167
2014	9	12	22	6	47	0.3	4.3	0.76	97.9	89.79	64.2638
2014	9	12	22	16	47	0.3	4.3	0.77	92.4	89.79	65.3814
2014	9	12	22	26	47	0.3	4.3	0.79	94.3	89.79	67.0579
2014	9	12	22	36	47	0.3	4.3	0.78	98.3	89.79	65.3814
2014	9	12	22	46	47	0.3	4.3	0.75	97.5	89.79	63.4256
2014	9	12	22	56	47	0.3	4.3	0.8	95.6	89.8556	67.9475
2014	9	12	23	6	47	0.3	4.3	0.76	97.2	89.9869	64.4099
2014	9	12	23	16	47	0.3	4.3	0.77	95.9	89.9869	64.97
2014	9	12	23	26	47	0.3	4.3	0.77	96.1	89.9869	65.25
2014	9	12	23	36	47	0.3	4.3	0.76	99.1	90.0525	64.4586
2014	9	12	23	46	47	0.3	4.3	0.75	95.5	90.0525	64.1783
2014	9	12	23	56	47	0.3	4.3	0.77	94.9	90.0525	65.8599
2014	9	13	0	6	47	0.3	4.3	0.76	94.7	90.0525	65.0191
2014	9	13	0	16	47	0.3	4.3	0.73	96.9	90.0525	62.2165
2014	9	13	0	26	47	0.3	4.3	0.76	96.4	90.0525	64.7388
2014	9	13	0	36	47	0.3	4.3	0.76	95.7	90.0525	64.1783
2014	9	13	0	46	47	0.3	4.3	0.75	96.5	90.1181	63.9463
2014	9	13	0	56	47	0.3	4.3	0.76	96.7	90.1181	64.2268
2014	9	13	1	6	47	0.3	4.3	0.77	94.6	90.1181	65.9096
2014	9	13	1	16	47	0.3	4.3	0.76	96.2	90.1181	64.5073
2014	9	13	1	26	47	0.3	4.3	0.79	96.2	90.1181	66.751
2014	9	13	1	36	47	0.3	4.3	0.78	97	90.1181	66.4706
2014	9	13	1	46	47	0.3	4.3	0.76	95.2	90.1181	64.7878
2014	9	13	1	56	47	0.3	4.3	0.78	95.1	90.1181	66.1901
2014	9	13	2	6	47	0.3	4.3	0.78	97	90.1181	66.4706
2014	9	13	2	16	47	0.3	4.3	0.8	96.3	90.1181	68.1534
2014	9	13	2	26	47	0.3	4.3	0.77	96.1	90.1181	65.3487
2014	9	13	2	36	47	0.3	4.3	0.78	97.2	90.1181	66.4706
2014	9	13	2	46	47	0.3	4.3	0.76	96.4	90.1181	64.7878
2014	9	13	2	56	47	0.3	4.3	0.77	96.4	90.1837	65.3981
2014	9	13	3	6	47	0.3	4.3	0.79	96.2	90.1837	66.8015
2014	9	13	3	16	47	0.3	4.3	0.76	96.5	90.1837	64.2754

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	3	26	47	0.3	4.3	0.74	97.7	90.1837	62.5913
2014	9	13	3	36	47	0.3	4.3	0.77	97.1	90.1837	65.3981
2014	9	13	3	46	47	0.3	4.3	0.78	95.6	90.1837	66.2402
2014	9	13	3	56	47	0.3	4.3	0.79	97.9	90.1837	66.5209
2014	9	13	4	6	47	0.3	4.3	0.78	97	90.1837	66.5209
2014	9	13	4	16	47	0.3	4.3	0.77	97.1	90.1837	65.1175
2014	9	13	4	26	47	0.3	4.3	0.78	97.5	90.1837	66.2402
2014	9	13	4	36	47	0.3	4.3	0.8	96.6	90.1837	67.6436
2014	9	13	4	46	47	0.3	4.3	0.78	95.8	90.1837	65.9596
2014	9	13	4	56	47	0.3	4.3	0.77	95.9	90.1837	65.6789
2014	9	13	5	6	47	0.3	4.3	0.77	96.3	90.1837	65.6789
2014	9	13	5	16	47	0.3	4.3	0.77	95.4	90.1837	65.3982
2014	9	13	5	26	47	0.3	4.3	0.76	96.9	90.2494	64.8858
2014	9	13	5	36	47	0.3	4.3	0.76	95.7	90.2494	64.324
2014	9	13	5	46	47	0.3	4.3	0.78	96.1	90.2494	66.0094
2014	9	13	5	56	47	0.3	4.3	0.75	98.3	90.2494	63.7622
2014	9	13	6	6	47	0.3	4.3	0.76	95.4	90.2494	65.1667
2014	9	13	6	16	47	0.3	4.3	0.78	96.5	90.2494	66.5712
2014	9	13	6	26	47	0.3	4.3	0.78	96.6	90.2494	66.0094
2014	9	13	6	36	47	0.3	4.3	0.74	97.1	90.2494	62.9196
2014	9	13	6	46	47	0.3	4.3	0.8	96.6	90.2494	68.2566
2014	9	13	6	56	47	0.3	4.3	0.78	96.3	90.2494	66.5712
2014	9	13	7	6	47	0.3	4.3	0.79	96.9	90.2494	66.8521
2014	9	13	7	16	47	0.3	4.3	0.75	96	90.2494	64.0432
2014	9	13	7	26	47	0.3	4.3	0.78	95.1	90.2494	66.2903
2014	9	13	7	36	47	0.3	4.3	0.78	95.5	90.2494	66.5712
2014	9	13	7	46	47	0.3	4.3	0.77	97.1	90.2494	65.4477
2014	9	13	7	56	47	0.3	4.3	0.75	96	90.2494	64.0432
2014	9	13	8	6	47	0.3	4.3	0.78	96.5	90.2494	66.2903
2014	9	13	8	16	47	0.3	4.3	0.77	95.9	90.2494	65.7286
2014	9	13	8	26	47	0.3	4.3	0.77	95.9	90.2494	65.4477
2014	9	13	8	36	47	0.3	4.3	0.76	98.7	90.2494	64.605
2014	9	13	8	46	47	0.3	4.3	0.76	97.4	90.2494	64.605
2014	9	13	8	56	47	0.3	4.3	0.75	97.3	90.2494	63.7623
2014	9	13	9	6	47	0.3	4.3	0.77	98.1	90.2494	65.4476
2014	9	13	9	16	47	0.3	4.3	0.79	95.7	90.2494	67.1329
2014	9	13	9	26	47	0.3	4.3	0.78	95.6	90.2494	66.2903
2014	9	13	9	36	47	0.3	4.3	0.76	97.4	90.2494	64.6049
2014	9	13	9	46	47	0.3	4.3	0.78	95.6	90.2494	66.2902
2014	9	13	9	56	47	0.3	4.3	0.79	96	90.2494	66.852
2014	9	13	10	6	47	0.3	4.3	0.8	97.1	90.2494	67.9755
2014	9	13	10	16	47	0.3	4.3	0.79	97.9	90.2494	67.1329
2014	9	13	10	26	47	0.3	4.3	0.75	96.8	90.2494	64.043
2014	9	13	10	36	47	0.3	4.3	0.82	99.9	90.2494	69.0991
2014	9	13	10	46	47	0.3	4.3	0.79	97.6	90.2494	67.4137
2014	9	13	10	56	47	0.3	4.3	0.77	99.8	90.1837	65.1174

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	11	6	47	0.3	4.3	0.77	97.5	90.1837	65.6788
2014	9	13	11	16	47	0.3	4.3	0.76	99.4	90.1837	64.2754
2014	9	13	11	26	47	0.3	4.3	0.78	96.6	90.1837	65.9594
2014	9	13	11	36	47	0.3	4.3	0.82	98	90.1837	69.6082
2014	9	13	11	46	47	0.3	4.3	0.77	99.6	90.1837	64.556
2014	9	13	11	56	47	0.3	4.3	0.78	101.2	90.1837	65.398
2014	9	13	12	6	47	0.3	4.3	0.76	100	90.1181	63.9463
2014	9	13	12	16	47	0.3	4.3	0.79	97.7	90.1181	66.751
2014	9	13	12	26	47	0.3	4.3	0.79	101	90.1181	66.4705
2014	9	13	12	36	47	0.3	4.3	0.77	100.9	90.1181	64.2268
2014	9	13	12	46	47	0.3	4.3	0.78	98.7	90.0525	65.5796
2014	9	13	12	56	47	0.3	4.3	0.77	101.8	90.0525	64.1783
2014	9	13	13	6	47	0.3	4.3	0.8	99	89.9869	67.4903
2014	9	13	13	16	47	0.3	4.3	0.81	101.5	89.9869	67.4903
2014	9	13	13	26	47	0.3	4.3	0.75	99.8	90.0525	63.3376
2014	9	13	13	36	47	0.3	4.3	0.79	100	89.9213	66.3199
2014	9	13	13	46	47	0.3	4.3	0.78	99.7	89.9869	65.81
2014	9	13	13	56	47	0.3	4.3	0.78	100	89.9869	65.2499
2014	9	13	14	6	47	0.3	4.3	0.78	99.7	89.9869	65.2499
2014	9	13	14	16	47	0.3	4.3	0.76	98.5	89.8556	63.7532
2014	9	13	14	26	47	0.3	4.3	0.79	101.7	89.8556	65.9901
2014	9	13	14	36	47	0.3	4.3	0.77	99	89.8556	65.1513
2014	9	13	14	46	47	0.3	4.3	0.81	100.5	89.79	67.6166
2014	9	13	14	56	47	0.3	4.3	0.79	98.6	89.8556	66.829
2014	9	13	15	6	47	0.3	4.3	0.8	99.2	89.79	67.0578
2014	9	13	15	16	47	0.3	4.3	0.78	101.1	89.79	65.3814
2014	9	13	15	26	47	0.3	4.3	0.77	101.1	89.79	64.2638
2014	9	13	15	36	47	0.3	4.3	0.76	98.7	89.79	63.705
2014	9	13	15	46	47	0.3	4.3	0.74	96.8	89.7244	62.8191
2014	9	13	15	58	29	0.3	4.3	0.74	98.7	89.79	62.3079
2014	9	13	16	8	29	0.3	4.3	0.82	100.4	89.8556	68.5068
2014	9	13	16	18	29	0.3	4.3	0.78	100	89.79	65.102
2014	9	13	16	28	29	0.3	4.3	0.79	99.9	89.79	65.9403
2014	9	13	16	38	29	0.3	4.3	0.82	98.1	89.79	69.0137
2014	9	13	16	48	29	0.3	4.3	0.78	95	89.79	66.4991
2014	9	13	16	58	29	0.3	4.3	0.8	97.7	89.79	67.8961
2014	9	13	17	8	29	0.3	4.3	0.76	99	89.79	63.705
2014	9	13	17	18	29	0.3	4.3	0.76	96.7	89.79	64.2638
2014	9	13	17	28	29	0.3	4.3	0.77	97.6	89.79	65.1021
2014	9	13	17	38	29	0.3	4.3	0.76	97.4	89.8556	64.3125
2014	9	13	17	48	29	0.3	4.3	0.77	97.6	89.8556	65.1514
2014	9	13	17	58	29	0.3	4.3	0.75	97.5	89.79	63.4256
2014	9	13	18	8	29	0.3	4.3	0.75	97.5	89.79	63.4256
2014	9	13	18	18	29	0.3	4.3	0.76	95.4	89.8556	64.8717
2014	9	13	18	28	29	0.3	4.3	0.78	95.3	89.79	66.2197
2014	9	13	18	38	29	0.3	4.3	0.77	95.9	89.79	65.102

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	18	48	29	0.3	4.3	0.78	96.3	89.79	65.9403
2014	9	13	18	58	29	0.3	4.3	0.78	95.1	89.79	65.9403
2014	9	13	19	8	29	0.3	4.3	0.78	95.8	89.79	66.4991
2014	9	13	19	18	29	0.3	4.3	0.77	95.6	89.79	65.3814
2014	9	13	19	28	29	0.3	4.3	0.77	95.9	89.79	64.8226
2014	9	13	19	38	29	0.3	4.3	0.77	96.3	89.79	65.3814
2014	9	13	19	48	29	0.3	4.3	0.77	97.5	89.79	65.3814
2014	9	13	19	58	29	0.3	4.3	0.76	96	89.79	63.9844
2014	9	13	20	8	29	0.3	4.3	0.8	96.6	89.79	67.6167
2014	9	13	20	18	29	0.3	4.3	0.75	97.1	89.8556	63.194
2014	9	13	20	28	29	0.3	4.3	0.76	94	89.8556	64.5921
2014	9	13	20	38	29	0.3	4.3	0.77	97.1	89.8556	65.4309
2014	9	13	20	48	29	0.3	4.3	0.8	96.2	89.8556	67.3882
2014	9	13	20	58	29	0.3	4.3	0.77	94.9	89.9213	65.7603
2014	9	13	21	8	29	0.3	4.3	0.75	95.5	89.8556	64.0328
2014	9	13	21	18	29	0.3	4.3	0.78	96.6	89.9213	65.7602
2014	9	13	21	28	29	0.3	4.3	0.75	95	89.9213	64.0813
2014	9	13	21	38	29	0.3	4.3	0.77	95.6	89.9869	65.5299
2014	9	13	21	48	29	0.3	4.3	0.76	95.9	89.9869	64.6898
2014	9	13	21	58	29	0.3	4.3	0.76	95.9	89.9869	64.6898
2014	9	13	22	8	29	0.3	4.3	0.78	98.5	89.9869	65.81
2014	9	13	22	18	29	0.3	4.3	0.77	96.3	90.0525	65.5795
2014	9	13	22	28	29	0.3	4.3	0.76	97.4	89.9869	64.4098
2014	9	13	22	38	29	0.3	4.3	0.76	97.2	90.0525	64.4585
2014	9	13	22	48	29	0.3	4.3	0.76	95.7	90.1181	64.7876
2014	9	13	22	58	29	0.3	4.3	0.76	96.7	90.0525	64.1782
2014	9	13	23	8	29	0.3	4.3	0.79	95	90.0525	66.9807
2014	9	13	23	18	29	0.3	4.3	0.79	96.2	90.0525	66.7005
2014	9	13	23	28	29	0.3	4.3	0.78	96.3	90.1181	66.1899
2014	9	13	23	38	29	0.3	4.3	0.77	94.2	90.1181	65.629
2014	9	13	23	48	29	0.3	4.3	0.74	96.9	90.1181	62.8243
2014	9	13	23	58	29	0.3	4.3	0.77	97.4	90.1181	65.0681
2014	9	14	0	8	29	0.3	4.3	0.74	95.6	90.1181	62.8243
2014	9	14	0	18	29	0.3	4.3	0.75	95.2	90.1181	64.2267
2014	9	14	0	28	29	0.3	4.3	0.77	95.6	90.1181	65.629
2014	9	14	0	38	29	0.3	4.3	0.79	97.4	90.1181	67.0313
2014	9	14	0	48	29	0.3	4.3	0.77	96.6	90.1181	65.629
2014	9	14	0	58	29	0.3	4.3	0.76	96	90.1181	64.2267
2014	9	14	1	8	29	0.3	4.3	0.76	96	90.1181	64.5071
2014	9	14	1	18	29	0.3	4.3	0.75	96.6	90.1181	63.3853
2014	9	14	1	28	29	0.3	4.3	0.78	94.6	90.1181	66.4704
2014	9	14	1	38	29	0.3	4.3	0.76	97.6	90.1181	64.7876
2014	9	14	1	48	29	0.3	4.3	0.78	97	90.1181	65.9095
2014	9	14	1	58	29	0.3	4.3	0.75	97.2	90.1837	63.9945
2014	9	14	2	8	29	0.3	4.3	0.75	95.5	90.1837	63.7138
2014	9	14	2	18	29	0.3	4.3	0.79	96.2	90.1837	67.082

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	2	28	29	0.3	4.3	0.76	94.9	90.1837	65.1173
2014	9	14	2	38	29	0.3	4.3	0.74	95.1	90.1837	63.1525
2014	9	14	2	48	29	0.3	4.3	0.76	95.7	90.1837	64.8366
2014	9	14	2	58	29	0.3	4.3	0.76	97.9	90.1837	64.5559
2014	9	14	3	8	29	0.3	4.3	0.78	96.8	90.1837	66.24
2014	9	14	3	18	29	0.3	4.3	0.8	94.5	90.1837	68.4854
2014	9	14	3	28	29	0.3	4.3	0.78	98	90.1837	65.6786
2014	9	14	3	38	29	0.3	4.3	0.77	98.4	90.1837	64.8366
2014	9	14	3	48	29	0.3	4.3	0.77	97.4	90.1837	65.1173
2014	9	14	3	58	29	0.3	4.3	0.75	93.5	90.1837	64.2753
2014	9	14	4	8	29	0.3	4.3	0.76	96.5	90.1837	64.2753
2014	9	14	4	18	29	0.3	4.3	0.79	96.2	90.1837	67.0821
2014	9	14	4	28	29	0.3	4.3	0.75	94.8	90.1837	63.7139
2014	9	14	4	38	29	0.3	4.3	0.74	96.3	90.1837	63.1526
2014	9	14	4	48	29	0.3	4.3	0.78	97.3	90.1837	65.9594
2014	9	14	4	58	29	0.3	4.3	0.77	97.3	90.2494	65.4474
2014	9	14	5	8	29	0.3	4.3	0.79	96.7	90.2494	67.4136
2014	9	14	5	18	29	0.3	4.3	0.78	96.8	90.2494	66.2901
2014	9	14	5	28	29	0.3	4.3	0.77	95.9	90.2494	65.4474
2014	9	14	5	38	29	0.3	4.3	0.75	97	90.315	64.0912
2014	9	14	5	48	29	0.3	4.3	0.78	95.8	90.315	66.9023
2014	9	14	5	58	29	0.3	4.3	0.78	95.5	90.2494	66.8519
2014	9	14	6	8	29	0.3	4.3	0.77	96.6	90.315	65.2157
2014	9	14	6	18	29	0.3	4.3	0.77	95.6	90.315	65.7779
2014	9	14	6	28	29	0.3	4.3	0.77	95.9	90.315	65.4968
2014	9	14	6	38	29	0.3	4.3	0.76	97.9	90.315	64.6535
2014	9	14	6	48	29	0.3	4.3	0.77	95.2	90.315	65.4968
2014	9	14	6	58	29	0.3	4.3	0.77	96.1	90.315	65.4968
2014	9	14	7	8	29	0.3	4.3	0.78	94.8	90.315	66.9023
2014	9	14	7	18	29	0.3	4.3	0.77	94.6	90.315	65.7779
2014	9	14	7	28	29	0.3	4.3	0.74	97.9	90.315	62.6858
2014	9	14	7	38	29	0.3	4.3	0.79	97.7	90.315	66.9023
2014	9	14	7	48	29	0.3	4.3	0.76	95.9	90.2494	64.8857
2014	9	14	7	58	29	0.3	4.3	0.77	97.1	90.315	65.4968
2014	9	14	8	8	29	0.3	4.3	0.77	97.5	90.315	65.7779
2014	9	14	8	18	29	0.3	4.3	0.76	97.2	90.315	64.3724
2014	9	14	8	28	29	0.3	4.3	0.76	95.4	90.315	65.2157
2014	9	14	8	38	29	0.3	4.3	0.77	95.6	90.315	65.7779
2014	9	14	8	48	29	0.3	4.3	0.75	96.6	90.315	63.5291
2014	9	14	8	58	29	0.3	4.3	0.74	97.6	90.315	63.248
2014	9	14	9	8	29	0.3	4.3	0.75	96.3	90.315	64.0913
2014	9	14	9	18	29	0.3	4.3	0.78	96.6	90.315	66.059
2014	9	14	9	28	29	0.3	4.3	0.75	93.8	90.2494	64.0429
2014	9	14	9	38	29	0.3	4.3	0.78	97	90.2494	66.0092
2014	9	14	9	48	29	0.3	4.3	0.77	96.8	90.315	65.7778
2014	9	14	9	58	29	0.3	4.3	0.78	96.8	90.315	66.34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	10	8	29	0.3	4.3	0.78	99.2	90.2494	65.7282
2014	9	14	10	18	29	0.3	4.3	0.75	96	90.2494	64.0429
2014	9	14	10	28	29	0.3	4.3	0.77	97.6	90.2494	65.4473
2014	9	14	10	38	29	0.3	4.3	0.8	98.5	90.2494	67.6944
2014	9	14	10	48	29	0.3	4.3	0.79	98.1	90.2494	66.8517
2014	9	14	10	58	29	0.3	4.3	0.77	99.8	90.2494	65.1664
2014	9	14	11	8	29	0.3	4.3	0.78	101.6	90.2494	65.4472
2014	9	14	11	18	29	0.3	4.3	0.76	96.7	90.1837	64.5558
2014	9	14	11	28	29	0.3	4.3	0.79	97.4	90.1837	66.8013
2014	9	14	11	38	29	0.3	4.3	0.78	98.2	90.1837	66.2399
2014	9	14	11	48	29	0.3	4.3	0.77	101.1	90.1837	64.5558
2014	9	14	11	58	29	0.3	4.3	0.78	101.8	90.1837	65.6785
2014	9	14	12	8	29	0.3	4.3	0.78	102.6	90.1837	65.3979
2014	9	14	12	18	29	0.3	4.3	0.81	98.8	90.1181	68.7142
2014	9	14	12	28	29	0.3	4.3	0.79	102.5	90.0525	65.8598
2014	9	14	12	38	29	0.3	4.3	0.77	96.8	90.0525	65.5795
2014	9	14	12	48	29	0.3	4.3	0.78	100.4	90.1181	65.9095
2014	9	14	12	58	29	0.3	4.3	0.78	97.3	90.0525	65.8597
2014	9	14	13	8	29	0.3	4.3	0.79	97.1	89.9869	67.2101
2014	9	14	13	18	29	0.3	4.3	0.81	98.4	90.0525	68.1017
2014	9	14	13	28	29	0.3	4.3	0.78	97.8	90.0525	65.8596
2014	9	14	13	38	29	0.3	4.3	0.78	95.8	89.9869	66.0899
2014	9	14	13	48	29	0.3	4.3	0.78	97	89.9213	65.7601
2014	9	14	13	58	29	0.3	4.3	0.81	98.4	89.9869	68.3302
2014	9	14	14	8	29	0.3	4.3	0.76	96.7	89.9869	64.4096
2014	9	14	14	18	29	0.3	4.3	0.8	100	89.9213	66.8794
2014	9	14	14	28	29	0.3	4.3	0.76	96.2	89.9213	64.3609
2014	9	14	14	38	29	0.3	4.3	0.77	97.1	89.9213	65.4802
2014	9	14	14	48	29	0.3	4.3	0.79	99.9	89.8556	65.99
2014	9	14	14	58	29	0.3	4.3	0.77	95.9	89.8556	65.4307
2014	9	14	15	8	29	0.3	4.3	0.76	98.9	89.8556	64.0326
2014	9	14	15	18	29	0.3	4.3	0.77	101.1	89.8556	64.3123
2014	9	14	15	28	29	0.3	4.3	0.77	98.1	89.8556	64.5919
2014	9	14	15	38	29	0.3	4.3	0.78	99.9	89.8556	65.4307
2014	9	14	15	48	29	0.3	4.3	0.78	101.1	89.8556	65.4307
2014	9	14	15	58	29	0.3	4.3	0.75	100.1	89.8556	62.6345
2014	9	14	16	8	29	0.3	4.3	0.77	100.5	89.79	64.8224
2014	9	14	16	18	29	0.3	4.3	0.77	100.8	89.8556	64.5919
2014	9	14	16	28	29	0.3	4.3	0.77	98.1	89.79	65.1018
2014	9	14	16	38	29	0.3	4.3	0.77	96.9	89.79	65.1018
2014	9	14	16	48	29	0.3	4.3	0.79	98.4	89.8556	66.5493
2014	9	14	16	58	29	0.3	4.3	0.77	98.1	89.79	65.1019
2014	9	14	17	8	29	0.3	4.3	0.77	97.1	89.8556	65.1512
2014	9	14	17	18	29	0.3	4.3	0.73	96.2	89.8556	62.0754
2014	9	14	17	28	29	0.3	4.3	0.77	97.6	89.8556	65.1512
2014	9	14	17	38	29	0.3	4.3	0.75	95.3	89.8556	63.7531

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	17	48	29	0.3	4.3	0.75	96	89.9213	63.8013
2014	9	14	17	58	29	0.3	4.3	0.76	96.2	89.9213	64.0812
2014	9	14	18	8	29	0.3	4.3	0.76	94.5	89.8556	64.5919
2014	9	14	18	18	29	0.3	4.3	0.78	95	89.9213	66.5996
2014	9	14	18	28	29	0.3	4.3	0.78	95	89.9213	66.5996
2014	9	14	18	38	29	0.3	4.3	0.75	95.2	89.9213	64.0811
2014	9	14	18	48	29	0.3	4.3	0.77	97.3	89.9213	65.4803
2014	9	14	18	58	29	0.3	4.3	0.75	97	89.9213	63.8013
2014	9	14	19	8	29	0.3	4.3	0.74	96.9	89.9213	62.682
2014	9	14	19	18	29	0.3	4.3	0.77	95.9	89.9213	65.2005
2014	9	14	19	28	29	0.3	4.3	0.75	97.8	89.9213	63.2416
2014	9	14	19	38	29	0.3	4.3	0.76	97.6	89.9869	64.6897
2014	9	14	19	48	29	0.3	4.3	0.76	96	89.9869	64.1296
2014	9	14	19	58	29	0.3	4.3	0.75	95	90.0525	64.1781
2014	9	14	20	8	29	0.3	4.3	0.77	92.9	90.0525	65.5794
2014	9	14	20	18	29	0.3	4.3	0.75	97.7	90.1181	63.9461
2014	9	14	20	28	29	0.3	4.3	0.78	95.8	90.1181	66.7507
2014	9	14	20	38	29	0.3	4.3	0.75	95.5	90.1181	64.2265
2014	9	14	20	48	29	0.3	4.3	0.78	93.2	90.1181	66.1898
2014	9	14	20	58	29	0.3	4.3	0.75	96.5	90.1181	63.9461
2014	9	14	21	8	29	0.3	4.3	0.76	96.7	90.1181	64.2265
2014	9	14	21	18	29	0.3	4.3	0.79	94.5	90.1181	67.0312
2014	9	14	21	28	29	0.3	4.3	0.77	97.8	90.1837	65.6784
2014	9	14	21	38	29	0.3	4.3	0.77	96.9	90.1837	65.3977
2014	9	14	21	48	29	0.3	4.3	0.77	94.6	90.1837	65.9591
2014	9	14	21	58	29	0.3	4.3	0.77	95.6	90.1837	65.3977
2014	9	14	22	8	29	0.3	4.3	0.77	94.2	90.1837	65.6784
2014	9	14	22	18	29	0.3	4.3	0.76	95.7	90.1837	64.8363
2014	9	14	22	28	29	0.3	4.3	0.76	97.2	90.2494	64.3235
2014	9	14	22	38	29	0.3	4.3	0.76	94.2	90.2494	64.6044
2014	9	14	22	48	29	0.3	4.3	0.77	96.6	90.2494	65.7279
2014	9	14	22	58	29	0.3	4.3	0.77	97.1	90.2494	65.1661
2014	9	14	23	8	29	0.3	4.3	0.76	95	90.2494	64.6043
2014	9	14	23	18	29	0.3	4.3	0.77	97.4	90.2494	65.1661
2014	9	14	23	28	29	0.3	4.3	0.74	96.8	90.2494	63.1999
2014	9	14	23	38	29	0.3	4.3	0.77	96.4	90.2494	65.447
2014	9	14	23	48	29	0.3	4.3	0.77	97.1	90.2494	65.7279
2014	9	14	23	58	29	0.3	4.3	0.78	95.5	90.2494	66.8514
2014	9	15	0	8	29	0.3	4.3	0.77	95.9	90.315	65.2152
2014	9	15	0	18	29	0.3	4.3	0.79	96	90.315	67.1829
2014	9	15	0	28	29	0.3	4.3	0.78	96.6	90.315	66.0585
2014	9	15	0	38	29	0.3	4.3	0.79	94.8	90.315	67.1829
2014	9	15	0	48	29	0.3	4.3	0.74	98.6	90.315	62.9664
2014	9	15	0	58	29	0.3	4.3	0.76	96	90.315	64.3719
2014	9	15	1	8	29	0.3	4.3	0.78	95.8	90.315	66.6207
2014	9	15	1	18	29	0.3	4.3	0.77	97.3	90.315	65.7775

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	1	28	29	0.3	4.3	0.74	94.8	90.315	62.9665
2014	9	15	1	38	29	0.3	4.3	0.79	97.2	90.315	67.183
2014	9	15	1	48	29	0.3	4.3	0.76	94.5	90.315	64.9342
2014	9	15	1	58	29	0.3	4.3	0.76	96.4	90.315	64.6531
2014	9	15	2	8	29	0.3	4.3	0.77	95.9	90.315	65.4964
2014	9	15	2	18	29	0.3	4.3	0.77	97.9	90.315	65.2153
2014	9	15	2	28	29	0.3	4.3	0.76	95	90.315	64.6531
2014	9	15	2	38	29	0.3	4.3	0.8	96.6	90.315	68.0263
2014	9	15	2	48	29	0.3	4.3	0.77	94.7	90.315	65.4964
2014	9	15	2	58	29	0.3	4.3	0.79	96.2	90.315	67.183
2014	9	15	3	8	29	0.3	4.3	0.76	97.2	90.315	64.372
2014	9	15	3	18	29	0.3	4.3	0.76	96.2	90.315	64.372
2014	9	15	3	28	29	0.3	4.3	0.76	96.9	90.315	64.9342
2014	9	15	3	38	29	0.3	4.3	0.78	95.6	90.315	66.3398
2014	9	15	3	48	29	0.3	4.3	0.76	95.7	90.315	64.3721
2014	9	15	3	58	29	0.3	4.3	0.76	98.2	90.315	64.3721
2014	9	15	4	8	29	0.3	4.3	0.76	98.7	90.315	64.3721
2014	9	15	4	18	29	0.3	4.3	0.77	95.6	90.3806	66.1085
2014	9	15	4	28	29	0.3	4.3	0.77	94.6	90.3806	65.8271
2014	9	15	4	38	29	0.3	4.3	0.75	97.2	90.315	64.091
2014	9	15	4	48	55	0.3	4.3	0.78	95.8	90.3806	66.9524
2014	9	15	4	58	55	0.3	4.3	0.79	95.2	90.3806	67.515
2014	9	15	5	8	55	0.3	4.3	0.78	94.8	90.3806	66.6711
2014	9	15	5	18	55	0.3	4.3	0.74	96.1	90.3806	63.0141
2014	9	15	5	28	55	0.3	4.3	0.75	97.1	90.3806	63.5767
2014	9	15	5	38	55	0.3	4.3	0.79	95.7	90.3806	67.5151
2014	9	15	5	48	55	0.3	4.3	0.79	96.2	90.3806	67.2338
2014	9	15	5	58	55	0.3	4.3	0.8	96.8	90.3806	68.359
2014	9	15	6	8	55	0.3	4.3	0.79	96.4	90.3806	67.5151
2014	9	15	6	18	55	0.3	4.3	0.78	96.1	90.3806	66.1086
2014	9	15	6	28	55	0.3	4.3	0.78	96.5	90.3806	66.6712
2014	9	15	6	38	55	0.3	4.3	0.8	93.8	90.3806	68.6404
2014	9	15	6	48	55	0.3	4.3	0.79	97.4	90.3806	67.2338
2014	9	15	6	58	55	0.3	4.3	0.78	94.6	90.3806	66.3899
2014	9	15	7	8	55	0.3	4.3	0.77	94.9	90.3806	66.1086
2014	9	15	7	18	55	0.3	4.3	0.78	95.8	90.3806	66.9525
2014	9	15	7	28	55	0.3	4.3	0.77	95.9	90.3806	65.546
2014	9	15	7	38	55	0.3	4.3	0.76	97	90.3806	64.4207
2014	9	15	7	48	55	0.3	4.3	0.78	94.6	90.3806	66.3899
2014	9	15	7	58	55	0.3	4.3	0.77	96.1	90.3806	65.546
2014	9	15	8	8	55	0.3	4.3	0.77	97.1	90.3806	65.546
2014	9	15	8	18	55	0.3	4.3	0.8	96.9	90.3806	67.7965
2014	9	15	8	28	55	0.3	4.3	0.77	96.3	90.3806	65.8273
2014	9	15	8	38	55	0.3	4.3	0.77	98.3	90.3806	65.546
2014	9	15	8	48	55	0.3	4.3	0.77	97.1	90.3806	65.546
2014	9	15	8	58	55	0.3	4.3	0.78	96.1	90.3806	66.1086

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	9	8	55	0.3	4.3	0.78	98.7	90.3806	66.3899
2014	9	15	9	18	55	0.3	4.3	0.79	97.7	90.3806	66.9525
2014	9	15	9	28	55	0.3	4.3	0.79	97.1	90.3806	67.5151
2014	9	15	9	38	55	0.3	4.3	0.77	96.4	90.3806	65.5459
2014	9	15	9	48	55	0.3	4.3	0.76	96.2	90.3806	64.702
2014	9	15	9	58	55	0.3	4.3	0.78	97.3	90.3806	66.1085
2014	9	15	10	8	55	0.3	4.3	0.78	94.8	90.3806	66.6711
2014	9	15	10	18	55	0.3	4.3	0.79	96	90.3806	67.2337
2014	9	15	10	28	55	0.3	4.3	0.8	99.5	90.3806	67.515
2014	9	15	10	38	55	0.3	4.3	0.77	96.4	90.3806	65.5458
2014	9	15	10	48	55	0.3	4.3	0.77	95.4	90.3806	65.8271
2014	9	15	10	58	55	0.3	4.3	0.78	100.4	90.3806	66.1084
2014	9	15	11	8	55	0.3	4.3	0.78	100	90.3806	65.5458
2014	9	15	11	18	55	0.3	4.3	0.78	98.7	90.3806	66.3897
2014	9	15	11	28	55	0.3	4.3	0.79	100.3	90.3806	66.3897
2014	9	15	11	38	55	0.3	4.3	0.77	98.9	90.315	64.9342
2014	9	15	11	48	55	0.3	4.3	0.77	99.9	90.315	64.6531
2014	9	15	11	58	55	0.3	4.3	0.8	99.7	90.315	67.183
2014	9	15	12	11	2	0.3	4.3	0.81	96.5	90.315	68.8695
2014	9	15	12	21	2	0.3	4.3	0.78	98.2	90.315	66.0585
2014	9	15	12	31	2	0.3	4.3	0.78	98.7	90.315	66.0585
2014	9	15	12	41	2	0.3	4.3	0.77	97.8	90.315	65.7774
2014	9	15	12	51	2	0.3	4.3	0.78	102.6	90.315	65.2152
2014	9	15	13	1	2	0.3	4.3	0.78	98.7	90.315	66.0585
2014	9	15	13	11	2	0.3	4.3	0.78	102.9	90.2494	64.8852
2014	9	15	13	21	2	0.3	4.3	0.77	102	90.2494	64.6043
2014	9	15	13	31	2	0.3	4.3	0.8	99.9	90.2494	67.4131
2014	9	15	13	41	2	0.3	4.3	0.8	97.3	90.1837	67.643
2014	9	15	13	51	2	0.3	4.3	0.8	102.3	90.1837	67.0816
2014	9	15	14	1	2	0.3	4.3	0.79	102.5	90.1181	65.6287
2014	9	15	14	11	2	0.3	4.3	0.77	97.4	90.1837	65.1169
2014	9	15	14	21	2	0.3	4.3	0.76	102.3	90.1181	63.1045
2014	9	15	14	31	2	0.3	4.3	0.79	102.8	90.1181	65.6287
2014	9	15	14	41	2	0.3	4.3	0.77	99.3	90.1181	65.3482
2014	9	15	14	51	2	0.3	4.3	0.79	96.9	90.1181	67.031
2014	9	15	15	1	2	0.3	4.3	0.82	102.3	90.0525	68.1015
2014	9	15	15	11	2	0.3	4.3	0.77	100.8	90.0525	64.7384
2014	9	15	15	21	2	0.3	4.3	0.81	100.5	90.0525	67.8212
2014	9	15	15	31	2	0.3	4.3	0.79	99.9	90.0525	66.1397
2014	9	15	15	41	2	0.3	4.3	0.77	100.1	90.0525	64.7384
2014	9	15	15	51	2	0.3	4.3	0.77	100.5	90.0525	64.7384
2014	9	15	16	1	2	0.3	4.3	0.8	101.1	90.0525	66.9805
2014	9	15	16	11	2	0.3	4.3	0.78	101.9	90.0525	65.0187
2014	9	15	16	21	2	0.3	4.3	0.75	102.3	90.0525	62.7767
2014	9	15	16	31	2	0.3	4.3	0.78	100.2	89.9869	65.5296
2014	9	15	16	41	2	0.3	4.3	0.8	99.2	89.9869	67.2099

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	16	51	2	0.3	4.3	0.79	100.6	89.9869	66.0897
2014	9	15	17	1	2	0.3	4.3	0.79	101.2	89.9869	66.3698
2014	9	15	17	11	2	0.3	4.3	0.79	98.1	90.0525	66.9805
2014	9	15	17	21	2	0.3	4.3	0.77	98.1	90.0525	64.7384
2014	9	15	17	31	2	0.3	4.3	0.79	98.8	90.0525	66.9805
2014	9	15	17	41	2	0.3	4.3	0.79	96	89.9869	66.9298
2014	9	15	17	51	2	0.3	4.3	0.78	99.5	89.9869	65.2496
2014	9	15	18	1	2	0.3	4.3	0.76	98.2	89.9869	64.1294
2014	9	15	18	11	2	0.3	4.3	0.79	96.9	89.9869	66.9298
2014	9	15	18	21	2	0.3	4.3	0.79	97.4	90.0525	66.9804
2014	9	15	18	31	2	0.3	4.3	0.73	95.7	90.0525	62.2161
2014	9	15	18	41	2	0.3	4.3	0.76	97.2	90.1181	64.7873
2014	9	15	18	51	2	0.3	4.3	0.78	97.8	90.1181	65.9092
2014	9	15	19	1	2	0.3	4.3	0.76	97.2	90.1181	64.5068
2014	9	15	19	11	2	0.3	4.3	0.8	96.1	90.1181	68.1529
2014	9	15	19	21	2	0.3	4.3	0.78	97	90.1181	65.9091
2014	9	15	19	31	2	0.3	4.3	0.77	96.4	90.1181	65.3482
2014	9	15	19	41	2	0.3	4.3	0.77	96.1	90.1181	65.3482
2014	9	15	19	51	2	0.3	4.3	0.78	97.3	90.1181	65.9091
2014	9	15	20	1	2	0.3	4.3	0.75	96.3	90.1837	63.7135
2014	9	15	20	11	2	0.3	4.3	0.77	96.9	90.1837	65.3975
2014	9	15	20	21	2	0.3	4.3	0.75	95.5	90.1837	64.2748
2014	9	15	20	31	2	0.3	4.3	0.78	96.6	90.1837	65.9588
2014	9	15	20	41	2	0.3	4.3	0.75	96.8	90.1837	63.7134
2014	9	15	20	51	2	0.3	4.3	0.75	97.2	90.1837	63.9941
2014	9	15	21	1	2	0.3	4.3	0.76	98.7	90.2494	64.3232
2014	9	15	21	11	2	0.3	4.3	0.79	95	90.2494	67.413
2014	9	15	21	21	2	0.3	4.3	0.78	96.3	90.2494	66.0086
2014	9	15	21	31	2	0.3	4.3	0.78	97	90.2494	66.5703
2014	9	15	21	41	2	0.3	4.3	0.79	94.7	90.2494	67.6939
2014	9	15	21	51	2	0.3	4.3	0.82	95	90.2494	69.9409
2014	9	15	22	1	2	0.3	4.3	0.75	95	90.2494	64.3232
2014	9	15	22	11	2	0.3	4.3	0.78	97	90.2494	66.0085
2014	9	15	22	21	2	0.3	4.3	0.78	96.1	90.2494	66.0085
2014	9	15	22	31	2	0.3	4.3	0.79	98.2	90.2494	66.5703
2014	9	15	22	41	2	0.3	4.3	0.77	97.1	90.2494	65.1658
2014	9	15	22	51	2	0.3	4.3	0.76	95.7	90.2494	64.604
2014	9	15	23	1	2	0.3	4.3	0.79	96	90.2494	67.132
2014	9	15	23	11	2	0.3	4.3	0.74	94.6	90.315	63.5283
2014	9	15	23	21	2	0.3	4.3	0.76	95.7	90.2494	64.8849
2014	9	15	23	31	2	0.3	4.3	0.75	96.6	90.2494	63.4805
2014	9	15	23	41	2	0.3	4.3	0.76	96.7	90.315	64.6527
2014	9	15	23	51	2	0.3	4.3	0.77	96.4	90.315	65.496
2014	9	16	0	1	2	0.3	4.3	0.76	94.7	90.315	65.2149
2014	9	16	0	11	2	0.3	4.3	0.77	95.4	90.2494	65.7276
2014	9	16	0	21	2	0.3	4.3	0.8	96.1	90.315	68.307

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	0	31	2	0.3	4.3	0.8	96.2	90.315	67.7448
2014	9	16	0	41	2	0.3	4.3	0.76	95.7	90.315	64.6527
2014	9	16	0	51	2	0.3	4.3	0.78	94.6	90.315	66.3393
2014	9	16	1	1	2	0.3	4.3	0.76	94.7	90.315	64.9338
2014	9	16	1	11	2	0.3	4.3	0.78	98.2	90.315	66.3393
2014	9	16	1	21	2	0.3	4.3	0.74	95.3	90.315	63.5283
2014	9	16	1	31	2	0.3	4.3	0.78	96.8	90.315	66.3393
2014	9	16	1	41	2	0.3	4.3	0.8	97.8	90.315	67.7448
2014	9	16	1	51	2	0.3	4.3	0.8	95.7	90.315	68.0259
2014	9	16	2	1	2	0.3	4.3	0.79	96.9	90.315	66.9016
2014	9	16	2	11	2	0.3	4.3	0.76	97.5	90.315	64.3717
2014	9	16	2	21	2	0.3	4.3	0.77	94.4	90.315	66.0583
2014	9	16	2	31	2	0.3	4.3	0.74	96.6	90.315	63.2473
2014	9	16	2	41	2	0.3	4.3	0.79	96.4	90.315	67.1827
2014	9	16	2	51	2	0.3	4.3	0.76	96.2	90.315	64.6528
2014	9	16	3	1	2	0.3	4.3	0.75	97.7	90.315	64.0906
2014	9	16	3	11	2	0.3	4.3	0.76	95.4	90.315	65.215
2014	9	16	3	21	2	0.3	4.3	0.8	96.9	90.315	67.7449
2014	9	16	3	31	2	0.3	4.3	0.77	97.1	90.315	65.4961
2014	9	16	3	41	2	0.3	4.3	0.8	95.9	90.315	68.026
2014	9	16	3	51	2	0.3	4.3	0.81	97	90.315	68.5882
2014	9	16	4	1	2	0.3	4.3	0.75	95	90.3806	63.8576
2014	9	16	4	11	2	0.3	4.3	0.78	96.8	90.315	66.3394
2014	9	16	4	21	2	0.3	4.3	0.78	97.3	90.315	66.0584
2014	9	16	4	31	2	0.3	4.3	0.79	93.6	90.315	67.1828
2014	9	16	4	41	2	0.3	4.3	0.78	95	90.315	66.9017
2014	9	16	4	51	2	0.3	4.3	0.75	97.2	90.3806	64.139
2014	9	16	5	1	2	0.3	4.3	0.76	96.4	90.3806	64.7016
2014	9	16	5	11	2	0.3	4.3	0.77	95.6	90.3806	66.1082
2014	9	16	5	21	2	0.3	4.3	0.76	97.2	90.3806	64.7016
2014	9	16	5	31	2	0.3	4.3	0.76	94.5	90.4462	64.7503
2014	9	16	5	41	2	0.3	4.3	0.76	95	90.4462	64.7503
2014	9	16	5	51	2	0.3	4.3	0.75	96	90.4462	63.9058
2014	9	16	6	1	2	0.3	4.3	0.78	98.3	90.4462	65.8764
2014	9	16	6	11	2	0.3	4.3	0.77	96.6	90.4462	65.8765
2014	9	16	6	21	2	0.3	4.3	0.78	94.8	90.4462	66.721
2014	9	16	6	31	2	0.3	4.3	0.76	98	90.4462	64.4689
2014	9	16	6	41	2	0.3	4.3	0.79	94.3	90.4462	67.5656
2014	9	16	6	51	2	0.3	4.3	0.77	96.6	90.4462	65.8765
2014	9	16	7	1	2	0.3	4.3	0.76	96.7	90.4462	64.4689
2014	9	16	7	11	2	0.3	4.3	0.78	96.3	90.4462	66.4396
2014	9	16	7	21	2	0.3	4.3	0.76	94.7	90.4462	65.0319
2014	9	16	7	31	2	0.3	4.3	0.79	95.7	90.4462	67.2841
2014	9	16	7	41	2	0.3	4.3	0.77	95.2	90.5118	65.6443
2014	9	16	7	51	2	0.3	4.3	0.81	94	90.4462	68.9733
2014	9	16	8	1	2	0.3	4.3	0.79	97.1	90.4462	67.5657

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	8	11	2	0.3	4.3	0.78	96.6	90.4462	66.158
2014	9	16	8	21	2	0.3	4.3	0.78	97.3	90.4462	66.158
2014	9	16	8	31	2	0.3	4.3	0.77	95.6	90.4462	65.595
2014	9	16	8	41	2	0.3	4.3	0.79	95.3	90.4462	67.2841
2014	9	16	8	51	2	0.3	4.3	0.76	95.4	90.4462	65.3135
2014	9	16	9	1	2	0.3	4.3	0.77	96.1	90.4462	65.595
2014	9	16	9	11	2	0.3	4.3	0.76	97.6	90.4462	65.0319
2014	9	16	9	21	2	0.3	4.3	0.76	96.7	90.4462	64.4689
2014	9	16	9	31	2	0.3	4.3	0.77	95.4	90.4462	65.8765
2014	9	16	9	41	2	0.3	4.3	0.79	97.6	90.4462	67.2841
2014	9	16	9	51	2	0.3	4.3	0.79	95.7	90.4462	67.5656
2014	9	16	10	1	2	0.3	4.3	0.77	96.1	90.4462	65.8764
2014	9	16	10	11	2	0.3	4.3	0.78	96.1	90.4462	66.1579
2014	9	16	10	21	2	0.3	4.3	0.75	98	90.4462	63.9057
2014	9	16	10	31	2	0.3	4.3	0.8	99	90.4462	67.5655
2014	9	16	10	41	2	0.3	4.3	0.78	97.8	90.4462	66.1579
2014	9	16	10	51	2	0.3	4.3	0.8	96.8	90.4462	68.1285
2014	9	16	11	1	2	0.3	4.3	0.78	98.5	90.4462	66.1579
2014	9	16	11	11	2	0.3	4.3	0.82	100	90.4462	68.9731
2014	9	16	11	21	2	0.3	4.3	0.81	97.5	90.4462	68.6915
2014	9	16	11	31	2	0.3	4.3	0.79	99.9	90.3806	66.3894
2014	9	16	11	41	2	0.3	4.3	0.76	100	90.3806	63.8576
2014	9	16	11	51	2	0.3	4.3	0.79	100.5	90.3806	66.6706
2014	9	16	12	1	2	0.3	4.3	0.79	98.3	90.3806	67.2333
2014	9	16	12	11	2	0.3	4.3	0.79	101.5	90.3806	66.3893
2014	9	16	12	21	2	0.3	4.3	0.79	100.6	90.315	66.3393
2014	9	16	12	31	2	0.3	4.3	0.8	99.5	90.315	67.4637
2014	9	16	12	41	2	0.3	4.3	0.79	97.8	90.315	67.4637
2014	9	16	12	51	2	0.3	4.3	0.79	101.5	90.2494	66.2893
2014	9	16	13	1	2	0.3	4.3	0.79	99.6	90.2494	66.5702
2014	9	16	13	11	2	0.3	4.3	0.79	100.3	90.2494	66.2893
2014	9	16	13	21	2	0.3	4.3	0.77	101.7	90.1837	64.836
2014	9	16	13	31	2	0.3	4.3	0.74	100.4	90.1837	62.5906
2014	9	16	13	41	2	0.3	4.3	0.76	97.7	90.2494	64.604
2014	9	16	13	51	2	0.3	4.3	0.79	98.9	90.1837	66.52
2014	9	16	14	1	2	0.3	4.3	0.79	98.8	90.2494	67.132
2014	9	16	14	11	2	0.3	4.3	0.81	101	90.1181	67.8721
2014	9	16	14	21	2	0.3	4.3	0.77	96.6	90.1181	65.6284
2014	9	16	14	31	2	0.3	4.3	0.78	100.6	90.1181	65.9089
2014	9	16	14	41	2	0.3	4.3	0.75	100.9	90.0525	62.4961
2014	9	16	14	51	2	0.3	4.3	0.77	97.3	90.0525	65.5789
2014	9	16	15	1	2	0.3	4.3	0.78	102.9	90.0525	64.7381
2014	9	16	15	11	2	0.3	4.3	0.79	101.5	90.0525	65.8591
2014	9	16	15	21	2	0.3	4.3	0.78	100.7	89.9869	65.2493
2014	9	16	15	31	2	0.3	4.3	0.81	103.4	90.0525	66.9802
2014	9	16	15	41	2	0.3	4.3	0.78	100.7	90.0525	65.2987

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	15	51	2	0.3	4.3	0.78	99.5	89.9869	65.5294
2014	9	16	16	1	2	0.3	4.3	0.79	99.6	89.9869	66.0894
2014	9	16	16	11	2	0.3	4.3	0.75	101.7	89.9869	62.4489
2014	9	16	16	21	2	0.3	4.3	0.77	102	89.9213	64.3605
2014	9	16	16	31	2	0.3	4.3	0.78	101	89.9213	64.9202
2014	9	16	16	41	2	0.3	4.3	0.76	99.2	89.9869	64.1292
2014	9	16	16	51	2	0.3	4.3	0.78	98.4	89.9213	66.0395
2014	9	16	17	1	2	0.3	4.3	0.78	98	89.9869	65.8094
2014	9	16	17	11	2	0.3	4.3	0.79	100.8	89.9213	66.0395
2014	9	16	17	21	2	0.3	4.3	0.77	99.6	89.9869	64.4092
2014	9	16	17	31	2	0.3	4.3	0.78	102.6	89.9213	64.9202
2014	9	16	17	41	2	0.3	4.3	0.78	99.4	89.9213	66.0395
2014	9	16	17	51	2	0.3	4.3	0.79	101.5	89.9213	66.0395
2014	9	16	18	1	2	0.3	4.3	0.78	99.4	89.9869	66.0895
2014	9	16	18	11	2	0.3	4.3	0.76	98	89.9213	64.0807
2014	9	16	18	21	2	0.3	4.3	0.78	97.7	89.9213	66.0395
2014	9	16	18	31	2	0.3	4.3	0.76	95.4	89.9213	64.6403
2014	9	16	18	41	2	0.3	4.3	0.8	96.9	89.9213	67.4386
2014	9	16	18	51	2	0.3	4.3	0.79	96.9	89.9213	66.5991
2014	9	16	19	1	2	0.3	4.3	0.78	96	89.9213	66.0395
2014	9	16	19	11	2	0.3	4.3	0.8	96.4	89.9213	67.4386
2014	9	16	19	21	2	0.3	4.3	0.78	95.8	89.9213	66.0394
2014	9	16	19	31	2	0.3	4.3	0.8	96.1	89.9213	67.9982
2014	9	16	19	41	2	0.3	4.3	0.77	97.1	89.9213	65.4798
2014	9	16	19	51	2	0.3	4.3	0.79	96.7	89.9213	66.5991
2014	9	16	20	1	2	0.3	4.3	0.78	96.3	89.9213	66.0394
2014	9	16	20	11	2	0.3	4.3	0.78	97	89.9869	66.0893
2014	9	16	20	21	2	0.3	4.3	0.79	96.7	89.9869	67.2095
2014	9	16	20	31	2	0.3	4.3	0.78	98.4	89.9869	66.0893
2014	9	16	20	41	2	0.3	4.3	0.77	96.1	89.9213	65.4797
2014	9	16	20	51	2	0.3	4.3	0.78	94.8	89.9213	66.3192
2014	9	16	21	1	2	0.3	4.3	0.77	97.8	89.9869	65.5292
2014	9	16	21	11	2	0.3	4.3	0.76	96.7	89.9869	64.6891
2014	9	16	21	21	2	0.3	4.3	0.77	97.1	89.9869	65.2492
2014	9	16	21	31	2	0.3	4.3	0.8	95.7	89.9869	67.7695
2014	9	16	21	41	2	0.3	4.3	0.77	95.2	89.9869	65.2491
2014	9	16	21	51	2	0.3	4.3	0.79	98.1	89.9869	66.9294
2014	9	16	22	1	2	0.3	4.3	0.76	96.7	89.9869	64.129
2014	9	16	22	11	2	0.3	4.3	0.78	95.3	89.9869	66.0892
2014	9	16	22	21	2	0.3	4.3	0.78	97.2	89.9869	66.0892
2014	9	16	22	31	2	0.3	4.3	0.76	96	89.9869	64.1289
2014	9	16	22	41	2	0.3	4.3	0.75	95	89.9869	63.5689
2014	9	16	22	51	2	0.3	4.3	0.77	97.1	89.9869	64.969
2014	9	16	23	1	2	0.3	4.3	0.77	95.6	89.9869	65.8092
2014	9	16	23	11	2	0.3	4.3	0.75	96	90.0525	63.8972
2014	9	16	23	21	2	0.3	4.3	0.79	97.9	89.9869	66.3692

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	23	31	2	0.3	4.3	0.8	94	90.0525	68.3812
2014	9	16	23	41	2	0.3	4.3	0.79	96	90.0525	66.9799
2014	9	16	23	51	2	0.3	4.3	0.79	95.7	90.0525	67.2602
2014	9	17	0	1	2	0.3	4.3	0.76	96.4	89.9869	64.4089
2014	9	17	0	11	2	0.3	4.3	0.75	97.6	89.9869	63.2888
2014	9	17	0	21	2	0.3	4.3	0.78	94.6	89.9869	66.6493
2014	9	17	0	31	2	0.3	4.3	0.77	94.6	90.0525	65.5787
2014	9	17	0	41	2	0.3	4.3	0.77	93.7	90.0525	65.8589
2014	9	17	0	51	2	0.3	4.3	0.78	94.6	90.0525	66.6997
2014	9	17	1	1	2	0.3	4.3	0.79	97.9	90.0525	66.4194
2014	9	17	1	11	2	0.3	4.3	0.78	97.2	90.0525	66.4194
2014	9	17	1	21	2	0.3	4.3	0.77	96.4	90.0525	65.0182
2014	9	17	1	31	2	0.3	4.3	0.75	94.2	90.0525	64.1774
2014	9	17	1	41	2	0.3	4.3	0.79	95	90.0525	67.2602
2014	9	17	1	51	2	0.3	4.3	0.75	96.1	90.0525	63.3367
2014	9	17	2	1	2	0.3	4.3	0.8	94.7	90.0525	67.8207
2014	9	17	2	11	2	0.3	4.3	0.76	95.2	90.0525	65.0182
2014	9	17	2	21	2	0.3	4.3	0.78	98.2	90.0525	66.1392
2014	9	17	2	31	2	0.3	4.3	0.79	97.9	90.0525	66.4194
2014	9	17	2	41	2	0.3	4.3	0.79	96.9	90.0525	66.9799
2014	9	17	2	51	2	0.3	4.3	0.75	96.3	90.1181	63.665
2014	9	17	3	1	2	0.3	4.3	0.74	96.3	90.1181	63.104
2014	9	17	3	11	2	0.3	4.3	0.81	95.4	90.1181	68.7133
2014	9	17	3	21	2	0.3	4.3	0.77	94.9	90.1181	65.6282
2014	9	17	3	31	2	0.3	4.3	0.8	96.8	90.1181	67.8719
2014	9	17	3	41	2	0.3	4.3	0.79	95.7	90.1181	67.0305
2014	9	17	3	51	2	0.3	4.3	0.76	97.2	90.1837	64.5551
2014	9	17	4	1	2	0.3	4.3	0.77	96.1	90.1837	65.3971
2014	9	17	4	11	2	0.3	4.3	0.76	95.7	90.1181	65.0673
2014	9	17	4	21	2	0.3	4.3	0.78	95.3	90.1181	66.1891
2014	9	17	4	31	2	0.3	4.3	0.79	96.7	90.1837	67.3618
2014	9	17	4	41	2	0.3	4.3	0.78	97.5	90.1181	66.4696
2014	9	17	4	51	2	0.3	4.3	0.78	96	90.2494	66.57
2014	9	17	5	1	2	0.3	4.3	0.79	96.7	90.2494	67.4126
2014	9	17	5	11	2	0.3	4.3	0.76	97.2	90.315	64.9336
2014	9	17	5	21	2	0.3	4.3	0.76	95.4	90.2494	65.1656
2014	9	17	5	31	2	0.3	4.3	0.74	95.6	90.315	63.5281
2014	9	17	5	41	2	0.3	4.3	0.76	98.4	90.2494	64.3229
2014	9	17	5	51	2	0.3	4.3	0.79	95.5	90.1181	67.311
2014	9	17	6	1	2	0.3	4.3	0.75	96.8	90.0525	63.617
2014	9	17	6	11	2	0.3	4.3	0.78	95.8	89.9869	66.3693
2014	9	17	6	21	2	0.3	4.3	0.77	96.2	90.0525	65.0182
2014	9	17	6	31	2	0.3	4.3	0.78	95.8	90.0525	66.4195
2014	9	17	6	41	2	0.3	4.3	0.76	95.2	90.0525	65.0182
2014	9	17	6	51	2	0.3	4.3	0.79	96.4	90.0525	66.98
2014	9	17	7	1	2	0.3	4.3	0.77	98.1	89.9869	65.2492

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	7	11	2	0.3	4.3	0.75	95.8	89.9869	63.849
2014	9	17	7	21	2	0.3	4.3	0.77	96.1	89.9869	65.5292
2014	9	17	7	31	2	0.3	4.3	0.78	95.5	89.9869	66.3693
2014	9	17	7	41	2	0.3	4.3	0.78	97	89.9869	66.0893
2014	9	17	7	51	2	0.3	4.3	0.77	97.1	89.9869	64.9691
2014	9	17	8	1	2	0.3	4.3	0.75	95.5	89.9869	63.5689
2014	9	17	8	11	2	0.3	4.3	0.75	96.5	89.9869	63.849
2014	9	17	8	21	2	0.3	4.3	0.76	98.7	89.9869	64.129
2014	9	17	8	31	2	0.3	4.3	0.8	95.7	89.9869	67.7695
2014	9	17	8	41	2	0.3	4.3	0.79	96.2	89.9869	66.6493
2014	9	17	8	51	2	0.3	4.3	0.78	97	89.9869	66.3693
2014	9	17	9	1	2	0.3	4.3	0.77	97.1	89.9869	65.2491
2014	9	17	9	11	2	0.3	4.3	0.75	95	89.9869	63.8489
2014	9	17	9	21	2	0.3	4.3	0.82	99	89.9869	68.8896
2014	9	17	9	31	2	0.3	4.3	0.79	100	89.9869	66.3692
2014	9	17	9	41	2	0.3	4.3	0.79	100	89.9869	66.3692
2014	9	17	9	51	2	0.3	4.3	0.8	100.9	89.9213	67.1585
2014	9	17	10	1	2	0.3	4.3	0.8	100.2	89.9213	67.1585
2014	9	17	10	11	2	0.3	4.3	0.78	98.5	89.9213	65.4795
2014	9	17	10	21	2	0.3	4.3	0.8	97.3	89.9213	67.7181
2014	9	17	10	31	2	0.3	4.3	0.79	101.5	89.9213	66.0392
2014	9	17	10	41	2	0.3	4.3	0.78	101.9	89.9213	64.9198
2014	9	17	10	51	2	0.3	4.3	0.81	99.6	89.9213	67.7181
2014	9	17	11	1	2	0.3	4.3	0.81	97.4	89.9213	68.8374
2014	9	17	11	11	2	0.3	4.3	0.8	99.5	89.9213	66.8786
2014	9	17	11	21	2	0.3	4.3	0.75	100.8	89.8556	62.9134
2014	9	17	11	31	2	0.3	4.3	0.78	99.5	89.8556	65.1503
2014	9	17	11	41	2	0.3	4.3	0.78	99.4	89.8556	65.7095
2014	9	17	11	51	2	0.3	4.3	0.78	98.2	89.8556	65.7095
2014	9	17	12	1	2	0.3	4.3	0.78	98.4	89.8556	65.9891
2014	9	17	12	11	2	0.3	4.3	0.78	99.4	89.8556	65.9891
2014	9	17	12	21	2	0.3	4.3	0.79	98.3	89.8556	66.8279
2014	9	17	12	31	2	0.3	4.3	0.77	99.3	89.8556	65.1502
2014	9	17	12	41	2	0.3	4.3	0.79	101.7	89.8556	65.989
2014	9	17	12	51	2	0.3	4.3	0.8	98	89.8556	67.6667
2014	9	17	13	1	2	0.3	4.3	0.78	99.7	89.8556	65.7094
2014	9	17	13	11	2	0.3	4.3	0.78	103	89.8556	65.1501
2014	9	17	13	21	2	0.3	4.3	0.77	101.6	89.79	63.9832
2014	9	17	13	31	2	0.3	4.3	0.78	100.6	89.79	65.3802
2014	9	17	13	41	2	0.3	4.3	0.77	99.8	89.79	64.542
2014	9	17	13	51	2	0.3	4.3	0.79	96	89.79	66.7772
2014	9	17	14	1	2	0.3	4.3	0.79	101.7	89.7244	65.889
2014	9	17	14	11	2	0.3	4.3	0.78	102.2	89.79	64.8214
2014	9	17	14	21	2	0.3	4.3	0.77	98.8	89.79	65.1008
2014	9	17	14	31	2	0.3	4.3	0.79	98.2	89.7244	66.1682
2014	9	17	14	41	2	0.3	4.3	0.76	97.4	89.6588	64.4442

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	14	51	2	0.3	4.3	0.77	103	89.7244	64.214
2014	9	17	15	1	2	0.3	4.3	0.77	101.8	89.7244	64.214
2014	9	17	15	11	2	0.3	4.3	0.75	98.6	89.7244	62.818
2014	9	17	15	21	2	0.3	4.3	0.77	98.1	89.6588	64.7232
2014	9	17	15	31	2	0.3	4.3	0.78	98.3	89.6588	65.2812
2014	9	17	15	41	2	0.3	4.3	0.75	100.1	89.6588	62.7704
2014	9	17	15	51	2	0.3	4.3	0.76	100.4	89.6588	63.8863
2014	9	17	16	1	2	0.3	4.3	0.77	97.9	89.7244	64.4932
2014	9	17	16	11	2	0.3	4.3	0.76	103.7	89.6588	63.0494
2014	9	17	16	21	2	0.3	4.3	0.77	99.6	89.6588	64.4443
2014	9	17	16	31	2	0.3	3.9	0.78	99.7	89.5932	64.9529
2014	9	17	16	41	2	0.3	3.9	0.75	97.5	89.5932	63.5591
2014	9	17	16	51	2	0.3	4.3	0.77	99.1	89.6588	64.4443
2014	9	17	17	1	2	0.3	4.3	0.77	99.1	89.6588	64.4443
2014	9	17	17	11	2	0.3	3.9	0.78	98.7	89.5932	65.5104
2014	9	17	17	21	2	0.3	3.9	0.79	97.6	89.5932	66.6255
2014	9	17	17	31	2	0.3	4.3	0.77	96.1	89.6588	65.2812
2014	9	17	17	41	2	0.3	3.9	0.79	98.6	89.5932	66.068
2014	9	17	17	51	2	0.3	3.9	0.8	95.6	89.5932	67.7406
2014	9	17	18	1	2	0.3	3.9	0.78	94.8	89.5932	65.7892
2014	9	17	18	11	2	0.3	3.9	0.78	97.5	89.5932	66.068
2014	9	17	18	21	2	0.3	3.9	0.78	98.5	89.5932	65.2316
2014	9	17	18	31	2	0.3	3.9	0.75	95	89.5932	63.2803
2014	9	17	18	41	2	0.3	3.9	0.75	95	89.5932	63.559
2014	9	17	18	51	2	0.3	3.9	0.78	97.2	89.5932	65.7892
2014	9	17	19	1	2	0.3	3.9	0.78	97	89.5932	65.7892
2014	9	17	19	11	2	0.3	4.3	0.78	96.3	89.6588	65.5601
2014	9	17	19	21	2	0.3	4.3	0.76	98.2	89.6588	64.1652
2014	9	17	19	31	2	0.3	3.9	0.77	96.2	89.5932	64.6741
2014	9	17	19	41	2	0.3	3.9	0.76	96.7	89.5932	64.3953
2014	9	17	19	51	2	0.3	4.3	0.77	99.3	89.6588	64.7232
2014	9	17	20	1	2	0.3	4.3	0.8	96.6	89.6588	67.5129
2014	9	17	20	11	2	0.3	4.3	0.76	96.7	89.6588	64.4442
2014	9	17	20	21	2	0.3	4.3	0.77	96.9	89.6588	65.0021
2014	9	17	20	31	2	0.3	4.3	0.77	97.6	89.7244	65.0514
2014	9	17	20	41	2	0.3	4.3	0.77	94.9	89.7244	65.3306
2014	9	17	20	51	2	0.3	4.3	0.77	95.9	89.7244	65.0514
2014	9	17	21	1	2	0.3	4.3	0.79	95	89.7244	67.0057
2014	9	17	21	11	2	0.3	4.3	0.76	94.5	89.7244	64.2138
2014	9	17	21	21	2	0.3	4.3	0.79	95.7	89.7244	67.0057
2014	9	17	21	31	2	0.3	4.3	0.78	98	89.7244	65.3306
2014	9	17	21	41	2	0.3	4.3	0.78	94.1	89.7244	66.4473
2014	9	17	21	51	2	0.3	4.3	0.77	97.6	89.7244	64.7722
2014	9	17	22	1	2	0.3	4.3	0.77	95.6	89.7244	65.3305
2014	9	17	22	11	2	0.3	4.3	0.77	96.9	89.7244	64.7722
2014	9	17	22	21	2	0.3	4.3	0.74	94.8	89.7244	63.097

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	22	31	2	0.3	4.3	0.76	94.9	89.7244	64.7721
2014	9	17	22	41	2	0.3	4.3	0.79	96.4	89.7244	66.7265
2014	9	17	22	51	2	0.3	4.3	0.76	95.2	89.7244	64.7721
2014	9	17	23	1	2	0.3	4.3	0.74	96.8	89.7244	62.8178
2014	9	17	23	11	2	0.3	4.3	0.78	94.8	89.7244	66.4473
2014	9	17	23	21	2	0.3	4.3	0.78	96.8	89.7244	65.6097
2014	9	17	23	31	2	0.3	4.3	0.77	97.1	89.7244	65.0513
2014	9	17	23	41	2	0.3	4.3	0.76	97.2	89.7244	64.4929
2014	9	17	23	51	2	0.3	4.3	0.75	96.1	89.7244	63.097
2014	9	18	0	1	2	0.3	4.3	0.79	97.4	89.7244	66.4473
2014	9	18	0	11	2	0.3	4.3	0.79	96.9	89.79	66.7771
2014	9	18	0	21	2	0.3	4.3	0.76	95	89.79	64.2625
2014	9	18	0	31	2	0.3	4.3	0.78	96	89.79	65.9389
2014	9	18	0	41	2	0.3	4.3	0.77	96.1	89.79	65.1007
2014	9	18	0	51	2	0.3	4.3	0.81	96.5	89.7244	68.1224
2014	9	18	1	1	2	0.3	4.3	0.8	95.2	89.79	67.8947
2014	9	18	1	11	2	0.3	4.3	0.76	96.2	89.7244	63.9346
2014	9	18	1	21	2	0.3	4.3	0.79	95.7	89.79	67.0565
2014	9	18	1	31	2	0.3	4.3	0.79	93.6	89.79	67.0565
2014	9	18	1	41	2	0.3	4.3	0.76	97.5	89.79	63.9831
2014	9	18	1	51	2	0.3	4.3	0.8	96.9	89.79	67.3359
2014	9	18	2	1	2	0.3	4.3	0.79	98.1	89.79	66.7771
2014	9	18	2	11	2	0.3	4.3	0.77	96.3	89.79	65.3801
2014	9	18	2	21	2	0.3	4.3	0.78	95.3	89.79	65.9389
2014	9	18	2	31	2	0.3	4.3	0.76	96.7	89.79	64.5419
2014	9	18	2	41	2	0.3	4.3	0.78	98.4	89.79	65.9389
2014	9	18	2	51	2	0.3	4.3	0.76	96.7	89.79	64.5419
2014	9	18	3	1	2	0.3	4.3	0.74	95.1	89.79	63.1449
2014	9	18	3	11	2	0.3	4.3	0.76	95.4	89.79	64.5419
2014	9	18	3	21	2	0.3	4.3	0.8	95.2	89.79	67.8947
2014	9	18	3	31	2	0.3	4.3	0.77	94.2	89.79	65.3801
2014	9	18	3	41	2	0.3	4.3	0.79	96	89.79	66.7771
2014	9	18	3	51	2	0.3	4.3	0.79	95.9	89.79	67.336
2014	9	18	4	1	2	0.3	4.3	0.77	95.6	89.79	65.3801
2014	9	18	4	11	2	0.3	4.3	0.77	96.9	89.79	64.8214
2014	9	18	4	21	2	0.3	4.3	0.74	96.3	89.79	62.8655
2014	9	18	4	31	2	0.3	4.3	0.77	96.9	89.79	64.8214
2014	9	18	4	41	2	0.3	4.3	0.74	96.1	89.79	62.5862
2014	9	18	4	51	2	0.3	4.3	0.76	95.7	89.8556	64.8705
2014	9	18	5	1	2	0.3	4.3	0.78	96.8	89.8556	65.7093
2014	9	18	5	11	2	0.3	4.3	0.77	94.9	89.8556	65.1501
2014	9	18	5	21	2	0.3	4.3	0.76	96.7	89.8556	64.5909
2014	9	18	5	31	2	0.3	4.3	0.75	96	89.8556	63.7521
2014	9	18	5	41	2	0.3	4.3	0.77	98.3	89.8556	65.1501
2014	9	18	5	51	2	0.3	4.3	0.75	97.7	89.8556	63.7521
2014	9	18	6	1	2	0.3	4.3	0.77	96.4	89.8556	65.1502

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	6	11	2	0.3	4.3	0.74	96.1	89.9213	62.6811
2014	9	18	6	21	2	0.3	4.3	0.76	98.2	89.9213	63.8004
2014	9	18	6	31	2	0.3	4.3	0.75	94.2	89.9213	64.0802
2014	9	18	6	41	2	0.3	4.3	0.79	96.9	89.9213	66.5987
2014	9	18	6	51	2	0.3	4.3	0.77	95.6	89.9213	65.1995
2014	9	18	7	1	2	0.3	4.3	0.77	96.4	89.9213	65.1995
2014	9	18	7	11	2	0.3	4.3	0.75	95.3	89.9213	63.5206
2014	9	18	7	21	2	0.3	4.3	0.75	95.5	89.9213	64.0803
2014	9	18	7	31	2	0.3	4.3	0.78	97	89.9213	66.3189
2014	9	18	7	41	2	0.3	4.3	0.77	96.2	89.8556	64.8706
2014	9	18	7	51	2	0.3	4.3	0.76	95.7	89.9213	64.9198
2014	9	18	8	1	2	0.3	4.3	0.79	96	89.9213	66.5987
2014	9	18	8	11	2	0.3	4.3	0.78	94.6	89.9213	66.5987
2014	9	18	8	21	2	0.3	4.3	0.78	98.9	89.9213	66.039
2014	9	18	8	31	2	0.3	4.3	0.73	95.1	89.9213	62.4013
2014	9	18	8	41	2	0.3	4.3	0.81	97.9	89.9213	68.5575
2014	9	18	8	51	2	0.3	4.3	0.8	95.6	89.8556	67.9464
2014	9	18	9	1	2	0.3	4.3	0.78	100.2	89.8556	65.4298
2014	9	18	9	11	2	0.3	4.3	0.78	96.8	89.8556	65.7094
2014	9	18	9	21	2	0.3	4.3	0.78	100.2	89.8556	65.1502
2014	9	18	9	31	2	0.3	4.3	0.79	101.3	89.8556	65.989
2014	9	18	9	41	2	0.3	4.3	0.76	99	89.8556	63.7521
2014	9	18	9	51	2	0.3	4.3	0.79	100.6	89.8556	65.989
2014	9	18	10	1	2	0.3	4.3	0.79	98.2	89.8556	66.2686
2014	9	18	10	11	2	0.3	4.3	0.8	97.6	89.8556	67.387
2014	9	18	10	21	2	0.3	4.3	0.78	98.4	89.79	65.939
2014	9	18	10	31	2	0.3	4.3	0.81	100.7	89.8556	67.9462
2014	9	18	10	41	2	0.3	4.3	0.78	100.9	89.79	65.1008
2014	9	18	10	51	2	0.3	4.3	0.79	99.8	89.79	66.4978
2014	9	18	11	1	2	0.3	4.3	0.78	101.4	89.79	65.1007
2014	9	18	11	11	2	0.3	4.3	0.8	100.4	89.79	66.7772
2014	9	18	11	21	2	0.3	4.3	0.77	98.8	89.79	64.8213
2014	9	18	11	31	2	0.3	4.3	0.78	99.7	89.7244	65.6097
2014	9	18	11	41	2	0.3	4.3	0.77	100	89.79	64.8213
2014	9	18	11	51	2	0.3	4.3	0.79	97.7	89.7244	66.4473
2014	9	18	12	1	2	0.3	4.3	0.78	101.2	89.7244	64.7721
2014	9	18	12	11	2	0.3	4.3	0.8	101.9	89.6588	66.3969
2014	9	18	12	21	2	0.3	4.3	0.8	100.7	89.6588	66.6759
2014	9	18	12	31	2	0.3	4.3	0.78	104	89.6588	64.723
2014	9	18	12	41	2	0.3	4.3	0.76	102.2	89.6588	63.0491
2014	9	18	12	51	2	0.3	4.3	0.78	99.7	89.6588	65.281
2014	9	18	13	1	2	0.3	3.9	0.76	103.4	89.5932	63.0013
2014	9	18	13	11	2	0.3	3.9	0.76	98.5	89.5932	63.5588
2014	9	18	13	21	2	0.3	3.9	0.74	100.5	89.5276	61.8392
2014	9	18	13	31	2	0.3	3.9	0.75	100	89.5276	62.9534
2014	9	18	13	41	2	0.3	3.9	0.78	103	89.5276	64.9033

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	13	51	2	0.3	3.9	0.76	99.4	89.5276	64.0676
2014	9	18	14	1	2	0.3	3.9	0.75	102.6	89.462	62.0705
2014	9	18	14	11	2	0.3	3.9	0.8	99.7	89.462	66.524
2014	9	18	14	21	2	0.3	3.9	0.74	98.6	89.462	62.3489
2014	9	18	14	31	2	0.3	3.9	0.74	95.8	89.3963	62.5796
2014	9	18	14	41	2	0.3	3.9	0.75	98.6	89.3963	62.8577
2014	9	18	14	51	2	0.3	3.9	0.76	103.7	89.3963	62.5796
2014	9	18	15	1	2	0.3	3.9	0.74	103.1	89.3963	60.9108
2014	9	18	15	11	2	0.3	3.9	0.77	99.8	89.3307	64.1995
2014	9	18	15	21	2	0.3	3.9	0.76	99.2	89.3307	63.6437
2014	9	18	15	31	2	0.3	3.9	0.78	100.9	89.3307	64.7554
2014	9	18	15	41	2	0.3	3.9	0.8	98	89.3307	66.9787
2014	9	18	15	51	2	0.3	3.9	0.77	98.3	89.3307	64.4774
2014	9	18	16	1	2	0.3	3.9	0.8	100.9	89.3307	66.145
2014	9	18	16	11	2	0.3	3.9	0.78	100.7	89.3307	64.7554
2014	9	18	16	21	2	0.3	3.9	0.77	99.8	89.3307	64.1995
2014	9	18	16	31	2	0.3	3.9	0.78	97.5	89.3307	65.3112
2014	9	18	16	41	2	0.3	3.9	0.78	101.2	89.3307	64.4775
2014	9	18	16	51	2	0.3	3.9	0.76	100.7	89.3307	63.3658
2014	9	18	17	1	2	0.3	3.9	0.79	100	89.3307	66.145
2014	9	18	17	11	2	0.3	3.9	0.81	98.2	89.3307	67.8125
2014	9	18	17	21	2	0.3	3.9	0.77	98.5	89.3307	64.7554
2014	9	18	17	31	2	0.3	3.9	0.76	98.9	89.2651	63.873
2014	9	18	17	41	2	0.3	3.9	0.78	98.7	89.3307	65.3113
2014	9	18	17	51	2	0.3	3.9	0.77	95.4	89.3307	64.7554
2014	9	18	18	1	2	0.3	3.9	0.73	95.2	89.2651	61.3736
2014	9	18	18	11	2	0.3	3.9	0.75	96	89.3307	63.3658
2014	9	18	18	21	2	0.3	3.9	0.77	96.3	89.3307	65.0333
2014	9	18	18	31	2	0.3	3.9	0.77	96.8	89.3307	65.0333
2014	9	18	18	41	2	0.3	3.9	0.79	96.9	89.3307	66.145
2014	9	18	18	51	2	0.3	3.9	0.76	95.2	89.3307	64.4775
2014	9	18	19	1	2	0.3	3.9	0.75	95	89.3307	63.6437
2014	9	18	19	11	2	0.3	3.9	0.79	97.8	89.2651	66.65
2014	9	18	19	21	2	0.3	3.9	0.77	97.5	89.3307	65.0333
2014	9	18	19	31	2	0.3	3.9	0.77	94.9	89.2651	64.9838
2014	9	18	19	41	2	0.3	3.9	0.75	97.6	89.1995	62.7143
2014	9	18	19	51	2	0.3	3.9	0.78	97.5	89.2651	65.8169
2014	9	18	20	1	2	0.3	3.9	0.77	97.4	89.2651	64.4284
2014	9	18	20	11	2	0.3	3.9	0.77	95.4	89.2651	64.9838
2014	9	18	20	21	2	0.3	3.9	0.76	96	89.2651	63.5952
2014	9	18	20	31	2	0.3	3.9	0.74	95.1	89.2651	62.2067
2014	9	18	20	41	2	0.3	3.9	0.77	96.1	89.2651	64.706
2014	9	18	20	51	2	0.3	3.9	0.79	95.7	89.2651	66.3723
2014	9	18	21	1	2	0.3	3.9	0.77	97.3	89.2651	64.9837
2014	9	18	21	11	2	0.3	3.9	0.74	95.3	89.2651	62.4844
2014	9	18	21	21	2	0.3	3.9	0.75	95	89.2651	63.3175

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	21	31	2	0.3	3.9	0.76	96.2	89.2651	64.1506
2014	9	18	21	41	2	0.3	3.9	0.76	96.2	89.3307	64.1995
2014	9	18	21	51	2	0.3	3.9	0.76	94.7	89.3307	64.1995
2014	9	18	22	1	2	0.3	3.9	0.78	96.7	89.3307	65.867
2014	9	18	22	11	2	0.3	3.9	0.76	96.9	89.2651	63.8729
2014	9	18	22	21	2	0.3	3.9	0.75	97.5	89.2651	63.3175
2014	9	18	22	31	2	0.3	3.9	0.76	96.7	89.3307	63.6437
2014	9	18	22	41	2	0.3	3.9	0.77	97.1	89.2651	64.706
2014	9	18	22	51	2	0.3	3.9	0.77	97.1	89.2651	64.9837
2014	9	18	23	1	2	0.3	3.9	0.77	95.9	89.3307	65.0333
2014	9	18	23	11	2	0.3	3.9	0.78	99	89.3307	65.0333
2014	9	18	23	21	2	0.3	3.9	0.75	94.7	89.3307	63.6437
2014	9	18	23	31	2	0.3	3.9	0.77	99.8	89.3307	64.4774
2014	9	18	23	41	2	0.3	3.9	0.75	97.2	89.3307	63.3658
2014	9	18	23	51	2	0.3	3.9	0.79	98.6	89.3307	65.867
2014	9	19	0	1	2	0.3	3.9	0.76	96.5	89.3307	63.6437
2014	9	19	0	11	2	0.3	3.9	0.75	95	89.3307	63.0878
2014	9	19	0	21	2	0.3	3.9	0.75	95	89.3307	63.6437
2014	9	19	0	31	2	0.3	3.9	0.77	96.6	89.3307	64.7554
2014	9	19	0	41	2	0.3	3.9	0.74	95.9	89.3307	62.2541
2014	9	19	0	51	2	0.3	3.9	0.77	97.1	89.3307	65.0333
2014	9	19	1	1	2	0.3	3.9	0.75	92.8	89.3307	63.0879
2014	9	19	1	11	2	0.3	3.9	0.78	93.6	89.3307	65.5892
2014	9	19	1	21	2	0.3	3.9	0.76	95.2	89.3307	63.9217
2014	9	19	1	31	2	0.3	3.9	0.75	95.5	89.3307	63.3659
2014	9	19	1	41	2	0.3	3.9	0.76	96.5	89.3307	63.6438
2014	9	19	1	51	2	0.3	3.9	0.76	96.9	89.3963	63.9704
2014	9	19	2	1	2	0.3	3.9	0.75	96.3	89.3963	63.4142
2014	9	19	2	11	2	0.3	3.9	0.75	95	89.3963	63.6923
2014	9	19	2	21	2	0.3	3.9	0.74	95.1	89.462	62.3491
2014	9	19	2	31	2	0.3	3.9	0.77	97.6	89.462	64.8542
2014	9	19	2	41	2	0.3	3.9	0.75	92	89.462	63.7408
2014	9	19	2	51	2	0.3	3.9	0.78	95.3	89.462	65.6893
2014	9	19	3	1	2	0.3	3.9	0.75	97.8	89.5276	63.2322
2014	9	19	3	11	2	0.3	3.9	0.77	95.6	89.5276	64.9036
2014	9	19	3	21	2	0.3	3.9	0.76	95.4	89.5276	64.3465
2014	9	19	3	31	2	0.3	3.9	0.77	96.2	89.5276	64.6251
2014	9	19	3	41	2	0.3	3.9	0.75	96.3	89.5276	63.5109
2014	9	19	3	51	2	0.3	3.9	0.77	96.1	89.5276	64.9036
2014	9	19	4	1	2	0.3	3.9	0.79	96.2	89.5276	66.2964
2014	9	19	4	11	2	0.3	3.9	0.77	94.9	89.5276	65.1822
2014	9	19	4	21	2	0.3	3.9	0.75	96.3	89.5276	63.5109
2014	9	19	4	31	2	0.3	3.9	0.76	94.7	89.5276	64.3466
2014	9	19	4	41	2	0.3	3.9	0.78	97.7	89.5276	66.018
2014	9	19	4	51	2	0.3	3.9	0.74	96.7	89.5276	62.1182
2014	9	19	5	1	2	0.3	3.9	0.76	94.7	89.5276	64.6252

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	5	11	2	0.3	3.9	0.75	95.5	89.5276	63.2324
2014	9	19	5	21	2	0.3	3.9	0.77	95.1	89.5276	65.4609
2014	9	19	5	31	2	0.3	3.9	0.77	97.1	89.5276	64.6252
2014	9	19	5	41	2	0.3	3.9	0.75	95.8	89.5276	63.2325
2014	9	19	5	51	2	0.3	3.9	0.73	97.4	89.5932	61.8867
2014	9	19	6	1	2	0.3	3.9	0.75	95.3	89.5932	63.2805
2014	9	19	6	11	2	0.3	3.9	0.76	95.2	89.5932	64.6744
2014	9	19	6	21	2	0.3	3.9	0.75	97.5	89.5932	63.2806
2014	9	19	6	31	2	0.3	3.9	0.76	96	89.5932	63.8381
2014	9	19	6	41	2	0.3	3.9	0.81	95.8	89.5932	68.856
2014	9	19	6	51	2	0.3	3.9	0.77	95.6	89.5932	65.5107
2014	9	19	7	1	2	0.3	3.9	0.77	95.9	89.5932	64.6745
2014	9	19	7	11	2	0.3	3.9	0.77	95.1	89.5932	65.5108
2014	9	19	7	21	2	0.3	3.9	0.78	96.5	89.5932	65.7896
2014	9	19	7	31	2	0.3	3.9	0.76	97.2	89.5932	64.3957
2014	9	19	7	41	2	0.3	3.9	0.76	96.7	89.5932	64.3957
2014	9	19	7	51	2	0.3	3.9	0.74	95.1	89.5932	62.4443
2014	9	19	8	1	2	0.3	3.9	0.75	97.2	89.5932	63.5594
2014	9	19	8	11	2	0.3	3.9	0.78	96	89.5932	66.0683
2014	9	19	8	21	2	0.3	3.9	0.77	94.9	89.5932	65.232
2014	9	19	8	31	2	0.3	3.9	0.77	94.7	89.5276	64.9039
2014	9	19	8	41	2	0.3	3.9	0.76	96.9	89.5276	64.0683
2014	9	19	8	51	2	0.3	3.9	0.78	94.1	89.5276	65.7396
2014	9	19	9	1	2	0.3	3.9	0.79	95.7	89.5276	66.8538
2014	9	19	9	11	2	0.3	3.9	0.76	96.2	89.5276	63.7897
2014	9	19	9	21	2	0.3	3.9	0.73	93.3	89.5276	62.1184
2014	9	19	9	31	2	0.3	3.9	0.75	95	89.462	63.4629
2014	9	19	9	41	2	0.3	3.9	0.76	96.4	89.462	64.0196
2014	9	19	9	51	2	0.3	3.9	0.75	94.8	89.462	63.1845
2014	9	19	10	1	2	0.3	3.9	0.78	96.8	89.3963	65.6396
2014	9	19	10	11	2	0.3	3.9	0.76	96.2	89.462	63.7412
2014	9	19	10	21	2	0.3	3.9	0.77	96.1	89.3963	65.0834
2014	9	19	10	31	2	0.3	3.9	0.77	94.6	89.3307	65.3117
2014	9	19	10	41	2	0.3	3.9	0.78	95	89.3307	66.1455
2014	9	19	10	51	2	0.3	3.9	0.77	94.9	89.3307	65.0338
2014	9	19	11	1	2	0.3	3.9	0.78	94.6	89.3307	65.5896
2014	9	19	11	11	2	0.3	3.9	0.79	95.3	89.2651	66.3728
2014	9	19	11	21	2	0.3	3.9	0.76	96.2	89.2651	64.1511
2014	9	19	11	31	2	0.3	3.9	0.76	94.7	89.1995	64.1021
2014	9	19	11	41	2	0.3	3.9	0.77	96.9	89.1995	64.3796
2014	9	19	11	51	2	0.3	3.9	0.75	95.5	89.1995	62.9921
2014	9	19	12	1	2	0.3	3.9	0.76	96	89.1995	63.5471
2014	9	19	12	11	2	0.3	3.9	0.79	96.9	89.1995	66.3221
2014	9	19	12	21	2	0.3	3.9	0.76	95.2	89.1995	63.8246
2014	9	19	12	31	2	0.3	3.9	0.76	97.2	89.1339	63.4986
2014	9	19	12	41	2	0.3	3.9	0.78	96.3	89.1339	65.7169

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	12	51	2	0.3	3.9	0.76	96.2	89.1339	63.7759
2014	9	19	13	1	2	0.3	3.9	0.77	97.1	89.1339	64.3305
2014	9	19	13	11	2	0.3	3.9	0.8	98.5	89.1339	67.1033
2014	9	19	13	21	2	0.3	3.9	0.77	97.1	89.1339	64.6077
2014	9	19	13	31	2	0.3	3.9	0.76	94.7	89.1339	64.0532
2014	9	19	13	41	2	0.3	3.9	0.77	97.6	89.0683	64.5584
2014	9	19	13	51	2	0.3	3.9	0.8	97.1	89.0683	66.775
2014	9	19	14	1	2	0.3	3.9	0.74	96.3	89.0683	62.3418
2014	9	19	14	11	2	0.3	3.9	0.76	95.7	89.0683	64.2813
2014	9	19	14	21	2	0.3	3.9	0.75	97.2	89.0683	63.173
2014	9	19	14	31	2	0.3	3.9	0.74	96.7	89.0683	61.7877
2014	9	19	14	41	2	0.3	3.9	0.76	96.2	89.0683	63.7272
2014	9	19	14	51	2	0.3	3.9	0.77	97.1	89.0683	64.2814
2014	9	19	15	1	2	0.3	3.9	0.77	100.7	89.0683	64.2814
2014	9	19	15	11	2	0.3	3.9	0.77	98.1	89.0026	64.2323
2014	9	19	15	21	2	0.3	3.9	0.8	99.5	89.0026	66.1703
2014	9	19	15	31	2	0.3	3.9	0.76	97.2	89.0683	63.7272
2014	9	19	15	41	2	0.3	3.9	0.8	96.8	89.0683	67.0521
2014	9	19	15	51	2	0.3	3.9	0.76	97.2	89.0026	63.9554
2014	9	19	16	1	2	0.3	3.9	0.77	97.9	89.0026	63.9554
2014	9	19	16	11	2	0.3	3.9	0.77	97.4	89.0026	64.2323
2014	9	19	16	21	2	0.3	3.9	0.75	98.5	89.0026	62.848
2014	9	19	16	31	2	0.3	3.9	0.78	98.2	89.0026	65.0629
2014	9	19	16	41	2	0.3	3.9	0.75	97	89.0026	62.848
2014	9	19	16	51	2	0.3	3.9	0.77	98.4	89.0026	63.9555
2014	9	19	17	1	2	0.3	3.9	0.8	99.2	89.0026	67.001
2014	9	19	17	11	2	0.3	3.9	0.76	95.9	89.0026	63.9555
2014	9	19	17	21	2	0.3	3.9	0.75	99.8	89.0026	62.5712
2014	9	19	17	31	2	0.3	3.9	0.78	95	89.0026	65.8936
2014	9	19	17	41	2	0.3	3.9	0.78	97.2	89.0026	65.3398
2014	9	19	17	51	2	0.3	3.9	0.76	96.4	89.0026	63.6786
2014	9	19	18	1	2	0.3	3.9	0.76	93.5	89.0026	64.2324
2014	9	19	18	11	2	0.3	3.9	0.76	95.7	89.0026	63.6787
2014	9	19	18	21	2	0.3	3.9	0.8	96.1	89.0026	67.001
2014	9	19	18	31	2	0.3	3.9	0.75	95.8	89.0026	63.1249
2014	9	19	18	41	2	0.3	3.9	0.78	94.8	89.0026	65.3398
2014	9	19	18	51	2	0.3	3.9	0.77	98.4	89.0026	63.9555
2014	9	19	19	1	2	0.3	3.9	0.75	97.3	89.0026	62.8481
2014	9	19	19	11	2	0.3	3.9	0.77	96.9	89.0026	64.2324
2014	9	19	19	21	2	0.3	3.9	0.76	95.4	89.0683	64.0044
2014	9	19	19	31	2	0.3	3.9	0.8	95.4	89.0026	67.001
2014	9	19	19	41	2	0.3	3.9	0.78	98.7	89.0026	65.063
2014	9	19	19	51	2	0.3	3.9	0.77	96.6	89.0026	64.2324
2014	9	19	20	1	2	0.3	3.9	0.77	97.6	89.0026	64.5092
2014	9	19	20	11	2	0.3	3.9	0.74	96.9	89.0683	62.0649
2014	9	19	20	21	2	0.3	3.9	0.79	96.7	89.0683	65.9439

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	20	31	2	0.3	3.9	0.75	97.5	89.0683	62.8961
2014	9	19	20	41	2	0.3	3.9	0.78	95	89.0683	65.9439
2014	9	19	20	51	2	0.3	3.9	0.77	96.1	89.0683	64.5586
2014	9	19	21	1	2	0.3	3.9	0.78	94.3	89.0683	65.6669
2014	9	19	21	11	2	0.3	3.9	0.76	95.4	89.0683	64.2815
2014	9	19	21	21	2	0.3	3.9	0.76	94.9	89.0683	64.0044
2014	9	19	21	31	2	0.3	3.9	0.78	95.3	89.0683	65.3898
2014	9	19	21	41	2	0.3	3.9	0.76	96.4	89.0683	63.7273
2014	9	19	21	51	2	0.3	3.9	0.79	95.7	89.0683	66.221
2014	9	19	22	1	2	0.3	3.9	0.74	96.6	89.0683	62.342
2014	9	19	22	11	2	0.3	3.9	0.77	94.9	89.0683	64.8356
2014	9	19	22	21	2	0.3	3.9	0.73	97.7	89.0683	61.5107
2014	9	19	22	31	2	0.3	3.9	0.76	94	89.0683	63.7273
2014	9	19	22	41	2	0.3	3.9	0.78	96	89.0683	65.3898
2014	9	19	22	51	2	0.3	3.9	0.75	94.5	89.0683	62.8961
2014	9	19	23	1	2	0.3	3.9	0.78	97	89.0683	65.6669
2014	9	19	23	11	2	0.3	3.9	0.76	97.2	89.1339	63.4988
2014	9	19	23	21	2	0.3	3.9	0.77	96.6	89.0683	64.2815
2014	9	19	23	31	2	0.3	3.9	0.76	95.4	89.1339	64.3306
2014	9	19	23	41	2	0.3	3.9	0.75	95	89.1339	62.9442
2014	9	19	23	51	2	0.3	3.9	0.78	94.8	89.1339	65.7171
2014	9	20	0	1	2	0.3	3.9	0.74	95.1	89.1339	62.1124
2014	9	20	0	11	2	0.3	3.9	0.78	97.2	89.1339	65.4398
2014	9	20	0	21	2	0.3	3.9	0.79	96.4	89.1339	66.2717
2014	9	20	0	31	2	0.3	3.9	0.73	95.1	89.1339	61.8351
2014	9	20	0	41	2	0.3	3.9	0.75	96.8	89.1339	62.9442
2014	9	20	0	51	2	0.3	3.9	0.79	96.7	89.1339	65.9944
2014	9	20	1	1	2	0.3	3.9	0.76	96.9	89.1339	63.7761
2014	9	20	1	11	2	0.3	3.9	0.78	95.5	89.1339	65.7172
2014	9	20	1	21	2	0.3	3.9	0.75	96.3	89.1339	62.9443
2014	9	20	1	31	2	0.3	3.9	0.75	95.8	89.1339	62.9443
2014	9	20	1	41	2	0.3	3.9	0.78	96.1	89.1339	65.1626
2014	9	20	1	51	2	0.3	3.9	0.76	94.7	89.1339	64.0535
2014	9	20	2	1	2	0.3	3.9	0.78	95.8	89.1339	65.4399
2014	9	20	2	11	2	0.3	3.9	0.76	94.4	89.1339	64.3308
2014	9	20	2	21	2	0.3	3.9	0.76	94.9	89.1339	64.3308
2014	9	20	2	31	2	0.3	3.9	0.75	97.8	89.1339	62.6671
2014	9	20	2	41	2	0.3	3.9	0.77	97.1	89.1339	64.8854
2014	9	20	2	51	2	0.3	3.9	0.77	96.9	89.1339	64.6081
2014	9	20	3	1	2	0.3	3.9	0.76	97.6	89.1339	64.0536
2014	9	20	3	11	2	0.3	3.9	0.77	97.6	89.1995	64.6575
2014	9	20	3	21	2	0.3	3.9	0.74	95.6	89.1995	62.16
2014	9	20	3	31	2	0.3	3.9	0.76	97.4	89.1339	63.7763
2014	9	20	3	41	2	0.3	3.9	0.75	97.3	89.1995	62.9925
2014	9	20	3	51	2	0.3	3.9	0.79	94.3	89.1995	66.6001
2014	9	20	4	1	2	0.3	3.9	0.79	97.4	89.1995	66.0451

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	4	11	2	0.3	3.9	0.76	94.7	89.1995	64.3801
2014	9	20	4	21	2	0.3	3.9	0.75	96.8	89.1995	62.7151
2014	9	20	4	31	2	0.3	3.9	0.75	96.6	89.1995	62.7151
2014	9	20	4	41	2	0.3	3.9	0.75	94.8	89.2651	63.0407
2014	9	20	4	51	2	0.3	3.9	0.76	96.2	89.3307	63.6446
2014	9	20	5	1	2	0.3	3.9	0.78	96.1	89.3963	65.3619
2014	9	20	5	11	2	0.3	3.9	0.77	97.9	89.3963	64.5275
2014	9	20	5	21	2	0.3	3.9	0.75	95.8	89.3963	62.8587
2014	9	20	5	31	2	0.3	3.9	0.78	97	89.462	65.4117
2014	9	20	5	41	2	0.3	3.9	0.77	95.9	89.462	64.5767
2014	9	20	5	51	2	0.3	3.9	0.76	96	89.462	64.02
2014	9	20	6	1	2	0.3	3.9	0.8	98.8	89.462	66.8035
2014	9	20	6	11	2	0.3	3.9	0.77	95.1	89.462	65.4118
2014	9	20	6	21	2	0.3	3.9	0.76	96.9	89.462	64.2984
2014	9	20	6	31	2	0.3	3.9	0.74	95.9	89.5276	62.1188
2014	9	20	6	41	2	0.3	3.9	0.76	95.5	89.462	64.0201
2014	9	20	6	51	2	0.3	3.9	0.8	96.4	89.5276	67.4115
2014	9	20	7	1	2	0.3	3.9	0.75	94.7	89.5276	63.7902
2014	9	20	7	11	2	0.3	3.9	0.73	97	89.5276	61.2832
2014	9	20	7	21	2	0.3	3.9	0.8	95.6	89.5276	67.9686
2014	9	20	7	31	2	0.3	3.9	0.77	97.1	89.5276	64.6259
2014	9	20	7	41	2	0.3	3.9	0.79	97.2	89.5276	66.2973
2014	9	20	7	51	2	0.3	3.9	0.76	96.2	89.5276	63.7903
2014	9	20	8	1	2	0.3	3.9	0.77	95.9	89.5276	65.1831
2014	9	20	8	11	2	0.3	3.9	0.8	94.9	89.5276	67.6901
2014	9	20	8	21	2	0.3	3.9	0.76	95.4	89.5276	64.626
2014	9	20	8	31	2	0.3	3.9	0.77	96.2	89.5276	64.626
2014	9	20	8	41	2	0.3	3.9	0.76	95.4	89.5276	64.626
2014	9	20	8	51	2	0.3	3.9	0.77	98.1	89.462	64.2985
2014	9	20	9	1	2	0.3	3.9	0.81	97.9	89.5276	67.9687
2014	9	20	9	11	2	0.3	3.9	0.77	96.6	89.5276	65.1831
2014	9	20	9	21	2	0.3	3.9	0.77	96.6	89.5276	64.6259
2014	9	20	9	31	2	0.3	3.9	0.78	96.3	89.462	65.6902
2014	9	20	9	41	2	0.3	3.9	0.79	94.8	89.5276	66.5758
2014	9	20	9	51	2	0.3	3.9	0.74	98.6	89.5276	62.3974
2014	9	20	10	1	2	0.3	3.9	0.77	96.4	89.462	64.8551
2014	9	20	10	11	2	0.3	3.9	0.78	97.3	89.462	65.4118
2014	9	20	10	21	2	0.3	3.9	0.79	95.2	89.462	66.8035
2014	9	20	10	31	2	0.3	3.9	0.77	96.6	89.462	64.5767
2014	9	20	10	41	2	0.3	3.9	0.76	98.7	89.462	63.7417
2014	9	20	10	51	2	0.3	3.9	0.77	95.6	89.462	65.4117
2014	9	20	11	1	2	0.3	3.9	0.75	98.5	89.462	63.1849
2014	9	20	11	11	2	0.3	3.9	0.77	101.3	89.3963	64.2495
2014	9	20	11	21	2	0.3	3.9	0.78	99.9	89.3963	65.0839
2014	9	20	11	31	2	0.3	3.9	0.77	97.1	89.3963	65.0838
2014	9	20	11	41	2	0.3	3.9	0.77	99.5	89.3963	64.5276

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	11	51	2	0.3	3.9	0.77	100.8	89.3963	64.2495
2014	9	20	12	1	2	0.3	3.9	0.79	99.9	89.3963	65.6402
2014	9	20	12	11	2	0.3	3.9	0.8	99.2	89.3963	66.7527
2014	9	20	12	21	2	0.3	3.9	0.75	98.5	89.3963	63.1369
2014	9	20	12	31	2	0.3	3.9	0.78	99.5	89.3307	64.7564
2014	9	20	12	41	2	0.3	3.9	0.78	97.3	89.3307	65.3122
2014	9	20	12	51	2	0.3	3.9	0.76	97.6	89.2651	64.1516
2014	9	20	13	1	2	0.3	3.9	0.77	98.8	89.1995	64.6577
2014	9	20	13	11	2	0.3	3.9	0.77	99.6	89.2651	64.1515
2014	9	20	13	21	2	0.3	3.9	0.8	100.9	89.1995	66.3227
2014	9	20	13	31	2	0.3	3.9	0.77	97.8	89.1339	64.8856
2014	9	20	13	41	2	0.3	3.9	0.77	99.5	89.1995	64.3802
2014	9	20	13	51	2	0.3	3.9	0.79	100.3	89.1339	65.4403
2014	9	20	14	1	2	0.3	3.9	0.79	96.4	89.1339	66.5494
2014	9	20	14	11	2	0.3	3.9	0.79	98.9	89.1339	65.7176
2014	9	20	14	21	2	0.3	3.9	0.78	98.7	89.1339	64.8857
2014	9	20	14	31	2	0.3	3.9	0.8	98	89.0683	66.7757
2014	9	20	14	41	2	0.3	3.9	0.77	99.5	89.0683	64.282
2014	9	20	14	51	2	0.3	3.9	0.78	99	89.0683	64.8361
2014	9	20	15	1	2	0.3	3.9	0.76	99.7	89.1339	63.4992
2014	9	20	15	11	2	0.3	3.9	0.76	100.2	89.0683	63.1736
2014	9	20	15	21	2	0.3	3.9	0.8	99.5	89.0683	66.2215
2014	9	20	15	31	2	0.3	3.9	0.8	97.8	89.1339	66.8267
2014	9	20	15	41	2	0.3	3.9	0.79	98.2	89.0683	65.6673
2014	9	20	15	51	2	0.3	3.9	0.78	100.1	89.0683	65.1132
2014	9	20	16	1	2	0.3	3.9	0.78	101.2	89.0026	64.5097
2014	9	20	16	11	2	0.3	3.9	0.78	95.8	89.0683	65.1132
2014	9	20	16	21	2	0.3	3.9	0.76	99	89.0026	63.1254
2014	9	20	16	31	2	0.3	3.9	0.78	98.2	89.0683	65.1132
2014	9	20	16	41	2	0.3	3.9	0.78	100.2	89.0026	64.7866
2014	9	20	16	51	2	0.3	3.9	0.75	98.6	89.0026	62.5717
2014	9	20	17	1	2	0.3	3.9	0.78	98.7	89.0683	64.8361
2014	9	20	17	11	2	0.3	3.9	0.78	97	89.0026	65.3403
2014	9	20	17	21	2	0.3	3.9	0.81	97.5	89.0683	67.6069
2014	9	20	17	31	2	0.3	3.9	0.78	97	89.0683	65.1132
2014	9	20	17	41	2	0.3	3.9	0.8	97.8	89.0683	66.7757
2014	9	20	17	51	2	0.3	3.9	0.8	98.8	89.0683	66.4986
2014	9	20	18	1	2	0.3	3.9	0.77	97.4	89.0683	64.282
2014	9	20	18	11	2	0.3	3.9	0.77	95.4	89.0026	64.7866
2014	9	20	18	21	2	0.3	3.9	0.75	96.3	89.0683	62.8966
2014	9	20	18	31	2	0.3	3.9	0.75	95.5	89.0683	62.8966
2014	9	20	18	41	2	0.3	3.9	0.75	99.3	89.0683	62.3425
2014	9	20	18	51	2	0.3	3.9	0.78	94.4	89.0683	65.3903
2014	9	20	19	1	2	0.3	3.9	0.77	98.4	89.0683	64.0049
2014	9	20	19	11	2	0.3	3.9	0.75	95.8	89.0683	63.1737
2014	9	20	19	21	2	0.3	3.9	0.76	96.2	89.0683	63.4508

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	19	31	2	0.3	3.9	0.76	95	89.0683	63.7278
2014	9	20	19	41	2	0.3	3.9	0.77	97.6	89.1339	64.6084
2014	9	20	19	51	2	0.3	3.9	0.76	94.5	89.1339	64.0538
2014	9	20	20	1	2	0.3	3.9	0.77	97.4	89.1339	64.3311
2014	9	20	20	11	2	0.3	3.9	0.77	101.1	89.1339	63.7765
2014	9	20	20	21	2	0.3	3.9	0.79	96	89.1339	66.2721
2014	9	20	20	31	2	0.3	3.9	0.76	96.2	89.0683	64.0049
2014	9	20	20	41	2	0.3	3.9	0.77	97.1	89.1339	64.3311
2014	9	20	20	51	2	0.3	3.9	0.78	98.2	89.1339	65.1629
2014	9	20	21	1	2	0.3	3.9	0.75	96.5	89.1995	63.2702
2014	9	20	21	11	2	0.3	3.9	0.75	95	89.1995	62.9927
2014	9	20	21	21	2	0.3	3.9	0.76	96.2	89.1995	63.5477
2014	9	20	21	31	2	0.3	3.9	0.76	96.2	89.1995	63.5477
2014	9	20	21	41	2	0.3	3.9	0.76	94.2	89.2651	64.1516
2014	9	20	21	51	2	0.3	3.9	0.79	98.1	89.2651	66.3733
2014	9	20	22	1	2	0.3	3.9	0.78	95.8	89.2651	65.2624
2014	9	20	22	11	2	0.3	3.9	0.76	97.2	89.3307	63.6446
2014	9	20	22	21	2	0.3	3.9	0.75	98.6	89.2651	62.4853
2014	9	20	22	31	2	0.3	3.9	0.76	96.4	89.3307	63.9225
2014	9	20	22	41	2	0.3	3.9	0.76	96.4	89.3307	64.2004
2014	9	20	22	51	2	0.3	3.9	0.76	97	89.3307	63.6446
2014	9	20	23	1	2	0.3	3.9	0.77	98.6	89.3307	64.4784
2014	9	20	23	11	2	0.3	3.9	0.79	96.7	89.2651	66.6509
2014	9	20	23	21	2	0.3	3.9	0.76	96.2	89.2651	63.8738
2014	9	20	23	31	2	0.3	3.9	0.78	98	89.3963	65.3619
2014	9	20	23	41	2	0.3	3.9	0.75	94.5	89.3963	63.4149
2014	9	20	23	51	2	0.3	3.9	0.77	98.3	89.3963	64.5275
2014	9	21	0	1	2	0.3	3.9	0.78	96.8	89.3963	65.64
2014	9	21	0	11	2	0.3	3.9	0.77	94.4	89.3963	64.8056
2014	9	21	0	21	2	0.3	3.9	0.74	95.1	89.3963	62.8587
2014	9	21	0	31	2	0.3	3.9	0.76	94.7	89.3963	64.2493
2014	9	21	0	41	2	0.3	3.9	0.78	97.5	89.462	65.69
2014	9	21	0	51	2	0.3	3.9	0.78	95.3	89.462	65.9683
2014	9	21	1	1	2	0.3	3.9	0.74	95.3	89.462	62.6282
2014	9	21	1	11	2	0.3	3.9	0.77	97.8	89.462	65.1333
2014	9	21	1	21	2	0.3	3.9	0.76	93.7	89.462	64.2983
2014	9	21	1	31	2	0.3	3.9	0.77	97.4	89.462	64.5766
2014	9	21	1	41	2	0.3	3.9	0.75	94	89.462	63.4632
2014	9	21	1	51	2	0.3	3.9	0.74	96.1	89.462	62.6282
2014	9	21	2	1	2	0.3	3.9	0.78	96.3	89.462	65.4117
2014	9	21	2	11	2	0.3	3.9	0.76	95.7	89.462	64.02
2014	9	21	2	21	2	0.3	3.9	0.77	97.1	89.462	65.1333
2014	9	21	2	31	2	0.3	3.9	0.78	95.1	89.462	65.69
2014	9	21	2	41	2	0.3	3.9	0.77	99.1	89.462	64.5767
2014	9	21	2	51	2	0.3	3.9	0.79	98.2	89.462	65.9684
2014	9	21	3	1	2	0.3	3.9	0.76	95.4	89.5276	64.6258

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	3	11	2	0.3	3.9	0.78	98.5	89.5276	65.1829
2014	9	21	3	21	2	0.3	3.9	0.78	96.6	89.5276	65.4615
2014	9	21	3	31	2	0.3	3.9	0.76	97.2	89.5276	64.0687
2014	9	21	3	41	2	0.3	3.9	0.76	95.4	89.5276	64.6258
2014	9	21	3	51	2	0.3	3.9	0.76	96.4	89.5276	64.3472
2014	9	21	4	1	2	0.3	3.9	0.76	96	89.5276	63.7901
2014	9	21	4	11	2	0.3	3.9	0.78	95.8	89.5276	66.2972
2014	9	21	4	21	2	0.3	3.9	0.79	96.2	89.5276	66.8543
2014	9	21	4	31	2	0.3	3.9	0.77	97.4	89.5276	64.6258
2014	9	21	4	41	2	0.3	3.9	0.76	97.9	89.5276	64.0687
2014	9	21	4	51	2	0.3	3.9	0.74	95.6	89.5276	62.6759
2014	9	21	5	1	2	0.3	3.9	0.78	98.9	89.5276	65.4615
2014	9	21	5	11	2	0.3	3.9	0.78	94.4	89.5276	65.7401
2014	9	21	5	21	2	0.3	3.9	0.75	96.8	89.5276	63.233
2014	9	21	5	31	2	0.3	3.9	0.79	94.5	89.5276	66.5758
2014	9	21	5	41	2	0.3	3.9	0.76	95.2	89.5276	64.0687
2014	9	21	5	51	2	0.3	3.9	0.79	98.6	89.5276	66.2972
2014	9	21	6	1	2	0.3	3.9	0.77	96.8	89.5276	65.183
2014	9	21	6	11	2	0.3	3.9	0.77	96.9	89.5276	64.9044
2014	9	21	6	21	2	0.3	3.9	0.78	97.5	89.5276	65.7401
2014	9	21	6	31	2	0.3	3.9	0.77	96.6	89.5276	64.6259
2014	9	21	6	41	2	0.3	3.9	0.77	95.9	89.5932	64.9538
2014	9	21	6	51	2	0.3	3.9	0.78	95	89.5276	66.2973
2014	9	21	7	1	2	0.3	3.9	0.76	97.2	89.5276	64.0688
2014	9	21	7	11	2	0.3	3.9	0.78	98	89.5276	65.183
2014	9	21	7	21	2	0.3	3.9	0.78	95	89.5932	66.3477
2014	9	21	7	31	2	0.3	3.9	0.74	93.8	89.5276	62.3974
2014	9	21	7	41	2	0.3	3.9	0.77	94.4	89.5276	65.4616
2014	9	21	7	51	2	0.3	3.9	0.76	96.7	89.5932	64.1175
2014	9	21	8	1	2	0.3	3.9	0.77	94.6	89.5276	65.1831
2014	9	21	8	11	2	0.3	3.9	0.77	93.7	89.5276	65.1831
2014	9	21	8	21	2	0.3	3.9	0.71	96.6	89.5276	59.8904
2014	9	21	8	31	2	0.3	3.9	0.75	95.3	89.5276	63.5117
2014	9	21	8	41	2	0.3	3.9	0.78	98.3	89.5276	65.1831
2014	9	21	8	51	2	0.3	3.9	0.76	97.4	89.5276	64.0688
2014	9	21	9	1	2	0.3	3.9	0.76	96.2	89.5276	63.7902
2014	9	21	9	11	2	0.3	3.9	0.77	97.6	89.5276	64.9045
2014	9	21	9	21	2	0.3	3.9	0.77	98.8	89.5276	64.9045
2014	9	21	9	31	2	0.3	3.9	0.79	98.6	89.5276	66.2972
2014	9	21	9	41	2	0.3	3.9	0.76	99.4	89.5276	63.7902
2014	9	21	9	51	2	0.3	3.9	0.78	98.2	89.5276	65.4615
2014	9	21	10	1	2	0.3	3.9	0.78	96.3	89.5276	65.7401
2014	9	21	10	11	2	0.3	3.9	0.78	96.6	89.5276	65.4615
2014	9	21	10	21	2	0.3	3.9	0.77	96.9	89.5276	64.9044
2014	9	21	10	31	2	0.3	3.9	0.78	99.5	89.5276	65.1829
2014	9	21	10	41	2	0.3	3.9	0.76	95.4	89.5276	64.6258

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	10	51	2	0.3	3.9	0.76	97.4	89.5276	64.0687
2014	9	21	11	1	2	0.3	3.9	0.77	97.1	89.5276	64.6258
2014	9	21	11	11	2	0.3	3.9	0.79	96.2	89.5276	66.8542
2014	9	21	11	21	2	0.3	3.9	0.76	97.7	89.5276	63.7901
2014	9	21	11	31	2	0.3	3.9	0.78	95.8	89.5276	65.74
2014	9	21	11	41	2	0.3	3.9	0.78	98.2	89.5276	65.4614
2014	9	21	11	51	2	0.3	3.9	0.78	101.9	89.462	64.5766
2014	9	21	12	1	2	0.3	3.9	0.77	99.5	89.462	64.5766
2014	9	21	12	11	2	0.3	3.9	0.76	98.7	89.462	64.0199
2014	9	21	12	21	2	0.3	3.9	0.78	100.1	89.462	65.4116
2014	9	21	12	31	2	0.3	3.9	0.77	97.1	89.462	64.8549
2014	9	21	12	41	2	0.3	3.9	0.8	100.4	89.462	66.5251
2014	9	21	12	51	2	0.3	3.9	0.79	96.7	89.462	66.2467
2014	9	21	13	1	2	0.3	3.9	0.79	99.3	89.3963	65.9182
2014	9	21	13	11	2	0.3	3.9	0.81	98.2	89.3963	67.8652
2014	9	21	13	21	2	0.3	3.9	0.79	100.8	89.3307	65.8681
2014	9	21	13	31	2	0.3	3.9	0.78	98.3	89.3963	65.0838
2014	9	21	13	41	2	0.3	3.9	0.76	98.4	89.3963	63.6932
2014	9	21	13	51	2	0.3	3.9	0.78	100.7	89.3307	64.7564
2014	9	21	14	1	2	0.3	3.9	0.77	98.8	89.3307	64.7564
2014	9	21	14	11	2	0.3	3.9	0.75	98.8	89.3307	62.533
2014	9	21	14	21	2	0.3	3.9	0.79	98.2	89.3307	65.868
2014	9	21	14	31	2	0.3	3.9	0.79	99.3	89.3307	66.1459
2014	9	21	14	41	2	0.3	3.9	0.78	98.2	89.3307	65.3121
2014	9	21	14	51	2	0.3	3.9	0.78	101.9	89.3307	64.7563
2014	9	21	15	1	2	0.3	3.9	0.78	100.1	89.2651	65.2624
2014	9	21	15	11	2	0.3	3.9	0.77	101.4	89.3307	63.6446
2014	9	21	15	21	2	0.3	3.9	0.81	98.9	89.2651	67.7619
2014	9	21	15	31	2	0.3	3.9	0.77	96.3	89.1995	64.9352
2014	9	21	15	41	2	0.3	3.9	0.81	95.5	89.2651	68.595
2014	9	21	15	51	2	0.3	3.9	0.8	98.8	89.2651	66.6511
2014	9	21	16	1	2	0.3	3.9	0.76	99.5	89.2651	63.3185
2014	9	21	16	11	2	0.3	3.9	0.76	99.7	89.2651	63.5962
2014	9	21	16	21	2	0.3	3.9	0.78	101.6	89.2651	64.707
2014	9	21	16	31	2	0.3	3.9	0.78	100.5	89.2651	64.707
2014	9	21	16	41	2	0.3	3.9	0.78	97.8	89.2651	65.2625
2014	9	21	16	51	2	0.3	3.9	0.79	96.4	89.2651	66.3733
2014	9	21	17	1	2	0.3	3.9	0.76	99.7	89.2651	63.3185
2014	9	21	17	11	2	0.3	3.9	0.78	100.5	89.2651	64.7071
2014	9	21	17	21	2	0.3	3.9	0.75	99.3	89.1995	62.9927
2014	9	21	17	31	2	0.3	3.9	0.81	98.4	89.2651	67.4842
2014	9	21	17	41	2	0.3	3.9	0.79	98.3	89.2651	66.3733
2014	9	21	17	51	2	0.3	3.9	0.77	98.3	89.3307	64.4785
2014	9	21	18	1	2	0.3	3.9	0.78	98.2	89.3307	65.3122
2014	9	21	18	11	2	0.3	3.9	0.77	96.8	89.3307	65.0343
2014	9	21	18	21	2	0.3	3.9	0.78	95.5	89.3963	66.1964

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	18	31	2	0.3	3.9	0.77	95.4	89.3963	65.0839
2014	9	21	18	41	2	0.3	3.9	0.76	94.5	89.3963	64.2494
2014	9	21	18	51	2	0.3	3.9	0.79	95.2	89.3963	66.7527
2014	9	21	19	1	2	0.3	3.9	0.79	95.9	89.3963	66.7527
2014	9	21	19	11	2	0.3	3.9	0.76	96.9	89.3963	64.2494
2014	9	21	19	21	2	0.3	3.9	0.73	95.7	89.3963	61.7462
2014	9	21	19	31	2	0.3	3.9	0.8	94.2	89.3963	67.5871
2014	9	21	19	41	2	0.3	3.9	0.75	95.3	89.3963	63.415
2014	9	21	19	51	2	0.3	3.9	0.76	94	89.462	64.2983
2014	9	21	20	1	2	0.3	3.9	0.77	95.6	89.462	64.855
2014	9	21	20	11	2	0.3	3.9	0.75	95	89.462	63.7416
2014	9	21	20	21	2	0.3	3.9	0.78	95.8	89.462	65.4117
2014	9	21	20	31	2	0.3	3.9	0.78	97	89.462	65.6901
2014	9	21	20	41	2	0.3	3.9	0.78	93.6	89.462	65.9684
2014	9	21	20	51	2	0.3	3.9	0.77	94.7	89.462	64.855
2014	9	21	21	1	2	0.3	3.9	0.79	95.3	89.5276	66.5757
2014	9	21	21	11	2	0.3	3.9	0.8	96.6	89.5276	67.4114
2014	9	21	21	21	2	0.3	3.9	0.77	95.6	89.5276	65.4614
2014	9	21	21	31	2	0.3	3.9	0.79	96.4	89.5276	66.5757
2014	9	21	21	41	2	0.3	3.9	0.77	94.9	89.5276	65.4614
2014	9	21	21	51	2	0.3	3.9	0.78	95.1	89.5276	65.74
2014	9	21	22	1	2	0.3	3.9	0.8	95.9	89.5276	67.9685
2014	9	21	22	11	2	0.3	3.9	0.78	97.5	89.5276	65.74
2014	9	21	22	21	2	0.3	3.9	0.81	94.4	89.5276	68.247
2014	9	21	22	31	2	0.3	3.9	0.76	98.5	89.5276	63.5115
2014	9	21	22	41	2	0.3	3.9	0.74	94.8	89.5276	62.6759
2014	9	21	22	51	2	0.3	3.9	0.79	96.9	89.5276	66.5757
2014	9	21	23	1	2	0.3	3.9	0.76	95.2	89.5276	64.0687
2014	9	21	23	11	2	0.3	3.9	0.77	94.6	89.5932	65.5112
2014	9	21	23	21	2	0.3	3.9	0.76	96	89.5932	64.1174
2014	9	21	23	31	2	0.3	3.9	0.75	97.7	89.5932	63.5598
2014	9	21	23	41	2	0.3	3.9	0.76	97.4	89.5932	64.1174
2014	9	21	23	51	2	0.3	3.9	0.74	96.1	89.5932	62.7235
2014	9	22	0	1	2	0.3	3.9	0.76	96.2	89.5932	64.1174
2014	9	22	0	11	2	0.3	3.9	0.74	96.4	89.5932	62.4447
2014	9	22	0	21	2	0.3	3.9	0.77	96.9	89.5932	64.9537
2014	9	22	0	31	2	0.3	3.9	0.77	95.9	89.5932	65.2325
2014	9	22	0	41	2	0.3	3.9	0.78	95.8	89.5932	65.79
2014	9	22	0	51	2	0.3	3.9	0.77	94.2	89.5932	65.2325
2014	9	22	1	1	2	0.3	3.9	0.76	96.4	89.5932	64.3962
2014	9	22	1	11	2	0.3	3.9	0.78	95.8	89.5932	66.3476
2014	9	22	1	21	2	0.3	3.9	0.78	96.6	89.5932	65.5113
2014	9	22	1	31	2	0.3	3.9	0.77	95.2	89.5932	64.9538
2014	9	22	1	41	2	0.3	3.9	0.79	96.4	89.5932	66.6264
2014	9	22	1	51	2	0.3	3.9	0.74	96.6	89.5932	62.7236
2014	9	22	2	1	2	0.3	3.9	0.78	96.5	89.5932	66.0689

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	2	11	2	0.3	3.9	0.79	98.2	89.5932	66.0689
2014	9	22	2	21	2	0.3	3.9	0.78	98	89.5932	65.7901
2014	9	22	2	31	2	0.3	3.9	0.79	97.9	89.5932	66.6264
2014	9	22	2	41	2	0.3	3.9	0.78	97	89.5932	65.7901
2014	9	22	2	51	2	0.3	3.9	0.75	95.8	89.5932	63.56
2014	9	22	3	1	2	0.3	3.9	0.79	95	89.5932	66.6265
2014	9	22	3	11	2	0.3	3.9	0.77	96.6	89.5932	65.2326
2014	9	22	3	21	2	0.3	3.9	0.78	95.8	89.5932	65.7902
2014	9	22	3	31	2	0.3	4.3	0.78	95.8	89.6588	65.5612
2014	9	22	3	41	2	0.3	3.9	0.78	95.5	89.5932	66.3477
2014	9	22	3	51	2	0.3	4.3	0.77	95.9	89.6588	65.0032
2014	9	22	4	1	2	0.3	4.3	0.78	96.5	89.6588	66.1192
2014	9	22	4	11	2	0.3	4.3	0.77	96.9	89.6588	65.0033
2014	9	22	4	21	2	0.3	4.3	0.77	96.6	89.6588	64.7243
2014	9	22	4	31	2	0.3	4.3	0.76	96	89.6588	63.8873
2014	9	22	4	41	2	0.3	4.3	0.76	97.2	89.6588	64.4453
2014	9	22	4	51	2	0.3	4.3	0.78	96.3	89.6588	65.8402
2014	9	22	5	1	2	0.3	4.3	0.76	97.2	89.6588	63.8874
2014	9	22	5	11	2	0.3	4.3	0.8	95.9	89.6588	67.5142
2014	9	22	5	21	2	0.3	4.3	0.77	96.2	89.6588	64.7243
2014	9	22	5	31	2	0.3	4.3	0.77	95.9	89.6588	65.0033
2014	9	22	5	41	2	0.3	4.3	0.77	98.3	89.7244	65.0527
2014	9	22	5	51	2	0.3	4.3	0.79	95.7	89.7244	67.007
2014	9	22	6	1	2	0.3	4.3	0.78	95.1	89.7244	65.8903
2014	9	22	6	11	2	0.3	4.3	0.77	96.9	89.79	65.102
2014	9	22	6	21	2	0.3	4.3	0.76	96.5	89.7244	63.9359
2014	9	22	6	31	2	0.3	4.3	0.75	96.8	89.79	63.705
2014	9	22	6	41	2	0.3	4.3	0.78	96.1	89.79	65.6609
2014	9	22	6	51	2	0.3	4.3	0.74	97.1	89.79	62.5874
2014	9	22	7	1	2	0.3	4.3	0.77	96.2	89.79	64.8227
2014	9	22	7	11	2	0.3	4.3	0.75	96	89.79	63.7051
2014	9	22	7	21	2	0.3	4.3	0.75	98.8	89.79	63.4257
2014	9	22	7	31	2	0.3	4.3	0.8	96.4	89.79	67.6168
2014	9	22	7	41	2	0.3	4.3	0.77	96.8	89.79	65.3815
2014	9	22	7	51	2	0.3	4.3	0.76	97.2	89.8556	64.3126
2014	9	22	8	1	2	0.3	4.3	0.78	98.3	89.8556	65.4311
2014	9	22	8	11	2	0.3	4.3	0.76	95.2	89.8556	64.5922
2014	9	22	8	21	2	0.3	4.3	0.75	97.3	89.79	63.4257
2014	9	22	8	31	2	0.3	4.3	0.8	97.1	89.79	67.6168
2014	9	22	8	41	2	0.3	4.3	0.77	95.9	89.79	65.1021
2014	9	22	8	51	2	0.3	4.3	0.78	96.3	89.79	65.9403
2014	9	22	9	1	2	0.3	4.3	0.76	98.2	89.79	63.9845
2014	9	22	9	11	2	0.3	4.3	0.75	96	89.79	63.705
2014	9	22	9	21	2	0.3	4.3	0.79	93.3	89.79	67.0579
2014	9	22	9	31	2	0.3	4.3	0.79	95.9	89.79	67.0579
2014	9	22	9	41	2	0.3	4.3	0.79	97.4	89.79	66.7785

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	9	51	2	0.3	4.3	0.76	97.2	89.79	64.5432
2014	9	22	10	1	2	0.3	4.3	0.73	95.9	89.79	61.7491
2014	9	22	10	11	2	0.3	4.3	0.77	99.3	89.79	65.102
2014	9	22	10	21	2	0.3	4.3	0.77	95.3	89.79	65.6608
2014	9	22	10	31	2	0.3	4.3	0.81	96.5	89.79	68.1754
2014	9	22	10	41	2	0.3	4.3	0.78	99.1	89.79	65.9402
2014	9	22	10	51	2	0.3	4.3	0.78	101.4	89.79	65.1019
2014	9	22	11	1	2	0.3	4.3	0.76	98.4	89.79	63.9843
2014	9	22	11	11	2	0.3	4.3	0.78	99.4	89.7244	65.8901
2014	9	22	11	21	2	0.3	4.3	0.8	100.2	89.7244	67.0069
2014	9	22	11	31	2	0.3	4.3	0.78	99.2	89.79	65.3813
2014	9	22	11	41	2	0.3	4.3	0.78	99.7	89.7244	65.6109
2014	9	22	11	51	2	0.3	4.3	0.75	100.4	89.7244	62.5397
2014	9	22	12	1	2	0.3	4.3	0.8	98	89.7244	67.286
2014	9	22	12	11	2	0.3	4.3	0.81	98.4	89.7244	67.8444
2014	9	22	12	21	2	0.3	4.3	0.83	100.1	89.7244	69.2404
2014	9	22	12	31	2	0.3	4.3	0.79	101	89.7244	65.89
2014	9	22	12	41	2	0.3	4.3	0.79	102	89.7244	65.6108
2014	9	22	12	51	2	0.3	4.3	0.8	97.1	89.79	67.6164
2014	9	22	13	1	2	0.3	4.3	0.77	100.3	89.7244	64.2148
2014	9	22	13	11	2	0.3	4.3	0.79	102.5	89.7244	65.6108
2014	9	22	13	21	2	0.3	4.3	0.79	102.5	89.6588	65.561
2014	9	22	13	31	2	0.3	4.3	0.77	99.5	89.7244	64.7732
2014	9	22	13	41	2	0.3	4.3	0.77	101.8	89.6588	63.8871
2014	9	22	13	51	2	0.3	4.3	0.78	103.2	89.6588	64.4451
2014	9	22	14	1	2	0.3	4.3	0.8	96.6	89.6588	67.2349
2014	9	22	14	11	2	0.3	4.3	0.79	98.9	89.6588	66.119
2014	9	22	14	21	2	0.3	4.3	0.79	99.8	89.6588	66.398
2014	9	22	14	31	2	0.3	4.3	0.76	101.4	89.6588	63.6081
2014	9	22	14	41	2	0.3	4.3	0.78	101.5	89.6588	64.7241
2014	9	22	14	51	2	0.3	4.3	0.79	98.1	89.6588	66.398
2014	9	22	15	1	2	0.3	4.3	0.77	99.5	89.6588	64.7241
2014	9	22	15	11	2	0.3	3.9	0.78	102.4	89.5932	64.3962
2014	9	22	15	21	2	0.3	4.3	0.79	99.3	89.6588	66.398
2014	9	22	15	31	2	0.3	4.3	0.79	99.3	89.6588	66.119
2014	9	22	15	41	2	0.3	4.3	0.8	102.6	89.6588	66.398
2014	9	22	15	51	2	0.3	4.3	0.75	99.5	89.6588	63.0502
2014	9	22	16	1	2	0.3	4.3	0.78	98.7	89.6588	65.84
2014	9	22	16	11	2	0.3	4.3	0.79	101.7	89.6588	65.84
2014	9	22	16	21	2	0.3	4.3	0.81	98.9	89.6588	68.0719
2014	9	22	16	31	2	0.3	4.3	0.78	99.5	89.6588	65.2821
2014	9	22	16	41	2	0.3	4.3	0.78	99.5	89.6588	65.2821
2014	9	22	16	51	2	0.3	4.3	0.77	99.3	89.6588	65.0031
2014	9	22	17	1	2	0.3	4.3	0.77	97.5	89.6588	65.2821
2014	9	22	17	11	2	0.3	4.3	0.77	99.1	89.6588	64.7241
2014	9	22	17	21	2	0.3	4.3	0.79	100.8	89.6588	65.5611

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	17	31	2	0.3	4.3	0.8	99.2	89.6588	67.235
2014	9	22	17	41	2	0.3	4.3	0.77	98.9	89.6588	64.4452
2014	9	22	17	51	2	0.3	4.3	0.79	98.9	89.6588	66.1191
2014	9	22	18	1	2	0.3	4.3	0.79	97.6	89.6588	66.956
2014	9	22	18	11	2	0.3	4.3	0.79	96.9	89.6588	66.677
2014	9	22	18	21	2	0.3	4.3	0.77	96.3	89.6588	65.2821
2014	9	22	18	31	2	0.3	4.3	0.82	96.2	89.6588	68.9089
2014	9	22	18	41	2	0.3	4.3	0.81	98.6	89.6588	68.3509
2014	9	22	18	51	2	0.3	4.3	0.8	97.3	89.6588	67.235
2014	9	22	19	1	2	0.3	4.3	0.8	100.4	89.6588	66.956
2014	9	22	19	11	2	0.3	4.3	0.79	96.4	89.6588	66.956
2014	9	22	19	21	2	0.3	4.3	0.82	98.7	89.7244	69.2403
2014	9	22	19	31	2	0.3	4.3	0.79	96.9	89.7244	66.4484
2014	9	22	19	41	2	0.3	4.3	0.8	95.4	89.7244	67.8443
2014	9	22	19	51	2	0.3	4.3	0.78	99.2	89.7244	65.3316
2014	9	22	20	1	2	0.3	4.3	0.76	97.2	89.7244	63.9356
2014	9	22	20	11	2	0.3	4.3	0.77	98.4	89.7244	64.494
2014	9	22	20	21	2	0.3	4.3	0.77	97.6	89.7244	65.0524
2014	9	22	20	31	2	0.3	4.3	0.76	96	89.7244	64.2148
2014	9	22	20	41	2	0.3	4.3	0.79	98.9	89.79	66.2193
2014	9	22	20	51	2	0.3	4.3	0.78	96.3	89.79	65.6605
2014	9	22	21	1	2	0.3	4.3	0.79	97.9	89.79	66.4987
2014	9	22	21	11	2	0.3	4.3	0.78	96.5	89.79	66.2193
2014	9	22	21	21	2	0.3	4.3	0.78	96.3	89.79	65.9399
2014	9	22	21	31	2	0.3	4.3	0.8	96.4	89.8556	67.6675
2014	9	22	21	41	2	0.3	4.3	0.79	95.3	89.79	66.7781
2014	9	22	21	51	2	0.3	4.3	0.8	98.1	89.8556	67.1083
2014	9	22	22	1	2	0.3	4.3	0.77	97.1	89.8556	65.4306
2014	9	22	22	11	2	0.3	4.3	0.79	95.5	89.8556	67.3879
2014	9	22	22	21	2	0.3	4.3	0.76	97	89.8556	64.0325
2014	9	22	22	31	2	0.3	4.3	0.77	95.6	89.8556	65.1509
2014	9	22	22	41	2	0.3	4.3	0.79	95	89.8556	67.1083
2014	9	22	22	51	2	0.3	4.3	0.77	95.9	89.8556	64.8713
2014	9	22	23	1	2	0.3	4.3	0.77	97.1	89.8556	64.8713
2014	9	22	23	11	2	0.3	4.3	0.8	96.4	89.8556	67.6675
2014	9	22	23	21	2	0.3	4.3	0.78	95.5	89.9213	66.5994
2014	9	22	23	31	2	0.3	4.3	0.76	95.2	89.9213	64.6406
2014	9	22	23	41	2	0.3	4.3	0.78	96	89.9213	66.3196
2014	9	22	23	51	2	0.3	4.3	0.74	96.1	89.9869	62.7292
2014	9	23	0	1	2	0.3	4.3	0.76	96.2	89.9869	64.4095
2014	9	23	0	11	2	0.3	4.3	0.75	94.5	90.0525	63.8977
2014	9	23	0	21	2	0.3	4.3	0.76	95.4	90.0525	65.0187
2014	9	23	0	31	2	0.3	4.3	0.76	95	90.0525	64.4582
2014	9	23	0	41	2	0.3	4.3	0.78	97.7	90.0525	66.42
2014	9	23	0	51	2	0.3	4.3	0.78	95.8	90.1181	66.7507
2014	9	23	1	1	2	0.3	4.3	0.75	94.5	90.1181	63.946

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	1	11	2	0.3	4.3	0.78	95.8	90.1837	65.959
2014	9	23	1	21	2	0.3	4.3	0.77	96.2	90.1837	65.117
2014	9	23	1	31	2	0.3	4.3	0.78	96.6	90.1837	65.9591
2014	9	23	1	41	2	0.3	4.3	0.75	95	90.1837	63.7137
2014	9	23	1	51	2	0.3	4.3	0.76	97	90.1837	64.275
2014	9	23	2	1	2	0.3	4.3	0.8	93.1	90.1837	68.2045
2014	9	23	2	11	2	0.3	4.3	0.83	94.7	90.1837	71.0113
2014	9	23	2	21	2	0.3	4.3	0.77	96.8	90.1837	65.6785
2014	9	23	2	31	2	0.3	4.3	0.78	96.3	90.1837	66.2398
2014	9	23	2	41	2	0.3	4.3	0.76	97.4	90.1837	64.5558
2014	9	23	2	51	2	0.3	4.3	0.75	96.1	90.1837	63.4331
2014	9	23	3	1	2	0.3	4.3	0.75	95	90.1837	64.2751
2014	9	23	3	11	2	0.3	4.3	0.79	95	90.1837	67.0819
2014	9	23	3	21	2	0.3	4.3	0.78	95.6	90.1837	66.2399
2014	9	23	3	31	2	0.3	4.3	0.77	95.3	90.2494	66.009
2014	9	23	3	41	2	0.3	4.3	0.78	96.6	90.2494	66.009
2014	9	23	3	51	2	0.3	4.3	0.79	94.3	90.2494	67.6944
2014	9	23	4	1	2	0.3	4.3	0.76	93.5	90.2494	65.1664
2014	9	23	4	11	2	0.3	4.3	0.76	95.9	90.2494	64.8855
2014	9	23	4	21	2	0.3	4.3	0.76	95.7	90.2494	64.8855
2014	9	23	4	31	2	0.3	4.3	0.77	95.9	90.2494	65.7282
2014	9	23	4	41	2	0.3	4.3	0.78	95.3	90.2494	66.5709
2014	9	23	4	51	2	0.3	4.3	0.76	95.9	90.2494	64.8855
2014	9	23	5	1	2	0.3	4.3	0.77	96.2	90.315	65.2156
2014	9	23	5	11	2	0.3	4.3	0.76	95.5	90.315	64.6534
2014	9	23	5	21	2	0.3	4.3	0.74	94	90.315	63.529
2014	9	23	5	31	2	0.3	4.3	0.77	96.6	90.315	65.2156
2014	9	23	5	41	2	0.3	4.3	0.75	97.6	90.315	63.529
2014	9	23	5	51	2	0.3	4.3	0.77	95.3	90.315	66.0589
2014	9	23	6	1	2	0.3	4.3	0.77	97.4	90.315	65.2156
2014	9	23	6	11	2	0.3	4.3	0.77	95.6	90.3806	65.5461
2014	9	23	6	21	2	0.3	4.3	0.79	97.4	90.3806	67.234
2014	9	23	6	31	2	0.3	4.3	0.77	94.7	90.3806	65.5461
2014	9	23	6	41	2	0.3	4.3	0.79	95	90.3806	67.234
2014	9	23	6	51	2	0.3	4.3	0.8	97.3	90.3806	68.078
2014	9	23	7	1	2	0.3	4.3	0.77	96.1	90.3806	65.5462
2014	9	23	7	11	2	0.3	4.3	0.77	96.3	90.3806	65.8275
2014	9	23	7	21	2	0.3	4.3	0.79	95.5	90.3806	67.7967
2014	9	23	7	31	2	0.3	4.3	0.78	98	90.3806	66.1088
2014	9	23	7	41	2	0.3	4.3	0.78	97	90.3806	66.6715
2014	9	23	7	51	2	0.3	4.3	0.79	97.7	90.3806	66.9528
2014	9	23	8	1	2	0.3	4.3	0.77	98.3	90.3806	65.2649
2014	9	23	8	11	2	0.3	4.3	0.77	94.9	90.3806	66.1088
2014	9	23	8	21	2	0.3	4.3	0.77	95.6	90.3806	65.8275
2014	9	23	8	31	2	0.3	4.3	0.78	96.6	90.3806	66.1088
2014	9	23	8	41	2	0.3	4.3	0.78	95.8	90.3806	66.9528

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	8	51	2	0.3	4.3	0.75	97.3	90.3806	63.577
2014	9	23	9	1	2	0.3	4.3	0.78	95.3	90.3806	66.6714
2014	9	23	9	11	2	0.3	4.3	0.8	96.2	90.3806	67.7967
2014	9	23	9	21	2	0.3	4.3	0.79	95.5	90.3806	67.7967
2014	9	23	9	31	2	0.3	4.3	0.8	96.3	90.3806	68.3593
2014	9	23	9	41	2	0.3	4.3	0.79	98.8	90.3806	66.9527
2014	9	23	9	51	2	0.3	4.3	0.78	97.5	90.3806	66.6714
2014	9	23	10	1	2	0.3	4.3	0.76	99.1	90.3806	64.7022
2014	9	23	10	11	2	0.3	4.3	0.8	97.5	90.315	68.3078
2014	9	23	10	21	2	0.3	4.3	0.8	97.8	90.3806	67.7966
2014	9	23	10	31	2	0.3	4.3	0.8	97.8	90.315	68.0267
2014	9	23	10	41	2	0.3	4.3	0.79	98.6	90.315	66.6211
2014	9	23	10	51	2	0.3	4.3	0.78	99.5	90.315	65.4967
2014	9	23	11	1	2	0.3	4.3	0.78	98	90.315	65.7778
2014	9	23	11	11	2	0.3	4.3	0.77	97.4	90.315	65.2156
2014	9	23	11	21	2	0.3	4.3	0.8	95.6	90.315	68.3077
2014	9	23	11	31	2	0.3	4.3	0.81	99.1	90.315	68.3077
2014	9	23	11	41	2	0.3	4.3	0.84	98.4	90.315	70.8376
2014	9	23	11	51	2	0.3	4.3	0.77	97.9	90.315	65.2156
2014	9	23	12	1	2	0.3	4.3	0.78	101.5	90.315	65.2155
2014	9	23	12	11	2	0.3	4.3	0.79	104.3	90.315	65.2155
2014	9	23	12	21	2	0.3	4.3	0.77	99.5	90.315	65.2155
2014	9	23	12	31	2	0.3	4.3	0.78	99.5	90.315	65.7777
2014	9	23	12	41	2	0.3	4.3	0.79	102.7	90.315	66.0588
2014	9	23	12	51	2	0.3	4.3	0.79	102.5	90.2494	66.009
2014	9	23	13	1	2	0.3	4.3	0.78	101.4	90.2494	65.4473
2014	9	23	13	11	2	0.3	4.3	0.81	103.9	90.2494	67.1326
2014	9	23	13	21	2	0.3	4.3	0.78	101.5	90.2494	65.1664
2014	9	23	13	31	2	0.3	4.3	0.78	100.4	90.2494	65.7281
2014	9	23	13	41	2	0.3	4.3	0.78	101.6	90.2494	65.4473
2014	9	23	13	51	2	0.3	4.3	0.78	97.5	90.2494	66.2899
2014	9	23	14	1	2	0.3	4.3	0.8	103.8	90.2494	66.5708
2014	9	23	14	11	2	0.3	4.3	0.79	102.8	90.1837	65.6786
2014	9	23	14	21	2	0.3	4.3	0.8	101.4	90.1837	66.8013
2014	9	23	14	31	2	0.3	4.3	0.78	101.4	90.1837	65.3979
2014	9	23	14	41	2	0.3	4.3	0.78	100.4	90.1837	65.6786
2014	9	23	14	51	2	0.3	4.3	0.78	101.9	90.1181	65.0681
2014	9	23	15	1	2	0.3	4.3	0.8	99.5	90.1837	67.3627
2014	9	23	15	11	2	0.3	4.3	0.8	101.8	90.1837	67.3627
2014	9	23	15	21	2	0.3	4.3	0.78	99.7	90.1181	65.3486
2014	9	23	15	31	2	0.3	4.3	0.8	98.7	90.1181	67.8728
2014	9	23	15	41	2	0.3	4.3	0.78	101.6	90.1181	65.3487
2014	9	23	15	51	2	0.3	4.3	0.82	98.3	90.1181	69.5556
2014	9	23	16	1	2	0.3	4.3	0.78	99.7	90.1181	65.9096
2014	9	23	16	11	2	0.3	4.3	0.77	100.3	90.1181	65.0682
2014	9	23	16	21	2	0.3	4.3	0.81	97.2	90.1181	68.9947

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	16	31	2	0.3	4.3	0.76	96.9	90.1181	64.7878
2014	9	23	16	41	2	0.3	4.3	0.79	100.2	90.1181	66.751
2014	9	23	16	51	2	0.3	4.3	0.79	99.8	90.1181	66.751
2014	9	23	17	1	2	0.3	4.3	0.8	99.2	90.1181	67.5924
2014	9	23	17	11	2	0.3	4.3	0.79	99.6	90.1181	66.4706
2014	9	23	17	21	2	0.3	4.3	0.81	98.1	90.1837	68.7662
2014	9	23	17	31	2	0.3	4.3	0.79	97.1	90.1181	67.312
2014	9	23	17	41	2	0.3	4.3	0.79	98.4	90.1181	66.4706
2014	9	23	17	51	2	0.3	4.3	0.78	99.7	90.1837	65.3981
2014	9	23	18	1	2	0.3	4.3	0.78	98.7	90.1181	65.6292
2014	9	23	18	11	2	0.3	4.3	0.79	100	90.1837	66.8015
2014	9	23	18	21	2	0.3	4.3	0.79	100.2	90.1837	66.8015
2014	9	23	18	31	2	0.3	4.3	0.79	98.1	90.1837	67.0821
2014	9	23	18	41	2	0.3	4.3	0.8	97.7	90.1837	68.2048
2014	9	23	18	51	2	0.3	4.3	0.81	98	90.1837	68.2048
2014	9	23	19	1	2	0.3	4.3	0.78	98.5	90.1837	65.9594
2014	9	23	19	11	2	0.3	4.3	0.76	96.7	90.1837	64.556
2014	9	23	19	21	2	0.3	4.3	0.79	97.7	90.1837	66.8014
2014	9	23	19	31	2	0.3	4.3	0.81	99.1	90.1837	68.2048
2014	9	23	19	41	2	0.3	4.3	0.79	98.1	90.1837	66.8014
2014	9	23	19	51	2	0.3	4.3	0.81	98.4	90.1837	68.4855
2014	9	23	20	1	2	0.3	4.3	0.78	94.3	90.1837	66.8014
2014	9	23	20	11	2	0.3	4.3	0.8	97.3	90.2494	68.2562
2014	9	23	20	21	2	0.3	4.3	0.79	98.6	90.2494	66.8518
2014	9	23	20	31	2	0.3	4.3	0.77	96.3	90.2494	65.7282
2014	9	23	20	41	2	0.3	4.3	0.77	95.6	90.2494	65.7282
2014	9	23	20	51	2	0.3	4.3	0.75	95	90.2494	64.3238
2014	9	23	21	1	2	0.3	4.3	0.78	97.5	90.2494	66.29
2014	9	23	21	11	2	0.3	4.3	0.76	95.5	90.315	64.6534
2014	9	23	21	21	2	0.3	4.3	0.79	97.1	90.315	67.4644
2014	9	23	21	31	2	0.3	4.3	0.78	96.1	90.315	66.0589
2014	9	23	21	41	2	0.3	4.3	0.76	94.7	90.315	64.6534
2014	9	23	21	51	2	0.3	4.3	0.76	94.7	90.315	65.2155
2014	9	23	22	1	2	0.3	4.3	0.76	94.7	90.315	64.6533
2014	9	23	22	11	2	0.3	4.3	0.77	98.3	90.315	65.4967
2014	9	23	22	21	2	0.3	4.3	0.77	95.1	90.315	65.7778
2014	9	23	22	31	2	0.3	4.3	0.78	95.3	90.315	66.6211
2014	9	23	22	41	2	0.3	4.3	0.72	96	90.315	61.5612
2014	9	23	22	51	2	0.3	4.3	0.77	95.1	90.315	65.7778
2014	9	23	23	1	2	0.3	4.3	0.81	96.5	90.315	69.151
2014	9	23	23	11	2	0.3	4.3	0.74	96.8	90.315	63.2479
2014	9	23	23	21	2	0.3	4.3	0.78	95.1	90.315	66.34
2014	9	23	23	31	2	0.3	4.3	0.77	93.7	90.315	65.7778
2014	9	23	23	41	2	0.3	4.3	0.79	94.5	90.315	67.1833
2014	9	23	23	51	2	0.3	4.3	0.8	95.2	90.315	68.0266
2014	9	24	0	1	2	0.3	4.3	0.75	95.2	90.315	64.3723

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	0	11	2	0.3	4.3	0.77	95.6	90.315	65.4967
2014	9	24	0	21	2	0.3	4.3	0.74	97.3	90.315	63.2479
2014	9	24	0	31	2	0.3	4.3	0.77	96.1	90.315	65.4967
2014	9	24	0	41	2	0.3	4.3	0.78	96.5	90.315	66.6211
2014	9	24	0	51	2	0.3	4.3	0.79	97.6	90.3806	67.5153
2014	9	24	1	1	2	0.3	4.3	0.77	95.9	90.315	65.4968
2014	9	24	1	11	2	0.3	4.3	0.8	96.6	90.3806	68.3593
2014	9	24	1	21	2	0.3	4.3	0.79	95.7	90.3806	67.7966
2014	9	24	1	31	2	0.3	4.3	0.75	96.3	90.3806	63.8583
2014	9	24	1	41	2	0.3	4.3	0.75	95.5	90.3806	63.8583
2014	9	24	1	51	2	0.3	4.3	0.77	95.9	90.3806	65.8275
2014	9	24	2	1	2	0.3	4.3	0.76	97.4	90.3806	64.7022
2014	9	24	2	11	2	0.3	4.3	0.76	96	90.3806	64.7023
2014	9	24	2	21	2	0.3	4.3	0.78	96.7	90.3806	66.6715
2014	9	24	2	31	2	0.3	4.3	0.79	96.2	90.3806	67.2341
2014	9	24	2	41	2	0.3	4.3	0.77	95.9	90.3806	65.5462
2014	9	24	2	51	2	0.3	4.3	0.77	97.1	90.3806	65.5463
2014	9	24	3	1	2	0.3	4.3	0.76	93.2	90.3806	64.9836
2014	9	24	3	11	2	0.3	4.3	0.78	95.6	90.3806	66.3902
2014	9	24	3	21	2	0.3	4.3	0.8	97.5	90.3806	68.3594
2014	9	24	3	31	2	0.3	4.3	0.8	95	90.3806	68.0781
2014	9	24	3	41	2	0.3	4.3	0.78	97	90.3806	66.3903
2014	9	24	3	51	2	0.3	4.3	0.75	95.8	90.3806	63.8585
2014	9	24	4	1	2	0.3	4.3	0.77	95.9	90.3806	65.8277
2014	9	24	4	11	2	0.3	4.3	0.76	95	90.3806	64.7024
2014	9	24	4	21	2	0.3	4.3	0.77	93.9	90.3806	65.8277
2014	9	24	4	31	2	0.3	4.3	0.78	96	90.3806	66.6717
2014	9	24	4	41	2	0.3	4.3	0.77	95.4	90.3806	65.5464
2014	9	24	4	51	2	0.3	4.3	0.76	96.4	90.3806	64.9838
2014	9	24	5	1	2	0.3	4.3	0.75	95.5	90.3806	64.1399
2014	9	24	5	11	2	0.3	4.3	0.81	96.8	90.3806	68.6409
2014	9	24	5	21	2	0.3	4.3	0.77	96.4	90.4462	65.3143
2014	9	24	5	31	2	0.3	4.3	0.76	97.2	90.4462	65.0328
2014	9	24	5	41	2	0.3	4.3	0.79	95.5	90.4462	67.285
2014	9	24	5	51	2	0.3	4.3	0.76	97.2	90.5118	64.8
2014	9	24	6	1	2	0.3	4.3	0.76	96.4	90.5118	65.0817
2014	9	24	6	11	2	0.3	4.3	0.78	96.6	90.5118	66.2087
2014	9	24	6	21	2	0.3	4.3	0.76	94.9	90.5774	65.4126
2014	9	24	6	31	2	0.3	4.3	0.76	96	90.6431	64.6153
2014	9	24	6	41	2	0.3	4.3	0.78	94.8	90.5774	66.5405
2014	9	24	6	51	2	0.3	4.3	0.73	97.2	90.6431	62.6402
2014	9	24	7	1	2	0.3	4.3	0.74	95.1	90.6431	63.2045
2014	9	24	7	11	2	0.3	4.3	0.77	97.3	90.6431	65.744
2014	9	24	7	21	2	0.3	4.3	0.78	96.6	90.6431	66.3083
2014	9	24	7	31	2	0.3	4.3	0.76	96.9	90.6431	65.1797
2014	9	24	7	41	2	0.3	4.3	0.79	96.7	90.6431	67.7192

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	7	51	2	0.3	4.3	0.79	94.5	90.6431	67.437
2014	9	24	8	1	2	0.3	4.3	0.79	95.5	90.6431	67.7192
2014	9	24	8	11	2	0.3	4.3	0.78	96.7	90.6431	66.8727
2014	9	24	8	21	2	0.3	4.3	0.79	96.7	90.6431	67.7192
2014	9	24	8	31	2	0.3	4.3	0.79	95.5	90.6431	67.437
2014	9	24	8	41	2	0.3	4.3	0.77	95.1	90.6431	66.0262
2014	9	24	8	51	2	0.3	4.3	0.78	95.1	90.6431	66.5905
2014	9	24	9	1	2	0.3	4.3	0.77	95.9	90.6431	65.4619
2014	9	24	9	11	2	0.3	4.3	0.78	97	90.5774	66.2586
2014	9	24	9	21	2	0.3	4.3	0.79	97.4	90.6431	67.437
2014	9	24	9	31	2	0.3	4.3	0.79	95	90.5774	67.3864
2014	9	24	9	41	2	0.3	4.3	0.78	94.6	90.5774	66.5405
2014	9	24	9	51	2	0.3	4.3	0.78	96.6	90.5118	66.2088
2014	9	24	10	1	2	0.3	4.3	0.78	96.5	90.4462	66.4406
2014	9	24	10	11	2	0.3	4.3	0.79	98.2	90.4462	66.7221
2014	9	24	10	21	2	0.3	4.3	0.8	98.8	90.4462	67.5666
2014	9	24	10	31	2	0.3	4.3	0.8	98.3	90.4462	67.5666
2014	9	24	10	41	2	0.3	4.3	0.79	95.9	90.3806	67.7971
2014	9	24	10	51	2	0.3	4.3	0.78	98.4	90.3806	66.3905
2014	9	24	11	1	2	0.3	4.3	0.8	100.4	90.3806	67.5157
2014	9	24	11	11	2	0.3	4.3	0.83	97.5	90.3806	70.6102
2014	9	24	11	21	2	0.3	4.3	0.8	98.9	90.3806	68.0784
2014	9	24	11	31	2	0.3	4.3	0.78	98	90.3806	66.3904
2014	9	24	11	41	2	0.3	4.3	0.81	98.7	90.3806	68.3596
2014	9	24	11	51	2	0.3	4.3	0.77	98.3	90.3806	65.2651
2014	9	24	12	1	2	0.3	4.3	0.81	98.6	90.315	68.8704
2014	9	24	12	11	2	0.3	4.3	0.77	98.6	90.3806	64.9838
2014	9	24	12	21	2	0.3	4.3	0.79	101	90.315	66.3404
2014	9	24	12	31	2	0.3	4.3	0.78	100.4	90.315	66.0593
2014	9	24	12	41	2	0.3	4.3	0.79	98.4	90.315	66.9026
2014	9	24	12	51	2	0.3	4.3	0.79	101.4	90.315	66.6215
2014	9	24	13	1	2	0.3	4.3	0.82	104.1	90.315	68.027
2014	9	24	13	11	2	0.3	4.3	0.79	97.8	90.315	67.4648
2014	9	24	13	21	2	0.3	4.3	0.8	100.2	90.2494	67.1331
2014	9	24	13	31	2	0.3	4.3	0.78	98.2	90.315	66.3404
2014	9	24	13	41	2	0.3	4.3	0.8	99	90.2494	67.6949
2014	9	24	13	51	2	0.3	4.3	0.81	97.7	90.2494	68.5375
2014	9	24	14	1	2	0.3	4.3	0.8	99.2	90.2494	67.9758
2014	9	24	14	11	2	0.3	4.3	0.77	100.7	90.2494	65.1668
2014	9	24	14	21	2	0.3	4.3	0.77	102.6	90.2494	64.3242
2014	9	24	14	31	2	0.3	4.3	0.77	103.7	90.2494	64.3242
2014	9	24	14	41	2	0.3	4.3	0.78	99.7	90.2494	66.0095
2014	9	24	14	51	2	0.3	4.3	0.8	100.1	90.2494	67.6949
2014	9	24	15	1	2	0.3	4.3	0.8	100.6	90.1837	67.3632
2014	9	24	15	11	2	0.3	4.3	0.79	101.5	90.1837	65.9598
2014	9	24	15	21	2	0.3	4.3	0.81	101.2	90.1837	68.2052

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	15	31	2	0.3	4.3	0.8	101.2	90.1837	66.8019
2014	9	24	15	41	2	0.3	4.3	0.8	98.5	90.1837	67.9246
2014	9	24	15	51	2	0.3	4.3	0.78	98.7	90.1181	65.6296
2014	9	24	16	1	2	0.3	4.3	0.78	99.1	90.1837	66.2405
2014	9	24	16	11	2	0.3	4.3	0.79	100.5	90.1837	66.5212
2014	9	24	16	21	2	0.3	4.3	0.79	100.8	90.1181	65.9101
2014	9	24	16	31	2	0.3	4.3	0.78	100.2	90.1181	65.3492
2014	9	24	16	41	2	0.3	4.3	0.77	100.6	90.1181	64.5078
2014	9	24	16	51	2	0.3	4.3	0.8	100.9	90.1181	67.032
2014	9	24	17	1	2	0.3	4.3	0.78	99.5	90.1181	65.6297
2014	9	24	17	11	2	0.3	4.3	0.81	99.1	90.1181	68.4343
2014	9	24	17	21	2	0.3	4.3	0.78	98	90.1181	65.9101
2014	9	24	17	31	2	0.3	4.3	0.74	96.8	90.1181	63.1054
2014	9	24	17	41	2	0.3	4.3	0.78	98.7	90.1181	65.9101
2014	9	24	17	51	2	0.3	4.3	0.77	100.9	90.0525	64.1789
2014	9	24	18	1	2	0.3	4.3	0.78	99.7	90.1181	65.9101
2014	9	24	18	11	2	0.3	4.3	0.76	97.4	90.1181	64.5078
2014	9	24	18	21	2	0.3	4.3	0.8	98.3	90.1181	67.3125
2014	9	24	18	31	2	0.3	4.3	0.77	96.6	90.1181	65.3492
2014	9	24	18	41	2	0.3	4.3	0.77	97.1	90.1181	65.6297
2014	9	24	18	51	2	0.3	4.3	0.8	99.7	90.1181	67.032
2014	9	24	19	1	2	0.3	4.3	0.76	96.4	90.1181	64.7883
2014	9	24	19	11	2	0.3	4.3	0.78	96.6	90.1181	65.9101
2014	9	24	19	21	2	0.3	4.3	0.78	99.2	90.1181	65.6296
2014	9	24	19	31	2	0.3	4.3	0.78	97.5	90.1181	66.471
2014	9	24	19	41	2	0.3	4.3	0.76	96.2	90.1181	64.5078
2014	9	24	19	51	2	0.3	4.3	0.77	98.1	90.1181	64.7882
2014	9	24	20	1	2	0.3	4.3	0.78	99.7	90.1181	65.9101
2014	9	24	20	11	2	0.3	4.3	0.79	97.6	90.1181	67.3124
2014	9	24	20	21	2	0.3	4.3	0.75	97.1	90.1181	63.3859
2014	9	24	20	31	2	0.3	4.3	0.76	98.2	90.1181	64.5077
2014	9	24	20	41	2	0.3	4.3	0.76	97.9	90.1837	64.5564
2014	9	24	20	51	2	0.3	4.3	0.77	97.1	90.1181	65.0687
2014	9	24	21	1	2	0.3	4.3	0.81	97.7	90.1837	68.4859
2014	9	24	21	11	2	0.3	4.3	0.81	98.9	90.1837	68.4859
2014	9	24	21	21	2	0.3	4.3	0.75	96.6	90.1837	63.4337
2014	9	24	21	31	2	0.3	4.3	0.76	97.2	90.1837	64.8371
2014	9	24	21	41	2	0.3	4.3	0.79	96.9	90.1837	66.8018
2014	9	24	21	51	2	0.3	4.3	0.78	96.5	90.1837	66.2405
2014	9	24	22	1	2	0.3	4.3	0.82	98.6	90.1181	68.9952
2014	9	24	22	11	2	0.3	4.3	0.76	99.4	90.1837	64.2757
2014	9	24	22	21	2	0.3	4.3	0.77	98.9	90.1837	64.837
2014	9	24	22	31	2	0.3	4.3	0.8	97.8	90.1837	67.9245
2014	9	24	22	41	2	0.3	4.3	0.77	98.1	90.1837	64.837
2014	9	24	22	51	2	0.3	4.3	0.79	100.3	90.1837	66.2404
2014	9	24	23	1	2	0.3	4.3	0.75	98.1	90.1837	63.1529

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	23	11	2	0.3	4.3	0.78	98.9	90.1837	66.2404
2014	9	24	23	21	2	0.3	4.3	0.79	100.3	90.1837	66.5211
2014	9	24	23	31	2	0.3	4.3	0.77	98.1	90.1837	65.1177
2014	9	24	23	41	2	0.3	4.3	0.74	99.2	90.1837	62.3109
2014	9	24	23	51	2	0.3	4.3	0.75	101.6	90.1837	62.8723
2014	9	25	0	1	2	0.3	4.3	0.74	95.1	90.1837	63.4336
2014	9	25	0	11	2	0.3	4.3	0.76	99.5	90.1837	63.7143
2014	9	25	0	21	2	0.3	4.3	0.79	101	90.1837	66.2404
2014	9	25	0	31	2	0.3	4.3	0.77	98.4	90.1837	64.837
2014	9	25	0	41	2	0.3	4.3	0.76	99.7	90.2494	63.7624
2014	9	25	0	51	2	0.3	4.3	0.74	102.5	90.2494	62.077
2014	9	25	1	1	2	0.3	4.3	0.71	98.8	90.1837	60.0655
2014	9	25	1	11	2	0.3	4.3	0.79	96.5	90.1837	66.8018
2014	9	25	1	21	2	0.3	4.3	0.8	99	90.1837	67.3632
2014	9	25	1	31	2	0.3	4.3	0.76	97.7	90.1837	64.2757
2014	9	25	1	41	2	0.3	4.3	0.74	95.1	90.1837	63.153
2014	9	25	1	51	2	0.3	4.3	0.75	99.5	90.1837	63.4337
2014	9	25	2	1	2	0.3	4.3	0.73	101.7	90.1837	61.1882
2014	9	25	2	11	2	0.3	4.3	0.71	103	90.1837	59.5042
2014	9	25	2	21	2	0.3	4.3	0.73	104	90.2494	60.9535
2014	9	25	2	31	2	0.3	4.3	0.71	99.1	90.2494	59.83
2014	9	25	2	41	2	0.3	4.3	0.75	97.8	90.1837	63.7144
2014	9	25	2	51	2	0.3	4.3	0.75	97.3	90.1837	63.7144
2014	9	25	3	1	2	0.3	4.3	0.73	100.4	90.1837	61.1883
2014	9	25	3	11	2	0.3	4.3	0.73	99.8	90.1837	61.7496
2014	9	25	3	21	2	0.3	4.3	0.75	98.6	90.1837	63.4337
2014	9	25	3	31	2	0.3	4.3	0.73	102.2	90.1837	61.1883
2014	9	25	3	41	2	0.3	4.3	0.76	98.2	90.1837	63.9951
2014	9	25	3	51	2	0.3	4.3	0.75	99.6	90.1837	62.8724
2014	9	25	4	1	2	0.3	4.3	0.73	99	90.1837	62.0303
2014	9	25	4	11	2	0.3	4.3	0.75	97.8	90.1837	63.4337
2014	9	25	4	21	2	0.3	4.3	0.77	96.9	90.1837	65.1178
2014	9	25	4	31	2	0.3	4.3	0.74	98.4	90.1837	62.5917
2014	9	25	4	41	2	0.3	4.3	0.75	98.6	90.1837	63.4338
2014	9	25	4	51	2	0.3	4.3	0.77	100.1	90.1837	64.8372
2014	9	25	5	1	2	0.3	4.3	0.74	101.2	90.1837	62.3111
2014	9	25	5	11	2	0.3	4.3	0.74	98.9	90.1837	62.5917
2014	9	25	5	21	2	0.3	4.3	0.75	97.8	90.2494	63.7625
2014	9	25	5	31	2	0.3	4.3	0.78	98.7	90.2494	65.7288
2014	9	25	5	41	2	0.3	4.3	0.78	97	90.2494	66.5715
2014	9	25	5	51	2	0.3	4.3	0.8	101.3	90.2494	67.4141
2014	9	25	6	1	2	0.3	4.3	0.76	97.2	90.1837	64.8372
2014	9	25	6	11	2	0.3	4.3	0.79	98.1	90.2494	67.1333
2014	9	25	6	21	2	0.3	4.3	0.76	97.6	90.2494	64.8861
2014	9	25	6	31	2	0.3	4.3	0.78	96.8	90.2494	66.0097
2014	9	25	6	41	2	0.3	4.3	0.78	97	90.2494	66.0097

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	6	51	2	0.3	4.3	0.78	96.6	90.2494	66.0097
2014	9	25	7	1	2	0.3	4.3	0.79	97.9	90.2494	67.1333
2014	9	25	7	11	2	0.3	4.3	0.78	94.6	90.2494	66.2906
2014	9	25	7	21	2	0.3	4.3	0.78	97.8	90.2494	66.0097
2014	9	25	7	31	2	0.3	4.3	0.76	97.6	90.2494	64.8862
2014	9	25	7	41	2	0.3	4.3	0.78	99.9	90.2494	66.0097
2014	9	25	7	51	2	0.3	4.3	0.76	95.4	90.2494	64.8862
2014	9	25	8	1	2	0.3	4.3	0.77	95.9	90.2494	65.167
2014	9	25	8	11	2	0.3	4.3	0.79	97.1	90.2494	67.4142
2014	9	25	8	21	2	0.3	4.3	0.77	96.6	90.315	65.4973
2014	9	25	8	31	2	0.3	4.3	0.76	96.2	90.2494	64.8861
2014	9	25	8	41	2	0.3	4.3	0.78	97.2	90.1837	66.2406
2014	9	25	8	51	2	0.3	4.3	0.73	97.2	90.1181	62.2641
2014	9	25	9	1	2	0.3	4.3	0.79	94.5	90.2494	67.1333
2014	9	25	9	11	2	0.3	4.3	0.75	95.5	90.0525	63.8986
2014	9	25	9	21	2	0.3	4.3	0.77	95.6	90.2494	65.7288
2014	9	25	9	31	2	0.3	4.3	0.75	97.8	90.1837	63.7145
2014	9	25	9	41	2	0.3	4.3	0.74	96.9	90.0525	62.4973
2014	9	25	9	51	2	0.3	4.3	0.73	93.4	90.0525	61.9368
2014	9	25	10	1	2	0.3	4.3	0.74	95.6	90.0525	63.0578
2014	9	25	10	11	2	0.3	4.3	0.75	96.3	90.0525	63.3381
2014	9	25	10	21	2	0.3	4.3	0.76	94.7	90.0525	65.0196
2014	9	25	10	31	2	0.3	4.3	0.72	96.3	89.9869	61.0498
2014	9	25	10	41	2	0.3	4.3	0.75	95.5	90.1837	63.9951
2014	9	25	10	51	2	0.3	4.3	0.75	94.8	90.1181	63.6664
2014	9	25	11	1	2	0.3	4.3	0.77	98.1	89.9869	64.6904
2014	9	25	11	11	2	0.3	4.3	0.74	96.1	90.1181	62.5445
2014	9	25	11	21	2	0.3	4.3	0.74	95.6	89.9869	63.0101
2014	9	25	11	31	2	0.3	4.3	0.75	98.3	90.0525	63.338
2014	9	25	11	41	2	0.3	4.3	0.78	96.5	89.9869	66.0906
2014	9	25	11	51	2	0.3	4.3	0.73	93.8	89.9869	62.45
2014	9	25	12	1	2	0.3	4.3	0.8	97.6	89.9869	67.4908
2014	9	25	12	11	2	0.3	4.3	0.76	97.2	89.9213	64.6414
2014	9	25	12	21	2	0.3	4.3	0.8	96.2	90.1181	67.5928
2014	9	25	12	31	2	0.3	4.3	0.74	96.1	90.0525	62.7774
2014	9	25	12	41	2	0.3	4.3	0.76	97.2	89.9869	64.6903
2014	9	25	12	51	2	0.3	4.3	0.75	94.8	90.0525	63.8984
2014	9	25	13	1	2	0.3	4.3	0.79	96	89.9869	66.6506
2014	9	25	13	11	2	0.3	4.3	0.78	95.3	89.9869	66.6506
2014	9	25	13	21	2	0.3	4.3	0.77	96.2	89.9869	64.9703
2014	9	25	13	31	2	0.3	4.3	0.77	96.8	89.8556	65.4313
2014	9	25	13	41	2	0.3	4.3	0.78	98.5	89.9869	65.8104
2014	9	25	13	51	2	0.3	4.3	0.74	93.1	89.9213	62.9623
2014	9	25	14	1	2	0.3	4.3	0.77	95.9	89.9213	64.9211
2014	9	25	14	11	2	0.3	4.3	0.74	97.1	89.8556	62.635
2014	9	25	14	21	2	0.3	4.3	0.75	97.1	89.9213	63.2421

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	14	31	2	0.3	4.3	0.77	94.2	89.7244	65.053
2014	9	25	14	41	2	0.3	4.3	0.75	95.5	89.9213	63.522
2014	9	25	14	51	2	0.3	4.3	0.74	99.7	89.7244	61.9818
2014	9	25	15	1	2	0.3	4.3	0.71	100.9	89.7244	59.1898
2014	9	25	15	11	2	0.3	4.3	0.76	103	89.8556	63.1943
2014	9	25	15	21	2	0.3	4.3	0.74	98.2	89.8556	62.0758
2014	9	25	15	31	2	0.3	4.3	0.78	97	89.79	65.9405
2014	9	25	15	41	2	0.3	4.3	0.77	97.5	89.8556	65.4313
2014	9	25	15	51	2	0.3	4.3	0.75	95	89.7244	63.9362
2014	9	25	16	1	2	0.3	4.3	0.76	95.9	89.7244	64.4946
2014	9	25	16	11	2	0.3	4.3	0.77	98.3	89.8556	64.872
2014	9	25	16	21	2	0.3	4.3	0.76	98.2	89.7244	64.2154
2014	9	25	16	31	2	0.3	4.3	0.75	99.6	89.6588	62.4928
2014	9	25	16	41	2	0.3	4.3	0.77	98.6	89.6588	64.7247
2014	9	25	16	51	2	0.3	4.3	0.75	97.3	89.7244	63.3778
2014	9	25	17	1	2	0.3	4.3	0.77	98.9	89.6588	64.4457
2014	9	25	17	11	2	0.3	4.3	0.78	99.5	89.7244	65.053
2014	9	25	17	21	2	0.3	4.3	0.78	97.2	89.7244	65.8906
2014	9	25	17	31	2	0.3	4.3	0.74	95.6	89.6588	62.2138
2014	9	25	17	41	2	0.3	4.3	0.74	96.7	89.79	62.3083
2014	9	25	17	51	2	0.3	4.3	0.75	95	89.7244	63.3778
2014	9	25	18	1	2	0.3	4.3	0.77	97.9	89.6588	64.7247
2014	9	25	18	11	2	0.3	4.3	0.78	97.7	89.7244	65.8906
2014	9	25	18	21	2	0.3	4.3	0.75	96	89.7244	63.657
2014	9	25	18	31	2	0.3	4.3	0.74	95.6	89.7244	62.8194
2014	9	25	18	41	2	0.3	4.3	0.75	98	89.79	63.4259
2014	9	25	18	51	2	0.3	4.3	0.74	95.6	89.7244	62.261
2014	9	25	19	1	2	0.3	4.3	0.75	95	89.7244	63.9362
2014	9	25	19	11	2	0.3	4.3	0.75	94.8	89.6588	63.6087
2014	9	25	19	21	2	0.3	4.3	0.78	95.6	89.7244	65.8906
2014	9	25	19	31	2	0.3	4.3	0.72	95.2	89.7244	61.1442
2014	9	25	19	41	2	0.3	4.3	0.74	93.8	89.6588	62.7718
2014	9	25	19	51	2	0.3	4.3	0.73	95.1	89.7244	62.261
2014	9	25	20	1	2	0.3	3.9	0.76	96	89.5932	63.8392
2014	9	25	20	11	2	0.3	4.3	0.76	98.9	89.7244	63.9362
2014	9	25	20	21	2	0.3	4.3	0.74	95.3	89.6588	63.0507
2014	9	25	20	31	2	0.3	4.3	0.75	95	89.7244	63.3777
2014	9	25	20	41	2	0.3	4.3	0.77	94.2	89.7244	65.0529
2014	9	25	20	51	2	0.3	4.3	0.75	94.5	89.7244	63.3777
2014	9	25	21	1	2	0.3	4.3	0.77	94.6	89.8556	65.7108
2014	9	25	21	11	2	0.3	4.3	0.74	95.9	89.7244	62.5401
2014	9	25	21	21	2	0.3	4.3	0.77	95.3	89.7244	65.6113
2014	9	25	21	31	2	0.3	4.3	0.75	94	89.6588	63.6086
2014	9	25	21	41	2	0.3	4.3	0.76	96.4	89.7244	64.4945
2014	9	25	21	51	2	0.3	4.3	0.76	95.9	89.79	64.5434
2014	9	25	22	1	2	0.3	4.3	0.78	95.3	89.7244	66.4489

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	22	11	2	0.3	4.3	0.76	98	89.79	63.7052
2014	9	25	22	21	2	0.3	4.3	0.75	97.2	89.8556	63.7534
2014	9	25	22	31	2	0.3	4.3	0.76	97.9	89.79	64.264
2014	9	25	22	41	2	0.3	4.3	0.75	94.5	89.79	63.9846
2014	9	25	22	51	2	0.3	4.3	0.75	97.5	89.79	63.7052
2014	9	25	23	1	2	0.3	4.3	0.73	97	89.79	61.4699
2014	9	25	23	11	2	0.3	4.3	0.74	96.7	89.79	62.3081
2014	9	25	23	21	2	0.3	4.3	0.8	95.7	89.8556	67.6681
2014	9	25	23	31	2	0.3	4.3	0.77	96.3	89.7244	65.332
2014	9	25	23	41	2	0.3	4.3	0.75	96.6	89.79	63.1463
2014	9	25	23	51	2	0.3	4.3	0.79	96.5	89.7244	66.4488
2014	9	26	0	1	2	0.3	4.3	0.75	97.8	89.79	63.4257
2014	9	26	0	11	2	0.3	4.3	0.75	95	89.79	63.7051
2014	9	26	0	21	2	0.3	4.3	0.75	95.3	89.8556	63.7534
2014	9	26	0	31	2	0.3	4.3	0.77	95.3	89.7244	65.6112
2014	9	26	0	41	2	0.3	4.3	0.75	99.1	89.6588	63.0506
2014	9	26	0	51	2	0.3	4.3	0.72	97.6	89.79	60.9111
2014	9	26	1	1	2	0.3	4.3	0.77	96.9	89.7244	64.7737
2014	9	26	1	11	2	0.3	4.3	0.77	96.8	89.79	65.3816
2014	9	26	1	21	2	0.3	4.3	0.75	96.1	89.79	63.1464
2014	9	26	1	31	2	0.3	4.3	0.76	95.7	89.79	64.5434
2014	9	26	1	41	2	0.3	4.3	0.74	96.7	89.8556	62.3553
2014	9	26	1	51	2	0.3	4.3	0.75	94.5	89.79	63.7052
2014	9	26	2	1	2	0.3	4.3	0.74	96.1	89.8556	62.9146
2014	9	26	2	11	2	0.3	4.3	0.75	96	89.79	63.7052
2014	9	26	2	21	2	0.3	4.3	0.75	96.1	89.9213	63.2421
2014	9	26	2	31	2	0.3	4.3	0.75	96.3	89.79	63.4258
2014	9	26	2	41	2	0.3	4.3	0.8	96.9	89.8556	67.3885
2014	9	26	2	51	2	0.3	4.3	0.78	96.1	89.9213	65.7606
2014	9	26	3	1	2	0.3	4.3	0.76	98.2	89.8556	64.0331
2014	9	26	3	11	2	0.3	4.3	0.77	95.3	89.8556	65.7108
2014	9	26	3	21	2	0.3	4.3	0.76	95.7	89.9213	64.0816
2014	9	26	3	31	2	0.3	4.3	0.77	97.8	89.8556	65.1516
2014	9	26	3	41	2	0.3	4.3	0.79	95.9	89.8556	67.109
2014	9	26	3	51	2	0.3	4.3	0.77	97.1	89.9213	64.9211
2014	9	26	4	1	2	0.3	4.3	0.75	95	89.9213	63.8018
2014	9	26	4	11	2	0.3	4.3	0.75	96.3	89.9213	63.8018
2014	9	26	4	21	2	0.3	4.3	0.75	96.8	89.9213	63.8018
2014	9	26	4	31	2	0.3	4.3	0.77	96.1	89.9213	65.201
2014	9	26	4	41	2	0.3	4.3	0.75	98.5	89.9213	63.522
2014	9	26	4	51	2	0.3	4.3	0.77	97.1	89.8556	65.4313
2014	9	26	5	1	2	0.3	4.3	0.8	97.3	89.9213	67.4397
2014	9	26	5	11	2	0.3	4.3	0.79	96.5	89.8556	66.5498
2014	9	26	5	21	2	0.3	4.3	0.76	97.6	89.9213	64.6413
2014	9	26	5	31	2	0.3	4.3	0.76	96.7	89.8556	64.3128
2014	9	26	5	41	2	0.3	4.3	0.76	95.2	89.9213	64.6413

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	5	51	2	0.3	4.3	0.78	95.8	89.8556	66.2702
2014	9	26	6	1	2	0.3	4.3	0.77	97.1	89.8556	64.8721
2014	9	26	6	11	2	0.3	4.3	0.78	97.7	89.9213	66.0405
2014	9	26	6	21	2	0.3	4.3	0.77	95.4	89.9213	65.201
2014	9	26	6	31	2	0.3	4.3	0.77	95.9	89.8556	65.4313
2014	9	26	6	41	2	0.3	4.3	0.73	96.7	89.8556	62.0759
2014	9	26	6	51	2	0.3	4.3	0.75	95	89.8556	63.474
2014	9	26	7	1	2	0.3	4.3	0.77	97.4	89.8556	64.8721
2014	9	26	7	11	2	0.3	4.3	0.73	93.6	89.9213	62.1229
2014	9	26	7	21	2	0.3	4.3	0.78	97	89.8556	65.9906
2014	9	26	7	31	2	0.3	4.3	0.77	96.9	89.9213	64.9212
2014	9	26	7	41	2	0.3	4.3	0.76	95.5	89.9213	64.3616
2014	9	26	7	51	2	0.3	4.3	0.75	95.5	89.8556	63.7536
2014	9	26	8	1	2	0.3	4.3	0.76	95.9	89.8556	64.5925
2014	9	26	8	11	2	0.3	4.3	0.76	93.7	89.8556	64.3129
2014	9	26	8	21	2	0.3	4.3	0.76	96.4	89.8556	64.5925
2014	9	26	8	31	2	0.3	4.3	0.76	98.7	89.8556	64.3129
2014	9	26	8	41	2	0.3	4.3	0.77	97.1	89.79	65.3818
2014	9	26	8	51	2	0.3	4.3	0.76	95.7	89.8556	64.5925
2014	9	26	9	1	2	0.3	4.3	0.75	97.8	89.8556	63.1943
2014	9	26	9	11	2	0.3	4.3	0.74	98.7	89.9213	62.1229
2014	9	26	9	21	2	0.3	4.3	0.73	95.7	89.8556	61.5166
2014	9	26	9	31	2	0.3	4.3	0.81	96.8	89.7244	68.1242
2014	9	26	9	41	2	0.3	4.3	0.73	97.8	89.79	61.47
2014	9	26	9	51	2	0.3	4.3	0.75	96.8	89.79	63.7053
2014	9	26	10	1	2	0.3	4.3	0.75	96	89.7244	63.3778
2014	9	26	10	11	2	0.3	4.3	0.76	94.2	89.7244	64.2154
2014	9	26	10	21	2	0.3	4.3	0.76	99.2	89.7244	63.657
2014	9	26	10	31	2	0.3	4.3	0.76	99.7	89.6588	63.6087
2014	9	26	10	41	2	0.3	3.9	0.77	97.1	89.5932	64.6755
2014	9	26	10	51	2	0.3	3.9	0.79	97.8	89.5932	66.9057
2014	9	26	11	1	2	0.3	3.9	0.74	95.6	89.5276	62.6764
2014	9	26	11	11	2	0.3	4.3	0.72	96.3	89.6588	61.0978
2014	9	26	11	21	2	0.3	3.9	0.74	95.3	89.5276	62.955
2014	9	26	11	31	2	0.3	4.3	0.76	95	89.6588	64.1666
2014	9	26	11	41	2	0.3	3.9	0.75	95	89.5276	63.5121
2014	9	26	11	51	2	0.3	3.9	0.75	96	89.5276	63.5121
2014	9	26	12	1	2	0.3	3.9	0.72	98.9	89.5276	60.7265
2014	9	26	12	11	2	0.3	3.9	0.74	97.4	89.462	62.3504
2014	9	26	12	21	2	0.3	3.9	0.76	95.5	89.462	64.0205
2014	9	26	12	31	2	0.3	3.9	0.75	93.8	89.462	63.4638
2014	9	26	12	41	2	0.3	3.9	0.73	97	89.462	61.237
2014	9	26	12	51	2	0.3	3.9	0.75	96.3	89.5932	63.2816
2014	9	26	13	1	2	0.3	3.9	0.75	95.8	89.462	63.4639
2014	9	26	13	11	2	0.3	3.9	0.72	96.8	89.3963	60.9123
2014	9	26	13	21	2	0.3	3.9	0.74	96.1	89.3307	61.9777

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	13	31	2	0.3	3.9	0.75	95	89.462	63.4639
2014	9	26	13	41	2	0.3	3.9	0.75	96.1	89.3963	62.8593
2014	9	26	13	51	2	0.3	3.9	0.74	96.1	89.3307	62.2556
2014	9	26	14	1	2	0.3	3.9	0.72	95.5	89.2651	60.8196
2014	9	26	14	11	2	0.3	3.9	0.76	98	89.3307	63.3673
2014	9	26	14	21	2	0.3	3.9	0.72	94.9	89.3307	61.1439
2014	9	26	14	31	2	0.3	3.9	0.74	96.3	89.3307	62.5335
2014	9	26	14	41	2	0.3	3.9	0.72	93.7	89.3307	60.5881
2014	9	26	14	51	2	0.3	3.9	0.72	95	89.2651	60.5419
2014	9	26	15	1	2	0.3	3.9	0.72	94.2	89.1995	60.4958
2014	9	26	15	11	2	0.3	3.9	0.76	95	89.2651	63.8745
2014	9	26	15	21	2	0.3	3.9	0.75	94.5	89.1995	63.5483
2014	9	26	15	31	2	0.3	3.9	0.71	94.2	89.1339	59.8951
2014	9	26	15	41	2	0.3	3.9	0.73	95.4	89.1339	61.8361
2014	9	26	15	51	2	0.3	3.9	0.75	94.5	89.1339	62.9453
2014	9	26	16	1	2	0.3	3.9	0.71	94	89.1995	59.6633
2014	9	26	16	11	2	0.3	3.9	0.77	94.1	89.0683	65.1139
2014	9	26	16	21	2	0.3	3.9	0.74	96.1	89.0683	61.7889
2014	9	26	16	31	2	0.3	3.9	0.73	95.9	89.2651	61.6529
2014	9	26	16	41	2	0.3	3.9	0.75	97	89.1339	62.9453
2014	9	26	16	51	2	0.3	3.9	0.73	94.9	89.1339	61.8362
2014	9	26	17	1	2	0.3	3.9	0.74	95.1	89.1339	62.1135
2014	9	26	17	11	2	0.3	3.9	0.71	94.5	89.0026	60.0806
2014	9	26	17	21	2	0.3	3.9	0.73	94.4	89.1339	61.5589
2014	9	26	17	31	2	0.3	3.9	0.74	96.1	89.0026	61.7418
2014	9	26	17	41	2	0.3	3.9	0.71	96.9	89.0026	59.8037
2014	9	26	17	51	2	0.3	3.9	0.74	97.6	89.0026	62.2955
2014	9	26	18	1	2	0.3	3.9	0.77	95.9	89.0026	64.2336
2014	9	26	18	11	2	0.3	3.9	0.76	95.7	88.937	63.3545
2014	9	26	18	21	2	0.3	3.9	0.74	95.6	89.1339	61.8362
2014	9	26	18	31	2	0.3	3.9	0.75	94.8	89.0683	63.1744
2014	9	26	18	41	2	0.3	3.9	0.74	93.6	89.0026	62.0187
2014	9	26	18	51	2	0.3	3.9	0.71	95.6	88.937	59.758
2014	9	26	19	1	2	0.3	3.9	0.73	93.4	89.0683	61.512
2014	9	26	19	11	2	0.3	3.9	0.76	96	89.0026	63.403
2014	9	26	19	21	2	0.3	3.9	0.73	93.4	89.0683	61.2349
2014	9	26	19	31	2	0.3	3.9	0.72	95.2	89.0683	60.4036
2014	9	26	19	41	2	0.3	3.9	0.73	94.6	89.0026	61.465
2014	9	26	19	51	2	0.3	3.9	0.75	94	88.937	63.3546
2014	9	26	20	1	2	0.3	3.9	0.74	96.3	89.0026	62.2956
2014	9	26	20	11	2	0.3	3.9	0.74	95.4	89.0026	62.0187
2014	9	26	20	21	2	0.3	3.9	0.73	95.1	88.937	61.418
2014	9	26	20	31	2	0.3	3.9	0.73	95.7	89.0026	60.9112
2014	9	26	20	41	2	0.3	3.9	0.72	96.8	89.0683	60.1266
2014	9	26	20	51	2	0.3	3.9	0.73	95.9	89.0683	61.512
2014	9	26	21	1	2	0.3	3.9	0.74	94	88.8058	62.4289

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	21	11	2	0.3	3.9	0.73	94.6	88.937	61.418
2014	9	26	21	21	2	0.3	3.9	0.75	97.2	89.0026	63.1262
2014	9	26	21	31	2	0.3	3.9	0.76	94.2	89.0026	63.6799
2014	9	26	21	41	2	0.3	3.9	0.72	95.2	89.0683	60.9578
2014	9	26	21	51	2	0.3	3.9	0.74	94.6	88.937	61.9713
2014	9	26	22	1	2	0.3	3.9	0.73	95.1	89.0026	61.7419
2014	9	26	22	11	2	0.3	3.9	0.72	96.3	88.937	60.3114
2014	9	26	22	21	2	0.3	3.9	0.74	98.9	89.0026	61.7419
2014	9	26	22	31	2	0.3	3.9	0.79	98.6	89.0026	65.618
2014	9	26	22	41	2	0.3	3.9	0.74	97.1	88.8714	61.9239
2014	9	26	22	51	2	0.3	3.9	0.75	97.1	88.8714	62.4768
2014	9	26	23	1	2	0.3	3.9	0.74	99.5	88.937	61.418
2014	9	26	23	11	2	0.3	3.9	0.76	98	88.937	63.0779
2014	9	26	23	21	2	0.3	3.9	0.77	98.6	88.937	63.9079
2014	9	26	23	31	2	0.3	3.9	0.76	98.2	88.8714	63.3061
2014	9	26	23	41	2	0.3	3.9	0.74	95.6	88.8714	61.6475
2014	9	26	23	51	2	0.3	3.9	0.75	98.6	88.937	62.5246
2014	9	27	0	1	2	0.3	3.9	0.74	97.4	88.937	61.9713
2014	9	27	0	11	2	0.3	3.9	0.75	95.2	88.937	63.3546
2014	9	27	0	21	2	0.3	3.9	0.76	98.2	88.937	63.078
2014	9	27	0	31	2	0.3	3.9	0.75	99.3	88.8714	62.4768
2014	9	27	0	41	2	0.3	3.9	0.77	97.1	88.8714	64.1355
2014	9	27	0	51	2	0.3	3.9	0.77	96.6	88.8714	64.412
2014	9	27	1	1	2	0.3	3.9	0.76	98	88.8714	63.0297
2014	9	27	1	11	2	0.3	3.9	0.73	99	88.8714	60.8182
2014	9	27	1	21	2	0.3	3.9	0.74	96.4	88.937	61.6947
2014	9	27	1	31	2	0.3	3.9	0.76	95.2	88.8714	64.1356
2014	9	27	1	41	2	0.3	3.9	0.74	94.8	88.8714	62.4769
2014	9	27	1	51	2	0.3	3.9	0.77	95.9	88.8714	64.412
2014	9	27	2	1	2	0.3	3.9	0.73	96.2	88.8714	61.0947
2014	9	27	2	11	2	0.3	3.9	0.74	95.9	88.8714	61.924
2014	9	27	2	21	2	0.3	3.9	0.77	97.9	88.8714	63.8592
2014	9	27	2	31	2	0.3	3.9	0.74	97.4	88.8714	61.924
2014	9	27	2	41	2	0.3	3.9	0.72	97.6	88.8058	60.2192
2014	9	27	2	51	2	0.3	3.9	0.74	96.1	88.8714	61.9241
2014	9	27	3	1	2	0.3	3.9	0.75	96	88.8058	62.7054
2014	9	27	3	11	2	0.3	3.9	0.74	96.9	88.8058	61.6004
2014	9	27	3	21	2	0.3	3.9	0.71	95.3	88.8058	59.1143
2014	9	27	3	31	2	0.3	3.9	0.78	97	88.8058	64.9153
2014	9	27	3	41	2	0.3	3.9	0.76	98.2	88.8058	62.9817
2014	9	27	3	51	2	0.3	3.9	0.76	96	88.8058	63.2579
2014	9	27	4	1	2	0.3	3.9	0.73	97.7	88.8058	61.048
2014	9	27	4	11	2	0.3	3.9	0.75	97.2	88.8058	62.9817
2014	9	27	4	21	2	0.3	3.9	0.73	97.5	88.8058	60.7718
2014	9	27	4	31	2	0.3	3.9	0.76	96.5	88.8058	63.258
2014	9	27	4	41	2	0.3	3.9	0.74	96.1	88.8058	62.153

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	4	51	2	0.3	3.9	0.76	96	88.8058	63.5342
2014	9	27	5	1	2	0.3	3.9	0.76	97.7	88.8714	63.5829
2014	9	27	5	11	2	0.3	3.9	0.76	96.5	88.8058	63.258
2014	9	27	5	21	2	0.3	3.9	0.77	94.4	88.8714	64.6888
2014	9	27	5	31	2	0.3	3.9	0.74	96.1	88.8058	62.1531
2014	9	27	5	41	2	0.3	3.9	0.74	94.3	88.8058	62.4294
2014	9	27	5	51	2	0.3	3.9	0.74	96.9	88.8058	61.6007
2014	9	27	6	1	2	0.3	3.9	0.78	96	88.8058	65.1917
2014	9	27	6	11	2	0.3	3.9	0.74	95.8	88.8714	62.2008
2014	9	27	6	21	2	0.3	3.9	0.74	95.6	88.8058	61.6007
2014	9	27	6	31	2	0.3	3.9	0.77	95.6	88.8058	64.6393
2014	9	27	6	41	2	0.3	3.9	0.73	95.7	88.8058	61.0483
2014	9	27	6	51	2	0.3	3.9	0.75	97.3	88.8058	62.7057
2014	9	27	7	1	2	0.3	3.9	0.77	94.7	88.8058	64.3631
2014	9	27	7	11	2	0.3	3.9	0.75	94.7	88.8058	63.2582
2014	9	27	7	21	2	0.3	3.9	0.75	95.2	88.8714	63.3067
2014	9	27	7	31	2	0.3	3.9	0.72	92.9	88.8058	60.7721
2014	9	27	7	41	2	0.3	3.9	0.73	94.4	88.8058	61.6008
2014	9	27	7	51	2	0.3	3.9	0.75	97	88.8058	62.982
2014	9	27	8	1	2	0.3	3.9	0.75	96	88.8058	62.7058
2014	9	27	8	11	2	0.3	3.9	0.75	96.1	88.8058	62.4295
2014	9	27	8	21	2	0.3	3.9	0.74	97.4	88.8058	61.8771
2014	9	27	8	31	2	0.3	3.9	0.74	97.6	88.8058	61.8771
2014	9	27	8	41	2	0.3	3.9	0.75	96.8	88.7402	62.3817
2014	9	27	8	51	2	0.3	3.9	0.77	96.9	88.7402	64.0379
2014	9	27	9	1	2	0.3	3.9	0.77	95.9	88.7402	64.3139
2014	9	27	9	11	2	0.3	3.9	0.75	95.5	88.7402	63.2098
2014	9	27	9	21	2	0.3	3.9	0.75	97	88.6745	62.8855
2014	9	27	9	31	2	0.3	3.9	0.76	95.9	88.6745	63.7129
2014	9	27	9	41	2	0.3	3.9	0.73	94.6	88.6745	61.2306
2014	9	27	9	51	2	0.3	3.9	0.76	97.5	88.6745	63.1613
2014	9	27	10	1	2	0.3	3.9	0.73	94.9	88.6745	61.5064
2014	9	27	10	11	2	0.3	3.9	0.76	97.5	88.6745	63.1613
2014	9	27	10	21	2	0.3	3.9	0.72	97	88.6745	60.4031
2014	9	27	10	31	2	0.3	3.9	0.74	95.6	88.6089	62.286
2014	9	27	10	41	2	0.3	3.9	0.75	97.3	88.6089	62.5616
2014	9	27	10	51	2	0.3	3.9	0.74	97.4	88.6089	61.7348
2014	9	27	11	1	2	0.3	3.9	0.75	95.8	88.5433	62.5135
2014	9	27	11	11	2	0.3	3.9	0.76	97.2	88.5433	63.3397
2014	9	27	11	21	2	0.3	3.9	0.75	96.3	88.5433	62.2381
2014	9	27	11	31	2	0.3	3.9	0.78	98	88.5433	64.992
2014	9	27	11	41	2	0.3	3.9	0.76	96.9	88.5433	63.3397
2014	9	27	11	51	2	0.3	3.9	0.76	97.2	88.5433	63.3397
2014	9	27	12	1	2	0.3	3.9	0.74	95.8	88.4777	61.9151
2014	9	27	12	11	2	0.3	3.9	0.72	96.3	88.4777	59.9888
2014	9	27	12	21	2	0.3	3.9	0.74	95.8	88.4777	61.9151

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	12	31	2	0.3	3.9	0.77	95.1	88.4121	64.3421
2014	9	27	12	41	2	0.3	3.9	0.74	95.6	88.4121	62.1424
2014	9	27	12	51	2	0.3	3.9	0.73	98.3	88.4777	60.5392
2014	9	27	13	1	2	0.3	3.9	0.71	95.8	88.3465	59.347
2014	9	27	13	11	2	0.3	3.9	0.74	95.1	88.3465	62.0946
2014	9	27	13	21	2	0.3	3.9	0.74	97.4	88.2808	61.4977
2014	9	27	13	31	2	0.3	3.9	0.74	96.1	88.3465	61.5451
2014	9	27	13	41	2	0.3	3.9	0.74	95.8	88.2808	61.7722
2014	9	27	13	51	2	0.3	3.9	0.71	93.4	88.2808	59.5759
2014	9	27	14	1	2	0.3	3.9	0.75	95	88.2808	62.5959
2014	9	27	14	11	2	0.3	3.9	0.74	96.6	88.2808	61.4977
2014	9	27	14	21	2	0.3	3.9	0.73	95.2	88.2152	60.6273
2014	9	27	14	31	2	0.3	3.9	0.74	96.4	88.2152	61.176
2014	9	27	14	41	2	0.3	3.9	0.77	95.4	88.2152	64.1937
2014	9	27	14	51	2	0.3	3.9	0.72	97.5	88.2808	60.1251
2014	9	27	15	1	2	0.3	3.9	0.74	97.4	88.2152	61.4504
2014	9	27	15	11	2	0.3	3.9	0.72	97.5	88.2152	60.0788
2014	9	27	15	21	2	0.3	3.9	0.73	96.2	88.1496	60.8548
2014	9	27	15	31	2	0.3	3.9	0.74	97.6	88.2152	61.4505
2014	9	27	15	41	2	0.3	3.9	0.69	93.8	88.1496	57.5654
2014	9	27	15	51	2	0.3	3.9	0.74	97.1	88.1496	61.4031
2014	9	27	16	1	2	0.3	3.9	0.75	96	88.1496	62.4996
2014	9	27	16	11	2	0.3	3.9	0.75	95.5	88.084	62.7252
2014	9	27	16	21	2	0.3	3.9	0.74	96.1	88.1496	61.4031
2014	9	27	16	31	2	0.3	3.9	0.74	96.7	88.084	61.0818
2014	9	27	16	41	2	0.3	3.9	0.73	95.9	88.084	60.8079
2014	9	27	16	51	2	0.3	3.9	0.75	96	88.1496	62.4996
2014	9	27	17	1	2	0.3	3.9	0.76	96	88.084	62.7253
2014	9	27	17	11	2	0.3	3.9	0.72	96.3	88.084	59.7123
2014	9	27	17	21	2	0.3	3.9	0.75	97.5	88.084	62.1775
2014	9	27	17	31	2	0.3	3.9	0.75	96	88.084	62.4514
2014	9	27	17	41	2	0.3	3.9	0.73	96.2	88.0184	60.4873
2014	9	27	17	51	2	0.3	3.9	0.73	95.9	88.0184	60.761
2014	9	27	18	1	2	0.3	3.9	0.76	96	88.0184	62.9505
2014	9	27	18	11	2	0.3	3.9	0.76	96	88.0184	62.6768
2014	9	27	18	21	2	0.3	3.9	0.73	98.2	88.0184	60.4873
2014	9	27	18	31	2	0.3	3.9	0.72	98.1	88.0184	59.3925
2014	9	27	18	41	2	0.3	3.9	0.71	96.6	87.9528	59.0731
2014	9	27	18	51	2	0.3	3.9	0.72	97.6	87.9528	59.62
2014	9	27	19	1	2	0.3	3.9	0.74	95.9	87.9528	60.9875
2014	9	27	19	11	2	0.3	3.9	0.74	96.1	87.8871	61.4868
2014	9	27	19	21	2	0.3	3.9	0.74	97.1	87.9528	61.5344
2014	9	27	19	31	2	0.3	3.9	0.73	95.2	87.8871	60.3937
2014	9	27	19	41	2	0.3	3.9	0.76	96.9	87.9528	62.9019
2014	9	27	19	51	2	0.3	3.9	0.77	97.6	87.8871	63.673
2014	9	27	20	1	2	0.3	3.9	0.77	96.6	87.9528	63.9958

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	20	11	2	0.3	3.9	0.71	95.6	87.8871	58.7541
2014	9	27	20	21	2	0.3	3.9	0.74	95.6	87.8871	61.2136
2014	9	27	20	31	2	0.3	3.9	0.72	96.5	87.8871	59.8472
2014	9	27	20	41	2	0.3	3.9	0.72	96	87.8871	59.5739
2014	9	27	20	51	2	0.3	3.9	0.73	95.5	87.9528	60.167
2014	9	27	21	1	2	0.3	3.9	0.75	96.3	87.9528	61.808
2014	9	27	21	11	2	0.3	3.9	0.73	95.9	87.9528	60.714
2014	9	27	21	21	2	0.3	3.9	0.74	95.6	87.8871	61.7601
2014	9	27	21	31	2	0.3	3.9	0.74	96.1	87.9528	61.261
2014	9	27	21	41	2	0.3	3.9	0.7	94.9	87.8871	57.9343
2014	9	27	21	51	2	0.3	3.9	0.72	95.5	87.9528	59.3466
2014	9	27	22	1	2	0.3	3.9	0.74	96.1	87.9528	61.261
2014	9	27	22	11	2	0.3	3.9	0.74	95.6	87.8871	61.7602
2014	9	27	22	21	2	0.3	3.9	0.72	97.4	87.8871	59.3007
2014	9	27	22	31	2	0.3	3.9	0.73	96.7	87.8871	60.6671
2014	9	27	22	41	2	0.3	3.9	0.72	98.6	87.9528	59.6201
2014	9	27	22	51	2	0.3	3.9	0.71	96.1	87.9528	58.7997
2014	9	27	23	1	2	0.3	3.9	0.74	95.9	87.9528	60.9876
2014	9	27	23	11	2	0.3	3.9	0.75	97.8	87.9528	62.0815
2014	9	27	23	21	2	0.3	3.9	0.74	95.6	87.9528	61.808
2014	9	27	23	31	2	0.3	3.9	0.72	97	88.0184	59.94
2014	9	27	23	41	2	0.3	3.9	0.75	97.3	88.084	61.9037
2014	9	27	23	51	2	0.3	3.9	0.72	96.5	88.0184	59.94
2014	9	28	0	1	2	0.3	3.9	0.73	95.7	88.0184	60.4874
2014	9	28	0	11	2	0.3	3.9	0.74	96.9	88.0184	61.3085
2014	9	28	0	21	2	0.3	3.9	0.75	98.3	88.0184	61.5822
2014	9	28	0	31	2	0.3	3.9	0.76	97.2	88.0184	62.9507
2014	9	28	0	41	2	0.3	3.9	0.75	96.8	88.084	61.9038
2014	9	28	0	51	2	0.3	3.9	0.75	94	88.0184	62.1297
2014	9	28	1	1	2	0.3	3.9	0.75	95.3	87.9528	62.0816
2014	9	28	1	11	2	0.3	3.9	0.75	94.8	87.8871	62.0336
2014	9	28	1	21	2	0.3	3.9	0.75	97.8	87.8871	61.4871
2014	9	28	1	31	2	0.3	3.9	0.71	97.1	87.8871	59.0276
2014	9	28	1	41	2	0.3	3.9	0.73	98	87.8215	60.0741
2014	9	28	1	51	2	0.3	3.9	0.74	97.3	87.8215	61.4395
2014	9	28	2	1	2	0.3	3.9	0.79	96.9	87.8871	65.5863
2014	9	28	2	11	2	0.3	3.9	0.74	96.7	87.8871	60.9406
2014	9	28	2	21	2	0.3	3.9	0.76	96	87.8215	62.8048
2014	9	28	2	31	2	0.3	3.9	0.75	97.8	87.8871	61.4872
2014	9	28	2	41	2	0.3	3.9	0.75	96.3	87.8871	61.7605
2014	9	28	2	51	2	0.3	3.9	0.73	95.1	87.8215	60.6204
2014	9	28	3	1	2	0.3	3.9	0.74	95.8	87.8215	61.4396
2014	9	28	3	11	2	0.3	3.9	0.72	96.3	87.8215	59.5281
2014	9	28	3	21	2	0.3	3.9	0.77	99.1	87.8215	63.3511
2014	9	28	3	31	2	0.3	3.9	0.71	96.1	87.8215	58.709
2014	9	28	3	41	2	0.3	3.9	0.75	97.3	87.8215	61.7127

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	3	51	2	0.3	3.9	0.74	97.9	87.8215	60.6204
2014	9	28	4	1	2	0.3	3.9	0.72	98.6	87.8215	59.2551
2014	9	28	4	11	2	0.3	3.9	0.74	97.9	87.8871	60.9407
2014	9	28	4	21	2	0.3	3.9	0.71	95.8	87.8215	58.9821
2014	9	28	4	31	2	0.3	3.9	0.72	97	87.8871	59.8477
2014	9	28	4	41	2	0.3	3.9	0.73	96.9	87.8871	60.6675
2014	9	28	4	51	2	0.3	3.9	0.75	93.5	87.9528	62.3554
2014	9	28	5	1	2	0.3	3.9	0.73	98.5	88.0184	60.2141
2014	9	28	5	11	2	0.3	3.9	0.72	97.6	87.9528	59.3471
2014	9	28	5	21	2	0.3	3.9	0.75	97.5	87.9528	62.082
2014	9	28	5	31	2	0.3	3.9	0.74	95.8	88.0184	61.5826
2014	9	28	5	41	2	0.3	3.9	0.76	99.2	88.0184	62.4038
2014	9	28	5	51	2	0.3	3.9	0.73	96.2	88.0184	60.7616
2014	9	28	6	1	2	0.3	3.9	0.73	97.4	88.0184	60.7616
2014	9	28	6	11	2	0.3	3.9	0.73	96.7	88.0184	60.4879
2014	9	28	6	21	2	0.3	3.9	0.73	97.8	88.0184	60.2142
2014	9	28	6	31	2	0.3	3.9	0.74	95.9	88.0184	61.0353
2014	9	28	6	41	2	0.3	3.9	0.76	96.2	88.0184	62.6775
2014	9	28	6	51	2	0.3	3.9	0.75	96.3	88.0184	62.1301
2014	9	28	7	1	2	0.3	3.9	0.71	97.4	88.0184	58.8457
2014	9	28	7	11	2	0.3	3.9	0.75	95.2	88.0184	62.6776
2014	9	28	7	21	2	0.3	3.9	0.76	96.2	87.9528	62.9026
2014	9	28	7	31	2	0.3	3.9	0.74	97.3	88.0184	61.5828
2014	9	28	7	41	2	0.3	3.9	0.73	96.5	87.9528	60.1677
2014	9	28	7	51	2	0.3	3.9	0.76	96.5	87.9528	62.6291
2014	9	28	8	1	2	0.3	3.9	0.72	94.7	87.9528	60.1677
2014	9	28	8	11	2	0.3	3.9	0.76	95.7	87.9528	62.6292
2014	9	28	8	21	2	0.3	3.9	0.76	96.7	87.9528	62.6292
2014	9	28	8	31	2	0.3	3.9	0.79	97.4	87.9528	65.364
2014	9	28	8	41	2	0.3	3.9	0.75	99.3	87.8871	62.0341
2014	9	28	8	51	2	0.3	3.9	0.73	98.5	87.8871	60.1212
2014	9	28	9	1	2	0.3	3.9	0.73	97.8	87.8871	59.8479
2014	9	28	9	11	2	0.3	3.9	0.73	97.8	87.8215	60.0746
2014	9	28	9	21	2	0.3	3.9	0.72	97.6	87.7559	59.2094
2014	9	28	9	31	2	0.3	3.9	0.76	98.4	87.7559	62.4837
2014	9	28	9	41	2	0.3	3.9	0.72	98.9	87.7559	58.9366
2014	9	28	9	51	2	0.3	3.9	0.76	97.2	87.7559	63.0294
2014	9	28	10	1	2	0.3	3.9	0.73	97.7	87.7559	60.5737
2014	9	28	10	11	2	0.3	3.9	0.77	100.6	87.7559	62.7565
2014	9	28	10	21	2	0.3	3.9	0.77	99.6	87.6903	62.7078
2014	9	28	10	31	2	0.3	3.9	0.76	98.7	87.6903	62.4352
2014	9	28	10	41	2	0.3	3.9	0.77	100.1	87.6903	62.7078
2014	9	28	10	51	2	0.3	3.9	0.77	98.4	87.6903	62.9804
2014	9	28	11	1	2	0.3	3.9	0.75	99.8	87.6903	61.6172
2014	9	28	11	11	2	0.3	3.9	0.76	97.9	87.6903	62.7078
2014	9	28	11	21	2	0.3	3.9	0.77	100.5	87.6903	63.253

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	11	31	2	0.3	3.9	0.75	97.7	87.6903	62.1625
2014	9	28	11	41	2	0.3	3.9	0.73	97.4	87.6903	60.5266
2014	9	28	11	51	2	0.3	3.9	0.76	97.4	87.6903	62.7077
2014	9	28	12	1	2	0.3	3.9	0.76	98.7	87.6903	62.4351
2014	9	28	12	11	2	0.3	3.9	0.75	96.1	87.6903	61.6171
2014	9	28	12	21	2	0.3	3.9	0.74	101.8	87.6247	59.9347
2014	9	28	12	31	2	0.3	3.9	0.74	99	87.6247	60.4796
2014	9	28	12	41	2	0.3	3.9	0.75	98.1	87.6247	61.5693
2014	9	28	12	51	2	0.3	3.9	0.75	98.1	87.6247	61.2968
2014	9	28	13	1	2	0.3	3.9	0.75	98.8	87.6247	61.2969
2014	9	28	13	11	2	0.3	3.9	0.74	100.7	87.6247	60.752
2014	9	28	13	21	2	0.3	3.9	0.77	99.9	87.6247	62.659
2014	9	28	13	31	2	0.3	3.9	0.77	97.6	87.6247	63.4763
2014	9	28	13	41	2	0.3	3.9	0.75	100.5	87.6247	61.5694
2014	9	28	13	51	2	0.3	3.9	0.79	97.6	87.5591	65.0604
2014	9	28	14	1	2	0.3	3.9	0.75	98.3	87.5591	61.7938
2014	9	28	14	11	2	0.3	3.9	0.74	97.6	87.6247	61.297
2014	9	28	14	21	2	0.3	3.9	0.73	97.7	87.5591	60.4327
2014	9	28	14	31	2	0.3	3.9	0.77	99.1	87.5591	62.8826
2014	9	28	14	41	2	0.3	3.9	0.74	102.6	87.5591	59.8882
2014	9	28	14	51	2	0.3	3.9	0.75	101.8	87.5591	61.2493
2014	9	28	15	1	2	0.3	3.9	0.78	100.6	87.5591	63.6993
2014	9	28	15	11	2	0.3	3.9	0.75	99.3	87.5591	61.5216
2014	9	28	15	21	2	0.3	3.9	0.75	100.1	87.5591	60.9771
2014	9	28	15	31	2	0.3	3.9	0.77	99.1	87.5591	63.1549
2014	9	28	15	41	2	0.3	3.9	0.77	99.3	87.5591	63.1549
2014	9	28	15	51	2	0.3	3.9	0.72	101.1	87.5591	58.5272
2014	9	28	16	1	2	0.3	3.9	0.73	99.5	87.5591	59.8883
2014	9	28	16	11	2	0.3	3.9	0.76	100.4	87.5591	62.066
2014	9	28	16	21	2	0.3	3.9	0.75	100.6	87.5591	60.9772
2014	9	28	16	31	2	0.3	3.9	0.73	98.7	87.5591	60.1605
2014	9	28	16	41	2	0.3	3.9	0.72	97.6	87.5591	58.7994
2014	9	28	16	51	2	0.3	3.9	0.74	101.5	87.5591	60.4327
2014	9	28	17	1	2	0.3	3.9	0.74	99.4	87.6247	60.7522
2014	9	28	17	11	2	0.3	3.9	0.72	98.4	87.6247	59.1176
2014	9	28	17	21	2	0.3	3.9	0.76	98.2	87.5591	62.6105
2014	9	28	17	31	2	0.3	3.9	0.75	95.5	87.6247	62.3868
2014	9	28	17	41	2	0.3	3.9	0.71	95.6	87.6247	58.5727
2014	9	28	17	51	2	0.3	3.9	0.71	96.3	87.6247	58.8452
2014	9	28	18	1	2	0.3	3.9	0.74	96.7	87.6247	60.7522
2014	9	28	18	11	2	0.3	3.9	0.74	96.7	87.6247	60.7522
2014	9	28	18	21	2	0.3	3.9	0.76	96.9	87.6247	62.9316
2014	9	28	18	31	2	0.3	3.9	0.74	96.4	87.6247	61.0246
2014	9	28	18	41	2	0.3	3.9	0.74	97.2	87.6247	60.7522
2014	9	28	18	51	2	0.3	3.9	0.75	94.8	87.6247	62.1144
2014	9	28	19	1	2	0.3	3.9	0.73	97.8	87.6247	59.9349

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	19	11	2	0.3	3.9	0.74	97.4	87.6247	61.0246
2014	9	28	19	21	2	0.3	3.9	0.71	97.7	87.6247	58.5727
2014	9	28	19	31	2	0.3	3.9	0.72	93.6	87.6247	59.9349
2014	9	28	19	41	2	0.3	3.9	0.73	97.4	87.6247	60.4798
2014	9	28	19	51	2	0.3	3.9	0.73	97.5	87.6247	60.2073
2014	9	28	20	1	2	0.3	3.9	0.74	97.3	87.6247	61.2971
2014	9	28	20	11	2	0.3	3.9	0.73	94.9	87.6247	60.4798
2014	9	28	20	21	2	0.3	3.9	0.72	97.1	87.6247	59.1176
2014	9	28	20	31	2	0.3	3.9	0.74	94.6	87.6903	61.3447
2014	9	28	20	41	2	0.3	3.9	0.71	97.7	87.6903	58.6182
2014	9	28	20	51	2	0.3	3.9	0.7	97	87.6903	58.073
2014	9	28	21	1	2	0.3	3.9	0.71	96.6	87.6903	58.6182
2014	9	28	21	11	2	0.3	3.9	0.72	95.2	87.6903	59.7088
2014	9	28	21	21	2	0.3	3.9	0.75	96.1	87.6247	61.5695
2014	9	28	21	31	2	0.3	3.9	0.74	95.1	87.6903	61.072
2014	9	28	21	41	2	0.3	3.9	0.72	96	87.6903	59.7088
2014	9	28	21	51	2	0.3	3.9	0.74	95.1	87.7559	61.3923
2014	9	28	22	1	2	0.3	3.9	0.74	97.6	87.7559	61.1194
2014	9	28	22	11	2	0.3	3.9	0.74	99.1	87.6247	61.0246
2014	9	28	22	21	2	0.3	3.9	0.74	95.8	87.6903	61.3447
2014	9	28	22	31	2	0.3	3.9	0.76	100.2	87.6903	62.1626
2014	9	28	22	41	2	0.3	3.9	0.74	95.6	87.6903	61.3447
2014	9	28	22	51	2	0.3	3.9	0.73	98.7	87.6903	60.2541
2014	9	28	23	1	2	0.3	3.9	0.72	97	87.6903	59.7088
2014	9	28	23	11	2	0.3	3.9	0.73	98.3	87.7559	59.7552
2014	9	28	23	21	2	0.3	3.9	0.73	96.7	87.6903	59.9815
2014	9	28	23	31	2	0.3	3.9	0.72	94.7	87.6903	59.9815
2014	9	28	23	41	2	0.3	3.9	0.72	97	87.6903	59.7088
2014	9	28	23	51	2	0.3	3.9	0.74	97.3	87.6903	61.3447
2014	9	29	0	1	2	0.3	3.9	0.74	96.4	87.6903	61.0721
2014	9	29	0	11	2	0.3	3.9	0.76	96.9	87.6903	62.7079
2014	9	29	0	21	2	0.3	3.9	0.74	97.1	87.6903	61.3447
2014	9	29	0	31	2	0.3	3.9	0.75	98.8	87.6903	61.89
2014	9	29	0	41	2	0.3	3.9	0.73	97.8	87.6903	59.9815
2014	9	29	0	51	2	0.3	3.9	0.73	96.7	87.7559	60.0281
2014	9	29	1	1	2	0.3	3.9	0.75	96.6	87.7559	61.6652
2014	9	29	1	11	2	0.3	3.9	0.75	96.6	87.7559	61.6652
2014	9	29	1	21	2	0.3	3.9	0.74	97.3	87.7559	61.3924
2014	9	29	1	31	2	0.3	3.9	0.74	95.6	87.7559	61.1195
2014	9	29	1	41	2	0.3	3.9	0.75	95.8	87.7559	62.2109
2014	9	29	1	51	2	0.3	3.9	0.73	96.7	87.7559	60.301
2014	9	29	2	1	2	0.3	3.9	0.71	96.9	87.7559	58.9367
2014	9	29	2	11	2	0.3	3.9	0.75	97	87.7559	61.9381
2014	9	29	2	21	2	0.3	3.9	0.74	98.5	87.7559	60.5738
2014	9	29	2	31	2	0.3	3.9	0.75	97.1	87.7559	61.6653
2014	9	29	2	41	2	0.3	3.9	0.75	96.1	87.7559	61.6653

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	2	51	2	0.3	3.9	0.73	95.9	87.8215	60.3478
2014	9	29	3	1	2	0.3	3.9	0.74	97.4	87.8215	60.8939
2014	9	29	3	11	2	0.3	3.9	0.75	96.6	87.8215	61.7132
2014	9	29	3	21	2	0.3	3.9	0.72	96.8	87.7559	59.4825
2014	9	29	3	31	2	0.3	3.9	0.75	95.2	87.8215	62.5324
2014	9	29	3	41	2	0.3	3.9	0.75	94.5	87.8215	62.5324
2014	9	29	3	51	2	0.3	3.9	0.74	97.9	87.8215	61.1671
2014	9	29	4	1	2	0.3	3.9	0.72	95.7	87.8215	59.8017
2014	9	29	4	11	2	0.3	3.9	0.74	97.1	87.8215	61.1671
2014	9	29	4	21	2	0.3	3.9	0.74	94.6	87.8215	61.1671
2014	9	29	4	31	2	0.3	3.9	0.72	97.4	87.8871	59.3016
2014	9	29	4	41	2	0.3	3.9	0.73	98	87.8871	60.3947
2014	9	29	4	51	2	0.3	3.9	0.73	98.5	87.8871	60.1214
2014	9	29	5	1	2	0.3	3.9	0.74	98.2	87.9528	60.9885
2014	9	29	5	11	2	0.3	3.9	0.73	97.2	87.9528	60.4415
2014	9	29	5	21	2	0.3	3.9	0.72	97.3	87.9528	59.621
2014	9	29	5	31	2	0.3	3.9	0.75	94.3	87.9528	62.0825
2014	9	29	5	41	2	0.3	3.9	0.71	99.3	88.0184	58.5724
2014	9	29	5	51	2	0.3	3.9	0.72	97.9	88.0184	59.3935
2014	9	29	6	1	2	0.3	3.9	0.73	97.5	87.9528	60.4415
2014	9	29	6	11	2	0.3	3.9	0.72	96.8	87.9528	59.6211
2014	9	29	6	21	2	0.3	3.9	0.73	96.2	88.0184	60.4883
2014	9	29	6	31	2	0.3	3.9	0.73	95.1	88.0184	60.762
2014	9	29	6	41	2	0.3	3.9	0.74	98.4	88.0184	61.0358
2014	9	29	6	51	2	0.3	3.9	0.75	96	88.0184	62.4043
2014	9	29	7	1	2	0.3	3.9	0.73	97.3	87.9528	60.1681
2014	9	29	7	11	2	0.3	3.9	0.74	97.2	88.0184	61.0358
2014	9	29	7	21	2	0.3	3.9	0.74	97.1	88.0184	61.3095
2014	9	29	7	31	2	0.3	3.9	0.74	96.1	88.0184	61.0358
2014	9	29	7	41	2	0.3	3.9	0.75	97.8	87.9528	62.0826
2014	9	29	7	51	2	0.3	3.9	0.78	98.5	87.9528	64.2705
2014	9	29	8	1	2	0.3	3.9	0.74	96.3	87.9528	61.5356
2014	9	29	8	11	2	0.3	3.9	0.73	96.5	87.9528	60.1681
2014	9	29	8	21	2	0.3	3.9	0.76	95.9	87.9528	63.1766
2014	9	29	8	31	2	0.3	3.9	0.73	97.7	87.9528	60.7151
2014	9	29	8	41	2	0.3	3.9	0.73	96.7	87.9528	60.4416
2014	9	29	8	51	2	0.3	3.9	0.72	96.8	87.9528	59.8946
2014	9	29	9	1	2	0.3	3.9	0.76	99.4	87.9528	62.903
2014	9	29	9	11	2	0.3	3.9	0.74	99.7	87.9528	60.9886
2014	9	29	9	21	2	0.3	3.9	0.74	99.4	87.9528	60.9886
2014	9	29	9	31	2	0.3	3.9	0.72	95.2	87.9528	59.6211
2014	9	29	9	41	2	0.3	3.9	0.72	98.6	87.9528	59.6211
2014	9	29	9	51	2	0.3	3.9	0.71	96.3	87.9528	59.0741
2014	9	29	10	1	2	0.3	3.9	0.73	99	87.9528	60.1681
2014	9	29	10	11	2	0.3	3.9	0.74	100.5	87.9528	60.4416
2014	9	29	10	21	2	0.3	3.9	0.74	96.4	87.9528	60.9885

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	10	31	2	0.3	3.9	0.75	97.3	87.9528	62.0825
2014	9	29	10	41	2	0.3	3.9	0.74	98.6	87.8871	61.2146
2014	9	29	10	51	2	0.3	3.9	0.72	97.9	87.8215	59.2557
2014	9	29	11	1	2	0.3	3.9	0.77	102.6	87.8871	62.581
2014	9	29	11	11	2	0.3	3.9	0.73	99.8	87.8871	59.8482
2014	9	29	11	21	2	0.3	3.9	0.72	97.6	87.8871	59.0283
2014	9	29	11	31	2	0.3	3.9	0.71	98.7	87.8871	58.755
2014	9	29	11	41	2	0.3	3.9	0.72	97.3	87.8871	59.8481
2014	9	29	11	51	2	0.3	3.9	0.73	98.8	87.8215	59.8018
2014	9	29	12	1	2	0.3	3.9	0.73	95.9	87.8215	60.621
2014	9	29	12	11	2	0.3	3.9	0.73	98.5	87.7559	60.0283
2014	9	29	12	21	2	0.3	3.9	0.73	100.6	87.7559	59.7554
2014	9	29	12	31	2	0.3	3.9	0.72	96.8	87.6903	59.4364
2014	9	29	12	41	2	0.3	3.9	0.72	98.7	87.6903	58.8911
2014	9	29	12	51	2	0.3	3.9	0.76	99.2	87.6903	62.1628
2014	9	29	13	1	2	0.3	3.9	0.73	98.6	87.6247	59.6627
2014	9	29	13	11	2	0.3	3.9	0.73	97.7	87.6247	60.48
2014	9	29	13	21	2	0.3	3.9	0.72	100.2	87.6247	58.8454
2014	9	29	13	31	2	0.3	3.9	0.74	98.5	87.6247	60.48
2014	9	29	13	41	2	0.3	3.9	0.74	97.4	87.6247	61.0248
2014	9	29	13	51	2	0.3	3.9	0.73	96.7	87.6247	60.2075
2014	9	29	14	1	2	0.3	3.9	0.72	95.5	87.6247	59.6627
2014	9	29	14	11	2	0.3	3.9	0.77	96.6	87.6247	63.2043
2014	9	29	14	21	2	0.3	3.9	0.76	98.2	87.6247	62.1146
2014	9	29	14	31	2	0.3	3.9	0.71	96.1	87.6247	58.8454
2014	9	29	14	41	2	0.3	3.9	0.77	97.9	87.5591	62.883
2014	9	29	14	51	2	0.3	3.9	0.73	97.8	87.5591	59.8885
2014	9	29	15	1	2	0.3	3.9	0.73	98	87.5591	60.1608
2014	9	29	15	11	2	0.3	3.9	0.74	95.8	87.5591	61.2497
2014	9	29	15	21	2	0.3	3.9	0.73	96.9	87.5591	60.433
2014	9	29	15	31	2	0.3	3.9	0.76	98	87.5591	62.3386
2014	9	29	15	41	2	0.3	3.9	0.72	98.2	87.5591	58.7997
2014	9	29	15	51	2	0.3	3.9	0.73	97	87.5591	59.8886
2014	9	29	16	1	2	0.3	3.9	0.75	100.6	87.5591	61.2497
2014	9	29	16	11	2	0.3	3.9	0.73	99.3	87.4934	59.57
2014	9	29	16	21	2	0.3	3.9	0.74	99.1	87.5591	60.9775
2014	9	29	16	31	2	0.3	3.9	0.72	99.2	87.4934	59.026
2014	9	29	16	41	2	0.3	3.9	0.71	99.2	87.4934	58.482
2014	9	29	16	51	2	0.3	3.9	0.74	98.7	87.4934	60.6581
2014	9	29	17	1	2	0.3	3.9	0.76	96.9	87.4934	62.8342
2014	9	29	17	11	2	0.3	3.9	0.73	99.1	87.5591	59.6164
2014	9	29	17	21	2	0.3	3.9	0.74	101.5	87.5591	60.4331
2014	9	29	17	31	2	0.3	3.9	0.77	102.4	87.5591	62.0664
2014	9	29	17	41	2	0.3	3.9	0.71	100.9	87.5591	57.9831
2014	9	29	17	51	2	0.3	3.9	0.7	98.8	87.5591	57.7109
2014	9	29	18	1	2	0.3	3.9	0.71	99.5	87.5591	58.2553

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	18	11	2	0.3	3.9	0.71	98.5	87.5591	58.5275
2014	9	29	18	21	2	0.3	3.9	0.71	98.2	87.5591	58.2553
2014	9	29	18	31	2	0.3	3.9	0.72	99.5	87.5591	58.7998
2014	9	29	18	41	2	0.3	3.9	0.75	98.8	87.5591	61.7942
2014	9	29	18	51	2	0.3	3.9	0.73	100.1	87.5591	59.3442
2014	9	29	19	1	2	0.3	3.9	0.74	98.2	87.5591	60.7053
2014	9	29	19	11	2	0.3	3.9	0.68	96.9	87.5591	56.3498
2014	9	29	19	21	2	0.3	3.9	0.73	95.7	87.4934	60.3861
2014	9	29	19	31	2	0.3	3.9	0.73	95.9	87.5591	60.1608
2014	9	29	19	41	2	0.3	3.9	0.72	98.9	87.5591	58.7997
2014	9	29	19	51	2	0.3	3.9	0.71	96.4	87.5591	58.2553
2014	9	29	20	1	2	0.3	3.9	0.73	99.1	87.5591	59.6164
2014	9	29	20	11	2	0.3	3.9	0.74	97.4	87.5591	60.9775
2014	9	29	20	21	2	0.3	3.9	0.72	95	87.5591	59.6164
2014	9	29	20	31	2	0.3	3.9	0.69	97.7	87.5591	56.3497
2014	9	29	20	41	2	0.3	3.9	0.72	98.6	87.5591	59.3442
2014	9	29	20	51	2	0.3	3.9	0.72	98.7	87.5591	58.7997
2014	9	29	21	1	2	0.3	3.9	0.71	97.9	87.5591	58.5275
2014	9	29	21	11	2	0.3	3.9	0.7	96.4	87.4934	57.938
2014	9	29	21	21	2	0.3	3.9	0.75	98	87.5591	61.7941
2014	9	29	21	31	2	0.3	3.9	0.74	97.9	87.5591	60.7052
2014	9	29	21	41	2	0.3	3.9	0.72	95	87.5591	59.6164
2014	9	29	21	51	2	0.3	3.9	0.73	98.3	87.4934	59.842
2014	9	29	22	1	2	0.3	3.9	0.73	98.5	87.5591	59.8886
2014	9	29	22	11	2	0.3	3.9	0.75	98.1	87.5591	61.2497
2014	9	29	22	21	2	0.3	3.9	0.7	99.2	87.5591	57.4386
2014	9	29	22	31	2	0.3	3.9	0.73	99	87.5591	59.8886
2014	9	29	22	41	2	0.3	3.9	0.7	97.6	87.5591	57.4386
2014	9	29	22	51	2	0.3	3.9	0.76	98.5	87.5591	62.0663
2014	9	29	23	1	2	0.3	3.9	0.73	97.8	87.4934	59.57
2014	9	29	23	11	2	0.3	3.9	0.71	99	87.4934	58.482
2014	9	29	23	21	2	0.3	3.9	0.72	97.6	87.4934	59.298
2014	9	29	23	31	2	0.3	3.9	0.73	96	87.5591	59.8886
2014	9	29	23	41	2	0.3	3.9	0.72	97.1	87.5591	59.0719
2014	9	29	23	51	2	0.3	3.9	0.71	97.2	87.4934	58.482
2014	9	30	0	1	2	0.3	3.9	0.71	97.8	87.5591	57.9831
2014	9	30	0	11	2	0.3	3.9	0.71	95.3	87.4934	59.026
2014	9	30	0	21	2	0.3	3.9	0.73	98.8	87.5591	59.6164
2014	9	30	0	31	2	0.3	3.9	0.74	97.4	87.4934	60.9301
2014	9	30	0	41	2	0.3	3.9	0.71	95.3	87.4934	59.0261
2014	9	30	0	51	2	0.3	3.9	0.71	96.9	87.4934	58.7541
2014	9	30	1	1	2	0.3	3.9	0.73	97.5	87.4934	60.1141
2014	9	30	1	11	2	0.3	3.9	0.71	95.6	87.4934	58.7541
2014	9	30	1	21	2	0.3	3.9	0.7	95.4	87.4934	57.666
2014	9	30	1	31	2	0.3	3.9	0.73	99.5	87.5591	59.8887
2014	9	30	1	41	2	0.3	3.9	0.74	98.2	87.4934	60.6582

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	1	51	2	0.3	3.9	0.7	99.7	87.4934	57.3941
2014	9	30	2	1	2	0.3	3.9	0.72	97.1	87.4934	59.0261
2014	9	30	2	11	2	0.3	3.9	0.73	97.2	87.4934	60.3862
2014	9	30	2	21	2	0.3	3.9	0.7	97	87.4934	57.9381
2014	9	30	2	31	2	0.3	3.9	0.7	94	87.4934	58.2101
2014	9	30	2	41	2	0.3	3.9	0.7	99.7	87.4934	57.3941
2014	9	30	2	51	2	0.3	3.9	0.7	96.5	87.4934	57.3941
2014	9	30	3	1	2	0.3	3.9	0.72	95.8	87.4934	59.2982
2014	9	30	3	11	2	0.3	3.9	0.71	96.4	87.4934	58.2102
2014	9	30	3	21	2	0.3	3.9	0.69	96.3	87.4934	56.5782
2014	9	30	3	31	2	0.3	3.9	0.72	97.3	87.4934	59.2983
2014	9	30	3	41	2	0.3	3.9	0.71	99.6	87.4934	57.9382
2014	9	30	3	51	2	0.3	3.9	0.76	98	87.4934	62.0184
2014	9	30	4	1	2	0.3	3.9	0.71	97.2	87.4934	58.4823
2014	9	30	4	11	2	0.3	3.9	0.71	97.5	87.4934	58.2103
2014	9	30	4	21	2	0.3	3.9	0.72	98.4	87.4934	59.2983
2014	9	30	4	31	2	0.3	3.9	0.72	98.9	87.4934	58.7543
2014	9	30	4	41	2	0.3	3.9	0.74	100	87.4934	60.1144
2014	9	30	4	51	2	0.3	3.9	0.69	99.3	87.4934	56.5783
2014	9	30	5	1	2	0.3	3.9	0.69	99.8	87.4278	56.5343
2014	9	30	5	11	2	0.3	3.9	0.72	96.8	87.4934	59.5704
2014	9	30	5	21	2	0.3	3.9	0.71	101.7	87.4934	57.6663
2014	9	30	5	31	2	0.3	3.9	0.72	97.4	87.4934	59.0264
2014	9	30	5	41	2	0.3	3.9	0.73	96.2	87.4934	60.3865
2014	9	30	5	51	2	0.3	3.9	0.72	98.6	87.4934	59.2985
2014	9	30	6	1	2	0.3	3.9	0.74	98.1	87.4934	60.9305
2014	9	30	6	11	2	0.3	3.9	0.72	96.1	87.4934	59.0265
2014	9	30	6	21	2	0.3	3.9	0.71	98.5	87.4934	57.9384
2014	9	30	6	31	2	0.3	3.9	0.72	96	87.4934	59.5705
2014	9	30	6	41	2	0.3	3.9	0.73	97.8	87.5591	59.8891
2014	9	30	6	51	2	0.3	3.9	0.74	100	87.4934	60.3866
2014	9	30	7	1	2	0.3	3.9	0.73	95.9	87.4934	60.1146
2014	9	30	7	11	2	0.3	3.9	0.73	99.6	87.5591	59.3447
2014	9	30	7	21	2	0.3	3.9	0.72	96.3	87.5591	59.6169
2014	9	30	7	31	2	0.3	3.9	0.71	97.4	87.4934	58.4825
2014	9	30	7	41	2	0.3	3.9	0.7	97.3	87.4934	57.6665
2014	9	30	7	51	2	0.3	3.9	0.7	96.7	87.4934	57.6665
2014	9	30	8	1	2	0.3	3.9	0.72	99.7	87.4934	59.0266
2014	9	30	8	11	2	0.3	3.9	0.71	99.5	87.4934	58.2106
2014	9	30	8	21	2	0.3	3.9	0.72	96	87.4934	59.2986
2014	9	30	8	31	2	0.3	3.9	0.73	97.3	87.4934	59.8426
2014	9	30	8	41	2	0.3	3.9	0.71	97.9	87.4934	58.4826
2014	9	30	8	51	2	0.3	3.9	0.73	94.7	87.4934	60.1146
2014	9	30	9	1	2	0.3	3.9	0.72	97.5	87.4934	59.5706
2014	9	30	9	11	2	0.3	3.9	0.72	97.5	87.4934	59.5706
2014	9	30	9	21	2	0.3	3.9	0.74	97.4	87.4934	60.9306

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	9	31	2	0.3	3.9	0.72	96.8	87.4934	59.5706
2014	9	30	9	41	2	0.3	3.9	0.76	97.2	87.4278	62.2422
2014	9	30	9	51	2	0.3	3.9	0.71	97.7	87.4278	58.1652
2014	9	30	10	1	2	0.3	3.9	0.73	98.5	87.4278	60.0678
2014	9	30	10	11	2	0.3	3.9	0.72	96.3	87.4278	58.9806
2014	9	30	10	21	2	0.3	3.9	0.72	97.5	87.4278	59.5241
2014	9	30	10	31	2	0.3	3.9	0.74	97.4	87.4278	60.8831
2014	9	30	10	41	2	0.3	3.9	0.7	98.9	87.4278	57.0779
2014	9	30	10	51	2	0.3	3.9	0.73	94.9	87.4278	60.6113
2014	9	30	11	1	2	0.3	3.9	0.74	98.7	87.4278	60.3395
2014	9	30	11	11	2	0.3	3.9	0.74	100.5	87.4278	60.3395
2014	9	30	11	21	2	0.3	3.9	0.73	97.2	87.3622	60.0209
2014	9	30	11	31	2	0.3	3.9	0.72	97.4	87.3622	58.9345
2014	9	30	11	41	2	0.3	3.9	0.74	100	87.3622	60.2925
2014	9	30	11	51	2	0.3	3.9	0.72	99.4	87.3622	58.9345
2014	9	30	12	1	2	0.3	3.9	0.74	99.4	87.3622	60.8356
2014	9	30	12	11	2	0.3	3.9	0.76	99.7	87.3622	62.1935
2014	9	30	12	21	2	0.3	3.9	0.73	99	87.2966	59.7027
2014	9	30	12	31	2	0.3	3.9	0.73	99.3	87.2966	59.4313
2014	9	30	12	41	2	0.3	3.9	0.74	102.8	87.2966	59.7026
2014	9	30	12	51	2	0.3	3.9	0.73	98.8	87.2966	59.4313
2014	9	30	13	1	2	0.3	3.9	0.74	100.8	87.2966	59.974
2014	9	30	13	11	2	0.3	3.9	0.75	99.3	87.2966	61.0595
2014	9	30	13	21	2	0.3	3.9	0.75	97.8	87.231	61.283
2014	9	30	13	31	2	0.3	3.9	0.75	97.3	87.2966	61.3309
2014	9	30	13	41	2	0.3	3.9	0.73	103.3	87.231	58.5714
2014	9	30	13	51	2	0.3	3.9	0.72	101.3	87.231	58.3002
2014	9	30	14	1	2	0.3	3.9	0.73	100.8	87.231	59.656
2014	9	30	14	11	2	0.3	3.9	0.73	99.6	87.231	59.1137
2014	9	30	14	21	2	0.3	3.9	0.74	102	87.1654	59.8804
2014	9	30	14	31	2	0.3	3.9	0.73	100.9	87.1654	59.3385
2014	9	30	14	41	2	0.3	3.9	0.73	101.2	87.1654	58.7966
2014	9	30	14	51	2	0.3	3.9	0.75	101.4	87.1654	60.4224
2014	9	30	15	1	2	0.3	3.9	0.75	99.9	87.1654	60.6933
2014	9	30	15	11	2	0.3	3.9	0.74	99.4	87.0997	60.6459
2014	9	30	15	21	2	0.3	3.9	0.74	99.5	87.0997	59.8337
2014	9	30	15	31	2	0.3	3.9	0.7	102.8	87.0997	56.0433
2014	9	30	15	41	2	0.3	3.9	0.75	100.9	87.0997	60.3752
2014	9	30	15	51	2	0.3	3.9	0.71	101.5	87.0341	57.3522
2014	9	30	16	1	2	0.3	3.9	0.72	102.4	87.0341	57.8933
2014	9	30	16	11	2	0.3	3.9	0.74	103.1	87.0997	59.2923
2014	9	30	16	21	2	0.3	3.9	0.74	98.4	87.0341	60.328
2014	9	30	16	31	2	0.3	3.9	0.73	101.5	87.0341	58.7049
2014	9	30	16	41	2	0.3	3.9	0.71	99.9	86.9685	57.5777
2014	9	30	16	51	2	0.3	3.9	0.7	100.8	87.0341	56.8112
2014	9	30	17	1	2	0.3	3.9	0.74	103	86.9685	59.7403

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	17	11	2	0.3	3.9	0.75	101.3	86.9685	60.8215
2014	9	30	17	21	2	0.3	3.9	0.74	102	86.9685	59.7403
2014	9	30	17	31	2	0.3	3.9	0.7	101.7	86.9685	56.2262
2014	9	30	17	41	2	0.3	3.9	0.77	98.3	86.9685	62.7138
2014	9	30	17	51	2	0.3	3.9	0.74	100.7	86.9685	60.0106
2014	9	30	18	1	2	0.3	3.9	0.71	96.6	86.9685	58.1184
2014	9	30	18	11	2	0.3	3.9	0.71	99	87.0341	57.8933
2014	9	30	18	21	2	0.3	3.9	0.75	97.8	87.0341	61.1397
2014	9	30	18	31	2	0.3	3.9	0.74	95.8	87.0341	60.8692
2014	9	30	18	41	2	0.3	3.9	0.74	96.4	87.0341	60.3281
2014	9	30	18	51	2	0.3	3.9	0.72	97.4	86.9685	58.659
2014	9	30	19	1	2	0.3	3.9	0.74	95.6	86.9685	60.2809
2014	9	30	19	11	2	0.3	3.9	0.75	98.1	86.9685	61.0919
2014	9	30	19	21	2	0.3	3.9	0.71	97.4	86.9685	58.3887
2014	9	30	19	31	2	0.3	3.9	0.72	98.6	86.9685	58.659
2014	9	30	19	41	2	0.3	3.9	0.74	99.7	86.9685	60.2809
2014	9	30	19	51	2	0.3	3.9	0.72	98.7	86.9685	58.3887
2014	9	30	20	1	2	0.3	3.9	0.72	96	86.9029	59.1533
2014	9	30	20	11	2	0.3	3.9	0.73	98.1	86.8373	59.1069
2014	9	30	20	21	2	0.3	3.9	0.72	97.1	86.8373	58.5671
2014	9	30	20	31	2	0.3	3.9	0.73	97.3	86.8373	59.3768
2014	9	30	20	41	2	0.3	3.9	0.71	97.4	86.8373	58.2972
2014	9	30	20	51	2	0.3	3.9	0.72	95	86.8373	59.1069
2014	9	30	21	1	2	0.3	3.9	0.71	96.9	86.8373	58.2972
2014	9	30	21	11	2	0.3	3.9	0.71	96.1	86.8373	57.7574
2014	9	30	21	21	2	0.3	3.9	0.74	96.7	86.8373	60.1865
2014	9	30	21	31	2	0.3	3.9	0.72	98.2	86.9029	58.3429
2014	9	30	21	41	2	0.3	3.9	0.76	95.7	86.9029	62.1244
2014	9	30	21	51	2	0.3	3.9	0.75	95.8	86.9029	61.3141
2014	9	30	22	1	2	0.3	3.9	0.7	96.2	86.9685	57.5777
2014	9	30	22	11	2	0.3	3.9	0.73	98.5	86.9029	59.6934
2014	9	30	22	21	2	0.3	3.9	0.69	97.6	86.9029	56.4521
2014	9	30	22	31	2	0.3	3.9	0.7	96.5	86.8373	56.9477
2014	9	30	22	41	2	0.3	3.9	0.74	97.2	86.9029	60.2336
2014	9	30	22	51	2	0.3	3.9	0.72	97.6	86.9029	58.3429
2014	9	30	23	1	2	0.3	3.9	0.7	97.5	86.8373	57.4875
2014	9	30	23	11	2	0.3	3.9	0.73	97.3	86.8373	59.3767
2014	9	30	23	21	2	0.3	3.9	0.73	97	86.8373	59.3767
2014	9	30	23	31	2	0.3	3.9	0.69	97.7	86.8373	56.138
2014	9	30	23	41	2	0.3	3.9	0.72	95.2	86.8373	59.3767
2014	9	30	23	51	2	0.3	3.9	0.72	96.8	86.8373	58.837

Locust Ditch Return
Station 0215

Date	Flow (cfs)
9/1/2014	0
9/2/2014	0
9/3/2014	0
9/4/2014	0
9/5/2014	0
9/6/2014	0
9/7/2014	0
9/8/2014	0
9/9/2014	0
9/10/2014	0
9/11/2014	0
9/12/2014	0
9/13/2014	0
9/14/2014	0
9/15/2014	0
9/16/2014	0
9/17/2014	0
9/18/2014	0
9/19/2014	0
9/20/2014	0
9/21/2014	0
9/22/2014	0
9/23/2014	0
9/24/2014	0
9/25/2014	0
9/26/2014	0
9/27/2014	0
9/28/2014	0
9/29/2014	0
9/30/2014	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	12:00:00 AM	0
9/1/2014	12:15:00 AM	0
9/1/2014	12:30:00 AM	0
9/1/2014	12:45:00 AM	0
9/1/2014	1:00:00 AM	0
9/1/2014	1:15:00 AM	0
9/1/2014	1:30:00 AM	0
9/1/2014	1:45:00 AM	0
9/1/2014	2:00:00 AM	0
9/1/2014	2:15:00 AM	0
9/1/2014	2:30:00 AM	0
9/1/2014	2:45:00 AM	0
9/1/2014	3:00:00 AM	0
9/1/2014	3:15:00 AM	0
9/1/2014	3:30:00 AM	0
9/1/2014	3:45:00 AM	0
9/1/2014	4:00:00 AM	0
9/1/2014	4:15:00 AM	0
9/1/2014	4:30:00 AM	0
9/1/2014	4:45:00 AM	0
9/1/2014	5:00:00 AM	0
9/1/2014	5:15:00 AM	0
9/1/2014	5:30:00 AM	0
9/1/2014	5:45:00 AM	0
9/1/2014	6:00:00 AM	0
9/1/2014	6:15:00 AM	0
9/1/2014	6:30:00 AM	0
9/1/2014	6:45:00 AM	0
9/1/2014	7:00:00 AM	0
9/1/2014	7:15:00 AM	0
9/1/2014	7:30:00 AM	0
9/1/2014	7:45:00 AM	0
9/1/2014	8:00:00 AM	0
9/1/2014	8:15:00 AM	0
9/1/2014	8:30:00 AM	0
9/1/2014	8:45:00 AM	0
9/1/2014	9:00:00 AM	0
9/1/2014	9:15:00 AM	0
9/1/2014	9:30:00 AM	0
9/1/2014	9:45:00 AM	0
9/1/2014	10:00:00 AM	0
9/1/2014	10:15:00 AM	0
9/1/2014	10:30:00 AM	0
9/1/2014	10:45:00 AM	0
9/1/2014	11:00:00 AM	0
9/1/2014	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	11:30:00 AM	0
9/1/2014	11:45:00 AM	0
9/1/2014	12:00:00 PM	0
9/1/2014	12:15:00 PM	0
9/1/2014	12:30:00 PM	0
9/1/2014	12:45:00 PM	0
9/1/2014	1:00:00 PM	0
9/1/2014	1:15:00 PM	0
9/1/2014	1:30:00 PM	0
9/1/2014	1:45:00 PM	0
9/1/2014	2:00:00 PM	0
9/1/2014	2:15:00 PM	0
9/1/2014	2:30:00 PM	0
9/1/2014	2:45:00 PM	0
9/1/2014	3:00:00 PM	0
9/1/2014	3:15:00 PM	0
9/1/2014	3:30:00 PM	0
9/1/2014	3:45:00 PM	0
9/1/2014	4:00:00 PM	0
9/1/2014	4:15:00 PM	0
9/1/2014	4:30:00 PM	0
9/1/2014	4:45:00 PM	0
9/1/2014	5:00:00 PM	0
9/1/2014	5:15:00 PM	0
9/1/2014	5:30:00 PM	0
9/1/2014	5:45:00 PM	0
9/1/2014	6:00:00 PM	0
9/1/2014	6:15:00 PM	0
9/1/2014	6:30:00 PM	0
9/1/2014	6:45:00 PM	0
9/1/2014	7:00:00 PM	0
9/1/2014	7:15:00 PM	0
9/1/2014	7:30:00 PM	0
9/1/2014	7:45:00 PM	0
9/1/2014	8:00:00 PM	0
9/1/2014	8:15:00 PM	0
9/1/2014	8:30:00 PM	0
9/1/2014	8:45:00 PM	0
9/1/2014	9:00:00 PM	0
9/1/2014	9:15:00 PM	0
9/1/2014	9:30:00 PM	0
9/1/2014	9:45:00 PM	0
9/1/2014	10:00:00 PM	0
9/1/2014	10:15:00 PM	0
9/1/2014	10:30:00 PM	0
9/1/2014	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	11:00:00 PM	0
9/1/2014	11:15:00 PM	0
9/1/2014	11:30:00 PM	0
9/1/2014	11:45:00 PM	0
9/2/2014	12:00:00 AM	0
9/2/2014	12:15:00 AM	0
9/2/2014	12:30:00 AM	0
9/2/2014	12:45:00 AM	0
9/2/2014	1:00:00 AM	0
9/2/2014	1:15:00 AM	0
9/2/2014	1:30:00 AM	0
9/2/2014	1:45:00 AM	0
9/2/2014	2:00:00 AM	0
9/2/2014	2:15:00 AM	0
9/2/2014	2:30:00 AM	0
9/2/2014	2:45:00 AM	0
9/2/2014	3:00:00 AM	0
9/2/2014	3:15:00 AM	0
9/2/2014	3:30:00 AM	0
9/2/2014	3:45:00 AM	0
9/2/2014	4:00:00 AM	0
9/2/2014	4:15:00 AM	0
9/2/2014	4:30:00 AM	0
9/2/2014	4:45:00 AM	0
9/2/2014	5:00:00 AM	0
9/2/2014	5:15:00 AM	0
9/2/2014	5:30:00 AM	0
9/2/2014	5:45:00 AM	0
9/2/2014	6:00:00 AM	0
9/2/2014	6:15:00 AM	0
9/2/2014	6:30:00 AM	0
9/2/2014	6:45:00 AM	0
9/2/2014	7:00:00 AM	0
9/2/2014	7:15:00 AM	0
9/2/2014	7:30:00 AM	0
9/2/2014	7:45:00 AM	0
9/2/2014	8:00:00 AM	0
9/2/2014	8:15:00 AM	0
9/2/2014	8:30:00 AM	0
9/2/2014	8:45:00 AM	0
9/2/2014	9:00:00 AM	0
9/2/2014	9:15:00 AM	0
9/2/2014	9:30:00 AM	0
9/2/2014	9:45:00 AM	0
9/2/2014	10:00:00 AM	0
9/2/2014	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/2/2014	10:30:00 AM	0
9/2/2014	10:45:00 AM	0
9/2/2014	11:00:00 AM	0
9/2/2014	11:15:00 AM	0
9/2/2014	11:30:00 AM	0
9/2/2014	11:45:00 AM	0
9/2/2014	12:00:00 PM	0
9/2/2014	12:15:00 PM	0
9/2/2014	12:30:00 PM	0
9/2/2014	12:45:00 PM	0
9/2/2014	1:00:00 PM	0
9/2/2014	1:15:00 PM	0
9/2/2014	1:30:00 PM	0
9/2/2014	1:45:00 PM	0
9/2/2014	2:00:00 PM	0
9/2/2014	2:15:00 PM	0
9/2/2014	2:30:00 PM	0
9/2/2014	2:45:00 PM	0
9/2/2014	3:00:00 PM	0
9/2/2014	3:15:00 PM	0
9/2/2014	3:30:00 PM	0
9/2/2014	3:45:00 PM	0
9/2/2014	4:00:00 PM	0
9/2/2014	4:15:00 PM	0
9/2/2014	4:30:00 PM	0
9/2/2014	4:45:00 PM	0
9/2/2014	5:00:00 PM	0
9/2/2014	5:15:00 PM	0
9/2/2014	5:30:00 PM	0
9/2/2014	5:45:00 PM	0
9/2/2014	6:00:00 PM	0
9/2/2014	6:15:00 PM	0
9/2/2014	6:30:00 PM	0
9/2/2014	6:45:00 PM	0
9/2/2014	7:00:00 PM	0
9/2/2014	7:15:00 PM	0
9/2/2014	7:30:00 PM	0
9/2/2014	7:45:00 PM	0
9/2/2014	8:00:00 PM	0
9/2/2014	8:15:00 PM	0
9/2/2014	8:30:00 PM	0
9/2/2014	8:45:00 PM	0
9/2/2014	9:00:00 PM	0
9/2/2014	9:15:00 PM	0
9/2/2014	9:30:00 PM	0
9/2/2014	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/2/2014	10:00:00 PM	0
9/2/2014	10:15:00 PM	0
9/2/2014	10:30:00 PM	0
9/2/2014	10:45:00 PM	0
9/2/2014	11:00:00 PM	0
9/2/2014	11:15:00 PM	0
9/2/2014	11:30:00 PM	0
9/2/2014	11:45:00 PM	0
9/3/2014	12:00:00 AM	0
9/3/2014	12:15:00 AM	0
9/3/2014	12:30:00 AM	0
9/3/2014	12:45:00 AM	0
9/3/2014	1:00:00 AM	0
9/3/2014	1:15:00 AM	0
9/3/2014	1:30:00 AM	0
9/3/2014	1:45:00 AM	0
9/3/2014	2:00:00 AM	0
9/3/2014	2:15:00 AM	0
9/3/2014	2:30:00 AM	0
9/3/2014	2:45:00 AM	0
9/3/2014	3:00:00 AM	0
9/3/2014	3:15:00 AM	0
9/3/2014	3:30:00 AM	0
9/3/2014	3:45:00 AM	0
9/3/2014	4:00:00 AM	0
9/3/2014	4:15:00 AM	0
9/3/2014	4:30:00 AM	0
9/3/2014	4:45:00 AM	0
9/3/2014	5:00:00 AM	0
9/3/2014	5:15:00 AM	0
9/3/2014	5:30:00 AM	0
9/3/2014	5:45:00 AM	0
9/3/2014	6:00:00 AM	0
9/3/2014	6:15:00 AM	0
9/3/2014	6:30:00 AM	0
9/3/2014	6:45:00 AM	0
9/3/2014	7:00:00 AM	0
9/3/2014	7:15:00 AM	0
9/3/2014	7:30:00 AM	0
9/3/2014	7:45:00 AM	0
9/3/2014	8:00:00 AM	0
9/3/2014	8:15:00 AM	0
9/3/2014	8:30:00 AM	0
9/3/2014	8:45:00 AM	0
9/3/2014	9:00:00 AM	0
9/3/2014	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/3/2014	9:30:00 AM	0
9/3/2014	9:45:00 AM	0
9/3/2014	10:00:00 AM	0
9/3/2014	10:15:00 AM	0
9/3/2014	10:30:00 AM	0
9/3/2014	10:45:00 AM	0
9/3/2014	11:00:00 AM	0
9/3/2014	11:15:00 AM	0
9/3/2014	11:30:00 AM	0
9/3/2014	11:45:00 AM	0
9/3/2014	12:00:00 PM	0
9/3/2014	12:15:00 PM	0
9/3/2014	12:30:00 PM	0
9/3/2014	12:45:00 PM	0
9/3/2014	1:00:00 PM	0
9/3/2014	1:15:00 PM	0
9/3/2014	1:30:00 PM	0
9/3/2014	1:45:00 PM	0
9/3/2014	2:00:00 PM	0
9/3/2014	2:15:00 PM	0
9/3/2014	2:30:00 PM	0
9/3/2014	2:45:00 PM	0
9/3/2014	3:00:00 PM	0
9/3/2014	3:15:00 PM	0
9/3/2014	3:30:00 PM	0
9/3/2014	3:45:00 PM	0
9/3/2014	4:00:00 PM	0
9/3/2014	4:15:00 PM	0
9/3/2014	4:30:00 PM	0
9/3/2014	4:45:00 PM	0
9/3/2014	5:00:00 PM	0
9/3/2014	5:15:00 PM	0
9/3/2014	5:30:00 PM	0
9/3/2014	5:45:00 PM	0
9/3/2014	6:00:00 PM	0
9/3/2014	6:15:00 PM	0
9/3/2014	6:30:00 PM	0
9/3/2014	6:45:00 PM	0
9/3/2014	7:00:00 PM	0
9/3/2014	7:15:00 PM	0
9/3/2014	7:30:00 PM	0
9/3/2014	7:45:00 PM	0
9/3/2014	8:00:00 PM	0
9/3/2014	8:15:00 PM	0
9/3/2014	8:30:00 PM	0
9/3/2014	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/3/2014	9:00:00 PM	0
9/3/2014	9:15:00 PM	0
9/3/2014	9:30:00 PM	0
9/3/2014	9:45:00 PM	0
9/3/2014	10:00:00 PM	0
9/3/2014	10:15:00 PM	0
9/3/2014	10:30:00 PM	0
9/3/2014	10:45:00 PM	0
9/3/2014	11:00:00 PM	0
9/3/2014	11:15:00 PM	0
9/3/2014	11:30:00 PM	0
9/3/2014	11:45:00 PM	0
9/4/2014	12:00:00 AM	0
9/4/2014	12:15:00 AM	0
9/4/2014	12:30:00 AM	0
9/4/2014	12:45:00 AM	0
9/4/2014	1:00:00 AM	0
9/4/2014	1:15:00 AM	0
9/4/2014	1:30:00 AM	0
9/4/2014	1:45:00 AM	0
9/4/2014	2:00:00 AM	0
9/4/2014	2:15:00 AM	0
9/4/2014	2:30:00 AM	0
9/4/2014	2:45:00 AM	0
9/4/2014	3:00:00 AM	0
9/4/2014	3:15:00 AM	0
9/4/2014	3:30:00 AM	0
9/4/2014	3:45:00 AM	0
9/4/2014	4:00:00 AM	0
9/4/2014	4:15:00 AM	0
9/4/2014	4:30:00 AM	0
9/4/2014	4:45:00 AM	0
9/4/2014	5:00:00 AM	0
9/4/2014	5:15:00 AM	0
9/4/2014	5:30:00 AM	0
9/4/2014	5:45:00 AM	0
9/4/2014	6:00:00 AM	0
9/4/2014	6:15:00 AM	0
9/4/2014	6:30:00 AM	0
9/4/2014	6:45:00 AM	0
9/4/2014	7:00:00 AM	0
9/4/2014	7:15:00 AM	0
9/4/2014	7:30:00 AM	0
9/4/2014	7:45:00 AM	0
9/4/2014	8:00:00 AM	0
9/4/2014	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/4/2014	8:30:00 AM	0
9/4/2014	8:45:00 AM	0
9/4/2014	9:00:00 AM	0
9/4/2014	9:15:00 AM	0
9/4/2014	9:30:00 AM	0
9/4/2014	9:45:00 AM	0
9/4/2014	10:00:00 AM	0
9/4/2014	10:15:00 AM	0
9/4/2014	10:30:00 AM	0
9/4/2014	10:45:00 AM	0
9/4/2014	11:00:00 AM	0
9/4/2014	11:15:00 AM	0
9/4/2014	11:30:00 AM	0
9/4/2014	11:45:00 AM	0
9/4/2014	12:00:00 PM	0
9/4/2014	12:15:00 PM	0
9/4/2014	12:30:00 PM	0
9/4/2014	12:45:00 PM	0
9/4/2014	1:00:00 PM	0
9/4/2014	1:15:00 PM	0
9/4/2014	1:30:00 PM	0
9/4/2014	1:45:00 PM	0
9/4/2014	2:00:00 PM	0
9/4/2014	2:15:00 PM	0
9/4/2014	2:30:00 PM	0
9/4/2014	2:45:00 PM	0
9/4/2014	3:00:00 PM	0
9/4/2014	3:15:00 PM	0
9/4/2014	3:30:00 PM	0
9/4/2014	3:45:00 PM	0
9/4/2014	4:00:00 PM	0
9/4/2014	4:15:00 PM	0
9/4/2014	4:30:00 PM	0
9/4/2014	4:45:00 PM	0
9/4/2014	5:00:00 PM	0
9/4/2014	5:15:00 PM	0
9/4/2014	5:30:00 PM	0
9/4/2014	5:45:00 PM	0
9/4/2014	6:00:00 PM	0
9/4/2014	6:15:00 PM	0
9/4/2014	6:30:00 PM	0
9/4/2014	6:45:00 PM	0
9/4/2014	7:00:00 PM	0
9/4/2014	7:15:00 PM	0
9/4/2014	7:30:00 PM	0
9/4/2014	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/4/2014	8:00:00 PM	0
9/4/2014	8:15:00 PM	0
9/4/2014	8:30:00 PM	0
9/4/2014	8:45:00 PM	0
9/4/2014	9:00:00 PM	0
9/4/2014	9:15:00 PM	0
9/4/2014	9:30:00 PM	0
9/4/2014	9:45:00 PM	0
9/4/2014	10:00:00 PM	0
9/4/2014	10:15:00 PM	0
9/4/2014	10:30:00 PM	0
9/4/2014	10:45:00 PM	0
9/4/2014	11:00:00 PM	0
9/4/2014	11:15:00 PM	0
9/4/2014	11:30:00 PM	0
9/4/2014	11:45:00 PM	0
9/5/2014	12:00:00 AM	0
9/5/2014	12:15:00 AM	0
9/5/2014	12:30:00 AM	0
9/5/2014	12:45:00 AM	0
9/5/2014	1:00:00 AM	0
9/5/2014	1:15:00 AM	0
9/5/2014	1:30:00 AM	0
9/5/2014	1:45:00 AM	0
9/5/2014	2:00:00 AM	0
9/5/2014	2:15:00 AM	0
9/5/2014	2:30:00 AM	0
9/5/2014	2:45:00 AM	0
9/5/2014	3:00:00 AM	0
9/5/2014	3:15:00 AM	0
9/5/2014	3:30:00 AM	0
9/5/2014	3:45:00 AM	0
9/5/2014	4:00:00 AM	0
9/5/2014	4:15:00 AM	0
9/5/2014	4:30:00 AM	0
9/5/2014	4:45:00 AM	0
9/5/2014	5:00:00 AM	0
9/5/2014	5:15:00 AM	0
9/5/2014	5:30:00 AM	0
9/5/2014	5:45:00 AM	0
9/5/2014	6:00:00 AM	0
9/5/2014	6:15:00 AM	0
9/5/2014	6:30:00 AM	0
9/5/2014	6:45:00 AM	0
9/5/2014	7:00:00 AM	0
9/5/2014	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/5/2014	7:30:00 AM	0
9/5/2014	7:45:00 AM	0
9/5/2014	8:00:00 AM	0
9/5/2014	8:15:00 AM	0
9/5/2014	8:30:00 AM	0
9/5/2014	8:45:00 AM	0
9/5/2014	9:00:00 AM	0
9/5/2014	9:15:00 AM	0
9/5/2014	9:30:00 AM	0
9/5/2014	9:45:00 AM	0
9/5/2014	10:00:00 AM	0
9/5/2014	10:15:00 AM	0
9/5/2014	10:30:00 AM	0
9/5/2014	10:45:00 AM	0
9/5/2014	11:00:00 AM	0
9/5/2014	11:15:00 AM	0
9/5/2014	11:30:00 AM	0
9/5/2014	11:45:00 AM	0
9/5/2014	12:00:00 PM	0
9/5/2014	12:15:00 PM	0
9/5/2014	12:30:00 PM	0
9/5/2014	12:45:00 PM	0
9/5/2014	1:00:00 PM	0
9/5/2014	1:15:00 PM	0
9/5/2014	1:30:00 PM	0
9/5/2014	1:45:00 PM	0
9/5/2014	2:00:00 PM	0
9/5/2014	2:15:00 PM	0
9/5/2014	2:30:00 PM	0
9/5/2014	2:45:00 PM	0
9/5/2014	3:00:00 PM	0
9/5/2014	3:15:00 PM	0
9/5/2014	3:30:00 PM	0
9/5/2014	3:45:00 PM	0
9/5/2014	4:00:00 PM	0
9/5/2014	4:15:00 PM	0
9/5/2014	4:30:00 PM	0
9/5/2014	4:45:00 PM	0
9/5/2014	5:00:00 PM	0
9/5/2014	5:15:00 PM	0
9/5/2014	5:30:00 PM	0
9/5/2014	5:45:00 PM	0
9/5/2014	6:00:00 PM	0
9/5/2014	6:15:00 PM	0
9/5/2014	6:30:00 PM	0
9/5/2014	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/5/2014	7:00:00 PM	0
9/5/2014	7:15:00 PM	0
9/5/2014	7:30:00 PM	0
9/5/2014	7:45:00 PM	0
9/5/2014	8:00:00 PM	0
9/5/2014	8:15:00 PM	0
9/5/2014	8:30:00 PM	0
9/5/2014	8:45:00 PM	0
9/5/2014	9:00:00 PM	0
9/5/2014	9:15:00 PM	0
9/5/2014	9:30:00 PM	0
9/5/2014	9:45:00 PM	0
9/5/2014	10:00:00 PM	0
9/5/2014	10:15:00 PM	0
9/5/2014	10:30:00 PM	0
9/5/2014	10:45:00 PM	0
9/5/2014	11:00:00 PM	0
9/5/2014	11:15:00 PM	0
9/5/2014	11:30:00 PM	0
9/5/2014	11:45:00 PM	0
9/6/2014	12:00:00 AM	0
9/6/2014	12:15:00 AM	0
9/6/2014	12:30:00 AM	0
9/6/2014	12:45:00 AM	0
9/6/2014	1:00:00 AM	0
9/6/2014	1:15:00 AM	0
9/6/2014	1:30:00 AM	0
9/6/2014	1:45:00 AM	0
9/6/2014	2:00:00 AM	0
9/6/2014	2:15:00 AM	0
9/6/2014	2:30:00 AM	0
9/6/2014	2:45:00 AM	0
9/6/2014	3:00:00 AM	0
9/6/2014	3:15:00 AM	0
9/6/2014	3:30:00 AM	0
9/6/2014	3:45:00 AM	0
9/6/2014	4:00:00 AM	0
9/6/2014	4:15:00 AM	0
9/6/2014	4:30:00 AM	0
9/6/2014	4:45:00 AM	0
9/6/2014	5:00:00 AM	0
9/6/2014	5:15:00 AM	0
9/6/2014	5:30:00 AM	0
9/6/2014	5:45:00 AM	0
9/6/2014	6:00:00 AM	0
9/6/2014	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/6/2014	6:30:00 AM	0
9/6/2014	6:45:00 AM	0
9/6/2014	7:00:00 AM	0
9/6/2014	7:15:00 AM	0
9/6/2014	7:30:00 AM	0
9/6/2014	7:45:00 AM	0
9/6/2014	8:00:00 AM	0
9/6/2014	8:15:00 AM	0
9/6/2014	8:30:00 AM	0
9/6/2014	8:45:00 AM	0
9/6/2014	9:00:00 AM	0
9/6/2014	9:15:00 AM	0
9/6/2014	9:30:00 AM	0
9/6/2014	9:45:00 AM	0
9/6/2014	10:00:00 AM	0
9/6/2014	10:15:00 AM	0
9/6/2014	10:30:00 AM	0
9/6/2014	10:45:00 AM	0
9/6/2014	11:00:00 AM	0
9/6/2014	11:15:00 AM	0
9/6/2014	11:30:00 AM	0
9/6/2014	11:45:00 AM	0
9/6/2014	12:00:00 PM	0
9/6/2014	12:15:00 PM	0
9/6/2014	12:30:00 PM	0
9/6/2014	12:45:00 PM	0
9/6/2014	1:00:00 PM	0
9/6/2014	1:15:00 PM	0
9/6/2014	1:30:00 PM	0
9/6/2014	1:45:00 PM	0
9/6/2014	2:00:00 PM	0
9/6/2014	2:15:00 PM	0
9/6/2014	2:30:00 PM	0
9/6/2014	2:45:00 PM	0
9/6/2014	3:00:00 PM	0
9/6/2014	3:15:00 PM	0
9/6/2014	3:30:00 PM	0
9/6/2014	3:45:00 PM	0
9/6/2014	4:00:00 PM	0
9/6/2014	4:15:00 PM	0
9/6/2014	4:30:00 PM	0
9/6/2014	4:45:00 PM	0
9/6/2014	5:00:00 PM	0
9/6/2014	5:15:00 PM	0
9/6/2014	5:30:00 PM	0
9/6/2014	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/6/2014	6:00:00 PM	0
9/6/2014	6:15:00 PM	0
9/6/2014	6:30:00 PM	0
9/6/2014	6:45:00 PM	0
9/6/2014	7:00:00 PM	0
9/6/2014	7:15:00 PM	0
9/6/2014	7:30:00 PM	0
9/6/2014	7:45:00 PM	0
9/6/2014	8:00:00 PM	0
9/6/2014	8:15:00 PM	0
9/6/2014	8:30:00 PM	0
9/6/2014	8:45:00 PM	0
9/6/2014	9:00:00 PM	0
9/6/2014	9:15:00 PM	0
9/6/2014	9:30:00 PM	0
9/6/2014	9:45:00 PM	0
9/6/2014	10:00:00 PM	0
9/6/2014	10:15:00 PM	0
9/6/2014	10:30:00 PM	0
9/6/2014	10:45:00 PM	0
9/6/2014	11:00:00 PM	0
9/6/2014	11:15:00 PM	0
9/6/2014	11:30:00 PM	0
9/6/2014	11:45:00 PM	0
9/7/2014	12:00:00 AM	0
9/7/2014	12:15:00 AM	0
9/7/2014	12:30:00 AM	0
9/7/2014	12:45:00 AM	0
9/7/2014	1:00:00 AM	0
9/7/2014	1:15:00 AM	0
9/7/2014	1:30:00 AM	0
9/7/2014	1:45:00 AM	0
9/7/2014	2:00:00 AM	0
9/7/2014	2:15:00 AM	0
9/7/2014	2:30:00 AM	0
9/7/2014	2:45:00 AM	0
9/7/2014	3:00:00 AM	0
9/7/2014	3:15:00 AM	0
9/7/2014	3:30:00 AM	0
9/7/2014	3:45:00 AM	0
9/7/2014	4:00:00 AM	0
9/7/2014	4:15:00 AM	0
9/7/2014	4:30:00 AM	0
9/7/2014	4:45:00 AM	0
9/7/2014	5:00:00 AM	0
9/7/2014	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/7/2014	5:30:00 AM	0
9/7/2014	5:45:00 AM	0
9/7/2014	6:00:00 AM	0
9/7/2014	6:15:00 AM	0
9/7/2014	6:30:00 AM	0
9/7/2014	6:45:00 AM	0
9/7/2014	7:00:00 AM	0
9/7/2014	7:15:00 AM	0
9/7/2014	7:30:00 AM	0
9/7/2014	7:45:00 AM	0
9/7/2014	8:00:00 AM	0
9/7/2014	8:15:00 AM	0
9/7/2014	8:30:00 AM	0
9/7/2014	8:45:00 AM	0
9/7/2014	9:00:00 AM	0
9/7/2014	9:15:00 AM	0
9/7/2014	9:30:00 AM	0
9/7/2014	9:45:00 AM	0
9/7/2014	10:00:00 AM	0
9/7/2014	10:15:00 AM	0
9/7/2014	10:30:00 AM	0
9/7/2014	10:45:00 AM	0
9/7/2014	11:00:00 AM	0
9/7/2014	11:15:00 AM	0
9/7/2014	11:30:00 AM	0
9/7/2014	11:45:00 AM	0
9/7/2014	12:00:00 PM	0
9/7/2014	12:15:00 PM	0
9/7/2014	12:30:00 PM	0
9/7/2014	12:45:00 PM	0
9/7/2014	1:00:00 PM	0
9/7/2014	1:15:00 PM	0
9/7/2014	1:30:00 PM	0
9/7/2014	1:45:00 PM	0
9/7/2014	2:00:00 PM	0
9/7/2014	2:15:00 PM	0
9/7/2014	2:30:00 PM	0
9/7/2014	2:45:00 PM	0
9/7/2014	3:00:00 PM	0
9/7/2014	3:15:00 PM	0
9/7/2014	3:30:00 PM	0
9/7/2014	3:45:00 PM	0
9/7/2014	4:00:00 PM	0
9/7/2014	4:15:00 PM	0
9/7/2014	4:30:00 PM	0
9/7/2014	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/7/2014	5:00:00 PM	0
9/7/2014	5:15:00 PM	0
9/7/2014	5:30:00 PM	0
9/7/2014	5:45:00 PM	0
9/7/2014	6:00:00 PM	0
9/7/2014	6:15:00 PM	0
9/7/2014	6:30:00 PM	0
9/7/2014	6:45:00 PM	0
9/7/2014	7:00:00 PM	0
9/7/2014	7:15:00 PM	0
9/7/2014	7:30:00 PM	0
9/7/2014	7:45:00 PM	0
9/7/2014	8:00:00 PM	0
9/7/2014	8:15:00 PM	0
9/7/2014	8:30:00 PM	0
9/7/2014	8:45:00 PM	0
9/7/2014	9:00:00 PM	0
9/7/2014	9:15:00 PM	0
9/7/2014	9:30:00 PM	0
9/7/2014	9:45:00 PM	0
9/7/2014	10:00:00 PM	0
9/7/2014	10:15:00 PM	0
9/7/2014	10:30:00 PM	0
9/7/2014	10:45:00 PM	0
9/7/2014	11:00:00 PM	0
9/7/2014	11:15:00 PM	0
9/7/2014	11:30:00 PM	0
9/7/2014	11:45:00 PM	0
9/8/2014	12:00:00 AM	0
9/8/2014	12:15:00 AM	0
9/8/2014	12:30:00 AM	0
9/8/2014	12:45:00 AM	0
9/8/2014	1:00:00 AM	0
9/8/2014	1:15:00 AM	0
9/8/2014	1:30:00 AM	0
9/8/2014	1:45:00 AM	0
9/8/2014	2:00:00 AM	0
9/8/2014	2:15:00 AM	0
9/8/2014	2:30:00 AM	0
9/8/2014	2:45:00 AM	0
9/8/2014	3:00:00 AM	0
9/8/2014	3:15:00 AM	0
9/8/2014	3:30:00 AM	0
9/8/2014	3:45:00 AM	0
9/8/2014	4:00:00 AM	0
9/8/2014	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/8/2014	4:30:00 AM	0
9/8/2014	4:45:00 AM	0
9/8/2014	5:00:00 AM	0
9/8/2014	5:15:00 AM	0
9/8/2014	5:30:00 AM	0
9/8/2014	5:45:00 AM	0
9/8/2014	6:00:00 AM	0
9/8/2014	6:15:00 AM	0
9/8/2014	6:30:00 AM	0
9/8/2014	6:45:00 AM	0
9/8/2014	7:00:00 AM	0
9/8/2014	7:15:00 AM	0
9/8/2014	7:30:00 AM	0
9/8/2014	7:45:00 AM	0
9/8/2014	8:00:00 AM	0
9/8/2014	8:15:00 AM	0
9/8/2014	8:30:00 AM	0
9/8/2014	8:45:00 AM	0
9/8/2014	9:00:00 AM	0
9/8/2014	9:15:00 AM	0
9/8/2014	9:30:00 AM	0
9/8/2014	9:45:00 AM	0
9/8/2014	10:00:00 AM	0
9/8/2014	10:15:00 AM	0
9/8/2014	10:30:00 AM	0
9/8/2014	10:45:00 AM	0
9/8/2014	11:00:00 AM	0
9/8/2014	11:15:00 AM	0
9/8/2014	11:30:00 AM	0
9/8/2014	11:45:00 AM	0
9/8/2014	12:00:00 PM	0
9/8/2014	12:15:00 PM	0
9/8/2014	12:30:00 PM	0
9/8/2014	12:45:00 PM	0
9/8/2014	1:00:00 PM	0
9/8/2014	1:15:00 PM	0
9/8/2014	1:30:00 PM	0
9/8/2014	1:45:00 PM	0
9/8/2014	2:00:00 PM	0
9/8/2014	2:15:00 PM	0
9/8/2014	2:30:00 PM	0
9/8/2014	2:45:00 PM	0
9/8/2014	3:00:00 PM	0
9/8/2014	3:15:00 PM	0
9/8/2014	3:30:00 PM	0
9/8/2014	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/8/2014	4:00:00 PM	0
9/8/2014	4:15:00 PM	0
9/8/2014	4:30:00 PM	0
9/8/2014	4:45:00 PM	0
9/8/2014	5:00:00 PM	0
9/8/2014	5:15:00 PM	0
9/8/2014	5:30:00 PM	0
9/8/2014	5:45:00 PM	0
9/8/2014	6:00:00 PM	0
9/8/2014	6:15:00 PM	0
9/8/2014	6:30:00 PM	0
9/8/2014	6:45:00 PM	0
9/8/2014	7:00:00 PM	0
9/8/2014	7:15:00 PM	0
9/8/2014	7:30:00 PM	0
9/8/2014	7:45:00 PM	0
9/8/2014	8:00:00 PM	0
9/8/2014	8:15:00 PM	0
9/8/2014	8:30:00 PM	0
9/8/2014	8:45:00 PM	0
9/8/2014	9:00:00 PM	0
9/8/2014	9:15:00 PM	0
9/8/2014	9:30:00 PM	0
9/8/2014	9:45:00 PM	0
9/8/2014	10:00:00 PM	0
9/8/2014	10:15:00 PM	0
9/8/2014	10:30:00 PM	0
9/8/2014	10:45:00 PM	0
9/8/2014	11:00:00 PM	0
9/8/2014	11:15:00 PM	0
9/8/2014	11:30:00 PM	0
9/8/2014	11:45:00 PM	0
9/9/2014	12:00:00 AM	0
9/9/2014	12:15:00 AM	0
9/9/2014	12:30:00 AM	0
9/9/2014	12:45:00 AM	0
9/9/2014	1:00:00 AM	0
9/9/2014	1:15:00 AM	0
9/9/2014	1:30:00 AM	0
9/9/2014	1:45:00 AM	0
9/9/2014	2:00:00 AM	0
9/9/2014	2:15:00 AM	0
9/9/2014	2:30:00 AM	0
9/9/2014	2:45:00 AM	0
9/9/2014	3:00:00 AM	0
9/9/2014	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/9/2014	3:30:00 AM	0
9/9/2014	3:45:00 AM	0
9/9/2014	4:00:00 AM	0
9/9/2014	4:15:00 AM	0
9/9/2014	4:30:00 AM	0
9/9/2014	4:45:00 AM	0
9/9/2014	5:00:00 AM	0
9/9/2014	5:15:00 AM	0
9/9/2014	5:30:00 AM	0
9/9/2014	5:45:00 AM	0
9/9/2014	6:00:00 AM	0
9/9/2014	6:15:00 AM	0
9/9/2014	6:30:00 AM	0
9/9/2014	6:45:00 AM	0
9/9/2014	7:00:00 AM	0
9/9/2014	7:15:00 AM	0
9/9/2014	7:30:00 AM	0
9/9/2014	7:45:00 AM	0
9/9/2014	8:00:00 AM	0
9/9/2014	8:15:00 AM	0
9/9/2014	8:30:00 AM	0
9/9/2014	8:45:00 AM	0
9/9/2014	9:00:00 AM	0
9/9/2014	9:15:00 AM	0
9/9/2014	9:30:00 AM	0
9/9/2014	9:45:00 AM	0
9/9/2014	10:00:00 AM	0
9/9/2014	10:15:00 AM	0
9/9/2014	10:30:00 AM	0
9/9/2014	10:45:00 AM	0
9/9/2014	11:00:00 AM	0
9/9/2014	11:15:00 AM	0
9/9/2014	11:30:00 AM	0
9/9/2014	11:45:00 AM	0
9/9/2014	12:00:00 PM	0
9/9/2014	12:15:00 PM	0
9/9/2014	12:30:00 PM	0
9/9/2014	12:45:00 PM	0
9/9/2014	1:00:00 PM	0
9/9/2014	1:15:00 PM	0
9/9/2014	1:30:00 PM	0
9/9/2014	1:45:00 PM	0
9/9/2014	2:00:00 PM	0
9/9/2014	2:15:00 PM	0
9/9/2014	2:30:00 PM	0
9/9/2014	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/9/2014	3:00:00 PM	0
9/9/2014	3:15:00 PM	0
9/9/2014	3:30:00 PM	0
9/9/2014	3:45:00 PM	0
9/9/2014	4:00:00 PM	0
9/9/2014	4:15:00 PM	0
9/9/2014	4:30:00 PM	0
9/9/2014	4:45:00 PM	0
9/9/2014	5:00:00 PM	0
9/9/2014	5:15:00 PM	0
9/9/2014	5:30:00 PM	0
9/9/2014	5:45:00 PM	0
9/9/2014	6:00:00 PM	0
9/9/2014	6:15:00 PM	0
9/9/2014	6:30:00 PM	0
9/9/2014	6:45:00 PM	0
9/9/2014	7:00:00 PM	0
9/9/2014	7:15:00 PM	0
9/9/2014	7:30:00 PM	0
9/9/2014	7:45:00 PM	0
9/9/2014	8:00:00 PM	0
9/9/2014	8:15:00 PM	0
9/9/2014	8:30:00 PM	0
9/9/2014	8:45:00 PM	0
9/9/2014	9:00:00 PM	0
9/9/2014	9:15:00 PM	0
9/9/2014	9:30:00 PM	0
9/9/2014	9:45:00 PM	0
9/9/2014	10:00:00 PM	0
9/9/2014	10:15:00 PM	0
9/9/2014	10:30:00 PM	0
9/9/2014	10:45:00 PM	0
9/9/2014	11:00:00 PM	0
9/9/2014	11:15:00 PM	0
9/9/2014	11:30:00 PM	0
9/9/2014	11:45:00 PM	0
9/10/2014	12:00:00 AM	0
9/10/2014	12:15:00 AM	0
9/10/2014	12:30:00 AM	0
9/10/2014	12:45:00 AM	0
9/10/2014	1:00:00 AM	0
9/10/2014	1:15:00 AM	0
9/10/2014	1:30:00 AM	0
9/10/2014	1:45:00 AM	0
9/10/2014	2:00:00 AM	0
9/10/2014	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/10/2014	2:30:00 AM	0
9/10/2014	2:45:00 AM	0
9/10/2014	3:00:00 AM	0
9/10/2014	3:15:00 AM	0
9/10/2014	3:30:00 AM	0
9/10/2014	3:45:00 AM	0
9/10/2014	4:00:00 AM	0
9/10/2014	4:15:00 AM	0
9/10/2014	4:30:00 AM	0
9/10/2014	4:45:00 AM	0
9/10/2014	5:00:00 AM	0
9/10/2014	5:15:00 AM	0
9/10/2014	5:30:00 AM	0
9/10/2014	5:45:00 AM	0
9/10/2014	6:00:00 AM	0
9/10/2014	6:15:00 AM	0
9/10/2014	6:30:00 AM	0
9/10/2014	6:45:00 AM	0
9/10/2014	7:00:00 AM	0
9/10/2014	7:15:00 AM	0
9/10/2014	7:30:00 AM	0
9/10/2014	7:45:00 AM	0
9/10/2014	8:00:00 AM	0
9/10/2014	8:15:00 AM	0
9/10/2014	8:30:00 AM	0
9/10/2014	8:45:00 AM	0
9/10/2014	9:00:00 AM	0
9/10/2014	9:15:00 AM	0
9/10/2014	9:30:00 AM	0
9/10/2014	9:45:00 AM	0
9/10/2014	10:00:00 AM	0
9/10/2014	10:15:00 AM	0
9/10/2014	10:30:00 AM	0
9/10/2014	10:45:00 AM	0
9/10/2014	11:00:00 AM	0
9/10/2014	11:15:00 AM	0
9/10/2014	11:30:00 AM	0
9/10/2014	11:45:00 AM	0
9/10/2014	12:00:00 PM	0
9/10/2014	12:15:00 PM	0
9/10/2014	12:30:00 PM	0
9/10/2014	12:45:00 PM	0
9/10/2014	1:00:00 PM	0
9/10/2014	1:15:00 PM	0
9/10/2014	1:30:00 PM	0
9/10/2014	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/10/2014	2:00:00 PM	0
9/10/2014	2:15:00 PM	0
9/10/2014	2:30:00 PM	0
9/10/2014	2:45:00 PM	0
9/10/2014	3:00:00 PM	0
9/10/2014	3:15:00 PM	0
9/10/2014	3:30:00 PM	0
9/10/2014	3:45:00 PM	0
9/10/2014	4:00:00 PM	0
9/10/2014	4:15:00 PM	0
9/10/2014	4:30:00 PM	0
9/10/2014	4:45:00 PM	0
9/10/2014	5:00:00 PM	0
9/10/2014	5:15:00 PM	0
9/10/2014	5:30:00 PM	0
9/10/2014	5:45:00 PM	0
9/10/2014	6:00:00 PM	0
9/10/2014	6:15:00 PM	0
9/10/2014	6:30:00 PM	0
9/10/2014	6:45:00 PM	0
9/10/2014	7:00:00 PM	0
9/10/2014	7:15:00 PM	0
9/10/2014	7:30:00 PM	0
9/10/2014	7:45:00 PM	0
9/10/2014	8:00:00 PM	0
9/10/2014	8:15:00 PM	0
9/10/2014	8:30:00 PM	0
9/10/2014	8:45:00 PM	0
9/10/2014	9:00:00 PM	0
9/10/2014	9:15:00 PM	0
9/10/2014	9:30:00 PM	0
9/10/2014	9:45:00 PM	0
9/10/2014	10:00:00 PM	0
9/10/2014	10:15:00 PM	0
9/10/2014	10:30:00 PM	0
9/10/2014	10:45:00 PM	0
9/10/2014	11:00:00 PM	0
9/10/2014	11:15:00 PM	0
9/10/2014	11:30:00 PM	0
9/10/2014	11:45:00 PM	0
9/11/2014	12:00:00 AM	0
9/11/2014	12:15:00 AM	0
9/11/2014	12:30:00 AM	0
9/11/2014	12:45:00 AM	0
9/11/2014	1:00:00 AM	0
9/11/2014	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/11/2014	1:30:00 AM	0
9/11/2014	1:45:00 AM	0
9/11/2014	2:00:00 AM	0
9/11/2014	2:15:00 AM	0
9/11/2014	2:30:00 AM	0
9/11/2014	2:45:00 AM	0
9/11/2014	3:00:00 AM	0
9/11/2014	3:15:00 AM	0
9/11/2014	3:30:00 AM	0
9/11/2014	3:45:00 AM	0
9/11/2014	4:00:00 AM	0
9/11/2014	4:15:00 AM	0
9/11/2014	4:30:00 AM	0
9/11/2014	4:45:00 AM	0
9/11/2014	5:00:00 AM	0
9/11/2014	5:15:00 AM	0
9/11/2014	5:30:00 AM	0
9/11/2014	5:45:00 AM	0
9/11/2014	6:00:00 AM	0
9/11/2014	6:15:00 AM	0
9/11/2014	6:30:00 AM	0
9/11/2014	6:45:00 AM	0
9/11/2014	7:00:00 AM	0
9/11/2014	7:15:00 AM	0
9/11/2014	7:30:00 AM	0
9/11/2014	7:45:00 AM	0
9/11/2014	8:00:00 AM	0
9/11/2014	8:15:00 AM	0
9/11/2014	8:30:00 AM	0
9/11/2014	8:45:00 AM	0
9/11/2014	9:00:00 AM	0
9/11/2014	9:15:00 AM	0
9/11/2014	9:30:00 AM	0
9/11/2014	9:45:00 AM	0
9/11/2014	10:00:00 AM	0
9/11/2014	10:15:00 AM	0
9/11/2014	10:30:00 AM	0
9/11/2014	10:45:00 AM	0
9/11/2014	11:00:00 AM	0
9/11/2014	11:15:00 AM	0
9/11/2014	11:30:00 AM	0
9/11/2014	11:45:00 AM	0
9/11/2014	12:00:00 PM	0
9/11/2014	12:15:00 PM	0
9/11/2014	12:30:00 PM	0
9/11/2014	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/11/2014	1:00:00 PM	0
9/11/2014	1:15:00 PM	0
9/11/2014	1:30:00 PM	0
9/11/2014	1:45:00 PM	0
9/11/2014	2:00:00 PM	0
9/11/2014	2:15:00 PM	0
9/11/2014	2:30:00 PM	0
9/11/2014	2:45:00 PM	0
9/11/2014	3:00:00 PM	0
9/11/2014	3:15:00 PM	0
9/11/2014	3:30:00 PM	0
9/11/2014	3:45:00 PM	0
9/11/2014	4:00:00 PM	0
9/11/2014	4:15:00 PM	0
9/11/2014	4:30:00 PM	0
9/11/2014	4:45:00 PM	0
9/11/2014	5:00:00 PM	0
9/11/2014	5:15:00 PM	0
9/11/2014	5:30:00 PM	0
9/11/2014	5:45:00 PM	0
9/11/2014	6:00:00 PM	0
9/11/2014	6:15:00 PM	0
9/11/2014	6:30:00 PM	0
9/11/2014	6:45:00 PM	0
9/11/2014	7:00:00 PM	0
9/11/2014	7:15:00 PM	0
9/11/2014	7:30:00 PM	0
9/11/2014	7:45:00 PM	0
9/11/2014	8:00:00 PM	0
9/11/2014	8:15:00 PM	0
9/11/2014	8:30:00 PM	0
9/11/2014	8:45:00 PM	0
9/11/2014	9:00:00 PM	0
9/11/2014	9:15:00 PM	0
9/11/2014	9:30:00 PM	0
9/11/2014	9:45:00 PM	0
9/11/2014	10:00:00 PM	0
9/11/2014	10:15:00 PM	0
9/11/2014	10:30:00 PM	0
9/11/2014	10:45:00 PM	0
9/11/2014	11:00:00 PM	0
9/11/2014	11:15:00 PM	0
9/11/2014	11:30:00 PM	0
9/11/2014	11:45:00 PM	0
9/12/2014	12:00:00 AM	0
9/12/2014	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	12:30:00 AM	0
9/12/2014	12:45:00 AM	0
9/12/2014	1:00:00 AM	0
9/12/2014	1:15:00 AM	0
9/12/2014	1:30:00 AM	0
9/12/2014	1:45:00 AM	0
9/12/2014	2:00:00 AM	0
9/12/2014	2:15:00 AM	0
9/12/2014	2:30:00 AM	0
9/12/2014	2:45:00 AM	0
9/12/2014	3:00:00 AM	0
9/12/2014	3:15:00 AM	0
9/12/2014	3:30:00 AM	0
9/12/2014	3:45:00 AM	0
9/12/2014	4:00:00 AM	0
9/12/2014	4:15:00 AM	0
9/12/2014	4:30:00 AM	0
9/12/2014	4:45:00 AM	0
9/12/2014	5:00:00 AM	0
9/12/2014	5:15:00 AM	0
9/12/2014	5:30:00 AM	0
9/12/2014	5:45:00 AM	0
9/12/2014	6:00:00 AM	0
9/12/2014	6:15:00 AM	0
9/12/2014	6:30:00 AM	0
9/12/2014	6:45:00 AM	0
9/12/2014	7:00:00 AM	0
9/12/2014	7:15:00 AM	0
9/12/2014	7:30:00 AM	0
9/12/2014	7:45:00 AM	0
9/12/2014	8:00:00 AM	0
9/12/2014	8:15:00 AM	0
9/12/2014	8:30:00 AM	0
9/12/2014	8:45:00 AM	0
9/12/2014	9:00:00 AM	0
9/12/2014	9:15:00 AM	0
9/12/2014	9:30:00 AM	0
9/12/2014	9:45:00 AM	0
9/12/2014	10:00:00 AM	0
9/12/2014	10:15:00 AM	0
9/12/2014	10:30:00 AM	0
9/12/2014	10:45:00 AM	0
9/12/2014	11:00:00 AM	0
9/12/2014	11:15:00 AM	0
9/12/2014	11:30:00 AM	0
9/12/2014	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	12:00:00 PM	0
9/12/2014	12:15:00 PM	0
9/12/2014	12:30:00 PM	0
9/12/2014	12:45:00 PM	0
9/12/2014	1:00:00 PM	0
9/12/2014	1:15:00 PM	0
9/12/2014	1:30:00 PM	0
9/12/2014	1:45:00 PM	0
9/12/2014	2:00:00 PM	0
9/12/2014	2:15:00 PM	0
9/12/2014	2:30:00 PM	0
9/12/2014	2:45:00 PM	0
9/12/2014	3:00:00 PM	0
9/12/2014	3:15:00 PM	0
9/12/2014	3:30:00 PM	0
9/12/2014	3:45:00 PM	0
9/12/2014	4:00:00 PM	0
9/12/2014	4:15:00 PM	0
9/12/2014	4:30:00 PM	0
9/12/2014	4:45:00 PM	0
9/12/2014	5:00:00 PM	0
9/12/2014	5:15:00 PM	0
9/12/2014	5:30:00 PM	0
9/12/2014	5:45:00 PM	0
9/12/2014	6:00:00 PM	0
9/12/2014	6:15:00 PM	0
9/12/2014	6:30:00 PM	0
9/12/2014	6:45:00 PM	0
9/12/2014	7:00:00 PM	0
9/12/2014	7:15:00 PM	0
9/12/2014	7:30:00 PM	0
9/12/2014	7:45:00 PM	0
9/12/2014	8:00:00 PM	0
9/12/2014	8:15:00 PM	0
9/12/2014	8:30:00 PM	0
9/12/2014	8:45:00 PM	0
9/12/2014	9:00:00 PM	0
9/12/2014	9:15:00 PM	0
9/12/2014	9:30:00 PM	0
9/12/2014	9:45:00 PM	0
9/12/2014	10:00:00 PM	0
9/12/2014	10:15:00 PM	0
9/12/2014	10:30:00 PM	0
9/12/2014	10:45:00 PM	0
9/12/2014	11:00:00 PM	0
9/12/2014	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	11:30:00 PM	0
9/12/2014	11:45:00 PM	0
9/13/2014	12:00:00 AM	0
9/13/2014	12:15:00 AM	0
9/13/2014	12:30:00 AM	0
9/13/2014	12:45:00 AM	0
9/13/2014	1:00:00 AM	0
9/13/2014	1:15:00 AM	0
9/13/2014	1:30:00 AM	0
9/13/2014	1:45:00 AM	0
9/13/2014	2:00:00 AM	0
9/13/2014	2:15:00 AM	0
9/13/2014	2:30:00 AM	0
9/13/2014	2:45:00 AM	0
9/13/2014	3:00:00 AM	0
9/13/2014	3:15:00 AM	0
9/13/2014	3:30:00 AM	0
9/13/2014	3:45:00 AM	0
9/13/2014	4:00:00 AM	0
9/13/2014	4:15:00 AM	0
9/13/2014	4:30:00 AM	0
9/13/2014	4:45:00 AM	0
9/13/2014	5:00:00 AM	0
9/13/2014	5:15:00 AM	0
9/13/2014	5:30:00 AM	0
9/13/2014	5:45:00 AM	0
9/13/2014	6:00:00 AM	0
9/13/2014	6:15:00 AM	0
9/13/2014	6:30:00 AM	0
9/13/2014	6:45:00 AM	0
9/13/2014	7:00:00 AM	0
9/13/2014	7:15:00 AM	0
9/13/2014	7:30:00 AM	0
9/13/2014	7:45:00 AM	0
9/13/2014	8:00:00 AM	0
9/13/2014	8:15:00 AM	0
9/13/2014	8:30:00 AM	0
9/13/2014	8:45:00 AM	0
9/13/2014	9:00:00 AM	0
9/13/2014	9:15:00 AM	0
9/13/2014	9:30:00 AM	0
9/13/2014	9:45:00 AM	0
9/13/2014	10:00:00 AM	0
9/13/2014	10:15:00 AM	0
9/13/2014	10:30:00 AM	0
9/13/2014	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/13/2014	11:00:00 AM	0
9/13/2014	11:15:00 AM	0
9/13/2014	11:30:00 AM	0
9/13/2014	11:45:00 AM	0
9/13/2014	12:00:00 PM	0
9/13/2014	12:15:00 PM	0
9/13/2014	12:30:00 PM	0
9/13/2014	12:45:00 PM	0
9/13/2014	1:00:00 PM	0
9/13/2014	1:15:00 PM	0
9/13/2014	1:30:00 PM	0
9/13/2014	1:45:00 PM	0
9/13/2014	2:00:00 PM	0
9/13/2014	2:15:00 PM	0
9/13/2014	2:30:00 PM	0
9/13/2014	2:45:00 PM	0
9/13/2014	3:00:00 PM	0
9/13/2014	3:15:00 PM	0
9/13/2014	3:30:00 PM	0
9/13/2014	3:45:00 PM	0
9/13/2014	4:00:00 PM	0
9/13/2014	4:15:00 PM	0
9/13/2014	4:30:00 PM	0
9/13/2014	4:45:00 PM	0
9/13/2014	5:00:00 PM	0
9/13/2014	5:15:00 PM	0
9/13/2014	5:30:00 PM	0
9/13/2014	5:45:00 PM	0
9/13/2014	6:00:00 PM	0
9/13/2014	6:15:00 PM	0
9/13/2014	6:30:00 PM	0
9/13/2014	6:45:00 PM	0
9/13/2014	7:00:00 PM	0
9/13/2014	7:15:00 PM	0
9/13/2014	7:30:00 PM	0
9/13/2014	7:45:00 PM	0
9/13/2014	8:00:00 PM	0
9/13/2014	8:15:00 PM	0
9/13/2014	8:30:00 PM	0
9/13/2014	8:45:00 PM	0
9/13/2014	9:00:00 PM	0
9/13/2014	9:15:00 PM	0
9/13/2014	9:30:00 PM	0
9/13/2014	9:45:00 PM	0
9/13/2014	10:00:00 PM	0
9/13/2014	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/13/2014	10:30:00 PM	0
9/13/2014	10:45:00 PM	0
9/13/2014	11:00:00 PM	0
9/13/2014	11:15:00 PM	0
9/13/2014	11:30:00 PM	0
9/13/2014	11:45:00 PM	0
9/14/2014	12:00:00 AM	0
9/14/2014	12:15:00 AM	0
9/14/2014	12:30:00 AM	0
9/14/2014	12:45:00 AM	0
9/14/2014	1:00:00 AM	0
9/14/2014	1:15:00 AM	0
9/14/2014	1:30:00 AM	0
9/14/2014	1:45:00 AM	0
9/14/2014	2:00:00 AM	0
9/14/2014	2:15:00 AM	0
9/14/2014	2:30:00 AM	0
9/14/2014	2:45:00 AM	0
9/14/2014	3:00:00 AM	0
9/14/2014	3:15:00 AM	0
9/14/2014	3:30:00 AM	0
9/14/2014	3:45:00 AM	0
9/14/2014	4:00:00 AM	0
9/14/2014	4:15:00 AM	0
9/14/2014	4:30:00 AM	0
9/14/2014	4:45:00 AM	0
9/14/2014	5:00:00 AM	0
9/14/2014	5:15:00 AM	0
9/14/2014	5:30:00 AM	0
9/14/2014	5:45:00 AM	0
9/14/2014	6:00:00 AM	0
9/14/2014	6:15:00 AM	0
9/14/2014	6:30:00 AM	0
9/14/2014	6:45:00 AM	0
9/14/2014	7:00:00 AM	0
9/14/2014	7:15:00 AM	0
9/14/2014	7:30:00 AM	0
9/14/2014	7:45:00 AM	0
9/14/2014	8:00:00 AM	0
9/14/2014	8:15:00 AM	0
9/14/2014	8:30:00 AM	0
9/14/2014	8:45:00 AM	0
9/14/2014	9:00:00 AM	0
9/14/2014	9:15:00 AM	0
9/14/2014	9:30:00 AM	0
9/14/2014	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/14/2014	10:00:00 AM	0
9/14/2014	10:15:00 AM	0
9/14/2014	10:30:00 AM	0
9/14/2014	10:45:00 AM	0
9/14/2014	11:00:00 AM	0
9/14/2014	11:15:00 AM	0
9/14/2014	11:30:00 AM	0
9/14/2014	11:45:00 AM	0
9/14/2014	12:00:00 PM	0
9/14/2014	12:15:00 PM	0
9/14/2014	12:30:00 PM	0
9/14/2014	12:45:00 PM	0
9/14/2014	1:00:00 PM	0
9/14/2014	1:15:00 PM	0
9/14/2014	1:30:00 PM	0
9/14/2014	1:45:00 PM	0
9/14/2014	2:00:00 PM	0
9/14/2014	2:15:00 PM	0
9/14/2014	2:30:00 PM	0
9/14/2014	2:45:00 PM	0
9/14/2014	3:00:00 PM	0
9/14/2014	3:15:00 PM	0
9/14/2014	3:30:00 PM	0
9/14/2014	3:45:00 PM	0
9/14/2014	4:00:00 PM	0
9/14/2014	4:15:00 PM	0
9/14/2014	4:30:00 PM	0
9/14/2014	4:45:00 PM	0
9/14/2014	5:00:00 PM	0
9/14/2014	5:15:00 PM	0
9/14/2014	5:30:00 PM	0
9/14/2014	5:45:00 PM	0
9/14/2014	6:00:00 PM	0
9/14/2014	6:15:00 PM	0
9/14/2014	6:30:00 PM	0
9/14/2014	6:45:00 PM	0
9/14/2014	7:00:00 PM	0
9/14/2014	7:15:00 PM	0
9/14/2014	7:30:00 PM	0
9/14/2014	7:45:00 PM	0
9/14/2014	8:00:00 PM	0
9/14/2014	8:15:00 PM	0
9/14/2014	8:30:00 PM	0
9/14/2014	8:45:00 PM	0
9/14/2014	9:00:00 PM	0
9/14/2014	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/14/2014	9:30:00 PM	0
9/14/2014	9:45:00 PM	0
9/14/2014	10:00:00 PM	0
9/14/2014	10:15:00 PM	0
9/14/2014	10:30:00 PM	0
9/14/2014	10:45:00 PM	0
9/14/2014	11:00:00 PM	0
9/14/2014	11:15:00 PM	0
9/14/2014	11:30:00 PM	0
9/14/2014	11:45:00 PM	0
9/15/2014	12:00:00 AM	0
9/15/2014	12:15:00 AM	0
9/15/2014	12:30:00 AM	0
9/15/2014	12:45:00 AM	0
9/15/2014	1:00:00 AM	0
9/15/2014	1:15:00 AM	0
9/15/2014	1:30:00 AM	0
9/15/2014	1:45:00 AM	0
9/15/2014	2:00:00 AM	0
9/15/2014	2:15:00 AM	0
9/15/2014	2:30:00 AM	0
9/15/2014	2:45:00 AM	0
9/15/2014	3:00:00 AM	0
9/15/2014	3:15:00 AM	0
9/15/2014	3:30:00 AM	0
9/15/2014	3:45:00 AM	0
9/15/2014	4:00:00 AM	0
9/15/2014	4:15:00 AM	0
9/15/2014	4:30:00 AM	0
9/15/2014	4:45:00 AM	0
9/15/2014	5:00:00 AM	0
9/15/2014	5:15:00 AM	0
9/15/2014	5:30:00 AM	0
9/15/2014	5:45:00 AM	0
9/15/2014	6:00:00 AM	0
9/15/2014	6:15:00 AM	0
9/15/2014	6:30:00 AM	0
9/15/2014	6:45:00 AM	0
9/15/2014	7:00:00 AM	0
9/15/2014	7:15:00 AM	0
9/15/2014	7:30:00 AM	0
9/15/2014	7:45:00 AM	0
9/15/2014	8:00:00 AM	0
9/15/2014	8:15:00 AM	0
9/15/2014	8:30:00 AM	0
9/15/2014	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/15/2014	9:00:00 AM	0
9/15/2014	9:15:00 AM	0
9/15/2014	9:30:00 AM	0
9/15/2014	9:45:00 AM	0
9/15/2014	10:00:00 AM	0
9/15/2014	10:15:00 AM	0
9/15/2014	10:30:00 AM	0
9/15/2014	10:45:00 AM	0
9/15/2014	11:00:00 AM	0
9/15/2014	11:15:00 AM	0
9/15/2014	11:30:00 AM	0
9/15/2014	11:45:00 AM	0
9/15/2014	12:00:00 PM	0
9/15/2014	12:15:00 PM	0
9/15/2014	12:30:00 PM	0
9/15/2014	12:45:00 PM	0
9/15/2014	1:00:00 PM	0
9/15/2014	1:15:00 PM	0
9/15/2014	1:30:00 PM	0
9/15/2014	1:45:00 PM	0
9/15/2014	2:00:00 PM	0
9/15/2014	2:15:00 PM	0
9/15/2014	2:30:00 PM	0
9/15/2014	2:45:00 PM	0
9/15/2014	3:00:00 PM	0
9/15/2014	3:15:00 PM	0
9/15/2014	3:30:00 PM	0
9/15/2014	3:45:00 PM	0
9/15/2014	4:00:00 PM	0
9/15/2014	4:15:00 PM	0
9/15/2014	4:30:00 PM	0
9/15/2014	4:45:00 PM	0
9/15/2014	5:00:00 PM	0
9/15/2014	5:15:00 PM	0
9/15/2014	5:30:00 PM	0
9/15/2014	5:45:00 PM	0
9/15/2014	6:00:00 PM	0
9/15/2014	6:15:00 PM	0
9/15/2014	6:30:00 PM	0
9/15/2014	6:45:00 PM	0
9/15/2014	7:00:00 PM	0
9/15/2014	7:15:00 PM	0
9/15/2014	7:30:00 PM	0
9/15/2014	7:45:00 PM	0
9/15/2014	8:00:00 PM	0
9/15/2014	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/15/2014	8:30:00 PM	0
9/15/2014	8:45:00 PM	0
9/15/2014	9:00:00 PM	0
9/15/2014	9:15:00 PM	0
9/15/2014	9:30:00 PM	0
9/15/2014	9:45:00 PM	0
9/15/2014	10:00:00 PM	0
9/15/2014	10:15:00 PM	0
9/15/2014	10:30:00 PM	0
9/15/2014	10:45:00 PM	0
9/15/2014	11:00:00 PM	0
9/15/2014	11:15:00 PM	0
9/15/2014	11:30:00 PM	0
9/15/2014	11:45:00 PM	0
9/16/2014	12:00:00 AM	0
9/16/2014	12:15:00 AM	0
9/16/2014	12:30:00 AM	0
9/16/2014	12:45:00 AM	0
9/16/2014	1:00:00 AM	0
9/16/2014	1:15:00 AM	0
9/16/2014	1:30:00 AM	0
9/16/2014	1:45:00 AM	0
9/16/2014	2:00:00 AM	0
9/16/2014	2:15:00 AM	0
9/16/2014	2:30:00 AM	0
9/16/2014	2:45:00 AM	0
9/16/2014	3:00:00 AM	0
9/16/2014	3:15:00 AM	0
9/16/2014	3:30:00 AM	0
9/16/2014	3:45:00 AM	0
9/16/2014	4:00:00 AM	0
9/16/2014	4:15:00 AM	0
9/16/2014	4:30:00 AM	0
9/16/2014	4:45:00 AM	0
9/16/2014	5:00:00 AM	0
9/16/2014	5:15:00 AM	0
9/16/2014	5:30:00 AM	0
9/16/2014	5:45:00 AM	0
9/16/2014	6:00:00 AM	0
9/16/2014	6:15:00 AM	0
9/16/2014	6:30:00 AM	0
9/16/2014	6:45:00 AM	0
9/16/2014	7:00:00 AM	0
9/16/2014	7:15:00 AM	0
9/16/2014	7:30:00 AM	0
9/16/2014	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/16/2014	8:00:00 AM	0
9/16/2014	8:15:00 AM	0
9/16/2014	8:30:00 AM	0
9/16/2014	8:45:00 AM	0
9/16/2014	9:00:00 AM	0
9/16/2014	9:15:00 AM	0
9/16/2014	9:30:00 AM	0
9/16/2014	9:45:00 AM	0
9/16/2014	10:00:00 AM	0
9/16/2014	10:15:00 AM	0
9/16/2014	10:30:00 AM	0
9/16/2014	10:45:00 AM	0
9/16/2014	11:00:00 AM	0
9/16/2014	11:15:00 AM	0
9/16/2014	11:30:00 AM	0
9/16/2014	11:45:00 AM	0
9/16/2014	12:00:00 PM	0
9/16/2014	12:15:00 PM	0
9/16/2014	12:30:00 PM	0
9/16/2014	12:45:00 PM	0
9/16/2014	1:00:00 PM	0
9/16/2014	1:15:00 PM	0
9/16/2014	1:30:00 PM	0
9/16/2014	1:45:00 PM	0
9/16/2014	2:00:00 PM	0
9/16/2014	2:15:00 PM	0
9/16/2014	2:30:00 PM	0
9/16/2014	2:45:00 PM	0
9/16/2014	3:00:00 PM	0
9/16/2014	3:15:00 PM	0
9/16/2014	3:30:00 PM	0
9/16/2014	3:45:00 PM	0
9/16/2014	4:00:00 PM	0
9/16/2014	4:15:00 PM	0
9/16/2014	4:30:00 PM	0
9/16/2014	4:45:00 PM	0
9/16/2014	5:00:00 PM	0
9/16/2014	5:15:00 PM	0
9/16/2014	5:30:00 PM	0
9/16/2014	5:45:00 PM	0
9/16/2014	6:00:00 PM	0
9/16/2014	6:15:00 PM	0
9/16/2014	6:30:00 PM	0
9/16/2014	6:45:00 PM	0
9/16/2014	7:00:00 PM	0
9/16/2014	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/16/2014	7:30:00 PM	0
9/16/2014	7:45:00 PM	0
9/16/2014	8:00:00 PM	0
9/16/2014	8:15:00 PM	0
9/16/2014	8:30:00 PM	0
9/16/2014	8:45:00 PM	0
9/16/2014	9:00:00 PM	0
9/16/2014	9:15:00 PM	0
9/16/2014	9:30:00 PM	0
9/16/2014	9:45:00 PM	0
9/16/2014	10:00:00 PM	0
9/16/2014	10:15:00 PM	0
9/16/2014	10:30:00 PM	0
9/16/2014	10:45:00 PM	0
9/16/2014	11:00:00 PM	0
9/16/2014	11:15:00 PM	0
9/16/2014	11:30:00 PM	0
9/16/2014	11:45:00 PM	0
9/17/2014	12:00:00 AM	0
9/17/2014	12:15:00 AM	0
9/17/2014	12:30:00 AM	0
9/17/2014	12:45:00 AM	0
9/17/2014	1:00:00 AM	0
9/17/2014	1:15:00 AM	0
9/17/2014	1:30:00 AM	0
9/17/2014	1:45:00 AM	0
9/17/2014	2:00:00 AM	0
9/17/2014	2:15:00 AM	0
9/17/2014	2:30:00 AM	0
9/17/2014	2:45:00 AM	0
9/17/2014	3:00:00 AM	0
9/17/2014	3:15:00 AM	0
9/17/2014	3:30:00 AM	0
9/17/2014	3:45:00 AM	0
9/17/2014	4:00:00 AM	0
9/17/2014	4:15:00 AM	0
9/17/2014	4:30:00 AM	0
9/17/2014	4:45:00 AM	0
9/17/2014	5:00:00 AM	0
9/17/2014	5:15:00 AM	0
9/17/2014	5:30:00 AM	0
9/17/2014	5:45:00 AM	0
9/17/2014	6:00:00 AM	0
9/17/2014	6:15:00 AM	0
9/17/2014	6:30:00 AM	0
9/17/2014	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/17/2014	7:00:00 AM	0
9/17/2014	7:15:00 AM	0
9/17/2014	7:30:00 AM	0
9/17/2014	7:45:00 AM	0
9/17/2014	8:00:00 AM	0
9/17/2014	8:15:00 AM	0
9/17/2014	8:30:00 AM	0
9/17/2014	8:45:00 AM	0
9/17/2014	9:00:00 AM	0
9/17/2014	9:15:00 AM	0
9/17/2014	9:30:00 AM	0
9/17/2014	9:45:00 AM	0
9/17/2014	10:00:00 AM	0
9/17/2014	10:15:00 AM	0
9/17/2014	10:30:00 AM	0
9/17/2014	10:45:00 AM	0
9/17/2014	11:00:00 AM	0
9/17/2014	11:15:00 AM	0
9/17/2014	11:30:00 AM	0
9/17/2014	11:45:00 AM	0
9/17/2014	12:00:00 PM	0
9/17/2014	12:15:00 PM	0
9/17/2014	12:30:00 PM	0
9/17/2014	12:45:00 PM	0
9/17/2014	1:00:00 PM	0
9/17/2014	1:15:00 PM	0
9/17/2014	1:30:00 PM	0
9/17/2014	1:45:00 PM	0
9/17/2014	2:00:00 PM	0
9/17/2014	2:15:00 PM	0
9/17/2014	2:30:00 PM	0
9/17/2014	2:45:00 PM	0
9/17/2014	3:00:00 PM	0
9/17/2014	3:15:00 PM	0
9/17/2014	3:30:00 PM	0
9/17/2014	3:45:00 PM	0
9/17/2014	4:00:00 PM	0
9/17/2014	4:15:00 PM	0
9/17/2014	4:30:00 PM	0
9/17/2014	4:45:00 PM	0
9/17/2014	5:00:00 PM	0
9/17/2014	5:15:00 PM	0
9/17/2014	5:30:00 PM	0
9/17/2014	5:45:00 PM	0
9/17/2014	6:00:00 PM	0
9/17/2014	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/17/2014	6:30:00 PM	0
9/17/2014	6:45:00 PM	0
9/17/2014	7:00:00 PM	0
9/17/2014	7:15:00 PM	0
9/17/2014	7:30:00 PM	0
9/17/2014	7:45:00 PM	0
9/17/2014	8:00:00 PM	0
9/17/2014	8:15:00 PM	0
9/17/2014	8:30:00 PM	0
9/17/2014	8:45:00 PM	0
9/17/2014	9:00:00 PM	0
9/17/2014	9:15:00 PM	0
9/17/2014	9:30:00 PM	0
9/17/2014	9:45:00 PM	0
9/17/2014	10:00:00 PM	0
9/17/2014	10:15:00 PM	0
9/17/2014	10:30:00 PM	0
9/17/2014	10:45:00 PM	0
9/17/2014	11:00:00 PM	0
9/17/2014	11:15:00 PM	0
9/17/2014	11:30:00 PM	0
9/17/2014	11:45:00 PM	0
9/18/2014	12:00:00 AM	0
9/18/2014	12:15:00 AM	0
9/18/2014	12:30:00 AM	0
9/18/2014	12:45:00 AM	0
9/18/2014	1:00:00 AM	0
9/18/2014	1:15:00 AM	0
9/18/2014	1:30:00 AM	0
9/18/2014	1:45:00 AM	0
9/18/2014	2:00:00 AM	0
9/18/2014	2:15:00 AM	0
9/18/2014	2:30:00 AM	0
9/18/2014	2:45:00 AM	0
9/18/2014	3:00:00 AM	0
9/18/2014	3:15:00 AM	0
9/18/2014	3:30:00 AM	0
9/18/2014	3:45:00 AM	0
9/18/2014	4:00:00 AM	0
9/18/2014	4:15:00 AM	0
9/18/2014	4:30:00 AM	0
9/18/2014	4:45:00 AM	0
9/18/2014	5:00:00 AM	0
9/18/2014	5:15:00 AM	0
9/18/2014	5:30:00 AM	0
9/18/2014	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/18/2014	6:00:00 AM	0
9/18/2014	6:15:00 AM	0
9/18/2014	6:30:00 AM	0
9/18/2014	6:45:00 AM	0
9/18/2014	7:00:00 AM	0
9/18/2014	7:15:00 AM	0
9/18/2014	7:30:00 AM	0
9/18/2014	7:45:00 AM	0
9/18/2014	8:00:00 AM	0
9/18/2014	8:15:00 AM	0
9/18/2014	8:30:00 AM	0
9/18/2014	8:45:00 AM	0
9/18/2014	9:00:00 AM	0
9/18/2014	9:15:00 AM	0
9/18/2014	9:30:00 AM	0
9/18/2014	9:45:00 AM	0
9/18/2014	10:00:00 AM	0
9/18/2014	10:15:00 AM	0
9/18/2014	10:30:00 AM	0
9/18/2014	10:45:00 AM	0
9/18/2014	11:00:00 AM	0
9/18/2014	11:15:00 AM	0
9/18/2014	11:30:00 AM	0
9/18/2014	11:45:00 AM	0
9/18/2014	12:00:00 PM	0
9/18/2014	12:15:00 PM	0
9/18/2014	12:30:00 PM	0
9/18/2014	12:45:00 PM	0
9/18/2014	1:00:00 PM	0
9/18/2014	1:15:00 PM	0
9/18/2014	1:30:00 PM	0
9/18/2014	1:45:00 PM	0
9/18/2014	2:00:00 PM	0
9/18/2014	2:15:00 PM	0
9/18/2014	2:30:00 PM	0
9/18/2014	2:45:00 PM	0
9/18/2014	3:00:00 PM	0
9/18/2014	3:15:00 PM	0
9/18/2014	3:30:00 PM	0
9/18/2014	3:45:00 PM	0
9/18/2014	4:00:00 PM	0
9/18/2014	4:15:00 PM	0
9/18/2014	4:30:00 PM	0
9/18/2014	4:45:00 PM	0
9/18/2014	5:00:00 PM	0
9/18/2014	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/18/2014	5:30:00 PM	0
9/18/2014	5:45:00 PM	0
9/18/2014	6:00:00 PM	0
9/18/2014	6:15:00 PM	0
9/18/2014	6:30:00 PM	0
9/18/2014	6:45:00 PM	0
9/18/2014	7:00:00 PM	0
9/18/2014	7:15:00 PM	0
9/18/2014	7:30:00 PM	0
9/18/2014	7:45:00 PM	0
9/18/2014	8:00:00 PM	0
9/18/2014	8:15:00 PM	0
9/18/2014	8:30:00 PM	0
9/18/2014	8:45:00 PM	0
9/18/2014	9:00:00 PM	0
9/18/2014	9:15:00 PM	0
9/18/2014	9:30:00 PM	0
9/18/2014	9:45:00 PM	0
9/18/2014	10:00:00 PM	0
9/18/2014	10:15:00 PM	0
9/18/2014	10:30:00 PM	0
9/18/2014	10:45:00 PM	0
9/18/2014	11:00:00 PM	0
9/18/2014	11:15:00 PM	0
9/18/2014	11:30:00 PM	0
9/18/2014	11:45:00 PM	0
9/19/2014	12:00:00 AM	0
9/19/2014	12:15:00 AM	0
9/19/2014	12:30:00 AM	0
9/19/2014	12:45:00 AM	0
9/19/2014	1:00:00 AM	0
9/19/2014	1:15:00 AM	0
9/19/2014	1:30:00 AM	0
9/19/2014	1:45:00 AM	0
9/19/2014	2:00:00 AM	0
9/19/2014	2:15:00 AM	0
9/19/2014	2:30:00 AM	0
9/19/2014	2:45:00 AM	0
9/19/2014	3:00:00 AM	0
9/19/2014	3:15:00 AM	0
9/19/2014	3:30:00 AM	0
9/19/2014	3:45:00 AM	0
9/19/2014	4:00:00 AM	0
9/19/2014	4:15:00 AM	0
9/19/2014	4:30:00 AM	0
9/19/2014	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/19/2014	5:00:00 AM	0
9/19/2014	5:15:00 AM	0
9/19/2014	5:30:00 AM	0
9/19/2014	5:45:00 AM	0
9/19/2014	6:00:00 AM	0
9/19/2014	6:15:00 AM	0
9/19/2014	6:30:00 AM	0
9/19/2014	6:45:00 AM	0
9/19/2014	7:00:00 AM	0
9/19/2014	7:15:00 AM	0
9/19/2014	7:30:00 AM	0
9/19/2014	7:45:00 AM	0
9/19/2014	8:00:00 AM	0
9/19/2014	8:15:00 AM	0
9/19/2014	8:30:00 AM	0
9/19/2014	8:45:00 AM	0
9/19/2014	9:00:00 AM	0
9/19/2014	9:15:00 AM	0
9/19/2014	9:30:00 AM	0
9/19/2014	9:45:00 AM	0
9/19/2014	10:00:00 AM	0
9/19/2014	10:15:00 AM	0
9/19/2014	10:30:00 AM	0
9/19/2014	10:45:00 AM	0
9/19/2014	11:00:00 AM	0
9/19/2014	11:15:00 AM	0
9/19/2014	11:30:00 AM	0
9/19/2014	11:45:00 AM	0
9/19/2014	12:00:00 PM	0
9/19/2014	12:15:00 PM	0
9/19/2014	12:30:00 PM	0
9/19/2014	12:45:00 PM	0
9/19/2014	1:00:00 PM	0
9/19/2014	1:15:00 PM	0
9/19/2014	1:30:00 PM	0
9/19/2014	1:45:00 PM	0
9/19/2014	2:00:00 PM	0
9/19/2014	2:15:00 PM	0
9/19/2014	2:30:00 PM	0
9/19/2014	2:45:00 PM	0
9/19/2014	3:00:00 PM	0
9/19/2014	3:15:00 PM	0
9/19/2014	3:30:00 PM	0
9/19/2014	3:45:00 PM	0
9/19/2014	4:00:00 PM	0
9/19/2014	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/19/2014	4:30:00 PM	0
9/19/2014	4:45:00 PM	0
9/19/2014	5:00:00 PM	0
9/19/2014	5:15:00 PM	0
9/19/2014	5:30:00 PM	0
9/19/2014	5:45:00 PM	0
9/19/2014	6:00:00 PM	0
9/19/2014	6:15:00 PM	0
9/19/2014	6:30:00 PM	0
9/19/2014	6:45:00 PM	0
9/19/2014	7:00:00 PM	0
9/19/2014	7:15:00 PM	0
9/19/2014	7:30:00 PM	0
9/19/2014	7:45:00 PM	0
9/19/2014	8:00:00 PM	0
9/19/2014	8:15:00 PM	0
9/19/2014	8:30:00 PM	0
9/19/2014	8:45:00 PM	0
9/19/2014	9:00:00 PM	0
9/19/2014	9:15:00 PM	0
9/19/2014	9:30:00 PM	0
9/19/2014	9:45:00 PM	0
9/19/2014	10:00:00 PM	0
9/19/2014	10:15:00 PM	0
9/19/2014	10:30:00 PM	0
9/19/2014	10:45:00 PM	0
9/19/2014	11:00:00 PM	0
9/19/2014	11:15:00 PM	0
9/19/2014	11:30:00 PM	0
9/19/2014	11:45:00 PM	0
9/20/2014	12:00:00 AM	0
9/20/2014	12:15:00 AM	0
9/20/2014	12:30:00 AM	0
9/20/2014	12:45:00 AM	0
9/20/2014	1:00:00 AM	0
9/20/2014	1:15:00 AM	0
9/20/2014	1:30:00 AM	0
9/20/2014	1:45:00 AM	0
9/20/2014	2:00:00 AM	0
9/20/2014	2:15:00 AM	0
9/20/2014	2:30:00 AM	0
9/20/2014	2:45:00 AM	0
9/20/2014	3:00:00 AM	0
9/20/2014	3:15:00 AM	0
9/20/2014	3:30:00 AM	0
9/20/2014	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/20/2014	4:00:00 AM	0
9/20/2014	4:15:00 AM	0
9/20/2014	4:30:00 AM	0
9/20/2014	4:45:00 AM	0
9/20/2014	5:00:00 AM	0
9/20/2014	5:15:00 AM	0
9/20/2014	5:30:00 AM	0
9/20/2014	5:45:00 AM	0
9/20/2014	6:00:00 AM	0
9/20/2014	6:15:00 AM	0
9/20/2014	6:30:00 AM	0
9/20/2014	6:45:00 AM	0
9/20/2014	7:00:00 AM	0
9/20/2014	7:15:00 AM	0
9/20/2014	7:30:00 AM	0
9/20/2014	7:45:00 AM	0
9/20/2014	8:00:00 AM	0
9/20/2014	8:15:00 AM	0
9/20/2014	8:30:00 AM	0
9/20/2014	8:45:00 AM	0
9/20/2014	9:00:00 AM	0
9/20/2014	9:15:00 AM	0
9/20/2014	9:30:00 AM	0
9/20/2014	9:45:00 AM	0
9/20/2014	10:00:00 AM	0
9/20/2014	10:15:00 AM	0
9/20/2014	10:30:00 AM	0
9/20/2014	10:45:00 AM	0
9/20/2014	11:00:00 AM	0
9/20/2014	11:15:00 AM	0
9/20/2014	11:30:00 AM	0
9/20/2014	11:45:00 AM	0
9/20/2014	12:00:00 PM	0
9/20/2014	12:15:00 PM	0
9/20/2014	12:30:00 PM	0
9/20/2014	12:45:00 PM	0
9/20/2014	1:00:00 PM	0
9/20/2014	1:15:00 PM	0
9/20/2014	1:30:00 PM	0
9/20/2014	1:45:00 PM	0
9/20/2014	2:00:00 PM	0
9/20/2014	2:15:00 PM	0
9/20/2014	2:30:00 PM	0
9/20/2014	2:45:00 PM	0
9/20/2014	3:00:00 PM	0
9/20/2014	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/20/2014	3:30:00 PM	0
9/20/2014	3:45:00 PM	0
9/20/2014	4:00:00 PM	0
9/20/2014	4:15:00 PM	0
9/20/2014	4:30:00 PM	0
9/20/2014	4:45:00 PM	0
9/20/2014	5:00:00 PM	0
9/20/2014	5:15:00 PM	0
9/20/2014	5:30:00 PM	0
9/20/2014	5:45:00 PM	0
9/20/2014	6:00:00 PM	0
9/20/2014	6:15:00 PM	0
9/20/2014	6:30:00 PM	0
9/20/2014	6:45:00 PM	0
9/20/2014	7:00:00 PM	0
9/20/2014	7:15:00 PM	0
9/20/2014	7:30:00 PM	0
9/20/2014	7:45:00 PM	0
9/20/2014	8:00:00 PM	0
9/20/2014	8:15:00 PM	0
9/20/2014	8:30:00 PM	0
9/20/2014	8:45:00 PM	0
9/20/2014	9:00:00 PM	0
9/20/2014	9:15:00 PM	0
9/20/2014	9:30:00 PM	0
9/20/2014	9:45:00 PM	0
9/20/2014	10:00:00 PM	0
9/20/2014	10:15:00 PM	0
9/20/2014	10:30:00 PM	0
9/20/2014	10:45:00 PM	0
9/20/2014	11:00:00 PM	0
9/20/2014	11:15:00 PM	0
9/20/2014	11:30:00 PM	0
9/20/2014	11:45:00 PM	0
9/21/2014	12:00:00 AM	0
9/21/2014	12:15:00 AM	0
9/21/2014	12:30:00 AM	0
9/21/2014	12:45:00 AM	0
9/21/2014	1:00:00 AM	0
9/21/2014	1:15:00 AM	0
9/21/2014	1:30:00 AM	0
9/21/2014	1:45:00 AM	0
9/21/2014	2:00:00 AM	0
9/21/2014	2:15:00 AM	0
9/21/2014	2:30:00 AM	0
9/21/2014	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/21/2014	3:00:00 AM	0
9/21/2014	3:15:00 AM	0
9/21/2014	3:30:00 AM	0
9/21/2014	3:45:00 AM	0
9/21/2014	4:00:00 AM	0
9/21/2014	4:15:00 AM	0
9/21/2014	4:30:00 AM	0
9/21/2014	4:45:00 AM	0
9/21/2014	5:00:00 AM	0
9/21/2014	5:15:00 AM	0
9/21/2014	5:30:00 AM	0
9/21/2014	5:45:00 AM	0
9/21/2014	6:00:00 AM	0
9/21/2014	6:15:00 AM	0
9/21/2014	6:30:00 AM	0
9/21/2014	6:45:00 AM	0
9/21/2014	7:00:00 AM	0
9/21/2014	7:15:00 AM	0
9/21/2014	7:30:00 AM	0
9/21/2014	7:45:00 AM	0
9/21/2014	8:00:00 AM	0
9/21/2014	8:15:00 AM	0
9/21/2014	8:30:00 AM	0
9/21/2014	8:45:00 AM	0
9/21/2014	9:00:00 AM	0
9/21/2014	9:15:00 AM	0
9/21/2014	9:30:00 AM	0
9/21/2014	9:45:00 AM	0
9/21/2014	10:00:00 AM	0
9/21/2014	10:15:00 AM	0
9/21/2014	10:30:00 AM	0
9/21/2014	10:45:00 AM	0
9/21/2014	11:00:00 AM	0
9/21/2014	11:15:00 AM	0
9/21/2014	11:30:00 AM	0
9/21/2014	11:45:00 AM	0
9/21/2014	12:00:00 PM	0
9/21/2014	12:15:00 PM	0
9/21/2014	12:30:00 PM	0
9/21/2014	12:45:00 PM	0
9/21/2014	1:00:00 PM	0
9/21/2014	1:15:00 PM	0
9/21/2014	1:30:00 PM	0
9/21/2014	1:45:00 PM	0
9/21/2014	2:00:00 PM	0
9/21/2014	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/21/2014	2:30:00 PM	0
9/21/2014	2:45:00 PM	0
9/21/2014	3:00:00 PM	0
9/21/2014	3:15:00 PM	0
9/21/2014	3:30:00 PM	0
9/21/2014	3:45:00 PM	0
9/21/2014	4:00:00 PM	0
9/21/2014	4:15:00 PM	0
9/21/2014	4:30:00 PM	0
9/21/2014	4:45:00 PM	0
9/21/2014	5:00:00 PM	0
9/21/2014	5:15:00 PM	0
9/21/2014	5:30:00 PM	0
9/21/2014	5:45:00 PM	0
9/21/2014	6:00:00 PM	0
9/21/2014	6:15:00 PM	0
9/21/2014	6:30:00 PM	0
9/21/2014	6:45:00 PM	0
9/21/2014	7:00:00 PM	0
9/21/2014	7:15:00 PM	0
9/21/2014	7:30:00 PM	0
9/21/2014	7:45:00 PM	0
9/21/2014	8:00:00 PM	0
9/21/2014	8:15:00 PM	0
9/21/2014	8:30:00 PM	0
9/21/2014	8:45:00 PM	0
9/21/2014	9:00:00 PM	0
9/21/2014	9:15:00 PM	0
9/21/2014	9:30:00 PM	0
9/21/2014	9:45:00 PM	0
9/21/2014	10:00:00 PM	0
9/21/2014	10:15:00 PM	0
9/21/2014	10:30:00 PM	0
9/21/2014	10:45:00 PM	0
9/21/2014	11:00:00 PM	0
9/21/2014	11:15:00 PM	0
9/21/2014	11:30:00 PM	0
9/21/2014	11:45:00 PM	0
9/22/2014	12:00:00 AM	0
9/22/2014	12:15:00 AM	0
9/22/2014	12:30:00 AM	0
9/22/2014	12:45:00 AM	0
9/22/2014	1:00:00 AM	0
9/22/2014	1:15:00 AM	0
9/22/2014	1:30:00 AM	0
9/22/2014	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/22/2014	2:00:00 AM	0
9/22/2014	2:15:00 AM	0
9/22/2014	2:30:00 AM	0
9/22/2014	2:45:00 AM	0
9/22/2014	3:00:00 AM	0
9/22/2014	3:15:00 AM	0
9/22/2014	3:30:00 AM	0
9/22/2014	3:45:00 AM	0
9/22/2014	4:00:00 AM	0
9/22/2014	4:15:00 AM	0
9/22/2014	4:30:00 AM	0
9/22/2014	4:45:00 AM	0
9/22/2014	5:00:00 AM	0
9/22/2014	5:15:00 AM	0
9/22/2014	5:30:00 AM	0
9/22/2014	5:45:00 AM	0
9/22/2014	6:00:00 AM	0
9/22/2014	6:15:00 AM	0
9/22/2014	6:30:00 AM	0
9/22/2014	6:45:00 AM	0
9/22/2014	7:00:00 AM	0
9/22/2014	7:15:00 AM	0
9/22/2014	7:30:00 AM	0
9/22/2014	7:45:00 AM	0
9/22/2014	8:00:00 AM	0
9/22/2014	8:15:00 AM	0
9/22/2014	8:30:00 AM	0
9/22/2014	8:45:00 AM	0
9/22/2014	9:00:00 AM	0
9/22/2014	9:15:00 AM	0
9/22/2014	9:30:00 AM	0
9/22/2014	9:45:00 AM	0
9/22/2014	10:00:00 AM	0
9/22/2014	10:15:00 AM	0
9/22/2014	10:30:00 AM	0
9/22/2014	10:45:00 AM	0
9/22/2014	11:00:00 AM	0
9/22/2014	11:15:00 AM	0
9/22/2014	11:30:00 AM	0
9/22/2014	11:45:00 AM	0
9/22/2014	12:00:00 PM	0
9/22/2014	12:15:00 PM	0
9/22/2014	12:30:00 PM	0
9/22/2014	12:45:00 PM	0
9/22/2014	1:00:00 PM	0
9/22/2014	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/22/2014	1:30:00 PM	0
9/22/2014	1:45:00 PM	0
9/22/2014	2:00:00 PM	0
9/22/2014	2:15:00 PM	0
9/22/2014	2:30:00 PM	0
9/22/2014	2:45:00 PM	0
9/22/2014	3:00:00 PM	0
9/22/2014	3:15:00 PM	0
9/22/2014	3:30:00 PM	0
9/22/2014	3:45:00 PM	0
9/22/2014	4:00:00 PM	0
9/22/2014	4:15:00 PM	0
9/22/2014	4:30:00 PM	0
9/22/2014	4:45:00 PM	0
9/22/2014	5:00:00 PM	0
9/22/2014	5:15:00 PM	0
9/22/2014	5:30:00 PM	0
9/22/2014	5:45:00 PM	0
9/22/2014	6:00:00 PM	0
9/22/2014	6:15:00 PM	0
9/22/2014	6:30:00 PM	0
9/22/2014	6:45:00 PM	0
9/22/2014	7:00:00 PM	0
9/22/2014	7:15:00 PM	0
9/22/2014	7:30:00 PM	0
9/22/2014	7:45:00 PM	0
9/22/2014	8:00:00 PM	0
9/22/2014	8:15:00 PM	0
9/22/2014	8:30:00 PM	0
9/22/2014	8:45:00 PM	0
9/22/2014	9:00:00 PM	0
9/22/2014	9:15:00 PM	0
9/22/2014	9:30:00 PM	0
9/22/2014	9:45:00 PM	0
9/22/2014	10:00:00 PM	0
9/22/2014	10:15:00 PM	0
9/22/2014	10:30:00 PM	0
9/22/2014	10:45:00 PM	0
9/22/2014	11:00:00 PM	0
9/22/2014	11:15:00 PM	0
9/22/2014	11:30:00 PM	0
9/22/2014	11:45:00 PM	0
9/23/2014	12:00:00 AM	0
9/23/2014	12:15:00 AM	0
9/23/2014	12:30:00 AM	0
9/23/2014	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/23/2014	1:00:00 AM	0
9/23/2014	1:15:00 AM	0
9/23/2014	1:30:00 AM	0
9/23/2014	1:45:00 AM	0
9/23/2014	2:00:00 AM	0
9/23/2014	2:15:00 AM	0
9/23/2014	2:30:00 AM	0
9/23/2014	2:45:00 AM	0
9/23/2014	3:00:00 AM	0
9/23/2014	3:15:00 AM	0
9/23/2014	3:30:00 AM	0
9/23/2014	3:45:00 AM	0
9/23/2014	4:00:00 AM	0
9/23/2014	4:15:00 AM	0
9/23/2014	4:30:00 AM	0
9/23/2014	4:45:00 AM	0
9/23/2014	5:00:00 AM	0
9/23/2014	5:15:00 AM	0
9/23/2014	5:30:00 AM	0
9/23/2014	5:45:00 AM	0
9/23/2014	6:00:00 AM	0
9/23/2014	6:15:00 AM	0
9/23/2014	6:30:00 AM	0
9/23/2014	6:45:00 AM	0
9/23/2014	7:00:00 AM	0
9/23/2014	7:15:00 AM	0
9/23/2014	7:30:00 AM	0
9/23/2014	7:45:00 AM	0
9/23/2014	8:00:00 AM	0
9/23/2014	8:15:00 AM	0
9/23/2014	8:30:00 AM	0
9/23/2014	8:45:00 AM	0
9/23/2014	9:00:00 AM	0
9/23/2014	9:15:00 AM	0
9/23/2014	9:30:00 AM	0
9/23/2014	9:45:00 AM	0
9/23/2014	10:00:00 AM	0
9/23/2014	10:15:00 AM	0
9/23/2014	10:30:00 AM	0
9/23/2014	10:45:00 AM	0
9/23/2014	11:00:00 AM	0
9/23/2014	11:15:00 AM	0
9/23/2014	11:30:00 AM	0
9/23/2014	11:45:00 AM	0
9/23/2014	12:00:00 PM	0
9/23/2014	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/23/2014	12:30:00 PM	0
9/23/2014	12:45:00 PM	0
9/23/2014	1:00:00 PM	0
9/23/2014	1:15:00 PM	0
9/23/2014	1:30:00 PM	0
9/23/2014	1:45:00 PM	0
9/23/2014	2:00:00 PM	0
9/23/2014	2:15:00 PM	0
9/23/2014	2:30:00 PM	0
9/23/2014	2:45:00 PM	0
9/23/2014	3:00:00 PM	0
9/23/2014	3:15:00 PM	0
9/23/2014	3:30:00 PM	0
9/23/2014	3:45:00 PM	0
9/23/2014	4:00:00 PM	0
9/23/2014	4:15:00 PM	0
9/23/2014	4:30:00 PM	0
9/23/2014	4:45:00 PM	0
9/23/2014	5:00:00 PM	0
9/23/2014	5:15:00 PM	0
9/23/2014	5:30:00 PM	0
9/23/2014	5:45:00 PM	0
9/23/2014	6:00:00 PM	0
9/23/2014	6:15:00 PM	0
9/23/2014	6:30:00 PM	0
9/23/2014	6:45:00 PM	0
9/23/2014	7:00:00 PM	0
9/23/2014	7:15:00 PM	0
9/23/2014	7:30:00 PM	0
9/23/2014	7:45:00 PM	0
9/23/2014	8:00:00 PM	0
9/23/2014	8:15:00 PM	0
9/23/2014	8:30:00 PM	0
9/23/2014	8:45:00 PM	0
9/23/2014	9:00:00 PM	0
9/23/2014	9:15:00 PM	0
9/23/2014	9:30:00 PM	0
9/23/2014	9:45:00 PM	0
9/23/2014	10:00:00 PM	0
9/23/2014	10:15:00 PM	0
9/23/2014	10:30:00 PM	0
9/23/2014	10:45:00 PM	0
9/23/2014	11:00:00 PM	0
9/23/2014	11:15:00 PM	0
9/23/2014	11:30:00 PM	0
9/23/2014	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	12:00:00 AM	0
9/24/2014	12:15:00 AM	0
9/24/2014	12:30:00 AM	0
9/24/2014	12:45:00 AM	0
9/24/2014	1:00:00 AM	0
9/24/2014	1:15:00 AM	0
9/24/2014	1:30:00 AM	0
9/24/2014	1:45:00 AM	0
9/24/2014	2:00:00 AM	0
9/24/2014	2:15:00 AM	0
9/24/2014	2:30:00 AM	0
9/24/2014	2:45:00 AM	0
9/24/2014	3:00:00 AM	0
9/24/2014	3:15:00 AM	0
9/24/2014	3:30:00 AM	0
9/24/2014	3:45:00 AM	0
9/24/2014	4:00:00 AM	0
9/24/2014	4:15:00 AM	0
9/24/2014	4:30:00 AM	0
9/24/2014	4:45:00 AM	0
9/24/2014	5:00:00 AM	0
9/24/2014	5:15:00 AM	0
9/24/2014	5:30:00 AM	0
9/24/2014	5:45:00 AM	0
9/24/2014	6:00:00 AM	0
9/24/2014	6:15:00 AM	0
9/24/2014	6:30:00 AM	0
9/24/2014	6:45:00 AM	0
9/24/2014	7:00:00 AM	0
9/24/2014	7:15:00 AM	0
9/24/2014	7:30:00 AM	0
9/24/2014	7:45:00 AM	0
9/24/2014	8:00:00 AM	0
9/24/2014	8:15:00 AM	0
9/24/2014	8:30:00 AM	0
9/24/2014	8:45:00 AM	0
9/24/2014	9:00:00 AM	0
9/24/2014	9:15:00 AM	0
9/24/2014	9:30:00 AM	0
9/24/2014	9:45:00 AM	0
9/24/2014	10:00:00 AM	0
9/24/2014	10:15:00 AM	0
9/24/2014	10:30:00 AM	0
9/24/2014	10:45:00 AM	0
9/24/2014	11:00:00 AM	0
9/24/2014	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	11:30:00 AM	0
9/24/2014	11:45:00 AM	0
9/24/2014	12:00:00 PM	0
9/24/2014	12:15:00 PM	0
9/24/2014	12:30:00 PM	0
9/24/2014	12:45:00 PM	0
9/24/2014	1:00:00 PM	0
9/24/2014	1:15:00 PM	0
9/24/2014	1:30:00 PM	0
9/24/2014	1:45:00 PM	0
9/24/2014	2:00:00 PM	0
9/24/2014	2:15:00 PM	0
9/24/2014	2:30:00 PM	0
9/24/2014	2:45:00 PM	0
9/24/2014	3:00:00 PM	0
9/24/2014	3:15:00 PM	0
9/24/2014	3:30:00 PM	0
9/24/2014	3:45:00 PM	0
9/24/2014	4:00:00 PM	0
9/24/2014	4:15:00 PM	0
9/24/2014	4:30:00 PM	0
9/24/2014	4:45:00 PM	0
9/24/2014	5:00:00 PM	0
9/24/2014	5:15:00 PM	0
9/24/2014	5:30:00 PM	0
9/24/2014	5:45:00 PM	0
9/24/2014	6:00:00 PM	0
9/24/2014	6:15:00 PM	0
9/24/2014	6:30:00 PM	0
9/24/2014	6:45:00 PM	0
9/24/2014	7:00:00 PM	0
9/24/2014	7:15:00 PM	0
9/24/2014	7:30:00 PM	0
9/24/2014	7:45:00 PM	0
9/24/2014	8:00:00 PM	0
9/24/2014	8:15:00 PM	0
9/24/2014	8:30:00 PM	0
9/24/2014	8:45:00 PM	0
9/24/2014	9:00:00 PM	0
9/24/2014	9:15:00 PM	0
9/24/2014	9:30:00 PM	0
9/24/2014	9:45:00 PM	0
9/24/2014	10:00:00 PM	0
9/24/2014	10:15:00 PM	0
9/24/2014	10:30:00 PM	0
9/24/2014	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	11:00:00 PM	0
9/24/2014	11:15:00 PM	0
9/24/2014	11:30:00 PM	0
9/24/2014	11:45:00 PM	0
9/25/2014	12:00:00 AM	0
9/25/2014	12:15:00 AM	0
9/25/2014	12:30:00 AM	0
9/25/2014	12:45:00 AM	0
9/25/2014	1:00:00 AM	0
9/25/2014	1:15:00 AM	0
9/25/2014	1:30:00 AM	0
9/25/2014	1:45:00 AM	0
9/25/2014	2:00:00 AM	0
9/25/2014	2:15:00 AM	0
9/25/2014	2:30:00 AM	0
9/25/2014	2:45:00 AM	0
9/25/2014	3:00:00 AM	0
9/25/2014	3:15:00 AM	0
9/25/2014	3:30:00 AM	0
9/25/2014	3:45:00 AM	0
9/25/2014	4:00:00 AM	0
9/25/2014	4:15:00 AM	0
9/25/2014	4:30:00 AM	0
9/25/2014	4:45:00 AM	0
9/25/2014	5:00:00 AM	0
9/25/2014	5:15:00 AM	0
9/25/2014	5:30:00 AM	0
9/25/2014	5:45:00 AM	0
9/25/2014	6:00:00 AM	0
9/25/2014	6:15:00 AM	0
9/25/2014	6:30:00 AM	0
9/25/2014	6:45:00 AM	0
9/25/2014	7:00:00 AM	0
9/25/2014	7:15:00 AM	0
9/25/2014	7:30:00 AM	0
9/25/2014	7:45:00 AM	0
9/25/2014	8:00:00 AM	0
9/25/2014	8:15:00 AM	0
9/25/2014	8:30:00 AM	0
9/25/2014	8:45:00 AM	0
9/25/2014	9:00:00 AM	0
9/25/2014	9:15:00 AM	0
9/25/2014	9:30:00 AM	0
9/25/2014	9:45:00 AM	0
9/25/2014	10:00:00 AM	0
9/25/2014	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/25/2014	10:30:00 AM	0
9/25/2014	10:45:00 AM	0
9/25/2014	11:00:00 AM	0
9/25/2014	11:15:00 AM	0
9/25/2014	11:30:00 AM	0
9/25/2014	11:45:00 AM	0
9/25/2014	12:00:00 PM	0
9/25/2014	12:15:00 PM	0
9/25/2014	12:30:00 PM	0
9/25/2014	12:45:00 PM	0
9/25/2014	1:00:00 PM	0
9/25/2014	1:15:00 PM	0
9/25/2014	1:30:00 PM	0
9/25/2014	1:45:00 PM	0
9/25/2014	2:00:00 PM	0
9/25/2014	2:15:00 PM	0
9/25/2014	2:30:00 PM	0
9/25/2014	2:45:00 PM	0
9/25/2014	3:00:00 PM	0
9/25/2014	3:15:00 PM	0
9/25/2014	3:30:00 PM	0
9/25/2014	3:45:00 PM	0
9/25/2014	4:00:00 PM	0
9/25/2014	4:15:00 PM	0
9/25/2014	4:30:00 PM	0
9/25/2014	4:45:00 PM	0
9/25/2014	5:00:00 PM	0
9/25/2014	5:15:00 PM	0
9/25/2014	5:30:00 PM	0
9/25/2014	5:45:00 PM	0
9/25/2014	6:00:00 PM	0
9/25/2014	6:15:00 PM	0
9/25/2014	6:30:00 PM	0
9/25/2014	6:45:00 PM	0
9/25/2014	7:00:00 PM	0
9/25/2014	7:15:00 PM	0
9/25/2014	7:30:00 PM	0
9/25/2014	7:45:00 PM	0
9/25/2014	8:00:00 PM	0
9/25/2014	8:15:00 PM	0
9/25/2014	8:30:00 PM	0
9/25/2014	8:45:00 PM	0
9/25/2014	9:00:00 PM	0
9/25/2014	9:15:00 PM	0
9/25/2014	9:30:00 PM	0
9/25/2014	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/25/2014	10:00:00 PM	0
9/25/2014	10:15:00 PM	0
9/25/2014	10:30:00 PM	0
9/25/2014	10:45:00 PM	0
9/25/2014	11:00:00 PM	0
9/25/2014	11:15:00 PM	0
9/25/2014	11:30:00 PM	0
9/25/2014	11:45:00 PM	0
9/26/2014	12:00:00 AM	0
9/26/2014	12:15:00 AM	0
9/26/2014	12:30:00 AM	0
9/26/2014	12:45:00 AM	0
9/26/2014	1:00:00 AM	0
9/26/2014	1:15:00 AM	0
9/26/2014	1:30:00 AM	0
9/26/2014	1:45:00 AM	0
9/26/2014	2:00:00 AM	0
9/26/2014	2:15:00 AM	0
9/26/2014	2:30:00 AM	0
9/26/2014	2:45:00 AM	0
9/26/2014	3:00:00 AM	0
9/26/2014	3:15:00 AM	0
9/26/2014	3:30:00 AM	0
9/26/2014	3:45:00 AM	0
9/26/2014	4:00:00 AM	0
9/26/2014	4:15:00 AM	0
9/26/2014	4:30:00 AM	0
9/26/2014	4:45:00 AM	0
9/26/2014	5:00:00 AM	0
9/26/2014	5:15:00 AM	0
9/26/2014	5:30:00 AM	0
9/26/2014	5:45:00 AM	0
9/26/2014	6:00:00 AM	0
9/26/2014	6:15:00 AM	0
9/26/2014	6:30:00 AM	0
9/26/2014	6:45:00 AM	0
9/26/2014	7:00:00 AM	0
9/26/2014	7:15:00 AM	0
9/26/2014	7:30:00 AM	0
9/26/2014	7:45:00 AM	0
9/26/2014	8:00:00 AM	0
9/26/2014	8:15:00 AM	0
9/26/2014	8:30:00 AM	0
9/26/2014	8:45:00 AM	0
9/26/2014	9:00:00 AM	0
9/26/2014	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/26/2014	9:30:00 AM	0
9/26/2014	9:45:00 AM	0
9/26/2014	10:00:00 AM	0
9/26/2014	10:15:00 AM	0
9/26/2014	10:30:00 AM	0
9/26/2014	10:45:00 AM	0
9/26/2014	11:00:00 AM	0
9/26/2014	11:15:00 AM	0
9/26/2014	11:30:00 AM	0
9/26/2014	11:45:00 AM	0
9/26/2014	12:00:00 PM	0
9/26/2014	12:15:00 PM	0
9/26/2014	12:30:00 PM	0
9/26/2014	12:45:00 PM	0
9/26/2014	1:00:00 PM	0
9/26/2014	1:15:00 PM	0
9/26/2014	1:30:00 PM	0
9/26/2014	1:45:00 PM	0
9/26/2014	2:00:00 PM	0
9/26/2014	2:15:00 PM	0
9/26/2014	2:30:00 PM	0
9/26/2014	2:45:00 PM	0
9/26/2014	3:00:00 PM	0
9/26/2014	3:15:00 PM	0
9/26/2014	3:30:00 PM	0
9/26/2014	3:45:00 PM	0
9/26/2014	4:00:00 PM	0
9/26/2014	4:15:00 PM	0
9/26/2014	4:30:00 PM	0
9/26/2014	4:45:00 PM	0
9/26/2014	5:00:00 PM	0
9/26/2014	5:15:00 PM	0
9/26/2014	5:30:00 PM	0
9/26/2014	5:45:00 PM	0
9/26/2014	6:00:00 PM	0
9/26/2014	6:15:00 PM	0
9/26/2014	6:30:00 PM	0
9/26/2014	6:45:00 PM	0
9/26/2014	7:00:00 PM	0
9/26/2014	7:15:00 PM	0
9/26/2014	7:30:00 PM	0
9/26/2014	7:45:00 PM	0
9/26/2014	8:00:00 PM	0
9/26/2014	8:15:00 PM	0
9/26/2014	8:30:00 PM	0
9/26/2014	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/26/2014	9:00:00 PM	0
9/26/2014	9:15:00 PM	0
9/26/2014	9:30:00 PM	0
9/26/2014	9:45:00 PM	0
9/26/2014	10:00:00 PM	0
9/26/2014	10:15:00 PM	0
9/26/2014	10:30:00 PM	0
9/26/2014	10:45:00 PM	0
9/26/2014	11:00:00 PM	0
9/26/2014	11:15:00 PM	0
9/26/2014	11:30:00 PM	0
9/26/2014	11:45:00 PM	0
9/27/2014	12:00:00 AM	0
9/27/2014	12:15:00 AM	0
9/27/2014	12:30:00 AM	0
9/27/2014	12:45:00 AM	0
9/27/2014	1:00:00 AM	0
9/27/2014	1:15:00 AM	0
9/27/2014	1:30:00 AM	0
9/27/2014	1:45:00 AM	0
9/27/2014	2:00:00 AM	0
9/27/2014	2:15:00 AM	0
9/27/2014	2:30:00 AM	0
9/27/2014	2:45:00 AM	0
9/27/2014	3:00:00 AM	0
9/27/2014	3:15:00 AM	0
9/27/2014	3:30:00 AM	0
9/27/2014	3:45:00 AM	0
9/27/2014	4:00:00 AM	0
9/27/2014	4:15:00 AM	0
9/27/2014	4:30:00 AM	0
9/27/2014	4:45:00 AM	0
9/27/2014	5:00:00 AM	0
9/27/2014	5:15:00 AM	0
9/27/2014	5:30:00 AM	0
9/27/2014	5:45:00 AM	0
9/27/2014	6:00:00 AM	0
9/27/2014	6:15:00 AM	0
9/27/2014	6:30:00 AM	0
9/27/2014	6:45:00 AM	0
9/27/2014	7:00:00 AM	0
9/27/2014	7:15:00 AM	0
9/27/2014	7:30:00 AM	0
9/27/2014	7:45:00 AM	0
9/27/2014	8:00:00 AM	0
9/27/2014	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/27/2014	8:30:00 AM	0
9/27/2014	8:45:00 AM	0
9/27/2014	9:00:00 AM	0
9/27/2014	9:15:00 AM	0
9/27/2014	9:30:00 AM	0
9/27/2014	9:45:00 AM	0
9/27/2014	10:00:00 AM	0
9/27/2014	10:15:00 AM	0
9/27/2014	10:30:00 AM	0
9/27/2014	10:45:00 AM	0
9/27/2014	11:00:00 AM	0
9/27/2014	11:15:00 AM	0
9/27/2014	11:30:00 AM	0
9/27/2014	11:45:00 AM	0
9/27/2014	12:00:00 PM	0
9/27/2014	12:15:00 PM	0
9/27/2014	12:30:00 PM	0
9/27/2014	12:45:00 PM	0
9/27/2014	1:00:00 PM	0
9/27/2014	1:15:00 PM	0
9/27/2014	1:30:00 PM	0
9/27/2014	1:45:00 PM	0
9/27/2014	2:00:00 PM	0
9/27/2014	2:15:00 PM	0
9/27/2014	2:30:00 PM	0
9/27/2014	2:45:00 PM	0
9/27/2014	3:00:00 PM	0
9/27/2014	3:15:00 PM	0
9/27/2014	3:30:00 PM	0
9/27/2014	3:45:00 PM	0
9/27/2014	4:00:00 PM	0
9/27/2014	4:15:00 PM	0
9/27/2014	4:30:00 PM	0
9/27/2014	4:45:00 PM	0
9/27/2014	5:00:00 PM	0
9/27/2014	5:15:00 PM	0
9/27/2014	5:30:00 PM	0
9/27/2014	5:45:00 PM	0
9/27/2014	6:00:00 PM	0
9/27/2014	6:15:00 PM	0
9/27/2014	6:30:00 PM	0
9/27/2014	6:45:00 PM	0
9/27/2014	7:00:00 PM	0
9/27/2014	7:15:00 PM	0
9/27/2014	7:30:00 PM	0
9/27/2014	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/27/2014	8:00:00 PM	0
9/27/2014	8:15:00 PM	0
9/27/2014	8:30:00 PM	0
9/27/2014	8:45:00 PM	0
9/27/2014	9:00:00 PM	0
9/27/2014	9:15:00 PM	0
9/27/2014	9:30:00 PM	0
9/27/2014	9:45:00 PM	0
9/27/2014	10:00:00 PM	0
9/27/2014	10:15:00 PM	0
9/27/2014	10:30:00 PM	0
9/27/2014	10:45:00 PM	0
9/27/2014	11:00:00 PM	0
9/27/2014	11:15:00 PM	0
9/27/2014	11:30:00 PM	0
9/27/2014	11:45:00 PM	0
9/28/2014	12:00:00 AM	0
9/28/2014	12:15:00 AM	0
9/28/2014	12:30:00 AM	0
9/28/2014	12:45:00 AM	0
9/28/2014	1:00:00 AM	0
9/28/2014	1:15:00 AM	0
9/28/2014	1:30:00 AM	0
9/28/2014	1:45:00 AM	0
9/28/2014	2:00:00 AM	0
9/28/2014	2:15:00 AM	0
9/28/2014	2:30:00 AM	0
9/28/2014	2:45:00 AM	0
9/28/2014	3:00:00 AM	0
9/28/2014	3:15:00 AM	0
9/28/2014	3:30:00 AM	0
9/28/2014	3:45:00 AM	0
9/28/2014	4:00:00 AM	0
9/28/2014	4:15:00 AM	0
9/28/2014	4:30:00 AM	0
9/28/2014	4:45:00 AM	0
9/28/2014	5:00:00 AM	0
9/28/2014	5:15:00 AM	0
9/28/2014	5:30:00 AM	0
9/28/2014	5:45:00 AM	0
9/28/2014	6:00:00 AM	0
9/28/2014	6:15:00 AM	0
9/28/2014	6:30:00 AM	0
9/28/2014	6:45:00 AM	0
9/28/2014	7:00:00 AM	0
9/28/2014	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/28/2014	7:30:00 AM	0
9/28/2014	7:45:00 AM	0
9/28/2014	8:00:00 AM	0
9/28/2014	8:15:00 AM	0
9/28/2014	8:30:00 AM	0
9/28/2014	8:45:00 AM	0
9/28/2014	9:00:00 AM	0
9/28/2014	9:15:00 AM	0
9/28/2014	9:30:00 AM	0
9/28/2014	9:45:00 AM	0
9/28/2014	10:00:00 AM	0
9/28/2014	10:15:00 AM	0
9/28/2014	10:30:00 AM	0
9/28/2014	10:45:00 AM	0
9/28/2014	11:00:00 AM	0
9/28/2014	11:15:00 AM	0
9/28/2014	11:30:00 AM	0
9/28/2014	11:45:00 AM	0
9/28/2014	12:00:00 PM	0
9/28/2014	12:15:00 PM	0
9/28/2014	12:30:00 PM	0
9/28/2014	12:45:00 PM	0
9/28/2014	1:00:00 PM	0
9/28/2014	1:15:00 PM	0
9/28/2014	1:30:00 PM	0
9/28/2014	1:45:00 PM	0
9/28/2014	2:00:00 PM	0
9/28/2014	2:15:00 PM	0
9/28/2014	2:30:00 PM	0
9/28/2014	2:45:00 PM	0
9/28/2014	3:00:00 PM	0
9/28/2014	3:15:00 PM	0
9/28/2014	3:30:00 PM	0
9/28/2014	3:45:00 PM	0
9/28/2014	4:00:00 PM	0
9/28/2014	4:15:00 PM	0
9/28/2014	4:30:00 PM	0
9/28/2014	4:45:00 PM	0
9/28/2014	5:00:00 PM	0
9/28/2014	5:15:00 PM	0
9/28/2014	5:30:00 PM	0
9/28/2014	5:45:00 PM	0
9/28/2014	6:00:00 PM	0
9/28/2014	6:15:00 PM	0
9/28/2014	6:30:00 PM	0
9/28/2014	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/28/2014	7:00:00 PM	0
9/28/2014	7:15:00 PM	0
9/28/2014	7:30:00 PM	0
9/28/2014	7:45:00 PM	0
9/28/2014	8:00:00 PM	0
9/28/2014	8:15:00 PM	0
9/28/2014	8:30:00 PM	0
9/28/2014	8:45:00 PM	0
9/28/2014	9:00:00 PM	0
9/28/2014	9:15:00 PM	0
9/28/2014	9:30:00 PM	0
9/28/2014	9:45:00 PM	0
9/28/2014	10:00:00 PM	0
9/28/2014	10:15:00 PM	0
9/28/2014	10:30:00 PM	0
9/28/2014	10:45:00 PM	0
9/28/2014	11:00:00 PM	0
9/28/2014	11:15:00 PM	0
9/28/2014	11:30:00 PM	0
9/28/2014	11:45:00 PM	0
9/29/2014	12:00:00 AM	0
9/29/2014	12:15:00 AM	0
9/29/2014	12:30:00 AM	0
9/29/2014	12:45:00 AM	0
9/29/2014	1:00:00 AM	0
9/29/2014	1:15:00 AM	0
9/29/2014	1:30:00 AM	0
9/29/2014	1:45:00 AM	0
9/29/2014	2:00:00 AM	0
9/29/2014	2:15:00 AM	0
9/29/2014	2:30:00 AM	0
9/29/2014	2:45:00 AM	0
9/29/2014	3:00:00 AM	0
9/29/2014	3:15:00 AM	0
9/29/2014	3:30:00 AM	0
9/29/2014	3:45:00 AM	0
9/29/2014	4:00:00 AM	0
9/29/2014	4:15:00 AM	0
9/29/2014	4:30:00 AM	0
9/29/2014	4:45:00 AM	0
9/29/2014	5:00:00 AM	0
9/29/2014	5:15:00 AM	0
9/29/2014	5:30:00 AM	0
9/29/2014	5:45:00 AM	0
9/29/2014	6:00:00 AM	0
9/29/2014	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/29/2014	6:30:00 AM	0
9/29/2014	6:45:00 AM	0
9/29/2014	7:00:00 AM	0
9/29/2014	7:15:00 AM	0
9/29/2014	7:30:00 AM	0
9/29/2014	7:45:00 AM	0
9/29/2014	8:00:00 AM	0
9/29/2014	8:15:00 AM	0
9/29/2014	8:30:00 AM	0
9/29/2014	8:45:00 AM	0
9/29/2014	9:00:00 AM	0
9/29/2014	9:15:00 AM	0
9/29/2014	9:30:00 AM	0
9/29/2014	9:45:00 AM	0
9/29/2014	10:00:00 AM	0
9/29/2014	10:15:00 AM	0
9/29/2014	10:30:00 AM	0
9/29/2014	10:45:00 AM	0
9/29/2014	11:00:00 AM	0
9/29/2014	11:15:00 AM	0
9/29/2014	11:30:00 AM	0
9/29/2014	11:45:00 AM	0
9/29/2014	12:00:00 PM	0
9/29/2014	12:15:00 PM	0
9/29/2014	12:30:00 PM	0
9/29/2014	12:45:00 PM	0
9/29/2014	1:00:00 PM	0
9/29/2014	1:15:00 PM	0
9/29/2014	1:30:00 PM	0
9/29/2014	1:45:00 PM	0
9/29/2014	2:00:00 PM	0
9/29/2014	2:15:00 PM	0
9/29/2014	2:30:00 PM	0
9/29/2014	2:45:00 PM	0
9/29/2014	3:00:00 PM	0
9/29/2014	3:15:00 PM	0
9/29/2014	3:30:00 PM	0
9/29/2014	3:45:00 PM	0
9/29/2014	4:00:00 PM	0
9/29/2014	4:15:00 PM	0
9/29/2014	4:30:00 PM	0
9/29/2014	4:45:00 PM	0
9/29/2014	5:00:00 PM	0
9/29/2014	5:15:00 PM	0
9/29/2014	5:30:00 PM	0
9/29/2014	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/29/2014	6:00:00 PM	0
9/29/2014	6:15:00 PM	0
9/29/2014	6:30:00 PM	0
9/29/2014	6:45:00 PM	0
9/29/2014	7:00:00 PM	0
9/29/2014	7:15:00 PM	0
9/29/2014	7:30:00 PM	0
9/29/2014	7:45:00 PM	0
9/29/2014	8:00:00 PM	0
9/29/2014	8:15:00 PM	0
9/29/2014	8:30:00 PM	0
9/29/2014	8:45:00 PM	0
9/29/2014	9:00:00 PM	0
9/29/2014	9:15:00 PM	0
9/29/2014	9:30:00 PM	0
9/29/2014	9:45:00 PM	0
9/29/2014	10:00:00 PM	0
9/29/2014	10:15:00 PM	0
9/29/2014	10:30:00 PM	0
9/29/2014	10:45:00 PM	0
9/29/2014	11:00:00 PM	0
9/29/2014	11:15:00 PM	0
9/29/2014	11:30:00 PM	0
9/29/2014	11:45:00 PM	0
9/30/2014	12:00:00 AM	0
9/30/2014	12:15:00 AM	0
9/30/2014	12:30:00 AM	0
9/30/2014	12:45:00 AM	0
9/30/2014	1:00:00 AM	0
9/30/2014	1:15:00 AM	0
9/30/2014	1:30:00 AM	0
9/30/2014	1:45:00 AM	0
9/30/2014	2:00:00 AM	0
9/30/2014	2:15:00 AM	0
9/30/2014	2:30:00 AM	0
9/30/2014	2:45:00 AM	0
9/30/2014	3:00:00 AM	0
9/30/2014	3:15:00 AM	0
9/30/2014	3:30:00 AM	0
9/30/2014	3:45:00 AM	0
9/30/2014	4:00:00 AM	0
9/30/2014	4:15:00 AM	0
9/30/2014	4:30:00 AM	0
9/30/2014	4:45:00 AM	0
9/30/2014	5:00:00 AM	0
9/30/2014	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/30/2014	5:30:00 AM	0
9/30/2014	5:45:00 AM	0
9/30/2014	6:00:00 AM	0
9/30/2014	6:15:00 AM	0
9/30/2014	6:30:00 AM	0
9/30/2014	6:45:00 AM	0
9/30/2014	7:00:00 AM	0
9/30/2014	7:15:00 AM	0
9/30/2014	7:30:00 AM	0
9/30/2014	7:45:00 AM	0
9/30/2014	8:00:00 AM	0
9/30/2014	8:15:00 AM	0
9/30/2014	8:30:00 AM	0
9/30/2014	8:45:00 AM	0
9/30/2014	9:00:00 AM	0
9/30/2014	9:15:00 AM	0
9/30/2014	9:30:00 AM	0
9/30/2014	9:45:00 AM	0
9/30/2014	10:00:00 AM	0
9/30/2014	10:15:00 AM	0
9/30/2014	10:30:00 AM	0
9/30/2014	10:45:00 AM	0
9/30/2014	11:00:00 AM	0
9/30/2014	11:15:00 AM	0
9/30/2014	11:30:00 AM	0
9/30/2014	11:45:00 AM	0
9/30/2014	12:00:00 PM	0
9/30/2014	12:15:00 PM	0
9/30/2014	12:30:00 PM	0
9/30/2014	12:45:00 PM	0
9/30/2014	1:00:00 PM	0
9/30/2014	1:15:00 PM	0
9/30/2014	1:30:00 PM	0
9/30/2014	1:45:00 PM	0
9/30/2014	2:00:00 PM	0
9/30/2014	2:15:00 PM	0
9/30/2014	2:30:00 PM	0
9/30/2014	2:45:00 PM	0
9/30/2014	3:00:00 PM	0
9/30/2014	3:15:00 PM	0
9/30/2014	3:30:00 PM	0
9/30/2014	3:45:00 PM	0
9/30/2014	4:00:00 PM	0
9/30/2014	4:15:00 PM	0
9/30/2014	4:30:00 PM	0
9/30/2014	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
9/30/2014	5:00:00 PM	0
9/30/2014	5:15:00 PM	0
9/30/2014	5:30:00 PM	0
9/30/2014	5:45:00 PM	0
9/30/2014	6:00:00 PM	0
9/30/2014	6:15:00 PM	0
9/30/2014	6:30:00 PM	0
9/30/2014	6:45:00 PM	0
9/30/2014	7:00:00 PM	0
9/30/2014	7:15:00 PM	0
9/30/2014	7:30:00 PM	0
9/30/2014	7:45:00 PM	0
9/30/2014	8:00:00 PM	0
9/30/2014	8:15:00 PM	0
9/30/2014	8:30:00 PM	0
9/30/2014	8:45:00 PM	0
9/30/2014	9:00:00 PM	0
9/30/2014	9:15:00 PM	0
9/30/2014	9:30:00 PM	0
9/30/2014	9:45:00 PM	0
9/30/2014	10:00:00 PM	0
9/30/2014	10:15:00 PM	0
9/30/2014	10:30:00 PM	0
9/30/2014	10:45:00 PM	0
9/30/2014	11:00:00 PM	0
9/30/2014	11:15:00 PM	0
9/30/2014	11:30:00 PM	0
9/30/2014	11:45:00 PM	0
10/1/2014	12:00:00 AM	0

Georges Ditch Return
Station 0217

Date	Flow (cfs)
9/1/2014	0
9/2/2014	0.024
9/3/2014	0.004
9/4/2014	0.003
9/5/2014	0.004
9/6/2014	0
9/7/2014	0
9/8/2014	0
9/9/2014	0
9/10/2014	0.009
9/11/2014	0.048
9/12/2014	0.021
9/13/2014	0.011
9/14/2014	0.017
9/15/2014	0.01
9/16/2014	0.032
9/17/2014	0.008
9/18/2014	0.004
9/19/2014	0.002
9/20/2014	0.008
9/21/2014	0.008
9/22/2014	0.009
9/23/2014	0.005
9/24/2014	0.005
9/25/2014	0
9/26/2014	0
9/27/2014	0
9/28/2014	0.007
9/29/2014	0.007
9/30/2014	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	12:00:00 AM	0
9/1/2014	12:15:00 AM	0
9/1/2014	12:30:00 AM	0
9/1/2014	12:45:00 AM	0
9/1/2014	1:00:00 AM	0
9/1/2014	1:15:00 AM	0
9/1/2014	1:30:00 AM	0
9/1/2014	1:45:00 AM	0
9/1/2014	2:00:00 AM	0
9/1/2014	2:15:00 AM	0
9/1/2014	2:30:00 AM	0
9/1/2014	2:45:00 AM	0
9/1/2014	3:00:00 AM	0
9/1/2014	3:15:00 AM	0
9/1/2014	3:30:00 AM	0
9/1/2014	3:45:00 AM	0
9/1/2014	4:00:00 AM	0
9/1/2014	4:15:00 AM	0
9/1/2014	4:30:00 AM	0
9/1/2014	4:45:00 AM	0
9/1/2014	5:00:00 AM	0
9/1/2014	5:15:00 AM	0
9/1/2014	5:30:00 AM	0
9/1/2014	5:45:00 AM	0
9/1/2014	6:00:00 AM	0
9/1/2014	6:15:00 AM	0
9/1/2014	6:30:00 AM	0
9/1/2014	6:45:00 AM	0
9/1/2014	7:00:00 AM	0
9/1/2014	7:15:00 AM	0
9/1/2014	7:30:00 AM	0
9/1/2014	7:45:00 AM	0
9/1/2014	8:00:00 AM	0
9/1/2014	8:15:00 AM	0
9/1/2014	8:30:00 AM	0
9/1/2014	8:45:00 AM	0
9/1/2014	9:00:00 AM	0
9/1/2014	9:15:00 AM	0
9/1/2014	9:30:00 AM	0
9/1/2014	9:45:00 AM	0
9/1/2014	10:00:00 AM	0
9/1/2014	10:15:00 AM	0
9/1/2014	10:30:00 AM	0
9/1/2014	10:45:00 AM	0
9/1/2014	11:00:00 AM	0
9/1/2014	11:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	11:30:00 AM	0
9/1/2014	11:45:00 AM	0
9/1/2014	12:00:00 PM	0
9/1/2014	12:15:00 PM	0
9/1/2014	12:30:00 PM	0
9/1/2014	12:45:00 PM	0
9/1/2014	1:00:00 PM	0
9/1/2014	1:15:00 PM	0
9/1/2014	1:30:00 PM	0
9/1/2014	1:45:00 PM	0
9/1/2014	2:00:00 PM	0
9/1/2014	2:15:00 PM	0
9/1/2014	2:30:00 PM	0
9/1/2014	2:45:00 PM	0
9/1/2014	3:00:00 PM	0
9/1/2014	3:15:00 PM	0
9/1/2014	3:30:00 PM	0
9/1/2014	3:45:00 PM	0
9/1/2014	4:00:00 PM	0
9/1/2014	4:15:00 PM	0
9/1/2014	4:30:00 PM	0
9/1/2014	4:45:00 PM	0
9/1/2014	5:00:00 PM	0
9/1/2014	5:15:00 PM	0
9/1/2014	5:30:00 PM	0
9/1/2014	5:45:00 PM	0
9/1/2014	6:00:00 PM	0
9/1/2014	6:15:00 PM	0
9/1/2014	6:30:00 PM	0
9/1/2014	6:45:00 PM	0
9/1/2014	7:00:00 PM	0
9/1/2014	7:15:00 PM	0
9/1/2014	7:30:00 PM	0
9/1/2014	7:45:00 PM	0
9/1/2014	8:00:00 PM	0
9/1/2014	8:15:00 PM	0
9/1/2014	8:30:00 PM	0
9/1/2014	8:45:00 PM	0
9/1/2014	9:00:00 PM	0
9/1/2014	9:15:00 PM	0
9/1/2014	9:30:00 PM	0
9/1/2014	9:45:00 PM	0
9/1/2014	10:00:00 PM	0
9/1/2014	10:15:00 PM	0
9/1/2014	10:30:00 PM	0
9/1/2014	10:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/1/2014	11:00:00 PM	0
9/1/2014	11:15:00 PM	0
9/1/2014	11:30:00 PM	0
9/1/2014	11:45:00 PM	0
9/2/2014	12:00:00 AM	0
9/2/2014	12:15:00 AM	0
9/2/2014	12:30:00 AM	0
9/2/2014	12:45:00 AM	0
9/2/2014	1:00:00 AM	0
9/2/2014	1:15:00 AM	0
9/2/2014	1:30:00 AM	0
9/2/2014	1:45:00 AM	0
9/2/2014	2:00:00 AM	0
9/2/2014	2:15:00 AM	0
9/2/2014	2:30:00 AM	0
9/2/2014	2:45:00 AM	0
9/2/2014	3:00:00 AM	0
9/2/2014	3:15:00 AM	0.01
9/2/2014	3:30:00 AM	0.02
9/2/2014	3:45:00 AM	0.02
9/2/2014	4:00:00 AM	0.02
9/2/2014	4:15:00 AM	0.02
9/2/2014	4:30:00 AM	0.02
9/2/2014	4:45:00 AM	0.02
9/2/2014	5:00:00 AM	0.02
9/2/2014	5:15:00 AM	0.02
9/2/2014	5:30:00 AM	0.02
9/2/2014	5:45:00 AM	0.02
9/2/2014	6:00:00 AM	0.02
9/2/2014	6:15:00 AM	0.02
9/2/2014	6:30:00 AM	0.02
9/2/2014	6:45:00 AM	0.02
9/2/2014	7:00:00 AM	0.02
9/2/2014	7:15:00 AM	0.02
9/2/2014	7:30:00 AM	0.02
9/2/2014	7:45:00 AM	0.02
9/2/2014	8:00:00 AM	0.02
9/2/2014	8:15:00 AM	0.02
9/2/2014	8:30:00 AM	0.02
9/2/2014	8:45:00 AM	0.02
9/2/2014	9:00:00 AM	0.02
9/2/2014	9:15:00 AM	0.02
9/2/2014	9:30:00 AM	0.02
9/2/2014	9:45:00 AM	0.02
9/2/2014	10:00:00 AM	0.02
9/2/2014	10:15:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
9/2/2014	10:30:00 AM	0.02
9/2/2014	10:45:00 AM	0.02
9/2/2014	11:00:00 AM	0.01
9/2/2014	11:15:00 AM	0.01
9/2/2014	11:30:00 AM	0.01
9/2/2014	11:45:00 AM	0.01
9/2/2014	12:00:00 PM	0.01
9/2/2014	12:15:00 PM	0.01
9/2/2014	12:30:00 PM	0.01
9/2/2014	12:45:00 PM	0.01
9/2/2014	1:00:00 PM	0.01
9/2/2014	1:15:00 PM	0.01
9/2/2014	1:30:00 PM	0.01
9/2/2014	1:45:00 PM	0.01
9/2/2014	2:00:00 PM	0.01
9/2/2014	2:15:00 PM	0.01
9/2/2014	2:30:00 PM	0.01
9/2/2014	2:45:00 PM	0.01
9/2/2014	3:00:00 PM	0.01
9/2/2014	3:15:00 PM	0.01
9/2/2014	3:30:00 PM	0.01
9/2/2014	3:45:00 PM	0.01
9/2/2014	4:00:00 PM	0.01
9/2/2014	4:15:00 PM	0.01
9/2/2014	4:30:00 PM	0.01
9/2/2014	4:45:00 PM	0.01
9/2/2014	5:00:00 PM	0.01
9/2/2014	5:15:00 PM	0.01
9/2/2014	5:30:00 PM	0.01
9/2/2014	5:45:00 PM	0.01
9/2/2014	6:00:00 PM	0.01
9/2/2014	6:15:00 PM	0.01
9/2/2014	6:30:00 PM	0.01
9/2/2014	6:45:00 PM	0.01
9/2/2014	7:00:00 PM	0.01
9/2/2014	7:15:00 PM	0.01
9/2/2014	7:30:00 PM	0.01
9/2/2014	7:45:00 PM	0.01
9/2/2014	8:00:00 PM	0.01
9/2/2014	8:15:00 PM	0.01
9/2/2014	8:30:00 PM	0.01
9/2/2014	8:45:00 PM	0.01
9/2/2014	9:00:00 PM	0.01
9/2/2014	9:15:00 PM	0.01
9/2/2014	9:30:00 PM	0.01
9/2/2014	9:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/2/2014	10:00:00 PM	0.01
9/2/2014	10:15:00 PM	0.01
9/2/2014	10:30:00 PM	0.01
9/2/2014	10:45:00 PM	0.01
9/2/2014	11:00:00 PM	0.01
9/2/2014	11:15:00 PM	0.01
9/2/2014	11:30:00 PM	0.01
9/2/2014	11:45:00 PM	0
9/3/2014	12:00:00 AM	0
9/3/2014	12:15:00 AM	0
9/3/2014	12:30:00 AM	0
9/3/2014	12:45:00 AM	0
9/3/2014	1:00:00 AM	0
9/3/2014	1:15:00 AM	0
9/3/2014	1:30:00 AM	0
9/3/2014	1:45:00 AM	0
9/3/2014	2:00:00 AM	0
9/3/2014	2:15:00 AM	0
9/3/2014	2:30:00 AM	0
9/3/2014	2:45:00 AM	0
9/3/2014	3:00:00 AM	0
9/3/2014	3:15:00 AM	0
9/3/2014	3:30:00 AM	0
9/3/2014	3:45:00 AM	0
9/3/2014	4:00:00 AM	0
9/3/2014	4:15:00 AM	0
9/3/2014	4:30:00 AM	0
9/3/2014	4:45:00 AM	0
9/3/2014	5:00:00 AM	0
9/3/2014	5:15:00 AM	0
9/3/2014	5:30:00 AM	0
9/3/2014	5:45:00 AM	0.01
9/3/2014	6:00:00 AM	0.01
9/3/2014	6:15:00 AM	0.01
9/3/2014	6:30:00 AM	0.01
9/3/2014	6:45:00 AM	0.01
9/3/2014	7:00:00 AM	0.01
9/3/2014	7:15:00 AM	0.01
9/3/2014	7:30:00 AM	0.01
9/3/2014	7:45:00 AM	0.01
9/3/2014	8:00:00 AM	0.01
9/3/2014	8:15:00 AM	0.01
9/3/2014	8:30:00 AM	0.01
9/3/2014	8:45:00 AM	0.01
9/3/2014	9:00:00 AM	0.01
9/3/2014	9:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/3/2014	9:30:00 AM	0.01
9/3/2014	9:45:00 AM	0.01
9/3/2014	10:00:00 AM	0.01
9/3/2014	10:15:00 AM	0.01
9/3/2014	10:30:00 AM	0.01
9/3/2014	10:45:00 AM	0.01
9/3/2014	11:00:00 AM	0.01
9/3/2014	11:15:00 AM	0.01
9/3/2014	11:30:00 AM	0.01
9/3/2014	11:45:00 AM	0
9/3/2014	12:00:00 PM	0
9/3/2014	12:15:00 PM	0
9/3/2014	12:30:00 PM	0
9/3/2014	12:45:00 PM	0
9/3/2014	1:00:00 PM	0
9/3/2014	1:15:00 PM	0
9/3/2014	1:30:00 PM	0
9/3/2014	1:45:00 PM	0
9/3/2014	2:00:00 PM	0
9/3/2014	2:15:00 PM	0
9/3/2014	2:30:00 PM	0
9/3/2014	2:45:00 PM	0
9/3/2014	3:00:00 PM	0
9/3/2014	3:15:00 PM	0
9/3/2014	3:30:00 PM	0
9/3/2014	3:45:00 PM	0
9/3/2014	4:00:00 PM	0
9/3/2014	4:15:00 PM	0
9/3/2014	4:30:00 PM	0
9/3/2014	4:45:00 PM	0
9/3/2014	5:00:00 PM	0
9/3/2014	5:15:00 PM	0
9/3/2014	5:30:00 PM	0
9/3/2014	5:45:00 PM	0
9/3/2014	6:00:00 PM	0
9/3/2014	6:15:00 PM	0
9/3/2014	6:30:00 PM	0
9/3/2014	6:45:00 PM	0
9/3/2014	7:00:00 PM	0
9/3/2014	7:15:00 PM	0
9/3/2014	7:30:00 PM	0
9/3/2014	7:45:00 PM	0
9/3/2014	8:00:00 PM	0
9/3/2014	8:15:00 PM	0
9/3/2014	8:30:00 PM	0
9/3/2014	8:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/3/2014	9:00:00 PM	0
9/3/2014	9:15:00 PM	0
9/3/2014	9:30:00 PM	0
9/3/2014	9:45:00 PM	0
9/3/2014	10:00:00 PM	0
9/3/2014	10:15:00 PM	0
9/3/2014	10:30:00 PM	0
9/3/2014	10:45:00 PM	0
9/3/2014	11:00:00 PM	0
9/3/2014	11:15:00 PM	0
9/3/2014	11:30:00 PM	0
9/3/2014	11:45:00 PM	0
9/4/2014	12:00:00 AM	0
9/4/2014	12:15:00 AM	0
9/4/2014	12:30:00 AM	0
9/4/2014	12:45:00 AM	0
9/4/2014	1:00:00 AM	0
9/4/2014	1:15:00 AM	0
9/4/2014	1:30:00 AM	0
9/4/2014	1:45:00 AM	0
9/4/2014	2:00:00 AM	0
9/4/2014	2:15:00 AM	0
9/4/2014	2:30:00 AM	0
9/4/2014	2:45:00 AM	0
9/4/2014	3:00:00 AM	0
9/4/2014	3:15:00 AM	0
9/4/2014	3:30:00 AM	0
9/4/2014	3:45:00 AM	0
9/4/2014	4:00:00 AM	0
9/4/2014	4:15:00 AM	0
9/4/2014	4:30:00 AM	0
9/4/2014	4:45:00 AM	0
9/4/2014	5:00:00 AM	0
9/4/2014	5:15:00 AM	0.01
9/4/2014	5:30:00 AM	0.01
9/4/2014	5:45:00 AM	0.01
9/4/2014	6:00:00 AM	0.01
9/4/2014	6:15:00 AM	0.01
9/4/2014	6:30:00 AM	0.01
9/4/2014	6:45:00 AM	0.01
9/4/2014	7:00:00 AM	0.01
9/4/2014	7:15:00 AM	0.01
9/4/2014	7:30:00 AM	0.01
9/4/2014	7:45:00 AM	0.01
9/4/2014	8:00:00 AM	0.01
9/4/2014	8:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/4/2014	8:30:00 AM	0
9/4/2014	8:45:00 AM	0
9/4/2014	9:00:00 AM	0
9/4/2014	9:15:00 AM	0
9/4/2014	9:30:00 AM	0
9/4/2014	9:45:00 AM	0
9/4/2014	10:00:00 AM	0
9/4/2014	10:15:00 AM	0
9/4/2014	10:30:00 AM	0
9/4/2014	10:45:00 AM	0
9/4/2014	11:00:00 AM	0
9/4/2014	11:15:00 AM	0
9/4/2014	11:30:00 AM	0
9/4/2014	11:45:00 AM	0
9/4/2014	12:00:00 PM	0
9/4/2014	12:15:00 PM	0
9/4/2014	12:30:00 PM	0
9/4/2014	12:45:00 PM	0.01
9/4/2014	1:00:00 PM	0.01
9/4/2014	1:15:00 PM	0.01
9/4/2014	1:30:00 PM	0
9/4/2014	1:45:00 PM	0
9/4/2014	2:00:00 PM	0
9/4/2014	2:15:00 PM	0
9/4/2014	2:30:00 PM	0
9/4/2014	2:45:00 PM	0
9/4/2014	3:00:00 PM	0
9/4/2014	3:15:00 PM	0
9/4/2014	3:30:00 PM	0
9/4/2014	3:45:00 PM	0
9/4/2014	4:00:00 PM	0
9/4/2014	4:15:00 PM	0
9/4/2014	4:30:00 PM	0
9/4/2014	4:45:00 PM	0
9/4/2014	5:00:00 PM	0
9/4/2014	5:15:00 PM	0
9/4/2014	5:30:00 PM	0
9/4/2014	5:45:00 PM	0
9/4/2014	6:00:00 PM	0
9/4/2014	6:15:00 PM	0
9/4/2014	6:30:00 PM	0
9/4/2014	6:45:00 PM	0
9/4/2014	7:00:00 PM	0
9/4/2014	7:15:00 PM	0
9/4/2014	7:30:00 PM	0
9/4/2014	7:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/4/2014	8:00:00 PM	0
9/4/2014	8:15:00 PM	0
9/4/2014	8:30:00 PM	0
9/4/2014	8:45:00 PM	0
9/4/2014	9:00:00 PM	0
9/4/2014	9:15:00 PM	0
9/4/2014	9:30:00 PM	0
9/4/2014	9:45:00 PM	0
9/4/2014	10:00:00 PM	0
9/4/2014	10:15:00 PM	0
9/4/2014	10:30:00 PM	0
9/4/2014	10:45:00 PM	0
9/4/2014	11:00:00 PM	0
9/4/2014	11:15:00 PM	0
9/4/2014	11:30:00 PM	0
9/4/2014	11:45:00 PM	0
9/5/2014	12:00:00 AM	0
9/5/2014	12:15:00 AM	0
9/5/2014	12:30:00 AM	0
9/5/2014	12:45:00 AM	0
9/5/2014	1:00:00 AM	0
9/5/2014	1:15:00 AM	0
9/5/2014	1:30:00 AM	0
9/5/2014	1:45:00 AM	0
9/5/2014	2:00:00 AM	0
9/5/2014	2:15:00 AM	0
9/5/2014	2:30:00 AM	0
9/5/2014	2:45:00 AM	0
9/5/2014	3:00:00 AM	0
9/5/2014	3:15:00 AM	0
9/5/2014	3:30:00 AM	0.01
9/5/2014	3:45:00 AM	0.01
9/5/2014	4:00:00 AM	0.01
9/5/2014	4:15:00 AM	0.01
9/5/2014	4:30:00 AM	0.01
9/5/2014	4:45:00 AM	0.01
9/5/2014	5:00:00 AM	0.01
9/5/2014	5:15:00 AM	0.01
9/5/2014	5:30:00 AM	0
9/5/2014	5:45:00 AM	0
9/5/2014	6:00:00 AM	0
9/5/2014	6:15:00 AM	0.01
9/5/2014	6:30:00 AM	0.01
9/5/2014	6:45:00 AM	0.01
9/5/2014	7:00:00 AM	0.01
9/5/2014	7:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/5/2014	7:30:00 AM	0.01
9/5/2014	7:45:00 AM	0.01
9/5/2014	8:00:00 AM	0.01
9/5/2014	8:15:00 AM	0.01
9/5/2014	8:30:00 AM	0.01
9/5/2014	8:45:00 AM	0.01
9/5/2014	9:00:00 AM	0.01
9/5/2014	9:15:00 AM	0.01
9/5/2014	9:30:00 AM	0
9/5/2014	9:45:00 AM	0
9/5/2014	10:00:00 AM	0
9/5/2014	10:15:00 AM	0
9/5/2014	10:30:00 AM	0
9/5/2014	10:45:00 AM	0
9/5/2014	11:00:00 AM	0
9/5/2014	11:15:00 AM	0
9/5/2014	11:30:00 AM	0
9/5/2014	11:45:00 AM	0
9/5/2014	12:00:00 PM	0
9/5/2014	12:15:00 PM	0
9/5/2014	12:30:00 PM	0
9/5/2014	12:45:00 PM	0
9/5/2014	1:00:00 PM	0
9/5/2014	1:15:00 PM	0
9/5/2014	1:30:00 PM	0
9/5/2014	1:45:00 PM	0
9/5/2014	2:00:00 PM	0
9/5/2014	2:15:00 PM	0
9/5/2014	2:30:00 PM	0
9/5/2014	2:45:00 PM	0
9/5/2014	3:00:00 PM	0
9/5/2014	3:15:00 PM	0
9/5/2014	3:30:00 PM	0
9/5/2014	3:45:00 PM	0
9/5/2014	4:00:00 PM	0
9/5/2014	4:15:00 PM	0
9/5/2014	4:30:00 PM	0
9/5/2014	4:45:00 PM	0
9/5/2014	5:00:00 PM	0
9/5/2014	5:15:00 PM	0
9/5/2014	5:30:00 PM	0
9/5/2014	5:45:00 PM	0
9/5/2014	6:00:00 PM	0
9/5/2014	6:15:00 PM	0
9/5/2014	6:30:00 PM	0
9/5/2014	6:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/5/2014	7:00:00 PM	0
9/5/2014	7:15:00 PM	0
9/5/2014	7:30:00 PM	0
9/5/2014	7:45:00 PM	0
9/5/2014	8:00:00 PM	0
9/5/2014	8:15:00 PM	0
9/5/2014	8:30:00 PM	0
9/5/2014	8:45:00 PM	0
9/5/2014	9:00:00 PM	0
9/5/2014	9:15:00 PM	0
9/5/2014	9:30:00 PM	0
9/5/2014	9:45:00 PM	0
9/5/2014	10:00:00 PM	0
9/5/2014	10:15:00 PM	0
9/5/2014	10:30:00 PM	0
9/5/2014	10:45:00 PM	0
9/5/2014	11:00:00 PM	0
9/5/2014	11:15:00 PM	0
9/5/2014	11:30:00 PM	0
9/5/2014	11:45:00 PM	0
9/6/2014	12:00:00 AM	0
9/6/2014	12:15:00 AM	0
9/6/2014	12:30:00 AM	0
9/6/2014	12:45:00 AM	0
9/6/2014	1:00:00 AM	0
9/6/2014	1:15:00 AM	0
9/6/2014	1:30:00 AM	0
9/6/2014	1:45:00 AM	0
9/6/2014	2:00:00 AM	0
9/6/2014	2:15:00 AM	0
9/6/2014	2:30:00 AM	0
9/6/2014	2:45:00 AM	0
9/6/2014	3:00:00 AM	0
9/6/2014	3:15:00 AM	0
9/6/2014	3:30:00 AM	0
9/6/2014	3:45:00 AM	0
9/6/2014	4:00:00 AM	0
9/6/2014	4:15:00 AM	0
9/6/2014	4:30:00 AM	0
9/6/2014	4:45:00 AM	0
9/6/2014	5:00:00 AM	0
9/6/2014	5:15:00 AM	0
9/6/2014	5:30:00 AM	0
9/6/2014	5:45:00 AM	0
9/6/2014	6:00:00 AM	0
9/6/2014	6:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/6/2014	6:30:00 AM	0
9/6/2014	6:45:00 AM	0
9/6/2014	7:00:00 AM	0
9/6/2014	7:15:00 AM	0
9/6/2014	7:30:00 AM	0
9/6/2014	7:45:00 AM	0
9/6/2014	8:00:00 AM	0
9/6/2014	8:15:00 AM	0
9/6/2014	8:30:00 AM	0
9/6/2014	8:45:00 AM	0
9/6/2014	9:00:00 AM	0
9/6/2014	9:15:00 AM	0
9/6/2014	9:30:00 AM	0
9/6/2014	9:45:00 AM	0
9/6/2014	10:00:00 AM	0
9/6/2014	10:15:00 AM	0
9/6/2014	10:30:00 AM	0
9/6/2014	10:45:00 AM	0
9/6/2014	11:00:00 AM	0
9/6/2014	11:15:00 AM	0
9/6/2014	11:30:00 AM	0
9/6/2014	11:45:00 AM	0
9/6/2014	12:00:00 PM	0
9/6/2014	12:15:00 PM	0
9/6/2014	12:30:00 PM	0
9/6/2014	12:45:00 PM	0
9/6/2014	1:00:00 PM	0
9/6/2014	1:15:00 PM	0
9/6/2014	1:30:00 PM	0
9/6/2014	1:45:00 PM	0
9/6/2014	2:00:00 PM	0
9/6/2014	2:15:00 PM	0
9/6/2014	2:30:00 PM	0
9/6/2014	2:45:00 PM	0
9/6/2014	3:00:00 PM	0
9/6/2014	3:15:00 PM	0
9/6/2014	3:30:00 PM	0
9/6/2014	3:45:00 PM	0
9/6/2014	4:00:00 PM	0
9/6/2014	4:15:00 PM	0
9/6/2014	4:30:00 PM	0
9/6/2014	4:45:00 PM	0
9/6/2014	5:00:00 PM	0
9/6/2014	5:15:00 PM	0
9/6/2014	5:30:00 PM	0
9/6/2014	5:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/6/2014	6:00:00 PM	0
9/6/2014	6:15:00 PM	0
9/6/2014	6:30:00 PM	0
9/6/2014	6:45:00 PM	0
9/6/2014	7:00:00 PM	0
9/6/2014	7:15:00 PM	0
9/6/2014	7:30:00 PM	0
9/6/2014	7:45:00 PM	0
9/6/2014	8:00:00 PM	0
9/6/2014	8:15:00 PM	0
9/6/2014	8:30:00 PM	0
9/6/2014	8:45:00 PM	0
9/6/2014	9:00:00 PM	0
9/6/2014	9:15:00 PM	0
9/6/2014	9:30:00 PM	0
9/6/2014	9:45:00 PM	0
9/6/2014	10:00:00 PM	0
9/6/2014	10:15:00 PM	0
9/6/2014	10:30:00 PM	0
9/6/2014	10:45:00 PM	0
9/6/2014	11:00:00 PM	0
9/6/2014	11:15:00 PM	0
9/6/2014	11:30:00 PM	0
9/6/2014	11:45:00 PM	0
9/7/2014	12:00:00 AM	0
9/7/2014	12:15:00 AM	0
9/7/2014	12:30:00 AM	0
9/7/2014	12:45:00 AM	0
9/7/2014	1:00:00 AM	0
9/7/2014	1:15:00 AM	0
9/7/2014	1:30:00 AM	0
9/7/2014	1:45:00 AM	0
9/7/2014	2:00:00 AM	0
9/7/2014	2:15:00 AM	0
9/7/2014	2:30:00 AM	0
9/7/2014	2:45:00 AM	0
9/7/2014	3:00:00 AM	0
9/7/2014	3:15:00 AM	0
9/7/2014	3:30:00 AM	0
9/7/2014	3:45:00 AM	0
9/7/2014	4:00:00 AM	0
9/7/2014	4:15:00 AM	0
9/7/2014	4:30:00 AM	0
9/7/2014	4:45:00 AM	0
9/7/2014	5:00:00 AM	0
9/7/2014	5:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/7/2014	5:30:00 AM	0
9/7/2014	5:45:00 AM	0
9/7/2014	6:00:00 AM	0
9/7/2014	6:15:00 AM	0
9/7/2014	6:30:00 AM	0
9/7/2014	6:45:00 AM	0
9/7/2014	7:00:00 AM	0
9/7/2014	7:15:00 AM	0
9/7/2014	7:30:00 AM	0
9/7/2014	7:45:00 AM	0
9/7/2014	8:00:00 AM	0
9/7/2014	8:15:00 AM	0
9/7/2014	8:30:00 AM	0
9/7/2014	8:45:00 AM	0
9/7/2014	9:00:00 AM	0
9/7/2014	9:15:00 AM	0
9/7/2014	9:30:00 AM	0
9/7/2014	9:45:00 AM	0
9/7/2014	10:00:00 AM	0
9/7/2014	10:15:00 AM	0
9/7/2014	10:30:00 AM	0
9/7/2014	10:45:00 AM	0
9/7/2014	11:00:00 AM	0
9/7/2014	11:15:00 AM	0
9/7/2014	11:30:00 AM	0
9/7/2014	11:45:00 AM	0
9/7/2014	12:00:00 PM	0
9/7/2014	12:15:00 PM	0
9/7/2014	12:30:00 PM	0
9/7/2014	12:45:00 PM	0
9/7/2014	1:00:00 PM	0
9/7/2014	1:15:00 PM	0
9/7/2014	1:30:00 PM	0
9/7/2014	1:45:00 PM	0
9/7/2014	2:00:00 PM	0
9/7/2014	2:15:00 PM	0
9/7/2014	2:30:00 PM	0
9/7/2014	2:45:00 PM	0
9/7/2014	3:00:00 PM	0
9/7/2014	3:15:00 PM	0
9/7/2014	3:30:00 PM	0
9/7/2014	3:45:00 PM	0
9/7/2014	4:00:00 PM	0
9/7/2014	4:15:00 PM	0
9/7/2014	4:30:00 PM	0
9/7/2014	4:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/7/2014	5:00:00 PM	0
9/7/2014	5:15:00 PM	0
9/7/2014	5:30:00 PM	0
9/7/2014	5:45:00 PM	0
9/7/2014	6:00:00 PM	0
9/7/2014	6:15:00 PM	0
9/7/2014	6:30:00 PM	0
9/7/2014	6:45:00 PM	0
9/7/2014	7:00:00 PM	0
9/7/2014	7:15:00 PM	0
9/7/2014	7:30:00 PM	0
9/7/2014	7:45:00 PM	0
9/7/2014	8:00:00 PM	0
9/7/2014	8:15:00 PM	0
9/7/2014	8:30:00 PM	0
9/7/2014	8:45:00 PM	0
9/7/2014	9:00:00 PM	0
9/7/2014	9:15:00 PM	0
9/7/2014	9:30:00 PM	0
9/7/2014	9:45:00 PM	0
9/7/2014	10:00:00 PM	0
9/7/2014	10:15:00 PM	0
9/7/2014	10:30:00 PM	0
9/7/2014	10:45:00 PM	0
9/7/2014	11:00:00 PM	0
9/7/2014	11:15:00 PM	0
9/7/2014	11:30:00 PM	0
9/7/2014	11:45:00 PM	0
9/8/2014	12:00:00 AM	0
9/8/2014	12:15:00 AM	0
9/8/2014	12:30:00 AM	0
9/8/2014	12:45:00 AM	0
9/8/2014	1:00:00 AM	0
9/8/2014	1:15:00 AM	0
9/8/2014	1:30:00 AM	0
9/8/2014	1:45:00 AM	0
9/8/2014	2:00:00 AM	0
9/8/2014	2:15:00 AM	0
9/8/2014	2:30:00 AM	0
9/8/2014	2:45:00 AM	0
9/8/2014	3:00:00 AM	0
9/8/2014	3:15:00 AM	0
9/8/2014	3:30:00 AM	0
9/8/2014	3:45:00 AM	0
9/8/2014	4:00:00 AM	0
9/8/2014	4:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/8/2014	4:30:00 AM	0
9/8/2014	4:45:00 AM	0
9/8/2014	5:00:00 AM	0
9/8/2014	5:15:00 AM	0
9/8/2014	5:30:00 AM	0
9/8/2014	5:45:00 AM	0
9/8/2014	6:00:00 AM	0
9/8/2014	6:15:00 AM	0
9/8/2014	6:30:00 AM	0
9/8/2014	6:45:00 AM	0
9/8/2014	7:00:00 AM	0
9/8/2014	7:15:00 AM	0
9/8/2014	7:30:00 AM	0
9/8/2014	7:45:00 AM	0
9/8/2014	8:00:00 AM	0
9/8/2014	8:15:00 AM	0
9/8/2014	8:30:00 AM	0
9/8/2014	8:45:00 AM	0
9/8/2014	9:00:00 AM	0
9/8/2014	9:15:00 AM	0
9/8/2014	9:30:00 AM	0
9/8/2014	9:45:00 AM	0
9/8/2014	10:00:00 AM	0
9/8/2014	10:15:00 AM	0
9/8/2014	10:30:00 AM	0
9/8/2014	10:45:00 AM	0
9/8/2014	11:00:00 AM	0
9/8/2014	11:15:00 AM	0
9/8/2014	11:30:00 AM	0
9/8/2014	11:45:00 AM	0
9/8/2014	12:00:00 PM	0
9/8/2014	12:15:00 PM	0
9/8/2014	12:30:00 PM	0
9/8/2014	12:45:00 PM	0
9/8/2014	1:00:00 PM	0
9/8/2014	1:15:00 PM	0
9/8/2014	1:30:00 PM	0
9/8/2014	1:45:00 PM	0
9/8/2014	2:00:00 PM	0
9/8/2014	2:15:00 PM	0
9/8/2014	2:30:00 PM	0
9/8/2014	2:45:00 PM	0
9/8/2014	3:00:00 PM	0
9/8/2014	3:15:00 PM	0
9/8/2014	3:30:00 PM	0
9/8/2014	3:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/8/2014	4:00:00 PM	0
9/8/2014	4:15:00 PM	0
9/8/2014	4:30:00 PM	0
9/8/2014	4:45:00 PM	0
9/8/2014	5:00:00 PM	0
9/8/2014	5:15:00 PM	0
9/8/2014	5:30:00 PM	0
9/8/2014	5:45:00 PM	0
9/8/2014	6:00:00 PM	0
9/8/2014	6:15:00 PM	0
9/8/2014	6:30:00 PM	0
9/8/2014	6:45:00 PM	0
9/8/2014	7:00:00 PM	0
9/8/2014	7:15:00 PM	0
9/8/2014	7:30:00 PM	0
9/8/2014	7:45:00 PM	0
9/8/2014	8:00:00 PM	0
9/8/2014	8:15:00 PM	0
9/8/2014	8:30:00 PM	0
9/8/2014	8:45:00 PM	0
9/8/2014	9:00:00 PM	0
9/8/2014	9:15:00 PM	0
9/8/2014	9:30:00 PM	0
9/8/2014	9:45:00 PM	0
9/8/2014	10:00:00 PM	0
9/8/2014	10:15:00 PM	0
9/8/2014	10:30:00 PM	0
9/8/2014	10:45:00 PM	0
9/8/2014	11:00:00 PM	0
9/8/2014	11:15:00 PM	0
9/8/2014	11:30:00 PM	0
9/8/2014	11:45:00 PM	0
9/9/2014	12:00:00 AM	0
9/9/2014	12:15:00 AM	0
9/9/2014	12:30:00 AM	0
9/9/2014	12:45:00 AM	0
9/9/2014	1:00:00 AM	0
9/9/2014	1:15:00 AM	0
9/9/2014	1:30:00 AM	0
9/9/2014	1:45:00 AM	0
9/9/2014	2:00:00 AM	0
9/9/2014	2:15:00 AM	0
9/9/2014	2:30:00 AM	0
9/9/2014	2:45:00 AM	0
9/9/2014	3:00:00 AM	0
9/9/2014	3:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/9/2014	3:30:00 AM	0
9/9/2014	3:45:00 AM	0
9/9/2014	4:00:00 AM	0
9/9/2014	4:15:00 AM	0
9/9/2014	4:30:00 AM	0
9/9/2014	4:45:00 AM	0
9/9/2014	5:00:00 AM	0
9/9/2014	5:15:00 AM	0
9/9/2014	5:30:00 AM	0
9/9/2014	5:45:00 AM	0
9/9/2014	6:00:00 AM	0
9/9/2014	6:15:00 AM	0
9/9/2014	6:30:00 AM	0
9/9/2014	6:45:00 AM	0
9/9/2014	7:00:00 AM	0
9/9/2014	7:15:00 AM	0
9/9/2014	7:30:00 AM	0
9/9/2014	7:45:00 AM	0
9/9/2014	8:00:00 AM	0
9/9/2014	8:15:00 AM	0
9/9/2014	8:30:00 AM	0
9/9/2014	8:45:00 AM	0
9/9/2014	9:00:00 AM	0
9/9/2014	9:15:00 AM	0
9/9/2014	9:30:00 AM	0
9/9/2014	9:45:00 AM	0
9/9/2014	10:00:00 AM	0
9/9/2014	10:15:00 AM	0
9/9/2014	10:30:00 AM	0
9/9/2014	10:45:00 AM	0
9/9/2014	11:00:00 AM	0
9/9/2014	11:15:00 AM	0
9/9/2014	11:30:00 AM	0
9/9/2014	11:45:00 AM	0
9/9/2014	12:00:00 PM	0
9/9/2014	12:15:00 PM	0
9/9/2014	12:30:00 PM	0
9/9/2014	12:45:00 PM	0
9/9/2014	1:00:00 PM	0
9/9/2014	1:15:00 PM	0
9/9/2014	1:30:00 PM	0
9/9/2014	1:45:00 PM	0
9/9/2014	2:00:00 PM	0
9/9/2014	2:15:00 PM	0
9/9/2014	2:30:00 PM	0
9/9/2014	2:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/9/2014	3:00:00 PM	0
9/9/2014	3:15:00 PM	0
9/9/2014	3:30:00 PM	0
9/9/2014	3:45:00 PM	0
9/9/2014	4:00:00 PM	0
9/9/2014	4:15:00 PM	0
9/9/2014	4:30:00 PM	0
9/9/2014	4:45:00 PM	0
9/9/2014	5:00:00 PM	0
9/9/2014	5:15:00 PM	0
9/9/2014	5:30:00 PM	0
9/9/2014	5:45:00 PM	0
9/9/2014	6:00:00 PM	0
9/9/2014	6:15:00 PM	0
9/9/2014	6:30:00 PM	0
9/9/2014	6:45:00 PM	0
9/9/2014	7:00:00 PM	0
9/9/2014	7:15:00 PM	0
9/9/2014	7:30:00 PM	0
9/9/2014	7:45:00 PM	0
9/9/2014	8:00:00 PM	0
9/9/2014	8:15:00 PM	0
9/9/2014	8:30:00 PM	0
9/9/2014	8:45:00 PM	0
9/9/2014	9:00:00 PM	0
9/9/2014	9:15:00 PM	0
9/9/2014	9:30:00 PM	0
9/9/2014	9:45:00 PM	0
9/9/2014	10:00:00 PM	0
9/9/2014	10:15:00 PM	0
9/9/2014	10:30:00 PM	0
9/9/2014	10:45:00 PM	0
9/9/2014	11:00:00 PM	0
9/9/2014	11:15:00 PM	0
9/9/2014	11:30:00 PM	0
9/9/2014	11:45:00 PM	0
9/10/2014	12:00:00 AM	0
9/10/2014	12:15:00 AM	0
9/10/2014	12:30:00 AM	0
9/10/2014	12:45:00 AM	0
9/10/2014	1:00:00 AM	0
9/10/2014	1:15:00 AM	0
9/10/2014	1:30:00 AM	0
9/10/2014	1:45:00 AM	0
9/10/2014	2:00:00 AM	0
9/10/2014	2:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/10/2014	2:30:00 AM	0
9/10/2014	2:45:00 AM	0
9/10/2014	3:00:00 AM	0
9/10/2014	3:15:00 AM	0
9/10/2014	3:30:00 AM	0
9/10/2014	3:45:00 AM	0
9/10/2014	4:00:00 AM	0
9/10/2014	4:15:00 AM	0
9/10/2014	4:30:00 AM	0
9/10/2014	4:45:00 AM	0
9/10/2014	5:00:00 AM	0
9/10/2014	5:15:00 AM	0
9/10/2014	5:30:00 AM	0
9/10/2014	5:45:00 AM	0
9/10/2014	6:00:00 AM	0.01
9/10/2014	6:15:00 AM	0.01
9/10/2014	6:30:00 AM	0.01
9/10/2014	6:45:00 AM	0.01
9/10/2014	7:00:00 AM	0.01
9/10/2014	7:15:00 AM	0.01
9/10/2014	7:30:00 AM	0.01
9/10/2014	7:45:00 AM	0.01
9/10/2014	8:00:00 AM	0.01
9/10/2014	8:15:00 AM	0.01
9/10/2014	8:30:00 AM	0.01
9/10/2014	8:45:00 AM	0.01
9/10/2014	9:00:00 AM	0.01
9/10/2014	9:15:00 AM	0.01
9/10/2014	9:30:00 AM	0.01
9/10/2014	9:45:00 AM	0.01
9/10/2014	10:00:00 AM	0.01
9/10/2014	10:15:00 AM	0.01
9/10/2014	10:30:00 AM	0.01
9/10/2014	10:45:00 AM	0.01
9/10/2014	11:00:00 AM	0
9/10/2014	11:15:00 AM	0.01
9/10/2014	11:30:00 AM	0.01
9/10/2014	11:45:00 AM	0.01
9/10/2014	12:00:00 PM	0.01
9/10/2014	12:15:00 PM	0.01
9/10/2014	12:30:00 PM	0.01
9/10/2014	12:45:00 PM	0.01
9/10/2014	1:00:00 PM	0.01
9/10/2014	1:15:00 PM	0.01
9/10/2014	1:30:00 PM	0.01
9/10/2014	1:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/10/2014	2:00:00 PM	0.01
9/10/2014	2:15:00 PM	0.01
9/10/2014	2:30:00 PM	0.01
9/10/2014	2:45:00 PM	0.01
9/10/2014	3:00:00 PM	0.01
9/10/2014	3:15:00 PM	0.01
9/10/2014	3:30:00 PM	0.01
9/10/2014	3:45:00 PM	0.01
9/10/2014	4:00:00 PM	0.01
9/10/2014	4:15:00 PM	0
9/10/2014	4:30:00 PM	0
9/10/2014	4:45:00 PM	0
9/10/2014	5:00:00 PM	0
9/10/2014	5:15:00 PM	0
9/10/2014	5:30:00 PM	0
9/10/2014	5:45:00 PM	0
9/10/2014	6:00:00 PM	0
9/10/2014	6:15:00 PM	0
9/10/2014	6:30:00 PM	0
9/10/2014	6:45:00 PM	0
9/10/2014	7:00:00 PM	0
9/10/2014	7:15:00 PM	0
9/10/2014	7:30:00 PM	0
9/10/2014	7:45:00 PM	0
9/10/2014	8:00:00 PM	0
9/10/2014	8:15:00 PM	0
9/10/2014	8:30:00 PM	0
9/10/2014	8:45:00 PM	0
9/10/2014	9:00:00 PM	0.01
9/10/2014	9:15:00 PM	0.01
9/10/2014	9:30:00 PM	0.01
9/10/2014	9:45:00 PM	0.01
9/10/2014	10:00:00 PM	0.01
9/10/2014	10:15:00 PM	0.01
9/10/2014	10:30:00 PM	0.01
9/10/2014	10:45:00 PM	0.01
9/10/2014	11:00:00 PM	0.01
9/10/2014	11:15:00 PM	0.01
9/10/2014	11:30:00 PM	0.01
9/10/2014	11:45:00 PM	0.01
9/11/2014	12:00:00 AM	0.01
9/11/2014	12:15:00 AM	0.01
9/11/2014	12:30:00 AM	0.01
9/11/2014	12:45:00 AM	0.01
9/11/2014	1:00:00 AM	0.02
9/11/2014	1:15:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
9/11/2014	1:30:00 AM	0.02
9/11/2014	1:45:00 AM	0.03
9/11/2014	2:00:00 AM	0.03
9/11/2014	2:15:00 AM	0.03
9/11/2014	2:30:00 AM	0.03
9/11/2014	2:45:00 AM	0.03
9/11/2014	3:00:00 AM	0.03
9/11/2014	3:15:00 AM	0.02
9/11/2014	3:30:00 AM	0.02
9/11/2014	3:45:00 AM	0.02
9/11/2014	4:00:00 AM	0.02
9/11/2014	4:15:00 AM	0.02
9/11/2014	4:30:00 AM	0.02
9/11/2014	4:45:00 AM	0.02
9/11/2014	5:00:00 AM	0.02
9/11/2014	5:15:00 AM	0.02
9/11/2014	5:30:00 AM	0.02
9/11/2014	5:45:00 AM	0.02
9/11/2014	6:00:00 AM	0.02
9/11/2014	6:15:00 AM	0.02
9/11/2014	6:30:00 AM	0.02
9/11/2014	6:45:00 AM	0.02
9/11/2014	7:00:00 AM	0.02
9/11/2014	7:15:00 AM	0.02
9/11/2014	7:30:00 AM	0.02
9/11/2014	7:45:00 AM	0.02
9/11/2014	8:00:00 AM	0.02
9/11/2014	8:15:00 AM	0.02
9/11/2014	8:30:00 AM	0.02
9/11/2014	8:45:00 AM	0.02
9/11/2014	9:00:00 AM	0.02
9/11/2014	9:15:00 AM	0.02
9/11/2014	9:30:00 AM	0.02
9/11/2014	9:45:00 AM	0.02
9/11/2014	10:00:00 AM	0.02
9/11/2014	10:15:00 AM	0.02
9/11/2014	10:30:00 AM	0.02
9/11/2014	10:45:00 AM	0.02
9/11/2014	11:00:00 AM	0.02
9/11/2014	11:15:00 AM	0.02
9/11/2014	11:30:00 AM	0.02
9/11/2014	11:45:00 AM	0.02
9/11/2014	12:00:00 PM	0.02
9/11/2014	12:15:00 PM	0.02
9/11/2014	12:30:00 PM	0.02
9/11/2014	12:45:00 PM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
9/11/2014	1:00:00 PM	0.02
9/11/2014	1:15:00 PM	0.02
9/11/2014	1:30:00 PM	0.02
9/11/2014	1:45:00 PM	0.02
9/11/2014	2:00:00 PM	0.02
9/11/2014	2:15:00 PM	0.02
9/11/2014	2:30:00 PM	0.02
9/11/2014	2:45:00 PM	0.02
9/11/2014	3:00:00 PM	0.02
9/11/2014	3:15:00 PM	0.02
9/11/2014	3:30:00 PM	0.02
9/11/2014	3:45:00 PM	0.02
9/11/2014	4:00:00 PM	0.02
9/11/2014	4:15:00 PM	0.02
9/11/2014	4:30:00 PM	0.02
9/11/2014	4:45:00 PM	0.02
9/11/2014	5:00:00 PM	0.02
9/11/2014	5:15:00 PM	0.02
9/11/2014	5:30:00 PM	0.02
9/11/2014	5:45:00 PM	0.02
9/11/2014	6:00:00 PM	0.02
9/11/2014	6:15:00 PM	0.02
9/11/2014	6:30:00 PM	0.02
9/11/2014	6:45:00 PM	0.02
9/11/2014	7:00:00 PM	0.02
9/11/2014	7:15:00 PM	0.02
9/11/2014	7:30:00 PM	0.02
9/11/2014	7:45:00 PM	0.02
9/11/2014	8:00:00 PM	0.02
9/11/2014	8:15:00 PM	0.02
9/11/2014	8:30:00 PM	0.02
9/11/2014	8:45:00 PM	0.02
9/11/2014	9:00:00 PM	0.02
9/11/2014	9:15:00 PM	0.02
9/11/2014	9:30:00 PM	0.02
9/11/2014	9:45:00 PM	0.02
9/11/2014	10:00:00 PM	0.02
9/11/2014	10:15:00 PM	0.02
9/11/2014	10:30:00 PM	0.02
9/11/2014	10:45:00 PM	0.02
9/11/2014	11:00:00 PM	0.01
9/11/2014	11:15:00 PM	0.01
9/11/2014	11:30:00 PM	0.01
9/11/2014	11:45:00 PM	0.01
9/12/2014	12:00:00 AM	0.01
9/12/2014	12:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	12:30:00 AM	0.01
9/12/2014	12:45:00 AM	0.01
9/12/2014	1:00:00 AM	0.01
9/12/2014	1:15:00 AM	0.01
9/12/2014	1:30:00 AM	0.01
9/12/2014	1:45:00 AM	0.01
9/12/2014	2:00:00 AM	0.01
9/12/2014	2:15:00 AM	0.01
9/12/2014	2:30:00 AM	0.01
9/12/2014	2:45:00 AM	0.01
9/12/2014	3:00:00 AM	0.01
9/12/2014	3:15:00 AM	0.01
9/12/2014	3:30:00 AM	0.01
9/12/2014	3:45:00 AM	0.01
9/12/2014	4:00:00 AM	0.01
9/12/2014	4:15:00 AM	0.01
9/12/2014	4:30:00 AM	0.01
9/12/2014	4:45:00 AM	0.01
9/12/2014	5:00:00 AM	0.01
9/12/2014	5:15:00 AM	0.02
9/12/2014	5:30:00 AM	0.02
9/12/2014	5:45:00 AM	0.02
9/12/2014	6:00:00 AM	0.02
9/12/2014	6:15:00 AM	0.02
9/12/2014	6:30:00 AM	0.02
9/12/2014	6:45:00 AM	0.02
9/12/2014	7:00:00 AM	0.02
9/12/2014	7:15:00 AM	0.02
9/12/2014	7:30:00 AM	0.02
9/12/2014	7:45:00 AM	0.02
9/12/2014	8:00:00 AM	0.02
9/12/2014	8:15:00 AM	0.02
9/12/2014	8:30:00 AM	0.02
9/12/2014	8:45:00 AM	0.02
9/12/2014	9:00:00 AM	0.02
9/12/2014	9:15:00 AM	0.02
9/12/2014	9:30:00 AM	0.02
9/12/2014	9:45:00 AM	0.02
9/12/2014	10:00:00 AM	0.02
9/12/2014	10:15:00 AM	0.02
9/12/2014	10:30:00 AM	0.02
9/12/2014	10:45:00 AM	0.01
9/12/2014	11:00:00 AM	0.01
9/12/2014	11:15:00 AM	0.01
9/12/2014	11:30:00 AM	0.01
9/12/2014	11:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	12:00:00 PM	0.01
9/12/2014	12:15:00 PM	0.01
9/12/2014	12:30:00 PM	0.01
9/12/2014	12:45:00 PM	0.01
9/12/2014	1:00:00 PM	0.01
9/12/2014	1:15:00 PM	0.01
9/12/2014	1:30:00 PM	0.01
9/12/2014	1:45:00 PM	0.01
9/12/2014	2:00:00 PM	0.01
9/12/2014	2:15:00 PM	0.01
9/12/2014	2:30:00 PM	0.01
9/12/2014	2:45:00 PM	0.01
9/12/2014	3:00:00 PM	0.01
9/12/2014	3:15:00 PM	0.01
9/12/2014	3:30:00 PM	0.01
9/12/2014	3:45:00 PM	0.01
9/12/2014	4:00:00 PM	0.01
9/12/2014	4:15:00 PM	0.01
9/12/2014	4:30:00 PM	0.01
9/12/2014	4:45:00 PM	0.01
9/12/2014	5:00:00 PM	0.01
9/12/2014	5:15:00 PM	0
9/12/2014	5:30:00 PM	0
9/12/2014	5:45:00 PM	0
9/12/2014	6:00:00 PM	0
9/12/2014	6:15:00 PM	0
9/12/2014	6:30:00 PM	0
9/12/2014	6:45:00 PM	0
9/12/2014	7:00:00 PM	0
9/12/2014	7:15:00 PM	0
9/12/2014	7:30:00 PM	0
9/12/2014	7:45:00 PM	0
9/12/2014	8:00:00 PM	0
9/12/2014	8:15:00 PM	0
9/12/2014	8:30:00 PM	0
9/12/2014	8:45:00 PM	0
9/12/2014	9:00:00 PM	0.01
9/12/2014	9:15:00 PM	0.01
9/12/2014	9:30:00 PM	0.01
9/12/2014	9:45:00 PM	0.01
9/12/2014	10:00:00 PM	0.01
9/12/2014	10:15:00 PM	0.01
9/12/2014	10:30:00 PM	0.01
9/12/2014	10:45:00 PM	0.01
9/12/2014	11:00:00 PM	0.01
9/12/2014	11:15:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/12/2014	11:30:00 PM	0.01
9/12/2014	11:45:00 PM	0.01
9/13/2014	12:00:00 AM	0.01
9/13/2014	12:15:00 AM	0.01
9/13/2014	12:30:00 AM	0.01
9/13/2014	12:45:00 AM	0.01
9/13/2014	1:00:00 AM	0.01
9/13/2014	1:15:00 AM	0.01
9/13/2014	1:30:00 AM	0.01
9/13/2014	1:45:00 AM	0.01
9/13/2014	2:00:00 AM	0.01
9/13/2014	2:15:00 AM	0.01
9/13/2014	2:30:00 AM	0.01
9/13/2014	2:45:00 AM	0.01
9/13/2014	3:00:00 AM	0.01
9/13/2014	3:15:00 AM	0.01
9/13/2014	3:30:00 AM	0.01
9/13/2014	3:45:00 AM	0.01
9/13/2014	4:00:00 AM	0.01
9/13/2014	4:15:00 AM	0.01
9/13/2014	4:30:00 AM	0.01
9/13/2014	4:45:00 AM	0.01
9/13/2014	5:00:00 AM	0.01
9/13/2014	5:15:00 AM	0.01
9/13/2014	5:30:00 AM	0.01
9/13/2014	5:45:00 AM	0.01
9/13/2014	6:00:00 AM	0.01
9/13/2014	6:15:00 AM	0.01
9/13/2014	6:30:00 AM	0.01
9/13/2014	6:45:00 AM	0.01
9/13/2014	7:00:00 AM	0.01
9/13/2014	7:15:00 AM	0.01
9/13/2014	7:30:00 AM	0.01
9/13/2014	7:45:00 AM	0.01
9/13/2014	8:00:00 AM	0.01
9/13/2014	8:15:00 AM	0.01
9/13/2014	8:30:00 AM	0.01
9/13/2014	8:45:00 AM	0.01
9/13/2014	9:00:00 AM	0.01
9/13/2014	9:15:00 AM	0.01
9/13/2014	9:30:00 AM	0.01
9/13/2014	9:45:00 AM	0.01
9/13/2014	10:00:00 AM	0.01
9/13/2014	10:15:00 AM	0.01
9/13/2014	10:30:00 AM	0.01
9/13/2014	10:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/13/2014	11:00:00 AM	0.01
9/13/2014	11:15:00 AM	0.01
9/13/2014	11:30:00 AM	0.01
9/13/2014	11:45:00 AM	0.01
9/13/2014	12:00:00 PM	0.01
9/13/2014	12:15:00 PM	0.01
9/13/2014	12:30:00 PM	0.01
9/13/2014	12:45:00 PM	0.01
9/13/2014	1:00:00 PM	0.01
9/13/2014	1:15:00 PM	0.01
9/13/2014	1:30:00 PM	0
9/13/2014	1:45:00 PM	0
9/13/2014	2:00:00 PM	0
9/13/2014	2:15:00 PM	0
9/13/2014	2:30:00 PM	0
9/13/2014	2:45:00 PM	0
9/13/2014	3:00:00 PM	0
9/13/2014	3:15:00 PM	0
9/13/2014	3:30:00 PM	0
9/13/2014	3:45:00 PM	0
9/13/2014	4:00:00 PM	0
9/13/2014	4:15:00 PM	0
9/13/2014	4:30:00 PM	0
9/13/2014	4:45:00 PM	0
9/13/2014	5:00:00 PM	0
9/13/2014	5:15:00 PM	0
9/13/2014	5:30:00 PM	0
9/13/2014	5:45:00 PM	0
9/13/2014	6:00:00 PM	0
9/13/2014	6:15:00 PM	0
9/13/2014	6:30:00 PM	0
9/13/2014	6:45:00 PM	0
9/13/2014	7:00:00 PM	0
9/13/2014	7:15:00 PM	0
9/13/2014	7:30:00 PM	0
9/13/2014	7:45:00 PM	0
9/13/2014	8:00:00 PM	0
9/13/2014	8:15:00 PM	0
9/13/2014	8:30:00 PM	0
9/13/2014	8:45:00 PM	0
9/13/2014	9:00:00 PM	0
9/13/2014	9:15:00 PM	0
9/13/2014	9:30:00 PM	0
9/13/2014	9:45:00 PM	0
9/13/2014	10:00:00 PM	0
9/13/2014	10:15:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/13/2014	10:30:00 PM	0.01
9/13/2014	10:45:00 PM	0.01
9/13/2014	11:00:00 PM	0.01
9/13/2014	11:15:00 PM	0.01
9/13/2014	11:30:00 PM	0.01
9/13/2014	11:45:00 PM	0.01
9/14/2014	12:00:00 AM	0.01
9/14/2014	12:15:00 AM	0.01
9/14/2014	12:30:00 AM	0.01
9/14/2014	12:45:00 AM	0.01
9/14/2014	1:00:00 AM	0.01
9/14/2014	1:15:00 AM	0.01
9/14/2014	1:30:00 AM	0.01
9/14/2014	1:45:00 AM	0.01
9/14/2014	2:00:00 AM	0.01
9/14/2014	2:15:00 AM	0.01
9/14/2014	2:30:00 AM	0.01
9/14/2014	2:45:00 AM	0.01
9/14/2014	3:00:00 AM	0.01
9/14/2014	3:15:00 AM	0.01
9/14/2014	3:30:00 AM	0.01
9/14/2014	3:45:00 AM	0.01
9/14/2014	4:00:00 AM	0.01
9/14/2014	4:15:00 AM	0.01
9/14/2014	4:30:00 AM	0.01
9/14/2014	4:45:00 AM	0.01
9/14/2014	5:00:00 AM	0.01
9/14/2014	5:15:00 AM	0.01
9/14/2014	5:30:00 AM	0.01
9/14/2014	5:45:00 AM	0.01
9/14/2014	6:00:00 AM	0.01
9/14/2014	6:15:00 AM	0.01
9/14/2014	6:30:00 AM	0.01
9/14/2014	6:45:00 AM	0.01
9/14/2014	7:00:00 AM	0.01
9/14/2014	7:15:00 AM	0.01
9/14/2014	7:30:00 AM	0.01
9/14/2014	7:45:00 AM	0.01
9/14/2014	8:00:00 AM	0.01
9/14/2014	8:15:00 AM	0.01
9/14/2014	8:30:00 AM	0.01
9/14/2014	8:45:00 AM	0.01
9/14/2014	9:00:00 AM	0.01
9/14/2014	9:15:00 AM	0.01
9/14/2014	9:30:00 AM	0.01
9/14/2014	9:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/14/2014	10:00:00 AM	0.01
9/14/2014	10:15:00 AM	0.01
9/14/2014	10:30:00 AM	0.01
9/14/2014	10:45:00 AM	0.01
9/14/2014	11:00:00 AM	0.01
9/14/2014	11:15:00 AM	0.01
9/14/2014	11:30:00 AM	0.01
9/14/2014	11:45:00 AM	0.01
9/14/2014	12:00:00 PM	0.01
9/14/2014	12:15:00 PM	0.01
9/14/2014	12:30:00 PM	0.01
9/14/2014	12:45:00 PM	0.01
9/14/2014	1:00:00 PM	0.01
9/14/2014	1:15:00 PM	0.01
9/14/2014	1:30:00 PM	0.01
9/14/2014	1:45:00 PM	0.01
9/14/2014	2:00:00 PM	0.01
9/14/2014	2:15:00 PM	0.01
9/14/2014	2:30:00 PM	0.01
9/14/2014	2:45:00 PM	0.01
9/14/2014	3:00:00 PM	0.01
9/14/2014	3:15:00 PM	0.01
9/14/2014	3:30:00 PM	0.01
9/14/2014	3:45:00 PM	0.01
9/14/2014	4:00:00 PM	0.01
9/14/2014	4:15:00 PM	0.01
9/14/2014	4:30:00 PM	0.01
9/14/2014	4:45:00 PM	0.01
9/14/2014	5:00:00 PM	0.01
9/14/2014	5:15:00 PM	0.01
9/14/2014	5:30:00 PM	0.01
9/14/2014	5:45:00 PM	0.01
9/14/2014	6:00:00 PM	0.01
9/14/2014	6:15:00 PM	0.01
9/14/2014	6:30:00 PM	0.01
9/14/2014	6:45:00 PM	0.01
9/14/2014	7:00:00 PM	0.01
9/14/2014	7:15:00 PM	0.01
9/14/2014	7:30:00 PM	0.01
9/14/2014	7:45:00 PM	0.01
9/14/2014	8:00:00 PM	0.01
9/14/2014	8:15:00 PM	0.01
9/14/2014	8:30:00 PM	0.01
9/14/2014	8:45:00 PM	0.01
9/14/2014	9:00:00 PM	0.01
9/14/2014	9:15:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/14/2014	9:30:00 PM	0.01
9/14/2014	9:45:00 PM	0.01
9/14/2014	10:00:00 PM	0.01
9/14/2014	10:15:00 PM	0.01
9/14/2014	10:30:00 PM	0.01
9/14/2014	10:45:00 PM	0.01
9/14/2014	11:00:00 PM	0.01
9/14/2014	11:15:00 PM	0.01
9/14/2014	11:30:00 PM	0.01
9/14/2014	11:45:00 PM	0.01
9/15/2014	12:00:00 AM	0.01
9/15/2014	12:15:00 AM	0.01
9/15/2014	12:30:00 AM	0.01
9/15/2014	12:45:00 AM	0.01
9/15/2014	1:00:00 AM	0.01
9/15/2014	1:15:00 AM	0.01
9/15/2014	1:30:00 AM	0.01
9/15/2014	1:45:00 AM	0.01
9/15/2014	2:00:00 AM	0.01
9/15/2014	2:15:00 AM	0.01
9/15/2014	2:30:00 AM	0.01
9/15/2014	2:45:00 AM	0.01
9/15/2014	3:00:00 AM	0.01
9/15/2014	3:15:00 AM	0.01
9/15/2014	3:30:00 AM	0.01
9/15/2014	3:45:00 AM	0.01
9/15/2014	4:00:00 AM	0.01
9/15/2014	4:15:00 AM	0.01
9/15/2014	4:30:00 AM	0.01
9/15/2014	4:45:00 AM	0.01
9/15/2014	5:00:00 AM	0.01
9/15/2014	5:15:00 AM	0.01
9/15/2014	5:30:00 AM	0.01
9/15/2014	5:45:00 AM	0.01
9/15/2014	6:00:00 AM	0.01
9/15/2014	6:15:00 AM	0.01
9/15/2014	6:30:00 AM	0.01
9/15/2014	6:45:00 AM	0.01
9/15/2014	7:00:00 AM	0.01
9/15/2014	7:15:00 AM	0.01
9/15/2014	7:30:00 AM	0.01
9/15/2014	7:45:00 AM	0.01
9/15/2014	8:00:00 AM	0.01
9/15/2014	8:15:00 AM	0.01
9/15/2014	8:30:00 AM	0.01
9/15/2014	8:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/15/2014	9:00:00 AM	0.01
9/15/2014	9:15:00 AM	0.01
9/15/2014	9:30:00 AM	0.01
9/15/2014	9:45:00 AM	0.01
9/15/2014	10:00:00 AM	0.01
9/15/2014	10:15:00 AM	0.01
9/15/2014	10:30:00 AM	0.01
9/15/2014	10:45:00 AM	0.01
9/15/2014	11:00:00 AM	0.01
9/15/2014	11:15:00 AM	0.01
9/15/2014	11:30:00 AM	0.01
9/15/2014	11:45:00 AM	0.01
9/15/2014	12:00:00 PM	0.01
9/15/2014	12:15:00 PM	0.01
9/15/2014	12:30:00 PM	0.01
9/15/2014	12:45:00 PM	0.01
9/15/2014	1:00:00 PM	0.01
9/15/2014	1:15:00 PM	0.01
9/15/2014	1:30:00 PM	0
9/15/2014	1:45:00 PM	0
9/15/2014	2:00:00 PM	0
9/15/2014	2:15:00 PM	0
9/15/2014	2:30:00 PM	0
9/15/2014	2:45:00 PM	0
9/15/2014	3:00:00 PM	0
9/15/2014	3:15:00 PM	0
9/15/2014	3:30:00 PM	0
9/15/2014	3:45:00 PM	0
9/15/2014	4:00:00 PM	0
9/15/2014	4:15:00 PM	0
9/15/2014	4:30:00 PM	0
9/15/2014	4:45:00 PM	0
9/15/2014	5:00:00 PM	0
9/15/2014	5:15:00 PM	0
9/15/2014	5:30:00 PM	0
9/15/2014	5:45:00 PM	0
9/15/2014	6:00:00 PM	0
9/15/2014	6:15:00 PM	0
9/15/2014	6:30:00 PM	0
9/15/2014	6:45:00 PM	0
9/15/2014	7:00:00 PM	0
9/15/2014	7:15:00 PM	0
9/15/2014	7:30:00 PM	0
9/15/2014	7:45:00 PM	0
9/15/2014	8:00:00 PM	0
9/15/2014	8:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/15/2014	8:30:00 PM	0
9/15/2014	8:45:00 PM	0
9/15/2014	9:00:00 PM	0
9/15/2014	9:15:00 PM	0
9/15/2014	9:30:00 PM	0
9/15/2014	9:45:00 PM	0
9/15/2014	10:00:00 PM	0
9/15/2014	10:15:00 PM	0
9/15/2014	10:30:00 PM	0
9/15/2014	10:45:00 PM	0
9/15/2014	11:00:00 PM	0.01
9/15/2014	11:15:00 PM	0.01
9/15/2014	11:30:00 PM	0.01
9/15/2014	11:45:00 PM	0.01
9/16/2014	12:00:00 AM	0.01
9/16/2014	12:15:00 AM	0.01
9/16/2014	12:30:00 AM	0.01
9/16/2014	12:45:00 AM	0.01
9/16/2014	1:00:00 AM	0.01
9/16/2014	1:15:00 AM	0.01
9/16/2014	1:30:00 AM	0.01
9/16/2014	1:45:00 AM	0.01
9/16/2014	2:00:00 AM	0.01
9/16/2014	2:15:00 AM	0.01
9/16/2014	2:30:00 AM	0.01
9/16/2014	2:45:00 AM	0.02
9/16/2014	3:00:00 AM	0.02
9/16/2014	3:15:00 AM	0.02
9/16/2014	3:30:00 AM	0.02
9/16/2014	3:45:00 AM	0.02
9/16/2014	4:00:00 AM	0.02
9/16/2014	4:15:00 AM	0.02
9/16/2014	4:30:00 AM	0.02
9/16/2014	4:45:00 AM	0.02
9/16/2014	5:00:00 AM	0.02
9/16/2014	5:15:00 AM	0.02
9/16/2014	5:30:00 AM	0.02
9/16/2014	5:45:00 AM	0.02
9/16/2014	6:00:00 AM	0.02
9/16/2014	6:15:00 AM	0.02
9/16/2014	6:30:00 AM	0.02
9/16/2014	6:45:00 AM	0.02
9/16/2014	7:00:00 AM	0.02
9/16/2014	7:15:00 AM	0.02
9/16/2014	7:30:00 AM	0.02
9/16/2014	7:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
9/16/2014	8:00:00 AM	0.02
9/16/2014	8:15:00 AM	0.02
9/16/2014	8:30:00 AM	0.02
9/16/2014	8:45:00 AM	0.02
9/16/2014	9:00:00 AM	0.02
9/16/2014	9:15:00 AM	0.02
9/16/2014	9:30:00 AM	0.02
9/16/2014	9:45:00 AM	0.02
9/16/2014	10:00:00 AM	0.02
9/16/2014	10:15:00 AM	0.02
9/16/2014	10:30:00 AM	0.02
9/16/2014	10:45:00 AM	0.02
9/16/2014	11:00:00 AM	0.02
9/16/2014	11:15:00 AM	0.02
9/16/2014	11:30:00 AM	0.02
9/16/2014	11:45:00 AM	0.02
9/16/2014	12:00:00 PM	0.02
9/16/2014	12:15:00 PM	0.02
9/16/2014	12:30:00 PM	0.02
9/16/2014	12:45:00 PM	0.02
9/16/2014	1:00:00 PM	0.02
9/16/2014	1:15:00 PM	0.02
9/16/2014	1:30:00 PM	0.02
9/16/2014	1:45:00 PM	0.02
9/16/2014	2:00:00 PM	0.02
9/16/2014	2:15:00 PM	0.01
9/16/2014	2:30:00 PM	0.02
9/16/2014	2:45:00 PM	0.01
9/16/2014	3:00:00 PM	0.01
9/16/2014	3:15:00 PM	0.01
9/16/2014	3:30:00 PM	0.01
9/16/2014	3:45:00 PM	0.01
9/16/2014	4:00:00 PM	0.01
9/16/2014	4:15:00 PM	0.01
9/16/2014	4:30:00 PM	0.01
9/16/2014	4:45:00 PM	0.01
9/16/2014	5:00:00 PM	0.01
9/16/2014	5:15:00 PM	0.01
9/16/2014	5:30:00 PM	0.01
9/16/2014	5:45:00 PM	0.01
9/16/2014	6:00:00 PM	0.01
9/16/2014	6:15:00 PM	0.01
9/16/2014	6:30:00 PM	0.01
9/16/2014	6:45:00 PM	0.01
9/16/2014	7:00:00 PM	0.01
9/16/2014	7:15:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/16/2014	7:30:00 PM	0.01
9/16/2014	7:45:00 PM	0.01
9/16/2014	8:00:00 PM	0.01
9/16/2014	8:15:00 PM	0.01
9/16/2014	8:30:00 PM	0.01
9/16/2014	8:45:00 PM	0.01
9/16/2014	9:00:00 PM	0.01
9/16/2014	9:15:00 PM	0.01
9/16/2014	9:30:00 PM	0.01
9/16/2014	9:45:00 PM	0.01
9/16/2014	10:00:00 PM	0.01
9/16/2014	10:15:00 PM	0.01
9/16/2014	10:30:00 PM	0.01
9/16/2014	10:45:00 PM	0.01
9/16/2014	11:00:00 PM	0.01
9/16/2014	11:15:00 PM	0.01
9/16/2014	11:30:00 PM	0.01
9/16/2014	11:45:00 PM	0.01
9/17/2014	12:00:00 AM	0.01
9/17/2014	12:15:00 AM	0.01
9/17/2014	12:30:00 AM	0.01
9/17/2014	12:45:00 AM	0.01
9/17/2014	1:00:00 AM	0.01
9/17/2014	1:15:00 AM	0.01
9/17/2014	1:30:00 AM	0.01
9/17/2014	1:45:00 AM	0.01
9/17/2014	2:00:00 AM	0.01
9/17/2014	2:15:00 AM	0.01
9/17/2014	2:30:00 AM	0.01
9/17/2014	2:45:00 AM	0.01
9/17/2014	3:00:00 AM	0.01
9/17/2014	3:15:00 AM	0.01
9/17/2014	3:30:00 AM	0.01
9/17/2014	3:45:00 AM	0.01
9/17/2014	4:00:00 AM	0.01
9/17/2014	4:15:00 AM	0.01
9/17/2014	4:30:00 AM	0.01
9/17/2014	4:45:00 AM	0.01
9/17/2014	5:00:00 AM	0.01
9/17/2014	5:15:00 AM	0.01
9/17/2014	5:30:00 AM	0.01
9/17/2014	5:45:00 AM	0.01
9/17/2014	6:00:00 AM	0.01
9/17/2014	6:15:00 AM	0.01
9/17/2014	6:30:00 AM	0.01
9/17/2014	6:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/17/2014	7:00:00 AM	0.01
9/17/2014	7:15:00 AM	0.01
9/17/2014	7:30:00 AM	0.01
9/17/2014	7:45:00 AM	0.01
9/17/2014	8:00:00 AM	0.01
9/17/2014	8:15:00 AM	0.01
9/17/2014	8:30:00 AM	0.01
9/17/2014	8:45:00 AM	0.01
9/17/2014	9:00:00 AM	0.01
9/17/2014	9:15:00 AM	0.01
9/17/2014	9:30:00 AM	0.01
9/17/2014	9:45:00 AM	0.01
9/17/2014	10:00:00 AM	0.01
9/17/2014	10:15:00 AM	0.01
9/17/2014	10:30:00 AM	0.01
9/17/2014	10:45:00 AM	0.01
9/17/2014	11:00:00 AM	0.01
9/17/2014	11:15:00 AM	0.01
9/17/2014	11:30:00 AM	0.01
9/17/2014	11:45:00 AM	0.01
9/17/2014	12:00:00 PM	0
9/17/2014	12:15:00 PM	0
9/17/2014	12:30:00 PM	0
9/17/2014	12:45:00 PM	0
9/17/2014	1:00:00 PM	0
9/17/2014	1:15:00 PM	0
9/17/2014	1:30:00 PM	0
9/17/2014	1:45:00 PM	0
9/17/2014	2:00:00 PM	0
9/17/2014	2:15:00 PM	0
9/17/2014	2:30:00 PM	0
9/17/2014	2:45:00 PM	0
9/17/2014	3:00:00 PM	0
9/17/2014	3:15:00 PM	0
9/17/2014	3:30:00 PM	0
9/17/2014	3:45:00 PM	0
9/17/2014	4:00:00 PM	0
9/17/2014	4:15:00 PM	0
9/17/2014	4:30:00 PM	0
9/17/2014	4:45:00 PM	0
9/17/2014	5:00:00 PM	0
9/17/2014	5:15:00 PM	0
9/17/2014	5:30:00 PM	0
9/17/2014	5:45:00 PM	0
9/17/2014	6:00:00 PM	0
9/17/2014	6:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/17/2014	6:30:00 PM	0
9/17/2014	6:45:00 PM	0
9/17/2014	7:00:00 PM	0
9/17/2014	7:15:00 PM	0
9/17/2014	7:30:00 PM	0
9/17/2014	7:45:00 PM	0
9/17/2014	8:00:00 PM	0
9/17/2014	8:15:00 PM	0
9/17/2014	8:30:00 PM	0
9/17/2014	8:45:00 PM	0
9/17/2014	9:00:00 PM	0
9/17/2014	9:15:00 PM	0
9/17/2014	9:30:00 PM	0
9/17/2014	9:45:00 PM	0
9/17/2014	10:00:00 PM	0
9/17/2014	10:15:00 PM	0
9/17/2014	10:30:00 PM	0
9/17/2014	10:45:00 PM	0
9/17/2014	11:00:00 PM	0
9/17/2014	11:15:00 PM	0
9/17/2014	11:30:00 PM	0
9/17/2014	11:45:00 PM	0
9/18/2014	12:00:00 AM	0
9/18/2014	12:15:00 AM	0
9/18/2014	12:30:00 AM	0
9/18/2014	12:45:00 AM	0
9/18/2014	1:00:00 AM	0
9/18/2014	1:15:00 AM	0
9/18/2014	1:30:00 AM	0
9/18/2014	1:45:00 AM	0
9/18/2014	2:00:00 AM	0
9/18/2014	2:15:00 AM	0
9/18/2014	2:30:00 AM	0
9/18/2014	2:45:00 AM	0
9/18/2014	3:00:00 AM	0
9/18/2014	3:15:00 AM	0.01
9/18/2014	3:30:00 AM	0.01
9/18/2014	3:45:00 AM	0.01
9/18/2014	4:00:00 AM	0.01
9/18/2014	4:15:00 AM	0.01
9/18/2014	4:30:00 AM	0.01
9/18/2014	4:45:00 AM	0.01
9/18/2014	5:00:00 AM	0.01
9/18/2014	5:15:00 AM	0.01
9/18/2014	5:30:00 AM	0.01
9/18/2014	5:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/18/2014	6:00:00 AM	0.01
9/18/2014	6:15:00 AM	0.01
9/18/2014	6:30:00 AM	0.01
9/18/2014	6:45:00 AM	0.01
9/18/2014	7:00:00 AM	0.01
9/18/2014	7:15:00 AM	0.01
9/18/2014	7:30:00 AM	0.01
9/18/2014	7:45:00 AM	0.01
9/18/2014	8:00:00 AM	0.01
9/18/2014	8:15:00 AM	0.01
9/18/2014	8:30:00 AM	0.01
9/18/2014	8:45:00 AM	0.01
9/18/2014	9:00:00 AM	0.01
9/18/2014	9:15:00 AM	0.01
9/18/2014	9:30:00 AM	0
9/18/2014	9:45:00 AM	0
9/18/2014	10:00:00 AM	0
9/18/2014	10:15:00 AM	0
9/18/2014	10:30:00 AM	0
9/18/2014	10:45:00 AM	0
9/18/2014	11:00:00 AM	0
9/18/2014	11:15:00 AM	0
9/18/2014	11:30:00 AM	0
9/18/2014	11:45:00 AM	0
9/18/2014	12:00:00 PM	0
9/18/2014	12:15:00 PM	0
9/18/2014	12:30:00 PM	0
9/18/2014	12:45:00 PM	0
9/18/2014	1:00:00 PM	0
9/18/2014	1:15:00 PM	0
9/18/2014	1:30:00 PM	0
9/18/2014	1:45:00 PM	0
9/18/2014	2:00:00 PM	0
9/18/2014	2:15:00 PM	0
9/18/2014	2:30:00 PM	0
9/18/2014	2:45:00 PM	0
9/18/2014	3:00:00 PM	0
9/18/2014	3:15:00 PM	0
9/18/2014	3:30:00 PM	0
9/18/2014	3:45:00 PM	0
9/18/2014	4:00:00 PM	0
9/18/2014	4:15:00 PM	0
9/18/2014	4:30:00 PM	0
9/18/2014	4:45:00 PM	0
9/18/2014	5:00:00 PM	0
9/18/2014	5:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/18/2014	5:30:00 PM	0
9/18/2014	5:45:00 PM	0
9/18/2014	6:00:00 PM	0
9/18/2014	6:15:00 PM	0
9/18/2014	6:30:00 PM	0
9/18/2014	6:45:00 PM	0
9/18/2014	7:00:00 PM	0
9/18/2014	7:15:00 PM	0
9/18/2014	7:30:00 PM	0
9/18/2014	7:45:00 PM	0
9/18/2014	8:00:00 PM	0
9/18/2014	8:15:00 PM	0
9/18/2014	8:30:00 PM	0
9/18/2014	8:45:00 PM	0
9/18/2014	9:00:00 PM	0
9/18/2014	9:15:00 PM	0
9/18/2014	9:30:00 PM	0
9/18/2014	9:45:00 PM	0
9/18/2014	10:00:00 PM	0
9/18/2014	10:15:00 PM	0
9/18/2014	10:30:00 PM	0
9/18/2014	10:45:00 PM	0
9/18/2014	11:00:00 PM	0
9/18/2014	11:15:00 PM	0
9/18/2014	11:30:00 PM	0
9/18/2014	11:45:00 PM	0
9/19/2014	12:00:00 AM	0
9/19/2014	12:15:00 AM	0
9/19/2014	12:30:00 AM	0
9/19/2014	12:45:00 AM	0
9/19/2014	1:00:00 AM	0
9/19/2014	1:15:00 AM	0
9/19/2014	1:30:00 AM	0
9/19/2014	1:45:00 AM	0
9/19/2014	2:00:00 AM	0
9/19/2014	2:15:00 AM	0
9/19/2014	2:30:00 AM	0
9/19/2014	2:45:00 AM	0
9/19/2014	3:00:00 AM	0
9/19/2014	3:15:00 AM	0
9/19/2014	3:30:00 AM	0
9/19/2014	3:45:00 AM	0
9/19/2014	4:00:00 AM	0
9/19/2014	4:15:00 AM	0
9/19/2014	4:30:00 AM	0
9/19/2014	4:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/19/2014	5:00:00 AM	0
9/19/2014	5:15:00 AM	0
9/19/2014	5:30:00 AM	0
9/19/2014	5:45:00 AM	0
9/19/2014	6:00:00 AM	0
9/19/2014	6:15:00 AM	0
9/19/2014	6:30:00 AM	0.01
9/19/2014	6:45:00 AM	0.01
9/19/2014	7:00:00 AM	0.01
9/19/2014	7:15:00 AM	0.01
9/19/2014	7:30:00 AM	0.01
9/19/2014	7:45:00 AM	0.01
9/19/2014	8:00:00 AM	0.01
9/19/2014	8:15:00 AM	0.01
9/19/2014	8:30:00 AM	0.01
9/19/2014	8:45:00 AM	0.01
9/19/2014	9:00:00 AM	0.01
9/19/2014	9:15:00 AM	0.01
9/19/2014	9:30:00 AM	0.01
9/19/2014	9:45:00 AM	0
9/19/2014	10:00:00 AM	0
9/19/2014	10:15:00 AM	0
9/19/2014	10:30:00 AM	0
9/19/2014	10:45:00 AM	0
9/19/2014	11:00:00 AM	0
9/19/2014	11:15:00 AM	0
9/19/2014	11:30:00 AM	0
9/19/2014	11:45:00 AM	0
9/19/2014	12:00:00 PM	0
9/19/2014	12:15:00 PM	0
9/19/2014	12:30:00 PM	0
9/19/2014	12:45:00 PM	0
9/19/2014	1:00:00 PM	0
9/19/2014	1:15:00 PM	0
9/19/2014	1:30:00 PM	0
9/19/2014	1:45:00 PM	0
9/19/2014	2:00:00 PM	0
9/19/2014	2:15:00 PM	0
9/19/2014	2:30:00 PM	0
9/19/2014	2:45:00 PM	0
9/19/2014	3:00:00 PM	0
9/19/2014	3:15:00 PM	0
9/19/2014	3:30:00 PM	0
9/19/2014	3:45:00 PM	0
9/19/2014	4:00:00 PM	0
9/19/2014	4:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/19/2014	4:30:00 PM	0
9/19/2014	4:45:00 PM	0
9/19/2014	5:00:00 PM	0
9/19/2014	5:15:00 PM	0
9/19/2014	5:30:00 PM	0
9/19/2014	5:45:00 PM	0
9/19/2014	6:00:00 PM	0
9/19/2014	6:15:00 PM	0
9/19/2014	6:30:00 PM	0
9/19/2014	6:45:00 PM	0
9/19/2014	7:00:00 PM	0
9/19/2014	7:15:00 PM	0
9/19/2014	7:30:00 PM	0
9/19/2014	7:45:00 PM	0
9/19/2014	8:00:00 PM	0
9/19/2014	8:15:00 PM	0
9/19/2014	8:30:00 PM	0
9/19/2014	8:45:00 PM	0
9/19/2014	9:00:00 PM	0
9/19/2014	9:15:00 PM	0
9/19/2014	9:30:00 PM	0
9/19/2014	9:45:00 PM	0
9/19/2014	10:00:00 PM	0
9/19/2014	10:15:00 PM	0
9/19/2014	10:30:00 PM	0
9/19/2014	10:45:00 PM	0
9/19/2014	11:00:00 PM	0
9/19/2014	11:15:00 PM	0
9/19/2014	11:30:00 PM	0
9/19/2014	11:45:00 PM	0
9/20/2014	12:00:00 AM	0
9/20/2014	12:15:00 AM	0
9/20/2014	12:30:00 AM	0
9/20/2014	12:45:00 AM	0
9/20/2014	1:00:00 AM	0
9/20/2014	1:15:00 AM	0
9/20/2014	1:30:00 AM	0
9/20/2014	1:45:00 AM	0.01
9/20/2014	2:00:00 AM	0.01
9/20/2014	2:15:00 AM	0.01
9/20/2014	2:30:00 AM	0.01
9/20/2014	2:45:00 AM	0.01
9/20/2014	3:00:00 AM	0.01
9/20/2014	3:15:00 AM	0.01
9/20/2014	3:30:00 AM	0.01
9/20/2014	3:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/20/2014	4:00:00 AM	0.01
9/20/2014	4:15:00 AM	0.01
9/20/2014	4:30:00 AM	0.01
9/20/2014	4:45:00 AM	0.01
9/20/2014	5:00:00 AM	0.01
9/20/2014	5:15:00 AM	0.01
9/20/2014	5:30:00 AM	0.01
9/20/2014	5:45:00 AM	0.01
9/20/2014	6:00:00 AM	0.01
9/20/2014	6:15:00 AM	0.01
9/20/2014	6:30:00 AM	0.01
9/20/2014	6:45:00 AM	0.01
9/20/2014	7:00:00 AM	0.01
9/20/2014	7:15:00 AM	0.01
9/20/2014	7:30:00 AM	0.01
9/20/2014	7:45:00 AM	0.01
9/20/2014	8:00:00 AM	0.01
9/20/2014	8:15:00 AM	0.01
9/20/2014	8:30:00 AM	0.01
9/20/2014	8:45:00 AM	0.01
9/20/2014	9:00:00 AM	0.01
9/20/2014	9:15:00 AM	0.01
9/20/2014	9:30:00 AM	0.01
9/20/2014	9:45:00 AM	0.01
9/20/2014	10:00:00 AM	0.01
9/20/2014	10:15:00 AM	0.01
9/20/2014	10:30:00 AM	0.01
9/20/2014	10:45:00 AM	0.01
9/20/2014	11:00:00 AM	0.01
9/20/2014	11:15:00 AM	0.01
9/20/2014	11:30:00 AM	0.01
9/20/2014	11:45:00 AM	0.01
9/20/2014	12:00:00 PM	0.01
9/20/2014	12:15:00 PM	0.01
9/20/2014	12:30:00 PM	0.01
9/20/2014	12:45:00 PM	0
9/20/2014	1:00:00 PM	0
9/20/2014	1:15:00 PM	0
9/20/2014	1:30:00 PM	0
9/20/2014	1:45:00 PM	0
9/20/2014	2:00:00 PM	0
9/20/2014	2:15:00 PM	0
9/20/2014	2:30:00 PM	0
9/20/2014	2:45:00 PM	0
9/20/2014	3:00:00 PM	0
9/20/2014	3:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/20/2014	3:30:00 PM	0
9/20/2014	3:45:00 PM	0
9/20/2014	4:00:00 PM	0
9/20/2014	4:15:00 PM	0
9/20/2014	4:30:00 PM	0
9/20/2014	4:45:00 PM	0
9/20/2014	5:00:00 PM	0
9/20/2014	5:15:00 PM	0
9/20/2014	5:30:00 PM	0
9/20/2014	5:45:00 PM	0
9/20/2014	6:00:00 PM	0
9/20/2014	6:15:00 PM	0
9/20/2014	6:30:00 PM	0
9/20/2014	6:45:00 PM	0
9/20/2014	7:00:00 PM	0
9/20/2014	7:15:00 PM	0
9/20/2014	7:30:00 PM	0
9/20/2014	7:45:00 PM	0
9/20/2014	8:00:00 PM	0
9/20/2014	8:15:00 PM	0
9/20/2014	8:30:00 PM	0
9/20/2014	8:45:00 PM	0
9/20/2014	9:00:00 PM	0
9/20/2014	9:15:00 PM	0
9/20/2014	9:30:00 PM	0
9/20/2014	9:45:00 PM	0
9/20/2014	10:00:00 PM	0
9/20/2014	10:15:00 PM	0
9/20/2014	10:30:00 PM	0
9/20/2014	10:45:00 PM	0
9/20/2014	11:00:00 PM	0
9/20/2014	11:15:00 PM	0
9/20/2014	11:30:00 PM	0
9/20/2014	11:45:00 PM	0
9/21/2014	12:00:00 AM	0
9/21/2014	12:15:00 AM	0
9/21/2014	12:30:00 AM	0
9/21/2014	12:45:00 AM	0
9/21/2014	1:00:00 AM	0
9/21/2014	1:15:00 AM	0
9/21/2014	1:30:00 AM	0
9/21/2014	1:45:00 AM	0
9/21/2014	2:00:00 AM	0.01
9/21/2014	2:15:00 AM	0.01
9/21/2014	2:30:00 AM	0.01
9/21/2014	2:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/21/2014	3:00:00 AM	0.01
9/21/2014	3:15:00 AM	0.01
9/21/2014	3:30:00 AM	0.01
9/21/2014	3:45:00 AM	0.01
9/21/2014	4:00:00 AM	0.01
9/21/2014	4:15:00 AM	0.01
9/21/2014	4:30:00 AM	0.01
9/21/2014	4:45:00 AM	0.01
9/21/2014	5:00:00 AM	0.01
9/21/2014	5:15:00 AM	0.01
9/21/2014	5:30:00 AM	0.01
9/21/2014	5:45:00 AM	0.01
9/21/2014	6:00:00 AM	0.01
9/21/2014	6:15:00 AM	0.01
9/21/2014	6:30:00 AM	0.01
9/21/2014	6:45:00 AM	0.01
9/21/2014	7:00:00 AM	0.01
9/21/2014	7:15:00 AM	0.01
9/21/2014	7:30:00 AM	0.01
9/21/2014	7:45:00 AM	0.01
9/21/2014	8:00:00 AM	0.01
9/21/2014	8:15:00 AM	0.01
9/21/2014	8:30:00 AM	0.01
9/21/2014	8:45:00 AM	0.01
9/21/2014	9:00:00 AM	0.01
9/21/2014	9:15:00 AM	0.01
9/21/2014	9:30:00 AM	0.01
9/21/2014	9:45:00 AM	0.01
9/21/2014	10:00:00 AM	0.01
9/21/2014	10:15:00 AM	0.01
9/21/2014	10:30:00 AM	0.01
9/21/2014	10:45:00 AM	0.01
9/21/2014	11:00:00 AM	0.01
9/21/2014	11:15:00 AM	0.01
9/21/2014	11:30:00 AM	0.01
9/21/2014	11:45:00 AM	0.01
9/21/2014	12:00:00 PM	0.01
9/21/2014	12:15:00 PM	0.01
9/21/2014	12:30:00 PM	0.01
9/21/2014	12:45:00 PM	0
9/21/2014	1:00:00 PM	0
9/21/2014	1:15:00 PM	0
9/21/2014	1:30:00 PM	0
9/21/2014	1:45:00 PM	0
9/21/2014	2:00:00 PM	0
9/21/2014	2:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/21/2014	2:30:00 PM	0
9/21/2014	2:45:00 PM	0
9/21/2014	3:00:00 PM	0
9/21/2014	3:15:00 PM	0
9/21/2014	3:30:00 PM	0
9/21/2014	3:45:00 PM	0
9/21/2014	4:00:00 PM	0
9/21/2014	4:15:00 PM	0
9/21/2014	4:30:00 PM	0
9/21/2014	4:45:00 PM	0
9/21/2014	5:00:00 PM	0
9/21/2014	5:15:00 PM	0
9/21/2014	5:30:00 PM	0
9/21/2014	5:45:00 PM	0
9/21/2014	6:00:00 PM	0
9/21/2014	6:15:00 PM	0
9/21/2014	6:30:00 PM	0
9/21/2014	6:45:00 PM	0
9/21/2014	7:00:00 PM	0
9/21/2014	7:15:00 PM	0
9/21/2014	7:30:00 PM	0
9/21/2014	7:45:00 PM	0
9/21/2014	8:00:00 PM	0
9/21/2014	8:15:00 PM	0
9/21/2014	8:30:00 PM	0
9/21/2014	8:45:00 PM	0
9/21/2014	9:00:00 PM	0
9/21/2014	9:15:00 PM	0
9/21/2014	9:30:00 PM	0
9/21/2014	9:45:00 PM	0
9/21/2014	10:00:00 PM	0
9/21/2014	10:15:00 PM	0
9/21/2014	10:30:00 PM	0
9/21/2014	10:45:00 PM	0
9/21/2014	11:00:00 PM	0
9/21/2014	11:15:00 PM	0
9/21/2014	11:30:00 PM	0
9/21/2014	11:45:00 PM	0.01
9/22/2014	12:00:00 AM	0.01
9/22/2014	12:15:00 AM	0.01
9/22/2014	12:30:00 AM	0.01
9/22/2014	12:45:00 AM	0.01
9/22/2014	1:00:00 AM	0.01
9/22/2014	1:15:00 AM	0.01
9/22/2014	1:30:00 AM	0.01
9/22/2014	1:45:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/22/2014	2:00:00 AM	0.01
9/22/2014	2:15:00 AM	0.01
9/22/2014	2:30:00 AM	0.01
9/22/2014	2:45:00 AM	0.01
9/22/2014	3:00:00 AM	0.01
9/22/2014	3:15:00 AM	0.01
9/22/2014	3:30:00 AM	0.01
9/22/2014	3:45:00 AM	0.01
9/22/2014	4:00:00 AM	0.01
9/22/2014	4:15:00 AM	0.01
9/22/2014	4:30:00 AM	0.01
9/22/2014	4:45:00 AM	0.01
9/22/2014	5:00:00 AM	0.01
9/22/2014	5:15:00 AM	0.01
9/22/2014	5:30:00 AM	0.01
9/22/2014	5:45:00 AM	0.01
9/22/2014	6:00:00 AM	0.01
9/22/2014	6:15:00 AM	0.01
9/22/2014	6:30:00 AM	0.01
9/22/2014	6:45:00 AM	0.01
9/22/2014	7:00:00 AM	0.01
9/22/2014	7:15:00 AM	0.01
9/22/2014	7:30:00 AM	0.01
9/22/2014	7:45:00 AM	0.01
9/22/2014	8:00:00 AM	0.01
9/22/2014	8:15:00 AM	0.01
9/22/2014	8:30:00 AM	0.01
9/22/2014	8:45:00 AM	0.01
9/22/2014	9:00:00 AM	0.01
9/22/2014	9:15:00 AM	0.01
9/22/2014	9:30:00 AM	0.01
9/22/2014	9:45:00 AM	0.01
9/22/2014	10:00:00 AM	0.01
9/22/2014	10:15:00 AM	0.01
9/22/2014	10:30:00 AM	0.01
9/22/2014	10:45:00 AM	0.01
9/22/2014	11:00:00 AM	0.01
9/22/2014	11:15:00 AM	0.01
9/22/2014	11:30:00 AM	0.01
9/22/2014	11:45:00 AM	0.01
9/22/2014	12:00:00 PM	0.01
9/22/2014	12:15:00 PM	0.01
9/22/2014	12:30:00 PM	0.01
9/22/2014	12:45:00 PM	0
9/22/2014	1:00:00 PM	0
9/22/2014	1:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/22/2014	1:30:00 PM	0
9/22/2014	1:45:00 PM	0
9/22/2014	2:00:00 PM	0
9/22/2014	2:15:00 PM	0
9/22/2014	2:30:00 PM	0
9/22/2014	2:45:00 PM	0
9/22/2014	3:00:00 PM	0
9/22/2014	3:15:00 PM	0
9/22/2014	3:30:00 PM	0
9/22/2014	3:45:00 PM	0
9/22/2014	4:00:00 PM	0
9/22/2014	4:15:00 PM	0
9/22/2014	4:30:00 PM	0
9/22/2014	4:45:00 PM	0
9/22/2014	5:00:00 PM	0
9/22/2014	5:15:00 PM	0
9/22/2014	5:30:00 PM	0
9/22/2014	5:45:00 PM	0
9/22/2014	6:00:00 PM	0
9/22/2014	6:15:00 PM	0
9/22/2014	6:30:00 PM	0
9/22/2014	6:45:00 PM	0
9/22/2014	7:00:00 PM	0
9/22/2014	7:15:00 PM	0
9/22/2014	7:30:00 PM	0
9/22/2014	7:45:00 PM	0
9/22/2014	8:00:00 PM	0
9/22/2014	8:15:00 PM	0
9/22/2014	8:30:00 PM	0
9/22/2014	8:45:00 PM	0
9/22/2014	9:00:00 PM	0
9/22/2014	9:15:00 PM	0
9/22/2014	9:30:00 PM	0
9/22/2014	9:45:00 PM	0
9/22/2014	10:00:00 PM	0
9/22/2014	10:15:00 PM	0
9/22/2014	10:30:00 PM	0
9/22/2014	10:45:00 PM	0
9/22/2014	11:00:00 PM	0
9/22/2014	11:15:00 PM	0
9/22/2014	11:30:00 PM	0
9/22/2014	11:45:00 PM	0
9/23/2014	12:00:00 AM	0
9/23/2014	12:15:00 AM	0
9/23/2014	12:30:00 AM	0
9/23/2014	12:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/23/2014	1:00:00 AM	0
9/23/2014	1:15:00 AM	0
9/23/2014	1:30:00 AM	0
9/23/2014	1:45:00 AM	0
9/23/2014	2:00:00 AM	0
9/23/2014	2:15:00 AM	0
9/23/2014	2:30:00 AM	0
9/23/2014	2:45:00 AM	0
9/23/2014	3:00:00 AM	0
9/23/2014	3:15:00 AM	0.01
9/23/2014	3:30:00 AM	0.01
9/23/2014	3:45:00 AM	0.01
9/23/2014	4:00:00 AM	0.01
9/23/2014	4:15:00 AM	0.01
9/23/2014	4:30:00 AM	0.01
9/23/2014	4:45:00 AM	0.01
9/23/2014	5:00:00 AM	0.01
9/23/2014	5:15:00 AM	0.01
9/23/2014	5:30:00 AM	0.01
9/23/2014	5:45:00 AM	0.01
9/23/2014	6:00:00 AM	0.01
9/23/2014	6:15:00 AM	0.01
9/23/2014	6:30:00 AM	0.01
9/23/2014	6:45:00 AM	0.01
9/23/2014	7:00:00 AM	0.01
9/23/2014	7:15:00 AM	0.01
9/23/2014	7:30:00 AM	0.01
9/23/2014	7:45:00 AM	0.01
9/23/2014	8:00:00 AM	0.01
9/23/2014	8:15:00 AM	0.01
9/23/2014	8:30:00 AM	0.01
9/23/2014	8:45:00 AM	0.01
9/23/2014	9:00:00 AM	0.01
9/23/2014	9:15:00 AM	0.01
9/23/2014	9:30:00 AM	0.01
9/23/2014	9:45:00 AM	0.01
9/23/2014	10:00:00 AM	0.01
9/23/2014	10:15:00 AM	0
9/23/2014	10:30:00 AM	0
9/23/2014	10:45:00 AM	0
9/23/2014	11:00:00 AM	0
9/23/2014	11:15:00 AM	0
9/23/2014	11:30:00 AM	0
9/23/2014	11:45:00 AM	0
9/23/2014	12:00:00 PM	0
9/23/2014	12:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/23/2014	12:30:00 PM	0
9/23/2014	12:45:00 PM	0
9/23/2014	1:00:00 PM	0
9/23/2014	1:15:00 PM	0
9/23/2014	1:30:00 PM	0
9/23/2014	1:45:00 PM	0
9/23/2014	2:00:00 PM	0
9/23/2014	2:15:00 PM	0
9/23/2014	2:30:00 PM	0
9/23/2014	2:45:00 PM	0
9/23/2014	3:00:00 PM	0
9/23/2014	3:15:00 PM	0
9/23/2014	3:30:00 PM	0
9/23/2014	3:45:00 PM	0
9/23/2014	4:00:00 PM	0
9/23/2014	4:15:00 PM	0
9/23/2014	4:30:00 PM	0
9/23/2014	4:45:00 PM	0
9/23/2014	5:00:00 PM	0
9/23/2014	5:15:00 PM	0
9/23/2014	5:30:00 PM	0
9/23/2014	5:45:00 PM	0
9/23/2014	6:00:00 PM	0
9/23/2014	6:15:00 PM	0
9/23/2014	6:30:00 PM	0
9/23/2014	6:45:00 PM	0
9/23/2014	7:00:00 PM	0
9/23/2014	7:15:00 PM	0
9/23/2014	7:30:00 PM	0
9/23/2014	7:45:00 PM	0
9/23/2014	8:00:00 PM	0
9/23/2014	8:15:00 PM	0
9/23/2014	8:30:00 PM	0
9/23/2014	8:45:00 PM	0
9/23/2014	9:00:00 PM	0
9/23/2014	9:15:00 PM	0
9/23/2014	9:30:00 PM	0
9/23/2014	9:45:00 PM	0
9/23/2014	10:00:00 PM	0
9/23/2014	10:15:00 PM	0
9/23/2014	10:30:00 PM	0
9/23/2014	10:45:00 PM	0
9/23/2014	11:00:00 PM	0
9/23/2014	11:15:00 PM	0
9/23/2014	11:30:00 PM	0
9/23/2014	11:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	12:00:00 AM	0
9/24/2014	12:15:00 AM	0
9/24/2014	12:30:00 AM	0
9/24/2014	12:45:00 AM	0
9/24/2014	1:00:00 AM	0
9/24/2014	1:15:00 AM	0
9/24/2014	1:30:00 AM	0
9/24/2014	1:45:00 AM	0
9/24/2014	2:00:00 AM	0
9/24/2014	2:15:00 AM	0
9/24/2014	2:30:00 AM	0
9/24/2014	2:45:00 AM	0
9/24/2014	3:00:00 AM	0
9/24/2014	3:15:00 AM	0
9/24/2014	3:30:00 AM	0
9/24/2014	3:45:00 AM	0
9/24/2014	4:00:00 AM	0
9/24/2014	4:15:00 AM	0
9/24/2014	4:30:00 AM	0
9/24/2014	4:45:00 AM	0.01
9/24/2014	5:00:00 AM	0.01
9/24/2014	5:15:00 AM	0.01
9/24/2014	5:30:00 AM	0.01
9/24/2014	5:45:00 AM	0.01
9/24/2014	6:00:00 AM	0.01
9/24/2014	6:15:00 AM	0.01
9/24/2014	6:30:00 AM	0.01
9/24/2014	6:45:00 AM	0.01
9/24/2014	7:00:00 AM	0.01
9/24/2014	7:15:00 AM	0.01
9/24/2014	7:30:00 AM	0.01
9/24/2014	7:45:00 AM	0.01
9/24/2014	8:00:00 AM	0.01
9/24/2014	8:15:00 AM	0.01
9/24/2014	8:30:00 AM	0.01
9/24/2014	8:45:00 AM	0.01
9/24/2014	9:00:00 AM	0.01
9/24/2014	9:15:00 AM	0.01
9/24/2014	9:30:00 AM	0.01
9/24/2014	9:45:00 AM	0.01
9/24/2014	10:00:00 AM	0.01
9/24/2014	10:15:00 AM	0.01
9/24/2014	10:30:00 AM	0.01
9/24/2014	10:45:00 AM	0.01
9/24/2014	11:00:00 AM	0.01
9/24/2014	11:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	11:30:00 AM	0.01
9/24/2014	11:45:00 AM	0.01
9/24/2014	12:00:00 PM	0.01
9/24/2014	12:15:00 PM	0
9/24/2014	12:30:00 PM	0
9/24/2014	12:45:00 PM	0
9/24/2014	1:00:00 PM	0
9/24/2014	1:15:00 PM	0
9/24/2014	1:30:00 PM	0
9/24/2014	1:45:00 PM	0
9/24/2014	2:00:00 PM	0
9/24/2014	2:15:00 PM	0
9/24/2014	2:30:00 PM	0
9/24/2014	2:45:00 PM	0
9/24/2014	3:00:00 PM	0
9/24/2014	3:15:00 PM	0
9/24/2014	3:30:00 PM	0
9/24/2014	3:45:00 PM	0
9/24/2014	4:00:00 PM	0
9/24/2014	4:15:00 PM	0
9/24/2014	4:30:00 PM	0
9/24/2014	4:45:00 PM	0
9/24/2014	5:00:00 PM	0
9/24/2014	5:15:00 PM	0
9/24/2014	5:30:00 PM	0
9/24/2014	5:45:00 PM	0
9/24/2014	6:00:00 PM	0
9/24/2014	6:15:00 PM	0
9/24/2014	6:30:00 PM	0
9/24/2014	6:45:00 PM	0
9/24/2014	7:00:00 PM	0
9/24/2014	7:15:00 PM	0
9/24/2014	7:30:00 PM	0
9/24/2014	7:45:00 PM	0
9/24/2014	8:00:00 PM	0
9/24/2014	8:15:00 PM	0
9/24/2014	8:30:00 PM	0
9/24/2014	8:45:00 PM	0
9/24/2014	9:00:00 PM	0
9/24/2014	9:15:00 PM	0
9/24/2014	9:30:00 PM	0
9/24/2014	9:45:00 PM	0
9/24/2014	10:00:00 PM	0
9/24/2014	10:15:00 PM	0
9/24/2014	10:30:00 PM	0
9/24/2014	10:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/24/2014	11:00:00 PM	0
9/24/2014	11:15:00 PM	0
9/24/2014	11:30:00 PM	0
9/24/2014	11:45:00 PM	0
9/25/2014	12:00:00 AM	0
9/25/2014	12:15:00 AM	0
9/25/2014	12:30:00 AM	0
9/25/2014	12:45:00 AM	0
9/25/2014	1:00:00 AM	0
9/25/2014	1:15:00 AM	0
9/25/2014	1:30:00 AM	0
9/25/2014	1:45:00 AM	0
9/25/2014	2:00:00 AM	0
9/25/2014	2:15:00 AM	0
9/25/2014	2:30:00 AM	0
9/25/2014	2:45:00 AM	0
9/25/2014	3:00:00 AM	0
9/25/2014	3:15:00 AM	0
9/25/2014	3:30:00 AM	0
9/25/2014	3:45:00 AM	0
9/25/2014	4:00:00 AM	0
9/25/2014	4:15:00 AM	0
9/25/2014	4:30:00 AM	0
9/25/2014	4:45:00 AM	0
9/25/2014	5:00:00 AM	0
9/25/2014	5:15:00 AM	0
9/25/2014	5:30:00 AM	0
9/25/2014	5:45:00 AM	0
9/25/2014	6:00:00 AM	0
9/25/2014	6:15:00 AM	0
9/25/2014	6:30:00 AM	0
9/25/2014	6:45:00 AM	0
9/25/2014	7:00:00 AM	0
9/25/2014	7:15:00 AM	0
9/25/2014	7:30:00 AM	0
9/25/2014	7:45:00 AM	0
9/25/2014	8:00:00 AM	0
9/25/2014	8:15:00 AM	0
9/25/2014	8:30:00 AM	0
9/25/2014	8:45:00 AM	0
9/25/2014	9:00:00 AM	0
9/25/2014	9:15:00 AM	0
9/25/2014	9:30:00 AM	0
9/25/2014	9:45:00 AM	0
9/25/2014	10:00:00 AM	0
9/25/2014	10:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/25/2014	10:30:00 AM	0
9/25/2014	10:45:00 AM	0
9/25/2014	11:00:00 AM	0
9/25/2014	11:15:00 AM	0
9/25/2014	11:30:00 AM	0
9/25/2014	11:45:00 AM	0
9/25/2014	12:00:00 PM	0
9/25/2014	12:15:00 PM	0
9/25/2014	12:30:00 PM	0
9/25/2014	12:45:00 PM	0
9/25/2014	1:00:00 PM	0
9/25/2014	1:15:00 PM	0
9/25/2014	1:30:00 PM	0
9/25/2014	1:45:00 PM	0
9/25/2014	2:00:00 PM	0
9/25/2014	2:15:00 PM	0
9/25/2014	2:30:00 PM	0
9/25/2014	2:45:00 PM	0
9/25/2014	3:00:00 PM	0
9/25/2014	3:15:00 PM	0
9/25/2014	3:30:00 PM	0
9/25/2014	3:45:00 PM	0
9/25/2014	4:00:00 PM	0
9/25/2014	4:15:00 PM	0
9/25/2014	4:30:00 PM	0
9/25/2014	4:45:00 PM	0
9/25/2014	5:00:00 PM	0
9/25/2014	5:15:00 PM	0
9/25/2014	5:30:00 PM	0
9/25/2014	5:45:00 PM	0
9/25/2014	6:00:00 PM	0
9/25/2014	6:15:00 PM	0
9/25/2014	6:30:00 PM	0
9/25/2014	6:45:00 PM	0
9/25/2014	7:00:00 PM	0
9/25/2014	7:15:00 PM	0
9/25/2014	7:30:00 PM	0
9/25/2014	7:45:00 PM	0
9/25/2014	8:00:00 PM	0
9/25/2014	8:15:00 PM	0
9/25/2014	8:30:00 PM	0
9/25/2014	8:45:00 PM	0
9/25/2014	9:00:00 PM	0
9/25/2014	9:15:00 PM	0
9/25/2014	9:30:00 PM	0
9/25/2014	9:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/25/2014	10:00:00 PM	0
9/25/2014	10:15:00 PM	0
9/25/2014	10:30:00 PM	0
9/25/2014	10:45:00 PM	0
9/25/2014	11:00:00 PM	0
9/25/2014	11:15:00 PM	0
9/25/2014	11:30:00 PM	0
9/25/2014	11:45:00 PM	0
9/26/2014	12:00:00 AM	0
9/26/2014	12:15:00 AM	0
9/26/2014	12:30:00 AM	0
9/26/2014	12:45:00 AM	0
9/26/2014	1:00:00 AM	0
9/26/2014	1:15:00 AM	0
9/26/2014	1:30:00 AM	0
9/26/2014	1:45:00 AM	0
9/26/2014	2:00:00 AM	0
9/26/2014	2:15:00 AM	0
9/26/2014	2:30:00 AM	0
9/26/2014	2:45:00 AM	0
9/26/2014	3:00:00 AM	0
9/26/2014	3:15:00 AM	0
9/26/2014	3:30:00 AM	0
9/26/2014	3:45:00 AM	0
9/26/2014	4:00:00 AM	0
9/26/2014	4:15:00 AM	0
9/26/2014	4:30:00 AM	0
9/26/2014	4:45:00 AM	0
9/26/2014	5:00:00 AM	0
9/26/2014	5:15:00 AM	0
9/26/2014	5:30:00 AM	0
9/26/2014	5:45:00 AM	0
9/26/2014	6:00:00 AM	0
9/26/2014	6:15:00 AM	0
9/26/2014	6:30:00 AM	0
9/26/2014	6:45:00 AM	0
9/26/2014	7:00:00 AM	0
9/26/2014	7:15:00 AM	0
9/26/2014	7:30:00 AM	0
9/26/2014	7:45:00 AM	0
9/26/2014	8:00:00 AM	0
9/26/2014	8:15:00 AM	0
9/26/2014	8:30:00 AM	0
9/26/2014	8:45:00 AM	0
9/26/2014	9:00:00 AM	0
9/26/2014	9:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/26/2014	9:30:00 AM	0
9/26/2014	9:45:00 AM	0
9/26/2014	10:00:00 AM	0
9/26/2014	10:15:00 AM	0
9/26/2014	10:30:00 AM	0
9/26/2014	10:45:00 AM	0
9/26/2014	11:00:00 AM	0
9/26/2014	11:15:00 AM	0
9/26/2014	11:30:00 AM	0
9/26/2014	11:45:00 AM	0
9/26/2014	12:00:00 PM	0
9/26/2014	12:15:00 PM	0
9/26/2014	12:30:00 PM	0
9/26/2014	12:45:00 PM	0
9/26/2014	1:00:00 PM	0
9/26/2014	1:15:00 PM	0
9/26/2014	1:30:00 PM	0
9/26/2014	1:45:00 PM	0
9/26/2014	2:00:00 PM	0
9/26/2014	2:15:00 PM	0
9/26/2014	2:30:00 PM	0
9/26/2014	2:45:00 PM	0
9/26/2014	3:00:00 PM	0
9/26/2014	3:15:00 PM	0
9/26/2014	3:30:00 PM	0
9/26/2014	3:45:00 PM	0
9/26/2014	4:00:00 PM	0
9/26/2014	4:15:00 PM	0
9/26/2014	4:30:00 PM	0
9/26/2014	4:45:00 PM	0
9/26/2014	5:00:00 PM	0
9/26/2014	5:15:00 PM	0
9/26/2014	5:30:00 PM	0
9/26/2014	5:45:00 PM	0
9/26/2014	6:00:00 PM	0
9/26/2014	6:15:00 PM	0
9/26/2014	6:30:00 PM	0
9/26/2014	6:45:00 PM	0
9/26/2014	7:00:00 PM	0
9/26/2014	7:15:00 PM	0
9/26/2014	7:30:00 PM	0
9/26/2014	7:45:00 PM	0
9/26/2014	8:00:00 PM	0
9/26/2014	8:15:00 PM	0
9/26/2014	8:30:00 PM	0
9/26/2014	8:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/26/2014	9:00:00 PM	0
9/26/2014	9:15:00 PM	0
9/26/2014	9:30:00 PM	0
9/26/2014	9:45:00 PM	0
9/26/2014	10:00:00 PM	0
9/26/2014	10:15:00 PM	0
9/26/2014	10:30:00 PM	0
9/26/2014	10:45:00 PM	0
9/26/2014	11:00:00 PM	0
9/26/2014	11:15:00 PM	0
9/26/2014	11:30:00 PM	0
9/26/2014	11:45:00 PM	0
9/27/2014	12:00:00 AM	0
9/27/2014	12:15:00 AM	0
9/27/2014	12:30:00 AM	0
9/27/2014	12:45:00 AM	0
9/27/2014	1:00:00 AM	0
9/27/2014	1:15:00 AM	0
9/27/2014	1:30:00 AM	0
9/27/2014	1:45:00 AM	0
9/27/2014	2:00:00 AM	0
9/27/2014	2:15:00 AM	0
9/27/2014	2:30:00 AM	0
9/27/2014	2:45:00 AM	0
9/27/2014	3:00:00 AM	0
9/27/2014	3:15:00 AM	0
9/27/2014	3:30:00 AM	0
9/27/2014	3:45:00 AM	0
9/27/2014	4:00:00 AM	0
9/27/2014	4:15:00 AM	0
9/27/2014	4:30:00 AM	0
9/27/2014	4:45:00 AM	0
9/27/2014	5:00:00 AM	0
9/27/2014	5:15:00 AM	0
9/27/2014	5:30:00 AM	0
9/27/2014	5:45:00 AM	0
9/27/2014	6:00:00 AM	0
9/27/2014	6:15:00 AM	0
9/27/2014	6:30:00 AM	0
9/27/2014	6:45:00 AM	0
9/27/2014	7:00:00 AM	0
9/27/2014	7:15:00 AM	0
9/27/2014	7:30:00 AM	0
9/27/2014	7:45:00 AM	0
9/27/2014	8:00:00 AM	0
9/27/2014	8:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/27/2014	8:30:00 AM	0
9/27/2014	8:45:00 AM	0
9/27/2014	9:00:00 AM	0
9/27/2014	9:15:00 AM	0
9/27/2014	9:30:00 AM	0
9/27/2014	9:45:00 AM	0
9/27/2014	10:00:00 AM	0
9/27/2014	10:15:00 AM	0
9/27/2014	10:30:00 AM	0
9/27/2014	10:45:00 AM	0
9/27/2014	11:00:00 AM	0
9/27/2014	11:15:00 AM	0
9/27/2014	11:30:00 AM	0
9/27/2014	11:45:00 AM	0
9/27/2014	12:00:00 PM	0
9/27/2014	12:15:00 PM	0
9/27/2014	12:30:00 PM	0
9/27/2014	12:45:00 PM	0
9/27/2014	1:00:00 PM	0
9/27/2014	1:15:00 PM	0
9/27/2014	1:30:00 PM	0
9/27/2014	1:45:00 PM	0
9/27/2014	2:00:00 PM	0
9/27/2014	2:15:00 PM	0
9/27/2014	2:30:00 PM	0
9/27/2014	2:45:00 PM	0
9/27/2014	3:00:00 PM	0
9/27/2014	3:15:00 PM	0
9/27/2014	3:30:00 PM	0
9/27/2014	3:45:00 PM	0
9/27/2014	4:00:00 PM	0
9/27/2014	4:15:00 PM	0
9/27/2014	4:30:00 PM	0
9/27/2014	4:45:00 PM	0
9/27/2014	5:00:00 PM	0
9/27/2014	5:15:00 PM	0
9/27/2014	5:30:00 PM	0
9/27/2014	5:45:00 PM	0
9/27/2014	6:00:00 PM	0
9/27/2014	6:15:00 PM	0
9/27/2014	6:30:00 PM	0
9/27/2014	6:45:00 PM	0
9/27/2014	7:00:00 PM	0
9/27/2014	7:15:00 PM	0
9/27/2014	7:30:00 PM	0
9/27/2014	7:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/27/2014	8:00:00 PM	0
9/27/2014	8:15:00 PM	0
9/27/2014	8:30:00 PM	0
9/27/2014	8:45:00 PM	0
9/27/2014	9:00:00 PM	0
9/27/2014	9:15:00 PM	0
9/27/2014	9:30:00 PM	0
9/27/2014	9:45:00 PM	0
9/27/2014	10:00:00 PM	0
9/27/2014	10:15:00 PM	0
9/27/2014	10:30:00 PM	0
9/27/2014	10:45:00 PM	0
9/27/2014	11:00:00 PM	0
9/27/2014	11:15:00 PM	0
9/27/2014	11:30:00 PM	0
9/27/2014	11:45:00 PM	0
9/28/2014	12:00:00 AM	0
9/28/2014	12:15:00 AM	0
9/28/2014	12:30:00 AM	0
9/28/2014	12:45:00 AM	0
9/28/2014	1:00:00 AM	0
9/28/2014	1:15:00 AM	0
9/28/2014	1:30:00 AM	0.01
9/28/2014	1:45:00 AM	0.01
9/28/2014	2:00:00 AM	0.01
9/28/2014	2:15:00 AM	0.01
9/28/2014	2:30:00 AM	0.01
9/28/2014	2:45:00 AM	0.01
9/28/2014	3:00:00 AM	0.01
9/28/2014	3:15:00 AM	0.01
9/28/2014	3:30:00 AM	0.01
9/28/2014	3:45:00 AM	0.01
9/28/2014	4:00:00 AM	0.01
9/28/2014	4:15:00 AM	0.01
9/28/2014	4:30:00 AM	0.01
9/28/2014	4:45:00 AM	0.01
9/28/2014	5:00:00 AM	0.01
9/28/2014	5:15:00 AM	0.01
9/28/2014	5:30:00 AM	0.01
9/28/2014	5:45:00 AM	0.01
9/28/2014	6:00:00 AM	0.01
9/28/2014	6:15:00 AM	0.01
9/28/2014	6:30:00 AM	0.01
9/28/2014	6:45:00 AM	0.01
9/28/2014	7:00:00 AM	0.01
9/28/2014	7:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/28/2014	7:30:00 AM	0.01
9/28/2014	7:45:00 AM	0.01
9/28/2014	8:00:00 AM	0.01
9/28/2014	8:15:00 AM	0.01
9/28/2014	8:30:00 AM	0.01
9/28/2014	8:45:00 AM	0.01
9/28/2014	9:00:00 AM	0.01
9/28/2014	9:15:00 AM	0.01
9/28/2014	9:30:00 AM	0.01
9/28/2014	9:45:00 AM	0.01
9/28/2014	10:00:00 AM	0.01
9/28/2014	10:15:00 AM	0.01
9/28/2014	10:30:00 AM	0.01
9/28/2014	10:45:00 AM	0.01
9/28/2014	11:00:00 AM	0.01
9/28/2014	11:15:00 AM	0.01
9/28/2014	11:30:00 AM	0.01
9/28/2014	11:45:00 AM	0.01
9/28/2014	12:00:00 PM	0
9/28/2014	12:15:00 PM	0
9/28/2014	12:30:00 PM	0
9/28/2014	12:45:00 PM	0
9/28/2014	1:00:00 PM	0
9/28/2014	1:15:00 PM	0
9/28/2014	1:30:00 PM	0
9/28/2014	1:45:00 PM	0
9/28/2014	2:00:00 PM	0
9/28/2014	2:15:00 PM	0
9/28/2014	2:30:00 PM	0
9/28/2014	2:45:00 PM	0
9/28/2014	3:00:00 PM	0
9/28/2014	3:15:00 PM	0
9/28/2014	3:30:00 PM	0
9/28/2014	3:45:00 PM	0
9/28/2014	4:00:00 PM	0
9/28/2014	4:15:00 PM	0
9/28/2014	4:30:00 PM	0
9/28/2014	4:45:00 PM	0
9/28/2014	5:00:00 PM	0
9/28/2014	5:15:00 PM	0
9/28/2014	5:30:00 PM	0
9/28/2014	5:45:00 PM	0
9/28/2014	6:00:00 PM	0
9/28/2014	6:15:00 PM	0
9/28/2014	6:30:00 PM	0
9/28/2014	6:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/28/2014	7:00:00 PM	0
9/28/2014	7:15:00 PM	0
9/28/2014	7:30:00 PM	0
9/28/2014	7:45:00 PM	0
9/28/2014	8:00:00 PM	0
9/28/2014	8:15:00 PM	0
9/28/2014	8:30:00 PM	0
9/28/2014	8:45:00 PM	0
9/28/2014	9:00:00 PM	0
9/28/2014	9:15:00 PM	0
9/28/2014	9:30:00 PM	0
9/28/2014	9:45:00 PM	0
9/28/2014	10:00:00 PM	0
9/28/2014	10:15:00 PM	0
9/28/2014	10:30:00 PM	0
9/28/2014	10:45:00 PM	0
9/28/2014	11:00:00 PM	0
9/28/2014	11:15:00 PM	0
9/28/2014	11:30:00 PM	0
9/28/2014	11:45:00 PM	0
9/29/2014	12:00:00 AM	0
9/29/2014	12:15:00 AM	0
9/29/2014	12:30:00 AM	0
9/29/2014	12:45:00 AM	0
9/29/2014	1:00:00 AM	0
9/29/2014	1:15:00 AM	0
9/29/2014	1:30:00 AM	0
9/29/2014	1:45:00 AM	0
9/29/2014	2:00:00 AM	0
9/29/2014	2:15:00 AM	0
9/29/2014	2:30:00 AM	0.01
9/29/2014	2:45:00 AM	0.01
9/29/2014	3:00:00 AM	0.01
9/29/2014	3:15:00 AM	0.01
9/29/2014	3:30:00 AM	0.01
9/29/2014	3:45:00 AM	0.01
9/29/2014	4:00:00 AM	0.01
9/29/2014	4:15:00 AM	0.01
9/29/2014	4:30:00 AM	0.01
9/29/2014	4:45:00 AM	0.01
9/29/2014	5:00:00 AM	0.01
9/29/2014	5:15:00 AM	0.01
9/29/2014	5:30:00 AM	0.01
9/29/2014	5:45:00 AM	0.01
9/29/2014	6:00:00 AM	0.01
9/29/2014	6:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/29/2014	6:30:00 AM	0.01
9/29/2014	6:45:00 AM	0.01
9/29/2014	7:00:00 AM	0.01
9/29/2014	7:15:00 AM	0.01
9/29/2014	7:30:00 AM	0.01
9/29/2014	7:45:00 AM	0.01
9/29/2014	8:00:00 AM	0.01
9/29/2014	8:15:00 AM	0.01
9/29/2014	8:30:00 AM	0.01
9/29/2014	8:45:00 AM	0.01
9/29/2014	9:00:00 AM	0.01
9/29/2014	9:15:00 AM	0.01
9/29/2014	9:30:00 AM	0.01
9/29/2014	9:45:00 AM	0.01
9/29/2014	10:00:00 AM	0.01
9/29/2014	10:15:00 AM	0.01
9/29/2014	10:30:00 AM	0.01
9/29/2014	10:45:00 AM	0.01
9/29/2014	11:00:00 AM	0
9/29/2014	11:15:00 AM	0
9/29/2014	11:30:00 AM	0
9/29/2014	11:45:00 AM	0
9/29/2014	12:00:00 PM	0
9/29/2014	12:15:00 PM	0
9/29/2014	12:30:00 PM	0
9/29/2014	12:45:00 PM	0
9/29/2014	1:00:00 PM	0
9/29/2014	1:15:00 PM	0
9/29/2014	1:30:00 PM	0
9/29/2014	1:45:00 PM	0
9/29/2014	2:00:00 PM	0
9/29/2014	2:15:00 PM	0
9/29/2014	2:30:00 PM	0
9/29/2014	2:45:00 PM	0
9/29/2014	3:00:00 PM	0
9/29/2014	3:15:00 PM	0
9/29/2014	3:30:00 PM	0
9/29/2014	3:45:00 PM	0
9/29/2014	4:00:00 PM	0
9/29/2014	4:15:00 PM	0
9/29/2014	4:30:00 PM	0
9/29/2014	4:45:00 PM	0
9/29/2014	5:00:00 PM	0
9/29/2014	5:15:00 PM	0
9/29/2014	5:30:00 PM	0
9/29/2014	5:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/29/2014	6:00:00 PM	0
9/29/2014	6:15:00 PM	0
9/29/2014	6:30:00 PM	0
9/29/2014	6:45:00 PM	0
9/29/2014	7:00:00 PM	0
9/29/2014	7:15:00 PM	0
9/29/2014	7:30:00 PM	0
9/29/2014	7:45:00 PM	0
9/29/2014	8:00:00 PM	0
9/29/2014	8:15:00 PM	0
9/29/2014	8:30:00 PM	0
9/29/2014	8:45:00 PM	0
9/29/2014	9:00:00 PM	0
9/29/2014	9:15:00 PM	0
9/29/2014	9:30:00 PM	0
9/29/2014	9:45:00 PM	0
9/29/2014	10:00:00 PM	0.01
9/29/2014	10:15:00 PM	0.01
9/29/2014	10:30:00 PM	0.01
9/29/2014	10:45:00 PM	0.01
9/29/2014	11:00:00 PM	0.01
9/29/2014	11:15:00 PM	0.01
9/29/2014	11:30:00 PM	0.01
9/29/2014	11:45:00 PM	0.01
9/30/2014	12:00:00 AM	0.01
9/30/2014	12:15:00 AM	0.01
9/30/2014	12:30:00 AM	0.01
9/30/2014	12:45:00 AM	0.01
9/30/2014	1:00:00 AM	0.01
9/30/2014	1:15:00 AM	0.01
9/30/2014	1:30:00 AM	0.01
9/30/2014	1:45:00 AM	0.01
9/30/2014	2:00:00 AM	0.01
9/30/2014	2:15:00 AM	0.01
9/30/2014	2:30:00 AM	0.01
9/30/2014	2:45:00 AM	0.01
9/30/2014	3:00:00 AM	0.01
9/30/2014	3:15:00 AM	0.01
9/30/2014	3:30:00 AM	0.01
9/30/2014	3:45:00 AM	0.01
9/30/2014	4:00:00 AM	0.01
9/30/2014	4:15:00 AM	0.01
9/30/2014	4:30:00 AM	0.01
9/30/2014	4:45:00 AM	0.01
9/30/2014	5:00:00 AM	0.01
9/30/2014	5:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
9/30/2014	5:30:00 AM	0.01
9/30/2014	5:45:00 AM	0.01
9/30/2014	6:00:00 AM	0.01
9/30/2014	6:15:00 AM	0.01
9/30/2014	6:30:00 AM	0.01
9/30/2014	6:45:00 AM	0.01
9/30/2014	7:00:00 AM	0.01
9/30/2014	7:15:00 AM	0.01
9/30/2014	7:30:00 AM	0.01
9/30/2014	7:45:00 AM	0.01
9/30/2014	8:00:00 AM	0.01
9/30/2014	8:15:00 AM	0.01
9/30/2014	8:30:00 AM	0.01
9/30/2014	8:45:00 AM	0.01
9/30/2014	9:00:00 AM	0.01
9/30/2014	9:15:00 AM	0.01
9/30/2014	9:30:00 AM	0.01
9/30/2014	9:45:00 AM	0.01
9/30/2014	10:00:00 AM	0.01
9/30/2014	10:15:00 AM	0.01
9/30/2014	10:30:00 AM	0.01
9/30/2014	10:45:00 AM	0.01
9/30/2014	11:00:00 AM	0.01
9/30/2014	11:15:00 AM	0.01
9/30/2014	11:30:00 AM	0.01
9/30/2014	11:45:00 AM	0.01
9/30/2014	12:00:00 PM	0.01
9/30/2014	12:15:00 PM	0.01
9/30/2014	12:30:00 PM	0.01
9/30/2014	12:45:00 PM	0.01
9/30/2014	1:00:00 PM	0.01
9/30/2014	1:15:00 PM	0.01
9/30/2014	1:30:00 PM	0
9/30/2014	1:45:00 PM	0
9/30/2014	2:00:00 PM	0
9/30/2014	2:15:00 PM	0
9/30/2014	2:30:00 PM	0
9/30/2014	2:45:00 PM	0
9/30/2014	3:00:00 PM	0
9/30/2014	3:15:00 PM	0
9/30/2014	3:30:00 PM	0
9/30/2014	3:45:00 PM	0
9/30/2014	4:00:00 PM	0
9/30/2014	4:15:00 PM	0
9/30/2014	4:30:00 PM	0
9/30/2014	4:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
9/30/2014	5:00:00 PM	0
9/30/2014	5:15:00 PM	0
9/30/2014	5:30:00 PM	0
9/30/2014	5:45:00 PM	0
9/30/2014	6:00:00 PM	0
9/30/2014	6:15:00 PM	0
9/30/2014	6:30:00 PM	0
9/30/2014	6:45:00 PM	0
9/30/2014	7:00:00 PM	0
9/30/2014	7:15:00 PM	0
9/30/2014	7:30:00 PM	0
9/30/2014	7:45:00 PM	0
9/30/2014	8:00:00 PM	0
9/30/2014	8:15:00 PM	0
9/30/2014	8:30:00 PM	0
9/30/2014	8:45:00 PM	0
9/30/2014	9:00:00 PM	0
9/30/2014	9:15:00 PM	0
9/30/2014	9:30:00 PM	0
9/30/2014	9:45:00 PM	0
9/30/2014	10:00:00 PM	0
9/30/2014	10:15:00 PM	0
9/30/2014	10:30:00 PM	0
9/30/2014	10:45:00 PM	0
9/30/2014	11:00:00 PM	0.01
9/30/2014	11:15:00 PM	0.01
9/30/2014	11:30:00 PM	0.01
9/30/2014	11:45:00 PM	0.01
10/1/2014	12:00:00 AM	0.01

Station Number: 0356 Meas. No: 005

Station Name: LOR @ REINHACKLE Date: 09/17/2014

Party: BJA/KSL	Width: 19.6 ft	Processed by: BJA/KSL
Boat/Motor:	Area: 73.4 ft²	Mean Velocity: 0.667 ft/s
Gage Height: 4.08 ft	G.H.Change: 0.000 ft	Discharge: 48.9 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 1.43 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 4.23 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 3.73 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 67.35	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 65.0 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 140917 LOR@ Reinhackle000r

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	33	6.75	33.8	5.37	2.30	1.84	50.1	19	71	08:03	08:04	0.49	0.71	6	0
001	*R*	*2*	*2*	*33*	*6.00*	*30.3*	*4.98*	*2.15*	*2.05*	*45.5*	*19*	*70*	*08:04*	*08:05*	*0.51*	*0.65*	*6*	*0*
002	L	*2*	*2*	*34*	*6.36*	*32.0*	*5.16*	*2.33*	*1.80*	*47.6*	*20*	*75*	*08:05*	*08:06*	*0.52*	*0.63*	*6*	*0*
003	R	*2*	*2*	*34*	*6.57*	*33.1*	*5.76*	*2.01*	*1.59*	*49.0*	*19*	*73*	*08:07*	*08:07*	*0.52*	*0.67*	*6*	*0*
004	*L*	*2*	*2*	*33*	*7.06*	*35.5*	*5.72*	*2.01*	*1.80*	*52.0*	*20*	*76*	*08:08*	*08:08*	*0.51*	*0.69*	*6*	*0*
005	R	*2*	*2*	*31*	*6.57*	*33.1*	*5.86*	*2.01*	*1.84*	*49.4*	*20*	*75*	*08:09*	*08:10*	*0.56*	*0.66*	*6*	*0*
Mean		2	2	33	6.55	33.0	5.47	2.14	1.82	48.9	20	73	**Total**	00:06	0.52	0.67	6	0
SDev		0	0	1	0.357	1.74	0.360	0.148	0.146	2.21	0.6	2.5			0.02	0.03		
SD/M		0.00	0.00	0.03	0.05	0.05	0.07	0.07	0.08	0.05	0.03	0.03			0.05	0.04		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	0	0	41	0.817	-0.095	3.819	0.013	0.01	0	44.3	40.9	77.4	138	127	0	35	32
2014	9	1	0	10	41	0.768	-0.079	3.819	0.01	0.007	0	44.3	40.4	77.4	139	127	0	36	33
2014	9	1	0	20	41	0.781	-0.066	3.819	0.01	0.007	0	44.3	40	77	138	126	0	35	33
2014	9	1	0	30	41	0.774	-0.075	3.819	0.01	0.007	0	44.3	40.4	77	138	126	0	35	32
2014	9	1	0	40	41	0.817	-0.075	3.819	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	1	0	50	41	0.764	-0.056	3.819	0.01	0.007	0	44.3	40.4	77.4	138	127	0	35	33
2014	9	1	1	0	41	0.778	-0.069	3.819	0.016	0.013	0	44.3	40	77.8	138	126	0	35	33
2014	9	1	1	10	41	0.791	-0.085	3.819	0.013	0.01	0	44.3	40.4	77	138	127	0	35	33
2014	9	1	1	20	41	0.791	-0.059	3.819	0.01	0.007	0	44.7	40.4	76.5	138	126	0	34	32
2014	9	1	1	30	41	0.823	-0.089	3.819	0.013	0.01	0	43.9	40	77.4	137	125	0	35	32
2014	9	1	1	40	41	0.771	-0.082	3.819	0.01	0.007	0	43.9	39.6	77.8	137	125	0	35	33
2014	9	1	1	50	41	0.778	-0.059	3.819	0.016	0.013	0	44.3	40	77.4	138	126	0	35	33
2014	9	1	2	0	41	0.781	-0.066	3.819	0.013	0.01	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	1	2	10	41	0.768	-0.085	3.819	0.01	0.007	0	44.3	40	77.4	138	126	0	35	33
2014	9	1	2	20	41	0.804	-0.079	3.816	0.013	0.01	0	43.9	40	77.8	137	126	0	35	33
2014	9	1	2	30	41	0.781	-0.079	3.816	0.01	0.007	0	43.9	40	77.4	137	126	0	35	33
2014	9	1	2	40	41	0.804	-0.079	3.819	0.013	0.01	0	44.3	40	76.5	138	126	0	35	33
2014	9	1	2	50	41	0.778	-0.102	3.819	0.016	0.013	0	44.3	40	78.3	137	125	0	34	32
2014	9	1	3	0	41	0.807	-0.069	3.816	0.013	0.01	0	43.9	40	77.8	137	125	0	35	32
2014	9	1	3	10	41	0.784	-0.062	3.819	0.01	0.007	0	43.9	40	77.4	137	125	0	35	32
2014	9	1	3	20	41	0.794	-0.075	3.819	0.01	0.007	0	43.9	40	77.8	137	125	0	35	32
2014	9	1	3	30	41	0.869	-0.079	3.816	0.013	0.01	0	43.9	40	77.8	137	125	0	35	32
2014	9	1	3	40	41	0.817	-0.079	3.819	0.01	0.007	0	43.9	40	78.3	137	125	0	35	32
2014	9	1	3	50	41	0.791	-0.072	3.816	0.013	0.01	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	1	4	0	41	0.787	-0.075	3.816	0.016	0.016	0	43.9	39.6	77.8	137	125	0	35	33
2014	9	1	4	10	41	0.787	-0.102	3.816	0.013	0.01	0	43.9	40	77.8	137	126	0	35	33
2014	9	1	4	20	41	0.774	-0.059	3.816	0.013	0.01	0	44.3	40	77.4	137	125	0	34	32
2014	9	1	4	30	41	0.801	-0.052	3.816	0.016	0.013	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	1	4	40	41	0.774	-0.069	3.816	0.013	0.01	0	44.3	40	77	138	126	0	35	33
2014	9	1	4	50	41	0.755	-0.085	3.816	0.013	0.01	0	43.9	40.4	77.8	137	126	0	35	32
2014	9	1	5	0	41	0.791	-0.075	3.816	0.013	0.01	0	43.4	39.6	77.4	137	125	0	36	33
2014	9	1	5	10	41	0.801	-0.075	3.816	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	1	5	20	41	0.827	-0.128	3.816	0.01	0.007	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	1	5	30	41	0.814	-0.115	3.816	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	1	5	40	41	0.774	-0.089	3.816	0.016	0.016	0	44.3	40	78.3	138	126	0	35	33
2014	9	1	5	50	41	0.794	-0.092	3.816	0.016	0.013	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	1	6	0	41	0.804	-0.079	3.816	0.013	0.01	0	44.7	40	77	139	126	0	35	33
2014	9	1	6	10	41	0.837	-0.102	3.816	0.01	0.007	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	1	6	20	41	0.807	-0.092	3.816	0.01	0.007	0	44.3	39.6	77.8	138	125	0	35	33
2014	9	1	6	30	41	0.791	-0.089	3.816	0.01	0.007	0	44.3	39.6	76.5	138	125	0	35	33
2014	9	1	6	40	41	0.778	-0.092	3.816	0.013	0.01	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	1	6	50	41	0.817	-0.075	3.816	0.01	0.007	0	43.9	39.6	77.8	137	124	0	35	32
2014	9	1	7	0	41	0.797	-0.098	3.816	0.01	0.007	0	44.3	39.1	77.8	137	124	0	34	33
2014	9	1	7	10	41	0.823	-0.098	3.812	0.013	0.01	0	43	39.1	77.8	136	123	0	36	32
2014	9	1	7	20	41	0.784	-0.115	3.812	0.01	0.007	0	43.4	38.7	78.3	136	123	0	35	33
2014	9	1	7	30	41	0.771	-0.079	3.816	0.01	0.007	0	43	38.7	77.4	136	123	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	7	40	41	0.807	-0.082	3.812	0.013	0.01	0	43.4	39.1	78.3	136	124	0	35	33
2014	9	1	7	50	41	0.791	-0.072	3.812	0.01	0.007	0	43	39.1	79.1	136	124	0	36	33
2014	9	1	8	0	41	0.764	-0.072	3.812	0.01	0.007	0	43.4	38.7	78.7	136	123	0	35	33
2014	9	1	8	10	41	0.794	-0.092	3.812	0.01	0.007	0	43.4	38.7	78.3	136	123	0	35	33
2014	9	1	8	20	41	0.82	-0.085	3.812	0.01	0.007	0	43	38.7	78.3	135	123	0	35	33
2014	9	1	8	30	41	0.768	-0.092	3.816	0.01	0.007	0	43	38.7	78.7	135	123	0	35	33
2014	9	1	8	40	41	0.801	-0.082	3.816	0.013	0.01	0	43	38.3	78.3	135	122	0	35	33
2014	9	1	8	50	41	0.784	-0.072	3.812	0.016	0.016	0	43	38.3	78.3	135	122	0	35	33
2014	9	1	9	0	41	0.807	-0.092	3.812	0.01	0.007	0	43	38.7	76.5	135	123	0	35	33
2014	9	1	9	10	41	0.81	-0.069	3.812	0.013	0.01	0	42.6	38.7	77	135	123	0	36	33
2014	9	1	9	20	41	0.801	-0.085	3.812	0.013	0.01	0	43	38.7	77.4	135	123	0	35	33
2014	9	1	9	30	41	0.817	-0.082	3.812	0.01	0.007	0	43	38.3	78.3	135	122	0	35	33
2014	9	1	9	40	41	0.807	-0.089	3.812	0.01	0.007	0	42.1	38.3	77	134	122	0	36	33
2014	9	1	9	50	41	0.81	-0.125	3.812	0.01	0.007	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	1	10	0	41	0.791	-0.092	3.812	0.013	0.01	0	42.1	38.7	77	134	122	0	36	32
2014	9	1	10	10	41	0.794	-0.092	3.812	0.013	0.01	0	42.1	38.3	76.1	134	122	0	36	33
2014	9	1	10	20	41	0.801	-0.095	3.812	0.01	0.007	0	43	38.7	77	135	123	0	35	33
2014	9	1	10	30	41	0.784	-0.095	3.812	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	9	1	10	40	41	0.787	-0.089	3.812	0.013	0.01	0	42.6	38.7	76.5	135	123	0	36	33
2014	9	1	10	50	41	0.787	-0.066	3.812	0.01	0.007	0	43.4	39.1	76.1	136	123	0	35	32
2014	9	1	11	0	41	0.784	-0.085	3.812	0.016	0.013	0	43	38.7	76.1	135	123	0	35	33
2014	9	1	11	10	41	0.823	-0.089	3.812	0.016	0.013	0	43	38.7	76.5	135	123	0	35	33
2014	9	1	11	20	41	0.801	-0.085	3.809	0.013	0.01	0	42.6	38.3	75.3	134	122	0	35	33
2014	9	1	11	30	41	0.781	-0.095	3.809	0.013	0.01	0	42.6	38.3	74.8	134	122	0	35	33
2014	9	1	11	40	41	0.807	-0.072	3.809	0.01	0.007	0	42.1	38.3	75.3	134	122	0	36	33
2014	9	1	11	50	41	0.784	-0.112	3.806	0.013	0.01	0	42.6	38.3	74.4	134	122	0	35	33
2014	9	1	12	0	41	0.807	-0.092	3.806	0.013	0.01	0	43	39.1	74.4	135	123	0	35	32
2014	9	1	12	10	41	0.791	-0.115	3.799	0.016	0.013	0	43.4	38.7	74.8	136	123	0	35	33
2014	9	1	12	20	41	0.794	-0.046	3.799	0.013	0.01	0	43.4	38.7	75.3	136	123	0	35	33
2014	9	1	12	30	41	0.787	-0.072	3.799	0.016	0.013	0	43.4	39.1	75.3	136	123	0	35	32
2014	9	1	12	40	41	0.823	-0.085	3.799	0.016	0.013	0	43.4	39.1	74.4	136	123	0	35	32
2014	9	1	12	50	41	0.758	-0.075	3.796	0.013	0.01	0	43.4	38.7	74.4	136	123	0	35	33
2014	9	1	13	0	41	0.761	-0.098	3.796	0.01	0.007	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	1	13	10	41	0.794	-0.095	3.796	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	9	1	13	20	41	0.781	-0.095	3.799	0.013	0.01	0	43	39.1	77	135	123	0	35	32
2014	9	1	13	30	41	0.787	-0.079	3.796	0.013	0.01	0	43	39.1	76.1	135	123	0	35	32
2014	9	1	13	40	41	0.761	-0.082	3.796	0.01	0.007	0	43	38.7	71.8	135	123	0	35	33
2014	9	1	13	50	41	0.778	-0.108	3.793	0.01	0.007	0	42.6	38.3	67.5	134	122	0	35	33
2014	9	1	14	0	41	0.761	-0.102	3.793	0.013	0.01	0	43	38.3	58	134	122	0	34	33
2014	9	1	14	10	41	0.827	-0.079	3.793	0.01	0.007	0	43	39.1	58.9	135	123	0	35	32
2014	9	1	14	20	41	0.781	-0.098	3.793	0.01	0.007	0	43	39.1	56.8	135	124	0	35	33
2014	9	1	14	30	41	0.751	-0.075	3.793	0.01	0.007	0	43.4	38.7	58.5	135	123	0	34	33
2014	9	1	14	40	41	0.787	-0.092	3.793	0.01	0.007	0	43	39.1	60.2	135	123	0	35	32
2014	9	1	14	50	41	0.764	-0.092	3.793	0.013	0.01	0	43.9	39.1	68.4	137	124	0	35	33
2014	9	1	15	0	41	0.801	-0.095	3.789	0.01	0.007	0	43	39.1	60.2	135	123	0	35	32
2014	9	1	15	10	41	0.791	-0.062	3.789	0.01	0.007	0	43	39.1	63.6	135	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	15	20	41	0.748	-0.082	3.789	0.016	0.013	0	43.4	39.1	60.2	136	123	0	35	32
2014	9	1	15	30	41	0.768	-0.108	3.789	0.016	0.013	0	43	39.1	67.9	135	123	0	35	32
2014	9	1	15	40	41	0.738	-0.062	3.789	0.01	0.007	0	43	38.7	61.9	135	123	0	35	33
2014	9	1	15	50	41	0.761	-0.062	3.789	0.01	0.007	0	43	38.7	64.9	135	123	0	35	33
2014	9	1	16	0	41	0.791	-0.108	3.789	0.016	0.013	0	43.4	39.1	55.9	136	124	0	35	33
2014	9	1	16	10	41	0.764	-0.075	3.786	0.013	0.01	0	43.4	39.1	56.3	136	124	0	35	33
2014	9	1	16	20	41	0.81	-0.125	3.786	0.01	0.007	0	43.9	40	60.6	137	126	0	35	33
2014	9	1	16	30	41	0.784	-0.069	3.786	0.013	0.01	0	43.4	40	58.9	136	125	0	35	32
2014	9	1	16	40	41	0.748	-0.059	3.786	0.01	0.007	0	43.9	40	58.5	137	125	0	35	32
2014	9	1	16	50	41	0.771	-0.072	3.783	0.013	0.01	0	43.4	39.1	54.2	136	124	0	35	33
2014	9	1	17	0	41	0.771	-0.079	3.783	0.01	0.007	0	43.9	40	56.3	136	125	0	34	32
2014	9	1	17	10	41	0.781	-0.112	3.786	0.013	0.01	0	44.7	40.9	57.2	139	127	0	35	32
2014	9	1	17	20	41	0.787	-0.056	3.78	0.013	0.01	0	46.4	42.1	53.8	143	131	0	35	33
2014	9	1	17	30	41	0.787	-0.098	3.776	0.013	0.01	0	51.2	46.9	43.4	154	142	0	35	33
2014	9	1	17	40	41	0.83	-0.079	3.776	0.016	0.013	0	46.4	41.3	46.9	142	129	0	34	33
2014	9	1	17	50	41	0.814	-0.098	3.776	0.01	0.007	0	48.2	44.3	45.2	147	136	0	35	33
2014	9	1	18	0	41	0.745	-0.079	3.783	0.016	0.013	0	45.6	41.7	56.3	141	129	0	35	32
2014	9	1	18	10	41	0.761	-0.089	3.783	0.013	0.01	0	42.6	39.1	67.1	134	123	0	35	32
2014	9	1	18	20	41	0.807	-0.092	3.783	0.016	0.013	0	42.6	38.3	70.5	134	122	0	35	33
2014	9	1	18	30	41	0.764	-0.085	3.786	0.016	0.013	0	42.6	38.7	78.3	134	122	0	35	32
2014	9	1	18	40	41	0.745	-0.082	3.786	0.01	0.007	0	42.6	38.7	78.7	134	122	0	35	32
2014	9	1	18	50	41	0.784	-0.069	3.783	0.01	0.007	0	43.4	39.6	77.8	136	124	0	35	32
2014	9	1	19	0	41	0.784	-0.108	3.783	0.01	0.007	0	43	38.7	76.1	135	123	0	35	33
2014	9	1	19	10	41	0.787	-0.121	3.783	0.01	0.007	0	43.4	39.1	78.7	136	124	0	35	33
2014	9	1	19	20	41	0.778	-0.072	3.783	0.01	0.007	0	43.4	39.1	77.8	136	124	0	35	33
2014	9	1	19	30	41	0.778	-0.105	3.783	0.01	0.007	0	43.4	39.6	77.4	136	124	0	35	32
2014	9	1	19	40	41	0.787	-0.098	3.783	0.013	0.01	0	43.9	40	73.1	137	125	0	35	32
2014	9	1	19	50	41	0.758	-0.108	3.783	0.013	0.01	0	44.3	40	74.8	137	125	0	34	32
2014	9	1	20	0	41	0.794	-0.105	3.783	0.01	0.007	0	44.3	39.6	74	138	125	0	35	33
2014	9	1	20	10	41	0.82	-0.098	3.783	0.013	0.01	0	44.3	40	74.4	138	126	0	35	33
2014	9	1	20	20	41	0.794	-0.112	3.783	0.016	0.013	0	44.3	40.4	78.3	138	126	0	35	32
2014	9	1	20	30	41	0.768	-0.125	3.783	0.01	0.007	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	1	20	40	41	0.748	-0.092	3.783	0.01	0.007	0	44.7	40.4	77.4	138	126	0	34	32
2014	9	1	20	50	41	0.781	-0.125	3.783	0.013	0.01	0	44.3	40.9	79.1	138	127	0	35	32
2014	9	1	21	0	41	0.843	-0.098	3.783	0.01	0.007	0	44.3	40	79.6	138	126	0	35	33
2014	9	1	21	10	41	0.778	-0.033	3.783	0.013	0.01	0	44.3	40.4	79.1	138	126	0	35	32
2014	9	1	21	20	41	0.778	-0.056	3.783	0.013	0.01	0	44.7	40.4	78.3	138	126	0	34	32
2014	9	1	21	30	41	0.774	-0.085	3.783	0.016	0.013	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	1	21	40	41	0.797	-0.079	3.783	0.01	0.007	0	44.3	40.4	77	138	127	0	35	33
2014	9	1	21	50	41	0.823	-0.079	3.783	0.013	0.01	0	44.3	40.4	78.3	138	126	0	35	32
2014	9	1	22	0	41	0.794	-0.079	3.783	0.016	0.013	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	1	22	10	41	0.745	-0.066	3.783	0.013	0.01	0	44.3	40.4	78.3	138	126	0	35	32
2014	9	1	22	20	41	0.758	-0.069	3.783	0.013	0.01	0	44.3	40.4	77.8	138	127	0	35	33
2014	9	1	22	30	41	0.791	-0.095	3.783	0.013	0.01	0	43.9	40	77	137	126	0	35	33
2014	9	1	22	40	41	0.807	-0.092	3.783	0.013	0.01	0	44.3	40	78.3	138	126	0	35	33
2014	9	1	22	50	41	0.794	-0.075	3.783	0.013	0.01	0	44.7	40.4	77.4	139	126	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	1	23	0	41	0.755	-0.072	3.783	0.01	0.007	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	1	23	10	41	0.784	-0.079	3.783	0.01	0.007	0	44.7	40	77.8	139	126	0	35	33
2014	9	1	23	20	41	0.761	-0.056	3.783	0.013	0.01	0	44.7	40	78.7	138	126	0	34	33
2014	9	1	23	30	41	0.794	-0.079	3.783	0.013	0.01	0	44.3	40.4	78.3	138	126	0	35	32
2014	9	1	23	40	41	0.787	-0.079	3.783	0.013	0.01	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	1	23	50	41	0.768	-0.079	3.783	0.016	0.016	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	2	0	0	41	0.797	-0.079	3.783	0.013	0.01	0	43.9	40.4	78.3	138	126	0	36	32
2014	9	2	0	10	41	0.764	-0.098	3.783	0.013	0.01	0	44.7	40	78.7	138	126	0	34	33
2014	9	2	0	20	41	0.814	-0.056	3.783	0.013	0.01	0	44.3	40	79.1	138	126	0	35	33
2014	9	2	0	30	41	0.784	-0.046	3.783	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	2	0	40	41	0.781	-0.046	3.783	0.016	0.013	0	44.3	40	79.1	138	125	0	35	32
2014	9	2	0	50	41	0.781	-0.108	3.783	0.016	0.013	0	44.3	40	79.1	138	126	0	35	33
2014	9	2	1	0	41	0.784	-0.079	3.783	0.013	0.01	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	2	1	10	41	0.817	-0.075	3.783	0.016	0.013	0	44.3	39.6	79.1	137	125	0	34	33
2014	9	2	1	20	41	0.82	-0.089	3.783	0.013	0.01	0	43.9	39.6	78.7	137	125	0	35	33
2014	9	2	1	30	41	0.771	-0.033	3.783	0.01	0.007	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	2	1	40	41	0.774	-0.112	3.783	0.013	0.01	0	43.9	39.6	80	137	125	0	35	33
2014	9	2	1	50	41	0.866	-0.089	3.783	0.01	0.007	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	2	2	0	41	0.778	-0.059	3.783	0.013	0.01	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	2	2	10	41	0.791	-0.079	3.783	0.016	0.013	0	43.9	40	79.1	136	125	0	34	32
2014	9	2	2	20	41	0.764	-0.082	3.783	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33
2014	9	2	2	30	41	0.771	-0.095	3.783	0.01	0.007	0	44.3	40	80.4	138	126	0	35	33
2014	9	2	2	40	41	0.787	-0.092	3.783	0.013	0.01	0	43.9	39.6	79.1	137	125	0	35	33
2014	9	2	2	50	41	0.797	-0.056	3.783	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	2	3	0	41	0.797	-0.089	3.783	0.01	0.007	0	43.4	39.6	80	136	125	0	35	33
2014	9	2	3	10	41	0.814	-0.082	3.783	0.013	0.01	0	43	40	80	136	125	0	36	32
2014	9	2	3	20	41	0.791	-0.062	3.783	0.01	0.007	0	43.9	40.4	80	137	126	0	35	32
2014	9	2	3	30	41	0.781	-0.098	3.783	0.01	0.007	0	44.3	40.4	80	138	126	0	35	32
2014	9	2	3	40	41	0.787	-0.056	3.783	0.01	0.007	0	44.3	40	79.1	138	126	0	35	33
2014	9	2	3	50	41	0.787	-0.095	3.783	0.013	0.01	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	2	4	0	41	0.804	-0.075	3.783	0.016	0.013	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	2	4	10	41	0.771	-0.075	3.783	0.013	0.01	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	2	4	20	41	0.814	-0.082	3.783	0.01	0.007	0	43.9	40	79.6	138	125	0	36	32
2014	9	2	4	30	41	0.774	-0.072	3.783	0.01	0.007	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	2	4	40	41	0.794	-0.062	3.783	0.013	0.01	0	44.3	40	79.6	138	125	0	35	32
2014	9	2	4	50	41	0.804	-0.069	3.783	0.013	0.01	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	2	5	0	41	0.771	-0.085	3.783	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33
2014	9	2	5	10	41	0.787	-0.075	3.783	0.01	0.007	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	2	5	20	41	0.801	-0.085	3.783	0.01	0.007	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	2	5	30	41	0.81	-0.092	3.783	0.01	0.007	0	44.3	40	79.6	138	126	0	35	33
2014	9	2	5	40	41	0.771	-0.056	3.783	0.01	0.007	0	44.7	40	78.7	139	126	0	35	33
2014	9	2	5	50	41	0.814	-0.082	3.783	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	2	6	0	41	0.801	-0.095	3.783	0.013	0.01	0	43.9	39.6	79.1	138	125	0	36	33
2014	9	2	6	10	41	0.801	-0.105	3.78	0.01	0.007	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	2	6	20	41	0.833	-0.098	3.783	0.013	0.01	0	44.3	39.6	79.1	138	125	0	35	33
2014	9	2	6	30	41	0.791	-0.108	3.78	0.013	0.01	0	44.3	40	79.1	138	125	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	6	40	41	0.771	-0.075	3.78	0.016	0.013	0	43.9	39.1	79.1	137	124	0	35	33
2014	9	2	6	50	41	0.784	-0.075	3.783	0.01	0.007	0	43.4	38.3	79.1	136	123	0	35	34
2014	9	2	7	0	41	0.801	-0.108	3.78	0.01	0.007	0	43	38.7	80	135	122	0	35	32
2014	9	2	7	10	41	0.801	-0.062	3.783	0.013	0.01	0	43.4	38.3	80	135	122	0	34	33
2014	9	2	7	20	41	0.801	-0.092	3.783	0.01	0.007	0	42.6	38.3	79.6	134	122	0	35	33
2014	9	2	7	30	41	0.751	-0.092	3.78	0.01	0.007	0	42.6	38.3	79.1	134	121	0	35	32
2014	9	2	7	40	41	0.755	-0.079	3.783	0.013	0.01	0	42.1	38.3	79.6	134	121	0	36	32
2014	9	2	7	50	41	0.748	-0.062	3.783	0.013	0.01	0	42.6	37.8	80	134	121	0	35	33
2014	9	2	8	0	41	0.748	-0.089	3.783	0.016	0.013	0	42.6	37.8	80.4	134	122	0	35	34
2014	9	2	8	10	41	0.797	-0.075	3.783	0.013	0.01	0	43	38.3	80	135	122	0	35	33
2014	9	2	8	20	41	0.817	-0.075	3.783	0.013	0.01	0	43	38.3	80.4	135	122	0	35	33
2014	9	2	8	30	41	0.787	-0.102	3.783	0.013	0.01	0	42.6	37.8	80.4	134	121	0	35	33
2014	9	2	8	40	41	0.755	-0.066	3.783	0.01	0.007	0	42.1	38.3	80	134	122	0	36	33
2014	9	2	8	50	41	0.768	-0.095	3.783	0.01	0.007	0	42.6	38.3	80	135	122	0	36	33
2014	9	2	9	0	41	0.801	-0.056	3.783	0.013	0.01	0	42.6	38.7	80.8	134	122	0	35	32
2014	9	2	9	10	41	0.784	-0.098	3.783	0.01	0.007	0	42.1	38.3	80	134	122	0	36	33
2014	9	2	9	20	41	0.791	-0.082	3.783	0.01	0.007	0	42.6	37.8	79.6	134	121	0	35	33
2014	9	2	9	30	41	0.764	-0.079	3.783	0.013	0.01	0	42.6	38.3	80	134	122	0	35	33
2014	9	2	9	40	41	0.823	-0.082	3.783	0.013	0.01	0	43	38.3	78.7	135	122	0	35	33
2014	9	2	9	50	41	0.745	-0.066	3.783	0.013	0.01	0	42.6	38.3	80.8	134	122	0	35	33
2014	9	2	10	0	41	0.751	-0.079	3.783	0.01	0.007	0	42.6	38.3	79.6	134	121	0	35	32
2014	9	2	10	10	41	0.797	-0.105	3.783	0.01	0.007	0	42.6	38.3	79.6	134	122	0	35	33
2014	9	2	10	20	41	0.794	-0.095	3.783	0.01	0.007	0	42.1	38.7	80.4	134	123	0	36	33
2014	9	2	10	30	41	0.784	-0.121	3.783	0.016	0.013	0	42.6	38.3	80	134	122	0	35	33
2014	9	2	10	40	41	0.804	-0.098	3.783	0.013	0.01	0	43	38.7	77	135	123	0	35	33
2014	9	2	10	50	41	0.741	-0.069	3.783	0.01	0.007	0	42.1	38.3	79.1	134	122	0	36	33
2014	9	2	11	0	41	0.781	-0.075	3.78	0.01	0.007	0	43	38.3	76.1	135	122	0	35	33
2014	9	2	11	10	41	0.725	-0.092	3.78	0.013	0.01	0	43	38.3	70.1	135	122	0	35	33
2014	9	2	11	20	41	0.745	-0.069	3.78	0.01	0.007	0	42.6	38.7	78.3	134	122	0	35	32
2014	9	2	11	30	41	0.758	-0.095	3.78	0.01	0.007	0	42.6	38.3	62.4	134	122	0	35	33
2014	9	2	11	40	41	0.748	-0.095	3.78	0.016	0.016	0	42.6	38.7	64.1	134	123	0	35	33
2014	9	2	11	50	41	0.741	-0.079	3.78	0.013	0.01	0	42.6	38.3	68.4	134	122	0	35	33
2014	9	2	12	0	41	0.784	-0.095	3.776	0.013	0.01	0	42.6	39.1	55.9	134	123	0	35	32
2014	9	2	12	10	41	0.745	-0.049	3.776	0.01	0.007	0	43	38.7	56.8	135	123	0	35	33
2014	9	2	12	20	41	0.748	-0.108	3.776	0.013	0.01	0	43	38.7	59.8	135	123	0	35	33
2014	9	2	12	30	41	0.758	-0.112	3.773	0.013	0.01	0	43	38.7	54.6	135	123	0	35	33
2014	9	2	12	40	41	0.784	-0.128	3.773	0.01	0.007	0	43.4	39.6	60.6	136	124	0	35	32
2014	9	2	12	50	41	0.781	-0.089	3.773	0.01	0.007	0	43.9	40	55.9	137	125	0	35	32
2014	9	2	13	0	41	0.745	-0.056	3.773	0.013	0.01	0	43.4	39.6	54.6	136	125	0	35	33
2014	9	2	13	10	41	0.794	-0.052	3.77	0.01	0.007	0	43	40	52	136	125	0	36	32
2014	9	2	13	20	41	0.791	-0.112	3.77	0.013	0.01	0	43.4	39.6	52.5	136	125	0	35	33
2014	9	2	13	30	41	0.764	-0.089	3.766	0.01	0.007	0	43.9	40	58	137	126	0	35	33
2014	9	2	13	40	41	0.751	-0.079	3.766	0.013	0.01	0	43	39.1	57.6	135	124	0	35	33
2014	9	2	13	50	41	0.764	-0.095	3.766	0.01	0.007	0	43.4	39.6	53.8	136	124	0	35	32
2014	9	2	14	0	41	0.774	-0.079	3.763	0.013	0.01	0	43	39.1	53.8	135	124	0	35	33
2014	9	2	14	10	41	0.764	-0.085	3.76	0.013	0.01	0	43.4	39.6	57.2	136	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	14	20	41	0.758	-0.075	3.76	0.013	0.01	0	43.4	39.6	52.5	136	125	0	35	33
2014	9	2	14	30	41	0.758	-0.102	3.76	0.013	0.01	0	43	39.1	52	135	124	0	35	33
2014	9	2	14	40	41	0.764	-0.121	3.76	0.016	0.013	0	43.4	39.1	53.8	135	124	0	34	33
2014	9	2	14	50	41	0.764	-0.098	3.76	0.016	0.013	0	43	39.6	53.3	135	124	0	35	32
2014	9	2	15	0	41	0.755	-0.105	3.757	0.01	0.007	0	43.4	39.6	55.5	136	124	0	35	32
2014	9	2	15	10	41	0.768	-0.112	3.757	0.01	0.007	0	43.4	40	53.8	136	125	0	35	32
2014	9	2	15	20	41	0.764	-0.128	3.757	0.016	0.013	0	43.4	39.6	54.6	136	125	0	35	33
2014	9	2	15	30	41	0.751	-0.125	3.757	0.016	0.013	0	43.9	39.6	52	137	125	0	35	33
2014	9	2	15	40	41	0.764	-0.085	3.753	0.01	0.007	0	43.9	40	54.6	137	126	0	35	33
2014	9	2	15	50	41	0.715	-0.108	3.753	0.016	0.013	0	43.4	39.6	55.9	136	125	0	35	33
2014	9	2	16	0	41	0.764	-0.095	3.753	0.013	0.01	0	43.9	40	55.9	137	125	0	35	32
2014	9	2	16	10	41	0.748	-0.085	3.753	0.013	0.01	0	43.4	39.6	53.8	136	125	0	35	33
2014	9	2	16	20	41	0.791	-0.095	3.753	0.013	0.01	0	43.4	39.1	57.2	136	124	0	35	33
2014	9	2	16	30	41	0.771	-0.105	3.753	0.01	0.007	0	43	39.1	55.9	135	124	0	35	33
2014	9	2	16	40	41	0.797	-0.102	3.753	0.013	0.01	0	43	39.6	54.6	135	124	0	35	32
2014	9	2	16	50	41	0.735	-0.069	3.753	0.01	0.007	0	43	39.1	59.8	135	124	0	35	33
2014	9	2	17	0	41	0.771	-0.112	3.753	0.01	0.007	0	43	38.7	55.5	135	123	0	35	33
2014	9	2	17	10	41	0.745	-0.115	3.753	0.016	0.016	0	42.6	39.6	58	135	124	0	36	32
2014	9	2	17	20	41	0.719	-0.085	3.753	0.016	0.016	0	43	39.1	59.3	135	123	0	35	32
2014	9	2	17	30	41	0.781	-0.079	3.75	0.01	0.007	0	43	39.6	56.3	135	124	0	35	32
2014	9	2	17	40	41	0.764	-0.079	3.75	0.01	0.007	0	43	38.7	58.5	135	123	0	35	33
2014	9	2	17	50	41	0.781	-0.075	3.75	0.013	0.01	0	43.4	38.7	61.5	135	123	0	34	33
2014	9	2	18	0	41	0.768	-0.079	3.75	0.01	0.007	0	43.4	39.1	62.4	136	124	0	35	33
2014	9	2	18	10	41	0.764	-0.085	3.75	0.01	0.007	0	43	39.1	57.6	135	124	0	35	33
2014	9	2	18	20	41	0.741	-0.102	3.75	0.01	0.007	0	43	39.6	60.6	135	124	0	35	32
2014	9	2	18	30	41	0.814	-0.069	3.75	0.01	0.007	0	43	39.6	65.4	135	124	0	35	32
2014	9	2	18	40	41	0.784	-0.075	3.75	0.01	0.007	0	43	39.6	55	135	124	0	35	32
2014	9	2	18	50	41	0.725	-0.069	3.753	0.01	0.007	0	43.4	39.1	78.7	136	124	0	35	33
2014	9	2	19	0	41	0.781	-0.079	3.75	0.016	0.013	0	43.4	39.6	62.8	136	124	0	35	32
2014	9	2	19	10	41	0.748	-0.098	3.753	0.01	0.007	0	43.4	40	76.5	136	125	0	35	32
2014	9	2	19	20	41	0.751	-0.052	3.753	0.01	0.007	0	43.9	40	80	137	125	0	35	32
2014	9	2	19	30	41	0.732	-0.079	3.75	0.013	0.01	0	44.3	40	79.6	138	126	0	35	33
2014	9	2	19	40	41	0.784	-0.092	3.75	0.013	0.01	0	44.3	40	71.8	138	126	0	35	33
2014	9	2	19	50	41	0.755	-0.098	3.753	0.01	0.007	0	44.3	40.4	79.6	138	127	0	35	33
2014	9	2	20	0	41	0.758	-0.079	3.753	0.013	0.01	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	2	20	10	41	0.764	-0.112	3.753	0.013	0.01	0	44.7	40.9	79.1	139	128	0	35	33
2014	9	2	20	20	41	0.768	-0.062	3.753	0.013	0.01	0	44.7	40.4	80	139	127	0	35	33
2014	9	2	20	30	41	0.797	-0.112	3.753	0.01	0.007	0	45.2	40.9	80	139	127	0	34	32
2014	9	2	20	40	41	0.774	-0.049	3.753	0.013	0.01	0	45.2	40.4	78.7	140	127	0	35	33
2014	9	2	20	50	41	0.751	-0.108	3.75	0.013	0.01	0	45.6	40.9	73.1	140	127	0	34	32
2014	9	2	21	0	41	0.735	-0.082	3.753	0.013	0.01	0	45.2	40.4	76.1	140	127	0	35	33
2014	9	2	21	10	41	0.719	-0.079	3.753	0.013	0.01	0	45.6	40.9	78.7	140	127	0	34	32
2014	9	2	21	20	41	0.827	-0.059	3.75	0.01	0.007	0	45.2	40.4	70.5	139	126	0	34	32
2014	9	2	21	30	41	0.771	-0.105	3.753	0.01	0.007	0	45.2	40.4	79.1	140	127	0	35	33
2014	9	2	21	40	41	0.741	-0.092	3.753	0.013	0.01	0	45.2	40.9	77.8	140	127	0	35	32
2014	9	2	21	50	41	0.751	-0.069	3.753	0.016	0.013	0	45.2	40.4	78.7	139	127	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	2	22	0	41	0.784	-0.085	3.753	0.01	0.007	0	45.2	40.4	79.1	140	127	0	35	33
2014	9	2	22	10	41	0.784	-0.085	3.75	0.01	0.007	0	44.3	40.4	79.6	139	127	0	36	33
2014	9	2	22	20	41	0.781	-0.095	3.753	0.016	0.013	0	45.2	40.4	80	139	126	0	34	32
2014	9	2	22	30	41	0.751	-0.066	3.75	0.01	0.007	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	2	22	40	41	0.781	-0.072	3.753	0.013	0.01	0	45.2	40.9	78.7	140	128	0	35	33
2014	9	2	22	50	41	0.761	-0.079	3.753	0.013	0.01	0	45.2	40.4	79.6	140	127	0	35	33
2014	9	2	23	0	41	0.778	-0.108	3.753	0.01	0.007	0	45.6	40.9	79.1	140	127	0	34	32
2014	9	2	23	10	41	0.741	-0.098	3.753	0.013	0.01	0	45.2	40.4	78.3	140	127	0	35	33
2014	9	2	23	20	41	0.738	-0.105	3.753	0.013	0.01	0	45.2	41.3	79.1	140	128	0	35	32
2014	9	2	23	30	41	0.827	-0.072	3.753	0.016	0.016	0	45.2	40.4	78.7	140	127	0	35	33
2014	9	2	23	40	41	0.787	-0.072	3.753	0.01	0.007	0	45.6	40.9	79.6	141	128	0	35	33
2014	9	2	23	50	41	0.778	-0.082	3.753	0.013	0.01	0	45.6	41.3	79.1	141	128	0	35	32
2014	9	3	0	0	41	0.807	-0.085	3.753	0.013	0.01	0	45.6	41.3	79.6	141	128	0	35	32
2014	9	3	0	10	41	0.797	-0.082	3.753	0.013	0.01	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	3	0	20	41	0.787	-0.082	3.753	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	3	0	30	41	0.784	-0.092	3.753	0.01	0.007	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	3	0	40	41	0.778	-0.089	3.753	0.01	0.007	0	45.2	40.4	78.3	140	127	0	35	33
2014	9	3	0	50	41	0.84	-0.079	3.753	0.01	0.007	0	44.7	40.4	77	139	127	0	35	33
2014	9	3	1	0	41	0.787	-0.098	3.753	0.013	0.01	0	45.2	40.9	78.3	140	127	0	35	32
2014	9	3	1	10	41	0.794	-0.092	3.753	0.016	0.016	0	45.2	40.9	78.3	140	127	0	35	32
2014	9	3	1	20	41	0.755	-0.082	3.753	0.01	0.007	0	45.6	40.4	77.8	140	127	0	34	33
2014	9	3	1	30	41	0.797	-0.089	3.753	0.013	0.01	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	3	1	40	41	0.804	-0.056	3.753	0.016	0.013	0	45.2	40	77	140	127	0	35	34
2014	9	3	1	50	41	0.781	-0.095	3.753	0.013	0.01	0	45.2	40.4	77.8	140	127	0	35	33
2014	9	3	2	0	41	0.804	-0.079	3.753	0.013	0.01	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	3	2	10	41	0.784	-0.102	3.753	0.01	0.007	0	44.7	40.9	77.4	139	127	0	35	32
2014	9	3	2	20	41	0.833	-0.085	3.753	0.01	0.007	0	44.7	40.9	77	139	127	0	35	32
2014	9	3	2	30	41	0.807	-0.092	3.753	0.01	0.007	0	45.2	40.4	76.1	139	127	0	34	33
2014	9	3	2	40	41	0.81	-0.108	3.753	0.01	0.007	0	45.2	40.4	77	140	127	0	35	33
2014	9	3	2	50	41	0.797	-0.089	3.753	0.01	0.007	0	44.7	40.4	77	139	127	0	35	33
2014	9	3	3	0	41	0.823	-0.085	3.753	0.01	0.007	0	44.3	40.4	76.5	139	127	0	36	33
2014	9	3	3	10	41	0.817	-0.079	3.753	0.013	0.01	0	44.7	40.4	77	139	126	0	35	32
2014	9	3	3	20	41	0.804	-0.098	3.753	0.01	0.007	0	44.3	40.4	76.5	139	126	0	36	32
2014	9	3	3	30	41	0.774	-0.075	3.753	0.013	0.01	0	44.7	40.4	77	139	126	0	35	32
2014	9	3	3	40	41	0.807	-0.095	3.753	0.013	0.01	0	44.7	40	76.5	139	126	0	35	33
2014	9	3	3	50	41	0.778	-0.092	3.753	0.01	0.007	0	44.3	40	76.5	138	126	0	35	33
2014	9	3	4	0	41	0.768	-0.079	3.753	0.016	0.013	0	44.3	40	76.5	138	126	0	35	33
2014	9	3	4	10	41	0.781	-0.082	3.757	0.013	0.01	0	44.7	40	75.7	139	127	0	35	34
2014	9	3	4	20	41	0.801	-0.069	3.753	0.01	0.007	0	45.2	40.9	76.5	140	127	0	35	32
2014	9	3	4	30	41	0.801	-0.052	3.753	0.013	0.01	0	45.2	40.4	75.7	140	127	0	35	33
2014	9	3	4	40	41	0.807	-0.092	3.753	0.013	0.01	0	44.7	40.9	76.1	139	127	0	35	32
2014	9	3	4	50	41	0.81	-0.108	3.753	0.01	0.007	0	44.7	40	75.7	139	126	0	35	33
2014	9	3	5	0	41	0.738	-0.079	3.757	0.013	0.01	0	44.7	40	75.7	139	126	0	35	33
2014	9	3	5	10	41	0.778	-0.069	3.757	0.01	0.007	0	44.7	40	76.1	139	126	0	35	33
2014	9	3	5	20	41	0.787	-0.098	3.757	0.013	0.01	0	44.3	40.4	75.7	139	127	0	36	33
2014	9	3	5	30	41	0.778	-0.079	3.757	0.013	0.01	0	44.7	40.4	75.7	139	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	5	40	41	0.761	-0.095	3.757	0.013	0.01	0	44.7	40.9	75.3	139	127	0	35	32
2014	9	3	5	50	41	0.764	-0.072	3.757	0.01	0.007	0	44.7	40	74.8	139	126	0	35	33
2014	9	3	6	0	41	0.771	-0.095	3.757	0.013	0.01	0	44.7	40	75.3	139	126	0	35	33
2014	9	3	6	10	41	0.755	-0.062	3.757	0.013	0.01	0	45.2	40	74	139	126	0	34	33
2014	9	3	6	20	41	0.814	-0.072	3.757	0.013	0.01	0	45.2	40	74.8	139	126	0	34	33
2014	9	3	6	30	41	0.768	-0.069	3.757	0.01	0.007	0	44.3	40	74	138	126	0	35	33
2014	9	3	6	40	41	0.801	-0.072	3.757	0.01	0.007	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	3	6	50	41	0.751	-0.095	3.757	0.013	0.01	0	43.9	40	74.8	137	125	0	35	32
2014	9	3	7	0	41	0.778	-0.102	3.76	0.01	0.007	0	43.9	39.6	74.8	137	124	0	35	32
2014	9	3	7	10	41	0.768	-0.079	3.76	0.01	0.007	0	43.9	39.6	74.4	137	124	0	35	32
2014	9	3	7	20	41	0.764	-0.105	3.76	0.013	0.01	0	43.4	38.7	74	136	123	0	35	33
2014	9	3	7	30	41	0.787	-0.062	3.76	0.01	0.007	0	43	38.7	74	136	123	0	36	33
2014	9	3	7	40	41	0.784	-0.075	3.763	0.01	0.007	0	43.4	39.1	74.4	136	123	0	35	32
2014	9	3	7	50	41	0.787	-0.062	3.763	0.01	0.007	0	43.4	38.7	73.5	136	123	0	35	33
2014	9	3	8	0	41	0.771	-0.079	3.763	0.01	0.007	0	43.4	38.7	74	136	123	0	35	33
2014	9	3	8	10	41	0.797	-0.092	3.763	0.01	0.007	0	43.4	39.1	74.4	136	123	0	35	32
2014	9	3	8	20	41	0.801	-0.069	3.763	0.01	0.007	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	3	8	30	41	0.791	-0.089	3.766	0.01	0.007	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	3	8	40	41	0.814	-0.092	3.766	0.01	0.007	0	43.4	38.7	74.8	136	123	0	35	33
2014	9	3	8	50	41	0.801	-0.095	3.766	0.01	0.007	0	43	38.7	74.8	135	123	0	35	33
2014	9	3	9	0	41	0.827	-0.079	3.766	0.016	0.013	0	43	38.7	75.3	135	122	0	35	32
2014	9	3	9	10	41	0.784	-0.092	3.766	0.01	0.007	0	43	38.7	75.3	135	122	0	35	32
2014	9	3	9	20	41	0.768	-0.085	3.766	0.013	0.01	0	43.4	38.7	74.8	136	123	0	35	33
2014	9	3	9	30	41	0.81	-0.069	3.766	0.01	0.007	0	43	38.7	75.3	135	123	0	35	33
2014	9	3	9	40	41	0.807	-0.089	3.763	0.01	0.007	0	43	38.7	74.8	135	122	0	35	32
2014	9	3	9	50	41	0.791	-0.059	3.763	0.013	0.01	0	43	38.7	75.3	135	123	0	35	33
2014	9	3	10	0	41	0.804	-0.046	3.76	0.013	0.01	0	43.4	39.6	74.4	136	124	0	35	32
2014	9	3	10	10	41	0.791	-0.082	3.76	0.02	0.016	0	43	38.3	74.4	135	123	0	35	34
2014	9	3	10	20	41	0.774	-0.082	3.76	0.016	0.013	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	3	10	30	41	0.817	-0.108	3.76	0.01	0.007	0	43.4	39.1	75.3	136	124	0	35	33
2014	9	3	10	40	41	0.791	-0.075	3.757	0.01	0.007	0	43	38.7	73.1	135	123	0	35	33
2014	9	3	10	50	41	0.807	-0.108	3.76	0.013	0.01	0	43	38.7	75.7	135	123	0	35	33
2014	9	3	11	0	41	0.778	-0.102	3.757	0.01	0.007	0	43.4	38.7	75.7	136	123	0	35	33
2014	9	3	11	10	41	0.804	-0.066	3.757	0.01	0.007	0	43	38.7	75.7	135	123	0	35	33
2014	9	3	11	20	41	0.791	-0.052	3.757	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	9	3	11	30	41	0.823	-0.079	3.757	0.013	0.01	0	43	38.7	75.3	135	123	0	35	33
2014	9	3	11	40	41	0.761	-0.069	3.757	0.013	0.01	0	43	38.7	76.1	135	124	0	35	34
2014	9	3	11	50	41	0.787	-0.079	3.757	0.013	0.01	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	3	12	0	41	0.784	-0.079	3.757	0.01	0.007	0	43	38.7	77.8	135	123	0	35	33
2014	9	3	12	10	41	0.81	-0.079	3.757	0.01	0.007	0	42.6	38.3	78.3	134	122	0	35	33
2014	9	3	12	20	41	0.778	-0.072	3.757	0.013	0.01	0	43	38.7	77.8	135	124	0	35	34
2014	9	3	12	30	41	0.764	-0.105	3.757	0.016	0.013	0	43	39.1	77	135	124	0	35	33
2014	9	3	12	40	41	0.781	-0.098	3.757	0.01	0.007	0	43	39.1	77.4	135	123	0	35	32
2014	9	3	12	50	41	0.794	-0.072	3.757	0.01	0.007	0	43	39.1	77.4	135	123	0	35	32
2014	9	3	13	0	41	0.761	-0.079	3.757	0.01	0.007	0	43	39.1	77.8	135	123	0	35	32
2014	9	3	13	10	41	0.794	-0.092	3.757	0.01	0.007	0	42.6	39.1	77.4	134	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	13	20	41	0.764	-0.082	3.757	0.01	0.007	0	43	38.7	77	135	123	0	35	33
2014	9	3	13	30	41	0.787	-0.089	3.757	0.01	0.007	0	42.6	38.7	78.3	134	123	0	35	33
2014	9	3	13	40	41	0.778	-0.095	3.753	0.013	0.01	0	42.6	38.7	67.5	135	123	0	36	33
2014	9	3	13	50	41	0.774	-0.112	3.753	0.01	0.007	0	43	39.1	64.9	135	123	0	35	32
2014	9	3	14	0	41	0.738	-0.105	3.753	0.013	0.01	0	43	38.7	58.9	135	123	0	35	33
2014	9	3	14	10	41	0.768	-0.059	3.75	0.013	0.01	0	43	39.1	58	135	124	0	35	33
2014	9	3	14	20	41	0.784	-0.092	3.75	0.013	0.01	0	43	39.1	56.8	135	124	0	35	33
2014	9	3	14	30	41	0.778	-0.079	3.75	0.016	0.016	0	43.4	39.6	54.2	136	124	0	35	32
2014	9	3	14	40	41	0.791	-0.108	3.75	0.01	0.007	0	43.9	39.6	63.2	137	125	0	35	33
2014	9	3	14	50	41	0.761	-0.112	3.75	0.01	0.007	0	43.9	39.1	57.6	136	124	0	34	33
2014	9	3	15	0	41	0.728	-0.072	3.75	0.016	0.013	0	43	39.1	55.5	135	123	0	35	32
2014	9	3	15	10	41	0.751	-0.102	3.75	0.01	0.007	0	43.4	39.1	53.8	136	124	0	35	33
2014	9	3	15	20	41	0.781	-0.095	3.747	0.01	0.007	0	43.9	40	55	137	125	0	35	32
2014	9	3	15	30	41	0.758	-0.062	3.747	0.013	0.01	0	43.9	39.6	52.9	137	125	0	35	33
2014	9	3	15	40	41	0.758	-0.092	3.747	0.01	0.007	0	44.3	39.6	56.8	137	125	0	34	33
2014	9	3	15	50	41	0.768	-0.095	3.747	0.01	0.007	0	43.9	40	57.6	137	125	0	35	32
2014	9	3	16	0	41	0.774	-0.059	3.743	0.01	0.007	0	43.9	40	52.5	137	125	0	35	32
2014	9	3	16	10	41	0.761	-0.062	3.743	0.01	0.007	0	43.9	40	50.7	137	125	0	35	32
2014	9	3	16	20	41	0.748	-0.108	3.743	0.01	0.007	0	43.9	40.4	55.9	137	126	0	35	32
2014	9	3	16	30	41	0.771	-0.131	3.743	0.01	0.007	0	43.9	39.6	52.9	137	125	0	35	33
2014	9	3	16	40	41	0.768	-0.062	3.743	0.016	0.013	0	43.9	39.6	53.8	137	125	0	35	33
2014	9	3	16	50	41	0.764	-0.092	3.743	0.013	0.01	0	43.9	40	51.6	137	125	0	35	32
2014	9	3	17	0	41	0.728	-0.098	3.743	0.016	0.013	0	43.4	39.6	57.2	136	124	0	35	32
2014	9	3	17	10	41	0.732	-0.066	3.743	0.01	0.007	0	43.4	39.1	55	136	124	0	35	33
2014	9	3	17	20	41	0.735	-0.108	3.74	0.016	0.013	0	43	38.7	54.2	135	123	0	35	33
2014	9	3	17	30	41	0.768	-0.095	3.743	0.01	0.007	0	43	38.7	65.4	135	123	0	35	33
2014	9	3	17	40	41	0.764	-0.079	3.743	0.01	0.007	0	43	38.7	63.2	135	123	0	35	33
2014	9	3	17	50	41	0.781	-0.112	3.743	0.013	0.01	0	43.4	39.6	64.1	136	124	0	35	32
2014	9	3	18	0	41	0.778	-0.072	3.74	0.01	0.007	0	43.4	39.1	55.5	136	124	0	35	33
2014	9	3	18	10	41	0.784	-0.089	3.743	0.013	0.01	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	3	18	20	41	0.804	-0.072	3.743	0.013	0.01	0	43.9	39.6	71.8	136	124	0	34	32
2014	9	3	18	30	41	0.791	-0.095	3.743	0.013	0.01	0	43.9	39.6	77	136	124	0	34	32
2014	9	3	18	40	41	0.771	-0.079	3.743	0.016	0.013	0	43.4	39.1	77.4	136	124	0	35	33
2014	9	3	18	50	41	0.787	-0.092	3.743	0.013	0.01	0	43.4	39.1	77.4	136	124	0	35	33
2014	9	3	19	0	41	0.781	-0.043	3.743	0.016	0.013	0	43.9	40	77.8	137	125	0	35	32
2014	9	3	19	10	41	0.791	-0.079	3.743	0.013	0.01	0	43.9	40	76.1	137	125	0	35	32
2014	9	3	19	20	41	0.764	-0.079	3.743	0.01	0.007	0	43.9	40	78.3	137	125	0	35	32
2014	9	3	19	30	41	0.801	-0.059	3.743	0.013	0.01	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	3	19	40	41	0.771	-0.056	3.743	0.016	0.013	0	44.7	40.9	76.1	139	127	0	35	32
2014	9	3	19	50	41	0.791	-0.079	3.743	0.01	0.007	0	45.2	41.3	77	140	128	0	35	32
2014	9	3	20	0	41	0.797	-0.105	3.743	0.013	0.01	0	45.2	41.3	76.5	140	128	0	35	32
2014	9	3	20	10	41	0.778	-0.079	3.743	0.016	0.013	0	46	41.3	76.5	141	129	0	34	33
2014	9	3	20	20	41	0.797	-0.079	3.743	0.01	0.007	0	45.6	41.3	77.8	140	128	0	34	32
2014	9	3	20	30	41	0.797	-0.072	3.743	0.013	0.01	0	45.2	40.9	77	140	128	0	35	33
2014	9	3	20	40	41	0.817	-0.089	3.743	0.01	0.007	0	45.2	41.3	76.1	140	128	0	35	32
2014	9	3	20	50	41	0.81	-0.089	3.743	0.013	0.01	0	45.2	41.3	77	140	128	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	3	21	0	41	0.804	-0.056	3.743	0.016	0.013	0	44.7	41.3	77.4	139	128	0	35	32
2014	9	3	21	10	41	0.784	-0.072	3.743	0.013	0.01	0	45.2	40.9	77	140	128	0	35	33
2014	9	3	21	20	41	0.781	-0.066	3.743	0.01	0.007	0	45.2	41.3	77	140	128	0	35	32
2014	9	3	21	30	41	0.745	-0.072	3.743	0.01	0.007	0	45.2	41.3	76.1	140	129	0	35	33
2014	9	3	21	40	41	0.755	-0.062	3.743	0.01	0.007	0	45.2	41.3	76.5	141	129	0	36	33
2014	9	3	21	50	41	0.755	-0.095	3.743	0.016	0.013	0	45.6	41.3	77	140	128	0	34	32
2014	9	3	22	0	41	0.741	-0.092	3.743	0.013	0.01	0	45.2	41.3	77	140	128	0	35	32
2014	9	3	22	10	41	0.781	-0.072	3.743	0.013	0.01	0	45.2	41.3	77	140	128	0	35	32
2014	9	3	22	20	41	0.764	-0.092	3.743	0.013	0.01	0	45.2	40.9	75.7	140	128	0	35	33
2014	9	3	22	30	41	0.774	-0.069	3.743	0.016	0.013	0	45.6	40.9	76.5	140	128	0	34	33
2014	9	3	22	40	41	0.817	-0.102	3.743	0.01	0.007	0	45.2	40.9	77.4	140	128	0	35	33
2014	9	3	22	50	41	0.751	-0.112	3.743	0.01	0.007	0	45.2	41.7	76.5	140	129	0	35	32
2014	9	3	23	0	41	0.81	-0.059	3.747	0.01	0.007	0	44.7	40.9	77.4	139	128	0	35	33
2014	9	3	23	10	41	0.787	-0.059	3.743	0.013	0.01	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	3	23	20	41	0.748	-0.092	3.747	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	3	23	30	41	0.814	-0.069	3.747	0.013	0.01	0	45.2	40.4	77	140	128	0	35	34
2014	9	3	23	40	41	0.791	-0.095	3.743	0.01	0.007	0	44.7	41.3	77.4	139	128	0	35	32
2014	9	3	23	50	41	0.787	-0.115	3.747	0.01	0.007	0	45.2	41.3	77.8	140	128	0	35	32
2014	9	4	0	0	41	0.758	-0.079	3.747	0.016	0.013	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	4	0	10	41	0.794	-0.062	3.747	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	4	0	20	41	0.794	-0.092	3.747	0.013	0.01	0	45.2	40.9	77.4	139	127	0	34	32
2014	9	4	0	30	41	0.781	-0.079	3.747	0.01	0.007	0	45.2	40.4	78.3	139	127	0	34	33
2014	9	4	0	40	41	0.755	-0.098	3.747	0.01	0.007	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	4	0	50	41	0.768	-0.102	3.747	0.01	0.007	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	4	1	0	41	0.787	-0.082	3.747	0.013	0.01	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	4	1	10	41	0.787	-0.115	3.747	0.01	0.007	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	4	1	20	41	0.774	-0.059	3.747	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	4	1	30	41	0.771	-0.098	3.747	0.01	0.007	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	4	1	40	41	0.778	-0.075	3.747	0.01	0.007	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	4	1	50	41	0.778	-0.085	3.747	0.016	0.013	0	44.3	40.4	79.1	138	127	0	35	33
2014	9	4	2	0	41	0.787	-0.079	3.747	0.01	0.007	0	45.2	40.4	78.3	139	127	0	34	33
2014	9	4	2	10	41	0.781	-0.098	3.747	0.013	0.01	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	4	2	20	41	0.778	-0.098	3.747	0.01	0.007	0	44.7	40.9	78.3	138	127	0	34	32
2014	9	4	2	30	41	0.768	-0.062	3.747	0.01	0.007	0	44.7	40.9	77.8	139	128	0	35	33
2014	9	4	2	40	41	0.761	-0.082	3.747	0.013	0.01	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	4	2	50	41	0.804	-0.098	3.747	0.01	0.007	0	44.3	40.4	78.3	138	127	0	35	33
2014	9	4	3	0	41	0.768	-0.095	3.747	0.013	0.01	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	4	3	10	41	0.745	-0.066	3.747	0.01	0.007	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	4	3	20	41	0.774	-0.095	3.747	0.01	0.007	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	4	3	30	41	0.778	-0.062	3.747	0.01	0.007	0	44.3	40.9	78.7	139	127	0	36	32
2014	9	4	3	40	41	0.764	-0.095	3.747	0.013	0.01	0	44.7	40.9	78.3	138	127	0	34	32
2014	9	4	3	50	41	0.787	-0.108	3.747	0.013	0.01	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	4	4	0	41	0.787	-0.072	3.747	0.01	0.007	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	4	4	10	41	0.791	-0.095	3.747	0.01	0.007	0	44.7	40.9	77.4	139	127	0	35	32
2014	9	4	4	20	41	0.745	-0.062	3.747	0.013	0.01	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	4	4	30	41	0.778	-0.118	3.747	0.01	0.007	0	44.3	40.4	77.4	138	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	4	40	41	0.804	-0.049	3.747	0.013	0.01	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	4	4	50	41	0.787	-0.066	3.747	0.01	0.007	0	43.9	40	78.3	137	126	0	35	33
2014	9	4	5	0	41	0.771	-0.089	3.747	0.013	0.01	0	44.3	39.6	77	138	126	0	35	34
2014	9	4	5	10	41	0.774	-0.082	3.747	0.016	0.016	0	44.3	40	77	138	126	0	35	33
2014	9	4	5	20	41	0.768	-0.075	3.747	0.013	0.01	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	4	5	30	41	0.791	-0.089	3.747	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	4	5	40	41	0.761	-0.079	3.747	0.01	0.007	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	4	5	50	41	0.82	-0.075	3.747	0.01	0.007	0	44.3	40.4	77.4	139	127	0	36	33
2014	9	4	6	0	41	0.781	-0.056	3.747	0.016	0.013	0	44.3	40.9	77.4	139	127	0	36	32
2014	9	4	6	10	41	0.771	-0.056	3.747	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	4	6	20	41	0.758	-0.066	3.747	0.016	0.013	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	4	6	30	41	0.755	-0.072	3.747	0.013	0.01	0	44.7	40	77.4	139	126	0	35	33
2014	9	4	6	40	41	0.774	-0.075	3.747	0.013	0.01	0	44.7	40.4	77.4	139	126	0	35	32
2014	9	4	6	50	41	0.758	-0.082	3.747	0.013	0.01	0	43.9	39.1	77.4	137	124	0	35	33
2014	9	4	7	0	41	0.807	-0.056	3.747	0.016	0.013	0	43.9	39.1	77.4	137	124	0	35	33
2014	9	4	7	10	41	0.764	-0.062	3.747	0.01	0.007	0	43.9	38.7	77.8	137	123	0	35	33
2014	9	4	7	20	41	0.784	-0.095	3.747	0.01	0.007	0	43.4	39.1	77.8	136	124	0	35	33
2014	9	4	7	30	41	0.758	-0.098	3.747	0.01	0.007	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	4	7	40	41	0.846	-0.046	3.747	0.01	0.007	0	43.4	39.1	77.4	136	124	0	35	33
2014	9	4	7	50	41	0.791	-0.121	3.747	0.01	0.007	0	43.4	38.7	77	136	123	0	35	33
2014	9	4	8	0	41	0.787	-0.075	3.747	0.013	0.01	0	42.6	39.1	76.5	135	123	0	36	32
2014	9	4	8	10	41	0.771	-0.066	3.747	0.016	0.013	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	4	8	20	41	0.745	-0.075	3.747	0.013	0.01	0	43.4	39.1	76.5	135	124	0	34	33
2014	9	4	8	30	41	0.768	-0.059	3.747	0.013	0.01	0	43.4	39.1	75.7	136	124	0	35	33
2014	9	4	8	40	41	0.787	-0.092	3.747	0.01	0.007	0	43	39.1	77.8	135	124	0	35	33
2014	9	4	8	50	41	0.81	-0.075	3.747	0.013	0.01	0	43.4	38.7	77.4	136	124	0	35	34
2014	9	4	9	0	41	0.771	-0.066	3.747	0.013	0.01	0	43	38.7	76.5	135	123	0	35	33
2014	9	4	9	10	41	0.804	-0.079	3.747	0.01	0.007	0	43	39.1	77.4	135	124	0	35	33
2014	9	4	9	20	41	0.801	-0.069	3.747	0.01	0.007	0	43	39.1	76.5	135	124	0	35	33
2014	9	4	9	30	41	0.787	-0.059	3.747	0.013	0.01	0	43	39.1	76.1	135	124	0	35	33
2014	9	4	9	40	41	0.781	-0.082	3.747	0.01	0.007	0	43	38.7	77.4	135	123	0	35	33
2014	9	4	9	50	41	0.738	-0.066	3.747	0.01	0.007	0	43	38.7	77.4	135	123	0	35	33
2014	9	4	10	0	41	0.804	-0.082	3.747	0.016	0.013	0	43	39.6	78.3	135	124	0	35	32
2014	9	4	10	10	41	0.787	-0.075	3.747	0.013	0.01	0	43	38.7	77.4	135	123	0	35	33
2014	9	4	10	20	41	0.784	-0.092	3.747	0.01	0.007	0	43	38.7	77.8	135	123	0	35	33
2014	9	4	10	30	41	0.794	-0.069	3.747	0.013	0.01	0	43	38.7	77.8	135	123	0	35	33
2014	9	4	10	40	41	0.774	-0.098	3.747	0.013	0.01	0	42.6	38.7	78.3	134	123	0	35	33
2014	9	4	10	50	41	0.781	-0.066	3.747	0.016	0.013	0	42.6	38.7	79.1	134	123	0	35	33
2014	9	4	11	0	41	0.768	-0.112	3.747	0.01	0.007	0	43	38.3	77.8	135	123	0	35	34
2014	9	4	11	10	41	0.778	-0.095	3.747	0.01	0.007	0	42.6	38.3	79.1	134	123	0	35	34
2014	9	4	11	20	41	0.827	-0.118	3.747	0.013	0.01	0	43	39.1	79.1	135	123	0	35	32
2014	9	4	11	30	41	0.804	-0.098	3.747	0.01	0.007	0	42.6	38.7	79.6	134	123	0	35	33
2014	9	4	11	40	41	0.781	-0.095	3.747	0.013	0.01	0	43	39.6	79.1	135	124	0	35	32
2014	9	4	11	50	41	0.751	-0.118	3.747	0.016	0.013	0	42.6	38.7	80	134	122	0	35	32
2014	9	4	12	0	41	0.794	-0.052	3.747	0.013	0.01	0	43	39.1	80	135	124	0	35	33
2014	9	4	12	10	41	0.751	-0.092	3.743	0.01	0.007	0	42.1	38.7	79.6	134	123	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	12	20	41	0.771	-0.128	3.743	0.01	0.007	0	42.6	38.7	79.6	134	123	0	35	33
2014	9	4	12	30	41	0.764	-0.098	3.743	0.013	0.01	0	43	39.1	79.6	135	123	0	35	32
2014	9	4	12	40	41	0.761	-0.072	3.743	0.013	0.01	0	43	39.1	77.4	135	124	0	35	33
2014	9	4	12	50	41	0.768	-0.085	3.743	0.016	0.013	0	43	38.7	67.5	135	123	0	35	33
2014	9	4	13	0	41	0.784	-0.075	3.743	0.01	0.007	0	43	38.7	78.3	134	123	0	34	33
2014	9	4	13	10	41	0.738	-0.105	3.743	0.01	0.007	0	42.6	38.7	77	134	123	0	35	33
2014	9	4	13	20	41	0.778	-0.128	3.74	0.016	0.013	0	43.4	39.6	59.8	135	124	0	34	32
2014	9	4	13	30	41	0.761	-0.072	3.737	0.013	0.01	0	43	39.6	54.6	135	124	0	35	32
2014	9	4	13	40	41	0.794	-0.062	3.737	0.013	0.01	0	43.4	38.7	60.6	136	124	0	35	34
2014	9	4	13	50	41	0.758	-0.079	3.737	0.013	0.01	0	43	39.1	57.2	135	124	0	35	33
2014	9	4	14	0	41	0.787	-0.108	3.734	0.013	0.01	0	43	39.1	59.8	135	124	0	35	33
2014	9	4	14	10	41	0.771	-0.089	3.734	0.01	0.007	0	43.9	39.6	56.3	136	125	0	34	33
2014	9	4	14	20	41	0.748	-0.066	3.734	0.013	0.01	0	43.4	39.6	59.3	136	125	0	35	33
2014	9	4	14	30	41	0.719	-0.098	3.734	0.013	0.01	0	43.4	39.6	71.8	136	125	0	35	33
2014	9	4	14	40	41	0.735	-0.082	3.73	0.013	0.01	0	43.4	40	69.7	136	125	0	35	32
2014	9	4	14	50	41	0.82	-0.079	3.727	0.016	0.013	0	43.4	39.6	54.2	136	125	0	35	33
2014	9	4	15	0	41	0.755	-0.079	3.724	0.01	0.007	0	43.4	40	60.2	136	125	0	35	32
2014	9	4	15	10	41	0.761	-0.089	3.724	0.01	0.007	0	43.4	40.4	61.5	137	126	0	36	32
2014	9	4	15	20	41	0.774	-0.085	3.724	0.01	0.007	0	44.7	40.4	58.5	138	126	0	34	32
2014	9	4	15	30	41	0.755	-0.098	3.724	0.01	0.007	0	44.3	40.4	53.3	138	127	0	35	33
2014	9	4	15	40	41	0.758	-0.085	3.72	0.013	0.01	0	43.9	40.4	54.6	137	126	0	35	32
2014	9	4	15	50	41	0.764	-0.098	3.72	0.013	0.01	0	43.9	40.4	53.3	137	126	0	35	32
2014	9	4	16	0	41	0.761	-0.105	3.72	0.016	0.013	0	43.9	40	55	137	126	0	35	33
2014	9	4	16	10	41	0.741	-0.066	3.72	0.01	0.007	0	44.3	40	54.2	137	126	0	34	33
2014	9	4	16	20	41	0.722	-0.072	3.717	0.01	0.007	0	43.9	40	55.5	137	126	0	35	33
2014	9	4	16	30	41	0.755	-0.121	3.717	0.01	0.007	0	43.9	40	52.9	137	126	0	35	33
2014	9	4	16	40	41	0.758	-0.092	3.717	0.016	0.013	0	43.9	40.4	57.6	137	126	0	35	32
2014	9	4	16	50	41	0.761	-0.105	3.717	0.01	0.007	0	44.3	40.4	61.5	137	126	0	34	32
2014	9	4	17	0	41	0.755	-0.095	3.717	0.01	0.007	0	43.4	40.4	57.2	136	126	0	35	32
2014	9	4	17	10	41	0.827	-0.082	3.717	0.01	0.007	0	43.4	39.6	62.8	136	125	0	35	33
2014	9	4	17	20	41	0.751	-0.079	3.717	0.016	0.013	0	43.9	39.6	54.2	136	125	0	34	33
2014	9	4	17	30	41	0.791	-0.108	3.717	0.01	0.007	0	43.4	39.1	59.8	136	124	0	35	33
2014	9	4	17	40	41	0.797	-0.095	3.717	0.013	0.01	0	43.4	39.1	58	136	124	0	35	33
2014	9	4	17	50	41	0.781	-0.089	3.717	0.016	0.013	0	43.4	39.1	62.8	136	124	0	35	33
2014	9	4	18	0	41	0.787	-0.059	3.714	0.01	0.007	0	43.4	39.1	61.1	136	124	0	35	33
2014	9	4	18	10	41	0.764	-0.102	3.717	0.016	0.016	0	43.4	39.6	71	136	124	0	35	32
2014	9	4	18	20	41	0.758	-0.092	3.717	0.01	0.007	0	43.9	39.1	71.8	136	124	0	34	33
2014	9	4	18	30	41	0.787	-0.092	3.717	0.01	0.007	0	43.4	39.6	77.8	136	125	0	35	33
2014	9	4	18	40	41	0.801	-0.095	3.717	0.01	0.007	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	4	18	50	41	0.804	-0.066	3.717	0.01	0.007	0	43.9	40	77.4	137	125	0	35	32
2014	9	4	19	0	41	0.768	-0.062	3.717	0.01	0.007	0	43.9	40.4	78.3	137	126	0	35	32
2014	9	4	19	10	41	0.771	-0.089	3.717	0.013	0.01	0	43.9	40.4	77.4	137	126	0	35	32
2014	9	4	19	20	41	0.764	-0.102	3.717	0.013	0.01	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	4	19	30	41	0.794	-0.105	3.717	0.013	0.01	0	44.3	40.4	76.1	138	126	0	35	32
2014	9	4	19	40	41	0.797	-0.102	3.717	0.01	0.007	0	44.7	41.3	74	139	128	0	35	32
2014	9	4	19	50	41	0.761	-0.072	3.717	0.016	0.013	0	45.2	41.3	57.6	140	129	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	4	20	0	41	0.761	-0.089	3.717	0.013	0.01	0	45.2	41.7	64.5	140	129	0	35	32
2014	9	4	20	10	41	0.764	-0.059	3.717	0.016	0.016	0	45.6	41.3	62.4	141	130	0	35	34
2014	9	4	20	20	41	0.791	-0.112	3.717	0.01	0.007	0	45.6	41.3	72.7	141	129	0	35	33
2014	9	4	20	30	41	0.761	-0.098	3.717	0.01	0.007	0	45.6	41.3	76.1	140	129	0	34	33
2014	9	4	20	40	41	0.781	-0.052	3.717	0.013	0.01	0	45.2	41.3	74	140	129	0	35	33
2014	9	4	20	50	41	0.781	-0.066	3.717	0.013	0.01	0	45.2	40.9	77.8	139	128	0	34	33
2014	9	4	21	0	41	0.764	-0.079	3.717	0.01	0.007	0	45.2	41.7	77.4	140	129	0	35	32
2014	9	4	21	10	41	0.83	-0.092	3.72	0.016	0.013	0	44.7	41.7	76.1	139	129	0	35	32
2014	9	4	21	20	41	0.778	-0.098	3.717	0.01	0.007	0	44.7	41.7	76.1	139	129	0	35	32
2014	9	4	21	30	41	0.764	-0.079	3.717	0.013	0.01	0	44.7	41.7	70.1	139	129	0	35	32
2014	9	4	21	40	41	0.755	-0.095	3.72	0.01	0.007	0	45.2	41.3	77	140	129	0	35	33
2014	9	4	21	50	41	0.81	-0.092	3.72	0.01	0.007	0	45.2	41.7	76.5	140	129	0	35	32
2014	9	4	22	0	41	0.83	-0.115	3.72	0.016	0.013	0	45.2	41.3	77	140	129	0	35	33
2014	9	4	22	10	41	0.791	-0.102	3.72	0.016	0.016	0	45.2	41.7	76.5	140	129	0	35	32
2014	9	4	22	20	41	0.761	-0.105	3.72	0.016	0.013	0	45.2	40.9	76.1	140	128	0	35	33
2014	9	4	22	30	41	0.751	-0.085	3.72	0.01	0.007	0	45.6	41.3	76.1	140	129	0	34	33
2014	9	4	22	40	41	0.81	-0.128	3.72	0.01	0.007	0	44.7	41.3	75.7	139	129	0	35	33
2014	9	4	22	50	41	0.781	-0.089	3.72	0.016	0.013	0	44.7	40.9	73.1	139	128	0	35	33
2014	9	4	23	0	41	0.755	-0.089	3.72	0.013	0.01	0	45.2	41.3	75.3	140	129	0	35	33
2014	9	4	23	10	41	0.755	-0.066	3.72	0.016	0.013	0	44.7	40.9	75.7	139	128	0	35	33
2014	9	4	23	20	41	0.758	-0.079	3.72	0.013	0.01	0	44.7	41.3	76.1	139	128	0	35	32
2014	9	4	23	30	41	0.781	-0.075	3.72	0.01	0.007	0	44.7	41.3	75.3	139	129	0	35	33
2014	9	4	23	40	41	0.804	-0.089	3.72	0.013	0.01	0	45.2	40.9	75.3	139	128	0	34	33
2014	9	4	23	50	41	0.784	-0.059	3.72	0.013	0.01	0	44.7	41.3	74	139	128	0	35	32
2014	9	5	0	0	41	0.787	-0.089	3.724	0.013	0.01	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	5	0	10	41	0.791	-0.052	3.724	0.013	0.01	0	44.3	40.9	75.3	138	127	0	35	32
2014	9	5	0	20	41	0.761	-0.033	3.724	0.013	0.01	0	44.3	40.4	74.8	138	127	0	35	33
2014	9	5	0	30	41	0.751	-0.066	3.724	0.01	0.007	0	44.3	41.3	74.8	138	128	0	35	32
2014	9	5	0	40	41	0.797	-0.092	3.727	0.013	0.01	0	44.3	41.3	75.3	138	128	0	35	32
2014	9	5	0	50	41	0.784	-0.059	3.727	0.01	0.007	0	44.3	40.9	74.8	138	127	0	35	32
2014	9	5	1	0	41	0.778	-0.066	3.727	0.01	0.007	0	44.3	40.9	74.4	138	128	0	35	33
2014	9	5	1	10	41	0.741	-0.095	3.734	0.013	0.01	0	43.9	40.4	75.7	137	127	0	35	33
2014	9	5	1	20	41	0.761	-0.056	3.734	0.016	0.013	0	44.3	41.3	74.8	138	128	0	35	32
2014	9	5	1	30	41	0.761	-0.079	3.734	0.013	0.01	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	5	1	40	41	0.804	-0.108	3.734	0.013	0.01	0	44.3	40.9	75.3	137	127	0	34	32
2014	9	5	1	50	41	0.764	-0.056	3.737	0.013	0.01	0	43.9	40.4	76.1	137	127	0	35	33
2014	9	5	2	0	41	0.778	-0.052	3.737	0.013	0.01	0	44.3	40.9	76.1	138	128	0	35	33
2014	9	5	2	10	41	0.764	-0.046	3.737	0.01	0.007	0	44.3	40.4	77	138	127	0	35	33
2014	9	5	2	20	41	0.797	-0.082	3.737	0.013	0.01	0	44.3	40.9	77.4	137	127	0	34	32
2014	9	5	2	30	41	0.764	-0.082	3.737	0.01	0.007	0	43.9	40.4	77	137	127	0	35	33
2014	9	5	2	40	41	0.778	-0.118	3.737	0.01	0.007	0	43.9	40.4	77.4	137	127	0	35	33
2014	9	5	2	50	41	0.787	-0.072	3.737	0.01	0.007	0	44.3	40.9	77.4	138	128	0	35	33
2014	9	5	3	0	41	0.791	-0.079	3.737	0.01	0.007	0	43.9	40.9	77.8	137	127	0	35	32
2014	9	5	3	10	41	0.745	-0.066	3.737	0.01	0.007	0	44.3	41.3	77.8	138	128	0	35	32
2014	9	5	3	20	41	0.817	-0.085	3.74	0.013	0.01	0	44.3	40.9	77.8	138	127	0	35	32
2014	9	5	3	30	41	0.787	-0.089	3.74	0.013	0.01	0	44.3	40.4	78.3	138	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	3	40	41	0.787	-0.092	3.74	0.016	0.013	0	43.9	40.4	78.3	137	126	0	35	32
2014	9	5	3	50	41	0.761	-0.102	3.74	0.013	0.01	0	44.3	40	78.7	137	126	0	34	33
2014	9	5	4	0	41	0.764	-0.095	3.74	0.01	0.007	0	44.3	40.9	80	138	127	0	35	32
2014	9	5	4	10	41	0.764	-0.095	3.74	0.013	0.01	0	43.9	40.4	80	137	127	0	35	33
2014	9	5	4	20	41	0.797	-0.092	3.74	0.01	0.007	0	44.3	40.4	80	138	127	0	35	33
2014	9	5	4	30	41	0.768	-0.075	3.74	0.01	0.007	0	43.9	40	80.4	137	126	0	35	33
2014	9	5	4	40	41	0.804	-0.098	3.74	0.013	0.01	0	43.9	40.4	80.4	137	126	0	35	32
2014	9	5	4	50	41	0.771	-0.095	3.743	0.013	0.01	0	44.7	40.9	79.6	139	127	0	35	32
2014	9	5	5	0	41	0.758	-0.082	3.74	0.016	0.016	0	44.3	40.4	79.1	138	127	0	35	33
2014	9	5	5	10	41	0.735	-0.085	3.74	0.01	0.007	0	44.7	41.3	79.6	139	128	0	35	32
2014	9	5	5	20	41	0.771	-0.089	3.74	0.01	0.007	0	44.3	40.4	79.1	138	127	0	35	33
2014	9	5	5	30	41	0.814	-0.056	3.743	0.01	0.007	0	44.3	40.4	80	138	127	0	35	33
2014	9	5	5	40	41	0.755	-0.095	3.743	0.01	0.007	0	44.3	40.4	80	138	127	0	35	33
2014	9	5	5	50	41	0.774	-0.089	3.74	0.01	0.007	0	44.3	40.4	79.6	138	127	0	35	33
2014	9	5	6	0	41	0.774	-0.072	3.74	0.01	0.007	0	44.7	41.3	78.7	139	128	0	35	32
2014	9	5	6	10	41	0.784	-0.105	3.743	0.013	0.01	0	44.3	40.4	79.6	138	127	0	35	33
2014	9	5	6	20	41	0.771	-0.085	3.74	0.01	0.007	0	44.3	40.9	79.6	138	127	0	35	32
2014	9	5	6	30	41	0.817	-0.108	3.743	0.013	0.01	0	43.9	40.4	79.1	137	127	0	35	33
2014	9	5	6	40	41	0.771	-0.072	3.743	0.016	0.013	0	43.9	40	79.1	138	126	0	36	33
2014	9	5	6	50	41	0.778	-0.059	3.743	0.013	0.01	0	43.9	40	78.7	137	126	0	35	33
2014	9	5	7	0	41	0.774	-0.046	3.743	0.01	0.007	0	43.4	40	79.6	136	125	0	35	32
2014	9	5	7	10	41	0.755	-0.075	3.743	0.01	0.007	0	43	39.1	79.6	135	124	0	35	33
2014	9	5	7	20	41	0.771	-0.092	3.743	0.01	0.007	0	43	39.1	79.1	135	124	0	35	33
2014	9	5	7	30	41	0.791	-0.082	3.743	0.013	0.01	0	42.6	38.7	79.1	134	123	0	35	33
2014	9	5	7	40	41	0.804	-0.062	3.743	0.013	0.01	0	42.6	38.7	78.3	135	123	0	36	33
2014	9	5	7	50	41	0.81	-0.075	3.743	0.01	0.007	0	43	39.1	78.3	135	124	0	35	33
2014	9	5	8	0	41	0.791	-0.115	3.743	0.01	0.007	0	42.6	39.1	77.8	134	124	0	35	33
2014	9	5	8	10	41	0.807	-0.072	3.743	0.01	0.007	0	43	38.7	78.3	135	124	0	35	34
2014	9	5	8	20	41	0.768	-0.085	3.743	0.01	0.007	0	42.6	39.1	77.4	135	124	0	36	33
2014	9	5	8	30	41	0.794	-0.085	3.743	0.013	0.01	0	42.6	38.7	78.7	134	123	0	35	33
2014	9	5	8	40	41	0.778	-0.108	3.743	0.016	0.013	0	43	39.6	78.3	135	124	0	35	32
2014	9	5	8	50	41	0.801	-0.082	3.743	0.01	0.007	0	43	39.1	78.3	135	123	0	35	32
2014	9	5	9	0	41	0.781	-0.092	3.743	0.013	0.01	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	5	9	10	41	0.817	-0.085	3.743	0.01	0.007	0	42.6	38.7	78.3	134	123	0	35	33
2014	9	5	9	20	41	0.827	-0.121	3.743	0.01	0.007	0	42.1	38.7	77.4	133	123	0	35	33
2014	9	5	9	30	41	0.784	-0.098	3.743	0.013	0.01	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	5	9	40	41	0.794	-0.095	3.743	0.013	0.01	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	5	9	50	41	0.751	-0.079	3.743	0.01	0.007	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	5	10	0	41	0.755	-0.062	3.743	0.013	0.01	0	42.6	38.7	78.3	134	123	0	35	33
2014	9	5	10	10	41	0.751	-0.079	3.743	0.01	0.007	0	42.6	38.7	78.7	134	123	0	35	33
2014	9	5	10	20	41	0.771	-0.102	3.743	0.01	0.007	0	43	39.6	78.7	135	124	0	35	32
2014	9	5	10	30	41	0.768	-0.112	3.743	0.013	0.01	0	42.6	38.7	78.3	134	124	0	35	34
2014	9	5	10	40	41	0.784	-0.108	3.743	0.016	0.013	0	43	40	71.8	135	125	0	35	32
2014	9	5	10	50	41	0.801	-0.125	3.747	0.013	0.01	0	43	39.6	78.3	135	125	0	35	33
2014	9	5	11	0	41	0.797	-0.075	3.743	0.013	0.01	0	43	39.6	64.1	135	125	0	35	33
2014	9	5	11	10	41	0.758	-0.062	3.743	0.01	0.007	0	43	39.1	64.1	135	124	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	11	20	41	0.745	-0.095	3.743	0.01	0.007	0	43	40	65.4	135	125	0	35	32
2014	9	5	11	30	41	0.771	-0.105	3.743	0.013	0.01	0	43.4	39.6	68.8	136	125	0	35	33
2014	9	5	11	40	41	0.768	-0.092	3.743	0.01	0.007	0	42.1	39.6	65.4	134	124	0	36	32
2014	9	5	11	50	41	0.764	-0.095	3.743	0.013	0.01	0	42.6	39.1	67.1	134	124	0	35	33
2014	9	5	12	0	41	0.745	-0.108	3.743	0.01	0.007	0	42.6	38.7	68.8	134	123	0	35	33
2014	9	5	12	10	41	0.764	-0.079	3.743	0.013	0.01	0	43	39.1	59.8	135	124	0	35	33
2014	9	5	12	20	41	0.755	-0.108	3.743	0.01	0.007	0	43.4	39.6	63.2	135	125	0	34	33
2014	9	5	12	30	41	0.748	-0.066	3.743	0.013	0.01	0	43.4	39.6	55.5	136	125	0	35	33
2014	9	5	12	40	41	0.745	-0.085	3.74	0.01	0.007	0	43	39.6	58	135	125	0	35	33
2014	9	5	12	50	41	0.758	-0.125	3.74	0.01	0.007	0	43	40	59.3	135	125	0	35	32
2014	9	5	13	0	41	0.784	-0.075	3.74	0.013	0.01	0	43	40	62.8	135	125	0	35	32
2014	9	5	13	10	41	0.741	-0.112	3.737	0.01	0.007	0	43.9	40	52.9	137	126	0	35	33
2014	9	5	13	20	41	0.771	-0.079	3.74	0.01	0.007	0	43.9	40	52.9	137	126	0	35	33
2014	9	5	13	30	41	0.768	-0.075	3.74	0.01	0.007	0	43.4	40.9	55	137	127	0	36	32
2014	9	5	13	40	41	0.771	-0.023	3.74	0.013	0.01	0	43.9	40	55	137	126	0	35	33
2014	9	5	13	50	41	0.774	-0.112	3.74	0.016	0.013	0	44.3	41.3	61.9	138	128	0	35	32
2014	9	5	14	0	41	0.751	-0.118	3.737	0.016	0.016	0	43.9	40.9	58	137	127	0	35	32
2014	9	5	14	10	41	0.732	-0.115	3.734	0.013	0.01	0	43.4	40	55.5	136	126	0	35	33
2014	9	5	14	20	41	0.751	-0.125	3.734	0.01	0.007	0	43.9	40.4	54.6	136	126	0	34	32
2014	9	5	14	30	41	0.761	-0.066	3.737	0.016	0.013	0	43.4	39.6	59.8	136	125	0	35	33
2014	9	5	14	40	41	0.764	-0.089	3.734	0.016	0.013	0	43.4	40	53.8	136	126	0	35	33
2014	9	5	14	50	41	0.705	-0.079	3.734	0.013	0.01	0	43.4	39.6	57.6	136	125	0	35	33
2014	9	5	15	0	41	0.791	-0.102	3.73	0.013	0.01	0	43.4	40	52.9	136	126	0	35	33
2014	9	5	15	10	41	0.758	-0.059	3.727	0.016	0.013	0	43.4	40	52	136	126	0	35	33
2014	9	5	15	20	41	0.801	-0.112	3.73	0.013	0.01	0	43.4	40	56.8	136	126	0	35	33
2014	9	5	15	30	41	0.748	-0.095	3.727	0.013	0.01	0	43.4	40.4	58.9	136	126	0	35	32
2014	9	5	15	40	41	0.784	-0.102	3.727	0.013	0.01	0	43.9	40	55.5	137	126	0	35	33
2014	9	5	15	50	41	0.794	-0.085	3.727	0.016	0.013	0	43.9	40	52.5	137	126	0	35	33
2014	9	5	16	0	41	0.748	-0.069	3.727	0.016	0.013	0	43.9	40.4	53.3	137	126	0	35	32
2014	9	5	16	10	41	0.778	-0.112	3.724	0.01	0.007	0	43.9	40.9	52	137	127	0	35	32
2014	9	5	16	20	41	0.761	-0.056	3.724	0.013	0.01	0	43.4	40.4	54.2	136	126	0	35	32
2014	9	5	16	30	41	0.778	-0.098	3.72	0.016	0.013	0	43.9	40.4	56.3	137	126	0	35	32
2014	9	5	16	40	41	0.778	-0.095	3.724	0.013	0.01	0	43.4	40	51.2	136	125	0	35	32
2014	9	5	16	50	41	0.778	-0.089	3.724	0.016	0.013	0	43	40	52.9	135	125	0	35	32
2014	9	5	17	0	41	0.778	-0.108	3.72	0.013	0.01	0	43.4	40	54.2	136	125	0	35	32
2014	9	5	17	10	41	0.778	-0.062	3.72	0.01	0.007	0	43.4	40	54.2	136	125	0	35	32
2014	9	5	17	20	41	0.807	-0.112	3.72	0.013	0.01	0	43.9	40	52	136	125	0	34	32
2014	9	5	17	30	41	0.768	-0.151	3.72	0.013	0.01	0	43.9	39.6	58.5	136	125	0	34	33
2014	9	5	17	40	41	0.781	-0.098	3.72	0.013	0.01	0	43.9	40	64.9	136	125	0	34	32
2014	9	5	17	50	41	0.778	-0.105	3.72	0.01	0.007	0	43.4	40	60.2	136	125	0	35	32
2014	9	5	18	0	41	0.774	-0.062	3.72	0.016	0.013	0	43.9	40	66.2	136	125	0	34	32
2014	9	5	18	10	41	0.807	-0.092	3.72	0.013	0.01	0	43.4	40	71.8	136	125	0	35	32
2014	9	5	18	20	41	0.768	-0.059	3.72	0.013	0.01	0	43.9	40.9	74	137	127	0	35	32
2014	9	5	18	30	41	0.761	-0.095	3.724	0.01	0.007	0	43.4	39.6	76.5	136	125	0	35	33
2014	9	5	18	40	41	0.784	-0.108	3.724	0.01	0.007	0	43.4	39.6	77	136	125	0	35	33
2014	9	5	18	50	41	0.741	-0.092	3.724	0.01	0.007	0	43.4	40.4	77	136	126	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	5	19	0	41	0.791	-0.075	3.724	0.01	0.007	0	43.9	40.4	77	137	126	0	35	32
2014	9	5	19	10	41	0.801	-0.062	3.724	0.013	0.01	0	43.4	40	76.5	136	126	0	35	33
2014	9	5	19	20	41	0.761	-0.082	3.724	0.01	0.007	0	43.9	40.4	75.7	137	127	0	35	33
2014	9	5	19	30	41	0.764	-0.079	3.72	0.016	0.013	0	44.3	40.4	72.2	138	127	0	35	33
2014	9	5	19	40	41	0.784	-0.108	3.72	0.013	0.01	0	44.7	40.9	72.7	139	128	0	35	33
2014	9	5	19	50	41	0.768	-0.075	3.724	0.016	0.013	0	44.7	41.3	72.7	139	129	0	35	33
2014	9	5	20	0	41	0.761	-0.082	3.724	0.013	0.01	0	44.7	41.3	74.4	139	129	0	35	33
2014	9	5	20	10	41	0.804	-0.072	3.724	0.01	0.007	0	44.3	40.9	75.3	138	128	0	35	33
2014	9	5	20	20	41	0.781	-0.082	3.724	0.01	0.007	0	45.2	40.9	67.5	140	128	0	35	33
2014	9	5	20	30	41	0.778	-0.092	3.724	0.01	0.007	0	45.6	40.9	74.8	140	128	0	34	33
2014	9	5	20	40	41	0.794	-0.085	3.724	0.016	0.013	0	45.2	41.3	75.3	140	128	0	35	32
2014	9	5	20	50	41	0.778	-0.098	3.724	0.016	0.013	0	45.2	41.3	74.8	140	128	0	35	32
2014	9	5	21	0	41	0.804	-0.066	3.727	0.01	0.007	0	45.2	41.7	74.4	140	129	0	35	32
2014	9	5	21	10	41	0.768	-0.062	3.724	0.016	0.016	0	45.2	40.9	61.5	140	128	0	35	33
2014	9	5	21	20	41	0.807	-0.112	3.724	0.01	0.007	0	45.2	40.9	55.5	140	128	0	35	33
2014	9	5	21	30	41	0.768	-0.112	3.727	0.01	0.007	0	45.2	40.9	73.5	140	128	0	35	33
2014	9	5	21	40	41	0.804	-0.108	3.727	0.013	0.01	0	45.2	40.9	65.4	140	128	0	35	33
2014	9	5	21	50	41	0.751	-0.066	3.727	0.013	0.01	0	45.6	41.3	65.8	141	129	0	35	33
2014	9	5	22	0	41	0.764	-0.089	3.727	0.013	0.01	0	45.2	41.7	64.9	140	129	0	35	32
2014	9	5	22	10	41	0.774	-0.075	3.73	0.016	0.013	0	45.2	41.3	67.5	140	128	0	35	32
2014	9	5	22	20	41	0.797	-0.105	3.73	0.01	0.007	0	45.2	41.3	63.6	140	128	0	35	32
2014	9	5	22	30	41	0.755	-0.108	3.73	0.016	0.013	0	45.6	41.7	58.9	140	129	0	34	32
2014	9	5	22	40	41	0.787	-0.082	3.73	0.013	0.01	0	45.2	40.9	57.6	140	128	0	35	33
2014	9	5	22	50	41	0.761	-0.108	3.737	0.016	0.013	0	45.2	41.3	75.7	140	128	0	35	32
2014	9	5	23	0	41	0.751	-0.092	3.737	0.013	0.01	0	44.7	41.3	77	139	128	0	35	32
2014	9	5	23	10	41	0.778	-0.069	3.737	0.016	0.013	0	45.2	40.9	71.8	140	128	0	35	33
2014	9	5	23	20	41	0.807	-0.059	3.737	0.013	0.01	0	45.2	40.9	77	140	128	0	35	33
2014	9	5	23	30	41	0.778	-0.072	3.737	0.01	0.007	0	45.2	41.3	77.4	140	129	0	35	33
2014	9	5	23	40	41	0.791	-0.062	3.737	0.016	0.016	0	45.2	41.3	77.4	140	129	0	35	33
2014	9	5	23	50	41	0.774	-0.079	3.74	0.01	0.007	0	45.2	41.3	78.3	140	129	0	35	33
2014	9	6	0	0	41	0.804	-0.138	3.737	0.016	0.016	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	6	0	10	41	0.781	-0.089	3.74	0.013	0.01	0	44.3	40.4	77.4	138	127	0	35	33
2014	9	6	0	20	41	0.807	-0.095	3.74	0.013	0.01	0	44.3	40.9	77.4	138	127	0	35	32
2014	9	6	0	30	41	0.791	-0.092	3.74	0.013	0.01	0	44.7	40.9	77.8	139	128	0	35	33
2014	9	6	0	40	41	0.781	-0.079	3.74	0.01	0.007	0	44.7	40.9	79.1	139	128	0	35	33
2014	9	6	0	50	41	0.751	-0.085	3.74	0.01	0.007	0	44.7	40.9	78.7	139	128	0	35	33
2014	9	6	1	0	41	0.791	-0.092	3.74	0.016	0.013	0	44.7	40.9	79.1	139	128	0	35	33
2014	9	6	1	10	41	0.758	-0.072	3.74	0.013	0.01	0	45.2	41.3	78.7	140	128	0	35	32
2014	9	6	1	20	41	0.778	-0.095	3.74	0.01	0.007	0	45.2	40.9	79.1	140	128	0	35	33
2014	9	6	1	30	41	0.804	-0.098	3.74	0.013	0.01	0	44.7	40.9	77.8	139	128	0	35	33
2014	9	6	1	40	41	0.82	-0.066	3.743	0.013	0.01	0	45.2	41.3	79.1	140	128	0	35	32
2014	9	6	1	50	41	0.771	-0.095	3.74	0.013	0.01	0	45.2	41.3	79.6	140	128	0	35	32
2014	9	6	2	0	41	0.797	-0.092	3.743	0.013	0.01	0	44.3	40.4	78.7	138	127	0	35	33
2014	9	6	2	10	41	0.81	-0.095	3.743	0.01	0.007	0	44.7	41.3	79.1	139	128	0	35	32
2014	9	6	2	20	41	0.797	-0.059	3.743	0.016	0.013	0	44.7	40.9	78.7	139	128	0	35	33
2014	9	6	2	30	41	0.797	-0.072	3.743	0.016	0.013	0	44.7	40.4	78.7	139	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	2	40	41	0.801	-0.079	3.743	0.013	0.01	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	6	2	50	41	0.82	-0.085	3.743	0.01	0.007	0	44.3	40.4	79.6	138	127	0	35	33
2014	9	6	3	0	41	0.797	-0.075	3.743	0.016	0.016	0	44.7	40.9	79.6	139	127	0	35	32
2014	9	6	3	10	41	0.768	-0.102	3.743	0.013	0.01	0	44.3	40.4	78.7	138	127	0	35	33
2014	9	6	3	20	41	0.781	-0.095	3.743	0.013	0.01	0	44.3	40.4	78.7	138	127	0	35	33
2014	9	6	3	30	41	0.801	-0.046	3.743	0.01	0.007	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	6	3	40	41	0.833	-0.075	3.743	0.01	0.007	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	6	3	50	41	0.768	-0.098	3.743	0.013	0.01	0	44.3	40.9	78.7	138	127	0	35	32
2014	9	6	4	0	41	0.787	-0.069	3.743	0.01	0.007	0	44.3	40.4	78.7	138	126	0	35	32
2014	9	6	4	10	41	0.778	-0.102	3.743	0.01	0.007	0	43.9	40	78.3	137	126	0	35	33
2014	9	6	4	20	41	0.758	-0.072	3.743	0.01	0.007	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	6	4	30	41	0.801	-0.059	3.743	0.013	0.01	0	44.3	40.9	78.3	139	128	0	36	33
2014	9	6	4	40	41	0.787	-0.075	3.743	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	6	4	50	41	0.781	-0.092	3.743	0.01	0.007	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	6	5	0	41	0.81	-0.135	3.743	0.016	0.013	0	44.7	41.3	77.8	139	128	0	35	32
2014	9	6	5	10	41	0.758	-0.082	3.743	0.01	0.007	0	43.9	40.9	78.3	138	127	0	36	32
2014	9	6	5	20	41	0.797	-0.125	3.743	0.013	0.01	0	44.3	40	77.4	138	126	0	35	33
2014	9	6	5	30	41	0.778	-0.062	3.743	0.016	0.013	0	44.7	40	78.3	138	126	0	34	33
2014	9	6	5	40	41	0.771	-0.069	3.743	0.01	0.007	0	43.9	40	76.5	138	126	0	36	33
2014	9	6	5	50	41	0.791	-0.138	3.743	0.01	0.007	0	44.3	40	77.4	138	126	0	35	33
2014	9	6	6	0	41	0.817	-0.105	3.743	0.01	0.007	0	43.9	40.9	77.8	138	127	0	36	32
2014	9	6	6	10	41	0.781	-0.082	3.743	0.016	0.013	0	44.7	40.9	77.4	139	128	0	35	33
2014	9	6	6	20	41	0.755	-0.092	3.743	0.01	0.007	0	44.3	40.4	77.4	139	127	0	36	33
2014	9	6	6	30	41	0.823	-0.108	3.743	0.013	0.01	0	44.3	40.4	77	138	127	0	35	33
2014	9	6	6	40	41	0.804	-0.062	3.743	0.01	0.007	0	44.3	40	77	138	126	0	35	33
2014	9	6	6	50	41	0.823	-0.108	3.743	0.01	0.007	0	43.9	40.4	76.5	137	126	0	35	32
2014	9	6	7	0	41	0.774	-0.072	3.747	0.01	0.007	0	43.4	40	76.5	136	125	0	35	32
2014	9	6	7	10	41	0.784	-0.072	3.747	0.01	0.007	0	43.4	39.1	75.7	136	124	0	35	33
2014	9	6	7	20	41	0.778	-0.085	3.747	0.016	0.016	0	42.6	38.7	76.1	135	123	0	36	33
2014	9	6	7	30	41	0.781	-0.089	3.747	0.01	0.007	0	42.6	39.1	76.5	134	123	0	35	32
2014	9	6	7	40	41	0.768	-0.082	3.747	0.013	0.01	0	42.6	38.7	76.1	134	123	0	35	33
2014	9	6	7	50	41	0.764	-0.092	3.747	0.016	0.013	0	42.6	38.7	76.1	134	123	0	35	33
2014	9	6	8	0	41	0.794	-0.098	3.747	0.01	0.007	0	42.6	38.7	76.1	134	123	0	35	33
2014	9	6	8	10	41	0.755	-0.095	3.747	0.01	0.007	0	42.1	38.3	76.1	134	122	0	36	33
2014	9	6	8	20	41	0.817	-0.089	3.747	0.01	0.007	0	42.1	38.3	76.1	134	122	0	36	33
2014	9	6	8	30	41	0.787	-0.075	3.75	0.016	0.013	0	42.6	38.7	76.5	134	123	0	35	33
2014	9	6	8	40	41	0.794	-0.085	3.75	0.013	0.01	0	42.6	38.3	77	134	122	0	35	33
2014	9	6	8	50	41	0.781	-0.085	3.75	0.01	0.007	0	42.6	38.7	76.5	134	123	0	35	33
2014	9	6	9	0	41	0.781	-0.089	3.75	0.013	0.01	0	42.6	38.3	77	134	122	0	35	33
2014	9	6	9	10	41	0.771	-0.062	3.75	0.016	0.013	0	41.7	38.3	76.1	133	122	0	36	33
2014	9	6	9	20	41	0.774	-0.138	3.747	0.01	0.007	0	41.7	38.3	76.1	133	122	0	36	33
2014	9	6	9	30	41	0.804	-0.059	3.75	0.013	0.01	0	43	38.7	77.4	135	123	0	35	33
2014	9	6	9	40	41	0.781	-0.075	3.75	0.01	0.007	0	42.6	38.7	77.4	134	123	0	35	33
2014	9	6	9	50	41	0.804	-0.118	3.75	0.013	0.01	0	42.6	38.7	77	134	123	0	35	33
2014	9	6	10	0	41	0.797	-0.075	3.75	0.01	0.007	0	43	39.1	77	135	124	0	35	33
2014	9	6	10	10	41	0.774	-0.092	3.75	0.01	0.007	0	43	39.1	77.4	135	124	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	10	20	41	0.784	-0.059	3.75	0.016	0.016	0	42.6	38.7	77.4	134	123	0	35	33
2014	9	6	10	30	41	0.784	-0.089	3.75	0.013	0.01	0	42.6	38.3	77	134	122	0	35	33
2014	9	6	10	40	41	0.778	-0.075	3.75	0.01	0.007	0	43	38.7	77	135	123	0	35	33
2014	9	6	10	50	41	0.814	-0.105	3.747	0.01	0.007	0	42.6	38.7	78.3	134	123	0	35	33
2014	9	6	11	0	41	0.761	-0.108	3.75	0.01	0.007	0	42.6	38.7	76.5	134	123	0	35	33
2014	9	6	11	10	41	0.791	-0.098	3.747	0.01	0.007	0	42.6	38.7	63.2	134	123	0	35	33
2014	9	6	11	20	41	0.791	-0.082	3.747	0.013	0.01	0	43	39.1	55	135	124	0	35	33
2014	9	6	11	30	41	0.751	-0.095	3.747	0.013	0.01	0	43	38.7	59.3	135	123	0	35	33
2014	9	6	11	40	41	0.771	-0.095	3.747	0.013	0.01	0	42.6	38.7	59.8	134	123	0	35	33
2014	9	6	11	50	41	0.751	-0.095	3.747	0.01	0.007	0	43.4	39.1	55	136	124	0	35	33
2014	9	6	12	0	41	0.751	-0.105	3.747	0.016	0.013	0	43.4	40	62.8	136	125	0	35	32
2014	9	6	12	10	41	0.774	-0.095	3.747	0.01	0.007	0	43.9	39.6	55.5	137	125	0	35	33
2014	9	6	12	20	41	0.725	-0.089	3.743	0.01	0.007	0	43	39.1	56.8	135	124	0	35	33
2014	9	6	12	30	41	0.758	-0.079	3.743	0.013	0.01	0	43.4	40.4	58	136	126	0	35	32
2014	9	6	12	40	41	0.758	-0.082	3.743	0.016	0.013	0	43.9	40	54.2	137	126	0	35	33
2014	9	6	12	50	41	0.758	-0.098	3.743	0.013	0.01	0	44.3	40.4	54.6	138	127	0	35	33
2014	9	6	13	0	41	0.781	-0.105	3.743	0.013	0.01	0	43.9	40.4	55	138	127	0	36	33
2014	9	6	13	10	41	0.725	-0.075	3.743	0.013	0.01	0	43.9	40	57.6	137	126	0	35	33
2014	9	6	13	20	41	0.771	-0.092	3.743	0.016	0.013	0	43.9	39.6	55.5	137	125	0	35	33
2014	9	6	13	30	41	0.787	-0.108	3.743	0.016	0.013	0	43.9	40	51.2	137	126	0	35	33
2014	9	6	13	40	41	0.758	-0.075	3.74	0.013	0.01	0	43.9	40.9	55	137	127	0	35	32
2014	9	6	13	50	41	0.755	-0.062	3.74	0.01	0.007	0	44.3	40	53.3	138	126	0	35	33
2014	9	6	14	0	41	0.719	-0.102	3.74	0.01	0.007	0	44.3	40.4	54.2	138	127	0	35	33
2014	9	6	14	10	41	0.755	-0.089	3.74	0.01	0.007	0	44.3	39.6	52.5	138	126	0	35	34
2014	9	6	14	20	41	0.751	-0.095	3.74	0.01	0.007	0	44.3	40	54.6	138	126	0	35	33
2014	9	6	14	30	41	0.774	-0.115	3.74	0.01	0.007	0	43.9	40	58.5	137	125	0	35	32
2014	9	6	14	40	41	0.797	-0.079	3.74	0.013	0.01	0	43.9	39.6	54.2	137	125	0	35	33
2014	9	6	14	50	41	0.761	-0.092	3.737	0.013	0.01	0	44.3	40.4	54.2	138	127	0	35	33
2014	9	6	15	0	41	0.673	-0.062	3.737	0.016	0.013	0	43.9	40	53.3	137	126	0	35	33
2014	9	6	15	10	41	0.755	-0.062	3.737	0.013	0.01	0	43.9	40.4	52.5	137	126	0	35	32
2014	9	6	15	20	41	0.784	-0.062	3.737	0.01	0.007	0	43.9	40	52.5	137	126	0	35	33
2014	9	6	15	30	41	0.735	-0.102	3.737	0.016	0.016	0	43.9	40	53.3	137	126	0	35	33
2014	9	6	15	40	41	0.741	-0.075	3.734	0.01	0.007	0	43.9	40	53.3	137	126	0	35	33
2014	9	6	15	50	41	0.791	-0.079	3.734	0.01	0.007	0	43.4	40	52.9	136	126	0	35	33
2014	9	6	16	0	41	0.764	-0.056	3.73	0.013	0.01	0	43.9	40.9	58.9	137	127	0	35	32
2014	9	6	16	10	41	0.774	-0.105	3.734	0.01	0.007	0	43.4	39.1	52	136	124	0	35	33
2014	9	6	16	20	41	0.787	-0.059	3.734	0.01	0.007	0	43.9	40.4	54.6	137	126	0	35	32
2014	9	6	16	30	41	0.764	-0.089	3.73	0.013	0.01	0	43.9	40	54.2	136	126	0	34	33
2014	9	6	16	40	41	0.755	-0.066	3.73	0.013	0.01	0	44.7	40.9	52.9	139	128	0	35	33
2014	9	6	16	50	41	0.764	-0.098	3.734	0.01	0.007	0	44.3	40.9	58	138	127	0	35	32
2014	9	6	17	0	41	0.761	-0.089	3.73	0.016	0.013	0	44.3	40.4	52.9	138	127	0	35	33
2014	9	6	17	10	41	0.794	-0.095	3.73	0.016	0.013	0	43.4	39.6	50.7	135	125	0	34	33
2014	9	6	17	20	41	0.764	-0.082	3.73	0.01	0.007	0	46	41.7	58.9	141	130	0	34	33
2014	9	6	17	30	41	0.761	-0.069	3.73	0.01	0.007	0	43	39.1	55.5	135	124	0	35	33
2014	9	6	17	40	41	0.771	-0.066	3.73	0.01	0.007	0	43	39.1	55.5	135	124	0	35	33
2014	9	6	17	50	41	0.748	-0.098	3.73	0.013	0.01	0	43	39.1	51.6	135	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	6	18	0	41	0.748	-0.115	3.727	0.01	0.007	0	42.6	38.7	53.8	134	123	0	35	33
2014	9	6	18	10	41	0.784	-0.092	3.73	0.013	0.01	0	42.6	38.7	57.2	134	122	0	35	32
2014	9	6	18	20	41	0.751	-0.085	3.73	0.013	0.01	0	42.6	38.7	64.5	134	123	0	35	33
2014	9	6	18	30	41	0.784	-0.092	3.734	0.013	0.01	0	42.6	38.7	73.1	134	123	0	35	33
2014	9	6	18	40	41	0.768	-0.095	3.73	0.013	0.01	0	43	39.1	58.9	135	124	0	35	33
2014	9	6	18	50	41	0.761	-0.079	3.73	0.016	0.013	0	43	39.6	54.2	135	124	0	35	32
2014	9	6	19	0	41	0.738	-0.098	3.73	0.01	0.007	0	43	39.1	51.2	135	124	0	35	33
2014	9	6	19	10	41	0.751	-0.085	3.73	0.013	0.01	0	43.4	39.6	57.2	136	124	0	35	32
2014	9	6	19	20	41	0.745	-0.089	3.727	0.016	0.013	0	43	39.6	55	135	125	0	35	33
2014	9	6	19	30	41	0.774	-0.105	3.73	0.013	0.01	0	43.9	40	54.2	136	125	0	34	32
2014	9	6	19	40	41	0.732	-0.085	3.73	0.016	0.013	0	43.9	40.4	54.2	137	127	0	35	33
2014	9	6	19	50	41	0.774	-0.095	3.73	0.013	0.01	0	44.7	41.3	56.3	139	128	0	35	32
2014	9	6	20	0	41	0.761	-0.079	3.73	0.016	0.013	0	44.7	41.3	52	139	129	0	35	33
2014	9	6	20	10	41	0.771	-0.072	3.734	0.016	0.013	0	45.2	42.1	53.8	140	130	0	35	32
2014	9	6	20	20	41	0.745	-0.112	3.734	0.013	0.01	0	45.2	41.7	54.2	140	129	0	35	32
2014	9	6	20	30	41	0.735	-0.092	3.73	0.01	0.007	0	45.2	41.7	50.3	140	130	0	35	33
2014	9	6	20	40	41	0.764	-0.072	3.734	0.01	0.007	0	45.2	41.7	54.6	140	129	0	35	32
2014	9	6	20	50	41	0.781	-0.072	3.737	0.01	0.007	0	44.7	41.7	60.2	139	129	0	35	32
2014	9	6	21	0	41	0.778	-0.108	3.74	0.013	0.01	0	44.7	40.9	77.4	139	128	0	35	33
2014	9	6	21	10	41	0.81	-0.069	3.74	0.016	0.013	0	44.7	41.7	74.8	139	129	0	35	32
2014	9	6	21	20	41	0.801	-0.095	3.74	0.013	0.01	0	44.3	40.9	77.4	138	128	0	35	33
2014	9	6	21	30	41	0.784	-0.052	3.74	0.01	0.007	0	44.3	41.3	78.3	138	128	0	35	32
2014	9	6	21	40	41	0.804	-0.089	3.74	0.01	0.007	0	44.3	40.4	72.2	138	127	0	35	33
2014	9	6	21	50	41	0.801	-0.062	3.74	0.01	0.007	0	44.3	40.9	77.4	138	128	0	35	33
2014	9	6	22	0	41	0.758	-0.062	3.74	0.01	0.007	0	44.3	40.9	76.1	138	128	0	35	33
2014	9	6	22	10	41	0.778	-0.079	3.74	0.013	0.01	0	45.2	40.9	71.8	139	128	0	34	33
2014	9	6	22	20	41	0.817	-0.128	3.74	0.016	0.013	0	44.3	41.3	61.5	138	128	0	35	32
2014	9	6	22	30	41	0.741	-0.102	3.74	0.013	0.01	0	44.7	41.3	62.4	139	129	0	35	33
2014	9	6	22	40	41	0.761	-0.072	3.74	0.013	0.01	0	44.3	40.9	55.9	138	128	0	35	33
2014	9	6	22	50	41	0.735	-0.085	3.74	0.013	0.01	0	44.7	41.3	60.2	139	128	0	35	32
2014	9	6	23	0	41	0.787	-0.121	3.743	0.01	0.007	0	44.3	40	78.3	138	127	0	35	34
2014	9	6	23	10	41	0.761	-0.092	3.743	0.013	0.01	0	43.9	41.3	76.5	138	129	0	36	33
2014	9	6	23	20	41	0.761	-0.105	3.743	0.013	0.01	0	43.9	40.4	71.8	137	127	0	35	33
2014	9	6	23	30	41	0.764	-0.039	3.743	0.013	0.01	0	44.3	41.3	73.5	138	128	0	35	32
2014	9	6	23	40	41	0.771	-0.082	3.743	0.013	0.01	0	43.9	40.4	71.8	137	127	0	35	33
2014	9	6	23	50	41	0.781	-0.066	3.743	0.02	0.016	0	44.3	40.9	76.1	138	128	0	35	33
2014	9	7	0	0	41	0.774	-0.079	3.743	0.01	0.007	0	44.3	40.9	78.7	138	128	0	35	33
2014	9	7	0	10	41	0.823	-0.089	3.743	0.01	0.007	0	43.9	40.4	75.7	137	127	0	35	33
2014	9	7	0	20	41	0.761	-0.082	3.747	0.016	0.013	0	43.9	40.4	77.4	137	127	0	35	33
2014	9	7	0	30	41	0.751	-0.118	3.747	0.016	0.013	0	43.9	40.4	80.4	137	127	0	35	33
2014	9	7	0	40	41	0.761	-0.069	3.743	0.01	0.007	0	43.9	40.4	76.5	137	127	0	35	33
2014	9	7	0	50	41	0.781	-0.079	3.743	0.016	0.013	0	43.9	40.4	78.3	137	127	0	35	33
2014	9	7	1	0	41	0.771	-0.082	3.747	0.013	0.01	0	43.9	40.4	80.8	137	127	0	35	33
2014	9	7	1	10	41	0.807	-0.059	3.747	0.013	0.01	0	43.9	40.9	80.4	137	128	0	35	33
2014	9	7	1	20	41	0.801	-0.102	3.747	0.01	0.007	0	43.9	41.3	79.6	137	128	0	35	32
2014	9	7	1	30	41	0.804	-0.092	3.747	0.013	0.01	0	43.9	40.4	80	137	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	1	40	41	0.823	-0.102	3.747	0.016	0.013	0	43.9	40.4	80	137	127	0	35	33
2014	9	7	1	50	41	0.774	-0.092	3.747	0.013	0.01	0	44.3	41.3	79.1	138	128	0	35	32
2014	9	7	2	0	41	0.791	-0.059	3.747	0.01	0.007	0	43.9	40.4	78.7	137	127	0	35	33
2014	9	7	2	10	41	0.804	-0.082	3.747	0.013	0.01	0	43.9	40.4	79.1	137	127	0	35	33
2014	9	7	2	20	41	0.722	-0.082	3.747	0.01	0.007	0	43.9	40.4	78.3	137	127	0	35	33
2014	9	7	2	30	41	0.745	-0.092	3.747	0.013	0.01	0	43.9	40.4	79.1	137	127	0	35	33
2014	9	7	2	40	41	0.804	-0.079	3.747	0.01	0.007	0	43.9	40.4	78.7	137	127	0	35	33
2014	9	7	2	50	41	0.801	-0.079	3.747	0.016	0.013	0	43.9	40.9	78.3	137	127	0	35	32
2014	9	7	3	0	41	0.774	-0.069	3.747	0.01	0.007	0	43.9	40.9	78.7	137	128	0	35	33
2014	9	7	3	10	41	0.778	-0.092	3.747	0.013	0.01	0	43.9	40.4	78.3	137	127	0	35	33
2014	9	7	3	20	41	0.81	-0.092	3.747	0.01	0.007	0	43.4	40.4	77.8	136	127	0	35	33
2014	9	7	3	30	41	0.751	-0.085	3.747	0.01	0.007	0	43.9	40.9	77.8	137	127	0	35	32
2014	9	7	3	40	41	0.745	-0.079	3.75	0.01	0.007	0	43.9	40.9	77	137	128	0	35	33
2014	9	7	3	50	41	0.771	-0.098	3.75	0.01	0.007	0	43.4	40.9	77.8	136	127	0	35	32
2014	9	7	4	0	41	0.758	-0.056	3.75	0.016	0.016	0	43.4	40.4	77.8	136	127	0	35	33
2014	9	7	4	10	41	0.735	-0.102	3.75	0.013	0.01	0	43.4	40	77.4	136	126	0	35	33
2014	9	7	4	20	41	0.774	-0.082	3.75	0.013	0.01	0	43	40	77.4	135	126	0	35	33
2014	9	7	4	30	41	0.804	-0.056	3.75	0.01	0.007	0	43.4	40.4	77.4	136	126	0	35	32
2014	9	7	4	40	41	0.807	-0.075	3.75	0.01	0.007	0	43	40	77.4	135	126	0	35	33
2014	9	7	4	50	41	0.787	-0.108	3.75	0.013	0.01	0	43.4	40.4	77.8	136	126	0	35	32
2014	9	7	5	0	41	0.781	-0.105	3.75	0.01	0.007	0	43.9	40.4	77.4	136	127	0	34	33
2014	9	7	5	10	41	0.82	-0.079	3.75	0.01	0.007	0	43.4	40	77.4	136	126	0	35	33
2014	9	7	5	20	41	0.781	-0.082	3.75	0.01	0.007	0	43.4	40.4	76.5	136	126	0	35	32
2014	9	7	5	30	41	0.784	-0.079	3.75	0.016	0.016	0	43.4	40	77	136	126	0	35	33
2014	9	7	5	40	41	0.784	-0.069	3.75	0.01	0.007	0	43.4	40.4	76.5	136	127	0	35	33
2014	9	7	5	50	41	0.778	-0.079	3.75	0.01	0.007	0	43.4	40.4	76.5	136	127	0	35	33
2014	9	7	6	0	41	0.807	-0.059	3.753	0.01	0.007	0	43.4	40.4	76.1	136	127	0	35	33
2014	9	7	6	10	41	0.781	-0.095	3.75	0.013	0.01	0	43.4	40	76.5	136	126	0	35	33
2014	9	7	6	20	41	0.784	-0.095	3.753	0.016	0.013	0	43	40	76.1	135	126	0	35	33
2014	9	7	6	30	41	0.784	-0.075	3.753	0.013	0.01	0	43	40	75.7	135	126	0	35	33
2014	9	7	6	40	41	0.771	-0.072	3.753	0.016	0.013	0	43	40	76.1	135	126	0	35	33
2014	9	7	6	50	41	0.768	-0.079	3.753	0.016	0.013	0	43	40	76.5	135	126	0	35	33
2014	9	7	7	0	41	0.764	-0.079	3.753	0.01	0.007	0	42.6	40	76.1	134	125	0	35	32
2014	9	7	7	10	41	0.804	-0.062	3.753	0.01	0.007	0	42.1	39.1	75.7	133	124	0	35	33
2014	9	7	7	20	41	0.81	-0.085	3.757	0.013	0.01	0	41.7	38.3	76.1	132	123	0	35	34
2014	9	7	7	30	41	0.801	-0.082	3.757	0.01	0.007	0	41.7	38.7	75.3	132	123	0	35	33
2014	9	7	7	40	41	0.801	-0.072	3.757	0.013	0.01	0	41.7	38.7	75.3	132	123	0	35	33
2014	9	7	7	50	41	0.778	-0.069	3.757	0.01	0.007	0	42.1	39.1	75.7	133	124	0	35	33
2014	9	7	8	0	41	0.827	-0.03	3.76	0.013	0.01	0	41.7	38.3	76.1	132	122	0	35	33
2014	9	7	8	10	41	0.804	-0.062	3.76	0.013	0.01	0	41.3	38.7	75.3	131	123	0	35	33
2014	9	7	8	20	41	0.781	-0.059	3.763	0.01	0.007	0	41.3	38.3	75.3	131	122	0	35	33
2014	9	7	8	30	41	0.781	-0.092	3.763	0.01	0.007	0	41.3	38.7	75.3	131	123	0	35	33
2014	9	7	8	40	41	0.817	-0.049	3.763	0.016	0.013	0	41.3	37.8	76.1	131	122	0	35	34
2014	9	7	8	50	41	0.791	-0.082	3.763	0.013	0.01	0	41.3	38.3	75.7	131	122	0	35	33
2014	9	7	9	0	41	0.781	-0.092	3.766	0.01	0.007	0	41.3	39.1	76.1	131	123	0	35	32
2014	9	7	9	10	41	0.81	-0.102	3.766	0.01	0.007	0	41.7	39.1	77	132	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	9	20	41	0.787	-0.085	3.766	0.01	0.007	0	41.3	39.1	77.4	131	123	0	35	32
2014	9	7	9	30	41	0.801	-0.075	3.766	0.01	0.007	0	41.3	39.1	77	131	123	0	35	32
2014	9	7	9	40	41	0.804	-0.075	3.766	0.013	0.01	0	41.3	38.3	77	131	122	0	35	33
2014	9	7	9	50	41	0.768	-0.082	3.766	0.013	0.01	0	41.3	38.7	78.3	131	123	0	35	33
2014	9	7	10	0	41	0.804	-0.079	3.77	0.013	0.01	0	41.3	38.7	77.8	131	122	0	35	32
2014	9	7	10	10	41	0.728	-0.095	3.77	0.016	0.013	0	41.3	39.1	78.3	131	123	0	35	32
2014	9	7	10	20	41	0.771	-0.125	3.77	0.01	0.007	0	41.3	38.3	78.3	131	122	0	35	33
2014	9	7	10	30	41	0.764	-0.095	3.766	0.01	0.007	0	41.3	39.1	76.1	131	123	0	35	32
2014	9	7	10	40	41	0.801	-0.092	3.766	0.016	0.013	0	41.7	38.7	75.3	132	123	0	35	33
2014	9	7	10	50	41	0.748	-0.098	3.766	0.01	0.007	0	41.3	38.3	74.8	131	122	0	35	33
2014	9	7	11	0	41	0.771	-0.089	3.766	0.016	0.013	0	41.3	38.7	74.4	131	122	0	35	32
2014	9	7	11	10	41	0.794	-0.095	3.766	0.01	0.007	0	41.7	39.1	77	132	123	0	35	32
2014	9	7	11	20	41	0.778	-0.075	3.766	0.01	0.007	0	41.3	38.7	75.7	131	123	0	35	33
2014	9	7	11	30	41	0.761	-0.112	3.763	0.01	0.007	0	41.7	39.1	75.7	132	124	0	35	33
2014	9	7	11	40	41	0.751	-0.085	3.76	0.013	0.01	0	42.1	39.1	71.4	133	124	0	35	33
2014	9	7	11	50	41	0.804	-0.082	3.76	0.013	0.01	0	41.7	39.1	53.3	132	124	0	35	33
2014	9	7	12	0	41	0.748	-0.105	3.757	0.01	0.007	0	42.1	39.6	56.3	133	125	0	35	33
2014	9	7	12	10	41	0.764	-0.089	3.757	0.013	0.01	0	42.6	40	58	134	125	0	35	32
2014	9	7	12	20	41	0.758	-0.108	3.757	0.01	0.007	0	42.6	40	51.6	134	126	0	35	33
2014	9	7	12	30	41	0.735	-0.092	3.757	0.013	0.01	0	42.6	39.6	51.6	134	125	0	35	33
2014	9	7	12	40	41	0.758	-0.079	3.757	0.01	0.007	0	43	39.6	50.7	134	125	0	34	33
2014	9	7	12	50	41	0.758	-0.079	3.757	0.013	0.01	0	42.6	39.6	52.9	134	126	0	35	34
2014	9	7	13	0	41	0.702	-0.092	3.753	0.01	0.007	0	42.1	39.6	53.3	133	125	0	35	33
2014	9	7	13	10	41	0.781	-0.089	3.753	0.01	0.007	0	43	40.4	54.2	135	126	0	35	32
2014	9	7	13	20	41	0.751	-0.085	3.753	0.016	0.013	0	42.1	39.6	53.8	133	125	0	35	33
2014	9	7	13	30	41	0.755	-0.098	3.753	0.016	0.013	0	42.6	40	51.2	134	126	0	35	33
2014	9	7	13	40	41	0.738	-0.079	3.753	0.013	0.01	0	42.6	40	50.3	134	126	0	35	33
2014	9	7	13	50	41	0.761	-0.069	3.753	0.01	0.007	0	43	39.6	55.5	134	125	0	34	33
2014	9	7	14	0	41	0.774	-0.079	3.753	0.01	0.007	0	42.1	39.6	55	133	125	0	35	33
2014	9	7	14	10	41	0.781	-0.098	3.753	0.01	0.007	0	42.1	39.6	59.3	133	124	0	35	32
2014	9	7	14	20	41	0.768	-0.075	3.753	0.01	0.007	0	42.1	40	53.3	133	125	0	35	32
2014	9	7	14	30	41	0.745	-0.108	3.753	0.01	0.007	0	42.1	39.6	54.2	133	125	0	35	33
2014	9	7	14	40	41	0.771	-0.098	3.753	0.016	0.013	0	41.7	39.6	55	132	124	0	35	32
2014	9	7	14	50	41	0.755	-0.079	3.753	0.01	0.007	0	41.7	39.1	53.8	132	123	0	35	32
2014	9	7	15	0	41	0.771	-0.105	3.753	0.013	0.01	0	41.7	40	54.2	132	125	0	35	32
2014	9	7	15	10	41	0.761	-0.062	3.753	0.01	0.007	0	41.7	39.6	56.8	132	124	0	35	32
2014	9	7	15	20	41	0.748	-0.095	3.75	0.013	0.01	0	41.7	39.6	55.5	132	124	0	35	32
2014	9	7	15	30	41	0.768	-0.092	3.75	0.016	0.013	0	41.7	38.7	53.8	132	123	0	35	33
2014	9	7	15	40	41	0.807	-0.069	3.75	0.016	0.013	0	42.1	39.6	54.6	133	124	0	35	32
2014	9	7	15	50	41	0.794	-0.092	3.75	0.013	0.01	0	41.7	38.7	61.1	132	123	0	35	33
2014	9	7	16	0	41	0.745	-0.095	3.75	0.013	0.01	0	41.3	38.3	54.6	131	122	0	35	33
2014	9	7	16	10	41	0.787	-0.105	3.75	0.013	0.01	0	42.6	39.6	57.2	134	124	0	35	32
2014	9	7	16	20	41	0.768	-0.075	3.75	0.01	0.007	0	42.1	38.7	56.8	133	122	0	35	32
2014	9	7	16	30	41	0.764	-0.108	3.75	0.01	0.007	0	42.1	38.3	60.6	133	122	0	35	33
2014	9	7	16	40	41	0.764	-0.102	3.75	0.01	0.007	0	42.6	38.7	58	134	123	0	35	33
2014	9	7	16	50	41	0.748	-0.092	3.75	0.013	0.01	0	42.6	39.1	66.2	134	124	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	7	17	0	41	0.761	-0.079	3.75	0.01	0.007	0	42.6	38.7	58	134	123	0	35	33
2014	9	7	17	10	41	0.81	-0.072	3.75	0.01	0.007	0	42.1	38.7	73.5	133	123	0	35	33
2014	9	7	17	20	41	0.791	-0.108	3.75	0.016	0.013	0	41.7	38.7	67.9	132	122	0	35	32
2014	9	7	17	30	41	0.778	-0.102	3.747	0.01	0.007	0	42.1	39.1	60.6	133	123	0	35	32
2014	9	7	17	40	41	0.764	-0.079	3.747	0.01	0.007	0	42.6	39.1	59.3	134	123	0	35	32
2014	9	7	17	50	41	0.751	-0.092	3.75	0.01	0.007	0	42.1	38.7	64.9	133	122	0	35	32
2014	9	7	18	0	41	0.764	-0.089	3.75	0.016	0.013	0	42.1	38.3	65.8	133	122	0	35	33
2014	9	7	18	10	41	0.741	-0.079	3.747	0.013	0.01	0	42.1	39.1	53.8	133	123	0	35	32
2014	9	7	18	20	41	0.787	-0.105	3.747	0.01	0.007	0	43	39.1	56.3	135	124	0	35	33
2014	9	7	18	30	41	0.741	-0.098	3.747	0.016	0.013	0	43	39.6	53.8	135	125	0	35	33
2014	9	7	18	40	41	0.797	-0.095	3.747	0.01	0.007	0	43	39.6	57.2	135	125	0	35	33
2014	9	7	18	50	41	0.764	-0.102	3.747	0.016	0.013	0	43	39.6	58.9	135	125	0	35	33
2014	9	7	19	0	41	0.784	-0.108	3.747	0.016	0.013	0	44.7	40.9	53.8	138	128	0	34	33
2014	9	7	19	10	41	0.774	-0.062	3.747	0.01	0.007	0	45.2	42.6	51.6	140	131	0	35	32
2014	9	7	19	20	41	0.764	-0.062	3.747	0.01	0.007	0	46	43	51.2	142	132	0	35	32
2014	9	7	19	30	41	0.748	-0.085	3.747	0.013	0.01	0	46.4	43.4	53.8	143	133	0	35	32
2014	9	7	19	40	41	0.748	-0.095	3.747	0.016	0.013	0	46.9	43.4	50.3	144	134	0	35	33
2014	9	7	19	50	41	0.738	-0.066	3.747	0.016	0.013	0	47.7	44.7	51.2	145	136	0	34	32
2014	9	7	20	0	41	0.709	-0.098	3.747	0.013	0.01	0	47.7	44.3	50.3	145	135	0	34	32
2014	9	7	20	10	41	0.758	-0.108	3.75	0.016	0.013	0	46.4	43.4	50.7	143	134	0	35	33
2014	9	7	20	20	41	0.774	-0.108	3.747	0.01	0.007	0	46	42.6	50.7	142	132	0	35	33
2014	9	7	20	30	41	0.748	-0.089	3.75	0.013	0.01	0	45.2	42.6	54.2	140	131	0	35	32
2014	9	7	20	40	41	0.745	-0.131	3.75	0.01	0.007	0	45.2	41.7	58.5	140	130	0	35	33
2014	9	7	20	50	41	0.797	-0.118	3.75	0.016	0.013	0	44.7	41.3	58.5	139	129	0	35	33
2014	9	7	21	0	41	0.751	-0.069	3.75	0.013	0.01	0	44.7	42.1	54.2	139	130	0	35	32
2014	9	7	21	10	41	0.745	-0.072	3.75	0.013	0.01	0	44.3	41.3	52.9	138	129	0	35	33
2014	9	7	21	20	41	0.801	-0.075	3.75	0.01	0.007	0	44.3	41.3	49.5	138	129	0	35	33
2014	9	7	21	30	41	0.771	-0.089	3.75	0.013	0.01	0	43.9	40.9	52.9	137	128	0	35	33
2014	9	7	21	40	41	0.761	-0.108	3.75	0.016	0.013	0	43.9	40.9	51.6	137	128	0	35	33
2014	9	7	21	50	41	0.778	-0.105	3.75	0.016	0.013	0	43.9	40.9	51.2	137	128	0	35	33
2014	9	7	22	0	41	0.758	-0.079	3.75	0.01	0.007	0	43.9	40.4	53.8	137	127	0	35	33
2014	9	7	22	10	41	0.764	-0.115	3.75	0.013	0.01	0	43.9	40.9	51.2	137	128	0	35	33
2014	9	7	22	20	41	0.748	-0.085	3.75	0.013	0.01	0	43.9	40.9	62.8	137	128	0	35	33
2014	9	7	22	30	41	0.778	-0.095	3.753	0.013	0.01	0	43.4	40.4	77.4	136	127	0	35	33
2014	9	7	22	40	41	0.804	-0.089	3.753	0.013	0.01	0	43.4	40.4	79.1	136	127	0	35	33
2014	9	7	22	50	41	0.781	-0.066	3.753	0.01	0.007	0	43.4	40.9	77.8	136	127	0	35	32
2014	9	7	23	0	41	0.807	-0.102	3.753	0.013	0.01	0	43.4	40.4	80.8	136	127	0	35	33
2014	9	7	23	10	41	0.768	-0.062	3.753	0.013	0.01	0	43.4	40.4	79.1	136	127	0	35	33
2014	9	7	23	20	41	0.755	-0.095	3.753	0.013	0.01	0	43.9	40.9	80	137	128	0	35	33
2014	9	7	23	30	41	0.781	-0.098	3.753	0.01	0.007	0	43.4	40.9	80.4	136	127	0	35	32
2014	9	7	23	40	41	0.791	-0.059	3.753	0.01	0.007	0	43.4	40.4	79.6	136	127	0	35	33
2014	9	7	23	50	41	0.764	-0.079	3.753	0.016	0.013	0	43.4	41.3	79.1	136	128	0	35	32
2014	9	8	0	0	41	0.774	-0.102	3.753	0.013	0.01	0	43.4	40.9	80	136	128	0	35	33
2014	9	8	0	10	41	0.801	-0.118	3.753	0.013	0.01	0	43.4	41.3	79.6	136	128	0	35	32
2014	9	8	0	20	41	0.846	-0.072	3.753	0.01	0.007	0	43	40.4	79.1	135	126	0	35	32
2014	9	8	0	30	41	0.748	-0.085	3.753	0.01	0.007	0	43	40.4	79.1	135	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	0	40	41	0.758	-0.102	3.753	0.01	0.007	0	43	40.4	78.7	135	127	0	35	33
2014	9	8	0	50	41	0.794	-0.105	3.753	0.01	0.007	0	43	40.4	78.7	135	127	0	35	33
2014	9	8	1	0	41	0.794	-0.079	3.757	0.013	0.01	0	43.4	40	79.1	135	126	0	34	33
2014	9	8	1	10	41	0.814	-0.085	3.757	0.013	0.01	0	42.6	40	78.7	134	126	0	35	33
2014	9	8	1	20	41	0.81	-0.115	3.757	0.01	0.007	0	42.6	40.4	78.3	134	126	0	35	32
2014	9	8	1	30	41	0.794	-0.082	3.757	0.013	0.01	0	42.6	40.9	79.1	135	127	0	36	32
2014	9	8	1	40	41	0.814	-0.095	3.757	0.016	0.013	0	43	40.9	77.8	135	127	0	35	32
2014	9	8	1	50	41	0.827	-0.072	3.757	0.013	0.01	0	43	40.4	79.1	135	127	0	35	33
2014	9	8	2	0	41	0.82	-0.092	3.757	0.013	0.01	0	43	40.4	78.3	135	126	0	35	32
2014	9	8	2	10	41	0.794	-0.092	3.757	0.013	0.01	0	43	40.4	79.1	135	127	0	35	33
2014	9	8	2	20	41	0.774	-0.092	3.757	0.01	0.007	0	43	40.4	78.3	135	127	0	35	33
2014	9	8	2	30	41	0.774	-0.092	3.757	0.01	0.007	0	43	40.9	68.8	135	128	0	35	33
2014	9	8	2	40	41	0.778	-0.062	3.757	0.013	0.01	0	43	40.4	77.4	135	127	0	35	33
2014	9	8	2	50	41	0.804	-0.082	3.757	0.013	0.01	0	42.6	40	76.1	134	126	0	35	33
2014	9	8	3	0	41	0.778	-0.095	3.757	0.01	0.007	0	42.6	40.4	78.3	134	126	0	35	32
2014	9	8	3	10	41	0.761	-0.062	3.757	0.013	0.01	0	42.6	40	77.4	134	126	0	35	33
2014	9	8	3	20	41	0.801	-0.062	3.757	0.013	0.01	0	42.6	40	75.3	134	126	0	35	33
2014	9	8	3	30	41	0.761	-0.108	3.76	0.013	0.01	0	42.1	40	77	133	126	0	35	33
2014	9	8	3	40	41	0.778	-0.095	3.757	0.016	0.013	0	43	40	77.4	135	126	0	35	33
2014	9	8	3	50	41	0.732	-0.095	3.757	0.013	0.01	0	43	40.4	77	135	126	0	35	32
2014	9	8	4	0	41	0.764	-0.066	3.76	0.01	0.007	0	43	40.4	77	135	126	0	35	32
2014	9	8	4	10	41	0.784	-0.095	3.757	0.013	0.01	0	42.6	40.4	77	134	126	0	35	32
2014	9	8	4	20	41	0.781	-0.066	3.76	0.013	0.01	0	42.1	39.6	77	133	125	0	35	33
2014	9	8	4	30	41	0.787	-0.092	3.76	0.013	0.01	0	42.6	40	76.1	134	126	0	35	33
2014	9	8	4	40	41	0.771	-0.098	3.76	0.01	0.007	0	43	40.4	77.4	135	126	0	35	32
2014	9	8	4	50	41	0.768	-0.075	3.76	0.01	0.007	0	43	40.4	77	135	126	0	35	32
2014	9	8	5	0	41	0.771	-0.082	3.76	0.01	0.007	0	43	40	75.7	135	126	0	35	33
2014	9	8	5	10	41	0.778	-0.069	3.76	0.01	0.007	0	43.4	40.9	77	136	127	0	35	32
2014	9	8	5	20	41	0.758	-0.095	3.76	0.013	0.01	0	43.4	40	76.1	135	126	0	34	33
2014	9	8	5	30	41	0.794	-0.082	3.76	0.01	0.007	0	43	40.4	67.5	135	126	0	35	32
2014	9	8	5	40	41	0.787	-0.098	3.757	0.013	0.01	0	43.9	41.3	53.8	137	128	0	35	32
2014	9	8	5	50	41	0.833	-0.092	3.76	0.01	0.007	0	43.9	41.3	72.7	137	128	0	35	32
2014	9	8	6	0	41	0.804	-0.066	3.757	0.013	0.01	0	44.7	42.1	53.3	139	130	0	35	32
2014	9	8	6	10	41	0.778	-0.095	3.76	0.01	0.007	0	44.7	41.3	64.5	139	129	0	35	33
2014	9	8	6	20	41	0.787	-0.049	3.76	0.01	0.007	0	44.7	41.3	70.5	139	129	0	35	33
2014	9	8	6	30	41	0.801	-0.052	3.763	0.013	0.01	0	44.3	40.9	72.2	138	128	0	35	33
2014	9	8	6	40	41	0.827	-0.089	3.763	0.016	0.013	0	44.3	40.9	71.4	137	128	0	34	33
2014	9	8	6	50	41	0.751	-0.085	3.763	0.016	0.013	0	43.4	40.4	61.1	136	127	0	35	33
2014	9	8	7	0	41	0.807	-0.102	3.766	0.01	0.007	0	43.4	40.4	69.7	136	126	0	35	32
2014	9	8	7	10	41	0.758	-0.075	3.766	0.01	0.007	0	43	39.6	73.1	135	125	0	35	33
2014	9	8	7	20	41	0.853	-0.082	3.766	0.016	0.013	0	43	39.6	73.5	135	125	0	35	33
2014	9	8	7	30	41	0.751	-0.102	3.77	0.01	0.007	0	43	39.1	73.5	134	124	0	34	33
2014	9	8	7	40	41	0.778	-0.121	3.77	0.013	0.01	0	42.1	38.7	73.1	133	123	0	35	33
2014	9	8	7	50	41	0.764	-0.105	3.773	0.01	0.007	0	42.1	38.7	73.5	133	123	0	35	33
2014	9	8	8	0	41	0.81	-0.108	3.773	0.016	0.013	0	42.1	38.7	74.4	133	123	0	35	33
2014	9	8	8	10	41	0.761	-0.115	3.773	0.01	0.007	0	41.7	38.7	74.8	132	123	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	8	20	41	0.817	-0.095	3.776	0.01	0.007	0	41.7	38.7	75.3	132	123	0	35	33
2014	9	8	8	30	41	0.787	-0.092	3.773	0.01	0.007	0	41.7	38.3	72.7	132	122	0	35	33
2014	9	8	8	40	41	0.837	-0.115	3.776	0.013	0.01	0	41.7	38.7	75.7	132	123	0	35	33
2014	9	8	8	50	41	0.833	-0.095	3.776	0.016	0.013	0	42.1	38.7	75.3	133	123	0	35	33
2014	9	8	9	0	41	0.794	-0.092	3.776	0.01	0.007	0	41.3	38.7	75.3	131	122	0	35	32
2014	9	8	9	10	41	0.804	-0.098	3.776	0.013	0.01	0	42.1	38.7	75.7	132	123	0	34	33
2014	9	8	9	20	41	0.748	-0.105	3.776	0.013	0.01	0	42.1	38.7	75.7	133	123	0	35	33
2014	9	8	9	30	41	0.817	-0.102	3.776	0.01	0.007	0	41.7	39.1	74.8	132	123	0	35	32
2014	9	8	9	40	41	0.791	-0.085	3.776	0.016	0.013	0	42.1	39.6	67.1	133	124	0	35	32
2014	9	8	9	50	41	0.761	-0.128	3.776	0.013	0.01	0	41.7	38.7	67.9	132	123	0	35	33
2014	9	8	10	0	41	0.771	-0.079	3.78	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	9	8	10	10	41	0.755	-0.121	3.78	0.01	0.007	0	41.7	38.7	75.3	132	123	0	35	33
2014	9	8	10	20	41	0.764	-0.092	3.776	0.01	0.007	0	41.7	38.7	69.7	132	123	0	35	33
2014	9	8	10	30	41	0.771	-0.082	3.776	0.01	0.007	0	41.7	39.1	68.8	132	123	0	35	32
2014	9	8	10	40	41	0.787	-0.092	3.776	0.016	0.013	0	42.6	39.6	62.4	133	124	0	34	32
2014	9	8	10	50	41	0.764	-0.102	3.78	0.01	0.007	0	42.1	39.1	72.2	132	123	0	34	32
2014	9	8	11	0	41	0.807	-0.108	3.776	0.01	0.007	0	41.7	39.6	64.5	132	124	0	35	32
2014	9	8	11	10	41	0.801	-0.095	3.773	0.01	0.007	0	41.7	39.1	55.9	132	123	0	35	32
2014	9	8	11	20	41	0.735	-0.105	3.773	0.013	0.01	0	42.1	39.6	56.8	133	125	0	35	33
2014	9	8	11	30	41	0.761	-0.079	3.773	0.01	0.007	0	42.6	39.1	50.7	133	124	0	34	33
2014	9	8	11	40	41	0.771	-0.095	3.773	0.013	0.01	0	42.1	39.1	57.6	133	124	0	35	33
2014	9	8	11	50	41	0.778	-0.089	3.77	0.013	0.01	0	42.6	40	52.9	134	125	0	35	32
2014	9	8	12	0	41	0.761	-0.112	3.773	0.016	0.013	0	42.6	40	54.6	134	125	0	35	32
2014	9	8	12	10	41	0.807	-0.059	3.77	0.01	0.007	0	42.1	40	51.2	133	125	0	35	32
2014	9	8	12	20	41	0.764	-0.082	3.77	0.016	0.013	0	43	40.4	52	135	126	0	35	32
2014	9	8	12	30	41	0.768	-0.066	3.77	0.013	0.01	0	43	40.9	52.5	135	127	0	35	32
2014	9	8	12	40	41	0.764	-0.075	3.773	0.013	0.01	0	43	40.9	51.6	135	127	0	35	32
2014	9	8	12	50	41	0.807	-0.095	3.77	0.013	0.01	0	43	40	52.9	134	126	0	34	33
2014	9	8	13	0	41	0.778	-0.072	3.77	0.01	0.007	0	42.6	40	51.2	134	125	0	35	32
2014	9	8	13	10	41	0.81	-0.098	3.77	0.013	0.01	0	42.1	39.6	56.3	133	124	0	35	32
2014	9	8	13	28	19	0.751	-0.085	3.77	0.01	0.007	0	42.1	39.6	65.8	133	124	0	35	32
2014	9	8	13	38	19	0.807	-0.128	3.77	0.013	0.01	0	42.1	40	63.2	133	125	0	35	32
2014	9	8	13	48	19	0.771	-0.115	3.77	0.01	0.007	0	42.1	39.1	68.8	133	124	0	35	33
2014	9	8	13	58	19	0.801	-0.105	3.77	0.01	0.007	0	41.7	39.1	69.7	132	124	0	35	33
2014	9	8	14	8	19	0.728	-0.098	3.766	0.013	0.01	0	42.1	40	59.3	133	125	0	35	32
2014	9	8	14	18	19	0.719	-0.089	3.766	0.013	0.01	0	46.9	43.4	55	144	134	0	35	33
2014	9	8	14	28	19	0.791	-0.125	3.77	0.01	0.007	0	41.3	39.1	55	131	124	0	35	33
2014	9	8	14	38	19	0.748	-0.095	3.77	0.016	0.013	0	41.7	40	56.3	131	125	0	34	32
2014	9	8	14	48	19	0.778	-0.089	3.766	0.01	0.007	0	41.3	39.6	55	131	124	0	35	32
2014	9	8	14	58	19	0.764	-0.085	3.77	0.01	0.007	0	40.9	39.6	63.6	130	124	0	35	32
2014	9	8	15	8	19	0.758	-0.085	3.766	0.013	0.01	0	40.9	39.6	60.6	130	124	0	35	32
2014	9	8	15	18	19	0.738	-0.075	3.766	0.013	0.01	0	40.9	39.6	55.5	130	124	0	35	32
2014	9	8	15	28	19	0.784	-0.095	3.766	0.01	0.007	0	41.7	40	61.1	131	125	0	34	32
2014	9	8	15	38	19	0.771	-0.082	3.766	0.016	0.013	0	41.7	39.6	60.6	131	125	0	34	33
2014	9	8	15	48	19	0.82	-0.092	3.766	0.01	0.007	0	40.9	40	65.8	130	125	0	35	32
2014	9	8	15	58	19	0.787	-0.082	3.77	0.01	0.007	0	40.9	39.6	77	130	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	16	8	19	0.768	-0.095	3.77	0.013	0.01	0	40.9	40	77	130	125	0	35	32
2014	9	8	16	18	19	0.84	-0.135	3.77	0.01	0.007	0	40.4	39.1	78.7	129	123	0	35	32
2014	9	8	16	28	19	0.81	-0.138	3.77	0.01	0.007	0	41.3	40	78.3	131	125	0	35	32
2014	9	8	16	38	19	0.801	-0.115	3.77	0.013	0.01	0	41.3	40	78.3	131	125	0	35	32
2014	9	8	16	48	19	0.804	-0.072	3.766	0.013	0.01	0	41.3	40.4	78.3	131	126	0	35	32
2014	9	8	16	58	19	0.81	-0.072	3.766	0.01	0.007	0	41.3	40.4	77.8	131	126	0	35	32
2014	9	8	17	8	19	0.787	-0.072	3.766	0.01	0.007	0	41.7	39.6	77	132	125	0	35	33
2014	9	8	17	18	19	0.774	-0.079	3.766	0.013	0.01	0	40.9	39.6	77.8	130	124	0	35	32
2014	9	8	17	28	19	0.774	-0.079	3.766	0.01	0.007	0	40.9	39.6	71.4	130	125	0	35	33
2014	9	8	17	38	19	0.797	-0.059	3.766	0.01	0.007	0	42.1	40.9	75.3	133	127	0	35	32
2014	9	8	17	48	19	0.787	-0.085	3.766	0.01	0.007	0	41.7	40.4	77.8	131	126	0	34	32
2014	9	8	17	58	19	0.771	-0.082	3.766	0.01	0.007	0	41.3	39.6	77.4	131	125	0	35	33
2014	9	8	18	8	19	0.774	-0.059	3.766	0.013	0.01	0	41.3	40.4	76.1	131	126	0	35	32
2014	9	8	18	18	19	0.794	-0.121	3.766	0.013	0.01	0	41.7	40	76.5	131	125	0	34	32
2014	9	8	18	28	19	0.774	-0.062	3.766	0.01	0.007	0	41.3	40	76.1	131	126	0	35	33
2014	9	8	18	38	19	0.781	-0.043	3.766	0.01	0.007	0	41.7	40.4	77.4	132	126	0	35	32
2014	9	8	18	48	19	0.807	-0.144	3.766	0.013	0.01	0	42.1	40.4	76.5	132	126	0	34	32
2014	9	8	18	58	19	0.758	-0.082	3.766	0.01	0.007	0	41.7	40.4	77.8	132	126	0	35	32
2014	9	8	19	8	19	0.817	-0.066	3.766	0.013	0.01	0	41.3	40	76.1	131	126	0	35	33
2014	9	8	19	18	19	0.81	-0.115	3.766	0.016	0.013	0	42.1	40.4	77.4	133	127	0	35	33
2014	9	8	19	28	19	0.764	-0.108	3.766	0.01	0.007	0	42.1	40.9	76.1	133	127	0	35	32
2014	9	8	19	38	19	0.771	-0.049	3.766	0.013	0.01	0	42.6	40.9	77	134	128	0	35	33
2014	9	8	19	48	19	0.774	-0.079	3.77	0.01	0.007	0	42.1	41.3	77	133	128	0	35	32
2014	9	8	19	58	19	0.814	-0.095	3.77	0.013	0.01	0	42.1	40.9	77.4	133	128	0	35	33
2014	9	8	20	8	19	0.83	-0.102	3.77	0.01	0.007	0	42.6	41.3	76.5	134	128	0	35	32
2014	9	8	20	18	19	0.791	-0.079	3.77	0.013	0.01	0	42.6	41.3	76.5	134	129	0	35	33
2014	9	8	20	28	19	0.823	-0.075	3.77	0.013	0.01	0	42.1	41.3	76.5	133	128	0	35	32
2014	9	8	20	38	19	0.81	-0.079	3.77	0.01	0.007	0	42.6	41.3	77	133	128	0	34	32
2014	9	8	20	48	19	0.804	-0.095	3.77	0.01	0.007	0	42.6	40.9	76.5	133	128	0	34	33
2014	9	8	20	58	19	0.781	-0.079	3.77	0.013	0.01	0	42.1	41.3	76.5	133	128	0	35	32
2014	9	8	21	8	19	0.827	-0.095	3.77	0.01	0.007	0	42.1	41.3	76.5	133	128	0	35	32
2014	9	8	21	18	19	0.738	-0.082	3.773	0.013	0.01	0	42.1	40.9	76.1	133	128	0	35	33
2014	9	8	21	28	19	0.81	-0.072	3.773	0.013	0.01	0	42.1	40.9	76.5	133	127	0	35	32
2014	9	8	21	38	19	0.768	-0.079	3.773	0.01	0.007	0	43	41.3	76.5	134	128	0	34	32
2014	9	8	21	48	19	0.768	-0.098	3.773	0.013	0.01	0	43	41.7	77	134	129	0	34	32
2014	9	8	21	58	19	0.758	-0.108	3.776	0.01	0.007	0	43	41.7	76.5	135	129	0	35	32
2014	9	8	22	8	19	0.768	-0.098	3.78	0.01	0.007	0	43	41.3	77	134	128	0	34	32
2014	9	8	22	18	19	0.722	-0.115	3.78	0.01	0.007	0	43	41.7	77.4	135	129	0	35	32
2014	9	8	22	28	19	0.722	-0.131	3.78	0.013	0.01	0	43	41.3	77	135	128	0	35	32
2014	9	8	22	38	19	0.771	-0.095	3.78	0.013	0.01	0	43	41.3	77	135	128	0	35	32
2014	9	8	22	48	19	0.722	-0.118	3.78	0.013	0.01	0	43	41.3	76.5	134	128	0	34	32
2014	9	8	22	58	19	0.755	-0.112	3.783	0.016	0.016	0	43	40.9	77	134	127	0	34	32
2014	9	8	23	8	19	0.751	-0.112	3.783	0.013	0.01	0	43	40.9	77.4	134	128	0	34	33
2014	9	8	23	18	19	0.768	-0.102	3.783	0.01	0.007	0	43	40.4	77.8	134	127	0	34	33
2014	9	8	23	28	19	0.764	-0.108	3.783	0.016	0.016	0	43	40.9	78.3	135	128	0	35	33
2014	9	8	23	38	19	0.768	-0.115	3.783	0.013	0.01	0	42.1	40.9	78.7	133	127	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	8	23	48	19	0.774	-0.085	3.783	0.013	0.01	0	42.1	40.9	78.7	133	127	0	35	32
2014	9	8	23	58	19	0.771	-0.128	3.783	0.013	0.01	0	42.6	40.9	78.7	134	127	0	35	32
2014	9	9	0	8	19	0.758	-0.118	3.783	0.01	0.007	0	42.1	40.9	79.6	133	127	0	35	32
2014	9	9	0	18	19	0.764	-0.135	3.783	0.013	0.01	0	42.6	40.4	79.1	134	127	0	35	33
2014	9	9	0	28	19	0.781	-0.105	3.783	0.013	0.01	0	42.6	41.3	78.7	134	128	0	35	32
2014	9	9	0	38	19	0.778	-0.112	3.786	0.013	0.01	0	42.1	40.4	80	133	127	0	35	33
2014	9	9	0	48	19	0.781	-0.128	3.786	0.01	0.007	0	42.1	40.4	79.6	133	127	0	35	33
2014	9	9	0	58	19	0.797	-0.062	3.786	0.01	0.007	0	43.9	40.9	79.1	137	128	0	35	33
2014	9	9	1	8	19	0.83	-0.079	3.786	0.013	0.01	0	44.3	41.3	80.4	138	128	0	35	32
2014	9	9	1	18	19	0.794	-0.072	3.786	0.01	0.007	0	44.7	41.3	80.4	139	128	0	35	32
2014	9	9	1	28	19	0.801	-0.085	3.786	0.01	0.007	0	44.3	40.9	79.6	138	127	0	35	32
2014	9	9	1	38	19	0.804	-0.079	3.786	0.013	0.01	0	44.3	40.4	80	138	127	0	35	33
2014	9	9	1	48	19	0.784	-0.069	3.786	0.01	0.007	0	44.3	40.9	76.5	138	127	0	35	32
2014	9	9	1	58	19	0.768	-0.079	3.786	0.013	0.01	0	44.7	40.9	80.4	139	128	0	35	33
2014	9	9	2	8	19	0.823	-0.075	3.786	0.01	0.007	0	44.7	41.3	80.4	139	128	0	35	32
2014	9	9	2	18	19	0.814	-0.089	3.786	0.01	0.007	0	44.7	40.9	81.3	139	128	0	35	33
2014	9	9	2	28	19	0.751	-0.085	3.786	0.013	0.01	0	44.7	41.7	80	139	129	0	35	32
2014	9	9	2	38	19	0.817	-0.108	3.786	0.013	0.01	0	44.7	40.9	80.8	139	128	0	35	33
2014	9	9	2	48	19	0.781	-0.095	3.786	0.013	0.01	0	45.2	40.9	80.4	139	127	0	34	32
2014	9	9	2	58	19	0.794	-0.089	3.786	0.016	0.016	0	44.3	40.9	80.8	138	127	0	35	32
2014	9	9	3	8	19	0.837	-0.089	3.786	0.01	0.007	0	44.7	40.9	82.1	138	127	0	34	32
2014	9	9	3	18	19	0.758	-0.079	3.786	0.01	0.007	0	44.3	40.9	81.7	138	127	0	35	32
2014	9	9	3	28	19	0.81	-0.089	3.786	0.013	0.01	0	44.3	40.4	82.1	138	127	0	35	33
2014	9	9	3	38	19	0.797	-0.092	3.786	0.013	0.01	0	44.3	40.9	80	138	127	0	35	32
2014	9	9	3	48	19	0.778	-0.098	3.786	0.01	0.007	0	44.3	40	81.7	138	127	0	35	34
2014	9	9	3	58	19	0.771	-0.066	3.789	0.016	0.013	0	44.7	41.3	81.7	139	128	0	35	32
2014	9	9	4	8	19	0.81	-0.075	3.786	0.01	0.007	0	44.3	40.4	80	138	127	0	35	33
2014	9	9	4	18	19	0.804	-0.079	3.789	0.013	0.01	0	44.3	40.4	80.8	138	127	0	35	33
2014	9	9	4	28	19	0.787	-0.079	3.789	0.01	0.007	0	43.9	40	80.8	137	127	0	35	34
2014	9	9	4	38	19	0.827	-0.079	3.789	0.01	0.007	0	45.2	40.4	80.4	139	127	0	34	33
2014	9	9	4	48	19	0.804	-0.098	3.786	0.01	0.007	0	45.2	40.9	80.8	139	128	0	34	33
2014	9	9	4	58	19	0.823	-0.108	3.789	0.01	0.007	0	45.2	40.9	80	139	127	0	34	32
2014	9	9	5	8	19	0.804	-0.089	3.789	0.01	0.007	0	45.2	41.3	79.6	139	128	0	34	32
2014	9	9	5	18	19	0.791	-0.092	3.786	0.01	0.007	0	45.2	41.3	80	140	128	0	35	32
2014	9	9	5	28	19	0.81	-0.046	3.789	0.016	0.013	0	44.3	41.3	78.7	138	128	0	35	32
2014	9	9	5	38	19	0.787	-0.079	3.789	0.013	0.01	0	45.2	41.3	79.6	139	128	0	34	32
2014	9	9	5	48	19	0.764	-0.062	3.789	0.016	0.013	0	45.2	40.9	79.6	140	128	0	35	33
2014	9	9	5	58	19	0.807	-0.092	3.789	0.01	0.007	0	44.7	40.9	79.1	139	128	0	35	33
2014	9	9	6	8	19	0.82	-0.108	3.789	0.016	0.013	0	45.2	40.9	79.6	140	128	0	35	33
2014	9	9	6	18	19	0.807	-0.075	3.789	0.016	0.013	0	44.7	40.9	79.6	139	127	0	35	32
2014	9	9	6	28	19	0.807	-0.075	3.789	0.01	0.007	0	43.9	40.9	79.1	137	127	0	35	32
2014	9	9	6	38	19	0.784	-0.085	3.789	0.01	0.007	0	43.9	40.4	79.6	137	127	0	35	33
2014	9	9	6	48	19	0.768	-0.059	3.789	0.013	0.01	0	43.9	40.4	78.7	137	127	0	35	33
2014	9	9	6	58	19	0.771	-0.092	3.789	0.016	0.013	0	43.9	40.4	78.3	137	127	0	35	33
2014	9	9	7	8	19	0.807	-0.092	3.789	0.013	0.01	0	43	39.6	78.7	135	125	0	35	33
2014	9	9	7	18	19	0.791	-0.115	3.789	0.016	0.013	0	43	40	78.7	135	125	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	7	28	19	0.778	-0.095	3.789	0.013	0.01	0	42.6	40	78.7	134	125	0	35	32
2014	9	9	7	38	19	0.787	-0.092	3.789	0.01	0.007	0	43	39.1	78.3	135	124	0	35	33
2014	9	9	7	48	19	0.804	-0.098	3.789	0.013	0.01	0	42.6	39.1	78.3	134	124	0	35	33
2014	9	9	7	58	19	0.804	-0.115	3.789	0.013	0.01	0	42.6	39.6	77.4	134	124	0	35	32
2014	9	9	8	8	19	0.774	-0.069	3.789	0.01	0.007	0	42.1	39.1	77	133	124	0	35	33
2014	9	9	8	18	19	0.814	-0.089	3.789	0.013	0.01	0	42.6	39.1	78.3	134	124	0	35	33
2014	9	9	8	28	19	0.764	-0.079	3.789	0.016	0.013	0	42.6	40	78.7	134	125	0	35	32
2014	9	9	8	38	19	0.778	-0.095	3.793	0.01	0.007	0	43	39.6	76.1	134	125	0	34	33
2014	9	9	8	48	19	0.784	-0.052	3.793	0.013	0.01	0	42.6	40	78.7	134	125	0	35	32
2014	9	9	8	58	19	0.794	-0.085	3.793	0.01	0.007	0	42.6	39.6	77.8	134	125	0	35	33
2014	9	9	9	8	19	0.761	-0.075	3.793	0.01	0.007	0	42.6	39.6	77.8	134	125	0	35	33
2014	9	9	9	18	19	0.791	-0.079	3.793	0.013	0.01	0	42.6	40	77.4	134	125	0	35	32
2014	9	9	9	28	19	0.771	-0.095	3.793	0.013	0.01	0	42.6	39.1	77	134	124	0	35	33
2014	9	9	9	38	19	0.833	-0.085	3.793	0.013	0.01	0	42.6	39.6	77.8	134	125	0	35	33
2014	9	9	9	48	19	0.784	-0.052	3.793	0.01	0.007	0	42.1	39.1	78.3	133	124	0	35	33
2014	9	9	9	58	19	0.768	-0.118	3.793	0.013	0.01	0	42.6	39.1	78.3	134	124	0	35	33
2014	9	9	10	8	19	0.81	-0.108	3.793	0.01	0.007	0	42.1	39.6	79.1	133	124	0	35	32
2014	9	9	10	18	19	0.791	-0.079	3.793	0.01	0.007	0	41.7	38.7	78.7	132	123	0	35	33
2014	9	9	10	28	19	0.758	-0.085	3.793	0.013	0.01	0	41.7	39.1	79.1	132	123	0	35	32
2014	9	9	10	38	19	0.82	-0.098	3.793	0.01	0.007	0	41.7	38.7	79.1	132	123	0	35	33
2014	9	9	10	48	19	0.758	-0.112	3.793	0.01	0.007	0	42.6	39.1	78.7	133	124	0	34	33
2014	9	9	10	58	19	0.751	-0.085	3.793	0.013	0.01	0	41.7	39.6	80	133	124	0	36	32
2014	9	9	11	8	19	0.794	-0.085	3.793	0.016	0.013	0	42.1	39.6	79.1	133	124	0	35	32
2014	9	9	11	18	19	0.784	-0.085	3.793	0.013	0.01	0	41.7	38.7	77.8	132	123	0	35	33
2014	9	9	11	28	19	0.817	-0.062	3.793	0.013	0.01	0	42.1	39.6	80	133	124	0	35	32
2014	9	9	11	38	19	0.787	-0.072	3.793	0.013	0.01	0	42.6	39.6	79.6	134	125	0	35	33
2014	9	9	11	48	19	0.81	-0.108	3.793	0.01	0.007	0	42.6	40	80	134	125	0	35	32
2014	9	9	11	58	19	0.787	-0.098	3.793	0.016	0.013	0	42.1	39.1	80	133	124	0	35	33
2014	9	9	12	8	19	0.807	-0.092	3.793	0.016	0.013	0	41.7	39.6	80.4	132	124	0	35	32
2014	9	9	12	18	19	0.748	-0.069	3.793	0.013	0.01	0	41.7	38.7	79.1	132	123	0	35	33
2014	9	9	12	28	19	0.814	-0.079	3.793	0.01	0.007	0	43	39.1	79.1	134	124	0	34	33
2014	9	9	12	38	19	0.807	-0.079	3.793	0.01	0.007	0	42.1	39.1	79.6	133	124	0	35	33
2014	9	9	12	48	19	0.814	-0.079	3.793	0.013	0.01	0	42.1	39.1	80	133	124	0	35	33
2014	9	9	12	58	19	0.817	-0.079	3.793	0.013	0.01	0	42.1	39.6	80	133	124	0	35	32
2014	9	9	13	8	19	0.781	-0.079	3.793	0.013	0.01	0	42.1	39.6	80.8	133	124	0	35	32
2014	9	9	13	18	19	0.797	-0.072	3.793	0.01	0.007	0	42.1	39.6	80.4	133	124	0	35	32
2014	9	9	13	28	19	0.823	-0.095	3.793	0.013	0.01	0	42.1	39.6	81.3	133	124	0	35	32
2014	9	9	13	38	19	0.771	-0.066	3.793	0.01	0.007	0	42.1	40	81.3	133	124	0	35	31
2014	9	9	13	48	19	0.764	-0.095	3.789	0.01	0.007	0	41.7	38.7	59.8	132	123	0	35	33
2014	9	9	13	58	19	0.827	-0.089	3.793	0.016	0.013	0	42.1	39.6	80.8	133	124	0	35	32
2014	9	9	14	8	19	0.761	-0.079	3.793	0.013	0.01	0	42.6	39.1	81.7	134	124	0	35	33
2014	9	9	14	18	19	0.791	-0.092	3.793	0.013	0.01	0	42.1	39.1	80	133	124	0	35	33
2014	9	9	14	28	19	0.797	-0.092	3.789	0.013	0.01	0	42.1	39.1	80.8	132	124	0	34	33
2014	9	9	14	38	19	0.814	-0.079	3.789	0.01	0.007	0	41.7	38.7	80.4	132	123	0	35	33
2014	9	9	14	48	19	0.787	-0.098	3.789	0.01	0.007	0	42.6	39.6	81.7	134	124	0	35	32
2014	9	9	14	58	19	0.817	-0.092	3.789	0.013	0.01	0	43	39.6	80.4	135	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	15	8	19	0.784	-0.092	3.789	0.01	0.007	0	43	39.6	81.3	134	125	0	34	33
2014	9	9	15	18	19	0.797	-0.066	3.789	0.01	0.007	0	43	39.6	81.7	135	125	0	35	33
2014	9	9	15	28	19	0.797	-0.105	3.789	0.01	0.007	0	43.4	40	80.8	135	125	0	34	32
2014	9	9	15	38	19	0.83	-0.092	3.789	0.01	0.007	0	42.6	40	80.8	134	125	0	35	32
2014	9	9	15	48	19	0.781	-0.092	3.789	0.013	0.01	0	42.6	39.6	81.3	134	125	0	35	33
2014	9	9	15	58	19	0.764	-0.092	3.789	0.013	0.01	0	42.6	40	80	134	125	0	35	32
2014	9	9	16	8	19	0.794	-0.072	3.789	0.01	0.007	0	42.1	39.1	79.1	133	124	0	35	33
2014	9	9	16	18	19	0.817	-0.075	3.789	0.01	0.007	0	43	40	80.4	135	125	0	35	32
2014	9	9	16	28	19	0.787	-0.092	3.789	0.01	0.007	0	43.4	40	80	136	126	0	35	33
2014	9	9	16	38	19	0.781	-0.098	3.789	0.01	0.007	0	43.4	40	79.1	135	126	0	34	33
2014	9	9	16	48	19	0.791	-0.079	3.786	0.01	0.007	0	42.1	39.6	79.6	134	125	0	36	33
2014	9	9	16	58	19	0.784	-0.075	3.786	0.01	0.007	0	42.6	39.6	80	134	125	0	35	33
2014	9	9	17	8	19	0.761	-0.082	3.786	0.016	0.016	0	41.7	40	80.8	132	125	0	35	32
2014	9	9	17	18	19	0.784	-0.062	3.786	0.01	0.007	0	42.6	40	80.8	134	125	0	35	32
2014	9	9	17	28	19	0.791	-0.085	3.786	0.013	0.01	0	43	40.9	78.7	135	127	0	35	32
2014	9	9	17	38	19	0.768	-0.095	3.786	0.013	0.01	0	42.6	40	80.4	134	125	0	35	32
2014	9	9	17	48	19	0.771	-0.105	3.786	0.016	0.013	0	42.6	39.6	79.6	134	125	0	35	33
2014	9	9	17	58	19	0.784	-0.046	3.786	0.013	0.01	0	43.4	39.6	80	135	125	0	34	33
2014	9	9	18	8	19	0.791	-0.062	3.786	0.013	0.01	0	42.6	40	80	133	125	0	34	32
2014	9	9	18	18	19	0.774	-0.108	3.786	0.016	0.013	0	42.1	40	80	133	125	0	35	32
2014	9	9	18	28	19	0.807	-0.102	3.789	0.016	0.013	0	42.6	39.6	80.8	134	125	0	35	33
2014	9	9	18	38	19	0.784	-0.075	3.786	0.01	0.007	0	42.6	40.4	80.4	134	125	0	35	31
2014	9	9	18	48	19	0.801	-0.059	3.789	0.013	0.01	0	43	40.4	81.3	135	127	0	35	33
2014	9	9	18	58	19	0.797	-0.062	3.789	0.01	0.007	0	43	40.4	81.7	135	127	0	35	33
2014	9	9	19	8	19	0.82	-0.092	3.789	0.013	0.01	0	43	40.9	81.3	135	127	0	35	32
2014	9	9	19	18	19	0.784	-0.112	3.789	0.01	0.007	0	43.4	40.9	80.8	135	127	0	34	32
2014	9	9	19	28	19	0.804	-0.072	3.789	0.016	0.013	0	43.9	40.4	80.8	136	127	0	34	33
2014	9	9	19	38	19	0.774	-0.102	3.789	0.016	0.013	0	43.4	40.9	81.3	136	128	0	35	33
2014	9	9	19	48	19	0.781	-0.075	3.789	0.013	0.01	0	43	40.9	81.7	135	127	0	35	32
2014	9	9	19	58	19	0.797	-0.062	3.789	0.01	0.007	0	43.4	40.9	80.8	135	127	0	34	32
2014	9	9	20	8	19	0.755	-0.072	3.789	0.01	0.007	0	45.2	41.3	79.1	140	128	0	35	32
2014	9	9	20	18	19	0.797	-0.066	3.789	0.016	0.013	0	44.7	40.9	80	138	127	0	34	32
2014	9	9	20	28	19	0.778	-0.072	3.789	0.013	0.01	0	44.7	40.9	79.6	139	128	0	35	33
2014	9	9	20	38	19	0.781	-0.108	3.789	0.01	0.007	0	45.2	41.3	80	140	128	0	35	32
2014	9	9	20	48	19	0.791	-0.102	3.789	0.01	0.007	0	45.2	41.3	80	140	128	0	35	32
2014	9	9	20	58	19	0.764	-0.092	3.789	0.013	0.01	0	44.7	40.9	80	139	128	0	35	33
2014	9	9	21	8	19	0.778	-0.102	3.789	0.01	0.007	0	45.2	40.9	80	140	128	0	35	33
2014	9	9	21	18	19	0.81	-0.115	3.789	0.016	0.013	0	45.2	40.9	79.1	140	128	0	35	33
2014	9	9	21	28	19	0.797	-0.079	3.789	0.01	0.007	0	45.2	40.9	79.1	140	128	0	35	33
2014	9	9	21	38	19	0.817	-0.079	3.789	0.013	0.01	0	45.2	41.3	79.1	140	128	0	35	32
2014	9	9	21	48	19	0.817	-0.046	3.789	0.013	0.01	0	45.6	40.9	79.1	140	128	0	34	33
2014	9	9	21	58	19	0.794	-0.082	3.789	0.013	0.01	0	45.2	40.9	79.1	140	128	0	35	33
2014	9	9	22	8	19	0.807	-0.092	3.789	0.013	0.01	0	45.6	40.9	79.1	140	128	0	34	33
2014	9	9	22	18	19	0.774	-0.108	3.789	0.016	0.013	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	9	22	28	19	0.827	-0.112	3.789	0.013	0.01	0	44.3	40.4	79.1	138	126	0	35	32
2014	9	9	22	38	19	0.81	-0.115	3.789	0.01	0.007	0	44.3	40.4	78.7	138	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	9	22	48	19	0.797	-0.082	3.789	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	9	22	58	19	0.764	-0.089	3.789	0.013	0.01	0	44.3	40.9	78.7	139	128	0	36	33
2014	9	9	23	8	19	0.81	-0.056	3.789	0.013	0.01	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	9	23	18	19	0.801	-0.095	3.789	0.013	0.01	0	44.7	40.9	78.3	139	128	0	35	33
2014	9	9	23	28	19	0.784	-0.075	3.789	0.01	0.007	0	44.7	40.9	78.3	139	128	0	35	33
2014	9	9	23	38	19	0.807	-0.102	3.789	0.016	0.013	0	44.7	40.9	78.3	138	128	0	34	33
2014	9	9	23	48	19	0.814	-0.089	3.789	0.01	0.007	0	44.7	40.9	77.8	139	128	0	35	33
2014	9	9	23	58	19	0.797	-0.089	3.789	0.013	0.01	0	44.3	40.4	77.8	138	127	0	35	33
2014	9	10	0	8	19	0.827	-0.118	3.789	0.01	0.007	0	44.3	40.4	77.8	138	127	0	35	33
2014	9	10	0	18	19	0.823	-0.095	3.789	0.01	0.007	0	43.9	40.9	77.8	138	127	0	36	32
2014	9	10	0	28	19	0.801	-0.095	3.789	0.01	0.007	0	44.7	41.3	77.4	139	128	0	35	32
2014	9	10	0	38	19	0.827	-0.095	3.789	0.013	0.01	0	44.3	40.4	77.4	138	127	0	35	33
2014	9	10	0	48	19	0.81	-0.075	3.789	0.016	0.013	0	44.7	41.3	77	139	128	0	35	32
2014	9	10	0	58	19	0.804	-0.072	3.789	0.016	0.013	0	44.3	40.9	77.4	138	128	0	35	33
2014	9	10	1	8	19	0.784	-0.125	3.789	0.013	0.01	0	44.7	41.3	77.4	138	128	0	34	32
2014	9	10	1	18	19	0.774	-0.049	3.789	0.016	0.013	0	43.9	40.4	76.5	137	127	0	35	33
2014	9	10	1	28	19	0.82	-0.059	3.789	0.01	0.007	0	44.3	40.9	76.1	137	127	0	34	32
2014	9	10	1	38	19	0.761	-0.079	3.789	0.01	0.007	0	43.9	40.4	77	138	127	0	36	33
2014	9	10	1	48	19	0.787	-0.079	3.789	0.01	0.007	0	43.9	40.9	77	137	127	0	35	32
2014	9	10	1	58	19	0.81	-0.095	3.789	0.01	0.007	0	43.9	40.4	77.4	137	127	0	35	33
2014	9	10	2	8	19	0.784	-0.125	3.789	0.01	0.007	0	44.3	40.4	77	138	127	0	35	33
2014	9	10	2	18	19	0.784	-0.075	3.789	0.01	0.007	0	43.4	40	76.5	136	126	0	35	33
2014	9	10	2	28	19	0.755	-0.092	3.789	0.013	0.01	0	43.9	40.4	76.5	138	127	0	36	33
2014	9	10	2	38	19	0.787	-0.079	3.789	0.013	0.01	0	44.3	40.9	76.1	138	127	0	35	32
2014	9	10	2	48	19	0.784	-0.108	3.793	0.016	0.013	0	44.3	40.9	76.5	138	127	0	35	32
2014	9	10	2	58	19	0.784	-0.092	3.793	0.01	0.007	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	10	3	8	19	0.794	-0.075	3.789	0.013	0.01	0	44.7	40.9	75.7	140	127	0	36	32
2014	9	10	3	18	19	0.784	-0.075	3.789	0.01	0.007	0	44.3	40	75.3	138	126	0	35	33
2014	9	10	3	28	19	0.823	-0.092	3.789	0.013	0.01	0	43.9	40	75.3	138	126	0	36	33
2014	9	10	3	38	19	0.823	-0.098	3.789	0.016	0.013	0	43.9	40	74.4	137	125	0	35	32
2014	9	10	3	48	19	0.781	-0.075	3.789	0.016	0.016	0	44.7	40.4	74.8	139	127	0	35	33
2014	9	10	3	58	19	0.797	-0.079	3.789	0.013	0.01	0	44.7	40	74.8	139	126	0	35	33
2014	9	10	4	8	19	0.83	-0.052	3.793	0.01	0.007	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	10	4	18	19	0.797	-0.062	3.793	0.016	0.013	0	44.3	40	73.5	138	126	0	35	33
2014	9	10	4	28	19	0.801	-0.105	3.793	0.016	0.013	0	44.3	40	73.5	138	126	0	35	33
2014	9	10	4	38	19	0.791	-0.075	3.796	0.01	0.007	0	44.3	40	74	138	126	0	35	33
2014	9	10	4	48	19	0.784	-0.066	3.796	0.013	0.01	0	44.3	40	72.7	138	126	0	35	33
2014	9	10	4	58	19	0.827	-0.059	3.796	0.01	0.007	0	44.3	40	73.1	138	126	0	35	33
2014	9	10	5	8	19	0.794	-0.095	3.799	0.01	0.007	0	44.3	40	74	138	126	0	35	33
2014	9	10	5	18	19	0.781	-0.069	3.799	0.013	0.01	0	43.9	40.4	73.1	137	126	0	35	32
2014	9	10	5	28	19	0.797	-0.062	3.799	0.01	0.007	0	43.9	40	74.4	137	125	0	35	32
2014	9	10	5	38	19	0.801	-0.059	3.802	0.01	0.007	0	44.3	39.6	74	138	125	0	35	33
2014	9	10	5	48	19	0.827	-0.072	3.802	0.01	0.007	0	43.9	39.6	74.4	138	125	0	36	33
2014	9	10	5	58	19	0.827	-0.125	3.802	0.01	0.007	0	43.9	39.6	74.4	138	125	0	36	33
2014	9	10	6	8	19	0.814	-0.092	3.802	0.013	0.01	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	10	6	18	19	0.797	-0.079	3.802	0.013	0.01	0	44.3	39.6	74.8	138	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	6	28	19	0.791	-0.066	3.802	0.01	0.007	0	43.9	40	75.3	137	125	0	35	32
2014	9	10	6	38	19	0.794	-0.056	3.802	0.016	0.013	0	43.4	39.6	76.1	137	124	0	36	32
2014	9	10	6	48	19	0.794	-0.075	3.806	0.01	0.007	0	43.4	39.1	74.8	137	124	0	36	33
2014	9	10	6	58	19	0.755	-0.062	3.806	0.013	0.01	0	43.4	39.6	76.1	136	124	0	35	32
2014	9	10	7	8	19	0.81	-0.092	3.806	0.01	0.007	0	43	38.7	75.7	136	123	0	36	33
2014	9	10	7	18	19	0.823	-0.085	3.806	0.016	0.013	0	42.6	38.3	77	135	122	0	36	33
2014	9	10	7	28	19	0.797	-0.092	3.806	0.013	0.01	0	42.6	38.7	75.7	135	123	0	36	33
2014	9	10	7	38	19	0.794	-0.089	3.806	0.01	0.007	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	10	7	48	19	0.787	-0.108	3.806	0.01	0.007	0	42.6	37.8	77	134	122	0	35	34
2014	9	10	7	58	19	0.781	-0.102	3.806	0.013	0.01	0	42.6	38.3	77.8	134	122	0	35	33
2014	9	10	8	8	19	0.801	-0.039	3.806	0.013	0.01	0	42.6	38.3	77.8	134	122	0	35	33
2014	9	10	8	18	19	0.791	-0.095	3.806	0.01	0.007	0	42.6	38.3	77.4	135	122	0	36	33
2014	9	10	8	28	19	0.804	-0.075	3.809	0.016	0.013	0	42.6	38.3	77.8	134	122	0	35	33
2014	9	10	8	38	19	0.804	-0.079	3.809	0.013	0.01	0	42.6	38.3	78.3	134	122	0	35	33
2014	9	10	8	48	19	0.801	-0.082	3.809	0.013	0.01	0	42.1	37.8	77	133	121	0	35	33
2014	9	10	8	58	19	0.81	-0.108	3.809	0.01	0.007	0	42.1	37.8	78.3	133	121	0	35	33
2014	9	10	9	8	19	0.745	-0.079	3.809	0.01	0.007	0	42.6	37.8	78.3	134	122	0	35	34
2014	9	10	9	18	19	0.797	-0.069	3.809	0.01	0.007	0	42.6	37.8	77.4	134	121	0	35	33
2014	9	10	9	28	19	0.804	-0.092	3.809	0.01	0.007	0	42.1	38.3	77.8	133	122	0	35	33
2014	9	10	9	38	19	0.807	-0.082	3.809	0.01	0.007	0	42.6	37.8	77.4	134	122	0	35	34
2014	9	10	9	48	19	0.83	-0.085	3.809	0.013	0.01	0	41.7	37.8	78.7	133	121	0	36	33
2014	9	10	9	58	19	0.764	-0.095	3.809	0.01	0.007	0	41.7	38.3	77.8	133	122	0	36	33
2014	9	10	10	8	19	0.82	-0.079	3.809	0.01	0.007	0	41.7	38.3	79.1	133	121	0	36	32
2014	9	10	10	18	19	0.801	-0.072	3.809	0.013	0.01	0	41.7	37.4	78.3	132	120	0	35	33
2014	9	10	10	28	19	0.837	-0.095	3.809	0.013	0.01	0	41.7	37.8	78.7	133	121	0	36	33
2014	9	10	10	38	19	0.781	-0.089	3.809	0.013	0.01	0	41.7	37.4	77.8	132	120	0	35	33
2014	9	10	10	48	19	0.794	-0.085	3.809	0.01	0.007	0	42.1	37.8	77	133	121	0	35	33
2014	9	10	10	58	19	0.781	-0.089	3.809	0.013	0.01	0	41.7	37.4	77.8	132	120	0	35	33
2014	9	10	11	8	19	0.794	-0.095	3.809	0.01	0.007	0	41.7	37.8	77.8	132	121	0	35	33
2014	9	10	11	18	19	0.81	-0.085	3.809	0.013	0.01	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	10	11	28	19	0.784	-0.079	3.809	0.01	0.007	0	41.7	37.4	77.8	132	120	0	35	33
2014	9	10	11	38	19	0.814	-0.092	3.809	0.016	0.013	0	42.1	37.4	77.4	133	121	0	35	34
2014	9	10	11	48	19	0.781	-0.108	3.809	0.01	0.007	0	42.1	38.3	77.4	133	122	0	35	33
2014	9	10	11	58	19	0.804	-0.092	3.809	0.01	0.007	0	41.7	38.3	76.5	133	122	0	36	33
2014	9	10	12	8	19	0.784	-0.062	3.809	0.013	0.01	0	42.1	37.8	76.5	133	121	0	35	33
2014	9	10	12	18	19	0.778	-0.069	3.809	0.013	0.01	0	41.7	38.3	77	132	121	0	35	32
2014	9	10	12	28	19	0.801	-0.079	3.809	0.01	0.007	0	42.1	38.3	76.5	133	122	0	35	33
2014	9	10	12	38	19	0.833	-0.105	3.809	0.016	0.013	0	42.6	38.7	76.1	134	122	0	35	32
2014	9	10	12	48	19	0.768	-0.085	3.809	0.013	0.01	0	42.1	37.8	76.1	133	121	0	35	33
2014	9	10	12	58	19	0.764	-0.098	3.809	0.013	0.01	0	42.1	38.7	74.8	133	122	0	35	32
2014	9	10	13	8	19	0.778	-0.102	3.806	0.013	0.01	0	42.1	38.7	74.4	133	122	0	35	32
2014	9	10	13	18	19	0.784	-0.095	3.806	0.01	0.007	0	42.6	39.1	74.8	134	123	0	35	32
2014	9	10	13	28	19	0.81	-0.059	3.802	0.013	0.01	0	43	38.7	67.9	135	123	0	35	33
2014	9	10	13	38	19	0.787	-0.085	3.799	0.016	0.013	0	43.4	39.1	67.9	135	124	0	34	33
2014	9	10	13	48	19	0.787	-0.095	3.799	0.016	0.013	0	43	39.1	64.1	135	124	0	35	33
2014	9	10	13	58	19	0.833	-0.095	3.799	0.01	0.007	0	42.6	38.7	73.5	134	123	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	14	8	19	0.774	-0.072	3.796	0.013	0.01	0	42.6	38.7	68.4	134	123	0	35	33
2014	9	10	14	18	19	0.755	-0.098	3.796	0.013	0.01	0	42.6	39.1	74.8	134	123	0	35	32
2014	9	10	14	28	19	0.807	-0.108	3.796	0.013	0.01	0	43	39.1	73.1	135	124	0	35	33
2014	9	10	14	38	19	0.787	-0.069	3.796	0.016	0.013	0	42.6	39.1	71.4	135	124	0	36	33
2014	9	10	14	48	19	0.787	-0.085	3.793	0.013	0.01	0	43	39.6	65.4	135	124	0	35	32
2014	9	10	14	58	19	0.823	-0.131	3.793	0.016	0.013	0	43	39.6	70.5	135	124	0	35	32
2014	9	10	15	8	19	0.823	-0.098	3.796	0.01	0.007	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	10	15	18	19	0.778	-0.085	3.793	0.013	0.01	0	43.4	39.6	74.8	136	125	0	35	33
2014	9	10	15	28	19	0.81	-0.069	3.793	0.013	0.01	0	43.4	39.1	76.1	136	125	0	35	34
2014	9	10	15	38	19	0.804	-0.059	3.793	0.01	0.007	0	43	40	73.5	136	125	0	36	32
2014	9	10	15	48	19	0.787	-0.092	3.793	0.01	0.007	0	43.4	40	75.7	136	125	0	35	32
2014	9	10	15	58	19	0.801	-0.092	3.793	0.013	0.01	0	43.4	39.1	73.5	136	124	0	35	33
2014	9	10	16	8	19	0.778	-0.092	3.793	0.01	0.007	0	43.4	40	76.1	136	125	0	35	32
2014	9	10	16	18	19	0.797	-0.079	3.793	0.016	0.013	0	43	39.1	76.1	135	124	0	35	33
2014	9	10	16	28	19	0.791	-0.105	3.793	0.01	0.007	0	43	39.1	74.8	135	124	0	35	33
2014	9	10	16	38	19	0.807	-0.092	3.793	0.01	0.007	0	43.4	39.6	77	136	124	0	35	32
2014	9	10	16	48	19	0.807	-0.066	3.793	0.013	0.01	0	43	39.1	76.5	135	124	0	35	33
2014	9	10	16	58	19	0.774	-0.121	3.793	0.013	0.01	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	10	17	8	19	0.814	-0.056	3.789	0.016	0.013	0	43	39.1	76.5	135	124	0	35	33
2014	9	10	17	18	19	0.787	-0.098	3.793	0.01	0.007	0	43	39.1	75.7	135	124	0	35	33
2014	9	10	17	28	19	0.771	-0.082	3.793	0.01	0.007	0	42.6	39.1	75.7	135	124	0	36	33
2014	9	10	17	38	19	0.814	-0.089	3.789	0.013	0.01	0	43	38.7	76.5	135	123	0	35	33
2014	9	10	17	48	19	0.755	-0.089	3.789	0.013	0.01	0	42.6	39.1	76.5	134	123	0	35	32
2014	9	10	17	58	19	0.81	-0.062	3.789	0.016	0.016	0	43	38.7	77.4	134	123	0	34	33
2014	9	10	18	8	19	0.764	-0.089	3.793	0.016	0.013	0	42.6	39.1	77	134	123	0	35	32
2014	9	10	18	18	19	0.787	-0.066	3.793	0.013	0.01	0	43	39.1	77.4	135	123	0	35	32
2014	9	10	18	28	19	0.804	-0.092	3.793	0.013	0.01	0	43	38.7	77	135	123	0	35	33
2014	9	10	18	38	19	0.804	-0.082	3.793	0.01	0.007	0	43	38.7	76.1	135	123	0	35	33
2014	9	10	18	48	19	0.823	-0.056	3.793	0.016	0.013	0	43.9	39.1	76.5	136	124	0	34	33
2014	9	10	18	58	19	0.791	-0.079	3.793	0.013	0.01	0	43.9	39.1	76.5	136	124	0	34	33
2014	9	10	19	8	19	0.807	-0.079	3.793	0.01	0.007	0	43.9	39.6	76.1	137	125	0	35	33
2014	9	10	19	18	19	0.778	-0.102	3.793	0.01	0.007	0	44.3	39.6	76.1	138	126	0	35	34
2014	9	10	19	28	19	0.791	-0.085	3.793	0.01	0.007	0	44.7	40.4	75.7	139	127	0	35	33
2014	9	10	19	38	19	0.823	-0.092	3.793	0.013	0.01	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	10	19	48	19	0.807	-0.108	3.793	0.01	0.007	0	44.3	40.4	75.7	139	127	0	36	33
2014	9	10	19	58	19	0.791	-0.052	3.793	0.013	0.01	0	45.2	40.9	75.7	140	127	0	35	32
2014	9	10	20	8	19	0.778	-0.092	3.793	0.01	0.007	0	44.7	40.4	75.7	139	127	0	35	33
2014	9	10	20	18	19	0.791	-0.108	3.793	0.013	0.01	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	10	20	28	19	0.781	-0.066	3.793	0.013	0.01	0	45.2	40	75.7	139	126	0	34	33
2014	9	10	20	38	19	0.82	-0.112	3.793	0.013	0.01	0	44.3	40	75.3	138	126	0	35	33
2014	9	10	20	48	19	0.791	-0.079	3.793	0.013	0.01	0	44.7	40.9	75.3	139	127	0	35	32
2014	9	10	20	58	19	0.807	-0.108	3.793	0.016	0.016	0	44.3	40	74.8	138	126	0	35	33
2014	9	10	21	8	19	0.794	-0.085	3.793	0.01	0.007	0	44.3	40	73.5	138	126	0	35	33
2014	9	10	21	18	19	0.807	-0.095	3.793	0.01	0.007	0	44.7	41.3	74.8	139	128	0	35	32
2014	9	10	21	28	19	0.791	-0.089	3.793	0.013	0.01	0	44.7	40.9	74.8	139	128	0	35	33
2014	9	10	21	38	19	0.801	-0.062	3.796	0.013	0.01	0	44.7	41.3	74.8	139	128	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	10	21	48	19	0.774	-0.095	3.796	0.01	0.007	0	45.2	40.9	74	140	128	0	35	33
2014	9	10	21	58	19	0.807	-0.062	3.796	0.013	0.01	0	45.2	40.9	74.8	140	128	0	35	33
2014	9	10	22	8	19	0.758	-0.105	3.796	0.013	0.01	0	45.2	40.9	75.7	140	128	0	35	33
2014	9	10	22	18	19	0.807	-0.108	3.796	0.01	0.007	0	44.7	40.4	74.8	139	127	0	35	33
2014	9	10	22	28	19	0.755	-0.095	3.796	0.01	0.007	0	45.2	40.9	74.8	140	128	0	35	33
2014	9	10	22	38	19	0.794	-0.069	3.796	0.016	0.013	0	45.2	40.4	74	140	127	0	35	33
2014	9	10	22	48	19	0.807	-0.072	3.799	0.013	0.01	0	45.2	40.9	74.4	140	128	0	35	33
2014	9	10	22	58	19	0.804	-0.059	3.799	0.013	0.01	0	44.7	40.9	74.4	139	127	0	35	32
2014	9	10	23	8	19	0.794	-0.079	3.802	0.016	0.013	0	44.7	40.4	74	139	127	0	35	33
2014	9	10	23	18	19	0.804	-0.075	3.806	0.01	0.007	0	44.7	40.4	75.3	140	127	0	36	33
2014	9	10	23	28	19	0.758	-0.046	3.806	0.013	0.01	0	45.2	41.3	72.7	140	128	0	35	32
2014	9	10	23	38	19	0.784	-0.118	3.806	0.016	0.013	0	45.2	40.9	75.3	140	128	0	35	33
2014	9	10	23	48	19	0.81	-0.062	3.806	0.01	0.007	0	45.2	40.9	74.8	140	127	0	35	32
2014	9	10	23	58	19	0.82	-0.082	3.806	0.013	0.01	0	44.7	40.4	74.8	139	127	0	35	33
2014	9	11	0	8	19	0.807	-0.075	3.809	0.013	0.01	0	44.7	40.4	74.8	139	127	0	35	33
2014	9	11	0	18	19	0.817	-0.079	3.809	0.01	0.007	0	45.6	40.9	75.3	140	128	0	34	33
2014	9	11	0	28	19	0.778	-0.085	3.809	0.01	0.007	0	45.2	40.9	76.1	140	128	0	35	33
2014	9	11	0	38	19	0.817	-0.072	3.809	0.013	0.01	0	44.7	40.4	75.7	139	127	0	35	33
2014	9	11	0	48	19	0.801	-0.108	3.809	0.013	0.01	0	45.2	40.4	76.1	139	127	0	34	33
2014	9	11	0	58	19	0.801	-0.102	3.809	0.01	0.007	0	45.2	40.9	76.1	140	127	0	35	32
2014	9	11	1	8	19	0.801	-0.075	3.809	0.013	0.01	0	44.7	40.9	76.1	139	128	0	35	33
2014	9	11	1	18	19	0.794	-0.046	3.809	0.01	0.007	0	44.7	40.4	75.7	139	127	0	35	33
2014	9	11	1	28	19	0.791	-0.092	3.809	0.016	0.013	0	45.2	40.4	77	140	127	0	35	33
2014	9	11	1	38	19	0.791	-0.092	3.809	0.013	0.01	0	44.3	40.4	76.5	139	127	0	36	33
2014	9	11	1	48	19	0.768	-0.075	3.809	0.013	0.01	0	44.3	40.9	76.1	139	127	0	36	32
2014	9	11	1	58	19	0.778	-0.079	3.812	0.01	0.007	0	44.7	40.4	77	139	127	0	35	33
2014	9	11	2	8	19	0.797	-0.056	3.812	0.016	0.013	0	44.3	40.4	77.4	138	127	0	35	33
2014	9	11	2	18	19	0.83	-0.085	3.812	0.016	0.013	0	43.9	40.4	77.4	138	126	0	36	32
2014	9	11	2	28	19	0.814	-0.075	3.812	0.01	0.007	0	44.3	40.9	77.8	139	127	0	36	32
2014	9	11	2	38	19	0.797	-0.066	3.812	0.01	0.007	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	11	2	48	19	0.784	-0.075	3.812	0.01	0.007	0	44.3	40.9	78.3	138	127	0	35	32
2014	9	11	2	58	19	0.797	-0.075	3.812	0.01	0.007	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	11	3	8	19	0.787	-0.079	3.812	0.01	0.007	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	11	3	18	19	0.801	-0.098	3.812	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	11	3	28	19	0.781	-0.118	3.812	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33
2014	9	11	3	38	19	0.755	-0.118	3.812	0.01	0.007	0	44.3	39.6	78.7	139	126	0	36	34
2014	9	11	3	48	19	0.784	-0.092	3.812	0.013	0.01	0	44.3	40	78.7	138	126	0	35	33
2014	9	11	3	58	19	0.787	-0.095	3.812	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	11	4	8	19	0.771	-0.108	3.812	0.01	0.007	0	44.3	40	79.1	138	126	0	35	33
2014	9	11	4	18	19	0.804	-0.102	3.812	0.01	0.007	0	44.3	40.4	78.7	138	127	0	35	33
2014	9	11	4	28	19	0.837	-0.079	3.812	0.013	0.01	0	44.3	40	78.3	138	126	0	35	33
2014	9	11	4	38	19	0.781	-0.082	3.812	0.013	0.01	0	44.3	40.9	79.1	138	127	0	35	32
2014	9	11	4	48	19	0.764	-0.072	3.812	0.01	0.007	0	44.3	40	79.1	138	126	0	35	33
2014	9	11	4	58	19	0.794	-0.069	3.812	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	11	5	8	19	0.807	-0.131	3.812	0.01	0.007	0	43.9	40	78.3	138	126	0	36	33
2014	9	11	5	18	19	0.761	-0.082	3.812	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	5	28	19	0.784	-0.082	3.812	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	11	5	38	19	0.84	-0.082	3.812	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	11	5	48	19	0.84	-0.095	3.812	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	11	5	58	19	0.794	-0.082	3.812	0.013	0.01	0	43.9	40	77.8	138	126	0	36	33
2014	9	11	6	8	19	0.827	-0.098	3.812	0.01	0.007	0	43.9	40	77.8	137	125	0	35	32
2014	9	11	6	18	19	0.791	-0.085	3.812	0.01	0.007	0	43.9	39.6	76.5	137	125	0	35	33
2014	9	11	6	28	19	0.827	-0.075	3.812	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	11	6	38	19	0.784	-0.089	3.816	0.013	0.01	0	43.4	38.7	78.7	136	124	0	35	34
2014	9	11	6	48	19	0.807	-0.069	3.812	0.01	0.007	0	43.4	39.1	77.8	136	124	0	35	33
2014	9	11	6	58	19	0.823	-0.056	3.816	0.01	0.007	0	43	38.7	78.7	136	123	0	36	33
2014	9	11	7	8	19	0.846	-0.102	3.816	0.013	0.01	0	43.4	38.7	77.8	136	123	0	35	33
2014	9	11	7	18	19	0.781	-0.075	3.816	0.01	0.007	0	43.4	38.7	78.3	136	123	0	35	33
2014	9	11	7	28	19	0.814	-0.059	3.816	0.013	0.01	0	43	38.7	77.8	135	123	0	35	33
2014	9	11	7	38	19	0.807	-0.066	3.816	0.013	0.01	0	42.1	38.3	77.8	134	122	0	36	33
2014	9	11	7	48	19	0.846	-0.079	3.816	0.01	0.007	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	11	7	58	19	0.797	-0.118	3.816	0.013	0.01	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	11	8	8	19	0.81	-0.082	3.816	0.01	0.007	0	42.1	37.8	77.8	133	121	0	35	33
2014	9	11	8	18	19	0.791	-0.075	3.816	0.016	0.013	0	42.1	37.8	77.8	133	121	0	35	33
2014	9	11	8	28	19	0.814	-0.095	3.816	0.01	0.007	0	42.1	37.8	77.8	133	121	0	35	33
2014	9	11	8	38	19	0.774	-0.062	3.816	0.013	0.01	0	41.7	37.8	77.8	133	122	0	36	34
2014	9	11	8	48	19	0.781	-0.062	3.816	0.013	0.01	0	42.1	37.8	77.8	133	121	0	35	33
2014	9	11	8	58	19	0.791	-0.125	3.816	0.01	0.007	0	42.6	38.3	77	134	122	0	35	33
2014	9	11	9	8	19	0.755	-0.095	3.816	0.01	0.007	0	42.6	38.3	77	134	122	0	35	33
2014	9	11	9	18	19	0.797	-0.075	3.816	0.013	0.01	0	41.7	37.4	78.3	133	121	0	36	34
2014	9	11	9	28	19	0.814	-0.112	3.816	0.013	0.01	0	42.1	38.3	77.4	134	122	0	36	33
2014	9	11	9	38	19	0.807	-0.108	3.816	0.01	0.007	0	42.1	37.8	77	133	122	0	35	34
2014	9	11	9	48	19	0.755	-0.079	3.816	0.016	0.016	0	42.6	38.3	77.8	134	122	0	35	33
2014	9	11	9	58	19	0.774	-0.092	3.816	0.013	0.01	0	43	38.7	78.3	135	123	0	35	33
2014	9	11	10	8	19	0.778	-0.069	3.816	0.013	0.01	0	42.6	38.7	77.4	134	123	0	35	33
2014	9	11	10	18	19	0.787	-0.069	3.816	0.013	0.01	0	42.1	38.3	78.3	133	122	0	35	33
2014	9	11	10	28	19	0.778	-0.052	3.816	0.016	0.013	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	11	10	38	19	0.797	-0.102	3.816	0.01	0.007	0	42.6	39.1	78.3	135	123	0	36	32
2014	9	11	10	48	19	0.768	-0.105	3.816	0.01	0.007	0	42.6	38.7	78.7	134	123	0	35	33
2014	9	11	10	58	19	0.817	-0.056	3.816	0.013	0.01	0	42.6	38.3	77.8	134	123	0	35	34
2014	9	11	11	8	19	0.827	-0.082	3.816	0.013	0.01	0	42.1	38.7	78.3	134	123	0	36	33
2014	9	11	11	18	19	0.745	-0.092	3.816	0.013	0.01	0	42.6	38.3	79.1	134	123	0	35	34
2014	9	11	11	28	19	0.784	-0.059	3.816	0.01	0.007	0	42.6	38.7	78.7	134	123	0	35	33
2014	9	11	11	38	19	0.804	-0.075	3.816	0.013	0.01	0	42.1	38.3	79.1	133	122	0	35	33
2014	9	11	11	48	19	0.81	-0.095	3.816	0.013	0.01	0	42.1	37.8	78.7	133	121	0	35	33
2014	9	11	11	58	19	0.843	-0.095	3.816	0.013	0.01	0	42.1	38.3	78.7	133	122	0	35	33
2014	9	11	12	8	19	0.791	-0.072	3.816	0.01	0.007	0	42.6	38.7	79.6	134	122	0	35	32
2014	9	11	12	18	19	0.801	-0.075	3.816	0.016	0.013	0	42.6	38.7	79.6	134	123	0	35	33
2014	9	11	12	28	19	0.833	-0.089	3.816	0.01	0.007	0	41.7	38.3	79.6	133	122	0	36	33
2014	9	11	12	38	19	0.774	-0.089	3.816	0.01	0.007	0	42.6	38.7	78.7	134	123	0	35	33
2014	9	11	12	48	19	0.814	-0.092	3.816	0.01	0.007	0	42.6	39.6	78.7	135	124	0	36	32
2014	9	11	12	58	19	0.784	-0.085	3.816	0.01	0.007	0	42.6	37.8	79.1	134	122	0	35	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	13	8	19	0.804	-0.069	3.816	0.01	0.007	0	42.1	38.7	78.7	134	123	0	36	33
2014	9	11	13	18	19	0.843	-0.105	3.812	0.013	0.01	0	43	39.1	77.4	135	123	0	35	32
2014	9	11	13	28	19	0.755	-0.052	3.812	0.013	0.01	0	42.1	38.3	77	133	122	0	35	33
2014	9	11	13	38	19	0.801	-0.108	3.812	0.01	0.007	0	42.1	37.8	78.3	133	121	0	35	33
2014	9	11	13	48	19	0.791	-0.089	3.812	0.01	0.007	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	11	13	58	19	0.771	-0.108	3.812	0.01	0.007	0	42.1	38.3	76.5	133	122	0	35	33
2014	9	11	14	8	19	0.804	-0.052	3.812	0.01	0.007	0	41.7	38.3	77	133	122	0	36	33
2014	9	11	14	18	19	0.787	-0.082	3.812	0.013	0.01	0	42.1	38.7	74	133	122	0	35	32
2014	9	11	14	28	19	0.833	-0.085	3.809	0.016	0.013	0	42.1	38.3	76.1	133	122	0	35	33
2014	9	11	14	38	19	0.787	-0.049	3.809	0.01	0.007	0	42.6	38.7	76.1	134	123	0	35	33
2014	9	11	14	48	19	0.801	-0.079	3.809	0.01	0.007	0	42.6	37.8	76.5	134	122	0	35	34
2014	9	11	14	58	19	0.81	-0.079	3.809	0.01	0.007	0	42.6	39.1	74.4	134	123	0	35	32
2014	9	11	15	8	19	0.794	-0.102	3.809	0.013	0.01	0	43	38.7	75.3	135	123	0	35	33
2014	9	11	15	18	19	0.833	-0.102	3.809	0.01	0.007	0	42.6	38.7	74.8	134	123	0	35	33
2014	9	11	15	28	19	0.787	-0.059	3.809	0.013	0.01	0	43	38.7	75.7	135	123	0	35	33
2014	9	11	15	38	19	0.84	-0.082	3.806	0.01	0.007	0	42.6	38.7	75.3	134	123	0	35	33
2014	9	11	15	48	19	0.82	-0.085	3.806	0.01	0.007	0	43	39.6	74	135	124	0	35	32
2014	9	11	15	58	19	0.85	-0.115	3.802	0.01	0.007	0	42.6	39.1	74.4	134	123	0	35	32
2014	9	11	16	8	19	0.794	-0.092	3.799	0.013	0.01	0	42.6	38.7	70.1	134	122	0	35	32
2014	9	11	16	18	19	0.784	-0.095	3.799	0.01	0.007	0	42.6	38.7	74.4	134	123	0	35	33
2014	9	11	16	28	19	0.784	-0.108	3.799	0.016	0.013	0	42.6	39.1	75.3	134	123	0	35	32
2014	9	11	16	38	19	0.778	-0.085	3.796	0.01	0.007	0	42.6	38.7	74.4	134	123	0	35	33
2014	9	11	16	48	19	0.801	-0.069	3.796	0.013	0.01	0	42.6	38.7	74.8	134	123	0	35	33
2014	9	11	16	58	19	0.801	-0.075	3.796	0.016	0.016	0	43.4	39.1	75.3	136	124	0	35	33
2014	9	11	17	8	19	0.801	-0.092	3.796	0.01	0.007	0	42.6	39.1	75.3	134	123	0	35	32
2014	9	11	17	18	19	0.751	-0.069	3.796	0.01	0.007	0	42.6	38.7	74.8	134	123	0	35	33
2014	9	11	17	28	19	0.794	-0.108	3.796	0.013	0.01	0	42.6	38.3	75.7	134	122	0	35	33
2014	9	11	17	38	19	0.801	-0.075	3.796	0.01	0.007	0	43	38.7	74.4	135	123	0	35	33
2014	9	11	17	48	19	0.797	-0.059	3.796	0.01	0.007	0	42.6	38.7	75.3	134	122	0	35	32
2014	9	11	17	58	19	0.778	-0.075	3.796	0.013	0.01	0	42.6	38.3	75.7	134	122	0	35	33
2014	9	11	18	8	19	0.81	-0.085	3.796	0.01	0.007	0	42.6	38.7	74.8	134	123	0	35	33
2014	9	11	18	18	19	0.797	-0.072	3.796	0.01	0.007	0	42.6	39.1	75.3	134	123	0	35	32
2014	9	11	18	28	19	0.771	-0.085	3.796	0.01	0.007	0	43	38.3	75.3	135	122	0	35	33
2014	9	11	18	38	19	0.801	-0.108	3.796	0.01	0.007	0	42.6	38.3	74.8	134	122	0	35	33
2014	9	11	18	48	19	0.81	-0.085	3.796	0.01	0.007	0	43	39.1	75.3	135	123	0	35	32
2014	9	11	18	58	19	0.797	-0.075	3.796	0.01	0.007	0	43	39.1	74.4	135	123	0	35	32
2014	9	11	19	8	19	0.801	-0.052	3.796	0.01	0.007	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	11	19	18	19	0.781	-0.059	3.799	0.01	0.007	0	43.4	39.6	75.3	136	124	0	35	32
2014	9	11	19	28	19	0.801	-0.085	3.796	0.01	0.007	0	43.9	39.6	75.3	137	125	0	35	33
2014	9	11	19	38	19	0.833	-0.092	3.799	0.013	0.01	0	43.9	39.6	74	137	125	0	35	33
2014	9	11	19	48	19	0.804	-0.118	3.802	0.01	0.007	0	44.3	40	73.5	138	126	0	35	33
2014	9	11	19	58	19	0.791	-0.089	3.802	0.01	0.007	0	44.3	40	74.8	138	126	0	35	33
2014	9	11	20	8	19	0.771	-0.118	3.802	0.013	0.01	0	44.3	40.4	74.4	138	126	0	35	32
2014	9	11	20	18	19	0.784	-0.085	3.802	0.01	0.007	0	44.3	40	74.8	138	126	0	35	33
2014	9	11	20	28	19	0.804	-0.105	3.806	0.013	0.01	0	44.3	40	74.8	138	126	0	35	33
2014	9	11	20	38	19	0.797	-0.092	3.806	0.016	0.013	0	44.3	40	74.8	138	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	11	20	48	19	0.758	-0.072	3.806	0.013	0.01	0	44.3	40	74.8	138	126	0	35	33
2014	9	11	20	58	19	0.774	-0.098	3.806	0.013	0.01	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	11	21	8	19	0.807	-0.105	3.809	0.01	0.007	0	43.9	39.6	74.4	137	125	0	35	33
2014	9	11	21	18	19	0.817	-0.095	3.809	0.01	0.007	0	44.3	40	74.8	138	126	0	35	33
2014	9	11	21	28	19	0.794	-0.092	3.809	0.01	0.007	0	44.3	40.4	75.3	138	126	0	35	32
2014	9	11	21	38	19	0.82	-0.102	3.809	0.016	0.013	0	44.3	40.4	76.1	138	126	0	35	32
2014	9	11	21	48	19	0.794	-0.108	3.809	0.01	0.007	0	44.3	40	75.3	138	126	0	35	33
2014	9	11	21	58	19	0.797	-0.072	3.809	0.016	0.013	0	44.7	40	75.7	139	126	0	35	33
2014	9	11	22	8	19	0.843	-0.085	3.809	0.01	0.007	0	44.3	40.9	76.5	138	127	0	35	32
2014	9	11	22	18	19	0.81	-0.095	3.809	0.01	0.007	0	44.3	39.6	76.1	138	126	0	35	34
2014	9	11	22	28	19	0.791	-0.082	3.809	0.01	0.007	0	44.3	40	76.5	138	126	0	35	33
2014	9	11	22	38	19	0.83	-0.075	3.809	0.01	0.007	0	44.7	40.4	77	139	127	0	35	33
2014	9	11	22	48	19	0.827	-0.059	3.812	0.016	0.013	0	43.9	40	76.5	138	126	0	36	33
2014	9	11	22	58	19	0.837	-0.095	3.812	0.01	0.007	0	44.3	40.4	77	138	126	0	35	32
2014	9	11	23	8	19	0.797	-0.082	3.812	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	11	23	18	19	0.764	-0.062	3.812	0.016	0.013	0	44.7	40.9	77.8	139	127	0	35	32
2014	9	11	23	28	19	0.807	-0.033	3.812	0.01	0.007	0	44.3	40.4	77.8	138	127	0	35	33
2014	9	11	23	38	19	0.794	-0.079	3.812	0.01	0.007	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	11	23	48	19	0.856	-0.098	3.812	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	11	23	58	19	0.774	-0.049	3.812	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	12	0	8	19	0.814	-0.108	3.812	0.01	0.007	0	43.9	40	78.3	138	126	0	36	33
2014	9	12	0	18	19	0.817	-0.059	3.812	0.01	0.007	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	12	0	28	19	0.817	-0.075	3.812	0.01	0.007	0	44.3	40	78.7	138	127	0	35	34
2014	9	12	0	38	19	0.814	-0.082	3.812	0.01	0.007	0	44.3	40.9	77.8	138	127	0	35	32
2014	9	12	0	48	19	0.797	-0.098	3.812	0.013	0.01	0	45.2	40.9	78.3	139	128	0	34	33
2014	9	12	0	58	19	0.781	-0.072	3.816	0.01	0.007	0	44.7	40.9	79.1	139	128	0	35	33
2014	9	12	1	8	19	0.804	-0.075	3.816	0.01	0.007	0	44.3	40	79.1	138	127	0	35	34
2014	9	12	1	18	19	0.81	-0.069	3.816	0.013	0.01	0	43.9	40.4	79.6	137	127	0	35	33
2014	9	12	1	28	19	0.83	-0.079	3.812	0.01	0.007	0	44.7	40.9	79.1	139	127	0	35	32
2014	9	12	1	38	19	0.758	-0.082	3.816	0.01	0.007	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	12	1	48	19	0.82	-0.102	3.816	0.01	0.007	0	44.7	40	78.3	139	126	0	35	33
2014	9	12	1	58	19	0.764	-0.089	3.816	0.013	0.01	0	43.9	40.4	78.7	138	127	0	36	33
2014	9	12	2	8	19	0.823	-0.115	3.816	0.01	0.007	0	45.2	40.4	79.1	140	127	0	35	33
2014	9	12	2	18	19	0.748	-0.105	3.816	0.013	0.01	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	12	2	28	19	0.81	-0.092	3.816	0.016	0.013	0	43.9	40	78.7	138	126	0	36	33
2014	9	12	2	38	19	0.794	-0.095	3.816	0.01	0.007	0	44.3	40.4	79.1	138	127	0	35	33
2014	9	12	2	48	19	0.791	-0.072	3.816	0.013	0.01	0	44.3	40.9	78.7	138	127	0	35	32
2014	9	12	2	58	19	0.814	-0.079	3.816	0.013	0.01	0	44.3	40	78.7	138	126	0	35	33
2014	9	12	3	8	19	0.764	-0.105	3.816	0.01	0.007	0	44.3	40	79.6	138	126	0	35	33
2014	9	12	3	18	19	0.827	-0.092	3.816	0.013	0.01	0	43.9	40.4	78.3	137	126	0	35	32
2014	9	12	3	28	19	0.814	-0.118	3.816	0.01	0.007	0	43.9	40	78.3	138	126	0	36	33
2014	9	12	3	38	19	0.817	-0.105	3.816	0.013	0.01	0	44.3	40	79.1	138	126	0	35	33
2014	9	12	3	48	19	0.797	-0.112	3.816	0.013	0.01	0	43.4	40	78.3	137	125	0	36	32
2014	9	12	3	58	19	0.827	-0.075	3.816	0.01	0.007	0	44.3	40	79.1	137	126	0	34	33
2014	9	12	4	8	19	0.823	-0.066	3.816	0.013	0.01	0	43.9	39.6	77.8	137	126	0	35	34
2014	9	12	4	18	19	0.817	-0.092	3.816	0.016	0.013	0	43.9	39.6	78.7	137	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	4	28	19	0.768	-0.075	3.816	0.01	0.007	0	44.3	39.6	78.7	138	126	0	35	34
2014	9	12	4	38	19	0.784	-0.066	3.816	0.01	0.007	0	43.9	39.6	76.1	137	125	0	35	33
2014	9	12	4	48	19	0.81	-0.072	3.816	0.01	0.007	0	43.9	39.6	77	137	125	0	35	33
2014	9	12	4	58	19	0.837	-0.075	3.816	0.01	0.007	0	43.4	39.6	77.8	137	125	0	36	33
2014	9	12	5	8	19	0.804	-0.108	3.816	0.013	0.01	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	12	5	18	19	0.82	-0.079	3.816	0.01	0.007	0	43.9	39.1	77.4	137	124	0	35	33
2014	9	12	5	28	19	0.791	-0.125	3.816	0.013	0.01	0	43.9	39.1	76.5	138	125	0	36	34
2014	9	12	5	38	19	0.778	-0.046	3.816	0.013	0.01	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	12	5	48	19	0.866	-0.105	3.816	0.013	0.01	0	43.4	39.6	78.3	137	125	0	36	33
2014	9	12	5	58	19	0.823	-0.102	3.816	0.013	0.01	0	43	39.1	76.5	136	124	0	36	33
2014	9	12	6	8	19	0.797	-0.092	3.816	0.01	0.007	0	43	39.1	77.4	136	124	0	36	33
2014	9	12	6	18	19	0.804	-0.079	3.816	0.01	0.007	0	43.4	38.7	77.4	136	124	0	35	34
2014	9	12	6	28	19	0.787	-0.092	3.816	0.01	0.007	0	43.4	39.1	77.4	136	124	0	35	33
2014	9	12	6	38	19	0.774	-0.092	3.819	0.016	0.013	0	43.4	39.1	76.5	136	124	0	35	33
2014	9	12	6	48	19	0.81	-0.082	3.816	0.01	0.007	0	42.6	38.7	77.4	135	123	0	36	33
2014	9	12	6	58	19	0.807	-0.108	3.819	0.016	0.013	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	12	7	8	19	0.801	-0.098	3.819	0.01	0.007	0	42.6	38.3	76.1	135	122	0	36	33
2014	9	12	7	18	19	0.791	-0.108	3.819	0.013	0.01	0	42.1	38.3	77.4	134	122	0	36	33
2014	9	12	7	28	19	0.794	-0.092	3.819	0.01	0.007	0	42.1	37.8	77	133	121	0	35	33
2014	9	12	7	38	19	0.778	-0.059	3.819	0.013	0.01	0	42.1	37.8	76.1	133	121	0	35	33
2014	9	12	7	48	19	0.81	-0.092	3.819	0.016	0.013	0	42.1	37.8	76.5	133	121	0	35	33
2014	9	12	7	58	19	0.758	-0.089	3.819	0.01	0.007	0	41.7	37.4	76.5	133	121	0	36	34
2014	9	12	8	8	19	0.745	-0.098	3.819	0.013	0.01	0	42.1	37.8	76.1	133	121	0	35	33
2014	9	12	8	18	19	0.833	-0.118	3.819	0.01	0.007	0	42.1	37.4	76.5	133	121	0	35	34
2014	9	12	8	28	19	0.778	-0.075	3.819	0.013	0.01	0	42.1	37.8	75.7	133	121	0	35	33
2014	9	12	8	38	19	0.791	-0.072	3.819	0.01	0.007	0	42.1	38.3	76.5	133	122	0	35	33
2014	9	12	8	48	19	0.807	-0.075	3.819	0.01	0.007	0	41.7	38.3	76.5	133	121	0	36	32
2014	9	12	8	58	19	0.817	-0.092	3.819	0.01	0.007	0	42.1	37.8	75.7	133	121	0	35	33
2014	9	12	9	8	19	0.807	-0.075	3.819	0.01	0.007	0	41.7	37.4	77	133	121	0	36	34
2014	9	12	9	18	19	0.774	-0.085	3.819	0.01	0.007	0	41.7	37.8	76.1	133	121	0	36	33
2014	9	12	9	28	19	0.794	-0.082	3.819	0.016	0.016	0	41.7	37.8	76.5	132	121	0	35	33
2014	9	12	9	38	19	0.761	-0.079	3.819	0.01	0.007	0	41.7	37.4	76.5	132	121	0	35	34
2014	9	12	9	48	19	0.801	-0.082	3.819	0.013	0.01	0	41.7	37	76.5	133	120	0	36	34
2014	9	12	9	58	19	0.758	-0.092	3.819	0.013	0.01	0	42.1	38.3	77	133	122	0	35	33
2014	9	12	10	8	19	0.801	-0.105	3.819	0.01	0.007	0	41.7	37.8	76.5	133	121	0	36	33
2014	9	12	10	18	19	0.82	-0.095	3.819	0.01	0.007	0	41.3	37.8	77.8	132	121	0	36	33
2014	9	12	10	28	19	0.817	-0.098	3.819	0.013	0.01	0	42.1	37.8	76.5	133	121	0	35	33
2014	9	12	10	38	19	0.778	-0.115	3.819	0.01	0.007	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	12	10	48	19	0.778	-0.085	3.819	0.01	0.007	0	41.7	37.8	77.8	132	121	0	35	33
2014	9	12	10	58	19	0.761	-0.079	3.819	0.01	0.007	0	41.7	37.4	77.4	132	120	0	35	33
2014	9	12	11	8	19	0.801	-0.115	3.819	0.016	0.013	0	41.7	37.4	77.4	132	120	0	35	33
2014	9	12	11	18	19	0.771	-0.092	3.819	0.013	0.01	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	12	11	28	19	0.774	-0.105	3.819	0.01	0.007	0	41.7	38.3	78.3	133	122	0	36	33
2014	9	12	11	38	19	0.794	-0.102	3.819	0.01	0.007	0	41.7	37.8	77.8	132	121	0	35	33
2014	9	12	11	48	19	0.807	-0.082	3.819	0.013	0.01	0	41.7	37.8	77.8	132	121	0	35	33
2014	9	12	11	58	19	0.764	-0.085	3.819	0.016	0.013	0	42.6	39.1	77.8	134	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	12	8	19	0.801	-0.089	3.819	0.016	0.013	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	12	12	18	19	0.797	-0.105	3.819	0.013	0.01	0	42.1	37.8	77.8	133	121	0	35	33
2014	9	12	12	28	19	0.797	-0.082	3.819	0.01	0.007	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	12	12	38	19	0.82	-0.095	3.819	0.013	0.01	0	42.1	38.3	78.3	133	122	0	35	33
2014	9	12	12	48	19	0.761	-0.079	3.819	0.01	0.007	0	41.7	38.3	78.3	132	121	0	35	32
2014	9	12	12	58	19	0.814	-0.092	3.819	0.013	0.01	0	41.3	37.8	79.6	132	121	0	36	33
2014	9	12	13	8	19	0.764	-0.089	3.819	0.013	0.01	0	41.3	38.3	78.7	132	121	0	36	32
2014	9	12	13	18	19	0.738	-0.089	3.819	0.01	0.007	0	41.3	37.8	72.7	132	121	0	36	33
2014	9	12	13	28	19	0.735	-0.102	3.819	0.01	0.007	0	41.7	37.8	58.9	132	121	0	35	33
2014	9	12	13	38	19	0.784	-0.115	3.816	0.01	0.007	0	42.1	37.8	62.8	133	122	0	35	34
2014	9	12	13	48	19	0.804	-0.075	3.816	0.016	0.013	0	43	38.7	63.2	134	123	0	34	33
2014	9	12	13	58	19	0.768	-0.112	3.816	0.01	0.007	0	41.7	38.3	71.4	132	122	0	35	33
2014	9	12	14	8	19	0.778	-0.092	3.816	0.016	0.013	0	43	39.1	66.7	135	124	0	35	33
2014	9	12	14	18	19	0.807	-0.098	3.816	0.013	0.01	0	42.1	38.7	62.8	133	122	0	35	32
2014	9	12	14	28	19	0.791	-0.105	3.816	0.016	0.013	0	42.1	38.3	64.9	134	123	0	36	34
2014	9	12	14	38	19	0.774	-0.082	3.816	0.016	0.013	0	42.6	38.7	63.2	134	123	0	35	33
2014	9	12	14	48	19	0.84	-0.089	3.816	0.016	0.013	0	42.6	38.7	65.4	134	123	0	35	33
2014	9	12	14	58	19	0.738	-0.108	3.812	0.013	0.01	0	42.6	38.7	62.8	134	123	0	35	33
2014	9	12	15	8	19	0.771	-0.095	3.816	0.013	0.01	0	42.6	38.3	74.8	134	122	0	35	33
2014	9	12	15	18	19	0.801	-0.098	3.816	0.013	0.01	0	42.1	37.8	71	133	122	0	35	34
2014	9	12	15	28	19	0.787	-0.089	3.812	0.01	0.007	0	41.7	38.3	67.9	132	121	0	35	32
2014	9	12	15	38	19	0.741	-0.079	3.812	0.013	0.01	0	42.6	38.7	75.7	134	123	0	35	33
2014	9	12	15	48	19	0.758	-0.089	3.812	0.01	0.007	0	42.6	39.1	64.9	134	123	0	35	32
2014	9	12	15	58	19	0.758	-0.079	3.812	0.01	0.007	0	42.6	39.1	70.5	134	124	0	35	33
2014	9	12	16	8	19	0.784	-0.069	3.812	0.013	0.01	0	43	39.1	65.4	135	124	0	35	33
2014	9	12	16	18	19	0.804	-0.092	3.812	0.016	0.013	0	42.6	38.7	73.5	134	123	0	35	33
2014	9	12	16	28	19	0.787	-0.082	3.809	0.013	0.01	0	42.6	38.7	60.2	134	123	0	35	33
2014	9	12	16	38	19	0.771	-0.108	3.809	0.013	0.01	0	42.6	38.7	62.4	134	123	0	35	33
2014	9	12	16	48	19	0.804	-0.075	3.809	0.01	0.007	0	42.6	38.7	61.1	134	123	0	35	33
2014	9	12	16	58	19	0.784	-0.092	3.809	0.013	0.01	0	42.6	38.3	68.8	134	122	0	35	33
2014	9	12	17	8	19	0.784	-0.121	3.809	0.01	0.007	0	43	39.1	69.2	135	124	0	35	33
2014	9	12	17	18	19	0.82	-0.092	3.806	0.013	0.01	0	43	39.1	57.2	135	123	0	35	32
2014	9	12	17	28	19	0.774	-0.075	3.809	0.016	0.016	0	42.6	38.7	72.7	134	123	0	35	33
2014	9	12	17	38	19	0.791	-0.098	3.809	0.016	0.013	0	42.1	38.7	71.4	133	122	0	35	32
2014	9	12	17	48	19	0.804	-0.052	3.809	0.01	0.007	0	42.1	38.3	75.7	133	122	0	35	33
2014	9	12	17	58	19	0.804	-0.069	3.809	0.01	0.007	0	42.6	38.3	75.3	134	122	0	35	33
2014	9	12	18	8	19	0.771	-0.092	3.809	0.013	0.01	0	42.1	38.3	75.3	134	122	0	36	33
2014	9	12	18	18	19	0.758	-0.082	3.809	0.01	0.007	0	42.6	38.3	74	134	122	0	35	33
2014	9	12	18	28	19	0.817	-0.115	3.809	0.01	0.007	0	42.6	38.7	76.1	134	123	0	35	33
2014	9	12	18	38	19	0.787	-0.082	3.809	0.01	0.007	0	42.1	38.7	75.7	134	123	0	36	33
2014	9	12	18	48	19	0.81	-0.069	3.809	0.013	0.01	0	43	39.6	75.7	135	124	0	35	32
2014	9	12	18	58	19	0.791	-0.092	3.809	0.01	0.007	0	43	39.1	75.3	135	123	0	35	32
2014	9	12	19	8	19	0.784	-0.112	3.809	0.013	0.01	0	43	39.1	76.1	135	123	0	35	32
2014	9	12	19	18	19	0.814	-0.075	3.809	0.013	0.01	0	43	39.1	75.7	135	124	0	35	33
2014	9	12	19	28	19	0.843	-0.102	3.809	0.016	0.016	0	43.9	39.6	74.4	137	125	0	35	33
2014	9	12	19	38	19	0.784	-0.095	3.809	0.013	0.01	0	43.9	40	72.7	137	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	12	19	48	19	0.81	-0.102	3.809	0.01	0.007	0	44.3	40.9	75.3	138	127	0	35	32
2014	9	12	19	58	19	0.774	-0.066	3.809	0.013	0.01	0	44.7	40.4	75.3	139	126	0	35	32
2014	9	12	20	8	19	0.741	-0.082	3.809	0.013	0.01	0	44.7	40.4	75.3	139	127	0	35	33
2014	9	12	20	18	19	0.82	-0.105	3.809	0.01	0.007	0	44.3	40	75.7	138	126	0	35	33
2014	9	12	20	28	19	0.81	-0.075	3.809	0.013	0.01	0	44.3	40.4	74.8	138	127	0	35	33
2014	9	12	20	38	19	0.817	-0.092	3.809	0.01	0.007	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	12	20	48	19	0.817	-0.108	3.809	0.013	0.01	0	45.2	40.4	76.1	140	127	0	35	33
2014	9	12	20	58	19	0.784	-0.075	3.809	0.01	0.007	0	44.7	40.4	75.7	139	127	0	35	33
2014	9	12	21	8	19	0.814	-0.092	3.809	0.01	0.007	0	44.3	40.4	75.3	138	127	0	35	33
2014	9	12	21	18	19	0.833	-0.089	3.809	0.013	0.01	0	44.7	40.9	75.7	139	127	0	35	32
2014	9	12	21	28	19	0.781	-0.089	3.809	0.013	0.01	0	44.7	40.9	76.1	139	127	0	35	32
2014	9	12	21	38	19	0.764	-0.105	3.809	0.01	0.007	0	43.9	40.4	74.8	137	127	0	35	33
2014	9	12	21	48	19	0.784	-0.131	3.809	0.01	0.007	0	44.7	40	75.7	139	126	0	35	33
2014	9	12	21	58	19	0.817	-0.066	3.809	0.016	0.013	0	44.3	40	75.7	138	126	0	35	33
2014	9	12	22	8	19	0.804	-0.092	3.812	0.01	0.007	0	44.3	40.4	77	138	126	0	35	32
2014	9	12	22	18	19	0.814	-0.066	3.812	0.01	0.007	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	12	22	28	19	0.797	-0.075	3.812	0.016	0.013	0	44.7	40.4	76.5	139	127	0	35	33
2014	9	12	22	38	19	0.791	-0.075	3.812	0.013	0.01	0	44.7	40	77	139	127	0	35	34
2014	9	12	22	48	19	0.791	-0.092	3.812	0.013	0.01	0	45.2	40.4	76.1	139	127	0	34	33
2014	9	12	22	58	19	0.807	-0.075	3.812	0.013	0.01	0	44.7	40.4	77	139	127	0	35	33
2014	9	12	23	8	19	0.807	-0.121	3.812	0.013	0.01	0	44.7	40.4	76.5	139	127	0	35	33
2014	9	12	23	18	19	0.784	-0.085	3.812	0.01	0.007	0	44.7	40.4	77.4	139	127	0	35	33
2014	9	12	23	28	19	0.817	-0.108	3.812	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	12	23	38	19	0.804	-0.079	3.812	0.013	0.01	0	44.7	40.4	77	139	127	0	35	33
2014	9	12	23	48	19	0.787	-0.125	3.812	0.01	0.007	0	44.3	40.4	77.8	139	127	0	36	33
2014	9	12	23	58	19	0.83	-0.105	3.812	0.01	0.007	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	13	0	8	19	0.801	-0.098	3.812	0.013	0.01	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	13	0	18	19	0.784	-0.092	3.812	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	13	0	28	19	0.774	-0.075	3.812	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	13	0	38	19	0.82	-0.105	3.812	0.01	0.007	0	44.7	40.4	77	139	127	0	35	33
2014	9	13	0	48	19	0.81	-0.102	3.812	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	13	0	58	19	0.797	-0.085	3.812	0.013	0.01	0	44.3	40.4	77.8	139	127	0	36	33
2014	9	13	1	8	19	0.778	-0.095	3.812	0.01	0.007	0	44.7	40	78.7	139	126	0	35	33
2014	9	13	1	18	19	0.794	-0.075	3.816	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33
2014	9	13	1	28	19	0.807	-0.056	3.812	0.016	0.013	0	44.7	40.4	74.8	139	127	0	35	33
2014	9	13	1	38	19	0.764	-0.072	3.816	0.013	0.01	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	13	1	48	19	0.814	-0.089	3.816	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	13	1	58	19	0.781	-0.075	3.812	0.013	0.01	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	13	2	8	19	0.781	-0.089	3.812	0.013	0.01	0	44.3	40.4	77.8	138	127	0	35	33
2014	9	13	2	18	19	0.817	-0.092	3.816	0.01	0.007	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	13	2	28	19	0.814	-0.121	3.816	0.013	0.01	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	13	2	38	19	0.781	-0.092	3.816	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	13	2	48	19	0.787	-0.075	3.816	0.013	0.01	0	44.3	40.4	78.7	138	126	0	35	32
2014	9	13	2	58	19	0.823	-0.082	3.816	0.013	0.01	0	44.3	39.6	78.3	138	126	0	35	34
2014	9	13	3	8	19	0.794	-0.095	3.816	0.013	0.01	0	44.3	40	78.3	138	126	0	35	33
2014	9	13	3	18	19	0.787	-0.046	3.816	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	3	28	19	0.801	-0.072	3.812	0.013	0.01	0	43.4	40	78.7	137	126	0	36	33
2014	9	13	3	38	19	0.807	-0.089	3.816	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	13	3	48	19	0.797	-0.102	3.812	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	13	3	58	19	0.787	-0.059	3.816	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	13	4	8	19	0.814	-0.075	3.816	0.016	0.013	0	43.9	40	78.3	137	126	0	35	33
2014	9	13	4	18	19	0.827	-0.098	3.816	0.013	0.01	0	43.9	39.6	78.3	137	126	0	35	34
2014	9	13	4	28	19	0.784	-0.066	3.812	0.01	0.007	0	44.3	40	77.4	138	126	0	35	33
2014	9	13	4	38	19	0.771	-0.102	3.816	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	13	4	48	19	0.791	-0.098	3.816	0.01	0.007	0	43.9	40	77	137	126	0	35	33
2014	9	13	4	58	19	0.804	-0.095	3.816	0.01	0.007	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	13	5	8	19	0.774	-0.075	3.812	0.016	0.013	0	44.3	40	77.4	138	126	0	35	33
2014	9	13	5	18	19	0.784	-0.092	3.812	0.013	0.01	0	43.4	40	77	137	125	0	36	32
2014	9	13	5	28	19	0.827	-0.092	3.816	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	13	5	38	19	0.761	-0.092	3.816	0.013	0.01	0	43.9	39.6	77.8	137	125	0	35	33
2014	9	13	5	48	19	0.823	-0.089	3.816	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	13	5	58	19	0.801	-0.092	3.816	0.016	0.013	0	43.4	40	77	137	126	0	36	33
2014	9	13	6	8	19	0.791	-0.085	3.816	0.013	0.01	0	43.9	39.6	77	137	125	0	35	33
2014	9	13	6	18	19	0.778	-0.085	3.816	0.01	0.007	0	43	39.1	76.5	136	124	0	36	33
2014	9	13	6	28	19	0.791	-0.059	3.816	0.016	0.016	0	43.9	39.6	77.4	137	125	0	35	33
2014	9	13	6	38	19	0.774	-0.075	3.816	0.013	0.01	0	43	39.1	77.4	136	124	0	36	33
2014	9	13	6	48	19	0.791	-0.092	3.816	0.013	0.01	0	43	39.1	76.5	135	123	0	35	32
2014	9	13	6	58	19	0.83	-0.069	3.816	0.016	0.013	0	42.6	38.7	78.3	135	123	0	36	33
2014	9	13	7	8	19	0.797	-0.069	3.816	0.016	0.013	0	42.6	38.7	77.8	134	123	0	35	33
2014	9	13	7	18	19	0.833	-0.075	3.816	0.013	0.01	0	42.1	38.3	76.5	134	122	0	36	33
2014	9	13	7	28	19	0.768	-0.092	3.816	0.01	0.007	0	41.7	37.8	77.4	133	121	0	36	33
2014	9	13	7	38	19	0.807	-0.085	3.816	0.01	0.007	0	42.1	37.4	76.5	133	121	0	35	34
2014	9	13	7	48	19	0.807	-0.085	3.816	0.013	0.01	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	13	7	58	19	0.784	-0.075	3.816	0.013	0.01	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	13	8	8	19	0.804	-0.075	3.816	0.013	0.01	0	42.6	38.3	77.8	134	122	0	35	33
2014	9	13	8	18	19	0.764	-0.069	3.816	0.01	0.007	0	43	38.7	77	135	123	0	35	33
2014	9	13	8	28	19	0.768	-0.072	3.816	0.01	0.007	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	13	8	38	19	0.869	-0.082	3.816	0.01	0.007	0	41.7	37.4	77.4	132	120	0	35	33
2014	9	13	8	48	19	0.797	-0.095	3.816	0.013	0.01	0	41.3	37.4	76.1	132	121	0	36	34
2014	9	13	8	58	19	0.81	-0.082	3.816	0.01	0.007	0	41.7	37.4	77.4	132	120	0	35	33
2014	9	13	9	8	19	0.784	-0.092	3.816	0.01	0.007	0	41.3	37.8	77.4	132	121	0	36	33
2014	9	13	9	18	19	0.768	-0.092	3.816	0.01	0.007	0	41.7	37.8	77.4	132	120	0	35	32
2014	9	13	9	28	19	0.778	-0.069	3.816	0.01	0.007	0	41.3	37	77.4	131	120	0	35	34
2014	9	13	9	38	19	0.784	-0.082	3.816	0.01	0.007	0	42.1	38.3	77.8	133	122	0	35	33
2014	9	13	9	48	19	0.797	-0.085	3.816	0.013	0.01	0	41.7	37.8	77	132	121	0	35	33
2014	9	13	9	58	19	0.81	-0.089	3.816	0.01	0.007	0	40.9	37.4	77.4	131	120	0	36	33
2014	9	13	10	8	19	0.778	-0.085	3.819	0.016	0.013	0	40.9	37.4	78.3	131	120	0	36	33
2014	9	13	10	18	19	0.81	-0.075	3.816	0.013	0.01	0	41.3	37.4	78.3	131	120	0	35	33
2014	9	13	10	28	19	0.837	-0.085	3.816	0.01	0.007	0	40.9	37.4	78.3	131	120	0	36	33
2014	9	13	10	38	19	0.758	-0.108	3.816	0.01	0.007	0	42.1	38.3	77.8	133	122	0	35	33
2014	9	13	10	48	19	0.771	-0.075	3.816	0.01	0.007	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	13	10	58	19	0.83	-0.052	3.819	0.016	0.016	0	41.3	37.4	79.6	131	120	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	11	8	19	0.81	-0.052	3.816	0.013	0.01	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	13	11	18	19	0.801	-0.092	3.816	0.013	0.01	0	41.7	37.4	78.3	132	121	0	35	34
2014	9	13	11	28	19	0.791	-0.082	3.816	0.01	0.007	0	41.7	37.8	78.7	132	121	0	35	33
2014	9	13	11	38	19	0.801	-0.098	3.816	0.01	0.007	0	41.3	37.4	76.1	132	120	0	36	33
2014	9	13	11	48	19	0.81	-0.108	3.816	0.01	0.007	0	41.7	37.8	78.3	132	121	0	35	33
2014	9	13	11	58	19	0.801	-0.075	3.816	0.01	0.007	0	42.1	37.8	78.7	133	121	0	35	33
2014	9	13	12	8	19	0.794	-0.148	3.816	0.01	0.007	0	41.3	37.8	77	132	121	0	36	33
2014	9	13	12	18	19	0.758	-0.082	3.816	0.01	0.007	0	41.3	37.8	75.3	132	121	0	36	33
2014	9	13	12	28	19	0.774	-0.098	3.816	0.016	0.013	0	41.7	37.8	58.9	132	121	0	35	33
2014	9	13	12	38	19	0.778	-0.102	3.812	0.013	0.01	0	42.1	37.8	60.6	133	122	0	35	34
2014	9	13	12	48	19	0.764	-0.108	3.812	0.013	0.01	0	42.6	38.7	60.6	134	123	0	35	33
2014	9	13	12	58	19	0.768	-0.105	3.812	0.01	0.007	0	42.6	37.8	67.1	134	122	0	35	34
2014	9	13	13	8	19	0.784	-0.059	3.812	0.01	0.007	0	43	38.3	63.6	134	122	0	34	33
2014	9	13	13	18	19	0.768	-0.095	3.812	0.013	0.01	0	43	38.7	58	135	123	0	35	33
2014	9	13	13	28	19	0.751	-0.089	3.812	0.01	0.007	0	42.6	38.3	66.2	133	122	0	34	33
2014	9	13	13	38	19	0.784	-0.072	3.812	0.013	0.01	0	42.1	38.7	58.9	133	122	0	35	32
2014	9	13	13	48	19	0.791	-0.105	3.812	0.01	0.007	0	42.1	38.3	73.5	133	122	0	35	33
2014	9	13	13	58	19	0.791	-0.105	3.809	0.01	0.007	0	42.1	38.3	69.7	133	122	0	35	33
2014	9	13	14	8	19	0.794	-0.095	3.809	0.013	0.01	0	41.7	38.3	58.9	133	122	0	36	33
2014	9	13	14	18	19	0.807	-0.082	3.809	0.016	0.013	0	42.1	38.3	65.4	133	122	0	35	33
2014	9	13	14	28	19	0.794	-0.112	3.809	0.01	0.007	0	41.7	37.8	66.2	132	121	0	35	33
2014	9	13	14	38	19	0.794	-0.079	3.809	0.013	0.01	0	41.7	38.7	73.5	133	122	0	36	32
2014	9	13	14	48	19	0.774	-0.108	3.809	0.013	0.01	0	42.1	38.3	73.1	133	122	0	35	33
2014	9	13	14	58	19	0.823	-0.082	3.809	0.01	0.007	0	42.6	38.7	76.5	134	123	0	35	33
2014	9	13	15	8	19	0.814	-0.105	3.809	0.01	0.007	0	42.1	38.3	75.7	133	122	0	35	33
2014	9	13	15	18	19	0.787	-0.092	3.809	0.016	0.013	0	42.1	38.3	76.1	133	122	0	35	33
2014	9	13	15	28	19	0.817	-0.108	3.806	0.013	0.01	0	42.1	38.3	76.1	133	122	0	35	33
2014	9	13	15	38	19	0.751	-0.046	3.806	0.01	0.007	0	42.6	38.7	71.8	134	123	0	35	33
2014	9	13	15	48	19	0.797	-0.108	3.799	0.013	0.01	0	42.1	38.3	61.5	133	122	0	35	33
2014	9	13	15	58	19	0.771	-0.049	3.799	0.013	0.01	0	42.6	38.7	71.8	134	123	0	35	33
2014	9	13	16	8	19	0.787	-0.112	3.796	0.01	0.007	0	42.1	38.3	64.1	133	122	0	35	33
2014	9	13	16	18	19	0.774	-0.115	3.796	0.013	0.01	0	42.6	39.1	72.2	134	123	0	35	32
2014	9	13	16	28	19	0.774	-0.108	3.796	0.013	0.01	0	43	38.7	75.3	134	123	0	34	33
2014	9	13	16	38	19	0.791	-0.059	3.796	0.013	0.01	0	41.7	38.7	74.4	133	122	0	36	32
2014	9	13	16	48	19	0.804	-0.082	3.793	0.01	0.007	0	42.6	38.7	64.9	134	123	0	35	33
2014	9	13	16	58	19	0.804	-0.115	3.793	0.01	0.007	0	43	38.7	74.8	135	123	0	35	33
2014	9	13	17	8	19	0.774	-0.079	3.793	0.013	0.01	0	42.6	38.7	75.3	134	123	0	35	33
2014	9	13	17	18	19	0.82	-0.072	3.793	0.01	0.007	0	42.6	38.7	74.8	134	122	0	35	32
2014	9	13	17	28	19	0.791	-0.115	3.793	0.013	0.01	0	42.6	38.3	74	134	122	0	35	33
2014	9	13	17	38	19	0.81	-0.069	3.793	0.013	0.01	0	43	39.1	75.3	135	124	0	35	33
2014	9	13	17	48	19	0.807	-0.092	3.793	0.01	0.007	0	42.6	38.7	75.3	134	123	0	35	33
2014	9	13	17	58	19	0.774	-0.066	3.793	0.01	0.007	0	43	38.7	75.3	135	123	0	35	33
2014	9	13	18	8	19	0.797	-0.108	3.793	0.01	0.007	0	43.4	39.1	74.8	135	124	0	34	33
2014	9	13	18	18	19	0.807	-0.059	3.793	0.01	0.007	0	43.4	39.6	75.7	136	125	0	35	33
2014	9	13	18	28	19	0.778	-0.062	3.793	0.016	0.013	0	43.4	39.6	75.7	136	124	0	35	32
2014	9	13	18	38	19	0.823	-0.046	3.793	0.016	0.013	0	42.6	39.6	75.7	135	124	0	36	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	13	18	48	19	0.817	-0.062	3.793	0.016	0.016	0	43.4	40	74.4	136	125	0	35	32
2014	9	13	18	58	19	0.797	-0.131	3.793	0.016	0.013	0	43.4	39.6	75.3	137	125	0	36	33
2014	9	13	19	8	19	0.807	-0.092	3.793	0.016	0.013	0	43.9	39.6	75.3	137	125	0	35	33
2014	9	13	19	18	19	0.761	-0.069	3.793	0.016	0.013	0	43.9	40.4	75.7	137	126	0	35	32
2014	9	13	19	28	19	0.833	-0.092	3.793	0.013	0.01	0	44.7	40.4	75.3	138	126	0	34	32
2014	9	13	19	38	19	0.804	-0.059	3.796	0.01	0.007	0	44.3	40	74.4	138	126	0	35	33
2014	9	13	19	48	19	0.794	-0.062	3.796	0.016	0.013	0	44.7	40.9	74	139	127	0	35	32
2014	9	13	19	58	19	0.843	-0.075	3.796	0.01	0.007	0	44.3	40.4	74.4	138	127	0	35	33
2014	9	13	20	8	19	0.784	-0.075	3.796	0.01	0.007	0	44.3	40	74.4	138	126	0	35	33
2014	9	13	20	18	19	0.791	-0.066	3.796	0.01	0.007	0	44.3	40.4	74	138	127	0	35	33
2014	9	13	20	28	19	0.771	-0.082	3.796	0.013	0.01	0	44.7	40.9	74.4	139	127	0	35	32
2014	9	13	20	38	19	0.787	-0.072	3.796	0.013	0.01	0	44.3	40.4	73.5	138	127	0	35	33
2014	9	13	20	48	19	0.827	-0.075	3.796	0.016	0.013	0	44.7	40	74.8	139	126	0	35	33
2014	9	13	20	58	19	0.791	-0.105	3.799	0.01	0.007	0	44.3	40.9	74.4	139	127	0	36	32
2014	9	13	21	8	19	0.774	-0.105	3.799	0.01	0.007	0	44.3	40	74.4	138	126	0	35	33
2014	9	13	21	18	19	0.833	-0.105	3.802	0.013	0.01	0	44.3	40.4	74.8	138	127	0	35	33
2014	9	13	21	28	19	0.771	-0.102	3.802	0.01	0.007	0	43.9	39.6	74.8	137	126	0	35	34
2014	9	13	21	38	19	0.794	-0.069	3.802	0.01	0.007	0	44.7	40.9	74.8	139	127	0	35	32
2014	9	13	21	48	19	0.784	-0.092	3.802	0.013	0.01	0	44.7	40.4	75.3	139	127	0	35	33
2014	9	13	21	58	19	0.833	-0.128	3.806	0.013	0.01	0	44.3	40.4	74	138	127	0	35	33
2014	9	13	22	8	19	0.787	-0.033	3.802	0.013	0.01	0	44.3	40.9	71	139	127	0	36	32
2014	9	13	22	18	19	0.801	-0.092	3.806	0.01	0.007	0	44.3	40.4	75.7	138	127	0	35	33
2014	9	13	22	28	19	0.791	-0.072	3.806	0.01	0.007	0	44.7	40.4	75.3	139	127	0	35	33
2014	9	13	22	38	19	0.83	-0.105	3.806	0.013	0.01	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	13	22	48	19	0.778	-0.069	3.806	0.013	0.01	0	43.9	40	74.8	138	126	0	36	33
2014	9	13	22	58	19	0.768	-0.075	3.806	0.01	0.007	0	44.7	40	75.7	138	126	0	34	33
2014	9	13	23	8	19	0.83	-0.072	3.806	0.013	0.01	0	44.3	40.4	75.7	138	127	0	35	33
2014	9	13	23	18	19	0.784	-0.079	3.806	0.013	0.01	0	44.3	40.4	76.5	138	127	0	35	33
2014	9	13	23	28	19	0.817	-0.102	3.809	0.016	0.013	0	45.6	40.9	76.1	141	127	0	35	32
2014	9	13	23	38	19	0.82	-0.075	3.809	0.01	0.007	0	45.2	40.4	76.5	140	127	0	35	33
2014	9	13	23	48	19	0.801	-0.102	3.809	0.013	0.01	0	45.2	40	77	140	126	0	35	33
2014	9	13	23	58	19	0.804	-0.092	3.809	0.013	0.01	0	44.7	40	77.8	139	126	0	35	33
2014	9	14	0	8	19	0.784	-0.115	3.809	0.01	0.007	0	45.2	40.4	77.4	140	127	0	35	33
2014	9	14	0	18	19	0.768	-0.046	3.809	0.01	0.007	0	45.2	40.4	77	140	127	0	35	33
2014	9	14	0	28	19	0.797	-0.089	3.809	0.01	0.007	0	45.2	40.4	77.4	140	126	0	35	32
2014	9	14	0	38	19	0.83	-0.075	3.809	0.01	0.007	0	45.2	40	77.8	140	126	0	35	33
2014	9	14	0	48	19	0.791	-0.066	3.809	0.01	0.007	0	44.7	40.4	78.3	139	127	0	35	33
2014	9	14	0	58	19	0.797	-0.092	3.809	0.01	0.007	0	45.2	40	77.4	139	126	0	34	33
2014	9	14	1	8	19	0.797	-0.082	3.809	0.013	0.01	0	44.7	40	78.3	139	126	0	35	33
2014	9	14	1	18	19	0.774	-0.056	3.809	0.01	0.007	0	45.2	40.4	78.7	140	127	0	35	33
2014	9	14	1	28	19	0.82	-0.062	3.809	0.01	0.007	0	45.2	40	78.7	140	126	0	35	33
2014	9	14	1	38	19	0.807	-0.108	3.812	0.01	0.007	0	45.2	40.4	79.6	140	127	0	35	33
2014	9	14	1	48	19	0.797	-0.056	3.812	0.01	0.007	0	45.2	40.4	79.1	140	126	0	35	32
2014	9	14	1	58	19	0.797	-0.062	3.812	0.013	0.01	0	45.2	39.6	79.1	140	126	0	35	34
2014	9	14	2	8	19	0.814	-0.089	3.812	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	14	2	18	19	0.787	-0.102	3.812	0.016	0.013	0	44.3	40	79.6	139	126	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	2	28	19	0.866	-0.075	3.812	0.01	0.007	0	45.2	40	80	140	126	0	35	33
2014	9	14	2	38	19	0.791	-0.092	3.812	0.01	0.007	0	45.2	40	79.6	140	126	0	35	33
2014	9	14	2	48	19	0.83	-0.075	3.812	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	2	58	19	0.787	-0.102	3.812	0.013	0.01	0	44.7	40	80	139	126	0	35	33
2014	9	14	3	8	19	0.823	-0.089	3.812	0.013	0.01	0	44.7	39.6	78.7	139	125	0	35	33
2014	9	14	3	18	19	0.804	-0.102	3.812	0.01	0.007	0	44.3	39.6	80.4	138	125	0	35	33
2014	9	14	3	28	19	0.814	-0.072	3.812	0.016	0.013	0	44.7	39.6	79.1	139	125	0	35	33
2014	9	14	3	38	19	0.833	-0.098	3.812	0.01	0.007	0	43.9	40	80.4	138	125	0	36	32
2014	9	14	3	48	19	0.827	-0.105	3.812	0.01	0.007	0	44.3	40	80.8	138	125	0	35	32
2014	9	14	3	58	19	0.817	-0.059	3.812	0.01	0.007	0	44.3	39.6	80	138	125	0	35	33
2014	9	14	4	8	19	0.768	-0.108	3.812	0.013	0.01	0	44.7	40	80.8	139	126	0	35	33
2014	9	14	4	18	19	0.823	-0.105	3.812	0.01	0.007	0	45.2	40	80.4	139	126	0	34	33
2014	9	14	4	28	19	0.814	-0.079	3.812	0.01	0.007	0	45.2	40	78.3	140	126	0	35	33
2014	9	14	4	38	19	0.82	-0.112	3.812	0.01	0.007	0	44.7	40	80	139	126	0	35	33
2014	9	14	4	48	19	0.801	-0.072	3.812	0.013	0.01	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	14	4	58	19	0.837	-0.069	3.812	0.01	0.007	0	45.2	40.4	79.1	140	127	0	35	33
2014	9	14	5	8	19	0.784	-0.105	3.812	0.013	0.01	0	45.2	40.4	79.6	140	127	0	35	33
2014	9	14	5	18	19	0.82	-0.092	3.812	0.01	0.007	0	44.7	40	79.1	139	126	0	35	33
2014	9	14	5	28	19	0.797	-0.092	3.812	0.013	0.01	0	44.7	40	78.7	139	126	0	35	33
2014	9	14	5	38	19	0.794	-0.075	3.812	0.013	0.01	0	44.7	40	77	139	126	0	35	33
2014	9	14	5	48	19	0.787	-0.075	3.812	0.01	0.007	0	44.7	40	79.1	139	126	0	35	33
2014	9	14	5	58	19	0.823	-0.095	3.812	0.01	0.007	0	44.3	39.1	79.6	138	125	0	35	34
2014	9	14	6	8	19	0.755	-0.046	3.812	0.013	0.01	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	14	6	18	19	0.797	-0.069	3.812	0.013	0.01	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	14	6	28	19	0.853	-0.102	3.812	0.01	0.007	0	43.9	39.6	78.7	138	125	0	36	33
2014	9	14	6	38	19	0.81	-0.079	3.812	0.01	0.007	0	43.9	39.6	78.3	138	125	0	36	33
2014	9	14	6	48	19	0.81	-0.085	3.812	0.013	0.01	0	43.4	39.1	77.8	137	124	0	36	33
2014	9	14	6	58	19	0.814	-0.121	3.812	0.01	0.007	0	43.4	39.1	79.1	137	124	0	36	33
2014	9	14	7	8	19	0.784	-0.092	3.812	0.01	0.007	0	43	38.7	78.3	136	123	0	36	33
2014	9	14	7	18	19	0.833	-0.098	3.812	0.013	0.01	0	43	38.3	78.3	135	122	0	35	33
2014	9	14	7	28	19	0.791	-0.072	3.816	0.01	0.007	0	43.4	38.3	78.7	136	123	0	35	34
2014	9	14	7	38	19	0.791	-0.059	3.816	0.013	0.01	0	43	38.3	77.8	135	123	0	35	34
2014	9	14	7	48	19	0.791	-0.062	3.816	0.01	0.007	0	43	38.7	78.3	136	123	0	36	33
2014	9	14	7	58	19	0.801	-0.082	3.816	0.013	0.01	0	43.4	38.7	78.3	136	123	0	35	33
2014	9	14	8	8	19	0.814	-0.102	3.816	0.016	0.013	0	43	38.7	78.3	135	123	0	35	33
2014	9	14	8	18	19	0.814	-0.121	3.816	0.01	0.007	0	42.6	38.3	78.7	135	122	0	36	33
2014	9	14	8	28	19	0.879	-0.095	3.816	0.01	0.007	0	43	37.4	79.1	135	121	0	35	34
2014	9	14	8	38	19	0.778	-0.046	3.816	0.01	0.007	0	42.6	38.3	78.7	135	122	0	36	33
2014	9	14	8	48	19	0.807	-0.039	3.816	0.013	0.01	0	42.6	38.7	78.7	134	122	0	35	32
2014	9	14	8	58	19	0.833	-0.072	3.816	0.01	0.007	0	42.6	38.3	79.1	134	122	0	35	33
2014	9	14	9	8	19	0.827	-0.105	3.816	0.01	0.007	0	42.1	37.4	79.1	134	121	0	36	34
2014	9	14	9	18	19	0.823	-0.072	3.816	0.013	0.01	0	42.6	38.3	79.1	135	122	0	36	33
2014	9	14	9	28	19	0.81	-0.075	3.816	0.016	0.013	0	42.6	38.3	79.1	134	121	0	35	32
2014	9	14	9	38	19	0.837	-0.079	3.816	0.01	0.007	0	42.1	37.8	78.7	134	121	0	36	33
2014	9	14	9	48	19	0.801	-0.082	3.816	0.01	0.007	0	42.6	37.8	79.1	134	121	0	35	33
2014	9	14	9	58	19	0.794	-0.079	3.816	0.013	0.01	0	41.7	37.4	78.7	133	120	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	10	8	19	0.797	-0.102	3.816	0.01	0.007	0	42.6	38.3	78.7	134	122	0	35	33
2014	9	14	10	18	19	0.81	-0.056	3.816	0.01	0.007	0	41.7	37.8	78.7	133	121	0	36	33
2014	9	14	10	28	19	0.784	-0.098	3.816	0.01	0.007	0	42.1	37.8	79.1	134	121	0	36	33
2014	9	14	10	38	19	0.82	-0.079	3.816	0.016	0.016	0	43.9	39.6	78.7	137	125	0	35	33
2014	9	14	10	48	19	0.787	-0.036	3.816	0.013	0.01	0	42.6	38.3	79.6	135	122	0	36	33
2014	9	14	10	58	19	0.797	-0.056	3.816	0.01	0.007	0	42.6	38.3	79.6	134	121	0	35	32
2014	9	14	11	8	19	0.804	-0.102	3.816	0.01	0.007	0	42.1	37	79.6	133	120	0	35	34
2014	9	14	11	18	19	0.797	-0.075	3.816	0.013	0.01	0	42.1	37.8	78.3	133	121	0	35	33
2014	9	14	11	28	19	0.794	-0.079	3.816	0.016	0.013	0	41.7	37.4	80	133	120	0	36	33
2014	9	14	11	38	19	0.797	-0.062	3.816	0.01	0.007	0	42.6	37.8	78.3	134	121	0	35	33
2014	9	14	11	48	19	0.807	-0.092	3.816	0.01	0.007	0	42.6	38.3	76.1	134	121	0	35	32
2014	9	14	11	58	19	0.817	-0.095	3.816	0.013	0.01	0	43	38.3	63.6	135	122	0	35	33
2014	9	14	12	8	19	0.823	-0.089	3.816	0.013	0.01	0	41.7	37.4	65.8	133	120	0	36	33
2014	9	14	12	18	19	0.807	-0.089	3.812	0.013	0.01	0	42.6	38.3	66.7	134	121	0	35	32
2014	9	14	12	28	19	0.827	-0.072	3.812	0.01	0.007	0	45.2	40.4	60.6	140	127	0	35	33
2014	9	14	12	38	19	0.787	-0.118	3.816	0.01	0.007	0	43.4	39.1	70.5	137	124	0	36	33
2014	9	14	12	48	19	0.807	-0.092	3.816	0.016	0.013	0	43.9	39.6	76.1	137	125	0	35	33
2014	9	14	12	58	19	0.787	-0.079	3.812	0.016	0.013	0	43.4	39.1	67.5	137	124	0	36	33
2014	9	14	13	8	19	0.83	-0.105	3.816	0.01	0.007	0	43	39.1	67.1	136	124	0	36	33
2014	9	14	13	18	19	0.83	-0.118	3.816	0.016	0.013	0	43	38.7	77.4	135	123	0	35	33
2014	9	14	13	28	19	0.801	-0.108	3.816	0.01	0.007	0	42.6	38.7	79.6	135	123	0	36	33
2014	9	14	13	38	19	0.869	-0.121	3.816	0.013	0.01	0	43	37.8	80	135	122	0	35	34
2014	9	14	13	48	19	0.794	-0.059	3.812	0.01	0.007	0	43	38.3	65.4	135	122	0	35	33
2014	9	14	13	58	19	0.83	-0.085	3.816	0.01	0.007	0	43	38.3	79.6	135	122	0	35	33
2014	9	14	14	8	19	0.797	-0.092	3.816	0.01	0.007	0	43	38.7	79.6	135	123	0	35	33
2014	9	14	14	18	19	0.807	-0.092	3.816	0.01	0.007	0	43.4	39.6	78.7	136	124	0	35	32
2014	9	14	14	28	19	0.814	-0.089	3.816	0.01	0.007	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	14	14	38	19	0.784	-0.092	3.816	0.01	0.007	0	43	38.3	80	135	122	0	35	33
2014	9	14	14	48	19	0.784	-0.118	3.816	0.013	0.01	0	42.1	37.8	80.8	133	121	0	35	33
2014	9	14	14	58	19	0.81	-0.085	3.816	0.01	0.007	0	42.6	37.8	79.1	134	121	0	35	33
2014	9	14	15	8	19	0.768	-0.062	3.816	0.013	0.01	0	43	39.1	80	136	123	0	36	32
2014	9	14	15	18	19	0.823	-0.072	3.816	0.01	0.007	0	42.6	38.3	80	135	122	0	36	33
2014	9	14	15	28	19	0.771	-0.059	3.816	0.013	0.01	0	43	38.3	80.8	135	122	0	35	33
2014	9	14	15	38	19	0.771	-0.108	3.816	0.01	0.007	0	43.9	39.6	79.1	137	124	0	35	32
2014	9	14	15	48	19	0.833	-0.105	3.816	0.01	0.007	0	43	38.7	79.6	135	123	0	35	33
2014	9	14	15	58	19	0.807	-0.082	3.812	0.01	0.007	0	42.6	38.3	79.6	134	122	0	35	33
2014	9	14	16	8	19	0.853	-0.095	3.816	0.013	0.01	0	43.9	39.6	78.7	137	124	0	35	32
2014	9	14	16	18	19	0.817	-0.118	3.816	0.01	0.007	0	43.4	39.6	77.8	136	124	0	35	32
2014	9	14	16	28	19	0.791	-0.092	3.812	0.01	0.007	0	43.4	39.6	78.7	136	124	0	35	32
2014	9	14	16	38	19	0.787	-0.108	3.812	0.013	0.01	0	43.4	39.1	78.3	136	124	0	35	33
2014	9	14	16	48	19	0.791	-0.089	3.812	0.01	0.007	0	42.6	38.3	78.3	135	122	0	36	33
2014	9	14	16	58	19	0.82	-0.092	3.812	0.013	0.01	0	43.4	37.8	79.6	135	122	0	34	34
2014	9	14	17	8	19	0.787	-0.118	3.812	0.01	0.007	0	43.4	39.1	79.1	136	124	0	35	33
2014	9	14	17	18	19	0.807	-0.089	3.812	0.013	0.01	0	43.9	39.1	77.8	136	124	0	34	33
2014	9	14	17	28	19	0.768	-0.075	3.812	0.016	0.013	0	43	38.7	78.3	136	123	0	36	33
2014	9	14	17	38	19	0.778	-0.125	3.812	0.013	0.01	0	43	39.1	78.3	135	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	14	17	48	19	0.784	-0.098	3.812	0.01	0.007	0	43.4	38.7	77.4	136	123	0	35	33
2014	9	14	17	58	19	0.82	-0.102	3.812	0.013	0.01	0	43.4	38.7	77.4	136	123	0	35	33
2014	9	14	18	8	19	0.794	-0.075	3.812	0.01	0.007	0	43.4	38.7	77.8	136	123	0	35	33
2014	9	14	18	18	19	0.794	-0.102	3.812	0.016	0.016	0	43	38.3	80	135	122	0	35	33
2014	9	14	18	28	19	0.784	-0.079	3.816	0.013	0.01	0	43.4	37.8	80	136	122	0	35	34
2014	9	14	18	38	19	0.82	-0.069	3.816	0.01	0.007	0	43.9	39.1	80.4	137	124	0	35	33
2014	9	14	18	48	19	0.83	-0.092	3.816	0.016	0.013	0	43.4	39.1	79.6	136	123	0	35	32
2014	9	14	18	58	19	0.801	-0.052	3.816	0.01	0.007	0	44.3	40	80	138	125	0	35	32
2014	9	14	19	8	19	0.82	-0.079	3.816	0.01	0.007	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	14	19	18	19	0.82	-0.112	3.816	0.01	0.007	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	14	19	28	19	0.823	-0.075	3.816	0.01	0.007	0	44.7	40	80	139	126	0	35	33
2014	9	14	19	38	19	0.83	-0.059	3.816	0.01	0.007	0	44.7	39.6	80	139	126	0	35	34
2014	9	14	19	48	19	0.771	-0.059	3.816	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	14	19	58	19	0.791	-0.105	3.816	0.013	0.01	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	14	20	8	19	0.787	-0.066	3.816	0.013	0.01	0	44.3	40	80.4	139	125	0	36	32
2014	9	14	20	18	19	0.823	-0.075	3.816	0.013	0.01	0	44.7	40	80	139	126	0	35	33
2014	9	14	20	28	19	0.804	-0.095	3.816	0.013	0.01	0	44.7	40.4	80	139	126	0	35	32
2014	9	14	20	38	19	0.791	-0.092	3.816	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	14	20	48	19	0.817	-0.072	3.816	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	14	20	58	19	0.823	-0.141	3.816	0.013	0.01	0	44.7	40	79.6	139	126	0	35	33
2014	9	14	21	8	19	0.82	-0.102	3.816	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	21	18	19	0.778	-0.095	3.816	0.01	0.007	0	44.7	40	80	139	126	0	35	33
2014	9	14	21	28	19	0.787	-0.059	3.816	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	21	38	19	0.764	-0.098	3.816	0.013	0.01	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	21	48	19	0.797	-0.082	3.816	0.01	0.007	0	45.2	40.9	81.3	140	127	0	35	32
2014	9	14	21	58	19	0.817	-0.098	3.816	0.01	0.007	0	44.7	40	80.8	139	126	0	35	33
2014	9	14	22	8	19	0.804	-0.062	3.816	0.01	0.007	0	44.7	40.4	80.4	139	127	0	35	33
2014	9	14	22	18	19	0.797	-0.075	3.819	0.01	0.007	0	45.2	40.9	81.3	140	127	0	35	32
2014	9	14	22	28	19	0.846	-0.105	3.819	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	22	38	19	0.856	-0.098	3.819	0.013	0.01	0	44.7	40	80.8	139	126	0	35	33
2014	9	14	22	48	19	0.817	-0.098	3.819	0.01	0.007	0	44.7	40	80.8	139	126	0	35	33
2014	9	14	22	58	19	0.837	-0.062	3.819	0.01	0.007	0	44.3	40	81.7	139	126	0	36	33
2014	9	14	23	8	19	0.82	-0.112	3.819	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	23	18	19	0.823	-0.089	3.819	0.01	0.007	0	44.7	40.4	81.3	139	126	0	35	32
2014	9	14	23	28	19	0.843	-0.085	3.819	0.013	0.01	0	45.2	40.9	80.4	140	127	0	35	32
2014	9	14	23	38	19	0.82	-0.102	3.819	0.01	0.007	0	44.7	40	80.4	139	126	0	35	33
2014	9	14	23	48	19	0.781	-0.108	3.819	0.01	0.007	0	45.2	40	78.3	140	127	0	35	34
2014	9	14	23	58	19	0.83	-0.082	3.819	0.013	0.01	0	44.7	40	80	139	126	0	35	33
2014	9	15	0	8	19	0.817	-0.089	3.819	0.016	0.013	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	15	0	18	19	0.83	-0.072	3.819	0.016	0.013	0	45.2	40.4	79.1	140	127	0	35	33
2014	9	15	0	28	19	0.84	-0.125	3.819	0.013	0.01	0	44.7	40	80.8	139	126	0	35	33
2014	9	15	0	38	19	0.801	-0.066	3.819	0.01	0.007	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	15	0	48	19	0.827	-0.108	3.819	0.013	0.01	0	44.7	40	80	139	126	0	35	33
2014	9	15	0	58	19	0.817	-0.069	3.819	0.01	0.007	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	15	1	8	19	0.866	-0.082	3.819	0.016	0.013	0	45.2	40	79.6	140	126	0	35	33
2014	9	15	1	18	19	0.804	-0.102	3.819	0.01	0.007	0	45.2	40.4	80	140	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	1	28	19	0.814	-0.098	3.819	0.013	0.01	0	45.2	40.4	80.8	140	127	0	35	33
2014	9	15	1	38	19	0.827	-0.102	3.819	0.016	0.013	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	15	1	48	19	0.804	-0.052	3.819	0.013	0.01	0	44.3	40	79.6	139	126	0	36	33
2014	9	15	1	58	19	0.774	-0.066	3.819	0.01	0.007	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	15	2	8	19	0.764	-0.062	3.819	0.01	0.007	0	45.6	40.4	79.1	141	127	0	35	33
2014	9	15	2	18	19	0.794	-0.069	3.819	0.01	0.007	0	45.2	40	79.1	140	127	0	35	34
2014	9	15	2	28	19	0.83	-0.072	3.819	0.013	0.01	0	45.2	40.4	77.8	140	127	0	35	33
2014	9	15	2	38	19	0.856	-0.066	3.819	0.01	0.007	0	44.7	40.4	78.7	139	126	0	35	32
2014	9	15	2	48	19	0.837	-0.105	3.819	0.01	0.007	0	44.7	40	78.7	139	126	0	35	33
2014	9	15	2	58	19	0.83	-0.085	3.819	0.013	0.01	0	44.7	40	78.7	139	126	0	35	33
2014	9	15	3	8	19	0.807	-0.108	3.819	0.013	0.01	0	44.7	40.4	79.1	139	126	0	35	32
2014	9	15	3	18	19	0.843	-0.079	3.819	0.013	0.01	0	44.7	40	77.8	139	126	0	35	33
2014	9	15	3	28	19	0.81	-0.102	3.819	0.01	0.007	0	44.7	40	78.3	139	126	0	35	33
2014	9	15	3	38	19	0.807	-0.092	3.819	0.01	0.007	0	44.7	40	78.7	139	126	0	35	33
2014	9	15	3	48	19	0.794	-0.069	3.819	0.013	0.01	0	44.7	40	78.3	139	126	0	35	33
2014	9	15	3	58	19	0.787	-0.079	3.819	0.013	0.01	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	15	4	8	19	0.774	-0.082	3.822	0.01	0.007	0	43.9	39.6	78.3	138	125	0	36	33
2014	9	15	4	18	19	0.797	-0.062	3.822	0.01	0.007	0	43.9	39.6	78.7	138	125	0	36	33
2014	9	15	4	28	19	0.781	-0.082	3.822	0.013	0.01	0	44.3	40	78.7	138	125	0	35	32
2014	9	15	4	38	19	0.804	-0.102	3.822	0.013	0.01	0	44.7	40	77	139	126	0	35	33
2014	9	15	4	48	19	0.84	-0.085	3.822	0.01	0.007	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	15	4	58	19	0.81	-0.105	3.822	0.01	0.007	0	43.4	39.6	78.3	137	125	0	36	33
2014	9	15	5	8	19	0.804	-0.062	3.822	0.01	0.007	0	43.9	40	78.3	138	126	0	36	33
2014	9	15	5	18	19	0.768	-0.082	3.822	0.01	0.007	0	44.7	40	77.4	139	126	0	35	33
2014	9	15	5	28	19	0.81	-0.092	3.822	0.01	0.007	0	44.7	40	77	139	126	0	35	33
2014	9	15	5	38	19	0.814	-0.102	3.822	0.01	0.007	0	43.9	39.6	76.1	138	125	0	36	33
2014	9	15	5	48	19	0.804	-0.085	3.822	0.01	0.007	0	43.9	39.6	77	138	125	0	36	33
2014	9	15	5	58	19	0.823	-0.089	3.822	0.013	0.01	0	44.3	39.6	76.1	138	125	0	35	33
2014	9	15	6	8	19	0.794	-0.079	3.822	0.013	0.01	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	15	6	18	19	0.823	-0.118	3.822	0.01	0.007	0	43.9	39.6	77	138	125	0	36	33
2014	9	15	6	28	19	0.823	-0.079	3.822	0.013	0.01	0	44.3	39.6	77	138	125	0	35	33
2014	9	15	6	38	19	0.817	-0.056	3.822	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	15	6	48	19	0.827	-0.082	3.822	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	15	6	58	19	0.784	-0.056	3.822	0.01	0.007	0	43.9	38.7	76.1	137	123	0	35	33
2014	9	15	7	8	19	0.797	-0.085	3.822	0.013	0.01	0	43	38.3	76.5	135	122	0	35	33
2014	9	15	7	18	19	0.823	-0.082	3.822	0.01	0.007	0	43	38.3	77	135	122	0	35	33
2014	9	15	7	28	19	0.797	-0.079	3.822	0.01	0.007	0	42.6	38.3	77	135	122	0	36	33
2014	9	15	7	38	19	0.771	-0.092	3.822	0.013	0.01	0	43	38.3	76.5	135	122	0	35	33
2014	9	15	7	48	19	0.807	-0.089	3.825	0.013	0.01	0	42.6	38.3	75.7	134	122	0	35	33
2014	9	15	7	58	19	0.814	-0.108	3.825	0.013	0.01	0	42.6	38.3	75.7	135	122	0	36	33
2014	9	15	8	8	19	0.823	-0.079	3.825	0.013	0.01	0	42.6	37.4	76.1	134	120	0	35	33
2014	9	15	8	18	19	0.846	-0.079	3.825	0.013	0.01	0	42.1	37.4	77	133	120	0	35	33
2014	9	15	8	28	19	0.791	-0.082	3.825	0.01	0.007	0	42.1	37.8	76.5	134	121	0	36	33
2014	9	15	8	38	19	0.84	-0.075	3.825	0.016	0.013	0	42.6	38.3	75.7	134	122	0	35	33
2014	9	15	8	48	19	0.778	-0.075	3.825	0.01	0.007	0	42.6	38.3	75.3	135	122	0	36	33
2014	9	15	8	58	19	0.794	-0.082	3.825	0.01	0.007	0	42.6	38.3	76.1	134	122	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	9	8	19	0.81	-0.079	3.825	0.013	0.01	0	42.6	37.8	76.5	134	121	0	35	33
2014	9	15	9	18	19	0.83	-0.069	3.825	0.016	0.013	0	42.1	37.8	75.7	134	121	0	36	33
2014	9	15	9	28	19	0.791	-0.082	3.825	0.016	0.013	0	42.6	38.3	74.8	134	122	0	35	33
2014	9	15	9	38	19	0.83	-0.092	3.825	0.01	0.007	0	42.6	38.3	77	134	122	0	35	33
2014	9	15	9	48	19	0.853	-0.062	3.825	0.01	0.007	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	15	9	58	19	0.794	-0.112	3.825	0.01	0.007	0	42.1	38.3	77	134	122	0	36	33
2014	9	15	10	8	19	0.817	-0.098	3.825	0.013	0.01	0	43	38.3	76.1	135	123	0	35	34
2014	9	15	10	18	19	0.843	-0.092	3.825	0.01	0.007	0	43	38.7	76.1	135	123	0	35	33
2014	9	15	10	28	19	0.84	-0.098	3.825	0.013	0.01	0	42.6	38.3	76.1	134	122	0	35	33
2014	9	15	10	38	19	0.833	-0.075	3.825	0.01	0.007	0	41.7	37.8	77	133	121	0	36	33
2014	9	15	10	48	19	0.771	-0.102	3.825	0.01	0.007	0	43	38.7	76.1	135	123	0	35	33
2014	9	15	10	58	19	0.83	-0.079	3.825	0.01	0.007	0	42.6	38.3	76.1	134	122	0	35	33
2014	9	15	11	8	19	0.82	-0.118	3.825	0.013	0.01	0	43.4	38.7	76.1	136	124	0	35	34
2014	9	15	11	18	19	0.784	-0.052	3.825	0.016	0.013	0	43	38.7	77.4	136	123	0	36	33
2014	9	15	11	28	19	0.83	-0.079	3.825	0.01	0.007	0	42.1	38.3	76.1	134	122	0	36	33
2014	9	15	11	38	19	0.794	-0.069	3.825	0.01	0.007	0	41.7	37.8	77	132	121	0	35	33
2014	9	15	11	48	19	0.81	-0.092	3.822	0.01	0.007	0	41.7	37.4	76.5	132	121	0	35	34
2014	9	15	11	58	19	0.823	-0.082	3.825	0.01	0.007	0	42.1	38.7	76.5	133	122	0	35	32
2014	9	15	12	8	19	0.827	-0.075	3.825	0.013	0.01	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	15	12	18	19	0.83	-0.066	3.825	0.013	0.01	0	42.1	37.8	77.4	133	121	0	35	33
2014	9	15	12	28	19	0.823	-0.082	3.825	0.013	0.01	0	42.1	38.7	76.5	133	123	0	35	33
2014	9	15	12	38	19	0.814	-0.098	3.825	0.013	0.01	0	41.3	38.3	76.5	132	122	0	36	33
2014	9	15	12	48	19	0.82	-0.105	3.825	0.01	0.007	0	42.1	38.3	77	133	122	0	35	33
2014	9	15	12	58	19	0.85	-0.108	3.825	0.016	0.013	0	42.1	38.7	77.8	133	123	0	35	33
2014	9	15	13	8	19	0.787	-0.102	3.825	0.01	0.007	0	41.7	38.7	78.3	133	123	0	36	33
2014	9	15	13	18	19	0.801	-0.085	3.825	0.01	0.007	0	42.1	38.3	78.3	133	122	0	35	33
2014	9	15	13	28	19	0.804	-0.069	3.822	0.013	0.01	0	42.6	39.1	55.9	134	123	0	35	32
2014	9	15	13	38	19	0.801	-0.092	3.822	0.016	0.013	0	42.1	39.1	60.2	134	124	0	36	33
2014	9	15	13	48	19	0.801	-0.118	3.822	0.01	0.007	0	42.6	38.7	64.5	134	123	0	35	33
2014	9	15	13	58	19	0.794	-0.075	3.822	0.01	0.007	0	42.6	38.7	62.8	134	123	0	35	33
2014	9	15	14	8	19	0.787	-0.072	3.822	0.013	0.01	0	42.6	39.6	64.5	134	124	0	35	32
2014	9	15	14	18	19	0.797	-0.082	3.822	0.01	0.007	0	42.1	38.7	61.9	134	123	0	36	33
2014	9	15	14	28	19	0.84	-0.108	3.822	0.013	0.01	0	42.6	38.7	61.1	133	123	0	34	33
2014	9	15	14	38	19	0.84	-0.092	3.822	0.016	0.013	0	42.6	39.1	60.6	134	124	0	35	33
2014	9	15	14	48	19	0.791	-0.072	3.822	0.013	0.01	0	42.6	38.7	63.6	134	123	0	35	33
2014	9	15	14	58	19	0.771	-0.095	3.822	0.013	0.01	0	43.4	40	60.6	136	126	0	35	33
2014	9	15	15	8	19	0.781	-0.082	3.819	0.01	0.007	0	43.4	39.6	60.2	136	125	0	35	33
2014	9	15	15	18	19	0.82	-0.085	3.822	0.01	0.007	0	42.6	39.1	66.7	134	124	0	35	33
2014	9	15	15	28	19	0.774	-0.075	3.819	0.01	0.007	0	42.6	39.1	58.5	134	124	0	35	33
2014	9	15	15	38	19	0.804	-0.052	3.819	0.013	0.01	0	42.6	39.6	59.3	135	125	0	36	33
2014	9	15	15	48	19	0.801	-0.052	3.819	0.013	0.01	0	42.6	39.6	55.5	135	125	0	36	33
2014	9	15	15	58	19	0.804	-0.115	3.819	0.016	0.013	0	43	39.6	65.4	135	124	0	35	32
2014	9	15	16	8	19	0.804	-0.118	3.819	0.01	0.007	0	43	39.6	58.9	135	124	0	35	32
2014	9	15	16	18	19	0.774	-0.108	3.819	0.01	0.007	0	42.1	38.7	57.2	133	123	0	35	33
2014	9	15	16	28	19	0.778	-0.108	3.819	0.013	0.01	0	42.1	37.8	75.7	133	122	0	35	34
2014	9	15	16	38	19	0.794	-0.085	3.819	0.01	0.007	0	42.6	39.1	80	134	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	15	16	48	19	0.787	-0.095	3.819	0.01	0.007	0	42.6	39.6	77.4	134	124	0	35	32
2014	9	15	16	58	19	0.82	-0.069	3.819	0.016	0.013	0	43	38.7	80	135	123	0	35	33
2014	9	15	17	8	19	0.794	-0.092	3.819	0.01	0.007	0	42.6	38.7	80.4	134	123	0	35	33
2014	9	15	17	18	19	0.801	-0.092	3.819	0.013	0.01	0	42.1	38.7	80	133	123	0	35	33
2014	9	15	17	28	19	0.787	-0.108	3.819	0.01	0.007	0	42.6	39.1	80	134	124	0	35	33
2014	9	15	17	38	19	0.81	-0.095	3.819	0.01	0.007	0	42.6	38.7	80.8	134	123	0	35	33
2014	9	15	17	48	19	0.86	-0.108	3.819	0.01	0.007	0	42.1	38.7	80.8	133	123	0	35	33
2014	9	15	17	58	19	0.82	-0.105	3.819	0.01	0.007	0	42.1	38.3	80.8	133	122	0	35	33
2014	9	15	18	8	19	0.741	-0.082	3.819	0.01	0.007	0	42.6	38.7	81.3	134	123	0	35	33
2014	9	15	18	18	19	0.804	-0.098	3.819	0.013	0.01	0	42.1	38.3	80.8	133	122	0	35	33
2014	9	15	18	28	19	0.83	-0.075	3.819	0.013	0.01	0	42.1	38.7	81.3	133	123	0	35	33
2014	9	15	18	38	19	0.801	-0.059	3.819	0.013	0.01	0	42.6	38.7	80	134	123	0	35	33
2014	9	15	18	48	19	0.797	-0.092	3.819	0.013	0.01	0	42.6	38.7	80.8	134	123	0	35	33
2014	9	15	18	58	19	0.797	-0.066	3.819	0.013	0.01	0	42.1	39.6	81.3	134	124	0	36	32
2014	9	15	19	8	19	0.797	-0.072	3.822	0.013	0.01	0	42.6	39.6	80.8	134	124	0	35	32
2014	9	15	19	18	19	0.814	-0.075	3.819	0.01	0.007	0	43	40	80.8	135	125	0	35	32
2014	9	15	19	28	19	0.823	-0.082	3.822	0.013	0.01	0	42.6	39.6	80.8	135	125	0	36	33
2014	9	15	19	38	19	0.807	-0.089	3.822	0.013	0.01	0	43.9	40.4	81.3	137	126	0	35	32
2014	9	15	19	48	19	0.807	-0.075	3.822	0.01	0.007	0	43.9	39.6	81.7	137	126	0	35	34
2014	9	15	19	58	19	0.833	-0.118	3.822	0.013	0.01	0	43.9	40	82.1	137	126	0	35	33
2014	9	15	20	8	19	0.82	-0.046	3.822	0.013	0.01	0	43.9	40	81.7	137	126	0	35	33
2014	9	15	20	18	19	0.791	-0.082	3.822	0.01	0.007	0	43.9	40	81.3	137	126	0	35	33
2014	9	15	20	28	19	0.804	-0.056	3.822	0.013	0.01	0	43.4	40	81.7	136	126	0	35	33
2014	9	15	20	38	19	0.843	-0.102	3.822	0.01	0.007	0	43	39.6	81.3	135	125	0	35	33
2014	9	15	20	48	19	0.827	-0.052	3.822	0.01	0.007	0	44.3	40	81.3	138	125	0	35	32
2014	9	15	20	58	19	0.787	-0.102	3.822	0.01	0.007	0	44.3	40	82.1	138	125	0	35	32
2014	9	15	21	8	19	0.797	-0.115	3.822	0.013	0.01	0	43.9	39.1	80.8	137	124	0	35	33
2014	9	15	21	18	19	0.814	-0.115	3.822	0.01	0.007	0	43.9	39.6	80.8	137	125	0	35	33
2014	9	15	21	28	19	0.81	-0.085	3.822	0.013	0.01	0	43.9	38.7	81.3	137	124	0	35	34
2014	9	15	21	38	19	0.807	-0.082	3.822	0.01	0.007	0	43.9	39.1	81.7	137	124	0	35	33
2014	9	15	21	48	19	0.846	-0.098	3.822	0.013	0.01	0	44.3	39.6	80.8	138	125	0	35	33
2014	9	15	21	58	19	0.797	-0.049	3.822	0.01	0.007	0	44.3	39.6	80.4	138	125	0	35	33
2014	9	15	22	8	19	0.794	-0.095	3.822	0.013	0.01	0	43.9	39.6	80.8	137	125	0	35	33
2014	9	15	22	18	19	0.771	-0.112	3.822	0.013	0.01	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	15	22	28	19	0.833	-0.075	3.822	0.013	0.01	0	44.3	39.6	80.4	138	125	0	35	33
2014	9	15	22	38	19	0.814	-0.121	3.822	0.013	0.01	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	15	22	48	19	0.738	-0.118	3.822	0.013	0.01	0	43.4	40	80.8	137	125	0	36	32
2014	9	15	22	58	19	0.801	-0.102	3.822	0.013	0.01	0	44.3	39.6	80.4	138	125	0	35	33
2014	9	15	23	8	19	0.807	-0.089	3.822	0.01	0.007	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	15	23	18	19	0.814	-0.092	3.822	0.016	0.013	0	44.3	39.6	80.8	138	125	0	35	33
2014	9	15	23	28	19	0.82	-0.092	3.822	0.01	0.007	0	43.9	39.1	80	137	124	0	35	33
2014	9	15	23	38	19	0.791	-0.075	3.822	0.013	0.01	0	43.4	39.6	80.8	137	125	0	36	33
2014	9	15	23	48	19	0.801	-0.079	3.822	0.016	0.013	0	44.3	39.6	79.6	137	125	0	34	33
2014	9	15	23	58	19	0.771	-0.079	3.822	0.01	0.007	0	44.3	39.6	80.4	138	125	0	35	33
2014	9	16	0	8	19	0.791	-0.075	3.822	0.016	0.013	0	44.7	40	79.6	138	126	0	34	33
2014	9	16	0	18	19	0.82	-0.085	3.822	0.01	0.007	0	44.3	40	79.1	138	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	0	28	19	0.817	-0.079	3.825	0.01	0.007	0	44.3	40	77.8	138	126	0	35	33
2014	9	16	0	38	19	0.817	-0.121	3.822	0.013	0.01	0	44.7	39.6	79.1	138	125	0	34	33
2014	9	16	0	48	19	0.778	-0.069	3.822	0.013	0.01	0	44.3	40	79.1	138	125	0	35	32
2014	9	16	0	58	19	0.823	-0.089	3.822	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	16	1	8	19	0.768	-0.082	3.822	0.013	0.01	0	43.9	39.6	77.8	138	126	0	36	34
2014	9	16	1	18	19	0.817	-0.062	3.822	0.01	0.007	0	44.7	40	77.8	139	126	0	35	33
2014	9	16	1	28	19	0.801	-0.075	3.822	0.013	0.01	0	43.9	40	77	138	125	0	36	32
2014	9	16	1	38	19	0.827	-0.079	3.822	0.013	0.01	0	44.3	39.6	77.8	138	125	0	35	33
2014	9	16	1	48	19	0.797	-0.089	3.822	0.01	0.007	0	44.3	39.6	77.8	138	125	0	35	33
2014	9	16	1	58	19	0.823	-0.089	3.822	0.013	0.01	0	44.3	40	76.1	138	126	0	35	33
2014	9	16	2	8	19	0.827	-0.085	3.825	0.016	0.013	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	16	2	18	19	0.771	-0.075	3.825	0.01	0.007	0	44.3	40	78.3	138	126	0	35	33
2014	9	16	2	28	19	0.804	-0.112	3.825	0.01	0.007	0	44.3	40	78.3	138	125	0	35	32
2014	9	16	2	38	19	0.82	-0.069	3.825	0.016	0.013	0	43.9	39.6	78.7	137	125	0	35	33
2014	9	16	2	48	19	0.856	-0.108	3.825	0.013	0.01	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	16	2	58	19	0.768	-0.102	3.825	0.01	0.007	0	44.3	39.1	77.4	138	125	0	35	34
2014	9	16	3	8	19	0.82	-0.092	3.825	0.01	0.007	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	16	3	18	19	0.807	-0.089	3.825	0.01	0.007	0	43.9	40	77.8	138	125	0	36	32
2014	9	16	3	28	19	0.823	-0.059	3.825	0.01	0.007	0	43.9	39.1	77.8	137	124	0	35	33
2014	9	16	3	38	19	0.823	-0.092	3.825	0.01	0.007	0	43.9	39.1	77.8	137	124	0	35	33
2014	9	16	3	48	19	0.794	-0.085	3.825	0.01	0.007	0	43.9	39.6	77.8	137	124	0	35	32
2014	9	16	3	58	19	0.846	-0.069	3.825	0.01	0.007	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	16	4	8	19	0.817	-0.072	3.825	0.01	0.007	0	43.9	38.7	76.5	137	124	0	35	34
2014	9	16	4	18	19	0.837	-0.105	3.829	0.01	0.007	0	43	39.1	77.4	136	124	0	36	33
2014	9	16	4	28	19	0.81	-0.079	3.829	0.013	0.01	0	43.9	39.6	77	137	124	0	35	32
2014	9	16	4	38	19	0.83	-0.092	3.825	0.01	0.007	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	16	4	48	19	0.837	-0.089	3.829	0.01	0.007	0	43.9	39.6	76.5	137	125	0	35	33
2014	9	16	4	58	19	0.84	-0.092	3.829	0.013	0.01	0	44.3	40	77.4	138	125	0	35	32
2014	9	16	5	8	19	0.801	-0.066	3.829	0.013	0.01	0	43.9	39.6	77	137	125	0	35	33
2014	9	16	5	18	19	0.876	-0.075	3.829	0.013	0.01	0	43.4	39.1	77	137	125	0	36	34
2014	9	16	5	28	19	0.797	-0.102	3.829	0.01	0.007	0	43.9	39.6	77	137	125	0	35	33
2014	9	16	5	38	19	0.801	-0.075	3.829	0.013	0.01	0	43.9	39.6	76.5	138	125	0	36	33
2014	9	16	5	48	19	0.84	-0.089	3.829	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	16	5	58	19	0.823	-0.072	3.829	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	16	6	8	19	0.81	-0.075	3.829	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	16	6	18	19	0.807	-0.072	3.829	0.016	0.016	0	43.4	38.7	76.5	136	123	0	35	33
2014	9	16	6	28	19	0.827	-0.095	3.829	0.013	0.01	0	43.4	38.7	76.1	136	123	0	35	33
2014	9	16	6	38	19	0.84	-0.089	3.829	0.01	0.007	0	43	38.3	76.1	135	122	0	35	33
2014	9	16	6	48	19	0.797	-0.102	3.832	0.013	0.01	0	43.4	38.3	75.7	136	122	0	35	33
2014	9	16	6	58	19	0.846	-0.085	3.835	0.01	0.007	0	43	38.3	76.1	135	121	0	35	32
2014	9	16	7	8	19	0.791	-0.092	3.835	0.013	0.01	0	43	37.4	75.7	135	120	0	35	33
2014	9	16	7	18	19	0.81	-0.108	3.835	0.01	0.007	0	42.1	37.4	76.1	133	120	0	35	33
2014	9	16	7	28	19	0.856	-0.108	3.835	0.01	0.007	0	42.1	37.4	75.7	134	120	0	36	33
2014	9	16	7	38	19	0.82	-0.079	3.839	0.01	0.007	0	42.1	38.3	76.1	134	122	0	36	33
2014	9	16	7	48	19	0.791	-0.089	3.839	0.013	0.01	0	43	38.3	76.1	135	122	0	35	33
2014	9	16	7	58	19	0.794	-0.072	3.839	0.013	0.01	0	41.3	38.3	76.1	132	122	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	8	8	19	0.817	-0.121	3.839	0.016	0.016	0	41.7	37.8	77	132	122	0	35	34
2014	9	16	8	18	19	0.823	-0.066	3.839	0.016	0.013	0	42.1	38.3	76.5	133	122	0	35	33
2014	9	16	8	28	19	0.794	-0.075	3.839	0.013	0.01	0	41.3	38.3	77	132	122	0	36	33
2014	9	16	8	38	19	0.781	-0.118	3.839	0.016	0.016	0	41.3	37.8	77	132	121	0	36	33
2014	9	16	8	48	19	0.801	-0.082	3.839	0.01	0.007	0	42.1	37.8	76.1	133	122	0	35	34
2014	9	16	8	58	19	0.781	-0.056	3.839	0.01	0.007	0	41.7	38.3	77	132	122	0	35	33
2014	9	16	9	8	19	0.83	-0.079	3.839	0.01	0.007	0	41.7	38.7	76.5	132	122	0	35	32
2014	9	16	9	18	19	0.794	-0.092	3.839	0.01	0.007	0	41.3	37.8	76.5	132	121	0	36	33
2014	9	16	9	28	19	0.817	-0.049	3.839	0.013	0.01	0	41.7	37.4	76.5	132	121	0	35	34
2014	9	16	9	38	19	0.81	-0.085	3.839	0.016	0.013	0	42.1	38.3	76.5	133	122	0	35	33
2014	9	16	9	48	19	0.81	-0.108	3.839	0.01	0.007	0	41.3	38.3	77	132	122	0	36	33
2014	9	16	9	58	19	0.843	-0.075	3.839	0.01	0.007	0	41.7	38.3	76.1	132	122	0	35	33
2014	9	16	10	8	19	0.807	-0.072	3.839	0.013	0.01	0	41.7	38.3	76.1	133	122	0	36	33
2014	9	16	10	18	19	0.814	-0.069	3.839	0.013	0.01	0	41.7	38.3	76.1	132	122	0	35	33
2014	9	16	10	28	19	0.801	-0.115	3.835	0.01	0.007	0	41.7	37.8	76.1	132	121	0	35	33
2014	9	16	10	38	19	0.843	-0.085	3.835	0.013	0.01	0	41.3	37.8	75.3	131	121	0	35	33
2014	9	16	10	48	19	0.784	-0.115	3.832	0.01	0.007	0	41.7	37.8	75.7	132	121	0	35	33
2014	9	16	10	58	19	0.827	-0.079	3.832	0.01	0.007	0	41.7	37.8	74.4	132	121	0	35	33
2014	9	16	11	8	19	0.804	-0.112	3.832	0.013	0.01	0	41.3	37.8	74	131	120	0	35	32
2014	9	16	11	18	19	0.797	-0.092	3.829	0.01	0.007	0	41.3	37.4	74.4	131	120	0	35	33
2014	9	16	11	28	19	0.82	-0.095	3.829	0.013	0.01	0	41.3	37.8	74	131	121	0	35	33
2014	9	16	11	38	19	0.807	-0.082	3.829	0.01	0.007	0	41.7	37.8	73.5	132	121	0	35	33
2014	9	16	11	48	19	0.84	-0.108	3.829	0.01	0.007	0	41.7	38.3	76.1	132	121	0	35	32
2014	9	16	11	58	19	0.827	-0.075	3.829	0.01	0.007	0	41.7	37.4	76.1	132	121	0	35	34
2014	9	16	12	8	19	0.794	-0.069	3.829	0.01	0.007	0	41.7	38.3	62.4	132	121	0	35	32
2014	9	16	12	18	19	0.804	-0.108	3.829	0.01	0.007	0	41.7	38.3	60.2	132	122	0	35	33
2014	9	16	12	28	19	0.827	-0.102	3.825	0.013	0.01	0	42.1	37.8	55.9	133	122	0	35	34
2014	9	16	12	38	19	0.748	-0.098	3.829	0.01	0.007	0	42.1	38.7	56.8	133	123	0	35	33
2014	9	16	12	48	19	0.768	-0.095	3.829	0.01	0.007	0	42.1	38.7	54.2	133	123	0	35	33
2014	9	16	12	58	19	0.833	-0.069	3.825	0.013	0.01	0	42.1	38.7	55.9	133	123	0	35	33
2014	9	16	13	8	19	0.784	-0.105	3.825	0.01	0.007	0	42.6	39.1	59.3	134	124	0	35	33
2014	9	16	13	18	19	0.787	-0.082	3.825	0.013	0.01	0	42.6	38.7	61.5	133	122	0	34	32
2014	9	16	13	28	19	0.761	-0.085	3.825	0.01	0.007	0	42.6	38.7	62.4	133	123	0	34	33
2014	9	16	13	38	19	0.745	-0.095	3.825	0.013	0.01	0	42.1	38.7	57.2	133	123	0	35	33
2014	9	16	13	48	19	0.823	-0.105	3.825	0.013	0.01	0	42.1	38.3	68.8	133	122	0	35	33
2014	9	16	13	58	19	0.794	-0.102	3.825	0.016	0.013	0	42.1	39.1	64.1	133	123	0	35	32
2014	9	16	14	8	19	0.804	-0.118	3.825	0.016	0.013	0	42.1	38.3	71.8	133	123	0	35	34
2014	9	16	14	18	19	0.764	-0.089	3.822	0.01	0.007	0	42.1	39.1	59.3	134	124	0	36	33
2014	9	16	14	28	19	0.82	-0.085	3.822	0.013	0.01	0	42.1	38.7	54.6	133	123	0	35	33
2014	9	16	14	38	19	0.787	-0.115	3.825	0.01	0.007	0	42.6	38.7	64.5	134	123	0	35	33
2014	9	16	14	48	19	0.738	-0.108	3.822	0.01	0.007	0	42.6	38.7	58	134	123	0	35	33
2014	9	16	14	58	19	0.807	-0.075	3.822	0.01	0.007	0	42.6	39.1	64.1	134	124	0	35	33
2014	9	16	15	8	19	0.791	-0.075	3.822	0.01	0.007	0	42.1	38.7	56.8	134	123	0	36	33
2014	9	16	15	18	19	0.778	-0.128	3.822	0.013	0.01	0	43	39.6	61.1	135	124	0	35	32
2014	9	16	15	28	19	0.755	-0.089	3.822	0.013	0.01	0	43	39.6	55.5	134	124	0	34	32
2014	9	16	15	38	19	0.797	-0.079	3.822	0.013	0.01	0	42.6	39.1	55	134	124	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	15	48	19	0.791	-0.092	3.822	0.01	0.007	0	42.6	39.1	66.2	134	124	0	35	33
2014	9	16	15	58	19	0.784	-0.092	3.819	0.01	0.007	0	42.6	38.7	55.5	134	123	0	35	33
2014	9	16	16	8	19	0.748	-0.089	3.819	0.016	0.013	0	42.6	39.1	55	134	124	0	35	33
2014	9	16	16	18	19	0.761	-0.102	3.819	0.01	0.007	0	42.6	39.1	55.9	134	124	0	35	33
2014	9	16	16	28	19	0.807	-0.112	3.822	0.01	0.007	0	43	39.6	60.2	135	125	0	35	33
2014	9	16	16	38	19	0.761	-0.075	3.819	0.01	0.007	0	43	39.6	63.2	135	125	0	35	33
2014	9	16	16	48	19	0.751	-0.102	3.819	0.01	0.007	0	42.6	39.1	61.5	134	124	0	35	33
2014	9	16	16	58	19	0.755	-0.098	3.819	0.01	0.007	0	42.6	39.1	61.9	134	124	0	35	33
2014	9	16	17	8	19	0.774	-0.095	3.819	0.01	0.007	0	42.6	38.7	61.1	134	123	0	35	33
2014	9	16	17	18	19	0.807	-0.079	3.819	0.01	0.007	0	42.6	38.7	61.5	134	123	0	35	33
2014	9	16	17	28	19	0.781	-0.082	3.819	0.01	0.007	0	42.6	38.7	64.1	134	123	0	35	33
2014	9	16	17	38	19	0.797	-0.066	3.819	0.01	0.007	0	42.6	38.7	61.5	134	123	0	35	33
2014	9	16	17	48	19	0.801	-0.108	3.819	0.016	0.013	0	42.1	38.7	69.7	133	123	0	35	33
2014	9	16	17	58	19	0.837	-0.098	3.822	0.013	0.01	0	42.1	38.7	75.3	133	123	0	35	33
2014	9	16	18	8	19	0.81	-0.092	3.822	0.016	0.013	0	42.6	38.7	79.6	134	123	0	35	33
2014	9	16	18	18	19	0.797	-0.079	3.819	0.016	0.013	0	42.6	38.7	72.2	134	123	0	35	33
2014	9	16	18	28	19	0.814	-0.092	3.822	0.016	0.013	0	42.6	39.1	78.7	134	123	0	35	32
2014	9	16	18	38	19	0.823	-0.098	3.822	0.01	0.007	0	42.6	39.1	74.8	134	123	0	35	32
2014	9	16	18	48	19	0.791	-0.108	3.822	0.013	0.01	0	43	39.1	77.8	135	124	0	35	33
2014	9	16	18	58	19	0.797	-0.092	3.819	0.013	0.01	0	42.1	38.7	59.3	133	122	0	35	32
2014	9	16	19	8	19	0.81	-0.092	3.819	0.013	0.01	0	43.4	39.6	69.7	135	124	0	34	32
2014	9	16	19	18	19	0.804	-0.082	3.822	0.013	0.01	0	43.4	40.4	76.5	136	126	0	35	32
2014	9	16	19	28	19	0.781	-0.108	3.822	0.01	0.007	0	43.9	40.4	73.5	137	126	0	35	32
2014	9	16	19	38	19	0.794	-0.112	3.822	0.013	0.01	0	44.7	40.4	67.9	139	127	0	35	33
2014	9	16	19	48	19	0.823	-0.072	3.822	0.01	0.007	0	45.2	40.4	77	140	127	0	35	33
2014	9	16	19	58	19	0.84	-0.121	3.822	0.013	0.01	0	45.2	40.4	70.5	140	127	0	35	33
2014	9	16	20	8	19	0.84	-0.082	3.822	0.01	0.007	0	44.7	40.4	78.7	139	126	0	35	32
2014	9	16	20	18	19	0.791	-0.036	3.822	0.01	0.007	0	44.7	40	80	139	126	0	35	33
2014	9	16	20	28	19	0.807	-0.092	3.822	0.013	0.01	0	44.7	40.4	80	139	126	0	35	32
2014	9	16	20	38	19	0.81	-0.079	3.822	0.013	0.01	0	44.7	40.4	80	139	126	0	35	32
2014	9	16	20	48	19	0.814	-0.066	3.822	0.01	0.007	0	44.7	40	80.8	139	126	0	35	33
2014	9	16	20	58	19	0.81	-0.108	3.822	0.01	0.007	0	44.3	40	80.4	138	125	0	35	32
2014	9	16	21	8	19	0.801	-0.118	3.822	0.013	0.01	0	44.3	40	65.4	138	125	0	35	32
2014	9	16	21	18	19	0.791	-0.062	3.822	0.013	0.01	0	44.7	40	80	139	126	0	35	33
2014	9	16	21	28	19	0.801	-0.085	3.822	0.01	0.007	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	16	21	38	19	0.774	-0.092	3.822	0.016	0.016	0	44.7	40	80.8	139	126	0	35	33
2014	9	16	21	48	19	0.843	-0.069	3.822	0.01	0.007	0	44.7	40	80.8	139	126	0	35	33
2014	9	16	21	58	19	0.807	-0.069	3.822	0.01	0.007	0	44.7	39.6	81.3	139	126	0	35	34
2014	9	16	22	8	19	0.85	-0.102	3.822	0.013	0.01	0	44.3	40	81.3	138	126	0	35	33
2014	9	16	22	18	19	0.863	-0.066	3.822	0.013	0.01	0	44.7	40.4	80	139	126	0	35	32
2014	9	16	22	28	19	0.81	-0.085	3.822	0.013	0.01	0	45.2	40.4	78.7	139	126	0	34	32
2014	9	16	22	38	19	0.791	-0.089	3.822	0.01	0.007	0	44.7	40	74	138	125	0	34	32
2014	9	16	22	48	19	0.84	-0.089	3.822	0.01	0.007	0	44.3	40	72.7	138	125	0	35	32
2014	9	16	22	58	19	0.784	-0.075	3.822	0.013	0.01	0	44.7	40	78.3	139	126	0	35	33
2014	9	16	23	8	19	0.794	-0.085	3.822	0.01	0.007	0	44.3	39.6	77	138	125	0	35	33
2014	9	16	23	18	19	0.82	-0.089	3.822	0.013	0.01	0	44.3	39.1	77.4	138	125	0	35	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	16	23	28	19	0.768	-0.102	3.822	0.013	0.01	0	44.3	39.6	71.8	138	125	0	35	33
2014	9	16	23	38	19	0.814	-0.092	3.822	0.013	0.01	0	43.9	39.6	56.8	138	125	0	36	33
2014	9	16	23	48	19	0.778	-0.095	3.822	0.013	0.01	0	44.7	40.4	55.9	139	127	0	35	33
2014	9	16	23	58	19	0.758	-0.062	3.822	0.013	0.01	0	45.2	40	63.6	139	126	0	34	33
2014	9	17	0	8	19	0.768	-0.085	3.822	0.013	0.01	0	44.7	40	57.6	139	126	0	35	33
2014	9	17	0	18	19	0.794	-0.079	3.822	0.016	0.013	0	44.7	40	59.3	139	126	0	35	33
2014	9	17	0	28	19	0.784	-0.128	3.822	0.013	0.01	0	44.7	40	69.2	139	126	0	35	33
2014	9	17	0	38	19	0.774	-0.062	3.825	0.01	0.007	0	44.7	40	77	139	126	0	35	33
2014	9	17	0	48	19	0.814	-0.105	3.825	0.013	0.01	0	44.3	40	79.6	138	125	0	35	32
2014	9	17	0	58	19	0.807	-0.089	3.825	0.016	0.013	0	44.7	40	79.6	139	126	0	35	33
2014	9	17	1	8	19	0.804	-0.082	3.825	0.013	0.01	0	44.7	40	63.6	139	126	0	35	33
2014	9	17	1	18	19	0.791	-0.121	3.822	0.013	0.01	0	44.7	40	59.3	139	126	0	35	33
2014	9	17	1	28	19	0.787	-0.082	3.825	0.016	0.013	0	44.7	40	64.9	139	126	0	35	33
2014	9	17	1	38	19	0.823	-0.072	3.822	0.01	0.007	0	44.7	40	59.3	139	126	0	35	33
2014	9	17	1	48	19	0.787	-0.112	3.822	0.01	0.007	0	44.3	40	63.6	138	126	0	35	33
2014	9	17	1	58	19	0.761	-0.085	3.825	0.016	0.013	0	44.7	40.4	74	139	126	0	35	32
2014	9	17	2	8	19	0.797	-0.059	3.825	0.01	0.007	0	44.3	40	78.7	138	125	0	35	32
2014	9	17	2	18	19	0.787	-0.108	3.825	0.01	0.007	0	43.9	39.6	67.9	138	125	0	36	33
2014	9	17	2	28	19	0.774	-0.095	3.825	0.01	0.007	0	44.7	40	69.7	139	126	0	35	33
2014	9	17	2	38	19	0.774	-0.089	3.825	0.013	0.01	0	44.3	39.6	73.1	139	126	0	36	34
2014	9	17	2	48	19	0.817	-0.079	3.825	0.01	0.007	0	44.3	39.6	74	138	125	0	35	33
2014	9	17	2	58	19	0.837	-0.079	3.825	0.01	0.007	0	44.3	39.6	57.2	138	125	0	35	33
2014	9	17	3	8	19	0.771	-0.095	3.825	0.01	0.007	0	44.7	40	61.9	139	126	0	35	33
2014	9	17	3	18	19	0.81	-0.085	3.825	0.016	0.013	0	44.3	40.4	57.6	139	126	0	36	32
2014	9	17	3	28	19	0.745	-0.079	3.825	0.01	0.007	0	45.2	40	58	139	126	0	34	33
2014	9	17	3	38	19	0.797	-0.108	3.825	0.01	0.007	0	45.2	40	61.9	139	126	0	34	33
2014	9	17	3	48	19	0.778	-0.112	3.829	0.01	0.007	0	44.7	40	70.5	139	126	0	35	33
2014	9	17	3	58	19	0.82	-0.125	3.829	0.016	0.013	0	44.7	40	79.1	139	126	0	35	33
2014	9	17	4	8	19	0.823	-0.092	3.829	0.01	0.007	0	44.7	40	79.1	139	126	0	35	33
2014	9	17	4	18	19	0.778	-0.092	3.829	0.013	0.01	0	44.3	40.4	78.7	138	126	0	35	32
2014	9	17	4	28	19	0.82	-0.089	3.829	0.01	0.007	0	44.3	40	79.6	138	126	0	35	33
2014	9	17	4	38	19	0.82	-0.066	3.832	0.013	0.01	0	45.2	40	79.1	139	126	0	34	33
2014	9	17	4	48	19	0.807	-0.069	3.832	0.01	0.007	0	44.3	39.6	77.8	138	125	0	35	33
2014	9	17	4	58	19	0.807	-0.079	3.832	0.01	0.007	0	44.7	40	78.3	139	125	0	35	32
2014	9	17	5	8	19	0.807	-0.092	3.829	0.01	0.007	0	43.9	39.6	78.3	138	125	0	36	33
2014	9	17	5	18	19	0.83	-0.072	3.829	0.01	0.007	0	44.3	40	78.7	138	126	0	35	33
2014	9	17	5	28	19	0.807	-0.092	3.832	0.01	0.007	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	17	5	38	19	0.86	-0.108	3.832	0.01	0.007	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	17	5	48	19	0.817	-0.138	3.832	0.013	0.01	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	17	5	58	19	0.807	-0.095	3.832	0.01	0.007	0	44.7	40.4	77	139	126	0	35	32
2014	9	17	6	8	19	0.83	-0.098	3.832	0.01	0.007	0	44.3	40.4	77.8	138	126	0	35	32
2014	9	17	6	18	19	0.823	-0.075	3.832	0.016	0.013	0	44.7	40.4	78.3	139	126	0	35	32
2014	9	17	6	28	19	0.814	-0.105	3.832	0.013	0.01	0	44.3	39.6	77	138	125	0	35	33
2014	9	17	6	38	19	0.837	-0.085	3.832	0.01	0.007	0	43.9	39.6	77.4	138	125	0	36	33
2014	9	17	6	48	19	0.771	-0.102	3.832	0.01	0.007	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	17	6	58	19	0.778	-0.062	3.832	0.016	0.013	0	43.9	39.1	77.4	137	124	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	7	8	19	0.791	-0.075	3.832	0.01	0.007	0	43.4	39.1	76.5	136	123	0	35	32
2014	9	17	7	18	19	0.82	-0.075	3.832	0.01	0.007	0	43.4	38.3	77.4	136	123	0	35	34
2014	9	17	7	28	19	0.827	-0.102	3.832	0.01	0.007	0	43.4	38.7	76.5	136	123	0	35	33
2014	9	17	7	38	19	0.778	-0.108	3.832	0.01	0.007	0	43.4	39.1	76.1	136	123	0	35	32
2014	9	17	7	48	19	0.853	-0.089	3.832	0.013	0.01	0	42.6	38.7	77	135	123	0	36	33
2014	9	17	7	58	19	0.807	-0.059	3.832	0.01	0.007	0	43.9	39.1	70.5	137	124	0	35	33
2014	9	17	8	8	19	0.787	-0.092	3.832	0.01	0.007	0	43	39.1	76.5	136	124	0	36	33
2014	9	17	8	18	19	0.817	-0.085	3.832	0.013	0.01	0	43.4	39.1	75.7	136	124	0	35	33
2014	9	17	8	28	19	0.81	-0.095	3.835	0.01	0.007	0	43	38.7	75.7	135	123	0	35	33
2014	9	17	8	38	19	0.794	-0.102	3.835	0.01	0.007	0	43	38.7	75.7	135	123	0	35	33
2014	9	17	8	48	19	0.843	-0.095	3.835	0.01	0.007	0	43.4	38.7	76.1	136	123	0	35	33
2014	9	17	8	58	19	0.82	-0.089	3.835	0.01	0.007	0	43.4	39.6	76.1	136	124	0	35	32
2014	9	17	9	8	19	0.781	-0.098	3.835	0.01	0.007	0	43.4	39.1	76.1	136	124	0	35	33
2014	9	17	9	18	19	0.817	-0.092	3.835	0.01	0.007	0	43.4	39.1	75.3	136	124	0	35	33
2014	9	17	9	28	19	0.794	-0.102	3.835	0.013	0.01	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	17	9	38	19	0.82	-0.108	3.835	0.01	0.007	0	43	38.7	75.3	135	123	0	35	33
2014	9	17	9	48	19	0.784	-0.085	3.835	0.013	0.01	0	43.4	39.1	73.5	136	123	0	35	32
2014	9	17	9	58	19	0.791	-0.082	3.835	0.01	0.007	0	43	38.7	75.3	135	123	0	35	33
2014	9	17	10	8	19	0.784	-0.118	3.835	0.01	0.007	0	43.4	39.1	76.5	136	124	0	35	33
2014	9	17	10	18	19	0.787	-0.089	3.835	0.01	0.007	0	43.4	39.1	76.5	136	124	0	35	33
2014	9	17	10	28	19	0.81	-0.085	3.835	0.016	0.013	0	43.4	39.1	74.8	136	124	0	35	33
2014	9	17	10	38	19	0.807	-0.092	3.835	0.016	0.013	0	43.4	39.6	76.1	136	124	0	35	32
2014	9	17	10	48	19	0.814	-0.089	3.839	0.013	0.01	0	43.9	39.6	74.4	137	125	0	35	33
2014	9	17	10	58	19	0.794	-0.079	3.835	0.013	0.01	0	43.9	39.6	76.5	137	125	0	35	33
2014	9	17	11	8	19	0.814	-0.089	3.835	0.016	0.013	0	43	39.1	77	136	124	0	36	33
2014	9	17	11	18	19	0.794	-0.098	3.835	0.013	0.01	0	43.4	39.6	77.8	136	124	0	35	32
2014	9	17	11	28	19	0.781	-0.108	3.835	0.01	0.007	0	43.4	40	77.8	136	125	0	35	32
2014	9	17	11	38	19	0.797	-0.082	3.835	0.01	0.007	0	43.4	39.6	68.8	136	124	0	35	32
2014	9	17	11	48	19	0.817	-0.069	3.835	0.013	0.01	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	17	11	58	19	0.83	-0.108	3.835	0.01	0.007	0	43.9	39.1	62.8	136	124	0	34	33
2014	9	17	12	8	19	0.787	-0.082	3.832	0.013	0.01	0	43.9	39.6	59.3	137	125	0	35	33
2014	9	17	12	18	19	0.797	-0.105	3.832	0.013	0.01	0	43	38.7	58.9	135	123	0	35	33
2014	9	17	12	28	19	0.791	-0.112	3.832	0.01	0.007	0	43.4	39.1	61.1	136	124	0	35	33
2014	9	17	12	38	19	0.791	-0.095	3.832	0.013	0.01	0	43.4	39.6	55.9	136	125	0	35	33
2014	9	17	12	48	19	0.771	-0.098	3.832	0.01	0.007	0	45.2	40.9	55	140	128	0	35	33
2014	9	17	12	58	19	0.787	-0.056	3.832	0.016	0.013	0	43.9	40	60.6	137	126	0	35	33
2014	9	17	13	8	19	0.82	-0.082	3.832	0.01	0.007	0	43.9	39.6	55.5	137	125	0	35	33
2014	9	17	13	18	19	0.781	-0.102	3.832	0.016	0.013	0	44.3	39.6	52.9	137	125	0	34	33
2014	9	17	13	28	19	0.781	-0.079	3.832	0.01	0.007	0	43.9	40	52	137	126	0	35	33
2014	9	17	13	38	19	0.804	-0.112	3.832	0.01	0.007	0	44.7	40.9	56.3	139	127	0	35	32
2014	9	17	13	48	19	0.787	-0.098	3.829	0.016	0.016	0	43.4	39.6	54.2	136	125	0	35	33
2014	9	17	13	58	19	0.748	-0.095	3.829	0.013	0.01	0	43.9	40	52	137	126	0	35	33
2014	9	17	14	8	19	0.774	-0.102	3.829	0.01	0.007	0	44.7	41.3	52.9	139	128	0	35	32
2014	9	17	14	18	19	0.797	-0.062	3.832	0.01	0.007	0	45.2	41.3	52	140	128	0	35	32
2014	9	17	14	28	19	0.807	-0.092	3.829	0.013	0.01	0	44.7	40.9	51.6	139	128	0	35	33
2014	9	17	14	38	19	0.755	-0.052	3.829	0.013	0.01	0	45.2	40.9	51.2	140	128	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	14	48	19	0.784	-0.056	3.825	0.013	0.01	0	45.6	41.7	52	141	129	0	35	32
2014	9	17	14	58	19	0.735	-0.062	3.825	0.01	0.007	0	46	41.7	51.6	141	130	0	34	33
2014	9	17	15	8	19	0.778	-0.082	3.825	0.01	0.007	0	45.2	41.3	51.6	140	128	0	35	32
2014	9	17	15	18	19	0.787	-0.082	3.825	0.01	0.007	0	44.7	40.4	52.5	139	127	0	35	33
2014	9	17	15	28	19	0.804	-0.072	3.825	0.01	0.007	0	44.7	40.9	52.9	139	127	0	35	32
2014	9	17	15	38	19	0.774	-0.062	3.825	0.013	0.01	0	44.7	40.4	52.5	138	127	0	34	33
2014	9	17	15	48	19	0.778	-0.082	3.825	0.016	0.013	0	43.9	40	52.5	137	126	0	35	33
2014	9	17	15	58	19	0.833	-0.069	3.825	0.013	0.01	0	44.3	40.4	55	138	127	0	35	33
2014	9	17	16	8	19	0.784	-0.102	3.825	0.01	0.007	0	45.2	40.9	53.3	140	128	0	35	33
2014	9	17	16	18	19	0.801	-0.112	3.825	0.016	0.016	0	44.7	40.9	57.2	139	128	0	35	33
2014	9	17	16	28	19	0.764	-0.075	3.822	0.013	0.01	0	43.9	40	54.2	137	126	0	35	33
2014	9	17	16	38	19	0.797	-0.095	3.825	0.01	0.007	0	43.9	39.6	55.5	137	125	0	35	33
2014	9	17	16	48	19	0.787	-0.098	3.825	0.013	0.01	0	43.9	39.6	54.6	137	125	0	35	33
2014	9	17	16	58	19	0.774	-0.092	3.825	0.01	0.007	0	43.9	39.6	52.9	137	125	0	35	33
2014	9	17	17	8	19	0.781	-0.098	3.825	0.013	0.01	0	44.7	39.6	59.3	138	126	0	34	34
2014	9	17	17	18	19	0.761	-0.098	3.822	0.01	0.007	0	44.3	39.6	55	137	124	0	34	32
2014	9	17	17	28	19	0.787	-0.092	3.825	0.016	0.016	0	43.4	39.6	56.8	136	124	0	35	32
2014	9	17	17	38	19	0.771	-0.115	3.822	0.01	0.007	0	43.4	39.6	53.3	136	124	0	35	32
2014	9	17	17	48	19	0.817	-0.089	3.822	0.01	0.007	0	44.3	40	53.8	138	125	0	35	32
2014	9	17	17	58	19	0.794	-0.098	3.822	0.013	0.01	0	44.7	40.4	51.2	138	126	0	34	32
2014	9	17	18	8	19	0.791	-0.085	3.822	0.013	0.01	0	44.7	40	56.3	138	125	0	34	32
2014	9	17	18	18	19	0.748	-0.085	3.822	0.013	0.01	0	44.3	40	56.8	137	125	0	34	32
2014	9	17	18	28	19	0.768	-0.108	3.822	0.01	0.007	0	43.9	39.6	53.3	137	125	0	35	33
2014	9	17	18	38	19	0.784	-0.095	3.825	0.01	0.007	0	43.9	39.6	64.5	137	125	0	35	33
2014	9	17	18	48	19	0.794	-0.072	3.825	0.013	0.01	0	43.9	39.1	61.1	137	124	0	35	33
2014	9	17	18	58	19	0.748	-0.059	3.825	0.013	0.01	0	43.9	39.6	73.1	137	124	0	35	32
2014	9	17	19	8	19	0.817	-0.089	3.829	0.01	0.007	0	44.3	40	80.8	138	126	0	35	33
2014	9	17	19	18	19	0.837	-0.089	3.829	0.013	0.01	0	44.7	40	81.3	139	126	0	35	33
2014	9	17	19	28	19	0.781	-0.098	3.829	0.01	0.007	0	44.7	40.4	81.3	139	127	0	35	33
2014	9	17	19	38	19	0.837	-0.072	3.829	0.01	0.007	0	45.6	40.4	81.3	140	127	0	34	33
2014	9	17	19	48	19	0.794	-0.062	3.829	0.013	0.01	0	45.2	40.4	80.8	140	127	0	35	33
2014	9	17	19	58	19	0.797	-0.092	3.829	0.01	0.007	0	45.6	41.3	79.6	140	128	0	34	32
2014	9	17	20	8	19	0.807	-0.095	3.829	0.013	0.01	0	44.7	40.4	80.8	139	127	0	35	33
2014	9	17	20	18	19	0.778	-0.082	3.829	0.016	0.013	0	44.7	40.4	77.8	139	126	0	35	32
2014	9	17	20	28	19	0.797	-0.108	3.829	0.01	0.007	0	45.2	40.4	80.4	139	127	0	34	33
2014	9	17	20	38	19	0.823	-0.085	3.829	0.013	0.01	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	17	20	48	19	0.807	-0.075	3.829	0.01	0.007	0	44.7	40.9	80	139	127	0	35	32
2014	9	17	20	58	19	0.791	-0.112	3.829	0.01	0.007	0	45.2	40.9	80.4	140	128	0	35	33
2014	9	17	21	8	19	0.801	-0.108	3.829	0.01	0.007	0	44.7	40.4	80.4	139	127	0	35	33
2014	9	17	21	18	19	0.784	-0.069	3.829	0.01	0.007	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	17	21	28	19	0.778	-0.098	3.829	0.01	0.007	0	45.2	40.9	78.3	140	127	0	35	32
2014	9	17	21	38	19	0.81	-0.089	3.829	0.01	0.007	0	45.6	40.9	80.4	140	127	0	34	32
2014	9	17	21	48	19	0.787	-0.089	3.829	0.013	0.01	0	45.6	40.9	79.6	140	128	0	34	33
2014	9	17	21	58	19	0.781	-0.085	3.829	0.01	0.007	0	45.6	40.4	80	140	127	0	34	33
2014	9	17	22	8	19	0.837	-0.079	3.829	0.01	0.007	0	44.7	40.9	77.4	139	127	0	35	32
2014	9	17	22	18	19	0.764	-0.089	3.829	0.013	0.01	0	45.2	40.9	79.6	140	127	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	17	22	28	19	0.807	-0.102	3.829	0.016	0.013	0	45.2	41.3	79.1	140	128	0	35	32
2014	9	17	22	38	19	0.814	-0.085	3.829	0.013	0.01	0	45.2	40.4	80.4	140	127	0	35	33
2014	9	17	22	48	19	0.784	-0.082	3.829	0.01	0.007	0	45.2	40.9	80	140	128	0	35	33
2014	9	17	22	58	19	0.81	-0.059	3.829	0.016	0.016	0	45.6	40.4	68.4	140	127	0	34	33
2014	9	17	23	8	19	0.755	-0.089	3.825	0.013	0.01	0	44.7	40.4	60.6	139	127	0	35	33
2014	9	17	23	18	19	0.791	-0.085	3.825	0.01	0.007	0	45.2	40.4	62.8	140	127	0	35	33
2014	9	17	23	28	19	0.807	-0.112	3.829	0.01	0.007	0	44.7	40	64.5	139	126	0	35	33
2014	9	17	23	38	19	0.778	-0.121	3.829	0.01	0.007	0	45.2	40.4	65.8	140	127	0	35	33
2014	9	17	23	48	19	0.82	-0.098	3.829	0.01	0.007	0	45.2	40.9	72.2	140	127	0	35	32
2014	9	17	23	58	19	0.764	-0.095	3.829	0.01	0.007	0	44.7	40.4	74	139	127	0	35	33
2014	9	18	0	8	19	0.81	-0.089	3.829	0.013	0.01	0	44.7	40.9	72.2	139	127	0	35	32
2014	9	18	0	18	19	0.797	-0.075	3.829	0.013	0.01	0	44.7	40.4	74.8	139	126	0	35	32
2014	9	18	0	28	19	0.801	-0.085	3.829	0.01	0.007	0	44.7	40.4	67.9	139	126	0	35	32
2014	9	18	0	38	19	0.781	-0.079	3.829	0.01	0.007	0	45.2	40.4	59.3	139	127	0	34	33
2014	9	18	0	48	19	0.781	-0.072	3.829	0.01	0.007	0	44.7	40.4	60.6	139	127	0	35	33
2014	9	18	0	58	19	0.758	-0.095	3.829	0.013	0.01	0	44.7	40.9	63.6	139	127	0	35	32
2014	9	18	1	8	19	0.794	-0.105	3.829	0.013	0.01	0	44.7	40.4	60.2	139	127	0	35	33
2014	9	18	1	18	19	0.801	-0.062	3.829	0.016	0.016	0	44.3	40	75.7	138	126	0	35	33
2014	9	18	1	28	19	0.81	-0.079	3.829	0.013	0.01	0	44.7	40	79.1	139	126	0	35	33
2014	9	18	1	38	19	0.774	-0.079	3.829	0.01	0.007	0	44.3	40	75.7	138	126	0	35	33
2014	9	18	1	48	19	0.846	-0.082	3.829	0.01	0.007	0	43.9	40.4	78.3	138	126	0	36	32
2014	9	18	1	58	19	0.823	-0.102	3.829	0.013	0.01	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	18	2	8	19	0.768	-0.102	3.829	0.01	0.007	0	44.3	39.6	64.1	138	125	0	35	33
2014	9	18	2	18	19	0.791	-0.092	3.832	0.01	0.007	0	44.3	40.4	80.8	138	126	0	35	32
2014	9	18	2	28	19	0.787	-0.082	3.832	0.01	0.007	0	44.7	40.4	80.8	138	126	0	34	32
2014	9	18	2	38	19	0.784	-0.095	3.832	0.01	0.007	0	44.3	40.4	79.6	138	126	0	35	32
2014	9	18	2	48	19	0.807	-0.102	3.832	0.01	0.007	0	43.9	40	78.3	137	125	0	35	32
2014	9	18	2	58	19	0.787	-0.079	3.832	0.013	0.01	0	44.3	39.6	80.8	138	126	0	35	34
2014	9	18	3	8	19	0.764	-0.102	3.832	0.016	0.013	0	44.3	40.4	78.3	138	126	0	35	32
2014	9	18	3	18	19	0.787	-0.105	3.829	0.01	0.007	0	44.3	40.4	68.4	138	126	0	35	32
2014	9	18	3	28	19	0.751	-0.075	3.829	0.016	0.013	0	44.3	40.4	58.9	138	126	0	35	32
2014	9	18	3	38	19	0.801	-0.092	3.832	0.01	0.007	0	44.3	40.4	69.2	138	126	0	35	32
2014	9	18	3	48	19	0.817	-0.079	3.832	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	18	3	58	19	0.781	-0.085	3.832	0.01	0.007	0	44.3	40	76.1	138	126	0	35	33
2014	9	18	4	8	19	0.794	-0.066	3.832	0.01	0.007	0	44.3	40.4	79.1	138	127	0	35	33
2014	9	18	4	18	19	0.82	-0.098	3.832	0.01	0.007	0	44.7	40.9	78.7	139	127	0	35	32
2014	9	18	4	28	19	0.784	-0.095	3.832	0.016	0.013	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	18	4	38	19	0.807	-0.138	3.832	0.01	0.007	0	44.7	40.9	78.3	139	127	0	35	32
2014	9	18	4	48	19	0.778	-0.092	3.832	0.01	0.007	0	44.3	40	79.1	139	126	0	36	33
2014	9	18	4	58	19	0.794	-0.075	3.832	0.013	0.01	0	44.7	40.9	78.7	139	127	0	35	32
2014	9	18	5	8	19	0.804	-0.092	3.832	0.016	0.016	0	44.7	40.4	76.5	139	127	0	35	33
2014	9	18	5	18	19	0.768	-0.062	3.832	0.01	0.007	0	44.7	40.9	79.1	139	127	0	35	32
2014	9	18	5	28	19	0.81	-0.072	3.832	0.013	0.01	0	44.7	40.4	78.7	139	126	0	35	32
2014	9	18	5	38	19	0.801	-0.112	3.832	0.013	0.01	0	44.7	40.4	72.7	139	126	0	35	32
2014	9	18	5	48	19	0.761	-0.105	3.832	0.01	0.007	0	45.2	40.9	78.3	139	127	0	34	32
2014	9	18	5	58	19	0.817	-0.092	3.832	0.01	0.007	0	44.7	40.4	76.5	139	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	6	8	19	0.761	-0.105	3.832	0.013	0.01	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	18	6	18	19	0.771	-0.128	3.832	0.01	0.007	0	44.7	40	77.4	139	126	0	35	33
2014	9	18	6	28	19	0.728	-0.072	3.832	0.013	0.01	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	18	6	38	19	0.82	-0.082	3.832	0.01	0.007	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	18	6	48	19	0.81	-0.062	3.832	0.016	0.013	0	43.9	40	75.7	137	125	0	35	32
2014	9	18	6	58	19	0.764	-0.089	3.832	0.013	0.01	0	43.9	40	78.3	137	125	0	35	32
2014	9	18	7	8	19	0.814	-0.108	3.832	0.013	0.01	0	43.9	39.6	78.3	137	125	0	35	33
2014	9	18	7	18	19	0.833	-0.075	3.832	0.01	0.007	0	43.9	39.6	77.8	137	125	0	35	33
2014	9	18	7	28	19	0.791	-0.131	3.832	0.013	0.01	0	43.9	39.1	77	136	124	0	34	33
2014	9	18	7	38	19	0.846	-0.125	3.832	0.013	0.01	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	18	7	48	19	0.791	-0.079	3.832	0.01	0.007	0	43.4	38.7	62.4	136	123	0	35	33
2014	9	18	7	58	19	0.778	-0.112	3.832	0.01	0.007	0	43.4	39.1	70.5	136	124	0	35	33
2014	9	18	8	8	19	0.784	-0.079	3.832	0.01	0.007	0	43	38.7	66.2	135	123	0	35	33
2014	9	18	8	18	19	0.814	-0.072	3.832	0.013	0.01	0	43.4	38.7	61.5	135	123	0	34	33
2014	9	18	8	28	19	0.804	-0.089	3.832	0.01	0.007	0	43	38.7	71.8	135	123	0	35	33
2014	9	18	8	38	19	0.817	-0.075	3.829	0.013	0.01	0	43	38.7	58.9	135	123	0	35	33
2014	9	18	8	48	19	0.778	-0.102	3.829	0.01	0.007	0	42.6	38.7	53.8	134	122	0	35	32
2014	9	18	8	58	19	0.778	-0.131	3.829	0.01	0.007	0	42.6	39.1	55	134	123	0	35	32
2014	9	18	9	8	19	0.784	-0.095	3.829	0.01	0.007	0	43	38.7	56.3	135	123	0	35	33
2014	9	18	9	18	19	0.83	-0.108	3.829	0.013	0.01	0	43	38.7	56.3	135	123	0	35	33
2014	9	18	9	28	19	0.778	-0.095	3.832	0.013	0.01	0	42.6	39.1	67.1	135	123	0	36	32
2014	9	18	9	38	19	0.761	-0.095	3.829	0.01	0.007	0	43.4	39.6	58.5	136	125	0	35	33
2014	9	18	9	48	19	0.791	-0.108	3.832	0.013	0.01	0	43.4	39.6	56.8	136	124	0	35	32
2014	9	18	9	58	19	0.784	-0.085	3.829	0.013	0.01	0	43.4	39.6	60.2	136	124	0	35	32
2014	9	18	10	8	19	0.791	-0.085	3.829	0.016	0.013	0	43	39.1	58.9	135	124	0	35	33
2014	9	18	10	18	19	0.751	-0.141	3.829	0.013	0.01	0	43	39.1	58.9	135	123	0	35	32
2014	9	18	10	28	19	0.82	-0.082	3.829	0.013	0.01	0	42.6	39.1	59.3	135	123	0	36	32
2014	9	18	10	38	19	0.801	-0.095	3.829	0.01	0.007	0	43.4	39.1	54.6	136	124	0	35	33
2014	9	18	10	48	19	0.778	-0.121	3.829	0.013	0.01	0	43	38.7	59.3	135	123	0	35	33
2014	9	18	10	58	19	0.794	-0.072	3.829	0.01	0.007	0	43	39.6	54.6	135	124	0	35	32
2014	9	18	11	8	19	0.82	-0.079	3.829	0.01	0.007	0	43	39.1	55.9	135	123	0	35	32
2014	9	18	11	18	19	0.804	-0.112	3.829	0.013	0.01	0	43	39.1	58	135	124	0	35	33
2014	9	18	11	28	19	0.784	-0.079	3.829	0.01	0.007	0	43	39.1	58.9	135	124	0	35	33
2014	9	18	11	38	19	0.758	-0.085	3.825	0.01	0.007	0	43.4	39.6	55.9	136	125	0	35	33
2014	9	18	11	48	19	0.764	-0.112	3.825	0.016	0.013	0	43	39.1	55.9	135	124	0	35	33
2014	9	18	11	58	19	0.807	-0.112	3.825	0.01	0.007	0	43	39.1	56.3	135	124	0	35	33
2014	9	18	12	8	19	0.758	-0.079	3.825	0.016	0.013	0	44.3	40	55	137	126	0	34	33
2014	9	18	12	18	19	0.801	-0.079	3.822	0.016	0.013	0	43.4	39.6	51.2	136	125	0	35	33
2014	9	18	12	28	19	0.817	-0.066	3.822	0.013	0.01	0	43.4	40	53.3	136	125	0	35	32
2014	9	18	12	38	19	0.774	-0.085	3.822	0.01	0.007	0	44.3	40.9	50.3	138	127	0	35	32
2014	9	18	12	48	19	0.751	-0.118	3.822	0.013	0.01	0	44.3	40.4	52.5	138	126	0	35	32
2014	9	18	12	58	19	0.761	-0.095	3.822	0.013	0.01	0	43.9	40.4	52	137	127	0	35	33
2014	9	18	13	8	19	0.768	-0.112	3.822	0.01	0.007	0	43.9	40	53.3	136	125	0	34	32
2014	9	18	13	18	19	0.732	-0.075	3.822	0.01	0.007	0	43.9	40	52	136	125	0	34	32
2014	9	18	13	28	19	0.758	-0.079	3.819	0.013	0.01	0	43.9	40.4	52.5	137	126	0	35	32
2014	9	18	13	38	19	0.778	-0.098	3.822	0.01	0.007	0	43.9	40.4	55.9	137	126	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	13	48	19	0.761	-0.066	3.819	0.01	0.007	0	44.7	41.3	52	139	128	0	35	32
2014	9	18	13	58	19	0.768	-0.102	3.816	0.013	0.01	0	43.9	40	51.2	137	126	0	35	33
2014	9	18	14	8	19	0.755	-0.082	3.816	0.01	0.007	0	45.2	40.9	52.5	139	128	0	34	33
2014	9	18	14	18	19	0.755	-0.082	3.816	0.016	0.013	0	45.6	42.1	51.6	141	130	0	35	32
2014	9	18	14	28	19	0.774	-0.092	3.816	0.013	0.01	0	45.6	42.1	53.3	141	130	0	35	32
2014	9	18	14	38	19	0.784	-0.128	3.812	0.01	0.007	0	45.2	41.7	52.9	140	129	0	35	32
2014	9	18	14	48	19	0.738	-0.082	3.812	0.01	0.007	0	45.2	41.3	51.6	139	128	0	34	32
2014	9	18	14	58	19	0.748	-0.095	3.812	0.013	0.01	0	44.7	41.3	51.6	139	128	0	35	32
2014	9	18	15	8	19	0.794	-0.062	3.809	0.01	0.007	0	44.7	41.3	50.7	139	128	0	35	32
2014	9	18	15	18	19	0.768	-0.095	3.809	0.01	0.007	0	44.3	40.4	53.8	138	126	0	35	32
2014	9	18	15	28	19	0.807	-0.079	3.809	0.01	0.007	0	44.7	41.3	54.2	139	128	0	35	32
2014	9	18	15	38	19	0.758	-0.085	3.806	0.01	0.007	0	44.3	40.4	53.8	138	127	0	35	33
2014	9	18	15	48	19	0.797	-0.128	3.806	0.013	0.01	0	44.3	40.9	54.6	138	127	0	35	32
2014	9	18	15	58	19	0.755	-0.049	3.806	0.01	0.007	0	44.3	40.4	51.6	138	127	0	35	33
2014	9	18	16	8	19	0.764	-0.102	3.806	0.01	0.007	0	44.3	40.9	51.6	138	127	0	35	32
2014	9	18	16	18	19	0.771	-0.066	3.806	0.01	0.007	0	43.9	40	52.5	137	126	0	35	33
2014	9	18	16	28	19	0.774	-0.075	3.806	0.013	0.01	0	43.9	40	52	137	125	0	35	32
2014	9	18	16	38	19	0.791	-0.108	3.802	0.01	0.007	0	43	39.6	53.8	135	124	0	35	32
2014	9	18	16	48	19	0.774	-0.095	3.802	0.013	0.01	0	43.4	40	52	136	125	0	35	32
2014	9	18	16	58	19	0.823	-0.085	3.802	0.01	0.007	0	43.4	40.4	52.9	136	126	0	35	32
2014	9	18	17	8	19	0.807	-0.095	3.802	0.013	0.01	0	44.7	40.9	53.3	139	128	0	35	33
2014	9	18	17	18	19	0.797	-0.108	3.802	0.01	0.007	0	44.7	40.4	52.9	138	126	0	34	32
2014	9	18	17	28	19	0.768	-0.095	3.802	0.013	0.01	0	44.3	40.9	52	138	127	0	35	32
2014	9	18	17	38	19	0.768	-0.108	3.799	0.013	0.01	0	44.7	40.9	51.6	138	127	0	34	32
2014	9	18	17	48	19	0.722	-0.098	3.802	0.01	0.007	0	43.9	40.4	51.2	137	126	0	35	32
2014	9	18	17	58	19	0.781	-0.092	3.802	0.013	0.01	0	43.9	40	52.5	137	125	0	35	32
2014	9	18	18	8	19	0.778	-0.095	3.799	0.01	0.007	0	43.4	40	55	136	125	0	35	32
2014	9	18	18	18	19	0.781	-0.079	3.799	0.016	0.013	0	43.4	40	56.3	136	125	0	35	32
2014	9	18	18	28	19	0.771	-0.079	3.802	0.01	0.007	0	43.9	40.4	52.5	137	126	0	35	32
2014	9	18	18	38	19	0.804	-0.072	3.799	0.016	0.013	0	43.9	40	51.6	137	126	0	35	33
2014	9	18	18	48	19	0.781	-0.079	3.799	0.016	0.013	0	43.9	40	52.9	136	125	0	34	32
2014	9	18	18	58	19	0.797	-0.135	3.802	0.01	0.007	0	44.3	40	53.3	137	126	0	34	33
2014	9	18	19	8	19	0.784	-0.115	3.802	0.01	0.007	0	43.4	39.6	54.2	136	125	0	35	33
2014	9	18	19	18	19	0.768	-0.072	3.802	0.01	0.007	0	43.9	40	54.6	137	126	0	35	33
2014	9	18	19	28	19	0.768	-0.082	3.802	0.01	0.007	0	44.3	40.9	54.6	138	127	0	35	32
2014	9	18	19	38	19	0.758	-0.085	3.802	0.013	0.01	0	45.2	40.9	54.2	139	127	0	34	32
2014	9	18	19	48	19	0.781	-0.092	3.802	0.016	0.013	0	45.2	40.9	54.6	139	128	0	34	33
2014	9	18	19	58	19	0.794	-0.121	3.802	0.013	0.01	0	44.3	40.9	58.9	138	127	0	35	32
2014	9	18	20	8	19	0.735	-0.089	3.802	0.01	0.007	0	43.9	40.9	64.5	137	127	0	35	32
2014	9	18	20	18	19	0.764	-0.128	3.802	0.013	0.01	0	44.3	40.4	59.3	138	126	0	35	32
2014	9	18	20	28	19	0.764	-0.079	3.802	0.016	0.016	0	43.9	40.9	54.2	137	127	0	35	32
2014	9	18	20	38	19	0.755	-0.085	3.802	0.013	0.01	0	43.9	40.4	55	137	126	0	35	32
2014	9	18	20	48	19	0.781	-0.085	3.802	0.016	0.013	0	43.9	40.9	53.8	137	126	0	35	31
2014	9	18	20	58	19	0.801	-0.082	3.802	0.013	0.01	0	44.3	40	62.4	137	126	0	34	33
2014	9	18	21	8	19	0.784	-0.115	3.802	0.013	0.01	0	43.9	40.4	76.5	137	126	0	35	32
2014	9	18	21	18	19	0.771	-0.079	3.802	0.016	0.013	0	44.3	40.9	63.2	138	127	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	18	21	28	19	0.784	-0.102	3.802	0.013	0.01	0	43.4	40.4	55.9	136	126	0	35	32
2014	9	18	21	38	19	0.771	-0.089	3.802	0.013	0.01	0	43.9	40.4	71.4	137	126	0	35	32
2014	9	18	21	48	19	0.833	-0.066	3.802	0.016	0.013	0	43.9	40.9	67.5	137	127	0	35	32
2014	9	18	21	58	19	0.817	-0.082	3.802	0.016	0.013	0	43.4	40.9	65.8	137	127	0	36	32
2014	9	18	22	8	19	0.791	-0.102	3.806	0.013	0.01	0	44.3	40	71.4	137	126	0	34	33
2014	9	18	22	18	19	0.784	-0.095	3.806	0.013	0.01	0	43.9	40.9	71.8	137	127	0	35	32
2014	9	18	22	28	19	0.791	-0.085	3.806	0.013	0.01	0	43.9	40	71	136	126	0	34	33
2014	9	18	22	38	19	0.797	-0.085	3.806	0.01	0.007	0	44.3	40.4	70.5	138	127	0	35	33
2014	9	18	22	48	19	0.784	-0.125	3.806	0.013	0.01	0	43.9	40.4	70.5	137	126	0	35	32
2014	9	18	22	58	19	0.791	-0.095	3.806	0.013	0.01	0	43.4	40	72.2	136	126	0	35	33
2014	9	18	23	8	19	0.81	-0.125	3.809	0.013	0.01	0	43.9	40	72.7	137	126	0	35	33
2014	9	18	23	18	19	0.82	-0.089	3.809	0.013	0.01	0	43.4	40.4	72.2	136	126	0	35	32
2014	9	18	23	28	19	0.797	-0.082	3.806	0.01	0.007	0	44.3	40.4	66.2	137	126	0	34	32
2014	9	18	23	38	19	0.797	-0.082	3.812	0.01	0.007	0	43.9	40.4	76.5	137	127	0	35	33
2014	9	18	23	48	19	0.791	-0.112	3.816	0.013	0.01	0	43.9	40.4	76.5	137	126	0	35	32
2014	9	18	23	58	19	0.804	-0.105	3.812	0.01	0.007	0	42.6	40	76.5	134	126	0	35	33
2014	9	19	0	8	19	0.823	-0.092	3.816	0.01	0.007	0	43.4	40.4	77	136	127	0	35	33
2014	9	19	0	18	19	0.778	-0.098	3.816	0.01	0.007	0	43.4	40.9	77	136	127	0	35	32
2014	9	19	0	28	19	0.797	-0.082	3.816	0.01	0.007	0	43.4	40.9	77	136	127	0	35	32
2014	9	19	0	38	19	0.778	-0.095	3.816	0.016	0.013	0	42.6	40.4	77	134	126	0	35	32
2014	9	19	0	48	19	0.823	-0.079	3.819	0.013	0.01	0	43.4	40	77.4	136	126	0	35	33
2014	9	19	0	58	19	0.797	-0.075	3.819	0.01	0.007	0	43	40.4	77.8	135	126	0	35	32
2014	9	19	1	8	19	0.787	-0.066	3.816	0.016	0.013	0	43	39.6	76.5	135	125	0	35	33
2014	9	19	1	18	19	0.781	-0.105	3.819	0.016	0.013	0	44.3	40.4	78.3	137	126	0	34	32
2014	9	19	1	28	19	0.761	-0.095	3.819	0.013	0.01	0	43.9	40	77	136	126	0	34	33
2014	9	19	1	38	19	0.761	-0.089	3.819	0.01	0.007	0	43.4	40	77	136	125	0	35	32
2014	9	19	1	48	19	0.768	-0.062	3.819	0.01	0.007	0	43.9	40.4	77.4	136	126	0	34	32
2014	9	19	1	58	19	0.807	-0.062	3.819	0.01	0.007	0	43.4	40	77.8	136	125	0	35	32
2014	9	19	2	8	19	0.771	-0.095	3.819	0.01	0.007	0	43	40	77.4	135	125	0	35	32
2014	9	19	2	18	19	0.781	-0.095	3.819	0.013	0.01	0	43.4	39.6	77.4	136	125	0	35	33
2014	9	19	2	28	19	0.781	-0.115	3.819	0.01	0.007	0	43.4	40.4	76.5	136	126	0	35	32
2014	9	19	2	38	19	0.794	-0.072	3.819	0.013	0.01	0	43	40	78.3	135	125	0	35	32
2014	9	19	2	48	19	0.823	-0.125	3.819	0.013	0.01	0	43	39.1	78.7	135	124	0	35	33
2014	9	19	2	58	19	0.823	-0.079	3.819	0.013	0.01	0	43.4	39.6	77.8	136	125	0	35	33
2014	9	19	3	8	19	0.797	-0.098	3.819	0.01	0.007	0	43.9	40	78.3	137	126	0	35	33
2014	9	19	3	18	19	0.794	-0.128	3.819	0.016	0.013	0	43.9	39.6	79.1	137	125	0	35	33
2014	9	19	3	28	19	0.794	-0.108	3.819	0.013	0.01	0	43.9	39.6	79.1	137	125	0	35	33
2014	9	19	3	38	19	0.778	-0.062	3.819	0.016	0.016	0	43.9	40	79.6	137	126	0	35	33
2014	9	19	3	48	19	0.797	-0.079	3.819	0.016	0.013	0	43.9	39.6	78.7	137	125	0	35	33
2014	9	19	3	58	19	0.791	-0.069	3.819	0.013	0.01	0	44.3	40	79.6	138	125	0	35	32
2014	9	19	4	8	19	0.807	-0.108	3.819	0.01	0.007	0	43.9	39.6	78.7	137	125	0	35	33
2014	9	19	4	18	19	0.823	-0.079	3.819	0.013	0.01	0	43.9	39.1	80	137	124	0	35	33
2014	9	19	4	28	19	0.804	-0.105	3.822	0.01	0.007	0	44.3	40.4	79.6	138	126	0	35	32
2014	9	19	4	38	19	0.774	-0.115	3.819	0.01	0.007	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	19	4	48	19	0.791	-0.092	3.822	0.01	0.007	0	44.3	40.4	80.8	138	126	0	35	32
2014	9	19	4	58	19	0.801	-0.085	3.822	0.01	0.007	0	44.3	40	80	138	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	5	8	19	0.823	-0.066	3.822	0.016	0.013	0	44.3	40.4	80.8	138	126	0	35	32
2014	9	19	5	18	19	0.797	-0.049	3.822	0.01	0.007	0	44.3	40.4	80.4	138	126	0	35	32
2014	9	19	5	28	19	0.817	-0.092	3.822	0.016	0.013	0	44.3	40.4	80.8	138	127	0	35	33
2014	9	19	5	38	19	0.791	-0.115	3.822	0.01	0.007	0	44.3	40	80	138	126	0	35	33
2014	9	19	5	48	19	0.84	-0.075	3.822	0.01	0.007	0	44.7	40.4	80	139	126	0	35	32
2014	9	19	5	58	19	0.804	-0.098	3.822	0.013	0.01	0	44.7	40.4	79.1	139	126	0	35	32
2014	9	19	6	8	19	0.804	-0.092	3.822	0.01	0.007	0	44.7	40.4	80	139	126	0	35	32
2014	9	19	6	18	19	0.837	-0.089	3.822	0.01	0.007	0	44.3	40.4	79.6	138	126	0	35	32
2014	9	19	6	28	19	0.82	-0.115	3.822	0.013	0.01	0	44.3	40	80	138	126	0	35	33
2014	9	19	6	38	19	0.807	-0.112	3.822	0.01	0.007	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	19	6	48	19	0.797	-0.089	3.822	0.01	0.007	0	43.4	38.7	80.4	136	123	0	35	33
2014	9	19	6	58	19	0.797	-0.092	3.822	0.01	0.007	0	43	39.1	80.4	135	123	0	35	32
2014	9	19	7	8	19	0.82	-0.118	3.822	0.013	0.01	0	43	38.3	80	135	122	0	35	33
2014	9	19	7	18	19	0.846	-0.108	3.822	0.01	0.007	0	43	38.3	80.8	135	122	0	35	33
2014	9	19	7	28	19	0.82	-0.092	3.822	0.016	0.013	0	42.6	38.3	79.6	135	122	0	36	33
2014	9	19	7	38	19	0.794	-0.085	3.822	0.016	0.013	0	43	38.3	80.4	135	122	0	35	33
2014	9	19	7	48	19	0.804	-0.059	3.822	0.01	0.007	0	43	38.3	80	135	122	0	35	33
2014	9	19	7	58	19	0.784	-0.075	3.822	0.013	0.01	0	43	38.3	80	135	122	0	35	33
2014	9	19	8	8	19	0.84	-0.098	3.822	0.013	0.01	0	42.6	38.3	80.4	134	122	0	35	33
2014	9	19	8	18	19	0.771	-0.102	3.825	0.01	0.007	0	42.6	38.3	80	134	122	0	35	33
2014	9	19	8	28	19	0.778	-0.052	3.825	0.01	0.007	0	42.6	38.3	80	134	122	0	35	33
2014	9	19	8	38	19	0.804	-0.105	3.825	0.01	0.007	0	42.6	38.3	80.8	134	121	0	35	32
2014	9	19	8	48	19	0.846	-0.089	3.825	0.016	0.013	0	42.6	38.3	80	134	122	0	35	33
2014	9	19	8	58	19	0.784	-0.069	3.822	0.013	0.01	0	42.1	37.8	80.4	133	121	0	35	33
2014	9	19	9	8	19	0.787	-0.092	3.825	0.016	0.013	0	42.1	37.8	80	133	121	0	35	33
2014	9	19	9	18	19	0.853	-0.075	3.825	0.016	0.016	0	42.1	37.8	80.4	133	121	0	35	33
2014	9	19	9	28	19	0.797	-0.082	3.825	0.016	0.013	0	42.1	37.8	78.3	133	121	0	35	33
2014	9	19	9	38	19	0.833	-0.092	3.825	0.01	0.007	0	43.4	39.6	72.7	137	124	0	36	32
2014	9	19	9	48	19	0.791	-0.066	3.825	0.013	0.01	0	44.3	39.6	72.7	138	125	0	35	33
2014	9	19	9	58	19	0.784	-0.062	3.822	0.016	0.016	0	44.7	40.4	62.4	139	127	0	35	33
2014	9	19	10	8	19	0.791	-0.105	3.822	0.01	0.007	0	44.7	40.9	58.5	140	128	0	36	33
2014	9	19	10	18	19	0.794	-0.039	3.822	0.013	0.01	0	45.2	41.3	57.6	140	128	0	35	32
2014	9	19	10	28	19	0.771	-0.066	3.822	0.013	0.01	0	45.2	40.4	62.8	140	127	0	35	33
2014	9	19	10	38	19	0.804	-0.059	3.822	0.01	0.007	0	44.3	40	64.9	138	126	0	35	33
2014	9	19	10	48	19	0.83	-0.059	3.825	0.01	0.007	0	43.9	39.6	67.1	137	125	0	35	33
2014	9	19	10	58	19	0.807	-0.069	3.825	0.01	0.007	0	43.4	39.1	71.8	136	124	0	35	33
2014	9	19	11	8	19	0.804	-0.059	3.825	0.013	0.01	0	43	38.7	80	135	123	0	35	33
2014	9	19	11	18	19	0.83	-0.092	3.825	0.01	0.007	0	43	38.7	79.1	135	122	0	35	32
2014	9	19	11	28	19	0.804	-0.082	3.825	0.01	0.007	0	42.6	38.3	79.1	134	122	0	35	33
2014	9	19	11	38	19	0.781	-0.095	3.822	0.01	0.007	0	42.6	38.3	76.1	134	122	0	35	33
2014	9	19	11	48	19	0.794	-0.085	3.825	0.016	0.013	0	42.6	38.3	80	134	122	0	35	33
2014	9	19	11	58	19	0.768	-0.085	3.822	0.01	0.007	0	42.1	37.8	79.6	133	121	0	35	33
2014	9	19	12	8	19	0.784	-0.085	3.822	0.01	0.007	0	42.1	38.3	79.1	133	122	0	35	33
2014	9	19	12	18	19	0.827	-0.052	3.822	0.013	0.01	0	42.6	37.8	80.8	134	121	0	35	33
2014	9	19	12	28	19	0.787	-0.072	3.822	0.013	0.01	0	42.1	38.3	77.8	133	121	0	35	32
2014	9	19	12	38	19	0.791	-0.095	3.822	0.013	0.01	0	42.6	37.8	79.1	133	121	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	12	48	19	0.797	-0.108	3.822	0.013	0.01	0	42.1	38.3	81.3	133	121	0	35	32
2014	9	19	12	58	19	0.778	-0.108	3.822	0.013	0.01	0	42.1	37.8	81.3	133	121	0	35	33
2014	9	19	13	8	19	0.791	-0.108	3.822	0.016	0.013	0	41.7	38.3	80.8	132	121	0	35	32
2014	9	19	13	18	19	0.784	-0.079	3.822	0.013	0.01	0	42.6	37.4	80	133	120	0	34	33
2014	9	19	13	28	19	0.814	-0.059	3.822	0.013	0.01	0	43	38.7	80	134	122	0	34	32
2014	9	19	13	38	19	0.843	-0.105	3.822	0.01	0.007	0	43	38.7	80	135	122	0	35	32
2014	9	19	13	48	19	0.764	-0.075	3.822	0.013	0.01	0	42.6	38.3	80.4	134	122	0	35	33
2014	9	19	13	58	19	0.778	-0.092	3.819	0.013	0.01	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	19	14	8	19	0.801	-0.108	3.819	0.013	0.01	0	42.1	37.8	78.3	133	121	0	35	33
2014	9	19	14	18	19	0.764	-0.108	3.819	0.01	0.007	0	42.1	37.8	69.2	133	121	0	35	33
2014	9	19	14	28	19	0.814	-0.085	3.816	0.016	0.013	0	42.6	38.3	64.9	134	122	0	35	33
2014	9	19	14	38	19	0.787	-0.082	3.819	0.01	0.007	0	43.4	38.3	79.1	135	122	0	34	33
2014	9	19	14	48	19	0.843	-0.092	3.819	0.013	0.01	0	43	39.1	77.4	135	123	0	35	32
2014	9	19	14	58	19	0.797	-0.095	3.819	0.01	0.007	0	43	38.3	79.1	134	122	0	34	33
2014	9	19	15	8	19	0.82	-0.072	3.819	0.013	0.01	0	42.6	38.7	78.7	134	122	0	35	32
2014	9	19	15	18	19	0.814	-0.085	3.819	0.016	0.016	0	42.6	38.3	79.1	134	122	0	35	33
2014	9	19	15	28	19	0.804	-0.115	3.816	0.01	0.007	0	42.6	38.7	74	134	122	0	35	32
2014	9	19	15	38	19	0.755	-0.066	3.816	0.01	0.007	0	43	38.7	75.7	135	123	0	35	33
2014	9	19	15	48	19	0.817	-0.085	3.816	0.013	0.01	0	42.6	39.1	78.7	134	123	0	35	32
2014	9	19	15	58	19	0.807	-0.108	3.816	0.016	0.013	0	43	38.3	79.1	134	122	0	34	33
2014	9	19	16	8	19	0.751	-0.079	3.812	0.01	0.007	0	43	38.3	78.3	134	122	0	34	33
2014	9	19	16	18	19	0.791	-0.085	3.812	0.01	0.007	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	19	16	28	19	0.781	-0.105	3.812	0.01	0.007	0	42.6	38.3	72.7	134	122	0	35	33
2014	9	19	16	38	19	0.784	-0.079	3.812	0.01	0.007	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	19	16	48	19	0.797	-0.115	3.812	0.01	0.007	0	42.6	37.8	77.4	134	121	0	35	33
2014	9	19	16	58	19	0.814	-0.046	3.809	0.01	0.007	0	42.6	38.7	77.4	134	122	0	35	32
2014	9	19	17	8	19	0.797	-0.085	3.812	0.013	0.01	0	43.4	38.7	77	135	123	0	34	33
2014	9	19	17	18	19	0.794	-0.059	3.809	0.013	0.01	0	43	39.1	77.4	135	123	0	35	32
2014	9	19	17	28	19	0.817	-0.108	3.809	0.01	0.007	0	43	38.7	77.4	135	123	0	35	33
2014	9	19	17	38	19	0.797	-0.095	3.809	0.013	0.01	0	43.9	38.7	77.4	136	123	0	34	33
2014	9	19	17	48	19	0.794	-0.072	3.809	0.016	0.013	0	43	39.1	78.3	135	123	0	35	32
2014	9	19	17	58	19	0.804	-0.092	3.806	0.01	0.007	0	43	39.1	77.4	135	123	0	35	32
2014	9	19	18	8	19	0.814	-0.092	3.809	0.016	0.013	0	43	38.7	76.5	135	122	0	35	32
2014	9	19	18	18	19	0.807	-0.112	3.809	0.016	0.013	0	43	38.7	77.8	135	123	0	35	33
2014	9	19	18	28	19	0.797	-0.092	3.809	0.01	0.007	0	43.4	38.7	77.4	136	123	0	35	33
2014	9	19	18	38	19	0.83	-0.085	3.809	0.016	0.016	0	43.4	39.6	76.5	135	124	0	34	32
2014	9	19	18	48	19	0.761	-0.098	3.809	0.01	0.007	0	44.3	39.1	77.4	137	124	0	34	33
2014	9	19	18	58	19	0.804	-0.092	3.809	0.013	0.01	0	43.9	39.1	75.3	137	124	0	35	33
2014	9	19	19	8	19	0.781	-0.112	3.809	0.01	0.007	0	43.9	39.6	74.4	137	125	0	35	33
2014	9	19	19	18	19	0.784	-0.108	3.812	0.013	0.01	0	44.3	40.4	77.4	138	126	0	35	32
2014	9	19	19	28	19	0.784	-0.079	3.809	0.01	0.007	0	44.7	40	73.1	138	125	0	34	32
2014	9	19	19	38	19	0.837	-0.079	3.812	0.01	0.007	0	44.7	40.4	76.1	139	127	0	35	33
2014	9	19	19	48	19	0.843	-0.092	3.812	0.016	0.013	0	44.7	40.9	77	139	127	0	35	32
2014	9	19	19	58	19	0.83	-0.095	3.816	0.01	0.007	0	44.3	40	76.5	138	126	0	35	33
2014	9	19	20	8	19	0.761	-0.082	3.812	0.013	0.01	0	44.3	40	76.5	138	126	0	35	33
2014	9	19	20	18	19	0.784	-0.108	3.816	0.01	0.007	0	45.2	40	77.8	139	126	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	19	20	28	19	0.84	-0.085	3.816	0.013	0.01	0	44.7	40	77	139	126	0	35	33
2014	9	19	20	38	19	0.801	-0.085	3.816	0.01	0.007	0	44.3	40	76.1	138	126	0	35	33
2014	9	19	20	48	19	0.807	-0.069	3.816	0.01	0.007	0	44.7	40	77.8	139	126	0	35	33
2014	9	19	20	58	19	0.83	-0.079	3.816	0.013	0.01	0	44.7	40.4	73.1	139	126	0	35	32
2014	9	19	21	8	19	0.837	-0.066	3.816	0.013	0.01	0	45.2	40	77.4	140	127	0	35	34
2014	9	19	21	18	19	0.82	-0.079	3.816	0.01	0.007	0	45.6	40.4	77.8	140	127	0	34	33
2014	9	19	21	28	19	0.797	-0.105	3.816	0.01	0.007	0	44.7	40.4	77.8	139	127	0	35	33
2014	9	19	21	38	19	0.771	-0.095	3.816	0.013	0.01	0	44.7	40.9	77	139	127	0	35	32
2014	9	19	21	48	19	0.781	-0.072	3.819	0.016	0.013	0	44.7	40	79.1	139	126	0	35	33
2014	9	19	21	58	19	0.751	-0.112	3.819	0.013	0.01	0	44.7	40.4	77.8	139	126	0	35	32
2014	9	19	22	8	19	0.814	-0.062	3.819	0.013	0.01	0	44.3	40.4	79.6	138	126	0	35	32
2014	9	19	22	18	19	0.797	-0.079	3.819	0.013	0.01	0	44.7	40.4	78.3	138	126	0	34	32
2014	9	19	22	28	19	0.778	-0.095	3.819	0.01	0.007	0	44.3	40.4	79.1	138	126	0	35	32
2014	9	19	22	38	19	0.794	-0.098	3.819	0.013	0.01	0	45.2	40.4	79.6	139	126	0	34	32
2014	9	19	22	48	19	0.787	-0.089	3.819	0.01	0.007	0	44.7	40.4	79.1	139	127	0	35	33
2014	9	19	22	58	19	0.787	-0.079	3.819	0.01	0.007	0	44.7	40.4	79.6	139	127	0	35	33
2014	9	19	23	8	19	0.787	-0.066	3.819	0.013	0.01	0	44.7	40.9	80	139	127	0	35	32
2014	9	19	23	18	19	0.804	-0.082	3.819	0.01	0.007	0	44.3	40.4	79.6	139	127	0	36	33
2014	9	19	23	28	19	0.794	-0.092	3.819	0.013	0.01	0	44.7	40	79.1	139	126	0	35	33
2014	9	19	23	38	19	0.791	-0.118	3.819	0.013	0.01	0	44.7	40.4	78.7	139	126	0	35	32
2014	9	19	23	48	19	0.837	-0.082	3.819	0.01	0.007	0	45.2	40	80.8	139	126	0	34	33
2014	9	19	23	58	19	0.81	-0.079	3.819	0.01	0.007	0	45.2	40.4	79.1	139	127	0	34	33
2014	9	20	0	8	19	0.791	-0.105	3.819	0.013	0.01	0	45.2	40.4	80	139	126	0	34	32
2014	9	20	0	18	19	0.794	-0.062	3.819	0.01	0.007	0	44.7	40.4	80.4	139	126	0	35	32
2014	9	20	0	28	19	0.778	-0.079	3.819	0.013	0.01	0	44.7	40.4	80	139	126	0	35	32
2014	9	20	0	38	19	0.791	-0.085	3.819	0.01	0.007	0	44.3	40	79.6	138	126	0	35	33
2014	9	20	0	48	19	0.787	-0.108	3.819	0.016	0.016	0	44.7	40.4	71.4	139	127	0	35	33
2014	9	20	0	58	19	0.817	-0.112	3.822	0.013	0.01	0	45.2	40.4	80	139	127	0	34	33
2014	9	20	1	8	19	0.791	-0.069	3.822	0.01	0.007	0	45.2	40.9	80	139	127	0	34	32
2014	9	20	1	18	19	0.778	-0.095	3.822	0.013	0.01	0	44.7	40.9	80	139	127	0	35	32
2014	9	20	1	28	19	0.807	-0.089	3.822	0.01	0.007	0	44.7	40.9	80.8	139	127	0	35	32
2014	9	20	1	38	19	0.778	-0.069	3.822	0.013	0.01	0	46	41.7	81.3	142	129	0	35	32
2014	9	20	1	48	19	0.817	-0.092	3.822	0.013	0.01	0	45.2	40.9	81.3	140	127	0	35	32
2014	9	20	1	58	19	0.837	-0.075	3.822	0.01	0.007	0	45.2	40.4	80.8	140	127	0	35	33
2014	9	20	2	8	19	0.797	-0.098	3.822	0.01	0.007	0	44.7	39.6	80.8	139	126	0	35	34
2014	9	20	2	18	19	0.846	-0.082	3.822	0.013	0.01	0	44.3	39.6	82.1	138	125	0	35	33
2014	9	20	2	28	19	0.784	-0.075	3.822	0.013	0.01	0	44.3	40	81.7	138	126	0	35	33
2014	9	20	2	38	19	0.787	-0.072	3.822	0.01	0.007	0	44.3	39.6	82.1	138	125	0	35	33
2014	9	20	2	48	19	0.774	-0.098	3.822	0.02	0.016	0	44.3	39.6	80.8	138	125	0	35	33
2014	9	20	2	58	19	0.771	-0.062	3.822	0.01	0.007	0	43.9	39.6	82.1	137	125	0	35	33
2014	9	20	3	8	19	0.791	-0.105	3.822	0.01	0.007	0	43.9	39.6	82.1	137	125	0	35	33
2014	9	20	3	18	19	0.761	-0.102	3.822	0.01	0.007	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	20	3	28	19	0.791	-0.082	3.822	0.01	0.007	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	20	3	38	19	0.833	-0.102	3.822	0.01	0.007	0	43.4	39.1	81.7	137	124	0	36	33
2014	9	20	3	48	19	0.82	-0.072	3.822	0.01	0.007	0	43.9	40	81.7	137	125	0	35	32
2014	9	20	3	58	19	0.827	-0.095	3.822	0.01	0.007	0	43.9	40	81.3	138	126	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	4	8	19	0.804	-0.069	3.822	0.01	0.007	0	44.3	39.6	81.3	138	125	0	35	33
2014	9	20	4	18	19	0.771	-0.049	3.822	0.016	0.013	0	44.7	40	80.8	138	125	0	34	32
2014	9	20	4	28	19	0.791	-0.089	3.822	0.01	0.007	0	44.7	40.4	80.8	139	126	0	35	32
2014	9	20	4	38	19	0.814	-0.098	3.822	0.016	0.013	0	43.9	39.6	80.4	137	125	0	35	33
2014	9	20	4	48	19	0.801	-0.089	3.822	0.01	0.007	0	43.9	39.6	80.4	138	125	0	36	33
2014	9	20	4	58	19	0.801	-0.108	3.822	0.01	0.007	0	44.3	39.6	80.8	138	125	0	35	33
2014	9	20	5	8	19	0.791	-0.089	3.822	0.013	0.01	0	44.3	40	80.8	138	126	0	35	33
2014	9	20	5	18	19	0.801	-0.082	3.822	0.01	0.007	0	44.3	40	80.8	138	126	0	35	33
2014	9	20	5	28	19	0.797	-0.059	3.825	0.01	0.007	0	44.3	39.6	81.3	138	125	0	35	33
2014	9	20	5	38	19	0.81	-0.095	3.822	0.016	0.013	0	43.9	39.1	81.3	137	124	0	35	33
2014	9	20	5	48	19	0.807	-0.072	3.822	0.01	0.007	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	20	5	58	19	0.774	-0.092	3.822	0.013	0.01	0	43.9	39.6	79.1	138	125	0	36	33
2014	9	20	6	8	19	0.784	-0.066	3.822	0.013	0.01	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	20	6	18	19	0.814	-0.102	3.822	0.01	0.007	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	20	6	28	19	0.781	-0.059	3.822	0.013	0.01	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	20	6	38	19	0.784	-0.098	3.822	0.01	0.007	0	43.4	38.7	79.6	136	123	0	35	33
2014	9	20	6	48	19	0.823	-0.105	3.822	0.01	0.007	0	43	38.7	79.6	135	123	0	35	33
2014	9	20	6	58	19	0.83	-0.075	3.822	0.01	0.007	0	43.4	39.1	79.1	136	123	0	35	32
2014	9	20	7	8	19	0.807	-0.098	3.822	0.01	0.007	0	42.6	38.3	79.6	134	122	0	35	33
2014	9	20	7	18	19	0.81	-0.085	3.825	0.016	0.013	0	42.6	37.8	78.7	134	121	0	35	33
2014	9	20	7	28	19	0.83	-0.092	3.825	0.01	0.007	0	42.1	37.4	80.4	133	120	0	35	33
2014	9	20	7	38	19	0.791	-0.092	3.825	0.01	0.007	0	42.1	37.8	80.4	133	120	0	35	32
2014	9	20	7	48	19	0.84	-0.105	3.825	0.01	0.007	0	42.1	37.4	80	133	120	0	35	33
2014	9	20	7	58	19	0.827	-0.075	3.825	0.013	0.01	0	42.1	37.4	79.6	133	120	0	35	33
2014	9	20	8	8	19	0.804	-0.092	3.825	0.013	0.01	0	42.1	37.8	79.1	133	121	0	35	33
2014	9	20	8	18	19	0.797	-0.115	3.825	0.013	0.01	0	42.1	37.4	79.1	133	120	0	35	33
2014	9	20	8	28	19	0.804	-0.095	3.825	0.01	0.007	0	41.7	37	80	132	119	0	35	33
2014	9	20	8	38	19	0.797	-0.098	3.825	0.01	0.007	0	41.7	37	80	132	119	0	35	33
2014	9	20	8	48	19	0.82	-0.092	3.825	0.01	0.007	0	41.3	37.4	79.6	132	120	0	36	33
2014	9	20	8	58	19	0.797	-0.108	3.825	0.013	0.01	0	41.7	37.4	78.3	132	119	0	35	32
2014	9	20	9	8	19	0.823	-0.092	3.825	0.01	0.007	0	42.1	37.4	80	133	120	0	35	33
2014	9	20	9	18	19	0.787	-0.092	3.825	0.016	0.013	0	41.7	37.4	79.6	132	120	0	35	33
2014	9	20	9	28	19	0.807	-0.075	3.825	0.013	0.01	0	41.7	37	79.1	132	119	0	35	33
2014	9	20	9	38	19	0.81	-0.092	3.825	0.01	0.007	0	41.7	37.4	79.6	132	120	0	35	33
2014	9	20	9	48	19	0.774	-0.089	3.825	0.01	0.007	0	41.7	37.4	79.1	132	120	0	35	33
2014	9	20	9	58	19	0.787	-0.085	3.825	0.01	0.007	0	41.7	37.4	79.1	133	120	0	36	33
2014	9	20	10	8	19	0.791	-0.089	3.825	0.01	0.007	0	42.1	37.4	79.6	133	120	0	35	33
2014	9	20	10	18	19	0.843	-0.089	3.825	0.013	0.01	0	41.7	37.4	78.7	132	120	0	35	33
2014	9	20	10	28	19	0.801	-0.066	3.825	0.01	0.007	0	41.7	37.4	80	132	120	0	35	33
2014	9	20	10	38	19	0.82	-0.095	3.825	0.01	0.007	0	41.7	37.4	80.4	132	120	0	35	33
2014	9	20	10	48	19	0.83	-0.075	3.825	0.01	0.007	0	42.1	37.8	79.6	133	121	0	35	33
2014	9	20	10	58	19	0.804	-0.108	3.825	0.01	0.007	0	41.7	37.4	71.4	132	119	0	35	32
2014	9	20	11	8	19	0.791	-0.089	3.825	0.016	0.013	0	41.7	37.4	73.5	132	120	0	35	33
2014	9	20	11	18	19	0.82	-0.092	3.825	0.013	0.01	0	41.7	37	76.1	132	119	0	35	33
2014	9	20	11	28	19	0.797	-0.108	3.822	0.016	0.013	0	43	38.7	65.4	135	123	0	35	33
2014	9	20	11	38	19	0.797	-0.082	3.825	0.013	0.01	0	40.9	36.5	73.5	130	118	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	11	48	19	0.791	-0.075	3.822	0.01	0.007	0	40.4	36.5	66.7	130	118	0	36	33
2014	9	20	11	58	19	0.771	-0.098	3.825	0.013	0.01	0	40.9	37	71.8	130	118	0	35	32
2014	9	20	12	8	19	0.807	-0.089	3.825	0.016	0.013	0	40.9	36.5	77.4	130	118	0	35	33
2014	9	20	12	18	19	0.774	-0.105	3.822	0.01	0.007	0	40.9	36.1	61.5	130	117	0	35	33
2014	9	20	12	28	19	0.764	-0.072	3.822	0.01	0.007	0	41.3	36.5	57.2	131	118	0	35	33
2014	9	20	12	38	19	0.774	-0.089	3.822	0.02	0.016	0	40.9	36.5	59.3	130	118	0	35	33
2014	9	20	12	48	19	0.774	-0.082	3.822	0.01	0.007	0	41.3	37	75.3	131	118	0	35	32
2014	9	20	12	58	19	0.741	-0.079	3.822	0.01	0.007	0	40.9	36.5	61.5	130	118	0	35	33
2014	9	20	13	8	19	0.794	-0.102	3.819	0.013	0.01	0	41.7	37	56.3	132	119	0	35	33
2014	9	20	13	18	19	0.791	-0.092	3.822	0.013	0.01	0	41.3	36.5	61.9	131	118	0	35	33
2014	9	20	13	28	19	0.801	-0.075	3.819	0.013	0.01	0	41.3	37	66.2	131	119	0	35	33
2014	9	20	13	38	19	0.761	-0.056	3.819	0.013	0.01	0	41.7	37.4	61.5	132	120	0	35	33
2014	9	20	13	48	19	0.748	-0.095	3.819	0.01	0.007	0	41.3	37	56.8	131	119	0	35	33
2014	9	20	13	58	19	0.771	-0.098	3.819	0.016	0.016	0	41.7	37.4	67.9	132	119	0	35	32
2014	9	20	14	8	19	0.778	-0.092	3.819	0.013	0.01	0	41.7	37.4	62.8	132	120	0	35	33
2014	9	20	14	18	19	0.787	-0.072	3.816	0.01	0.007	0	41.3	37.4	59.3	132	120	0	36	33
2014	9	20	14	28	19	0.791	-0.082	3.819	0.013	0.01	0	41.7	37.8	66.2	132	120	0	35	32
2014	9	20	14	38	19	0.81	-0.095	3.819	0.016	0.013	0	41.7	37.4	67.1	132	120	0	35	33
2014	9	20	14	48	19	0.774	-0.095	3.816	0.013	0.01	0	42.1	37.8	65.8	133	121	0	35	33
2014	9	20	14	58	19	0.784	-0.102	3.812	0.016	0.013	0	42.1	37.8	55	133	121	0	35	33
2014	9	20	15	8	19	0.781	-0.095	3.816	0.01	0.007	0	42.1	37.8	58.5	133	121	0	35	33
2014	9	20	15	18	19	0.791	-0.102	3.812	0.013	0.01	0	42.1	38.3	60.6	133	121	0	35	32
2014	9	20	15	28	19	0.801	-0.108	3.816	0.01	0.007	0	42.1	38.3	64.9	133	121	0	35	32
2014	9	20	15	38	19	0.83	-0.079	3.812	0.01	0.007	0	42.1	38.7	58.5	133	122	0	35	32
2014	9	20	15	48	19	0.791	-0.128	3.812	0.013	0.01	0	42.1	38.3	64.5	134	122	0	36	33
2014	9	20	15	58	19	0.82	-0.098	3.812	0.01	0.007	0	42.6	38.3	53.3	134	122	0	35	33
2014	9	20	16	8	19	0.764	-0.089	3.816	0.013	0.01	0	42.6	37.8	74.4	134	121	0	35	33
2014	9	20	16	18	19	0.761	-0.085	3.816	0.013	0.01	0	42.6	37.8	74.4	134	121	0	35	33
2014	9	20	16	28	19	0.797	-0.082	3.806	0.013	0.01	0	42.6	37.8	54.6	134	122	0	35	34
2014	9	20	16	38	19	0.817	-0.095	3.816	0.016	0.013	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	20	16	48	19	0.784	-0.079	3.812	0.013	0.01	0	42.6	37.8	71.4	134	121	0	35	33
2014	9	20	16	58	19	0.797	-0.079	3.806	0.016	0.013	0	42.6	38.3	57.6	134	123	0	35	34
2014	9	20	17	8	19	0.761	-0.072	3.812	0.013	0.01	0	42.6	38.7	75.3	135	122	0	36	32
2014	9	20	17	18	19	0.82	-0.079	3.812	0.01	0.007	0	43.4	39.1	76.5	136	123	0	35	32
2014	9	20	17	28	19	0.823	-0.092	3.812	0.016	0.013	0	43.4	38.7	77	136	123	0	35	33
2014	9	20	17	38	19	0.83	-0.098	3.812	0.013	0.01	0	43.4	39.1	77	136	124	0	35	33
2014	9	20	17	48	19	0.843	-0.079	3.812	0.013	0.01	0	43.4	38.7	77	136	123	0	35	33
2014	9	20	17	58	19	0.807	-0.079	3.812	0.013	0.01	0	43.4	39.1	77.4	136	123	0	35	32
2014	9	20	18	8	19	0.807	-0.085	3.812	0.013	0.01	0	43.4	39.6	76.5	136	124	0	35	32
2014	9	20	18	18	19	0.817	-0.069	3.812	0.01	0.007	0	43.4	39.1	77	136	124	0	35	33
2014	9	20	18	28	19	0.804	-0.092	3.812	0.013	0.01	0	43.9	39.1	77.8	137	124	0	35	33
2014	9	20	18	38	19	0.778	-0.092	3.812	0.013	0.01	0	43.9	39.1	77.4	137	124	0	35	33
2014	9	20	18	48	19	0.771	-0.072	3.816	0.01	0.007	0	43.4	39.1	77.8	136	124	0	35	33
2014	9	20	18	58	19	0.768	-0.052	3.812	0.013	0.01	0	43.9	39.6	75.3	137	125	0	35	33
2014	9	20	19	8	19	0.791	-0.105	3.812	0.01	0.007	0	44.7	40.4	71	139	126	0	35	32
2014	9	20	19	18	19	0.801	-0.108	3.806	0.01	0.007	0	44.7	40.9	54.6	139	127	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	20	19	28	19	0.791	-0.085	3.806	0.013	0.01	0	45.2	40.9	51.6	140	128	0	35	33
2014	9	20	19	38	19	0.83	-0.072	3.812	0.013	0.01	0	45.6	40.9	68.8	141	128	0	35	33
2014	9	20	19	48	19	0.784	-0.108	3.812	0.013	0.01	0	45.2	40.9	67.9	140	128	0	35	33
2014	9	20	19	58	19	0.797	-0.066	3.816	0.013	0.01	0	45.2	40.4	74	140	127	0	35	33
2014	9	20	20	8	19	0.725	-0.092	3.806	0.016	0.013	0	46	40.9	52.9	142	128	0	35	33
2014	9	20	20	18	19	0.768	-0.069	3.809	0.01	0.007	0	46.9	41.3	51.6	143	129	0	34	33
2014	9	20	20	28	19	0.804	-0.082	3.812	0.01	0.007	0	46.9	42.1	52.5	144	131	0	35	33
2014	9	20	20	38	19	0.814	-0.082	3.812	0.013	0.01	0	46.4	41.7	56.3	143	129	0	35	32
2014	9	20	20	48	19	0.791	-0.072	3.816	0.013	0.01	0	46	41.3	77.8	142	129	0	35	33
2014	9	20	20	58	19	0.807	-0.108	3.816	0.013	0.01	0	45.6	40.9	78.7	140	127	0	34	32
2014	9	20	21	8	19	0.771	-0.072	3.816	0.016	0.013	0	45.2	40	78.3	140	126	0	35	33
2014	9	20	21	18	19	0.823	-0.098	3.816	0.01	0.007	0	44.7	40.4	79.6	139	126	0	35	32
2014	9	20	21	28	19	0.85	-0.085	3.816	0.016	0.013	0	44.7	40	79.6	139	126	0	35	33
2014	9	20	21	38	19	0.774	-0.112	3.816	0.013	0.01	0	45.2	40	76.1	140	126	0	35	33
2014	9	20	21	48	19	0.814	-0.089	3.816	0.01	0.007	0	45.2	40.4	74.4	140	127	0	35	33
2014	9	20	21	58	19	0.827	-0.092	3.819	0.01	0.007	0	44.7	40.4	79.1	139	126	0	35	32
2014	9	20	22	8	19	0.801	-0.085	3.816	0.013	0.01	0	44.7	40	80.4	139	126	0	35	33
2014	9	20	22	18	19	0.82	-0.108	3.819	0.013	0.01	0	44.3	40.4	79.1	139	126	0	36	32
2014	9	20	22	28	19	0.794	-0.108	3.819	0.01	0.007	0	44.7	40	80.8	139	126	0	35	33
2014	9	20	22	38	19	0.807	-0.072	3.819	0.013	0.01	0	44.7	40	80.4	139	126	0	35	33
2014	9	20	22	48	19	0.801	-0.075	3.819	0.013	0.01	0	45.2	40.4	78.3	140	127	0	35	33
2014	9	20	22	58	19	0.833	-0.121	3.819	0.016	0.016	0	44.7	40	79.6	139	126	0	35	33
2014	9	20	23	8	19	0.814	-0.072	3.819	0.013	0.01	0	44.3	40	80	138	126	0	35	33
2014	9	20	23	18	19	0.823	-0.092	3.819	0.013	0.01	0	45.2	39.6	79.6	139	126	0	34	34
2014	9	20	23	28	19	0.81	-0.085	3.819	0.016	0.013	0	44.7	40	80.4	139	126	0	35	33
2014	9	20	23	38	19	0.823	-0.079	3.819	0.01	0.007	0	44.7	40.4	80.8	139	126	0	35	32
2014	9	20	23	48	19	0.781	-0.082	3.819	0.01	0.007	0	44.3	40.4	81.3	139	126	0	36	32
2014	9	20	23	58	19	0.801	-0.069	3.819	0.013	0.01	0	44.3	39.6	80.8	138	125	0	35	33
2014	9	21	0	8	19	0.761	-0.062	3.819	0.01	0.007	0	44.3	40	81.3	138	126	0	35	33
2014	9	21	0	18	19	0.797	-0.082	3.819	0.013	0.01	0	44.7	40	81.3	139	126	0	35	33
2014	9	21	0	28	19	0.837	-0.075	3.819	0.01	0.007	0	44.7	40.4	80.8	139	126	0	35	32
2014	9	21	0	38	19	0.833	-0.075	3.822	0.01	0.007	0	43.9	40	81.3	137	125	0	35	32
2014	9	21	0	48	19	0.797	-0.066	3.822	0.01	0.007	0	44.3	39.6	81.3	138	125	0	35	33
2014	9	21	0	58	19	0.781	-0.059	3.819	0.016	0.016	0	44.7	40	80.4	139	126	0	35	33
2014	9	21	1	8	19	0.807	-0.105	3.822	0.01	0.007	0	44.3	40	80.8	138	125	0	35	32
2014	9	21	1	18	19	0.781	-0.072	3.822	0.01	0.007	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	21	1	28	19	0.804	-0.082	3.822	0.01	0.007	0	43.9	39.6	80.8	137	125	0	35	33
2014	9	21	1	38	19	0.778	-0.079	3.822	0.016	0.013	0	44.3	39.6	78.7	138	125	0	35	33
2014	9	21	1	48	19	0.814	-0.075	3.822	0.01	0.007	0	44.7	40.4	77	139	126	0	35	32
2014	9	21	1	58	19	0.797	-0.115	3.822	0.01	0.007	0	44.3	40	80.4	138	125	0	35	32
2014	9	21	2	8	19	0.804	-0.098	3.819	0.013	0.01	0	45.2	40.4	62.4	140	126	0	35	32
2014	9	21	2	18	19	0.787	-0.075	3.822	0.01	0.007	0	44.3	40	61.9	139	126	0	36	33
2014	9	21	2	28	19	0.781	-0.066	3.819	0.016	0.016	0	46.4	41.7	48.6	143	130	0	35	33
2014	9	21	2	38	19	0.84	-0.075	3.822	0.013	0.01	0	45.6	41.3	74.8	141	128	0	35	32
2014	9	21	2	48	19	0.82	-0.059	3.822	0.01	0.007	0	45.6	40.9	78.3	141	128	0	35	33
2014	9	21	2	58	19	0.833	-0.102	3.822	0.01	0.007	0	45.2	40	79.6	139	126	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	3	8	19	0.876	-0.059	3.822	0.013	0.01	0	44.3	39.6	80	138	125	0	35	33
2014	9	21	3	18	19	0.801	-0.062	3.825	0.013	0.01	0	44.7	39.6	79.1	139	125	0	35	33
2014	9	21	3	28	19	0.82	-0.098	3.825	0.01	0.007	0	44.3	39.6	78.7	138	125	0	35	33
2014	9	21	3	38	19	0.85	-0.079	3.825	0.013	0.01	0	43.4	39.6	79.6	137	124	0	36	32
2014	9	21	3	48	19	0.823	-0.075	3.825	0.01	0.007	0	43.9	39.1	79.1	137	124	0	35	33
2014	9	21	3	58	19	0.827	-0.118	3.825	0.01	0.007	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	21	4	8	19	0.794	-0.118	3.825	0.01	0.007	0	43.9	40	79.1	137	125	0	35	32
2014	9	21	4	18	19	0.83	-0.049	3.825	0.013	0.01	0	44.7	39.6	79.6	139	125	0	35	33
2014	9	21	4	28	19	0.797	-0.098	3.825	0.013	0.01	0	44.3	39.6	79.1	138	125	0	35	33
2014	9	21	4	38	19	0.82	-0.105	3.825	0.01	0.007	0	44.3	39.6	80	138	125	0	35	33
2014	9	21	4	48	19	0.82	-0.069	3.825	0.013	0.01	0	43.9	39.6	79.6	137	125	0	35	33
2014	9	21	4	58	19	0.82	-0.095	3.825	0.01	0.007	0	43.9	39.1	79.1	137	124	0	35	33
2014	9	21	5	8	19	0.833	-0.075	3.825	0.01	0.007	0	44.3	40	80.4	138	125	0	35	32
2014	9	21	5	18	19	0.843	-0.095	3.825	0.013	0.01	0	43.9	39.1	79.1	137	124	0	35	33
2014	9	21	5	28	19	0.84	-0.105	3.825	0.01	0.007	0	43.9	39.6	80	138	125	0	36	33
2014	9	21	5	38	19	0.801	-0.066	3.825	0.016	0.013	0	44.3	39.6	80	138	125	0	35	33
2014	9	21	5	48	19	0.784	-0.098	3.825	0.01	0.007	0	44.7	40.4	80	139	126	0	35	32
2014	9	21	5	58	19	0.83	-0.066	3.825	0.01	0.007	0	45.2	40.4	79.6	140	127	0	35	33
2014	9	21	6	8	19	0.827	-0.069	3.825	0.01	0.007	0	44.3	39.6	79.6	138	125	0	35	33
2014	9	21	6	18	19	0.804	-0.095	3.825	0.01	0.007	0	44.3	39.6	80	138	125	0	35	33
2014	9	21	6	28	19	0.82	-0.085	3.825	0.016	0.013	0	44.3	39.6	78.7	138	125	0	35	33
2014	9	21	6	38	19	0.81	-0.085	3.825	0.013	0.01	0	43.9	39.1	79.6	137	124	0	35	33
2014	9	21	6	48	19	0.758	-0.098	3.825	0.016	0.013	0	43.4	38.7	79.6	136	123	0	35	33
2014	9	21	6	58	19	0.817	-0.095	3.825	0.01	0.007	0	43.9	38.7	79.1	137	123	0	35	33
2014	9	21	7	8	19	0.817	-0.079	3.825	0.013	0.01	0	43.4	38.7	79.6	136	123	0	35	33
2014	9	21	7	18	19	0.82	-0.085	3.829	0.013	0.01	0	43	38.7	80	135	123	0	35	33
2014	9	21	7	28	19	0.801	-0.112	3.829	0.01	0.007	0	43	38.7	78.7	135	122	0	35	32
2014	9	21	7	38	19	0.82	-0.095	3.829	0.01	0.007	0	43	38.7	79.6	135	122	0	35	32
2014	9	21	7	48	19	0.82	-0.062	3.829	0.01	0.007	0	42.6	39.1	78.7	135	123	0	36	32
2014	9	21	7	58	19	0.82	-0.069	3.829	0.01	0.007	0	43.4	38.7	78.7	136	123	0	35	33
2014	9	21	8	8	19	0.837	-0.095	3.829	0.013	0.01	0	42.6	38.3	78.7	134	122	0	35	33
2014	9	21	8	18	19	0.83	-0.075	3.829	0.013	0.01	0	43	38.7	78.7	135	123	0	35	33
2014	9	21	8	28	19	0.807	-0.098	3.829	0.013	0.01	0	42.6	38.3	78.3	135	122	0	36	33
2014	9	21	8	38	19	0.83	-0.115	3.829	0.013	0.01	0	43	38.3	78.7	134	122	0	34	33
2014	9	21	8	48	19	0.801	-0.089	3.829	0.016	0.013	0	42.6	38.7	78.7	134	122	0	35	32
2014	9	21	8	58	19	0.807	-0.089	3.829	0.01	0.007	0	43.4	39.1	78.7	136	123	0	35	32
2014	9	21	9	8	19	0.768	-0.082	3.829	0.01	0.007	0	42.6	38.3	78.7	134	122	0	35	33
2014	9	21	9	18	19	0.807	-0.072	3.829	0.01	0.007	0	43	38.7	77.8	135	123	0	35	33
2014	9	21	9	28	19	0.846	-0.105	3.829	0.013	0.01	0	42.6	37.4	78.7	134	121	0	35	34
2014	9	21	9	38	19	0.823	-0.089	3.829	0.01	0.007	0	42.1	37.8	78.3	133	120	0	35	32
2014	9	21	9	48	19	0.801	-0.062	3.829	0.01	0.007	0	42.1	37.8	79.6	133	121	0	35	33
2014	9	21	9	58	19	0.814	-0.092	3.829	0.01	0.007	0	42.1	38.3	80	133	121	0	35	32
2014	9	21	10	8	19	0.801	-0.112	3.832	0.01	0.007	0	41.7	37.8	79.1	133	121	0	36	33
2014	9	21	10	18	19	0.804	-0.069	3.832	0.01	0.007	0	41.7	37.4	80	132	120	0	35	33
2014	9	21	10	28	19	0.833	-0.089	3.832	0.01	0.007	0	42.1	37.4	80	133	120	0	35	33
2014	9	21	10	38	19	0.804	-0.118	3.832	0.016	0.013	0	41.7	37.4	80	132	120	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	10	48	19	0.801	-0.095	3.832	0.01	0.007	0	41.7	37.4	80.4	132	120	0	35	33
2014	9	21	10	58	19	0.837	-0.082	3.832	0.016	0.013	0	41.7	37.8	79.1	132	120	0	35	32
2014	9	21	11	8	19	0.823	-0.092	3.832	0.016	0.013	0	41.7	37.8	80.8	132	120	0	35	32
2014	9	21	11	18	19	0.833	-0.095	3.832	0.013	0.01	0	41.7	37.4	80	132	120	0	35	33
2014	9	21	11	28	19	0.771	-0.089	3.829	0.01	0.007	0	42.1	37.4	81.3	132	120	0	34	33
2014	9	21	11	38	19	0.837	-0.118	3.829	0.01	0.007	0	41.7	37.4	80.8	132	120	0	35	33
2014	9	21	11	48	19	0.794	-0.102	3.829	0.013	0.01	0	41.7	37.8	81.3	132	120	0	35	32
2014	9	21	11	58	19	0.837	-0.092	3.829	0.01	0.007	0	42.1	37.8	80.4	133	121	0	35	33
2014	9	21	12	8	19	0.804	-0.082	3.829	0.016	0.013	0	42.1	37.8	80.4	133	121	0	35	33
2014	9	21	12	18	19	0.801	-0.075	3.829	0.013	0.01	0	41.7	37.4	80	132	120	0	35	33
2014	9	21	12	28	19	0.801	-0.085	3.829	0.013	0.01	0	41.3	37.4	81.7	131	119	0	35	32
2014	9	21	12	38	19	0.791	-0.095	3.829	0.01	0.007	0	41.7	37.4	81.7	132	120	0	35	33
2014	9	21	12	48	19	0.823	-0.075	3.829	0.013	0.01	0	42.1	37.8	79.1	133	121	0	35	33
2014	9	21	12	58	19	0.814	-0.082	3.825	0.01	0.007	0	42.1	37.8	61.1	133	121	0	35	33
2014	9	21	13	8	19	0.804	-0.098	3.829	0.013	0.01	0	43	38.7	72.2	135	123	0	35	33
2014	9	21	13	18	19	0.735	-0.085	3.825	0.013	0.01	0	42.6	37.8	72.7	134	121	0	35	33
2014	9	21	13	28	19	0.807	-0.095	3.825	0.01	0.007	0	42.6	38.3	78.7	134	122	0	35	33
2014	9	21	13	38	19	0.781	-0.072	3.825	0.01	0.007	0	43	38.3	75.7	135	122	0	35	33
2014	9	21	13	48	19	0.807	-0.085	3.825	0.016	0.013	0	42.6	38.7	71	134	122	0	35	32
2014	9	21	13	58	19	0.784	-0.112	3.825	0.01	0.007	0	42.6	38.7	60.6	134	122	0	35	32
2014	9	21	14	8	19	0.794	-0.102	3.825	0.013	0.01	0	42.6	38.7	74.8	134	122	0	35	32
2014	9	21	14	18	19	0.823	-0.128	3.825	0.01	0.007	0	42.6	38.7	70.1	134	122	0	35	32
2014	9	21	14	28	19	0.797	-0.079	3.825	0.01	0.007	0	42.6	38.3	80.8	134	122	0	35	33
2014	9	21	14	38	19	0.823	-0.108	3.829	0.01	0.007	0	42.6	37.8	80.8	134	121	0	35	33
2014	9	21	14	48	19	0.823	-0.095	3.825	0.01	0.007	0	42.6	38.3	61.5	134	122	0	35	33
2014	9	21	14	58	19	0.794	-0.102	3.825	0.013	0.01	0	42.1	37.8	69.7	133	121	0	35	33
2014	9	21	15	8	19	0.817	-0.075	3.825	0.013	0.01	0	42.6	38.3	77.4	134	122	0	35	33
2014	9	21	15	18	19	0.82	-0.092	3.825	0.01	0.007	0	42.1	38.7	73.1	133	122	0	35	32
2014	9	21	15	28	19	0.843	-0.079	3.822	0.01	0.007	0	42.6	38.7	59.3	134	122	0	35	32
2014	9	21	15	38	19	0.764	-0.069	3.825	0.016	0.013	0	43	38.3	72.7	134	122	0	34	33
2014	9	21	15	48	19	0.804	-0.098	3.822	0.01	0.007	0	43	38.7	67.1	135	122	0	35	32
2014	9	21	15	58	19	0.748	-0.085	3.825	0.013	0.01	0	43	38.7	80	135	123	0	35	33
2014	9	21	16	8	19	0.807	-0.079	3.825	0.013	0.01	0	43	38.7	78.3	135	123	0	35	33
2014	9	21	16	18	19	0.804	-0.082	3.825	0.01	0.007	0	43	38.7	82.1	135	122	0	35	32
2014	9	21	16	28	19	0.82	-0.059	3.825	0.013	0.01	0	43	39.1	81.3	135	123	0	35	32
2014	9	21	16	38	19	0.833	-0.069	3.825	0.013	0.01	0	43	38.3	81.3	135	122	0	35	33
2014	9	21	16	48	19	0.794	-0.075	3.822	0.013	0.01	0	42.6	38.3	81.3	134	122	0	35	33
2014	9	21	16	58	19	0.81	-0.072	3.825	0.013	0.01	0	42.6	38.3	80.4	134	121	0	35	32
2014	9	21	17	8	19	0.82	-0.092	3.825	0.01	0.007	0	42.1	37.8	79.6	133	121	0	35	33
2014	9	21	17	18	19	0.823	-0.105	3.825	0.01	0.007	0	42.6	38.3	81.3	134	122	0	35	33
2014	9	21	17	28	19	0.794	-0.102	3.822	0.01	0.007	0	42.1	38.3	81.3	133	121	0	35	32
2014	9	21	17	38	19	0.804	-0.105	3.825	0.013	0.01	0	42.1	37.8	80.8	133	121	0	35	33
2014	9	21	17	48	19	0.791	-0.102	3.825	0.01	0.007	0	42.1	38.3	81.3	133	121	0	35	32
2014	9	21	17	58	19	0.801	-0.079	3.825	0.013	0.01	0	42.6	37.8	78.7	134	121	0	35	33
2014	9	21	18	8	19	0.82	-0.115	3.825	0.013	0.01	0	42.6	37.8	82.1	134	121	0	35	33
2014	9	21	18	18	19	0.823	-0.112	3.822	0.016	0.013	0	43	38.3	81.3	135	122	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	21	18	28	19	0.804	-0.082	3.825	0.013	0.01	0	42.6	37.4	81.7	134	121	0	35	34
2014	9	21	18	38	19	0.837	-0.089	3.825	0.01	0.007	0	43.4	38.7	81.7	135	122	0	34	32
2014	9	21	18	48	19	0.823	-0.092	3.825	0.01	0.007	0	43.4	38.3	81.3	136	123	0	35	34
2014	9	21	18	58	19	0.843	-0.102	3.825	0.01	0.007	0	43.4	38.7	81.7	136	123	0	35	33
2014	9	21	19	8	19	0.814	-0.072	3.825	0.013	0.01	0	43.9	39.1	80.8	136	124	0	34	33
2014	9	21	19	18	19	0.814	-0.092	3.825	0.013	0.01	0	43.9	39.6	80	137	125	0	35	33
2014	9	21	19	28	19	0.804	-0.082	3.825	0.013	0.01	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	21	19	38	19	0.784	-0.075	3.825	0.01	0.007	0	43.9	40.4	81.7	138	126	0	36	32
2014	9	21	19	48	19	0.853	-0.092	3.825	0.013	0.01	0	44.3	40.4	81.7	138	126	0	35	32
2014	9	21	19	58	19	0.804	-0.092	3.825	0.01	0.007	0	44.3	40.4	80.8	138	126	0	35	32
2014	9	21	20	8	19	0.853	-0.059	3.825	0.013	0.01	0	44.3	40	81.3	138	126	0	35	33
2014	9	21	20	18	19	0.83	-0.089	3.825	0.013	0.01	0	43.9	39.6	81.7	137	125	0	35	33
2014	9	21	20	28	19	0.823	-0.108	3.825	0.013	0.01	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	21	20	38	19	0.84	-0.089	3.825	0.013	0.01	0	44.3	39.6	81.7	138	125	0	35	33
2014	9	21	20	48	19	0.791	-0.095	3.825	0.013	0.01	0	44.7	40.4	80.4	138	126	0	34	32
2014	9	21	20	58	19	0.804	-0.089	3.825	0.013	0.01	0	44.3	40.4	81.3	138	126	0	35	32
2014	9	21	21	8	19	0.823	-0.082	3.825	0.01	0.007	0	44.3	39.6	72.2	138	125	0	35	33
2014	9	21	21	18	19	0.866	-0.108	3.825	0.013	0.01	0	44.3	40.4	81.7	138	126	0	35	32
2014	9	21	21	28	19	0.801	-0.052	3.825	0.01	0.007	0	44.7	40	82.1	139	126	0	35	33
2014	9	21	21	38	19	0.82	-0.098	3.825	0.016	0.013	0	44.3	40	81.3	138	125	0	35	32
2014	9	21	21	48	19	0.804	-0.082	3.825	0.013	0.01	0	44.3	40	81.3	138	125	0	35	32
2014	9	21	21	58	19	0.83	-0.115	3.825	0.013	0.01	0	44.7	40	80.8	139	126	0	35	33
2014	9	21	22	8	19	0.801	-0.092	3.825	0.016	0.013	0	44.3	40	80.8	138	125	0	35	32
2014	9	21	22	18	19	0.823	-0.066	3.825	0.013	0.01	0	43.9	40	80.4	137	125	0	35	32
2014	9	21	22	28	19	0.843	-0.069	3.825	0.01	0.007	0	44.3	40	81.7	138	126	0	35	33
2014	9	21	22	38	19	0.797	-0.098	3.825	0.013	0.01	0	44.7	40	81.3	139	126	0	35	33
2014	9	21	22	48	19	0.791	-0.072	3.825	0.01	0.007	0	44.3	40	80.8	138	126	0	35	33
2014	9	21	22	58	19	0.794	-0.102	3.822	0.013	0.01	0	44.7	40.4	78.7	139	126	0	35	32
2014	9	21	23	8	19	0.814	-0.082	3.822	0.013	0.01	0	44.7	39.6	78.3	139	125	0	35	33
2014	9	21	23	18	19	0.81	-0.069	3.822	0.013	0.01	0	44.7	39.6	78.7	139	125	0	35	33
2014	9	21	23	28	19	0.804	-0.118	3.822	0.013	0.01	0	44.7	39.6	78.3	139	125	0	35	33
2014	9	21	23	38	19	0.807	-0.075	3.822	0.01	0.007	0	44.7	39.6	78.7	139	125	0	35	33
2014	9	21	23	48	19	0.814	-0.092	3.822	0.013	0.01	0	44.7	39.6	77.8	138	125	0	34	33
2014	9	21	23	58	19	0.794	-0.092	3.822	0.016	0.013	0	44.3	39.6	77.8	138	125	0	35	33
2014	9	22	0	8	19	0.797	-0.092	3.822	0.01	0.007	0	44.3	39.6	77.4	138	124	0	35	32
2014	9	22	0	18	19	0.81	-0.085	3.822	0.01	0.007	0	44.7	39.6	78.3	138	125	0	34	33
2014	9	22	0	28	19	0.837	-0.095	3.822	0.01	0.007	0	44.3	39.6	78.3	138	125	0	35	33
2014	9	22	0	38	19	0.82	-0.049	3.822	0.01	0.007	0	44.3	39.1	78.3	138	124	0	35	33
2014	9	22	0	48	19	0.817	-0.079	3.822	0.01	0.007	0	44.3	39.1	77.4	138	124	0	35	33
2014	9	22	0	58	19	0.787	-0.082	3.822	0.013	0.01	0	44.3	39.6	77	138	124	0	35	32
2014	9	22	1	8	19	0.823	-0.075	3.822	0.01	0.007	0	44.3	39.1	77.8	138	124	0	35	33
2014	9	22	1	18	19	0.794	-0.069	3.822	0.013	0.01	0	44.3	40	78.3	138	125	0	35	32
2014	9	22	1	28	19	0.787	-0.082	3.822	0.01	0.007	0	44.7	40.4	77.8	139	126	0	35	32
2014	9	22	1	38	19	0.781	-0.072	3.822	0.016	0.013	0	44.7	39.6	77.4	139	125	0	35	33
2014	9	22	1	48	19	0.801	-0.062	3.822	0.013	0.01	0	44.3	39.1	77.8	138	124	0	35	33
2014	9	22	1	58	19	0.764	-0.082	3.822	0.013	0.01	0	44.3	39.6	77	138	124	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	2	8	19	0.787	-0.089	3.825	0.01	0.007	0	44.3	39.6	77	138	125	0	35	33
2014	9	22	2	18	19	0.804	-0.112	3.825	0.01	0.007	0	44.3	39.1	77.4	138	124	0	35	33
2014	9	22	2	28	19	0.82	-0.105	3.822	0.013	0.01	0	43.4	39.1	75.7	136	124	0	35	33
2014	9	22	2	38	19	0.823	-0.082	3.822	0.013	0.01	0	44.3	39.1	76.5	138	124	0	35	33
2014	9	22	2	48	19	0.833	-0.059	3.822	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	22	2	58	19	0.784	-0.085	3.822	0.01	0.007	0	44.3	39.1	76.5	138	124	0	35	33
2014	9	22	3	8	19	0.82	-0.095	3.822	0.013	0.01	0	44.7	39.6	76.5	138	124	0	34	32
2014	9	22	3	18	19	0.804	-0.108	3.822	0.01	0.007	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	22	3	28	19	0.794	-0.069	3.822	0.013	0.01	0	43.9	38.3	76.5	137	123	0	35	34
2014	9	22	3	38	19	0.791	-0.115	3.822	0.013	0.01	0	44.3	39.1	77	138	124	0	35	33
2014	9	22	3	48	19	0.837	-0.085	3.822	0.01	0.007	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	22	3	58	19	0.784	-0.075	3.822	0.013	0.01	0	43.9	38.7	76.1	137	123	0	35	33
2014	9	22	4	8	19	0.82	-0.092	3.822	0.013	0.01	0	43.9	38.7	75.7	137	123	0	35	33
2014	9	22	4	18	19	0.81	-0.079	3.822	0.013	0.01	0	43.9	38.7	76.1	137	123	0	35	33
2014	9	22	4	28	19	0.817	-0.075	3.822	0.013	0.01	0	43.9	38.7	75.3	137	123	0	35	33
2014	9	22	4	38	19	0.817	-0.092	3.822	0.01	0.007	0	43.9	38.3	75.3	137	122	0	35	33
2014	9	22	4	48	19	0.791	-0.141	3.822	0.013	0.01	0	43.4	38.3	74.4	136	123	0	35	34
2014	9	22	4	58	19	0.83	-0.089	3.822	0.013	0.01	0	44.3	39.1	76.1	137	123	0	34	32
2014	9	22	5	8	19	0.801	-0.056	3.822	0.01	0.007	0	43.9	38.7	76.5	137	123	0	35	33
2014	9	22	5	18	19	0.801	-0.075	3.822	0.01	0.007	0	43.9	38.3	76.5	137	123	0	35	34
2014	9	22	5	28	19	0.814	-0.059	3.822	0.016	0.013	0	43.4	38.3	76.1	136	122	0	35	33
2014	9	22	5	38	19	0.83	-0.089	3.822	0.01	0.007	0	43.4	38.7	75.3	136	123	0	35	33
2014	9	22	5	48	19	0.797	-0.085	3.822	0.016	0.013	0	43.9	38.7	76.1	137	123	0	35	33
2014	9	22	5	58	19	0.837	-0.075	3.822	0.01	0.007	0	43.9	38.7	74.4	137	123	0	35	33
2014	9	22	6	8	19	0.784	-0.085	3.822	0.01	0.007	0	43.9	38.3	74	137	123	0	35	34
2014	9	22	6	18	19	0.823	-0.115	3.822	0.01	0.007	0	43.4	38.3	76.1	136	122	0	35	33
2014	9	22	6	28	19	0.807	-0.066	3.822	0.016	0.013	0	43	38.3	75.7	135	122	0	35	33
2014	9	22	6	38	19	0.83	-0.062	3.822	0.013	0.01	0	43.4	38.3	75.7	136	122	0	35	33
2014	9	22	6	48	19	0.797	-0.095	3.822	0.01	0.007	0	43	37.8	74.8	135	121	0	35	33
2014	9	22	6	58	19	0.837	-0.118	3.822	0.016	0.013	0	42.6	37.8	75.3	134	121	0	35	33
2014	9	22	7	8	19	0.82	-0.079	3.822	0.013	0.01	0	42.1	37	75.3	133	119	0	35	33
2014	9	22	7	18	19	0.827	-0.095	3.822	0.01	0.007	0	41.7	37	75.3	132	119	0	35	33
2014	9	22	7	28	19	0.814	-0.089	3.822	0.016	0.013	0	41.3	36.5	74.4	131	118	0	35	33
2014	9	22	7	38	19	0.853	-0.085	3.825	0.01	0.007	0	41.7	36.5	75.7	132	118	0	35	33
2014	9	22	7	48	19	0.778	-0.069	3.822	0.01	0.007	0	41.3	36.5	74.8	131	117	0	35	32
2014	9	22	7	58	19	0.81	-0.059	3.822	0.013	0.01	0	41.3	36.5	75.7	131	118	0	35	33
2014	9	22	8	8	19	0.837	-0.112	3.822	0.01	0.007	0	41.7	37.4	74.4	132	119	0	35	32
2014	9	22	8	18	19	0.814	-0.059	3.825	0.013	0.01	0	41.7	37	75.7	132	119	0	35	33
2014	9	22	8	28	19	0.814	-0.075	3.825	0.013	0.01	0	41.7	36.5	75.7	132	118	0	35	33
2014	9	22	8	38	19	0.827	-0.092	3.822	0.01	0.007	0	40.9	36.5	76.1	131	118	0	36	33
2014	9	22	8	48	19	0.804	-0.095	3.825	0.01	0.007	0	40.9	36.5	75.7	131	118	0	36	33
2014	9	22	8	58	19	0.797	-0.079	3.825	0.013	0.01	0	40.9	36.1	75.3	130	117	0	35	33
2014	9	22	9	8	19	0.797	-0.085	3.825	0.013	0.01	0	41.7	37	75.7	132	118	0	35	32
2014	9	22	9	18	19	0.814	-0.089	3.825	0.013	0.01	0	40.9	36.1	75.3	130	117	0	35	33
2014	9	22	9	28	19	0.85	-0.115	3.825	0.013	0.01	0	40.9	36.5	74.4	131	118	0	36	33
2014	9	22	9	38	19	0.797	-0.046	3.825	0.01	0.007	0	41.7	37.4	75.7	132	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	9	48	19	0.827	-0.079	3.825	0.01	0.007	0	40.9	36.5	75.7	131	118	0	36	33
2014	9	22	9	58	19	0.768	-0.062	3.825	0.01	0.007	0	41.3	36.5	75.7	131	118	0	35	33
2014	9	22	10	8	19	0.804	-0.095	3.825	0.01	0.007	0	40.9	35.7	76.1	130	117	0	35	34
2014	9	22	10	18	19	0.837	-0.102	3.825	0.01	0.007	0	41.3	36.5	75.7	131	118	0	35	33
2014	9	22	10	28	19	0.794	-0.085	3.825	0.01	0.007	0	40.9	36.1	76.5	130	117	0	35	33
2014	9	22	10	38	19	0.827	-0.095	3.825	0.016	0.013	0	41.3	37	76.1	131	118	0	35	32
2014	9	22	10	48	19	0.801	-0.092	3.825	0.013	0.01	0	40.9	36.1	76.1	130	117	0	35	33
2014	9	22	10	58	19	0.778	-0.079	3.825	0.01	0.007	0	41.3	36.1	77	131	117	0	35	33
2014	9	22	11	8	19	0.817	-0.095	3.825	0.013	0.01	0	40.9	36.1	75.3	130	117	0	35	33
2014	9	22	11	18	19	0.797	-0.098	3.822	0.01	0.007	0	40.9	36.5	74.8	130	117	0	35	32
2014	9	22	11	28	19	0.801	-0.085	3.822	0.01	0.007	0	40.9	36.5	76.5	130	117	0	35	32
2014	9	22	11	38	19	0.807	-0.098	3.822	0.013	0.01	0	40.9	36.5	74	130	118	0	35	33
2014	9	22	11	48	19	0.807	-0.098	3.822	0.01	0.007	0	40.4	36.1	74.4	130	117	0	36	33
2014	9	22	11	58	19	0.784	-0.092	3.822	0.01	0.007	0	40.9	37	58	130	118	0	35	32
2014	9	22	12	8	19	0.774	-0.131	3.822	0.01	0.007	0	40.9	36.1	61.5	131	117	0	36	33
2014	9	22	12	18	19	0.784	-0.052	3.822	0.013	0.01	0	41.3	37	58.9	131	119	0	35	33
2014	9	22	12	28	19	0.771	-0.089	3.822	0.01	0.007	0	41.7	37	58.9	132	119	0	35	33
2014	9	22	12	38	19	0.758	-0.115	3.822	0.01	0.007	0	41.7	36.5	58.9	132	119	0	35	34
2014	9	22	12	48	19	0.741	-0.095	3.822	0.013	0.01	0	41.7	36.5	59.8	132	118	0	35	33
2014	9	22	12	58	19	0.758	-0.098	3.822	0.016	0.013	0	41.7	37.4	58	132	120	0	35	33
2014	9	22	13	8	19	0.814	-0.075	3.822	0.01	0.007	0	41.7	37.4	62.4	132	119	0	35	32
2014	9	22	13	18	19	0.784	-0.062	3.822	0.013	0.01	0	41.3	37	61.1	131	118	0	35	32
2014	9	22	13	28	19	0.794	-0.112	3.822	0.01	0.007	0	41.3	37	58	131	119	0	35	33
2014	9	22	13	38	19	0.784	-0.095	3.822	0.01	0.007	0	41.7	37.4	57.2	132	120	0	35	33
2014	9	22	13	48	19	0.774	-0.098	3.822	0.013	0.01	0	41.7	37	64.5	132	119	0	35	33
2014	9	22	13	58	19	0.791	-0.105	3.822	0.01	0.007	0	41.3	37	62.8	131	119	0	35	33
2014	9	22	14	8	19	0.771	-0.105	3.822	0.01	0.007	0	41.3	36.5	57.2	131	118	0	35	33
2014	9	22	14	18	19	0.778	-0.085	3.819	0.016	0.013	0	41.7	37	56.8	132	119	0	35	33
2014	9	22	14	28	19	0.787	-0.079	3.819	0.01	0.007	0	42.1	37.4	59.8	133	120	0	35	33
2014	9	22	14	38	19	0.751	-0.092	3.819	0.013	0.01	0	41.7	37.4	61.1	132	120	0	35	33
2014	9	22	14	48	19	0.764	-0.089	3.819	0.01	0.007	0	41.7	37	57.2	132	119	0	35	33
2014	9	22	14	58	19	0.781	-0.059	3.819	0.013	0.01	0	41.7	37	63.2	132	119	0	35	33
2014	9	22	15	8	19	0.784	-0.095	3.819	0.013	0.01	0	42.6	38.3	69.2	134	121	0	35	32
2014	9	22	15	18	19	0.784	-0.092	3.819	0.01	0.007	0	42.1	37.8	66.2	133	120	0	35	32
2014	9	22	15	28	19	0.784	-0.075	3.816	0.01	0.007	0	41.7	37	58.5	132	119	0	35	33
2014	9	22	15	38	19	0.791	-0.095	3.819	0.013	0.01	0	41.7	37	67.1	132	119	0	35	33
2014	9	22	15	48	19	0.784	-0.092	3.816	0.01	0.007	0	41.7	37	64.1	132	119	0	35	33
2014	9	22	15	58	19	0.735	-0.092	3.816	0.013	0.01	0	41.7	37	59.8	132	119	0	35	33
2014	9	22	16	8	19	0.787	-0.115	3.816	0.01	0.007	0	41.7	37.4	58.9	132	119	0	35	32
2014	9	22	16	18	19	0.81	-0.075	3.816	0.01	0.007	0	42.6	37.8	69.2	133	120	0	34	32
2014	9	22	16	28	19	0.761	-0.095	3.816	0.01	0.007	0	41.7	37.4	58.5	132	120	0	35	33
2014	9	22	16	38	19	0.771	-0.095	3.816	0.016	0.013	0	42.1	37.4	64.5	133	120	0	35	33
2014	9	22	16	48	19	0.797	-0.115	3.816	0.013	0.01	0	42.6	37.4	58.9	133	120	0	34	33
2014	9	22	16	58	19	0.801	-0.092	3.816	0.013	0.01	0	41.7	37.8	57.6	132	120	0	35	32
2014	9	22	17	8	19	0.791	-0.092	3.816	0.016	0.013	0	41.7	37.4	60.6	132	119	0	35	32
2014	9	22	17	18	19	0.797	-0.079	3.816	0.016	0.013	0	41.7	37	66.2	132	119	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	22	17	28	19	0.778	-0.095	3.816	0.01	0.007	0	41.7	37.4	67.1	132	120	0	35	33
2014	9	22	17	38	19	0.781	-0.089	3.816	0.013	0.01	0	42.1	36.5	67.5	133	119	0	35	34
2014	9	22	17	48	19	0.804	-0.098	3.816	0.01	0.007	0	41.3	36.5	70.1	131	118	0	35	33
2014	9	22	17	58	19	0.81	-0.092	3.816	0.01	0.007	0	42.1	37	71	133	119	0	35	33
2014	9	22	18	8	19	0.807	-0.079	3.816	0.016	0.013	0	41.7	37	76.5	132	119	0	35	33
2014	9	22	18	18	19	0.787	-0.079	3.816	0.01	0.007	0	41.7	36.5	74	132	118	0	35	33
2014	9	22	18	28	19	0.85	-0.089	3.816	0.01	0.007	0	41.7	37.4	72.2	132	119	0	35	32
2014	9	22	18	38	19	0.774	-0.089	3.816	0.01	0.007	0	42.6	37.8	74.4	134	121	0	35	33
2014	9	22	18	48	19	0.84	-0.089	3.812	0.01	0.007	0	42.6	37.8	59.3	134	120	0	35	32
2014	9	22	18	58	19	0.794	-0.102	3.816	0.01	0.007	0	42.6	37.8	74	134	121	0	35	33
2014	9	22	19	8	19	0.817	-0.059	3.816	0.01	0.007	0	43	38.3	73.1	135	122	0	35	33
2014	9	22	19	18	19	0.804	-0.082	3.816	0.01	0.007	0	43.4	38.3	71.4	136	122	0	35	33
2014	9	22	19	28	19	0.774	-0.095	3.812	0.01	0.007	0	44.3	39.1	60.6	137	124	0	34	33
2014	9	22	19	38	19	0.787	-0.066	3.816	0.01	0.007	0	43.9	38.7	71	137	124	0	35	34
2014	9	22	19	48	19	0.837	-0.075	3.816	0.01	0.007	0	44.3	39.1	65.8	137	124	0	34	33
2014	9	22	19	58	19	0.81	-0.079	3.816	0.013	0.01	0	43.9	39.1	70.1	137	124	0	35	33
2014	9	22	20	8	19	0.787	-0.092	3.816	0.01	0.007	0	43.9	39.1	73.1	137	124	0	35	33
2014	9	22	20	18	19	0.804	-0.082	3.816	0.016	0.013	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	22	20	28	19	0.787	-0.102	3.816	0.01	0.007	0	43.9	39.6	75.7	137	124	0	35	32
2014	9	22	20	38	19	0.804	-0.089	3.816	0.013	0.01	0	43	38.7	75.7	136	123	0	36	33
2014	9	22	20	48	19	0.837	-0.089	3.819	0.013	0.01	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	22	20	58	19	0.807	-0.079	3.816	0.01	0.007	0	44.3	39.1	76.1	137	124	0	34	33
2014	9	22	21	8	19	0.846	-0.089	3.816	0.013	0.01	0	43.9	39.1	75.7	137	123	0	35	32
2014	9	22	21	18	19	0.83	-0.098	3.819	0.016	0.013	0	43.9	39.1	75.3	137	123	0	35	32
2014	9	22	21	28	19	0.823	-0.069	3.819	0.01	0.007	0	43.9	38.7	75.3	137	123	0	35	33
2014	9	22	21	38	19	0.774	-0.095	3.819	0.016	0.013	0	43.9	39.6	74.4	137	124	0	35	32
2014	9	22	21	48	19	0.784	-0.075	3.819	0.013	0.01	0	44.3	39.6	76.5	138	124	0	35	32
2014	9	22	21	58	19	0.791	-0.085	3.816	0.01	0.007	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	22	22	8	19	0.84	-0.105	3.819	0.013	0.01	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	22	22	18	19	0.807	-0.085	3.819	0.013	0.01	0	43.9	39.6	76.5	137	125	0	35	33
2014	9	22	22	28	19	0.846	-0.108	3.819	0.013	0.01	0	44.3	39.6	76.5	137	124	0	34	32
2014	9	22	22	38	19	0.801	-0.069	3.819	0.013	0.01	0	43.9	39.6	77	137	124	0	35	32
2014	9	22	22	48	19	0.81	-0.095	3.819	0.01	0.007	0	43.9	39.1	77	137	124	0	35	33
2014	9	22	22	58	19	0.804	-0.108	3.819	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	22	23	8	19	0.804	-0.072	3.819	0.013	0.01	0	43.9	39.6	76.1	137	124	0	35	32
2014	9	22	23	18	19	0.81	-0.102	3.819	0.01	0.007	0	43.9	39.6	77	137	124	0	35	32
2014	9	22	23	28	19	0.774	-0.075	3.819	0.01	0.007	0	43.9	39.1	77	137	124	0	35	33
2014	9	22	23	38	19	0.823	-0.105	3.819	0.01	0.007	0	44.3	39.1	77	138	124	0	35	33
2014	9	22	23	48	19	0.787	-0.095	3.819	0.013	0.01	0	44.3	39.1	76.5	138	124	0	35	33
2014	9	22	23	58	19	0.85	-0.085	3.819	0.01	0.007	0	43.9	39.1	77.4	137	124	0	35	33
2014	9	23	0	8	19	0.784	-0.069	3.819	0.01	0.007	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	23	0	18	19	0.82	-0.069	3.819	0.01	0.007	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	23	0	28	19	0.787	-0.095	3.819	0.01	0.007	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	23	0	38	19	0.791	-0.121	3.819	0.016	0.016	0	44.3	39.6	77.4	138	124	0	35	32
2014	9	23	0	48	19	0.791	-0.092	3.819	0.013	0.01	0	43.9	39.1	76.5	137	124	0	35	33
2014	9	23	0	58	19	0.787	-0.112	3.819	0.016	0.013	0	44.3	39.6	77.4	138	124	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	1	8	19	0.81	-0.102	3.819	0.01	0.007	0	44.3	39.6	76.5	138	125	0	35	33
2014	9	23	1	18	19	0.833	-0.092	3.819	0.01	0.007	0	44.3	39.6	76.5	138	125	0	35	33
2014	9	23	1	28	19	0.83	-0.092	3.819	0.016	0.013	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	23	1	38	19	0.82	-0.062	3.819	0.013	0.01	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	1	48	19	0.83	-0.082	3.819	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	23	1	58	19	0.817	-0.095	3.819	0.016	0.013	0	44.3	39.6	77	138	125	0	35	33
2014	9	23	2	8	19	0.817	-0.072	3.819	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	23	2	18	19	0.807	-0.089	3.819	0.013	0.01	0	43.9	39.1	77	137	124	0	35	33
2014	9	23	2	28	19	0.83	-0.066	3.819	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	2	38	19	0.83	-0.075	3.819	0.013	0.01	0	44.3	39.1	76.5	137	124	0	34	33
2014	9	23	2	48	19	0.807	-0.092	3.819	0.013	0.01	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	2	58	19	0.82	-0.092	3.819	0.013	0.01	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	3	8	19	0.82	-0.135	3.819	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	3	18	19	0.807	-0.082	3.819	0.013	0.01	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	23	3	28	19	0.827	-0.105	3.819	0.013	0.01	0	44.3	39.6	75.7	138	124	0	35	32
2014	9	23	3	38	19	0.827	-0.098	3.819	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	3	48	19	0.797	-0.105	3.819	0.013	0.01	0	43.4	39.6	76.1	136	124	0	35	32
2014	9	23	3	58	19	0.797	-0.089	3.819	0.013	0.01	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	23	4	8	19	0.781	-0.079	3.819	0.013	0.01	0	43.9	39.1	75.3	137	124	0	35	33
2014	9	23	4	18	19	0.791	-0.108	3.819	0.01	0.007	0	43.9	39.1	75.3	137	124	0	35	33
2014	9	23	4	28	19	0.84	-0.072	3.819	0.01	0.007	0	43.9	39.1	75.3	137	124	0	35	33
2014	9	23	4	38	19	0.791	-0.098	3.819	0.01	0.007	0	43.4	39.1	75.3	137	124	0	36	33
2014	9	23	4	48	19	0.843	-0.105	3.819	0.01	0.007	0	43.9	39.1	76.1	137	124	0	35	33
2014	9	23	4	58	19	0.801	-0.098	3.819	0.013	0.01	0	43.9	39.6	75.7	137	124	0	35	32
2014	9	23	5	8	19	0.83	-0.085	3.819	0.01	0.007	0	43.9	39.1	75.7	137	124	0	35	33
2014	9	23	5	18	19	0.807	-0.089	3.819	0.013	0.01	0	43.9	39.1	74.8	137	124	0	35	33
2014	9	23	5	28	19	0.84	-0.082	3.819	0.013	0.01	0	43.9	39.1	74.8	137	124	0	35	33
2014	9	23	5	38	19	0.843	-0.108	3.819	0.016	0.013	0	43.9	39.1	75.3	137	124	0	35	33
2014	9	23	5	48	19	0.787	-0.102	3.819	0.013	0.01	0	43.9	39.1	74.8	137	124	0	35	33
2014	9	23	5	58	19	0.833	-0.098	3.819	0.01	0.007	0	43.9	39.6	74	137	124	0	35	32
2014	9	23	6	8	19	0.794	-0.069	3.819	0.01	0.007	0	43.9	38.7	74	137	124	0	35	34
2014	9	23	6	18	19	0.797	-0.079	3.819	0.01	0.007	0	43.9	39.1	74	137	124	0	35	33
2014	9	23	6	28	19	0.853	-0.095	3.822	0.016	0.013	0	42.6	38.3	74.4	135	122	0	36	33
2014	9	23	6	38	19	0.833	-0.089	3.822	0.01	0.007	0	42.6	37.8	74.8	134	121	0	35	33
2014	9	23	6	48	19	0.837	-0.062	3.819	0.01	0.007	0	43.4	38.7	74.8	136	123	0	35	33
2014	9	23	6	58	19	0.869	-0.089	3.822	0.01	0.007	0	41.7	37.8	74	133	120	0	36	32
2014	9	23	7	8	19	0.774	-0.082	3.822	0.013	0.01	0	42.1	37.4	74	133	120	0	35	33
2014	9	23	7	18	19	0.827	-0.072	3.822	0.013	0.01	0	42.1	37.4	74	133	120	0	35	33
2014	9	23	7	28	19	0.794	-0.072	3.822	0.01	0.007	0	41.3	36.1	74	131	118	0	35	34
2014	9	23	7	38	19	0.794	-0.066	3.822	0.013	0.01	0	41.7	37	74.4	132	119	0	35	33
2014	9	23	7	48	19	0.81	-0.092	3.822	0.013	0.01	0	40.9	37	74.4	131	119	0	36	33
2014	9	23	7	58	19	0.807	-0.105	3.822	0.013	0.01	0	41.3	37	74	132	119	0	36	33
2014	9	23	8	8	19	0.837	-0.105	3.822	0.01	0.007	0	41.3	36.1	73.1	131	118	0	35	34
2014	9	23	8	18	19	0.86	-0.059	3.822	0.013	0.01	0	40.9	36.5	73.5	131	118	0	36	33
2014	9	23	8	28	19	0.781	-0.085	3.822	0.01	0.007	0	41.3	36.5	73.1	131	118	0	35	33
2014	9	23	8	38	19	0.787	-0.108	3.822	0.013	0.01	0	41.3	37	73.1	131	119	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	8	48	19	0.791	-0.092	3.822	0.01	0.007	0	41.3	36.5	73.5	131	118	0	35	33
2014	9	23	8	58	19	0.804	-0.069	3.822	0.01	0.007	0	40.9	36.1	73.5	130	118	0	35	34
2014	9	23	9	8	19	0.791	-0.085	3.825	0.01	0.007	0	40.9	37	73.5	131	119	0	36	33
2014	9	23	9	18	19	0.837	-0.105	3.825	0.016	0.013	0	41.3	36.5	73.1	131	119	0	35	34
2014	9	23	9	28	19	0.801	-0.108	3.822	0.01	0.007	0	40.9	37	74	131	119	0	36	33
2014	9	23	9	38	19	0.86	-0.118	3.822	0.01	0.007	0	40.9	36.5	73.5	130	118	0	35	33
2014	9	23	9	48	19	0.827	-0.108	3.825	0.01	0.007	0	40.9	37.4	73.5	131	119	0	36	32
2014	9	23	9	58	19	0.817	-0.092	3.825	0.01	0.007	0	40.9	36.5	73.5	130	118	0	35	33
2014	9	23	10	8	19	0.827	-0.072	3.822	0.013	0.01	0	40.9	36.1	74	130	117	0	35	33
2014	9	23	10	18	19	0.82	-0.105	3.825	0.01	0.007	0	40.4	36.1	73.5	129	117	0	35	33
2014	9	23	10	28	19	0.84	-0.089	3.825	0.013	0.01	0	40.4	36.1	73.5	129	117	0	35	33
2014	9	23	10	38	19	0.804	-0.112	3.822	0.01	0.007	0	40.4	36.1	73.5	129	117	0	35	33
2014	9	23	10	48	19	0.833	-0.082	3.825	0.013	0.01	0	40.4	35.7	73.5	129	116	0	35	33
2014	9	23	10	58	19	0.778	-0.125	3.822	0.013	0.01	0	40.4	36.1	74.4	129	116	0	35	32
2014	9	23	11	8	19	0.801	-0.108	3.822	0.01	0.007	0	40	35.7	67.5	128	116	0	35	33
2014	9	23	11	18	19	0.764	-0.085	3.822	0.016	0.013	0	40.4	36.1	58.9	129	117	0	35	33
2014	9	23	11	28	19	0.794	-0.075	3.825	0.013	0.01	0	40.9	36.5	55.9	130	118	0	35	33
2014	9	23	11	38	19	0.794	-0.092	3.822	0.01	0.007	0	41.7	37	58.5	132	119	0	35	33
2014	9	23	11	48	19	0.807	-0.092	3.822	0.01	0.007	0	41.3	37	56.3	131	119	0	35	33
2014	9	23	11	58	19	0.768	-0.072	3.822	0.013	0.01	0	41.3	37	56.3	131	119	0	35	33
2014	9	23	12	8	19	0.801	-0.125	3.822	0.016	0.013	0	41.7	37	57.6	132	119	0	35	33
2014	9	23	12	18	19	0.778	-0.092	3.822	0.016	0.013	0	40.9	37	56.3	131	119	0	36	33
2014	9	23	12	28	19	0.768	-0.098	3.822	0.01	0.007	0	41.7	37.4	57.2	132	120	0	35	33
2014	9	23	12	38	19	0.778	-0.075	3.822	0.013	0.01	0	41.3	37.4	58.5	132	120	0	36	33
2014	9	23	12	48	19	0.771	-0.085	3.822	0.016	0.013	0	41.3	37	62.4	131	119	0	35	33
2014	9	23	12	58	19	0.814	-0.089	3.822	0.01	0.007	0	40.9	37	54.6	131	119	0	36	33
2014	9	23	13	8	19	0.84	-0.056	3.819	0.01	0.007	0	41.7	37.4	63.2	132	119	0	35	32
2014	9	23	13	18	19	0.804	-0.079	3.822	0.016	0.013	0	41.3	37	56.8	131	119	0	35	33
2014	9	23	13	28	19	0.794	-0.092	3.822	0.013	0.01	0	41.3	37	55.5	132	119	0	36	33
2014	9	23	13	38	19	0.755	-0.118	3.819	0.013	0.01	0	41.3	37.4	58	132	120	0	36	33
2014	9	23	13	48	19	0.787	-0.108	3.819	0.01	0.007	0	41.3	37.4	57.2	132	120	0	36	33
2014	9	23	13	58	19	0.794	-0.095	3.819	0.016	0.013	0	41.7	37.8	67.1	132	120	0	35	32
2014	9	23	14	8	19	0.81	-0.075	3.819	0.013	0.01	0	41.7	37.8	55.5	132	120	0	35	32
2014	9	23	14	18	19	0.83	-0.079	3.819	0.016	0.013	0	41.7	37.8	62.4	132	120	0	35	32
2014	9	23	14	28	19	0.817	-0.079	3.819	0.01	0.007	0	42.1	37.8	59.3	133	120	0	35	32
2014	9	23	14	38	19	0.771	-0.075	3.816	0.01	0.007	0	42.1	37.8	55	133	121	0	35	33
2014	9	23	14	48	19	0.784	-0.079	3.819	0.016	0.013	0	41.7	38.3	58.9	133	121	0	36	32
2014	9	23	14	58	19	0.817	-0.092	3.819	0.013	0.01	0	42.1	37.8	58.5	133	121	0	35	33
2014	9	23	15	8	19	0.791	-0.066	3.816	0.013	0.01	0	42.6	37.8	61.9	134	121	0	35	33
2014	9	23	15	18	19	0.784	-0.098	3.816	0.013	0.01	0	42.1	37.8	58.5	133	121	0	35	33
2014	9	23	15	28	19	0.801	-0.089	3.816	0.013	0.01	0	41.7	37.4	55.5	132	120	0	35	33
2014	9	23	15	38	19	0.814	-0.082	3.816	0.013	0.01	0	41.7	37.4	54.6	132	120	0	35	33
2014	9	23	15	48	19	0.787	-0.072	3.816	0.013	0.01	0	42.1	37.4	61.5	133	120	0	35	33
2014	9	23	15	58	19	0.781	-0.095	3.816	0.013	0.01	0	42.1	37.8	61.1	133	121	0	35	33
2014	9	23	16	8	19	0.784	-0.069	3.816	0.01	0.007	0	42.1	38.3	59.8	133	121	0	35	32
2014	9	23	16	18	19	0.787	-0.092	3.816	0.01	0.007	0	42.1	37	60.6	133	120	0	35	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	23	16	28	19	0.771	-0.112	3.812	0.01	0.007	0	41.3	37.4	57.6	132	120	0	36	33
2014	9	23	16	38	19	0.794	-0.112	3.812	0.016	0.013	0	42.1	37.4	55.9	133	120	0	35	33
2014	9	23	16	48	19	0.804	-0.043	3.812	0.016	0.013	0	42.6	37.8	63.6	134	121	0	35	33
2014	9	23	16	58	19	0.794	-0.075	3.812	0.013	0.01	0	42.6	38.3	62.8	134	122	0	35	33
2014	9	23	17	8	19	0.797	-0.098	3.812	0.01	0.007	0	41.7	37.4	58.5	132	120	0	35	33
2014	9	23	17	18	19	0.761	-0.085	3.812	0.01	0.007	0	41.7	37.8	61.1	132	120	0	35	32
2014	9	23	17	28	19	0.794	-0.095	3.812	0.01	0.007	0	41.7	37.4	62.8	133	120	0	36	33
2014	9	23	17	38	19	0.801	-0.108	3.812	0.013	0.01	0	42.1	37.4	60.2	133	120	0	35	33
2014	9	23	17	48	19	0.794	-0.075	3.812	0.013	0.01	0	42.1	37.8	75.3	133	120	0	35	32
2014	9	23	17	58	19	0.814	-0.115	3.812	0.01	0.007	0	42.1	37.4	73.1	133	120	0	35	33
2014	9	23	18	8	19	0.827	-0.102	3.812	0.01	0.007	0	42.1	37.4	76.5	133	120	0	35	33
2014	9	23	18	18	19	0.853	-0.089	3.816	0.01	0.007	0	42.1	37.8	77	133	120	0	35	32
2014	9	23	18	28	19	0.804	-0.079	3.812	0.01	0.007	0	41.7	37.4	75.7	133	120	0	36	33
2014	9	23	18	38	19	0.833	-0.118	3.812	0.013	0.01	0	42.6	38.3	74.4	134	121	0	35	32
2014	9	23	18	48	19	0.801	-0.082	3.812	0.013	0.01	0	42.6	38.3	65.8	135	122	0	36	33
2014	9	23	18	58	19	0.797	-0.105	3.812	0.01	0.007	0	43	38.7	64.1	135	123	0	35	33
2014	9	23	19	8	19	0.82	-0.102	3.812	0.013	0.01	0	43.4	39.1	73.1	136	123	0	35	32
2014	9	23	19	18	19	0.794	-0.125	3.812	0.01	0.007	0	43.4	39.6	56.8	136	124	0	35	32
2014	9	23	19	28	19	0.823	-0.092	3.816	0.016	0.013	0	44.3	39.6	71.8	138	125	0	35	33
2014	9	23	19	38	19	0.833	-0.072	3.812	0.013	0.01	0	44.7	40	75.3	139	126	0	35	33
2014	9	23	19	48	19	0.801	-0.082	3.816	0.01	0.007	0	44.7	40	77	139	126	0	35	33
2014	9	23	19	58	19	0.82	-0.043	3.816	0.01	0.007	0	44.3	40	76.5	138	125	0	35	32
2014	9	23	20	8	19	0.817	-0.102	3.816	0.013	0.01	0	44.3	39.6	75.3	138	125	0	35	33
2014	9	23	20	18	19	0.814	-0.075	3.816	0.013	0.01	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	23	20	28	19	0.817	-0.072	3.816	0.016	0.013	0	44.3	40	76.5	138	126	0	35	33
2014	9	23	20	38	19	0.797	-0.072	3.816	0.01	0.007	0	44.7	40	77.4	139	126	0	35	33
2014	9	23	20	48	19	0.797	-0.066	3.816	0.016	0.016	0	44.7	40.4	77	139	127	0	35	33
2014	9	23	20	58	19	0.814	-0.089	3.816	0.013	0.01	0	44.7	40	77	139	126	0	35	33
2014	9	23	21	8	19	0.761	-0.079	3.816	0.013	0.01	0	44.7	40.9	77	139	127	0	35	32
2014	9	23	21	18	19	0.833	-0.056	3.816	0.013	0.01	0	43.9	40	77.8	138	125	0	36	32
2014	9	23	21	28	19	0.814	-0.056	3.816	0.013	0.01	0	44.3	40	77.8	138	126	0	35	33
2014	9	23	21	38	19	0.801	-0.092	3.816	0.016	0.013	0	44.7	40.4	78.7	139	127	0	35	33
2014	9	23	21	48	19	0.83	-0.072	3.816	0.013	0.01	0	44.7	40.9	78.7	139	127	0	35	32
2014	9	23	21	58	19	0.814	-0.056	3.816	0.01	0.007	0	44.7	40	78.7	139	126	0	35	33
2014	9	23	22	8	19	0.801	-0.072	3.816	0.013	0.01	0	44.7	40.4	79.6	139	126	0	35	32
2014	9	23	22	18	19	0.823	-0.098	3.816	0.013	0.01	0	44.3	40.4	79.6	138	126	0	35	32
2014	9	23	22	28	19	0.846	-0.105	3.816	0.01	0.007	0	44.3	40.4	78.7	138	126	0	35	32
2014	9	23	22	38	19	0.804	-0.075	3.816	0.016	0.013	0	44.3	40	79.1	138	126	0	35	33
2014	9	23	22	48	19	0.807	-0.092	3.816	0.01	0.007	0	44.3	39.6	78.7	138	125	0	35	33
2014	9	23	22	58	19	0.791	-0.082	3.816	0.013	0.01	0	44.7	40	75.3	139	126	0	35	33
2014	9	23	23	8	19	0.823	-0.075	3.816	0.016	0.013	0	44.3	40	77.4	138	126	0	35	33
2014	9	23	23	18	19	0.797	-0.082	3.816	0.01	0.007	0	44.3	40.4	78.7	138	126	0	35	32
2014	9	23	23	28	19	0.827	-0.092	3.816	0.013	0.01	0	44.7	40	76.5	139	126	0	35	33
2014	9	23	23	38	19	0.797	-0.046	3.816	0.01	0.007	0	45.2	40.9	76.5	139	127	0	34	32
2014	9	23	23	48	19	0.784	-0.075	3.816	0.01	0.007	0	44.7	40	77.8	139	126	0	35	33
2014	9	23	23	58	19	0.814	-0.102	3.816	0.016	0.013	0	44.3	40	77	139	126	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	0	8	19	0.807	-0.092	3.816	0.016	0.013	0	44.7	40	76.1	139	126	0	35	33
2014	9	24	0	18	19	0.791	-0.092	3.816	0.013	0.01	0	44.3	40	77	139	126	0	36	33
2014	9	24	0	28	19	0.843	-0.075	3.816	0.01	0.007	0	44.3	39.6	77.4	139	125	0	36	33
2014	9	24	0	38	19	0.787	-0.108	3.816	0.016	0.013	0	44.3	39.6	77.4	138	125	0	35	33
2014	9	24	0	48	19	0.794	-0.118	3.816	0.013	0.01	0	44.3	40	76.1	139	126	0	36	33
2014	9	24	0	58	19	0.82	-0.092	3.816	0.016	0.013	0	44.7	39.6	76.5	139	126	0	35	34
2014	9	24	1	8	19	0.807	-0.108	3.816	0.01	0.007	0	44.3	39.6	77	139	125	0	36	33
2014	9	24	1	18	19	0.794	-0.059	3.816	0.01	0.007	0	44.7	40	75.7	139	126	0	35	33
2014	9	24	1	28	19	0.84	-0.095	3.816	0.013	0.01	0	44.3	39.6	76.5	138	125	0	35	33
2014	9	24	1	38	19	0.873	-0.085	3.816	0.01	0.007	0	44.3	39.6	76.5	138	125	0	35	33
2014	9	24	1	48	19	0.784	-0.098	3.816	0.013	0.01	0	44.7	39.6	76.1	139	125	0	35	33
2014	9	24	1	58	19	0.823	-0.121	3.816	0.01	0.007	0	44.7	39.6	75.7	139	125	0	35	33
2014	9	24	2	8	19	0.787	-0.079	3.816	0.013	0.01	0	44.3	40	77	139	126	0	36	33
2014	9	24	2	18	19	0.82	-0.062	3.816	0.013	0.01	0	44.7	39.6	76.5	139	126	0	35	34
2014	9	24	2	28	19	0.823	-0.069	3.816	0.013	0.01	0	44.7	39.6	76.5	139	125	0	35	33
2014	9	24	2	38	19	0.801	-0.105	3.816	0.01	0.007	0	44.3	40	76.1	138	125	0	35	32
2014	9	24	2	48	19	0.804	-0.079	3.816	0.016	0.013	0	44.7	40	75.3	139	126	0	35	33
2014	9	24	2	58	19	0.791	-0.105	3.816	0.01	0.007	0	44.3	39.6	77	139	125	0	36	33
2014	9	24	3	8	19	0.853	-0.121	3.816	0.01	0.007	0	44.3	39.6	75.3	138	125	0	35	33
2014	9	24	3	18	19	0.794	-0.056	3.816	0.016	0.013	0	44.3	40	76.5	139	125	0	36	32
2014	9	24	3	28	19	0.823	-0.085	3.816	0.013	0.01	0	44.3	39.1	75.3	138	124	0	35	33
2014	9	24	3	38	19	0.804	-0.102	3.816	0.016	0.016	0	44.3	39.1	76.5	138	124	0	35	33
2014	9	24	3	48	19	0.804	-0.062	3.816	0.013	0.01	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	24	3	58	19	0.827	-0.082	3.816	0.01	0.007	0	43.9	39.1	75.7	138	124	0	36	33
2014	9	24	4	8	19	0.827	-0.092	3.816	0.01	0.007	0	43.9	39.6	75.3	138	125	0	36	33
2014	9	24	4	18	19	0.801	-0.066	3.816	0.01	0.007	0	44.7	39.1	74.8	139	125	0	35	34
2014	9	24	4	28	19	0.83	-0.095	3.816	0.013	0.01	0	44.7	39.6	74.8	139	125	0	35	33
2014	9	24	4	38	19	0.84	-0.085	3.816	0.01	0.007	0	44.3	39.6	75.7	139	125	0	36	33
2014	9	24	4	48	19	0.823	-0.085	3.816	0.01	0.007	0	44.3	39.1	75.3	138	124	0	35	33
2014	9	24	4	58	19	0.787	-0.115	3.816	0.01	0.007	0	44.7	39.6	74.8	139	125	0	35	33
2014	9	24	5	8	19	0.82	-0.092	3.816	0.01	0.007	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	24	5	18	19	0.787	-0.098	3.816	0.01	0.007	0	44.3	39.6	74.8	138	125	0	35	33
2014	9	24	5	28	19	0.748	-0.062	3.819	0.013	0.01	0	43.9	38.7	74.8	137	123	0	35	33
2014	9	24	5	38	19	0.823	-0.079	3.816	0.01	0.007	0	44.3	39.1	75.3	138	124	0	35	33
2014	9	24	5	48	19	0.807	-0.112	3.816	0.013	0.01	0	43.9	39.1	74.4	138	124	0	36	33
2014	9	24	5	58	19	0.817	-0.102	3.816	0.01	0.007	0	43.9	39.1	74.4	137	124	0	35	33
2014	9	24	6	8	19	0.794	-0.105	3.816	0.013	0.01	0	43.4	38.7	74.4	137	124	0	36	34
2014	9	24	6	18	19	0.837	-0.105	3.819	0.01	0.007	0	43.9	39.1	74.4	137	123	0	35	32
2014	9	24	6	28	19	0.814	-0.102	3.816	0.013	0.01	0	43.4	38.7	74.4	136	123	0	35	33
2014	9	24	6	38	19	0.771	-0.066	3.816	0.01	0.007	0	43.4	38.7	74	136	122	0	35	32
2014	9	24	6	48	19	0.814	-0.102	3.819	0.01	0.007	0	43	37.8	74	135	122	0	35	34
2014	9	24	6	58	19	0.833	-0.079	3.819	0.013	0.01	0	43	38.3	74	136	122	0	36	33
2014	9	24	7	8	19	0.814	-0.089	3.819	0.016	0.016	0	42.6	37.8	74	135	121	0	36	33
2014	9	24	7	18	19	0.768	-0.112	3.819	0.013	0.01	0	42.1	37.8	74	134	121	0	36	33
2014	9	24	7	28	19	0.771	-0.089	3.816	0.01	0.007	0	42.6	37.4	74	134	120	0	35	33
2014	9	24	7	38	19	0.83	-0.089	3.819	0.013	0.01	0	42.1	37.8	72.7	134	121	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	7	48	19	0.807	-0.075	3.819	0.01	0.007	0	42.6	37.8	73.5	135	121	0	36	33
2014	9	24	7	58	19	0.797	-0.089	3.822	0.01	0.007	0	42.1	37	73.5	134	120	0	36	34
2014	9	24	8	8	19	0.81	-0.075	3.822	0.013	0.01	0	41.7	37.8	73.5	133	121	0	36	33
2014	9	24	8	18	19	0.797	-0.075	3.822	0.013	0.01	0	41.7	37.4	74	133	120	0	36	33
2014	9	24	8	28	19	0.807	-0.085	3.822	0.01	0.007	0	42.1	37.4	74	133	120	0	35	33
2014	9	24	8	38	19	0.837	-0.089	3.822	0.013	0.01	0	41.7	37.4	73.5	133	120	0	36	33
2014	9	24	8	48	19	0.804	-0.089	3.822	0.013	0.01	0	42.1	37.4	73.1	133	120	0	35	33
2014	9	24	8	58	19	0.83	-0.082	3.822	0.013	0.01	0	41.7	37	74	133	120	0	36	34
2014	9	24	9	8	19	0.784	-0.089	3.822	0.01	0.007	0	41.7	36.5	74	132	119	0	35	34
2014	9	24	9	18	19	0.843	-0.098	3.822	0.013	0.01	0	42.1	37.8	73.1	133	121	0	35	33
2014	9	24	9	28	19	0.853	-0.089	3.822	0.016	0.013	0	42.1	37.8	73.5	134	121	0	36	33
2014	9	24	9	38	19	0.774	-0.075	3.822	0.013	0.01	0	41.3	37	73.5	132	119	0	36	33
2014	9	24	9	48	19	0.797	-0.079	3.822	0.01	0.007	0	41.7	37	74.8	132	119	0	35	33
2014	9	24	9	58	19	0.843	-0.115	3.819	0.01	0.007	0	41.7	37.4	74	133	120	0	36	33
2014	9	24	10	8	19	0.801	-0.121	3.819	0.013	0.01	0	42.1	37.8	74.4	133	121	0	35	33
2014	9	24	10	18	19	0.82	-0.098	3.819	0.01	0.007	0	41.7	37.4	74.4	133	120	0	36	33
2014	9	24	10	28	19	0.814	-0.105	3.819	0.016	0.013	0	41.7	36.5	74.4	132	118	0	35	33
2014	9	24	10	38	19	0.814	-0.118	3.819	0.013	0.01	0	41.7	37.4	74.4	133	120	0	36	33
2014	9	24	10	48	19	0.801	-0.118	3.819	0.013	0.01	0	42.1	37.8	74.8	133	120	0	35	32
2014	9	24	10	58	19	0.801	-0.105	3.819	0.01	0.007	0	41.3	37	73.5	132	119	0	36	33
2014	9	24	11	8	19	0.843	-0.092	3.819	0.013	0.01	0	41.3	37.4	74.8	131	119	0	35	32
2014	9	24	11	18	19	0.781	-0.118	3.819	0.016	0.013	0	41.7	37	75.7	132	119	0	35	33
2014	9	24	11	28	19	0.774	-0.075	3.816	0.01	0.007	0	41.7	37	74	132	119	0	35	33
2014	9	24	11	38	19	0.787	-0.128	3.816	0.01	0.007	0	41.3	37	75.3	132	119	0	36	33
2014	9	24	11	48	19	0.814	-0.112	3.819	0.01	0.007	0	41.3	36.5	75.7	131	118	0	35	33
2014	9	24	11	58	19	0.827	-0.092	3.819	0.01	0.007	0	41.3	37	76.5	132	119	0	36	33
2014	9	24	12	8	19	0.817	-0.072	3.816	0.013	0.01	0	41.7	37	70.5	132	119	0	35	33
2014	9	24	12	18	19	0.797	-0.118	3.816	0.01	0.007	0	40.9	37	76.1	131	119	0	36	33
2014	9	24	12	28	19	0.797	-0.095	3.816	0.013	0.01	0	41.7	37	76.1	132	119	0	35	33
2014	9	24	12	38	19	0.807	-0.108	3.816	0.01	0.007	0	41.7	36.5	76.1	132	119	0	35	34
2014	9	24	12	48	19	0.846	-0.102	3.816	0.016	0.013	0	42.1	37.4	67.1	133	120	0	35	33
2014	9	24	12	58	19	0.82	-0.108	3.816	0.01	0.007	0	42.1	37.4	63.6	133	120	0	35	33
2014	9	24	13	8	19	0.774	-0.098	3.812	0.013	0.01	0	42.1	37.8	66.7	133	121	0	35	33
2014	9	24	13	18	19	0.791	-0.108	3.816	0.013	0.01	0	42.1	37.4	59.8	133	120	0	35	33
2014	9	24	13	28	19	0.804	-0.102	3.816	0.016	0.013	0	42.1	37.4	61.9	133	120	0	35	33
2014	9	24	13	38	19	0.807	-0.075	3.816	0.01	0.007	0	42.6	37.8	56.8	134	121	0	35	33
2014	9	24	13	48	19	0.778	-0.062	3.816	0.016	0.013	0	42.1	37.4	65.4	133	120	0	35	33
2014	9	24	13	58	19	0.804	-0.095	3.816	0.013	0.01	0	42.1	37	57.6	133	119	0	35	33
2014	9	24	14	8	19	0.797	-0.079	3.812	0.013	0.01	0	42.1	37.4	63.2	133	120	0	35	33
2014	9	24	14	18	19	0.758	-0.089	3.812	0.013	0.01	0	42.1	37.4	55.9	133	120	0	35	33
2014	9	24	14	28	19	0.807	-0.056	3.812	0.013	0.01	0	42.1	37.8	55.5	134	121	0	36	33
2014	9	24	14	38	19	0.81	-0.108	3.812	0.01	0.007	0	42.6	38.3	58.5	135	122	0	36	33
2014	9	24	14	48	19	0.794	-0.108	3.812	0.013	0.01	0	42.6	37.8	57.2	134	121	0	35	33
2014	9	24	14	58	19	0.781	-0.092	3.812	0.013	0.01	0	42.6	37.4	58	134	121	0	35	34
2014	9	24	15	8	19	0.755	-0.135	3.812	0.013	0.01	0	42.1	37.4	55.5	133	120	0	35	33
2014	9	24	15	18	19	0.801	-0.082	3.812	0.016	0.013	0	42.1	37.4	55.5	133	120	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	15	28	19	0.794	-0.108	3.809	0.013	0.01	0	42.6	37.8	56.8	134	121	0	35	33
2014	9	24	15	38	19	0.781	-0.112	3.812	0.016	0.013	0	42.6	37.8	58	134	121	0	35	33
2014	9	24	15	48	19	0.823	-0.105	3.809	0.013	0.01	0	42.6	37.8	55	134	121	0	35	33
2014	9	24	15	58	19	0.797	-0.085	3.809	0.01	0.007	0	42.6	37.8	58.5	134	121	0	35	33
2014	9	24	16	8	19	0.778	-0.115	3.809	0.01	0.007	0	42.6	37.8	53.3	134	121	0	35	33
2014	9	24	16	18	19	0.833	-0.072	3.809	0.013	0.01	0	42.1	37.8	55.5	134	121	0	36	33
2014	9	24	16	28	19	0.817	-0.072	3.809	0.01	0.007	0	43	38.3	54.2	135	122	0	35	33
2014	9	24	16	38	19	0.774	-0.098	3.806	0.013	0.01	0	43	37.8	54.2	135	121	0	35	33
2014	9	24	16	48	19	0.814	-0.056	3.806	0.01	0.007	0	42.1	37.8	52	134	121	0	36	33
2014	9	24	16	58	19	0.787	-0.095	3.806	0.016	0.016	0	43	38.3	52.5	135	122	0	35	33
2014	9	24	17	8	19	0.745	-0.092	3.809	0.013	0.01	0	43.4	37.8	55.9	136	122	0	35	34
2014	9	24	17	18	19	0.807	-0.072	3.806	0.013	0.01	0	42.1	37.8	55.5	134	121	0	36	33
2014	9	24	17	28	19	0.784	-0.092	3.806	0.013	0.01	0	43.4	38.7	54.2	136	122	0	35	32
2014	9	24	17	38	19	0.794	-0.079	3.806	0.01	0.007	0	43	37.8	52.9	135	121	0	35	33
2014	9	24	17	48	19	0.778	-0.092	3.806	0.013	0.01	0	43	37.4	58	135	121	0	35	34
2014	9	24	17	58	19	0.794	-0.082	3.802	0.01	0.007	0	43	37.8	53.3	135	121	0	35	33
2014	9	24	18	8	19	0.814	-0.098	3.806	0.01	0.007	0	43	38.3	55.9	135	122	0	35	33
2014	9	24	18	18	19	0.787	-0.108	3.806	0.01	0.007	0	43	37.8	60.2	135	121	0	35	33
2014	9	24	18	28	19	0.768	-0.121	3.806	0.013	0.01	0	43.4	38.7	53.8	136	123	0	35	33
2014	9	24	18	38	19	0.804	-0.092	3.806	0.01	0.007	0	43.9	38.7	55.9	137	123	0	35	33
2014	9	24	18	48	19	0.755	-0.069	3.802	0.013	0.01	0	43.4	38.3	55.5	136	122	0	35	33
2014	9	24	18	58	19	0.755	-0.085	3.806	0.013	0.01	0	44.7	39.6	56.8	139	125	0	35	33
2014	9	24	19	8	19	0.797	-0.069	3.806	0.016	0.013	0	43.4	39.1	61.1	137	124	0	36	33
2014	9	24	19	18	19	0.807	-0.075	3.806	0.013	0.01	0	44.3	39.1	58.5	138	124	0	35	33
2014	9	24	19	28	19	0.82	-0.105	3.806	0.01	0.007	0	44.3	39.1	57.6	138	124	0	35	33
2014	9	24	19	38	19	0.856	-0.115	3.806	0.01	0.007	0	43.9	39.1	62.4	138	124	0	36	33
2014	9	24	19	48	19	0.794	-0.052	3.809	0.01	0.007	0	44.7	39.1	62.4	139	125	0	35	34
2014	9	24	19	58	19	0.83	-0.105	3.809	0.01	0.007	0	44.3	39.1	67.1	138	124	0	35	33
2014	9	24	20	8	19	0.84	-0.108	3.806	0.013	0.01	0	43.9	39.1	63.6	137	124	0	35	33
2014	9	24	20	18	19	0.804	-0.092	3.809	0.013	0.01	0	44.3	39.1	66.2	138	124	0	35	33
2014	9	24	20	28	19	0.83	-0.105	3.809	0.013	0.01	0	44.3	39.1	70.5	138	124	0	35	33
2014	9	24	20	38	19	0.833	-0.075	3.809	0.01	0.007	0	44.3	39.1	74.8	138	124	0	35	33
2014	9	24	20	48	19	0.83	-0.121	3.809	0.013	0.01	0	43.9	39.1	75.3	138	124	0	36	33
2014	9	24	20	58	19	0.846	-0.095	3.809	0.01	0.007	0	44.3	39.6	68.4	138	125	0	35	33
2014	9	24	21	8	19	0.814	-0.072	3.809	0.01	0.007	0	44.7	39.6	61.1	139	125	0	35	33
2014	9	24	21	18	19	0.764	-0.082	3.809	0.013	0.01	0	44.3	39.6	61.5	138	125	0	35	33
2014	9	24	21	28	19	0.817	-0.089	3.809	0.016	0.013	0	44.3	39.6	61.1	139	125	0	36	33
2014	9	24	21	38	19	0.81	-0.092	3.809	0.013	0.01	0	44.7	39.6	57.6	139	124	0	35	32
2014	9	24	21	48	19	0.827	-0.125	3.809	0.01	0.007	0	44.7	39.6	56.3	139	125	0	35	33
2014	9	24	21	58	19	0.81	-0.062	3.809	0.013	0.01	0	44.7	39.6	58	139	125	0	35	33
2014	9	24	22	8	19	0.817	-0.082	3.809	0.01	0.007	0	44.3	39.1	56.3	138	124	0	35	33
2014	9	24	22	18	19	0.863	-0.095	3.809	0.01	0.007	0	44.3	39.1	58.9	138	125	0	35	34
2014	9	24	22	28	19	0.787	-0.112	3.809	0.01	0.007	0	44.3	39.6	60.6	138	125	0	35	33
2014	9	24	22	38	19	0.807	-0.059	3.809	0.01	0.007	0	44.3	39.6	61.1	139	125	0	36	33
2014	9	24	22	48	19	0.86	-0.089	3.809	0.01	0.007	0	44.7	40	65.8	139	126	0	35	33
2014	9	24	22	58	19	0.873	-0.072	3.812	0.01	0.007	0	44.7	39.6	77.8	139	125	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	24	23	8	19	0.797	-0.095	3.812	0.01	0.007	0	44.7	39.1	77.4	139	125	0	35	34
2014	9	24	23	18	19	0.817	-0.072	3.809	0.016	0.013	0	44.7	39.6	63.6	139	125	0	35	33
2014	9	24	23	28	19	0.82	-0.075	3.809	0.01	0.007	0	43.9	39.1	55.9	138	124	0	36	33
2014	9	24	23	38	19	0.748	-0.066	3.809	0.013	0.01	0	44.3	40	55.5	139	126	0	36	33
2014	9	24	23	48	19	0.81	-0.085	3.809	0.016	0.013	0	46.4	40.9	53.8	143	128	0	35	33
2014	9	24	23	58	19	0.797	-0.092	3.809	0.01	0.007	0	46	40.4	51.6	142	127	0	35	33
2014	9	25	0	8	19	0.758	-0.062	3.809	0.01	0.007	0	45.6	40.4	53.8	141	127	0	35	33
2014	9	25	0	18	19	0.804	-0.102	3.809	0.013	0.01	0	45.2	40	56.8	140	126	0	35	33
2014	9	25	0	28	19	0.82	-0.095	3.809	0.016	0.013	0	45.2	39.6	55	140	126	0	35	34
2014	9	25	0	38	19	0.856	-0.079	3.809	0.013	0.01	0	44.7	39.6	54.2	139	125	0	35	33
2014	9	25	0	48	19	0.814	-0.075	3.809	0.013	0.01	0	44.7	40	54.2	139	126	0	35	33
2014	9	25	0	58	19	0.82	-0.105	3.809	0.016	0.013	0	45.6	40	54.2	141	127	0	35	34
2014	9	25	1	8	19	0.843	-0.082	3.812	0.01	0.007	0	46	40.9	57.2	142	128	0	35	33
2014	9	25	1	18	19	0.81	-0.079	3.812	0.01	0.007	0	46	40.4	57.6	142	127	0	35	33
2014	9	25	1	28	19	0.797	-0.112	3.812	0.013	0.01	0	45.2	40.4	55	140	127	0	35	33
2014	9	25	1	38	19	0.823	-0.098	3.812	0.013	0.01	0	45.2	40.4	55.5	140	126	0	35	32
2014	9	25	1	48	19	0.784	-0.105	3.809	0.013	0.01	0	45.2	40	50.7	140	126	0	35	33
2014	9	25	1	58	19	0.791	-0.115	3.812	0.01	0.007	0	45.2	39.6	50.7	140	126	0	35	34
2014	9	25	2	8	19	0.814	-0.069	3.812	0.01	0.007	0	43.9	39.1	52.9	138	124	0	36	33
2014	9	25	2	18	19	0.778	-0.098	3.812	0.013	0.01	0	44.7	40	53.3	139	125	0	35	32
2014	9	25	2	28	19	0.791	-0.102	3.812	0.013	0.01	0	44.7	39.6	52	139	125	0	35	33
2014	9	25	2	38	19	0.81	-0.066	3.812	0.01	0.007	0	45.2	39.6	54.6	139	125	0	34	33
2014	9	25	2	48	19	0.778	-0.075	3.812	0.013	0.01	0	44.7	39.6	52	139	125	0	35	33
2014	9	25	2	58	19	0.814	-0.092	3.812	0.016	0.013	0	44.3	39.1	53.8	139	124	0	36	33
2014	9	25	3	8	19	0.843	-0.115	3.812	0.01	0.007	0	43.9	39.1	55	138	124	0	36	33
2014	9	25	3	18	19	0.807	-0.092	3.812	0.016	0.013	0	44.3	38.7	52.9	138	124	0	35	34
2014	9	25	3	28	19	0.804	-0.085	3.812	0.01	0.007	0	44.7	40	52.9	139	125	0	35	32
2014	9	25	3	38	19	0.804	-0.085	3.812	0.01	0.007	0	44.7	40	52	140	126	0	36	33
2014	9	25	3	48	19	0.807	-0.105	3.816	0.013	0.01	0	45.2	40	52.9	140	126	0	35	33
2014	9	25	3	58	19	0.784	-0.089	3.812	0.01	0.007	0	45.2	39.6	52.5	140	126	0	35	34
2014	9	25	4	8	19	0.768	-0.092	3.812	0.013	0.01	0	45.6	40.4	52.9	141	127	0	35	33
2014	9	25	4	18	19	0.774	-0.102	3.816	0.01	0.007	0	46	41.3	52	142	128	0	35	32
2014	9	25	4	28	19	0.774	-0.075	3.816	0.01	0.007	0	46.4	41.3	52	143	129	0	35	33
2014	9	25	4	38	19	0.768	-0.075	3.816	0.016	0.013	0	46.4	41.3	50.7	143	129	0	35	33
2014	9	25	4	48	19	0.748	-0.079	3.812	0.01	0.007	0	47.3	42.1	50.7	145	131	0	35	33
2014	9	25	4	58	19	0.801	-0.098	3.816	0.016	0.013	0	48.2	43.9	50.3	148	134	0	36	32
2014	9	25	5	8	19	0.787	-0.085	3.812	0.013	0.01	0	47.7	42.6	47.7	146	132	0	35	33
2014	9	25	5	18	19	0.794	-0.075	3.816	0.01	0.007	0	47.3	42.1	49.9	145	131	0	35	33
2014	9	25	5	28	19	0.791	-0.059	3.816	0.01	0.007	0	47.3	42.1	49.9	145	131	0	35	33
2014	9	25	5	38	19	0.778	-0.098	3.816	0.013	0.01	0	46.4	41.3	48.2	143	129	0	35	33
2014	9	25	5	48	19	0.784	-0.092	3.816	0.013	0.01	0	46.9	41.3	49.5	144	130	0	35	34
2014	9	25	5	58	19	0.807	-0.059	3.816	0.01	0.007	0	46.9	41.7	52.5	144	130	0	35	33
2014	9	25	6	8	19	0.774	-0.069	3.816	0.013	0.01	0	46.4	41.3	51.6	143	129	0	35	33
2014	9	25	6	18	19	0.764	-0.075	3.816	0.01	0.007	0	46	40.9	50.3	142	128	0	35	33
2014	9	25	6	28	19	0.781	-0.102	3.816	0.01	0.007	0	46	40.9	51.6	142	128	0	35	33
2014	9	25	6	38	19	0.794	-0.075	3.816	0.01	0.007	0	45.6	40.4	52	141	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	6	48	19	0.807	-0.082	3.816	0.016	0.013	0	45.2	40	49	140	126	0	35	33
2014	9	25	6	58	19	0.853	-0.059	3.816	0.01	0.007	0	44.3	39.1	51.2	139	124	0	36	33
2014	9	25	7	8	19	0.791	-0.108	3.816	0.01	0.007	0	43.4	38.7	50.7	137	123	0	36	33
2014	9	25	7	18	19	0.774	-0.082	3.816	0.016	0.013	0	43.4	38.3	52.5	136	122	0	35	33
2014	9	25	7	28	19	0.807	-0.105	3.812	0.013	0.01	0	43	37.4	54.6	135	121	0	35	34
2014	9	25	7	38	19	0.81	-0.075	3.816	0.013	0.01	0	43	37.8	55	135	121	0	35	33
2014	9	25	7	48	19	0.778	-0.089	3.816	0.013	0.01	0	43	37.8	52.9	134	121	0	34	33
2014	9	25	7	58	19	0.764	-0.092	3.816	0.013	0.01	0	42.6	37.4	57.2	134	120	0	35	33
2014	9	25	8	8	19	0.787	-0.115	3.816	0.01	0.007	0	41.7	37.4	55.5	133	120	0	36	33
2014	9	25	8	18	19	0.801	-0.089	3.816	0.013	0.01	0	43	38.3	54.6	135	122	0	35	33
2014	9	25	8	28	19	0.807	-0.115	3.816	0.01	0.007	0	43.9	38.3	55	137	123	0	35	34
2014	9	25	8	38	19	0.804	-0.092	3.816	0.01	0.007	0	45.2	40.4	53.8	140	127	0	35	33
2014	9	25	8	48	19	0.758	-0.092	3.816	0.013	0.01	0	45.6	40.9	53.8	142	128	0	36	33
2014	9	25	8	58	19	0.791	-0.092	3.819	0.013	0.01	0	46.9	42.1	50.3	145	131	0	36	33
2014	9	25	9	8	19	0.748	-0.069	3.816	0.01	0.007	0	47.7	42.6	52	146	132	0	35	33
2014	9	25	9	18	19	0.745	-0.072	3.816	0.016	0.013	0	47.7	43	50.3	146	133	0	35	33
2014	9	25	9	28	19	0.784	-0.072	3.816	0.01	0.007	0	47.3	42.6	52	146	133	0	36	34
2014	9	25	9	38	19	0.784	-0.105	3.819	0.013	0.01	0	49	44.3	52.5	149	136	0	35	33
2014	9	25	9	48	19	0.764	-0.052	3.816	0.013	0.01	0	49.9	45.2	49	151	138	0	35	33
2014	9	25	9	58	19	0.774	-0.082	3.816	0.013	0.01	0	49.9	44.7	50.3	151	137	0	35	33
2014	9	25	10	8	19	0.768	-0.082	3.819	0.01	0.007	0	49.9	45.2	51.2	151	138	0	35	33
2014	9	25	10	18	19	0.794	-0.105	3.819	0.013	0.01	0	49	44.3	50.7	150	136	0	36	33
2014	9	25	10	28	19	0.745	-0.095	3.816	0.01	0.007	0	49.9	44.7	51.6	151	137	0	35	33
2014	9	25	10	38	19	0.761	-0.098	3.816	0.013	0.01	0	49.5	44.3	51.2	150	136	0	35	33
2014	9	25	10	48	19	0.774	-0.108	3.816	0.01	0.007	0	49.9	45.2	52	151	138	0	35	33
2014	9	25	10	58	19	0.784	-0.089	3.816	0.01	0.007	0	49.5	44.7	49.9	150	137	0	35	33
2014	9	25	11	8	19	0.751	-0.072	3.816	0.013	0.01	0	49	43.9	51.6	149	136	0	35	34
2014	9	25	11	18	19	0.778	-0.098	3.816	0.01	0.007	0	49	44.3	50.3	149	136	0	35	33
2014	9	25	11	28	19	0.748	-0.069	3.816	0.016	0.013	0	48.6	44.3	51.6	149	136	0	36	33
2014	9	25	11	38	19	0.768	-0.072	3.816	0.01	0.007	0	48.2	43.9	50.7	147	135	0	35	33
2014	9	25	11	48	19	0.712	-0.052	3.816	0.013	0.01	0	49	44.3	50.3	149	136	0	35	33
2014	9	25	11	58	19	0.719	-0.066	3.812	0.02	0.016	0	49.5	44.7	49	150	137	0	35	33
2014	9	25	12	8	19	0.751	-0.062	3.812	0.016	0.013	0	48.6	43.9	49.9	148	135	0	35	33
2014	9	25	12	18	19	0.781	-0.066	3.812	0.01	0.007	0	48.2	43	52.9	147	133	0	35	33
2014	9	25	12	28	19	0.774	-0.075	3.812	0.01	0.007	0	47.7	43	49	147	134	0	36	34
2014	9	25	12	38	19	0.771	-0.075	3.812	0.01	0.007	0	48.6	43	51.2	148	134	0	35	34
2014	9	25	12	48	19	0.791	-0.108	3.816	0.01	0.007	0	47.7	43	51.2	146	133	0	35	33
2014	9	25	12	58	19	0.768	-0.072	3.816	0.016	0.013	0	47.3	42.1	50.3	145	132	0	35	34
2014	9	25	13	8	19	0.781	-0.082	3.809	0.013	0.01	0	46.9	41.7	52	144	131	0	35	34
2014	9	25	13	18	19	0.755	-0.095	3.809	0.01	0.007	0	46.4	41.7	50.3	143	130	0	35	33
2014	9	25	13	28	19	0.764	-0.056	3.812	0.01	0.007	0	46	41.7	49.9	143	130	0	36	33
2014	9	25	13	38	19	0.771	-0.072	3.809	0.01	0.007	0	46.4	41.7	49.9	143	130	0	35	33
2014	9	25	13	48	19	0.764	-0.105	3.812	0.013	0.01	0	46	40.9	50.7	142	129	0	35	34
2014	9	25	13	58	19	0.761	-0.069	3.812	0.01	0.007	0	46	41.3	51.6	142	129	0	35	33
2014	9	25	14	8	19	0.751	-0.075	3.809	0.013	0.01	0	44.7	40.4	51.6	140	127	0	36	33
2014	9	25	14	18	19	0.781	-0.089	3.806	0.013	0.01	0	44.7	40.4	49.9	140	127	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	14	28	19	0.817	-0.089	3.806	0.01	0.007	0	44.7	40	50.7	139	126	0	35	33
2014	9	25	14	38	19	0.791	-0.072	3.806	0.013	0.01	0	45.2	40	52	140	127	0	35	34
2014	9	25	14	48	19	0.778	-0.062	3.806	0.013	0.01	0	44.3	40	52	139	126	0	36	33
2014	9	25	14	58	19	0.791	-0.089	3.806	0.01	0.007	0	44.7	40	51.2	139	126	0	35	33
2014	9	25	15	8	19	0.774	-0.072	3.802	0.013	0.01	0	44.7	40	51.2	139	126	0	35	33
2014	9	25	15	18	19	0.817	-0.102	3.802	0.013	0.01	0	44.7	40	49.5	139	126	0	35	33
2014	9	25	15	28	19	0.738	-0.079	3.806	0.01	0.007	0	45.2	40.4	51.6	140	127	0	35	33
2014	9	25	15	38	19	0.781	-0.072	3.802	0.01	0.007	0	45.2	40.9	50.7	140	128	0	35	33
2014	9	25	15	48	19	0.764	-0.066	3.802	0.016	0.013	0	45.2	40.9	51.2	140	127	0	35	32
2014	9	25	15	58	19	0.784	-0.089	3.802	0.01	0.007	0	44.7	39.6	51.2	139	125	0	35	33
2014	9	25	16	8	19	0.827	-0.075	3.802	0.013	0.01	0	45.2	40.9	50.3	140	127	0	35	32
2014	9	25	16	18	19	0.778	-0.092	3.799	0.013	0.01	0	44.7	40	50.7	139	126	0	35	33
2014	9	25	16	28	19	0.817	-0.092	3.802	0.013	0.01	0	44.7	40	49.5	139	126	0	35	33
2014	9	25	16	38	19	0.732	-0.108	3.802	0.013	0.01	0	44.3	39.1	51.6	138	124	0	35	33
2014	9	25	16	48	19	0.778	-0.085	3.799	0.016	0.013	0	44.3	38.7	49.9	138	124	0	35	34
2014	9	25	16	58	19	0.787	-0.095	3.799	0.013	0.01	0	43.9	38.7	52	137	123	0	35	33
2014	9	25	17	8	19	0.791	-0.072	3.799	0.013	0.01	0	44.3	38.7	52.5	137	123	0	34	33
2014	9	25	17	18	19	0.764	-0.079	3.796	0.016	0.016	0	44.3	39.6	52.5	138	124	0	35	32
2014	9	25	17	28	19	0.804	-0.069	3.799	0.013	0.01	0	43.9	40	48.6	138	125	0	36	32
2014	9	25	17	38	19	0.755	-0.075	3.799	0.013	0.01	0	44.3	39.6	51.2	138	125	0	35	33
2014	9	25	17	48	19	0.787	-0.069	3.796	0.01	0.007	0	44.3	39.6	50.3	138	124	0	35	32
2014	9	25	17	58	19	0.804	-0.079	3.799	0.013	0.01	0	44.7	39.6	50.7	139	125	0	35	33
2014	9	25	18	8	19	0.755	-0.066	3.796	0.013	0.01	0	44.3	39.6	51.2	138	125	0	35	33
2014	9	25	18	18	19	0.801	-0.082	3.796	0.013	0.01	0	43.4	38.7	52.9	136	123	0	35	33
2014	9	25	18	28	19	0.755	-0.036	3.799	0.016	0.013	0	44.7	39.6	52.5	139	125	0	35	33
2014	9	25	18	38	19	0.758	-0.089	3.796	0.01	0.007	0	44.3	39.6	50.7	138	125	0	35	33
2014	9	25	18	48	19	0.781	-0.066	3.796	0.01	0.007	0	44.3	39.6	51.6	138	125	0	35	33
2014	9	25	18	58	19	0.755	-0.069	3.799	0.016	0.013	0	44.7	39.6	52	139	125	0	35	33
2014	9	25	19	8	19	0.719	-0.085	3.799	0.013	0.01	0	45.2	40.4	50.3	140	127	0	35	33
2014	9	25	19	18	19	0.784	-0.108	3.796	0.013	0.01	0	45.6	40.4	49	141	127	0	35	33
2014	9	25	19	28	19	0.817	-0.062	3.793	0.01	0.007	0	46	40.9	52	142	128	0	35	33
2014	9	25	19	38	19	0.751	-0.095	3.796	0.01	0.007	0	45.2	40.9	49.9	141	128	0	36	33
2014	9	25	19	48	19	0.781	-0.072	3.796	0.013	0.01	0	46	40.9	50.7	142	128	0	35	33
2014	9	25	19	58	19	0.784	-0.059	3.796	0.01	0.007	0	46	40.9	50.7	142	128	0	35	33
2014	9	25	20	8	19	0.801	-0.059	3.796	0.013	0.01	0	46	40.9	50.3	142	128	0	35	33
2014	9	25	20	18	19	0.755	-0.079	3.796	0.013	0.01	0	46.4	40.9	50.3	143	128	0	35	33
2014	9	25	20	28	19	0.791	-0.108	3.796	0.01	0.007	0	46.9	41.7	49.9	143	130	0	34	33
2014	9	25	20	38	19	0.794	-0.085	3.796	0.013	0.01	0	46.9	41.7	49.9	144	130	0	35	33
2014	9	25	20	48	19	0.768	-0.062	3.796	0.016	0.013	0	46.4	41.3	51.2	143	129	0	35	33
2014	9	25	20	58	19	0.738	-0.082	3.796	0.016	0.013	0	46	40.9	52	142	128	0	35	33
2014	9	25	21	8	19	0.787	-0.092	3.796	0.01	0.007	0	46	41.3	49.9	142	128	0	35	32
2014	9	25	21	18	19	0.741	-0.089	3.796	0.01	0.007	0	46	41.3	51.6	142	129	0	35	33
2014	9	25	21	28	19	0.751	-0.108	3.796	0.01	0.007	0	46	40.9	49.9	142	128	0	35	33
2014	9	25	21	38	19	0.781	-0.066	3.796	0.01	0.007	0	45.6	40.9	51.2	141	128	0	35	33
2014	9	25	21	48	19	0.764	-0.079	3.796	0.01	0.007	0	46	41.7	50.7	142	129	0	35	32
2014	9	25	21	58	19	0.784	-0.075	3.796	0.016	0.013	0	46	41.3	51.2	142	129	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	25	22	8	19	0.797	-0.075	3.796	0.013	0.01	0	46	40.9	50.7	142	128	0	35	33
2014	9	25	22	18	19	0.755	-0.075	3.793	0.01	0.007	0	45.6	40.9	52.9	141	128	0	35	33
2014	9	25	22	28	19	0.807	-0.092	3.796	0.01	0.007	0	45.6	40.9	51.6	142	128	0	36	33
2014	9	25	22	38	19	0.745	-0.108	3.793	0.01	0.007	0	45.6	40.9	52.5	141	128	0	35	33
2014	9	25	22	48	19	0.833	-0.082	3.793	0.013	0.01	0	45.2	40.4	51.2	141	127	0	36	33
2014	9	25	22	58	19	0.784	-0.092	3.789	0.01	0.007	0	45.6	40.4	62.8	141	127	0	35	33
2014	9	25	23	8	19	0.787	-0.085	3.793	0.013	0.01	0	45.2	40.4	55	140	127	0	35	33
2014	9	25	23	18	19	0.807	-0.092	3.793	0.016	0.013	0	45.2	40.4	61.9	140	127	0	35	33
2014	9	25	23	28	19	0.807	-0.089	3.793	0.016	0.013	0	44.7	40	55.9	139	126	0	35	33
2014	9	25	23	38	19	0.81	-0.075	3.789	0.013	0.01	0	45.2	39.6	54.2	140	126	0	35	34
2014	9	25	23	48	19	0.82	-0.102	3.793	0.016	0.013	0	45.2	39.6	56.8	140	126	0	35	34
2014	9	25	23	58	19	0.784	-0.075	3.793	0.013	0.01	0	45.2	40	50.3	140	126	0	35	33
2014	9	26	0	8	19	0.784	-0.089	3.793	0.01	0.007	0	44.7	40.4	54.2	140	127	0	36	33
2014	9	26	0	18	19	0.764	-0.128	3.793	0.01	0.007	0	45.6	40.4	53.3	141	127	0	35	33
2014	9	26	0	28	19	0.771	-0.095	3.793	0.013	0.01	0	46	40.9	50.7	142	128	0	35	33
2014	9	26	0	38	19	0.764	-0.079	3.793	0.013	0.01	0	46.4	40.4	51.2	143	128	0	35	34
2014	9	26	0	48	19	0.751	-0.089	3.793	0.01	0.007	0	46.4	41.7	50.7	143	129	0	35	32
2014	9	26	0	58	19	0.781	-0.085	3.796	0.01	0.007	0	46.4	41.3	50.3	143	129	0	35	33
2014	9	26	1	8	19	0.735	-0.079	3.793	0.01	0.007	0	46.9	41.7	51.6	143	129	0	34	32
2014	9	26	1	18	19	0.778	-0.085	3.793	0.013	0.01	0	46.4	41.3	49	143	129	0	35	33
2014	9	26	1	28	19	0.725	-0.066	3.793	0.01	0.007	0	46.4	40.9	52	143	128	0	35	33
2014	9	26	1	38	19	0.797	-0.098	3.796	0.01	0.007	0	46.4	40.9	51.2	143	128	0	35	33
2014	9	26	1	48	19	0.787	-0.092	3.796	0.013	0.01	0	46	40.9	49	142	128	0	35	33
2014	9	26	1	58	19	0.787	-0.092	3.793	0.01	0.007	0	46.4	41.3	47.7	143	129	0	35	33
2014	9	26	2	8	19	0.781	-0.092	3.796	0.013	0.01	0	46	40.9	49.5	142	128	0	35	33
2014	9	26	2	18	19	0.751	-0.082	3.796	0.013	0.01	0	46	41.3	49.9	142	128	0	35	32
2014	9	26	2	28	19	0.781	-0.102	3.796	0.01	0.007	0	46	40.9	50.7	142	128	0	35	33
2014	9	26	2	38	19	0.768	-0.089	3.796	0.016	0.013	0	46	40.9	50.7	142	128	0	35	33
2014	9	26	2	48	19	0.81	-0.079	3.796	0.016	0.013	0	46.4	40.4	50.7	143	128	0	35	34
2014	9	26	2	58	19	0.781	-0.072	3.796	0.013	0.01	0	45.2	40.9	50.3	141	127	0	36	32
2014	9	26	3	8	19	0.787	-0.079	3.796	0.01	0.007	0	45.2	40.4	50.7	140	127	0	35	33
2014	9	26	3	18	19	0.827	-0.092	3.796	0.013	0.01	0	45.6	40	50.3	141	126	0	35	33
2014	9	26	3	28	19	0.801	-0.092	3.796	0.01	0.007	0	45.2	40	50.3	140	126	0	35	33
2014	9	26	3	38	19	0.771	-0.092	3.796	0.013	0.01	0	44.7	40	49	140	126	0	36	33
2014	9	26	3	48	19	0.801	-0.098	3.799	0.01	0.007	0	45.6	40.4	49	141	127	0	35	33
2014	9	26	3	58	19	0.761	-0.085	3.793	0.013	0.01	0	45.6	40.4	51.2	141	127	0	35	33
2014	9	26	4	8	19	0.814	-0.075	3.796	0.013	0.01	0	45.2	40.4	51.2	140	127	0	35	33
2014	9	26	4	18	19	0.787	-0.075	3.793	0.016	0.013	0	45.2	40	49.5	140	126	0	35	33
2014	9	26	4	28	19	0.781	-0.082	3.796	0.01	0.007	0	45.6	40.4	50.7	141	127	0	35	33
2014	9	26	4	38	19	0.778	-0.095	3.796	0.01	0.007	0	45.2	40	50.7	140	126	0	35	33
2014	9	26	4	48	19	0.764	-0.092	3.796	0.013	0.01	0	45.2	40.4	49	140	126	0	35	32
2014	9	26	4	58	19	0.778	-0.108	3.799	0.013	0.01	0	45.2	40	51.2	140	126	0	35	33
2014	9	26	5	8	19	0.781	-0.075	3.796	0.01	0.007	0	45.2	40	51.6	140	126	0	35	33
2014	9	26	5	18	19	0.771	-0.092	3.799	0.016	0.013	0	45.2	40.4	51.2	140	127	0	35	33
2014	9	26	5	28	19	0.778	-0.075	3.799	0.013	0.01	0	45.6	39.6	52	140	125	0	34	33
2014	9	26	5	38	19	0.801	-0.066	3.796	0.01	0.007	0	45.2	40	49	140	126	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	5	48	19	0.794	-0.108	3.799	0.01	0.007	0	44.7	39.1	49	139	125	0	35	34
2014	9	26	5	58	19	0.801	-0.098	3.799	0.01	0.007	0	44.7	39.6	49.9	139	125	0	35	33
2014	9	26	6	8	19	0.761	-0.085	3.799	0.016	0.013	0	44.7	39.6	47.7	139	125	0	35	33
2014	9	26	6	18	19	0.745	-0.072	3.799	0.013	0.01	0	44.7	40	50.3	140	126	0	36	33
2014	9	26	6	28	19	0.784	-0.108	3.799	0.013	0.01	0	44.3	39.6	50.7	138	125	0	35	33
2014	9	26	6	38	19	0.784	-0.059	3.799	0.01	0.007	0	44.3	39.1	49.5	138	124	0	35	33
2014	9	26	6	48	19	0.797	-0.059	3.799	0.01	0.007	0	44.3	38.7	52.5	138	123	0	35	33
2014	9	26	6	58	19	0.817	-0.075	3.799	0.013	0.01	0	43.4	38.7	51.2	137	123	0	36	33
2014	9	26	7	8	19	0.784	-0.098	3.802	0.01	0.007	0	43.4	38.3	54.2	136	122	0	35	33
2014	9	26	7	18	19	0.787	-0.095	3.802	0.01	0.007	0	43.4	38.3	52.9	136	122	0	35	33
2014	9	26	7	28	19	0.794	-0.092	3.802	0.01	0.007	0	43	38.3	50.3	136	122	0	36	33
2014	9	26	7	38	19	0.794	-0.056	3.802	0.013	0.01	0	43	37.4	54.6	135	121	0	35	34
2014	9	26	7	48	19	0.797	-0.069	3.802	0.01	0.007	0	43	37.8	53.8	135	121	0	35	33
2014	9	26	7	58	19	0.787	-0.092	3.802	0.013	0.01	0	42.1	37.4	53.8	134	120	0	36	33
2014	9	26	8	8	19	0.791	-0.056	3.802	0.016	0.013	0	42.1	37.4	53.8	134	120	0	36	33
2014	9	26	8	18	19	0.784	-0.089	3.802	0.01	0.007	0	42.6	37.4	54.2	134	120	0	35	33
2014	9	26	8	28	19	0.791	-0.072	3.802	0.013	0.01	0	42.6	38.3	52.9	134	121	0	35	32
2014	9	26	8	38	19	0.797	-0.092	3.802	0.016	0.013	0	42.6	37.8	51.6	134	121	0	35	33
2014	9	26	8	48	19	0.755	-0.059	3.806	0.01	0.007	0	42.6	37.8	52	135	121	0	36	33
2014	9	26	8	58	19	0.774	-0.092	3.799	0.01	0.007	0	43.4	37.8	51.2	136	122	0	35	34
2014	9	26	9	8	19	0.761	-0.092	3.802	0.01	0.007	0	43.4	38.3	52	136	122	0	35	33
2014	9	26	9	18	19	0.784	-0.092	3.802	0.013	0.01	0	43	38.3	51.6	136	122	0	36	33
2014	9	26	9	28	19	0.791	-0.112	3.806	0.013	0.01	0	43.4	38.7	50.3	136	123	0	35	33
2014	9	26	9	38	19	0.778	-0.059	3.806	0.01	0.007	0	43	37.8	52.5	135	121	0	35	33
2014	9	26	9	48	19	0.755	-0.046	3.806	0.01	0.007	0	42.6	37.8	49.9	135	121	0	36	33
2014	9	26	9	58	19	0.745	-0.092	3.806	0.01	0.007	0	42.1	36.5	51.6	133	119	0	35	34
2014	9	26	10	8	19	0.761	-0.082	3.802	0.01	0.007	0	42.1	37.4	51.6	133	120	0	35	33
2014	9	26	10	18	19	0.778	-0.069	3.806	0.01	0.007	0	42.1	37	50.3	133	120	0	35	34
2014	9	26	10	28	19	0.768	-0.072	3.806	0.01	0.007	0	42.1	37.8	52.5	133	120	0	35	32
2014	9	26	10	38	19	0.807	-0.115	3.806	0.013	0.01	0	42.6	37.8	51.6	134	121	0	35	33
2014	9	26	10	48	19	0.715	-0.069	3.802	0.01	0.007	0	42.1	38.7	53.8	133	122	0	35	32
2014	9	26	10	58	19	0.758	-0.082	3.806	0.01	0.007	0	43.4	39.1	52.9	136	123	0	35	32
2014	9	26	11	8	19	0.722	-0.059	3.806	0.013	0.01	0	44.3	39.6	52.9	138	125	0	35	33
2014	9	26	11	18	19	0.741	-0.098	3.806	0.016	0.013	0	45.6	40.9	50.7	141	128	0	35	33
2014	9	26	11	28	19	0.745	-0.108	3.806	0.013	0.01	0	45.6	40.9	51.6	141	127	0	35	32
2014	9	26	11	38	19	0.764	-0.085	3.806	0.01	0.007	0	46	40.9	53.3	142	128	0	35	33
2014	9	26	11	48	19	0.722	-0.069	3.802	0.01	0.007	0	45.6	41.3	51.6	142	128	0	36	32
2014	9	26	11	58	19	0.735	-0.072	3.802	0.01	0.007	0	46	41.7	50.3	142	129	0	35	32
2014	9	26	12	8	19	0.751	-0.098	3.806	0.01	0.007	0	45.2	40.4	51.6	140	127	0	35	33
2014	9	26	12	18	19	0.719	-0.069	3.806	0.016	0.013	0	45.6	40.9	51.6	142	128	0	36	33
2014	9	26	12	28	19	0.732	-0.079	3.802	0.013	0.01	0	45.6	40.9	51.2	141	128	0	35	33
2014	9	26	12	38	19	0.771	-0.075	3.806	0.013	0.01	0	46	41.3	51.2	142	129	0	35	33
2014	9	26	12	48	19	0.764	-0.072	3.802	0.013	0.01	0	45.2	40.9	52	141	128	0	36	33
2014	9	26	12	58	19	0.764	-0.092	3.802	0.016	0.013	0	45.2	40.9	50.7	141	128	0	36	33
2014	9	26	13	8	19	0.768	-0.062	3.799	0.01	0.007	0	45.6	41.3	49.5	141	128	0	35	32
2014	9	26	13	18	19	0.751	-0.079	3.799	0.01	0.007	0	45.6	40.9	52.9	141	128	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	13	28	19	0.768	-0.062	3.799	0.01	0.007	0	45.6	40.9	53.3	141	127	0	35	32
2014	9	26	13	38	19	0.771	-0.125	3.799	0.016	0.013	0	45.2	40.9	52.9	140	127	0	35	32
2014	9	26	13	48	19	0.791	-0.125	3.802	0.01	0.007	0	45.2	40	53.8	140	126	0	35	33
2014	9	26	13	58	19	0.738	-0.085	3.796	0.01	0.007	0	44.7	40	53.3	140	126	0	36	33
2014	9	26	14	8	19	0.748	-0.066	3.796	0.013	0.01	0	45.2	40.4	52.5	140	127	0	35	33
2014	9	26	14	18	19	0.784	-0.092	3.796	0.013	0.01	0	45.2	40.4	52.9	140	127	0	35	33
2014	9	26	14	28	19	0.768	-0.062	3.799	0.01	0.007	0	45.6	40.9	52.5	142	128	0	36	33
2014	9	26	14	38	19	0.732	-0.089	3.796	0.01	0.007	0	45.6	40.9	51.2	141	128	0	35	33
2014	9	26	14	48	19	0.705	-0.092	3.796	0.013	0.01	0	45.6	40.4	50.7	141	127	0	35	33
2014	9	26	14	58	19	0.764	-0.082	3.796	0.013	0.01	0	45.6	41.3	51.6	142	129	0	36	33
2014	9	26	15	8	19	0.761	-0.095	3.793	0.01	0.007	0	46.4	41.3	50.3	143	129	0	35	33
2014	9	26	15	18	19	0.725	-0.062	3.796	0.013	0.01	0	46.4	42.1	51.2	143	130	0	35	32
2014	9	26	15	28	19	0.741	-0.066	3.796	0.013	0.01	0	46	41.3	52	142	129	0	35	33
2014	9	26	15	38	19	0.768	-0.059	3.793	0.016	0.013	0	45.6	40.9	49.9	141	128	0	35	33
2014	9	26	15	48	19	0.784	-0.089	3.793	0.01	0.007	0	45.6	40.9	52	141	128	0	35	33
2014	9	26	15	58	19	0.748	-0.098	3.793	0.016	0.013	0	45.2	40.9	50.3	140	127	0	35	32
2014	9	26	16	8	19	0.787	-0.075	3.793	0.013	0.01	0	44.7	40.9	52	140	127	0	36	32
2014	9	26	16	18	19	0.751	-0.049	3.793	0.013	0.01	0	44.7	40.4	52	139	126	0	35	32
2014	9	26	16	28	19	0.787	-0.125	3.793	0.01	0.007	0	44.3	40	54.2	139	126	0	36	33
2014	9	26	16	38	19	0.771	-0.102	3.789	0.013	0.01	0	44.3	39.6	53.3	138	124	0	35	32
2014	9	26	16	48	19	0.768	-0.059	3.793	0.01	0.007	0	43.4	39.1	52.9	137	124	0	36	33
2014	9	26	16	58	19	0.784	-0.075	3.793	0.013	0.01	0	43	38.3	51.6	135	122	0	35	33
2014	9	26	17	8	19	0.774	-0.049	3.789	0.01	0.007	0	43.4	38.3	53.3	136	122	0	35	33
2014	9	26	17	18	19	0.827	-0.102	3.789	0.01	0.007	0	42.6	37.8	53.3	134	121	0	35	33
2014	9	26	17	28	19	0.758	-0.082	3.789	0.013	0.01	0	42.6	37.4	52.9	134	120	0	35	33
2014	9	26	17	38	19	0.768	-0.105	3.789	0.01	0.007	0	42.6	37.4	52.9	134	120	0	35	33
2014	9	26	17	48	19	0.784	-0.092	3.786	0.013	0.01	0	42.6	37.4	56.3	134	120	0	35	33
2014	9	26	17	58	19	0.817	-0.082	3.789	0.013	0.01	0	42.6	37.8	52	134	120	0	35	32
2014	9	26	18	8	19	0.738	-0.095	3.786	0.013	0.01	0	42.1	37.4	53.3	133	120	0	35	33
2014	9	26	18	18	19	0.797	-0.089	3.786	0.01	0.007	0	42.6	37.4	55.5	134	120	0	35	33
2014	9	26	18	28	19	0.797	-0.069	3.786	0.01	0.007	0	42.1	38.3	52.9	134	121	0	36	32
2014	9	26	18	38	19	0.771	-0.079	3.786	0.01	0.007	0	42.6	37.4	55	134	120	0	35	33
2014	9	26	18	48	19	0.778	-0.105	3.786	0.01	0.007	0	43	38.3	55.9	135	121	0	35	32
2014	9	26	18	58	19	0.764	-0.102	3.786	0.01	0.007	0	42.1	37.8	54.2	134	120	0	36	32
2014	9	26	19	8	19	0.771	-0.095	3.786	0.013	0.01	0	43	37.8	55.9	135	121	0	35	33
2014	9	26	19	18	19	0.732	-0.108	3.789	0.01	0.007	0	43	38.3	54.6	136	122	0	36	33
2014	9	26	19	28	19	0.761	-0.069	3.786	0.01	0.007	0	43.9	39.1	52.5	137	123	0	35	32
2014	9	26	19	38	19	0.784	-0.105	3.789	0.013	0.01	0	43.4	38.3	51.6	137	123	0	36	34
2014	9	26	19	48	19	0.748	-0.092	3.789	0.013	0.01	0	43.9	39.1	52.5	138	124	0	36	33
2014	9	26	19	58	19	0.751	-0.089	3.789	0.013	0.01	0	44.7	40	52	139	125	0	35	32
2014	9	26	20	8	19	0.768	-0.115	3.789	0.016	0.016	0	43.9	39.1	54.6	138	124	0	36	33
2014	9	26	20	18	19	0.778	-0.059	3.789	0.01	0.007	0	44.3	39.6	51.6	139	125	0	36	33
2014	9	26	20	28	19	0.804	-0.075	3.789	0.01	0.007	0	44.3	40	53.8	138	125	0	35	32
2014	9	26	20	38	19	0.728	-0.079	3.793	0.013	0.01	0	45.6	40.4	50.7	141	127	0	35	33
2014	9	26	20	48	19	0.761	-0.062	3.789	0.016	0.016	0	45.6	40.9	52	141	127	0	35	32
2014	9	26	20	58	19	0.791	-0.082	3.793	0.013	0.01	0	45.6	40.4	51.2	141	127	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	26	21	8	19	0.735	-0.089	3.789	0.01	0.007	0	45.6	40.4	52.9	141	127	0	35	33
2014	9	26	21	18	19	0.741	-0.089	3.789	0.01	0.007	0	45.2	40	52	140	126	0	35	33
2014	9	26	21	28	19	0.774	-0.082	3.789	0.016	0.013	0	45.2	40.4	51.2	141	127	0	36	33
2014	9	26	21	38	19	0.787	-0.062	3.789	0.01	0.007	0	45.6	40.9	52.9	141	128	0	35	33
2014	9	26	21	48	19	0.761	-0.085	3.789	0.013	0.01	0	45.6	40	51.6	141	127	0	35	34
2014	9	26	21	58	19	0.791	-0.092	3.789	0.01	0.007	0	45.6	40	51.2	141	126	0	35	33
2014	9	26	22	8	19	0.758	-0.092	3.789	0.013	0.01	0	44.7	39.6	52.9	139	125	0	35	33
2014	9	26	22	18	19	0.758	-0.066	3.789	0.013	0.01	0	43.9	39.1	52.9	138	124	0	36	33
2014	9	26	22	28	19	0.771	-0.092	3.789	0.013	0.01	0	44.7	39.6	52.5	139	124	0	35	32
2014	9	26	22	38	19	0.732	-0.069	3.793	0.01	0.007	0	44.3	39.6	51.6	139	125	0	36	33
2014	9	26	22	48	19	0.771	-0.092	3.789	0.01	0.007	0	44.3	39.1	52.5	138	123	0	35	32
2014	9	26	22	58	19	0.758	-0.092	3.789	0.01	0.007	0	44.3	38.7	52.5	138	124	0	35	34
2014	9	26	23	8	19	0.774	-0.092	3.789	0.013	0.01	0	44.3	39.1	52	138	124	0	35	33
2014	9	26	23	18	19	0.764	-0.095	3.789	0.01	0.007	0	44.3	38.7	52.9	138	123	0	35	33
2014	9	26	23	28	19	0.768	-0.089	3.789	0.013	0.01	0	44.3	39.1	53.8	138	124	0	35	33
2014	9	26	23	38	19	0.784	-0.082	3.789	0.01	0.007	0	44.7	39.1	51.2	139	124	0	35	33
2014	9	26	23	48	19	0.787	-0.085	3.789	0.01	0.007	0	43.9	38.7	54.2	137	123	0	35	33
2014	9	26	23	58	19	0.745	-0.072	3.793	0.01	0.007	0	44.3	38.7	56.3	138	123	0	35	33
2014	9	27	0	8	19	0.837	-0.069	3.789	0.01	0.007	0	43.9	38.7	55.9	137	123	0	35	33
2014	9	27	0	18	19	0.778	-0.098	3.789	0.013	0.01	0	43.4	37.8	51.6	136	122	0	35	34
2014	9	27	0	28	19	0.761	-0.069	3.789	0.016	0.013	0	43	38.3	56.8	136	122	0	36	33
2014	9	27	0	38	19	0.758	-0.079	3.789	0.01	0.007	0	43.9	38.3	54.2	137	122	0	35	33
2014	9	27	0	48	19	0.807	-0.092	3.796	0.013	0.01	0	44.3	38.7	68.8	138	123	0	35	33
2014	9	27	0	58	19	0.784	-0.089	3.793	0.01	0.007	0	43.9	38.7	51.6	137	123	0	35	33
2014	9	27	1	8	19	0.784	-0.092	3.793	0.01	0.007	0	43.9	37.8	49.5	137	122	0	35	34
2014	9	27	1	18	19	0.801	-0.098	3.793	0.01	0.007	0	43.4	38.7	54.6	137	123	0	36	33
2014	9	27	1	28	19	0.804	-0.092	3.793	0.01	0.007	0	43.9	38.7	52.9	137	123	0	35	33
2014	9	27	1	38	19	0.778	-0.121	3.789	0.01	0.007	0	43.4	38.7	53.8	136	123	0	35	33
2014	9	27	1	48	19	0.764	-0.059	3.789	0.016	0.013	0	43.4	38.7	54.2	136	123	0	35	33
2014	9	27	1	58	19	0.741	-0.079	3.793	0.016	0.013	0	43.9	38.3	51.6	137	122	0	35	33
2014	9	27	2	8	19	0.794	-0.105	3.796	0.013	0.01	0	43	38.3	62.8	136	122	0	36	33
2014	9	27	2	18	19	0.817	-0.072	3.799	0.01	0.007	0	43.4	38.3	74.8	136	122	0	35	33
2014	9	27	2	28	19	0.797	-0.118	3.799	0.01	0.007	0	43.9	38.7	77	137	123	0	35	33
2014	9	27	2	38	19	0.787	-0.089	3.799	0.013	0.01	0	43.4	38.7	77	136	122	0	35	32
2014	9	27	2	48	19	0.804	-0.075	3.799	0.01	0.007	0	43.4	38.3	77.8	136	122	0	35	33
2014	9	27	2	58	19	0.794	-0.072	3.799	0.01	0.007	0	43.4	38.3	77.4	136	122	0	35	33
2014	9	27	3	8	19	0.82	-0.085	3.799	0.01	0.007	0	43.9	38.3	77.4	137	122	0	35	33
2014	9	27	3	18	19	0.784	-0.089	3.799	0.013	0.01	0	42.6	38.3	76.5	134	122	0	35	33
2014	9	27	3	28	19	0.794	-0.059	3.799	0.016	0.013	0	43	38.3	78.3	136	122	0	36	33
2014	9	27	3	38	19	0.827	-0.105	3.799	0.013	0.01	0	43	38.3	77	136	122	0	36	33
2014	9	27	3	48	19	0.758	-0.098	3.799	0.01	0.007	0	43.4	38.7	78.3	137	123	0	36	33
2014	9	27	3	58	19	0.82	-0.082	3.799	0.01	0.007	0	43.4	38.3	77	136	122	0	35	33
2014	9	27	4	8	19	0.768	-0.108	3.799	0.016	0.013	0	43	38.3	78.3	136	122	0	36	33
2014	9	27	4	18	19	0.784	-0.089	3.799	0.01	0.007	0	43.4	38.3	78.3	136	122	0	35	33
2014	9	27	4	28	19	0.843	-0.066	3.799	0.016	0.013	0	43	38.3	79.6	136	122	0	36	33
2014	9	27	4	38	19	0.794	-0.089	3.799	0.01	0.007	0	43	37.4	78.7	135	121	0	35	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	4	48	19	0.778	-0.105	3.799	0.01	0.007	0	43.4	38.3	78.3	136	122	0	35	33
2014	9	27	4	58	19	0.794	-0.089	3.799	0.01	0.007	0	43	37.8	73.5	136	122	0	36	34
2014	9	27	5	8	19	0.797	-0.079	3.799	0.013	0.01	0	43.9	38.7	77	137	123	0	35	33
2014	9	27	5	18	19	0.794	-0.075	3.799	0.016	0.013	0	42.6	37.8	71.4	135	121	0	36	33
2014	9	27	5	28	19	0.784	-0.092	3.799	0.01	0.007	0	43	38.7	71	136	123	0	36	33
2014	9	27	5	38	19	0.804	-0.072	3.799	0.01	0.007	0	43.4	38.3	71	136	122	0	35	33
2014	9	27	5	48	19	0.804	-0.079	3.799	0.013	0.01	0	43	38.3	67.1	136	122	0	36	33
2014	9	27	5	58	19	0.817	-0.098	3.799	0.013	0.01	0	43	38.3	71	136	122	0	36	33
2014	9	27	6	8	19	0.797	-0.118	3.802	0.013	0.01	0	43	37.4	78.7	135	121	0	35	34
2014	9	27	6	18	19	0.794	-0.082	3.802	0.013	0.01	0	42.6	37.4	77	134	120	0	35	33
2014	9	27	6	28	19	0.82	-0.089	3.799	0.01	0.007	0	42.6	37.4	74.8	134	120	0	35	33
2014	9	27	6	38	19	0.791	-0.079	3.799	0.016	0.013	0	42.1	37.4	70.5	134	120	0	36	33
2014	9	27	6	48	19	0.784	-0.085	3.802	0.01	0.007	0	42.1	37.4	78.7	134	120	0	36	33
2014	9	27	6	58	19	0.801	-0.052	3.799	0.01	0.007	0	42.1	36.5	75.7	133	119	0	35	34
2014	9	27	7	8	19	0.784	-0.069	3.802	0.013	0.01	0	41.3	36.1	75.7	131	117	0	35	33
2014	9	27	7	18	19	0.794	-0.098	3.802	0.013	0.01	0	41.3	35.7	76.1	131	117	0	35	34
2014	9	27	7	28	19	0.804	-0.066	3.802	0.01	0.007	0	41.3	36.1	74	131	117	0	35	33
2014	9	27	7	38	19	0.801	-0.059	3.799	0.01	0.007	0	41.3	36.1	72.2	132	118	0	36	34
2014	9	27	7	48	19	0.784	-0.085	3.799	0.01	0.007	0	41.3	36.1	67.1	131	117	0	35	33
2014	9	27	7	58	19	0.794	-0.075	3.802	0.01	0.007	0	41.3	36.1	72.2	131	118	0	35	34
2014	9	27	8	8	19	0.794	-0.098	3.799	0.01	0.007	0	40.9	35.7	60.6	130	116	0	35	33
2014	9	27	8	18	19	0.807	-0.043	3.802	0.013	0.01	0	40.9	36.5	71.4	131	118	0	36	33
2014	9	27	8	28	19	0.801	-0.135	3.802	0.01	0.007	0	40.9	36.1	64.5	130	117	0	35	33
2014	9	27	8	38	19	0.804	-0.105	3.802	0.016	0.016	0	41.3	37	58.5	132	119	0	36	33
2014	9	27	8	48	19	0.755	-0.069	3.799	0.016	0.013	0	42.6	37.8	57.6	135	121	0	36	33
2014	9	27	8	58	19	0.797	-0.062	3.802	0.01	0.007	0	42.6	37.8	64.1	135	121	0	36	33
2014	9	27	9	8	19	0.771	-0.059	3.802	0.013	0.01	0	43	37.8	55	135	121	0	35	33
2014	9	27	9	18	19	0.801	-0.062	3.802	0.01	0.007	0	43.9	39.1	55.5	137	124	0	35	33
2014	9	27	9	28	19	0.81	-0.082	3.802	0.013	0.01	0	43.4	38.3	54.6	136	123	0	35	34
2014	9	27	9	38	19	0.771	-0.075	3.802	0.013	0.01	0	43	37.8	58.9	135	122	0	35	34
2014	9	27	9	48	19	0.768	-0.105	3.802	0.013	0.01	0	42.1	37.4	56.3	133	120	0	35	33
2014	9	27	9	58	19	0.81	-0.089	3.802	0.01	0.007	0	42.1	37.8	54.6	134	121	0	36	33
2014	9	27	10	8	19	0.764	-0.062	3.802	0.01	0.007	0	43	38.3	55	135	122	0	35	33
2014	9	27	10	18	19	0.764	-0.079	3.802	0.01	0.007	0	42.6	37.8	55.9	135	122	0	36	34
2014	9	27	10	28	19	0.781	-0.062	3.802	0.01	0.007	0	42.6	37.4	55	134	121	0	35	34
2014	9	27	10	38	19	0.784	-0.072	3.802	0.01	0.007	0	42.1	37.4	61.1	133	120	0	35	33
2014	9	27	10	48	19	0.801	-0.098	3.802	0.013	0.01	0	41.3	36.1	56.3	132	118	0	36	34
2014	9	27	10	58	19	0.771	-0.075	3.806	0.013	0.01	0	40.9	36.1	64.9	131	118	0	36	34
2014	9	27	11	8	19	0.787	-0.089	3.802	0.01	0.007	0	41.3	36.5	58.9	131	118	0	35	33
2014	9	27	11	18	19	0.801	-0.066	3.802	0.013	0.01	0	39.6	34.8	59.8	128	115	0	36	34
2014	9	27	11	28	19	0.745	-0.079	3.802	0.013	0.01	0	40	34.8	63.2	128	114	0	35	33
2014	9	27	11	38	19	0.787	-0.072	3.802	0.01	0.007	0	39.6	34.4	63.6	127	113	0	35	33
2014	9	27	11	48	19	0.797	-0.095	3.806	0.013	0.01	0	39.6	34	71	127	113	0	35	34
2014	9	27	11	58	19	0.794	-0.082	3.806	0.016	0.013	0	39.1	34	65.4	127	113	0	36	34
2014	9	27	12	8	19	0.771	-0.075	3.802	0.01	0.007	0	39.1	34.4	61.9	126	113	0	35	33
2014	9	27	12	18	19	0.787	-0.079	3.806	0.01	0.007	0	39.6	35.3	71.8	128	115	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	12	28	19	0.781	-0.089	3.806	0.013	0.01	0	39.6	34.8	66.7	127	114	0	35	33
2014	9	27	12	38	19	0.787	-0.075	3.806	0.013	0.01	0	40	34.8	67.1	128	114	0	35	33
2014	9	27	12	48	19	0.81	-0.059	3.802	0.01	0.007	0	39.1	34.8	69.2	127	114	0	36	33
2014	9	27	12	58	19	0.771	-0.052	3.802	0.013	0.01	0	40	35.3	66.7	128	114	0	35	32
2014	9	27	13	8	19	0.787	-0.108	3.802	0.01	0.007	0	40.4	35.7	59.3	129	116	0	35	33
2014	9	27	13	18	19	0.801	-0.056	3.802	0.013	0.01	0	40	35.7	55.5	129	116	0	36	33
2014	9	27	13	28	19	0.774	-0.085	3.802	0.01	0.007	0	40.4	35.7	55.5	129	116	0	35	33
2014	9	27	13	38	19	0.764	-0.095	3.802	0.01	0.007	0	41.3	36.1	54.2	131	117	0	35	33
2014	9	27	13	48	19	0.807	-0.089	3.802	0.01	0.007	0	41.7	36.5	55.5	132	118	0	35	33
2014	9	27	13	58	19	0.794	-0.082	3.802	0.01	0.007	0	41.3	37	56.3	131	119	0	35	33
2014	9	27	14	8	19	0.764	-0.085	3.802	0.013	0.01	0	41.7	37.4	55	133	120	0	36	33
2014	9	27	14	18	19	0.781	-0.069	3.802	0.01	0.007	0	41.7	37	57.2	132	120	0	35	34
2014	9	27	14	28	19	0.774	-0.072	3.802	0.016	0.013	0	41.7	37	55	132	119	0	35	33
2014	9	27	14	38	19	0.794	-0.075	3.802	0.01	0.007	0	41.7	36.5	57.2	132	119	0	35	34
2014	9	27	14	48	19	0.764	-0.095	3.802	0.01	0.007	0	40.9	36.1	58.9	131	118	0	36	34
2014	9	27	14	58	19	0.781	-0.075	3.802	0.016	0.013	0	41.3	36.5	56.8	131	118	0	35	33
2014	9	27	15	8	19	0.781	-0.085	3.802	0.016	0.016	0	41.3	35.7	65.8	131	117	0	35	34
2014	9	27	15	18	19	0.817	-0.066	3.802	0.013	0.01	0	40.9	35.7	65.4	130	116	0	35	33
2014	9	27	15	28	19	0.804	-0.102	3.802	0.013	0.01	0	39.6	35.3	70.1	128	115	0	36	33
2014	9	27	15	38	19	0.771	-0.069	3.802	0.013	0.01	0	39.6	34.8	78.7	128	115	0	36	34
2014	9	27	15	48	19	0.823	-0.079	3.802	0.013	0.01	0	39.6	34.8	77.8	127	113	0	35	32
2014	9	27	15	58	19	0.787	-0.092	3.802	0.013	0.01	0	39.6	34.4	77	127	113	0	35	33
2014	9	27	16	8	19	0.804	-0.059	3.802	0.01	0.007	0	40	34.8	77.8	128	114	0	35	33
2014	9	27	16	18	19	0.804	-0.075	3.802	0.01	0.007	0	40	35.3	74.8	129	115	0	36	33
2014	9	27	16	28	19	0.801	-0.082	3.802	0.01	0.007	0	40.4	34.8	78.7	129	115	0	35	34
2014	9	27	16	38	19	0.751	-0.072	3.802	0.01	0.007	0	40	34.8	78.3	128	115	0	35	34
2014	9	27	16	48	19	0.814	-0.079	3.802	0.01	0.007	0	40	35.3	78.3	128	115	0	35	33
2014	9	27	16	58	19	0.82	-0.089	3.802	0.01	0.007	0	40	34.8	77.4	128	114	0	35	33
2014	9	27	17	8	19	0.774	-0.095	3.802	0.016	0.013	0	40.4	35.3	78.7	129	115	0	35	33
2014	9	27	17	18	19	0.846	-0.095	3.802	0.01	0.007	0	40.4	35.7	79.1	130	116	0	36	33
2014	9	27	17	28	19	0.801	-0.098	3.802	0.01	0.007	0	40.9	36.5	78.7	131	118	0	36	33
2014	9	27	17	38	19	0.797	-0.085	3.802	0.01	0.007	0	39.1	34	79.1	127	113	0	36	34
2014	9	27	17	48	19	0.797	-0.075	3.806	0.01	0.007	0	40	35.7	74.8	129	116	0	36	33
2014	9	27	17	58	19	0.801	-0.072	3.806	0.01	0.007	0	40	35.3	81.3	129	115	0	36	33
2014	9	27	18	8	19	0.761	-0.062	3.806	0.013	0.01	0	40	35.7	80.4	129	116	0	36	33
2014	9	27	18	18	19	0.814	-0.079	3.806	0.01	0.007	0	40.4	35.7	80	129	116	0	35	33
2014	9	27	18	28	19	0.833	-0.105	3.806	0.01	0.007	0	40.4	35.7	80.8	130	116	0	36	33
2014	9	27	18	38	19	0.827	-0.082	3.806	0.01	0.007	0	40.9	35.7	81.3	130	117	0	35	34
2014	9	27	18	48	19	0.846	-0.079	3.806	0.01	0.007	0	41.3	36.5	81.3	131	118	0	35	33
2014	9	27	18	58	19	0.748	-0.046	3.806	0.01	0.007	0	41.7	37	81.3	132	118	0	35	32
2014	9	27	19	8	19	0.814	-0.108	3.806	0.01	0.007	0	41.7	37	80.8	133	119	0	36	33
2014	9	27	19	18	19	0.807	-0.112	3.806	0.013	0.01	0	41.7	37	80.4	133	120	0	36	34
2014	9	27	19	28	19	0.801	-0.082	3.806	0.01	0.007	0	43	37.8	80.8	135	121	0	35	33
2014	9	27	19	38	19	0.784	-0.072	3.806	0.013	0.01	0	42.6	37.8	80.8	134	120	0	35	32
2014	9	27	19	48	19	0.817	-0.098	3.806	0.013	0.01	0	43	37.8	80.8	136	121	0	36	33
2014	9	27	19	58	19	0.814	-0.118	3.806	0.01	0.007	0	43	38.3	79.6	136	122	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	27	20	8	19	0.817	-0.098	3.806	0.01	0.007	0	43	37.8	80	136	121	0	36	33
2014	9	27	20	18	19	0.817	-0.075	3.806	0.01	0.007	0	43.9	38.7	80	137	123	0	35	33
2014	9	27	20	28	19	0.827	-0.089	3.806	0.01	0.007	0	43	38.3	79.1	136	122	0	36	33
2014	9	27	20	38	19	0.801	-0.085	3.806	0.01	0.007	0	43	38.3	79.6	136	122	0	36	33
2014	9	27	20	48	19	0.83	-0.079	3.806	0.01	0.007	0	43	38.3	80	136	122	0	36	33
2014	9	27	20	58	19	0.774	-0.102	3.806	0.013	0.01	0	43.4	37.4	79.6	136	121	0	35	34
2014	9	27	21	8	19	0.81	-0.098	3.806	0.01	0.007	0	43.4	37.8	79.6	136	122	0	35	34
2014	9	27	21	18	19	0.837	-0.082	3.806	0.01	0.007	0	43	37.4	79.6	135	121	0	35	34
2014	9	27	21	28	19	0.804	-0.056	3.806	0.01	0.007	0	43	37.8	80	135	121	0	35	33
2014	9	27	21	38	19	0.794	-0.089	3.806	0.01	0.007	0	43	37.8	79.1	136	122	0	36	34
2014	9	27	21	48	19	0.827	-0.118	3.806	0.013	0.01	0	43.4	37.8	79.1	136	122	0	35	34
2014	9	27	21	58	19	0.827	-0.102	3.806	0.013	0.01	0	43	38.3	79.1	136	122	0	36	33
2014	9	27	22	8	19	0.817	-0.118	3.806	0.01	0.007	0	43	38.3	78.7	136	122	0	36	33
2014	9	27	22	18	19	0.784	-0.085	3.806	0.01	0.007	0	43.4	38.3	79.1	136	122	0	35	33
2014	9	27	22	28	19	0.833	-0.075	3.806	0.013	0.01	0	43	37.8	79.1	135	121	0	35	33
2014	9	27	22	38	19	0.81	-0.089	3.806	0.01	0.007	0	43	38.3	79.6	136	122	0	36	33
2014	9	27	22	48	19	0.787	-0.089	3.806	0.01	0.007	0	43.4	38.3	78.7	136	122	0	35	33
2014	9	27	22	58	19	0.794	-0.092	3.809	0.01	0.007	0	43	37.4	79.1	135	121	0	35	34
2014	9	27	23	8	19	0.768	-0.075	3.809	0.013	0.01	0	43	37.8	79.1	136	122	0	36	34
2014	9	27	23	18	19	0.814	-0.075	3.809	0.013	0.01	0	42.6	37.4	78.7	135	121	0	36	34
2014	9	27	23	28	19	0.817	-0.062	3.809	0.013	0.01	0	43.4	37.8	79.1	136	121	0	35	33
2014	9	27	23	38	19	0.817	-0.105	3.809	0.01	0.007	0	43.4	38.3	78.7	136	122	0	35	33
2014	9	27	23	48	19	0.82	-0.075	3.809	0.013	0.01	0	43	37.8	78.3	136	121	0	36	33
2014	9	27	23	58	19	0.833	-0.135	3.809	0.013	0.01	0	42.6	37.8	78.7	135	121	0	36	33
2014	9	28	0	8	19	0.817	-0.095	3.809	0.013	0.01	0	42.1	37.8	78.3	135	121	0	37	33
2014	9	28	0	18	19	0.814	-0.092	3.809	0.013	0.01	0	43	37.8	77.8	135	121	0	35	33
2014	9	28	0	28	19	0.784	-0.062	3.809	0.016	0.013	0	43	37	77.8	135	120	0	35	34
2014	9	28	0	38	19	0.833	-0.085	3.809	0.01	0.007	0	43	37.4	77.4	135	121	0	35	34
2014	9	28	0	48	19	0.781	-0.066	3.809	0.016	0.013	0	42.6	37.4	77.4	135	121	0	36	34
2014	9	28	0	58	19	0.807	-0.095	3.809	0.013	0.01	0	42.6	37.8	77	135	121	0	36	33
2014	9	28	1	8	19	0.81	-0.072	3.809	0.01	0.007	0	43	37.8	77	136	121	0	36	33
2014	9	28	1	18	19	0.81	-0.059	3.809	0.013	0.01	0	42.1	37	77.8	134	119	0	36	33
2014	9	28	1	28	19	0.814	-0.082	3.809	0.016	0.016	0	43	37	77	135	120	0	35	34
2014	9	28	1	38	19	0.837	-0.115	3.809	0.013	0.01	0	43	37.8	77	136	121	0	36	33
2014	9	28	1	48	19	0.794	-0.075	3.809	0.016	0.016	0	43.4	38.3	77	136	122	0	35	33
2014	9	28	1	58	19	0.774	-0.069	3.809	0.013	0.01	0	43.4	38.3	77	137	122	0	36	33
2014	9	28	2	8	19	0.778	-0.095	3.809	0.01	0.007	0	43	37.8	76.1	136	121	0	36	33
2014	9	28	2	18	19	0.833	-0.095	3.809	0.01	0.007	0	43.4	38.3	76.1	136	122	0	35	33
2014	9	28	2	28	19	0.814	-0.082	3.812	0.013	0.01	0	43	37.8	76.1	136	122	0	36	34
2014	9	28	2	38	19	0.787	-0.072	3.812	0.016	0.013	0	43	38.3	75.3	136	122	0	36	33
2014	9	28	2	48	19	0.781	-0.089	3.812	0.01	0.007	0	43	37.8	76.1	135	121	0	35	33
2014	9	28	2	58	19	0.801	-0.089	3.812	0.01	0.007	0	43	37.4	75.7	136	121	0	36	34
2014	9	28	3	8	19	0.807	-0.112	3.812	0.013	0.01	0	42.6	37.8	75.7	135	121	0	36	33
2014	9	28	3	18	19	0.81	-0.102	3.812	0.01	0.007	0	43	37.8	75.3	136	121	0	36	33
2014	9	28	3	28	19	0.791	-0.072	3.816	0.01	0.007	0	43	37.8	75.7	135	121	0	35	33
2014	9	28	3	38	19	0.804	-0.108	3.816	0.016	0.016	0	42.6	37.8	75.3	135	121	0	36	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	3	48	19	0.804	-0.089	3.819	0.01	0.007	0	42.6	37	75.7	135	120	0	36	34
2014	9	28	3	58	19	0.774	-0.092	3.819	0.013	0.01	0	42.1	37.4	75.7	135	120	0	37	33
2014	9	28	4	8	19	0.82	-0.089	3.819	0.01	0.007	0	42.1	37.4	76.1	134	120	0	36	33
2014	9	28	4	18	19	0.787	-0.072	3.822	0.013	0.01	0	42.1	37.4	75.7	134	120	0	36	33
2014	9	28	4	28	19	0.817	-0.089	3.822	0.01	0.007	0	42.1	36.5	75.7	133	119	0	35	34
2014	9	28	4	38	19	0.863	-0.105	3.822	0.01	0.007	0	41.7	36.5	75.7	132	118	0	35	33
2014	9	28	4	48	19	0.82	-0.075	3.822	0.013	0.01	0	41.7	36.5	76.1	132	118	0	35	33
2014	9	28	4	58	19	0.801	-0.075	3.822	0.01	0.007	0	41.3	36.5	76.1	132	118	0	36	33
2014	9	28	5	8	19	0.814	-0.056	3.822	0.01	0.007	0	41.3	36.1	76.1	132	117	0	36	33
2014	9	28	5	18	19	0.794	-0.138	3.822	0.01	0.007	0	40.9	36.1	76.1	131	117	0	36	33
2014	9	28	5	28	19	0.82	-0.089	3.822	0.013	0.01	0	40.4	35.7	77	130	116	0	36	33
2014	9	28	5	38	19	0.84	-0.102	3.822	0.01	0.007	0	40.4	35.7	77	130	116	0	36	33
2014	9	28	5	48	19	0.801	-0.085	3.822	0.01	0.007	0	40.9	35.7	76.5	130	116	0	35	33
2014	9	28	5	58	19	0.764	-0.082	3.822	0.016	0.013	0	40.9	35.3	77	130	116	0	35	34
2014	9	28	6	8	19	0.817	-0.089	3.822	0.01	0.007	0	40.4	35.3	77.4	130	116	0	36	34
2014	9	28	6	18	19	0.804	-0.072	3.822	0.01	0.007	0	40.9	35.3	77.4	130	115	0	35	33
2014	9	28	6	28	19	0.791	-0.089	3.822	0.01	0.007	0	40.4	35.7	77.4	130	116	0	36	33
2014	9	28	6	38	19	0.755	-0.079	3.822	0.013	0.01	0	40	35.3	74	129	115	0	36	33
2014	9	28	6	48	19	0.817	-0.105	3.825	0.013	0.01	0	40	34.4	77.8	129	114	0	36	34
2014	9	28	6	58	19	0.784	-0.105	3.825	0.01	0.007	0	40.4	34.4	78.3	129	114	0	35	34
2014	9	28	7	8	19	0.787	-0.046	3.825	0.01	0.007	0	39.6	33.5	78.3	127	112	0	35	34
2014	9	28	7	18	19	0.814	-0.089	3.825	0.016	0.013	0	38.7	33.5	78.3	126	112	0	36	34
2014	9	28	7	28	19	0.771	-0.082	3.825	0.01	0.007	0	38.7	33.1	77.4	126	111	0	36	34
2014	9	28	7	38	19	0.791	-0.092	3.825	0.01	0.007	0	38.7	33.1	78.3	126	111	0	36	34
2014	9	28	7	48	19	0.797	-0.098	3.825	0.016	0.013	0	38.3	33.5	79.1	125	111	0	36	33
2014	9	28	7	58	19	0.827	-0.089	3.825	0.013	0.01	0	38.3	32.7	79.1	125	110	0	36	34
2014	9	28	8	8	19	0.784	-0.092	3.825	0.013	0.01	0	38.3	33.1	77	125	111	0	36	34
2014	9	28	8	18	19	0.784	-0.105	3.825	0.01	0.007	0	37.4	32.3	78.7	123	109	0	36	34
2014	9	28	8	28	19	0.814	-0.105	3.825	0.01	0.007	0	37.8	33.1	77.8	124	110	0	36	33
2014	9	28	8	38	19	0.82	-0.105	3.825	0.016	0.013	0	38.3	33.1	77.8	125	111	0	36	34
2014	9	28	8	48	19	0.801	-0.092	3.825	0.013	0.01	0	37.4	32.3	79.1	123	109	0	36	34
2014	9	28	8	58	19	0.83	-0.092	3.825	0.01	0.007	0	37	31.8	78.7	122	108	0	36	34
2014	9	28	9	8	19	0.781	-0.105	3.825	0.01	0.007	0	37	32.3	79.6	122	108	0	36	33
2014	9	28	9	18	19	0.801	-0.089	3.825	0.016	0.013	0	36.5	32.3	79.6	122	108	0	37	33
2014	9	28	9	28	19	0.83	-0.092	3.825	0.01	0.007	0	37	32.3	78.7	122	109	0	36	34
2014	9	28	9	38	19	0.81	-0.105	3.825	0.01	0.007	0	37.4	32.7	78.7	123	109	0	36	33
2014	9	28	9	48	19	0.774	-0.098	3.829	0.016	0.013	0	37	32.3	79.1	123	109	0	37	34
2014	9	28	9	58	19	0.787	-0.046	3.825	0.01	0.007	0	37	32.3	78.7	122	108	0	36	33
2014	9	28	10	8	19	0.817	-0.092	3.829	0.01	0.007	0	36.5	31.8	78.7	121	108	0	36	34
2014	9	28	10	18	19	0.833	-0.108	3.825	0.01	0.007	0	37	31.8	78.7	122	108	0	36	34
2014	9	28	10	28	19	0.791	-0.089	3.829	0.01	0.007	0	37	31.4	79.1	121	107	0	35	34
2014	9	28	10	38	19	0.787	-0.095	3.825	0.01	0.007	0	37	32.3	78.7	122	108	0	36	33
2014	9	28	10	48	19	0.774	-0.072	3.829	0.01	0.007	0	37	31.8	79.6	122	108	0	36	34
2014	9	28	10	58	19	0.82	-0.121	3.829	0.01	0.007	0	38.7	33.5	78.7	125	111	0	35	33
2014	9	28	11	8	19	0.764	-0.092	3.829	0.01	0.007	0	37	32.3	78.7	122	108	0	36	33
2014	9	28	11	18	19	0.827	-0.102	3.829	0.013	0.01	0	36.5	31.4	77.8	121	107	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	11	28	19	0.761	-0.118	3.829	0.01	0.007	0	37.4	32.7	76.5	123	109	0	36	33
2014	9	28	11	38	19	0.804	-0.118	3.829	0.013	0.01	0	37	31.8	76.1	122	108	0	36	34
2014	9	28	11	48	19	0.846	-0.098	3.829	0.01	0.007	0	37.4	32.3	77.8	122	108	0	35	33
2014	9	28	11	58	19	0.823	-0.089	3.825	0.01	0.007	0	37	31.8	74.4	122	108	0	36	34
2014	9	28	12	8	19	0.791	-0.118	3.825	0.01	0.007	0	37.4	32.3	74	122	108	0	35	33
2014	9	28	12	18	19	0.774	-0.118	3.825	0.01	0.007	0	36.1	31.4	75.7	120	107	0	36	34
2014	9	28	12	28	19	0.833	-0.102	3.825	0.01	0.007	0	36.5	31.4	68.8	121	107	0	36	34
2014	9	28	12	38	19	0.797	-0.092	3.829	0.01	0.007	0	36.1	31	74.8	120	106	0	36	34
2014	9	28	12	48	19	0.797	-0.066	3.825	0.01	0.007	0	37	32.3	69.2	122	108	0	36	33
2014	9	28	12	58	19	0.778	-0.072	3.819	0.013	0.01	0	37.4	31.8	54.2	122	108	0	35	34
2014	9	28	13	8	19	0.781	-0.066	3.825	0.016	0.013	0	37	32.3	65.4	122	108	0	36	33
2014	9	28	13	18	19	0.778	-0.066	3.819	0.013	0.01	0	36.5	31.4	55	121	107	0	36	34
2014	9	28	13	28	19	0.755	-0.075	3.819	0.01	0.007	0	37.8	32.7	57.2	123	109	0	35	33
2014	9	28	13	38	19	0.751	-0.102	3.819	0.01	0.007	0	37.8	32.7	53.8	123	109	0	35	33
2014	9	28	13	48	19	0.794	-0.049	3.819	0.01	0.007	0	37.4	32.7	59.3	123	109	0	36	33
2014	9	28	13	58	19	0.764	-0.108	3.819	0.013	0.01	0	37.4	32.7	55.9	123	110	0	36	34
2014	9	28	14	8	19	0.794	-0.089	3.816	0.01	0.007	0	37.4	32.3	52.9	123	109	0	36	34
2014	9	28	14	18	19	0.82	-0.115	3.819	0.01	0.007	0	38.3	32.7	65.4	124	110	0	35	34
2014	9	28	14	28	19	0.801	-0.043	3.816	0.01	0.007	0	37	32.3	58.5	122	109	0	36	34
2014	9	28	14	38	19	0.768	-0.059	3.819	0.01	0.007	0	36.1	31.4	64.5	120	106	0	36	33
2014	9	28	14	48	19	0.748	-0.082	3.816	0.01	0.007	0	36.1	31	58	120	106	0	36	34
2014	9	28	14	58	19	0.784	-0.085	3.819	0.01	0.007	0	36.1	31	64.5	119	106	0	35	34
2014	9	28	15	8	19	0.797	-0.075	3.816	0.013	0.01	0	36.1	31.4	63.6	120	106	0	36	33
2014	9	28	15	18	19	0.801	-0.095	3.816	0.01	0.007	0	37.4	32.7	62.4	123	109	0	36	33
2014	9	28	15	28	19	0.83	-0.089	3.816	0.01	0.007	0	37.4	32.7	57.2	123	109	0	36	33
2014	9	28	15	38	19	0.774	-0.052	3.812	0.013	0.01	0	37.4	33.1	56.3	123	110	0	36	33
2014	9	28	15	48	19	0.807	-0.095	3.816	0.013	0.01	0	37.4	32.7	65.8	123	109	0	36	33
2014	9	28	15	58	19	0.794	-0.072	3.816	0.01	0.007	0	37	31.4	73.5	122	107	0	36	34
2014	9	28	16	8	19	0.791	-0.069	3.816	0.013	0.01	0	36.5	31.8	71.8	121	107	0	36	33
2014	9	28	16	18	19	0.817	-0.102	3.819	0.013	0.01	0	36.1	31.4	74.4	120	106	0	36	33
2014	9	28	16	28	19	0.846	-0.115	3.816	0.013	0.01	0	37	31.8	68.8	121	107	0	35	33
2014	9	28	16	38	19	0.791	-0.095	3.816	0.01	0.007	0	36.5	31.4	73.1	121	107	0	36	34
2014	9	28	16	48	19	0.797	-0.098	3.812	0.013	0.01	0	36.5	31.8	61.1	121	107	0	36	33
2014	9	28	16	58	19	0.794	-0.098	3.816	0.01	0.007	0	37.8	32.3	65.8	123	109	0	35	34
2014	9	28	17	8	19	0.82	-0.082	3.816	0.01	0.007	0	38.3	32.7	71	124	110	0	35	34
2014	9	28	17	18	19	0.758	-0.105	3.816	0.013	0.01	0	38.7	34	74.4	126	112	0	36	33
2014	9	28	17	28	19	0.84	-0.092	3.812	0.016	0.013	0	38.7	34	63.2	125	112	0	35	33
2014	9	28	17	38	19	0.761	-0.066	3.816	0.013	0.01	0	38.7	34	72.7	126	112	0	36	33
2014	9	28	17	48	19	0.774	-0.102	3.816	0.013	0.01	0	38.7	33.1	74.4	126	111	0	36	34
2014	9	28	17	58	19	0.853	-0.098	3.819	0.013	0.01	0	38.7	33.5	74.8	126	112	0	36	34
2014	9	28	18	8	19	0.827	-0.075	3.819	0.013	0.01	0	38.7	33.5	74.4	126	112	0	36	34
2014	9	28	18	18	19	0.778	-0.085	3.816	0.013	0.01	0	39.1	34.8	66.7	127	114	0	36	33
2014	9	28	18	28	19	0.794	-0.092	3.816	0.013	0.01	0	40	34.8	65.8	128	114	0	35	33
2014	9	28	18	38	19	0.791	-0.052	3.816	0.016	0.013	0	40.4	35.7	68.4	130	116	0	36	33
2014	9	28	18	48	19	0.801	-0.095	3.819	0.01	0.007	0	40.9	36.1	72.7	131	117	0	36	33
2014	9	28	18	58	19	0.784	-0.079	3.819	0.01	0.007	0	40	35.3	72.2	129	116	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	28	19	8	19	0.778	-0.121	3.819	0.013	0.01	0	40.4	35.3	74	130	116	0	36	34
2014	9	28	19	18	19	0.807	-0.102	3.819	0.013	0.01	0	40.9	35.7	72.2	131	116	0	36	33
2014	9	28	19	28	19	0.794	-0.082	3.822	0.016	0.016	0	40.9	35.7	72.2	131	117	0	36	34
2014	9	28	19	38	19	0.791	-0.102	3.819	0.01	0.007	0	41.7	37	69.7	133	119	0	36	33
2014	9	28	19	48	19	0.791	-0.095	3.819	0.01	0.007	0	42.1	37	61.5	134	119	0	36	33
2014	9	28	19	58	19	0.83	-0.059	3.822	0.016	0.016	0	41.7	36.5	65.4	133	118	0	36	33
2014	9	28	20	8	19	0.81	-0.062	3.822	0.013	0.01	0	41.3	36.5	67.1	132	118	0	36	33
2014	9	28	20	18	19	0.823	-0.075	3.822	0.013	0.01	0	42.1	37	65.4	133	119	0	35	33
2014	9	28	20	28	19	0.791	-0.066	3.822	0.013	0.01	0	41.7	37	72.2	133	119	0	36	33
2014	9	28	20	38	19	0.797	-0.108	3.822	0.013	0.01	0	41.3	35.7	72.7	132	117	0	36	34
2014	9	28	20	48	19	0.791	-0.092	3.825	0.016	0.013	0	41.7	36.1	74	133	118	0	36	34
2014	9	28	20	58	19	0.768	-0.062	3.825	0.016	0.016	0	41.7	36.5	74.8	133	119	0	36	34
2014	9	28	21	8	19	0.81	-0.075	3.822	0.013	0.01	0	41.7	37	67.9	133	119	0	36	33
2014	9	28	21	18	19	0.807	-0.085	3.822	0.013	0.01	0	41.7	37	60.6	133	119	0	36	33
2014	9	28	21	28	19	0.768	-0.046	3.822	0.013	0.01	0	42.1	37	60.6	134	120	0	36	34
2014	9	28	21	38	19	0.843	-0.069	3.825	0.01	0.007	0	42.1	37	74.4	134	120	0	36	34
2014	9	28	21	48	19	0.81	-0.112	3.825	0.01	0.007	0	42.1	37	71.4	134	120	0	36	34
2014	9	28	21	58	19	0.784	-0.105	3.825	0.01	0.007	0	41.7	37	75.7	133	119	0	36	33
2014	9	28	22	8	19	0.81	-0.112	3.825	0.01	0.007	0	41.7	36.5	75.3	133	119	0	36	34
2014	9	28	22	18	19	0.853	-0.102	3.825	0.016	0.013	0	42.1	37.4	76.1	133	120	0	35	33
2014	9	28	22	28	19	0.804	-0.075	3.825	0.013	0.01	0	42.1	37	76.1	134	120	0	36	34
2014	9	28	22	38	19	0.807	-0.089	3.825	0.013	0.01	0	42.6	37	77	134	120	0	35	34
2014	9	28	22	48	19	0.794	-0.079	3.829	0.01	0.007	0	42.6	37	76.1	134	120	0	35	34
2014	9	28	22	58	19	0.81	-0.069	3.829	0.013	0.01	0	41.7	37.4	77.8	134	120	0	37	33
2014	9	28	23	8	19	0.856	-0.141	3.829	0.01	0.007	0	41.7	37	77	133	119	0	36	33
2014	9	28	23	18	19	0.794	-0.085	3.829	0.016	0.013	0	42.1	37	77.4	133	119	0	35	33
2014	9	28	23	28	19	0.804	-0.105	3.829	0.01	0.007	0	41.7	37	77.4	133	119	0	36	33
2014	9	28	23	38	19	0.801	-0.112	3.829	0.013	0.01	0	42.1	36.5	77.8	133	119	0	35	34
2014	9	28	23	48	19	0.801	-0.095	3.829	0.01	0.007	0	41.3	36.5	78.7	132	118	0	36	33
2014	9	28	23	58	19	0.833	-0.079	3.829	0.01	0.007	0	41.3	36.1	79.1	132	118	0	36	34
2014	9	29	0	8	19	0.804	-0.059	3.829	0.01	0.007	0	41.3	36.1	78.7	132	118	0	36	34
2014	9	29	0	18	19	0.794	-0.121	3.829	0.013	0.01	0	41.3	37	78.3	132	119	0	36	33
2014	9	29	0	28	19	0.807	-0.082	3.829	0.013	0.01	0	41.7	36.5	77.8	132	118	0	35	33
2014	9	29	0	38	19	0.771	-0.092	3.829	0.01	0.007	0	41.7	36.1	78.3	133	118	0	36	34
2014	9	29	0	48	19	0.761	-0.069	3.829	0.01	0.007	0	42.1	36.5	78.7	133	118	0	35	33
2014	9	29	0	58	19	0.81	-0.089	3.829	0.013	0.01	0	40.9	35.7	78.7	131	117	0	36	34
2014	9	29	1	8	19	0.764	-0.098	3.829	0.013	0.01	0	41.3	36.1	79.6	131	117	0	35	33
2014	9	29	1	18	19	0.791	-0.115	3.829	0.01	0.007	0	40.9	36.1	79.6	131	117	0	36	33
2014	9	29	1	28	19	0.804	-0.069	3.829	0.01	0.007	0	40.9	35.7	79.6	131	117	0	36	34
2014	9	29	1	38	19	0.82	-0.072	3.829	0.013	0.01	0	40.9	35.7	79.1	131	117	0	36	34
2014	9	29	1	48	19	0.768	-0.069	3.829	0.01	0.007	0	40.9	36.1	79.1	131	117	0	36	33
2014	9	29	1	58	19	0.807	-0.105	3.829	0.013	0.01	0	40.9	36.1	79.6	131	117	0	36	33
2014	9	29	2	8	19	0.794	-0.095	3.829	0.013	0.01	0	41.3	36.5	79.1	132	118	0	36	33
2014	9	29	2	18	19	0.791	-0.089	3.829	0.01	0.007	0	41.3	36.1	78.7	131	117	0	35	33
2014	9	29	2	28	19	0.814	-0.072	3.829	0.013	0.01	0	41.3	35.7	79.6	131	117	0	35	34
2014	9	29	2	38	19	0.791	-0.121	3.829	0.01	0.007	0	41.3	35.7	79.6	131	117	0	35	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	2	48	19	0.807	-0.108	3.829	0.016	0.013	0	40.4	35.3	79.6	130	116	0	36	34
2014	9	29	2	58	19	0.794	-0.112	3.829	0.01	0.007	0	40.9	36.1	77.4	131	117	0	36	33
2014	9	29	3	8	19	0.82	-0.069	3.832	0.013	0.01	0	41.3	35.7	80.4	131	117	0	35	34
2014	9	29	3	18	19	0.797	-0.075	3.829	0.01	0.007	0	41.3	36.1	80	132	118	0	36	34
2014	9	29	3	28	19	0.807	-0.043	3.829	0.01	0.007	0	40.9	36.1	80.8	131	117	0	36	33
2014	9	29	3	38	19	0.84	-0.108	3.829	0.01	0.007	0	40.9	35.7	80.4	131	116	0	36	33
2014	9	29	3	48	19	0.781	-0.075	3.829	0.01	0.007	0	40.9	35.7	80	131	117	0	36	34
2014	9	29	3	58	19	0.781	-0.082	3.829	0.013	0.01	0	41.3	36.5	80.8	132	118	0	36	33
2014	9	29	4	8	19	0.817	-0.089	3.829	0.013	0.01	0	41.3	36.1	80	131	117	0	35	33
2014	9	29	4	18	19	0.784	-0.072	3.829	0.013	0.01	0	40.4	35.7	80.4	130	116	0	36	33
2014	9	29	4	28	19	0.83	-0.082	3.832	0.01	0.007	0	40.4	35.3	80.8	130	116	0	36	34
2014	9	29	4	38	19	0.814	-0.092	3.829	0.01	0.007	0	40.4	35.3	81.7	130	115	0	36	33
2014	9	29	4	48	19	0.784	-0.072	3.829	0.01	0.007	0	40.4	35.3	79.1	130	116	0	36	34
2014	9	29	4	58	19	0.768	-0.089	3.829	0.013	0.01	0	40.4	35.7	80.8	130	116	0	36	33
2014	9	29	5	8	19	0.817	-0.049	3.829	0.013	0.01	0	40.4	35.7	80.8	130	116	0	36	33
2014	9	29	5	18	19	0.787	-0.095	3.829	0.013	0.01	0	40	34.8	80	129	115	0	36	34
2014	9	29	5	28	19	0.794	-0.102	3.829	0.013	0.01	0	39.6	34	80.8	128	113	0	36	34
2014	9	29	5	38	19	0.801	-0.085	3.829	0.01	0.007	0	39.1	34	80.4	127	113	0	36	34
2014	9	29	5	48	19	0.833	-0.066	3.829	0.01	0.007	0	39.6	34.4	80.4	128	114	0	36	34
2014	9	29	5	58	19	0.768	-0.092	3.829	0.016	0.013	0	39.1	34.4	78.7	127	113	0	36	33
2014	9	29	6	8	19	0.843	-0.089	3.829	0.013	0.01	0	38.7	33.5	80.4	126	112	0	36	34
2014	9	29	6	18	19	0.784	-0.059	3.829	0.013	0.01	0	38.3	33.5	80.8	125	111	0	36	33
2014	9	29	6	28	19	0.827	-0.102	3.829	0.01	0.007	0	37.8	32.7	80.8	124	110	0	36	34
2014	9	29	6	38	19	0.814	-0.092	3.829	0.01	0.007	0	37.8	32.7	80.8	124	109	0	36	33
2014	9	29	6	48	19	0.846	-0.095	3.829	0.01	0.007	0	37.8	32.7	80.8	123	109	0	35	33
2014	9	29	6	58	19	0.807	-0.098	3.829	0.01	0.007	0	37	32.3	80.8	122	109	0	36	34
2014	9	29	7	8	19	0.797	-0.069	3.829	0.016	0.013	0	36.5	31.8	80.8	121	107	0	36	33
2014	9	29	7	18	19	0.755	-0.069	3.829	0.01	0.007	0	36.5	31.4	80.4	121	107	0	36	34
2014	9	29	7	28	19	0.797	-0.095	3.829	0.013	0.01	0	35.7	31.4	80.4	120	107	0	37	34
2014	9	29	7	38	19	0.83	-0.089	3.829	0.013	0.01	0	36.5	31.4	80.4	121	107	0	36	34
2014	9	29	7	48	19	0.804	-0.085	3.829	0.01	0.007	0	36.1	31	80	120	106	0	36	34
2014	9	29	7	58	19	0.771	-0.052	3.829	0.01	0.007	0	35.7	31	80.8	119	106	0	36	34
2014	9	29	8	8	19	0.768	-0.089	3.829	0.01	0.007	0	36.1	31	80	119	106	0	35	34
2014	9	29	8	18	19	0.814	-0.089	3.829	0.01	0.007	0	35.3	31	78.7	118	105	0	36	33
2014	9	29	8	28	19	0.791	-0.089	3.829	0.01	0.007	0	35.3	30.5	80	118	105	0	36	34
2014	9	29	8	38	19	0.755	-0.075	3.829	0.013	0.01	0	35.3	30.1	80.4	118	104	0	36	34
2014	9	29	8	48	19	0.807	-0.105	3.829	0.016	0.013	0	34.4	29.7	79.6	116	103	0	36	34
2014	9	29	8	58	19	0.771	-0.052	3.829	0.01	0.007	0	34.4	29.2	79.6	116	102	0	36	34
2014	9	29	9	8	19	0.784	-0.075	3.829	0.013	0.01	0	34.4	30.1	80	116	103	0	36	33
2014	9	29	9	18	19	0.814	-0.056	3.832	0.01	0.007	0	35.3	30.5	80	118	104	0	36	33
2014	9	29	9	28	19	0.784	-0.082	3.832	0.013	0.01	0	34.4	29.7	79.6	116	103	0	36	34
2014	9	29	9	38	19	0.807	-0.059	3.829	0.016	0.013	0	34.8	29.7	72.7	117	103	0	36	34
2014	9	29	9	48	19	0.791	-0.072	3.832	0.01	0.007	0	34.8	30.5	80.4	118	105	0	37	34
2014	9	29	9	58	19	0.804	-0.062	3.832	0.013	0.01	0	34.4	29.7	80.4	116	103	0	36	34
2014	9	29	10	8	19	0.797	-0.082	3.832	0.016	0.013	0	36.5	31.4	80.8	120	107	0	35	34
2014	9	29	10	18	19	0.856	-0.102	3.832	0.01	0.007	0	35.7	31	79.1	118	105	0	35	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	10	28	19	0.748	-0.075	3.832	0.01	0.007	0	34.8	30.1	79.1	117	104	0	36	34
2014	9	29	10	38	19	0.784	-0.128	3.832	0.01	0.007	0	35.7	30.5	79.6	119	105	0	36	34
2014	9	29	10	48	19	0.774	-0.089	3.832	0.016	0.013	0	35.7	31.4	80	119	106	0	36	33
2014	9	29	10	58	19	0.81	-0.105	3.832	0.01	0.007	0	34.8	30.1	80	116	104	0	35	34
2014	9	29	11	8	19	0.794	-0.112	3.832	0.01	0.007	0	34	29.2	80	115	102	0	36	34
2014	9	29	11	18	19	0.755	-0.059	3.832	0.01	0.007	0	34.8	30.1	80.4	117	103	0	36	33
2014	9	29	11	28	19	0.804	-0.105	3.832	0.01	0.007	0	35.3	30.5	80	118	105	0	36	34
2014	9	29	11	38	19	0.771	-0.095	3.832	0.01	0.007	0	35.3	30.1	77	117	104	0	35	34
2014	9	29	11	48	19	0.771	-0.075	3.832	0.013	0.01	0	35.3	30.5	79.1	118	104	0	36	33
2014	9	29	11	58	19	0.82	-0.075	3.832	0.01	0.007	0	34.8	30.1	80.4	117	103	0	36	33
2014	9	29	12	8	19	0.781	-0.082	3.832	0.01	0.007	0	35.7	30.5	78.3	119	105	0	36	34
2014	9	29	12	18	19	0.755	-0.059	3.832	0.01	0.007	0	36.1	31.4	76.5	120	106	0	36	33
2014	9	29	12	28	19	0.774	-0.092	3.832	0.01	0.007	0	35.3	30.5	80	118	105	0	36	34
2014	9	29	12	38	19	0.807	-0.105	3.832	0.013	0.01	0	35.3	30.5	80.4	118	105	0	36	34
2014	9	29	12	48	19	0.768	-0.046	3.832	0.013	0.01	0	35.3	30.5	80.4	118	105	0	36	34
2014	9	29	12	58	19	0.804	-0.115	3.832	0.01	0.007	0	34.8	30.5	80.4	117	104	0	36	33
2014	9	29	13	8	19	0.804	-0.075	3.832	0.01	0.007	0	35.3	30.5	79.1	118	104	0	36	33
2014	9	29	13	18	19	0.791	-0.075	3.832	0.01	0.007	0	34.8	30.1	79.1	116	104	0	35	34
2014	9	29	13	28	19	0.774	-0.069	3.832	0.016	0.013	0	35.3	30.5	80	118	105	0	36	34
2014	9	29	13	38	19	0.807	-0.059	3.832	0.01	0.007	0	35.3	30.5	79.1	117	104	0	35	33
2014	9	29	13	48	19	0.784	-0.095	3.832	0.01	0.007	0	35.3	30.1	77.4	117	103	0	35	33
2014	9	29	13	58	19	0.774	-0.066	3.829	0.01	0.007	0	35.3	31	79.1	118	105	0	36	33
2014	9	29	14	8	19	0.801	-0.085	3.832	0.01	0.007	0	34.8	30.5	79.1	117	104	0	36	33
2014	9	29	14	18	19	0.794	-0.075	3.829	0.01	0.007	0	36.1	30.5	78.7	119	105	0	35	34
2014	9	29	14	28	19	0.797	-0.115	3.829	0.016	0.013	0	35.3	31	78.7	118	105	0	36	33
2014	9	29	14	38	19	0.768	-0.095	3.829	0.01	0.007	0	35.7	31	78.7	119	106	0	36	34
2014	9	29	14	48	19	0.804	-0.105	3.829	0.016	0.013	0	35.7	30.5	78.3	119	105	0	36	34
2014	9	29	14	58	19	0.761	-0.108	3.829	0.01	0.007	0	35.7	31	78.3	118	106	0	35	34
2014	9	29	15	8	19	0.797	-0.089	3.829	0.01	0.007	0	35.7	31	78.7	119	106	0	36	34
2014	9	29	15	18	19	0.82	-0.102	3.829	0.01	0.007	0	35.3	30.5	78.3	118	105	0	36	34
2014	9	29	15	28	19	0.791	-0.089	3.829	0.01	0.007	0	35.3	30.5	78.3	118	105	0	36	34
2014	9	29	15	38	19	0.797	-0.082	3.829	0.01	0.007	0	35.7	31.4	78.3	119	106	0	36	33
2014	9	29	15	48	19	0.758	-0.095	3.829	0.013	0.01	0	35.7	31.4	77.4	119	106	0	36	33
2014	9	29	15	58	19	0.787	-0.108	3.825	0.01	0.007	0	37	31.4	77.4	121	107	0	35	34
2014	9	29	16	8	19	0.814	-0.072	3.825	0.01	0.007	0	36.1	31.4	77.4	120	107	0	36	34
2014	9	29	16	18	19	0.807	-0.108	3.829	0.01	0.007	0	36.5	31.4	77	120	106	0	35	33
2014	9	29	16	28	19	0.794	-0.105	3.825	0.01	0.007	0	36.5	31.8	77.4	121	107	0	36	33
2014	9	29	16	38	19	0.784	-0.102	3.825	0.01	0.007	0	36.1	31.8	77	120	107	0	36	33
2014	9	29	16	48	19	0.817	-0.128	3.825	0.01	0.007	0	37	32.7	77	122	108	0	36	32
2014	9	29	16	58	19	0.781	-0.089	3.825	0.01	0.007	0	37	31.8	75.7	122	108	0	36	34
2014	9	29	17	8	19	0.823	-0.102	3.825	0.013	0.01	0	37.4	31.8	77	122	108	0	35	34
2014	9	29	17	18	19	0.787	-0.089	3.825	0.016	0.013	0	37.4	32.7	76.5	123	109	0	36	33
2014	9	29	17	28	19	0.794	-0.075	3.825	0.016	0.013	0	37	31.8	75.3	122	108	0	36	34
2014	9	29	17	38	19	0.814	-0.115	3.825	0.013	0.01	0	37.4	32.3	76.5	123	109	0	36	34
2014	9	29	17	48	19	0.761	-0.118	3.825	0.01	0.007	0	37.8	32.7	76.1	123	109	0	35	33
2014	9	29	17	58	19	0.807	-0.082	3.825	0.013	0.01	0	37.4	32.3	77	123	109	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	29	18	8	19	0.801	-0.112	3.825	0.01	0.007	0	37.8	32.7	76.5	123	110	0	35	34
2014	9	29	18	18	19	0.794	-0.089	3.825	0.01	0.007	0	37.8	32.7	76.1	124	110	0	36	34
2014	9	29	18	28	19	0.827	-0.095	3.825	0.01	0.007	0	37.8	33.1	77	124	110	0	36	33
2014	9	29	18	38	19	0.774	-0.085	3.825	0.01	0.007	0	39.1	33.5	77	126	112	0	35	34
2014	9	29	18	48	19	0.781	-0.056	3.825	0.013	0.01	0	38.3	33.5	77.4	125	112	0	36	34
2014	9	29	18	58	19	0.787	-0.082	3.825	0.013	0.01	0	38.3	33.5	77	125	112	0	36	34
2014	9	29	19	8	19	0.801	-0.102	3.825	0.01	0.007	0	39.6	34.4	76.5	128	114	0	36	34
2014	9	29	19	18	19	0.823	-0.082	3.825	0.013	0.01	0	40.9	35.7	77	130	116	0	35	33
2014	9	29	19	28	19	0.837	-0.118	3.825	0.013	0.01	0	40	35.3	77	129	115	0	36	33
2014	9	29	19	38	19	0.787	-0.075	3.825	0.01	0.007	0	40.4	35.7	77.4	130	116	0	36	33
2014	9	29	19	48	19	0.787	-0.092	3.825	0.01	0.007	0	40.4	36.1	78.3	130	117	0	36	33
2014	9	29	19	58	19	0.817	-0.105	3.825	0.01	0.007	0	40.9	35.7	77.8	131	117	0	36	34
2014	9	29	20	8	19	0.82	-0.095	3.825	0.01	0.007	0	41.7	36.5	77.4	132	118	0	35	33
2014	9	29	20	18	19	0.781	-0.089	3.825	0.01	0.007	0	41.7	37	76.1	133	120	0	36	34
2014	9	29	20	28	19	0.801	-0.105	3.825	0.013	0.01	0	41.7	36.1	77.4	132	118	0	35	34
2014	9	29	20	38	19	0.787	-0.082	3.825	0.01	0.007	0	41.3	36.1	77.4	132	118	0	36	34
2014	9	29	20	48	19	0.807	-0.112	3.825	0.013	0.01	0	41.3	36.5	77.4	132	118	0	36	33
2014	9	29	20	58	19	0.787	-0.105	3.825	0.01	0.007	0	41.7	36.5	77.4	132	119	0	35	34
2014	9	29	21	8	19	0.833	-0.085	3.825	0.01	0.007	0	41.3	36.5	77.4	132	119	0	36	34
2014	9	29	21	18	19	0.804	-0.098	3.825	0.01	0.007	0	42.1	37	77.4	133	119	0	35	33
2014	9	29	21	28	19	0.797	-0.105	3.825	0.013	0.01	0	41.7	36.5	77.4	132	119	0	35	34
2014	9	29	21	38	19	0.817	-0.075	3.825	0.01	0.007	0	41.7	36.1	77.4	132	118	0	35	34
2014	9	29	21	48	19	0.764	-0.092	3.829	0.01	0.007	0	41.3	36.5	78.3	132	118	0	36	33
2014	9	29	21	58	19	0.787	-0.089	3.825	0.01	0.007	0	41.7	36.5	78.3	133	119	0	36	34
2014	9	29	22	8	19	0.797	-0.098	3.829	0.013	0.01	0	40.9	36.1	78.7	131	117	0	36	33
2014	9	29	22	18	19	0.787	-0.105	3.829	0.016	0.013	0	41.3	36.5	78.7	132	118	0	36	33
2014	9	29	22	28	19	0.787	-0.079	3.829	0.01	0.007	0	44.7	39.6	76.5	139	125	0	35	33
2014	9	29	22	38	19	0.823	-0.082	3.829	0.013	0.01	0	42.6	37.8	78.3	135	121	0	36	33
2014	9	29	22	48	19	0.787	-0.062	3.829	0.013	0.01	0	42.1	37.8	77.4	134	121	0	36	33
2014	9	29	22	58	19	0.804	-0.105	3.829	0.013	0.01	0	42.1	37.4	78.3	134	120	0	36	33
2014	9	29	23	8	19	0.82	-0.062	3.829	0.013	0.01	0	42.6	37.4	79.1	134	120	0	35	33
2014	9	29	23	18	19	0.797	-0.075	3.829	0.013	0.01	0	41.3	36.5	78.7	132	118	0	36	33
2014	9	29	23	28	19	0.801	-0.089	3.829	0.013	0.01	0	41.3	36.5	78.3	133	119	0	37	34
2014	9	29	23	38	19	0.814	-0.089	3.829	0.013	0.01	0	41.3	36.5	74.4	132	118	0	36	33
2014	9	29	23	48	19	0.764	-0.082	3.829	0.01	0.007	0	41.3	36.5	79.6	132	118	0	36	33
2014	9	29	23	58	19	0.794	-0.075	3.829	0.01	0.007	0	41.3	36.1	78.7	132	118	0	36	34
2014	9	30	0	8	19	0.83	-0.118	3.829	0.01	0.007	0	42.6	37.4	74.8	135	120	0	36	33
2014	9	30	0	18	19	0.771	-0.059	3.829	0.01	0.007	0	41.7	37.4	78.7	133	120	0	36	33
2014	9	30	0	28	19	0.794	-0.102	3.829	0.013	0.01	0	41.7	36.5	78.7	133	119	0	36	34
2014	9	30	0	38	19	0.778	-0.062	3.829	0.01	0.007	0	40.9	36.1	79.6	131	117	0	36	33
2014	9	30	0	48	19	0.807	-0.092	3.829	0.01	0.007	0	40.9	36.1	71	131	117	0	36	33
2014	9	30	0	58	19	0.801	-0.072	3.829	0.01	0.007	0	41.3	36.1	79.1	132	117	0	36	33
2014	9	30	1	8	19	0.804	-0.085	3.829	0.013	0.01	0	41.3	36.1	79.1	132	118	0	36	34
2014	9	30	1	18	19	0.797	-0.072	3.829	0.016	0.013	0	40.9	35.7	79.6	131	117	0	36	34
2014	9	30	1	28	19	0.807	-0.056	3.829	0.01	0.007	0	40.9	35.7	79.6	131	117	0	36	34
2014	9	30	1	38	19	0.823	-0.092	3.829	0.01	0.007	0	40.4	35.7	78.7	130	117	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	1	48	19	0.814	-0.089	3.829	0.01	0.007	0	41.3	35.3	79.1	131	116	0	35	34
2014	9	30	1	58	19	0.768	-0.072	3.829	0.016	0.013	0	40.9	36.1	77.8	131	117	0	36	33
2014	9	30	2	8	19	0.781	-0.079	3.829	0.013	0.01	0	40.9	35.7	79.1	131	117	0	36	34
2014	9	30	2	18	19	0.794	-0.072	3.829	0.01	0.007	0	41.3	35.7	78.7	131	117	0	35	34
2014	9	30	2	28	19	0.794	-0.079	3.829	0.016	0.013	0	40.4	35.7	79.1	130	117	0	36	34
2014	9	30	2	38	19	0.784	-0.098	3.829	0.013	0.01	0	40.9	35.7	79.6	131	116	0	36	33
2014	9	30	2	48	19	0.827	-0.092	3.829	0.013	0.01	0	41.3	35.7	79.1	131	117	0	35	34
2014	9	30	2	58	19	0.81	-0.102	3.829	0.01	0.007	0	40.9	35.3	78.7	130	116	0	35	34
2014	9	30	3	8	19	0.83	-0.089	3.829	0.01	0.007	0	40.4	35.3	79.6	130	116	0	36	34
2014	9	30	3	18	19	0.781	-0.075	3.829	0.01	0.007	0	40.4	34.8	79.1	129	115	0	35	34
2014	9	30	3	28	19	0.774	-0.108	3.829	0.01	0.007	0	40	35.3	78.7	129	115	0	36	33
2014	9	30	3	38	19	0.84	-0.082	3.829	0.01	0.007	0	40	34.8	79.1	129	115	0	36	34
2014	9	30	3	48	19	0.797	-0.072	3.829	0.01	0.007	0	40	34.8	78.7	129	115	0	36	34
2014	9	30	3	58	19	0.801	-0.082	3.829	0.01	0.007	0	40.4	35.7	78.7	130	116	0	36	33
2014	9	30	4	8	19	0.761	-0.102	3.829	0.013	0.01	0	40.4	35.3	78.3	130	116	0	36	34
2014	9	30	4	18	19	0.794	-0.105	3.829	0.013	0.01	0	40	35.3	77.8	129	115	0	36	33
2014	9	30	4	28	19	0.827	-0.089	3.829	0.01	0.007	0	40.4	35.7	77.8	130	116	0	36	33
2014	9	30	4	38	19	0.791	-0.098	3.829	0.013	0.01	0	39.6	34.4	78.7	128	114	0	36	34
2014	9	30	4	48	19	0.797	-0.072	3.829	0.01	0.007	0	39.6	34.8	77.8	128	114	0	36	33
2014	9	30	4	58	19	0.761	-0.112	3.829	0.01	0.007	0	39.6	34.8	78.3	128	115	0	36	34
2014	9	30	5	8	19	0.797	-0.095	3.829	0.01	0.007	0	39.1	34	77.8	127	113	0	36	34
2014	9	30	5	18	19	0.771	-0.095	3.829	0.01	0.007	0	40	34.8	77.8	129	115	0	36	34
2014	9	30	5	28	19	0.764	-0.112	3.829	0.016	0.013	0	39.1	34.4	78.3	128	114	0	37	34
2014	9	30	5	38	19	0.814	-0.072	3.829	0.01	0.007	0	39.6	34	77.8	127	113	0	35	34
2014	9	30	5	48	19	0.771	-0.102	3.829	0.013	0.01	0	38.7	33.5	77.8	126	112	0	36	34
2014	9	30	5	58	19	0.778	-0.092	3.829	0.013	0.01	0	38.3	33.5	77.4	126	112	0	37	34
2014	9	30	6	8	19	0.807	-0.112	3.829	0.01	0.007	0	38.3	33.1	77.4	125	111	0	36	34
2014	9	30	6	18	19	0.791	-0.072	3.829	0.013	0.01	0	37.4	32.7	77.8	124	110	0	37	34
2014	9	30	6	28	19	0.774	-0.102	3.829	0.016	0.013	0	37.8	32.7	77.8	124	110	0	36	34
2014	9	30	6	38	19	0.833	-0.108	3.829	0.01	0.007	0	37.4	32.3	77.4	123	109	0	36	34
2014	9	30	6	48	19	0.768	-0.098	3.829	0.013	0.01	0	36.5	31.8	77.4	122	108	0	37	34
2014	9	30	6	58	19	0.807	-0.089	3.829	0.01	0.007	0	36.5	31.8	77.4	121	107	0	36	33
2014	9	30	7	8	19	0.801	-0.082	3.829	0.013	0.01	0	36.5	31	77	121	106	0	36	34
2014	9	30	7	18	19	0.801	-0.108	3.829	0.016	0.016	0	36.1	31	77	120	105	0	36	33
2014	9	30	7	28	19	0.794	-0.059	3.829	0.01	0.007	0	36.1	31	77	120	106	0	36	34
2014	9	30	7	38	19	0.804	-0.085	3.829	0.013	0.01	0	35.7	30.5	76.5	119	105	0	36	34
2014	9	30	7	48	19	0.787	-0.098	3.829	0.01	0.007	0	35.3	30.5	77	118	104	0	36	33
2014	9	30	7	58	19	0.787	-0.102	3.829	0.013	0.01	0	35.3	31	77.4	118	105	0	36	33
2014	9	30	8	8	19	0.797	-0.089	3.829	0.013	0.01	0	35.3	30.1	76.1	118	104	0	36	34
2014	9	30	8	18	19	0.768	-0.066	3.829	0.01	0.007	0	35.3	30.5	77.4	119	105	0	37	34
2014	9	30	8	28	19	0.804	-0.079	3.829	0.01	0.007	0	36.5	31.8	77	121	108	0	36	34
2014	9	30	8	38	19	0.82	-0.082	3.829	0.013	0.01	0	35.7	30.5	77	119	105	0	36	34
2014	9	30	8	48	19	0.801	-0.108	3.829	0.01	0.007	0	35.3	30.5	77	118	105	0	36	34
2014	9	30	8	58	19	0.791	-0.095	3.829	0.01	0.007	0	34.8	30.1	77.4	117	103	0	36	33
2014	9	30	9	8	19	0.804	-0.072	3.829	0.016	0.013	0	34.4	29.2	77	116	102	0	36	34
2014	9	30	9	18	19	0.791	-0.092	3.829	0.01	0.007	0	34.8	29.7	77	117	103	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	9	28	19	0.797	-0.069	3.832	0.01	0.007	0	34.4	29.2	76.5	116	102	0	36	34
2014	9	30	9	38	19	0.797	-0.052	3.829	0.01	0.007	0	34	29.2	77.4	116	102	0	37	34
2014	9	30	9	48	19	0.774	-0.118	3.829	0.013	0.01	0	35.3	29.7	77	117	103	0	35	34
2014	9	30	9	58	19	0.778	-0.089	3.829	0.01	0.007	0	34.4	29.7	76.5	117	103	0	37	34
2014	9	30	10	8	19	0.781	-0.102	3.832	0.01	0.007	0	34.4	29.7	77	116	103	0	36	34
2014	9	30	10	18	19	0.745	-0.102	3.832	0.01	0.007	0	34.4	29.2	74	116	102	0	36	34
2014	9	30	10	28	19	0.794	-0.075	3.832	0.013	0.01	0	35.3	29.7	77.8	117	103	0	35	34
2014	9	30	10	38	19	0.814	-0.095	3.832	0.013	0.01	0	34.4	29.7	77.8	116	103	0	36	34
2014	9	30	10	48	19	0.761	-0.121	3.832	0.016	0.013	0	35.7	31	77.8	119	106	0	36	34
2014	9	30	10	58	19	0.774	-0.075	3.832	0.01	0.007	0	36.1	31.4	77.4	120	107	0	36	34
2014	9	30	11	8	19	0.807	-0.108	3.832	0.01	0.007	0	34.8	30.5	78.7	117	104	0	36	33
2014	9	30	11	18	19	0.83	-0.102	3.832	0.013	0.01	0	35.7	30.5	77.8	119	105	0	36	34
2014	9	30	11	28	19	0.764	-0.105	3.832	0.01	0.007	0	36.1	31.4	78.3	120	107	0	36	34
2014	9	30	11	38	19	0.814	-0.095	3.829	0.01	0.007	0	34	29.2	78.7	115	102	0	36	34
2014	9	30	11	48	19	0.781	-0.095	3.829	0.013	0.01	0	34	28.8	77.8	114	100	0	35	33
2014	9	30	11	58	19	0.784	-0.082	3.829	0.01	0.007	0	34	28.8	78.3	115	101	0	36	34
2014	9	30	12	8	19	0.774	-0.105	3.829	0.01	0.007	0	34	29.2	79.1	115	102	0	36	34
2014	9	30	12	18	19	0.814	-0.148	3.832	0.01	0.007	0	33.5	29.2	77.8	115	102	0	37	34
2014	9	30	12	28	19	0.853	-0.112	3.832	0.01	0.007	0	33.5	29.2	78.3	114	101	0	36	33
2014	9	30	12	38	19	0.768	-0.105	3.829	0.01	0.007	0	33.5	28.8	68.8	114	101	0	36	34
2014	9	30	12	48	19	0.787	-0.069	3.829	0.01	0.007	0	34.8	29.7	77.4	117	103	0	36	34
2014	9	30	12	58	19	0.797	-0.059	3.829	0.01	0.007	0	35.3	30.5	71	118	104	0	36	33
2014	9	30	13	8	19	0.797	-0.072	3.829	0.01	0.007	0	34.4	29.7	70.1	116	103	0	36	34
2014	9	30	13	18	19	0.814	-0.075	3.829	0.01	0.007	0	34.8	29.7	77.4	117	103	0	36	34
2014	9	30	13	28	19	0.768	-0.089	3.829	0.013	0.01	0	34.8	30.1	71.4	117	103	0	36	33
2014	9	30	13	38	19	0.781	-0.115	3.829	0.01	0.007	0	34.8	29.7	61.5	117	103	0	36	34
2014	9	30	13	48	19	0.764	-0.089	3.829	0.01	0.007	0	35.3	31	70.1	118	105	0	36	33
2014	9	30	13	58	19	0.784	-0.105	3.829	0.013	0.01	0	34.8	30.5	65.4	117	104	0	36	33
2014	9	30	14	8	19	0.725	-0.062	3.829	0.01	0.007	0	36.1	30.5	63.6	119	105	0	35	34
2014	9	30	14	18	19	0.784	-0.079	3.825	0.01	0.007	0	35.7	31.4	58	119	106	0	36	33
2014	9	30	14	28	19	0.761	-0.089	3.829	0.01	0.007	0	35.7	30.5	61.5	119	105	0	36	34
2014	9	30	14	38	19	0.764	-0.098	3.825	0.013	0.01	0	35.7	31	56.8	119	106	0	36	34
2014	9	30	14	48	19	0.768	-0.062	3.825	0.01	0.007	0	35.3	30.5	55.9	119	105	0	37	34
2014	9	30	14	58	19	0.755	-0.105	3.825	0.01	0.007	0	35.3	30.1	56.3	118	104	0	36	34
2014	9	30	15	8	19	0.787	-0.102	3.825	0.01	0.007	0	35.7	31	60.2	119	106	0	36	34
2014	9	30	15	18	19	0.781	-0.092	3.825	0.01	0.007	0	35.3	31	56.8	118	105	0	36	33
2014	9	30	15	28	19	0.794	-0.102	3.825	0.013	0.01	0	35.3	30.5	61.5	118	105	0	36	34
2014	9	30	15	38	19	0.768	-0.089	3.825	0.01	0.007	0	34.8	29.7	55.9	117	103	0	36	34
2014	9	30	15	48	19	0.801	-0.085	3.825	0.01	0.007	0	34.8	30.1	64.9	117	104	0	36	34
2014	9	30	15	58	19	0.755	-0.085	3.822	0.01	0.007	0	35.3	30.5	55.9	118	105	0	36	34
2014	9	30	16	8	19	0.797	-0.105	3.822	0.01	0.007	0	35.7	31	55.9	119	106	0	36	34
2014	9	30	16	18	19	0.741	-0.105	3.822	0.01	0.007	0	34.8	30.1	59.3	117	104	0	36	34
2014	9	30	16	28	19	0.791	-0.105	3.822	0.013	0.01	0	35.3	31	54.6	118	105	0	36	33
2014	9	30	16	38	19	0.83	-0.089	3.822	0.01	0.007	0	35.3	30.1	62.8	117	103	0	35	33
2014	9	30	16	48	19	0.755	-0.085	3.822	0.01	0.007	0	34.8	30.5	56.3	118	105	0	37	34
2014	9	30	16	58	19	0.774	-0.108	3.819	0.01	0.007	0	35.3	31	56.8	119	106	0	37	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	9	30	17	8	19	0.807	-0.115	3.822	0.01	0.007	0	35.3	30.1	60.6	118	104	0	36	34
2014	9	30	17	18	19	0.794	-0.105	3.822	0.01	0.007	0	35.7	31	63.2	119	105	0	36	33
2014	9	30	17	28	19	0.807	-0.105	3.819	0.01	0.007	0	35.3	30.5	58.5	118	104	0	36	33
2014	9	30	17	38	19	0.751	-0.089	3.822	0.01	0.007	0	35.7	30.5	67.1	119	105	0	36	34
2014	9	30	17	48	19	0.807	-0.115	3.822	0.013	0.01	0	36.1	31	76.1	120	106	0	36	34
2014	9	30	17	58	19	0.814	-0.105	3.822	0.01	0.007	0	36.1	31.4	74.8	120	106	0	36	33
2014	9	30	18	8	19	0.774	-0.089	3.822	0.01	0.007	0	36.1	30.5	77.4	120	106	0	36	35
2014	9	30	18	18	19	0.804	-0.102	3.822	0.01	0.007	0	37	31.8	77.4	122	108	0	36	34
2014	9	30	18	28	19	0.801	-0.089	3.822	0.013	0.01	0	37.8	32.7	77	124	110	0	36	34
2014	9	30	18	38	19	0.837	-0.089	3.822	0.01	0.007	0	37	31.8	76.5	122	108	0	36	34
2014	9	30	18	48	19	0.81	-0.118	3.822	0.01	0.007	0	37.4	32.7	77.4	123	109	0	36	33
2014	9	30	18	58	19	0.797	-0.059	3.822	0.01	0.007	0	37.8	33.1	77	124	110	0	36	33
2014	9	30	19	8	19	0.787	-0.066	3.822	0.013	0.01	0	39.1	34.4	76.1	127	113	0	36	33
2014	9	30	19	18	19	0.781	-0.082	3.822	0.01	0.007	0	40.4	34.8	77.8	129	115	0	35	34
2014	9	30	19	28	19	0.787	-0.118	3.822	0.013	0.01	0	40	34.8	78.3	129	115	0	36	34
2014	9	30	19	38	19	0.81	-0.112	3.822	0.013	0.01	0	40.9	36.1	77.8	131	117	0	36	33
2014	9	30	19	48	19	0.801	-0.082	3.822	0.01	0.007	0	40.4	35.3	77.4	130	116	0	36	34
2014	9	30	19	58	19	0.771	-0.115	3.822	0.013	0.01	0	40.4	35.7	77.4	130	116	0	36	33
2014	9	30	20	8	19	0.817	-0.098	3.822	0.013	0.01	0	41.3	35.7	77.8	131	117	0	35	34
2014	9	30	20	18	19	0.755	-0.082	3.822	0.01	0.007	0	40.9	35.7	77.4	131	117	0	36	34
2014	9	30	20	28	19	0.817	-0.102	3.822	0.01	0.007	0	41.3	36.5	77.4	132	118	0	36	33
2014	9	30	20	38	19	0.817	-0.072	3.822	0.013	0.01	0	41.3	36.1	77.4	132	118	0	36	34
2014	9	30	20	48	19	0.797	-0.089	3.822	0.01	0.007	0	41.3	36.5	77.8	132	118	0	36	33
2014	9	30	20	58	19	0.791	-0.098	3.822	0.013	0.01	0	41.7	36.5	77.4	133	119	0	36	34
2014	9	30	21	8	19	0.784	-0.069	3.822	0.013	0.01	0	41.7	36.1	77.8	133	118	0	36	34
2014	9	30	21	18	19	0.814	-0.112	3.822	0.01	0.007	0	41.3	36.5	77.4	132	118	0	36	33
2014	9	30	21	28	19	0.797	-0.108	3.822	0.013	0.01	0	42.1	37	77	134	120	0	36	34
2014	9	30	21	38	19	0.807	-0.049	3.822	0.01	0.007	0	41.7	36.5	77.4	133	119	0	36	34
2014	9	30	21	48	19	0.794	-0.105	3.822	0.013	0.01	0	41.7	36.1	77	133	118	0	36	34
2014	9	30	21	58	19	0.801	-0.089	3.822	0.01	0.007	0	41.7	36.5	77.4	133	119	0	36	34
2014	9	30	22	8	19	0.82	-0.069	3.822	0.016	0.013	0	41.7	37	77.4	133	119	0	36	33
2014	9	30	22	18	19	0.801	-0.089	3.822	0.016	0.013	0	42.1	36.5	77.4	133	119	0	35	34
2014	9	30	22	28	19	0.83	-0.072	3.822	0.01	0.007	0	41.7	37	75.3	133	119	0	36	33
2014	9	30	22	38	19	0.823	-0.075	3.822	0.01	0.007	0	42.1	37	77.4	134	120	0	36	34
2014	9	30	22	48	19	0.764	-0.105	3.822	0.013	0.01	0	41.3	36.1	72.2	132	118	0	36	34
2014	9	30	22	58	19	0.81	-0.115	3.822	0.01	0.007	0	40.9	36.5	77.4	131	118	0	36	33
2014	9	30	23	8	19	0.745	-0.085	3.822	0.01	0.007	0	42.1	37	76.1	134	120	0	36	34
2014	9	30	23	18	19	0.817	-0.092	3.822	0.016	0.013	0	41.3	36.1	76.1	132	118	0	36	34
2014	9	30	23	28	19	0.745	-0.089	3.822	0.01	0.007	0	42.1	37.4	75.7	134	120	0	36	33
2014	9	30	23	38	19	0.784	-0.105	3.822	0.01	0.007	0	42.1	36.5	75.7	134	119	0	36	34
2014	9	30	23	48	19	0.784	-0.059	3.822	0.01	0.007	0	42.1	37	76.1	134	120	0	36	34
2014	9	30	23	58	19	0.764	-0.095	3.822	0.013	0.01	0	42.6	37	72.2	135	120	0	36	34

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	0	0	41	32	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	1	0	10	41	34	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	1	0	20	41	34	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	1	0	30	41	34	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	1	0	40	41	33	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	1	0	50	41	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	1	1	0	41	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	1	1	10	41	33	0	0	0	0	0	0	0	63.7	0	0	11.6
2014	9	1	1	20	41	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	1	1	30	41	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	1	1	40	41	33	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	1	1	50	41	34	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	1	2	0	41	34	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	1	2	10	41	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	1	2	20	41	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	1	2	30	41	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	1	2	40	41	33	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	1	2	50	41	33	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	1	3	0	41	33	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	1	3	10	41	34	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	1	3	20	41	34	0	0	0	0	0	0	0	63.14	0	0	11.6
2014	9	1	3	30	41	33	0	0	0	0	0	0	0	63.07	0	0	11.6
2014	9	1	3	40	41	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	1	3	50	41	33	0	0	0	0	0	0	0	62.98	0	0	11.6
2014	9	1	4	0	41	33	0	0	0	0	0	0	0	62.94	0	0	11.6
2014	9	1	4	10	41	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	1	4	20	41	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	1	4	30	41	34	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	1	4	40	41	34	0	0	0	0	0	0	0	62.76	0	0	11.6
2014	9	1	4	50	41	34	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	1	5	0	41	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	1	5	10	41	33	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	1	5	20	41	33	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	1	5	30	41	33	0	0	0	0	0	0	0	62.55	0	0	11.6
2014	9	1	5	40	41	33	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	1	5	50	41	34	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	1	6	0	41	34	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	1	6	10	41	33	0	0	0	0	0	0	0	62.35	0	0	11.4
2014	9	1	6	20	41	34	0	0	0	0	0	0	0	62.31	0	0	11.6
2014	9	1	6	30	41	34	0	0	0	0	0	0	0	62.28	0	0	11.6
2014	9	1	6	40	41	33	0	0	0	0	0	0	0	62.24	0	0	11.6
2014	9	1	6	50	41	33	0	0	0	0	0	0	0	62.2	0	0	11.6
2014	9	1	7	0	41	34	0	0	0	0	0	0	0	62.19	0	0	11.4
2014	9	1	7	10	41	34	0	0	0	0	0	0	0	62.15	0	0	11.4
2014	9	1	7	20	41	33	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	1	7	30	41	34	0	0	0	0	0	0	0	62.1	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	7	40	41	34	0	0	0	0	0	0	0	62.06	0	0	12
2014	9	1	7	50	41	32	0	0	0	0	0	0	0	62.08	0	0	12
2014	9	1	8	0	41	33	0	0	0	0	0	0	0	62.11	0	0	12
2014	9	1	8	10	41	34	0	0	0	0	0	0	0	62.06	0	0	11.8
2014	9	1	8	20	41	34	0	0	0	0	0	0	0	62.1	0	0	12
2014	9	1	8	30	41	33	0	0	0	0	0	0	0	62.17	0	0	12
2014	9	1	8	40	41	33	0	0	0	0	0	0	0	62.2	0	0	12
2014	9	1	8	50	41	33	0	0	0	0	0	0	0	62.24	0	0	12
2014	9	1	9	0	41	34	0	0	0	0	0	0	0	62.29	0	0	12
2014	9	1	9	10	41	34	0	0	0	0	0	0	0	62.33	0	0	12
2014	9	1	9	20	41	33	0	0	0	0	0	0	0	62.37	0	0	12.2
2014	9	1	9	30	41	33	0	0	0	0	0	0	0	62.44	0	0	12.2
2014	9	1	9	40	41	34	0	0	0	0	0	0	0	62.49	0	0	12.2
2014	9	1	9	50	41	33	0	0	0	0	0	0	0	62.55	0	0	12.4
2014	9	1	10	0	41	34	0	0	0	0	0	0	0	62.62	0	0	12.4
2014	9	1	10	10	41	34	0	0	0	0	0	0	0	62.69	0	0	12.4
2014	9	1	10	20	41	33	0	0	0	0	0	0	0	62.76	0	0	12.6
2014	9	1	10	30	41	33	0	0	0	0	0	0	0	62.83	0	0	12.6
2014	9	1	10	40	41	33	0	0	0	0	0	0	0	62.91	0	0	12.4
2014	9	1	10	50	41	34	0	0	0	0	0	0	0	62.96	0	0	12.6
2014	9	1	11	0	41	33	0	0	0	0	0	0	0	63.03	0	0	12.4
2014	9	1	11	10	41	33	0	0	0	0	0	0	0	63.12	0	0	12.6
2014	9	1	11	20	41	34	0	0	0	0	0	0	0	63.19	0	0	12.4
2014	9	1	11	30	41	33	0	0	0	0	0	0	0	63.23	0	0	12.4
2014	9	1	11	40	41	33	0	0	0	0	0	0	0	63.32	0	0	12.4
2014	9	1	11	50	41	33	0	0	0	0	0	0	0	63.37	0	0	12.4
2014	9	1	12	0	41	34	0	0	0	0	0	0	0	63.46	0	0	12.4
2014	9	1	12	10	41	33	0	0	0	0	0	0	0	63.54	0	0	12.4
2014	9	1	12	20	41	33	0	0	0	0	0	0	0	63.61	0	0	12.4
2014	9	1	12	30	41	34	0	0	0	0	0	0	0	63.66	0	0	12.4
2014	9	1	12	40	41	34	0	0	0	0	0	0	0	63.72	0	0	12.4
2014	9	1	12	50	41	33	0	0	0	0	0	0	0	63.79	0	0	12.4
2014	9	1	13	0	41	34	0	0	0	0	0	0	0	63.84	0	0	12.4
2014	9	1	13	10	41	33	0	0	0	0	0	0	0	63.9	0	0	12.4
2014	9	1	13	20	41	33	0	0	0	0	0	0	0	63.97	0	0	12.4
2014	9	1	13	30	41	33	0	0	0	0	0	0	0	64.02	0	0	12.4
2014	9	1	13	40	41	33	0	0	0	0	0	0	0	64.08	0	0	12.4
2014	9	1	13	50	41	34	0	0	0	0	0	0	0	64.13	0	0	12.4
2014	9	1	14	0	41	34	0	0	0	0	0	0	0	64.15	0	0	12.4
2014	9	1	14	10	41	33	0	0	0	0	0	0	0	64.18	0	0	12.4
2014	9	1	14	20	41	34	0	0	0	0	0	0	0	64.24	0	0	12.4
2014	9	1	14	30	41	33	0	0	0	0	0	0	0	64.29	0	0	12.4
2014	9	1	14	40	41	33	0	0	0	0	0	0	0	64.31	0	0	12.4
2014	9	1	14	50	41	33	0	0	0	0	0	0	0	64.33	0	0	12.4
2014	9	1	15	0	41	33	0	0	0	0	0	0	0	64.36	0	0	12.4
2014	9	1	15	10	41	33	0	0	0	0	0	0	0	64.4	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	15	20	41	32	0	0	0	0	0	0	0	64.42	0	0	12.4
2014	9	1	15	30	41	34	0	0	0	0	0	0	0	64.44	0	0	12.4
2014	9	1	15	40	41	33	0	0	0	0	0	0	0	64.45	0	0	12.4
2014	9	1	15	50	41	34	0	0	0	0	0	0	0	64.47	0	0	12.4
2014	9	1	16	0	41	34	0	0	0	0	0	0	0	64.47	0	0	12.4
2014	9	1	16	10	41	33	0	0	0	0	0	0	0	64.49	0	0	12.4
2014	9	1	16	20	41	33	0	0	0	0	0	0	0	64.49	0	0	12.4
2014	9	1	16	30	41	34	0	0	0	0	0	0	0	64.51	0	0	12.2
2014	9	1	16	40	41	33	0	0	0	0	0	0	0	64.51	0	0	12.2
2014	9	1	16	50	41	34	0	0	0	0	0	0	0	64.53	0	0	12.2
2014	9	1	17	0	41	33	0	0	0	0	0	0	0	64.51	0	0	12
2014	9	1	17	10	41	34	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	1	17	20	41	32	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	1	17	30	41	33	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	1	17	40	41	33	0	0	0	0	0	0	0	64.54	0	0	11.6
2014	9	1	17	50	41	33	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	1	18	0	41	34	0	0	0	0	0	0	0	64.53	0	0	11.2
2014	9	1	18	10	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	18	20	41	33	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	1	18	30	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	18	40	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	18	50	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	19	0	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	19	10	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	19	20	41	34	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	19	30	41	33	0	0	0	0	0	0	0	64.54	0	0	11.2
2014	9	1	19	40	41	33	0	0	0	0	0	0	0	64.53	0	0	11.2
2014	9	1	19	50	41	33	0	0	0	0	0	0	0	64.53	0	0	11.2
2014	9	1	20	0	41	33	0	0	0	0	0	0	0	64.51	0	0	11.2
2014	9	1	20	10	41	33	0	0	0	0	0	0	0	64.51	0	0	11.2
2014	9	1	20	20	41	34	0	0	0	0	0	0	0	64.49	0	0	11.2
2014	9	1	20	30	41	33	0	0	0	0	0	0	0	64.49	0	0	11.2
2014	9	1	20	40	41	33	0	0	0	0	0	0	0	64.49	0	0	11.2
2014	9	1	20	50	41	33	0	0	0	0	0	0	0	64.47	0	0	11.2
2014	9	1	21	0	41	33	0	0	0	0	0	0	0	64.45	0	0	11.2
2014	9	1	21	10	41	33	0	0	0	0	0	0	0	64.44	0	0	11.2
2014	9	1	21	20	41	33	0	0	0	0	0	0	0	64.42	0	0	11.2
2014	9	1	21	30	41	33	0	0	0	0	0	0	0	64.4	0	0	11.2
2014	9	1	21	40	41	34	0	0	0	0	0	0	0	64.38	0	0	11.2
2014	9	1	21	50	41	33	0	0	0	0	0	0	0	64.36	0	0	11.2
2014	9	1	22	0	41	33	0	0	0	0	0	0	0	64.31	0	0	11.2
2014	9	1	22	10	41	33	0	0	0	0	0	0	0	64.29	0	0	11.2
2014	9	1	22	20	41	33	0	0	0	0	0	0	0	64.26	0	0	11.2
2014	9	1	22	30	41	34	0	0	0	0	0	0	0	64.24	0	0	11.2
2014	9	1	22	40	41	33	0	0	0	0	0	0	0	64.2	0	0	11.2
2014	9	1	22	50	41	33	0	0	0	0	0	0	0	64.17	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	1	23	0	41	33	0	0	0	0	0	0	0	64.13	0	0	11.2
2014	9	1	23	10	41	33	0	0	0	0	0	0	0	64.09	0	0	11
2014	9	1	23	20	41	33	0	0	0	0	0	0	0	64.08	0	0	11.2
2014	9	1	23	30	41	33	0	0	0	0	0	0	0	64.04	0	0	11.2
2014	9	1	23	40	41	33	0	0	0	0	0	0	0	64	0	0	11.2
2014	9	1	23	50	41	34	0	0	0	0	0	0	0	63.97	0	0	11
2014	9	2	0	0	41	34	0	0	0	0	0	0	0	63.93	0	0	11
2014	9	2	0	10	41	33	0	0	0	0	0	0	0	63.9	0	0	11
2014	9	2	0	20	41	33	0	0	0	0	0	0	0	63.86	0	0	11
2014	9	2	0	30	41	33	0	0	0	0	0	0	0	63.82	0	0	11
2014	9	2	0	40	41	32	0	0	0	0	0	0	0	63.79	0	0	11
2014	9	2	0	50	41	33	0	0	0	0	0	0	0	63.75	0	0	11
2014	9	2	1	0	41	34	0	0	0	0	0	0	0	63.72	0	0	11
2014	9	2	1	10	41	33	0	0	0	0	0	0	0	63.68	0	0	11
2014	9	2	1	20	41	33	0	0	0	0	0	0	0	63.64	0	0	11
2014	9	2	1	30	41	34	0	0	0	0	0	0	0	63.61	0	0	11
2014	9	2	1	40	41	33	0	0	0	0	0	0	0	63.57	0	0	11
2014	9	2	1	50	41	34	0	0	0	0	0	0	0	63.54	0	0	11
2014	9	2	2	0	41	33	0	0	0	0	0	0	0	63.48	0	0	11
2014	9	2	2	10	41	34	0	0	0	0	0	0	0	63.45	0	0	11
2014	9	2	2	20	41	34	0	0	0	0	0	0	0	63.41	0	0	11
2014	9	2	2	30	41	33	0	0	0	0	0	0	0	63.36	0	0	11
2014	9	2	2	40	41	33	0	0	0	0	0	0	0	63.3	0	0	11
2014	9	2	2	50	41	33	0	0	0	0	0	0	0	63.27	0	0	11
2014	9	2	3	0	41	33	0	0	0	0	0	0	0	63.23	0	0	11
2014	9	2	3	10	41	33	0	0	0	0	0	0	0	63.18	0	0	11
2014	9	2	3	20	41	33	0	0	0	0	0	0	0	63.14	0	0	11
2014	9	2	3	30	41	33	0	0	0	0	0	0	0	63.09	0	0	11
2014	9	2	3	40	41	33	0	0	0	0	0	0	0	63.05	0	0	11
2014	9	2	3	50	41	33	0	0	0	0	0	0	0	63.01	0	0	11
2014	9	2	4	0	41	33	0	0	0	0	0	0	0	62.98	0	0	11
2014	9	2	4	10	41	33	0	0	0	0	0	0	0	62.94	0	0	11
2014	9	2	4	20	41	33	0	0	0	0	0	0	0	62.89	0	0	11
2014	9	2	4	30	41	34	0	0	0	0	0	0	0	62.85	0	0	11
2014	9	2	4	40	41	34	0	0	0	0	0	0	0	62.8	0	0	11
2014	9	2	4	50	41	34	0	0	0	0	0	0	0	62.76	0	0	11
2014	9	2	5	0	41	33	0	0	0	0	0	0	0	62.71	0	0	11
2014	9	2	5	10	41	32	0	0	0	0	0	0	0	62.67	0	0	11
2014	9	2	5	20	41	33	0	0	0	0	0	0	0	62.62	0	0	11
2014	9	2	5	30	41	34	0	0	0	0	0	0	0	62.6	0	0	11
2014	9	2	5	40	41	34	0	0	0	0	0	0	0	62.55	0	0	11
2014	9	2	5	50	41	34	0	0	0	0	0	0	0	62.51	0	0	11
2014	9	2	6	0	41	34	0	0	0	0	0	0	0	62.46	0	0	11
2014	9	2	6	10	41	33	0	0	0	0	0	0	0	62.42	0	0	11
2014	9	2	6	20	41	34	0	0	0	0	0	0	0	62.38	0	0	11
2014	9	2	6	30	41	34	0	0	0	0	0	0	0	62.35	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	6	40	41	34	0	0	0	0	0	0	0	62.29	0	0	11
2014	9	2	6	50	41	33	0	0	0	0	0	0	0	62.28	0	0	11
2014	9	2	7	0	41	33	0	0	0	0	0	0	0	62.22	0	0	11
2014	9	2	7	10	41	33	0	0	0	0	0	0	0	62.2	0	0	11
2014	9	2	7	20	41	34	0	0	0	0	0	0	0	62.17	0	0	11.2
2014	9	2	7	30	41	33	0	0	0	0	0	0	0	62.15	0	0	11.2
2014	9	2	7	40	41	33	0	0	0	0	0	0	0	62.11	0	0	11.4
2014	9	2	7	50	41	33	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	2	8	0	41	33	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	2	8	10	41	33	0	0	0	0	0	0	0	62.1	0	0	11.8
2014	9	2	8	20	41	33	0	0	0	0	0	0	0	62.11	0	0	11.8
2014	9	2	8	30	41	33	0	0	0	0	0	0	0	62.19	0	0	12
2014	9	2	8	40	41	34	0	0	0	0	0	0	0	62.22	0	0	12
2014	9	2	8	50	41	34	0	0	0	0	0	0	0	62.24	0	0	12.2
2014	9	2	9	0	41	33	0	0	0	0	0	0	0	62.29	0	0	12
2014	9	2	9	10	41	34	0	0	0	0	0	0	0	62.33	0	0	12.2
2014	9	2	9	20	41	34	0	0	0	0	0	0	0	62.37	0	0	12.2
2014	9	2	9	30	41	34	0	0	0	0	0	0	0	62.42	0	0	12.4
2014	9	2	9	40	41	34	0	0	0	0	0	0	0	62.47	0	0	12.4
2014	9	2	9	50	41	33	0	0	0	0	0	0	0	62.53	0	0	12.4
2014	9	2	10	0	41	34	0	0	0	0	0	0	0	62.58	0	0	12.4
2014	9	2	10	10	41	34	0	0	0	0	0	0	0	62.64	0	0	12.4
2014	9	2	10	20	41	33	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	2	10	30	41	33	0	0	0	0	0	0	0	62.76	0	0	13
2014	9	2	10	40	41	34	0	0	0	0	0	0	0	62.82	0	0	13
2014	9	2	10	50	41	33	0	0	0	0	0	0	0	62.89	0	0	13
2014	9	2	11	0	41	34	0	0	0	0	0	0	0	62.96	0	0	13
2014	9	2	11	10	41	33	0	0	0	0	0	0	0	63.01	0	0	13
2014	9	2	11	20	41	34	0	0	0	0	0	0	0	63.09	0	0	12.8
2014	9	2	11	30	41	33	0	0	0	0	0	0	0	63.18	0	0	12.6
2014	9	2	11	40	41	34	0	0	0	0	0	0	0	63.23	0	0	12.6
2014	9	2	11	50	41	33	0	0	0	0	0	0	0	63.3	0	0	12.6
2014	9	2	12	0	41	33	0	0	0	0	0	0	0	63.37	0	0	12.6
2014	9	2	12	10	41	33	0	0	0	0	0	0	0	63.45	0	0	12.6
2014	9	2	12	20	41	33	0	0	0	0	0	0	0	63.5	0	0	12.6
2014	9	2	12	30	41	33	0	0	0	0	0	0	0	63.57	0	0	12.8
2014	9	2	12	40	41	33	0	0	0	0	0	0	0	63.63	0	0	12.6
2014	9	2	12	50	41	33	0	0	0	0	0	0	0	63.68	0	0	12.6
2014	9	2	13	0	41	34	0	0	0	0	0	0	0	63.75	0	0	12.6
2014	9	2	13	10	41	33	0	0	0	0	0	0	0	63.82	0	0	12.6
2014	9	2	13	20	41	34	0	0	0	0	0	0	0	63.88	0	0	12.6
2014	9	2	13	30	41	33	0	0	0	0	0	0	0	63.93	0	0	12.6
2014	9	2	13	40	41	33	0	0	0	0	0	0	0	63.97	0	0	12.6
2014	9	2	13	50	41	33	0	0	0	0	0	0	0	64.06	0	0	12.6
2014	9	2	14	0	41	34	0	0	0	0	0	0	0	64.09	0	0	12.6
2014	9	2	14	10	41	33	0	0	0	0	0	0	0	64.15	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	14	20	41	34	0	0	0	0	0	0	0	64.18	0	0	12.6
2014	9	2	14	30	41	33	0	0	0	0	0	0	0	64.22	0	0	12.6
2014	9	2	14	40	41	34	0	0	0	0	0	0	0	64.26	0	0	12.6
2014	9	2	14	50	41	34	0	0	0	0	0	0	0	64.29	0	0	12.6
2014	9	2	15	0	41	34	0	0	0	0	0	0	0	64.31	0	0	12.6
2014	9	2	15	10	41	34	0	0	0	0	0	0	0	64.33	0	0	12.6
2014	9	2	15	20	41	33	0	0	0	0	0	0	0	64.36	0	0	12.6
2014	9	2	15	30	41	33	0	0	0	0	0	0	0	64.36	0	0	12.6
2014	9	2	15	40	41	33	0	0	0	0	0	0	0	64.38	0	0	12.6
2014	9	2	15	50	41	34	0	0	0	0	0	0	0	64.4	0	0	12.6
2014	9	2	16	0	41	33	0	0	0	0	0	0	0	64.42	0	0	12.6
2014	9	2	16	10	41	33	0	0	0	0	0	0	0	64.44	0	0	12.6
2014	9	2	16	20	41	33	0	0	0	0	0	0	0	64.45	0	0	12.6
2014	9	2	16	30	41	34	0	0	0	0	0	0	0	64.47	0	0	12.6
2014	9	2	16	40	41	33	0	0	0	0	0	0	0	64.47	0	0	12.4
2014	9	2	16	50	41	32	0	0	0	0	0	0	0	64.49	0	0	12.4
2014	9	2	17	0	41	34	0	0	0	0	0	0	0	64.49	0	0	12.2
2014	9	2	17	10	41	33	0	0	0	0	0	0	0	64.51	0	0	12.2
2014	9	2	17	20	41	33	0	0	0	0	0	0	0	64.51	0	0	12
2014	9	2	17	30	41	33	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	2	17	40	41	33	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	2	17	50	41	33	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	2	18	0	41	33	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	2	18	10	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	18	20	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	18	30	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	18	40	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	18	50	41	33	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	2	19	0	41	33	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	2	19	10	41	34	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	2	19	20	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	19	30	41	33	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	2	19	40	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	19	50	41	33	0	0	0	0	0	0	0	64.53	0	0	11.2
2014	9	2	20	0	41	33	0	0	0	0	0	0	0	64.53	0	0	11.2
2014	9	2	20	10	41	33	0	0	0	0	0	0	0	64.53	0	0	11.4
2014	9	2	20	20	41	32	0	0	0	0	0	0	0	64.51	0	0	11.4
2014	9	2	20	30	41	34	0	0	0	0	0	0	0	64.49	0	0	11.2
2014	9	2	20	40	41	33	0	0	0	0	0	0	0	64.49	0	0	11.2
2014	9	2	20	50	41	33	0	0	0	0	0	0	0	64.47	0	0	11.2
2014	9	2	21	0	41	33	0	0	0	0	0	0	0	64.45	0	0	11.2
2014	9	2	21	10	41	33	0	0	0	0	0	0	0	64.44	0	0	11.2
2014	9	2	21	20	41	34	0	0	0	0	0	0	0	64.42	0	0	11.2
2014	9	2	21	30	41	33	0	0	0	0	0	0	0	64.4	0	0	11.2
2014	9	2	21	40	41	33	0	0	0	0	0	0	0	64.38	0	0	11.2
2014	9	2	21	50	41	34	0	0	0	0	0	0	0	64.36	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	2	22	0	41	33	0	0	0	0	0	0	0	64.35	0	0	11.2
2014	9	2	22	10	41	34	0	0	0	0	0	0	0	64.33	0	0	11.2
2014	9	2	22	20	41	33	0	0	0	0	0	0	0	64.31	0	0	11.2
2014	9	2	22	30	41	33	0	0	0	0	0	0	0	64.31	0	0	11.2
2014	9	2	22	40	41	33	0	0	0	0	0	0	0	64.27	0	0	11.2
2014	9	2	22	50	41	34	0	0	0	0	0	0	0	64.26	0	0	11.4
2014	9	2	23	0	41	34	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	2	23	10	41	33	0	0	0	0	0	0	0	64.22	0	0	11.2
2014	9	2	23	20	41	34	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	2	23	30	41	33	0	0	0	0	0	0	0	64.17	0	0	11.4
2014	9	2	23	40	41	33	0	0	0	0	0	0	0	64.15	0	0	11.4
2014	9	2	23	50	41	33	0	0	0	0	0	0	0	64.13	0	0	11.4
2014	9	3	0	0	41	33	0	0	0	0	0	0	0	64.09	0	0	11.2
2014	9	3	0	10	41	33	0	0	0	0	0	0	0	64.08	0	0	11.2
2014	9	3	0	20	41	33	0	0	0	0	0	0	0	64.06	0	0	11.2
2014	9	3	0	30	41	33	0	0	0	0	0	0	0	64.02	0	0	11.2
2014	9	3	0	40	41	34	0	0	0	0	0	0	0	64	0	0	11.2
2014	9	3	0	50	41	33	0	0	0	0	0	0	0	63.97	0	0	11.2
2014	9	3	1	0	41	33	0	0	0	0	0	0	0	63.93	0	0	11.2
2014	9	3	1	10	41	33	0	0	0	0	0	0	0	63.91	0	0	11.2
2014	9	3	1	20	41	33	0	0	0	0	0	0	0	63.88	0	0	11.2
2014	9	3	1	30	41	33	0	0	0	0	0	0	0	63.84	0	0	11.2
2014	9	3	1	40	41	33	0	0	0	0	0	0	0	63.81	0	0	11.2
2014	9	3	1	50	41	33	0	0	0	0	0	0	0	63.79	0	0	11.2
2014	9	3	2	0	41	33	0	0	0	0	0	0	0	63.73	0	0	11.2
2014	9	3	2	10	41	33	0	0	0	0	0	0	0	63.7	0	0	11.2
2014	9	3	2	20	41	33	0	0	0	0	0	0	0	63.68	0	0	11.2
2014	9	3	2	30	41	33	0	0	0	0	0	0	0	63.63	0	0	11.2
2014	9	3	2	40	41	33	0	0	0	0	0	0	0	63.59	0	0	11.2
2014	9	3	2	50	41	33	0	0	0	0	0	0	0	63.57	0	0	11.2
2014	9	3	3	0	41	33	0	0	0	0	0	0	0	63.54	0	0	11.2
2014	9	3	3	10	41	33	0	0	0	0	0	0	0	63.48	0	0	11.2
2014	9	3	3	20	41	33	0	0	0	0	0	0	0	63.45	0	0	11.2
2014	9	3	3	30	41	33	0	0	0	0	0	0	0	63.41	0	0	11
2014	9	3	3	40	41	33	0	0	0	0	0	0	0	63.37	0	0	11
2014	9	3	3	50	41	34	0	0	0	0	0	0	0	63.34	0	0	11
2014	9	3	4	0	41	33	0	0	0	0	0	0	0	63.3	0	0	11.2
2014	9	3	4	10	41	34	0	0	0	0	0	0	0	63.25	0	0	11.2
2014	9	3	4	20	41	33	0	0	0	0	0	0	0	63.21	0	0	11
2014	9	3	4	30	41	33	0	0	0	0	0	0	0	63.18	0	0	11
2014	9	3	4	40	41	33	0	0	0	0	0	0	0	63.14	0	0	11
2014	9	3	4	50	41	34	0	0	0	0	0	0	0	63.09	0	0	11
2014	9	3	5	0	41	34	0	0	0	0	0	0	0	63.05	0	0	11
2014	9	3	5	10	41	33	0	0	0	0	0	0	0	63.03	0	0	11
2014	9	3	5	20	41	33	0	0	0	0	0	0	0	62.98	0	0	11
2014	9	3	5	30	41	33	0	0	0	0	0	0	0	62.94	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	5	40	41	34	0	0	0	0	0	0	0	62.91	0	0	11
2014	9	3	5	50	41	34	0	0	0	0	0	0	0	62.87	0	0	11
2014	9	3	6	0	41	33	0	0	0	0	0	0	0	62.83	0	0	11
2014	9	3	6	10	41	33	0	0	0	0	0	0	0	62.8	0	0	11
2014	9	3	6	20	41	34	0	0	0	0	0	0	0	62.76	0	0	11
2014	9	3	6	30	41	34	0	0	0	0	0	0	0	62.71	0	0	11
2014	9	3	6	40	41	34	0	0	0	0	0	0	0	62.67	0	0	11
2014	9	3	6	50	41	34	0	0	0	0	0	0	0	62.64	0	0	11
2014	9	3	7	0	41	33	0	0	0	0	0	0	0	62.62	0	0	11
2014	9	3	7	10	41	33	0	0	0	0	0	0	0	62.58	0	0	11
2014	9	3	7	20	41	34	0	0	0	0	0	0	0	62.55	0	0	11.2
2014	9	3	7	30	41	33	0	0	0	0	0	0	0	62.53	0	0	11.2
2014	9	3	7	40	41	34	0	0	0	0	0	0	0	62.51	0	0	11.4
2014	9	3	7	50	41	34	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	3	8	0	41	34	0	0	0	0	0	0	0	62.51	0	0	11.6
2014	9	3	8	10	41	34	0	0	0	0	0	0	0	62.47	0	0	11.8
2014	9	3	8	20	41	33	0	0	0	0	0	0	0	62.49	0	0	11.8
2014	9	3	8	30	41	33	0	0	0	0	0	0	0	62.55	0	0	11.8
2014	9	3	8	40	41	34	0	0	0	0	0	0	0	62.58	0	0	11.8
2014	9	3	8	50	41	34	0	0	0	0	0	0	0	62.6	0	0	12
2014	9	3	9	0	41	33	0	0	0	0	0	0	0	62.64	0	0	12
2014	9	3	9	10	41	33	0	0	0	0	0	0	0	62.69	0	0	12
2014	9	3	9	20	41	34	0	0	0	0	0	0	0	62.73	0	0	12
2014	9	3	9	30	41	33	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	3	9	40	41	34	0	0	0	0	0	0	0	62.82	0	0	12.2
2014	9	3	9	50	41	33	0	0	0	0	0	0	0	62.87	0	0	12.4
2014	9	3	10	0	41	33	0	0	0	0	0	0	0	62.92	0	0	12.2
2014	9	3	10	10	41	33	0	0	0	0	0	0	0	62.98	0	0	12.4
2014	9	3	10	20	41	33	0	0	0	0	0	0	0	63.05	0	0	12.4
2014	9	3	10	30	41	33	0	0	0	0	0	0	0	63.1	0	0	12.4
2014	9	3	10	40	41	33	0	0	0	0	0	0	0	63.18	0	0	12.4
2014	9	3	10	50	41	33	0	0	0	0	0	0	0	63.23	0	0	12.4
2014	9	3	11	0	41	33	0	0	0	0	0	0	0	63.3	0	0	12.4
2014	9	3	11	10	41	33	0	0	0	0	0	0	0	63.39	0	0	12.4
2014	9	3	11	20	41	33	0	0	0	0	0	0	0	63.45	0	0	12.4
2014	9	3	11	30	41	33	0	0	0	0	0	0	0	63.5	0	0	12.6
2014	9	3	11	40	41	33	0	0	0	0	0	0	0	63.59	0	0	12.6
2014	9	3	11	50	41	33	0	0	0	0	0	0	0	63.64	0	0	12.2
2014	9	3	12	0	41	33	0	0	0	0	0	0	0	63.75	0	0	12.2
2014	9	3	12	10	41	33	0	0	0	0	0	0	0	63.84	0	0	12.2
2014	9	3	12	20	41	34	0	0	0	0	0	0	0	63.91	0	0	12.6
2014	9	3	12	30	41	34	0	0	0	0	0	0	0	63.99	0	0	12.6
2014	9	3	12	40	41	33	0	0	0	0	0	0	0	64.04	0	0	12.4
2014	9	3	12	50	41	33	0	0	0	0	0	0	0	64.09	0	0	12.4
2014	9	3	13	0	41	33	0	0	0	0	0	0	0	64.15	0	0	12.4
2014	9	3	13	10	41	33	0	0	0	0	0	0	0	64.22	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	13	20	41	33	0	0	0	0	0	0	0	64.26	0	0	12.4
2014	9	3	13	30	41	33	0	0	0	0	0	0	0	64.31	0	0	12.2
2014	9	3	13	40	41	33	0	0	0	0	0	0	0	64.36	0	0	12.2
2014	9	3	13	50	41	32	0	0	0	0	0	0	0	64.4	0	0	12.4
2014	9	3	14	0	41	34	0	0	0	0	0	0	0	64.45	0	0	12.4
2014	9	3	14	10	41	34	0	0	0	0	0	0	0	64.49	0	0	12.4
2014	9	3	14	20	41	33	0	0	0	0	0	0	0	64.53	0	0	12.4
2014	9	3	14	30	41	33	0	0	0	0	0	0	0	64.56	0	0	12.2
2014	9	3	14	40	41	33	0	0	0	0	0	0	0	64.6	0	0	12.2
2014	9	3	14	50	41	33	0	0	0	0	0	0	0	64.62	0	0	12.2
2014	9	3	15	0	41	34	0	0	0	0	0	0	0	64.67	0	0	12.2
2014	9	3	15	10	41	34	0	0	0	0	0	0	0	64.69	0	0	12.4
2014	9	3	15	20	41	33	0	0	0	0	0	0	0	64.71	0	0	12.8
2014	9	3	15	30	41	33	0	0	0	0	0	0	0	64.72	0	0	12.8
2014	9	3	15	40	41	33	0	0	0	0	0	0	0	64.74	0	0	12.8
2014	9	3	15	50	41	33	0	0	0	0	0	0	0	64.76	0	0	12.4
2014	9	3	16	0	41	33	0	0	0	0	0	0	0	64.78	0	0	12.2
2014	9	3	16	10	41	33	0	0	0	0	0	0	0	64.78	0	0	12.2
2014	9	3	16	20	41	33	0	0	0	0	0	0	0	64.8	0	0	12.4
2014	9	3	16	30	41	33	0	0	0	0	0	0	0	64.8	0	0	12.2
2014	9	3	16	40	41	33	0	0	0	0	0	0	0	64.8	0	0	12.4
2014	9	3	16	50	41	33	0	0	0	0	0	0	0	64.81	0	0	12.4
2014	9	3	17	0	41	33	0	0	0	0	0	0	0	64.8	0	0	12
2014	9	3	17	10	41	34	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	3	17	20	41	32	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	9	3	17	30	41	33	0	0	0	0	0	0	0	64.83	0	0	11.6
2014	9	3	17	40	41	33	0	0	0	0	0	0	0	64.81	0	0	11.6
2014	9	3	17	50	41	34	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	18	0	41	33	0	0	0	0	0	0	0	64.81	0	0	11.6
2014	9	3	18	10	41	33	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	18	20	41	33	0	0	0	0	0	0	0	64.81	0	0	11.2
2014	9	3	18	30	41	34	0	0	0	0	0	0	0	64.81	0	0	11.6
2014	9	3	18	40	41	32	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	18	50	41	34	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	19	0	41	33	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	19	10	41	33	0	0	0	0	0	0	0	64.81	0	0	11.2
2014	9	3	19	20	41	33	0	0	0	0	0	0	0	64.81	0	0	11.2
2014	9	3	19	30	41	33	0	0	0	0	0	0	0	64.81	0	0	11.2
2014	9	3	19	40	41	33	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	3	19	50	41	33	0	0	0	0	0	0	0	64.8	0	0	11.6
2014	9	3	20	0	41	34	0	0	0	0	0	0	0	64.78	0	0	11.6
2014	9	3	20	10	41	33	0	0	0	0	0	0	0	64.78	0	0	11.6
2014	9	3	20	20	41	32	0	0	0	0	0	0	0	64.76	0	0	11.6
2014	9	3	20	30	41	33	0	0	0	0	0	0	0	64.74	0	0	11.6
2014	9	3	20	40	41	33	0	0	0	0	0	0	0	64.72	0	0	11.6
2014	9	3	20	50	41	33	0	0	0	0	0	0	0	64.72	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	3	21	0	41	33	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	3	21	10	41	33	0	0	0	0	0	0	0	64.67	0	0	11.6
2014	9	3	21	20	41	33	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	3	21	30	41	33	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	3	21	40	41	33	0	0	0	0	0	0	0	64.58	0	0	11.6
2014	9	3	21	50	41	33	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	3	22	0	41	33	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	3	22	10	41	33	0	0	0	0	0	0	0	64.49	0	0	11.6
2014	9	3	22	20	41	33	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	3	22	30	41	33	0	0	0	0	0	0	0	64.44	0	0	11.6
2014	9	3	22	40	41	34	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	3	22	50	41	33	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	3	23	0	41	34	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	3	23	10	41	33	0	0	0	0	0	0	0	64.35	0	0	11.6
2014	9	3	23	20	41	33	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	3	23	30	41	34	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	3	23	40	41	33	0	0	0	0	0	0	0	64.26	0	0	11.6
2014	9	3	23	50	41	33	0	0	0	0	0	0	0	64.24	0	0	11.6
2014	9	4	0	0	41	33	0	0	0	0	0	0	0	64.2	0	0	11.6
2014	9	4	0	10	41	33	0	0	0	0	0	0	0	64.18	0	0	11.6
2014	9	4	0	20	41	33	0	0	0	0	0	0	0	64.17	0	0	11.6
2014	9	4	0	30	41	33	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	4	0	40	41	34	0	0	0	0	0	0	0	64.09	0	0	11.6
2014	9	4	0	50	41	33	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	4	1	0	41	33	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	4	1	10	41	33	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	4	1	20	41	33	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	4	1	30	41	33	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	4	1	40	41	34	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	4	1	50	41	32	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	4	2	0	41	34	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	4	2	10	41	33	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	4	2	20	41	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	4	2	30	41	33	0	0	0	0	0	0	0	63.72	0	0	11.6
2014	9	4	2	40	41	34	0	0	0	0	0	0	0	63.68	0	0	11.6
2014	9	4	2	50	41	34	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	4	3	0	41	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	4	3	10	41	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	4	3	20	41	34	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	4	3	30	41	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	4	3	40	41	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	4	3	50	41	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	4	4	0	41	33	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	4	4	10	41	33	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	4	4	20	41	33	0	0	0	0	0	0	0	63.21	0	0	11.6
2014	9	4	4	30	41	34	0	0	0	0	0	0	0	63.18	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	4	40	41	33	0	0	0	0	0	0	0	63.12	0	0	11.6
2014	9	4	4	50	41	33	0	0	0	0	0	0	0	63.09	0	0	11.6
2014	9	4	5	0	41	34	0	0	0	0	0	0	0	63.05	0	0	11.6
2014	9	4	5	10	41	34	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	4	5	20	41	33	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	4	5	30	41	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	4	5	40	41	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	4	5	50	41	34	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	4	6	0	41	34	0	0	0	0	0	0	0	62.8	0	0	11.6
2014	9	4	6	10	41	33	0	0	0	0	0	0	0	62.76	0	0	11.6
2014	9	4	6	20	41	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	4	6	30	41	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	4	6	40	41	34	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	4	6	50	41	34	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	4	7	0	41	33	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	4	7	10	41	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	4	7	20	41	33	0	0	0	0	0	0	0	62.51	0	0	11.8
2014	9	4	7	30	41	34	0	0	0	0	0	0	0	62.47	0	0	11.8
2014	9	4	7	40	41	34	0	0	0	0	0	0	0	62.46	0	0	12
2014	9	4	7	50	41	34	0	0	0	0	0	0	0	62.44	0	0	12
2014	9	4	8	0	41	33	0	0	0	0	0	0	0	62.42	0	0	12.2
2014	9	4	8	10	41	33	0	0	0	0	0	0	0	62.4	0	0	12.4
2014	9	4	8	20	41	34	0	0	0	0	0	0	0	62.4	0	0	12.4
2014	9	4	8	30	41	33	0	0	0	0	0	0	0	62.44	0	0	12.4
2014	9	4	8	40	41	33	0	0	0	0	0	0	0	62.46	0	0	12.4
2014	9	4	8	50	41	33	0	0	0	0	0	0	0	62.49	0	0	12.4
2014	9	4	9	0	41	34	0	0	0	0	0	0	0	62.51	0	0	12.6
2014	9	4	9	10	41	33	0	0	0	0	0	0	0	62.53	0	0	12.6
2014	9	4	9	20	41	34	0	0	0	0	0	0	0	62.56	0	0	12.6
2014	9	4	9	30	41	34	0	0	0	0	0	0	0	62.6	0	0	12.6
2014	9	4	9	40	41	34	0	0	0	0	0	0	0	62.65	0	0	12.8
2014	9	4	9	50	41	33	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	4	10	0	41	33	0	0	0	0	0	0	0	62.74	0	0	12.8
2014	9	4	10	10	41	34	0	0	0	0	0	0	0	62.8	0	0	13
2014	9	4	10	20	41	33	0	0	0	0	0	0	0	62.83	0	0	13.2
2014	9	4	10	30	41	33	0	0	0	0	0	0	0	62.91	0	0	13
2014	9	4	10	40	41	33	0	0	0	0	0	0	0	62.96	0	0	13.2
2014	9	4	10	50	41	33	0	0	0	0	0	0	0	63.01	0	0	13
2014	9	4	11	0	41	34	0	0	0	0	0	0	0	63.07	0	0	12.8
2014	9	4	11	10	41	33	0	0	0	0	0	0	0	63.14	0	0	12.8
2014	9	4	11	20	41	34	0	0	0	0	0	0	0	63.19	0	0	13.4
2014	9	4	11	30	41	34	0	0	0	0	0	0	0	63.27	0	0	13.2
2014	9	4	11	40	41	34	0	0	0	0	0	0	0	63.32	0	0	13.2
2014	9	4	11	50	41	33	0	0	0	0	0	0	0	63.39	0	0	13
2014	9	4	12	0	41	33	0	0	0	0	0	0	0	63.46	0	0	13
2014	9	4	12	10	41	34	0	0	0	0	0	0	0	63.54	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	12	20	41	34	0	0	0	0	0	0	0	63.59	0	0	13
2014	9	4	12	30	41	33	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	4	12	40	41	34	0	0	0	0	0	0	0	63.73	0	0	12.8
2014	9	4	12	50	41	33	0	0	0	0	0	0	0	63.77	0	0	12.8
2014	9	4	13	0	41	34	0	0	0	0	0	0	0	63.84	0	0	13
2014	9	4	13	10	41	33	0	0	0	0	0	0	0	63.9	0	0	12.8
2014	9	4	13	20	41	33	0	0	0	0	0	0	0	63.97	0	0	12.8
2014	9	4	13	30	41	34	0	0	0	0	0	0	0	64.02	0	0	12.8
2014	9	4	13	40	41	33	0	0	0	0	0	0	0	64.06	0	0	13
2014	9	4	13	50	41	33	0	0	0	0	0	0	0	64.11	0	0	13
2014	9	4	14	0	41	33	0	0	0	0	0	0	0	64.15	0	0	13
2014	9	4	14	10	41	34	0	0	0	0	0	0	0	64.2	0	0	13
2014	9	4	14	20	41	33	0	0	0	0	0	0	0	64.24	0	0	13
2014	9	4	14	30	41	32	0	0	0	0	0	0	0	64.27	0	0	13
2014	9	4	14	40	41	34	0	0	0	0	0	0	0	64.33	0	0	12.8
2014	9	4	14	50	41	34	0	0	0	0	0	0	0	64.35	0	0	12.8
2014	9	4	15	0	41	33	0	0	0	0	0	0	0	64.38	0	0	12.8
2014	9	4	15	10	41	33	0	0	0	0	0	0	0	64.42	0	0	12.8
2014	9	4	15	20	41	34	0	0	0	0	0	0	0	64.44	0	0	12.8
2014	9	4	15	30	41	32	0	0	0	0	0	0	0	64.47	0	0	12.8
2014	9	4	15	40	41	33	0	0	0	0	0	0	0	64.47	0	0	12.8
2014	9	4	15	50	41	33	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	4	16	0	41	33	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	4	16	10	41	34	0	0	0	0	0	0	0	64.53	0	0	13
2014	9	4	16	20	41	33	0	0	0	0	0	0	0	64.54	0	0	13
2014	9	4	16	30	41	33	0	0	0	0	0	0	0	64.54	0	0	12.8
2014	9	4	16	40	41	33	0	0	0	0	0	0	0	64.54	0	0	12.8
2014	9	4	16	50	41	33	0	0	0	0	0	0	0	64.58	0	0	12.6
2014	9	4	17	0	41	33	0	0	0	0	0	0	0	64.56	0	0	12.6
2014	9	4	17	10	41	33	0	0	0	0	0	0	0	64.56	0	0	12.6
2014	9	4	17	20	41	33	0	0	0	0	0	0	0	64.58	0	0	12.4
2014	9	4	17	30	41	33	0	0	0	0	0	0	0	64.58	0	0	12.2
2014	9	4	17	40	41	34	0	0	0	0	0	0	0	64.58	0	0	12.2
2014	9	4	17	50	41	33	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	4	18	0	41	33	0	0	0	0	0	0	0	64.56	0	0	12
2014	9	4	18	10	41	33	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	18	20	41	33	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	18	30	41	34	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	18	40	41	34	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	18	50	41	33	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	19	0	41	32	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	4	19	10	41	33	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	4	19	20	41	33	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	4	19	30	41	33	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	4	19	40	41	32	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	4	19	50	41	33	0	0	0	0	0	0	0	64.53	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	4	20	0	41	33	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	4	20	10	41	33	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	4	20	20	41	33	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	4	20	30	41	33	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	4	20	40	41	33	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	4	20	50	41	33	0	0	0	0	0	0	0	64.44	0	0	11.8
2014	9	4	21	0	41	33	0	0	0	0	0	0	0	64.42	0	0	11.8
2014	9	4	21	10	41	33	0	0	0	0	0	0	0	64.4	0	0	11.8
2014	9	4	21	20	41	33	0	0	0	0	0	0	0	64.38	0	0	11.8
2014	9	4	21	30	41	34	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	4	21	40	41	33	0	0	0	0	0	0	0	64.35	0	0	11.8
2014	9	4	21	50	41	33	0	0	0	0	0	0	0	64.33	0	0	11.8
2014	9	4	22	0	41	32	0	0	0	0	0	0	0	64.31	0	0	11.8
2014	9	4	22	10	41	33	0	0	0	0	0	0	0	64.29	0	0	11.8
2014	9	4	22	20	41	33	0	0	0	0	0	0	0	64.26	0	0	11.8
2014	9	4	22	30	41	33	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	4	22	40	41	33	0	0	0	0	0	0	0	64.22	0	0	11.8
2014	9	4	22	50	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	4	23	0	41	34	0	0	0	0	0	0	0	64.17	0	0	11.8
2014	9	4	23	10	41	33	0	0	0	0	0	0	0	64.13	0	0	11.8
2014	9	4	23	20	41	33	0	0	0	0	0	0	0	64.11	0	0	11.8
2014	9	4	23	30	41	33	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	4	23	40	41	34	0	0	0	0	0	0	0	64.06	0	0	11.8
2014	9	4	23	50	41	34	0	0	0	0	0	0	0	64.04	0	0	11.8
2014	9	5	0	0	41	34	0	0	0	0	0	0	0	64	0	0	11.8
2014	9	5	0	10	41	33	0	0	0	0	0	0	0	63.99	0	0	11.8
2014	9	5	0	20	41	33	0	0	0	0	0	0	0	63.95	0	0	11.8
2014	9	5	0	30	41	33	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	5	0	40	41	33	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	5	0	50	41	33	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	5	1	0	41	33	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	5	1	10	41	33	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	5	1	20	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	5	1	30	41	33	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	5	1	40	41	34	0	0	0	0	0	0	0	63.7	0	0	11.6
2014	9	5	1	50	41	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	5	2	0	41	33	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	5	2	10	41	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	5	2	20	41	33	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	5	2	30	41	33	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	5	2	40	41	33	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	5	2	50	41	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	5	3	0	41	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	5	3	10	41	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	5	3	20	41	34	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	5	3	30	41	34	0	0	0	0	0	0	0	63.25	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	3	40	41	34	0	0	0	0	0	0	0	63.21	0	0	11.6
2014	9	5	3	50	41	34	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	5	4	0	41	33	0	0	0	0	0	0	0	63.12	0	0	11.6
2014	9	5	4	10	41	33	0	0	0	0	0	0	0	63.07	0	0	11.6
2014	9	5	4	20	41	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	5	4	30	41	33	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	5	4	40	41	33	0	0	0	0	0	0	0	62.94	0	0	11.6
2014	9	5	4	50	41	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	5	5	0	41	34	0	0	0	0	0	0	0	62.85	0	0	11.6
2014	9	5	5	10	41	33	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	5	5	20	41	34	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	5	5	30	41	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	5	5	40	41	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	5	5	50	41	33	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	5	6	0	41	34	0	0	0	0	0	0	0	62.58	0	0	11.6
2014	9	5	6	10	41	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	5	6	20	41	33	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	5	6	30	41	34	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	5	6	40	41	34	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	5	6	50	41	33	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	5	7	0	41	33	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	5	7	10	41	33	0	0	0	0	0	0	0	62.29	0	0	11.6
2014	9	5	7	20	41	33	0	0	0	0	0	0	0	62.26	0	0	11.8
2014	9	5	7	30	41	33	0	0	0	0	0	0	0	62.22	0	0	11.8
2014	9	5	7	40	41	34	0	0	0	0	0	0	0	62.2	0	0	12
2014	9	5	7	50	41	34	0	0	0	0	0	0	0	62.17	0	0	12.2
2014	9	5	8	0	41	34	0	0	0	0	0	0	0	62.15	0	0	12.2
2014	9	5	8	10	41	33	0	0	0	0	0	0	0	62.13	0	0	12.4
2014	9	5	8	20	41	34	0	0	0	0	0	0	0	62.11	0	0	12.4
2014	9	5	8	30	41	33	0	0	0	0	0	0	0	62.13	0	0	12.4
2014	9	5	8	40	41	33	0	0	0	0	0	0	0	62.17	0	0	12.6
2014	9	5	8	50	41	34	0	0	0	0	0	0	0	62.2	0	0	12.6
2014	9	5	9	0	41	34	0	0	0	0	0	0	0	62.22	0	0	12.6
2014	9	5	9	10	41	33	0	0	0	0	0	0	0	62.24	0	0	12.6
2014	9	5	9	20	41	33	0	0	0	0	0	0	0	62.28	0	0	12.6
2014	9	5	9	30	41	33	0	0	0	0	0	0	0	62.33	0	0	12.8
2014	9	5	9	40	41	34	0	0	0	0	0	0	0	62.37	0	0	12.8
2014	9	5	9	50	41	33	0	0	0	0	0	0	0	62.42	0	0	13
2014	9	5	10	0	41	33	0	0	0	0	0	0	0	62.47	0	0	13.4
2014	9	5	10	10	41	34	0	0	0	0	0	0	0	62.53	0	0	13.8
2014	9	5	10	20	41	33	0	0	0	0	0	0	0	62.58	0	0	13.8
2014	9	5	10	30	41	34	0	0	0	0	0	0	0	62.64	0	0	13.8
2014	9	5	10	40	41	34	0	0	0	0	0	0	0	62.71	0	0	13.8
2014	9	5	10	50	41	34	0	0	0	0	0	0	0	62.78	0	0	13.8
2014	9	5	11	0	41	34	0	0	0	0	0	0	0	62.83	0	0	13.8
2014	9	5	11	10	41	33	0	0	0	0	0	0	0	62.89	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	11	20	41	34	0	0	0	0	0	0	0	62.96	0	0	14.2
2014	9	5	11	30	41	33	0	0	0	0	0	0	0	63.03	0	0	14.2
2014	9	5	11	40	41	34	0	0	0	0	0	0	0	63.1	0	0	14.2
2014	9	5	11	50	41	34	0	0	0	0	0	0	0	63.18	0	0	14
2014	9	5	12	0	41	33	0	0	0	0	0	0	0	63.21	0	0	14
2014	9	5	12	10	41	34	0	0	0	0	0	0	0	63.28	0	0	14
2014	9	5	12	20	41	33	0	0	0	0	0	0	0	63.34	0	0	14
2014	9	5	12	30	41	34	0	0	0	0	0	0	0	63.41	0	0	14
2014	9	5	12	40	41	33	0	0	0	0	0	0	0	63.46	0	0	13.8
2014	9	5	12	50	41	33	0	0	0	0	0	0	0	63.52	0	0	13.8
2014	9	5	13	0	41	33	0	0	0	0	0	0	0	63.57	0	0	13.8
2014	9	5	13	10	41	33	0	0	0	0	0	0	0	63.63	0	0	13.8
2014	9	5	13	20	41	33	0	0	0	0	0	0	0	63.66	0	0	13.8
2014	9	5	13	30	41	32	0	0	0	0	0	0	0	63.72	0	0	13.8
2014	9	5	13	40	41	34	0	0	0	0	0	0	0	63.75	0	0	13.8
2014	9	5	13	50	41	34	0	0	0	0	0	0	0	63.79	0	0	13.6
2014	9	5	14	0	41	33	0	0	0	0	0	0	0	63.84	0	0	13.8
2014	9	5	14	10	41	34	0	0	0	0	0	0	0	63.88	0	0	14
2014	9	5	14	20	41	34	0	0	0	0	0	0	0	63.91	0	0	13.8
2014	9	5	14	30	41	33	0	0	0	0	0	0	0	63.95	0	0	13.8
2014	9	5	14	40	41	33	0	0	0	0	0	0	0	63.99	0	0	13.8
2014	9	5	14	50	41	33	0	0	0	0	0	0	0	64	0	0	13.6
2014	9	5	15	0	41	34	0	0	0	0	0	0	0	64.04	0	0	13.6
2014	9	5	15	10	41	34	0	0	0	0	0	0	0	64.08	0	0	13.6
2014	9	5	15	20	41	34	0	0	0	0	0	0	0	64.09	0	0	13.4
2014	9	5	15	30	41	33	0	0	0	0	0	0	0	64.11	0	0	13.2
2014	9	5	15	40	41	33	0	0	0	0	0	0	0	64.11	0	0	13.4
2014	9	5	15	50	41	33	0	0	0	0	0	0	0	64.15	0	0	13.2
2014	9	5	16	0	41	33	0	0	0	0	0	0	0	64.15	0	0	13.4
2014	9	5	16	10	41	33	0	0	0	0	0	0	0	64.17	0	0	13.4
2014	9	5	16	20	41	33	0	0	0	0	0	0	0	64.18	0	0	13.2
2014	9	5	16	30	41	33	0	0	0	0	0	0	0	64.18	0	0	13
2014	9	5	16	40	41	33	0	0	0	0	0	0	0	64.2	0	0	12.8
2014	9	5	16	50	41	33	0	0	0	0	0	0	0	64.2	0	0	12.6
2014	9	5	17	0	41	33	0	0	0	0	0	0	0	64.2	0	0	12.6
2014	9	5	17	10	41	33	0	0	0	0	0	0	0	64.2	0	0	12.4
2014	9	5	17	20	41	33	0	0	0	0	0	0	0	64.2	0	0	12.2
2014	9	5	17	30	41	34	0	0	0	0	0	0	0	64.2	0	0	12.2
2014	9	5	17	40	41	33	0	0	0	0	0	0	0	64.2	0	0	12
2014	9	5	17	50	41	33	0	0	0	0	0	0	0	64.18	0	0	12
2014	9	5	18	0	41	33	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	5	18	10	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	5	18	20	41	34	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	5	18	30	41	34	0	0	0	0	0	0	0	64.2	0	0	11.8
2014	9	5	18	40	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	5	18	50	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	5	19	0	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	5	19	10	41	34	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	5	19	20	41	33	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	5	19	30	41	33	0	0	0	0	0	0	0	64.17	0	0	11.8
2014	9	5	19	40	41	32	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	5	19	50	41	33	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	5	20	0	41	34	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	5	20	10	41	33	0	0	0	0	0	0	0	64.11	0	0	11.6
2014	9	5	20	20	41	33	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	5	20	30	41	33	0	0	0	0	0	0	0	64.06	0	0	11.6
2014	9	5	20	40	41	33	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	5	20	50	41	33	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	5	21	0	41	33	0	0	0	0	0	0	0	63.99	0	0	11.6
2014	9	5	21	10	41	33	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	5	21	20	41	33	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	5	21	30	41	32	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	5	21	40	41	33	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	5	21	50	41	33	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	5	22	0	41	33	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	5	22	10	41	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	5	22	20	41	34	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	5	22	30	41	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	5	22	40	41	33	0	0	0	0	0	0	0	63.72	0	0	11.6
2014	9	5	22	50	41	33	0	0	0	0	0	0	0	63.68	0	0	11.6
2014	9	5	23	0	41	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	5	23	10	41	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	5	23	20	41	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	5	23	30	41	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	5	23	40	41	33	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	5	23	50	41	33	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	6	0	0	41	33	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	6	0	10	41	33	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	6	0	20	41	34	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	6	0	30	41	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	6	0	40	41	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	6	0	50	41	34	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	6	1	0	41	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	6	1	10	41	34	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	6	1	20	41	33	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	6	1	30	41	33	0	0	0	0	0	0	0	63.25	0	0	11.6
2014	9	6	1	40	41	33	0	0	0	0	0	0	0	63.21	0	0	11.6
2014	9	6	1	50	41	33	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	6	2	0	41	34	0	0	0	0	0	0	0	63.12	0	0	11.6
2014	9	6	2	10	41	34	0	0	0	0	0	0	0	63.09	0	0	11.6
2014	9	6	2	20	41	34	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	6	2	30	41	34	0	0	0	0	0	0	0	62.98	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	2	40	41	33	0	0	0	0	0	0	0	62.94	0	0	11.6
2014	9	6	2	50	41	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	6	3	0	41	34	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	6	3	10	41	34	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	6	3	20	41	34	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	6	3	30	41	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	6	3	40	41	34	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	6	3	50	41	33	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	6	4	0	41	33	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	6	4	10	41	34	0	0	0	0	0	0	0	62.44	0	0	11.6
2014	9	6	4	20	41	33	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	6	4	30	41	33	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	6	4	40	41	33	0	0	0	0	0	0	0	62.29	0	0	11.6
2014	9	6	4	50	41	33	0	0	0	0	0	0	0	62.24	0	0	11.6
2014	9	6	5	0	41	34	0	0	0	0	0	0	0	62.19	0	0	11.6
2014	9	6	5	10	41	33	0	0	0	0	0	0	0	62.13	0	0	11.6
2014	9	6	5	20	41	34	0	0	0	0	0	0	0	62.08	0	0	11.6
2014	9	6	5	30	41	33	0	0	0	0	0	0	0	62.04	0	0	11.6
2014	9	6	5	40	41	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	6	5	50	41	33	0	0	0	0	0	0	0	61.93	0	0	11.6
2014	9	6	6	0	41	33	0	0	0	0	0	0	0	61.88	0	0	11.6
2014	9	6	6	10	41	33	0	0	0	0	0	0	0	61.83	0	0	11.6
2014	9	6	6	20	41	32	0	0	0	0	0	0	0	61.79	0	0	11.6
2014	9	6	6	30	41	33	0	0	0	0	0	0	0	61.74	0	0	11.6
2014	9	6	6	40	41	33	0	0	0	0	0	0	0	61.68	0	0	11.6
2014	9	6	6	50	41	34	0	0	0	0	0	0	0	61.65	0	0	11.6
2014	9	6	7	0	41	34	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	6	7	10	41	34	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	6	7	20	41	33	0	0	0	0	0	0	0	61.52	0	0	11.8
2014	9	6	7	30	41	33	0	0	0	0	0	0	0	61.5	0	0	11.8
2014	9	6	7	40	41	33	0	0	0	0	0	0	0	61.47	0	0	12
2014	9	6	7	50	41	34	0	0	0	0	0	0	0	61.43	0	0	12.2
2014	9	6	8	0	41	34	0	0	0	0	0	0	0	61.41	0	0	12.2
2014	9	6	8	10	41	34	0	0	0	0	0	0	0	61.39	0	0	12.4
2014	9	6	8	20	41	33	0	0	0	0	0	0	0	61.38	0	0	12.4
2014	9	6	8	30	41	34	0	0	0	0	0	0	0	61.41	0	0	12.8
2014	9	6	8	40	41	34	0	0	0	0	0	0	0	61.45	0	0	12.8
2014	9	6	8	50	41	34	0	0	0	0	0	0	0	61.45	0	0	12.8
2014	9	6	9	0	41	33	0	0	0	0	0	0	0	61.5	0	0	13
2014	9	6	9	10	41	34	0	0	0	0	0	0	0	61.52	0	0	13
2014	9	6	9	20	41	33	0	0	0	0	0	0	0	61.54	0	0	13
2014	9	6	9	30	41	33	0	0	0	0	0	0	0	61.59	0	0	13.6
2014	9	6	9	40	41	34	0	0	0	0	0	0	0	61.63	0	0	13.6
2014	9	6	9	50	41	34	0	0	0	0	0	0	0	61.66	0	0	13.8
2014	9	6	10	0	41	33	0	0	0	0	0	0	0	61.72	0	0	13.6
2014	9	6	10	10	41	34	0	0	0	0	0	0	0	61.79	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	10	20	41	34	0	0	0	0	0	0	0	61.84	0	0	13.6
2014	9	6	10	30	41	35	0	0	0	0	0	0	0	61.9	0	0	13.4
2014	9	6	10	40	41	33	0	0	0	0	0	0	0	61.95	0	0	13.4
2014	9	6	10	50	41	33	0	0	0	0	0	0	0	62.02	0	0	13.4
2014	9	6	11	0	41	33	0	0	0	0	0	0	0	62.1	0	0	13.4
2014	9	6	11	10	41	33	0	0	0	0	0	0	0	62.17	0	0	13.4
2014	9	6	11	20	41	34	0	0	0	0	0	0	0	62.24	0	0	13.2
2014	9	6	11	30	41	34	0	0	0	0	0	0	0	62.31	0	0	13.4
2014	9	6	11	40	41	34	0	0	0	0	0	0	0	62.38	0	0	13.4
2014	9	6	11	50	41	34	0	0	0	0	0	0	0	62.46	0	0	13.4
2014	9	6	12	0	41	33	0	0	0	0	0	0	0	62.53	0	0	13.2
2014	9	6	12	10	41	33	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	6	12	20	41	33	0	0	0	0	0	0	0	62.65	0	0	12.8
2014	9	6	12	30	41	33	0	0	0	0	0	0	0	62.71	0	0	13.4
2014	9	6	12	40	41	33	0	0	0	0	0	0	0	62.8	0	0	13.8
2014	9	6	12	50	41	33	0	0	0	0	0	0	0	62.87	0	0	13.6
2014	9	6	13	0	41	33	0	0	0	0	0	0	0	62.94	0	0	13.8
2014	9	6	13	10	41	34	0	0	0	0	0	0	0	62.98	0	0	13.6
2014	9	6	13	20	41	34	0	0	0	0	0	0	0	63.03	0	0	13.8
2014	9	6	13	30	41	34	0	0	0	0	0	0	0	63.09	0	0	13.6
2014	9	6	13	40	41	34	0	0	0	0	0	0	0	63.12	0	0	13.6
2014	9	6	13	50	41	34	0	0	0	0	0	0	0	63.18	0	0	13.6
2014	9	6	14	0	41	33	0	0	0	0	0	0	0	63.23	0	0	13.6
2014	9	6	14	10	41	34	0	0	0	0	0	0	0	63.27	0	0	13.6
2014	9	6	14	20	41	34	0	0	0	0	0	0	0	63.32	0	0	13.4
2014	9	6	14	30	41	33	0	0	0	0	0	0	0	63.37	0	0	13.4
2014	9	6	14	40	41	33	0	0	0	0	0	0	0	63.43	0	0	13.6
2014	9	6	14	50	41	33	0	0	0	0	0	0	0	63.45	0	0	13.4
2014	9	6	15	0	41	34	0	0	0	0	0	0	0	63.48	0	0	13.4
2014	9	6	15	10	41	33	0	0	0	0	0	0	0	63.52	0	0	13.4
2014	9	6	15	20	41	34	0	0	0	0	0	0	0	63.54	0	0	13.2
2014	9	6	15	30	41	33	0	0	0	0	0	0	0	63.55	0	0	13.2
2014	9	6	15	40	41	34	0	0	0	0	0	0	0	63.59	0	0	13.2
2014	9	6	15	50	41	33	0	0	0	0	0	0	0	63.61	0	0	13.2
2014	9	6	16	0	41	33	0	0	0	0	0	0	0	63.63	0	0	13.2
2014	9	6	16	10	41	33	0	0	0	0	0	0	0	63.64	0	0	13
2014	9	6	16	20	41	33	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	6	16	30	41	33	0	0	0	0	0	0	0	63.66	0	0	12.6
2014	9	6	16	40	41	33	0	0	0	0	0	0	0	63.68	0	0	12.6
2014	9	6	16	50	41	34	0	0	0	0	0	0	0	63.7	0	0	12.4
2014	9	6	17	0	41	33	0	0	0	0	0	0	0	63.7	0	0	12.4
2014	9	6	17	10	41	33	0	0	0	0	0	0	0	63.7	0	0	12.4
2014	9	6	17	20	41	33	0	0	0	0	0	0	0	63.7	0	0	12.2
2014	9	6	17	30	41	34	0	0	0	0	0	0	0	63.72	0	0	12
2014	9	6	17	40	41	33	0	0	0	0	0	0	0	63.73	0	0	12
2014	9	6	17	50	41	33	0	0	0	0	0	0	0	63.7	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	6	18	0	41	33	0	0	0	0	0	0	0	63.72	0	0	11.8
2014	9	6	18	10	41	33	0	0	0	0	0	0	0	63.72	0	0	11.8
2014	9	6	18	20	41	33	0	0	0	0	0	0	0	63.73	0	0	11.8
2014	9	6	18	30	41	33	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	6	18	40	41	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	6	18	50	41	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	6	19	0	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	19	10	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	19	20	41	34	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	19	30	41	34	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	19	40	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	19	50	41	34	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	20	0	41	34	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	6	20	10	41	34	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	6	20	20	41	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	6	20	30	41	34	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	6	20	40	41	32	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	20	50	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	21	0	41	33	0	0	0	0	0	0	0	63.77	0	0	11.6
2014	9	6	21	10	41	33	0	0	0	0	0	0	0	63.77	0	0	11.4
2014	9	6	21	20	41	34	0	0	0	0	0	0	0	63.77	0	0	11.4
2014	9	6	21	30	41	33	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	6	21	40	41	33	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	6	21	50	41	32	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	6	22	0	41	33	0	0	0	0	0	0	0	63.73	0	0	11.4
2014	9	6	22	10	41	33	0	0	0	0	0	0	0	63.72	0	0	11.4
2014	9	6	22	20	41	32	0	0	0	0	0	0	0	63.72	0	0	11.4
2014	9	6	22	30	41	33	0	0	0	0	0	0	0	63.7	0	0	11.4
2014	9	6	22	40	41	33	0	0	0	0	0	0	0	63.68	0	0	11.4
2014	9	6	22	50	41	34	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	6	23	0	41	34	0	0	0	0	0	0	0	63.64	0	0	11.4
2014	9	6	23	10	41	33	0	0	0	0	0	0	0	63.63	0	0	11.4
2014	9	6	23	20	41	33	0	0	0	0	0	0	0	63.61	0	0	11.4
2014	9	6	23	30	41	34	0	0	0	0	0	0	0	63.59	0	0	11.4
2014	9	6	23	40	41	33	0	0	0	0	0	0	0	63.57	0	0	11.4
2014	9	6	23	50	41	33	0	0	0	0	0	0	0	63.55	0	0	11.4
2014	9	7	0	0	41	34	0	0	0	0	0	0	0	63.54	0	0	11.4
2014	9	7	0	10	41	33	0	0	0	0	0	0	0	63.52	0	0	11.4
2014	9	7	0	20	41	33	0	0	0	0	0	0	0	63.52	0	0	11.4
2014	9	7	0	30	41	33	0	0	0	0	0	0	0	63.5	0	0	11.4
2014	9	7	0	40	41	33	0	0	0	0	0	0	0	63.48	0	0	11.4
2014	9	7	0	50	41	33	0	0	0	0	0	0	0	63.46	0	0	11.4
2014	9	7	1	0	41	33	0	0	0	0	0	0	0	63.45	0	0	11.4
2014	9	7	1	10	41	33	0	0	0	0	0	0	0	63.43	0	0	11.4
2014	9	7	1	20	41	34	0	0	0	0	0	0	0	63.41	0	0	11.4
2014	9	7	1	30	41	33	0	0	0	0	0	0	0	63.39	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	1	40	41	34	0	0	0	0	0	0	0	63.37	0	0	11.4
2014	9	7	1	50	41	34	0	0	0	0	0	0	0	63.36	0	0	11.4
2014	9	7	2	0	41	34	0	0	0	0	0	0	0	63.32	0	0	11.4
2014	9	7	2	10	41	33	0	0	0	0	0	0	0	63.3	0	0	11.4
2014	9	7	2	20	41	33	0	0	0	0	0	0	0	63.28	0	0	11.4
2014	9	7	2	30	41	33	0	0	0	0	0	0	0	63.27	0	0	11.4
2014	9	7	2	40	41	34	0	0	0	0	0	0	0	63.25	0	0	11.4
2014	9	7	2	50	41	34	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	7	3	0	41	33	0	0	0	0	0	0	0	63.19	0	0	11.4
2014	9	7	3	10	41	34	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	7	3	20	41	33	0	0	0	0	0	0	0	63.14	0	0	11.4
2014	9	7	3	30	41	33	0	0	0	0	0	0	0	63.1	0	0	11.4
2014	9	7	3	40	41	33	0	0	0	0	0	0	0	63.07	0	0	11.4
2014	9	7	3	50	41	33	0	0	0	0	0	0	0	63.05	0	0	11.4
2014	9	7	4	0	41	33	0	0	0	0	0	0	0	63.01	0	0	11.4
2014	9	7	4	10	41	34	0	0	0	0	0	0	0	62.98	0	0	11.4
2014	9	7	4	20	41	33	0	0	0	0	0	0	0	62.92	0	0	11.4
2014	9	7	4	30	41	33	0	0	0	0	0	0	0	62.91	0	0	11.4
2014	9	7	4	40	41	33	0	0	0	0	0	0	0	62.87	0	0	11.4
2014	9	7	4	50	41	33	0	0	0	0	0	0	0	62.83	0	0	11.4
2014	9	7	5	0	41	33	0	0	0	0	0	0	0	62.8	0	0	11.4
2014	9	7	5	10	41	33	0	0	0	0	0	0	0	62.76	0	0	11.4
2014	9	7	5	20	41	34	0	0	0	0	0	0	0	62.73	0	0	11.4
2014	9	7	5	30	41	33	0	0	0	0	0	0	0	62.69	0	0	11.4
2014	9	7	5	40	41	34	0	0	0	0	0	0	0	62.65	0	0	11.4
2014	9	7	5	50	41	33	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	7	6	0	41	34	0	0	0	0	0	0	0	62.58	0	0	11.4
2014	9	7	6	10	41	33	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	7	6	20	41	34	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	7	6	30	41	34	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	7	6	40	41	33	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	7	6	50	41	33	0	0	0	0	0	0	0	62.37	0	0	11.4
2014	9	7	7	0	41	33	0	0	0	0	0	0	0	62.33	0	0	11.4
2014	9	7	7	10	41	34	0	0	0	0	0	0	0	62.29	0	0	11.4
2014	9	7	7	20	41	34	0	0	0	0	0	0	0	62.26	0	0	11.4
2014	9	7	7	30	41	33	0	0	0	0	0	0	0	62.22	0	0	11.6
2014	9	7	7	40	41	34	0	0	0	0	0	0	0	62.2	0	0	11.6
2014	9	7	7	50	41	33	0	0	0	0	0	0	0	62.19	0	0	11.8
2014	9	7	8	0	41	33	0	0	0	0	0	0	0	62.17	0	0	12
2014	9	7	8	10	41	33	0	0	0	0	0	0	0	62.15	0	0	12
2014	9	7	8	20	41	33	0	0	0	0	0	0	0	62.13	0	0	12.2
2014	9	7	8	30	41	34	0	0	0	0	0	0	0	62.15	0	0	12.2
2014	9	7	8	40	41	33	0	0	0	0	0	0	0	62.17	0	0	12.2
2014	9	7	8	50	41	34	0	0	0	0	0	0	0	62.19	0	0	12.2
2014	9	7	9	0	41	34	0	0	0	0	0	0	0	62.22	0	0	12.2
2014	9	7	9	10	41	33	0	0	0	0	0	0	0	62.22	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	9	20	41	33	0	0	0	0	0	0	0	62.28	0	0	12.4
2014	9	7	9	30	41	34	0	0	0	0	0	0	0	62.29	0	0	12
2014	9	7	9	40	41	34	0	0	0	0	0	0	0	62.28	0	0	12.4
2014	9	7	9	50	41	33	0	0	0	0	0	0	0	62.33	0	0	12.4
2014	9	7	10	0	41	33	0	0	0	0	0	0	0	62.4	0	0	12.6
2014	9	7	10	10	41	34	0	0	0	0	0	0	0	62.46	0	0	12.6
2014	9	7	10	20	41	33	0	0	0	0	0	0	0	62.53	0	0	12.8
2014	9	7	10	30	41	33	0	0	0	0	0	0	0	62.6	0	0	12.8
2014	9	7	10	40	41	33	0	0	0	0	0	0	0	62.64	0	0	12.6
2014	9	7	10	50	41	34	0	0	0	0	0	0	0	62.71	0	0	12.8
2014	9	7	11	0	41	33	0	0	0	0	0	0	0	62.76	0	0	12.2
2014	9	7	11	10	41	33	0	0	0	0	0	0	0	62.78	0	0	12.6
2014	9	7	11	20	41	33	0	0	0	0	0	0	0	62.82	0	0	12.8
2014	9	7	11	30	41	34	0	0	0	0	0	0	0	62.91	0	0	13.6
2014	9	7	11	40	41	33	0	0	0	0	0	0	0	63	0	0	13.6
2014	9	7	11	50	41	34	0	0	0	0	0	0	0	63.07	0	0	13.2
2014	9	7	12	0	41	33	0	0	0	0	0	0	0	63.14	0	0	12.8
2014	9	7	12	10	41	34	0	0	0	0	0	0	0	63.21	0	0	12.8
2014	9	7	12	20	41	33	0	0	0	0	0	0	0	63.27	0	0	12.8
2014	9	7	12	30	41	33	0	0	0	0	0	0	0	63.32	0	0	12.8
2014	9	7	12	40	41	33	0	0	0	0	0	0	0	63.41	0	0	12.8
2014	9	7	12	50	41	33	0	0	0	0	0	0	0	63.48	0	0	12.8
2014	9	7	13	0	41	33	0	0	0	0	0	0	0	63.54	0	0	12.8
2014	9	7	13	10	41	33	0	0	0	0	0	0	0	63.59	0	0	12.8
2014	9	7	13	20	41	34	0	0	0	0	0	0	0	63.64	0	0	12.8
2014	9	7	13	30	41	33	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	7	13	40	41	33	0	0	0	0	0	0	0	63.75	0	0	12.8
2014	9	7	13	50	41	34	0	0	0	0	0	0	0	63.79	0	0	12.8
2014	9	7	14	0	41	33	0	0	0	0	0	0	0	63.84	0	0	12.8
2014	9	7	14	10	41	33	0	0	0	0	0	0	0	63.9	0	0	12.6
2014	9	7	14	20	41	33	0	0	0	0	0	0	0	63.93	0	0	12.6
2014	9	7	14	30	41	33	0	0	0	0	0	0	0	63.97	0	0	12.6
2014	9	7	14	40	41	34	0	0	0	0	0	0	0	64.02	0	0	12.6
2014	9	7	14	50	41	33	0	0	0	0	0	0	0	64.06	0	0	12.6
2014	9	7	15	0	41	33	0	0	0	0	0	0	0	64.08	0	0	12.6
2014	9	7	15	10	41	33	0	0	0	0	0	0	0	64.11	0	0	12.6
2014	9	7	15	20	41	32	0	0	0	0	0	0	0	64.15	0	0	12.6
2014	9	7	15	30	41	33	0	0	0	0	0	0	0	64.18	0	0	12.6
2014	9	7	15	40	41	33	0	0	0	0	0	0	0	64.2	0	0	12.6
2014	9	7	15	50	41	33	0	0	0	0	0	0	0	64.24	0	0	12.6
2014	9	7	16	0	41	34	0	0	0	0	0	0	0	64.24	0	0	12.6
2014	9	7	16	10	41	33	0	0	0	0	0	0	0	64.26	0	0	12.6
2014	9	7	16	20	41	33	0	0	0	0	0	0	0	64.26	0	0	12.6
2014	9	7	16	30	41	33	0	0	0	0	0	0	0	64.27	0	0	12.6
2014	9	7	16	40	41	33	0	0	0	0	0	0	0	64.27	0	0	12.4
2014	9	7	16	50	41	33	0	0	0	0	0	0	0	64.29	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	7	17	0	41	33	0	0	0	0	0	0	0	64.29	0	0	12.2
2014	9	7	17	10	41	33	0	0	0	0	0	0	0	64.27	0	0	12
2014	9	7	17	20	41	33	0	0	0	0	0	0	0	64.29	0	0	12
2014	9	7	17	30	41	34	0	0	0	0	0	0	0	64.29	0	0	11.8
2014	9	7	17	40	41	33	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	7	17	50	41	33	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	7	18	0	41	34	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	7	18	10	41	34	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	7	18	20	41	34	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	7	18	30	41	33	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	7	18	40	41	34	0	0	0	0	0	0	0	64.29	0	0	11.6
2014	9	7	18	50	41	32	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	7	19	0	41	33	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	7	19	10	41	33	0	0	0	0	0	0	0	64.31	0	0	11.4
2014	9	7	19	20	41	34	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	7	19	30	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	19	40	41	33	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	7	19	50	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	20	0	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	20	10	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	20	20	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	20	30	41	33	0	0	0	0	0	0	0	64.36	0	0	11.4
2014	9	7	20	40	41	33	0	0	0	0	0	0	0	64.36	0	0	11.4
2014	9	7	20	50	41	33	0	0	0	0	0	0	0	64.36	0	0	11.4
2014	9	7	21	0	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	21	10	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	21	20	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	21	30	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	21	40	41	34	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	21	50	41	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	7	22	0	41	33	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	7	22	10	41	33	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	7	22	20	41	32	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	7	22	30	41	33	0	0	0	0	0	0	0	64.31	0	0	11.4
2014	9	7	22	40	41	33	0	0	0	0	0	0	0	64.29	0	0	11.4
2014	9	7	22	50	41	33	0	0	0	0	0	0	0	64.29	0	0	11.4
2014	9	7	23	0	41	32	0	0	0	0	0	0	0	64.27	0	0	11.4
2014	9	7	23	10	41	33	0	0	0	0	0	0	0	64.27	0	0	11.4
2014	9	7	23	20	41	33	0	0	0	0	0	0	0	64.26	0	0	11.4
2014	9	7	23	30	41	33	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	7	23	40	41	33	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	7	23	50	41	33	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	8	0	0	41	33	0	0	0	0	0	0	0	64.22	0	0	11.4
2014	9	8	0	10	41	34	0	0	0	0	0	0	0	64.22	0	0	11.4
2014	9	8	0	20	41	33	0	0	0	0	0	0	0	64.2	0	0	11.4
2014	9	8	0	30	41	34	0	0	0	0	0	0	0	64.2	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	0	40	41	33	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	8	0	50	41	33	0	0	0	0	0	0	0	64.17	0	0	11.4
2014	9	8	1	0	41	33	0	0	0	0	0	0	0	64.17	0	0	11.4
2014	9	8	1	10	41	33	0	0	0	0	0	0	0	64.15	0	0	11.4
2014	9	8	1	20	41	33	0	0	0	0	0	0	0	64.15	0	0	11.4
2014	9	8	1	30	41	33	0	0	0	0	0	0	0	64.13	0	0	11.4
2014	9	8	1	40	41	34	0	0	0	0	0	0	0	64.11	0	0	11.4
2014	9	8	1	50	41	33	0	0	0	0	0	0	0	64.11	0	0	11.4
2014	9	8	2	0	41	33	0	0	0	0	0	0	0	64.09	0	0	11.4
2014	9	8	2	10	41	33	0	0	0	0	0	0	0	64.09	0	0	11.4
2014	9	8	2	20	41	33	0	0	0	0	0	0	0	64.09	0	0	11.4
2014	9	8	2	30	41	33	0	0	0	0	0	0	0	64.08	0	0	11.4
2014	9	8	2	40	41	33	0	0	0	0	0	0	0	64.08	0	0	11.4
2014	9	8	2	50	41	33	0	0	0	0	0	0	0	64.06	0	0	11.4
2014	9	8	3	0	41	33	0	0	0	0	0	0	0	64.06	0	0	11.4
2014	9	8	3	10	41	33	0	0	0	0	0	0	0	64.04	0	0	11.4
2014	9	8	3	20	41	33	0	0	0	0	0	0	0	64.04	0	0	11.4
2014	9	8	3	30	41	33	0	0	0	0	0	0	0	64.02	0	0	11.4
2014	9	8	3	40	41	33	0	0	0	0	0	0	0	63.99	0	0	11.4
2014	9	8	3	50	41	33	0	0	0	0	0	0	0	64	0	0	11.4
2014	9	8	4	0	41	33	0	0	0	0	0	0	0	63.99	0	0	11.4
2014	9	8	4	10	41	34	0	0	0	0	0	0	0	63.99	0	0	11.4
2014	9	8	4	20	41	34	0	0	0	0	0	0	0	63.99	0	0	11.4
2014	9	8	4	30	41	33	0	0	0	0	0	0	0	63.97	0	0	11.4
2014	9	8	4	40	41	32	0	0	0	0	0	0	0	63.97	0	0	11.4
2014	9	8	4	50	41	33	0	0	0	0	0	0	0	63.97	0	0	11.4
2014	9	8	5	0	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	5	10	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	5	20	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	5	30	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	5	40	41	33	0	0	0	0	0	0	0	63.93	0	0	11.4
2014	9	8	5	50	41	33	0	0	0	0	0	0	0	63.93	0	0	11.4
2014	9	8	6	0	41	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	8	6	10	41	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	8	6	20	41	34	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	8	6	30	41	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	8	6	40	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	6	50	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	0	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	10	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	20	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	30	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	40	41	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	8	7	50	41	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	8	8	0	41	33	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	8	8	10	41	33	0	0	0	0	0	0	0	63.93	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	8	20	41	33	0	0	0	0	0	0	0	63.93	0	0	11.4
2014	9	8	8	30	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	8	40	41	33	0	0	0	0	0	0	0	63.95	0	0	11.4
2014	9	8	8	50	41	32	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	8	9	0	41	34	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	8	9	10	41	33	0	0	0	0	0	0	0	63.99	0	0	12
2014	9	8	9	20	41	33	0	0	0	0	0	0	0	64.06	0	0	12.2
2014	9	8	9	30	41	33	0	0	0	0	0	0	0	64.11	0	0	12.4
2014	9	8	9	40	41	33	0	0	0	0	0	0	0	64.17	0	0	12.6
2014	9	8	9	50	41	34	0	0	0	0	0	0	0	64.22	0	0	12.6
2014	9	8	10	0	41	33	0	0	0	0	0	0	0	64.27	0	0	12.6
2014	9	8	10	10	41	33	0	0	0	0	0	0	0	64.33	0	0	12.6
2014	9	8	10	20	41	33	0	0	0	0	0	0	0	64.36	0	0	12.6
2014	9	8	10	30	41	33	0	0	0	0	0	0	0	64.42	0	0	12.6
2014	9	8	10	40	41	33	0	0	0	0	0	0	0	64.47	0	0	12.8
2014	9	8	10	50	41	33	0	0	0	0	0	0	0	64.51	0	0	13
2014	9	8	11	0	41	34	0	0	0	0	0	0	0	64.58	0	0	13
2014	9	8	11	10	41	33	0	0	0	0	0	0	0	64.62	0	0	13
2014	9	8	11	20	41	33	0	0	0	0	0	0	0	64.65	0	0	13
2014	9	8	11	30	41	33	0	0	0	0	0	0	0	64.69	0	0	12.4
2014	9	8	11	40	41	33	0	0	0	0	0	0	0	64.63	0	0	12.4
2014	9	8	11	50	41	33	0	0	0	0	0	0	0	64.62	0	0	13.2
2014	9	8	12	0	41	34	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	8	12	10	41	33	0	0	0	0	0	0	0	64.71	0	0	12.6
2014	9	8	12	20	41	33	0	0	0	0	0	0	0	64.76	0	0	13.2
2014	9	8	12	30	41	33	0	0	0	0	0	0	0	64.87	0	0	13.2
2014	9	8	12	40	41	34	0	0	0	0	0	0	0	64.94	0	0	13.2
2014	9	8	12	50	41	33	0	0	0	0	0	0	0	64.99	0	0	13.2
2014	9	8	13	0	41	33	0	0	0	0	0	0	0	65.08	0	0	13.2
2014	9	8	13	10	41	33	0	0	0	0	0	0	0	65.12	0	0	12.2
2014	9	8	13	28	19	33	0	0	0	0	0	0	0	65.07	0	0	13.2
2014	9	8	13	38	19	33	0	0	0	0	0	0	0	65.16	0	0	13.4
2014	9	8	13	48	19	33	0	0	0	0	0	0	0	65.19	0	0	12.6
2014	9	8	13	58	19	34	0	0	0	0	0	0	0	65.16	0	0	13.4
2014	9	8	14	8	19	32	0	0	0	0	0	0	0	65.25	0	0	13.6
2014	9	8	14	18	19	34	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	8	14	28	19	34	0	0	0	0	0	0	0	65.37	0	0	12.8
2014	9	8	14	38	19	32	0	0	0	0	0	0	0	65.39	0	0	13.4
2014	9	8	14	48	19	33	0	0	0	0	0	0	0	65.44	0	0	13.4
2014	9	8	14	58	19	34	0	0	0	0	0	0	0	65.52	0	0	13.4
2014	9	8	15	8	19	33	0	0	0	0	0	0	0	65.57	0	0	13.4
2014	9	8	15	18	19	33	0	0	0	0	0	0	0	65.59	0	0	13.4
2014	9	8	15	28	19	33	0	0	0	0	0	0	0	65.62	0	0	13.4
2014	9	8	15	38	19	33	0	0	0	0	0	0	0	65.62	0	0	13.4
2014	9	8	15	48	19	34	0	0	0	0	0	0	0	65.66	0	0	13.4
2014	9	8	15	58	19	34	0	0	0	0	0	0	0	65.68	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	16	8	19	33	0	0	0	0	0	0	0	65.7	0	0	13.2
2014	9	8	16	18	19	33	0	0	0	0	0	0	0	65.7	0	0	12.6
2014	9	8	16	28	19	33	0	0	0	0	0	0	0	65.71	0	0	13.2
2014	9	8	16	38	19	33	0	0	0	0	0	0	0	65.73	0	0	13
2014	9	8	16	48	19	33	0	0	0	0	0	0	0	65.75	0	0	12.8
2014	9	8	16	58	19	32	0	0	0	0	0	0	0	65.75	0	0	12.6
2014	9	8	17	8	19	32	0	0	0	0	0	0	0	65.73	0	0	12.4
2014	9	8	17	18	19	32	0	0	0	0	0	0	0	65.71	0	0	12
2014	9	8	17	28	19	33	0	0	0	0	0	0	0	65.71	0	0	12.2
2014	9	8	17	38	19	33	0	0	0	0	0	0	0	65.75	0	0	12.2
2014	9	8	17	48	19	33	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	8	17	58	19	33	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	8	18	8	19	33	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	8	18	18	19	33	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	8	18	28	19	33	0	0	0	0	0	0	0	65.73	0	0	12
2014	9	8	18	38	19	33	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	8	18	48	19	33	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	8	18	58	19	33	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	8	19	8	19	34	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	8	19	18	19	32	0	0	0	0	0	0	0	65.73	0	0	11.8
2014	9	8	19	28	19	33	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	8	19	38	19	33	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	8	19	48	19	32	0	0	0	0	0	0	0	65.71	0	0	11.8
2014	9	8	19	58	19	33	0	0	0	0	0	0	0	65.7	0	0	11.8
2014	9	8	20	8	19	32	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	8	20	18	19	33	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	9	8	20	28	19	33	0	0	0	0	0	0	0	65.66	0	0	11.8
2014	9	8	20	38	19	33	0	0	0	0	0	0	0	65.64	0	0	11.8
2014	9	8	20	48	19	33	0	0	0	0	0	0	0	65.62	0	0	11.8
2014	9	8	20	58	19	33	0	0	0	0	0	0	0	65.61	0	0	11.8
2014	9	8	21	8	19	33	0	0	0	0	0	0	0	65.59	0	0	11.8
2014	9	8	21	18	19	34	0	0	0	0	0	0	0	65.57	0	0	11.8
2014	9	8	21	28	19	33	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	9	8	21	38	19	33	0	0	0	0	0	0	0	65.52	0	0	11.8
2014	9	8	21	48	19	32	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	9	8	21	58	19	33	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	9	8	22	8	19	33	0	0	0	0	0	0	0	65.44	0	0	11.8
2014	9	8	22	18	19	33	0	0	0	0	0	0	0	65.43	0	0	11.8
2014	9	8	22	28	19	33	0	0	0	0	0	0	0	65.39	0	0	11.8
2014	9	8	22	38	19	33	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	9	8	22	48	19	32	0	0	0	0	0	0	0	65.32	0	0	11.8
2014	9	8	22	58	19	33	0	0	0	0	0	0	0	65.3	0	0	11.8
2014	9	8	23	8	19	33	0	0	0	0	0	0	0	65.26	0	0	11.8
2014	9	8	23	18	19	33	0	0	0	0	0	0	0	65.23	0	0	11.8
2014	9	8	23	28	19	33	0	0	0	0	0	0	0	65.19	0	0	11.8
2014	9	8	23	38	19	33	0	0	0	0	0	0	0	65.16	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	8	23	48	19	33	0	0	0	0	0	0	0	65.12	0	0	11.8
2014	9	8	23	58	19	33	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	9	9	0	8	19	32	0	0	0	0	0	0	0	65.05	0	0	11.8
2014	9	9	0	18	19	33	0	0	0	0	0	0	0	65.03	0	0	11.8
2014	9	9	0	28	19	33	0	0	0	0	0	0	0	64.98	0	0	11.8
2014	9	9	0	38	19	32	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	9	0	48	19	33	0	0	0	0	0	0	0	64.9	0	0	11.8
2014	9	9	0	58	19	33	0	0	0	0	0	0	0	64.8	0	0	11.8
2014	9	9	1	8	19	33	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	9	1	18	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	9	1	28	19	34	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	9	1	38	19	33	0	0	0	0	0	0	0	64.56	0	0	11.8
2014	9	9	1	48	19	33	0	0	0	0	0	0	0	64.53	0	0	11.8
2014	9	9	1	58	19	33	0	0	0	0	0	0	0	64.49	0	0	11.8
2014	9	9	2	8	19	33	0	0	0	0	0	0	0	64.45	0	0	11.8
2014	9	9	2	18	19	33	0	0	0	0	0	0	0	64.4	0	0	11.8
2014	9	9	2	28	19	33	0	0	0	0	0	0	0	64.36	0	0	11.8
2014	9	9	2	38	19	33	0	0	0	0	0	0	0	64.33	0	0	11.8
2014	9	9	2	48	19	34	0	0	0	0	0	0	0	64.27	0	0	11.8
2014	9	9	2	58	19	34	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	9	3	8	19	32	0	0	0	0	0	0	0	64.2	0	0	11.6
2014	9	9	3	18	19	33	0	0	0	0	0	0	0	64.15	0	0	11.6
2014	9	9	3	28	19	33	0	0	0	0	0	0	0	64.11	0	0	11.6
2014	9	9	3	38	19	33	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	9	3	48	19	33	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	9	3	58	19	33	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	9	4	8	19	33	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	9	4	18	19	34	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	9	4	28	19	33	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	9	4	38	19	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	9	4	48	19	32	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	9	4	58	19	33	0	0	0	0	0	0	0	63.7	0	0	11.6
2014	9	9	5	8	19	34	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	9	5	18	19	33	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	9	5	28	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	9	5	38	19	33	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	9	5	48	19	33	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	9	5	58	19	32	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	9	6	8	19	33	0	0	0	0	0	0	0	63.37	0	0	11.6
2014	9	9	6	18	19	33	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	9	6	28	19	33	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	9	6	38	19	33	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	9	6	48	19	33	0	0	0	0	0	0	0	63.19	0	0	11.6
2014	9	9	6	58	19	34	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	9	7	8	19	33	0	0	0	0	0	0	0	63.1	0	0	11.6
2014	9	9	7	18	19	34	0	0	0	0	0	0	0	63.09	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	7	28	19	33	0	0	0	0	0	0	0	63.05	0	0	12
2014	9	9	7	38	19	33	0	0	0	0	0	0	0	63.01	0	0	12
2014	9	9	7	48	19	33	0	0	0	0	0	0	0	62.98	0	0	12.2
2014	9	9	7	58	19	34	0	0	0	0	0	0	0	62.96	0	0	12.4
2014	9	9	8	8	19	33	0	0	0	0	0	0	0	62.96	0	0	12.6
2014	9	9	8	18	19	33	0	0	0	0	0	0	0	62.94	0	0	12.6
2014	9	9	8	28	19	33	0	0	0	0	0	0	0	63	0	0	12.6
2014	9	9	8	38	19	33	0	0	0	0	0	0	0	63.01	0	0	12.6
2014	9	9	8	48	19	33	0	0	0	0	0	0	0	63.05	0	0	12.6
2014	9	9	8	58	19	33	0	0	0	0	0	0	0	63.07	0	0	12.8
2014	9	9	9	8	19	33	0	0	0	0	0	0	0	63.1	0	0	12.8
2014	9	9	9	18	19	33	0	0	0	0	0	0	0	63.12	0	0	12.8
2014	9	9	9	28	19	34	0	0	0	0	0	0	0	63.16	0	0	12.8
2014	9	9	9	38	19	34	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	9	9	48	19	34	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	9	9	58	19	34	0	0	0	0	0	0	0	63.28	0	0	13.4
2014	9	9	10	8	19	33	0	0	0	0	0	0	0	63.34	0	0	13.6
2014	9	9	10	18	19	34	0	0	0	0	0	0	0	63.39	0	0	13.6
2014	9	9	10	28	19	33	0	0	0	0	0	0	0	63.45	0	0	13.6
2014	9	9	10	38	19	34	0	0	0	0	0	0	0	63.48	0	0	13.2
2014	9	9	10	48	19	34	0	0	0	0	0	0	0	63.55	0	0	13.6
2014	9	9	10	58	19	33	0	0	0	0	0	0	0	63.61	0	0	13.6
2014	9	9	11	8	19	33	0	0	0	0	0	0	0	63.64	0	0	13.4
2014	9	9	11	18	19	33	0	0	0	0	0	0	0	63.7	0	0	13.4
2014	9	9	11	28	19	33	0	0	0	0	0	0	0	63.77	0	0	13.4
2014	9	9	11	38	19	34	0	0	0	0	0	0	0	63.81	0	0	13.4
2014	9	9	11	48	19	34	0	0	0	0	0	0	0	63.88	0	0	14
2014	9	9	11	58	19	33	0	0	0	0	0	0	0	63.91	0	0	13.8
2014	9	9	12	8	19	33	0	0	0	0	0	0	0	63.99	0	0	14
2014	9	9	12	18	19	34	0	0	0	0	0	0	0	64.04	0	0	13.4
2014	9	9	12	28	19	33	0	0	0	0	0	0	0	64.15	0	0	13.4
2014	9	9	12	38	19	33	0	0	0	0	0	0	0	64.2	0	0	13.4
2014	9	9	12	48	19	34	0	0	0	0	0	0	0	64.26	0	0	13.4
2014	9	9	12	58	19	33	0	0	0	0	0	0	0	64.29	0	0	13.4
2014	9	9	13	8	19	33	0	0	0	0	0	0	0	64.35	0	0	13.2
2014	9	9	13	18	19	34	0	0	0	0	0	0	0	64.4	0	0	13.4
2014	9	9	13	28	19	33	0	0	0	0	0	0	0	64.44	0	0	13.4
2014	9	9	13	38	19	34	0	0	0	0	0	0	0	64.49	0	0	13.4
2014	9	9	13	48	19	33	0	0	0	0	0	0	0	64.51	0	0	13.2
2014	9	9	13	58	19	33	0	0	0	0	0	0	0	64.53	0	0	13.2
2014	9	9	14	8	19	33	0	0	0	0	0	0	0	64.58	0	0	13.2
2014	9	9	14	18	19	33	0	0	0	0	0	0	0	64.62	0	0	13.2
2014	9	9	14	28	19	33	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	9	14	38	19	33	0	0	0	0	0	0	0	64.65	0	0	13.2
2014	9	9	14	48	19	33	0	0	0	0	0	0	0	64.69	0	0	13.2
2014	9	9	14	58	19	33	0	0	0	0	0	0	0	64.69	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	15	8	19	33	0	0	0	0	0	0	0	64.71	0	0	13
2014	9	9	15	18	19	32	0	0	0	0	0	0	0	64.72	0	0	12.8
2014	9	9	15	28	19	33	0	0	0	0	0	0	0	64.74	0	0	12.8
2014	9	9	15	38	19	34	0	0	0	0	0	0	0	64.74	0	0	12.8
2014	9	9	15	48	19	32	0	0	0	0	0	0	0	64.76	0	0	12.8
2014	9	9	15	58	19	33	0	0	0	0	0	0	0	64.78	0	0	12.8
2014	9	9	16	8	19	32	0	0	0	0	0	0	0	64.78	0	0	12.8
2014	9	9	16	18	19	33	0	0	0	0	0	0	0	64.78	0	0	12.8
2014	9	9	16	28	19	33	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	9	16	38	19	33	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	9	16	48	19	33	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	9	16	58	19	34	0	0	0	0	0	0	0	64.8	0	0	12.8
2014	9	9	17	8	19	33	0	0	0	0	0	0	0	64.78	0	0	12.6
2014	9	9	17	18	19	33	0	0	0	0	0	0	0	64.78	0	0	12.4
2014	9	9	17	28	19	33	0	0	0	0	0	0	0	64.78	0	0	12.4
2014	9	9	17	38	19	33	0	0	0	0	0	0	0	64.78	0	0	12.2
2014	9	9	17	48	19	33	0	0	0	0	0	0	0	64.78	0	0	12
2014	9	9	17	58	19	33	0	0	0	0	0	0	0	64.78	0	0	12
2014	9	9	18	8	19	33	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	9	18	18	19	34	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	9	18	28	19	33	0	0	0	0	0	0	0	64.78	0	0	11.8
2014	9	9	18	38	19	33	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	9	18	48	19	33	0	0	0	0	0	0	0	64.76	0	0	11.8
2014	9	9	18	58	19	33	0	0	0	0	0	0	0	64.74	0	0	11.8
2014	9	9	19	8	19	33	0	0	0	0	0	0	0	64.74	0	0	11.8
2014	9	9	19	18	19	33	0	0	0	0	0	0	0	64.71	0	0	11.8
2014	9	9	19	28	19	33	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	9	9	19	38	19	34	0	0	0	0	0	0	0	64.67	0	0	11.8
2014	9	9	19	48	19	33	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	9	19	58	19	34	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	9	20	8	19	34	0	0	0	0	0	0	0	64.58	0	0	11.8
2014	9	9	20	18	19	33	0	0	0	0	0	0	0	64.54	0	0	11.8
2014	9	9	20	28	19	33	0	0	0	0	0	0	0	64.51	0	0	11.8
2014	9	9	20	38	19	33	0	0	0	0	0	0	0	64.47	0	0	11.8
2014	9	9	20	48	19	33	0	0	0	0	0	0	0	64.44	0	0	11.8
2014	9	9	20	58	19	34	0	0	0	0	0	0	0	64.38	0	0	11.8
2014	9	9	21	8	19	34	0	0	0	0	0	0	0	64.33	0	0	11.8
2014	9	9	21	18	19	33	0	0	0	0	0	0	0	64.29	0	0	11.8
2014	9	9	21	28	19	34	0	0	0	0	0	0	0	64.24	0	0	11.8
2014	9	9	21	38	19	34	0	0	0	0	0	0	0	64.18	0	0	11.8
2014	9	9	21	48	19	34	0	0	0	0	0	0	0	64.15	0	0	11.8
2014	9	9	21	58	19	33	0	0	0	0	0	0	0	64.09	0	0	11.8
2014	9	9	22	8	19	33	0	0	0	0	0	0	0	64.02	0	0	11.8
2014	9	9	22	18	19	33	0	0	0	0	0	0	0	63.97	0	0	11.8
2014	9	9	22	28	19	33	0	0	0	0	0	0	0	63.91	0	0	11.8
2014	9	9	22	38	19	32	0	0	0	0	0	0	0	63.86	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	9	22	48	19	33	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	9	22	58	19	34	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	9	23	8	19	33	0	0	0	0	0	0	0	63.7	0	0	11.6
2014	9	9	23	18	19	34	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	9	23	28	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	9	23	38	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	9	23	48	19	34	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	9	23	58	19	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	10	0	8	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	10	0	18	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	10	0	28	19	33	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	10	0	38	19	33	0	0	0	0	0	0	0	63.25	0	0	11.6
2014	9	10	0	48	19	34	0	0	0	0	0	0	0	63.19	0	0	11.6
2014	9	10	0	58	19	33	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	10	1	8	19	34	0	0	0	0	0	0	0	63.1	0	0	11.6
2014	9	10	1	18	19	34	0	0	0	0	0	0	0	63.05	0	0	11.6
2014	9	10	1	28	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	10	1	38	19	33	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	10	1	48	19	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	10	1	58	19	33	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	10	2	8	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	10	2	18	19	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	10	2	28	19	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	10	2	38	19	33	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	10	2	48	19	34	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	10	2	58	19	34	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	10	3	8	19	33	0	0	0	0	0	0	0	62.44	0	0	11.6
2014	9	10	3	18	19	34	0	0	0	0	0	0	0	62.38	0	0	11.6
2014	9	10	3	28	19	33	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	10	3	38	19	34	0	0	0	0	0	0	0	62.26	0	0	11.6
2014	9	10	3	48	19	34	0	0	0	0	0	0	0	62.2	0	0	11.6
2014	9	10	3	58	19	33	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	10	4	8	19	33	0	0	0	0	0	0	0	62.1	0	0	11.6
2014	9	10	4	18	19	34	0	0	0	0	0	0	0	62.04	0	0	11.6
2014	9	10	4	28	19	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	10	4	38	19	34	0	0	0	0	0	0	0	61.93	0	0	11.6
2014	9	10	4	48	19	34	0	0	0	0	0	0	0	61.88	0	0	11.6
2014	9	10	4	58	19	34	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	10	5	8	19	33	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	10	5	18	19	34	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	10	5	28	19	33	0	0	0	0	0	0	0	61.65	0	0	11.6
2014	9	10	5	38	19	34	0	0	0	0	0	0	0	61.59	0	0	11.6
2014	9	10	5	48	19	33	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	10	5	58	19	33	0	0	0	0	0	0	0	61.47	0	0	11.6
2014	9	10	6	8	19	34	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	10	6	18	19	34	0	0	0	0	0	0	0	61.38	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	6	28	19	34	0	0	0	0	0	0	0	61.34	0	0	11.6
2014	9	10	6	38	19	33	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	10	6	48	19	34	0	0	0	0	0	0	0	61.23	0	0	11.6
2014	9	10	6	58	19	34	0	0	0	0	0	0	0	61.2	0	0	11.6
2014	9	10	7	8	19	33	0	0	0	0	0	0	0	61.14	0	0	11.6
2014	9	10	7	18	19	33	0	0	0	0	0	0	0	61.11	0	0	11.6
2014	9	10	7	28	19	34	0	0	0	0	0	0	0	61.05	0	0	11.8
2014	9	10	7	38	19	33	0	0	0	0	0	0	0	61.02	0	0	12
2014	9	10	7	48	19	33	0	0	0	0	0	0	0	60.98	0	0	12.2
2014	9	10	7	58	19	33	0	0	0	0	0	0	0	60.96	0	0	12.4
2014	9	10	8	8	19	34	0	0	0	0	0	0	0	60.94	0	0	12.6
2014	9	10	8	18	19	33	0	0	0	0	0	0	0	60.94	0	0	12.6
2014	9	10	8	28	19	33	0	0	0	0	0	0	0	60.98	0	0	12.6
2014	9	10	8	38	19	33	0	0	0	0	0	0	0	61.03	0	0	12.6
2014	9	10	8	48	19	34	0	0	0	0	0	0	0	61.07	0	0	12.8
2014	9	10	8	58	19	33	0	0	0	0	0	0	0	61.09	0	0	12.8
2014	9	10	9	8	19	34	0	0	0	0	0	0	0	61.12	0	0	12.8
2014	9	10	9	18	19	34	0	0	0	0	0	0	0	61.16	0	0	12.8
2014	9	10	9	28	19	34	0	0	0	0	0	0	0	61.21	0	0	13
2014	9	10	9	38	19	34	0	0	0	0	0	0	0	61.25	0	0	13
2014	9	10	9	48	19	34	0	0	0	0	0	0	0	61.3	0	0	13.2
2014	9	10	9	58	19	34	0	0	0	0	0	0	0	61.36	0	0	13.2
2014	9	10	10	8	19	33	0	0	0	0	0	0	0	61.43	0	0	13.2
2014	9	10	10	18	19	34	0	0	0	0	0	0	0	61.5	0	0	13.2
2014	9	10	10	28	19	33	0	0	0	0	0	0	0	61.57	0	0	13.2
2014	9	10	10	38	19	34	0	0	0	0	0	0	0	61.63	0	0	13.2
2014	9	10	10	48	19	34	0	0	0	0	0	0	0	61.7	0	0	13.2
2014	9	10	10	58	19	34	0	0	0	0	0	0	0	61.77	0	0	13.2
2014	9	10	11	8	19	34	0	0	0	0	0	0	0	61.84	0	0	13
2014	9	10	11	18	19	33	0	0	0	0	0	0	0	61.92	0	0	13
2014	9	10	11	28	19	33	0	0	0	0	0	0	0	61.99	0	0	13
2014	9	10	11	38	19	34	0	0	0	0	0	0	0	62.06	0	0	13.6
2014	9	10	11	48	19	33	0	0	0	0	0	0	0	62.13	0	0	13.4
2014	9	10	11	58	19	34	0	0	0	0	0	0	0	62.2	0	0	13.4
2014	9	10	12	8	19	34	0	0	0	0	0	0	0	62.28	0	0	13.4
2014	9	10	12	18	19	33	0	0	0	0	0	0	0	62.35	0	0	13
2014	9	10	12	28	19	33	0	0	0	0	0	0	0	62.42	0	0	13.6
2014	9	10	12	38	19	33	0	0	0	0	0	0	0	62.47	0	0	13.8
2014	9	10	12	48	19	33	0	0	0	0	0	0	0	62.53	0	0	13
2014	9	10	12	58	19	33	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	10	13	8	19	34	0	0	0	0	0	0	0	62.65	0	0	13.4
2014	9	10	13	18	19	33	0	0	0	0	0	0	0	62.71	0	0	13.4
2014	9	10	13	28	19	33	0	0	0	0	0	0	0	62.74	0	0	13.6
2014	9	10	13	38	19	33	0	0	0	0	0	0	0	62.8	0	0	13.6
2014	9	10	13	48	19	34	0	0	0	0	0	0	0	62.85	0	0	13.4
2014	9	10	13	58	19	34	0	0	0	0	0	0	0	62.89	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	14	8	19	33	0	0	0	0	0	0	0	62.92	0	0	13.4
2014	9	10	14	18	19	34	0	0	0	0	0	0	0	62.98	0	0	13.2
2014	9	10	14	28	19	34	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	10	14	38	19	33	0	0	0	0	0	0	0	63.03	0	0	13.4
2014	9	10	14	48	19	33	0	0	0	0	0	0	0	63.07	0	0	13.4
2014	9	10	14	58	19	33	0	0	0	0	0	0	0	63.1	0	0	13.2
2014	9	10	15	8	19	34	0	0	0	0	0	0	0	63.14	0	0	13.2
2014	9	10	15	18	19	33	0	0	0	0	0	0	0	63.16	0	0	13.2
2014	9	10	15	28	19	33	0	0	0	0	0	0	0	63.18	0	0	13.2
2014	9	10	15	38	19	33	0	0	0	0	0	0	0	63.19	0	0	13.2
2014	9	10	15	48	19	33	0	0	0	0	0	0	0	63.21	0	0	13
2014	9	10	15	58	19	33	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	10	16	8	19	33	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	10	16	18	19	33	0	0	0	0	0	0	0	63.25	0	0	13
2014	9	10	16	28	19	34	0	0	0	0	0	0	0	63.25	0	0	13
2014	9	10	16	38	19	33	0	0	0	0	0	0	0	63.27	0	0	13
2014	9	10	16	48	19	33	0	0	0	0	0	0	0	63.28	0	0	13
2014	9	10	16	58	19	34	0	0	0	0	0	0	0	63.28	0	0	13
2014	9	10	17	8	19	34	0	0	0	0	0	0	0	63.28	0	0	12.8
2014	9	10	17	18	19	33	0	0	0	0	0	0	0	63.28	0	0	12.4
2014	9	10	17	28	19	33	0	0	0	0	0	0	0	63.3	0	0	12.2
2014	9	10	17	38	19	33	0	0	0	0	0	0	0	63.28	0	0	11.8
2014	9	10	17	48	19	33	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	10	17	58	19	33	0	0	0	0	0	0	0	63.28	0	0	11.4
2014	9	10	18	8	19	33	0	0	0	0	0	0	0	63.3	0	0	11.2
2014	9	10	18	18	19	33	0	0	0	0	0	0	0	63.3	0	0	11.2
2014	9	10	18	28	19	33	0	0	0	0	0	0	0	63.32	0	0	11.2
2014	9	10	18	38	19	33	0	0	0	0	0	0	0	63.32	0	0	11.2
2014	9	10	18	48	19	33	0	0	0	0	0	0	0	63.32	0	0	11
2014	9	10	18	58	19	33	0	0	0	0	0	0	0	63.32	0	0	11
2014	9	10	19	8	19	34	0	0	0	0	0	0	0	63.32	0	0	10.8
2014	9	10	19	18	19	33	0	0	0	0	0	0	0	63.3	0	0	11.8
2014	9	10	19	28	19	33	0	0	0	0	0	0	0	63.3	0	0	11.8
2014	9	10	19	38	19	33	0	0	0	0	0	0	0	63.28	0	0	11.8
2014	9	10	19	48	19	33	0	0	0	0	0	0	0	63.27	0	0	11.8
2014	9	10	19	58	19	33	0	0	0	0	0	0	0	63.27	0	0	11.8
2014	9	10	20	8	19	33	0	0	0	0	0	0	0	63.25	0	0	11.8
2014	9	10	20	18	19	34	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	10	20	28	19	33	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	10	20	38	19	34	0	0	0	0	0	0	0	63.21	0	0	10.8
2014	9	10	20	48	19	33	0	0	0	0	0	0	0	63.19	0	0	10.8
2014	9	10	20	58	19	33	0	0	0	0	0	0	0	63.18	0	0	10.8
2014	9	10	21	8	19	34	0	0	0	0	0	0	0	63.16	0	0	10.8
2014	9	10	21	18	19	34	0	0	0	0	0	0	0	63.12	0	0	11.6
2014	9	10	21	28	19	33	0	0	0	0	0	0	0	63.1	0	0	11.6
2014	9	10	21	38	19	33	0	0	0	0	0	0	0	63.09	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	10	21	48	19	33	0	0	0	0	0	0	0	63.05	0	0	11.6
2014	9	10	21	58	19	32	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	10	22	8	19	32	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	10	22	18	19	33	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	10	22	28	19	33	0	0	0	0	0	0	0	62.92	0	0	11.6
2014	9	10	22	38	19	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	10	22	48	19	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	10	22	58	19	34	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	10	23	8	19	34	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	10	23	18	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	10	23	28	19	33	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	10	23	38	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	10	23	48	19	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	10	23	58	19	34	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	11	0	8	19	34	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	11	0	18	19	33	0	0	0	0	0	0	0	62.55	0	0	11.6
2014	9	11	0	28	19	33	0	0	0	0	0	0	0	62.51	0	0	11.6
2014	9	11	0	38	19	33	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	11	0	48	19	33	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	11	0	58	19	34	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	11	1	8	19	34	0	0	0	0	0	0	0	62.35	0	0	11.6
2014	9	11	1	18	19	33	0	0	0	0	0	0	0	62.31	0	0	11.6
2014	9	11	1	28	19	33	0	0	0	0	0	0	0	62.26	0	0	11.6
2014	9	11	1	38	19	34	0	0	0	0	0	0	0	62.22	0	0	11.6
2014	9	11	1	48	19	33	0	0	0	0	0	0	0	62.19	0	0	11.6
2014	9	11	1	58	19	33	0	0	0	0	0	0	0	62.13	0	0	11.6
2014	9	11	2	8	19	33	0	0	0	0	0	0	0	62.1	0	0	11.6
2014	9	11	2	18	19	33	0	0	0	0	0	0	0	62.04	0	0	11.6
2014	9	11	2	28	19	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	11	2	38	19	33	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	11	2	48	19	33	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	11	2	58	19	33	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	11	3	8	19	33	0	0	0	0	0	0	0	61.83	0	0	11.6
2014	9	11	3	18	19	33	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	11	3	28	19	33	0	0	0	0	0	0	0	61.72	0	0	11.6
2014	9	11	3	38	19	33	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	11	3	48	19	34	0	0	0	0	0	0	0	61.63	0	0	11.6
2014	9	11	3	58	19	34	0	0	0	0	0	0	0	61.59	0	0	11.6
2014	9	11	4	8	19	33	0	0	0	0	0	0	0	61.54	0	0	11.6
2014	9	11	4	18	19	34	0	0	0	0	0	0	0	61.48	0	0	11.6
2014	9	11	4	28	19	33	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	11	4	38	19	33	0	0	0	0	0	0	0	61.38	0	0	11.6
2014	9	11	4	48	19	33	0	0	0	0	0	0	0	61.34	0	0	11.6
2014	9	11	4	58	19	34	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	11	5	8	19	34	0	0	0	0	0	0	0	61.23	0	0	11.6
2014	9	11	5	18	19	34	0	0	0	0	0	0	0	61.2	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	5	28	19	34	0	0	0	0	0	0	0	61.14	0	0	11.6
2014	9	11	5	38	19	34	0	0	0	0	0	0	0	61.11	0	0	11.6
2014	9	11	5	48	19	34	0	0	0	0	0	0	0	61.05	0	0	11.6
2014	9	11	5	58	19	34	0	0	0	0	0	0	0	61	0	0	11.6
2014	9	11	6	8	19	33	0	0	0	0	0	0	0	60.96	0	0	11.6
2014	9	11	6	18	19	33	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	11	6	28	19	34	0	0	0	0	0	0	0	60.87	0	0	11.6
2014	9	11	6	38	19	33	0	0	0	0	0	0	0	60.84	0	0	11.6
2014	9	11	6	48	19	34	0	0	0	0	0	0	0	60.8	0	0	11.6
2014	9	11	6	58	19	33	0	0	0	0	0	0	0	60.75	0	0	11.6
2014	9	11	7	8	19	34	0	0	0	0	0	0	0	60.71	0	0	11.6
2014	9	11	7	18	19	33	0	0	0	0	0	0	0	60.67	0	0	11.6
2014	9	11	7	28	19	34	0	0	0	0	0	0	0	60.64	0	0	11.8
2014	9	11	7	38	19	35	0	0	0	0	0	0	0	60.6	0	0	12
2014	9	11	7	48	19	34	0	0	0	0	0	0	0	60.58	0	0	12.2
2014	9	11	7	58	19	34	0	0	0	0	0	0	0	60.57	0	0	12.4
2014	9	11	8	8	19	34	0	0	0	0	0	0	0	60.55	0	0	12.6
2014	9	11	8	18	19	34	0	0	0	0	0	0	0	60.55	0	0	12.6
2014	9	11	8	28	19	34	0	0	0	0	0	0	0	60.57	0	0	12.6
2014	9	11	8	38	19	34	0	0	0	0	0	0	0	60.64	0	0	13.2
2014	9	11	8	48	19	33	0	0	0	0	0	0	0	60.66	0	0	13.2
2014	9	11	8	58	19	34	0	0	0	0	0	0	0	60.69	0	0	13.2
2014	9	11	9	8	19	34	0	0	0	0	0	0	0	60.73	0	0	13.4
2014	9	11	9	18	19	33	0	0	0	0	0	0	0	60.76	0	0	13.6
2014	9	11	9	28	19	34	0	0	0	0	0	0	0	60.8	0	0	14
2014	9	11	9	38	19	34	0	0	0	0	0	0	0	60.85	0	0	13.8
2014	9	11	9	48	19	33	0	0	0	0	0	0	0	60.91	0	0	13.8
2014	9	11	9	58	19	33	0	0	0	0	0	0	0	60.96	0	0	14
2014	9	11	10	8	19	34	0	0	0	0	0	0	0	61.02	0	0	14
2014	9	11	10	18	19	34	0	0	0	0	0	0	0	61.09	0	0	14
2014	9	11	10	28	19	34	0	0	0	0	0	0	0	61.14	0	0	14
2014	9	11	10	38	19	34	0	0	0	0	0	0	0	61.2	0	0	14
2014	9	11	10	48	19	33	0	0	0	0	0	0	0	61.27	0	0	14
2014	9	11	10	58	19	34	0	0	0	0	0	0	0	61.34	0	0	14.2
2014	9	11	11	8	19	34	0	0	0	0	0	0	0	61.41	0	0	14.2
2014	9	11	11	18	19	33	0	0	0	0	0	0	0	61.48	0	0	13.6
2014	9	11	11	28	19	34	0	0	0	0	0	0	0	61.56	0	0	13.6
2014	9	11	11	38	19	33	0	0	0	0	0	0	0	61.63	0	0	13.6
2014	9	11	11	48	19	34	0	0	0	0	0	0	0	61.7	0	0	13.6
2014	9	11	11	58	19	34	0	0	0	0	0	0	0	61.77	0	0	13.4
2014	9	11	12	8	19	33	0	0	0	0	0	0	0	61.83	0	0	13.4
2014	9	11	12	18	19	33	0	0	0	0	0	0	0	61.9	0	0	13.4
2014	9	11	12	28	19	33	0	0	0	0	0	0	0	61.95	0	0	13.4
2014	9	11	12	38	19	33	0	0	0	0	0	0	0	62.02	0	0	13.4
2014	9	11	12	48	19	33	0	0	0	0	0	0	0	62.08	0	0	13.4
2014	9	11	12	58	19	33	0	0	0	0	0	0	0	62.15	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	13	8	19	34	0	0	0	0	0	0	0	62.22	0	0	13.4
2014	9	11	13	18	19	34	0	0	0	0	0	0	0	62.26	0	0	13.4
2014	9	11	13	28	19	33	0	0	0	0	0	0	0	62.29	0	0	13.4
2014	9	11	13	38	19	34	0	0	0	0	0	0	0	62.35	0	0	13.4
2014	9	11	13	48	19	33	0	0	0	0	0	0	0	62.4	0	0	13.2
2014	9	11	13	58	19	34	0	0	0	0	0	0	0	62.46	0	0	13.2
2014	9	11	14	8	19	33	0	0	0	0	0	0	0	62.49	0	0	13.2
2014	9	11	14	18	19	33	0	0	0	0	0	0	0	62.53	0	0	13.2
2014	9	11	14	28	19	34	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	11	14	38	19	33	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	11	14	48	19	33	0	0	0	0	0	0	0	62.65	0	0	13.2
2014	9	11	14	58	19	34	0	0	0	0	0	0	0	62.67	0	0	13.2
2014	9	11	15	8	19	33	0	0	0	0	0	0	0	62.69	0	0	13.2
2014	9	11	15	18	19	33	0	0	0	0	0	0	0	62.73	0	0	13
2014	9	11	15	28	19	33	0	0	0	0	0	0	0	62.74	0	0	13
2014	9	11	15	38	19	33	0	0	0	0	0	0	0	62.76	0	0	13
2014	9	11	15	48	19	34	0	0	0	0	0	0	0	62.78	0	0	13
2014	9	11	15	58	19	33	0	0	0	0	0	0	0	62.8	0	0	13
2014	9	11	16	8	19	34	0	0	0	0	0	0	0	62.82	0	0	12.4
2014	9	11	16	18	19	33	0	0	0	0	0	0	0	62.83	0	0	13
2014	9	11	16	28	19	33	0	0	0	0	0	0	0	62.85	0	0	12.8
2014	9	11	16	38	19	33	0	0	0	0	0	0	0	62.85	0	0	12.8
2014	9	11	16	48	19	33	0	0	0	0	0	0	0	62.87	0	0	12.8
2014	9	11	16	58	19	33	0	0	0	0	0	0	0	62.87	0	0	12.8
2014	9	11	17	8	19	34	0	0	0	0	0	0	0	62.87	0	0	12.4
2014	9	11	17	18	19	33	0	0	0	0	0	0	0	62.85	0	0	12.2
2014	9	11	17	28	19	33	0	0	0	0	0	0	0	62.89	0	0	12
2014	9	11	17	38	19	33	0	0	0	0	0	0	0	62.87	0	0	11.8
2014	9	11	17	48	19	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	11	17	58	19	33	0	0	0	0	0	0	0	62.89	0	0	11.4
2014	9	11	18	8	19	34	0	0	0	0	0	0	0	62.89	0	0	11.2
2014	9	11	18	18	19	34	0	0	0	0	0	0	0	62.91	0	0	11.2
2014	9	11	18	28	19	33	0	0	0	0	0	0	0	62.91	0	0	11.2
2014	9	11	18	38	19	33	0	0	0	0	0	0	0	62.92	0	0	11
2014	9	11	18	48	19	33	0	0	0	0	0	0	0	62.91	0	0	10.8
2014	9	11	18	58	19	33	0	0	0	0	0	0	0	62.91	0	0	10.8
2014	9	11	19	8	19	34	0	0	0	0	0	0	0	62.91	0	0	10.8
2014	9	11	19	18	19	33	0	0	0	0	0	0	0	62.91	0	0	11
2014	9	11	19	28	19	33	0	0	0	0	0	0	0	62.89	0	0	11
2014	9	11	19	38	19	33	0	0	0	0	0	0	0	62.87	0	0	11
2014	9	11	19	48	19	33	0	0	0	0	0	0	0	62.87	0	0	11
2014	9	11	19	58	19	33	0	0	0	0	0	0	0	62.85	0	0	11
2014	9	11	20	8	19	34	0	0	0	0	0	0	0	62.85	0	0	11
2014	9	11	20	18	19	33	0	0	0	0	0	0	0	62.83	0	0	11
2014	9	11	20	28	19	34	0	0	0	0	0	0	0	62.82	0	0	11
2014	9	11	20	38	19	34	0	0	0	0	0	0	0	62.8	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	11	20	48	19	34	0	0	0	0	0	0	0	62.78	0	0	10.8
2014	9	11	20	58	19	33	0	0	0	0	0	0	0	62.76	0	0	10.8
2014	9	11	21	8	19	34	0	0	0	0	0	0	0	62.73	0	0	10.8
2014	9	11	21	18	19	33	0	0	0	0	0	0	0	62.69	0	0	11.2
2014	9	11	21	28	19	34	0	0	0	0	0	0	0	62.69	0	0	11
2014	9	11	21	38	19	33	0	0	0	0	0	0	0	62.65	0	0	11
2014	9	11	21	48	19	33	0	0	0	0	0	0	0	62.62	0	0	11
2014	9	11	21	58	19	33	0	0	0	0	0	0	0	62.6	0	0	11
2014	9	11	22	8	19	33	0	0	0	0	0	0	0	62.56	0	0	11
2014	9	11	22	18	19	33	0	0	0	0	0	0	0	62.55	0	0	10.8
2014	9	11	22	28	19	33	0	0	0	0	0	0	0	62.51	0	0	10.6
2014	9	11	22	38	19	33	0	0	0	0	0	0	0	62.47	0	0	10.6
2014	9	11	22	48	19	34	0	0	0	0	0	0	0	62.46	0	0	10.6
2014	9	11	22	58	19	34	0	0	0	0	0	0	0	62.42	0	0	10.6
2014	9	11	23	8	19	33	0	0	0	0	0	0	0	62.4	0	0	10.6
2014	9	11	23	18	19	33	0	0	0	0	0	0	0	62.37	0	0	10.6
2014	9	11	23	28	19	33	0	0	0	0	0	0	0	62.35	0	0	10.6
2014	9	11	23	38	19	34	0	0	0	0	0	0	0	62.31	0	0	10.6
2014	9	11	23	48	19	33	0	0	0	0	0	0	0	62.28	0	0	10.6
2014	9	11	23	58	19	34	0	0	0	0	0	0	0	62.26	0	0	10.6
2014	9	12	0	8	19	34	0	0	0	0	0	0	0	62.22	0	0	10.6
2014	9	12	0	18	19	33	0	0	0	0	0	0	0	62.17	0	0	11.6
2014	9	12	0	28	19	34	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	12	0	38	19	33	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	12	0	48	19	34	0	0	0	0	0	0	0	62.06	0	0	11.6
2014	9	12	0	58	19	34	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	12	1	8	19	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	12	1	18	19	33	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	12	1	28	19	34	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	12	1	38	19	34	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	12	1	48	19	34	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	12	1	58	19	33	0	0	0	0	0	0	0	61.77	0	0	11.6
2014	9	12	2	8	19	34	0	0	0	0	0	0	0	61.74	0	0	11.6
2014	9	12	2	18	19	34	0	0	0	0	0	0	0	61.68	0	0	11.6
2014	9	12	2	28	19	34	0	0	0	0	0	0	0	61.65	0	0	11.6
2014	9	12	2	38	19	34	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	12	2	48	19	34	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	12	2	58	19	34	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	12	3	8	19	33	0	0	0	0	0	0	0	61.48	0	0	11.6
2014	9	12	3	18	19	34	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	12	3	28	19	34	0	0	0	0	0	0	0	61.39	0	0	11.6
2014	9	12	3	38	19	34	0	0	0	0	0	0	0	61.34	0	0	11.6
2014	9	12	3	48	19	34	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	12	3	58	19	33	0	0	0	0	0	0	0	61.25	0	0	11.6
2014	9	12	4	8	19	34	0	0	0	0	0	0	0	61.21	0	0	11.6
2014	9	12	4	18	19	34	0	0	0	0	0	0	0	61.16	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	4	28	19	33	0	0	0	0	0	0	0	61.12	0	0	11.6
2014	9	12	4	38	19	34	0	0	0	0	0	0	0	61.07	0	0	11.6
2014	9	12	4	48	19	34	0	0	0	0	0	0	0	61.03	0	0	11.6
2014	9	12	4	58	19	34	0	0	0	0	0	0	0	61	0	0	11.6
2014	9	12	5	8	19	34	0	0	0	0	0	0	0	60.94	0	0	11.6
2014	9	12	5	18	19	34	0	0	0	0	0	0	0	60.91	0	0	11.6
2014	9	12	5	28	19	34	0	0	0	0	0	0	0	60.85	0	0	11.6
2014	9	12	5	38	19	33	0	0	0	0	0	0	0	60.82	0	0	11.6
2014	9	12	5	48	19	33	0	0	0	0	0	0	0	60.78	0	0	11.6
2014	9	12	5	58	19	34	0	0	0	0	0	0	0	60.75	0	0	11.6
2014	9	12	6	8	19	34	0	0	0	0	0	0	0	60.71	0	0	11.6
2014	9	12	6	18	19	34	0	0	0	0	0	0	0	60.67	0	0	11.6
2014	9	12	6	28	19	34	0	0	0	0	0	0	0	60.62	0	0	11.6
2014	9	12	6	38	19	34	0	0	0	0	0	0	0	60.6	0	0	11.6
2014	9	12	6	48	19	33	0	0	0	0	0	0	0	60.57	0	0	11.6
2014	9	12	6	58	19	33	0	0	0	0	0	0	0	60.51	0	0	11.6
2014	9	12	7	8	19	34	0	0	0	0	0	0	0	60.48	0	0	11.6
2014	9	12	7	18	19	33	0	0	0	0	0	0	0	60.46	0	0	11.6
2014	9	12	7	28	19	34	0	0	0	0	0	0	0	60.42	0	0	11.8
2014	9	12	7	38	19	34	0	0	0	0	0	0	0	60.4	0	0	12
2014	9	12	7	48	19	34	0	0	0	0	0	0	0	60.37	0	0	12
2014	9	12	7	58	19	34	0	0	0	0	0	0	0	60.37	0	0	12.2
2014	9	12	8	8	19	33	0	0	0	0	0	0	0	60.37	0	0	12.4
2014	9	12	8	18	19	34	0	0	0	0	0	0	0	60.35	0	0	12.4
2014	9	12	8	28	19	34	0	0	0	0	0	0	0	60.39	0	0	12.6
2014	9	12	8	38	19	34	0	0	0	0	0	0	0	60.44	0	0	12.6
2014	9	12	8	48	19	34	0	0	0	0	0	0	0	60.48	0	0	12.6
2014	9	12	8	58	19	34	0	0	0	0	0	0	0	60.51	0	0	12.6
2014	9	12	9	8	19	33	0	0	0	0	0	0	0	60.55	0	0	12.6
2014	9	12	9	18	19	34	0	0	0	0	0	0	0	60.58	0	0	12.8
2014	9	12	9	28	19	34	0	0	0	0	0	0	0	60.64	0	0	12.8
2014	9	12	9	38	19	34	0	0	0	0	0	0	0	60.69	0	0	12.8
2014	9	12	9	48	19	34	0	0	0	0	0	0	0	60.75	0	0	12.8
2014	9	12	9	58	19	34	0	0	0	0	0	0	0	60.8	0	0	13
2014	9	12	10	8	19	34	0	0	0	0	0	0	0	60.85	0	0	13
2014	9	12	10	18	19	33	0	0	0	0	0	0	0	60.94	0	0	13.2
2014	9	12	10	28	19	34	0	0	0	0	0	0	0	61.03	0	0	13.2
2014	9	12	10	38	19	34	0	0	0	0	0	0	0	61.09	0	0	13
2014	9	12	10	48	19	33	0	0	0	0	0	0	0	61.14	0	0	13
2014	9	12	10	58	19	34	0	0	0	0	0	0	0	61.23	0	0	13
2014	9	12	11	8	19	34	0	0	0	0	0	0	0	61.29	0	0	13
2014	9	12	11	18	19	33	0	0	0	0	0	0	0	61.36	0	0	13
2014	9	12	11	28	19	33	0	0	0	0	0	0	0	61.45	0	0	13.2
2014	9	12	11	38	19	34	0	0	0	0	0	0	0	61.5	0	0	13.2
2014	9	12	11	48	19	34	0	0	0	0	0	0	0	61.57	0	0	13.2
2014	9	12	11	58	19	34	0	0	0	0	0	0	0	61.63	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	12	8	19	34	0	0	0	0	0	0	0	61.68	0	0	13
2014	9	12	12	18	19	34	0	0	0	0	0	0	0	61.75	0	0	13.4
2014	9	12	12	28	19	33	0	0	0	0	0	0	0	61.83	0	0	13.4
2014	9	12	12	38	19	33	0	0	0	0	0	0	0	61.88	0	0	13.2
2014	9	12	12	48	19	34	0	0	0	0	0	0	0	61.95	0	0	13.4
2014	9	12	12	58	19	33	0	0	0	0	0	0	0	62.01	0	0	13.2
2014	9	12	13	8	19	34	0	0	0	0	0	0	0	62.06	0	0	13.4
2014	9	12	13	18	19	34	0	0	0	0	0	0	0	62.11	0	0	13.2
2014	9	12	13	28	19	33	0	0	0	0	0	0	0	62.17	0	0	13
2014	9	12	13	38	19	34	0	0	0	0	0	0	0	62.2	0	0	13.2
2014	9	12	13	48	19	34	0	0	0	0	0	0	0	62.26	0	0	13.2
2014	9	12	13	58	19	33	0	0	0	0	0	0	0	62.29	0	0	13.2
2014	9	12	14	8	19	33	0	0	0	0	0	0	0	62.37	0	0	13.2
2014	9	12	14	18	19	33	0	0	0	0	0	0	0	62.44	0	0	13.2
2014	9	12	14	28	19	33	0	0	0	0	0	0	0	62.47	0	0	13.2
2014	9	12	14	38	19	34	0	0	0	0	0	0	0	62.49	0	0	13.2
2014	9	12	14	48	19	33	0	0	0	0	0	0	0	62.53	0	0	13.2
2014	9	12	14	58	19	33	0	0	0	0	0	0	0	62.55	0	0	13
2014	9	12	15	8	19	34	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	12	15	18	19	34	0	0	0	0	0	0	0	62.58	0	0	12.8
2014	9	12	15	28	19	34	0	0	0	0	0	0	0	62.62	0	0	12.8
2014	9	12	15	38	19	34	0	0	0	0	0	0	0	62.64	0	0	12.8
2014	9	12	15	48	19	34	0	0	0	0	0	0	0	62.65	0	0	12.8
2014	9	12	15	58	19	34	0	0	0	0	0	0	0	62.65	0	0	12.8
2014	9	12	16	8	19	33	0	0	0	0	0	0	0	62.67	0	0	12.8
2014	9	12	16	18	19	34	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	12	16	28	19	34	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	12	16	38	19	33	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	12	16	48	19	33	0	0	0	0	0	0	0	62.71	0	0	12.6
2014	9	12	16	58	19	33	0	0	0	0	0	0	0	62.71	0	0	12.6
2014	9	12	17	8	19	33	0	0	0	0	0	0	0	62.71	0	0	12.4
2014	9	12	17	18	19	33	0	0	0	0	0	0	0	62.69	0	0	12.4
2014	9	12	17	28	19	33	0	0	0	0	0	0	0	62.71	0	0	12.2
2014	9	12	17	38	19	33	0	0	0	0	0	0	0	62.69	0	0	12
2014	9	12	17	48	19	33	0	0	0	0	0	0	0	62.71	0	0	12
2014	9	12	17	58	19	33	0	0	0	0	0	0	0	62.71	0	0	11.8
2014	9	12	18	8	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	18	18	19	34	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	18	28	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	18	38	19	33	0	0	0	0	0	0	0	62.74	0	0	11.8
2014	9	12	18	48	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	18	58	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	19	8	19	33	0	0	0	0	0	0	0	62.74	0	0	11.8
2014	9	12	19	18	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	19	28	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	19	38	19	33	0	0	0	0	0	0	0	62.73	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	12	19	48	19	34	0	0	0	0	0	0	0	62.73	0	0	11.8
2014	9	12	19	58	19	33	0	0	0	0	0	0	0	62.71	0	0	11.8
2014	9	12	20	8	19	34	0	0	0	0	0	0	0	62.69	0	0	11.8
2014	9	12	20	18	19	33	0	0	0	0	0	0	0	62.69	0	0	11.8
2014	9	12	20	28	19	34	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	12	20	38	19	33	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	12	20	48	19	33	0	0	0	0	0	0	0	62.64	0	0	11.8
2014	9	12	20	58	19	34	0	0	0	0	0	0	0	62.62	0	0	11.8
2014	9	12	21	8	19	33	0	0	0	0	0	0	0	62.58	0	0	11.6
2014	9	12	21	18	19	33	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	12	21	28	19	33	0	0	0	0	0	0	0	62.55	0	0	11.6
2014	9	12	21	38	19	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	12	21	48	19	34	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	12	21	58	19	33	0	0	0	0	0	0	0	62.47	0	0	11.6
2014	9	12	22	8	19	33	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	12	22	18	19	34	0	0	0	0	0	0	0	62.44	0	0	11.6
2014	9	12	22	28	19	34	0	0	0	0	0	0	0	62.42	0	0	11.6
2014	9	12	22	38	19	33	0	0	0	0	0	0	0	62.38	0	0	11.6
2014	9	12	22	48	19	34	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	12	22	58	19	34	0	0	0	0	0	0	0	62.35	0	0	11.6
2014	9	12	23	8	19	34	0	0	0	0	0	0	0	62.31	0	0	11.6
2014	9	12	23	18	19	34	0	0	0	0	0	0	0	62.29	0	0	11.6
2014	9	12	23	28	19	33	0	0	0	0	0	0	0	62.26	0	0	11.6
2014	9	12	23	38	19	33	0	0	0	0	0	0	0	62.24	0	0	11.6
2014	9	12	23	48	19	34	0	0	0	0	0	0	0	62.2	0	0	11.6
2014	9	12	23	58	19	33	0	0	0	0	0	0	0	62.19	0	0	11.6
2014	9	13	0	8	19	33	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	13	0	18	19	33	0	0	0	0	0	0	0	62.13	0	0	11.6
2014	9	13	0	28	19	34	0	0	0	0	0	0	0	62.1	0	0	11.6
2014	9	13	0	38	19	33	0	0	0	0	0	0	0	62.06	0	0	11.6
2014	9	13	0	48	19	34	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	13	0	58	19	33	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	13	1	8	19	33	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	13	1	18	19	34	0	0	0	0	0	0	0	61.92	0	0	11.6
2014	9	13	1	28	19	34	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	13	1	38	19	33	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	13	1	48	19	34	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	13	1	58	19	34	0	0	0	0	0	0	0	61.77	0	0	11.6
2014	9	13	2	8	19	34	0	0	0	0	0	0	0	61.74	0	0	11.6
2014	9	13	2	18	19	34	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	13	2	28	19	34	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	13	2	38	19	34	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	13	2	48	19	33	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	13	2	58	19	33	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	13	3	8	19	34	0	0	0	0	0	0	0	61.48	0	0	11.6
2014	9	13	3	18	19	34	0	0	0	0	0	0	0	61.45	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	3	28	19	33	0	0	0	0	0	0	0	61.41	0	0	11.6
2014	9	13	3	38	19	34	0	0	0	0	0	0	0	61.36	0	0	11.6
2014	9	13	3	48	19	34	0	0	0	0	0	0	0	61.3	0	0	11.6
2014	9	13	3	58	19	33	0	0	0	0	0	0	0	61.27	0	0	11.6
2014	9	13	4	8	19	34	0	0	0	0	0	0	0	61.23	0	0	11.6
2014	9	13	4	18	19	33	0	0	0	0	0	0	0	61.2	0	0	11.6
2014	9	13	4	28	19	33	0	0	0	0	0	0	0	61.16	0	0	11.6
2014	9	13	4	38	19	33	0	0	0	0	0	0	0	61.12	0	0	11.6
2014	9	13	4	48	19	34	0	0	0	0	0	0	0	61.09	0	0	11.6
2014	9	13	4	58	19	34	0	0	0	0	0	0	0	61.05	0	0	11.6
2014	9	13	5	8	19	34	0	0	0	0	0	0	0	61.02	0	0	11.6
2014	9	13	5	18	19	34	0	0	0	0	0	0	0	60.98	0	0	11.6
2014	9	13	5	28	19	34	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	13	5	38	19	34	0	0	0	0	0	0	0	60.89	0	0	11.6
2014	9	13	5	48	19	33	0	0	0	0	0	0	0	60.85	0	0	11.6
2014	9	13	5	58	19	34	0	0	0	0	0	0	0	60.8	0	0	11.6
2014	9	13	6	8	19	34	0	0	0	0	0	0	0	60.76	0	0	11.6
2014	9	13	6	18	19	34	0	0	0	0	0	0	0	60.73	0	0	11.6
2014	9	13	6	28	19	34	0	0	0	0	0	0	0	60.69	0	0	11.6
2014	9	13	6	38	19	34	0	0	0	0	0	0	0	60.66	0	0	11.6
2014	9	13	6	48	19	34	0	0	0	0	0	0	0	60.62	0	0	11.6
2014	9	13	6	58	19	33	0	0	0	0	0	0	0	60.58	0	0	11.6
2014	9	13	7	8	19	34	0	0	0	0	0	0	0	60.55	0	0	11.6
2014	9	13	7	18	19	34	0	0	0	0	0	0	0	60.53	0	0	11.6
2014	9	13	7	28	19	34	0	0	0	0	0	0	0	60.49	0	0	11.6
2014	9	13	7	38	19	34	0	0	0	0	0	0	0	60.48	0	0	11.8
2014	9	13	7	48	19	34	0	0	0	0	0	0	0	60.44	0	0	12
2014	9	13	7	58	19	33	0	0	0	0	0	0	0	60.44	0	0	12.2
2014	9	13	8	8	19	33	0	0	0	0	0	0	0	60.42	0	0	12.4
2014	9	13	8	18	19	33	0	0	0	0	0	0	0	60.42	0	0	12.4
2014	9	13	8	28	19	33	0	0	0	0	0	0	0	60.44	0	0	12.4
2014	9	13	8	38	19	33	0	0	0	0	0	0	0	60.53	0	0	12.4
2014	9	13	8	48	19	34	0	0	0	0	0	0	0	60.57	0	0	12.6
2014	9	13	8	58	19	34	0	0	0	0	0	0	0	60.6	0	0	12.6
2014	9	13	9	8	19	33	0	0	0	0	0	0	0	60.64	0	0	12.6
2014	9	13	9	18	19	34	0	0	0	0	0	0	0	60.69	0	0	12.6
2014	9	13	9	28	19	34	0	0	0	0	0	0	0	60.75	0	0	12.6
2014	9	13	9	38	19	33	0	0	0	0	0	0	0	60.8	0	0	12.8
2014	9	13	9	48	19	34	0	0	0	0	0	0	0	60.85	0	0	12.8
2014	9	13	9	58	19	33	0	0	0	0	0	0	0	60.91	0	0	13
2014	9	13	10	8	19	33	0	0	0	0	0	0	0	61	0	0	13.4
2014	9	13	10	18	19	33	0	0	0	0	0	0	0	61.05	0	0	13.2
2014	9	13	10	28	19	34	0	0	0	0	0	0	0	61.12	0	0	13
2014	9	13	10	38	19	34	0	0	0	0	0	0	0	61.2	0	0	13
2014	9	13	10	48	19	34	0	0	0	0	0	0	0	61.27	0	0	13
2014	9	13	10	58	19	33	0	0	0	0	0	0	0	61.32	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	11	8	19	34	0	0	0	0	0	0	0	61.39	0	0	13.2
2014	9	13	11	18	19	34	0	0	0	0	0	0	0	61.47	0	0	13.2
2014	9	13	11	28	19	34	0	0	0	0	0	0	0	61.54	0	0	13.2
2014	9	13	11	38	19	34	0	0	0	0	0	0	0	61.61	0	0	13.2
2014	9	13	11	48	19	34	0	0	0	0	0	0	0	61.66	0	0	13.2
2014	9	13	11	58	19	34	0	0	0	0	0	0	0	61.74	0	0	13.2
2014	9	13	12	8	19	33	0	0	0	0	0	0	0	61.79	0	0	13.2
2014	9	13	12	18	19	33	0	0	0	0	0	0	0	61.86	0	0	13.2
2014	9	13	12	28	19	34	0	0	0	0	0	0	0	61.92	0	0	13.2
2014	9	13	12	38	19	34	0	0	0	0	0	0	0	61.99	0	0	13.2
2014	9	13	12	48	19	34	0	0	0	0	0	0	0	62.02	0	0	13.2
2014	9	13	12	58	19	33	0	0	0	0	0	0	0	62.1	0	0	13.2
2014	9	13	13	8	19	34	0	0	0	0	0	0	0	62.15	0	0	13.2
2014	9	13	13	18	19	34	0	0	0	0	0	0	0	62.2	0	0	13.2
2014	9	13	13	28	19	33	0	0	0	0	0	0	0	62.26	0	0	13.2
2014	9	13	13	38	19	34	0	0	0	0	0	0	0	62.31	0	0	13.2
2014	9	13	13	48	19	34	0	0	0	0	0	0	0	62.15	0	0	12.8
2014	9	13	13	58	19	33	0	0	0	0	0	0	0	62.17	0	0	13.2
2014	9	13	14	8	19	34	0	0	0	0	0	0	0	62.29	0	0	13.2
2014	9	13	14	18	19	34	0	0	0	0	0	0	0	62.28	0	0	13.2
2014	9	13	14	28	19	33	0	0	0	0	0	0	0	62.44	0	0	13.2
2014	9	13	14	38	19	34	0	0	0	0	0	0	0	62.51	0	0	13.2
2014	9	13	14	48	19	34	0	0	0	0	0	0	0	62.46	0	0	13
2014	9	13	14	58	19	34	0	0	0	0	0	0	0	62.44	0	0	13.2
2014	9	13	15	8	19	34	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	13	15	18	19	34	0	0	0	0	0	0	0	62.62	0	0	13
2014	9	13	15	28	19	33	0	0	0	0	0	0	0	62.56	0	0	12.8
2014	9	13	15	38	19	33	0	0	0	0	0	0	0	62.64	0	0	13.2
2014	9	13	15	48	19	34	0	0	0	0	0	0	0	62.69	0	0	13
2014	9	13	15	58	19	34	0	0	0	0	0	0	0	62.71	0	0	12.8
2014	9	13	16	8	19	34	0	0	0	0	0	0	0	62.71	0	0	12.8
2014	9	13	16	18	19	34	0	0	0	0	0	0	0	62.67	0	0	12.6
2014	9	13	16	28	19	33	0	0	0	0	0	0	0	62.71	0	0	12.8
2014	9	13	16	38	19	34	0	0	0	0	0	0	0	62.65	0	0	12.2
2014	9	13	16	48	19	33	0	0	0	0	0	0	0	62.76	0	0	12.8
2014	9	13	16	58	19	33	0	0	0	0	0	0	0	62.78	0	0	12.8
2014	9	13	17	8	19	33	0	0	0	0	0	0	0	62.78	0	0	12.6
2014	9	13	17	18	19	34	0	0	0	0	0	0	0	62.74	0	0	12.2
2014	9	13	17	28	19	33	0	0	0	0	0	0	0	62.74	0	0	12
2014	9	13	17	38	19	34	0	0	0	0	0	0	0	62.76	0	0	12
2014	9	13	17	48	19	33	0	0	0	0	0	0	0	62.76	0	0	11.8
2014	9	13	17	58	19	33	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	13	18	8	19	33	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	13	18	18	19	33	0	0	0	0	0	0	0	62.78	0	0	11.8
2014	9	13	18	28	19	33	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	13	18	38	19	33	0	0	0	0	0	0	0	62.78	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	13	18	48	19	34	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	13	18	58	19	33	0	0	0	0	0	0	0	62.8	0	0	11.8
2014	9	13	19	8	19	33	0	0	0	0	0	0	0	62.8	0	0	11.6
2014	9	13	19	18	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	19	28	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	19	38	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	19	48	19	34	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	19	58	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	20	8	19	34	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	13	20	18	19	33	0	0	0	0	0	0	0	62.76	0	0	11.6
2014	9	13	20	28	19	33	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	13	20	38	19	34	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	13	20	48	19	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	13	20	58	19	34	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	13	21	8	19	33	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	13	21	18	19	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	13	21	28	19	34	0	0	0	0	0	0	0	62.65	0	0	11.6
2014	9	13	21	38	19	33	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	13	21	48	19	33	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	13	21	58	19	34	0	0	0	0	0	0	0	62.58	0	0	11.6
2014	9	13	22	8	19	33	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	13	22	18	19	34	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	13	22	28	19	33	0	0	0	0	0	0	0	62.51	0	0	11.6
2014	9	13	22	38	19	33	0	0	0	0	0	0	0	62.47	0	0	11.6
2014	9	13	22	48	19	33	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	13	22	58	19	34	0	0	0	0	0	0	0	62.42	0	0	11.6
2014	9	13	23	8	19	33	0	0	0	0	0	0	0	62.38	0	0	11.6
2014	9	13	23	18	19	33	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	13	23	28	19	34	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	13	23	38	19	33	0	0	0	0	0	0	0	62.31	0	0	11.6
2014	9	13	23	48	19	32	0	0	0	0	0	0	0	62.28	0	0	11.6
2014	9	13	23	58	19	33	0	0	0	0	0	0	0	62.24	0	0	11.6
2014	9	14	0	8	19	34	0	0	0	0	0	0	0	62.22	0	0	11.6
2014	9	14	0	18	19	34	0	0	0	0	0	0	0	62.19	0	0	11.6
2014	9	14	0	28	19	33	0	0	0	0	0	0	0	62.15	0	0	11.6
2014	9	14	0	38	19	34	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	14	0	48	19	33	0	0	0	0	0	0	0	62.08	0	0	11.6
2014	9	14	0	58	19	34	0	0	0	0	0	0	0	62.06	0	0	11.6
2014	9	14	1	8	19	34	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	14	1	18	19	33	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	14	1	28	19	33	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	14	1	38	19	33	0	0	0	0	0	0	0	61.93	0	0	11.6
2014	9	14	1	48	19	34	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	14	1	58	19	33	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	14	2	8	19	33	0	0	0	0	0	0	0	61.83	0	0	11.6
2014	9	14	2	18	19	34	0	0	0	0	0	0	0	61.79	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	2	28	19	33	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	14	2	38	19	34	0	0	0	0	0	0	0	61.72	0	0	11.6
2014	9	14	2	48	19	33	0	0	0	0	0	0	0	61.68	0	0	11.6
2014	9	14	2	58	19	33	0	0	0	0	0	0	0	61.65	0	0	11.6
2014	9	14	3	8	19	33	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	14	3	18	19	33	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	14	3	28	19	34	0	0	0	0	0	0	0	61.56	0	0	11.6
2014	9	14	3	38	19	33	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	14	3	48	19	34	0	0	0	0	0	0	0	61.48	0	0	11.6
2014	9	14	3	58	19	34	0	0	0	0	0	0	0	61.45	0	0	11.6
2014	9	14	4	8	19	34	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	14	4	18	19	34	0	0	0	0	0	0	0	61.39	0	0	11.6
2014	9	14	4	28	19	33	0	0	0	0	0	0	0	61.36	0	0	11.6
2014	9	14	4	38	19	33	0	0	0	0	0	0	0	61.32	0	0	11.6
2014	9	14	4	48	19	33	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	14	4	58	19	34	0	0	0	0	0	0	0	61.27	0	0	11.6
2014	9	14	5	8	19	33	0	0	0	0	0	0	0	61.21	0	0	11.6
2014	9	14	5	18	19	33	0	0	0	0	0	0	0	61.2	0	0	11.6
2014	9	14	5	28	19	33	0	0	0	0	0	0	0	61.16	0	0	11.6
2014	9	14	5	38	19	34	0	0	0	0	0	0	0	61.14	0	0	11.4
2014	9	14	5	48	19	34	0	0	0	0	0	0	0	61.12	0	0	11.4
2014	9	14	5	58	19	33	0	0	0	0	0	0	0	61.09	0	0	11.4
2014	9	14	6	8	19	33	0	0	0	0	0	0	0	61.07	0	0	11.4
2014	9	14	6	18	19	33	0	0	0	0	0	0	0	61.03	0	0	11.4
2014	9	14	6	28	19	34	0	0	0	0	0	0	0	61.02	0	0	11.4
2014	9	14	6	38	19	34	0	0	0	0	0	0	0	61	0	0	11.4
2014	9	14	6	48	19	34	0	0	0	0	0	0	0	60.96	0	0	11.4
2014	9	14	6	58	19	33	0	0	0	0	0	0	0	60.94	0	0	11.4
2014	9	14	7	8	19	34	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	14	7	18	19	34	0	0	0	0	0	0	0	60.89	0	0	11.6
2014	9	14	7	28	19	34	0	0	0	0	0	0	0	60.89	0	0	11.6
2014	9	14	7	38	19	34	0	0	0	0	0	0	0	60.87	0	0	11.8
2014	9	14	7	48	19	34	0	0	0	0	0	0	0	60.85	0	0	12
2014	9	14	7	58	19	34	0	0	0	0	0	0	0	60.85	0	0	12.2
2014	9	14	8	8	19	34	0	0	0	0	0	0	0	60.85	0	0	12.2
2014	9	14	8	18	19	34	0	0	0	0	0	0	0	60.85	0	0	12.2
2014	9	14	8	28	19	33	0	0	0	0	0	0	0	60.89	0	0	12.4
2014	9	14	8	38	19	34	0	0	0	0	0	0	0	61	0	0	12.4
2014	9	14	8	48	19	34	0	0	0	0	0	0	0	61.03	0	0	12.4
2014	9	14	8	58	19	34	0	0	0	0	0	0	0	61.07	0	0	12.4
2014	9	14	9	8	19	34	0	0	0	0	0	0	0	61.11	0	0	12.6
2014	9	14	9	18	19	34	0	0	0	0	0	0	0	61.14	0	0	12.6
2014	9	14	9	28	19	34	0	0	0	0	0	0	0	61.2	0	0	12.6
2014	9	14	9	38	19	34	0	0	0	0	0	0	0	61.25	0	0	12.6
2014	9	14	9	48	19	33	0	0	0	0	0	0	0	61.34	0	0	12.8
2014	9	14	9	58	19	34	0	0	0	0	0	0	0	61.25	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	10	8	19	34	0	0	0	0	0	0	0	61.47	0	0	13.4
2014	9	14	10	18	19	33	0	0	0	0	0	0	0	61.45	0	0	13.4
2014	9	14	10	28	19	34	0	0	0	0	0	0	0	61.54	0	0	13.4
2014	9	14	10	38	19	34	0	0	0	0	0	0	0	61.61	0	0	13
2014	9	14	10	48	19	33	0	0	0	0	0	0	0	61.7	0	0	13
2014	9	14	10	58	19	33	0	0	0	0	0	0	0	61.83	0	0	13
2014	9	14	11	8	19	34	0	0	0	0	0	0	0	61.59	0	0	12.4
2014	9	14	11	18	19	34	0	0	0	0	0	0	0	61.7	0	0	12.8
2014	9	14	11	28	19	33	0	0	0	0	0	0	0	61.75	0	0	12.8
2014	9	14	11	38	19	34	0	0	0	0	0	0	0	61.9	0	0	13
2014	9	14	11	48	19	33	0	0	0	0	0	0	0	62.08	0	0	13
2014	9	14	11	58	19	33	0	0	0	0	0	0	0	62.17	0	0	13
2014	9	14	12	8	19	33	0	0	0	0	0	0	0	61.83	0	0	12
2014	9	14	12	18	19	34	0	0	0	0	0	0	0	61.75	0	0	11.8
2014	9	14	12	28	19	32	0	0	0	0	0	0	0	61.75	0	0	12
2014	9	14	12	38	19	34	0	0	0	0	0	0	0	61.79	0	0	12.4
2014	9	14	12	48	19	34	0	0	0	0	0	0	0	61.84	0	0	13.2
2014	9	14	12	58	19	33	0	0	0	0	0	0	0	61.99	0	0	13.6
2014	9	14	13	8	19	34	0	0	0	0	0	0	0	62.24	0	0	13.4
2014	9	14	13	18	19	33	0	0	0	0	0	0	0	62.2	0	0	13
2014	9	14	13	28	19	34	0	0	0	0	0	0	0	62.1	0	0	12.4
2014	9	14	13	38	19	34	0	0	0	0	0	0	0	62.13	0	0	13
2014	9	14	13	48	19	34	0	0	0	0	0	0	0	62.38	0	0	13
2014	9	14	13	58	19	34	0	0	0	0	0	0	0	62.33	0	0	13.2
2014	9	14	14	8	19	33	0	0	0	0	0	0	0	62.46	0	0	12.8
2014	9	14	14	18	19	34	0	0	0	0	0	0	0	62.44	0	0	12.8
2014	9	14	14	28	19	33	0	0	0	0	0	0	0	62.31	0	0	12.6
2014	9	14	14	38	19	34	0	0	0	0	0	0	0	62.31	0	0	12.4
2014	9	14	14	48	19	33	0	0	0	0	0	0	0	62.31	0	0	12.2
2014	9	14	14	58	19	34	0	0	0	0	0	0	0	62.33	0	0	12.2
2014	9	14	15	8	19	33	0	0	0	0	0	0	0	62.37	0	0	12.4
2014	9	14	15	18	19	34	0	0	0	0	0	0	0	62.42	0	0	12.4
2014	9	14	15	28	19	33	0	0	0	0	0	0	0	62.46	0	0	12.4
2014	9	14	15	38	19	34	0	0	0	0	0	0	0	62.64	0	0	13.6
2014	9	14	15	48	19	34	0	0	0	0	0	0	0	62.73	0	0	13.6
2014	9	14	15	58	19	33	0	0	0	0	0	0	0	62.62	0	0	12.2
2014	9	14	16	8	19	34	0	0	0	0	0	0	0	62.71	0	0	13.4
2014	9	14	16	18	19	34	0	0	0	0	0	0	0	62.73	0	0	13.2
2014	9	14	16	28	19	33	0	0	0	0	0	0	0	62.74	0	0	12.8
2014	9	14	16	38	19	34	0	0	0	0	0	0	0	62.73	0	0	13.2
2014	9	14	16	48	19	34	0	0	0	0	0	0	0	62.69	0	0	12
2014	9	14	16	58	19	33	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	14	17	8	19	33	0	0	0	0	0	0	0	62.69	0	0	12.2
2014	9	14	17	18	19	34	0	0	0	0	0	0	0	62.67	0	0	12
2014	9	14	17	28	19	34	0	0	0	0	0	0	0	62.67	0	0	12
2014	9	14	17	38	19	34	0	0	0	0	0	0	0	62.69	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	14	17	48	19	34	0	0	0	0	0	0	0	62.71	0	0	11.8
2014	9	14	17	58	19	34	0	0	0	0	0	0	0	62.69	0	0	11.8
2014	9	14	18	8	19	34	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	18	18	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	18	28	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	18	38	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	18	48	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	18	58	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	19	8	19	34	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	19	18	19	34	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	19	28	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	14	19	38	19	33	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	14	19	48	19	33	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	14	19	58	19	34	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	14	20	8	19	33	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	14	20	18	19	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	14	20	28	19	33	0	0	0	0	0	0	0	62.67	0	0	11.4
2014	9	14	20	38	19	34	0	0	0	0	0	0	0	62.65	0	0	11.4
2014	9	14	20	48	19	33	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	14	20	58	19	33	0	0	0	0	0	0	0	62.64	0	0	11.6
2014	9	14	21	8	19	34	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	14	21	18	19	32	0	0	0	0	0	0	0	62.6	0	0	11.4
2014	9	14	21	28	19	33	0	0	0	0	0	0	0	62.58	0	0	11.4
2014	9	14	21	38	19	34	0	0	0	0	0	0	0	62.56	0	0	11.6
2014	9	14	21	48	19	33	0	0	0	0	0	0	0	62.55	0	0	11.4
2014	9	14	21	58	19	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	14	22	8	19	33	0	0	0	0	0	0	0	62.51	0	0	11.6
2014	9	14	22	18	19	33	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	14	22	28	19	34	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	14	22	38	19	34	0	0	0	0	0	0	0	62.44	0	0	11.4
2014	9	14	22	48	19	33	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	14	22	58	19	33	0	0	0	0	0	0	0	62.4	0	0	11.4
2014	9	14	23	8	19	34	0	0	0	0	0	0	0	62.38	0	0	11.4
2014	9	14	23	18	19	34	0	0	0	0	0	0	0	62.35	0	0	11.4
2014	9	14	23	28	19	33	0	0	0	0	0	0	0	62.33	0	0	11.4
2014	9	14	23	38	19	34	0	0	0	0	0	0	0	62.29	0	0	11.4
2014	9	14	23	48	19	34	0	0	0	0	0	0	0	62.28	0	0	11.4
2014	9	14	23	58	19	33	0	0	0	0	0	0	0	62.24	0	0	11.4
2014	9	15	0	8	19	34	0	0	0	0	0	0	0	62.22	0	0	11.4
2014	9	15	0	18	19	34	0	0	0	0	0	0	0	62.19	0	0	11.4
2014	9	15	0	28	19	32	0	0	0	0	0	0	0	62.15	0	0	11.4
2014	9	15	0	38	19	33	0	0	0	0	0	0	0	62.13	0	0	11.4
2014	9	15	0	48	19	34	0	0	0	0	0	0	0	62.1	0	0	11.4
2014	9	15	0	58	19	33	0	0	0	0	0	0	0	62.06	0	0	11.4
2014	9	15	1	8	19	34	0	0	0	0	0	0	0	62.04	0	0	11.4
2014	9	15	1	18	19	34	0	0	0	0	0	0	0	62.01	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	1	28	19	33	0	0	0	0	0	0	0	61.99	0	0	11.4
2014	9	15	1	38	19	33	0	0	0	0	0	0	0	61.95	0	0	11.4
2014	9	15	1	48	19	34	0	0	0	0	0	0	0	61.92	0	0	11.4
2014	9	15	1	58	19	33	0	0	0	0	0	0	0	61.9	0	0	11.4
2014	9	15	2	8	19	33	0	0	0	0	0	0	0	61.86	0	0	11.4
2014	9	15	2	18	19	33	0	0	0	0	0	0	0	61.84	0	0	11.4
2014	9	15	2	28	19	34	0	0	0	0	0	0	0	61.81	0	0	11.4
2014	9	15	2	38	19	33	0	0	0	0	0	0	0	61.79	0	0	11.4
2014	9	15	2	48	19	34	0	0	0	0	0	0	0	61.75	0	0	11.4
2014	9	15	2	58	19	34	0	0	0	0	0	0	0	61.74	0	0	11.4
2014	9	15	3	8	19	33	0	0	0	0	0	0	0	61.7	0	0	11.4
2014	9	15	3	18	19	34	0	0	0	0	0	0	0	61.66	0	0	11.4
2014	9	15	3	28	19	33	0	0	0	0	0	0	0	61.65	0	0	11.4
2014	9	15	3	38	19	33	0	0	0	0	0	0	0	61.61	0	0	11.4
2014	9	15	3	48	19	33	0	0	0	0	0	0	0	61.59	0	0	11.4
2014	9	15	3	58	19	34	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	15	4	8	19	33	0	0	0	0	0	0	0	61.52	0	0	11.4
2014	9	15	4	18	19	34	0	0	0	0	0	0	0	61.5	0	0	11.4
2014	9	15	4	28	19	33	0	0	0	0	0	0	0	61.47	0	0	11.4
2014	9	15	4	38	19	33	0	0	0	0	0	0	0	61.45	0	0	11.4
2014	9	15	4	48	19	33	0	0	0	0	0	0	0	61.41	0	0	11.4
2014	9	15	4	58	19	33	0	0	0	0	0	0	0	61.39	0	0	11.4
2014	9	15	5	8	19	33	0	0	0	0	0	0	0	61.36	0	0	11.4
2014	9	15	5	18	19	34	0	0	0	0	0	0	0	61.34	0	0	11.4
2014	9	15	5	28	19	34	0	0	0	0	0	0	0	61.32	0	0	11.4
2014	9	15	5	38	19	34	0	0	0	0	0	0	0	61.29	0	0	11.4
2014	9	15	5	48	19	33	0	0	0	0	0	0	0	61.25	0	0	11.4
2014	9	15	5	58	19	34	0	0	0	0	0	0	0	61.23	0	0	11.4
2014	9	15	6	8	19	34	0	0	0	0	0	0	0	61.2	0	0	11.4
2014	9	15	6	18	19	34	0	0	0	0	0	0	0	61.18	0	0	11.4
2014	9	15	6	28	19	34	0	0	0	0	0	0	0	61.14	0	0	11.4
2014	9	15	6	38	19	34	0	0	0	0	0	0	0	61.12	0	0	11.4
2014	9	15	6	48	19	34	0	0	0	0	0	0	0	61.11	0	0	11.4
2014	9	15	6	58	19	33	0	0	0	0	0	0	0	61.07	0	0	11.4
2014	9	15	7	8	19	33	0	0	0	0	0	0	0	61.05	0	0	11.4
2014	9	15	7	18	19	33	0	0	0	0	0	0	0	61.03	0	0	11.4
2014	9	15	7	28	19	34	0	0	0	0	0	0	0	61.02	0	0	11.6
2014	9	15	7	38	19	34	0	0	0	0	0	0	0	61	0	0	11.8
2014	9	15	7	48	19	34	0	0	0	0	0	0	0	60.98	0	0	11.8
2014	9	15	7	58	19	34	0	0	0	0	0	0	0	60.98	0	0	12
2014	9	15	8	8	19	34	0	0	0	0	0	0	0	60.98	0	0	12.2
2014	9	15	8	18	19	33	0	0	0	0	0	0	0	61	0	0	12.2
2014	9	15	8	28	19	34	0	0	0	0	0	0	0	61	0	0	12.4
2014	9	15	8	38	19	34	0	0	0	0	0	0	0	61.07	0	0	12.4
2014	9	15	8	48	19	34	0	0	0	0	0	0	0	61.12	0	0	12.8
2014	9	15	8	58	19	34	0	0	0	0	0	0	0	61.16	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	9	8	19	33	0	0	0	0	0	0	0	61.2	0	0	12.8
2014	9	15	9	18	19	33	0	0	0	0	0	0	0	61.25	0	0	12.8
2014	9	15	9	28	19	34	0	0	0	0	0	0	0	61.29	0	0	13.2
2014	9	15	9	38	19	33	0	0	0	0	0	0	0	61.34	0	0	13.4
2014	9	15	9	48	19	34	0	0	0	0	0	0	0	61.39	0	0	13.6
2014	9	15	9	58	19	33	0	0	0	0	0	0	0	61.45	0	0	13.6
2014	9	15	10	8	19	34	0	0	0	0	0	0	0	61.52	0	0	13.8
2014	9	15	10	18	19	34	0	0	0	0	0	0	0	61.57	0	0	14
2014	9	15	10	28	19	34	0	0	0	0	0	0	0	61.65	0	0	14
2014	9	15	10	38	19	34	0	0	0	0	0	0	0	61.59	0	0	13
2014	9	15	10	48	19	34	0	0	0	0	0	0	0	61.77	0	0	13.8
2014	9	15	10	58	19	34	0	0	0	0	0	0	0	61.59	0	0	12.8
2014	9	15	11	8	19	34	0	0	0	0	0	0	0	61.65	0	0	12.8
2014	9	15	11	18	19	33	0	0	0	0	0	0	0	61.75	0	0	13.2
2014	9	15	11	28	19	33	0	0	0	0	0	0	0	61.83	0	0	13.2
2014	9	15	11	38	19	33	0	0	0	0	0	0	0	61.66	0	0	12.4
2014	9	15	11	48	19	34	0	0	0	0	0	0	0	61.72	0	0	12.4
2014	9	15	11	58	19	33	0	0	0	0	0	0	0	61.9	0	0	13.4
2014	9	15	12	8	19	33	0	0	0	0	0	0	0	62.08	0	0	13.6
2014	9	15	12	18	19	33	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	15	12	28	19	34	0	0	0	0	0	0	0	62.22	0	0	13.8
2014	9	15	12	38	19	34	0	0	0	0	0	0	0	62.19	0	0	13.6
2014	9	15	12	48	19	34	0	0	0	0	0	0	0	62.24	0	0	13.6
2014	9	15	12	58	19	34	0	0	0	0	0	0	0	62.46	0	0	13.8
2014	9	15	13	8	19	33	0	0	0	0	0	0	0	62.55	0	0	13.4
2014	9	15	13	18	19	33	0	0	0	0	0	0	0	62.58	0	0	13.4
2014	9	15	13	28	19	34	0	0	0	0	0	0	0	62.64	0	0	13.4
2014	9	15	13	38	19	33	0	0	0	0	0	0	0	62.6	0	0	13.4
2014	9	15	13	48	19	34	0	0	0	0	0	0	0	62.53	0	0	13.2
2014	9	15	13	58	19	33	0	0	0	0	0	0	0	62.55	0	0	13
2014	9	15	14	8	19	33	0	0	0	0	0	0	0	62.65	0	0	13.4
2014	9	15	14	18	19	33	0	0	0	0	0	0	0	62.69	0	0	13.2
2014	9	15	14	28	19	33	0	0	0	0	0	0	0	62.78	0	0	13.2
2014	9	15	14	38	19	34	0	0	0	0	0	0	0	62.8	0	0	13.2
2014	9	15	14	48	19	33	0	0	0	0	0	0	0	62.8	0	0	13.2
2014	9	15	14	58	19	34	0	0	0	0	0	0	0	62.83	0	0	13.2
2014	9	15	15	8	19	33	0	0	0	0	0	0	0	62.87	0	0	13.2
2014	9	15	15	18	19	34	0	0	0	0	0	0	0	62.87	0	0	13
2014	9	15	15	28	19	33	0	0	0	0	0	0	0	62.91	0	0	13
2014	9	15	15	38	19	33	0	0	0	0	0	0	0	62.92	0	0	13
2014	9	15	15	48	19	33	0	0	0	0	0	0	0	62.92	0	0	13
2014	9	15	15	58	19	34	0	0	0	0	0	0	0	62.89	0	0	12
2014	9	15	16	8	19	33	0	0	0	0	0	0	0	62.89	0	0	13.2
2014	9	15	16	18	19	34	0	0	0	0	0	0	0	62.89	0	0	11.8
2014	9	15	16	28	19	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	15	16	38	19	33	0	0	0	0	0	0	0	62.91	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	15	16	48	19	33	0	0	0	0	0	0	0	62.94	0	0	12.2
2014	9	15	16	58	19	32	0	0	0	0	0	0	0	62.96	0	0	12.4
2014	9	15	17	8	19	33	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	15	17	18	19	34	0	0	0	0	0	0	0	62.96	0	0	11.8
2014	9	15	17	28	19	33	0	0	0	0	0	0	0	62.98	0	0	11.8
2014	9	15	17	38	19	33	0	0	0	0	0	0	0	63	0	0	11.8
2014	9	15	17	48	19	33	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	15	17	58	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	15	18	8	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	15	18	18	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	18	28	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	18	38	19	34	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	18	48	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	18	58	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	19	8	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	15	19	18	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	15	19	28	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	15	19	38	19	34	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	15	19	48	19	33	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	15	19	58	19	33	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	15	20	8	19	33	0	0	0	0	0	0	0	62.98	0	0	11.6
2014	9	15	20	18	19	34	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	15	20	28	19	33	0	0	0	0	0	0	0	62.94	0	0	11.6
2014	9	15	20	38	19	33	0	0	0	0	0	0	0	62.92	0	0	11.6
2014	9	15	20	48	19	33	0	0	0	0	0	0	0	62.91	0	0	11.6
2014	9	15	20	58	19	33	0	0	0	0	0	0	0	62.89	0	0	11.4
2014	9	15	21	8	19	34	0	0	0	0	0	0	0	62.87	0	0	11.4
2014	9	15	21	18	19	33	0	0	0	0	0	0	0	62.85	0	0	11.6
2014	9	15	21	28	19	33	0	0	0	0	0	0	0	62.83	0	0	11.6
2014	9	15	21	38	19	33	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	15	21	48	19	33	0	0	0	0	0	0	0	62.8	0	0	11.4
2014	9	15	21	58	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	15	22	8	19	34	0	0	0	0	0	0	0	62.76	0	0	11.6
2014	9	15	22	18	19	34	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	15	22	28	19	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	15	22	38	19	34	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	15	22	48	19	33	0	0	0	0	0	0	0	62.69	0	0	11.6
2014	9	15	22	58	19	34	0	0	0	0	0	0	0	62.67	0	0	11.4
2014	9	15	23	8	19	34	0	0	0	0	0	0	0	62.65	0	0	11.4
2014	9	15	23	18	19	33	0	0	0	0	0	0	0	62.64	0	0	11.4
2014	9	15	23	28	19	34	0	0	0	0	0	0	0	62.64	0	0	11.4
2014	9	15	23	38	19	33	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	15	23	48	19	34	0	0	0	0	0	0	0	62.6	0	0	11.4
2014	9	15	23	58	19	33	0	0	0	0	0	0	0	62.58	0	0	11.4
2014	9	16	0	8	19	33	0	0	0	0	0	0	0	62.56	0	0	11.4
2014	9	16	0	18	19	33	0	0	0	0	0	0	0	62.55	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	0	28	19	34	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	16	0	38	19	33	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	16	0	48	19	33	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	16	0	58	19	33	0	0	0	0	0	0	0	62.47	0	0	11.4
2014	9	16	1	8	19	34	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	16	1	18	19	33	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	16	1	28	19	33	0	0	0	0	0	0	0	62.38	0	0	11.4
2014	9	16	1	38	19	33	0	0	0	0	0	0	0	62.37	0	0	11.4
2014	9	16	1	48	19	33	0	0	0	0	0	0	0	62.33	0	0	11.4
2014	9	16	1	58	19	34	0	0	0	0	0	0	0	62.31	0	0	11.4
2014	9	16	2	8	19	33	0	0	0	0	0	0	0	62.28	0	0	11.4
2014	9	16	2	18	19	34	0	0	0	0	0	0	0	62.24	0	0	11.4
2014	9	16	2	28	19	33	0	0	0	0	0	0	0	62.22	0	0	11.4
2014	9	16	2	38	19	33	0	0	0	0	0	0	0	62.17	0	0	11.4
2014	9	16	2	48	19	33	0	0	0	0	0	0	0	62.15	0	0	11.4
2014	9	16	2	58	19	34	0	0	0	0	0	0	0	62.11	0	0	11.4
2014	9	16	3	8	19	34	0	0	0	0	0	0	0	62.08	0	0	11.4
2014	9	16	3	18	19	34	0	0	0	0	0	0	0	62.04	0	0	11.4
2014	9	16	3	28	19	33	0	0	0	0	0	0	0	62.01	0	0	11.4
2014	9	16	3	38	19	34	0	0	0	0	0	0	0	61.99	0	0	11.4
2014	9	16	3	48	19	33	0	0	0	0	0	0	0	61.95	0	0	11.4
2014	9	16	3	58	19	33	0	0	0	0	0	0	0	61.92	0	0	11.4
2014	9	16	4	8	19	33	0	0	0	0	0	0	0	61.88	0	0	11.4
2014	9	16	4	18	19	33	0	0	0	0	0	0	0	61.84	0	0	11.4
2014	9	16	4	28	19	34	0	0	0	0	0	0	0	61.81	0	0	11.4
2014	9	16	4	38	19	34	0	0	0	0	0	0	0	61.77	0	0	11.4
2014	9	16	4	48	19	34	0	0	0	0	0	0	0	61.74	0	0	11.4
2014	9	16	4	58	19	33	0	0	0	0	0	0	0	61.7	0	0	11.4
2014	9	16	5	8	19	33	0	0	0	0	0	0	0	61.68	0	0	11.4
2014	9	16	5	18	19	34	0	0	0	0	0	0	0	61.65	0	0	11.4
2014	9	16	5	28	19	34	0	0	0	0	0	0	0	61.61	0	0	11.4
2014	9	16	5	38	19	33	0	0	0	0	0	0	0	61.59	0	0	11.4
2014	9	16	5	48	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	16	5	58	19	33	0	0	0	0	0	0	0	61.52	0	0	11.4
2014	9	16	6	8	19	34	0	0	0	0	0	0	0	61.5	0	0	11.4
2014	9	16	6	18	19	33	0	0	0	0	0	0	0	61.47	0	0	11.4
2014	9	16	6	28	19	34	0	0	0	0	0	0	0	61.43	0	0	11.4
2014	9	16	6	38	19	34	0	0	0	0	0	0	0	61.41	0	0	11.4
2014	9	16	6	48	19	34	0	0	0	0	0	0	0	61.36	0	0	11.4
2014	9	16	6	58	19	34	0	0	0	0	0	0	0	61.36	0	0	11.4
2014	9	16	7	8	19	34	0	0	0	0	0	0	0	61.32	0	0	11.4
2014	9	16	7	18	19	34	0	0	0	0	0	0	0	61.29	0	0	11.4
2014	9	16	7	28	19	34	0	0	0	0	0	0	0	61.27	0	0	11.4
2014	9	16	7	38	19	34	0	0	0	0	0	0	0	61.25	0	0	11.6
2014	9	16	7	48	19	34	0	0	0	0	0	0	0	61.23	0	0	11.8
2014	9	16	7	58	19	33	0	0	0	0	0	0	0	61.23	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	8	8	19	33	0	0	0	0	0	0	0	61.23	0	0	12.2
2014	9	16	8	18	19	34	0	0	0	0	0	0	0	61.23	0	0	13
2014	9	16	8	28	19	33	0	0	0	0	0	0	0	61.21	0	0	12.8
2014	9	16	8	38	19	33	0	0	0	0	0	0	0	61.29	0	0	12.8
2014	9	16	8	48	19	34	0	0	0	0	0	0	0	61.32	0	0	13
2014	9	16	8	58	19	33	0	0	0	0	0	0	0	61.36	0	0	13
2014	9	16	9	8	19	34	0	0	0	0	0	0	0	61.39	0	0	13.4
2014	9	16	9	18	19	34	0	0	0	0	0	0	0	61.43	0	0	13.2
2014	9	16	9	28	19	34	0	0	0	0	0	0	0	61.48	0	0	13.4
2014	9	16	9	38	19	33	0	0	0	0	0	0	0	61.52	0	0	13.4
2014	9	16	9	48	19	33	0	0	0	0	0	0	0	61.56	0	0	13.6
2014	9	16	9	58	19	34	0	0	0	0	0	0	0	61.61	0	0	13.6
2014	9	16	10	8	19	33	0	0	0	0	0	0	0	61.66	0	0	13.6
2014	9	16	10	18	19	34	0	0	0	0	0	0	0	61.72	0	0	13.4
2014	9	16	10	28	19	34	0	0	0	0	0	0	0	61.77	0	0	13.4
2014	9	16	10	38	19	34	0	0	0	0	0	0	0	61.81	0	0	13.4
2014	9	16	10	48	19	34	0	0	0	0	0	0	0	61.88	0	0	13.2
2014	9	16	10	58	19	34	0	0	0	0	0	0	0	61.93	0	0	13.2
2014	9	16	11	8	19	34	0	0	0	0	0	0	0	61.99	0	0	13.2
2014	9	16	11	18	19	34	0	0	0	0	0	0	0	62.04	0	0	13.2
2014	9	16	11	28	19	33	0	0	0	0	0	0	0	62.11	0	0	13.2
2014	9	16	11	38	19	34	0	0	0	0	0	0	0	62.17	0	0	13.4
2014	9	16	11	48	19	33	0	0	0	0	0	0	0	62.22	0	0	13.2
2014	9	16	11	58	19	34	0	0	0	0	0	0	0	62.28	0	0	13.2
2014	9	16	12	8	19	34	0	0	0	0	0	0	0	62.33	0	0	13.2
2014	9	16	12	18	19	34	0	0	0	0	0	0	0	62.4	0	0	13.2
2014	9	16	12	28	19	34	0	0	0	0	0	0	0	62.46	0	0	13.2
2014	9	16	12	38	19	34	0	0	0	0	0	0	0	62.51	0	0	13.2
2014	9	16	12	48	19	33	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	16	12	58	19	34	0	0	0	0	0	0	0	62.6	0	0	13.2
2014	9	16	13	8	19	33	0	0	0	0	0	0	0	62.64	0	0	13.2
2014	9	16	13	18	19	34	0	0	0	0	0	0	0	62.69	0	0	13.2
2014	9	16	13	28	19	33	0	0	0	0	0	0	0	62.74	0	0	13.2
2014	9	16	13	38	19	33	0	0	0	0	0	0	0	62.8	0	0	13.2
2014	9	16	13	48	19	33	0	0	0	0	0	0	0	62.85	0	0	13
2014	9	16	13	58	19	33	0	0	0	0	0	0	0	62.89	0	0	13
2014	9	16	14	8	19	34	0	0	0	0	0	0	0	62.92	0	0	13
2014	9	16	14	18	19	33	0	0	0	0	0	0	0	62.98	0	0	13.2
2014	9	16	14	28	19	34	0	0	0	0	0	0	0	63.01	0	0	13.2
2014	9	16	14	38	19	33	0	0	0	0	0	0	0	63.05	0	0	13
2014	9	16	14	48	19	33	0	0	0	0	0	0	0	63.09	0	0	13
2014	9	16	14	58	19	33	0	0	0	0	0	0	0	63.14	0	0	13
2014	9	16	15	8	19	34	0	0	0	0	0	0	0	63.18	0	0	13
2014	9	16	15	18	19	33	0	0	0	0	0	0	0	63.19	0	0	13
2014	9	16	15	28	19	33	0	0	0	0	0	0	0	63.23	0	0	13
2014	9	16	15	38	19	33	0	0	0	0	0	0	0	63.27	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	15	48	19	33	0	0	0	0	0	0	0	63.3	0	0	13
2014	9	16	15	58	19	33	0	0	0	0	0	0	0	63.32	0	0	12.8
2014	9	16	16	8	19	33	0	0	0	0	0	0	0	63.34	0	0	12.8
2014	9	16	16	18	19	33	0	0	0	0	0	0	0	63.36	0	0	12.8
2014	9	16	16	28	19	34	0	0	0	0	0	0	0	63.39	0	0	12.8
2014	9	16	16	38	19	33	0	0	0	0	0	0	0	63.41	0	0	12.8
2014	9	16	16	48	19	33	0	0	0	0	0	0	0	63.45	0	0	12.6
2014	9	16	16	58	19	33	0	0	0	0	0	0	0	63.46	0	0	12.4
2014	9	16	17	8	19	34	0	0	0	0	0	0	0	63.48	0	0	12.2
2014	9	16	17	18	19	33	0	0	0	0	0	0	0	63.48	0	0	12
2014	9	16	17	28	19	33	0	0	0	0	0	0	0	63.48	0	0	11.8
2014	9	16	17	38	19	33	0	0	0	0	0	0	0	63.5	0	0	11.8
2014	9	16	17	48	19	33	0	0	0	0	0	0	0	63.52	0	0	11.8
2014	9	16	17	58	19	34	0	0	0	0	0	0	0	63.54	0	0	11.8
2014	9	16	18	8	19	33	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	16	18	18	19	34	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	16	18	28	19	32	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	16	18	38	19	34	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	16	18	48	19	33	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	16	18	58	19	34	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	8	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	18	19	34	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	28	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	38	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	48	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	19	58	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	20	8	19	34	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	20	18	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	20	28	19	33	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	16	20	38	19	34	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	20	48	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	20	58	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	16	21	8	19	34	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	16	21	18	19	34	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	16	21	28	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	16	21	38	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	16	21	48	19	34	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	16	21	58	19	33	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	16	22	8	19	33	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	16	22	18	19	33	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	16	22	28	19	33	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	16	22	38	19	34	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	16	22	48	19	33	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	16	22	58	19	33	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	16	23	8	19	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	16	23	18	19	33	0	0	0	0	0	0	0	63.43	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	16	23	28	19	33	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	16	23	38	19	34	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	16	23	48	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	16	23	58	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	17	0	8	19	33	0	0	0	0	0	0	0	63.37	0	0	11.6
2014	9	17	0	18	19	33	0	0	0	0	0	0	0	63.36	0	0	11.4
2014	9	17	0	28	19	33	0	0	0	0	0	0	0	63.36	0	0	11.4
2014	9	17	0	38	19	33	0	0	0	0	0	0	0	63.34	0	0	11.4
2014	9	17	0	48	19	33	0	0	0	0	0	0	0	63.34	0	0	11.4
2014	9	17	0	58	19	33	0	0	0	0	0	0	0	63.32	0	0	11.4
2014	9	17	1	8	19	33	0	0	0	0	0	0	0	63.32	0	0	11.4
2014	9	17	1	18	19	34	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	17	1	28	19	33	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	17	1	38	19	34	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	17	1	48	19	34	0	0	0	0	0	0	0	63.28	0	0	11.4
2014	9	17	1	58	19	33	0	0	0	0	0	0	0	63.27	0	0	11.4
2014	9	17	2	8	19	33	0	0	0	0	0	0	0	63.25	0	0	11.4
2014	9	17	2	18	19	33	0	0	0	0	0	0	0	63.25	0	0	11.4
2014	9	17	2	28	19	33	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	17	2	38	19	33	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	17	2	48	19	33	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	17	2	58	19	34	0	0	0	0	0	0	0	63.21	0	0	11.4
2014	9	17	3	8	19	33	0	0	0	0	0	0	0	63.19	0	0	11.4
2014	9	17	3	18	19	34	0	0	0	0	0	0	0	63.19	0	0	11.4
2014	9	17	3	28	19	33	0	0	0	0	0	0	0	63.18	0	0	11.4
2014	9	17	3	38	19	33	0	0	0	0	0	0	0	63.18	0	0	11.4
2014	9	17	3	48	19	33	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	17	3	58	19	33	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	17	4	8	19	33	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	17	4	18	19	33	0	0	0	0	0	0	0	63.14	0	0	11.4
2014	9	17	4	28	19	33	0	0	0	0	0	0	0	63.12	0	0	11.4
2014	9	17	4	38	19	34	0	0	0	0	0	0	0	63.12	0	0	11.4
2014	9	17	4	48	19	34	0	0	0	0	0	0	0	63.1	0	0	11.4
2014	9	17	4	58	19	34	0	0	0	0	0	0	0	63.09	0	0	11.4
2014	9	17	5	8	19	33	0	0	0	0	0	0	0	63.07	0	0	11.4
2014	9	17	5	18	19	33	0	0	0	0	0	0	0	63.05	0	0	11.4
2014	9	17	5	28	19	33	0	0	0	0	0	0	0	63.05	0	0	11.4
2014	9	17	5	38	19	34	0	0	0	0	0	0	0	63.03	0	0	11.4
2014	9	17	5	48	19	33	0	0	0	0	0	0	0	63	0	0	11.4
2014	9	17	5	58	19	33	0	0	0	0	0	0	0	62.98	0	0	11.4
2014	9	17	6	8	19	33	0	0	0	0	0	0	0	62.96	0	0	11.4
2014	9	17	6	18	19	33	0	0	0	0	0	0	0	62.94	0	0	11.4
2014	9	17	6	28	19	33	0	0	0	0	0	0	0	62.92	0	0	11.4
2014	9	17	6	38	19	34	0	0	0	0	0	0	0	62.91	0	0	11.4
2014	9	17	6	48	19	33	0	0	0	0	0	0	0	62.89	0	0	11.4
2014	9	17	6	58	19	33	0	0	0	0	0	0	0	62.87	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	7	8	19	34	0	0	0	0	0	0	0	62.85	0	0	11.4
2014	9	17	7	18	19	33	0	0	0	0	0	0	0	62.83	0	0	11.4
2014	9	17	7	28	19	33	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	17	7	38	19	33	0	0	0	0	0	0	0	62.82	0	0	11.8
2014	9	17	7	48	19	33	0	0	0	0	0	0	0	62.82	0	0	11.8
2014	9	17	7	58	19	34	0	0	0	0	0	0	0	62.8	0	0	12
2014	9	17	8	8	19	33	0	0	0	0	0	0	0	62.8	0	0	12.2
2014	9	17	8	18	19	34	0	0	0	0	0	0	0	62.8	0	0	12.4
2014	9	17	8	28	19	34	0	0	0	0	0	0	0	62.82	0	0	12.4
2014	9	17	8	38	19	34	0	0	0	0	0	0	0	62.87	0	0	12.6
2014	9	17	8	48	19	34	0	0	0	0	0	0	0	62.92	0	0	12.6
2014	9	17	8	58	19	33	0	0	0	0	0	0	0	62.96	0	0	12.6
2014	9	17	9	8	19	33	0	0	0	0	0	0	0	63.01	0	0	12.6
2014	9	17	9	18	19	34	0	0	0	0	0	0	0	63.05	0	0	12.8
2014	9	17	9	28	19	33	0	0	0	0	0	0	0	63.1	0	0	12.8
2014	9	17	9	38	19	33	0	0	0	0	0	0	0	63.16	0	0	12.8
2014	9	17	9	48	19	33	0	0	0	0	0	0	0	63.19	0	0	12.8
2014	9	17	9	58	19	33	0	0	0	0	0	0	0	63.25	0	0	13
2014	9	17	10	8	19	33	0	0	0	0	0	0	0	63.3	0	0	13
2014	9	17	10	18	19	34	0	0	0	0	0	0	0	63.37	0	0	13
2014	9	17	10	28	19	33	0	0	0	0	0	0	0	63.43	0	0	13
2014	9	17	10	38	19	34	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	17	10	48	19	34	0	0	0	0	0	0	0	63.57	0	0	13.8
2014	9	17	10	58	19	33	0	0	0	0	0	0	0	63.64	0	0	13.8
2014	9	17	11	8	19	33	0	0	0	0	0	0	0	63.7	0	0	13.8
2014	9	17	11	18	19	33	0	0	0	0	0	0	0	63.77	0	0	13.4
2014	9	17	11	28	19	33	0	0	0	0	0	0	0	63.82	0	0	13.8
2014	9	17	11	38	19	33	0	0	0	0	0	0	0	63.9	0	0	13.8
2014	9	17	11	48	19	33	0	0	0	0	0	0	0	63.97	0	0	13.6
2014	9	17	11	58	19	33	0	0	0	0	0	0	0	64.04	0	0	13.8
2014	9	17	12	8	19	34	0	0	0	0	0	0	0	64.09	0	0	13.8
2014	9	17	12	18	19	34	0	0	0	0	0	0	0	64.15	0	0	13
2014	9	17	12	28	19	34	0	0	0	0	0	0	0	64.22	0	0	13.2
2014	9	17	12	38	19	34	0	0	0	0	0	0	0	64.27	0	0	13.4
2014	9	17	12	48	19	33	0	0	0	0	0	0	0	64.31	0	0	13.4
2014	9	17	12	58	19	33	0	0	0	0	0	0	0	64.36	0	0	13.4
2014	9	17	13	8	19	34	0	0	0	0	0	0	0	64.42	0	0	13.4
2014	9	17	13	18	19	34	0	0	0	0	0	0	0	64.49	0	0	13.4
2014	9	17	13	28	19	34	0	0	0	0	0	0	0	64.53	0	0	13.4
2014	9	17	13	38	19	33	0	0	0	0	0	0	0	64.58	0	0	13.4
2014	9	17	13	48	19	33	0	0	0	0	0	0	0	64.63	0	0	13.4
2014	9	17	13	58	19	33	0	0	0	0	0	0	0	64.67	0	0	13.4
2014	9	17	14	8	19	34	0	0	0	0	0	0	0	64.69	0	0	13.4
2014	9	17	14	18	19	33	0	0	0	0	0	0	0	64.72	0	0	13.4
2014	9	17	14	28	19	33	0	0	0	0	0	0	0	64.76	0	0	13.6
2014	9	17	14	38	19	34	0	0	0	0	0	0	0	64.8	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	14	48	19	34	0	0	0	0	0	0	0	64.81	0	0	13.6
2014	9	17	14	58	19	33	0	0	0	0	0	0	0	64.81	0	0	13.6
2014	9	17	15	8	19	33	0	0	0	0	0	0	0	64.72	0	0	12.2
2014	9	17	15	18	19	33	0	0	0	0	0	0	0	64.69	0	0	12.2
2014	9	17	15	28	19	33	0	0	0	0	0	0	0	64.78	0	0	13.4
2014	9	17	15	38	19	33	0	0	0	0	0	0	0	64.85	0	0	13
2014	9	17	15	48	19	33	0	0	0	0	0	0	0	64.83	0	0	12.6
2014	9	17	15	58	19	33	0	0	0	0	0	0	0	64.9	0	0	13.4
2014	9	17	16	8	19	34	0	0	0	0	0	0	0	64.94	0	0	13.4
2014	9	17	16	18	19	33	0	0	0	0	0	0	0	64.96	0	0	13.2
2014	9	17	16	28	19	33	0	0	0	0	0	0	0	64.96	0	0	13
2014	9	17	16	38	19	33	0	0	0	0	0	0	0	64.98	0	0	12.8
2014	9	17	16	48	19	33	0	0	0	0	0	0	0	64.98	0	0	12.6
2014	9	17	16	58	19	33	0	0	0	0	0	0	0	64.98	0	0	12.4
2014	9	17	17	8	19	33	0	0	0	0	0	0	0	64.96	0	0	12.2
2014	9	17	17	18	19	33	0	0	0	0	0	0	0	64.94	0	0	12
2014	9	17	17	28	19	33	0	0	0	0	0	0	0	64.92	0	0	12
2014	9	17	17	38	19	34	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	17	17	48	19	33	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	17	17	58	19	33	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	17	18	8	19	33	0	0	0	0	0	0	0	64.92	0	0	11.8
2014	9	17	18	18	19	33	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	17	18	28	19	33	0	0	0	0	0	0	0	64.94	0	0	11.6
2014	9	17	18	38	19	33	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	9	17	18	48	19	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	17	18	58	19	33	0	0	0	0	0	0	0	64.94	0	0	11.6
2014	9	17	19	8	19	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	17	19	18	19	33	0	0	0	0	0	0	0	64.94	0	0	11.6
2014	9	17	19	28	19	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	17	19	38	19	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	17	19	48	19	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2014	9	17	19	58	19	33	0	0	0	0	0	0	0	64.9	0	0	11.6
2014	9	17	20	8	19	33	0	0	0	0	0	0	0	64.89	0	0	11.6
2014	9	17	20	18	19	33	0	0	0	0	0	0	0	64.89	0	0	11.6
2014	9	17	20	28	19	33	0	0	0	0	0	0	0	64.87	0	0	11.6
2014	9	17	20	38	19	33	0	0	0	0	0	0	0	64.87	0	0	11.6
2014	9	17	20	48	19	33	0	0	0	0	0	0	0	64.85	0	0	11.6
2014	9	17	20	58	19	33	0	0	0	0	0	0	0	64.83	0	0	11.6
2014	9	17	21	8	19	33	0	0	0	0	0	0	0	64.83	0	0	11.6
2014	9	17	21	18	19	34	0	0	0	0	0	0	0	64.81	0	0	11.6
2014	9	17	21	28	19	33	0	0	0	0	0	0	0	64.8	0	0	11.6
2014	9	17	21	38	19	33	0	0	0	0	0	0	0	64.78	0	0	11.6
2014	9	17	21	48	19	33	0	0	0	0	0	0	0	64.76	0	0	11.6
2014	9	17	21	58	19	33	0	0	0	0	0	0	0	64.74	0	0	11.6
2014	9	17	22	8	19	34	0	0	0	0	0	0	0	64.72	0	0	11.6
2014	9	17	22	18	19	33	0	0	0	0	0	0	0	64.71	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	17	22	28	19	33	0	0	0	0	0	0	0	64.69	0	0	11.6
2014	9	17	22	38	19	33	0	0	0	0	0	0	0	64.67	0	0	11.6
2014	9	17	22	48	19	33	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	17	22	58	19	33	0	0	0	0	0	0	0	64.63	0	0	11.6
2014	9	17	23	8	19	33	0	0	0	0	0	0	0	64.62	0	0	11.6
2014	9	17	23	18	19	34	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	17	23	28	19	33	0	0	0	0	0	0	0	64.58	0	0	11.6
2014	9	17	23	38	19	33	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	17	23	48	19	33	0	0	0	0	0	0	0	64.54	0	0	11.6
2014	9	17	23	58	19	32	0	0	0	0	0	0	0	64.53	0	0	11.6
2014	9	18	0	8	19	33	0	0	0	0	0	0	0	64.51	0	0	11.6
2014	9	18	0	18	19	33	0	0	0	0	0	0	0	64.51	0	0	11.6
2014	9	18	0	28	19	33	0	0	0	0	0	0	0	64.49	0	0	11.6
2014	9	18	0	38	19	33	0	0	0	0	0	0	0	64.47	0	0	11.6
2014	9	18	0	48	19	33	0	0	0	0	0	0	0	64.45	0	0	11.6
2014	9	18	0	58	19	33	0	0	0	0	0	0	0	64.45	0	0	11.6
2014	9	18	1	8	19	33	0	0	0	0	0	0	0	64.44	0	0	11.6
2014	9	18	1	18	19	33	0	0	0	0	0	0	0	64.42	0	0	11.4
2014	9	18	1	28	19	33	0	0	0	0	0	0	0	64.4	0	0	11.4
2014	9	18	1	38	19	33	0	0	0	0	0	0	0	64.38	0	0	11.6
2014	9	18	1	48	19	33	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	18	1	58	19	33	0	0	0	0	0	0	0	64.36	0	0	11.4
2014	9	18	2	8	19	33	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	18	2	18	19	33	0	0	0	0	0	0	0	64.33	0	0	11.4
2014	9	18	2	28	19	33	0	0	0	0	0	0	0	64.31	0	0	11.4
2014	9	18	2	38	19	33	0	0	0	0	0	0	0	64.29	0	0	11.4
2014	9	18	2	48	19	33	0	0	0	0	0	0	0	64.27	0	0	11.4
2014	9	18	2	58	19	33	0	0	0	0	0	0	0	64.26	0	0	11.4
2014	9	18	3	8	19	33	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	18	3	18	19	33	0	0	0	0	0	0	0	64.22	0	0	11.4
2014	9	18	3	28	19	33	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	18	3	38	19	33	0	0	0	0	0	0	0	64.18	0	0	11.4
2014	9	18	3	48	19	33	0	0	0	0	0	0	0	64.17	0	0	11.4
2014	9	18	3	58	19	34	0	0	0	0	0	0	0	64.15	0	0	11.4
2014	9	18	4	8	19	34	0	0	0	0	0	0	0	64.13	0	0	11.4
2014	9	18	4	18	19	34	0	0	0	0	0	0	0	64.11	0	0	11.4
2014	9	18	4	28	19	33	0	0	0	0	0	0	0	64.09	0	0	11.4
2014	9	18	4	38	19	33	0	0	0	0	0	0	0	64.09	0	0	11.4
2014	9	18	4	48	19	33	0	0	0	0	0	0	0	64.06	0	0	11.4
2014	9	18	4	58	19	33	0	0	0	0	0	0	0	64.06	0	0	11.4
2014	9	18	5	8	19	33	0	0	0	0	0	0	0	64.04	0	0	11.4
2014	9	18	5	18	19	33	0	0	0	0	0	0	0	64.02	0	0	11.4
2014	9	18	5	28	19	33	0	0	0	0	0	0	0	64	0	0	11.4
2014	9	18	5	38	19	34	0	0	0	0	0	0	0	63.97	0	0	11.4
2014	9	18	5	48	19	33	0	0	0	0	0	0	0	63.97	0	0	11.4
2014	9	18	5	58	19	33	0	0	0	0	0	0	0	63.95	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	6	8	19	33	0	0	0	0	0	0	0	63.93	0	0	11.4
2014	9	18	6	18	19	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	18	6	28	19	33	0	0	0	0	0	0	0	63.91	0	0	11.4
2014	9	18	6	38	19	33	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	18	6	48	19	34	0	0	0	0	0	0	0	63.88	0	0	11.4
2014	9	18	6	58	19	33	0	0	0	0	0	0	0	63.86	0	0	11.4
2014	9	18	7	8	19	33	0	0	0	0	0	0	0	63.84	0	0	11.4
2014	9	18	7	18	19	33	0	0	0	0	0	0	0	63.84	0	0	11.4
2014	9	18	7	28	19	34	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	18	7	38	19	33	0	0	0	0	0	0	0	63.81	0	0	11.8
2014	9	18	7	48	19	33	0	0	0	0	0	0	0	63.79	0	0	12
2014	9	18	7	58	19	32	0	0	0	0	0	0	0	63.79	0	0	12.2
2014	9	18	8	8	19	33	0	0	0	0	0	0	0	63.79	0	0	12.2
2014	9	18	8	18	19	33	0	0	0	0	0	0	0	63.79	0	0	12.4
2014	9	18	8	28	19	33	0	0	0	0	0	0	0	63.79	0	0	12.4
2014	9	18	8	38	19	34	0	0	0	0	0	0	0	63.84	0	0	12.4
2014	9	18	8	48	19	33	0	0	0	0	0	0	0	63.88	0	0	12.4
2014	9	18	8	58	19	33	0	0	0	0	0	0	0	63.91	0	0	12.4
2014	9	18	9	8	19	33	0	0	0	0	0	0	0	63.95	0	0	12.6
2014	9	18	9	18	19	33	0	0	0	0	0	0	0	63.99	0	0	12.8
2014	9	18	9	28	19	33	0	0	0	0	0	0	0	64.02	0	0	12.8
2014	9	18	9	38	19	33	0	0	0	0	0	0	0	64.04	0	0	13
2014	9	18	9	48	19	33	0	0	0	0	0	0	0	64.09	0	0	13.2
2014	9	18	9	58	19	33	0	0	0	0	0	0	0	64.13	0	0	13.8
2014	9	18	10	8	19	33	0	0	0	0	0	0	0	64.18	0	0	13.8
2014	9	18	10	18	19	33	0	0	0	0	0	0	0	64.22	0	0	13.6
2014	9	18	10	28	19	34	0	0	0	0	0	0	0	64.27	0	0	13.6
2014	9	18	10	38	19	33	0	0	0	0	0	0	0	64.31	0	0	14
2014	9	18	10	48	19	34	0	0	0	0	0	0	0	64.36	0	0	13.8
2014	9	18	10	58	19	33	0	0	0	0	0	0	0	64.42	0	0	13.8
2014	9	18	11	8	19	33	0	0	0	0	0	0	0	64.49	0	0	14
2014	9	18	11	18	19	33	0	0	0	0	0	0	0	64.53	0	0	13.4
2014	9	18	11	28	19	34	0	0	0	0	0	0	0	64.6	0	0	13.4
2014	9	18	11	38	19	33	0	0	0	0	0	0	0	64.69	0	0	13.6
2014	9	18	11	48	19	33	0	0	0	0	0	0	0	64.72	0	0	13.8
2014	9	18	11	58	19	33	0	0	0	0	0	0	0	64.8	0	0	13.8
2014	9	18	12	8	19	33	0	0	0	0	0	0	0	64.8	0	0	13.8
2014	9	18	12	18	19	33	0	0	0	0	0	0	0	64.87	0	0	13.4
2014	9	18	12	28	19	33	0	0	0	0	0	0	0	64.92	0	0	13.4
2014	9	18	12	38	19	33	0	0	0	0	0	0	0	64.98	0	0	13.4
2014	9	18	12	48	19	33	0	0	0	0	0	0	0	65.01	0	0	13.4
2014	9	18	12	58	19	34	0	0	0	0	0	0	0	65.05	0	0	13.4
2014	9	18	13	8	19	33	0	0	0	0	0	0	0	65.1	0	0	13.4
2014	9	18	13	18	19	33	0	0	0	0	0	0	0	65.14	0	0	13.4
2014	9	18	13	28	19	33	0	0	0	0	0	0	0	65.17	0	0	13.4
2014	9	18	13	38	19	33	0	0	0	0	0	0	0	65.21	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	13	48	19	33	0	0	0	0	0	0	0	65.25	0	0	13.4
2014	9	18	13	58	19	33	0	0	0	0	0	0	0	65.28	0	0	13.2
2014	9	18	14	8	19	34	0	0	0	0	0	0	0	65.32	0	0	13.2
2014	9	18	14	18	19	33	0	0	0	0	0	0	0	65.32	0	0	13.2
2014	9	18	14	28	19	33	0	0	0	0	0	0	0	65.34	0	0	13.2
2014	9	18	14	38	19	34	0	0	0	0	0	0	0	65.35	0	0	13.2
2014	9	18	14	48	19	33	0	0	0	0	0	0	0	65.39	0	0	13.2
2014	9	18	14	58	19	33	0	0	0	0	0	0	0	65.41	0	0	13
2014	9	18	15	8	19	34	0	0	0	0	0	0	0	65.43	0	0	13
2014	9	18	15	18	19	33	0	0	0	0	0	0	0	65.44	0	0	13
2014	9	18	15	28	19	33	0	0	0	0	0	0	0	65.44	0	0	13
2014	9	18	15	38	19	33	0	0	0	0	0	0	0	65.46	0	0	13
2014	9	18	15	48	19	33	0	0	0	0	0	0	0	65.44	0	0	13
2014	9	18	15	58	19	33	0	0	0	0	0	0	0	65.46	0	0	13
2014	9	18	16	8	19	33	0	0	0	0	0	0	0	65.46	0	0	12.8
2014	9	18	16	18	19	34	0	0	0	0	0	0	0	65.46	0	0	12.6
2014	9	18	16	28	19	33	0	0	0	0	0	0	0	65.48	0	0	12.6
2014	9	18	16	38	19	33	0	0	0	0	0	0	0	65.46	0	0	12.4
2014	9	18	16	48	19	33	0	0	0	0	0	0	0	65.46	0	0	12.4
2014	9	18	16	58	19	33	0	0	0	0	0	0	0	65.44	0	0	12.4
2014	9	18	17	8	19	32	0	0	0	0	0	0	0	65.43	0	0	12.2
2014	9	18	17	18	19	33	0	0	0	0	0	0	0	65.39	0	0	12
2014	9	18	17	28	19	34	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	9	18	17	38	19	34	0	0	0	0	0	0	0	65.34	0	0	11.8
2014	9	18	17	48	19	33	0	0	0	0	0	0	0	65.34	0	0	11.6
2014	9	18	17	58	19	33	0	0	0	0	0	0	0	65.32	0	0	11.6
2014	9	18	18	8	19	34	0	0	0	0	0	0	0	65.32	0	0	11.6
2014	9	18	18	18	19	33	0	0	0	0	0	0	0	65.32	0	0	11.6
2014	9	18	18	28	19	34	0	0	0	0	0	0	0	65.3	0	0	11.6
2014	9	18	18	38	19	33	0	0	0	0	0	0	0	65.3	0	0	11.6
2014	9	18	18	48	19	33	0	0	0	0	0	0	0	65.28	0	0	11.6
2014	9	18	18	58	19	33	0	0	0	0	0	0	0	65.28	0	0	11.4
2014	9	18	19	8	19	33	0	0	0	0	0	0	0	65.26	0	0	11.6
2014	9	18	19	18	19	33	0	0	0	0	0	0	0	65.26	0	0	11.6
2014	9	18	19	28	19	33	0	0	0	0	0	0	0	65.25	0	0	11.6
2014	9	18	19	38	19	33	0	0	0	0	0	0	0	65.23	0	0	11.6
2014	9	18	19	48	19	33	0	0	0	0	0	0	0	65.23	0	0	11.6
2014	9	18	19	58	19	33	0	0	0	0	0	0	0	65.21	0	0	11.6
2014	9	18	20	8	19	33	0	0	0	0	0	0	0	65.21	0	0	11.6
2014	9	18	20	18	19	34	0	0	0	0	0	0	0	65.19	0	0	11.6
2014	9	18	20	28	19	34	0	0	0	0	0	0	0	65.17	0	0	11.6
2014	9	18	20	38	19	33	0	0	0	0	0	0	0	65.16	0	0	11.6
2014	9	18	20	48	19	34	0	0	0	0	0	0	0	65.16	0	0	11.4
2014	9	18	20	58	19	33	0	0	0	0	0	0	0	65.14	0	0	11.4
2014	9	18	21	8	19	33	0	0	0	0	0	0	0	65.12	0	0	11.4
2014	9	18	21	18	19	33	0	0	0	0	0	0	0	65.1	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	18	21	28	19	34	0	0	0	0	0	0	0	65.08	0	0	11.4
2014	9	18	21	38	19	33	0	0	0	0	0	0	0	65.07	0	0	11.4
2014	9	18	21	48	19	33	0	0	0	0	0	0	0	65.03	0	0	11.4
2014	9	18	21	58	19	33	0	0	0	0	0	0	0	65.01	0	0	11.6
2014	9	18	22	8	19	33	0	0	0	0	0	0	0	64.99	0	0	11.4
2014	9	18	22	18	19	34	0	0	0	0	0	0	0	64.98	0	0	11.4
2014	9	18	22	28	19	33	0	0	0	0	0	0	0	64.94	0	0	11.4
2014	9	18	22	38	19	33	0	0	0	0	0	0	0	64.92	0	0	11.4
2014	9	18	22	48	19	33	0	0	0	0	0	0	0	64.9	0	0	11.4
2014	9	18	22	58	19	33	0	0	0	0	0	0	0	64.89	0	0	11.4
2014	9	18	23	8	19	34	0	0	0	0	0	0	0	64.87	0	0	11.4
2014	9	18	23	18	19	32	0	0	0	0	0	0	0	64.85	0	0	11.4
2014	9	18	23	28	19	34	0	0	0	0	0	0	0	64.81	0	0	11.4
2014	9	18	23	38	19	33	0	0	0	0	0	0	0	64.8	0	0	11.4
2014	9	18	23	48	19	33	0	0	0	0	0	0	0	64.78	0	0	11.4
2014	9	18	23	58	19	33	0	0	0	0	0	0	0	64.76	0	0	11.4
2014	9	19	0	8	19	33	0	0	0	0	0	0	0	64.74	0	0	11.4
2014	9	19	0	18	19	33	0	0	0	0	0	0	0	64.71	0	0	11.4
2014	9	19	0	28	19	33	0	0	0	0	0	0	0	64.69	0	0	11.4
2014	9	19	0	38	19	33	0	0	0	0	0	0	0	64.65	0	0	11.4
2014	9	19	0	48	19	33	0	0	0	0	0	0	0	64.62	0	0	11.4
2014	9	19	0	58	19	33	0	0	0	0	0	0	0	64.6	0	0	11.4
2014	9	19	1	8	19	32	0	0	0	0	0	0	0	64.54	0	0	11.4
2014	9	19	1	18	19	33	0	0	0	0	0	0	0	64.51	0	0	11.4
2014	9	19	1	28	19	33	0	0	0	0	0	0	0	64.47	0	0	11.4
2014	9	19	1	38	19	33	0	0	0	0	0	0	0	64.42	0	0	11.4
2014	9	19	1	48	19	33	0	0	0	0	0	0	0	64.38	0	0	11.4
2014	9	19	1	58	19	33	0	0	0	0	0	0	0	64.35	0	0	11.4
2014	9	19	2	8	19	33	0	0	0	0	0	0	0	64.31	0	0	11.4
2014	9	19	2	18	19	33	0	0	0	0	0	0	0	64.27	0	0	11.4
2014	9	19	2	28	19	34	0	0	0	0	0	0	0	64.24	0	0	11.4
2014	9	19	2	38	19	33	0	0	0	0	0	0	0	64.2	0	0	11.4
2014	9	19	2	48	19	32	0	0	0	0	0	0	0	64.17	0	0	11.6
2014	9	19	2	58	19	33	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	19	3	8	19	33	0	0	0	0	0	0	0	64.08	0	0	11.4
2014	9	19	3	18	19	33	0	0	0	0	0	0	0	64.02	0	0	11.4
2014	9	19	3	28	19	33	0	0	0	0	0	0	0	63.99	0	0	11.4
2014	9	19	3	38	19	33	0	0	0	0	0	0	0	63.93	0	0	11.4
2014	9	19	3	48	19	34	0	0	0	0	0	0	0	63.9	0	0	11.4
2014	9	19	3	58	19	34	0	0	0	0	0	0	0	63.84	0	0	11.4
2014	9	19	4	8	19	34	0	0	0	0	0	0	0	63.81	0	0	11.4
2014	9	19	4	18	19	33	0	0	0	0	0	0	0	63.75	0	0	11.4
2014	9	19	4	28	19	33	0	0	0	0	0	0	0	63.73	0	0	11.4
2014	9	19	4	38	19	34	0	0	0	0	0	0	0	63.68	0	0	11.4
2014	9	19	4	48	19	32	0	0	0	0	0	0	0	63.66	0	0	11.4
2014	9	19	4	58	19	34	0	0	0	0	0	0	0	63.63	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	5	8	19	33	0	0	0	0	0	0	0	63.57	0	0	11.4
2014	9	19	5	18	19	33	0	0	0	0	0	0	0	63.55	0	0	11.4
2014	9	19	5	28	19	34	0	0	0	0	0	0	0	63.52	0	0	11.4
2014	9	19	5	38	19	33	0	0	0	0	0	0	0	63.48	0	0	11.4
2014	9	19	5	48	19	34	0	0	0	0	0	0	0	63.45	0	0	11.4
2014	9	19	5	58	19	34	0	0	0	0	0	0	0	63.41	0	0	11.4
2014	9	19	6	8	19	34	0	0	0	0	0	0	0	63.36	0	0	11.4
2014	9	19	6	18	19	34	0	0	0	0	0	0	0	63.32	0	0	11.4
2014	9	19	6	28	19	32	0	0	0	0	0	0	0	63.27	0	0	11.4
2014	9	19	6	38	19	33	0	0	0	0	0	0	0	63.25	0	0	11.4
2014	9	19	6	48	19	32	0	0	0	0	0	0	0	63.21	0	0	11.4
2014	9	19	6	58	19	33	0	0	0	0	0	0	0	63.18	0	0	11.4
2014	9	19	7	8	19	33	0	0	0	0	0	0	0	63.14	0	0	11.4
2014	9	19	7	18	19	33	0	0	0	0	0	0	0	63.12	0	0	11.4
2014	9	19	7	28	19	34	0	0	0	0	0	0	0	63.09	0	0	11.6
2014	9	19	7	38	19	33	0	0	0	0	0	0	0	63.07	0	0	11.6
2014	9	19	7	48	19	33	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	19	7	58	19	33	0	0	0	0	0	0	0	63.05	0	0	11.8
2014	9	19	8	8	19	33	0	0	0	0	0	0	0	63.03	0	0	12
2014	9	19	8	18	19	33	0	0	0	0	0	0	0	63.01	0	0	12.2
2014	9	19	8	28	19	34	0	0	0	0	0	0	0	63.01	0	0	12.2
2014	9	19	8	38	19	33	0	0	0	0	0	0	0	63.03	0	0	12.4
2014	9	19	8	48	19	33	0	0	0	0	0	0	0	63.07	0	0	12.4
2014	9	19	8	58	19	33	0	0	0	0	0	0	0	63.09	0	0	12.4
2014	9	19	9	8	19	33	0	0	0	0	0	0	0	63.12	0	0	12.4
2014	9	19	9	18	19	33	0	0	0	0	0	0	0	63.16	0	0	12.4
2014	9	19	9	28	19	33	0	0	0	0	0	0	0	63.21	0	0	12.6
2014	9	19	9	38	19	34	0	0	0	0	0	0	0	63.23	0	0	12.6
2014	9	19	9	48	19	33	0	0	0	0	0	0	0	63.27	0	0	12.6
2014	9	19	9	58	19	34	0	0	0	0	0	0	0	63.3	0	0	12.6
2014	9	19	10	8	19	33	0	0	0	0	0	0	0	63.34	0	0	12.8
2014	9	19	10	18	19	33	0	0	0	0	0	0	0	63.39	0	0	12.8
2014	9	19	10	28	19	33	0	0	0	0	0	0	0	63.45	0	0	13
2014	9	19	10	38	19	34	0	0	0	0	0	0	0	63.5	0	0	13.4
2014	9	19	10	48	19	33	0	0	0	0	0	0	0	63.55	0	0	13.4
2014	9	19	10	58	19	32	0	0	0	0	0	0	0	63.61	0	0	13.4
2014	9	19	11	8	19	34	0	0	0	0	0	0	0	63.68	0	0	13.4
2014	9	19	11	18	19	33	0	0	0	0	0	0	0	63.73	0	0	13.4
2014	9	19	11	28	19	33	0	0	0	0	0	0	0	63.79	0	0	13.4
2014	9	19	11	38	19	34	0	0	0	0	0	0	0	63.84	0	0	13.2
2014	9	19	11	48	19	33	0	0	0	0	0	0	0	63.9	0	0	13.2
2014	9	19	11	58	19	33	0	0	0	0	0	0	0	63.93	0	0	13.2
2014	9	19	12	8	19	33	0	0	0	0	0	0	0	63.99	0	0	13.2
2014	9	19	12	18	19	34	0	0	0	0	0	0	0	64.02	0	0	13.2
2014	9	19	12	28	19	33	0	0	0	0	0	0	0	64.06	0	0	13.2
2014	9	19	12	38	19	33	0	0	0	0	0	0	0	64.11	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	12	48	19	32	0	0	0	0	0	0	0	64.15	0	0	13.2
2014	9	19	12	58	19	33	0	0	0	0	0	0	0	64.18	0	0	13.2
2014	9	19	13	8	19	34	0	0	0	0	0	0	0	64.24	0	0	13.2
2014	9	19	13	18	19	33	0	0	0	0	0	0	0	64.27	0	0	13.2
2014	9	19	13	28	19	33	0	0	0	0	0	0	0	64.31	0	0	13.2
2014	9	19	13	38	19	34	0	0	0	0	0	0	0	64.33	0	0	13.4
2014	9	19	13	48	19	33	0	0	0	0	0	0	0	64.38	0	0	13.4
2014	9	19	13	58	19	34	0	0	0	0	0	0	0	64.4	0	0	13.4
2014	9	19	14	8	19	33	0	0	0	0	0	0	0	64.44	0	0	13.4
2014	9	19	14	18	19	34	0	0	0	0	0	0	0	64.47	0	0	13.4
2014	9	19	14	28	19	33	0	0	0	0	0	0	0	64.47	0	0	13.4
2014	9	19	14	38	19	33	0	0	0	0	0	0	0	64.51	0	0	13.4
2014	9	19	14	48	19	34	0	0	0	0	0	0	0	64.53	0	0	13.2
2014	9	19	14	58	19	32	0	0	0	0	0	0	0	64.56	0	0	13
2014	9	19	15	8	19	33	0	0	0	0	0	0	0	64.58	0	0	13
2014	9	19	15	18	19	33	0	0	0	0	0	0	0	64.58	0	0	13
2014	9	19	15	28	19	33	0	0	0	0	0	0	0	64.6	0	0	13
2014	9	19	15	38	19	33	0	0	0	0	0	0	0	64.62	0	0	13
2014	9	19	15	48	19	33	0	0	0	0	0	0	0	64.62	0	0	13
2014	9	19	15	58	19	32	0	0	0	0	0	0	0	64.63	0	0	13.2
2014	9	19	16	8	19	33	0	0	0	0	0	0	0	64.63	0	0	13.2
2014	9	19	16	18	19	34	0	0	0	0	0	0	0	64.63	0	0	13
2014	9	19	16	28	19	34	0	0	0	0	0	0	0	64.65	0	0	12.8
2014	9	19	16	38	19	34	0	0	0	0	0	0	0	64.65	0	0	12.6
2014	9	19	16	48	19	34	0	0	0	0	0	0	0	64.65	0	0	12.6
2014	9	19	16	58	19	33	0	0	0	0	0	0	0	64.65	0	0	12.4
2014	9	19	17	8	19	34	0	0	0	0	0	0	0	64.67	0	0	12.4
2014	9	19	17	18	19	33	0	0	0	0	0	0	0	64.65	0	0	12.2
2014	9	19	17	28	19	33	0	0	0	0	0	0	0	64.63	0	0	12.2
2014	9	19	17	38	19	33	0	0	0	0	0	0	0	64.65	0	0	12
2014	9	19	17	48	19	33	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	19	17	58	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	18	8	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	18	18	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	18	28	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	18	38	19	33	0	0	0	0	0	0	0	64.65	0	0	11.8
2014	9	19	18	48	19	33	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	19	18	58	19	33	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	19	19	8	19	32	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	9	19	19	18	19	33	0	0	0	0	0	0	0	64.62	0	0	11.8
2014	9	19	19	28	19	34	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	19	19	38	19	33	0	0	0	0	0	0	0	64.6	0	0	11.6
2014	9	19	19	48	19	33	0	0	0	0	0	0	0	64.58	0	0	11.6
2014	9	19	19	58	19	33	0	0	0	0	0	0	0	64.56	0	0	11.6
2014	9	19	20	8	19	33	0	0	0	0	0	0	0	64.54	0	0	11.6
2014	9	19	20	18	19	33	0	0	0	0	0	0	0	64.53	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	19	20	28	19	33	0	0	0	0	0	0	0	64.51	0	0	11.6
2014	9	19	20	38	19	33	0	0	0	0	0	0	0	64.47	0	0	11.6
2014	9	19	20	48	19	33	0	0	0	0	0	0	0	64.45	0	0	11.6
2014	9	19	20	58	19	33	0	0	0	0	0	0	0	64.42	0	0	11.6
2014	9	19	21	8	19	32	0	0	0	0	0	0	0	64.4	0	0	11.6
2014	9	19	21	18	19	33	0	0	0	0	0	0	0	64.36	0	0	11.6
2014	9	19	21	28	19	34	0	0	0	0	0	0	0	64.35	0	0	11.6
2014	9	19	21	38	19	33	0	0	0	0	0	0	0	64.31	0	0	11.6
2014	9	19	21	48	19	33	0	0	0	0	0	0	0	64.27	0	0	11.6
2014	9	19	21	58	19	33	0	0	0	0	0	0	0	64.26	0	0	11.6
2014	9	19	22	8	19	33	0	0	0	0	0	0	0	64.22	0	0	11.6
2014	9	19	22	18	19	34	0	0	0	0	0	0	0	64.18	0	0	11.6
2014	9	19	22	28	19	33	0	0	0	0	0	0	0	64.17	0	0	11.6
2014	9	19	22	38	19	33	0	0	0	0	0	0	0	64.13	0	0	11.6
2014	9	19	22	48	19	33	0	0	0	0	0	0	0	64.08	0	0	11.6
2014	9	19	22	58	19	34	0	0	0	0	0	0	0	64.04	0	0	11.6
2014	9	19	23	8	19	33	0	0	0	0	0	0	0	64.02	0	0	11.6
2014	9	19	23	18	19	33	0	0	0	0	0	0	0	63.97	0	0	11.6
2014	9	19	23	28	19	34	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	19	23	38	19	33	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	19	23	48	19	33	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	19	23	58	19	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	20	0	8	19	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	20	0	18	19	33	0	0	0	0	0	0	0	63.72	0	0	11.6
2014	9	20	0	28	19	33	0	0	0	0	0	0	0	63.68	0	0	11.6
2014	9	20	0	38	19	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	20	0	48	19	34	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	20	0	58	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	20	1	8	19	34	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	20	1	18	19	33	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	20	1	28	19	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	20	1	38	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	20	1	48	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	20	1	58	19	33	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	20	2	8	19	34	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	20	2	18	19	33	0	0	0	0	0	0	0	63.23	0	0	11.4
2014	9	20	2	28	19	34	0	0	0	0	0	0	0	63.19	0	0	11.4
2014	9	20	2	38	19	34	0	0	0	0	0	0	0	63.16	0	0	11.4
2014	9	20	2	48	19	34	0	0	0	0	0	0	0	63.1	0	0	11.4
2014	9	20	2	58	19	33	0	0	0	0	0	0	0	63.07	0	0	11.4
2014	9	20	3	8	19	33	0	0	0	0	0	0	0	63.01	0	0	11.4
2014	9	20	3	18	19	33	0	0	0	0	0	0	0	62.98	0	0	11.6
2014	9	20	3	28	19	34	0	0	0	0	0	0	0	62.92	0	0	11.6
2014	9	20	3	38	19	33	0	0	0	0	0	0	0	62.87	0	0	11.6
2014	9	20	3	48	19	34	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	20	3	58	19	34	0	0	0	0	0	0	0	62.76	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	4	8	19	33	0	0	0	0	0	0	0	62.73	0	0	11.6
2014	9	20	4	18	19	34	0	0	0	0	0	0	0	62.67	0	0	11.4
2014	9	20	4	28	19	33	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	20	4	38	19	33	0	0	0	0	0	0	0	62.56	0	0	11.4
2014	9	20	4	48	19	34	0	0	0	0	0	0	0	62.51	0	0	11.4
2014	9	20	4	58	19	33	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	20	5	8	19	33	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	20	5	18	19	33	0	0	0	0	0	0	0	62.37	0	0	11.4
2014	9	20	5	28	19	33	0	0	0	0	0	0	0	62.33	0	0	11.4
2014	9	20	5	38	19	33	0	0	0	0	0	0	0	62.28	0	0	11.4
2014	9	20	5	48	19	33	0	0	0	0	0	0	0	62.24	0	0	11.4
2014	9	20	5	58	19	33	0	0	0	0	0	0	0	62.2	0	0	11.4
2014	9	20	6	8	19	34	0	0	0	0	0	0	0	62.15	0	0	11.4
2014	9	20	6	18	19	34	0	0	0	0	0	0	0	62.1	0	0	11.4
2014	9	20	6	28	19	34	0	0	0	0	0	0	0	62.04	0	0	11.4
2014	9	20	6	38	19	33	0	0	0	0	0	0	0	61.99	0	0	11.4
2014	9	20	6	48	19	33	0	0	0	0	0	0	0	61.95	0	0	11.4
2014	9	20	6	58	19	34	0	0	0	0	0	0	0	61.9	0	0	11.4
2014	9	20	7	8	19	33	0	0	0	0	0	0	0	61.86	0	0	11.4
2014	9	20	7	18	19	33	0	0	0	0	0	0	0	61.84	0	0	11.4
2014	9	20	7	28	19	33	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	20	7	38	19	33	0	0	0	0	0	0	0	61.77	0	0	11.8
2014	9	20	7	48	19	33	0	0	0	0	0	0	0	61.74	0	0	11.8
2014	9	20	7	58	19	34	0	0	0	0	0	0	0	61.72	0	0	12.2
2014	9	20	8	8	19	34	0	0	0	0	0	0	0	61.7	0	0	12.4
2014	9	20	8	18	19	34	0	0	0	0	0	0	0	61.68	0	0	12.4
2014	9	20	8	28	19	33	0	0	0	0	0	0	0	61.66	0	0	12.6
2014	9	20	8	38	19	33	0	0	0	0	0	0	0	61.66	0	0	12.2
2014	9	20	8	48	19	33	0	0	0	0	0	0	0	61.7	0	0	12.4
2014	9	20	8	58	19	34	0	0	0	0	0	0	0	61.77	0	0	12.6
2014	9	20	9	8	19	33	0	0	0	0	0	0	0	61.79	0	0	12.6
2014	9	20	9	18	19	34	0	0	0	0	0	0	0	61.79	0	0	12.6
2014	9	20	9	28	19	33	0	0	0	0	0	0	0	61.79	0	0	12.4
2014	9	20	9	38	19	33	0	0	0	0	0	0	0	61.88	0	0	12.8
2014	9	20	9	48	19	34	0	0	0	0	0	0	0	61.9	0	0	12.8
2014	9	20	9	58	19	34	0	0	0	0	0	0	0	61.97	0	0	12.8
2014	9	20	10	8	19	34	0	0	0	0	0	0	0	62.02	0	0	13
2014	9	20	10	18	19	34	0	0	0	0	0	0	0	61.92	0	0	12.4
2014	9	20	10	28	19	34	0	0	0	0	0	0	0	62.02	0	0	12.6
2014	9	20	10	38	19	33	0	0	0	0	0	0	0	62.08	0	0	13.2
2014	9	20	10	48	19	34	0	0	0	0	0	0	0	62.2	0	0	13.4
2014	9	20	10	58	19	33	0	0	0	0	0	0	0	62.29	0	0	13.4
2014	9	20	11	8	19	33	0	0	0	0	0	0	0	62.4	0	0	13.2
2014	9	20	11	18	19	33	0	0	0	0	0	0	0	62.46	0	0	13
2014	9	20	11	28	19	33	0	0	0	0	0	0	0	62.53	0	0	13
2014	9	20	11	38	19	33	0	0	0	0	0	0	0	62.62	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	11	48	19	33	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	20	11	58	19	33	0	0	0	0	0	0	0	62.74	0	0	12.8
2014	9	20	12	8	19	34	0	0	0	0	0	0	0	62.8	0	0	12.8
2014	9	20	12	18	19	33	0	0	0	0	0	0	0	62.85	0	0	12.8
2014	9	20	12	28	19	33	0	0	0	0	0	0	0	62.89	0	0	12.8
2014	9	20	12	38	19	33	0	0	0	0	0	0	0	62.96	0	0	12.8
2014	9	20	12	48	19	33	0	0	0	0	0	0	0	62.96	0	0	12.6
2014	9	20	12	58	19	34	0	0	0	0	0	0	0	63.05	0	0	12.8
2014	9	20	13	8	19	33	0	0	0	0	0	0	0	63.1	0	0	12.8
2014	9	20	13	18	19	33	0	0	0	0	0	0	0	63.16	0	0	12.8
2014	9	20	13	28	19	33	0	0	0	0	0	0	0	63.21	0	0	12.8
2014	9	20	13	38	19	33	0	0	0	0	0	0	0	63.27	0	0	12.8
2014	9	20	13	48	19	34	0	0	0	0	0	0	0	63.28	0	0	12.8
2014	9	20	13	58	19	33	0	0	0	0	0	0	0	63.27	0	0	12.8
2014	9	20	14	8	19	33	0	0	0	0	0	0	0	63.27	0	0	12.8
2014	9	20	14	18	19	34	0	0	0	0	0	0	0	63.36	0	0	12.8
2014	9	20	14	28	19	33	0	0	0	0	0	0	0	63.23	0	0	12.6
2014	9	20	14	38	19	34	0	0	0	0	0	0	0	63.3	0	0	12.8
2014	9	20	14	48	19	33	0	0	0	0	0	0	0	63.39	0	0	13
2014	9	20	14	58	19	34	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	20	15	8	19	33	0	0	0	0	0	0	0	63.48	0	0	13.2
2014	9	20	15	18	19	34	0	0	0	0	0	0	0	63.52	0	0	12.8
2014	9	20	15	28	19	33	0	0	0	0	0	0	0	63.55	0	0	12.8
2014	9	20	15	38	19	34	0	0	0	0	0	0	0	63.57	0	0	12.8
2014	9	20	15	48	19	34	0	0	0	0	0	0	0	63.61	0	0	12.8
2014	9	20	15	58	19	33	0	0	0	0	0	0	0	63.63	0	0	12.8
2014	9	20	16	8	19	33	0	0	0	0	0	0	0	63.63	0	0	12.8
2014	9	20	16	18	19	33	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	20	16	28	19	33	0	0	0	0	0	0	0	63.66	0	0	12.8
2014	9	20	16	38	19	33	0	0	0	0	0	0	0	63.68	0	0	12.8
2014	9	20	16	48	19	33	0	0	0	0	0	0	0	63.66	0	0	12.6
2014	9	20	16	58	19	33	0	0	0	0	0	0	0	63.66	0	0	12.2
2014	9	20	17	8	19	33	0	0	0	0	0	0	0	63.64	0	0	12
2014	9	20	17	18	19	33	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	20	17	28	19	33	0	0	0	0	0	0	0	63.63	0	0	11.8
2014	9	20	17	38	19	32	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	20	17	48	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	20	17	58	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	20	18	8	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	20	18	18	19	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	20	18	28	19	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	20	18	38	19	34	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	20	18	48	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	20	18	58	19	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	20	19	8	19	33	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	20	19	18	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	20	19	28	19	33	0	0	0	0	0	0	0	63.64	0	0	11.6
2014	9	20	19	38	19	34	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	20	19	48	19	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	20	19	58	19	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	20	20	8	19	33	0	0	0	0	0	0	0	63.61	0	0	11.6
2014	9	20	20	18	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	20	20	28	19	33	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	20	20	38	19	33	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	20	20	48	19	34	0	0	0	0	0	0	0	63.57	0	0	11.6
2014	9	20	20	58	19	33	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	20	21	8	19	34	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	20	21	18	19	33	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	20	21	28	19	33	0	0	0	0	0	0	0	63.52	0	0	11.6
2014	9	20	21	38	19	33	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	20	21	48	19	32	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	20	21	58	19	34	0	0	0	0	0	0	0	63.48	0	0	11.6
2014	9	20	22	8	19	33	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	20	22	18	19	34	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	20	22	28	19	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	20	22	38	19	33	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	20	22	48	19	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	20	22	58	19	34	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	20	23	8	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	20	23	18	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	20	23	28	19	34	0	0	0	0	0	0	0	63.34	0	0	11.6
2014	9	20	23	38	19	33	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	20	23	48	19	33	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	20	23	58	19	33	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	21	0	8	19	33	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	21	0	18	19	34	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	21	0	28	19	34	0	0	0	0	0	0	0	63.25	0	0	11.6
2014	9	21	0	38	19	34	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	21	0	48	19	33	0	0	0	0	0	0	0	63.19	0	0	11.6
2014	9	21	0	58	19	34	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	21	1	8	19	33	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	21	1	18	19	33	0	0	0	0	0	0	0	63.14	0	0	11.4
2014	9	21	1	28	19	34	0	0	0	0	0	0	0	63.12	0	0	11.4
2014	9	21	1	38	19	34	0	0	0	0	0	0	0	63.09	0	0	11.4
2014	9	21	1	48	19	34	0	0	0	0	0	0	0	63.07	0	0	11.4
2014	9	21	1	58	19	33	0	0	0	0	0	0	0	63.05	0	0	11.4
2014	9	21	2	8	19	33	0	0	0	0	0	0	0	63.03	0	0	11.4
2014	9	21	2	18	19	33	0	0	0	0	0	0	0	63.01	0	0	11.4
2014	9	21	2	28	19	34	0	0	0	0	0	0	0	63	0	0	11.4
2014	9	21	2	38	19	34	0	0	0	0	0	0	0	62.96	0	0	11.4
2014	9	21	2	48	19	34	0	0	0	0	0	0	0	62.94	0	0	11.4
2014	9	21	2	58	19	33	0	0	0	0	0	0	0	62.92	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	3	8	19	33	0	0	0	0	0	0	0	62.91	0	0	11.4
2014	9	21	3	18	19	34	0	0	0	0	0	0	0	62.89	0	0	11.4
2014	9	21	3	28	19	33	0	0	0	0	0	0	0	62.87	0	0	11.4
2014	9	21	3	38	19	34	0	0	0	0	0	0	0	62.83	0	0	11.4
2014	9	21	3	48	19	33	0	0	0	0	0	0	0	62.83	0	0	11.4
2014	9	21	3	58	19	33	0	0	0	0	0	0	0	62.8	0	0	11.4
2014	9	21	4	8	19	34	0	0	0	0	0	0	0	62.78	0	0	11.4
2014	9	21	4	18	19	34	0	0	0	0	0	0	0	62.76	0	0	11.4
2014	9	21	4	28	19	34	0	0	0	0	0	0	0	62.74	0	0	11.4
2014	9	21	4	38	19	34	0	0	0	0	0	0	0	62.73	0	0	11.4
2014	9	21	4	48	19	34	0	0	0	0	0	0	0	62.71	0	0	11.4
2014	9	21	4	58	19	34	0	0	0	0	0	0	0	62.67	0	0	11.4
2014	9	21	5	8	19	33	0	0	0	0	0	0	0	62.65	0	0	11.4
2014	9	21	5	18	19	34	0	0	0	0	0	0	0	62.64	0	0	11.4
2014	9	21	5	28	19	33	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	21	5	38	19	34	0	0	0	0	0	0	0	62.62	0	0	11.4
2014	9	21	5	48	19	33	0	0	0	0	0	0	0	62.58	0	0	11.4
2014	9	21	5	58	19	34	0	0	0	0	0	0	0	62.56	0	0	11.4
2014	9	21	6	8	19	34	0	0	0	0	0	0	0	62.55	0	0	11.4
2014	9	21	6	18	19	33	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	21	6	28	19	34	0	0	0	0	0	0	0	62.51	0	0	11.4
2014	9	21	6	38	19	33	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	21	6	48	19	34	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	21	6	58	19	34	0	0	0	0	0	0	0	62.44	0	0	11.4
2014	9	21	7	8	19	34	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	21	7	18	19	33	0	0	0	0	0	0	0	62.4	0	0	11.4
2014	9	21	7	28	19	34	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	21	7	38	19	33	0	0	0	0	0	0	0	62.37	0	0	11.8
2014	9	21	7	48	19	34	0	0	0	0	0	0	0	62.35	0	0	12
2014	9	21	7	58	19	33	0	0	0	0	0	0	0	62.33	0	0	12.2
2014	9	21	8	8	19	33	0	0	0	0	0	0	0	62.33	0	0	12.2
2014	9	21	8	18	19	34	0	0	0	0	0	0	0	62.33	0	0	12.4
2014	9	21	8	28	19	33	0	0	0	0	0	0	0	62.33	0	0	12.4
2014	9	21	8	38	19	33	0	0	0	0	0	0	0	62.38	0	0	12.4
2014	9	21	8	48	19	34	0	0	0	0	0	0	0	62.44	0	0	12.4
2014	9	21	8	58	19	33	0	0	0	0	0	0	0	62.47	0	0	12.4
2014	9	21	9	8	19	34	0	0	0	0	0	0	0	62.49	0	0	12.6
2014	9	21	9	18	19	34	0	0	0	0	0	0	0	62.53	0	0	12.6
2014	9	21	9	28	19	33	0	0	0	0	0	0	0	62.56	0	0	12.6
2014	9	21	9	38	19	34	0	0	0	0	0	0	0	62.6	0	0	12.6
2014	9	21	9	48	19	33	0	0	0	0	0	0	0	62.64	0	0	12.8
2014	9	21	9	58	19	33	0	0	0	0	0	0	0	62.69	0	0	12.8
2014	9	21	10	8	19	34	0	0	0	0	0	0	0	62.74	0	0	13
2014	9	21	10	18	19	34	0	0	0	0	0	0	0	62.78	0	0	13
2014	9	21	10	28	19	33	0	0	0	0	0	0	0	62.83	0	0	13.4
2014	9	21	10	38	19	33	0	0	0	0	0	0	0	62.87	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	10	48	19	33	0	0	0	0	0	0	0	62.94	0	0	13.2
2014	9	21	10	58	19	33	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	21	11	8	19	33	0	0	0	0	0	0	0	63.05	0	0	13.2
2014	9	21	11	18	19	33	0	0	0	0	0	0	0	63.09	0	0	13.2
2014	9	21	11	28	19	33	0	0	0	0	0	0	0	63.16	0	0	13.2
2014	9	21	11	38	19	33	0	0	0	0	0	0	0	63.19	0	0	13.2
2014	9	21	11	48	19	34	0	0	0	0	0	0	0	63.25	0	0	13.2
2014	9	21	11	58	19	33	0	0	0	0	0	0	0	63.3	0	0	13.2
2014	9	21	12	8	19	34	0	0	0	0	0	0	0	63.39	0	0	13.2
2014	9	21	12	18	19	33	0	0	0	0	0	0	0	63.28	0	0	12.8
2014	9	21	12	28	19	33	0	0	0	0	0	0	0	63.18	0	0	12.4
2014	9	21	12	38	19	33	0	0	0	0	0	0	0	63.23	0	0	13.4
2014	9	21	12	48	19	34	0	0	0	0	0	0	0	63.43	0	0	13.2
2014	9	21	12	58	19	33	0	0	0	0	0	0	0	63.54	0	0	13.2
2014	9	21	13	8	19	33	0	0	0	0	0	0	0	63.43	0	0	13.2
2014	9	21	13	18	19	33	0	0	0	0	0	0	0	63.45	0	0	12.6
2014	9	21	13	28	19	33	0	0	0	0	0	0	0	63.34	0	0	12.6
2014	9	21	13	38	19	34	0	0	0	0	0	0	0	63.52	0	0	13
2014	9	21	13	48	19	34	0	0	0	0	0	0	0	63.63	0	0	13.4
2014	9	21	13	58	19	33	0	0	0	0	0	0	0	63.73	0	0	13.2
2014	9	21	14	8	19	34	0	0	0	0	0	0	0	63.75	0	0	13.2
2014	9	21	14	18	19	33	0	0	0	0	0	0	0	63.82	0	0	13.2
2014	9	21	14	28	19	33	0	0	0	0	0	0	0	63.73	0	0	13.2
2014	9	21	14	38	19	33	0	0	0	0	0	0	0	63.84	0	0	13.2
2014	9	21	14	48	19	32	0	0	0	0	0	0	0	63.88	0	0	13.2
2014	9	21	14	58	19	34	0	0	0	0	0	0	0	63.81	0	0	13
2014	9	21	15	8	19	33	0	0	0	0	0	0	0	63.79	0	0	12.8
2014	9	21	15	18	19	33	0	0	0	0	0	0	0	63.84	0	0	13
2014	9	21	15	28	19	32	0	0	0	0	0	0	0	63.88	0	0	13.2
2014	9	21	15	38	19	33	0	0	0	0	0	0	0	63.93	0	0	13.2
2014	9	21	15	48	19	33	0	0	0	0	0	0	0	63.91	0	0	12.8
2014	9	21	15	58	19	33	0	0	0	0	0	0	0	63.91	0	0	13.2
2014	9	21	16	8	19	34	0	0	0	0	0	0	0	63.95	0	0	13
2014	9	21	16	18	19	33	0	0	0	0	0	0	0	63.91	0	0	12.4
2014	9	21	16	28	19	34	0	0	0	0	0	0	0	63.9	0	0	12.2
2014	9	21	16	38	19	33	0	0	0	0	0	0	0	63.9	0	0	12
2014	9	21	16	48	19	34	0	0	0	0	0	0	0	63.93	0	0	12.2
2014	9	21	16	58	19	33	0	0	0	0	0	0	0	63.93	0	0	12.2
2014	9	21	17	8	19	34	0	0	0	0	0	0	0	63.93	0	0	12.2
2014	9	21	17	18	19	34	0	0	0	0	0	0	0	63.93	0	0	12
2014	9	21	17	28	19	33	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	21	17	38	19	33	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	21	17	48	19	34	0	0	0	0	0	0	0	63.93	0	0	11.8
2014	9	21	17	58	19	34	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	21	18	8	19	33	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	21	18	18	19	33	0	0	0	0	0	0	0	63.95	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	21	18	28	19	33	0	0	0	0	0	0	0	63.95	0	0	11.6
2014	9	21	18	38	19	34	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	21	18	48	19	33	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	21	18	58	19	33	0	0	0	0	0	0	0	63.93	0	0	11.6
2014	9	21	19	8	19	33	0	0	0	0	0	0	0	63.91	0	0	11.6
2014	9	21	19	18	19	34	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	21	19	28	19	33	0	0	0	0	0	0	0	63.9	0	0	11.6
2014	9	21	19	38	19	33	0	0	0	0	0	0	0	63.88	0	0	11.6
2014	9	21	19	48	19	33	0	0	0	0	0	0	0	63.86	0	0	11.6
2014	9	21	19	58	19	33	0	0	0	0	0	0	0	63.84	0	0	11.6
2014	9	21	20	8	19	33	0	0	0	0	0	0	0	63.82	0	0	11.6
2014	9	21	20	18	19	33	0	0	0	0	0	0	0	63.81	0	0	11.6
2014	9	21	20	28	19	33	0	0	0	0	0	0	0	63.79	0	0	11.6
2014	9	21	20	38	19	33	0	0	0	0	0	0	0	63.75	0	0	11.6
2014	9	21	20	48	19	33	0	0	0	0	0	0	0	63.73	0	0	11.6
2014	9	21	20	58	19	34	0	0	0	0	0	0	0	63.72	0	0	11.6
2014	9	21	21	8	19	33	0	0	0	0	0	0	0	63.68	0	0	11.6
2014	9	21	21	18	19	34	0	0	0	0	0	0	0	63.66	0	0	11.6
2014	9	21	21	28	19	33	0	0	0	0	0	0	0	63.63	0	0	11.6
2014	9	21	21	38	19	34	0	0	0	0	0	0	0	63.59	0	0	11.6
2014	9	21	21	48	19	34	0	0	0	0	0	0	0	63.55	0	0	11.6
2014	9	21	21	58	19	34	0	0	0	0	0	0	0	63.54	0	0	11.6
2014	9	21	22	8	19	34	0	0	0	0	0	0	0	63.5	0	0	11.6
2014	9	21	22	18	19	34	0	0	0	0	0	0	0	63.46	0	0	11.6
2014	9	21	22	28	19	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	21	22	38	19	33	0	0	0	0	0	0	0	63.43	0	0	11.6
2014	9	21	22	48	19	34	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	21	22	58	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	21	23	8	19	34	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	21	23	18	19	33	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	21	23	28	19	33	0	0	0	0	0	0	0	63.25	0	0	11.6
2014	9	21	23	38	19	33	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	21	23	48	19	34	0	0	0	0	0	0	0	63.19	0	0	11.6
2014	9	21	23	58	19	33	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	22	0	8	19	33	0	0	0	0	0	0	0	63.1	0	0	11.6
2014	9	22	0	18	19	33	0	0	0	0	0	0	0	63.09	0	0	11.6
2014	9	22	0	28	19	34	0	0	0	0	0	0	0	63.05	0	0	11.6
2014	9	22	0	38	19	33	0	0	0	0	0	0	0	63.01	0	0	11.6
2014	9	22	0	48	19	33	0	0	0	0	0	0	0	63	0	0	11.4
2014	9	22	0	58	19	33	0	0	0	0	0	0	0	62.96	0	0	11.4
2014	9	22	1	8	19	33	0	0	0	0	0	0	0	62.92	0	0	11.4
2014	9	22	1	18	19	33	0	0	0	0	0	0	0	62.91	0	0	11.4
2014	9	22	1	28	19	33	0	0	0	0	0	0	0	62.87	0	0	11.4
2014	9	22	1	38	19	34	0	0	0	0	0	0	0	62.82	0	0	11.4
2014	9	22	1	48	19	33	0	0	0	0	0	0	0	62.8	0	0	11.4
2014	9	22	1	58	19	33	0	0	0	0	0	0	0	62.76	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	2	8	19	34	0	0	0	0	0	0	0	62.73	0	0	11.4
2014	9	22	2	18	19	33	0	0	0	0	0	0	0	62.67	0	0	11.4
2014	9	22	2	28	19	33	0	0	0	0	0	0	0	62.64	0	0	11.4
2014	9	22	2	38	19	34	0	0	0	0	0	0	0	62.6	0	0	11.4
2014	9	22	2	48	19	33	0	0	0	0	0	0	0	62.56	0	0	11.4
2014	9	22	2	58	19	33	0	0	0	0	0	0	0	62.53	0	0	11.4
2014	9	22	3	8	19	34	0	0	0	0	0	0	0	62.49	0	0	11.4
2014	9	22	3	18	19	34	0	0	0	0	0	0	0	62.46	0	0	11.4
2014	9	22	3	28	19	33	0	0	0	0	0	0	0	62.42	0	0	11.4
2014	9	22	3	38	19	33	0	0	0	0	0	0	0	62.38	0	0	11.4
2014	9	22	3	48	19	33	0	0	0	0	0	0	0	62.35	0	0	11.4
2014	9	22	3	58	19	34	0	0	0	0	0	0	0	62.31	0	0	11.4
2014	9	22	4	8	19	34	0	0	0	0	0	0	0	62.28	0	0	11.4
2014	9	22	4	18	19	33	0	0	0	0	0	0	0	62.24	0	0	11.4
2014	9	22	4	28	19	34	0	0	0	0	0	0	0	62.2	0	0	11.4
2014	9	22	4	38	19	34	0	0	0	0	0	0	0	62.17	0	0	11.4
2014	9	22	4	48	19	33	0	0	0	0	0	0	0	62.13	0	0	11.4
2014	9	22	4	58	19	33	0	0	0	0	0	0	0	62.1	0	0	11.4
2014	9	22	5	8	19	33	0	0	0	0	0	0	0	62.06	0	0	11.4
2014	9	22	5	18	19	33	0	0	0	0	0	0	0	62.02	0	0	11.4
2014	9	22	5	28	19	33	0	0	0	0	0	0	0	61.99	0	0	11.4
2014	9	22	5	38	19	34	0	0	0	0	0	0	0	61.95	0	0	11.4
2014	9	22	5	48	19	33	0	0	0	0	0	0	0	61.92	0	0	11.4
2014	9	22	5	58	19	34	0	0	0	0	0	0	0	61.88	0	0	11.4
2014	9	22	6	8	19	34	0	0	0	0	0	0	0	61.84	0	0	11.4
2014	9	22	6	18	19	33	0	0	0	0	0	0	0	61.81	0	0	11.4
2014	9	22	6	28	19	33	0	0	0	0	0	0	0	61.77	0	0	11.4
2014	9	22	6	38	19	33	0	0	0	0	0	0	0	61.74	0	0	11.4
2014	9	22	6	48	19	33	0	0	0	0	0	0	0	61.7	0	0	11.4
2014	9	22	6	58	19	34	0	0	0	0	0	0	0	61.68	0	0	11.4
2014	9	22	7	8	19	34	0	0	0	0	0	0	0	61.65	0	0	11.4
2014	9	22	7	18	19	34	0	0	0	0	0	0	0	61.61	0	0	11.4
2014	9	22	7	28	19	34	0	0	0	0	0	0	0	61.59	0	0	11.4
2014	9	22	7	38	19	33	0	0	0	0	0	0	0	61.57	0	0	11.8
2014	9	22	7	48	19	34	0	0	0	0	0	0	0	61.54	0	0	12
2014	9	22	7	58	19	34	0	0	0	0	0	0	0	61.52	0	0	12.2
2014	9	22	8	8	19	34	0	0	0	0	0	0	0	61.52	0	0	12.4
2014	9	22	8	18	19	34	0	0	0	0	0	0	0	61.5	0	0	12.4
2014	9	22	8	28	19	33	0	0	0	0	0	0	0	61.52	0	0	12.4
2014	9	22	8	38	19	33	0	0	0	0	0	0	0	61.52	0	0	12.4
2014	9	22	8	48	19	33	0	0	0	0	0	0	0	61.56	0	0	12.4
2014	9	22	8	58	19	34	0	0	0	0	0	0	0	61.59	0	0	12.6
2014	9	22	9	8	19	33	0	0	0	0	0	0	0	61.63	0	0	12.6
2014	9	22	9	18	19	33	0	0	0	0	0	0	0	61.66	0	0	12.6
2014	9	22	9	28	19	33	0	0	0	0	0	0	0	61.68	0	0	12.6
2014	9	22	9	38	19	33	0	0	0	0	0	0	0	61.74	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	9	48	19	34	0	0	0	0	0	0	0	61.75	0	0	12.8
2014	9	22	9	58	19	34	0	0	0	0	0	0	0	61.81	0	0	12.8
2014	9	22	10	8	19	33	0	0	0	0	0	0	0	61.86	0	0	13
2014	9	22	10	18	19	34	0	0	0	0	0	0	0	61.9	0	0	13
2014	9	22	10	28	19	33	0	0	0	0	0	0	0	61.97	0	0	13.2
2014	9	22	10	38	19	34	0	0	0	0	0	0	0	62.01	0	0	13.4
2014	9	22	10	48	19	34	0	0	0	0	0	0	0	62.1	0	0	13.4
2014	9	22	10	58	19	33	0	0	0	0	0	0	0	62.15	0	0	13.4
2014	9	22	11	8	19	34	0	0	0	0	0	0	0	62.2	0	0	13.4
2014	9	22	11	18	19	33	0	0	0	0	0	0	0	62.26	0	0	13.6
2014	9	22	11	28	19	33	0	0	0	0	0	0	0	62.31	0	0	13.6
2014	9	22	11	38	19	33	0	0	0	0	0	0	0	62.38	0	0	13.4
2014	9	22	11	48	19	34	0	0	0	0	0	0	0	62.44	0	0	13.2
2014	9	22	11	58	19	34	0	0	0	0	0	0	0	62.51	0	0	12.8
2014	9	22	12	8	19	33	0	0	0	0	0	0	0	62.56	0	0	13
2014	9	22	12	18	19	33	0	0	0	0	0	0	0	62.62	0	0	13.4
2014	9	22	12	28	19	34	0	0	0	0	0	0	0	62.67	0	0	13.4
2014	9	22	12	38	19	33	0	0	0	0	0	0	0	62.74	0	0	13.4
2014	9	22	12	48	19	33	0	0	0	0	0	0	0	62.78	0	0	13.4
2014	9	22	12	58	19	34	0	0	0	0	0	0	0	62.83	0	0	13.4
2014	9	22	13	8	19	33	0	0	0	0	0	0	0	62.87	0	0	13.4
2014	9	22	13	18	19	34	0	0	0	0	0	0	0	62.94	0	0	13
2014	9	22	13	28	19	33	0	0	0	0	0	0	0	63	0	0	13.2
2014	9	22	13	38	19	33	0	0	0	0	0	0	0	63.01	0	0	13.4
2014	9	22	13	48	19	33	0	0	0	0	0	0	0	63.07	0	0	13.4
2014	9	22	13	58	19	34	0	0	0	0	0	0	0	63.1	0	0	13.4
2014	9	22	14	8	19	34	0	0	0	0	0	0	0	63.16	0	0	13.4
2014	9	22	14	18	19	33	0	0	0	0	0	0	0	63.19	0	0	13.4
2014	9	22	14	28	19	34	0	0	0	0	0	0	0	63.23	0	0	13.4
2014	9	22	14	38	19	33	0	0	0	0	0	0	0	63.25	0	0	13.4
2014	9	22	14	48	19	33	0	0	0	0	0	0	0	63.28	0	0	13.4
2014	9	22	14	58	19	33	0	0	0	0	0	0	0	63.3	0	0	13.4
2014	9	22	15	8	19	33	0	0	0	0	0	0	0	63.34	0	0	13.4
2014	9	22	15	18	19	33	0	0	0	0	0	0	0	63.34	0	0	13.4
2014	9	22	15	28	19	33	0	0	0	0	0	0	0	63.37	0	0	13.4
2014	9	22	15	38	19	34	0	0	0	0	0	0	0	63.41	0	0	13.4
2014	9	22	15	48	19	33	0	0	0	0	0	0	0	63.41	0	0	13.4
2014	9	22	15	58	19	33	0	0	0	0	0	0	0	63.41	0	0	13.4
2014	9	22	16	8	19	33	0	0	0	0	0	0	0	63.43	0	0	13.4
2014	9	22	16	18	19	34	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	22	16	28	19	34	0	0	0	0	0	0	0	63.45	0	0	13.4
2014	9	22	16	38	19	34	0	0	0	0	0	0	0	63.45	0	0	13.2
2014	9	22	16	48	19	33	0	0	0	0	0	0	0	63.45	0	0	13
2014	9	22	16	58	19	33	0	0	0	0	0	0	0	63.45	0	0	12.8
2014	9	22	17	8	19	33	0	0	0	0	0	0	0	63.46	0	0	12.6
2014	9	22	17	18	19	34	0	0	0	0	0	0	0	63.45	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	22	17	28	19	34	0	0	0	0	0	0	0	63.45	0	0	12.2
2014	9	22	17	38	19	33	0	0	0	0	0	0	0	63.45	0	0	12
2014	9	22	17	48	19	33	0	0	0	0	0	0	0	63.45	0	0	12
2014	9	22	17	58	19	33	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	22	18	8	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	18	18	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	18	28	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	18	38	19	34	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	18	48	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	18	58	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	19	8	19	33	0	0	0	0	0	0	0	63.45	0	0	11.6
2014	9	22	19	18	19	33	0	0	0	0	0	0	0	63.46	0	0	11.8
2014	9	22	19	28	19	33	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	22	19	38	19	33	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	22	19	48	19	33	0	0	0	0	0	0	0	63.45	0	0	11.8
2014	9	22	19	58	19	33	0	0	0	0	0	0	0	63.43	0	0	11.8
2014	9	22	20	8	19	32	0	0	0	0	0	0	0	63.43	0	0	11.8
2014	9	22	20	18	19	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	22	20	28	19	33	0	0	0	0	0	0	0	63.41	0	0	11.6
2014	9	22	20	38	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	22	20	48	19	33	0	0	0	0	0	0	0	63.39	0	0	11.6
2014	9	22	20	58	19	34	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	22	21	8	19	33	0	0	0	0	0	0	0	63.36	0	0	11.6
2014	9	22	21	18	19	34	0	0	0	0	0	0	0	63.32	0	0	11.6
2014	9	22	21	28	19	34	0	0	0	0	0	0	0	63.3	0	0	11.6
2014	9	22	21	38	19	34	0	0	0	0	0	0	0	63.28	0	0	11.6
2014	9	22	21	48	19	33	0	0	0	0	0	0	0	63.27	0	0	11.6
2014	9	22	21	58	19	33	0	0	0	0	0	0	0	63.23	0	0	11.6
2014	9	22	22	8	19	33	0	0	0	0	0	0	0	63.21	0	0	11.6
2014	9	22	22	18	19	33	0	0	0	0	0	0	0	63.18	0	0	11.6
2014	9	22	22	28	19	33	0	0	0	0	0	0	0	63.16	0	0	11.6
2014	9	22	22	38	19	33	0	0	0	0	0	0	0	63.14	0	0	11.6
2014	9	22	22	48	19	33	0	0	0	0	0	0	0	63.1	0	0	11.6
2014	9	22	22	58	19	33	0	0	0	0	0	0	0	63.07	0	0	11.6
2014	9	22	23	8	19	33	0	0	0	0	0	0	0	63.03	0	0	11.6
2014	9	22	23	18	19	33	0	0	0	0	0	0	0	63	0	0	11.6
2014	9	22	23	28	19	33	0	0	0	0	0	0	0	62.96	0	0	11.6
2014	9	22	23	38	19	34	0	0	0	0	0	0	0	62.92	0	0	11.6
2014	9	22	23	48	19	34	0	0	0	0	0	0	0	62.89	0	0	11.6
2014	9	22	23	58	19	33	0	0	0	0	0	0	0	62.85	0	0	11.6
2014	9	23	0	8	19	34	0	0	0	0	0	0	0	62.82	0	0	11.6
2014	9	23	0	18	19	33	0	0	0	0	0	0	0	62.78	0	0	11.6
2014	9	23	0	28	19	33	0	0	0	0	0	0	0	62.74	0	0	11.6
2014	9	23	0	38	19	33	0	0	0	0	0	0	0	62.71	0	0	11.6
2014	9	23	0	48	19	33	0	0	0	0	0	0	0	62.67	0	0	11.6
2014	9	23	0	58	19	33	0	0	0	0	0	0	0	62.64	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	1	8	19	34	0	0	0	0	0	0	0	62.58	0	0	11.6
2014	9	23	1	18	19	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	23	1	28	19	34	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	23	1	38	19	34	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	23	1	48	19	33	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	23	1	58	19	33	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	23	2	8	19	33	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	23	2	18	19	33	0	0	0	0	0	0	0	62.29	0	0	11.6
2014	9	23	2	28	19	34	0	0	0	0	0	0	0	62.22	0	0	11.6
2014	9	23	2	38	19	34	0	0	0	0	0	0	0	62.17	0	0	11.6
2014	9	23	2	48	19	34	0	0	0	0	0	0	0	62.13	0	0	11.6
2014	9	23	2	58	19	34	0	0	0	0	0	0	0	62.08	0	0	11.6
2014	9	23	3	8	19	33	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	23	3	18	19	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	23	3	28	19	34	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	23	3	38	19	33	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	23	3	48	19	33	0	0	0	0	0	0	0	61.84	0	0	11.6
2014	9	23	3	58	19	34	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	23	4	8	19	34	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	23	4	18	19	34	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	23	4	28	19	33	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	23	4	38	19	34	0	0	0	0	0	0	0	61.63	0	0	11.6
2014	9	23	4	48	19	33	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	23	4	58	19	34	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	23	5	8	19	33	0	0	0	0	0	0	0	61.47	0	0	11.6
2014	9	23	5	18	19	34	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	23	5	28	19	33	0	0	0	0	0	0	0	61.38	0	0	11.6
2014	9	23	5	38	19	33	0	0	0	0	0	0	0	61.32	0	0	11.6
2014	9	23	5	48	19	33	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	23	5	58	19	34	0	0	0	0	0	0	0	61.23	0	0	11.6
2014	9	23	6	8	19	33	0	0	0	0	0	0	0	61.18	0	0	11.6
2014	9	23	6	18	19	34	0	0	0	0	0	0	0	61.14	0	0	11.6
2014	9	23	6	28	19	33	0	0	0	0	0	0	0	61.11	0	0	11.6
2014	9	23	6	38	19	34	0	0	0	0	0	0	0	61.05	0	0	11.6
2014	9	23	6	48	19	33	0	0	0	0	0	0	0	61.03	0	0	11.6
2014	9	23	6	58	19	34	0	0	0	0	0	0	0	60.98	0	0	11.6
2014	9	23	7	8	19	33	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	23	7	18	19	34	0	0	0	0	0	0	0	60.89	0	0	11.6
2014	9	23	7	28	19	34	0	0	0	0	0	0	0	60.84	0	0	11.6
2014	9	23	7	38	19	33	0	0	0	0	0	0	0	60.8	0	0	12
2014	9	23	7	48	19	33	0	0	0	0	0	0	0	60.76	0	0	12.2
2014	9	23	7	58	19	34	0	0	0	0	0	0	0	60.73	0	0	12.4
2014	9	23	8	8	19	34	0	0	0	0	0	0	0	60.71	0	0	12.6
2014	9	23	8	18	19	34	0	0	0	0	0	0	0	60.69	0	0	12.8
2014	9	23	8	28	19	33	0	0	0	0	0	0	0	60.67	0	0	13
2014	9	23	8	38	19	34	0	0	0	0	0	0	0	60.69	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	8	48	19	33	0	0	0	0	0	0	0	60.71	0	0	13
2014	9	23	8	58	19	34	0	0	0	0	0	0	0	60.75	0	0	13
2014	9	23	9	8	19	34	0	0	0	0	0	0	0	60.76	0	0	13.2
2014	9	23	9	18	19	34	0	0	0	0	0	0	0	60.78	0	0	13.4
2014	9	23	9	28	19	33	0	0	0	0	0	0	0	60.82	0	0	13.6
2014	9	23	9	38	19	34	0	0	0	0	0	0	0	60.85	0	0	13.4
2014	9	23	9	48	19	33	0	0	0	0	0	0	0	60.87	0	0	13.4
2014	9	23	9	58	19	34	0	0	0	0	0	0	0	60.93	0	0	13.2
2014	9	23	10	8	19	34	0	0	0	0	0	0	0	60.96	0	0	13.2
2014	9	23	10	18	19	34	0	0	0	0	0	0	0	61	0	0	13.2
2014	9	23	10	28	19	34	0	0	0	0	0	0	0	61.05	0	0	13.4
2014	9	23	10	38	19	34	0	0	0	0	0	0	0	61.11	0	0	13
2014	9	23	10	48	19	34	0	0	0	0	0	0	0	61.16	0	0	12.6
2014	9	23	10	58	19	33	0	0	0	0	0	0	0	61.21	0	0	12.6
2014	9	23	11	8	19	34	0	0	0	0	0	0	0	61.27	0	0	12.6
2014	9	23	11	18	19	34	0	0	0	0	0	0	0	61.34	0	0	13.6
2014	9	23	11	28	19	33	0	0	0	0	0	0	0	61.39	0	0	13.6
2014	9	23	11	38	19	34	0	0	0	0	0	0	0	61.47	0	0	13.6
2014	9	23	11	48	19	33	0	0	0	0	0	0	0	61.52	0	0	13.6
2014	9	23	11	58	19	33	0	0	0	0	0	0	0	61.57	0	0	13.6
2014	9	23	12	8	19	33	0	0	0	0	0	0	0	61.63	0	0	13.6
2014	9	23	12	18	19	34	0	0	0	0	0	0	0	61.7	0	0	13.6
2014	9	23	12	28	19	34	0	0	0	0	0	0	0	61.74	0	0	13.6
2014	9	23	12	38	19	33	0	0	0	0	0	0	0	61.81	0	0	13.6
2014	9	23	12	48	19	33	0	0	0	0	0	0	0	61.86	0	0	13.6
2014	9	23	12	58	19	33	0	0	0	0	0	0	0	61.92	0	0	13.6
2014	9	23	13	8	19	34	0	0	0	0	0	0	0	61.97	0	0	13.6
2014	9	23	13	18	19	34	0	0	0	0	0	0	0	62.02	0	0	13.6
2014	9	23	13	28	19	33	0	0	0	0	0	0	0	62.08	0	0	13.6
2014	9	23	13	38	19	34	0	0	0	0	0	0	0	62.13	0	0	13.6
2014	9	23	13	48	19	33	0	0	0	0	0	0	0	62.17	0	0	13.4
2014	9	23	13	58	19	33	0	0	0	0	0	0	0	62.22	0	0	13.4
2014	9	23	14	8	19	33	0	0	0	0	0	0	0	62.26	0	0	13.4
2014	9	23	14	18	19	33	0	0	0	0	0	0	0	62.29	0	0	13.4
2014	9	23	14	28	19	33	0	0	0	0	0	0	0	62.35	0	0	13.4
2014	9	23	14	38	19	33	0	0	0	0	0	0	0	62.38	0	0	13.4
2014	9	23	14	48	19	34	0	0	0	0	0	0	0	62.42	0	0	13.4
2014	9	23	14	58	19	33	0	0	0	0	0	0	0	62.46	0	0	13.4
2014	9	23	15	8	19	33	0	0	0	0	0	0	0	62.49	0	0	13.4
2014	9	23	15	18	19	33	0	0	0	0	0	0	0	62.51	0	0	13.2
2014	9	23	15	28	19	33	0	0	0	0	0	0	0	62.53	0	0	13
2014	9	23	15	38	19	34	0	0	0	0	0	0	0	62.55	0	0	13.2
2014	9	23	15	48	19	33	0	0	0	0	0	0	0	62.56	0	0	13.2
2014	9	23	15	58	19	34	0	0	0	0	0	0	0	62.58	0	0	13.2
2014	9	23	16	8	19	33	0	0	0	0	0	0	0	62.6	0	0	13.2
2014	9	23	16	18	19	33	0	0	0	0	0	0	0	62.62	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	23	16	28	19	34	0	0	0	0	0	0	0	62.62	0	0	13
2014	9	23	16	38	19	33	0	0	0	0	0	0	0	62.64	0	0	12.8
2014	9	23	16	48	19	34	0	0	0	0	0	0	0	62.64	0	0	12.8
2014	9	23	16	58	19	33	0	0	0	0	0	0	0	62.65	0	0	12.6
2014	9	23	17	8	19	34	0	0	0	0	0	0	0	62.65	0	0	12.4
2014	9	23	17	18	19	34	0	0	0	0	0	0	0	62.65	0	0	12.4
2014	9	23	17	28	19	33	0	0	0	0	0	0	0	62.64	0	0	12.2
2014	9	23	17	38	19	34	0	0	0	0	0	0	0	62.64	0	0	12
2014	9	23	17	48	19	34	0	0	0	0	0	0	0	62.65	0	0	12
2014	9	23	17	58	19	34	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	18	8	19	34	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	18	18	19	33	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	18	28	19	33	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	18	38	19	33	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	18	48	19	34	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	18	58	19	34	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	19	8	19	33	0	0	0	0	0	0	0	62.67	0	0	11.8
2014	9	23	19	18	19	33	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	19	28	19	34	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	19	38	19	34	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	19	48	19	33	0	0	0	0	0	0	0	62.65	0	0	11.8
2014	9	23	19	58	19	33	0	0	0	0	0	0	0	62.64	0	0	11.8
2014	9	23	20	8	19	34	0	0	0	0	0	0	0	62.64	0	0	11.8
2014	9	23	20	18	19	33	0	0	0	0	0	0	0	62.62	0	0	11.6
2014	9	23	20	28	19	34	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	23	20	38	19	33	0	0	0	0	0	0	0	62.6	0	0	11.6
2014	9	23	20	48	19	33	0	0	0	0	0	0	0	62.58	0	0	11.6
2014	9	23	20	58	19	33	0	0	0	0	0	0	0	62.55	0	0	11.6
2014	9	23	21	8	19	33	0	0	0	0	0	0	0	62.53	0	0	11.6
2014	9	23	21	18	19	33	0	0	0	0	0	0	0	62.49	0	0	11.6
2014	9	23	21	28	19	34	0	0	0	0	0	0	0	62.46	0	0	11.6
2014	9	23	21	38	19	33	0	0	0	0	0	0	0	62.44	0	0	11.6
2014	9	23	21	48	19	33	0	0	0	0	0	0	0	62.4	0	0	11.6
2014	9	23	21	58	19	34	0	0	0	0	0	0	0	62.37	0	0	11.6
2014	9	23	22	8	19	33	0	0	0	0	0	0	0	62.33	0	0	11.6
2014	9	23	22	18	19	33	0	0	0	0	0	0	0	62.28	0	0	11.6
2014	9	23	22	28	19	34	0	0	0	0	0	0	0	62.24	0	0	11.6
2014	9	23	22	38	19	34	0	0	0	0	0	0	0	62.2	0	0	11.6
2014	9	23	22	48	19	34	0	0	0	0	0	0	0	62.17	0	0	11.6
2014	9	23	22	58	19	33	0	0	0	0	0	0	0	62.11	0	0	11.6
2014	9	23	23	8	19	33	0	0	0	0	0	0	0	62.06	0	0	11.6
2014	9	23	23	18	19	33	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	23	23	28	19	34	0	0	0	0	0	0	0	61.99	0	0	11.6
2014	9	23	23	38	19	34	0	0	0	0	0	0	0	61.95	0	0	11.6
2014	9	23	23	48	19	34	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	23	23	58	19	34	0	0	0	0	0	0	0	61.86	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	0	8	19	34	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	24	0	18	19	34	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	24	0	28	19	33	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	24	0	38	19	33	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	24	0	48	19	33	0	0	0	0	0	0	0	61.63	0	0	11.6
2014	9	24	0	58	19	33	0	0	0	0	0	0	0	61.59	0	0	11.6
2014	9	24	1	8	19	33	0	0	0	0	0	0	0	61.56	0	0	11.6
2014	9	24	1	18	19	34	0	0	0	0	0	0	0	61.5	0	0	11.6
2014	9	24	1	28	19	34	0	0	0	0	0	0	0	61.45	0	0	11.6
2014	9	24	1	38	19	33	0	0	0	0	0	0	0	61.41	0	0	11.6
2014	9	24	1	48	19	34	0	0	0	0	0	0	0	61.36	0	0	11.6
2014	9	24	1	58	19	34	0	0	0	0	0	0	0	61.3	0	0	11.6
2014	9	24	2	8	19	33	0	0	0	0	0	0	0	61.27	0	0	11.6
2014	9	24	2	18	19	34	0	0	0	0	0	0	0	61.2	0	0	11.6
2014	9	24	2	28	19	34	0	0	0	0	0	0	0	61.16	0	0	11.6
2014	9	24	2	38	19	34	0	0	0	0	0	0	0	61.11	0	0	11.6
2014	9	24	2	48	19	34	0	0	0	0	0	0	0	61.03	0	0	11.6
2014	9	24	2	58	19	33	0	0	0	0	0	0	0	60.98	0	0	11.6
2014	9	24	3	8	19	33	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	24	3	18	19	33	0	0	0	0	0	0	0	60.87	0	0	11.6
2014	9	24	3	28	19	34	0	0	0	0	0	0	0	60.82	0	0	11.6
2014	9	24	3	38	19	34	0	0	0	0	0	0	0	60.76	0	0	11.6
2014	9	24	3	48	19	34	0	0	0	0	0	0	0	60.71	0	0	11.6
2014	9	24	3	58	19	34	0	0	0	0	0	0	0	60.67	0	0	11.6
2014	9	24	4	8	19	34	0	0	0	0	0	0	0	60.6	0	0	11.6
2014	9	24	4	18	19	34	0	0	0	0	0	0	0	60.57	0	0	11.6
2014	9	24	4	28	19	34	0	0	0	0	0	0	0	60.49	0	0	11.6
2014	9	24	4	38	19	33	0	0	0	0	0	0	0	60.44	0	0	11.6
2014	9	24	4	48	19	34	0	0	0	0	0	0	0	60.39	0	0	11.6
2014	9	24	4	58	19	34	0	0	0	0	0	0	0	60.33	0	0	11.6
2014	9	24	5	8	19	34	0	0	0	0	0	0	0	60.3	0	0	11.6
2014	9	24	5	18	19	34	0	0	0	0	0	0	0	60.24	0	0	11.4
2014	9	24	5	28	19	34	0	0	0	0	0	0	0	60.19	0	0	11.4
2014	9	24	5	38	19	33	0	0	0	0	0	0	0	60.13	0	0	11.4
2014	9	24	5	48	19	34	0	0	0	0	0	0	0	60.08	0	0	11.4
2014	9	24	5	58	19	34	0	0	0	0	0	0	0	60.04	0	0	11.4
2014	9	24	6	8	19	34	0	0	0	0	0	0	0	59.97	0	0	11.4
2014	9	24	6	18	19	34	0	0	0	0	0	0	0	59.94	0	0	11.4
2014	9	24	6	28	19	34	0	0	0	0	0	0	0	59.88	0	0	11.4
2014	9	24	6	38	19	34	0	0	0	0	0	0	0	59.85	0	0	11.4
2014	9	24	6	48	19	34	0	0	0	0	0	0	0	59.81	0	0	11.4
2014	9	24	6	58	19	34	0	0	0	0	0	0	0	59.76	0	0	11.4
2014	9	24	7	8	19	34	0	0	0	0	0	0	0	59.72	0	0	11.4
2014	9	24	7	18	19	34	0	0	0	0	0	0	0	59.68	0	0	11.6
2014	9	24	7	28	19	33	0	0	0	0	0	0	0	59.65	0	0	11.6
2014	9	24	7	38	19	34	0	0	0	0	0	0	0	59.61	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	7	48	19	34	0	0	0	0	0	0	0	59.56	0	0	12.2
2014	9	24	7	58	19	34	0	0	0	0	0	0	0	59.54	0	0	12.4
2014	9	24	8	8	19	34	0	0	0	0	0	0	0	59.52	0	0	12.6
2014	9	24	8	18	19	34	0	0	0	0	0	0	0	59.5	0	0	12.6
2014	9	24	8	28	19	33	0	0	0	0	0	0	0	59.49	0	0	12.6
2014	9	24	8	38	19	34	0	0	0	0	0	0	0	59.5	0	0	13.2
2014	9	24	8	48	19	34	0	0	0	0	0	0	0	59.59	0	0	13.2
2014	9	24	8	58	19	34	0	0	0	0	0	0	0	59.63	0	0	13.4
2014	9	24	9	8	19	34	0	0	0	0	0	0	0	59.65	0	0	13.8
2014	9	24	9	18	19	34	0	0	0	0	0	0	0	59.7	0	0	13.8
2014	9	24	9	28	19	34	0	0	0	0	0	0	0	59.72	0	0	13.8
2014	9	24	9	38	19	34	0	0	0	0	0	0	0	59.76	0	0	13.6
2014	9	24	9	48	19	33	0	0	0	0	0	0	0	59.81	0	0	13.4
2014	9	24	9	58	19	34	0	0	0	0	0	0	0	59.85	0	0	13.4
2014	9	24	10	8	19	34	0	0	0	0	0	0	0	59.92	0	0	13.4
2014	9	24	10	18	19	34	0	0	0	0	0	0	0	59.95	0	0	13.4
2014	9	24	10	28	19	34	0	0	0	0	0	0	0	60.01	0	0	13.4
2014	9	24	10	38	19	34	0	0	0	0	0	0	0	60.06	0	0	13.4
2014	9	24	10	48	19	33	0	0	0	0	0	0	0	60.1	0	0	13.2
2014	9	24	10	58	19	34	0	0	0	0	0	0	0	60.19	0	0	13.4
2014	9	24	11	8	19	35	0	0	0	0	0	0	0	60.24	0	0	13.4
2014	9	24	11	18	19	34	0	0	0	0	0	0	0	60.3	0	0	13.2
2014	9	24	11	28	19	34	0	0	0	0	0	0	0	60.35	0	0	13.2
2014	9	24	11	38	19	33	0	0	0	0	0	0	0	60.42	0	0	13.2
2014	9	24	11	48	19	34	0	0	0	0	0	0	0	60.48	0	0	13.2
2014	9	24	11	58	19	34	0	0	0	0	0	0	0	60.53	0	0	13.2
2014	9	24	12	8	19	34	0	0	0	0	0	0	0	60.58	0	0	13.2
2014	9	24	12	18	19	34	0	0	0	0	0	0	0	60.64	0	0	13
2014	9	24	12	28	19	34	0	0	0	0	0	0	0	60.69	0	0	13
2014	9	24	12	38	19	34	0	0	0	0	0	0	0	60.75	0	0	13
2014	9	24	12	48	19	34	0	0	0	0	0	0	0	60.78	0	0	13
2014	9	24	12	58	19	35	0	0	0	0	0	0	0	60.84	0	0	13
2014	9	24	13	8	19	33	0	0	0	0	0	0	0	60.89	0	0	13
2014	9	24	13	18	19	34	0	0	0	0	0	0	0	61.2	0	0	13
2014	9	24	13	28	19	34	0	0	0	0	0	0	0	61.27	0	0	13
2014	9	24	13	38	19	34	0	0	0	0	0	0	0	61.32	0	0	13.2
2014	9	24	13	48	19	33	0	0	0	0	0	0	0	61.34	0	0	13.2
2014	9	24	13	58	19	34	0	0	0	0	0	0	0	61.38	0	0	13.2
2014	9	24	14	8	19	34	0	0	0	0	0	0	0	61.41	0	0	13
2014	9	24	14	18	19	33	0	0	0	0	0	0	0	61.45	0	0	12.8
2014	9	24	14	28	19	34	0	0	0	0	0	0	0	61.45	0	0	13
2014	9	24	14	38	19	33	0	0	0	0	0	0	0	61.47	0	0	13
2014	9	24	14	48	19	34	0	0	0	0	0	0	0	61.48	0	0	12.8
2014	9	24	14	58	19	34	0	0	0	0	0	0	0	61.5	0	0	12.8
2014	9	24	15	8	19	34	0	0	0	0	0	0	0	61.5	0	0	12.8
2014	9	24	15	18	19	34	0	0	0	0	0	0	0	61.5	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	15	28	19	33	0	0	0	0	0	0	0	61.5	0	0	13
2014	9	24	15	38	19	33	0	0	0	0	0	0	0	61.52	0	0	13
2014	9	24	15	48	19	34	0	0	0	0	0	0	0	61.52	0	0	12.8
2014	9	24	15	58	19	33	0	0	0	0	0	0	0	61.54	0	0	12.8
2014	9	24	16	8	19	33	0	0	0	0	0	0	0	61.54	0	0	12.6
2014	9	24	16	18	19	34	0	0	0	0	0	0	0	61.54	0	0	12.6
2014	9	24	16	28	19	33	0	0	0	0	0	0	0	61.54	0	0	12.6
2014	9	24	16	38	19	33	0	0	0	0	0	0	0	61.54	0	0	12.6
2014	9	24	16	48	19	33	0	0	0	0	0	0	0	61.56	0	0	12.4
2014	9	24	16	58	19	34	0	0	0	0	0	0	0	61.56	0	0	12.2
2014	9	24	17	8	19	34	0	0	0	0	0	0	0	61.56	0	0	12
2014	9	24	17	18	19	34	0	0	0	0	0	0	0	61.54	0	0	11.8
2014	9	24	17	28	19	34	0	0	0	0	0	0	0	61.54	0	0	11.8
2014	9	24	17	38	19	33	0	0	0	0	0	0	0	61.54	0	0	11.6
2014	9	24	17	48	19	34	0	0	0	0	0	0	0	61.54	0	0	11.4
2014	9	24	17	58	19	34	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	18	8	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	18	18	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	18	28	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	18	38	19	34	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	18	48	19	34	0	0	0	0	0	0	0	61.57	0	0	11.4
2014	9	24	18	58	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	19	8	19	34	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	19	18	19	33	0	0	0	0	0	0	0	61.57	0	0	11.4
2014	9	24	19	28	19	34	0	0	0	0	0	0	0	61.57	0	0	11.4
2014	9	24	19	38	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	19	48	19	34	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	19	58	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	20	8	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	24	20	18	19	34	0	0	0	0	0	0	0	61.54	0	0	11.2
2014	9	24	20	28	19	33	0	0	0	0	0	0	0	61.54	0	0	11.2
2014	9	24	20	38	19	33	0	0	0	0	0	0	0	61.54	0	0	11.2
2014	9	24	20	48	19	34	0	0	0	0	0	0	0	61.52	0	0	11.2
2014	9	24	20	58	19	34	0	0	0	0	0	0	0	61.52	0	0	11.2
2014	9	24	21	8	19	34	0	0	0	0	0	0	0	61.5	0	0	11.2
2014	9	24	21	18	19	33	0	0	0	0	0	0	0	61.48	0	0	11.2
2014	9	24	21	28	19	34	0	0	0	0	0	0	0	61.48	0	0	11.2
2014	9	24	21	38	19	33	0	0	0	0	0	0	0	61.47	0	0	11.2
2014	9	24	21	48	19	34	0	0	0	0	0	0	0	61.45	0	0	11.2
2014	9	24	21	58	19	34	0	0	0	0	0	0	0	61.43	0	0	11.2
2014	9	24	22	8	19	34	0	0	0	0	0	0	0	61.41	0	0	11.2
2014	9	24	22	18	19	34	0	0	0	0	0	0	0	61.39	0	0	11.2
2014	9	24	22	28	19	33	0	0	0	0	0	0	0	61.38	0	0	11.2
2014	9	24	22	38	19	33	0	0	0	0	0	0	0	61.36	0	0	11.2
2014	9	24	22	48	19	34	0	0	0	0	0	0	0	61.34	0	0	11.2
2014	9	24	22	58	19	34	0	0	0	0	0	0	0	61.34	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	24	23	8	19	34	0	0	0	0	0	0	0	61.32	0	0	11.2
2014	9	24	23	18	19	33	0	0	0	0	0	0	0	61.3	0	0	11.2
2014	9	24	23	28	19	34	0	0	0	0	0	0	0	61.29	0	0	11.2
2014	9	24	23	38	19	33	0	0	0	0	0	0	0	61.27	0	0	11.2
2014	9	24	23	48	19	33	0	0	0	0	0	0	0	61.25	0	0	11.2
2014	9	24	23	58	19	34	0	0	0	0	0	0	0	61.21	0	0	11.2
2014	9	25	0	8	19	33	0	0	0	0	0	0	0	61.21	0	0	11.2
2014	9	25	0	18	19	34	0	0	0	0	0	0	0	61.2	0	0	11.2
2014	9	25	0	28	19	33	0	0	0	0	0	0	0	61.18	0	0	11.2
2014	9	25	0	38	19	33	0	0	0	0	0	0	0	61.16	0	0	11.2
2014	9	25	0	48	19	34	0	0	0	0	0	0	0	61.14	0	0	11.2
2014	9	25	0	58	19	34	0	0	0	0	0	0	0	61.12	0	0	11.2
2014	9	25	1	8	19	33	0	0	0	0	0	0	0	61.11	0	0	11.2
2014	9	25	1	18	19	34	0	0	0	0	0	0	0	61.09	0	0	11.2
2014	9	25	1	28	19	34	0	0	0	0	0	0	0	61.09	0	0	11.2
2014	9	25	1	38	19	33	0	0	0	0	0	0	0	61.05	0	0	11.2
2014	9	25	1	48	19	34	0	0	0	0	0	0	0	61.05	0	0	11.2
2014	9	25	1	58	19	34	0	0	0	0	0	0	0	61.03	0	0	11.2
2014	9	25	2	8	19	33	0	0	0	0	0	0	0	61	0	0	11.2
2014	9	25	2	18	19	34	0	0	0	0	0	0	0	60.98	0	0	11.2
2014	9	25	2	28	19	34	0	0	0	0	0	0	0	60.96	0	0	11.2
2014	9	25	2	38	19	33	0	0	0	0	0	0	0	60.96	0	0	11.2
2014	9	25	2	48	19	34	0	0	0	0	0	0	0	60.94	0	0	11.2
2014	9	25	2	58	19	34	0	0	0	0	0	0	0	60.91	0	0	11.2
2014	9	25	3	8	19	34	0	0	0	0	0	0	0	60.91	0	0	11.2
2014	9	25	3	18	19	33	0	0	0	0	0	0	0	60.87	0	0	11.2
2014	9	25	3	28	19	34	0	0	0	0	0	0	0	60.85	0	0	11.2
2014	9	25	3	38	19	34	0	0	0	0	0	0	0	60.84	0	0	11.2
2014	9	25	3	48	19	34	0	0	0	0	0	0	0	60.82	0	0	11.2
2014	9	25	3	58	19	34	0	0	0	0	0	0	0	60.8	0	0	11.2
2014	9	25	4	8	19	33	0	0	0	0	0	0	0	60.8	0	0	11.2
2014	9	25	4	18	19	33	0	0	0	0	0	0	0	60.78	0	0	11.2
2014	9	25	4	28	19	34	0	0	0	0	0	0	0	60.75	0	0	11.2
2014	9	25	4	38	19	34	0	0	0	0	0	0	0	60.75	0	0	11.2
2014	9	25	4	48	19	34	0	0	0	0	0	0	0	60.71	0	0	11.2
2014	9	25	4	58	19	34	0	0	0	0	0	0	0	60.69	0	0	11.2
2014	9	25	5	8	19	34	0	0	0	0	0	0	0	60.67	0	0	11.2
2014	9	25	5	18	19	34	0	0	0	0	0	0	0	60.66	0	0	11.2
2014	9	25	5	28	19	34	0	0	0	0	0	0	0	60.66	0	0	11.2
2014	9	25	5	38	19	34	0	0	0	0	0	0	0	60.64	0	0	11.2
2014	9	25	5	48	19	34	0	0	0	0	0	0	0	60.62	0	0	11.2
2014	9	25	5	58	19	34	0	0	0	0	0	0	0	60.6	0	0	11.2
2014	9	25	6	8	19	33	0	0	0	0	0	0	0	60.6	0	0	11.2
2014	9	25	6	18	19	34	0	0	0	0	0	0	0	60.58	0	0	11.2
2014	9	25	6	28	19	34	0	0	0	0	0	0	0	60.57	0	0	11.2
2014	9	25	6	38	19	33	0	0	0	0	0	0	0	60.57	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	6	48	19	34	0	0	0	0	0	0	0	60.55	0	0	11.2
2014	9	25	6	58	19	34	0	0	0	0	0	0	0	60.55	0	0	11.2
2014	9	25	7	8	19	34	0	0	0	0	0	0	0	60.53	0	0	11.2
2014	9	25	7	18	19	34	0	0	0	0	0	0	0	60.53	0	0	11.2
2014	9	25	7	28	19	34	0	0	0	0	0	0	0	60.53	0	0	11.2
2014	9	25	7	38	19	34	0	0	0	0	0	0	0	60.53	0	0	12
2014	9	25	7	48	19	34	0	0	0	0	0	0	0	60.51	0	0	12
2014	9	25	7	58	19	34	0	0	0	0	0	0	0	60.53	0	0	12.2
2014	9	25	8	8	19	34	0	0	0	0	0	0	0	60.53	0	0	12.4
2014	9	25	8	18	19	34	0	0	0	0	0	0	0	60.55	0	0	12.4
2014	9	25	8	28	19	34	0	0	0	0	0	0	0	60.55	0	0	12.8
2014	9	25	8	38	19	34	0	0	0	0	0	0	0	60.6	0	0	13
2014	9	25	8	48	19	33	0	0	0	0	0	0	0	60.66	0	0	13
2014	9	25	8	58	19	34	0	0	0	0	0	0	0	60.69	0	0	13
2014	9	25	9	8	19	34	0	0	0	0	0	0	0	60.73	0	0	13.4
2014	9	25	9	18	19	34	0	0	0	0	0	0	0	60.75	0	0	13.4
2014	9	25	9	28	19	34	0	0	0	0	0	0	0	60.78	0	0	13.6
2014	9	25	9	38	19	34	0	0	0	0	0	0	0	60.82	0	0	13.6
2014	9	25	9	48	19	34	0	0	0	0	0	0	0	60.85	0	0	13.8
2014	9	25	9	58	19	34	0	0	0	0	0	0	0	60.87	0	0	13.8
2014	9	25	10	8	19	34	0	0	0	0	0	0	0	60.93	0	0	13.8
2014	9	25	10	18	19	34	0	0	0	0	0	0	0	60.96	0	0	13.8
2014	9	25	10	28	19	33	0	0	0	0	0	0	0	61.03	0	0	13.8
2014	9	25	10	38	19	33	0	0	0	0	0	0	0	61.07	0	0	13.8
2014	9	25	10	48	19	33	0	0	0	0	0	0	0	61.12	0	0	13.8
2014	9	25	10	58	19	34	0	0	0	0	0	0	0	61.18	0	0	13.8
2014	9	25	11	8	19	34	0	0	0	0	0	0	0	61.23	0	0	13.8
2014	9	25	11	18	19	34	0	0	0	0	0	0	0	61.32	0	0	13.8
2014	9	25	11	28	19	33	0	0	0	0	0	0	0	61.36	0	0	14
2014	9	25	11	38	19	34	0	0	0	0	0	0	0	61.43	0	0	14
2014	9	25	11	48	19	34	0	0	0	0	0	0	0	61.5	0	0	14
2014	9	25	11	58	19	34	0	0	0	0	0	0	0	61.54	0	0	14
2014	9	25	12	8	19	34	0	0	0	0	0	0	0	61.59	0	0	14
2014	9	25	12	18	19	34	0	0	0	0	0	0	0	61.75	0	0	13.4
2014	9	25	12	28	19	34	0	0	0	0	0	0	0	61.83	0	0	13.8
2014	9	25	12	38	19	34	0	0	0	0	0	0	0	61.9	0	0	13.8
2014	9	25	12	48	19	34	0	0	0	0	0	0	0	61.95	0	0	13.8
2014	9	25	12	58	19	34	0	0	0	0	0	0	0	62.01	0	0	13.8
2014	9	25	13	8	19	34	0	0	0	0	0	0	0	62.06	0	0	13.8
2014	9	25	13	18	19	34	0	0	0	0	0	0	0	62.11	0	0	13.8
2014	9	25	13	28	19	33	0	0	0	0	0	0	0	62.17	0	0	13.8
2014	9	25	13	38	19	34	0	0	0	0	0	0	0	62.22	0	0	13.8
2014	9	25	13	48	19	33	0	0	0	0	0	0	0	62.26	0	0	13.8
2014	9	25	13	58	19	32	0	0	0	0	0	0	0	62.28	0	0	13.6
2014	9	25	14	8	19	34	0	0	0	0	0	0	0	62.2	0	0	12.8
2014	9	25	14	18	19	34	0	0	0	0	0	0	0	62.2	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	14	28	19	33	0	0	0	0	0	0	0	62.2	0	0	13.6
2014	9	25	14	38	19	34	0	0	0	0	0	0	0	62.33	0	0	13.8
2014	9	25	14	48	19	34	0	0	0	0	0	0	0	62.35	0	0	13.6
2014	9	25	14	58	19	34	0	0	0	0	0	0	0	62.31	0	0	13.2
2014	9	25	15	8	19	34	0	0	0	0	0	0	0	62.37	0	0	13
2014	9	25	15	18	19	34	0	0	0	0	0	0	0	62.42	0	0	13
2014	9	25	15	28	19	34	0	0	0	0	0	0	0	62.38	0	0	13.2
2014	9	25	15	38	19	33	0	0	0	0	0	0	0	62.42	0	0	13.4
2014	9	25	15	48	19	34	0	0	0	0	0	0	0	62.4	0	0	13.2
2014	9	25	15	58	19	34	0	0	0	0	0	0	0	62.38	0	0	12.4
2014	9	25	16	8	19	34	0	0	0	0	0	0	0	62.44	0	0	13.4
2014	9	25	16	18	19	34	0	0	0	0	0	0	0	62.44	0	0	13
2014	9	25	16	28	19	33	0	0	0	0	0	0	0	62.46	0	0	12.8
2014	9	25	16	38	19	34	0	0	0	0	0	0	0	62.46	0	0	12.8
2014	9	25	16	48	19	33	0	0	0	0	0	0	0	62.46	0	0	12.6
2014	9	25	16	58	19	33	0	0	0	0	0	0	0	62.46	0	0	12.4
2014	9	25	17	8	19	34	0	0	0	0	0	0	0	62.46	0	0	12.4
2014	9	25	17	18	19	33	0	0	0	0	0	0	0	62.44	0	0	12.2
2014	9	25	17	28	19	33	0	0	0	0	0	0	0	62.44	0	0	12.2
2014	9	25	17	38	19	33	0	0	0	0	0	0	0	62.44	0	0	12
2014	9	25	17	48	19	33	0	0	0	0	0	0	0	62.44	0	0	12
2014	9	25	17	58	19	34	0	0	0	0	0	0	0	62.44	0	0	11.8
2014	9	25	18	8	19	34	0	0	0	0	0	0	0	62.42	0	0	11.8
2014	9	25	18	18	19	33	0	0	0	0	0	0	0	62.42	0	0	11.8
2014	9	25	18	28	19	33	0	0	0	0	0	0	0	62.42	0	0	11.8
2014	9	25	18	38	19	34	0	0	0	0	0	0	0	62.42	0	0	11.8
2014	9	25	18	48	19	33	0	0	0	0	0	0	0	62.4	0	0	11.8
2014	9	25	18	58	19	33	0	0	0	0	0	0	0	62.4	0	0	11.8
2014	9	25	19	8	19	34	0	0	0	0	0	0	0	62.38	0	0	11.8
2014	9	25	19	18	19	32	0	0	0	0	0	0	0	62.38	0	0	11.8
2014	9	25	19	28	19	34	0	0	0	0	0	0	0	62.37	0	0	11.8
2014	9	25	19	38	19	33	0	0	0	0	0	0	0	62.37	0	0	11.8
2014	9	25	19	48	19	34	0	0	0	0	0	0	0	62.35	0	0	11.8
2014	9	25	19	58	19	33	0	0	0	0	0	0	0	62.33	0	0	11.8
2014	9	25	20	8	19	34	0	0	0	0	0	0	0	62.33	0	0	11.8
2014	9	25	20	18	19	34	0	0	0	0	0	0	0	62.29	0	0	11.8
2014	9	25	20	28	19	34	0	0	0	0	0	0	0	62.29	0	0	11.8
2014	9	25	20	38	19	33	0	0	0	0	0	0	0	62.28	0	0	11.8
2014	9	25	20	48	19	33	0	0	0	0	0	0	0	62.26	0	0	11.8
2014	9	25	20	58	19	34	0	0	0	0	0	0	0	62.24	0	0	11.8
2014	9	25	21	8	19	34	0	0	0	0	0	0	0	62.22	0	0	11.8
2014	9	25	21	18	19	33	0	0	0	0	0	0	0	62.2	0	0	11.8
2014	9	25	21	28	19	34	0	0	0	0	0	0	0	62.19	0	0	11.8
2014	9	25	21	38	19	34	0	0	0	0	0	0	0	62.17	0	0	11.8
2014	9	25	21	48	19	34	0	0	0	0	0	0	0	62.15	0	0	11.8
2014	9	25	21	58	19	33	0	0	0	0	0	0	0	62.13	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	25	22	8	19	33	0	0	0	0	0	0	0	62.11	0	0	11.8
2014	9	25	22	18	19	33	0	0	0	0	0	0	0	62.1	0	0	11.8
2014	9	25	22	28	19	34	0	0	0	0	0	0	0	62.08	0	0	11.8
2014	9	25	22	38	19	33	0	0	0	0	0	0	0	62.06	0	0	11.8
2014	9	25	22	48	19	34	0	0	0	0	0	0	0	62.04	0	0	11.8
2014	9	25	22	58	19	34	0	0	0	0	0	0	0	62.02	0	0	11.6
2014	9	25	23	8	19	34	0	0	0	0	0	0	0	62.01	0	0	11.6
2014	9	25	23	18	19	34	0	0	0	0	0	0	0	61.99	0	0	11.8
2014	9	25	23	28	19	33	0	0	0	0	0	0	0	61.99	0	0	11.8
2014	9	25	23	38	19	33	0	0	0	0	0	0	0	61.97	0	0	11.8
2014	9	25	23	48	19	34	0	0	0	0	0	0	0	61.95	0	0	11.8
2014	9	25	23	58	19	33	0	0	0	0	0	0	0	61.93	0	0	11.8
2014	9	26	0	8	19	33	0	0	0	0	0	0	0	61.92	0	0	11.6
2014	9	26	0	18	19	34	0	0	0	0	0	0	0	61.9	0	0	11.6
2014	9	26	0	28	19	34	0	0	0	0	0	0	0	61.88	0	0	11.6
2014	9	26	0	38	19	34	0	0	0	0	0	0	0	61.86	0	0	11.6
2014	9	26	0	48	19	34	0	0	0	0	0	0	0	61.83	0	0	11.6
2014	9	26	0	58	19	33	0	0	0	0	0	0	0	61.81	0	0	11.6
2014	9	26	1	8	19	33	0	0	0	0	0	0	0	61.79	0	0	11.6
2014	9	26	1	18	19	34	0	0	0	0	0	0	0	61.75	0	0	11.6
2014	9	26	1	28	19	33	0	0	0	0	0	0	0	61.74	0	0	11.6
2014	9	26	1	38	19	33	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	26	1	48	19	34	0	0	0	0	0	0	0	61.68	0	0	11.6
2014	9	26	1	58	19	33	0	0	0	0	0	0	0	61.66	0	0	11.6
2014	9	26	2	8	19	34	0	0	0	0	0	0	0	61.63	0	0	11.6
2014	9	26	2	18	19	34	0	0	0	0	0	0	0	61.61	0	0	11.6
2014	9	26	2	28	19	34	0	0	0	0	0	0	0	61.57	0	0	11.6
2014	9	26	2	38	19	34	0	0	0	0	0	0	0	61.56	0	0	11.6
2014	9	26	2	48	19	33	0	0	0	0	0	0	0	61.52	0	0	11.6
2014	9	26	2	58	19	34	0	0	0	0	0	0	0	61.5	0	0	11.6
2014	9	26	3	8	19	34	0	0	0	0	0	0	0	61.47	0	0	11.6
2014	9	26	3	18	19	33	0	0	0	0	0	0	0	61.45	0	0	11.6
2014	9	26	3	28	19	34	0	0	0	0	0	0	0	61.43	0	0	11.6
2014	9	26	3	38	19	34	0	0	0	0	0	0	0	61.39	0	0	11.6
2014	9	26	3	48	19	34	0	0	0	0	0	0	0	61.38	0	0	11.6
2014	9	26	3	58	19	33	0	0	0	0	0	0	0	61.36	0	0	11.6
2014	9	26	4	8	19	34	0	0	0	0	0	0	0	61.32	0	0	11.6
2014	9	26	4	18	19	33	0	0	0	0	0	0	0	61.29	0	0	11.6
2014	9	26	4	28	19	34	0	0	0	0	0	0	0	61.27	0	0	11.6
2014	9	26	4	38	19	34	0	0	0	0	0	0	0	61.25	0	0	11.6
2014	9	26	4	48	19	34	0	0	0	0	0	0	0	61.21	0	0	11.6
2014	9	26	4	58	19	33	0	0	0	0	0	0	0	61.2	0	0	11.6
2014	9	26	5	8	19	33	0	0	0	0	0	0	0	61.16	0	0	11.6
2014	9	26	5	18	19	34	0	0	0	0	0	0	0	61.14	0	0	11.6
2014	9	26	5	28	19	34	0	0	0	0	0	0	0	61.11	0	0	11.6
2014	9	26	5	38	19	34	0	0	0	0	0	0	0	61.09	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	5	48	19	34	0	0	0	0	0	0	0	61.07	0	0	11.6
2014	9	26	5	58	19	34	0	0	0	0	0	0	0	61.05	0	0	11.6
2014	9	26	6	8	19	34	0	0	0	0	0	0	0	61.03	0	0	11.6
2014	9	26	6	18	19	34	0	0	0	0	0	0	0	61	0	0	11.6
2014	9	26	6	28	19	34	0	0	0	0	0	0	0	60.98	0	0	11.6
2014	9	26	6	38	19	34	0	0	0	0	0	0	0	60.96	0	0	11.6
2014	9	26	6	48	19	33	0	0	0	0	0	0	0	60.94	0	0	11.6
2014	9	26	6	58	19	33	0	0	0	0	0	0	0	60.93	0	0	11.6
2014	9	26	7	8	19	33	0	0	0	0	0	0	0	60.91	0	0	11.6
2014	9	26	7	18	19	34	0	0	0	0	0	0	0	60.89	0	0	11.6
2014	9	26	7	28	19	34	0	0	0	0	0	0	0	60.87	0	0	11.6
2014	9	26	7	38	19	34	0	0	0	0	0	0	0	60.85	0	0	12
2014	9	26	7	48	19	34	0	0	0	0	0	0	0	60.85	0	0	12.2
2014	9	26	7	58	19	34	0	0	0	0	0	0	0	60.85	0	0	12.2
2014	9	26	8	8	19	34	0	0	0	0	0	0	0	60.85	0	0	12.4
2014	9	26	8	18	19	34	0	0	0	0	0	0	0	60.85	0	0	12.4
2014	9	26	8	28	19	33	0	0	0	0	0	0	0	60.84	0	0	12.4
2014	9	26	8	38	19	34	0	0	0	0	0	0	0	60.89	0	0	12.6
2014	9	26	8	48	19	34	0	0	0	0	0	0	0	60.94	0	0	12.6
2014	9	26	8	58	19	34	0	0	0	0	0	0	0	60.96	0	0	12.6
2014	9	26	9	8	19	34	0	0	0	0	0	0	0	61	0	0	12.6
2014	9	26	9	18	19	33	0	0	0	0	0	0	0	61.02	0	0	13.2
2014	9	26	9	28	19	34	0	0	0	0	0	0	0	61.03	0	0	13.2
2014	9	26	9	38	19	33	0	0	0	0	0	0	0	61.09	0	0	13.2
2014	9	26	9	48	19	34	0	0	0	0	0	0	0	61.12	0	0	13.4
2014	9	26	9	58	19	34	0	0	0	0	0	0	0	61.16	0	0	12.6
2014	9	26	10	8	19	34	0	0	0	0	0	0	0	61.2	0	0	13.6
2014	9	26	10	18	19	33	0	0	0	0	0	0	0	61.23	0	0	13.6
2014	9	26	10	28	19	33	0	0	0	0	0	0	0	61.29	0	0	14
2014	9	26	10	38	19	34	0	0	0	0	0	0	0	61.32	0	0	13.8
2014	9	26	10	48	19	33	0	0	0	0	0	0	0	61.36	0	0	14
2014	9	26	10	58	19	34	0	0	0	0	0	0	0	61.48	0	0	14
2014	9	26	11	8	19	33	0	0	0	0	0	0	0	61.52	0	0	13.8
2014	9	26	11	18	19	34	0	0	0	0	0	0	0	61.54	0	0	14
2014	9	26	11	28	19	34	0	0	0	0	0	0	0	61.57	0	0	14.2
2014	9	26	11	38	19	33	0	0	0	0	0	0	0	61.61	0	0	14.2
2014	9	26	11	48	19	34	0	0	0	0	0	0	0	61.65	0	0	14.2
2014	9	26	11	58	19	34	0	0	0	0	0	0	0	61.66	0	0	14.2
2014	9	26	12	8	19	33	0	0	0	0	0	0	0	61.72	0	0	13.2
2014	9	26	12	18	19	33	0	0	0	0	0	0	0	61.74	0	0	13.2
2014	9	26	12	28	19	34	0	0	0	0	0	0	0	61.75	0	0	13.2
2014	9	26	12	38	19	33	0	0	0	0	0	0	0	61.79	0	0	13.2
2014	9	26	12	48	19	34	0	0	0	0	0	0	0	61.83	0	0	13.2
2014	9	26	12	58	19	34	0	0	0	0	0	0	0	61.84	0	0	13.2
2014	9	26	13	8	19	34	0	0	0	0	0	0	0	61.88	0	0	13
2014	9	26	13	18	19	34	0	0	0	0	0	0	0	61.9	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	13	28	19	33	0	0	0	0	0	0	0	61.92	0	0	13.2
2014	9	26	13	38	19	34	0	0	0	0	0	0	0	61.93	0	0	13.2
2014	9	26	13	48	19	34	0	0	0	0	0	0	0	61.95	0	0	13.2
2014	9	26	13	58	19	33	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	8	19	34	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	18	19	34	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	28	19	34	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	38	19	34	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	48	19	34	0	0	0	0	0	0	0	61.97	0	0	13
2014	9	26	14	58	19	33	0	0	0	0	0	0	0	61.95	0	0	13
2014	9	26	15	8	19	34	0	0	0	0	0	0	0	61.95	0	0	13
2014	9	26	15	18	19	34	0	0	0	0	0	0	0	61.93	0	0	13
2014	9	26	15	28	19	34	0	0	0	0	0	0	0	61.92	0	0	13
2014	9	26	15	38	19	34	0	0	0	0	0	0	0	61.92	0	0	13
2014	9	26	15	48	19	34	0	0	0	0	0	0	0	61.9	0	0	13
2014	9	26	15	58	19	33	0	0	0	0	0	0	0	61.88	0	0	13
2014	9	26	16	8	19	33	0	0	0	0	0	0	0	61.86	0	0	12.6
2014	9	26	16	18	19	33	0	0	0	0	0	0	0	61.86	0	0	12.6
2014	9	26	16	28	19	33	0	0	0	0	0	0	0	61.83	0	0	12.6
2014	9	26	16	38	19	33	0	0	0	0	0	0	0	61.83	0	0	12.4
2014	9	26	16	48	19	34	0	0	0	0	0	0	0	61.81	0	0	12.4
2014	9	26	16	58	19	34	0	0	0	0	0	0	0	61.79	0	0	12.2
2014	9	26	17	8	19	33	0	0	0	0	0	0	0	61.77	0	0	12
2014	9	26	17	18	19	34	0	0	0	0	0	0	0	61.74	0	0	12
2014	9	26	17	28	19	33	0	0	0	0	0	0	0	61.72	0	0	11.8
2014	9	26	17	38	19	34	0	0	0	0	0	0	0	61.7	0	0	11.6
2014	9	26	17	48	19	34	0	0	0	0	0	0	0	61.7	0	0	11.4
2014	9	26	17	58	19	33	0	0	0	0	0	0	0	61.7	0	0	11.4
2014	9	26	18	8	19	33	0	0	0	0	0	0	0	61.68	0	0	11.4
2014	9	26	18	18	19	34	0	0	0	0	0	0	0	61.66	0	0	11.2
2014	9	26	18	28	19	34	0	0	0	0	0	0	0	61.66	0	0	11.2
2014	9	26	18	38	19	33	0	0	0	0	0	0	0	61.65	0	0	11.2
2014	9	26	18	48	19	34	0	0	0	0	0	0	0	61.63	0	0	11.2
2014	9	26	18	58	19	34	0	0	0	0	0	0	0	61.59	0	0	11.2
2014	9	26	19	8	19	33	0	0	0	0	0	0	0	61.57	0	0	11.2
2014	9	26	19	18	19	33	0	0	0	0	0	0	0	61.56	0	0	11.4
2014	9	26	19	28	19	33	0	0	0	0	0	0	0	61.54	0	0	11.4
2014	9	26	19	38	19	34	0	0	0	0	0	0	0	61.52	0	0	11.4
2014	9	26	19	48	19	34	0	0	0	0	0	0	0	61.48	0	0	11.4
2014	9	26	19	58	19	34	0	0	0	0	0	0	0	61.47	0	0	11.4
2014	9	26	20	8	19	33	0	0	0	0	0	0	0	61.43	0	0	11.4
2014	9	26	20	18	19	34	0	0	0	0	0	0	0	61.41	0	0	11.2
2014	9	26	20	28	19	34	0	0	0	0	0	0	0	61.36	0	0	11.2
2014	9	26	20	38	19	34	0	0	0	0	0	0	0	61.34	0	0	11.2
2014	9	26	20	48	19	34	0	0	0	0	0	0	0	61.29	0	0	11.2
2014	9	26	20	58	19	34	0	0	0	0	0	0	0	61.27	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	26	21	8	19	33	0	0	0	0	0	0	0	61.21	0	0	11.2
2014	9	26	21	18	19	34	0	0	0	0	0	0	0	61.18	0	0	11
2014	9	26	21	28	19	34	0	0	0	0	0	0	0	61.14	0	0	11
2014	9	26	21	38	19	34	0	0	0	0	0	0	0	61.11	0	0	11
2014	9	26	21	48	19	33	0	0	0	0	0	0	0	61.07	0	0	11.2
2014	9	26	21	58	19	33	0	0	0	0	0	0	0	61.03	0	0	11
2014	9	26	22	8	19	34	0	0	0	0	0	0	0	61	0	0	11
2014	9	26	22	18	19	34	0	0	0	0	0	0	0	60.96	0	0	11
2014	9	26	22	28	19	34	0	0	0	0	0	0	0	60.93	0	0	11
2014	9	26	22	38	19	33	0	0	0	0	0	0	0	60.89	0	0	11
2014	9	26	22	48	19	34	0	0	0	0	0	0	0	60.87	0	0	11
2014	9	26	22	58	19	33	0	0	0	0	0	0	0	60.84	0	0	11
2014	9	26	23	8	19	34	0	0	0	0	0	0	0	60.8	0	0	11
2014	9	26	23	18	19	34	0	0	0	0	0	0	0	60.76	0	0	11
2014	9	26	23	28	19	33	0	0	0	0	0	0	0	60.76	0	0	11
2014	9	26	23	38	19	34	0	0	0	0	0	0	0	60.73	0	0	11
2014	9	26	23	48	19	34	0	0	0	0	0	0	0	60.71	0	0	11
2014	9	26	23	58	19	34	0	0	0	0	0	0	0	60.67	0	0	11
2014	9	27	0	8	19	34	0	0	0	0	0	0	0	60.67	0	0	11
2014	9	27	0	18	19	34	0	0	0	0	0	0	0	60.64	0	0	10.8
2014	9	27	0	28	19	34	0	0	0	0	0	0	0	60.62	0	0	10.8
2014	9	27	0	38	19	34	0	0	0	0	0	0	0	60.6	0	0	11
2014	9	27	0	48	19	34	0	0	0	0	0	0	0	60.58	0	0	11.2
2014	9	27	0	58	19	34	0	0	0	0	0	0	0	60.55	0	0	11.2
2014	9	27	1	8	19	34	0	0	0	0	0	0	0	60.53	0	0	11.2
2014	9	27	1	18	19	34	0	0	0	0	0	0	0	60.51	0	0	11.2
2014	9	27	1	28	19	34	0	0	0	0	0	0	0	60.48	0	0	11.2
2014	9	27	1	38	19	34	0	0	0	0	0	0	0	60.46	0	0	11.2
2014	9	27	1	48	19	33	0	0	0	0	0	0	0	60.44	0	0	11.2
2014	9	27	1	58	19	34	0	0	0	0	0	0	0	60.4	0	0	11.2
2014	9	27	2	8	19	33	0	0	0	0	0	0	0	60.39	0	0	11.2
2014	9	27	2	18	19	34	0	0	0	0	0	0	0	60.35	0	0	11.2
2014	9	27	2	28	19	34	0	0	0	0	0	0	0	60.33	0	0	11.4
2014	9	27	2	38	19	34	0	0	0	0	0	0	0	60.31	0	0	11.4
2014	9	27	2	48	19	33	0	0	0	0	0	0	0	60.3	0	0	11.4
2014	9	27	2	58	19	34	0	0	0	0	0	0	0	60.26	0	0	11.4
2014	9	27	3	8	19	34	0	0	0	0	0	0	0	60.24	0	0	11.4
2014	9	27	3	18	19	33	0	0	0	0	0	0	0	60.21	0	0	11.4
2014	9	27	3	28	19	34	0	0	0	0	0	0	0	60.19	0	0	11.4
2014	9	27	3	38	19	33	0	0	0	0	0	0	0	60.15	0	0	11.4
2014	9	27	3	48	19	33	0	0	0	0	0	0	0	60.12	0	0	11.4
2014	9	27	3	58	19	34	0	0	0	0	0	0	0	60.1	0	0	11.4
2014	9	27	4	8	19	34	0	0	0	0	0	0	0	60.06	0	0	11.4
2014	9	27	4	18	19	34	0	0	0	0	0	0	0	60.04	0	0	11.2
2014	9	27	4	28	19	33	0	0	0	0	0	0	0	60.01	0	0	11.2
2014	9	27	4	38	19	35	0	0	0	0	0	0	0	59.97	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	4	48	19	34	0	0	0	0	0	0	0	59.94	0	0	11.2
2014	9	27	4	58	19	34	0	0	0	0	0	0	0	59.9	0	0	11.2
2014	9	27	5	8	19	34	0	0	0	0	0	0	0	59.86	0	0	11.2
2014	9	27	5	18	19	34	0	0	0	0	0	0	0	59.85	0	0	11.2
2014	9	27	5	28	19	34	0	0	0	0	0	0	0	59.81	0	0	11.2
2014	9	27	5	38	19	34	0	0	0	0	0	0	0	59.77	0	0	11.2
2014	9	27	5	48	19	34	0	0	0	0	0	0	0	59.76	0	0	11.2
2014	9	27	5	58	19	34	0	0	0	0	0	0	0	59.74	0	0	11.2
2014	9	27	6	8	19	33	0	0	0	0	0	0	0	59.7	0	0	11.2
2014	9	27	6	18	19	34	0	0	0	0	0	0	0	59.7	0	0	11.2
2014	9	27	6	28	19	33	0	0	0	0	0	0	0	59.68	0	0	11.2
2014	9	27	6	38	19	34	0	0	0	0	0	0	0	59.65	0	0	11.2
2014	9	27	6	48	19	34	0	0	0	0	0	0	0	59.63	0	0	11.2
2014	9	27	6	58	19	34	0	0	0	0	0	0	0	59.61	0	0	11.2
2014	9	27	7	8	19	34	0	0	0	0	0	0	0	59.59	0	0	11.4
2014	9	27	7	18	19	33	0	0	0	0	0	0	0	59.58	0	0	11.4
2014	9	27	7	28	19	34	0	0	0	0	0	0	0	59.56	0	0	11.4
2014	9	27	7	38	19	34	0	0	0	0	0	0	0	59.54	0	0	11.8
2014	9	27	7	48	19	34	0	0	0	0	0	0	0	59.52	0	0	12
2014	9	27	7	58	19	33	0	0	0	0	0	0	0	59.49	0	0	12.2
2014	9	27	8	8	19	34	0	0	0	0	0	0	0	59.49	0	0	12.2
2014	9	27	8	18	19	34	0	0	0	0	0	0	0	59.49	0	0	12.4
2014	9	27	8	28	19	34	0	0	0	0	0	0	0	59.47	0	0	12.6
2014	9	27	8	38	19	34	0	0	0	0	0	0	0	59.49	0	0	12.8
2014	9	27	8	48	19	34	0	0	0	0	0	0	0	59.56	0	0	12.8
2014	9	27	8	58	19	34	0	0	0	0	0	0	0	59.58	0	0	12.8
2014	9	27	9	8	19	34	0	0	0	0	0	0	0	59.58	0	0	13
2014	9	27	9	18	19	34	0	0	0	0	0	0	0	59.59	0	0	13
2014	9	27	9	28	19	34	0	0	0	0	0	0	0	59.61	0	0	13
2014	9	27	9	38	19	34	0	0	0	0	0	0	0	59.63	0	0	13
2014	9	27	9	48	19	34	0	0	0	0	0	0	0	59.65	0	0	13
2014	9	27	9	58	19	34	0	0	0	0	0	0	0	59.67	0	0	13.2
2014	9	27	10	8	19	33	0	0	0	0	0	0	0	59.7	0	0	13.4
2014	9	27	10	18	19	34	0	0	0	0	0	0	0	59.72	0	0	13.2
2014	9	27	10	28	19	34	0	0	0	0	0	0	0	59.74	0	0	13.4
2014	9	27	10	38	19	34	0	0	0	0	0	0	0	59.77	0	0	13.4
2014	9	27	10	48	19	34	0	0	0	0	0	0	0	59.83	0	0	13.6
2014	9	27	10	58	19	34	0	0	0	0	0	0	0	59.85	0	0	13.4
2014	9	27	11	8	19	34	0	0	0	0	0	0	0	59.88	0	0	13.4
2014	9	27	11	18	19	34	0	0	0	0	0	0	0	59.94	0	0	13.2
2014	9	27	11	28	19	34	0	0	0	0	0	0	0	59.95	0	0	13
2014	9	27	11	38	19	33	0	0	0	0	0	0	0	59.99	0	0	12.8
2014	9	27	11	48	19	34	0	0	0	0	0	0	0	60.03	0	0	13.2
2014	9	27	11	58	19	34	0	0	0	0	0	0	0	60.08	0	0	13.2
2014	9	27	12	8	19	34	0	0	0	0	0	0	0	60.12	0	0	13.2
2014	9	27	12	18	19	33	0	0	0	0	0	0	0	60.17	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	12	28	19	34	0	0	0	0	0	0	0	60.22	0	0	13.2
2014	9	27	12	38	19	34	0	0	0	0	0	0	0	60.3	0	0	13.4
2014	9	27	12	48	19	34	0	0	0	0	0	0	0	60.19	0	0	13.4
2014	9	27	12	58	19	34	0	0	0	0	0	0	0	60.3	0	0	13.6
2014	9	27	13	8	19	33	0	0	0	0	0	0	0	60.31	0	0	13.6
2014	9	27	13	18	19	34	0	0	0	0	0	0	0	60.31	0	0	13.8
2014	9	27	13	28	19	35	0	0	0	0	0	0	0	60.35	0	0	13.8
2014	9	27	13	38	19	34	0	0	0	0	0	0	0	60.37	0	0	13.8
2014	9	27	13	48	19	34	0	0	0	0	0	0	0	60.39	0	0	13.6
2014	9	27	13	58	19	34	0	0	0	0	0	0	0	60.4	0	0	14
2014	9	27	14	8	19	34	0	0	0	0	0	0	0	60.4	0	0	14.2
2014	9	27	14	18	19	34	0	0	0	0	0	0	0	60.4	0	0	14.2
2014	9	27	14	28	19	33	0	0	0	0	0	0	0	60.4	0	0	14.2
2014	9	27	14	38	19	34	0	0	0	0	0	0	0	60.42	0	0	14
2014	9	27	14	48	19	34	0	0	0	0	0	0	0	60.28	0	0	13.4
2014	9	27	14	58	19	34	0	0	0	0	0	0	0	60.31	0	0	13.8
2014	9	27	15	8	19	34	0	0	0	0	0	0	0	60.22	0	0	12.6
2014	9	27	15	18	19	34	0	0	0	0	0	0	0	60.15	0	0	12.4
2014	9	27	15	28	19	34	0	0	0	0	0	0	0	60.12	0	0	12.2
2014	9	27	15	38	19	34	0	0	0	0	0	0	0	60.12	0	0	12.2
2014	9	27	15	48	19	34	0	0	0	0	0	0	0	60.1	0	0	12
2014	9	27	15	58	19	33	0	0	0	0	0	0	0	60.1	0	0	12
2014	9	27	16	8	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	16	18	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	16	28	19	33	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	16	38	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	16	48	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	16	58	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	17	8	19	34	0	0	0	0	0	0	0	60.08	0	0	11.8
2014	9	27	17	18	19	34	0	0	0	0	0	0	0	60.06	0	0	11.8
2014	9	27	17	28	19	34	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	27	17	38	19	34	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	27	17	48	19	33	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	27	17	58	19	34	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	27	18	8	19	34	0	0	0	0	0	0	0	60.04	0	0	11.8
2014	9	27	18	18	19	34	0	0	0	0	0	0	0	60.03	0	0	11.8
2014	9	27	18	28	19	34	0	0	0	0	0	0	0	59.99	0	0	11.8
2014	9	27	18	38	19	34	0	0	0	0	0	0	0	59.97	0	0	11.8
2014	9	27	18	48	19	34	0	0	0	0	0	0	0	59.94	0	0	11.8
2014	9	27	18	58	19	34	0	0	0	0	0	0	0	59.92	0	0	11.8
2014	9	27	19	8	19	34	0	0	0	0	0	0	0	59.9	0	0	11.8
2014	9	27	19	18	19	34	0	0	0	0	0	0	0	59.86	0	0	11.8
2014	9	27	19	28	19	34	0	0	0	0	0	0	0	59.81	0	0	11.8
2014	9	27	19	38	19	34	0	0	0	0	0	0	0	59.79	0	0	11.8
2014	9	27	19	48	19	34	0	0	0	0	0	0	0	59.74	0	0	11.8
2014	9	27	19	58	19	34	0	0	0	0	0	0	0	59.7	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	27	20	8	19	34	0	0	0	0	0	0	0	59.68	0	0	11.8
2014	9	27	20	18	19	34	0	0	0	0	0	0	0	59.63	0	0	11.8
2014	9	27	20	28	19	34	0	0	0	0	0	0	0	59.59	0	0	11.8
2014	9	27	20	38	19	34	0	0	0	0	0	0	0	59.56	0	0	11.8
2014	9	27	20	48	19	34	0	0	0	0	0	0	0	59.5	0	0	11.8
2014	9	27	20	58	19	33	0	0	0	0	0	0	0	59.49	0	0	11.8
2014	9	27	21	8	19	34	0	0	0	0	0	0	0	59.43	0	0	11.8
2014	9	27	21	18	19	34	0	0	0	0	0	0	0	59.4	0	0	11.8
2014	9	27	21	28	19	33	0	0	0	0	0	0	0	59.36	0	0	11.8
2014	9	27	21	38	19	34	0	0	0	0	0	0	0	59.32	0	0	11.8
2014	9	27	21	48	19	34	0	0	0	0	0	0	0	59.27	0	0	11.8
2014	9	27	21	58	19	34	0	0	0	0	0	0	0	59.23	0	0	11.8
2014	9	27	22	8	19	34	0	0	0	0	0	0	0	59.2	0	0	11.6
2014	9	27	22	18	19	34	0	0	0	0	0	0	0	59.16	0	0	11.6
2014	9	27	22	28	19	34	0	0	0	0	0	0	0	59.13	0	0	11.6
2014	9	27	22	38	19	34	0	0	0	0	0	0	0	59.09	0	0	11.6
2014	9	27	22	48	19	34	0	0	0	0	0	0	0	59.05	0	0	11.6
2014	9	27	22	58	19	34	0	0	0	0	0	0	0	59.02	0	0	11.6
2014	9	27	23	8	19	34	0	0	0	0	0	0	0	58.98	0	0	11.6
2014	9	27	23	18	19	34	0	0	0	0	0	0	0	58.96	0	0	11.6
2014	9	27	23	28	19	33	0	0	0	0	0	0	0	58.91	0	0	11.6
2014	9	27	23	38	19	34	0	0	0	0	0	0	0	58.89	0	0	11.6
2014	9	27	23	48	19	33	0	0	0	0	0	0	0	58.86	0	0	11.6
2014	9	27	23	58	19	33	0	0	0	0	0	0	0	58.82	0	0	11.6
2014	9	28	0	8	19	34	0	0	0	0	0	0	0	58.78	0	0	11.6
2014	9	28	0	18	19	34	0	0	0	0	0	0	0	58.75	0	0	11.6
2014	9	28	0	28	19	34	0	0	0	0	0	0	0	58.73	0	0	11.6
2014	9	28	0	38	19	34	0	0	0	0	0	0	0	58.69	0	0	11.6
2014	9	28	0	48	19	34	0	0	0	0	0	0	0	58.66	0	0	11.6
2014	9	28	0	58	19	34	0	0	0	0	0	0	0	58.62	0	0	11.6
2014	9	28	1	8	19	34	0	0	0	0	0	0	0	58.6	0	0	11.6
2014	9	28	1	18	19	33	0	0	0	0	0	0	0	58.59	0	0	11.6
2014	9	28	1	28	19	34	0	0	0	0	0	0	0	58.55	0	0	11.6
2014	9	28	1	38	19	34	0	0	0	0	0	0	0	58.51	0	0	11.6
2014	9	28	1	48	19	34	0	0	0	0	0	0	0	58.48	0	0	11.6
2014	9	28	1	58	19	34	0	0	0	0	0	0	0	58.46	0	0	11.6
2014	9	28	2	8	19	34	0	0	0	0	0	0	0	58.42	0	0	11.6
2014	9	28	2	18	19	35	0	0	0	0	0	0	0	58.39	0	0	11.6
2014	9	28	2	28	19	34	0	0	0	0	0	0	0	58.35	0	0	11.6
2014	9	28	2	38	19	34	0	0	0	0	0	0	0	58.32	0	0	11.6
2014	9	28	2	48	19	34	0	0	0	0	0	0	0	58.28	0	0	11.6
2014	9	28	2	58	19	34	0	0	0	0	0	0	0	58.26	0	0	11.6
2014	9	28	3	8	19	34	0	0	0	0	0	0	0	58.23	0	0	11.6
2014	9	28	3	18	19	34	0	0	0	0	0	0	0	58.19	0	0	11.6
2014	9	28	3	28	19	34	0	0	0	0	0	0	0	58.15	0	0	11.6
2014	9	28	3	38	19	34	0	0	0	0	0	0	0	58.12	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	3	48	19	34	0	0	0	0	0	0	0	58.08	0	0	11.6
2014	9	28	3	58	19	34	0	0	0	0	0	0	0	58.05	0	0	11.6
2014	9	28	4	8	19	33	0	0	0	0	0	0	0	58.01	0	0	11.6
2014	9	28	4	18	19	34	0	0	0	0	0	0	0	57.96	0	0	11.6
2014	9	28	4	28	19	34	0	0	0	0	0	0	0	57.92	0	0	11.6
2014	9	28	4	38	19	34	0	0	0	0	0	0	0	57.87	0	0	11.6
2014	9	28	4	48	19	34	0	0	0	0	0	0	0	57.83	0	0	11.6
2014	9	28	4	58	19	34	0	0	0	0	0	0	0	57.79	0	0	11.6
2014	9	28	5	8	19	34	0	0	0	0	0	0	0	57.76	0	0	11.6
2014	9	28	5	18	19	34	0	0	0	0	0	0	0	57.72	0	0	11.6
2014	9	28	5	28	19	33	0	0	0	0	0	0	0	57.67	0	0	11.6
2014	9	28	5	38	19	34	0	0	0	0	0	0	0	57.63	0	0	11.6
2014	9	28	5	48	19	34	0	0	0	0	0	0	0	57.6	0	0	11.6
2014	9	28	5	58	19	34	0	0	0	0	0	0	0	57.54	0	0	11.6
2014	9	28	6	8	19	34	0	0	0	0	0	0	0	57.51	0	0	11.6
2014	9	28	6	18	19	34	0	0	0	0	0	0	0	57.45	0	0	11.4
2014	9	28	6	28	19	33	0	0	0	0	0	0	0	57.42	0	0	11.4
2014	9	28	6	38	19	34	0	0	0	0	0	0	0	57.38	0	0	11.4
2014	9	28	6	48	19	34	0	0	0	0	0	0	0	57.34	0	0	11.6
2014	9	28	6	58	19	34	0	0	0	0	0	0	0	57.31	0	0	11.6
2014	9	28	7	8	19	34	0	0	0	0	0	0	0	57.27	0	0	11.6
2014	9	28	7	18	19	34	0	0	0	0	0	0	0	57.24	0	0	11.6
2014	9	28	7	28	19	34	0	0	0	0	0	0	0	57.2	0	0	11.6
2014	9	28	7	38	19	34	0	0	0	0	0	0	0	57.18	0	0	12
2014	9	28	7	48	19	34	0	0	0	0	0	0	0	57.16	0	0	12.2
2014	9	28	7	58	19	35	0	0	0	0	0	0	0	57.15	0	0	12.4
2014	9	28	8	8	19	34	0	0	0	0	0	0	0	57.15	0	0	12.6
2014	9	28	8	18	19	34	0	0	0	0	0	0	0	57.13	0	0	12.4
2014	9	28	8	28	19	35	0	0	0	0	0	0	0	57.13	0	0	13
2014	9	28	8	38	19	34	0	0	0	0	0	0	0	57.16	0	0	13.6
2014	9	28	8	48	19	34	0	0	0	0	0	0	0	57.22	0	0	13.8
2014	9	28	8	58	19	34	0	0	0	0	0	0	0	57.2	0	0	12.6
2014	9	28	9	8	19	34	0	0	0	0	0	0	0	57.18	0	0	12.8
2014	9	28	9	18	19	34	0	0	0	0	0	0	0	57.2	0	0	13.2
2014	9	28	9	28	19	34	0	0	0	0	0	0	0	57.31	0	0	14
2014	9	28	9	38	19	34	0	0	0	0	0	0	0	57.36	0	0	14
2014	9	28	9	48	19	34	0	0	0	0	0	0	0	57.43	0	0	14
2014	9	28	9	58	19	34	0	0	0	0	0	0	0	57.51	0	0	13.6
2014	9	28	10	8	19	34	0	0	0	0	0	0	0	57.47	0	0	13.8
2014	9	28	10	18	19	34	0	0	0	0	0	0	0	57.42	0	0	13.2
2014	9	28	10	28	19	34	0	0	0	0	0	0	0	57.58	0	0	13
2014	9	28	10	38	19	34	0	0	0	0	0	0	0	57.51	0	0	12.8
2014	9	28	10	48	19	34	0	0	0	0	0	0	0	57.65	0	0	13.8
2014	9	28	10	58	19	34	0	0	0	0	0	0	0	57.78	0	0	13.6
2014	9	28	11	8	19	34	0	0	0	0	0	0	0	57.87	0	0	13.6
2014	9	28	11	18	19	35	0	0	0	0	0	0	0	57.88	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	11	28	19	34	0	0	0	0	0	0	0	57.97	0	0	13.6
2014	9	28	11	38	19	35	0	0	0	0	0	0	0	58.01	0	0	13.8
2014	9	28	11	48	19	33	0	0	0	0	0	0	0	58.06	0	0	13.2
2014	9	28	11	58	19	34	0	0	0	0	0	0	0	58.01	0	0	13.2
2014	9	28	12	8	19	34	0	0	0	0	0	0	0	58.15	0	0	13.2
2014	9	28	12	18	19	34	0	0	0	0	0	0	0	58.08	0	0	13.2
2014	9	28	12	28	19	33	0	0	0	0	0	0	0	58.21	0	0	13.4
2014	9	28	12	38	19	34	0	0	0	0	0	0	0	58.21	0	0	13.2
2014	9	28	12	48	19	34	0	0	0	0	0	0	0	58.28	0	0	13.6
2014	9	28	12	58	19	34	0	0	0	0	0	0	0	58.35	0	0	13.8
2014	9	28	13	8	19	34	0	0	0	0	0	0	0	58.41	0	0	13.8
2014	9	28	13	18	19	34	0	0	0	0	0	0	0	58.26	0	0	13.2
2014	9	28	13	28	19	34	0	0	0	0	0	0	0	58.44	0	0	13.6
2014	9	28	13	38	19	34	0	0	0	0	0	0	0	58.48	0	0	13.2
2014	9	28	13	48	19	34	0	0	0	0	0	0	0	58.41	0	0	13.2
2014	9	28	13	58	19	34	0	0	0	0	0	0	0	58.42	0	0	13.4
2014	9	28	14	8	19	34	0	0	0	0	0	0	0	58.35	0	0	13.2
2014	9	28	14	18	19	34	0	0	0	0	0	0	0	58.35	0	0	13.4
2014	9	28	14	28	19	34	0	0	0	0	0	0	0	58.35	0	0	13.4
2014	9	28	14	38	19	34	0	0	0	0	0	0	0	58.33	0	0	13
2014	9	28	14	48	19	34	0	0	0	0	0	0	0	58.35	0	0	13.2
2014	9	28	14	58	19	34	0	0	0	0	0	0	0	58.37	0	0	13
2014	9	28	15	8	19	34	0	0	0	0	0	0	0	58.37	0	0	12.8
2014	9	28	15	18	19	34	0	0	0	0	0	0	0	58.42	0	0	13.4
2014	9	28	15	28	19	34	0	0	0	0	0	0	0	58.46	0	0	13.4
2014	9	28	15	38	19	34	0	0	0	0	0	0	0	58.48	0	0	13.4
2014	9	28	15	48	19	34	0	0	0	0	0	0	0	58.48	0	0	12.6
2014	9	28	15	58	19	33	0	0	0	0	0	0	0	58.5	0	0	12.4
2014	9	28	16	8	19	34	0	0	0	0	0	0	0	58.5	0	0	12.2
2014	9	28	16	18	19	34	0	0	0	0	0	0	0	58.5	0	0	12
2014	9	28	16	28	19	34	0	0	0	0	0	0	0	58.5	0	0	11.8
2014	9	28	16	38	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	16	48	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	16	58	19	34	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	28	17	8	19	34	0	0	0	0	0	0	0	58.53	0	0	11.6
2014	9	28	17	18	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	17	28	19	34	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	28	17	38	19	33	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	28	17	48	19	34	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	28	17	58	19	34	0	0	0	0	0	0	0	58.55	0	0	11.8
2014	9	28	18	8	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	18	18	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	18	28	19	34	0	0	0	0	0	0	0	58.53	0	0	11.8
2014	9	28	18	38	19	34	0	0	0	0	0	0	0	58.51	0	0	11.8
2014	9	28	18	48	19	34	0	0	0	0	0	0	0	58.5	0	0	11.8
2014	9	28	18	58	19	34	0	0	0	0	0	0	0	58.48	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	28	19	8	19	34	0	0	0	0	0	0	0	58.46	0	0	11.8
2014	9	28	19	18	19	34	0	0	0	0	0	0	0	58.46	0	0	11.2
2014	9	28	19	28	19	34	0	0	0	0	0	0	0	58.44	0	0	11.2
2014	9	28	19	38	19	34	0	0	0	0	0	0	0	58.42	0	0	11.2
2014	9	28	19	48	19	34	0	0	0	0	0	0	0	58.41	0	0	11.2
2014	9	28	19	58	19	34	0	0	0	0	0	0	0	58.41	0	0	11.2
2014	9	28	20	8	19	34	0	0	0	0	0	0	0	58.39	0	0	11.2
2014	9	28	20	18	19	35	0	0	0	0	0	0	0	58.37	0	0	11.2
2014	9	28	20	28	19	34	0	0	0	0	0	0	0	58.35	0	0	11.2
2014	9	28	20	38	19	34	0	0	0	0	0	0	0	58.33	0	0	11.2
2014	9	28	20	48	19	35	0	0	0	0	0	0	0	58.32	0	0	11.2
2014	9	28	20	58	19	34	0	0	0	0	0	0	0	58.3	0	0	11.2
2014	9	28	21	8	19	34	0	0	0	0	0	0	0	58.28	0	0	11.2
2014	9	28	21	18	19	34	0	0	0	0	0	0	0	58.26	0	0	11.2
2014	9	28	21	28	19	34	0	0	0	0	0	0	0	58.24	0	0	11.2
2014	9	28	21	38	19	35	0	0	0	0	0	0	0	58.21	0	0	11.2
2014	9	28	21	48	19	33	0	0	0	0	0	0	0	58.21	0	0	11.2
2014	9	28	21	58	19	33	0	0	0	0	0	0	0	58.19	0	0	11.2
2014	9	28	22	8	19	33	0	0	0	0	0	0	0	58.17	0	0	11.2
2014	9	28	22	18	19	34	0	0	0	0	0	0	0	58.15	0	0	11.6
2014	9	28	22	28	19	35	0	0	0	0	0	0	0	58.15	0	0	11.6
2014	9	28	22	38	19	34	0	0	0	0	0	0	0	58.14	0	0	11.6
2014	9	28	22	48	19	33	0	0	0	0	0	0	0	58.12	0	0	11.6
2014	9	28	22	58	19	33	0	0	0	0	0	0	0	58.1	0	0	11.6
2014	9	28	23	8	19	34	0	0	0	0	0	0	0	58.08	0	0	11.6
2014	9	28	23	18	19	34	0	0	0	0	0	0	0	58.06	0	0	11.6
2014	9	28	23	28	19	34	0	0	0	0	0	0	0	58.05	0	0	11.6
2014	9	28	23	38	19	35	0	0	0	0	0	0	0	58.03	0	0	11.6
2014	9	28	23	48	19	34	0	0	0	0	0	0	0	58.01	0	0	11.6
2014	9	28	23	58	19	33	0	0	0	0	0	0	0	57.99	0	0	11.6
2014	9	29	0	8	19	34	0	0	0	0	0	0	0	57.97	0	0	11.6
2014	9	29	0	18	19	34	0	0	0	0	0	0	0	57.96	0	0	11.6
2014	9	29	0	28	19	34	0	0	0	0	0	0	0	57.94	0	0	11.6
2014	9	29	0	38	19	34	0	0	0	0	0	0	0	57.92	0	0	11.6
2014	9	29	0	48	19	35	0	0	0	0	0	0	0	57.9	0	0	11.6
2014	9	29	0	58	19	33	0	0	0	0	0	0	0	57.87	0	0	11.6
2014	9	29	1	8	19	33	0	0	0	0	0	0	0	57.85	0	0	11.6
2014	9	29	1	18	19	34	0	0	0	0	0	0	0	57.81	0	0	11.6
2014	9	29	1	28	19	34	0	0	0	0	0	0	0	57.78	0	0	11.6
2014	9	29	1	38	19	34	0	0	0	0	0	0	0	57.74	0	0	11.6
2014	9	29	1	48	19	34	0	0	0	0	0	0	0	57.72	0	0	11.6
2014	9	29	1	58	19	34	0	0	0	0	0	0	0	57.69	0	0	11.6
2014	9	29	2	8	19	34	0	0	0	0	0	0	0	57.65	0	0	11.6
2014	9	29	2	18	19	34	0	0	0	0	0	0	0	57.61	0	0	11.6
2014	9	29	2	28	19	34	0	0	0	0	0	0	0	57.58	0	0	11.6
2014	9	29	2	38	19	34	0	0	0	0	0	0	0	57.54	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	2	48	19	34	0	0	0	0	0	0	0	57.51	0	0	11.6
2014	9	29	2	58	19	33	0	0	0	0	0	0	0	57.47	0	0	11.6
2014	9	29	3	8	19	34	0	0	0	0	0	0	0	57.43	0	0	11.6
2014	9	29	3	18	19	34	0	0	0	0	0	0	0	57.38	0	0	11.6
2014	9	29	3	28	19	34	0	0	0	0	0	0	0	57.34	0	0	11.6
2014	9	29	3	38	19	34	0	0	0	0	0	0	0	57.31	0	0	11.6
2014	9	29	3	48	19	35	0	0	0	0	0	0	0	57.27	0	0	11.6
2014	9	29	3	58	19	34	0	0	0	0	0	0	0	57.24	0	0	11.6
2014	9	29	4	8	19	35	0	0	0	0	0	0	0	57.2	0	0	11.6
2014	9	29	4	18	19	35	0	0	0	0	0	0	0	57.16	0	0	11.6
2014	9	29	4	28	19	35	0	0	0	0	0	0	0	57.11	0	0	11.6
2014	9	29	4	38	19	34	0	0	0	0	0	0	0	57.09	0	0	11.6
2014	9	29	4	48	19	34	0	0	0	0	0	0	0	57.04	0	0	11.6
2014	9	29	4	58	19	34	0	0	0	0	0	0	0	57.02	0	0	11.6
2014	9	29	5	8	19	34	0	0	0	0	0	0	0	56.98	0	0	11.6
2014	9	29	5	18	19	34	0	0	0	0	0	0	0	56.95	0	0	11.6
2014	9	29	5	28	19	35	0	0	0	0	0	0	0	56.93	0	0	11.6
2014	9	29	5	38	19	34	0	0	0	0	0	0	0	56.89	0	0	11.6
2014	9	29	5	48	19	34	0	0	0	0	0	0	0	56.86	0	0	11.6
2014	9	29	5	58	19	34	0	0	0	0	0	0	0	56.82	0	0	11.6
2014	9	29	6	8	19	34	0	0	0	0	0	0	0	56.82	0	0	11.6
2014	9	29	6	18	19	34	0	0	0	0	0	0	0	56.79	0	0	11.6
2014	9	29	6	28	19	34	0	0	0	0	0	0	0	56.75	0	0	11.6
2014	9	29	6	38	19	34	0	0	0	0	0	0	0	56.73	0	0	11.6
2014	9	29	6	48	19	34	0	0	0	0	0	0	0	56.71	0	0	11.6
2014	9	29	6	58	19	34	0	0	0	0	0	0	0	56.68	0	0	11.6
2014	9	29	7	8	19	35	0	0	0	0	0	0	0	56.66	0	0	11.6
2014	9	29	7	18	19	34	0	0	0	0	0	0	0	56.64	0	0	11.6
2014	9	29	7	28	19	34	0	0	0	0	0	0	0	56.61	0	0	11.6
2014	9	29	7	38	19	34	0	0	0	0	0	0	0	56.59	0	0	11.8
2014	9	29	7	48	19	34	0	0	0	0	0	0	0	56.57	0	0	12.2
2014	9	29	7	58	19	34	0	0	0	0	0	0	0	56.55	0	0	12.4
2014	9	29	8	8	19	34	0	0	0	0	0	0	0	56.55	0	0	12.6
2014	9	29	8	18	19	34	0	0	0	0	0	0	0	56.52	0	0	12.6
2014	9	29	8	28	19	34	0	0	0	0	0	0	0	56.52	0	0	13.2
2014	9	29	8	38	19	34	0	0	0	0	0	0	0	56.52	0	0	13.4
2014	9	29	8	48	19	34	0	0	0	0	0	0	0	56.61	0	0	13.2
2014	9	29	8	58	19	35	0	0	0	0	0	0	0	56.64	0	0	13.2
2014	9	29	9	8	19	34	0	0	0	0	0	0	0	56.66	0	0	13.2
2014	9	29	9	18	19	34	0	0	0	0	0	0	0	56.7	0	0	13.2
2014	9	29	9	28	19	34	0	0	0	0	0	0	0	56.73	0	0	13.4
2014	9	29	9	38	19	34	0	0	0	0	0	0	0	56.77	0	0	14
2014	9	29	9	48	19	35	0	0	0	0	0	0	0	56.8	0	0	13.8
2014	9	29	9	58	19	34	0	0	0	0	0	0	0	56.84	0	0	14
2014	9	29	10	8	19	34	0	0	0	0	0	0	0	56.88	0	0	14.2
2014	9	29	10	18	19	35	0	0	0	0	0	0	0	56.93	0	0	14.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	10	28	19	34	0	0	0	0	0	0	0	56.97	0	0	14.2
2014	9	29	10	38	19	34	0	0	0	0	0	0	0	57.02	0	0	14
2014	9	29	10	48	19	35	0	0	0	0	0	0	0	57.07	0	0	13.8
2014	9	29	10	58	19	34	0	0	0	0	0	0	0	57.13	0	0	13.8
2014	9	29	11	8	19	34	0	0	0	0	0	0	0	57.16	0	0	13.8
2014	9	29	11	18	19	34	0	0	0	0	0	0	0	57.24	0	0	13.8
2014	9	29	11	28	19	34	0	0	0	0	0	0	0	57.27	0	0	13.8
2014	9	29	11	38	19	35	0	0	0	0	0	0	0	57.34	0	0	13.8
2014	9	29	11	48	19	34	0	0	0	0	0	0	0	57.38	0	0	13.8
2014	9	29	11	58	19	34	0	0	0	0	0	0	0	57.43	0	0	13.8
2014	9	29	12	8	19	34	0	0	0	0	0	0	0	57.49	0	0	14.2
2014	9	29	12	18	19	34	0	0	0	0	0	0	0	57.54	0	0	14.2
2014	9	29	12	28	19	34	0	0	0	0	0	0	0	57.58	0	0	14
2014	9	29	12	38	19	34	0	0	0	0	0	0	0	57.63	0	0	14.2
2014	9	29	12	48	19	34	0	0	0	0	0	0	0	57.69	0	0	14
2014	9	29	12	58	19	34	0	0	0	0	0	0	0	57.72	0	0	14
2014	9	29	13	8	19	34	0	0	0	0	0	0	0	57.79	0	0	13.8
2014	9	29	13	18	19	34	0	0	0	0	0	0	0	57.83	0	0	14
2014	9	29	13	28	19	34	0	0	0	0	0	0	0	57.88	0	0	14
2014	9	29	13	38	19	34	0	0	0	0	0	0	0	57.92	0	0	14
2014	9	29	13	48	19	35	0	0	0	0	0	0	0	57.94	0	0	14
2014	9	29	13	58	19	34	0	0	0	0	0	0	0	57.97	0	0	13.8
2014	9	29	14	8	19	34	0	0	0	0	0	0	0	57.99	0	0	13.8
2014	9	29	14	18	19	34	0	0	0	0	0	0	0	58.03	0	0	13.6
2014	9	29	14	28	19	34	0	0	0	0	0	0	0	58.03	0	0	13.4
2014	9	29	14	38	19	34	0	0	0	0	0	0	0	58.06	0	0	13.4
2014	9	29	14	48	19	34	0	0	0	0	0	0	0	58.06	0	0	13.4
2014	9	29	14	58	19	34	0	0	0	0	0	0	0	58.06	0	0	13.4
2014	9	29	15	8	19	34	0	0	0	0	0	0	0	58.1	0	0	13.4
2014	9	29	15	18	19	34	0	0	0	0	0	0	0	58.12	0	0	13.4
2014	9	29	15	28	19	34	0	0	0	0	0	0	0	58.12	0	0	13.2
2014	9	29	15	38	19	34	0	0	0	0	0	0	0	58.14	0	0	13.2
2014	9	29	15	48	19	34	0	0	0	0	0	0	0	58.14	0	0	13.2
2014	9	29	15	58	19	34	0	0	0	0	0	0	0	58.14	0	0	13.2
2014	9	29	16	8	19	34	0	0	0	0	0	0	0	58.14	0	0	13.2
2014	9	29	16	18	19	35	0	0	0	0	0	0	0	58.12	0	0	13.2
2014	9	29	16	28	19	34	0	0	0	0	0	0	0	58.08	0	0	13.2
2014	9	29	16	38	19	34	0	0	0	0	0	0	0	58.14	0	0	13.2
2014	9	29	16	48	19	34	0	0	0	0	0	0	0	58.14	0	0	13
2014	9	29	16	58	19	35	0	0	0	0	0	0	0	58.14	0	0	12.8
2014	9	29	17	8	19	34	0	0	0	0	0	0	0	58.12	0	0	12.4
2014	9	29	17	18	19	34	0	0	0	0	0	0	0	58.1	0	0	12.2
2014	9	29	17	28	19	34	0	0	0	0	0	0	0	58.1	0	0	12.2
2014	9	29	17	38	19	34	0	0	0	0	0	0	0	58.1	0	0	12
2014	9	29	17	48	19	34	0	0	0	0	0	0	0	58.12	0	0	11.8
2014	9	29	17	58	19	33	0	0	0	0	0	0	0	58.12	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	29	18	8	19	34	0	0	0	0	0	0	0	58.12	0	0	11.8
2014	9	29	18	18	19	34	0	0	0	0	0	0	0	58.12	0	0	11.8
2014	9	29	18	28	19	34	0	0	0	0	0	0	0	58.12	0	0	11.8
2014	9	29	18	38	19	34	0	0	0	0	0	0	0	58.12	0	0	11.8
2014	9	29	18	48	19	34	0	0	0	0	0	0	0	58.1	0	0	11.8
2014	9	29	18	58	19	34	0	0	0	0	0	0	0	58.08	0	0	11.8
2014	9	29	19	8	19	35	0	0	0	0	0	0	0	58.08	0	0	11.8
2014	9	29	19	18	19	34	0	0	0	0	0	0	0	58.06	0	0	11.8
2014	9	29	19	28	19	34	0	0	0	0	0	0	0	58.05	0	0	11.8
2014	9	29	19	38	19	34	0	0	0	0	0	0	0	58.03	0	0	11.8
2014	9	29	19	48	19	33	0	0	0	0	0	0	0	58.01	0	0	11.8
2014	9	29	19	58	19	34	0	0	0	0	0	0	0	57.99	0	0	11.8
2014	9	29	20	8	19	34	0	0	0	0	0	0	0	57.97	0	0	11.8
2014	9	29	20	18	19	34	0	0	0	0	0	0	0	57.94	0	0	11.8
2014	9	29	20	28	19	34	0	0	0	0	0	0	0	57.92	0	0	11.8
2014	9	29	20	38	19	34	0	0	0	0	0	0	0	57.88	0	0	11.8
2014	9	29	20	48	19	34	0	0	0	0	0	0	0	57.83	0	0	11.8
2014	9	29	20	58	19	34	0	0	0	0	0	0	0	57.81	0	0	11.8
2014	9	29	21	8	19	34	0	0	0	0	0	0	0	57.78	0	0	11.8
2014	9	29	21	18	19	34	0	0	0	0	0	0	0	57.74	0	0	11.6
2014	9	29	21	28	19	34	0	0	0	0	0	0	0	57.7	0	0	11.6
2014	9	29	21	38	19	34	0	0	0	0	0	0	0	57.67	0	0	11.6
2014	9	29	21	48	19	34	0	0	0	0	0	0	0	57.63	0	0	11.6
2014	9	29	21	58	19	33	0	0	0	0	0	0	0	57.6	0	0	11.6
2014	9	29	22	8	19	34	0	0	0	0	0	0	0	57.56	0	0	11.6
2014	9	29	22	18	19	34	0	0	0	0	0	0	0	57.51	0	0	11.6
2014	9	29	22	28	19	35	0	0	0	0	0	0	0	57.47	0	0	11.6
2014	9	29	22	38	19	34	0	0	0	0	0	0	0	57.45	0	0	11.6
2014	9	29	22	48	19	34	0	0	0	0	0	0	0	57.42	0	0	11.6
2014	9	29	22	58	19	34	0	0	0	0	0	0	0	57.38	0	0	11.6
2014	9	29	23	8	19	34	0	0	0	0	0	0	0	57.34	0	0	11.6
2014	9	29	23	18	19	34	0	0	0	0	0	0	0	57.31	0	0	11.6
2014	9	29	23	28	19	34	0	0	0	0	0	0	0	57.27	0	0	11.6
2014	9	29	23	38	19	34	0	0	0	0	0	0	0	57.24	0	0	11.6
2014	9	29	23	48	19	34	0	0	0	0	0	0	0	57.2	0	0	11.6
2014	9	29	23	58	19	34	0	0	0	0	0	0	0	57.16	0	0	11.6
2014	9	30	0	8	19	34	0	0	0	0	0	0	0	57.13	0	0	11.6
2014	9	30	0	18	19	34	0	0	0	0	0	0	0	57.07	0	0	11.6
2014	9	30	0	28	19	34	0	0	0	0	0	0	0	57.04	0	0	11.6
2014	9	30	0	38	19	34	0	0	0	0	0	0	0	57	0	0	11.6
2014	9	30	0	48	19	34	0	0	0	0	0	0	0	56.95	0	0	11.6
2014	9	30	0	58	19	35	0	0	0	0	0	0	0	56.93	0	0	11.6
2014	9	30	1	8	19	34	0	0	0	0	0	0	0	56.89	0	0	11.6
2014	9	30	1	18	19	34	0	0	0	0	0	0	0	56.86	0	0	11.6
2014	9	30	1	28	19	33	0	0	0	0	0	0	0	56.8	0	0	11.6
2014	9	30	1	38	19	35	0	0	0	0	0	0	0	56.77	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	1	48	19	34	0	0	0	0	0	0	0	56.73	0	0	11.6
2014	9	30	1	58	19	34	0	0	0	0	0	0	0	56.7	0	0	11.6
2014	9	30	2	8	19	34	0	0	0	0	0	0	0	56.64	0	0	11.6
2014	9	30	2	18	19	35	0	0	0	0	0	0	0	56.61	0	0	11.6
2014	9	30	2	28	19	34	0	0	0	0	0	0	0	56.55	0	0	11.6
2014	9	30	2	38	19	34	0	0	0	0	0	0	0	56.52	0	0	11.6
2014	9	30	2	48	19	34	0	0	0	0	0	0	0	56.48	0	0	11.6
2014	9	30	2	58	19	34	0	0	0	0	0	0	0	56.43	0	0	11.6
2014	9	30	3	8	19	34	0	0	0	0	0	0	0	56.39	0	0	11.6
2014	9	30	3	18	19	34	0	0	0	0	0	0	0	56.35	0	0	11.6
2014	9	30	3	28	19	35	0	0	0	0	0	0	0	56.32	0	0	11.6
2014	9	30	3	38	19	34	0	0	0	0	0	0	0	56.26	0	0	11.6
2014	9	30	3	48	19	35	0	0	0	0	0	0	0	56.23	0	0	11.6
2014	9	30	3	58	19	34	0	0	0	0	0	0	0	56.19	0	0	11.6
2014	9	30	4	8	19	34	0	0	0	0	0	0	0	56.14	0	0	11.6
2014	9	30	4	18	19	35	0	0	0	0	0	0	0	56.1	0	0	11.6
2014	9	30	4	28	19	34	0	0	0	0	0	0	0	56.07	0	0	11.6
2014	9	30	4	38	19	34	0	0	0	0	0	0	0	56.03	0	0	11.4
2014	9	30	4	48	19	35	0	0	0	0	0	0	0	55.98	0	0	11.4
2014	9	30	4	58	19	34	0	0	0	0	0	0	0	55.94	0	0	11.4
2014	9	30	5	8	19	35	0	0	0	0	0	0	0	55.9	0	0	11.2
2014	9	30	5	18	19	34	0	0	0	0	0	0	0	55.85	0	0	11.6
2014	9	30	5	28	19	34	0	0	0	0	0	0	0	55.81	0	0	11.6
2014	9	30	5	38	19	35	0	0	0	0	0	0	0	55.76	0	0	11.6
2014	9	30	5	48	19	34	0	0	0	0	0	0	0	55.72	0	0	11.6
2014	9	30	5	58	19	34	0	0	0	0	0	0	0	55.69	0	0	11.6
2014	9	30	6	8	19	35	0	0	0	0	0	0	0	55.63	0	0	11.6
2014	9	30	6	18	19	34	0	0	0	0	0	0	0	55.6	0	0	11.4
2014	9	30	6	28	19	34	0	0	0	0	0	0	0	55.56	0	0	11.4
2014	9	30	6	38	19	34	0	0	0	0	0	0	0	55.51	0	0	11.4
2014	9	30	6	48	19	34	0	0	0	0	0	0	0	55.49	0	0	11.4
2014	9	30	6	58	19	34	0	0	0	0	0	0	0	55.44	0	0	11.6
2014	9	30	7	8	19	35	0	0	0	0	0	0	0	55.42	0	0	11.6
2014	9	30	7	18	19	34	0	0	0	0	0	0	0	55.38	0	0	11.6
2014	9	30	7	28	19	34	0	0	0	0	0	0	0	55.35	0	0	11.6
2014	9	30	7	38	19	35	0	0	0	0	0	0	0	55.31	0	0	11.8
2014	9	30	7	48	19	34	0	0	0	0	0	0	0	55.29	0	0	12.2
2014	9	30	7	58	19	34	0	0	0	0	0	0	0	55.27	0	0	12.4
2014	9	30	8	8	19	35	0	0	0	0	0	0	0	55.27	0	0	12.6
2014	9	30	8	18	19	34	0	0	0	0	0	0	0	55.26	0	0	12.8
2014	9	30	8	28	19	35	0	0	0	0	0	0	0	55.24	0	0	13
2014	9	30	8	38	19	35	0	0	0	0	0	0	0	55.27	0	0	13
2014	9	30	8	48	19	35	0	0	0	0	0	0	0	55.36	0	0	13
2014	9	30	8	58	19	34	0	0	0	0	0	0	0	55.42	0	0	13
2014	9	30	9	8	19	34	0	0	0	0	0	0	0	55.45	0	0	13.2
2014	9	30	9	18	19	35	0	0	0	0	0	0	0	55.51	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	9	28	19	35	0	0	0	0	0	0	0	55.54	0	0	13.2
2014	9	30	9	38	19	34	0	0	0	0	0	0	0	55.6	0	0	13.4
2014	9	30	9	48	19	35	0	0	0	0	0	0	0	55.65	0	0	13.4
2014	9	30	9	58	19	35	0	0	0	0	0	0	0	55.71	0	0	13.4
2014	9	30	10	8	19	35	0	0	0	0	0	0	0	55.76	0	0	13.6
2014	9	30	10	18	19	34	0	0	0	0	0	0	0	55.83	0	0	13.6
2014	9	30	10	28	19	34	0	0	0	0	0	0	0	55.9	0	0	13.6
2014	9	30	10	38	19	34	0	0	0	0	0	0	0	55.96	0	0	13.6
2014	9	30	10	48	19	35	0	0	0	0	0	0	0	56.01	0	0	13.6
2014	9	30	10	58	19	35	0	0	0	0	0	0	0	56.08	0	0	13.6
2014	9	30	11	8	19	34	0	0	0	0	0	0	0	56.14	0	0	13.6
2014	9	30	11	18	19	34	0	0	0	0	0	0	0	56.21	0	0	13.6
2014	9	30	11	28	19	34	0	0	0	0	0	0	0	56.28	0	0	13.6
2014	9	30	11	38	19	35	0	0	0	0	0	0	0	56.35	0	0	13.4
2014	9	30	11	48	19	34	0	0	0	0	0	0	0	56.41	0	0	13.4
2014	9	30	11	58	19	35	0	0	0	0	0	0	0	56.46	0	0	13.4
2014	9	30	12	8	19	34	0	0	0	0	0	0	0	56.52	0	0	13.4
2014	9	30	12	18	19	34	0	0	0	0	0	0	0	56.57	0	0	13.4
2014	9	30	12	28	19	35	0	0	0	0	0	0	0	56.64	0	0	13.4
2014	9	30	12	38	19	35	0	0	0	0	0	0	0	56.66	0	0	13.4
2014	9	30	12	48	19	34	0	0	0	0	0	0	0	56.82	0	0	13.4
2014	9	30	12	58	19	34	0	0	0	0	0	0	0	56.86	0	0	13.4
2014	9	30	13	8	19	34	0	0	0	0	0	0	0	56.93	0	0	13.4
2014	9	30	13	18	19	35	0	0	0	0	0	0	0	56.95	0	0	13.4
2014	9	30	13	28	19	34	0	0	0	0	0	0	0	56.97	0	0	13.4
2014	9	30	13	38	19	35	0	0	0	0	0	0	0	57	0	0	13.4
2014	9	30	13	48	19	34	0	0	0	0	0	0	0	57.06	0	0	13.4
2014	9	30	13	58	19	34	0	0	0	0	0	0	0	57.11	0	0	13.4
2014	9	30	14	8	19	35	0	0	0	0	0	0	0	57.11	0	0	13.4
2014	9	30	14	18	19	34	0	0	0	0	0	0	0	57.15	0	0	13.4
2014	9	30	14	28	19	34	0	0	0	0	0	0	0	57.16	0	0	13.4
2014	9	30	14	38	19	34	0	0	0	0	0	0	0	57.2	0	0	13.4
2014	9	30	14	48	19	34	0	0	0	0	0	0	0	57.2	0	0	13.4
2014	9	30	14	58	19	34	0	0	0	0	0	0	0	57.22	0	0	13.4
2014	9	30	15	8	19	34	0	0	0	0	0	0	0	57.24	0	0	13.4
2014	9	30	15	18	19	34	0	0	0	0	0	0	0	57.25	0	0	13.4
2014	9	30	15	28	19	34	0	0	0	0	0	0	0	57.25	0	0	13.4
2014	9	30	15	38	19	34	0	0	0	0	0	0	0	57.27	0	0	13.4
2014	9	30	15	48	19	34	0	0	0	0	0	0	0	57.27	0	0	13.4
2014	9	30	15	58	19	35	0	0	0	0	0	0	0	57.29	0	0	13.4
2014	9	30	16	8	19	34	0	0	0	0	0	0	0	57.27	0	0	13.4
2014	9	30	16	18	19	34	0	0	0	0	0	0	0	57.27	0	0	13.4
2014	9	30	16	28	19	34	0	0	0	0	0	0	0	57.2	0	0	13.2
2014	9	30	16	38	19	35	0	0	0	0	0	0	0	57.27	0	0	13
2014	9	30	16	48	19	34	0	0	0	0	0	0	0	57.29	0	0	12.8
2014	9	30	16	58	19	33	0	0	0	0	0	0	0	57.29	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	9	30	17	8	19	35	0	0	0	0	0	0	0	57.25	0	0	12.6
2014	9	30	17	18	19	34	0	0	0	0	0	0	0	57.24	0	0	12.4
2014	9	30	17	28	19	34	0	0	0	0	0	0	0	57.25	0	0	12.2
2014	9	30	17	38	19	34	0	0	0	0	0	0	0	57.27	0	0	12
2014	9	30	17	48	19	34	0	0	0	0	0	0	0	57.27	0	0	12
2014	9	30	17	58	19	34	0	0	0	0	0	0	0	57.27	0	0	11.8
2014	9	30	18	8	19	34	0	0	0	0	0	0	0	57.29	0	0	11.8
2014	9	30	18	18	19	35	0	0	0	0	0	0	0	57.29	0	0	11.8
2014	9	30	18	28	19	35	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	30	18	38	19	35	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	30	18	48	19	34	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	30	18	58	19	34	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	30	19	8	19	34	0	0	0	0	0	0	0	57.31	0	0	11.8
2014	9	30	19	18	19	34	0	0	0	0	0	0	0	57.29	0	0	11.8
2014	9	30	19	28	19	34	0	0	0	0	0	0	0	57.29	0	0	11.8
2014	9	30	19	38	19	34	0	0	0	0	0	0	0	57.27	0	0	11.8
2014	9	30	19	48	19	35	0	0	0	0	0	0	0	57.27	0	0	11.8
2014	9	30	19	58	19	34	0	0	0	0	0	0	0	57.24	0	0	11.8
2014	9	30	20	8	19	34	0	0	0	0	0	0	0	57.24	0	0	11.8
2014	9	30	20	18	19	34	0	0	0	0	0	0	0	57.22	0	0	11.8
2014	9	30	20	28	19	34	0	0	0	0	0	0	0	57.2	0	0	11.8
2014	9	30	20	38	19	34	0	0	0	0	0	0	0	57.16	0	0	11.8
2014	9	30	20	48	19	34	0	0	0	0	0	0	0	57.15	0	0	11.8
2014	9	30	20	58	19	34	0	0	0	0	0	0	0	57.13	0	0	11.8
2014	9	30	21	8	19	34	0	0	0	0	0	0	0	57.09	0	0	11.8
2014	9	30	21	18	19	34	0	0	0	0	0	0	0	57.07	0	0	11.8
2014	9	30	21	28	19	34	0	0	0	0	0	0	0	57.04	0	0	11.8
2014	9	30	21	38	19	34	0	0	0	0	0	0	0	57	0	0	11.8
2014	9	30	21	48	19	34	0	0	0	0	0	0	0	56.98	0	0	11.8
2014	9	30	21	58	19	34	0	0	0	0	0	0	0	56.95	0	0	11.8
2014	9	30	22	8	19	34	0	0	0	0	0	0	0	56.91	0	0	11.8
2014	9	30	22	18	19	34	0	0	0	0	0	0	0	56.89	0	0	11.8
2014	9	30	22	28	19	34	0	0	0	0	0	0	0	56.86	0	0	11.8
2014	9	30	22	38	19	34	0	0	0	0	0	0	0	56.84	0	0	11.8
2014	9	30	22	48	19	34	0	0	0	0	0	0	0	56.8	0	0	11.8
2014	9	30	22	58	19	34	0	0	0	0	0	0	0	56.79	0	0	11.8
2014	9	30	23	8	19	34	0	0	0	0	0	0	0	56.75	0	0	11.8
2014	9	30	23	18	19	34	0	0	0	0	0	0	0	56.71	0	0	11.6
2014	9	30	23	28	19	34	0	0	0	0	0	0	0	56.7	0	0	11.6
2014	9	30	23	38	19	35	0	0	0	0	0	0	0	56.66	0	0	11.6
2014	9	30	23	48	19	34	0	0	0	0	0	0	0	56.64	0	0	11.6
2014	9	30	23	58	19	34	0	0	0	0	0	0	0	56.62	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	0	0	41	0.3	3.6	0.82	96.6	82.3753	63.9665
2014	9	1	0	10	41	0.3	3.6	0.77	95.9	82.3753	60.1131
2014	9	1	0	20	41	0.3	3.6	0.78	94.8	82.3753	61.1407
2014	9	1	0	30	41	0.3	3.6	0.78	95.6	82.3753	60.627
2014	9	1	0	40	41	0.3	3.6	0.82	95.3	82.3753	63.9666
2014	9	1	0	50	41	0.3	3.6	0.77	94.2	82.3753	59.8563
2014	9	1	1	0	41	0.3	3.6	0.78	95.1	82.3753	60.8839
2014	9	1	1	10	41	0.3	3.6	0.8	96.2	82.3753	61.9115
2014	9	1	1	20	41	0.3	3.6	0.79	94.3	82.3753	61.9115
2014	9	1	1	30	41	0.3	3.6	0.83	96.1	82.3753	64.4805
2014	9	1	1	40	41	0.3	3.6	0.78	96.1	82.3753	60.3702
2014	9	1	1	50	41	0.3	3.6	0.78	94.3	82.3753	60.884
2014	9	1	2	0	41	0.3	3.6	0.78	94.8	82.3753	61.1409
2014	9	1	2	10	41	0.3	3.6	0.77	96.3	82.3753	60.1133
2014	9	1	2	20	41	0.3	3.6	0.81	95.6	82.3097	62.8868
2014	9	1	2	30	41	0.3	3.6	0.78	95.8	82.3097	61.0901
2014	9	1	2	40	41	0.3	3.6	0.81	95.6	82.3753	62.9393
2014	9	1	2	50	41	0.3	3.6	0.78	97.5	82.3753	60.8841
2014	9	1	3	0	41	0.3	3.6	0.81	94.9	82.3097	63.1436
2014	9	1	3	10	41	0.3	3.6	0.79	94.5	82.3753	61.3979
2014	9	1	3	20	41	0.3	3.6	0.8	95.4	82.3753	62.1687
2014	9	1	3	30	41	0.3	3.6	0.87	95.2	82.3097	68.0206
2014	9	1	3	40	41	0.3	3.6	0.82	95.5	82.3753	63.967
2014	9	1	3	50	41	0.3	3.6	0.79	95.2	82.3097	61.8603
2014	9	1	4	0	41	0.3	3.6	0.79	95.5	82.3097	61.6037
2014	9	1	4	10	41	0.3	3.6	0.79	97.4	82.3097	61.6037
2014	9	1	4	20	41	0.3	3.6	0.78	94.4	82.3097	60.577
2014	9	1	4	30	41	0.3	3.6	0.8	93.8	82.3097	62.6304
2014	9	1	4	40	41	0.3	3.6	0.78	95.1	82.3097	60.577
2014	9	1	4	50	41	0.3	3.6	0.76	96.4	82.3097	59.0369
2014	9	1	5	0	41	0.3	3.6	0.79	95.5	82.3097	61.8605
2014	9	1	5	10	41	0.3	3.6	0.8	95.4	82.3097	62.6305
2014	9	1	5	20	41	0.3	3.6	0.84	98.8	82.3097	64.684
2014	9	1	5	30	41	0.3	3.6	0.82	98	82.3097	63.6573
2014	9	1	5	40	41	0.3	3.6	0.78	96.5	82.3097	60.5771
2014	9	1	5	50	41	0.3	3.6	0.8	96.6	82.3097	62.1173
2014	9	1	6	0	41	0.3	3.6	0.81	95.6	82.3097	62.8873
2014	9	1	6	10	41	0.3	3.6	0.84	96.9	82.3097	65.4542
2014	9	1	6	20	41	0.3	3.6	0.81	96.5	82.3097	63.1441
2014	9	1	6	30	41	0.3	3.6	0.8	96.4	82.3097	61.8606
2014	9	1	6	40	41	0.3	3.6	0.78	96.7	82.3097	60.8339
2014	9	1	6	50	41	0.3	3.6	0.82	95.3	82.3097	63.9142
2014	9	1	7	0	41	0.3	3.6	0.8	97	82.3097	62.3741
2014	9	1	7	10	41	0.3	3.6	0.83	96.8	82.2441	64.3739
2014	9	1	7	20	41	0.3	3.6	0.79	98.3	82.2441	61.2963
2014	9	1	7	30	41	0.3	3.6	0.78	95.8	82.3097	60.3206

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	7	40	41	0.3	3.6	0.81	95.8	82.2441	63.0916
2014	9	1	7	50	41	0.3	3.6	0.79	95.2	82.2441	61.8092
2014	9	1	8	0	41	0.3	3.6	0.77	95.4	82.2441	59.7575
2014	9	1	8	10	41	0.3	3.6	0.8	96.6	82.2441	62.0657
2014	9	1	8	20	41	0.3	3.6	0.82	95.9	82.2441	64.1175
2014	9	1	8	30	41	0.3	3.6	0.77	96.8	82.3097	60.0639
2014	9	1	8	40	41	0.3	3.6	0.8	95.9	82.3097	62.6307
2014	9	1	8	50	41	0.3	3.6	0.79	95.3	82.2441	61.2962
2014	9	1	9	0	41	0.3	3.6	0.81	96.5	82.2441	63.0915
2014	9	1	9	10	41	0.3	3.6	0.81	94.9	82.2441	63.3479
2014	9	1	9	20	41	0.3	3.6	0.81	96.1	82.2441	62.5785
2014	9	1	9	30	41	0.3	3.6	0.82	95.7	82.2441	63.8608
2014	9	1	9	40	41	0.3	3.6	0.81	96.3	82.2441	63.0914
2014	9	1	9	50	41	0.3	3.6	0.82	98.7	82.2441	63.3478
2014	9	1	10	0	41	0.3	3.6	0.8	96.6	82.2441	61.809
2014	9	1	10	10	41	0.3	3.6	0.8	96.6	82.2441	62.0654
2014	9	1	10	20	41	0.3	3.6	0.81	96.8	82.2441	62.5783
2014	9	1	10	30	41	0.3	3.6	0.79	96.9	82.2441	61.2959
2014	9	1	10	40	41	0.3	3.6	0.79	96.4	82.2441	61.5524
2014	9	1	10	50	41	0.3	3.6	0.79	94.8	82.2441	61.5524
2014	9	1	11	0	41	0.3	3.6	0.79	96.2	82.2441	61.2958
2014	9	1	11	10	41	0.3	3.6	0.83	96.1	82.2441	64.3734
2014	9	1	11	20	41	0.3	3.6	0.81	96.1	82.1785	62.5259
2014	9	1	11	30	41	0.3	3.6	0.79	96.9	82.1785	60.9884
2014	9	1	11	40	41	0.3	3.6	0.81	95.1	82.1785	63.0384
2014	9	1	11	50	41	0.3	3.6	0.79	98.1	82.1129	61.1935
2014	9	1	12	0	41	0.3	3.6	0.81	96.5	82.1129	62.9858
2014	9	1	12	10	41	0.3	3.6	0.8	98.3	81.9816	61.6025
2014	9	1	12	20	41	0.3	3.6	0.8	93.3	81.9816	61.8581
2014	9	1	12	30	41	0.3	3.6	0.79	95.2	81.9816	61.3468
2014	9	1	12	40	41	0.3	3.6	0.83	95.9	81.9816	64.1585
2014	9	1	12	50	41	0.3	3.6	0.76	95.7	81.916	58.9969
2014	9	1	13	0	41	0.3	3.6	0.77	97.4	81.916	59.2523
2014	9	1	13	10	41	0.3	3.6	0.8	96.8	81.916	61.8062
2014	9	1	13	20	41	0.3	3.6	0.79	96.9	81.9816	60.8355
2014	9	1	13	30	41	0.3	3.6	0.79	95.7	81.916	61.2954
2014	9	1	13	40	41	0.3	3.6	0.77	96.2	81.916	59.2522
2014	9	1	13	50	41	0.3	3.6	0.79	97.9	81.8504	60.4785
2014	9	1	14	0	41	0.3	3.6	0.77	97.6	81.8504	59.2025
2014	9	1	14	10	41	0.3	3.6	0.83	95.4	81.8504	64.3062
2014	9	1	14	20	41	0.3	3.6	0.79	97.2	81.8504	60.7336
2014	9	1	14	30	41	0.3	3.6	0.76	95.7	81.8504	58.4369
2014	9	1	14	40	41	0.3	3.6	0.79	96.7	81.8504	61.2439
2014	9	1	14	50	41	0.3	3.6	0.77	96.9	81.8504	59.4576
2014	9	1	15	0	41	0.3	3.6	0.81	96.8	81.7848	62.2125
2014	9	1	15	10	41	0.3	3.6	0.79	94.5	81.7848	61.4476

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	15	20	41	0.3	3.6	0.75	96.3	81.7848	58.133
2014	9	1	15	30	41	0.3	3.6	0.78	98	81.7848	59.6628
2014	9	1	15	40	41	0.3	3.6	0.74	94.8	81.7848	57.368
2014	9	1	15	50	41	0.3	3.6	0.76	94.7	81.7848	59.1528
2014	9	1	16	0	41	0.3	3.6	0.8	97.8	81.7848	61.4475
2014	9	1	16	10	41	0.3	3.6	0.77	95.6	81.7192	59.358
2014	9	1	16	20	41	0.3	3.6	0.82	98.7	81.7192	62.9246
2014	9	1	16	30	41	0.3	3.6	0.79	95	81.7192	60.8865
2014	9	1	16	40	41	0.3	3.6	0.75	94.5	81.7192	58.0842
2014	9	1	16	50	41	0.3	3.6	0.77	95.3	81.6535	59.8173
2014	9	1	17	0	41	0.3	3.6	0.78	95.8	81.6535	59.8173
2014	9	1	17	10	41	0.3	3.6	0.79	98.1	81.7192	60.6318
2014	9	1	17	20	41	0.3	3.6	0.79	94.1	81.5879	61.0387
2014	9	1	17	30	41	0.3	3.6	0.79	97.1	81.5223	60.9874
2014	9	1	17	40	41	0.3	3.6	0.83	95.4	81.5223	64.2909
2014	9	1	17	50	41	0.3	3.6	0.82	96.9	81.5223	63.0203
2014	9	1	18	0	41	0.3	3.6	0.75	96	81.6535	57.7809
2014	9	1	18	10	41	0.3	3.6	0.77	96.6	81.6535	59.0536
2014	9	1	18	20	41	0.3	3.6	0.81	96.5	81.6535	62.6172
2014	9	1	18	30	41	0.3	3.6	0.77	96.4	81.7192	59.358
2014	9	1	18	40	41	0.3	3.6	0.75	96.3	81.7192	57.8294
2014	9	1	18	50	41	0.3	3.6	0.79	95	81.6535	60.8354
2014	9	1	19	0	41	0.3	3.6	0.79	97.9	81.6535	60.8354
2014	9	1	19	10	41	0.3	3.6	0.8	98.8	81.6535	61.09
2014	9	1	19	20	41	0.3	3.6	0.78	95.3	81.6535	60.3263
2014	9	1	19	30	41	0.3	3.6	0.78	97.7	81.6535	60.3263
2014	9	1	19	40	41	0.3	3.6	0.79	97.1	81.6535	61.09
2014	9	1	19	50	41	0.3	3.6	0.77	98.1	81.6535	58.7991
2014	9	1	20	0	41	0.3	3.6	0.8	97.5	81.6535	61.5991
2014	9	1	20	10	41	0.3	3.6	0.83	96.8	81.6535	63.6354
2014	9	1	20	20	41	0.3	3.6	0.8	98	81.6535	61.5991
2014	9	1	20	30	41	0.3	3.6	0.78	99.2	81.6535	59.5627
2014	9	1	20	40	41	0.3	3.6	0.75	97	81.6535	58.0355
2014	9	1	20	50	41	0.3	3.6	0.79	99.1	81.6535	60.5809
2014	9	1	21	0	41	0.3	3.6	0.85	96.7	81.6535	65.4172
2014	9	1	21	10	41	0.3	3.6	0.78	92.4	81.6535	60.3264
2014	9	1	21	20	41	0.3	3.6	0.78	94.1	81.6535	60.3264
2014	9	1	21	30	41	0.3	3.6	0.78	96.3	81.6535	60.0719
2014	9	1	21	40	41	0.3	3.6	0.8	95.6	81.6535	61.8537
2014	9	1	21	50	41	0.3	3.6	0.83	95.5	81.6535	63.89
2014	9	1	22	0	41	0.3	3.6	0.8	95.7	81.6535	61.5992
2014	9	1	22	10	41	0.3	3.6	0.75	95	81.6535	57.781
2014	9	1	22	20	41	0.3	3.6	0.76	95.2	81.6535	58.7992
2014	9	1	22	30	41	0.3	3.6	0.8	96.9	81.6535	61.3446
2014	9	1	22	40	41	0.3	3.6	0.81	96.5	81.6535	62.6174
2014	9	1	22	50	41	0.3	3.6	0.8	95.4	81.6535	61.5992

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	1	23	0	41	0.3	3.6	0.76	95.5	81.6535	58.5447
2014	9	1	23	10	41	0.3	3.6	0.79	95.7	81.6535	60.8356
2014	9	1	23	20	41	0.3	3.6	0.76	94.2	81.6535	59.0538
2014	9	1	23	30	41	0.3	3.6	0.8	95.7	81.6535	61.5993
2014	9	1	23	40	41	0.3	3.6	0.79	95.7	81.6535	61.0902
2014	9	1	23	50	41	0.3	3.6	0.77	95.9	81.6535	59.563
2014	9	2	0	0	41	0.3	3.6	0.8	95.6	81.6535	61.8539
2014	9	2	0	10	41	0.3	3.6	0.77	97.3	81.6535	59.3085
2014	9	2	0	20	41	0.3	3.6	0.82	93.9	81.6535	63.1266
2014	9	2	0	30	41	0.3	3.6	0.79	93.4	81.6535	60.8357
2014	9	2	0	40	41	0.3	3.6	0.78	93.4	81.6535	60.5812
2014	9	2	0	50	41	0.3	3.6	0.79	97.9	81.6535	60.5812
2014	9	2	1	0	41	0.3	3.6	0.79	95.7	81.6535	60.8358
2014	9	2	1	10	41	0.3	3.6	0.82	95.3	81.6535	63.3812
2014	9	2	1	20	41	0.3	3.6	0.82	96.2	81.6535	63.6358
2014	9	2	1	30	41	0.3	3.6	0.77	92.4	81.6535	59.8177
2014	9	2	1	40	41	0.3	3.6	0.78	98.2	81.6535	60.0722
2014	9	2	1	50	41	0.3	3.6	0.87	95.8	81.6535	67.1995
2014	9	2	2	0	41	0.3	3.6	0.78	94.3	81.6535	60.3268
2014	9	2	2	10	41	0.3	3.6	0.79	95.7	81.6535	61.345
2014	9	2	2	20	41	0.3	3.6	0.77	96.1	81.6535	59.3087
2014	9	2	2	30	41	0.3	3.6	0.78	97	81.6535	59.8178
2014	9	2	2	40	41	0.3	3.6	0.79	96.7	81.6535	61.0905
2014	9	2	2	50	41	0.3	3.6	0.8	94	81.6535	61.8542
2014	9	2	3	0	41	0.3	3.6	0.8	96.3	81.6535	61.8542
2014	9	2	3	10	41	0.3	3.6	0.82	95.8	81.6535	63.1269
2014	9	2	3	20	41	0.3	3.6	0.79	94.5	81.6535	61.3451
2014	9	2	3	30	41	0.3	3.6	0.79	97.2	81.6535	60.5815
2014	9	2	3	40	41	0.3	3.6	0.79	94.1	81.6535	61.0906
2014	9	2	3	50	41	0.3	3.6	0.79	96.9	81.6535	61.0907
2014	9	2	4	0	41	0.3	3.6	0.81	95.4	81.6535	62.3634
2014	9	2	4	10	41	0.3	3.6	0.77	95.6	81.6535	59.818
2014	9	2	4	20	41	0.3	3.6	0.82	95.8	81.6535	63.1271
2014	9	2	4	30	41	0.3	3.6	0.78	95.3	81.6535	60.0726
2014	9	2	4	40	41	0.3	3.6	0.8	94.5	81.6535	61.5999
2014	9	2	4	50	41	0.3	3.6	0.81	94.9	81.6535	62.3635
2014	9	2	5	0	41	0.3	3.6	0.78	96.3	81.6535	59.8181
2014	9	2	5	10	41	0.3	3.6	0.79	95.5	81.6535	61.0908
2014	9	2	5	20	41	0.3	3.6	0.81	96.1	81.6535	62.109
2014	9	2	5	30	41	0.3	3.6	0.82	96.5	81.6535	62.8727
2014	9	2	5	40	41	0.3	3.6	0.77	94.1	81.6535	59.8181
2014	9	2	5	50	41	0.3	3.6	0.82	95.8	81.6535	63.1273
2014	9	2	6	0	41	0.3	3.6	0.81	96.8	81.6535	62.1091
2014	9	2	6	10	41	0.3	3.6	0.81	97.5	81.5879	62.057
2014	9	2	6	20	41	0.3	3.6	0.84	96.7	81.6535	64.6546
2014	9	2	6	30	41	0.3	3.6	0.8	97.8	81.5879	61.294

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	6	40	41	0.3	3.6	0.77	95.6	81.5879	59.7681
2014	9	2	6	50	41	0.3	3.6	0.79	95.5	81.6535	60.8365
2014	9	2	7	0	41	0.3	3.6	0.81	97.7	81.5879	62.0571
2014	9	2	7	10	41	0.3	3.6	0.8	94.5	81.6535	62.1092
2014	9	2	7	20	41	0.3	3.6	0.81	96.5	81.6535	62.1092
2014	9	2	7	30	41	0.3	3.6	0.76	97	81.5879	58.2421
2014	9	2	7	40	41	0.3	3.6	0.76	96	81.6535	58.5456
2014	9	2	7	50	41	0.3	3.6	0.75	94.8	81.6535	58.0365
2014	9	2	8	0	41	0.3	3.6	0.75	96.8	81.6535	58.0365
2014	9	2	8	10	41	0.3	3.6	0.8	95.4	81.6535	61.8547
2014	9	2	8	20	41	0.3	3.6	0.82	95.3	81.6535	63.382
2014	9	2	8	30	41	0.3	3.6	0.79	97.4	81.6535	61.091
2014	9	2	8	40	41	0.3	3.6	0.76	95	81.6535	58.5456
2014	9	2	8	50	41	0.3	3.6	0.77	97.1	81.6535	59.5637
2014	9	2	9	0	41	0.3	3.6	0.8	94	81.6535	62.1092
2014	9	2	9	10	41	0.3	3.6	0.79	97.2	81.6535	60.8364
2014	9	2	9	20	41	0.3	3.6	0.79	95.9	81.6535	61.3455
2014	9	2	9	30	41	0.3	3.6	0.77	95.9	81.6535	59.3091
2014	9	2	9	40	41	0.3	3.6	0.83	95.7	81.6535	63.8909
2014	9	2	9	50	41	0.3	3.6	0.75	95	81.6535	57.7818
2014	9	2	10	0	41	0.3	3.6	0.76	96	81.6535	58.2909
2014	9	2	10	10	41	0.3	3.6	0.8	97.5	81.6535	61.8545
2014	9	2	10	20	41	0.3	3.6	0.8	96.8	81.6535	61.5999
2014	9	2	10	30	41	0.3	3.6	0.79	98.8	81.6535	60.8362
2014	9	2	10	40	41	0.3	3.6	0.81	97	81.6535	62.3635
2014	9	2	10	50	41	0.3	3.6	0.74	95.3	81.6535	57.5271
2014	9	2	11	0	41	0.3	3.6	0.78	95.5	81.5879	60.5307
2014	9	2	11	10	41	0.3	3.6	0.73	97.2	81.5879	56.2071
2014	9	2	11	20	41	0.3	3.6	0.75	95.3	81.5879	57.733
2014	9	2	11	30	41	0.3	3.6	0.76	97.2	81.5879	58.7503
2014	9	2	11	40	41	0.3	3.6	0.75	97.2	81.5879	57.9873
2014	9	2	11	50	41	0.3	3.6	0.75	96.1	81.5879	57.4786
2014	9	2	12	0	41	0.3	3.6	0.79	96.9	81.5223	60.7338
2014	9	2	12	10	41	0.3	3.6	0.75	93.8	81.5223	57.6844
2014	9	2	12	20	41	0.3	3.6	0.76	98.2	81.5223	57.9385
2014	9	2	12	30	41	0.3	3.6	0.77	98.4	81.4567	58.6514
2014	9	2	12	40	41	0.3	3.6	0.79	99.3	81.4567	60.6826
2014	9	2	12	50	41	0.3	3.6	0.79	96.5	81.4567	60.4287
2014	9	2	13	0	41	0.3	3.6	0.75	94.3	81.4567	57.6357
2014	9	2	13	10	41	0.3	3.6	0.8	93.8	81.3911	61.3925
2014	9	2	13	20	41	0.3	3.6	0.8	98	81.3911	61.1388
2014	9	2	13	30	41	0.3	3.6	0.77	96.6	81.3255	59.0595
2014	9	2	13	40	41	0.3	3.6	0.76	96	81.3255	58.0456
2014	9	2	13	50	41	0.3	3.6	0.77	97.1	81.3255	59.0594
2014	9	2	14	0	41	0.3	3.6	0.78	95.8	81.2598	59.7694
2014	9	2	14	10	41	0.3	3.6	0.77	96.4	81.1942	58.9598

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	14	20	41	0.3	3.6	0.76	95.7	81.1942	58.4537
2014	9	2	14	30	41	0.3	3.6	0.76	97.6	81.1942	58.4537
2014	9	2	14	40	41	0.3	3.6	0.77	99	81.1942	58.9598
2014	9	2	14	50	41	0.3	3.6	0.77	97.3	81.1942	58.9597
2014	9	2	15	0	41	0.3	3.6	0.76	97.9	81.1286	58.1515
2014	9	2	15	10	41	0.3	3.6	0.78	98.3	81.1286	59.1628
2014	9	2	15	20	41	0.3	3.6	0.78	99.5	81.1286	58.9099
2014	9	2	15	30	41	0.3	3.6	0.76	99.4	81.1286	57.8986
2014	9	2	15	40	41	0.3	3.6	0.77	96.4	81.063	58.8601
2014	9	2	15	50	41	0.3	3.6	0.72	98.6	81.063	55.0708
2014	9	2	16	0	41	0.3	3.6	0.77	97.1	81.063	58.8601
2014	9	2	16	10	41	0.3	3.6	0.75	96.5	81.063	57.597
2014	9	2	16	20	41	0.3	3.6	0.8	96.9	81.063	60.881
2014	9	2	16	30	41	0.3	3.6	0.78	97.8	81.063	59.3653
2014	9	2	16	40	41	0.3	3.6	0.8	97.3	81.063	61.3863
2014	9	2	16	50	41	0.3	3.6	0.74	95.4	81.063	56.5865
2014	9	2	17	0	41	0.3	3.6	0.78	98.2	81.063	59.3653
2014	9	2	17	10	41	0.3	3.6	0.75	98.8	81.063	57.3444
2014	9	2	17	20	41	0.3	3.6	0.72	96.8	81.063	55.3234
2014	9	2	17	30	41	0.3	3.6	0.78	95.8	80.9974	60.0723
2014	9	2	17	40	41	0.3	3.6	0.77	95.9	80.9974	58.8103
2014	9	2	17	50	41	0.3	3.6	0.78	95.5	80.9974	60.0723
2014	9	2	18	0	41	0.3	3.6	0.77	95.9	80.9974	59.0627
2014	9	2	18	10	41	0.3	3.6	0.77	96.4	80.9974	58.8103
2014	9	2	18	20	41	0.3	3.6	0.75	97.8	80.9974	57.0435
2014	9	2	18	30	41	0.3	3.6	0.82	94.8	80.9974	62.5964
2014	9	2	18	40	41	0.3	3.6	0.79	95.5	80.9974	60.3247
2014	9	2	18	50	41	0.3	3.6	0.73	95.4	81.063	55.8286
2014	9	2	19	0	41	0.3	3.6	0.78	95.8	80.9974	60.0723
2014	9	2	19	10	41	0.3	3.6	0.75	97.5	81.063	57.597
2014	9	2	19	20	41	0.3	3.6	0.75	94	81.063	57.8496
2014	9	2	19	30	41	0.3	3.6	0.74	96.1	80.9974	56.2862
2014	9	2	19	40	41	0.3	3.6	0.79	96.7	80.9974	60.3247
2014	9	2	19	50	41	0.3	3.6	0.76	97.4	81.063	58.1022
2014	9	2	20	0	41	0.3	3.6	0.76	95.9	81.063	58.3548
2014	9	2	20	10	41	0.3	3.6	0.77	98.3	81.063	58.8601
2014	9	2	20	20	41	0.3	3.6	0.77	94.6	81.063	59.1127
2014	9	2	20	30	41	0.3	3.6	0.81	98	81.063	61.3863
2014	9	2	20	40	41	0.3	3.6	0.78	93.6	81.063	59.6179
2014	9	2	20	50	41	0.3	3.6	0.76	98.2	80.9974	57.8007
2014	9	2	21	0	41	0.3	3.6	0.74	96.4	81.063	56.5865
2014	9	2	21	10	41	0.3	3.6	0.72	96.3	81.063	55.3234
2014	9	2	21	20	41	0.3	3.6	0.83	94.1	80.9974	63.606
2014	9	2	21	30	41	0.3	3.6	0.78	97.8	81.063	59.3654
2014	9	2	21	40	41	0.3	3.6	0.75	97.1	81.063	57.0918
2014	9	2	21	50	41	0.3	3.6	0.75	95.2	81.063	57.8497

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	2	22	0	41	0.3	3.6	0.79	96.2	81.063	60.3759
2014	9	2	22	10	41	0.3	3.6	0.79	96.2	80.9974	60.3248
2014	9	2	22	20	41	0.3	3.6	0.79	96.9	81.063	60.1233
2014	9	2	22	30	41	0.3	3.6	0.75	95	80.9974	57.8008
2014	9	2	22	40	41	0.3	3.6	0.78	95.3	81.063	60.1233
2014	9	2	22	50	41	0.3	3.6	0.77	95.9	81.063	58.6076
2014	9	2	23	0	41	0.3	3.6	0.79	97.9	81.063	59.8707
2014	9	2	23	10	41	0.3	3.6	0.75	97.6	81.063	57.0919
2014	9	2	23	20	41	0.3	3.6	0.75	98.1	81.063	56.8393
2014	9	2	23	30	41	0.3	3.6	0.83	95	81.063	63.66
2014	9	2	23	40	41	0.3	3.6	0.79	95.2	81.063	60.6286
2014	9	2	23	50	41	0.3	3.6	0.78	96	81.063	59.8707
2014	9	3	0	0	41	0.3	3.6	0.81	96	81.063	62.1443
2014	9	3	0	10	41	0.3	3.6	0.8	95.9	81.063	61.3865
2014	9	3	0	20	41	0.3	3.6	0.79	95.9	81.063	60.6286
2014	9	3	0	30	41	0.3	3.6	0.79	96.7	81.063	60.376
2014	9	3	0	40	41	0.3	3.6	0.78	96.5	81.063	59.8708
2014	9	3	0	50	41	0.3	3.6	0.84	95.4	81.063	64.6706
2014	9	3	1	0	41	0.3	3.6	0.79	97.1	81.063	60.6287
2014	9	3	1	10	41	0.3	3.6	0.8	96.6	81.063	61.1339
2014	9	3	1	20	41	0.3	3.6	0.76	96.2	81.063	58.1025
2014	9	3	1	30	41	0.3	3.6	0.8	96.3	81.063	61.3866
2014	9	3	1	40	41	0.3	3.6	0.81	94	81.063	61.8918
2014	9	3	1	50	41	0.3	3.6	0.79	96.9	81.063	60.1235
2014	9	3	2	0	41	0.3	3.6	0.81	95.6	81.063	61.8919
2014	9	3	2	10	41	0.3	3.6	0.79	97.4	81.063	60.3761
2014	9	3	2	20	41	0.3	3.6	0.84	95.8	81.063	64.1655
2014	9	3	2	30	41	0.3	3.6	0.81	96.5	81.063	62.1445
2014	9	3	2	40	41	0.3	3.6	0.82	97.6	81.063	62.3972
2014	9	3	2	50	41	0.3	3.6	0.8	96.3	81.063	61.3867
2014	9	3	3	0	41	0.3	3.6	0.83	95.9	81.063	63.4077
2014	9	3	3	10	41	0.3	3.6	0.82	95.5	81.063	62.9025
2014	9	3	3	20	41	0.3	3.6	0.81	97	81.063	61.892
2014	9	3	3	30	41	0.3	3.6	0.78	95.6	81.063	59.6184
2014	9	3	3	40	41	0.3	3.6	0.81	96.7	81.063	62.1446
2014	9	3	3	50	41	0.3	3.6	0.78	96.7	81.063	59.8711
2014	9	3	4	0	41	0.3	3.6	0.77	95.9	81.063	59.1132
2014	9	3	4	10	41	0.3	3.6	0.79	96	81.1286	60.1746
2014	9	3	4	20	41	0.3	3.6	0.8	94.9	81.063	61.6395
2014	9	3	4	30	41	0.3	3.6	0.8	93.8	81.063	61.6395
2014	9	3	4	40	41	0.3	3.6	0.81	96.5	81.063	62.1448
2014	9	3	4	50	41	0.3	3.6	0.82	97.6	81.063	62.3974
2014	9	3	5	0	41	0.3	3.6	0.74	96.1	81.1286	56.8878
2014	9	3	5	10	41	0.3	3.6	0.78	95.1	81.1286	59.9219
2014	9	3	5	20	41	0.3	3.6	0.79	97.1	81.1286	60.6804
2014	9	3	5	30	41	0.3	3.6	0.78	95.8	81.1286	59.9219

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	5	40	41	0.3	3.6	0.77	97.1	81.1286	58.6577
2014	9	3	5	50	41	0.3	3.6	0.77	95.4	81.1286	58.9106
2014	9	3	6	0	41	0.3	3.6	0.78	97	81.1286	59.4163
2014	9	3	6	10	41	0.3	3.6	0.76	94.7	81.1286	58.1521
2014	9	3	6	20	41	0.3	3.6	0.82	95.1	81.1286	62.7032
2014	9	3	6	30	41	0.3	3.6	0.77	95.1	81.1286	59.1635
2014	9	3	6	40	41	0.3	3.6	0.8	95.2	81.1286	61.6919
2014	9	3	6	50	41	0.3	3.6	0.76	97.2	81.1286	57.8993
2014	9	3	7	0	41	0.3	3.6	0.78	97.5	81.1942	59.9727
2014	9	3	7	10	41	0.3	3.6	0.77	95.9	81.1942	59.2136
2014	9	3	7	20	41	0.3	3.6	0.77	97.8	81.1942	58.9605
2014	9	3	7	30	41	0.3	3.6	0.79	94.5	81.1942	60.7319
2014	9	3	7	40	41	0.3	3.6	0.79	95.5	81.2598	60.5299
2014	9	3	7	50	41	0.3	3.6	0.79	94.5	81.2598	60.7832
2014	9	3	8	0	41	0.3	3.6	0.78	95.8	81.2598	59.5168
2014	9	3	8	10	41	0.3	3.6	0.8	96.6	81.2598	61.543
2014	9	3	8	20	41	0.3	3.6	0.8	94.9	81.2598	61.7962
2014	9	3	8	30	41	0.3	3.6	0.8	96.4	81.3255	61.0879
2014	9	3	8	40	41	0.3	3.6	0.82	96.4	81.3255	62.8622
2014	9	3	8	50	41	0.3	3.6	0.81	96.8	81.3255	61.8483
2014	9	3	9	0	41	0.3	3.6	0.83	95.4	81.3255	63.8761
2014	9	3	9	10	41	0.3	3.6	0.79	96.7	81.3255	60.5809
2014	9	3	9	20	41	0.3	3.6	0.77	96.3	81.3255	59.3135
2014	9	3	9	30	41	0.3	3.6	0.81	94.9	81.3255	62.6087
2014	9	3	9	40	41	0.3	3.6	0.81	96.3	81.2598	62.3026
2014	9	3	9	50	41	0.3	3.6	0.79	94.3	81.2598	61.0363
2014	9	3	10	0	41	0.3	3.6	0.81	93.3	81.1942	61.9969
2014	9	3	10	10	41	0.3	3.6	0.79	95.9	81.1942	60.9847
2014	9	3	10	20	41	0.3	3.6	0.78	96	81.1942	59.7194
2014	9	3	10	30	41	0.3	3.6	0.82	97.5	81.1942	63.009
2014	9	3	10	40	41	0.3	3.6	0.79	95.5	81.1286	60.9331
2014	9	3	10	50	41	0.3	3.6	0.81	97.6	81.1942	62.2498
2014	9	3	11	0	41	0.3	3.6	0.78	97.5	81.1286	59.9217
2014	9	3	11	10	41	0.3	3.6	0.81	94.7	81.1286	61.9444
2014	9	3	11	20	41	0.3	3.6	0.79	93.8	81.1286	60.933
2014	9	3	11	30	41	0.3	3.6	0.83	95.5	81.1286	63.4613
2014	9	3	11	40	41	0.3	3.6	0.76	95.2	81.1286	58.6574
2014	9	3	11	50	41	0.3	3.6	0.79	95.7	81.1286	60.6801
2014	9	3	12	0	41	0.3	3.6	0.79	95.7	81.1286	60.4272
2014	9	3	12	10	41	0.3	3.6	0.81	95.5	81.1286	62.4498
2014	9	3	12	20	41	0.3	3.6	0.78	95.3	81.1286	59.9215
2014	9	3	12	30	41	0.3	3.6	0.77	97.8	81.1286	58.9101
2014	9	3	12	40	41	0.3	3.6	0.79	97.2	81.1286	60.1742
2014	9	3	12	50	41	0.3	3.6	0.8	95.2	81.1286	61.1855
2014	9	3	13	0	41	0.3	3.6	0.77	95.9	81.1286	58.6572
2014	9	3	13	10	41	0.3	3.6	0.8	96.6	81.1286	61.1855

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	13	20	41	0.3	3.6	0.77	96.1	81.1286	58.91
2014	9	3	13	30	41	0.3	3.6	0.79	96.4	81.1286	60.6798
2014	9	3	13	40	41	0.3	3.6	0.78	97	81.063	59.8706
2014	9	3	13	50	41	0.3	3.6	0.78	98.2	81.063	59.618
2014	9	3	14	0	41	0.3	3.6	0.75	98.1	81.063	56.8391
2014	9	3	14	10	41	0.3	3.6	0.77	94.4	80.9974	59.0627
2014	9	3	14	20	41	0.3	3.6	0.79	96.7	80.9974	60.3247
2014	9	3	14	30	41	0.3	3.6	0.78	95.8	80.9974	59.8199
2014	9	3	14	40	41	0.3	3.6	0.8	97.8	80.9974	60.8295
2014	9	3	14	50	41	0.3	3.6	0.77	98.3	80.9974	58.5578
2014	9	3	15	0	41	0.3	3.6	0.73	95.7	80.9974	56.0338
2014	9	3	15	10	41	0.3	3.6	0.76	97.7	80.9974	57.8006
2014	9	3	15	20	41	0.3	3.6	0.79	96.9	80.9318	60.0214
2014	9	3	15	30	41	0.3	3.6	0.76	94.7	80.9318	58.256
2014	9	3	15	40	41	0.3	3.6	0.76	96.9	80.9318	58.256
2014	9	3	15	50	41	0.3	3.6	0.77	97.1	80.9318	59.0126
2014	9	3	16	0	41	0.3	3.6	0.78	94.4	80.8661	59.4665
2014	9	3	16	10	41	0.3	3.6	0.76	94.7	80.8661	58.4586
2014	9	3	16	20	41	0.3	3.6	0.76	98.2	80.8661	57.4507
2014	9	3	16	30	41	0.3	3.6	0.78	99.7	80.8661	59.2146
2014	9	3	16	40	41	0.3	3.6	0.77	94.6	80.8661	58.9626
2014	9	3	16	50	41	0.3	3.6	0.77	96.9	80.8661	58.7106
2014	9	3	17	0	41	0.3	3.6	0.73	97.7	80.8661	55.9389
2014	9	3	17	10	41	0.3	3.6	0.73	95.1	80.8661	56.1908
2014	9	3	17	20	41	0.3	3.6	0.74	98.4	80.8005	56.3949
2014	9	3	17	30	41	0.3	3.6	0.77	97.1	80.8661	58.9626
2014	9	3	17	40	41	0.3	3.6	0.77	95.9	80.8661	58.7106
2014	9	3	17	50	41	0.3	3.6	0.79	98.1	80.8661	59.9705
2014	9	3	18	0	41	0.3	3.6	0.78	95.3	80.8005	59.6679
2014	9	3	18	10	41	0.3	3.6	0.79	96.4	80.8661	60.2224
2014	9	3	18	20	41	0.3	3.6	0.81	95.1	80.8661	61.7343
2014	9	3	18	30	41	0.3	3.6	0.8	96.9	80.8661	60.7264
2014	9	3	18	40	41	0.3	3.6	0.78	95.8	80.8661	59.2145
2014	9	3	18	50	41	0.3	3.6	0.79	96.7	80.8661	60.4744
2014	9	3	19	0	41	0.3	3.6	0.78	93.1	80.8661	59.9705
2014	9	3	19	10	41	0.3	3.6	0.79	95.7	80.8661	60.7264
2014	9	3	19	20	41	0.3	3.6	0.77	95.9	80.8661	58.7106
2014	9	3	19	30	41	0.3	3.6	0.8	94.2	80.8661	61.4823
2014	9	3	19	40	41	0.3	3.6	0.77	94.1	80.8661	59.2145
2014	9	3	19	50	41	0.3	3.6	0.79	95.7	80.8661	60.7264
2014	9	3	20	0	41	0.3	3.6	0.8	97.5	80.8661	61.2304
2014	9	3	20	10	41	0.3	3.6	0.78	95.8	80.8661	59.7185
2014	9	3	20	20	41	0.3	3.6	0.8	95.6	80.8661	61.2304
2014	9	3	20	30	41	0.3	3.6	0.8	95.2	80.8661	61.2304
2014	9	3	20	40	41	0.3	3.6	0.82	96.2	80.8661	62.7423
2014	9	3	20	50	41	0.3	3.6	0.82	96.2	80.8661	62.2383

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	3	21	0	41	0.3	3.6	0.81	94	80.8661	61.7344
2014	9	3	21	10	41	0.3	3.6	0.79	95.3	80.8661	60.2225
2014	9	3	21	20	41	0.3	3.6	0.78	94.8	80.8661	59.9706
2014	9	3	21	30	41	0.3	3.6	0.75	95.5	80.8661	57.1988
2014	9	3	21	40	41	0.3	3.6	0.76	94.7	80.8661	57.9548
2014	9	3	21	50	41	0.3	3.6	0.76	97.2	80.8661	57.9548
2014	9	3	22	0	41	0.3	3.6	0.75	97.1	80.8661	56.9469
2014	9	3	22	10	41	0.3	3.6	0.78	95.3	80.8661	59.9706
2014	9	3	22	20	41	0.3	3.6	0.77	96.9	80.8661	58.7107
2014	9	3	22	30	41	0.3	3.6	0.78	95.1	80.8661	59.4667
2014	9	3	22	40	41	0.3	3.6	0.82	97.1	80.8661	62.7424
2014	9	3	22	50	41	0.3	3.6	0.76	98.4	80.8661	57.7029
2014	9	3	23	0	41	0.3	3.6	0.81	94.2	80.9318	62.2912
2014	9	3	23	10	41	0.3	3.6	0.79	94.3	80.8661	60.4746
2014	9	3	23	20	41	0.3	3.6	0.75	97	80.9318	57.4996
2014	9	3	23	30	41	0.3	3.6	0.82	94.8	80.9318	62.5435
2014	9	3	23	40	41	0.3	3.6	0.8	96.9	80.8661	60.7267
2014	9	3	23	50	41	0.3	3.6	0.8	98.3	80.9318	60.526
2014	9	4	0	0	41	0.3	3.6	0.76	95.9	80.9318	58.2563
2014	9	4	0	10	41	0.3	3.6	0.8	94.5	80.9318	61.0304
2014	9	4	0	20	41	0.3	3.6	0.8	96.6	80.9318	61.0304
2014	9	4	0	30	41	0.3	3.6	0.78	95.8	80.9318	60.0216
2014	9	4	0	40	41	0.3	3.6	0.76	97.4	80.9318	58.0041
2014	9	4	0	50	41	0.3	3.6	0.77	97.5	80.9318	59.0129
2014	9	4	1	0	41	0.3	3.6	0.79	95.9	80.9318	60.5261
2014	9	4	1	10	41	0.3	3.6	0.8	98.3	80.9318	60.5261
2014	9	4	1	20	41	0.3	3.6	0.78	94.4	80.9318	59.5173
2014	9	4	1	30	41	0.3	3.6	0.78	97.3	80.9318	59.2651
2014	9	4	1	40	41	0.3	3.6	0.78	95.5	80.9318	59.7695
2014	9	4	1	50	41	0.3	3.6	0.78	96.3	80.9318	59.7696
2014	9	4	2	0	41	0.3	3.6	0.79	95.7	80.9318	60.5261
2014	9	4	2	10	41	0.3	3.6	0.79	97.2	80.9318	60.0218
2014	9	4	2	20	41	0.3	3.6	0.78	97.2	80.9318	59.7696
2014	9	4	2	30	41	0.3	3.6	0.77	94.6	80.9318	59.013
2014	9	4	2	40	41	0.3	3.6	0.77	96.2	80.9318	58.5087
2014	9	4	2	50	41	0.3	3.6	0.81	97	80.9318	61.7872
2014	9	4	3	0	41	0.3	3.6	0.77	97.1	80.9318	59.0131
2014	9	4	3	10	41	0.3	3.6	0.75	95	80.9318	57.2478
2014	9	4	3	20	41	0.3	3.6	0.78	97	80.9318	59.5175
2014	9	4	3	30	41	0.3	3.6	0.78	94.6	80.9318	59.7697
2014	9	4	3	40	41	0.3	3.6	0.77	97.1	80.9318	58.761
2014	9	4	3	50	41	0.3	3.6	0.79	97.8	80.9318	60.5264
2014	9	4	4	0	41	0.3	3.6	0.79	95.2	80.9318	60.5264
2014	9	4	4	10	41	0.3	3.6	0.8	96.9	80.9318	60.7786
2014	9	4	4	20	41	0.3	3.6	0.75	94.8	80.9318	57.2479
2014	9	4	4	30	41	0.3	3.6	0.79	98.6	80.9318	59.7699

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	4	40	41	0.3	3.6	0.81	93.5	80.9318	61.7874
2014	9	4	4	50	41	0.3	3.6	0.79	94.8	80.9318	60.5265
2014	9	4	5	0	41	0.3	3.6	0.78	96.6	80.9318	59.2655
2014	9	4	5	10	41	0.3	3.6	0.78	96	80.9318	59.5178
2014	9	4	5	20	41	0.3	3.6	0.77	95.6	80.9318	59.0134
2014	9	4	5	30	41	0.3	3.6	0.8	96.4	80.9318	60.7788
2014	9	4	5	40	41	0.3	3.6	0.77	95.9	80.9318	58.509
2014	9	4	5	50	41	0.3	3.6	0.82	95.3	80.9318	63.0485
2014	9	4	6	0	41	0.3	3.6	0.78	94.1	80.9318	60.0222
2014	9	4	6	10	41	0.3	3.6	0.77	94.1	80.9318	59.2657
2014	9	4	6	20	41	0.3	3.6	0.76	94.9	80.9318	58.2569
2014	9	4	6	30	41	0.3	3.6	0.76	95.5	80.9318	58.0047
2014	9	4	6	40	41	0.3	3.6	0.78	95.6	80.9318	59.5179
2014	9	4	6	50	41	0.3	3.6	0.76	96.2	80.9318	58.257
2014	9	4	7	0	41	0.3	3.6	0.81	94	80.9318	62.0399
2014	9	4	7	10	41	0.3	3.6	0.77	94.7	80.9318	58.7614
2014	9	4	7	20	41	0.3	3.6	0.79	96.9	80.9318	60.2746
2014	9	4	7	30	41	0.3	3.6	0.76	97.4	80.9318	58.257
2014	9	4	7	40	41	0.3	3.6	0.85	93.1	80.9318	65.0663
2014	9	4	7	50	41	0.3	3.6	0.8	98.7	80.9318	60.779
2014	9	4	8	0	41	0.3	3.6	0.79	95.5	80.9318	60.5268
2014	9	4	8	10	41	0.3	3.6	0.77	94.9	80.9318	59.2658
2014	9	4	8	20	41	0.3	3.6	0.75	95.8	80.9318	57.2483
2014	9	4	8	30	41	0.3	3.6	0.77	94.4	80.9318	59.0136
2014	9	4	8	40	41	0.3	3.6	0.79	96.7	80.9318	60.5268
2014	9	4	8	50	41	0.3	3.6	0.81	95.3	80.9318	62.2921
2014	9	4	9	0	41	0.3	3.6	0.77	94.9	80.9318	59.2658
2014	9	4	9	10	41	0.3	3.6	0.81	95.6	80.9318	61.7877
2014	9	4	9	20	41	0.3	3.6	0.8	94.9	80.9318	61.5355
2014	9	4	9	30	41	0.3	3.6	0.79	94.3	80.9318	60.5267
2014	9	4	9	40	41	0.3	3.6	0.79	96	80.9318	60.0223
2014	9	4	9	50	41	0.3	3.6	0.74	95.1	80.9318	56.7438
2014	9	4	10	0	41	0.3	3.6	0.81	95.8	80.9318	61.7876
2014	9	4	10	10	41	0.3	3.6	0.79	95.5	80.9318	60.5266
2014	9	4	10	20	41	0.3	3.6	0.79	96.7	80.9318	60.2744
2014	9	4	10	30	41	0.3	3.6	0.8	95	80.9318	61.031
2014	9	4	10	40	41	0.3	3.6	0.78	97.2	80.9318	59.5178
2014	9	4	10	50	41	0.3	3.6	0.78	94.8	80.9318	60.0221
2014	9	4	11	0	41	0.3	3.6	0.78	98.3	80.9318	59.0133
2014	9	4	11	10	41	0.3	3.6	0.78	97	80.9318	59.7699
2014	9	4	11	20	41	0.3	3.6	0.84	98.1	80.9318	63.5528
2014	9	4	11	30	41	0.3	3.6	0.81	97	80.9318	61.7874
2014	9	4	11	40	41	0.3	3.6	0.79	96.9	80.9318	60.022
2014	9	4	11	50	41	0.3	3.6	0.76	98.9	80.9318	57.7522
2014	9	4	12	0	41	0.3	3.6	0.8	93.8	80.9318	61.0307
2014	9	4	12	10	41	0.3	3.6	0.76	97	80.8661	57.7032

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	12	20	41	0.3	3.6	0.78	99.4	80.8661	59.2151
2014	9	4	12	30	41	0.3	3.6	0.77	97.3	80.8661	58.7111
2014	9	4	12	40	41	0.3	3.6	0.76	95.4	80.8661	58.4591
2014	9	4	12	50	41	0.3	3.6	0.77	96.3	80.8661	58.963
2014	9	4	13	0	41	0.3	3.6	0.79	95.5	80.8661	60.2229
2014	9	4	13	10	41	0.3	3.6	0.75	98.1	80.8661	56.6952
2014	9	4	13	20	41	0.3	3.6	0.79	99.3	80.8005	59.6682
2014	9	4	13	30	41	0.3	3.6	0.76	95.4	80.7349	58.3598
2014	9	4	13	40	41	0.3	3.6	0.8	94.5	80.7349	60.8753
2014	9	4	13	50	41	0.3	3.6	0.76	95.9	80.7349	58.1082
2014	9	4	14	0	41	0.3	3.6	0.79	97.8	80.6693	60.3209
2014	9	4	14	10	41	0.3	3.6	0.78	96.6	80.6693	59.0642
2014	9	4	14	20	41	0.3	3.6	0.75	95	80.6693	57.3048
2014	9	4	14	30	41	0.3	3.6	0.73	97.8	80.6693	55.0428
2014	9	4	14	40	41	0.3	3.6	0.74	96.4	80.6037	56.2516
2014	9	4	14	50	41	0.3	3.6	0.82	95.5	80.5381	62.7273
2014	9	4	15	0	41	0.3	3.6	0.76	96	80.4724	57.66
2014	9	4	15	10	41	0.3	3.6	0.77	96.6	80.4724	58.1614
2014	9	4	15	20	41	0.3	3.6	0.78	96.3	80.4724	59.1642
2014	9	4	15	30	41	0.3	3.6	0.76	97.4	80.4724	57.66
2014	9	4	15	40	41	0.3	3.6	0.76	96.4	80.4068	57.8613
2014	9	4	15	50	41	0.3	3.6	0.77	97.3	80.4068	58.3623
2014	9	4	16	0	41	0.3	3.6	0.77	97.9	80.4068	58.1118
2014	9	4	16	10	41	0.3	3.6	0.74	95.1	80.4068	56.6089
2014	9	4	16	20	41	0.3	3.6	0.73	95.7	80.3412	55.059
2014	9	4	16	30	41	0.3	3.6	0.76	99.1	80.3412	57.5617
2014	9	4	16	40	41	0.3	3.6	0.76	96.9	80.3412	57.8119
2014	9	4	16	50	41	0.3	3.6	0.77	97.9	80.3412	58.0622
2014	9	4	17	0	41	0.3	3.6	0.76	97.2	80.3412	57.5617
2014	9	4	17	10	41	0.3	3.6	0.83	95.7	80.3412	63.0676
2014	9	4	17	20	41	0.3	3.6	0.76	96	80.3412	57.3114
2014	9	4	17	30	41	0.3	3.6	0.8	97.8	80.3412	60.3146
2014	9	4	17	40	41	0.3	3.6	0.8	96.8	80.3412	60.8151
2014	9	4	17	50	41	0.3	3.6	0.79	96.5	80.3412	59.5638
2014	9	4	18	0	41	0.3	3.6	0.79	94.3	80.2756	60.0131
2014	9	4	18	10	41	0.3	3.6	0.77	97.6	80.3412	58.3125
2014	9	4	18	20	41	0.3	3.6	0.76	96.9	80.3412	57.8119
2014	9	4	18	30	41	0.3	3.6	0.79	96.7	80.3412	60.0643
2014	9	4	18	40	41	0.3	3.6	0.81	96.8	80.3412	61.0654
2014	9	4	18	50	41	0.3	3.6	0.81	94.7	80.3412	61.3157
2014	9	4	19	0	41	0.3	3.6	0.77	94.6	80.3412	58.5627
2014	9	4	19	10	41	0.3	3.6	0.78	96.6	80.3412	58.813
2014	9	4	19	20	41	0.3	3.6	0.77	97.6	80.3412	58.3125
2014	9	4	19	30	41	0.3	3.6	0.8	97.5	80.3412	60.5649
2014	9	4	19	40	41	0.3	3.6	0.8	97.3	80.3412	60.8152
2014	9	4	19	50	41	0.3	3.6	0.76	95.4	80.3412	58.0622

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	4	20	0	41	0.3	3.6	0.77	96.6	80.3412	58.0622
2014	9	4	20	10	41	0.3	3.6	0.77	94.4	80.3412	58.3125
2014	9	4	20	20	41	0.3	3.6	0.8	98	80.3412	60.3147
2014	9	4	20	30	41	0.3	3.6	0.77	97.4	80.3412	58.0622
2014	9	4	20	40	41	0.3	3.6	0.78	93.8	80.3412	59.5639
2014	9	4	20	50	41	0.3	3.6	0.78	94.8	80.3412	59.5639
2014	9	4	21	0	41	0.3	3.6	0.77	95.9	80.3412	58.3125
2014	9	4	21	10	41	0.3	3.6	0.84	96.3	80.4068	63.372
2014	9	4	21	20	41	0.3	3.6	0.78	97.2	80.3412	59.3136
2014	9	4	21	30	41	0.3	3.6	0.77	95.9	80.3412	58.3126
2014	9	4	21	40	41	0.3	3.6	0.76	97.2	80.4068	57.6109
2014	9	4	21	50	41	0.3	3.6	0.82	96.5	80.4068	61.8691
2014	9	4	22	0	41	0.3	3.6	0.84	97.9	80.4068	63.372
2014	9	4	22	10	41	0.3	3.6	0.8	97.3	80.4068	60.3662
2014	9	4	22	20	41	0.3	3.6	0.77	97.9	80.4068	58.1119
2014	9	4	22	30	41	0.3	3.6	0.76	96.5	80.4068	57.3605
2014	9	4	22	40	41	0.3	3.6	0.82	99	80.4068	61.8691
2014	9	4	22	50	41	0.3	3.6	0.79	96.5	80.4068	59.6148
2014	9	4	23	0	41	0.3	3.6	0.76	96.7	80.4068	57.611
2014	9	4	23	10	41	0.3	3.6	0.76	95	80.4068	57.611
2014	9	4	23	20	41	0.3	3.6	0.76	95.9	80.4068	57.8615
2014	9	4	23	30	41	0.3	3.6	0.78	95.5	80.4068	59.6149
2014	9	4	23	40	41	0.3	3.6	0.81	96.3	80.4068	61.3683
2014	9	4	23	50	41	0.3	3.6	0.79	94.3	80.4068	59.8654
2014	9	5	0	0	41	0.3	3.6	0.79	96.4	80.4724	60.1671
2014	9	5	0	10	41	0.3	3.6	0.79	93.8	80.4724	60.4178
2014	9	5	0	20	41	0.3	3.6	0.76	92.5	80.4724	58.1616
2014	9	5	0	30	41	0.3	3.6	0.75	95	80.4724	57.4095
2014	9	5	0	40	41	0.3	3.6	0.8	96.6	80.5381	60.9712
2014	9	5	0	50	41	0.3	3.6	0.79	94.3	80.5381	59.9676
2014	9	5	1	0	41	0.3	3.6	0.78	94.8	80.5381	59.4658
2014	9	5	1	10	41	0.3	3.6	0.75	97.3	80.6693	56.8023
2014	9	5	1	20	41	0.3	3.6	0.76	94.2	80.6693	58.3104
2014	9	5	1	30	41	0.3	3.6	0.77	95.9	80.6693	58.3104
2014	9	5	1	40	41	0.3	3.6	0.81	97.7	80.6693	61.5778
2014	9	5	1	50	41	0.3	3.6	0.77	94.2	80.7349	58.6115
2014	9	5	2	0	41	0.3	3.6	0.78	93.9	80.7349	59.6178
2014	9	5	2	10	41	0.3	3.6	0.77	93.4	80.7349	58.6116
2014	9	5	2	20	41	0.3	3.6	0.8	95.9	80.7349	61.1271
2014	9	5	2	30	41	0.3	3.6	0.77	96.1	80.7349	58.6116
2014	9	5	2	40	41	0.3	3.6	0.79	98.6	80.7349	59.6178
2014	9	5	2	50	41	0.3	3.6	0.79	95.2	80.7349	60.3725
2014	9	5	3	0	41	0.3	3.6	0.79	95.7	80.7349	60.6241
2014	9	5	3	10	41	0.3	3.6	0.75	95	80.7349	57.1023
2014	9	5	3	20	41	0.3	3.6	0.82	96	80.8005	62.6897
2014	9	5	3	30	41	0.3	3.6	0.79	96.4	80.8005	60.4239

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	3	40	41	0.3	3.6	0.79	96.7	80.8005	60.4239
2014	9	5	3	50	41	0.3	3.6	0.77	97.6	80.8005	58.4098
2014	9	5	4	0	41	0.3	3.6	0.77	97.1	80.8005	58.6616
2014	9	5	4	10	41	0.3	3.6	0.77	97.1	80.8005	58.6616
2014	9	5	4	20	41	0.3	3.6	0.8	96.6	80.8005	61.1793
2014	9	5	4	30	41	0.3	3.6	0.77	95.6	80.8005	58.9134
2014	9	5	4	40	41	0.3	3.6	0.81	97	80.8005	61.6828
2014	9	5	4	50	41	0.3	3.6	0.78	97	80.8661	59.2154
2014	9	5	5	0	41	0.3	3.6	0.76	96.2	80.8005	58.1581
2014	9	5	5	10	41	0.3	3.6	0.74	96.6	80.8005	56.3958
2014	9	5	5	20	41	0.3	3.6	0.78	96.6	80.8005	59.1652
2014	9	5	5	30	41	0.3	3.6	0.82	93.9	80.8661	62.4912
2014	9	5	5	40	41	0.3	3.6	0.76	97.2	80.8661	57.9556
2014	9	5	5	50	41	0.3	3.6	0.78	96.5	80.8005	59.4171
2014	9	5	6	0	41	0.3	3.6	0.78	95.3	80.8005	59.4171
2014	9	5	6	10	41	0.3	3.6	0.79	97.6	80.8661	60.2235
2014	9	5	6	20	41	0.3	3.6	0.78	96.3	80.8005	59.1654
2014	9	5	6	30	41	0.3	3.6	0.82	97.5	80.8661	62.7433
2014	9	5	6	40	41	0.3	3.6	0.77	95.3	80.8661	59.2156
2014	9	5	6	50	41	0.3	3.6	0.78	94.3	80.8661	59.7196
2014	9	5	7	0	41	0.3	3.6	0.78	93.4	80.8661	59.4676
2014	9	5	7	10	41	0.3	3.6	0.76	95.7	80.8661	57.9558
2014	9	5	7	20	41	0.3	3.6	0.78	96.8	80.8661	59.2157
2014	9	5	7	30	41	0.3	3.6	0.79	95.9	80.8661	60.7276
2014	9	5	7	40	41	0.3	3.6	0.81	94.4	80.8661	61.7355
2014	9	5	7	50	41	0.3	3.6	0.81	95.3	80.8661	62.2395
2014	9	5	8	0	41	0.3	3.6	0.8	98.3	80.8661	60.7276
2014	9	5	8	10	41	0.3	3.6	0.81	95.1	80.8661	61.9875
2014	9	5	8	20	41	0.3	3.6	0.77	96.3	80.8661	58.9638
2014	9	5	8	30	41	0.3	3.6	0.8	96.1	80.8661	60.9796
2014	9	5	8	40	41	0.3	3.6	0.79	97.9	80.8661	59.7197
2014	9	5	8	50	41	0.3	3.6	0.8	95.9	80.8661	61.4835
2014	9	5	9	0	41	0.3	3.6	0.79	96.7	80.8661	59.9717
2014	9	5	9	10	41	0.3	3.6	0.82	96	80.8661	62.7434
2014	9	5	9	20	41	0.3	3.6	0.84	98.4	80.8661	63.4994
2014	9	5	9	30	41	0.3	3.6	0.79	97.2	80.8661	60.2236
2014	9	5	9	40	41	0.3	3.6	0.8	96.8	80.8661	60.9795
2014	9	5	9	50	41	0.3	3.6	0.76	96	80.8661	57.7037
2014	9	5	10	0	41	0.3	3.6	0.76	94.7	80.8661	57.9557
2014	9	5	10	10	41	0.3	3.6	0.76	96	80.8661	57.7037
2014	9	5	10	20	41	0.3	3.6	0.78	97.5	80.8661	59.2155
2014	9	5	10	30	41	0.3	3.6	0.78	98.3	80.8661	58.9635
2014	9	5	10	40	41	0.3	3.6	0.79	97.9	80.8661	60.2234
2014	9	5	10	50	41	0.3	3.6	0.81	98.9	80.9318	61.5354
2014	9	5	11	0	41	0.3	3.6	0.8	95.4	80.8661	61.2313
2014	9	5	11	10	41	0.3	3.6	0.76	94.7	80.8661	58.2075

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	11	20	41	0.3	3.6	0.75	97.3	80.8661	57.1995
2014	9	5	11	30	41	0.3	3.6	0.78	97.8	80.8661	59.2153
2014	9	5	11	40	41	0.3	3.6	0.77	96.8	80.8661	58.9633
2014	9	5	11	50	41	0.3	3.6	0.77	97.1	80.8661	58.7113
2014	9	5	12	0	41	0.3	3.6	0.75	98.3	80.8661	57.1994
2014	9	5	12	10	41	0.3	3.6	0.77	95.9	80.8661	58.7113
2014	9	5	12	20	41	0.3	3.6	0.76	98.2	80.8661	57.9553
2014	9	5	12	30	41	0.3	3.6	0.75	95	80.8661	57.4513
2014	9	5	12	40	41	0.3	3.6	0.75	96.5	80.8005	57.1508
2014	9	5	12	50	41	0.3	3.6	0.77	99.3	80.8005	58.1578
2014	9	5	13	0	41	0.3	3.6	0.79	95.5	80.8005	60.1719
2014	9	5	13	10	41	0.3	3.6	0.75	98.6	80.7349	56.8507
2014	9	5	13	20	41	0.3	3.6	0.78	95.8	80.8005	59.1648
2014	9	5	13	30	41	0.3	3.6	0.77	95.6	80.8005	58.9131
2014	9	5	13	40	41	0.3	3.6	0.77	91.7	80.8005	59.1648
2014	9	5	13	50	41	0.3	3.6	0.78	98.2	80.8005	59.4165
2014	9	5	14	0	41	0.3	3.6	0.76	98.9	80.7349	57.6052
2014	9	5	14	10	41	0.3	3.6	0.74	98.9	80.6693	56.0483
2014	9	5	14	20	41	0.3	3.6	0.76	99.4	80.6693	57.5563
2014	9	5	14	30	41	0.3	3.6	0.76	94.9	80.7349	58.3599
2014	9	5	14	40	41	0.3	3.6	0.77	96.6	80.6693	58.5616
2014	9	5	14	50	41	0.3	3.6	0.71	96.4	80.6693	54.0375
2014	9	5	15	0	41	0.3	3.6	0.8	97.3	80.6037	60.5208
2014	9	5	15	10	41	0.3	3.6	0.76	94.5	80.5381	57.9602
2014	9	5	15	20	41	0.3	3.6	0.81	97.9	80.6037	61.2741
2014	9	5	15	30	41	0.3	3.6	0.75	97.2	80.5381	57.2074
2014	9	5	15	40	41	0.3	3.6	0.79	97.4	80.5381	59.9674
2014	9	5	15	50	41	0.3	3.6	0.8	96.1	80.5381	60.7202
2014	9	5	16	0	41	0.3	3.6	0.75	95.3	80.5381	57.2074
2014	9	5	16	10	41	0.3	3.6	0.79	98.2	80.4724	59.415
2014	9	5	16	20	41	0.3	3.6	0.76	94.2	80.4724	58.1615
2014	9	5	16	30	41	0.3	3.6	0.78	97.2	80.4068	59.3643
2014	9	5	16	40	41	0.3	3.6	0.78	97	80.4724	59.415
2014	9	5	16	50	41	0.3	3.6	0.78	96.5	80.4724	59.415
2014	9	5	17	0	41	0.3	3.6	0.79	97.9	80.4068	59.3643
2014	9	5	17	10	41	0.3	3.6	0.78	94.6	80.4068	59.3643
2014	9	5	17	20	41	0.3	3.6	0.81	97.9	80.4068	61.6187
2014	9	5	17	30	41	0.3	3.6	0.78	101.1	80.4068	58.6129
2014	9	5	17	40	41	0.3	3.6	0.79	97.2	80.4068	59.6148
2014	9	5	17	50	41	0.3	3.6	0.78	97.7	80.4068	59.3643
2014	9	5	18	0	41	0.3	3.6	0.78	94.6	80.4068	59.1138
2014	9	5	18	10	41	0.3	3.6	0.81	96.5	80.4068	61.6187
2014	9	5	18	20	41	0.3	3.6	0.77	94.4	80.4068	58.6129
2014	9	5	18	30	41	0.3	3.6	0.77	97.1	80.4724	58.1615
2014	9	5	18	40	41	0.3	3.6	0.79	97.9	80.4724	59.9164
2014	9	5	18	50	41	0.3	3.6	0.75	97.1	80.4724	56.6573

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	5	19	0	41	0.3	3.6	0.79	95.5	80.4724	60.4178
2014	9	5	19	10	41	0.3	3.6	0.8	94.5	80.4724	61.1698
2014	9	5	19	20	41	0.3	3.6	0.77	96.2	80.4724	58.1615
2014	9	5	19	30	41	0.3	3.6	0.77	95.9	80.4068	58.3624
2014	9	5	19	40	41	0.3	3.6	0.79	97.9	80.4068	59.8653
2014	9	5	19	50	41	0.3	3.6	0.77	95.6	80.4724	58.6629
2014	9	5	20	0	41	0.3	3.6	0.77	96.2	80.4724	58.1615
2014	9	5	20	10	41	0.3	3.6	0.81	95.1	80.4724	61.4206
2014	9	5	20	20	41	0.3	3.6	0.79	96	80.4724	59.6657
2014	9	5	20	30	41	0.3	3.6	0.78	96.7	80.4724	59.415
2014	9	5	20	40	41	0.3	3.6	0.8	96.1	80.4724	60.6685
2014	9	5	20	50	41	0.3	3.6	0.78	97.2	80.4724	59.415
2014	9	5	21	0	41	0.3	3.6	0.81	94.7	80.5381	61.473
2014	9	5	21	10	41	0.3	3.6	0.77	94.6	80.4724	58.663
2014	9	5	21	20	41	0.3	3.6	0.81	97.9	80.4724	61.6714
2014	9	5	21	30	41	0.3	3.6	0.78	98.3	80.5381	58.713
2014	9	5	21	40	41	0.3	3.6	0.81	97.7	80.5381	61.473
2014	9	5	21	50	41	0.3	3.6	0.75	95	80.5381	57.4585
2014	9	5	22	0	41	0.3	3.6	0.77	96.6	80.5381	58.4621
2014	9	5	22	10	41	0.3	3.6	0.78	95.6	80.6037	59.2653
2014	9	5	22	20	41	0.3	3.6	0.8	97.5	80.6037	61.0232
2014	9	5	22	30	41	0.3	3.6	0.76	98.2	80.6037	57.7586
2014	9	5	22	40	41	0.3	3.6	0.79	95.9	80.6037	60.2698
2014	9	5	22	50	41	0.3	3.6	0.77	98.1	80.7349	58.36
2014	9	5	23	0	41	0.3	3.6	0.76	97	80.7349	57.6053
2014	9	5	23	10	41	0.3	3.6	0.78	95.1	80.7349	59.6177
2014	9	5	23	20	41	0.3	3.6	0.81	94.2	80.7349	61.8817
2014	9	5	23	30	41	0.3	3.6	0.78	95.3	80.7349	59.6178
2014	9	5	23	40	41	0.3	3.6	0.79	94.5	80.7349	60.624
2014	9	5	23	50	41	0.3	3.6	0.78	95.8	80.8005	59.4167
2014	9	6	0	0	41	0.3	3.6	0.82	99.7	80.7349	61.6302
2014	9	6	0	10	41	0.3	3.6	0.79	96.5	80.8005	59.9202
2014	9	6	0	20	41	0.3	3.6	0.81	96.7	80.8005	61.9344
2014	9	6	0	30	41	0.3	3.6	0.8	96.6	80.8005	60.6755
2014	9	6	0	40	41	0.3	3.6	0.78	95.8	80.8005	59.9203
2014	9	6	0	50	41	0.3	3.6	0.76	96.5	80.8005	57.6544
2014	9	6	1	0	41	0.3	3.6	0.8	96.6	80.8005	60.6756
2014	9	6	1	10	41	0.3	3.6	0.76	95.4	80.8005	58.1579
2014	9	6	1	20	41	0.3	3.6	0.78	97	80.8005	59.6685
2014	9	6	1	30	41	0.3	3.6	0.81	97	80.8005	61.6827
2014	9	6	1	40	41	0.3	3.6	0.82	94.6	80.8661	62.9949
2014	9	6	1	50	41	0.3	3.6	0.78	97	80.8005	59.1651
2014	9	6	2	0	41	0.3	3.6	0.8	96.6	80.8661	61.2311
2014	9	6	2	10	41	0.3	3.6	0.82	96.7	80.8661	62.2391
2014	9	6	2	20	41	0.3	3.6	0.8	94.2	80.8661	61.2312
2014	9	6	2	30	41	0.3	3.6	0.8	95.2	80.8661	61.2312

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	2	40	41	0.3	3.6	0.8	95.6	80.8661	61.4832
2014	9	6	2	50	41	0.3	3.6	0.82	95.9	80.8661	62.9951
2014	9	6	3	0	41	0.3	3.6	0.8	95.4	80.8661	61.2313
2014	9	6	3	10	41	0.3	3.6	0.77	97.5	80.8661	58.9635
2014	9	6	3	20	41	0.3	3.6	0.79	96.9	80.8661	59.9714
2014	9	6	3	30	41	0.3	3.6	0.8	93.3	80.8661	61.4833
2014	9	6	3	40	41	0.3	3.6	0.84	95.2	80.8661	64.0032
2014	9	6	3	50	41	0.3	3.6	0.77	97.3	80.8661	58.9636
2014	9	6	4	0	41	0.3	3.6	0.79	95	80.8661	60.4755
2014	9	6	4	10	41	0.3	3.6	0.78	97.5	80.8661	59.7196
2014	9	6	4	20	41	0.3	3.6	0.76	95.4	80.8661	58.2077
2014	9	6	4	30	41	0.3	3.6	0.8	94.2	80.8661	61.4835
2014	9	6	4	40	41	0.3	3.6	0.79	95.5	80.8661	60.4756
2014	9	6	4	50	41	0.3	3.6	0.79	96.7	80.8661	59.9716
2014	9	6	5	0	41	0.3	3.6	0.82	99.4	80.8661	62.2395
2014	9	6	5	10	41	0.3	3.6	0.76	96.2	80.8661	58.2078
2014	9	6	5	20	41	0.3	3.6	0.81	98.9	80.8661	61.2316
2014	9	6	5	30	41	0.3	3.6	0.78	94.6	80.8661	59.7197
2014	9	6	5	40	41	0.3	3.6	0.77	95.1	80.8661	59.2158
2014	9	6	5	50	41	0.3	3.6	0.8	99.9	80.8661	60.7277
2014	9	6	6	0	41	0.3	3.6	0.82	97.3	80.8661	62.7436
2014	9	6	6	10	41	0.3	3.6	0.79	96	80.8661	59.9718
2014	9	6	6	20	41	0.3	3.6	0.76	96.9	80.8661	57.956
2014	9	6	6	30	41	0.3	3.6	0.83	97.5	80.8661	63.2477
2014	9	6	6	40	41	0.3	3.6	0.81	94.4	80.8661	61.7358
2014	9	6	6	50	41	0.3	3.6	0.83	97.5	80.8661	63.2477
2014	9	6	7	0	41	0.3	3.6	0.78	95.3	80.9318	59.5184
2014	9	6	7	10	41	0.3	3.6	0.79	95.3	80.9318	60.275
2014	9	6	7	20	41	0.3	3.6	0.78	96.3	80.9318	59.7706
2014	9	6	7	30	41	0.3	3.6	0.79	96.5	80.9318	60.0228
2014	9	6	7	40	41	0.3	3.6	0.77	96.1	80.9318	59.0141
2014	9	6	7	50	41	0.3	3.6	0.77	96.9	80.9318	58.7619
2014	9	6	8	0	41	0.3	3.6	0.8	97.1	80.9318	61.0317
2014	9	6	8	10	41	0.3	3.6	0.76	97.2	80.9318	58.0053
2014	9	6	8	20	41	0.3	3.6	0.82	96.2	80.9318	62.7971
2014	9	6	8	30	41	0.3	3.6	0.79	95.5	80.9974	60.5786
2014	9	6	8	40	41	0.3	3.6	0.8	96.1	80.9974	61.0834
2014	9	6	8	50	41	0.3	3.6	0.79	96.2	80.9974	60.0737
2014	9	6	9	0	41	0.3	3.6	0.79	96.5	80.9974	60.0737
2014	9	6	9	10	41	0.3	3.6	0.77	94.6	80.9974	59.3164
2014	9	6	9	20	41	0.3	3.6	0.79	100.1	80.9318	59.5184
2014	9	6	9	30	41	0.3	3.6	0.81	94.2	80.9974	61.8405
2014	9	6	9	40	41	0.3	3.6	0.78	95.5	80.9974	60.0736
2014	9	6	9	50	41	0.3	3.6	0.81	98.4	80.9974	61.8405
2014	9	6	10	0	41	0.3	3.6	0.8	95.4	80.9974	61.3356
2014	9	6	10	10	41	0.3	3.6	0.78	96.8	80.9974	59.5687

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	10	20	41	0.3	3.6	0.79	94.3	80.9974	60.3259
2014	9	6	10	30	41	0.3	3.6	0.79	96.4	80.9974	60.3259
2014	9	6	10	40	41	0.3	3.6	0.78	95.5	80.9974	59.8211
2014	9	6	10	50	41	0.3	3.6	0.82	97.4	80.9318	62.5446
2014	9	6	11	0	41	0.3	3.6	0.77	98.1	80.9974	58.559
2014	9	6	11	10	41	0.3	3.6	0.8	97.1	80.9318	60.7791
2014	9	6	11	20	41	0.3	3.6	0.79	95.9	80.9318	60.7791
2014	9	6	11	30	41	0.3	3.6	0.76	97.2	80.9318	57.7527
2014	9	6	11	40	41	0.3	3.6	0.78	97	80.9318	59.2658
2014	9	6	11	50	41	0.3	3.6	0.76	97.2	80.9318	57.7526
2014	9	6	12	0	41	0.3	3.6	0.76	98	80.9318	57.7526
2014	9	6	12	10	41	0.3	3.6	0.78	97	80.9318	59.5179
2014	9	6	12	20	41	0.3	3.6	0.73	97	80.8661	55.6878
2014	9	6	12	30	41	0.3	3.6	0.76	95.9	80.8661	58.2076
2014	9	6	12	40	41	0.3	3.6	0.76	96.2	80.8661	58.2075
2014	9	6	12	50	41	0.3	3.6	0.76	97.4	80.8661	58.2075
2014	9	6	13	0	41	0.3	3.6	0.79	97.7	80.8661	59.9713
2014	9	6	13	10	41	0.3	3.6	0.73	95.9	80.8661	55.6876
2014	9	6	13	20	41	0.3	3.6	0.78	96.8	80.8661	59.2153
2014	9	6	13	30	41	0.3	3.6	0.79	97.8	80.8661	60.4752
2014	9	6	13	40	41	0.3	3.6	0.76	95.7	80.8005	58.158
2014	9	6	13	50	41	0.3	3.6	0.76	94.7	80.8005	57.9062
2014	9	6	14	0	41	0.3	3.6	0.73	98.1	80.8005	55.1368
2014	9	6	14	10	41	0.3	3.6	0.76	96.7	80.8005	57.9062
2014	9	6	14	20	41	0.3	3.6	0.76	97.2	80.8005	57.6544
2014	9	6	14	30	41	0.3	3.6	0.78	98.4	80.8005	59.4167
2014	9	6	14	40	41	0.3	3.6	0.8	95.6	80.8005	61.1791
2014	9	6	14	50	41	0.3	3.6	0.77	96.9	80.7349	58.3601
2014	9	6	15	0	41	0.3	3.6	0.68	95.3	80.7349	51.5681
2014	9	6	15	10	41	0.3	3.6	0.76	94.7	80.7349	57.8569
2014	9	6	15	20	41	0.3	3.6	0.79	94.5	80.7349	60.1209
2014	9	6	15	30	41	0.3	3.6	0.74	97.9	80.7349	56.3476
2014	9	6	15	40	41	0.3	3.6	0.75	95.8	80.6693	56.8024
2014	9	6	15	50	41	0.3	3.6	0.79	95.7	80.6693	60.5725
2014	9	6	16	0	41	0.3	3.6	0.77	94.2	80.6037	58.512
2014	9	6	16	10	41	0.3	3.6	0.78	97.7	80.6693	59.3158
2014	9	6	16	20	41	0.3	3.6	0.79	94.3	80.6693	60.3211
2014	9	6	16	30	41	0.3	3.6	0.77	96.6	80.6037	58.512
2014	9	6	16	40	41	0.3	3.6	0.76	95	80.6037	57.7586
2014	9	6	16	50	41	0.3	3.6	0.77	97.3	80.6693	58.5617
2014	9	6	17	0	41	0.3	3.6	0.77	96.6	80.6037	58.2608
2014	9	6	17	10	41	0.3	3.6	0.8	96.8	80.6037	60.7721
2014	9	6	17	20	41	0.3	3.6	0.77	96.1	80.6037	58.512
2014	9	6	17	30	41	0.3	3.6	0.76	95.2	80.6037	58.2608
2014	9	6	17	40	41	0.3	3.6	0.77	94.9	80.6037	59.0142
2014	9	6	17	50	41	0.3	3.6	0.75	97.5	80.6037	57.2563

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	6	18	0	41	0.3	3.6	0.76	98.7	80.5381	57.2076
2014	9	6	18	10	41	0.3	3.6	0.79	96.7	80.6037	60.0187
2014	9	6	18	20	41	0.3	3.6	0.76	96.5	80.6037	57.5074
2014	9	6	18	30	41	0.3	3.6	0.79	96.7	80.6693	60.0697
2014	9	6	18	40	41	0.3	3.6	0.77	97.1	80.6037	58.7631
2014	9	6	18	50	41	0.3	3.6	0.77	95.9	80.6037	58.2608
2014	9	6	19	0	41	0.3	3.6	0.74	97.6	80.6037	56.5029
2014	9	6	19	10	41	0.3	3.6	0.76	96.5	80.6037	57.5074
2014	9	6	19	20	41	0.3	3.6	0.75	96.8	80.5381	56.9567
2014	9	6	19	30	41	0.3	3.6	0.78	97.7	80.6037	59.2653
2014	9	6	19	40	41	0.3	3.6	0.74	96.7	80.6037	56.0007
2014	9	6	19	50	41	0.3	3.6	0.78	97	80.6037	59.2653
2014	9	6	20	0	41	0.3	3.6	0.77	95.9	80.6037	58.2608
2014	9	6	20	10	41	0.3	3.6	0.77	95.3	80.6693	59.0644
2014	9	6	20	20	41	0.3	3.6	0.75	98.5	80.6693	57.0537
2014	9	6	20	30	41	0.3	3.6	0.74	97.1	80.6037	56.2518
2014	9	6	20	40	41	0.3	3.6	0.77	95.4	80.6693	58.5617
2014	9	6	20	50	41	0.3	3.6	0.78	95.3	80.7349	59.8692
2014	9	6	21	0	41	0.3	3.6	0.79	97.9	80.8005	59.6683
2014	9	6	21	10	41	0.3	3.6	0.81	94.9	80.8005	62.186
2014	9	6	21	20	41	0.3	3.6	0.81	96.8	80.8005	61.4307
2014	9	6	21	30	41	0.3	3.6	0.79	93.8	80.8005	60.1719
2014	9	6	21	40	41	0.3	3.6	0.81	96.3	80.8005	61.6825
2014	9	6	21	50	41	0.3	3.6	0.8	94.5	80.8005	61.4307
2014	9	6	22	0	41	0.3	3.6	0.76	94.7	80.8005	58.1577
2014	9	6	22	10	41	0.3	3.6	0.78	95.8	80.8005	59.6683
2014	9	6	22	20	41	0.3	3.6	0.83	98.9	80.8005	62.6895
2014	9	6	22	30	41	0.3	3.6	0.75	97.8	80.8005	56.8989
2014	9	6	22	40	41	0.3	3.6	0.76	95.4	80.8005	58.4095
2014	9	6	22	50	41	0.3	3.6	0.74	96.6	80.8005	56.3954
2014	9	6	23	0	41	0.3	3.6	0.8	98.8	80.8661	60.475
2014	9	6	23	10	41	0.3	3.6	0.77	96.9	80.8661	58.4591
2014	9	6	23	20	41	0.3	3.6	0.77	97.9	80.8661	58.4591
2014	9	6	23	30	41	0.3	3.6	0.77	92.9	80.8661	58.7111
2014	9	6	23	40	41	0.3	3.6	0.78	96.1	80.8661	59.2151
2014	9	6	23	50	41	0.3	3.6	0.78	94.8	80.8661	59.971
2014	9	7	0	0	41	0.3	3.6	0.78	95.8	80.8661	59.4671
2014	9	7	0	10	41	0.3	3.6	0.83	96.1	80.8661	63.2468
2014	9	7	0	20	41	0.3	3.6	0.77	96.2	80.9318	58.5087
2014	9	7	0	30	41	0.3	3.6	0.76	98.9	80.9318	57.7522
2014	9	7	0	40	41	0.3	3.6	0.76	95.2	80.8661	58.4592
2014	9	7	0	50	41	0.3	3.6	0.78	95.8	80.8661	59.9711
2014	9	7	1	0	41	0.3	3.6	0.78	96.1	80.9318	59.2654
2014	9	7	1	10	41	0.3	3.6	0.81	94.2	80.9318	62.0395
2014	9	7	1	20	41	0.3	3.6	0.81	97.2	80.9318	61.5351
2014	9	7	1	30	41	0.3	3.6	0.81	96.5	80.9318	61.7873

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	1	40	41	0.3	3.6	0.83	97	80.9318	63.3005
2014	9	7	1	50	41	0.3	3.6	0.78	96.8	80.9318	59.5176
2014	9	7	2	0	41	0.3	3.6	0.79	94.3	80.9318	60.7786
2014	9	7	2	10	41	0.3	3.6	0.81	95.8	80.9318	61.7874
2014	9	7	2	20	41	0.3	3.6	0.73	96.5	80.9318	55.4825
2014	9	7	2	30	41	0.3	3.6	0.75	97	80.9318	57.2479
2014	9	7	2	40	41	0.3	3.6	0.81	95.6	80.9318	61.7874
2014	9	7	2	50	41	0.3	3.6	0.8	95.6	80.9318	61.5352
2014	9	7	3	0	41	0.3	3.6	0.78	95.1	80.9318	59.5177
2014	9	7	3	10	41	0.3	3.6	0.78	96.7	80.9318	59.7699
2014	9	7	3	20	41	0.3	3.6	0.82	96.5	80.9318	62.2918
2014	9	7	3	30	41	0.3	3.6	0.76	96.5	80.9318	57.7523
2014	9	7	3	40	41	0.3	3.6	0.75	96	80.9974	57.2965
2014	9	7	3	50	41	0.3	3.6	0.78	97.3	80.9974	59.3158
2014	9	7	4	0	41	0.3	3.6	0.76	94.2	80.9974	58.3061
2014	9	7	4	10	41	0.3	3.6	0.74	97.9	80.9974	56.5393
2014	9	7	4	20	41	0.3	3.6	0.78	96	80.9974	59.5682
2014	9	7	4	30	41	0.3	3.6	0.81	94	80.9974	61.8399
2014	9	7	4	40	41	0.3	3.6	0.81	95.3	80.9974	62.0923
2014	9	7	4	50	41	0.3	3.6	0.79	97.8	80.9974	60.5779
2014	9	7	5	0	41	0.3	3.6	0.79	97.7	80.9974	60.0731
2014	9	7	5	10	41	0.3	3.6	0.82	95.5	80.9974	63.102
2014	9	7	5	20	41	0.3	3.6	0.79	96	80.9974	60.0731
2014	9	7	5	30	41	0.3	3.6	0.79	95.7	80.9974	60.3255
2014	9	7	5	40	41	0.3	3.6	0.79	95	80.9974	60.3256
2014	9	7	5	50	41	0.3	3.6	0.78	95.8	80.9974	59.8208
2014	9	7	6	0	41	0.3	3.6	0.81	94.2	81.063	62.145
2014	9	7	6	10	41	0.3	3.6	0.79	96.9	80.9974	60.0732
2014	9	7	6	20	41	0.3	3.6	0.79	96.9	81.063	60.3767
2014	9	7	6	30	41	0.3	3.6	0.79	95.5	81.063	60.3767
2014	9	7	6	40	41	0.3	3.6	0.77	95.3	81.063	59.3662
2014	9	7	6	50	41	0.3	3.6	0.77	95.9	81.063	59.1137
2014	9	7	7	0	41	0.3	3.6	0.77	95.9	81.063	58.861
2014	9	7	7	10	41	0.3	3.6	0.81	94.4	81.063	61.8925
2014	9	7	7	20	41	0.3	3.6	0.81	96	81.1286	62.4506
2014	9	7	7	30	41	0.3	3.6	0.8	95.9	81.1286	61.6921
2014	9	7	7	40	41	0.3	3.6	0.8	95.2	81.1286	61.6921
2014	9	7	7	50	41	0.3	3.6	0.78	95.1	81.1286	59.9222
2014	9	7	8	0	41	0.3	3.6	0.83	92	81.1942	63.7687
2014	9	7	8	10	41	0.3	3.6	0.81	94.4	81.1942	61.9973
2014	9	7	8	20	41	0.3	3.6	0.78	94.3	81.2598	60.2768
2014	9	7	8	30	41	0.3	3.6	0.79	96.7	81.2598	60.2768
2014	9	7	8	40	41	0.3	3.6	0.82	93.4	81.2598	63.0627
2014	9	7	8	50	41	0.3	3.6	0.79	95.9	81.2598	61.0366
2014	9	7	9	0	41	0.3	3.6	0.79	96.7	81.3255	60.3276
2014	9	7	9	10	41	0.3	3.6	0.82	97.2	81.3255	62.6089

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	9	20	41	0.3	3.6	0.79	96.2	81.3255	60.8346
2014	9	7	9	30	41	0.3	3.6	0.8	95.4	81.3255	61.8485
2014	9	7	9	40	41	0.3	3.6	0.81	95.4	81.3255	62.1019
2014	9	7	9	50	41	0.3	3.6	0.77	96.1	81.3255	59.3137
2014	9	7	10	0	41	0.3	3.6	0.81	95.6	81.3911	62.1542
2014	9	7	10	10	41	0.3	3.6	0.73	97.4	81.3911	56.3193
2014	9	7	10	20	41	0.3	3.6	0.78	99.2	81.3911	59.6173
2014	9	7	10	30	41	0.3	3.6	0.77	97.1	81.3255	59.0601
2014	9	7	10	40	41	0.3	3.6	0.81	96.5	81.3255	61.8483
2014	9	7	10	50	41	0.3	3.6	0.75	97.5	81.3255	57.7926
2014	9	7	11	0	41	0.3	3.6	0.78	96.6	81.3255	59.567
2014	9	7	11	10	41	0.3	3.6	0.8	96.8	81.3255	61.3413
2014	9	7	11	20	41	0.3	3.6	0.78	95.5	81.3255	60.0739
2014	9	7	11	30	41	0.3	3.6	0.77	98.3	81.2598	58.7569
2014	9	7	11	40	41	0.3	3.6	0.76	96.5	81.1942	57.9481
2014	9	7	11	50	41	0.3	3.6	0.81	95.8	81.1942	61.9969
2014	9	7	12	0	41	0.3	3.6	0.76	98	81.1286	57.6463
2014	9	7	12	10	41	0.3	3.6	0.77	96.6	81.1286	58.9104
2014	9	7	12	20	41	0.3	3.6	0.77	98.1	81.1286	58.4047
2014	9	7	12	30	41	0.3	3.6	0.74	97.1	81.1286	56.6349
2014	9	7	12	40	41	0.3	3.6	0.76	95.9	81.1286	58.4047
2014	9	7	12	50	41	0.3	3.6	0.76	95.9	81.1286	58.4046
2014	9	7	13	0	41	0.3	3.6	0.71	97.5	81.063	54.0607
2014	9	7	13	10	41	0.3	3.6	0.79	96.5	81.063	60.1236
2014	9	7	13	20	41	0.3	3.6	0.76	96.5	81.063	57.85
2014	9	7	13	30	41	0.3	3.6	0.76	97.4	81.063	58.1026
2014	9	7	13	40	41	0.3	3.6	0.74	96.1	81.063	56.8394
2014	9	7	13	50	41	0.3	3.6	0.76	95.2	81.063	58.6078
2014	9	7	14	0	41	0.3	3.6	0.78	95.8	81.063	59.6182
2014	9	7	14	10	41	0.3	3.6	0.79	97.2	81.063	60.1234
2014	9	7	14	20	41	0.3	3.6	0.77	95.6	81.063	59.1129
2014	9	7	14	30	41	0.3	3.6	0.75	98.3	81.063	57.3446
2014	9	7	14	40	41	0.3	3.6	0.78	97.3	81.063	59.3655
2014	9	7	14	50	41	0.3	3.6	0.76	96	81.063	58.1024
2014	9	7	15	0	41	0.3	3.6	0.78	97.8	81.063	59.3655
2014	9	7	15	10	41	0.3	3.6	0.76	94.7	81.063	58.6076
2014	9	7	15	20	41	0.3	3.6	0.75	97.2	80.9974	57.5484
2014	9	7	15	30	41	0.3	3.6	0.77	96.8	80.9974	59.0628
2014	9	7	15	40	41	0.3	3.6	0.81	94.9	80.9974	62.0917
2014	9	7	15	50	41	0.3	3.6	0.8	96.6	80.9974	61.0821
2014	9	7	16	0	41	0.3	3.6	0.75	97.3	80.9974	57.296
2014	9	7	16	10	41	0.3	3.6	0.79	97.6	80.9974	60.5772
2014	9	7	16	20	41	0.3	3.6	0.77	95.6	80.9974	59.0628
2014	9	7	16	30	41	0.3	3.6	0.77	98.1	80.9974	58.8104
2014	9	7	16	40	41	0.3	3.6	0.77	97.6	80.9974	58.8104
2014	9	7	16	50	41	0.3	3.6	0.75	97	80.9974	57.5484

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	7	17	0	41	0.3	3.6	0.77	95.9	80.9974	58.558
2014	9	7	17	10	41	0.3	3.6	0.81	95.1	80.9974	62.3441
2014	9	7	17	20	41	0.3	3.6	0.8	97.8	80.9974	60.8296
2014	9	7	17	30	41	0.3	3.6	0.78	97.5	80.9318	59.7694
2014	9	7	17	40	41	0.3	3.6	0.77	95.9	80.9318	58.7606
2014	9	7	17	50	41	0.3	3.6	0.76	97	80.9974	57.8008
2014	9	7	18	0	41	0.3	3.6	0.77	96.6	80.9974	58.8104
2014	9	7	18	10	41	0.3	3.6	0.75	96.1	80.9318	56.9953
2014	9	7	18	20	41	0.3	3.6	0.79	97.6	80.9318	60.5259
2014	9	7	18	30	41	0.3	3.6	0.75	97.6	80.9318	56.9953
2014	9	7	18	40	41	0.3	3.6	0.8	96.8	80.9318	61.2825
2014	9	7	18	50	41	0.3	3.6	0.77	97.6	80.9318	58.7606
2014	9	7	19	0	41	0.3	3.6	0.79	97.9	80.9318	60.2737
2014	9	7	19	10	41	0.3	3.6	0.78	94.6	80.9318	59.5172
2014	9	7	19	20	41	0.3	3.6	0.77	94.7	80.9318	58.7606
2014	9	7	19	30	41	0.3	3.6	0.75	96.5	80.9318	57.4996
2014	9	7	19	40	41	0.3	3.6	0.75	97.2	80.9318	57.4996
2014	9	7	19	50	41	0.3	3.6	0.74	95.1	80.9318	56.743
2014	9	7	20	0	41	0.3	3.6	0.72	97.9	80.9318	54.4733
2014	9	7	20	10	41	0.3	3.6	0.77	98.1	80.9974	58.3056
2014	9	7	20	20	41	0.3	3.6	0.78	98	80.9318	59.5171
2014	9	7	20	30	41	0.3	3.6	0.75	96.8	80.9974	57.5483
2014	9	7	20	40	41	0.3	3.6	0.76	100	80.9974	57.2959
2014	9	7	20	50	41	0.3	3.6	0.81	98.4	80.9974	61.3344
2014	9	7	21	0	41	0.3	3.6	0.75	95.2	80.9974	57.8007
2014	9	7	21	10	41	0.3	3.6	0.75	95.5	80.9974	57.2959
2014	9	7	21	20	41	0.3	3.6	0.8	95.4	80.9974	61.5868
2014	9	7	21	30	41	0.3	3.6	0.78	96.6	80.9974	59.3152
2014	9	7	21	40	41	0.3	3.6	0.77	98.1	80.9974	58.558
2014	9	7	21	50	41	0.3	3.6	0.78	97.7	80.9974	59.82
2014	9	7	22	0	41	0.3	3.6	0.76	95.9	80.9974	58.3056
2014	9	7	22	10	41	0.3	3.6	0.77	98.5	80.9974	58.8104
2014	9	7	22	20	41	0.3	3.6	0.75	96.5	80.9974	57.5483
2014	9	7	22	30	41	0.3	3.6	0.78	97	81.063	59.8706
2014	9	7	22	40	41	0.3	3.6	0.81	96.3	81.063	61.8916
2014	9	7	22	50	41	0.3	3.6	0.78	94.8	81.063	60.1233
2014	9	7	23	0	41	0.3	3.6	0.81	97.2	81.063	62.1442
2014	9	7	23	10	41	0.3	3.6	0.77	94.6	81.063	59.1128
2014	9	7	23	20	41	0.3	3.6	0.76	97.2	81.063	58.1023
2014	9	7	23	30	41	0.3	3.6	0.79	97.2	81.063	60.1233
2014	9	7	23	40	41	0.3	3.6	0.79	94.3	81.063	60.8811
2014	9	7	23	50	41	0.3	3.6	0.77	95.9	81.063	58.8602
2014	9	8	0	0	41	0.3	3.6	0.78	97.5	81.063	59.6181
2014	9	8	0	10	41	0.3	3.6	0.81	98.4	81.063	61.639
2014	9	8	0	20	41	0.3	3.6	0.85	94.9	81.063	65.1757
2014	9	8	0	30	41	0.3	3.6	0.75	96.5	81.063	57.5971

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	0	40	41	0.3	3.6	0.76	97.6	81.063	58.355
2014	9	8	0	50	41	0.3	3.6	0.8	97.5	81.063	61.1338
2014	9	8	1	0	41	0.3	3.6	0.8	95.7	81.1286	61.1855
2014	9	8	1	10	41	0.3	3.6	0.82	96	81.1286	62.7025
2014	9	8	1	20	41	0.3	3.6	0.82	98.1	81.1286	62.4497
2014	9	8	1	30	41	0.3	3.6	0.8	95.9	81.1286	61.1855
2014	9	8	1	40	41	0.3	3.6	0.82	96.7	81.1286	62.7025
2014	9	8	1	50	41	0.3	3.6	0.83	95	81.1286	63.7139
2014	9	8	2	0	41	0.3	3.6	0.83	96.4	81.1286	63.2082
2014	9	8	2	10	41	0.3	3.6	0.8	96.6	81.1286	61.1855
2014	9	8	2	20	41	0.3	3.6	0.78	96.8	81.1286	59.6685
2014	9	8	2	30	41	0.3	3.6	0.78	96.8	81.1286	59.6685
2014	9	8	2	40	41	0.3	3.6	0.78	94.6	81.1286	59.9214
2014	9	8	2	50	41	0.3	3.6	0.81	95.8	81.1286	61.944
2014	9	8	3	0	41	0.3	3.6	0.78	97	81.1286	59.9214
2014	9	8	3	10	41	0.3	3.6	0.76	94.7	81.1286	58.6572
2014	9	8	3	20	41	0.3	3.6	0.8	94.5	81.1286	61.6912
2014	9	8	3	30	41	0.3	3.6	0.77	98.1	81.1942	58.7068
2014	9	8	3	40	41	0.3	3.6	0.78	97	81.1286	59.9214
2014	9	8	3	50	41	0.3	3.6	0.74	97.4	81.1286	56.3817
2014	9	8	4	0	41	0.3	3.6	0.77	94.9	81.1942	58.9599
2014	9	8	4	10	41	0.3	3.6	0.79	96.9	81.1286	60.4271
2014	9	8	4	20	41	0.3	3.6	0.78	94.8	81.1942	60.2251
2014	9	8	4	30	41	0.3	3.6	0.79	96.7	81.1942	60.7312
2014	9	8	4	40	41	0.3	3.6	0.78	97.3	81.1942	59.466
2014	9	8	4	50	41	0.3	3.6	0.77	95.6	81.1942	59.2129
2014	9	8	5	0	41	0.3	3.6	0.78	96.1	81.1942	59.466
2014	9	8	5	10	41	0.3	3.6	0.78	95.1	81.1942	59.9721
2014	9	8	5	20	41	0.3	3.6	0.76	97.2	81.1942	58.4538
2014	9	8	5	30	41	0.3	3.6	0.8	95.9	81.1942	61.2373
2014	9	8	5	40	41	0.3	3.6	0.79	97.1	81.1286	60.6799
2014	9	8	5	50	41	0.3	3.6	0.84	96.3	81.1942	64.2739
2014	9	8	6	0	41	0.3	3.6	0.81	94.7	81.1286	61.9441
2014	9	8	6	10	41	0.3	3.6	0.78	97	81.1942	59.9721
2014	9	8	6	20	41	0.3	3.6	0.79	93.6	81.1942	60.7312
2014	9	8	6	30	41	0.3	3.6	0.8	93.8	81.2598	61.7956
2014	9	8	6	40	41	0.3	3.6	0.83	96.1	81.2598	63.8217
2014	9	8	6	50	41	0.3	3.6	0.76	96.5	81.2598	57.9967
2014	9	8	7	0	41	0.3	3.6	0.81	97.2	81.3255	62.3547
2014	9	8	7	10	41	0.3	3.6	0.76	95.7	81.3255	58.5525
2014	9	8	7	20	41	0.3	3.6	0.86	95.5	81.3255	65.9033
2014	9	8	7	30	41	0.3	3.6	0.76	97.7	81.3911	58.0945
2014	9	8	7	40	41	0.3	3.6	0.79	98.9	81.3911	60.124
2014	9	8	7	50	41	0.3	3.6	0.77	97.8	81.4567	59.1591
2014	9	8	8	0	41	0.3	3.6	0.82	97.6	81.4567	62.7137
2014	9	8	8	10	41	0.3	3.6	0.77	98.6	81.4567	58.9052

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	8	20	41	0.3	3.6	0.82	96.6	81.5223	63.2747
2014	9	8	8	30	41	0.3	3.6	0.79	96.7	81.4567	60.9364
2014	9	8	8	40	41	0.3	3.6	0.84	97.8	81.5223	64.7994
2014	9	8	8	50	41	0.3	3.6	0.84	96.5	81.5223	64.5452
2014	9	8	9	0	41	0.3	3.6	0.8	96.6	81.5223	61.4959
2014	9	8	9	10	41	0.3	3.6	0.81	97	81.5223	62.2582
2014	9	8	9	20	41	0.3	3.6	0.76	98	81.5223	57.9382
2014	9	8	9	30	41	0.3	3.6	0.82	97.1	81.5223	63.2746
2014	9	8	9	40	41	0.3	3.6	0.8	96.2	81.5223	61.2417
2014	9	8	9	50	41	0.3	3.6	0.77	99.5	81.5223	58.9546
2014	9	8	10	0	41	0.3	3.6	0.78	95.8	81.5879	59.7672
2014	9	8	10	10	41	0.3	3.6	0.76	99.1	81.5879	58.4955
2014	9	8	10	20	41	0.3	3.6	0.77	96.9	81.5223	59.2087
2014	9	8	10	30	41	0.3	3.6	0.78	96.1	81.5223	59.7169
2014	9	8	10	40	41	0.3	3.6	0.79	96.7	81.5223	60.9874
2014	9	8	10	50	41	0.3	3.6	0.77	97.6	81.5879	59.2584
2014	9	8	11	0	41	0.3	3.6	0.81	97.6	81.5223	62.512
2014	9	8	11	10	41	0.3	3.6	0.81	96.8	81.4567	61.9517
2014	9	8	11	20	41	0.3	3.6	0.74	98.1	81.4567	56.8736
2014	9	8	11	30	41	0.3	3.6	0.77	95.9	81.4567	58.9048
2014	9	8	11	40	41	0.3	3.6	0.78	97	81.4567	59.6665
2014	9	8	11	50	41	0.3	3.6	0.78	96.5	81.3911	60.1237
2014	9	8	12	0	41	0.3	3.6	0.77	98.3	81.4567	58.9048
2014	9	8	12	10	41	0.3	3.6	0.81	94.2	81.3911	62.4069
2014	9	8	12	20	41	0.3	3.6	0.77	96.1	81.3911	59.1089
2014	9	8	12	30	41	0.3	3.6	0.77	94.9	81.3911	59.3625
2014	9	8	12	40	41	0.3	3.6	0.77	95.6	81.4567	59.1586
2014	9	8	12	50	41	0.3	3.6	0.81	96.7	81.3911	62.4067
2014	9	8	13	0	41	0.3	3.6	0.78	95.3	81.3911	60.1235
2014	9	8	13	10	41	0.3	3.6	0.82	96.9	81.3911	62.6604
2014	9	8	13	28	19	0.3	3.6	0.76	96.5	81.3911	58.094
2014	9	8	13	38	19	0.3	3.6	0.82	99	81.3911	62.4066
2014	9	8	13	48	19	0.3	3.6	0.78	98.5	81.3911	59.6161
2014	9	8	13	58	19	0.3	3.6	0.81	97.5	81.3911	61.8993
2014	9	8	14	8	19	0.3	3.6	0.73	97.7	81.3255	56.2707
2014	9	8	14	18	19	0.3	3.6	0.72	97	81.3255	55.5103
2014	9	8	14	28	19	0.3	3.6	0.8	99	81.3911	61.1381
2014	9	8	14	38	19	0.3	3.6	0.75	97.2	81.3911	57.8402
2014	9	8	14	48	19	0.3	3.6	0.78	96.5	81.3255	60.0727
2014	9	8	14	58	19	0.3	3.6	0.77	96.4	81.3911	59.1086
2014	9	8	15	8	19	0.3	3.6	0.76	96.4	81.3255	58.5518
2014	9	8	15	18	19	0.3	3.6	0.74	95.8	81.3255	57.031
2014	9	8	15	28	19	0.3	3.6	0.79	96.9	81.3255	60.5796
2014	9	8	15	38	19	0.3	3.6	0.78	96.1	81.3255	59.5657
2014	9	8	15	48	19	0.3	3.6	0.83	96.4	81.3255	63.3677
2014	9	8	15	58	19	0.3	3.6	0.79	95.9	81.3911	60.8843

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	16	8	19	0.3	3.6	0.77	97.1	81.3911	59.3622
2014	9	8	16	18	19	0.3	3.6	0.85	99.1	81.3911	64.9432
2014	9	8	16	28	19	0.3	3.6	0.82	99.7	81.3911	62.6601
2014	9	8	16	38	19	0.3	3.6	0.81	98.2	81.3911	61.899
2014	9	8	16	48	19	0.3	3.6	0.81	95.1	81.3255	62.1003
2014	9	8	16	58	19	0.3	3.6	0.81	95.1	81.3255	62.6073
2014	9	8	17	8	19	0.3	3.6	0.79	95.2	81.3255	60.833
2014	9	8	17	18	19	0.3	3.6	0.78	95.8	81.3255	59.8191
2014	9	8	17	28	19	0.3	3.6	0.78	95.8	81.3255	59.8191
2014	9	8	17	38	19	0.3	3.6	0.8	94.2	81.3255	61.5934
2014	9	8	17	48	19	0.3	3.6	0.79	96.2	81.3255	60.833
2014	9	8	17	58	19	0.3	3.6	0.78	96.1	81.3255	59.5656
2014	9	8	18	8	19	0.3	3.6	0.78	94.4	81.3255	59.8191
2014	9	8	18	18	19	0.3	3.6	0.8	98.7	81.3255	61.3399
2014	9	8	18	28	19	0.3	3.6	0.78	94.6	81.3255	59.8191
2014	9	8	18	38	19	0.3	3.6	0.78	93.1	81.3255	60.326
2014	9	8	18	48	19	0.3	3.6	0.82	100.1	81.3255	62.3538
2014	9	8	18	58	19	0.3	3.6	0.76	96.2	81.3255	58.5518
2014	9	8	19	8	19	0.3	3.6	0.82	94.6	81.3255	63.1142
2014	9	8	19	18	19	0.3	3.6	0.82	98.1	81.3255	62.6073
2014	9	8	19	28	19	0.3	3.6	0.77	98.1	81.3255	59.0587
2014	9	8	19	38	19	0.3	3.6	0.77	93.7	81.3255	59.5656
2014	9	8	19	48	19	0.3	3.6	0.78	95.8	81.3911	59.8695
2014	9	8	19	58	19	0.3	3.6	0.82	96.7	81.3911	62.9138
2014	9	8	20	8	19	0.3	3.6	0.84	97	81.3911	64.1822
2014	9	8	20	18	19	0.3	3.6	0.79	95.7	81.3911	61.138
2014	9	8	20	28	19	0.3	3.6	0.83	95.2	81.3911	63.6748
2014	9	8	20	38	19	0.3	3.6	0.81	95.5	81.3911	62.6601
2014	9	8	20	48	19	0.3	3.6	0.81	96.8	81.3911	62.1527
2014	9	8	20	58	19	0.3	3.6	0.78	95.8	81.3911	60.377
2014	9	8	21	8	19	0.3	3.6	0.83	96.6	81.3911	63.9286
2014	9	8	21	18	19	0.3	3.6	0.74	96.3	81.4567	57.1272
2014	9	8	21	28	19	0.3	3.6	0.81	95.1	81.4567	62.7129
2014	9	8	21	38	19	0.3	3.6	0.77	95.9	81.4567	59.4123
2014	9	8	21	48	19	0.3	3.6	0.77	97.3	81.4567	59.4123
2014	9	8	21	58	19	0.3	3.6	0.77	98.1	81.5223	58.6999
2014	9	8	22	8	19	0.3	3.6	0.77	97.3	81.5879	59.5123
2014	9	8	22	18	19	0.3	3.6	0.73	99	81.5879	55.9517
2014	9	8	22	28	19	0.3	3.6	0.73	100.3	81.5879	55.9518
2014	9	8	22	38	19	0.3	3.6	0.78	97	81.5879	59.7667
2014	9	8	22	48	19	0.3	3.6	0.73	99.3	81.5879	55.9518
2014	9	8	22	58	19	0.3	3.6	0.76	98.4	81.6535	58.5442
2014	9	8	23	8	19	0.3	3.6	0.76	98.4	81.6535	58.2897
2014	9	8	23	18	19	0.3	3.6	0.77	97.5	81.6535	59.5624
2014	9	8	23	28	19	0.3	3.6	0.77	98.1	81.6535	59.3079
2014	9	8	23	38	19	0.3	3.6	0.78	98.5	81.6535	59.5624

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	8	23	48	19	0.3	3.6	0.78	96.3	81.6535	60.0715
2014	9	8	23	58	19	0.3	3.6	0.78	99.4	81.6535	59.817
2014	9	9	0	8	19	0.3	3.6	0.77	98.9	81.6535	58.7989
2014	9	9	0	18	19	0.3	3.6	0.78	100	81.6535	59.308
2014	9	9	0	28	19	0.3	3.6	0.79	97.7	81.6535	60.5807
2014	9	9	0	38	19	0.3	3.6	0.79	98.2	81.7192	60.3768
2014	9	9	0	48	19	0.3	3.6	0.79	99.3	81.7192	60.6316
2014	9	9	0	58	19	0.3	3.6	0.8	94.5	81.7192	61.9054
2014	9	9	1	8	19	0.3	3.6	0.83	95.4	81.7192	64.453
2014	9	9	1	18	19	0.3	3.6	0.8	95.2	81.7192	61.6507
2014	9	9	1	28	19	0.3	3.6	0.81	96.1	81.7192	62.1602
2014	9	9	1	38	19	0.3	3.6	0.81	95.6	81.7192	62.415
2014	9	9	1	48	19	0.3	3.6	0.79	95	81.7192	60.8865
2014	9	9	1	58	19	0.3	3.6	0.77	95.9	81.7192	59.6127
2014	9	9	2	8	19	0.3	3.6	0.83	95.2	81.7192	63.9436
2014	9	9	2	18	19	0.3	3.6	0.82	96.2	81.7192	63.1794
2014	9	9	2	28	19	0.3	3.6	0.76	96.5	81.7192	58.339
2014	9	9	2	38	19	0.3	3.6	0.82	97.5	81.7192	63.4342
2014	9	9	2	48	19	0.3	3.6	0.79	96.9	81.7192	60.6319
2014	9	9	2	58	19	0.3	3.6	0.8	96.4	81.7192	61.6509
2014	9	9	3	8	19	0.3	3.6	0.84	96	81.7192	64.9627
2014	9	9	3	18	19	0.3	3.6	0.76	95.9	81.7192	58.8486
2014	9	9	3	28	19	0.3	3.6	0.82	96.2	81.7192	62.9247
2014	9	9	3	38	19	0.3	3.6	0.8	96.6	81.7192	61.9057
2014	9	9	3	48	19	0.3	3.6	0.78	97.2	81.7192	60.3772
2014	9	9	3	58	19	0.3	3.6	0.77	94.9	81.7848	59.918
2014	9	9	4	8	19	0.3	3.6	0.81	95.3	81.7192	62.9248
2014	9	9	4	18	19	0.3	3.6	0.81	95.6	81.7848	62.4677
2014	9	9	4	28	19	0.3	3.6	0.79	95.7	81.7848	61.1929
2014	9	9	4	38	19	0.3	3.6	0.83	95.4	81.7848	64.2525
2014	9	9	4	48	19	0.3	3.6	0.81	97	81.7192	62.4154
2014	9	9	4	58	19	0.3	3.6	0.83	97.5	81.7848	63.9976
2014	9	9	5	8	19	0.3	3.6	0.81	96.3	81.7848	62.4678
2014	9	9	5	18	19	0.3	3.6	0.8	96.6	81.7192	61.3964
2014	9	9	5	28	19	0.3	3.6	0.81	93.2	81.7848	62.9778
2014	9	9	5	38	19	0.3	3.6	0.79	95.7	81.7848	61.193
2014	9	9	5	48	19	0.3	3.6	0.77	94.7	81.7848	59.4082
2014	9	9	5	58	19	0.3	3.6	0.81	96.5	81.7848	62.7229
2014	9	9	6	8	19	0.3	3.6	0.83	97.5	81.7848	63.7428
2014	9	9	6	18	19	0.3	3.6	0.81	95.3	81.7848	62.7229
2014	9	9	6	28	19	0.3	3.6	0.81	95.3	81.7848	62.723
2014	9	9	6	38	19	0.3	3.6	0.79	96.2	81.7848	60.9382
2014	9	9	6	48	19	0.3	3.6	0.77	94.4	81.7848	59.6633
2014	9	9	6	58	19	0.3	3.6	0.78	96.8	81.7848	59.9183
2014	9	9	7	8	19	0.3	3.6	0.81	96.5	81.7848	62.723
2014	9	9	7	18	19	0.3	3.6	0.8	98.3	81.7848	61.4482

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	7	28	19	0.3	3.6	0.78	97	81.7848	60.4283
2014	9	9	7	38	19	0.3	3.6	0.79	96.7	81.7848	61.1932
2014	9	9	7	48	19	0.3	3.6	0.81	97	81.7848	62.4681
2014	9	9	7	58	19	0.3	3.6	0.81	98.1	81.7848	62.4681
2014	9	9	8	8	19	0.3	3.6	0.78	95.1	81.7848	60.1734
2014	9	9	8	18	19	0.3	3.6	0.82	96.2	81.7848	63.2331
2014	9	9	8	28	19	0.3	3.6	0.77	95.9	81.7848	59.4085
2014	9	9	8	38	19	0.3	3.6	0.78	97	81.8504	60.479
2014	9	9	8	48	19	0.3	3.6	0.79	93.8	81.8504	60.9893
2014	9	9	8	58	19	0.3	3.6	0.8	96.1	81.8504	61.7549
2014	9	9	9	8	19	0.3	3.6	0.76	95.7	81.8504	59.203
2014	9	9	9	18	19	0.3	3.6	0.79	95.7	81.8504	61.4997
2014	9	9	9	28	19	0.3	3.6	0.78	97	81.8504	59.9685
2014	9	9	9	38	19	0.3	3.6	0.84	95.8	81.8504	64.817
2014	9	9	9	48	19	0.3	3.6	0.79	93.8	81.8504	60.9892
2014	9	9	9	58	19	0.3	3.6	0.78	98.7	81.8504	59.7133
2014	9	9	10	8	19	0.3	3.6	0.82	97.6	81.8504	63.0307
2014	9	9	10	18	19	0.3	3.6	0.79	95.7	81.8504	61.4995
2014	9	9	10	28	19	0.3	3.6	0.76	96.4	81.8504	58.9477
2014	9	9	10	38	19	0.3	3.6	0.83	96.8	81.8504	63.7962
2014	9	9	10	48	19	0.3	3.6	0.77	98.4	81.8504	58.9476
2014	9	9	10	58	19	0.3	3.6	0.76	96.5	81.8504	58.4372
2014	9	9	11	8	19	0.3	3.6	0.8	96.1	81.8504	61.7546
2014	9	9	11	18	19	0.3	3.6	0.79	96.2	81.8504	60.989
2014	9	9	11	28	19	0.3	3.6	0.82	94.4	81.8504	63.5408
2014	9	9	11	38	19	0.3	3.6	0.79	95.2	81.8504	61.2442
2014	9	9	11	48	19	0.3	3.6	0.82	97.6	81.8504	63.0304
2014	9	9	11	58	19	0.3	3.6	0.79	97.1	81.8504	61.2441
2014	9	9	12	8	19	0.3	3.6	0.81	96.5	81.8504	62.7752
2014	9	9	12	18	19	0.3	3.6	0.75	95.3	81.8504	58.1819
2014	9	9	12	28	19	0.3	3.6	0.82	95.5	81.8504	63.2855
2014	9	9	12	38	19	0.3	3.6	0.81	95.6	81.8504	62.7751
2014	9	9	12	48	19	0.3	3.6	0.82	95.5	81.8504	63.2854
2014	9	9	12	58	19	0.3	3.6	0.82	95.5	81.8504	63.5406
2014	9	9	13	8	19	0.3	3.6	0.78	95.8	81.8504	60.7336
2014	9	9	13	18	19	0.3	3.6	0.8	95.2	81.8504	62.0094
2014	9	9	13	28	19	0.3	3.6	0.83	96.6	81.8504	64.0509
2014	9	9	13	38	19	0.3	3.6	0.77	94.9	81.8504	59.9679
2014	9	9	13	48	19	0.3	3.6	0.77	97.1	81.7848	59.4078
2014	9	9	13	58	19	0.3	3.6	0.83	96.1	81.8504	64.306
2014	9	9	14	8	19	0.3	3.6	0.77	95.9	81.8504	59.2024
2014	9	9	14	18	19	0.3	3.6	0.8	96.6	81.8504	61.499
2014	9	9	14	28	19	0.3	3.6	0.8	96.6	81.7848	61.9574
2014	9	9	14	38	19	0.3	3.6	0.82	95.5	81.7848	63.2322
2014	9	9	14	48	19	0.3	3.6	0.79	97.1	81.7848	61.1925
2014	9	9	14	58	19	0.3	3.6	0.82	96.4	81.7848	63.4872

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	15	8	19	0.3	3.6	0.79	96.7	81.7848	60.9375
2014	9	9	15	18	19	0.3	3.6	0.8	94.7	81.7848	61.9574
2014	9	9	15	28	19	0.3	3.6	0.8	97.5	81.7848	61.9574
2014	9	9	15	38	19	0.3	3.6	0.84	96.3	81.7848	64.507
2014	9	9	15	48	19	0.3	3.6	0.79	96.7	81.7848	60.6825
2014	9	9	15	58	19	0.3	3.6	0.77	96.9	81.7848	59.4077
2014	9	9	16	8	19	0.3	3.6	0.8	95.2	81.7848	61.7024
2014	9	9	16	18	19	0.3	3.6	0.82	95.3	81.7848	63.4871
2014	9	9	16	28	19	0.3	3.6	0.79	96.7	81.7848	61.1924
2014	9	9	16	38	19	0.3	3.6	0.79	97.2	81.7848	60.6825
2014	9	9	16	48	19	0.3	3.6	0.79	95.7	81.7192	61.3959
2014	9	9	16	58	19	0.3	3.6	0.79	95.5	81.7192	60.8864
2014	9	9	17	8	19	0.3	3.6	0.77	96.2	81.7192	59.1031
2014	9	9	17	18	19	0.3	3.6	0.79	94.5	81.7192	60.8864
2014	9	9	17	28	19	0.3	3.6	0.8	96.2	81.7192	61.3959
2014	9	9	17	38	19	0.3	3.6	0.77	97.1	81.7192	59.6126
2014	9	9	17	48	19	0.3	3.6	0.78	97.8	81.7192	59.8674
2014	9	9	17	58	19	0.3	3.6	0.79	93.4	81.7192	60.8864
2014	9	9	18	8	19	0.3	3.6	0.79	94.5	81.7192	61.3959
2014	9	9	18	18	19	0.3	3.6	0.78	98	81.7192	60.1221
2014	9	9	18	28	19	0.3	3.6	0.81	97.2	81.7848	62.7222
2014	9	9	18	38	19	0.3	3.6	0.79	95.5	81.7192	60.8864
2014	9	9	18	48	19	0.3	3.6	0.8	94.2	81.7848	62.2123
2014	9	9	18	58	19	0.3	3.6	0.8	94.5	81.7848	61.9574
2014	9	9	19	8	19	0.3	3.6	0.83	96.4	81.7848	63.7421
2014	9	9	19	18	19	0.3	3.6	0.79	98.1	81.7848	60.9375
2014	9	9	19	28	19	0.3	3.6	0.81	95.1	81.7848	62.4673
2014	9	9	19	38	19	0.3	3.6	0.78	97.5	81.7848	60.1726
2014	9	9	19	48	19	0.3	3.6	0.78	95.5	81.7848	60.6826
2014	9	9	19	58	19	0.3	3.6	0.8	94.5	81.7848	61.9574
2014	9	9	20	8	19	0.3	3.6	0.76	95.5	81.7848	58.6428
2014	9	9	20	18	19	0.3	3.6	0.8	94.7	81.7848	61.9574
2014	9	9	20	28	19	0.3	3.6	0.78	95.3	81.7848	60.4277
2014	9	9	20	38	19	0.3	3.6	0.79	97.9	81.7848	60.6826
2014	9	9	20	48	19	0.3	3.6	0.8	97.3	81.7848	61.4476
2014	9	9	20	58	19	0.3	3.6	0.77	96.9	81.7848	59.4078
2014	9	9	21	8	19	0.3	3.6	0.78	97.5	81.7848	60.4277
2014	9	9	21	18	19	0.3	3.6	0.82	98.1	81.7848	62.9774
2014	9	9	21	28	19	0.3	3.6	0.8	95.6	81.7848	61.9576
2014	9	9	21	38	19	0.3	3.6	0.82	95.5	81.7848	63.4874
2014	9	9	21	48	19	0.3	3.6	0.82	93.2	81.7848	63.4874
2014	9	9	21	58	19	0.3	3.6	0.8	95.9	81.7848	61.7027
2014	9	9	22	8	19	0.3	3.6	0.81	96.5	81.7848	62.7226
2014	9	9	22	18	19	0.3	3.6	0.78	98	81.7848	60.1729
2014	9	9	22	28	19	0.3	3.6	0.83	97.7	81.7848	64.2525
2014	9	9	22	38	19	0.3	3.6	0.82	98.1	81.7848	62.9776

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	9	22	48	19	0.3	3.6	0.8	95.9	81.7848	61.9578
2014	9	9	22	58	19	0.3	3.6	0.77	96.6	81.7848	59.4081
2014	9	9	23	8	19	0.3	3.6	0.81	93.9	81.7848	62.9777
2014	9	9	23	18	19	0.3	3.6	0.81	96.8	81.7848	62.2128
2014	9	9	23	28	19	0.3	3.6	0.79	95.5	81.7848	60.938
2014	9	9	23	38	19	0.3	3.6	0.81	97.2	81.7848	62.7228
2014	9	9	23	48	19	0.3	3.6	0.82	96.2	81.7848	63.2328
2014	9	9	23	58	19	0.3	3.6	0.8	96.3	81.7848	61.958
2014	9	10	0	8	19	0.3	3.6	0.84	98.1	81.7848	64.2527
2014	9	10	0	18	19	0.3	3.6	0.83	96.6	81.7848	63.9978
2014	9	10	0	28	19	0.3	3.6	0.81	96.8	81.7848	62.213
2014	9	10	0	38	19	0.3	3.6	0.83	96.6	81.7848	64.2528
2014	9	10	0	48	19	0.3	3.6	0.81	95.3	81.7848	62.978
2014	9	10	0	58	19	0.3	3.6	0.81	95.1	81.7848	62.468
2014	9	10	1	8	19	0.3	3.6	0.79	99	81.7848	60.9382
2014	9	10	1	18	19	0.3	3.6	0.78	93.6	81.7848	60.1733
2014	9	10	1	28	19	0.3	3.6	0.82	94.1	81.7848	63.743
2014	9	10	1	38	19	0.3	3.6	0.77	95.9	81.7848	59.1535
2014	9	10	1	48	19	0.3	3.6	0.79	95.7	81.7848	61.1933
2014	9	10	1	58	19	0.3	3.6	0.82	96.7	81.7848	62.9781
2014	9	10	2	8	19	0.3	3.6	0.79	99	81.7848	60.9384
2014	9	10	2	18	19	0.3	3.6	0.79	95.5	81.7848	60.9384
2014	9	10	2	28	19	0.3	3.6	0.76	96.9	81.7848	58.6437
2014	9	10	2	38	19	0.3	3.6	0.79	95.7	81.7848	61.1934
2014	9	10	2	48	19	0.3	3.6	0.79	97.9	81.8504	60.9896
2014	9	10	2	58	19	0.3	3.6	0.79	96.7	81.8504	60.9896
2014	9	10	3	8	19	0.3	3.6	0.8	95.4	81.7848	61.7035
2014	9	10	3	18	19	0.3	3.6	0.79	95.5	81.7848	60.9386
2014	9	10	3	28	19	0.3	3.6	0.83	96.4	81.7848	63.9983
2014	9	10	3	38	19	0.3	3.6	0.83	96.8	81.7848	63.9983
2014	9	10	3	48	19	0.3	3.6	0.78	95.5	81.7848	60.6837
2014	9	10	3	58	19	0.3	3.6	0.8	95.6	81.7848	61.9586
2014	9	10	4	8	19	0.3	3.6	0.83	93.6	81.8504	64.5624
2014	9	10	4	18	19	0.3	3.6	0.8	94.5	81.8504	62.0106
2014	9	10	4	28	19	0.3	3.6	0.81	97.5	81.8504	62.2658
2014	9	10	4	38	19	0.3	3.6	0.79	95.5	81.916	61.5517
2014	9	10	4	48	19	0.3	3.6	0.79	94.8	81.916	61.041
2014	9	10	4	58	19	0.3	3.6	0.83	94.1	81.916	64.3612
2014	9	10	5	8	19	0.3	3.6	0.8	96.8	81.9816	61.859
2014	9	10	5	18	19	0.3	3.6	0.78	95	81.9816	60.8365
2014	9	10	5	28	19	0.3	3.6	0.8	94.5	81.9816	62.1146
2014	9	10	5	38	19	0.3	3.6	0.8	94.2	82.0472	62.4224
2014	9	10	5	48	19	0.3	3.6	0.83	95	82.0472	64.4691
2014	9	10	5	58	19	0.3	3.6	0.84	98.6	82.0472	64.4691
2014	9	10	6	8	19	0.3	3.6	0.82	96.4	82.0472	63.4458
2014	9	10	6	18	19	0.3	3.6	0.8	95.6	82.0472	62.1667

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	6	28	19	0.3	3.6	0.79	94.7	82.0472	61.655
2014	9	10	6	38	19	0.3	3.6	0.8	94	82.0472	61.9109
2014	9	10	6	48	19	0.3	3.6	0.8	95.4	82.1129	61.9627
2014	9	10	6	58	19	0.3	3.6	0.76	94.7	82.1129	58.8901
2014	9	10	7	8	19	0.3	3.6	0.82	96.5	82.1129	63.2429
2014	9	10	7	18	19	0.3	3.6	0.83	95.9	82.1129	64.2671
2014	9	10	7	28	19	0.3	3.6	0.8	96.6	82.1129	62.2188
2014	9	10	7	38	19	0.3	3.6	0.8	96.4	82.1129	61.9628
2014	9	10	7	48	19	0.3	3.6	0.79	97.8	82.1129	61.4507
2014	9	10	7	58	19	0.3	3.6	0.79	97.4	82.1129	60.9386
2014	9	10	8	8	19	0.3	3.6	0.8	92.8	82.1129	62.4749
2014	9	10	8	18	19	0.3	3.6	0.8	96.9	82.1129	61.7067
2014	9	10	8	28	19	0.3	3.6	0.81	95.4	82.1785	62.7833
2014	9	10	8	38	19	0.3	3.6	0.81	95.6	82.1785	62.7832
2014	9	10	8	48	19	0.3	3.6	0.8	95.9	82.1785	62.527
2014	9	10	8	58	19	0.3	3.6	0.82	97.6	82.1785	63.2957
2014	9	10	9	8	19	0.3	3.6	0.75	96	82.1785	58.1706
2014	9	10	9	18	19	0.3	3.6	0.8	94.9	82.1785	62.2707
2014	9	10	9	28	19	0.3	3.6	0.81	96.5	82.1785	62.7832
2014	9	10	9	38	19	0.3	3.6	0.81	95.8	82.1785	63.0394
2014	9	10	9	48	19	0.3	3.6	0.83	95.9	82.1785	64.8332
2014	9	10	9	58	19	0.3	3.6	0.77	97.1	82.1785	59.708
2014	9	10	10	8	19	0.3	3.6	0.82	95.5	82.1785	64.0643
2014	9	10	10	18	19	0.3	3.6	0.8	95.2	82.1785	62.5268
2014	9	10	10	28	19	0.3	3.6	0.84	96.5	82.1785	65.3456
2014	9	10	10	38	19	0.3	3.6	0.79	96.5	82.1785	60.9892
2014	9	10	10	48	19	0.3	3.6	0.8	96.1	82.1785	62.0142
2014	9	10	10	58	19	0.3	3.6	0.79	96.5	82.1785	60.9891
2014	9	10	11	8	19	0.3	3.6	0.8	96.8	82.1785	62.0141
2014	9	10	11	18	19	0.3	3.6	0.81	96	82.1785	63.2953
2014	9	10	11	28	19	0.3	3.6	0.79	95.7	82.1785	61.2452
2014	9	10	11	38	19	0.3	3.6	0.82	96.4	82.1785	63.5515
2014	9	10	11	48	19	0.3	3.6	0.79	97.9	82.1785	60.9889
2014	9	10	11	58	19	0.3	3.6	0.81	96.5	82.1785	62.7827
2014	9	10	12	8	19	0.3	3.6	0.79	94.5	82.1785	61.2451
2014	9	10	12	18	19	0.3	3.6	0.78	95.1	82.1785	60.7326
2014	9	10	12	28	19	0.3	3.6	0.8	95.6	82.1785	62.5263
2014	9	10	12	38	19	0.3	3.6	0.84	97.2	82.1785	65.0888
2014	9	10	12	48	19	0.3	3.6	0.77	96.3	82.1785	59.9637
2014	9	10	12	58	19	0.3	3.6	0.77	97.3	82.1785	59.7074
2014	9	10	13	8	19	0.3	3.6	0.78	97.5	82.1129	60.6818
2014	9	10	13	18	19	0.3	3.6	0.79	96.9	82.1129	61.1938
2014	9	10	13	28	19	0.3	3.6	0.81	94.2	82.0472	63.1893
2014	9	10	13	38	19	0.3	3.6	0.79	96.2	81.9816	61.3472
2014	9	10	13	48	19	0.3	3.6	0.79	96.9	81.9816	61.3472
2014	9	10	13	58	19	0.3	3.6	0.84	96.5	81.9816	64.9258

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	14	8	19	0.3	3.6	0.78	95.3	81.916	60.2743
2014	9	10	14	18	19	0.3	3.6	0.76	97.4	81.916	58.7419
2014	9	10	14	28	19	0.3	3.6	0.81	97.6	81.916	62.8282
2014	9	10	14	38	19	0.3	3.6	0.79	95	81.916	61.2958
2014	9	10	14	48	19	0.3	3.6	0.79	96.2	81.8504	61.2445
2014	9	10	14	58	19	0.3	3.6	0.83	99.1	81.8504	64.0515
2014	9	10	15	8	19	0.3	3.6	0.83	96.8	81.916	64.1052
2014	9	10	15	18	19	0.3	3.6	0.78	96.3	81.8504	60.4789
2014	9	10	15	28	19	0.3	3.6	0.81	94.9	81.8504	63.0308
2014	9	10	15	38	19	0.3	3.6	0.81	94.2	81.8504	62.5204
2014	9	10	15	48	19	0.3	3.6	0.79	96.7	81.8504	61.2444
2014	9	10	15	58	19	0.3	3.6	0.81	96.5	81.8504	62.2652
2014	9	10	16	8	19	0.3	3.6	0.78	96.7	81.8504	60.4789
2014	9	10	16	18	19	0.3	3.6	0.8	95.6	81.8504	62.01
2014	9	10	16	28	19	0.3	3.6	0.8	97.6	81.8504	61.4996
2014	9	10	16	38	19	0.3	3.6	0.81	96.5	81.8504	62.7755
2014	9	10	16	48	19	0.3	3.6	0.81	94.6	81.8504	62.7755
2014	9	10	16	58	19	0.3	3.6	0.78	98.9	81.8504	60.2237
2014	9	10	17	8	19	0.3	3.6	0.82	93.9	81.7848	63.2329
2014	9	10	17	18	19	0.3	3.6	0.79	97.1	81.8504	61.2444
2014	9	10	17	28	19	0.3	3.6	0.78	96.1	81.8504	59.9685
2014	9	10	17	38	19	0.3	3.6	0.82	96.2	81.7848	63.2329
2014	9	10	17	48	19	0.3	3.6	0.76	96.7	81.7848	58.6434
2014	9	10	17	58	19	0.3	3.6	0.81	94.4	81.7848	62.9779
2014	9	10	18	8	19	0.3	3.6	0.77	96.6	81.8504	59.4581
2014	9	10	18	18	19	0.3	3.6	0.79	94.8	81.8504	61.2444
2014	9	10	18	28	19	0.3	3.6	0.81	96.5	81.8504	62.5203
2014	9	10	18	38	19	0.3	3.6	0.81	95.8	81.8504	62.5203
2014	9	10	18	48	19	0.3	3.6	0.83	93.9	81.8504	64.0514
2014	9	10	18	58	19	0.3	3.6	0.79	95.7	81.8504	61.4996
2014	9	10	19	8	19	0.3	3.6	0.81	95.6	81.8504	62.7755
2014	9	10	19	18	19	0.3	3.6	0.78	97.5	81.8504	60.4788
2014	9	10	19	28	19	0.3	3.6	0.8	96.2	81.8504	61.4996
2014	9	10	19	38	19	0.3	3.6	0.83	96.4	81.8504	64.0515
2014	9	10	19	48	19	0.3	3.6	0.81	97.6	81.8504	62.7755
2014	9	10	19	58	19	0.3	3.6	0.79	93.8	81.8504	61.4996
2014	9	10	20	8	19	0.3	3.6	0.78	96.7	81.8504	60.4789
2014	9	10	20	18	19	0.3	3.6	0.8	97.8	81.8504	61.4996
2014	9	10	20	28	19	0.3	3.6	0.78	94.8	81.8504	60.7341
2014	9	10	20	38	19	0.3	3.6	0.83	97.7	81.8504	63.7963
2014	9	10	20	48	19	0.3	3.6	0.79	95.7	81.8504	61.4996
2014	9	10	20	58	19	0.3	3.6	0.81	97.6	81.8504	62.7756
2014	9	10	21	8	19	0.3	3.6	0.8	96.1	81.8504	61.7548
2014	9	10	21	18	19	0.3	3.6	0.81	96.7	81.8504	62.7756
2014	9	10	21	28	19	0.3	3.6	0.8	96.4	81.8504	61.4997
2014	9	10	21	38	19	0.3	3.6	0.8	94.5	81.916	62.3174

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	10	21	48	19	0.3	3.6	0.78	97	81.916	60.2742
2014	9	10	21	58	19	0.3	3.6	0.81	94.4	81.916	62.8282
2014	9	10	22	8	19	0.3	3.6	0.77	97.9	81.916	58.9973
2014	9	10	22	18	19	0.3	3.6	0.81	97.6	81.916	62.8283
2014	9	10	22	28	19	0.3	3.6	0.76	97.2	81.916	58.7419
2014	9	10	22	38	19	0.3	3.6	0.8	95	81.916	61.8067
2014	9	10	22	48	19	0.3	3.6	0.81	95.1	81.9816	62.8809
2014	9	10	22	58	19	0.3	3.6	0.81	94.2	81.9816	62.6253
2014	9	10	23	8	19	0.3	3.6	0.8	95.7	82.0472	61.9102
2014	9	10	23	18	19	0.3	3.6	0.81	95.4	82.1129	62.73
2014	9	10	23	28	19	0.3	3.6	0.76	93.5	82.1129	59.1455
2014	9	10	23	38	19	0.3	3.6	0.79	98.6	82.1129	61.1938
2014	9	10	23	48	19	0.3	3.6	0.81	94.4	82.1129	63.2422
2014	9	10	23	58	19	0.3	3.6	0.82	95.7	82.1129	64.0103
2014	9	11	0	8	19	0.3	3.6	0.81	95.3	82.1785	63.0387
2014	9	11	0	18	19	0.3	3.6	0.82	95.5	82.1785	63.8075
2014	9	11	0	28	19	0.3	3.6	0.78	96.3	82.1785	60.7325
2014	9	11	0	38	19	0.3	3.6	0.82	95	82.1785	63.8076
2014	9	11	0	48	19	0.3	3.6	0.81	97.7	82.1785	62.5263
2014	9	11	0	58	19	0.3	3.6	0.81	97.2	82.1785	62.5263
2014	9	11	1	8	19	0.3	3.6	0.8	95.4	82.1785	62.5264
2014	9	11	1	18	19	0.3	3.6	0.8	93.3	82.1785	62.0139
2014	9	11	1	28	19	0.3	3.6	0.8	96.6	82.1785	61.7576
2014	9	11	1	38	19	0.3	3.6	0.8	96.6	82.1785	61.7576
2014	9	11	1	48	19	0.3	3.6	0.77	95.6	82.1785	59.9639
2014	9	11	1	58	19	0.3	3.6	0.78	95.8	82.2441	60.7833
2014	9	11	2	8	19	0.3	3.6	0.8	94	82.2441	62.3222
2014	9	11	2	18	19	0.3	3.6	0.83	95.9	82.2441	64.8869
2014	9	11	2	28	19	0.3	3.6	0.82	95.3	82.2441	63.6046
2014	9	11	2	38	19	0.3	3.6	0.8	94.7	82.2441	62.3222
2014	9	11	2	48	19	0.3	3.6	0.79	95.5	82.2441	61.2964
2014	9	11	2	58	19	0.3	3.6	0.8	95.4	82.2441	62.3223
2014	9	11	3	8	19	0.3	3.6	0.79	95.7	82.2441	61.5529
2014	9	11	3	18	19	0.3	3.6	0.81	97	82.2441	62.5788
2014	9	11	3	28	19	0.3	3.6	0.79	98.6	82.2441	61.04
2014	9	11	3	38	19	0.3	3.6	0.76	98.9	82.2441	58.9883
2014	9	11	3	48	19	0.3	3.6	0.79	96.7	82.2441	61.2965
2014	9	11	3	58	19	0.3	3.6	0.79	96.9	82.2441	61.553
2014	9	11	4	8	19	0.3	3.6	0.78	98	82.2441	60.2707
2014	9	11	4	18	19	0.3	3.6	0.81	97.2	82.2441	62.8354
2014	9	11	4	28	19	0.3	3.6	0.84	95.4	82.2441	65.4001
2014	9	11	4	38	19	0.3	3.6	0.79	96	82.2441	61.0402
2014	9	11	4	48	19	0.3	3.6	0.77	95.4	82.2441	59.7578
2014	9	11	4	58	19	0.3	3.6	0.8	95	82.2441	62.0661
2014	9	11	5	8	19	0.3	3.6	0.82	99.2	82.2441	63.092
2014	9	11	5	18	19	0.3	3.6	0.77	96.2	82.2441	59.5014

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	5	28	19	0.3	3.6	0.79	96	82.2441	61.2967
2014	9	11	5	38	19	0.3	3.6	0.84	95.6	82.2441	65.6568
2014	9	11	5	48	19	0.3	3.6	0.85	96.5	82.2441	65.6568
2014	9	11	5	58	19	0.3	3.6	0.8	95.9	82.2441	62.0662
2014	9	11	6	8	19	0.3	3.6	0.83	96.8	82.2441	64.631
2014	9	11	6	18	19	0.3	3.6	0.8	96.2	82.2441	61.8098
2014	9	11	6	28	19	0.3	3.6	0.83	95.2	82.2441	64.631
2014	9	11	6	38	19	0.3	3.6	0.79	96.4	82.3097	61.348
2014	9	11	6	48	19	0.3	3.6	0.81	94.9	82.2441	63.0922
2014	9	11	6	58	19	0.3	3.6	0.83	93.9	82.3097	64.4283
2014	9	11	7	8	19	0.3	3.6	0.85	96.9	82.3097	66.2251
2014	9	11	7	18	19	0.3	3.6	0.78	95.5	82.3097	61.0914
2014	9	11	7	28	19	0.3	3.6	0.82	94.2	82.3097	63.6582
2014	9	11	7	38	19	0.3	3.6	0.81	94.6	82.3097	63.1449
2014	9	11	7	48	19	0.3	3.6	0.85	95.3	82.3097	66.2251
2014	9	11	7	58	19	0.3	3.6	0.81	98.4	82.3097	62.3748
2014	9	11	8	8	19	0.3	3.6	0.81	95.8	82.3097	63.4016
2014	9	11	8	18	19	0.3	3.6	0.79	95.5	82.3097	61.8615
2014	9	11	8	28	19	0.3	3.6	0.82	96.7	82.3097	63.6583
2014	9	11	8	38	19	0.3	3.6	0.78	94.6	82.3097	60.578
2014	9	11	8	48	19	0.3	3.6	0.78	94.6	82.3097	61.0914
2014	9	11	8	58	19	0.3	3.6	0.8	99	82.3097	61.8614
2014	9	11	9	8	19	0.3	3.6	0.76	97.2	82.3097	59.0378
2014	9	11	9	18	19	0.3	3.6	0.8	95.4	82.3097	62.3747
2014	9	11	9	28	19	0.3	3.6	0.82	97.8	82.3097	63.6582
2014	9	11	9	38	19	0.3	3.6	0.81	97.6	82.3097	63.1448
2014	9	11	9	48	19	0.3	3.6	0.76	96	82.3097	59.0378
2014	9	11	9	58	19	0.3	3.6	0.78	96.8	82.3097	60.5779
2014	9	11	10	8	19	0.3	3.6	0.78	95.1	82.3097	60.8345
2014	9	11	10	18	19	0.3	3.6	0.79	95	82.3097	61.6045
2014	9	11	10	28	19	0.3	3.6	0.78	93.9	82.3097	60.8345
2014	9	11	10	38	19	0.3	3.6	0.8	97.3	82.3097	62.3745
2014	9	11	10	48	19	0.3	3.6	0.77	97.8	82.3097	60.0643
2014	9	11	10	58	19	0.3	3.6	0.82	93.9	82.3097	63.9146
2014	9	11	11	8	19	0.3	3.6	0.83	95.7	82.3097	64.6846
2014	9	11	11	18	19	0.3	3.6	0.75	97	82.3097	58.2674
2014	9	11	11	28	19	0.3	3.6	0.79	94.3	82.3097	61.3476
2014	9	11	11	38	19	0.3	3.6	0.81	95.4	82.3097	62.8877
2014	9	11	11	48	19	0.3	3.6	0.82	96.7	82.3097	63.401
2014	9	11	11	58	19	0.3	3.6	0.85	96.4	82.3097	65.9678
2014	9	11	12	8	19	0.3	3.6	0.79	95.2	82.3097	61.8609
2014	9	11	12	18	19	0.3	3.6	0.8	95.4	82.3097	62.6309
2014	9	11	12	28	19	0.3	3.6	0.84	96.1	82.3097	65.1977
2014	9	11	12	38	19	0.3	3.6	0.78	96.5	82.3097	60.5774
2014	9	11	12	48	19	0.3	3.6	0.82	96.4	82.3097	63.6575
2014	9	11	12	58	19	0.3	3.6	0.79	96.2	82.3097	61.3473

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	13	8	19	0.3	3.6	0.81	94.9	82.3097	62.8874
2014	9	11	13	18	19	0.3	3.6	0.85	97.1	82.2441	65.9127
2014	9	11	13	28	19	0.3	3.6	0.76	94	82.2441	58.988
2014	9	11	13	38	19	0.3	3.6	0.81	97.7	82.2441	62.5785
2014	9	11	13	48	19	0.3	3.6	0.8	96.4	82.2441	61.8091
2014	9	11	13	58	19	0.3	3.6	0.78	98	82.2441	60.2702
2014	9	11	14	8	19	0.3	3.6	0.81	93.7	82.2441	62.8349
2014	9	11	14	18	19	0.3	3.6	0.79	95.9	82.2441	61.5526
2014	9	11	14	28	19	0.3	3.6	0.84	95.8	82.1785	65.0888
2014	9	11	14	38	19	0.3	3.6	0.79	93.6	82.1785	61.5012
2014	9	11	14	48	19	0.3	3.6	0.8	95.6	82.1785	62.5262
2014	9	11	14	58	19	0.3	3.6	0.81	95.5	82.1785	63.295
2014	9	11	15	8	19	0.3	3.6	0.8	97.3	82.1785	62.0137
2014	9	11	15	18	19	0.3	3.6	0.84	97	82.1785	65.0887
2014	9	11	15	28	19	0.3	3.6	0.79	94.3	82.1785	61.5011
2014	9	11	15	38	19	0.3	3.6	0.84	95.6	82.1129	65.5465
2014	9	11	15	48	19	0.3	3.6	0.82	95.9	82.1129	64.0102
2014	9	11	15	58	19	0.3	3.6	0.86	97.7	82.0472	66.2592
2014	9	11	16	8	19	0.3	3.6	0.8	96.6	81.9816	61.8585
2014	9	11	16	18	19	0.3	3.6	0.79	96.9	81.9816	61.0916
2014	9	11	16	28	19	0.3	3.6	0.79	97.9	81.9816	61.0916
2014	9	11	16	38	19	0.3	3.6	0.78	96.3	81.916	60.5297
2014	9	11	16	48	19	0.3	3.6	0.8	94.9	81.916	62.3175
2014	9	11	16	58	19	0.3	3.6	0.8	95.4	81.916	62.3175
2014	9	11	17	8	19	0.3	3.6	0.81	96.5	81.916	62.3175
2014	9	11	17	18	19	0.3	3.6	0.75	95.2	81.916	58.4865
2014	9	11	17	28	19	0.3	3.6	0.8	97.8	81.916	61.8067
2014	9	11	17	38	19	0.3	3.6	0.8	95.4	81.916	62.3175
2014	9	11	17	48	19	0.3	3.6	0.8	94.2	81.916	62.0621
2014	9	11	17	58	19	0.3	3.6	0.78	95.5	81.916	60.5297
2014	9	11	18	8	19	0.3	3.6	0.81	96	81.916	63.0837
2014	9	11	18	18	19	0.3	3.6	0.8	95.2	81.916	62.0621
2014	9	11	18	28	19	0.3	3.6	0.78	96.3	81.916	60.0189
2014	9	11	18	38	19	0.3	3.6	0.81	97.7	81.916	62.3175
2014	9	11	18	48	19	0.3	3.6	0.81	96	81.916	63.0837
2014	9	11	18	58	19	0.3	3.6	0.8	95.4	81.916	62.0621
2014	9	11	19	8	19	0.3	3.6	0.8	93.8	81.916	62.3175
2014	9	11	19	18	19	0.3	3.6	0.78	94.3	81.9816	60.836
2014	9	11	19	28	19	0.3	3.6	0.81	96.1	81.916	62.3175
2014	9	11	19	38	19	0.3	3.6	0.84	96.3	81.9816	64.9258
2014	9	11	19	48	19	0.3	3.6	0.81	98.4	82.0472	62.6776
2014	9	11	19	58	19	0.3	3.6	0.8	96.4	82.0472	61.6543
2014	9	11	20	8	19	0.3	3.6	0.78	98.7	82.0472	60.1194
2014	9	11	20	18	19	0.3	3.6	0.79	96.2	82.0472	61.1427
2014	9	11	20	28	19	0.3	3.6	0.81	97.4	82.1129	62.73
2014	9	11	20	38	19	0.3	3.6	0.8	96.6	82.1129	62.2179

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	11	20	48	19	0.3	3.6	0.76	95.4	82.1129	59.1455
2014	9	11	20	58	19	0.3	3.6	0.78	97.2	82.1129	60.4257
2014	9	11	21	8	19	0.3	3.6	0.81	97.4	82.1785	63.0387
2014	9	11	21	18	19	0.3	3.6	0.82	96.6	82.1785	63.8075
2014	9	11	21	28	19	0.3	3.6	0.8	96.6	82.1785	62.0137
2014	9	11	21	38	19	0.3	3.6	0.83	97.1	82.1785	64.0637
2014	9	11	21	48	19	0.3	3.6	0.8	97.8	82.1785	62.0137
2014	9	11	21	58	19	0.3	3.6	0.8	95.2	82.1785	62.27
2014	9	11	22	8	19	0.3	3.6	0.85	95.8	82.1785	65.8576
2014	9	11	22	18	19	0.3	3.6	0.82	96.7	82.1785	63.295
2014	9	11	22	28	19	0.3	3.6	0.79	95.9	82.1785	61.7575
2014	9	11	22	38	19	0.3	3.6	0.83	95.2	82.1785	64.8326
2014	9	11	22	48	19	0.3	3.6	0.83	94.1	82.2441	64.6302
2014	9	11	22	58	19	0.3	3.6	0.84	96.5	82.2441	65.3996
2014	9	11	23	8	19	0.3	3.6	0.8	95.9	82.2441	62.322
2014	9	11	23	18	19	0.3	3.6	0.77	94.7	82.2441	59.7573
2014	9	11	23	28	19	0.3	3.6	0.81	92.3	82.2441	63.0915
2014	9	11	23	38	19	0.3	3.6	0.8	95.7	82.2441	62.0656
2014	9	11	23	48	19	0.3	3.6	0.86	96.6	82.2441	66.9385
2014	9	11	23	58	19	0.3	3.6	0.78	93.6	82.2441	60.5268
2014	9	12	0	8	19	0.3	3.6	0.82	97.6	82.2441	63.6045
2014	9	12	0	18	19	0.3	3.6	0.82	94.1	82.2441	63.861
2014	9	12	0	28	19	0.3	3.6	0.82	95.3	82.2441	63.861
2014	9	12	0	38	19	0.3	3.6	0.82	95.8	82.2441	63.6045
2014	9	12	0	48	19	0.3	3.6	0.8	97	82.2441	62.3222
2014	9	12	0	58	19	0.3	3.6	0.78	95.3	82.3097	61.0907
2014	9	12	1	8	19	0.3	3.6	0.81	95.4	82.3097	62.8875
2014	9	12	1	18	19	0.3	3.6	0.81	94.9	82.3097	63.4009
2014	9	12	1	28	19	0.3	3.6	0.83	95.4	82.2441	64.887
2014	9	12	1	38	19	0.3	3.6	0.76	96.2	82.3097	59.294
2014	9	12	1	48	19	0.3	3.6	0.83	97.1	82.3097	64.171
2014	9	12	1	58	19	0.3	3.6	0.77	96.6	82.3097	59.8074
2014	9	12	2	8	19	0.3	3.6	0.83	97.9	82.3097	64.4278
2014	9	12	2	18	19	0.3	3.6	0.76	98	82.3097	58.524
2014	9	12	2	28	19	0.3	3.6	0.82	96.5	82.3097	63.4011
2014	9	12	2	38	19	0.3	3.6	0.8	96.8	82.3097	62.1177
2014	9	12	2	48	19	0.3	3.6	0.79	95.2	82.3097	61.861
2014	9	12	2	58	19	0.3	3.6	0.82	95.5	82.3097	63.6578
2014	9	12	3	8	19	0.3	3.6	0.77	97.8	82.3097	59.8076
2014	9	12	3	18	19	0.3	3.6	0.83	96.3	82.3097	64.6846
2014	9	12	3	28	19	0.3	3.6	0.82	98.3	82.3097	63.6579
2014	9	12	3	38	19	0.3	3.6	0.82	97.3	82.3097	63.9146
2014	9	12	3	48	19	0.3	3.6	0.81	98	82.3097	62.3745
2014	9	12	3	58	19	0.3	3.6	0.83	95.2	82.3097	64.6847
2014	9	12	4	8	19	0.3	3.6	0.83	94.6	82.3097	64.428
2014	9	12	4	18	19	0.3	3.6	0.82	96.4	82.3097	63.9147

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	4	28	19	0.3	3.6	0.77	95.6	82.3097	60.0644
2014	9	12	4	38	19	0.3	3.6	0.79	94.8	82.3097	61.3479
2014	9	12	4	48	19	0.3	3.6	0.81	95.1	82.3097	63.4014
2014	9	12	4	58	19	0.3	3.6	0.84	95.2	82.3097	65.4549
2014	9	12	5	8	19	0.3	3.6	0.81	97.7	82.3097	62.888
2014	9	12	5	18	19	0.3	3.6	0.82	95.5	82.3097	64.1715
2014	9	12	5	28	19	0.3	3.6	0.8	99	82.3097	61.8613
2014	9	12	5	38	19	0.3	3.6	0.78	93.4	82.3097	60.8346
2014	9	12	5	48	19	0.3	3.6	0.87	96.9	82.3097	67.7652
2014	9	12	5	58	19	0.3	3.6	0.83	97	82.3097	64.4283
2014	9	12	6	8	19	0.3	3.6	0.8	96.6	82.3097	62.3748
2014	9	12	6	18	19	0.3	3.6	0.81	95.6	82.3097	62.8882
2014	9	12	6	28	19	0.3	3.6	0.79	96.7	82.3097	61.6048
2014	9	12	6	38	19	0.3	3.6	0.78	96.8	82.3753	60.6285
2014	9	12	6	48	19	0.3	3.6	0.81	95.8	82.3097	63.4016
2014	9	12	6	58	19	0.3	3.6	0.81	97.6	82.3753	63.1975
2014	9	12	7	8	19	0.3	3.6	0.81	97	82.3753	62.6837
2014	9	12	7	18	19	0.3	3.6	0.8	97.8	82.3753	61.913
2014	9	12	7	28	19	0.3	3.6	0.8	96.6	82.3753	62.17
2014	9	12	7	38	19	0.3	3.6	0.78	94.3	82.3753	60.8855
2014	9	12	7	48	19	0.3	3.6	0.82	96.5	82.3753	63.4545
2014	9	12	7	58	19	0.3	3.6	0.76	96.7	82.3753	59.3441
2014	9	12	8	8	19	0.3	3.6	0.75	97.5	82.3753	58.3165
2014	9	12	8	18	19	0.3	3.6	0.84	98.1	82.3753	65.2528
2014	9	12	8	28	19	0.3	3.6	0.78	95.5	82.3753	60.8855
2014	9	12	8	38	19	0.3	3.6	0.79	95.2	82.3753	61.913
2014	9	12	8	48	19	0.3	3.6	0.81	95.3	82.3753	63.1975
2014	9	12	8	58	19	0.3	3.6	0.82	96.4	82.3753	63.9682
2014	9	12	9	8	19	0.3	3.6	0.81	95.3	82.3753	63.1975
2014	9	12	9	18	19	0.3	3.6	0.78	96.3	82.3753	60.6285
2014	9	12	9	28	19	0.3	3.6	0.8	95.9	82.3753	62.1698
2014	9	12	9	38	19	0.3	3.6	0.77	95.9	82.3753	59.6008
2014	9	12	9	48	19	0.3	3.6	0.8	95.9	82.3753	62.6836
2014	9	12	9	58	19	0.3	3.6	0.76	96.9	82.3753	59.3439
2014	9	12	10	8	19	0.3	3.6	0.81	97.5	82.3753	62.6835
2014	9	12	10	18	19	0.3	3.6	0.83	96.6	82.3753	64.2249
2014	9	12	10	28	19	0.3	3.6	0.82	96.9	82.3753	63.968
2014	9	12	10	38	19	0.3	3.6	0.79	98.4	82.3753	60.8851
2014	9	12	10	48	19	0.3	3.6	0.78	96.3	82.3753	60.8851
2014	9	12	10	58	19	0.3	3.6	0.77	95.9	82.3753	59.6006
2014	9	12	11	8	19	0.3	3.6	0.81	98.2	82.3753	62.6833
2014	9	12	11	18	19	0.3	3.6	0.78	96.8	82.3753	60.3712
2014	9	12	11	28	19	0.3	3.6	0.78	97.7	82.3753	60.6281
2014	9	12	11	38	19	0.3	3.6	0.8	97.3	82.3753	62.1694
2014	9	12	11	48	19	0.3	3.6	0.81	95.8	82.3753	63.197
2014	9	12	11	58	19	0.3	3.6	0.77	96.4	82.3753	59.8573

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	12	8	19	0.3	3.6	0.81	96.3	82.3753	62.6831
2014	9	12	12	18	19	0.3	3.6	0.8	97.5	82.3753	62.4262
2014	9	12	12	28	19	0.3	3.6	0.8	95.9	82.3753	62.4262
2014	9	12	12	38	19	0.3	3.6	0.83	96.6	82.3753	64.2244
2014	9	12	12	48	19	0.3	3.6	0.77	95.9	82.3753	59.6002
2014	9	12	12	58	19	0.3	3.6	0.82	96.4	82.3753	63.7106
2014	9	12	13	8	19	0.3	3.6	0.77	96.6	82.3753	59.8571
2014	9	12	13	18	19	0.3	3.6	0.74	96.8	82.3753	57.8019
2014	9	12	13	28	19	0.3	3.6	0.74	97.9	82.3753	57.545
2014	9	12	13	38	19	0.3	3.6	0.79	98.3	82.3097	61.3473
2014	9	12	13	48	19	0.3	3.6	0.81	95.4	82.3097	62.8874
2014	9	12	13	58	19	0.3	3.6	0.78	98.3	82.3097	60.0639
2014	9	12	14	8	19	0.3	3.6	0.78	96.7	82.3097	60.8339
2014	9	12	14	18	19	0.3	3.6	0.81	97	82.3097	63.144
2014	9	12	14	28	19	0.3	3.6	0.8	97.6	82.3097	61.8606
2014	9	12	14	38	19	0.3	3.6	0.78	96	82.3097	60.5771
2014	9	12	14	48	19	0.3	3.6	0.84	96	82.3097	65.7108
2014	9	12	14	58	19	0.3	3.6	0.75	98.3	82.2441	57.7055
2014	9	12	15	8	19	0.3	3.6	0.78	97	82.3097	60.3204
2014	9	12	15	18	19	0.3	3.6	0.81	97	82.3097	62.6306
2014	9	12	15	28	19	0.3	3.6	0.79	96.4	82.2441	61.5525
2014	9	12	15	38	19	0.3	3.6	0.75	96.1	82.2441	57.9619
2014	9	12	15	48	19	0.3	3.6	0.76	96.7	82.2441	59.2443
2014	9	12	15	58	19	0.3	3.6	0.76	95.9	82.2441	59.2443
2014	9	12	16	8	19	0.3	3.6	0.79	95	82.2441	61.296
2014	9	12	16	18	19	0.3	3.6	0.81	96.5	82.2441	62.8348
2014	9	12	16	28	19	0.3	3.6	0.79	95.9	82.1785	61.5012
2014	9	12	16	38	19	0.3	3.6	0.78	98	82.1785	60.2199
2014	9	12	16	48	19	0.3	3.6	0.81	95.4	82.1785	62.7824
2014	9	12	16	58	19	0.3	3.6	0.79	96.7	82.1785	61.2449
2014	9	12	17	8	19	0.3	3.6	0.79	98.8	82.1785	61.2449
2014	9	12	17	18	19	0.3	3.6	0.83	96.4	82.1129	64.0103
2014	9	12	17	28	19	0.3	3.6	0.78	95.6	82.1785	60.4761
2014	9	12	17	38	19	0.3	3.6	0.8	97.1	82.1785	61.7574
2014	9	12	17	48	19	0.3	3.6	0.81	93.7	82.1785	62.7824
2014	9	12	17	58	19	0.3	3.6	0.81	94.9	82.1785	62.7824
2014	9	12	18	8	19	0.3	3.6	0.78	96.8	82.1785	60.2199
2014	9	12	18	18	19	0.3	3.6	0.76	96.2	82.1785	59.1949
2014	9	12	18	28	19	0.3	3.6	0.82	98	82.1785	63.8074
2014	9	12	18	38	19	0.3	3.6	0.79	95.9	82.1785	61.5011
2014	9	12	18	48	19	0.3	3.6	0.81	94.9	82.1785	63.2949
2014	9	12	18	58	19	0.3	3.6	0.8	96.6	82.1785	61.7574
2014	9	12	19	8	19	0.3	3.6	0.79	98.1	82.1785	61.2449
2014	9	12	19	18	19	0.3	3.6	0.82	95.3	82.1785	63.5512
2014	9	12	19	28	19	0.3	3.6	0.85	96.9	82.1785	65.8575
2014	9	12	19	38	19	0.3	3.6	0.79	96.9	82.1785	61.2449

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	12	19	48	19	0.3	3.6	0.82	97.2	82.1785	63.2949
2014	9	12	19	58	19	0.3	3.6	0.78	94.8	82.1785	60.4761
2014	9	12	20	8	19	0.3	3.6	0.75	96.3	82.1785	57.9136
2014	9	12	20	18	19	0.3	3.6	0.83	97.3	82.1785	64.0637
2014	9	12	20	28	19	0.3	3.6	0.81	95.3	82.1785	63.295
2014	9	12	20	38	19	0.3	3.6	0.82	96.4	82.1785	63.8075
2014	9	12	20	48	19	0.3	3.6	0.82	97.5	82.1785	63.8075
2014	9	12	20	58	19	0.3	3.6	0.79	95.5	82.1785	61.2449
2014	9	12	21	8	19	0.3	3.6	0.82	96.4	82.1785	63.5513
2014	9	12	21	18	19	0.3	3.6	0.84	96.1	82.1785	65.0888
2014	9	12	21	28	19	0.3	3.6	0.79	96.5	82.1785	60.9887
2014	9	12	21	38	19	0.3	3.6	0.77	97.8	82.1785	59.7075
2014	9	12	21	48	19	0.3	3.6	0.8	99.5	82.1785	61.245
2014	9	12	21	58	19	0.3	3.6	0.82	94.6	82.1785	63.8076
2014	9	12	22	8	19	0.3	3.6	0.81	96.5	82.2441	62.8349
2014	9	12	22	18	19	0.3	3.6	0.82	94.6	82.2441	63.6044
2014	9	12	22	28	19	0.3	3.6	0.8	95.4	82.2441	62.322
2014	9	12	22	38	19	0.3	3.6	0.79	95.5	82.2441	61.8091
2014	9	12	22	48	19	0.3	3.6	0.8	96.6	82.2441	61.8091
2014	9	12	22	58	19	0.3	3.6	0.81	95.3	82.2441	63.0915
2014	9	12	23	8	19	0.3	3.6	0.82	98.6	82.2441	63.0915
2014	9	12	23	18	19	0.3	3.6	0.79	96.2	82.2441	61.2962
2014	9	12	23	28	19	0.3	3.6	0.82	97.5	82.2441	63.8609
2014	9	12	23	38	19	0.3	3.6	0.81	95.6	82.2441	62.835
2014	9	12	23	48	19	0.3	3.6	0.8	99	82.2441	61.5527
2014	9	12	23	58	19	0.3	3.6	0.84	97.2	82.2441	64.8868
2014	9	13	0	8	19	0.3	3.6	0.81	97	82.2441	62.5786
2014	9	13	0	18	19	0.3	3.6	0.79	96.7	82.2441	61.2963
2014	9	13	0	28	19	0.3	3.6	0.78	95.6	82.2441	60.5269
2014	9	13	0	38	19	0.3	3.6	0.83	97.3	82.2441	64.1175
2014	9	13	0	48	19	0.3	3.6	0.82	97.2	82.2441	63.3481
2014	9	13	0	58	19	0.3	3.6	0.8	96.1	82.2441	62.3222
2014	9	13	1	8	19	0.3	3.6	0.78	97	82.2441	60.7834
2014	9	13	1	18	19	0.3	3.6	0.8	95.4	82.3097	62.1175
2014	9	13	1	28	19	0.3	3.6	0.81	94	82.2441	63.0917
2014	9	13	1	38	19	0.3	3.6	0.77	95.4	82.3097	59.8074
2014	9	13	1	48	19	0.3	3.6	0.82	96.2	82.3097	63.6577
2014	9	13	1	58	19	0.3	3.6	0.78	95.5	82.2441	61.04
2014	9	13	2	8	19	0.3	3.6	0.79	96.5	82.2441	61.04
2014	9	13	2	18	19	0.3	3.6	0.82	96.4	82.3097	63.9144
2014	9	13	2	28	19	0.3	3.6	0.82	98.5	82.3097	63.6577
2014	9	13	2	38	19	0.3	3.6	0.79	96.7	82.3097	61.0909
2014	9	13	2	48	19	0.3	3.6	0.79	95.5	82.3097	61.6043
2014	9	13	2	58	19	0.3	3.6	0.83	95.7	82.3097	64.4279
2014	9	13	3	8	19	0.3	3.6	0.8	96.8	82.3097	62.1177
2014	9	13	3	18	19	0.3	3.6	0.79	93.3	82.3097	61.6044

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	3	28	19	0.3	3.6	0.8	95.2	82.2441	62.579
2014	9	13	3	38	19	0.3	3.6	0.81	96.3	82.3097	63.1445
2014	9	13	3	48	19	0.3	3.6	0.8	97.3	82.2441	62.3225
2014	9	13	3	58	19	0.3	3.6	0.79	94.3	82.3097	61.6045
2014	9	13	4	8	19	0.3	3.6	0.82	95.3	82.3097	63.658
2014	9	13	4	18	19	0.3	3.6	0.83	96.8	82.3097	64.6847
2014	9	13	4	28	19	0.3	3.6	0.79	94.8	82.2441	61.2967
2014	9	13	4	38	19	0.3	3.6	0.78	97.5	82.3097	60.3211
2014	9	13	4	48	19	0.3	3.6	0.8	97.1	82.3097	61.8612
2014	9	13	4	58	19	0.3	3.6	0.81	96.8	82.3097	62.888
2014	9	13	5	8	19	0.3	3.6	0.78	95.6	82.2441	60.5274
2014	9	13	5	18	19	0.3	3.6	0.79	96.7	82.2441	61.2968
2014	9	13	5	28	19	0.3	3.6	0.83	96.3	82.3097	64.6848
2014	9	13	5	38	19	0.3	3.6	0.77	96.9	82.3097	59.5511
2014	9	13	5	48	19	0.3	3.6	0.83	96.1	82.3097	64.4282
2014	9	13	5	58	19	0.3	3.6	0.81	96.5	82.3097	62.6314
2014	9	13	6	8	19	0.3	3.6	0.8	96.2	82.3097	61.8614
2014	9	13	6	18	19	0.3	3.6	0.78	96.3	82.3097	60.8346
2014	9	13	6	28	19	0.3	3.6	0.79	94.3	82.3097	61.8614
2014	9	13	6	38	19	0.3	3.6	0.78	95.6	82.3097	60.578
2014	9	13	6	48	19	0.3	3.6	0.8	96.6	82.3097	61.8614
2014	9	13	6	58	19	0.3	3.6	0.83	94.7	82.3097	64.9417
2014	9	13	7	8	19	0.3	3.6	0.8	94.9	82.3097	62.3749
2014	9	13	7	18	19	0.3	3.6	0.84	95.2	82.3097	65.1984
2014	9	13	7	28	19	0.3	3.6	0.77	96.8	82.3097	60.0647
2014	9	13	7	38	19	0.3	3.6	0.81	96	82.3097	63.145
2014	9	13	7	48	19	0.3	3.6	0.81	96	82.3097	63.145
2014	9	13	7	58	19	0.3	3.6	0.79	95.5	82.3097	61.3482
2014	9	13	8	8	19	0.3	3.6	0.81	95.4	82.3097	62.8883
2014	9	13	8	18	19	0.3	3.6	0.77	95.2	82.3097	59.808
2014	9	13	8	28	19	0.3	3.6	0.77	95.4	82.3097	60.0647
2014	9	13	8	38	19	0.3	3.6	0.87	95.4	82.3097	68.022
2014	9	13	8	48	19	0.3	3.6	0.8	96.8	82.3097	62.3748
2014	9	13	8	58	19	0.3	3.6	0.81	95.8	82.3097	63.4016
2014	9	13	9	8	19	0.3	3.6	0.79	96.7	82.3097	61.3481
2014	9	13	9	18	19	0.3	3.6	0.77	96.8	82.3097	60.0646
2014	9	13	9	28	19	0.3	3.6	0.78	95.1	82.3097	60.8346
2014	9	13	9	38	19	0.3	3.6	0.79	96	82.3097	61.348
2014	9	13	9	48	19	0.3	3.6	0.8	96.1	82.3097	62.3747
2014	9	13	9	58	19	0.3	3.6	0.82	96.2	82.3097	63.4014
2014	9	13	10	8	19	0.3	3.6	0.78	96.3	82.3753	60.8852
2014	9	13	10	18	19	0.3	3.6	0.81	95.3	82.3097	63.4014
2014	9	13	10	28	19	0.3	3.6	0.84	95.8	82.3097	65.4548
2014	9	13	10	38	19	0.3	3.6	0.77	98.1	82.3097	59.2943
2014	9	13	10	48	19	0.3	3.6	0.77	95.6	82.3097	60.321
2014	9	13	10	58	19	0.3	3.6	0.83	93.6	82.3753	64.9954

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	11	8	19	0.3	3.6	0.81	93.7	82.3097	63.4012
2014	9	13	11	18	19	0.3	3.6	0.81	96.5	82.3097	62.6311
2014	9	13	11	28	19	0.3	3.6	0.79	95.9	82.3097	61.861
2014	9	13	11	38	19	0.3	3.6	0.81	97	82.3097	62.631
2014	9	13	11	48	19	0.3	3.6	0.82	97.6	82.3097	63.4011
2014	9	13	11	58	19	0.3	3.6	0.8	95.4	82.3097	62.631
2014	9	13	12	8	19	0.3	3.6	0.81	100.5	82.3097	62.1176
2014	9	13	12	18	19	0.3	3.6	0.76	96.2	82.3097	59.294
2014	9	13	12	28	19	0.3	3.6	0.78	97.2	82.3097	60.5774
2014	9	13	12	38	19	0.3	3.6	0.78	97.5	82.2441	60.7834
2014	9	13	12	48	19	0.3	3.6	0.77	98.1	82.2441	59.7575
2014	9	13	12	58	19	0.3	3.6	0.77	97.8	82.2441	60.0139
2014	9	13	13	8	19	0.3	3.6	0.79	94.3	82.2441	61.2963
2014	9	13	13	18	19	0.3	3.6	0.77	97.1	82.2441	60.0139
2014	9	13	13	28	19	0.3	3.6	0.76	96.7	82.2441	58.7315
2014	9	13	13	38	19	0.3	3.6	0.79	95.3	82.2441	61.2962
2014	9	13	13	48	19	0.3	3.6	0.8	97.6	82.2441	61.8092
2014	9	13	13	58	19	0.3	3.6	0.8	97.6	82.1785	61.7577
2014	9	13	14	8	19	0.3	3.6	0.8	96.8	82.1785	62.0139
2014	9	13	14	18	19	0.3	3.6	0.81	95.8	82.1785	63.0389
2014	9	13	14	28	19	0.3	3.6	0.8	98	82.1785	62.0138
2014	9	13	14	38	19	0.3	3.6	0.8	95.7	82.1785	62.0138
2014	9	13	14	48	19	0.3	3.6	0.78	98	82.1785	60.4763
2014	9	13	14	58	19	0.3	3.6	0.83	95.7	82.1785	64.3201
2014	9	13	15	8	19	0.3	3.6	0.82	97.4	82.1785	63.5513
2014	9	13	15	18	19	0.3	3.6	0.79	96.7	82.1785	61.5012
2014	9	13	15	28	19	0.3	3.6	0.82	97.5	82.1129	63.7543
2014	9	13	15	38	19	0.3	3.6	0.75	93.5	82.1129	58.6334
2014	9	13	15	48	19	0.3	3.6	0.8	97.7	81.9816	62.1141
2014	9	13	15	58	19	0.3	3.6	0.77	93.7	81.9816	60.0692
2014	9	13	16	8	19	0.3	3.6	0.8	98.1	81.916	61.296
2014	9	13	16	18	19	0.3	3.6	0.78	98.4	81.916	60.2744
2014	9	13	16	28	19	0.3	3.6	0.78	98	81.916	60.2744
2014	9	13	16	38	19	0.3	3.6	0.79	94.3	81.916	61.5514
2014	9	13	16	48	19	0.3	3.6	0.81	95.8	81.8504	62.5206
2014	9	13	16	58	19	0.3	3.6	0.81	98.1	81.8504	62.5206
2014	9	13	17	8	19	0.3	3.6	0.78	95.8	81.8504	60.2239
2014	9	13	17	18	19	0.3	3.6	0.82	95	81.8504	63.7965
2014	9	13	17	28	19	0.3	3.6	0.8	98.3	81.8504	61.4998
2014	9	13	17	38	19	0.3	3.6	0.81	94.9	81.8504	63.031
2014	9	13	17	48	19	0.3	3.6	0.81	96.5	81.8504	62.7758
2014	9	13	17	58	19	0.3	3.6	0.78	94.8	81.8504	60.2239
2014	9	13	18	8	19	0.3	3.6	0.8	97.7	81.8504	62.0102
2014	9	13	18	18	19	0.3	3.6	0.81	94.2	81.8504	62.7758
2014	9	13	18	28	19	0.3	3.6	0.78	94.6	81.8504	60.4791
2014	9	13	18	38	19	0.3	3.6	0.82	93.2	81.8504	64.0517

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	13	18	48	19	0.3	3.6	0.82	94.4	81.8504	63.5413
2014	9	13	18	58	19	0.3	3.6	0.81	99.3	81.8504	62.0102
2014	9	13	19	8	19	0.3	3.6	0.81	96.5	81.8504	62.7757
2014	9	13	19	18	19	0.3	3.6	0.76	95.2	81.8504	59.2032
2014	9	13	19	28	19	0.3	3.6	0.84	96.3	81.8504	64.8172
2014	9	13	19	38	19	0.3	3.6	0.81	94.2	81.916	62.5729
2014	9	13	19	48	19	0.3	3.6	0.8	94.5	81.916	61.8068
2014	9	13	19	58	19	0.3	3.6	0.85	95.1	81.916	65.6377
2014	9	13	20	8	19	0.3	3.6	0.79	95.5	81.916	61.0405
2014	9	13	20	18	19	0.3	3.6	0.79	94.7	81.916	61.5514
2014	9	13	20	28	19	0.3	3.6	0.78	96.1	81.916	60.019
2014	9	13	20	38	19	0.3	3.6	0.79	95.2	81.916	61.296
2014	9	13	20	48	19	0.3	3.6	0.83	95.2	81.916	64.3608
2014	9	13	20	58	19	0.3	3.6	0.8	97.6	81.9816	61.6029
2014	9	13	21	8	19	0.3	3.6	0.78	97.7	81.9816	60.3248
2014	9	13	21	18	19	0.3	3.6	0.84	97.2	82.0472	64.9802
2014	9	13	21	28	19	0.3	3.6	0.78	97.5	82.0472	60.1195
2014	9	13	21	38	19	0.3	3.6	0.8	95	82.0472	61.9103
2014	9	13	21	48	19	0.3	3.6	0.79	96.7	82.0472	61.1428
2014	9	13	21	58	19	0.3	3.6	0.84	98.7	82.1129	65.0345
2014	9	13	22	8	19	0.3	3.6	0.79	92.4	82.0472	61.3986
2014	9	13	22	18	19	0.3	3.6	0.81	96.5	82.1129	62.4741
2014	9	13	22	28	19	0.3	3.6	0.79	95.2	82.1129	61.706
2014	9	13	22	38	19	0.3	3.6	0.84	97.2	82.1129	64.7785
2014	9	13	22	48	19	0.3	3.6	0.78	95.1	82.1129	60.6819
2014	9	13	22	58	19	0.3	3.6	0.77	95.6	82.1129	59.9137
2014	9	13	23	8	19	0.3	3.6	0.83	95	82.1129	64.7786
2014	9	13	23	18	19	0.3	3.6	0.79	95.7	82.1129	61.194
2014	9	13	23	28	19	0.3	3.6	0.82	97.1	82.1785	63.8076
2014	9	13	23	38	19	0.3	3.6	0.82	95.3	82.1785	64.0639
2014	9	13	23	48	19	0.3	3.6	0.81	97.2	82.1785	62.5264
2014	9	13	23	58	19	0.3	3.6	0.81	96.5	82.1785	62.7827
2014	9	14	0	8	19	0.3	3.6	0.79	98.3	82.1785	61.2451
2014	9	14	0	18	19	0.3	3.6	0.77	93.4	82.1785	59.9639
2014	9	14	0	28	19	0.3	3.6	0.8	96.3	82.1785	62.2702
2014	9	14	0	38	19	0.3	3.6	0.83	95.2	82.1785	64.8328
2014	9	14	0	48	19	0.3	3.6	0.79	94.7	82.1785	61.7577
2014	9	14	0	58	19	0.3	3.6	0.8	96.6	82.1785	62.2702
2014	9	14	1	8	19	0.3	3.6	0.8	95.9	82.1785	62.2703
2014	9	14	1	18	19	0.3	3.6	0.78	94.1	82.1785	60.4765
2014	9	14	1	28	19	0.3	3.6	0.82	94.3	82.1785	64.0641
2014	9	14	1	38	19	0.3	3.6	0.81	97.6	82.2441	63.0917
2014	9	14	1	48	19	0.3	3.6	0.8	94	82.2441	62.3223
2014	9	14	1	58	19	0.3	3.6	0.8	94.5	82.2441	62.3223
2014	9	14	2	8	19	0.3	3.6	0.82	96.2	82.2441	63.6047
2014	9	14	2	18	19	0.3	3.6	0.79	97.4	82.2441	61.5529

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	2	28	19	0.3	3.6	0.87	95	82.2441	67.7082
2014	9	14	2	38	19	0.3	3.6	0.8	96.6	82.2441	61.8094
2014	9	14	2	48	19	0.3	3.6	0.83	95.2	82.2441	64.8871
2014	9	14	2	58	19	0.3	3.6	0.79	97.4	82.2441	61.553
2014	9	14	3	8	19	0.3	3.6	0.83	96.1	82.2441	64.3742
2014	9	14	3	18	19	0.3	3.6	0.81	97.2	82.2441	62.8354
2014	9	14	3	28	19	0.3	3.6	0.82	95.1	82.2441	63.6048
2014	9	14	3	38	19	0.3	3.6	0.84	96.7	82.2441	65.1436
2014	9	14	3	48	19	0.3	3.6	0.83	97.2	82.2441	64.6307
2014	9	14	3	58	19	0.3	3.6	0.82	94.1	82.2441	63.8613
2014	9	14	4	8	19	0.3	3.6	0.78	98	82.2441	60.0142
2014	9	14	4	18	19	0.3	3.6	0.83	97.3	82.2441	64.3743
2014	9	14	4	28	19	0.3	3.6	0.82	95.5	82.2441	63.6049
2014	9	14	4	38	19	0.3	3.6	0.83	97.7	82.2441	64.1178
2014	9	14	4	48	19	0.3	3.6	0.8	95.2	82.2441	62.579
2014	9	14	4	58	19	0.3	3.6	0.84	94.7	82.2441	65.4002
2014	9	14	5	8	19	0.3	3.6	0.79	97.6	82.2441	61.2967
2014	9	14	5	18	19	0.3	3.6	0.83	96.4	82.2441	64.1179
2014	9	14	5	28	19	0.3	3.6	0.8	96.6	82.2441	62.3226
2014	9	14	5	38	19	0.3	3.6	0.8	95.4	82.2441	62.0662
2014	9	14	5	48	19	0.3	3.6	0.79	95.5	82.2441	61.5532
2014	9	14	5	58	19	0.3	3.6	0.83	96.6	82.2441	64.3744
2014	9	14	6	8	19	0.3	3.6	0.76	93.5	82.2441	58.9885
2014	9	14	6	18	19	0.3	3.6	0.8	94.9	82.2441	62.3227
2014	9	14	6	28	19	0.3	3.6	0.86	96.8	82.2441	66.6827
2014	9	14	6	38	19	0.3	3.6	0.81	95.5	82.2441	63.3486
2014	9	14	6	48	19	0.3	3.6	0.81	96	82.2441	63.3486
2014	9	14	6	58	19	0.3	3.6	0.82	98.5	82.2441	63.6051
2014	9	14	7	8	19	0.3	3.6	0.79	96.7	82.2441	61.2968
2014	9	14	7	18	19	0.3	3.6	0.84	96.7	82.2441	65.1439
2014	9	14	7	28	19	0.3	3.6	0.79	95.2	82.3097	61.8613
2014	9	14	7	38	19	0.3	3.6	0.79	94.3	82.3097	61.8613
2014	9	14	7	48	19	0.3	3.6	0.79	94.5	82.3097	61.8613
2014	9	14	7	58	19	0.3	3.6	0.8	95.9	82.3097	62.6314
2014	9	14	8	8	19	0.3	3.6	0.82	97.1	82.3097	63.6581
2014	9	14	8	18	19	0.3	3.6	0.82	98.5	82.3097	63.6581
2014	9	14	8	28	19	0.3	3.6	0.88	96.2	82.3097	68.7918
2014	9	14	8	38	19	0.3	3.6	0.78	93.4	82.3097	60.8345
2014	9	14	8	48	19	0.3	3.6	0.81	92.8	82.3097	63.1447
2014	9	14	8	58	19	0.3	3.6	0.84	95	82.3097	65.1981
2014	9	14	9	8	19	0.3	3.6	0.83	97.2	82.3097	64.6848
2014	9	14	9	18	19	0.3	3.6	0.83	95	82.3097	64.4281
2014	9	14	9	28	19	0.3	3.6	0.81	95.3	82.3097	63.4013
2014	9	14	9	38	19	0.3	3.6	0.84	95.4	82.3097	65.4547
2014	9	14	9	48	19	0.3	3.6	0.8	95.9	82.3097	62.6312
2014	9	14	9	58	19	0.3	3.6	0.8	95.7	82.3097	62.1178

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	10	8	19	0.3	3.6	0.8	97.3	82.3097	62.3744
2014	9	14	10	18	19	0.3	3.6	0.81	93.9	82.3097	63.4012
2014	9	14	10	28	19	0.3	3.6	0.79	97.2	82.3097	61.3476
2014	9	14	10	38	19	0.3	3.6	0.82	95.5	82.3097	64.1711
2014	9	14	10	48	19	0.3	3.6	0.79	92.6	82.3097	61.6042
2014	9	14	10	58	19	0.3	3.6	0.8	94	82.3097	62.3742
2014	9	14	11	8	19	0.3	3.6	0.81	97.2	82.3097	62.8877
2014	9	14	11	18	19	0.3	3.6	0.8	95.4	82.3097	62.3743
2014	9	14	11	28	19	0.3	3.6	0.8	95.7	82.3097	62.1176
2014	9	14	11	38	19	0.3	3.6	0.8	94.5	82.3097	62.3742
2014	9	14	11	48	19	0.3	3.6	0.81	96.5	82.3097	63.1442
2014	9	14	11	58	19	0.3	3.6	0.82	96.6	82.3097	63.9142
2014	9	14	12	8	19	0.3	3.6	0.83	96.1	82.3097	64.4277
2014	9	14	12	18	19	0.3	3.6	0.81	96.3	82.2441	63.0917
2014	9	14	12	28	19	0.3	3.6	0.83	95	82.2441	64.6306
2014	9	14	12	38	19	0.3	3.6	0.8	98.5	82.3097	61.6042
2014	9	14	12	48	19	0.3	3.6	0.81	96.5	82.3097	63.1443
2014	9	14	12	58	19	0.3	3.6	0.79	95.7	82.2441	61.5528
2014	9	14	13	8	19	0.3	3.6	0.84	97.2	82.3097	64.9409
2014	9	14	13	18	19	0.3	3.6	0.84	98.1	82.3097	64.9409
2014	9	14	13	28	19	0.3	3.6	0.81	97.7	82.3097	62.6308
2014	9	14	13	38	19	0.3	3.6	0.88	97.9	82.3097	68.0211
2014	9	14	13	48	19	0.3	3.6	0.8	94.3	82.2441	62.0656
2014	9	14	13	58	19	0.3	3.6	0.83	95.9	82.3097	64.9408
2014	9	14	14	8	19	0.3	3.6	0.8	96.6	82.3097	62.3739
2014	9	14	14	18	19	0.3	3.6	0.81	96.5	82.3097	63.144
2014	9	14	14	28	19	0.3	3.6	0.82	96.2	82.3097	63.6574
2014	9	14	14	38	19	0.3	3.6	0.79	96.7	82.3097	61.3473
2014	9	14	14	48	19	0.3	3.6	0.79	98.6	82.3097	61.3473
2014	9	14	14	58	19	0.3	3.6	0.81	96	82.3097	63.4007
2014	9	14	15	8	19	0.3	3.6	0.77	94.6	82.3097	60.0638
2014	9	14	15	18	19	0.3	3.6	0.83	95	82.3097	64.4274
2014	9	14	15	28	19	0.3	3.6	0.77	94.4	82.3097	60.3205
2014	9	14	15	38	19	0.3	3.6	0.78	98	82.3097	60.3204
2014	9	14	15	48	19	0.3	3.6	0.84	97.2	82.3097	65.1973
2014	9	14	15	58	19	0.3	3.6	0.81	95.8	82.2441	63.0913
2014	9	14	16	8	19	0.3	3.6	0.86	96.4	82.3097	66.7374
2014	9	14	16	18	19	0.3	3.6	0.83	98.2	82.3097	63.9139
2014	9	14	16	28	19	0.3	3.6	0.8	96.6	82.2441	61.8089
2014	9	14	16	38	19	0.3	3.6	0.79	97.8	82.2441	61.5525
2014	9	14	16	48	19	0.3	3.6	0.8	96.4	82.2441	61.8089
2014	9	14	16	58	19	0.3	3.6	0.83	96.4	82.2441	64.1172
2014	9	14	17	8	19	0.3	3.6	0.8	98.5	82.2441	61.5525
2014	9	14	17	18	19	0.3	3.6	0.81	96.3	82.2441	63.0913
2014	9	14	17	28	19	0.3	3.6	0.77	95.6	82.2441	60.0137
2014	9	14	17	38	19	0.3	3.6	0.79	99.1	82.2441	60.7831

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	14	17	48	19	0.3	3.6	0.79	97.2	82.2441	61.296
2014	9	14	17	58	19	0.3	3.6	0.83	97.1	82.2441	64.1172
2014	9	14	18	8	19	0.3	3.6	0.8	95.4	82.2441	62.0654
2014	9	14	18	18	19	0.3	3.6	0.8	97.3	82.2441	62.0654
2014	9	14	18	28	19	0.3	3.6	0.79	95.7	82.3097	61.3471
2014	9	14	18	38	19	0.3	3.6	0.82	94.8	82.3097	64.1706
2014	9	14	18	48	19	0.3	3.6	0.84	96.3	82.3097	64.9406
2014	9	14	18	58	19	0.3	3.6	0.8	93.8	82.3097	62.6305
2014	9	14	19	8	19	0.3	3.6	0.82	95.5	82.3097	64.1706
2014	9	14	19	18	19	0.3	3.6	0.83	97.7	82.3097	64.1706
2014	9	14	19	28	19	0.3	3.6	0.83	95.2	82.3097	64.4273
2014	9	14	19	38	19	0.3	3.6	0.83	94.1	82.3097	64.9407
2014	9	14	19	48	19	0.3	3.6	0.77	94.4	82.3097	60.3204
2014	9	14	19	58	19	0.3	3.6	0.8	97.6	82.3097	61.8605
2014	9	14	20	8	19	0.3	3.6	0.79	94.8	82.3097	61.6038
2014	9	14	20	18	19	0.3	3.6	0.83	95.2	82.3097	64.4273
2014	9	14	20	28	19	0.3	3.6	0.81	96.8	82.3097	62.8872
2014	9	14	20	38	19	0.3	3.6	0.8	96.6	82.3097	61.8605
2014	9	14	20	48	19	0.3	3.6	0.82	95	82.3097	63.9139
2014	9	14	20	58	19	0.3	3.6	0.84	99.7	82.3097	64.4273
2014	9	14	21	8	19	0.3	3.6	0.83	97.1	82.3097	64.1706
2014	9	14	21	18	19	0.3	3.6	0.78	97	82.3097	60.8338
2014	9	14	21	28	19	0.3	3.6	0.79	94.3	82.3097	61.6038
2014	9	14	21	38	19	0.3	3.6	0.77	97.3	82.3097	59.8071
2014	9	14	21	48	19	0.3	3.6	0.8	95.9	82.3097	62.3739
2014	9	14	21	58	19	0.3	3.6	0.82	96.9	82.3097	63.914
2014	9	14	22	8	19	0.3	3.6	0.81	94.4	82.3097	62.8873
2014	9	14	22	18	19	0.3	3.6	0.8	95.4	82.3753	62.4259
2014	9	14	22	28	19	0.3	3.6	0.85	97.1	82.3753	66.2793
2014	9	14	22	38	19	0.3	3.6	0.86	96.6	82.3753	67.05
2014	9	14	22	48	19	0.3	3.6	0.82	96.9	82.3753	63.9673
2014	9	14	22	58	19	0.3	3.6	0.84	94.3	82.3753	65.5087
2014	9	14	23	8	19	0.3	3.6	0.83	97.7	82.3753	64.2242
2014	9	14	23	18	19	0.3	3.6	0.83	96.1	82.3753	64.4811
2014	9	14	23	28	19	0.3	3.6	0.85	95.8	82.3753	66.0225
2014	9	14	23	38	19	0.3	3.6	0.83	97.1	82.3753	64.2242
2014	9	14	23	48	19	0.3	3.6	0.79	97.9	82.3753	61.1415
2014	9	14	23	58	19	0.3	3.6	0.83	95.6	82.3753	64.9949
2014	9	15	0	8	19	0.3	3.6	0.82	96.2	82.3753	63.9674
2014	9	15	0	18	19	0.3	3.6	0.83	95	82.3753	64.995
2014	9	15	0	28	19	0.3	3.6	0.85	98.4	82.3753	65.7657
2014	9	15	0	38	19	0.3	3.6	0.8	94.7	82.3753	62.6829
2014	9	15	0	48	19	0.3	3.6	0.83	97.5	82.3753	64.7381
2014	9	15	0	58	19	0.3	3.6	0.82	94.8	82.3753	63.9674
2014	9	15	1	8	19	0.3	3.6	0.87	95.4	82.3753	67.8209
2014	9	15	1	18	19	0.3	3.6	0.81	97.2	82.3753	62.9399

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	1	28	19	0.3	3.6	0.82	96.9	82.3753	63.7106
2014	9	15	1	38	19	0.3	3.6	0.83	97	82.3753	64.7382
2014	9	15	1	48	19	0.3	3.6	0.81	93.7	82.3753	62.9399
2014	9	15	1	58	19	0.3	3.6	0.78	94.8	82.3753	60.6279
2014	9	15	2	8	19	0.3	3.6	0.77	94.7	82.3753	59.8572
2014	9	15	2	18	19	0.3	3.6	0.8	95	82.3753	62.1693
2014	9	15	2	28	19	0.3	3.6	0.83	95	82.3753	64.9952
2014	9	15	2	38	19	0.3	3.6	0.86	94.4	82.3753	67.0504
2014	9	15	2	48	19	0.3	3.6	0.84	97.2	82.3753	65.509
2014	9	15	2	58	19	0.3	3.6	0.83	95.9	82.3753	64.9952
2014	9	15	3	8	19	0.3	3.6	0.81	97.6	82.3753	63.1969
2014	9	15	3	18	19	0.3	3.6	0.85	95.3	82.3753	66.0228
2014	9	15	3	28	19	0.3	3.6	0.82	97.2	82.3753	63.4539
2014	9	15	3	38	19	0.3	3.6	0.81	96.5	82.3753	63.197
2014	9	15	3	48	19	0.3	3.6	0.8	95	82.3753	62.1694
2014	9	15	3	58	19	0.3	3.6	0.79	95.7	82.3753	61.6556
2014	9	15	4	8	19	0.3	3.9	0.78	96	82.4409	60.6785
2014	9	15	4	18	19	0.3	3.9	0.8	94.5	82.4409	62.4783
2014	9	15	4	28	19	0.3	3.9	0.79	96	82.4409	61.1927
2014	9	15	4	38	19	0.3	3.9	0.81	97.2	82.4409	62.9925
2014	9	15	4	48	19	0.3	3.9	0.84	95.8	82.4409	65.8208
2014	9	15	4	58	19	0.3	3.9	0.82	97.4	82.4409	63.5068
2014	9	15	5	8	19	0.3	3.9	0.81	94.4	82.4409	62.9926
2014	9	15	5	18	19	0.3	3.9	0.77	96.1	82.4409	60.1643
2014	9	15	5	28	19	0.3	3.9	0.82	96.5	82.4409	63.5068
2014	9	15	5	38	19	0.3	3.9	0.82	97.1	82.4409	63.7639
2014	9	15	5	48	19	0.3	3.9	0.81	96.1	82.4409	62.9926
2014	9	15	5	58	19	0.3	3.9	0.83	96.1	82.4409	64.5353
2014	9	15	6	8	19	0.3	3.9	0.8	95.7	82.4409	62.2213
2014	9	15	6	18	19	0.3	3.9	0.83	98.2	82.4409	64.5353
2014	9	15	6	28	19	0.3	3.9	0.83	95.5	82.4409	64.5354
2014	9	15	6	38	19	0.3	3.9	0.82	93.9	82.4409	64.0211
2014	9	15	6	48	19	0.3	3.9	0.83	95.7	82.4409	64.7925
2014	9	15	6	58	19	0.3	3.9	0.79	94.1	82.4409	61.45
2014	9	15	7	8	19	0.3	3.9	0.8	96.1	82.4409	62.4785
2014	9	15	7	18	19	0.3	3.9	0.83	95.7	82.4409	64.5354
2014	9	15	7	28	19	0.3	3.9	0.8	95.6	82.4409	62.4785
2014	9	15	7	38	19	0.3	3.9	0.78	96.8	82.4409	60.4216
2014	9	15	7	48	19	0.3	3.9	0.81	96.3	82.5066	63.3025
2014	9	15	7	58	19	0.3	3.9	0.82	97.6	82.5066	63.8171
2014	9	15	8	8	19	0.3	3.9	0.83	95.5	82.5066	64.5891
2014	9	15	8	18	19	0.3	3.9	0.85	95.3	82.5066	66.3904
2014	9	15	8	28	19	0.3	3.9	0.79	95.9	82.5066	62.0158
2014	9	15	8	38	19	0.3	3.9	0.84	95.1	82.5066	65.8757
2014	9	15	8	48	19	0.3	3.9	0.78	95.5	82.5066	60.9864
2014	9	15	8	58	19	0.3	3.9	0.8	95.9	82.5066	62.2731

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	9	8	19	0.3	3.9	0.81	95.5	82.5066	63.5597
2014	9	15	9	18	19	0.3	3.9	0.83	94.7	82.5066	65.1036
2014	9	15	9	28	19	0.3	3.9	0.79	95.9	82.5066	62.0157
2014	9	15	9	38	19	0.3	3.9	0.84	96.3	82.5066	65.1036
2014	9	15	9	48	19	0.3	3.9	0.86	94.2	82.5066	66.9048
2014	9	15	9	58	19	0.3	3.9	0.8	98	82.5066	62.2729
2014	9	15	10	8	19	0.3	3.9	0.82	96.9	82.5066	64.0742
2014	9	15	10	18	19	0.3	3.9	0.85	96.2	82.5066	66.1328
2014	9	15	10	28	19	0.3	3.9	0.85	96.7	82.5066	65.8754
2014	9	15	10	38	19	0.3	3.9	0.84	95.2	82.5066	65.3608
2014	9	15	10	48	19	0.3	3.9	0.78	97.5	82.5066	60.4715
2014	9	15	10	58	19	0.3	3.9	0.83	95.4	82.5066	65.1034
2014	9	15	11	8	19	0.3	3.9	0.83	98.2	82.5066	64.3314
2014	9	15	11	18	19	0.3	3.9	0.79	93.8	82.5066	61.5008
2014	9	15	11	28	19	0.3	3.9	0.83	95.4	82.5066	65.1033
2014	9	15	11	38	19	0.3	3.9	0.8	95	82.5066	62.2728
2014	9	15	11	48	19	0.3	3.9	0.82	96.5	82.4409	63.5066
2014	9	15	11	58	19	0.3	3.9	0.83	95.7	82.5066	64.5886
2014	9	15	12	8	19	0.3	3.9	0.83	95.2	82.5066	64.8459
2014	9	15	12	18	19	0.3	3.9	0.83	94.5	82.5066	65.1033
2014	9	15	12	28	19	0.3	3.9	0.83	95.7	82.5066	64.5885
2014	9	15	12	38	19	0.3	3.9	0.82	96.9	82.5066	63.8165
2014	9	15	12	48	19	0.3	3.9	0.83	97.3	82.5066	64.3311
2014	9	15	12	58	19	0.3	3.9	0.86	97.3	82.5066	66.6469
2014	9	15	13	8	19	0.3	3.9	0.79	97.4	82.5066	61.7578
2014	9	15	13	18	19	0.3	3.9	0.81	96.1	82.5066	62.787
2014	9	15	13	28	19	0.3	3.9	0.81	94.9	82.4409	62.992
2014	9	15	13	38	19	0.3	3.9	0.81	96.5	82.4409	62.7349
2014	9	15	13	48	19	0.3	3.9	0.81	98.4	82.4409	62.7349
2014	9	15	13	58	19	0.3	3.9	0.8	95.4	82.4409	62.2207
2014	9	15	14	8	19	0.3	3.9	0.79	95.2	82.4409	61.7064
2014	9	15	14	18	19	0.3	3.9	0.8	95.9	82.4409	62.4777
2014	9	15	14	28	19	0.3	3.9	0.85	97.3	82.4409	65.8201
2014	9	15	14	38	19	0.3	3.9	0.84	96.2	82.4409	65.8201
2014	9	15	14	48	19	0.3	3.9	0.79	95.2	82.4409	61.9634
2014	9	15	14	58	19	0.3	3.9	0.78	97	82.4409	60.4208
2014	9	15	15	8	19	0.3	3.6	0.79	96	82.3753	61.1412
2014	9	15	15	18	19	0.3	3.9	0.82	95.9	82.4409	64.2774
2014	9	15	15	28	19	0.3	3.6	0.78	95.6	82.3753	60.6274
2014	9	15	15	38	19	0.3	3.6	0.81	93.7	82.3753	62.9394
2014	9	15	15	48	19	0.3	3.6	0.8	93.8	82.3753	62.6825
2014	9	15	15	58	19	0.3	3.6	0.81	98.1	82.3753	62.9395
2014	9	15	16	8	19	0.3	3.6	0.81	98.4	82.3753	62.9395
2014	9	15	16	18	19	0.3	3.6	0.78	98	82.3753	60.6274
2014	9	15	16	28	19	0.3	3.6	0.79	97.9	82.3753	60.8843
2014	9	15	16	38	19	0.3	3.6	0.8	96.1	82.3753	62.1688

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	15	16	48	19	0.3	3.6	0.79	96.9	82.3753	61.655
2014	9	15	16	58	19	0.3	3.6	0.82	94.8	82.3753	64.2239
2014	9	15	17	8	19	0.3	3.6	0.8	96.6	82.3753	62.1687
2014	9	15	17	18	19	0.3	3.6	0.81	96.5	82.3753	62.6825
2014	9	15	17	28	19	0.3	3.6	0.79	97.8	82.3753	61.6549
2014	9	15	17	38	19	0.3	3.6	0.82	96.7	82.3753	63.4532
2014	9	15	17	48	19	0.3	3.6	0.87	97.2	82.3753	67.3066
2014	9	15	17	58	19	0.3	3.6	0.83	97.3	82.3753	64.2239
2014	9	15	18	8	19	0.3	3.6	0.75	96.3	82.3753	58.0584
2014	9	15	18	18	19	0.3	3.6	0.81	97	82.3753	62.9394
2014	9	15	18	28	19	0.3	3.6	0.83	95.2	82.3753	64.9946
2014	9	15	18	38	19	0.3	3.6	0.8	94.2	82.3753	62.6825
2014	9	15	18	48	19	0.3	3.6	0.8	96.6	82.3753	62.4256
2014	9	15	18	58	19	0.3	3.6	0.8	94.7	82.3753	62.4256
2014	9	15	19	8	19	0.3	3.9	0.8	95.2	82.4409	62.4775
2014	9	15	19	18	19	0.3	3.6	0.82	95.3	82.3753	63.7101
2014	9	15	19	28	19	0.3	3.9	0.83	95.7	82.4409	64.5344
2014	9	15	19	38	19	0.3	3.9	0.81	96.3	82.4409	63.2489
2014	9	15	19	48	19	0.3	3.9	0.81	95.3	82.4409	63.2489
2014	9	15	19	58	19	0.3	3.9	0.84	98.1	82.4409	65.3058
2014	9	15	20	8	19	0.3	3.9	0.82	93.2	82.4409	64.2773
2014	9	15	20	18	19	0.3	3.9	0.79	95.9	82.4409	61.9634
2014	9	15	20	28	19	0.3	3.9	0.81	94	82.4409	62.9918
2014	9	15	20	38	19	0.3	3.9	0.85	96.9	82.4409	66.0771
2014	9	15	20	48	19	0.3	3.9	0.83	93.6	82.4409	64.7916
2014	9	15	20	58	19	0.3	3.9	0.79	97.4	82.4409	61.7063
2014	9	15	21	8	19	0.3	3.9	0.81	98.2	82.4409	62.4776
2014	9	15	21	18	19	0.3	3.9	0.82	98	82.4409	63.7632
2014	9	15	21	28	19	0.3	3.9	0.81	96	82.4409	63.5061
2014	9	15	21	38	19	0.3	3.9	0.81	95.8	82.4409	63.249
2014	9	15	21	48	19	0.3	3.9	0.85	96.6	82.4409	66.3343
2014	9	15	21	58	19	0.3	3.9	0.8	93.5	82.4409	62.4777
2014	9	15	22	8	19	0.3	3.9	0.8	96.8	82.4409	62.2206
2014	9	15	22	18	19	0.3	3.9	0.78	98.2	82.4409	60.4208
2014	9	15	22	28	19	0.3	3.9	0.84	95.2	82.4409	65.3059
2014	9	15	22	38	19	0.3	3.9	0.82	98.5	82.4409	63.7633
2014	9	15	22	48	19	0.3	3.9	0.75	99.1	82.4409	57.8497
2014	9	15	22	58	19	0.3	3.9	0.81	97.2	82.4409	62.7348
2014	9	15	23	8	19	0.3	3.9	0.81	96.3	82.4409	63.2491
2014	9	15	23	18	19	0.3	3.9	0.82	96.4	82.4409	63.7633
2014	9	15	23	28	19	0.3	3.9	0.83	96.4	82.4409	64.2775
2014	9	15	23	38	19	0.3	3.9	0.79	95.5	82.4409	61.9635
2014	9	15	23	48	19	0.3	3.9	0.8	95.6	82.4409	62.7349
2014	9	15	23	58	19	0.3	3.9	0.78	95.8	82.4409	60.4209
2014	9	16	0	8	19	0.3	3.9	0.79	95.5	82.4409	61.9635
2014	9	16	0	18	19	0.3	3.9	0.82	95.9	82.4409	64.2775

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	0	28	19	0.3	3.9	0.82	95.5	82.5066	64.0737
2014	9	16	0	38	19	0.3	3.9	0.83	98.5	82.4409	64.0204
2014	9	16	0	48	19	0.3	3.9	0.78	95.1	82.4409	60.9351
2014	9	16	0	58	19	0.3	3.9	0.83	96.1	82.4409	64.5347
2014	9	16	1	8	19	0.3	3.9	0.77	96.1	82.4409	60.1638
2014	9	16	1	18	19	0.3	3.9	0.82	94.4	82.4409	64.0205
2014	9	16	1	28	19	0.3	3.9	0.8	95.4	82.4409	62.735
2014	9	16	1	38	19	0.3	3.9	0.83	95.4	82.4409	64.7919
2014	9	16	1	48	19	0.3	3.9	0.8	96.3	82.4409	62.4779
2014	9	16	1	58	19	0.3	3.9	0.83	96.1	82.4409	64.5348
2014	9	16	2	8	19	0.3	3.9	0.83	95.9	82.5066	64.8458
2014	9	16	2	18	19	0.3	3.9	0.77	95.6	82.5066	60.4713
2014	9	16	2	28	19	0.3	3.9	0.81	97.9	82.5066	63.0445
2014	9	16	2	38	19	0.3	3.9	0.82	94.8	82.5066	64.3312
2014	9	16	2	48	19	0.3	3.9	0.86	97.2	82.5066	67.1618
2014	9	16	2	58	19	0.3	3.9	0.77	97.5	82.5066	60.214
2014	9	16	3	8	19	0.3	3.9	0.83	96.4	82.5066	64.3312
2014	9	16	3	18	19	0.3	3.9	0.81	96.3	82.5066	63.3019
2014	9	16	3	28	19	0.3	3.9	0.83	94.1	82.5066	64.5886
2014	9	16	3	38	19	0.3	3.9	0.83	96.4	82.5066	64.5886
2014	9	16	3	48	19	0.3	3.9	0.8	96.1	82.5066	62.2727
2014	9	16	3	58	19	0.3	3.9	0.85	94.7	82.5066	66.3899
2014	9	16	4	8	19	0.3	3.9	0.82	95	82.5066	64.074
2014	9	16	4	18	19	0.3	3.9	0.84	97.2	82.5722	65.6725
2014	9	16	4	28	19	0.3	3.9	0.81	95.5	82.5722	63.6122
2014	9	16	4	38	19	0.3	3.9	0.84	96.3	82.5066	65.1034
2014	9	16	4	48	19	0.3	3.9	0.84	96	82.5722	65.6725
2014	9	16	4	58	19	0.3	3.9	0.84	96.2	82.5722	65.9301
2014	9	16	5	8	19	0.3	3.9	0.8	94.7	82.5722	62.8396
2014	9	16	5	18	19	0.3	3.9	0.88	94.9	82.5722	68.7631
2014	9	16	5	28	19	0.3	3.9	0.8	97.3	82.5722	62.5821
2014	9	16	5	38	19	0.3	3.9	0.8	95.4	82.5722	62.8397
2014	9	16	5	48	19	0.3	3.9	0.84	96	82.5722	65.9302
2014	9	16	5	58	19	0.3	3.9	0.83	95	82.5722	64.6425
2014	9	16	6	8	19	0.3	3.9	0.81	95.3	82.5722	63.6123
2014	9	16	6	18	19	0.3	3.9	0.81	95.1	82.5722	63.3548
2014	9	16	6	28	19	0.3	3.9	0.83	96.6	82.5722	64.9001
2014	9	16	6	38	19	0.3	3.9	0.84	96	82.5722	65.9302
2014	9	16	6	48	19	0.3	3.9	0.8	97.3	82.6378	62.6342
2014	9	16	6	58	19	0.3	3.9	0.85	95.8	82.7034	66.5557
2014	9	16	7	8	19	0.3	3.9	0.8	96.6	82.7034	62.1702
2014	9	16	7	18	19	0.3	3.9	0.82	97.6	82.7034	63.718
2014	9	16	7	28	19	0.3	3.9	0.86	97.2	82.7034	67.3296
2014	9	16	7	38	19	0.3	3.9	0.82	95.5	82.769	64.5454
2014	9	16	7	48	19	0.3	3.9	0.8	96.4	82.769	62.2218
2014	9	16	7	58	19	0.3	3.9	0.8	95.2	82.769	62.48

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	8	8	19	0.3	3.9	0.83	98.5	82.769	64.2872
2014	9	16	8	18	19	0.3	3.9	0.83	94.6	82.769	64.8036
2014	9	16	8	28	19	0.3	3.9	0.8	95.4	82.769	62.48
2014	9	16	8	38	19	0.3	3.9	0.79	98.6	82.769	61.4472
2014	9	16	8	48	19	0.3	3.9	0.8	95.9	82.769	62.9963
2014	9	16	8	58	19	0.3	3.9	0.78	94.1	82.769	61.4472
2014	9	16	9	8	19	0.3	3.9	0.83	95.4	82.769	65.3199
2014	9	16	9	18	19	0.3	3.9	0.8	96.6	82.769	62.4799
2014	9	16	9	28	19	0.3	3.9	0.82	93.4	82.769	64.2871
2014	9	16	9	38	19	0.3	3.9	0.81	96	82.769	63.7707
2014	9	16	9	48	19	0.3	3.9	0.82	97.6	82.769	63.7707
2014	9	16	9	58	19	0.3	3.9	0.85	95.1	82.769	66.3525
2014	9	16	10	8	19	0.3	3.9	0.81	95.1	82.769	63.5125
2014	9	16	10	18	19	0.3	3.9	0.82	94.8	82.769	64.0288
2014	9	16	10	28	19	0.3	3.9	0.81	98.2	82.7034	62.9439
2014	9	16	10	38	19	0.3	3.9	0.85	95.8	82.7034	66.2975
2014	9	16	10	48	19	0.3	3.9	0.79	98.3	82.6378	61.6029
2014	9	16	10	58	19	0.3	3.9	0.83	95.4	82.6378	64.9537
2014	9	16	11	8	19	0.3	3.9	0.81	97.9	82.6378	63.1494
2014	9	16	11	18	19	0.3	3.9	0.8	96.6	82.5722	62.5819
2014	9	16	11	28	19	0.3	3.9	0.83	96.6	82.5722	64.3847
2014	9	16	11	38	19	0.3	3.9	0.81	95.8	82.5722	63.3545
2014	9	16	11	48	19	0.3	3.9	0.85	97.3	82.5722	65.9298
2014	9	16	11	58	19	0.3	3.9	0.83	95.2	82.5722	64.8997
2014	9	16	12	8	19	0.3	3.9	0.8	95	82.5722	62.3242
2014	9	16	12	18	19	0.3	3.9	0.81	97.7	82.5722	63.0968
2014	9	16	12	28	19	0.3	3.9	0.83	97	82.5066	64.8457
2014	9	16	12	38	19	0.3	3.9	0.75	97.5	82.5722	58.7186
2014	9	16	12	48	19	0.3	3.9	0.77	97.1	82.5722	60.2638
2014	9	16	12	58	19	0.3	3.9	0.84	94.7	82.5066	65.3603
2014	9	16	13	8	19	0.3	3.9	0.79	97.6	82.5066	61.5004
2014	9	16	13	18	19	0.3	3.9	0.79	95.9	82.5066	61.7577
2014	9	16	13	28	19	0.3	3.9	0.77	96.4	82.5066	59.6991
2014	9	16	13	38	19	0.3	3.9	0.75	97.3	82.5066	58.4124
2014	9	16	13	48	19	0.3	3.9	0.83	97.3	82.5066	64.5882
2014	9	16	13	58	19	0.3	3.9	0.8	97.3	82.5066	62.2722
2014	9	16	14	8	19	0.3	3.9	0.81	98.4	82.5066	63.0442
2014	9	16	14	18	19	0.3	3.9	0.77	96.6	82.4409	59.9065
2014	9	16	14	28	19	0.3	3.9	0.82	95.9	82.4409	64.2773
2014	9	16	14	38	19	0.3	3.9	0.8	98.3	82.5066	61.7575
2014	9	16	14	48	19	0.3	3.9	0.75	98.3	82.4409	57.8496
2014	9	16	14	58	19	0.3	3.9	0.81	95.3	82.4409	63.2488
2014	9	16	15	8	19	0.3	3.9	0.79	95.5	82.4409	61.9633
2014	9	16	15	18	19	0.3	3.6	0.79	99.3	82.4409	60.9348
2014	9	16	15	28	19	0.3	3.6	0.76	96.7	82.4409	59.135
2014	9	16	15	38	19	0.3	3.6	0.8	95.6	82.4409	62.4774

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	15	48	19	0.3	3.6	0.8	96.6	82.4409	61.9632
2014	9	16	15	58	19	0.3	3.6	0.79	96.7	82.3753	61.3979
2014	9	16	16	8	19	0.3	3.6	0.75	96.8	82.3753	58.572
2014	9	16	16	18	19	0.3	3.6	0.77	97.6	82.3753	59.5996
2014	9	16	16	28	19	0.3	3.6	0.81	97.9	82.4409	63.2487
2014	9	16	16	38	19	0.3	3.6	0.76	95.7	82.3753	59.5996
2014	9	16	16	48	19	0.3	3.6	0.76	97.7	82.3753	58.8289
2014	9	16	16	58	19	0.3	3.6	0.76	97.4	82.3753	59.0858
2014	9	16	17	8	19	0.3	3.6	0.78	97	82.3753	60.6271
2014	9	16	17	18	19	0.3	3.6	0.81	95.6	82.3753	63.1961
2014	9	16	17	28	19	0.3	3.6	0.79	96	82.3753	61.1409
2014	9	16	17	38	19	0.3	3.6	0.8	94.7	82.3753	62.4254
2014	9	16	17	48	19	0.3	3.6	0.81	97.7	82.3753	62.6823
2014	9	16	17	58	19	0.3	3.6	0.84	96.7	82.4409	65.5626
2014	9	16	18	8	19	0.3	3.6	0.82	96.5	82.4409	63.5057
2014	9	16	18	18	19	0.3	3.6	0.8	95.6	82.3753	62.4254
2014	9	16	18	28	19	0.3	3.6	0.82	96.4	82.4409	63.7628
2014	9	16	18	38	19	0.3	3.6	0.83	96.8	82.4409	64.5342
2014	9	16	18	48	19	0.3	3.6	0.8	97.8	82.4409	61.9631
2014	9	16	18	58	19	0.3	3.6	0.8	96.6	82.3753	62.4253
2014	9	16	19	8	19	0.3	3.6	0.82	96.5	82.3753	63.4529
2014	9	16	19	18	19	0.3	3.6	0.81	95.8	82.4409	62.9915
2014	9	16	19	28	19	0.3	3.6	0.79	97.9	82.4409	61.1917
2014	9	16	19	38	19	0.3	3.6	0.8	98	82.4409	62.2202
2014	9	16	19	48	19	0.3	3.6	0.83	95	82.4409	64.5342
2014	9	16	19	58	19	0.3	3.6	0.85	98.2	82.4409	65.8197
2014	9	16	20	8	19	0.3	3.6	0.84	95.6	82.4409	65.8197
2014	9	16	20	18	19	0.3	3.6	0.79	92.6	82.4409	61.9631
2014	9	16	20	28	19	0.3	3.6	0.81	96.5	82.4409	63.2486
2014	9	16	20	38	19	0.3	3.6	0.81	95.5	82.4409	63.5057
2014	9	16	20	48	19	0.3	3.6	0.82	94.6	82.4409	63.7628
2014	9	16	20	58	19	0.3	3.6	0.82	97.6	82.4409	63.5057
2014	9	16	21	8	19	0.3	3.6	0.81	98.4	82.4409	62.7344
2014	9	16	21	18	19	0.3	3.6	0.79	94.5	82.4409	61.9631
2014	9	16	21	28	19	0.3	3.6	0.81	96.1	82.4409	62.7344
2014	9	16	21	38	19	0.3	3.6	0.78	96.8	82.4409	60.6775
2014	9	16	21	48	19	0.3	3.6	0.85	94.7	82.4409	66.0768
2014	9	16	21	58	19	0.3	3.6	0.81	94.9	82.4409	63.2486
2014	9	16	22	8	19	0.3	3.6	0.86	96.8	82.4409	66.591
2014	9	16	22	18	19	0.3	3.6	0.87	94.3	82.4409	67.6195
2014	9	16	22	28	19	0.3	3.6	0.81	96	82.4409	63.5058
2014	9	16	22	38	19	0.3	3.6	0.8	96.4	82.4409	61.9631
2014	9	16	22	48	19	0.3	3.6	0.84	96	82.4409	65.8197
2014	9	16	22	58	19	0.3	3.6	0.79	95.5	82.4409	61.4489
2014	9	16	23	8	19	0.3	3.6	0.8	96.1	82.4409	62.2202
2014	9	16	23	18	19	0.3	3.6	0.82	96.2	82.4409	64.2771

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	16	23	28	19	0.3	3.6	0.77	97.5	82.4409	60.1634
2014	9	16	23	38	19	0.3	3.6	0.82	96.4	82.4409	63.7629
2014	9	16	23	48	19	0.3	3.6	0.78	97	82.4409	60.9347
2014	9	16	23	58	19	0.3	3.6	0.76	94.7	82.4409	59.3921
2014	9	17	0	8	19	0.3	3.6	0.77	96.3	82.4409	60.1634
2014	9	17	0	18	19	0.3	3.6	0.8	95.7	82.4409	62.2203
2014	9	17	0	28	19	0.3	3.6	0.79	99.3	82.4409	61.449
2014	9	17	0	38	19	0.3	3.6	0.78	94.6	82.5066	60.7281
2014	9	17	0	48	19	0.3	3.6	0.82	97.4	82.5066	63.816
2014	9	17	0	58	19	0.3	3.6	0.81	96.3	82.5066	63.3013
2014	9	17	1	8	19	0.3	3.6	0.81	95.8	82.5066	63.044
2014	9	17	1	18	19	0.3	3.6	0.8	98.7	82.4409	61.9632
2014	9	17	1	28	19	0.3	3.6	0.79	95.9	82.5066	61.7574
2014	9	17	1	38	19	0.3	3.6	0.83	95	82.4409	64.5343
2014	9	17	1	48	19	0.3	3.6	0.8	98.1	82.4409	61.7061
2014	9	17	1	58	19	0.3	3.6	0.77	96.4	82.5066	59.6988
2014	9	17	2	8	19	0.3	3.9	0.8	94.2	82.5066	62.5294
2014	9	17	2	18	19	0.3	3.9	0.79	97.8	82.5066	61.7574
2014	9	17	2	28	19	0.3	3.6	0.78	97	82.5066	60.7281
2014	9	17	2	38	19	0.3	3.6	0.78	96.5	82.5066	60.7281
2014	9	17	2	48	19	0.3	3.9	0.82	95.5	82.5066	64.0733
2014	9	17	2	58	19	0.3	3.9	0.84	95.4	82.5066	65.6173
2014	9	17	3	8	19	0.3	3.9	0.78	97	82.5066	60.4708
2014	9	17	3	18	19	0.3	3.9	0.81	96	82.5066	63.5587
2014	9	17	3	28	19	0.3	3.9	0.75	96	82.5066	58.4123
2014	9	17	3	38	19	0.3	3.9	0.8	97.7	82.5066	62.5294
2014	9	17	3	48	19	0.3	3.9	0.79	98.2	82.5722	61.0362
2014	9	17	3	58	19	0.3	3.9	0.83	98.6	82.5722	64.3841
2014	9	17	4	8	19	0.3	3.9	0.83	96.4	82.5722	64.6417
2014	9	17	4	18	19	0.3	3.9	0.78	96.7	82.5722	61.0362
2014	9	17	4	28	19	0.3	3.9	0.82	96.2	82.5722	64.3842
2014	9	17	4	38	19	0.3	3.9	0.82	94.6	82.6378	64.4376
2014	9	17	4	48	19	0.3	3.9	0.81	94.9	82.6378	63.4066
2014	9	17	4	58	19	0.3	3.9	0.81	95.6	82.6378	63.4066
2014	9	17	5	8	19	0.3	3.9	0.81	96.5	82.5722	63.354
2014	9	17	5	18	19	0.3	3.9	0.83	95	82.5722	65.1568
2014	9	17	5	28	19	0.3	3.9	0.81	96.5	82.6378	63.4066
2014	9	17	5	38	19	0.3	3.9	0.87	97.2	82.6378	67.5306
2014	9	17	5	48	19	0.3	3.9	0.83	99.6	82.6378	64.1799
2014	9	17	5	58	19	0.3	3.9	0.81	96.7	82.6378	63.4067
2014	9	17	6	8	19	0.3	3.9	0.84	96.8	82.6378	65.2109
2014	9	17	6	18	19	0.3	3.9	0.83	95.2	82.6378	64.6954
2014	9	17	6	28	19	0.3	3.9	0.82	97.4	82.6378	63.9222
2014	9	17	6	38	19	0.3	3.9	0.84	95.8	82.6378	65.7264
2014	9	17	6	48	19	0.3	3.9	0.78	97.5	82.6378	60.5714
2014	9	17	6	58	19	0.3	3.9	0.78	94.6	82.6378	61.087

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	7	8	19	0.3	3.9	0.79	95.5	82.6378	62.118
2014	9	17	7	18	19	0.3	3.9	0.82	95.3	82.6378	64.4377
2014	9	17	7	28	19	0.3	3.9	0.83	97	82.6378	64.9532
2014	9	17	7	38	19	0.3	3.9	0.79	97.9	82.6378	61.087
2014	9	17	7	48	19	0.3	3.9	0.86	95.9	82.6378	67.0153
2014	9	17	7	58	19	0.3	3.9	0.81	94.2	82.6378	63.4067
2014	9	17	8	8	19	0.3	3.9	0.79	96.7	82.6378	61.8602
2014	9	17	8	18	19	0.3	3.9	0.82	96	82.6378	64.18
2014	9	17	8	28	19	0.3	3.9	0.82	96.7	82.7034	63.7173
2014	9	17	8	38	19	0.3	3.9	0.8	97.3	82.7034	62.4274
2014	9	17	8	48	19	0.3	3.9	0.85	96.4	82.7034	66.2969
2014	9	17	8	58	19	0.3	3.9	0.82	96.2	82.7034	64.4911
2014	9	17	9	8	19	0.3	3.9	0.79	97.2	82.7034	61.3955
2014	9	17	9	18	19	0.3	3.9	0.82	96.4	82.7034	64.2331
2014	9	17	9	28	19	0.3	3.9	0.8	97.3	82.7034	62.4273
2014	9	17	9	38	19	0.3	3.9	0.83	97.5	82.7034	64.491
2014	9	17	9	48	19	0.3	3.9	0.79	96.2	82.7034	61.6534
2014	9	17	9	58	19	0.3	3.9	0.79	95.9	82.7034	62.1693
2014	9	17	10	8	19	0.3	3.6	0.79	98.6	82.7034	61.6534
2014	9	17	10	18	19	0.3	3.6	0.79	96.4	82.7034	61.9113
2014	9	17	10	28	19	0.3	3.6	0.81	96	82.7034	63.717
2014	9	17	10	38	19	0.3	3.6	0.81	96.5	82.7034	63.459
2014	9	17	10	48	19	0.3	3.6	0.82	96.2	82.769	64.0279
2014	9	17	10	58	19	0.3	3.6	0.8	95.7	82.7034	62.4271
2014	9	17	11	8	19	0.3	3.6	0.82	96.2	82.7034	63.9748
2014	9	17	11	18	19	0.3	3.6	0.8	97.1	82.7034	62.427
2014	9	17	11	28	19	0.3	3.6	0.79	97.9	82.7034	61.3952
2014	9	17	11	38	19	0.3	3.6	0.8	95.9	82.7034	62.6849
2014	9	17	11	48	19	0.3	3.6	0.82	94.8	82.7034	64.2327
2014	9	17	11	58	19	0.3	3.6	0.84	97.4	82.7034	65.2645
2014	9	17	12	8	19	0.3	3.6	0.79	95.9	82.6378	61.8596
2014	9	17	12	18	19	0.3	3.6	0.8	97.5	82.6378	62.6329
2014	9	17	12	28	19	0.3	3.6	0.8	98	82.6378	62.1173
2014	9	17	12	38	19	0.3	3.6	0.8	96.9	82.6378	62.1173
2014	9	17	12	48	19	0.3	3.6	0.78	97.3	82.6378	60.5708
2014	9	17	12	58	19	0.3	3.6	0.79	94.1	82.6378	61.8595
2014	9	17	13	8	19	0.3	3.6	0.82	95.7	82.6378	64.437
2014	9	17	13	18	19	0.3	3.6	0.79	97.4	82.6378	61.344
2014	9	17	13	28	19	0.3	3.6	0.78	95.8	82.6378	61.344
2014	9	17	13	38	19	0.3	3.6	0.81	97.9	82.6378	63.1482
2014	9	17	13	48	19	0.3	3.6	0.79	97.1	82.5722	61.8081
2014	9	17	13	58	19	0.3	3.6	0.75	97.2	82.5722	58.7177
2014	9	17	14	8	19	0.3	3.6	0.78	97.5	82.5722	60.7779
2014	9	17	14	18	19	0.3	3.6	0.8	94.5	82.6378	62.6326
2014	9	17	14	28	19	0.3	3.6	0.81	96.5	82.5722	63.3532
2014	9	17	14	38	19	0.3	3.6	0.76	94	82.5722	59.2327

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	14	48	19	0.3	3.6	0.79	94.1	82.5066	61.4994
2014	9	17	14	58	19	0.3	3.6	0.74	94.8	82.5066	57.6396
2014	9	17	15	8	19	0.3	3.6	0.78	96	82.5066	60.9848
2014	9	17	15	18	19	0.3	3.6	0.79	95.9	82.5066	61.7568
2014	9	17	15	28	19	0.3	3.6	0.81	95.1	82.5066	63.0433
2014	9	17	15	38	19	0.3	3.6	0.78	94.6	82.5066	60.7274
2014	9	17	15	48	19	0.3	3.6	0.78	96	82.5066	60.9847
2014	9	17	15	58	19	0.3	3.6	0.84	94.7	82.5066	65.3591
2014	9	17	16	8	19	0.3	3.6	0.79	97.4	82.5066	61.4993
2014	9	17	16	18	19	0.3	3.6	0.81	97.9	82.5066	62.7859
2014	9	17	16	28	19	0.3	3.6	0.77	95.6	82.4409	59.9056
2014	9	17	16	38	19	0.3	3.6	0.8	96.8	82.5066	62.5286
2014	9	17	16	48	19	0.3	3.6	0.79	97.1	82.5066	61.7566
2014	9	17	16	58	19	0.3	3.6	0.78	96.8	82.5066	60.7274
2014	9	17	17	8	19	0.3	3.6	0.79	97.2	82.5066	61.242
2014	9	17	17	18	19	0.3	3.6	0.77	97.4	82.4409	59.6485
2014	9	17	17	28	19	0.3	3.6	0.79	96.7	82.5066	61.7567
2014	9	17	17	38	19	0.3	3.6	0.78	98.5	82.4409	60.4198
2014	9	17	17	48	19	0.3	3.6	0.82	96.2	82.4409	64.0193
2014	9	17	17	58	19	0.3	3.6	0.8	97.1	82.4409	62.2196
2014	9	17	18	8	19	0.3	3.6	0.8	96.2	82.4409	61.9625
2014	9	17	18	18	19	0.3	3.6	0.75	96.5	82.4409	58.6201
2014	9	17	18	28	19	0.3	3.6	0.78	98	82.4409	60.1627
2014	9	17	18	38	19	0.3	3.6	0.79	96.9	82.5066	61.4993
2014	9	17	18	48	19	0.3	3.6	0.8	95.2	82.5066	62.2713
2014	9	17	18	58	19	0.3	3.6	0.75	94.5	82.5066	58.6688
2014	9	17	19	8	19	0.3	3.6	0.82	96.2	82.5722	64.1258
2014	9	17	19	18	19	0.3	3.6	0.84	96	82.5722	65.671
2014	9	17	19	28	19	0.3	3.6	0.79	97.2	82.5722	61.2929
2014	9	17	19	38	19	0.3	3.6	0.84	94.9	82.5722	65.671
2014	9	17	19	48	19	0.3	3.6	0.8	94.5	82.5722	62.323
2014	9	17	19	58	19	0.3	3.6	0.8	96.6	82.5722	62.5806
2014	9	17	20	8	19	0.3	3.6	0.81	96.7	82.5722	63.3532
2014	9	17	20	18	19	0.3	3.6	0.78	96	82.5722	61.0354
2014	9	17	20	28	19	0.3	3.6	0.8	97.7	82.5722	62.5806
2014	9	17	20	38	19	0.3	3.6	0.83	95.9	82.5722	64.6409
2014	9	17	20	48	19	0.3	3.6	0.81	95.3	82.5722	63.3532
2014	9	17	20	58	19	0.3	3.6	0.8	98	82.5722	62.0655
2014	9	17	21	8	19	0.3	3.6	0.81	97.7	82.5722	62.8381
2014	9	17	21	18	19	0.3	3.6	0.79	95	82.5722	61.5505
2014	9	17	21	28	19	0.3	3.6	0.78	97.2	82.5722	61.0354
2014	9	17	21	38	19	0.3	3.6	0.82	96.2	82.5722	63.6108
2014	9	17	21	48	19	0.3	3.6	0.79	96.4	82.5722	61.808
2014	9	17	21	58	19	0.3	3.6	0.79	96.2	82.5722	61.293
2014	9	17	22	8	19	0.3	3.6	0.84	95.4	82.5722	65.6711
2014	9	17	22	18	19	0.3	3.6	0.77	96.6	82.5722	60.0053

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	17	22	28	19	0.3	3.6	0.81	97.2	82.5722	63.3533
2014	9	17	22	38	19	0.3	3.6	0.82	96	82.5722	63.8683
2014	9	17	22	48	19	0.3	3.6	0.79	96	82.5722	61.5506
2014	9	17	22	58	19	0.3	3.6	0.81	94.2	82.5722	63.6108
2014	9	17	23	8	19	0.3	3.6	0.76	96.7	82.5066	59.1836
2014	9	17	23	18	19	0.3	3.6	0.8	96.2	82.5066	62.0141
2014	9	17	23	28	19	0.3	3.6	0.81	97.9	82.5722	63.3533
2014	9	17	23	38	19	0.3	3.6	0.79	98.9	82.5722	61.0355
2014	9	17	23	48	19	0.3	3.6	0.83	96.8	82.5722	64.3835
2014	9	17	23	58	19	0.3	3.6	0.77	97.1	82.5722	60.0054
2014	9	18	0	8	19	0.3	3.6	0.82	96.2	82.5722	63.6109
2014	9	18	0	18	19	0.3	3.6	0.8	95.4	82.5722	62.5807
2014	9	18	0	28	19	0.3	3.6	0.81	96.1	82.5722	62.8383
2014	9	18	0	38	19	0.3	3.6	0.78	95.8	82.5722	61.2931
2014	9	18	0	48	19	0.3	3.6	0.78	95.3	82.5722	61.2931
2014	9	18	0	58	19	0.3	3.6	0.76	97.2	82.5722	59.4904
2014	9	18	1	8	19	0.3	3.6	0.8	97.5	82.5722	62.3233
2014	9	18	1	18	19	0.3	3.6	0.8	94.5	82.5722	62.8383
2014	9	18	1	28	19	0.3	3.6	0.81	95.5	82.5722	63.6109
2014	9	18	1	38	19	0.3	3.6	0.78	95.8	82.5722	60.7781
2014	9	18	1	48	19	0.3	3.6	0.85	95.5	82.5722	66.4438
2014	9	18	1	58	19	0.3	3.6	0.83	97	82.5722	64.6411
2014	9	18	2	8	19	0.3	3.6	0.77	97.5	82.5722	60.263
2014	9	18	2	18	19	0.3	3.6	0.8	96.6	82.6378	62.1173
2014	9	18	2	28	19	0.3	3.6	0.79	95.9	82.6378	61.8595
2014	9	18	2	38	19	0.3	3.6	0.79	96.9	82.6378	61.6018
2014	9	18	2	48	19	0.3	3.6	0.81	97.2	82.6378	63.406
2014	9	18	2	58	19	0.3	3.6	0.79	95.7	82.6378	61.8596
2014	9	18	3	8	19	0.3	3.6	0.77	97.6	82.6378	60.0553
2014	9	18	3	18	19	0.3	3.6	0.79	97.6	82.5722	61.8083
2014	9	18	3	28	19	0.3	3.6	0.76	95.7	82.5722	58.9754
2014	9	18	3	38	19	0.3	3.6	0.81	96.5	82.6378	62.8906
2014	9	18	3	48	19	0.3	3.6	0.82	95.5	82.6378	64.1793
2014	9	18	3	58	19	0.3	3.6	0.79	96.2	82.6378	61.3441
2014	9	18	4	8	19	0.3	3.6	0.8	94.7	82.6378	62.3751
2014	9	18	4	18	19	0.3	3.6	0.83	96.8	82.6378	64.4371
2014	9	18	4	28	19	0.3	3.6	0.79	96.9	82.6378	61.6019
2014	9	18	4	38	19	0.3	3.6	0.82	99.7	82.6378	63.4061
2014	9	18	4	48	19	0.3	3.6	0.78	96.7	82.6378	61.0864
2014	9	18	4	58	19	0.3	3.6	0.8	95.4	82.6378	62.3752
2014	9	18	5	8	19	0.3	3.6	0.81	96.5	82.6378	63.1484
2014	9	18	5	18	19	0.3	3.6	0.77	94.6	82.6378	60.3132
2014	9	18	5	28	19	0.3	3.6	0.81	95.1	82.6378	63.6639
2014	9	18	5	38	19	0.3	3.6	0.81	97.9	82.6378	62.8907
2014	9	18	5	48	19	0.3	3.6	0.77	97.9	82.6378	59.7977
2014	9	18	5	58	19	0.3	3.6	0.82	96.4	82.6378	64.1794

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	6	8	19	0.3	3.6	0.77	97.9	82.6378	59.7977
2014	9	18	6	18	19	0.3	3.6	0.78	99.4	82.6378	60.571
2014	9	18	6	28	19	0.3	3.6	0.73	95.7	82.6378	57.2202
2014	9	18	6	38	19	0.3	3.6	0.82	95.7	82.6378	64.4372
2014	9	18	6	48	19	0.3	3.6	0.81	94.4	82.6378	63.664
2014	9	18	6	58	19	0.3	3.6	0.77	96.6	82.6378	60.0555
2014	9	18	7	8	19	0.3	3.6	0.82	97.6	82.6378	63.9218
2014	9	18	7	18	19	0.3	3.6	0.84	95.2	82.6378	65.4682
2014	9	18	7	28	19	0.3	3.6	0.8	99.4	82.6378	62.1175
2014	9	18	7	38	19	0.3	3.6	0.86	98.4	82.6378	66.4993
2014	9	18	7	48	19	0.3	3.6	0.79	95.7	82.6378	62.1175
2014	9	18	7	58	19	0.3	3.6	0.79	98.2	82.6378	61.0865
2014	9	18	8	8	19	0.3	3.6	0.79	95.7	82.6378	61.602
2014	9	18	8	18	19	0.3	3.6	0.82	95.1	82.6378	63.9218
2014	9	18	8	28	19	0.3	3.6	0.81	96.3	82.6378	63.1485
2014	9	18	8	38	19	0.3	3.6	0.82	95.3	82.5722	64.1263
2014	9	18	8	48	19	0.3	3.6	0.78	97.5	82.5722	61.0358
2014	9	18	8	58	19	0.3	3.6	0.79	99.6	82.5722	61.0358
2014	9	18	9	8	19	0.3	3.6	0.79	96.9	82.5722	61.5509
2014	9	18	9	18	19	0.3	3.6	0.84	97.4	82.5722	65.1563
2014	9	18	9	28	19	0.3	3.6	0.78	97	82.6378	61.0864
2014	9	18	9	38	19	0.3	3.6	0.77	97.1	82.5722	59.7481
2014	9	18	9	48	19	0.3	3.6	0.8	97.8	82.6378	62.1174
2014	9	18	9	58	19	0.3	3.6	0.79	96.2	82.5722	61.5508
2014	9	18	10	8	19	0.3	3.6	0.8	96.2	82.5722	62.0658
2014	9	18	10	18	19	0.3	3.6	0.76	100.6	82.5722	58.9754
2014	9	18	10	28	19	0.3	3.6	0.82	95.7	82.5722	64.3836
2014	9	18	10	38	19	0.3	3.6	0.81	96.8	82.5722	62.8384
2014	9	18	10	48	19	0.3	3.6	0.79	98.9	82.5722	61.0356
2014	9	18	10	58	19	0.3	3.6	0.8	95.2	82.5722	62.3233
2014	9	18	11	8	19	0.3	3.6	0.82	95.5	82.5722	64.3835
2014	9	18	11	18	19	0.3	3.6	0.81	97.9	82.5722	63.0958
2014	9	18	11	28	19	0.3	3.6	0.79	95.7	82.5722	61.5506
2014	9	18	11	38	19	0.3	3.6	0.76	96.4	82.5066	59.4409
2014	9	18	11	48	19	0.3	3.6	0.77	98.3	82.5066	59.9555
2014	9	18	11	58	19	0.3	3.6	0.81	97.9	82.5066	63.3006
2014	9	18	12	8	19	0.3	3.6	0.76	95.9	82.5066	59.4408
2014	9	18	12	18	19	0.3	3.6	0.8	95.6	82.4409	62.7338
2014	9	18	12	28	19	0.3	3.6	0.82	94.6	82.4409	64.0193
2014	9	18	12	38	19	0.3	3.6	0.78	96.3	82.4409	60.6769
2014	9	18	12	48	19	0.3	3.6	0.76	98.9	82.4409	58.8771
2014	9	18	12	58	19	0.3	3.6	0.77	97.1	82.4409	59.6484
2014	9	18	13	8	19	0.3	3.6	0.78	98.3	82.4409	60.1626
2014	9	18	13	18	19	0.3	3.6	0.74	95.9	82.4409	57.3345
2014	9	18	13	28	19	0.3	3.6	0.76	95.9	82.3753	59.3419
2014	9	18	13	38	19	0.3	3.6	0.78	97.2	82.4409	60.9339

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	13	48	19	0.3	3.6	0.76	94.9	82.3753	59.5988
2014	9	18	13	58	19	0.3	3.6	0.77	97.5	82.3097	60.0625
2014	9	18	14	8	19	0.3	3.6	0.76	96.2	82.3097	59.0358
2014	9	18	14	18	19	0.3	3.6	0.76	96.2	82.3097	59.0358
2014	9	18	14	28	19	0.3	3.6	0.78	96.8	82.3097	60.5759
2014	9	18	14	38	19	0.3	3.6	0.79	99.3	82.2441	61.2948
2014	9	18	14	48	19	0.3	3.6	0.74	96.3	82.2441	57.7043
2014	9	18	14	58	19	0.3	3.6	0.75	97.2	82.2441	58.4737
2014	9	18	15	8	19	0.3	3.6	0.8	94.5	82.1785	62.0124
2014	9	18	15	18	19	0.3	3.6	0.77	97.1	82.1785	59.9624
2014	9	18	15	28	19	0.3	3.6	0.81	95.6	82.1785	63.0374
2014	9	18	15	38	19	0.3	3.6	0.76	96.4	82.1129	59.1443
2014	9	18	15	48	19	0.3	3.6	0.81	99.1	82.1129	62.2167
2014	9	18	15	58	19	0.3	3.6	0.76	93.7	82.1129	58.8882
2014	9	18	16	8	19	0.3	3.6	0.77	97.6	82.1129	59.6564
2014	9	18	16	18	19	0.3	3.6	0.77	94.9	82.1129	60.1684
2014	9	18	16	28	19	0.3	3.6	0.78	95.6	82.1129	60.4244
2014	9	18	16	38	19	0.3	3.6	0.8	97.8	82.0472	61.6531
2014	9	18	16	48	19	0.3	3.6	0.78	97	82.0472	60.374
2014	9	18	16	58	19	0.3	3.6	0.83	95.9	82.0472	64.2114
2014	9	18	17	8	19	0.3	3.6	0.81	96.7	82.0472	62.9323
2014	9	18	17	18	19	0.3	3.6	0.8	97.7	82.0472	62.1648
2014	9	18	17	28	19	0.3	3.6	0.77	97.1	82.0472	59.8624
2014	9	18	17	38	19	0.3	3.6	0.78	98	81.9816	59.8124
2014	9	18	17	48	19	0.3	3.6	0.73	97.8	82.0472	56.2809
2014	9	18	17	58	19	0.3	3.6	0.79	96.7	82.0472	60.8857
2014	9	18	18	8	19	0.3	3.6	0.78	97	81.9816	60.5793
2014	9	18	18	18	19	0.3	3.6	0.78	95.8	81.9816	60.8349
2014	9	18	18	28	19	0.3	3.6	0.78	95.8	82.0472	60.1183
2014	9	18	18	38	19	0.3	3.6	0.81	95.1	81.9816	62.6241
2014	9	18	18	48	19	0.3	3.6	0.78	95.8	81.9816	60.8349
2014	9	18	18	58	19	0.3	3.6	0.81	99.6	82.0472	62.1648
2014	9	18	19	8	19	0.3	3.6	0.79	98.3	82.0472	61.1416
2014	9	18	19	18	19	0.3	3.6	0.77	95.4	82.0472	59.8625
2014	9	18	19	28	19	0.3	3.6	0.77	96.1	82.0472	59.8625
2014	9	18	19	38	19	0.3	3.6	0.76	96.4	82.0472	59.095
2014	9	18	19	48	19	0.3	3.6	0.79	96.7	82.0472	60.8858
2014	9	18	19	58	19	0.3	3.6	0.8	98.7	82.0472	61.9091
2014	9	18	20	8	19	0.3	3.6	0.74	96.9	82.0472	57.3043
2014	9	18	20	18	19	0.3	3.6	0.78	99.5	82.0472	59.6067
2014	9	18	20	28	19	0.3	3.6	0.77	95.9	82.0472	59.6067
2014	9	18	20	38	19	0.3	3.6	0.76	96.4	82.0472	58.8392
2014	9	18	20	48	19	0.3	3.6	0.79	96.2	82.0472	60.8858
2014	9	18	20	58	19	0.3	3.6	0.8	95.9	82.0472	62.4207
2014	9	18	21	8	19	0.3	3.6	0.79	98.3	82.0472	61.1416
2014	9	18	21	18	19	0.3	3.6	0.78	95.8	82.0472	60.1184

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	18	21	28	19	0.3	3.6	0.79	97.4	82.0472	61.1416
2014	9	18	21	38	19	0.3	3.6	0.78	96.6	82.0472	60.1184
2014	9	18	21	48	19	0.3	3.6	0.84	94.5	82.0472	64.979
2014	9	18	21	58	19	0.3	3.6	0.82	95.7	82.0472	63.6999
2014	9	18	22	8	19	0.3	3.6	0.8	97.3	82.1129	61.7048
2014	9	18	22	18	19	0.3	3.6	0.79	96.9	82.1129	61.1928
2014	9	18	22	28	19	0.3	3.6	0.8	96.2	82.1129	61.7049
2014	9	18	22	38	19	0.3	3.6	0.8	96.1	82.1129	62.217
2014	9	18	22	48	19	0.3	3.6	0.79	99	82.1129	61.1928
2014	9	18	22	58	19	0.3	3.6	0.8	96.9	82.1129	61.7049
2014	9	18	23	8	19	0.3	3.6	0.82	98.7	82.1785	63.2939
2014	9	18	23	18	19	0.3	3.6	0.82	96.2	82.1785	64.0627
2014	9	18	23	28	19	0.3	3.6	0.8	95.9	82.1129	62.217
2014	9	18	23	38	19	0.3	3.6	0.8	95.9	82.2441	62.3209
2014	9	18	23	48	19	0.3	3.6	0.8	98	82.3097	61.8595
2014	9	18	23	58	19	0.3	3.6	0.81	97.4	82.2441	62.8338
2014	9	19	0	8	19	0.3	3.6	0.83	96.4	82.3097	64.4263
2014	9	19	0	18	19	0.3	3.6	0.78	97.2	82.3097	60.8328
2014	9	19	0	28	19	0.3	3.6	0.8	95.9	82.3097	62.3729
2014	9	19	0	38	19	0.3	3.6	0.78	97	82.3097	60.8328
2014	9	19	0	48	19	0.3	3.6	0.83	95.5	82.3753	64.48
2014	9	19	0	58	19	0.3	3.6	0.8	95.4	82.3753	62.4249
2014	9	19	1	8	19	0.3	3.6	0.79	94.8	82.3097	61.6029
2014	9	19	1	18	19	0.3	3.6	0.79	97.7	82.3753	61.1404
2014	9	19	1	28	19	0.3	3.6	0.77	97.1	82.3753	59.5991
2014	9	19	1	38	19	0.3	3.6	0.77	96.6	82.3753	59.5991
2014	9	19	1	48	19	0.3	3.6	0.77	94.6	82.3753	60.1129
2014	9	19	1	58	19	0.3	3.6	0.81	94.4	82.3753	63.1957
2014	9	19	2	8	19	0.3	3.6	0.78	97	82.3753	60.3699
2014	9	19	2	18	19	0.3	3.6	0.79	96.9	82.3753	61.1406
2014	9	19	2	28	19	0.3	3.6	0.79	98.4	82.3753	61.1406
2014	9	19	2	38	19	0.3	3.6	0.8	95.2	82.3753	62.1682
2014	9	19	2	48	19	0.3	3.6	0.83	98.6	82.3753	64.4802
2014	9	19	2	58	19	0.3	3.6	0.83	95.5	82.3753	64.4802
2014	9	19	3	8	19	0.3	3.6	0.8	97	82.3753	62.4251
2014	9	19	3	18	19	0.3	3.6	0.8	99.2	82.3753	62.1682
2014	9	19	3	28	19	0.3	3.6	0.8	97.8	82.3753	62.1683
2014	9	19	3	38	19	0.3	3.6	0.78	94.6	82.3753	60.8838
2014	9	19	3	48	19	0.3	3.6	0.8	95.6	82.3753	62.4252
2014	9	19	3	58	19	0.3	3.6	0.79	95	82.3753	61.9114
2014	9	19	4	8	19	0.3	3.6	0.81	97.6	82.3753	63.1959
2014	9	19	4	18	19	0.3	3.6	0.83	95.5	82.3753	64.4804
2014	9	19	4	28	19	0.3	3.6	0.81	97.4	82.4409	62.9914
2014	9	19	4	38	19	0.3	3.6	0.78	98.4	82.3753	60.627
2014	9	19	4	48	19	0.3	3.6	0.8	96.6	82.4409	61.963
2014	9	19	4	58	19	0.3	3.6	0.81	96.1	82.4409	62.7344

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	5	8	19	0.3	3.6	0.83	94.6	82.4409	64.5342
2014	9	19	5	18	19	0.3	3.6	0.8	93.5	82.4409	62.4773
2014	9	19	5	28	19	0.3	3.6	0.82	96.4	82.4409	64.02
2014	9	19	5	38	19	0.3	3.6	0.8	98.3	82.4409	61.9631
2014	9	19	5	48	19	0.3	3.6	0.84	95.1	82.4409	65.8198
2014	9	19	5	58	19	0.3	3.6	0.81	97	82.4409	62.9916
2014	9	19	6	8	19	0.3	3.6	0.81	96.5	82.4409	62.9916
2014	9	19	6	18	19	0.3	3.6	0.84	96	82.4409	65.5627
2014	9	19	6	28	19	0.3	3.6	0.83	98	82.4409	64.2772
2014	9	19	6	38	19	0.3	3.6	0.81	97.9	82.4409	63.2488
2014	9	19	6	48	19	0.3	3.9	0.8	96.3	82.4409	62.4775
2014	9	19	6	58	19	0.3	3.9	0.8	96.6	82.4409	62.4775
2014	9	19	7	8	19	0.3	3.9	0.83	98.2	82.4409	64.2773
2014	9	19	7	18	19	0.3	3.9	0.85	97.3	82.4409	66.3341
2014	9	19	7	28	19	0.3	3.9	0.83	96.4	82.4409	64.2773
2014	9	19	7	38	19	0.3	3.9	0.8	96.1	82.4409	62.2204
2014	9	19	7	48	19	0.3	3.9	0.81	94.2	82.4409	62.9918
2014	9	19	7	58	19	0.3	3.9	0.79	95.5	82.4409	61.4491
2014	9	19	8	8	19	0.3	3.9	0.85	96.7	82.4409	65.82
2014	9	19	8	18	19	0.3	3.9	0.78	97.5	82.5066	60.4709
2014	9	19	8	28	19	0.3	3.9	0.78	93.9	82.5066	60.9856
2014	9	19	8	38	19	0.3	3.9	0.81	97.4	82.5066	63.0441
2014	9	19	8	48	19	0.3	3.9	0.85	96	82.5066	66.3893
2014	9	19	8	58	19	0.3	3.9	0.79	95	82.4409	61.4491
2014	9	19	9	8	19	0.3	3.9	0.79	96.7	82.5066	61.7575
2014	9	19	9	18	19	0.3	3.9	0.86	95.1	82.5066	66.9039
2014	9	19	9	28	19	0.3	3.9	0.8	95.9	82.5066	62.5294
2014	9	19	9	38	19	0.3	3.6	0.84	96.3	82.5066	65.3599
2014	9	19	9	48	19	0.3	3.6	0.79	94.7	82.5066	62.0147
2014	9	19	9	58	19	0.3	3.6	0.79	94.5	82.4409	61.449
2014	9	19	10	8	19	0.3	3.6	0.8	97.6	82.4409	61.9632
2014	9	19	10	18	19	0.3	3.6	0.79	92.8	82.4409	62.2203
2014	9	19	10	28	19	0.3	3.6	0.77	94.9	82.4409	60.4205
2014	9	19	10	38	19	0.3	3.6	0.81	94.2	82.4409	62.9915
2014	9	19	10	48	19	0.3	3.6	0.83	94.1	82.5066	65.1025
2014	9	19	10	58	19	0.3	3.6	0.81	94.9	82.5066	63.3012
2014	9	19	11	8	19	0.3	3.6	0.81	94.2	82.5066	63.0438
2014	9	19	11	18	19	0.3	3.6	0.84	96.3	82.5066	65.1024
2014	9	19	11	28	19	0.3	3.6	0.81	95.8	82.5066	63.0438
2014	9	19	11	38	19	0.3	3.6	0.79	96.9	82.4409	61.1916
2014	9	19	11	48	19	0.3	3.6	0.8	96.1	82.5066	62.2718
2014	9	19	11	58	19	0.3	3.6	0.77	96.3	82.4409	60.1632
2014	9	19	12	8	19	0.3	3.6	0.79	96.2	82.4409	61.4487
2014	9	19	12	18	19	0.3	3.6	0.83	93.6	82.4409	64.791
2014	9	19	12	28	19	0.3	3.6	0.79	95.2	82.4409	61.7057
2014	9	19	12	38	19	0.3	3.6	0.8	96.9	82.4409	61.9628

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	12	48	19	0.3	3.6	0.8	97.7	82.4409	62.477
2014	9	19	12	58	19	0.3	3.6	0.79	97.9	82.4409	60.9344
2014	9	19	13	8	19	0.3	3.6	0.8	97.8	82.4409	61.9628
2014	9	19	13	18	19	0.3	3.6	0.79	95.7	82.4409	61.4485
2014	9	19	13	28	19	0.3	3.6	0.82	94.2	82.4409	63.7625
2014	9	19	13	38	19	0.3	3.6	0.85	97.1	82.4409	66.0764
2014	9	19	13	48	19	0.3	3.6	0.77	95.6	82.4409	59.9058
2014	9	19	13	58	19	0.3	3.6	0.78	96.7	82.3753	60.8836
2014	9	19	14	8	19	0.3	3.6	0.81	97.7	82.3753	62.6818
2014	9	19	14	18	19	0.3	3.6	0.77	98.1	82.3753	59.856
2014	9	19	14	28	19	0.3	3.6	0.82	96	82.3097	63.6564
2014	9	19	14	38	19	0.3	3.6	0.79	95.9	82.3753	61.6542
2014	9	19	14	48	19	0.3	3.6	0.85	96.2	82.3753	66.0214
2014	9	19	14	58	19	0.3	3.6	0.8	96.8	82.3753	62.4249
2014	9	19	15	8	19	0.3	3.6	0.82	95	82.3753	64.2231
2014	9	19	15	18	19	0.3	3.6	0.82	96	82.3753	63.7093
2014	9	19	15	28	19	0.3	3.6	0.81	98.1	82.3097	62.8863
2014	9	19	15	38	19	0.3	3.6	0.76	95	82.3097	59.0361
2014	9	19	15	48	19	0.3	3.6	0.82	96	82.3097	63.913
2014	9	19	15	58	19	0.3	3.6	0.81	97.6	82.3097	63.1429
2014	9	19	16	8	19	0.3	3.6	0.76	96	82.2441	58.7305
2014	9	19	16	18	19	0.3	3.6	0.8	96.2	82.2441	61.808
2014	9	19	16	28	19	0.3	3.6	0.79	97.7	82.2441	61.0386
2014	9	19	16	38	19	0.3	3.6	0.79	95.7	82.2441	61.2951
2014	9	19	16	48	19	0.3	3.6	0.81	98.2	82.2441	62.321
2014	9	19	16	58	19	0.3	3.6	0.81	93.2	82.1785	63.5503
2014	9	19	17	8	19	0.3	3.6	0.8	96.1	82.2441	62.321
2014	9	19	17	18	19	0.3	3.6	0.8	94.3	82.1785	62.0128
2014	9	19	17	28	19	0.3	3.6	0.82	97.5	82.1785	63.8065
2014	9	19	17	38	19	0.3	3.6	0.8	96.8	82.1785	62.269
2014	9	19	17	48	19	0.3	3.6	0.8	95.2	82.1785	62.0128
2014	9	19	17	58	19	0.3	3.6	0.81	96.5	82.1129	62.7292
2014	9	19	18	8	19	0.3	3.6	0.82	96.4	82.1785	63.5503
2014	9	19	18	18	19	0.3	3.6	0.81	97.9	82.1785	63.0378
2014	9	19	18	28	19	0.3	3.6	0.8	96.6	82.1785	62.269
2014	9	19	18	38	19	0.3	3.6	0.83	95.9	82.1785	64.8315
2014	9	19	18	48	19	0.3	3.6	0.77	97.4	82.1785	59.4503
2014	9	19	18	58	19	0.3	3.6	0.81	96.5	82.1785	62.7815
2014	9	19	19	8	19	0.3	3.6	0.79	98.1	82.1785	60.9878
2014	9	19	19	18	19	0.3	3.6	0.79	97.9	82.2441	61.2951
2014	9	19	19	28	19	0.3	3.6	0.79	95.7	82.1785	61.244
2014	9	19	19	38	19	0.3	3.6	0.84	95.4	82.2441	65.3986
2014	9	19	19	48	19	0.3	3.6	0.85	96.2	82.2441	65.9115
2014	9	19	19	58	19	0.3	3.6	0.84	96.5	82.3097	64.9397
2014	9	19	20	8	19	0.3	3.6	0.77	96.2	82.2441	59.4999
2014	9	19	20	18	19	0.3	3.6	0.79	97.9	82.3097	61.3462

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	19	20	28	19	0.3	3.6	0.84	95.8	82.3097	65.7098
2014	9	19	20	38	19	0.3	3.6	0.81	96.1	82.3097	62.6297
2014	9	19	20	48	19	0.3	3.6	0.81	94.9	82.3097	63.143
2014	9	19	20	58	19	0.3	3.6	0.83	95.4	82.3097	64.9398
2014	9	19	21	8	19	0.3	3.6	0.84	94.5	82.3097	65.4532
2014	9	19	21	18	19	0.3	3.6	0.82	95.5	82.3097	64.1698
2014	9	19	21	28	19	0.3	3.6	0.8	97.5	82.3097	62.373
2014	9	19	21	38	19	0.3	3.6	0.78	97	82.3097	60.3196
2014	9	19	21	48	19	0.3	3.6	0.78	95.3	82.3753	61.1406
2014	9	19	21	58	19	0.3	3.6	0.76	98.4	82.3753	58.8285
2014	9	19	22	8	19	0.3	3.6	0.82	94.4	82.3753	63.7095
2014	9	19	22	18	19	0.3	3.6	0.8	95.6	82.3753	62.4251
2014	9	19	22	28	19	0.3	3.6	0.78	97	82.3753	60.8837
2014	9	19	22	38	19	0.3	3.6	0.8	97.1	82.3753	62.1682
2014	9	19	22	48	19	0.3	3.6	0.79	96.4	82.3753	61.6544
2014	9	19	22	58	19	0.3	3.6	0.79	95.7	82.3753	61.6544
2014	9	19	23	8	19	0.3	3.6	0.79	94.8	82.3753	61.6545
2014	9	19	23	18	19	0.3	3.6	0.81	95.8	82.3753	62.9389
2014	9	19	23	28	19	0.3	3.6	0.8	96.6	82.3753	62.1683
2014	9	19	23	38	19	0.3	3.6	0.8	98.5	82.3753	61.9114
2014	9	19	23	48	19	0.3	3.6	0.84	95.6	82.3753	65.5079
2014	9	19	23	58	19	0.3	3.6	0.81	95.5	82.3753	63.4528
2014	9	20	0	8	19	0.3	3.6	0.8	97.6	82.3753	61.9115
2014	9	20	0	18	19	0.3	3.6	0.8	94.5	82.3753	62.1684
2014	9	20	0	28	19	0.3	3.6	0.78	95.8	82.3753	60.8839
2014	9	20	0	38	19	0.3	3.6	0.8	96.2	82.3753	61.9115
2014	9	20	0	48	19	0.3	3.6	0.79	97.8	82.3753	61.6546
2014	9	20	0	58	19	0.3	3.6	0.82	97.8	82.4409	64.02
2014	9	20	1	8	19	0.3	3.6	0.79	95	82.4409	61.9631
2014	9	20	1	18	19	0.3	3.6	0.78	97	82.4409	60.9347
2014	9	20	1	28	19	0.3	3.6	0.81	96.3	82.4409	63.2487
2014	9	20	1	38	19	0.3	3.6	0.78	95.1	82.4409	60.9347
2014	9	20	1	48	19	0.3	3.6	0.82	96.4	82.4409	64.02
2014	9	20	1	58	19	0.3	3.6	0.84	95.2	82.4409	65.5627
2014	9	20	2	8	19	0.3	3.6	0.8	97	82.4409	62.4774
2014	9	20	2	18	19	0.3	3.6	0.85	95.5	82.4409	66.3341
2014	9	20	2	28	19	0.3	3.9	0.79	95.5	82.4409	61.449
2014	9	20	2	38	19	0.3	3.9	0.79	95.2	82.4409	61.7062
2014	9	20	2	48	19	0.3	3.9	0.78	97.2	82.4409	60.6777
2014	9	20	2	58	19	0.3	3.9	0.77	94.6	82.4409	60.4207
2014	9	20	3	8	19	0.3	3.9	0.8	97.6	82.4409	61.9633
2014	9	20	3	18	19	0.3	3.9	0.77	97.6	82.4409	59.6494
2014	9	20	3	28	19	0.3	3.9	0.79	95.9	82.4409	61.9634
2014	9	20	3	38	19	0.3	3.9	0.84	97	82.4409	65.3058
2014	9	20	3	48	19	0.3	3.9	0.82	95	82.4409	64.2774
2014	9	20	3	58	19	0.3	3.9	0.83	96.6	82.4409	64.7917

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	4	8	19	0.3	3.9	0.81	94.9	82.4409	62.9919
2014	9	20	4	18	19	0.3	3.9	0.77	93.7	82.4409	60.4208
2014	9	20	4	28	19	0.3	3.9	0.8	96.4	82.4409	61.9635
2014	9	20	4	38	19	0.3	3.9	0.82	96.9	82.4409	63.7633
2014	9	20	4	48	19	0.3	3.9	0.81	96.3	82.4409	62.7349
2014	9	20	4	58	19	0.3	3.9	0.81	97.7	82.4409	62.7349
2014	9	20	5	8	19	0.3	3.9	0.8	96.4	82.4409	61.9636
2014	9	20	5	18	19	0.3	3.9	0.8	95.9	82.4409	62.735
2014	9	20	5	28	19	0.3	3.9	0.8	94.2	82.5066	62.5298
2014	9	20	5	38	19	0.3	3.9	0.82	96.7	82.4409	63.5064
2014	9	20	5	48	19	0.3	3.9	0.81	95.1	82.4409	63.2493
2014	9	20	5	58	19	0.3	3.9	0.78	96.8	82.4409	60.6782
2014	9	20	6	8	19	0.3	3.9	0.79	94.8	82.4409	61.4495
2014	9	20	6	18	19	0.3	3.9	0.82	97.1	82.4409	63.7635
2014	9	20	6	28	19	0.3	3.9	0.78	94.3	82.4409	61.1925
2014	9	20	6	38	19	0.3	3.9	0.79	97.2	82.4409	61.4496
2014	9	20	6	48	19	0.3	3.9	0.83	97.3	82.4409	64.535
2014	9	20	6	58	19	0.3	3.9	0.83	95.2	82.4409	65.0492
2014	9	20	7	8	19	0.3	3.9	0.81	97	82.4409	63.2494
2014	9	20	7	18	19	0.3	3.9	0.81	96	82.5066	63.5594
2014	9	20	7	28	19	0.3	3.9	0.84	96.3	82.5066	65.1033
2014	9	20	7	38	19	0.3	3.9	0.8	96.6	82.5066	62.0154
2014	9	20	7	48	19	0.3	3.9	0.85	97.1	82.5066	65.8754
2014	9	20	7	58	19	0.3	3.9	0.83	95.2	82.5066	64.8461
2014	9	20	8	8	19	0.3	3.9	0.81	96.5	82.5066	63.0448
2014	9	20	8	18	19	0.3	3.9	0.81	98.2	82.5066	62.5301
2014	9	20	8	28	19	0.3	3.9	0.81	96.8	82.5066	63.0448
2014	9	20	8	38	19	0.3	3.9	0.8	97	82.5066	62.5301
2014	9	20	8	48	19	0.3	3.9	0.83	96.4	82.5066	64.3314
2014	9	20	8	58	19	0.3	3.9	0.8	97.7	82.5066	62.5301
2014	9	20	9	8	19	0.3	3.9	0.83	96.4	82.5066	64.5887
2014	9	20	9	18	19	0.3	3.9	0.79	96.7	82.5066	61.7581
2014	9	20	9	28	19	0.3	3.9	0.81	95.3	82.5066	63.3021
2014	9	20	9	38	19	0.3	3.9	0.82	96.5	82.5066	63.5593
2014	9	20	9	48	19	0.3	3.9	0.78	96.5	82.5066	60.7288
2014	9	20	9	58	19	0.3	3.9	0.79	96.2	82.5066	61.758
2014	9	20	10	8	19	0.3	3.9	0.8	96.4	82.5066	62.0153
2014	9	20	10	18	19	0.3	3.9	0.85	96	82.5066	66.1326
2014	9	20	10	28	19	0.3	3.9	0.8	94.7	82.5066	62.7873
2014	9	20	10	38	19	0.3	3.9	0.83	96.6	82.5066	64.3312
2014	9	20	10	48	19	0.3	3.9	0.83	95.2	82.5066	65.1031
2014	9	20	10	58	19	0.3	3.9	0.81	97.7	82.5066	63.0445
2014	9	20	11	8	19	0.3	3.9	0.8	96.4	82.5066	62.0151
2014	9	20	11	18	19	0.3	3.9	0.83	96.4	82.5066	64.331
2014	9	20	11	28	19	0.3	3.9	0.8	97.7	82.4409	62.4778
2014	9	20	11	38	19	0.3	3.9	0.8	95.9	82.5066	62.5297

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	11	48	19	0.3	3.9	0.79	95.5	82.4409	61.9635
2014	9	20	11	58	19	0.3	3.9	0.78	97.3	82.5066	60.471
2014	9	20	12	8	19	0.3	3.9	0.81	96.3	82.5066	63.3016
2014	9	20	12	18	19	0.3	3.9	0.78	97.7	82.4409	60.6779
2014	9	20	12	28	19	0.3	3.9	0.77	95.4	82.4409	59.9065
2014	9	20	12	38	19	0.3	3.9	0.78	96.5	82.4409	60.6778
2014	9	20	12	48	19	0.3	3.9	0.78	96	82.4409	60.6778
2014	9	20	12	58	19	0.3	3.9	0.75	96.1	82.4409	58.1067
2014	9	20	13	8	19	0.3	3.6	0.8	97.3	82.3753	62.1687
2014	9	20	13	18	19	0.3	3.9	0.8	96.6	82.4409	61.9633
2014	9	20	13	28	19	0.3	3.6	0.8	95.4	82.3753	62.6824
2014	9	20	13	38	19	0.3	3.6	0.76	94.2	82.3753	59.5996
2014	9	20	13	48	19	0.3	3.6	0.75	97.2	82.3753	58.5721
2014	9	20	13	58	19	0.3	3.6	0.78	97.3	82.3753	60.3703
2014	9	20	14	8	19	0.3	3.6	0.78	96.7	82.3753	60.8841
2014	9	20	14	18	19	0.3	3.6	0.79	95.2	82.3097	61.6035
2014	9	20	14	28	19	0.3	3.6	0.79	95.9	82.3753	61.9117
2014	9	20	14	38	19	0.3	3.6	0.82	96.7	82.3753	63.453
2014	9	20	14	48	19	0.3	3.6	0.78	97	82.3097	60.5767
2014	9	20	14	58	19	0.3	3.6	0.79	97.4	82.2441	61.2957
2014	9	20	15	8	19	0.3	3.6	0.79	96.9	82.3097	61.09
2014	9	20	15	18	19	0.3	3.6	0.8	97.3	82.2441	61.8086
2014	9	20	15	28	19	0.3	3.6	0.81	97.7	82.3097	62.6301
2014	9	20	15	38	19	0.3	3.6	0.83	95.4	82.2441	64.8861
2014	9	20	15	48	19	0.3	3.6	0.8	99.2	82.2441	61.8085
2014	9	20	15	58	19	0.3	3.6	0.83	96.8	82.2441	64.1167
2014	9	20	16	8	19	0.3	3.6	0.77	96.6	82.3097	59.8066
2014	9	20	16	18	19	0.3	3.6	0.77	96.4	82.3097	59.5499
2014	9	20	16	28	19	0.3	3.6	0.8	95.9	82.1129	62.2175
2014	9	20	16	38	19	0.3	3.6	0.82	96.6	82.3097	63.9134
2014	9	20	16	48	19	0.3	3.6	0.79	95.7	82.2441	61.2956
2014	9	20	16	58	19	0.3	3.6	0.8	95.6	82.1129	62.2175
2014	9	20	17	8	19	0.3	3.6	0.76	95.4	82.2441	59.5003
2014	9	20	17	18	19	0.3	3.6	0.82	95.5	82.2441	64.1167
2014	9	20	17	28	19	0.3	3.6	0.83	96.4	82.2441	64.3732
2014	9	20	17	38	19	0.3	3.6	0.84	96.8	82.2441	64.8861
2014	9	20	17	48	19	0.3	3.6	0.85	95.3	82.2441	65.912
2014	9	20	17	58	19	0.3	3.6	0.81	95.6	82.2441	63.0908
2014	9	20	18	8	19	0.3	3.6	0.81	96	82.2441	63.0908
2014	9	20	18	18	19	0.3	3.6	0.82	94.8	82.2441	63.8602
2014	9	20	18	28	19	0.3	3.6	0.81	96.5	82.2441	62.8344
2014	9	20	18	38	19	0.3	3.6	0.78	96.7	82.2441	60.7826
2014	9	20	18	48	19	0.3	3.6	0.77	95.3	82.3097	60.3199
2014	9	20	18	58	19	0.3	3.6	0.77	93.9	82.2441	60.0132
2014	9	20	19	8	19	0.3	3.6	0.8	97.6	82.2441	61.8085
2014	9	20	19	18	19	0.3	3.6	0.81	97.7	82.1129	62.4736

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	20	19	28	19	0.3	3.6	0.8	96.2	82.1129	61.7055
2014	9	20	19	38	19	0.3	3.6	0.83	95	82.2441	64.8861
2014	9	20	19	48	19	0.3	3.6	0.79	97.9	82.2441	61.2956
2014	9	20	19	58	19	0.3	3.6	0.8	94.7	82.3097	62.3734
2014	9	20	20	8	19	0.3	3.6	0.73	97.2	82.1129	56.5847
2014	9	20	20	18	19	0.3	3.6	0.77	95.1	82.1785	59.9632
2014	9	20	20	28	19	0.3	3.6	0.81	95.8	82.2441	62.8344
2014	9	20	20	38	19	0.3	3.6	0.82	95.8	82.2441	63.6038
2014	9	20	20	48	19	0.3	3.6	0.79	95.2	82.3097	61.86
2014	9	20	20	58	19	0.3	3.6	0.81	97.6	82.3097	63.1435
2014	9	20	21	8	19	0.3	3.6	0.77	95.3	82.3097	60.32
2014	9	20	21	18	19	0.3	3.6	0.83	96.8	82.3097	64.4269
2014	9	20	21	28	19	0.3	3.6	0.85	95.7	82.3097	66.4803
2014	9	20	21	38	19	0.3	3.6	0.78	98.2	82.3097	60.5767
2014	9	20	21	48	19	0.3	3.6	0.82	96.2	82.3097	63.6569
2014	9	20	21	58	19	0.3	3.6	0.83	96.3	82.3753	64.7374
2014	9	20	22	8	19	0.3	3.6	0.81	96.1	82.3097	62.6301
2014	9	20	22	18	19	0.3	3.6	0.83	97.5	82.3753	64.2237
2014	9	20	22	28	19	0.3	3.6	0.8	97.8	82.3753	62.1685
2014	9	20	22	38	19	0.3	3.6	0.81	95.1	82.3753	63.1961
2014	9	20	22	48	19	0.3	3.6	0.8	95.4	82.3753	62.6823
2014	9	20	22	58	19	0.3	3.6	0.84	98.3	82.3753	65.2513
2014	9	20	23	8	19	0.3	3.6	0.82	95.1	82.3753	63.7099
2014	9	20	23	18	19	0.3	3.6	0.83	96.4	82.3753	64.4806
2014	9	20	23	28	19	0.3	3.6	0.81	96	82.3753	63.453
2014	9	20	23	38	19	0.3	3.6	0.83	95.5	82.3753	64.4806
2014	9	20	23	48	19	0.3	3.6	0.79	96	82.3753	61.141
2014	9	20	23	58	19	0.3	3.6	0.8	94.9	82.3753	62.6824
2014	9	21	0	8	19	0.3	3.6	0.76	94.7	82.3753	59.5996
2014	9	21	0	18	19	0.3	3.6	0.8	95.9	82.3753	62.4255
2014	9	21	0	28	19	0.3	3.6	0.84	95.2	82.3753	65.5082
2014	9	21	0	38	19	0.3	3.9	0.84	95.2	82.4409	65.3056
2014	9	21	0	48	19	0.3	3.9	0.8	94.7	82.4409	62.4775
2014	9	21	0	58	19	0.3	3.6	0.78	94.3	82.3753	61.1411
2014	9	21	1	8	19	0.3	3.9	0.81	97.4	82.4409	63.2488
2014	9	21	1	18	19	0.3	3.9	0.78	95.3	82.4409	61.192
2014	9	21	1	28	19	0.3	3.9	0.81	95.8	82.4409	62.9917
2014	9	21	1	38	19	0.3	3.9	0.78	95.8	82.4409	60.9349
2014	9	21	1	48	19	0.3	3.9	0.82	95.3	82.4409	63.7631
2014	9	21	1	58	19	0.3	3.9	0.81	98.2	82.4409	62.4775
2014	9	21	2	8	19	0.3	3.6	0.81	97	82.3753	62.9394
2014	9	21	2	18	19	0.3	3.9	0.79	95.5	82.4409	61.7062
2014	9	21	2	28	19	0.3	3.6	0.78	94.8	82.3753	61.1411
2014	9	21	2	38	19	0.3	3.9	0.84	95.1	82.4409	65.82
2014	9	21	2	48	19	0.3	3.9	0.82	94.1	82.4409	64.2774
2014	9	21	2	58	19	0.3	3.9	0.84	97	82.4409	65.3058

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	3	8	19	0.3	3.9	0.88	93.9	82.4409	68.6482
2014	9	21	3	18	19	0.3	3.9	0.8	94.5	82.5066	62.7869
2014	9	21	3	28	19	0.3	3.9	0.83	96.8	82.5066	64.3308
2014	9	21	3	38	19	0.3	3.9	0.85	95.3	82.5066	66.6468
2014	9	21	3	48	19	0.3	3.9	0.83	95.2	82.5066	64.5882
2014	9	21	3	58	19	0.3	3.9	0.84	98.1	82.5066	64.8455
2014	9	21	4	8	19	0.3	3.9	0.8	98.5	82.5066	62.2723
2014	9	21	4	18	19	0.3	3.9	0.83	93.4	82.5066	65.1029
2014	9	21	4	28	19	0.3	3.9	0.8	97	82.5066	62.5296
2014	9	21	4	38	19	0.3	3.9	0.83	97.3	82.5066	64.3309
2014	9	21	4	48	19	0.3	3.9	0.82	94.8	82.5066	64.3309
2014	9	21	4	58	19	0.3	3.9	0.83	96.6	82.5066	64.3309
2014	9	21	5	8	19	0.3	3.9	0.84	95.2	82.5066	65.3602
2014	9	21	5	18	19	0.3	3.9	0.85	96.4	82.5066	66.1322
2014	9	21	5	28	19	0.3	3.9	0.85	97.1	82.5066	65.8749
2014	9	21	5	38	19	0.3	3.9	0.8	94.7	82.5066	62.787
2014	9	21	5	48	19	0.3	3.9	0.79	97.2	82.5066	61.5004
2014	9	21	5	58	19	0.3	3.9	0.83	94.5	82.5066	65.103
2014	9	21	6	8	19	0.3	3.9	0.83	94.8	82.5066	64.8456
2014	9	21	6	18	19	0.3	3.9	0.81	96.8	82.5066	63.0444
2014	9	21	6	28	19	0.3	3.9	0.82	95.9	82.5066	64.331
2014	9	21	6	38	19	0.3	3.9	0.81	96	82.5066	63.5591
2014	9	21	6	48	19	0.3	3.9	0.76	97.4	82.5066	59.4419
2014	9	21	6	58	19	0.3	3.9	0.82	96.6	82.5066	64.0737
2014	9	21	7	8	19	0.3	3.9	0.82	95.5	82.5066	64.0737
2014	9	21	7	18	19	0.3	3.9	0.82	95.9	82.5722	64.3845
2014	9	21	7	28	19	0.3	3.9	0.81	97.9	82.5722	62.8393
2014	9	21	7	38	19	0.3	3.9	0.83	96.6	82.5722	64.3845
2014	9	21	7	48	19	0.3	3.9	0.82	94.3	82.5722	64.3845
2014	9	21	7	58	19	0.3	3.9	0.82	94.8	82.5722	64.3845
2014	9	21	8	8	19	0.3	3.9	0.84	96.5	82.5722	65.6722
2014	9	21	8	18	19	0.3	3.9	0.83	95.2	82.5722	65.1572
2014	9	21	8	28	19	0.3	3.9	0.81	97	82.5722	63.3544
2014	9	21	8	38	19	0.3	3.9	0.84	97.9	82.5722	65.1571
2014	9	21	8	48	19	0.3	3.9	0.81	96.3	82.5722	62.8393
2014	9	21	8	58	19	0.3	3.9	0.81	96.3	82.5722	63.3543
2014	9	21	9	8	19	0.3	3.9	0.77	96.1	82.5722	60.2639
2014	9	21	9	18	19	0.3	3.9	0.81	95.1	82.5722	63.3543
2014	9	21	9	28	19	0.3	3.9	0.85	97.1	82.5722	66.4447
2014	9	21	9	38	19	0.3	3.9	0.83	96.1	82.5722	64.642
2014	9	21	9	48	19	0.3	3.9	0.8	94.5	82.5722	62.8392
2014	9	21	9	58	19	0.3	3.9	0.82	96.4	82.5722	63.8693
2014	9	21	10	8	19	0.3	3.9	0.81	97.9	82.6378	62.8913
2014	9	21	10	18	19	0.3	3.9	0.81	94.9	82.6378	63.149
2014	9	21	10	28	19	0.3	3.9	0.84	96.1	82.6378	65.4687
2014	9	21	10	38	19	0.3	3.9	0.81	98.4	82.6378	63.149

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	10	48	19	0.3	3.9	0.81	96.8	82.6378	62.8912
2014	9	21	10	58	19	0.3	3.9	0.84	95.6	82.6378	65.7264
2014	9	21	11	8	19	0.3	3.9	0.83	96.4	82.6378	64.6954
2014	9	21	11	18	19	0.3	3.9	0.84	96.5	82.6378	65.4686
2014	9	21	11	28	19	0.3	3.9	0.78	96.6	82.5722	60.5211
2014	9	21	11	38	19	0.3	3.9	0.84	98	82.5722	65.6718
2014	9	21	11	48	19	0.3	3.9	0.8	97.3	82.5722	62.3238
2014	9	21	11	58	19	0.3	3.6	0.84	96.3	82.5722	65.6717
2014	9	21	12	8	19	0.3	3.6	0.81	95.8	82.5722	63.0963
2014	9	21	12	18	19	0.3	3.6	0.8	95.4	82.5722	62.8389
2014	9	21	12	28	19	0.3	3.9	0.81	96.1	82.5722	62.8389
2014	9	21	12	38	19	0.3	3.9	0.8	96.9	82.5722	62.0663
2014	9	21	12	48	19	0.3	3.6	0.83	95.2	82.5722	64.6415
2014	9	21	12	58	19	0.3	3.6	0.82	95.8	82.5066	63.8159
2014	9	21	13	8	19	0.3	3.6	0.81	97	82.5722	63.0963
2014	9	21	13	18	19	0.3	3.6	0.74	96.6	82.5066	57.6402
2014	9	21	13	28	19	0.3	3.6	0.81	96.7	82.5066	63.3013
2014	9	21	13	38	19	0.3	3.6	0.78	95.3	82.5066	61.2427
2014	9	21	13	48	19	0.3	3.6	0.81	96	82.5066	63.3012
2014	9	21	13	58	19	0.3	3.6	0.79	98.1	82.5066	61.4999
2014	9	21	14	8	19	0.3	3.6	0.8	97.3	82.5066	62.2718
2014	9	21	14	18	19	0.3	3.6	0.83	98.8	82.5066	64.5877
2014	9	21	14	28	19	0.3	3.6	0.8	95.6	82.5066	62.5292
2014	9	21	14	38	19	0.3	3.6	0.83	97.5	82.5722	64.6413
2014	9	21	14	48	19	0.3	3.6	0.83	96.6	82.5066	64.5877
2014	9	21	14	58	19	0.3	3.6	0.8	97.3	82.5066	62.2718
2014	9	21	15	8	19	0.3	3.6	0.82	95.3	82.5066	64.0731
2014	9	21	15	18	19	0.3	3.6	0.83	96.4	82.5066	64.3304
2014	9	21	15	28	19	0.3	3.6	0.85	95.3	82.4409	66.0767
2014	9	21	15	38	19	0.3	3.6	0.77	95.2	82.5066	59.9559
2014	9	21	15	48	19	0.3	3.6	0.81	97	82.4409	62.9913
2014	9	21	15	58	19	0.3	3.6	0.75	96.5	82.5066	58.6693
2014	9	21	16	8	19	0.3	3.6	0.81	95.6	82.5066	63.301
2014	9	21	16	18	19	0.3	3.6	0.81	95.8	82.5066	63.0437
2014	9	21	16	28	19	0.3	3.6	0.82	94.1	82.5066	64.3303
2014	9	21	16	38	19	0.3	3.6	0.84	94.7	82.5066	65.3596
2014	9	21	16	48	19	0.3	3.6	0.8	95.4	82.4409	62.22
2014	9	21	16	58	19	0.3	3.6	0.81	95.1	82.5066	63.5584
2014	9	21	17	8	19	0.3	3.6	0.83	96.4	82.5066	64.3303
2014	9	21	17	18	19	0.3	3.6	0.83	97.3	82.5066	64.5876
2014	9	21	17	28	19	0.3	3.6	0.8	97.3	82.4409	62.22
2014	9	21	17	38	19	0.3	3.6	0.81	97.4	82.5066	63.0437
2014	9	21	17	48	19	0.3	3.6	0.8	97.3	82.5066	62.0144
2014	9	21	17	58	19	0.3	3.6	0.8	95.6	82.5066	62.7864
2014	9	21	18	8	19	0.3	3.6	0.83	98	82.5066	64.3303
2014	9	21	18	18	19	0.3	3.6	0.83	97.7	82.4409	64.534

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	21	18	28	19	0.3	3.6	0.81	95.8	82.5066	63.0437
2014	9	21	18	38	19	0.3	3.6	0.84	96	82.5066	65.6169
2014	9	21	18	48	19	0.3	3.6	0.83	96.4	82.5066	64.5876
2014	9	21	18	58	19	0.3	3.6	0.85	96.9	82.5066	66.1316
2014	9	21	19	8	19	0.3	3.6	0.82	95.1	82.5066	63.8157
2014	9	21	19	18	19	0.3	3.6	0.82	96.4	82.5066	63.8157
2014	9	21	19	28	19	0.3	3.6	0.81	95.8	82.5066	63.0437
2014	9	21	19	38	19	0.3	3.6	0.79	95.5	82.5066	61.4998
2014	9	21	19	48	19	0.3	3.6	0.86	96.1	82.5066	66.9036
2014	9	21	19	58	19	0.3	3.6	0.81	96.5	82.5066	63.0438
2014	9	21	20	8	19	0.3	3.6	0.86	94	82.5066	66.9036
2014	9	21	20	18	19	0.3	3.6	0.83	96.1	82.5066	65.1023
2014	9	21	20	28	19	0.3	3.6	0.83	97.5	82.5066	64.5877
2014	9	21	20	38	19	0.3	3.6	0.84	96	82.5066	65.8743
2014	9	21	20	48	19	0.3	3.6	0.8	96.9	82.5066	62.0145
2014	9	21	20	58	19	0.3	3.6	0.81	96.3	82.5066	63.0438
2014	9	21	21	8	19	0.3	3.6	0.83	95.7	82.5066	64.5878
2014	9	21	21	18	19	0.3	3.6	0.87	97.1	82.5066	67.933
2014	9	21	21	28	19	0.3	3.6	0.8	93.8	82.5066	62.7865
2014	9	21	21	38	19	0.3	3.6	0.83	96.8	82.5066	64.3305
2014	9	21	21	48	19	0.3	3.6	0.81	95.8	82.5066	63.0439
2014	9	21	21	58	19	0.3	3.6	0.84	97.9	82.5066	65.1025
2014	9	21	22	8	19	0.3	3.6	0.81	96.5	82.5066	62.7866
2014	9	21	22	18	19	0.3	3.6	0.83	94.6	82.5066	64.5879
2014	9	21	22	28	19	0.3	3.6	0.85	94.7	82.5066	66.1318
2014	9	21	22	38	19	0.3	3.6	0.8	97	82.5066	62.5293
2014	9	21	22	48	19	0.3	3.6	0.79	95.2	82.5066	62.0147
2014	9	21	22	58	19	0.3	3.6	0.8	97.3	82.4409	62.2203
2014	9	21	23	8	19	0.3	3.6	0.82	95.8	82.4409	63.763
2014	9	21	23	18	19	0.3	3.6	0.81	94.9	82.4409	63.5059
2014	9	21	23	28	19	0.3	3.6	0.81	98.4	82.4409	62.9917
2014	9	21	23	38	19	0.3	3.6	0.81	95.3	82.4409	63.2488
2014	9	21	23	48	19	0.3	3.9	0.82	96.4	82.4409	63.763
2014	9	21	23	58	19	0.3	3.9	0.8	96.6	82.4409	62.2204
2014	9	22	0	8	19	0.3	3.9	0.8	96.6	82.4409	62.4775
2014	9	22	0	18	19	0.3	3.9	0.81	96	82.4409	63.506
2014	9	22	0	28	19	0.3	3.9	0.84	96.5	82.4409	65.5628
2014	9	22	0	38	19	0.3	3.9	0.82	93.4	82.4409	64.2773
2014	9	22	0	48	19	0.3	3.9	0.82	95.5	82.4409	64.0202
2014	9	22	0	58	19	0.3	3.9	0.79	95.9	82.4409	61.7063
2014	9	22	1	8	19	0.3	3.9	0.83	95.2	82.4409	64.5345
2014	9	22	1	18	19	0.3	3.9	0.8	95	82.4409	62.2205
2014	9	22	1	28	19	0.3	3.9	0.79	95.9	82.4409	61.7063
2014	9	22	1	38	19	0.3	3.9	0.78	95.3	82.4409	61.1921
2014	9	22	1	48	19	0.3	3.9	0.8	94.5	82.4409	62.7348
2014	9	22	1	58	19	0.3	3.9	0.77	96.1	82.4409	59.9066

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	2	8	19	0.3	3.9	0.79	96.4	82.5066	61.7577
2014	9	22	2	18	19	0.3	3.9	0.81	97.9	82.5066	63.0443
2014	9	22	2	28	19	0.3	3.9	0.83	97.3	82.4409	64.2775
2014	9	22	2	38	19	0.3	3.9	0.83	95.7	82.4409	64.5346
2014	9	22	2	48	19	0.3	3.9	0.84	94.1	82.4409	65.306
2014	9	22	2	58	19	0.3	3.9	0.79	96.2	82.4409	61.4493
2014	9	22	3	8	19	0.3	3.9	0.83	96.6	82.4409	64.2776
2014	9	22	3	18	19	0.3	3.9	0.81	97.7	82.4409	62.992
2014	9	22	3	28	19	0.3	3.9	0.8	95	82.4409	62.2207
2014	9	22	3	38	19	0.3	3.9	0.8	98.3	82.4409	61.9636
2014	9	22	3	48	19	0.3	3.9	0.84	95.8	82.4409	65.5632
2014	9	22	3	58	19	0.3	3.9	0.79	95.5	82.4409	61.4494
2014	9	22	4	8	19	0.3	3.9	0.83	96.4	82.4409	64.2777
2014	9	22	4	18	19	0.3	3.9	0.81	95.5	82.4409	63.5064
2014	9	22	4	28	19	0.3	3.9	0.82	95.3	82.4409	64.0206
2014	9	22	4	38	19	0.3	3.9	0.82	96.4	82.4409	64.0206
2014	9	22	4	48	19	0.3	3.9	0.8	100.1	82.4409	61.9637
2014	9	22	4	58	19	0.3	3.9	0.83	96.1	82.4409	65.0491
2014	9	22	5	8	19	0.3	3.9	0.8	94	82.4409	62.7351
2014	9	22	5	18	19	0.3	3.9	0.8	95.4	82.4409	62.7351
2014	9	22	5	28	19	0.3	3.9	0.82	94.2	82.4409	63.7636
2014	9	22	5	38	19	0.3	3.9	0.83	96.1	82.4409	65.0492
2014	9	22	5	48	19	0.3	3.9	0.8	96.1	82.4409	62.4781
2014	9	22	5	58	19	0.3	3.9	0.84	95.2	82.4409	65.5634
2014	9	22	6	8	19	0.3	3.9	0.79	96.2	82.4409	61.4497
2014	9	22	6	18	19	0.3	3.9	0.83	97.9	82.4409	64.535
2014	9	22	6	28	19	0.3	3.9	0.81	94.6	82.4409	63.2495
2014	9	22	6	38	19	0.3	3.9	0.83	94.3	82.4409	65.0493
2014	9	22	6	48	19	0.3	3.9	0.8	96.8	82.4409	62.4782
2014	9	22	6	58	19	0.3	3.9	0.84	98	82.4409	65.5635
2014	9	22	7	8	19	0.3	3.9	0.82	95.5	82.4409	64.278
2014	9	22	7	18	19	0.3	3.9	0.83	96.6	82.4409	64.7922
2014	9	22	7	28	19	0.3	3.9	0.82	96.2	82.4409	63.7638
2014	9	22	7	38	19	0.3	3.9	0.86	95.7	82.5066	66.9047
2014	9	22	7	48	19	0.3	3.9	0.78	95.1	82.4409	60.9356
2014	9	22	7	58	19	0.3	3.9	0.81	94.2	82.4409	63.5067
2014	9	22	8	8	19	0.3	3.9	0.84	97.6	82.4409	65.5636
2014	9	22	8	18	19	0.3	3.9	0.82	94.2	82.5066	63.8169
2014	9	22	8	28	19	0.3	3.9	0.82	95.3	82.5066	63.8168
2014	9	22	8	38	19	0.3	3.9	0.83	96.3	82.4409	64.7923
2014	9	22	8	48	19	0.3	3.9	0.81	96.8	82.5066	63.0449
2014	9	22	8	58	19	0.3	3.9	0.8	95.6	82.5066	62.5302
2014	9	22	9	8	19	0.3	3.9	0.8	96.1	82.5066	62.5302
2014	9	22	9	18	19	0.3	3.9	0.82	96.2	82.5066	63.8168
2014	9	22	9	28	19	0.3	3.9	0.86	97.7	82.5066	66.6473
2014	9	22	9	38	19	0.3	3.9	0.8	93.3	82.5066	62.5301

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	9	48	19	0.3	3.9	0.83	95.4	82.5066	64.846
2014	9	22	9	58	19	0.3	3.9	0.77	94.6	82.5066	60.2141
2014	9	22	10	8	19	0.3	3.9	0.81	96.8	82.5066	63.0447
2014	9	22	10	18	19	0.3	3.9	0.84	96.9	82.5066	65.6179
2014	9	22	10	28	19	0.3	3.9	0.8	96.1	82.5066	62.2727
2014	9	22	10	38	19	0.3	3.9	0.83	96.6	82.5066	64.8459
2014	9	22	10	48	19	0.3	3.9	0.81	96.5	82.5066	62.7873
2014	9	22	10	58	19	0.3	3.9	0.78	95.8	82.5066	60.986
2014	9	22	11	8	19	0.3	3.9	0.82	96.6	82.5066	64.0738
2014	9	22	11	18	19	0.3	3.9	0.8	97	82.4409	62.4779
2014	9	22	11	28	19	0.3	3.9	0.81	96.1	82.4409	62.735
2014	9	22	11	38	19	0.3	3.9	0.81	97	82.4409	63.2492
2014	9	22	11	48	19	0.3	3.9	0.81	97	82.4409	63.2492
2014	9	22	11	58	19	0.3	3.9	0.79	96.7	82.4409	61.4493
2014	9	22	12	8	19	0.3	3.9	0.79	99.6	82.4409	60.678
2014	9	22	12	18	19	0.3	3.9	0.79	93.8	82.4409	61.4493
2014	9	22	12	28	19	0.3	3.9	0.78	96.6	82.4409	60.4208
2014	9	22	12	38	19	0.3	3.9	0.77	98.6	82.4409	59.3924
2014	9	22	12	48	19	0.3	3.9	0.75	97.3	82.4409	58.1068
2014	9	22	12	58	19	0.3	3.9	0.76	97.4	82.4409	59.3923
2014	9	22	13	8	19	0.3	3.9	0.82	95.3	82.4409	63.7632
2014	9	22	13	18	19	0.3	3.9	0.79	94.5	82.4409	61.4491
2014	9	22	13	28	19	0.3	3.9	0.8	98	82.4409	62.2205
2014	9	22	13	38	19	0.3	3.9	0.79	96.9	82.4409	61.4491
2014	9	22	13	48	19	0.3	3.9	0.78	97.2	82.4409	60.6778
2014	9	22	13	58	19	0.3	3.9	0.8	97.6	82.4409	61.9633
2014	9	22	14	8	19	0.3	3.9	0.78	97.8	82.4409	60.4206
2014	9	22	14	18	19	0.3	3.6	0.78	96.3	82.3753	60.8841
2014	9	22	14	28	19	0.3	3.6	0.79	95.7	82.3753	61.6548
2014	9	22	14	38	19	0.3	3.6	0.76	97	82.3753	58.829
2014	9	22	14	48	19	0.3	3.6	0.77	96.6	82.3753	59.8565
2014	9	22	14	58	19	0.3	3.6	0.78	94.3	82.3753	61.141
2014	9	22	15	8	19	0.3	3.6	0.79	96.9	82.3753	61.3979
2014	9	22	15	18	19	0.3	3.6	0.79	96.7	82.3753	61.3979
2014	9	22	15	28	19	0.3	3.6	0.79	95.5	82.3097	61.3468
2014	9	22	15	38	19	0.3	3.6	0.8	96.9	82.3753	61.9116
2014	9	22	15	48	19	0.3	3.6	0.79	96.7	82.3097	61.3468
2014	9	22	15	58	19	0.3	3.6	0.74	97.1	82.3097	57.4965
2014	9	22	16	8	19	0.3	3.6	0.8	98.3	82.3097	61.6034
2014	9	22	16	18	19	0.3	3.6	0.81	95.3	82.3097	63.4002
2014	9	22	16	28	19	0.3	3.6	0.77	97.1	82.3097	59.55
2014	9	22	16	38	19	0.3	3.6	0.78	97	82.3097	60.32
2014	9	22	16	48	19	0.3	3.6	0.81	98.2	82.3097	62.3735
2014	9	22	16	58	19	0.3	3.6	0.81	96.5	82.3097	62.6301
2014	9	22	17	8	19	0.3	3.6	0.8	96.6	82.3097	61.8601
2014	9	22	17	18	19	0.3	3.6	0.8	95.6	82.3097	62.3735

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	22	17	28	19	0.3	3.6	0.78	97	82.3097	60.8334
2014	9	22	17	38	19	0.3	3.6	0.79	96.5	82.3097	61.0901
2014	9	22	17	48	19	0.3	3.6	0.81	97	82.3097	62.8868
2014	9	22	17	58	19	0.3	3.6	0.82	96.5	82.3097	63.4002
2014	9	22	18	8	19	0.3	3.6	0.81	95.6	82.3097	63.1435
2014	9	22	18	18	19	0.3	3.6	0.79	95.7	82.3097	61.6034
2014	9	22	18	28	19	0.3	3.6	0.85	96	82.3097	66.4804
2014	9	22	18	38	19	0.3	3.6	0.78	96.5	82.3097	60.5767
2014	9	22	18	48	19	0.3	3.6	0.84	96	82.2441	65.6556
2014	9	22	18	58	19	0.3	3.6	0.8	97.3	82.3097	62.1168
2014	9	22	19	8	19	0.3	3.6	0.82	94.1	82.3097	63.9136
2014	9	22	19	18	19	0.3	3.6	0.81	95.8	82.3097	62.8868
2014	9	22	19	28	19	0.3	3.6	0.78	97	82.2441	60.5263
2014	9	22	19	38	19	0.3	3.6	0.79	94.8	82.3097	61.6034
2014	9	22	19	48	19	0.3	3.6	0.84	95.2	82.3097	65.4536
2014	9	22	19	58	19	0.3	3.6	0.81	95.5	82.3097	63.4002
2014	9	22	20	8	19	0.3	3.6	0.79	96.7	82.3097	61.6034
2014	9	22	20	18	19	0.3	3.6	0.81	95.8	82.3097	62.8868
2014	9	22	20	28	19	0.3	3.6	0.79	97.4	82.3097	61.6034
2014	9	22	20	38	19	0.3	3.6	0.81	96.3	82.3097	62.8869
2014	9	22	20	48	19	0.3	3.6	0.84	96	82.3753	65.5082
2014	9	22	20	58	19	0.3	3.6	0.81	95.6	82.3097	63.1436
2014	9	22	21	8	19	0.3	3.6	0.85	96	82.3097	66.2237
2014	9	22	21	18	19	0.3	3.6	0.84	96.8	82.3753	64.9944
2014	9	22	21	28	19	0.3	3.6	0.83	94.8	82.3753	64.4806
2014	9	22	21	38	19	0.3	3.6	0.78	97	82.3753	60.6272
2014	9	22	21	48	19	0.3	3.6	0.79	95.5	82.3753	61.3979
2014	9	22	21	58	19	0.3	3.6	0.8	96.2	82.3097	61.8602
2014	9	22	22	8	19	0.3	3.6	0.85	97.1	82.3753	65.7652
2014	9	22	22	18	19	0.3	3.6	0.81	96	82.3753	63.1962
2014	9	22	22	28	19	0.3	3.6	0.85	97.3	82.3753	66.279
2014	9	22	22	38	19	0.3	3.6	0.8	94.9	82.3753	62.6824
2014	9	22	22	48	19	0.3	3.6	0.82	96.7	82.3753	63.4531
2014	9	22	22	58	19	0.3	3.6	0.81	97.7	82.3753	62.9394
2014	9	22	23	8	19	0.3	3.6	0.81	95.1	82.3753	62.9394
2014	9	22	23	18	19	0.3	3.6	0.82	97.2	82.3753	63.4532
2014	9	22	23	28	19	0.3	3.6	0.78	95.6	82.3753	60.6274
2014	9	22	23	38	19	0.3	3.6	0.83	97.3	82.3753	64.4808
2014	9	22	23	48	19	0.3	3.6	0.79	96.9	82.3753	61.655
2014	9	22	23	58	19	0.3	3.6	0.85	95.7	82.3753	66.536
2014	9	23	0	8	19	0.3	3.6	0.79	95	82.3753	61.3981
2014	9	23	0	18	19	0.3	3.6	0.82	94.8	82.3753	64.224
2014	9	23	0	28	19	0.3	3.6	0.79	96.9	82.3753	61.655
2014	9	23	0	38	19	0.3	3.6	0.8	98.7	82.3753	61.912
2014	9	23	0	48	19	0.3	3.6	0.8	96.6	82.3753	61.912
2014	9	23	0	58	19	0.3	3.6	0.8	98.1	82.3753	61.6551

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	1	8	19	0.3	3.6	0.82	97.2	82.3753	63.4534
2014	9	23	1	18	19	0.3	3.6	0.84	96.3	82.3753	65.2517
2014	9	23	1	28	19	0.3	3.6	0.84	96.3	82.3753	64.9948
2014	9	23	1	38	19	0.3	3.6	0.82	94.3	82.3753	64.2241
2014	9	23	1	48	19	0.3	3.6	0.83	95.6	82.3753	64.9949
2014	9	23	1	58	19	0.3	3.6	0.82	96.6	82.3753	63.9673
2014	9	23	2	8	19	0.3	3.6	0.82	95	82.3753	63.9673
2014	9	23	2	18	19	0.3	3.6	0.81	96.3	82.3753	63.1966
2014	9	23	2	28	19	0.3	3.6	0.83	94.5	82.3753	64.995
2014	9	23	2	38	19	0.3	3.6	0.83	95.2	82.3753	64.995
2014	9	23	2	48	19	0.3	3.6	0.81	96.5	82.3753	63.1967
2014	9	23	2	58	19	0.3	3.6	0.83	96.4	82.3753	64.2243
2014	9	23	3	8	19	0.3	3.6	0.83	99.3	82.3753	64.2244
2014	9	23	3	18	19	0.3	3.6	0.81	95.8	82.3753	63.1968
2014	9	23	3	28	19	0.3	3.6	0.83	97.2	82.3753	64.7382
2014	9	23	3	38	19	0.3	3.6	0.83	96.8	82.3753	64.7382
2014	9	23	3	48	19	0.3	3.6	0.8	97.5	82.3753	62.4262
2014	9	23	3	58	19	0.3	3.6	0.8	96.3	82.3753	62.4262
2014	9	23	4	8	19	0.3	3.6	0.78	95.8	82.3753	61.1417
2014	9	23	4	18	19	0.3	3.6	0.8	97.8	82.3753	61.9124
2014	9	23	4	28	19	0.3	3.6	0.84	94.9	82.3753	65.7659
2014	9	23	4	38	19	0.3	3.6	0.8	97.1	82.3753	61.9125
2014	9	23	4	48	19	0.3	3.6	0.85	97.1	82.3753	66.0229
2014	9	23	4	58	19	0.3	3.6	0.81	97	82.3753	62.6832
2014	9	23	5	8	19	0.3	3.6	0.83	95.9	82.3753	64.9953
2014	9	23	5	18	19	0.3	3.6	0.81	96.3	82.3753	63.1971
2014	9	23	5	28	19	0.3	3.6	0.84	95.6	82.3753	65.7661
2014	9	23	5	38	19	0.3	3.6	0.85	97.3	82.3753	66.023
2014	9	23	5	48	19	0.3	3.6	0.79	97.4	82.3753	61.6557
2014	9	23	5	58	19	0.3	3.6	0.84	96.7	82.3753	65.2523
2014	9	23	6	8	19	0.3	3.6	0.8	95	82.3753	62.1696
2014	9	23	6	18	19	0.3	3.6	0.8	95.6	82.3753	62.4265
2014	9	23	6	28	19	0.3	3.9	0.86	96.4	82.4409	66.8494
2014	9	23	6	38	19	0.3	3.9	0.84	96.1	82.4409	65.3067
2014	9	23	6	48	19	0.3	3.6	0.84	94.3	82.3753	65.5093
2014	9	23	6	58	19	0.3	3.9	0.87	95.8	82.4409	68.135
2014	9	23	7	8	19	0.3	3.9	0.78	96	82.4409	60.6788
2014	9	23	7	18	19	0.3	3.9	0.83	95	82.4409	64.7926
2014	9	23	7	28	19	0.3	3.9	0.8	95.2	82.4409	62.2215
2014	9	23	7	38	19	0.3	3.9	0.8	94.7	82.4409	62.2215
2014	9	23	7	48	19	0.3	3.9	0.82	96.5	82.4409	63.5071
2014	9	23	7	58	19	0.3	3.9	0.81	97.4	82.4409	63.25
2014	9	23	8	8	19	0.3	3.9	0.84	97.2	82.4409	65.564
2014	9	23	8	18	19	0.3	3.9	0.86	93.9	82.4409	67.3638
2014	9	23	8	28	19	0.3	3.9	0.79	96.2	82.4409	61.1931
2014	9	23	8	38	19	0.3	3.9	0.79	97.8	82.4409	61.7073

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	8	48	19	0.3	3.9	0.8	96.6	82.4409	61.9644
2014	9	23	8	58	19	0.3	3.9	0.81	94.9	82.4409	62.9929
2014	9	23	9	8	19	0.3	3.9	0.8	96.2	82.5066	62.0159
2014	9	23	9	18	19	0.3	3.9	0.84	97.2	82.5066	65.6185
2014	9	23	9	28	19	0.3	3.9	0.81	97.7	82.4409	62.7357
2014	9	23	9	38	19	0.3	3.9	0.87	97.8	82.4409	67.3637
2014	9	23	9	48	19	0.3	3.9	0.83	97.5	82.5066	64.8465
2014	9	23	9	58	19	0.3	3.9	0.82	96.4	82.5066	64.0745
2014	9	23	10	8	19	0.3	3.9	0.83	95	82.4409	64.7926
2014	9	23	10	18	19	0.3	3.9	0.83	97.3	82.5066	64.3318
2014	9	23	10	28	19	0.3	3.9	0.84	96	82.5066	65.8757
2014	9	23	10	38	19	0.3	3.9	0.81	97.9	82.4409	62.9927
2014	9	23	10	48	19	0.3	3.9	0.84	95.6	82.5066	65.361
2014	9	23	10	58	19	0.3	3.9	0.79	99.1	82.4409	60.9357
2014	9	23	11	8	19	0.3	3.9	0.81	97.7	82.4409	62.7355
2014	9	23	11	18	19	0.3	3.9	0.77	96.4	82.4409	59.9072
2014	9	23	11	28	19	0.3	3.9	0.8	95.4	82.5066	62.273
2014	9	23	11	38	19	0.3	3.9	0.8	96.6	82.4409	62.2212
2014	9	23	11	48	19	0.3	3.9	0.81	96.5	82.4409	63.2496
2014	9	23	11	58	19	0.3	3.9	0.77	95.4	82.4409	60.1642
2014	9	23	12	8	19	0.3	3.9	0.81	98.9	82.4409	62.7353
2014	9	23	12	18	19	0.3	3.9	0.78	96.7	82.4409	60.9355
2014	9	23	12	28	19	0.3	3.9	0.77	97.3	82.4409	60.1642
2014	9	23	12	38	19	0.3	3.9	0.78	95.5	82.4409	60.9355
2014	9	23	12	48	19	0.3	3.9	0.78	96.3	82.4409	60.4212
2014	9	23	12	58	19	0.3	3.9	0.82	96.2	82.4409	63.7636
2014	9	23	13	8	19	0.3	3.6	0.84	93.8	82.3753	65.7658
2014	9	23	13	18	19	0.3	3.9	0.81	95.6	82.4409	62.9922
2014	9	23	13	28	19	0.3	3.9	0.8	96.6	82.4409	62.2209
2014	9	23	13	38	19	0.3	3.6	0.76	98.9	82.3753	59.0864
2014	9	23	13	48	19	0.3	3.6	0.79	97.8	82.3753	61.6553
2014	9	23	13	58	19	0.3	3.6	0.8	96.8	82.3753	62.1691
2014	9	23	14	8	19	0.3	3.6	0.81	95.3	82.3753	63.4536
2014	9	23	14	18	19	0.3	3.6	0.83	95.4	82.3753	64.9949
2014	9	23	14	28	19	0.3	3.6	0.82	95.5	82.3753	63.9673
2014	9	23	14	38	19	0.3	3.6	0.77	95.6	82.3097	60.3205
2014	9	23	14	48	19	0.3	3.6	0.79	95.7	82.3753	61.3983
2014	9	23	14	58	19	0.3	3.6	0.82	96.4	82.3753	63.9672
2014	9	23	15	8	19	0.3	3.6	0.79	94.7	82.3097	61.8605
2014	9	23	15	18	19	0.3	3.6	0.79	97.2	82.3097	61.3472
2014	9	23	15	28	19	0.3	3.6	0.81	96.3	82.3097	62.6306
2014	9	23	15	38	19	0.3	3.6	0.82	95.8	82.3097	63.6573
2014	9	23	15	48	19	0.3	3.6	0.79	95.2	82.3097	61.6038
2014	9	23	15	58	19	0.3	3.6	0.79	96.9	82.3097	61.0905
2014	9	23	16	8	19	0.3	3.6	0.79	95	82.3097	61.3471
2014	9	23	16	18	19	0.3	3.6	0.79	96.7	82.3097	61.6038

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	23	16	28	19	0.3	3.6	0.78	98.2	82.2441	60.2702
2014	9	23	16	38	19	0.3	3.6	0.8	98	82.2441	62.0654
2014	9	23	16	48	19	0.3	3.6	0.8	93	82.2441	62.8349
2014	9	23	16	58	19	0.3	3.6	0.8	95.4	82.2441	62.0654
2014	9	23	17	8	19	0.3	3.6	0.8	97	82.2441	62.3219
2014	9	23	17	18	19	0.3	3.6	0.77	96.4	82.2441	59.5007
2014	9	23	17	28	19	0.3	3.6	0.8	96.8	82.2441	62.0654
2014	9	23	17	38	19	0.3	3.6	0.81	97.7	82.2441	62.5784
2014	9	23	17	48	19	0.3	3.6	0.8	95.4	82.2441	62.0654
2014	9	23	17	58	19	0.3	3.6	0.82	98	82.2441	63.6042
2014	9	23	18	8	19	0.3	3.6	0.83	97	82.2441	64.6301
2014	9	23	18	18	19	0.3	3.6	0.86	95.9	82.3097	66.7374
2014	9	23	18	28	19	0.3	3.6	0.81	95.6	82.2441	62.8348
2014	9	23	18	38	19	0.3	3.6	0.84	98.1	82.2441	65.1431
2014	9	23	18	48	19	0.3	3.6	0.8	95.9	82.2441	62.5784
2014	9	23	18	58	19	0.3	3.6	0.8	97.5	82.2441	62.3219
2014	9	23	19	8	19	0.3	3.6	0.83	97.1	82.2441	64.1172
2014	9	23	19	18	19	0.3	3.6	0.8	98.9	82.2441	62.0654
2014	9	23	19	28	19	0.3	3.6	0.83	96.4	82.3097	64.4273
2014	9	23	19	38	19	0.3	3.6	0.84	95	82.2441	65.1431
2014	9	23	19	48	19	0.3	3.6	0.8	95.9	82.3097	62.6305
2014	9	23	19	58	19	0.3	3.6	0.82	93	82.3097	64.1706
2014	9	23	20	8	19	0.3	3.6	0.82	97.1	82.3097	63.9139
2014	9	23	20	18	19	0.3	3.6	0.82	95.3	82.3097	63.6573
2014	9	23	20	28	19	0.3	3.6	0.82	95	82.3097	63.914
2014	9	23	20	38	19	0.3	3.6	0.8	95.2	82.3097	62.3739
2014	9	23	20	48	19	0.3	3.6	0.8	94.7	82.3097	62.3739
2014	9	23	20	58	19	0.3	3.6	0.82	96.2	82.3097	63.6573
2014	9	23	21	8	19	0.3	3.6	0.77	95.9	82.3097	59.5504
2014	9	23	21	18	19	0.3	3.6	0.84	93.8	82.3097	65.1974
2014	9	23	21	28	19	0.3	3.6	0.82	93.9	82.3097	63.6573
2014	9	23	21	38	19	0.3	3.6	0.81	96.5	82.3097	62.6306
2014	9	23	21	48	19	0.3	3.6	0.83	95	82.3097	64.9408
2014	9	23	21	58	19	0.3	3.6	0.82	93.9	82.3097	63.6574
2014	9	23	22	8	19	0.3	3.6	0.8	95.2	82.3097	62.6307
2014	9	23	22	18	19	0.3	3.6	0.83	96.8	82.3097	64.4275
2014	9	23	22	28	19	0.3	3.6	0.85	97.1	82.3097	66.2243
2014	9	23	22	38	19	0.3	3.6	0.81	95.4	82.3097	62.8874
2014	9	23	22	48	19	0.3	3.6	0.81	96.5	82.3097	63.1441
2014	9	23	22	58	19	0.3	3.6	0.79	95.9	82.3097	61.8607
2014	9	23	23	8	19	0.3	3.6	0.83	95.2	82.3097	64.4276
2014	9	23	23	18	19	0.3	3.6	0.8	95.9	82.3097	62.3741
2014	9	23	23	28	19	0.3	3.6	0.83	96.3	82.3097	64.6843
2014	9	23	23	38	19	0.3	3.6	0.8	93.3	82.3097	62.3742
2014	9	23	23	48	19	0.3	3.6	0.79	95.5	82.3097	61.3475
2014	9	23	23	58	19	0.3	3.6	0.82	97.1	82.3097	63.6576

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	0	8	19	0.3	3.6	0.81	96.5	82.3097	63.1443
2014	9	24	0	18	19	0.3	3.6	0.8	96.6	82.3097	61.8609
2014	9	24	0	28	19	0.3	3.6	0.85	95.1	82.3097	65.9679
2014	9	24	0	38	19	0.3	3.6	0.79	97.8	82.3097	61.6043
2014	9	24	0	48	19	0.3	3.6	0.8	98.5	82.3097	62.1176
2014	9	24	0	58	19	0.3	3.6	0.83	96.4	82.3097	64.1711
2014	9	24	1	8	19	0.3	3.6	0.81	97.6	82.3097	63.1444
2014	9	24	1	18	19	0.3	3.6	0.8	94.3	82.3097	62.1177
2014	9	24	1	28	19	0.3	3.6	0.85	96.5	82.3097	65.7113
2014	9	24	1	38	19	0.3	3.6	0.88	95.6	82.3097	68.2782
2014	9	24	1	48	19	0.3	3.6	0.79	97.2	82.3097	61.3477
2014	9	24	1	58	19	0.3	3.6	0.83	98.4	82.3097	64.428
2014	9	24	2	8	19	0.3	3.6	0.79	95.7	82.3097	61.6045
2014	9	24	2	18	19	0.3	3.6	0.82	94.3	82.3097	64.1713
2014	9	24	2	28	19	0.3	3.6	0.83	94.8	82.3097	64.428
2014	9	24	2	38	19	0.3	3.6	0.81	97.5	82.3097	62.6313
2014	9	24	2	48	19	0.3	3.6	0.81	95.6	82.3097	62.888
2014	9	24	2	58	19	0.3	3.6	0.8	97.6	82.3097	61.8613
2014	9	24	3	8	19	0.3	3.6	0.86	98.1	82.3097	66.7383
2014	9	24	3	18	19	0.3	3.6	0.8	94	82.3097	62.118
2014	9	24	3	28	19	0.3	3.6	0.83	95.9	82.3097	64.4282
2014	9	24	3	38	19	0.3	3.6	0.81	97.2	82.3097	62.8881
2014	9	24	3	48	19	0.3	3.6	0.81	94.4	82.3097	62.8881
2014	9	24	3	58	19	0.3	3.6	0.83	95.7	82.3097	64.685
2014	9	24	4	8	19	0.3	3.6	0.83	96.3	82.3097	64.685
2014	9	24	4	18	19	0.3	3.6	0.8	94.7	82.3097	62.6315
2014	9	24	4	28	19	0.3	3.6	0.84	96.5	82.3097	64.9418
2014	9	24	4	38	19	0.3	3.6	0.84	95.8	82.3097	65.7118
2014	9	24	4	48	19	0.3	3.6	0.83	95.9	82.3097	64.4284
2014	9	24	4	58	19	0.3	3.6	0.8	98.3	82.3097	61.6049
2014	9	24	5	8	19	0.3	3.6	0.83	96.4	82.3097	64.1718
2014	9	24	5	18	19	0.3	3.6	0.79	97.1	82.3097	61.6049
2014	9	24	5	28	19	0.3	3.6	0.75	94.8	82.3753	58.5735
2014	9	24	5	38	19	0.3	3.6	0.83	95.5	82.3097	64.4286
2014	9	24	5	48	19	0.3	3.6	0.81	97.9	82.3097	63.1451
2014	9	24	5	58	19	0.3	3.6	0.82	97.1	82.3097	63.9152
2014	9	24	6	8	19	0.3	3.6	0.8	97.5	82.3097	62.1185
2014	9	24	6	18	19	0.3	3.6	0.84	97.2	82.3753	65.5099
2014	9	24	6	28	19	0.3	3.6	0.82	97.1	82.3097	63.6586
2014	9	24	6	38	19	0.3	3.6	0.77	94.9	82.3097	60.3217
2014	9	24	6	48	19	0.3	3.6	0.82	97.1	82.3753	63.7117
2014	9	24	6	58	19	0.3	3.6	0.84	95.4	82.3753	65.2531
2014	9	24	7	8	19	0.3	3.6	0.82	96.2	82.3753	63.7117
2014	9	24	7	18	19	0.3	3.6	0.78	98.3	82.3753	60.1151
2014	9	24	7	28	19	0.3	3.6	0.78	96.6	82.3097	60.3218
2014	9	24	7	38	19	0.3	3.6	0.83	96.1	82.3753	64.9963

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	7	48	19	0.3	3.6	0.81	95.3	82.3753	63.198
2014	9	24	7	58	19	0.3	3.9	0.8	96.3	82.4409	62.4792
2014	9	24	8	8	19	0.3	3.9	0.81	95.3	82.4409	63.5077
2014	9	24	8	18	19	0.3	3.9	0.8	95.4	82.4409	62.4793
2014	9	24	8	28	19	0.3	3.9	0.81	96	82.4409	63.2506
2014	9	24	8	38	19	0.3	3.9	0.84	96	82.4409	65.5647
2014	9	24	8	48	19	0.3	3.9	0.81	96.3	82.4409	62.9934
2014	9	24	8	58	19	0.3	3.9	0.83	95.6	82.4409	65.0504
2014	9	24	9	8	19	0.3	3.9	0.79	96.4	82.4409	61.4507
2014	9	24	9	18	19	0.3	3.9	0.85	96.7	82.4409	66.0788
2014	9	24	9	28	19	0.3	3.9	0.86	95.9	82.4409	66.8501
2014	9	24	9	38	19	0.3	3.9	0.78	95.6	82.4409	60.6793
2014	9	24	9	48	19	0.3	3.9	0.8	95.6	82.4409	62.4791
2014	9	24	9	58	19	0.3	3.6	0.85	97.8	82.3753	66.0238
2014	9	24	10	8	19	0.3	3.6	0.81	98.6	82.3753	62.684
2014	9	24	10	18	19	0.3	3.6	0.83	96.8	82.3753	64.2254
2014	9	24	10	28	19	0.3	3.6	0.82	97.4	82.3753	63.7116
2014	9	24	10	38	19	0.3	3.6	0.82	98.3	82.3753	63.7115
2014	9	24	10	48	19	0.3	3.6	0.81	98.4	82.3753	62.6839
2014	9	24	10	58	19	0.3	3.6	0.81	97.5	82.3753	62.6839
2014	9	24	11	8	19	0.3	3.6	0.85	96.2	82.3753	66.0236
2014	9	24	11	18	19	0.3	3.6	0.79	98.6	82.3753	61.1424
2014	9	24	11	28	19	0.3	3.6	0.78	95.6	82.3097	60.5781
2014	9	24	11	38	19	0.3	3.6	0.8	99.2	82.3097	61.6049
2014	9	24	11	48	19	0.3	3.6	0.82	97.8	82.3753	63.7113
2014	9	24	11	58	19	0.3	3.6	0.83	96.3	82.3753	64.7389
2014	9	24	12	8	19	0.3	3.6	0.82	95	82.3097	63.915
2014	9	24	12	18	19	0.3	3.6	0.81	98.4	82.3097	62.3748
2014	9	24	12	28	19	0.3	3.6	0.8	96.8	82.3097	62.3748
2014	9	24	12	38	19	0.3	3.6	0.81	97.6	82.3097	63.1448
2014	9	24	12	48	19	0.3	3.6	0.85	96.9	82.3097	66.225
2014	9	24	12	58	19	0.3	3.6	0.83	97.5	82.3097	64.1715
2014	9	24	13	8	19	0.3	3.6	0.78	97.2	82.2441	60.5274
2014	9	24	13	18	19	0.3	3.6	0.8	97.8	82.3097	61.8612
2014	9	24	13	28	19	0.3	3.6	0.81	97.2	82.3097	62.8879
2014	9	24	13	38	19	0.3	3.6	0.81	95.3	82.3097	63.1445
2014	9	24	13	48	19	0.3	3.6	0.78	94.6	82.3097	60.8344
2014	9	24	13	58	19	0.3	3.6	0.81	96.8	82.3097	62.8878
2014	9	24	14	8	19	0.3	3.6	0.8	95.6	82.2441	62.3225
2014	9	24	14	18	19	0.3	3.6	0.76	96.7	82.2441	59.2448
2014	9	24	14	28	19	0.3	3.6	0.81	94	82.2441	63.0919
2014	9	24	14	38	19	0.3	3.6	0.82	97.6	82.2441	63.3484
2014	9	24	14	48	19	0.3	3.6	0.8	97.8	82.2441	62.066
2014	9	24	14	58	19	0.3	3.6	0.79	96.7	82.2441	61.0401
2014	9	24	15	8	19	0.3	3.6	0.77	100.1	82.2441	58.9883
2014	9	24	15	18	19	0.3	3.6	0.8	95.9	82.2441	62.5789

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	15	28	19	0.3	3.6	0.8	97.8	82.1785	62.0142
2014	9	24	15	38	19	0.3	3.6	0.79	98.1	82.2441	61.0401
2014	9	24	15	48	19	0.3	3.6	0.83	97.3	82.1785	64.3206
2014	9	24	15	58	19	0.3	3.6	0.8	96.1	82.1785	62.2705
2014	9	24	16	8	19	0.3	3.6	0.79	98.4	82.1785	60.7329
2014	9	24	16	18	19	0.3	3.6	0.84	95	82.1785	65.0893
2014	9	24	16	28	19	0.3	3.6	0.82	95	82.1785	63.808
2014	9	24	16	38	19	0.3	3.6	0.78	97.2	82.1129	60.4262
2014	9	24	16	48	19	0.3	3.6	0.82	93.9	82.1129	63.4988
2014	9	24	16	58	19	0.3	3.6	0.79	96.9	82.1129	61.4504
2014	9	24	17	8	19	0.3	3.6	0.75	97	82.1785	58.1704
2014	9	24	17	18	19	0.3	3.6	0.81	95.1	82.1129	62.9867
2014	9	24	17	28	19	0.3	3.6	0.79	96.7	82.1129	61.1944
2014	9	24	17	38	19	0.3	3.6	0.8	95.7	82.1129	61.9625
2014	9	24	17	48	19	0.3	3.6	0.78	96.7	82.1129	60.6823
2014	9	24	17	58	19	0.3	3.6	0.8	95.9	82.0472	61.9108
2014	9	24	18	8	19	0.3	3.6	0.82	96.9	82.1129	63.4988
2014	9	24	18	18	19	0.3	3.6	0.79	97.8	82.1129	61.4504
2014	9	24	18	28	19	0.3	3.6	0.78	99	82.1129	59.9141
2014	9	24	18	38	19	0.3	3.6	0.81	96.5	82.1129	62.7306
2014	9	24	18	48	19	0.3	3.6	0.76	95.2	82.0472	58.8408
2014	9	24	18	58	19	0.3	3.6	0.76	96.4	82.1129	58.89
2014	9	24	19	8	19	0.3	3.6	0.8	94.9	82.1129	62.2185
2014	9	24	19	18	19	0.3	3.6	0.81	95.3	82.1129	62.9867
2014	9	24	19	28	19	0.3	3.6	0.83	97.3	82.1129	64.0108
2014	9	24	19	38	19	0.3	3.6	0.86	97.6	82.1129	66.8273
2014	9	24	19	48	19	0.3	3.6	0.8	93.8	82.1785	62.0142
2014	9	24	19	58	19	0.3	3.6	0.84	97.2	82.1785	64.8331
2014	9	24	20	8	19	0.3	3.6	0.85	97.3	82.1129	65.5471
2014	9	24	20	18	19	0.3	3.6	0.81	96.5	82.1785	62.783
2014	9	24	20	28	19	0.3	3.6	0.84	97.2	82.1785	64.8331
2014	9	24	20	38	19	0.3	3.6	0.84	95.2	82.1785	65.0893
2014	9	24	20	48	19	0.3	3.6	0.84	98.3	82.1785	64.8331
2014	9	24	20	58	19	0.3	3.6	0.85	96.4	82.1785	66.1144
2014	9	24	21	8	19	0.3	3.6	0.82	95.1	82.1785	63.5518
2014	9	24	21	18	19	0.3	3.6	0.77	96.1	82.1785	59.7079
2014	9	24	21	28	19	0.3	3.6	0.82	96.2	82.1785	63.808
2014	9	24	21	38	19	0.3	3.6	0.82	96.5	82.1785	63.2955
2014	9	24	21	48	19	0.3	3.6	0.84	98.6	82.1785	64.5768
2014	9	24	21	58	19	0.3	3.6	0.81	94.4	82.1785	63.2956
2014	9	24	22	8	19	0.3	3.6	0.82	95.7	82.1785	63.8081
2014	9	24	22	18	19	0.3	3.6	0.87	96.3	82.1785	67.3957
2014	9	24	22	28	19	0.3	3.6	0.8	98.1	82.1785	61.5018
2014	9	24	22	38	19	0.3	3.6	0.81	94.2	82.1785	63.0393
2014	9	24	22	48	19	0.3	3.6	0.86	95.9	82.1785	67.1395
2014	9	24	22	58	19	0.3	3.6	0.88	94.7	82.2441	68.2214

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	24	23	8	19	0.3	3.6	0.8	96.8	82.2441	62.3225
2014	9	24	23	18	19	0.3	3.6	0.82	95	82.1785	63.8081
2014	9	24	23	28	19	0.3	3.6	0.82	95.3	82.1785	64.0644
2014	9	24	23	38	19	0.3	3.6	0.75	95	82.1785	58.4268
2014	9	24	23	48	19	0.3	3.6	0.81	96	82.1785	63.2957
2014	9	24	23	58	19	0.3	3.6	0.8	96.6	82.1785	62.2706
2014	9	25	0	8	19	0.3	3.6	0.76	94.7	82.1785	59.1955
2014	9	25	0	18	19	0.3	3.6	0.81	97.2	82.1785	62.7832
2014	9	25	0	28	19	0.3	3.6	0.83	96.6	82.1785	64.0645
2014	9	25	0	38	19	0.3	3.6	0.86	95.3	82.1785	66.8833
2014	9	25	0	48	19	0.3	3.6	0.82	95.3	82.1785	63.552
2014	9	25	0	58	19	0.3	3.6	0.83	97.3	82.1785	64.0645
2014	9	25	1	8	19	0.3	3.6	0.85	95.6	82.2441	65.9132
2014	9	25	1	18	19	0.3	3.6	0.81	95.5	82.2441	63.3485
2014	9	25	1	28	19	0.3	3.6	0.81	98	82.2441	62.3227
2014	9	25	1	38	19	0.3	3.6	0.83	96.8	82.2441	64.3745
2014	9	25	1	48	19	0.3	3.6	0.79	97.6	82.1785	61.2457
2014	9	25	1	58	19	0.3	3.6	0.8	98.3	82.2441	61.8097
2014	9	25	2	8	19	0.3	3.6	0.82	94.8	82.2441	63.6051
2014	9	25	2	18	19	0.3	3.6	0.78	97.2	82.2441	60.7839
2014	9	25	2	28	19	0.3	3.6	0.8	97.3	82.2441	61.8098
2014	9	25	2	38	19	0.3	3.6	0.81	94.6	82.2441	63.3486
2014	9	25	2	48	19	0.3	3.6	0.78	95.5	82.2441	60.7839
2014	9	25	2	58	19	0.3	3.6	0.82	96.4	82.2441	63.6051
2014	9	25	3	8	19	0.3	3.6	0.85	97.8	82.2441	65.9134
2014	9	25	3	18	19	0.3	3.6	0.81	96.5	82.2441	63.0922
2014	9	25	3	28	19	0.3	3.6	0.81	96.1	82.2441	62.8357
2014	9	25	3	38	19	0.3	3.6	0.81	96.1	82.2441	62.8357
2014	9	25	3	48	19	0.3	3.6	0.81	97.4	82.3097	63.1448
2014	9	25	3	58	19	0.3	3.6	0.79	96.4	82.2441	61.2969
2014	9	25	4	8	19	0.3	3.6	0.77	96.8	82.2441	60.0145
2014	9	25	4	18	19	0.3	3.6	0.78	97.5	82.3097	60.5779
2014	9	25	4	28	19	0.3	3.6	0.78	95.6	82.3097	60.578
2014	9	25	4	38	19	0.3	3.6	0.77	95.6	82.3097	60.0646
2014	9	25	4	48	19	0.3	3.6	0.75	96	82.2441	58.4758
2014	9	25	4	58	19	0.3	3.6	0.81	97	82.3097	62.6315
2014	9	25	5	8	19	0.3	3.6	0.79	96.2	82.2441	61.5534
2014	9	25	5	18	19	0.3	3.6	0.8	95.4	82.3097	62.1181
2014	9	25	5	28	19	0.3	3.6	0.79	94.3	82.3097	61.8614
2014	9	25	5	38	19	0.3	3.6	0.78	97.2	82.3097	60.8347
2014	9	25	5	48	19	0.3	3.6	0.79	96.7	82.3097	61.3481
2014	9	25	5	58	19	0.3	3.6	0.81	94.2	82.3097	63.1449
2014	9	25	6	8	19	0.3	3.6	0.78	95.1	82.3097	60.578
2014	9	25	6	18	19	0.3	3.6	0.77	95.6	82.3097	59.808
2014	9	25	6	28	19	0.3	3.6	0.79	97.4	82.3097	61.0914
2014	9	25	6	38	19	0.3	3.6	0.8	95.4	82.3097	62.1182

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	6	48	19	0.3	3.6	0.81	95.8	82.3097	63.1449
2014	9	25	6	58	19	0.3	3.6	0.86	94	82.3097	66.7385
2014	9	25	7	8	19	0.3	3.6	0.8	97.8	82.3097	61.8615
2014	9	25	7	18	19	0.3	3.6	0.78	96	82.3097	60.5781
2014	9	25	7	28	19	0.3	3.6	0.81	97.4	82.2441	63.0923
2014	9	25	7	38	19	0.3	3.6	0.81	95.3	82.3097	63.4016
2014	9	25	7	48	19	0.3	3.6	0.78	96.5	82.3097	60.8348
2014	9	25	7	58	19	0.3	3.6	0.77	96.9	82.3097	59.808
2014	9	25	8	8	19	0.3	3.6	0.8	98.3	82.3097	61.6048
2014	9	25	8	18	19	0.3	3.6	0.81	96.3	82.3097	62.6315
2014	9	25	8	28	19	0.3	3.6	0.82	98.1	82.3097	63.1449
2014	9	25	8	38	19	0.3	3.6	0.81	96.5	82.3097	62.8882
2014	9	25	8	48	19	0.3	3.6	0.76	96.9	82.3097	59.2946
2014	9	25	8	58	19	0.3	3.6	0.8	96.6	82.3753	61.9129
2014	9	25	9	8	19	0.3	3.6	0.75	95.3	82.3097	58.5245
2014	9	25	9	18	19	0.3	3.6	0.75	95.5	82.3097	58.2678
2014	9	25	9	28	19	0.3	3.6	0.79	95.3	82.3097	61.348
2014	9	25	9	38	19	0.3	3.6	0.79	97.6	82.3753	61.3991
2014	9	25	9	48	19	0.3	3.6	0.77	93.9	82.3097	59.8078
2014	9	25	9	58	19	0.3	3.6	0.78	96	82.3097	60.5779
2014	9	25	10	8	19	0.3	3.6	0.77	96.1	82.3753	60.1145
2014	9	25	10	18	19	0.3	3.6	0.8	97.5	82.3753	62.1697
2014	9	25	10	28	19	0.3	3.6	0.75	97.3	82.3097	58.2676
2014	9	25	10	38	19	0.3	3.6	0.77	97.4	82.3097	59.5511
2014	9	25	10	48	19	0.3	3.6	0.78	98	82.3097	60.5778
2014	9	25	10	58	19	0.3	3.6	0.79	96.4	82.3097	61.3478
2014	9	25	11	8	19	0.3	3.6	0.75	95.5	82.3097	58.7809
2014	9	25	11	18	19	0.3	3.6	0.78	97.2	82.3097	60.8344
2014	9	25	11	28	19	0.3	3.6	0.75	95.3	82.3097	58.5242
2014	9	25	11	38	19	0.3	3.6	0.77	95.4	82.3097	60.0643
2014	9	25	11	48	19	0.3	3.6	0.71	94.2	82.3097	55.7006
2014	9	25	11	58	19	0.3	3.6	0.72	95.2	82.2441	56.1671
2014	9	25	12	8	19	0.3	3.6	0.75	94.7	82.2441	58.7318
2014	9	25	12	18	19	0.3	3.6	0.78	94.8	82.2441	61.04
2014	9	25	12	28	19	0.3	3.6	0.78	95.6	82.2441	60.527
2014	9	25	12	38	19	0.3	3.6	0.77	95.6	82.2441	60.2705
2014	9	25	12	48	19	0.3	3.6	0.8	97.8	82.3097	61.8608
2014	9	25	12	58	19	0.3	3.6	0.77	95.4	82.3097	60.064
2014	9	25	13	8	19	0.3	3.6	0.79	96	82.1785	60.989
2014	9	25	13	18	19	0.3	3.6	0.76	97.2	82.1785	58.9389
2014	9	25	13	28	19	0.3	3.6	0.77	94.2	82.2441	59.7574
2014	9	25	13	38	19	0.3	3.6	0.77	95.3	82.1785	60.2201
2014	9	25	13	48	19	0.3	3.6	0.77	97.8	82.2441	59.7574
2014	9	25	13	58	19	0.3	3.6	0.76	95.2	82.2441	59.5009
2014	9	25	14	8	19	0.3	3.6	0.76	95.7	82.1785	58.6826
2014	9	25	14	18	19	0.3	3.6	0.79	96.5	82.1129	60.938

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	14	28	19	0.3	3.6	0.82	96.2	82.1129	63.7545
2014	9	25	14	38	19	0.3	3.6	0.79	95.2	82.1129	61.7061
2014	9	25	14	48	19	0.3	3.6	0.78	94.6	82.1129	60.6819
2014	9	25	14	58	19	0.3	3.6	0.8	96.4	82.1129	61.7061
2014	9	25	15	8	19	0.3	3.6	0.78	95.3	82.0472	60.3754
2014	9	25	15	18	19	0.3	3.6	0.82	97.1	82.0472	63.7011
2014	9	25	15	28	19	0.3	3.6	0.74	96.1	82.1129	57.6094
2014	9	25	15	38	19	0.3	3.6	0.78	95.3	82.0472	60.8871
2014	9	25	15	48	19	0.3	3.6	0.77	94.9	82.0472	59.6079
2014	9	25	15	58	19	0.3	3.6	0.79	96.4	82.0472	61.1429
2014	9	25	16	8	19	0.3	3.6	0.83	95.2	82.0472	64.4686
2014	9	25	16	18	19	0.3	3.6	0.78	96.7	81.9816	60.5806
2014	9	25	16	28	19	0.3	3.6	0.82	96.4	82.0472	63.7011
2014	9	25	16	38	19	0.3	3.6	0.74	98.4	82.0472	57.0496
2014	9	25	16	48	19	0.3	3.6	0.78	96.3	81.9816	60.5805
2014	9	25	16	58	19	0.3	3.6	0.79	96.9	81.9816	61.3474
2014	9	25	17	8	19	0.3	3.6	0.79	95.2	81.9816	61.603
2014	9	25	17	18	19	0.3	3.6	0.77	95.9	81.916	59.5083
2014	9	25	17	28	19	0.3	3.6	0.81	94.9	81.9816	62.6255
2014	9	25	17	38	19	0.3	3.6	0.76	95.7	81.9816	58.7913
2014	9	25	17	48	19	0.3	3.6	0.79	95	81.916	61.2961
2014	9	25	17	58	19	0.3	3.6	0.81	95.6	81.9816	62.6255
2014	9	25	18	8	19	0.3	3.6	0.76	95	81.916	58.7421
2014	9	25	18	18	19	0.3	3.6	0.8	95.9	81.916	62.3177
2014	9	25	18	28	19	0.3	3.6	0.76	92.7	81.9816	58.7913
2014	9	25	18	38	19	0.3	3.6	0.76	96.7	81.916	58.9975
2014	9	25	18	48	19	0.3	3.6	0.78	94.8	81.916	60.7853
2014	9	25	18	58	19	0.3	3.6	0.76	95.2	81.9816	58.7913
2014	9	25	19	8	19	0.3	3.6	0.72	96.8	81.9816	55.9795
2014	9	25	19	18	19	0.3	3.6	0.79	97.9	81.916	61.0407
2014	9	25	19	28	19	0.3	3.6	0.82	94.4	81.8504	63.5415
2014	9	25	19	38	19	0.3	3.6	0.76	97.2	81.916	58.4867
2014	9	25	19	48	19	0.3	3.6	0.78	95.3	81.916	60.7854
2014	9	25	19	58	19	0.3	3.6	0.79	94.3	81.916	61.0408
2014	9	25	20	8	19	0.3	3.6	0.8	94.2	81.916	62.3178
2014	9	25	20	18	19	0.3	3.6	0.76	96	81.916	58.7422
2014	9	25	20	28	19	0.3	3.6	0.8	97.8	81.916	61.5516
2014	9	25	20	38	19	0.3	3.6	0.8	96.1	81.916	61.807
2014	9	25	20	48	19	0.3	3.6	0.77	94.6	81.916	59.7638
2014	9	25	20	58	19	0.3	3.6	0.74	96.3	81.916	57.4652
2014	9	25	21	8	19	0.3	3.6	0.79	96.7	81.916	61.2962
2014	9	25	21	18	19	0.3	3.6	0.75	96.8	81.916	57.7206
2014	9	25	21	28	19	0.3	3.6	0.76	98.2	81.916	58.4868
2014	9	25	21	38	19	0.3	3.6	0.78	94.8	81.916	60.7854
2014	9	25	21	48	19	0.3	3.6	0.77	95.9	81.916	59.5084
2014	9	25	21	58	19	0.3	3.6	0.79	95.5	81.916	61.0408

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	25	22	8	19	0.3	3.6	0.8	95.4	81.916	62.0625
2014	9	25	22	18	19	0.3	3.6	0.76	95.7	81.8504	58.6931
2014	9	25	22	28	19	0.3	3.6	0.81	96.5	81.916	62.8287
2014	9	25	22	38	19	0.3	3.6	0.75	98.3	81.8504	57.9275
2014	9	25	22	48	19	0.3	3.6	0.84	95.6	81.8504	64.8176
2014	9	25	22	58	19	0.3	3.6	0.79	96.7	81.7848	60.9387
2014	9	25	23	8	19	0.3	3.6	0.79	96.2	81.8504	61.245
2014	9	25	23	18	19	0.3	3.6	0.81	96.5	81.8504	62.7761
2014	9	25	23	28	19	0.3	3.6	0.81	96.3	81.8504	62.7761
2014	9	25	23	38	19	0.3	3.6	0.81	95.3	81.7848	62.9785
2014	9	25	23	48	19	0.3	3.6	0.83	97.1	81.8504	63.7969
2014	9	25	23	58	19	0.3	3.6	0.79	95.5	81.8504	60.9898
2014	9	26	0	8	19	0.3	3.6	0.79	96.4	81.8504	60.9899
2014	9	26	0	18	19	0.3	3.6	0.78	99.5	81.8504	59.4587
2014	9	26	0	28	19	0.3	3.6	0.78	97	81.8504	59.9691
2014	9	26	0	38	19	0.3	3.6	0.77	95.9	81.8504	59.4588
2014	9	26	0	48	19	0.3	3.6	0.76	96.7	81.8504	58.438
2014	9	26	0	58	19	0.3	3.6	0.79	96.2	81.916	60.7856
2014	9	26	1	8	19	0.3	3.6	0.74	96.1	81.8504	57.1621
2014	9	26	1	18	19	0.3	3.6	0.78	96.3	81.8504	60.4796
2014	9	26	1	28	19	0.3	3.6	0.73	95.2	81.8504	56.3966
2014	9	26	1	38	19	0.3	3.6	0.8	97	81.916	62.0627
2014	9	26	1	48	19	0.3	3.6	0.79	96.7	81.916	61.2965
2014	9	26	1	58	19	0.3	3.6	0.79	96.7	81.8504	61.2452
2014	9	26	2	8	19	0.3	3.6	0.79	96.7	81.916	60.7857
2014	9	26	2	18	19	0.3	3.6	0.76	96.2	81.916	58.4871
2014	9	26	2	28	19	0.3	3.6	0.79	97.4	81.916	60.7857
2014	9	26	2	38	19	0.3	3.6	0.77	96.6	81.916	59.7641
2014	9	26	2	48	19	0.3	3.6	0.81	95.5	81.916	63.0844
2014	9	26	2	58	19	0.3	3.6	0.78	95.3	81.916	60.7857
2014	9	26	3	8	19	0.3	3.6	0.79	95.7	81.916	61.2966
2014	9	26	3	18	19	0.3	3.6	0.83	96.3	81.916	64.3614
2014	9	26	3	28	19	0.3	3.6	0.81	96.5	81.916	62.3182
2014	9	26	3	38	19	0.3	3.6	0.78	96.8	81.916	60.0196
2014	9	26	3	48	19	0.3	3.6	0.81	97	81.9816	62.3704
2014	9	26	3	58	19	0.3	3.6	0.77	96.4	81.8504	59.2038
2014	9	26	4	8	19	0.3	3.6	0.82	95.3	81.916	63.3399
2014	9	26	4	18	19	0.3	3.6	0.79	95.5	81.8504	61.2453
2014	9	26	4	28	19	0.3	3.6	0.79	96	81.916	60.7859
2014	9	26	4	38	19	0.3	3.6	0.78	97	81.916	60.5305
2014	9	26	4	48	19	0.3	3.6	0.77	96.9	81.916	59.5089
2014	9	26	4	58	19	0.3	3.6	0.79	97.9	81.9816	60.5811
2014	9	26	5	8	19	0.3	3.6	0.78	95.5	81.916	60.7859
2014	9	26	5	18	19	0.3	3.6	0.78	96.8	81.9816	60.0699
2014	9	26	5	28	19	0.3	3.6	0.78	95.5	81.9816	60.5812
2014	9	26	5	38	19	0.3	3.6	0.8	94.7	81.916	62.3184

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	5	48	19	0.3	3.6	0.8	97.8	81.9816	61.8593
2014	9	26	5	58	19	0.3	3.6	0.81	97	81.9816	62.3705
2014	9	26	6	8	19	0.3	3.6	0.77	96.4	81.9816	59.3031
2014	9	26	6	18	19	0.3	3.6	0.75	95.5	81.9816	58.0251
2014	9	26	6	28	19	0.3	3.6	0.79	97.9	81.9816	61.0925
2014	9	26	6	38	19	0.3	3.6	0.79	94.3	81.9816	61.0925
2014	9	26	6	48	19	0.3	3.6	0.8	94.2	81.9816	62.115
2014	9	26	6	58	19	0.3	3.6	0.82	95.3	81.9816	63.6487
2014	9	26	7	8	19	0.3	3.6	0.79	97.2	82.0472	61.1436
2014	9	26	7	18	19	0.3	3.6	0.79	96.9	82.0472	61.3994
2014	9	26	7	28	19	0.3	3.6	0.8	96.6	82.0472	61.9111
2014	9	26	7	38	19	0.3	3.6	0.8	94	82.0472	61.9111
2014	9	26	7	48	19	0.3	3.6	0.8	94.9	82.0472	62.1669
2014	9	26	7	58	19	0.3	3.6	0.79	96.7	82.0472	61.3994
2014	9	26	8	8	19	0.3	3.6	0.79	94	82.0472	61.6553
2014	9	26	8	18	19	0.3	3.6	0.79	96.4	82.0472	61.1436
2014	9	26	8	28	19	0.3	3.6	0.79	95.2	82.0472	61.6553
2014	9	26	8	38	19	0.3	3.6	0.8	96.6	82.0472	62.1669
2014	9	26	8	48	19	0.3	3.6	0.76	94.5	82.1129	58.8903
2014	9	26	8	58	19	0.3	3.6	0.78	96.8	81.9816	60.3256
2014	9	26	9	8	19	0.3	3.6	0.77	96.9	82.0472	59.3527
2014	9	26	9	18	19	0.3	3.6	0.79	96.7	82.0472	61.1435
2014	9	26	9	28	19	0.3	3.6	0.8	98	82.1129	61.7067
2014	9	26	9	38	19	0.3	3.6	0.78	94.3	82.1129	60.6825
2014	9	26	9	48	19	0.3	3.6	0.76	93.5	82.1129	58.8902
2014	9	26	9	58	19	0.3	3.6	0.75	97	82.1129	58.122
2014	9	26	10	8	19	0.3	3.6	0.77	96.2	82.0472	59.3526
2014	9	26	10	18	19	0.3	3.6	0.78	95.1	82.1129	60.6824
2014	9	26	10	28	19	0.3	3.6	0.77	95.4	82.1129	59.9143
2014	9	26	10	38	19	0.3	3.6	0.82	98.1	82.1129	62.9868
2014	9	26	10	48	19	0.3	3.6	0.72	95.5	82.0472	55.7709
2014	9	26	10	58	19	0.3	3.6	0.76	96.2	82.1129	59.1461
2014	9	26	11	8	19	0.3	3.6	0.72	94.7	82.1129	56.3296
2014	9	26	11	18	19	0.3	3.6	0.75	97.6	82.1129	57.8658
2014	9	26	11	28	19	0.3	3.6	0.75	98.3	82.1129	58.1218
2014	9	26	11	38	19	0.3	3.6	0.77	96.4	82.1129	59.6581
2014	9	26	11	48	19	0.3	3.6	0.73	95.5	82.0472	56.2825
2014	9	26	11	58	19	0.3	3.6	0.74	95.6	82.0472	57.3058
2014	9	26	12	8	19	0.3	3.6	0.76	97.5	82.1129	58.6339
2014	9	26	12	18	19	0.3	3.6	0.72	95.5	82.1129	56.0734
2014	9	26	12	28	19	0.3	3.6	0.74	96.1	82.0472	57.0499
2014	9	26	12	38	19	0.3	3.6	0.77	95.6	82.1129	60.1701
2014	9	26	12	48	19	0.3	3.6	0.77	95.4	82.0472	59.6082
2014	9	26	12	58	19	0.3	3.6	0.77	96.9	82.0472	59.6082
2014	9	26	13	8	19	0.3	3.6	0.77	94.6	81.9816	59.814
2014	9	26	13	18	19	0.3	3.6	0.76	96	81.9816	58.5359

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	13	28	19	0.3	3.6	0.77	94.6	81.9816	59.814
2014	9	26	13	38	19	0.3	3.6	0.78	99.2	81.9816	60.0696
2014	9	26	13	48	19	0.3	3.6	0.8	99	82.0472	61.6547
2014	9	26	13	58	19	0.3	3.6	0.74	96.6	81.916	57.4653
2014	9	26	14	8	19	0.3	3.6	0.75	95	81.916	58.2315
2014	9	26	14	18	19	0.3	3.6	0.79	96.7	81.916	61.0409
2014	9	26	14	28	19	0.3	3.6	0.77	94.6	81.9816	59.8139
2014	9	26	14	38	19	0.3	3.6	0.74	96.9	81.916	56.9545
2014	9	26	14	48	19	0.3	3.6	0.71	97.4	81.916	54.9113
2014	9	26	14	58	19	0.3	3.6	0.77	96.1	81.916	59.5085
2014	9	26	15	8	19	0.3	3.6	0.77	97.1	81.8504	59.2035
2014	9	26	15	18	19	0.3	3.6	0.73	94.9	81.916	56.4437
2014	9	26	15	28	19	0.3	3.6	0.74	95.1	81.916	57.7207
2014	9	26	15	38	19	0.3	3.6	0.77	94.4	81.8504	59.7139
2014	9	26	15	48	19	0.3	3.6	0.79	96.4	81.8504	60.9899
2014	9	26	15	58	19	0.3	3.6	0.75	97.5	81.8504	58.1828
2014	9	26	16	8	19	0.3	3.6	0.79	95.5	81.8504	61.2451
2014	9	26	16	18	19	0.3	3.6	0.75	93.7	81.8504	58.438
2014	9	26	16	28	19	0.3	3.6	0.8	99	81.8504	61.2451
2014	9	26	16	38	19	0.3	3.6	0.78	97.5	81.7848	59.9189
2014	9	26	16	48	19	0.3	3.6	0.77	94.4	81.8504	59.714
2014	9	26	16	58	19	0.3	3.6	0.79	95.5	81.8504	60.9899
2014	9	26	17	8	19	0.3	3.6	0.78	93.6	81.7848	60.1739
2014	9	26	17	18	19	0.3	3.6	0.83	97	81.7848	64.2535
2014	9	26	17	28	19	0.3	3.6	0.76	96.2	81.7848	58.8991
2014	9	26	17	38	19	0.3	3.6	0.77	97.8	81.7848	59.664
2014	9	26	17	48	19	0.3	3.6	0.79	96.7	81.7192	60.8878
2014	9	26	17	58	19	0.3	3.6	0.82	95.7	81.7848	63.4886
2014	9	26	18	8	19	0.3	3.6	0.74	97.3	81.7192	57.3212
2014	9	26	18	18	19	0.3	3.6	0.8	96.3	81.7192	61.9069
2014	9	26	18	28	19	0.3	3.6	0.8	94.9	81.7192	61.9069
2014	9	26	18	38	19	0.3	3.6	0.78	95.8	81.7192	59.8688
2014	9	26	18	48	19	0.3	3.6	0.78	97.7	81.7192	60.3783
2014	9	26	18	58	19	0.3	3.6	0.77	97.6	81.7192	59.3593
2014	9	26	19	8	19	0.3	3.6	0.78	97	81.7192	59.8688
2014	9	26	19	18	19	0.3	3.6	0.74	98.4	81.7848	56.8594
2014	9	26	19	28	19	0.3	3.6	0.76	95.2	81.7192	59.1046
2014	9	26	19	38	19	0.3	3.6	0.79	97.6	81.7848	60.939
2014	9	26	19	48	19	0.3	3.6	0.75	97	81.7848	58.1343
2014	9	26	19	58	19	0.3	3.6	0.76	96.7	81.7848	58.3892
2014	9	26	20	8	19	0.3	3.6	0.78	98.5	81.7848	59.6641
2014	9	26	20	18	19	0.3	3.6	0.78	94.3	81.7848	60.4291
2014	9	26	20	28	19	0.3	3.6	0.81	95.4	81.7848	62.4689
2014	9	26	20	38	19	0.3	3.6	0.73	96.2	81.8504	56.6519
2014	9	26	20	48	19	0.3	3.6	0.76	94.7	81.7848	59.1543
2014	9	26	20	58	19	0.3	3.6	0.79	95.9	81.8504	61.5005

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	26	21	8	19	0.3	3.6	0.74	96.9	81.7848	57.1145
2014	9	26	21	18	19	0.3	3.6	0.75	96.8	81.7848	57.6245
2014	9	26	21	28	19	0.3	3.6	0.78	96	81.7848	60.1742
2014	9	26	21	38	19	0.3	3.6	0.79	94.5	81.7848	61.1941
2014	9	26	21	48	19	0.3	3.6	0.77	96.4	81.7848	59.1544
2014	9	26	21	58	19	0.3	3.6	0.8	96.6	81.7848	61.4492
2014	9	26	22	8	19	0.3	3.6	0.76	96.9	81.7848	58.8994
2014	9	26	22	18	19	0.3	3.6	0.76	94.9	81.7848	58.8994
2014	9	26	22	28	19	0.3	3.6	0.78	96.8	81.7848	59.9193
2014	9	26	22	38	19	0.3	3.6	0.73	95.4	81.8504	56.9073
2014	9	26	22	48	19	0.3	3.6	0.78	96.8	81.7848	59.9194
2014	9	26	22	58	19	0.3	3.6	0.76	96.9	81.7848	58.8995
2014	9	26	23	8	19	0.3	3.6	0.78	96.8	81.7848	60.1744
2014	9	26	23	18	19	0.3	3.6	0.77	97.1	81.7848	59.4095
2014	9	26	23	28	19	0.3	3.6	0.77	96.6	81.7848	59.6645
2014	9	26	23	38	19	0.3	3.6	0.79	96	81.7848	60.9393
2014	9	26	23	48	19	0.3	3.6	0.79	96.2	81.7848	61.1943
2014	9	26	23	58	19	0.3	3.6	0.75	95.5	81.8504	57.9282
2014	9	27	0	8	19	0.3	3.6	0.84	94.7	81.7848	65.019
2014	9	27	0	18	19	0.3	3.6	0.78	97.2	81.7848	60.4294
2014	9	27	0	28	19	0.3	3.6	0.76	95.2	81.7848	59.1546
2014	9	27	0	38	19	0.3	3.6	0.76	95.9	81.7848	58.8996
2014	9	27	0	48	19	0.3	3.6	0.81	96.5	81.916	62.8294
2014	9	27	0	58	19	0.3	3.6	0.79	96.4	81.8504	60.9905
2014	9	27	1	8	19	0.3	3.6	0.79	96.7	81.8504	60.9905
2014	9	27	1	18	19	0.3	3.6	0.81	97	81.8504	62.2665
2014	9	27	1	28	19	0.3	3.6	0.81	96.5	81.8504	62.5217
2014	9	27	1	38	19	0.3	3.6	0.79	98.9	81.7848	60.4295
2014	9	27	1	48	19	0.3	3.6	0.77	94.4	81.7848	59.4096
2014	9	27	1	58	19	0.3	3.6	0.75	96.1	81.8504	57.6731
2014	9	27	2	8	19	0.3	3.6	0.8	97.5	81.916	61.8079
2014	9	27	2	18	19	0.3	3.6	0.82	95	81.9816	63.649
2014	9	27	2	28	19	0.3	3.6	0.81	98.4	81.9816	62.1153
2014	9	27	2	38	19	0.3	3.6	0.79	96.4	81.9816	61.3484
2014	9	27	2	48	19	0.3	3.6	0.81	95.4	81.9816	62.6265
2014	9	27	2	58	19	0.3	3.6	0.8	95.2	81.9816	61.8597
2014	9	27	3	8	19	0.3	3.6	0.82	95.9	81.9816	63.9046
2014	9	27	3	18	19	0.3	3.6	0.79	96.4	81.9816	61.0928
2014	9	27	3	28	19	0.3	3.6	0.8	94.3	81.9816	61.8597
2014	9	27	3	38	19	0.3	3.6	0.83	97.2	81.9816	64.4159
2014	9	27	3	48	19	0.3	3.6	0.76	97.4	81.9816	59.0479
2014	9	27	3	58	19	0.3	3.6	0.82	95.7	81.9816	63.9047
2014	9	27	4	8	19	0.3	3.6	0.78	98	81.9816	59.8148
2014	9	27	4	18	19	0.3	3.6	0.79	96.4	81.9816	61.0929
2014	9	27	4	28	19	0.3	3.6	0.85	94.4	81.9816	65.6941
2014	9	27	4	38	19	0.3	3.6	0.8	96.4	81.9816	61.8598

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	4	48	19	0.3	3.6	0.78	97.7	81.9816	60.5817
2014	9	27	4	58	19	0.3	3.6	0.8	96.4	81.9816	61.8599
2014	9	27	5	8	19	0.3	3.6	0.8	95.6	81.9816	62.1155
2014	9	27	5	18	19	0.3	3.6	0.8	95.4	81.9816	61.8599
2014	9	27	5	28	19	0.3	3.6	0.79	96.7	81.9816	61.093
2014	9	27	5	38	19	0.3	3.6	0.81	95.1	81.9816	62.6268
2014	9	27	5	48	19	0.3	3.6	0.81	95.6	81.9816	62.6268
2014	9	27	5	58	19	0.3	3.6	0.82	96.9	81.9816	63.6493
2014	9	27	6	8	19	0.3	3.6	0.81	98.4	82.0472	62.1675
2014	9	27	6	18	19	0.3	3.6	0.8	95.9	82.0472	61.9117
2014	9	27	6	28	19	0.3	3.6	0.82	96.2	81.9816	63.9049
2014	9	27	6	38	19	0.3	3.6	0.79	95.7	81.9816	61.6044
2014	9	27	6	48	19	0.3	3.6	0.79	96.2	82.0472	61.1442
2014	9	27	6	58	19	0.3	3.6	0.8	93.8	81.9816	62.3712
2014	9	27	7	8	19	0.3	3.6	0.79	95	82.0472	61.1442
2014	9	27	7	18	19	0.3	3.6	0.8	97.1	82.0472	61.9117
2014	9	27	7	28	19	0.3	3.6	0.81	94.7	82.0472	62.6792
2014	9	27	7	38	19	0.3	3.6	0.8	94.2	81.9816	62.3713
2014	9	27	7	48	19	0.3	3.6	0.79	96.2	81.9816	61.0932
2014	9	27	7	58	19	0.3	3.6	0.8	95.4	82.0472	61.9118
2014	9	27	8	8	19	0.3	3.6	0.8	97.1	81.9816	61.8601
2014	9	27	8	18	19	0.3	3.6	0.81	93	82.0472	62.9351
2014	9	27	8	28	19	0.3	3.6	0.81	99.5	82.0472	62.4235
2014	9	27	8	38	19	0.3	3.6	0.81	97.4	82.0472	62.6793
2014	9	27	8	48	19	0.3	3.6	0.76	95.2	81.9816	58.7926
2014	9	27	8	58	19	0.3	3.6	0.8	94.5	82.0472	62.1676
2014	9	27	9	8	19	0.3	3.6	0.77	94.4	82.0472	60.1209
2014	9	27	9	18	19	0.3	3.6	0.8	94.5	82.0472	62.4234
2014	9	27	9	28	19	0.3	3.6	0.81	95.8	82.0472	63.1909
2014	9	27	9	38	19	0.3	3.6	0.77	95.6	82.0472	60.1209
2014	9	27	9	48	19	0.3	3.6	0.77	97.8	82.0472	59.865
2014	9	27	9	58	19	0.3	3.6	0.82	96.2	82.0472	63.1909
2014	9	27	10	8	19	0.3	3.6	0.77	94.7	82.0472	59.6092
2014	9	27	10	18	19	0.3	3.6	0.77	95.9	82.0472	59.6092
2014	9	27	10	28	19	0.3	3.6	0.78	94.6	82.0472	60.8883
2014	9	27	10	38	19	0.3	3.6	0.79	95.3	82.0472	61.1441
2014	9	27	10	48	19	0.3	3.6	0.81	97	82.0472	62.4233
2014	9	27	10	58	19	0.3	3.6	0.77	95.6	82.1129	60.171
2014	9	27	11	8	19	0.3	3.6	0.79	96.4	82.0472	61.3999
2014	9	27	11	18	19	0.3	3.6	0.8	94.7	82.0472	62.4232
2014	9	27	11	28	19	0.3	3.6	0.75	96	82.0472	58.0741
2014	9	27	11	38	19	0.3	3.6	0.79	95.2	82.0472	61.3999
2014	9	27	11	48	19	0.3	3.6	0.8	96.8	82.1129	62.2193
2014	9	27	11	58	19	0.3	3.6	0.8	95.9	82.1129	61.9632
2014	9	27	12	8	19	0.3	3.6	0.77	95.6	82.0472	60.1206
2014	9	27	12	18	19	0.3	3.6	0.79	95.7	82.1129	61.4511

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	12	28	19	0.3	3.6	0.79	96.5	82.1129	60.939
2014	9	27	12	38	19	0.3	3.6	0.79	95.5	82.1129	61.451
2014	9	27	12	48	19	0.3	3.6	0.81	94.2	82.0472	63.1906
2014	9	27	12	58	19	0.3	3.6	0.77	93.9	82.0472	60.1206
2014	9	27	13	8	19	0.3	3.6	0.79	97.8	82.0472	61.3997
2014	9	27	13	18	19	0.3	3.6	0.8	94	82.0472	62.423
2014	9	27	13	28	19	0.3	3.6	0.78	96.3	82.0472	60.3764
2014	9	27	13	38	19	0.3	3.6	0.77	97.1	82.0472	59.6089
2014	9	27	13	48	19	0.3	3.6	0.81	96.3	82.0472	62.9347
2014	9	27	13	58	19	0.3	3.6	0.8	95.9	82.0472	61.9113
2014	9	27	14	8	19	0.3	3.6	0.77	96.4	82.0472	59.6088
2014	9	27	14	18	19	0.3	3.6	0.78	95	82.0472	60.888
2014	9	27	14	28	19	0.3	3.6	0.78	95.3	82.0472	60.3763
2014	9	27	14	38	19	0.3	3.6	0.8	95.4	82.0472	61.9113
2014	9	27	14	48	19	0.3	3.6	0.77	97.1	82.0472	59.6089
2014	9	27	14	58	19	0.3	3.6	0.78	95.5	82.0472	60.888
2014	9	27	15	8	19	0.3	3.6	0.79	96.2	82.0472	60.8881
2014	9	27	15	18	19	0.3	3.6	0.82	94.6	82.0472	63.7023
2014	9	27	15	28	19	0.3	3.6	0.81	97.2	82.0472	62.679
2014	9	27	15	38	19	0.3	3.6	0.77	95.1	82.0472	60.1206
2014	9	27	15	48	19	0.3	3.6	0.83	95.5	82.0472	64.214
2014	9	27	15	58	19	0.3	3.6	0.79	96.7	82.0472	61.3998
2014	9	27	16	8	19	0.3	3.6	0.81	94.2	82.0472	62.679
2014	9	27	16	18	19	0.3	3.6	0.81	95.4	82.0472	62.679
2014	9	27	16	28	19	0.3	3.6	0.8	95.9	82.0472	62.4231
2014	9	27	16	38	19	0.3	3.6	0.75	95.5	82.0472	58.5857
2014	9	27	16	48	19	0.3	3.6	0.82	95.5	82.0472	63.4465
2014	9	27	16	58	19	0.3	3.6	0.82	96.2	82.0472	63.9581
2014	9	27	17	8	19	0.3	3.6	0.78	97	82.0472	60.3765
2014	9	27	17	18	19	0.3	3.6	0.85	96.4	82.0472	66.0048
2014	9	27	17	28	19	0.3	3.6	0.81	97	82.0472	62.4232
2014	9	27	17	38	19	0.3	3.6	0.8	96.1	82.0472	62.1673
2014	9	27	17	48	19	0.3	3.6	0.8	95.4	82.1129	62.2193
2014	9	27	17	58	19	0.3	3.6	0.8	95.2	82.1129	62.4753
2014	9	27	18	8	19	0.3	3.6	0.76	94.7	82.1129	59.4028
2014	9	27	18	18	19	0.3	3.6	0.82	95.5	82.1129	63.4995
2014	9	27	18	28	19	0.3	3.6	0.84	97.2	82.1129	65.0358
2014	9	27	18	38	19	0.3	3.6	0.83	95.7	82.1129	64.5237
2014	9	27	18	48	19	0.3	3.6	0.85	95.3	82.1129	66.06
2014	9	27	18	58	19	0.3	3.6	0.75	93.5	82.1129	58.3786
2014	9	27	19	8	19	0.3	3.6	0.82	97.6	82.1129	63.4996
2014	9	27	19	18	19	0.3	3.6	0.81	97.9	82.1129	62.9875
2014	9	27	19	28	19	0.3	3.6	0.8	95.9	82.1129	62.4754
2014	9	27	19	38	19	0.3	3.6	0.79	95.3	82.1129	61.1952
2014	9	27	19	48	19	0.3	3.6	0.82	96.9	82.1129	63.7557
2014	9	27	19	58	19	0.3	3.6	0.82	98.3	82.1129	63.4997

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	27	20	8	19	0.3	3.6	0.82	96.9	82.1129	63.7557
2014	9	27	20	18	19	0.3	3.6	0.82	95.3	82.1129	63.7558
2014	9	27	20	28	19	0.3	3.6	0.83	96.1	82.1129	64.5239
2014	9	27	20	38	19	0.3	3.6	0.81	96.1	82.1129	62.4756
2014	9	27	20	48	19	0.3	3.6	0.83	95.4	82.1129	64.78
2014	9	27	20	58	19	0.3	3.6	0.78	97.5	82.1129	60.4272
2014	9	27	21	8	19	0.3	3.6	0.82	96.9	82.1129	63.2438
2014	9	27	21	18	19	0.3	3.6	0.84	95.6	82.1129	65.2922
2014	9	27	21	28	19	0.3	3.6	0.81	94	82.1129	62.7317
2014	9	27	21	38	19	0.3	3.6	0.8	96.4	82.1129	61.9636
2014	9	27	21	48	19	0.3	3.6	0.84	98.1	82.1129	64.5241
2014	9	27	21	58	19	0.3	3.6	0.83	97	82.1129	64.5241
2014	9	27	22	8	19	0.3	3.6	0.83	98.2	82.1129	63.756
2014	9	27	22	18	19	0.3	3.6	0.79	96.2	82.1129	61.1955
2014	9	27	22	28	19	0.3	3.6	0.84	95.2	82.1129	65.0363
2014	9	27	22	38	19	0.3	3.6	0.82	96.2	82.1129	63.2439
2014	9	27	22	48	19	0.3	3.6	0.79	96.4	82.1129	61.4516
2014	9	27	22	58	19	0.3	3.6	0.8	96.6	82.1785	62.0155
2014	9	27	23	8	19	0.3	3.6	0.77	95.6	82.1785	59.9654
2014	9	27	23	18	19	0.3	3.6	0.82	95.3	82.1785	63.5531
2014	9	27	23	28	19	0.3	3.6	0.82	94.4	82.1785	63.8093
2014	9	27	23	38	19	0.3	3.6	0.82	97.3	82.1785	63.8094
2014	9	27	23	48	19	0.3	3.6	0.82	95.3	82.1785	64.0656
2014	9	27	23	58	19	0.3	3.6	0.84	99.2	82.1785	65.0907
2014	9	28	0	8	19	0.3	3.6	0.82	96.6	82.1785	63.8094
2014	9	28	0	18	19	0.3	3.6	0.82	96.4	82.1785	63.5532
2014	9	28	0	28	19	0.3	3.6	0.79	94.5	82.1785	61.2468
2014	9	28	0	38	19	0.3	3.6	0.84	95.8	82.1785	65.0908
2014	9	28	0	48	19	0.3	3.6	0.78	94.8	82.1785	60.9906
2014	9	28	0	58	19	0.3	3.6	0.81	96.7	82.1785	63.0407
2014	9	28	1	8	19	0.3	3.6	0.81	95.1	82.1785	63.297
2014	9	28	1	18	19	0.3	3.6	0.81	94.2	82.1785	63.297
2014	9	28	1	28	19	0.3	3.6	0.82	95.8	82.1785	63.5533
2014	9	28	1	38	19	0.3	3.6	0.84	97.8	82.1785	65.3471
2014	9	28	1	48	19	0.3	3.6	0.8	95.4	82.1785	62.0157
2014	9	28	1	58	19	0.3	3.6	0.78	95.1	82.1785	60.4782
2014	9	28	2	8	19	0.3	3.6	0.78	97	82.1785	60.7344
2014	9	28	2	18	19	0.3	3.6	0.84	96.5	82.1785	65.0909
2014	9	28	2	28	19	0.3	3.6	0.82	95.8	82.2441	63.6064
2014	9	28	2	38	19	0.3	3.6	0.79	95.2	82.2441	61.5546
2014	9	28	2	48	19	0.3	3.6	0.79	96.5	82.2441	61.0417
2014	9	28	2	58	19	0.3	3.6	0.81	96.3	82.2441	62.5805
2014	9	28	3	8	19	0.3	3.6	0.81	97.9	82.2441	63.0935
2014	9	28	3	18	19	0.3	3.6	0.82	97.2	82.2441	63.35
2014	9	28	3	28	19	0.3	3.6	0.79	95.2	82.3097	61.8627
2014	9	28	3	38	19	0.3	3.6	0.81	97.7	82.3097	62.8895

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	3	48	19	0.3	3.6	0.81	96.3	82.3753	62.9418
2014	9	28	3	58	19	0.3	3.6	0.78	96.8	82.3753	60.6297
2014	9	28	4	8	19	0.3	3.6	0.82	96.2	82.3753	64.2264
2014	9	28	4	18	19	0.3	3.9	0.79	95.2	82.4409	61.7087
2014	9	28	4	28	19	0.3	3.9	0.82	96.2	82.4409	64.0228
2014	9	28	4	38	19	0.3	3.9	0.87	96.9	82.4409	67.6225
2014	9	28	4	48	19	0.3	3.9	0.82	95.3	82.4409	64.2799
2014	9	28	4	58	19	0.3	3.9	0.8	95.4	82.4409	62.7372
2014	9	28	5	8	19	0.3	3.9	0.82	93.9	82.4409	63.7657
2014	9	28	5	18	19	0.3	3.9	0.81	99.8	82.4409	62.223
2014	9	28	5	28	19	0.3	3.9	0.82	96.2	82.4409	64.28
2014	9	28	5	38	19	0.3	3.9	0.85	96.9	82.4409	65.8228
2014	9	28	5	48	19	0.3	3.9	0.81	96.1	82.4409	62.7373
2014	9	28	5	58	19	0.3	3.9	0.77	96.1	82.4409	59.909
2014	9	28	6	8	19	0.3	3.9	0.82	96.2	82.4409	64.023
2014	9	28	6	18	19	0.3	3.9	0.81	95.1	82.4409	62.9945
2014	9	28	6	28	19	0.3	3.9	0.8	96.4	82.4409	61.9661
2014	9	28	6	38	19	0.3	3.9	0.76	96	82.4409	59.1378
2014	9	28	6	48	19	0.3	3.9	0.82	97.3	82.5066	64.0763
2014	9	28	6	58	19	0.3	3.9	0.79	97.6	82.5066	61.503
2014	9	28	7	8	19	0.3	3.9	0.79	93.3	82.5066	61.7603
2014	9	28	7	18	19	0.3	3.9	0.82	96.2	82.5066	63.819
2014	9	28	7	28	19	0.3	3.9	0.78	96.1	82.5066	60.4737
2014	9	28	7	38	19	0.3	3.9	0.8	96.6	82.5066	62.0177
2014	9	28	7	48	19	0.3	3.9	0.8	97	82.5066	62.5324
2014	9	28	7	58	19	0.3	3.9	0.83	96.1	82.5066	64.8484
2014	9	28	8	8	19	0.3	3.9	0.79	96.7	82.5066	61.5031
2014	9	28	8	18	19	0.3	3.9	0.79	97.6	82.5066	61.5031
2014	9	28	8	28	19	0.3	3.9	0.82	97.4	82.5066	63.8191
2014	9	28	8	38	19	0.3	3.9	0.83	97.3	82.5066	64.3337
2014	9	28	8	48	19	0.3	3.9	0.81	96.5	82.5066	62.7897
2014	9	28	8	58	19	0.3	3.9	0.84	96.3	82.5066	65.1057
2014	9	28	9	8	19	0.3	3.9	0.79	97.7	82.5066	61.2457
2014	9	28	9	18	19	0.3	3.9	0.81	96.3	82.5066	62.7897
2014	9	28	9	28	19	0.3	3.9	0.84	96.3	82.5066	65.1057
2014	9	28	9	38	19	0.3	3.9	0.82	97.4	82.5066	63.5616
2014	9	28	9	48	19	0.3	3.9	0.78	97.2	82.5722	60.7814
2014	9	28	9	58	19	0.3	3.9	0.79	93.3	82.5066	61.7602
2014	9	28	10	8	19	0.3	3.9	0.82	96.4	82.5722	64.1295
2014	9	28	10	18	19	0.3	3.9	0.84	97.4	82.5066	65.3629
2014	9	28	10	28	19	0.3	3.9	0.8	96.4	82.5722	62.069
2014	9	28	10	38	19	0.3	3.9	0.79	96.9	82.5066	61.7602
2014	9	28	10	48	19	0.3	3.9	0.78	95.3	82.5722	60.7813
2014	9	28	10	58	19	0.3	3.9	0.83	98.4	82.5722	64.3869
2014	9	28	11	8	19	0.3	3.9	0.77	96.9	82.5722	60.0085
2014	9	28	11	18	19	0.3	3.9	0.83	97	82.5722	64.9019

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	11	28	19	0.3	3.9	0.77	98.8	82.5722	59.7509
2014	9	28	11	38	19	0.3	3.9	0.81	98.4	82.5722	63.099
2014	9	28	11	48	19	0.3	3.9	0.85	96.6	82.5722	66.4471
2014	9	28	11	58	19	0.3	3.9	0.83	96.1	82.5066	64.5906
2014	9	28	12	8	19	0.3	3.9	0.8	98.5	82.5066	62.0172
2014	9	28	12	18	19	0.3	3.9	0.78	98.7	82.5066	60.7306
2014	9	28	12	28	19	0.3	3.9	0.84	97	82.5066	65.3625
2014	9	28	12	38	19	0.3	3.9	0.8	96.6	82.5722	62.5838
2014	9	28	12	48	19	0.3	3.9	0.8	94.7	82.5066	62.5318
2014	9	28	12	58	19	0.3	3.6	0.78	95.3	82.3753	60.8865
2014	9	28	13	8	19	0.3	3.9	0.78	94.8	82.5066	61.2451
2014	9	28	13	18	19	0.3	3.6	0.78	94.8	82.3753	60.8865
2014	9	28	13	28	19	0.3	3.6	0.76	95.7	82.3753	59.0881
2014	9	28	13	38	19	0.3	3.6	0.76	97.7	82.3753	58.8312
2014	9	28	13	48	19	0.3	3.6	0.8	93.5	82.3753	62.171
2014	9	28	13	58	19	0.3	3.6	0.77	98.1	82.3753	59.8588
2014	9	28	14	8	19	0.3	3.6	0.8	96.4	82.3097	62.1193
2014	9	28	14	18	19	0.3	3.6	0.83	98	82.3753	64.2262
2014	9	28	14	28	19	0.3	3.6	0.8	93	82.3097	62.6326
2014	9	28	14	38	19	0.3	3.6	0.77	94.4	82.3753	60.1157
2014	9	28	14	48	19	0.3	3.6	0.75	96.3	82.3097	58.5256
2014	9	28	14	58	19	0.3	3.6	0.79	96.2	82.3753	61.4003
2014	9	28	15	8	19	0.3	3.6	0.8	95.4	82.3097	62.3759
2014	9	28	15	18	19	0.3	3.6	0.81	96.8	82.3097	62.6326
2014	9	28	15	28	19	0.3	3.6	0.83	96.1	82.3097	64.9428
2014	9	28	15	38	19	0.3	3.6	0.78	93.9	82.2441	60.5286
2014	9	28	15	48	19	0.3	3.6	0.81	96.7	82.3097	63.146
2014	9	28	15	58	19	0.3	3.6	0.8	95.2	82.3097	62.1192
2014	9	28	16	8	19	0.3	3.6	0.79	95	82.3097	61.8625
2014	9	28	16	18	19	0.3	3.6	0.82	97.1	82.3753	63.9692
2014	9	28	16	28	19	0.3	3.6	0.85	97.7	82.3097	66.2262
2014	9	28	16	38	19	0.3	3.6	0.8	96.9	82.3097	61.8625
2014	9	28	16	48	19	0.3	3.6	0.8	97	82.2441	62.3239
2014	9	28	16	58	19	0.3	3.6	0.8	97.1	82.3097	62.1192
2014	9	28	17	8	19	0.3	3.6	0.82	95.7	82.3097	64.1727
2014	9	28	17	18	19	0.3	3.6	0.77	97.9	82.3097	59.2956
2014	9	28	17	28	19	0.3	3.6	0.84	96.2	82.2441	65.6581
2014	9	28	17	38	19	0.3	3.6	0.76	94.9	82.3097	59.5522
2014	9	28	17	48	19	0.3	3.6	0.78	97.5	82.3097	60.579
2014	9	28	17	58	19	0.3	3.6	0.86	96.6	82.3753	66.7952
2014	9	28	18	8	19	0.3	3.6	0.83	95.2	82.3753	64.7399
2014	9	28	18	18	19	0.3	3.6	0.78	96.3	82.3097	60.8357
2014	9	28	18	28	19	0.3	3.6	0.8	96.6	82.3097	62.1192
2014	9	28	18	38	19	0.3	3.6	0.79	93.8	82.3097	61.8625
2014	9	28	18	48	19	0.3	3.6	0.81	96.8	82.3753	62.6847
2014	9	28	18	58	19	0.3	3.6	0.79	95.7	82.3753	61.4002

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	28	19	8	19	0.3	3.6	0.79	98.9	82.3753	60.8864
2014	9	28	19	18	19	0.3	3.6	0.81	97.2	82.3753	63.1985
2014	9	28	19	28	19	0.3	3.9	0.8	95.9	82.4409	62.2227
2014	9	28	19	38	19	0.3	3.6	0.8	97.3	82.3753	61.914
2014	9	28	19	48	19	0.3	3.6	0.8	96.9	82.3753	61.914
2014	9	28	19	58	19	0.3	3.9	0.83	94.1	82.4409	65.051
2014	9	28	20	8	19	0.3	3.9	0.81	94.4	82.4409	63.5083
2014	9	28	20	18	19	0.3	3.9	0.83	95.2	82.4409	64.5368
2014	9	28	20	28	19	0.3	3.9	0.79	94.7	82.4409	61.9656
2014	9	28	20	38	19	0.3	3.9	0.8	97.7	82.4409	62.4798
2014	9	28	20	48	19	0.3	3.9	0.8	96.6	82.5066	62.0171
2014	9	28	20	58	19	0.3	3.9	0.77	94.6	82.5066	60.2158
2014	9	28	21	8	19	0.3	3.9	0.81	95.3	82.4409	63.5083
2014	9	28	21	18	19	0.3	3.9	0.81	96	82.4409	63.2512
2014	9	28	21	28	19	0.3	3.9	0.77	93.4	82.4409	60.1658
2014	9	28	21	38	19	0.3	3.9	0.85	94.7	82.5066	66.1345
2014	9	28	21	48	19	0.3	3.9	0.82	97.8	82.5066	63.5612
2014	9	28	21	58	19	0.3	3.9	0.79	97.6	82.5066	61.5025
2014	9	28	22	8	19	0.3	3.9	0.82	97.8	82.5066	63.5612
2014	9	28	22	18	19	0.3	3.9	0.86	96.8	82.5066	66.9065
2014	9	28	22	28	19	0.3	3.9	0.81	95.4	82.5066	63.0466
2014	9	28	22	38	19	0.3	3.9	0.81	96.3	82.5066	63.3039
2014	9	28	22	48	19	0.3	3.9	0.8	95.7	82.5722	62.3263
2014	9	28	22	58	19	0.3	3.9	0.81	94.9	82.5722	63.6141
2014	9	28	23	8	19	0.3	3.9	0.87	99.4	82.5722	67.2197
2014	9	28	23	18	19	0.3	3.9	0.8	96.1	82.5722	62.3263
2014	9	28	23	28	19	0.3	3.9	0.81	97.4	82.5722	63.099
2014	9	28	23	38	19	0.3	3.9	0.81	97.9	82.5722	62.8414
2014	9	28	23	48	19	0.3	3.9	0.81	96.8	82.5722	62.8415
2014	9	28	23	58	19	0.3	3.9	0.84	95.4	82.5722	65.4169
2014	9	29	0	8	19	0.3	3.9	0.81	94.2	82.5722	63.099
2014	9	29	0	18	19	0.3	3.9	0.8	98.7	82.5722	62.3264
2014	9	29	0	28	19	0.3	3.9	0.81	95.8	82.5722	63.3566
2014	9	29	0	38	19	0.3	3.9	0.78	96.8	82.5722	60.5236
2014	9	29	0	48	19	0.3	3.9	0.76	95.2	82.5722	59.7509
2014	9	29	0	58	19	0.3	3.9	0.82	96.2	82.5722	63.6142
2014	9	29	1	8	19	0.3	3.9	0.77	97.3	82.5722	60.0085
2014	9	29	1	18	19	0.3	3.9	0.8	98.3	82.5722	62.0689
2014	9	29	1	28	19	0.3	3.9	0.81	94.9	82.5722	63.0991
2014	9	29	1	38	19	0.3	3.9	0.82	95	82.5722	64.3869
2014	9	29	1	48	19	0.3	3.9	0.77	95.1	82.5722	60.2661
2014	9	29	1	58	19	0.3	3.9	0.81	97.4	82.5722	63.3567
2014	9	29	2	8	19	0.3	3.9	0.8	96.8	82.5722	62.3265
2014	9	29	2	18	19	0.3	3.9	0.8	96.4	82.5722	62.069
2014	9	29	2	28	19	0.3	3.9	0.82	95.1	82.5722	63.8719
2014	9	29	2	38	19	0.3	3.9	0.8	98.7	82.5722	62.069

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	2	48	19	0.3	3.9	0.81	97.6	82.5722	63.3568
2014	9	29	2	58	19	0.3	3.9	0.8	98	82.5722	62.3266
2014	9	29	3	8	19	0.3	3.9	0.82	94.8	82.6378	64.4405
2014	9	29	3	18	19	0.3	3.9	0.8	95.4	82.5722	62.5842
2014	9	29	3	28	19	0.3	3.9	0.81	93	82.5722	63.3569
2014	9	29	3	38	19	0.3	3.9	0.85	97.3	82.5722	65.9324
2014	9	29	3	48	19	0.3	3.9	0.78	95.5	82.5722	61.2966
2014	9	29	3	58	19	0.3	3.9	0.79	96	82.5722	61.2966
2014	9	29	4	8	19	0.3	3.9	0.82	96.2	82.5722	64.1296
2014	9	29	4	18	19	0.3	3.9	0.79	95.3	82.5722	61.5541
2014	9	29	4	28	19	0.3	3.9	0.83	95.6	82.6378	65.2139
2014	9	29	4	38	19	0.3	3.9	0.82	96.4	82.5722	63.8721
2014	9	29	4	48	19	0.3	3.9	0.79	95.3	82.5722	61.5542
2014	9	29	4	58	19	0.3	3.9	0.77	96.6	82.5722	60.2665
2014	9	29	5	8	19	0.3	3.9	0.82	93.4	82.5722	64.1297
2014	9	29	5	18	19	0.3	3.9	0.79	96.9	82.5722	61.8118
2014	9	29	5	28	19	0.3	3.9	0.8	97.3	82.5722	62.3269
2014	9	29	5	38	19	0.3	3.9	0.81	96.1	82.5722	62.842
2014	9	29	5	48	19	0.3	3.9	0.84	94.5	82.5722	65.4175
2014	9	29	5	58	19	0.3	3.9	0.77	96.8	82.5722	60.2666
2014	9	29	6	8	19	0.3	3.9	0.85	96	82.5722	66.1902
2014	9	29	6	18	19	0.3	3.9	0.79	94.3	82.5722	61.5543
2014	9	29	6	28	19	0.3	3.9	0.83	97	82.5722	64.9025
2014	9	29	6	38	19	0.3	3.9	0.82	96.4	82.5722	63.8723
2014	9	29	6	48	19	0.3	3.9	0.85	96.4	82.5722	66.4478
2014	9	29	6	58	19	0.3	3.9	0.81	97	82.5722	63.3572
2014	9	29	7	8	19	0.3	3.9	0.8	94.9	82.5722	62.5846
2014	9	29	7	18	19	0.3	3.9	0.76	95.2	82.5722	59.2365
2014	9	29	7	28	19	0.3	3.9	0.8	96.8	82.5722	62.5846
2014	9	29	7	38	19	0.3	3.9	0.83	96.1	82.5722	65.1601
2014	9	29	7	48	19	0.3	3.9	0.81	96.1	82.5722	63.0997
2014	9	29	7	58	19	0.3	3.9	0.77	93.9	82.5722	60.5243
2014	9	29	8	8	19	0.3	3.9	0.77	96.6	82.5722	60.2667
2014	9	29	8	18	19	0.3	3.9	0.82	96.2	82.5722	63.8724
2014	9	29	8	28	19	0.3	3.9	0.8	96.4	82.5722	62.0696
2014	9	29	8	38	19	0.3	3.9	0.76	95.7	82.5722	59.2365
2014	9	29	8	48	19	0.3	3.9	0.81	97.4	82.5722	63.3573
2014	9	29	8	58	19	0.3	3.9	0.77	93.9	82.5722	60.5242
2014	9	29	9	8	19	0.3	3.9	0.79	95.5	82.5722	61.5544
2014	9	29	9	18	19	0.3	3.9	0.82	93.9	82.6378	63.9253
2014	9	29	9	28	19	0.3	3.9	0.79	96	82.6378	61.6054
2014	9	29	9	38	19	0.3	3.9	0.81	94.2	82.5722	63.3572
2014	9	29	9	48	19	0.3	3.9	0.79	95.2	82.6378	62.1209
2014	9	29	9	58	19	0.3	3.9	0.81	94.4	82.6378	63.152
2014	9	29	10	8	19	0.3	3.9	0.8	95.9	82.6378	62.6364
2014	9	29	10	18	19	0.3	3.9	0.86	96.8	82.6378	67.2761

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	10	28	19	0.3	3.9	0.75	95.8	82.6378	58.7699
2014	9	29	10	38	19	0.3	3.9	0.79	99.3	82.6378	61.6053
2014	9	29	10	48	19	0.3	3.9	0.78	96.5	82.6378	60.832
2014	9	29	10	58	19	0.3	3.9	0.82	97.4	82.6378	63.6674
2014	9	29	11	8	19	0.3	3.9	0.8	98	82.6378	62.3785
2014	9	29	11	18	19	0.3	3.9	0.76	94.5	82.6378	59.2853
2014	9	29	11	28	19	0.3	3.9	0.81	97.4	82.6378	63.1518
2014	9	29	11	38	19	0.3	3.9	0.78	97	82.6378	60.5741
2014	9	29	11	48	19	0.3	3.9	0.77	95.6	82.6378	60.5741
2014	9	29	11	58	19	0.3	3.9	0.82	95.3	82.6378	64.4405
2014	9	29	12	8	19	0.3	3.9	0.79	96	82.6378	61.3473
2014	9	29	12	18	19	0.3	3.9	0.76	94.5	82.6378	59.2852
2014	9	29	12	28	19	0.3	3.9	0.78	96.8	82.6378	60.8317
2014	9	29	12	38	19	0.3	3.9	0.81	97.4	82.6378	63.4093
2014	9	29	12	48	19	0.3	3.9	0.77	93.4	82.6378	60.3162
2014	9	29	12	58	19	0.3	3.9	0.81	98.1	82.6378	63.1515
2014	9	29	13	8	19	0.3	3.9	0.81	95.4	82.6378	63.1515
2014	9	29	13	18	19	0.3	3.9	0.79	95.5	82.6378	62.1204
2014	9	29	13	28	19	0.3	3.9	0.78	95.1	82.6378	60.8316
2014	9	29	13	38	19	0.3	3.9	0.81	94.2	82.6378	63.4092
2014	9	29	13	48	19	0.3	3.9	0.79	96.9	82.6378	61.6048
2014	9	29	13	58	19	0.3	3.9	0.78	94.8	82.5722	60.7811
2014	9	29	14	8	19	0.3	3.9	0.81	96.1	82.6378	62.8936
2014	9	29	14	18	19	0.3	3.9	0.8	95.4	82.5722	62.3264
2014	9	29	14	28	19	0.3	3.9	0.81	98.2	82.5722	62.5839
2014	9	29	14	38	19	0.3	3.9	0.77	97.1	82.5722	60.266
2014	9	29	14	48	19	0.3	3.9	0.81	97.4	82.5722	63.099
2014	9	29	14	58	19	0.3	3.9	0.77	98.1	82.5722	59.7509
2014	9	29	15	8	19	0.3	3.9	0.8	96.3	82.5722	62.5839
2014	9	29	15	18	19	0.3	3.9	0.83	97.1	82.5722	64.3867
2014	9	29	15	28	19	0.3	3.9	0.8	96.4	82.5722	62.0688
2014	9	29	15	38	19	0.3	3.9	0.8	95.9	82.5722	62.5838
2014	9	29	15	48	19	0.3	3.9	0.76	97.2	82.5722	59.4933
2014	9	29	15	58	19	0.3	3.9	0.79	97.8	82.5066	61.7599
2014	9	29	16	8	19	0.3	3.9	0.82	95.1	82.5066	63.8186
2014	9	29	16	18	19	0.3	3.9	0.81	97.6	82.5722	63.3565
2014	9	29	16	28	19	0.3	3.9	0.8	97.5	82.5066	62.2746
2014	9	29	16	38	19	0.3	3.9	0.79	97.4	82.5066	61.5026
2014	9	29	16	48	19	0.3	3.9	0.83	98.9	82.5066	64.0759
2014	9	29	16	58	19	0.3	3.9	0.79	96.5	82.5066	61.2452
2014	9	29	17	8	19	0.3	3.9	0.83	97	82.5066	64.5906
2014	9	29	17	18	19	0.3	3.9	0.79	96.4	82.5066	61.7599
2014	9	29	17	28	19	0.3	3.9	0.8	95.4	82.5066	62.2746
2014	9	29	17	38	19	0.3	3.9	0.82	98	82.5066	63.8186
2014	9	29	17	48	19	0.3	3.9	0.77	98.8	82.5066	59.7012
2014	9	29	17	58	19	0.3	3.9	0.81	95.8	82.5066	63.3039

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	29	18	8	19	0.3	3.9	0.81	97.9	82.5066	62.7892
2014	9	29	18	18	19	0.3	3.9	0.8	96.4	82.5066	62.2746
2014	9	29	18	28	19	0.3	3.9	0.83	96.6	82.5066	64.8479
2014	9	29	18	38	19	0.3	3.9	0.78	96.3	82.5066	60.7306
2014	9	29	18	48	19	0.3	3.9	0.78	94.1	82.5066	61.2453
2014	9	29	18	58	19	0.3	3.9	0.79	95.9	82.5066	61.7599
2014	9	29	19	8	19	0.3	3.9	0.81	97.2	82.5066	62.7893
2014	9	29	19	18	19	0.3	3.9	0.83	95.7	82.5066	64.5906
2014	9	29	19	28	19	0.3	3.9	0.84	98	82.5066	65.6199
2014	9	29	19	38	19	0.3	3.9	0.79	95.5	82.5066	61.76
2014	9	29	19	48	19	0.3	3.9	0.79	96.7	82.5066	61.76
2014	9	29	19	58	19	0.3	3.9	0.82	97.3	82.5066	64.076
2014	9	29	20	8	19	0.3	3.9	0.83	96.6	82.5066	64.3333
2014	9	29	20	18	19	0.3	3.9	0.79	96.5	82.5066	61.2453
2014	9	29	20	28	19	0.3	3.9	0.81	97.5	82.5066	62.7893
2014	9	29	20	38	19	0.3	3.9	0.79	95.9	82.5066	61.76
2014	9	29	20	48	19	0.3	3.9	0.81	97.9	82.5066	63.3041
2014	9	29	20	58	19	0.3	3.9	0.79	97.6	82.5066	61.7601
2014	9	29	21	8	19	0.3	3.9	0.84	95.8	82.5066	65.3627
2014	9	29	21	18	19	0.3	3.9	0.81	97	82.5066	63.0468
2014	9	29	21	28	19	0.3	3.9	0.8	97.5	82.5066	62.5321
2014	9	29	21	38	19	0.3	3.9	0.82	95.3	82.5066	64.0761
2014	9	29	21	48	19	0.3	3.9	0.77	96.9	82.5722	60.0086
2014	9	29	21	58	19	0.3	3.9	0.79	96.4	82.5066	61.7602
2014	9	29	22	8	19	0.3	3.9	0.8	97	82.5722	62.5841
2014	9	29	22	18	19	0.3	3.9	0.79	97.6	82.5722	61.8115
2014	9	29	22	28	19	0.3	3.9	0.79	95.7	82.5722	61.8115
2014	9	29	22	38	19	0.3	3.9	0.83	95.7	82.5722	64.6446
2014	9	29	22	48	19	0.3	3.9	0.79	94.5	82.5722	61.8116
2014	9	29	22	58	19	0.3	3.9	0.81	97.4	82.5722	63.0993
2014	9	29	23	8	19	0.3	3.9	0.82	94.3	82.5722	64.3871
2014	9	29	23	18	19	0.3	3.9	0.8	95.4	82.5722	62.5843
2014	9	29	23	28	19	0.3	3.9	0.81	96.3	82.5722	62.8418
2014	9	29	23	38	19	0.3	3.9	0.82	96.2	82.5722	63.872
2014	9	29	23	48	19	0.3	3.9	0.77	96.1	82.5722	60.0088
2014	9	29	23	58	19	0.3	3.9	0.8	95.4	82.5722	62.3268
2014	9	30	0	8	19	0.3	3.9	0.84	98.1	82.5722	65.1599
2014	9	30	0	18	19	0.3	3.9	0.77	94.4	82.5722	60.524
2014	9	30	0	28	19	0.3	3.9	0.8	97.3	82.5722	62.3269
2014	9	30	0	38	19	0.3	3.9	0.78	94.6	82.5722	61.0391
2014	9	30	0	48	19	0.3	3.9	0.81	96.5	82.5722	63.3571
2014	9	30	0	58	19	0.3	3.9	0.8	95.2	82.5722	62.842
2014	9	30	1	8	19	0.3	3.9	0.81	96.1	82.5722	63.0996
2014	9	30	1	18	19	0.3	3.9	0.8	95.2	82.5722	62.5845
2014	9	30	1	28	19	0.3	3.9	0.81	94	82.5722	63.3572
2014	9	30	1	38	19	0.3	3.9	0.83	96.4	82.5722	64.645

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	1	48	19	0.3	3.9	0.82	96.2	82.5722	63.8723
2014	9	30	1	58	19	0.3	3.9	0.77	95.4	82.5722	60.2666
2014	9	30	2	8	19	0.3	3.9	0.78	95.8	82.5722	61.2969
2014	9	30	2	18	19	0.3	3.9	0.8	95.2	82.5722	62.3271
2014	9	30	2	28	19	0.3	3.9	0.8	95.7	82.5722	62.3271
2014	9	30	2	38	19	0.3	3.9	0.79	97.2	82.5722	61.5545
2014	9	30	2	48	19	0.3	3.9	0.83	96.3	82.5722	64.9026
2014	9	30	2	58	19	0.3	3.9	0.82	97.2	82.5722	63.6149
2014	9	30	3	8	19	0.3	3.9	0.83	96.1	82.5722	65.1602
2014	9	30	3	18	19	0.3	3.9	0.78	95.5	82.5722	61.297
2014	9	30	3	28	19	0.3	3.9	0.78	98	82.5722	60.7819
2014	9	30	3	38	19	0.3	3.9	0.84	95.6	82.5722	65.933
2014	9	30	3	48	19	0.3	3.9	0.8	95.2	82.5722	62.5848
2014	9	30	3	58	19	0.3	3.9	0.8	95.9	82.5722	62.8424
2014	9	30	4	8	19	0.3	3.9	0.77	97.6	82.5722	59.7518
2014	9	30	4	18	19	0.3	3.9	0.8	97.5	82.5722	62.3273
2014	9	30	4	28	19	0.3	3.9	0.83	96.1	82.5722	64.9029
2014	9	30	4	38	19	0.3	3.9	0.8	97.1	82.5722	62.0698
2014	9	30	4	48	19	0.3	3.9	0.8	95.2	82.5722	62.585
2014	9	30	4	58	19	0.3	3.9	0.77	98.3	82.5722	59.7519
2014	9	30	5	8	19	0.3	3.9	0.8	96.8	82.5722	62.585
2014	9	30	5	18	19	0.3	3.9	0.78	97	82.5722	60.5246
2014	9	30	5	28	19	0.3	3.9	0.77	98.3	82.5722	60.0095
2014	9	30	5	38	19	0.3	3.9	0.82	95.1	82.5722	63.8728
2014	9	30	5	48	19	0.3	3.9	0.78	97.5	82.5722	60.5247
2014	9	30	5	58	19	0.3	3.9	0.78	96.7	82.5722	61.0398
2014	9	30	6	8	19	0.3	3.9	0.81	97.9	82.5722	63.3578
2014	9	30	6	18	19	0.3	3.9	0.79	95.2	82.5722	62.0701
2014	9	30	6	28	19	0.3	3.9	0.78	97.5	82.5722	60.7823
2014	9	30	6	38	19	0.3	3.9	0.84	97.4	82.5722	65.4183
2014	9	30	6	48	19	0.3	3.9	0.77	97.3	82.5722	60.2672
2014	9	30	6	58	19	0.3	3.9	0.81	96.3	82.5722	63.3579
2014	9	30	7	8	19	0.3	3.9	0.8	95.9	82.5722	62.8428
2014	9	30	7	18	19	0.3	3.9	0.81	97.7	82.5722	62.8428
2014	9	30	7	28	19	0.3	3.9	0.8	94.3	82.5722	62.3277
2014	9	30	7	38	19	0.3	3.9	0.81	96.1	82.5722	63.1004
2014	9	30	7	48	19	0.3	3.9	0.79	97.1	82.5722	61.8127
2014	9	30	7	58	19	0.3	3.9	0.79	97.4	82.5722	61.8127
2014	9	30	8	8	19	0.3	3.9	0.8	96.3	82.5722	62.5853
2014	9	30	8	18	19	0.3	3.9	0.77	94.9	82.5722	60.2674
2014	9	30	8	28	19	0.3	3.9	0.81	95.6	82.5722	63.1005
2014	9	30	8	38	19	0.3	3.9	0.82	95.7	82.5722	64.3882
2014	9	30	8	48	19	0.3	3.9	0.81	97.7	82.5722	62.8428
2014	9	30	8	58	19	0.3	3.9	0.8	96.9	82.5722	62.0701
2014	9	30	9	8	19	0.3	3.9	0.81	95.1	82.5722	63.1003
2014	9	30	9	18	19	0.3	3.9	0.8	96.6	82.5722	62.0701

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	9	28	19	0.3	3.9	0.8	94.9	82.6378	62.6371
2014	9	30	9	38	19	0.3	3.9	0.8	93.8	82.5722	62.5852
2014	9	30	9	48	19	0.3	3.9	0.78	98.7	82.5722	60.7823
2014	9	30	9	58	19	0.3	3.9	0.78	96.5	82.5722	61.0398
2014	9	30	10	8	19	0.3	3.9	0.79	97.4	82.6378	61.3482
2014	9	30	10	18	19	0.3	3.9	0.75	97.8	82.6378	58.5127
2014	9	30	10	28	19	0.3	3.9	0.8	95.4	82.6378	62.3792
2014	9	30	10	38	19	0.3	3.9	0.82	96.7	82.6378	63.9257
2014	9	30	10	48	19	0.3	3.9	0.77	99.1	82.6378	59.8015
2014	9	30	10	58	19	0.3	3.9	0.78	95.6	82.6378	60.8325
2014	9	30	11	8	19	0.3	3.9	0.81	97.6	82.6378	63.4101
2014	9	30	11	18	19	0.3	3.9	0.84	97	82.6378	65.2144
2014	9	30	11	28	19	0.3	3.9	0.77	97.8	82.6378	60.0591
2014	9	30	11	38	19	0.3	3.9	0.82	96.7	82.5722	63.8725
2014	9	30	11	48	19	0.3	3.9	0.79	96.9	82.5722	61.297
2014	9	30	11	58	19	0.3	3.9	0.79	96	82.5722	61.5545
2014	9	30	12	8	19	0.3	3.9	0.78	97.7	82.5722	60.7818
2014	9	30	12	18	19	0.3	3.9	0.83	100.3	82.6378	63.9254
2014	9	30	12	28	19	0.3	3.9	0.86	97.5	82.6378	67.0185
2014	9	30	12	38	19	0.3	3.9	0.77	97.8	82.5722	60.2667
2014	9	30	12	48	19	0.3	3.9	0.79	95	82.5722	61.8119
2014	9	30	12	58	19	0.3	3.9	0.8	94.2	82.5722	62.5845
2014	9	30	13	8	19	0.3	3.9	0.8	95.2	82.5722	62.5845
2014	9	30	13	18	19	0.3	3.9	0.82	95.3	82.5722	63.8722
2014	9	30	13	28	19	0.3	3.9	0.77	96.6	82.5722	60.2665
2014	9	30	13	38	19	0.3	3.9	0.79	98.4	82.5722	61.2967
2014	9	30	13	48	19	0.3	3.9	0.77	96.6	82.5722	60.0089
2014	9	30	13	58	19	0.3	3.9	0.79	97.6	82.5722	61.5542
2014	9	30	14	8	19	0.3	3.9	0.73	94.9	82.5722	56.9183
2014	9	30	14	18	19	0.3	3.9	0.79	95.7	82.5066	61.5031
2014	9	30	14	28	19	0.3	3.9	0.77	96.6	82.5722	59.7513
2014	9	30	14	38	19	0.3	3.9	0.77	97.3	82.5066	59.959
2014	9	30	14	48	19	0.3	3.9	0.77	94.6	82.5066	60.2164
2014	9	30	14	58	19	0.3	3.9	0.76	97.9	82.5066	59.187
2014	9	30	15	8	19	0.3	3.9	0.79	97.4	82.5066	61.7603
2014	9	30	15	18	19	0.3	3.9	0.79	96.7	82.5066	61.2457
2014	9	30	15	28	19	0.3	3.9	0.8	97.3	82.5066	62.275
2014	9	30	15	38	19	0.3	3.9	0.77	96.6	82.5066	60.2163
2014	9	30	15	48	19	0.3	3.9	0.81	96.1	82.5066	62.7897
2014	9	30	15	58	19	0.3	3.9	0.76	96.4	82.4409	59.1378
2014	9	30	16	8	19	0.3	3.9	0.8	97.5	82.4409	62.4804
2014	9	30	16	18	19	0.3	3.9	0.75	98.1	82.4409	58.1093
2014	9	30	16	28	19	0.3	3.9	0.8	97.6	82.4409	61.9662
2014	9	30	16	38	19	0.3	3.9	0.83	96.1	82.4409	65.0516
2014	9	30	16	48	19	0.3	3.9	0.76	96.4	82.4409	59.1378
2014	9	30	16	58	19	0.3	3.6	0.78	98	82.3753	60.6301

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	9	30	17	8	19	0.3	3.9	0.82	98.1	82.4409	63.2518
2014	9	30	17	18	19	0.3	3.9	0.8	97.5	82.4409	62.2233
2014	9	30	17	28	19	0.3	3.6	0.81	97.4	82.3753	63.1992
2014	9	30	17	38	19	0.3	3.9	0.76	96.7	82.4409	58.8807
2014	9	30	17	48	19	0.3	3.9	0.82	98.1	82.4409	63.2517
2014	9	30	17	58	19	0.3	3.9	0.82	97.4	82.4409	63.766
2014	9	30	18	8	19	0.3	3.9	0.78	96.5	82.4409	60.6805
2014	9	30	18	18	19	0.3	3.9	0.81	97.2	82.4409	62.9946
2014	9	30	18	28	19	0.3	3.9	0.81	96.3	82.4409	62.7375
2014	9	30	18	38	19	0.3	3.9	0.84	96	82.4409	65.5658
2014	9	30	18	48	19	0.3	3.9	0.82	98.3	82.4409	63.5089
2014	9	30	18	58	19	0.3	3.9	0.8	94.2	82.4409	62.4804
2014	9	30	19	8	19	0.3	3.9	0.79	94.8	82.4409	61.709
2014	9	30	19	18	19	0.3	3.9	0.79	96	82.4409	61.1948
2014	9	30	19	28	19	0.3	3.9	0.8	98.5	82.4409	61.709
2014	9	30	19	38	19	0.3	3.9	0.82	97.8	82.4409	63.5089
2014	9	30	19	48	19	0.3	3.9	0.8	95.9	82.4409	62.7375
2014	9	30	19	58	19	0.3	3.9	0.78	98.5	82.4409	60.4234
2014	9	30	20	8	19	0.3	3.9	0.82	96.9	82.4409	64.0231
2014	9	30	20	18	19	0.3	3.9	0.76	96.2	82.4409	59.1378
2014	9	30	20	28	19	0.3	3.9	0.82	97.1	82.4409	64.0231
2014	9	30	20	38	19	0.3	3.9	0.82	95	82.4409	64.0232
2014	9	30	20	48	19	0.3	3.9	0.8	96.3	82.4409	62.4804
2014	9	30	20	58	19	0.3	3.9	0.8	97.1	82.4409	61.9662
2014	9	30	21	8	19	0.3	3.9	0.79	95	82.4409	61.452
2014	9	30	21	18	19	0.3	3.9	0.82	97.8	82.4409	63.7661
2014	9	30	21	28	19	0.3	3.9	0.8	97.7	82.4409	62.4805
2014	9	30	21	38	19	0.3	3.9	0.81	93.5	82.4409	63.2519
2014	9	30	21	48	19	0.3	3.9	0.8	97.5	82.4409	62.2234
2014	9	30	21	58	19	0.3	3.9	0.81	96.3	82.4409	62.7377
2014	9	30	22	8	19	0.3	3.9	0.82	94.8	82.4409	64.2804
2014	9	30	22	18	19	0.3	3.9	0.81	96.3	82.4409	62.7377
2014	9	30	22	28	19	0.3	3.9	0.83	95	82.4409	65.0518
2014	9	30	22	38	19	0.3	3.9	0.83	95.2	82.4409	64.5376
2014	9	30	22	48	19	0.3	3.9	0.77	97.8	82.4409	59.9094
2014	9	30	22	58	19	0.3	3.9	0.82	98.1	82.4409	63.5091
2014	9	30	23	8	19	0.3	3.9	0.75	96.5	82.4409	58.3667
2014	9	30	23	18	19	0.3	3.9	0.82	96.4	82.4409	64.0234
2014	9	30	23	28	19	0.3	3.9	0.75	96.8	82.4409	58.3667
2014	9	30	23	38	19	0.3	3.9	0.79	97.6	82.4409	61.4522
2014	9	30	23	48	19	0.3	3.9	0.79	94.3	82.4409	61.4522
2014	9	30	23	58	19	0.3	3.9	0.77	97.1	82.4409	59.9095

Alabama Gates Release
Station 0087

Date	Flow (cfs)
9/1/2014	0
9/2/2014	0
9/3/2014	0
9/4/2014	0
9/5/2014	0
9/6/2014	0
9/7/2014	0
9/8/2014	0
9/9/2014	0
9/10/2014	0
9/11/2014	0
9/12/2014	0
9/13/2014	0
9/14/2014	0
9/15/2014	0
9/16/2014	0
9/17/2014	0
9/18/2014	0
9/19/2014	0
9/20/2014	0
9/21/2014	0
9/22/2014	0
9/23/2014	0
9/24/2014	0
9/25/2014	0
9/26/2014	0
9/27/2014	0
9/28/2014	0
9/29/2014	0
9/30/2014	0

Pumpback Station Discharge

REPORT_DATE	READING
9/1/2014	44
9/2/2014	43
9/3/2014	42
9/4/2014	37
9/5/2014	40
9/6/2014	37
9/7/2014	35
9/8/2014	35
9/9/2014	35
9/10/2014	35
9/11/2014	35
9/12/2014	35
9/13/2014	36
9/14/2014	28
9/15/2014	27
9/16/2014	28
9/17/2014	29
9/18/2014	35
9/19/2014	34
9/20/2014	34
9/21/2014	33
9/22/2014	35
9/23/2014	37
9/24/2014	38
9/25/2014	39
9/26/2014	36
9/27/2014	35
9/28/2014	34
9/29/2014	35
9/30/2014	36

Langemann Gate to Delta

REPORT_DATE	READING
9/1/2014	8
9/2/2014	7
9/3/2014	7
9/4/2014	8
9/5/2014	8
9/6/2014	8
9/7/2014	8
9/8/2014	8
9/9/2014	8
9/10/2014	8
9/11/2014	8
9/12/2014	7
9/13/2014	8
9/14/2014	8
9/15/2014	8
9/16/2014	15
9/17/2014	14
9/18/2014	8
9/19/2014	8
9/20/2014	8
9/21/2014	8
9/22/2014	8
9/23/2014	8
9/24/2014	8
9/25/2014	8
9/26/2014	8
9/27/2014	8
9/28/2014	7
9/29/2014	7
9/30/2014	8

Pumpback Station Weir to Delta

REPORT_DATE	READING
9/1/2014	0
9/2/2014	0
9/3/2014	0
9/4/2014	0
9/5/2014	1
9/6/2014	0
9/7/2014	0
9/8/2014	0
9/9/2014	0
9/10/2014	0
9/11/2014	0
9/12/2014	0
9/13/2014	0
9/14/2014	4
9/15/2014	12
9/16/2014	0
9/17/2014	0
9/18/2014	0
9/19/2014	0
9/20/2014	0
9/21/2014	0
9/22/2014	0
9/23/2014	0
9/24/2014	0
9/25/2014	0
9/26/2014	0
9/27/2014	0
9/28/2014	0
9/29/2014	0
9/30/2014	0

Pumpback Station Discharge (0364)

9/1/14 0:00 == 46.4
9/1/14 0:05 == 46.4
9/1/14 0:10 == 46.4
9/1/14 0:15 == 46.3
9/1/14 0:20 == 46.3
9/1/14 0:25 == 46.5
9/1/14 0:30 == 46.5
9/1/14 0:35 == 46.3
9/1/14 0:40 == 46.3
9/1/14 0:45 == 46.3
9/1/14 0:50 == 46.4
9/1/14 0:55 == 46.4
9/1/14 1:00 == 46.4
9/1/14 1:05 == 46.4
9/1/14 1:10 == 46.4
9/1/14 1:15 == 46.4
9/1/14 1:20 == 46.4
9/1/14 1:25 == 46.4
9/1/14 1:30 == 46.3
9/1/14 1:35 == 46.4
9/1/14 1:40 == 46.4
9/1/14 1:45 == 46.4
9/1/14 1:50 == 46.5
9/1/14 1:55 == 46.4
9/1/14 2:00 == 46.4
9/1/14 2:05 == 46.4
9/1/14 2:10 == 46.4
9/1/14 2:15 == 46.3
9/1/14 2:20 == 42.6
9/1/14 2:25 == 31.7
9/1/14 2:30 == 31.9
9/1/14 2:35 == 31.9
9/1/14 2:40 == 32.1
9/1/14 2:45 == 32.1
9/1/14 2:50 == 32.4
9/1/14 2:55 == 32.9
9/1/14 3:00 == 32.9
9/1/14 3:05 == 32
9/1/14 3:10 == 45.8
9/1/14 3:15 == 46.4
9/1/14 3:20 == 46.5
9/1/14 3:25 == 46.3
9/1/14 3:30 == 46.5
9/1/14 3:35 == 46.4
9/1/14 3:40 == 46.4
9/1/14 3:45 == 46.5
9/1/14 3:50 == 46.4
9/1/14 3:55 == 46.4
9/1/14 4:00 == 46.4
9/1/14 4:05 == 46.4
9/1/14 4:10 == 46.5
9/1/14 4:15 == 46.4
9/1/14 4:20 == 46.5
9/1/14 4:25 == 46.4
9/1/14 4:30 == 46.4
9/1/14 4:35 == 46.4
9/1/14 4:40 == 46.4
9/1/14 4:45 == 46.4
9/1/14 4:50 == 42.5
9/1/14 4:55 == 32.1
9/1/14 5:00 == 32.2
9/1/14 5:05 == 32.4
9/1/14 5:10 == 32.7
9/1/14 5:15 == 32.8
9/1/14 5:20 == 32.9
9/1/14 5:25 == 33.2
9/1/14 5:30 == 33
9/1/14 5:35 == 32.4
9/1/14 5:40 == 45.8
9/1/14 5:45 == 46.5
9/1/14 5:50 == 46.4
9/1/14 5:55 == 46.4
9/1/14 6:00 == 46.4
9/1/14 6:05 == 46.4
9/1/14 6:10 == 46.5
9/1/14 6:15 == 46.4
9/1/14 6:20 == 46.5
9/1/14 6:25 == 46.5
9/1/14 6:30 == 46.4
9/1/14 6:35 == 46.4
9/1/14 6:40 == 46.5
9/1/14 6:45 == 46.4
9/1/14 6:50 == 46.4
9/1/14 6:55 == 46.5
9/1/14 7:00 == 46.4
9/1/14 7:05 == 42.6
9/1/14 7:10 == 32
9/1/14 7:15 == 32.2
9/1/14 7:20 == 32.2
9/1/14 7:25 == 32.2
9/1/14 7:30 == 32.2
9/1/14 7:35 == 32.2
9/1/14 7:40 == 32.3
9/1/14 7:45 == 32.2
9/1/14 7:50 == 32.1
9/1/14 7:55 == 32.2
9/1/14 8:00 == 32.2
9/1/14 8:05 == 32.2
9/1/14 8:10 == 32.2
9/1/14 8:15 == 32.1
9/1/14 8:20 == 32.2
9/1/14 8:25 == 32.3
9/1/14 8:30 == 32.2
9/1/14 8:35 == 32.2
9/1/14 8:40 == 32.3
9/1/14 8:45 == 32.4
9/1/14 8:50 == 32.3
9/1/14 8:55 == 32.3
9/1/14 9:00 == 32.3
9/1/14 9:05 == 32.3
9/1/14 9:10 == 38.2
9/1/14 9:15 == 46.6
9/1/14 9:20 == 46.5
9/1/14 9:25 == 46.5
9/1/14 9:30 == 46.6
9/1/14 9:35 == 46.6
9/1/14 9:40 == 46.5
9/1/14 9:45 == 46.5
9/1/14 9:50 == 46.5
9/1/14 9:55 == 46.6
9/1/14 10:00 == 46.6
9/1/14 10:05 == 46.5
9/1/14 10:10 == 46.4
9/1/14 10:15 == 46.5
9/1/14 10:20 == 46.5
9/1/14 10:25 == 46.6
9/1/14 10:30 == 46.6
9/1/14 10:35 == 46.5
9/1/14 10:40 == 46.4
9/1/14 10:45 == 46.5
9/1/14 10:50 == 46.4
9/1/14 10:55 == 46.4
9/1/14 11:00 == 46.5
9/1/14 11:05 == 46.4
9/1/14 11:10 == 46.4
9/1/14 11:15 == 46.5
9/1/14 11:20 == 46.5
9/1/14 11:25 == 46.5
9/1/14 11:30 == 46.5
9/1/14 11:35 == 46.5
9/1/14 11:40 == 46.6
9/1/14 11:45 == 46.5
9/1/14 11:50 == 46.4
9/1/14 11:55 == 46.5
9/1/14 12:00 == 46.4
9/1/14 12:05 == 46.4
9/1/14 12:10 == 46.4
9/1/14 12:15 == 46.4
9/1/14 12:20 == 46.5
9/1/14 12:25 == 46.5
9/1/14 12:30 == 46.3
9/1/14 12:35 == 46.4
9/1/14 12:40 == 46.4
9/1/14 12:45 == 46.4
9/1/14 12:50 == 46.4
9/1/14 12:55 == 46.3
9/1/14 13:00 == 46.3
9/1/14 13:05 == 46.5
9/1/14 13:10 == 46.4
9/1/14 13:15 == 46.3
9/1/14 13:20 == 46.3
9/1/14 13:25 == 46.3
9/1/14 13:30 == 46.4
9/1/14 13:35 == 46.4
9/1/14 13:40 == 46.4
9/1/14 13:45 == 46.4
9/1/14 13:50 == 46.4
9/1/14 13:55 == 46.4
9/1/14 14:00 == 46.4
9/1/14 14:05 == 46.3
9/1/14 14:10 == 46.3
9/1/14 14:15 == 46.4
9/1/14 14:20 == 46.4
9/1/14 14:25 == 46.4
9/1/14 14:30 == 46.4
9/1/14 14:35 == 46.4
9/1/14 14:40 == 46.4
9/1/14 14:45 == 46.3
9/1/14 14:50 == 46.2
9/1/14 14:55 == 46.5
9/1/14 15:00 == 46.4
9/1/14 15:05 == 46.3
9/1/14 15:10 == 46.3
9/1/14 15:15 == 46.5
9/1/14 15:20 == 46.4
9/1/14 15:25 == 46.4
9/1/14 15:30 == 46.2
9/1/14 15:35 == 46.3
9/1/14 15:40 == 46.4
9/1/14 15:45 == 46.4
9/1/14 15:50 == 46.3
9/1/14 15:55 == 46.3
9/1/14 16:00 == 46.2
9/1/14 16:05 == 46.4
9/1/14 16:10 == 46.3
9/1/14 16:15 == 46.3
9/1/14 16:20 == 46.5
9/1/14 16:25 == 46.2
9/1/14 16:30 == 46.4
9/1/14 16:35 == 46.2
9/1/14 16:40 == 46.3
9/1/14 16:45 == 46.4
9/1/14 16:50 == 46.4
9/1/14 16:55 == 46.3
9/1/14 17:00 == 46.3
9/1/14 17:05 == 46.4
9/1/14 17:10 == 46.5
9/1/14 17:15 == 46.4
9/1/14 17:20 == 46.4
9/1/14 17:25 == 46.3
9/1/14 17:30 == 46.3
9/1/14 17:35 == 46.4
9/1/14 17:40 == 46.4
9/1/14 17:45 == 46.4
9/1/14 17:50 == 46.3
9/1/14 17:55 == 46.3
9/1/14 18:00 == 46.3
9/1/14 18:05 == 46.4
9/1/14 18:10 == 46.3
9/1/14 18:15 == 46.3

Pumpback Station Discharge (0364)

9/1/14 18:20 == 46.3
9/1/14 18:25 == 46.4
9/1/14 18:30 == 46.4
9/1/14 18:35 == 46.3
9/1/14 18:40 == 46.3
9/1/14 18:45 == 46.4
9/1/14 18:50 == 46.3
9/1/14 18:55 == 46.4
9/1/14 19:00 == 46.3
9/1/14 19:05 == 46.4
9/1/14 19:10 == 46.4
9/1/14 19:15 == 46.3
9/1/14 19:20 == 46.4
9/1/14 19:25 == 46.3
9/1/14 19:30 == 46.3
9/1/14 19:35 == 46.4
9/1/14 19:40 == 46.4
9/1/14 19:45 == 46.3
9/1/14 19:50 == 46.3
9/1/14 19:55 == 46.3
9/1/14 20:00 == 46.3
9/1/14 20:05 == 46.4
9/1/14 20:10 == 46.3
9/1/14 20:15 == 46.4
9/1/14 20:20 == 46.3
9/1/14 20:25 == 46.3
9/1/14 20:30 == 46.4
9/1/14 20:35 == 46.3
9/1/14 20:40 == 46.3
9/1/14 20:45 == 46.3
9/1/14 20:50 == 46.5
9/1/14 20:55 == 46.3
9/1/14 21:00 == 46.4
9/1/14 21:05 == 46.3
9/1/14 21:10 == 46.4
9/1/14 21:15 == 46.4
9/1/14 21:20 == 46.3
9/1/14 21:25 == 46.3
9/1/14 21:30 == 46.3
9/1/14 21:35 == 46.4
9/1/14 21:40 == 46.4
9/1/14 21:45 == 46.4
9/1/14 21:50 == 46.4
9/1/14 21:55 == 46.3
9/1/14 22:00 == 46.4
9/1/14 22:05 == 46.3
9/1/14 22:10 == 46.2
9/1/14 22:15 == 46.3
9/1/14 22:20 == 41.4
9/1/14 22:25 == 32
9/1/14 22:30 == 32.2
9/1/14 22:35 == 32.4
9/1/14 22:40 == 32.6
9/1/14 22:45 == 32.7
9/1/14 22:50 == 32.9
9/1/14 22:55 == 33.2
9/1/14 23:00 == 33.1
9/1/14 23:05 == 33.2
9/1/14 23:10 == 46
9/1/14 23:15 == 46.4
9/1/14 23:20 == 46.4
9/1/14 23:25 == 46.4
9/1/14 23:30 == 46.3
9/1/14 23:35 == 46.5
9/1/14 23:40 == 46.5
9/1/14 23:45 == 46.4
9/1/14 23:50 == 46.4
9/1/14 23:55 == 46.3
9/2/14 0:00 == 46.3
9/2/14 0:05 == 46.4
9/2/14 0:10 == 46.4
9/2/14 0:15 == 46.3
9/2/14 0:20 == 46.3
9/2/14 0:25 == 46.2
9/2/14 0:30 == 46.4
9/2/14 0:35 == 46.3
9/2/14 0:40 == 46.3
9/2/14 0:45 == 46.4
9/2/14 0:50 == 46.3
9/2/14 0:55 == 46.3
9/2/14 1:00 == 46.4
9/2/14 1:05 == 46.4
9/2/14 1:10 == 46.4
9/2/14 1:15 == 46.3
9/2/14 1:20 == 46.3
9/2/14 1:25 == 46.2
9/2/14 1:30 == 46.3
9/2/14 1:35 == 46.3
9/2/14 1:40 == 46.5
9/2/14 1:45 == 46.3
9/2/14 1:50 == 41.2
9/2/14 1:55 == 32.2
9/2/14 2:00 == 32.2
9/2/14 2:05 == 32.4
9/2/14 2:10 == 32.8
9/2/14 2:15 == 32.9
9/2/14 2:20 == 33
9/2/14 2:25 == 33.2
9/2/14 2:30 == 33.2
9/2/14 2:35 == 33.3
9/2/14 2:40 == 46.1
9/2/14 2:45 == 46.4
9/2/14 2:50 == 46.4
9/2/14 2:55 == 46.4
9/2/14 3:00 == 46.4
9/2/14 3:05 == 46.4
9/2/14 3:10 == 46.3
9/2/14 3:15 == 46.3
9/2/14 3:20 == 46.5
9/2/14 3:25 == 46.4
9/2/14 3:30 == 46.5
9/2/14 3:35 == 46.3
9/2/14 3:40 == 46.3
9/2/14 3:45 == 46.4
9/2/14 3:50 == 46.4
9/2/14 3:55 == 46.4
9/2/14 4:00 == 46.3
9/2/14 4:05 == 46.4
9/2/14 4:10 == 46.6
9/2/14 4:15 == 46.5
9/2/14 4:20 == 46.5
9/2/14 4:25 == 46.5
9/2/14 4:30 == 46.5
9/2/14 4:35 == 40.9
9/2/14 4:40 == 31.5
9/2/14 4:45 == 31.6
9/2/14 4:50 == 31.7
9/2/14 4:55 == 32.1
9/2/14 5:00 == 32.1
9/2/14 5:05 == 32.2
9/2/14 5:10 == 32.3
9/2/14 5:15 == 32.5
9/2/14 5:20 == 32.5
9/2/14 5:25 == 32.6
9/2/14 5:30 == 32.7
9/2/14 5:35 == 32.8
9/2/14 5:40 == 33
9/2/14 5:45 == 33
9/2/14 5:50 == 33.1
9/2/14 5:55 == 33.1
9/2/14 6:00 == 33.2
9/2/14 6:05 == 33.5
9/2/14 6:10 == 46.4
9/2/14 6:15 == 46.7
9/2/14 6:20 == 46.7
9/2/14 6:25 == 46.6
9/2/14 6:30 == 46.7
9/2/14 6:35 == 46.4
9/2/14 6:40 == 46.6
9/2/14 6:45 == 46.5
9/2/14 6:50 == 46.5
9/2/14 6:55 == 46.5
9/2/14 7:00 == 46.7
9/2/14 7:05 == 46.3
9/2/14 7:10 == 46.3
9/2/14 7:15 == 46.4
9/2/14 7:20 == 46.4
9/2/14 7:25 == 46.4
9/2/14 7:30 == 46.7
9/2/14 7:35 == 46.3
9/2/14 7:40 == 46.5
9/2/14 7:45 == 46.6
9/2/14 7:50 == 46.4
9/2/14 7:55 == 46.4
9/2/14 8:00 == 46.5
9/2/14 8:05 == 41.1
9/2/14 8:10 == 32.2
9/2/14 8:15 == 32.3
9/2/14 8:20 == 32.5
9/2/14 8:25 == 32.7
9/2/14 8:30 == 32.7
9/2/14 8:35 == 33
9/2/14 8:40 == 33.2
9/2/14 8:45 == 33.2
9/2/14 8:50 == 33.7
9/2/14 8:55 == 46.6
9/2/14 9:00 == 46.5
9/2/14 9:05 == 46.6
9/2/14 9:10 == 46.6
9/2/14 9:15 == 46.3
9/2/14 9:20 == 46.5
9/2/14 9:25 == 46.4
9/2/14 9:30 == 46.3
9/2/14 9:35 == 46.3
9/2/14 9:40 == 46.4
9/2/14 9:45 == 46.4
9/2/14 9:50 == 46.6
9/2/14 9:55 == 46.5
9/2/14 10:00 == 46.6
9/2/14 10:05 == 46.8
9/2/14 10:10 == 46.4
9/2/14 10:15 == 46.4
9/2/14 10:20 == 46.4
9/2/14 10:25 == 46.3
9/2/14 10:30 == 46.5
9/2/14 10:35 == 46.4
9/2/14 10:40 == 46.2
9/2/14 10:45 == 46.5
9/2/14 10:50 == 46.4
9/2/14 10:55 == 46.7
9/2/14 11:00 == 46.5
9/2/14 11:05 == 46.4
9/2/14 11:10 == 46.5
9/2/14 11:15 == 46.3
9/2/14 11:20 == 46.4
9/2/14 11:25 == 46.3
9/2/14 11:30 == 46.4
9/2/14 11:35 == 46.6
9/2/14 11:40 == 46.6
9/2/14 11:45 == 46.5
9/2/14 11:50 == 46.7
9/2/14 11:55 == 47.5
9/2/14 12:00 == 47.8
9/2/14 12:05 == 47.9
9/2/14 12:10 == 47.9
9/2/14 12:15 == 47.9
9/2/14 12:20 == 47.7
9/2/14 12:25 == 47.7
9/2/14 12:30 == 47.9
9/2/14 12:35 == 47.8

Pumpback Station Discharge (0364)

9/2/14 12:40 == 47.8
9/2/14 12:45 == 47.8
9/2/14 12:50 == 47.8
9/2/14 12:55 == 47.6
9/2/14 13:00 == 47.7
9/2/14 13:05 == 41.8
9/2/14 13:10 == 32.6
9/2/14 13:15 == 32.8
9/2/14 13:20 == 33.1
9/2/14 13:25 == 33.1
9/2/14 13:30 == 33.4
9/2/14 13:35 == 33.5
9/2/14 13:40 == 33.8
9/2/14 13:45 == 33.9
9/2/14 13:50 == 31.5
9/2/14 13:55 == 43.4
9/2/14 14:00 == 47.9
9/2/14 14:05 == 48
9/2/14 14:10 == 48
9/2/14 14:15 == 48.1
9/2/14 14:20 == 48
9/2/14 14:25 == 48.1
9/2/14 14:30 == 47.7
9/2/14 14:35 == 48.2
9/2/14 14:40 == 48
9/2/14 14:45 == 47.7
9/2/14 14:50 == 48
9/2/14 14:55 == 48
9/2/14 15:00 == 48
9/2/14 15:05 == 48.1
9/2/14 15:10 == 48
9/2/14 15:15 == 48
9/2/14 15:20 == 47.9
9/2/14 15:25 == 48
9/2/14 15:30 == 48
9/2/14 15:35 == 48
9/2/14 15:40 == 48
9/2/14 15:45 == 48
9/2/14 15:50 == 41.8
9/2/14 15:55 == 33.1
9/2/14 16:00 == 33
9/2/14 16:05 == 33.4
9/2/14 16:10 == 33.7
9/2/14 16:15 == 33.6
9/2/14 16:20 == 33.9
9/2/14 16:25 == 34
9/2/14 16:30 == 34
9/2/14 16:35 == 35.3
9/2/14 16:40 == 47.9
9/2/14 16:45 == 48
9/2/14 16:50 == 47.9
9/2/14 16:55 == 48.1
9/2/14 17:00 == 48.1
9/2/14 17:05 == 48
9/2/14 17:10 == 47.9
9/2/14 17:15 == 48
9/2/14 17:20 == 47.9
9/2/14 17:25 == 48
9/2/14 17:30 == 48.1
9/2/14 17:35 == #
9/2/14 17:40 == 48
9/2/14 17:45 == 48
9/2/14 17:50 == 48.1
9/2/14 17:55 == 48
9/2/14 18:00 == 48.1
9/2/14 18:05 == 41.2
9/2/14 18:10 == 33
9/2/14 18:15 == 33.2
9/2/14 18:20 == 33.4
9/2/14 18:25 == 33.7
9/2/14 18:30 == 33.5
9/2/14 18:35 == 33.7
9/2/14 18:40 == 33.9
9/2/14 18:45 == 33.9
9/2/14 18:50 == 35
9/2/14 18:55 == 48
9/2/14 19:00 == 48
9/2/14 19:05 == 48.1
9/2/14 19:10 == 48
9/2/14 19:15 == 47.9
9/2/14 19:20 == 48
9/2/14 19:25 == 48
9/2/14 19:30 == 48.1
9/2/14 19:35 == 48
9/2/14 19:40 == 48
9/2/14 19:45 == 48
9/2/14 19:50 == 47.9
9/2/14 19:55 == 48.1
9/2/14 20:00 == 48
9/2/14 20:05 == 41.2
9/2/14 20:10 == 32.9
9/2/14 20:15 == 33.1
9/2/14 20:20 == 33.2
9/2/14 20:25 == 33.4
9/2/14 20:30 == 33.4
9/2/14 20:35 == 33.5
9/2/14 20:40 == 33.8
9/2/14 20:45 == 33.8
9/2/14 20:50 == 33.9
9/2/14 20:55 == 34
9/2/14 21:00 == 34
9/2/14 21:05 == 35.1
9/2/14 21:10 == 47.7
9/2/14 21:15 == 48
9/2/14 21:20 == 48
9/2/14 21:25 == 48
9/2/14 21:30 == 48
9/2/14 21:35 == 47.8
9/2/14 21:40 == 48
9/2/14 21:45 == 47.9
9/2/14 21:50 == 48
9/2/14 21:55 == 48.1
9/2/14 22:00 == 47.9
9/2/14 22:05 == 48
9/2/14 22:10 == 48
9/2/14 22:15 == 48.1
9/2/14 22:20 == 41.1
9/2/14 22:25 == 33
9/2/14 22:30 == 33
9/2/14 22:35 == 33.2
9/2/14 22:40 == 33.5
9/2/14 22:45 == 33.5
9/2/14 22:50 == 33.6
9/2/14 22:55 == 33.8
9/2/14 23:00 == 33.8
9/2/14 23:05 == 34
9/2/14 23:10 == 34.2
9/2/14 23:15 == 34.1
9/2/14 23:20 == 34.1
9/2/14 23:25 == 34.1
9/2/14 23:30 == 34.1
9/2/14 23:35 == 34.2
9/2/14 23:40 == 34.2
9/2/14 23:45 == 34.1
9/2/14 23:50 == 35.2
9/2/14 23:55 == 47.8
9/3/14 0:00 == 48
9/3/14 0:05 == 48
9/3/14 0:10 == 48
9/3/14 0:15 == 47.9
9/3/14 0:20 == 48.1
9/3/14 0:25 == 48.1
9/3/14 0:30 == 48.1
9/3/14 0:35 == 48
9/3/14 0:40 == 48.1
9/3/14 0:45 == 48
9/3/14 0:50 == 40.9
9/3/14 0:55 == 33.1
9/3/14 1:00 == 33.1
9/3/14 1:05 == 33.3
9/3/14 1:10 == 33.4
9/3/14 1:15 == 33.5
9/3/14 1:20 == 33.6
9/3/14 1:25 == 33.7
9/3/14 1:30 == 33.7
9/3/14 1:35 == 33.8
9/3/14 1:40 == 33.9
9/3/14 1:45 == 34
9/3/14 1:50 == 35.1
9/3/14 1:55 == 47.9
9/3/14 2:00 == 47.9
9/3/14 2:05 == 48.1
9/3/14 2:10 == 47.9
9/3/14 2:15 == 48
9/3/14 2:20 == 47.9
9/3/14 2:25 == 48
9/3/14 2:30 == 47.9
9/3/14 2:35 == 47.8
9/3/14 2:40 == 47.9
9/3/14 2:45 == 48
9/3/14 2:50 == 40.8
9/3/14 2:55 == 33
9/3/14 3:00 == 33
9/3/14 3:05 == 33.2
9/3/14 3:10 == 33.4
9/3/14 3:15 == 33.4
9/3/14 3:20 == 33.4
9/3/14 3:25 == 33.7
9/3/14 3:30 == 33.7
9/3/14 3:35 == 33.8
9/3/14 3:40 == 33.9
9/3/14 3:45 == 33.9
9/3/14 3:50 == 33.9
9/3/14 3:55 == 33.9
9/3/14 4:00 == 34.1
9/3/14 4:05 == 35.5
9/3/14 4:10 == 47.9
9/3/14 4:15 == 48.1
9/3/14 4:20 == 48
9/3/14 4:25 == 48
9/3/14 4:30 == 48.2
9/3/14 4:35 == 48
9/3/14 4:40 == 47.9
9/3/14 4:45 == 48.1
9/3/14 4:50 == 47.9
9/3/14 4:55 == 48.1
9/3/14 5:00 == 48.1
9/3/14 5:05 == 41
9/3/14 5:10 == 32.9
9/3/14 5:15 == 33
9/3/14 5:20 == 33.1
9/3/14 5:25 == 33.3
9/3/14 5:30 == 33.4
9/3/14 5:35 == 33.4
9/3/14 5:40 == 33.6
9/3/14 5:45 == 33.6
9/3/14 5:50 == 33.7
9/3/14 5:55 == 33.9
9/3/14 6:00 == 33.9
9/3/14 6:05 == 34
9/3/14 6:10 == 34
9/3/14 6:15 == 34
9/3/14 6:20 == 31.2
9/3/14 6:25 == 33.9
9/3/14 6:30 == 48
9/3/14 6:35 == 48
9/3/14 6:40 == 48.1
9/3/14 6:45 == 48
9/3/14 6:50 == 48
9/3/14 6:55 == 48

Pumpback Station Discharge (0364)

9/3/14 7:00 == 48
9/3/14 7:05 == 47.9
9/3/14 7:10 == 48
9/3/14 7:15 == 48
9/3/14 7:20 == 48
9/3/14 7:25 == 47.9
9/3/14 7:30 == 47.9
9/3/14 7:35 == 40.7
9/3/14 7:40 == 33.1
9/3/14 7:45 == 33.1
9/3/14 7:50 == 33.1
9/3/14 7:55 == 33.3
9/3/14 8:00 == 33.5
9/3/14 8:05 == 33.6
9/3/14 8:10 == 34.2
9/3/14 8:15 == 34.1
9/3/14 8:20 == 33.8
9/3/14 8:25 == 34.1
9/3/14 8:30 == 34
9/3/14 8:35 == 36.1
9/3/14 8:40 == 47.8
9/3/14 8:45 == 48
9/3/14 8:50 == 47.9
9/3/14 8:55 == 48
9/3/14 9:00 == 48
9/3/14 9:05 == 47.9
9/3/14 9:10 == 48
9/3/14 9:15 == 48
9/3/14 9:20 == 48.1
9/3/14 9:25 == 48
9/3/14 9:30 == 48
9/3/14 9:35 == 47.9
9/3/14 9:40 == 47.9
9/3/14 9:45 == 47.9
9/3/14 9:50 == 48
9/3/14 9:55 == 48
9/3/14 10:00 == 48
9/3/14 10:05 == 48
9/3/14 10:10 == 48.1
9/3/14 10:15 == 48.1
9/3/14 10:20 == 48
9/3/14 10:25 == 47.9
9/3/14 10:30 == 48.1
9/3/14 10:35 == 40.6
9/3/14 10:40 == 32.8
9/3/14 10:45 == 33.1
9/3/14 10:50 == 33.3
9/3/14 10:55 == 33.6
9/3/14 11:00 == 33.6
9/3/14 11:05 == 33.8
9/3/14 11:10 == 34
9/3/14 11:15 == 34.1
9/3/14 11:20 == 36.1
9/3/14 11:25 == 47.9
9/3/14 11:30 == 48.1
9/3/14 11:35 == 48
9/3/14 11:40 == 48.1
9/3/14 11:45 == 48
9/3/14 11:50 == 48
9/3/14 11:55 == 48.1
9/3/14 12:00 == 48.1
9/3/14 12:05 == 47.9
9/3/14 12:10 == 48
9/3/14 12:15 == 47.9
9/3/14 12:20 == 47.9
9/3/14 12:25 == 47.8
9/3/14 12:30 == 47.9
9/3/14 12:35 == 48
9/3/14 12:40 == 47.7
9/3/14 12:45 == 48.1
9/3/14 12:50 == 40.4
9/3/14 12:55 == 33.6
9/3/14 13:00 == 33.7
9/3/14 13:05 == 33.8
9/3/14 13:10 == 34
9/3/14 13:15 == 34.1
9/3/14 13:20 == 34.3
9/3/14 13:25 == 34.4
9/3/14 13:30 == 34.4
9/3/14 13:35 == 34.6
9/3/14 13:40 == 34.6
9/3/14 13:45 == 34.1
9/3/14 13:50 == 36.8
9/3/14 13:55 == 48.1
9/3/14 14:00 == 47.9
9/3/14 14:05 == 48.1
9/3/14 14:10 == 48
9/3/14 14:15 == 48.1
9/3/14 14:20 == 48
9/3/14 14:25 == 48
9/3/14 14:30 == 48
9/3/14 14:35 == 48
9/3/14 14:40 == 48
9/3/14 14:45 == 48
9/3/14 14:50 == 48
9/3/14 14:55 == 48
9/3/14 15:00 == 48.1
9/3/14 15:05 == 48
9/3/14 15:10 == 48
9/3/14 15:15 == 48.2
9/3/14 15:20 == 48.1
9/3/14 15:25 == 48.1
9/3/14 15:30 == 48
9/3/14 15:35 == 40.1
9/3/14 15:40 == 33.6
9/3/14 15:45 == 33.6
9/3/14 15:50 == 33.9
9/3/14 15:55 == 34
9/3/14 16:00 == 34
9/3/14 16:05 == 34.2
9/3/14 16:10 == 34.3
9/3/14 16:15 == 34.3
9/3/14 16:20 == 34.5
9/3/14 16:25 == 34.6
9/3/14 16:30 == 34.6
9/3/14 16:35 == 37
9/3/14 16:40 == 47.9
9/3/14 16:45 == 48
9/3/14 16:50 == 48
9/3/14 16:55 == 47.9
9/3/14 17:00 == 48
9/3/14 17:05 == 48.1
9/3/14 17:10 == 48.1
9/3/14 17:15 == 48
9/3/14 17:20 == 48.1
9/3/14 17:25 == 48
9/3/14 17:30 == 47.9
9/3/14 17:35 == 47.9
9/3/14 17:40 == 48
9/3/14 17:45 == 48
9/3/14 17:50 == 48.1
9/3/14 17:55 == 47.9
9/3/14 18:00 == 48
9/3/14 18:05 == 48
9/3/14 18:10 == 48
9/3/14 18:15 == 47.9
9/3/14 18:20 == 39.7
9/3/14 18:25 == 33.4
9/3/14 18:30 == 33.6
9/3/14 18:35 == 33.7
9/3/14 18:40 == 34
9/3/14 18:45 == 33.9
9/3/14 18:50 == 33.9
9/3/14 18:55 == 34
9/3/14 19:00 == 34
9/3/14 19:05 == 34.1
9/3/14 19:10 == 34.3
9/3/14 19:15 == 34.2
9/3/14 19:20 == 34.4
9/3/14 19:25 == 34.6
9/3/14 19:30 == 34.6
9/3/14 19:35 == 36.7
9/3/14 19:40 == 48
9/3/14 19:45 == 48
9/3/14 19:50 == 47.9
9/3/14 19:55 == 48.1
9/3/14 20:00 == 47.9
9/3/14 20:05 == 48
9/3/14 20:10 == 48
9/3/14 20:15 == 48
9/3/14 20:20 == 48
9/3/14 20:25 == 48.1
9/3/14 20:30 == 47.9
9/3/14 20:35 == 48
9/3/14 20:40 == 48.1
9/3/14 20:45 == 48
9/3/14 20:50 == 39.6
9/3/14 20:55 == 33.6
9/3/14 21:00 == 33.6
9/3/14 21:05 == 33.8
9/3/14 21:10 == 34.1
9/3/14 21:15 == 34.1
9/3/14 21:20 == 34
9/3/14 21:25 == 34
9/3/14 21:30 == 34
9/3/14 21:35 == 34.2
9/3/14 21:40 == 34.3
9/3/14 21:45 == 34.3
9/3/14 21:50 == 34.4
9/3/14 21:55 == 34.6
9/3/14 22:00 == 34.5
9/3/14 22:05 == 34.4
9/3/14 22:10 == 34.4
9/3/14 22:15 == 34.4
9/3/14 22:20 == 34.4
9/3/14 22:25 == 34.6
9/3/14 22:30 == 34.6
9/3/14 22:35 == 34.6
9/3/14 22:40 == 34.6
9/3/14 22:45 == 34.5
9/3/14 22:50 == 37.2
9/3/14 22:55 == 48
9/3/14 23:00 == 48
9/3/14 23:05 == 48
9/3/14 23:10 == 48.1
9/3/14 23:15 == 47.9
9/3/14 23:20 == 48
9/3/14 23:25 == 48.2
9/3/14 23:30 == 47.9
9/3/14 23:35 == 39.8
9/3/14 23:40 == 33.8
9/3/14 23:45 == 33.7
9/3/14 23:50 == 33.9
9/3/14 23:55 == 33.9
9/4/14 0:00 == 34
9/4/14 0:05 == 34
9/4/14 0:10 == 34.1
9/4/14 0:15 == 34.2
9/4/14 0:20 == 34.4
9/4/14 0:25 == 34.5
9/4/14 0:30 == 34.5
9/4/14 0:35 == 34.5
9/4/14 0:40 == 34.4
9/4/14 0:45 == 34.5
9/4/14 0:50 == 37.1
9/4/14 0:55 == 48.1
9/4/14 1:00 == 48
9/4/14 1:05 == 48
9/4/14 1:10 == 47.9
9/4/14 1:15 == 47.9

Pumpback Station Discharge (0364)

9/4/14 1:20 == 47.9
9/4/14 1:25 == 48
9/4/14 1:30 == 48
9/4/14 1:35 == 39.8
9/4/14 1:40 == 33.7
9/4/14 1:45 == 33.6
9/4/14 1:50 == 34
9/4/14 1:55 == 34.2
9/4/14 2:00 == 34.2
9/4/14 2:05 == 34.3
9/4/14 2:10 == 34.3
9/4/14 2:15 == 34.4
9/4/14 2:20 == 34.4
9/4/14 2:25 == 34.5
9/4/14 2:30 == 34.4
9/4/14 2:35 == 37
9/4/14 2:40 == 48
9/4/14 2:45 == 48.2
9/4/14 2:50 == 48
9/4/14 2:55 == 48
9/4/14 3:00 == 47.9
9/4/14 3:05 == 47.8
9/4/14 3:10 == 47.9
9/4/14 3:15 == 48
9/4/14 3:20 == 39.5
9/4/14 3:25 == 33.6
9/4/14 3:30 == 33.7
9/4/14 3:35 == 33.7
9/4/14 3:40 == 33.8
9/4/14 3:45 == 33.8
9/4/14 3:50 == 34
9/4/14 3:55 == 34
9/4/14 4:00 == 34
9/4/14 4:05 == 34.1
9/4/14 4:10 == 34.2
9/4/14 4:15 == 34.2
9/4/14 4:20 == 34.2
9/4/14 4:25 == 34.2
9/4/14 4:30 == 34.3
9/4/14 4:35 == 34.4
9/4/14 4:40 == 34.5
9/4/14 4:45 == 34.4
9/4/14 4:50 == 34.4
9/4/14 4:55 == 34.5
9/4/14 5:00 == 34.6
9/4/14 5:05 == 34.6
9/4/14 5:10 == 34.5
9/4/14 5:15 == 34.5
9/4/14 5:20 == 37.1
9/4/14 5:25 == 47.9
9/4/14 5:30 == 47.8
9/4/14 5:35 == 48.1
9/4/14 5:40 == 48.1
9/4/14 5:45 == 48
9/4/14 5:50 == 47.8
9/4/14 5:55 == 48
9/4/14 6:00 == 47.9
9/4/14 6:05 == 39.6
9/4/14 6:10 == 33.6
9/4/14 6:15 == 33.7
9/4/14 6:20 == 33.9
9/4/14 6:25 == 34
9/4/14 6:30 == 34
9/4/14 6:35 == 34.1
9/4/14 6:40 == 34.2
9/4/14 6:45 == 34.3
9/4/14 6:50 == 34.3
9/4/14 6:55 == 34.3
9/4/14 7:00 == 34.2
9/4/14 7:05 == 34.3
9/4/14 7:10 == 34.4
9/4/14 7:15 == 34.5
9/4/14 7:20 == 34.4
9/4/14 7:25 == 34.5
9/4/14 7:30 == 34.5
9/4/14 7:35 == 34.7
9/4/14 7:40 == 34.7
9/4/14 7:45 == 34.7
9/4/14 7:50 == 37.5
9/4/14 7:55 == 48.1
9/4/14 8:00 == 48.1
9/4/14 8:05 == 47.9
9/4/14 8:10 == 48
9/4/14 8:15 == 48.1
9/4/14 8:20 == 48
9/4/14 8:25 == 48
9/4/14 8:30 == 48.1
9/4/14 8:35 == 48
9/4/14 8:40 == 47.9
9/4/14 8:45 == 47.9
9/4/14 8:50 == 39.5
9/4/14 8:55 == 33.6
9/4/14 9:00 == 33.7
9/4/14 9:05 == 34
9/4/14 9:10 == 34
9/4/14 9:15 == 34.1
9/4/14 9:20 == 34.1
9/4/14 9:25 == 34.1
9/4/14 9:30 == 31.9
9/4/14 9:35 == 34.1
9/4/14 9:40 == 34.4
9/4/14 9:45 == 34.4
9/4/14 9:50 == 34.5
9/4/14 9:55 == 34.6
9/4/14 10:00 == 34.6
9/4/14 10:05 == 37.8
9/4/14 10:10 == 48
9/4/14 10:15 == 47.9
9/4/14 10:20 == 47.9
9/4/14 10:25 == 48
9/4/14 10:30 == 48.1
9/4/14 10:35 == 48
9/4/14 10:40 == 48
9/4/14 10:45 == 48
9/4/14 10:50 == 48
9/4/14 10:55 == 48
9/4/14 11:00 == 40.2
9/4/14 11:05 == 31.4
9/4/14 11:10 == 31.5
9/4/14 11:15 == 31.5
9/4/14 11:20 == 31.5
9/4/14 11:25 == 31.5
9/4/14 11:30 == 31.5
9/4/14 11:35 == 31.7
9/4/14 11:40 == 31.5
9/4/14 11:45 == 31.7
9/4/14 11:50 == 31.5
9/4/14 11:55 == 31.5
9/4/14 12:00 == 31.5
9/4/14 12:05 == 31.5
9/4/14 12:10 == 31.5
9/4/14 12:15 == 31.5
9/4/14 12:20 == 31.6
9/4/14 12:25 == 31.5
9/4/14 12:30 == 31.5
9/4/14 12:35 == 31.7
9/4/14 12:40 == 31.5
9/4/14 12:45 == 31.5
9/4/14 12:50 == 31.7
9/4/14 12:55 == 31.7
9/4/14 13:00 == 31.5
9/4/14 13:05 == 31.7
9/4/14 13:10 == 31.6
9/4/14 13:15 == 31.4
9/4/14 13:20 == 31.5
9/4/14 13:25 == 31.5
9/4/14 13:30 == 31.5
9/4/14 13:35 == 34.8
9/4/14 13:40 == 48.4
9/4/14 13:45 == 48.2
9/4/14 13:50 == 46.9
9/4/14 13:55 == 34
9/4/14 14:00 == 48.1
9/4/14 14:05 == 48.5
9/4/14 14:10 == 48.2
9/4/14 14:15 == 48.5
9/4/14 14:20 == 48.3
9/4/14 14:25 == 45.1
9/4/14 14:30 == 31.7
9/4/14 14:35 == 31.7
9/4/14 14:40 == 31.6
9/4/14 14:45 == 37.2
9/4/14 14:50 == 47.4
9/4/14 14:55 == 39.3
9/4/14 15:00 == 38.3
9/4/14 15:05 == 29.1
9/4/14 15:10 == 29.3
9/4/14 15:15 == 29.3
9/4/14 15:20 == 43.5
9/4/14 15:25 == 45.8
9/4/14 15:30 == 45.8
9/4/14 15:35 == 46.1
9/4/14 15:40 == 47
9/4/14 15:45 == 47.9
9/4/14 15:50 == 48
9/4/14 15:55 == 48
9/4/14 16:00 == 48.1
9/4/14 16:05 == 48.1
9/4/14 16:10 == 48.1
9/4/14 16:15 == 47.9
9/4/14 16:20 == 47.9
9/4/14 16:25 == 48.1
9/4/14 16:30 == 48.1
9/4/14 16:35 == 48
9/4/14 16:40 == 47.9
9/4/14 16:45 == 47.8
9/4/14 16:50 == 47.9
9/4/14 16:55 == 48.3
9/4/14 17:00 == 48.1
9/4/14 17:05 == 48
9/4/14 17:10 == 47.9
9/4/14 17:15 == 48
9/4/14 17:20 == 48.2
9/4/14 17:25 == 48.2
9/4/14 17:30 == 48.1
9/4/14 17:35 == 47.9
9/4/14 17:40 == 48.2
9/4/14 17:45 == 47.9
9/4/14 17:50 == 48.2
9/4/14 17:55 == 48.2
9/4/14 18:00 == 47.9
9/4/14 18:05 == 38.4
9/4/14 18:10 == 33.8
9/4/14 18:15 == 33.8
9/4/14 18:20 == 33.9
9/4/14 18:25 == 33.9
9/4/14 18:30 == 33.9
9/4/14 18:35 == 34.3
9/4/14 18:40 == 34.4
9/4/14 18:45 == 34.5
9/4/14 18:50 == 34.5
9/4/14 18:55 == 34.5
9/4/14 19:00 == 34.5
9/4/14 19:05 == 34.6
9/4/14 19:10 == 34.7
9/4/14 19:15 == 34.7
9/4/14 19:20 == 34.7
9/4/14 19:25 == 34.7
9/4/14 19:30 == 34.6
9/4/14 19:35 == 30.8

Pumpback Station Discharge (0364)

9/4/14 19:40 == 28.8
9/4/14 19:45 == 28.8
9/4/14 19:50 == 28.8
9/4/14 19:55 == 28.8
9/4/14 20:00 == 28.9
9/4/14 20:05 == 28.9
9/4/14 20:10 == 28.8
9/4/14 20:15 == 28.9
9/4/14 20:20 == 28.9
9/4/14 20:25 == 28.9
9/4/14 20:30 == 28.9
9/4/14 20:35 == 28.9
9/4/14 20:40 == 29
9/4/14 20:45 == 28.9
9/4/14 20:50 == 28.9
9/4/14 20:55 == 28.9
9/4/14 21:00 == 28.9
9/4/14 21:05 == 29
9/4/14 21:10 == 29
9/4/14 21:15 == 29
9/4/14 21:20 == 28.9
9/4/14 21:25 == 28.9
9/4/14 21:30 == 29
9/4/14 21:35 == 28.9
9/4/14 21:40 == 29
9/4/14 21:45 == 29
9/4/14 21:50 == 28.9
9/4/14 21:55 == 29
9/4/14 22:00 == 28.9
9/4/14 22:05 == 28.9
9/4/14 22:10 == 28.9
9/4/14 22:15 == 28.9
9/4/14 22:20 == 29
9/4/14 22:25 == 28.9
9/4/14 22:30 == 29
9/4/14 22:35 == 28.9
9/4/14 22:40 == 29
9/4/14 22:45 == 29
9/4/14 22:50 == 29
9/4/14 22:55 == 29
9/4/14 23:00 == 28.9
9/4/14 23:05 == 29
9/4/14 23:10 == 29.1
9/4/14 23:15 == 29
9/4/14 23:20 == 29
9/4/14 23:25 == 29
9/4/14 23:30 == 29
9/4/14 23:35 == 29
9/4/14 23:40 == 29.1
9/4/14 23:45 == 29
9/4/14 23:50 == 28.9
9/4/14 23:55 == 29
9/5/14 0:00 == 29
9/5/14 0:05 == 29
9/5/14 0:10 == 29
9/5/14 0:15 == 29.1
9/5/14 0:20 == 29
9/5/14 0:25 == 29.1
9/5/14 0:30 == 29
9/5/14 0:35 == 29.1
9/5/14 0:40 == 29
9/5/14 0:45 == 29.1
9/5/14 0:50 == 29
9/5/14 0:55 == 29.1
9/5/14 1:00 == 29
9/5/14 1:05 == 29
9/5/14 1:10 == 29
9/5/14 1:15 == 29
9/5/14 1:20 == 29.1
9/5/14 1:25 == 29
9/5/14 1:30 == 29
9/5/14 1:35 == 29
9/5/14 1:40 == 29
9/5/14 1:45 == 29
9/5/14 1:50 == 29.1
9/5/14 1:55 == 29
9/5/14 2:00 == 29.1
9/5/14 2:05 == 29.1
9/5/14 2:10 == 29
9/5/14 2:15 == 29
9/5/14 2:20 == 29.1
9/5/14 2:25 == 29.1
9/5/14 2:30 == 29
9/5/14 2:35 == 29.1
9/5/14 2:40 == 29
9/5/14 2:45 == 29
9/5/14 2:50 == 29.1
9/5/14 2:55 == 29
9/5/14 3:00 == 29.1
9/5/14 3:05 == 29.1
9/5/14 3:10 == 29.1
9/5/14 3:15 == 29.1
9/5/14 3:20 == 29.1
9/5/14 3:25 == 29.2
9/5/14 3:30 == 29
9/5/14 3:35 == 29.1
9/5/14 3:40 == 29.1
9/5/14 3:45 == 29.1
9/5/14 3:50 == 29.1
9/5/14 3:55 == 29.1
9/5/14 4:00 == 29
9/5/14 4:05 == 29
9/5/14 4:10 == 29.1
9/5/14 4:15 == 29.1
9/5/14 4:20 == 29
9/5/14 4:25 == 29
9/5/14 4:30 == 29
9/5/14 4:35 == 29
9/5/14 4:40 == 29
9/5/14 4:45 == 29.1
9/5/14 4:50 == 29.1
9/5/14 4:55 == 29.1
9/5/14 5:00 == 29.2
9/5/14 5:05 == 29.1
9/5/14 5:10 == 29.1
9/5/14 5:15 == 29
9/5/14 5:20 == 29.1
9/5/14 5:25 == 29.2
9/5/14 5:30 == 29
9/5/14 5:35 == 29.1
9/5/14 5:40 == 29.2
9/5/14 5:45 == 29
9/5/14 5:50 == 29.1
9/5/14 5:55 == 29.1
9/5/14 6:00 == 29.2
9/5/14 6:05 == 29.1
9/5/14 6:10 == 29.1
9/5/14 6:15 == 29.1
9/5/14 6:20 == 29.3
9/5/14 6:25 == 29.1
9/5/14 6:30 == 29
9/5/14 6:35 == 29.1
9/5/14 6:40 == 29.2
9/5/14 6:45 == 29.1
9/5/14 6:50 == 29.3
9/5/14 6:55 == 29.2
9/5/14 7:00 == 29.3
9/5/14 7:05 == 33.9
9/5/14 7:10 == 48
9/5/14 7:15 == 47.9
9/5/14 7:20 == 48
9/5/14 7:25 == 48
9/5/14 7:30 == 47.9
9/5/14 7:35 == 47.9
9/5/14 7:40 == 48.1
9/5/14 7:45 == 47.9
9/5/14 7:50 == 48.1
9/5/14 7:55 == 48
9/5/14 8:00 == 47.9
9/5/14 8:05 == 47.9
9/5/14 8:10 == 48.3
9/5/14 8:15 == 47.9
9/5/14 8:20 == 48.1
9/5/14 8:25 == 48.1
9/5/14 8:30 == 47.8
9/5/14 8:35 == 48
9/5/14 8:40 == 47.9
9/5/14 8:45 == 48.1
9/5/14 8:50 == 47.9
9/5/14 8:55 == 48
9/5/14 9:00 == 48.1
9/5/14 9:05 == 47.9
9/5/14 9:10 == 47.9
9/5/14 9:15 == 47.9
9/5/14 9:20 == 48
9/5/14 9:25 == 47.9
9/5/14 9:30 == 48.1
9/5/14 9:35 == 47.9
9/5/14 9:40 == 48
9/5/14 9:45 == 48
9/5/14 9:50 == 48
9/5/14 9:55 == 47.9
9/5/14 10:00 == 47.9
9/5/14 10:05 == 47.9
9/5/14 10:10 == 47.9
9/5/14 10:15 == 47.9
9/5/14 10:20 == 47.9
9/5/14 10:25 == 48.1
9/5/14 10:30 == 47.9
9/5/14 10:35 == #
9/5/14 10:40 == 47.9
9/5/14 10:45 == 48.1
9/5/14 10:50 == 47.9
9/5/14 10:55 == 48.1
9/5/14 11:00 == 47.9
9/5/14 11:05 == 48.1
9/5/14 11:10 == 48
9/5/14 11:15 == 48
9/5/14 11:20 == 47.9
9/5/14 11:25 == 47.9
9/5/14 11:30 == 48
9/5/14 11:35 == 48
9/5/14 11:40 == 48.1
9/5/14 11:45 == 48
9/5/14 11:50 == 48.1
9/5/14 11:55 == 48
9/5/14 12:00 == 48.1
9/5/14 12:05 == 48.2
9/5/14 12:10 == 48.1
9/5/14 12:15 == 48.1
9/5/14 12:20 == 48.1
9/5/14 12:25 == 48
9/5/14 12:30 == 48.1
9/5/14 12:35 == 48.2
9/5/14 12:40 == 47.9
9/5/14 12:45 == 48
9/5/14 12:50 == 48.1
9/5/14 12:55 == 48
9/5/14 13:00 == 48
9/5/14 13:05 == 48.1
9/5/14 13:10 == 47.8
9/5/14 13:15 == 48
9/5/14 13:20 == 48
9/5/14 13:25 == 48
9/5/14 13:30 == 47.9
9/5/14 13:35 == 48
9/5/14 13:40 == 47.9
9/5/14 13:45 == 48
9/5/14 13:50 == 48.1
9/5/14 13:55 == 48

Pumpback Station Discharge (0364)

9/5/14 14:00 == 47.9
9/5/14 14:05 == 48.1
9/5/14 14:10 == 48
9/5/14 14:15 == 48
9/5/14 14:20 == 48
9/5/14 14:25 == 47.8
9/5/14 14:30 == 48
9/5/14 14:35 == 48
9/5/14 14:40 == 48
9/5/14 14:45 == 47.9
9/5/14 14:50 == 48.1
9/5/14 14:55 == 48
9/5/14 15:00 == 48
9/5/14 15:05 == 48
9/5/14 15:10 == 48
9/5/14 15:15 == 47.9
9/5/14 15:20 == 48.1
9/5/14 15:25 == 48
9/5/14 15:30 == 47.9
9/5/14 15:35 == 48
9/5/14 15:40 == 48
9/5/14 15:45 == 48.1
9/5/14 15:50 == 48
9/5/14 15:55 == 47.8
9/5/14 16:00 == 48
9/5/14 16:05 == 47.9
9/5/14 16:10 == 47.9
9/5/14 16:15 == 48
9/5/14 16:20 == 48.1
9/5/14 16:25 == 48.1
9/5/14 16:30 == 48.1
9/5/14 16:35 == 48
9/5/14 16:40 == 48
9/5/14 16:45 == 48.1
9/5/14 16:50 == 47.9
9/5/14 16:55 == 47.9
9/5/14 17:00 == 48
9/5/14 17:05 == 48.1
9/5/14 17:10 == 47.9
9/5/14 17:15 == 48
9/5/14 17:20 == 47.9
9/5/14 17:25 == 48
9/5/14 17:30 == 48
9/5/14 17:35 == 47.9
9/5/14 17:40 == 37
9/5/14 17:45 == 33.8
9/5/14 17:50 == 33.8
9/5/14 17:55 == 34
9/5/14 18:00 == 34.1
9/5/14 18:05 == 34.3
9/5/14 18:10 == 34.4
9/5/14 18:15 == 34.5
9/5/14 18:20 == 34.4
9/5/14 18:25 == 34.7
9/5/14 18:30 == 34.6
9/5/14 18:35 == 34.6
9/5/14 18:40 == 34.6
9/5/14 18:45 == 34.5
9/5/14 18:50 == 34.5
9/5/14 18:55 == 34.7
9/5/14 19:00 == 34.7
9/5/14 19:05 == 34.8
9/5/14 19:10 == 39.8
9/5/14 19:15 == 48
9/5/14 19:20 == 48.1
9/5/14 19:25 == 48
9/5/14 19:30 == 48
9/5/14 19:35 == 48
9/5/14 19:40 == 48
9/5/14 19:45 == 47.9
9/5/14 19:50 == 47.9
9/5/14 19:55 == 36.9
9/5/14 20:00 == 33.8
9/5/14 20:05 == 33.8
9/5/14 20:10 == 34
9/5/14 20:15 == 34.1
9/5/14 20:20 == 34
9/5/14 20:25 == 34.3
9/5/14 20:30 == 34.2
9/5/14 20:35 == 34.3
9/5/14 20:40 == 34.2
9/5/14 20:45 == 34.3
9/5/14 20:50 == 34.2
9/5/14 20:55 == 34.4
9/5/14 21:00 == 34.4
9/5/14 21:05 == 34.4
9/5/14 21:10 == 34.4
9/5/14 21:15 == 34.5
9/5/14 21:20 == 34.6
9/5/14 21:25 == 34.5
9/5/14 21:30 == 34.5
9/5/14 21:35 == 34.6
9/5/14 21:40 == 34.6
9/5/14 21:45 == 34.7
9/5/14 21:50 == 34.6
9/5/14 21:55 == 34.6
9/5/14 22:00 == 34.5
9/5/14 22:05 == 34.6
9/5/14 22:10 == 34.6
9/5/14 22:15 == 34.7
9/5/14 22:20 == 34.6
9/5/14 22:25 == 34.7
9/5/14 22:30 == 34.8
9/5/14 22:35 == 34.8
9/5/14 22:40 == 34.8
9/5/14 22:45 == 34.8
9/5/14 22:50 == 34.8
9/5/14 22:55 == 34.8
9/5/14 23:00 == 34.8
9/5/14 23:05 == 34.8
9/5/14 23:10 == 34.8
9/5/14 23:15 == 34.8
9/5/14 23:20 == 34.8
9/5/14 23:25 == 39.9
9/5/14 23:30 == 48
9/5/14 23:35 == 48
9/5/14 23:40 == 48
9/5/14 23:45 == 47.9
9/5/14 23:50 == 48.1
9/5/14 23:55 == 47.9
9/6/14 0:00 == 47.9
9/6/14 0:05 == 48
9/6/14 0:10 == 36.8
9/6/14 0:15 == 33.6
9/6/14 0:20 == 33.7
9/6/14 0:25 == 33.9
9/6/14 0:30 == 34
9/6/14 0:35 == 34.1
9/6/14 0:40 == 34.1
9/6/14 0:45 == 34.1
9/6/14 0:50 == 34.2
9/6/14 0:55 == 34.1
9/6/14 1:00 == 34.2
9/6/14 1:05 == 34.1
9/6/14 1:10 == 34.5
9/6/14 1:15 == 34.4
9/6/14 1:20 == 34.5
9/6/14 1:25 == 34.3
9/6/14 1:30 == 34.4
9/6/14 1:35 == 34.4
9/6/14 1:40 == 34.5
9/6/14 1:45 == 34.5
9/6/14 1:50 == 34.4
9/6/14 1:55 == 34.6
9/6/14 2:00 == 34.6
9/6/14 2:05 == 34.7
9/6/14 2:10 == 34.6
9/6/14 2:15 == 34.7
9/6/14 2:20 == 34.7
9/6/14 2:25 == 34.7
9/6/14 2:30 == 34.7
9/6/14 2:35 == 34.8
9/6/14 2:40 == 34.7
9/6/14 2:45 == 34.8
9/6/14 2:50 == 34.8
9/6/14 2:55 == 34.8
9/6/14 3:00 == 34.7
9/6/14 3:05 == 34.8
9/6/14 3:10 == 34.8
9/6/14 3:15 == 34.8
9/6/14 3:20 == 34.7
9/6/14 3:25 == 40.1
9/6/14 3:30 == 48
9/6/14 3:35 == 48.1
9/6/14 3:40 == 48
9/6/14 3:45 == 48
9/6/14 3:50 == 47.9
9/6/14 3:55 == 48
9/6/14 4:00 == 47.9
9/6/14 4:05 == 47.9
9/6/14 4:10 == 36.9
9/6/14 4:15 == 33.9
9/6/14 4:20 == 33.9
9/6/14 4:25 == 34
9/6/14 4:30 == 34.2
9/6/14 4:35 == 34.1
9/6/14 4:40 == 34.2
9/6/14 4:45 == 34.2
9/6/14 4:50 == 34.2
9/6/14 4:55 == 34.2
9/6/14 5:00 == 34.4
9/6/14 5:05 == 34.3
9/6/14 5:10 == 34.3
9/6/14 5:15 == 34.4
9/6/14 5:20 == 34.4
9/6/14 5:25 == 34.5
9/6/14 5:30 == 34.4
9/6/14 5:35 == 34.4
9/6/14 5:40 == 34.7
9/6/14 5:45 == 34.5
9/6/14 5:50 == 34.4
9/6/14 5:55 == 34.5
9/6/14 6:00 == 34.6
9/6/14 6:05 == 34.6
9/6/14 6:10 == 34.6
9/6/14 6:15 == 34.5
9/6/14 6:20 == 34.5
9/6/14 6:25 == 34.7
9/6/14 6:30 == 34.5
9/6/14 6:35 == 34.5
9/6/14 6:40 == 34.6
9/6/14 6:45 == 34.6
9/6/14 6:50 == 34.6
9/6/14 6:55 == 34.7
9/6/14 7:00 == 34.6
9/6/14 7:05 == 34.7
9/6/14 7:10 == 34.7
9/6/14 7:15 == 34.7
9/6/14 7:20 == 34.8
9/6/14 7:25 == 34.6
9/6/14 7:30 == 34.7
9/6/14 7:35 == 34.7
9/6/14 7:40 == 34.6
9/6/14 7:45 == 34.6
9/6/14 7:50 == 34.6
9/6/14 7:55 == 34.8
9/6/14 8:00 == 34.9
9/6/14 8:05 == 34.8
9/6/14 8:10 == 41.1
9/6/14 8:15 == 48

Pumpback Station Discharge (0364)

9/6/14 8:20 == 48
9/6/14 8:25 == 48.2
9/6/14 8:30 == 48
9/6/14 8:35 == 48
9/6/14 8:40 == 48
9/6/14 8:45 == 48.1
9/6/14 8:50 == 48
9/6/14 8:55 == 35.9
9/6/14 9:00 == 34
9/6/14 9:05 == 34.1
9/6/14 9:10 == 34.2
9/6/14 9:15 == 34.2
9/6/14 9:20 == 34.2
9/6/14 9:25 == 34.4
9/6/14 9:30 == 34.5
9/6/14 9:35 == 34.2
9/6/14 9:40 == 34.5
9/6/14 9:45 == 34.5
9/6/14 9:50 == 34.5
9/6/14 9:55 == 34.6
9/6/14 10:00 == 34.6
9/6/14 10:05 == 34.7
9/6/14 10:10 == 34.6
9/6/14 10:15 == 34.7
9/6/14 10:20 == 34.8
9/6/14 10:25 == 34.7
9/6/14 10:30 == 34.8
9/6/14 10:35 == 34.8
9/6/14 10:40 == 31
9/6/14 10:45 == 47
9/6/14 10:50 == 48
9/6/14 10:55 == 48
9/6/14 11:00 == 48
9/6/14 11:05 == 47.9
9/6/14 11:10 == 48
9/6/14 11:15 == 48.1
9/6/14 11:20 == 48
9/6/14 11:25 == 48
9/6/14 11:30 == 48
9/6/14 11:35 == 47.9
9/6/14 11:40 == 35.8
9/6/14 11:45 == 33.7
9/6/14 11:50 == 33.8
9/6/14 11:55 == 33.9
9/6/14 12:00 == 34
9/6/14 12:05 == 34
9/6/14 12:10 == 34.2
9/6/14 12:15 == 34.1
9/6/14 12:20 == 34.3
9/6/14 12:25 == 34.3
9/6/14 12:30 == 34.1
9/6/14 12:35 == 34.2
9/6/14 12:40 == 34.3
9/6/14 12:45 == 34.5
9/6/14 12:50 == 34.3
9/6/14 12:55 == 34.4
9/6/14 13:00 == 34.4
9/6/14 13:05 == 34.6
9/6/14 13:10 == 34.6
9/6/14 13:15 == 34.6
9/6/14 13:20 == 34.8
9/6/14 13:25 == 34.5
9/6/14 13:30 == 34.4
9/6/14 13:35 == 34.4
9/6/14 13:40 == 34.7
9/6/14 13:45 == 34.8
9/6/14 13:50 == 34.8
9/6/14 13:55 == 32.1
9/6/14 14:00 == 48
9/6/14 14:05 == 47.9
9/6/14 14:10 == 48.1
9/6/14 14:15 == 48
9/6/14 14:20 == 48
9/6/14 14:25 == 47.9
9/6/14 14:30 == 48
9/6/14 14:35 == 48
9/6/14 14:40 == 35.6
9/6/14 14:45 == 33.7
9/6/14 14:50 == 33.7
9/6/14 14:55 == 34.1
9/6/14 15:00 == 34
9/6/14 15:05 == 34.1
9/6/14 15:10 == 34.1
9/6/14 15:15 == 34.2
9/6/14 15:20 == 34.2
9/6/14 15:25 == 34.4
9/6/14 15:30 == 34.4
9/6/14 15:35 == 34.4
9/6/14 15:40 == 34.4
9/6/14 15:45 == 34.5
9/6/14 15:50 == 34.4
9/6/14 15:55 == 34.5
9/6/14 16:00 == 34.5
9/6/14 16:05 == 34.5
9/6/14 16:10 == 34.6
9/6/14 16:15 == 34.6
9/6/14 16:20 == 34.6
9/6/14 16:25 == 34.6
9/6/14 16:30 == 34.6
9/6/14 16:35 == 34.7
9/6/14 16:40 == 34.7
9/6/14 16:45 == 34.7
9/6/14 16:50 == 34.7
9/6/14 16:55 == 34.6
9/6/14 17:00 == 34.8
9/6/14 17:05 == 34.7
9/6/14 17:10 == 34.9
9/6/14 17:15 == 34.8
9/6/14 17:20 == 34.8
9/6/14 17:25 == 41.2
9/6/14 17:30 == 48
9/6/14 17:35 == 48
9/6/14 17:40 == 48
9/6/14 17:45 == 47.9
9/6/14 17:50 == 47.9
9/6/14 17:55 == 48.1
9/6/14 18:00 == 47.9
9/6/14 18:05 == 48
9/6/14 18:10 == 35.5
9/6/14 18:15 == 33.8
9/6/14 18:20 == 33.9
9/6/14 18:25 == 34.1
9/6/14 18:30 == 34
9/6/14 18:35 == 34.1
9/6/14 18:40 == 34.2
9/6/14 18:45 == 34.1
9/6/14 18:50 == 34.2
9/6/14 18:55 == 34.3
9/6/14 19:00 == 34.2
9/6/14 19:05 == 34.3
9/6/14 19:10 == 34.4
9/6/14 19:15 == 34.4
9/6/14 19:20 == 34.3
9/6/14 19:25 == 34.4
9/6/14 19:30 == 34.5
9/6/14 19:35 == 34.4
9/6/14 19:40 == 34.4
9/6/14 19:45 == 34.4
9/6/14 19:50 == 34.4
9/6/14 19:55 == 34.5
9/6/14 20:00 == 34.4
9/6/14 20:05 == 34.4
9/6/14 20:10 == 34.4
9/6/14 20:15 == 34.6
9/6/14 20:20 == 34.5
9/6/14 20:25 == 34.5
9/6/14 20:30 == 34.5
9/6/14 20:35 == 34.5
9/6/14 20:40 == 34.6
9/6/14 20:45 == 34.6
9/6/14 20:50 == 34.6
9/6/14 20:55 == 34.6
9/6/14 21:00 == 34.6
9/6/14 21:05 == 34.6
9/6/14 21:10 == 34.7
9/6/14 21:15 == 34.6
9/6/14 21:20 == 34.7
9/6/14 21:25 == 34.7
9/6/14 21:30 == 34.7
9/6/14 21:35 == 34.8
9/6/14 21:40 == 34.8
9/6/14 21:45 == 34.9
9/6/14 21:50 == 34.8
9/6/14 21:55 == 34.8
9/6/14 22:00 == 34.7
9/6/14 22:05 == 34.9
9/6/14 22:10 == 41.2
9/6/14 22:15 == 47.9
9/6/14 22:20 == 48.1
9/6/14 22:25 == 48
9/6/14 22:30 == 47.9
9/6/14 22:35 == 48.1
9/6/14 22:40 == 48
9/6/14 22:45 == 48
9/6/14 22:50 == 48.1
9/6/14 22:55 == 35.4
9/6/14 23:00 == 33.6
9/6/14 23:05 == 33.6
9/6/14 23:10 == 33.8
9/6/14 23:15 == 33.9
9/6/14 23:20 == 33.9
9/6/14 23:25 == 34
9/6/14 23:30 == 34
9/6/14 23:35 == 34
9/6/14 23:40 == 34.1
9/6/14 23:45 == 34
9/6/14 23:50 == 34.1
9/6/14 23:55 == 34.3
9/7/14 0:00 == 34.3
9/7/14 0:05 == 34.2
9/7/14 0:10 == 34.2
9/7/14 0:15 == 34.2
9/7/14 0:20 == 34.2
9/7/14 0:25 == 34.4
9/7/14 0:30 == 34.3
9/7/14 0:35 == 34.4
9/7/14 0:40 == 34.5
9/7/14 0:45 == 34.5
9/7/14 0:50 == 34.5
9/7/14 0:55 == 34.4
9/7/14 1:00 == 34.5
9/7/14 1:05 == 34.4
9/7/14 1:10 == 34.5
9/7/14 1:15 == 34.6
9/7/14 1:20 == 34.6
9/7/14 1:25 == 34.6
9/7/14 1:30 == 34.7
9/7/14 1:35 == 34.5
9/7/14 1:40 == 34.6
9/7/14 1:45 == 34.6
9/7/14 1:50 == 34.6
9/7/14 1:55 == 34.5
9/7/14 2:00 == 34.4
9/7/14 2:05 == 34.4
9/7/14 2:10 == 34.5
9/7/14 2:15 == 34.5
9/7/14 2:20 == 34.4
9/7/14 2:25 == 34.6
9/7/14 2:30 == 34.5
9/7/14 2:35 == 34.5

Pumpback Station Discharge (0364)

9/7/14 2:40 == 34.5
9/7/14 2:45 == 34.5
9/7/14 2:50 == 34.6
9/7/14 2:55 == 34.6
9/7/14 3:00 == 34.6
9/7/14 3:05 == 34.6
9/7/14 3:10 == 34.5
9/7/14 3:15 == 34.5
9/7/14 3:20 == 34.6
9/7/14 3:25 == 34.6
9/7/14 3:30 == 34.8
9/7/14 3:35 == 34.6
9/7/14 3:40 == 34.6
9/7/14 3:45 == 34.7
9/7/14 3:50 == 34.7
9/7/14 3:55 == 34.5
9/7/14 4:00 == 34.7
9/7/14 4:05 == 34.6
9/7/14 4:10 == 34.7
9/7/14 4:15 == 34.6
9/7/14 4:20 == 34.5
9/7/14 4:25 == 34.6
9/7/14 4:30 == 34.6
9/7/14 4:35 == 34.7
9/7/14 4:40 == 34.6
9/7/14 4:45 == 34.5
9/7/14 4:50 == 34.6
9/7/14 4:55 == 34.6
9/7/14 5:00 == 34.6
9/7/14 5:05 == 34.6
9/7/14 5:10 == 34.6
9/7/14 5:15 == 34.6
9/7/14 5:20 == 34.6
9/7/14 5:25 == 34.6
9/7/14 5:30 == 34.5
9/7/14 5:35 == 34.7
9/7/14 5:40 == 34.7
9/7/14 5:45 == 34.7
9/7/14 5:50 == 34.6
9/7/14 5:55 == 34.6
9/7/14 6:00 == 34.5
9/7/14 6:05 == 34.6
9/7/14 6:10 == 34.5
9/7/14 6:15 == 34.6
9/7/14 6:20 == 34.5
9/7/14 6:25 == 34.5
9/7/14 6:30 == 34.6
9/7/14 6:35 == 34.5
9/7/14 6:40 == 34.6
9/7/14 6:45 == 34.7
9/7/14 6:50 == 34.6
9/7/14 6:55 == 34.5
9/7/14 7:00 == 34.7
9/7/14 7:05 == 34.6
9/7/14 7:10 == 34.6
9/7/14 7:15 == 34.5
9/7/14 7:20 == 34.5
9/7/14 7:25 == 34.7
9/7/14 7:30 == 34.7
9/7/14 7:35 == 34.9
9/7/14 7:40 == 35
9/7/14 7:45 == 34.7
9/7/14 7:50 == 34.9
9/7/14 7:55 == 34.8
9/7/14 8:00 == 34.9
9/7/14 8:05 == 34.9
9/7/14 8:10 == 34.8
9/7/14 8:15 == 34.8
9/7/14 8:20 == 34.9
9/7/14 8:25 == 35
9/7/14 8:30 == 35
9/7/14 8:35 == 34.9
9/7/14 8:40 == 34.9
9/7/14 8:45 == 35
9/7/14 8:50 == 34.9
9/7/14 8:55 == 34.9
9/7/14 9:00 == 34.9
9/7/14 9:05 == 35
9/7/14 9:10 == 35
9/7/14 9:15 == 35
9/7/14 9:20 == 35
9/7/14 9:25 == 35
9/7/14 9:30 == 34.9
9/7/14 9:35 == 35
9/7/14 9:40 == 34.9
9/7/14 9:45 == 35
9/7/14 9:50 == 35
9/7/14 9:55 == 35.1
9/7/14 10:00 == 35.1
9/7/14 10:05 == 35.2
9/7/14 10:10 == 42.7
9/7/14 10:15 == 48
9/7/14 10:20 == 48.1
9/7/14 10:25 == 48
9/7/14 10:30 == 48.1
9/7/14 10:35 == 47.9
9/7/14 10:40 == 48
9/7/14 10:45 == 48.1
9/7/14 10:50 == 47.9
9/7/14 10:55 == 34.7
9/7/14 11:00 == 34.1
9/7/14 11:05 == 34.1
9/7/14 11:10 == 34.3
9/7/14 11:15 == 34.3
9/7/14 11:20 == 34.3
9/7/14 11:25 == 34.4
9/7/14 11:30 == 34.5
9/7/14 11:35 == 34.5
9/7/14 11:40 == 34.5
9/7/14 11:45 == 34.6
9/7/14 11:50 == 34.5
9/7/14 11:55 == 34.5
9/7/14 12:00 == 34.6
9/7/14 12:05 == 34.5
9/7/14 12:10 == 34.6
9/7/14 12:15 == 34.6
9/7/14 12:20 == 34.6
9/7/14 12:25 == 34.4
9/7/14 12:30 == 34.6
9/7/14 12:35 == 34.6
9/7/14 12:40 == 34.6
9/7/14 12:45 == 34.5
9/7/14 12:50 == 34.6
9/7/14 12:55 == 34.5
9/7/14 13:00 == 34.5
9/7/14 13:05 == 34.6
9/7/14 13:10 == 34.5
9/7/14 13:15 == 34.6
9/7/14 13:20 == 34.6
9/7/14 13:25 == 34.5
9/7/14 13:30 == 34.5
9/7/14 13:35 == 34.6
9/7/14 13:40 == 34.8
9/7/14 13:45 == 34.8
9/7/14 13:50 == 34.7
9/7/14 13:55 == 34.7
9/7/14 14:00 == 34.8
9/7/14 14:05 == 34.9
9/7/14 14:10 == 34.8
9/7/14 14:15 == 34.9
9/7/14 14:20 == 34.8
9/7/14 14:25 == 34.9
9/7/14 14:30 == 34.8
9/7/14 14:35 == 34.8
9/7/14 14:40 == 34.8
9/7/14 14:45 == 34.8
9/7/14 14:50 == 34.8
9/7/14 14:55 == 34.9
9/7/14 15:00 == 34.9
9/7/14 15:05 == 34.9
9/7/14 15:10 == 34.9
9/7/14 15:15 == 34.9
9/7/14 15:20 == 34.8
9/7/14 15:25 == 34.9
9/7/14 15:30 == 34.9
9/7/14 15:35 == 34.9
9/7/14 15:40 == 35
9/7/14 15:45 == 34.9
9/7/14 15:50 == 34.9
9/7/14 15:55 == 34.9
9/7/14 16:00 == 34.9
9/7/14 16:05 == 34.9
9/7/14 16:10 == 35
9/7/14 16:15 == 35.1
9/7/14 16:20 == 35.1
9/7/14 16:25 == 35.1
9/7/14 16:30 == 35.1
9/7/14 16:35 == 35.1
9/7/14 16:40 == 35.1
9/7/14 16:45 == 35
9/7/14 16:50 == 35
9/7/14 16:55 == 35.1
9/7/14 17:00 == 35.1
9/7/14 17:05 == 35.1
9/7/14 17:10 == 42.8
9/7/14 17:15 == 48
9/7/14 17:20 == 48.1
9/7/14 17:25 == 48
9/7/14 17:30 == 47.8
9/7/14 17:35 == 48
9/7/14 17:40 == 34.6
9/7/14 17:45 == 34.3
9/7/14 17:50 == 34.3
9/7/14 17:55 == 34.5
9/7/14 18:00 == 34.4
9/7/14 18:05 == 34.5
9/7/14 18:10 == 34.6
9/7/14 18:15 == 34.7
9/7/14 18:20 == 34.6
9/7/14 18:25 == 34.6
9/7/14 18:30 == 34.6
9/7/14 18:35 == 34.5
9/7/14 18:40 == 34.7
9/7/14 18:45 == 34.6
9/7/14 18:50 == 34.8
9/7/14 18:55 == 34.7
9/7/14 19:00 == 34.8
9/7/14 19:05 == 34.6
9/7/14 19:10 == 34.6
9/7/14 19:15 == 34.5
9/7/14 19:20 == 34.6
9/7/14 19:25 == 34.5
9/7/14 19:30 == 34.7
9/7/14 19:35 == 34.6
9/7/14 19:40 == 34.7
9/7/14 19:45 == 34.6
9/7/14 19:50 == 34.6
9/7/14 19:55 == 34.7
9/7/14 20:00 == 34.7
9/7/14 20:05 == 34.6
9/7/14 20:10 == 34.7
9/7/14 20:15 == 34.7
9/7/14 20:20 == 34.6
9/7/14 20:25 == 34.7
9/7/14 20:30 == 34.8
9/7/14 20:35 == 34.7
9/7/14 20:40 == 34.8
9/7/14 20:45 == 34.8
9/7/14 20:50 == 34.8
9/7/14 20:55 == 34.7

Pumpback Station Discharge (0364)

9/7/14 21:00 == 34.7
9/7/14 21:05 == 34.7
9/7/14 21:10 == 34.8
9/7/14 21:15 == 34.7
9/7/14 21:20 == 34.7
9/7/14 21:25 == 34.7
9/7/14 21:30 == 34.7
9/7/14 21:35 == 34.8
9/7/14 21:40 == 34.7
9/7/14 21:45 == 34.7
9/7/14 21:50 == 34.7
9/7/14 21:55 == 34.8
9/7/14 22:00 == 34.8
9/7/14 22:05 == 34.8
9/7/14 22:10 == 34.8
9/7/14 22:15 == 34.8
9/7/14 22:20 == 34.9
9/7/14 22:25 == 34.8
9/7/14 22:30 == 35
9/7/14 22:35 == 34.8
9/7/14 22:40 == 34.8
9/7/14 22:45 == 34.8
9/7/14 22:50 == 34.9
9/7/14 22:55 == 34.7
9/7/14 23:00 == 34.6
9/7/14 23:05 == 34.7
9/7/14 23:10 == 34.6
9/7/14 23:15 == 34.6
9/7/14 23:20 == 34.8
9/7/14 23:25 == 34.7
9/7/14 23:30 == 34.7
9/7/14 23:35 == 34.7
9/7/14 23:40 == 34.8
9/7/14 23:45 == 34.9
9/7/14 23:50 == 34.7
9/7/14 23:55 == 34.7
9/8/14 0:00 == 34.7
9/8/14 0:05 == 34.8
9/8/14 0:10 == 34.8
9/8/14 0:15 == 34.8
9/8/14 0:20 == 34.8
9/8/14 0:25 == 34.7
9/8/14 0:30 == 34.7
9/8/14 0:35 == 34.8
9/8/14 0:40 == 34.8
9/8/14 0:45 == 34.9
9/8/14 0:50 == 34.9
9/8/14 0:55 == 34.8
9/8/14 1:00 == 34.8
9/8/14 1:05 == 34.7
9/8/14 1:10 == 34.7
9/8/14 1:15 == 34.8
9/8/14 1:20 == 34.8
9/8/14 1:25 == 34.7
9/8/14 1:30 == 34.7
9/8/14 1:35 == 34.9
9/8/14 1:40 == 34.8
9/8/14 1:45 == 34.8
9/8/14 1:50 == 34.9
9/8/14 1:55 == 34.8
9/8/14 2:00 == 34.9
9/8/14 2:05 == 34.8
9/8/14 2:10 == 34.8
9/8/14 2:15 == 34.7
9/8/14 2:20 == 34.9
9/8/14 2:25 == 34.8
9/8/14 2:30 == 34.9
9/8/14 2:35 == 34.9
9/8/14 2:40 == 34.8
9/8/14 2:45 == 34.9
9/8/14 2:50 == 34.8
9/8/14 2:55 == 34.8
9/8/14 3:00 == 34.8
9/8/14 3:05 == 34.9
9/8/14 3:10 == 35
9/8/14 3:15 == 34.8
9/8/14 3:20 == 34.8
9/8/14 3:25 == 34.8
9/8/14 3:30 == 34.9
9/8/14 3:35 == 34.7
9/8/14 3:40 == 34.8
9/8/14 3:45 == 34.8
9/8/14 3:50 == 34.8
9/8/14 3:55 == 34.9
9/8/14 4:00 == 34.8
9/8/14 4:05 == 34.8
9/8/14 4:10 == 34.8
9/8/14 4:15 == 34.9
9/8/14 4:20 == 34.7
9/8/14 4:25 == 34.8
9/8/14 4:30 == 34.7
9/8/14 4:35 == 34.7
9/8/14 4:40 == 34.5
9/8/14 4:45 == 27.6
9/8/14 4:50 == 0
9/8/14 4:55 == 0
9/8/14 5:00 == 0
9/8/14 5:05 == 0
9/8/14 5:10 == 0
9/8/14 5:15 == 0
9/8/14 5:20 == 0
9/8/14 5:25 == 0
9/8/14 5:30 == #
9/8/14 5:35 == #
9/8/14 5:40 == 0
9/8/14 5:45 == 1.3
9/8/14 5:50 == 30.6
9/8/14 5:55 == 48.2
9/8/14 6:00 == 47.9
9/8/14 6:05 == 48.1
9/8/14 6:10 == 48.1
9/8/14 6:15 == 48.2
9/8/14 6:20 == 47.9
9/8/14 6:25 == 48
9/8/14 6:30 == 48
9/8/14 6:35 == 48
9/8/14 6:40 == 47.9
9/8/14 6:45 == 48
9/8/14 6:50 == 48.1
9/8/14 6:55 == 48.1
9/8/14 7:00 == 48.1
9/8/14 7:05 == 48
9/8/14 7:10 == 48.1
9/8/14 7:15 == 48.2
9/8/14 7:20 == 47.9
9/8/14 7:25 == 48
9/8/14 7:30 == 48
9/8/14 7:35 == 48.1
9/8/14 7:40 == 48.1
9/8/14 7:45 == 47.9
9/8/14 7:50 == 48.1
9/8/14 7:55 == 48
9/8/14 8:00 == 48
9/8/14 8:05 == 47.1
9/8/14 8:10 == 35.4
9/8/14 8:15 == 35.3
9/8/14 8:20 == 35.2
9/8/14 8:25 == 35.4
9/8/14 8:30 == 35.5
9/8/14 8:35 == 35.4
9/8/14 8:40 == 35.5
9/8/14 8:45 == 35.4
9/8/14 8:50 == 35.5
9/8/14 8:55 == 35.5
9/8/14 9:00 == 35.5
9/8/14 9:05 == 35.5
9/8/14 9:10 == 35.6
9/8/14 9:15 == 35.6
9/8/14 9:20 == 35.5
9/8/14 9:25 == 35.5
9/8/14 9:30 == 35.5
9/8/14 9:35 == 35.5
9/8/14 9:40 == 35.5
9/8/14 9:45 == 35.5
9/8/14 9:50 == 35.5
9/8/14 9:55 == 35.6
9/8/14 10:00 == 35.6
9/8/14 10:05 == 35.7
9/8/14 10:10 == 35.6
9/8/14 10:15 == 35.7
9/8/14 10:20 == 35.7
9/8/14 10:25 == 35.6
9/8/14 10:30 == 35.6
9/8/14 10:35 == 35.6
9/8/14 10:40 == 35.6
9/8/14 10:45 == 35.6
9/8/14 10:50 == 35.6
9/8/14 10:55 == 35.6
9/8/14 11:00 == 35.5
9/8/14 11:05 == 35.6
9/8/14 11:10 == 35.6
9/8/14 11:15 == 35.6
9/8/14 11:20 == 35.6
9/8/14 11:25 == 35.6
9/8/14 11:30 == 35.5
9/8/14 11:35 == 35.6
9/8/14 11:40 == 35.6
9/8/14 11:45 == 35.7
9/8/14 11:50 == 35.6
9/8/14 11:55 == 35.4
9/8/14 12:00 == 35.5
9/8/14 12:05 == 35.4
9/8/14 12:10 == 35.4
9/8/14 12:15 == 35.4
9/8/14 12:20 == 35.6
9/8/14 12:25 == 35.6
9/8/14 12:30 == 35.5
9/8/14 12:35 == 35.4
9/8/14 12:40 == 35.7
9/8/14 12:45 == 35.7
9/8/14 12:50 == 35.8
9/8/14 12:55 == 35.7
9/8/14 13:00 == 35.7
9/8/14 13:05 == 35.6
9/8/14 13:10 == 35.7
9/8/14 13:15 == 35.8
9/8/14 13:20 == 35.7
9/8/14 13:25 == 35.7
9/8/14 13:30 == 35.7
9/8/14 13:35 == 35.7
9/8/14 13:40 == 35.7
9/8/14 13:45 == 35.7
9/8/14 13:50 == 35.7
9/8/14 13:55 == 35.6
9/8/14 14:00 == 35.6
9/8/14 14:05 == 35.6
9/8/14 14:10 == 35.5
9/8/14 14:15 == 35.4
9/8/14 14:20 == 35.5
9/8/14 14:25 == 35.5
9/8/14 14:30 == 35.4
9/8/14 14:35 == 35.6
9/8/14 14:40 == 35.4
9/8/14 14:45 == 35.5
9/8/14 14:50 == 35.6
9/8/14 14:55 == 35.5
9/8/14 15:00 == 35.5
9/8/14 15:05 == 35.6
9/8/14 15:10 == 35.5
9/8/14 15:15 == 35.6

Pumpback Station Discharge (0364)

9/8/14 15:20 == 35.4
9/8/14 15:25 == 35.5
9/8/14 15:30 == 35.6
9/8/14 15:35 == 35.7
9/8/14 15:40 == 35.7
9/8/14 15:45 == 35.6
9/8/14 15:50 == 35.5
9/8/14 15:55 == 35.7
9/8/14 16:00 == 35.7
9/8/14 16:05 == 35.6
9/8/14 16:10 == 35.6
9/8/14 16:15 == 35.5
9/8/14 16:20 == 35.5
9/8/14 16:25 == 35.5
9/8/14 16:30 == 35.7
9/8/14 16:35 == 35.6
9/8/14 16:40 == 35.5
9/8/14 16:45 == 35.6
9/8/14 16:50 == 35.6
9/8/14 16:55 == 35.5
9/8/14 17:00 == 35.5
9/8/14 17:05 == 35.6
9/8/14 17:10 == 35.4
9/8/14 17:15 == 35.4
9/8/14 17:20 == 35.4
9/8/14 17:25 == 35.4
9/8/14 17:30 == 35.4
9/8/14 17:35 == 35.4
9/8/14 17:40 == 35.5
9/8/14 17:45 == 35.3
9/8/14 17:50 == 35.4
9/8/14 17:55 == 35.5
9/8/14 18:00 == 35.4
9/8/14 18:05 == 35.5
9/8/14 18:10 == 35.4
9/8/14 18:15 == 35.4
9/8/14 18:20 == 35.4
9/8/14 18:25 == 35.4
9/8/14 18:30 == 35.4
9/8/14 18:35 == 35.5
9/8/14 18:40 == 35.5
9/8/14 18:45 == 35.4
9/8/14 18:50 == 35.4
9/8/14 18:55 == 35.4
9/8/14 19:00 == 35.5
9/8/14 19:05 == 35.5
9/8/14 19:10 == 35.6
9/8/14 19:15 == 35.5
9/8/14 19:20 == 35.6
9/8/14 19:25 == 35.4
9/8/14 19:30 == 35.4
9/8/14 19:35 == 35.4
9/8/14 19:40 == 35.5
9/8/14 19:45 == 35.4
9/8/14 19:50 == 35.5
9/8/14 19:55 == 35.4
9/8/14 20:00 == 35.4
9/8/14 20:05 == 35.4
9/8/14 20:10 == 35.5
9/8/14 20:15 == 35.5
9/8/14 20:20 == 35.5
9/8/14 20:25 == 35.4
9/8/14 20:30 == 35.5
9/8/14 20:35 == 35.4
9/8/14 20:40 == 35.4
9/8/14 20:45 == 35.5
9/8/14 20:50 == 35.4
9/8/14 20:55 == 35.4
9/8/14 21:00 == 35.5
9/8/14 21:05 == 35.4
9/8/14 21:10 == 35.5
9/8/14 21:15 == 35.4
9/8/14 21:20 == 35.5
9/8/14 21:25 == 35.5
9/8/14 21:30 == 35.5
9/8/14 21:35 == 35.5
9/8/14 21:40 == 35.4
9/8/14 21:45 == 35.5
9/8/14 21:50 == 35.5
9/8/14 21:55 == 35.5
9/8/14 22:00 == 35.4
9/8/14 22:05 == 35.5
9/8/14 22:10 == 35.4
9/8/14 22:15 == 35.5
9/8/14 22:20 == 35.4
9/8/14 22:25 == 35.4
9/8/14 22:30 == 35.4
9/8/14 22:35 == 35.4
9/8/14 22:40 == 35.4
9/8/14 22:45 == 35.4
9/8/14 22:50 == 35.4
9/8/14 22:55 == 35.3
9/8/14 23:00 == 35.4
9/8/14 23:05 == 35.5
9/8/14 23:10 == 35.4
9/8/14 23:15 == 35.4
9/8/14 23:20 == 35.5
9/8/14 23:25 == 35.4
9/8/14 23:30 == 35.4
9/8/14 23:35 == 35.4
9/8/14 23:40 == 35.4
9/8/14 23:45 == 35.4
9/8/14 23:50 == 35.3
9/8/14 23:55 == 35.4
9/9/14 0:00 == 35.4
9/9/14 0:05 == 35.3
9/9/14 0:10 == 35.3
9/9/14 0:15 == 35.3
9/9/14 0:20 == 35.4
9/9/14 0:25 == 35.3
9/9/14 0:30 == 35.3
9/9/14 0:35 == 35.4
9/9/14 0:40 == 35.3
9/9/14 0:45 == 35.4
9/9/14 0:50 == 35.3
9/9/14 0:55 == 35.3
9/9/14 1:00 == 35.3
9/9/14 1:05 == 35.2
9/9/14 1:10 == 35.3
9/9/14 1:15 == 35.2
9/9/14 1:20 == 35.3
9/9/14 1:25 == 35.3
9/9/14 1:30 == 35.3
9/9/14 1:35 == 35.2
9/9/14 1:40 == 35.4
9/9/14 1:45 == 35.4
9/9/14 1:50 == 35.3
9/9/14 1:55 == 35.3
9/9/14 2:00 == 35.2
9/9/14 2:05 == 35.2
9/9/14 2:10 == 35.2
9/9/14 2:15 == 35.2
9/9/14 2:20 == 35.2
9/9/14 2:25 == 35.2
9/9/14 2:30 == 35.3
9/9/14 2:35 == 35.2
9/9/14 2:40 == 35.3
9/9/14 2:45 == 35.3
9/9/14 2:50 == 35.3
9/9/14 2:55 == 35.3
9/9/14 3:00 == 35.3
9/9/14 3:05 == 35.3
9/9/14 3:10 == 35.4
9/9/14 3:15 == 35.3
9/9/14 3:20 == 35.3
9/9/14 3:25 == 35.2
9/9/14 3:30 == 35.2
9/9/14 3:35 == 35.3
9/9/14 3:40 == 35.2
9/9/14 3:45 == 35.2
9/9/14 3:50 == 35.1
9/9/14 3:55 == 35.3
9/9/14 4:00 == 35.2
9/9/14 4:05 == 35.2
9/9/14 4:10 == 35.2
9/9/14 4:15 == 35.2
9/9/14 4:20 == 35.2
9/9/14 4:25 == 35.3
9/9/14 4:30 == 35.3
9/9/14 4:35 == 35.2
9/9/14 4:40 == 35.2
9/9/14 4:45 == 35.1
9/9/14 4:50 == 35.1
9/9/14 4:55 == 35.2
9/9/14 5:00 == 35.3
9/9/14 5:05 == 35.3
9/9/14 5:10 == 35.2
9/9/14 5:15 == 35.3
9/9/14 5:20 == 35.2
9/9/14 5:25 == 35.3
9/9/14 5:30 == 35.2
9/9/14 5:35 == 35.2
9/9/14 5:40 == 35.2
9/9/14 5:45 == 35.2
9/9/14 5:50 == 35.2
9/9/14 5:55 == 35.2
9/9/14 6:00 == 35.3
9/9/14 6:05 == 35.3
9/9/14 6:10 == 35.1
9/9/14 6:15 == 35.1
9/9/14 6:20 == 35.3
9/9/14 6:25 == 35.3
9/9/14 6:30 == 35.3
9/9/14 6:35 == 35.4
9/9/14 6:40 == 35.3
9/9/14 6:45 == 35.3
9/9/14 6:50 == 35.3
9/9/14 6:55 == 35.3
9/9/14 7:00 == 35.3
9/9/14 7:05 == 35.3
9/9/14 7:10 == 35.3
9/9/14 7:15 == 35.3
9/9/14 7:20 == 35.3
9/9/14 7:25 == 35.3
9/9/14 7:30 == 35.4
9/9/14 7:35 == 35.3
9/9/14 7:40 == 35.5
9/9/14 7:45 == 35.6
9/9/14 7:50 == 35.3
9/9/14 7:55 == 35.3
9/9/14 8:00 == 35.2
9/9/14 8:05 == 35.3
9/9/14 8:10 == 35.3
9/9/14 8:15 == 35.3
9/9/14 8:20 == 35.3
9/9/14 8:25 == 35.4
9/9/14 8:30 == 35.5
9/9/14 8:35 == 35.3
9/9/14 8:40 == 35.3
9/9/14 8:45 == 35.4
9/9/14 8:50 == 35.3
9/9/14 8:55 == 35.4
9/9/14 9:00 == 35.4
9/9/14 9:05 == 35.3
9/9/14 9:10 == 35.5
9/9/14 9:15 == 35.5
9/9/14 9:20 == 35.4
9/9/14 9:25 == 35.5
9/9/14 9:30 == 35.4
9/9/14 9:35 == 35.5

Pumpback Station Discharge (0364)

9/9/14 9:40 == 35.6
9/9/14 9:45 == 35.5
9/9/14 9:50 == 35.6
9/9/14 9:55 == 35.7
9/9/14 10:00 == 35.6
9/9/14 10:05 == 35.5
9/9/14 10:10 == 35.7
9/9/14 10:15 == 35.7
9/9/14 10:20 == 35.7
9/9/14 10:25 == 35.7
9/9/14 10:30 == 35.7
9/9/14 10:35 == 35.6
9/9/14 10:40 == 35.6
9/9/14 10:45 == 35.7
9/9/14 10:50 == 35.7
9/9/14 10:55 == 35.6
9/9/14 11:00 == 35.8
9/9/14 11:05 == 35.7
9/9/14 11:10 == 35.6
9/9/14 11:15 == 35.8
9/9/14 11:20 == 35.7
9/9/14 11:25 == 35.7
9/9/14 11:30 == 35.5
9/9/14 11:35 == 35.7
9/9/14 11:40 == 35.7
9/9/14 11:45 == 35.7
9/9/14 11:50 == 35.6
9/9/14 11:55 == 35.7
9/9/14 12:00 == 35.6
9/9/14 12:05 == 35.6
9/9/14 12:10 == 35.8
9/9/14 12:15 == 35.6
9/9/14 12:20 == 35.5
9/9/14 12:25 == 35.6
9/9/14 12:30 == 35.6
9/9/14 12:35 == 35.6
9/9/14 12:40 == 35.6
9/9/14 12:45 == 35.6
9/9/14 12:50 == 35.6
9/9/14 12:55 == 35.6
9/9/14 13:00 == 35.5
9/9/14 13:05 == 35.7
9/9/14 13:10 == 35.7
9/9/14 13:15 == 35.7
9/9/14 13:20 == 35.6
9/9/14 13:25 == 35.7
9/9/14 13:30 == 35.6
9/9/14 13:35 == 35.7
9/9/14 13:40 == 35.6
9/9/14 13:45 == 35.7
9/9/14 13:50 == 35.6
9/9/14 13:55 == 35.6
9/9/14 14:00 == 35.6
9/9/14 14:05 == 35.7
9/9/14 14:10 == 35.7
9/9/14 14:15 == 35.8
9/9/14 14:20 == 35.8
9/9/14 14:25 == 35.6
9/9/14 14:30 == 35.7
9/9/14 14:35 == 35.8
9/9/14 14:40 == 35.6
9/9/14 14:45 == 35.7
9/9/14 14:50 == 35.5
9/9/14 14:55 == 35.6
9/9/14 15:00 == 35.6
9/9/14 15:05 == 35.5
9/9/14 15:10 == 35.4
9/9/14 15:15 == 35.6
9/9/14 15:20 == 35.4
9/9/14 15:25 == 35.5
9/9/14 15:30 == 35.5
9/9/14 15:35 == 35.5
9/9/14 15:40 == 35.7
9/9/14 15:45 == 35.4
9/9/14 15:50 == 35.4
9/9/14 15:55 == 35.3
9/9/14 16:00 == 35.4
9/9/14 16:05 == 35.7
9/9/14 16:10 == 35.4
9/9/14 16:15 == 35.5
9/9/14 16:20 == 35.4
9/9/14 16:25 == 35.5
9/9/14 16:30 == 35.4
9/9/14 16:35 == 35.4
9/9/14 16:40 == 35.5
9/9/14 16:45 == 35.4
9/9/14 16:50 == 35.3
9/9/14 16:55 == 35.4
9/9/14 17:00 == 35.5
9/9/14 17:05 == 35.6
9/9/14 17:10 == 35.5
9/9/14 17:15 == 35.5
9/9/14 17:20 == 35.5
9/9/14 17:25 == 35.4
9/9/14 17:30 == 35.5
9/9/14 17:35 == 35.5
9/9/14 17:40 == 35.5
9/9/14 17:45 == 35.4
9/9/14 17:50 == 35.4
9/9/14 17:55 == 35.3
9/9/14 18:00 == 35.4
9/9/14 18:05 == 35.5
9/9/14 18:10 == 35.5
9/9/14 18:15 == 35.4
9/9/14 18:20 == 35.4
9/9/14 18:25 == 35.5
9/9/14 18:30 == 35.6
9/9/14 18:35 == 35.5
9/9/14 18:40 == 35.5
9/9/14 18:45 == 35.5
9/9/14 18:50 == 35.4
9/9/14 18:55 == 35.5
9/9/14 19:00 == 35.5
9/9/14 19:05 == 35.6
9/9/14 19:10 == 35.4
9/9/14 19:15 == 35.5
9/9/14 19:20 == 35.5
9/9/14 19:25 == 35.4
9/9/14 19:30 == 35.3
9/9/14 19:35 == 35.4
9/9/14 19:40 == 35.2
9/9/14 19:45 == 35.2
9/9/14 19:50 == 35.2
9/9/14 19:55 == 35.3
9/9/14 20:00 == 35.2
9/9/14 20:05 == 35.1
9/9/14 20:10 == 35.2
9/9/14 20:15 == 35.2
9/9/14 20:20 == 35
9/9/14 20:25 == 35.1
9/9/14 20:30 == 35.1
9/9/14 20:35 == 35
9/9/14 20:40 == 34.9
9/9/14 20:45 == 35.1
9/9/14 20:50 == 35
9/9/14 20:55 == 35
9/9/14 21:00 == 35.1
9/9/14 21:05 == 35
9/9/14 21:10 == 35.1
9/9/14 21:15 == 35
9/9/14 21:20 == 35
9/9/14 21:25 == 35.1
9/9/14 21:30 == 35
9/9/14 21:35 == 35
9/9/14 21:40 == 35
9/9/14 21:45 == 35.1
9/9/14 21:50 == 35.1
9/9/14 21:55 == 35.2
9/9/14 22:00 == 35.1
9/9/14 22:05 == 35
9/9/14 22:10 == 35
9/9/14 22:15 == 35
9/9/14 22:20 == 35
9/9/14 22:25 == 35
9/9/14 22:30 == 34.9
9/9/14 22:35 == 34.9
9/9/14 22:40 == 35
9/9/14 22:45 == 35
9/9/14 22:50 == 35
9/9/14 22:55 == 35
9/9/14 23:00 == 35
9/9/14 23:05 == 34.9
9/9/14 23:10 == 35
9/9/14 23:15 == 34.9
9/9/14 23:20 == 35.1
9/9/14 23:25 == 35
9/9/14 23:30 == 35
9/9/14 23:35 == 35
9/9/14 23:40 == 34.9
9/9/14 23:45 == 35
9/9/14 23:50 == 35
9/9/14 23:55 == 35
9/10/14 0:00 == 34.9
9/10/14 0:05 == 34.9
9/10/14 0:10 == 34.9
9/10/14 0:15 == 35
9/10/14 0:20 == 35.1
9/10/14 0:25 == 35
9/10/14 0:30 == 35
9/10/14 0:35 == 34.9
9/10/14 0:40 == 34.8
9/10/14 0:45 == 34.8
9/10/14 0:50 == 34.9
9/10/14 0:55 == 34.9
9/10/14 1:00 == 34.9
9/10/14 1:05 == 34.9
9/10/14 1:10 == 34.9
9/10/14 1:15 == 34.9
9/10/14 1:20 == 34.9
9/10/14 1:25 == 34.9
9/10/14 1:30 == 34.9
9/10/14 1:35 == 34.8
9/10/14 1:40 == 34.8
9/10/14 1:45 == 34.8
9/10/14 1:50 == 34.8
9/10/14 1:55 == 34.8
9/10/14 2:00 == 34.8
9/10/14 2:05 == 34.7
9/10/14 2:10 == 34.7
9/10/14 2:15 == 34.7
9/10/14 2:20 == 34.6
9/10/14 2:25 == 34.7
9/10/14 2:30 == 34.6
9/10/14 2:35 == 34.6
9/10/14 2:40 == 34.7
9/10/14 2:45 == 34.6
9/10/14 2:50 == 34.6
9/10/14 2:55 == 34.6
9/10/14 3:00 == 34.7
9/10/14 3:05 == 34.6
9/10/14 3:10 == 34.7
9/10/14 3:15 == 34.7
9/10/14 3:20 == 34.6
9/10/14 3:25 == 34.6
9/10/14 3:30 == 34.6
9/10/14 3:35 == 34.6
9/10/14 3:40 == 34.6
9/10/14 3:45 == 34.6
9/10/14 3:50 == 34.5
9/10/14 3:55 == 34.6

Pumpback Station Discharge (0364)

9/10/14 4:00 == 34.5
9/10/14 4:05 == 34.6
9/10/14 4:10 == 34.7
9/10/14 4:15 == 34.6
9/10/14 4:20 == 34.6
9/10/14 4:25 == 34.6
9/10/14 4:30 == 34.5
9/10/14 4:35 == 34.5
9/10/14 4:40 == 34.4
9/10/14 4:45 == 34.5
9/10/14 4:50 == 34.5
9/10/14 4:55 == 34.6
9/10/14 5:00 == 34.6
9/10/14 5:05 == 34.5
9/10/14 5:10 == 34.5
9/10/14 5:15 == 34.5
9/10/14 5:20 == 34.5
9/10/14 5:25 == 34.6
9/10/14 5:30 == 34.6
9/10/14 5:35 == 34.5
9/10/14 5:40 == 34.7
9/10/14 5:45 == 34.5
9/10/14 5:50 == 34.5
9/10/14 5:55 == 34.5
9/10/14 6:00 == 34.6
9/10/14 6:05 == 34.5
9/10/14 6:10 == 34.6
9/10/14 6:15 == 34.6
9/10/14 6:20 == 34.6
9/10/14 6:25 == 34.6
9/10/14 6:30 == 34.5
9/10/14 6:35 == 34.6
9/10/14 6:40 == 34.7
9/10/14 6:45 == 34.6
9/10/14 6:50 == 34.6
9/10/14 6:55 == 34.6
9/10/14 7:00 == 34.7
9/10/14 7:05 == 34.5
9/10/14 7:10 == 34.6
9/10/14 7:15 == 34.5
9/10/14 7:20 == 34.5
9/10/14 7:25 == 34.5
9/10/14 7:30 == 34.6
9/10/14 7:35 == 34.6
9/10/14 7:40 == 34.6
9/10/14 7:45 == 34.5
9/10/14 7:50 == 34.6
9/10/14 7:55 == 34.6
9/10/14 8:00 == 34.6
9/10/14 8:05 == 34.7
9/10/14 8:10 == 34.8
9/10/14 8:15 == 34.6
9/10/14 8:20 == 34.8
9/10/14 8:25 == 34.6
9/10/14 8:30 == 34.6
9/10/14 8:35 == 34.7
9/10/14 8:40 == 34.7
9/10/14 8:45 == 34.8
9/10/14 8:50 == 34.6
9/10/14 8:55 == 34.7
9/10/14 9:00 == 34.8
9/10/14 9:05 == 34.7
9/10/14 9:10 == 34.6
9/10/14 9:15 == 34.6
9/10/14 9:20 == 34.9
9/10/14 9:25 == 34.9
9/10/14 9:30 == 34.7
9/10/14 9:35 == 34.7
9/10/14 9:40 == 34.7
9/10/14 9:45 == 34.6
9/10/14 9:50 == 34.8
9/10/14 9:55 == 34.9
9/10/14 10:00 == 34.8
9/10/14 10:05 == 34.6
9/10/14 10:10 == 34.7
9/10/14 10:15 == 34.7
9/10/14 10:20 == 34.8
9/10/14 10:25 == 34.6
9/10/14 10:30 == 34.7
9/10/14 10:35 == 34.6
9/10/14 10:40 == 34.6
9/10/14 10:45 == 34.7
9/10/14 10:50 == 34.8
9/10/14 10:55 == 34.7
9/10/14 11:00 == 34.8
9/10/14 11:05 == 34.8
9/10/14 11:10 == 34.9
9/10/14 11:15 == 34.8
9/10/14 11:20 == 34.8
9/10/14 11:25 == 34.8
9/10/14 11:30 == 34.8
9/10/14 11:35 == 34.8
9/10/14 11:40 == 34.7
9/10/14 11:45 == 34.7
9/10/14 11:50 == 34.8
9/10/14 11:55 == 34.7
9/10/14 12:00 == 34.8
9/10/14 12:05 == 34.9
9/10/14 12:10 == 34.7
9/10/14 12:15 == 34.7
9/10/14 12:20 == 34.7
9/10/14 12:25 == 34.7
9/10/14 12:30 == 34.5
9/10/14 12:35 == 34.4
9/10/14 12:40 == 34.7
9/10/14 12:45 == 34.7
9/10/14 12:50 == 34.6
9/10/14 12:55 == 34.5
9/10/14 13:00 == 34.7
9/10/14 13:05 == 34.7
9/10/14 13:10 == 34.8
9/10/14 13:15 == 34.8
9/10/14 13:20 == 34.7
9/10/14 13:25 == 34.7
9/10/14 13:30 == 34.7
9/10/14 13:35 == 34.7
9/10/14 13:40 == 34.9
9/10/14 13:45 == 34.7
9/10/14 13:50 == 34.6
9/10/14 13:55 == 34.8
9/10/14 14:00 == 34.6
9/10/14 14:05 == 34.4
9/10/14 14:10 == 34.5
9/10/14 14:15 == 34.5
9/10/14 14:20 == 34.5
9/10/14 14:25 == 34.8
9/10/14 14:30 == 34.7
9/10/14 14:35 == 34.7
9/10/14 14:40 == 34.7
9/10/14 14:45 == 34.7
9/10/14 14:50 == 34.7
9/10/14 14:55 == 34.8
9/10/14 15:00 == 34.7
9/10/14 15:05 == 34.7
9/10/14 15:10 == 34.9
9/10/14 15:15 == 34.9
9/10/14 15:20 == 34.8
9/10/14 15:25 == 34.8
9/10/14 15:30 == 34.7
9/10/14 15:35 == 34.8
9/10/14 15:40 == 34.8
9/10/14 15:45 == 34.8
9/10/14 15:50 == 34.7
9/10/14 15:55 == 34.8
9/10/14 16:00 == 34.7
9/10/14 16:05 == 34.9
9/10/14 16:10 == 34.9
9/10/14 16:15 == 34.9
9/10/14 16:20 == 35
9/10/14 16:25 == 34.8
9/10/14 16:30 == 34.7
9/10/14 16:35 == 34.9
9/10/14 16:40 == 34.9
9/10/14 16:45 == 34.8
9/10/14 16:50 == 34.8
9/10/14 16:55 == 34.7
9/10/14 17:00 == 34.7
9/10/14 17:05 == 34.8
9/10/14 17:10 == 35
9/10/14 17:15 == 34.9
9/10/14 17:20 == 34.8
9/10/14 17:25 == 34.7
9/10/14 17:30 == 34.8
9/10/14 17:35 == 34.7
9/10/14 17:40 == 34.8
9/10/14 17:45 == 34.8
9/10/14 17:50 == 34.9
9/10/14 17:55 == 34.8
9/10/14 18:00 == 34.8
9/10/14 18:05 == 34.9
9/10/14 18:10 == 34.8
9/10/14 18:15 == 34.9
9/10/14 18:20 == 34.8
9/10/14 18:25 == 34.8
9/10/14 18:30 == 34.8
9/10/14 18:35 == 34.9
9/10/14 18:40 == 34.8
9/10/14 18:45 == 34.8
9/10/14 18:50 == 34.8
9/10/14 18:55 == 34.8
9/10/14 19:00 == 34.9
9/10/14 19:05 == 34.8
9/10/14 19:10 == 34.8
9/10/14 19:15 == 34.9
9/10/14 19:20 == 34.8
9/10/14 19:25 == 34.7
9/10/14 19:30 == 34.7
9/10/14 19:35 == 34.8
9/10/14 19:40 == 34.8
9/10/14 19:45 == 34.7
9/10/14 19:50 == 34.7
9/10/14 19:55 == 34.8
9/10/14 20:00 == 34.8
9/10/14 20:05 == 34.7
9/10/14 20:10 == 34.8
9/10/14 20:15 == 34.8
9/10/14 20:20 == 34.8
9/10/14 20:25 == 34.8
9/10/14 20:30 == 34.8
9/10/14 20:35 == 34.7
9/10/14 20:40 == 34.8
9/10/14 20:45 == 34.7
9/10/14 20:50 == 34.7
9/10/14 20:55 == 34.8
9/10/14 21:00 == 34.8
9/10/14 21:05 == 34.8
9/10/14 21:10 == 34.7
9/10/14 21:15 == 34.7
9/10/14 21:20 == 34.9
9/10/14 21:25 == 34.8
9/10/14 21:30 == 34.8
9/10/14 21:35 == 34.8
9/10/14 21:40 == 34.9
9/10/14 21:45 == 34.8
9/10/14 21:50 == 34.8
9/10/14 21:55 == 34.7
9/10/14 22:00 == 34.7
9/10/14 22:05 == 34.7
9/10/14 22:10 == 34.6
9/10/14 22:15 == 34.6

Pumpback Station Discharge (0364)

9/10/14 22:20 == 34.6
9/10/14 22:25 == 34.8
9/10/14 22:30 == 34.6
9/10/14 22:35 == 34.7
9/10/14 22:40 == 34.7
9/10/14 22:45 == 34.7
9/10/14 22:50 == 34.7
9/10/14 22:55 == 34.7
9/10/14 23:00 == 34.7
9/10/14 23:05 == 34.7
9/10/14 23:10 == 34.8
9/10/14 23:15 == 34.8
9/10/14 23:20 == 34.7
9/10/14 23:25 == 34.7
9/10/14 23:30 == 34.8
9/10/14 23:35 == 34.8
9/10/14 23:40 == 34.7
9/10/14 23:45 == 34.8
9/10/14 23:50 == 34.7
9/10/14 23:55 == 34.8
9/11/14 0:00 == 34.7
9/11/14 0:05 == 34.7
9/11/14 0:10 == 34.7
9/11/14 0:15 == 34.7
9/11/14 0:20 == 34.6
9/11/14 0:25 == 34.7
9/11/14 0:30 == 34.7
9/11/14 0:35 == 34.6
9/11/14 0:40 == 34.6
9/11/14 0:45 == 34.6
9/11/14 0:50 == 34.6
9/11/14 0:55 == 34.7
9/11/14 1:00 == 34.6
9/11/14 1:05 == 34.6
9/11/14 1:10 == 34.5
9/11/14 1:15 == 34.5
9/11/14 1:20 == 34.5
9/11/14 1:25 == 34.5
9/11/14 1:30 == 34.6
9/11/14 1:35 == 34.5
9/11/14 1:40 == 34.6
9/11/14 1:45 == 34.6
9/11/14 1:50 == 34.6
9/11/14 1:55 == 34.6
9/11/14 2:00 == 34.6
9/11/14 2:05 == 34.6
9/11/14 2:10 == 34.5
9/11/14 2:15 == 34.5
9/11/14 2:20 == 34.6
9/11/14 2:25 == 34.6
9/11/14 2:30 == 34.6
9/11/14 2:35 == 34.6
9/11/14 2:40 == 34.5
9/11/14 2:45 == 34.5
9/11/14 2:50 == 34.5
9/11/14 2:55 == 34.5
9/11/14 3:00 == 34.6
9/11/14 3:05 == 34.5
9/11/14 3:10 == 34.5
9/11/14 3:15 == 34.5
9/11/14 3:20 == 34.5
9/11/14 3:25 == 34.5
9/11/14 3:30 == 34.3
9/11/14 3:35 == 34.4
9/11/14 3:40 == 34.5
9/11/14 3:45 == 34.4
9/11/14 3:50 == 34.5
9/11/14 3:55 == 34.4
9/11/14 4:00 == 34.5
9/11/14 4:05 == 34.5
9/11/14 4:10 == 34.4
9/11/14 4:15 == 34.5
9/11/14 4:20 == 34.5
9/11/14 4:25 == 34.5
9/11/14 4:30 == 34.5
9/11/14 4:35 == 34.4
9/11/14 4:40 == 34.5
9/11/14 4:45 == 34.5
9/11/14 4:50 == 34.4
9/11/14 4:55 == 34.5
9/11/14 5:00 == 34.6
9/11/14 5:05 == 34.6
9/11/14 5:10 == 34.6
9/11/14 5:15 == 34.6
9/11/14 5:20 == 34.6
9/11/14 5:25 == 34.6
9/11/14 5:30 == 34.7
9/11/14 5:35 == 34.6
9/11/14 5:40 == 34.7
9/11/14 5:45 == 34.6
9/11/14 5:50 == 34.5
9/11/14 5:55 == 34.5
9/11/14 6:00 == 34.5
9/11/14 6:05 == 34.5
9/11/14 6:10 == 34.6
9/11/14 6:15 == 34.6
9/11/14 6:20 == 34.6
9/11/14 6:25 == 34.5
9/11/14 6:30 == 34.7
9/11/14 6:35 == 34.7
9/11/14 6:40 == 34.5
9/11/14 6:45 == 34.6
9/11/14 6:50 == 34.6
9/11/14 6:55 == 34.7
9/11/14 7:00 == 34.8
9/11/14 7:05 == 34.5
9/11/14 7:10 == 34.6
9/11/14 7:15 == 34.5
9/11/14 7:20 == 34.7
9/11/14 7:25 == 34.5
9/11/14 7:30 == 34.6
9/11/14 7:35 == 34.5
9/11/14 7:40 == 34.6
9/11/14 7:45 == 34.6
9/11/14 7:50 == 34.5
9/11/14 7:55 == 34.6
9/11/14 8:00 == 34.5
9/11/14 8:05 == 34.7
9/11/14 8:10 == 34.5
9/11/14 8:15 == 34.5
9/11/14 8:20 == 34.8
9/11/14 8:25 == 34.6
9/11/14 8:30 == 34.7
9/11/14 8:35 == 34.6
9/11/14 8:40 == 34.6
9/11/14 8:45 == 34.6
9/11/14 8:50 == 34.6
9/11/14 8:55 == 34.8
9/11/14 9:00 == 34.4
9/11/14 9:05 == 34.4
9/11/14 9:10 == 34.7
9/11/14 9:15 == 34.6
9/11/14 9:20 == 34.6
9/11/14 9:25 == 34.5
9/11/14 9:30 == 34.6
9/11/14 9:35 == 34.5
9/11/14 9:40 == 34.7
9/11/14 9:45 == 34.6
9/11/14 9:50 == 34.6
9/11/14 9:55 == 34.7
9/11/14 10:00 == 34.7
9/11/14 10:05 == 34.4
9/11/14 10:10 == 34.1
9/11/14 10:15 == 33.7
9/11/14 10:20 == 33.5
9/11/14 10:25 == 33.7
9/11/14 10:30 == 34.2
9/11/14 10:35 == 34.7
9/11/14 10:40 == 34.7
9/11/14 10:45 == 34.9
9/11/14 10:50 == 34.8
9/11/14 10:55 == 34.8
9/11/14 11:00 == 34.8
9/11/14 11:05 == 34.8
9/11/14 11:10 == 34.8
9/11/14 11:15 == 34.6
9/11/14 11:20 == 34
9/11/14 11:25 == 33.7
9/11/14 11:30 == 33.5
9/11/14 11:35 == 33.4
9/11/14 11:40 == 33.5
9/11/14 11:45 == 33.6
9/11/14 11:50 == 34.7
9/11/14 11:55 == 34.9
9/11/14 12:00 == 35
9/11/14 12:05 == 35
9/11/14 12:10 == 34.9
9/11/14 12:15 == 34.9
9/11/14 12:20 == 34.9
9/11/14 12:25 == 35.1
9/11/14 12:30 == 34.9
9/11/14 12:35 == 34.9
9/11/14 12:40 == 34.9
9/11/14 12:45 == 34.9
9/11/14 12:50 == 34.9
9/11/14 12:55 == 35
9/11/14 13:00 == 35.1
9/11/14 13:05 == 34.9
9/11/14 13:10 == 35.2
9/11/14 13:15 == 34.9
9/11/14 13:20 == 34.9
9/11/14 13:25 == 34.8
9/11/14 13:30 == 35
9/11/14 13:35 == 35
9/11/14 13:40 == 34.8
9/11/14 13:45 == 35
9/11/14 13:50 == 34.9
9/11/14 13:55 == 34.9
9/11/14 14:00 == 34.9
9/11/14 14:05 == 35
9/11/14 14:10 == 34.9
9/11/14 14:15 == 35.1
9/11/14 14:20 == 35
9/11/14 14:25 == 35
9/11/14 14:30 == 34.9
9/11/14 14:35 == 34.9
9/11/14 14:40 == 34.8
9/11/14 14:45 == 34.9
9/11/14 14:50 == 34.9
9/11/14 14:55 == 34.8
9/11/14 15:00 == 35
9/11/14 15:05 == 34.9
9/11/14 15:10 == 35
9/11/14 15:15 == 34.8
9/11/14 15:20 == 34.9
9/11/14 15:25 == 34.8
9/11/14 15:30 == 34.8
9/11/14 15:35 == 34.7
9/11/14 15:40 == 34.8
9/11/14 15:45 == 34.8
9/11/14 15:50 == 34.8
9/11/14 15:55 == 34.9
9/11/14 16:00 == 34.8
9/11/14 16:05 == 34.8
9/11/14 16:10 == 34.6
9/11/14 16:15 == 34.7
9/11/14 16:20 == 34.9
9/11/14 16:25 == 34.8
9/11/14 16:30 == 34.7
9/11/14 16:35 == 34.8

Pumpback Station Discharge (0364)

9/11/14 16:40 == 34.7
9/11/14 16:45 == 34.8
9/11/14 16:50 == 34.7
9/11/14 16:55 == 34.8
9/11/14 17:00 == 34.7
9/11/14 17:05 == 34.8
9/11/14 17:10 == 34.8
9/11/14 17:15 == 34.7
9/11/14 17:20 == 34.8
9/11/14 17:25 == 34.8
9/11/14 17:30 == 34.9
9/11/14 17:35 == 34.8
9/11/14 17:40 == 34.7
9/11/14 17:45 == 34.9
9/11/14 17:50 == 34.9
9/11/14 17:55 == 34.8
9/11/14 18:00 == 34.8
9/11/14 18:05 == 34.8
9/11/14 18:10 == 34.8
9/11/14 18:15 == 34.8
9/11/14 18:20 == 34.9
9/11/14 18:25 == 35
9/11/14 18:30 == 34.9
9/11/14 18:35 == 34.9
9/11/14 18:40 == 34.9
9/11/14 18:45 == 34.9
9/11/14 18:50 == 34.8
9/11/14 18:55 == 34.9
9/11/14 19:00 == 35
9/11/14 19:05 == 34.9
9/11/14 19:10 == 34.9
9/11/14 19:15 == 34.8
9/11/14 19:20 == 35
9/11/14 19:25 == 35.1
9/11/14 19:30 == 34.9
9/11/14 19:35 == 35
9/11/14 19:40 == 34.9
9/11/14 19:45 == 35
9/11/14 19:50 == 34.9
9/11/14 19:55 == 35
9/11/14 20:00 == 35
9/11/14 20:05 == 35
9/11/14 20:10 == 34.9
9/11/14 20:15 == 34.9
9/11/14 20:20 == 34.9
9/11/14 20:25 == 34.9
9/11/14 20:30 == 34.9
9/11/14 20:35 == 34.8
9/11/14 20:40 == 34.9
9/11/14 20:45 == 34.8
9/11/14 20:50 == 34.9
9/11/14 20:55 == 34.9
9/11/14 21:00 == 34.9
9/11/14 21:05 == 34.9
9/11/14 21:10 == 34.9
9/11/14 21:15 == 34.8
9/11/14 21:20 == 35
9/11/14 21:25 == 34.9
9/11/14 21:30 == 34.9
9/11/14 21:35 == 34.9
9/11/14 21:40 == 35
9/11/14 21:45 == 34.9
9/11/14 21:50 == 34.9
9/11/14 21:55 == 34.9
9/11/14 22:00 == 34.9
9/11/14 22:05 == 34.9
9/11/14 22:10 == 34.9
9/11/14 22:15 == 35
9/11/14 22:20 == 34.9
9/11/14 22:25 == 34.9
9/11/14 22:30 == 35
9/11/14 22:35 == 34.9
9/11/14 22:40 == #
9/11/14 22:45 == 34.9
9/11/14 22:50 == 34.9
9/11/14 22:55 == 34.9
9/11/14 23:00 == 34.8
9/11/14 23:05 == 35
9/11/14 23:10 == 35
9/11/14 23:15 == 35
9/11/14 23:20 == 35
9/11/14 23:25 == 35
9/11/14 23:30 == 35
9/11/14 23:35 == 35
9/11/14 23:40 == 34.9
9/11/14 23:45 == 34.9
9/11/14 23:50 == 34.9
9/11/14 23:55 == 34.9
9/12/14 0:00 == 34.9
9/12/14 0:05 == 34.9
9/12/14 0:10 == 34.9
9/12/14 0:15 == 35
9/12/14 0:20 == 34.9
9/12/14 0:25 == 35
9/12/14 0:30 == 34.9
9/12/14 0:35 == 34.9
9/12/14 0:40 == 34.9
9/12/14 0:45 == 34.9
9/12/14 0:50 == 34.8
9/12/14 0:55 == 34.9
9/12/14 1:00 == 34.8
9/12/14 1:05 == 34.8
9/12/14 1:10 == 34.9
9/12/14 1:15 == 34.9
9/12/14 1:20 == 34.9
9/12/14 1:25 == 34.9
9/12/14 1:30 == 34.9
9/12/14 1:35 == 34.8
9/12/14 1:40 == 34.8
9/12/14 1:45 == 34.9
9/12/14 1:50 == 34.8
9/12/14 1:55 == 34.9
9/12/14 2:00 == 34.8
9/12/14 2:05 == 34.8
9/12/14 2:10 == 34.9
9/12/14 2:15 == 34.9
9/12/14 2:20 == 34.9
9/12/14 2:25 == 34.8
9/12/14 2:30 == 34.8
9/12/14 2:35 == 34.8
9/12/14 2:40 == 34.9
9/12/14 2:45 == 34.8
9/12/14 2:50 == 34.8
9/12/14 2:55 == 34.9
9/12/14 3:00 == 34.8
9/12/14 3:05 == 34.8
9/12/14 3:10 == 34.8
9/12/14 3:15 == 34.9
9/12/14 3:20 == 34.9
9/12/14 3:25 == 34.9
9/12/14 3:30 == 35
9/12/14 3:35 == 34.8
9/12/14 3:40 == 34.9
9/12/14 3:45 == 34.9
9/12/14 3:50 == 34.9
9/12/14 3:55 == 35
9/12/14 4:00 == 34.9
9/12/14 4:05 == 34.8
9/12/14 4:10 == 34.9
9/12/14 4:15 == 35
9/12/14 4:20 == 34.9
9/12/14 4:25 == 34.9
9/12/14 4:30 == 34.9
9/12/14 4:35 == 34.9
9/12/14 4:40 == 34.8
9/12/14 4:45 == 34.9
9/12/14 4:50 == 34.9
9/12/14 4:55 == 34.9
9/12/14 5:00 == 34.9
9/12/14 5:05 == 34.9
9/12/14 5:10 == 34.9
9/12/14 5:15 == 34.9
9/12/14 5:20 == 34.9
9/12/14 5:25 == 35
9/12/14 5:30 == 34.9
9/12/14 5:35 == 35.1
9/12/14 5:40 == 35.1
9/12/14 5:45 == 35
9/12/14 5:50 == 35
9/12/14 5:55 == 34.9
9/12/14 6:00 == 35
9/12/14 6:05 == 34.9
9/12/14 6:10 == 34.8
9/12/14 6:15 == 35
9/12/14 6:20 == 34.8
9/12/14 6:25 == 34.9
9/12/14 6:30 == 34.8
9/12/14 6:35 == 34.9
9/12/14 6:40 == 35.1
9/12/14 6:45 == 35
9/12/14 6:50 == 35
9/12/14 6:55 == 34.9
9/12/14 7:00 == 35
9/12/14 7:05 == 35
9/12/14 7:10 == 35
9/12/14 7:15 == 35.1
9/12/14 7:20 == 35.1
9/12/14 7:25 == 35
9/12/14 7:30 == 35.4
9/12/14 7:35 == 35.2
9/12/14 7:40 == 35.1
9/12/14 7:45 == 35.4
9/12/14 7:50 == 35
9/12/14 7:55 == 35.2
9/12/14 8:00 == 35.1
9/12/14 8:05 == 35.2
9/12/14 8:10 == 35.2
9/12/14 8:15 == 35.1
9/12/14 8:20 == 35.1
9/12/14 8:25 == 35.3
9/12/14 8:30 == 35.6
9/12/14 8:35 == 35.5
9/12/14 8:40 == 35.2
9/12/14 8:45 == 35.3
9/12/14 8:50 == 35.3
9/12/14 8:55 == 35.4
9/12/14 9:00 == 35.4
9/12/14 9:05 == 35.5
9/12/14 9:10 == 35.6
9/12/14 9:15 == 34.7
9/12/14 9:20 == 35
9/12/14 9:25 == 35.2
9/12/14 9:30 == 35.3
9/12/14 9:35 == 35.4
9/12/14 9:40 == 35.3
9/12/14 9:45 == 35.5
9/12/14 9:50 == 35.6
9/12/14 9:55 == 35.7
9/12/14 10:00 == 35.6
9/12/14 10:05 == 35.6
9/12/14 10:10 == 35.6
9/12/14 10:15 == 35.7
9/12/14 10:20 == 35.6
9/12/14 10:25 == 35.7
9/12/14 10:30 == 35.7
9/12/14 10:35 == 35.7
9/12/14 10:40 == 35.6
9/12/14 10:45 == 35.6
9/12/14 10:50 == 35.7
9/12/14 10:55 == 35.6

Pumpback Station Discharge (0364)

9/12/14 11:00 == 35.8
9/12/14 11:05 == 35.6
9/12/14 11:10 == 35.8
9/12/14 11:15 == 35.9
9/12/14 11:20 == 35.7
9/12/14 11:25 == 35.7
9/12/14 11:30 == 35.8
9/12/14 11:35 == 35.7
9/12/14 11:40 == 35.7
9/12/14 11:45 == 35.6
9/12/14 11:50 == 35.7
9/12/14 11:55 == 35.7
9/12/14 12:00 == 35.9
9/12/14 12:05 == 36.1
9/12/14 12:10 == 35.9
9/12/14 12:15 == 36
9/12/14 12:20 == 35.9
9/12/14 12:25 == 36
9/12/14 12:30 == 35.9
9/12/14 12:35 == 36
9/12/14 12:40 == 35.9
9/12/14 12:45 == 36
9/12/14 12:50 == 36.1
9/12/14 12:55 == 35.8
9/12/14 13:00 == 36
9/12/14 13:05 == 35.9
9/12/14 13:10 == 36
9/12/14 13:15 == 35.9
9/12/14 13:20 == 35.8
9/12/14 13:25 == 36
9/12/14 13:30 == 36
9/12/14 13:35 == 36
9/12/14 13:40 == 36
9/12/14 13:45 == 35.8
9/12/14 13:50 == 35.8
9/12/14 13:55 == 35.8
9/12/14 14:00 == 35.9
9/12/14 14:05 == 35.8
9/12/14 14:10 == 35.8
9/12/14 14:15 == 35.8
9/12/14 14:20 == 35.8
9/12/14 14:25 == 35.8
9/12/14 14:30 == 36
9/12/14 14:35 == 35.8
9/12/14 14:40 == 35.9
9/12/14 14:45 == 35.8
9/12/14 14:50 == 35.9
9/12/14 14:55 == 35.9
9/12/14 15:00 == 36
9/12/14 15:05 == 35.9
9/12/14 15:10 == 35.8
9/12/14 15:15 == 35.9
9/12/14 15:20 == 35.8
9/12/14 15:25 == 35.9
9/12/14 15:30 == 35.9
9/12/14 15:35 == 36
9/12/14 15:40 == 36
9/12/14 15:45 == 35.8
9/12/14 15:50 == 35.8
9/12/14 15:55 == 35.9
9/12/14 16:00 == 35.9
9/12/14 16:05 == 35.8
9/12/14 16:10 == 35.9
9/12/14 16:15 == 36
9/12/14 16:20 == 35.9
9/12/14 16:25 == 35.8
9/12/14 16:30 == 35.9
9/12/14 16:35 == 35.9
9/12/14 16:40 == 35.9
9/12/14 16:45 == 35.8
9/12/14 16:50 == 35.8
9/12/14 16:55 == 35.8
9/12/14 17:00 == 35.8
9/12/14 17:05 == 35.8
9/12/14 17:10 == 35.8
9/12/14 17:15 == 36
9/12/14 17:20 == 35.9
9/12/14 17:25 == 35.9
9/12/14 17:30 == 35.8
9/12/14 17:35 == 35.8
9/12/14 17:40 == 35.9
9/12/14 17:45 == 35.8
9/12/14 17:50 == 35.8
9/12/14 17:55 == 35.8
9/12/14 18:00 == 35.9
9/12/14 18:05 == 35.9
9/12/14 18:10 == 35.9
9/12/14 18:15 == 35.8
9/12/14 18:20 == 35.9
9/12/14 18:25 == 35.8
9/12/14 18:30 == 35.8
9/12/14 18:35 == 35.9
9/12/14 18:40 == 35.8
9/12/14 18:45 == 35.8
9/12/14 18:50 == 35.8
9/12/14 18:55 == 35.8
9/12/14 19:00 == 35.8
9/12/14 19:05 == 35.8
9/12/14 19:10 == 35.8
9/12/14 19:15 == 35.8
9/12/14 19:20 == 35.8
9/12/14 19:25 == 35.8
9/12/14 19:30 == 35.8
9/12/14 19:35 == 35.7
9/12/14 19:40 == 35.8
9/12/14 19:45 == 35.8
9/12/14 19:50 == 35.8
9/12/14 19:55 == 35.7
9/12/14 20:00 == 35.8
9/12/14 20:05 == 35.8
9/12/14 20:10 == 35.7
9/12/14 20:15 == 35.7
9/12/14 20:20 == 35.6
9/12/14 20:25 == 35.7
9/12/14 20:30 == 35.7
9/12/14 20:35 == 35.7
9/12/14 20:40 == 35.6
9/12/14 20:45 == 35.6
9/12/14 20:50 == 35.7
9/12/14 20:55 == 35.7
9/12/14 21:00 == 35.7
9/12/14 21:05 == 35.6
9/12/14 21:10 == 35.7
9/12/14 21:15 == 35.7
9/12/14 21:20 == 35.7
9/12/14 21:25 == 35.7
9/12/14 21:30 == 35.7
9/12/14 21:35 == 35.7
9/12/14 21:40 == 35.8
9/12/14 21:45 == 35.7
9/12/14 21:50 == 35.7
9/12/14 21:55 == 35.7
9/12/14 22:00 == 35.7
9/12/14 22:05 == 35.7
9/12/14 22:10 == 35.6
9/12/14 22:15 == 35.6
9/12/14 22:20 == 35.8
9/12/14 22:25 == 35.7
9/12/14 22:30 == 35.7
9/12/14 22:35 == 35.7
9/12/14 22:40 == 35.6
9/12/14 22:45 == 35.6
9/12/14 22:50 == 35.7
9/12/14 22:55 == 35.7
9/12/14 23:00 == 35.7
9/12/14 23:05 == 35.6
9/12/14 23:10 == 35.6
9/12/14 23:15 == 35.6
9/12/14 23:20 == 35.7
9/12/14 23:25 == 35.6
9/12/14 23:30 == 35.7
9/12/14 23:35 == 35.7
9/12/14 23:40 == 35.5
9/12/14 23:45 == 35.6
9/12/14 23:50 == 35.6
9/12/14 23:55 == 35.6
9/13/14 0:00 == 35.7
9/13/14 0:05 == 35.7
9/13/14 0:10 == 35.6
9/13/14 0:15 == 35.5
9/13/14 0:20 == 35.6
9/13/14 0:25 == 35.6
9/13/14 0:30 == 35.6
9/13/14 0:35 == 35.6
9/13/14 0:40 == 35.6
9/13/14 0:45 == 35.6
9/13/14 0:50 == 35.6
9/13/14 0:55 == 35.6
9/13/14 1:00 == 35.6
9/13/14 1:05 == 35.6
9/13/14 1:10 == 35.5
9/13/14 1:15 == 35.6
9/13/14 1:20 == 35.6
9/13/14 1:25 == 35.6
9/13/14 1:30 == 35.6
9/13/14 1:35 == 35.6
9/13/14 1:40 == 35.6
9/13/14 1:45 == 35.5
9/13/14 1:50 == 35.6
9/13/14 1:55 == 35.6
9/13/14 2:00 == 35.6
9/13/14 2:05 == 35.7
9/13/14 2:10 == 35.6
9/13/14 2:15 == 35.6
9/13/14 2:20 == 35.6
9/13/14 2:25 == 35.6
9/13/14 2:30 == 35.7
9/13/14 2:35 == 35.6
9/13/14 2:40 == 35.6
9/13/14 2:45 == 35.7
9/13/14 2:50 == 35.6
9/13/14 2:55 == 35.7
9/13/14 3:00 == 35.6
9/13/14 3:05 == 35.6
9/13/14 3:10 == 35.7
9/13/14 3:15 == 35.7
9/13/14 3:20 == 35.7
9/13/14 3:25 == 35.6
9/13/14 3:30 == 35.6
9/13/14 3:35 == 35.7
9/13/14 3:40 == 35.7
9/13/14 3:45 == 35.6
9/13/14 3:50 == 35.6
9/13/14 3:55 == 35.7
9/13/14 4:00 == 35.6
9/13/14 4:05 == 35.7
9/13/14 4:10 == 35.6
9/13/14 4:15 == 35.7
9/13/14 4:20 == 35.6
9/13/14 4:25 == 35.6
9/13/14 4:30 == 35.6
9/13/14 4:35 == 35.7
9/13/14 4:40 == 35.6
9/13/14 4:45 == 35.6
9/13/14 4:50 == 35.6
9/13/14 4:55 == 35.6
9/13/14 5:00 == 35.6
9/13/14 5:05 == 35.6
9/13/14 5:10 == 35.6
9/13/14 5:15 == 35.5

Pumpback Station Discharge (0364)

9/13/14 5:20 == 35.6
9/13/14 5:25 == 35.6
9/13/14 5:30 == 35.6
9/13/14 5:35 == 35.5
9/13/14 5:40 == 35.6
9/13/14 5:45 == 35.6
9/13/14 5:50 == 35.6
9/13/14 5:55 == 35.7
9/13/14 6:00 == 35.7
9/13/14 6:05 == 35.6
9/13/14 6:10 == 35.7
9/13/14 6:15 == 35.6
9/13/14 6:20 == 35.5
9/13/14 6:25 == 35.7
9/13/14 6:30 == 35.6
9/13/14 6:35 == 35.6
9/13/14 6:40 == 35.6
9/13/14 6:45 == 35.6
9/13/14 6:50 == 35.6
9/13/14 6:55 == 35.6
9/13/14 7:00 == 35.6
9/13/14 7:05 == 35.6
9/13/14 7:10 == 35.7
9/13/14 7:15 == 35.6
9/13/14 7:20 == 35.7
9/13/14 7:25 == 35.6
9/13/14 7:30 == 35.6
9/13/14 7:35 == 35.6
9/13/14 7:40 == 35.6
9/13/14 7:45 == 35.6
9/13/14 7:50 == 35.4
9/13/14 7:55 == 35.4
9/13/14 8:00 == 35.5
9/13/14 8:05 == 35.5
9/13/14 8:10 == 35.6
9/13/14 8:15 == 35.5
9/13/14 8:20 == 35.5
9/13/14 8:25 == 35.6
9/13/14 8:30 == 35.6
9/13/14 8:35 == 35.6
9/13/14 8:40 == 35.6
9/13/14 8:45 == 35.6
9/13/14 8:50 == 35.6
9/13/14 8:55 == 35.6
9/13/14 9:00 == 35.6
9/13/14 9:05 == 35.7
9/13/14 9:10 == 35.7
9/13/14 9:15 == 35.8
9/13/14 9:20 == 35.8
9/13/14 9:25 == 35.7
9/13/14 9:30 == 35.7
9/13/14 9:35 == 35.7
9/13/14 9:40 == 35.7
9/13/14 9:45 == 35.8
9/13/14 9:50 == 35.7
9/13/14 9:55 == 35.7
9/13/14 10:00 == 35.8
9/13/14 10:05 == 35.8
9/13/14 10:10 == 35.9
9/13/14 10:15 == 35.8
9/13/14 10:20 == 35.8
9/13/14 10:25 == 35.8
9/13/14 10:30 == 35.8
9/13/14 10:35 == 35.8
9/13/14 10:40 == 35.8
9/13/14 10:45 == 35.7
9/13/14 10:50 == 35.8
9/13/14 10:55 == 35.9
9/13/14 11:00 == 35.7
9/13/14 11:05 == 38.4
9/13/14 11:10 == 47.8
9/13/14 11:15 == 48.1
9/13/14 11:20 == 48
9/13/14 11:25 == 47.8
9/13/14 11:30 == 48.1
9/13/14 11:35 == 47.9
9/13/14 11:40 == 48
9/13/14 11:45 == 48
9/13/14 11:50 == 40.3
9/13/14 11:55 == 35
9/13/14 12:00 == 34.9
9/13/14 12:05 == 35
9/13/14 12:10 == 35.1
9/13/14 12:15 == 35
9/13/14 12:20 == 35.2
9/13/14 12:25 == 35.1
9/13/14 12:30 == 35
9/13/14 12:35 == 35.1
9/13/14 12:40 == 35
9/13/14 12:45 == 35.1
9/13/14 12:50 == 35.1
9/13/14 12:55 == 35.2
9/13/14 13:00 == 35.1
9/13/14 13:05 == 35.2
9/13/14 13:10 == 35.2
9/13/14 13:15 == 35.1
9/13/14 13:20 == 35.2
9/13/14 13:25 == 35.3
9/13/14 13:30 == 35.3
9/13/14 13:35 == 35.3
9/13/14 13:40 == 35.3
9/13/14 13:45 == 35.2
9/13/14 13:50 == 35.2
9/13/14 13:55 == 35.3
9/13/14 14:00 == 35.2
9/13/14 14:05 == 35.3
9/13/14 14:10 == 35.3
9/13/14 14:15 == 35.4
9/13/14 14:20 == 35.3
9/13/14 14:25 == 35.2
9/13/14 14:30 == 35.3
9/13/14 14:35 == 35.3
9/13/14 14:40 == 35.3
9/13/14 14:45 == 35.3
9/13/14 14:50 == 35.3
9/13/14 14:55 == 35.3
9/13/14 15:00 == 35.3
9/13/14 15:05 == 35.3
9/13/14 15:10 == 35.4
9/13/14 15:15 == 35.3
9/13/14 15:20 == 35.4
9/13/14 15:25 == 35.3
9/13/14 15:30 == 35.3
9/13/14 15:35 == 35.3
9/13/14 15:40 == 35.4
9/13/14 15:45 == 35.3
9/13/14 15:50 == 35.3
9/13/14 15:55 == 35.4
9/13/14 16:00 == 35.5
9/13/14 16:05 == 35.4
9/13/14 16:10 == 35.4
9/13/14 16:15 == 35.4
9/13/14 16:20 == 35.5
9/13/14 16:25 == 35.4
9/13/14 16:30 == 35.5
9/13/14 16:35 == 35.4
9/13/14 16:40 == 35.4
9/13/14 16:45 == 35.4
9/13/14 16:50 == 35.5
9/13/14 16:55 == 35.3
9/13/14 17:00 == 35.4
9/13/14 17:05 == 35.5
9/13/14 17:10 == 35.4
9/13/14 17:15 == 35.4
9/13/14 17:20 == 35.4
9/13/14 17:25 == 35.4
9/13/14 17:30 == 35.5
9/13/14 17:35 == 35.4
9/13/14 17:40 == 35.4
9/13/14 17:45 == 35.5
9/13/14 17:50 == 35.4
9/13/14 17:55 == 35.4
9/13/14 18:00 == 35.4
9/13/14 18:05 == 35.4
9/13/14 18:10 == 35.4
9/13/14 18:15 == 35.6
9/13/14 18:20 == 35.4
9/13/14 18:25 == 35.5
9/13/14 18:30 == 35.4
9/13/14 18:35 == 35.4
9/13/14 18:40 == 35.4
9/13/14 18:45 == 35.4
9/13/14 18:50 == 35.4
9/13/14 18:55 == 35.3
9/13/14 19:00 == 35.4
9/13/14 19:05 == 35.5
9/13/14 19:10 == 35.5
9/13/14 19:15 == 35.5
9/13/14 19:20 == 35.5
9/13/14 19:25 == 35.5
9/13/14 19:30 == 35.4
9/13/14 19:35 == 35.5
9/13/14 19:40 == 35.4
9/13/14 19:45 == 35.6
9/13/14 19:50 == 35.5
9/13/14 19:55 == 35.4
9/13/14 20:00 == 35.5
9/13/14 20:05 == 35.4
9/13/14 20:10 == 35.5
9/13/14 20:15 == 35.6
9/13/14 20:20 == 35.3
9/13/14 20:25 == 35.4
9/13/14 20:30 == 35.4
9/13/14 20:35 == 35.4
9/13/14 20:40 == 35.5
9/13/14 20:45 == 35.3
9/13/14 20:50 == 35.5
9/13/14 20:55 == 35.3
9/13/14 21:00 == 35.4
9/13/14 21:05 == 35.3
9/13/14 21:10 == 35.4
9/13/14 21:15 == 35.4
9/13/14 21:20 == 35.4
9/13/14 21:25 == 35.3
9/13/14 21:30 == 35.4
9/13/14 21:35 == 35.4
9/13/14 21:40 == 35.5
9/13/14 21:45 == 35.4
9/13/14 21:50 == 35.3
9/13/14 21:55 == 35.3
9/13/14 22:00 == 35.4
9/13/14 22:05 == 35.4
9/13/14 22:10 == 35.3
9/13/14 22:15 == 35.3
9/13/14 22:20 == 35.4
9/13/14 22:25 == 35.4
9/13/14 22:30 == 35.4
9/13/14 22:35 == 35.4
9/13/14 22:40 == 35.3
9/13/14 22:45 == 35.4
9/13/14 22:50 == 35.5
9/13/14 22:55 == 35.4
9/13/14 23:00 == 35.4
9/13/14 23:05 == 35.4
9/13/14 23:10 == 35.4
9/13/14 23:15 == 35.5
9/13/14 23:20 == 35.5
9/13/14 23:25 == 35.4
9/13/14 23:30 == 35.3
9/13/14 23:35 == 35.4

Pumpback Station Discharge (0364)

9/13/14 23:40 == 35.4
9/13/14 23:45 == 35.4
9/13/14 23:50 == 35.4
9/13/14 23:55 == 35.4
9/14/14 0:00 == 35.4
9/14/14 0:05 == 35.4
9/14/14 0:10 == 35.5
9/14/14 0:15 == 35.4
9/14/14 0:20 == 35.5
9/14/14 0:25 == 35.4
9/14/14 0:30 == 35.3
9/14/14 0:35 == 35.4
9/14/14 0:40 == 35.4
9/14/14 0:45 == 35.4
9/14/14 0:50 == 35.5
9/14/14 0:55 == 35.3
9/14/14 1:00 == 35.3
9/14/14 1:05 == 35.4
9/14/14 1:10 == 35.3
9/14/14 1:15 == 35.4
9/14/14 1:20 == 35.3
9/14/14 1:25 == 35.4
9/14/14 1:30 == 35.4
9/14/14 1:35 == 35.3
9/14/14 1:40 == 35.5
9/14/14 1:45 == 35.3
9/14/14 1:50 == 35.2
9/14/14 1:55 == 35.4
9/14/14 2:00 == 35.4
9/14/14 2:05 == 35.4
9/14/14 2:10 == 35.4
9/14/14 2:15 == 35.3
9/14/14 2:20 == 35.4
9/14/14 2:25 == 35.3
9/14/14 2:30 == 35.4
9/14/14 2:35 == 35.3
9/14/14 2:40 == 35.4
9/14/14 2:45 == 35.4
9/14/14 2:50 == 35.5
9/14/14 2:55 == 35.4
9/14/14 3:00 == 35.5
9/14/14 3:05 == 35.3
9/14/14 3:10 == 35.3
9/14/14 3:15 == 35.3
9/14/14 3:20 == 35.5
9/14/14 3:25 == 35.4
9/14/14 3:30 == 35.5
9/14/14 3:35 == 35.4
9/14/14 3:40 == 35.3
9/14/14 3:45 == 35.3
9/14/14 3:50 == 35.3
9/14/14 3:55 == 35.3
9/14/14 4:00 == 35.4
9/14/14 4:05 == 35.3
9/14/14 4:10 == 35.3
9/14/14 4:15 == 35.3
9/14/14 4:20 == 35.3
9/14/14 4:25 == 35.3
9/14/14 4:30 == 35.4
9/14/14 4:35 == 35.2
9/14/14 4:40 == 35.3
9/14/14 4:45 == 35.3
9/14/14 4:50 == 35.4
9/14/14 4:55 == 35.2
9/14/14 5:00 == 35.3
9/14/14 5:05 == 35.2
9/14/14 5:10 == 35.3
9/14/14 5:15 == 35.3
9/14/14 5:20 == 35.4
9/14/14 5:25 == #
9/14/14 5:30 == 35.3
9/14/14 5:35 == 35.3
9/14/14 5:40 == 35.3
9/14/14 5:45 == 35.4
9/14/14 5:50 == 35.3
9/14/14 5:55 == 35.3
9/14/14 6:00 == 35.3
9/14/14 6:05 == 35.3
9/14/14 6:10 == 35.3
9/14/14 6:15 == 35.3
9/14/14 6:20 == 35.3
9/14/14 6:25 == 35.3
9/14/14 6:30 == 35.4
9/14/14 6:35 == 35.3
9/14/14 6:40 == 35.3
9/14/14 6:45 == 35.3
9/14/14 6:50 == 35.3
9/14/14 6:55 == 35.3
9/14/14 7:00 == 35.3
9/14/14 7:05 == 35.3
9/14/14 7:10 == 35.4
9/14/14 7:15 == 35.4
9/14/14 7:20 == 35.3
9/14/14 7:25 == 35.3
9/14/14 7:30 == 35.3
9/14/14 7:35 == 35.3
9/14/14 7:40 == 35.3
9/14/14 7:45 == 35.2
9/14/14 7:50 == 35.3
9/14/14 7:55 == 35.3
9/14/14 8:00 == 35.3
9/14/14 8:05 == 35.2
9/14/14 8:10 == 35.3
9/14/14 8:15 == 35.2
9/14/14 8:20 == 35.2
9/14/14 8:25 == 35.3
9/14/14 8:30 == 35.3
9/14/14 8:35 == 35.4
9/14/14 8:40 == 35.3
9/14/14 8:45 == 35.5
9/14/14 8:50 == 35.4
9/14/14 8:55 == 35.4
9/14/14 9:00 == 35.6
9/14/14 9:05 == 35.4
9/14/14 9:10 == 35.3
9/14/14 9:15 == 35.4
9/14/14 9:20 == 35.5
9/14/14 9:25 == 35.5
9/14/14 9:30 == 35.5
9/14/14 9:35 == 35.5
9/14/14 9:40 == 35.5
9/14/14 9:45 == 35.5
9/14/14 9:50 == 35.7
9/14/14 9:55 == 35.6
9/14/14 10:00 == #
9/14/14 10:05 == 35.6
9/14/14 10:10 == 35.7
9/14/14 10:15 == 35.7
9/14/14 10:20 == 35.7
9/14/14 10:25 == 35.6
9/14/14 10:30 == 35.5
9/14/14 10:35 == 35.6
9/14/14 10:40 == 35.7
9/14/14 10:45 == 35.7
9/14/14 10:50 == 35.6
9/14/14 10:55 == 35.8
9/14/14 11:00 == 35.8
9/14/14 11:05 == 35.8
9/14/14 11:10 == 35.7
9/14/14 11:15 == 35.8
9/14/14 11:20 == 35.8
9/14/14 11:25 == 35.8
9/14/14 11:30 == 35.7
9/14/14 11:35 == 35.8
9/14/14 11:40 == 35.7
9/14/14 11:45 == 35.8
9/14/14 11:50 == 35.9
9/14/14 11:55 == 35.8
9/14/14 12:00 == 35.8
9/14/14 12:05 == 35.8
9/14/14 12:10 == 35.8
9/14/14 12:15 == 35.8
9/14/14 12:20 == 35.8
9/14/14 12:25 == 35.9
9/14/14 12:30 == 35.8
9/14/14 12:35 == 35.8
9/14/14 12:40 == 40.2
9/14/14 12:45 == 48
9/14/14 12:50 == 48
9/14/14 12:55 == 48
9/14/14 13:00 == 47.9
9/14/14 13:05 == 47.9
9/14/14 13:10 == 39
9/14/14 13:15 == 35.2
9/14/14 13:20 == 35.1
9/14/14 13:25 == 35.2
9/14/14 13:30 == 35.2
9/14/14 13:35 == 35.3
9/14/14 13:40 == 35.3
9/14/14 13:45 == 35.2
9/14/14 13:50 == 35.3
9/14/14 13:55 == 35.5
9/14/14 14:00 == 35.4
9/14/14 14:05 == 35.4
9/14/14 14:10 == 35.4
9/14/14 14:15 == 35.5
9/14/14 14:20 == 35.3
9/14/14 14:25 == 35.5
9/14/14 14:30 == 35.4
9/14/14 14:35 == 35.5
9/14/14 14:40 == 35.6
9/14/14 14:45 == 35.6
9/14/14 14:50 == 35.6
9/14/14 14:55 == 35.7
9/14/14 15:00 == 35.8
9/14/14 15:05 == 35.8
9/14/14 15:10 == 35.7
9/14/14 15:15 == 35.8
9/14/14 15:20 == 35.8
9/14/14 15:25 == 35.8
9/14/14 15:30 == 35.8
9/14/14 15:35 == 35.8
9/14/14 15:40 == 35.8
9/14/14 15:45 == 35.8
9/14/14 15:50 == 35.8
9/14/14 15:55 == 35.7
9/14/14 16:00 == 35.6
9/14/14 16:05 == 35.7
9/14/14 16:10 == 35.6
9/14/14 16:15 == 35.7
9/14/14 16:20 == 35.7
9/14/14 16:25 == 35.7
9/14/14 16:30 == 35.7
9/14/14 16:35 == #
9/14/14 16:40 == 35.8
9/14/14 16:45 == 35.6
9/14/14 16:50 == 35.7
9/14/14 16:55 == 35.6
9/14/14 17:00 == 35.8
9/14/14 17:05 == 35.7
9/14/14 17:10 == 35.7
9/14/14 17:15 == 35.9
9/14/14 17:20 == 35.7
9/14/14 17:25 == 35.9
9/14/14 17:30 == 35.7
9/14/14 17:35 == 35.7
9/14/14 17:40 == 35.7
9/14/14 17:45 == 35.7
9/14/14 17:50 == 35.7
9/14/14 17:55 == 35.8

Pumpback Station Discharge (0364)

9/14/14 18:00 == 35.7
9/14/14 18:05 == 35.8
9/14/14 18:10 == 35.8
9/14/14 18:15 == 35.8
9/14/14 18:20 == 35.8
9/14/14 18:25 == 35.9
9/14/14 18:30 == 35.8
9/14/14 18:35 == 35.9
9/14/14 18:40 == 10.1
9/14/14 18:45 == 0
9/14/14 18:50 == 0
9/14/14 18:55 == 0
9/14/14 19:00 == 0
9/14/14 19:05 == 0
9/14/14 19:10 == 0
9/14/14 19:15 == #
9/14/14 19:20 == 0
9/14/14 19:25 == 0
9/14/14 19:30 == 0
9/14/14 19:35 == 0
9/14/14 19:40 == 0
9/14/14 19:45 == 0
9/14/14 19:50 == 0
9/14/14 19:55 == 0
9/14/14 20:00 == 0
9/14/14 20:05 == 0
9/14/14 20:10 == 0
9/14/14 20:15 == #
9/14/14 20:20 == #
9/14/14 20:25 == 0
9/14/14 20:30 == 0
9/14/14 20:35 == 0
9/14/14 20:40 == 0
9/14/14 20:45 == #
9/14/14 20:50 == 0
9/14/14 20:55 == #
9/14/14 21:00 == #
9/14/14 21:05 == 0
9/14/14 21:10 == 0
9/14/14 21:15 == 0
9/14/14 21:20 == #
9/14/14 21:25 == 0
9/14/14 21:30 == 0
9/14/14 21:35 == 0
9/14/14 21:40 == 0
9/14/14 21:45 == 0
9/14/14 21:50 == #
9/14/14 21:55 == #
9/14/14 22:00 == 0
9/14/14 22:05 == 0
9/14/14 22:10 == #
9/14/14 22:15 == 0
9/14/14 22:20 == 0
9/14/14 22:25 == #
9/14/14 22:30 == #
9/14/14 22:35 == 0
9/14/14 22:40 == 0
9/14/14 22:45 == #
9/14/14 22:50 == 0
9/14/14 22:55 == 0
9/14/14 23:00 == #
9/14/14 23:05 == #
9/14/14 23:10 == #
9/14/14 23:15 == #
9/14/14 23:20 == #
9/14/14 23:25 == #
9/14/14 23:30 == #
9/14/14 23:35 == #
9/14/14 23:40 == 0
9/14/14 23:45 == 0
9/14/14 23:50 == #
9/14/14 23:55 == #
9/15/14 0:00 == 0
9/15/14 0:05 == #
9/15/14 0:10 == 0
9/15/14 0:15 == #
9/15/14 0:20 == #
9/15/14 0:25 == #
9/15/14 0:30 == #
9/15/14 0:35 == #
9/15/14 0:40 == #
9/15/14 0:45 == 0
9/15/14 0:50 == 0
9/15/14 0:55 == 0
9/15/14 1:00 == 0
9/15/14 1:05 == #
9/15/14 1:10 == 0
9/15/14 1:15 == 0
9/15/14 1:20 == 0
9/15/14 1:25 == 0
9/15/14 1:30 == 0
9/15/14 1:35 == 0
9/15/14 1:40 == 0
9/15/14 1:45 == 0
9/15/14 1:50 == #
9/15/14 1:55 == 0
9/15/14 2:00 == 0
9/15/14 2:05 == #
9/15/14 2:10 == 0
9/15/14 2:15 == #
9/15/14 2:20 == #
9/15/14 2:25 == 0
9/15/14 2:30 == 0
9/15/14 2:35 == 0
9/15/14 2:40 == 0
9/15/14 2:45 == #
9/15/14 2:50 == #
9/15/14 2:55 == #
9/15/14 3:00 == #
9/15/14 3:05 == #
9/15/14 3:10 == 0
9/15/14 3:15 == 0
9/15/14 3:20 == 0
9/15/14 3:25 == 0
9/15/14 3:30 == 0
9/15/14 3:35 == 0
9/15/14 3:40 == #
9/15/14 3:45 == #
9/15/14 3:50 == #
9/15/14 3:55 == #
9/15/14 4:00 == 0
9/15/14 4:05 == #
9/15/14 4:10 == 0
9/15/14 4:15 == 0
9/15/14 4:20 == 0
9/15/14 4:25 == 0
9/15/14 4:30 == #
9/15/14 4:35 == 0
9/15/14 4:40 == 0
9/15/14 4:45 == 0
9/15/14 4:50 == #
9/15/14 4:55 == 0
9/15/14 5:00 == #
9/15/14 5:05 == #
9/15/14 5:10 == #
9/15/14 5:15 == 0
9/15/14 5:20 == 0
9/15/14 5:25 == #
9/15/14 5:30 == 0
9/15/14 5:35 == 0
9/15/14 5:40 == 0
9/15/14 5:45 == 0
9/15/14 5:50 == 0
9/15/14 5:55 == #
9/15/14 6:00 == 0
9/15/14 6:05 == 0
9/15/14 6:10 == 0
9/15/14 6:15 == 0
9/15/14 6:20 == 0
9/15/14 6:25 == 0
9/15/14 6:30 == #
9/15/14 6:35 == 0
9/15/14 6:40 == 0
9/15/14 6:45 == 0
9/15/14 6:50 == #
9/15/14 6:55 == 0
9/15/14 7:00 == 0
9/15/14 7:05 == #
9/15/14 7:10 == 0
9/15/14 7:15 == #
9/15/14 7:20 == #
9/15/14 7:25 == 0
9/15/14 7:30 == 0
9/15/14 7:35 == 0
9/15/14 7:40 == 2.9
9/15/14 7:45 == 20.5
9/15/14 7:50 == 28.6
9/15/14 7:55 == 34.7
9/15/14 8:00 == 36.8
9/15/14 8:05 == 49.4
9/15/14 8:10 == 49.1
9/15/14 8:15 == 49.1
9/15/14 8:20 == 49.1
9/15/14 8:25 == 49.2
9/15/14 8:30 == 49.1
9/15/14 8:35 == 49
9/15/14 8:40 == 48.7
9/15/14 8:45 == 47.6
9/15/14 8:50 == 47.6
9/15/14 8:55 == 47.9
9/15/14 9:00 == 47.6
9/15/14 9:05 == 47.7
9/15/14 9:10 == 47.8
9/15/14 9:15 == 47.9
9/15/14 9:20 == 47.9
9/15/14 9:25 == 47.7
9/15/14 9:30 == 47.6
9/15/14 9:35 == 47.6
9/15/14 9:40 == 47.6
9/15/14 9:45 == 47.5
9/15/14 9:50 == 47.6
9/15/14 9:55 == 47.5
9/15/14 10:00 == 47.6
9/15/14 10:05 == 47.6
9/15/14 10:10 == 47.7
9/15/14 10:15 == 47.5
9/15/14 10:20 == 47.6
9/15/14 10:25 == 25.5
9/15/14 10:30 == 0
9/15/14 10:35 == 0
9/15/14 10:40 == #
9/15/14 10:45 == 14.8
9/15/14 10:50 == 45
9/15/14 10:55 == 47.8
9/15/14 11:00 == 48
9/15/14 11:05 == 48.1
9/15/14 11:10 == 48.1
9/15/14 11:15 == 48.1
9/15/14 11:20 == 48.1
9/15/14 11:25 == 48.1
9/15/14 11:30 == 48
9/15/14 11:35 == 48
9/15/14 11:40 == 48
9/15/14 11:45 == 48.1
9/15/14 11:50 == 48
9/15/14 11:55 == 48
9/15/14 12:00 == 48.1
9/15/14 12:05 == 47.8
9/15/14 12:10 == 47.9
9/15/14 12:15 == 47.9

Pumpback Station Discharge (0364)

9/15/14 12:20 == 47.9
9/15/14 12:25 == 48
9/15/14 12:30 == 47.9
9/15/14 12:35 == 48
9/15/14 12:40 == 48
9/15/14 12:45 == 48
9/15/14 12:50 == 48
9/15/14 12:55 == 47.9
9/15/14 13:00 == 48
9/15/14 13:05 == 47.9
9/15/14 13:10 == 48
9/15/14 13:15 == 48
9/15/14 13:20 == 48
9/15/14 13:25 == 48
9/15/14 13:30 == 47.9
9/15/14 13:35 == 48
9/15/14 13:40 == 47.9
9/15/14 13:45 == 48
9/15/14 13:50 == 48
9/15/14 13:55 == 48
9/15/14 14:00 == 48
9/15/14 14:05 == 47.9
9/15/14 14:10 == 47.7
9/15/14 14:15 == 48.1
9/15/14 14:20 == 48
9/15/14 14:25 == 48.1
9/15/14 14:30 == 47.9
9/15/14 14:35 == 48
9/15/14 14:40 == 37.7
9/15/14 14:45 == 35.1
9/15/14 14:50 == 35
9/15/14 14:55 == 35.3
9/15/14 15:00 == 35.3
9/15/14 15:05 == 35.4
9/15/14 15:10 == 35.3
9/15/14 15:15 == 35.3
9/15/14 15:20 == 35.3
9/15/14 15:25 == 35.5
9/15/14 15:30 == 35.3
9/15/14 15:35 == 35.3
9/15/14 15:40 == 35.2
9/15/14 15:45 == 35.4
9/15/14 15:50 == 35.4
9/15/14 15:55 == 35.5
9/15/14 16:00 == 35.3
9/15/14 16:05 == 35.5
9/15/14 16:10 == 35.4
9/15/14 16:15 == 35.6
9/15/14 16:20 == 35.6
9/15/14 16:25 == 35.5
9/15/14 16:30 == 35.4
9/15/14 16:35 == 35.4
9/15/14 16:40 == 35.5
9/15/14 16:45 == 35.5
9/15/14 16:50 == 35.5
9/15/14 16:55 == 35.6
9/15/14 17:00 == 35.5
9/15/14 17:05 == 35.6
9/15/14 17:10 == 35.5
9/15/14 17:15 == 35.5
9/15/14 17:20 == 35.7
9/15/14 17:25 == 35.6
9/15/14 17:30 == 35.5
9/15/14 17:35 == 35.6
9/15/14 17:40 == 35.6
9/15/14 17:45 == 35.6
9/15/14 17:50 == 35.5
9/15/14 17:55 == 35.5
9/15/14 18:00 == 35.5
9/15/14 18:05 == 35.5
9/15/14 18:10 == 35.4
9/15/14 18:15 == 35.5
9/15/14 18:20 == 35.5
9/15/14 18:25 == 35.4
9/15/14 18:30 == 35.4
9/15/14 18:35 == 35.5
9/15/14 18:40 == 35.5
9/15/14 18:45 == 35.6
9/15/14 18:50 == 35.3
9/15/14 18:55 == 35.4
9/15/14 19:00 == 35.4
9/15/14 19:05 == 35.4
9/15/14 19:10 == 35.2
9/15/14 19:15 == 35.4
9/15/14 19:20 == 35.3
9/15/14 19:25 == 35.3
9/15/14 19:30 == 35.2
9/15/14 19:35 == 35.2
9/15/14 19:40 == 35.1
9/15/14 19:45 == 35.1
9/15/14 19:50 == 35.1
9/15/14 19:55 == 35.2
9/15/14 20:00 == 35.1
9/15/14 20:05 == 35.1
9/15/14 20:10 == 35
9/15/14 20:15 == 35
9/15/14 20:20 == 34.9
9/15/14 20:25 == 35.1
9/15/14 20:30 == 35.1
9/15/14 20:35 == 35.1
9/15/14 20:40 == 35.1
9/15/14 20:45 == 35
9/15/14 20:50 == 35
9/15/14 20:55 == 35.2
9/15/14 21:00 == 35
9/15/14 21:05 == 35
9/15/14 21:10 == 35
9/15/14 21:15 == 35
9/15/14 21:20 == 35
9/15/14 21:25 == 35.1
9/15/14 21:30 == 35.1
9/15/14 21:35 == 35
9/15/14 21:40 == 35
9/15/14 21:45 == 34.8
9/15/14 21:50 == 34.9
9/15/14 21:55 == 34.9
9/15/14 22:00 == 34.8
9/15/14 22:05 == 35
9/15/14 22:10 == 34.9
9/15/14 22:15 == 34.9
9/15/14 22:20 == 34.9
9/15/14 22:25 == 34.7
9/15/14 22:30 == 34.8
9/15/14 22:35 == 34.8
9/15/14 22:40 == 34.8
9/15/14 22:45 == 34.8
9/15/14 22:50 == 34.7
9/15/14 22:55 == 34.7
9/15/14 23:00 == 34.6
9/15/14 23:05 == 34.8
9/15/14 23:10 == 34.8
9/15/14 23:15 == 34.6
9/15/14 23:20 == 34.6
9/15/14 23:25 == 34.7
9/15/14 23:30 == 34.6
9/15/14 23:35 == 34.7
9/15/14 23:40 == 34.6
9/15/14 23:45 == 34.7
9/15/14 23:50 == 34.7
9/15/14 23:55 == 34.6
9/16/14 0:00 == 34.6
9/16/14 0:05 == 34.6
9/16/14 0:10 == 34.5
9/16/14 0:15 == 34.5
9/16/14 0:20 == 34.5
9/16/14 0:25 == 34.4
9/16/14 0:30 == 34.4
9/16/14 0:35 == 34.4
9/16/14 0:40 == 34.4
9/16/14 0:45 == 34.4
9/16/14 0:50 == 34.3
9/16/14 0:55 == 34.4
9/16/14 1:00 == 34.3
9/16/14 1:05 == 34.3
9/16/14 1:10 == 34.1
9/16/14 1:15 == 34
9/16/14 1:20 == 34
9/16/14 1:25 == 17.8
9/16/14 1:30 == 15.4
9/16/14 1:35 == 15.3
9/16/14 1:40 == 15.8
9/16/14 1:45 == 15.8
9/16/14 1:50 == 15.8
9/16/14 1:55 == 16.1
9/16/14 2:00 == 16.2
9/16/14 2:05 == 16.2
9/16/14 2:10 == 32
9/16/14 2:15 == 35.3
9/16/14 2:20 == 35.3
9/16/14 2:25 == 34.8
9/16/14 2:30 == 34.8
9/16/14 2:35 == 34.8
9/16/14 2:40 == 34.7
9/16/14 2:45 == 34.7
9/16/14 2:50 == 34.7
9/16/14 2:55 == 34.4
9/16/14 3:00 == 34.4
9/16/14 3:05 == 34.4
9/16/14 3:10 == 34.3
9/16/14 3:15 == 34.3
9/16/14 3:20 == 34.2
9/16/14 3:25 == 34.2
9/16/14 3:30 == 34.2
9/16/14 3:35 == 34.1
9/16/14 3:40 == 17.5
9/16/14 3:45 == 15.4
9/16/14 3:50 == 15.3
9/16/14 3:55 == 15.9
9/16/14 4:00 == 15.9
9/16/14 4:05 == 15.9
9/16/14 4:10 == 16.2
9/16/14 4:15 == 16.2
9/16/14 4:20 == 16.2
9/16/14 4:25 == 32.1
9/16/14 4:30 == 35.3
9/16/14 4:35 == 35.1
9/16/14 4:40 == 34.9
9/16/14 4:45 == 34.8
9/16/14 4:50 == 34.8
9/16/14 4:55 == 34.6
9/16/14 5:00 == 34.4
9/16/14 5:05 == 34.5
9/16/14 5:10 == 34.2
9/16/14 5:15 == 34.3
9/16/14 5:20 == 34.2
9/16/14 5:25 == 17.6
9/16/14 5:30 == 15.5
9/16/14 5:35 == 15.5
9/16/14 5:40 == 15.9
9/16/14 5:45 == 15.9
9/16/14 5:50 == 15.9
9/16/14 5:55 == 16.3
9/16/14 6:00 == 16.4
9/16/14 6:05 == 16.3
9/16/14 6:10 == 32.2
9/16/14 6:15 == 35
9/16/14 6:20 == 35.1
9/16/14 6:25 == 34.8
9/16/14 6:30 == 34.6
9/16/14 6:35 == 34.6

Pumpback Station Discharge (0364)

9/16/14 6:40 == 34.4
9/16/14 6:45 == 34.2
9/16/14 6:50 == 34.3
9/16/14 6:55 == 34.3
9/16/14 7:00 == 34
9/16/14 7:05 == 34.2
9/16/14 7:10 == 33.9
9/16/14 7:15 == 33.9
9/16/14 7:20 == 33.8
9/16/14 7:25 == 18.9
9/16/14 7:30 == 15.3
9/16/14 7:35 == 15.3
9/16/14 7:40 == 15.2
9/16/14 7:45 == 15.4
9/16/14 7:50 == 15.2
9/16/14 7:55 == 15.3
9/16/14 8:00 == 15.3
9/16/14 8:05 == 15.4
9/16/14 8:10 == 15.2
9/16/14 8:15 == 15.2
9/16/14 8:20 == 15.3
9/16/14 8:25 == 15.3
9/16/14 8:30 == 15.3
9/16/14 8:35 == 15.3
9/16/14 8:40 == 15.3
9/16/14 8:45 == 15.3
9/16/14 8:50 == 15.4
9/16/14 8:55 == 15.3
9/16/14 9:00 == 15.4
9/16/14 9:05 == 15.4
9/16/14 9:10 == 15.4
9/16/14 9:15 == 15.4
9/16/14 9:20 == 15.3
9/16/14 9:25 == 15.3
9/16/14 9:30 == 15.3
9/16/14 9:35 == 15.3
9/16/14 9:40 == 15.3
9/16/14 9:45 == 15.4
9/16/14 9:50 == 15.3
9/16/14 9:55 == 15.5
9/16/14 10:00 == 15.3
9/16/14 10:05 == 15.4
9/16/14 10:10 == 15.3
9/16/14 10:15 == 15.3
9/16/14 10:20 == 15.4
9/16/14 10:25 == 15.4
9/16/14 10:30 == 15.3
9/16/14 10:35 == 15.3
9/16/14 10:40 == 15.3
9/16/14 10:45 == 15.3
9/16/14 10:50 == 15.3
9/16/14 10:55 == 15.3
9/16/14 11:00 == 15.4
9/16/14 11:05 == 15.4
9/16/14 11:10 == 15.4
9/16/14 11:15 == 15.4
9/16/14 11:20 == 15.5
9/16/14 11:25 == 15.5
9/16/14 11:30 == 15.4
9/16/14 11:35 == 15.3
9/16/14 11:40 == 15.3
9/16/14 11:45 == 15.3
9/16/14 11:50 == 15.4
9/16/14 11:55 == 15.5
9/16/14 12:00 == 15.3
9/16/14 12:05 == 15.3
9/16/14 12:10 == 15.4
9/16/14 12:15 == 15.5
9/16/14 12:20 == 15.4
9/16/14 12:25 == 15.3
9/16/14 12:30 == 15.5
9/16/14 12:35 == 15.4
9/16/14 12:40 == 15.3
9/16/14 12:45 == 15.3
9/16/14 12:50 == 15.2
9/16/14 12:55 == 15.3
9/16/14 13:00 == 29.5
9/16/14 13:05 == 48
9/16/14 13:10 == 47.9
9/16/14 13:15 == 48.1
9/16/14 13:20 == 48
9/16/14 13:25 == 48.1
9/16/14 13:30 == 48.1
9/16/14 13:35 == 48
9/16/14 13:40 == 48.1
9/16/14 13:45 == 48
9/16/14 13:50 == 48.1
9/16/14 13:55 == 47.9
9/16/14 14:00 == 47.9
9/16/14 14:05 == 48.2
9/16/14 14:10 == 48.1
9/16/14 14:15 == 48
9/16/14 14:20 == 48
9/16/14 14:25 == 48
9/16/14 14:30 == 48.1
9/16/14 14:35 == 48.2
9/16/14 14:40 == 48.1
9/16/14 14:45 == 47.9
9/16/14 14:50 == 47.9
9/16/14 14:55 == 48
9/16/14 15:00 == 48
9/16/14 15:05 == 48
9/16/14 15:10 == 35.3
9/16/14 15:15 == 34.7
9/16/14 15:20 == 34.9
9/16/14 15:25 == 34.8
9/16/14 15:30 == 34.8
9/16/14 15:35 == 34.8
9/16/14 15:40 == 34.8
9/16/14 15:45 == 34.6
9/16/14 15:50 == 34.8
9/16/14 15:55 == 34.6
9/16/14 16:00 == 34.7
9/16/14 16:05 == 34.6
9/16/14 16:10 == 34.6
9/16/14 16:15 == 34.7
9/16/14 16:20 == 34.6
9/16/14 16:25 == 34.5
9/16/14 16:30 == 34.4
9/16/14 16:35 == 34.5
9/16/14 16:40 == 34.4
9/16/14 16:45 == 34.4
9/16/14 16:50 == 34.4
9/16/14 16:55 == 34.2
9/16/14 17:00 == 34.3
9/16/14 17:05 == 34.3
9/16/14 17:10 == 34.1
9/16/14 17:15 == 34.1
9/16/14 17:20 == 34.1
9/16/14 17:25 == 34
9/16/14 17:30 == 34
9/16/14 17:35 == 34
9/16/14 17:40 == 33.8
9/16/14 17:45 == 33.8
9/16/14 17:50 == 33.9
9/16/14 17:55 == 33.9
9/16/14 18:00 == 33.8
9/16/14 18:05 == 33.8
9/16/14 18:10 == 33.8
9/16/14 18:15 == 33.8
9/16/14 18:20 == 33.8
9/16/14 18:25 == 17.4
9/16/14 18:30 == 15.4
9/16/14 18:35 == 15.4
9/16/14 18:40 == 15.8
9/16/14 18:45 == 15.8
9/16/14 18:50 == 15.8
9/16/14 18:55 == 32.6
9/16/14 19:00 == 34.7
9/16/14 19:05 == 34.8
9/16/14 19:10 == 34.5
9/16/14 19:15 == 34.5
9/16/14 19:20 == 34.5
9/16/14 19:25 == 34.2
9/16/14 19:30 == 34.1
9/16/14 19:35 == 34.2
9/16/14 19:40 == 34.1
9/16/14 19:45 == 34.1
9/16/14 19:50 == 34
9/16/14 19:55 == 33.9
9/16/14 20:00 == 33.8
9/16/14 20:05 == 33.9
9/16/14 20:10 == 33.7
9/16/14 20:15 == 33.8
9/16/14 20:20 == 33.7
9/16/14 20:25 == 17.3
9/16/14 20:30 == 15.3
9/16/14 20:35 == 15.3
9/16/14 20:40 == 15.7
9/16/14 20:45 == 15.7
9/16/14 20:50 == 15.7
9/16/14 20:55 == 16
9/16/14 21:00 == 16
9/16/14 21:05 == 16.1
9/16/14 21:10 == 33.1
9/16/14 21:15 == 34.8
9/16/14 21:20 == 34.7
9/16/14 21:25 == 34.6
9/16/14 21:30 == 34.6
9/16/14 21:35 == 34.5
9/16/14 21:40 == 34.2
9/16/14 21:45 == 34
9/16/14 21:50 == 34.2
9/16/14 21:55 == 33.9
9/16/14 22:00 == 33.8
9/16/14 22:05 == 33.9
9/16/14 22:10 == 17.2
9/16/14 22:15 == 15.3
9/16/14 22:20 == 15.4
9/16/14 22:25 == 15.7
9/16/14 22:30 == 15.7
9/16/14 22:35 == 15.7
9/16/14 22:40 == 16
9/16/14 22:45 == 16
9/16/14 22:50 == 16
9/16/14 22:55 == 33.3
9/16/14 23:00 == 34.8
9/16/14 23:05 == 34.8
9/16/14 23:10 == 34.3
9/16/14 23:15 == 34.4
9/16/14 23:20 == 34.4
9/16/14 23:25 == 34.1
9/16/14 23:30 == 34.1
9/16/14 23:35 == 34.1
9/16/14 23:40 == 33.8
9/16/14 23:45 == 33.9
9/16/14 23:50 == 33.8
9/16/14 23:55 == 17.2
9/17/14 0:00 == 15.2
9/17/14 0:05 == 15.2
9/17/14 0:10 == 15.7
9/17/14 0:15 == 15.7
9/17/14 0:20 == 15.6
9/17/14 0:25 == 16.1
9/17/14 0:30 == 16.1
9/17/14 0:35 == 16
9/17/14 0:40 == 33.5
9/17/14 0:45 == 34.9
9/17/14 0:50 == 34.9
9/17/14 0:55 == 34.4

Pumpback Station Discharge (0364)

9/17/14 1:00 == 34.4
9/17/14 1:05 == 34.4
9/17/14 1:10 == 34.1
9/17/14 1:15 == 34
9/17/14 1:20 == 34.1
9/17/14 1:25 == 33.8
9/17/14 1:30 == 33.9
9/17/14 1:35 == 33.9
9/17/14 1:40 == 15.5
9/17/14 1:45 == 15.1
9/17/14 1:50 == 15.2
9/17/14 1:55 == 15.6
9/17/14 2:00 == 15.5
9/17/14 2:05 == 15.5
9/17/14 2:10 == 15.9
9/17/14 2:15 == 16
9/17/14 2:20 == 16
9/17/14 2:25 == 33.6
9/17/14 2:30 == 34.8
9/17/14 2:35 == 34.8
9/17/14 2:40 == 34.5
9/17/14 2:45 == 34.6
9/17/14 2:50 == 34.4
9/17/14 2:55 == 34
9/17/14 3:00 == 34.1
9/17/14 3:05 == 34
9/17/14 3:10 == 15.6
9/17/14 3:15 == 15.3
9/17/14 3:20 == 15.3
9/17/14 3:25 == 15.7
9/17/14 3:30 == 15.7
9/17/14 3:35 == 15.7
9/17/14 3:40 == 16
9/17/14 3:45 == 16
9/17/14 3:50 == 16
9/17/14 3:55 == 33.8
9/17/14 4:00 == 34.8
9/17/14 4:05 == 34.9
9/17/14 4:10 == 34.5
9/17/14 4:15 == 34.4
9/17/14 4:20 == 34.4
9/17/14 4:25 == 34
9/17/14 4:30 == 34
9/17/14 4:35 == 34
9/17/14 4:40 == 15.6
9/17/14 4:45 == 15.3
9/17/14 4:50 == 15.4
9/17/14 4:55 == 15.8
9/17/14 5:00 == 15.7
9/17/14 5:05 == 15.8
9/17/14 5:10 == 16
9/17/14 5:15 == 16
9/17/14 5:20 == 16
9/17/14 5:25 == 34.1
9/17/14 5:30 == 34.9
9/17/14 5:35 == 34.9
9/17/14 5:40 == 34.6
9/17/14 5:45 == 34.6
9/17/14 5:50 == 34.5
9/17/14 5:55 == 34.1
9/17/14 6:00 == 34.1
9/17/14 6:05 == 34.1
9/17/14 6:10 == 15.6
9/17/14 6:15 == 15.3
9/17/14 6:20 == 15.4
9/17/14 6:25 == 15.8
9/17/14 6:30 == 15.9
9/17/14 6:35 == 15.7
9/17/14 6:40 == 16.1
9/17/14 6:45 == 16.1
9/17/14 6:50 == 16.1
9/17/14 6:55 == 34.1
9/17/14 7:00 == 34.8
9/17/14 7:05 == 34.7
9/17/14 7:10 == 34.4
9/17/14 7:15 == 34.5
9/17/14 7:20 == 34.4
9/17/14 7:25 == 34.1
9/17/14 7:30 == 33.8
9/17/14 7:35 == 34
9/17/14 7:40 == 16.5
9/17/14 7:45 == 15.1
9/17/14 7:50 == 15.2
9/17/14 7:55 == 15.3
9/17/14 8:00 == 15.4
9/17/14 8:05 == 15.4
9/17/14 8:10 == 15.7
9/17/14 8:15 == 15.7
9/17/14 8:20 == 15.7
9/17/14 8:25 == 15.8
9/17/14 8:30 == 15.8
9/17/14 8:35 == 15.8
9/17/14 8:40 == 15.8
9/17/14 8:45 == 15.7
9/17/14 8:50 == 15.8
9/17/14 8:55 == 15.8
9/17/14 9:00 == 15.7
9/17/14 9:05 == 15.9
9/17/14 9:10 == 15.9
9/17/14 9:15 == 15.8
9/17/14 9:20 == 15.9
9/17/14 9:25 == 15.9
9/17/14 9:30 == 15.9
9/17/14 9:35 == 15.9
9/17/14 9:40 == 15.8
9/17/14 9:45 == 15.8
9/17/14 9:50 == 15.8
9/17/14 9:55 == 15.8
9/17/14 10:00 == 15.8
9/17/14 10:05 == 15.8
9/17/14 10:10 == 15.8
9/17/14 10:15 == 15.9
9/17/14 10:20 == 15.9
9/17/14 10:25 == 15.8
9/17/14 10:30 == 15.9
9/17/14 10:35 == 15.9
9/17/14 10:40 == 15.8
9/17/14 10:45 == 15.9
9/17/14 10:50 == 15.9
9/17/14 10:55 == 15.8
9/17/14 11:00 == 15.9
9/17/14 11:05 == 15.9
9/17/14 11:10 == 15.8
9/17/14 11:15 == 15.8
9/17/14 11:20 == 15.9
9/17/14 11:25 == 15.9
9/17/14 11:30 == 15.9
9/17/14 11:35 == 15.9
9/17/14 11:40 == 15.9
9/17/14 11:45 == 15.9
9/17/14 11:50 == 15.9
9/17/14 11:55 == 15.9
9/17/14 12:00 == 16
9/17/14 12:05 == 15.9
9/17/14 12:10 == 16
9/17/14 12:15 == 15.9
9/17/14 12:20 == 15.9
9/17/14 12:25 == 15.9
9/17/14 12:30 == 15.9
9/17/14 12:35 == 15.9
9/17/14 12:40 == 15.9
9/17/14 12:45 == 15.8
9/17/14 12:50 == 15.9
9/17/14 12:55 == 15.9
9/17/14 13:00 == 15.9
9/17/14 13:05 == 16
9/17/14 13:10 == 15.9
9/17/14 13:15 == 15.9
9/17/14 13:20 == 15.8
9/17/14 13:25 == 15.9
9/17/14 13:30 == 15.8
9/17/14 13:35 == 15.9
9/17/14 13:40 == 16
9/17/14 13:45 == 15.9
9/17/14 13:50 == 15.9
9/17/14 13:55 == 15.9
9/17/14 14:00 == 15.9
9/17/14 14:05 == 15.9
9/17/14 14:10 == 15.9
9/17/14 14:15 == 15.9
9/17/14 14:20 == 15.9
9/17/14 14:25 == 15.9
9/17/14 14:30 == 15.9
9/17/14 14:35 == 15.9
9/17/14 14:40 == 15.9
9/17/14 14:45 == 15.8
9/17/14 14:50 == 15.9
9/17/14 14:55 == 15.9
9/17/14 15:00 == 25.5
9/17/14 15:05 == 47.6
9/17/14 15:10 == 47.9
9/17/14 15:15 == 47.9
9/17/14 15:20 == 48
9/17/14 15:25 == 47.9
9/17/14 15:30 == 48
9/17/14 15:35 == 48.2
9/17/14 15:40 == 48
9/17/14 15:45 == 48.1
9/17/14 15:50 == 48.1
9/17/14 15:55 == 47.9
9/17/14 16:00 == 48
9/17/14 16:05 == 48
9/17/14 16:10 == 48
9/17/14 16:15 == 48.1
9/17/14 16:20 == 48
9/17/14 16:25 == 48
9/17/14 16:30 == 48
9/17/14 16:35 == 48
9/17/14 16:40 == 48
9/17/14 16:45 == 48
9/17/14 16:50 == 48
9/17/14 16:55 == 48
9/17/14 17:00 == 47.9
9/17/14 17:05 == 48
9/17/14 17:10 == 48
9/17/14 17:15 == 48
9/17/14 17:20 == 48
9/17/14 17:25 == 48
9/17/14 17:30 == 48
9/17/14 17:35 == 47.9
9/17/14 17:40 == 48
9/17/14 17:45 == 48
9/17/14 17:50 == 47.9
9/17/14 17:55 == 48
9/17/14 18:00 == 48.1
9/17/14 18:05 == 48.1
9/17/14 18:10 == 47.9
9/17/14 18:15 == 47.9
9/17/14 18:20 == 48
9/17/14 18:25 == 48
9/17/14 18:30 == 48
9/17/14 18:35 == 47.8
9/17/14 18:40 == 48
9/17/14 18:45 == 47.7
9/17/14 18:50 == 48
9/17/14 18:55 == 47.9
9/17/14 19:00 == 48.1
9/17/14 19:05 == 47.9
9/17/14 19:10 == 48
9/17/14 19:15 == 48.1

Pumpback Station Discharge (0364)

9/17/14 19:20 == 48.1
9/17/14 19:25 == 48
9/17/14 19:30 == 48
9/17/14 19:35 == 46.9
9/17/14 19:40 == 35.2
9/17/14 19:45 == 35
9/17/14 19:50 == 35
9/17/14 19:55 == 35.3
9/17/14 20:00 == 35.2
9/17/14 20:05 == 35.3
9/17/14 20:10 == 35.4
9/17/14 20:15 == 35.4
9/17/14 20:20 == 35.4
9/17/14 20:25 == 35.3
9/17/14 20:30 == 35.4
9/17/14 20:35 == 35.3
9/17/14 20:40 == 35.3
9/17/14 20:45 == 35.4
9/17/14 20:50 == 35.3
9/17/14 20:55 == 35.4
9/17/14 21:00 == 35.2
9/17/14 21:05 == 35.3
9/17/14 21:10 == 35.3
9/17/14 21:15 == 35.3
9/17/14 21:20 == 35.3
9/17/14 21:25 == 35.4
9/17/14 21:30 == 35.3
9/17/14 21:35 == 35.2
9/17/14 21:40 == 35.2
9/17/14 21:45 == 35.3
9/17/14 21:50 == 35.4
9/17/14 21:55 == 35.2
9/17/14 22:00 == 35.2
9/17/14 22:05 == 35.2
9/17/14 22:10 == 35.3
9/17/14 22:15 == 35.4
9/17/14 22:20 == 35.3
9/17/14 22:25 == 35.4
9/17/14 22:30 == 35.3
9/17/14 22:35 == 35.3
9/17/14 22:40 == 35.4
9/17/14 22:45 == 35.3
9/17/14 22:50 == 35.2
9/17/14 22:55 == 35.4
9/17/14 23:00 == 35.3
9/17/14 23:05 == 35.3
9/17/14 23:10 == 35.3
9/17/14 23:15 == 35.4
9/17/14 23:20 == 35.4
9/17/14 23:25 == 35.4
9/17/14 23:30 == 35.4
9/17/14 23:35 == 35.5
9/17/14 23:40 == 35.4
9/17/14 23:45 == 35.5
9/17/14 23:50 == 35.5
9/17/14 23:55 == 35.5
9/18/14 0:00 == 35.4
9/18/14 0:05 == 35.3
9/18/14 0:10 == 35.3
9/18/14 0:15 == 35.3
9/18/14 0:20 == 35.2
9/18/14 0:25 == 35.3
9/18/14 0:30 == 35.3
9/18/14 0:35 == 35.3
9/18/14 0:40 == 35.1
9/18/14 0:45 == 35.2
9/18/14 0:50 == 35.2
9/18/14 0:55 == 35
9/18/14 1:00 == 35.1
9/18/14 1:05 == 35
9/18/14 1:10 == 35.1
9/18/14 1:15 == 35
9/18/14 1:20 == 35.2
9/18/14 1:25 == 35.1
9/18/14 1:30 == 35.1
9/18/14 1:35 == 35.2
9/18/14 1:40 == 35.2
9/18/14 1:45 == 35.1
9/18/14 1:50 == 35.2
9/18/14 1:55 == 35.1
9/18/14 2:00 == 35.2
9/18/14 2:05 == 35.2
9/18/14 2:10 == 35.1
9/18/14 2:15 == 35.2
9/18/14 2:20 == 35.2
9/18/14 2:25 == 35.1
9/18/14 2:30 == 35
9/18/14 2:35 == 35.1
9/18/14 2:40 == 35.1
9/18/14 2:45 == 35
9/18/14 2:50 == 35
9/18/14 2:55 == 35.1
9/18/14 3:00 == 35
9/18/14 3:05 == 35.1
9/18/14 3:10 == 35.2
9/18/14 3:15 == 35.1
9/18/14 3:20 == 35.1
9/18/14 3:25 == 35.1
9/18/14 3:30 == 35.2
9/18/14 3:35 == 35.1
9/18/14 3:40 == 35
9/18/14 3:45 == 35
9/18/14 3:50 == 35.2
9/18/14 3:55 == 35
9/18/14 4:00 == 35.1
9/18/14 4:05 == 35.2
9/18/14 4:10 == 35.2
9/18/14 4:15 == 35.2
9/18/14 4:20 == 35.4
9/18/14 4:25 == 35.2
9/18/14 4:30 == 35.3
9/18/14 4:35 == 35.2
9/18/14 4:40 == 34.8
9/18/14 4:45 == 34.8
9/18/14 4:50 == 34.8
9/18/14 4:55 == 34.9
9/18/14 5:00 == 34.9
9/18/14 5:05 == 34.9
9/18/14 5:10 == 34.9
9/18/14 5:15 == 34.8
9/18/14 5:20 == 34.9
9/18/14 5:25 == 34.9
9/18/14 5:30 == 34.9
9/18/14 5:35 == 34.8
9/18/14 5:40 == 35
9/18/14 5:45 == 35
9/18/14 5:50 == 35
9/18/14 5:55 == 34.9
9/18/14 6:00 == 34.9
9/18/14 6:05 == 35
9/18/14 6:10 == 34.9
9/18/14 6:15 == 34.9
9/18/14 6:20 == 35
9/18/14 6:25 == 35.1
9/18/14 6:30 == 35.2
9/18/14 6:35 == 35.2
9/18/14 6:40 == 35.1
9/18/14 6:45 == 35.2
9/18/14 6:50 == 35.2
9/18/14 6:55 == 35.2
9/18/14 7:00 == 35.1
9/18/14 7:05 == 35.3
9/18/14 7:10 == 35.5
9/18/14 7:15 == 35.5
9/18/14 7:20 == 35.1
9/18/14 7:25 == 35.2
9/18/14 7:30 == 35
9/18/14 7:35 == 35.2
9/18/14 7:40 == 34.9
9/18/14 7:45 == 34.9
9/18/14 7:50 == 34.6
9/18/14 7:55 == 34.3
9/18/14 8:00 == 33.9
9/18/14 8:05 == 32.9
9/18/14 8:10 == 33.5
9/18/14 8:15 == 33.6
9/18/14 8:20 == 33.7
9/18/14 8:25 == 33.8
9/18/14 8:30 == 33.7
9/18/14 8:35 == 34
9/18/14 8:40 == 34.3
9/18/14 8:45 == 34.4
9/18/14 8:50 == 34.3
9/18/14 8:55 == 34.3
9/18/14 9:00 == 34.3
9/18/14 9:05 == 34.3
9/18/14 9:10 == 34.3
9/18/14 9:15 == 34.5
9/18/14 9:20 == 34.3
9/18/14 9:25 == 34.5
9/18/14 9:30 == 34.5
9/18/14 9:35 == 34.5
9/18/14 9:40 == 34.5
9/18/14 9:45 == 34.5
9/18/14 9:50 == 34.4
9/18/14 9:55 == 34.5
9/18/14 10:00 == 34.5
9/18/14 10:05 == 34.6
9/18/14 10:10 == 34.6
9/18/14 10:15 == 34.6
9/18/14 10:20 == 34.5
9/18/14 10:25 == 34.7
9/18/14 10:30 == 34.6
9/18/14 10:35 == 34.6
9/18/14 10:40 == 34.7
9/18/14 10:45 == 34.7
9/18/14 10:50 == 34.6
9/18/14 10:55 == 34.7
9/18/14 11:00 == 34.8
9/18/14 11:05 == 34.7
9/18/14 11:10 == 34.9
9/18/14 11:15 == 35.1
9/18/14 11:20 == 35
9/18/14 11:25 == 35.1
9/18/14 11:30 == 35
9/18/14 11:35 == 35.2
9/18/14 11:40 == 35.3
9/18/14 11:45 == 35.4
9/18/14 11:50 == 35.2
9/18/14 11:55 == 35.1
9/18/14 12:00 == 35.1
9/18/14 12:05 == 35.3
9/18/14 12:10 == 35.4
9/18/14 12:15 == 35.2
9/18/14 12:20 == 34.9
9/18/14 12:25 == 34.9
9/18/14 12:30 == 35.2
9/18/14 12:35 == 35.4
9/18/14 12:40 == 35.3
9/18/14 12:45 == 34.7
9/18/14 12:50 == 34.9
9/18/14 12:55 == 34.8
9/18/14 13:00 == 34.8
9/18/14 13:05 == 34.8
9/18/14 13:10 == 34.9
9/18/14 13:15 == 34.9
9/18/14 13:20 == 34.9
9/18/14 13:25 == 34.9
9/18/14 13:30 == 35.1
9/18/14 13:35 == 35.4

Pumpback Station Discharge (0364)

9/18/14 13:40 == 35.4
9/18/14 13:45 == 35.4
9/18/14 13:50 == 35.1
9/18/14 13:55 == 35.2
9/18/14 14:00 == 35.3
9/18/14 14:05 == 35.5
9/18/14 14:10 == 35.3
9/18/14 14:15 == 35.4
9/18/14 14:20 == 35.6
9/18/14 14:25 == 35.3
9/18/14 14:30 == 35.3
9/18/14 14:35 == 35.4
9/18/14 14:40 == 35.5
9/18/14 14:45 == 35.5
9/18/14 14:50 == 35.4
9/18/14 14:55 == 35.4
9/18/14 15:00 == 35.4
9/18/14 15:05 == 35.4
9/18/14 15:10 == 35.5
9/18/14 15:15 == 35.5
9/18/14 15:20 == 35.6
9/18/14 15:25 == 35.4
9/18/14 15:30 == 35.5
9/18/14 15:35 == 35.6
9/18/14 15:40 == 35.6
9/18/14 15:45 == 35.4
9/18/14 15:50 == 35.4
9/18/14 15:55 == 35.6
9/18/14 16:00 == 35.7
9/18/14 16:05 == 35.6
9/18/14 16:10 == 35.7
9/18/14 16:15 == 35.5
9/18/14 16:20 == 35.4
9/18/14 16:25 == 35.5
9/18/14 16:30 == 35.5
9/18/14 16:35 == 35.4
9/18/14 16:40 == 35.5
9/18/14 16:45 == 35.5
9/18/14 16:50 == 35.5
9/18/14 16:55 == 35.5
9/18/14 17:00 == 35.5
9/18/14 17:05 == 35.4
9/18/14 17:10 == 35.6
9/18/14 17:15 == 35.4
9/18/14 17:20 == 35.3
9/18/14 17:25 == 35.4
9/18/14 17:30 == 35.4
9/18/14 17:35 == 35.4
9/18/14 17:40 == 35.4
9/18/14 17:45 == 35.5
9/18/14 17:50 == 35.4
9/18/14 17:55 == 35.4
9/18/14 18:00 == 35.4
9/18/14 18:05 == 35.4
9/18/14 18:10 == 35.5
9/18/14 18:15 == 35.3
9/18/14 18:20 == 35.4
9/18/14 18:25 == 35.4
9/18/14 18:30 == 35.3
9/18/14 18:35 == 35.4
9/18/14 18:40 == 35.3
9/18/14 18:45 == 35.3
9/18/14 18:50 == 35.2
9/18/14 18:55 == 35.2
9/18/14 19:00 == 35.3
9/18/14 19:05 == 35.3
9/18/14 19:10 == 35.3
9/18/14 19:15 == 35.3
9/18/14 19:20 == 35.3
9/18/14 19:25 == 35.2
9/18/14 19:30 == 35.3
9/18/14 19:35 == 35.3
9/18/14 19:40 == 35.2
9/18/14 19:45 == 35.3
9/18/14 19:50 == 35.2
9/18/14 19:55 == 35.2
9/18/14 20:00 == 35.1
9/18/14 20:05 == 35.2
9/18/14 20:10 == 35.2
9/18/14 20:15 == 35.1
9/18/14 20:20 == 35.2
9/18/14 20:25 == 35.3
9/18/14 20:30 == 35.2
9/18/14 20:35 == 35.2
9/18/14 20:40 == 35.2
9/18/14 20:45 == 35.2
9/18/14 20:50 == 35.2
9/18/14 20:55 == 35.2
9/18/14 21:00 == 35.2
9/18/14 21:05 == 35.2
9/18/14 21:10 == 35.2
9/18/14 21:15 == 35.3
9/18/14 21:20 == 35.2
9/18/14 21:25 == 35.2
9/18/14 21:30 == 35.2
9/18/14 21:35 == 35.1
9/18/14 21:40 == 35.2
9/18/14 21:45 == 35.2
9/18/14 21:50 == 35.1
9/18/14 21:55 == 35.1
9/18/14 22:00 == 35
9/18/14 22:05 == 35.1
9/18/14 22:10 == 35.2
9/18/14 22:15 == 35.1
9/18/14 22:20 == 35.1
9/18/14 22:25 == 34.9
9/18/14 22:30 == 35
9/18/14 22:35 == 35
9/18/14 22:40 == 34.9
9/18/14 22:45 == 35.1
9/18/14 22:50 == 34.9
9/18/14 22:55 == 35
9/18/14 23:00 == 35
9/18/14 23:05 == 35
9/18/14 23:10 == 35
9/18/14 23:15 == 35.1
9/18/14 23:20 == 34.9
9/18/14 23:25 == 34.8
9/18/14 23:30 == 34.9
9/18/14 23:35 == 34.8
9/18/14 23:40 == 35.1
9/18/14 23:45 == 34.8
9/18/14 23:50 == 34.7
9/18/14 23:55 == 34.9
9/19/14 0:00 == 34.6
9/19/14 0:05 == 34.7
9/19/14 0:10 == 34.7
9/19/14 0:15 == 34.5
9/19/14 0:20 == 34.4
9/19/14 0:25 == 34.8
9/19/14 0:30 == 34.6
9/19/14 0:35 == 34.3
9/19/14 0:40 == 34.7
9/19/14 0:45 == 34.7
9/19/14 0:50 == 34.2
9/19/14 0:55 == 34.6
9/19/14 1:00 == 34.6
9/19/14 1:05 == 34.4
9/19/14 1:10 == 34.1
9/19/14 1:15 == 34.8
9/19/14 1:20 == 34.5
9/19/14 1:25 == 34.4
9/19/14 1:30 == 34.3
9/19/14 1:35 == 34.6
9/19/14 1:40 == 34.7
9/19/14 1:45 == 34.3
9/19/14 1:50 == 34.8
9/19/14 1:55 == 34.6
9/19/14 2:00 == 34.3
9/19/14 2:05 == 34.1
9/19/14 2:10 == 34.8
9/19/14 2:15 == 34.5
9/19/14 2:20 == 34.2
9/19/14 2:25 == 33.9
9/19/14 2:30 == 34.7
9/19/14 2:35 == 34.5
9/19/14 2:40 == 34
9/19/14 2:45 == 34.2
9/19/14 2:50 == 34.5
9/19/14 2:55 == 34.2
9/19/14 3:00 == 33.7
9/19/14 3:05 == 34.4
9/19/14 3:10 == 34.4
9/19/14 3:15 == 34.2
9/19/14 3:20 == 33.7
9/19/14 3:25 == 34.1
9/19/14 3:30 == 34.4
9/19/14 3:35 == 34.2
9/19/14 3:40 == 33.8
9/19/14 3:45 == 33.7
9/19/14 3:50 == 34.4
9/19/14 3:55 == 34.4
9/19/14 4:00 == 34.3
9/19/14 4:05 == 33.7
9/19/14 4:10 == 33.7
9/19/14 4:15 == 34.5
9/19/14 4:20 == 34.1
9/19/14 4:25 == 33.9
9/19/14 4:30 == 33.5
9/19/14 4:35 == 34.2
9/19/14 4:40 == 34.2
9/19/14 4:45 == 34.1
9/19/14 4:50 == 33.7
9/19/14 4:55 == 33.6
9/19/14 5:00 == 34.5
9/19/14 5:05 == 34.2
9/19/14 5:10 == 33.8
9/19/14 5:15 == 33.5
9/19/14 5:20 == 34
9/19/14 5:25 == 34.4
9/19/14 5:30 == 34.1
9/19/14 5:35 == 33.7
9/19/14 5:40 == 33.6
9/19/14 5:45 == 34.2
9/19/14 5:50 == 34.3
9/19/14 5:55 == 34.1
9/19/14 6:00 == 33.5
9/19/14 6:05 == 33.9
9/19/14 6:10 == 34.4
9/19/14 6:15 == 34.3
9/19/14 6:20 == 33.9
9/19/14 6:25 == 33.4
9/19/14 6:30 == 34.1
9/19/14 6:35 == 34.2
9/19/14 6:40 == 34.2
9/19/14 6:45 == 33.5
9/19/14 6:50 == 34
9/19/14 6:55 == 34.3
9/19/14 7:00 == 34.1
9/19/14 7:05 == 33.6
9/19/14 7:10 == 34
9/19/14 7:15 == 34.3
9/19/14 7:20 == 34
9/19/14 7:25 == 33.6
9/19/14 7:30 == 34.2
9/19/14 7:35 == 34.1
9/19/14 7:40 == 33.7
9/19/14 7:45 == 33.3
9/19/14 7:50 == 34.1
9/19/14 7:55 == 33.8

Pumpback Station Discharge (0364)

9/19/14 8:00 == 33.3
9/19/14 8:05 == 33.5
9/19/14 8:10 == 33.7
9/19/14 8:15 == 33.6
9/19/14 8:20 == 33.1
9/19/14 8:25 == 33.3
9/19/14 8:30 == 33.6
9/19/14 8:35 == 30.3
9/19/14 8:40 == 14.8
9/19/14 8:45 == 15.3
9/19/14 8:50 == 15.4
9/19/14 8:55 == 15.6
9/19/14 9:00 == 15.5
9/19/14 9:05 == 19.1
9/19/14 9:10 == 34.5
9/19/14 9:15 == 34.1
9/19/14 9:20 == 34.6
9/19/14 9:25 == 34.3
9/19/14 9:30 == 34.3
9/19/14 9:35 == 33.7
9/19/14 9:40 == 34.2
9/19/14 9:45 == 34.3
9/19/14 9:50 == 34.3
9/19/14 9:55 == 33.5
9/19/14 10:00 == 34
9/19/14 10:05 == 34.3
9/19/14 10:10 == 34.2
9/19/14 10:15 == 33.7
9/19/14 10:20 == 33.6
9/19/14 10:25 == 34.4
9/19/14 10:30 == 34.1
9/19/14 10:35 == 33.7
9/19/14 10:40 == 33.6
9/19/14 10:45 == 34.1
9/19/14 10:50 == 34
9/19/14 10:55 == 33.9
9/19/14 11:00 == 33.4
9/19/14 11:05 == 34.3
9/19/14 11:10 == 34.1
9/19/14 11:15 == 33.9
9/19/14 11:20 == 33.5
9/19/14 11:25 == 34.1
9/19/14 11:30 == 33.9
9/19/14 11:35 == 33.7
9/19/14 11:40 == 33.5
9/19/14 11:45 == 34.2
9/19/14 11:50 == 33.9
9/19/14 11:55 == 33.9
9/19/14 12:00 == 33.4
9/19/14 12:05 == 34.1
9/19/14 12:10 == 34.1
9/19/14 12:15 == 33.9
9/19/14 12:20 == 33.4
9/19/14 12:25 == 34
9/19/14 12:30 == 34.2
9/19/14 12:35 == 33.9
9/19/14 12:40 == 33.5
9/19/14 12:45 == 33.4
9/19/14 12:50 == 34.2
9/19/14 12:55 == 33.9
9/19/14 13:00 == 33.8
9/19/14 13:05 == 34
9/19/14 13:10 == 34.1
9/19/14 13:15 == 33.9
9/19/14 13:20 == 34
9/19/14 13:25 == 34.1
9/19/14 13:30 == 33.9
9/19/14 13:35 == 34.1
9/19/14 13:40 == 34.1
9/19/14 13:45 == 34
9/19/14 13:50 == 34.4
9/19/14 13:55 == 33.9
9/19/14 14:00 == 34.2
9/19/14 14:05 == 34.2
9/19/14 14:10 == 34.1
9/19/14 14:15 == 34
9/19/14 14:20 == 34.2
9/19/14 14:25 == 34.2
9/19/14 14:30 == 34.1
9/19/14 14:35 == 34.2
9/19/14 14:40 == 34.1
9/19/14 14:45 == 34.3
9/19/14 14:50 == 34.1
9/19/14 14:55 == 34.1
9/19/14 15:00 == 34.3
9/19/14 15:05 == 34.3
9/19/14 15:10 == 34.1
9/19/14 15:15 == 34
9/19/14 15:20 == 34.5
9/19/14 15:25 == 34.3
9/19/14 15:30 == 33.9
9/19/14 15:35 == 34.5
9/19/14 15:40 == 34.3
9/19/14 15:45 == 34.2
9/19/14 15:50 == 34.5
9/19/14 15:55 == 34.3
9/19/14 16:00 == 34.2
9/19/14 16:05 == 34.3
9/19/14 16:10 == 34.3
9/19/14 16:15 == 34.2
9/19/14 16:20 == 33.9
9/19/14 16:25 == 34.5
9/19/14 16:30 == 34.1
9/19/14 16:35 == 33.9
9/19/14 16:40 == 34.3
9/19/14 16:45 == 34.1
9/19/14 16:50 == 33.8
9/19/14 16:55 == 34.1
9/19/14 17:00 == 34.1
9/19/14 17:05 == 34
9/19/14 17:10 == 33.6
9/19/14 17:15 == 34.5
9/19/14 17:20 == 34
9/19/14 17:25 == 33.9
9/19/14 17:30 == 33.8
9/19/14 17:35 == 34.5
9/19/14 17:40 == 34.1
9/19/14 17:45 == 33.9
9/19/14 17:50 == 34.3
9/19/14 17:55 == 34.2
9/19/14 18:00 == 34
9/19/14 18:05 == 34
9/19/14 18:10 == 34.3
9/19/14 18:15 == 34.2
9/19/14 18:20 == 33.9
9/19/14 18:25 == 34.2
9/19/14 18:30 == 34.2
9/19/14 18:35 == 33.8
9/19/14 18:40 == 34.2
9/19/14 18:45 == 34.2
9/19/14 18:50 == 34.1
9/19/14 18:55 == 33.9
9/19/14 19:00 == 34.3
9/19/14 19:05 == 34.1
9/19/14 19:10 == 33.9
9/19/14 19:15 == 34.2
9/19/14 19:20 == 34.2
9/19/14 19:25 == 34
9/19/14 19:30 == 33.6
9/19/14 19:35 == 34.4
9/19/14 19:40 == 34.1
9/19/14 19:45 == 33.9
9/19/14 19:50 == 34.2
9/19/14 19:55 == 34.3
9/19/14 20:00 == 34.2
9/19/14 20:05 == 33.8
9/19/14 20:10 == 34.4
9/19/14 20:15 == 34.1
9/19/14 20:20 == 33.7
9/19/14 20:25 == 34.4
9/19/14 20:30 == 34.1
9/19/14 20:35 == 33.8
9/19/14 20:40 == 34.3
9/19/14 20:45 == 34.1
9/19/14 20:50 == 33.9
9/19/14 20:55 == 33.6
9/19/14 21:00 == 34.2
9/19/14 21:05 == 33.9
9/19/14 21:10 == 33.7
9/19/14 21:15 == 34.1
9/19/14 21:20 == 33.9
9/19/14 21:25 == 33.5
9/19/14 21:30 == 34
9/19/14 21:35 == 33.9
9/19/14 21:40 == 33.6
9/19/14 21:45 == 34
9/19/14 21:50 == 33.8
9/19/14 21:55 == 33.9
9/19/14 22:00 == 33.4
9/19/14 22:05 == 34.2
9/19/14 22:10 == 33.9
9/19/14 22:15 == 33.7
9/19/14 22:20 == 33.7
9/19/14 22:25 == 34
9/19/14 22:30 == 33.8
9/19/14 22:35 == 33.5
9/19/14 22:40 == 34
9/19/14 22:45 == 33.6
9/19/14 22:50 == 33.7
9/19/14 22:55 == 33.9
9/19/14 23:00 == 33.6
9/19/14 23:05 == 33.5
9/19/14 23:10 == 33.7
9/19/14 23:15 == 33.8
9/19/14 23:20 == 33.7
9/19/14 23:25 == 33.5
9/19/14 23:30 == 34.2
9/19/14 23:35 == 33.8
9/19/14 23:40 == 33.4
9/19/14 23:45 == 33.9
9/19/14 23:50 == 33.7
9/19/14 23:55 == 33.4
9/20/14 0:00 == 33.7
9/20/14 0:05 == 33.6
9/20/14 0:10 == 33.3
9/20/14 0:15 == 33.7
9/20/14 0:20 == 33.5
9/20/14 0:25 == 33.4
9/20/14 0:30 == 33.7
9/20/14 0:35 == 33.7
9/20/14 0:40 == 33.5
9/20/14 0:45 == 33.1
9/20/14 0:50 == 33.8
9/20/14 0:55 == 33.5
9/20/14 1:00 == 33.2
9/20/14 1:05 == 33.5
9/20/14 1:10 == 33.5
9/20/14 1:15 == 33.3
9/20/14 1:20 == 33.5
9/20/14 1:25 == 33.6
9/20/14 1:30 == 33.4
9/20/14 1:35 == 33.2
9/20/14 1:40 == 33.7
9/20/14 1:45 == 33.5
9/20/14 1:50 == 33.2
9/20/14 1:55 == 33.6
9/20/14 2:00 == 33.4
9/20/14 2:05 == 33.3
9/20/14 2:10 == 33.6
9/20/14 2:15 == 33.4

Pumpback Station Discharge (0364)

9/20/14 2:20 == 33.2
9/20/14 2:25 == 33.5
9/20/14 2:30 == 33.5
9/20/14 2:35 == 29.2
9/20/14 2:40 == 15.1
9/20/14 2:45 == 15.1
9/20/14 2:50 == 15.2
9/20/14 2:55 == 15.8
9/20/14 3:00 == 15.8
9/20/14 3:05 == 20.4
9/20/14 3:10 == 34.6
9/20/14 3:15 == 34.8
9/20/14 3:20 == 34.5
9/20/14 3:25 == 34.1
9/20/14 3:30 == 34.4
9/20/14 3:35 == 34.3
9/20/14 3:40 == 34.1
9/20/14 3:45 == 34.2
9/20/14 3:50 == 34.2
9/20/14 3:55 == 33.8
9/20/14 4:00 == 34.1
9/20/14 4:05 == 34.1
9/20/14 4:10 == 33.7
9/20/14 4:15 == 33.9
9/20/14 4:20 == 33.9
9/20/14 4:25 == 34
9/20/14 4:30 == 33.6
9/20/14 4:35 == 34.1
9/20/14 4:40 == 33.8
9/20/14 4:45 == 33.6
9/20/14 4:50 == 34
9/20/14 4:55 == 33.8
9/20/14 5:00 == 33.5
9/20/14 5:05 == 34
9/20/14 5:10 == 33.7
9/20/14 5:15 == 33.4
9/20/14 5:20 == 33.8
9/20/14 5:25 == 33.7
9/20/14 5:30 == 33.5
9/20/14 5:35 == 33.7
9/20/14 5:40 == 33.5
9/20/14 5:45 == 33.4
9/20/14 5:50 == 33.7
9/20/14 5:55 == 33.6
9/20/14 6:00 == 33.7
9/20/14 6:05 == 33.3
9/20/14 6:10 == 33.7
9/20/14 6:15 == 33.5
9/20/14 6:20 == 33.4
9/20/14 6:25 == 33.6
9/20/14 6:30 == 33.4
9/20/14 6:35 == 33.1
9/20/14 6:40 == 33.9
9/20/14 6:45 == 33.4
9/20/14 6:50 == 28.4
9/20/14 6:55 == 14.9
9/20/14 7:00 == 15.3
9/20/14 7:05 == 15.4
9/20/14 7:10 == 15.5
9/20/14 7:15 == 15.7
9/20/14 7:20 == 20.8
9/20/14 7:25 == 34.6
9/20/14 7:30 == 34.1
9/20/14 7:35 == 34.8
9/20/14 7:40 == 34.2
9/20/14 7:45 == 34
9/20/14 7:50 == 34
9/20/14 7:55 == 33.9
9/20/14 8:00 == 33.9
9/20/14 8:05 == 33.3
9/20/14 8:10 == 33.6
9/20/14 8:15 == 33.7
9/20/14 8:20 == 28.5
9/20/14 8:25 == 14.5
9/20/14 8:30 == 15.1
9/20/14 8:35 == 15.2
9/20/14 8:40 == 15.4
9/20/14 8:45 == 15.3
9/20/14 8:50 == 15.7
9/20/14 8:55 == 15.8
9/20/14 9:00 == 15.6
9/20/14 9:05 == 21.2
9/20/14 9:10 == 34.8
9/20/14 9:15 == 34.4
9/20/14 9:20 == 34.5
9/20/14 9:25 == 34.7
9/20/14 9:30 == 34.4
9/20/14 9:35 == 34
9/20/14 9:40 == 34.5
9/20/14 9:45 == 34.6
9/20/14 9:50 == 34.3
9/20/14 9:55 == 33.9
9/20/14 10:00 == 34.5
9/20/14 10:05 == 34.4
9/20/14 10:10 == 33.9
9/20/14 10:15 == 34
9/20/14 10:20 == 34.4
9/20/14 10:25 == 34.1
9/20/14 10:30 == 33.7
9/20/14 10:35 == 33.6
9/20/14 10:40 == 34.4
9/20/14 10:45 == 34.2
9/20/14 10:50 == 34
9/20/14 10:55 == 33.5
9/20/14 11:00 == 34.1
9/20/14 11:05 == 34.2
9/20/14 11:10 == 34.2
9/20/14 11:15 == 33.5
9/20/14 11:20 == 33.4
9/20/14 11:25 == 34.4
9/20/14 11:30 == 34.2
9/20/14 11:35 == 34.1
9/20/14 11:40 == 33.7
9/20/14 11:45 == 34.2
9/20/14 11:50 == 34.4
9/20/14 11:55 == 34.2
9/20/14 12:00 == 33.9
9/20/14 12:05 == 33.7
9/20/14 12:10 == 34.5
9/20/14 12:15 == 34.3
9/20/14 12:20 == 34.1
9/20/14 12:25 == 33.7
9/20/14 12:30 == 34.2
9/20/14 12:35 == 34.4
9/20/14 12:40 == 34.3
9/20/14 12:45 == 33.7
9/20/14 12:50 == 34.2
9/20/14 12:55 == 34.4
9/20/14 13:00 == 34.3
9/20/14 13:05 == 33.8
9/20/14 13:10 == 33.9
9/20/14 13:15 == 34.6
9/20/14 13:20 == 34.3
9/20/14 13:25 == 34
9/20/14 13:30 == 34.1
9/20/14 13:35 == 34.9
9/20/14 13:40 == 34.6
9/20/14 13:45 == 34.1
9/20/14 13:50 == 34
9/20/14 13:55 == 34.8
9/20/14 14:00 == 34.6
9/20/14 14:05 == 34.4
9/20/14 14:10 == 34.1
9/20/14 14:15 == 34.7
9/20/14 14:20 == 34.5
9/20/14 14:25 == 34.3
9/20/14 14:30 == 34.5
9/20/14 14:35 == 34.6
9/20/14 14:40 == 34.5
9/20/14 14:45 == 33.9
9/20/14 14:50 == 34.4
9/20/14 14:55 == 34.9
9/20/14 15:00 == 34.7
9/20/14 15:05 == 34.4
9/20/14 15:10 == 34
9/20/14 15:15 == 34.6
9/20/14 15:20 == 34.7
9/20/14 15:25 == 34.3
9/20/14 15:30 == 34.2
9/20/14 15:35 == 34.7
9/20/14 15:40 == 34.6
9/20/14 15:45 == 34.4
9/20/14 15:50 == 34
9/20/14 15:55 == 34.6
9/20/14 16:00 == 34.7
9/20/14 16:05 == 34.6
9/20/14 16:10 == 34
9/20/14 16:15 == 34.5
9/20/14 16:20 == 34.6
9/20/14 16:25 == 34.4
9/20/14 16:30 == 34
9/20/14 16:35 == 34
9/20/14 16:40 == 34.7
9/20/14 16:45 == 34.7
9/20/14 16:50 == 34.5
9/20/14 16:55 == 34
9/20/14 17:00 == 34.5
9/20/14 17:05 == 34.6
9/20/14 17:10 == 34.4
9/20/14 17:15 == 34.1
9/20/14 17:20 == 34.7
9/20/14 17:25 == 34.6
9/20/14 17:30 == 34.6
9/20/14 17:35 == 34.1
9/20/14 17:40 == 34.5
9/20/14 17:45 == 34.6
9/20/14 17:50 == 34.5
9/20/14 17:55 == 34.1
9/20/14 18:00 == 34.8
9/20/14 18:05 == 34.6
9/20/14 18:10 == 34.4
9/20/14 18:15 == 34.4
9/20/14 18:20 == 34.9
9/20/14 18:25 == 34.6
9/20/14 18:30 == 34.2
9/20/14 18:35 == 35
9/20/14 18:40 == 34.7
9/20/14 18:45 == 34.4
9/20/14 18:50 == 34.8
9/20/14 18:55 == 34.7
9/20/14 19:00 == 34.6
9/20/14 19:05 == 34.3
9/20/14 19:10 == 35
9/20/14 19:15 == 34.7
9/20/14 19:20 == 34.3
9/20/14 19:25 == 34.5
9/20/14 19:30 == 34.5
9/20/14 19:35 == 34.4
9/20/14 19:40 == 12.3
9/20/14 19:45 == 0
9/20/14 19:50 == 0
9/20/14 19:55 == 0
9/20/14 20:00 == #
9/20/14 20:05 == 0
9/20/14 20:10 == 0
9/20/14 20:15 == 0
9/20/14 20:20 == 0
9/20/14 20:25 == 0
9/20/14 20:30 == #
9/20/14 20:35 == 0

Pumpback Station Discharge (0364)

9/20/14 20:40 == 0
9/20/14 20:45 == 0
9/20/14 20:50 == 0
9/20/14 20:55 == 1.1
9/20/14 21:00 == 29.5
9/20/14 21:05 == 48
9/20/14 21:10 == 47.9
9/20/14 21:15 == 48.1
9/20/14 21:20 == 48
9/20/14 21:25 == 48
9/20/14 21:30 == 47.9
9/20/14 21:35 == 48.1
9/20/14 21:40 == 47.9
9/20/14 21:45 == 48.1
9/20/14 21:50 == 48
9/20/14 21:55 == 48
9/20/14 22:00 == 48
9/20/14 22:05 == 48
9/20/14 22:10 == 47.9
9/20/14 22:15 == 48
9/20/14 22:20 == 48
9/20/14 22:25 == 48
9/20/14 22:30 == 48
9/20/14 22:35 == 48
9/20/14 22:40 == 48
9/20/14 22:45 == 47.9
9/20/14 22:50 == 48
9/20/14 22:55 == 47.9
9/20/14 23:00 == 47.9
9/20/14 23:05 == 48.1
9/20/14 23:10 == 48
9/20/14 23:15 == 47.9
9/20/14 23:20 == 42.8
9/20/14 23:25 == 34.2
9/20/14 23:30 == 34.5
9/20/14 23:35 == 34.5
9/20/14 23:40 == 34.4
9/20/14 23:45 == 34.3
9/20/14 23:50 == 34.7
9/20/14 23:55 == 34.5
9/21/14 0:00 == 34.3
9/21/14 0:05 == 34.4
9/21/14 0:10 == 34.8
9/21/14 0:15 == 34.6
9/21/14 0:20 == 34.4
9/21/14 0:25 == 34.7
9/21/14 0:30 == 34.7
9/21/14 0:35 == 34.2
9/21/14 0:40 == 34.7
9/21/14 0:45 == 34.6
9/21/14 0:50 == 34.3
9/21/14 0:55 == 34.3
9/21/14 1:00 == 34.7
9/21/14 1:05 == 34.5
9/21/14 1:10 == 34
9/21/14 1:15 == 34.5
9/21/14 1:20 == 34.5
9/21/14 1:25 == 34.4
9/21/14 1:30 == 34.2
9/21/14 1:35 == 0.4
9/21/14 1:40 == 0
9/21/14 1:45 == 0
9/21/14 1:50 == #
9/21/14 1:55 == #
9/21/14 2:00 == 0
9/21/14 2:05 == 0
9/21/14 2:10 == #
9/21/14 2:15 == #
9/21/14 2:20 == #
9/21/14 2:25 == 0
9/21/14 2:30 == 0
9/21/14 2:35 == 0
9/21/14 2:40 == 0
9/21/14 2:45 == 5
9/21/14 2:50 == 37.5
9/21/14 2:55 == 48
9/21/14 3:00 == 48
9/21/14 3:05 == 48
9/21/14 3:10 == 47.9
9/21/14 3:15 == 48
9/21/14 3:20 == 48
9/21/14 3:25 == 48.1
9/21/14 3:30 == 48
9/21/14 3:35 == 47.9
9/21/14 3:40 == 48.1
9/21/14 3:45 == 47.9
9/21/14 3:50 == 47.9
9/21/14 3:55 == 48
9/21/14 4:00 == 48.1
9/21/14 4:05 == 48
9/21/14 4:10 == 48
9/21/14 4:15 == 48
9/21/14 4:20 == 48.1
9/21/14 4:25 == 48
9/21/14 4:30 == 48
9/21/14 4:35 == 48.1
9/21/14 4:40 == 48
9/21/14 4:45 == 48
9/21/14 4:50 == 42.2
9/21/14 4:55 == 33.4
9/21/14 5:00 == 33.5
9/21/14 5:05 == 33.6
9/21/14 5:10 == 33.8
9/21/14 5:15 == 33.7
9/21/14 5:20 == 33.7
9/21/14 5:25 == 33.8
9/21/14 5:30 == 33.7
9/21/14 5:35 == 33.8
9/21/14 5:40 == 33.9
9/21/14 5:45 == 33.8
9/21/14 5:50 == 33.7
9/21/14 5:55 == 33.7
9/21/14 6:00 == 33.7
9/21/14 6:05 == 33.7
9/21/14 6:10 == 33.7
9/21/14 6:15 == 34.4
9/21/14 6:20 == 34.5
9/21/14 6:25 == 34.6
9/21/14 6:30 == 34.6
9/21/14 6:35 == 34.6
9/21/14 6:40 == 34.6
9/21/14 6:45 == 34.5
9/21/14 6:50 == 34.5
9/21/14 6:55 == 34.5
9/21/14 7:00 == 34.6
9/21/14 7:05 == 34.6
9/21/14 7:10 == 34.6
9/21/14 7:15 == 34.6
9/21/14 7:20 == 34.5
9/21/14 7:25 == 34.4
9/21/14 7:30 == 34.3
9/21/14 7:35 == 34.1
9/21/14 7:40 == 34
9/21/14 7:45 == 34.1
9/21/14 7:50 == 33.9
9/21/14 7:55 == 33.9
9/21/14 8:00 == 33.8
9/21/14 8:05 == 33.8
9/21/14 8:10 == 33.7
9/21/14 8:15 == 33.8
9/21/14 8:20 == 33.7
9/21/14 8:25 == 33.7
9/21/14 8:30 == 33.8
9/21/14 8:35 == 26.8
9/21/14 8:40 == 15.3
9/21/14 8:45 == 15.3
9/21/14 8:50 == 15.6
9/21/14 8:55 == 15.8
9/21/14 9:00 == 15.9
9/21/14 9:05 == 23.4
9/21/14 9:10 == 34.8
9/21/14 9:15 == 34.7
9/21/14 9:20 == 34.5
9/21/14 9:25 == 34.3
9/21/14 9:30 == 34.3
9/21/14 9:35 == 34.1
9/21/14 9:40 == 34
9/21/14 9:45 == 34.1
9/21/14 9:50 == 34.2
9/21/14 9:55 == 34.1
9/21/14 10:00 == 34.1
9/21/14 10:05 == 34.1
9/21/14 10:10 == 34.1
9/21/14 10:15 == 34.1
9/21/14 10:20 == 34.1
9/21/14 10:25 == 34
9/21/14 10:30 == 34.1
9/21/14 10:35 == 34
9/21/14 10:40 == 34.1
9/21/14 10:45 == 34.2
9/21/14 10:50 == 34.1
9/21/14 10:55 == 33.9
9/21/14 11:00 == 34
9/21/14 11:05 == 34
9/21/14 11:10 == 34.1
9/21/14 11:15 == 34.1
9/21/14 11:20 == 34.1
9/21/14 11:25 == 34.1
9/21/14 11:30 == 34.1
9/21/14 11:35 == 34.3
9/21/14 11:40 == 34.5
9/21/14 11:45 == 34.4
9/21/14 11:50 == 34.3
9/21/14 11:55 == 34.3
9/21/14 12:00 == 34.3
9/21/14 12:05 == 34.3
9/21/14 12:10 == 34.3
9/21/14 12:15 == 34.2
9/21/14 12:20 == 34.3
9/21/14 12:25 == 34.3
9/21/14 12:30 == 34.2
9/21/14 12:35 == 34.5
9/21/14 12:40 == 34.6
9/21/14 12:45 == 34.5
9/21/14 12:50 == 34.5
9/21/14 12:55 == 34.4
9/21/14 13:00 == 34.6
9/21/14 13:05 == 34.5
9/21/14 13:10 == 34.5
9/21/14 13:15 == 34.4
9/21/14 13:20 == 34.6
9/21/14 13:25 == 34.5
9/21/14 13:30 == 34.6
9/21/14 13:35 == 34.7
9/21/14 13:40 == 34.5
9/21/14 13:45 == 34.6
9/21/14 13:50 == 34.6
9/21/14 13:55 == 34.7
9/21/14 14:00 == 34.6
9/21/14 14:05 == 34.6
9/21/14 14:10 == 34.7
9/21/14 14:15 == 34.6
9/21/14 14:20 == 34.7
9/21/14 14:25 == 34.8
9/21/14 14:30 == 34.7
9/21/14 14:35 == 34.7
9/21/14 14:40 == 34.6
9/21/14 14:45 == 34.6
9/21/14 14:50 == 34.6
9/21/14 14:55 == 34.6

Pumpback Station Discharge (0364)

9/21/14 15:00 == 34.6
9/21/14 15:05 == 34.5
9/21/14 15:10 == 34.5
9/21/14 15:15 == 34.5
9/21/14 15:20 == 34.5
9/21/14 15:25 == 34.6
9/21/14 15:30 == 34.6
9/21/14 15:35 == 34.6
9/21/14 15:40 == 34.6
9/21/14 15:45 == 34.5
9/21/14 15:50 == 34.5
9/21/14 15:55 == 34.4
9/21/14 16:00 == 34.3
9/21/14 16:05 == 34.4
9/21/14 16:10 == 34.6
9/21/14 16:15 == 34.5
9/21/14 16:20 == 34.5
9/21/14 16:25 == 34.5
9/21/14 16:30 == 34.4
9/21/14 16:35 == 34.5
9/21/14 16:40 == 34.5
9/21/14 16:45 == 34.5
9/21/14 16:50 == 34.5
9/21/14 16:55 == 34.5
9/21/14 17:00 == 34.5
9/21/14 17:05 == 34.5
9/21/14 17:10 == 34.5
9/21/14 17:15 == 34.6
9/21/14 17:20 == 34.7
9/21/14 17:25 == 34.5
9/21/14 17:30 == 34.5
9/21/14 17:35 == 34.4
9/21/14 17:40 == 34.6
9/21/14 17:45 == 34.7
9/21/14 17:50 == 34.6
9/21/14 17:55 == 34.5
9/21/14 18:00 == 34.6
9/21/14 18:05 == 34.6
9/21/14 18:10 == 34.7
9/21/14 18:15 == 34.7
9/21/14 18:20 == 34.6
9/21/14 18:25 == 34.5
9/21/14 18:30 == 34.6
9/21/14 18:35 == 34.5
9/21/14 18:40 == 34.5
9/21/14 18:45 == 34.7
9/21/14 18:50 == 34.5
9/21/14 18:55 == 34.5
9/21/14 19:00 == 34.6
9/21/14 19:05 == 34.5
9/21/14 19:10 == 34.4
9/21/14 19:15 == 34.6
9/21/14 19:20 == 34.4
9/21/14 19:25 == 34.5
9/21/14 19:30 == 34.5
9/21/14 19:35 == 34.5
9/21/14 19:40 == 34.6
9/21/14 19:45 == 34.7
9/21/14 19:50 == 34.6
9/21/14 19:55 == 34.4
9/21/14 20:00 == 34.5
9/21/14 20:05 == 34.5
9/21/14 20:10 == 34.5
9/21/14 20:15 == 34.6
9/21/14 20:20 == 34.5
9/21/14 20:25 == 34.5
9/21/14 20:30 == 34.5
9/21/14 20:35 == 34.4
9/21/14 20:40 == 34.3
9/21/14 20:45 == 34.3
9/21/14 20:50 == 34.2
9/21/14 20:55 == 34.2
9/21/14 21:00 == 34.2
9/21/14 21:05 == 34
9/21/14 21:10 == 34.2
9/21/14 21:15 == 34.1
9/21/14 21:20 == 34
9/21/14 21:25 == 34.2
9/21/14 21:30 == 34.1
9/21/14 21:35 == 34
9/21/14 21:40 == 33.9
9/21/14 21:45 == 34.2
9/21/14 21:50 == 34
9/21/14 21:55 == 33.7
9/21/14 22:00 == 34
9/21/14 22:05 == 34
9/21/14 22:10 == 33.9
9/21/14 22:15 == 34.2
9/21/14 22:20 == 34.1
9/21/14 22:25 == 33.8
9/21/14 22:30 == 34.1
9/21/14 22:35 == 33.8
9/21/14 22:40 == 33.7
9/21/14 22:45 == 33.8
9/21/14 22:50 == 33.8
9/21/14 22:55 == 33.6
9/21/14 23:00 == 33.8
9/21/14 23:05 == 33.8
9/21/14 23:10 == 33.7
9/21/14 23:15 == 33.9
9/21/14 23:20 == 33.7
9/21/14 23:25 == 33.5
9/21/14 23:30 == 33.8
9/21/14 23:35 == 33.7
9/21/14 23:40 == 33.5
9/21/14 23:45 == 33.4
9/21/14 23:50 == 33.9
9/21/14 23:55 == 33.5
9/22/14 0:00 == 33.5
9/22/14 0:05 == 33.8
9/22/14 0:10 == 33.5
9/22/14 0:15 == 33.2
9/22/14 0:20 == 33.9
9/22/14 0:25 == 33.6
9/22/14 0:30 == 33.3
9/22/14 0:35 == 33.1
9/22/14 0:40 == 33.9
9/22/14 0:45 == 33.6
9/22/14 0:50 == 33.3
9/22/14 0:55 == 33.1
9/22/14 1:00 == 33.7
9/22/14 1:05 == 33.6
9/22/14 1:10 == 33
9/22/14 1:15 == 33.6
9/22/14 1:20 == 33.3
9/22/14 1:25 == 33.3
9/22/14 1:30 == 33.1
9/22/14 1:35 == 33.8
9/22/14 1:40 == 33.4
9/22/14 1:45 == 32.9
9/22/14 1:50 == 33.4
9/22/14 1:55 == 33.6
9/22/14 2:00 == 33.4
9/22/14 2:05 == 32.9
9/22/14 2:10 == 33.7
9/22/14 2:15 == 33.3
9/22/14 2:20 == 24.5
9/22/14 2:25 == 15.1
9/22/14 2:30 == 15.2
9/22/14 2:35 == 15.4
9/22/14 2:40 == 15.4
9/22/14 2:45 == 15.9
9/22/14 2:50 == 24.6
9/22/14 2:55 == 34.4
9/22/14 3:00 == 34.6
9/22/14 3:05 == 34.5
9/22/14 3:10 == 34.2
9/22/14 3:15 == 34.5
9/22/14 3:20 == 34.4
9/22/14 3:25 == 34.2
9/22/14 3:30 == 34.4
9/22/14 3:35 == 34.2
9/22/14 3:40 == 33.9
9/22/14 3:45 == 34.2
9/22/14 3:50 == 34.3
9/22/14 3:55 == 34
9/22/14 4:00 == 34
9/22/14 4:05 == 34.1
9/22/14 4:10 == 34
9/22/14 4:15 == 33.8
9/22/14 4:20 == 34.1
9/22/14 4:25 == 33.9
9/22/14 4:30 == 33.7
9/22/14 4:35 == 34.1
9/22/14 4:40 == 33.8
9/22/14 4:45 == 33.7
9/22/14 4:50 == 33.9
9/22/14 4:55 == 33.8
9/22/14 5:00 == 33.6
9/22/14 5:05 == 34
9/22/14 5:10 == 33.7
9/22/14 5:15 == 33.4
9/22/14 5:20 == 33.9
9/22/14 5:25 == 33.7
9/22/14 5:30 == 33.6
9/22/14 5:35 == 33.9
9/22/14 5:40 == 33.6
9/22/14 5:45 == 33.5
9/22/14 5:50 == 33.8
9/22/14 5:55 == 33.6
9/22/14 6:00 == 33.4
9/22/14 6:05 == 33.7
9/22/14 6:10 == 33.7
9/22/14 6:15 == 33.5
9/22/14 6:20 == 33.7
9/22/14 6:25 == 33.5
9/22/14 6:30 == 33.6
9/22/14 6:35 == 33.4
9/22/14 6:40 == 33.7
9/22/14 6:45 == 33.5
9/22/14 6:50 == 33.3
9/22/14 6:55 == 33.6
9/22/14 7:00 == 33.4
9/22/14 7:05 == 33.2
9/22/14 7:10 == 33.5
9/22/14 7:15 == 33.6
9/22/14 7:20 == 24.1
9/22/14 7:25 == 15.1
9/22/14 7:30 == 15
9/22/14 7:35 == 15.1
9/22/14 7:40 == 15
9/22/14 7:45 == 15.5
9/22/14 7:50 == 15.6
9/22/14 7:55 == 15.7
9/22/14 8:00 == 15.4
9/22/14 8:05 == 24.9
9/22/14 8:10 == 34.5
9/22/14 8:15 == 34.5
9/22/14 8:20 == 33.7
9/22/14 8:25 == 33.7
9/22/14 8:30 == 34.3
9/22/14 8:35 == 34.4
9/22/14 8:40 == 33.9
9/22/14 8:45 == 33.5
9/22/14 8:50 == 34.1
9/22/14 8:55 == 34
9/22/14 9:00 == 34
9/22/14 9:05 == 33.3
9/22/14 9:10 == 33.5
9/22/14 9:15 == 33.9

Pumpback Station Discharge (0364)

9/22/14 9:20 == 33.8
9/22/14 9:25 == 33.2
9/22/14 9:30 == 33.7
9/22/14 9:35 == 34.1
9/22/14 9:40 == 34.1
9/22/14 9:45 == 33.7
9/22/14 9:50 == 33.5
9/22/14 9:55 == 34.3
9/22/14 10:00 == 34.1
9/22/14 10:05 == 33.6
9/22/14 10:10 == 33.5
9/22/14 10:15 == 34.2
9/22/14 10:20 == 34.1
9/22/14 10:25 == 34.1
9/22/14 10:30 == 33.5
9/22/14 10:35 == 34.2
9/22/14 10:40 == 34.1
9/22/14 10:45 == 34
9/22/14 10:50 == 34.4
9/22/14 10:55 == 34.3
9/22/14 11:00 == 34.5
9/22/14 11:05 == 34.6
9/22/14 11:10 == 34.6
9/22/14 11:15 == 34.6
9/22/14 11:20 == 34.8
9/22/14 11:25 == 34.8
9/22/14 11:30 == 34.7
9/22/14 11:35 == 34.9
9/22/14 11:40 == 35.1
9/22/14 11:45 == 35.1
9/22/14 11:50 == 35.1
9/22/14 11:55 == 35.1
9/22/14 12:00 == 35.1
9/22/14 12:05 == 35.3
9/22/14 12:10 == 35.2
9/22/14 12:15 == 35.5
9/22/14 12:20 == 35.4
9/22/14 12:25 == 35.2
9/22/14 12:30 == 35.3
9/22/14 12:35 == 35.5
9/22/14 12:40 == 35.5
9/22/14 12:45 == 35.5
9/22/14 12:50 == 35.5
9/22/14 12:55 == 35.3
9/22/14 13:00 == 35.3
9/22/14 13:05 == 35.6
9/22/14 13:10 == 35.4
9/22/14 13:15 == 35.1
9/22/14 13:20 == 36
9/22/14 13:25 == 35.8
9/22/14 13:30 == 35.6
9/22/14 13:35 == 35.2
9/22/14 13:40 == 35.4
9/22/14 13:45 == 35.9
9/22/14 13:50 == 32.4
9/22/14 13:55 == 30.1
9/22/14 14:00 == 29.5
9/22/14 14:05 == 30.1
9/22/14 14:10 == 30.4
9/22/14 14:15 == 36.3
9/22/14 14:20 == 48
9/22/14 14:25 == 47.9
9/22/14 14:30 == 48
9/22/14 14:35 == 48.1
9/22/14 14:40 == 47.9
9/22/14 14:45 == 47.9
9/22/14 14:50 == 48
9/22/14 14:55 == 48
9/22/14 15:00 == 48
9/22/14 15:05 == 48.1
9/22/14 15:10 == 48
9/22/14 15:15 == 47.9
9/22/14 15:20 == 48.1
9/22/14 15:25 == 47.9
9/22/14 15:30 == 48
9/22/14 15:35 == 40
9/22/14 15:40 == 34.8
9/22/14 15:45 == 34.8
9/22/14 15:50 == 34.5
9/22/14 15:55 == 34.8
9/22/14 16:00 == 35.3
9/22/14 16:05 == 35.3
9/22/14 16:10 == 34.6
9/22/14 16:15 == 35
9/22/14 16:20 == 35.2
9/22/14 16:25 == 35.4
9/22/14 16:30 == 34.8
9/22/14 16:35 == 35.4
9/22/14 16:40 == 35.4
9/22/14 16:45 == 35
9/22/14 16:50 == 35.6
9/22/14 16:55 == 35.5
9/22/14 17:00 == 34.9
9/22/14 17:05 == 35.4
9/22/14 17:10 == 35.7
9/22/14 17:15 == 35.6
9/22/14 17:20 == 35.1
9/22/14 17:25 == 35
9/22/14 17:30 == 35.7
9/22/14 17:35 == 35.7
9/22/14 17:40 == 35.3
9/22/14 17:45 == 35.3
9/22/14 17:50 == 35.9
9/22/14 17:55 == 35.7
9/22/14 18:00 == 35.4
9/22/14 18:05 == 35.3
9/22/14 18:10 == 35.9
9/22/14 18:15 == 35.6
9/22/14 18:20 == 35.3
9/22/14 18:25 == 35.6
9/22/14 18:30 == 35.9
9/22/14 18:35 == 35.8
9/22/14 18:40 == 35.4
9/22/14 18:45 == 35.8
9/22/14 18:50 == 38.4
9/22/14 18:55 == 48
9/22/14 19:00 == 48.1
9/22/14 19:05 == 47.7
9/22/14 19:10 == 47.9
9/22/14 19:15 == 48
9/22/14 19:20 == 48
9/22/14 19:25 == 48.1
9/22/14 19:30 == 48
9/22/14 19:35 == 47.9
9/22/14 19:40 == 48.1
9/22/14 19:45 == 48
9/22/14 19:50 == 40.1
9/22/14 19:55 == 34.2
9/22/14 20:00 == 34.7
9/22/14 20:05 == 35
9/22/14 20:10 == 35
9/22/14 20:15 == 34.5
9/22/14 20:20 == 35.4
9/22/14 20:25 == 35.4
9/22/14 20:30 == 35.2
9/22/14 20:35 == 34.8
9/22/14 20:40 == 35.3
9/22/14 20:45 == 35.3
9/22/14 20:50 == 35.4
9/22/14 20:55 == 34.8
9/22/14 21:00 == 35.3
9/22/14 21:05 == 35.4
9/22/14 21:10 == 35.3
9/22/14 21:15 == 34.9
9/22/14 21:20 == 35.8
9/22/14 21:25 == 35.5
9/22/14 21:30 == 35.2
9/22/14 21:35 == 35.1
9/22/14 21:40 == 35.8
9/22/14 21:45 == 35.6
9/22/14 21:50 == 35.4
9/22/14 21:55 == 35.1
9/22/14 22:00 == 35.6
9/22/14 22:05 == 35.6
9/22/14 22:10 == 35.4
9/22/14 22:15 == 35.7
9/22/14 22:20 == 36
9/22/14 22:25 == 35.8
9/22/14 22:30 == 35.3
9/22/14 22:35 == 36
9/22/14 22:40 == 35.8
9/22/14 22:45 == 35.6
9/22/14 22:50 == 35.6
9/22/14 22:55 == 35.7
9/22/14 23:00 == 35.7
9/22/14 23:05 == 35.4
9/22/14 23:10 == 35.8
9/22/14 23:15 == 35.8
9/22/14 23:20 == 38.2
9/22/14 23:25 == 48
9/22/14 23:30 == 47.9
9/22/14 23:35 == 48
9/22/14 23:40 == 47.9
9/22/14 23:45 == 48
9/22/14 23:50 == 48.1
9/22/14 23:55 == 48.1
9/23/14 0:00 == 48
9/23/14 0:05 == 47.9
9/23/14 0:10 == 47.9
9/23/14 0:15 == 48.1
9/23/14 0:20 == 39.4
9/23/14 0:25 == 34.5
9/23/14 0:30 == 34.6
9/23/14 0:35 == 34.6
9/23/14 0:40 == 34.4
9/23/14 0:45 == 35.3
9/23/14 0:50 == 34.9
9/23/14 0:55 == 34.7
9/23/14 1:00 == 34.4
9/23/14 1:05 == 35
9/23/14 1:10 == 35
9/23/14 1:15 == 34.7
9/23/14 1:20 == 34.9
9/23/14 1:25 == 35.2
9/23/14 1:30 == 35
9/23/14 1:35 == 34.7
9/23/14 1:40 == 35.2
9/23/14 1:45 == #
9/23/14 1:50 == 35.1
9/23/14 1:55 == 35
9/23/14 2:00 == 35.2
9/23/14 2:05 == 35.5
9/23/14 2:10 == 35.4
9/23/14 2:15 == 35.3
9/23/14 2:20 == 35.1
9/23/14 2:25 == 35.6
9/23/14 2:30 == 35.3
9/23/14 2:35 == 34.9
9/23/14 2:40 == 35.3
9/23/14 2:45 == 35.3
9/23/14 2:50 == 35.1
9/23/14 2:55 == 35.2
9/23/14 3:00 == 35.7
9/23/14 3:05 == 35.5
9/23/14 3:10 == 35.1
9/23/14 3:15 == 35.1
9/23/14 3:20 == 35.6
9/23/14 3:25 == 35.4
9/23/14 3:30 == 35
9/23/14 3:35 == 35.4

Pumpback Station Discharge (0364)

9/23/14 3:40 == 35.5
9/23/14 3:45 == 35.1
9/23/14 3:50 == 35.3
9/23/14 3:55 == 35.7
9/23/14 4:00 == 35.5
9/23/14 4:05 == 35.1
9/23/14 4:10 == 35.5
9/23/14 4:15 == 35.6
9/23/14 4:20 == 35.2
9/23/14 4:25 == 35.3
9/23/14 4:30 == 35.7
9/23/14 4:35 == 35.5
9/23/14 4:40 == 34.9
9/23/14 4:45 == 35.2
9/23/14 4:50 == 35.5
9/23/14 4:55 == 35.5
9/23/14 5:00 == 35.1
9/23/14 5:05 == 35.4
9/23/14 5:10 == 35.7
9/23/14 5:15 == 35.5
9/23/14 5:20 == 35
9/23/14 5:25 == 35.6
9/23/14 5:30 == 35.5
9/23/14 5:35 == 35.3
9/23/14 5:40 == 35.3
9/23/14 5:45 == 35.6
9/23/14 5:50 == 35.5
9/23/14 5:55 == 34.9
9/23/14 6:00 == 35.5
9/23/14 6:05 == 35.5
9/23/14 6:10 == 35.3
9/23/14 6:15 == 35.2
9/23/14 6:20 == 35.7
9/23/14 6:25 == 35.7
9/23/14 6:30 == 35.4
9/23/14 6:35 == 35.2
9/23/14 6:40 == 35.7
9/23/14 6:45 == 35.4
9/23/14 6:50 == 35.1
9/23/14 6:55 == 34.9
9/23/14 7:00 == 35.4
9/23/14 7:05 == 35.3
9/23/14 7:10 == 34.6
9/23/14 7:15 == 35
9/23/14 7:20 == 35.4
9/23/14 7:25 == 35
9/23/14 7:30 == 34.7
9/23/14 7:35 == 35.2
9/23/14 7:40 == 34.9
9/23/14 7:45 == 34.5
9/23/14 7:50 == 34.6
9/23/14 7:55 == 34.8
9/23/14 8:00 == 34.5
9/23/14 8:05 == 34.2
9/23/14 8:10 == 34.9
9/23/14 8:15 == 34.7
9/23/14 8:20 == 34.8
9/23/14 8:25 == 34.5
9/23/14 8:30 == 34
9/23/14 8:35 == 35
9/23/14 8:40 == 35
9/23/14 8:45 == 34.8
9/23/14 8:50 == 34.4
9/23/14 8:55 == 34.2
9/23/14 9:00 == 34.9
9/23/14 9:05 == 35
9/23/14 9:10 == 34.6
9/23/14 9:15 == 34.4
9/23/14 9:20 == 34.3
9/23/14 9:25 == 35
9/23/14 9:30 == 35.3
9/23/14 9:35 == 34.9
9/23/14 9:40 == 34.5
9/23/14 9:45 == 34.1
9/23/14 9:50 == 34.7
9/23/14 9:55 == 35.1
9/23/14 10:00 == 34.8
9/23/14 10:05 == 34.5
9/23/14 10:10 == 34.3
9/23/14 10:15 == 34.1
9/23/14 10:20 == 35.3
9/23/14 10:25 == 35.1
9/23/14 10:30 == 34.7
9/23/14 10:35 == 34.4
9/23/14 10:40 == 34.3
9/23/14 10:45 == 35.2
9/23/14 10:50 == 35.4
9/23/14 10:55 == 35.2
9/23/14 11:00 == 34.7
9/23/14 11:05 == 34.5
9/23/14 11:10 == 35.2
9/23/14 11:15 == 35.5
9/23/14 11:20 == 35.5
9/23/14 11:25 == 35
9/23/14 11:30 == 34.8
9/23/14 11:35 == 35
9/23/14 11:40 == 39.7
9/23/14 11:45 == 47.9
9/23/14 11:50 == 48.1
9/23/14 11:55 == 47.8
9/23/14 12:00 == 48.2
9/23/14 12:05 == 48
9/23/14 12:10 == 48.1
9/23/14 12:15 == 47.9
9/23/14 12:20 == 47.8
9/23/14 12:25 == 48.1
9/23/14 12:30 == 47.9
9/23/14 12:35 == 48
9/23/14 12:40 == 47.9
9/23/14 12:45 == 48
9/23/14 12:50 == 47.9
9/23/14 12:55 == 39
9/23/14 13:00 == 34.5
9/23/14 13:05 == 34
9/23/14 13:10 == 33.9
9/23/14 13:15 == 35.1
9/23/14 13:20 == 35.2
9/23/14 13:25 == 35.1
9/23/14 13:30 == 34.8
9/23/14 13:35 == 34.4
9/23/14 13:40 == 34.3
9/23/14 13:45 == 35.7
9/23/14 13:50 == 35.5
9/23/14 13:55 == 35.5
9/23/14 14:00 == 35.1
9/23/14 14:05 == 34.7
9/23/14 14:10 == 34.6
9/23/14 14:15 == 35.5
9/23/14 14:20 == 35.8
9/23/14 14:25 == 35.6
9/23/14 14:30 == 35.1
9/23/14 14:35 == 35.1
9/23/14 14:40 == 35
9/23/14 14:45 == 35.8
9/23/14 14:50 == 35.7
9/23/14 14:55 == 35.2
9/23/14 15:00 == 35.1
9/23/14 15:05 == 35.4
9/23/14 15:10 == 39.8
9/23/14 15:15 == 48
9/23/14 15:20 == 47.9
9/23/14 15:25 == 47.8
9/23/14 15:30 == 47.9
9/23/14 15:35 == 48.1
9/23/14 15:40 == 48.1
9/23/14 15:45 == 47.9
9/23/14 15:50 == 47.9
9/23/14 15:55 == 38.8
9/23/14 16:00 == 34
9/23/14 16:05 == 34.3
9/23/14 16:10 == 35.5
9/23/14 16:15 == 35.6
9/23/14 16:20 == 35.2
9/23/14 16:25 == 35
9/23/14 16:30 == 34.7
9/23/14 16:35 == 35
9/23/14 16:40 == 35.7
9/23/14 16:45 == 35.6
9/23/14 16:50 == 35
9/23/14 16:55 == 34.8
9/23/14 17:00 == 35.1
9/23/14 17:05 == 35.9
9/23/14 17:10 == 35.7
9/23/14 17:15 == 35.3
9/23/14 17:20 == 35
9/23/14 17:25 == 34.9
9/23/14 17:30 == 35.9
9/23/14 17:35 == 35.7
9/23/14 17:40 == 35.4
9/23/14 17:45 == 35.3
9/23/14 17:50 == 35.2
9/23/14 17:55 == 36.3
9/23/14 18:00 == 36
9/23/14 18:05 == 35.8
9/23/14 18:10 == 35.4
9/23/14 18:15 == 35.4
9/23/14 18:20 == 36.1
9/23/14 18:25 == 39.9
9/23/14 18:30 == 48.1
9/23/14 18:35 == 48
9/23/14 18:40 == 48
9/23/14 18:45 == 48.2
9/23/14 18:50 == 47.9
9/23/14 18:55 == 48.1
9/23/14 19:00 == 48
9/23/14 19:05 == 48
9/23/14 19:10 == 47.9
9/23/14 19:15 == 48
9/23/14 19:20 == 48
9/23/14 19:25 == 38.3
9/23/14 19:30 == 35.2
9/23/14 19:35 == 35.1
9/23/14 19:40 == 35.3
9/23/14 19:45 == 34.7
9/23/14 19:50 == 34.5
9/23/14 19:55 == 35.2
9/23/14 20:00 == 35.7
9/23/14 20:05 == 35.4
9/23/14 20:10 == 35
9/23/14 20:15 == 34.8
9/23/14 20:20 == 35.3
9/23/14 20:25 == 35.6
9/23/14 20:30 == 35.5
9/23/14 20:35 == 34.9
9/23/14 20:40 == 35
9/23/14 20:45 == 35.7
9/23/14 20:50 == 35.6
9/23/14 20:55 == 35.4
9/23/14 21:00 == 35.2
9/23/14 21:05 == 35.7
9/23/14 21:10 == 35.8
9/23/14 21:15 == 35.5
9/23/14 21:20 == 35.3
9/23/14 21:25 == 36.1
9/23/14 21:30 == 35.9
9/23/14 21:35 == 35.4
9/23/14 21:40 == 39.5
9/23/14 21:45 == 47.9
9/23/14 21:50 == 48
9/23/14 21:55 == 48

Pumpback Station Discharge (0364)

9/23/14 22:00 == 47.8
9/23/14 22:05 == 48.1
9/23/14 22:10 == 47.8
9/23/14 22:15 == 47.9
9/23/14 22:20 == 48.1
9/23/14 22:25 == 38.6
9/23/14 22:30 == 35.2
9/23/14 22:35 == 35.1
9/23/14 22:40 == 34.9
9/23/14 22:45 == 34.7
9/23/14 22:50 == 35.4
9/23/14 22:55 == 35.4
9/23/14 23:00 == 35.1
9/23/14 23:05 == 34.8
9/23/14 23:10 == 35.6
9/23/14 23:15 == 35.5
9/23/14 23:20 == 35.1
9/23/14 23:25 == 34.9
9/23/14 23:30 == 35.2
9/23/14 23:35 == 35.7
9/23/14 23:40 == 35.5
9/23/14 23:45 == 35.1
9/23/14 23:50 == 35
9/23/14 23:55 == 35.5
9/24/14 0:00 == 35.6
9/24/14 0:05 == 35.4
9/24/14 0:10 == 35.1
9/24/14 0:15 == 34.8
9/24/14 0:20 == 35.7
9/24/14 0:25 == 35.9
9/24/14 0:30 == 35.5
9/24/14 0:35 == 35.3
9/24/14 0:40 == 34.9
9/24/14 0:45 == 35.4
9/24/14 0:50 == 35.5
9/24/14 0:55 == 35.4
9/24/14 1:00 == 34.9
9/24/14 1:05 == 34.9
9/24/14 1:10 == 35.7
9/24/14 1:15 == 35.6
9/24/14 1:20 == 35.3
9/24/14 1:25 == 35.2
9/24/14 1:30 == 35.1
9/24/14 1:35 == 36.1
9/24/14 1:40 == 35.8
9/24/14 1:45 == 35.6
9/24/14 1:50 == 34.9
9/24/14 1:55 == 34.9
9/24/14 2:00 == 35.3
9/24/14 2:05 == 35.9
9/24/14 2:10 == 35.6
9/24/14 2:15 == 35.4
9/24/14 2:20 == 35
9/24/14 2:25 == 34.9
9/24/14 2:30 == 35.8
9/24/14 2:35 == 35.7
9/24/14 2:40 == 35.4
9/24/14 2:45 == 35
9/24/14 2:50 == 34.9
9/24/14 2:55 == 35.8
9/24/14 3:00 == 35.7
9/24/14 3:05 == 35.3
9/24/14 3:10 == 35.1
9/24/14 3:15 == 35
9/24/14 3:20 == 35.8
9/24/14 3:25 == 35.7
9/24/14 3:30 == 35.2
9/24/14 3:35 == 35
9/24/14 3:40 == 35.2
9/24/14 3:45 == 35.9
9/24/14 3:50 == 35.6
9/24/14 3:55 == 35.3
9/24/14 4:00 == 35
9/24/14 4:05 == 35.4
9/24/14 4:10 == 35.8
9/24/14 4:15 == 35.5
9/24/14 4:20 == 35.2
9/24/14 4:25 == 34.9
9/24/14 4:30 == 35.5
9/24/14 4:35 == 35.9
9/24/14 4:40 == 35.7
9/24/14 4:45 == 35.2
9/24/14 4:50 == 34.9
9/24/14 4:55 == 35.3
9/24/14 5:00 == 35.7
9/24/14 5:05 == 35.6
9/24/14 5:10 == 35
9/24/14 5:15 == 35
9/24/14 5:20 == 35
9/24/14 5:25 == 35.9
9/24/14 5:30 == 35.7
9/24/14 5:35 == 35.5
9/24/14 5:40 == 35.1
9/24/14 5:45 == 34.7
9/24/14 5:50 == 35.6
9/24/14 5:55 == 35.8
9/24/14 6:00 == 35.6
9/24/14 6:05 == 35.3
9/24/14 6:10 == 35
9/24/14 6:15 == 35.4
9/24/14 6:20 == 35.8
9/24/14 6:25 == 35.7
9/24/14 6:30 == 35.1
9/24/14 6:35 == 35
9/24/14 6:40 == 35.8
9/24/14 6:45 == 35.7
9/24/14 6:50 == 35.5
9/24/14 6:55 == 35.3
9/24/14 7:00 == 35
9/24/14 7:05 == 35.8
9/24/14 7:10 == 35.6
9/24/14 7:15 == 35.2
9/24/14 7:20 == 35
9/24/14 7:25 == 35.1
9/24/14 7:30 == 35.8
9/24/14 7:35 == 35.7
9/24/14 7:40 == 35
9/24/14 7:45 == 34.7
9/24/14 7:50 == 34.4
9/24/14 7:55 == 35.1
9/24/14 8:00 == 35
9/24/14 8:05 == 34.6
9/24/14 8:10 == 34.4
9/24/14 8:15 == 34.2
9/24/14 8:20 == 35.4
9/24/14 8:25 == 35
9/24/14 8:30 == 34.6
9/24/14 8:35 == 34.5
9/24/14 8:40 == 34
9/24/14 8:45 == 34
9/24/14 8:50 == 34.6
9/24/14 8:55 == 35.2
9/24/14 9:00 == 35.2
9/24/14 9:05 == 34.7
9/24/14 9:10 == 34.3
9/24/14 9:15 == 34.1
9/24/14 9:20 == 33.9
9/24/14 9:25 == 34.4
9/24/14 9:30 == 35
9/24/14 9:35 == 34.9
9/24/14 9:40 == 34.2
9/24/14 9:45 == 34
9/24/14 9:50 == 33.8
9/24/14 9:55 == 34.4
9/24/14 10:00 == 34.3
9/24/14 10:05 == 34.3
9/24/14 10:10 == 34.2
9/24/14 10:15 == 34.2
9/24/14 10:20 == 34.1
9/24/14 10:25 == 34.4
9/24/14 10:30 == 34.5
9/24/14 10:35 == 34.5
9/24/14 10:40 == 34.7
9/24/14 10:45 == 34.6
9/24/14 10:50 == 34.8
9/24/14 10:55 == 34.7
9/24/14 11:00 == 34.9
9/24/14 11:05 == 34.8
9/24/14 11:10 == 34.9
9/24/14 11:15 == 35
9/24/14 11:20 == 34.9
9/24/14 11:25 == 35.2
9/24/14 11:30 == 35.1
9/24/14 11:35 == 35.3
9/24/14 11:40 == 40.3
9/24/14 11:45 == 47.9
9/24/14 11:50 == 48.1
9/24/14 11:55 == 47.9
9/24/14 12:00 == 48
9/24/14 12:05 == 47.9
9/24/14 12:10 == 48
9/24/14 12:15 == 47.7
9/24/14 12:20 == 48
9/24/14 12:25 == 47.9
9/24/14 12:30 == 47.9
9/24/14 12:35 == 48.1
9/24/14 12:40 == 48
9/24/14 12:45 == 48
9/24/14 12:50 == 48.1
9/24/14 12:55 == 37.9
9/24/14 13:00 == 35.3
9/24/14 13:05 == 34.6
9/24/14 13:10 == 34.5
9/24/14 13:15 == 34.7
9/24/14 13:20 == 35.3
9/24/14 13:25 == 35.5
9/24/14 13:30 == 35
9/24/14 13:35 == 34.9
9/24/14 13:40 == 35
9/24/14 13:45 == 35.8
9/24/14 13:50 == 35.3
9/24/14 13:55 == 35
9/24/14 14:00 == 34.8
9/24/14 14:05 == 35.1
9/24/14 14:10 == 36.2
9/24/14 14:15 == 36
9/24/14 14:20 == 35.8
9/24/14 14:25 == 35.6
9/24/14 14:30 == 35.3
9/24/14 14:35 == 34.9
9/24/14 14:40 == 40.4
9/24/14 14:45 == 48.1
9/24/14 14:50 == 48
9/24/14 14:55 == 47.9
9/24/14 15:00 == 47.9
9/24/14 15:05 == 48
9/24/14 15:10 == 47.9
9/24/14 15:15 == 48.1
9/24/14 15:20 == 48.1
9/24/14 15:25 == 47.9
9/24/14 15:30 == 48
9/24/14 15:35 == 47.9
9/24/14 15:40 == 48.2
9/24/14 15:45 == 47.9
9/24/14 15:50 == 48
9/24/14 15:55 == 37.4
9/24/14 16:00 == 34.3
9/24/14 16:05 == 34
9/24/14 16:10 == 34.2
9/24/14 16:15 == 35.3

Pumpback Station Discharge (0364)

9/24/14 16:20 == 35.5
9/24/14 16:25 == 35.4
9/24/14 16:30 == 35
9/24/14 16:35 == 34.7
9/24/14 16:40 == 34.4
9/24/14 16:45 == 35.6
9/24/14 16:50 == 35.9
9/24/14 16:55 == 35.5
9/24/14 17:00 == 35.1
9/24/14 17:05 == 34.8
9/24/14 17:10 == 34.6
9/24/14 17:15 == 35.6
9/24/14 17:20 == 36
9/24/14 17:25 == 35.7
9/24/14 17:30 == 35.4
9/24/14 17:35 == 34.9
9/24/14 17:40 == 35.2
9/24/14 17:45 == 36.3
9/24/14 17:50 == 36.1
9/24/14 17:55 == 35.9
9/24/14 18:00 == 35.5
9/24/14 18:05 == 35.1
9/24/14 18:10 == 40.8
9/24/14 18:15 == 48
9/24/14 18:20 == 47.9
9/24/14 18:25 == 47.9
9/24/14 18:30 == 48
9/24/14 18:35 == 47.9
9/24/14 18:40 == 48
9/24/14 18:45 == 48
9/24/14 18:50 == 48
9/24/14 18:55 == 47.9
9/24/14 19:00 == 48
9/24/14 19:05 == 48.2
9/24/14 19:10 == 37.7
9/24/14 19:15 == 35.3
9/24/14 19:20 == 34.7
9/24/14 19:25 == 34.5
9/24/14 19:30 == 34.3
9/24/14 19:35 == 35.7
9/24/14 19:40 == 35.8
9/24/14 19:45 == 35.6
9/24/14 19:50 == 35.2
9/24/14 19:55 == 34.9
9/24/14 20:00 == 34.9
9/24/14 20:05 == 35.9
9/24/14 20:10 == 35.9
9/24/14 20:15 == 35.3
9/24/14 20:20 == 35.2
9/24/14 20:25 == 35.6
9/24/14 20:30 == 36.2
9/24/14 20:35 == 36
9/24/14 20:40 == 41.1
9/24/14 20:45 == 47.9
9/24/14 20:50 == 48.1
9/24/14 20:55 == 48
9/24/14 21:00 == 48
9/24/14 21:05 == 48
9/24/14 21:10 == 47.9
9/24/14 21:15 == 47.9
9/24/14 21:20 == 48
9/24/14 21:25 == 47.8
9/24/14 21:30 == 47.9
9/24/14 21:35 == 48.2
9/24/14 21:40 == 36.8
9/24/14 21:45 == 34.8
9/24/14 21:50 == 35.6
9/24/14 21:55 == 35.6
9/24/14 22:00 == 35.2
9/24/14 22:05 == 34.9
9/24/14 22:10 == 34.8
9/24/14 22:15 == 36
9/24/14 22:20 == 35.8
9/24/14 22:25 == 35.5
9/24/14 22:30 == 35.1
9/24/14 22:35 == 34.9
9/24/14 22:40 == 35.8
9/24/14 22:45 == 36.1
9/24/14 22:50 == 36
9/24/14 22:55 == 35.4
9/24/14 23:00 == 35.3
9/24/14 23:05 == 35.5
9/24/14 23:10 == 36.3
9/24/14 23:15 == 36.1
9/24/14 23:20 == 35.7
9/24/14 23:25 == 41.5
9/24/14 23:30 == 48
9/24/14 23:35 == 48.1
9/24/14 23:40 == 47.9
9/24/14 23:45 == 47.9
9/24/14 23:50 == 48.1
9/24/14 23:55 == 47.9
9/25/14 0:00 == 48
9/25/14 0:05 == 48
9/25/14 0:10 == 47.9
9/25/14 0:15 == 47.9
9/25/14 0:20 == 48
9/25/14 0:25 == 36.6
9/25/14 0:30 == 34.3
9/25/14 0:35 == 35.4
9/25/14 0:40 == 35.8
9/25/14 0:45 == 35.8
9/25/14 0:50 == 35
9/25/14 0:55 == 34.8
9/25/14 1:00 == 34.3
9/25/14 1:05 == 34.3
9/25/14 1:10 == 34.5
9/25/14 1:15 == 34.5
9/25/14 1:20 == 34.5
9/25/14 1:25 == 34.6
9/25/14 1:30 == 34.6
9/25/14 1:35 == 35.7
9/25/14 1:40 == 36.2
9/25/14 1:45 == 36.2
9/25/14 1:50 == 35.9
9/25/14 1:55 == 35.5
9/25/14 2:00 == 35.5
9/25/14 2:05 == 35.9
9/25/14 2:10 == 36
9/25/14 2:15 == 35.6
9/25/14 2:20 == 35.7
9/25/14 2:25 == 31
9/25/14 2:30 == 38.2
9/25/14 2:35 == 47.9
9/25/14 2:40 == 48
9/25/14 2:45 == 48.1
9/25/14 2:50 == 48.1
9/25/14 2:55 == 47.9
9/25/14 3:00 == 48.1
9/25/14 3:05 == 48
9/25/14 3:10 == 48.1
9/25/14 3:15 == 47.9
9/25/14 3:20 == 48
9/25/14 3:25 == 37
9/25/14 3:30 == 35
9/25/14 3:35 == 34.6
9/25/14 3:40 == 35.2
9/25/14 3:45 == 35.3
9/25/14 3:50 == 34.9
9/25/14 3:55 == 35.4
9/25/14 4:00 == 35.5
9/25/14 4:05 == 35.2
9/25/14 4:10 == 35.1
9/25/14 4:15 == 35.7
9/25/14 4:20 == 35.6
9/25/14 4:25 == 35.2
9/25/14 4:30 == 35
9/25/14 4:35 == 35.9
9/25/14 4:40 == 35.8
9/25/14 4:45 == 35.3
9/25/14 4:50 == 35
9/25/14 4:55 == 35.6
9/25/14 5:00 == 36
9/25/14 5:05 == 35.8
9/25/14 5:10 == 35.5
9/25/14 5:15 == 35.4
9/25/14 5:20 == 35.9
9/25/14 5:25 == 42.5
9/25/14 5:30 == 48
9/25/14 5:35 == 48
9/25/14 5:40 == 48.1
9/25/14 5:45 == 48
9/25/14 5:50 == 48.1
9/25/14 5:55 == 47.9
9/25/14 6:00 == 47.7
9/25/14 6:05 == 48
9/25/14 6:10 == 48.1
9/25/14 6:15 == 47.9
9/25/14 6:20 == 48
9/25/14 6:25 == 36.8
9/25/14 6:30 == 34.8
9/25/14 6:35 == 34.3
9/25/14 6:40 == 34.2
9/25/14 6:45 == 35.1
9/25/14 6:50 == 35.5
9/25/14 6:55 == 35.4
9/25/14 7:00 == 35.2
9/25/14 7:05 == 34.5
9/25/14 7:10 == 34.6
9/25/14 7:15 == 35.2
9/25/14 7:20 == 35.9
9/25/14 7:25 == 35.6
9/25/14 7:30 == 35.1
9/25/14 7:35 == 34.8
9/25/14 7:40 == 34.2
9/25/14 7:45 == 35.1
9/25/14 7:50 == 35.8
9/25/14 7:55 == 35.7
9/25/14 8:00 == 35
9/25/14 8:05 == 34.7
9/25/14 8:10 == 34.3
9/25/14 8:15 == 34.2
9/25/14 8:20 == 35
9/25/14 8:25 == 35.3
9/25/14 8:30 == 35
9/25/14 8:35 == 34.7
9/25/14 8:40 == 34.2
9/25/14 8:45 == 34.9
9/25/14 8:50 == 35.6
9/25/14 8:55 == 35.5
9/25/14 9:00 == 34.9
9/25/14 9:05 == 34.8
9/25/14 9:10 == 34.3
9/25/14 9:15 == 35.2
9/25/14 9:20 == 35.7
9/25/14 9:25 == 35.7
9/25/14 9:30 == 35
9/25/14 9:35 == 34.9
9/25/14 9:40 == 34.5
9/25/14 9:45 == 35.4
9/25/14 9:50 == 35.9
9/25/14 9:55 == 35.8
9/25/14 10:00 == 35.4
9/25/14 10:05 == 35.1
9/25/14 10:10 == 35
9/25/14 10:15 == 36
9/25/14 10:20 == 35.9
9/25/14 10:25 == 35.3
9/25/14 10:30 == 35.3
9/25/14 10:35 == 35.9

Pumpback Station Discharge (0364)

9/25/14 10:40 == 42.3
9/25/14 10:45 == 47.9
9/25/14 10:50 == 48
9/25/14 10:55 == 47.9
9/25/14 11:00 == 48
9/25/14 11:05 == 48.1
9/25/14 11:10 == 48.1
9/25/14 11:15 == 48
9/25/14 11:20 == 48
9/25/14 11:25 == 48.1
9/25/14 11:30 == 48
9/25/14 11:35 == 47.9
9/25/14 11:40 == 47.9
9/25/14 11:45 == 47.9
9/25/14 11:50 == 47.9
9/25/14 11:55 == 36.6
9/25/14 12:00 == 34.8
9/25/14 12:05 == 34.6
9/25/14 12:10 == 34.5
9/25/14 12:15 == 35.6
9/25/14 12:20 == 35.2
9/25/14 12:25 == 34.8
9/25/14 12:30 == 34.7
9/25/14 12:35 == 35.5
9/25/14 12:40 == 36.1
9/25/14 12:45 == 36
9/25/14 12:50 == 35.3
9/25/14 12:55 == 35.3
9/25/14 13:00 == 35.7
9/25/14 13:05 == 36.4
9/25/14 13:10 == 36
9/25/14 13:15 == 35.9
9/25/14 13:20 == 35.4
9/25/14 13:25 == 41.8
9/25/14 13:30 == 48
9/25/14 13:35 == 48
9/25/14 13:40 == 47.9
9/25/14 13:45 == 48
9/25/14 13:50 == 48
9/25/14 13:55 == 48.1
9/25/14 14:00 == 47.9
9/25/14 14:05 == 48
9/25/14 14:10 == 48.1
9/25/14 14:15 == 47.9
9/25/14 14:20 == 48
9/25/14 14:25 == 47.9
9/25/14 14:30 == 48
9/25/14 14:35 == 47.9
9/25/14 14:40 == 36.8
9/25/14 14:45 == 35.4
9/25/14 14:50 == 34.9
9/25/14 14:55 == 35.1
9/25/14 15:00 == 35.9
9/25/14 15:05 == 35.7
9/25/14 15:10 == 35.3
9/25/14 15:15 == 35.1
9/25/14 15:20 == 35.1
9/25/14 15:25 == 36.2
9/25/14 15:30 == 35.9
9/25/14 15:35 == 35.4
9/25/14 15:40 == 35.3
9/25/14 15:45 == 35.2
9/25/14 15:50 == 36
9/25/14 15:55 == 36.2
9/25/14 16:00 == 35.8
9/25/14 16:05 == 35.5
9/25/14 16:10 == 42.1
9/25/14 16:15 == 48.1
9/25/14 16:20 == 47.9
9/25/14 16:25 == 47.9
9/25/14 16:30 == 48
9/25/14 16:35 == 48.1
9/25/14 16:40 == 48.2
9/25/14 16:45 == 48
9/25/14 16:50 == 47.9
9/25/14 16:55 == 48
9/25/14 17:00 == 48
9/25/14 17:05 == 48.1
9/25/14 17:10 == 36.7
9/25/14 17:15 == 35.2
9/25/14 17:20 == 34.7
9/25/14 17:25 == 34.4
9/25/14 17:30 == 34.7
9/25/14 17:35 == 35.9
9/25/14 17:40 == 35.7
9/25/14 17:45 == 35.2
9/25/14 17:50 == 35
9/25/14 17:55 == 34.7
9/25/14 18:00 == 35.8
9/25/14 18:05 == 36.2
9/25/14 18:10 == 36
9/25/14 18:15 == 35.4
9/25/14 18:20 == 35.2
9/25/14 18:25 == 35.1
9/25/14 18:30 == 36.3
9/25/14 18:35 == 36.3
9/25/14 18:40 == 36.1
9/25/14 18:45 == 35.5
9/25/14 18:50 == 35.3
9/25/14 18:55 == 35.9
9/25/14 19:00 == 36.4
9/25/14 19:05 == 36.3
9/25/14 19:10 == 35.7
9/25/14 19:15 == 35.4
9/25/14 19:20 == 35.7
9/25/14 19:25 == 43.5
9/25/14 19:30 == 48.1
9/25/14 19:35 == 48.1
9/25/14 19:40 == 47.9
9/25/14 19:45 == 48
9/25/14 19:50 == 48
9/25/14 19:55 == 47.9
9/25/14 20:00 == 48
9/25/14 20:05 == 48
9/25/14 20:10 == 48
9/25/14 20:15 == 48
9/25/14 20:20 == 47.8
9/25/14 20:25 == 35.7
9/25/14 20:30 == 34.8
9/25/14 20:35 == 35.2
9/25/14 20:40 == 35.1
9/25/14 20:45 == 34.6
9/25/14 20:50 == 34.4
9/25/14 20:55 == 35.1
9/25/14 21:00 == 35.5
9/25/14 21:05 == 35.3
9/25/14 21:10 == 34.8
9/25/14 21:15 == 34.4
9/25/14 21:20 == 34.9
9/25/14 21:25 == 35.6
9/25/14 21:30 == 35.3
9/25/14 21:35 == 34.9
9/25/14 21:40 == 34.4
9/25/14 21:45 == 34.6
9/25/14 21:50 == 35.7
9/25/14 21:55 == 35.7
9/25/14 22:00 == 35.1
9/25/14 22:05 == 34.8
9/25/14 22:10 == 34.5
9/25/14 22:15 == 34.5
9/25/14 22:20 == 35.8
9/25/14 22:25 == 35.7
9/25/14 22:30 == 35
9/25/14 22:35 == 34.9
9/25/14 22:40 == 34.5
9/25/14 22:45 == 35.8
9/25/14 22:50 == 35.9
9/25/14 22:55 == 35.6
9/25/14 23:00 == 35.2
9/25/14 23:05 == 34.8
9/25/14 23:10 == 35.5
9/25/14 23:15 == 35.9
9/25/14 23:20 == 35.5
9/25/14 23:25 == 35.2
9/25/14 23:30 == 34.8
9/25/14 23:35 == 35.7
9/25/14 23:40 == 36
9/25/14 23:45 == 35.6
9/25/14 23:50 == 35.3
9/25/14 23:55 == 35
9/26/14 0:00 == 34.7
9/26/14 0:05 == 35.9
9/26/14 0:10 == 35.9
9/26/14 0:15 == 35.7
9/26/14 0:20 == 35.3
9/26/14 0:25 == 34.8
9/26/14 0:30 == 34.7
9/26/14 0:35 == 36
9/26/14 0:40 == 36.2
9/26/14 0:45 == 35.8
9/26/14 0:50 == 35.4
9/26/14 0:55 == 35.1
9/26/14 1:00 == 34.7
9/26/14 1:05 == 35.6
9/26/14 1:10 == 36.1
9/26/14 1:15 == 36
9/26/14 1:20 == 35.3
9/26/14 1:25 == 35.1
9/26/14 1:30 == 34.8
9/26/14 1:35 == 35.5
9/26/14 1:40 == 36.1
9/26/14 1:45 == 36
9/26/14 1:50 == 35.6
9/26/14 1:55 == 35.2
9/26/14 2:00 == 34.8
9/26/14 2:05 == 35.6
9/26/14 2:10 == 36.1
9/26/14 2:15 == 36
9/26/14 2:20 == 35.5
9/26/14 2:25 == 35.3
9/26/14 2:30 == 34.9
9/26/14 2:35 == 35.7
9/26/14 2:40 == 36.3
9/26/14 2:45 == 36.2
9/26/14 2:50 == 35.5
9/26/14 2:55 == 35.4
9/26/14 3:00 == 35
9/26/14 3:05 == 35.2
9/26/14 3:10 == 36.3
9/26/14 3:15 == 36.2
9/26/14 3:20 == 35.6
9/26/14 3:25 == 35.4
9/26/14 3:30 == 35.1
9/26/14 3:35 == 35.4
9/26/14 3:40 == 44
9/26/14 3:45 == 48
9/26/14 3:50 == 47.9
9/26/14 3:55 == 48.1
9/26/14 4:00 == 48
9/26/14 4:05 == 48.1
9/26/14 4:10 == 48.1
9/26/14 4:15 == 48
9/26/14 4:20 == 48
9/26/14 4:25 == 35.1
9/26/14 4:30 == 34.1
9/26/14 4:35 == 34.1
9/26/14 4:40 == 35
9/26/14 4:45 == 35.6
9/26/14 4:50 == 35.3
9/26/14 4:55 == 34.8

Pumpback Station Discharge (0364)

9/26/14 5:00 == 34.4
9/26/14 5:05 == 34.4
9/26/14 5:10 == 35.1
9/26/14 5:15 == 35.6
9/26/14 5:20 == 35.5
9/26/14 5:25 == 35.2
9/26/14 5:30 == 34.7
9/26/14 5:35 == 34.6
9/26/14 5:40 == 35.1
9/26/14 5:45 == 35.8
9/26/14 5:50 == 35.8
9/26/14 5:55 == 35.2
9/26/14 6:00 == 34.9
9/26/14 6:05 == 34.5
9/26/14 6:10 == 35.4
9/26/14 6:15 == 35.8
9/26/14 6:20 == 35.6
9/26/14 6:25 == 35.1
9/26/14 6:30 == 34.8
9/26/14 6:35 == 34.8
9/26/14 6:40 == 36.1
9/26/14 6:45 == 35.8
9/26/14 6:50 == 35.6
9/26/14 6:55 == 35.3
9/26/14 7:00 == 34.7
9/26/14 7:05 == 34.7
9/26/14 7:10 == 35.5
9/26/14 7:15 == 35.8
9/26/14 7:20 == 35.7
9/26/14 7:25 == 35.4
9/26/14 7:30 == 34.8
9/26/14 7:35 == 34.8
9/26/14 7:40 == 35.4
9/26/14 7:45 == 35.7
9/26/14 7:50 == 35.5
9/26/14 7:55 == 35.1
9/26/14 8:00 == 34.6
9/26/14 8:05 == 34.3
9/26/14 8:10 == 35.7
9/26/14 8:15 == 35.6
9/26/14 8:20 == 35.2
9/26/14 8:25 == 34.8
9/26/14 8:30 == 34.2
9/26/14 8:35 == 34.3
9/26/14 8:40 == 35.7
9/26/14 8:45 == 35.6
9/26/14 8:50 == 35.3
9/26/14 8:55 == 34.8
9/26/14 9:00 == 34.4
9/26/14 9:05 == 34.1
9/26/14 9:10 == 35.4
9/26/14 9:15 == 35.8
9/26/14 9:20 == 35.8
9/26/14 9:25 == 35.1
9/26/14 9:30 == 34.9
9/26/14 9:35 == 34.5
9/26/14 9:40 == 35.5
9/26/14 9:45 == 35.9
9/26/14 9:50 == 35.8
9/26/14 9:55 == 35.1
9/26/14 10:00 == 35
9/26/14 10:05 == 35.6
9/26/14 10:10 == 36.3
9/26/14 10:15 == 36.3
9/26/14 10:20 == 35.5
9/26/14 10:25 == 35.4
9/26/14 10:30 == 35.3
9/26/14 10:35 == 35.4
9/26/14 10:40 == 35.2
9/26/14 10:45 == 35.2
9/26/14 10:50 == 35.2
9/26/14 10:55 == 35.5
9/26/14 11:00 == 35.3
9/26/14 11:05 == 35.3
9/26/14 11:10 == 35.3
9/26/14 11:15 == 35.7
9/26/14 11:20 == 35.6
9/26/14 11:25 == 36
9/26/14 11:30 == 36.2
9/26/14 11:35 == 36.3
9/26/14 11:40 == 36.7
9/26/14 11:45 == 36.9
9/26/14 11:50 == 36.4
9/26/14 11:55 == 35.6
9/26/14 12:00 == 36.5
9/26/14 12:05 == 36.8
9/26/14 12:10 == 36.3
9/26/14 12:15 == 36.1
9/26/14 12:20 == 35.5
9/26/14 12:25 == 36
9/26/14 12:30 == 36.6
9/26/14 12:35 == 36.5
9/26/14 12:40 == 36.3
9/26/14 12:45 == 35.8
9/26/14 12:50 == 35.7
9/26/14 12:55 == 36.2
9/26/14 13:00 == 36.9
9/26/14 13:05 == 36.6
9/26/14 13:10 == 36.2
9/26/14 13:15 == 35.8
9/26/14 13:20 == 35.7
9/26/14 13:25 == 36.5
9/26/14 13:30 == 36.9
9/26/14 13:35 == 36.5
9/26/14 13:40 == 36.3
9/26/14 13:45 == 35.8
9/26/14 13:50 == 35.8
9/26/14 13:55 == 36
9/26/14 14:00 == 37.1
9/26/14 14:05 == 36.6
9/26/14 14:10 == 36.3
9/26/14 14:15 == 35.9
9/26/14 14:20 == 35.9
9/26/14 14:25 == 36.1
9/26/14 14:30 == 37
9/26/14 14:35 == 36.7
9/26/14 14:40 == 36.3
9/26/14 14:45 == 35.7
9/26/14 14:50 == 35.8
9/26/14 14:55 == 44.1
9/26/14 15:00 == 48.1
9/26/14 15:05 == 48
9/26/14 15:10 == 47.8
9/26/14 15:15 == 48.1
9/26/14 15:20 == 48
9/26/14 15:25 == 47.9
9/26/14 15:30 == 48
9/26/14 15:35 == 48
9/26/14 15:40 == 35.7
9/26/14 15:45 == 34.9
9/26/14 15:50 == 34.9
9/26/14 15:55 == 35.5
9/26/14 16:00 == 36
9/26/14 16:05 == 35.6
9/26/14 16:10 == 35
9/26/14 16:15 == 35.1
9/26/14 16:20 == 35.6
9/26/14 16:25 == 35.8
9/26/14 16:30 == 35.2
9/26/14 16:35 == 34.9
9/26/14 16:40 == 35.8
9/26/14 16:45 == 35.9
9/26/14 16:50 == 35.5
9/26/14 16:55 == 35
9/26/14 17:00 == 35.8
9/26/14 17:05 == 36.2
9/26/14 17:10 == 36.2
9/26/14 17:15 == 35.7
9/26/14 17:20 == 35.2
9/26/14 17:25 == 35.6
9/26/14 17:30 == 36.4
9/26/14 17:35 == 36.3
9/26/14 17:40 == 36
9/26/14 17:45 == 35.6
9/26/14 17:50 == 35.2
9/26/14 17:55 == 36
9/26/14 18:00 == 36.5
9/26/14 18:05 == 36.6
9/26/14 18:10 == 36.3
9/26/14 18:15 == 35.8
9/26/14 18:20 == 35.5
9/26/14 18:25 == 35.2
9/26/14 18:30 == 36.4
9/26/14 18:35 == 36.8
9/26/14 18:40 == 36.4
9/26/14 18:45 == 36.1
9/26/14 18:50 == 35.7
9/26/14 18:55 == 35.3
9/26/14 19:00 == 35.4
9/26/14 19:05 == 36.6
9/26/14 19:10 == 36.7
9/26/14 19:15 == 36.4
9/26/14 19:20 == 36.1
9/26/14 19:25 == 35.6
9/26/14 19:30 == 35.1
9/26/14 19:35 == 35.5
9/26/14 19:40 == 36.7
9/26/14 19:45 == 36.5
9/26/14 19:50 == 36.2
9/26/14 19:55 == 35.8
9/26/14 20:00 == 35.4
9/26/14 20:05 == 35.1
9/26/14 20:10 == 36.1
9/26/14 20:15 == 36.5
9/26/14 20:20 == 36.2
9/26/14 20:25 == 35.9
9/26/14 20:30 == 35.5
9/26/14 20:35 == 35
9/26/14 20:40 == 35.5
9/26/14 20:45 == 36.6
9/26/14 20:50 == 36.5
9/26/14 20:55 == 36.2
9/26/14 21:00 == 35.8
9/26/14 21:05 == 35.2
9/26/14 21:10 == 35
9/26/14 21:15 == 36
9/26/14 21:20 == 36.4
9/26/14 21:25 == 36.1
9/26/14 21:30 == 35.9
9/26/14 21:35 == 35.2
9/26/14 21:40 == 34.8
9/26/14 21:45 == 35.5
9/26/14 21:50 == 36.4
9/26/14 21:55 == 36
9/26/14 22:00 == 35.7
9/26/14 22:05 == 35.2
9/26/14 22:10 == 35
9/26/14 22:15 == 35
9/26/14 22:20 == 36
9/26/14 22:25 == 36.2
9/26/14 22:30 == 35.7
9/26/14 22:35 == 35.4
9/26/14 22:40 == 35
9/26/14 22:45 == 35
9/26/14 22:50 == 36.2
9/26/14 22:55 == 36.1
9/26/14 23:00 == 35.8
9/26/14 23:05 == 35.4
9/26/14 23:10 == 35
9/26/14 23:15 == 35

Pumpback Station Discharge (0364)

9/26/14 23:20 == 35.8
9/26/14 23:25 == 35.9
9/26/14 23:30 == 35.8
9/26/14 23:35 == 35.4
9/26/14 23:40 == 35
9/26/14 23:45 == 34.9
9/26/14 23:50 == 35
9/26/14 23:55 == 36.1
9/27/14 0:00 == 35.7
9/27/14 0:05 == 35.5
9/27/14 0:10 == 34.9
9/27/14 0:15 == 34.7
9/27/14 0:20 == 34.7
9/27/14 0:25 == 35
9/27/14 0:30 == 35.9
9/27/14 0:35 == 35.6
9/27/14 0:40 == 35.3
9/27/14 0:45 == 34.8
9/27/14 0:50 == 34.8
9/27/14 0:55 == 34.8
9/27/14 1:00 == 34.7
9/27/14 1:05 == 34.8
9/27/14 1:10 == 34.7
9/27/14 1:15 == 34.9
9/27/14 1:20 == 35.9
9/27/14 1:25 == 35.5
9/27/14 1:30 == 35.1
9/27/14 1:35 == 34.7
9/27/14 1:40 == 34.8
9/27/14 1:45 == 34.8
9/27/14 1:50 == 34.7
9/27/14 1:55 == 34.8
9/27/14 2:00 == 35.7
9/27/14 2:05 == 35.5
9/27/14 2:10 == 35.3
9/27/14 2:15 == 34.8
9/27/14 2:20 == 34.8
9/27/14 2:25 == 34.8
9/27/14 2:30 == 35.5
9/27/14 2:35 == 35.4
9/27/14 2:40 == 35.3
9/27/14 2:45 == 34.8
9/27/14 2:50 == 34.8
9/27/14 2:55 == 34.7
9/27/14 3:00 == 34.8
9/27/14 3:05 == 34.9
9/27/14 3:10 == 35.5
9/27/14 3:15 == 35.6
9/27/14 3:20 == 35.4
9/27/14 3:25 == 34.8
9/27/14 3:30 == 34.8
9/27/14 3:35 == 34.8
9/27/14 3:40 == 35.1
9/27/14 3:45 == 36
9/27/14 3:50 == 35.8
9/27/14 3:55 == 35.5
9/27/14 4:00 == 34.8
9/27/14 4:05 == 34.8
9/27/14 4:10 == 34.8
9/27/14 4:15 == 34.8
9/27/14 4:20 == 35.7
9/27/14 4:25 == 35.5
9/27/14 4:30 == 34.9
9/27/14 4:35 == 34.8
9/27/14 4:40 == 34.8
9/27/14 4:45 == 35.6
9/27/14 4:50 == 35.5
9/27/14 4:55 == 35.2
9/27/14 5:00 == 34.7
9/27/14 5:05 == 34.7
9/27/14 5:10 == 35.2
9/27/14 5:15 == 35.8
9/27/14 5:20 == 35.6
9/27/14 5:25 == 35.1
9/27/14 5:30 == 34.7
9/27/14 5:35 == 34.7
9/27/14 5:40 == 34.7
9/27/14 5:45 == 34.7
9/27/14 5:50 == 35.7
9/27/14 5:55 == 35.4
9/27/14 6:00 == 35.1
9/27/14 6:05 == 34.6
9/27/14 6:10 == 34.7
9/27/14 6:15 == 34.8
9/27/14 6:20 == 34.8
9/27/14 6:25 == 35.7
9/27/14 6:30 == 35.2
9/27/14 6:35 == 35
9/27/14 6:40 == 34.6
9/27/14 6:45 == 34.8
9/27/14 6:50 == 34.4
9/27/14 6:55 == 35
9/27/14 7:00 == 35.4
9/27/14 7:05 == 35.1
9/27/14 7:10 == 34.4
9/27/14 7:15 == 34.4
9/27/14 7:20 == 34.4
9/27/14 7:25 == 35
9/27/14 7:30 == 35.3
9/27/14 7:35 == 34.9
9/27/14 7:40 == 34.1
9/27/14 7:45 == 34
9/27/14 7:50 == 34.1
9/27/14 7:55 == 35.1
9/27/14 8:00 == 34.8
9/27/14 8:05 == 34.4
9/27/14 8:10 == 33.9
9/27/14 8:15 == 33.9
9/27/14 8:20 == 34
9/27/14 8:25 == 34.9
9/27/14 8:30 == 34.5
9/27/14 8:35 == 34.1
9/27/14 8:40 == 33.6
9/27/14 8:45 == 33.7
9/27/14 8:50 == 34.7
9/27/14 8:55 == 34.9
9/27/14 9:00 == 34.6
9/27/14 9:05 == 34.1
9/27/14 9:10 == 33.6
9/27/14 9:15 == 33.7
9/27/14 9:20 == 34.6
9/27/14 9:25 == 34.8
9/27/14 9:30 == 34.5
9/27/14 9:35 == 34.1
9/27/14 9:40 == 33.7
9/27/14 9:45 == 33.8
9/27/14 9:50 == 35
9/27/14 9:55 == 34.9
9/27/14 10:00 == 34.7
9/27/14 10:05 == 34.1
9/27/14 10:10 == 33.7
9/27/14 10:15 == 34.3
9/27/14 10:20 == 35.3
9/27/14 10:25 == 34.9
9/27/14 10:30 == 34.6
9/27/14 10:35 == 34.1
9/27/14 10:40 == 33.7
9/27/14 10:45 == 34.3
9/27/14 10:50 == 35.3
9/27/14 10:55 == 34.9
9/27/14 11:00 == 34.7
9/27/14 11:05 == 34.3
9/27/14 11:10 == 33.9
9/27/14 11:15 == 33.8
9/27/14 11:20 == 34.7
9/27/14 11:25 == 35.1
9/27/14 11:30 == 34.9
9/27/14 11:35 == 34.4
9/27/14 11:40 == 34.3
9/27/14 11:45 == 34.2
9/27/14 11:50 == 34.9
9/27/14 11:55 == 35.5
9/27/14 12:00 == 35.3
9/27/14 12:05 == 34.8
9/27/14 12:10 == 34.1
9/27/14 12:15 == 33.8
9/27/14 12:20 == 34.3
9/27/14 12:25 == 35.7
9/27/14 12:30 == 35.3
9/27/14 12:35 == 34.8
9/27/14 12:40 == 34.5
9/27/14 12:45 == 33.9
9/27/14 12:50 == 34.6
9/27/14 12:55 == 35.6
9/27/14 13:00 == 35.3
9/27/14 13:05 == 34.7
9/27/14 13:10 == 34.4
9/27/14 13:15 == 33.9
9/27/14 13:20 == 35.3
9/27/14 13:25 == 35.8
9/27/14 13:30 == 35.6
9/27/14 13:35 == 35.1
9/27/14 13:40 == 34.6
9/27/14 13:45 == 34.1
9/27/14 13:50 == 34.3
9/27/14 13:55 == 35.4
9/27/14 14:00 == 35.4
9/27/14 14:05 == 35
9/27/14 14:10 == 34.5
9/27/14 14:15 == 34.1
9/27/14 14:20 == 35
9/27/14 14:25 == 35.4
9/27/14 14:30 == 35.1
9/27/14 14:35 == 34.6
9/27/14 14:40 == 34.2
9/27/14 14:45 == 35.2
9/27/14 14:50 == 35.5
9/27/14 14:55 == 35.3
9/27/14 15:00 == 34.7
9/27/14 15:05 == 34.2
9/27/14 15:10 == 34.9
9/27/14 15:15 == 35.6
9/27/14 15:20 == 35.3
9/27/14 15:25 == 34.9
9/27/14 15:30 == 34.7
9/27/14 15:35 == 34.6
9/27/14 15:40 == 35.6
9/27/14 15:45 == 35.2
9/27/14 15:50 == 34.7
9/27/14 15:55 == 34.1
9/27/14 16:00 == 35
9/27/14 16:05 == 35.3
9/27/14 16:10 == 35
9/27/14 16:15 == 34.7
9/27/14 16:20 == 34.3
9/27/14 16:25 == 35.2
9/27/14 16:30 == 35.6
9/27/14 16:35 == 35.2
9/27/14 16:40 == 34.6
9/27/14 16:45 == 34.6
9/27/14 16:50 == 35.5
9/27/14 16:55 == 35.4
9/27/14 17:00 == 35
9/27/14 17:05 == 34.5
9/27/14 17:10 == 35.4
9/27/14 17:15 == 35.6
9/27/14 17:20 == 35.2
9/27/14 17:25 == 34.6
9/27/14 17:30 == 35
9/27/14 17:35 == 35.5

Pumpback Station Discharge (0364)

9/27/14 17:40 == 35.2
9/27/14 17:45 == 34.8
9/27/14 17:50 == 35.1
9/27/14 17:55 == 35.6
9/27/14 18:00 == 35.5
9/27/14 18:05 == 35
9/27/14 18:10 == 35.2
9/27/14 18:15 == 35.6
9/27/14 18:20 == 35.6
9/27/14 18:25 == 34.9
9/27/14 18:30 == 34.9
9/27/14 18:35 == 35.6
9/27/14 18:40 == 35.5
9/27/14 18:45 == 35.1
9/27/14 18:50 == 35
9/27/14 18:55 == 35.6
9/27/14 19:00 == 35.7
9/27/14 19:05 == 35.1
9/27/14 19:10 == 34.8
9/27/14 19:15 == 35.7
9/27/14 19:20 == 35.7
9/27/14 19:25 == 35.2
9/27/14 19:30 == 34.7
9/27/14 19:35 == 35.6
9/27/14 19:40 == 35.7
9/27/14 19:45 == 35.3
9/27/14 19:50 == 35
9/27/14 19:55 == 35.3
9/27/14 20:00 == 35.7
9/27/14 20:05 == 35.4
9/27/14 20:10 == 34.9
9/27/14 20:15 == 35.5
9/27/14 20:20 == 35.6
9/27/14 20:25 == 35.2
9/27/14 20:30 == 34.9
9/27/14 20:35 == 35.3
9/27/14 20:40 == 35.6
9/27/14 20:45 == 35.4
9/27/14 20:50 == 34.8
9/27/14 20:55 == 35.2
9/27/14 21:00 == 35.6
9/27/14 21:05 == 35.4
9/27/14 21:10 == 34.8
9/27/14 21:15 == 34.8
9/27/14 21:20 == 35.6
9/27/14 21:25 == 35.4
9/27/14 21:30 == 35.1
9/27/14 21:35 == 34.7
9/27/14 21:40 == 35.5
9/27/14 21:45 == 35.4
9/27/14 21:50 == 35.1
9/27/14 21:55 == 34.6
9/27/14 22:00 == 35
9/27/14 22:05 == 35.4
9/27/14 22:10 == 35.1
9/27/14 22:15 == 34.6
9/27/14 22:20 == 35.2
9/27/14 22:25 == 35
9/27/14 22:30 == 34.6
9/27/14 22:35 == 34.9
9/27/14 22:40 == 35.5
9/27/14 22:45 == 35.1
9/27/14 22:50 == 34.7
9/27/14 22:55 == 34.7
9/27/14 23:00 == 35.4
9/27/14 23:05 == 35.4
9/27/14 23:10 == 34.9
9/27/14 23:15 == 34.5
9/27/14 23:20 == 35.4
9/27/14 23:25 == 35.3
9/27/14 23:30 == 34.9
9/27/14 23:35 == 34.4
9/27/14 23:40 == 35.3
9/27/14 23:45 == 35.5
9/27/14 23:50 == 35
9/27/14 23:55 == 34.6
9/28/14 0:00 == 34.9
9/28/14 0:05 == 35.3
9/28/14 0:10 == 34.9
9/28/14 0:15 == 34.4
9/28/14 0:20 == 35
9/28/14 0:25 == 35.3
9/28/14 0:30 == 34.9
9/28/14 0:35 == 34.5
9/28/14 0:40 == 34.9
9/28/14 0:45 == 35.3
9/28/14 0:50 == 34.8
9/28/14 0:55 == 34.4
9/28/14 1:00 == 34.9
9/28/14 1:05 == 35.2
9/28/14 1:10 == 34.9
9/28/14 1:15 == 34.5
9/28/14 1:20 == 34.5
9/28/14 1:25 == 35.4
9/28/14 1:30 == 35.3
9/28/14 1:35 == 34.8
9/28/14 1:40 == 34.4
9/28/14 1:45 == 34.9
9/28/14 1:50 == 35.3
9/28/14 1:55 == 35.1
9/28/14 2:00 == 34.7
9/28/14 2:05 == 34.7
9/28/14 2:10 == 35.4
9/28/14 2:15 == 35.1
9/28/14 2:20 == 34.5
9/28/14 2:25 == 34.3
9/28/14 2:30 == 35.2
9/28/14 2:35 == 35.2
9/28/14 2:40 == 34.8
9/28/14 2:45 == 34.3
9/28/14 2:50 == 34.3
9/28/14 2:55 == 35.3
9/28/14 3:00 == 35.2
9/28/14 3:05 == 34.7
9/28/14 3:10 == 34.3
9/28/14 3:15 == 34.6
9/28/14 3:20 == 35.2
9/28/14 3:25 == 35
9/28/14 3:30 == 34.5
9/28/14 3:35 == 34.2
9/28/14 3:40 == 34.8
9/28/14 3:45 == 35.4
9/28/14 3:50 == 35.1
9/28/14 3:55 == 34.4
9/28/14 4:00 == 34
9/28/14 4:05 == 34.6
9/28/14 4:10 == 35.2
9/28/14 4:15 == 34.9
9/28/14 4:20 == 34.3
9/28/14 4:25 == 34.3
9/28/14 4:30 == 35
9/28/14 4:35 == 34.8
9/28/14 4:40 == 34.2
9/28/14 4:45 == 34.2
9/28/14 4:50 == 35
9/28/14 4:55 == 34.6
9/28/14 5:00 == 34.3
9/28/14 5:05 == 34.4
9/28/14 5:10 == 35.1
9/28/14 5:15 == 34.7
9/28/14 5:20 == 32.4
9/28/14 5:25 == 15.7
9/28/14 5:30 == 16.1
9/28/14 5:35 == 16
9/28/14 5:40 == 16.2
9/28/14 5:45 == 16.4
9/28/14 5:50 == 19.5
9/28/14 5:55 == 35.7
9/28/14 6:00 == 35.3
9/28/14 6:05 == 35.8
9/28/14 6:10 == 35.8
9/28/14 6:15 == 35.3
9/28/14 6:20 == 35.2
9/28/14 6:25 == 35.5
9/28/14 6:30 == 35.9
9/28/14 6:35 == 35.7
9/28/14 6:40 == 35.1
9/28/14 6:45 == 34.8
9/28/14 6:50 == 35.3
9/28/14 6:55 == 35.6
9/28/14 7:00 == 35.4
9/28/14 7:05 == 34.9
9/28/14 7:10 == 34.5
9/28/14 7:15 == 35.4
9/28/14 7:20 == 35.7
9/28/14 7:25 == 35.2
9/28/14 7:30 == 34.9
9/28/14 7:35 == 34.5
9/28/14 7:40 == 35
9/28/14 7:45 == 35
9/28/14 7:50 == 32.6
9/28/14 7:55 == 15.6
9/28/14 8:00 == 15.7
9/28/14 8:05 == 16.2
9/28/14 8:10 == 16.4
9/28/14 8:15 == 16
9/28/14 8:20 == 19
9/28/14 8:25 == 36.4
9/28/14 8:30 == 36.3
9/28/14 8:35 == 35.8
9/28/14 8:40 == 34.9
9/28/14 8:45 == 35.3
9/28/14 8:50 == 36
9/28/14 8:55 == 35.4
9/28/14 9:00 == 34.8
9/28/14 9:05 == 34.5
9/28/14 9:10 == 35.1
9/28/14 9:15 == 35.5
9/28/14 9:20 == 35
9/28/14 9:25 == 34.7
9/28/14 9:30 == 35.2
9/28/14 9:35 == 35.5
9/28/14 9:40 == 35.1
9/28/14 9:45 == 34.6
9/28/14 9:50 == 35.1
9/28/14 9:55 == 35.5
9/28/14 10:00 == 35.2
9/28/14 10:05 == 34.6
9/28/14 10:10 == 34.5
9/28/14 10:15 == 35.1
9/28/14 10:20 == 32.9
9/28/14 10:25 == 15.8
9/28/14 10:30 == 15.5
9/28/14 10:35 == 16.1
9/28/14 10:40 == 16.5
9/28/14 10:45 == 16.3
9/28/14 10:50 == 16
9/28/14 10:55 == 16.4
9/28/14 11:00 == 16.4
9/28/14 11:05 == 16.1
9/28/14 11:10 == 15.9
9/28/14 11:15 == 16.2
9/28/14 11:20 == 16.2
9/28/14 11:25 == 16
9/28/14 11:30 == 15.7
9/28/14 11:35 == 16
9/28/14 11:40 == 16
9/28/14 11:45 == 16
9/28/14 11:50 == 15.9
9/28/14 11:55 == 16.1

Pumpback Station Discharge (0364)

9/28/14 12:00 == 16.1
9/28/14 12:05 == 15.9
9/28/14 12:10 == 16
9/28/14 12:15 == 16.1
9/28/14 12:20 == 15.9
9/28/14 12:25 == 15.8
9/28/14 12:30 == 17.1
9/28/14 12:35 == 27.2
9/28/14 12:40 == 27
9/28/14 12:45 == 26.9
9/28/14 12:50 == 27.2
9/28/14 12:55 == 26.9
9/28/14 13:00 == 26.8
9/28/14 13:05 == 27.2
9/28/14 13:10 == 27.1
9/28/14 13:15 == 27
9/28/14 13:20 == 27.1
9/28/14 13:25 == 27.1
9/28/14 13:30 == 27.1
9/28/14 13:35 == 28.9
9/28/14 13:40 == 30.2
9/28/14 13:45 == 30.3
9/28/14 13:50 == 30.2
9/28/14 13:55 == 30.2
9/28/14 14:00 == 30.3
9/28/14 14:05 == 30.2
9/28/14 14:10 == 30.1
9/28/14 14:15 == 30.3
9/28/14 14:20 == 43.7
9/28/14 14:25 == 47.9
9/28/14 14:30 == 48
9/28/14 14:35 == 48.1
9/28/14 14:40 == 48
9/28/14 14:45 == 48
9/28/14 14:50 == 48
9/28/14 14:55 == 47.8
9/28/14 15:00 == 48.1
9/28/14 15:05 == 48
9/28/14 15:10 == 47.9
9/28/14 15:15 == 48
9/28/14 15:20 == 48
9/28/14 15:25 == 48
9/28/14 15:30 == 47.9
9/28/14 15:35 == 47.9
9/28/14 15:40 == 47.8
9/28/14 15:45 == 48
9/28/14 15:50 == 48
9/28/14 15:55 == 48
9/28/14 16:00 == 48
9/28/14 16:05 == 48
9/28/14 16:10 == 48
9/28/14 16:15 == 48
9/28/14 16:20 == 48
9/28/14 16:25 == 48
9/28/14 16:30 == 48
9/28/14 16:35 == 48.1
9/28/14 16:40 == 47.9
9/28/14 16:45 == 48.2
9/28/14 16:50 == 48
9/28/14 16:55 == 48.1
9/28/14 17:00 == 47.9
9/28/14 17:05 == 47.9
9/28/14 17:10 == 47.9
9/28/14 17:15 == 47.9
9/28/14 17:20 == 48.1
9/28/14 17:25 == 48.1
9/28/14 17:30 == 48
9/28/14 17:35 == 47.9
9/28/14 17:40 == 48.1
9/28/14 17:45 == 47.9
9/28/14 17:50 == 47.9
9/28/14 17:55 == 47.9
9/28/14 18:00 == 47.9
9/28/14 18:05 == 48.1
9/28/14 18:10 == 48.3
9/28/14 18:15 == 47.9
9/28/14 18:20 == 44.8
9/28/14 18:25 == 34.8
9/28/14 18:30 == 34.8
9/28/14 18:35 == 34.8
9/28/14 18:40 == 35
9/28/14 18:45 == 35
9/28/14 18:50 == 35
9/28/14 18:55 == 35
9/28/14 19:00 == 34.9
9/28/14 19:05 == 34.9
9/28/14 19:10 == 35
9/28/14 19:15 == 35.1
9/28/14 19:20 == 35.1
9/28/14 19:25 == 35.1
9/28/14 19:30 == 35.2
9/28/14 19:35 == 35.2
9/28/14 19:40 == 35.2
9/28/14 19:45 == 35.2
9/28/14 19:50 == 35.2
9/28/14 19:55 == 35.1
9/28/14 20:00 == 35.1
9/28/14 20:05 == 35.2
9/28/14 20:10 == 35.2
9/28/14 20:15 == 35.3
9/28/14 20:20 == 35.2
9/28/14 20:25 == 35.3
9/28/14 20:30 == 35.2
9/28/14 20:35 == 35.2
9/28/14 20:40 == 35.2
9/28/14 20:45 == 35.3
9/28/14 20:50 == 35.2
9/28/14 20:55 == 35.1
9/28/14 21:00 == 35.1
9/28/14 21:05 == 35.1
9/28/14 21:10 == 35.2
9/28/14 21:15 == 35.2
9/28/14 21:20 == 35.2
9/28/14 21:25 == 35.2
9/28/14 21:30 == 35.2
9/28/14 21:35 == 35.3
9/28/14 21:40 == 35.3
9/28/14 21:45 == 35.3
9/28/14 21:50 == 35.2
9/28/14 21:55 == 35.4
9/28/14 22:00 == 35.3
9/28/14 22:05 == 35.2
9/28/14 22:10 == 35.2
9/28/14 22:15 == 35.3
9/28/14 22:20 == 35.2
9/28/14 22:25 == 35.2
9/28/14 22:30 == 35.2
9/28/14 22:35 == 35.2
9/28/14 22:40 == 35.3
9/28/14 22:45 == 35.2
9/28/14 22:50 == 35.2
9/28/14 22:55 == 35.2
9/28/14 23:00 == 35.2
9/28/14 23:05 == 35.3
9/28/14 23:10 == 35.3
9/28/14 23:15 == 35.2
9/28/14 23:20 == 35.3
9/28/14 23:25 == 35.3
9/28/14 23:30 == 35.3
9/28/14 23:35 == 35.4
9/28/14 23:40 == 35.2
9/28/14 23:45 == 35.3
9/28/14 23:50 == 35.4
9/28/14 23:55 == 35.3
9/29/14 0:00 == 35.3
9/29/14 0:05 == 35.3
9/29/14 0:10 == 35.2
9/29/14 0:15 == 35.3
9/29/14 0:20 == 35.3
9/29/14 0:25 == 35.2
9/29/14 0:30 == 35.3
9/29/14 0:35 == 35.2
9/29/14 0:40 == 35.3
9/29/14 0:45 == 35.4
9/29/14 0:50 == 35.3
9/29/14 0:55 == 35.3
9/29/14 1:00 == 35.3
9/29/14 1:05 == 35.4
9/29/14 1:10 == 35.3
9/29/14 1:15 == 35.2
9/29/14 1:20 == 35.2
9/29/14 1:25 == 35.3
9/29/14 1:30 == 35.3
9/29/14 1:35 == 35.3
9/29/14 1:40 == 35.3
9/29/14 1:45 == 35.3
9/29/14 1:50 == 35.3
9/29/14 1:55 == 35.2
9/29/14 2:00 == 35.2
9/29/14 2:05 == 35.2
9/29/14 2:10 == 35.2
9/29/14 2:15 == 35.3
9/29/14 2:20 == 35.2
9/29/14 2:25 == 35.2
9/29/14 2:30 == 35.1
9/29/14 2:35 == 35.2
9/29/14 2:40 == 35.3
9/29/14 2:45 == 35.1
9/29/14 2:50 == 35.2
9/29/14 2:55 == 35.2
9/29/14 3:00 == 35.3
9/29/14 3:05 == 35.2
9/29/14 3:10 == 35.2
9/29/14 3:15 == 35.2
9/29/14 3:20 == 35.3
9/29/14 3:25 == 35.1
9/29/14 3:30 == 35.2
9/29/14 3:35 == 35.1
9/29/14 3:40 == 35.1
9/29/14 3:45 == 35
9/29/14 3:50 == 35.1
9/29/14 3:55 == 35.1
9/29/14 4:00 == 35.2
9/29/14 4:05 == 35.2
9/29/14 4:10 == 35.1
9/29/14 4:15 == 35.3
9/29/14 4:20 == 35.2
9/29/14 4:25 == 35.2
9/29/14 4:30 == 35.1
9/29/14 4:35 == 35.1
9/29/14 4:40 == 35.1
9/29/14 4:45 == 35.1
9/29/14 4:50 == 35.1
9/29/14 4:55 == 35
9/29/14 5:00 == 35.1
9/29/14 5:05 == 35
9/29/14 5:10 == 35.1
9/29/14 5:15 == 35.2
9/29/14 5:20 == 35
9/29/14 5:25 == 35
9/29/14 5:30 == 35
9/29/14 5:35 == 35
9/29/14 5:40 == 35
9/29/14 5:45 == 35
9/29/14 5:50 == 35.1
9/29/14 5:55 == 35.1
9/29/14 6:00 == 35.2
9/29/14 6:05 == 35.1
9/29/14 6:10 == 35.3
9/29/14 6:15 == 35.7

Pumpback Station Discharge (0364)

9/29/14 6:20 == 35.8
9/29/14 6:25 == 35.7
9/29/14 6:30 == 35.7
9/29/14 6:35 == 35.7
9/29/14 6:40 == 35.8
9/29/14 6:45 == 35.9
9/29/14 6:50 == 35.7
9/29/14 6:55 == 35.3
9/29/14 7:00 == 35.1
9/29/14 7:05 == 34.8
9/29/14 7:10 == 34.4
9/29/14 7:15 == 34.5
9/29/14 7:20 == 35.3
9/29/14 7:25 == 35.3
9/29/14 7:30 == 35.5
9/29/14 7:35 == 35.6
9/29/14 7:40 == 35.6
9/29/14 7:45 == 35.7
9/29/14 7:50 == 35.7
9/29/14 7:55 == 35.6
9/29/14 8:00 == 35.6
9/29/14 8:05 == 35.8
9/29/14 8:10 == 35.9
9/29/14 8:15 == 35.7
9/29/14 8:20 == 35.8
9/29/14 8:25 == 35.8
9/29/14 8:30 == 35.6
9/29/14 8:35 == 35.6
9/29/14 8:40 == 35.7
9/29/14 8:45 == 35.7
9/29/14 8:50 == 30
9/29/14 8:55 == 16.2
9/29/14 9:00 == 16.3
9/29/14 9:05 == 16.3
9/29/14 9:10 == 16.2
9/29/14 9:15 == 16.1
9/29/14 9:20 == 16.1
9/29/14 9:25 == 16.2
9/29/14 9:30 == 16.3
9/29/14 9:35 == 16.2
9/29/14 9:40 == 16.1
9/29/14 9:45 == 15.4
9/29/14 9:50 == 15.1
9/29/14 9:55 == 15.5
9/29/14 10:00 == 15.6
9/29/14 10:05 == 15.7
9/29/14 10:10 == 15.8
9/29/14 10:15 == 15.8
9/29/14 10:20 == 15.9
9/29/14 10:25 == 16
9/29/14 10:30 == 16
9/29/14 10:35 == 16
9/29/14 10:40 == 16
9/29/14 10:45 == 16
9/29/14 10:50 == 16
9/29/14 10:55 == 16.1
9/29/14 11:00 == 16
9/29/14 11:05 == 16.1
9/29/14 11:10 == 15.8
9/29/14 11:15 == 15.6
9/29/14 11:20 == 25.9
9/29/14 11:25 == 29.1
9/29/14 11:30 == 30.2
9/29/14 11:35 == 30.1
9/29/14 11:40 == 30
9/29/14 11:45 == 30.4
9/29/14 11:50 == 30.5
9/29/14 11:55 == 30.7
9/29/14 12:00 == 30.7
9/29/14 12:05 == 30.8
9/29/14 12:10 == 30.8
9/29/14 12:15 == 30.6
9/29/14 12:20 == 30.8
9/29/14 12:25 == 30.8
9/29/14 12:30 == 30.7
9/29/14 12:35 == 30.8
9/29/14 12:40 == 30.7
9/29/14 12:45 == 30.6
9/29/14 12:50 == 30.7
9/29/14 12:55 == 30.7
9/29/14 13:00 == 30.8
9/29/14 13:05 == 31
9/29/14 13:10 == 30.7
9/29/14 13:15 == 30.8
9/29/14 13:20 == 31
9/29/14 13:25 == 30.9
9/29/14 13:30 == 46.5
9/29/14 13:35 == 48.1
9/29/14 13:40 == 48
9/29/14 13:45 == 48.1
9/29/14 13:50 == 47.9
9/29/14 13:55 == 47.8
9/29/14 14:00 == 38.8
9/29/14 14:05 == 35.2
9/29/14 14:10 == 34.7
9/29/14 14:15 == 34.2
9/29/14 14:20 == 34
9/29/14 14:25 == 34.1
9/29/14 14:30 == 34
9/29/14 14:35 == 34.6
9/29/14 14:40 == 34.6
9/29/14 14:45 == 34.5
9/29/14 14:50 == 34.4
9/29/14 14:55 == 34.9
9/29/14 15:00 == 34.8
9/29/14 15:05 == 35.4
9/29/14 15:10 == 35.9
9/29/14 15:15 == 35.6
9/29/14 15:20 == 35.4
9/29/14 15:25 == 35.2
9/29/14 15:30 == 34.7
9/29/14 15:35 == 34.4
9/29/14 15:40 == 35
9/29/14 15:45 == 35.6
9/29/14 15:50 == 35.4
9/29/14 15:55 == 35.1
9/29/14 16:00 == 34.8
9/29/14 16:05 == 35.2
9/29/14 16:10 == 35.3
9/29/14 16:15 == 35.6
9/29/14 16:20 == 35.7
9/29/14 16:25 == 35.9
9/29/14 16:30 == 35.4
9/29/14 16:35 == 35.3
9/29/14 16:40 == 34.8
9/29/14 16:45 == 34.9
9/29/14 16:50 == 35.5
9/29/14 16:55 == 35.4
9/29/14 17:00 == 35.7
9/29/14 17:05 == 35.7
9/29/14 17:10 == 35.4
9/29/14 17:15 == 35.3
9/29/14 17:20 == 35.1
9/29/14 17:25 == 35.3
9/29/14 17:30 == 35.6
9/29/14 17:35 == 35.8
9/29/14 17:40 == 35.6
9/29/14 17:45 == 35.5
9/29/14 17:50 == 35.3
9/29/14 17:55 == 35.2
9/29/14 18:00 == 35.2
9/29/14 18:05 == 35.6
9/29/14 18:10 == 35.6
9/29/14 18:15 == 35.6
9/29/14 18:20 == 35.7
9/29/14 18:25 == 35.6
9/29/14 18:30 == 35.4
9/29/14 18:35 == 35.2
9/29/14 18:40 == 35.1
9/29/14 18:45 == 35.4
9/29/14 18:50 == 35.4
9/29/14 18:55 == 36.9
9/29/14 19:00 == 47.9
9/29/14 19:05 == 48
9/29/14 19:10 == 48.1
9/29/14 19:15 == 48.1
9/29/14 19:20 == 47.8
9/29/14 19:25 == 48.1
9/29/14 19:30 == 48
9/29/14 19:35 == 48
9/29/14 19:40 == 48.1
9/29/14 19:45 == 48
9/29/14 19:50 == 48
9/29/14 19:55 == 48.1
9/29/14 20:00 == 48
9/29/14 20:05 == 47.9
9/29/14 20:10 == 47.9
9/29/14 20:15 == 48.1
9/29/14 20:20 == 48
9/29/14 20:25 == 48
9/29/14 20:30 == 48
9/29/14 20:35 == 48
9/29/14 20:40 == 48.1
9/29/14 20:45 == 48
9/29/14 20:50 == 48
9/29/14 20:55 == 48
9/29/14 21:00 == 48.2
9/29/14 21:05 == 47.9
9/29/14 21:10 == 48.1
9/29/14 21:15 == 48.1
9/29/14 21:20 == 48
9/29/14 21:25 == 48.1
9/29/14 21:30 == 48.1
9/29/14 21:35 == 48
9/29/14 21:40 == 48.2
9/29/14 21:45 == 48
9/29/14 21:50 == 47.9
9/29/14 21:55 == 48
9/29/14 22:00 == 48.1
9/29/14 22:05 == 48
9/29/14 22:10 == 48
9/29/14 22:15 == 47.9
9/29/14 22:20 == 43.3
9/29/14 22:25 == 35.4
9/29/14 22:30 == 35.4
9/29/14 22:35 == 35.1
9/29/14 22:40 == 35.1
9/29/14 22:45 == 35.6
9/29/14 22:50 == 35.6
9/29/14 22:55 == 35.6
9/29/14 23:00 == 35.1
9/29/14 23:05 == 35.8
9/29/14 23:10 == 35.8
9/29/14 23:15 == 35.6
9/29/14 23:20 == 35.3
9/29/14 23:25 == 35.5
9/29/14 23:30 == 35.7
9/29/14 23:35 == 35.9
9/29/14 23:40 == 35.7
9/29/14 23:45 == 35.2
9/29/14 23:50 == 35.7
9/29/14 23:55 == 36
9/30/14 0:00 == 35.7
9/30/14 0:05 == 35.4
9/30/14 0:10 == 35.4
9/30/14 0:15 == 35.7
9/30/14 0:20 == 35.9
9/30/14 0:25 == 35.7
9/30/14 0:30 == 35.7
9/30/14 0:35 == 35.6

Pumpback Station Discharge (0364)

9/30/14 0:40 == 35.2
9/30/14 0:45 == 35.8
9/30/14 0:50 == 35.9
9/30/14 0:55 == 35.8
9/30/14 1:00 == 35.7
9/30/14 1:05 == 35.3
9/30/14 1:10 == 35.6
9/30/14 1:15 == 35.9
9/30/14 1:20 == 35.7
9/30/14 1:25 == 35.6
9/30/14 1:30 == 35.2
9/30/14 1:35 == 35.6
9/30/14 1:40 == 35.8
9/30/14 1:45 == 35.7
9/30/14 1:50 == 35.6
9/30/14 1:55 == 35.3
9/30/14 2:00 == 35.6
9/30/14 2:05 == 35.8
9/30/14 2:10 == 35.8
9/30/14 2:15 == 35.6
9/30/14 2:20 == 35.6
9/30/14 2:25 == 35.9
9/30/14 2:30 == 35.7
9/30/14 2:35 == 35.6
9/30/14 2:40 == 35.8
9/30/14 2:45 == 35.8
9/30/14 2:50 == 35.6
9/30/14 2:55 == 35.4
9/30/14 3:00 == 35.6
9/30/14 3:05 == 35.7
9/30/14 3:10 == 35.6
9/30/14 3:15 == 35.3
9/30/14 3:20 == 35.6
9/30/14 3:25 == 35.8
9/30/14 3:30 == 35.6
9/30/14 3:35 == 35.5
9/30/14 3:40 == 35.5
9/30/14 3:45 == 35.8
9/30/14 3:50 == 35.9
9/30/14 3:55 == 35.8
9/30/14 4:00 == 35.6
9/30/14 4:05 == 35.6
9/30/14 4:10 == 35.7
9/30/14 4:15 == 35.9
9/30/14 4:20 == 35.8
9/30/14 4:25 == 35.6
9/30/14 4:30 == 35.2
9/30/14 4:35 == 35.5
9/30/14 4:40 == 35.8
9/30/14 4:45 == 35.7
9/30/14 4:50 == 35.4
9/30/14 4:55 == 35.4
9/30/14 5:00 == 35.7
9/30/14 5:05 == 35.8
9/30/14 5:10 == 35.7
9/30/14 5:15 == 35.4
9/30/14 5:20 == 35.5
9/30/14 5:25 == 35.8
9/30/14 5:30 == 35.8
9/30/14 5:35 == 35.6
9/30/14 5:40 == 35.4
9/30/14 5:45 == 35.6
9/30/14 5:50 == 35.7
9/30/14 5:55 == 35.6
9/30/14 6:00 == 35.6
9/30/14 6:05 == 35.6
9/30/14 6:10 == 20.6
9/30/14 6:15 == 20.1
9/30/14 6:20 == 20
9/30/14 6:25 == 19.9
9/30/14 6:30 == 20
9/30/14 6:35 == 20.1
9/30/14 6:40 == 20.2
9/30/14 6:45 == 20.1
9/30/14 6:50 == 19.9
9/30/14 6:55 == 20.1
9/30/14 7:00 == 20.2
9/30/14 7:05 == 20.2
9/30/14 7:10 == 19.9
9/30/14 7:15 == 19.9
9/30/14 7:20 == 19.8
9/30/14 7:25 == 19.8
9/30/14 7:30 == 19.9
9/30/14 7:35 == 19.9
9/30/14 7:40 == 20.1
9/30/14 7:45 == 20.1
9/30/14 7:50 == 20.3
9/30/14 7:55 == 20.3
9/30/14 8:00 == 20
9/30/14 8:05 == 20
9/30/14 8:10 == 20.2
9/30/14 8:15 == 20.2
9/30/14 8:20 == 20.3
9/30/14 8:25 == 20
9/30/14 8:30 == 20.5
9/30/14 8:35 == 20.3
9/30/14 8:40 == 13.2
9/30/14 8:45 == 13.7
9/30/14 8:50 == 13.3
9/30/14 8:55 == 13.3
9/30/14 9:00 == 29.2
9/30/14 9:05 == 31.6
9/30/14 9:10 == 31.7
9/30/14 9:15 == 31.2
9/30/14 9:20 == 31.1
9/30/14 9:25 == 14.9
9/30/14 9:30 == 13
9/30/14 9:35 == 13.1
9/30/14 9:40 == 20.9
9/30/14 9:45 == 31.9
9/30/14 9:50 == 31.6
9/30/14 9:55 == 35.1
9/30/14 10:00 == 48.1
9/30/14 10:05 == 48
9/30/14 10:10 == 47.9
9/30/14 10:15 == 48.1
9/30/14 10:20 == 47.9
9/30/14 10:25 == 48
9/30/14 10:30 == 48
9/30/14 10:35 == 48
9/30/14 10:40 == 47.9
9/30/14 10:45 == 47.9
9/30/14 10:50 == 47.9
9/30/14 10:55 == 47.9
9/30/14 11:00 == 48
9/30/14 11:05 == 48.1
9/30/14 11:10 == 48
9/30/14 11:15 == 48
9/30/14 11:20 == 47.9
9/30/14 11:25 == 48
9/30/14 11:30 == 48.1
9/30/14 11:35 == 48
9/30/14 11:40 == 48
9/30/14 11:45 == 47.8
9/30/14 11:50 == 48
9/30/14 11:55 == 48.1
9/30/14 12:00 == 48.1
9/30/14 12:05 == 48.1
9/30/14 12:10 == 48
9/30/14 12:15 == 47.9
9/30/14 12:20 == 47.9
9/30/14 12:25 == 47.9
9/30/14 12:30 == 48
9/30/14 12:35 == 48
9/30/14 12:40 == 48.1
9/30/14 12:45 == 48
9/30/14 12:50 == 47.9
9/30/14 12:55 == 48
9/30/14 13:00 == 48.1
9/30/14 13:05 == 48
9/30/14 13:10 == 48
9/30/14 13:15 == 48.2
9/30/14 13:20 == 48
9/30/14 13:25 == 48.1
9/30/14 13:30 == 47.9
9/30/14 13:35 == 43
9/30/14 13:40 == 36.1
9/30/14 13:45 == 35.6
9/30/14 13:50 == 35.7
9/30/14 13:55 == 36
9/30/14 14:00 == 35.8
9/30/14 14:05 == 35.8
9/30/14 14:10 == 36
9/30/14 14:15 == 35.9
9/30/14 14:20 == 36
9/30/14 14:25 == 36.2
9/30/14 14:30 == 36.5
9/30/14 14:35 == 36.7
9/30/14 14:40 == 36.5
9/30/14 14:45 == 36.1
9/30/14 14:50 == 36
9/30/14 14:55 == 36
9/30/14 15:00 == 35.9
9/30/14 15:05 == 36
9/30/14 15:10 == 35.7
9/30/14 15:15 == 36.5
9/30/14 15:20 == 36.5
9/30/14 15:25 == 36.4
9/30/14 15:30 == 36.2
9/30/14 15:35 == 35.9
9/30/14 15:40 == 35.4
9/30/14 15:45 == 35.4
9/30/14 15:50 == 36.8
9/30/14 15:55 == 48.1
9/30/14 16:00 == 48.1
9/30/14 16:05 == 48
9/30/14 16:10 == 47.9
9/30/14 16:15 == 47.9
9/30/14 16:20 == 48
9/30/14 16:25 == 48
9/30/14 16:30 == 48
9/30/14 16:35 == 48
9/30/14 16:40 == 47.9
9/30/14 16:45 == 48
9/30/14 16:50 == 42
9/30/14 16:55 == 35.3
9/30/14 17:00 == 35.7
9/30/14 17:05 == 36.1
9/30/14 17:10 == 36.3
9/30/14 17:15 == 36.1
9/30/14 17:20 == 36.2
9/30/14 17:25 == 36.4
9/30/14 17:30 == 36.6
9/30/14 17:35 == 36.2
9/30/14 17:40 == 36
9/30/14 17:45 == 35.5
9/30/14 17:50 == 35.1
9/30/14 17:55 == 34.9
9/30/14 18:00 == 35.4
9/30/14 18:05 == 35.9
9/30/14 18:10 == 36.4
9/30/14 18:15 == 36.5
9/30/14 18:20 == 36.8
9/30/14 18:25 == 36.7
9/30/14 18:30 == 36.8
9/30/14 18:35 == 36.8
9/30/14 18:40 == 36.5
9/30/14 18:45 == 36.6
9/30/14 18:50 == 36.7
9/30/14 18:55 == 36.4

Pumpback Station Discharge (0364)

9/30/14 19:00 == 36.1
9/30/14 19:05 == 35.9
9/30/14 19:10 == 35.5
9/30/14 19:15 == 35.2
9/30/14 19:20 == 35.5
9/30/14 19:25 == 36
9/30/14 19:30 == 36.4
9/30/14 19:35 == 36.7
9/30/14 19:40 == 36.9
9/30/14 19:45 == 37.1
9/30/14 19:50 == 36.8
9/30/14 19:55 == 36.9
9/30/14 20:00 == 37.1
9/30/14 20:05 == 37
9/30/14 20:10 == 37
9/30/14 20:15 == 37.1
9/30/14 20:20 == 36.9
9/30/14 20:25 == 36.9
9/30/14 20:30 == 36.7
9/30/14 20:35 == 37.5
9/30/14 20:40 == 48
9/30/14 20:45 == 47.9
9/30/14 20:50 == 48.1
9/30/14 20:55 == 48
9/30/14 21:00 == 48
9/30/14 21:05 == 48
9/30/14 21:10 == 48
9/30/14 21:15 == 47.9
9/30/14 21:20 == 42.2
9/30/14 21:25 == 36.1
9/30/14 21:30 == 36.2
9/30/14 21:35 == 36.2
9/30/14 21:40 == 36.1
9/30/14 21:45 == 36.2
9/30/14 21:50 == 36.3
9/30/14 21:55 == 36.1
9/30/14 22:00 == 35.8
9/30/14 22:05 == 35.4
9/30/14 22:10 == 35.2
9/30/14 22:15 == 35.1
9/30/14 22:20 == 35.5
9/30/14 22:25 == 35.9
9/30/14 22:30 == 36.4
9/30/14 22:35 == 36.4
9/30/14 22:40 == 36.7
9/30/14 22:45 == 36.7
9/30/14 22:50 == 36.7
9/30/14 22:55 == 36.8
9/30/14 23:00 == 36.7
9/30/14 23:05 == 36.8
9/30/14 23:10 == 36.8
9/30/14 23:15 == 36.8
9/30/14 23:20 == 36.6
9/30/14 23:25 == 36.3
9/30/14 23:30 == 36
9/30/14 23:35 == 35.5
9/30/14 23:40 == 35.4
9/30/14 23:45 == 35.7
9/30/14 23:50 == 36.2
9/30/14 23:55 == 36.6