

LORP Synopsis for July 2014

Compliance Comments:

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting and increased sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

Here are the flow changes during the month:

LORP Intake increased from 75 cfs to 80 cfs on July 8th, 2014.

Langemann at Pump Station increased from 7.5 cfs to 20 cfs on July 21st, 2014.

Langemann at Pump Station decreased from 20 cfs to 7.5 cfs on July 31st, 2014.

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2014-15)

The runoff forecast for runoff year 2014-15 is 50%, so the waterfowl acreage goal for this year is 250 acres.

On April 7th the Thibaut Waterfowl Area inflow was turned off for the summer.

On April 16th the spring flows were set and the inflows to Drew were increased to 4.9 cfs. When the wetted perimeter was measured with GPS in the middle of the spring season, the wetted area was 309 acres for Drew.

On May 29th the summer flows were set and the inflows to Drew were decreased to 4.7 cfs. When the wetted perimeter was measured with GPS in the middle of the summer season, the wetted area was 278 acres for Drew.

Drew Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
4.9 cfs	4/16/14	309	5/8/14
4.7 cfs	5/29/14	278	7/8/14

Waggoner Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
N/A		N/A	

Winterton Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
N/A		N/A	

Thibaut Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
0	4/7/14	N/A	

JULY 2014 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes
At Mazourka Canyon Road	7/22/2014	68.88	81.92	80.89	-13	gage height 4.97
At Reinhackle Springs	7/22/2014	65.17	73.55	75.25	-9	gage height 4.55
LORP Intake	7/23/2014	77.8	81.1	81.1	N/A	bad read
LORP Intake	7/24/2014	88.9	80	80	N/A	bad read
LORP Intake	7/28/2014	83.7	78.9	78.9	5	gage height 6.17

Month: July
Year: 2014

Date	Intake			Blackrock Ditch Return		Goose Lake Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	River Daily Avg
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	Month to Date					
07/01/14	78	73	15	1	1	1	1	0.9	1	63	64	15	0	0	0	0	55	56	15	0	0	43	42	12	35	35	8	0	60
07/02/14	78	74	15	2	1	1	1	1.0	1	64	64	15	0	0	0	0	54	56	15	0	0	43	42	13	35	35	8	0	60
07/03/14	78	75	15	1	1	1	1	1.0	1	65	64	15	0	0	0	0	54	56	15	0	0	42	42	13	34	35	8	0	60
07/04/14	78	75	15	1	1	1	1	1.0	1	66	64	15	0	0	0	0	55	56	15	0	0	42	42	13	34	35	8	0	60
07/05/14	78	75	15	1	1	1	1	1.0	1	65	63	15	0	0	0	0	56	56	15	0	0	42	42	13	34	34	8	0	60
07/06/14	79	76	15	1	1	1	1	1.0	1	66	63	15	0	0	0	0	59	56	15	0	0	41	42	14	33	34	8	0	61
07/07/14	80	76	15	2	1	1	1	1.0	1	66	63	15	0	0	0	0	61	56	15	0	0	41	42	14	33	34	8	0	62
07/08/14	81	77	15	1	1	1	1	1.0	1	66	63	15	0	0	0	0	62	56	15	0	0	42	42	15	34	34	8	0	63
07/09/14	83	78	15	1	1	1	1	1.0	1	67	63	15	0	0	0	0	63	57	15	0	0	44	43	15	36	34	8	0	64
07/10/14	83	79	15	1	1	1	1	1.1	1	67	64	15	0	0	0	0	63	57	15	0	0	46	43	15	38	35	8	0	65
07/11/14	82	79	15	2	1	1	1	1.1	1	67	64	15	0	0	0	0	62	58	15	0	0	47	43	15	39	35	8	0	65
07/12/14	83	80	15	1	1	1	1	1.2	1	68	65	15	0	0	0	0	63	58	15	0	0	46	43	15	38	35	8	0	65
07/13/14	84	80	15	1	1	1	1	1.1	1	68	65	15	0	0	0	0	64	59	15	0	0	47	43	15	39	36	8	0	66
07/14/14	84	80	15	1	1	1	1	1.1	1	69	66	15	0	0	0	0	63	59	15	0	0	46	44	15	38	36	8	0	66
07/15/14	83	81	15	1	1	1	1	1.1	1	69	66	15	0	0	0	0	63	60	15	0	0	46	44	15	39	36	7	0	65
07/16/14	83	81	15	2	1	1	1	1.2	1	69	67	15	0	0	0	0	65	60	15	0	0	48	44	15	40	36	8	0	66
07/17/14	83	81	15	2	1	1	1	1.1	1	69	67	15	0	0	0	0	64	61	15	0	0	48	45	15	40	36	8	0	66
07/18/14	83	82	15	1	1	1	1	1.1	1	68	67	15	0	0	0	0	65	62	15	0	0	48	45	15	40	37	8	0	66
07/19/14	83	82	15	1	1	1	1	1.1	1	68	67	15	0	0	0	0	64	62	15	0	0	49	45	15	41	37	8	0	66
07/20/14	83	82	15	1	1	1	1	1.1	1	69	68	15	0	0	0	0	64	63	15	0	0	47	46	15	40	37	7	0	66
07/21/14	83	83	15	1	1	1	1	1.1	1	69	68	15	0	0	0	0	63	63	15	0	0	48	46	15	32	37	16	0	66
07/22/14	84	83	15	1	1	1	1	1.1	1	69	68	15	0	0	0	0	65	64	15	0	0	45	46	15	25	36	20	0	66
07/23/14	83	83	15	1	1	1	1	1.1	1	70	68	15	0	0	0	0	66	64	15	0	0	50	47	15	30	36	20	0	67
07/24/14	83	83	15	1	1	1	1	1.1	1	70	69	15	0	0	0	0	65	64	15	0	0	46	47	15	26	36	20	0	66
07/25/14	83	83	15	1	1	1	1	1.1	1	69	69	15	0	0	1	0	65	64	15	0	0	48	47	15	28	35	20	0	66
07/26/14	83	83	15	1	1	1	1	1.1	1	69	69	15	0	0	5	0	68	64	15	0	0	47	47	15	27	35	20	0	67
07/27/14	83	83	15	1	1	1	1	1.0	1	68	69	15	0	0	5	1	70	65	15	0	0	47	47	15	27	35	20	0	67
07/28/14	85	83	15	1	1	1	1	1.0	1	69	69	15	0	0	5	1	69	65	15	0	0	45	47	15	25	34	20	0	67
07/29/14	85	83	15	1	1	1	1	1.0	1	69	69	15	0	0	12	2	76	66	15	0	0	48	47	15	28	34	20	0	70
07/30/14	85	83	15	1	1	1	1	1.0	1	67	69	15	0	0	10	3	80	67	15	0	0	49	48	15	29	34	20	0	70
07/31/14	85	84	15	2	1	1	1	1.0	1	67	69	15	0	0	3	3	76	68	15	0	0	52	48	15	40	34	11	1	70

Lower Owens River Project Flow Report for 07/01/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	73	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.9	1			
Mazourka Canyon Road			63	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			43	42	12
Pump Station			35	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	59	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 6/18/2014)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.52 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/02/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	74	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			64	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			43	42	13
Pump Station			35	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	59	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/03/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	75	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			65	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			42	42	13
Pump Station			34	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	59	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/04/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	75	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			66	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			42	42	13
Pump Station			34	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	59	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/05/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	75	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			65	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			42	42	13
Pump Station			34	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	59	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/06/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			79	76	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			66	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			41	42	14
Pump Station			33	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			61	59	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/07/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	76	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			66	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			61	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			41	42	14
Pump Station			33	34	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			62	59	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/08/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			81	77	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			66	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			42	42	15
Pump Station			34	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			63	60	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/09/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	78	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			67	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			44	43	15
Pump Station			36	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			64	60	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/10/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	79	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			67	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			46	43	15
Pump Station			38	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	61	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/11/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			82	79	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			67	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	43	15
Pump Station			39	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	61	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/12/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			68	65	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			46	43	15
Pump Station			38	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	62	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/13/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			84	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			68	65	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			64	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	43	15
Pump Station			39	35	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	62	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/14/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			84	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	66	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			46	44	15
Pump Station			38	36	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	62	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/15/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	81	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	66	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			46	44	15
Pump Station			39	36	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	63	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 7/2/2014)
Lower Twin Lake Gage Read	2.16 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/16/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	81	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			69	67	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	44	15
Pump Station			40	36	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	63	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/17/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	81	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	67	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			64	61	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	45	15
Pump Station			40	37	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	64	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/18/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	82	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			68	67	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	62	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	45	15
Pump Station			40	37	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	64	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/19/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	82	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			68	67	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			64	62	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	45	15
Pump Station			41	37	
Langemann Gate to Delta			8	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	64	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	309 Acres	05/08/2014	4.9 cfs	04/16/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	309 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/20/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	82	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1 [e]	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	68	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			64	63	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	46	15
Pump Station			40	38	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	65	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Goose Lake Return by spot read due to communication problems with the instruments.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/21/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1 [e]	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	68	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	63	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	46	15
Pump Station			32	38	
Langemann Gate to Delta			16	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	65	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Goose Lake Return by spot read due to communication problems with the instruments.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/22/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			84	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1 [e]	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	68	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			45	46	15
Pump Station			25	37	
Langemann Gate to Delta			20	9	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	65	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Goose Lake Return by spot read due to communication problems with the instruments.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/23/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1 [e]	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			70	68	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			66	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			50	47	15
Pump Station			30	37	
Langemann Gate to Delta			20	10	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			67	66	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

[e] Flow estimated at Goose Lake Return by spot read due to communication problems with the instruments.

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/24/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			70	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			46	47	15
Pump Station			26	36	
Langemann Gate to Delta			20	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	66	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/25/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			65	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	47	15
Pump Station			28	36	
Langemann Gate to Delta			20	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	66	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/26/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			69	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	5	0			
Reinhackle Springs			68	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	47	15
Pump Station			27	35	
Langemann Gate to Delta			20	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			67	66	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/27/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			83	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			68	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	5	1			
Reinhackle Springs			70	65	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	47	15
Pump Station			27	34	
Langemann Gate to Delta			20	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			67	66	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/28/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			85	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			69	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	5	1			
Reinhackle Springs			69	65	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			45	47	15
Pump Station			25	33	
Langemann Gate to Delta			20	14	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			67	66	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/29/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			85	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			69	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	12	2			
Reinhackle Springs			76	66	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	47	15
Pump Station			28	33	
Langemann Gate to Delta			20	15	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	67	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.5 ft	(Last Collected: 7/16/2014)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/30/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			85	83	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			67	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	10	3			
Reinhackle Springs			80	67	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	48	15
Pump Station			29	32	
Langemann Gate to Delta			20	16	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	67	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/30/2014)
Lower Twin Lake Gage Read	2.05 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/31/2014

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			85	84	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			67	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	3	3			
Reinhackle Springs			76	68	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			52	48	15
Pump Station			40	32	
Langemann Gate to Delta			11	16	
Weir to Delta			1	0	
LORP In Channel Average Flow ²			70	67	

Pump Station Month-to-Date Average Flow 34 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	0 Acres	04/07/2014	0 cfs	04/07/2014
Winterton	0 Acres	05/31/2012	0 cfs	04/17/2012
Drew	278 Acres	07/08/2014	4.7 cfs	05/29/2014
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	278 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/30/2014)
Lower Twin Lake Gage Read	2.05 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	0 Acres	(Last Collected: 04/07/2014)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Robert Turner/Larry Benbrook/Todd Bunn/Mark Wilder/David Tait

DATE: Monday, July 7th, 2014

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: July 8th, 2014 TIME: Anytime

CHANGE FLOW FROM: 75 cfs TO 80 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Clarence Martin
Robert Prendergast
Charlotte Rodrigues
Steve Butler
Jim Campbell
William Jones
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Robert Olin/Nelson Mejia/Jason Olin

DATE: Friday July 18th, 2014

REQUESTED BY: William Jones x30380

FLOW CHANGE LOCATION **Langemann Gate at Pumpstation**

START DATE: Monday July 21st, 2014 TIME: 8 am

CHANGE FLOW: FROM: 7.5 cfs TO: 20 cfs at LORPS Langemann

END DATE: Thursday July 31st, 2014 TIME: 8 am

CHANGE FLOW: FROM: 20 cfs TO: 7.5 cfs at LORPS Langemann

C: James Yannotta
Clarence Martin
Jim Campbell
Nelson Mejia
Bruce Peterson
Charlotte Rodrigues
Ben Butler

Eric Tillemans
Steve Howe
Gary Reiser
Bob Strub
Neal Gordon
Jason Olin
Larry Benbrook

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.

Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

-  [Open a FlowTracker file](#)
-  [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

 [Connect to a FlowTracker](#)

To download data and run diagnostics

070706.ORABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007






File Information		Site Details	
File Name	070706.ORABR.LOR.WAD	Site Name	ORABR
Start Date and Time	2007/07/06 07:48:17	Operator(s)	DJT

System Information		Units	(English Units)
Sensor Type	FlowTracker	Distance	ft
Serial #	P1685	Velocity	ft/s
CPU Firmware Version	3.2	Area	ft^2
Software Ver	2.11	Discharge	cfs

Discharge Uncertainty		
Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	2.1%	1.8%

Summary			
Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	44.3025

Measurement Results												
St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	08:12	40.00	0.2/0.8	1.490	0.2	1.192	0.8245	1.00	0.6321	2.980	1.8837	4.3
13	08:13	40.00	0.2/0.8	1.490	0.8	0.298	0.4396					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

-  [Program Settings](#)
- [Quality Control Settings](#)
-  [Show User's Manual](#)
-  [Show Technical Manual](#)
-  [Show Quick Start](#)
-  [About FlowTracker](#)

 English




A YSI Environmental Company

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:




-  [Open a FlowTracker file](#)
-  [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

-  [Connect to a FlowTracker](#)
To download data and run diagnostics


070706.0RABR.LOR.WAD







Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



-  [Program Settings](#)
- [Quality Control Settings](#)
-  [Show User's Manual](#)
-  [Show Technical Manual](#)
-  [Show Quick Start](#)
-  [About FlowTracker](#)

 English
 

 A YSI Environmental Company

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:





-  [Open a FlowTracker file](#)
-  [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

 [Connect to a FlowTracker](#)




To download data and run diagnostics

-  [Program Settings](#)
- [Quality Control Settings](#)
-  [Show User's Manual](#)
-  [Show Technical Manual](#)
-  [Show Quick Start](#)
-  [About FlowTracker](#)

 English




070706.0RABR.LOR.WAD





Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz

File	BROR_070801_a
File Size	65.18 kB

Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:	
V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:	
V Beam (m)	0.426
Stage (m)	1.304 V
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:	
SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

Party: MKH/BJA	Width: 24.8 ft	Processed by: MKH
Boat/Motor:	Area: 182 ft ²	Mean Velocity: 0.429 ft/s
Gage Height: 7.73 ft	G.H.Change: 0.000 ft	Discharge: 77.9 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: _____ Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 140723 LAA @ INTAKE000r.m
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	36	5.62	59.3	8.40	1.80	3.28	78.4	25	180	08:03	08:03	0.63	0.44	8	0
001	R	2	2	35	5.09	54.0	7.73	1.94	3.81	72.6	25	179	08:04	08:05	0.60	0.41	9	0
002	L	2	2	35	5.09	53.3	7.84	1.77	3.60	71.6	25	180	08:05	08:06	0.61	0.40	9	0
003	R	2	2	34	6.11	65.0	9.36	1.70	3.64	85.8	25	184	08:06	08:07	0.63	0.47	9	0
004	L	2	2	34	5.79	61.6	8.72	1.59	3.88	81.6	25	184	08:07	08:08	0.60	0.44	6	0
005	R	2	2	35	6.29	67.4	8.90	1.62	3.32	87.5	25	181	08:08	08:09	0.61	0.49	9	0
006	L	2	2	34	5.26	55.5	7.95	1.80	3.18	73.7	25	180	08:10	08:10	0.62	0.41	9	0
007	R	2	2	34	5.58	59.2	8.79	1.55	3.04	78.1	26	190	08:11	08:11	0.63	0.41	9	0
008	L	2	2	35	5.19	55.3	8.02	1.52	3.71	73.8	24	179	08:13	08:13	0.57	0.41	9	0
009	R	2	2	34	5.33	57.1	7.80	1.80	3.53	75.6	24	178	08:14	08:14	0.60	0.42	9	0
Mean		2	2	34	5.53	58.8	8.35	1.71	3.50	77.9	25	182	Total	00:11	0.61	0.43	8	0
SDev		0	0	1	0.422	4.70	0.565	0.135	0.282	5.54	0.4	3.7			0.02	0.03		
SD/M		0.00	0.00	0.03	0.08	0.08	0.07	0.08	0.08	0.07	0.02	0.02			0.03	0.07		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Party: MKH/BJA	Width: 27.6 ft	Processed by: MKH
Boat/Motor:	Area: 174 ft ²	Mean Velocity: 0.510 ft/s
Gage Height: 6.55 ft	G.H.Change: 0.000 ft	Discharge: 89.0 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 2.18 ft/s	
Max. Depth: 7.47 ft	
Mean Depth: 6.31 ft	
% Meas.: 74.35	
Water Temp.: None	
ADCP Temp.: 75.5 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 140724 LORP @ INTAKE000r.1
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
005	L	2	2	35	7.10	63.6	9.32	1.77	3.67	85.4	28	175	13:42	13:42	0.67	0.49	9	0
007	L	2	2	37	<i>6.82</i>	<i>60.1</i>	<i>9.53</i>	<i>1.80</i>	<i>3.60</i>	<i>81.9</i>	27	168	13:44	13:44	0.68	0.49	16	0
009	L	2	2	36	<i>8.23</i>	<i>72.9</i>	<i>11.5</i>	<i>1.98</i>	<i>3.53</i>	<i>98.2</i>	29	180	13:46	13:46	0.71	0.54	8	0
010	R	2	2	35	<i>8.02</i>	<i>71.2</i>	<i>10.9</i>	<i>1.77</i>	<i>3.60</i>	<i>95.5</i>	28	175	13:47	13:47	0.73	0.55	14	0
011	L	2	2	35	7.31	64.6	9.96	1.98	3.57	87.5	27	174	13:48	13:49	0.70	0.51	9	0
012	R	2	2	34	<i>6.92</i>	<i>62.0</i>	<i>9.04</i>	<i>1.91</i>	<i>3.57</i>	<i>83.6</i>	27	173	13:49	13:50	0.72	0.48	9	0
013	L	2	2	34	<i>7.59</i>	<i>66.7</i>	<i>10.8</i>	<i>1.87</i>	<i>3.32</i>	<i>90.3</i>	28	175	13:51	13:52	0.71	0.52	9	0
014	R	2	2	36	<i>7.49</i>	<i>67.8</i>	<i>9.11</i>	<i>1.55</i>	<i>3.43</i>	<i>89.4</i>	28	175	13:52	13:53	0.70	0.51	14	0
Mean		2	2	35	7.43	66.1	10.0	1.83	3.54	89.0	28	174	Total	00:11	0.70	0.51	11	0
SDev		0	0	1	0.503	4.40	0.933	0.140	0.112	5.64	0.5	3.5			0.02	0.02		
SD/M		0.00	0.00	0.03	0.07	0.07	0.09	0.08	0.03	0.06	0.02	0.02			0.03	0.05		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Party: MKH/BJA	Width: 28.3 ft	Processed by: MKH/BJA
Boat/Motor:	Area: 172 ft ²	Mean Velocity: 0.486 ft/s
Gage Height: 6.28 ft	G.H.Change: 0.000 ft	Discharge: 83.8 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 2.01 ft/s	
Max. Depth: 7.16 ft	
Mean Depth: 6.08 ft	
% Meas.: 74.81	
Water Temp.: None	
ADCP Temp.: 74.8 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 14728 INTAKE @ LORP000r
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	33	<i>7.91</i>	<i>68.3</i>	<i>9.89</i>	<i>1.73</i>	<i>3.04</i>	<i>90.8</i>	28	173	11:46	11:47	0.72	0.52	6	0
001	R	2	2	33	<i>7.20</i>	<i>61.4</i>	<i>8.97</i>	<i>1.66</i>	<i>3.04</i>	<i>82.3</i>	28	172	11:47	11:48	0.75	0.48	6	0
002	L	2	2	33	<i>7.88</i>	<i>67.5</i>	<i>9.96</i>	<i>1.77</i>	<i>3.07</i>	<i>90.2</i>	29	176	11:48	11:49	0.75	0.51	6	0
003	R	2	2	33	<i>7.13</i>	<i>61.1</i>	<i>8.69</i>	<i>1.48</i>	<i>3.35</i>	<i>81.8</i>	28	173	11:49	11:50	0.75	0.48	6	0
004	L	2	2	33	<i>6.89</i>	<i>59.3</i>	<i>8.79</i>	<i>1.84</i>	<i>3.14</i>	<i>80.0</i>	28	171	11:50	11:51	0.78	0.47	6	0
005	R	2	2	34	<i>7.27</i>	<i>62.9</i>	<i>8.33</i>	<i>1.66</i>	<i>3.07</i>	<i>83.2</i>	28	170	11:51	11:52	0.72	0.49	9	0
006	L	2	2	42	<i>7.91</i>	<i>66.9</i>	<i>10.2</i>	<i>1.77</i>	<i>3.25</i>	<i>90.0</i>	31	186	11:55	11:56	0.65	0.49	26	0
007	R	2	2	36	<i>6.78</i>	<i>58.7</i>	<i>8.05</i>	<i>1.59</i>	<i>3.00</i>	<i>78.2</i>	28	169	11:57	11:57	0.72	0.46	11	0
008	L	2	2	33	<i>7.45</i>	<i>62.3</i>	<i>9.61</i>	<i>1.70</i>	<i>3.00</i>	<i>84.1</i>	27	166	11:58	11:59	0.73	0.51	6	0
009	R	2	2	34	<i>6.67</i>	<i>58.2</i>	<i>7.52</i>	<i>1.73</i>	<i>3.04</i>	<i>77.2</i>	28	168	11:59	12:00	0.74	0.46	9	0
Mean		2	2	34	7.31	62.7	9.00	1.69	3.10	83.8	28	172	Total	00:13	0.73	0.49	9	0
SDev		0	0	3	0.468	3.71	0.889	0.101	0.116	5.00	0.9	5.5			0.03	0.02		
SD/M		0.00	0.00	0.08	0.06	0.06	0.10	0.06	0.04	0.06	0.03	0.03			0.05	0.05		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Discharge Measurement Summary

Date Generated: Thu Jul 10 2014

File Information

File Name 140702BR.LOR.WAD
Start Date and Time 2014/07/02 09:05:31

Site Details

Site Name BLACK ROCK DITCH
Operator(s) BJA

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.8%	2.0%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	2.2%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	24.5 dB	Total Area	6.355
Mean Temp	68.97 °F	Mean Depth	1.070
Disch. Equation	Mid-Section	Mean Velocity	0.2137
		Total Discharge	1.3578

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:05	0.00	None	1.070	0.0	0.0	0.0000	1.00	0.1906	0.267	0.0510	3.8
1	09:05	0.50	0.6	1.070	0.6	0.428	0.1906	1.00	0.1906	0.535	0.1020	7.5
2	09:06	1.00	0.6	1.070	0.6	0.428	0.1791	1.00	0.1791	0.802	0.1437	10.6
3	09:07	2.00	0.6	1.070	0.6	0.428	0.2247	1.00	0.2247	1.070	0.2404	17.7
4	09:08	3.00	0.6	1.070	0.6	0.428	0.2333	1.00	0.2333	1.070	0.2496	18.4
5	09:09	4.00	0.6	1.070	0.6	0.428	0.2333	1.00	0.2333	1.070	0.2496	18.4
6	09:10	5.00	0.6	1.070	0.6	0.428	0.2103	1.00	0.2103	0.802	0.1687	12.4
7	09:11	5.50	0.6	1.070	0.6	0.428	0.2070	1.00	0.2070	0.503	0.1041	7.7
8	09:11	5.94	None	1.070	0.0	0.0	0.0000	1.00	0.2070	0.235	0.0487	3.6

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Thu Jul 10 2014

File Information

File Name 140702BR.LOR.WAD
 Start Date and Time 2014/07/02 09:05:31

Site Details

Site Name BLACK ROCK DITCH
 Operator(s) BJA



Discharge Measurement Summary

Date Generated: Thu Jul 10 2014

File Information

File Name 140702BR.LOR.WAD
Start Date and Time 2014/07/02 09:05:31

Site Details

Site Name BLACK ROCK DITCH
Operator(s) BJA

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Thu Jul 10 2014


File Information

File Name 140702BR.LOR.WAD
Start Date and Time 2014/07/02 09:05:31

Site Details

Site Name BLACK ROCK DITCH
Operator(s) BJA

Automatic Quality Control Test (BeamCheck)



- ✔ Noise level check - Pass
- ✔ SNR check - Pass
- ✔ Peak location check - Pass
- ✔ Peak shape check - Pass

Discharge Measurement Summary

Date Generated: Thu Jul 10 2014

File Information

File Name 140709BR.LOR.WAD
Start Date and Time 2014/07/09 08:28:10

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.7%	2.8%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	3.0%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	23.2 dB	Total Area	6.355
Mean Temp	69.81 °F	Mean Depth	1.070
Disch. Equation	Mid-Section	Mean Velocity	0.2077
		Total Discharge	1.3196

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:28	0.00	None	1.070	0.0	0.0	0.0000	1.00	0.1991	0.267	0.0533	4.0
1	08:28	0.50	0.6	1.070	0.6	0.428	0.1991	1.00	0.1991	0.535	0.1065	8.1
2	08:29	1.00	0.6	1.070	0.6	0.428	0.1909	1.00	0.1909	0.802	0.1532	11.6
3	08:30	2.00	0.6	1.070	0.6	0.428	0.2215	1.00	0.2215	1.070	0.2369	18.0
4	08:31	3.00	0.6	1.070	0.6	0.428	0.2441	1.00	0.2441	1.070	0.2612	19.8
5	08:32	4.00	0.6	1.070	0.6	0.428	0.2398	1.00	0.2398	1.070	0.2566	19.4
6	08:33	5.00	0.6	1.070	0.6	0.428	0.1670	1.00	0.1670	0.802	0.1340	10.2
7	08:34	5.50	0.6	1.070	0.6	0.428	0.1598	1.00	0.1598	0.503	0.0803	6.1
8	08:34	5.94	None	1.070	0.0	0.0	0.0000	1.00	0.1598	0.235	0.0376	2.8

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Thu Jul 10 2014

File Information

File Name 140709BR.LOR.WAD
 Start Date and Time 2014/07/09 08:28:10

Site Details

Site Name BLACK ROCK RETURN
 Operator(s) BJA



Discharge Measurement Summary

Date Generated: Thu Jul 10 2014

File Information

File Name 140709BR.LOR.WAD
Start Date and Time 2014/07/09 08:28:10

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Thu Jul 10 2014


File Information

File Name 140709BR.LOR.WAD
Start Date and Time 2014/07/09 08:28:10

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

Automatic Quality Control Test (BeamCheck)



Discharge Measurement Summary

Date Generated: Tue Jul 29 2014

File Information

File Name 140716BR.LOR.WAD
Start Date and Time 2014/07/16 07:34:53

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.6%	2.2%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	2.4%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	27.9 dB	Total Area	6.593
Mean Temp	70.01 °F	Mean Depth	1.110
Disch. Equation	Mid-Section	Mean Velocity	0.2696
		Total Discharge	1.7773

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:34	0.00	None	1.110	0.0	0.0	0.0000	1.00	0.2523	0.277	0.0700	3.9
1	07:34	0.50	0.6	1.110	0.6	0.444	0.2523	1.00	0.2523	0.555	0.1400	7.9
2	07:35	1.00	0.6	1.110	0.6	0.444	0.2297	1.00	0.2297	0.832	0.1912	10.8
3	07:36	2.00	0.6	1.110	0.6	0.444	0.2844	1.00	0.2844	1.110	0.3157	17.8
4	07:37	3.00	0.6	1.110	0.6	0.444	0.3054	1.00	0.3054	1.110	0.3390	19.1
5	07:38	4.00	0.6	1.110	0.6	0.444	0.3005	1.00	0.3005	1.110	0.3336	18.8
6	07:39	5.00	0.6	1.110	0.6	0.444	0.2510	1.00	0.2510	0.832	0.2089	11.8
7	07:40	5.50	0.6	1.110	0.6	0.444	0.2336	1.00	0.2336	0.522	0.1219	6.9
8	07:40	5.94	None	1.110	0.0	0.0	0.0000	1.00	0.2336	0.244	0.0570	3.2

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Tue Jul 29 2014

File Information

File Name 140716BR.LOR.WAD
 Start Date and Time 2014/07/16 07:34:53

Site Details

Site Name BLACK ROCK RETURN
 Operator(s) BJA



Discharge Measurement Summary

Date Generated: Tue Jul 29 2014

File Information

File Name 140716BR.LOR.WAD
Start Date and Time 2014/07/16 07:34:53

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Tue Jul 29 2014


File Information

File Name 140716BR.LOR.WAD
Start Date and Time 2014/07/16 07:34:53

Site Details

Site Name BLACK ROCK RETURN
Operator(s) BJA

Automatic Quality Control Test (BeamCheck)



Discharge Measurement Summary

Date Generated: Tue Jul 29 2014

File Information

File Name 140723BR.LOR.WAD
Start Date and Time 2014/07/23 09:39:25

Site Details

Site Name BR RETURN TO LOR
Operator(s) BJA

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.6%	2.4%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	2.6%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	17.0 dB	Total Area	5.998
Mean Temp	68.44 °F	Mean Depth	1.010
Disch. Equation	Mid-Section	Mean Velocity	0.1566
		Total Discharge	0.9392

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:39	0.00	None	1.010	0.0	0.0	0.0000	1.00	0.1378	0.252	0.0348	3.7
1	09:39	0.50	0.6	1.010	0.6	0.404	0.1378	1.00	0.1378	0.505	0.0696	7.4
2	09:40	1.00	0.6	1.010	0.6	0.404	0.1250	1.00	0.1250	0.757	0.0947	10.1
3	09:41	2.00	0.6	1.010	0.6	0.404	0.1568	1.00	0.1568	1.010	0.1584	16.9
4	09:42	3.00	0.6	1.010	0.6	0.404	0.1860	1.00	0.1860	1.010	0.1879	20.0
5	09:43	4.00	0.6	1.010	0.6	0.404	0.1824	1.00	0.1824	1.010	0.1842	19.6
6	09:45	5.00	0.6	1.010	0.6	0.404	0.1529	1.00	0.1529	0.757	0.1158	12.3
7	09:46	5.50	0.6	1.010	0.6	0.404	0.1348	1.00	0.1348	0.475	0.0640	6.8
8	09:46	5.94	None	1.010	0.0	0.0	0.0000	1.00	0.1348	0.222	0.0300	3.2

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Tue Jul 29 2014

File Information

File Name 140723BR.LOR.WAD
 Start Date and Time 2014/07/23 09:39:25

Site Details

Site Name BR RETURN TO LOR
 Operator(s) BJA



Discharge Measurement Summary

Date Generated: Tue Jul 29 2014

File Information

File Name 140723BR.LOR.WAD
Start Date and Time 2014/07/23 09:39:25

Site Details

Site Name BR RETURN TO LOR
Operator(s) BJA

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Tue Jul 29 2014

File Information


File Name 140723BR.LOR.WAD
Start Date and Time 2014/07/23 09:39:25

Site Details

Site Name BR RETURN TO LOR
Operator(s) BJA

Automatic Quality Control Test (BeamCheck)

Wed Jul 23 09:38:17 PDT 2014



- ✔ Noise level check - Pass
- ✔ SNR check - Pass
- ✔ Peak location check - Pass
- ✔ Peak shape check - Pass

Discharge Measurement Summary

Date Generated: Wed Jul 30 2014

File Information

File Name 140730BR.LOR.WAD
Start Date and Time 2014/07/30 08:55:31

Site Details

Site Name BR RTN TO LOR
Operator(s) BJA

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.6%	3.8%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	3.9%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	16.7 dB	Total Area	6.355
Mean Temp	70.33 °F	Mean Depth	1.070
Disch. Equation	Mid-Section	Mean Velocity	0.2268
		Total Discharge	1.4412

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:55	0.00	None	1.070	0.0	0.0	0.0000	1.00	0.2051	0.267	0.0548	3.8
1	08:55	0.50	0.6	1.070	0.6	0.428	0.2051	1.00	0.2051	0.535	0.1097	7.6
2	08:56	1.00	0.6	1.070	0.6	0.428	0.2359	1.00	0.2359	0.802	0.1893	13.1
3	08:57	2.00	0.6	1.070	0.6	0.428	0.2133	1.00	0.2133	1.070	0.2282	15.8
4	08:58	3.00	0.6	1.070	0.6	0.428	0.2595	1.00	0.2595	1.070	0.2776	19.3
5	09:00	4.00	0.6	1.070	0.6	0.428	0.2641	1.00	0.2641	1.070	0.2826	19.6
6	09:01	5.00	0.6	1.070	0.6	0.428	0.1952	1.00	0.1952	0.802	0.1566	10.9
7	09:02	5.50	0.6	1.070	0.6	0.428	0.1929	1.00	0.1929	0.503	0.0970	6.7
8	09:02	5.94	None	1.070	0.0	0.0	0.0000	1.00	0.1929	0.235	0.0454	3.2

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 30 2014

File Information

File Name 140730BR.LOR.WAD
 Start Date and Time 2014/07/30 08:55:31

Site Details

Site Name BR RTN TO LOR
 Operator(s) BJA



Discharge Measurement Summary

Date Generated: Wed Jul 30 2014

File Information

File Name 140730BR.LOR.WAD
Start Date and Time 2014/07/30 08:55:31

Site Details

Site Name BR RTN TO LOR
Operator(s) BJA

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Wed Jul 30 2014

File Information


File Name 140730BR.LOR.WAD
Start Date and Time 2014/07/30 08:55:31

Site Details

Site Name BR RTN TO LOR
Operator(s) BJA

Automatic Quality Control Test (BeamCheck)

Wed Jul 30 08:54:02 PDT 2014



- ✔ Noise level check - Pass
- ✔ SNR check - Pass
- ✔ Peak location check - Pass
- ✔ Peak shape check - Pass

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	0	0	9	0.394	0.052	0.86	0.039	0.036	0	49.9	49	71.4	146	143	0	30	29
2014	7	1	0	10	9	0.262	0.121	0.86	0.039	0.039	0	49	47.7	73.1	144	141	0	30	30
2014	7	1	0	20	9	0.22	-0.023	0.86	0.049	0.049	0	47.7	46.9	73.1	142	139	0	31	30
2014	7	1	0	30	9	0.344	0.016	0.856	0.039	0.039	0	48.2	47.3	73.1	142	140	0	30	30
2014	7	1	0	40	9	0.279	0.069	0.856	0.039	0.036	0	47.7	46.9	73.1	143	139	0	32	30
2014	7	1	0	50	9	0.282	0.056	0.856	0.036	0.033	0	48.2	46.9	73.5	143	139	0	31	30
2014	7	1	1	0	9	0.243	0	0.856	0.036	0.033	0	48.6	47.7	72.7	143	140	0	30	29
2014	7	1	1	10	9	0.285	0	0.856	0.033	0.03	0	49	47.3	72.2	145	140	0	31	30
2014	7	1	1	20	9	0.282	0.003	0.856	0.043	0.039	0	49.5	48.2	72.7	145	142	0	30	30
2014	7	1	1	30	9	0.282	-0.003	0.856	0.039	0.039	0	49.5	48.2	71.4	145	141	0	30	29
2014	7	1	1	40	9	0.299	-0.059	0.856	0.039	0.039	0	50.3	48.2	72.2	147	142	0	30	30
2014	7	1	1	50	9	0.279	-0.02	0.856	0.046	0.043	0	51.2	49.9	71	149	145	0	30	29
2014	7	1	2	0	9	0.256	0.016	0.856	0.039	0.036	0	50.7	48.6	71.4	148	143	0	30	30
2014	7	1	2	10	9	0.299	0.02	0.856	0.033	0.03	0	49.9	49.5	71	147	144	0	31	29
2014	7	1	2	20	9	0.338	0.033	0.856	0.039	0.036	0	50.3	49	71	148	144	0	31	30
2014	7	1	2	30	9	0.272	-0.043	0.853	0.039	0.036	0	50.3	48.2	71.4	147	142	0	30	30
2014	7	1	2	40	9	0.289	0.01	0.856	0.036	0.033	0	50.3	48.6	71	147	143	0	30	30
2014	7	1	2	50	9	0.335	0.049	0.853	0.046	0.043	0	49.9	48.6	71	146	142	0	30	29
2014	7	1	3	0	9	0.236	0.052	0.853	0.036	0.033	0	49.9	48.6	71.8	146	142	0	30	29
2014	7	1	3	10	9	0.312	-0.01	0.853	0.039	0.036	0	49.9	48.2	71.8	146	142	0	30	30
2014	7	1	3	20	9	0.305	0.003	0.853	0.039	0.036	0	49.5	48.6	71.8	146	143	0	31	30
2014	7	1	3	30	9	0.279	0.007	0.853	0.033	0.03	0	49	47.7	72.2	145	142	0	31	31
2014	7	1	3	40	9	0.262	0.069	0.853	0.039	0.036	0	49.5	48.2	73.1	145	142	0	30	30
2014	7	1	3	50	9	0.262	-0.023	0.853	0.036	0.033	0	49	48.6	71.8	145	142	0	31	29
2014	7	1	4	0	9	0.276	-0.066	0.853	0.039	0.039	0	50.3	49.9	71	148	146	0	31	30
2014	7	1	4	10	9	0.308	-0.007	0.853	0.039	0.036	0	49.9	48.2	71.4	146	142	0	30	30
2014	7	1	4	20	9	0.312	-0.016	0.853	0.033	0.03	0	49.9	48.2	71.8	146	142	0	30	30
2014	7	1	4	30	9	0.292	0.007	0.853	0.039	0.036	0	49.9	48.2	71.8	146	143	0	30	31
2014	7	1	4	40	9	0.292	-0.02	0.853	0.039	0.036	0	49.9	48.6	71.8	146	143	0	30	30
2014	7	1	4	50	9	0.289	0.02	0.853	0.036	0.033	0	49.5	49	71.8	146	143	0	31	29
2014	7	1	5	0	9	0.282	0.043	0.853	0.039	0.039	0	49.5	48.6	71.4	146	143	0	31	30
2014	7	1	5	10	9	0.325	0.016	0.853	0.036	0.033	0	49.9	48.6	71.8	146	143	0	30	30
2014	7	1	5	20	9	0.256	-0.026	0.853	0.039	0.036	0	49.5	48.6	71	146	143	0	31	30
2014	7	1	5	30	9	0.328	-0.052	0.85	0.033	0.03	0	49.9	49	71.4	146	144	0	30	30
2014	7	1	5	40	9	0.256	0.01	0.85	0.033	0.03	0	50.3	49.5	71.4	147	144	0	30	29
2014	7	1	5	50	9	0.331	0.01	0.85	0.039	0.036	0	51.2	49.5	70.5	149	145	0	30	30
2014	7	1	6	0	9	0.315	-0.016	0.85	0.043	0.039	0	50.3	49.5	70.1	148	145	0	31	30
2014	7	1	6	10	9	0.24	0.007	0.85	0.039	0.036	0	49.5	48.2	71	147	142	0	32	30
2014	7	1	6	20	9	0.24	-0.007	0.85	0.039	0.036	0	49.5	48.2	70.5	145	142	0	30	30
2014	7	1	6	30	9	0.253	-0.02	0.85	0.039	0.036	0	49.5	48.2	71.8	145	142	0	30	30
2014	7	1	6	40	9	0.325	0.02	0.85	0.036	0.033	0	49	47.3	72.2	145	140	0	31	30
2014	7	1	6	50	9	0.24	0.033	0.85	0.039	0.036	0	51.6	49.9	69.2	151	146	0	31	30
2014	7	1	7	0	9	0.318	-0.007	0.85	0.043	0.039	0	52	50.7	69.2	152	147	0	31	29
2014	7	1	7	10	9	0.341	-0.013	0.85	0.043	0.039	0	51.6	50.3	69.2	151	147	0	31	30
2014	7	1	7	20	9	0.289	0.046	0.846	0.046	0.043	0	51.2	49.9	69.2	150	147	0	31	31
2014	7	1	7	30	9	0.302	0.052	0.846	0.033	0.03	0	51.6	50.7	69.2	151	147	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	7	40	9	0.21	0.02	0.85	0.039	0.036	0	51.2	49.9	68.8	150	146	0	31	30
2014	7	1	7	50	9	0.318	0	0.846	0.039	0.036	0	52	50.7	67.9	151	148	0	30	30
2014	7	1	8	0	9	0.23	0.023	0.846	0.039	0.039	0	52.5	51.2	68.8	152	148	0	30	29
2014	7	1	8	10	9	0.344	0.023	0.846	0.039	0.039	0	50.7	49.9	69.7	149	146	0	31	30
2014	7	1	8	20	9	0.282	0.003	0.846	0.039	0.036	0	50.7	49.5	70.1	149	145	0	31	30
2014	7	1	8	30	9	0.223	0.03	0.846	0.046	0.043	0	49.5	48.6	70.5	146	143	0	31	30
2014	7	1	8	40	9	0.308	0.023	0.846	0.039	0.036	0	51.2	49.9	68.4	150	146	0	31	30
2014	7	1	8	50	9	0.266	0.01	0.846	0.039	0.039	0	53.3	52	66.2	155	152	0	31	31
2014	7	1	9	0	9	0.285	-0.03	0.846	0.039	0.039	0	52	50.7	67.5	152	148	0	31	30
2014	7	1	9	10	9	0.272	0.023	0.846	0.036	0.033	0	51.2	50.3	68.4	150	147	0	31	30
2014	7	1	9	20	9	0.272	0.013	0.846	0.043	0.039	0	51.6	50.7	67.5	151	148	0	31	30
2014	7	1	9	30	9	0.276	-0.02	0.846	0.036	0.033	0	51.6	50.7	67.5	151	148	0	31	30
2014	7	1	9	40	9	0.243	0.026	0.843	0.039	0.039	0	52.5	51.6	66.2	153	150	0	31	30
2014	7	1	9	50	9	0.256	0.036	0.843	0.033	0.03	0	52.5	50.7	67.1	153	148	0	31	30
2014	7	1	10	0	9	0.312	-0.072	0.843	0.039	0.039	0	51.6	50.3	67.5	151	147	0	31	30
2014	7	1	10	10	9	0.289	0.02	0.843	0.039	0.039	0	52	51.6	66.7	152	150	0	31	30
2014	7	1	10	20	9	0.354	-0.02	0.843	0.043	0.039	0	52.9	52	65.4	154	151	0	31	30
2014	7	1	10	30	9	0.292	-0.013	0.843	0.039	0.039	0	55.5	53.3	63.2	159	154	0	30	30
2014	7	1	10	40	9	0.341	-0.023	0.843	0.039	0.036	0	53.8	52.5	63.6	156	152	0	31	30
2014	7	1	10	50	9	0.351	-0.003	0.84	0.039	0.039	0	52.9	51.2	65.4	153	149	0	30	30
2014	7	1	11	0	9	0.272	0.01	0.84	0.043	0.039	0	52.5	51.2	65.8	153	149	0	31	30
2014	7	1	11	10	9	0.253	0.013	0.84	0.039	0.036	0	52.5	51.2	64.9	153	149	0	31	30
2014	7	1	11	20	9	0.285	0.03	0.837	0.039	0.036	0	52.9	52.9	64.5	154	152	0	31	29
2014	7	1	11	30	9	0.354	0.052	0.837	0.033	0.03	0	52	51.2	65.8	152	149	0	31	30
2014	7	1	11	40	9	0.233	0.072	0.833	0.039	0.036	0	51.6	50.7	65.8	151	148	0	31	30
2014	7	1	11	50	9	0.279	0.141	0.833	0.039	0.036	0	51.6	51.2	66.7	151	149	0	31	30
2014	7	1	12	0	9	0.351	0.082	0.83	0.039	0.039	0	52.5	51.6	65.4	152	149	0	30	29
2014	7	1	12	10	9	0.295	0.003	0.83	0.039	0.036	0	52	50.7	66.2	152	148	0	31	30
2014	7	1	12	20	9	0.285	0.039	0.827	0.039	0.036	0	52	51.6	66.2	151	149	0	30	29
2014	7	1	12	30	9	0.285	0.052	0.827	0.039	0.039	0	52.9	52	65.8	154	150	0	31	29
2014	7	1	12	40	9	0.266	0.112	0.827	0.039	0.036	0	52.5	51.2	67.5	152	149	0	30	30
2014	7	1	12	50	9	0.364	0.072	0.827	0.039	0.036	0	51.2	50.7	67.5	150	148	0	31	30
2014	7	1	13	0	9	0.302	0.092	0.827	0.036	0.033	0	52.5	51.6	68.8	152	149	0	30	29
2014	7	1	13	10	9	0.354	0.141	0.827	0.036	0.033	0	52	51.2	69.2	151	149	0	30	30
2014	7	1	13	20	9	0.374	0.115	0.823	0.039	0.036	0	52.5	51.6	67.5	152	149	0	30	29
2014	7	1	13	30	9	0.404	0.151	0.827	0.046	0.043	0	52.9	51.6	69.2	152	150	0	29	30
2014	7	1	13	40	9	0.322	0.131	0.823	0.046	0.043	0	53.8	52.5	66.2	155	152	0	30	30
2014	7	1	13	50	9	0.328	0.092	0.823	0.039	0.039	0	53.8	52.9	67.5	155	152	0	30	29
2014	7	1	14	0	9	0.407	0.148	0.823	0.036	0.033	0	53.3	52.9	67.5	154	152	0	30	29
2014	7	1	14	10	9	0.279	0.072	0.823	0.039	0.036	0	53.3	52.9	67.1	154	153	0	30	30
2014	7	1	14	20	9	0.292	0.056	0.823	0.039	0.036	0	54.2	52.9	67.9	156	152	0	30	29
2014	7	1	14	30	9	0.364	0.066	0.823	0.039	0.039	0	53.8	52	67.5	155	151	0	30	30
2014	7	1	14	40	9	0.312	0.052	0.823	0.039	0.036	0	52.9	51.6	67.9	153	149	0	30	29
2014	7	1	14	50	9	0.338	0.062	0.823	0.043	0.039	0	51.6	49.9	68.8	150	145	0	30	29
2014	7	1	15	0	9	0.292	0.092	0.823	0.043	0.039	0	52	51.2	70.1	151	148	0	30	29
2014	7	1	15	10	9	0.269	0.112	0.823	0.036	0.033	0	52.9	50.7	68.8	152	147	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	15	20	9	0.276	0.023	0.823	0.036	0.033	0	52.5	51.6	69.2	151	148	0	29	28
2014	7	1	15	30	9	0.302	0.066	0.82	0.039	0.036	0	51.2	49	68.8	149	144	0	30	30
2014	7	1	15	40	9	0.184	0.112	0.823	0.043	0.039	0	50.7	49	70.5	148	143	0	30	29
2014	7	1	15	50	9	0.312	0.056	0.82	0.036	0.033	0	52	50.7	69.2	151	147	0	30	29
2014	7	1	16	0	9	0.24	0.115	0.82	0.039	0.036	0	50.3	49	71	147	143	0	30	29
2014	7	1	16	10	9	0.269	0.072	0.82	0.033	0.03	0	50.7	47.7	71.8	148	141	0	30	30
2014	7	1	16	20	9	0.302	0.026	0.82	0.039	0.036	0	49.5	47.7	71.8	145	141	0	30	30
2014	7	1	16	30	9	0.308	0.039	0.82	0.036	0.033	0	49.9	48.6	71.4	146	142	0	30	29
2014	7	1	16	40	9	0.312	0.072	0.82	0.039	0.039	0	50.7	49.9	71.4	148	145	0	30	29
2014	7	1	16	50	9	0.331	0.112	0.82	0.033	0.03	0	49.9	48.2	71.4	146	141	0	30	29
2014	7	1	17	0	9	0.292	0.056	0.82	0.039	0.039	0	50.7	49.5	70.1	148	144	0	30	29
2014	7	1	17	10	9	0.259	0.052	0.82	0.039	0.039	0	50.7	49.5	70.1	148	144	0	30	29
2014	7	1	17	20	9	0.256	0.056	0.82	0.039	0.036	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	1	17	30	9	0.364	0.092	0.82	0.039	0.039	0	49.5	48.6	71.4	145	142	0	30	29
2014	7	1	17	40	9	0.249	0.089	0.82	0.036	0.033	0	49	48.2	71	144	141	0	30	29
2014	7	1	17	50	9	0.289	0.075	0.817	0.039	0.036	0	49	47.3	71	144	140	0	30	30
2014	7	1	18	0	9	0.272	0.049	0.817	0.039	0.036	0	49.5	47.7	71.8	145	140	0	30	29
2014	7	1	18	10	9	0.24	0.112	0.817	0.039	0.036	0	49.5	46.9	71.8	145	139	0	30	30
2014	7	1	18	20	9	0.233	0.01	0.817	0.043	0.039	0	48.6	46.9	72.2	142	138	0	29	29
2014	7	1	18	30	9	0.266	0.079	0.817	0.039	0.039	0	48.6	47.3	71.8	143	139	0	30	29
2014	7	1	18	40	9	0.223	-0.043	0.817	0.033	0.03	0	50.7	49	70.5	148	143	0	30	29
2014	7	1	18	50	9	0.262	-0.016	0.817	0.039	0.036	0	49.5	48.2	71	145	141	0	30	29
2014	7	1	19	0	9	0.325	0.016	0.817	0.043	0.039	0	51.6	49.9	69.7	150	145	0	30	29
2014	7	1	19	10	9	0.243	0.036	0.817	0.046	0.043	0	50.7	49.5	70.5	148	144	0	30	29
2014	7	1	19	20	9	0.23	-0.03	0.817	0.036	0.033	0	51.6	49.9	69.7	150	146	0	30	30
2014	7	1	19	30	9	0.249	0.092	0.817	0.043	0.039	0	52.5	50.3	68.8	153	147	0	31	30
2014	7	1	19	40	9	0.269	0.069	0.817	0.039	0.036	0	51.2	49.9	70.1	150	145	0	31	29
2014	7	1	19	50	9	0.217	-0.016	0.817	0.036	0.033	0	50.3	49	71	147	143	0	30	29
2014	7	1	20	0	9	0.23	0.03	0.817	0.033	0.03	0	50.3	48.6	71	147	142	0	30	29
2014	7	1	20	10	9	0.243	-0.046	0.82	0.036	0.033	0	50.3	49	70.5	147	143	0	30	29
2014	7	1	20	20	9	0.24	0.003	0.817	0.033	0.03	0	52.5	50.3	69.7	151	147	0	29	30
2014	7	1	20	30	9	0.236	-0.023	0.82	0.043	0.039	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	1	20	40	9	0.187	-0.02	0.817	0.039	0.039	0	51.6	49.9	70.1	150	146	0	30	30
2014	7	1	20	50	9	0.213	0.007	0.82	0.033	0.03	0	51.6	50.3	69.7	150	146	0	30	29
2014	7	1	21	0	9	0.259	0.036	0.817	0.039	0.036	0	52.5	51.2	68.8	152	148	0	30	29
2014	7	1	21	10	9	0.285	-0.056	0.817	0.039	0.036	0	52	49.9	69.7	151	146	0	30	30
2014	7	1	21	20	9	0.203	0.013	0.82	0.039	0.036	0	51.6	49.5	69.2	151	145	0	31	30
2014	7	1	21	30	9	0.289	-0.056	0.82	0.039	0.036	0	51.2	49	70.1	149	144	0	30	30
2014	7	1	21	40	9	0.19	0.023	0.82	0.039	0.036	0	51.6	49.5	70.1	150	145	0	30	30
2014	7	1	21	50	9	0.226	0.02	0.82	0.036	0.033	0	51.2	49.5	70.5	149	145	0	30	30
2014	7	1	22	0	9	0.24	0.036	0.82	0.036	0.033	0	51.6	50.3	69.2	151	146	0	31	29
2014	7	1	22	10	9	0.226	-0.036	0.82	0.043	0.039	0	50.7	49	70.1	148	144	0	30	30
2014	7	1	22	20	9	0.249	0.003	0.82	0.033	0.03	0	50.7	49	70.1	148	143	0	30	29
2014	7	1	22	30	9	0.23	-0.013	0.82	0.043	0.039	0	51.2	49.5	70.5	149	144	0	30	29
2014	7	1	22	40	9	0.167	-0.007	0.82	0.036	0.033	0	50.7	49	71	148	143	0	30	29
2014	7	1	22	50	9	0.282	0.026	0.82	0.039	0.039	0	52.5	51.2	69.2	153	148	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	23	0	9	0.253	0.016	0.82	0.043	0.039	0	50.7	49.9	69.7	149	145	0	31	29
2014	7	1	23	10	9	0.197	-0.007	0.82	0.036	0.033	0	52	50.7	69.2	151	147	0	30	29
2014	7	1	23	20	9	0.203	0.056	0.82	0.036	0.033	0	51.6	49.9	70.1	150	146	0	30	30
2014	7	1	23	30	9	0.19	0.118	0.82	0.036	0.033	0	51.2	49.5	70.5	149	145	0	30	30
2014	7	1	23	40	9	0.269	0.016	0.82	0.039	0.036	0	50.7	48.6	69.7	148	143	0	30	30
2014	7	1	23	50	9	0.233	0.092	0.82	0.033	0.03	0	49.9	48.6	70.5	146	143	0	30	30
2014	7	2	0	0	9	0.207	-0.052	0.823	0.039	0.036	0	49.9	49	70.1	146	143	0	30	29
2014	7	2	0	10	9	0.2	0.043	0.823	0.033	0.03	0	49.5	47.7	71	145	141	0	30	30
2014	7	2	0	20	9	0.299	0.082	0.823	0.036	0.033	0	49	48.2	71	144	142	0	30	30
2014	7	2	0	30	9	0.226	0.056	0.823	0.036	0.033	0	49	48.2	71.8	144	141	0	30	29
2014	7	2	0	40	9	0.217	-0.049	0.823	0.039	0.039	0	48.6	47.7	71	143	141	0	30	30
2014	7	2	0	50	9	0.256	-0.01	0.823	0.033	0.03	0	49.5	47.7	70.5	145	141	0	30	30
2014	7	2	1	0	9	0.308	0.013	0.823	0.039	0.036	0	49	47.7	70.5	144	140	0	30	29
2014	7	2	1	10	9	0.318	-0.013	0.823	0.039	0.036	0	49	47.7	70.5	144	141	0	30	30
2014	7	2	1	20	9	0.305	-0.016	0.823	0.039	0.039	0	48.6	47.3	71	143	140	0	30	30
2014	7	2	1	30	9	0.24	0.023	0.823	0.039	0.036	0	49	47.7	70.5	145	141	0	31	30
2014	7	2	1	40	9	0.243	0.026	0.823	0.039	0.036	0	49	47.3	69.7	144	140	0	30	30
2014	7	2	1	50	9	0.213	0	0.823	0.036	0.033	0	49	48.2	71	144	141	0	30	29
2014	7	2	2	0	9	0.23	-0.02	0.823	0.039	0.036	0	49	48.2	71	144	141	0	30	29
2014	7	2	2	10	9	0.23	0.016	0.823	0.039	0.036	0	48.6	47.3	70.5	143	140	0	30	30
2014	7	2	2	20	9	0.262	0.007	0.823	0.039	0.036	0	49	47.3	71.4	144	140	0	30	30
2014	7	2	2	30	9	0.24	-0.069	0.823	0.036	0.033	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	2	2	40	9	0.367	0.049	0.823	0.036	0.033	0	48.6	48.2	69.7	143	141	0	30	29
2014	7	2	2	50	9	0.223	0.026	0.823	0.036	0.033	0	48.6	47.3	70.1	144	140	0	31	30
2014	7	2	3	0	9	0.328	-0.01	0.823	0.043	0.039	0	48.6	47.7	69.7	143	140	0	30	29
2014	7	2	3	10	9	0.21	0.02	0.827	0.039	0.036	0	48.2	47.7	69.7	143	141	0	31	30
2014	7	2	3	20	9	0.24	0.007	0.827	0.049	0.046	0	48.6	47.3	69.2	144	140	0	31	30
2014	7	2	3	30	9	0.194	0.036	0.827	0.039	0.036	0	48.6	48.2	69.2	144	141	0	31	29
2014	7	2	3	40	9	0.318	0.039	0.827	0.039	0.036	0	49	48.2	68.8	145	141	0	31	29
2014	7	2	3	50	9	0.24	-0.052	0.827	0.039	0.039	0	48.6	48.2	68.4	144	142	0	31	30
2014	7	2	4	0	9	0.246	-0.023	0.823	0.036	0.033	0	50.3	48.6	67.5	148	143	0	31	30
2014	7	2	4	10	9	0.279	0.112	0.827	0.039	0.036	0	50.3	49.5	68.4	147	145	0	30	30
2014	7	2	4	20	9	0.249	-0.003	0.827	0.043	0.039	0	50.7	49.5	67.9	148	145	0	30	30
2014	7	2	4	30	9	0.302	0.013	0.827	0.039	0.036	0	49.5	49.5	67.5	146	144	0	31	29
2014	7	2	4	40	9	0.236	-0.003	0.827	0.036	0.033	0	49.9	48.6	67.9	147	143	0	31	30
2014	7	2	4	50	9	0.256	-0.043	0.827	0.036	0.033	0	50.3	48.6	67.9	147	143	0	30	30
2014	7	2	5	0	9	0.358	0.03	0.827	0.043	0.039	0	49.5	48.6	67.9	146	143	0	31	30
2014	7	2	5	10	9	0.253	0.046	0.827	0.039	0.039	0	50.3	49	67.1	147	143	0	30	29
2014	7	2	5	20	9	0.249	-0.016	0.83	0.043	0.039	0	49.9	48.6	66.7	147	142	0	31	29
2014	7	2	5	30	9	0.262	-0.023	0.83	0.033	0.03	0	50.3	48.6	67.1	148	143	0	31	30
2014	7	2	5	40	9	0.262	-0.02	0.83	0.039	0.039	0	49.9	48.2	67.1	147	143	0	31	31
2014	7	2	5	50	9	0.285	0.052	0.83	0.033	0.03	0	50.3	48.6	66.2	147	144	0	30	31
2014	7	2	6	0	9	0.289	0.059	0.83	0.039	0.036	0	50.7	49.9	65.4	149	145	0	31	29
2014	7	2	6	10	9	0.266	0.033	0.83	0.036	0.033	0	51.2	49.9	65.8	150	146	0	31	30
2014	7	2	6	20	9	0.285	0.062	0.83	0.039	0.036	0	50.3	49	66.2	148	144	0	31	30
2014	7	2	6	30	9	0.302	0.033	0.833	0.043	0.039	0	49.5	48.6	66.7	146	143	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	6	40	9	0.171	-0.02	0.833	0.039	0.036	0	50.3	49.5	65.8	148	145	0	31	30
2014	7	2	6	50	9	0.289	0	0.833	0.046	0.043	0	49.5	48.6	66.7	147	143	0	32	30
2014	7	2	7	0	9	0.233	0.013	0.833	0.039	0.036	0	50.3	48.6	67.1	148	143	0	31	30
2014	7	2	7	10	9	0.285	0.052	0.833	0.039	0.036	0	49	48.2	67.9	145	142	0	31	30
2014	7	2	7	20	9	0.308	-0.02	0.833	0.036	0.033	0	50.3	49	67.1	148	144	0	31	30
2014	7	2	7	30	9	0.299	-0.092	0.833	0.039	0.036	0	50.3	49	66.7	148	145	0	31	31
2014	7	2	7	40	9	0.305	0.075	0.837	0.036	0.033	0	49	48.6	67.5	145	143	0	31	30
2014	7	2	7	50	9	0.213	-0.023	0.837	0.039	0.039	0	50.7	49.5	66.7	149	145	0	31	30
2014	7	2	8	0	9	0.223	0.033	0.837	0.043	0.039	0	49.5	48.2	67.5	146	143	0	31	31
2014	7	2	8	10	9	0.305	0.033	0.837	0.036	0.033	0	50.7	49.5	66.7	149	145	0	31	30
2014	7	2	8	20	9	0.292	-0.01	0.837	0.039	0.036	0	50.7	49.9	66.7	149	146	0	31	30
2014	7	2	8	30	9	0.276	0.003	0.837	0.039	0.039	0	50.7	49.5	67.1	149	145	0	31	30
2014	7	2	8	40	9	0.292	0	0.833	0.039	0.039	0	50.7	49.9	65.8	149	146	0	31	30
2014	7	2	8	50	9	0.233	-0.03	0.837	0.036	0.033	0	50.3	49	67.1	148	144	0	31	30
2014	7	2	9	0	9	0.279	0	0.833	0.039	0.036	0	49	48.6	67.5	145	143	0	31	30
2014	7	2	9	10	9	0.299	0.01	0.833	0.039	0.039	0	50.3	49	67.1	148	144	0	31	30
2014	7	2	9	20	9	0.272	0.049	0.833	0.043	0.039	0	50.3	49	66.2	148	144	0	31	30
2014	7	2	9	30	9	0.282	0.01	0.84	0.043	0.039	0	50.7	48.6	63.6	148	144	0	30	31
2014	7	2	9	40	9	0.233	-0.036	0.84	0.036	0.033	0	51.2	50.3	63.2	150	147	0	31	30
2014	7	2	9	50	9	0.331	0.02	0.843	0.039	0.036	0	51.2	50.7	66.7	150	148	0	31	30
2014	7	2	10	0	9	0.344	0.026	0.84	0.039	0.039	0	52	50.7	66.7	152	148	0	31	30
2014	7	2	10	10	9	0.279	0.013	0.843	0.033	0.03	0	49	47.7	69.7	145	141	0	31	30
2014	7	2	10	20	9	0.289	0.108	0.84	0.039	0.036	0	48.2	46.9	70.5	143	139	0	31	30
2014	7	2	10	30	9	0.246	0.069	0.84	0.039	0.036	0	47.7	46.9	70.5	142	139	0	31	30
2014	7	2	10	40	9	0.207	0.016	0.837	0.039	0.039	0	48.6	47.3	70.5	143	140	0	30	30
2014	7	2	10	50	9	0.322	0.069	0.837	0.039	0.039	0	49	48.2	70.1	144	142	0	30	30
2014	7	2	11	0	9	0.243	0.082	0.833	0.039	0.036	0	48.2	47.3	69.7	143	140	0	31	30
2014	7	2	11	10	9	0.266	0.033	0.833	0.039	0.036	0	48.6	48.6	68.8	144	143	0	31	30
2014	7	2	11	20	9	0.249	0.02	0.83	0.033	0.03	0	49.5	49	68.4	147	144	0	32	30
2014	7	2	11	30	9	0.295	0.036	0.83	0.036	0.033	0	50.7	49.9	68.8	148	145	0	30	29
2014	7	2	11	40	9	0.279	0	0.83	0.036	0.033	0	49.9	49.5	68.8	147	144	0	31	29
2014	7	2	11	50	9	0.269	0.072	0.83	0.033	0.03	0	49	47.7	71	145	141	0	31	30
2014	7	2	12	0	9	0.325	0.013	0.827	0.03	0.03	0	50.3	49	70.5	147	143	0	30	29
2014	7	2	12	10	9	0.282	0.066	0.827	0.036	0.033	0	49.9	49	70.1	146	144	0	30	30
2014	7	2	12	20	9	0.289	0.003	0.827	0.039	0.036	0	50.7	49	69.7	148	144	0	30	30
2014	7	2	12	30	9	0.276	0.052	0.823	0.039	0.036	0	50.7	49.9	70.5	148	146	0	30	30
2014	7	2	12	40	9	0.354	0.026	0.823	0.036	0.033	0	51.6	49.5	69.7	150	145	0	30	30
2014	7	2	12	50	9	0.302	0.066	0.823	0.033	0.03	0	51.6	50.7	69.2	151	148	0	31	30
2014	7	2	13	0	9	0.348	0.036	0.823	0.049	0.046	0	51.2	50.3	70.1	149	147	0	30	30
2014	7	2	13	10	9	0.285	0.039	0.823	0.039	0.036	0	51.2	50.3	71.4	150	147	0	31	30
2014	7	2	13	20	9	0.266	0.01	0.823	0.039	0.036	0	51.2	49.9	70.1	149	146	0	30	30
2014	7	2	13	30	9	0.295	0.092	0.823	0.033	0.03	0	52	50.3	70.5	151	147	0	30	30
2014	7	2	13	40	9	0.315	0.072	0.823	0.033	0.03	0	52	51.2	70.1	151	148	0	30	29
2014	7	2	13	50	9	0.213	0.036	0.823	0.033	0.03	0	52.5	51.2	69.7	152	149	0	30	30
2014	7	2	14	0	9	0.302	0.098	0.823	0.033	0.03	0	51.6	50.3	70.5	150	147	0	30	30
2014	7	2	14	10	9	0.299	0.085	0.823	0.036	0.033	0	52	51.2	71.8	151	148	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	14	20	9	0.279	0.144	0.823	0.036	0.033	0	52	51.2	72.7	151	148	0	30	29
2014	7	2	14	30	9	0.226	0.108	0.82	0.036	0.033	0	52	51.2	72.2	151	148	0	30	29
2014	7	2	14	40	9	0.331	0.125	0.82	0.039	0.039	0	52.5	52	71.4	152	150	0	30	29
2014	7	2	14	50	9	0.295	0.089	0.82	0.036	0.033	0	52.5	50.7	71	152	147	0	30	29
2014	7	2	15	0	9	0.312	0.102	0.82	0.039	0.039	0	51.6	50.3	71.8	150	147	0	30	30
2014	7	2	15	10	9	0.285	0.144	0.82	0.033	0.03	0	53.8	52	71	154	150	0	29	29
2014	7	2	15	20	9	0.381	0.144	0.82	0.043	0.039	0	50.7	49.9	72.2	148	145	0	30	29
2014	7	2	15	30	9	0.341	0.121	0.82	0.033	0.03	0	53.3	51.6	70.5	153	149	0	29	29
2014	7	2	15	40	9	0.328	0.085	0.82	0.043	0.039	0	52.5	51.6	70.1	152	149	0	30	29
2014	7	2	15	50	9	0.335	0.105	0.82	0.036	0.033	0	51.6	51.2	69.2	150	147	0	30	28
2014	7	2	16	0	9	0.328	0.108	0.82	0.036	0.033	0	53.3	52	69.7	154	151	0	30	30
2014	7	2	16	10	9	0.295	0.121	0.817	0.033	0.03	0	53.3	52	69.2	153	149	0	29	28
2014	7	2	16	20	9	0.259	0.164	0.82	0.039	0.036	0	51.6	50.7	68.4	150	147	0	30	29
2014	7	2	16	30	9	0.305	0.095	0.817	0.036	0.033	0	52	49.9	70.1	150	145	0	29	29
2014	7	2	16	40	9	0.276	0.105	0.817	0.039	0.036	0	51.6	50.7	69.2	150	147	0	30	29
2014	7	2	16	50	9	0.397	0.072	0.817	0.036	0.033	0	51.6	50.3	69.2	149	146	0	29	29
2014	7	2	17	0	9	0.279	0.033	0.817	0.033	0.03	0	51.2	49.9	70.1	148	144	0	29	28
2014	7	2	17	10	9	0.256	0.075	0.817	0.033	0.03	0	53.3	50.7	68.4	153	147	0	29	29
2014	7	2	17	20	9	0.315	0.085	0.817	0.033	0.03	0	52.5	50.7	68.8	152	147	0	30	29
2014	7	2	17	30	9	0.256	0.056	0.817	0.039	0.036	0	51.6	49.9	69.7	149	145	0	29	29
2014	7	2	17	40	9	0.305	0.03	0.817	0.039	0.036	0	51.6	49.9	69.2	150	146	0	30	30
2014	7	2	17	50	9	0.331	0.072	0.817	0.033	0.03	0	52.9	50.7	67.9	153	147	0	30	29
2014	7	2	18	0	9	0.308	-0.043	0.817	0.043	0.039	0	52.9	50.7	67.1	152	147	0	29	29
2014	7	2	18	10	9	0.262	0.043	0.814	0.033	0.03	0	53.3	51.6	67.1	153	148	0	29	28
2014	7	2	18	20	9	0.279	0.059	0.814	0.033	0.03	0	52.9	51.2	67.1	152	148	0	29	29
2014	7	2	18	30	9	0.285	0.026	0.814	0.039	0.039	0	52.5	50.7	67.1	151	147	0	29	29
2014	7	2	18	40	9	0.295	-0.01	0.814	0.039	0.039	0	52.9	51.2	66.2	153	148	0	30	29
2014	7	2	18	50	9	0.285	-0.039	0.814	0.039	0.036	0	52	49.9	67.1	151	146	0	30	30
2014	7	2	19	0	9	0.318	0.016	0.814	0.039	0.039	0	53.3	51.6	64.9	154	149	0	30	29
2014	7	2	19	10	9	0.233	0.066	0.814	0.039	0.036	0	53.3	51.2	66.2	154	148	0	30	29
2014	7	2	19	20	9	0.292	0.016	0.814	0.039	0.039	0	53.3	51.6	66.2	154	149	0	30	29
2014	7	2	19	30	9	0.262	0.049	0.814	0.039	0.036	0	52.5	50.3	66.7	151	146	0	29	29
2014	7	2	19	40	9	0.18	0.171	0.814	0.043	0.039	0	52.5	49.9	67.5	152	145	0	30	29
2014	7	2	19	50	9	0.223	0.105	0.814	0.039	0.036	0	51.6	49	68.4	149	143	0	29	29
2014	7	2	20	0	9	0.292	-0.016	0.814	0.039	0.036	0	52.9	50.3	67.1	152	146	0	29	29
2014	7	2	20	10	9	0.213	0	0.814	0.039	0.036	0	51.6	49.5	68.4	150	144	0	30	29
2014	7	2	20	20	9	0.272	0.046	0.814	0.039	0.036	0	51.6	49.9	69.2	150	145	0	30	29
2014	7	2	20	30	9	0.233	0	0.814	0.033	0.03	0	51.6	49.9	68.4	150	145	0	30	29
2014	7	2	20	40	9	0.223	0	0.814	0.036	0.033	0	51.6	49.9	68.4	150	145	0	30	29
2014	7	2	20	50	9	0.295	-0.043	0.814	0.043	0.039	0	52.9	50.7	67.1	153	147	0	30	29
2014	7	2	21	0	9	0.328	0	0.817	0.039	0.039	0	52	50.3	67.5	151	146	0	30	29
2014	7	2	21	10	9	0.197	-0.03	0.817	0.036	0.033	0	51.2	49.9	68.8	149	145	0	30	29
2014	7	2	21	20	9	0.217	-0.066	0.817	0.039	0.039	0	50.3	49	70.5	147	143	0	30	29
2014	7	2	21	30	9	0.223	0.016	0.817	0.046	0.043	0	51.2	49.9	69.7	149	145	0	30	29
2014	7	2	21	40	9	0.246	-0.01	0.817	0.043	0.039	0	50.3	49	70.5	147	143	0	30	29
2014	7	2	21	50	9	0.23	0.052	0.817	0.039	0.036	0	50.3	48.6	70.5	147	143	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	22	0	9	0.276	0.079	0.817	0.039	0.039	0	49.9	48.2	71.4	146	142	0	30	30
2014	7	2	22	10	9	0.217	0	0.817	0.033	0.03	0	50.3	48.2	71	147	142	0	30	30
2014	7	2	22	20	9	0.167	-0.02	0.817	0.039	0.036	0	49.9	48.6	71	146	142	0	30	29
2014	7	2	22	30	9	0.24	0.02	0.817	0.036	0.033	0	49.9	48.6	71.8	146	142	0	30	29
2014	7	2	22	40	9	0.236	0.03	0.817	0.039	0.036	0	49.5	47.7	71.8	145	140	0	30	29
2014	7	2	22	50	9	0.22	0.046	0.817	0.039	0.036	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	2	23	0	9	0.259	-0.007	0.817	0.036	0.033	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	2	23	10	9	0.203	0.013	0.82	0.039	0.036	0	49.5	47.7	72.2	145	141	0	30	30
2014	7	2	23	20	9	0.233	0.059	0.82	0.039	0.036	0	48.2	46.9	73.1	142	138	0	30	29
2014	7	2	23	30	9	0.233	-0.01	0.82	0.039	0.036	0	47.7	46.9	73.5	142	139	0	31	30
2014	7	2	23	40	9	0.253	-0.03	0.82	0.039	0.036	0	48.6	47.3	73.5	143	139	0	30	29
2014	7	2	23	50	9	0.262	0	0.82	0.033	0.03	0	48.6	47.3	73.5	143	139	0	30	29
2014	7	3	0	0	9	0.226	-0.003	0.82	0.036	0.033	0	48.6	47.7	73.1	143	140	0	30	29
2014	7	3	0	10	9	0.262	0.007	0.82	0.043	0.039	0	48.6	47.3	73.1	143	139	0	30	29
2014	7	3	0	20	9	0.243	-0.02	0.82	0.043	0.039	0	48.2	46.9	72.7	142	139	0	30	30
2014	7	3	0	30	9	0.233	0.003	0.82	0.039	0.039	0	48.2	47.3	72.7	143	140	0	31	30
2014	7	3	0	40	9	0.299	0	0.82	0.039	0.036	0	48.6	46.9	72.7	143	139	0	30	30
2014	7	3	0	50	9	0.256	-0.016	0.82	0.039	0.036	0	49	47.7	72.7	144	141	0	30	30
2014	7	3	1	0	9	0.246	0.039	0.82	0.036	0.033	0	48.6	47.3	72.7	143	139	0	30	29
2014	7	3	1	10	9	0.243	0.049	0.82	0.039	0.036	0	48.2	48.2	72.2	142	141	0	30	29
2014	7	3	1	20	9	0.19	-0.007	0.82	0.039	0.039	0	48.6	47.7	72.2	143	141	0	30	30
2014	7	3	1	30	9	0.276	0.016	0.82	0.036	0.033	0	48.6	47.7	72.7	143	141	0	30	30
2014	7	3	1	40	9	0.217	0.01	0.82	0.039	0.039	0	48.2	47.3	72.7	143	140	0	31	30
2014	7	3	1	50	9	0.203	0.052	0.82	0.036	0.033	0	48.6	48.2	72.2	143	141	0	30	29
2014	7	3	2	0	9	0.207	0.072	0.82	0.033	0.03	0	48.6	47.3	71.8	143	139	0	30	29
2014	7	3	2	10	9	0.295	0.033	0.82	0.049	0.049	0	48.2	47.3	72.7	142	140	0	30	30
2014	7	3	2	20	9	0.22	-0.039	0.82	0.039	0.039	0	48.6	47.3	71.8	144	140	0	31	30
2014	7	3	2	30	9	0.2	0.036	0.82	0.036	0.033	0	48.2	47.7	71.8	142	140	0	30	29
2014	7	3	2	40	9	0.23	0	0.82	0.036	0.033	0	48.6	47.3	71.4	144	140	0	31	30
2014	7	3	2	50	9	0.266	0.082	0.82	0.033	0.03	0	48.2	47.3	71.8	143	140	0	31	30
2014	7	3	3	0	9	0.243	-0.01	0.82	0.036	0.033	0	49	48.2	71.4	144	141	0	30	29
2014	7	3	3	10	9	0.24	-0.013	0.82	0.039	0.036	0	48.6	46.9	71.4	144	139	0	31	30
2014	7	3	3	20	9	0.243	0.02	0.82	0.043	0.043	0	49.5	47.7	70.5	145	140	0	30	29
2014	7	3	3	30	9	0.259	0.01	0.82	0.039	0.036	0	50.3	49.5	71	148	145	0	31	30
2014	7	3	3	40	9	0.305	-0.049	0.82	0.033	0.03	0	49.9	49	69.7	147	144	0	31	30
2014	7	3	3	50	9	0.289	0.033	0.82	0.043	0.039	0	49.5	48.6	70.5	146	143	0	31	30
2014	7	3	4	0	9	0.308	0.052	0.82	0.039	0.036	0	50.3	49	70.1	148	144	0	31	30
2014	7	3	4	10	9	0.299	-0.026	0.82	0.039	0.039	0	50.3	49.5	70.1	147	144	0	30	29
2014	7	3	4	20	9	0.279	0.049	0.82	0.036	0.033	0	49.9	49.5	70.1	146	144	0	30	29
2014	7	3	4	30	9	0.262	0.007	0.82	0.039	0.036	0	49.5	48.6	70.1	146	143	0	31	30
2014	7	3	4	40	9	0.341	0.033	0.82	0.039	0.039	0	49.9	49	70.5	146	143	0	30	29
2014	7	3	4	50	9	0.266	0.02	0.82	0.036	0.033	0	49.5	48.6	70.1	146	143	0	31	30
2014	7	3	5	0	9	0.318	0.023	0.82	0.039	0.036	0	49.5	48.6	70.5	145	143	0	30	30
2014	7	3	5	10	9	0.246	-0.023	0.82	0.033	0.03	0	49.5	48.2	70.5	145	142	0	30	30
2014	7	3	5	20	9	0.308	0.033	0.82	0.039	0.036	0	51.2	49.9	68.4	150	146	0	31	30
2014	7	3	5	30	9	0.217	-0.02	0.82	0.039	0.036	0	50.3	49.5	68.8	148	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	5	40	9	0.262	-0.023	0.82	0.033	0.03	0	51.6	49.9	68.8	150	146	0	30	30
2014	7	3	5	50	9	0.2	0	0.82	0.039	0.036	0	49.9	49	68.8	147	144	0	31	30
2014	7	3	6	0	9	0.23	-0.03	0.82	0.036	0.033	0	50.3	48.6	68.4	148	143	0	31	30
2014	7	3	6	10	9	0.2	0.007	0.82	0.036	0.033	0	50.7	49.5	68.4	149	145	0	31	30
2014	7	3	6	20	9	0.308	0.039	0.82	0.039	0.036	0	48.6	47.7	70.1	145	141	0	32	30
2014	7	3	6	30	9	0.233	-0.036	0.82	0.039	0.036	0	49.5	48.6	68.8	146	143	0	31	30
2014	7	3	6	40	9	0.249	0.016	0.82	0.036	0.033	0	49.5	48.6	68.8	146	143	0	31	30
2014	7	3	6	50	9	0.276	0.016	0.82	0.049	0.046	0	49.5	48.2	68.8	146	142	0	31	30
2014	7	3	7	0	9	0.276	0.003	0.82	0.049	0.046	0	49.5	48.2	69.7	146	142	0	31	30
2014	7	3	7	10	9	0.282	-0.072	0.82	0.039	0.036	0	52	50.7	67.5	151	148	0	30	30
2014	7	3	7	20	9	0.22	-0.033	0.82	0.043	0.043	0	49.5	48.6	68.8	146	143	0	31	30
2014	7	3	7	30	9	0.233	-0.072	0.82	0.039	0.036	0	50.3	49	68.8	148	144	0	31	30
2014	7	3	7	40	9	0.302	-0.036	0.82	0.039	0.036	0	48.2	47.3	71	143	140	0	31	30
2014	7	3	7	50	9	0.292	0.036	0.82	0.039	0.039	0	48.6	48.2	70.1	144	142	0	31	30
2014	7	3	8	0	9	0.289	0.036	0.82	0.036	0.033	0	49	48.2	70.1	145	142	0	31	30
2014	7	3	8	10	9	0.18	-0.01	0.82	0.039	0.036	0	49.9	49	68.8	147	144	0	31	30
2014	7	3	8	20	9	0.312	-0.036	0.82	0.039	0.036	0	51.2	49.9	68.4	150	146	0	31	30
2014	7	3	8	30	9	0.253	0.039	0.82	0.039	0.036	0	49.5	48.2	69.2	146	142	0	31	30
2014	7	3	8	40	9	0.325	0.007	0.82	0.036	0.033	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	3	8	50	9	0.272	0.049	0.82	0.039	0.036	0	48.6	46.9	70.5	143	139	0	30	30
2014	7	3	9	0	9	0.249	0.01	0.82	0.039	0.039	0	48.6	47.7	71.4	144	141	0	31	30
2014	7	3	9	10	9	0.217	0.085	0.82	0.043	0.039	0	49	47.7	70.1	145	141	0	31	30
2014	7	3	9	20	9	0.292	0.092	0.82	0.039	0.039	0	48.6	47.3	70.5	144	140	0	31	30
2014	7	3	9	30	9	0.22	0.003	0.82	0.039	0.036	0	47.3	46.4	71.8	140	138	0	30	30
2014	7	3	9	40	9	0.256	0	0.82	0.039	0.036	0	47.3	46	72.2	141	137	0	31	30
2014	7	3	9	50	9	0.197	-0.013	0.82	0.036	0.033	0	48.2	47.3	71.8	143	140	0	31	30
2014	7	3	10	0	9	0.177	0.052	0.82	0.039	0.039	0	48.6	47.7	71	144	141	0	31	30
2014	7	3	10	10	9	0.269	-0.039	0.82	0.046	0.046	0	48.6	48.2	71	144	141	0	31	29
2014	7	3	10	20	9	0.285	0.046	0.82	0.049	0.046	0	47.3	46.4	72.7	141	138	0	31	30
2014	7	3	10	30	9	0.22	0.03	0.82	0.039	0.036	0	48.2	47.3	71.8	142	140	0	30	30
2014	7	3	10	40	9	0.305	-0.036	0.82	0.043	0.039	0	49.5	48.2	71.4	146	142	0	31	30
2014	7	3	10	50	9	0.292	0.03	0.82	0.043	0.039	0	49.5	48.2	71.4	146	142	0	31	30
2014	7	3	11	0	9	0.335	0.013	0.82	0.039	0.036	0	49	48.2	71.4	145	142	0	31	30
2014	7	3	11	10	9	0.285	0.016	0.82	0.036	0.033	0	49	49	71	144	143	0	30	29
2014	7	3	11	20	9	0.276	0.066	0.817	0.043	0.039	0	50.3	49	70.1	147	144	0	30	30
2014	7	3	11	30	9	0.312	0.003	0.82	0.039	0.036	0	49.5	48.2	71	146	142	0	31	30
2014	7	3	11	40	9	0.322	0.036	0.817	0.039	0.039	0	51.2	49.9	70.1	150	146	0	31	30
2014	7	3	11	50	9	0.318	0.082	0.817	0.036	0.033	0	49.9	49	71.8	146	143	0	30	29
2014	7	3	12	0	9	0.243	0.039	0.817	0.039	0.036	0	52.9	52	68.8	154	151	0	31	30
2014	7	3	12	10	9	0.341	0.036	0.817	0.033	0.03	0	51.6	49.9	69.7	150	146	0	30	30
2014	7	3	12	20	9	0.269	0.085	0.817	0.039	0.036	0	49.9	49.5	71	147	144	0	31	29
2014	7	3	12	30	9	0.282	0.043	0.817	0.033	0.03	0	48.2	48.2	72.7	144	142	0	32	30
2014	7	3	12	40	9	0.338	0.066	0.817	0.036	0.033	0	48.2	47.3	72.7	142	140	0	30	30
2014	7	3	12	50	9	0.259	0.03	0.817	0.033	0.03	0	47.7	47.7	73.5	142	141	0	31	30
2014	7	3	13	0	9	0.315	0.069	0.817	0.039	0.039	0	49	48.6	72.7	144	142	0	30	29
2014	7	3	13	10	9	0.262	0.066	0.817	0.036	0.033	0	49.9	48.6	71	146	143	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	13	20	9	0.282	0.016	0.814	0.039	0.036	0	50.3	50.3	70.5	148	146	0	31	29
2014	7	3	13	30	9	0.23	0.02	0.814	0.033	0.03	0	49.9	49	71	146	144	0	30	30
2014	7	3	13	40	9	0.358	0.059	0.817	0.039	0.036	0	49.5	48.2	71	145	142	0	30	30
2014	7	3	13	50	9	0.262	0.049	0.814	0.036	0.033	0	49.5	49	71	145	143	0	30	29
2014	7	3	14	0	9	0.276	0.036	0.814	0.036	0.033	0	49.9	48.2	70.1	146	142	0	30	30
2014	7	3	14	10	9	0.289	0.115	0.814	0.036	0.033	0	49.9	49	71.4	146	143	0	30	29
2014	7	3	14	20	9	0.331	0.164	0.814	0.039	0.039	0	49.5	48.2	70.1	146	141	0	31	29
2014	7	3	14	30	9	0.344	0.062	0.81	0.039	0.036	0	49.5	49	70.5	145	143	0	30	29
2014	7	3	14	40	9	0.197	0.069	0.81	0.033	0.03	0	49.9	49	69.7	146	143	0	30	29
2014	7	3	14	50	9	0.272	0.052	0.81	0.039	0.036	0	50.7	49.9	67.9	148	145	0	30	29
2014	7	3	15	0	9	0.302	0.066	0.807	0.039	0.036	0	50.3	50.3	68.8	147	146	0	30	29
2014	7	3	15	10	9	0.295	0.082	0.807	0.033	0.03	0	50.7	50.3	68.4	148	146	0	30	29
2014	7	3	15	20	9	0.335	0.062	0.804	0.039	0.039	0	50.3	49.5	68.4	147	144	0	30	29
2014	7	3	15	30	9	0.223	0.072	0.804	0.036	0.033	0	50.7	49.9	67.5	147	145	0	29	29
2014	7	3	15	40	9	0.322	0.036	0.801	0.033	0.03	0	50.7	49	67.9	148	143	0	30	29
2014	7	3	15	50	9	0.256	0.154	0.801	0.033	0.03	0	50.7	49.9	68.8	148	145	0	30	29
2014	7	3	16	0	9	0.289	0.069	0.797	0.039	0.039	0	49.5	49.9	67.9	146	145	0	31	29
2014	7	3	16	10	9	0.223	0.079	0.797	0.039	0.036	0	50.3	49.9	67.1	147	145	0	30	29
2014	7	3	16	20	9	0.184	0.072	0.794	0.039	0.036	0	50.3	49.5	69.2	147	144	0	30	29
2014	7	3	16	30	9	0.322	0.075	0.794	0.033	0.03	0	51.2	49.5	69.2	148	144	0	29	29
2014	7	3	16	40	9	0.266	0.092	0.794	0.039	0.039	0	50.3	49	69.2	146	143	0	29	29
2014	7	3	16	50	9	0.23	0.157	0.794	0.039	0.036	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	3	17	0	9	0.276	0	0.794	0.039	0.036	0	50.3	49.5	69.7	146	143	0	29	28
2014	7	3	17	10	9	0.24	0.01	0.794	0.036	0.033	0	49.9	49	68.8	146	143	0	30	29
2014	7	3	17	20	9	0.213	0.056	0.794	0.036	0.033	0	51.6	49	68.8	149	143	0	29	29
2014	7	3	17	30	9	0.295	0.049	0.794	0.039	0.036	0	51.2	49.5	68.4	148	144	0	29	29
2014	7	3	17	40	9	0.312	0.052	0.791	0.039	0.039	0	51.6	49.9	68.4	149	145	0	29	29
2014	7	3	17	50	9	0.194	0.167	0.791	0.043	0.039	0	50.7	49	68.8	148	143	0	30	29
2014	7	3	18	0	9	0.236	0	0.791	0.043	0.039	0	50.7	49.5	68.8	148	143	0	30	28
2014	7	3	18	10	9	0.184	0.016	0.791	0.046	0.043	0	52.9	51.2	66.7	153	148	0	30	29
2014	7	3	18	20	9	0.282	0.023	0.791	0.039	0.039	0	52.9	50.7	66.7	153	147	0	30	29
2014	7	3	18	30	9	0.253	0.043	0.791	0.039	0.039	0	52.9	51.2	66.7	152	148	0	29	29
2014	7	3	18	40	9	0.194	0	0.791	0.043	0.039	0	53.3	51.2	66.2	154	148	0	30	29
2014	7	3	18	50	9	0.197	0.072	0.791	0.039	0.036	0	53.3	50.7	66.7	153	147	0	29	29
2014	7	3	19	0	9	0.157	0.039	0.787	0.039	0.039	0	54.2	52.5	65.8	156	151	0	30	29
2014	7	3	19	10	9	0.187	0.03	0.787	0.039	0.036	0	54.2	52	65.8	156	150	0	30	29
2014	7	3	19	20	9	0.256	0.085	0.787	0.039	0.039	0	52.5	50.7	67.1	152	147	0	30	29
2014	7	3	19	30	9	0.18	0.039	0.787	0.036	0.033	0	52	50.3	68.4	151	146	0	30	29
2014	7	3	19	40	9	0.217	-0.023	0.791	0.039	0.036	0	51.6	50.3	67.5	151	146	0	31	29
2014	7	3	19	50	9	0.236	-0.007	0.791	0.039	0.039	0	51.2	49.5	68.4	149	144	0	30	29
2014	7	3	20	0	9	0.197	0.046	0.787	0.036	0.033	0	51.2	49.5	67.9	149	144	0	30	29
2014	7	3	20	10	9	0.2	-0.01	0.787	0.039	0.039	0	52.5	51.2	67.1	152	148	0	30	29
2014	7	3	20	20	9	0.207	0.082	0.791	0.039	0.036	0	52.9	51.2	67.1	153	148	0	30	29
2014	7	3	20	30	9	0.217	0.089	0.787	0.039	0.039	0	52.9	51.2	67.1	153	148	0	30	29
2014	7	3	20	40	9	0.194	0.036	0.787	0.036	0.033	0	52.5	50.7	67.5	152	147	0	30	29
2014	7	3	20	50	9	0.243	0.079	0.787	0.033	0.03	0	52	50.3	67.5	151	146	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	21	0	9	0.194	-0.079	0.787	0.039	0.039	0	52.5	51.2	67.1	152	148	0	30	29
2014	7	3	21	10	9	0.233	-0.036	0.787	0.039	0.036	0	52	50.7	67.5	151	147	0	30	29
2014	7	3	21	20	9	0.279	-0.043	0.791	0.046	0.043	0	50.7	49.5	68.4	148	144	0	30	29
2014	7	3	21	30	9	0.21	0.075	0.791	0.033	0.03	0	49.9	48.6	68.4	146	142	0	30	29
2014	7	3	21	40	9	0.161	0.016	0.791	0.039	0.036	0	49.9	48.6	68.8	146	142	0	30	29
2014	7	3	21	50	9	0.233	0	0.791	0.039	0.039	0	49.5	48.6	68.4	145	142	0	30	29
2014	7	3	22	0	9	0.259	0.072	0.791	0.043	0.039	0	49.9	48.2	69.2	146	141	0	30	29
2014	7	3	22	10	9	0.213	0.056	0.791	0.043	0.039	0	50.3	48.6	67.9	147	142	0	30	29
2014	7	3	22	20	9	0.22	0.023	0.791	0.033	0.03	0	49.5	48.2	68.4	146	141	0	31	29
2014	7	3	22	30	9	0.292	0	0.794	0.033	0.03	0	49.9	48.2	68.4	146	142	0	30	30
2014	7	3	22	40	9	0.243	-0.013	0.794	0.033	0.03	0	49	48.2	68.4	144	141	0	30	29
2014	7	3	22	50	9	0.272	-0.02	0.794	0.043	0.039	0	49.5	48.2	68.4	145	141	0	30	29
2014	7	3	23	0	9	0.187	0.062	0.794	0.033	0.03	0	49.9	48.2	67.9	146	142	0	30	30
2014	7	3	23	10	9	0.184	0	0.797	0.039	0.039	0	48.6	47.7	68.8	143	140	0	30	29
2014	7	3	23	20	9	0.266	0.007	0.797	0.039	0.036	0	48.6	47.3	69.2	143	139	0	30	29
2014	7	3	23	30	9	0.262	0.043	0.797	0.039	0.039	0	48.6	47.7	67.9	143	140	0	30	29
2014	7	3	23	40	9	0.217	0.039	0.801	0.043	0.039	0	49	47.3	68.4	144	139	0	30	29
2014	7	3	23	50	9	0.253	-0.02	0.801	0.036	0.033	0	49	47.7	67.9	144	140	0	30	29
2014	7	4	0	0	9	0.19	0.016	0.801	0.039	0.039	0	48.2	47.3	68.8	142	140	0	30	30
2014	7	4	0	10	9	0.194	-0.003	0.804	0.036	0.033	0	48.6	47.7	68.4	143	140	0	30	29
2014	7	4	0	20	9	0.223	0.016	0.804	0.039	0.036	0	48.2	46.9	69.2	142	139	0	30	30
2014	7	4	0	30	9	0.19	0	0.804	0.039	0.036	0	51.2	49.5	66.7	149	145	0	30	30
2014	7	4	0	40	9	0.157	-0.013	0.804	0.039	0.036	0	49	47.7	68.4	144	140	0	30	29
2014	7	4	0	50	9	0.236	-0.059	0.807	0.039	0.036	0	49	48.2	68.8	144	141	0	30	29
2014	7	4	1	0	9	0.22	0.062	0.807	0.039	0.036	0	47.3	47.3	70.5	141	139	0	31	29
2014	7	4	1	10	9	0.282	-0.003	0.807	0.039	0.039	0	48.2	46.9	69.7	142	139	0	30	30
2014	7	4	1	20	9	0.207	0.03	0.807	0.033	0.03	0	47.7	46.9	70.5	142	139	0	31	30
2014	7	4	1	30	9	0.19	0	0.807	0.036	0.033	0	48.2	47.3	69.7	142	139	0	30	29
2014	7	4	1	40	9	0.187	0.016	0.807	0.036	0.033	0	48.6	48.2	69.7	143	141	0	30	29
2014	7	4	1	50	9	0.272	0	0.807	0.033	0.03	0	46.9	46.4	71	140	137	0	31	29
2014	7	4	2	0	9	0.236	0.056	0.807	0.039	0.036	0	48.2	46.9	70.1	142	139	0	30	30
2014	7	4	2	10	9	0.207	0.036	0.807	0.036	0.033	0	48.2	46.9	71	142	139	0	30	30
2014	7	4	2	20	9	0.236	0.016	0.807	0.039	0.039	0	47.7	45.6	71	142	136	0	31	30
2014	7	4	2	30	9	0.24	0.036	0.807	0.036	0.033	0	48.2	46.4	71	142	138	0	30	30
2014	7	4	2	40	9	0.262	0.023	0.807	0.039	0.036	0	46.9	46.4	71.4	140	138	0	31	30
2014	7	4	2	50	9	0.285	0	0.807	0.039	0.036	0	48.2	46.9	71	142	139	0	30	30
2014	7	4	3	0	9	0.279	0.026	0.807	0.033	0.03	0	47.7	47.7	70.1	142	141	0	31	30
2014	7	4	3	10	9	0.299	-0.033	0.807	0.036	0.033	0	49	47.3	71	144	141	0	30	31
2014	7	4	3	20	9	0.18	-0.007	0.81	0.039	0.039	0	47.7	46.4	71.8	141	138	0	30	30
2014	7	4	3	30	9	0.167	-0.013	0.81	0.039	0.036	0	48.2	47.3	71	142	140	0	30	30
2014	7	4	3	40	9	0.22	0.03	0.807	0.039	0.039	0	47.7	46.9	71	142	139	0	31	30
2014	7	4	3	50	9	0.213	0.046	0.81	0.033	0.03	0	48.2	47.3	71	142	139	0	30	29
2014	7	4	4	0	9	0.262	0.052	0.81	0.03	0.03	0	47.7	46.9	71.8	141	138	0	30	29
2014	7	4	4	10	9	0.223	0.016	0.81	0.039	0.036	0	48.2	47.3	71.8	143	140	0	31	30
2014	7	4	4	20	9	0.194	0.016	0.81	0.033	0.03	0	47.3	46.9	71	141	139	0	31	30
2014	7	4	4	30	9	0.282	0.003	0.81	0.036	0.033	0	48.6	47.3	71	143	139	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	4	40	9	0.187	0.036	0.81	0.036	0.033	0	48.2	47.3	71.4	142	140	0	30	30
2014	7	4	4	50	9	0.331	0.01	0.81	0.039	0.036	0	48.2	46.9	71.8	142	139	0	30	30
2014	7	4	5	0	9	0.236	0.033	0.81	0.036	0.033	0	47.3	47.3	71.8	141	139	0	31	29
2014	7	4	5	10	9	0.266	0.089	0.81	0.036	0.033	0	47.7	47.3	71.8	142	140	0	31	30
2014	7	4	5	20	9	0.246	0.046	0.81	0.036	0.033	0	47.3	46	72.2	141	138	0	31	31
2014	7	4	5	30	9	0.226	0	0.81	0.039	0.039	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	4	5	40	9	0.256	0.052	0.81	0.039	0.036	0	46.9	46.4	72.2	140	138	0	31	30
2014	7	4	5	50	9	0.223	0.056	0.81	0.039	0.036	0	46.4	45.6	73.1	139	137	0	31	31
2014	7	4	6	0	9	0.279	0.052	0.81	0.039	0.036	0	46	45.2	73.5	138	135	0	31	30
2014	7	4	6	10	9	0.233	0.01	0.81	0.039	0.039	0	45.6	45.6	73.1	137	136	0	31	30
2014	7	4	6	20	9	0.174	0.046	0.81	0.036	0.033	0	46	45.6	74	138	136	0	31	30
2014	7	4	6	30	9	0.24	0.046	0.81	0.036	0.033	0	45.6	44.7	73.5	137	135	0	31	31
2014	7	4	6	40	9	0.256	0.007	0.81	0.036	0.033	0	45.6	44.7	74.4	137	134	0	31	30
2014	7	4	6	50	9	0.295	-0.03	0.81	0.036	0.033	0	46	45.2	74	137	135	0	30	30
2014	7	4	7	0	9	0.249	0.02	0.81	0.039	0.039	0	45.2	43.9	75.3	136	133	0	31	31
2014	7	4	7	10	9	0.259	-0.01	0.81	0.039	0.039	0	46	45.2	74.4	137	135	0	30	30
2014	7	4	7	20	9	0.197	-0.052	0.81	0.039	0.036	0	45.2	45.2	75.3	136	135	0	31	30
2014	7	4	7	30	9	0.2	0.049	0.814	0.039	0.036	0	45.2	44.7	74.8	136	134	0	31	30
2014	7	4	7	40	9	0.233	0.01	0.81	0.036	0.033	0	46	44.7	74.8	137	134	0	30	30
2014	7	4	7	50	9	0.272	0.125	0.81	0.039	0.036	0	45.2	44.3	74	136	133	0	31	30
2014	7	4	8	0	9	0.256	0.016	0.81	0.039	0.036	0	45.2	44.7	75.3	135	134	0	30	30
2014	7	4	8	10	9	0.256	0.056	0.81	0.039	0.036	0	44.7	44.7	75.3	135	133	0	31	29
2014	7	4	8	20	9	0.23	0.016	0.81	0.039	0.036	0	45.2	44.3	74.4	136	134	0	31	31
2014	7	4	8	30	9	0.217	0.013	0.81	0.036	0.033	0	45.2	44.3	74.8	136	133	0	31	30
2014	7	4	8	40	9	0.266	0.089	0.81	0.039	0.036	0	45.2	44.3	74.4	136	133	0	31	30
2014	7	4	8	50	9	0.249	0.059	0.81	0.039	0.036	0	44.7	43.9	75.3	134	132	0	30	30
2014	7	4	9	0	9	0.223	0.016	0.81	0.039	0.036	0	44.7	44.3	75.3	135	133	0	31	30
2014	7	4	9	10	9	0.18	0.02	0.81	0.039	0.036	0	45.2	45.2	74	136	135	0	31	30
2014	7	4	9	20	9	0.266	0.049	0.81	0.046	0.043	0	44.7	44.7	74	135	134	0	31	30
2014	7	4	9	30	9	0.279	0.141	0.81	0.036	0.033	0	44.7	44.3	74.8	135	133	0	31	30
2014	7	4	9	40	9	0.187	0.003	0.81	0.036	0.033	0	45.2	45.2	74.4	136	134	0	31	29
2014	7	4	9	50	9	0.276	0.056	0.81	0.036	0.033	0	46	45.6	72.7	138	136	0	31	30
2014	7	4	10	0	9	0.213	-0.007	0.81	0.033	0.03	0	45.6	45.2	73.1	137	135	0	31	30
2014	7	4	10	10	9	0.24	0.039	0.81	0.039	0.036	0	46.4	45.6	72.7	138	136	0	30	30
2014	7	4	10	20	9	0.21	0.01	0.81	0.036	0.033	0	45.6	45.2	71.8	136	136	0	30	31
2014	7	4	10	30	9	0.302	0.092	0.81	0.033	0.03	0	45.6	45.2	72.2	137	136	0	31	31
2014	7	4	10	40	9	0.266	0.033	0.81	0.043	0.043	0	45.6	44.7	72.7	137	134	0	31	30
2014	7	4	10	50	9	0.249	0.02	0.807	0.039	0.036	0	46	45.6	71.8	138	136	0	31	30
2014	7	4	11	0	9	0.279	0.052	0.807	0.036	0.033	0	46.9	46	71.4	140	137	0	31	30
2014	7	4	11	10	9	0.23	0.023	0.807	0.033	0.03	0	46	45.2	71.8	137	135	0	30	30
2014	7	4	11	20	9	0.203	0	0.807	0.036	0.033	0	46	45.6	71.8	137	136	0	30	30
2014	7	4	11	30	9	0.233	-0.003	0.807	0.033	0.03	0	47.7	46.9	70.1	142	139	0	31	30
2014	7	4	11	40	9	0.197	0.046	0.807	0.039	0.036	0	46.4	46.4	71	138	138	0	30	30
2014	7	4	11	50	9	0.285	0.102	0.804	0.039	0.036	0	46.4	46.4	71	138	138	0	30	30
2014	7	4	12	0	9	0.256	0.052	0.804	0.043	0.039	0	46.4	46.4	71.4	138	137	0	30	29
2014	7	4	12	10	9	0.305	0.052	0.804	0.036	0.033	0	47.3	46.9	70.1	140	139	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	12	20	9	0.246	0.052	0.804	0.036	0.033	0	46.9	46	70.5	139	137	0	30	30
2014	7	4	12	30	9	0.292	0.046	0.801	0.033	0.03	0	47.3	46.9	70.1	140	139	0	30	30
2014	7	4	12	40	9	0.272	0.075	0.804	0.033	0.03	0	47.7	47.3	69.2	141	140	0	30	30
2014	7	4	12	50	9	0.2	0.098	0.801	0.033	0.03	0	47.7	47.3	69.2	141	140	0	30	30
2014	7	4	13	0	9	0.315	0.056	0.797	0.039	0.039	0	47.3	47.3	69.2	141	140	0	31	30
2014	7	4	13	10	9	0.282	0.069	0.797	0.033	0.03	0	48.2	47.3	69.7	143	140	0	31	30
2014	7	4	13	20	9	0.295	0.115	0.794	0.033	0.03	0	48.2	47.7	69.2	143	140	0	31	29
2014	7	4	13	30	9	0.348	0.052	0.794	0.039	0.036	0	48.6	47.7	69.7	143	140	0	30	29
2014	7	4	13	40	9	0.279	0.059	0.794	0.033	0.03	0	49	49	69.7	144	143	0	30	29
2014	7	4	13	50	9	0.312	0.089	0.794	0.033	0.03	0	49.5	49.5	69.2	145	144	0	30	29
2014	7	4	14	0	9	0.312	0.105	0.791	0.036	0.033	0	48.2	48.6	69.2	143	143	0	31	30
2014	7	4	14	10	9	0.308	0.082	0.791	0.036	0.033	0	49.9	49	70.5	146	144	0	30	30
2014	7	4	14	20	9	0.285	0.059	0.791	0.033	0.03	0	48.6	49.5	70.5	144	144	0	31	29
2014	7	4	14	30	9	0.344	0.069	0.791	0.039	0.039	0	49.5	49.5	71	145	144	0	30	29
2014	7	4	14	40	9	0.197	0.141	0.791	0.033	0.03	0	49.5	49.5	71.4	145	144	0	30	29
2014	7	4	14	50	9	0.249	0.056	0.791	0.039	0.036	0	49.9	49.5	70.1	146	144	0	30	29
2014	7	4	15	0	9	0.276	0	0.787	0.033	0.03	0	50.3	49.9	71.4	147	145	0	30	29
2014	7	4	15	10	9	0.276	0.079	0.787	0.036	0.033	0	49.9	50.3	71	146	145	0	30	28
2014	7	4	15	20	9	0.266	0.023	0.787	0.036	0.033	0	50.7	50.7	70.5	148	147	0	30	29
2014	7	4	15	30	9	0.226	0.046	0.787	0.036	0.033	0	49.9	49	70.5	146	144	0	30	30
2014	7	4	15	40	9	0.266	0.039	0.787	0.036	0.033	0	51.2	50.3	71	148	146	0	29	29
2014	7	4	15	50	9	0.269	0.089	0.787	0.033	0.03	0	49.5	49.9	70.5	145	145	0	30	29
2014	7	4	16	0	9	0.276	0.046	0.787	0.033	0.03	0	49.9	49.5	72.2	146	145	0	30	30
2014	7	4	16	10	9	0.246	0.128	0.787	0.036	0.033	0	49.9	50.3	71.8	146	146	0	30	29
2014	7	4	16	20	9	0.262	0.089	0.787	0.033	0.03	0	49.9	49.9	72.2	146	145	0	30	29
2014	7	4	16	30	9	0.249	0.102	0.787	0.039	0.036	0	50.3	49	72.7	147	143	0	30	29
2014	7	4	16	40	9	0.243	0.079	0.787	0.039	0.036	0	49.9	49.9	72.2	145	145	0	29	29
2014	7	4	16	50	9	0.233	0.079	0.787	0.036	0.033	0	49.9	49.9	71.8	146	145	0	30	29
2014	7	4	17	0	9	0.236	0.125	0.787	0.033	0.03	0	49.5	48.6	72.2	145	143	0	30	30
2014	7	4	17	10	9	0.21	0.102	0.787	0.036	0.033	0	50.7	49.9	73.1	147	144	0	29	28
2014	7	4	17	20	9	0.236	0.089	0.787	0.03	0.03	0	50.3	49.5	72.7	147	144	0	30	29
2014	7	4	17	30	9	0.197	0.069	0.784	0.033	0.03	0	50.3	49	72.7	147	143	0	30	29
2014	7	4	17	40	9	0.246	0.043	0.784	0.036	0.033	0	48.6	48.2	73.5	142	140	0	29	28
2014	7	4	17	50	9	0.236	0.128	0.784	0.036	0.033	0	47.3	46.4	73.5	140	137	0	30	29
2014	7	4	18	0	9	0.24	0.112	0.781	0.033	0.03	0	46.9	46.4	74	138	137	0	29	29
2014	7	4	18	10	9	0.246	0.161	0.781	0.036	0.033	0	46	45.6	73.5	137	135	0	30	29
2014	7	4	18	20	9	0.262	0.194	0.781	0.049	0.046	0	45.6	44.7	73.5	137	133	0	31	29
2014	7	4	18	30	9	0.197	0.036	0.781	0.036	0.033	0	47.3	45.6	72.2	139	135	0	29	29
2014	7	4	18	40	9	0.266	0.154	0.778	0.039	0.036	0	45.6	44.7	72.7	136	133	0	30	29
2014	7	4	18	50	9	0.217	0.105	0.778	0.033	0.03	0	45.6	44.3	72.2	136	132	0	30	29
2014	7	4	19	0	9	0.253	0.082	0.778	0.036	0.033	0	45.6	43.9	72.7	136	131	0	30	29
2014	7	4	19	10	9	0.118	0.056	0.774	0.036	0.033	0	45.2	44.3	71.8	135	132	0	30	29
2014	7	4	19	20	9	0.213	0.102	0.771	0.036	0.033	0	45.6	44.7	71.8	135	133	0	29	29
2014	7	4	19	30	9	0.177	0.033	0.768	0.039	0.036	0	49.9	48.2	66.7	146	141	0	30	29
2014	7	4	19	40	9	0.161	0.144	0.768	0.046	0.043	0	49.9	47.7	68.4	145	140	0	29	29
2014	7	4	19	50	9	0.141	0.069	0.768	0.033	0.03	0	49.5	47.7	67.9	145	140	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	20	0	9	0.2	0.036	0.764	0.036	0.033	0	50.3	49.5	67.1	147	144	0	30	29
2014	7	4	20	10	9	0.21	0.039	0.764	0.039	0.036	0	49.5	48.6	67.5	145	142	0	30	29
2014	7	4	20	20	9	0.174	0.059	0.761	0.033	0.03	0	47.7	46.9	68.8	141	138	0	30	29
2014	7	4	20	30	9	0.23	0.026	0.758	0.036	0.033	0	47.7	46	69.7	140	136	0	29	29
2014	7	4	20	40	9	0.203	0.03	0.758	0.033	0.03	0	48.2	47.3	69.2	142	139	0	30	29
2014	7	4	20	50	9	0.187	-0.023	0.755	0.036	0.033	0	48.2	46.9	68.8	142	138	0	30	29
2014	7	4	21	0	9	0.131	0.016	0.758	0.039	0.036	0	47.3	46.9	69.7	140	137	0	30	28
2014	7	4	21	10	9	0.256	0.089	0.755	0.036	0.033	0	49.9	49	67.9	146	143	0	30	29
2014	7	4	21	20	9	0.194	0.026	0.755	0.039	0.036	0	51.6	50.3	66.7	150	146	0	30	29
2014	7	4	21	30	9	0.154	0.016	0.755	0.039	0.039	0	50.7	49	67.9	148	143	0	30	29
2014	7	4	21	40	9	0.21	0.062	0.755	0.036	0.033	0	51.6	50.3	66.7	150	146	0	30	29
2014	7	4	21	50	9	0.19	0.075	0.755	0.036	0.033	0	50.7	49.9	67.5	148	145	0	30	29
2014	7	4	22	0	9	0.203	-0.013	0.755	0.049	0.046	0	50.3	49	67.5	147	143	0	30	29
2014	7	4	22	10	9	0.223	-0.043	0.755	0.039	0.036	0	49.9	49	67.5	146	143	0	30	29
2014	7	4	22	20	9	0.249	0.062	0.755	0.033	0.03	0	50.3	48.6	67.1	147	142	0	30	29
2014	7	4	22	30	9	0.177	0	0.755	0.039	0.039	0	49.5	48.2	68.4	145	141	0	30	29
2014	7	4	22	40	9	0.171	0	0.755	0.039	0.039	0	49.5	48.6	68.4	145	142	0	30	29
2014	7	4	22	50	9	0.256	-0.01	0.755	0.039	0.036	0	48.6	47.7	69.2	144	140	0	31	29
2014	7	4	23	0	9	0.121	-0.003	0.755	0.039	0.036	0	48.2	47.7	68.8	142	141	0	30	30
2014	7	4	23	10	9	0.144	-0.026	0.751	0.049	0.046	0	48.6	47.7	68.4	143	140	0	30	29
2014	7	4	23	20	9	0.18	-0.007	0.751	0.033	0.03	0	48.2	47.3	69.7	142	139	0	30	29
2014	7	4	23	30	9	0.161	-0.072	0.751	0.043	0.039	0	48.6	47.7	68.8	143	140	0	30	29
2014	7	4	23	40	9	0.118	0	0.751	0.039	0.039	0	48.6	47.7	69.2	144	140	0	31	29
2014	7	4	23	50	9	0.157	0.03	0.751	0.039	0.036	0	48.6	47.7	68.8	143	140	0	30	29
2014	7	5	0	0	9	0.203	0.013	0.751	0.036	0.033	0	48.2	48.2	69.2	142	141	0	30	29
2014	7	5	0	10	9	0.121	0.049	0.751	0.033	0.03	0	48.6	47.7	68.8	143	140	0	30	29
2014	7	5	0	20	9	0.161	0.02	0.751	0.036	0.033	0	47.3	46.9	69.7	141	138	0	31	29
2014	7	5	0	30	9	0.115	0.026	0.751	0.036	0.033	0	48.6	46.9	68.8	143	138	0	30	29
2014	7	5	0	40	9	0.174	0.039	0.751	0.039	0.036	0	48.2	47.7	68.4	142	140	0	30	29
2014	7	5	0	50	9	0.138	0.02	0.755	0.036	0.033	0	47.7	47.7	68.8	141	140	0	30	29
2014	7	5	1	0	9	0.131	0.033	0.755	0.039	0.036	0	48.2	47.3	68.8	142	139	0	30	29
2014	7	5	1	10	9	0.171	-0.049	0.755	0.036	0.033	0	48.2	46.4	67.9	142	138	0	30	30
2014	7	5	1	20	9	0.213	0.036	0.755	0.039	0.036	0	47.7	47.3	68.4	141	139	0	30	29
2014	7	5	1	30	9	0.154	0.016	0.755	0.033	0.03	0	48.2	47.7	69.2	142	140	0	30	29
2014	7	5	1	40	9	0.197	0.056	0.755	0.039	0.036	0	47.7	46.9	69.2	141	139	0	30	30
2014	7	5	1	50	9	0.253	0.039	0.755	0.033	0.03	0	47.7	47.7	68.8	141	140	0	30	29
2014	7	5	2	0	9	0.144	0.066	0.758	0.036	0.033	0	48.2	47.7	68.8	142	140	0	30	29
2014	7	5	2	10	9	0.131	0.033	0.755	0.036	0.033	0	48.6	47.7	67.5	143	140	0	30	29
2014	7	5	2	20	9	0.115	0.016	0.758	0.039	0.039	0	48.2	47.3	67.9	142	140	0	30	30
2014	7	5	2	30	9	0.22	0.016	0.758	0.039	0.039	0	48.2	47.3	68.4	142	140	0	30	30
2014	7	5	2	40	9	0.171	0	0.758	0.039	0.039	0	48.2	46.4	68.4	142	138	0	30	30
2014	7	5	2	50	9	0.167	-0.02	0.758	0.033	0.03	0	48.6	46.9	68.8	143	139	0	30	30
2014	7	5	3	0	9	0.2	0.01	0.761	0.033	0.03	0	48.2	46.9	67.9	142	139	0	30	30
2014	7	5	3	10	9	0.171	0.072	0.758	0.036	0.033	0	49	47.3	67.9	144	140	0	30	30
2014	7	5	3	20	9	0.184	0.049	0.758	0.039	0.036	0	48.6	47.3	68.4	143	140	0	30	30
2014	7	5	3	30	9	0.125	-0.023	0.758	0.033	0.03	0	48.6	46.4	67.9	143	138	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	3	40	9	0.19	0.036	0.758	0.033	0.03	0	48.6	47.3	68.4	143	140	0	30	30
2014	7	5	3	50	9	0.115	0.003	0.755	0.033	0.03	0	48.6	47.3	68.4	144	139	0	31	29
2014	7	5	4	0	9	0.174	-0.059	0.758	0.039	0.036	0	48.6	46.9	67.9	143	139	0	30	30
2014	7	5	4	10	9	0.243	0.043	0.758	0.036	0.033	0	48.2	47.7	68.4	142	140	0	30	29
2014	7	5	4	20	9	0.203	0.016	0.755	0.039	0.036	0	48.6	46.4	67.9	143	139	0	30	31
2014	7	5	4	30	9	0.161	-0.026	0.755	0.03	0.03	0	48.6	47.7	68.4	143	140	0	30	29
2014	7	5	4	40	9	0.194	-0.02	0.755	0.036	0.033	0	48.2	47.7	68.4	143	141	0	31	30
2014	7	5	4	50	9	0.184	0.033	0.755	0.036	0.033	0	48.6	47.3	68.4	144	140	0	31	30
2014	7	5	5	0	9	0.154	0.033	0.755	0.033	0.03	0	48.2	47.3	69.2	143	140	0	31	30
2014	7	5	5	10	9	0.187	0.03	0.751	0.033	0.03	0	47.7	48.2	68.4	142	141	0	31	29
2014	7	5	5	20	9	0.272	0.033	0.751	0.033	0.03	0	49	47.3	67.5	144	140	0	30	30
2014	7	5	5	30	9	0.213	0.062	0.751	0.033	0.03	0	48.2	46.9	68.4	142	139	0	30	30
2014	7	5	5	40	9	0.19	0.023	0.751	0.036	0.033	0	47.7	46.9	69.2	142	139	0	31	30
2014	7	5	5	50	9	0.184	0	0.751	0.033	0.03	0	48.2	47.3	67.9	142	139	0	30	29
2014	7	5	6	0	9	0.22	-0.013	0.751	0.039	0.036	0	47.3	46.9	68.8	140	138	0	30	29
2014	7	5	6	10	9	0.144	0.056	0.748	0.036	0.033	0	47.3	46.4	69.7	141	137	0	31	29
2014	7	5	6	20	9	0.203	-0.01	0.748	0.033	0.033	0	46.9	46.9	68.8	140	138	0	31	29
2014	7	5	6	30	9	0.217	-0.016	0.748	0.033	0.03	0	46.9	46.4	69.7	139	137	0	30	29
2014	7	5	6	40	9	0.167	0.039	0.748	0.036	0.033	0	46.9	45.6	69.7	139	136	0	30	30
2014	7	5	6	50	9	0.177	-0.01	0.748	0.036	0.033	0	46.9	46.4	69.7	140	138	0	31	30
2014	7	5	7	0	9	0.164	0.003	0.748	0.033	0.03	0	46.4	46	69.7	138	137	0	30	30
2014	7	5	7	10	9	0.266	-0.043	0.748	0.036	0.033	0	46	45.6	71.4	138	136	0	31	30
2014	7	5	7	20	9	0.207	-0.036	0.748	0.036	0.033	0	46.4	45.2	71.4	138	135	0	30	30
2014	7	5	7	30	9	0.226	0.026	0.748	0.039	0.036	0	45.6	45.2	71	136	135	0	30	30
2014	7	5	7	40	9	0.177	0.036	0.748	0.036	0.033	0	45.6	45.2	71.4	137	135	0	31	30
2014	7	5	7	50	9	0.23	-0.023	0.748	0.036	0.033	0	45.6	44.7	71.4	137	134	0	31	30
2014	7	5	8	0	9	0.157	0	0.748	0.039	0.036	0	46	45.2	71	137	135	0	30	30
2014	7	5	8	10	9	0.236	0.03	0.748	0.033	0.03	0	45.6	45.6	71.4	137	135	0	31	29
2014	7	5	8	20	9	0.203	0.003	0.748	0.036	0.033	0	46	45.2	71	137	135	0	30	30
2014	7	5	8	30	9	0.177	0.02	0.748	0.039	0.036	0	46.4	44.7	71.4	138	135	0	30	31
2014	7	5	8	40	9	0.184	0.039	0.748	0.033	0.03	0	46	45.2	71.4	138	135	0	31	30
2014	7	5	8	50	9	0.121	-0.01	0.748	0.039	0.036	0	46.4	46	71.4	138	136	0	30	29
2014	7	5	9	0	9	0.24	0.023	0.748	0.033	0.03	0	45.6	44.7	72.2	136	134	0	30	30
2014	7	5	9	10	9	0.171	0.059	0.748	0.033	0.03	0	46	44.7	72.7	137	134	0	30	30
2014	7	5	9	20	9	0.184	0	0.748	0.033	0.03	0	45.2	44.7	72.2	136	134	0	31	30
2014	7	5	9	30	9	0.272	0.052	0.748	0.033	0.03	0	45.2	44.7	73.5	136	134	0	31	30
2014	7	5	9	40	9	0.174	0	0.748	0.039	0.039	0	45.6	45.6	73.1	137	135	0	31	29
2014	7	5	9	50	9	0.21	0.075	0.745	0.043	0.039	0	48.6	46	69.7	143	137	0	30	30
2014	7	5	10	0	9	0.246	0.046	0.745	0.036	0.033	0	46.4	45.2	73.5	139	135	0	31	30
2014	7	5	10	10	9	0.246	0.108	0.745	0.036	0.033	0	46.9	45.2	73.1	139	135	0	30	30
2014	7	5	10	20	9	0.21	0.049	0.745	0.036	0.033	0	45.6	44.7	73.5	137	134	0	31	30
2014	7	5	10	30	9	0.174	0.046	0.745	0.036	0.033	0	45.2	44.7	73.1	136	134	0	31	30
2014	7	5	10	40	9	0.207	0.062	0.745	0.039	0.039	0	45.2	45.2	73.5	136	135	0	31	30
2014	7	5	10	50	9	0.098	0.026	0.745	0.043	0.039	0	48.2	47.3	72.2	142	140	0	30	30
2014	7	5	11	0	9	0.226	-0.066	0.745	0.039	0.036	0	49	48.6	71.8	144	143	0	30	30
2014	7	5	11	10	9	0.203	0.046	0.745	0.033	0.03	0	47.7	47.7	71.8	142	141	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	11	20	9	0.223	0.049	0.745	0.033	0.03	0	47.3	46.4	72.2	140	138	0	30	30
2014	7	5	11	30	9	0.282	0	0.748	0.033	0.03	0	46.9	46	72.7	139	137	0	30	30
2014	7	5	11	40	9	0.226	0.036	0.748	0.036	0.033	0	47.3	47.3	72.2	140	139	0	30	29
2014	7	5	11	50	9	0.187	0.098	0.748	0.033	0.03	0	46.9	48.2	71.8	140	141	0	31	29
2014	7	5	12	0	9	0.207	0.056	0.748	0.036	0.033	0	46.9	47.3	71	140	139	0	31	29
2014	7	5	12	10	9	0.21	0.075	0.748	0.033	0.03	0	47.3	47.3	71.4	141	140	0	31	30
2014	7	5	12	20	9	0.19	0.003	0.751	0.036	0.033	0	49	48.2	70.5	144	141	0	30	29
2014	7	5	12	30	9	0.253	0.085	0.751	0.033	0.03	0	48.6	47.3	70.5	143	140	0	30	30
2014	7	5	12	40	9	0.217	0.033	0.755	0.033	0.03	0	47.3	47.7	70.5	141	141	0	31	30
2014	7	5	12	50	9	0.203	0.023	0.755	0.039	0.039	0	48.6	48.2	69.2	143	141	0	30	29
2014	7	5	13	0	9	0.187	0.056	0.758	0.036	0.033	0	48.6	47.7	68.8	143	141	0	30	30
2014	7	5	13	10	9	0.207	0.033	0.761	0.036	0.033	0	53.3	52	64.9	154	151	0	30	30
2014	7	5	13	20	9	0.223	0.135	0.764	0.033	0.03	0	50.7	49.9	67.5	148	145	0	30	29
2014	7	5	13	30	9	0.174	0.023	0.768	0.033	0.03	0	49.9	49.9	68.8	146	145	0	30	29
2014	7	5	13	40	9	0.194	0.046	0.771	0.033	0.03	0	49.5	49.5	69.2	145	144	0	30	29
2014	7	5	13	50	9	0.299	0.069	0.771	0.033	0.03	0	49.5	49	69.7	145	143	0	30	29
2014	7	5	14	0	9	0.24	0.059	0.774	0.033	0.03	0	49	49.9	71.4	144	145	0	30	29
2014	7	5	14	10	9	0.233	0.036	0.774	0.039	0.036	0	49.5	49.5	69.7	145	144	0	30	29
2014	7	5	14	20	9	0.23	0.036	0.778	0.033	0.03	0	48.6	49.5	71.4	142	144	0	29	29
2014	7	5	14	30	9	0.236	0.069	0.778	0.036	0.033	0	49.9	49.5	70.5	146	144	0	30	29
2014	7	5	14	40	9	0.269	0.115	0.778	0.039	0.039	0	49	49	71.4	144	143	0	30	29
2014	7	5	14	50	9	0.318	0.167	0.778	0.033	0.03	0	50.7	49.9	71	147	145	0	29	29
2014	7	5	15	0	9	0.256	0.036	0.781	0.033	0.03	0	49	49.9	71.4	144	145	0	30	29
2014	7	5	15	10	9	0.272	0.125	0.781	0.036	0.033	0	50.3	49.9	71	147	145	0	30	29
2014	7	5	15	20	9	0.266	0.138	0.781	0.03	0.03	0	49.9	49.9	71	146	145	0	30	29
2014	7	5	15	30	9	0.266	0.115	0.781	0.033	0.03	0	49.9	50.3	71.4	146	146	0	30	29
2014	7	5	15	40	9	0.217	0.131	0.781	0.036	0.033	0	50.7	50.3	71.4	148	146	0	30	29
2014	7	5	15	50	9	0.207	0.157	0.784	0.033	0.03	0	50.3	50.3	71.4	147	145	0	30	28
2014	7	5	16	0	9	0.164	0.085	0.784	0.033	0.03	0	50.7	49.9	71.4	147	144	0	29	28
2014	7	5	16	10	9	0.315	0.098	0.784	0.036	0.033	0	49.9	49.9	72.7	146	145	0	30	29
2014	7	5	16	20	9	0.262	0.118	0.784	0.036	0.033	0	50.7	49.9	72.7	147	145	0	29	29
2014	7	5	16	30	9	0.299	0.118	0.784	0.036	0.033	0	49.5	48.2	73.5	144	141	0	29	29
2014	7	5	16	40	9	0.262	0.135	0.787	0.036	0.033	0	49	49	72.2	144	143	0	30	29
2014	7	5	16	50	9	0.22	0.102	0.787	0.039	0.036	0	49	49	73.1	144	143	0	30	29
2014	7	5	17	0	9	0.279	0.138	0.787	0.033	0.03	0	49.9	49.5	72.7	145	144	0	29	29
2014	7	5	17	10	9	0.187	0.069	0.787	0.036	0.033	0	50.3	50.3	72.7	147	145	0	30	28
2014	7	5	17	20	9	0.262	0.108	0.787	0.033	0.03	0	48.6	48.6	72.7	143	142	0	30	29
2014	7	5	17	30	9	0.266	0.138	0.787	0.036	0.033	0	49	48.2	74	143	141	0	29	29
2014	7	5	17	40	9	0.187	0.052	0.787	0.036	0.033	0	47.3	48.2	73.1	140	140	0	30	28
2014	7	5	17	50	9	0.233	0.148	0.787	0.036	0.033	0	46.9	45.6	74.8	138	134	0	29	28
2014	7	5	18	0	9	0.236	0.105	0.787	0.039	0.039	0	47.7	46	72.7	141	136	0	30	29
2014	7	5	18	10	9	0.243	0.102	0.787	0.036	0.033	0	52.5	50.7	67.1	152	147	0	30	29
2014	7	5	18	20	9	0.305	0.062	0.787	0.039	0.039	0	50.3	48.6	70.5	146	142	0	29	29
2014	7	5	18	30	9	0.259	0.112	0.787	0.039	0.036	0	49.5	47.7	71.8	144	140	0	29	29
2014	7	5	18	40	9	0.246	0.105	0.787	0.039	0.039	0	48.2	47.3	72.2	142	138	0	30	28
2014	7	5	18	50	9	0.24	0.115	0.787	0.036	0.033	0	48.2	46.4	73.1	141	137	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	19	0	9	0.279	0.154	0.791	0.039	0.039	0	47.3	46.4	72.2	139	137	0	29	29
2014	7	5	19	10	9	0.272	0.092	0.787	0.036	0.033	0	49.5	48.6	70.5	144	141	0	29	28
2014	7	5	19	20	9	0.203	0.098	0.787	0.039	0.036	0	56.8	55	59.8	162	157	0	30	29
2014	7	5	19	30	9	0.125	0.108	0.787	0.039	0.039	0	55.9	54.6	60.6	159	155	0	29	28
2014	7	5	19	40	9	0.262	0.056	0.787	0.039	0.036	0	55	53.3	62.8	158	153	0	30	29
2014	7	5	19	50	9	0.194	0.075	0.787	0.039	0.039	0	54.2	52.9	64.1	156	152	0	30	29
2014	7	5	20	0	9	0.236	0.03	0.791	0.036	0.033	0	53.3	51.6	67.5	153	149	0	29	29
2014	7	5	20	10	9	0.161	0.112	0.791	0.039	0.039	0	52.9	51.6	67.5	152	148	0	29	28
2014	7	5	20	20	9	0.203	0.03	0.791	0.036	0.033	0	52	50.3	69.2	151	146	0	30	29
2014	7	5	20	30	9	0.256	0.043	0.791	0.036	0.033	0	50.7	49.9	68.4	148	144	0	30	28
2014	7	5	20	40	9	0.197	0.033	0.791	0.033	0.03	0	50.3	48.6	68.8	146	142	0	29	29
2014	7	5	20	50	9	0.2	0.036	0.791	0.036	0.033	0	49.9	49	69.2	146	143	0	30	29
2014	7	5	21	0	9	0.21	0.059	0.794	0.039	0.039	0	49.5	48.6	69.2	145	141	0	30	28
2014	7	5	21	10	9	0.289	0.062	0.794	0.033	0.03	0	49	47.7	70.1	144	140	0	30	29
2014	7	5	21	20	9	0.22	0.007	0.794	0.036	0.033	0	50.7	49.9	66.7	148	145	0	30	29
2014	7	5	21	30	9	0.24	-0.01	0.797	0.036	0.033	0	49.5	48.2	68.4	145	141	0	30	29
2014	7	5	21	40	9	0.226	0.039	0.797	0.033	0.03	0	48.6	47.3	67.9	143	139	0	30	29
2014	7	5	21	50	9	0.197	0.052	0.801	0.039	0.036	0	48.2	46.4	68.8	141	138	0	29	30
2014	7	5	22	0	9	0.19	-0.003	0.804	0.039	0.036	0	48.6	46.9	69.2	143	138	0	30	29
2014	7	5	22	10	9	0.282	-0.013	0.804	0.049	0.046	0	47.7	46.9	69.7	141	138	0	30	29
2014	7	5	22	20	9	0.184	0.033	0.807	0.033	0.03	0	48.2	47.3	69.7	142	139	0	30	29
2014	7	5	22	30	9	0.236	0.03	0.81	0.039	0.039	0	47.7	46.9	69.7	141	138	0	30	29
2014	7	5	22	40	9	0.217	-0.043	0.81	0.039	0.036	0	49.5	48.6	68.8	145	142	0	30	29
2014	7	5	22	50	9	0.151	0.016	0.81	0.039	0.039	0	51.6	49.9	67.5	150	145	0	30	29
2014	7	5	23	0	9	0.233	-0.01	0.81	0.039	0.036	0	51.2	49.5	67.1	149	144	0	30	29
2014	7	5	23	10	9	0.249	0	0.814	0.043	0.039	0	50.7	49.5	68.4	148	144	0	30	29
2014	7	5	23	20	9	0.272	0.075	0.814	0.036	0.033	0	50.3	49	68.4	147	143	0	30	29
2014	7	5	23	30	9	0.266	-0.036	0.814	0.033	0.03	0	49.5	48.6	71	145	142	0	30	29
2014	7	5	23	40	9	0.269	0.007	0.814	0.039	0.039	0	48.6	46.9	71	143	139	0	30	30
2014	7	5	23	50	9	0.246	0.023	0.814	0.033	0.03	0	48.2	47.3	70.5	142	139	0	30	29
2014	7	6	0	0	9	0.24	0	0.814	0.033	0.03	0	48.6	46.9	72.2	142	138	0	29	29
2014	7	6	0	10	9	0.207	-0.039	0.817	0.039	0.039	0	48.2	46	71.8	141	137	0	29	30
2014	7	6	0	20	9	0.266	0.046	0.817	0.03	0.03	0	47.3	46.9	73.5	140	138	0	30	29
2014	7	6	0	30	9	0.23	-0.02	0.817	0.036	0.033	0	47.7	46.9	73.1	141	138	0	30	29
2014	7	6	0	40	9	0.226	0.003	0.817	0.039	0.036	0	47.7	46	73.1	141	136	0	30	29
2014	7	6	0	50	9	0.217	-0.02	0.817	0.039	0.036	0	48.2	46.9	73.1	142	138	0	30	29
2014	7	6	1	0	9	0.266	-0.059	0.817	0.036	0.033	0	47.7	46.9	73.5	141	138	0	30	29
2014	7	6	1	10	9	0.223	-0.016	0.817	0.039	0.036	0	47.3	46.9	73.5	141	138	0	31	29
2014	7	6	1	20	9	0.236	-0.125	0.82	0.043	0.039	0	47.3	46.9	73.1	141	138	0	31	29
2014	7	6	1	30	9	0.259	0.052	0.82	0.039	0.039	0	48.6	47.7	74	143	140	0	30	29
2014	7	6	1	40	9	0.246	0.033	0.82	0.036	0.033	0	47.7	46.4	73.5	141	137	0	30	29
2014	7	6	1	50	9	0.285	0.016	0.82	0.043	0.039	0	48.6	47.3	72.2	143	139	0	30	29
2014	7	6	2	0	9	0.243	0.007	0.82	0.039	0.039	0	47.7	46.9	73.5	141	138	0	30	29
2014	7	6	2	10	9	0.253	0.007	0.82	0.033	0.03	0	47.7	46.4	73.1	142	137	0	31	29
2014	7	6	2	20	9	0.279	-0.01	0.82	0.039	0.039	0	47.3	46	74	140	137	0	30	30
2014	7	6	2	30	9	0.295	0	0.82	0.033	0.03	0	47.7	46.4	74	141	137	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	2	40	9	0.266	0.02	0.82	0.036	0.033	0	46.9	46.4	74	140	138	0	31	30
2014	7	6	2	50	9	0.253	0.036	0.82	0.039	0.036	0	48.2	46.4	74.4	141	138	0	29	30
2014	7	6	3	0	9	0.285	-0.007	0.82	0.033	0.03	0	47.3	46	73.1	140	137	0	30	30
2014	7	6	3	10	9	0.295	-0.016	0.82	0.036	0.033	0	47.7	46.4	74	141	137	0	30	29
2014	7	6	3	20	9	0.259	0.062	0.823	0.039	0.039	0	49	47.7	71	145	140	0	31	29
2014	7	6	3	30	9	0.243	-0.062	0.82	0.039	0.036	0	49	48.2	71.4	144	141	0	30	29
2014	7	6	3	40	9	0.266	-0.003	0.82	0.036	0.033	0	50.7	49.9	69.7	148	146	0	30	30
2014	7	6	3	50	9	0.302	0.033	0.82	0.039	0.036	0	50.3	49	69.7	148	144	0	31	30
2014	7	6	4	0	9	0.246	-0.02	0.82	0.043	0.039	0	49.9	48.6	71	146	142	0	30	29
2014	7	6	4	10	9	0.22	0.023	0.823	0.036	0.033	0	49.9	48.6	70.5	146	143	0	30	30
2014	7	6	4	20	9	0.243	0.085	0.82	0.043	0.039	0	49.5	48.2	71	146	142	0	31	30
2014	7	6	4	30	9	0.302	0.043	0.823	0.036	0.033	0	49	48.2	71	144	141	0	30	29
2014	7	6	4	40	9	0.266	-0.033	0.823	0.039	0.039	0	48.2	47.3	71.4	142	140	0	30	30
2014	7	6	4	50	9	0.262	0	0.823	0.036	0.033	0	49	47.3	71.8	144	139	0	30	29
2014	7	6	5	0	9	0.276	0.007	0.823	0.036	0.033	0	48.2	46.9	71.8	142	139	0	30	30
2014	7	6	5	10	9	0.253	-0.013	0.823	0.039	0.036	0	49	47.7	71	144	140	0	30	29
2014	7	6	5	20	9	0.249	0.016	0.823	0.039	0.036	0	49	47.7	71	144	141	0	30	30
2014	7	6	5	30	9	0.249	-0.016	0.823	0.033	0.03	0	48.6	47.7	71.4	143	140	0	30	29
2014	7	6	5	40	9	0.282	-0.043	0.823	0.039	0.039	0	47.7	46.9	71.8	141	138	0	30	29
2014	7	6	5	50	9	0.253	-0.007	0.823	0.036	0.033	0	47.3	46.4	72.2	141	137	0	31	29
2014	7	6	6	0	9	0.203	0.039	0.823	0.039	0.039	0	46.4	46	73.1	139	137	0	31	30
2014	7	6	6	10	9	0.233	0.003	0.823	0.033	0.03	0	46	46	72.7	138	136	0	31	29
2014	7	6	6	20	9	0.282	0.062	0.823	0.043	0.039	0	46	45.2	72.2	137	135	0	30	30
2014	7	6	6	30	9	0.351	-0.121	0.823	0.033	0.03	0	46.9	45.2	73.1	139	135	0	30	30
2014	7	6	6	40	9	0.341	0.03	0.823	0.036	0.033	0	46	45.6	73.5	138	135	0	31	29
2014	7	6	6	50	9	0.253	-0.02	0.823	0.039	0.036	0	46.4	45.2	73.1	138	135	0	30	30
2014	7	6	7	0	9	0.272	-0.01	0.823	0.046	0.043	0	46	45.2	72.7	137	134	0	30	29
2014	7	6	7	10	9	0.223	0.062	0.823	0.033	0.03	0	46	46	73.5	137	136	0	30	29
2014	7	6	7	20	9	0.292	0.046	0.823	0.039	0.036	0	46	45.2	73.1	137	135	0	30	30
2014	7	6	7	30	9	0.24	-0.049	0.823	0.036	0.033	0	46.4	45.6	72.7	139	135	0	31	29
2014	7	6	7	40	9	0.318	0.016	0.823	0.033	0.03	0	46.4	45.6	72.2	139	136	0	31	30
2014	7	6	7	50	9	0.213	-0.036	0.82	0.039	0.036	0	49	47.7	71.4	144	141	0	30	30
2014	7	6	8	0	9	0.24	0.016	0.823	0.039	0.036	0	48.6	47.7	71	143	141	0	30	30
2014	7	6	8	10	9	0.22	0.089	0.823	0.033	0.03	0	48.2	47.3	71.4	142	140	0	30	30
2014	7	6	8	20	9	0.259	0.036	0.823	0.036	0.033	0	48.2	47.3	71.4	142	140	0	30	30
2014	7	6	8	30	9	0.21	-0.043	0.823	0.043	0.039	0	48.2	47.7	71.8	143	141	0	31	30
2014	7	6	8	40	9	0.259	0.007	0.823	0.033	0.03	0	48.6	47.3	71.4	143	140	0	30	30
2014	7	6	8	50	9	0.305	0	0.823	0.043	0.039	0	48.2	47.3	71.4	143	140	0	31	30
2014	7	6	9	0	9	0.289	0.098	0.823	0.039	0.036	0	47.3	46.4	71.4	141	137	0	31	29
2014	7	6	9	10	9	0.246	0.03	0.823	0.036	0.033	0	47.3	46.9	71.8	141	139	0	31	30
2014	7	6	9	20	9	0.338	0.003	0.823	0.039	0.039	0	46.4	46.4	72.7	139	138	0	31	30
2014	7	6	9	30	9	0.259	0.069	0.823	0.039	0.036	0	46.9	46.4	72.2	139	137	0	30	29
2014	7	6	9	40	9	0.328	0.072	0.823	0.039	0.039	0	46.4	45.6	72.7	139	136	0	31	30
2014	7	6	9	50	9	0.269	0.036	0.823	0.039	0.039	0	46.4	46	73.5	139	137	0	31	30
2014	7	6	10	0	9	0.315	0.003	0.823	0.036	0.033	0	46.9	45.6	72.7	140	136	0	31	30
2014	7	6	10	10	9	0.236	0.125	0.823	0.033	0.03	0	46.4	45.6	72.7	138	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	10	20	9	0.341	0.046	0.823	0.033	0.03	0	46.9	46	72.2	139	137	0	30	30
2014	7	6	10	30	9	0.302	0.052	0.823	0.033	0.03	0	47.3	46.4	72.2	140	137	0	30	29
2014	7	6	10	40	9	0.295	0.02	0.823	0.036	0.033	0	46	45.6	74	138	136	0	31	30
2014	7	6	10	50	9	0.315	0.148	0.823	0.033	0.03	0	46.9	45.6	73.1	139	136	0	30	30
2014	7	6	11	0	9	0.262	0	0.823	0.033	0.03	0	45.6	45.6	73.5	137	135	0	31	29
2014	7	6	11	10	9	0.331	0.036	0.823	0.046	0.043	0	45.6	45.2	73.5	137	135	0	31	30
2014	7	6	11	20	9	0.259	0.059	0.823	0.036	0.033	0	46.4	45.2	73.5	139	135	0	31	30
2014	7	6	11	30	9	0.295	0.052	0.823	0.036	0.033	0	45.6	46.4	73.5	137	137	0	31	29
2014	7	6	11	40	9	0.312	0.026	0.823	0.036	0.033	0	47.3	46	74	140	136	0	30	29
2014	7	6	11	50	9	0.295	0.033	0.823	0.039	0.036	0	46.4	45.6	73.1	138	136	0	30	30
2014	7	6	12	0	9	0.253	0.007	0.823	0.036	0.033	0	46.4	45.2	73.5	138	135	0	30	30
2014	7	6	12	10	9	0.279	0.026	0.823	0.039	0.039	0	47.7	45.6	74	141	136	0	30	30
2014	7	6	12	20	9	0.253	0.102	0.823	0.033	0.03	0	47.7	47.3	73.1	141	140	0	30	30
2014	7	6	12	30	9	0.295	0.01	0.823	0.039	0.039	0	47.7	46.4	73.5	141	138	0	30	30
2014	7	6	12	40	9	0.364	0.039	0.823	0.036	0.033	0	48.2	46.9	73.5	142	138	0	30	29
2014	7	6	12	50	9	0.285	0.016	0.82	0.036	0.033	0	47.3	46	73.5	140	137	0	30	30
2014	7	6	13	0	9	0.276	0.056	0.823	0.036	0.033	0	47.7	46.9	72.7	141	139	0	30	30
2014	7	6	13	10	9	0.266	0.056	0.823	0.036	0.033	0	48.6	48.6	72.7	143	142	0	30	29
2014	7	6	13	20	9	0.266	0.079	0.823	0.039	0.036	0	48.2	48.2	74	142	141	0	30	29
2014	7	6	13	30	9	0.322	0.036	0.823	0.033	0.03	0	48.6	48.6	72.2	144	143	0	31	30
2014	7	6	13	40	9	0.302	0.026	0.823	0.036	0.033	0	49.5	49	73.1	145	143	0	30	29
2014	7	6	13	50	9	0.338	0.036	0.823	0.039	0.036	0	47.7	47.7	73.5	141	140	0	30	29
2014	7	6	14	0	9	0.226	0.056	0.823	0.036	0.033	0	48.6	48.6	74	143	142	0	30	29
2014	7	6	14	10	9	0.292	0	0.823	0.036	0.033	0	48.2	48.2	73.5	142	141	0	30	29
2014	7	6	14	20	9	0.269	-0.026	0.823	0.033	0.03	0	49	49.5	73.5	144	144	0	30	29
2014	7	6	14	30	9	0.243	0.046	0.823	0.039	0.039	0	48.6	49.5	73.5	143	144	0	30	29
2014	7	6	14	40	9	0.279	0.003	0.82	0.036	0.033	0	49	48.2	73.1	144	142	0	30	30
2014	7	6	14	50	9	0.282	0.118	0.82	0.039	0.039	0	49	48.2	73.5	144	141	0	30	29
2014	7	6	15	0	9	0.384	0.085	0.82	0.039	0.039	0	49.5	49	73.1	145	143	0	30	29
2014	7	6	15	10	9	0.285	0.075	0.82	0.039	0.039	0	49.9	48.6	73.1	146	143	0	30	30
2014	7	6	15	20	9	0.233	0.079	0.82	0.033	0.03	0	49.5	49	72.7	145	143	0	30	29
2014	7	6	15	30	9	0.223	0.043	0.82	0.039	0.036	0	48.2	47.7	73.5	142	140	0	30	29
2014	7	6	15	40	9	0.305	0.085	0.82	0.033	0.03	0	49.9	49.5	71.4	146	144	0	30	29
2014	7	6	15	50	9	0.295	0.095	0.82	0.036	0.033	0	50.3	49.9	71	146	145	0	29	29
2014	7	6	16	0	9	0.299	0.059	0.82	0.036	0.033	0	48.6	48.2	71.8	143	141	0	30	29
2014	7	6	16	10	9	0.253	0.095	0.82	0.036	0.033	0	47.7	46.4	71.8	141	137	0	30	29
2014	7	6	16	20	9	0.24	0.056	0.82	0.036	0.033	0	46.9	46	72.7	139	136	0	30	29
2014	7	6	16	30	9	0.262	0.105	0.82	0.039	0.036	0	48.2	46.4	71.8	141	137	0	29	29
2014	7	6	16	40	9	0.276	0.102	0.81	0.039	0.039	0	60.6	58	59.3	170	164	0	29	29
2014	7	6	16	50	9	0.256	0.151	0.817	0.033	0.03	0	54.6	53.8	66.2	157	154	0	30	29
2014	7	6	17	0	9	0.233	0.217	0.817	0.039	0.039	0	55	53.3	65.4	158	153	0	30	29
2014	7	6	17	10	9	0.243	0.157	0.817	0.049	0.046	0	55.9	54.2	64.5	159	155	0	29	29
2014	7	6	17	20	9	0.322	0.213	0.817	0.043	0.039	0	55.5	54.2	62.8	159	155	0	30	29
2014	7	6	17	30	9	0.325	0.348	0.817	0.036	0.033	0	55.5	53.8	63.2	159	154	0	30	29
2014	7	6	17	40	9	0.325	0.302	0.817	0.039	0.036	0	55	52.9	64.1	157	152	0	29	29
2014	7	6	17	50	9	0.276	0.377	0.817	0.039	0.036	0	53.8	52	64.9	155	150	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	18	0	9	0.259	0.331	0.817	0.033	0.03	0	53.3	51.6	65.8	154	149	0	30	29
2014	7	6	18	10	9	0.262	0.295	0.817	0.039	0.039	0	53.3	51.2	66.2	154	148	0	30	29
2014	7	6	18	20	9	0.299	0.384	0.817	0.039	0.036	0	52.5	50.7	66.2	152	147	0	30	29
2014	7	6	18	30	9	0.312	0.358	0.817	0.043	0.043	0	52.9	50.7	66.2	152	147	0	29	29
2014	7	6	18	40	9	0.341	0.42	0.814	0.039	0.039	0	52	50.3	67.1	151	146	0	30	29
2014	7	6	18	50	9	0.266	0.354	0.814	0.046	0.043	0	52	50.3	67.1	151	146	0	30	29
2014	7	6	19	0	9	0.246	0.246	0.817	0.039	0.039	0	52	50.7	66.7	151	147	0	30	29
2014	7	6	19	10	9	0.272	0.302	0.817	0.039	0.036	0	52.5	50.7	66.7	152	147	0	30	29
2014	7	6	19	20	9	0.312	0.174	0.814	0.046	0.046	0	51.6	49.9	67.1	150	145	0	30	29
2014	7	6	19	30	9	0.272	0.187	0.817	0.033	0.03	0	52	49.9	67.9	150	145	0	29	29
2014	7	6	19	40	9	0.259	0.138	0.814	0.039	0.039	0	52.9	50.7	66.7	152	147	0	29	29
2014	7	6	19	50	9	0.24	0.19	0.817	0.039	0.039	0	51.6	49.9	67.9	149	145	0	29	29
2014	7	6	20	0	9	0.272	0.131	0.817	0.036	0.033	0	51.6	49	68.4	149	143	0	29	29
2014	7	6	20	10	9	0.348	0.121	0.817	0.036	0.033	0	51.2	49	68.4	149	143	0	30	29
2014	7	6	20	20	9	0.253	0.138	0.817	0.036	0.033	0	52	49.5	68.4	151	144	0	30	29
2014	7	6	20	30	9	0.259	0.118	0.817	0.036	0.033	0	50.3	49	70.1	147	143	0	30	29
2014	7	6	20	40	9	0.299	0.046	0.817	0.033	0.03	0	51.2	49.9	68.8	149	145	0	30	29
2014	7	6	20	50	9	0.194	0.052	0.817	0.039	0.036	0	51.2	49.5	69.2	149	144	0	30	29
2014	7	6	21	0	9	0.24	0.01	0.817	0.033	0.03	0	52	50.7	68.4	151	147	0	30	29
2014	7	6	21	10	9	0.233	0.056	0.817	0.039	0.036	0	52.5	49.9	69.7	151	145	0	29	29
2014	7	6	21	20	9	0.22	0.013	0.82	0.039	0.036	0	50.7	49.5	70.5	148	144	0	30	29
2014	7	6	21	30	9	0.236	0.079	0.82	0.043	0.039	0	51.2	50.3	70.1	149	145	0	30	28
2014	7	6	21	40	9	0.19	0.056	0.817	0.036	0.033	0	50.7	49	71	148	144	0	30	30
2014	7	6	21	50	9	0.246	-0.026	0.82	0.039	0.036	0	50.3	49	71.4	147	143	0	30	29
2014	7	6	22	0	9	0.23	0	0.82	0.036	0.033	0	49.9	48.2	71.8	146	142	0	30	30
2014	7	6	22	10	9	0.217	0.02	0.82	0.039	0.036	0	50.7	49.9	68.4	149	145	0	31	29
2014	7	6	22	20	9	0.217	-0.056	0.82	0.039	0.036	0	51.6	50.3	70.5	150	146	0	30	29
2014	7	6	22	30	9	0.282	-0.039	0.82	0.036	0.033	0	51.6	49.9	70.5	150	145	0	30	29
2014	7	6	22	40	9	0.236	0.023	0.82	0.039	0.036	0	50.7	49.9	70.5	148	145	0	30	29
2014	7	6	22	50	9	0.269	0.049	0.82	0.033	0.03	0	52.5	51.2	68.4	152	149	0	30	30
2014	7	6	23	0	9	0.249	0.089	0.82	0.039	0.039	0	53.3	52.5	68.8	154	151	0	30	29
2014	7	6	23	10	9	0.249	0.089	0.82	0.039	0.036	0	53.3	52	70.1	154	150	0	30	29
2014	7	6	23	20	9	0.285	-0.007	0.82	0.036	0.033	0	53.3	52	69.2	154	150	0	30	29
2014	7	6	23	30	9	0.226	0.046	0.82	0.039	0.036	0	53.8	52.9	67.9	155	152	0	30	29
2014	7	6	23	40	9	0.269	0.072	0.82	0.039	0.036	0	54.2	52.9	67.9	156	152	0	30	29
2014	7	6	23	50	9	0.299	0.092	0.82	0.036	0.033	0	53.8	52.9	66.2	155	152	0	30	29
2014	7	7	0	0	9	0.266	0.082	0.82	0.036	0.033	0	53.8	51.6	67.9	155	150	0	30	30
2014	7	7	0	10	9	0.325	0.112	0.82	0.039	0.036	0	52.9	51.6	68.4	153	149	0	30	29
2014	7	7	0	20	9	0.279	0.075	0.82	0.039	0.039	0	52	50.7	68.8	151	147	0	30	29
2014	7	7	0	30	9	0.236	0.102	0.82	0.039	0.039	0	52.5	51.2	69.7	152	148	0	30	29
2014	7	7	0	40	9	0.279	0.02	0.82	0.039	0.036	0	52	50.3	69.7	151	147	0	30	30
2014	7	7	0	50	9	0.325	0.072	0.82	0.043	0.039	0	51.2	50.3	71	150	146	0	31	29
2014	7	7	1	0	9	0.308	0.069	0.82	0.039	0.039	0	51.6	50.3	69.2	150	146	0	30	29
2014	7	7	1	10	9	0.259	0.125	0.82	0.036	0.033	0	51.6	50.3	69.7	150	146	0	30	29
2014	7	7	1	20	9	0.344	0.016	0.82	0.036	0.033	0	50.7	49	70.1	148	144	0	30	30
2014	7	7	1	30	9	0.312	0.089	0.82	0.043	0.039	0	50.3	49.5	70.5	148	144	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	1	40	9	0.272	0.131	0.82	0.033	0.03	0	50.7	49	70.5	148	144	0	30	30
2014	7	7	1	50	9	0.295	0.052	0.82	0.036	0.033	0	50.3	49.5	70.5	148	144	0	31	29
2014	7	7	2	0	9	0.22	0.118	0.82	0.039	0.036	0	49.9	48.6	71	147	143	0	31	30
2014	7	7	2	10	9	0.318	0.092	0.82	0.036	0.033	0	50.3	49	71	147	143	0	30	29
2014	7	7	2	20	9	0.312	0.131	0.82	0.043	0.039	0	49.9	49	70.5	146	143	0	30	29
2014	7	7	2	30	9	0.233	0.059	0.82	0.036	0.033	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	7	2	40	9	0.262	0.072	0.82	0.039	0.036	0	49.9	49	70.5	146	143	0	30	29
2014	7	7	2	50	9	0.249	0.121	0.82	0.039	0.036	0	50.3	48.6	71	147	142	0	30	29
2014	7	7	3	0	9	0.285	0.016	0.823	0.036	0.033	0	49	48.2	71.4	145	142	0	31	30
2014	7	7	3	10	9	0.285	0.023	0.823	0.036	0.033	0	49.5	49	70.5	146	143	0	31	29
2014	7	7	3	20	9	0.262	0.016	0.823	0.039	0.039	0	49.9	48.2	71	146	142	0	30	30
2014	7	7	3	30	9	0.295	-0.016	0.823	0.039	0.039	0	49.5	48.6	71	146	143	0	31	30
2014	7	7	3	40	9	0.318	0.016	0.823	0.039	0.036	0	49.9	49	70.1	147	144	0	31	30
2014	7	7	3	50	9	0.344	0	0.823	0.039	0.036	0	49.5	49	70.5	146	143	0	31	29
2014	7	7	4	0	9	0.266	0.066	0.823	0.036	0.033	0	49.9	48.6	70.1	147	142	0	31	29
2014	7	7	4	10	9	0.243	0.033	0.823	0.033	0.03	0	49.5	48.6	71	145	142	0	30	29
2014	7	7	4	20	9	0.233	0.016	0.823	0.036	0.033	0	49.5	48.6	70.5	145	142	0	30	29
2014	7	7	4	30	9	0.226	-0.01	0.823	0.043	0.043	0	49.5	48.2	71.4	145	141	0	30	29
2014	7	7	4	40	9	0.249	0.066	0.823	0.036	0.033	0	49.5	47.7	71	144	140	0	29	29
2014	7	7	4	50	9	0.364	0.085	0.823	0.036	0.033	0	49.5	48.2	71	145	142	0	30	30
2014	7	7	5	0	9	0.246	0.03	0.823	0.039	0.036	0	49.5	47.7	70.1	145	141	0	30	30
2014	7	7	5	10	9	0.233	-0.02	0.823	0.039	0.039	0	49	48.2	70.5	145	142	0	31	30
2014	7	7	5	20	9	0.295	-0.016	0.823	0.036	0.033	0	49.9	48.6	71	146	143	0	30	30
2014	7	7	5	30	9	0.236	0.016	0.823	0.033	0.033	0	49.5	48.2	70.1	145	142	0	30	30
2014	7	7	5	40	9	0.233	0.089	0.823	0.036	0.033	0	49.5	48.6	70.1	145	143	0	30	30
2014	7	7	5	50	9	0.272	-0.02	0.823	0.039	0.036	0	49.5	47.7	70.5	145	141	0	30	30
2014	7	7	6	0	9	0.322	0.036	0.823	0.039	0.039	0	49.9	48.6	70.1	146	142	0	30	29
2014	7	7	6	10	9	0.249	0.066	0.823	0.043	0.039	0	48.2	47.3	71.4	143	139	0	31	29
2014	7	7	6	20	9	0.292	0.036	0.823	0.033	0.03	0	49	47.7	70.5	144	141	0	30	30
2014	7	7	6	30	9	0.295	0.01	0.823	0.036	0.033	0	47.7	46.9	71.4	141	138	0	30	29
2014	7	7	6	40	9	0.259	-0.007	0.823	0.039	0.036	0	48.2	46.9	70.5	142	139	0	30	30
2014	7	7	6	50	9	0.292	0.036	0.823	0.033	0.03	0	48.6	47.3	70.1	143	140	0	30	30
2014	7	7	7	0	9	0.266	0.01	0.823	0.039	0.036	0	48.2	47.3	71	142	140	0	30	30
2014	7	7	7	10	9	0.243	0.138	0.823	0.036	0.033	0	48.2	46.9	71	143	139	0	31	30
2014	7	7	7	20	9	0.315	-0.062	0.827	0.039	0.036	0	47.7	46.9	72.2	141	139	0	30	30
2014	7	7	7	30	9	0.276	0.013	0.823	0.036	0.033	0	47.7	47.3	71.4	142	139	0	31	29
2014	7	7	7	40	9	0.259	0.112	0.823	0.039	0.036	0	48.2	47.3	71.4	142	139	0	30	29
2014	7	7	7	50	9	0.262	0.016	0.823	0.036	0.033	0	48.2	46.4	71	142	138	0	30	30
2014	7	7	8	0	9	0.243	0.01	0.827	0.043	0.039	0	48.2	46.9	70.5	143	139	0	31	30
2014	7	7	8	10	9	0.243	0	0.823	0.039	0.036	0	47.7	46.9	71	142	139	0	31	30
2014	7	7	8	20	9	0.24	0	0.823	0.033	0.03	0	47.7	46.4	70.5	141	138	0	30	30
2014	7	7	8	30	9	0.305	0.01	0.827	0.033	0.03	0	48.2	46.9	71	143	139	0	31	30
2014	7	7	8	40	9	0.312	0.066	0.827	0.039	0.036	0	46.9	46.4	71.4	140	138	0	31	30
2014	7	7	8	50	9	0.217	-0.01	0.823	0.036	0.033	0	48.2	46.9	71.4	142	139	0	30	30
2014	7	7	9	0	9	0.236	-0.02	0.823	0.033	0.03	0	46.9	46	71.4	140	137	0	31	30
2014	7	7	9	10	9	0.266	0.003	0.827	0.039	0.039	0	46.4	46	71.8	139	137	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	9	20	9	0.236	0.046	0.827	0.036	0.033	0	47.7	46	71.4	141	137	0	30	30
2014	7	7	9	30	9	0.299	0.049	0.823	0.039	0.036	0	46.4	46.4	71.8	139	138	0	31	30
2014	7	7	9	40	9	0.2	0.043	0.827	0.039	0.039	0	46.9	46	71	140	137	0	31	30
2014	7	7	9	50	9	0.315	0.02	0.827	0.036	0.033	0	46.4	45.6	72.2	138	136	0	30	30
2014	7	7	10	0	9	0.269	-0.007	0.827	0.039	0.036	0	46.4	45.2	71.8	138	135	0	30	30
2014	7	7	10	10	9	0.18	0.016	0.827	0.039	0.036	0	46.4	45.6	71.8	138	136	0	30	30
2014	7	7	10	20	9	0.325	0.095	0.827	0.036	0.033	0	45.6	45.6	71.8	137	136	0	31	30
2014	7	7	10	30	9	0.279	0	0.827	0.039	0.039	0	46	45.2	71.8	137	135	0	30	30
2014	7	7	10	40	9	0.259	-0.02	0.827	0.039	0.036	0	45.6	45.6	73.1	137	135	0	31	29
2014	7	7	10	50	9	0.292	0.016	0.827	0.039	0.039	0	46.9	45.6	71	140	136	0	31	30
2014	7	7	11	0	9	0.325	-0.02	0.827	0.033	0.03	0	46	45.6	72.2	138	136	0	31	30
2014	7	7	11	10	9	0.295	0.079	0.827	0.033	0.03	0	46.4	45.2	72.2	138	134	0	30	29
2014	7	7	11	20	9	0.203	0.01	0.827	0.043	0.043	0	46.4	46	72.7	139	136	0	31	29
2014	7	7	11	30	9	0.299	-0.026	0.827	0.036	0.033	0	46	45.6	71.4	138	136	0	31	30
2014	7	7	11	40	9	0.174	0	0.827	0.033	0.03	0	46.4	46	72.2	138	136	0	30	29
2014	7	7	11	50	9	0.282	-0.02	0.827	0.039	0.039	0	46.9	45.6	71.8	139	136	0	30	30
2014	7	7	12	0	9	0.194	0	0.827	0.039	0.036	0	46	45.2	72.2	138	134	0	31	29
2014	7	7	12	10	9	0.266	-0.036	0.827	0.033	0.033	0	46.4	46	71.8	139	137	0	31	30
2014	7	7	12	20	9	0.24	0.036	0.827	0.036	0.033	0	46.4	46	72.7	139	137	0	31	30
2014	7	7	12	30	9	0.266	-0.026	0.827	0.033	0.03	0	46	46	73.1	138	137	0	31	30
2014	7	7	12	40	9	0.282	0	0.827	0.033	0.03	0	46.9	46.4	72.2	140	138	0	31	30
2014	7	7	12	50	9	0.207	0.016	0.827	0.036	0.033	0	46.9	46	72.2	140	137	0	31	30
2014	7	7	13	0	9	0.279	0	0.827	0.036	0.033	0	46.4	46	72.2	139	136	0	31	29
2014	7	7	13	10	9	0.341	-0.023	0.827	0.039	0.039	0	47.3	46.4	72.2	140	137	0	30	29
2014	7	7	13	20	9	0.249	0.003	0.827	0.043	0.039	0	47.7	47.3	71.8	141	140	0	30	30
2014	7	7	13	30	9	0.322	-0.036	0.827	0.039	0.039	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	7	13	40	9	0.282	0.007	0.827	0.036	0.033	0	46.4	46	73.1	138	136	0	30	29
2014	7	7	13	50	9	0.305	0.066	0.827	0.039	0.036	0	48.2	46.9	72.7	142	139	0	30	30
2014	7	7	14	0	9	0.325	0.056	0.827	0.039	0.036	0	48.6	47.3	71.4	143	140	0	30	30
2014	7	7	14	10	9	0.285	-0.007	0.827	0.043	0.039	0	47.7	46.9	72.2	141	139	0	30	30
2014	7	7	14	20	9	0.259	0.085	0.827	0.039	0.036	0	48.2	48.2	72.7	142	141	0	30	29
2014	7	7	14	30	9	0.299	0.03	0.827	0.039	0.036	0	47.3	46.9	73.5	140	138	0	30	29
2014	7	7	14	40	9	0.279	0.059	0.827	0.033	0.03	0	48.6	47.7	71.8	143	140	0	30	29
2014	7	7	14	50	9	0.292	0.039	0.827	0.039	0.036	0	46.9	46.9	72.2	139	138	0	30	29
2014	7	7	15	0	9	0.272	0.049	0.827	0.039	0.036	0	46.4	46	73.5	138	137	0	30	30
2014	7	7	15	10	9	0.308	0.089	0.823	0.036	0.033	0	47.3	46	73.1	140	136	0	30	29
2014	7	7	15	20	9	0.299	0.148	0.827	0.039	0.039	0	46.9	46	73.1	138	137	0	29	30
2014	7	7	15	30	9	0.269	0.059	0.823	0.036	0.033	0	46.4	47.3	73.1	138	139	0	30	29
2014	7	7	15	40	9	0.322	0.007	0.823	0.036	0.033	0	48.2	47.3	73.5	142	139	0	30	29
2014	7	7	15	50	9	0.279	0.049	0.823	0.039	0.039	0	48.2	46.9	73.5	142	138	0	30	29
2014	7	7	16	0	9	0.269	0.082	0.823	0.036	0.033	0	49	47.7	72.2	144	140	0	30	29
2014	7	7	16	10	9	0.289	0.049	0.823	0.033	0.03	0	47.3	46.4	73.1	141	138	0	31	30
2014	7	7	16	20	9	0.249	0.072	0.823	0.033	0.03	0	47.7	46.4	74.8	140	137	0	29	29
2014	7	7	16	30	9	0.266	0.036	0.823	0.036	0.033	0	48.6	47.7	74	143	141	0	30	30
2014	7	7	16	40	9	0.262	0.095	0.823	0.039	0.039	0	48.2	47.3	73.5	142	139	0	30	29
2014	7	7	16	50	9	0.292	0.066	0.823	0.036	0.033	0	47.3	47.3	73.1	141	139	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	17	0	9	0.256	0.121	0.823	0.039	0.036	0	47.7	46.9	73.5	141	138	0	30	29
2014	7	7	17	10	9	0.276	0.056	0.823	0.033	0.03	0	47.7	47.3	74.4	141	139	0	30	29
2014	7	7	17	20	9	0.302	0.016	0.823	0.036	0.033	0	49	49	73.1	144	144	0	30	30
2014	7	7	17	30	9	0.266	0.102	0.823	0.036	0.033	0	48.2	47.3	74.4	141	138	0	29	28
2014	7	7	17	40	9	0.312	0.128	0.823	0.039	0.036	0	46.4	45.2	75.3	138	134	0	30	29
2014	7	7	17	50	9	0.253	0.056	0.823	0.039	0.036	0	46.9	45.6	74.4	139	135	0	30	29
2014	7	7	18	0	9	0.217	0.089	0.823	0.036	0.033	0	46.9	45.6	74.4	139	135	0	30	29
2014	7	7	18	10	9	0.249	0.079	0.82	0.036	0.033	0	46.9	46	74.4	139	136	0	30	29
2014	7	7	18	20	9	0.289	0.039	0.82	0.043	0.039	0	46.4	44.3	74.4	138	133	0	30	30
2014	7	7	18	30	9	0.262	0.121	0.82	0.036	0.033	0	46.4	45.2	74.4	138	134	0	30	29
2014	7	7	18	40	9	0.223	0.026	0.82	0.039	0.036	0	47.3	45.6	74	139	135	0	29	29
2014	7	7	18	50	9	0.226	-0.007	0.82	0.039	0.039	0	49.9	48.2	72.2	146	141	0	30	29
2014	7	7	19	0	9	0.233	0.036	0.82	0.036	0.033	0	49.5	47.3	71.8	145	139	0	30	29
2014	7	7	19	10	9	0.249	0.108	0.82	0.046	0.043	0	49.9	48.6	71.4	146	141	0	30	28
2014	7	7	19	20	9	0.315	0	0.82	0.046	0.043	0	50.3	48.6	70.5	147	142	0	30	29
2014	7	7	19	30	9	0.266	0.039	0.82	0.039	0.036	0	48.6	46.9	72.7	143	138	0	30	29
2014	7	7	19	40	9	0.305	-0.007	0.82	0.039	0.039	0	48.6	47.3	72.7	143	139	0	30	29
2014	7	7	19	50	9	0.207	0.02	0.82	0.039	0.036	0	50.7	48.2	70.1	148	142	0	30	30
2014	7	7	20	0	9	0.207	-0.003	0.82	0.043	0.039	0	50.7	49.5	67.9	148	144	0	30	29
2014	7	7	20	10	9	0.233	0.01	0.82	0.043	0.039	0	51.2	49	68.8	149	143	0	30	29
2014	7	7	20	20	9	0.207	-0.003	0.82	0.039	0.036	0	50.7	49.5	68.4	148	144	0	30	29
2014	7	7	20	30	9	0.305	-0.052	0.817	0.033	0.03	0	51.2	49.5	69.7	150	144	0	31	29
2014	7	7	20	40	9	0.253	0	0.82	0.039	0.036	0	51.2	49.9	68.4	150	145	0	31	29
2014	7	7	20	50	9	0.253	0	0.817	0.039	0.036	0	51.6	49	68.4	150	144	0	30	30
2014	7	7	21	0	9	0.217	0.003	0.82	0.036	0.033	0	50.3	48.6	70.1	147	142	0	30	29
2014	7	7	21	10	9	0.217	-0.016	0.82	0.046	0.043	0	49.5	48.6	71	145	142	0	30	29
2014	7	7	21	20	9	0.233	0	0.82	0.039	0.039	0	49.9	48.6	71.4	147	142	0	31	29
2014	7	7	21	30	9	0.233	0	0.82	0.039	0.039	0	49.9	48.2	70.5	146	142	0	30	30
2014	7	7	21	40	9	0.213	-0.036	0.82	0.039	0.036	0	49.9	47.7	70.1	146	141	0	30	30
2014	7	7	21	50	9	0.246	-0.02	0.82	0.036	0.033	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	7	22	0	9	0.213	-0.02	0.82	0.039	0.039	0	49.5	48.2	71.4	145	141	0	30	29
2014	7	7	22	10	9	0.213	-0.007	0.82	0.036	0.033	0	49.9	48.6	70.1	146	142	0	30	29
2014	7	7	22	20	9	0.19	-0.033	0.82	0.036	0.033	0	50.3	48.2	70.1	147	142	0	30	30
2014	7	7	22	30	9	0.279	-0.003	0.82	0.036	0.033	0	50.3	48.6	70.1	147	143	0	30	30
2014	7	7	22	40	9	0.259	-0.02	0.82	0.036	0.033	0	50.3	49.5	69.2	147	144	0	30	29
2014	7	7	22	50	9	0.2	-0.016	0.82	0.033	0.03	0	49.9	47.7	71	146	141	0	30	30
2014	7	7	23	0	9	0.276	0	0.82	0.039	0.036	0	49.5	47.7	71	145	141	0	30	30
2014	7	7	23	10	9	0.249	0.059	0.82	0.039	0.036	0	49.5	47.7	71.4	145	141	0	30	30
2014	7	7	23	20	9	0.236	-0.046	0.82	0.036	0.033	0	49.5	47.7	70.5	145	141	0	30	30
2014	7	7	23	30	9	0.223	-0.056	0.82	0.046	0.046	0	49	48.2	71	144	141	0	30	29
2014	7	7	23	40	9	0.259	-0.007	0.82	0.033	0.03	0	48.6	47.7	71	144	141	0	31	30
2014	7	7	23	50	9	0.282	0	0.82	0.036	0.033	0	49	47.3	71	144	140	0	30	30
2014	7	8	0	0	9	0.249	0.059	0.82	0.036	0.033	0	49.5	48.6	70.1	146	143	0	31	30
2014	7	8	0	10	9	0.233	0.01	0.82	0.033	0.03	0	49.9	49	70.1	146	143	0	30	29
2014	7	8	0	20	9	0.282	-0.003	0.82	0.043	0.039	0	50.3	49	69.7	147	143	0	30	29
2014	7	8	0	30	9	0.266	0	0.82	0.039	0.039	0	49.5	48.6	70.1	146	142	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	0	40	9	0.272	0.016	0.82	0.039	0.036	0	49.5	48.2	70.5	145	142	0	30	30
2014	7	8	0	50	9	0.243	0	0.82	0.039	0.039	0	49	48.2	70.5	145	141	0	31	29
2014	7	8	1	0	9	0.262	0.102	0.82	0.039	0.036	0	48.6	47.7	70.5	144	141	0	31	30
2014	7	8	1	10	9	0.282	0.066	0.82	0.039	0.036	0	48.6	47.7	70.1	143	141	0	30	30
2014	7	8	1	20	9	0.236	0.039	0.82	0.036	0.033	0	49	47.7	70.5	144	141	0	30	30
2014	7	8	1	30	9	0.285	0.03	0.82	0.039	0.039	0	49	47.3	70.1	144	140	0	30	30
2014	7	8	1	40	9	0.23	0.007	0.82	0.039	0.039	0	49	48.2	69.7	145	141	0	31	29
2014	7	8	1	50	9	0.259	-0.036	0.82	0.043	0.039	0	49.5	48.6	71	145	143	0	30	30
2014	7	8	2	0	9	0.299	-0.007	0.82	0.039	0.036	0	49.5	47.7	70.5	145	141	0	30	30
2014	7	8	2	10	9	0.299	-0.016	0.82	0.039	0.036	0	49.5	48.2	70.1	145	142	0	30	30
2014	7	8	2	20	9	0.269	-0.007	0.82	0.039	0.036	0	49	48.2	71	144	141	0	30	29
2014	7	8	2	30	9	0.226	0	0.82	0.036	0.033	0	49.5	48.2	68.8	146	142	0	31	30
2014	7	8	2	40	9	0.266	-0.026	0.82	0.039	0.039	0	49.9	48.2	69.2	146	142	0	30	30
2014	7	8	2	50	9	0.285	-0.013	0.82	0.043	0.039	0	49.5	48.2	69.7	146	142	0	31	30
2014	7	8	3	0	9	0.223	0.072	0.82	0.039	0.039	0	49	48.6	70.1	145	143	0	31	30
2014	7	8	3	10	9	0.282	-0.059	0.82	0.039	0.039	0	49	48.2	69.7	144	141	0	30	29
2014	7	8	3	20	9	0.302	0.016	0.82	0.039	0.039	0	48.6	48.2	69.2	144	142	0	31	30
2014	7	8	3	30	9	0.256	0.049	0.82	0.036	0.033	0	48.6	47.7	69.7	144	141	0	31	30
2014	7	8	3	40	9	0.253	0.056	0.82	0.039	0.036	0	49.5	48.2	69.2	146	142	0	31	30
2014	7	8	3	50	9	0.295	0.003	0.82	0.039	0.036	0	49	48.2	71	145	142	0	31	30
2014	7	8	4	0	9	0.351	0.043	0.82	0.036	0.033	0	49	48.6	70.1	145	142	0	31	29
2014	7	8	4	10	9	0.2	-0.007	0.82	0.039	0.036	0	49	48.2	70.1	145	142	0	31	30
2014	7	8	4	20	9	0.174	0.013	0.823	0.033	0.03	0	49	47.7	70.5	144	141	0	30	30
2014	7	8	4	30	9	0.197	-0.023	0.823	0.033	0.033	0	49	47.7	70.1	144	141	0	30	30
2014	7	8	4	40	9	0.305	0.069	0.823	0.039	0.036	0	49	48.2	70.1	144	142	0	30	30
2014	7	8	4	50	9	0.259	0.01	0.823	0.036	0.033	0	48.6	47.7	70.5	144	141	0	31	30
2014	7	8	5	0	9	0.289	-0.01	0.823	0.036	0.033	0	48.6	47.7	70.1	144	141	0	31	30
2014	7	8	5	10	9	0.354	0.016	0.823	0.039	0.036	0	49	48.2	70.1	145	142	0	31	30
2014	7	8	5	20	9	0.262	0	0.823	0.036	0.033	0	48.2	47.3	70.1	143	139	0	31	29
2014	7	8	5	30	9	0.322	-0.056	0.823	0.033	0.03	0	49.9	48.6	69.2	146	143	0	30	30
2014	7	8	5	40	9	0.22	0.062	0.823	0.036	0.033	0	49	48.2	68.8	144	142	0	30	30
2014	7	8	5	50	9	0.292	0	0.823	0.039	0.036	0	50.3	49	68.4	147	143	0	30	29
2014	7	8	6	0	9	0.276	0	0.823	0.039	0.036	0	50.3	49	67.5	148	144	0	31	30
2014	7	8	6	10	9	0.276	-0.072	0.823	0.039	0.036	0	49.9	49	68.4	147	144	0	31	30
2014	7	8	6	20	9	0.243	0.02	0.823	0.049	0.046	0	50.3	49	67.9	148	144	0	31	30
2014	7	8	6	30	9	0.236	0.003	0.823	0.039	0.036	0	50.7	49.5	67.5	149	145	0	31	30
2014	7	8	6	40	9	0.269	-0.108	0.823	0.039	0.036	0	51.2	49	67.5	149	144	0	30	30
2014	7	8	6	50	9	0.243	-0.039	0.823	0.046	0.046	0	50.3	49	67.1	148	144	0	31	30
2014	7	8	7	0	9	0.246	0.03	0.823	0.039	0.036	0	49.5	47.7	68.4	146	141	0	31	30
2014	7	8	7	10	9	0.243	-0.033	0.823	0.039	0.036	0	50.7	49.5	66.7	149	145	0	31	30
2014	7	8	7	20	9	0.282	0.043	0.823	0.036	0.033	0	49.9	48.2	67.5	147	142	0	31	30
2014	7	8	7	30	9	0.259	-0.043	0.823	0.039	0.039	0	50.7	49	67.5	148	144	0	30	30
2014	7	8	7	40	9	0.312	-0.01	0.823	0.039	0.039	0	49.9	48.6	67.9	147	143	0	31	30
2014	7	8	7	50	9	0.246	0.036	0.823	0.046	0.043	0	49.9	49	67.5	147	144	0	31	30
2014	7	8	8	0	9	0.207	0	0.823	0.043	0.039	0	51.2	49.5	67.5	150	145	0	31	30
2014	7	8	8	10	9	0.249	0.066	0.823	0.039	0.039	0	52	50.7	65.8	151	148	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	8	20	9	0.213	-0.03	0.823	0.043	0.039	0	51.6	49.9	66.7	151	146	0	31	30
2014	7	8	8	30	9	0.243	0.049	0.823	0.039	0.036	0	51.2	49.9	67.1	150	146	0	31	30
2014	7	8	8	40	9	0.285	0.062	0.823	0.039	0.036	0	50.7	49	67.9	148	144	0	30	30
2014	7	8	8	50	9	0.279	-0.013	0.823	0.043	0.039	0	50.7	49.5	66.7	149	145	0	31	30
2014	7	8	9	0	9	0.249	0.003	0.823	0.039	0.036	0	49.5	47.7	69.2	145	141	0	30	30
2014	7	8	9	10	9	0.295	0.003	0.823	0.039	0.039	0	48.2	46.4	70.5	142	139	0	30	31
2014	7	8	9	20	9	0.22	0.026	0.823	0.036	0.033	0	47.7	46.4	71	142	138	0	31	30
2014	7	8	9	30	9	0.276	0.079	0.823	0.039	0.036	0	47.7	46.4	71.4	141	137	0	30	29
2014	7	8	9	40	9	0.276	-0.056	0.823	0.033	0.03	0	48.2	46	70.5	142	137	0	30	30
2014	7	8	9	50	9	0.272	0	0.823	0.039	0.036	0	46.4	46	71.8	139	137	0	31	30
2014	7	8	10	0	9	0.282	-0.043	0.823	0.039	0.036	0	46.9	45.6	72.7	140	136	0	31	30
2014	7	8	10	10	9	0.325	0.056	0.823	0.039	0.039	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	8	10	20	9	0.295	0.016	0.823	0.039	0.036	0	47.3	46.9	72.2	140	138	0	30	29
2014	7	8	10	30	9	0.318	-0.036	0.823	0.036	0.033	0	46.4	46	73.1	139	137	0	31	30
2014	7	8	10	40	9	0.308	0	0.823	0.039	0.036	0	46.9	46.9	72.2	140	139	0	31	30
2014	7	8	10	50	9	0.266	-0.043	0.823	0.036	0.033	0	47.3	47.7	72.7	141	141	0	31	30
2014	7	8	11	0	9	0.299	0.052	0.823	0.043	0.039	0	49	48.2	70.5	145	142	0	31	30
2014	7	8	11	10	9	0.243	-0.02	0.823	0.036	0.033	0	48.6	47.3	72.2	143	140	0	30	30
2014	7	8	11	20	9	0.299	0.007	0.823	0.036	0.033	0	49.5	49.5	72.2	145	144	0	30	29
2014	7	8	11	30	9	0.282	0.03	0.823	0.033	0.03	0	48.6	49	71.8	144	143	0	31	29
2014	7	8	11	40	9	0.279	-0.01	0.823	0.039	0.039	0	49.5	48.6	72.2	146	143	0	31	30
2014	7	8	11	50	9	0.246	-0.003	0.82	0.033	0.03	0	50.7	49	71.4	148	144	0	30	30
2014	7	8	12	0	9	0.322	0.03	0.82	0.03	0.03	0	49.5	49	72.2	145	144	0	30	30
2014	7	8	12	10	9	0.272	0.026	0.82	0.036	0.033	0	49.5	49	72.2	146	143	0	31	29
2014	7	8	12	20	9	0.302	0.03	0.82	0.036	0.033	0	49.5	49.5	72.2	145	144	0	30	29
2014	7	8	12	30	9	0.308	0.079	0.82	0.039	0.036	0	49.9	49.5	72.2	146	144	0	30	29
2014	7	8	12	40	9	0.246	0.043	0.82	0.039	0.036	0	49	49.5	71.4	145	145	0	31	30
2014	7	8	12	50	9	0.302	0.003	0.82	0.036	0.033	0	50.3	49.9	71	147	146	0	30	30
2014	7	8	13	0	9	0.259	0.03	0.82	0.033	0.03	0	51.2	50.7	71	149	148	0	30	30
2014	7	8	13	10	9	0.308	0.056	0.82	0.033	0.03	0	51.2	51.6	71	149	148	0	30	28
2014	7	8	13	20	9	0.276	0.095	0.82	0.036	0.033	0	50.3	50.3	70.5	148	146	0	31	29
2014	7	8	13	30	9	0.243	-0.013	0.82	0.039	0.039	0	49.5	48.2	71	145	142	0	30	30
2014	7	8	13	40	9	0.282	0.118	0.82	0.039	0.036	0	49.5	48.2	71.4	145	142	0	30	30
2014	7	8	13	50	9	0.276	0.072	0.82	0.039	0.036	0	50.3	49.9	71.8	147	145	0	30	29
2014	7	8	14	0	9	0.292	0.03	0.82	0.039	0.036	0	51.6	50.3	71	150	147	0	30	30
2014	7	8	14	10	9	0.249	0.03	0.817	0.039	0.036	0	54.6	52.9	66.2	157	153	0	30	30
2014	7	8	14	20	9	0.292	0.039	0.817	0.043	0.039	0	49.9	49.5	71	145	144	0	29	29
2014	7	8	14	30	9	0.256	0.036	0.817	0.036	0.033	0	50.3	48.6	69.7	147	143	0	30	30
2014	7	8	14	40	9	0.285	0.056	0.817	0.036	0.033	0	49.5	48.6	70.5	146	142	0	31	29
2014	7	8	14	50	9	0.272	0.02	0.817	0.036	0.033	0	51.2	49.9	69.7	149	145	0	30	29
2014	7	8	15	0	9	0.285	0.072	0.817	0.036	0.033	0	49.9	49.5	68.4	146	144	0	30	29
2014	7	8	15	10	9	0.348	0.03	0.814	0.033	0.03	0	52.9	51.6	66.7	152	149	0	29	29
2014	7	8	15	20	9	0.338	0.052	0.814	0.039	0.036	0	53.3	52.5	64.9	154	151	0	30	29
2014	7	8	15	30	9	0.331	0.052	0.814	0.036	0.033	0	53.3	51.6	66.2	153	149	0	29	29
2014	7	8	15	40	9	0.243	0.085	0.814	0.036	0.033	0	52.9	51.6	66.2	153	149	0	30	29
2014	7	8	15	50	9	0.285	0.105	0.814	0.036	0.033	0	51.6	50.3	68.4	150	147	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	16	0	9	0.217	0.072	0.814	0.039	0.036	0	52	50.7	66.2	151	148	0	30	30
2014	7	8	16	10	9	0.217	-0.056	0.81	0.033	0.03	0	52	49.9	66.7	151	146	0	30	30
2014	7	8	16	20	9	0.233	0	0.81	0.039	0.039	0	50.7	49.5	67.1	148	144	0	30	29
2014	7	8	16	30	9	0.253	0.026	0.81	0.033	0.03	0	51.2	49.9	67.5	149	145	0	30	29
2014	7	8	16	40	9	0.256	0.003	0.81	0.039	0.036	0	50.7	49.9	68.4	148	145	0	30	29
2014	7	8	16	50	9	0.24	0.066	0.81	0.043	0.039	0	50.3	49	68.8	147	143	0	30	29
2014	7	8	17	0	9	0.259	0.148	0.81	0.039	0.036	0	51.6	50.7	67.5	150	147	0	30	29
2014	7	8	17	10	9	0.246	0.105	0.814	0.046	0.043	0	49.5	49.5	68.4	145	144	0	30	29
2014	7	8	17	20	9	0.262	0.135	0.814	0.036	0.033	0	50.3	49.9	68.8	147	145	0	30	29
2014	7	8	17	30	9	0.272	0.072	0.81	0.039	0.036	0	51.2	50.3	67.9	149	146	0	30	29
2014	7	8	17	40	9	0.259	0.125	0.814	0.039	0.036	0	49.9	49	68.8	146	143	0	30	29
2014	7	8	17	50	9	0.269	0.075	0.814	0.036	0.033	0	48.6	47.3	70.5	143	139	0	30	29
2014	7	8	18	0	9	0.213	0.079	0.81	0.033	0.03	0	48.2	47.7	69.7	142	140	0	30	29
2014	7	8	18	10	9	0.194	0.056	0.804	0.036	0.033	0	52.9	51.2	62.8	153	148	0	30	29
2014	7	8	18	20	9	0.276	0.079	0.807	0.043	0.039	0	52.5	50.7	62.4	152	147	0	30	29
2014	7	8	18	30	9	0.21	0.085	0.807	0.039	0.036	0	52.5	51.2	63.2	152	148	0	30	29
2014	7	8	18	40	9	0.223	0.036	0.807	0.039	0.039	0	52.5	50.7	63.2	152	147	0	30	29
2014	7	8	18	50	9	0.217	0.112	0.807	0.043	0.039	0	52	49.9	63.6	150	146	0	29	30
2014	7	8	19	0	9	0.272	0.085	0.804	0.039	0.036	0	52	51.2	63.6	151	148	0	30	29
2014	7	8	19	10	9	0.279	0.072	0.804	0.039	0.039	0	51.2	49.9	64.5	149	145	0	30	29
2014	7	8	19	20	9	0.213	0.062	0.804	0.036	0.033	0	50.7	49.5	65.4	148	144	0	30	29
2014	7	8	19	30	9	0.312	0.056	0.807	0.039	0.036	0	49.9	49	67.1	146	143	0	30	29
2014	7	8	19	40	9	0.285	0.072	0.804	0.039	0.039	0	50.3	48.6	66.7	147	142	0	30	29
2014	7	8	19	50	9	0.295	0.036	0.804	0.036	0.033	0	51.2	49.9	64.9	150	145	0	31	29
2014	7	8	20	0	9	0.246	0.075	0.804	0.039	0.036	0	49.9	49	63.6	146	143	0	30	29
2014	7	8	20	10	9	0.276	0.069	0.804	0.039	0.036	0	50.7	49.5	66.2	148	143	0	30	28
2014	7	8	20	20	9	0.138	-0.016	0.801	0.033	0.03	0	51.2	49.9	63.6	149	145	0	30	29
2014	7	8	20	30	9	0.23	-0.098	0.804	0.036	0.033	0	52.5	51.2	63.2	152	148	0	30	29
2014	7	8	20	40	9	0.262	0.01	0.804	0.036	0.033	0	53.8	52	62.4	155	150	0	30	29
2014	7	8	20	50	9	0.171	-0.033	0.807	0.036	0.033	0	52.9	51.2	62.8	153	149	0	30	30
2014	7	8	21	0	9	0.226	0.026	0.807	0.046	0.043	0	53.8	52	62.8	155	150	0	30	29
2014	7	8	21	10	9	0.246	0	0.807	0.039	0.039	0	52.9	51.2	63.6	153	149	0	30	30
2014	7	8	21	20	9	0.285	0.118	0.807	0.049	0.046	0	53.3	52	64.1	154	150	0	30	29
2014	7	8	21	30	9	0.138	-0.043	0.807	0.033	0.03	0	52.9	50.7	64.5	153	148	0	30	30
2014	7	8	21	40	9	0.226	-0.023	0.81	0.046	0.043	0	52.9	51.6	64.9	153	149	0	30	29
2014	7	8	21	50	9	0.276	0	0.81	0.043	0.039	0	53.3	51.6	65.4	154	149	0	30	29
2014	7	8	22	0	9	0.276	-0.02	0.81	0.039	0.036	0	53.8	52	65.4	155	150	0	30	29
2014	7	8	22	10	9	0.246	0.023	0.81	0.043	0.039	0	52.9	50.7	65.8	153	148	0	30	30
2014	7	8	22	20	9	0.233	-0.082	0.81	0.039	0.039	0	52.5	50.3	66.2	152	148	0	30	31
2014	7	8	22	30	9	0.2	-0.003	0.81	0.043	0.039	0	52.9	51.2	66.2	153	149	0	30	30
2014	7	8	22	40	9	0.233	0.016	0.814	0.039	0.036	0	53.8	52	66.2	155	150	0	30	29
2014	7	8	22	50	9	0.269	-0.023	0.814	0.039	0.036	0	53.3	51.6	67.1	154	150	0	30	30
2014	7	8	23	0	9	0.174	-0.036	0.814	0.039	0.036	0	52.9	51.2	65.8	153	149	0	30	30
2014	7	8	23	10	9	0.249	-0.059	0.814	0.043	0.039	0	53.3	51.6	67.1	154	150	0	30	30
2014	7	8	23	20	9	0.236	-0.013	0.814	0.039	0.036	0	51.6	50.7	68.8	151	147	0	31	29
2014	7	8	23	30	9	0.256	-0.036	0.814	0.036	0.033	0	52.5	51.2	67.5	152	149	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	23	40	9	0.335	-0.062	0.814	0.033	0.03	0	51.6	50.3	68.4	150	146	0	30	29
2014	7	8	23	50	9	0.233	-0.016	0.817	0.049	0.049	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	9	0	0	9	0.318	0.007	0.817	0.039	0.036	0	50.3	49.5	69.7	148	144	0	31	29
2014	7	9	0	10	9	0.262	0	0.817	0.036	0.033	0	50.3	49.5	68.8	148	145	0	31	30
2014	7	9	0	20	9	0.233	-0.036	0.817	0.036	0.033	0	50.7	49	69.2	148	144	0	30	30
2014	7	9	0	30	9	0.262	0.013	0.817	0.043	0.043	0	50.3	49.5	70.1	147	145	0	30	30
2014	7	9	0	40	9	0.259	0.036	0.817	0.039	0.039	0	50.7	49	68.8	148	144	0	30	30
2014	7	9	0	50	9	0.253	-0.013	0.817	0.036	0.033	0	50.3	49.5	69.7	148	145	0	31	30
2014	7	9	1	0	9	0.23	-0.02	0.817	0.043	0.039	0	50.3	49	68.8	148	144	0	31	30
2014	7	9	1	10	9	0.308	0.007	0.817	0.033	0.03	0	50.3	49	69.7	147	144	0	30	30
2014	7	9	1	20	9	0.279	-0.056	0.817	0.036	0.033	0	50.3	48.6	69.2	147	143	0	30	30
2014	7	9	1	30	9	0.171	0.003	0.817	0.033	0.03	0	50.7	49.5	69.2	148	144	0	30	29
2014	7	9	1	40	9	0.282	0.003	0.817	0.036	0.033	0	51.6	49.9	68.8	150	146	0	30	30
2014	7	9	1	50	9	0.164	0.007	0.817	0.043	0.039	0	50.7	49.5	68.4	149	145	0	31	30
2014	7	9	2	0	9	0.318	-0.007	0.817	0.036	0.033	0	50.7	49	69.2	148	144	0	30	30
2014	7	9	2	10	9	0.272	0.016	0.817	0.033	0.03	0	50.3	49.5	70.1	148	145	0	31	30
2014	7	9	2	20	9	0.259	-0.026	0.817	0.036	0.033	0	50.7	48.6	69.7	148	143	0	30	30
2014	7	9	2	30	9	0.256	0.033	0.817	0.039	0.036	0	49.5	49	71	146	144	0	31	30
2014	7	9	2	40	9	0.259	-0.036	0.817	0.036	0.033	0	49.9	49	70.1	147	144	0	31	30
2014	7	9	2	50	9	0.308	0.056	0.817	0.039	0.036	0	49.5	48.6	70.5	146	143	0	31	30
2014	7	9	3	0	9	0.226	0.092	0.817	0.043	0.039	0	49.9	48.6	71	147	143	0	31	30
2014	7	9	3	10	9	0.256	-0.056	0.817	0.039	0.036	0	49.9	49	71	147	144	0	31	30
2014	7	9	3	20	9	0.256	0.049	0.817	0.039	0.039	0	49.9	48.6	70.1	147	144	0	31	31
2014	7	9	3	30	9	0.256	-0.02	0.817	0.039	0.036	0	49.9	48.6	70.1	146	143	0	30	30
2014	7	9	3	40	9	0.292	0.013	0.817	0.039	0.036	0	49.9	48.6	70.5	146	143	0	30	30
2014	7	9	3	50	9	0.203	0.069	0.817	0.039	0.039	0	49.9	48.6	70.5	147	143	0	31	30
2014	7	9	4	0	9	0.243	-0.049	0.817	0.036	0.033	0	49	48.2	71.4	145	142	0	31	30
2014	7	9	4	10	9	0.256	0	0.82	0.043	0.039	0	49.9	49	71	146	143	0	30	29
2014	7	9	4	20	9	0.207	-0.013	0.817	0.039	0.036	0	49	48.2	71	145	142	0	31	30
2014	7	9	4	30	9	0.262	0.072	0.82	0.036	0.033	0	49.5	48.6	71.4	145	143	0	30	30
2014	7	9	4	40	9	0.226	0.036	0.817	0.039	0.036	0	49	48.6	71.4	145	143	0	31	30
2014	7	9	4	50	9	0.266	-0.016	0.817	0.039	0.036	0	49	48.6	71	145	142	0	31	29
2014	7	9	5	0	9	0.276	0	0.817	0.049	0.049	0	49.5	48.6	70.1	146	143	0	31	30
2014	7	9	5	10	9	0.236	0.026	0.817	0.039	0.036	0	49.5	48.6	70.5	146	143	0	31	30
2014	7	9	5	20	9	0.217	-0.102	0.817	0.036	0.033	0	49.9	49	70.5	147	144	0	31	30
2014	7	9	5	30	9	0.279	0.007	0.817	0.039	0.036	0	49.5	48.2	70.5	146	142	0	31	30
2014	7	9	5	40	9	0.308	0.016	0.817	0.036	0.033	0	49.9	48.6	70.5	146	143	0	30	30
2014	7	9	5	50	9	0.272	0.033	0.817	0.039	0.036	0	49.9	48.6	69.2	147	143	0	31	30
2014	7	9	6	0	9	0.272	-0.03	0.817	0.043	0.039	0	50.3	48.6	69.2	148	144	0	31	31
2014	7	9	6	10	9	0.194	-0.026	0.817	0.036	0.033	0	50.3	48.6	70.1	148	143	0	31	30
2014	7	9	6	20	9	0.282	0.066	0.817	0.043	0.039	0	49.9	48.6	69.2	147	143	0	31	30
2014	7	9	6	30	9	0.269	0.046	0.817	0.043	0.039	0	50.3	49	70.1	147	144	0	30	30
2014	7	9	6	40	9	0.246	0.03	0.817	0.039	0.039	0	49.9	49	70.1	147	143	0	31	29
2014	7	9	6	50	9	0.259	0.059	0.817	0.039	0.036	0	49.5	48.2	69.7	146	142	0	31	30
2014	7	9	7	0	9	0.272	0	0.817	0.033	0.03	0	50.3	49	69.2	147	144	0	30	30
2014	7	9	7	10	9	0.282	0.02	0.817	0.039	0.039	0	50.7	49.5	69.7	149	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	7	20	9	0.23	0	0.817	0.036	0.033	0	49.5	48.6	70.1	146	143	0	31	30
2014	7	9	7	30	9	0.266	-0.036	0.817	0.043	0.039	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	9	7	40	9	0.246	0	0.817	0.033	0.03	0	49.5	48.2	70.5	146	142	0	31	30
2014	7	9	7	50	9	0.171	-0.01	0.817	0.039	0.039	0	49.5	48.2	70.1	146	142	0	31	30
2014	7	9	8	0	9	0.312	-0.007	0.817	0.039	0.039	0	50.3	49	69.2	148	144	0	31	30
2014	7	9	8	10	9	0.285	-0.007	0.817	0.039	0.036	0	49.9	48.2	70.5	147	142	0	31	30
2014	7	9	8	20	9	0.269	0.033	0.817	0.039	0.036	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	9	8	30	9	0.226	-0.016	0.817	0.049	0.049	0	49	47.7	71.4	144	141	0	30	30
2014	7	9	8	40	9	0.292	0.066	0.817	0.036	0.033	0	49.9	48.6	70.1	146	143	0	30	30
2014	7	9	8	50	9	0.161	0.01	0.82	0.039	0.039	0	58	55	47.7	166	157	0	31	29
2014	7	9	9	0	9	0.305	-0.003	0.823	0.039	0.036	0	49.9	48.2	66.7	147	142	0	31	30
2014	7	9	9	10	9	0.203	0.069	0.823	0.039	0.039	0	48.2	47.7	70.1	143	141	0	31	30
2014	7	9	9	20	9	0.289	-0.026	0.823	0.039	0.039	0	49.5	48.2	69.2	146	142	0	31	30
2014	7	9	9	30	9	0.308	0.007	0.82	0.039	0.036	0	50.7	49	69.2	148	144	0	30	30
2014	7	9	9	40	9	0.344	-0.026	0.82	0.039	0.039	0	49.9	48.6	70.5	147	143	0	31	30
2014	7	9	9	50	9	0.236	-0.036	0.82	0.039	0.039	0	49	47.7	70.5	145	142	0	31	31
2014	7	9	10	0	9	0.292	0	0.82	0.039	0.036	0	50.7	49	69.7	148	144	0	30	30
2014	7	9	10	10	9	0.331	0.036	0.82	0.039	0.036	0	49.9	48.6	70.5	146	143	0	30	30
2014	7	9	10	20	9	0.22	0	0.82	0.033	0.03	0	49.5	48.6	70.5	146	143	0	31	30
2014	7	9	10	30	9	0.262	0.039	0.82	0.039	0.039	0	51.2	49	69.2	149	144	0	30	30
2014	7	9	10	40	9	0.315	0.01	0.82	0.043	0.039	0	50.7	49	69.7	149	144	0	31	30
2014	7	9	10	50	9	0.203	-0.039	0.82	0.039	0.036	0	49.9	49	70.5	147	143	0	31	29
2014	7	9	11	0	9	0.285	0.007	0.82	0.039	0.039	0	51.6	49.9	69.2	151	146	0	31	30
2014	7	9	11	10	9	0.226	-0.003	0.82	0.036	0.033	0	51.2	49	70.1	149	144	0	30	30
2014	7	9	11	20	9	0.279	-0.02	0.82	0.036	0.033	0	49.9	48.6	71.4	147	143	0	31	30
2014	7	9	11	30	9	0.289	-0.033	0.82	0.039	0.036	0	49	48.2	72.2	145	141	0	31	29
2014	7	9	11	40	9	0.305	0.052	0.82	0.039	0.036	0	49.9	49	71.8	147	144	0	31	30
2014	7	9	11	50	9	0.23	0.039	0.82	0.036	0.033	0	50.3	48.6	71.4	148	143	0	31	30
2014	7	9	12	0	9	0.223	0.075	0.817	0.036	0.033	0	50.7	49	71.8	148	144	0	30	30
2014	7	9	12	10	9	0.24	0.089	0.817	0.036	0.033	0	51.2	49	72.2	149	144	0	30	30
2014	7	9	12	20	9	0.207	0.092	0.817	0.036	0.033	0	50.3	49	72.7	148	143	0	31	29
2014	7	9	12	30	9	0.285	0.052	0.82	0.036	0.033	0	50.7	48.6	71.8	149	143	0	31	30
2014	7	9	12	40	9	0.246	0.039	0.82	0.036	0.033	0	50.7	48.6	73.5	148	142	0	30	29
2014	7	9	12	50	9	0.194	0.033	0.817	0.036	0.033	0	50.7	48.6	73.1	148	143	0	30	30
2014	7	9	13	0	9	0.335	0	0.817	0.033	0.03	0	50.3	48.2	73.1	148	142	0	31	30
2014	7	9	13	10	9	0.312	0.003	0.817	0.033	0.03	0	50.3	48.6	72.7	147	143	0	30	30
2014	7	9	13	20	9	0.259	0	0.817	0.033	0.03	0	50.7	49	72.2	148	144	0	30	30
2014	7	9	13	30	9	0.259	0.046	0.817	0.039	0.036	0	50.3	49	71.8	148	143	0	31	29
2014	7	9	13	40	9	0.236	0.085	0.817	0.039	0.036	0	50.7	49	71	149	143	0	31	29
2014	7	9	13	50	9	0.259	0.023	0.817	0.039	0.036	0	52	49.5	70.1	151	144	0	30	29
2014	7	9	14	0	9	0.246	0.043	0.817	0.033	0.03	0	52	49.5	70.1	151	144	0	30	29
2014	7	9	14	10	9	0.272	-0.059	0.817	0.033	0.03	0	50.7	49	71.4	148	143	0	30	29
2014	7	9	14	20	9	0.233	-0.072	0.814	0.036	0.033	0	49.9	48.2	71	146	142	0	30	30
2014	7	9	14	30	9	0.315	0.082	0.814	0.043	0.043	0	51.6	49	70.5	150	143	0	30	29
2014	7	9	14	40	9	0.213	0.075	0.814	0.039	0.039	0	50.3	47.7	70.5	147	140	0	30	29
2014	7	9	14	50	9	0.325	0.059	0.814	0.033	0.03	0	51.2	49	68.4	150	143	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	15	0	9	0.315	0.118	0.81	0.039	0.036	0	52	50.7	66.2	151	147	0	30	29
2014	7	9	15	10	9	0.276	-0.03	0.814	0.033	0.03	0	51.2	48.2	68.4	149	142	0	30	30
2014	7	9	15	20	9	0.207	0.079	0.81	0.039	0.036	0	53.3	49.5	67.9	154	144	0	30	29
2014	7	9	15	30	9	0.276	0.059	0.814	0.039	0.036	0	52.5	49.9	68.4	152	145	0	30	29
2014	7	9	15	40	9	0.249	0.03	0.81	0.033	0.03	0	52.9	49.9	68.4	153	145	0	30	29
2014	7	9	15	50	9	0.259	0.095	0.81	0.039	0.036	0	50.7	48.2	69.2	148	141	0	30	29
2014	7	9	16	0	9	0.233	0.052	0.81	0.039	0.036	0	51.6	48.6	69.2	149	142	0	29	29
2014	7	9	16	10	9	0.246	0.049	0.81	0.039	0.036	0	51.2	48.6	68.4	148	142	0	29	29
2014	7	9	16	20	9	0.308	0.066	0.807	0.039	0.039	0	51.2	49	66.7	149	143	0	30	29
2014	7	9	16	30	9	0.276	0.039	0.807	0.039	0.036	0	52.5	50.3	66.2	152	146	0	30	29
2014	7	9	16	40	9	0.217	0.023	0.807	0.039	0.036	0	52.5	49.9	66.7	152	145	0	30	29
2014	7	9	16	50	9	0.236	0.075	0.804	0.036	0.033	0	52.9	49.5	66.7	152	144	0	29	29
2014	7	9	17	0	9	0.331	0.059	0.804	0.039	0.036	0	51.6	49	67.1	149	143	0	29	29
2014	7	9	17	10	9	0.272	0.023	0.804	0.046	0.043	0	52	49	66.7	151	143	0	30	29
2014	7	9	17	20	9	0.249	0	0.801	0.039	0.039	0	53.3	49.9	66.2	153	145	0	29	29
2014	7	9	17	30	9	0.253	0.059	0.801	0.043	0.039	0	51.6	49.9	66.2	150	144	0	30	28
2014	7	9	17	40	9	0.305	0.059	0.797	0.033	0.03	0	53.3	49.9	65.8	153	145	0	29	29
2014	7	9	17	50	9	0.318	0.079	0.801	0.039	0.036	0	52	49	66.7	150	143	0	29	29
2014	7	9	18	0	9	0.217	0.072	0.801	0.036	0.033	0	51.2	48.6	66.7	148	142	0	29	29
2014	7	9	18	10	9	0.256	-0.007	0.797	0.039	0.039	0	51.6	49	66.2	150	143	0	30	29
2014	7	9	18	20	9	0.272	-0.02	0.801	0.039	0.036	0	51.6	49.5	65.4	150	144	0	30	29
2014	7	9	18	30	9	0.262	-0.016	0.801	0.039	0.039	0	51.6	49.5	65.8	150	144	0	30	29
2014	7	9	18	40	9	0.299	0.036	0.797	0.039	0.036	0	51.2	49.9	66.2	149	144	0	30	28
2014	7	9	18	50	9	0.285	0.098	0.801	0.043	0.039	0	51.6	49.9	65.4	150	145	0	30	29
2014	7	9	19	0	9	0.243	0	0.801	0.043	0.039	0	51.2	49.9	66.2	148	145	0	29	29
2014	7	9	19	10	9	0.217	0.016	0.804	0.033	0.03	0	52.5	50.7	65.4	152	147	0	30	29
2014	7	9	19	20	9	0.259	0.095	0.801	0.036	0.033	0	50.7	49	66.2	148	143	0	30	29
2014	7	9	19	30	9	0.39	0.016	0.804	0.039	0.036	0	51.2	49.9	65.8	149	144	0	30	28
2014	7	9	19	40	9	0.302	0.049	0.807	0.039	0.036	0	51.2	49	66.7	148	143	0	29	29
2014	7	9	19	50	9	0.253	0.056	0.804	0.036	0.033	0	52.5	50.7	64.1	152	147	0	30	29
2014	7	9	20	0	9	0.24	0.02	0.807	0.043	0.039	0	52.5	51.2	65.4	152	147	0	30	28
2014	7	9	20	10	9	0.217	0.023	0.807	0.043	0.039	0	52.9	50.7	64.5	153	147	0	30	29
2014	7	9	20	20	9	0.246	-0.016	0.807	0.039	0.036	0	53.3	52	64.1	154	149	0	30	28
2014	7	9	20	30	9	0.2	0.036	0.807	0.043	0.039	0	53.8	51.6	64.5	154	149	0	29	29
2014	7	9	20	40	9	0.315	0.043	0.81	0.056	0.052	0	53.3	51.2	65.4	153	148	0	29	29
2014	7	9	20	50	9	0.292	-0.033	0.81	0.039	0.036	0	53.3	51.6	65.8	154	149	0	30	29
2014	7	9	21	0	9	0.243	0.052	0.81	0.036	0.033	0	53.3	51.2	65.4	154	148	0	30	29
2014	7	9	21	10	9	0.217	-0.059	0.814	0.039	0.039	0	52.5	50.7	65.8	152	147	0	30	29
2014	7	9	21	20	9	0.246	-0.072	0.814	0.039	0.036	0	50.7	49.5	67.9	148	145	0	30	30
2014	7	9	21	30	9	0.312	-0.033	0.814	0.039	0.036	0	51.2	49.9	67.5	149	145	0	30	29
2014	7	9	21	40	9	0.171	0.03	0.814	0.043	0.039	0	51.6	49.9	67.9	150	145	0	30	29
2014	7	9	21	50	9	0.269	0.02	0.814	0.039	0.036	0	52.5	51.2	67.1	152	148	0	30	29
2014	7	9	22	0	9	0.226	0.023	0.814	0.036	0.033	0	52	50.7	67.9	151	147	0	30	29
2014	7	9	22	10	9	0.246	-0.003	0.814	0.036	0.033	0	52.9	50.7	67.5	152	147	0	29	29
2014	7	9	22	20	9	0.243	0.036	0.817	0.049	0.046	0	52.9	50.7	67.9	153	147	0	30	29
2014	7	9	22	30	9	0.272	0.023	0.817	0.036	0.033	0	52.5	50.7	67.9	152	147	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	22	40	9	0.253	0.056	0.817	0.039	0.036	0	52.5	50.7	68.8	151	146	0	29	28
2014	7	9	22	50	9	0.21	0.036	0.817	0.039	0.039	0	51.2	50.3	69.7	149	145	0	30	28
2014	7	9	23	0	9	0.24	0.033	0.817	0.043	0.039	0	50.7	48.6	70.1	148	143	0	30	30
2014	7	9	23	10	9	0.269	0	0.817	0.033	0.03	0	50.3	48.6	71	147	143	0	30	30
2014	7	9	23	20	9	0.246	-0.082	0.817	0.033	0.03	0	49.9	48.6	72.2	146	142	0	30	29
2014	7	9	23	30	9	0.22	-0.013	0.817	0.039	0.039	0	50.7	49.9	71	148	145	0	30	29
2014	7	9	23	40	9	0.24	0.072	0.817	0.036	0.033	0	51.6	49.9	69.7	150	146	0	30	30
2014	7	9	23	50	9	0.23	-0.03	0.82	0.039	0.036	0	49.9	49	71.4	146	143	0	30	29
2014	7	10	0	0	9	0.285	-0.01	0.82	0.033	0.03	0	50.7	49.5	71.4	148	144	0	30	29
2014	7	10	0	10	9	0.24	-0.01	0.82	0.036	0.033	0	50.3	49	71	147	143	0	30	29
2014	7	10	0	20	9	0.253	0	0.82	0.043	0.039	0	50.3	49.5	70.5	147	144	0	30	29
2014	7	10	0	30	9	0.223	0.043	0.82	0.039	0.036	0	49.9	48.6	71.8	145	142	0	29	29
2014	7	10	0	40	9	0.2	0.01	0.82	0.036	0.033	0	49.9	49	71.8	147	143	0	31	29
2014	7	10	0	50	9	0.203	0.03	0.82	0.033	0.03	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	10	1	0	9	0.253	-0.039	0.82	0.036	0.033	0	49.5	47.7	72.7	145	141	0	30	30
2014	7	10	1	10	9	0.226	-0.03	0.82	0.039	0.036	0	50.3	48.6	71.8	147	143	0	30	30
2014	7	10	1	20	9	0.21	0.02	0.82	0.036	0.033	0	50.3	49	72.2	147	143	0	30	29
2014	7	10	1	30	9	0.262	0.016	0.82	0.036	0.033	0	50.3	48.6	72.2	146	142	0	29	29
2014	7	10	1	40	9	0.226	-0.059	0.82	0.039	0.039	0	49.9	48.6	72.2	146	142	0	30	29
2014	7	10	1	50	9	0.253	-0.007	0.82	0.033	0.03	0	49.5	48.6	71.8	145	142	0	30	29
2014	7	10	2	0	9	0.194	0.043	0.82	0.039	0.039	0	49.9	48.2	71.8	146	142	0	30	30
2014	7	10	2	10	9	0.269	-0.016	0.82	0.036	0.033	0	49.9	48.6	72.2	146	142	0	30	29
2014	7	10	2	20	9	0.22	0.069	0.82	0.039	0.036	0	49	48.2	72.2	144	142	0	30	30
2014	7	10	2	30	9	0.276	-0.039	0.82	0.039	0.036	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	10	2	40	9	0.282	-0.023	0.82	0.036	0.033	0	49.5	47.7	71.8	145	141	0	30	30
2014	7	10	2	50	9	0.305	-0.036	0.82	0.039	0.036	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	10	3	0	9	0.217	-0.026	0.82	0.039	0.036	0	49.5	48.2	71	145	142	0	30	30
2014	7	10	3	10	9	0.197	-0.03	0.823	0.036	0.033	0	49	48.6	71.4	144	142	0	30	29
2014	7	10	3	20	9	0.351	-0.003	0.82	0.039	0.036	0	49	48.2	71.8	145	141	0	31	29
2014	7	10	3	30	9	0.24	-0.095	0.82	0.039	0.036	0	48.6	47.3	71.8	143	139	0	30	29
2014	7	10	3	40	9	0.272	0.026	0.823	0.036	0.033	0	48.6	47.7	71.8	144	140	0	31	29
2014	7	10	3	50	9	0.262	-0.03	0.823	0.036	0.033	0	48.6	47.7	71.8	144	140	0	31	29
2014	7	10	4	0	9	0.233	0.026	0.823	0.036	0.033	0	49.5	47.7	71.8	145	141	0	30	30
2014	7	10	4	10	9	0.246	-0.069	0.82	0.039	0.039	0	49	47.7	71.4	144	140	0	30	29
2014	7	10	4	20	9	0.305	0.003	0.823	0.036	0.033	0	48.2	48.2	71.8	143	141	0	31	29
2014	7	10	4	30	9	0.21	-0.003	0.823	0.039	0.036	0	49	47.7	71.8	144	140	0	30	29
2014	7	10	4	40	9	0.279	0.016	0.823	0.036	0.033	0	49	47.7	71.4	144	141	0	30	30
2014	7	10	4	50	9	0.18	-0.007	0.823	0.033	0.03	0	49.9	49	70.5	146	143	0	30	29
2014	7	10	5	0	9	0.249	-0.056	0.823	0.039	0.036	0	51.2	49.9	70.1	149	145	0	30	29
2014	7	10	5	10	9	0.233	0.003	0.823	0.039	0.036	0	49.9	48.2	70.5	146	142	0	30	30
2014	7	10	5	20	9	0.269	-0.039	0.823	0.036	0.033	0	49.5	48.2	69.7	146	142	0	31	30
2014	7	10	5	30	9	0.282	-0.013	0.823	0.036	0.033	0	49	48.2	70.1	145	142	0	31	30
2014	7	10	5	40	9	0.249	-0.02	0.823	0.036	0.033	0	50.7	49	69.7	148	143	0	30	29
2014	7	10	5	50	9	0.262	0.095	0.823	0.039	0.039	0	51.2	50.3	68.8	149	146	0	30	29
2014	7	10	6	0	9	0.308	-0.007	0.823	0.039	0.036	0	49.5	49	69.2	146	143	0	31	29
2014	7	10	6	10	9	0.213	-0.03	0.823	0.036	0.033	0	49.9	48.2	69.2	146	141	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	6	20	9	0.213	0.095	0.823	0.036	0.033	0	49.9	48.2	69.2	147	142	0	31	30
2014	7	10	6	30	9	0.305	0.043	0.823	0.036	0.033	0	50.3	48.6	69.2	147	143	0	30	30
2014	7	10	6	40	9	0.249	-0.026	0.823	0.039	0.039	0	49.5	48.2	68.8	146	142	0	31	30
2014	7	10	6	50	9	0.217	-0.01	0.823	0.039	0.036	0	49.9	48.6	68.8	147	142	0	31	29
2014	7	10	7	0	9	0.223	-0.046	0.823	0.039	0.039	0	49.9	48.2	68.8	146	142	0	30	30
2014	7	10	7	10	9	0.203	-0.026	0.823	0.039	0.039	0	49.5	48.2	69.2	146	142	0	31	30
2014	7	10	7	20	9	0.318	0.007	0.823	0.043	0.039	0	50.3	49	67.5	148	144	0	31	30
2014	7	10	7	30	9	0.223	0	0.827	0.046	0.043	0	49.5	47.7	69.7	145	141	0	30	30
2014	7	10	7	40	9	0.23	-0.013	0.827	0.039	0.036	0	49	47.7	68.8	144	141	0	30	30
2014	7	10	7	50	9	0.207	0	0.827	0.039	0.036	0	49.5	48.6	68.8	146	142	0	31	29
2014	7	10	8	0	9	0.276	0.036	0.827	0.039	0.036	0	49.5	47.7	69.7	145	141	0	30	30
2014	7	10	8	10	9	0.24	0.02	0.827	0.039	0.039	0	48.6	47.7	69.7	143	140	0	30	29
2014	7	10	8	20	9	0.295	-0.036	0.827	0.036	0.033	0	50.7	48.6	67.5	148	143	0	30	30
2014	7	10	8	30	9	0.259	0.023	0.827	0.036	0.033	0	49	47.7	68.8	144	141	0	30	30
2014	7	10	8	40	9	0.276	0	0.833	0.046	0.043	0	48.6	47.7	67.1	144	141	0	31	30
2014	7	10	8	50	9	0.24	-0.01	0.84	0.036	0.033	0	49.5	48.2	67.5	146	142	0	31	30
2014	7	10	9	0	9	0.331	-0.039	0.843	0.039	0.036	0	47.7	46.4	70.1	141	138	0	30	30
2014	7	10	9	10	9	0.24	-0.003	0.846	0.036	0.033	0	49	47.7	69.7	144	141	0	30	30
2014	7	10	9	20	9	0.341	0.016	0.85	0.043	0.039	0	50.7	48.6	68.8	148	143	0	30	30
2014	7	10	9	30	9	0.328	0.016	0.853	0.046	0.043	0	49.5	47.7	71.4	145	140	0	30	29
2014	7	10	9	40	9	0.315	0.056	0.853	0.046	0.043	0	50.3	48.2	71.8	147	142	0	30	30
2014	7	10	9	50	9	0.308	0	0.856	0.039	0.036	0	47.3	46	74	140	137	0	30	30
2014	7	10	10	0	9	0.256	-0.049	0.856	0.043	0.039	0	47.3	46.9	74	141	138	0	31	29
2014	7	10	10	10	9	0.302	0.095	0.86	0.036	0.033	0	49.9	48.6	71.4	147	143	0	31	30
2014	7	10	10	20	9	0.279	0.003	0.86	0.039	0.036	0	47.3	46	73.5	140	137	0	30	30
2014	7	10	10	30	9	0.394	0.02	0.863	0.039	0.039	0	47.3	46	73.1	141	137	0	31	30
2014	7	10	10	40	9	0.312	0.003	0.863	0.036	0.033	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	10	10	50	9	0.315	0.056	0.866	0.039	0.036	0	47.7	46	72.7	141	138	0	30	31
2014	7	10	11	0	9	0.325	0.03	0.866	0.039	0.036	0	46.9	46.4	72.2	140	137	0	31	29
2014	7	10	11	10	9	0.302	0.046	0.869	0.039	0.036	0	47.3	46.4	71.4	140	138	0	30	30
2014	7	10	11	20	9	0.364	0.036	0.869	0.039	0.036	0	47.7	46.9	70.1	142	138	0	31	29
2014	7	10	11	30	9	0.374	0.128	0.873	0.043	0.039	0	47.3	46.4	70.5	140	137	0	30	29
2014	7	10	11	40	9	0.348	0.056	0.879	0.036	0.033	0	46.9	46	70.5	140	137	0	31	30
2014	7	10	11	50	9	0.4	0.052	0.883	0.033	0.03	0	47.3	46	71.4	140	137	0	30	30
2014	7	10	12	0	9	0.358	0.135	0.883	0.033	0.03	0	48.2	47.3	70.1	142	140	0	30	30
2014	7	10	12	10	9	0.39	0.052	0.886	0.039	0.036	0	48.6	46.9	71.4	143	138	0	30	29
2014	7	10	12	20	9	0.394	0.118	0.886	0.033	0.03	0	47.3	46.9	71.8	140	138	0	30	29
2014	7	10	12	30	9	0.315	0.072	0.889	0.033	0.03	0	48.6	47.3	70.5	143	140	0	30	30
2014	7	10	12	40	9	0.338	0.125	0.889	0.039	0.036	0	49	47.7	71	144	141	0	30	30
2014	7	10	12	50	9	0.367	0.131	0.889	0.039	0.036	0	50.7	48.2	69.7	147	142	0	29	30
2014	7	10	13	0	9	0.325	0.151	0.889	0.036	0.033	0	49	48.2	69.7	144	142	0	30	30
2014	7	10	13	10	9	0.384	0.082	0.892	0.039	0.036	0	49.5	48.6	71.4	145	143	0	30	30
2014	7	10	13	20	9	0.423	0.128	0.892	0.033	0.03	0	49.5	49	70.5	145	142	0	30	28
2014	7	10	13	30	9	0.387	0.105	0.892	0.039	0.039	0	50.3	49	68.8	147	143	0	30	29
2014	7	10	13	40	9	0.341	0.105	0.892	0.039	0.036	0	50.7	49.9	67.9	148	145	0	30	29
2014	7	10	13	50	9	0.42	0.128	0.892	0.043	0.039	0	49.5	48.2	68.8	145	141	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	14	0	9	0.344	0.108	0.896	0.039	0.036	0	51.6	49.9	67.1	150	145	0	30	29
2014	7	10	14	10	9	0.39	0.157	0.896	0.036	0.033	0	50.7	49	70.1	148	143	0	30	29
2014	7	10	14	20	9	0.354	0.118	0.896	0.039	0.036	0	51.2	49.9	68.8	148	145	0	29	29
2014	7	10	14	30	9	0.374	0.121	0.896	0.043	0.039	0	50.7	49	70.1	148	143	0	30	29
2014	7	10	14	40	9	0.344	0.236	0.896	0.043	0.039	0	51.2	48.6	68.8	148	142	0	29	29
2014	7	10	14	50	9	0.41	0.167	0.896	0.036	0.033	0	50.7	49.9	68.8	148	144	0	30	28
2014	7	10	15	0	9	0.44	0.118	0.896	0.043	0.039	0	51.2	49.5	68.8	149	144	0	30	29
2014	7	10	15	10	9	0.371	0.148	0.899	0.033	0.03	0	51.6	49	69.2	149	144	0	29	30
2014	7	10	15	20	9	0.348	0.135	0.899	0.039	0.039	0	50.7	49	69.7	148	143	0	30	29
2014	7	10	15	30	9	0.371	0.23	0.896	0.043	0.039	0	51.6	49.5	68.8	149	144	0	29	29
2014	7	10	15	40	9	0.367	0.203	0.899	0.039	0.036	0	50.3	48.6	70.1	147	142	0	30	29
2014	7	10	15	50	9	0.407	0.246	0.896	0.039	0.036	0	49.9	47.7	69.7	146	141	0	30	30
2014	7	10	16	0	9	0.331	0.121	0.899	0.039	0.039	0	50.7	49	70.1	148	143	0	30	29
2014	7	10	16	10	9	0.344	0.21	0.899	0.039	0.036	0	51.2	49	70.1	149	143	0	30	29
2014	7	10	16	20	9	0.335	0.19	0.899	0.039	0.036	0	51.6	49.5	69.2	150	144	0	30	29
2014	7	10	16	30	9	0.407	0.125	0.899	0.039	0.036	0	51.6	49	70.1	149	143	0	29	29
2014	7	10	16	40	9	0.387	0.112	0.899	0.043	0.039	0	51.2	49.5	70.1	149	144	0	30	29
2014	7	10	16	50	9	0.358	0.112	0.899	0.039	0.039	0	51.2	49.5	69.2	149	144	0	30	29
2014	7	10	17	0	9	0.397	0.092	0.899	0.039	0.036	0	51.2	48.6	71	148	142	0	29	29
2014	7	10	17	10	9	0.404	0.098	0.899	0.039	0.039	0	51.2	49.5	70.1	149	143	0	30	28
2014	7	10	17	20	9	0.361	0.115	0.899	0.043	0.039	0	52.9	50.3	68.4	153	147	0	30	30
2014	7	10	17	30	9	0.305	0.046	0.899	0.036	0.033	0	51.6	49.9	69.7	150	145	0	30	29
2014	7	10	17	40	9	0.413	0.128	0.899	0.039	0.039	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	10	17	50	9	0.381	0.066	0.899	0.039	0.039	0	51.2	49	70.1	149	143	0	30	29
2014	7	10	18	0	9	0.42	0.121	0.899	0.043	0.039	0	50.7	49	70.1	148	143	0	30	29
2014	7	10	18	10	9	0.348	0.016	0.899	0.046	0.043	0	52.5	49.9	68.8	151	145	0	29	29
2014	7	10	18	20	9	0.39	0.066	0.899	0.043	0.039	0	52.5	50.3	68.4	152	146	0	30	29
2014	7	10	18	30	9	0.367	0.125	0.899	0.039	0.036	0	50.3	48.6	71	147	141	0	30	28
2014	7	10	18	40	9	0.397	0.056	0.899	0.039	0.036	0	52.5	50.7	68.8	152	147	0	30	29
2014	7	10	18	50	9	0.404	0.075	0.899	0.036	0.033	0	52.5	50.7	68.4	152	147	0	30	29
2014	7	10	19	0	9	0.335	-0.039	0.899	0.043	0.039	0	52.5	50.7	68.8	152	147	0	30	29
2014	7	10	19	10	9	0.344	-0.039	0.899	0.039	0.039	0	52.5	50.7	68.8	152	147	0	30	29
2014	7	10	19	20	9	0.4	0.016	0.899	0.036	0.033	0	52.9	50.3	69.7	152	146	0	29	29
2014	7	10	19	30	9	0.404	0.102	0.899	0.039	0.039	0	51.6	49.9	70.1	150	145	0	30	29
2014	7	10	19	40	9	0.394	0.056	0.899	0.039	0.039	0	52	50.3	69.7	151	146	0	30	29
2014	7	10	19	50	9	0.371	0.056	0.899	0.036	0.033	0	50.3	48.6	71	147	142	0	30	29
2014	7	10	20	0	9	0.371	-0.056	0.899	0.039	0.039	0	50.7	49.5	71	148	144	0	30	29
2014	7	10	20	10	9	0.338	0.069	0.899	0.039	0.036	0	51.6	49.5	70.1	150	144	0	30	29
2014	7	10	20	20	9	0.361	-0.092	0.899	0.039	0.039	0	52.5	50.7	68.8	152	147	0	30	29
2014	7	10	20	30	9	0.351	-0.02	0.899	0.039	0.036	0	53.8	51.6	67.9	154	150	0	29	30
2014	7	10	20	40	9	0.433	0	0.899	0.046	0.043	0	53.3	52	68.4	154	150	0	30	29
2014	7	10	20	50	9	0.344	-0.02	0.899	0.039	0.036	0	52.5	50.7	67.5	153	148	0	31	30
2014	7	10	21	0	9	0.377	0.069	0.899	0.039	0.036	0	52	51.2	68.8	151	148	0	30	29
2014	7	10	21	10	9	0.262	-0.033	0.899	0.033	0.03	0	51.2	49.9	69.2	149	145	0	30	29
2014	7	10	21	20	9	0.433	-0.043	0.899	0.046	0.043	0	51.2	49.9	70.1	149	145	0	30	29
2014	7	10	21	30	9	0.364	0.016	0.899	0.043	0.039	0	51.2	49.9	68.8	150	145	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	21	40	9	0.308	0	0.899	0.033	0.03	0	51.6	49.5	68.8	150	145	0	30	30
2014	7	10	21	50	9	0.364	-0.03	0.899	0.039	0.039	0	51.2	49.5	69.7	149	145	0	30	30
2014	7	10	22	0	9	0.449	0.095	0.899	0.043	0.039	0	49.9	49.5	70.5	147	144	0	31	29
2014	7	10	22	10	9	0.302	-0.049	0.899	0.039	0.036	0	50.3	49	70.1	148	143	0	31	29
2014	7	10	22	20	9	0.413	0.007	0.899	0.039	0.036	0	50.7	49	70.5	148	144	0	30	30
2014	7	10	22	30	9	0.374	0.049	0.899	0.039	0.036	0	50.7	49	69.7	149	144	0	31	30
2014	7	10	22	40	9	0.285	0.007	0.902	0.039	0.039	0	50.3	49	70.1	147	143	0	30	29
2014	7	10	22	50	9	0.325	-0.03	0.902	0.036	0.033	0	51.2	49	70.5	149	143	0	30	29
2014	7	10	23	0	9	0.387	0.039	0.902	0.036	0.033	0	49.9	48.6	71	147	142	0	31	29
2014	7	10	23	10	9	0.387	0.052	0.902	0.036	0.033	0	51.2	49.5	69.2	150	145	0	31	30
2014	7	10	23	20	9	0.374	-0.007	0.902	0.046	0.043	0	50.3	49.9	69.7	148	145	0	31	29
2014	7	10	23	30	9	0.338	-0.039	0.902	0.039	0.039	0	51.2	49	69.2	149	144	0	30	30
2014	7	10	23	40	9	0.413	0.016	0.902	0.039	0.036	0	51.6	50.7	68.8	150	147	0	30	29
2014	7	10	23	50	9	0.364	0.03	0.902	0.039	0.039	0	50.7	49	69.2	148	144	0	30	30
2014	7	11	0	0	9	0.299	-0.013	0.902	0.036	0.033	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	11	0	10	9	0.397	-0.023	0.902	0.039	0.036	0	49.9	48.6	69.7	147	143	0	31	30
2014	7	11	0	20	9	0.364	-0.046	0.902	0.039	0.039	0	49	48.2	70.1	145	141	0	31	29
2014	7	11	0	30	9	0.387	0.013	0.902	0.036	0.033	0	50.3	48.6	71	147	143	0	30	30
2014	7	11	0	40	9	0.377	-0.016	0.902	0.039	0.039	0	50.3	48.2	69.2	147	142	0	30	30
2014	7	11	0	50	9	0.351	-0.049	0.902	0.036	0.033	0	49.9	48.2	69.7	146	142	0	30	30
2014	7	11	1	0	9	0.41	-0.059	0.902	0.033	0.03	0	49.9	47.7	70.1	146	141	0	30	30
2014	7	11	1	10	9	0.387	0	0.902	0.039	0.036	0	49.9	48.2	70.1	146	141	0	30	29
2014	7	11	1	20	9	0.354	-0.003	0.902	0.036	0.033	0	49	47.7	70.1	145	141	0	31	30
2014	7	11	1	30	9	0.39	0.023	0.902	0.039	0.039	0	49	47.7	70.5	144	141	0	30	30
2014	7	11	1	40	9	0.39	0.046	0.902	0.043	0.039	0	48.6	48.2	70.1	144	141	0	31	29
2014	7	11	1	50	9	0.39	-0.01	0.902	0.039	0.036	0	49.5	47.3	70.1	145	140	0	30	30
2014	7	11	2	0	9	0.348	0.079	0.902	0.033	0.03	0	48.2	47.7	70.1	143	141	0	31	30
2014	7	11	2	10	9	0.417	-0.01	0.902	0.043	0.039	0	49	47.3	70.1	144	140	0	30	30
2014	7	11	2	20	9	0.367	0.003	0.902	0.039	0.036	0	49	47.7	69.7	145	141	0	31	30
2014	7	11	2	30	9	0.358	0.007	0.902	0.039	0.036	0	49	47.7	69.7	145	141	0	31	30
2014	7	11	2	40	9	0.456	0	0.902	0.039	0.036	0	49	47.3	69.7	144	140	0	30	30
2014	7	11	2	50	9	0.374	-0.039	0.902	0.039	0.036	0	48.6	47.7	69.2	143	141	0	30	30
2014	7	11	3	0	9	0.331	0.023	0.902	0.043	0.039	0	49.5	47.3	70.1	145	140	0	30	30
2014	7	11	3	10	9	0.377	-0.02	0.902	0.043	0.039	0	50.3	48.6	69.2	147	143	0	30	30
2014	7	11	3	20	9	0.348	0.082	0.902	0.033	0.03	0	49.5	48.2	70.1	145	142	0	30	30
2014	7	11	3	30	9	0.358	-0.039	0.902	0.039	0.039	0	49.9	48.6	68.4	147	143	0	31	30
2014	7	11	3	40	9	0.371	-0.043	0.902	0.046	0.043	0	49.5	48.2	69.2	145	141	0	30	29
2014	7	11	3	50	9	0.367	0.059	0.902	0.039	0.039	0	50.7	48.2	68.4	148	142	0	30	30
2014	7	11	4	0	9	0.384	-0.036	0.902	0.033	0.03	0	50.3	49	67.9	147	144	0	30	30
2014	7	11	4	10	9	0.322	-0.056	0.902	0.039	0.039	0	49.9	48.6	67.9	147	143	0	31	30
2014	7	11	4	20	9	0.325	-0.052	0.902	0.043	0.039	0	49.5	48.2	68.4	146	142	0	31	30
2014	7	11	4	30	9	0.295	0.056	0.902	0.039	0.039	0	49.9	48.2	68.8	147	142	0	31	30
2014	7	11	4	40	9	0.397	0.013	0.902	0.036	0.033	0	49.9	49.5	67.9	147	144	0	31	29
2014	7	11	4	50	9	0.41	-0.016	0.902	0.039	0.036	0	49.9	48.6	68.8	146	143	0	30	30
2014	7	11	5	0	9	0.417	0	0.902	0.039	0.036	0	49.5	48.6	67.9	146	143	0	31	30
2014	7	11	5	10	9	0.417	-0.003	0.902	0.033	0.03	0	49.9	48.2	68.4	146	142	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	5	20	9	0.476	0.052	0.902	0.039	0.036	0	49.5	48.6	68.8	146	143	0	31	30
2014	7	11	5	30	9	0.341	-0.056	0.906	0.036	0.033	0	49.5	48.2	67.9	146	142	0	31	30
2014	7	11	5	40	9	0.328	0	0.906	0.043	0.043	0	48.6	46.9	68.8	144	140	0	31	31
2014	7	11	5	50	9	0.259	-0.003	0.906	0.039	0.039	0	48.6	47.7	67.9	144	141	0	31	30
2014	7	11	6	0	9	0.407	-0.02	0.902	0.043	0.039	0	49.5	48.2	68.4	146	142	0	31	30
2014	7	11	6	10	9	0.354	0.036	0.902	0.036	0.033	0	51.2	49.9	66.7	149	146	0	30	30
2014	7	11	6	20	9	0.397	-0.003	0.902	0.039	0.036	0	49.5	47.7	67.5	146	141	0	31	30
2014	7	11	6	30	9	0.348	0.059	0.902	0.036	0.033	0	49	48.2	68.4	145	142	0	31	30
2014	7	11	6	40	9	0.427	-0.033	0.902	0.043	0.039	0	51.6	49.5	65.4	151	145	0	31	30
2014	7	11	6	50	9	0.384	-0.03	0.902	0.036	0.033	0	50.7	49.5	66.7	149	145	0	31	30
2014	7	11	7	0	9	0.289	0.003	0.906	0.039	0.039	0	49	47.7	67.9	145	141	0	31	30
2014	7	11	7	10	9	0.358	-0.131	0.902	0.039	0.039	0	49.5	47.7	67.9	146	141	0	31	30
2014	7	11	7	20	9	0.394	-0.036	0.902	0.036	0.033	0	50.3	48.2	67.5	147	142	0	30	30
2014	7	11	7	30	9	0.374	-0.039	0.902	0.039	0.036	0	48.6	47.7	68.4	145	141	0	32	30
2014	7	11	7	40	9	0.331	0.016	0.906	0.036	0.033	0	48.2	46.9	68.8	143	139	0	31	30
2014	7	11	7	50	9	0.407	-0.007	0.906	0.039	0.039	0	48.2	46.9	69.2	143	139	0	31	30
2014	7	11	8	0	9	0.328	0.013	0.906	0.039	0.036	0	48.6	46.9	68.8	144	139	0	31	30
2014	7	11	8	10	9	0.331	-0.043	0.906	0.036	0.033	0	47.7	46.4	69.2	142	139	0	31	31
2014	7	11	8	20	9	0.318	-0.079	0.902	0.039	0.039	0	47.7	46.4	69.2	142	138	0	31	30
2014	7	11	8	30	9	0.341	-0.036	0.902	0.036	0.033	0	47.3	46.4	70.1	141	138	0	31	30
2014	7	11	8	40	9	0.335	0.013	0.906	0.039	0.039	0	46.9	46	70.1	139	137	0	30	30
2014	7	11	8	50	9	0.381	0.02	0.902	0.043	0.043	0	47.7	46.9	69.7	142	139	0	31	30
2014	7	11	9	0	9	0.315	0.003	0.902	0.043	0.039	0	47.7	46.9	68.8	142	139	0	31	30
2014	7	11	9	10	9	0.315	-0.016	0.902	0.039	0.036	0	48.6	46.4	69.7	143	139	0	30	31
2014	7	11	9	20	9	0.377	-0.013	0.902	0.043	0.039	0	49	47.3	68.8	145	140	0	31	30
2014	7	11	9	30	9	0.394	-0.02	0.902	0.036	0.033	0	48.2	46.9	69.2	143	140	0	31	31
2014	7	11	9	40	9	0.299	-0.033	0.902	0.036	0.033	0	48.2	46.4	69.2	143	138	0	31	30
2014	7	11	9	50	9	0.364	-0.072	0.902	0.039	0.036	0	47.3	46	71	141	137	0	31	30
2014	7	11	10	0	9	0.295	-0.046	0.902	0.039	0.036	0	47.7	46.9	69.2	142	139	0	31	30
2014	7	11	10	10	9	0.381	-0.036	0.902	0.036	0.033	0	49	47.3	69.2	144	140	0	30	30
2014	7	11	10	20	9	0.312	-0.056	0.899	0.039	0.039	0	50.3	49.5	67.5	148	145	0	31	30
2014	7	11	10	30	9	0.387	-0.01	0.902	0.036	0.033	0	48.6	47.7	70.5	144	141	0	31	30
2014	7	11	10	40	9	0.318	0	0.902	0.043	0.039	0	48.2	46.9	71.4	143	139	0	31	30
2014	7	11	10	50	9	0.344	0.089	0.899	0.039	0.036	0	48.2	46.9	71.4	142	139	0	30	30
2014	7	11	11	0	9	0.371	0.013	0.899	0.039	0.036	0	47.7	46.4	71.8	142	138	0	31	30
2014	7	11	11	10	9	0.4	0.026	0.899	0.033	0.03	0	48.2	46.9	72.2	143	139	0	31	30
2014	7	11	11	20	9	0.344	-0.026	0.899	0.033	0.03	0	49.5	47.3	71.8	145	140	0	30	30
2014	7	11	11	30	9	0.295	0.052	0.896	0.039	0.039	0	49.5	48.6	70.5	146	142	0	31	29
2014	7	11	11	40	9	0.328	0	0.896	0.036	0.033	0	49.9	49	70.1	147	144	0	31	30
2014	7	11	11	50	9	0.312	-0.059	0.896	0.039	0.039	0	50.3	48.6	71	147	143	0	30	30
2014	7	11	12	0	9	0.344	0.016	0.896	0.049	0.046	0	49	47.7	72.2	145	141	0	31	30
2014	7	11	12	10	9	0.344	0.003	0.892	0.046	0.043	0	51.6	50.3	70.1	151	147	0	31	30
2014	7	11	12	20	9	0.299	-0.003	0.892	0.036	0.033	0	50.3	49.5	71.4	148	144	0	31	29
2014	7	11	12	30	9	0.276	-0.007	0.889	0.033	0.03	0	49.9	48.6	71.4	146	143	0	30	30
2014	7	11	12	40	9	0.315	0.112	0.889	0.043	0.039	0	49	48.6	70.5	145	143	0	31	30
2014	7	11	12	50	9	0.39	0.036	0.886	0.043	0.039	0	50.3	49	70.1	147	144	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	13	0	9	0.446	0.036	0.886	0.043	0.039	0	50.7	49	68.4	148	144	0	30	30
2014	7	11	13	10	9	0.282	0	0.883	0.036	0.033	0	52	51.2	66.7	151	148	0	30	29
2014	7	11	13	20	9	0.299	0.056	0.876	0.036	0.033	0	55.5	54.6	63.2	160	156	0	31	29
2014	7	11	13	30	9	0.279	0.033	0.876	0.036	0.033	0	52.9	51.6	66.2	153	149	0	30	29
2014	7	11	13	40	9	0.377	0.112	0.873	0.039	0.036	0	50.7	50.3	67.5	149	146	0	31	29
2014	7	11	13	50	9	0.338	0.069	0.869	0.033	0.03	0	50.7	49.9	67.9	148	145	0	30	29
2014	7	11	14	0	9	0.305	0.056	0.866	0.036	0.033	0	49.5	49.5	68.8	146	144	0	31	29
2014	7	11	14	10	9	0.364	0.105	0.866	0.036	0.033	0	50.7	49.5	70.1	148	144	0	30	29
2014	7	11	14	20	9	0.302	0.01	0.866	0.036	0.033	0	51.6	49.9	69.2	150	146	0	30	30
2014	7	11	14	30	9	0.443	0.102	0.866	0.039	0.036	0	51.2	50.3	69.2	149	146	0	30	29
2014	7	11	14	40	9	0.302	0.02	0.863	0.043	0.039	0	51.6	49.9	70.1	150	146	0	30	30
2014	7	11	14	50	9	0.348	0.066	0.863	0.039	0.039	0	52	50.7	69.7	151	147	0	30	29
2014	7	11	15	0	9	0.308	0.072	0.863	0.033	0.03	0	50.3	49.5	70.5	148	144	0	31	29
2014	7	11	15	10	9	0.371	0.056	0.863	0.039	0.039	0	51.6	50.7	70.5	150	147	0	30	29
2014	7	11	15	20	9	0.331	0.007	0.86	0.039	0.036	0	52	51.2	70.1	151	147	0	30	28
2014	7	11	15	30	9	0.253	0.092	0.86	0.036	0.033	0	52	50.7	69.2	151	147	0	30	29
2014	7	11	15	40	9	0.331	0.052	0.86	0.036	0.033	0	52	50.7	70.1	151	147	0	30	29
2014	7	11	15	50	9	0.282	0.013	0.86	0.036	0.033	0	52	50.3	71	151	145	0	30	28
2014	7	11	16	0	9	0.381	0.112	0.856	0.033	0.03	0	51.2	50.3	68.4	149	146	0	30	29
2014	7	11	16	10	9	0.318	0.003	0.856	0.036	0.033	0	50.7	49.5	69.2	148	144	0	30	29
2014	7	11	16	20	9	0.318	0	0.856	0.039	0.036	0	50.7	49.9	68.8	148	145	0	30	29
2014	7	11	16	30	9	0.285	0.02	0.856	0.043	0.039	0	51.2	49.5	68.8	149	144	0	30	29
2014	7	11	16	40	9	0.269	0.089	0.853	0.043	0.039	0	50.7	49.5	68.4	148	144	0	30	29
2014	7	11	16	50	9	0.315	0.131	0.853	0.036	0.033	0	50.3	49.5	68.8	147	143	0	30	28
2014	7	11	17	0	9	0.364	0.089	0.853	0.039	0.036	0	51.6	49.9	68.4	150	144	0	30	28
2014	7	11	17	10	9	0.302	0.016	0.85	0.039	0.036	0	50.3	48.6	68.8	147	142	0	30	29
2014	7	11	17	20	9	0.299	0.062	0.85	0.039	0.036	0	49.9	48.2	67.5	146	141	0	30	29
2014	7	11	17	30	9	0.266	0.023	0.846	0.039	0.039	0	50.7	49	67.5	147	142	0	29	28
2014	7	11	17	40	9	0.41	0.108	0.846	0.039	0.036	0	49.9	48.2	66.7	146	142	0	30	30
2014	7	11	17	50	9	0.285	0.066	0.843	0.039	0.036	0	50.3	48.2	67.1	147	141	0	30	29
2014	7	11	18	0	9	0.341	0.105	0.843	0.039	0.039	0	49.5	47.7	67.5	145	140	0	30	29
2014	7	11	18	10	9	0.341	-0.043	0.84	0.039	0.039	0	48.6	47.7	68.4	143	139	0	30	28
2014	7	11	18	20	9	0.364	0.033	0.84	0.043	0.039	0	48.2	46.9	67.9	142	138	0	30	29
2014	7	11	18	30	9	0.315	0.059	0.837	0.033	0.03	0	48.6	46.9	67.1	143	138	0	30	29
2014	7	11	18	40	9	0.289	0.079	0.837	0.039	0.036	0	48.2	46.4	68.4	141	137	0	29	29
2014	7	11	18	50	9	0.299	0.03	0.837	0.039	0.039	0	48.6	46.9	68.8	143	138	0	30	29
2014	7	11	19	0	9	0.305	0.115	0.833	0.039	0.036	0	48.2	46.4	69.2	142	137	0	30	29
2014	7	11	19	10	9	0.335	-0.02	0.833	0.033	0.03	0	49.9	47.3	68.4	145	139	0	29	29
2014	7	11	19	20	9	0.344	0.007	0.833	0.039	0.036	0	47.7	45.6	71	140	135	0	29	29
2014	7	11	19	30	9	0.282	0.108	0.833	0.039	0.036	0	48.6	46.4	69.2	143	137	0	30	29
2014	7	11	19	40	9	0.325	-0.026	0.833	0.039	0.036	0	48.2	47.3	70.1	142	139	0	30	29
2014	7	11	19	50	9	0.249	0.013	0.833	0.039	0.036	0	49	46.9	70.1	143	138	0	29	29
2014	7	11	20	0	9	0.299	0.023	0.833	0.039	0.039	0	48.6	47.3	68.8	143	139	0	30	29
2014	7	11	20	10	9	0.308	0.039	0.83	0.036	0.033	0	48.6	47.3	69.7	143	139	0	30	29
2014	7	11	20	20	9	0.299	0.03	0.83	0.039	0.036	0	48.6	47.7	69.7	143	140	0	30	29
2014	7	11	20	30	9	0.289	0.016	0.83	0.039	0.039	0	49.5	48.6	68.8	145	142	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	20	40	9	0.328	0.036	0.83	0.033	0.03	0	48.6	47.7	69.2	143	140	0	30	29
2014	7	11	20	50	9	0.295	-0.043	0.833	0.039	0.039	0	49.5	47.7	70.1	144	140	0	29	29
2014	7	11	21	0	9	0.289	-0.01	0.83	0.036	0.033	0	49	47.7	70.1	144	140	0	30	29
2014	7	11	21	10	9	0.256	0.016	0.83	0.036	0.033	0	50.3	49	68.8	147	143	0	30	29
2014	7	11	21	20	9	0.361	-0.046	0.83	0.039	0.036	0	49	48.2	68.4	144	141	0	30	29
2014	7	11	21	30	9	0.213	-0.013	0.83	0.039	0.036	0	50.3	48.6	68.4	147	142	0	30	29
2014	7	11	21	40	9	0.285	-0.036	0.833	0.043	0.039	0	49.5	48.2	68.8	145	141	0	30	29
2014	7	11	21	50	9	0.269	-0.02	0.833	0.036	0.033	0	50.3	48.6	67.9	147	142	0	30	29
2014	7	11	22	0	9	0.302	0.059	0.833	0.039	0.036	0	50.7	48.6	67.5	148	143	0	30	30
2014	7	11	22	10	9	0.325	-0.02	0.833	0.043	0.039	0	50.7	49.5	66.2	149	145	0	31	30
2014	7	11	22	20	9	0.249	0	0.833	0.036	0.033	0	51.6	49.5	66.2	150	145	0	30	30
2014	7	11	22	30	9	0.312	0.036	0.833	0.039	0.036	0	50.7	49.5	66.7	148	145	0	30	30
2014	7	11	22	40	9	0.299	-0.007	0.837	0.033	0.03	0	50.3	48.2	67.5	147	142	0	30	30
2014	7	11	22	50	9	0.308	-0.007	0.837	0.039	0.036	0	49.5	48.2	67.5	145	142	0	30	30
2014	7	11	23	0	9	0.299	0.013	0.837	0.036	0.033	0	49.5	48.6	67.5	145	142	0	30	29
2014	7	11	23	10	9	0.24	-0.033	0.837	0.036	0.033	0	49.9	48.6	67.5	146	142	0	30	29
2014	7	11	23	20	9	0.295	-0.01	0.84	0.036	0.033	0	49.9	48.6	67.9	146	142	0	30	29
2014	7	11	23	30	9	0.328	0.026	0.84	0.033	0.03	0	49.5	47.7	67.1	146	141	0	31	30
2014	7	11	23	40	9	0.285	-0.046	0.843	0.039	0.036	0	49	47.7	67.9	145	140	0	31	29
2014	7	11	23	50	9	0.243	0.013	0.843	0.039	0.036	0	49.9	48.2	67.9	146	141	0	30	29
2014	7	12	0	0	9	0.279	0.01	0.84	0.036	0.033	0	49.9	48.2	67.9	146	142	0	30	30
2014	7	12	0	10	9	0.299	-0.069	0.843	0.036	0.033	0	49.9	49	67.1	147	143	0	31	29
2014	7	12	0	20	9	0.223	0	0.843	0.043	0.039	0	49.9	48.6	67.9	147	143	0	31	30
2014	7	12	0	30	9	0.299	-0.023	0.843	0.039	0.036	0	49.9	48.2	67.9	146	142	0	30	30
2014	7	12	0	40	9	0.279	-0.02	0.84	0.039	0.039	0	49.9	48.2	67.5	147	142	0	31	30
2014	7	12	0	50	9	0.328	-0.01	0.84	0.039	0.036	0	49.5	48.2	67.9	145	142	0	30	30
2014	7	12	1	0	9	0.223	-0.02	0.84	0.039	0.036	0	48.6	48.6	68.4	144	142	0	31	29
2014	7	12	1	10	9	0.299	-0.003	0.837	0.036	0.033	0	49.5	48.6	68.4	145	142	0	30	29
2014	7	12	1	20	9	0.279	-0.003	0.837	0.036	0.033	0	48.6	48.2	68.4	143	141	0	30	29
2014	7	12	1	30	9	0.243	0.059	0.833	0.039	0.039	0	48.6	47.7	68.8	143	141	0	30	30
2014	7	12	1	40	9	0.331	0.056	0.833	0.039	0.039	0	48.6	47.3	68.4	144	140	0	31	30
2014	7	12	1	50	9	0.285	0.013	0.83	0.039	0.036	0	49	47.3	68.8	144	140	0	30	30
2014	7	12	2	0	9	0.236	-0.046	0.83	0.036	0.033	0	48.6	46.9	69.2	143	138	0	30	29
2014	7	12	2	10	9	0.285	0.013	0.827	0.039	0.036	0	49	47.3	69.2	144	140	0	30	30
2014	7	12	2	20	9	0.279	-0.023	0.827	0.039	0.036	0	48.6	47.7	69.7	144	141	0	31	30
2014	7	12	2	30	9	0.24	0.059	0.827	0.033	0.03	0	48.2	47.3	70.5	143	139	0	31	29
2014	7	12	2	40	9	0.246	0.013	0.827	0.039	0.039	0	47.7	47.3	69.7	142	140	0	31	30
2014	7	12	2	50	9	0.279	-0.039	0.827	0.039	0.036	0	49	47.7	69.7	144	141	0	30	30
2014	7	12	3	0	9	0.276	-0.013	0.823	0.039	0.036	0	48.2	46.9	71	143	139	0	31	30
2014	7	12	3	10	9	0.236	-0.013	0.823	0.036	0.033	0	48.2	46.9	70.5	143	139	0	31	30
2014	7	12	3	20	9	0.279	-0.02	0.823	0.033	0.03	0	48.6	46.9	70.1	143	139	0	30	30
2014	7	12	3	30	9	0.171	-0.003	0.823	0.039	0.039	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	12	3	40	9	0.328	-0.026	0.823	0.039	0.036	0	48.6	47.3	70.1	144	140	0	31	30
2014	7	12	3	50	9	0.295	-0.046	0.82	0.039	0.036	0	47.7	46.9	71	141	139	0	30	30
2014	7	12	4	0	9	0.207	0.079	0.82	0.039	0.039	0	48.2	47.7	71.4	143	140	0	31	29
2014	7	12	4	10	9	0.174	0	0.82	0.043	0.039	0	48.6	47.3	71	144	140	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	4	20	9	0.282	0.089	0.82	0.039	0.036	0	49	46.4	71.4	144	139	0	30	31
2014	7	12	4	30	9	0.285	0.016	0.82	0.033	0.03	0	49	46.9	71.4	144	139	0	30	30
2014	7	12	4	40	9	0.24	-0.007	0.82	0.043	0.043	0	48.2	47.3	71	143	140	0	31	30
2014	7	12	4	50	9	0.302	-0.039	0.817	0.036	0.033	0	50.3	48.2	70.1	147	142	0	30	30
2014	7	12	5	0	9	0.328	-0.098	0.817	0.043	0.039	0	49.5	49	69.2	146	143	0	31	29
2014	7	12	5	10	9	0.308	0.072	0.817	0.039	0.039	0	49.5	48.2	71	146	142	0	31	30
2014	7	12	5	20	9	0.226	0.01	0.817	0.043	0.039	0	50.3	49.5	69.7	147	144	0	30	29
2014	7	12	5	30	9	0.24	-0.02	0.817	0.033	0.03	0	50.3	49	70.1	147	144	0	30	30
2014	7	12	5	40	9	0.302	-0.056	0.817	0.039	0.036	0	48.2	47.7	71.4	144	141	0	32	30
2014	7	12	5	50	9	0.266	-0.02	0.817	0.036	0.033	0	48.2	46.9	72.2	143	139	0	31	30
2014	7	12	6	0	9	0.302	0.007	0.817	0.033	0.03	0	47.7	46.9	72.7	142	139	0	31	30
2014	7	12	6	10	9	0.23	-0.03	0.817	0.046	0.043	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	12	6	20	9	0.197	-0.066	0.817	0.036	0.033	0	47.3	46	71.8	141	137	0	31	30
2014	7	12	6	30	9	0.276	-0.003	0.817	0.039	0.039	0	47.7	46.9	72.2	142	139	0	31	30
2014	7	12	6	40	9	0.308	0.016	0.814	0.043	0.039	0	50.7	49.5	69.2	149	145	0	31	30
2014	7	12	6	50	9	0.23	0	0.814	0.036	0.033	0	49.9	48.6	70.5	147	143	0	31	30
2014	7	12	7	0	9	0.253	-0.056	0.814	0.033	0.03	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	12	7	10	9	0.266	-0.033	0.814	0.036	0.033	0	50.3	48.6	71	148	144	0	31	31
2014	7	12	7	20	9	0.2	0.03	0.814	0.036	0.033	0	48.2	46.9	72.2	143	139	0	31	30
2014	7	12	7	30	9	0.243	-0.033	0.814	0.039	0.039	0	48.2	47.7	72.7	143	141	0	31	30
2014	7	12	7	40	9	0.207	-0.039	0.814	0.036	0.033	0	48.2	47.3	72.2	143	140	0	31	30
2014	7	12	7	50	9	0.246	0.039	0.814	0.039	0.039	0	49.9	48.6	70.5	147	143	0	31	30
2014	7	12	8	0	9	0.161	0.023	0.814	0.033	0.03	0	50.3	49	70.1	148	144	0	31	30
2014	7	12	8	10	9	0.161	0.003	0.814	0.039	0.039	0	48.2	47.7	71.8	143	140	0	31	29
2014	7	12	8	20	9	0.154	-0.02	0.814	0.039	0.036	0	49.5	48.2	71	146	142	0	31	30
2014	7	12	8	30	9	0.177	-0.043	0.814	0.043	0.039	0	48.6	47.3	71.8	144	140	0	31	30
2014	7	12	8	40	9	0.213	0	0.814	0.039	0.036	0	48.2	47.3	72.2	143	140	0	31	30
2014	7	12	8	50	9	0.299	0	0.814	0.039	0.039	0	48.2	47.3	72.7	143	140	0	31	30
2014	7	12	9	0	9	0.272	0	0.814	0.046	0.043	0	48.6	46.9	73.1	143	139	0	30	30
2014	7	12	9	10	9	0.282	0.02	0.814	0.039	0.036	0	47.7	46.4	72.7	142	138	0	31	30
2014	7	12	9	20	9	0.22	0.036	0.814	0.033	0.03	0	48.2	46.9	71.8	143	140	0	31	31
2014	7	12	9	30	9	0.236	-0.01	0.814	0.039	0.036	0	49	48.6	71	145	143	0	31	30
2014	7	12	9	40	9	0.197	-0.056	0.81	0.039	0.036	0	48.6	47.3	71.8	144	140	0	31	30
2014	7	12	9	50	9	0.223	0.085	0.81	0.036	0.033	0	49	48.2	71.8	144	142	0	30	30
2014	7	12	10	0	9	0.213	0.039	0.81	0.036	0.033	0	47.7	46.4	73.1	142	138	0	31	30
2014	7	12	10	10	9	0.21	-0.026	0.81	0.036	0.033	0	46.9	46	72.2	140	138	0	31	31
2014	7	12	10	20	9	0.246	0.036	0.81	0.046	0.046	0	47.7	46.9	71.4	142	139	0	31	30
2014	7	12	10	30	9	0.233	0.069	0.81	0.039	0.039	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	12	10	40	9	0.24	0.03	0.807	0.039	0.036	0	46.9	46	71.8	140	137	0	31	30
2014	7	12	10	50	9	0.164	0.03	0.807	0.036	0.033	0	46.4	46.4	71.8	139	138	0	31	30
2014	7	12	11	0	9	0.24	0.023	0.807	0.036	0.033	0	46.9	46.4	71.4	140	138	0	31	30
2014	7	12	11	10	9	0.246	0.023	0.807	0.036	0.033	0	47.3	47.7	70.5	141	140	0	31	29
2014	7	12	11	20	9	0.259	0.016	0.804	0.039	0.036	0	46.9	47.3	70.5	140	140	0	31	30
2014	7	12	11	30	9	0.223	0.033	0.804	0.033	0.03	0	47.3	47.3	68.8	141	140	0	31	30
2014	7	12	11	40	9	0.223	0.069	0.801	0.039	0.036	0	50.7	50.7	66.2	148	147	0	30	29
2014	7	12	11	50	9	0.184	0.144	0.791	0.043	0.039	0	52.5	51.6	64.9	152	150	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	12	0	9	0.331	0.174	0.791	0.033	0.03	0	51.6	51.6	67.1	150	149	0	30	29
2014	7	12	12	10	9	0.269	0.135	0.791	0.036	0.033	0	51.2	50.7	67.1	149	148	0	30	30
2014	7	12	12	20	9	0.184	0.072	0.787	0.036	0.033	0	50.7	49.9	68.4	148	146	0	30	30
2014	7	12	12	30	9	0.24	0.115	0.787	0.033	0.03	0	50.3	49.9	69.2	148	146	0	31	30
2014	7	12	12	40	9	0.223	0.052	0.787	0.036	0.033	0	50.3	49.9	69.7	147	145	0	30	29
2014	7	12	12	50	9	0.203	0.003	0.787	0.036	0.033	0	50.3	49	70.1	148	144	0	31	30
2014	7	12	13	0	9	0.154	0.098	0.784	0.039	0.039	0	50.3	49.9	71	148	146	0	31	30
2014	7	12	13	10	9	0.279	0.082	0.784	0.043	0.043	0	50.3	50.3	71	147	147	0	30	30
2014	7	12	13	20	9	0.213	0.092	0.784	0.033	0.03	0	51.2	51.2	71.4	149	148	0	30	29
2014	7	12	13	30	9	0.292	0.108	0.784	0.033	0.03	0	51.2	50.7	70.5	149	147	0	30	29
2014	7	12	13	40	9	0.272	0.003	0.784	0.033	0.03	0	51.2	50.7	71	149	148	0	30	30
2014	7	12	13	50	9	0.256	0.02	0.784	0.033	0.03	0	50.3	50.3	71.8	148	147	0	31	30
2014	7	12	14	0	9	0.276	0.072	0.781	0.033	0.03	0	52	52	71	151	150	0	30	29
2014	7	12	14	10	9	0.256	0.072	0.781	0.033	0.03	0	52.5	54.2	69.2	152	155	0	30	29
2014	7	12	14	20	9	0.305	0.007	0.781	0.036	0.033	0	51.6	52	71	150	150	0	30	29
2014	7	12	14	30	9	0.236	0.135	0.781	0.033	0.03	0	52.9	52.5	70.1	153	151	0	30	29
2014	7	12	14	40	9	0.24	0.043	0.778	0.03	0.03	0	52.9	52.5	69.2	152	151	0	29	29
2014	7	12	14	50	9	0.259	0.062	0.778	0.033	0.03	0	52.9	52.9	67.9	153	152	0	30	29
2014	7	12	15	0	9	0.292	0.072	0.778	0.039	0.036	0	52.9	52.9	69.2	153	152	0	30	29
2014	7	12	15	10	9	0.272	0.062	0.774	0.036	0.033	0	53.3	53.3	66.7	154	153	0	30	29
2014	7	12	15	20	9	0.203	0.095	0.774	0.033	0.03	0	52.9	53.3	67.9	154	153	0	31	29
2014	7	12	15	30	9	0.236	0.075	0.774	0.033	0.03	0	53.3	53.3	66.7	154	153	0	30	29
2014	7	12	15	40	9	0.276	0.059	0.774	0.033	0.03	0	53.8	52.9	64.9	155	151	0	30	28
2014	7	12	15	50	9	0.236	0.062	0.771	0.046	0.043	0	52.9	52.5	65.8	153	151	0	30	29
2014	7	12	16	0	9	0.249	0.056	0.771	0.043	0.039	0	52.9	53.3	67.1	154	153	0	31	29
2014	7	12	16	10	9	0.226	0.046	0.771	0.033	0.03	0	52.5	52.5	65.4	152	151	0	30	29
2014	7	12	16	20	9	0.207	0.026	0.764	0.033	0.03	0	52.5	52.9	66.2	152	152	0	30	29
2014	7	12	16	30	9	0.226	0.075	0.764	0.033	0.03	0	52.9	52	64.5	153	149	0	30	28
2014	7	12	16	40	9	0.256	0.052	0.761	0.036	0.033	0	52.5	51.2	67.1	152	148	0	30	29
2014	7	12	16	50	9	0.217	0.072	0.761	0.039	0.036	0	51.6	50.7	66.7	150	148	0	30	30
2014	7	12	17	0	9	0.223	0.089	0.758	0.036	0.033	0	52.5	51.2	67.9	151	148	0	29	29
2014	7	12	17	10	9	0.207	0.095	0.758	0.03	0.03	0	51.6	50.3	67.5	149	146	0	29	29
2014	7	12	17	20	9	0.223	0.112	0.758	0.033	0.03	0	50.7	50.3	67.9	148	146	0	30	29
2014	7	12	17	30	9	0.243	0.154	0.755	0.033	0.03	0	49.9	49.9	69.2	146	145	0	30	29
2014	7	12	17	40	9	0.217	0.128	0.755	0.036	0.033	0	49	48.6	70.5	143	142	0	29	29
2014	7	12	17	50	9	0.236	0.098	0.755	0.033	0.03	0	47.7	47.3	70.5	141	139	0	30	29
2014	7	12	18	0	9	0.282	0.036	0.755	0.036	0.033	0	46.4	46.9	71.4	138	137	0	30	28
2014	7	12	18	10	9	0.223	0.049	0.755	0.043	0.039	0	46	45.2	71	137	133	0	30	28
2014	7	12	18	20	9	0.197	0.079	0.751	0.036	0.033	0	46.4	44.3	72.2	137	132	0	29	29
2014	7	12	18	30	9	0.279	0.098	0.751	0.033	0.03	0	46	44.3	72.2	137	132	0	30	29
2014	7	12	18	40	9	0.256	0.112	0.751	0.033	0.03	0	45.6	44.7	72.2	136	132	0	30	28
2014	7	12	18	50	9	0.233	0.023	0.751	0.039	0.036	0	45.6	44.3	72.2	136	132	0	30	29
2014	7	12	19	0	9	0.151	0.128	0.751	0.033	0.03	0	46.4	45.2	72.7	137	134	0	29	29
2014	7	12	19	10	9	0.207	0.144	0.751	0.039	0.036	0	47.3	45.2	73.1	139	134	0	29	29
2014	7	12	19	20	9	0.174	0.049	0.751	0.039	0.039	0	46.4	46	72.2	138	135	0	30	28
2014	7	12	19	30	9	0.197	0.056	0.751	0.033	0.03	0	46	44.7	73.1	137	132	0	30	28

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	19	40	9	0.187	0.036	0.751	0.043	0.039	0	46.9	45.6	72.2	139	135	0	30	29
2014	7	12	19	50	9	0.259	0.056	0.751	0.039	0.036	0	48.6	46.4	71.4	142	137	0	29	29
2014	7	12	20	0	9	0.236	0.059	0.751	0.039	0.036	0	48.6	46.9	70.5	142	137	0	29	28
2014	7	12	20	10	9	0.259	-0.013	0.748	0.043	0.039	0	47.7	46.9	71.4	141	138	0	30	29
2014	7	12	20	20	9	0.135	-0.01	0.751	0.039	0.039	0	49	47.3	71	143	139	0	29	29
2014	7	12	20	30	9	0.233	0.01	0.751	0.039	0.036	0	49	46.9	70.5	144	138	0	30	29
2014	7	12	20	40	9	0.23	0	0.751	0.033	0.03	0	49.5	47.7	69.7	145	140	0	30	29
2014	7	12	20	50	9	0.22	0.013	0.751	0.039	0.036	0	49	47.7	70.5	144	140	0	30	29
2014	7	12	21	0	9	0.184	0.056	0.751	0.033	0.03	0	49.9	49.5	69.2	146	143	0	30	28
2014	7	12	21	10	9	0.23	0.016	0.751	0.039	0.036	0	50.3	49.5	69.2	147	144	0	30	29
2014	7	12	21	20	9	0.18	0.016	0.751	0.039	0.036	0	51.6	49.9	68.4	149	145	0	29	29
2014	7	12	21	30	9	0.246	0.02	0.751	0.039	0.036	0	51.2	49.9	68.4	149	145	0	30	29
2014	7	12	21	40	9	0.151	0.056	0.751	0.039	0.036	0	51.2	49.5	67.5	149	144	0	30	29
2014	7	12	21	50	9	0.24	0.043	0.751	0.036	0.033	0	52.5	50.7	66.7	151	147	0	29	29
2014	7	12	22	0	9	0.167	0.036	0.751	0.036	0.033	0	52.5	51.2	67.1	152	148	0	30	29
2014	7	12	22	10	9	0.207	0.003	0.751	0.043	0.043	0	52.9	51.6	66.7	153	149	0	30	29
2014	7	12	22	20	9	0.23	0.013	0.751	0.039	0.036	0	53.8	51.2	65.8	154	148	0	29	29
2014	7	12	22	30	9	0.157	-0.036	0.751	0.036	0.033	0	52	50.7	67.1	151	147	0	30	29
2014	7	12	22	40	9	0.148	0	0.751	0.033	0.03	0	53.3	52	67.5	153	150	0	29	29
2014	7	12	22	50	9	0.171	0.026	0.751	0.033	0.03	0	52.9	51.6	66.7	153	149	0	30	29
2014	7	12	23	0	9	0.217	-0.016	0.751	0.036	0.033	0	52.5	51.2	65.8	152	148	0	30	29
2014	7	12	23	10	9	0.151	0.016	0.751	0.036	0.033	0	52.9	52	65.4	153	150	0	30	29
2014	7	12	23	20	9	0.233	-0.003	0.755	0.036	0.033	0	52.5	51.2	65.8	152	148	0	30	29
2014	7	12	23	30	9	0.131	0	0.755	0.039	0.036	0	53.8	52.5	64.1	155	151	0	30	29
2014	7	12	23	40	9	0.194	-0.016	0.755	0.036	0.033	0	52.5	51.6	64.9	152	149	0	30	29
2014	7	12	23	50	9	0.194	0.026	0.755	0.036	0.033	0	52	50.7	66.2	151	147	0	30	29
2014	7	13	0	0	9	0.197	0	0.751	0.046	0.043	0	52	51.2	64.9	151	148	0	30	29
2014	7	13	0	10	9	0.125	-0.102	0.755	0.036	0.033	0	52.9	51.2	64.9	152	148	0	29	29
2014	7	13	0	20	9	0.171	-0.016	0.755	0.033	0.03	0	52.5	51.2	64.9	152	148	0	30	29
2014	7	13	0	30	9	0.226	0.02	0.755	0.036	0.033	0	52.5	51.2	65.8	152	148	0	30	29
2014	7	13	0	40	9	0.18	0.013	0.755	0.036	0.033	0	52.9	51.6	64.5	153	149	0	30	29
2014	7	13	0	50	9	0.19	0.013	0.751	0.03	0.03	0	53.3	51.6	65.8	154	150	0	30	30
2014	7	13	1	0	9	0.157	0	0.751	0.039	0.039	0	54.2	52.5	62.8	156	151	0	30	29
2014	7	13	1	10	9	0.171	0.003	0.751	0.046	0.046	0	54.6	52.5	63.6	157	152	0	30	30
2014	7	13	1	20	9	0.167	0.039	0.751	0.043	0.039	0	52.5	51.6	64.5	153	150	0	31	30
2014	7	13	1	30	9	0.217	0.049	0.751	0.036	0.033	0	53.3	51.6	64.9	154	150	0	30	30
2014	7	13	1	40	9	0.118	-0.013	0.751	0.036	0.033	0	53.3	51.2	64.5	154	148	0	30	29
2014	7	13	1	50	9	0.213	0.056	0.751	0.033	0.03	0	52.5	51.2	65.4	153	149	0	31	30
2014	7	13	2	0	9	0.19	0	0.751	0.036	0.033	0	52.5	51.2	65.8	152	149	0	30	30
2014	7	13	2	10	9	0.138	-0.026	0.751	0.033	0.03	0	52.5	50.7	66.2	152	148	0	30	30
2014	7	13	2	20	9	0.194	0.043	0.748	0.033	0.03	0	52.9	52	65.4	153	150	0	30	29
2014	7	13	2	30	9	0.151	-0.02	0.748	0.039	0.039	0	52.5	51.6	64.9	152	150	0	30	30
2014	7	13	2	40	9	0.203	0	0.748	0.039	0.036	0	52.5	51.6	65.4	152	149	0	30	29
2014	7	13	2	50	9	0.174	-0.036	0.748	0.039	0.036	0	52.9	50.7	66.2	153	148	0	30	30
2014	7	13	3	0	9	0.151	0.039	0.748	0.036	0.033	0	52	50.7	66.2	151	148	0	30	30
2014	7	13	3	10	9	0.167	-0.023	0.748	0.036	0.033	0	50.3	49.9	67.5	148	146	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	3	20	9	0.171	0.01	0.748	0.033	0.03	0	50.7	50.3	67.5	148	146	0	30	29
2014	7	13	3	30	9	0.174	-0.02	0.748	0.036	0.033	0	52	50.7	66.2	151	147	0	30	29
2014	7	13	3	40	9	0.148	0.069	0.748	0.033	0.03	0	51.6	49.9	67.5	150	146	0	30	30
2014	7	13	3	50	9	0.115	0.049	0.748	0.03	0.03	0	51.2	50.3	67.5	149	147	0	30	30
2014	7	13	4	0	9	0.23	0.016	0.745	0.033	0.03	0	52	50.7	66.2	151	148	0	30	30
2014	7	13	4	10	9	0.174	0.007	0.745	0.046	0.043	0	52.5	50.7	65.8	152	148	0	30	30
2014	7	13	4	20	9	0.135	0.039	0.745	0.043	0.039	0	50.7	50.3	67.1	149	146	0	31	29
2014	7	13	4	30	9	0.148	-0.023	0.745	0.043	0.039	0	50.3	49.9	67.9	148	146	0	31	30
2014	7	13	4	40	9	0.213	-0.02	0.745	0.033	0.03	0	51.6	50.3	67.5	150	147	0	30	30
2014	7	13	4	50	9	0.21	0.059	0.745	0.036	0.033	0	50.7	49.9	67.1	149	145	0	31	29
2014	7	13	5	0	9	0.262	0.03	0.745	0.039	0.036	0	49.9	48.6	68.8	146	144	0	30	31
2014	7	13	5	10	9	0.203	-0.01	0.745	0.043	0.039	0	51.6	49.9	67.1	151	146	0	31	30
2014	7	13	5	20	9	0.135	-0.007	0.745	0.036	0.033	0	50.7	50.3	67.1	149	146	0	31	29
2014	7	13	5	30	9	0.19	-0.02	0.745	0.039	0.039	0	52.5	50.7	66.7	153	148	0	31	30
2014	7	13	5	40	9	0.249	-0.003	0.745	0.039	0.036	0	51.6	49.9	66.7	151	146	0	31	30
2014	7	13	5	50	9	0.135	0.023	0.741	0.036	0.033	0	52	50.3	66.2	151	147	0	30	30
2014	7	13	6	0	9	0.164	0.007	0.741	0.036	0.033	0	50.7	50.3	67.5	149	146	0	31	29
2014	7	13	6	10	9	0.177	0.02	0.741	0.036	0.033	0	51.2	50.3	68.4	149	147	0	30	30
2014	7	13	6	20	9	0.167	0	0.741	0.039	0.036	0	51.6	49.9	67.5	150	146	0	30	30
2014	7	13	6	30	9	0.213	0.03	0.741	0.036	0.033	0	50.7	49.9	67.5	149	146	0	31	30
2014	7	13	6	40	9	0.262	-0.046	0.741	0.039	0.036	0	50.3	49	68.4	148	144	0	31	30
2014	7	13	6	50	9	0.21	0.01	0.741	0.039	0.036	0	52	50.3	67.1	151	147	0	30	30
2014	7	13	7	0	9	0.144	-0.01	0.741	0.033	0.03	0	50.3	49	68.4	148	145	0	31	31
2014	7	13	7	10	9	0.161	0.026	0.741	0.033	0.03	0	49.9	49	68.8	147	144	0	31	30
2014	7	13	7	20	9	0.118	0.013	0.741	0.033	0.03	0	49.5	48.2	69.2	146	142	0	31	30
2014	7	13	7	30	9	0.164	0	0.741	0.039	0.036	0	50.7	49.9	67.9	149	146	0	31	30
2014	7	13	7	40	9	0.194	0.059	0.741	0.033	0.03	0	49.5	49	68.8	147	145	0	32	31
2014	7	13	7	50	9	0.174	-0.02	0.741	0.033	0.03	0	49.9	49	68.4	147	144	0	31	30
2014	7	13	8	0	9	0.187	-0.039	0.741	0.046	0.043	0	51.2	50.3	68.8	149	146	0	30	29
2014	7	13	8	10	9	0.217	0.02	0.741	0.033	0.03	0	49.9	48.6	69.2	147	143	0	31	30
2014	7	13	8	20	9	0.19	0	0.741	0.036	0.033	0	49.9	48.6	69.7	146	143	0	30	30
2014	7	13	8	30	9	0.131	-0.01	0.741	0.039	0.036	0	49.9	48.6	70.1	147	143	0	31	30
2014	7	13	8	40	9	0.148	0.013	0.741	0.043	0.039	0	48.6	47.7	71.4	143	141	0	30	30
2014	7	13	8	50	9	0.2	0.02	0.741	0.036	0.033	0	50.3	48.6	69.2	147	143	0	30	30
2014	7	13	9	0	9	0.174	-0.007	0.741	0.039	0.036	0	49.5	48.6	70.1	145	143	0	30	30
2014	7	13	9	10	9	0.164	-0.085	0.741	0.036	0.033	0	49.5	48.2	70.1	146	142	0	31	30
2014	7	13	9	20	9	0.167	-0.023	0.741	0.039	0.039	0	50.3	49	68.8	148	144	0	31	30
2014	7	13	9	30	9	0.203	-0.013	0.741	0.043	0.039	0	50.7	49.9	67.9	149	146	0	31	30
2014	7	13	9	40	9	0.164	0.026	0.741	0.036	0.033	0	51.2	49	69.7	149	144	0	30	30
2014	7	13	9	50	9	0.154	-0.02	0.741	0.036	0.033	0	50.3	49	69.7	147	144	0	30	30
2014	7	13	10	0	9	0.194	0.049	0.741	0.039	0.036	0	51.2	50.3	69.2	150	147	0	31	30
2014	7	13	10	10	9	0.174	0.052	0.741	0.046	0.043	0	52.5	51.2	67.9	153	149	0	31	30
2014	7	13	10	20	9	0.236	0.052	0.741	0.039	0.039	0	51.6	49.9	69.2	150	146	0	30	30
2014	7	13	10	30	9	0.213	0.046	0.741	0.043	0.039	0	51.6	50.7	68.8	151	147	0	31	29
2014	7	13	10	40	9	0.157	-0.013	0.738	0.039	0.036	0	52	50.3	68.8	151	147	0	30	30
2014	7	13	10	50	9	0.121	0.033	0.738	0.033	0.03	0	51.2	50.3	69.7	150	146	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	11	0	9	0.236	-0.013	0.738	0.039	0.039	0	52	51.2	68.8	152	149	0	31	30
2014	7	13	11	10	9	0.217	0.01	0.738	0.043	0.039	0	52.9	52.5	67.9	153	152	0	30	30
2014	7	13	11	20	9	0.203	0.062	0.738	0.039	0.039	0	52	51.6	68.4	151	150	0	30	30
2014	7	13	11	30	9	0.135	0.046	0.738	0.039	0.036	0	51.6	52	68.8	151	150	0	31	29
2014	7	13	11	40	9	0.167	0.023	0.735	0.036	0.033	0	52.5	52.9	66.7	153	152	0	31	29
2014	7	13	11	50	9	0.184	-0.033	0.735	0.036	0.033	0	54.6	53.3	66.2	157	153	0	30	29
2014	7	13	12	0	9	0.154	0.052	0.735	0.039	0.039	0	54.2	53.8	65.8	156	154	0	30	29
2014	7	13	12	10	9	0.203	0.052	0.735	0.036	0.033	0	53.8	52.5	65.8	155	152	0	30	30
2014	7	13	12	20	9	0.197	0.118	0.735	0.039	0.039	0	52.9	52.9	66.7	153	153	0	30	30
2014	7	13	12	30	9	0.161	0.049	0.735	0.036	0.033	0	52.9	53.8	65.8	154	154	0	31	29
2014	7	13	12	40	9	0.151	0.085	0.732	0.033	0.03	0	52.9	53.8	65.8	153	154	0	30	29
2014	7	13	12	50	9	0.131	0.056	0.732	0.033	0.03	0	53.3	53.8	64.9	154	155	0	30	30
2014	7	13	13	0	9	0.164	0.036	0.732	0.033	0.03	0	54.6	53.8	63.2	157	155	0	30	30
2014	7	13	13	10	9	0.154	0.112	0.728	0.033	0.03	0	55	55	63.6	158	157	0	30	29
2014	7	13	13	20	9	0.246	0.033	0.725	0.036	0.033	0	54.2	55	64.9	156	157	0	30	29
2014	7	13	13	30	9	0.194	0.036	0.725	0.036	0.033	0	53.8	54.6	63.6	156	156	0	31	29
2014	7	13	13	40	9	0.2	0.066	0.725	0.033	0.03	0	54.6	54.2	64.5	157	155	0	30	29
2014	7	13	13	50	9	0.256	0.036	0.719	0.033	0.03	0	54.6	55	65.4	157	157	0	30	29
2014	7	13	14	0	9	0.21	0.092	0.719	0.033	0.03	0	55.5	55.5	65.4	159	158	0	30	29
2014	7	13	14	10	9	0.256	0.016	0.715	0.033	0.03	0	55.9	55.5	64.1	160	158	0	30	29
2014	7	13	14	20	9	0.131	0.062	0.715	0.033	0.03	0	54.2	55	66.2	155	157	0	29	29
2014	7	13	14	30	9	0.18	0.062	0.712	0.036	0.033	0	55.5	55.5	65.4	159	158	0	30	29
2014	7	13	14	40	9	0.171	0.036	0.712	0.033	0.03	0	55	55.5	65.8	158	158	0	30	29
2014	7	13	14	50	9	0.141	0.036	0.712	0.036	0.033	0	56.3	56.3	66.2	161	160	0	30	29
2014	7	13	15	0	9	0.2	0.043	0.712	0.033	0.03	0	56.8	56.3	65.8	161	160	0	29	29
2014	7	13	15	10	9	0.144	0.049	0.712	0.033	0.03	0	55.9	55.9	65.8	160	159	0	30	29
2014	7	13	15	20	9	0.22	0.046	0.709	0.033	0.03	0	56.8	55.9	63.6	162	159	0	30	29
2014	7	13	15	30	9	0.167	0.095	0.709	0.033	0.03	0	53.3	53.8	67.9	154	154	0	30	29
2014	7	13	15	40	9	0.233	0.059	0.709	0.033	0.03	0	54.2	52.9	68.8	155	152	0	29	29
2014	7	13	15	50	9	0.171	0.062	0.709	0.03	0.026	0	54.6	55	69.7	157	157	0	30	29
2014	7	13	16	0	9	0.125	-0.023	0.709	0.033	0.03	0	54.6	53.8	67.5	157	154	0	30	29
2014	7	13	16	10	9	0.24	0.085	0.709	0.033	0.03	0	53.8	54.6	69.2	154	155	0	29	28
2014	7	13	16	20	9	0.207	0	0.709	0.033	0.03	0	53.8	53.8	68.4	154	154	0	29	29
2014	7	13	16	30	9	0.161	0.056	0.709	0.033	0.03	0	54.2	53.8	67.9	155	154	0	29	29
2014	7	13	16	40	9	0.207	0.112	0.709	0.033	0.03	0	54.2	54.2	69.2	155	154	0	29	28
2014	7	13	16	50	9	0.2	0.039	0.709	0.039	0.036	0	53.8	53.8	68.8	154	154	0	29	29
2014	7	13	17	0	9	0.21	0.079	0.705	0.033	0.03	0	54.6	53.3	67.9	157	153	0	30	29
2014	7	13	17	10	9	0.144	0.039	0.705	0.033	0.03	0	53.8	53.8	68.4	155	153	0	30	28
2014	7	13	17	20	9	0.21	0.016	0.705	0.033	0.03	0	53.3	53.3	68.8	154	153	0	30	29
2014	7	13	17	30	9	0.18	0.046	0.705	0.033	0.03	0	52.5	52	69.2	151	149	0	29	28
2014	7	13	17	40	9	0.24	0	0.705	0.033	0.03	0	49	49	71.8	142	143	0	28	29
2014	7	13	17	50	9	0.18	0.056	0.705	0.033	0.03	0	47.3	46.9	71.4	140	138	0	30	29
2014	7	13	18	0	9	0.167	0.066	0.702	0.036	0.033	0	46	46.4	73.1	137	137	0	30	29
2014	7	13	18	10	9	0.18	0.023	0.702	0.033	0.03	0	46	44.7	72.2	136	133	0	29	29
2014	7	13	18	20	9	0.18	-0.003	0.702	0.036	0.033	0	45.2	44.7	72.2	134	132	0	29	28
2014	7	13	18	30	9	0.177	0.128	0.702	0.033	0.03	0	45.6	45.2	71.4	136	133	0	30	28

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	18	40	9	0.148	0.157	0.702	0.039	0.036	0	47.3	45.2	71.4	139	134	0	29	29
2014	7	13	18	50	9	0.279	0.102	0.702	0.039	0.036	0	48.2	45.2	71	141	134	0	29	29
2014	7	13	19	0	9	0.217	0.102	0.702	0.039	0.039	0	47.3	45.6	70.5	139	135	0	29	29
2014	7	13	19	10	9	0.131	0.138	0.702	0.039	0.036	0	47.3	46	70.1	140	136	0	30	29
2014	7	13	19	20	9	0.203	0.141	0.702	0.039	0.036	0	46.9	46	70.5	139	135	0	30	28
2014	7	13	19	30	9	0.098	0.059	0.702	0.043	0.039	0	47.3	46.4	69.7	140	136	0	30	28
2014	7	13	19	40	9	0.23	0.121	0.702	0.036	0.033	0	47.3	46	70.1	139	135	0	29	28
2014	7	13	19	50	9	0.157	0.089	0.702	0.039	0.036	0	47.7	46	70.1	140	135	0	29	28
2014	7	13	20	0	9	0.22	0.049	0.699	0.033	0.03	0	48.2	46.4	70.5	141	137	0	29	29
2014	7	13	20	10	9	0.22	0.003	0.699	0.039	0.036	0	48.2	46.4	69.2	142	137	0	30	29
2014	7	13	20	20	9	0.141	0.108	0.699	0.036	0.033	0	49.5	47.3	69.2	144	139	0	29	29
2014	7	13	20	30	9	0.144	0.02	0.699	0.039	0.036	0	50.3	48.2	68.4	146	141	0	29	29
2014	7	13	20	40	9	0.18	0.016	0.699	0.033	0.03	0	49	47.7	69.2	144	140	0	30	29
2014	7	13	20	50	9	0.118	0.03	0.699	0.033	0.03	0	49.9	48.6	69.2	146	142	0	30	29
2014	7	13	21	0	9	0.115	0	0.699	0.039	0.036	0	49.5	48.2	69.2	144	140	0	29	28
2014	7	13	21	10	9	0.118	-0.01	0.699	0.039	0.039	0	50.7	49	68.8	147	143	0	29	29
2014	7	13	21	20	9	0.164	-0.059	0.702	0.039	0.039	0	51.6	49	67.9	149	143	0	29	29
2014	7	13	21	30	9	0.102	0.039	0.702	0.039	0.036	0	51.6	49.9	67.5	150	145	0	30	29
2014	7	13	21	40	9	0.184	-0.059	0.702	0.036	0.033	0	51.2	49	68.4	149	143	0	30	29
2014	7	13	21	50	9	0.118	0.039	0.702	0.033	0.03	0	51.6	50.7	67.9	150	146	0	30	28
2014	7	13	22	0	9	0.098	-0.02	0.702	0.039	0.039	0	51.6	50.7	67.9	150	146	0	30	28
2014	7	13	22	10	9	0.177	0.049	0.702	0.033	0.03	0	51.6	49.9	68.8	150	145	0	30	29
2014	7	13	22	20	9	0.148	0.016	0.702	0.039	0.039	0	50.7	49.5	69.2	148	144	0	30	29
2014	7	13	22	30	9	0.226	0.013	0.705	0.033	0.033	0	51.6	49.9	69.2	150	145	0	30	29
2014	7	13	22	40	9	0.157	0.007	0.705	0.033	0.03	0	52.5	50.3	68.8	151	146	0	29	29
2014	7	13	22	50	9	0.177	0.016	0.705	0.033	0.03	0	52	49.5	69.2	150	144	0	29	29
2014	7	13	23	0	9	0.141	0.023	0.705	0.036	0.033	0	50.7	49	70.1	148	143	0	30	29
2014	7	13	23	10	9	0.092	-0.02	0.705	0.033	0.03	0	51.2	50.7	70.1	149	146	0	30	28
2014	7	13	23	20	9	0.115	0	0.705	0.033	0.03	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	13	23	30	9	0.066	0.02	0.705	0.039	0.039	0	51.6	50.3	69.7	150	146	0	30	29
2014	7	13	23	40	9	0.135	0.02	0.705	0.036	0.033	0	52	51.2	68.4	150	148	0	29	29
2014	7	13	23	50	9	0.167	0.01	0.705	0.036	0.033	0	53.3	52.5	67.5	154	150	0	30	28
2014	7	14	0	0	9	0.171	-0.036	0.705	0.033	0.03	0	52	50.7	69.7	150	147	0	29	29
2014	7	14	0	10	9	0.148	-0.007	0.705	0.036	0.033	0	52.5	49.9	68.8	152	145	0	30	29
2014	7	14	0	20	9	0.177	-0.046	0.705	0.03	0.03	0	53.3	51.6	67.9	153	149	0	29	29
2014	7	14	0	30	9	0.21	0.046	0.705	0.036	0.033	0	52.9	51.6	67.5	153	149	0	30	29
2014	7	14	0	40	9	0.154	0	0.705	0.036	0.033	0	53.8	52	67.5	155	149	0	30	28
2014	7	14	0	50	9	0.112	-0.066	0.705	0.036	0.033	0	54.2	52.5	67.1	155	151	0	29	29
2014	7	14	1	0	9	0.233	0	0.705	0.039	0.039	0	54.2	52.5	66.7	156	151	0	30	29
2014	7	14	1	10	9	0.121	0.026	0.705	0.043	0.039	0	53.3	52	67.1	154	150	0	30	29
2014	7	14	1	20	9	0.135	0.092	0.705	0.039	0.036	0	53.8	52	66.7	154	150	0	29	29
2014	7	14	1	30	9	0.121	0.059	0.705	0.033	0.03	0	53.3	51.2	67.9	154	148	0	30	29
2014	7	14	1	40	9	0.171	0.036	0.705	0.039	0.036	0	52.9	51.6	68.4	153	149	0	30	29
2014	7	14	1	50	9	0.112	-0.007	0.705	0.036	0.033	0	52.5	51.2	67.9	152	148	0	30	29
2014	7	14	2	0	9	0.128	0.033	0.705	0.036	0.033	0	52	51.2	69.7	151	148	0	30	29
2014	7	14	2	10	9	0.141	0.052	0.705	0.033	0.03	0	52	51.2	69.2	151	148	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	2	20	9	0.118	0.013	0.705	0.033	0.03	0	52	51.2	69.7	151	148	0	30	29
2014	7	14	2	30	9	0.174	0.016	0.705	0.039	0.036	0	51.2	49.9	70.1	148	145	0	29	29
2014	7	14	2	40	9	0.131	0	0.705	0.03	0.03	0	50.3	50.7	70.1	148	147	0	31	29
2014	7	14	2	50	9	0.118	0.016	0.709	0.033	0.03	0	51.2	50.3	68.8	148	146	0	29	29
2014	7	14	3	0	9	0.095	0.007	0.709	0.033	0.03	0	50.7	49.5	70.1	148	144	0	30	29
2014	7	14	3	10	9	0.157	-0.013	0.709	0.033	0.03	0	51.2	50.3	69.2	149	146	0	30	29
2014	7	14	3	20	9	0.177	0.02	0.709	0.033	0.03	0	50.3	49	69.2	147	144	0	30	30
2014	7	14	3	30	9	0.138	-0.003	0.712	0.033	0.03	0	51.2	49.5	67.9	149	145	0	30	30
2014	7	14	3	40	9	0.164	-0.023	0.712	0.033	0.03	0	51.2	50.7	68.4	149	147	0	30	29
2014	7	14	3	50	9	0.128	-0.026	0.715	0.033	0.03	0	52	50.7	67.5	151	147	0	30	29
2014	7	14	4	0	9	0.125	-0.02	0.719	0.033	0.03	0	50.3	49.5	67.1	147	145	0	30	30
2014	7	14	4	10	9	0.079	-0.036	0.725	0.033	0.03	0	49	49	67.5	144	143	0	30	29
2014	7	14	4	20	9	0.171	0.056	0.728	0.036	0.033	0	51.2	50.3	68.4	149	146	0	30	29
2014	7	14	4	30	9	0.236	0	0.732	0.039	0.036	0	49.5	48.6	68.4	145	143	0	30	30
2014	7	14	4	40	9	0.171	0.02	0.732	0.033	0.03	0	50.3	49	69.7	147	144	0	30	30
2014	7	14	4	50	9	0.174	-0.007	0.735	0.033	0.03	0	49.9	49.9	71	146	145	0	30	29
2014	7	14	5	0	9	0.217	0.016	0.735	0.033	0.03	0	49.9	49.5	70.5	146	144	0	30	29
2014	7	14	5	10	9	0.141	0.013	0.738	0.033	0.03	0	50.3	49.9	71.4	147	145	0	30	29
2014	7	14	5	20	9	0.161	0.02	0.738	0.039	0.036	0	49.9	49.5	72.7	146	145	0	30	30
2014	7	14	5	30	9	0.151	0.03	0.738	0.033	0.03	0	49.5	48.6	71.8	145	142	0	30	29
2014	7	14	5	40	9	0.069	0.03	0.741	0.033	0.03	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	14	5	50	9	0.157	-0.052	0.741	0.036	0.033	0	48.2	47.3	73.1	142	140	0	30	30
2014	7	14	6	0	9	0.167	0.016	0.741	0.033	0.03	0	47.7	47.3	72.2	142	140	0	31	30
2014	7	14	6	10	9	0.167	-0.033	0.741	0.039	0.036	0	47.7	46.4	71.8	141	137	0	30	29
2014	7	14	6	20	9	0.144	0	0.741	0.036	0.033	0	48.2	46.9	72.2	142	139	0	30	30
2014	7	14	6	30	9	0.167	-0.03	0.745	0.033	0.03	0	46.9	46	73.1	139	137	0	30	30
2014	7	14	6	40	9	0.19	-0.013	0.745	0.033	0.03	0	47.3	46.4	72.2	141	138	0	31	30
2014	7	14	6	50	9	0.161	0.003	0.745	0.039	0.036	0	47.3	45.6	71.8	141	136	0	31	30
2014	7	14	7	0	9	0.184	0.089	0.745	0.033	0.03	0	46.9	46	71.4	139	137	0	30	30
2014	7	14	7	10	9	0.2	0.026	0.745	0.033	0.03	0	46.9	46.4	71.8	139	138	0	30	30
2014	7	14	7	20	9	0.121	0.098	0.745	0.036	0.033	0	46	45.6	72.7	138	136	0	31	30
2014	7	14	7	30	9	0.144	0.026	0.745	0.036	0.033	0	46.4	46	72.2	138	137	0	30	30
2014	7	14	7	40	9	0.164	-0.02	0.745	0.033	0.03	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	14	7	50	9	0.167	0.023	0.745	0.039	0.039	0	46.4	45.2	72.7	138	135	0	30	30
2014	7	14	8	0	9	0.128	0.023	0.745	0.033	0.03	0	45.2	45.2	71.8	136	135	0	31	30
2014	7	14	8	10	9	0.112	0.013	0.745	0.039	0.036	0	46.4	44.3	72.7	137	133	0	29	30
2014	7	14	8	20	9	0.138	0.036	0.745	0.039	0.036	0	45.2	45.2	73.5	135	134	0	30	29
2014	7	14	8	30	9	0.174	-0.02	0.745	0.033	0.03	0	46.4	45.6	72.7	139	135	0	31	29
2014	7	14	8	40	9	0.217	-0.043	0.745	0.036	0.033	0	45.6	44.7	72.7	136	134	0	30	30
2014	7	14	8	50	9	0.194	0.056	0.745	0.039	0.036	0	46.4	44.7	72.7	138	134	0	30	30
2014	7	14	9	0	9	0.207	0.016	0.745	0.036	0.033	0	46	45.2	71.8	138	135	0	31	30
2014	7	14	9	10	9	0.128	0.056	0.745	0.036	0.033	0	46.4	44.7	72.7	139	134	0	31	30
2014	7	14	9	20	9	0.174	0.062	0.745	0.036	0.033	0	48.2	46.4	72.7	142	138	0	30	30
2014	7	14	9	30	9	0.167	0.079	0.745	0.033	0.03	0	46.9	45.6	73.1	139	135	0	30	29
2014	7	14	9	40	9	0.138	0.072	0.745	0.033	0.03	0	44.7	44.7	73.1	135	134	0	31	30
2014	7	14	9	50	9	0.164	-0.046	0.745	0.036	0.033	0	46.4	45.2	73.5	137	135	0	29	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	10	0	9	0.187	0.016	0.745	0.036	0.033	0	46.9	46.4	72.7	140	138	0	31	30
2014	7	14	10	10	9	0.167	-0.03	0.741	0.036	0.033	0	50.3	48.6	70.5	147	143	0	30	30
2014	7	14	10	20	9	0.174	-0.013	0.741	0.036	0.033	0	50.3	48.6	70.5	147	143	0	30	30
2014	7	14	10	30	9	0.226	0.066	0.741	0.039	0.039	0	49.9	48.6	70.1	146	143	0	30	30
2014	7	14	10	40	9	0.154	0.043	0.745	0.033	0.03	0	49.5	48.6	70.1	145	143	0	30	30
2014	7	14	10	50	9	0.217	0.01	0.745	0.039	0.039	0	48.6	47.7	70.5	144	141	0	31	30
2014	7	14	11	0	9	0.24	0.049	0.745	0.039	0.039	0	49.5	48.2	70.5	145	141	0	30	29
2014	7	14	11	10	9	0.24	0.072	0.741	0.036	0.033	0	49.5	48.6	71	145	143	0	30	30
2014	7	14	11	20	9	0.213	-0.039	0.741	0.033	0.03	0	50.3	49	69.7	147	144	0	30	30
2014	7	14	11	30	9	0.161	0.098	0.745	0.033	0.03	0	49.5	48.2	70.1	146	142	0	31	30
2014	7	14	11	40	9	0.21	0.043	0.745	0.039	0.036	0	49.5	47.7	71.4	145	141	0	30	30
2014	7	14	11	50	9	0.233	0.059	0.745	0.043	0.039	0	49	49	71	145	144	0	31	30
2014	7	14	12	2	18	0.187	0.049	0.745	0.033	0.03	0	50.7	49.9	70.5	148	145	0	30	29
2014	7	14	12	12	18	0.24	-0.003	0.745	0.033	0.03	0	50.3	50.7	70.1	147	147	0	30	29
2014	7	14	12	22	18	0.19	0.026	0.745	0.033	0.03	0	50.7	50.3	68.8	148	147	0	30	30
2014	7	14	12	32	18	0.167	0.036	0.745	0.036	0.033	0	51.2	50.7	69.7	148	147	0	29	29
2014	7	14	12	42	18	0.289	0.01	0.745	0.039	0.036	0	51.2	50.7	69.2	149	147	0	30	29
2014	7	14	12	52	18	0.249	0.033	0.745	0.036	0.033	0	50.3	49.5	69.2	147	145	0	30	30
2014	7	14	13	2	18	0.187	0.052	0.745	0.033	0.03	0	50.3	49.5	70.5	147	145	0	30	30
2014	7	14	13	12	18	0.2	0.01	0.745	0.033	0.03	0	51.6	51.2	69.2	150	149	0	30	30
2014	7	14	13	22	18	0.266	0.056	0.745	0.039	0.036	0	51.6	50.7	69.2	150	148	0	30	30
2014	7	14	13	32	18	0.246	0.043	0.745	0.036	0.033	0	50.7	51.2	68.8	148	148	0	30	29
2014	7	14	13	42	18	0.207	0	0.748	0.033	0.03	0	50.3	50.7	69.7	147	147	0	30	29
2014	7	14	13	52	18	0.197	0.102	0.748	0.039	0.036	0	49.5	49.5	71	146	144	0	31	29
2014	7	14	14	2	18	0.213	0.079	0.748	0.033	0.03	0	50.3	50.7	69.2	147	147	0	30	29
2014	7	14	14	12	18	0.22	0.056	0.748	0.033	0.03	0	50.3	49.9	70.1	146	145	0	29	29
2014	7	14	14	22	18	0.23	0.072	0.748	0.033	0.03	0	51.2	50.3	70.1	149	146	0	30	29
2014	7	14	14	32	18	0.272	0.135	0.748	0.039	0.036	0	51.6	51.2	68.4	150	149	0	30	30
2014	7	14	14	42	18	0.233	0.112	0.748	0.039	0.036	0	49.5	48.6	70.5	145	142	0	30	29
2014	7	14	14	52	18	0.161	0.066	0.748	0.033	0.03	0	48.2	47.3	71	142	139	0	30	29
2014	7	14	15	2	18	0.236	0.046	0.748	0.036	0.033	0	48.6	47.7	71	143	140	0	30	29
2014	7	14	15	12	18	0.233	0.082	0.748	0.036	0.033	0	49.5	47.7	70.5	145	140	0	30	29
2014	7	14	15	22	18	0.194	0	0.748	0.033	0.03	0	50.7	49	69.7	147	143	0	29	29
2014	7	14	15	32	18	0.167	0.105	0.751	0.039	0.039	0	48.2	47.3	71	142	139	0	30	29
2014	7	14	15	42	18	0.253	0.092	0.751	0.033	0.03	0	47.3	46.9	72.2	140	137	0	30	28
2014	7	14	15	52	18	0.21	0.059	0.748	0.046	0.043	0	47.7	46.9	71.4	140	138	0	29	29
2014	7	14	16	2	18	0.203	0.085	0.751	0.043	0.039	0	48.6	47.3	69.7	142	139	0	29	29
2014	7	14	16	12	18	0.233	0.059	0.751	0.033	0.03	0	49.9	48.2	70.1	146	141	0	30	29
2014	7	14	16	22	18	0.253	0.066	0.751	0.039	0.039	0	49	48.2	70.1	144	141	0	30	29
2014	7	14	16	32	18	0.167	0.082	0.751	0.039	0.036	0	49.9	48.6	70.5	145	142	0	29	29
2014	7	14	16	42	18	0.226	0.095	0.751	0.033	0.03	0	49.5	47.7	70.5	145	140	0	30	29
2014	7	14	16	52	18	0.194	0.105	0.751	0.033	0.03	0	49.5	48.6	69.2	145	142	0	30	29
2014	7	14	17	2	18	0.22	0.095	0.751	0.033	0.03	0	49.9	47.7	69.7	145	140	0	29	29
2014	7	14	17	12	18	0.194	0.118	0.751	0.033	0.03	0	49.9	48.6	70.1	146	142	0	30	29
2014	7	14	17	22	18	0.21	0.118	0.751	0.039	0.036	0	49.9	49	68.8	146	143	0	30	29
2014	7	14	17	32	18	0.233	0.059	0.751	0.036	0.033	0	49	48.2	70.5	144	140	0	30	28

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	17	42	18	0.194	0.144	0.751	0.039	0.036	0	46.4	46.4	71.4	138	137	0	30	29
2014	7	14	17	52	18	0.272	0.118	0.751	0.036	0.033	0	48.2	47.7	70.1	142	140	0	30	29
2014	7	14	18	2	18	0.256	0.066	0.751	0.039	0.036	0	48.2	47.3	69.7	142	139	0	30	29
2014	7	14	18	12	18	0.305	0.023	0.751	0.039	0.036	0	48.6	47.3	69.2	143	139	0	30	29
2014	7	14	18	22	18	0.213	0	0.751	0.043	0.039	0	49	47.3	69.2	144	139	0	30	29
2014	7	14	18	32	18	0.322	0.125	0.755	0.043	0.043	0	48.6	46.9	68.8	143	138	0	30	29
2014	7	14	18	42	18	0.243	0.039	0.755	0.039	0.036	0	48.6	46.9	68.4	143	138	0	30	29
2014	7	14	18	52	18	0.164	-0.013	0.755	0.039	0.036	0	50.3	47.7	66.7	146	140	0	29	29
2014	7	14	19	2	18	0.203	0.069	0.751	0.043	0.039	0	51.6	49.9	65.8	150	145	0	30	29
2014	7	14	19	12	18	0.253	0.016	0.755	0.039	0.036	0	51.2	49.5	66.2	149	144	0	30	29
2014	7	14	19	22	18	0.253	0.026	0.755	0.039	0.036	0	50.7	49	67.5	148	143	0	30	29
2014	7	14	19	32	18	0.174	0.013	0.755	0.039	0.036	0	49.9	48.6	66.2	146	142	0	30	29
2014	7	14	19	42	18	0.217	-0.016	0.758	0.049	0.046	0	49.5	47.7	67.1	145	140	0	30	29
2014	7	14	19	52	18	0.135	-0.01	0.758	0.039	0.036	0	49.5	48.2	66.7	145	141	0	30	29
2014	7	14	20	2	18	0.194	0	0.758	0.043	0.039	0	49.5	48.2	67.9	145	141	0	30	29
2014	7	14	20	12	18	0.253	0.016	0.761	0.036	0.033	0	50.3	47.7	66.7	147	141	0	30	30
2014	7	14	20	22	18	0.197	-0.03	0.761	0.039	0.036	0	52	50.3	64.5	152	146	0	31	29
2014	7	14	20	32	18	0.194	0.089	0.761	0.033	0.03	0	52	49.9	64.5	151	145	0	30	29
2014	7	14	20	42	18	0.243	-0.036	0.761	0.039	0.039	0	53.3	51.6	63.2	154	149	0	30	29
2014	7	14	20	52	18	0.125	0.007	0.764	0.036	0.033	0	53.8	51.6	63.2	155	150	0	30	30
2014	7	14	21	2	18	0.138	-0.016	0.764	0.046	0.043	0	54.2	52	63.2	156	150	0	30	29
2014	7	14	21	12	18	0.154	0	0.768	0.039	0.036	0	53.3	51.2	64.5	154	148	0	30	29
2014	7	14	21	22	18	0.22	0	0.768	0.033	0.03	0	52.9	50.7	65.4	153	147	0	30	29
2014	7	14	21	32	18	0.243	0.036	0.771	0.049	0.046	0	51.6	50.7	66.2	150	147	0	30	29
2014	7	14	21	42	18	0.184	0.066	0.771	0.036	0.033	0	52	51.2	65.8	151	148	0	30	29
2014	7	14	21	52	18	0.22	0	0.771	0.033	0.03	0	50.7	49.5	67.9	148	144	0	30	29
2014	7	14	22	2	18	0.203	-0.036	0.771	0.033	0.03	0	49.9	48.6	69.7	146	142	0	30	29
2014	7	14	22	12	18	0.174	-0.069	0.774	0.033	0.03	0	50.3	49	69.2	147	143	0	30	29
2014	7	14	22	22	18	0.19	0.023	0.774	0.036	0.033	0	50.3	48.6	68.8	147	143	0	30	30
2014	7	14	22	32	18	0.19	0	0.774	0.036	0.033	0	50.3	48.6	68.8	147	143	0	30	30
2014	7	14	22	42	18	0.187	-0.046	0.774	0.043	0.039	0	50.7	50.3	67.5	149	146	0	31	29
2014	7	14	22	52	18	0.23	-0.039	0.774	0.039	0.036	0	51.6	50.3	68.4	150	146	0	30	29
2014	7	14	23	2	18	0.246	0.016	0.774	0.043	0.039	0	51.6	50.3	68.4	150	146	0	30	29
2014	7	14	23	12	18	0.154	0.01	0.774	0.033	0.03	0	51.2	50.7	68.8	149	147	0	30	29
2014	7	14	23	22	18	0.279	0.003	0.774	0.039	0.036	0	52	50.3	67.9	151	147	0	30	30
2014	7	14	23	32	18	0.213	0.079	0.778	0.039	0.036	0	51.2	49.9	70.1	149	146	0	30	30
2014	7	14	23	42	18	0.174	0.036	0.778	0.039	0.039	0	51.6	51.2	68.8	150	148	0	30	29
2014	7	14	23	52	18	0.171	0.013	0.778	0.039	0.036	0	50.7	49.9	70.1	148	145	0	30	29
2014	7	15	0	2	18	0.157	0	0.778	0.036	0.033	0	51.6	49.9	70.1	150	146	0	30	30
2014	7	15	0	12	18	0.246	0.052	0.778	0.043	0.039	0	51.2	49	71	149	144	0	30	30
2014	7	15	0	22	18	0.2	-0.02	0.778	0.039	0.036	0	50.7	49	71	148	144	0	30	30
2014	7	15	0	32	18	0.23	-0.02	0.778	0.039	0.036	0	51.2	49.5	71	149	145	0	30	30
2014	7	15	0	42	18	0.217	0.066	0.778	0.043	0.039	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	15	0	52	18	0.272	0.059	0.778	0.033	0.03	0	51.2	49.5	70.5	149	144	0	30	29
2014	7	15	1	2	18	0.138	0.059	0.778	0.052	0.049	0	50.3	49	70.5	147	144	0	30	30
2014	7	15	1	12	18	0.161	0	0.778	0.036	0.033	0	50.7	49.5	70.5	149	144	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	1	22	18	0.167	-0.039	0.778	0.033	0.03	0	50.7	48.6	71	148	143	0	30	30
2014	7	15	1	32	18	0.187	-0.069	0.778	0.039	0.036	0	50.3	49.5	71	147	145	0	30	30
2014	7	15	1	42	18	0.184	0.003	0.778	0.036	0.033	0	50.7	49.5	71	148	145	0	30	30
2014	7	15	1	52	18	0.187	-0.023	0.778	0.039	0.036	0	49.9	49	71.4	147	144	0	31	30
2014	7	15	2	2	18	0.187	0.062	0.778	0.033	0.03	0	50.7	49	70.5	149	144	0	31	30
2014	7	15	2	12	18	0.174	0.007	0.778	0.033	0.03	0	51.2	49.9	70.1	150	146	0	31	30
2014	7	15	2	22	18	0.23	0.062	0.778	0.039	0.039	0	51.6	49.5	69.2	150	145	0	30	30
2014	7	15	2	32	18	0.167	0.007	0.778	0.039	0.039	0	50.7	50.3	71	149	147	0	31	30
2014	7	15	2	42	18	0.154	0.003	0.778	0.039	0.036	0	52	49.5	68.8	151	145	0	30	30
2014	7	15	2	52	18	0.236	0.052	0.778	0.039	0.039	0	50.7	49.5	70.1	148	145	0	30	30
2014	7	15	3	2	18	0.259	0.016	0.778	0.039	0.039	0	50.3	49.5	70.5	148	145	0	31	30
2014	7	15	3	12	18	0.233	0.059	0.778	0.033	0.03	0	50.3	48.6	71	147	143	0	30	30
2014	7	15	3	22	18	0.246	-0.039	0.778	0.033	0.03	0	49.9	49.9	70.5	147	145	0	31	29
2014	7	15	3	32	18	0.249	-0.016	0.781	0.036	0.033	0	50.3	48.6	71	147	143	0	30	30
2014	7	15	3	42	18	0.203	0.066	0.778	0.033	0.03	0	49.5	49	71.8	146	143	0	31	29
2014	7	15	3	52	18	0.223	0.072	0.781	0.033	0.03	0	49.9	49.9	71	147	145	0	31	29
2014	7	15	4	2	18	0.24	0	0.778	0.036	0.033	0	51.6	49.5	69.7	150	145	0	30	30
2014	7	15	4	12	18	0.197	-0.03	0.778	0.039	0.036	0	51.2	49.9	70.1	149	146	0	30	30
2014	7	15	4	22	18	0.184	0.036	0.778	0.039	0.036	0	51.6	50.7	69.7	150	148	0	30	30
2014	7	15	4	32	18	0.233	0.033	0.781	0.039	0.036	0	51.2	49.9	69.7	149	146	0	30	30
2014	7	15	4	42	18	0.138	-0.016	0.778	0.039	0.036	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	15	4	52	18	0.249	0.026	0.781	0.033	0.03	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	15	5	2	18	0.164	-0.013	0.781	0.033	0.03	0	50.3	49.5	70.5	148	145	0	31	30
2014	7	15	5	12	18	0.108	-0.003	0.781	0.036	0.033	0	51.2	49.9	69.7	149	146	0	30	30
2014	7	15	5	22	18	0.148	0	0.781	0.039	0.036	0	49.9	49	71.8	147	144	0	31	30
2014	7	15	5	32	18	0.154	0	0.781	0.039	0.036	0	49.9	49.5	71	146	144	0	30	29
2014	7	15	5	42	18	0.249	0.052	0.781	0.046	0.043	0	49.5	48.6	71	146	143	0	31	30
2014	7	15	5	52	18	0.226	0.016	0.781	0.033	0.03	0	48.6	48.6	71.8	144	143	0	31	30
2014	7	15	6	2	18	0.151	0.036	0.781	0.039	0.036	0	50.3	49.9	69.7	148	145	0	31	29
2014	7	15	6	12	18	0.233	-0.072	0.781	0.039	0.036	0	50.7	49.5	69.2	149	145	0	31	30
2014	7	15	6	22	18	0.19	-0.062	0.781	0.039	0.036	0	51.2	49.5	68.8	149	145	0	30	30
2014	7	15	6	32	18	0.266	0.003	0.781	0.036	0.033	0	50.7	49.5	69.2	149	145	0	31	30
2014	7	15	6	42	18	0.213	-0.007	0.781	0.039	0.036	0	50.7	49	70.5	148	144	0	30	30
2014	7	15	6	52	18	0.184	0.046	0.781	0.033	0.03	0	49.9	48.6	69.7	146	143	0	30	30
2014	7	15	7	2	18	0.203	0.013	0.781	0.039	0.039	0	49	48.2	71	145	142	0	31	30
2014	7	15	7	12	18	0.171	-0.075	0.781	0.046	0.046	0	50.3	48.6	69.2	148	143	0	31	30
2014	7	15	7	22	18	0.141	0.036	0.781	0.039	0.036	0	51.2	49.5	68.8	150	146	0	31	31
2014	7	15	7	32	18	0.174	0.013	0.781	0.043	0.039	0	51.2	49.5	69.2	149	145	0	30	30
2014	7	15	7	42	18	0.22	0.016	0.781	0.043	0.039	0	50.7	49	68.8	148	144	0	30	30
2014	7	15	7	52	18	0.236	-0.036	0.778	0.039	0.039	0	51.2	50.3	67.9	150	146	0	31	29
2014	7	15	8	2	18	0.266	0.056	0.778	0.033	0.03	0	51.2	49	67.5	149	144	0	30	30
2014	7	15	8	12	18	0.144	-0.003	0.778	0.039	0.036	0	51.2	50.3	67.1	150	146	0	31	29
2014	7	15	8	22	18	0.141	0.013	0.778	0.039	0.039	0	50.7	49	70.1	149	144	0	31	30
2014	7	15	8	32	18	0.266	0.056	0.781	0.033	0.03	0	49.5	48.6	69.2	146	142	0	31	29
2014	7	15	8	42	18	0.226	-0.02	0.781	0.033	0.03	0	49.5	47.7	71	145	141	0	30	30
2014	7	15	8	52	18	0.171	0.02	0.778	0.039	0.039	0	49	47.7	71.8	144	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	9	2	18	0.167	0.01	0.781	0.036	0.033	0	49	47.7	71.4	144	140	0	30	29
2014	7	15	9	12	18	0.194	-0.059	0.781	0.033	0.03	0	49.5	48.2	70.5	145	142	0	30	30
2014	7	15	9	22	18	0.128	-0.003	0.781	0.039	0.039	0	49.5	48.2	71	145	142	0	30	30
2014	7	15	9	32	18	0.167	0.02	0.781	0.039	0.039	0	51.2	49.5	70.1	149	145	0	30	30
2014	7	15	9	42	18	0.207	-0.039	0.781	0.039	0.039	0	50.3	48.6	69.7	147	143	0	30	30
2014	7	15	9	52	18	0.184	-0.007	0.781	0.036	0.033	0	50.7	49	69.2	148	143	0	30	29
2014	7	15	10	2	18	0.243	0.059	0.781	0.039	0.039	0	48.6	47.7	70.5	144	140	0	31	29
2014	7	15	10	12	18	0.203	-0.052	0.784	0.036	0.033	0	49	46.9	70.5	145	139	0	31	30
2014	7	15	10	22	18	0.21	-0.02	0.784	0.043	0.039	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	15	10	32	18	0.197	0	0.787	0.036	0.033	0	48.6	47.7	70.1	143	140	0	30	29
2014	7	15	10	42	18	0.233	0.072	0.787	0.033	0.03	0	49.5	47.7	69.2	145	141	0	30	30
2014	7	15	10	52	18	0.282	-0.016	0.791	0.036	0.033	0	48.2	47.3	69.2	142	139	0	30	29
2014	7	15	11	2	18	0.279	-0.026	0.801	0.033	0.03	0	48.6	48.2	67.1	144	141	0	31	29
2014	7	15	11	12	18	0.23	-0.03	0.804	0.039	0.036	0	48.6	46.9	68.8	143	139	0	30	30
2014	7	15	11	22	18	0.22	0.013	0.807	0.033	0.03	0	48.6	47.7	69.7	144	140	0	31	29
2014	7	15	11	32	18	0.246	0.046	0.81	0.033	0.03	0	48.2	46.4	70.5	142	138	0	30	30
2014	7	15	11	42	18	0.22	0.062	0.814	0.036	0.033	0	47.7	46.4	72.7	141	138	0	30	30
2014	7	15	11	52	18	0.226	0.02	0.817	0.033	0.03	0	47.7	46.9	72.7	140	139	0	29	30
2014	7	15	12	2	18	0.259	0.007	0.817	0.039	0.036	0	48.6	47.3	72.2	143	140	0	30	30
2014	7	15	12	12	18	0.217	0.049	0.817	0.046	0.043	0	49.5	48.2	72.2	145	142	0	30	30
2014	7	15	12	22	18	0.315	0.036	0.82	0.039	0.036	0	49.9	48.2	71.4	146	142	0	30	30
2014	7	15	12	32	18	0.262	-0.01	0.82	0.036	0.033	0	49.9	48.6	71.4	147	143	0	31	30
2014	7	15	12	42	18	0.266	0.016	0.82	0.033	0.03	0	49.5	49	70.5	146	144	0	31	30
2014	7	15	12	52	18	0.24	0.075	0.823	0.039	0.039	0	49.5	48.6	70.5	145	143	0	30	30
2014	7	15	13	2	18	0.322	0.148	0.823	0.033	0.03	0	50.7	49.5	69.7	148	145	0	30	30
2014	7	15	13	12	18	0.308	0.125	0.823	0.039	0.039	0	50.7	49.5	69.7	148	145	0	30	30
2014	7	15	13	22	18	0.305	-0.01	0.827	0.039	0.036	0	50.3	49.5	69.7	147	144	0	30	29
2014	7	15	13	32	18	0.262	-0.003	0.827	0.036	0.033	0	50.7	49.9	69.2	148	145	0	30	29
2014	7	15	13	42	18	0.269	0.016	0.83	0.036	0.033	0	50.7	49.9	68.8	148	145	0	30	29
2014	7	15	13	52	18	0.331	0.052	0.83	0.039	0.039	0	51.2	50.3	69.2	149	145	0	30	28
2014	7	15	14	2	18	0.312	0.023	0.83	0.046	0.043	0	51.2	49.9	68.4	149	145	0	30	29
2014	7	15	14	12	18	0.348	0.118	0.833	0.036	0.033	0	50.7	50.3	68.4	148	146	0	30	29
2014	7	15	14	22	18	0.256	0.151	0.833	0.036	0.033	0	50.7	49.5	68.4	148	144	0	30	29
2014	7	15	14	32	18	0.315	0.092	0.833	0.036	0.033	0	51.6	50.7	67.9	150	147	0	30	29
2014	7	15	14	42	18	0.312	0.102	0.833	0.049	0.049	0	50.3	49.5	67.1	147	145	0	30	30
2014	7	15	14	52	18	0.341	0.115	0.837	0.039	0.039	0	50.3	49.5	68.4	147	144	0	30	29
2014	7	15	15	2	18	0.282	0.046	0.837	0.039	0.036	0	49.5	48.6	68.8	145	142	0	30	29
2014	7	15	15	12	18	0.292	0.128	0.837	0.039	0.036	0	50.7	49.5	67.9	148	144	0	30	29
2014	7	15	15	22	18	0.367	0.157	0.84	0.039	0.036	0	51.2	49.5	67.1	149	144	0	30	29
2014	7	15	15	32	18	0.308	0.115	0.84	0.036	0.033	0	50.3	49.9	67.9	147	145	0	30	29
2014	7	15	15	42	18	0.404	0.167	0.84	0.039	0.039	0	50.7	49.5	67.5	148	144	0	30	29
2014	7	15	15	52	18	0.285	0.177	0.84	0.033	0.03	0	51.2	48.6	67.9	148	143	0	29	30
2014	7	15	16	2	18	0.312	0.079	0.84	0.039	0.039	0	49.9	49.5	67.9	146	143	0	30	28
2014	7	15	16	12	18	0.315	0.115	0.84	0.043	0.039	0	49.9	48.6	68.4	146	142	0	30	29
2014	7	15	16	22	18	0.312	0.21	0.843	0.039	0.039	0	49.5	48.2	68.8	145	141	0	30	29
2014	7	15	16	32	18	0.308	0.144	0.846	0.036	0.033	0	49	47.7	67.9	144	140	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	16	42	18	0.276	0.213	0.846	0.039	0.036	0	49.9	48.2	68.4	146	141	0	30	29
2014	7	15	16	52	18	0.302	0.105	0.846	0.039	0.036	0	49.9	49	67.9	146	143	0	30	29
2014	7	15	17	2	18	0.335	0.18	0.846	0.039	0.036	0	49.9	48.6	67.5	146	142	0	30	29
2014	7	15	17	12	18	0.387	0.177	0.85	0.039	0.036	0	49.5	47.7	68.4	145	140	0	30	29
2014	7	15	17	22	18	0.354	0.112	0.85	0.036	0.033	0	49.5	47.7	68.8	145	140	0	30	29
2014	7	15	17	32	18	0.276	0.092	0.85	0.039	0.036	0	49.5	47.3	68.8	145	139	0	30	29
2014	7	15	17	42	18	0.348	0.135	0.85	0.046	0.043	0	49	47.3	69.2	143	139	0	29	29
2014	7	15	17	52	18	0.295	0.164	0.853	0.039	0.036	0	48.2	47.3	69.2	142	139	0	30	29
2014	7	15	18	2	18	0.364	0.121	0.853	0.039	0.039	0	48.6	46.9	69.7	142	137	0	29	28
2014	7	15	18	12	18	0.374	0.135	0.853	0.039	0.036	0	48.6	46.4	70.5	142	136	0	29	28
2014	7	15	18	22	18	0.289	0.102	0.853	0.039	0.039	0	47.7	46.9	69.7	141	137	0	30	28
2014	7	15	18	32	18	0.279	0.115	0.853	0.039	0.036	0	48.2	46	69.7	142	136	0	30	29
2014	7	15	18	42	18	0.335	0.062	0.856	0.039	0.039	0	48.2	46	70.5	142	136	0	30	29
2014	7	15	18	52	18	0.374	0.151	0.856	0.043	0.039	0	48.2	46.4	71.4	142	137	0	30	29
2014	7	15	19	2	18	0.305	0.171	0.856	0.043	0.039	0	49.5	46.9	70.5	144	138	0	29	29
2014	7	15	19	12	18	0.328	0.069	0.856	0.039	0.039	0	49.5	47.3	70.5	145	139	0	30	29
2014	7	15	19	22	18	0.335	0.059	0.856	0.043	0.039	0	49.5	47.7	71.4	145	140	0	30	29
2014	7	15	19	32	18	0.361	0.115	0.86	0.039	0.036	0	49.5	48.2	71	145	140	0	30	28
2014	7	15	19	42	18	0.236	0.052	0.86	0.039	0.039	0	50.7	48.6	71	147	142	0	29	29
2014	7	15	19	52	18	0.256	0.036	0.86	0.039	0.036	0	50.7	48.6	71	147	142	0	29	29
2014	7	15	20	2	18	0.285	0.075	0.86	0.043	0.039	0	49.5	48.2	70.1	145	141	0	30	29
2014	7	15	20	12	18	0.253	0.033	0.853	0.043	0.039	0	66.2	64.5	45.2	184	179	0	30	29
2014	7	15	20	22	18	0.292	0.148	0.86	0.036	0.033	0	61.1	58.5	54.6	171	165	0	29	29
2014	7	15	20	32	18	0.272	0.069	0.856	0.046	0.043	0	57.6	55.9	59.8	164	159	0	30	29
2014	7	15	20	42	18	0.338	0.079	0.86	0.039	0.036	0	56.8	55	61.1	162	158	0	30	30
2014	7	15	20	52	18	0.285	0.072	0.856	0.036	0.033	0	56.8	54.6	58	162	157	0	30	30
2014	7	15	21	2	18	0.282	0.102	0.856	0.039	0.036	0	57.6	55.9	60.6	164	159	0	30	29
2014	7	15	21	12	18	0.295	0.154	0.856	0.033	0.03	0	56.8	55.5	60.6	162	158	0	30	29
2014	7	15	21	22	18	0.325	0.131	0.86	0.056	0.052	0	56.3	55	62.8	161	157	0	30	29
2014	7	15	21	32	18	0.262	0.036	0.86	0.046	0.043	0	55.9	54.2	61.5	160	155	0	30	29
2014	7	15	21	42	18	0.292	0.112	0.86	0.039	0.036	0	55	53.8	62.8	158	154	0	30	29
2014	7	15	21	52	18	0.328	0.098	0.856	0.039	0.036	0	55	53.3	64.5	158	153	0	30	29
2014	7	15	22	2	18	0.328	0.115	0.856	0.039	0.036	0	54.6	52.9	62.8	157	152	0	30	29
2014	7	15	22	12	18	0.364	0.131	0.856	0.039	0.036	0	54.2	52.9	64.5	156	152	0	30	29
2014	7	15	22	22	18	0.338	0.187	0.856	0.033	0.03	0	54.2	52	63.2	156	151	0	30	30
2014	7	15	22	32	18	0.305	0.095	0.856	0.039	0.039	0	54.2	52.5	63.6	156	151	0	30	29
2014	7	15	22	42	18	0.367	0.167	0.856	0.039	0.039	0	54.2	52.5	64.1	156	151	0	30	29
2014	7	15	22	52	18	0.344	0.161	0.856	0.039	0.036	0	53.8	52	63.2	155	151	0	30	30
2014	7	15	23	2	18	0.302	0.177	0.856	0.039	0.036	0	53.8	52	65.8	155	150	0	30	29
2014	7	15	23	12	18	0.338	0.223	0.86	0.039	0.039	0	53.8	52.5	66.2	155	151	0	30	29
2014	7	15	23	22	18	0.328	0.154	0.86	0.039	0.036	0	53.8	52	67.1	155	150	0	30	29
2014	7	15	23	32	18	0.322	0.118	0.86	0.039	0.036	0	53.3	51.6	66.7	154	149	0	30	29
2014	7	15	23	42	18	0.282	0.18	0.86	0.036	0.033	0	52.9	50.7	67.1	153	148	0	30	30
2014	7	15	23	52	18	0.315	0.246	0.86	0.043	0.039	0	52.9	51.2	67.9	153	148	0	30	29
2014	7	16	0	2	18	0.358	0.131	0.86	0.039	0.036	0	52.9	51.2	67.5	153	148	0	30	29
2014	7	16	0	12	18	0.285	0.059	0.86	0.039	0.039	0	52	50.7	68.4	151	147	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	0	22	18	0.335	0.066	0.86	0.036	0.033	0	53.3	51.6	67.5	154	150	0	30	30
2014	7	16	0	32	18	0.295	0.098	0.86	0.039	0.036	0	52.9	51.6	67.5	153	149	0	30	29
2014	7	16	0	42	18	0.302	0.056	0.86	0.039	0.039	0	52.5	51.2	68.8	152	148	0	30	29
2014	7	16	0	52	18	0.331	0.023	0.86	0.039	0.039	0	52.5	51.2	68.4	152	148	0	30	29
2014	7	16	1	2	18	0.318	0.072	0.86	0.049	0.046	0	52	50.3	68.4	151	146	0	30	29
2014	7	16	1	12	18	0.308	0	0.86	0.036	0.033	0	51.6	49.5	68.8	150	145	0	30	30
2014	7	16	1	22	18	0.354	0.003	0.86	0.039	0.036	0	51.2	49.5	69.2	149	144	0	30	29
2014	7	16	1	32	18	0.344	0.036	0.86	0.039	0.036	0	51.2	49.5	69.2	149	145	0	30	30
2014	7	16	1	42	18	0.262	-0.01	0.86	0.039	0.039	0	49.9	49.5	69.2	146	144	0	30	29
2014	7	16	1	52	18	0.243	0.003	0.863	0.039	0.039	0	50.3	49.5	69.2	147	144	0	30	29
2014	7	16	2	2	18	0.312	0.02	0.863	0.043	0.039	0	51.6	49	69.2	149	144	0	29	30
2014	7	16	2	12	18	0.292	-0.036	0.863	0.036	0.033	0	51.6	49.5	68.8	150	145	0	30	30
2014	7	16	2	22	18	0.315	0	0.863	0.036	0.033	0	50.7	49.5	69.2	149	144	0	31	29
2014	7	16	2	32	18	0.305	0.01	0.863	0.039	0.039	0	51.2	49.5	69.2	149	145	0	30	30
2014	7	16	2	42	18	0.312	0.026	0.863	0.039	0.036	0	50.7	49.5	68.4	148	145	0	30	30
2014	7	16	2	52	18	0.305	0.003	0.863	0.046	0.043	0	50.7	50.3	67.9	149	146	0	31	29
2014	7	16	3	2	18	0.348	0.023	0.863	0.039	0.036	0	51.6	50.3	66.7	150	146	0	30	29
2014	7	16	3	12	18	0.295	0.072	0.863	0.039	0.039	0	51.2	49.5	67.9	149	145	0	30	30
2014	7	16	3	22	18	0.295	-0.02	0.863	0.039	0.039	0	51.6	49.9	67.5	150	146	0	30	30
2014	7	16	3	32	18	0.289	-0.016	0.863	0.039	0.039	0	50.7	49.5	67.9	148	145	0	30	30
2014	7	16	3	42	18	0.335	0.036	0.863	0.039	0.036	0	51.2	49.9	67.9	149	145	0	30	29
2014	7	16	3	52	18	0.308	0.046	0.863	0.049	0.046	0	50.7	49	67.9	148	144	0	30	30
2014	7	16	4	2	18	0.351	-0.039	0.863	0.046	0.043	0	50.3	49.5	68.8	148	144	0	31	29
2014	7	16	4	12	18	0.308	-0.046	0.863	0.049	0.046	0	49.9	48.6	69.2	147	143	0	31	30
2014	7	16	4	22	18	0.312	0.043	0.863	0.039	0.036	0	50.3	49	68.4	148	144	0	31	30
2014	7	16	4	32	18	0.322	-0.066	0.863	0.039	0.039	0	50.7	49.5	68.4	149	145	0	31	30
2014	7	16	4	42	18	0.236	-0.007	0.863	0.039	0.039	0	49.9	49	68.8	147	144	0	31	30
2014	7	16	4	52	18	0.348	0.023	0.863	0.036	0.033	0	50.3	48.6	68.4	147	143	0	30	30
2014	7	16	5	2	18	0.302	0.03	0.863	0.039	0.036	0	50.7	49.5	67.9	148	145	0	30	30
2014	7	16	5	12	18	0.348	0.052	0.863	0.043	0.039	0	49.9	49.5	68.4	147	144	0	31	29
2014	7	16	5	22	18	0.315	-0.052	0.863	0.036	0.033	0	50.7	49	67.9	148	144	0	30	30
2014	7	16	5	32	18	0.335	-0.023	0.863	0.039	0.036	0	50.7	49	67.9	148	144	0	30	30
2014	7	16	5	42	18	0.344	0.036	0.863	0.039	0.036	0	50.3	48.6	67.9	147	143	0	30	30
2014	7	16	5	52	18	0.305	-0.016	0.863	0.039	0.039	0	51.2	49.5	67.1	149	145	0	30	30
2014	7	16	6	2	18	0.358	-0.013	0.863	0.039	0.036	0	51.2	50.3	66.2	150	146	0	31	29
2014	7	16	6	12	18	0.328	0.016	0.863	0.036	0.033	0	51.6	49.9	66.7	150	146	0	30	30
2014	7	16	6	22	18	0.312	-0.039	0.863	0.039	0.036	0	51.2	49.5	67.1	150	145	0	31	30
2014	7	16	6	32	18	0.272	0.033	0.863	0.043	0.039	0	50.7	49.5	67.1	148	145	0	30	30
2014	7	16	6	42	18	0.322	-0.016	0.863	0.046	0.043	0	51.2	49.5	67.5	149	145	0	30	30
2014	7	16	6	52	18	0.272	-0.03	0.863	0.039	0.039	0	50.3	49.9	66.7	148	145	0	31	29
2014	7	16	7	2	18	0.328	0.016	0.866	0.039	0.036	0	51.6	49.9	66.2	150	146	0	30	30
2014	7	16	7	12	18	0.256	-0.03	0.863	0.046	0.043	0	51.2	49.9	66.2	150	146	0	31	30
2014	7	16	7	22	18	0.358	0.007	0.866	0.039	0.039	0	50.7	49	67.1	149	144	0	31	30
2014	7	16	7	32	18	0.384	-0.089	0.866	0.039	0.036	0	49.9	48.6	67.5	147	143	0	31	30
2014	7	16	7	42	18	0.272	-0.026	0.866	0.036	0.033	0	50.3	48.6	67.5	147	143	0	30	30
2014	7	16	7	52	18	0.23	0	0.866	0.052	0.049	0	59.8	57.2	46.4	169	163	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	8	2	18	0.295	-0.007	0.873	0.043	0.039	0	50.7	49	63.6	148	144	0	30	30
2014	7	16	8	12	18	0.325	-0.052	0.876	0.043	0.039	0	51.2	49.9	65.4	150	146	0	31	30
2014	7	16	8	22	18	0.338	-0.033	0.873	0.039	0.036	0	50.7	48.6	66.2	149	143	0	31	30
2014	7	16	8	32	18	0.344	0	0.873	0.039	0.039	0	51.2	49.9	65.8	150	146	0	31	30
2014	7	16	8	42	18	0.367	-0.013	0.873	0.039	0.039	0	50.7	49	66.7	148	144	0	30	30
2014	7	16	8	52	18	0.358	-0.03	0.869	0.039	0.036	0	51.2	49.9	65.8	150	146	0	31	30
2014	7	16	9	2	18	0.338	0.003	0.869	0.043	0.039	0	51.2	49.9	66.2	149	146	0	30	30
2014	7	16	9	12	18	0.259	-0.026	0.869	0.036	0.033	0	50.7	49	66.2	149	144	0	31	30
2014	7	16	9	22	18	0.361	0.003	0.866	0.043	0.039	0	49.9	48.2	67.1	146	142	0	30	30
2014	7	16	9	32	18	0.279	-0.007	0.866	0.036	0.033	0	48.6	47.3	69.2	144	140	0	31	30
2014	7	16	9	42	18	0.335	-0.023	0.866	0.039	0.036	0	47.7	47.3	69.2	142	140	0	31	30
2014	7	16	9	52	18	0.299	-0.01	0.866	0.043	0.039	0	48.2	47.3	68.8	143	140	0	31	30
2014	7	16	10	2	18	0.272	0.043	0.866	0.039	0.036	0	48.6	46.9	69.2	143	139	0	30	30
2014	7	16	10	12	18	0.276	-0.02	0.866	0.039	0.039	0	48.2	47.3	69.7	142	139	0	30	29
2014	7	16	10	22	18	0.292	-0.056	0.866	0.039	0.036	0	47.3	46	70.5	141	137	0	31	30
2014	7	16	10	32	18	0.289	0.003	0.866	0.033	0.03	0	49	46.9	70.5	144	139	0	30	30
2014	7	16	10	42	18	0.338	-0.043	0.866	0.033	0.03	0	49	47.3	70.1	144	140	0	30	30
2014	7	16	10	52	18	0.295	0.016	0.866	0.033	0.03	0	48.6	47.3	70.1	144	140	0	31	30
2014	7	16	11	2	18	0.318	0.043	0.866	0.033	0.03	0	48.2	46.4	70.1	142	138	0	30	30
2014	7	16	11	12	18	0.272	0.043	0.866	0.036	0.033	0	48.2	46.9	71.4	142	139	0	30	30
2014	7	16	11	22	18	0.226	0.01	0.866	0.039	0.036	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	16	11	32	18	0.315	-0.046	0.866	0.043	0.039	0	48.2	46.4	71.4	143	138	0	31	30
2014	7	16	11	42	18	0.276	0.013	0.866	0.046	0.043	0	47.7	46.9	71.4	142	139	0	31	30
2014	7	16	11	52	18	0.282	0.036	0.863	0.043	0.039	0	47.7	46	72.2	142	138	0	31	31
2014	7	16	12	2	18	0.335	0.075	0.863	0.039	0.039	0	48.6	46.9	72.2	144	139	0	31	30
2014	7	16	12	12	18	0.338	0.023	0.863	0.033	0.03	0	48.6	47.7	71.8	144	140	0	31	29
2014	7	16	12	22	18	0.302	0.043	0.863	0.039	0.039	0	49	47.7	71	144	141	0	30	30
2014	7	16	12	32	18	0.361	0.036	0.863	0.043	0.039	0	48.6	48.2	71.8	144	141	0	31	29
2014	7	16	12	42	18	0.243	0.013	0.863	0.039	0.039	0	49.5	48.6	70.5	146	142	0	31	29
2014	7	16	12	52	18	0.325	0.03	0.863	0.039	0.036	0	49	48.2	72.2	144	141	0	30	29
2014	7	16	13	2	18	0.328	0	0.863	0.033	0.03	0	49.9	48.6	71.4	147	142	0	31	29
2014	7	16	13	12	18	0.341	0.171	0.863	0.036	0.033	0	49.9	48.6	71	147	143	0	31	30
2014	7	16	13	22	18	0.341	0.066	0.863	0.036	0.033	0	49.9	48.6	71.4	146	142	0	30	29
2014	7	16	13	32	18	0.292	0.013	0.863	0.039	0.039	0	50.3	49	71.8	147	143	0	30	29
2014	7	16	13	42	18	0.246	0.095	0.863	0.033	0.03	0	49.9	49	72.2	146	143	0	30	29
2014	7	16	13	52	18	0.351	0.075	0.863	0.039	0.036	0	49.9	48.2	72.2	146	141	0	30	29
2014	7	16	14	2	18	0.361	0.046	0.863	0.036	0.033	0	50.3	49	71.4	147	143	0	30	29
2014	7	16	14	12	18	0.292	0.02	0.863	0.039	0.036	0	50.7	49	71.8	148	143	0	30	29
2014	7	16	14	22	18	0.377	0	0.863	0.043	0.043	0	51.2	49	71.8	148	143	0	29	29
2014	7	16	14	32	18	0.295	0.016	0.863	0.036	0.033	0	50.3	48.6	72.7	147	143	0	30	30
2014	7	16	14	42	18	0.322	0.115	0.863	0.039	0.036	0	50.7	49	71.8	147	143	0	29	29
2014	7	16	14	52	18	0.344	0.148	0.863	0.033	0.03	0	50.3	49	71.8	147	143	0	30	29
2014	7	16	15	2	18	0.354	0.036	0.86	0.036	0.033	0	50.7	49.5	71.4	148	143	0	30	28
2014	7	16	15	12	18	0.253	0.095	0.86	0.039	0.039	0	51.2	48.6	71.8	148	142	0	29	29
2014	7	16	15	22	18	0.367	0.118	0.86	0.039	0.039	0	50.3	49	71.4	147	143	0	30	29
2014	7	16	15	32	18	0.299	0.098	0.86	0.039	0.036	0	49.9	48.6	71.4	146	142	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	15	42	18	0.23	0.082	0.86	0.039	0.039	0	50.3	48.6	71	147	142	0	30	29
2014	7	16	15	52	18	0.335	0.085	0.86	0.033	0.03	0	49.9	48.2	70.5	146	141	0	30	29
2014	7	16	16	2	18	0.276	0.082	0.856	0.039	0.036	0	50.3	47.3	70.5	147	140	0	30	30
2014	7	16	16	12	18	0.348	0.105	0.86	0.039	0.036	0	49.9	47.7	70.5	146	140	0	30	29
2014	7	16	16	22	18	0.361	0.069	0.856	0.039	0.036	0	50.7	48.2	70.1	148	141	0	30	29
2014	7	16	16	32	18	0.318	0.02	0.856	0.039	0.039	0	50.7	48.2	69.7	148	141	0	30	29
2014	7	16	16	42	18	0.348	0.036	0.856	0.039	0.036	0	51.2	48.6	69.7	148	141	0	29	28
2014	7	16	16	52	18	0.374	0.016	0.856	0.039	0.039	0	50.7	48.2	70.1	147	141	0	29	29
2014	7	16	17	2	18	0.308	0.02	0.856	0.036	0.033	0	50.3	49	69.2	147	142	0	30	28
2014	7	16	17	12	18	0.299	-0.01	0.856	0.039	0.036	0	52	49.5	67.9	151	144	0	30	29
2014	7	16	17	22	18	0.358	0.092	0.856	0.049	0.046	0	50.7	48.2	69.7	147	141	0	29	29
2014	7	16	17	32	18	0.246	0.135	0.856	0.046	0.043	0	49.5	47.3	70.5	145	139	0	30	29
2014	7	16	17	42	18	0.299	0.075	0.853	0.043	0.039	0	50.7	48.6	67.1	148	142	0	30	29
2014	7	16	17	52	18	0.295	0.007	0.856	0.033	0.03	0	51.2	48.6	67.1	149	142	0	30	29
2014	7	16	18	2	18	0.318	0.062	0.853	0.043	0.039	0	51.2	48.2	64.5	148	141	0	29	29
2014	7	16	18	12	18	0.246	0.161	0.853	0.043	0.039	0	51.2	49	64.9	148	143	0	29	29
2014	7	16	18	22	18	0.299	0.079	0.853	0.043	0.039	0	50.7	49	64.9	148	143	0	30	29
2014	7	16	18	32	18	0.348	0	0.85	0.039	0.039	0	51.2	49	63.6	148	143	0	29	29
2014	7	16	18	42	18	0.305	0.059	0.85	0.039	0.039	0	51.2	49	63.6	149	143	0	30	29
2014	7	16	18	52	18	0.223	0.049	0.85	0.039	0.036	0	51.2	49.5	64.1	149	143	0	30	28
2014	7	16	19	2	18	0.308	-0.003	0.85	0.036	0.033	0	51.6	49.9	64.9	149	144	0	29	28
2014	7	16	19	12	18	0.285	0.033	0.85	0.039	0.036	0	51.2	49.5	64.5	149	143	0	30	28
2014	7	16	19	22	18	0.299	0	0.85	0.043	0.039	0	50.7	49	64.1	148	143	0	30	29
2014	7	16	19	32	18	0.23	0.056	0.853	0.039	0.039	0	51.2	49.5	65.4	149	144	0	30	29
2014	7	16	19	42	18	0.302	0.059	0.853	0.039	0.036	0	52	49.9	65.4	151	145	0	30	29
2014	7	16	19	52	18	0.302	0.02	0.853	0.039	0.036	0	52.5	50.7	65.8	152	147	0	30	29
2014	7	16	20	2	18	0.269	0.049	0.853	0.039	0.036	0	52.9	51.2	64.1	153	148	0	30	29
2014	7	16	20	12	18	0.213	-0.013	0.853	0.036	0.033	0	53.3	51.2	64.5	154	148	0	30	29
2014	7	16	20	22	18	0.292	0.003	0.853	0.036	0.033	0	53.3	51.2	65.4	154	148	0	30	29
2014	7	16	20	32	18	0.305	0.023	0.853	0.039	0.036	0	53.8	52	66.2	155	150	0	30	29
2014	7	16	20	42	18	0.295	-0.039	0.853	0.039	0.039	0	53.3	51.6	66.7	154	149	0	30	29
2014	7	16	20	52	18	0.374	0.033	0.856	0.036	0.033	0	52.9	51.2	66.2	153	148	0	30	29
2014	7	16	21	2	18	0.335	0.043	0.856	0.039	0.036	0	52.5	50.7	67.9	152	147	0	30	29
2014	7	16	21	12	18	0.351	0.033	0.856	0.043	0.039	0	52	50.3	68.8	151	146	0	30	29
2014	7	16	21	22	18	0.335	0.036	0.856	0.043	0.039	0	52.5	50.3	68.4	152	146	0	30	29
2014	7	16	21	32	18	0.377	0	0.856	0.039	0.036	0	52.9	50.7	67.9	152	147	0	29	29
2014	7	16	21	42	18	0.308	0.033	0.856	0.039	0.039	0	52.5	49.9	67.9	151	146	0	29	30
2014	7	16	21	52	18	0.272	-0.016	0.856	0.036	0.033	0	52	50.3	67.5	151	147	0	30	30
2014	7	16	22	2	18	0.302	-0.016	0.856	0.033	0.03	0	52	50.3	69.7	151	146	0	30	29
2014	7	16	22	12	18	0.279	0.016	0.856	0.036	0.033	0	52	50.3	68.8	151	146	0	30	29
2014	7	16	22	22	18	0.292	0.095	0.856	0.036	0.033	0	52.5	51.2	68.8	152	148	0	30	29
2014	7	16	22	32	18	0.285	-0.03	0.856	0.036	0.033	0	52.9	51.2	68.4	153	148	0	30	29
2014	7	16	22	42	18	0.174	0.016	0.856	0.039	0.039	0	52.5	50.7	69.2	152	147	0	30	29
2014	7	16	22	52	18	0.315	-0.046	0.86	0.039	0.039	0	52	50.3	69.7	151	147	0	30	30
2014	7	16	23	2	18	0.305	-0.036	0.86	0.043	0.039	0	52	49.5	69.7	151	145	0	30	30
2014	7	16	23	12	18	0.279	-0.056	0.86	0.049	0.046	0	51.6	49.9	70.1	150	146	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	23	22	18	0.318	0.003	0.86	0.039	0.036	0	51.6	49.9	70.1	150	145	0	30	29
2014	7	16	23	32	18	0.344	-0.02	0.86	0.036	0.033	0	50.7	49.9	70.1	149	145	0	31	29
2014	7	16	23	42	18	0.325	0.007	0.86	0.039	0.036	0	50.3	49	70.5	148	144	0	31	30
2014	7	16	23	52	18	0.305	-0.072	0.86	0.039	0.036	0	51.2	49.9	70.5	149	145	0	30	29
2014	7	17	0	2	18	0.276	0.056	0.86	0.036	0.033	0	50.3	49.5	71	147	144	0	30	29
2014	7	17	0	12	18	0.276	-0.03	0.86	0.033	0.03	0	51.2	49.9	69.7	149	145	0	30	29
2014	7	17	0	22	18	0.299	0.036	0.86	0.043	0.039	0	52	50.3	69.7	151	146	0	30	29
2014	7	17	0	32	18	0.285	0	0.86	0.039	0.039	0	51.2	49	71	149	144	0	30	30
2014	7	17	0	42	18	0.325	0.023	0.86	0.046	0.043	0	51.2	49	71	149	144	0	30	30
2014	7	17	0	52	18	0.305	0.082	0.86	0.033	0.03	0	50.3	49.5	70.1	147	144	0	30	29
2014	7	17	1	2	18	0.292	-0.056	0.86	0.039	0.039	0	50.3	48.6	72.2	146	142	0	29	29
2014	7	17	1	12	18	0.4	-0.003	0.86	0.039	0.036	0	49	48.6	71.8	144	143	0	30	30
2014	7	17	1	22	18	0.276	-0.052	0.86	0.039	0.036	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	17	1	32	18	0.367	-0.02	0.86	0.036	0.033	0	50.7	48.6	71	148	142	0	30	29
2014	7	17	1	42	18	0.289	0.043	0.86	0.039	0.036	0	49.5	48.2	71	146	142	0	31	30
2014	7	17	1	52	18	0.318	-0.03	0.86	0.039	0.036	0	49.9	49.5	71	147	144	0	31	29
2014	7	17	2	2	18	0.318	0.056	0.86	0.036	0.033	0	49.9	48.2	71.4	146	142	0	30	30
2014	7	17	2	12	18	0.262	0.036	0.86	0.036	0.033	0	50.3	48.6	70.5	146	143	0	29	30
2014	7	17	2	22	18	0.285	-0.046	0.86	0.039	0.039	0	49.5	48.2	71.4	146	142	0	31	30
2014	7	17	2	32	18	0.289	-0.072	0.86	0.039	0.039	0	49.5	48.6	71.8	146	143	0	31	30
2014	7	17	2	42	18	0.322	-0.059	0.86	0.039	0.039	0	49	48.6	71	145	142	0	31	29
2014	7	17	2	52	18	0.351	0.036	0.86	0.043	0.039	0	49.5	48.2	71.4	145	142	0	30	30
2014	7	17	3	2	18	0.19	0	0.86	0.039	0.036	0	49.5	48.6	71	146	143	0	31	30
2014	7	17	3	12	18	0.282	-0.049	0.856	0.039	0.039	0	49.9	48.2	71.4	146	142	0	30	30
2014	7	17	3	22	18	0.299	-0.01	0.86	0.036	0.033	0	49	47.7	71.4	145	141	0	31	30
2014	7	17	3	32	18	0.312	-0.043	0.86	0.036	0.033	0	48.6	48.2	72.2	144	141	0	31	29
2014	7	17	3	42	18	0.358	-0.007	0.86	0.043	0.039	0	48.6	47.3	71.8	143	140	0	30	30
2014	7	17	3	52	18	0.348	0.016	0.856	0.039	0.036	0	51.2	49.9	70.1	149	145	0	30	29
2014	7	17	4	2	18	0.233	-0.01	0.856	0.039	0.039	0	51.2	49	70.1	149	144	0	30	30
2014	7	17	4	12	18	0.344	0.043	0.856	0.039	0.036	0	52	50.3	69.2	151	146	0	30	29
2014	7	17	4	22	18	0.24	-0.036	0.856	0.036	0.033	0	50.7	49.5	69.7	149	145	0	31	30
2014	7	17	4	32	18	0.295	-0.033	0.856	0.039	0.039	0	50.3	49	70.5	148	144	0	31	30
2014	7	17	4	42	18	0.194	-0.056	0.86	0.039	0.036	0	52	50.3	69.7	151	146	0	30	29
2014	7	17	4	52	18	0.302	-0.052	0.856	0.036	0.033	0	49.9	49	71	146	144	0	30	30
2014	7	17	5	2	18	0.285	-0.023	0.856	0.033	0.03	0	50.3	49	71	148	144	0	31	30
2014	7	17	5	12	18	0.266	-0.02	0.856	0.036	0.033	0	50.3	48.6	71	147	144	0	30	31
2014	7	17	5	22	18	0.256	0.026	0.856	0.033	0.03	0	49.9	48.6	71.4	147	143	0	31	30
2014	7	17	5	32	18	0.328	0.026	0.856	0.036	0.033	0	49.9	49.5	69.7	147	144	0	31	29
2014	7	17	5	42	18	0.315	0.082	0.856	0.036	0.033	0	49.9	48.6	70.1	146	143	0	30	30
2014	7	17	5	52	18	0.262	0.03	0.856	0.036	0.033	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	17	6	2	18	0.292	0.092	0.856	0.039	0.036	0	49	47.7	71.4	145	141	0	31	30
2014	7	17	6	12	18	0.328	-0.01	0.856	0.033	0.03	0	49	47.7	72.2	144	141	0	30	30
2014	7	17	6	22	18	0.322	-0.016	0.856	0.039	0.036	0	48.6	47.3	71.4	144	140	0	31	30
2014	7	17	6	32	18	0.292	0	0.856	0.036	0.033	0	48.6	46.4	71.8	143	138	0	30	30
2014	7	17	6	42	18	0.308	0.033	0.856	0.039	0.036	0	47.3	46.9	72.2	141	139	0	31	30
2014	7	17	6	52	18	0.354	-0.049	0.856	0.043	0.039	0	47.3	46.4	71.8	141	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2014	7	17	7	7	2	18	0.364	0	0.856	0.049	0.046	0	46.9	46	73.1	140	137	0	31	30
2014	7	17	7	12	18	0.315	-0.056	0.856	0.036	0.033	0	47.3	46.4	73.1	140	138	0	30	30	
2014	7	17	7	22	18	0.243	-0.003	0.856	0.043	0.039	0	46.9	46.4	74.4	140	137	0	31	29	
2014	7	17	7	32	18	0.358	0.007	0.856	0.033	0.03	0	46.4	45.6	73.5	139	136	0	31	30	
2014	7	17	7	42	18	0.312	0.016	0.856	0.039	0.036	0	46.9	45.6	74	140	136	0	31	30	
2014	7	17	7	52	18	0.243	0.026	0.856	0.033	0.03	0	46	45.2	74	138	135	0	31	30	
2014	7	17	8	2	18	0.384	0.01	0.856	0.039	0.036	0	45.6	45.2	73.5	137	135	0	31	30	
2014	7	17	8	12	18	0.348	-0.023	0.856	0.039	0.036	0	46	45.2	74	137	135	0	30	30	
2014	7	17	8	22	18	0.302	0.013	0.856	0.046	0.043	0	45.6	45.2	74.8	136	134	0	30	29	
2014	7	17	8	32	18	0.325	0.007	0.856	0.036	0.033	0	46	44.3	74.4	137	133	0	30	30	
2014	7	17	8	42	18	0.266	0.02	0.856	0.039	0.036	0	45.6	44.7	74.4	137	134	0	31	30	
2014	7	17	8	52	18	0.289	0.033	0.856	0.039	0.036	0	46.4	45.2	74.8	138	135	0	30	30	
2014	7	17	9	2	18	0.338	0.003	0.856	0.039	0.039	0	45.6	45.2	74.4	137	135	0	31	30	
2014	7	17	9	12	18	0.24	0.056	0.856	0.036	0.033	0	46.9	45.6	74	139	136	0	30	30	
2014	7	17	9	22	18	0.312	0	0.856	0.039	0.036	0	45.2	44.7	74	136	134	0	31	30	
2014	7	17	9	32	18	0.312	0.043	0.856	0.036	0.033	0	45.6	44.3	75.3	136	133	0	30	30	
2014	7	17	9	42	18	0.341	0.016	0.856	0.036	0.033	0	45.6	45.2	74.8	136	134	0	30	29	
2014	7	17	9	52	18	0.305	-0.026	0.856	0.036	0.033	0	45.6	45.2	74.8	137	135	0	31	30	
2014	7	17	10	2	18	0.289	-0.016	0.856	0.036	0.033	0	46	45.2	75.3	138	134	0	31	29	
2014	7	17	10	12	18	0.312	0	0.856	0.039	0.039	0	45.6	44.3	75.3	137	133	0	31	30	
2014	7	17	10	22	18	0.315	-0.043	0.856	0.036	0.033	0	45.6	45.2	75.3	137	135	0	31	30	
2014	7	17	10	32	18	0.292	-0.03	0.856	0.039	0.036	0	46	44.7	74.8	137	134	0	30	30	
2014	7	17	10	42	18	0.279	0.079	0.856	0.036	0.033	0	45.2	44.7	75.3	136	134	0	31	30	
2014	7	17	10	52	18	0.312	0.033	0.856	0.039	0.036	0	45.6	44.3	74.8	137	133	0	31	30	
2014	7	17	11	2	18	0.305	-0.016	0.856	0.039	0.036	0	46	46	76.1	137	136	0	30	29	
2014	7	17	11	12	18	0.282	0.003	0.856	0.039	0.036	0	46	45.2	75.3	137	135	0	30	30	
2014	7	17	11	22	18	0.384	0.033	0.856	0.036	0.033	0	45.6	45.2	74.4	137	135	0	31	30	
2014	7	17	11	32	18	0.269	0.039	0.856	0.039	0.036	0	46.9	45.6	74.4	139	136	0	30	30	
2014	7	17	11	42	18	0.233	-0.02	0.853	0.033	0.03	0	46.9	46	73.1	139	136	0	30	29	
2014	7	17	11	52	18	0.276	-0.039	0.853	0.033	0.03	0	47.7	46.4	72.7	141	137	0	30	29	
2014	7	17	12	2	18	0.302	0.141	0.85	0.033	0.03	0	47.3	46	73.1	141	137	0	31	30	
2014	7	17	12	12	18	0.246	0.023	0.85	0.036	0.033	0	47.7	46.9	71	141	138	0	30	29	
2014	7	17	12	22	18	0.341	-0.036	0.846	0.036	0.033	0	49	47.3	68.4	144	140	0	30	30	
2014	7	17	12	32	18	0.259	0.072	0.846	0.039	0.039	0	48.6	47.3	70.1	143	140	0	30	30	
2014	7	17	12	42	18	0.387	0.062	0.843	0.039	0.039	0	48.6	47.7	69.2	143	140	0	30	29	
2014	7	17	12	52	18	0.253	0.108	0.84	0.033	0.03	0	48.2	47.3	69.2	142	139	0	30	29	
2014	7	17	13	2	18	0.289	-0.02	0.837	0.039	0.036	0	48.2	47.3	68.8	143	139	0	31	29	
2014	7	17	13	12	18	0.289	0.069	0.833	0.036	0.033	0	48.6	47.7	69.2	143	140	0	30	29	
2014	7	17	13	22	18	0.272	0.072	0.83	0.036	0.033	0	50.3	49.9	68.4	147	145	0	30	29	
2014	7	17	13	32	18	0.302	0.036	0.83	0.033	0.03	0	48.6	48.2	71	144	141	0	31	29	
2014	7	17	13	42	18	0.292	0.128	0.83	0.033	0.03	0	49	47.7	71	144	141	0	30	30	
2014	7	17	13	52	18	0.302	0.105	0.83	0.039	0.039	0	49.5	49	71	145	143	0	30	29	
2014	7	17	14	2	18	0.331	0.082	0.827	0.036	0.033	0	49.9	49	69.7	146	144	0	30	30	
2014	7	17	14	12	18	0.351	0.043	0.827	0.039	0.036	0	49.5	49	70.5	145	143	0	30	29	
2014	7	17	14	22	18	0.243	0.079	0.827	0.046	0.043	0	50.3	49	71	147	143	0	30	29	
2014	7	17	14	32	18	0.308	0.089	0.827	0.039	0.036	0	49.9	48.6	72.7	146	142	0	30	29	

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	14	42	18	0.276	0.046	0.827	0.039	0.039	0	49	48.6	71.8	144	142	0	30	29
2014	7	17	14	52	18	0.318	0.082	0.823	0.039	0.039	0	49.9	48.6	71.8	146	142	0	30	29
2014	7	17	15	2	18	0.292	0.049	0.823	0.033	0.03	0	49	48.2	72.2	143	141	0	29	29
2014	7	17	15	12	18	0.315	0.059	0.823	0.033	0.03	0	50.3	48.6	72.7	146	142	0	29	29
2014	7	17	15	22	18	0.249	0.102	0.823	0.039	0.036	0	49.5	48.2	73.1	145	141	0	30	29
2014	7	17	15	32	18	0.262	0.059	0.823	0.033	0.03	0	49.9	48.6	71.8	146	142	0	30	29
2014	7	17	15	42	18	0.308	0.115	0.82	0.039	0.036	0	49.5	48.6	71.8	145	142	0	30	29
2014	7	17	15	52	18	0.308	0.082	0.82	0.033	0.03	0	49.5	48.6	71.4	145	142	0	30	29
2014	7	17	16	2	18	0.312	0.046	0.82	0.036	0.033	0	49.9	48.2	70.5	145	141	0	29	29
2014	7	17	16	12	18	0.272	0.046	0.817	0.033	0.03	0	50.3	47.7	71	146	141	0	29	30
2014	7	17	16	22	18	0.249	0.052	0.817	0.033	0.03	0	48.6	47.7	70.1	143	140	0	30	29
2014	7	17	16	32	18	0.272	0.115	0.817	0.033	0.03	0	49.9	48.2	69.7	146	141	0	30	29
2014	7	17	16	42	18	0.328	0.079	0.817	0.036	0.033	0	49.9	48.6	67.5	146	142	0	30	29
2014	7	17	16	52	18	0.292	0.135	0.817	0.033	0.03	0	50.3	48.2	69.2	147	141	0	30	29
2014	7	17	17	2	18	0.272	0.138	0.814	0.039	0.036	0	48.2	47.3	67.9	141	139	0	29	29
2014	7	17	17	12	18	0.23	0.098	0.814	0.039	0.036	0	49	47.7	67.9	143	139	0	29	28
2014	7	17	17	22	18	0.233	0.141	0.814	0.033	0.03	0	47.7	46	69.2	141	136	0	30	29
2014	7	17	17	32	18	0.187	0.039	0.814	0.039	0.036	0	48.2	46.4	68.8	141	136	0	29	28
2014	7	17	17	42	18	0.302	0.128	0.814	0.039	0.036	0	47.7	46	68.8	141	135	0	30	28
2014	7	17	17	52	18	0.302	0.049	0.814	0.039	0.036	0	48.2	46	69.2	141	136	0	29	29
2014	7	17	18	2	18	0.23	0.01	0.81	0.039	0.036	0	49	46.9	68.4	144	138	0	30	29
2014	7	17	18	12	18	0.292	0.049	0.81	0.039	0.036	0	49.9	48.2	66.2	145	140	0	29	28
2014	7	17	18	22	18	0.187	0.092	0.797	0.039	0.039	0	69.2	67.1	40.9	191	185	0	30	29
2014	7	17	18	32	18	0.121	0.167	0.801	0.043	0.039	0	63.2	61.5	46.4	177	172	0	30	29
2014	7	17	18	42	18	0.121	0.033	0.797	0.036	0.033	0	60.6	58.9	50.7	171	166	0	30	29
2014	7	17	18	52	18	0.115	0.062	0.794	0.039	0.036	0	57.2	55.9	56.3	163	158	0	30	28
2014	7	17	19	2	18	0.213	0.066	0.794	0.033	0.03	0	56.8	55.5	56.3	162	158	0	30	29
2014	7	17	19	12	18	0.213	0.102	0.794	0.039	0.039	0	56.3	55	58	161	157	0	30	29
2014	7	17	19	22	18	0.18	0.039	0.794	0.036	0.033	0	56.8	55.5	56.3	162	158	0	30	29
2014	7	17	19	32	18	0.236	0	0.791	0.033	0.03	0	55.9	54.6	57.6	160	155	0	30	28
2014	7	17	19	42	18	0.272	0.056	0.791	0.043	0.043	0	55.9	55.5	58	160	157	0	30	28
2014	7	17	19	52	18	0.262	0.095	0.791	0.039	0.039	0	56.3	54.2	58	160	155	0	29	29
2014	7	17	20	2	18	0.217	0.066	0.794	0.039	0.036	0	56.3	54.6	59.8	160	155	0	29	28
2014	7	17	20	12	18	0.2	0	0.794	0.039	0.039	0	55.5	53.8	61.1	159	154	0	30	29
2014	7	17	20	22	18	0.184	0	0.794	0.036	0.033	0	55.5	53.8	61.9	158	154	0	29	29
2014	7	17	20	32	18	0.23	0.007	0.794	0.039	0.036	0	54.2	52.9	61.9	156	152	0	30	29
2014	7	17	20	42	18	0.299	-0.036	0.797	0.046	0.043	0	53.8	52.5	61.9	155	151	0	30	29
2014	7	17	20	52	18	0.262	0.043	0.801	0.039	0.039	0	53.3	52	63.6	154	150	0	30	29
2014	7	17	21	2	18	0.197	0.023	0.804	0.036	0.033	0	52.5	51.6	63.6	152	149	0	30	29
2014	7	17	21	12	18	0.207	-0.02	0.807	0.039	0.036	0	52	51.2	65.8	151	148	0	30	29
2014	7	17	21	22	18	0.23	-0.039	0.81	0.039	0.036	0	51.6	50.7	66.7	150	147	0	30	29
2014	7	17	21	32	18	0.223	0.075	0.81	0.036	0.033	0	51.6	51.2	66.7	150	148	0	30	29
2014	7	17	21	42	18	0.246	0.03	0.81	0.036	0.033	0	50.3	50.7	67.1	148	147	0	31	29
2014	7	17	21	52	18	0.282	0.013	0.814	0.046	0.043	0	50.7	50.3	68.4	148	146	0	30	29
2014	7	17	22	2	18	0.187	0.016	0.814	0.043	0.039	0	51.6	50.3	66.7	150	146	0	30	29
2014	7	17	22	12	18	0.171	0	0.814	0.039	0.036	0	52	50.7	66.7	150	147	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	22	22	18	0.249	0.033	0.814	0.039	0.036	0	49.9	50.3	67.5	147	146	0	31	29
2014	7	17	22	32	18	0.213	-0.052	0.814	0.036	0.033	0	51.6	50.7	67.1	150	147	0	30	29
2014	7	17	22	42	18	0.207	-0.016	0.814	0.039	0.036	0	51.6	50.3	68.8	150	147	0	30	30
2014	7	17	22	52	18	0.207	0.033	0.814	0.036	0.033	0	50.7	49.9	68.4	148	146	0	30	30
2014	7	17	23	2	18	0.282	0.033	0.814	0.033	0.03	0	50.7	49.9	69.2	148	146	0	30	30
2014	7	17	23	12	18	0.226	0.059	0.817	0.039	0.039	0	50.7	49	69.7	148	144	0	30	30
2014	7	17	23	22	18	0.217	-0.02	0.817	0.039	0.039	0	50.3	49	71.4	147	143	0	30	29
2014	7	17	23	32	18	0.246	-0.02	0.817	0.049	0.046	0	50.3	49.9	71.8	147	145	0	30	29
2014	7	17	23	42	18	0.213	-0.007	0.817	0.039	0.039	0	49.5	49	71.4	145	144	0	30	30
2014	7	17	23	52	18	0.243	-0.016	0.817	0.046	0.043	0	49.5	48.6	71.8	146	143	0	31	30
2014	7	18	0	2	18	0.308	-0.069	0.817	0.036	0.033	0	50.3	49	71	148	144	0	31	30
2014	7	18	0	12	18	0.217	0.072	0.817	0.039	0.039	0	48.6	49	72.2	144	143	0	31	29
2014	7	18	0	22	18	0.249	-0.016	0.817	0.039	0.039	0	48.6	48.2	72.2	144	141	0	31	29
2014	7	18	0	32	18	0.217	-0.082	0.817	0.039	0.036	0	49	49.9	72.2	145	145	0	31	29
2014	7	18	0	42	18	0.315	-0.039	0.817	0.036	0.033	0	49.9	48.6	72.2	146	143	0	30	30
2014	7	18	0	52	18	0.243	-0.039	0.817	0.036	0.033	0	49.9	49	71.8	146	143	0	30	29
2014	7	18	1	2	18	0.262	0	0.817	0.033	0.03	0	49	48.6	72.2	145	143	0	31	30
2014	7	18	1	12	18	0.148	-0.02	0.817	0.039	0.039	0	49	48.6	71.8	145	143	0	31	30
2014	7	18	1	22	18	0.299	-0.079	0.817	0.033	0.03	0	48.6	48.6	71.8	144	142	0	31	29
2014	7	18	1	32	18	0.22	0.01	0.817	0.039	0.036	0	48.6	48.6	71.8	144	143	0	31	30
2014	7	18	1	42	18	0.233	0.036	0.817	0.039	0.036	0	49.9	48.6	71	146	143	0	30	30
2014	7	18	1	52	18	0.276	-0.072	0.82	0.039	0.039	0	49.9	48.6	70.5	146	142	0	30	29
2014	7	18	2	2	18	0.253	-0.02	0.817	0.039	0.039	0	50.3	49	70.5	148	144	0	31	30
2014	7	18	2	12	18	0.262	0.036	0.82	0.039	0.036	0	50.3	49.5	71	148	145	0	31	30
2014	7	18	2	22	18	0.262	0.016	0.82	0.039	0.036	0	49.9	49	69.7	146	143	0	30	29
2014	7	18	2	32	18	0.282	0.066	0.82	0.033	0.03	0	49.9	49	69.2	147	144	0	31	30
2014	7	18	2	42	18	0.236	0.003	0.82	0.033	0.03	0	48.6	48.6	71.4	144	143	0	31	30
2014	7	18	2	52	18	0.276	0	0.82	0.039	0.036	0	50.3	49	69.7	147	144	0	30	30
2014	7	18	3	2	18	0.276	-0.062	0.82	0.043	0.039	0	49.9	49.5	69.7	146	144	0	30	29
2014	7	18	3	12	18	0.249	0.036	0.82	0.039	0.039	0	48.6	48.2	70.5	143	142	0	30	30
2014	7	18	3	22	18	0.223	0.013	0.82	0.036	0.033	0	48.2	48.2	70.5	143	141	0	31	29
2014	7	18	3	32	18	0.299	0.033	0.82	0.033	0.03	0	47.7	46.9	71.4	142	139	0	31	30
2014	7	18	3	42	18	0.226	-0.049	0.82	0.046	0.043	0	48.6	48.6	70.5	144	142	0	31	29
2014	7	18	3	52	18	0.266	0.016	0.82	0.036	0.033	0	48.2	48.2	70.1	143	142	0	31	30
2014	7	18	4	2	18	0.315	0.036	0.82	0.039	0.036	0	49.5	47.7	70.1	145	141	0	30	30
2014	7	18	4	12	18	0.18	-0.023	0.823	0.033	0.03	0	48.2	48.2	71.4	143	141	0	31	29
2014	7	18	4	22	18	0.236	0.033	0.823	0.033	0.03	0	47.7	48.2	70.1	142	142	0	31	30
2014	7	18	4	32	18	0.299	0.01	0.82	0.039	0.036	0	48.2	47.3	71	143	140	0	31	30
2014	7	18	4	42	18	0.22	0	0.823	0.033	0.03	0	48.6	46.9	71	143	139	0	30	30
2014	7	18	4	52	18	0.18	0.056	0.823	0.039	0.036	0	47.3	46.9	71	141	140	0	31	31
2014	7	18	5	2	18	0.21	0.003	0.823	0.036	0.033	0	47.7	47.3	70.5	141	140	0	30	30
2014	7	18	5	12	18	0.246	0.046	0.823	0.036	0.033	0	47.3	47.3	70.5	141	140	0	31	30
2014	7	18	5	22	18	0.24	-0.03	0.823	0.039	0.036	0	47.7	47.3	70.5	142	140	0	31	30
2014	7	18	5	32	18	0.256	0.046	0.823	0.039	0.039	0	48.2	47.7	70.5	142	141	0	30	30
2014	7	18	5	42	18	0.154	-0.003	0.823	0.036	0.033	0	48.6	47.7	70.1	144	141	0	31	30
2014	7	18	5	52	18	0.243	-0.033	0.823	0.033	0.03	0	47.7	46.9	69.7	141	139	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	6	2	18	0.249	0.072	0.823	0.039	0.036	0	47.3	46.4	70.1	141	138	0	31	30
2014	7	18	6	12	18	0.217	-0.02	0.823	0.039	0.036	0	47.7	46.9	69.7	142	140	0	31	31
2014	7	18	6	22	18	0.236	-0.026	0.823	0.036	0.033	0	49.5	48.6	68.4	146	143	0	31	30
2014	7	18	6	32	18	0.272	-0.02	0.823	0.039	0.039	0	49	48.2	67.9	145	142	0	31	30
2014	7	18	6	42	18	0.262	-0.02	0.823	0.033	0.03	0	49	48.6	68.4	145	143	0	31	30
2014	7	18	6	52	18	0.171	-0.026	0.823	0.039	0.036	0	48.2	47.7	69.7	143	141	0	31	30
2014	7	18	7	2	18	0.262	0.023	0.823	0.039	0.036	0	49.5	48.2	67.1	145	142	0	30	30
2014	7	18	7	12	18	0.223	0.039	0.823	0.036	0.033	0	47.7	47.3	69.2	142	140	0	31	30
2014	7	18	7	22	18	0.236	-0.016	0.823	0.039	0.036	0	48.6	47.7	68.8	144	141	0	31	30
2014	7	18	7	32	18	0.308	-0.02	0.823	0.036	0.033	0	50.7	49	67.9	149	144	0	31	30
2014	7	18	7	42	18	0.249	0.036	0.823	0.039	0.036	0	49	48.6	68.4	145	143	0	31	30
2014	7	18	7	52	18	0.269	0.095	0.823	0.036	0.033	0	49	48.2	68.8	145	142	0	31	30
2014	7	18	8	2	18	0.161	0.059	0.823	0.039	0.039	0	49	48.2	67.5	145	142	0	31	30
2014	7	18	8	12	18	0.253	0.007	0.823	0.039	0.039	0	49.5	48.2	68.8	146	143	0	31	31
2014	7	18	8	22	18	0.269	-0.023	0.823	0.039	0.036	0	49.5	48.6	68.4	145	143	0	30	30
2014	7	18	8	32	18	0.269	0.03	0.823	0.043	0.039	0	51.2	49.5	68.4	149	145	0	30	30
2014	7	18	8	42	18	0.262	0.033	0.823	0.036	0.033	0	49.9	49.5	67.1	147	145	0	31	30
2014	7	18	8	52	18	0.305	-0.052	0.823	0.039	0.036	0	49.9	48.6	67.9	147	144	0	31	31
2014	7	18	9	2	18	0.272	-0.056	0.823	0.043	0.039	0	51.2	50.3	67.5	150	147	0	31	30
2014	7	18	9	12	18	0.246	0.046	0.823	0.039	0.036	0	50.7	49	68.8	148	144	0	30	30
2014	7	18	9	22	18	0.223	0.023	0.823	0.036	0.033	0	50.7	49	67.5	149	145	0	31	31
2014	7	18	9	32	18	0.184	-0.02	0.823	0.033	0.03	0	51.2	49.9	67.1	149	147	0	30	31
2014	7	18	9	42	18	0.2	0.026	0.823	0.043	0.039	0	50.3	49.5	68.8	148	145	0	31	30
2014	7	18	9	52	18	0.272	0.033	0.823	0.036	0.033	0	49.5	49	70.5	146	144	0	31	30
2014	7	18	10	2	18	0.19	0.095	0.823	0.036	0.033	0	48.6	48.6	69.7	144	143	0	31	30
2014	7	18	10	12	18	0.23	0.056	0.823	0.036	0.033	0	49.9	49	70.1	146	144	0	30	30
2014	7	18	10	22	18	0.167	-0.007	0.823	0.043	0.039	0	50.7	49.5	68.8	148	145	0	30	30
2014	7	18	10	32	18	0.272	-0.043	0.823	0.039	0.036	0	50.3	49.9	69.7	148	145	0	31	29
2014	7	18	10	42	18	0.233	0	0.823	0.036	0.033	0	49.5	49.9	70.1	146	145	0	31	29
2014	7	18	10	52	18	0.217	0.052	0.82	0.046	0.043	0	52.5	51.6	67.9	153	150	0	31	30
2014	7	18	11	2	18	0.285	-0.023	0.82	0.049	0.046	0	52	52	67.1	152	150	0	31	29
2014	7	18	11	12	18	0.249	0.052	0.823	0.043	0.039	0	50.7	50.3	68.8	149	147	0	31	30
2014	7	18	11	22	18	0.279	0.003	0.823	0.043	0.039	0	52	51.6	68.8	151	150	0	30	30
2014	7	18	11	32	18	0.23	0.039	0.82	0.039	0.039	0	51.2	50.3	70.1	150	147	0	31	30
2014	7	18	11	42	18	0.21	0.072	0.823	0.036	0.033	0	51.6	51.6	69.2	151	150	0	31	30
2014	7	18	11	52	18	0.266	0.066	0.82	0.043	0.039	0	52.9	52	68.4	153	151	0	30	30
2014	7	18	12	2	18	0.322	0.066	0.82	0.036	0.033	0	52	51.6	69.7	151	150	0	30	30
2014	7	18	12	12	18	0.161	-0.033	0.82	0.039	0.036	0	53.3	52.9	67.9	155	153	0	31	30
2014	7	18	12	22	18	0.22	0.056	0.82	0.036	0.033	0	55	54.2	66.7	159	156	0	31	30
2014	7	18	12	32	18	0.112	0.089	0.82	0.039	0.039	0	55.5	54.6	65.8	159	157	0	30	30
2014	7	18	12	42	18	0.226	0.069	0.82	0.033	0.03	0	55.9	54.2	66.2	160	156	0	30	30
2014	7	18	12	52	18	0.249	0.003	0.82	0.036	0.033	0	55	54.6	67.9	158	157	0	30	30
2014	7	18	13	2	18	0.187	0.089	0.82	0.033	0.03	0	55	55	66.2	159	156	0	31	28
2014	7	18	13	12	18	0.226	0.112	0.82	0.039	0.039	0	55.9	55	65.4	160	157	0	30	29
2014	7	18	13	22	18	0.226	0.023	0.82	0.043	0.043	0	55.5	54.6	67.5	160	157	0	31	30
2014	7	18	13	32	18	0.246	0.115	0.82	0.033	0.03	0	55.9	55.5	67.1	160	158	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	13	42	18	0.272	0.043	0.82	0.033	0.03	0	55.5	54.6	67.1	159	157	0	30	30
2014	7	18	13	52	18	0.289	0.121	0.82	0.033	0.03	0	56.8	55.5	67.1	162	158	0	30	29
2014	7	18	14	2	18	0.285	0.105	0.82	0.036	0.033	0	56.3	55.9	66.7	161	159	0	30	29
2014	7	18	14	12	18	0.249	0.013	0.82	0.036	0.033	0	56.8	55.9	64.9	162	159	0	30	29
2014	7	18	14	22	18	0.24	0.115	0.82	0.039	0.036	0	57.6	56.3	64.1	164	160	0	30	29
2014	7	18	14	32	18	0.279	0.184	0.82	0.033	0.03	0	57.6	56.3	64.1	163	161	0	29	30
2014	7	18	14	42	18	0.223	0.072	0.817	0.036	0.033	0	57.2	56.3	65.8	163	160	0	30	29
2014	7	18	14	52	18	0.272	0.148	0.817	0.043	0.043	0	57.6	56.3	64.1	163	160	0	29	29
2014	7	18	15	2	18	0.302	0.098	0.817	0.039	0.036	0	57.2	55.9	64.9	163	159	0	30	29
2014	7	18	15	12	18	0.302	0.075	0.817	0.033	0.03	0	57.6	56.3	64.9	164	159	0	30	28
2014	7	18	15	22	18	0.256	0.023	0.817	0.046	0.043	0	56.8	55.9	64.5	162	159	0	30	29
2014	7	18	15	32	18	0.276	0.105	0.817	0.039	0.036	0	56.8	55.5	65.4	162	158	0	30	29
2014	7	18	15	42	18	0.253	0.082	0.817	0.033	0.03	0	57.6	55.5	65.4	163	158	0	29	29
2014	7	18	15	52	18	0.266	0.039	0.814	0.033	0.03	0	56.8	55	64.9	161	157	0	29	29
2014	7	18	16	2	18	0.197	0.036	0.814	0.039	0.039	0	56.3	55	64.9	161	157	0	30	29
2014	7	18	16	12	18	0.223	0.043	0.814	0.039	0.036	0	57.6	55	64.9	163	157	0	29	29
2014	7	18	16	22	18	0.292	0.049	0.814	0.033	0.03	0	55.9	54.6	65.4	160	156	0	30	29
2014	7	18	16	32	18	0.226	0.079	0.814	0.039	0.036	0	55.9	53.8	66.7	160	154	0	30	29
2014	7	18	16	42	18	0.289	0.079	0.814	0.043	0.039	0	56.3	54.6	64.1	160	156	0	29	29
2014	7	18	16	52	18	0.272	0.069	0.814	0.036	0.033	0	56.8	54.2	64.5	162	155	0	30	29
2014	7	18	17	2	18	0.256	0.056	0.81	0.033	0.03	0	55	55	64.9	158	156	0	30	28
2014	7	18	17	12	18	0.177	0.059	0.81	0.033	0.03	0	56.8	54.6	62.4	161	157	0	29	30
2014	7	18	17	22	18	0.259	0.043	0.807	0.033	0.03	0	55.5	54.6	62.8	159	155	0	30	28
2014	7	18	17	32	18	0.302	0.075	0.804	0.033	0.03	0	55	52.9	63.6	157	152	0	29	29
2014	7	18	17	42	18	0.285	0.115	0.807	0.036	0.033	0	50.7	50.7	66.7	148	147	0	30	29
2014	7	18	17	52	18	0.236	0.115	0.807	0.039	0.036	0	49.5	49.5	66.7	145	144	0	30	29
2014	7	18	18	2	18	0.262	0.144	0.804	0.033	0.03	0	49.9	48.6	67.1	145	142	0	29	29
2014	7	18	18	12	18	0.249	0.108	0.804	0.039	0.036	0	47.7	47.3	67.5	141	139	0	30	29
2014	7	18	18	22	18	0.259	0.062	0.804	0.039	0.036	0	48.2	46	67.9	141	137	0	29	30
2014	7	18	18	32	18	0.269	0.174	0.804	0.039	0.039	0	46.9	46	69.2	138	135	0	29	28
2014	7	18	18	42	18	0.292	0.105	0.804	0.036	0.033	0	47.3	46.4	68.8	140	137	0	30	29
2014	7	18	18	52	18	0.184	0.056	0.804	0.039	0.036	0	48.6	46.4	67.9	142	137	0	29	29
2014	7	18	19	2	18	0.217	0.092	0.804	0.036	0.033	0	47.7	47.3	68.8	141	139	0	30	29
2014	7	18	19	12	18	0.233	0.059	0.804	0.039	0.039	0	48.2	48.2	68.4	142	140	0	30	28
2014	7	18	19	22	18	0.21	0.013	0.804	0.039	0.036	0	49.9	48.6	66.7	146	142	0	30	29
2014	7	18	19	32	18	0.295	-0.039	0.804	0.046	0.043	0	49.9	48.2	67.5	146	141	0	30	29
2014	7	18	19	42	18	0.315	-0.02	0.804	0.039	0.039	0	49.9	48.6	66.2	146	142	0	30	29
2014	7	18	19	52	18	0.262	-0.01	0.804	0.043	0.039	0	49.9	49	66.7	146	143	0	30	29
2014	7	18	20	2	18	0.233	-0.02	0.804	0.033	0.033	0	50.7	49.5	66.2	148	144	0	30	29
2014	7	18	20	12	18	0.246	-0.043	0.804	0.039	0.039	0	51.2	49.9	65.8	149	145	0	30	29
2014	7	18	20	22	18	0.233	0	0.807	0.039	0.039	0	52.5	51.2	64.1	152	148	0	30	29
2014	7	18	20	32	18	0.282	-0.023	0.807	0.036	0.033	0	51.6	49.5	66.2	149	144	0	29	29
2014	7	18	20	42	18	0.226	-0.013	0.807	0.036	0.033	0	50.7	49.5	66.7	148	144	0	30	29
2014	7	18	20	52	18	0.272	0.043	0.807	0.039	0.036	0	52	50.3	65.4	151	147	0	30	30
2014	7	18	21	2	18	0.256	0.016	0.81	0.039	0.036	0	51.6	50.7	66.2	150	147	0	30	29
2014	7	18	21	12	18	0.253	0.007	0.81	0.039	0.039	0	51.2	49	67.9	149	144	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	21	22	18	0.299	0	0.81	0.033	0.03	0	49.9	49.5	69.2	146	144	0	30	29
2014	7	18	21	32	18	0.292	0.039	0.81	0.039	0.036	0	49.5	48.6	69.7	145	142	0	30	29
2014	7	18	21	42	18	0.259	0.016	0.81	0.036	0.033	0	49	48.6	70.5	144	142	0	30	29
2014	7	18	21	52	18	0.21	0.016	0.81	0.043	0.039	0	50.3	49.5	69.2	147	145	0	30	30
2014	7	18	22	2	18	0.19	0.03	0.81	0.039	0.036	0	50.7	49	68.4	148	144	0	30	30
2014	7	18	22	12	18	0.226	-0.052	0.81	0.036	0.033	0	50.3	49.5	69.2	147	144	0	30	29
2014	7	18	22	22	18	0.187	0.039	0.814	0.039	0.036	0	49.5	49	70.1	145	143	0	30	29
2014	7	18	22	32	18	0.318	0.003	0.814	0.036	0.033	0	49	49.5	70.1	145	144	0	31	29
2014	7	18	22	42	18	0.262	0	0.814	0.036	0.033	0	49.9	49.9	69.7	147	145	0	31	29
2014	7	18	22	52	18	0.302	0.056	0.814	0.039	0.036	0	52	50.7	67.9	151	147	0	30	29
2014	7	18	23	2	18	0.243	0.046	0.814	0.036	0.033	0	51.2	49.9	68.4	149	146	0	30	30
2014	7	18	23	12	18	0.262	0.03	0.814	0.036	0.033	0	50.7	49.9	70.5	148	146	0	30	30
2014	7	18	23	22	18	0.21	0.075	0.814	0.036	0.033	0	49.5	49.5	71.4	146	144	0	31	29
2014	7	18	23	32	18	0.243	-0.023	0.814	0.039	0.036	0	49.5	49.5	70.5	145	144	0	30	29
2014	7	18	23	42	18	0.177	0.02	0.814	0.039	0.036	0	48.6	48.2	71.4	143	141	0	30	29
2014	7	18	23	52	18	0.246	0	0.814	0.033	0.03	0	48.2	48.2	72.7	142	142	0	30	30
2014	7	19	0	2	18	0.253	0.007	0.814	0.036	0.033	0	48.6	48.6	72.2	143	142	0	30	29
2014	7	19	0	12	18	0.21	0.026	0.814	0.046	0.043	0	49.5	48.6	71.4	145	143	0	30	30
2014	7	19	0	22	18	0.24	0.072	0.814	0.033	0.03	0	47.7	47.7	73.1	142	141	0	31	30
2014	7	19	0	32	18	0.223	0.033	0.814	0.036	0.033	0	48.6	47.7	72.7	143	141	0	30	30
2014	7	19	0	42	18	0.213	0.036	0.817	0.039	0.036	0	48.2	47.7	73.5	142	141	0	30	30
2014	7	19	0	52	18	0.213	-0.03	0.817	0.036	0.033	0	47.7	47.7	73.5	141	141	0	30	30
2014	7	19	1	2	18	0.19	-0.02	0.817	0.039	0.039	0	48.2	48.2	72.7	143	142	0	31	30
2014	7	19	1	12	18	0.148	0	0.817	0.036	0.033	0	48.2	47.3	73.1	142	140	0	30	30
2014	7	19	1	22	18	0.194	0.003	0.817	0.039	0.036	0	47.7	46.9	73.1	141	139	0	30	30
2014	7	19	1	32	18	0.22	-0.049	0.817	0.033	0.03	0	47.3	47.3	74.4	140	140	0	30	30
2014	7	19	1	42	18	0.299	0.02	0.817	0.036	0.033	0	48.2	46.9	73.1	142	139	0	30	30
2014	7	19	1	52	18	0.2	0.02	0.817	0.036	0.033	0	47.7	47.7	73.5	142	140	0	31	29
2014	7	19	2	2	18	0.249	0.033	0.817	0.039	0.039	0	48.2	47.3	73.5	142	139	0	30	29
2014	7	19	2	12	18	0.213	0.03	0.817	0.039	0.036	0	47.7	48.2	74	141	141	0	30	29
2014	7	19	2	22	18	0.148	-0.007	0.817	0.039	0.039	0	47.3	46.9	74	140	139	0	30	30
2014	7	19	2	32	18	0.246	0.046	0.817	0.033	0.03	0	46.9	47.3	74.4	139	139	0	30	29
2014	7	19	2	42	18	0.194	0.016	0.82	0.036	0.033	0	46.9	46.4	74	139	138	0	30	30
2014	7	19	2	52	18	0.246	0.007	0.817	0.046	0.043	0	46.4	46	73.5	138	137	0	30	30
2014	7	19	3	2	18	0.236	0.013	0.82	0.039	0.036	0	46.9	46.4	73.1	139	138	0	30	30
2014	7	19	3	12	18	0.223	0.003	0.82	0.033	0.03	0	46.9	46.4	74	139	138	0	30	30
2014	7	19	3	22	18	0.24	-0.023	0.82	0.036	0.033	0	46.9	46.4	74	139	138	0	30	30
2014	7	19	3	32	18	0.197	-0.013	0.82	0.036	0.033	0	46.4	46	73.1	138	137	0	30	30
2014	7	19	3	42	18	0.213	-0.007	0.82	0.043	0.039	0	46	46	73.1	137	137	0	30	30
2014	7	19	3	52	18	0.2	0.007	0.82	0.036	0.033	0	46.4	46.4	73.5	139	138	0	31	30
2014	7	19	4	2	18	0.164	0.056	0.82	0.039	0.036	0	47.3	46.9	73.5	141	139	0	31	30
2014	7	19	4	12	18	0.2	0.02	0.82	0.033	0.03	0	46.4	46.4	73.1	139	138	0	31	30
2014	7	19	4	22	18	0.18	0	0.82	0.046	0.043	0	46.4	46.4	72.7	138	138	0	30	30
2014	7	19	4	32	18	0.2	0.043	0.82	0.043	0.039	0	46.4	46.4	73.1	138	138	0	30	30
2014	7	19	4	42	18	0.19	-0.056	0.82	0.039	0.039	0	46	46	72.7	138	137	0	31	30
2014	7	19	4	52	18	0.144	0.01	0.82	0.036	0.033	0	46.4	46.4	73.5	139	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	5	2	18	0.233	0.043	0.82	0.036	0.033	0	47.3	46.4	72.7	140	138	0	30	30
2014	7	19	5	12	18	0.246	0.062	0.82	0.039	0.036	0	46.9	46.4	72.2	139	138	0	30	30
2014	7	19	5	22	18	0.194	0.059	0.82	0.039	0.036	0	46	46	73.1	138	137	0	31	30
2014	7	19	5	32	18	0.207	0.072	0.82	0.036	0.033	0	46	46	73.1	138	137	0	31	30
2014	7	19	5	42	18	0.213	0.036	0.82	0.033	0.03	0	46.4	46.4	71.4	139	138	0	31	30
2014	7	19	5	52	18	0.174	0.013	0.823	0.039	0.039	0	46.4	45.6	72.2	138	136	0	30	30
2014	7	19	6	2	18	0.243	-0.016	0.823	0.039	0.036	0	45.6	46	71.8	137	136	0	31	29
2014	7	19	6	12	18	0.243	0.016	0.823	0.039	0.036	0	46.9	46.9	70.1	139	139	0	30	30
2014	7	19	6	22	18	0.272	0.023	0.823	0.039	0.036	0	47.7	47.3	71	142	140	0	31	30
2014	7	19	6	32	18	0.312	-0.016	0.823	0.043	0.039	0	49.9	48.6	68.4	147	143	0	31	30
2014	7	19	6	42	18	0.19	0.007	0.823	0.036	0.033	0	49.5	48.2	68.4	145	142	0	30	30
2014	7	19	6	52	18	0.325	0.062	0.823	0.036	0.033	0	47.7	46.9	70.5	142	139	0	31	30
2014	7	19	7	2	18	0.276	0.01	0.823	0.033	0.03	0	46.4	46.4	71	138	138	0	30	30
2014	7	19	7	12	18	0.292	0.033	0.823	0.043	0.043	0	46.4	46	71.8	139	137	0	31	30
2014	7	19	7	22	18	0.236	0	0.823	0.036	0.033	0	45.6	46	72.2	137	138	0	31	31
2014	7	19	7	32	18	0.23	0.033	0.827	0.036	0.033	0	45.6	44.7	71.8	137	134	0	31	30
2014	7	19	7	42	18	0.315	0.02	0.827	0.039	0.036	0	45.6	45.6	71.8	137	136	0	31	30
2014	7	19	7	52	18	0.197	0.062	0.827	0.039	0.039	0	45.6	45.6	72.2	137	136	0	31	30
2014	7	19	8	2	18	0.207	0.069	0.827	0.033	0.03	0	46	45.6	71.4	137	136	0	30	30
2014	7	19	8	12	18	0.217	0.026	0.827	0.036	0.033	0	46.4	46	70.1	139	137	0	31	30
2014	7	19	8	22	18	0.262	0.118	0.827	0.033	0.03	0	46	46	71.8	138	136	0	31	29
2014	7	19	8	32	18	0.2	0.072	0.823	0.036	0.033	0	46	46	71.4	138	137	0	31	30
2014	7	19	8	42	18	0.266	0.043	0.827	0.033	0.03	0	45.6	45.6	71.4	137	136	0	31	30
2014	7	19	8	52	18	0.213	0.108	0.827	0.036	0.033	0	45.6	45.2	71.8	137	135	0	31	30
2014	7	19	9	2	18	0.259	0.069	0.827	0.039	0.036	0	45.6	45.2	72.2	137	135	0	31	30
2014	7	19	9	12	18	0.269	0.046	0.827	0.033	0.03	0	46	45.2	72.2	138	135	0	31	30
2014	7	19	9	22	18	0.299	0.036	0.827	0.036	0.033	0	45.2	45.2	71.4	136	135	0	31	30
2014	7	19	9	32	18	0.187	0.02	0.827	0.036	0.033	0	45.2	45.2	71.8	136	136	0	31	31
2014	7	19	9	42	18	0.276	0.03	0.827	0.036	0.033	0	45.6	45.2	72.2	137	135	0	31	30
2014	7	19	9	52	18	0.331	0.003	0.827	0.033	0.03	0	45.2	45.2	72.2	136	135	0	31	30
2014	7	19	10	2	18	0.308	0	0.827	0.033	0.03	0	45.6	45.2	72.2	137	136	0	31	31
2014	7	19	10	12	18	0.24	0.082	0.827	0.039	0.036	0	46	45.2	72.2	138	135	0	31	30
2014	7	19	10	22	18	0.236	0.075	0.827	0.033	0.03	0	46	46	73.1	137	137	0	30	30
2014	7	19	10	32	18	0.256	0.033	0.827	0.036	0.033	0	46	46.4	72.2	138	138	0	31	30
2014	7	19	10	42	18	0.312	0.089	0.827	0.036	0.033	0	47.3	46.9	73.1	141	139	0	31	30
2014	7	19	10	52	18	0.292	0.151	0.827	0.036	0.033	0	48.2	46.4	71.8	143	138	0	31	30
2014	7	19	11	2	18	0.236	-0.013	0.823	0.036	0.033	0	48.2	46.9	73.1	142	139	0	30	30
2014	7	19	11	12	18	0.187	0	0.823	0.036	0.033	0	47.3	47.7	72.2	140	141	0	30	30
2014	7	19	11	22	18	0.184	0.059	0.827	0.039	0.036	0	48.6	48.6	72.2	143	143	0	30	30
2014	7	19	11	32	18	0.194	0.043	0.823	0.039	0.036	0	47.7	47.7	72.2	141	141	0	30	30
2014	7	19	11	42	18	0.276	-0.079	0.823	0.036	0.033	0	48.6	47.3	71.8	144	141	0	31	31
2014	7	19	11	52	18	0.207	-0.013	0.823	0.033	0.03	0	47.7	48.2	73.5	142	141	0	31	29
2014	7	19	12	2	18	0.282	-0.01	0.823	0.036	0.033	0	51.2	50.3	71.4	149	146	0	30	29
2014	7	19	12	12	18	0.19	0	0.823	0.052	0.049	0	49.9	49.9	71.4	146	146	0	30	30
2014	7	19	12	22	18	0.292	0.023	0.823	0.039	0.036	0	49.5	49	71	145	144	0	30	30
2014	7	19	12	32	18	0.312	0.052	0.823	0.039	0.039	0	50.3	50.7	70.5	147	148	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	12	42	18	0.18	0.013	0.823	0.039	0.036	0	50.7	51.2	70.5	149	149	0	31	30
2014	7	19	12	52	18	0.299	0.125	0.823	0.033	0.03	0	50.7	50.7	71	148	148	0	30	30
2014	7	19	13	2	18	0.236	0.112	0.823	0.033	0.03	0	52	51.2	70.1	151	148	0	30	29
2014	7	19	13	12	18	0.256	0.01	0.823	0.033	0.03	0	49.9	48.6	72.7	146	143	0	30	30
2014	7	19	13	22	18	0.262	-0.01	0.823	0.043	0.043	0	50.3	49	71.4	147	144	0	30	30
2014	7	19	13	32	18	0.269	0	0.823	0.036	0.033	0	51.2	49.5	73.1	149	145	0	30	30
2014	7	19	13	42	18	0.279	0	0.823	0.036	0.033	0	52	50.7	72.2	151	148	0	30	30
2014	7	19	13	52	18	0.177	0.043	0.823	0.039	0.036	0	53.8	52.5	69.2	155	151	0	30	29
2014	7	19	14	2	18	0.246	-0.036	0.82	0.033	0.03	0	52	50.7	72.2	151	147	0	30	29
2014	7	19	14	12	18	0.213	0.056	0.82	0.036	0.033	0	50.3	50.7	72.7	147	147	0	30	29
2014	7	19	14	22	18	0.272	0.036	0.82	0.033	0.03	0	52	50.7	72.2	151	148	0	30	30
2014	7	19	14	32	18	0.23	0.039	0.82	0.033	0.03	0	53.8	53.8	71.4	155	155	0	30	30
2014	7	19	14	42	18	0.318	0.01	0.82	0.036	0.033	0	53.3	53.3	71.4	154	153	0	30	29
2014	7	19	14	52	18	0.269	0.046	0.82	0.036	0.033	0	53.3	52.9	70.5	154	152	0	30	29
2014	7	19	15	2	18	0.24	0.02	0.82	0.036	0.033	0	51.2	50.7	71.4	150	147	0	31	29
2014	7	19	15	12	18	0.256	-0.016	0.82	0.039	0.036	0	52	52	70.5	151	150	0	30	29
2014	7	19	15	22	18	0.348	0	0.817	0.033	0.03	0	56.3	55.5	65.8	161	159	0	30	30
2014	7	19	15	32	18	0.302	0.095	0.82	0.036	0.033	0	53.8	52.9	67.9	155	152	0	30	29
2014	7	19	15	42	18	0.292	0.105	0.817	0.033	0.03	0	53.3	52.5	67.1	154	151	0	30	29
2014	7	19	15	52	18	0.249	0	0.817	0.033	0.03	0	52.9	53.3	67.5	153	154	0	30	30
2014	7	19	16	2	18	0.285	0.092	0.817	0.036	0.033	0	55	54.2	64.9	158	155	0	30	29
2014	7	19	16	12	18	0.312	0.112	0.817	0.033	0.03	0	50.7	51.2	68.4	148	148	0	30	29
2014	7	19	16	22	18	0.292	0.102	0.817	0.033	0.03	0	51.6	50.7	69.2	149	147	0	29	29
2014	7	19	16	32	18	0.21	0.095	0.817	0.033	0.03	0	53.3	52.5	68.8	154	151	0	30	29
2014	7	19	16	42	18	0.24	0.098	0.817	0.043	0.039	0	49.9	49.5	69.7	146	144	0	30	29
2014	7	19	16	52	18	0.272	0.062	0.817	0.039	0.036	0	49.9	48.6	70.1	146	143	0	30	30
2014	7	19	17	2	18	0.272	0.049	0.817	0.039	0.036	0	50.7	49.9	67.9	148	145	0	30	29
2014	7	19	17	12	18	0.243	0.023	0.814	0.039	0.039	0	51.6	50.3	67.1	150	146	0	30	29
2014	7	19	17	22	18	0.2	0.049	0.817	0.033	0.03	0	52.9	50.7	66.7	152	147	0	29	29
2014	7	19	17	32	18	0.262	0.036	0.817	0.033	0.033	0	51.6	49.9	68.4	149	146	0	29	30
2014	7	19	17	42	18	0.203	0	0.814	0.039	0.036	0	51.6	50.3	67.9	150	146	0	30	29
2014	7	19	17	52	18	0.174	-0.007	0.814	0.039	0.036	0	52.5	51.2	64.1	152	148	0	30	29
2014	7	19	18	2	18	0.207	0	0.814	0.039	0.039	0	52	51.2	64.1	151	148	0	30	29
2014	7	19	18	12	18	0.23	0.003	0.814	0.033	0.03	0	53.3	51.2	64.9	153	149	0	29	30
2014	7	19	18	22	18	0.24	0.043	0.814	0.039	0.039	0	51.6	49.9	66.7	149	145	0	29	29
2014	7	19	18	32	18	0.207	0.105	0.814	0.039	0.039	0	50.3	48.6	66.7	148	143	0	31	30
2014	7	19	18	42	18	0.276	0.036	0.814	0.039	0.036	0	52	49.9	65.8	150	145	0	29	29
2014	7	19	18	52	18	0.335	0.033	0.814	0.043	0.039	0	49.9	48.2	68.8	146	141	0	30	29
2014	7	19	19	2	18	0.23	0.003	0.814	0.039	0.039	0	48.6	47.3	70.5	143	139	0	30	29
2014	7	19	19	12	18	0.203	0.056	0.814	0.036	0.033	0	47.7	46.9	69.2	141	138	0	30	29
2014	7	19	19	22	18	0.305	0.039	0.814	0.043	0.039	0	47.3	46.9	71.4	140	138	0	30	29
2014	7	19	19	32	18	0.302	0.059	0.814	0.036	0.033	0	48.2	46.9	71	142	139	0	30	30
2014	7	19	19	42	18	0.262	0.049	0.814	0.043	0.039	0	49.5	47.7	69.2	145	141	0	30	30
2014	7	19	19	52	18	0.344	0.016	0.814	0.036	0.033	0	48.2	47.3	70.1	143	139	0	31	29
2014	7	19	20	2	18	0.266	-0.013	0.814	0.033	0.03	0	46.4	46	71.8	138	136	0	30	29
2014	7	19	20	12	18	0.276	0	0.814	0.036	0.033	0	45.6	45.2	73.1	136	135	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	20	22	18	0.203	0.03	0.81	0.039	0.036	0	46	45.6	72.7	138	135	0	31	29
2014	7	19	20	32	18	0.213	0.075	0.81	0.046	0.043	0	48.6	46.9	70.5	142	139	0	29	30
2014	7	19	20	42	18	0.272	0.003	0.81	0.036	0.033	0	48.2	48.2	69.7	143	141	0	31	29
2014	7	19	20	52	18	0.187	0.03	0.81	0.039	0.039	0	47.3	47.3	71.4	141	139	0	31	29
2014	7	19	21	2	18	0.171	-0.066	0.81	0.046	0.043	0	48.2	46.9	71	142	138	0	30	29
2014	7	19	21	12	18	0.259	-0.02	0.81	0.033	0.03	0	47.7	46.4	71	141	138	0	30	30
2014	7	19	21	22	18	0.262	-0.013	0.81	0.039	0.036	0	47.3	46	71	140	137	0	30	30
2014	7	19	21	32	18	0.226	0.03	0.81	0.039	0.036	0	46.9	46.9	71.4	139	139	0	30	30
2014	7	19	21	42	18	0.299	-0.02	0.81	0.036	0.033	0	47.3	46.9	71.4	140	138	0	30	29
2014	7	19	21	52	18	0.285	0	0.81	0.039	0.039	0	46.9	46.9	71.4	140	139	0	31	30
2014	7	19	22	2	18	0.207	0.007	0.81	0.033	0.03	0	49	48.2	70.5	144	142	0	30	30
2014	7	19	22	12	18	0.253	0.023	0.81	0.043	0.039	0	49	48.2	70.1	144	142	0	30	30
2014	7	19	22	22	18	0.223	-0.02	0.81	0.039	0.036	0	48.2	47.7	71	142	140	0	30	29
2014	7	19	22	32	18	0.269	0.072	0.81	0.033	0.03	0	48.6	47.7	70.5	143	141	0	30	30
2014	7	19	22	42	18	0.282	-0.075	0.81	0.036	0.033	0	47.7	47.3	71.8	141	140	0	30	30
2014	7	19	22	52	18	0.259	0.016	0.81	0.033	0.03	0	48.2	47.7	71	142	140	0	30	29
2014	7	19	23	2	18	0.18	-0.007	0.81	0.036	0.033	0	47.7	46.9	71	141	139	0	30	30
2014	7	19	23	12	18	0.259	0	0.81	0.039	0.036	0	47.3	47.3	71.4	140	140	0	30	30
2014	7	19	23	22	18	0.243	0.066	0.81	0.043	0.043	0	47.7	46.9	71.4	141	139	0	30	30
2014	7	19	23	32	18	0.2	0.016	0.81	0.039	0.036	0	47.7	47.3	71.8	141	139	0	30	29
2014	7	19	23	42	18	0.2	0.003	0.81	0.039	0.036	0	46.9	46.4	71.8	139	138	0	30	30
2014	7	19	23	52	18	0.207	-0.046	0.81	0.046	0.043	0	46.9	46.9	71.8	140	139	0	31	30
2014	7	20	0	2	18	0.259	0.01	0.81	0.033	0.03	0	47.3	47.3	72.2	140	139	0	30	29
2014	7	20	0	12	18	0.226	-0.003	0.81	0.043	0.043	0	46.4	46.4	73.1	139	138	0	31	30
2014	7	20	0	22	18	0.279	-0.023	0.81	0.039	0.036	0	46.4	46.4	72.7	138	138	0	30	30
2014	7	20	0	32	18	0.223	0.03	0.81	0.033	0.03	0	46.4	46.4	72.2	138	137	0	30	29
2014	7	20	0	42	18	0.115	-0.039	0.81	0.036	0.033	0	47.3	47.7	71.8	141	141	0	31	30
2014	7	20	0	52	18	0.226	-0.075	0.81	0.036	0.033	0	46.4	46.4	72.7	138	138	0	30	30
2014	7	20	1	2	18	0.233	-0.016	0.81	0.033	0.03	0	46.9	46	72.7	139	137	0	30	30
2014	7	20	1	12	18	0.276	0.03	0.81	0.039	0.039	0	46.4	46.4	72.7	138	138	0	30	30
2014	7	20	1	22	18	0.259	0.02	0.81	0.043	0.039	0	46.4	47.3	72.2	139	139	0	31	29
2014	7	20	1	32	18	0.154	0.02	0.81	0.033	0.03	0	46	46.9	72.7	138	138	0	31	29
2014	7	20	1	42	18	0.236	-0.02	0.81	0.039	0.039	0	46.4	46.4	72.2	138	137	0	30	29
2014	7	20	1	52	18	0.259	-0.056	0.81	0.039	0.036	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	20	2	2	18	0.22	-0.023	0.81	0.039	0.039	0	46.9	46.4	72.2	140	138	0	31	30
2014	7	20	2	12	18	0.233	0	0.81	0.046	0.043	0	46	46	73.1	137	137	0	30	30
2014	7	20	2	22	18	0.236	-0.039	0.81	0.039	0.036	0	46.4	46	73.1	139	137	0	31	30
2014	7	20	2	32	18	0.272	-0.003	0.81	0.033	0.03	0	46.4	46.4	72.7	139	138	0	31	30
2014	7	20	2	42	18	0.279	0	0.81	0.036	0.033	0	46.4	46.4	73.1	138	137	0	30	29
2014	7	20	2	52	18	0.161	0.043	0.81	0.039	0.036	0	46	46	72.7	138	137	0	31	30
2014	7	20	3	2	18	0.19	0.023	0.81	0.039	0.036	0	46	45.6	73.5	138	137	0	31	31
2014	7	20	3	12	18	0.102	0.013	0.81	0.039	0.039	0	46	46.4	72.2	138	138	0	31	30
2014	7	20	3	22	18	0.256	-0.013	0.81	0.039	0.036	0	45.6	46	73.1	137	137	0	31	30
2014	7	20	3	32	18	0.23	0.023	0.81	0.033	0.03	0	46.9	46	73.1	140	137	0	31	30
2014	7	20	3	42	18	0.187	0	0.81	0.033	0.03	0	46.9	47.3	72.7	140	140	0	31	30
2014	7	20	3	52	18	0.292	0.085	0.81	0.033	0.03	0	46.9	46.4	72.7	139	138	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	4	2	18	0.236	0.01	0.81	0.033	0.03	0	46.4	46	73.1	138	137	0	30	30
2014	7	20	4	12	18	0.21	0.01	0.81	0.036	0.033	0	46.9	46.4	73.5	139	138	0	30	30
2014	7	20	4	22	18	0.164	0.03	0.81	0.039	0.036	0	46.4	45.6	73.1	138	136	0	30	30
2014	7	20	4	32	18	0.236	-0.036	0.81	0.033	0.03	0	46.4	45.6	73.5	138	136	0	30	30
2014	7	20	4	42	18	0.253	-0.062	0.81	0.033	0.03	0	46	46	73.5	138	137	0	31	30
2014	7	20	4	52	18	0.269	-0.052	0.81	0.036	0.033	0	46.4	46	74	139	137	0	31	30
2014	7	20	5	2	18	0.2	0	0.81	0.039	0.039	0	46	46.4	72.7	138	137	0	31	29
2014	7	20	5	12	18	0.2	0.033	0.81	0.036	0.033	0	46.4	45.6	74	138	136	0	30	30
2014	7	20	5	22	18	0.21	-0.026	0.81	0.039	0.036	0	46.4	46	74	139	137	0	31	30
2014	7	20	5	32	18	0.276	0.026	0.81	0.033	0.03	0	45.2	44.7	73.1	136	135	0	31	31
2014	7	20	5	42	18	0.246	-0.007	0.81	0.033	0.03	0	46	45.2	74.4	137	135	0	30	30
2014	7	20	5	52	18	0.276	0.003	0.81	0.039	0.036	0	44.7	45.6	74	135	136	0	31	30
2014	7	20	6	2	18	0.217	0.007	0.81	0.036	0.033	0	45.6	44.7	74.4	137	135	0	31	31
2014	7	20	6	12	18	0.213	-0.013	0.81	0.033	0.03	0	45.2	44.7	74.4	135	134	0	30	30
2014	7	20	6	22	18	0.226	0.003	0.81	0.033	0.03	0	45.2	44.7	74.4	135	134	0	30	30
2014	7	20	6	32	18	0.272	0.016	0.81	0.036	0.033	0	46	45.6	73.5	137	136	0	30	30
2014	7	20	6	42	18	0.236	-0.066	0.81	0.033	0.03	0	45.6	45.2	73.1	137	135	0	31	30
2014	7	20	6	52	18	0.276	-0.01	0.81	0.039	0.036	0	46	45.6	72.7	138	136	0	31	30
2014	7	20	7	2	18	0.177	0.03	0.807	0.033	0.03	0	46.9	45.6	72.7	139	136	0	30	30
2014	7	20	7	12	18	0.236	-0.052	0.81	0.033	0.03	0	46.9	46.9	71.8	140	139	0	31	30
2014	7	20	7	22	18	0.272	-0.016	0.807	0.033	0.03	0	49.9	49.5	67.1	147	145	0	31	30
2014	7	20	7	32	18	0.233	0	0.81	0.033	0.03	0	48.2	48.2	70.5	143	142	0	31	30
2014	7	20	7	42	18	0.39	0.135	0.801	0.039	0.036	0	58.5	58.5	57.2	167	167	0	31	31
2014	7	20	7	52	18	0.253	0.046	0.81	0.039	0.039	0	56.8	56.3	62.4	163	161	0	31	30
2014	7	20	8	2	18	0.285	0.079	0.81	0.036	0.033	0	57.6	56.8	61.5	165	162	0	31	30
2014	7	20	8	12	18	0.272	0.125	0.81	0.039	0.036	0	58.5	58	57.6	167	165	0	31	30
2014	7	20	8	22	18	0.226	0.144	0.81	0.036	0.033	0	59.3	58.5	55.9	169	166	0	31	30
2014	7	20	8	32	18	0.253	0.157	0.81	0.039	0.039	0	60.6	58.9	56.3	171	167	0	30	30
2014	7	20	8	42	18	0.24	0.213	0.814	0.043	0.039	0	60.6	59.8	55	172	169	0	31	30
2014	7	20	8	52	18	0.233	0.118	0.814	0.039	0.039	0	60.6	59.3	56.8	172	168	0	31	30
2014	7	20	9	2	18	0.282	0.197	0.81	0.039	0.036	0	60.6	59.8	57.2	172	168	0	31	29
2014	7	20	9	12	18	0.285	0.305	0.814	0.039	0.036	0	60.6	59.8	57.2	172	169	0	31	30
2014	7	20	9	22	18	0.308	0.305	0.814	0.046	0.043	0	60.6	59.3	57.6	172	168	0	31	30
2014	7	20	9	32	18	0.213	0.302	0.814	0.043	0.039	0	60.2	58.5	57.2	171	167	0	31	31
2014	7	20	9	42	18	0.226	0.322	0.814	0.043	0.043	0	59.8	58.9	58	170	167	0	31	30
2014	7	20	9	52	18	0.344	0.302	0.814	0.049	0.049	0	59.8	58.9	58.5	170	167	0	31	30
2014	7	20	10	2	18	0.302	0.328	0.814	0.046	0.043	0	59.8	59.3	58	170	167	0	31	29
2014	7	20	10	12	18	0.318	0.351	0.81	0.043	0.039	0	59.8	58.9	58.5	170	167	0	31	30
2014	7	20	10	22	18	0.272	0.417	0.81	0.043	0.039	0	60.2	58.9	58.5	170	167	0	30	30
2014	7	20	10	32	18	0.308	0.305	0.81	0.039	0.036	0	59.8	58.9	58.5	170	167	0	31	30
2014	7	20	10	42	18	0.249	0.397	0.81	0.039	0.039	0	59.8	58.5	58.5	170	166	0	31	30
2014	7	20	10	52	18	0.203	0.404	0.81	0.039	0.036	0	59.8	58.5	58	169	166	0	30	30
2014	7	20	11	2	18	0.272	0.344	0.81	0.043	0.039	0	58.9	58	58.9	168	165	0	31	30
2014	7	20	11	12	18	0.354	0.413	0.81	0.039	0.039	0	58.9	58	59.3	167	165	0	30	30
2014	7	20	11	22	18	0.289	0.407	0.81	0.043	0.039	0	58.5	57.6	59.3	166	164	0	30	30
2014	7	20	11	32	18	0.272	0.384	0.81	0.039	0.036	0	57.6	58	59.8	165	164	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	11	42	18	0.305	0.41	0.81	0.039	0.036	0	58	56.8	60.2	165	162	0	30	30
2014	7	20	11	52	18	0.226	0.233	0.807	0.039	0.036	0	56.8	55.9	61.9	162	160	0	30	30
2014	7	20	12	2	18	0.272	0.292	0.807	0.036	0.033	0	55.9	55	61.9	160	158	0	30	30
2014	7	20	12	12	18	0.292	0.404	0.807	0.036	0.033	0	55.9	55	62.8	160	158	0	30	30
2014	7	20	12	22	18	0.305	0.233	0.807	0.039	0.036	0	55.5	55.5	61.9	160	159	0	31	30
2014	7	20	12	32	18	0.243	0.207	0.807	0.039	0.039	0	55.5	54.6	63.2	159	157	0	30	30
2014	7	20	12	42	18	0.148	0.144	0.807	0.036	0.033	0	55.9	54.6	63.2	160	156	0	30	29
2014	7	20	12	52	18	0.223	0.174	0.807	0.039	0.036	0	55	54.2	63.6	159	156	0	31	30
2014	7	20	13	2	18	0.23	0.197	0.804	0.039	0.036	0	54.6	54.2	64.1	157	156	0	30	30
2014	7	20	13	12	18	0.23	0.112	0.804	0.039	0.039	0	53.3	52	64.9	154	151	0	30	30
2014	7	20	13	22	18	0.197	0.128	0.801	0.039	0.036	0	52.5	52.5	62.8	153	152	0	31	30
2014	7	20	13	32	18	0.164	0.174	0.797	0.039	0.039	0	53.8	53.3	64.1	155	154	0	30	30
2014	7	20	13	42	18	0.217	0.144	0.797	0.036	0.033	0	55.5	54.6	63.2	159	157	0	30	30
2014	7	20	13	52	18	0.177	-0.01	0.794	0.036	0.033	0	52.9	52	66.2	154	150	0	31	29
2014	7	20	14	2	18	0.187	0.151	0.794	0.036	0.033	0	54.6	53.8	64.9	157	155	0	30	30
2014	7	20	14	12	18	0.207	0.131	0.791	0.033	0.03	0	55	53.3	66.2	158	153	0	30	29
2014	7	20	14	22	18	0.236	0.072	0.791	0.039	0.039	0	55.5	53.3	65.8	159	154	0	30	30
2014	7	20	14	32	18	0.226	0.108	0.791	0.033	0.03	0	54.6	54.2	65.4	157	155	0	30	29
2014	7	20	14	42	18	0.24	0.072	0.791	0.033	0.03	0	54.2	54.6	66.2	157	157	0	31	30
2014	7	20	14	52	18	0.24	0.072	0.791	0.036	0.033	0	55	54.6	65.4	158	156	0	30	29
2014	7	20	15	2	18	0.18	0.102	0.787	0.036	0.033	0	55.5	54.2	67.1	159	155	0	30	29
2014	7	20	15	12	18	0.21	0.059	0.787	0.033	0.03	0	53.3	51.6	68.8	155	150	0	31	30
2014	7	20	15	22	18	0.269	0.016	0.787	0.036	0.033	0	52.9	50.3	70.1	153	147	0	30	30
2014	7	20	15	32	18	0.171	0.02	0.787	0.036	0.033	0	55.9	53.8	67.5	160	155	0	30	30
2014	7	20	15	42	18	0.194	0.056	0.787	0.036	0.033	0	53.3	52	69.2	154	151	0	30	30
2014	7	20	15	52	18	0.24	0.01	0.787	0.039	0.036	0	52	52.5	68.8	152	152	0	31	30
2014	7	20	16	2	18	0.154	0.085	0.787	0.036	0.033	0	55	54.2	68.4	158	156	0	30	30
2014	7	20	16	12	18	0.299	0.036	0.787	0.033	0.03	0	52.9	51.2	69.2	153	148	0	30	29
2014	7	20	16	22	18	0.262	0.082	0.784	0.039	0.039	0	52	51.2	70.1	151	148	0	30	29
2014	7	20	16	32	18	0.253	0.013	0.784	0.039	0.036	0	52.9	51.2	70.1	153	148	0	30	29
2014	7	20	16	42	18	0.174	0.039	0.784	0.036	0.033	0	53.3	50.7	70.5	154	148	0	30	30
2014	7	20	16	52	18	0.282	0.118	0.784	0.033	0.03	0	51.2	49.9	72.2	149	145	0	30	29
2014	7	20	17	2	18	0.308	0.036	0.784	0.036	0.033	0	55	53.8	66.7	158	154	0	30	29
2014	7	20	17	12	18	0.128	0.049	0.787	0.039	0.036	0	55	54.2	66.7	158	155	0	30	29
2014	7	20	17	22	18	0.253	0.03	0.784	0.036	0.033	0	54.6	52.9	68.4	157	152	0	30	29
2014	7	20	17	32	18	0.249	0.013	0.784	0.03	0.03	0	53.3	52	69.2	154	150	0	30	29
2014	7	20	17	42	18	0.167	-0.026	0.784	0.039	0.036	0	51.6	49.9	71.8	150	145	0	30	29
2014	7	20	17	52	18	0.223	0.02	0.784	0.036	0.033	0	49	48.6	72.7	144	142	0	30	29
2014	7	20	18	2	18	0.217	0.043	0.784	0.039	0.036	0	47.3	46	74	140	137	0	30	30
2014	7	20	18	12	18	0.18	0.092	0.784	0.039	0.036	0	47.3	46	74	140	136	0	30	29
2014	7	20	18	22	18	0.177	0.105	0.784	0.039	0.036	0	46.4	45.6	74.8	137	135	0	29	29
2014	7	20	18	32	18	0.249	0.138	0.784	0.039	0.039	0	46.4	45.2	74.4	138	134	0	30	29
2014	7	20	18	42	18	0.197	0.023	0.784	0.039	0.036	0	48.2	45.6	74.4	142	136	0	30	30
2014	7	20	18	52	18	0.118	0.013	0.784	0.039	0.039	0	47.3	46	74	140	135	0	30	28
2014	7	20	19	2	18	0.095	0.108	0.781	0.036	0.033	0	47.3	45.2	74.4	140	134	0	30	29
2014	7	20	19	12	18	0.148	-0.023	0.784	0.036	0.033	0	46.9	45.2	74.8	139	134	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	19	22	18	0.079	0.007	0.781	0.039	0.036	0	46.9	44.7	74.8	139	133	0	30	29
2014	7	20	19	32	18	0.095	-0.046	0.781	0.033	0.03	0	47.7	45.6	74.8	141	135	0	30	29
2014	7	20	19	42	18	0.161	0.036	0.781	0.039	0.036	0	49	45.2	74	143	135	0	29	30
2014	7	20	19	52	18	0.092	-0.046	0.781	0.039	0.039	0	49.5	45.6	73.5	145	135	0	30	29
2014	7	20	20	2	18	0.131	-0.092	0.781	0.039	0.036	0	48.6	45.2	74.8	142	134	0	29	29
2014	7	20	20	12	18	0.151	-0.02	0.784	0.036	0.033	0	48.2	45.6	74.4	142	135	0	30	29
2014	7	20	20	22	18	0.112	-0.01	0.781	0.033	0.03	0	47.3	45.6	74.8	140	135	0	30	29
2014	7	20	20	32	18	0.131	0.023	0.781	0.036	0.033	0	47.3	46	74.8	140	136	0	30	29
2014	7	20	20	42	18	0.233	-0.01	0.781	0.036	0.033	0	49	46.9	72.2	144	138	0	30	29
2014	7	20	20	52	18	0.118	0.013	0.781	0.033	0.03	0	49	46.9	73.5	144	138	0	30	29
2014	7	20	21	2	18	0.18	-0.056	0.781	0.039	0.039	0	48.2	46.9	73.5	142	138	0	30	29
2014	7	20	21	12	18	0.141	-0.079	0.781	0.033	0.03	0	49	47.7	73.1	144	140	0	30	29
2014	7	20	21	22	18	0.135	-0.013	0.781	0.033	0.03	0	49	47.7	71.8	144	140	0	30	29
2014	7	20	21	32	18	0.269	-0.075	0.781	0.036	0.033	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	20	21	42	18	0.167	-0.033	0.781	0.043	0.039	0	49	47.7	71.8	145	141	0	31	30
2014	7	20	21	52	18	0.187	0.007	0.781	0.039	0.036	0	49	48.2	71.8	144	141	0	30	29
2014	7	20	22	2	18	0.171	-0.072	0.781	0.039	0.036	0	49	48.2	71.8	144	141	0	30	29
2014	7	20	22	12	18	0.285	-0.007	0.781	0.036	0.033	0	49	47.3	72.2	144	140	0	30	30
2014	7	20	22	22	18	0.171	-0.043	0.781	0.039	0.036	0	48.2	47.3	70.5	142	139	0	30	29
2014	7	20	22	32	18	0.174	0.046	0.781	0.033	0.03	0	48.6	47.3	71.8	143	139	0	30	29
2014	7	20	22	42	18	0.18	0.052	0.781	0.039	0.036	0	48.6	47.3	70.5	143	140	0	30	30
2014	7	20	22	52	18	0.223	-0.02	0.781	0.039	0.036	0	48.2	47.3	71.4	142	140	0	30	30
2014	7	20	23	2	18	0.171	0.02	0.781	0.043	0.039	0	47.7	47.7	72.7	141	140	0	30	29
2014	7	20	23	12	18	0.171	0	0.784	0.033	0.03	0	47.7	47.3	71.8	142	140	0	31	30
2014	7	20	23	22	18	0.174	0.013	0.784	0.036	0.033	0	47.3	46.9	71.8	140	139	0	30	30
2014	7	20	23	32	18	0.167	-0.036	0.781	0.039	0.036	0	47.7	48.2	71.8	142	141	0	31	29
2014	7	20	23	42	18	0.174	0.023	0.784	0.039	0.036	0	48.6	49	71.4	143	142	0	30	28
2014	7	20	23	52	18	0.197	-0.03	0.784	0.033	0.03	0	49	47.7	70.1	145	141	0	31	30
2014	7	21	0	2	18	0.223	0.056	0.784	0.049	0.046	0	48.2	48.2	71.4	143	141	0	31	29
2014	7	21	0	12	18	0.194	-0.016	0.784	0.036	0.033	0	48.2	47.7	71	143	141	0	31	30
2014	7	21	0	22	18	0.203	0.026	0.784	0.033	0.03	0	48.2	47.7	71.8	142	141	0	30	30
2014	7	21	0	32	18	0.233	0.098	0.784	0.033	0.03	0	48.2	46.9	71	142	139	0	30	30
2014	7	21	0	42	18	0.203	-0.016	0.784	0.039	0.036	0	47.3	46.9	71	141	139	0	31	30
2014	7	21	0	52	18	0.2	0.036	0.784	0.043	0.039	0	47.3	46.9	71.8	141	139	0	31	30
2014	7	21	1	2	18	0.131	-0.059	0.784	0.033	0.03	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	21	1	12	18	0.21	0.026	0.787	0.036	0.033	0	46.9	46.4	71	140	137	0	31	29
2014	7	21	1	22	18	0.177	-0.056	0.784	0.039	0.036	0	47.7	46	72.2	142	137	0	31	30
2014	7	21	1	32	18	0.174	-0.036	0.784	0.036	0.033	0	47.7	47.3	72.2	141	139	0	30	29
2014	7	21	1	42	18	0.24	0.046	0.784	0.033	0.03	0	47.3	47.3	71.4	141	139	0	31	29
2014	7	21	1	52	18	0.262	0.052	0.787	0.039	0.036	0	47.3	46.4	71.4	141	137	0	31	29
2014	7	21	2	2	18	0.243	0.016	0.787	0.039	0.039	0	47.7	46	71	141	137	0	30	30
2014	7	21	2	12	18	0.21	-0.01	0.784	0.036	0.033	0	47.7	46.9	71.4	142	138	0	31	29
2014	7	21	2	22	18	0.18	-0.013	0.787	0.036	0.033	0	48.2	46.4	71	142	138	0	30	30
2014	7	21	2	32	18	0.151	-0.056	0.784	0.033	0.03	0	47.3	46.9	71	141	139	0	31	30
2014	7	21	2	42	18	0.184	-0.033	0.787	0.033	0.03	0	47.3	46.9	71.8	141	139	0	31	30
2014	7	21	2	52	18	0.292	-0.02	0.787	0.033	0.03	0	47.3	46.4	70.5	141	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	3	2	18	0.18	0.046	0.787	0.039	0.036	0	46.9	46.4	70.5	140	138	0	31	30
2014	7	21	3	12	18	0.213	0	0.787	0.036	0.033	0	46.9	46.9	70.1	140	139	0	31	30
2014	7	21	3	22	18	0.279	-0.023	0.787	0.036	0.033	0	47.7	46.4	69.2	142	138	0	31	30
2014	7	21	3	32	18	0.148	0.016	0.787	0.039	0.036	0	46.9	46.4	70.1	140	138	0	31	30
2014	7	21	3	42	18	0.144	0.013	0.787	0.039	0.036	0	46.4	46.4	70.1	139	138	0	31	30
2014	7	21	3	52	18	0.18	-0.03	0.787	0.036	0.033	0	47.3	46.4	70.1	140	138	0	30	30
2014	7	21	4	2	18	0.236	0.059	0.787	0.036	0.033	0	47.3	46.9	69.7	141	138	0	31	29
2014	7	21	4	12	18	0.187	0.016	0.787	0.036	0.033	0	46.4	46.4	69.7	138	138	0	30	30
2014	7	21	4	22	18	0.157	0.056	0.791	0.046	0.043	0	46	46	70.1	138	137	0	31	30
2014	7	21	4	32	18	0.184	-0.052	0.791	0.033	0.03	0	46.4	46.4	69.7	139	137	0	31	29
2014	7	21	4	42	18	0.272	0.016	0.794	0.033	0.03	0	46.4	46.4	70.1	138	138	0	30	30
2014	7	21	4	52	18	0.207	0	0.794	0.036	0.033	0	46.4	46	69.2	138	137	0	30	30
2014	7	21	5	2	18	0.187	-0.052	0.797	0.036	0.033	0	46.4	46.4	70.1	139	138	0	31	30
2014	7	21	5	12	18	0.213	0.036	0.797	0.039	0.036	0	45.6	44.7	70.5	137	135	0	31	31
2014	7	21	5	22	18	0.171	-0.02	0.797	0.039	0.039	0	46	46.4	70.1	138	138	0	31	30
2014	7	21	5	32	18	0.226	-0.016	0.801	0.039	0.036	0	46.9	45.6	69.7	139	136	0	30	30
2014	7	21	5	42	18	0.22	0.049	0.801	0.033	0.03	0	46.9	45.2	70.1	139	135	0	30	30
2014	7	21	5	52	18	0.223	-0.013	0.801	0.033	0.03	0	45.6	45.2	71	137	135	0	31	30
2014	7	21	6	2	18	0.141	0.023	0.801	0.033	0.03	0	45.6	44.7	71	137	135	0	31	31
2014	7	21	6	12	18	0.164	0.02	0.801	0.033	0.03	0	45.6	44.7	71.8	137	134	0	31	30
2014	7	21	6	22	18	0.144	-0.007	0.804	0.039	0.036	0	45.2	44.3	71.8	136	133	0	31	30
2014	7	21	6	32	18	0.246	0	0.804	0.039	0.036	0	44.7	44.3	71.8	135	133	0	31	30
2014	7	21	6	42	18	0.266	0	0.804	0.043	0.043	0	44.3	44.3	71	134	134	0	31	31
2014	7	21	6	52	18	0.249	0.036	0.801	0.033	0.03	0	47.3	46.4	69.7	140	138	0	30	30
2014	7	21	7	2	18	0.223	0.085	0.801	0.039	0.036	0	48.6	48.6	68.4	144	143	0	31	30
2014	7	21	7	12	18	0.259	-0.052	0.804	0.039	0.039	0	49	49	69.2	145	144	0	31	30
2014	7	21	7	22	18	0.233	-0.092	0.804	0.033	0.03	0	48.6	47.7	69.7	144	141	0	31	30
2014	7	21	7	32	18	0.148	0.026	0.804	0.039	0.036	0	47.7	47.7	70.1	142	141	0	31	30
2014	7	21	7	42	18	0.154	-0.033	0.804	0.039	0.036	0	47.3	46.9	71.4	141	139	0	31	30
2014	7	21	7	52	18	0.236	0.043	0.804	0.039	0.039	0	47.7	47.3	71.4	142	140	0	31	30
2014	7	21	8	2	18	0.289	0.052	0.804	0.039	0.039	0	46.9	47.3	71.4	141	140	0	32	30
2014	7	21	8	12	18	0.174	0.046	0.807	0.033	0.03	0	48.2	47.3	70.5	143	139	0	31	29
2014	7	21	8	22	18	0.233	0.095	0.807	0.036	0.033	0	47.3	47.3	70.5	141	140	0	31	30
2014	7	21	8	32	18	0.289	0.016	0.807	0.039	0.036	0	47.7	47.3	71	142	140	0	31	30
2014	7	21	8	42	18	0.19	0.089	0.807	0.039	0.036	0	47.3	46.4	71.4	141	138	0	31	30
2014	7	21	8	52	18	0.161	0.007	0.807	0.036	0.033	0	48.6	47.7	70.1	144	141	0	31	30
2014	7	21	9	2	18	0.22	0.036	0.807	0.033	0.03	0	51.2	49	69.2	149	144	0	30	30
2014	7	21	9	12	18	0.213	0.062	0.807	0.039	0.036	0	50.3	49.5	69.2	148	145	0	31	30
2014	7	21	9	22	18	0.223	0.023	0.807	0.036	0.033	0	49.5	49	69.7	146	144	0	31	30
2014	7	21	9	32	18	0.157	0.033	0.807	0.039	0.039	0	49	48.2	70.1	145	142	0	31	30
2014	7	21	9	42	18	0.256	0.138	0.807	0.03	0.03	0	48.6	48.2	71	144	142	0	31	30
2014	7	21	9	52	18	0.236	-0.013	0.807	0.033	0.03	0	48.6	47.7	71.8	144	141	0	31	30
2014	7	21	10	2	18	0.2	0.033	0.807	0.033	0.03	0	47.3	48.2	72.2	141	141	0	31	29
2014	7	21	10	12	18	0.226	-0.02	0.807	0.039	0.036	0	48.6	47.3	72.2	143	140	0	30	30
2014	7	21	10	22	18	0.23	0.095	0.807	0.033	0.03	0	47.7	46.9	71.8	142	139	0	31	30
2014	7	21	10	32	18	0.282	0.052	0.807	0.036	0.033	0	48.2	47.7	71.4	143	141	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	10	42	18	0.22	0.026	0.807	0.039	0.036	0	47.7	47.7	72.2	142	141	0	31	30
2014	7	21	10	52	18	0.151	0.046	0.807	0.039	0.036	0	48.6	47.7	71.4	144	141	0	31	30
2014	7	21	11	2	18	0.2	0.039	0.807	0.036	0.033	0	49.5	48.2	71.4	145	142	0	30	30
2014	7	21	11	12	18	0.262	0.039	0.807	0.036	0.033	0	48.6	49	69.7	144	144	0	31	30
2014	7	21	11	22	18	0.207	-0.02	0.807	0.033	0.03	0	48.6	49.5	70.5	144	145	0	31	30
2014	7	21	11	32	18	0.207	0.062	0.807	0.036	0.033	0	48.6	49.9	69.2	144	145	0	31	29
2014	7	21	11	42	18	0.177	-0.01	0.804	0.033	0.033	0	50.7	50.3	70.1	149	146	0	31	29
2014	7	21	11	52	18	0.154	0.036	0.804	0.033	0.03	0	49.9	50.3	69.2	147	147	0	31	30
2014	7	21	12	2	18	0.187	0.02	0.804	0.03	0.03	0	51.2	50.3	68.8	150	147	0	31	30
2014	7	21	12	12	18	0.197	0.023	0.804	0.043	0.039	0	50.7	51.2	67.9	149	149	0	31	30
2014	7	21	12	22	18	0.292	0.052	0.804	0.039	0.039	0	50.3	51.6	67.9	148	150	0	31	30
2014	7	21	12	32	18	0.266	0.075	0.801	0.039	0.039	0	51.2	51.2	67.1	150	149	0	31	30
2014	7	21	12	42	18	0.262	0.036	0.801	0.033	0.033	0	51.6	51.6	66.7	151	151	0	31	31
2014	7	21	12	52	18	0.23	0.052	0.797	0.033	0.03	0	52	52	67.1	152	151	0	31	30
2014	7	21	13	2	18	0.253	0.039	0.797	0.033	0.03	0	52	52.9	67.1	151	153	0	30	30
2014	7	21	13	12	18	0.24	0.026	0.797	0.033	0.03	0	53.3	52.9	66.7	154	153	0	30	30
2014	7	21	13	22	18	0.259	0.023	0.797	0.039	0.036	0	54.2	53.8	66.2	156	155	0	30	30
2014	7	21	13	32	18	0.148	0.007	0.797	0.033	0.03	0	54.6	53.3	66.2	157	154	0	30	30
2014	7	21	13	42	18	0.243	0.03	0.794	0.039	0.036	0	53.3	53.3	67.1	154	153	0	30	29
2014	7	21	13	52	18	0.174	0.056	0.791	0.039	0.036	0	53.8	53.8	67.5	155	155	0	30	30
2014	7	21	14	2	18	0.194	0.036	0.791	0.033	0.03	0	54.2	53.3	67.1	156	153	0	30	29
2014	7	21	14	12	18	0.203	-0.02	0.791	0.039	0.036	0	55	54.2	67.9	159	155	0	31	29
2014	7	21	14	22	18	0.157	0.052	0.791	0.033	0.03	0	55	53.8	66.7	158	154	0	30	29
2014	7	21	14	32	18	0.233	0.02	0.791	0.039	0.036	0	52.9	52	67.9	153	151	0	30	30
2014	7	21	14	42	18	0.269	0.03	0.787	0.033	0.03	0	53.3	52.9	68.4	154	152	0	30	29
2014	7	21	14	52	18	0.197	0.069	0.787	0.033	0.03	0	51.2	51.2	68.8	149	148	0	30	29
2014	7	21	15	2	18	0.174	-0.02	0.787	0.036	0.033	0	55.9	55	67.5	160	157	0	30	29
2014	7	21	15	12	18	0.203	0.062	0.787	0.033	0.03	0	55.9	54.6	67.1	160	157	0	30	30
2014	7	21	15	22	18	0.246	0.082	0.787	0.033	0.03	0	55.9	55	67.1	160	157	0	30	29
2014	7	21	15	32	18	0.226	0.016	0.787	0.033	0.03	0	55.9	54.2	67.5	160	155	0	30	29
2014	7	21	15	42	18	0.233	0.039	0.787	0.036	0.033	0	55.5	54.2	67.9	159	154	0	30	28
2014	7	21	15	52	18	0.213	0.052	0.787	0.033	0.03	0	52.9	51.6	70.1	153	150	0	30	30
2014	7	21	16	2	18	0.217	0.056	0.787	0.033	0.03	0	55	53.3	67.9	158	154	0	30	30
2014	7	21	16	12	18	0.19	0.089	0.787	0.033	0.03	0	54.2	54.6	68.8	156	156	0	30	29
2014	7	21	16	22	18	0.24	0.072	0.787	0.033	0.03	0	54.2	54.2	67.5	156	155	0	30	29
2014	7	21	16	32	18	0.256	0.079	0.787	0.033	0.03	0	54.6	54.2	68.4	157	155	0	30	29
2014	7	21	16	42	18	0.272	0.023	0.787	0.036	0.033	0	53.3	52.9	70.5	154	152	0	30	29
2014	7	21	16	52	18	0.23	0.095	0.787	0.039	0.039	0	50.7	50.7	71	148	146	0	30	28
2014	7	21	17	2	18	0.266	0.095	0.787	0.033	0.03	0	52.9	51.6	68.8	152	149	0	29	29
2014	7	21	17	12	18	0.207	0	0.787	0.036	0.033	0	53.3	52.5	68.4	154	151	0	30	29
2014	7	21	17	22	18	0.24	0.01	0.787	0.036	0.033	0	53.3	51.6	69.2	154	149	0	30	29
2014	7	21	17	32	18	0.194	0.007	0.787	0.039	0.036	0	52.5	50.3	70.5	152	146	0	30	29
2014	7	21	17	42	18	0.171	0.075	0.784	0.039	0.036	0	47.7	46	73.1	141	136	0	30	29
2014	7	21	17	52	18	0.184	0.056	0.787	0.033	0.03	0	46.4	45.6	74	138	135	0	30	29
2014	7	21	18	2	18	0.217	0.059	0.787	0.039	0.036	0	46	45.2	72.7	137	134	0	30	29
2014	7	21	18	12	18	0.253	0.033	0.787	0.036	0.033	0	46.9	44.7	73.1	138	133	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	18	22	18	0.24	0.066	0.784	0.036	0.033	0	46.4	45.2	73.1	138	134	0	30	29
2014	7	21	18	32	18	0.167	0.075	0.784	0.039	0.036	0	46	44.7	72.7	137	133	0	30	29
2014	7	21	18	42	18	0.207	0.043	0.787	0.039	0.036	0	46.4	44.3	73.5	137	132	0	29	29
2014	7	21	18	52	18	0.223	0.01	0.784	0.039	0.036	0	47.3	45.2	73.1	140	134	0	30	29
2014	7	21	19	2	18	0.135	0.089	0.784	0.036	0.033	0	46.9	44.7	73.5	139	133	0	30	29
2014	7	21	19	12	18	0.121	-0.079	0.787	0.039	0.036	0	47.3	44.3	73.1	139	132	0	29	29
2014	7	21	19	22	18	0.207	-0.01	0.787	0.036	0.033	0	46	44.3	74.4	137	132	0	30	29
2014	7	21	19	32	18	0.177	-0.043	0.787	0.039	0.036	0	46.9	43.9	74.4	139	131	0	30	29
2014	7	21	19	42	18	0.262	0.02	0.787	0.033	0.03	0	46.9	43.9	74.8	139	132	0	30	30
2014	7	21	19	52	18	0.171	-0.052	0.784	0.036	0.033	0	47.3	45.6	72.2	140	135	0	30	29
2014	7	21	20	2	18	0.171	-0.102	0.784	0.036	0.033	0	46.4	45.2	73.5	138	134	0	30	29
2014	7	21	20	12	18	0.151	0.075	0.787	0.036	0.033	0	46.4	44.3	73.5	138	133	0	30	30
2014	7	21	20	22	18	0.24	-0.02	0.784	0.036	0.033	0	47.3	46.4	72.2	140	137	0	30	29
2014	7	21	20	32	18	0.213	-0.062	0.784	0.043	0.039	0	49	48.2	70.1	144	141	0	30	29
2014	7	21	20	42	18	0.184	-0.016	0.784	0.033	0.03	0	48.2	47.3	71.4	142	139	0	30	29
2014	7	21	20	52	18	0.233	0.026	0.784	0.039	0.039	0	48.2	47.3	70.5	142	139	0	30	29
2014	7	21	21	2	18	0.226	-0.052	0.787	0.033	0.03	0	46.9	46.9	71	139	138	0	30	29
2014	7	21	21	12	18	0.23	0.128	0.787	0.039	0.036	0	48.6	48.2	68.8	143	141	0	30	29
2014	7	21	21	22	18	0.226	0.02	0.787	0.039	0.036	0	47.7	46.9	70.1	141	138	0	30	29
2014	7	21	21	32	18	0.207	-0.03	0.787	0.033	0.03	0	46.9	46.4	71.4	139	137	0	30	29
2014	7	21	21	42	18	0.282	-0.036	0.787	0.039	0.039	0	46.4	46	71.4	138	137	0	30	30
2014	7	21	21	52	18	0.308	-0.069	0.787	0.039	0.036	0	46	46.4	71.4	137	137	0	30	29
2014	7	21	22	2	18	0.269	0	0.787	0.036	0.033	0	46.4	46.4	71	138	137	0	30	29
2014	7	21	22	12	18	0.157	0	0.787	0.039	0.036	0	46.4	45.6	71.4	138	136	0	30	30
2014	7	21	22	22	18	0.19	0	0.787	0.033	0.03	0	46.9	46.4	71	139	137	0	30	29
2014	7	21	22	32	18	0.279	0.033	0.791	0.036	0.033	0	46	46.4	71	138	137	0	31	29
2014	7	21	22	42	18	0.203	-0.013	0.791	0.036	0.033	0	46.9	46.4	70.5	139	137	0	30	29
2014	7	21	22	52	18	0.259	0	0.791	0.036	0.033	0	46	45.6	70.5	138	136	0	31	30
2014	7	21	23	2	18	0.2	-0.026	0.791	0.039	0.036	0	46	46	71	137	136	0	30	29
2014	7	21	23	12	18	0.246	-0.036	0.791	0.039	0.039	0	46.4	46	70.5	139	137	0	31	30
2014	7	21	23	22	18	0.279	-0.016	0.791	0.036	0.033	0	46.4	45.2	70.5	138	135	0	30	30
2014	7	21	23	32	18	0.187	0.02	0.791	0.036	0.033	0	47.7	46	70.1	141	137	0	30	30
2014	7	21	23	42	18	0.184	0.056	0.791	0.033	0.03	0	48.2	47.3	70.1	142	139	0	30	29
2014	7	21	23	52	18	0.24	0.003	0.794	0.033	0.03	0	46.9	46.4	70.1	139	138	0	30	30
2014	7	22	0	2	18	0.259	-0.016	0.794	0.039	0.039	0	46.9	45.2	69.2	139	135	0	30	30
2014	7	22	0	12	18	0.157	0.03	0.794	0.033	0.03	0	46	45.6	70.5	137	136	0	30	30
2014	7	22	0	22	18	0.292	-0.03	0.794	0.033	0.03	0	46	45.2	70.1	137	135	0	30	30
2014	7	22	0	32	18	0.23	0.016	0.797	0.036	0.033	0	46.4	46	71	138	136	0	30	29
2014	7	22	0	42	18	0.226	0	0.797	0.036	0.033	0	46.4	46	70.1	139	137	0	31	30
2014	7	22	0	52	18	0.226	-0.049	0.797	0.036	0.033	0	46.4	46	71	138	137	0	30	30
2014	7	22	1	2	18	0.276	0	0.797	0.033	0.03	0	46	46	70.5	137	137	0	30	30
2014	7	22	1	12	18	0.213	0.03	0.797	0.036	0.033	0	46.4	46	70.5	138	137	0	30	30
2014	7	22	1	22	18	0.243	0.01	0.801	0.039	0.036	0	45.6	44.7	70.5	137	134	0	31	30
2014	7	22	1	32	18	0.21	0.02	0.801	0.033	0.03	0	46	44.7	70.5	137	134	0	30	30
2014	7	22	1	42	18	0.154	0.003	0.801	0.039	0.039	0	46.9	45.2	71	139	135	0	30	30
2014	7	22	1	52	18	0.213	0.046	0.801	0.039	0.039	0	45.6	45.6	71	137	135	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	2	2	18	0.243	-0.043	0.801	0.039	0.039	0	46.4	46.9	70.1	138	138	0	30	29
2014	7	22	2	12	18	0.203	-0.01	0.801	0.036	0.033	0	46.4	45.6	70.5	138	136	0	30	30
2014	7	22	2	22	18	0.253	0.033	0.801	0.039	0.036	0	46	45.2	70.5	137	136	0	30	31
2014	7	22	2	32	18	0.21	-0.02	0.804	0.036	0.033	0	45.6	46	70.5	137	136	0	31	29
2014	7	22	2	42	18	0.184	0.036	0.804	0.039	0.036	0	45.2	45.2	71	136	135	0	31	30
2014	7	22	2	52	18	0.226	0.033	0.804	0.039	0.036	0	45.6	45.6	69.7	137	136	0	31	30
2014	7	22	3	2	18	0.187	-0.049	0.804	0.033	0.03	0	46	45.6	71	137	136	0	30	30
2014	7	22	3	12	18	0.187	0.043	0.804	0.036	0.033	0	46	45.6	71.4	138	136	0	31	30
2014	7	22	3	22	18	0.259	-0.026	0.804	0.039	0.039	0	45.6	44.7	71.4	136	134	0	30	30
2014	7	22	3	32	18	0.23	-0.079	0.804	0.036	0.033	0	46	45.6	71.4	137	136	0	30	30
2014	7	22	3	42	18	0.144	0.092	0.804	0.039	0.036	0	45.2	45.2	71	136	135	0	31	30
2014	7	22	3	52	18	0.18	0	0.804	0.036	0.033	0	45.6	46	71.4	137	137	0	31	30
2014	7	22	4	2	18	0.2	-0.003	0.801	0.033	0.03	0	46	45.6	71.8	137	136	0	30	30
2014	7	22	4	12	18	0.121	-0.01	0.801	0.036	0.033	0	45.6	45.2	71	137	135	0	31	30
2014	7	22	4	22	18	0.266	-0.043	0.801	0.033	0.03	0	45.6	45.6	70.1	137	136	0	31	30
2014	7	22	4	32	18	0.151	-0.03	0.801	0.039	0.036	0	45.6	45.2	70.5	137	135	0	31	30
2014	7	22	4	42	18	0.19	0.03	0.801	0.039	0.036	0	46.9	45.6	70.5	139	136	0	30	30
2014	7	22	4	52	18	0.141	0	0.797	0.036	0.033	0	46.9	46.4	70.1	139	137	0	30	29
2014	7	22	5	2	18	0.138	0.02	0.794	0.033	0.03	0	46	46.4	69.7	138	138	0	31	30
2014	7	22	5	12	18	0.21	-0.066	0.794	0.043	0.039	0	47.3	45.6	70.1	141	137	0	31	31
2014	7	22	5	22	18	0.2	-0.049	0.791	0.036	0.033	0	46	45.2	70.1	138	135	0	31	30
2014	7	22	5	32	18	0.305	0.016	0.791	0.043	0.039	0	45.2	46	70.1	136	136	0	31	29
2014	7	22	5	42	18	0.269	-0.069	0.787	0.033	0.03	0	46	45.2	70.1	137	134	0	30	29
2014	7	22	5	52	18	0.138	-0.003	0.787	0.039	0.036	0	45.2	45.2	71	136	135	0	31	30
2014	7	22	6	2	18	0.108	-0.105	0.787	0.039	0.039	0	44.7	43.4	71.4	135	132	0	31	31
2014	7	22	6	12	18	0.121	0.026	0.787	0.036	0.033	0	44.7	44.7	71.8	135	134	0	31	30
2014	7	22	6	22	18	0.19	-0.052	0.784	0.03	0.03	0	45.2	44.3	72.2	136	133	0	31	30
2014	7	22	6	32	18	0.22	-0.033	0.784	0.036	0.033	0	45.2	44.7	71.8	136	134	0	31	30
2014	7	22	6	42	18	0.213	-0.075	0.784	0.033	0.03	0	44.3	43.4	72.7	134	131	0	31	30
2014	7	22	6	52	18	0.177	-0.033	0.784	0.033	0.03	0	44.3	43.9	72.7	134	132	0	31	30
2014	7	22	7	2	18	0.164	0.069	0.784	0.033	0.03	0	43.9	44.3	73.1	133	134	0	31	31
2014	7	22	7	12	18	0.213	0.108	0.784	0.033	0.03	0	45.2	43.9	73.1	136	132	0	31	30
2014	7	22	7	22	18	0.18	-0.052	0.781	0.039	0.039	0	44.3	43.9	73.5	134	132	0	31	30
2014	7	22	7	32	18	0.21	-0.01	0.781	0.033	0.033	0	44.7	44.3	74	135	133	0	31	30
2014	7	22	7	42	18	0.253	0.043	0.781	0.039	0.036	0	44.3	44.7	74	134	134	0	31	30
2014	7	22	7	52	18	0.144	0	0.781	0.033	0.03	0	46	44.3	74.4	137	133	0	30	30
2014	7	22	8	2	18	0.177	0.105	0.781	0.033	0.03	0	43.4	44.3	74.4	133	134	0	32	31
2014	7	22	8	12	18	0.253	0.007	0.781	0.039	0.039	0	44.3	44.7	74.8	134	134	0	31	30
2014	7	22	8	22	18	0.256	-0.046	0.781	0.036	0.033	0	45.6	44.3	74.8	137	133	0	31	30
2014	7	22	8	32	18	0.203	-0.066	0.781	0.036	0.033	0	46.4	45.6	73.5	139	136	0	31	30
2014	7	22	8	42	18	0.154	0.075	0.781	0.039	0.036	0	48.6	46	73.5	144	137	0	31	30
2014	7	22	8	52	18	0.187	-0.089	0.781	0.039	0.036	0	46.9	45.6	74.4	140	135	0	31	29
2014	7	22	9	2	18	0.148	0.003	0.781	0.036	0.033	0	47.7	46	74	141	136	0	30	29
2014	7	22	9	12	18	0.167	0	0.778	0.039	0.036	0	47.7	46.4	73.5	142	138	0	31	30
2014	7	22	9	22	18	0.249	-0.033	0.778	0.036	0.033	0	47.3	47.3	71.8	141	139	0	31	29
2014	7	22	9	32	18	0.174	-0.007	0.778	0.046	0.046	0	47.3	47.7	73.5	141	141	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	9	42	18	0.151	0.007	0.778	0.036	0.033	0	48.6	48.2	72.2	143	142	0	30	30
2014	7	22	9	52	18	0.236	0.046	0.778	0.039	0.036	0	47.7	47.3	73.5	141	140	0	30	30
2014	7	22	10	2	18	0.184	-0.052	0.778	0.033	0.03	0	48.2	47.7	74.4	142	141	0	30	30
2014	7	22	10	12	18	0.256	-0.02	0.778	0.033	0.03	0	47.7	47.7	73.5	142	141	0	31	30
2014	7	22	10	22	18	0.203	0.079	0.778	0.033	0.03	0	47.7	47.3	74	141	140	0	30	30
2014	7	22	10	32	18	0.164	0.02	0.778	0.039	0.036	0	48.2	48.2	73.1	143	141	0	31	29
2014	7	22	10	42	18	0.141	-0.039	0.778	0.033	0.03	0	48.6	48.2	74	143	142	0	30	30
2014	7	22	10	52	18	0.036	-0.066	0.778	0.036	0.033	0	49.9	49	73.1	146	144	0	30	30
2014	7	22	11	2	18	0.052	-0.151	0.778	0.033	0.03	0	51.2	49.5	72.7	149	145	0	30	30
2014	7	22	11	12	18	0.131	-0.161	0.774	0.033	0.03	0	49.9	50.3	71.8	147	147	0	31	30
2014	7	22	11	22	18	0.128	-0.052	0.774	0.033	0.03	0	50.3	49.9	72.2	147	146	0	30	30
2014	7	22	11	32	18	0.167	0	0.774	0.033	0.03	0	50.3	50.7	71.8	148	148	0	31	30
2014	7	22	11	42	18	0.167	0.03	0.774	0.033	0.03	0	50.7	51.2	71	148	149	0	30	30
2014	7	22	11	52	18	0.213	0.056	0.771	0.033	0.03	0	51.2	52.5	70.1	149	152	0	30	30
2014	7	22	12	2	18	0.217	0.052	0.771	0.033	0.03	0	50.7	52.5	69.7	148	151	0	30	29
2014	7	22	12	12	18	0.21	0.026	0.771	0.036	0.033	0	52.5	52.9	68.8	152	153	0	30	30
2014	7	22	12	22	18	0.223	0.026	0.771	0.033	0.03	0	52	52.9	68.4	152	153	0	31	30
2014	7	22	12	32	18	0.279	0.052	0.771	0.033	0.03	0	52.9	53.3	67.5	153	154	0	30	30
2014	7	22	12	42	18	0.249	0.026	0.771	0.036	0.033	0	52.5	53.8	68.8	152	155	0	30	30
2014	7	22	12	52	18	0.131	0.066	0.768	0.033	0.03	0	53.8	54.2	67.1	156	156	0	31	30
2014	7	22	13	2	18	0.194	0.059	0.768	0.033	0.03	0	53.3	53.8	66.2	155	155	0	31	30
2014	7	22	13	12	18	0.253	0.075	0.768	0.043	0.043	0	54.6	54.2	65.4	157	156	0	30	30
2014	7	22	13	22	18	0.171	0.046	0.764	0.03	0.03	0	54.2	54.2	66.2	156	156	0	30	30
2014	7	22	13	32	18	0.164	0.052	0.764	0.03	0.03	0	53.3	54.6	64.9	155	156	0	31	29
2014	7	22	13	42	18	0.213	0.056	0.761	0.039	0.036	0	55	55.5	65.4	158	158	0	30	29
2014	7	22	13	52	18	0.226	0.079	0.758	0.033	0.03	0	55	54.6	64.5	158	157	0	30	30
2014	7	22	14	2	18	0.174	0	0.758	0.033	0.03	0	55.5	55.5	64.1	159	158	0	30	29
2014	7	22	14	12	18	0.167	0.043	0.755	0.036	0.033	0	55	56.3	64.9	158	159	0	30	28
2014	7	22	14	22	18	0.269	0.105	0.755	0.033	0.03	0	55	55.9	65.8	158	159	0	30	29
2014	7	22	14	32	18	0.207	0.115	0.755	0.039	0.036	0	54.6	55.9	65.4	157	159	0	30	29
2014	7	22	14	42	18	0.2	0.043	0.751	0.033	0.03	0	55.9	55.5	64.5	160	158	0	30	29
2014	7	22	14	52	18	0.24	0.098	0.751	0.039	0.039	0	55	55.9	64.5	158	159	0	30	29
2014	7	22	15	2	18	0.223	0.105	0.751	0.036	0.033	0	55.9	55.5	63.6	160	158	0	30	29
2014	7	22	15	12	18	0.22	0.085	0.748	0.033	0.03	0	55	55.9	63.6	159	159	0	31	29
2014	7	22	15	22	18	0.167	0.075	0.748	0.033	0.03	0	55.9	55	64.5	160	157	0	30	29
2014	7	22	15	32	18	0.262	0.082	0.748	0.033	0.03	0	55.5	55.5	64.5	159	159	0	30	30
2014	7	22	15	42	18	0.217	0.049	0.748	0.039	0.036	0	55.5	55	64.1	160	158	0	31	30
2014	7	22	15	52	18	0.246	0.066	0.748	0.036	0.033	0	55.9	55.5	64.9	160	158	0	30	29
2014	7	22	16	2	18	0.243	0	0.748	0.036	0.033	0	55.9	55	66.7	160	157	0	30	29
2014	7	22	16	12	18	0.177	0.01	0.748	0.033	0.03	0	56.3	55	64.1	160	157	0	29	29
2014	7	22	16	22	18	0.226	0.102	0.748	0.033	0.033	0	55	54.6	64.5	158	156	0	30	29
2014	7	22	16	32	18	0.203	0.062	0.748	0.03	0.03	0	55	54.6	64.5	158	156	0	30	29
2014	7	22	16	42	18	0.236	0.069	0.748	0.033	0.03	0	55.5	54.6	65.8	158	156	0	29	29
2014	7	22	16	52	18	0.187	0.052	0.748	0.036	0.033	0	55	54.6	66.2	158	156	0	30	29
2014	7	22	17	2	18	0.226	0.062	0.748	0.033	0.03	0	53.8	54.2	65.8	155	155	0	30	29
2014	7	22	17	12	18	0.187	0.046	0.748	0.033	0.03	0	53.8	52.9	64.9	155	153	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	17	22	18	0.217	0.115	0.748	0.036	0.033	0	52.9	52.5	67.5	154	151	0	31	29
2014	7	22	17	32	18	0.23	0.112	0.748	0.033	0.03	0	51.2	51.2	67.5	149	148	0	30	29
2014	7	22	17	42	18	0.164	0.036	0.745	0.036	0.033	0	49	49.5	70.1	143	144	0	29	29
2014	7	22	17	52	18	0.253	0.141	0.745	0.036	0.033	0	48.6	48.2	69.7	143	141	0	30	29
2014	7	22	18	2	18	0.174	0.089	0.745	0.033	0.03	0	48.2	47.7	69.7	142	141	0	30	30
2014	7	22	18	12	18	0.243	0.102	0.745	0.033	0.03	0	47.7	46.4	70.5	141	137	0	30	29
2014	7	22	18	22	18	0.167	0.112	0.745	0.039	0.036	0	46.9	46	71.4	139	136	0	30	29
2014	7	22	18	32	18	0.18	0.069	0.745	0.039	0.039	0	48.2	46.9	71.4	142	138	0	30	29
2014	7	22	18	42	18	0.249	0.131	0.745	0.036	0.033	0	47.7	47.3	69.7	141	139	0	30	29
2014	7	22	18	52	18	0.213	0.095	0.745	0.043	0.039	0	47.3	46.4	70.1	140	138	0	30	30
2014	7	22	19	2	18	0.2	0.095	0.741	0.036	0.033	0	47.7	47.3	70.1	141	139	0	30	29
2014	7	22	19	12	18	0.171	0.085	0.741	0.039	0.036	0	47.7	46.9	69.7	141	138	0	30	29
2014	7	22	19	22	18	0.2	0.016	0.741	0.039	0.036	0	47.3	46.9	71.8	139	138	0	29	29
2014	7	22	19	32	18	0.171	0.016	0.741	0.036	0.033	0	47.3	46.4	71.8	141	137	0	31	29
2014	7	22	19	42	18	0.194	0.059	0.741	0.036	0.033	0	48.2	46.9	72.2	142	138	0	30	29
2014	7	22	19	52	18	0.23	0.013	0.741	0.039	0.036	0	48.2	46.4	71	142	138	0	30	30
2014	7	22	20	2	18	0.19	-0.02	0.741	0.033	0.03	0	46.9	45.6	72.2	139	135	0	30	29
2014	7	22	20	12	18	0.217	0.016	0.741	0.033	0.03	0	48.2	46	72.7	141	137	0	29	30
2014	7	22	20	22	18	0.177	0.049	0.741	0.033	0.03	0	47.7	46.9	71.4	142	138	0	31	29
2014	7	22	20	32	18	0.19	0.056	0.741	0.046	0.043	0	48.6	47.7	72.2	143	140	0	30	29
2014	7	22	20	42	18	0.161	0.033	0.741	0.036	0.033	0	50.7	49.9	69.2	149	145	0	31	29
2014	7	22	20	52	18	0.115	0.026	0.741	0.039	0.039	0	49.5	48.6	71	145	142	0	30	29
2014	7	22	21	2	18	0.197	0	0.741	0.036	0.033	0	48.2	46.9	72.7	142	138	0	30	29
2014	7	22	21	12	18	0.194	0.01	0.741	0.043	0.039	0	46.9	46.4	73.5	139	137	0	30	29
2014	7	22	21	22	18	0.174	0.036	0.741	0.033	0.03	0	46.9	46.4	73.5	139	137	0	30	29
2014	7	22	21	32	18	0.135	-0.023	0.741	0.033	0.03	0	46.9	46.4	73.1	139	138	0	30	30
2014	7	22	21	42	18	0.112	0.02	0.741	0.039	0.036	0	47.3	46.4	73.5	140	137	0	30	29
2014	7	22	21	52	18	0.18	-0.056	0.741	0.033	0.03	0	47.7	46	73.5	141	137	0	30	30
2014	7	22	22	2	18	0.148	0	0.741	0.033	0.03	0	46.9	46.4	73.5	140	137	0	31	29
2014	7	22	22	12	18	0.197	0	0.741	0.036	0.033	0	47.3	46.4	71.8	140	137	0	30	29
2014	7	22	22	22	18	0.174	0.03	0.741	0.033	0.03	0	48.2	46.9	72.7	143	139	0	31	30
2014	7	22	22	32	18	0.092	0.03	0.741	0.033	0.03	0	47.3	46.4	74	140	137	0	30	29
2014	7	22	22	42	18	0.138	0.049	0.741	0.039	0.039	0	46.4	46.4	73.1	139	138	0	31	30
2014	7	22	22	52	18	0.177	-0.016	0.741	0.033	0.03	0	47.7	46.9	72.2	141	139	0	30	30
2014	7	22	23	2	18	0.151	0.016	0.741	0.039	0.039	0	47.7	47.3	72.2	141	139	0	30	29
2014	7	22	23	12	18	0.164	0	0.741	0.033	0.03	0	48.2	47.3	71.4	142	139	0	30	29
2014	7	22	23	22	18	0.2	0.072	0.741	0.033	0.03	0	48.2	47.3	71.8	142	140	0	30	30
2014	7	22	23	32	18	0.18	-0.052	0.745	0.039	0.036	0	48.2	47.7	71.8	142	141	0	30	30
2014	7	22	23	42	18	0.203	-0.033	0.745	0.033	0.03	0	47.7	47.3	72.2	141	139	0	30	29
2014	7	22	23	52	18	0.089	-0.02	0.745	0.036	0.033	0	46.9	46	71	139	137	0	30	30
2014	7	23	0	2	18	0.157	0.036	0.745	0.033	0.03	0	47.7	46.9	72.2	142	139	0	31	30
2014	7	23	0	12	18	0.226	0.072	0.745	0.033	0.03	0	48.2	47.3	71.8	142	139	0	30	29
2014	7	23	0	22	18	0.138	0.059	0.745	0.033	0.03	0	46.9	46.9	72.2	139	139	0	30	30
2014	7	23	0	32	18	0.184	0.026	0.745	0.033	0.03	0	46.9	46.9	71.8	139	138	0	30	29
2014	7	23	0	42	18	0.157	0.033	0.745	0.033	0.03	0	47.3	46	71.8	140	136	0	30	29
2014	7	23	0	52	18	0.112	0.069	0.745	0.033	0.03	0	46.4	45.2	71.8	138	135	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	1	2	18	0.135	0.023	0.745	0.033	0.03	0	46	46.4	72.2	137	138	0	30	30
2014	7	23	1	12	18	0.177	0.016	0.745	0.036	0.033	0	46.4	45.6	71	138	136	0	30	30
2014	7	23	1	22	18	0.128	0.007	0.745	0.036	0.033	0	46.4	46	71	138	137	0	30	30
2014	7	23	1	32	18	0.138	-0.026	0.748	0.033	0.03	0	47.3	47.3	71	141	139	0	31	29
2014	7	23	1	42	18	0.138	-0.02	0.748	0.033	0.03	0	46	45.6	70.1	137	136	0	30	30
2014	7	23	1	52	18	0.164	-0.066	0.748	0.036	0.033	0	47.3	45.6	70.1	141	136	0	31	30
2014	7	23	2	2	18	0.226	-0.036	0.748	0.033	0.03	0	45.2	45.6	71	135	136	0	30	30
2014	7	23	2	12	18	0.157	-0.069	0.748	0.033	0.03	0	46	45.6	70.5	138	136	0	31	30
2014	7	23	2	22	18	0.115	-0.01	0.751	0.033	0.03	0	46	46	69.7	137	137	0	30	30
2014	7	23	2	32	18	0.121	-0.01	0.751	0.033	0.03	0	45.6	45.6	70.1	137	136	0	31	30
2014	7	23	2	42	18	0.21	-0.016	0.755	0.039	0.036	0	46	45.2	70.5	138	136	0	31	31
2014	7	23	2	52	18	0.112	-0.046	0.758	0.036	0.033	0	46	45.6	70.1	138	136	0	31	30
2014	7	23	3	2	18	0.161	-0.036	0.758	0.033	0.03	0	45.6	46	69.7	137	137	0	31	30
2014	7	23	3	12	18	0.125	-0.056	0.761	0.03	0.03	0	45.2	45.6	70.5	136	136	0	31	30
2014	7	23	3	22	18	0.161	0.036	0.761	0.036	0.033	0	45.6	45.2	71	137	135	0	31	30
2014	7	23	3	32	18	0.19	0.016	0.761	0.039	0.039	0	45.6	45.2	70.5	137	136	0	31	31
2014	7	23	3	42	18	0.144	-0.049	0.764	0.043	0.039	0	46.4	45.6	70.5	139	136	0	31	30
2014	7	23	3	52	18	0.141	-0.007	0.764	0.036	0.033	0	45.6	45.6	72.2	136	136	0	30	30
2014	7	23	4	2	18	0.161	-0.085	0.764	0.039	0.036	0	45.6	46	71	137	136	0	31	29
2014	7	23	4	12	18	0.18	-0.023	0.764	0.033	0.03	0	44.7	45.2	71.4	135	135	0	31	30
2014	7	23	4	22	18	0.141	0	0.764	0.033	0.03	0	46	45.2	71.8	137	135	0	30	30
2014	7	23	4	32	18	0.141	-0.033	0.764	0.046	0.043	0	44.7	44.3	71.4	135	134	0	31	31
2014	7	23	4	42	18	0.141	-0.079	0.764	0.039	0.036	0	45.2	45.6	72.2	137	136	0	32	30
2014	7	23	4	52	18	0.207	-0.007	0.764	0.036	0.033	0	47.3	46.9	70.5	141	139	0	31	30
2014	7	23	5	2	18	0.223	0.03	0.764	0.036	0.033	0	49.5	48.2	69.7	145	142	0	30	30
2014	7	23	5	12	18	0.2	0.023	0.764	0.036	0.033	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	23	5	22	18	0.285	0.013	0.768	0.036	0.033	0	46.9	46	71	140	138	0	31	31
2014	7	23	5	32	18	0.161	0.026	0.768	0.036	0.033	0	46.4	46	71.4	139	137	0	31	30
2014	7	23	5	42	18	0.089	0.013	0.768	0.033	0.033	0	46	45.2	71.8	138	135	0	31	30
2014	7	23	5	52	18	0.187	-0.092	0.768	0.043	0.039	0	45.6	45.2	71.8	137	135	0	31	30
2014	7	23	6	2	18	0.19	0.016	0.768	0.033	0.03	0	45.2	43.9	72.7	136	133	0	31	31
2014	7	23	6	12	18	0.203	0.02	0.768	0.033	0.03	0	45.6	44.7	72.7	137	134	0	31	30
2014	7	23	6	22	18	0.148	0	0.768	0.036	0.033	0	44.7	45.2	72.2	135	135	0	31	30
2014	7	23	6	32	18	0.151	0	0.768	0.033	0.03	0	44.7	43.9	73.1	135	133	0	31	31
2014	7	23	6	42	18	0.154	0.036	0.768	0.036	0.033	0	44.7	43.9	73.5	135	132	0	31	30
2014	7	23	6	52	18	0.157	0.03	0.768	0.039	0.036	0	43.9	43.9	73.1	133	133	0	31	31
2014	7	23	7	2	18	0.138	0.003	0.768	0.036	0.033	0	44.7	44.3	73.5	135	134	0	31	31
2014	7	23	7	12	18	0.072	0.046	0.768	0.036	0.033	0	45.2	44.7	73.5	137	134	0	32	30
2014	7	23	7	22	18	0.194	-0.026	0.768	0.036	0.033	0	44.7	44.3	73.5	134	133	0	30	30
2014	7	23	7	32	18	0.157	0.049	0.768	0.033	0.03	0	45.6	44.3	74	136	133	0	30	30
2014	7	23	7	42	18	0.121	-0.043	0.768	0.039	0.036	0	44.7	44.3	74	135	133	0	31	30
2014	7	23	7	52	18	0.164	-0.02	0.768	0.036	0.033	0	44.3	43.9	74	134	133	0	31	31
2014	7	23	8	2	18	0.177	0.039	0.768	0.039	0.036	0	44.7	44.3	72.7	135	133	0	31	30
2014	7	23	8	12	18	0.167	0	0.768	0.033	0.03	0	45.2	44.3	73.1	136	134	0	31	31
2014	7	23	8	22	18	0.161	0.039	0.768	0.039	0.036	0	45.6	45.6	73.1	138	136	0	32	30
2014	7	23	8	32	18	0.177	-0.052	0.768	0.033	0.03	0	46.4	45.6	73.1	139	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	8	42	18	0.066	0.003	0.768	0.036	0.033	0	45.6	45.2	73.1	136	135	0	30	30
2014	7	23	8	52	18	0.154	0.026	0.768	0.036	0.033	0	46	44.7	73.1	138	135	0	31	31
2014	7	23	9	2	18	0.141	-0.007	0.768	0.033	0.03	0	46	45.2	73.1	138	136	0	31	31
2014	7	23	9	12	18	0.062	0.013	0.768	0.033	0.03	0	46	45.6	72.2	138	136	0	31	30
2014	7	23	9	22	18	0.092	-0.026	0.768	0.033	0.03	0	46.4	45.2	73.1	139	135	0	31	30
2014	7	23	9	32	18	0.092	-0.059	0.768	0.036	0.033	0	47.3	45.6	71.4	141	137	0	31	31
2014	7	23	9	42	18	0.21	0.016	0.768	0.036	0.033	0	46.4	46	72.2	139	137	0	31	30
2014	7	23	9	52	18	0.141	-0.023	0.768	0.036	0.033	0	46.4	46.9	72.2	139	139	0	31	30
2014	7	23	10	2	18	0.072	0.085	0.761	0.039	0.036	0	56.8	54.6	54.2	164	157	0	32	30
2014	7	23	10	12	18	0.197	-0.059	0.771	0.033	0.03	0	46.4	45.2	73.1	139	135	0	31	30
2014	7	23	10	22	18	0.184	0.03	0.774	0.036	0.033	0	46	45.6	74.8	137	135	0	30	29
2014	7	23	10	32	18	0.203	-0.02	0.774	0.043	0.039	0	45.6	45.2	73.5	137	135	0	31	30
2014	7	23	10	42	18	0.213	0.046	0.774	0.036	0.033	0	45.2	44.3	74.4	136	134	0	31	31
2014	7	23	10	52	18	0.194	0.003	0.774	0.036	0.033	0	45.2	44.3	74.8	136	133	0	31	30
2014	7	23	11	2	18	0.24	-0.02	0.774	0.036	0.033	0	44.3	43.9	74.8	134	132	0	31	30
2014	7	23	11	12	18	0.157	-0.062	0.778	0.033	0.03	0	46	44.7	75.7	138	134	0	31	30
2014	7	23	11	22	18	0.167	0.016	0.778	0.039	0.036	0	46	44.7	74.4	137	134	0	30	30
2014	7	23	11	32	18	0.194	0.059	0.778	0.036	0.033	0	51.6	50.3	70.1	150	147	0	30	30
2014	7	23	11	42	18	0.24	0.052	0.781	0.039	0.036	0	51.2	49.5	69.7	149	145	0	30	30
2014	7	23	11	52	18	0.22	0.059	0.781	0.033	0.03	0	50.3	49.5	68.8	147	145	0	30	30
2014	7	23	12	2	18	0.21	-0.026	0.784	0.036	0.033	0	50.3	49.9	68.8	148	146	0	31	30
2014	7	23	12	12	18	0.184	0.115	0.787	0.043	0.043	0	49.9	48.2	69.2	146	142	0	30	30
2014	7	23	12	22	18	0.292	0.033	0.787	0.039	0.039	0	49.5	49	68.4	146	143	0	31	29
2014	7	23	12	32	18	0.272	0.052	0.794	0.033	0.03	0	49.5	48.6	68.8	146	143	0	31	30
2014	7	23	12	42	18	0.24	0.089	0.797	0.033	0.03	0	48.6	48.6	68.4	143	143	0	30	30
2014	7	23	12	52	18	0.262	0.062	0.801	0.036	0.033	0	49	48.2	69.2	144	142	0	30	30
2014	7	23	13	2	18	0.282	0.033	0.801	0.033	0.03	0	48.6	47.7	69.2	144	141	0	31	30
2014	7	23	13	12	18	0.217	0.121	0.807	0.036	0.033	0	49.9	47.7	69.2	146	141	0	30	30
2014	7	23	13	22	18	0.253	0.069	0.804	0.033	0.03	0	51.6	50.7	65.8	150	147	0	30	29
2014	7	23	13	32	18	0.322	0.033	0.807	0.033	0.03	0	55	53.3	64.5	158	154	0	30	30
2014	7	23	13	42	18	0.223	0.079	0.807	0.039	0.036	0	52	51.2	66.2	152	148	0	31	29
2014	7	23	13	52	18	0.256	0.112	0.81	0.033	0.03	0	51.2	50.3	67.9	150	147	0	31	30
2014	7	23	14	2	18	0.289	0.121	0.81	0.033	0.03	0	51.6	49.5	68.4	150	145	0	30	30
2014	7	23	14	12	18	0.328	0.151	0.814	0.036	0.033	0	50.7	50.3	68.4	148	146	0	30	29
2014	7	23	14	22	18	0.24	0.167	0.814	0.039	0.036	0	51.2	49.5	69.7	149	144	0	30	29
2014	7	23	14	32	18	0.236	0.135	0.814	0.039	0.036	0	50.3	48.6	69.7	147	143	0	30	30
2014	7	23	14	42	18	0.259	0.095	0.814	0.033	0.03	0	50.3	49	69.7	147	143	0	30	29
2014	7	23	14	52	18	0.266	0.118	0.814	0.033	0.03	0	49.5	49.5	71	145	144	0	30	29
2014	7	23	15	2	18	0.203	0.108	0.814	0.039	0.036	0	50.3	48.6	71	147	142	0	30	29
2014	7	23	15	12	18	0.292	0.079	0.817	0.039	0.036	0	49.9	49	70.5	146	143	0	30	29
2014	7	23	15	22	18	0.335	0.115	0.817	0.036	0.033	0	49	48.6	71.8	144	142	0	30	29
2014	7	23	15	32	18	0.269	0.144	0.817	0.033	0.03	0	49.9	48.6	71.8	146	142	0	30	29
2014	7	23	15	42	18	0.285	0.115	0.817	0.033	0.03	0	49.9	48.2	71.8	146	141	0	30	29
2014	7	23	15	52	18	0.348	0.141	0.817	0.033	0.03	0	49.9	48.6	72.2	145	142	0	29	29
2014	7	23	16	2	18	0.18	0.092	0.817	0.039	0.036	0	49	48.2	72.7	144	141	0	30	29
2014	7	23	16	12	18	0.325	0.112	0.82	0.039	0.036	0	49	48.2	72.2	144	141	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	16	22	18	0.272	0.043	0.817	0.036	0.033	0	52.5	51.6	69.2	152	149	0	30	29
2014	7	23	16	32	18	0.253	0.066	0.82	0.039	0.039	0	52	50.7	70.1	151	147	0	30	29
2014	7	23	16	42	18	0.23	0.095	0.817	0.036	0.033	0	53.3	51.6	68.4	154	149	0	30	29
2014	7	23	16	52	18	0.226	0.108	0.817	0.036	0.033	0	53.3	51.2	68.4	154	148	0	30	29
2014	7	23	17	2	18	0.318	0.2	0.817	0.036	0.033	0	53.3	50.7	68.4	154	147	0	30	29
2014	7	23	17	12	18	0.259	0.095	0.817	0.039	0.036	0	50.7	49	71	148	143	0	30	29
2014	7	23	17	22	18	0.384	0.125	0.82	0.039	0.039	0	49	48.2	71.4	143	141	0	29	29
2014	7	23	17	32	18	0.24	0.144	0.82	0.036	0.033	0	49	46.9	71.4	144	138	0	30	29
2014	7	23	17	42	18	0.315	0.075	0.82	0.039	0.039	0	47.3	46.4	73.5	140	137	0	30	29
2014	7	23	17	52	18	0.217	0.177	0.82	0.033	0.03	0	46.9	46.4	73.1	139	137	0	30	29
2014	7	23	18	2	18	0.348	0.184	0.82	0.036	0.033	0	47.3	46	72.7	140	136	0	30	29
2014	7	23	18	12	18	0.305	0.118	0.82	0.039	0.036	0	46	45.6	74	137	135	0	30	29
2014	7	23	18	22	18	0.282	0.118	0.82	0.039	0.036	0	46.4	44.7	74.4	138	133	0	30	29
2014	7	23	18	32	18	0.272	0.046	0.82	0.036	0.033	0	45.2	44.3	75.3	135	132	0	30	29
2014	7	23	18	42	18	0.243	0.095	0.82	0.039	0.036	0	46	44.7	74.8	137	132	0	30	28
2014	7	23	18	52	18	0.226	0.085	0.82	0.039	0.039	0	45.6	44.7	74.8	136	133	0	30	29
2014	7	23	19	2	18	0.256	0.092	0.82	0.039	0.039	0	45.6	44.3	76.1	136	132	0	30	29
2014	7	23	19	12	18	0.325	0.089	0.823	0.036	0.033	0	45.2	43	75.7	135	130	0	30	30
2014	7	23	19	22	18	0.207	0.174	0.823	0.036	0.033	0	44.7	44.7	75.3	134	132	0	30	28
2014	7	23	19	32	18	0.279	0.082	0.823	0.039	0.036	0	46	44.3	74.4	137	132	0	30	29
2014	7	23	19	42	18	0.299	0.036	0.823	0.036	0.033	0	45.2	44.7	75.7	135	132	0	30	28
2014	7	23	19	52	18	0.233	0.01	0.823	0.039	0.036	0	46.9	45.6	74	138	135	0	29	29
2014	7	23	20	2	18	0.276	0.039	0.823	0.036	0.033	0	45.2	43.9	74.8	135	131	0	30	29
2014	7	23	20	12	18	0.292	-0.02	0.823	0.036	0.033	0	45.2	44.7	75.7	135	133	0	30	29
2014	7	23	20	22	18	0.272	-0.026	0.823	0.036	0.033	0	45.6	44.3	75.7	135	132	0	29	29
2014	7	23	20	32	18	0.348	-0.026	0.823	0.039	0.036	0	47.3	46.4	73.1	140	136	0	30	28
2014	7	23	20	42	18	0.272	0.016	0.823	0.039	0.039	0	48.6	47.3	72.7	143	139	0	30	29
2014	7	23	20	52	18	0.328	0.016	0.823	0.033	0.03	0	47.7	46.9	73.1	141	138	0	30	29
2014	7	23	21	2	18	0.295	-0.043	0.823	0.036	0.033	0	46.9	46	74	139	136	0	30	29
2014	7	23	21	12	18	0.299	-0.039	0.827	0.039	0.036	0	47.7	46	74	141	136	0	30	29
2014	7	23	21	22	18	0.24	-0.059	0.823	0.036	0.033	0	46.4	45.2	74	138	134	0	30	29
2014	7	23	21	32	18	0.249	-0.023	0.827	0.039	0.036	0	46.4	45.6	73.5	138	136	0	30	30
2014	7	23	21	42	18	0.289	-0.02	0.827	0.036	0.033	0	46.4	46	74	138	136	0	30	29
2014	7	23	21	52	18	0.197	-0.02	0.827	0.039	0.036	0	46	45.6	73.1	137	135	0	30	29
2014	7	23	22	2	18	0.213	0.039	0.827	0.039	0.036	0	46.4	45.6	74	138	135	0	30	29
2014	7	23	22	12	18	0.262	0.095	0.827	0.036	0.033	0	46	45.6	74	137	135	0	30	29
2014	7	23	22	22	18	0.285	0.007	0.827	0.039	0.036	0	46.9	46	71.8	139	136	0	30	29
2014	7	23	22	32	18	0.23	0	0.827	0.039	0.039	0	47.7	46.4	72.7	141	137	0	30	29
2014	7	23	22	42	18	0.269	0.039	0.827	0.039	0.039	0	46.9	46.4	72.2	139	137	0	30	29
2014	7	23	22	52	18	0.236	0.023	0.827	0.039	0.036	0	46.9	46	71.8	139	136	0	30	29
2014	7	23	23	2	18	0.295	0.003	0.827	0.033	0.03	0	46.4	46	73.1	138	136	0	30	29
2014	7	23	23	12	18	0.279	-0.066	0.827	0.039	0.036	0	46.4	46.4	72.7	138	137	0	30	29
2014	7	23	23	22	18	0.285	-0.03	0.827	0.039	0.036	0	46.4	46	71.4	138	136	0	30	29
2014	7	23	23	32	18	0.289	0.066	0.827	0.033	0.03	0	47.7	45.6	72.2	141	135	0	30	29
2014	7	23	23	42	18	0.266	0.016	0.827	0.036	0.033	0	46.9	46.4	71.4	139	137	0	30	29
2014	7	23	23	52	18	0.269	-0.079	0.827	0.036	0.033	0	46.9	46	72.2	139	137	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	0	2	18	0.243	0.036	0.83	0.036	0.033	0	46.4	46	71.4	138	137	0	30	30
2014	7	24	0	12	18	0.266	0.01	0.83	0.036	0.033	0	46.9	45.2	71.4	139	135	0	30	30
2014	7	24	0	22	18	0.243	0.016	0.83	0.039	0.039	0	46	46	71.4	137	136	0	30	29
2014	7	24	0	32	18	0.318	-0.007	0.83	0.039	0.039	0	46	46	71.4	138	137	0	31	30
2014	7	24	0	42	18	0.276	-0.013	0.83	0.033	0.03	0	46.9	46	70.5	139	137	0	30	30
2014	7	24	0	52	18	0.24	-0.016	0.83	0.036	0.033	0	46	46	71	138	136	0	31	29
2014	7	24	1	2	18	0.256	-0.01	0.83	0.039	0.036	0	45.6	45.6	70.1	137	136	0	31	30
2014	7	24	1	12	18	0.299	0.026	0.83	0.039	0.039	0	46	44.7	71	138	134	0	31	30
2014	7	24	1	22	18	0.299	-0.075	0.833	0.039	0.036	0	46.4	45.6	70.5	138	135	0	30	29
2014	7	24	1	32	18	0.233	0.043	0.833	0.033	0.03	0	46	45.6	71.4	137	135	0	30	29
2014	7	24	1	42	18	0.272	-0.016	0.833	0.036	0.033	0	46	45.2	71	137	135	0	30	30
2014	7	24	1	52	18	0.262	-0.023	0.833	0.046	0.043	0	46	45.6	69.7	138	136	0	31	30
2014	7	24	2	2	18	0.282	0.003	0.837	0.039	0.036	0	46.4	45.6	70.1	138	135	0	30	29
2014	7	24	2	12	18	0.249	-0.003	0.837	0.039	0.036	0	46	45.2	70.5	138	134	0	31	29
2014	7	24	2	22	18	0.335	-0.059	0.84	0.036	0.033	0	46	45.2	70.1	137	135	0	30	30
2014	7	24	2	32	18	0.269	0.016	0.84	0.039	0.039	0	46.4	45.6	70.1	138	136	0	30	30
2014	7	24	2	42	18	0.262	-0.036	0.84	0.043	0.039	0	46.4	45.6	69.7	138	136	0	30	30
2014	7	24	2	52	18	0.285	0.016	0.84	0.036	0.033	0	46	45.6	70.1	138	136	0	31	30
2014	7	24	3	2	18	0.312	-0.049	0.84	0.039	0.039	0	46	45.2	70.5	138	135	0	31	30
2014	7	24	3	12	18	0.253	-0.046	0.84	0.043	0.039	0	46	45.6	71	138	136	0	31	30
2014	7	24	3	22	18	0.299	0.02	0.84	0.036	0.033	0	46.4	45.6	70.1	138	136	0	30	30
2014	7	24	3	32	18	0.299	-0.003	0.84	0.039	0.039	0	46.4	45.2	71.4	138	135	0	30	30
2014	7	24	3	42	18	0.299	0.026	0.84	0.033	0.03	0	46.4	45.6	71	139	136	0	31	30
2014	7	24	3	52	18	0.246	0	0.843	0.046	0.043	0	46.4	45.2	70.1	138	135	0	30	30
2014	7	24	4	2	18	0.217	-0.033	0.843	0.039	0.036	0	46.9	46	70.1	139	137	0	30	30
2014	7	24	4	12	18	0.236	0.033	0.843	0.036	0.033	0	46.9	46.4	69.7	140	137	0	31	29
2014	7	24	4	22	18	0.2	-0.023	0.843	0.033	0.03	0	46.9	45.6	70.1	140	136	0	31	30
2014	7	24	4	32	18	0.269	-0.007	0.843	0.033	0.03	0	46.9	46	70.5	139	137	0	30	30
2014	7	24	4	42	18	0.22	0.003	0.843	0.036	0.033	0	47.3	45.6	71	140	136	0	30	30
2014	7	24	4	52	18	0.23	0.007	0.843	0.039	0.039	0	47.7	46.4	70.5	141	138	0	30	30
2014	7	24	5	2	18	0.256	-0.039	0.843	0.033	0.03	0	47.3	47.7	70.1	141	140	0	31	29
2014	7	24	5	12	18	0.272	-0.007	0.843	0.033	0.03	0	47.7	46.9	69.7	142	139	0	31	30
2014	7	24	5	22	18	0.272	-0.066	0.843	0.033	0.03	0	48.2	47.7	68.8	143	141	0	31	30
2014	7	24	5	32	18	0.262	-0.039	0.843	0.036	0.033	0	47.7	46.9	70.1	142	138	0	31	29
2014	7	24	5	42	18	0.253	0.023	0.843	0.036	0.033	0	47.3	46.4	70.5	141	138	0	31	30
2014	7	24	5	52	18	0.233	0.026	0.843	0.049	0.049	0	47.7	47.3	69.2	143	139	0	32	29
2014	7	24	6	2	18	0.236	-0.043	0.843	0.049	0.046	0	47.3	46.4	70.5	141	138	0	31	30
2014	7	24	6	12	18	0.269	-0.036	0.843	0.036	0.033	0	49	47.7	69.2	145	141	0	31	30
2014	7	24	6	22	18	0.289	-0.016	0.843	0.036	0.033	0	49	48.2	68.4	145	142	0	31	30
2014	7	24	6	32	18	0.269	-0.02	0.843	0.043	0.039	0	49.9	48.2	69.2	146	142	0	30	30
2014	7	24	6	42	18	0.213	-0.013	0.843	0.033	0.03	0	47.7	46	70.5	141	138	0	30	31
2014	7	24	6	52	18	0.2	0.039	0.843	0.036	0.033	0	46.4	46	71.8	138	136	0	30	29
2014	7	24	7	2	18	0.203	0.043	0.843	0.036	0.033	0	50.3	48.6	68.4	148	143	0	31	30
2014	7	24	7	12	18	0.276	-0.033	0.843	0.039	0.036	0	47.3	46.4	71.4	141	138	0	31	30
2014	7	24	7	22	18	0.269	0.036	0.843	0.039	0.039	0	47.7	46.9	70.5	142	139	0	31	30
2014	7	24	7	32	18	0.404	-0.092	0.843	0.036	0.033	0	48.2	47.7	71	143	140	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	7	42	18	0.322	-0.02	0.843	0.036	0.033	0	49	47.7	69.7	145	141	0	31	30
2014	7	24	7	52	18	0.266	-0.089	0.846	0.036	0.033	0	47.7	47.7	70.5	143	141	0	32	30
2014	7	24	8	2	18	0.305	-0.007	0.846	0.036	0.033	0	48.6	47.3	70.5	144	140	0	31	30
2014	7	24	8	12	18	0.249	0.036	0.846	0.033	0.03	0	49	47.3	71	144	140	0	30	30
2014	7	24	8	22	18	0.279	0.052	0.846	0.039	0.036	0	49.9	48.2	70.5	147	142	0	31	30
2014	7	24	8	32	18	0.213	-0.056	0.846	0.036	0.033	0	47.3	46.4	71.8	141	138	0	31	30
2014	7	24	8	42	18	0.269	0.003	0.846	0.036	0.033	0	48.2	47.7	71.4	143	141	0	31	30
2014	7	24	8	52	18	0.305	-0.026	0.846	0.049	0.049	0	48.6	47.7	70.5	145	141	0	32	30
2014	7	24	9	2	18	0.266	-0.01	0.846	0.039	0.039	0	47.3	46.9	71.4	141	139	0	31	30
2014	7	24	9	12	18	0.276	0.01	0.846	0.039	0.039	0	48.6	47.7	69.7	144	141	0	31	30
2014	7	24	9	22	18	0.259	-0.026	0.846	0.039	0.036	0	49.5	47.7	70.1	145	141	0	30	30
2014	7	24	9	32	18	0.285	0.016	0.843	0.039	0.036	0	49.5	48.2	69.7	146	142	0	31	30
2014	7	24	9	42	18	0.246	0.052	0.846	0.039	0.036	0	49.9	48.2	69.7	147	142	0	31	30
2014	7	24	9	52	18	0.285	0.03	0.846	0.043	0.039	0	49	48.2	69.7	145	142	0	31	30
2014	7	24	10	2	18	0.282	-0.039	0.843	0.043	0.039	0	48.6	47.3	70.5	144	140	0	31	30
2014	7	24	10	12	18	0.318	-0.013	0.843	0.039	0.039	0	47.3	45.6	71.8	140	136	0	30	30
2014	7	24	10	22	18	0.299	0.026	0.846	0.039	0.039	0	45.6	45.6	72.2	138	136	0	32	30
2014	7	24	10	32	18	0.279	0.033	0.846	0.039	0.039	0	46	45.2	72.7	138	135	0	31	30
2014	7	24	10	42	18	0.256	-0.023	0.846	0.036	0.033	0	45.6	45.2	72.2	137	135	0	31	30
2014	7	24	10	52	18	0.259	-0.056	0.843	0.039	0.039	0	45.6	45.2	71.8	137	135	0	31	30
2014	7	24	11	2	18	0.289	0.033	0.843	0.043	0.039	0	45.6	46	72.2	137	137	0	31	30
2014	7	24	11	12	18	0.354	0.01	0.843	0.036	0.033	0	46	45.6	71.8	139	136	0	32	30
2014	7	24	11	22	18	0.256	0.039	0.843	0.033	0.033	0	46	46	71	138	137	0	31	30
2014	7	24	11	32	18	0.276	0.02	0.843	0.036	0.033	0	46.9	46	71.4	140	137	0	31	30
2014	7	24	11	42	18	0.348	0.135	0.843	0.036	0.033	0	47.3	46.9	70.5	140	139	0	30	30
2014	7	24	11	52	18	0.312	0.01	0.843	0.039	0.039	0	47.3	46.4	70.5	140	138	0	30	30
2014	7	24	12	2	18	0.272	0.092	0.84	0.036	0.033	0	47.7	47.3	69.7	141	140	0	30	30
2014	7	24	12	12	18	0.256	0.01	0.84	0.052	0.049	0	48.6	48.6	68.4	144	143	0	31	30
2014	7	24	12	22	18	0.318	0.039	0.843	0.039	0.036	0	51.2	49.9	68.8	149	146	0	30	30
2014	7	24	12	32	18	0.276	0.062	0.843	0.039	0.039	0	50.3	50.3	67.9	148	146	0	31	29
2014	7	24	12	42	18	0.279	0.013	0.84	0.039	0.036	0	50.7	49.9	67.1	148	146	0	30	30
2014	7	24	12	52	18	0.253	0	0.84	0.039	0.036	0	51.6	51.2	66.2	151	148	0	31	29
2014	7	24	13	2	18	0.318	0.023	0.84	0.039	0.036	0	50.7	49.5	67.9	148	144	0	30	29
2014	7	24	13	12	18	0.256	0.098	0.837	0.039	0.036	0	48.6	48.2	69.2	143	142	0	30	30
2014	7	24	13	22	18	0.315	0	0.833	0.039	0.036	0	49	48.6	68.8	144	142	0	30	29
2014	7	24	13	32	18	0.285	0.121	0.83	0.036	0.033	0	49	48.2	69.2	144	141	0	30	29
2014	7	24	13	42	18	0.338	0.03	0.83	0.033	0.03	0	48.6	47.7	69.2	143	141	0	30	30
2014	7	24	13	52	18	0.312	0.066	0.83	0.036	0.033	0	49	47.7	70.1	144	140	0	30	29
2014	7	24	14	2	18	0.289	0.095	0.83	0.033	0.03	0	48.6	48.2	70.5	143	141	0	30	29
2014	7	24	14	12	18	0.318	0.066	0.827	0.036	0.033	0	49	47.7	71	144	140	0	30	29
2014	7	24	14	22	18	0.308	0.085	0.827	0.039	0.039	0	48.6	47.7	71	143	140	0	30	29
2014	7	24	14	32	18	0.295	0.016	0.827	0.036	0.033	0	48.6	48.6	71.8	143	142	0	30	29
2014	7	24	14	42	18	0.308	0.036	0.827	0.033	0.03	0	49.5	48.6	71.8	145	142	0	30	29
2014	7	24	14	52	18	0.344	0.102	0.827	0.033	0.03	0	48.6	47.7	71.8	143	141	0	30	30
2014	7	24	15	2	18	0.289	0.079	0.823	0.036	0.033	0	48.6	47.3	71.4	143	140	0	30	30
2014	7	24	15	12	18	0.292	0.069	0.823	0.043	0.039	0	49.5	49	72.2	145	143	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	15	22	18	0.404	0.092	0.823	0.039	0.036	0	48.6	47.7	72.7	143	141	0	30	30
2014	7	24	15	32	18	0.256	0.105	0.823	0.033	0.03	0	49	47.7	73.1	144	141	0	30	30
2014	7	24	15	42	18	0.328	0.151	0.823	0.039	0.036	0	48.2	49	72.7	142	143	0	30	29
2014	7	24	15	52	18	0.312	0.121	0.823	0.036	0.033	0	49	47.7	72.2	144	140	0	30	29
2014	7	24	16	2	18	0.308	0.135	0.82	0.039	0.039	0	49	47.7	73.1	144	140	0	30	29
2014	7	24	16	12	18	0.24	0.177	0.82	0.033	0.03	0	49	47.7	72.2	144	140	0	30	29
2014	7	24	16	22	18	0.295	0.092	0.82	0.039	0.036	0	48.2	48.2	73.1	143	140	0	31	28
2014	7	24	16	32	18	0.276	0.18	0.82	0.033	0.03	0	48.2	46.9	73.1	142	139	0	30	30
2014	7	24	16	42	18	0.305	0.092	0.82	0.039	0.036	0	47.7	46.9	72.2	141	138	0	30	29
2014	7	24	16	52	18	0.272	0.125	0.82	0.033	0.03	0	47.7	46.9	72.2	141	138	0	30	29
2014	7	24	17	2	18	0.312	0.174	0.817	0.039	0.036	0	48.6	46.9	72.7	143	138	0	30	29
2014	7	24	17	12	18	0.22	0.148	0.817	0.039	0.036	0	47.3	46	72.2	140	136	0	30	29
2014	7	24	17	22	18	0.259	0.157	0.817	0.033	0.03	0	47.7	46	72.2	141	136	0	30	29
2014	7	24	17	32	18	0.292	0.154	0.817	0.039	0.036	0	48.6	46	70.5	143	137	0	30	30
2014	7	24	17	42	18	0.246	0.112	0.817	0.039	0.039	0	49	47.3	71	144	139	0	30	29
2014	7	24	17	52	18	0.279	0.161	0.817	0.039	0.039	0	48.2	46.4	69.7	142	137	0	30	29
2014	7	24	18	2	18	0.256	0.125	0.817	0.039	0.039	0	48.2	46.4	71	142	137	0	30	29
2014	7	24	18	12	18	0.226	0.125	0.814	0.039	0.036	0	47.7	46.4	71.4	141	137	0	30	29
2014	7	24	18	22	18	0.253	0.2	0.814	0.036	0.033	0	47.7	45.6	71	141	135	0	30	29
2014	7	24	18	32	18	0.24	0.128	0.814	0.043	0.039	0	51.2	49.5	67.1	149	144	0	30	29
2014	7	24	18	42	18	0.226	0.046	0.814	0.039	0.036	0	50.3	48.6	67.5	147	142	0	30	29
2014	7	24	18	52	18	0.295	0.102	0.814	0.043	0.039	0	48.2	46	69.2	142	138	0	30	31
2014	7	24	19	2	18	0.24	0.02	0.814	0.046	0.046	0	47.7	46.4	70.5	141	137	0	30	29
2014	7	24	19	12	18	0.269	0.059	0.814	0.039	0.039	0	47.7	46	71.4	141	136	0	30	29
2014	7	24	19	22	18	0.253	0.023	0.814	0.036	0.033	0	47.3	45.6	71	139	135	0	29	29
2014	7	24	19	32	18	0.233	0.066	0.814	0.033	0.03	0	47.3	45.2	71.4	139	134	0	29	29
2014	7	24	19	42	18	0.246	0.043	0.814	0.039	0.036	0	46	45.2	71.4	137	134	0	30	29
2014	7	24	19	52	18	0.266	0.039	0.814	0.039	0.036	0	46	44.3	72.2	137	132	0	30	29
2014	7	24	20	2	18	0.246	0.033	0.814	0.036	0.033	0	46	44.3	72.2	137	132	0	30	29
2014	7	24	20	12	18	0.207	0.043	0.814	0.039	0.036	0	48.6	47.7	69.2	143	140	0	30	29
2014	7	24	20	22	18	0.246	0.049	0.814	0.036	0.033	0	47.7	46.4	70.5	141	137	0	30	29
2014	7	24	20	32	18	0.246	-0.033	0.814	0.039	0.039	0	49	47.7	69.2	144	140	0	30	29
2014	7	24	20	42	18	0.305	0.016	0.81	0.039	0.036	0	50.7	49	67.5	148	143	0	30	29
2014	7	24	20	52	18	0.197	-0.023	0.814	0.043	0.039	0	50.7	49.5	67.9	148	144	0	30	29
2014	7	24	21	2	18	0.24	-0.033	0.814	0.043	0.039	0	49	47.3	69.7	144	140	0	30	30
2014	7	24	21	12	18	0.259	0.023	0.814	0.036	0.033	0	48.6	47.3	70.5	143	139	0	30	29
2014	7	24	21	22	18	0.289	-0.023	0.814	0.036	0.033	0	48.2	46.9	71.8	142	138	0	30	29
2014	7	24	21	32	18	0.318	-0.026	0.814	0.043	0.039	0	47.3	47.3	72.2	140	139	0	30	29
2014	7	24	21	42	18	0.256	-0.02	0.814	0.039	0.036	0	46.9	46.4	71.8	139	138	0	30	30
2014	7	24	21	52	18	0.2	0	0.814	0.049	0.046	0	46.9	46.4	72.7	140	137	0	31	29
2014	7	24	22	2	18	0.207	0.03	0.814	0.036	0.033	0	46.9	46	72.2	139	136	0	30	29
2014	7	24	22	12	18	0.256	-0.049	0.814	0.036	0.033	0	47.7	46.4	72.2	141	138	0	30	30
2014	7	24	22	22	18	0.2	0.016	0.817	0.036	0.033	0	46.9	46.4	73.5	140	137	0	31	29
2014	7	24	22	32	18	0.236	-0.052	0.817	0.033	0.03	0	47.7	46.9	73.1	140	138	0	29	29
2014	7	24	22	42	18	0.259	-0.023	0.817	0.036	0.033	0	46.9	46.4	74	139	137	0	30	29
2014	7	24	22	52	18	0.19	-0.02	0.817	0.036	0.033	0	47.3	46	73.5	140	137	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	23	2	18	0.259	-0.03	0.814	0.036	0.033	0	47.3	46.4	73.1	140	137	0	30	29
2014	7	24	23	12	18	0.256	-0.01	0.817	0.036	0.033	0	47.3	46	74	140	136	0	30	29
2014	7	24	23	22	18	0.289	0.016	0.817	0.039	0.039	0	46.4	46	74	138	136	0	30	29
2014	7	24	23	32	18	0.276	0.036	0.817	0.039	0.039	0	46.4	46.4	74.4	138	137	0	30	29
2014	7	24	23	42	18	0.217	0.092	0.817	0.033	0.03	0	46.9	46.9	74.4	138	138	0	29	29
2014	7	24	23	52	18	0.259	0.039	0.817	0.033	0.03	0	46.9	46.4	74.4	139	137	0	30	29
2014	7	25	0	2	18	0.236	-0.013	0.817	0.033	0.03	0	46.4	46	74	139	136	0	31	29
2014	7	25	0	12	18	0.23	-0.036	0.817	0.033	0.03	0	46.4	45.6	74	138	135	0	30	29
2014	7	25	0	22	18	0.243	0.075	0.817	0.039	0.036	0	46.4	46.4	74.4	139	137	0	31	29
2014	7	25	0	32	18	0.295	0.052	0.817	0.033	0.03	0	46.4	45.6	74.4	139	136	0	31	30
2014	7	25	0	42	18	0.262	-0.003	0.817	0.033	0.03	0	46.9	45.6	74.4	139	136	0	30	30
2014	7	25	0	52	18	0.249	0.059	0.817	0.036	0.033	0	46.9	45.2	74.8	139	135	0	30	30
2014	7	25	1	2	18	0.246	0.056	0.817	0.033	0.03	0	46	45.6	74.4	137	135	0	30	29
2014	7	25	1	12	18	0.21	0.043	0.817	0.039	0.039	0	47.3	46.9	73.1	141	139	0	31	30
2014	7	25	1	22	18	0.262	-0.02	0.817	0.033	0.03	0	49	48.2	71.8	144	142	0	30	30
2014	7	25	1	32	18	0.262	-0.085	0.817	0.033	0.03	0	47.7	46.9	74	142	138	0	31	29
2014	7	25	1	42	18	0.262	0.007	0.817	0.033	0.03	0	47.3	46	73.5	140	137	0	30	30
2014	7	25	1	52	18	0.21	-0.033	0.817	0.039	0.039	0	47.3	46.9	74	140	139	0	30	30
2014	7	25	2	2	18	0.207	0.013	0.817	0.036	0.033	0	47.3	46	74	140	137	0	30	30
2014	7	25	2	12	18	0.299	-0.013	0.817	0.036	0.033	0	46.9	46	73.5	139	136	0	30	29
2014	7	25	2	22	18	0.269	-0.069	0.817	0.033	0.03	0	46	45.6	74	137	136	0	30	30
2014	7	25	2	32	18	0.262	-0.036	0.817	0.039	0.036	0	46.9	46	74	139	137	0	30	30
2014	7	25	2	42	18	0.292	-0.023	0.817	0.036	0.033	0	45.6	44.7	74.4	137	134	0	31	30
2014	7	25	2	52	18	0.236	-0.007	0.817	0.043	0.039	0	46.4	45.2	74	139	135	0	31	30
2014	7	25	3	2	18	0.18	-0.075	0.817	0.033	0.03	0	45.6	46.4	74.8	137	137	0	31	29
2014	7	25	3	12	18	0.236	0.026	0.817	0.033	0.03	0	46	45.2	74.8	137	135	0	30	30
2014	7	25	3	22	18	0.22	-0.003	0.817	0.039	0.036	0	46.4	46	73.5	138	136	0	30	29
2014	7	25	3	32	18	0.292	0.03	0.817	0.039	0.039	0	46.4	45.2	74.4	139	135	0	31	30
2014	7	25	3	42	18	0.24	-0.016	0.817	0.036	0.033	0	45.2	45.6	74.4	137	135	0	32	29
2014	7	25	3	52	18	0.269	-0.03	0.817	0.036	0.033	0	46	45.2	73.5	138	135	0	31	30
2014	7	25	4	2	18	0.2	0.007	0.817	0.036	0.033	0	46.4	45.6	73.5	139	136	0	31	30
2014	7	25	4	12	18	0.253	-0.02	0.817	0.033	0.03	0	45.6	45.2	74.4	137	135	0	31	30
2014	7	25	4	22	18	0.236	-0.02	0.817	0.036	0.033	0	46	44.7	74	137	134	0	30	30
2014	7	25	4	32	18	0.223	0.013	0.817	0.033	0.03	0	46.4	46	74.4	138	136	0	30	29
2014	7	25	4	42	18	0.217	-0.023	0.817	0.036	0.033	0	45.6	45.6	74	137	135	0	31	29
2014	7	25	4	52	18	0.233	0.089	0.817	0.033	0.03	0	46.4	45.2	73.5	138	135	0	30	30
2014	7	25	5	2	18	0.236	0	0.817	0.039	0.036	0	46.4	45.2	73.5	138	135	0	30	30
2014	7	25	5	12	18	0.223	0.007	0.817	0.033	0.03	0	46.4	45.6	74	139	136	0	31	30
2014	7	25	5	22	18	0.233	0.003	0.817	0.039	0.036	0	46.4	45.6	74	138	136	0	30	30
2014	7	25	5	32	18	0.285	-0.039	0.817	0.036	0.033	0	45.6	44.7	74	137	134	0	31	30
2014	7	25	5	42	18	0.23	-0.046	0.817	0.036	0.033	0	44.7	44.7	74.4	136	134	0	32	30
2014	7	25	5	52	18	0.259	0.01	0.817	0.049	0.046	0	45.2	44.3	74	136	134	0	31	31
2014	7	25	6	2	18	0.21	0.02	0.817	0.039	0.036	0	44.7	43.9	74.4	135	132	0	31	30
2014	7	25	6	12	18	0.272	-0.062	0.814	0.036	0.033	0	44.7	44.3	74.8	135	133	0	31	30
2014	7	25	6	22	18	0.171	-0.02	0.814	0.039	0.036	0	45.2	43.9	74.4	136	132	0	31	30
2014	7	25	6	32	18	0.203	0.01	0.817	0.039	0.036	0	45.2	43.9	74.8	136	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	6	42	18	0.269	-0.026	0.814	0.033	0.03	0	45.2	44.3	74.8	136	133	0	31	30
2014	7	25	6	52	18	0.236	0.098	0.814	0.033	0.03	0	44.3	44.3	75.7	134	133	0	31	30
2014	7	25	7	2	18	0.292	0.003	0.814	0.039	0.039	0	44.7	44.7	74.8	135	134	0	31	30
2014	7	25	7	12	18	0.223	-0.036	0.814	0.033	0.03	0	44.7	45.2	75.3	135	134	0	31	29
2014	7	25	7	22	18	0.2	-0.016	0.814	0.033	0.03	0	45.6	44.7	74.4	136	134	0	30	30
2014	7	25	7	32	18	0.256	0.013	0.814	0.036	0.033	0	44.7	44.3	74.8	135	134	0	31	31
2014	7	25	7	42	18	0.24	-0.02	0.814	0.033	0.03	0	45.6	44.7	75.3	137	134	0	31	30
2014	7	25	7	52	18	0.256	0.007	0.814	0.033	0.03	0	46	45.2	74.8	137	135	0	30	30
2014	7	25	8	2	18	0.259	-0.026	0.814	0.036	0.033	0	45.6	44.7	74.8	137	135	0	31	31
2014	7	25	8	12	18	0.203	-0.016	0.814	0.039	0.036	0	45.2	44.7	75.7	136	135	0	31	31
2014	7	25	8	22	18	0.276	-0.003	0.814	0.033	0.03	0	45.2	44.7	75.7	136	133	0	31	29
2014	7	25	8	32	18	0.217	0	0.814	0.039	0.036	0	45.2	43.9	75.3	136	133	0	31	31
2014	7	25	8	42	18	0.203	0.036	0.814	0.039	0.036	0	45.6	44.3	75.7	137	133	0	31	30
2014	7	25	8	52	18	0.19	0.062	0.814	0.043	0.039	0	44.7	44.7	75.3	135	134	0	31	30
2014	7	25	9	2	18	0.203	0.036	0.814	0.036	0.033	0	45.2	44.7	75.7	136	134	0	31	30
2014	7	25	9	12	18	0.259	0.085	0.814	0.036	0.033	0	46	44.3	76.1	137	134	0	30	31
2014	7	25	9	22	18	0.243	0.01	0.814	0.033	0.03	0	46	45.2	74.8	138	135	0	31	30
2014	7	25	9	32	18	0.246	-0.036	0.814	0.039	0.036	0	45.6	45.2	74.4	137	135	0	31	30
2014	7	25	9	42	18	0.259	0.003	0.814	0.043	0.039	0	46.4	45.6	74.8	139	136	0	31	30
2014	7	25	9	52	18	0.276	0.033	0.814	0.039	0.036	0	46	45.6	74.4	138	135	0	31	29
2014	7	25	10	2	18	0.174	0.056	0.814	0.039	0.036	0	45.6	44.7	75.3	136	134	0	30	30
2014	7	25	10	12	18	0.308	0.007	0.814	0.039	0.039	0	45.2	43.9	74.8	136	132	0	31	30
2014	7	25	10	22	18	0.272	0.039	0.81	0.039	0.039	0	44.3	44.3	74.8	135	133	0	32	30
2014	7	25	10	32	18	0.226	-0.003	0.81	0.043	0.039	0	45.2	44.3	75.3	136	133	0	31	30
2014	7	25	10	42	18	0.292	0.03	0.81	0.033	0.03	0	45.2	44.3	74.8	136	133	0	31	30
2014	7	25	10	52	18	0.184	-0.036	0.81	0.036	0.033	0	45.2	44.7	74.8	135	134	0	30	30
2014	7	25	11	2	18	0.295	0.039	0.81	0.033	0.03	0	45.2	45.2	74.4	136	135	0	31	30
2014	7	25	11	12	18	0.22	-0.066	0.81	0.033	0.03	0	45.6	45.2	74	137	135	0	31	30
2014	7	25	11	22	18	0.249	0.089	0.81	0.036	0.033	0	46	45.6	73.1	138	136	0	31	30
2014	7	25	11	32	18	0.276	0	0.81	0.036	0.033	0	46	46	72.7	138	137	0	31	30
2014	7	25	11	42	18	0.22	-0.02	0.807	0.036	0.033	0	46.9	47.3	72.7	139	140	0	30	30
2014	7	25	11	52	18	0.259	0.069	0.807	0.039	0.036	0	46.4	46.9	72.2	139	139	0	31	30
2014	7	25	12	2	18	0.22	0.016	0.807	0.039	0.036	0	46.9	46.9	71.8	140	139	0	31	30
2014	7	25	12	12	18	0.292	0.03	0.804	0.033	0.03	0	47.3	46.4	70.5	140	138	0	30	30
2014	7	25	12	22	18	0.295	0.033	0.804	0.033	0.03	0	47.7	47.3	71	141	140	0	30	30
2014	7	25	12	32	18	0.253	0.036	0.801	0.043	0.043	0	46.9	46.4	69.7	140	138	0	31	30
2014	7	25	12	42	18	0.144	0.089	0.797	0.039	0.039	0	46.9	47.3	68.8	140	140	0	31	30
2014	7	25	12	52	18	0.203	0.033	0.794	0.033	0.03	0	48.6	47.7	69.7	143	140	0	30	29
2014	7	25	13	2	18	0.282	0.03	0.791	0.039	0.036	0	48.6	47.7	70.1	143	140	0	30	29
2014	7	25	13	12	18	0.285	-0.01	0.791	0.043	0.039	0	47.7	48.2	70.5	141	141	0	30	29
2014	7	25	13	22	18	0.184	0.075	0.787	0.03	0.03	0	48.6	48.2	70.1	143	141	0	30	29
2014	7	25	13	32	18	0.19	0.075	0.787	0.039	0.039	0	48.6	48.2	71.4	143	141	0	30	29
2014	7	25	13	42	18	0.259	0.069	0.787	0.036	0.033	0	48.2	47.3	72.2	142	139	0	30	29
2014	7	25	13	52	18	0.276	0.079	0.784	0.033	0.03	0	49.5	48.2	72.2	145	141	0	30	29
2014	7	25	14	2	18	0.266	0.046	0.784	0.033	0.03	0	48.6	47.3	72.7	143	140	0	30	30
2014	7	25	14	12	18	0.272	0.075	0.784	0.033	0.03	0	49	47.7	72.2	144	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	14	22	18	0.302	0.033	0.784	0.033	0.03	0	48.2	47.7	72.2	142	141	0	30	30
2014	7	25	14	32	18	0.279	0.066	0.784	0.033	0.03	0	49	47.7	72.2	144	141	0	30	30
2014	7	25	14	42	18	0.207	0.036	0.784	0.036	0.033	0	48.6	47.7	72.7	143	141	0	30	30
2014	7	25	14	52	18	0.259	-0.013	0.784	0.036	0.033	0	50.7	49.5	72.2	148	145	0	30	30
2014	7	25	15	2	18	0.217	0.092	0.781	0.039	0.036	0	48.6	48.2	71.8	144	141	0	31	29
2014	7	25	15	12	18	0.161	0.02	0.781	0.036	0.033	0	48.6	48.2	72.7	144	142	0	31	30
2014	7	25	15	22	18	0.292	0.003	0.781	0.036	0.033	0	48.2	48.2	72.7	142	141	0	30	29
2014	7	25	15	32	18	0.243	0.023	0.781	0.033	0.03	0	48.6	47.7	72.7	144	141	0	31	30
2014	7	25	15	42	18	0.21	-0.007	0.778	0.033	0.03	0	48.2	47.3	71.8	142	139	0	30	29
2014	7	25	15	52	18	0.197	0.066	0.781	0.039	0.036	0	47.3	46.9	71.8	140	138	0	30	29
2014	7	25	16	2	18	0.295	0.056	0.778	0.033	0.03	0	48.6	46.9	71.8	142	138	0	29	29
2014	7	25	16	12	18	0.213	0.036	0.778	0.039	0.036	0	47.7	47.3	71.8	141	139	0	30	29
2014	7	25	16	22	18	0.197	0.102	0.774	0.033	0.03	0	47.7	47.3	69.7	141	139	0	30	29
2014	7	25	16	32	18	0.226	0.079	0.778	0.036	0.033	0	48.2	47.7	69.7	142	140	0	30	29
2014	7	25	16	42	18	0.213	0.161	0.774	0.036	0.033	0	49	48.2	67.9	144	141	0	30	29
2014	7	25	16	52	18	0.167	0.105	0.774	0.036	0.033	0	49	48.2	67.5	144	141	0	30	29
2014	7	25	17	2	18	0.184	0.056	0.771	0.039	0.039	0	48.6	47.7	66.7	143	141	0	30	30
2014	7	25	17	12	18	0.174	0.056	0.771	0.033	0.03	0	48.6	47.7	68.4	142	140	0	29	29
2014	7	25	17	22	18	0.217	0.089	0.768	0.036	0.033	0	49.5	47.7	66.7	144	140	0	29	29
2014	7	25	17	32	18	0.174	0.059	0.768	0.039	0.036	0	48.2	46.9	67.5	142	138	0	30	29
2014	7	25	17	42	18	0.282	0.075	0.768	0.036	0.033	0	47.7	47.7	67.5	141	139	0	30	28
2014	7	25	17	52	18	0.21	0.079	0.768	0.033	0.03	0	47.7	46.4	67.9	141	137	0	30	29
2014	7	25	18	2	18	0.256	0.167	0.768	0.036	0.033	0	46.9	45.6	69.2	139	135	0	30	29
2014	7	25	18	12	18	0.207	0.19	0.764	0.036	0.033	0	46	44.7	70.1	137	133	0	30	29
2014	7	25	18	22	18	0.19	0.039	0.764	0.039	0.036	0	45.6	44.3	69.7	136	132	0	30	29
2014	7	25	18	32	18	0.253	0.151	0.761	0.043	0.039	0	45.2	44.7	69.7	135	133	0	30	29
2014	7	25	18	42	18	0.285	0.075	0.758	0.039	0.036	0	46.4	45.2	67.5	138	134	0	30	29
2014	7	25	18	52	18	0.233	-0.026	0.755	0.039	0.036	0	48.6	47.3	67.5	143	139	0	30	29
2014	7	25	19	2	18	0.223	0.036	0.755	0.039	0.036	0	49.9	48.2	66.7	146	141	0	30	29
2014	7	25	19	12	18	0.141	0.016	0.755	0.039	0.039	0	49.9	48.2	65.8	146	141	0	30	29
2014	7	25	19	22	18	0.174	-0.033	0.755	0.043	0.039	0	48.6	47.7	67.1	143	139	0	30	28
2014	7	25	19	32	18	0.194	-0.016	0.755	0.036	0.033	0	48.6	46.9	67.9	143	138	0	30	29
2014	7	25	19	42	18	0.197	0.03	0.751	0.039	0.036	0	49	47.7	66.7	144	139	0	30	28
2014	7	25	19	52	18	0.18	0	0.751	0.039	0.036	0	49.9	48.6	66.2	146	141	0	30	28
2014	7	25	20	2	18	0.177	0.003	0.751	0.036	0.033	0	48.2	46.4	68.8	142	137	0	30	29
2014	7	25	20	12	18	0.141	-0.039	0.751	0.039	0.039	0	46.9	45.6	69.7	138	135	0	29	29
2014	7	25	20	22	18	0.187	0.03	0.751	0.036	0.033	0	46	45.2	70.1	137	135	0	30	30
2014	7	25	20	32	18	0.174	-0.023	0.751	0.036	0.033	0	45.2	44.7	72.2	135	133	0	30	29
2014	7	25	20	42	18	0.154	0.013	0.751	0.033	0.03	0	46	44.7	71.4	137	133	0	30	29
2014	7	25	20	52	18	0.187	-0.03	0.751	0.033	0.03	0	46.4	44.7	71.8	138	134	0	30	30
2014	7	25	21	2	18	0.108	-0.007	0.751	0.036	0.033	0	46.4	45.2	71.4	137	134	0	29	29
2014	7	25	21	12	18	0.2	-0.059	0.751	0.036	0.033	0	46.4	46	71.4	138	136	0	30	29
2014	7	25	21	22	18	0.262	0.095	0.751	0.039	0.036	0	46.4	45.2	71.8	138	134	0	30	29
2014	7	25	21	32	18	0.253	0.039	0.748	0.036	0.033	0	46.4	46	71.8	138	136	0	30	29
2014	7	25	21	42	18	0.167	-0.072	0.748	0.033	0.03	0	47.3	45.6	72.2	140	135	0	30	29
2014	7	25	21	52	18	0.187	0	0.748	0.03	0.03	0	46	46	71.8	137	136	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	22	2	18	0.184	-0.003	0.748	0.033	0.03	0	47.3	45.2	71.8	140	135	0	30	30
2014	7	25	22	12	18	0.157	-0.023	0.748	0.039	0.039	0	45.2	44.7	73.1	135	134	0	30	30
2014	7	25	22	22	18	0.21	-0.026	0.748	0.033	0.033	0	46.9	45.2	72.2	138	135	0	29	30
2014	7	25	22	32	18	0.187	0.036	0.748	0.043	0.043	0	46.9	45.6	72.2	138	135	0	29	29
2014	7	25	22	42	18	0.148	0	0.745	0.036	0.033	0	46	45.2	72.7	138	135	0	31	30
2014	7	25	22	52	18	0.144	0	0.745	0.039	0.036	0	46	45.6	73.1	137	135	0	30	29
2014	7	25	23	2	18	0.131	-0.043	0.745	0.033	0.03	0	45.6	45.6	72.7	136	136	0	30	30
2014	7	25	23	12	18	0.121	-0.02	0.745	0.039	0.036	0	46.4	45.6	72.7	138	135	0	30	29
2014	7	25	23	22	18	0.194	-0.026	0.745	0.039	0.036	0	46.4	45.2	72.2	138	135	0	30	30
2014	7	25	23	32	18	0.128	-0.039	0.745	0.036	0.033	0	46.9	46	72.2	139	136	0	30	29
2014	7	25	23	42	18	0.135	-0.02	0.745	0.036	0.033	0	46.9	46	72.7	139	136	0	30	29
2014	7	25	23	52	18	0.151	0	0.745	0.036	0.033	0	46.9	46	73.1	139	136	0	30	29
2014	7	26	0	2	18	0.197	-0.052	0.741	0.033	0.03	0	47.3	46.9	72.2	140	139	0	30	30
2014	7	26	0	12	18	0.167	-0.02	0.745	0.033	0.03	0	46.4	45.6	72.2	138	136	0	30	30
2014	7	26	0	22	18	0.226	-0.049	0.745	0.039	0.036	0	46.4	46	72.7	139	136	0	31	29
2014	7	26	0	32	18	0.23	0.013	0.745	0.033	0.03	0	46.4	45.6	72.7	138	136	0	30	30
2014	7	26	0	42	18	0.167	-0.036	0.745	0.033	0.03	0	47.3	46	72.7	140	136	0	30	29
2014	7	26	0	52	18	0.213	-0.02	0.745	0.033	0.03	0	46	45.6	72.2	137	135	0	30	29
2014	7	26	1	2	18	0.177	-0.043	0.741	0.036	0.033	0	46.9	45.6	72.2	139	135	0	30	29
2014	7	26	1	12	18	0.128	-0.016	0.741	0.033	0.03	0	46	46	73.5	138	136	0	31	29
2014	7	26	1	22	18	0.154	0.02	0.741	0.039	0.036	0	44.3	45.2	73.1	134	134	0	31	29
2014	7	26	1	32	18	0.121	-0.066	0.741	0.033	0.03	0	46	45.6	73.5	138	136	0	31	30
2014	7	26	1	42	18	0.095	-0.02	0.741	0.039	0.036	0	46	45.6	73.1	138	136	0	31	30
2014	7	26	1	52	18	0.187	-0.039	0.741	0.033	0.03	0	46	45.2	73.1	137	135	0	30	30
2014	7	26	2	2	18	0.164	-0.085	0.741	0.033	0.03	0	46	45.6	73.5	137	136	0	30	30
2014	7	26	2	12	18	0.184	-0.02	0.741	0.033	0.03	0	46	45.6	73.5	138	136	0	31	30
2014	7	26	2	22	18	0.164	0.013	0.741	0.036	0.033	0	45.2	44.7	74	136	134	0	31	30
2014	7	26	2	32	18	0.207	0.013	0.741	0.039	0.036	0	46.9	46	73.1	140	137	0	31	30
2014	7	26	2	42	18	0.164	0.026	0.741	0.033	0.03	0	46.9	45.6	73.1	139	136	0	30	30
2014	7	26	2	52	18	0.23	-0.072	0.741	0.03	0.03	0	46	46.4	72.2	138	138	0	31	30
2014	7	26	3	2	18	0.2	-0.066	0.741	0.036	0.033	0	46.4	46.4	72.7	139	138	0	31	30
2014	7	26	3	12	18	0.171	0.02	0.741	0.036	0.033	0	46.9	47.3	72.2	140	139	0	31	29
2014	7	26	3	22	18	0.138	0.026	0.741	0.036	0.033	0	47.7	46.9	72.7	141	139	0	30	30
2014	7	26	3	32	18	0.197	-0.039	0.741	0.036	0.033	0	46.9	46.9	72.2	139	139	0	30	30
2014	7	26	3	42	18	0.135	-0.013	0.741	0.046	0.043	0	47.7	46.4	72.2	141	138	0	30	30
2014	7	26	3	52	18	0.213	0.036	0.741	0.036	0.033	0	47.3	46.9	72.7	140	139	0	30	30
2014	7	26	4	2	18	0.164	0.052	0.741	0.033	0.03	0	45.2	45.6	72.7	136	136	0	31	30
2014	7	26	4	12	18	0.112	-0.013	0.741	0.033	0.03	0	46	46	72.7	138	137	0	31	30
2014	7	26	4	22	18	0.19	0.03	0.741	0.033	0.03	0	46	45.6	73.5	137	136	0	30	30
2014	7	26	4	32	18	0.18	0.039	0.741	0.036	0.033	0	46	46	73.1	138	137	0	31	30
2014	7	26	4	42	18	0.184	0.036	0.741	0.036	0.033	0	45.6	45.2	73.1	137	135	0	31	30
2014	7	26	4	52	18	0.167	-0.069	0.741	0.033	0.03	0	45.6	45.6	73.1	137	136	0	31	30
2014	7	26	5	2	18	0.118	0.007	0.738	0.033	0.03	0	46	45.2	73.1	138	135	0	31	30
2014	7	26	5	12	18	0.18	0.013	0.741	0.036	0.033	0	45.2	45.6	73.5	136	136	0	31	30
2014	7	26	5	22	18	0.144	-0.036	0.738	0.033	0.03	0	45.2	44.7	72.2	136	135	0	31	31
2014	7	26	5	32	18	0.18	-0.003	0.738	0.039	0.039	0	45.2	44.7	72.7	136	134	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	5	42	18	0.148	-0.026	0.738	0.033	0.03	0	45.6	44.3	73.1	137	134	0	31	31
2014	7	26	5	52	18	0.141	0.052	0.738	0.036	0.033	0	45.2	44.7	73.1	136	134	0	31	30
2014	7	26	6	2	18	0.187	-0.033	0.738	0.036	0.033	0	44.3	44.3	74	134	133	0	31	30
2014	7	26	6	12	18	0.138	-0.016	0.738	0.033	0.03	0	44.3	43.4	73.5	134	131	0	31	30
2014	7	26	6	22	18	0.177	-0.02	0.738	0.036	0.033	0	43.4	43	74.4	132	130	0	31	30
2014	7	26	6	32	18	0.203	0.016	0.738	0.033	0.03	0	43.4	43.4	74	132	131	0	31	30
2014	7	26	6	42	18	0.144	0.01	0.738	0.039	0.036	0	43.4	43.4	74	132	131	0	31	30
2014	7	26	6	52	18	0.157	0	0.738	0.036	0.033	0	43.9	43.4	73.5	133	131	0	31	30
2014	7	26	7	2	18	0.177	0	0.738	0.033	0.03	0	43.9	43.9	74	133	132	0	31	30
2014	7	26	7	12	18	0.197	0.03	0.738	0.036	0.033	0	44.3	44.7	73.5	134	134	0	31	30
2014	7	26	7	22	18	0.194	-0.066	0.738	0.039	0.036	0	44.7	44.7	72.7	135	134	0	31	30
2014	7	26	7	32	18	0.21	0.003	0.738	0.033	0.03	0	45.2	44.7	73.5	136	134	0	31	30
2014	7	26	7	42	18	0.128	0.016	0.738	0.039	0.036	0	45.2	44.3	73.5	136	133	0	31	30
2014	7	26	7	52	18	0.19	0.023	0.738	0.039	0.036	0	45.2	44.3	74	136	133	0	31	30
2014	7	26	8	2	18	0.141	-0.092	0.738	0.036	0.033	0	45.2	44.3	73.5	136	134	0	31	31
2014	7	26	8	12	18	0.197	0.007	0.738	0.036	0.033	0	44.7	44.7	73.5	135	134	0	31	30
2014	7	26	8	22	18	0.184	-0.03	0.738	0.033	0.03	0	45.6	44.7	73.5	137	134	0	31	30
2014	7	26	8	32	18	0.194	0	0.738	0.036	0.033	0	45.6	44.7	74	137	134	0	31	30
2014	7	26	8	42	18	0.2	0.016	0.738	0.033	0.03	0	44.7	44.3	74.4	135	133	0	31	30
2014	7	26	8	52	18	0.184	0.062	0.738	0.033	0.03	0	43.9	44.3	74	133	133	0	31	30
2014	7	26	9	2	18	0.194	-0.033	0.738	0.033	0.03	0	44.7	44.7	74	135	134	0	31	30
2014	7	26	9	12	18	0.144	0.016	0.738	0.039	0.039	0	45.2	44.3	74.4	136	133	0	31	30
2014	7	26	9	22	18	0.174	-0.02	0.738	0.039	0.036	0	44.7	44.7	74	135	134	0	31	30
2014	7	26	9	32	18	0.197	-0.013	0.738	0.039	0.039	0	43.4	43.9	74.8	132	132	0	31	30
2014	7	26	9	42	18	0.2	-0.023	0.738	0.033	0.03	0	44.3	43.4	74.8	133	132	0	30	31
2014	7	26	9	52	18	0.233	-0.075	0.738	0.033	0.03	0	43.9	43.9	75.3	133	132	0	31	30
2014	7	26	10	2	18	0.144	-0.007	0.738	0.036	0.033	0	43.4	43.9	75.3	132	132	0	31	30
2014	7	26	10	12	18	0.151	-0.039	0.738	0.033	0.03	0	44.3	44.3	74.8	133	133	0	30	30
2014	7	26	10	22	18	0.144	-0.085	0.738	0.046	0.043	0	43.4	43	75.3	132	131	0	31	31
2014	7	26	10	32	18	0.148	-0.016	0.735	0.033	0.03	0	44.3	43.9	75.3	134	132	0	31	30
2014	7	26	10	42	18	0.131	-0.02	0.738	0.036	0.033	0	43.9	44.3	74.8	133	133	0	31	30
2014	7	26	10	52	18	0.272	-0.036	0.735	0.033	0.03	0	45.2	43.4	74	136	132	0	31	31
2014	7	26	11	2	18	0.157	0.023	0.735	0.039	0.036	0	44.3	43.9	74	134	132	0	31	30
2014	7	26	11	12	18	0.184	-0.007	0.735	0.033	0.03	0	44.3	43	74.4	133	130	0	30	30
2014	7	26	11	22	18	0.112	-0.102	0.735	0.039	0.036	0	43	43.4	74.8	131	131	0	31	30
2014	7	26	11	32	18	0.167	-0.03	0.735	0.036	0.033	0	43.9	44.3	73.5	133	132	0	31	29
2014	7	26	11	42	18	0.161	0.016	0.735	0.036	0.033	0	45.2	45.2	73.5	135	134	0	30	29
2014	7	26	11	52	18	0.217	-0.01	0.732	0.039	0.036	0	45.2	45.6	73.5	136	135	0	31	29
2014	7	26	12	2	18	0.18	0.085	0.732	0.036	0.033	0	46.4	46	71.8	138	137	0	30	30
2014	7	26	12	12	18	0.148	0.069	0.732	0.036	0.033	0	45.6	45.6	72.2	137	136	0	31	30
2014	7	26	12	22	18	0.174	0.013	0.732	0.033	0.03	0	46	45.6	71	138	135	0	31	29
2014	7	26	12	32	18	0.167	0.007	0.728	0.036	0.033	0	46	45.2	71.8	138	135	0	31	30
2014	7	26	12	42	18	0.105	0.056	0.728	0.039	0.036	0	46	46.4	70.5	138	138	0	31	30
2014	7	26	12	52	18	0.108	0.072	0.728	0.033	0.03	0	47.3	46.4	69.7	141	138	0	31	30
2014	7	26	13	2	18	0.207	0.085	0.728	0.033	0.03	0	47.7	47.3	70.1	142	140	0	31	30
2014	7	26	13	12	18	0.197	0.056	0.728	0.039	0.039	0	47.3	47.3	69.2	141	139	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	13	22	18	0.184	0.066	0.728	0.039	0.039	0	47.7	46.9	69.2	141	139	0	30	30
2014	7	26	13	32	18	0.121	0.043	0.725	0.033	0.03	0	46.9	48.2	69.2	140	141	0	31	29
2014	7	26	13	42	18	0.18	0.016	0.722	0.036	0.033	0	47.3	48.2	67.9	141	142	0	31	30
2014	7	26	13	52	18	0.187	0.052	0.722	0.036	0.033	0	48.2	47.7	68.8	142	141	0	30	30
2014	7	26	14	2	18	0.148	0	0.719	0.033	0.03	0	48.2	48.2	69.2	142	141	0	30	29
2014	7	26	14	12	18	0.22	0.052	0.715	0.039	0.036	0	48.6	47.3	67.9	143	140	0	30	30
2014	7	26	14	22	18	0.154	0.059	0.715	0.033	0.03	0	49	47.7	68.4	144	141	0	30	30
2014	7	26	14	32	18	0.161	0.066	0.715	0.033	0.03	0	49	48.2	68.4	144	141	0	30	29
2014	7	26	14	42	18	0.213	0.052	0.712	0.033	0.03	0	48.6	47.3	69.2	143	140	0	30	30
2014	7	26	14	52	18	0.2	0.138	0.712	0.033	0.03	0	48.6	48.2	69.7	143	141	0	30	29
2014	7	26	15	2	18	0.154	-0.072	0.712	0.039	0.036	0	49.5	48.2	68.8	145	142	0	30	30
2014	7	26	15	12	18	0.115	0.056	0.712	0.036	0.033	0	49.5	49	69.2	145	143	0	30	29
2014	7	26	15	22	18	0.223	0.105	0.709	0.036	0.033	0	48.2	47.3	70.5	143	140	0	31	30
2014	7	26	15	32	18	0.279	0.049	0.709	0.039	0.036	0	49	49	71	144	143	0	30	29
2014	7	26	15	42	18	0.21	0	0.709	0.03	0.03	0	49	49	70.5	144	143	0	30	29
2014	7	26	15	52	18	0.213	0.102	0.709	0.033	0.03	0	49.9	49	70.1	145	143	0	29	29
2014	7	26	16	2	18	0.141	0.079	0.709	0.039	0.036	0	48.2	48.2	70.5	143	141	0	31	29
2014	7	26	16	12	18	0.19	0.148	0.709	0.036	0.033	0	48.2	48.6	69.2	143	142	0	31	29
2014	7	26	16	22	18	0.194	0.069	0.709	0.036	0.033	0	48.6	47.7	71.4	143	140	0	30	29
2014	7	26	16	32	18	0.141	0.062	0.709	0.03	0.026	0	49	48.6	71	144	142	0	30	29
2014	7	26	16	42	18	0.2	0.01	0.709	0.033	0.03	0	49.5	48.2	69.2	145	141	0	30	29
2014	7	26	16	52	18	0.135	0.128	0.709	0.039	0.039	0	49	47.7	70.5	144	140	0	30	29
2014	7	26	17	2	18	0.18	0.115	0.709	0.036	0.033	0	48.6	47.3	71	143	140	0	30	30
2014	7	26	17	12	18	0.292	0.118	0.709	0.033	0.03	0	49.5	47.3	70.5	145	139	0	30	29
2014	7	26	17	22	18	0.18	0.069	0.709	0.033	0.03	0	47.7	47.7	70.1	141	139	0	30	28
2014	7	26	17	32	18	0.164	0.095	0.709	0.039	0.036	0	47.7	46.9	71.4	141	139	0	30	30
2014	7	26	17	42	18	0.226	0.095	0.709	0.036	0.033	0	47.7	46.9	71.8	141	138	0	30	29
2014	7	26	17	52	18	0.203	0.03	0.709	0.033	0.03	0	46.4	46	71.8	138	136	0	30	29
2014	7	26	18	2	18	0.21	0.095	0.709	0.039	0.036	0	46.4	46	73.5	138	136	0	30	29
2014	7	26	18	12	18	0.141	0.036	0.709	0.036	0.033	0	45.6	45.2	73.1	136	134	0	30	29
2014	7	26	18	22	18	0.249	0.128	0.705	0.03	0.026	0	45.2	44.7	72.7	135	134	0	30	30
2014	7	26	18	32	18	0.141	0.085	0.705	0.033	0.03	0	47.7	45.6	72.2	140	136	0	29	30
2014	7	26	18	42	18	0.135	0.039	0.705	0.033	0.03	0	46	45.6	72.7	137	135	0	30	29
2014	7	26	18	52	18	0.203	0.095	0.705	0.039	0.036	0	46.9	45.6	71.8	139	135	0	30	29
2014	7	26	19	2	18	0.167	0.056	0.705	0.039	0.039	0	45.6	44.3	73.1	136	133	0	30	30
2014	7	26	19	12	18	0.233	-0.016	0.709	0.036	0.033	0	44.7	43.9	73.5	134	131	0	30	29
2014	7	26	19	22	18	0.171	0.066	0.709	0.036	0.033	0	45.2	44.3	73.1	135	132	0	30	29
2014	7	26	19	32	18	0.161	0.128	0.705	0.039	0.036	0	44.3	44.3	72.7	133	132	0	30	29
2014	7	26	19	42	18	0.203	-0.007	0.705	0.043	0.039	0	48.2	45.2	71.8	141	135	0	29	30
2014	7	26	19	52	18	0.167	-0.01	0.705	0.039	0.039	0	47.7	46.9	71.4	141	138	0	30	29
2014	7	26	20	2	18	0.135	0	0.705	0.043	0.043	0	45.6	44.3	72.7	135	132	0	29	29
2014	7	26	20	12	18	0.135	0.023	0.709	0.039	0.039	0	44.3	43.9	73.1	133	131	0	30	29
2014	7	26	20	22	18	0.194	-0.03	0.709	0.033	0.03	0	43.9	43.4	74	133	130	0	31	29
2014	7	26	20	32	18	0.171	0.016	0.705	0.033	0.03	0	44.3	44.3	72.7	133	132	0	30	29
2014	7	26	20	42	18	0.19	-0.049	0.705	0.036	0.033	0	45.2	43.9	72.7	135	132	0	30	30
2014	7	26	20	52	18	0.174	0.016	0.705	0.039	0.039	0	48.2	46.4	71	141	137	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	21	2	18	0.151	0.016	0.705	0.039	0.036	0	45.6	45.2	72.7	136	134	0	30	29
2014	7	26	21	12	18	0.148	-0.023	0.709	0.036	0.033	0	46	45.6	71.8	137	135	0	30	29
2014	7	26	21	22	18	0.177	0.01	0.709	0.039	0.036	0	45.6	44.7	72.2	137	133	0	31	29
2014	7	26	21	32	18	0.095	-0.02	0.709	0.033	0.03	0	46.4	45.6	72.2	138	135	0	30	29
2014	7	26	21	42	18	0.174	0.069	0.709	0.036	0.033	0	46	45.2	71.8	137	135	0	30	30
2014	7	26	21	52	18	0.177	0.033	0.709	0.033	0.033	0	46.4	45.6	72.7	138	135	0	30	29
2014	7	26	22	2	18	0.085	0.03	0.709	0.036	0.033	0	45.6	45.2	71.8	137	134	0	31	29
2014	7	26	22	12	18	0.138	-0.01	0.709	0.036	0.033	0	47.3	47.3	71.4	140	139	0	30	29
2014	7	26	22	22	18	0.148	0.03	0.709	0.033	0.03	0	49.9	49	70.1	146	143	0	30	29
2014	7	26	22	32	18	0.207	0	0.709	0.033	0.03	0	48.6	46.4	70.1	143	138	0	30	30
2014	7	26	22	42	18	0.154	0.033	0.709	0.033	0.03	0	47.7	47.3	70.5	141	139	0	30	29
2014	7	26	22	52	18	0.141	-0.069	0.709	0.033	0.03	0	48.2	47.3	69.2	142	139	0	30	29
2014	7	26	23	2	18	0.112	-0.049	0.712	0.036	0.033	0	48.2	47.7	69.7	142	140	0	30	29
2014	7	26	23	12	18	0.19	0	0.712	0.036	0.033	0	46.9	46.9	69.7	139	138	0	30	29
2014	7	26	23	22	18	0.187	0	0.712	0.033	0.03	0	46	44.7	70.5	137	134	0	30	30
2014	7	26	23	32	18	0.128	-0.02	0.712	0.039	0.036	0	46.9	46	70.1	139	137	0	30	30
2014	7	26	23	42	18	0.161	0.026	0.712	0.039	0.039	0	45.6	45.2	70.1	137	135	0	31	30
2014	7	26	23	52	18	0.187	-0.003	0.712	0.039	0.039	0	45.6	45.2	70.5	137	135	0	31	30
2014	7	27	0	2	18	0.213	0.023	0.715	0.033	0.03	0	46.4	46	69.7	138	136	0	30	29
2014	7	27	0	12	18	0.125	0.023	0.715	0.036	0.033	0	46.4	45.6	69.7	138	135	0	30	29
2014	7	27	0	22	18	0.161	-0.016	0.715	0.036	0.033	0	46.4	45.6	70.5	138	136	0	30	30
2014	7	27	0	32	18	0.098	0.003	0.719	0.03	0.03	0	45.6	45.6	69.2	137	135	0	31	29
2014	7	27	0	42	18	0.167	0.033	0.719	0.036	0.033	0	45.6	45.6	70.1	136	135	0	30	29
2014	7	27	0	52	18	0.184	0.013	0.722	0.033	0.03	0	45.2	45.6	70.5	136	135	0	31	29
2014	7	27	1	2	18	0.138	0.056	0.722	0.033	0.03	0	45.6	46	70.1	136	137	0	30	30
2014	7	27	1	12	18	0.226	0	0.725	0.033	0.03	0	46	46	69.2	137	136	0	30	29
2014	7	27	1	22	18	0.157	-0.036	0.722	0.036	0.033	0	45.6	44.7	69.7	136	134	0	30	30
2014	7	27	1	32	18	0.174	-0.03	0.722	0.036	0.033	0	44.7	44.7	70.5	135	134	0	31	30
2014	7	27	1	42	18	0.184	-0.056	0.725	0.036	0.033	0	46.4	46	69.7	139	137	0	31	30
2014	7	27	1	52	18	0.148	-0.069	0.725	0.036	0.033	0	45.6	46.4	70.1	137	137	0	31	29
2014	7	27	2	2	18	0.161	0	0.725	0.033	0.03	0	46.9	46.4	69.2	140	138	0	31	30
2014	7	27	2	12	18	0.174	-0.007	0.725	0.033	0.03	0	46.9	46.9	69.7	140	139	0	31	30
2014	7	27	2	22	18	0.184	-0.023	0.728	0.036	0.033	0	47.3	46.9	70.5	140	139	0	30	30
2014	7	27	2	32	18	0.157	-0.062	0.728	0.036	0.033	0	47.3	47.3	69.7	141	140	0	31	30
2014	7	27	2	42	18	0.194	-0.036	0.728	0.036	0.033	0	46.4	45.6	70.5	138	136	0	30	30
2014	7	27	2	52	18	0.184	-0.02	0.728	0.033	0.033	0	46.9	46.9	71.4	140	139	0	31	30
2014	7	27	3	2	18	0.164	0.052	0.728	0.036	0.033	0	45.6	45.6	70.5	137	136	0	31	30
2014	7	27	3	12	18	0.144	-0.026	0.728	0.033	0.03	0	46	46.4	71	138	138	0	31	30
2014	7	27	3	22	18	0.082	0.026	0.732	0.033	0.03	0	45.6	45.2	71.4	136	135	0	30	30
2014	7	27	3	32	18	0.177	-0.043	0.732	0.033	0.03	0	46.4	45.2	72.2	138	135	0	30	30
2014	7	27	3	42	18	0.171	-0.036	0.732	0.036	0.033	0	46	44.7	72.7	138	134	0	31	30
2014	7	27	3	52	18	0.102	0.013	0.732	0.039	0.036	0	45.6	44.7	73.1	136	134	0	30	30
2014	7	27	4	2	18	0.23	-0.095	0.732	0.036	0.033	0	45.2	45.2	72.2	136	135	0	31	30
2014	7	27	4	12	18	0.112	0.046	0.732	0.039	0.039	0	46	44.3	72.2	138	133	0	31	30
2014	7	27	4	22	18	0.233	0.01	0.732	0.033	0.03	0	46	45.6	72.7	138	135	0	31	29
2014	7	27	4	32	18	0.18	0.056	0.732	0.033	0.03	0	45.6	45.2	72.2	136	135	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	4	42	18	0.174	0.016	0.732	0.036	0.033	0	46	45.6	73.1	138	136	0	31	30
2014	7	27	4	52	18	0.141	-0.013	0.735	0.039	0.036	0	45.2	45.2	73.5	136	135	0	31	30
2014	7	27	5	2	18	0.226	0.059	0.735	0.033	0.03	0	45.6	45.2	73.1	136	134	0	30	29
2014	7	27	5	12	18	0.144	0.016	0.735	0.036	0.033	0	46	44.7	74	138	134	0	31	30
2014	7	27	5	22	18	0.135	-0.03	0.735	0.036	0.033	0	45.6	45.2	73.1	137	135	0	31	30
2014	7	27	5	32	18	0.148	0	0.735	0.036	0.033	0	45.6	44.7	73.5	137	134	0	31	30
2014	7	27	5	42	18	0.141	-0.013	0.732	0.043	0.039	0	45.2	44.7	73.1	135	134	0	30	30
2014	7	27	5	52	18	0.154	-0.082	0.735	0.043	0.039	0	44.7	44.3	73.1	135	132	0	31	29
2014	7	27	6	2	18	0.151	0.03	0.735	0.036	0.033	0	44.3	43.9	74.4	134	132	0	31	30
2014	7	27	6	12	18	0.21	0.033	0.735	0.033	0.03	0	43.9	43.9	73.5	133	132	0	31	30
2014	7	27	6	22	18	0.161	-0.013	0.735	0.036	0.033	0	43.9	43.4	73.5	132	131	0	30	30
2014	7	27	6	32	18	0.184	0.013	0.735	0.036	0.033	0	43.9	43.9	73.5	133	132	0	31	30
2014	7	27	6	42	18	0.161	0.003	0.735	0.036	0.033	0	43.4	43.9	74	132	132	0	31	30
2014	7	27	6	52	18	0.092	-0.026	0.735	0.036	0.033	0	44.3	43.9	74.4	134	132	0	31	30
2014	7	27	7	2	18	0.105	-0.003	0.735	0.033	0.03	0	44.3	44.3	74	134	133	0	31	30
2014	7	27	7	12	18	0.138	-0.056	0.735	0.036	0.033	0	44.3	43.4	73.5	133	131	0	30	30
2014	7	27	7	22	18	0.121	0.049	0.732	0.033	0.03	0	44.3	43.4	74.4	134	132	0	31	31
2014	7	27	7	32	18	0.18	0.01	0.735	0.039	0.036	0	43.9	44.3	73.1	133	132	0	31	29
2014	7	27	7	42	18	0.23	-0.039	0.735	0.036	0.033	0	44.3	43.4	74	134	132	0	31	31
2014	7	27	7	52	18	0.144	0	0.735	0.039	0.036	0	43.4	43	74	132	131	0	31	31
2014	7	27	8	2	18	0.125	0	0.732	0.033	0.03	0	45.2	44.3	73.5	135	133	0	30	30
2014	7	27	8	12	18	0.207	0	0.732	0.033	0.033	0	45.6	44.7	73.1	138	134	0	32	30
2014	7	27	8	22	18	0.194	-0.01	0.732	0.033	0.03	0	44.3	44.3	74	134	133	0	31	30
2014	7	27	8	32	18	0.151	0.072	0.732	0.033	0.03	0	44.3	43.9	73.5	134	133	0	31	31
2014	7	27	8	42	18	0.19	0.056	0.732	0.033	0.03	0	45.2	43.4	74.4	135	132	0	30	31
2014	7	27	8	52	18	0.144	0	0.732	0.036	0.033	0	43.9	43.4	73.1	133	131	0	31	30
2014	7	27	9	2	18	0.118	-0.03	0.732	0.033	0.03	0	44.3	44.7	72.7	134	134	0	31	30
2014	7	27	9	12	18	0.2	0	0.732	0.039	0.036	0	44.7	43.9	72.7	135	132	0	31	30
2014	7	27	9	22	18	0.157	0.052	0.732	0.033	0.03	0	45.6	44.3	72.7	136	133	0	30	30
2014	7	27	9	32	18	0.115	0.01	0.732	0.036	0.033	0	43.9	43.9	72.7	133	132	0	31	30
2014	7	27	9	42	18	0.161	0	0.732	0.033	0.03	0	42.6	43.4	73.1	130	131	0	31	30
2014	7	27	9	52	18	0.151	0.069	0.732	0.036	0.033	0	44.3	43.4	73.1	134	131	0	31	30
2014	7	27	10	2	18	0.236	0	0.728	0.033	0.03	0	43.9	43.4	72.7	133	132	0	31	31
2014	7	27	10	12	18	0.167	0.052	0.728	0.033	0.03	0	44.3	44.3	73.5	134	133	0	31	30
2014	7	27	10	22	18	0.157	-0.03	0.728	0.033	0.03	0	43.9	44.3	71.8	132	133	0	30	30
2014	7	27	10	32	18	0.184	0.003	0.728	0.043	0.043	0	43.4	44.3	71.8	132	133	0	31	30
2014	7	27	10	42	18	0.207	-0.013	0.728	0.036	0.033	0	43.9	43.9	71.8	133	132	0	31	30
2014	7	27	10	52	18	0.102	-0.02	0.728	0.043	0.039	0	43.9	44.3	71.4	133	133	0	31	30
2014	7	27	11	2	18	0.167	0.056	0.725	0.033	0.033	0	43.9	43.9	70.5	133	132	0	31	30
2014	7	27	11	12	18	0.21	0.01	0.725	0.036	0.033	0	44.3	45.2	70.5	134	135	0	31	30
2014	7	27	11	22	18	0.167	-0.01	0.725	0.033	0.03	0	45.6	44.3	70.5	136	133	0	30	30
2014	7	27	11	32	18	0.223	0.013	0.722	0.033	0.03	0	45.2	46	69.7	135	136	0	30	29
2014	7	27	11	42	18	0.184	-0.02	0.722	0.036	0.033	0	44.7	45.6	69.2	135	136	0	31	30
2014	7	27	11	52	18	0.167	0.092	0.719	0.03	0.03	0	45.2	45.6	69.7	136	136	0	31	30
2014	7	27	12	2	18	0.18	0.023	0.715	0.033	0.03	0	45.6	44.7	70.1	136	134	0	30	30
2014	7	27	12	12	18	0.125	-0.03	0.712	0.036	0.033	0	45.2	46.9	71	136	138	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	12	22	18	0.144	0.072	0.712	0.033	0.03	0	46	46.4	70.1	137	138	0	30	30
2014	7	27	12	32	18	0.151	-0.03	0.712	0.033	0.03	0	46	46	69.7	137	137	0	30	30
2014	7	27	12	42	18	0.236	0	0.712	0.039	0.039	0	46.4	46.4	70.1	139	138	0	31	30
2014	7	27	12	52	18	0.167	0	0.712	0.033	0.03	0	46.9	47.3	71	140	140	0	31	30
2014	7	27	13	2	18	0.174	-0.036	0.709	0.039	0.036	0	46.9	48.6	70.1	141	142	0	32	29
2014	7	27	13	12	18	0.217	0.052	0.709	0.036	0.033	0	47.3	46.9	70.5	140	138	0	30	29
2014	7	27	13	22	18	0.21	0.049	0.709	0.039	0.036	0	48.6	47.7	70.5	143	141	0	30	30
2014	7	27	13	32	18	0.226	0.049	0.709	0.033	0.03	0	49	48.6	69.7	144	143	0	30	30
2014	7	27	13	42	18	0.187	0.016	0.709	0.033	0.03	0	47.7	47.7	71	141	141	0	30	30
2014	7	27	13	52	18	0.226	0.062	0.709	0.036	0.033	0	48.6	48.2	70.1	143	141	0	30	29
2014	7	27	14	2	18	0.187	0.013	0.709	0.033	0.03	0	48.2	48.2	70.1	143	141	0	31	29
2014	7	27	14	12	18	0.249	0.046	0.709	0.033	0.03	0	49.5	48.6	70.1	145	142	0	30	29
2014	7	27	14	22	18	0.161	0.115	0.709	0.033	0.03	0	49	48.2	71.4	144	141	0	30	29
2014	7	27	14	32	18	0.164	0.007	0.705	0.033	0.03	0	49.5	49	71	144	143	0	29	29
2014	7	27	14	42	18	0.19	0.095	0.705	0.033	0.03	0	49	48.2	71.4	144	141	0	30	29
2014	7	27	14	52	18	0.157	0.046	0.705	0.033	0.03	0	49	48.6	71.4	143	142	0	29	29
2014	7	27	15	2	18	0.223	0.059	0.705	0.039	0.036	0	48.2	47.7	71.8	142	140	0	30	29
2014	7	27	15	12	18	0.177	0.075	0.705	0.036	0.033	0	48.6	48.6	71.8	143	142	0	30	29
2014	7	27	15	22	18	0.187	0.075	0.705	0.033	0.03	0	48.6	48.6	71.4	144	143	0	31	30
2014	7	27	15	32	18	0.197	0.102	0.705	0.036	0.033	0	49.5	49.5	71.8	145	144	0	30	29
2014	7	27	15	42	18	0.22	0.079	0.705	0.036	0.033	0	49	48.6	72.2	144	142	0	30	29
2014	7	27	15	52	18	0.217	0.082	0.705	0.033	0.03	0	48.6	48.6	71.8	143	142	0	30	29
2014	7	27	16	2	18	0.174	0.069	0.705	0.033	0.03	0	49.5	49.9	71.8	145	145	0	30	29
2014	7	27	16	12	18	0.194	0.046	0.705	0.033	0.03	0	48.6	49	72.2	144	143	0	31	29
2014	7	27	16	22	18	0.203	0	0.705	0.039	0.036	0	48.2	49	70.5	142	143	0	30	29
2014	7	27	16	32	18	0.197	0.066	0.705	0.046	0.043	0	50.3	50.3	70.1	147	145	0	30	28
2014	7	27	16	42	18	0.184	0	0.705	0.039	0.036	0	49.9	49	71	146	144	0	30	30
2014	7	27	16	52	18	0.115	0.072	0.705	0.033	0.03	0	49.9	50.3	70.5	146	146	0	30	29
2014	7	27	17	2	18	0.184	0.043	0.702	0.03	0.03	0	50.7	49.9	72.2	148	145	0	30	29
2014	7	27	17	12	18	0.256	0.059	0.702	0.036	0.033	0	49	47.7	70.5	144	140	0	30	29
2014	7	27	17	22	18	0.167	0.036	0.702	0.039	0.036	0	45.6	45.2	72.7	136	134	0	30	29
2014	7	27	17	32	18	0.115	0.072	0.702	0.036	0.033	0	47.7	46.9	72.7	141	138	0	30	29
2014	7	27	17	42	18	0.138	0.049	0.702	0.033	0.03	0	46	46	72.2	137	136	0	30	29
2014	7	27	17	52	18	0.171	0.046	0.702	0.036	0.033	0	44.7	44.3	73.5	134	132	0	30	29
2014	7	27	18	2	18	0.157	0.157	0.702	0.033	0.03	0	46	43.9	73.1	136	131	0	29	29
2014	7	27	18	12	18	0.174	0.072	0.702	0.033	0.03	0	44.7	43.9	73.5	134	131	0	30	29
2014	7	27	18	22	18	0.105	0.098	0.702	0.036	0.033	0	44.3	43.4	74	133	130	0	30	29
2014	7	27	18	32	18	0.197	0.036	0.702	0.039	0.036	0	43.9	43.4	73.5	132	130	0	30	29
2014	7	27	18	42	18	0.125	0.085	0.702	0.036	0.033	0	43.9	43	73.5	132	129	0	30	29
2014	7	27	18	52	18	0.125	0	0.702	0.036	0.033	0	43.9	42.6	74	132	128	0	30	29
2014	7	27	19	2	18	0.171	0.095	0.702	0.039	0.036	0	44.3	42.6	72.7	132	128	0	29	29
2014	7	27	19	12	18	0.115	0.089	0.702	0.033	0.03	0	46	44.7	72.2	137	133	0	30	29
2014	7	27	19	22	18	0.167	0.089	0.702	0.039	0.036	0	44.7	43.4	72.7	134	130	0	30	29
2014	7	27	19	32	18	0.19	0.121	0.702	0.039	0.036	0	44.7	43.9	72.7	134	131	0	30	29
2014	7	27	19	42	18	0.115	0.052	0.702	0.036	0.033	0	44.3	43.9	72.2	133	131	0	30	29
2014	7	27	19	52	18	0.167	0.082	0.702	0.036	0.033	0	44.3	43	73.5	134	129	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	20	2	18	0.233	0.154	0.702	0.036	0.033	0	43	42.6	73.1	130	128	0	30	29
2014	7	27	20	12	18	0.157	0.026	0.702	0.039	0.036	0	43.9	43.4	73.1	131	130	0	29	29
2014	7	27	20	22	18	0.187	0.056	0.702	0.036	0.033	0	46	45.2	71.8	137	134	0	30	29
2014	7	27	20	32	18	0.21	0.013	0.699	0.033	0.03	0	51.6	51.6	67.1	150	149	0	30	29
2014	7	27	20	42	18	0.253	0.253	0.692	0.033	0.03	0	63.2	62.4	56.8	177	174	0	30	29
2014	7	27	20	52	18	0.184	0.223	0.702	0.036	0.033	0	61.1	59.3	56.8	172	167	0	30	29
2014	7	27	21	2	18	0.197	0.236	0.699	0.033	0.03	0	66.7	66.2	50.7	185	182	0	30	28
2014	7	27	21	12	18	0.154	0.308	0.712	0.036	0.033	0	64.9	62.4	50.3	181	174	0	30	29
2014	7	27	21	22	18	0.167	0.256	0.722	0.039	0.039	0	65.4	62.4	48.6	182	174	0	30	29
2014	7	27	21	32	18	0.184	0.21	0.728	0.043	0.039	0	64.1	61.9	49.9	179	173	0	30	29
2014	7	27	21	42	18	0.223	0.194	0.732	0.039	0.036	0	63.6	61.5	51.6	178	172	0	30	29
2014	7	27	21	52	18	0.197	0.233	0.735	0.036	0.033	0	64.9	63.2	51.2	181	176	0	30	29
2014	7	27	22	2	18	0.213	0.174	0.738	0.039	0.036	0	65.4	62.8	50.7	182	175	0	30	29
2014	7	27	22	12	18	0.177	0.24	0.735	0.039	0.036	0	64.5	62.4	52	180	174	0	30	29
2014	7	27	22	22	18	0.187	0.23	0.741	0.046	0.043	0	64.9	62.4	51.2	181	175	0	30	30
2014	7	27	22	32	18	0.223	0.233	0.741	0.039	0.039	0	65.4	62.8	51.2	182	175	0	30	29
2014	7	27	22	42	18	0.177	0.285	0.741	0.036	0.033	0	64.9	63.2	51.6	181	175	0	30	28
2014	7	27	22	52	18	0.23	0.236	0.741	0.039	0.039	0	65.4	62.4	52	182	174	0	30	29
2014	7	27	23	2	18	0.187	0.269	0.738	0.046	0.043	0	66.7	64.5	48.6	185	179	0	30	29
2014	7	27	23	12	18	0.154	0.328	0.741	0.049	0.046	0	65.8	63.2	48.6	183	176	0	30	29
2014	7	27	23	22	18	0.279	0.312	0.741	0.049	0.046	0	64.9	62.4	51.2	181	174	0	30	29
2014	7	27	23	32	18	0.24	0.351	0.741	0.036	0.033	0	64.1	61.9	51.6	179	173	0	30	29
2014	7	27	23	42	18	0.226	0.266	0.741	0.043	0.039	0	63.6	61.5	51.6	178	172	0	30	29
2014	7	27	23	52	18	0.243	0.269	0.741	0.046	0.043	0	63.6	61.1	52.9	178	171	0	30	29
2014	7	28	0	2	18	0.18	0.325	0.741	0.033	0.03	0	63.2	60.6	53.3	177	171	0	30	30
2014	7	28	0	12	18	0.187	0.302	0.741	0.036	0.033	0	62.4	60.6	53.8	176	171	0	31	30
2014	7	28	0	22	18	0.197	0.282	0.741	0.033	0.03	0	63.2	61.1	53.8	177	171	0	30	29
2014	7	28	0	32	18	0.217	0.312	0.741	0.049	0.046	0	63.2	60.6	52.5	177	171	0	30	30
2014	7	28	0	42	18	0.22	0.315	0.741	0.039	0.039	0	63.2	61.1	53.3	177	171	0	30	29
2014	7	28	0	52	18	0.144	0.335	0.741	0.036	0.033	0	62.8	61.1	54.2	176	171	0	30	29
2014	7	28	1	2	18	0.177	0.344	0.741	0.043	0.039	0	62.8	60.6	53.3	176	171	0	30	30
2014	7	28	1	12	18	0.203	0.364	0.741	0.043	0.039	0	62.8	60.6	53.3	176	170	0	30	29
2014	7	28	1	22	18	0.174	0.381	0.741	0.043	0.039	0	62.4	59.8	53.8	175	169	0	30	30
2014	7	28	1	32	18	0.177	0.377	0.738	0.043	0.039	0	61.9	60.2	53.8	175	169	0	31	29
2014	7	28	1	42	18	0.256	0.42	0.741	0.043	0.039	0	61.1	59.3	54.6	173	168	0	31	30
2014	7	28	1	52	18	0.19	0.387	0.741	0.046	0.043	0	61.5	59.8	55.5	173	168	0	30	29
2014	7	28	2	2	18	0.226	0.351	0.741	0.036	0.033	0	60.6	59.3	55	172	167	0	31	29
2014	7	28	2	12	18	0.203	0.322	0.741	0.039	0.036	0	60.2	58.5	56.3	171	166	0	31	30
2014	7	28	2	22	18	0.18	0.325	0.741	0.043	0.039	0	60.2	58	57.2	170	165	0	30	30
2014	7	28	2	32	18	0.269	0.302	0.741	0.049	0.046	0	59.8	57.6	57.6	169	164	0	30	30
2014	7	28	2	42	18	0.184	0.279	0.741	0.039	0.039	0	59.3	58	58	169	164	0	31	29
2014	7	28	2	52	18	0.243	0.269	0.738	0.039	0.039	0	58.5	57.2	58.5	167	163	0	31	30
2014	7	28	3	2	18	0.249	0.305	0.741	0.039	0.036	0	58.9	56.8	58.5	167	162	0	30	30
2014	7	28	3	12	18	0.164	0.279	0.741	0.036	0.033	0	58	56.8	59.8	165	162	0	30	30
2014	7	28	3	22	18	0.295	0.295	0.741	0.039	0.036	0	58	56.3	60.6	165	160	0	30	29
2014	7	28	3	32	18	0.253	0.331	0.741	0.033	0.03	0	57.6	55.9	61.5	164	160	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	3	42	18	0.276	0.312	0.738	0.033	0.03	0	56.8	55.5	61.9	163	158	0	31	29
2014	7	28	3	52	18	0.253	0.262	0.738	0.039	0.036	0	56.3	54.6	62.4	162	157	0	31	30
2014	7	28	4	2	18	0.141	0.259	0.738	0.036	0.033	0	56.3	54.2	63.2	161	156	0	30	30
2014	7	28	4	12	18	0.249	0.21	0.738	0.039	0.039	0	55.5	53.8	63.2	159	155	0	30	30
2014	7	28	4	22	18	0.207	0.197	0.738	0.049	0.046	0	54.6	54.2	64.9	158	155	0	31	29
2014	7	28	4	32	18	0.279	0.19	0.738	0.036	0.033	0	55	53.3	64.9	158	154	0	30	30
2014	7	28	4	42	18	0.148	0.197	0.738	0.046	0.043	0	53.8	52.5	65.8	156	152	0	31	30
2014	7	28	4	52	18	0.19	0.22	0.738	0.036	0.033	0	53.8	52.9	65.8	155	152	0	30	29
2014	7	28	5	2	18	0.2	0.108	0.738	0.039	0.036	0	53.8	52	65.8	156	151	0	31	30
2014	7	28	5	12	18	0.148	0.203	0.738	0.036	0.033	0	53.3	52	67.5	154	150	0	30	29
2014	7	28	5	22	18	0.131	0.138	0.738	0.033	0.03	0	52	51.6	67.9	152	149	0	31	29
2014	7	28	5	32	18	0.161	0.131	0.738	0.039	0.039	0	52	50.7	67.5	151	148	0	30	30
2014	7	28	5	42	18	0.102	0.184	0.738	0.036	0.033	0	52	51.2	68.4	152	148	0	31	29
2014	7	28	5	52	18	0.164	0.092	0.738	0.043	0.039	0	51.6	50.7	69.2	151	148	0	31	30
2014	7	28	6	2	18	0.19	0.125	0.738	0.033	0.03	0	51.6	49.9	69.7	150	146	0	30	30
2014	7	28	6	12	18	0.253	0.128	0.738	0.033	0.03	0	50.7	49.9	70.1	149	145	0	31	29
2014	7	28	6	22	18	0.105	0.069	0.738	0.033	0.03	0	49.9	49	70.1	147	144	0	31	30
2014	7	28	6	32	18	0.177	0.075	0.738	0.033	0.03	0	50.3	50.3	71.4	147	146	0	30	29
2014	7	28	6	42	18	0.141	0.141	0.738	0.043	0.043	0	49.9	49	70.5	147	144	0	31	30
2014	7	28	6	52	18	0.167	0.105	0.735	0.033	0.03	0	49.5	49	71.4	146	144	0	31	30
2014	7	28	7	2	18	0.115	0.148	0.735	0.036	0.033	0	49.5	49	71.4	146	143	0	31	29
2014	7	28	7	12	18	0.151	0.118	0.735	0.039	0.036	0	49.9	49.5	70.1	147	144	0	31	29
2014	7	28	7	22	18	0.092	0.075	0.735	0.033	0.03	0	49.9	49	70.5	147	143	0	31	29
2014	7	28	7	32	18	0.174	0.112	0.735	0.039	0.036	0	49	47.7	71.4	145	141	0	31	30
2014	7	28	7	42	18	0.187	0.072	0.735	0.036	0.033	0	49	47.7	71	144	142	0	30	31
2014	7	28	7	52	18	0.128	0.085	0.735	0.03	0.03	0	50.3	49.9	71.4	147	145	0	30	29
2014	7	28	8	2	18	0.233	0.092	0.735	0.036	0.033	0	50.3	49.9	70.5	147	146	0	30	30
2014	7	28	8	12	18	0.128	0.105	0.735	0.033	0.03	0	49	48.6	70.5	144	142	0	30	29
2014	7	28	8	22	18	0.2	0.125	0.732	0.033	0.03	0	49.5	48.2	70.1	145	142	0	30	30
2014	7	28	8	32	18	0.194	0.105	0.732	0.036	0.033	0	49.5	48.2	71	145	142	0	30	30
2014	7	28	8	42	18	0.213	0.052	0.732	0.039	0.036	0	49.5	48.6	70.1	145	143	0	30	30
2014	7	28	8	52	18	0.18	0.056	0.732	0.039	0.036	0	48.6	48.6	70.1	144	143	0	31	30
2014	7	28	9	2	18	0.144	0.072	0.732	0.036	0.033	0	47.7	48.2	70.1	143	142	0	32	30
2014	7	28	9	12	18	0.207	0.016	0.732	0.039	0.036	0	48.6	47.3	69.2	143	141	0	30	31
2014	7	28	9	22	18	0.167	0.128	0.728	0.039	0.036	0	49	48.2	67.9	144	142	0	30	30
2014	7	28	9	32	18	0.246	0.039	0.728	0.03	0.03	0	49	48.2	69.7	144	142	0	30	30
2014	7	28	9	42	18	0.213	0.108	0.728	0.036	0.033	0	49	48.6	68.4	144	143	0	30	30
2014	7	28	9	52	18	0.157	0.062	0.725	0.033	0.03	0	48.2	48.6	69.2	143	143	0	31	30
2014	7	28	10	2	18	0.177	0.138	0.725	0.033	0.03	0	49	49.5	67.9	145	145	0	31	30
2014	7	28	10	12	18	0.148	0.056	0.725	0.036	0.033	0	49	48.6	67.9	145	143	0	31	30
2014	7	28	10	22	18	0.19	0.079	0.725	0.033	0.03	0	49	48.6	68.4	144	143	0	30	30
2014	7	28	10	32	18	0.233	0.02	0.722	0.033	0.03	0	49.9	49	67.9	146	143	0	30	29
2014	7	28	10	42	18	0.184	0.049	0.722	0.033	0.03	0	49	49.5	67.5	145	144	0	31	29
2014	7	28	10	52	18	0.259	0.023	0.722	0.036	0.033	0	48.6	48.6	67.1	143	143	0	30	30
2014	7	28	11	2	18	0.203	0.102	0.719	0.03	0.03	0	49	49.5	67.5	144	145	0	30	30
2014	7	28	11	12	18	0.2	0.121	0.719	0.039	0.036	0	48.2	47.7	67.9	142	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	11	22	18	0.187	0.154	0.715	0.036	0.033	0	48.6	47.7	67.9	143	141	0	30	30
2014	7	28	11	32	18	0.21	0.098	0.712	0.039	0.036	0	48.6	48.2	67.9	143	141	0	30	29
2014	7	28	11	42	18	0.151	0.102	0.712	0.033	0.03	0	49	48.6	67.9	145	142	0	31	29
2014	7	28	11	52	18	0.171	0.036	0.712	0.033	0.033	0	49	48.6	68.8	144	143	0	30	30
2014	7	28	12	2	18	0.148	0.069	0.712	0.033	0.03	0	48.6	48.2	67.5	143	141	0	30	29
2014	7	28	12	12	18	0.112	0.069	0.712	0.039	0.036	0	48.6	48.2	67.5	143	142	0	30	30
2014	7	28	12	22	18	0.167	0.082	0.712	0.036	0.033	0	48.6	47.3	69.2	143	139	0	30	29
2014	7	28	12	32	18	0.223	0.089	0.712	0.036	0.033	0	48.6	48.2	68.8	143	142	0	30	30
2014	7	28	12	42	18	0.197	0.118	0.712	0.033	0.03	0	49.5	48.2	67.5	145	142	0	30	30
2014	7	28	12	52	18	0.21	0.052	0.709	0.033	0.03	0	49	49.9	69.2	145	145	0	31	29
2014	7	28	13	2	18	0.131	0.131	0.709	0.036	0.033	0	49.5	49	69.2	145	144	0	30	30
2014	7	28	13	12	18	0.157	0.135	0.709	0.039	0.036	0	48.6	49	69.7	143	143	0	30	29
2014	7	28	13	22	18	0.174	0.075	0.709	0.03	0.03	0	49.9	50.3	70.1	146	147	0	30	30
2014	7	28	13	32	18	0.115	0.151	0.709	0.033	0.03	0	49	49.9	69.7	144	145	0	30	29
2014	7	28	13	42	18	0.207	-0.003	0.709	0.033	0.03	0	49	48.6	69.7	144	143	0	30	30
2014	7	28	13	52	18	0.131	0.082	0.709	0.026	0.023	0	50.7	51.6	69.2	148	149	0	30	29
2014	7	28	14	2	18	0.148	0.112	0.709	0.033	0.03	0	50.7	51.2	69.7	148	148	0	30	29
2014	7	28	14	12	18	0.187	0.108	0.705	0.03	0.03	0	51.6	51.2	70.1	150	149	0	30	30
2014	7	28	14	22	18	0.154	0.151	0.705	0.033	0.03	0	51.2	50.7	68.8	149	147	0	30	29
2014	7	28	14	32	18	0.141	0.151	0.705	0.036	0.033	0	50.3	49.5	68.8	147	145	0	30	30
2014	7	28	14	42	18	0.161	0.161	0.705	0.033	0.03	0	50.3	49.9	68.4	147	145	0	30	29
2014	7	28	14	52	18	0.082	0.128	0.705	0.036	0.033	0	49.9	49	68.4	146	143	0	30	29
2014	7	28	15	2	18	0.21	0.079	0.705	0.036	0.033	0	49.9	48.2	70.1	146	142	0	30	30
2014	7	28	15	12	18	0.2	0.187	0.705	0.036	0.033	0	50.7	50.3	69.7	148	146	0	30	29
2014	7	28	15	22	18	0.161	0.161	0.705	0.039	0.036	0	49.5	48.6	68.8	145	143	0	30	30
2014	7	28	15	32	18	0.203	0.203	0.705	0.033	0.03	0	50.7	49.5	68.8	148	144	0	30	29
2014	7	28	15	42	18	0.098	0.121	0.702	0.036	0.033	0	54.6	53.3	66.7	157	154	0	30	30
2014	7	28	15	52	18	0.115	0.187	0.702	0.033	0.03	0	56.3	55.9	65.4	161	159	0	30	29
2014	7	28	16	2	18	0.21	0.138	0.702	0.033	0.03	0	56.8	56.3	66.2	162	160	0	30	29
2014	7	28	16	12	18	0.22	0.052	0.702	0.033	0.03	0	56.8	55.5	63.6	162	158	0	30	29
2014	7	28	16	22	18	0.151	0.171	0.702	0.036	0.033	0	56.8	56.3	63.2	162	160	0	30	29
2014	7	28	16	32	18	0.174	0.157	0.702	0.036	0.033	0	57.6	57.2	61.9	165	162	0	31	29
2014	7	28	16	42	18	0.184	0.2	0.702	0.033	0.03	0	57.2	56.3	62.8	163	160	0	30	29
2014	7	28	16	52	18	0.207	0.19	0.705	0.033	0.03	0	57.2	55.5	61.9	163	158	0	30	29
2014	7	28	17	2	18	0.112	0.092	0.705	0.036	0.033	0	55.9	54.2	63.2	160	155	0	30	29
2014	7	28	17	12	18	0.187	0.151	0.705	0.036	0.033	0	55.9	54.2	63.6	160	155	0	30	29
2014	7	28	17	22	18	0.207	0.197	0.705	0.033	0.03	0	55.9	54.2	63.2	160	155	0	30	29
2014	7	28	17	32	18	0.187	0.23	0.705	0.036	0.033	0	55.5	54.2	63.2	159	155	0	30	29
2014	7	28	17	42	18	0.148	0.19	0.705	0.043	0.039	0	55.5	53.8	63.2	159	154	0	30	29
2014	7	28	17	52	18	0.197	0.276	0.705	0.046	0.043	0	55.5	53.8	63.2	159	154	0	30	29
2014	7	28	18	2	18	0.207	0.262	0.705	0.043	0.039	0	55	52.9	63.2	158	153	0	30	30
2014	7	28	18	12	18	0.2	0.24	0.705	0.039	0.036	0	54.6	52.5	63.6	158	152	0	31	30
2014	7	28	18	22	18	0.262	0.308	0.705	0.039	0.039	0	54.6	52.9	63.2	157	152	0	30	29
2014	7	28	18	32	18	0.161	0.279	0.705	0.046	0.043	0	53.8	52.9	64.1	156	152	0	31	29
2014	7	28	18	42	18	0.171	0.249	0.705	0.033	0.03	0	53.8	52	64.9	155	150	0	30	29
2014	7	28	18	52	18	0.213	0.226	0.705	0.039	0.036	0	52.5	51.6	65.4	153	149	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	19	2	18	0.131	0.266	0.705	0.036	0.033	0	52.9	50.3	65.4	153	146	0	30	29
2014	7	28	19	12	18	0.128	0.187	0.705	0.036	0.033	0	52	51.2	65.8	152	148	0	31	29
2014	7	28	19	22	18	0.203	0.272	0.709	0.039	0.036	0	52.5	50.3	66.2	152	147	0	30	30
2014	7	28	19	32	18	0.151	0.197	0.709	0.039	0.036	0	52	50.3	65.4	151	147	0	30	30
2014	7	28	19	42	18	0.177	0.233	0.709	0.039	0.039	0	52.5	51.2	65.4	153	148	0	31	29
2014	7	28	19	52	18	0.121	0.233	0.709	0.033	0.03	0	54.6	52.5	64.5	157	151	0	30	29
2014	7	28	20	2	18	0.151	0.187	0.709	0.033	0.03	0	55	53.3	63.6	158	153	0	30	29
2014	7	28	20	12	18	0.246	0.213	0.709	0.036	0.033	0	54.2	52.9	63.2	156	152	0	30	29
2014	7	28	20	22	18	0.187	0.171	0.709	0.03	0.03	0	55	55	61.5	158	157	0	30	29
2014	7	28	20	32	18	0.098	0.171	0.709	0.033	0.03	0	55	54.2	62.4	158	156	0	30	30
2014	7	28	20	42	18	0.112	0.121	0.709	0.036	0.033	0	57.2	57.2	61.5	163	162	0	30	29
2014	7	28	20	52	18	0.167	0.098	0.712	0.033	0.03	0	55.9	55	61.5	160	158	0	30	30
2014	7	28	21	2	18	0.184	0.105	0.712	0.039	0.036	0	58	57.6	58.5	165	163	0	30	29
2014	7	28	21	12	18	0.131	0.187	0.715	0.03	0.03	0	58	57.2	57.6	165	163	0	30	30
2014	7	28	21	22	18	0.161	0.161	0.719	0.033	0.03	0	57.6	55.5	59.3	164	159	0	30	30
2014	7	28	21	32	18	0.174	0.141	0.725	0.046	0.043	0	57.2	55	59.3	163	158	0	30	30
2014	7	28	21	42	18	0.164	0.112	0.725	0.039	0.036	0	56.3	55	60.6	161	157	0	30	29
2014	7	28	21	52	18	0.2	0.177	0.725	0.039	0.036	0	55.9	54.6	60.6	160	156	0	30	29
2014	7	28	22	2	18	0.203	0.187	0.728	0.043	0.039	0	55.5	53.8	60.6	160	155	0	31	30
2014	7	28	22	12	18	0.19	0.157	0.728	0.043	0.039	0	56.3	54.6	60.6	161	156	0	30	29
2014	7	28	22	22	18	0.233	0.144	0.728	0.039	0.036	0	55.9	54.6	61.1	160	156	0	30	29
2014	7	28	22	32	18	0.233	0.184	0.728	0.039	0.036	0	55.5	54.2	60.6	160	156	0	31	30
2014	7	28	22	42	18	0.171	0.21	0.728	0.039	0.036	0	55.9	54.6	61.5	160	156	0	30	29
2014	7	28	22	52	18	0.203	0.24	0.728	0.039	0.039	0	55.9	54.2	61.9	160	155	0	30	29
2014	7	28	23	2	18	0.167	0.167	0.728	0.039	0.036	0	56.8	55	61.9	162	158	0	30	30
2014	7	28	23	12	18	0.207	0.128	0.728	0.039	0.036	0	56.3	55	61.9	161	158	0	30	30
2014	7	28	23	22	18	0.226	0.177	0.728	0.033	0.033	0	55	54.6	62.4	159	157	0	31	30
2014	7	28	23	32	18	0.24	0.108	0.728	0.046	0.043	0	55.5	54.2	62.8	159	155	0	30	29
2014	7	28	23	42	18	0.276	0.167	0.728	0.033	0.03	0	55	54.2	63.2	158	155	0	30	29
2014	7	28	23	52	18	0.223	0.151	0.732	0.036	0.033	0	54.2	53.3	63.6	157	154	0	31	30
2014	7	29	0	2	18	0.197	0.19	0.732	0.046	0.043	0	54.6	53.8	64.1	157	154	0	30	29
2014	7	29	0	12	18	0.259	0.128	0.728	0.033	0.03	0	54.2	53.3	64.1	156	154	0	30	30
2014	7	29	0	22	18	0.177	0.089	0.732	0.039	0.039	0	54.2	53.3	64.9	156	153	0	30	29
2014	7	29	0	32	18	0.2	0.154	0.732	0.036	0.033	0	53.3	52.9	65.4	154	152	0	30	29
2014	7	29	0	42	18	0.138	0.184	0.732	0.039	0.039	0	53.3	52	65.4	154	151	0	30	30
2014	7	29	0	52	18	0.2	0.19	0.732	0.033	0.03	0	52	51.6	65.8	152	150	0	31	30
2014	7	29	1	2	18	0.177	0.256	0.732	0.039	0.036	0	51.6	50.7	66.2	151	148	0	31	30
2014	7	29	1	12	18	0.18	0.131	0.732	0.039	0.036	0	51.6	51.2	66.7	151	148	0	31	29
2014	7	29	1	22	18	0.236	0.171	0.732	0.036	0.033	0	51.6	50.3	66.2	150	147	0	30	30
2014	7	29	1	32	18	0.18	0.246	0.732	0.033	0.03	0	51.6	50.3	66.7	151	147	0	31	30
2014	7	29	1	42	18	0.184	0.194	0.732	0.036	0.033	0	50.7	49.9	66.2	149	146	0	31	30
2014	7	29	1	52	18	0.125	0.167	0.732	0.036	0.033	0	52	51.2	65.4	152	148	0	31	29
2014	7	29	2	2	18	0.148	0.184	0.732	0.039	0.039	0	51.6	50.7	65.8	151	148	0	31	30
2014	7	29	2	12	18	0.125	0.144	0.732	0.039	0.036	0	51.2	50.3	66.7	149	147	0	30	30
2014	7	29	2	22	18	0.164	0.105	0.732	0.033	0.03	0	50.7	49.9	67.1	149	146	0	31	30
2014	7	29	2	32	18	0.171	0.098	0.732	0.039	0.036	0	50.3	49.5	68.4	148	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	2	42	18	0.144	0.164	0.732	0.033	0.03	0	50.3	49.5	66.7	147	145	0	30	30
2014	7	29	2	52	18	0.2	0.085	0.732	0.036	0.033	0	50.7	49	67.5	148	144	0	30	30
2014	7	29	3	2	18	0.154	0.059	0.732	0.033	0.033	0	49.9	48.6	68.4	146	143	0	30	30
2014	7	29	3	12	18	0.144	0.128	0.728	0.033	0.03	0	49.9	49.5	67.5	146	145	0	30	30
2014	7	29	3	22	18	0.154	0.036	0.728	0.039	0.036	0	49.5	49.5	68.8	146	144	0	31	29
2014	7	29	3	32	18	0.112	0.069	0.728	0.039	0.036	0	48.6	48.2	66.7	145	143	0	32	31
2014	7	29	3	42	18	0.2	0.059	0.728	0.033	0.03	0	49.9	49	67.9	146	144	0	30	30
2014	7	29	3	52	18	0.075	0.033	0.728	0.039	0.039	0	49	48.2	67.9	145	142	0	31	30
2014	7	29	4	2	18	0.177	0.095	0.725	0.043	0.043	0	49.5	49	68.4	146	144	0	31	30
2014	7	29	4	12	18	0.18	0.033	0.725	0.046	0.043	0	48.6	49	68.4	144	145	0	31	31
2014	7	29	4	22	18	0.144	0.039	0.725	0.036	0.033	0	48.6	48.6	68.4	144	143	0	31	30
2014	7	29	4	32	18	0.197	0.052	0.722	0.033	0.03	0	48.6	48.6	67.9	144	143	0	31	30
2014	7	29	4	42	18	0.157	0.095	0.725	0.036	0.033	0	49.5	48.2	67.9	145	142	0	30	30
2014	7	29	4	52	18	0.197	0.069	0.722	0.033	0.03	0	48.2	47.3	66.7	142	141	0	30	31
2014	7	29	5	2	18	0.118	0.056	0.722	0.033	0.03	0	48.6	47.3	68.4	144	140	0	31	30
2014	7	29	5	12	18	0.125	0.072	0.722	0.039	0.036	0	48.6	48.2	67.1	144	142	0	31	30
2014	7	29	5	22	18	0.144	-0.007	0.719	0.043	0.039	0	50.3	49	65.8	147	144	0	30	30
2014	7	29	5	32	18	0.144	0.036	0.715	0.036	0.033	0	49.9	49	66.7	146	144	0	30	30
2014	7	29	5	42	18	0.138	0.049	0.715	0.036	0.033	0	49.5	48.6	66.7	146	143	0	31	30
2014	7	29	5	52	18	0.19	0.085	0.712	0.036	0.033	0	48.2	47.3	67.1	143	141	0	31	31
2014	7	29	6	2	18	0.171	0.036	0.712	0.039	0.036	0	49	47.7	67.5	145	141	0	31	30
2014	7	29	6	12	18	0.161	0.056	0.712	0.033	0.03	0	47.3	47.3	67.9	141	140	0	31	30
2014	7	29	6	22	18	0.21	0.033	0.712	0.033	0.03	0	47.7	46.4	68.4	141	138	0	30	30
2014	7	29	6	32	18	0.217	0.052	0.709	0.039	0.039	0	46.9	46.4	67.9	140	138	0	31	30
2014	7	29	6	42	18	0.125	0.056	0.709	0.036	0.033	0	46.9	46.4	68.8	139	138	0	30	30
2014	7	29	6	52	18	0.141	0.112	0.709	0.039	0.036	0	46.4	46.4	69.2	139	138	0	31	30
2014	7	29	7	2	18	0.128	0.007	0.705	0.036	0.033	0	46.4	46.4	68.8	139	138	0	31	30
2014	7	29	7	12	18	0.131	0.02	0.705	0.039	0.036	0	46	45.6	68.8	138	136	0	31	30
2014	7	29	7	22	18	0.141	0.046	0.705	0.039	0.036	0	46	46	70.1	138	137	0	31	30
2014	7	29	7	32	18	0.154	0.043	0.705	0.036	0.033	0	46	46.4	70.5	138	138	0	31	30
2014	7	29	7	42	18	0.125	0	0.705	0.033	0.03	0	47.3	46.9	70.1	141	139	0	31	30
2014	7	29	7	52	18	0.112	0.023	0.705	0.033	0.03	0	46.4	46.4	70.1	139	138	0	31	30
2014	7	29	8	2	18	0.098	0.072	0.702	0.039	0.039	0	46.9	46.9	70.1	140	139	0	31	30
2014	7	29	8	12	18	0.102	0.056	0.702	0.036	0.033	0	46.9	46.9	70.5	140	139	0	31	30
2014	7	29	8	22	18	0.105	0.079	0.702	0.033	0.03	0	47.3	47.3	71.4	141	140	0	31	30
2014	7	29	8	32	18	0.161	-0.003	0.702	0.033	0.03	0	47.3	46.9	70.5	140	139	0	30	30
2014	7	29	8	42	18	0.167	0.03	0.702	0.033	0.03	0	45.6	46.4	71.8	137	138	0	31	30
2014	7	29	8	52	18	0.095	0.089	0.702	0.036	0.033	0	46	45.6	71.8	137	136	0	30	30
2014	7	29	9	2	18	0.174	0.052	0.702	0.033	0.03	0	45.6	45.2	72.2	137	135	0	31	30
2014	7	29	9	12	18	0.089	0.046	0.702	0.033	0.03	0	46	46	72.7	138	137	0	31	30
2014	7	29	9	22	18	0.144	0	0.699	0.036	0.033	0	46	46.4	72.7	137	138	0	30	30
2014	7	29	9	32	18	0.049	0.02	0.699	0.033	0.03	0	46.4	46.9	72.2	139	140	0	31	31
2014	7	29	9	42	18	0.095	0.023	0.699	0.036	0.033	0	46	47.3	72.7	138	141	0	31	31
2014	7	29	9	52	18	0.148	0.052	0.699	0.033	0.03	0	46	46.4	72.2	138	138	0	31	30
2014	7	29	10	2	18	0.138	0.059	0.699	0.033	0.03	0	46.9	45.6	72.7	140	137	0	31	31
2014	7	29	10	12	18	0.102	0.056	0.699	0.039	0.039	0	46	46.4	72.7	138	138	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	10	22	18	0.144	0.062	0.699	0.046	0.043	0	46.9	47.3	72.2	140	140	0	31	30
2014	7	29	10	32	18	0.177	0.033	0.699	0.036	0.033	0	46.4	46.9	72.2	139	138	0	31	29
2014	7	29	10	42	18	0.089	0.046	0.696	0.036	0.033	0	46.9	46.9	71	140	139	0	31	30
2014	7	29	10	52	18	0.144	0.03	0.696	0.033	0.03	0	46	47.3	70.5	137	140	0	30	30
2014	7	29	11	2	18	0.148	0.056	0.696	0.036	0.033	0	46.9	46.9	71	140	138	0	31	29
2014	7	29	11	12	18	0.115	0.072	0.696	0.033	0.033	0	46.4	46.4	70.5	139	138	0	31	30
2014	7	29	11	22	18	0.118	0.056	0.692	0.036	0.033	0	46	47.3	70.5	138	140	0	31	30
2014	7	29	11	32	18	0.128	0.052	0.692	0.033	0.03	0	46.4	48.2	70.1	139	141	0	31	29
2014	7	29	11	42	18	0.108	0.023	0.689	0.033	0.03	0	47.3	47.3	70.5	140	140	0	30	30
2014	7	29	11	52	18	0.121	0.01	0.689	0.033	0.03	0	47.7	47.3	69.7	141	139	0	30	29
2014	7	29	12	2	18	0.072	0.036	0.689	0.039	0.036	0	47.3	48.2	68.8	141	141	0	31	29
2014	7	29	12	12	18	0.03	0.085	0.686	0.033	0.033	0	47.7	49.9	67.5	142	145	0	31	29
2014	7	29	12	22	18	0.128	0.023	0.682	0.033	0.03	0	46.9	49	67.9	140	143	0	31	29
2014	7	29	12	32	18	-0.01	0.049	0.679	0.033	0.03	0	48.6	49.5	69.2	143	145	0	30	30
2014	7	29	12	42	18	0.089	0.007	0.676	0.033	0.03	0	47.3	48.6	67.9	141	143	0	31	30
2014	7	29	12	52	18	0.023	0.069	0.673	0.033	0.03	0	47.7	49	68.8	141	143	0	30	29
2014	7	29	13	2	18	0.007	0.095	0.673	0.033	0.03	0	48.2	49.9	67.5	142	146	0	30	30
2014	7	29	13	12	18	0.033	0	0.673	0.03	0.03	0	48.6	49.9	70.1	143	145	0	30	29
2014	7	29	13	22	18	0.062	0.036	0.673	0.039	0.036	0	49.5	50.3	69.2	145	147	0	30	30
2014	7	29	13	32	18	0.075	0.033	0.669	0.033	0.03	0	49.5	50.3	68.4	145	147	0	30	30
2014	7	29	13	42	18	0.056	0.079	0.673	0.03	0.03	0	48.6	49.9	68.8	143	145	0	30	29
2014	7	29	13	52	18	0.036	0.046	0.669	0.033	0.03	0	50.7	50.7	68.8	148	147	0	30	29
2014	7	29	14	2	18	0.095	0.052	0.669	0.03	0.03	0	49.9	51.6	69.2	146	149	0	30	29
2014	7	29	14	12	18	0.075	0.075	0.669	0.033	0.03	0	50.7	50.7	68.8	148	147	0	30	29
2014	7	29	14	22	18	0.102	0.016	0.669	0.036	0.033	0	51.2	51.2	68.8	150	148	0	31	29
2014	7	29	14	32	18	0.121	0.033	0.669	0.033	0.03	0	50.7	51.2	68.4	148	148	0	30	29
2014	7	29	14	42	18	0.115	0.069	0.666	0.039	0.036	0	51.6	51.6	68.8	150	149	0	30	29
2014	7	29	14	52	18	0.177	0.039	0.669	0.033	0.03	0	51.2	52	68.8	149	150	0	30	29
2014	7	29	15	2	18	0.135	0.052	0.669	0.033	0.03	0	51.2	52	69.2	149	150	0	30	29
2014	7	29	15	12	18	0.174	0.102	0.669	0.033	0.03	0	51.6	51.6	69.2	150	149	0	30	29
2014	7	29	15	22	18	0.131	0.023	0.666	0.033	0.03	0	52	52.5	68.8	151	151	0	30	29
2014	7	29	15	32	18	0.095	0.079	0.666	0.036	0.033	0	51.6	52	69.7	150	149	0	30	28
2014	7	29	15	42	18	0.19	0.082	0.666	0.033	0.03	0	51.6	52.5	68.8	150	151	0	30	29
2014	7	29	15	52	18	0.131	0.102	0.666	0.036	0.033	0	52	52	67.9	151	150	0	30	29
2014	7	29	16	2	18	0.177	0.128	0.666	0.036	0.033	0	53.3	53.3	68.8	154	153	0	30	29
2014	7	29	16	12	18	0.207	0.144	0.669	0.033	0.03	0	53.8	52.9	66.7	155	152	0	30	29
2014	7	29	16	22	18	0.141	0.141	0.666	0.033	0.03	0	53.3	52.9	67.9	153	152	0	29	29
2014	7	29	16	32	18	0.167	0.128	0.666	0.033	0.03	0	52.9	52.5	67.9	153	151	0	30	29
2014	7	29	16	42	18	0.161	0.089	0.666	0.033	0.03	0	52.9	52	68.8	152	150	0	29	29
2014	7	29	16	52	18	0.207	0.118	0.666	0.033	0.03	0	52.5	52.5	68.4	152	151	0	30	29
2014	7	29	17	2	18	0.115	0.102	0.666	0.036	0.033	0	51.2	51.2	67.9	149	148	0	30	29
2014	7	29	17	12	18	0.157	0.115	0.666	0.036	0.033	0	51.6	51.2	67.9	149	148	0	29	29
2014	7	29	17	22	18	0.171	0.102	0.666	0.039	0.036	0	50.7	50.3	68.8	148	146	0	30	29
2014	7	29	17	32	18	0.138	0.115	0.666	0.036	0.033	0	49.5	49.9	69.2	144	145	0	29	29
2014	7	29	17	42	18	0.157	0.128	0.666	0.036	0.033	0	49.5	49.5	70.5	145	144	0	30	29
2014	7	29	17	52	18	0.171	0.157	0.666	0.033	0.03	0	50.3	49.9	71	147	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	18	2	18	0.19	0.19	0.666	0.036	0.033	0	48.2	48.2	71.4	142	141	0	30	29
2014	7	29	18	12	18	0.135	0.105	0.666	0.033	0.03	0	47.7	47.3	71	141	139	0	30	29
2014	7	29	18	22	18	0.148	0.194	0.669	0.043	0.039	0	47.3	46.4	71.4	140	137	0	30	29
2014	7	29	18	32	18	0.125	0.131	0.669	0.033	0.03	0	47.3	46	72.7	139	135	0	29	28
2014	7	29	18	42	18	0.115	0.177	0.669	0.033	0.03	0	45.6	44.7	72.2	136	133	0	30	29
2014	7	29	18	52	18	0.151	0.161	0.669	0.033	0.03	0	46.4	44.7	71.4	137	133	0	29	29
2014	7	29	19	2	18	0.052	0.138	0.669	0.033	0.03	0	47.3	46	71.8	140	135	0	30	28
2014	7	29	19	12	18	0.098	0.154	0.673	0.039	0.036	0	47.3	45.2	69.2	139	133	0	29	28
2014	7	29	19	22	18	0.066	0.19	0.673	0.036	0.033	0	47.3	45.6	69.7	139	135	0	29	29
2014	7	29	19	32	18	0.164	0.062	0.676	0.039	0.036	0	48.2	46	68.4	142	136	0	30	29
2014	7	29	19	42	18	0.141	0.079	0.679	0.043	0.039	0	47.7	46	67.5	141	136	0	30	29
2014	7	29	19	52	18	0.039	0.056	0.689	0.033	0.033	0	49.5	46	68.4	145	136	0	30	29
2014	7	29	20	2	18	0.115	0.079	0.692	0.036	0.033	0	46.9	45.6	68.8	139	135	0	30	29
2014	7	29	20	12	18	0.138	0.102	0.699	0.033	0.03	0	46.4	45.2	70.1	138	134	0	30	29
2014	7	29	20	22	18	0.194	0.069	0.702	0.033	0.03	0	46.4	45.2	71.8	137	134	0	29	29
2014	7	29	20	32	18	0.233	0.092	0.705	0.036	0.033	0	46	45.6	73.5	136	134	0	29	28
2014	7	29	20	42	18	0.118	0.075	0.709	0.039	0.036	0	45.6	45.6	72.7	136	135	0	30	29
2014	7	29	20	52	18	0.194	0.036	0.712	0.033	0.03	0	45.6	45.2	72.2	136	134	0	30	29
2014	7	29	21	2	18	0.203	0.092	0.715	0.036	0.033	0	46.9	45.6	71	139	135	0	30	29
2014	7	29	21	12	18	0.223	0.075	0.719	0.039	0.036	0	46.9	45.2	69.2	139	134	0	30	29
2014	7	29	21	22	18	0.174	0.098	0.732	0.033	0.03	0	46.4	45.6	69.2	138	135	0	30	29
2014	7	29	21	32	18	0.207	0.095	0.735	0.036	0.033	0	46	44.7	71.4	137	133	0	30	29
2014	7	29	21	42	18	0.174	0.089	0.741	0.039	0.036	0	47.3	45.6	71	139	135	0	29	29
2014	7	29	21	52	18	0.207	0.098	0.745	0.036	0.033	0	48.2	46.4	72.7	142	137	0	30	29
2014	7	29	22	2	18	0.19	0.01	0.745	0.036	0.033	0	49.9	48.2	71	146	141	0	30	29
2014	7	29	22	12	18	0.092	-0.01	0.748	0.039	0.039	0	49	47.7	70.1	144	140	0	30	29
2014	7	29	22	22	18	0.194	0.092	0.751	0.043	0.039	0	47.7	46.4	70.5	141	137	0	30	29
2014	7	29	22	32	18	0.164	0.079	0.755	0.033	0.03	0	47.3	46.4	70.1	140	137	0	30	29
2014	7	29	22	42	18	0.121	0.033	0.758	0.039	0.036	0	47.3	45.2	69.2	140	135	0	30	30
2014	7	29	22	52	18	0.194	0.023	0.768	0.043	0.039	0	46.4	46	68.8	138	137	0	30	30
2014	7	29	23	2	18	0.223	0.043	0.771	0.036	0.033	0	47.3	46	70.5	139	136	0	29	29
2014	7	29	23	12	18	0.194	0.046	0.774	0.036	0.033	0	46	45.6	72.7	138	135	0	31	29
2014	7	29	23	22	18	0.18	0.052	0.778	0.033	0.03	0	46.4	45.2	72.7	137	134	0	29	29
2014	7	29	23	32	18	0.154	0.049	0.781	0.039	0.036	0	45.6	46.4	74	136	136	0	30	28
2014	7	29	23	42	18	0.157	0	0.784	0.039	0.036	0	46	45.6	74.4	136	135	0	29	29
2014	7	29	23	52	18	0.184	-0.003	0.784	0.033	0.033	0	45.2	45.6	75.3	135	135	0	30	29
2014	7	30	0	2	18	0.151	0.003	0.784	0.039	0.036	0	46	44.7	74.4	137	134	0	30	30
2014	7	30	0	12	18	0.223	0.089	0.787	0.033	0.03	0	46	45.6	73.5	137	135	0	30	29
2014	7	30	0	22	18	0.098	0.066	0.787	0.036	0.033	0	46.4	46	73.1	138	136	0	30	29
2014	7	30	0	32	18	0.151	-0.013	0.787	0.033	0.03	0	46	46.4	71.8	138	137	0	31	29
2014	7	30	0	42	18	0.24	0.036	0.791	0.03	0.03	0	46	46	72.2	137	137	0	30	30
2014	7	30	0	52	18	0.226	0.062	0.791	0.033	0.03	0	46	46	72.2	137	136	0	30	29
2014	7	30	1	2	18	0.207	0.082	0.791	0.033	0.03	0	45.6	44.7	70.5	136	134	0	30	30
2014	7	30	1	12	18	0.246	0.003	0.794	0.036	0.033	0	46	45.6	69.7	137	135	0	30	29
2014	7	30	1	22	18	0.226	-0.016	0.797	0.036	0.033	0	46.9	46	70.5	139	136	0	30	29
2014	7	30	1	32	18	0.167	-0.043	0.801	0.033	0.03	0	45.6	45.2	70.5	136	134	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	1	42	18	0.207	-0.003	0.804	0.033	0.03	0	46.4	46	70.5	137	136	0	29	29
2014	7	30	1	52	18	0.223	-0.013	0.807	0.036	0.033	0	46.4	45.6	71	138	135	0	30	29
2014	7	30	2	2	18	0.18	0.036	0.807	0.033	0.03	0	45.6	46	71.4	136	136	0	30	29
2014	7	30	2	12	18	0.171	0.013	0.81	0.043	0.039	0	48.6	48.2	68.8	143	142	0	30	30
2014	7	30	2	22	18	0.164	-0.023	0.81	0.033	0.03	0	47.7	47.3	70.1	141	139	0	30	29
2014	7	30	2	32	18	0.236	0.023	0.814	0.036	0.033	0	48.2	47.3	71.4	143	140	0	31	30
2014	7	30	2	42	18	0.18	0.052	0.814	0.039	0.036	0	48.2	47.3	71.8	142	140	0	30	30
2014	7	30	2	52	18	0.223	0.007	0.814	0.033	0.03	0	47.7	46.4	71.8	141	138	0	30	30
2014	7	30	3	2	18	0.203	0.069	0.817	0.036	0.033	0	47.3	46	73.5	140	137	0	30	30
2014	7	30	3	12	18	0.341	0.052	0.817	0.033	0.03	0	46.9	45.6	74.8	139	136	0	30	30
2014	7	30	3	22	18	0.164	-0.023	0.817	0.039	0.039	0	45.2	44.7	74.8	136	134	0	31	30
2014	7	30	3	32	18	0.259	0.036	0.817	0.036	0.033	0	45.2	45.2	75.3	136	134	0	31	29
2014	7	30	3	42	18	0.302	0.03	0.82	0.033	0.03	0	45.6	45.2	74.4	136	135	0	30	30
2014	7	30	3	52	18	0.249	-0.016	0.82	0.036	0.033	0	45.6	45.2	74	136	135	0	30	30
2014	7	30	4	2	18	0.282	0.026	0.82	0.036	0.033	0	46	45.2	73.5	137	135	0	30	30
2014	7	30	4	12	18	0.233	0.066	0.82	0.039	0.039	0	45.6	45.6	72.7	137	135	0	31	29
2014	7	30	4	22	18	0.217	-0.01	0.82	0.039	0.036	0	46.9	46	71.8	140	136	0	31	29
2014	7	30	4	32	18	0.213	-0.056	0.823	0.033	0.03	0	45.6	43.9	73.1	137	132	0	31	30
2014	7	30	4	42	18	0.243	0.02	0.823	0.033	0.03	0	45.6	45.6	72.2	136	135	0	30	29
2014	7	30	4	52	18	0.243	-0.049	0.823	0.039	0.036	0	45.6	45.2	72.7	137	135	0	31	30
2014	7	30	5	2	18	0.259	0	0.827	0.039	0.036	0	45.2	44.7	72.2	136	134	0	31	30
2014	7	30	5	12	18	0.2	0.036	0.827	0.033	0.03	0	46	45.2	71.8	137	134	0	30	29
2014	7	30	5	22	18	0.22	0.01	0.827	0.039	0.036	0	46.4	45.2	71.8	138	135	0	30	30
2014	7	30	5	32	18	0.272	-0.003	0.827	0.039	0.039	0	46.9	45.2	70.5	139	135	0	30	30
2014	7	30	5	42	18	0.213	0.046	0.827	0.036	0.033	0	46.9	45.6	71.4	139	136	0	30	30
2014	7	30	5	52	18	0.272	0.052	0.827	0.039	0.036	0	45.6	44.3	70.5	136	133	0	30	30
2014	7	30	6	2	18	0.197	0.092	0.83	0.039	0.036	0	45.2	45.2	70.1	136	135	0	31	30
2014	7	30	6	12	18	0.24	0.062	0.83	0.036	0.033	0	45.2	43.9	71	135	132	0	30	30
2014	7	30	6	22	18	0.22	0.007	0.83	0.033	0.03	0	44.7	43.9	71.4	135	132	0	31	30
2014	7	30	6	32	18	0.249	0	0.83	0.033	0.03	0	43.9	43.9	71.4	133	131	0	31	29
2014	7	30	6	42	18	0.279	0.026	0.833	0.033	0.03	0	44.3	43.9	71	134	132	0	31	30
2014	7	30	6	52	18	0.272	0.066	0.833	0.036	0.033	0	45.2	44.3	70.5	136	133	0	31	30
2014	7	30	7	2	18	0.246	0.085	0.833	0.039	0.036	0	43.9	43.9	70.5	133	132	0	31	30
2014	7	30	7	12	18	0.213	0	0.833	0.043	0.043	0	44.7	43.9	71.4	135	132	0	31	30
2014	7	30	7	22	18	0.289	0.003	0.83	0.036	0.033	0	44.7	44.3	70.5	135	133	0	31	30
2014	7	30	7	32	18	0.217	0.02	0.833	0.033	0.03	0	44.7	44.3	71	134	133	0	30	30
2014	7	30	7	42	18	0.194	-0.003	0.83	0.039	0.036	0	44.7	44.7	69.7	135	134	0	31	30
2014	7	30	7	52	18	0.256	0.03	0.833	0.039	0.036	0	44.3	44.3	71	134	133	0	31	30
2014	7	30	8	2	18	0.22	0.052	0.833	0.033	0.03	0	44.7	44.3	71	135	133	0	31	30
2014	7	30	8	12	18	0.203	-0.033	0.83	0.036	0.033	0	45.6	45.6	69.2	136	136	0	30	30
2014	7	30	8	22	18	0.2	-0.026	0.83	0.039	0.039	0	46	44.7	70.5	137	134	0	30	30
2014	7	30	8	32	18	0.184	0.013	0.83	0.036	0.033	0	45.2	45.2	69.2	136	135	0	31	30
2014	7	30	8	42	18	0.2	0.056	0.83	0.046	0.046	0	45.6	45.2	69.7	136	135	0	30	30
2014	7	30	8	52	18	0.236	-0.003	0.827	0.033	0.03	0	46	45.6	69.7	138	135	0	31	29
2014	7	30	9	2	18	0.285	-0.056	0.827	0.033	0.03	0	45.6	45.6	70.1	137	136	0	31	30
2014	7	30	9	12	18	0.108	0.033	0.827	0.039	0.036	0	57.6	55.5	43.9	164	159	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	9	22	18	0.207	0.062	0.833	0.03	0.03	0	46	45.6	55	138	136	0	31	30
2014	7	30	9	32	18	0.262	0.039	0.827	0.036	0.033	0	45.6	45.2	67.1	137	136	0	31	31
2014	7	30	9	42	18	0.285	0	0.823	0.036	0.033	0	46.4	45.6	72.2	139	136	0	31	30
2014	7	30	9	52	18	0.272	-0.007	0.823	0.033	0.03	0	45.6	44.7	71.8	137	134	0	31	30
2014	7	30	10	2	18	0.236	0.033	0.823	0.033	0.03	0	46.4	45.2	73.5	138	135	0	30	30
2014	7	30	10	12	18	0.243	0.036	0.82	0.036	0.033	0	46.4	45.6	72.2	139	136	0	31	30
2014	7	30	10	22	18	0.19	0.046	0.82	0.039	0.036	0	46.4	45.6	72.2	139	136	0	31	30
2014	7	30	10	32	18	0.2	0.072	0.82	0.033	0.03	0	46.4	45.6	71.8	139	136	0	31	30
2014	7	30	10	42	18	0.276	0.033	0.82	0.036	0.033	0	46.4	45.6	73.1	139	136	0	31	30
2014	7	30	10	52	18	0.236	0.056	0.82	0.039	0.036	0	46.9	46	73.1	139	137	0	30	30
2014	7	30	11	2	18	0.233	0.069	0.82	0.033	0.03	0	46.4	45.6	72.7	139	136	0	31	30
2014	7	30	11	12	18	0.236	-0.026	0.82	0.036	0.033	0	46	45.2	74	138	135	0	31	30
2014	7	30	11	22	18	0.318	0.046	0.817	0.033	0.03	0	46	45.2	71.4	138	135	0	31	30
2014	7	30	11	32	18	0.253	0.062	0.817	0.036	0.033	0	46.4	45.2	73.1	138	135	0	30	30
2014	7	30	11	42	18	0.161	-0.026	0.817	0.039	0.036	0	47.3	46	71.4	140	136	0	30	29
2014	7	30	11	52	18	0.174	0.095	0.817	0.039	0.036	0	49.5	48.2	68.4	145	142	0	30	30
2014	7	30	12	2	18	0.177	0.033	0.817	0.033	0.03	0	49.5	49	65.4	146	144	0	31	30
2014	7	30	12	12	18	0.262	0.085	0.814	0.039	0.039	0	50.7	49.9	67.1	149	146	0	31	30
2014	7	30	12	22	18	0.276	0.049	0.814	0.039	0.036	0	50.7	50.3	64.9	149	147	0	31	30
2014	7	30	12	32	18	0.249	0.144	0.814	0.036	0.033	0	51.2	49.5	66.7	149	145	0	30	30
2014	7	30	12	42	18	0.213	0.03	0.814	0.039	0.036	0	50.7	49.9	66.2	148	146	0	30	30
2014	7	30	12	52	18	0.262	0.069	0.814	0.036	0.033	0	50.7	49.9	67.5	148	146	0	30	30
2014	7	30	13	2	18	0.2	0.062	0.814	0.033	0.03	0	52.5	51.2	68.4	152	149	0	30	30
2014	7	30	13	12	18	0.226	0.092	0.814	0.033	0.03	0	52.5	52	66.7	153	151	0	31	30
2014	7	30	13	22	18	0.315	0.144	0.814	0.036	0.033	0	54.6	53.3	64.1	158	155	0	31	31
2014	7	30	13	32	18	0.128	0.144	0.801	0.039	0.039	0	61.9	61.1	54.2	175	172	0	31	30
2014	7	30	13	42	18	0.276	0.282	0.81	0.039	0.036	0	61.1	59.8	55	173	169	0	31	30
2014	7	30	13	52	18	0.269	0.197	0.814	0.043	0.039	0	61.1	60.2	53.8	173	169	0	31	29
2014	7	30	14	2	18	0.269	0.308	0.814	0.046	0.043	0	60.6	58.9	54.2	172	167	0	31	30
2014	7	30	14	12	18	0.302	0.23	0.814	0.043	0.039	0	60.6	59.3	54.2	172	168	0	31	30
2014	7	30	14	22	18	0.295	0.246	0.814	0.043	0.039	0	61.1	59.3	54.6	173	168	0	31	30
2014	7	30	14	32	18	0.24	0.207	0.814	0.039	0.039	0	61.5	59.8	53.3	174	169	0	31	30
2014	7	30	14	42	18	0.207	0.217	0.81	0.043	0.039	0	62.4	60.6	53.3	176	171	0	31	30
2014	7	30	14	52	18	0.335	0.262	0.814	0.033	0.03	0	62.4	60.6	52.5	175	171	0	30	30
2014	7	30	15	2	18	0.272	0.295	0.814	0.039	0.036	0	62.8	60.6	51.2	176	171	0	30	30
2014	7	30	15	12	18	0.282	0.282	0.817	0.046	0.043	0	61.9	60.2	52.5	175	170	0	31	30
2014	7	30	15	22	18	0.246	0.207	0.817	0.039	0.036	0	63.2	61.9	50.3	179	174	0	32	30
2014	7	30	15	32	18	0.299	0.213	0.82	0.039	0.036	0	63.6	62.4	51.2	179	175	0	31	30
2014	7	30	15	42	18	0.272	0.253	0.82	0.039	0.036	0	64.1	61.9	49.9	179	174	0	30	30
2014	7	30	15	52	18	0.335	0.262	0.82	0.039	0.039	0	63.6	61.1	49.9	178	172	0	30	30
2014	7	30	16	2	18	0.394	0.233	0.823	0.043	0.039	0	63.2	61.5	49.9	178	173	0	31	30
2014	7	30	16	12	18	0.302	0.213	0.83	0.039	0.036	0	62.8	61.1	51.6	177	172	0	31	30
2014	7	30	16	22	18	0.269	0.233	0.83	0.036	0.033	0	62.4	60.2	52	175	170	0	30	30
2014	7	30	16	32	18	0.318	0.266	0.83	0.039	0.036	0	62.4	60.6	50.7	176	171	0	31	30
2014	7	30	16	42	18	0.318	0.335	0.833	0.043	0.039	0	61.5	59.8	52	174	169	0	31	30
2014	7	30	16	52	18	0.39	0.381	0.833	0.039	0.036	0	61.5	59.3	53.3	174	169	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	17	2	18	0.335	0.322	0.833	0.039	0.039	0	60.6	58.9	53.8	172	167	0	31	30
2014	7	30	17	12	18	0.358	0.249	0.833	0.039	0.039	0	59.8	58.5	54.6	171	166	0	32	30
2014	7	30	17	22	18	0.358	0.358	0.833	0.043	0.039	0	60.2	58.5	55	171	166	0	31	30
2014	7	30	17	32	18	0.312	0.335	0.833	0.036	0.033	0	59.3	58	55	169	165	0	31	30
2014	7	30	17	42	18	0.338	0.384	0.833	0.039	0.039	0	59.3	57.6	55.9	169	164	0	31	30
2014	7	30	17	52	18	0.325	0.315	0.833	0.046	0.043	0	58.5	56.8	56.3	167	162	0	31	30
2014	7	30	18	2	18	0.338	0.358	0.833	0.039	0.039	0	58	55.9	57.6	166	161	0	31	31
2014	7	30	18	12	18	0.305	0.338	0.833	0.036	0.033	0	57.6	55.5	57.6	165	160	0	31	31
2014	7	30	18	22	18	0.361	0.328	0.833	0.039	0.039	0	56.8	55.5	58.5	163	159	0	31	30
2014	7	30	18	32	18	0.341	0.42	0.833	0.036	0.033	0	56.8	54.2	59.8	162	157	0	30	31
2014	7	30	18	42	18	0.354	0.354	0.833	0.039	0.039	0	56.3	54.2	60.6	161	156	0	30	30
2014	7	30	18	52	18	0.377	0.41	0.833	0.052	0.049	0	55.9	53.3	61.1	160	155	0	30	31
2014	7	30	19	2	18	0.371	0.299	0.833	0.039	0.039	0	54.6	52.9	61.1	158	153	0	31	30
2014	7	30	19	12	18	0.335	0.374	0.833	0.036	0.033	0	53.8	52.5	62.4	156	152	0	31	30
2014	7	30	19	22	18	0.318	0.335	0.833	0.046	0.043	0	53.8	52	62.8	156	151	0	31	30
2014	7	30	19	32	18	0.331	0.292	0.833	0.039	0.039	0	52.5	51.2	63.2	153	149	0	31	30
2014	7	30	19	42	18	0.338	0.328	0.833	0.049	0.046	0	52	50.7	63.2	153	148	0	32	30
2014	7	30	19	52	18	0.358	0.253	0.833	0.046	0.043	0	52	50.3	64.5	152	147	0	31	30
2014	7	30	20	2	18	0.322	0.351	0.833	0.046	0.043	0	51.2	49.9	65.4	150	146	0	31	30
2014	7	30	20	12	18	0.377	0.266	0.833	0.039	0.036	0	51.2	49.5	65.4	149	145	0	30	30
2014	7	30	20	22	18	0.335	0.233	0.837	0.039	0.036	0	50.3	49	66.2	148	144	0	31	30
2014	7	30	20	32	18	0.322	0.233	0.837	0.043	0.039	0	49.9	48.6	65.8	147	143	0	31	30
2014	7	30	20	42	18	0.322	0.249	0.833	0.039	0.036	0	49.9	48.2	67.1	147	142	0	31	30
2014	7	30	20	52	18	0.358	0.276	0.833	0.036	0.033	0	49	48.2	67.1	146	142	0	32	30
2014	7	30	21	2	18	0.322	0.312	0.837	0.039	0.039	0	48.6	48.2	67.5	144	142	0	31	30
2014	7	30	21	12	18	0.262	0.141	0.837	0.049	0.049	0	49.5	48.2	67.9	146	142	0	31	30
2014	7	30	21	22	18	0.338	0.075	0.837	0.043	0.039	0	49.9	48.6	67.5	147	143	0	31	30
2014	7	30	21	32	18	0.318	0.079	0.837	0.036	0.033	0	50.3	49	67.1	148	144	0	31	30
2014	7	30	21	42	18	0.266	0.151	0.837	0.033	0.03	0	49	48.2	68.4	145	142	0	31	30
2014	7	30	21	52	18	0.285	0.092	0.837	0.039	0.036	0	49.5	47.7	67.1	145	142	0	30	31
2014	7	30	22	2	18	0.299	0.059	0.837	0.036	0.033	0	49	47.3	67.5	145	141	0	31	31
2014	7	30	22	12	18	0.282	0.082	0.84	0.036	0.033	0	48.2	47.7	68.8	143	141	0	31	30
2014	7	30	22	22	18	0.299	0.108	0.837	0.039	0.036	0	48.6	47.3	69.2	144	140	0	31	30
2014	7	30	22	32	18	0.285	0.079	0.837	0.033	0.03	0	48.6	47.7	68.4	143	141	0	30	30
2014	7	30	22	42	18	0.305	0.072	0.837	0.033	0.03	0	48.2	46.4	69.7	142	139	0	30	31
2014	7	30	22	52	18	0.285	0.121	0.837	0.039	0.039	0	48.2	47.3	68.8	143	141	0	31	31
2014	7	30	23	2	18	0.276	0.003	0.84	0.033	0.03	0	48.6	48.2	69.2	144	142	0	31	30
2014	7	30	23	12	18	0.262	0	0.84	0.036	0.033	0	48.2	47.7	69.7	143	141	0	31	30
2014	7	30	23	22	18	0.236	0.016	0.84	0.033	0.03	0	47.7	48.2	70.5	142	142	0	31	30
2014	7	30	23	32	18	0.285	0.069	0.84	0.036	0.033	0	48.2	47.3	70.1	143	141	0	31	31
2014	7	30	23	42	18	0.292	0.02	0.837	0.033	0.03	0	48.2	46.9	69.7	143	140	0	31	31
2014	7	30	23	52	18	0.338	0.016	0.84	0.039	0.036	0	48.2	47.3	69.7	143	140	0	31	30
2014	7	31	0	2	18	0.315	0.036	0.84	0.039	0.036	0	48.6	47.3	69.2	144	140	0	31	30
2014	7	31	0	12	18	0.305	0.102	0.84	0.036	0.033	0	47.3	47.7	70.1	141	141	0	31	30
2014	7	31	0	22	18	0.276	0.003	0.84	0.033	0.03	0	46.9	46.4	71	141	138	0	32	30
2014	7	31	0	32	18	0.276	0.085	0.84	0.033	0.03	0	46.9	47.3	70.5	141	140	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	0	42	18	0.295	0.072	0.84	0.039	0.036	0	47.7	46.9	70.5	142	140	0	31	31
2014	7	31	0	52	18	0.207	0.03	0.84	0.039	0.036	0	47.7	46.4	70.1	142	139	0	31	31
2014	7	31	1	2	18	0.305	0.046	0.84	0.039	0.036	0	47.3	46.4	70.5	142	138	0	32	30
2014	7	31	1	12	18	0.276	0.066	0.84	0.036	0.033	0	48.2	47.7	69.7	143	141	0	31	30
2014	7	31	1	22	18	0.262	0.023	0.84	0.043	0.039	0	48.6	47.7	68.8	144	141	0	31	30
2014	7	31	1	32	18	0.249	-0.03	0.84	0.039	0.036	0	48.6	47.7	70.5	143	141	0	30	30
2014	7	31	1	42	18	0.243	0.036	0.84	0.043	0.039	0	48.6	47.3	69.7	144	140	0	31	30
2014	7	31	1	52	18	0.308	0.033	0.84	0.036	0.033	0	47.3	46.9	70.5	141	140	0	31	31
2014	7	31	2	2	18	0.256	0	0.84	0.033	0.03	0	47.3	46.9	71	141	139	0	31	30
2014	7	31	2	12	18	0.259	0.066	0.84	0.03	0.03	0	46.9	46.9	70.5	141	139	0	32	30
2014	7	31	2	22	18	0.246	0.043	0.84	0.039	0.036	0	46.9	46.9	70.5	140	139	0	31	30
2014	7	31	2	32	18	0.272	0.062	0.84	0.033	0.03	0	46.9	46.9	71.4	140	139	0	31	30
2014	7	31	2	42	18	0.331	0.02	0.84	0.033	0.03	0	46.9	46.4	71	140	138	0	31	30
2014	7	31	2	52	18	0.259	0.059	0.837	0.039	0.036	0	46.4	46.9	71.4	140	139	0	32	30
2014	7	31	3	2	18	0.213	-0.066	0.837	0.039	0.036	0	46.9	46.4	71	140	138	0	31	30
2014	7	31	3	12	18	0.246	0.049	0.84	0.033	0.03	0	47.3	47.3	70.5	141	141	0	31	31
2014	7	31	3	22	18	0.266	0.026	0.837	0.033	0.03	0	47.7	46	70.1	142	138	0	31	31
2014	7	31	3	32	18	0.315	0.043	0.837	0.043	0.039	0	46.9	46.4	69.7	140	139	0	31	31
2014	7	31	3	42	18	0.318	0.007	0.837	0.033	0.03	0	47.7	46.9	71.4	142	139	0	31	30
2014	7	31	3	52	18	0.246	-0.039	0.837	0.033	0.03	0	47.7	45.6	70.1	142	137	0	31	31
2014	7	31	4	2	18	0.246	0.026	0.837	0.033	0.03	0	46.9	46.9	70.5	141	140	0	32	31
2014	7	31	4	12	18	0.23	0.01	0.837	0.036	0.033	0	47.7	47.3	69.2	142	141	0	31	31
2014	7	31	4	22	18	0.233	0	0.837	0.039	0.039	0	47.3	46.9	70.1	141	139	0	31	30
2014	7	31	4	32	18	0.23	0.003	0.837	0.036	0.033	0	47.3	46.9	70.5	141	139	0	31	30
2014	7	31	4	42	18	0.282	0	0.833	0.036	0.033	0	47.3	47.3	70.1	141	140	0	31	30
2014	7	31	4	52	18	0.305	-0.013	0.833	0.033	0.03	0	47.7	47.3	69.2	142	140	0	31	30
2014	7	31	5	2	18	0.24	-0.007	0.833	0.033	0.03	0	48.2	47.3	69.7	143	141	0	31	31
2014	7	31	5	12	18	0.299	0.033	0.833	0.036	0.033	0	47.3	46.9	69.7	141	139	0	31	30
2014	7	31	5	22	18	0.276	0.033	0.833	0.033	0.03	0	47.3	47.3	69.7	141	140	0	31	30
2014	7	31	5	32	18	0.282	0.049	0.83	0.036	0.033	0	48.2	47.3	68.8	142	141	0	30	31
2014	7	31	5	42	18	0.289	-0.013	0.83	0.033	0.03	0	47.3	47.7	69.2	141	141	0	31	30
2014	7	31	5	52	18	0.325	0.075	0.83	0.033	0.03	0	46.4	45.6	71	139	137	0	31	31
2014	7	31	6	2	18	0.253	0.033	0.827	0.036	0.033	0	46	46.4	71	138	138	0	31	30
2014	7	31	6	12	18	0.305	0.023	0.827	0.03	0.03	0	45.6	46	70.1	137	138	0	31	31
2014	7	31	6	22	18	0.289	0.066	0.827	0.039	0.036	0	46	45.2	70.1	138	136	0	31	31
2014	7	31	6	32	18	0.21	-0.023	0.827	0.036	0.033	0	45.6	45.6	70.1	137	137	0	31	31
2014	7	31	6	42	18	0.243	0.066	0.827	0.039	0.036	0	45.2	45.6	70.1	136	136	0	31	30
2014	7	31	6	52	18	0.308	-0.003	0.823	0.033	0.03	0	45.2	45.2	70.5	137	136	0	32	31
2014	7	31	7	2	18	0.338	0.049	0.823	0.039	0.036	0	45.6	45.2	71	137	135	0	31	30
2014	7	31	7	12	18	0.21	0.052	0.823	0.033	0.03	0	45.6	46	71.4	137	137	0	31	30
2014	7	31	7	22	18	0.223	-0.016	0.823	0.039	0.036	0	44.7	44.7	71	136	134	0	32	30
2014	7	31	7	32	18	0.276	-0.049	0.823	0.036	0.033	0	45.2	45.2	71.4	137	135	0	32	30
2014	7	31	7	42	18	0.282	0.089	0.823	0.033	0.03	0	46	45.2	71	138	135	0	31	30
2014	7	31	7	52	18	0.259	0.016	0.82	0.039	0.036	0	45.2	45.6	71	136	136	0	31	30
2014	7	31	8	2	18	0.24	-0.023	0.823	0.039	0.036	0	45.2	45.2	71	136	136	0	31	31
2014	7	31	8	12	18	0.299	0.089	0.82	0.033	0.03	0	45.2	45.2	71.8	137	136	0	32	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	8	22	18	0.226	0.033	0.82	0.033	0.03	0	45.2	45.2	71.4	136	136	0	31	31
2014	7	31	8	32	18	0.223	0.049	0.82	0.043	0.043	0	46	45.2	71.8	138	136	0	31	31
2014	7	31	8	42	18	0.246	0.003	0.82	0.033	0.03	0	45.6	45.2	71.4	138	136	0	32	31
2014	7	31	8	52	18	0.262	0.016	0.82	0.036	0.033	0	45.6	44.7	71.8	138	135	0	32	31
2014	7	31	9	2	18	0.262	0.043	0.82	0.033	0.03	0	46	45.2	71.8	138	135	0	31	30
2014	7	31	9	12	18	0.233	0.013	0.82	0.036	0.033	0	46	46	72.2	138	138	0	31	31
2014	7	31	9	22	18	0.289	0.013	0.82	0.036	0.033	0	45.6	44.7	72.7	137	135	0	31	31
2014	7	31	9	32	18	0.312	0.089	0.82	0.033	0.03	0	45.2	45.6	72.2	136	136	0	31	30
2014	7	31	9	42	18	0.253	0.01	0.82	0.036	0.033	0	46	46	72.7	138	138	0	31	31
2014	7	31	9	52	18	0.276	0.108	0.82	0.036	0.033	0	46.4	45.6	71	139	137	0	31	31
2014	7	31	10	2	18	0.276	0.115	0.82	0.039	0.036	0	47.7	46.9	71.8	142	139	0	31	30
2014	7	31	10	12	18	0.308	0.131	0.82	0.033	0.03	0	47.7	46.9	71.8	142	140	0	31	31
2014	7	31	10	22	18	0.246	0.075	0.817	0.036	0.033	0	47.3	46.9	71.8	141	139	0	31	30
2014	7	31	10	32	18	0.236	0.049	0.82	0.036	0.033	0	47.3	46.9	72.7	141	139	0	31	30
2014	7	31	10	42	18	0.272	0.046	0.817	0.036	0.033	0	46.9	46.9	73.1	140	139	0	31	30
2014	7	31	10	52	18	0.262	0.105	0.817	0.033	0.03	0	46.9	46.4	72.7	140	139	0	31	31
2014	7	31	11	2	18	0.276	0.141	0.817	0.033	0.03	0	46.9	46.9	72.7	140	139	0	31	30
2014	7	31	11	12	18	0.266	0.075	0.817	0.033	0.03	0	47.3	46.4	73.5	141	139	0	31	31
2014	7	31	11	22	18	0.299	0.148	0.817	0.039	0.036	0	47.3	46.9	72.7	141	140	0	31	31
2014	7	31	11	32	18	0.217	0.167	0.817	0.033	0.03	0	46.9	46.9	74	140	139	0	31	30
2014	7	31	11	42	18	0.315	0.075	0.817	0.033	0.03	0	47.3	46.9	73.5	141	139	0	31	30
2014	7	31	11	52	18	0.2	0.069	0.817	0.036	0.033	0	47.3	47.3	72.7	141	140	0	31	30
2014	7	31	12	2	18	0.217	0.013	0.82	0.039	0.036	0	46.9	46.4	74	140	139	0	31	31
2014	7	31	12	12	18	0.256	0.052	0.82	0.036	0.033	0	46.9	46.4	73.1	140	138	0	31	30
2014	7	31	12	22	18	0.272	0.052	0.82	0.033	0.03	0	47.7	46.9	71.4	142	139	0	31	30
2014	7	31	12	32	18	0.187	0.033	0.823	0.039	0.039	0	46.9	46.9	72.2	140	139	0	31	30
2014	7	31	12	42	18	0.266	0.069	0.823	0.033	0.03	0	47.3	46.9	71.8	141	140	0	31	31
2014	7	31	12	52	18	0.318	0.039	0.823	0.036	0.033	0	47.7	47.7	71.4	142	141	0	31	30
2014	7	31	13	2	18	0.322	0.128	0.827	0.036	0.033	0	47.7	47.3	71.4	142	140	0	31	30
2014	7	31	13	12	18	0.262	0.108	0.83	0.039	0.036	0	48.2	47.3	71	143	140	0	31	30
2014	7	31	13	22	18	0.312	0.115	0.837	0.036	0.033	0	47.7	48.2	69.2	142	142	0	31	30
2014	7	31	13	32	18	0.351	0.052	0.84	0.033	0.03	0	48.2	48.2	69.7	142	141	0	30	29
2014	7	31	13	42	18	0.322	0.069	0.843	0.033	0.03	0	48.2	47.3	71	143	140	0	31	30
2014	7	31	13	52	18	0.285	0.118	0.846	0.033	0.03	0	48.6	47.7	71	143	141	0	30	30
2014	7	31	14	2	18	0.302	0.144	0.846	0.033	0.03	0	48.6	47.7	71	143	140	0	30	29
2014	7	31	14	12	18	0.384	0.075	0.85	0.033	0.03	0	48.6	47.7	71.4	143	141	0	30	30
2014	7	31	14	22	18	0.384	0.098	0.853	0.039	0.039	0	48.6	47.3	72.2	143	140	0	30	30
2014	7	31	14	32	18	0.338	0.092	0.853	0.036	0.033	0	48.6	48.2	73.5	143	141	0	30	29
2014	7	31	14	42	18	0.354	0.079	0.856	0.043	0.039	0	48.2	47.7	73.5	142	140	0	30	29
2014	7	31	14	52	18	0.377	0.148	0.856	0.039	0.036	0	48.6	47.3	72.7	143	140	0	30	30
2014	7	31	15	2	18	0.361	0.072	0.86	0.033	0.03	0	48.2	46.9	74	142	138	0	30	29
2014	7	31	15	12	18	0.371	0.148	0.86	0.033	0.03	0	48.2	47.3	74.8	142	139	0	30	29
2014	7	31	15	22	18	0.381	0.138	0.86	0.039	0.036	0	47.7	46.9	74.4	141	138	0	30	29
2014	7	31	15	32	18	0.302	0.098	0.863	0.036	0.033	0	47.7	46.4	74.8	141	137	0	30	29
2014	7	31	15	42	18	0.325	0.049	0.863	0.033	0.03	0	46.9	45.6	74.4	139	135	0	30	29
2014	7	31	15	52	18	0.404	0.2	0.863	0.039	0.036	0	46.9	45.6	74.8	139	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	16	2	18	0.328	0.131	0.863	0.039	0.036	0	46.4	45.2	75.3	138	134	0	30	29
2014	7	31	16	12	18	0.322	0.095	0.866	0.039	0.036	0	46.4	44.7	74.4	138	134	0	30	30
2014	7	31	16	22	18	0.292	0.151	0.866	0.039	0.036	0	45.6	45.2	74.8	136	134	0	30	29
2014	7	31	16	32	18	0.39	0.098	0.866	0.039	0.036	0	45.6	45.2	75.3	137	134	0	31	29
2014	7	31	16	42	18	0.348	0.151	0.866	0.039	0.036	0	47.7	46.4	73.5	140	138	0	29	30
2014	7	31	16	52	18	0.387	0.02	0.866	0.039	0.039	0	46.4	46	74.4	138	136	0	30	29
2014	7	31	17	2	18	0.41	0.131	0.869	0.039	0.036	0	46	45.6	74.4	137	134	0	30	28
2014	7	31	17	12	18	0.374	0.2	0.869	0.033	0.03	0	46	45.6	73.5	138	135	0	31	29
2014	7	31	17	22	18	0.423	0.148	0.869	0.043	0.039	0	46	45.2	74.4	137	134	0	30	29
2014	7	31	17	32	18	0.354	0.108	0.869	0.036	0.033	0	45.6	44.7	73.5	136	133	0	30	29
2014	7	31	17	42	18	0.335	0.112	0.869	0.039	0.036	0	45.2	44.7	74	135	133	0	30	29
2014	7	31	17	52	18	0.338	0.115	0.869	0.039	0.036	0	45.6	44.7	74	136	133	0	30	29
2014	7	31	18	2	18	0.364	0.21	0.869	0.033	0.03	0	44.7	44.3	72.7	134	132	0	30	29
2014	7	31	18	12	18	0.374	0.128	0.869	0.039	0.036	0	44.7	44.3	73.1	134	132	0	30	29
2014	7	31	18	22	18	0.387	0.121	0.869	0.039	0.036	0	44.7	44.3	73.5	134	132	0	30	29
2014	7	31	18	32	18	0.377	0.056	0.873	0.039	0.036	0	44.7	43.9	73.5	134	131	0	30	29
2014	7	31	18	42	18	0.443	0.095	0.873	0.046	0.043	0	44.7	43.4	73.1	134	131	0	30	30
2014	7	31	18	52	18	0.351	0.098	0.873	0.043	0.043	0	44.7	44.3	73.1	134	132	0	30	29
2014	7	31	19	2	18	0.443	0.066	0.873	0.036	0.033	0	45.6	44.3	72.2	136	133	0	30	30
2014	7	31	19	12	18	0.315	0.056	0.873	0.039	0.036	0	45.6	44.7	72.7	136	133	0	30	29
2014	7	31	19	22	18	0.348	0.056	0.873	0.039	0.036	0	45.6	44.3	71.8	136	133	0	30	30
2014	7	31	19	32	18	0.459	0.085	0.873	0.036	0.033	0	45.6	44.7	71.8	136	133	0	30	29
2014	7	31	19	42	18	0.367	0.075	0.873	0.039	0.036	0	45.2	44.3	71.4	135	132	0	30	29
2014	7	31	19	52	18	0.361	0.072	0.873	0.033	0.03	0	45.2	44.3	72.7	135	133	0	30	30
2014	7	31	20	2	18	0.328	0.066	0.876	0.039	0.039	0	45.2	45.2	71.8	135	134	0	30	29
2014	7	31	20	12	18	0.312	0.066	0.876	0.039	0.036	0	45.6	44.7	71	136	133	0	30	29
2014	7	31	20	22	18	0.344	0.007	0.879	0.036	0.033	0	45.2	45.2	71.8	135	134	0	30	29
2014	7	31	20	32	18	0.371	0.036	0.879	0.033	0.03	0	45.6	45.6	71.8	136	135	0	30	29
2014	7	31	20	42	18	0.394	0.033	0.883	0.039	0.036	0	46	45.2	71	137	134	0	30	29
2014	7	31	20	52	18	0.384	0.023	0.883	0.033	0.03	0	46	45.6	71.8	137	135	0	30	29
2014	7	31	21	2	18	0.367	0.049	0.883	0.039	0.036	0	46.4	45.2	71.4	138	135	0	30	30
2014	7	31	21	12	18	0.394	0.072	0.883	0.033	0.03	0	46.4	44.7	72.2	138	133	0	30	29
2014	7	31	21	22	18	0.4	0.046	0.886	0.039	0.036	0	46.9	46	70.5	139	136	0	30	29
2014	7	31	21	32	18	0.397	0.01	0.886	0.039	0.039	0	48.6	47.7	70.1	143	140	0	30	29
2014	7	31	21	42	18	0.344	-0.013	0.886	0.039	0.036	0	48.2	46.9	71	142	138	0	30	29
2014	7	31	21	52	18	0.341	0.089	0.889	0.036	0.033	0	46.9	46	71.8	139	136	0	30	29
2014	7	31	22	2	18	0.351	-0.016	0.889	0.033	0.03	0	46.4	46	72.2	138	136	0	30	29
2014	7	31	22	12	18	0.377	0.007	0.889	0.033	0.03	0	46.9	45.6	73.1	139	136	0	30	30
2014	7	31	22	22	18	0.381	0.026	0.889	0.039	0.036	0	46	46	71.4	138	136	0	31	29
2014	7	31	22	32	18	0.341	0.049	0.889	0.043	0.039	0	48.2	46.9	71.4	142	138	0	30	29
2014	7	31	22	42	18	0.325	-0.023	0.889	0.039	0.039	0	47.7	46	71.4	141	137	0	30	30
2014	7	31	22	52	18	0.397	0	0.889	0.039	0.039	0	46.9	45.6	72.7	140	136	0	31	30
2014	7	31	23	2	18	0.325	0.056	0.889	0.033	0.03	0	46.4	46	71.8	139	136	0	31	29
2014	7	31	23	12	18	0.377	0	0.889	0.039	0.036	0	46.9	46.4	72.7	139	137	0	30	29
2014	7	31	23	22	18	0.315	0	0.889	0.039	0.036	0	46.4	45.6	74	138	135	0	30	29
2014	7	31	23	32	18	0.305	0.075	0.892	0.033	0.03	0	46.4	45.6	73.1	138	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	23	42	18	0.325	-0.013	0.892	0.036	0.033	0	46	46.4	74	137	136	0	30	28
2014	7	31	23	52	18	0.377	0.026	0.892	0.036	0.033	0	46.4	45.6	73.1	138	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	0	0	9	31	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	1	0	10	9	31	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	1	0	20	9	31	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	1	0	30	9	31	0	0	0	0	0	0	0	74.41	0	0	12
2014	7	1	0	40	9	31	0	0	0	0	0	0	0	74.3	0	0	12
2014	7	1	0	50	9	31	0	0	0	0	0	0	0	74.19	0	0	12
2014	7	1	1	0	9	31	0	0	0	0	0	0	0	74.1	0	0	12
2014	7	1	1	10	9	31	0	0	0	0	0	0	0	73.98	0	0	12
2014	7	1	1	20	9	31	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	1	1	30	9	31	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	1	1	40	9	30	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	1	1	50	9	30	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	1	2	0	9	30	0	0	0	0	0	0	0	73.42	0	0	12
2014	7	1	2	10	9	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	1	2	20	9	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	1	2	30	9	31	0	0	0	0	0	0	0	73.08	0	0	12
2014	7	1	2	40	9	31	0	0	0	0	0	0	0	72.95	0	0	12
2014	7	1	2	50	9	32	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	1	3	0	9	31	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	1	3	10	9	31	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	1	3	20	9	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	1	3	30	9	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	1	3	40	9	30	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	1	3	50	9	32	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	1	4	0	9	32	0	0	0	0	0	0	0	71.83	0	0	12
2014	7	1	4	10	9	32	0	0	0	0	0	0	0	71.69	0	0	12
2014	7	1	4	20	9	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	1	4	30	9	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	1	4	40	9	31	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	1	4	50	9	30	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	1	5	0	9	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	1	5	10	9	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	1	5	20	9	32	0	0	0	0	0	0	0	70.61	0	0	12
2014	7	1	5	30	9	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	7	1	5	40	9	31	0	0	0	0	0	0	0	70.27	0	0	12
2014	7	1	5	50	9	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	7	1	6	0	9	32	0	0	0	0	0	0	0	69.94	0	0	12
2014	7	1	6	10	9	31	0	0	0	0	0	0	0	69.78	0	0	12
2014	7	1	6	20	9	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2014	7	1	6	30	9	31	0	0	0	0	0	0	0	69.49	0	0	12
2014	7	1	6	40	9	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	7	1	6	50	9	31	0	0	0	0	0	0	0	69.3	0	0	12.2
2014	7	1	7	0	9	31	0	0	0	0	0	0	0	69.22	0	0	12.2
2014	7	1	7	10	9	31	0	0	0	0	0	0	0	69.15	0	0	12.4
2014	7	1	7	20	9	32	0	0	0	0	0	0	0	69.12	0	0	12.4
2014	7	1	7	30	9	32	0	0	0	0	0	0	0	69.06	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	7	40	9	32	0	0	0	0	0	0	0	69.06	0	0	12.6
2014	7	1	7	50	9	32	0	0	0	0	0	0	0	69.08	0	0	12.8
2014	7	1	8	0	9	31	0	0	0	0	0	0	0	69.12	0	0	12.8
2014	7	1	8	10	9	31	0	0	0	0	0	0	0	69.19	0	0	13
2014	7	1	8	20	9	31	0	0	0	0	0	0	0	69.21	0	0	13
2014	7	1	8	30	9	32	0	0	0	0	0	0	0	69.28	0	0	13
2014	7	1	8	40	9	32	0	0	0	0	0	0	0	69.44	0	0	13.2
2014	7	1	8	50	9	32	0	0	0	0	0	0	0	69.51	0	0	13.2
2014	7	1	9	0	9	32	0	0	0	0	0	0	0	69.66	0	0	13.2
2014	7	1	9	10	9	32	0	0	0	0	0	0	0	69.82	0	0	13.2
2014	7	1	9	20	9	32	0	0	0	0	0	0	0	70.03	0	0	13.2
2014	7	1	9	30	9	32	0	0	0	0	0	0	0	70.23	0	0	13.2
2014	7	1	9	40	9	32	0	0	0	0	0	0	0	70.47	0	0	13.2
2014	7	1	9	50	9	31	0	0	0	0	0	0	0	70.66	0	0	13.2
2014	7	1	10	0	9	31	0	0	0	0	0	0	0	70.86	0	0	13.2
2014	7	1	10	10	9	31	0	0	0	0	0	0	0	71.15	0	0	13.2
2014	7	1	10	20	9	31	0	0	0	0	0	0	0	71.37	0	0	13
2014	7	1	10	30	9	31	0	0	0	0	0	0	0	71.62	0	0	13.2
2014	7	1	10	40	9	32	0	0	0	0	0	0	0	71.89	0	0	13.2
2014	7	1	10	50	9	31	0	0	0	0	0	0	0	72.21	0	0	13.2
2014	7	1	11	0	9	31	0	0	0	0	0	0	0	72.5	0	0	13.2
2014	7	1	11	10	9	31	0	0	0	0	0	0	0	72.81	0	0	13.2
2014	7	1	11	20	9	31	0	0	0	0	0	0	0	73.11	0	0	13.2
2014	7	1	11	30	9	31	0	0	0	0	0	0	0	73.44	0	0	13.2
2014	7	1	11	40	9	31	0	0	0	0	0	0	0	73.78	0	0	13.2
2014	7	1	11	50	9	30	0	0	0	0	0	0	0	73.9	0	0	13.2
2014	7	1	12	0	9	32	0	0	0	0	0	0	0	73.67	0	0	13.2
2014	7	1	12	10	9	30	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	1	12	20	9	31	0	0	0	0	0	0	0	74.26	0	0	13.2
2014	7	1	12	30	9	31	0	0	0	0	0	0	0	74.68	0	0	13.2
2014	7	1	12	40	9	31	0	0	0	0	0	0	0	75.06	0	0	13.2
2014	7	1	12	50	9	30	0	0	0	0	0	0	0	75.45	0	0	13.2
2014	7	1	13	0	9	30	0	0	0	0	0	0	0	75.85	0	0	13.2
2014	7	1	13	10	9	31	0	0	0	0	0	0	0	76.28	0	0	13.2
2014	7	1	13	20	9	31	0	0	0	0	0	0	0	77.02	0	0	13
2014	7	1	13	30	9	30	0	0	0	0	0	0	0	77.72	0	0	13.2
2014	7	1	13	40	9	30	0	0	0	0	0	0	0	78.24	0	0	13.2
2014	7	1	13	50	9	31	0	0	0	0	0	0	0	78.58	0	0	13.2
2014	7	1	14	0	9	31	0	0	0	0	0	0	0	78.94	0	0	13.2
2014	7	1	14	10	9	30	0	0	0	0	0	0	0	79.27	0	0	13.2
2014	7	1	14	20	9	30	0	0	0	0	0	0	0	79.57	0	0	13.2
2014	7	1	14	30	9	31	0	0	0	0	0	0	0	79.7	0	0	12.8
2014	7	1	14	40	9	30	0	0	0	0	0	0	0	79.5	0	0	12.4
2014	7	1	14	50	9	31	0	0	0	0	0	0	0	79.57	0	0	12.4
2014	7	1	15	0	9	30	0	0	0	0	0	0	0	79.74	0	0	12.6
2014	7	1	15	10	9	30	0	0	0	0	0	0	0	79.7	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	15	20	9	30	0	0	0	0	0	0	0	79.65	0	0	12.2
2014	7	1	15	30	9	31	0	0	0	0	0	0	0	79.54	0	0	12.4
2014	7	1	15	40	9	30	0	0	0	0	0	0	0	79.41	0	0	12.4
2014	7	1	15	50	9	30	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	1	16	0	9	30	0	0	0	0	0	0	0	79.32	0	0	12.4
2014	7	1	16	10	9	30	0	0	0	0	0	0	0	79.34	0	0	12.4
2014	7	1	16	20	9	29	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	1	16	30	9	30	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	1	16	40	9	30	0	0	0	0	0	0	0	79.54	0	0	12.6
2014	7	1	16	50	9	30	0	0	0	0	0	0	0	79.34	0	0	12.4
2014	7	1	17	0	9	31	0	0	0	0	0	0	0	79.56	0	0	12.4
2014	7	1	17	10	9	31	0	0	0	0	0	0	0	79.59	0	0	12.4
2014	7	1	17	20	9	31	0	0	0	0	0	0	0	79.45	0	0	12.2
2014	7	1	17	30	9	30	0	0	0	0	0	0	0	79.48	0	0	12.4
2014	7	1	17	40	9	31	0	0	0	0	0	0	0	79.38	0	0	12.4
2014	7	1	17	50	9	31	0	0	0	0	0	0	0	79.29	0	0	12.2
2014	7	1	18	0	9	30	0	0	0	0	0	0	0	79.21	0	0	12.2
2014	7	1	18	10	9	31	0	0	0	0	0	0	0	79.12	0	0	12.2
2014	7	1	18	20	9	30	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	1	18	30	9	30	0	0	0	0	0	0	0	78.87	0	0	12.2
2014	7	1	18	40	9	30	0	0	0	0	0	0	0	78.75	0	0	12.2
2014	7	1	18	50	9	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	1	19	0	9	30	0	0	0	0	0	0	0	78.4	0	0	12.2
2014	7	1	19	10	9	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2014	7	1	19	20	9	30	0	0	0	0	0	0	0	78.03	0	0	12.2
2014	7	1	19	30	9	31	0	0	0	0	0	0	0	77.81	0	0	12.2
2014	7	1	19	40	9	30	0	0	0	0	0	0	0	77.58	0	0	12.2
2014	7	1	19	50	9	30	0	0	0	0	0	0	0	77.38	0	0	12.2
2014	7	1	20	0	9	31	0	0	0	0	0	0	0	77.16	0	0	12.2
2014	7	1	20	10	9	31	0	0	0	0	0	0	0	77	0	0	12.2
2014	7	1	20	20	9	30	0	0	0	0	0	0	0	76.82	0	0	12.2
2014	7	1	20	30	9	31	0	0	0	0	0	0	0	76.66	0	0	12.2
2014	7	1	20	40	9	31	0	0	0	0	0	0	0	76.5	0	0	12.2
2014	7	1	20	50	9	31	0	0	0	0	0	0	0	76.35	0	0	12.2
2014	7	1	21	0	9	30	0	0	0	0	0	0	0	76.21	0	0	12.2
2014	7	1	21	10	9	30	0	0	0	0	0	0	0	76.06	0	0	12.2
2014	7	1	21	20	9	31	0	0	0	0	0	0	0	75.9	0	0	12
2014	7	1	21	30	9	31	0	0	0	0	0	0	0	75.72	0	0	12.2
2014	7	1	21	40	9	30	0	0	0	0	0	0	0	75.56	0	0	12.2
2014	7	1	21	50	9	30	0	0	0	0	0	0	0	75.4	0	0	12.2
2014	7	1	22	0	9	31	0	0	0	0	0	0	0	75.24	0	0	12.2
2014	7	1	22	10	9	31	0	0	0	0	0	0	0	75.11	0	0	12.2
2014	7	1	22	20	9	32	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	1	22	30	9	31	0	0	0	0	0	0	0	74.84	0	0	12.2
2014	7	1	22	40	9	30	0	0	0	0	0	0	0	74.71	0	0	12.2
2014	7	1	22	50	9	30	0	0	0	0	0	0	0	74.59	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	23	0	9	31	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	1	23	10	9	31	0	0	0	0	0	0	0	74.35	0	0	12
2014	7	1	23	20	9	30	0	0	0	0	0	0	0	74.26	0	0	12
2014	7	1	23	30	9	30	0	0	0	0	0	0	0	74.16	0	0	12
2014	7	1	23	40	9	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	1	23	50	9	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	2	0	0	9	31	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	2	0	10	9	31	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	2	0	20	9	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	2	0	30	9	30	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	2	0	40	9	31	0	0	0	0	0	0	0	73.4	0	0	12
2014	7	2	0	50	9	31	0	0	0	0	0	0	0	73.27	0	0	12
2014	7	2	1	0	9	31	0	0	0	0	0	0	0	73.17	0	0	12
2014	7	2	1	10	9	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	2	1	20	9	31	0	0	0	0	0	0	0	72.95	0	0	12
2014	7	2	1	30	9	31	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	2	1	40	9	31	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	2	1	50	9	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	2	2	0	9	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	2	2	10	9	31	0	0	0	0	0	0	0	72.46	0	0	12
2014	7	2	2	20	9	30	0	0	0	0	0	0	0	72.36	0	0	12
2014	7	2	2	30	9	31	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	2	2	40	9	32	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	2	2	50	9	30	0	0	0	0	0	0	0	72	0	0	12
2014	7	2	3	0	9	31	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	2	3	10	9	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	2	3	20	9	32	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	2	3	30	9	31	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	2	3	40	9	31	0	0	0	0	0	0	0	71.29	0	0	12
2014	7	2	3	50	9	31	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	2	4	0	9	31	0	0	0	0	0	0	0	71.01	0	0	12
2014	7	2	4	10	9	31	0	0	0	0	0	0	0	70.86	0	0	12
2014	7	2	4	20	9	31	0	0	0	0	0	0	0	70.72	0	0	12
2014	7	2	4	30	9	32	0	0	0	0	0	0	0	70.57	0	0	12
2014	7	2	4	40	9	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	7	2	4	50	9	31	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	2	5	0	9	31	0	0	0	0	0	0	0	70.16	0	0	12
2014	7	2	5	10	9	32	0	0	0	0	0	0	0	70.02	0	0	12
2014	7	2	5	20	9	32	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	2	5	30	9	31	0	0	0	0	0	0	0	69.71	0	0	12
2014	7	2	5	40	9	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	7	2	5	50	9	32	0	0	0	0	0	0	0	69.4	0	0	12
2014	7	2	6	0	9	32	0	0	0	0	0	0	0	69.26	0	0	12
2014	7	2	6	10	9	31	0	0	0	0	0	0	0	69.12	0	0	12
2014	7	2	6	20	9	31	0	0	0	0	0	0	0	68.97	0	0	11.8
2014	7	2	6	30	9	32	0	0	0	0	0	0	0	68.85	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	6	40	9	32	0	0	0	0	0	0	0	68.7	0	0	12
2014	7	2	6	50	9	31	0	0	0	0	0	0	0	68.67	0	0	12.2
2014	7	2	7	0	9	32	0	0	0	0	0	0	0	68.65	0	0	12.2
2014	7	2	7	10	9	32	0	0	0	0	0	0	0	68.63	0	0	12.4
2014	7	2	7	20	9	32	0	0	0	0	0	0	0	68.58	0	0	12.2
2014	7	2	7	30	9	31	0	0	0	0	0	0	0	68.58	0	0	12.6
2014	7	2	7	40	9	31	0	0	0	0	0	0	0	68.61	0	0	12.6
2014	7	2	7	50	9	31	0	0	0	0	0	0	0	68.63	0	0	12.8
2014	7	2	8	0	9	32	0	0	0	0	0	0	0	68.7	0	0	12.8
2014	7	2	8	10	9	32	0	0	0	0	0	0	0	68.79	0	0	13
2014	7	2	8	20	9	32	0	0	0	0	0	0	0	68.86	0	0	13
2014	7	2	8	30	9	31	0	0	0	0	0	0	0	68.99	0	0	13
2014	7	2	8	40	9	32	0	0	0	0	0	0	0	69.08	0	0	13.2
2014	7	2	8	50	9	31	0	0	0	0	0	0	0	69.24	0	0	13.2
2014	7	2	9	0	9	32	0	0	0	0	0	0	0	69.35	0	0	13.2
2014	7	2	9	10	9	32	0	0	0	0	0	0	0	69.51	0	0	13.2
2014	7	2	9	20	9	32	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	2	9	30	9	32	0	0	0	0	0	0	0	69.53	0	0	13.4
2014	7	2	9	40	9	31	0	0	0	0	0	0	0	69.71	0	0	13.4
2014	7	2	9	50	9	32	0	0	0	0	0	0	0	69.93	0	0	13.4
2014	7	2	10	0	9	31	0	0	0	0	0	0	0	70.16	0	0	13.2
2014	7	2	10	10	9	31	0	0	0	0	0	0	0	70.41	0	0	13.2
2014	7	2	10	20	9	32	0	0	0	0	0	0	0	70.65	0	0	13.2
2014	7	2	10	30	9	31	0	0	0	0	0	0	0	70.9	0	0	13.2
2014	7	2	10	40	9	31	0	0	0	0	0	0	0	71.13	0	0	13.2
2014	7	2	10	50	9	31	0	0	0	0	0	0	0	71.47	0	0	13.2
2014	7	2	11	0	9	31	0	0	0	0	0	0	0	71.71	0	0	13.2
2014	7	2	11	10	9	32	0	0	0	0	0	0	0	72.01	0	0	13.2
2014	7	2	11	20	9	32	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	2	11	30	9	31	0	0	0	0	0	0	0	72.63	0	0	13.2
2014	7	2	11	40	9	32	0	0	0	0	0	0	0	72.95	0	0	13.2
2014	7	2	11	50	9	31	0	0	0	0	0	0	0	73.13	0	0	13.2
2014	7	2	12	0	9	31	0	0	0	0	0	0	0	72.99	0	0	13.2
2014	7	2	12	10	9	32	0	0	0	0	0	0	0	73.22	0	0	13.2
2014	7	2	12	20	9	31	0	0	0	0	0	0	0	73.56	0	0	13.2
2014	7	2	12	30	9	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	2	12	40	9	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2014	7	2	12	50	9	30	0	0	0	0	0	0	0	74.68	0	0	13.2
2014	7	2	13	0	9	31	0	0	0	0	0	0	0	75.06	0	0	13.2
2014	7	2	13	10	9	30	0	0	0	0	0	0	0	75.47	0	0	13.2
2014	7	2	13	20	9	31	0	0	0	0	0	0	0	76.19	0	0	13
2014	7	2	13	30	9	31	0	0	0	0	0	0	0	76.82	0	0	13.2
2014	7	2	13	40	9	30	0	0	0	0	0	0	0	77.27	0	0	13.2
2014	7	2	13	50	9	31	0	0	0	0	0	0	0	77.67	0	0	13.2
2014	7	2	14	0	9	31	0	0	0	0	0	0	0	78.01	0	0	13.2
2014	7	2	14	10	9	30	0	0	0	0	0	0	0	78.35	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	14	20	9	30	0	0	0	0	0	0	0	78.71	0	0	13
2014	7	2	14	30	9	30	0	0	0	0	0	0	0	79	0	0	13.2
2014	7	2	14	40	9	30	0	0	0	0	0	0	0	79.29	0	0	13.2
2014	7	2	14	50	9	31	0	0	0	0	0	0	0	79.59	0	0	13
2014	7	2	15	0	9	31	0	0	0	0	0	0	0	79.66	0	0	12.8
2014	7	2	15	10	9	30	0	0	0	0	0	0	0	79.95	0	0	13
2014	7	2	15	20	9	30	0	0	0	0	0	0	0	79.9	0	0	12.6
2014	7	2	15	30	9	30	0	0	0	0	0	0	0	80.13	0	0	12.8
2014	7	2	15	40	9	30	0	0	0	0	0	0	0	80.4	0	0	13
2014	7	2	15	50	9	30	0	0	0	0	0	0	0	80.44	0	0	12.8
2014	7	2	16	0	9	30	0	0	0	0	0	0	0	80.65	0	0	12.8
2014	7	2	16	10	9	30	0	0	0	0	0	0	0	80.74	0	0	12.8
2014	7	2	16	20	9	30	0	0	0	0	0	0	0	80.83	0	0	12.6
2014	7	2	16	30	9	30	0	0	0	0	0	0	0	80.74	0	0	12.6
2014	7	2	16	40	9	31	0	0	0	0	0	0	0	80.94	0	0	12.6
2014	7	2	16	50	9	30	0	0	0	0	0	0	0	80.94	0	0	12.4
2014	7	2	17	0	9	30	0	0	0	0	0	0	0	80.87	0	0	12.4
2014	7	2	17	10	9	30	0	0	0	0	0	0	0	80.96	0	0	12.4
2014	7	2	17	20	9	30	0	0	0	0	0	0	0	80.98	0	0	12.4
2014	7	2	17	30	9	30	0	0	0	0	0	0	0	80.91	0	0	12.4
2014	7	2	17	40	9	30	0	0	0	0	0	0	0	80.76	0	0	12.4
2014	7	2	17	50	9	30	0	0	0	0	0	0	0	80.71	0	0	12.4
2014	7	2	18	0	9	30	0	0	0	0	0	0	0	80.65	0	0	12.4
2014	7	2	18	10	9	30	0	0	0	0	0	0	0	80.6	0	0	12.2
2014	7	2	18	20	9	30	0	0	0	0	0	0	0	80.53	0	0	12.2
2014	7	2	18	30	9	30	0	0	0	0	0	0	0	80.44	0	0	12.2
2014	7	2	18	40	9	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2014	7	2	18	50	9	30	0	0	0	0	0	0	0	80.26	0	0	12.2
2014	7	2	19	0	9	31	0	0	0	0	0	0	0	80.1	0	0	12.2
2014	7	2	19	10	9	30	0	0	0	0	0	0	0	79.95	0	0	12.2
2014	7	2	19	20	9	30	0	0	0	0	0	0	0	79.79	0	0	12.2
2014	7	2	19	30	9	31	0	0	0	0	0	0	0	79.65	0	0	12.2
2014	7	2	19	40	9	31	0	0	0	0	0	0	0	79.47	0	0	12.2
2014	7	2	19	50	9	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	2	20	0	9	30	0	0	0	0	0	0	0	79.16	0	0	12.2
2014	7	2	20	10	9	30	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	2	20	20	9	30	0	0	0	0	0	0	0	78.87	0	0	12
2014	7	2	20	30	9	31	0	0	0	0	0	0	0	78.73	0	0	12.2
2014	7	2	20	40	9	31	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	2	20	50	9	31	0	0	0	0	0	0	0	78.4	0	0	12.2
2014	7	2	21	0	9	31	0	0	0	0	0	0	0	78.24	0	0	12.2
2014	7	2	21	10	9	31	0	0	0	0	0	0	0	78.06	0	0	12.2
2014	7	2	21	20	9	30	0	0	0	0	0	0	0	77.88	0	0	12
2014	7	2	21	30	9	30	0	0	0	0	0	0	0	77.68	0	0	12.2
2014	7	2	21	40	9	31	0	0	0	0	0	0	0	77.5	0	0	12.2
2014	7	2	21	50	9	31	0	0	0	0	0	0	0	77.32	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	22	0	9	30	0	0	0	0	0	0	0	77.14	0	0	12.2
2014	7	2	22	10	9	31	0	0	0	0	0	0	0	76.95	0	0	12.2
2014	7	2	22	20	9	31	0	0	0	0	0	0	0	76.77	0	0	12
2014	7	2	22	30	9	30	0	0	0	0	0	0	0	76.59	0	0	12.2
2014	7	2	22	40	9	31	0	0	0	0	0	0	0	76.41	0	0	12.2
2014	7	2	22	50	9	31	0	0	0	0	0	0	0	76.24	0	0	12.2
2014	7	2	23	0	9	31	0	0	0	0	0	0	0	76.08	0	0	12.2
2014	7	2	23	10	9	30	0	0	0	0	0	0	0	75.92	0	0	12
2014	7	2	23	20	9	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	2	23	30	9	30	0	0	0	0	0	0	0	75.61	0	0	12
2014	7	2	23	40	9	30	0	0	0	0	0	0	0	75.47	0	0	12
2014	7	2	23	50	9	30	0	0	0	0	0	0	0	75.33	0	0	12
2014	7	3	0	0	9	30	0	0	0	0	0	0	0	75.18	0	0	12
2014	7	3	0	10	9	30	0	0	0	0	0	0	0	75.04	0	0	12
2014	7	3	0	20	9	31	0	0	0	0	0	0	0	74.89	0	0	12
2014	7	3	0	30	9	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	3	0	40	9	31	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	3	0	50	9	30	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	3	1	0	9	31	0	0	0	0	0	0	0	74.32	0	0	12
2014	7	3	1	10	9	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	3	1	20	9	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	3	1	30	9	31	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	3	1	40	9	31	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	3	1	50	9	30	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	3	2	0	9	31	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	3	2	10	9	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	3	2	20	9	31	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	3	2	30	9	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	3	2	40	9	31	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	3	2	50	9	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	3	3	0	9	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	3	3	10	9	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	3	3	20	9	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	3	3	30	9	30	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	3	3	40	9	32	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	3	3	50	9	31	0	0	0	0	0	0	0	72	0	0	12
2014	7	3	4	0	9	31	0	0	0	0	0	0	0	71.87	0	0	12
2014	7	3	4	10	9	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	3	4	20	9	31	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	3	4	30	9	32	0	0	0	0	0	0	0	71.46	0	0	12
2014	7	3	4	40	9	31	0	0	0	0	0	0	0	71.33	0	0	12
2014	7	3	4	50	9	32	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	3	5	0	9	31	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	3	5	10	9	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	3	5	20	9	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	3	5	30	9	31	0	0	0	0	0	0	0	70.65	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	5	40	9	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	3	5	50	9	32	0	0	0	0	0	0	0	70.36	0	0	12
2014	7	3	6	0	9	32	0	0	0	0	0	0	0	70.2	0	0	12
2014	7	3	6	10	9	32	0	0	0	0	0	0	0	70.03	0	0	12
2014	7	3	6	20	9	31	0	0	0	0	0	0	0	69.89	0	0	11.8
2014	7	3	6	30	9	32	0	0	0	0	0	0	0	69.75	0	0	12
2014	7	3	6	40	9	31	0	0	0	0	0	0	0	69.58	0	0	12
2014	7	3	6	50	9	32	0	0	0	0	0	0	0	69.53	0	0	12.2
2014	7	3	7	0	9	31	0	0	0	0	0	0	0	69.46	0	0	12.2
2014	7	3	7	10	9	32	0	0	0	0	0	0	0	69.39	0	0	12.4
2014	7	3	7	20	9	32	0	0	0	0	0	0	0	69.37	0	0	12.2
2014	7	3	7	30	9	31	0	0	0	0	0	0	0	69.33	0	0	12.6
2014	7	3	7	40	9	31	0	0	0	0	0	0	0	69.33	0	0	12.6
2014	7	3	7	50	9	32	0	0	0	0	0	0	0	69.33	0	0	12.8
2014	7	3	8	0	9	31	0	0	0	0	0	0	0	69.35	0	0	13
2014	7	3	8	10	9	32	0	0	0	0	0	0	0	69.4	0	0	13
2014	7	3	8	20	9	31	0	0	0	0	0	0	0	69.48	0	0	13
2014	7	3	8	30	9	31	0	0	0	0	0	0	0	69.57	0	0	13.2
2014	7	3	8	40	9	32	0	0	0	0	0	0	0	69.66	0	0	13.2
2014	7	3	8	50	9	31	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	3	9	0	9	31	0	0	0	0	0	0	0	69.85	0	0	13.2
2014	7	3	9	10	9	32	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	7	3	9	20	9	31	0	0	0	0	0	0	0	70.16	0	0	13.2
2014	7	3	9	30	9	32	0	0	0	0	0	0	0	70.34	0	0	13.2
2014	7	3	9	40	9	31	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	7	3	9	50	9	32	0	0	0	0	0	0	0	70.68	0	0	13.2
2014	7	3	10	0	9	32	0	0	0	0	0	0	0	70.9	0	0	13.2
2014	7	3	10	10	9	32	0	0	0	0	0	0	0	71.1	0	0	13.2
2014	7	3	10	20	9	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	7	3	10	30	9	32	0	0	0	0	0	0	0	71.55	0	0	13.2
2014	7	3	10	40	9	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	7	3	10	50	9	31	0	0	0	0	0	0	0	72.03	0	0	13.2
2014	7	3	11	0	9	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	3	11	10	9	31	0	0	0	0	0	0	0	72.55	0	0	13.2
2014	7	3	11	20	9	32	0	0	0	0	0	0	0	72.81	0	0	13.2
2014	7	3	11	30	9	31	0	0	0	0	0	0	0	73.11	0	0	13.2
2014	7	3	11	40	9	31	0	0	0	0	0	0	0	73.4	0	0	13.2
2014	7	3	11	50	9	31	0	0	0	0	0	0	0	73.45	0	0	13.2
2014	7	3	12	0	9	31	0	0	0	0	0	0	0	73.18	0	0	13.2
2014	7	3	12	10	9	32	0	0	0	0	0	0	0	73.35	0	0	13.2
2014	7	3	12	20	9	32	0	0	0	0	0	0	0	73.65	0	0	13.2
2014	7	3	12	30	9	31	0	0	0	0	0	0	0	73.96	0	0	13.2
2014	7	3	12	40	9	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2014	7	3	12	50	9	30	0	0	0	0	0	0	0	74.66	0	0	13.2
2014	7	3	13	0	9	31	0	0	0	0	0	0	0	75.06	0	0	13.2
2014	7	3	13	10	9	31	0	0	0	0	0	0	0	75.45	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	13	20	9	30	0	0	0	0	0	0	0	76.24	0	0	13.2
2014	7	3	13	30	9	31	0	0	0	0	0	0	0	76.89	0	0	13.2
2014	7	3	13	40	9	31	0	0	0	0	0	0	0	77.31	0	0	13.2
2014	7	3	13	50	9	31	0	0	0	0	0	0	0	77.7	0	0	13.2
2014	7	3	14	0	9	31	0	0	0	0	0	0	0	78.06	0	0	13.2
2014	7	3	14	10	9	31	0	0	0	0	0	0	0	78.39	0	0	13.2
2014	7	3	14	20	9	31	0	0	0	0	0	0	0	78.73	0	0	13
2014	7	3	14	30	9	30	0	0	0	0	0	0	0	79.07	0	0	13.2
2014	7	3	14	40	9	31	0	0	0	0	0	0	0	79.36	0	0	13.2
2014	7	3	14	50	9	31	0	0	0	0	0	0	0	79.65	0	0	13.2
2014	7	3	15	0	9	29	0	0	0	0	0	0	0	79.9	0	0	13
2014	7	3	15	10	9	30	0	0	0	0	0	0	0	80.19	0	0	13
2014	7	3	15	20	9	30	0	0	0	0	0	0	0	80.42	0	0	13
2014	7	3	15	30	9	30	0	0	0	0	0	0	0	80.69	0	0	13
2014	7	3	15	40	9	30	0	0	0	0	0	0	0	80.91	0	0	13
2014	7	3	15	50	9	30	0	0	0	0	0	0	0	81.14	0	0	13
2014	7	3	16	0	9	30	0	0	0	0	0	0	0	81.34	0	0	12.8
2014	7	3	16	10	9	30	0	0	0	0	0	0	0	81.54	0	0	12.8
2014	7	3	16	20	9	30	0	0	0	0	0	0	0	81.72	0	0	12.6
2014	7	3	16	30	9	30	0	0	0	0	0	0	0	81.88	0	0	12.6
2014	7	3	16	40	9	30	0	0	0	0	0	0	0	82.02	0	0	12.6
2014	7	3	16	50	9	30	0	0	0	0	0	0	0	82.13	0	0	12.4
2014	7	3	17	0	9	30	0	0	0	0	0	0	0	82.22	0	0	12.4
2014	7	3	17	10	9	30	0	0	0	0	0	0	0	82.35	0	0	12.4
2014	7	3	17	20	9	30	0	0	0	0	0	0	0	82.4	0	0	12.4
2014	7	3	17	30	9	30	0	0	0	0	0	0	0	82.4	0	0	12.4
2014	7	3	17	40	9	30	0	0	0	0	0	0	0	82.24	0	0	12.4
2014	7	3	17	50	9	30	0	0	0	0	0	0	0	82.22	0	0	12.4
2014	7	3	18	0	9	30	0	0	0	0	0	0	0	82.2	0	0	12.2
2014	7	3	18	10	9	30	0	0	0	0	0	0	0	82.15	0	0	12.2
2014	7	3	18	20	9	30	0	0	0	0	0	0	0	82.09	0	0	12.2
2014	7	3	18	30	9	29	0	0	0	0	0	0	0	82	0	0	12.2
2014	7	3	18	40	9	31	0	0	0	0	0	0	0	81.88	0	0	12.2
2014	7	3	18	50	9	30	0	0	0	0	0	0	0	81.73	0	0	12.2
2014	7	3	19	0	9	29	0	0	0	0	0	0	0	81.59	0	0	12.2
2014	7	3	19	10	9	30	0	0	0	0	0	0	0	81.41	0	0	12.2
2014	7	3	19	20	9	30	0	0	0	0	0	0	0	81.23	0	0	12.2
2014	7	3	19	30	9	29	0	0	0	0	0	0	0	81.05	0	0	12.2
2014	7	3	19	40	9	30	0	0	0	0	0	0	0	80.87	0	0	12.2
2014	7	3	19	50	9	30	0	0	0	0	0	0	0	80.71	0	0	12.2
2014	7	3	20	0	9	30	0	0	0	0	0	0	0	80.55	0	0	12.2
2014	7	3	20	10	9	31	0	0	0	0	0	0	0	80.38	0	0	12.2
2014	7	3	20	20	9	31	0	0	0	0	0	0	0	80.22	0	0	12.2
2014	7	3	20	30	9	30	0	0	0	0	0	0	0	80.06	0	0	12.2
2014	7	3	20	40	9	31	0	0	0	0	0	0	0	79.9	0	0	12.2
2014	7	3	20	50	9	30	0	0	0	0	0	0	0	79.72	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	21	0	9	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2014	7	3	21	10	9	30	0	0	0	0	0	0	0	79.36	0	0	12.2
2014	7	3	21	20	9	30	0	0	0	0	0	0	0	79.16	0	0	12
2014	7	3	21	30	9	31	0	0	0	0	0	0	0	78.96	0	0	12.2
2014	7	3	21	40	9	30	0	0	0	0	0	0	0	78.75	0	0	12.2
2014	7	3	21	50	9	30	0	0	0	0	0	0	0	78.53	0	0	12.2
2014	7	3	22	0	9	29	0	0	0	0	0	0	0	78.33	0	0	12.2
2014	7	3	22	10	9	31	0	0	0	0	0	0	0	78.12	0	0	12.2
2014	7	3	22	20	9	30	0	0	0	0	0	0	0	77.92	0	0	12
2014	7	3	22	30	9	30	0	0	0	0	0	0	0	77.68	0	0	12.2
2014	7	3	22	40	9	31	0	0	0	0	0	0	0	77.47	0	0	12.2
2014	7	3	22	50	9	30	0	0	0	0	0	0	0	77.27	0	0	12.2
2014	7	3	23	0	9	30	0	0	0	0	0	0	0	77.05	0	0	12.2
2014	7	3	23	10	9	30	0	0	0	0	0	0	0	76.87	0	0	12
2014	7	3	23	20	9	30	0	0	0	0	0	0	0	76.68	0	0	12
2014	7	3	23	30	9	31	0	0	0	0	0	0	0	76.5	0	0	12
2014	7	3	23	40	9	30	0	0	0	0	0	0	0	76.32	0	0	12
2014	7	3	23	50	9	31	0	0	0	0	0	0	0	76.14	0	0	12
2014	7	4	0	0	9	30	0	0	0	0	0	0	0	75.96	0	0	12
2014	7	4	0	10	9	31	0	0	0	0	0	0	0	75.79	0	0	12
2014	7	4	0	20	9	31	0	0	0	0	0	0	0	75.63	0	0	12
2014	7	4	0	30	9	30	0	0	0	0	0	0	0	75.47	0	0	12
2014	7	4	0	40	9	31	0	0	0	0	0	0	0	75.29	0	0	12
2014	7	4	0	50	9	30	0	0	0	0	0	0	0	75.11	0	0	12
2014	7	4	1	0	9	30	0	0	0	0	0	0	0	74.95	0	0	12
2014	7	4	1	10	9	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	4	1	20	9	31	0	0	0	0	0	0	0	74.59	0	0	12
2014	7	4	1	30	9	30	0	0	0	0	0	0	0	74.43	0	0	12
2014	7	4	1	40	9	30	0	0	0	0	0	0	0	74.26	0	0	12
2014	7	4	1	50	9	31	0	0	0	0	0	0	0	74.1	0	0	12
2014	7	4	2	0	9	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	4	2	10	9	30	0	0	0	0	0	0	0	73.78	0	0	12
2014	7	4	2	20	9	31	0	0	0	0	0	0	0	73.63	0	0	12
2014	7	4	2	30	9	31	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	4	2	40	9	30	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	4	2	50	9	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	4	3	0	9	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	4	3	10	9	30	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	4	3	20	9	31	0	0	0	0	0	0	0	72.81	0	0	12
2014	7	4	3	30	9	31	0	0	0	0	0	0	0	72.7	0	0	12
2014	7	4	3	40	9	31	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	4	3	50	9	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	4	4	0	9	31	0	0	0	0	0	0	0	72.3	0	0	12
2014	7	4	4	10	9	30	0	0	0	0	0	0	0	72.18	0	0	12
2014	7	4	4	20	9	31	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	4	30	9	32	0	0	0	0	0	0	0	71.89	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	4	40	9	32	0	0	0	0	0	0	0	71.76	0	0	12
2014	7	4	4	50	9	31	0	0	0	0	0	0	0	71.6	0	0	12
2014	7	4	5	0	9	32	0	0	0	0	0	0	0	71.46	0	0	12
2014	7	4	5	10	9	31	0	0	0	0	0	0	0	71.29	0	0	12
2014	7	4	5	20	9	32	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	4	5	30	9	31	0	0	0	0	0	0	0	71.01	0	0	12
2014	7	4	5	40	9	32	0	0	0	0	0	0	0	70.84	0	0	12
2014	7	4	5	50	9	32	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	4	6	0	9	31	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	4	6	10	9	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	7	4	6	20	9	31	0	0	0	0	0	0	0	70.27	0	0	11.8
2014	7	4	6	30	9	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	7	4	6	40	9	31	0	0	0	0	0	0	0	69.98	0	0	12
2014	7	4	6	50	9	32	0	0	0	0	0	0	0	69.96	0	0	12.2
2014	7	4	7	0	9	31	0	0	0	0	0	0	0	69.91	0	0	12.2
2014	7	4	7	10	9	32	0	0	0	0	0	0	0	69.89	0	0	12.4
2014	7	4	7	20	9	31	0	0	0	0	0	0	0	69.87	0	0	12.4
2014	7	4	7	30	9	32	0	0	0	0	0	0	0	69.87	0	0	12.6
2014	7	4	7	40	9	31	0	0	0	0	0	0	0	69.89	0	0	12.6
2014	7	4	7	50	9	32	0	0	0	0	0	0	0	69.87	0	0	12.8
2014	7	4	8	0	9	31	0	0	0	0	0	0	0	69.94	0	0	13
2014	7	4	8	10	9	31	0	0	0	0	0	0	0	69.98	0	0	13
2014	7	4	8	20	9	31	0	0	0	0	0	0	0	70.03	0	0	13
2014	7	4	8	30	9	32	0	0	0	0	0	0	0	70.14	0	0	13.2
2014	7	4	8	40	9	32	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	7	4	8	50	9	31	0	0	0	0	0	0	0	70.38	0	0	13.2
2014	7	4	9	0	9	31	0	0	0	0	0	0	0	70.48	0	0	13.2
2014	7	4	9	10	9	32	0	0	0	0	0	0	0	70.59	0	0	13.4
2014	7	4	9	20	9	32	0	0	0	0	0	0	0	70.77	0	0	13.2
2014	7	4	9	30	9	31	0	0	0	0	0	0	0	70.88	0	0	13.4
2014	7	4	9	40	9	31	0	0	0	0	0	0	0	71.06	0	0	13.4
2014	7	4	9	50	9	32	0	0	0	0	0	0	0	71.2	0	0	13.4
2014	7	4	10	0	9	31	0	0	0	0	0	0	0	71.4	0	0	13.4
2014	7	4	10	10	9	31	0	0	0	0	0	0	0	71.49	0	0	13.4
2014	7	4	10	20	9	32	0	0	0	0	0	0	0	71.74	0	0	13.4
2014	7	4	10	30	9	31	0	0	0	0	0	0	0	71.89	0	0	13.4
2014	7	4	10	40	9	31	0	0	0	0	0	0	0	72.07	0	0	13.4
2014	7	4	10	50	9	31	0	0	0	0	0	0	0	72.28	0	0	13.4
2014	7	4	11	0	9	31	0	0	0	0	0	0	0	72.46	0	0	13.4
2014	7	4	11	10	9	31	0	0	0	0	0	0	0	72.68	0	0	13.4
2014	7	4	11	20	9	31	0	0	0	0	0	0	0	72.93	0	0	13.4
2014	7	4	11	30	9	32	0	0	0	0	0	0	0	73.24	0	0	13.4
2014	7	4	11	40	9	31	0	0	0	0	0	0	0	73.47	0	0	13.4
2014	7	4	11	50	9	31	0	0	0	0	0	0	0	73.47	0	0	13.4
2014	7	4	12	0	9	31	0	0	0	0	0	0	0	73.15	0	0	13.4
2014	7	4	12	10	9	31	0	0	0	0	0	0	0	73.33	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	12	20	9	31	0	0	0	0	0	0	0	73.62	0	0	13.2
2014	7	4	12	30	9	31	0	0	0	0	0	0	0	73.92	0	0	13.4
2014	7	4	12	40	9	31	0	0	0	0	0	0	0	74.25	0	0	13.4
2014	7	4	12	50	9	31	0	0	0	0	0	0	0	74.59	0	0	13.4
2014	7	4	13	0	9	31	0	0	0	0	0	0	0	74.97	0	0	13.4
2014	7	4	13	10	9	31	0	0	0	0	0	0	0	75.34	0	0	13.4
2014	7	4	13	20	9	31	0	0	0	0	0	0	0	76.19	0	0	13.2
2014	7	4	13	30	9	31	0	0	0	0	0	0	0	76.82	0	0	13.2
2014	7	4	13	40	9	31	0	0	0	0	0	0	0	77.25	0	0	13.2
2014	7	4	13	50	9	31	0	0	0	0	0	0	0	77.63	0	0	13.2
2014	7	4	14	0	9	31	0	0	0	0	0	0	0	77.97	0	0	13.2
2014	7	4	14	10	9	30	0	0	0	0	0	0	0	78.3	0	0	13.2
2014	7	4	14	20	9	30	0	0	0	0	0	0	0	78.66	0	0	13.2
2014	7	4	14	30	9	31	0	0	0	0	0	0	0	78.94	0	0	13.2
2014	7	4	14	40	9	30	0	0	0	0	0	0	0	79.25	0	0	13.2
2014	7	4	14	50	9	31	0	0	0	0	0	0	0	79.48	0	0	13.2
2014	7	4	15	0	9	31	0	0	0	0	0	0	0	79.79	0	0	13.2
2014	7	4	15	10	9	30	0	0	0	0	0	0	0	80.02	0	0	13.2
2014	7	4	15	20	9	31	0	0	0	0	0	0	0	80.28	0	0	13
2014	7	4	15	30	9	30	0	0	0	0	0	0	0	80.53	0	0	13.2
2014	7	4	15	40	9	30	0	0	0	0	0	0	0	80.78	0	0	13.2
2014	7	4	15	50	9	30	0	0	0	0	0	0	0	81.03	0	0	13
2014	7	4	16	0	9	30	0	0	0	0	0	0	0	81.23	0	0	13
2014	7	4	16	10	9	30	0	0	0	0	0	0	0	81.45	0	0	12.8
2014	7	4	16	20	9	30	0	0	0	0	0	0	0	81.57	0	0	12.6
2014	7	4	16	30	9	30	0	0	0	0	0	0	0	81.75	0	0	12.6
2014	7	4	16	40	9	30	0	0	0	0	0	0	0	81.88	0	0	12.6
2014	7	4	16	50	9	30	0	0	0	0	0	0	0	81.97	0	0	12.4
2014	7	4	17	0	9	30	0	0	0	0	0	0	0	82.06	0	0	12.4
2014	7	4	17	10	9	30	0	0	0	0	0	0	0	82.17	0	0	12.4
2014	7	4	17	20	9	30	0	0	0	0	0	0	0	82.2	0	0	12.2
2014	7	4	17	30	9	30	0	0	0	0	0	0	0	82.24	0	0	12.4
2014	7	4	17	40	9	30	0	0	0	0	0	0	0	81.99	0	0	12.4
2014	7	4	17	50	9	30	0	0	0	0	0	0	0	81.93	0	0	12.4
2014	7	4	18	0	9	30	0	0	0	0	0	0	0	81.91	0	0	12.4
2014	7	4	18	10	9	30	0	0	0	0	0	0	0	81.88	0	0	12.4
2014	7	4	18	20	9	30	0	0	0	0	0	0	0	81.84	0	0	12.2
2014	7	4	18	30	9	30	0	0	0	0	0	0	0	81.81	0	0	12.2
2014	7	4	18	40	9	29	0	0	0	0	0	0	0	81.72	0	0	12.2
2014	7	4	18	50	9	30	0	0	0	0	0	0	0	81.63	0	0	12.2
2014	7	4	19	0	9	30	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	4	19	10	9	30	0	0	0	0	0	0	0	81.41	0	0	12.2
2014	7	4	19	20	9	29	0	0	0	0	0	0	0	81.3	0	0	12.2
2014	7	4	19	30	9	30	0	0	0	0	0	0	0	81.16	0	0	12.2
2014	7	4	19	40	9	29	0	0	0	0	0	0	0	81.03	0	0	12.2
2014	7	4	19	50	9	30	0	0	0	0	0	0	0	80.87	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	20	0	9	30	0	0	0	0	0	0	0	80.74	0	0	12.2
2014	7	4	20	10	9	30	0	0	0	0	0	0	0	80.58	0	0	12.2
2014	7	4	20	20	9	30	0	0	0	0	0	0	0	80.44	0	0	12.2
2014	7	4	20	30	9	31	0	0	0	0	0	0	0	80.29	0	0	12.2
2014	7	4	20	40	9	30	0	0	0	0	0	0	0	80.15	0	0	12.2
2014	7	4	20	50	9	31	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	4	21	0	9	30	0	0	0	0	0	0	0	79.84	0	0	12.2
2014	7	4	21	10	9	30	0	0	0	0	0	0	0	79.7	0	0	12.2
2014	7	4	21	20	9	30	0	0	0	0	0	0	0	79.52	0	0	12
2014	7	4	21	30	9	30	0	0	0	0	0	0	0	79.36	0	0	12.2
2014	7	4	21	40	9	30	0	0	0	0	0	0	0	79.18	0	0	12.2
2014	7	4	21	50	9	31	0	0	0	0	0	0	0	79	0	0	12.2
2014	7	4	22	0	9	30	0	0	0	0	0	0	0	78.82	0	0	12.2
2014	7	4	22	10	9	30	0	0	0	0	0	0	0	78.64	0	0	12.2
2014	7	4	22	20	9	31	0	0	0	0	0	0	0	78.42	0	0	12.2
2014	7	4	22	30	9	30	0	0	0	0	0	0	0	78.24	0	0	12.2
2014	7	4	22	40	9	31	0	0	0	0	0	0	0	78.06	0	0	12.2
2014	7	4	22	50	9	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2014	7	4	23	0	9	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	4	23	10	9	31	0	0	0	0	0	0	0	77.5	0	0	12.2
2014	7	4	23	20	9	31	0	0	0	0	0	0	0	77.31	0	0	12
2014	7	4	23	30	9	31	0	0	0	0	0	0	0	77.11	0	0	12.2
2014	7	4	23	40	9	31	0	0	0	0	0	0	0	76.95	0	0	12
2014	7	4	23	50	9	30	0	0	0	0	0	0	0	76.77	0	0	12
2014	7	5	0	0	9	30	0	0	0	0	0	0	0	76.6	0	0	12
2014	7	5	0	10	9	31	0	0	0	0	0	0	0	76.46	0	0	12
2014	7	5	0	20	9	30	0	0	0	0	0	0	0	76.3	0	0	12
2014	7	5	0	30	9	31	0	0	0	0	0	0	0	76.14	0	0	12
2014	7	5	0	40	9	31	0	0	0	0	0	0	0	75.97	0	0	12
2014	7	5	0	50	9	31	0	0	0	0	0	0	0	75.83	0	0	12
2014	7	5	1	0	9	31	0	0	0	0	0	0	0	75.67	0	0	12
2014	7	5	1	10	9	31	0	0	0	0	0	0	0	75.52	0	0	12
2014	7	5	1	20	9	31	0	0	0	0	0	0	0	75.38	0	0	12
2014	7	5	1	30	9	30	0	0	0	0	0	0	0	75.25	0	0	12
2014	7	5	1	40	9	31	0	0	0	0	0	0	0	75.11	0	0	12
2014	7	5	1	50	9	30	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	5	2	0	9	31	0	0	0	0	0	0	0	74.82	0	0	12
2014	7	5	2	10	9	31	0	0	0	0	0	0	0	74.66	0	0	12
2014	7	5	2	20	9	30	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	5	2	30	9	31	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	5	2	40	9	31	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	5	2	50	9	31	0	0	0	0	0	0	0	74.08	0	0	12
2014	7	5	3	0	9	31	0	0	0	0	0	0	0	73.92	0	0	12
2014	7	5	3	10	9	30	0	0	0	0	0	0	0	73.8	0	0	12
2014	7	5	3	20	9	30	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	5	3	30	9	31	0	0	0	0	0	0	0	73.51	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	3	40	9	31	0	0	0	0	0	0	0	73.36	0	0	12
2014	7	5	3	50	9	31	0	0	0	0	0	0	0	73.24	0	0	12
2014	7	5	4	0	9	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	5	4	10	9	30	0	0	0	0	0	0	0	72.97	0	0	12
2014	7	5	4	20	9	31	0	0	0	0	0	0	0	72.84	0	0	11.8
2014	7	5	4	30	9	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	5	4	40	9	31	0	0	0	0	0	0	0	72.59	0	0	12
2014	7	5	4	50	9	31	0	0	0	0	0	0	0	72.48	0	0	12
2014	7	5	5	0	9	31	0	0	0	0	0	0	0	72.37	0	0	12
2014	7	5	5	10	9	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	5	5	20	9	31	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	5	5	30	9	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	5	5	40	9	31	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	5	5	50	9	31	0	0	0	0	0	0	0	71.76	0	0	12
2014	7	5	6	0	9	32	0	0	0	0	0	0	0	71.67	0	0	12
2014	7	5	6	10	9	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	5	6	20	9	32	0	0	0	0	0	0	0	71.42	0	0	12
2014	7	5	6	30	9	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	7	5	6	40	9	32	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	5	6	50	9	31	0	0	0	0	0	0	0	71.2	0	0	12.2
2014	7	5	7	0	9	31	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	7	5	7	10	9	31	0	0	0	0	0	0	0	71.22	0	0	12.4
2014	7	5	7	20	9	31	0	0	0	0	0	0	0	71.2	0	0	12.2
2014	7	5	7	30	9	31	0	0	0	0	0	0	0	71.35	0	0	12.4
2014	7	5	7	40	9	31	0	0	0	0	0	0	0	71.38	0	0	12.6
2014	7	5	7	50	9	31	0	0	0	0	0	0	0	71.44	0	0	12.8
2014	7	5	8	0	9	32	0	0	0	0	0	0	0	71.47	0	0	12.8
2014	7	5	8	10	9	31	0	0	0	0	0	0	0	71.58	0	0	13
2014	7	5	8	20	9	31	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	5	8	30	9	31	0	0	0	0	0	0	0	71.82	0	0	13
2014	7	5	8	40	9	32	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	5	8	50	9	31	0	0	0	0	0	0	0	72.09	0	0	13.2
2014	7	5	9	0	9	31	0	0	0	0	0	0	0	72.19	0	0	13.2
2014	7	5	9	10	9	30	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	7	5	9	20	9	31	0	0	0	0	0	0	0	72.55	0	0	13.2
2014	7	5	9	30	9	31	0	0	0	0	0	0	0	72.73	0	0	13.2
2014	7	5	9	40	9	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2014	7	5	9	50	9	31	0	0	0	0	0	0	0	73.04	0	0	13.2
2014	7	5	10	0	9	31	0	0	0	0	0	0	0	73.33	0	0	13.2
2014	7	5	10	10	9	31	0	0	0	0	0	0	0	73.56	0	0	13.2
2014	7	5	10	20	9	31	0	0	0	0	0	0	0	73.76	0	0	13.2
2014	7	5	10	30	9	31	0	0	0	0	0	0	0	74.07	0	0	13.2
2014	7	5	10	40	9	31	0	0	0	0	0	0	0	74.28	0	0	13.2
2014	7	5	10	50	9	31	0	0	0	0	0	0	0	74.62	0	0	13.2
2014	7	5	11	0	9	31	0	0	0	0	0	0	0	74.86	0	0	13.2
2014	7	5	11	10	9	31	0	0	0	0	0	0	0	75.15	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	11	20	9	31	0	0	0	0	0	0	0	75.45	0	0	13.2
2014	7	5	11	30	9	30	0	0	0	0	0	0	0	75.72	0	0	13.2
2014	7	5	11	40	9	31	0	0	0	0	0	0	0	76.01	0	0	13.2
2014	7	5	11	50	9	31	0	0	0	0	0	0	0	76.05	0	0	13.2
2014	7	5	12	0	9	31	0	0	0	0	0	0	0	75.76	0	0	13.2
2014	7	5	12	10	9	31	0	0	0	0	0	0	0	75.92	0	0	13.2
2014	7	5	12	20	9	31	0	0	0	0	0	0	0	76.21	0	0	13.2
2014	7	5	12	30	9	30	0	0	0	0	0	0	0	76.53	0	0	13.2
2014	7	5	12	40	9	30	0	0	0	0	0	0	0	76.84	0	0	13.2
2014	7	5	12	50	9	30	0	0	0	0	0	0	0	77.18	0	0	13.2
2014	7	5	13	0	9	31	0	0	0	0	0	0	0	77.54	0	0	13.2
2014	7	5	13	10	9	31	0	0	0	0	0	0	0	77.92	0	0	13.2
2014	7	5	13	20	9	30	0	0	0	0	0	0	0	78.75	0	0	13.2
2014	7	5	13	30	9	30	0	0	0	0	0	0	0	79.34	0	0	13.2
2014	7	5	13	40	9	30	0	0	0	0	0	0	0	79.79	0	0	13.2
2014	7	5	13	50	9	30	0	0	0	0	0	0	0	80.11	0	0	13.2
2014	7	5	14	0	9	30	0	0	0	0	0	0	0	80.46	0	0	13.2
2014	7	5	14	10	9	30	0	0	0	0	0	0	0	80.82	0	0	13.2
2014	7	5	14	20	9	30	0	0	0	0	0	0	0	81.12	0	0	13.2
2014	7	5	14	30	9	30	0	0	0	0	0	0	0	81.46	0	0	13.2
2014	7	5	14	40	9	30	0	0	0	0	0	0	0	81.77	0	0	13.2
2014	7	5	14	50	9	30	0	0	0	0	0	0	0	82.2	0	0	13.2
2014	7	5	15	0	9	30	0	0	0	0	0	0	0	82.45	0	0	13.2
2014	7	5	15	10	9	31	0	0	0	0	0	0	0	82.8	0	0	13.2
2014	7	5	15	20	9	30	0	0	0	0	0	0	0	83.05	0	0	13
2014	7	5	15	30	9	30	0	0	0	0	0	0	0	83.32	0	0	13.2
2014	7	5	15	40	9	30	0	0	0	0	0	0	0	83.53	0	0	13.2
2014	7	5	15	50	9	30	0	0	0	0	0	0	0	83.79	0	0	13
2014	7	5	16	0	9	30	0	0	0	0	0	0	0	83.93	0	0	13
2014	7	5	16	10	9	30	0	0	0	0	0	0	0	84.09	0	0	13
2014	7	5	16	20	9	30	0	0	0	0	0	0	0	84.24	0	0	12.8
2014	7	5	16	30	9	29	0	0	0	0	0	0	0	84.33	0	0	12.6
2014	7	5	16	40	9	30	0	0	0	0	0	0	0	84.51	0	0	12.6
2014	7	5	16	50	9	29	0	0	0	0	0	0	0	84.63	0	0	12.6
2014	7	5	17	0	9	30	0	0	0	0	0	0	0	84.67	0	0	12.6
2014	7	5	17	10	9	30	0	0	0	0	0	0	0	84.76	0	0	12.4
2014	7	5	17	20	9	30	0	0	0	0	0	0	0	84.78	0	0	12.4
2014	7	5	17	30	9	29	0	0	0	0	0	0	0	84.76	0	0	12.4
2014	7	5	17	40	9	30	0	0	0	0	0	0	0	84.58	0	0	12.4
2014	7	5	17	50	9	29	0	0	0	0	0	0	0	84.52	0	0	12.4
2014	7	5	18	0	9	30	0	0	0	0	0	0	0	84.43	0	0	12.4
2014	7	5	18	10	9	30	0	0	0	0	0	0	0	84.33	0	0	12.4
2014	7	5	18	20	9	30	0	0	0	0	0	0	0	84.16	0	0	12.4
2014	7	5	18	30	9	31	0	0	0	0	0	0	0	84.02	0	0	12.4
2014	7	5	18	40	9	30	0	0	0	0	0	0	0	83.84	0	0	12.4
2014	7	5	18	50	9	29	0	0	0	0	0	0	0	83.68	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	19	0	9	30	0	0	0	0	0	0	0	83.46	0	0	12.4
2014	7	5	19	10	9	30	0	0	0	0	0	0	0	83.25	0	0	12.2
2014	7	5	19	20	9	30	0	0	0	0	0	0	0	83.03	0	0	12.2
2014	7	5	19	30	9	30	0	0	0	0	0	0	0	82.78	0	0	12.2
2014	7	5	19	40	9	29	0	0	0	0	0	0	0	82.53	0	0	12.2
2014	7	5	19	50	9	30	0	0	0	0	0	0	0	82.27	0	0	12.2
2014	7	5	20	0	9	30	0	0	0	0	0	0	0	82.02	0	0	12.2
2014	7	5	20	10	9	29	0	0	0	0	0	0	0	81.72	0	0	12.2
2014	7	5	20	20	9	29	0	0	0	0	0	0	0	81.48	0	0	12.2
2014	7	5	20	30	9	30	0	0	0	0	0	0	0	81.21	0	0	12.2
2014	7	5	20	40	9	31	0	0	0	0	0	0	0	80.96	0	0	12.2
2014	7	5	20	50	9	30	0	0	0	0	0	0	0	80.71	0	0	12.2
2014	7	5	21	0	9	30	0	0	0	0	0	0	0	80.47	0	0	12.2
2014	7	5	21	10	9	30	0	0	0	0	0	0	0	80.24	0	0	12.2
2014	7	5	21	20	9	31	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	5	21	30	9	30	0	0	0	0	0	0	0	79.77	0	0	12.2
2014	7	5	21	40	9	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2014	7	5	21	50	9	30	0	0	0	0	0	0	0	79.34	0	0	12.2
2014	7	5	22	0	9	30	0	0	0	0	0	0	0	79.11	0	0	12.2
2014	7	5	22	10	9	29	0	0	0	0	0	0	0	78.91	0	0	12.2
2014	7	5	22	20	9	30	0	0	0	0	0	0	0	78.71	0	0	12
2014	7	5	22	30	9	31	0	0	0	0	0	0	0	78.49	0	0	12.2
2014	7	5	22	40	9	30	0	0	0	0	0	0	0	78.31	0	0	12.2
2014	7	5	22	50	9	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2014	7	5	23	0	9	31	0	0	0	0	0	0	0	77.92	0	0	12.2
2014	7	5	23	10	9	30	0	0	0	0	0	0	0	77.76	0	0	12.2
2014	7	5	23	20	9	31	0	0	0	0	0	0	0	77.58	0	0	12
2014	7	5	23	30	9	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2014	7	5	23	40	9	30	0	0	0	0	0	0	0	77.25	0	0	12.2
2014	7	5	23	50	9	31	0	0	0	0	0	0	0	77.09	0	0	12.2
2014	7	6	0	0	9	30	0	0	0	0	0	0	0	76.95	0	0	12.2
2014	7	6	0	10	9	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2014	7	6	0	20	9	30	0	0	0	0	0	0	0	76.66	0	0	12
2014	7	6	0	30	9	30	0	0	0	0	0	0	0	76.53	0	0	12
2014	7	6	0	40	9	31	0	0	0	0	0	0	0	76.39	0	0	12
2014	7	6	0	50	9	31	0	0	0	0	0	0	0	76.26	0	0	12
2014	7	6	1	0	9	31	0	0	0	0	0	0	0	76.14	0	0	12
2014	7	6	1	10	9	30	0	0	0	0	0	0	0	76.03	0	0	12
2014	7	6	1	20	9	31	0	0	0	0	0	0	0	75.9	0	0	12
2014	7	6	1	30	9	30	0	0	0	0	0	0	0	75.81	0	0	12
2014	7	6	1	40	9	31	0	0	0	0	0	0	0	75.7	0	0	12
2014	7	6	1	50	9	31	0	0	0	0	0	0	0	75.6	0	0	12
2014	7	6	2	0	9	30	0	0	0	0	0	0	0	75.51	0	0	12
2014	7	6	2	10	9	31	0	0	0	0	0	0	0	75.42	0	0	12
2014	7	6	2	20	9	31	0	0	0	0	0	0	0	75.33	0	0	12
2014	7	6	2	30	9	30	0	0	0	0	0	0	0	75.24	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	2	40	9	30	0	0	0	0	0	0	0	75.15	0	0	12
2014	7	6	2	50	9	30	0	0	0	0	0	0	0	75.06	0	0	12
2014	7	6	3	0	9	31	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	6	3	10	9	30	0	0	0	0	0	0	0	74.89	0	0	12
2014	7	6	3	20	9	31	0	0	0	0	0	0	0	74.82	0	0	12
2014	7	6	3	30	9	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	6	3	40	9	31	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	6	3	50	9	31	0	0	0	0	0	0	0	74.64	0	0	12
2014	7	6	4	0	9	30	0	0	0	0	0	0	0	74.59	0	0	12
2014	7	6	4	10	9	31	0	0	0	0	0	0	0	74.53	0	0	12
2014	7	6	4	20	9	31	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	6	4	30	9	31	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	6	4	40	9	31	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	6	4	50	9	30	0	0	0	0	0	0	0	74.32	0	0	12
2014	7	6	5	0	9	31	0	0	0	0	0	0	0	74.26	0	0	12
2014	7	6	5	10	9	32	0	0	0	0	0	0	0	74.19	0	0	12
2014	7	6	5	20	9	31	0	0	0	0	0	0	0	74.1	0	0	11.8
2014	7	6	5	30	9	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	6	5	40	9	30	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	6	5	50	9	31	0	0	0	0	0	0	0	73.87	0	0	12
2014	7	6	6	0	9	31	0	0	0	0	0	0	0	73.8	0	0	12
2014	7	6	6	10	9	31	0	0	0	0	0	0	0	73.72	0	0	12
2014	7	6	6	20	9	32	0	0	0	0	0	0	0	73.65	0	0	11.8
2014	7	6	6	30	9	31	0	0	0	0	0	0	0	73.56	0	0	12
2014	7	6	6	40	9	30	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	6	6	50	9	31	0	0	0	0	0	0	0	73.4	0	0	12
2014	7	6	7	0	9	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	6	7	10	9	30	0	0	0	0	0	0	0	73.24	0	0	12
2014	7	6	7	20	9	32	0	0	0	0	0	0	0	73.17	0	0	12
2014	7	6	7	30	9	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	6	7	40	9	31	0	0	0	0	0	0	0	72.97	0	0	12
2014	7	6	7	50	9	31	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	6	8	0	9	32	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	6	8	10	9	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	6	8	20	9	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	6	8	30	9	30	0	0	0	0	0	0	0	72.57	0	0	12.2
2014	7	6	8	40	9	31	0	0	0	0	0	0	0	72.48	0	0	12
2014	7	6	8	50	9	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	6	9	0	9	31	0	0	0	0	0	0	0	72.36	0	0	12.2
2014	7	6	9	10	9	30	0	0	0	0	0	0	0	72.32	0	0	12.2
2014	7	6	9	20	9	30	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	6	9	30	9	31	0	0	0	0	0	0	0	72.32	0	0	12.4
2014	7	6	9	40	9	31	0	0	0	0	0	0	0	72.45	0	0	12.6
2014	7	6	9	50	9	30	0	0	0	0	0	0	0	72.59	0	0	12.8
2014	7	6	10	0	9	31	0	0	0	0	0	0	0	72.45	0	0	12.6
2014	7	6	10	10	9	31	0	0	0	0	0	0	0	72.55	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	10	20	9	31	0	0	0	0	0	0	0	72.86	0	0	13
2014	7	6	10	30	9	32	0	0	0	0	0	0	0	72.93	0	0	13
2014	7	6	10	40	9	30	0	0	0	0	0	0	0	73.11	0	0	13
2014	7	6	10	50	9	31	0	0	0	0	0	0	0	73.08	0	0	13
2014	7	6	11	0	9	31	0	0	0	0	0	0	0	73.17	0	0	12.8
2014	7	6	11	10	9	31	0	0	0	0	0	0	0	73.26	0	0	12.8
2014	7	6	11	20	9	31	0	0	0	0	0	0	0	73.53	0	0	13
2014	7	6	11	30	9	31	0	0	0	0	0	0	0	73.87	0	0	13.2
2014	7	6	11	40	9	30	0	0	0	0	0	0	0	73.85	0	0	13
2014	7	6	11	50	9	32	0	0	0	0	0	0	0	73.9	0	0	12.8
2014	7	6	12	0	9	31	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	6	12	10	9	30	0	0	0	0	0	0	0	74.26	0	0	13.2
2014	7	6	12	20	9	31	0	0	0	0	0	0	0	74.43	0	0	13
2014	7	6	12	30	9	31	0	0	0	0	0	0	0	74.61	0	0	13.4
2014	7	6	12	40	9	30	0	0	0	0	0	0	0	74.84	0	0	13.2
2014	7	6	12	50	9	31	0	0	0	0	0	0	0	75.04	0	0	12.8
2014	7	6	13	0	9	30	0	0	0	0	0	0	0	75.31	0	0	13.2
2014	7	6	13	10	9	31	0	0	0	0	0	0	0	75.61	0	0	13.2
2014	7	6	13	20	9	30	0	0	0	0	0	0	0	76.33	0	0	13.2
2014	7	6	13	30	9	31	0	0	0	0	0	0	0	76.84	0	0	13.2
2014	7	6	13	40	9	30	0	0	0	0	0	0	0	77.31	0	0	13.2
2014	7	6	13	50	9	31	0	0	0	0	0	0	0	77.7	0	0	13.2
2014	7	6	14	0	9	31	0	0	0	0	0	0	0	78.1	0	0	13.2
2014	7	6	14	10	9	31	0	0	0	0	0	0	0	78.44	0	0	13.2
2014	7	6	14	20	9	30	0	0	0	0	0	0	0	78.85	0	0	13
2014	7	6	14	30	9	30	0	0	0	0	0	0	0	79.21	0	0	13.2
2014	7	6	14	40	9	31	0	0	0	0	0	0	0	79.56	0	0	13
2014	7	6	14	50	9	31	0	0	0	0	0	0	0	79.93	0	0	13
2014	7	6	15	0	9	30	0	0	0	0	0	0	0	80.26	0	0	13
2014	7	6	15	10	9	30	0	0	0	0	0	0	0	80.55	0	0	13
2014	7	6	15	20	9	31	0	0	0	0	0	0	0	80.83	0	0	13
2014	7	6	15	30	9	29	0	0	0	0	0	0	0	80.87	0	0	12.8
2014	7	6	15	40	9	30	0	0	0	0	0	0	0	81.32	0	0	13
2014	7	6	15	50	9	31	0	0	0	0	0	0	0	81.5	0	0	12.8
2014	7	6	16	0	9	30	0	0	0	0	0	0	0	81.41	0	0	12.6
2014	7	6	16	10	9	31	0	0	0	0	0	0	0	81.5	0	0	12.4
2014	7	6	16	20	9	31	0	0	0	0	0	0	0	81.59	0	0	12.4
2014	7	6	16	30	9	30	0	0	0	0	0	0	0	81.63	0	0	12.4
2014	7	6	16	40	9	30	0	0	0	0	0	0	0	81.64	0	0	12.4
2014	7	6	16	50	9	30	0	0	0	0	0	0	0	81.64	0	0	12.4
2014	7	6	17	0	9	30	0	0	0	0	0	0	0	81.66	0	0	12.4
2014	7	6	17	10	9	30	0	0	0	0	0	0	0	81.73	0	0	12.4
2014	7	6	17	20	9	30	0	0	0	0	0	0	0	81.75	0	0	12.2
2014	7	6	17	30	9	30	0	0	0	0	0	0	0	81.72	0	0	12.4
2014	7	6	17	40	9	30	0	0	0	0	0	0	0	81.64	0	0	12.4
2014	7	6	17	50	9	30	0	0	0	0	0	0	0	81.57	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	18	0	9	30	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	6	18	10	9	30	0	0	0	0	0	0	0	81.45	0	0	12.2
2014	7	6	18	20	9	30	0	0	0	0	0	0	0	81.37	0	0	12.2
2014	7	6	18	30	9	30	0	0	0	0	0	0	0	81.3	0	0	12.2
2014	7	6	18	40	9	29	0	0	0	0	0	0	0	81.23	0	0	12.2
2014	7	6	18	50	9	30	0	0	0	0	0	0	0	81.14	0	0	12.2
2014	7	6	19	0	9	30	0	0	0	0	0	0	0	81.03	0	0	12.2
2014	7	6	19	10	9	30	0	0	0	0	0	0	0	80.91	0	0	12.2
2014	7	6	19	20	9	30	0	0	0	0	0	0	0	80.78	0	0	12
2014	7	6	19	30	9	29	0	0	0	0	0	0	0	80.65	0	0	12.2
2014	7	6	19	40	9	30	0	0	0	0	0	0	0	80.53	0	0	12.2
2014	7	6	19	50	9	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2014	7	6	20	0	9	30	0	0	0	0	0	0	0	80.2	0	0	12.2
2014	7	6	20	10	9	31	0	0	0	0	0	0	0	80.04	0	0	12.2
2014	7	6	20	20	9	31	0	0	0	0	0	0	0	79.88	0	0	12
2014	7	6	20	30	9	30	0	0	0	0	0	0	0	79.72	0	0	12.2
2014	7	6	20	40	9	31	0	0	0	0	0	0	0	79.57	0	0	12.2
2014	7	6	20	50	9	30	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	6	21	0	9	31	0	0	0	0	0	0	0	79.25	0	0	12.2
2014	7	6	21	10	9	30	0	0	0	0	0	0	0	79.07	0	0	12.2
2014	7	6	21	20	9	31	0	0	0	0	0	0	0	78.91	0	0	12
2014	7	6	21	30	9	30	0	0	0	0	0	0	0	78.75	0	0	12.2
2014	7	6	21	40	9	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	6	21	50	9	31	0	0	0	0	0	0	0	78.39	0	0	12.2
2014	7	6	22	0	9	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2014	7	6	22	10	9	30	0	0	0	0	0	0	0	78.04	0	0	12
2014	7	6	22	20	9	31	0	0	0	0	0	0	0	77.83	0	0	12
2014	7	6	22	30	9	30	0	0	0	0	0	0	0	77.65	0	0	12
2014	7	6	22	40	9	31	0	0	0	0	0	0	0	77.49	0	0	12
2014	7	6	22	50	9	30	0	0	0	0	0	0	0	77.34	0	0	12
2014	7	6	23	0	9	30	0	0	0	0	0	0	0	77.16	0	0	12
2014	7	6	23	10	9	30	0	0	0	0	0	0	0	77	0	0	12
2014	7	6	23	20	9	30	0	0	0	0	0	0	0	76.87	0	0	12
2014	7	6	23	30	9	31	0	0	0	0	0	0	0	76.77	0	0	12
2014	7	6	23	40	9	31	0	0	0	0	0	0	0	76.66	0	0	12
2014	7	6	23	50	9	30	0	0	0	0	0	0	0	76.55	0	0	12
2014	7	7	0	0	9	31	0	0	0	0	0	0	0	76.44	0	0	12
2014	7	7	0	10	9	30	0	0	0	0	0	0	0	76.33	0	0	12
2014	7	7	0	20	9	31	0	0	0	0	0	0	0	76.26	0	0	12
2014	7	7	0	30	9	30	0	0	0	0	0	0	0	76.19	0	0	12
2014	7	7	0	40	9	30	0	0	0	0	0	0	0	76.12	0	0	12
2014	7	7	0	50	9	30	0	0	0	0	0	0	0	76.06	0	0	12
2014	7	7	1	0	9	31	0	0	0	0	0	0	0	76.01	0	0	12
2014	7	7	1	10	9	31	0	0	0	0	0	0	0	75.94	0	0	12
2014	7	7	1	20	9	31	0	0	0	0	0	0	0	75.87	0	0	11.8
2014	7	7	1	30	9	30	0	0	0	0	0	0	0	75.81	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	1	40	9	30	0	0	0	0	0	0	0	75.74	0	0	12
2014	7	7	1	50	9	30	0	0	0	0	0	0	0	75.69	0	0	12
2014	7	7	2	0	9	30	0	0	0	0	0	0	0	75.61	0	0	12
2014	7	7	2	10	9	30	0	0	0	0	0	0	0	75.58	0	0	12
2014	7	7	2	20	9	31	0	0	0	0	0	0	0	75.52	0	0	11.8
2014	7	7	2	30	9	31	0	0	0	0	0	0	0	75.47	0	0	12
2014	7	7	2	40	9	31	0	0	0	0	0	0	0	75.42	0	0	12
2014	7	7	2	50	9	30	0	0	0	0	0	0	0	75.36	0	0	12
2014	7	7	3	0	9	31	0	0	0	0	0	0	0	75.31	0	0	12
2014	7	7	3	10	9	31	0	0	0	0	0	0	0	75.25	0	0	12
2014	7	7	3	20	9	31	0	0	0	0	0	0	0	75.2	0	0	12
2014	7	7	3	30	9	31	0	0	0	0	0	0	0	75.15	0	0	12
2014	7	7	3	40	9	31	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	7	3	50	9	31	0	0	0	0	0	0	0	75.04	0	0	12
2014	7	7	4	0	9	31	0	0	0	0	0	0	0	74.98	0	0	12
2014	7	7	4	10	9	31	0	0	0	0	0	0	0	74.91	0	0	12
2014	7	7	4	20	9	31	0	0	0	0	0	0	0	74.86	0	0	12
2014	7	7	4	30	9	30	0	0	0	0	0	0	0	74.79	0	0	12
2014	7	7	4	40	9	31	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	7	4	50	9	30	0	0	0	0	0	0	0	74.64	0	0	12
2014	7	7	5	0	9	31	0	0	0	0	0	0	0	74.57	0	0	12
2014	7	7	5	10	9	31	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	7	5	20	9	30	0	0	0	0	0	0	0	74.43	0	0	12
2014	7	7	5	30	9	31	0	0	0	0	0	0	0	74.35	0	0	12
2014	7	7	5	40	9	31	0	0	0	0	0	0	0	74.26	0	0	12
2014	7	7	5	50	9	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	7	6	0	9	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	7	7	6	10	9	31	0	0	0	0	0	0	0	73.96	0	0	12
2014	7	7	6	20	9	30	0	0	0	0	0	0	0	73.85	0	0	12
2014	7	7	6	30	9	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	7	6	40	9	32	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	7	6	50	9	31	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	7	7	0	9	31	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	7	7	10	9	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	7	7	20	9	30	0	0	0	0	0	0	0	73.22	0	0	12
2014	7	7	7	30	9	31	0	0	0	0	0	0	0	73.11	0	0	12
2014	7	7	7	40	9	31	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	7	7	50	9	31	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	7	8	0	9	31	0	0	0	0	0	0	0	72.86	0	0	12
2014	7	7	8	10	9	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	7	8	20	9	32	0	0	0	0	0	0	0	72.7	0	0	12
2014	7	7	8	30	9	31	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	7	8	40	9	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	7	8	50	9	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	7	9	0	9	31	0	0	0	0	0	0	0	72.46	0	0	12
2014	7	7	9	10	9	31	0	0	0	0	0	0	0	72.43	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	9	20	9	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	7	9	30	9	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	7	9	40	9	32	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	7	9	50	9	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	7	10	0	9	32	0	0	0	0	0	0	0	72.25	0	0	12.2
2014	7	7	10	10	9	31	0	0	0	0	0	0	0	72.21	0	0	12.2
2014	7	7	10	20	9	31	0	0	0	0	0	0	0	72.23	0	0	12
2014	7	7	10	30	9	31	0	0	0	0	0	0	0	72.19	0	0	12.2
2014	7	7	10	40	9	31	0	0	0	0	0	0	0	72.16	0	0	12.2
2014	7	7	10	50	9	31	0	0	0	0	0	0	0	72.18	0	0	12.2
2014	7	7	11	0	9	31	0	0	0	0	0	0	0	72.23	0	0	12.2
2014	7	7	11	10	9	31	0	0	0	0	0	0	0	72.3	0	0	12.4
2014	7	7	11	20	9	31	0	0	0	0	0	0	0	72.36	0	0	12.4
2014	7	7	11	30	9	31	0	0	0	0	0	0	0	72.5	0	0	12.6
2014	7	7	11	40	9	31	0	0	0	0	0	0	0	72.82	0	0	13
2014	7	7	11	50	9	31	0	0	0	0	0	0	0	72.9	0	0	13
2014	7	7	12	0	9	31	0	0	0	0	0	0	0	73	0	0	13.2
2014	7	7	12	10	9	31	0	0	0	0	0	0	0	73.13	0	0	13
2014	7	7	12	20	9	32	0	0	0	0	0	0	0	73.24	0	0	13.4
2014	7	7	12	30	9	30	0	0	0	0	0	0	0	73.4	0	0	13
2014	7	7	12	40	9	31	0	0	0	0	0	0	0	73.65	0	0	13.4
2014	7	7	12	50	9	31	0	0	0	0	0	0	0	73.96	0	0	13.2
2014	7	7	13	0	9	32	0	0	0	0	0	0	0	74.37	0	0	13
2014	7	7	13	10	9	31	0	0	0	0	0	0	0	74.71	0	0	13.2
2014	7	7	13	20	9	31	0	0	0	0	0	0	0	75.51	0	0	13.2
2014	7	7	13	30	9	31	0	0	0	0	0	0	0	75.96	0	0	13.2
2014	7	7	13	40	9	30	0	0	0	0	0	0	0	75.85	0	0	12.8
2014	7	7	13	50	9	31	0	0	0	0	0	0	0	76.51	0	0	13.2
2014	7	7	14	0	9	31	0	0	0	0	0	0	0	76.93	0	0	13.2
2014	7	7	14	10	9	30	0	0	0	0	0	0	0	76.86	0	0	12.8
2014	7	7	14	20	9	31	0	0	0	0	0	0	0	77.29	0	0	12.8
2014	7	7	14	30	9	30	0	0	0	0	0	0	0	77.38	0	0	12.8
2014	7	7	14	40	9	31	0	0	0	0	0	0	0	77.56	0	0	12.6
2014	7	7	14	50	9	30	0	0	0	0	0	0	0	77.67	0	0	12.6
2014	7	7	15	0	9	31	0	0	0	0	0	0	0	77.76	0	0	12.6
2014	7	7	15	10	9	31	0	0	0	0	0	0	0	77.85	0	0	12.4
2014	7	7	15	20	9	31	0	0	0	0	0	0	0	77.92	0	0	12.4
2014	7	7	15	30	9	31	0	0	0	0	0	0	0	77.97	0	0	12.6
2014	7	7	15	40	9	30	0	0	0	0	0	0	0	78.06	0	0	12.6
2014	7	7	15	50	9	31	0	0	0	0	0	0	0	78.13	0	0	12.6
2014	7	7	16	0	9	31	0	0	0	0	0	0	0	78.21	0	0	12.6
2014	7	7	16	10	9	30	0	0	0	0	0	0	0	78.26	0	0	12.4
2014	7	7	16	20	9	30	0	0	0	0	0	0	0	78.39	0	0	12.4
2014	7	7	16	30	9	30	0	0	0	0	0	0	0	78.69	0	0	12.6
2014	7	7	16	40	9	30	0	0	0	0	0	0	0	78.8	0	0	12.6
2014	7	7	16	50	9	31	0	0	0	0	0	0	0	78.94	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	17	0	9	31	0	0	0	0	0	0	0	79.09	0	0	12.4
2014	7	7	17	10	9	30	0	0	0	0	0	0	0	79.27	0	0	12.4
2014	7	7	17	20	9	30	0	0	0	0	0	0	0	79.59	0	0	12.4
2014	7	7	17	30	9	30	0	0	0	0	0	0	0	79.63	0	0	12.4
2014	7	7	17	40	9	30	0	0	0	0	0	0	0	79.66	0	0	12.4
2014	7	7	17	50	9	30	0	0	0	0	0	0	0	79.74	0	0	12.4
2014	7	7	18	0	9	31	0	0	0	0	0	0	0	79.81	0	0	12.4
2014	7	7	18	10	9	30	0	0	0	0	0	0	0	79.86	0	0	12.4
2014	7	7	18	20	9	30	0	0	0	0	0	0	0	79.86	0	0	12.2
2014	7	7	18	30	9	31	0	0	0	0	0	0	0	79.86	0	0	12.2
2014	7	7	18	40	9	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	7	18	50	9	30	0	0	0	0	0	0	0	79.75	0	0	12.2
2014	7	7	19	0	9	31	0	0	0	0	0	0	0	79.68	0	0	12.2
2014	7	7	19	10	9	30	0	0	0	0	0	0	0	79.61	0	0	12.2
2014	7	7	19	20	9	31	0	0	0	0	0	0	0	79.5	0	0	12
2014	7	7	19	30	9	31	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	7	19	40	9	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	7	19	50	9	31	0	0	0	0	0	0	0	79.2	0	0	12.2
2014	7	7	20	0	9	30	0	0	0	0	0	0	0	79.05	0	0	12.2
2014	7	7	20	10	9	30	0	0	0	0	0	0	0	78.87	0	0	12.2
2014	7	7	20	20	9	31	0	0	0	0	0	0	0	78.67	0	0	12
2014	7	7	20	30	9	30	0	0	0	0	0	0	0	78.49	0	0	12.2
2014	7	7	20	40	9	30	0	0	0	0	0	0	0	78.3	0	0	12.2
2014	7	7	20	50	9	31	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	7	21	0	9	31	0	0	0	0	0	0	0	77.88	0	0	12
2014	7	7	21	10	9	30	0	0	0	0	0	0	0	77.68	0	0	12
2014	7	7	21	20	9	30	0	0	0	0	0	0	0	77.5	0	0	12
2014	7	7	21	30	9	30	0	0	0	0	0	0	0	77.31	0	0	12
2014	7	7	21	40	9	31	0	0	0	0	0	0	0	77.13	0	0	12
2014	7	7	21	50	9	31	0	0	0	0	0	0	0	76.95	0	0	12
2014	7	7	22	0	9	31	0	0	0	0	0	0	0	76.77	0	0	12
2014	7	7	22	10	9	31	0	0	0	0	0	0	0	76.57	0	0	12
2014	7	7	22	20	9	31	0	0	0	0	0	0	0	76.41	0	0	12
2014	7	7	22	30	9	31	0	0	0	0	0	0	0	76.23	0	0	12
2014	7	7	22	40	9	32	0	0	0	0	0	0	0	76.05	0	0	12
2014	7	7	22	50	9	31	0	0	0	0	0	0	0	75.88	0	0	12
2014	7	7	23	0	9	31	0	0	0	0	0	0	0	75.7	0	0	12
2014	7	7	23	10	9	30	0	0	0	0	0	0	0	75.54	0	0	12
2014	7	7	23	20	9	30	0	0	0	0	0	0	0	75.36	0	0	11.8
2014	7	7	23	30	9	31	0	0	0	0	0	0	0	75.2	0	0	12
2014	7	7	23	40	9	31	0	0	0	0	0	0	0	75.02	0	0	12
2014	7	7	23	50	9	30	0	0	0	0	0	0	0	74.86	0	0	12
2014	7	8	0	0	9	31	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	8	0	10	9	30	0	0	0	0	0	0	0	74.53	0	0	12
2014	7	8	0	20	9	31	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	8	0	30	9	30	0	0	0	0	0	0	0	74.21	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	0	40	9	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	7	8	0	50	9	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	8	1	0	9	30	0	0	0	0	0	0	0	73.81	0	0	12
2014	7	8	1	10	9	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	8	1	20	9	30	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	8	1	30	9	31	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	8	1	40	9	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	8	1	50	9	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	8	2	0	9	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	8	2	10	9	31	0	0	0	0	0	0	0	72.97	0	0	12
2014	7	8	2	20	9	30	0	0	0	0	0	0	0	72.84	0	0	11.8
2014	7	8	2	30	9	32	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	8	2	40	9	30	0	0	0	0	0	0	0	72.63	0	0	12
2014	7	8	2	50	9	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	8	3	0	9	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	8	3	10	9	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	8	3	20	9	32	0	0	0	0	0	0	0	72.23	0	0	12
2014	7	8	3	30	9	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	8	3	40	9	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	8	3	50	9	30	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	8	4	0	9	31	0	0	0	0	0	0	0	71.8	0	0	12
2014	7	8	4	10	9	31	0	0	0	0	0	0	0	71.69	0	0	12
2014	7	8	4	20	9	31	0	0	0	0	0	0	0	71.55	0	0	12
2014	7	8	4	30	9	31	0	0	0	0	0	0	0	71.46	0	0	12
2014	7	8	4	40	9	31	0	0	0	0	0	0	0	71.35	0	0	12
2014	7	8	4	50	9	31	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	8	5	0	9	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	8	5	10	9	31	0	0	0	0	0	0	0	71.04	0	0	12
2014	7	8	5	20	9	31	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	8	5	30	9	31	0	0	0	0	0	0	0	70.83	0	0	12
2014	7	8	5	40	9	31	0	0	0	0	0	0	0	70.74	0	0	12
2014	7	8	5	50	9	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	7	8	6	0	9	32	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	8	6	10	9	32	0	0	0	0	0	0	0	70.45	0	0	12
2014	7	8	6	20	9	31	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	8	6	30	9	31	0	0	0	0	0	0	0	70.29	0	0	12
2014	7	8	6	40	9	31	0	0	0	0	0	0	0	70.18	0	0	12
2014	7	8	6	50	9	31	0	0	0	0	0	0	0	70.18	0	0	12.2
2014	7	8	7	0	9	31	0	0	0	0	0	0	0	70.14	0	0	12.2
2014	7	8	7	10	9	32	0	0	0	0	0	0	0	70.27	0	0	12.4
2014	7	8	7	20	9	32	0	0	0	0	0	0	0	70.32	0	0	12.4
2014	7	8	7	30	9	31	0	0	0	0	0	0	0	70.16	0	0	12.4
2014	7	8	7	40	9	31	0	0	0	0	0	0	0	70.34	0	0	12.6
2014	7	8	7	50	9	32	0	0	0	0	0	0	0	70.41	0	0	12.6
2014	7	8	8	0	9	31	0	0	0	0	0	0	0	70.48	0	0	12.6
2014	7	8	8	10	9	31	0	0	0	0	0	0	0	70.57	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	8	20	9	31	0	0	0	0	0	0	0	70.66	0	0	12.8
2014	7	8	8	30	9	31	0	0	0	0	0	0	0	70.63	0	0	12.8
2014	7	8	8	40	9	31	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	8	8	50	9	32	0	0	0	0	0	0	0	71.02	0	0	13
2014	7	8	9	0	9	31	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	8	9	10	9	31	0	0	0	0	0	0	0	71.33	0	0	13
2014	7	8	9	20	9	31	0	0	0	0	0	0	0	71.51	0	0	13
2014	7	8	9	30	9	31	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	8	9	40	9	32	0	0	0	0	0	0	0	71.89	0	0	13.2
2014	7	8	9	50	9	31	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	7	8	10	0	9	31	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	8	10	10	9	31	0	0	0	0	0	0	0	72.54	0	0	13.2
2014	7	8	10	20	9	31	0	0	0	0	0	0	0	72.81	0	0	13.2
2014	7	8	10	30	9	31	0	0	0	0	0	0	0	73.08	0	0	13.2
2014	7	8	10	40	9	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2014	7	8	10	50	9	30	0	0	0	0	0	0	0	73.63	0	0	13.2
2014	7	8	11	0	9	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	8	11	10	9	32	0	0	0	0	0	0	0	74.25	0	0	13.2
2014	7	8	11	20	9	30	0	0	0	0	0	0	0	74.57	0	0	13.2
2014	7	8	11	30	9	31	0	0	0	0	0	0	0	74.86	0	0	13.2
2014	7	8	11	40	9	31	0	0	0	0	0	0	0	75.09	0	0	13.2
2014	7	8	11	50	9	31	0	0	0	0	0	0	0	75.09	0	0	13.2
2014	7	8	12	0	9	31	0	0	0	0	0	0	0	75.24	0	0	13.2
2014	7	8	12	10	9	31	0	0	0	0	0	0	0	75.52	0	0	13.2
2014	7	8	12	20	9	31	0	0	0	0	0	0	0	75.78	0	0	13
2014	7	8	12	30	9	31	0	0	0	0	0	0	0	76.06	0	0	13.2
2014	7	8	12	40	9	31	0	0	0	0	0	0	0	76.28	0	0	13.2
2014	7	8	12	50	9	31	0	0	0	0	0	0	0	76.59	0	0	13.2
2014	7	8	13	0	9	30	0	0	0	0	0	0	0	76.87	0	0	13.2
2014	7	8	13	10	9	30	0	0	0	0	0	0	0	77.27	0	0	13.2
2014	7	8	13	20	9	31	0	0	0	0	0	0	0	78.01	0	0	13
2014	7	8	13	30	9	32	0	0	0	0	0	0	0	78.01	0	0	12.6
2014	7	8	13	40	9	31	0	0	0	0	0	0	0	78.33	0	0	12.8
2014	7	8	13	50	9	30	0	0	0	0	0	0	0	78.84	0	0	13
2014	7	8	14	0	9	30	0	0	0	0	0	0	0	79.32	0	0	13.2
2014	7	8	14	10	9	31	0	0	0	0	0	0	0	79.07	0	0	12.6
2014	7	8	14	20	9	30	0	0	0	0	0	0	0	79.11	0	0	12.6
2014	7	8	14	30	9	30	0	0	0	0	0	0	0	79.14	0	0	12.6
2014	7	8	14	40	9	30	0	0	0	0	0	0	0	79.14	0	0	12.6
2014	7	8	14	50	9	30	0	0	0	0	0	0	0	79.21	0	0	12.6
2014	7	8	15	0	9	30	0	0	0	0	0	0	0	79.3	0	0	12.6
2014	7	8	15	10	9	30	0	0	0	0	0	0	0	79.57	0	0	12.8
2014	7	8	15	20	9	31	0	0	0	0	0	0	0	79.57	0	0	12.6
2014	7	8	15	30	9	30	0	0	0	0	0	0	0	79.66	0	0	12.8
2014	7	8	15	40	9	31	0	0	0	0	0	0	0	79.68	0	0	12.6
2014	7	8	15	50	9	30	0	0	0	0	0	0	0	79.66	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	16	0	9	30	0	0	0	0	0	0	0	79.66	0	0	12.6
2014	7	8	16	10	9	30	0	0	0	0	0	0	0	79.66	0	0	12.6
2014	7	8	16	20	9	30	0	0	0	0	0	0	0	79.72	0	0	12.4
2014	7	8	16	30	9	31	0	0	0	0	0	0	0	79.75	0	0	12.6
2014	7	8	16	40	9	30	0	0	0	0	0	0	0	79.72	0	0	12.4
2014	7	8	16	50	9	30	0	0	0	0	0	0	0	79.7	0	0	12.4
2014	7	8	17	0	9	30	0	0	0	0	0	0	0	79.81	0	0	12.4
2014	7	8	17	10	9	31	0	0	0	0	0	0	0	79.68	0	0	12.4
2014	7	8	17	20	9	30	0	0	0	0	0	0	0	79.77	0	0	12.2
2014	7	8	17	30	9	30	0	0	0	0	0	0	0	79.77	0	0	12.4
2014	7	8	17	40	9	30	0	0	0	0	0	0	0	79.57	0	0	12.4
2014	7	8	17	50	9	30	0	0	0	0	0	0	0	79.48	0	0	12.4
2014	7	8	18	0	9	30	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	8	18	10	9	30	0	0	0	0	0	0	0	79.36	0	0	12.2
2014	7	8	18	20	9	30	0	0	0	0	0	0	0	79.3	0	0	12.2
2014	7	8	18	30	9	30	0	0	0	0	0	0	0	79.18	0	0	12.2
2014	7	8	18	40	9	30	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	8	18	50	9	30	0	0	0	0	0	0	0	78.85	0	0	12.2
2014	7	8	19	0	9	30	0	0	0	0	0	0	0	78.69	0	0	12.2
2014	7	8	19	10	9	30	0	0	0	0	0	0	0	78.49	0	0	12.2
2014	7	8	19	20	9	31	0	0	0	0	0	0	0	78.3	0	0	12
2014	7	8	19	30	9	30	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	8	19	40	9	31	0	0	0	0	0	0	0	77.88	0	0	12.2
2014	7	8	19	50	9	30	0	0	0	0	0	0	0	77.68	0	0	12.2
2014	7	8	20	0	9	31	0	0	0	0	0	0	0	77.49	0	0	12.2
2014	7	8	20	10	9	30	0	0	0	0	0	0	0	77.27	0	0	12.2
2014	7	8	20	20	9	30	0	0	0	0	0	0	0	77.05	0	0	12.2
2014	7	8	20	30	9	30	0	0	0	0	0	0	0	76.86	0	0	12.2
2014	7	8	20	40	9	30	0	0	0	0	0	0	0	76.66	0	0	12.2
2014	7	8	20	50	9	30	0	0	0	0	0	0	0	76.46	0	0	12.2
2014	7	8	21	0	9	31	0	0	0	0	0	0	0	76.28	0	0	12.2
2014	7	8	21	10	9	31	0	0	0	0	0	0	0	76.1	0	0	12.2
2014	7	8	21	20	9	30	0	0	0	0	0	0	0	75.94	0	0	12
2014	7	8	21	30	9	31	0	0	0	0	0	0	0	75.76	0	0	12.2
2014	7	8	21	40	9	31	0	0	0	0	0	0	0	75.58	0	0	12.2
2014	7	8	21	50	9	31	0	0	0	0	0	0	0	75.42	0	0	12.2
2014	7	8	22	0	9	30	0	0	0	0	0	0	0	75.25	0	0	12.2
2014	7	8	22	10	9	31	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	8	22	20	9	31	0	0	0	0	0	0	0	74.91	0	0	12
2014	7	8	22	30	9	31	0	0	0	0	0	0	0	74.75	0	0	12
2014	7	8	22	40	9	31	0	0	0	0	0	0	0	74.57	0	0	12
2014	7	8	22	50	9	30	0	0	0	0	0	0	0	74.43	0	0	12
2014	7	8	23	0	9	32	0	0	0	0	0	0	0	74.28	0	0	12
2014	7	8	23	10	9	31	0	0	0	0	0	0	0	74.14	0	0	12
2014	7	8	23	20	9	31	0	0	0	0	0	0	0	73.99	0	0	12
2014	7	8	23	30	9	31	0	0	0	0	0	0	0	73.87	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	23	40	9	31	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	8	23	50	9	31	0	0	0	0	0	0	0	73.62	0	0	12
2014	7	9	0	0	9	31	0	0	0	0	0	0	0	73.51	0	0	12
2014	7	9	0	10	9	31	0	0	0	0	0	0	0	73.38	0	0	12
2014	7	9	0	20	9	31	0	0	0	0	0	0	0	73.24	0	0	12
2014	7	9	0	30	9	30	0	0	0	0	0	0	0	73.13	0	0	12
2014	7	9	0	40	9	31	0	0	0	0	0	0	0	73	0	0	12
2014	7	9	0	50	9	32	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	9	1	0	9	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	9	1	10	9	31	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	9	1	20	9	31	0	0	0	0	0	0	0	72.48	0	0	12
2014	7	9	1	30	9	31	0	0	0	0	0	0	0	72.37	0	0	12
2014	7	9	1	40	9	31	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	9	1	50	9	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	9	2	0	9	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	9	2	10	9	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	9	2	20	9	31	0	0	0	0	0	0	0	71.8	0	0	12
2014	7	9	2	30	9	31	0	0	0	0	0	0	0	71.71	0	0	12
2014	7	9	2	40	9	31	0	0	0	0	0	0	0	71.6	0	0	12
2014	7	9	2	50	9	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	9	3	0	9	31	0	0	0	0	0	0	0	71.42	0	0	12
2014	7	9	3	10	9	31	0	0	0	0	0	0	0	71.35	0	0	12
2014	7	9	3	20	9	32	0	0	0	0	0	0	0	71.28	0	0	12
2014	7	9	3	30	9	31	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	9	3	40	9	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	9	3	50	9	31	0	0	0	0	0	0	0	71.04	0	0	12
2014	7	9	4	0	9	31	0	0	0	0	0	0	0	70.97	0	0	12
2014	7	9	4	10	9	31	0	0	0	0	0	0	0	70.9	0	0	12
2014	7	9	4	20	9	32	0	0	0	0	0	0	0	70.81	0	0	12
2014	7	9	4	30	9	31	0	0	0	0	0	0	0	70.75	0	0	12
2014	7	9	4	40	9	32	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	9	4	50	9	31	0	0	0	0	0	0	0	70.61	0	0	12
2014	7	9	5	0	9	32	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	9	5	10	9	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	9	5	20	9	31	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	9	5	30	9	31	0	0	0	0	0	0	0	70.32	0	0	12
2014	7	9	5	40	9	31	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	9	5	50	9	32	0	0	0	0	0	0	0	70.18	0	0	12
2014	7	9	6	0	9	31	0	0	0	0	0	0	0	70.09	0	0	12
2014	7	9	6	10	9	31	0	0	0	0	0	0	0	70	0	0	12
2014	7	9	6	20	9	32	0	0	0	0	0	0	0	69.93	0	0	12
2014	7	9	6	30	9	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	9	6	40	9	31	0	0	0	0	0	0	0	69.78	0	0	12
2014	7	9	6	50	9	31	0	0	0	0	0	0	0	69.76	0	0	12.2
2014	7	9	7	0	9	32	0	0	0	0	0	0	0	69.8	0	0	12.2
2014	7	9	7	10	9	31	0	0	0	0	0	0	0	69.82	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	7	20	9	31	0	0	0	0	0	0	0	69.84	0	0	12.2
2014	7	9	7	30	9	31	0	0	0	0	0	0	0	69.87	0	0	12.4
2014	7	9	7	40	9	31	0	0	0	0	0	0	0	69.93	0	0	12.4
2014	7	9	7	50	9	31	0	0	0	0	0	0	0	69.98	0	0	12.6
2014	7	9	8	0	9	31	0	0	0	0	0	0	0	70.07	0	0	12.6
2014	7	9	8	10	9	31	0	0	0	0	0	0	0	70.14	0	0	12.8
2014	7	9	8	20	9	31	0	0	0	0	0	0	0	70.23	0	0	12.6
2014	7	9	8	30	9	31	0	0	0	0	0	0	0	70.36	0	0	12.8
2014	7	9	8	40	9	31	0	0	0	0	0	0	0	70.47	0	0	12.8
2014	7	9	8	50	9	31	0	0	0	0	0	0	0	70.14	0	0	13
2014	7	9	9	0	9	31	0	0	0	0	0	0	0	70.43	0	0	13
2014	7	9	9	10	9	33	0	0	0	0	0	0	0	70.56	0	0	13
2014	7	9	9	20	9	32	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	9	9	30	9	31	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	9	9	40	9	30	0	0	0	0	0	0	0	71.08	0	0	13.2
2014	7	9	9	50	9	31	0	0	0	0	0	0	0	71.24	0	0	13.2
2014	7	9	10	0	9	31	0	0	0	0	0	0	0	71.44	0	0	13.2
2014	7	9	10	10	9	31	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	9	10	20	9	31	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	7	9	10	30	9	32	0	0	0	0	0	0	0	72.12	0	0	13.2
2014	7	9	10	40	9	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2014	7	9	10	50	9	31	0	0	0	0	0	0	0	72.66	0	0	13.2
2014	7	9	11	0	9	31	0	0	0	0	0	0	0	72.97	0	0	13.2
2014	7	9	11	10	9	31	0	0	0	0	0	0	0	73.22	0	0	13.2
2014	7	9	11	20	9	31	0	0	0	0	0	0	0	73.58	0	0	13
2014	7	9	11	30	9	31	0	0	0	0	0	0	0	73.9	0	0	13.2
2014	7	9	11	40	9	31	0	0	0	0	0	0	0	74.26	0	0	13.2
2014	7	9	11	50	9	31	0	0	0	0	0	0	0	74.28	0	0	13.2
2014	7	9	12	0	9	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2014	7	9	12	10	9	31	0	0	0	0	0	0	0	74.61	0	0	13.2
2014	7	9	12	20	9	31	0	0	0	0	0	0	0	74.95	0	0	13.2
2014	7	9	12	30	9	31	0	0	0	0	0	0	0	75.34	0	0	13.2
2014	7	9	12	40	9	30	0	0	0	0	0	0	0	75.72	0	0	13.2
2014	7	9	12	50	9	31	0	0	0	0	0	0	0	76.15	0	0	13.2
2014	7	9	13	0	9	30	0	0	0	0	0	0	0	76.53	0	0	13.2
2014	7	9	13	10	9	31	0	0	0	0	0	0	0	76.98	0	0	13.2
2014	7	9	13	20	9	30	0	0	0	0	0	0	0	77.83	0	0	13
2014	7	9	13	30	9	31	0	0	0	0	0	0	0	78.39	0	0	13.2
2014	7	9	13	40	9	31	0	0	0	0	0	0	0	78.87	0	0	13.2
2014	7	9	13	50	9	30	0	0	0	0	0	0	0	79.32	0	0	13.2
2014	7	9	14	0	9	31	0	0	0	0	0	0	0	79.7	0	0	13
2014	7	9	14	10	9	31	0	0	0	0	0	0	0	79.86	0	0	12.8
2014	7	9	14	20	9	30	0	0	0	0	0	0	0	79.95	0	0	12.4
2014	7	9	14	30	9	30	0	0	0	0	0	0	0	80.51	0	0	13
2014	7	9	14	40	9	30	0	0	0	0	0	0	0	80.56	0	0	12.6
2014	7	9	14	50	9	30	0	0	0	0	0	0	0	81.16	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	15	0	9	30	0	0	0	0	0	0	0	81.37	0	0	13
2014	7	9	15	10	9	30	0	0	0	0	0	0	0	81.16	0	0	12.6
2014	7	9	15	20	9	30	0	0	0	0	0	0	0	81.5	0	0	12.8
2014	7	9	15	30	9	30	0	0	0	0	0	0	0	81.66	0	0	12.8
2014	7	9	15	40	9	30	0	0	0	0	0	0	0	81.82	0	0	12.8
2014	7	9	15	50	9	30	0	0	0	0	0	0	0	81.7	0	0	12.6
2014	7	9	16	0	9	30	0	0	0	0	0	0	0	81.77	0	0	12.4
2014	7	9	16	10	9	29	0	0	0	0	0	0	0	81.93	0	0	12.6
2014	7	9	16	20	9	31	0	0	0	0	0	0	0	81.99	0	0	12.4
2014	7	9	16	30	9	30	0	0	0	0	0	0	0	82.27	0	0	12.6
2014	7	9	16	40	9	30	0	0	0	0	0	0	0	82.44	0	0	12.6
2014	7	9	16	50	9	30	0	0	0	0	0	0	0	82.49	0	0	12.4
2014	7	9	17	0	9	30	0	0	0	0	0	0	0	82.54	0	0	12.4
2014	7	9	17	10	9	30	0	0	0	0	0	0	0	82.53	0	0	12.4
2014	7	9	17	20	9	29	0	0	0	0	0	0	0	82.56	0	0	12.2
2014	7	9	17	30	9	30	0	0	0	0	0	0	0	82.6	0	0	12.4
2014	7	9	17	40	9	30	0	0	0	0	0	0	0	82.6	0	0	12.4
2014	7	9	17	50	9	30	0	0	0	0	0	0	0	82.54	0	0	12.4
2014	7	9	18	0	9	30	0	0	0	0	0	0	0	82.44	0	0	12.2
2014	7	9	18	10	9	30	0	0	0	0	0	0	0	82.33	0	0	12.2
2014	7	9	18	20	9	30	0	0	0	0	0	0	0	82.18	0	0	12.2
2014	7	9	18	30	9	30	0	0	0	0	0	0	0	82.06	0	0	12.2
2014	7	9	18	40	9	30	0	0	0	0	0	0	0	81.91	0	0	12.2
2014	7	9	18	50	9	30	0	0	0	0	0	0	0	81.79	0	0	12.2
2014	7	9	19	0	9	29	0	0	0	0	0	0	0	81.63	0	0	12.2
2014	7	9	19	10	9	29	0	0	0	0	0	0	0	81.5	0	0	12.2
2014	7	9	19	20	9	30	0	0	0	0	0	0	0	81.39	0	0	12.2
2014	7	9	19	30	9	30	0	0	0	0	0	0	0	81.28	0	0	12.2
2014	7	9	19	40	9	30	0	0	0	0	0	0	0	81.18	0	0	12.2
2014	7	9	19	50	9	30	0	0	0	0	0	0	0	81.07	0	0	12.2
2014	7	9	20	0	9	29	0	0	0	0	0	0	0	80.96	0	0	12.2
2014	7	9	20	10	9	30	0	0	0	0	0	0	0	80.87	0	0	12.2
2014	7	9	20	20	9	30	0	0	0	0	0	0	0	80.74	0	0	12
2014	7	9	20	30	9	30	0	0	0	0	0	0	0	80.62	0	0	12.2
2014	7	9	20	40	9	30	0	0	0	0	0	0	0	80.49	0	0	12.2
2014	7	9	20	50	9	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2014	7	9	21	0	9	30	0	0	0	0	0	0	0	80.22	0	0	12.2
2014	7	9	21	10	9	31	0	0	0	0	0	0	0	80.08	0	0	12.2
2014	7	9	21	20	9	30	0	0	0	0	0	0	0	79.95	0	0	12
2014	7	9	21	30	9	30	0	0	0	0	0	0	0	79.83	0	0	12.2
2014	7	9	21	40	9	30	0	0	0	0	0	0	0	79.7	0	0	12.2
2014	7	9	21	50	9	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2014	7	9	22	0	9	30	0	0	0	0	0	0	0	79.47	0	0	12.2
2014	7	9	22	10	9	30	0	0	0	0	0	0	0	79.36	0	0	12.2
2014	7	9	22	20	9	30	0	0	0	0	0	0	0	79.27	0	0	12
2014	7	9	22	30	9	30	0	0	0	0	0	0	0	79.16	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	22	40	9	30	0	0	0	0	0	0	0	79.07	0	0	12.2
2014	7	9	22	50	9	30	0	0	0	0	0	0	0	78.98	0	0	12.2
2014	7	9	23	0	9	30	0	0	0	0	0	0	0	78.89	0	0	12.2
2014	7	9	23	10	9	30	0	0	0	0	0	0	0	78.82	0	0	12
2014	7	9	23	20	9	30	0	0	0	0	0	0	0	78.71	0	0	12
2014	7	9	23	30	9	30	0	0	0	0	0	0	0	78.6	0	0	12
2014	7	9	23	40	9	30	0	0	0	0	0	0	0	78.48	0	0	12
2014	7	9	23	50	9	30	0	0	0	0	0	0	0	78.37	0	0	12
2014	7	10	0	0	9	30	0	0	0	0	0	0	0	78.24	0	0	12
2014	7	10	0	10	9	31	0	0	0	0	0	0	0	78.12	0	0	12
2014	7	10	0	20	9	31	0	0	0	0	0	0	0	77.99	0	0	12
2014	7	10	0	30	9	30	0	0	0	0	0	0	0	77.86	0	0	12
2014	7	10	0	40	9	31	0	0	0	0	0	0	0	77.74	0	0	12
2014	7	10	0	50	9	31	0	0	0	0	0	0	0	77.61	0	0	12
2014	7	10	1	0	9	30	0	0	0	0	0	0	0	77.47	0	0	12
2014	7	10	1	10	9	31	0	0	0	0	0	0	0	77.34	0	0	12
2014	7	10	1	20	9	30	0	0	0	0	0	0	0	77.22	0	0	12
2014	7	10	1	30	9	30	0	0	0	0	0	0	0	77.11	0	0	12
2014	7	10	1	40	9	30	0	0	0	0	0	0	0	76.96	0	0	12
2014	7	10	1	50	9	31	0	0	0	0	0	0	0	76.84	0	0	12
2014	7	10	2	0	9	30	0	0	0	0	0	0	0	76.71	0	0	12
2014	7	10	2	10	9	30	0	0	0	0	0	0	0	76.59	0	0	12
2014	7	10	2	20	9	30	0	0	0	0	0	0	0	76.44	0	0	11.8
2014	7	10	2	30	9	30	0	0	0	0	0	0	0	76.32	0	0	12
2014	7	10	2	40	9	30	0	0	0	0	0	0	0	76.17	0	0	12
2014	7	10	2	50	9	30	0	0	0	0	0	0	0	76.03	0	0	12
2014	7	10	3	0	9	31	0	0	0	0	0	0	0	75.88	0	0	12
2014	7	10	3	10	9	31	0	0	0	0	0	0	0	75.76	0	0	12
2014	7	10	3	20	9	31	0	0	0	0	0	0	0	75.61	0	0	12
2014	7	10	3	30	9	31	0	0	0	0	0	0	0	75.47	0	0	12
2014	7	10	3	40	9	31	0	0	0	0	0	0	0	75.33	0	0	12
2014	7	10	3	50	9	31	0	0	0	0	0	0	0	75.2	0	0	12
2014	7	10	4	0	9	30	0	0	0	0	0	0	0	75.04	0	0	12
2014	7	10	4	10	9	30	0	0	0	0	0	0	0	74.89	0	0	12
2014	7	10	4	20	9	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	10	4	30	9	31	0	0	0	0	0	0	0	74.62	0	0	12
2014	7	10	4	40	9	31	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	10	4	50	9	31	0	0	0	0	0	0	0	74.35	0	0	12
2014	7	10	5	0	9	30	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	10	5	10	9	30	0	0	0	0	0	0	0	74.08	0	0	12
2014	7	10	5	20	9	31	0	0	0	0	0	0	0	73.96	0	0	11.8
2014	7	10	5	30	9	31	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	10	5	40	9	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	10	5	50	9	30	0	0	0	0	0	0	0	73.58	0	0	12
2014	7	10	6	0	9	30	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	10	6	10	9	31	0	0	0	0	0	0	0	73.33	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	6	20	9	31	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	10	6	30	9	30	0	0	0	0	0	0	0	73.08	0	0	12
2014	7	10	6	40	9	31	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	10	6	50	9	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	7	10	7	0	9	30	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	10	7	10	9	31	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	10	7	20	9	32	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	10	7	30	9	31	0	0	0	0	0	0	0	72.64	0	0	12.4
2014	7	10	7	40	9	31	0	0	0	0	0	0	0	72.61	0	0	12.4
2014	7	10	7	50	9	31	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	10	8	0	9	31	0	0	0	0	0	0	0	72.59	0	0	12.6
2014	7	10	8	10	9	31	0	0	0	0	0	0	0	72.63	0	0	12.8
2014	7	10	8	20	9	30	0	0	0	0	0	0	0	72.64	0	0	12.8
2014	7	10	8	30	9	30	0	0	0	0	0	0	0	72.73	0	0	12.8
2014	7	10	8	40	9	32	0	0	0	0	0	0	0	72.79	0	0	13
2014	7	10	8	50	9	31	0	0	0	0	0	0	0	72.88	0	0	13
2014	7	10	9	0	9	31	0	0	0	0	0	0	0	73	0	0	13
2014	7	10	9	10	9	31	0	0	0	0	0	0	0	73.09	0	0	13
2014	7	10	9	20	9	32	0	0	0	0	0	0	0	73.22	0	0	13
2014	7	10	9	30	9	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2014	7	10	9	40	9	31	0	0	0	0	0	0	0	73.45	0	0	13.2
2014	7	10	9	50	9	31	0	0	0	0	0	0	0	73.63	0	0	13.2
2014	7	10	10	0	9	31	0	0	0	0	0	0	0	73.47	0	0	13
2014	7	10	10	10	9	31	0	0	0	0	0	0	0	73.76	0	0	13.2
2014	7	10	10	20	9	31	0	0	0	0	0	0	0	74.05	0	0	13.2
2014	7	10	10	30	9	30	0	0	0	0	0	0	0	74.26	0	0	13.2
2014	7	10	10	40	9	31	0	0	0	0	0	0	0	74.52	0	0	13.2
2014	7	10	10	50	9	31	0	0	0	0	0	0	0	74.75	0	0	13.2
2014	7	10	11	0	9	31	0	0	0	0	0	0	0	74.93	0	0	13.2
2014	7	10	11	10	9	30	0	0	0	0	0	0	0	75.18	0	0	13.2
2014	7	10	11	20	9	31	0	0	0	0	0	0	0	75.25	0	0	13
2014	7	10	11	30	9	31	0	0	0	0	0	0	0	75.34	0	0	13
2014	7	10	11	40	9	31	0	0	0	0	0	0	0	75.52	0	0	12.8
2014	7	10	11	50	9	30	0	0	0	0	0	0	0	75.7	0	0	13.2
2014	7	10	12	0	9	31	0	0	0	0	0	0	0	75.81	0	0	13.2
2014	7	10	12	10	9	31	0	0	0	0	0	0	0	76.01	0	0	13.2
2014	7	10	12	20	9	30	0	0	0	0	0	0	0	76.24	0	0	13
2014	7	10	12	30	9	30	0	0	0	0	0	0	0	76.51	0	0	13.2
2014	7	10	12	40	9	31	0	0	0	0	0	0	0	76.89	0	0	13.2
2014	7	10	12	50	9	31	0	0	0	0	0	0	0	77.27	0	0	13.2
2014	7	10	13	0	9	31	0	0	0	0	0	0	0	77.59	0	0	13.2
2014	7	10	13	10	9	30	0	0	0	0	0	0	0	77.95	0	0	13.2
2014	7	10	13	20	9	31	0	0	0	0	0	0	0	78.67	0	0	13
2014	7	10	13	30	9	30	0	0	0	0	0	0	0	78.96	0	0	13
2014	7	10	13	40	9	30	0	0	0	0	0	0	0	79.39	0	0	13.2
2014	7	10	13	50	9	31	0	0	0	0	0	0	0	79.27	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	14	0	9	31	0	0	0	0	0	0	0	79.7	0	0	13.2
2014	7	10	14	10	9	30	0	0	0	0	0	0	0	79.81	0	0	13
2014	7	10	14	20	9	31	0	0	0	0	0	0	0	79.92	0	0	13
2014	7	10	14	30	9	30	0	0	0	0	0	0	0	80.1	0	0	13.2
2014	7	10	14	40	9	31	0	0	0	0	0	0	0	79.95	0	0	12.8
2014	7	10	14	50	9	30	0	0	0	0	0	0	0	80.06	0	0	13
2014	7	10	15	0	9	30	0	0	0	0	0	0	0	80.11	0	0	12.8
2014	7	10	15	10	9	30	0	0	0	0	0	0	0	80.11	0	0	12.6
2014	7	10	15	20	9	30	0	0	0	0	0	0	0	80.19	0	0	12.8
2014	7	10	15	30	9	30	0	0	0	0	0	0	0	80.26	0	0	12.8
2014	7	10	15	40	9	30	0	0	0	0	0	0	0	80.19	0	0	12.6
2014	7	10	15	50	9	30	0	0	0	0	0	0	0	80.1	0	0	12.6
2014	7	10	16	0	9	30	0	0	0	0	0	0	0	80.24	0	0	12.6
2014	7	10	16	10	9	30	0	0	0	0	0	0	0	80.24	0	0	12.6
2014	7	10	16	20	9	30	0	0	0	0	0	0	0	80.2	0	0	12.6
2014	7	10	16	30	9	30	0	0	0	0	0	0	0	80.22	0	0	12.6
2014	7	10	16	40	9	30	0	0	0	0	0	0	0	80.13	0	0	12.4
2014	7	10	16	50	9	30	0	0	0	0	0	0	0	80.17	0	0	12.4
2014	7	10	17	0	9	30	0	0	0	0	0	0	0	80.06	0	0	12.4
2014	7	10	17	10	9	30	0	0	0	0	0	0	0	80.01	0	0	12.4
2014	7	10	17	20	9	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	10	17	30	9	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	10	17	40	9	30	0	0	0	0	0	0	0	79.65	0	0	12.2
2014	7	10	17	50	9	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2014	7	10	18	0	9	30	0	0	0	0	0	0	0	79.43	0	0	12.2
2014	7	10	18	10	9	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	10	18	20	9	30	0	0	0	0	0	0	0	79.16	0	0	12.2
2014	7	10	18	30	9	30	0	0	0	0	0	0	0	78.96	0	0	12.2
2014	7	10	18	40	9	30	0	0	0	0	0	0	0	78.76	0	0	12.2
2014	7	10	18	50	9	31	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	10	19	0	9	31	0	0	0	0	0	0	0	78.37	0	0	12.2
2014	7	10	19	10	9	30	0	0	0	0	0	0	0	78.19	0	0	12.2
2014	7	10	19	20	9	30	0	0	0	0	0	0	0	78.01	0	0	12.2
2014	7	10	19	30	9	30	0	0	0	0	0	0	0	77.83	0	0	12.2
2014	7	10	19	40	9	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	10	19	50	9	31	0	0	0	0	0	0	0	77.49	0	0	12.2
2014	7	10	20	0	9	30	0	0	0	0	0	0	0	77.32	0	0	12.2
2014	7	10	20	10	9	30	0	0	0	0	0	0	0	77.16	0	0	12.2
2014	7	10	20	20	9	31	0	0	0	0	0	0	0	77	0	0	12
2014	7	10	20	30	9	30	0	0	0	0	0	0	0	76.84	0	0	12.2
2014	7	10	20	40	9	30	0	0	0	0	0	0	0	76.66	0	0	12.2
2014	7	10	20	50	9	31	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	7	10	21	0	9	32	0	0	0	0	0	0	0	76.28	0	0	12.2
2014	7	10	21	10	9	31	0	0	0	0	0	0	0	76.08	0	0	12.2
2014	7	10	21	20	9	30	0	0	0	0	0	0	0	75.88	0	0	12.2
2014	7	10	21	30	9	31	0	0	0	0	0	0	0	75.69	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	21	40	9	31	0	0	0	0	0	0	0	75.49	0	0	12.2
2014	7	10	21	50	9	31	0	0	0	0	0	0	0	75.29	0	0	12.2
2014	7	10	22	0	9	31	0	0	0	0	0	0	0	75.13	0	0	12.2
2014	7	10	22	10	9	31	0	0	0	0	0	0	0	74.97	0	0	12.2
2014	7	10	22	20	9	31	0	0	0	0	0	0	0	74.82	0	0	12
2014	7	10	22	30	9	31	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	10	22	40	9	31	0	0	0	0	0	0	0	74.57	0	0	12
2014	7	10	22	50	9	30	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	10	23	0	9	30	0	0	0	0	0	0	0	74.3	0	0	12
2014	7	10	23	10	9	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	10	23	20	9	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	10	23	30	9	31	0	0	0	0	0	0	0	73.9	0	0	12
2014	7	10	23	40	9	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	10	23	50	9	31	0	0	0	0	0	0	0	73.62	0	0	12
2014	7	11	0	0	9	31	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	11	0	10	9	31	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	11	0	20	9	30	0	0	0	0	0	0	0	73.22	0	0	12
2014	7	11	0	30	9	30	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	11	0	40	9	32	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	11	0	50	9	31	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	11	1	0	9	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	11	1	10	9	31	0	0	0	0	0	0	0	72.7	0	0	12
2014	7	11	1	20	9	31	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	11	1	30	9	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	11	1	40	9	32	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	11	1	50	9	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	11	2	0	9	31	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	11	2	10	9	31	0	0	0	0	0	0	0	72.16	0	0	12
2014	7	11	2	20	9	31	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	11	2	30	9	31	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	11	2	40	9	31	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	11	2	50	9	32	0	0	0	0	0	0	0	71.76	0	0	12
2014	7	11	3	0	9	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	7	11	3	10	9	32	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	11	3	20	9	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	11	3	30	9	32	0	0	0	0	0	0	0	71.28	0	0	12
2014	7	11	3	40	9	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	11	3	50	9	31	0	0	0	0	0	0	0	70.97	0	0	12
2014	7	11	4	0	9	31	0	0	0	0	0	0	0	70.84	0	0	12
2014	7	11	4	10	9	31	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	11	4	20	9	31	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	11	4	30	9	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	7	11	4	40	9	32	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	11	4	50	9	31	0	0	0	0	0	0	0	70.09	0	0	12
2014	7	11	5	0	9	32	0	0	0	0	0	0	0	69.93	0	0	12
2014	7	11	5	10	9	31	0	0	0	0	0	0	0	69.76	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	5	20	9	31	0	0	0	0	0	0	0	69.6	0	0	12
2014	7	11	5	30	9	32	0	0	0	0	0	0	0	69.46	0	0	12
2014	7	11	5	40	9	30	0	0	0	0	0	0	0	69.31	0	0	12
2014	7	11	5	50	9	32	0	0	0	0	0	0	0	69.19	0	0	12
2014	7	11	6	0	9	31	0	0	0	0	0	0	0	69.04	0	0	12
2014	7	11	6	10	9	31	0	0	0	0	0	0	0	68.92	0	0	12
2014	7	11	6	20	9	32	0	0	0	0	0	0	0	68.77	0	0	11.8
2014	7	11	6	30	9	31	0	0	0	0	0	0	0	68.65	0	0	12
2014	7	11	6	40	9	33	0	0	0	0	0	0	0	68.5	0	0	12
2014	7	11	6	50	9	31	0	0	0	0	0	0	0	68.4	0	0	12
2014	7	11	7	0	9	32	0	0	0	0	0	0	0	68.38	0	0	12.2
2014	7	11	7	10	9	32	0	0	0	0	0	0	0	68.32	0	0	12.2
2014	7	11	7	20	9	31	0	0	0	0	0	0	0	68.23	0	0	12.2
2014	7	11	7	30	9	31	0	0	0	0	0	0	0	68.18	0	0	12.2
2014	7	11	7	40	9	32	0	0	0	0	0	0	0	68.13	0	0	12.2
2014	7	11	7	50	9	32	0	0	0	0	0	0	0	68.02	0	0	12.2
2014	7	11	8	0	9	32	0	0	0	0	0	0	0	68.09	0	0	12.4
2014	7	11	8	10	9	32	0	0	0	0	0	0	0	68.04	0	0	12.4
2014	7	11	8	20	9	32	0	0	0	0	0	0	0	68	0	0	12.2
2014	7	11	8	30	9	31	0	0	0	0	0	0	0	68.02	0	0	12.2
2014	7	11	8	40	9	32	0	0	0	0	0	0	0	68.11	0	0	12.6
2014	7	11	8	50	9	32	0	0	0	0	0	0	0	68.45	0	0	13
2014	7	11	9	0	9	32	0	0	0	0	0	0	0	68.4	0	0	12.8
2014	7	11	9	10	9	31	0	0	0	0	0	0	0	68.38	0	0	12.6
2014	7	11	9	20	9	31	0	0	0	0	0	0	0	68.49	0	0	12.6
2014	7	11	9	30	9	32	0	0	0	0	0	0	0	68.49	0	0	12.6
2014	7	11	9	40	9	32	0	0	0	0	0	0	0	68.81	0	0	13
2014	7	11	9	50	9	31	0	0	0	0	0	0	0	69.01	0	0	13.2
2014	7	11	10	0	9	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2014	7	11	10	10	9	32	0	0	0	0	0	0	0	69.55	0	0	13.2
2014	7	11	10	20	9	32	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	11	10	30	9	31	0	0	0	0	0	0	0	70.05	0	0	13.2
2014	7	11	10	40	9	31	0	0	0	0	0	0	0	70.38	0	0	13.4
2014	7	11	10	50	9	31	0	0	0	0	0	0	0	70.68	0	0	13.4
2014	7	11	11	0	9	31	0	0	0	0	0	0	0	71.02	0	0	13.2
2014	7	11	11	10	9	31	0	0	0	0	0	0	0	71.33	0	0	13.2
2014	7	11	11	20	9	31	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	11	11	30	9	32	0	0	0	0	0	0	0	72.01	0	0	13.2
2014	7	11	11	40	9	32	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	11	11	50	9	31	0	0	0	0	0	0	0	72.25	0	0	13.2
2014	7	11	12	0	9	31	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	11	12	10	9	31	0	0	0	0	0	0	0	72.63	0	0	13.2
2014	7	11	12	20	9	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2014	7	11	12	30	9	31	0	0	0	0	0	0	0	73.31	0	0	13.2
2014	7	11	12	40	9	32	0	0	0	0	0	0	0	73.67	0	0	13.2
2014	7	11	12	50	9	30	0	0	0	0	0	0	0	74.07	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	13	0	9	32	0	0	0	0	0	0	0	74.46	0	0	13.2
2014	7	11	13	10	9	31	0	0	0	0	0	0	0	74.88	0	0	13.2
2014	7	11	13	20	9	31	0	0	0	0	0	0	0	75.7	0	0	13.2
2014	7	11	13	30	9	31	0	0	0	0	0	0	0	76.21	0	0	13.2
2014	7	11	13	40	9	31	0	0	0	0	0	0	0	76.6	0	0	13.2
2014	7	11	13	50	9	31	0	0	0	0	0	0	0	76.96	0	0	13.2
2014	7	11	14	0	9	31	0	0	0	0	0	0	0	77.32	0	0	13.2
2014	7	11	14	10	9	30	0	0	0	0	0	0	0	77.65	0	0	13.2
2014	7	11	14	20	9	30	0	0	0	0	0	0	0	77.95	0	0	13
2014	7	11	14	30	9	31	0	0	0	0	0	0	0	78.26	0	0	13.2
2014	7	11	14	40	9	30	0	0	0	0	0	0	0	78.53	0	0	13.2
2014	7	11	14	50	9	31	0	0	0	0	0	0	0	78.82	0	0	13
2014	7	11	15	0	9	30	0	0	0	0	0	0	0	79.05	0	0	13
2014	7	11	15	10	9	30	0	0	0	0	0	0	0	79.3	0	0	13
2014	7	11	15	20	9	31	0	0	0	0	0	0	0	79.52	0	0	12.8
2014	7	11	15	30	9	31	0	0	0	0	0	0	0	79.74	0	0	12.8
2014	7	11	15	40	9	30	0	0	0	0	0	0	0	79.93	0	0	12.8
2014	7	11	15	50	9	30	0	0	0	0	0	0	0	80.1	0	0	12.8
2014	7	11	16	0	9	30	0	0	0	0	0	0	0	80.24	0	0	12.8
2014	7	11	16	10	9	31	0	0	0	0	0	0	0	80.38	0	0	12.6
2014	7	11	16	20	9	30	0	0	0	0	0	0	0	80.53	0	0	12.4
2014	7	11	16	30	9	30	0	0	0	0	0	0	0	80.62	0	0	12.6
2014	7	11	16	40	9	30	0	0	0	0	0	0	0	80.71	0	0	12.4
2014	7	11	16	50	9	30	0	0	0	0	0	0	0	80.8	0	0	12.4
2014	7	11	17	0	9	30	0	0	0	0	0	0	0	80.83	0	0	12.4
2014	7	11	17	10	9	29	0	0	0	0	0	0	0	80.87	0	0	12.4
2014	7	11	17	20	9	31	0	0	0	0	0	0	0	80.87	0	0	12.2
2014	7	11	17	30	9	30	0	0	0	0	0	0	0	80.85	0	0	12.2
2014	7	11	17	40	9	30	0	0	0	0	0	0	0	80.64	0	0	12.2
2014	7	11	17	50	9	30	0	0	0	0	0	0	0	80.55	0	0	12.2
2014	7	11	18	0	9	30	0	0	0	0	0	0	0	80.46	0	0	12.2
2014	7	11	18	10	9	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2014	7	11	18	20	9	30	0	0	0	0	0	0	0	80.26	0	0	12.2
2014	7	11	18	30	9	31	0	0	0	0	0	0	0	80.13	0	0	12.2
2014	7	11	18	40	9	30	0	0	0	0	0	0	0	79.99	0	0	12.2
2014	7	11	18	50	9	30	0	0	0	0	0	0	0	79.83	0	0	12.2
2014	7	11	19	0	9	30	0	0	0	0	0	0	0	79.68	0	0	12.2
2014	7	11	19	10	9	30	0	0	0	0	0	0	0	79.5	0	0	12.2
2014	7	11	19	20	9	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	11	19	30	9	31	0	0	0	0	0	0	0	79.11	0	0	12.2
2014	7	11	19	40	9	30	0	0	0	0	0	0	0	78.91	0	0	12.2
2014	7	11	19	50	9	30	0	0	0	0	0	0	0	78.73	0	0	12.2
2014	7	11	20	0	9	31	0	0	0	0	0	0	0	78.53	0	0	12.2
2014	7	11	20	10	9	30	0	0	0	0	0	0	0	78.35	0	0	12.2
2014	7	11	20	20	9	30	0	0	0	0	0	0	0	78.15	0	0	12.2
2014	7	11	20	30	9	30	0	0	0	0	0	0	0	77.97	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	20	40	9	30	0	0	0	0	0	0	0	77.79	0	0	12.2
2014	7	11	20	50	9	30	0	0	0	0	0	0	0	77.61	0	0	12.2
2014	7	11	21	0	9	30	0	0	0	0	0	0	0	77.43	0	0	12.2
2014	7	11	21	10	9	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2014	7	11	21	20	9	31	0	0	0	0	0	0	0	77.04	0	0	12
2014	7	11	21	30	9	31	0	0	0	0	0	0	0	76.84	0	0	12.2
2014	7	11	21	40	9	30	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	11	21	50	9	30	0	0	0	0	0	0	0	76.44	0	0	12.2
2014	7	11	22	0	9	31	0	0	0	0	0	0	0	76.24	0	0	12.2
2014	7	11	22	10	9	31	0	0	0	0	0	0	0	76.05	0	0	12.2
2014	7	11	22	20	9	30	0	0	0	0	0	0	0	75.87	0	0	12
2014	7	11	22	30	9	31	0	0	0	0	0	0	0	75.67	0	0	12.2
2014	7	11	22	40	9	30	0	0	0	0	0	0	0	75.47	0	0	12
2014	7	11	22	50	9	31	0	0	0	0	0	0	0	75.31	0	0	12
2014	7	11	23	0	9	31	0	0	0	0	0	0	0	75.13	0	0	12
2014	7	11	23	10	9	31	0	0	0	0	0	0	0	74.95	0	0	12
2014	7	11	23	20	9	31	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	11	23	30	9	31	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	11	23	40	9	31	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	11	23	50	9	31	0	0	0	0	0	0	0	74.28	0	0	12
2014	7	12	0	0	9	31	0	0	0	0	0	0	0	74.16	0	0	12
2014	7	12	0	10	9	31	0	0	0	0	0	0	0	73.99	0	0	12
2014	7	12	0	20	9	30	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	12	0	30	9	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	12	0	40	9	31	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	12	0	50	9	31	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	12	1	0	9	30	0	0	0	0	0	0	0	73.42	0	0	12
2014	7	12	1	10	9	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	12	1	20	9	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	12	1	30	9	30	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	12	1	40	9	31	0	0	0	0	0	0	0	73	0	0	12
2014	7	12	1	50	9	31	0	0	0	0	0	0	0	72.91	0	0	12
2014	7	12	2	0	9	31	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	12	2	10	9	30	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	12	2	20	9	31	0	0	0	0	0	0	0	72.59	0	0	12
2014	7	12	2	30	9	31	0	0	0	0	0	0	0	72.48	0	0	12
2014	7	12	2	40	9	32	0	0	0	0	0	0	0	72.36	0	0	12
2014	7	12	2	50	9	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	12	3	0	9	31	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	12	3	10	9	31	0	0	0	0	0	0	0	72.03	0	0	12
2014	7	12	3	20	9	32	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	12	3	30	9	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	12	3	40	9	31	0	0	0	0	0	0	0	71.65	0	0	12
2014	7	12	3	50	9	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	7	12	4	0	9	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	12	4	10	9	31	0	0	0	0	0	0	0	71.29	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	4	20	9	31	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	12	4	30	9	31	0	0	0	0	0	0	0	71.04	0	0	12
2014	7	12	4	40	9	31	0	0	0	0	0	0	0	70.92	0	0	12
2014	7	12	4	50	9	32	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	12	5	0	9	31	0	0	0	0	0	0	0	70.65	0	0	12
2014	7	12	5	10	9	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	7	12	5	20	9	31	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	12	5	30	9	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	7	12	5	40	9	31	0	0	0	0	0	0	0	70.09	0	0	12
2014	7	12	5	50	9	31	0	0	0	0	0	0	0	69.94	0	0	12
2014	7	12	6	0	9	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	7	12	6	10	9	31	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	12	6	20	9	32	0	0	0	0	0	0	0	69.53	0	0	11.8
2014	7	12	6	30	9	31	0	0	0	0	0	0	0	69.4	0	0	12
2014	7	12	6	40	9	32	0	0	0	0	0	0	0	69.3	0	0	12
2014	7	12	6	50	9	32	0	0	0	0	0	0	0	69.17	0	0	12
2014	7	12	7	0	9	32	0	0	0	0	0	0	0	69.21	0	0	12.2
2014	7	12	7	10	9	31	0	0	0	0	0	0	0	69.17	0	0	12.2
2014	7	12	7	20	9	31	0	0	0	0	0	0	0	69.13	0	0	12.2
2014	7	12	7	30	9	31	0	0	0	0	0	0	0	69.13	0	0	12.4
2014	7	12	7	40	9	32	0	0	0	0	0	0	0	69.12	0	0	12.6
2014	7	12	7	50	9	32	0	0	0	0	0	0	0	69.15	0	0	12.6
2014	7	12	8	0	9	32	0	0	0	0	0	0	0	69.19	0	0	12.8
2014	7	12	8	10	9	32	0	0	0	0	0	0	0	69.24	0	0	12.8
2014	7	12	8	20	9	31	0	0	0	0	0	0	0	69.3	0	0	12.8
2014	7	12	8	30	9	32	0	0	0	0	0	0	0	69.39	0	0	13
2014	7	12	8	40	9	32	0	0	0	0	0	0	0	69.51	0	0	13
2014	7	12	8	50	9	31	0	0	0	0	0	0	0	69.55	0	0	13
2014	7	12	9	0	9	31	0	0	0	0	0	0	0	69.64	0	0	13
2014	7	12	9	10	9	32	0	0	0	0	0	0	0	69.75	0	0	13.2
2014	7	12	9	20	9	32	0	0	0	0	0	0	0	69.91	0	0	13.2
2014	7	12	9	30	9	32	0	0	0	0	0	0	0	70	0	0	13.2
2014	7	12	9	40	9	31	0	0	0	0	0	0	0	70.14	0	0	13.2
2014	7	12	9	50	9	31	0	0	0	0	0	0	0	70.29	0	0	13.2
2014	7	12	10	0	9	31	0	0	0	0	0	0	0	70.48	0	0	13.2
2014	7	12	10	10	9	32	0	0	0	0	0	0	0	70.7	0	0	13.2
2014	7	12	10	20	9	32	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	7	12	10	30	9	31	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	7	12	10	40	9	31	0	0	0	0	0	0	0	71.33	0	0	13.2
2014	7	12	10	50	9	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	7	12	11	0	9	31	0	0	0	0	0	0	0	71.82	0	0	13.2
2014	7	12	11	10	9	31	0	0	0	0	0	0	0	72.09	0	0	13.2
2014	7	12	11	20	9	31	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	7	12	11	30	9	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2014	7	12	11	40	9	31	0	0	0	0	0	0	0	72.97	0	0	13.2
2014	7	12	11	50	9	31	0	0	0	0	0	0	0	72.72	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	12	0	9	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2014	7	12	12	10	9	31	0	0	0	0	0	0	0	72.95	0	0	13.2
2014	7	12	12	20	9	31	0	0	0	0	0	0	0	73.27	0	0	13.2
2014	7	12	12	30	9	32	0	0	0	0	0	0	0	73.6	0	0	13.2
2014	7	12	12	40	9	31	0	0	0	0	0	0	0	73.99	0	0	13.2
2014	7	12	12	50	9	31	0	0	0	0	0	0	0	74.37	0	0	13.2
2014	7	12	13	0	9	31	0	0	0	0	0	0	0	74.77	0	0	13.2
2014	7	12	13	10	9	31	0	0	0	0	0	0	0	75.22	0	0	13.2
2014	7	12	13	20	9	31	0	0	0	0	0	0	0	76.26	0	0	13.2
2014	7	12	13	30	9	31	0	0	0	0	0	0	0	76.84	0	0	13.2
2014	7	12	13	40	9	30	0	0	0	0	0	0	0	77.29	0	0	13.2
2014	7	12	13	50	9	31	0	0	0	0	0	0	0	77.68	0	0	13.2
2014	7	12	14	0	9	31	0	0	0	0	0	0	0	78.01	0	0	13.2
2014	7	12	14	10	9	31	0	0	0	0	0	0	0	78.39	0	0	13.2
2014	7	12	14	20	9	31	0	0	0	0	0	0	0	78.75	0	0	13
2014	7	12	14	30	9	31	0	0	0	0	0	0	0	79.05	0	0	13.2
2014	7	12	14	40	9	31	0	0	0	0	0	0	0	79.38	0	0	13.2
2014	7	12	14	50	9	30	0	0	0	0	0	0	0	79.7	0	0	13.2
2014	7	12	15	0	9	30	0	0	0	0	0	0	0	80.01	0	0	13
2014	7	12	15	10	9	31	0	0	0	0	0	0	0	80.28	0	0	13
2014	7	12	15	20	9	30	0	0	0	0	0	0	0	80.55	0	0	12.8
2014	7	12	15	30	9	30	0	0	0	0	0	0	0	80.78	0	0	13
2014	7	12	15	40	9	31	0	0	0	0	0	0	0	81.01	0	0	12.8
2014	7	12	15	50	9	30	0	0	0	0	0	0	0	81.25	0	0	12.8
2014	7	12	16	0	9	30	0	0	0	0	0	0	0	81.45	0	0	12.8
2014	7	12	16	10	9	31	0	0	0	0	0	0	0	81.66	0	0	12.8
2014	7	12	16	20	9	30	0	0	0	0	0	0	0	81.84	0	0	12.6
2014	7	12	16	30	9	31	0	0	0	0	0	0	0	82.02	0	0	12.6
2014	7	12	16	40	9	30	0	0	0	0	0	0	0	82.18	0	0	12.6
2014	7	12	16	50	9	30	0	0	0	0	0	0	0	82.29	0	0	12.4
2014	7	12	17	0	9	30	0	0	0	0	0	0	0	82.42	0	0	12.4
2014	7	12	17	10	9	30	0	0	0	0	0	0	0	82.54	0	0	12.4
2014	7	12	17	20	9	30	0	0	0	0	0	0	0	82.63	0	0	12.4
2014	7	12	17	30	9	30	0	0	0	0	0	0	0	82.67	0	0	12.4
2014	7	12	17	40	9	30	0	0	0	0	0	0	0	82.49	0	0	12.4
2014	7	12	17	50	9	30	0	0	0	0	0	0	0	82.47	0	0	12.4
2014	7	12	18	0	9	30	0	0	0	0	0	0	0	82.47	0	0	12.4
2014	7	12	18	10	9	31	0	0	0	0	0	0	0	82.44	0	0	12.2
2014	7	12	18	20	9	29	0	0	0	0	0	0	0	82.4	0	0	12.2
2014	7	12	18	30	9	30	0	0	0	0	0	0	0	82.35	0	0	12.2
2014	7	12	18	40	9	30	0	0	0	0	0	0	0	82.26	0	0	12.2
2014	7	12	18	50	9	30	0	0	0	0	0	0	0	82.17	0	0	12.2
2014	7	12	19	0	9	30	0	0	0	0	0	0	0	82.04	0	0	12.2
2014	7	12	19	10	9	30	0	0	0	0	0	0	0	81.91	0	0	12.2
2014	7	12	19	20	9	30	0	0	0	0	0	0	0	81.81	0	0	12.2
2014	7	12	19	30	9	30	0	0	0	0	0	0	0	81.66	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	19	40	9	30	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	12	19	50	9	30	0	0	0	0	0	0	0	81.39	0	0	12.2
2014	7	12	20	0	9	31	0	0	0	0	0	0	0	81.27	0	0	12.2
2014	7	12	20	10	9	30	0	0	0	0	0	0	0	81.1	0	0	12.2
2014	7	12	20	20	9	30	0	0	0	0	0	0	0	80.94	0	0	12
2014	7	12	20	30	9	30	0	0	0	0	0	0	0	80.8	0	0	12.2
2014	7	12	20	40	9	31	0	0	0	0	0	0	0	80.65	0	0	12.2
2014	7	12	20	50	9	30	0	0	0	0	0	0	0	80.47	0	0	12.2
2014	7	12	21	0	9	30	0	0	0	0	0	0	0	80.31	0	0	12.2
2014	7	12	21	10	9	30	0	0	0	0	0	0	0	80.15	0	0	12.2
2014	7	12	21	20	9	30	0	0	0	0	0	0	0	79.97	0	0	12.2
2014	7	12	21	30	9	31	0	0	0	0	0	0	0	79.79	0	0	12.2
2014	7	12	21	40	9	31	0	0	0	0	0	0	0	79.59	0	0	12.2
2014	7	12	21	50	9	30	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	12	22	0	9	30	0	0	0	0	0	0	0	79.21	0	0	12.2
2014	7	12	22	10	9	30	0	0	0	0	0	0	0	79	0	0	12.2
2014	7	12	22	20	9	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2014	7	12	22	30	9	30	0	0	0	0	0	0	0	78.58	0	0	12.2
2014	7	12	22	40	9	29	0	0	0	0	0	0	0	78.35	0	0	12.2
2014	7	12	22	50	9	31	0	0	0	0	0	0	0	78.13	0	0	12.2
2014	7	12	23	0	9	30	0	0	0	0	0	0	0	77.9	0	0	12.2
2014	7	12	23	10	9	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	12	23	20	9	30	0	0	0	0	0	0	0	77.43	0	0	12
2014	7	12	23	30	9	30	0	0	0	0	0	0	0	77.22	0	0	12
2014	7	12	23	40	9	31	0	0	0	0	0	0	0	76.98	0	0	12
2014	7	12	23	50	9	30	0	0	0	0	0	0	0	76.75	0	0	12
2014	7	13	0	0	9	31	0	0	0	0	0	0	0	76.55	0	0	12
2014	7	13	0	10	9	31	0	0	0	0	0	0	0	76.32	0	0	12
2014	7	13	0	20	9	31	0	0	0	0	0	0	0	76.12	0	0	12
2014	7	13	0	30	9	30	0	0	0	0	0	0	0	75.92	0	0	12
2014	7	13	0	40	9	31	0	0	0	0	0	0	0	75.72	0	0	12
2014	7	13	0	50	9	30	0	0	0	0	0	0	0	75.54	0	0	12
2014	7	13	1	0	9	31	0	0	0	0	0	0	0	75.36	0	0	12
2014	7	13	1	10	9	31	0	0	0	0	0	0	0	75.2	0	0	12
2014	7	13	1	20	9	31	0	0	0	0	0	0	0	75.04	0	0	12
2014	7	13	1	30	9	31	0	0	0	0	0	0	0	74.88	0	0	12
2014	7	13	1	40	9	31	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	13	1	50	9	31	0	0	0	0	0	0	0	74.55	0	0	12
2014	7	13	2	0	9	30	0	0	0	0	0	0	0	74.41	0	0	12
2014	7	13	2	10	9	31	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	13	2	20	9	31	0	0	0	0	0	0	0	74.08	0	0	12
2014	7	13	2	30	9	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	13	2	40	9	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	13	2	50	9	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	13	3	0	9	31	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	13	3	10	9	31	0	0	0	0	0	0	0	73.31	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	3	20	9	31	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	13	3	30	9	30	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	13	3	40	9	30	0	0	0	0	0	0	0	72.91	0	0	12
2014	7	13	3	50	9	31	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	13	4	0	9	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	13	4	10	9	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	13	4	20	9	31	0	0	0	0	0	0	0	72.39	0	0	12
2014	7	13	4	30	9	31	0	0	0	0	0	0	0	72.27	0	0	12
2014	7	13	4	40	9	31	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	13	4	50	9	32	0	0	0	0	0	0	0	72	0	0	12
2014	7	13	5	0	9	31	0	0	0	0	0	0	0	71.87	0	0	12
2014	7	13	5	10	9	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	13	5	20	9	31	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	13	5	30	9	30	0	0	0	0	0	0	0	71.46	0	0	12
2014	7	13	5	40	9	32	0	0	0	0	0	0	0	71.31	0	0	12
2014	7	13	5	50	9	32	0	0	0	0	0	0	0	71.19	0	0	12
2014	7	13	6	0	9	31	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	13	6	10	9	30	0	0	0	0	0	0	0	70.92	0	0	12
2014	7	13	6	20	9	31	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	13	6	30	9	31	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	13	6	40	9	31	0	0	0	0	0	0	0	70.57	0	0	12
2014	7	13	6	50	9	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	13	7	0	9	31	0	0	0	0	0	0	0	70.56	0	0	12.2
2014	7	13	7	10	9	32	0	0	0	0	0	0	0	70.59	0	0	12.2
2014	7	13	7	20	9	31	0	0	0	0	0	0	0	70.56	0	0	12.2
2014	7	13	7	30	9	31	0	0	0	0	0	0	0	70.5	0	0	12.4
2014	7	13	7	40	9	31	0	0	0	0	0	0	0	70.63	0	0	12.6
2014	7	13	7	50	9	32	0	0	0	0	0	0	0	70.65	0	0	12.6
2014	7	13	8	0	9	31	0	0	0	0	0	0	0	70.72	0	0	12.8
2014	7	13	8	10	9	31	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	13	8	20	9	31	0	0	0	0	0	0	0	70.95	0	0	12.8
2014	7	13	8	30	9	31	0	0	0	0	0	0	0	71.1	0	0	13
2014	7	13	8	40	9	31	0	0	0	0	0	0	0	71.28	0	0	13
2014	7	13	8	50	9	31	0	0	0	0	0	0	0	71.4	0	0	13
2014	7	13	9	0	9	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	7	13	9	10	9	31	0	0	0	0	0	0	0	71.67	0	0	13.2
2014	7	13	9	20	9	31	0	0	0	0	0	0	0	71.87	0	0	13
2014	7	13	9	30	9	32	0	0	0	0	0	0	0	72	0	0	13.2
2014	7	13	9	40	9	31	0	0	0	0	0	0	0	72.18	0	0	13.2
2014	7	13	9	50	9	31	0	0	0	0	0	0	0	72.41	0	0	13.2
2014	7	13	10	0	9	32	0	0	0	0	0	0	0	72.59	0	0	13.2
2014	7	13	10	10	9	31	0	0	0	0	0	0	0	72.86	0	0	13.2
2014	7	13	10	20	9	31	0	0	0	0	0	0	0	73.06	0	0	13.2
2014	7	13	10	30	9	31	0	0	0	0	0	0	0	73.29	0	0	13.2
2014	7	13	10	40	9	31	0	0	0	0	0	0	0	73.38	0	0	13.2
2014	7	13	10	50	9	32	0	0	0	0	0	0	0	73.71	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	11	0	9	31	0	0	0	0	0	0	0	74.03	0	0	13.2
2014	7	13	11	10	9	31	0	0	0	0	0	0	0	74.48	0	0	13.2
2014	7	13	11	20	9	31	0	0	0	0	0	0	0	74.7	0	0	13
2014	7	13	11	30	9	30	0	0	0	0	0	0	0	74.97	0	0	13.2
2014	7	13	11	40	9	31	0	0	0	0	0	0	0	75.25	0	0	13.2
2014	7	13	11	50	9	31	0	0	0	0	0	0	0	74.88	0	0	13.2
2014	7	13	12	0	9	32	0	0	0	0	0	0	0	74.73	0	0	13.2
2014	7	13	12	10	9	31	0	0	0	0	0	0	0	74.89	0	0	13.2
2014	7	13	12	20	9	31	0	0	0	0	0	0	0	75.15	0	0	13
2014	7	13	12	30	9	31	0	0	0	0	0	0	0	75.47	0	0	13.2
2014	7	13	12	40	9	31	0	0	0	0	0	0	0	75.83	0	0	13.2
2014	7	13	12	50	9	31	0	0	0	0	0	0	0	76.21	0	0	13.2
2014	7	13	13	0	9	31	0	0	0	0	0	0	0	76.6	0	0	13.2
2014	7	13	13	10	9	31	0	0	0	0	0	0	0	77.07	0	0	13.2
2014	7	13	13	20	9	31	0	0	0	0	0	0	0	78.24	0	0	13
2014	7	13	13	30	9	31	0	0	0	0	0	0	0	78.91	0	0	13.2
2014	7	13	13	40	9	31	0	0	0	0	0	0	0	79.3	0	0	13.2
2014	7	13	13	50	9	30	0	0	0	0	0	0	0	79.65	0	0	13.2
2014	7	13	14	0	9	31	0	0	0	0	0	0	0	80.02	0	0	13.2
2014	7	13	14	10	9	30	0	0	0	0	0	0	0	80.4	0	0	13
2014	7	13	14	20	9	30	0	0	0	0	0	0	0	80.74	0	0	13
2014	7	13	14	30	9	30	0	0	0	0	0	0	0	81.07	0	0	13
2014	7	13	14	40	9	31	0	0	0	0	0	0	0	81.36	0	0	13
2014	7	13	14	50	9	30	0	0	0	0	0	0	0	81.73	0	0	13
2014	7	13	15	0	9	30	0	0	0	0	0	0	0	81.99	0	0	13
2014	7	13	15	10	9	30	0	0	0	0	0	0	0	82.33	0	0	13
2014	7	13	15	20	9	30	0	0	0	0	0	0	0	82.62	0	0	12.8
2014	7	13	15	30	9	31	0	0	0	0	0	0	0	82.92	0	0	12.8
2014	7	13	15	40	9	30	0	0	0	0	0	0	0	83.19	0	0	12.8
2014	7	13	15	50	9	29	0	0	0	0	0	0	0	83.43	0	0	12.8
2014	7	13	16	0	9	30	0	0	0	0	0	0	0	83.7	0	0	12.8
2014	7	13	16	10	9	30	0	0	0	0	0	0	0	83.91	0	0	12.6
2014	7	13	16	20	9	30	0	0	0	0	0	0	0	84.11	0	0	12.6
2014	7	13	16	30	9	30	0	0	0	0	0	0	0	84.31	0	0	12.6
2014	7	13	16	40	9	30	0	0	0	0	0	0	0	84.51	0	0	12.6
2014	7	13	16	50	9	30	0	0	0	0	0	0	0	84.67	0	0	12.4
2014	7	13	17	0	9	30	0	0	0	0	0	0	0	84.76	0	0	12.4
2014	7	13	17	10	9	30	0	0	0	0	0	0	0	84.87	0	0	12.4
2014	7	13	17	20	9	30	0	0	0	0	0	0	0	84.96	0	0	12.4
2014	7	13	17	30	9	30	0	0	0	0	0	0	0	84.94	0	0	12.4
2014	7	13	17	40	9	29	0	0	0	0	0	0	0	84.74	0	0	12.4
2014	7	13	17	50	9	30	0	0	0	0	0	0	0	84.74	0	0	12.2
2014	7	13	18	0	9	29	0	0	0	0	0	0	0	84.76	0	0	12.2
2014	7	13	18	10	9	30	0	0	0	0	0	0	0	84.79	0	0	12.2
2014	7	13	18	20	9	30	0	0	0	0	0	0	0	84.85	0	0	12.2
2014	7	13	18	30	9	30	0	0	0	0	0	0	0	84.83	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	18	40	9	29	0	0	0	0	0	0	0	84.76	0	0	12.2
2014	7	13	18	50	9	29	0	0	0	0	0	0	0	84.76	0	0	12.2
2014	7	13	19	0	9	30	0	0	0	0	0	0	0	84.76	0	0	12.2
2014	7	13	19	10	9	30	0	0	0	0	0	0	0	84.7	0	0	12.2
2014	7	13	19	20	9	30	0	0	0	0	0	0	0	84.67	0	0	12.2
2014	7	13	19	30	9	30	0	0	0	0	0	0	0	84.63	0	0	12.2
2014	7	13	19	40	9	30	0	0	0	0	0	0	0	84.58	0	0	12.2
2014	7	13	19	50	9	30	0	0	0	0	0	0	0	84.49	0	0	12.2
2014	7	13	20	0	9	30	0	0	0	0	0	0	0	84.4	0	0	12.2
2014	7	13	20	10	9	30	0	0	0	0	0	0	0	84.31	0	0	12.2
2014	7	13	20	20	9	29	0	0	0	0	0	0	0	84.15	0	0	12
2014	7	13	20	30	9	30	0	0	0	0	0	0	0	84	0	0	12.2
2014	7	13	20	40	9	29	0	0	0	0	0	0	0	83.89	0	0	12.2
2014	7	13	20	50	9	29	0	0	0	0	0	0	0	83.77	0	0	12.2
2014	7	13	21	0	9	30	0	0	0	0	0	0	0	83.66	0	0	12.2
2014	7	13	21	10	9	29	0	0	0	0	0	0	0	83.46	0	0	12.2
2014	7	13	21	20	9	30	0	0	0	0	0	0	0	83.32	0	0	12
2014	7	13	21	30	9	30	0	0	0	0	0	0	0	83.21	0	0	12.2
2014	7	13	21	40	9	30	0	0	0	0	0	0	0	83.08	0	0	12.2
2014	7	13	21	50	9	30	0	0	0	0	0	0	0	82.98	0	0	12.2
2014	7	13	22	0	9	30	0	0	0	0	0	0	0	82.83	0	0	12.2
2014	7	13	22	10	9	30	0	0	0	0	0	0	0	82.65	0	0	12.2
2014	7	13	22	20	9	30	0	0	0	0	0	0	0	82.49	0	0	12
2014	7	13	22	30	9	30	0	0	0	0	0	0	0	82.31	0	0	12.2
2014	7	13	22	40	9	30	0	0	0	0	0	0	0	82.11	0	0	12.2
2014	7	13	22	50	9	30	0	0	0	0	0	0	0	81.91	0	0	12.2
2014	7	13	23	0	9	30	0	0	0	0	0	0	0	81.72	0	0	12.2
2014	7	13	23	10	9	30	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	13	23	20	9	30	0	0	0	0	0	0	0	81.28	0	0	12
2014	7	13	23	30	9	30	0	0	0	0	0	0	0	81.07	0	0	12
2014	7	13	23	40	9	30	0	0	0	0	0	0	0	80.83	0	0	12
2014	7	13	23	50	9	30	0	0	0	0	0	0	0	80.6	0	0	12
2014	7	14	0	0	9	30	0	0	0	0	0	0	0	80.37	0	0	12
2014	7	14	0	10	9	31	0	0	0	0	0	0	0	80.15	0	0	12
2014	7	14	0	20	9	30	0	0	0	0	0	0	0	79.9	0	0	12
2014	7	14	0	30	9	30	0	0	0	0	0	0	0	79.65	0	0	12
2014	7	14	0	40	9	30	0	0	0	0	0	0	0	79.45	0	0	12
2014	7	14	0	50	9	30	0	0	0	0	0	0	0	79.29	0	0	12
2014	7	14	1	0	9	30	0	0	0	0	0	0	0	79.07	0	0	12
2014	7	14	1	10	9	30	0	0	0	0	0	0	0	78.85	0	0	12
2014	7	14	1	20	9	30	0	0	0	0	0	0	0	78.66	0	0	12
2014	7	14	1	30	9	30	0	0	0	0	0	0	0	78.44	0	0	12
2014	7	14	1	40	9	30	0	0	0	0	0	0	0	78.26	0	0	12
2014	7	14	1	50	9	31	0	0	0	0	0	0	0	78.06	0	0	12
2014	7	14	2	0	9	30	0	0	0	0	0	0	0	77.86	0	0	12
2014	7	14	2	10	9	31	0	0	0	0	0	0	0	77.67	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	2	20	9	30	0	0	0	0	0	0	0	77.5	0	0	12
2014	7	14	2	30	9	30	0	0	0	0	0	0	0	77.32	0	0	12
2014	7	14	2	40	9	30	0	0	0	0	0	0	0	77.14	0	0	12
2014	7	14	2	50	9	31	0	0	0	0	0	0	0	76.95	0	0	12
2014	7	14	3	0	9	30	0	0	0	0	0	0	0	76.8	0	0	12
2014	7	14	3	10	9	31	0	0	0	0	0	0	0	76.64	0	0	12
2014	7	14	3	20	9	31	0	0	0	0	0	0	0	76.51	0	0	12
2014	7	14	3	30	9	31	0	0	0	0	0	0	0	76.35	0	0	12
2014	7	14	3	40	9	30	0	0	0	0	0	0	0	76.23	0	0	12
2014	7	14	3	50	9	30	0	0	0	0	0	0	0	76.08	0	0	12
2014	7	14	4	0	9	31	0	0	0	0	0	0	0	75.94	0	0	12
2014	7	14	4	10	9	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	14	4	20	9	31	0	0	0	0	0	0	0	75.63	0	0	12
2014	7	14	4	30	9	31	0	0	0	0	0	0	0	75.49	0	0	12
2014	7	14	4	40	9	31	0	0	0	0	0	0	0	75.34	0	0	12
2014	7	14	4	50	9	30	0	0	0	0	0	0	0	75.18	0	0	12
2014	7	14	5	0	9	31	0	0	0	0	0	0	0	75.06	0	0	12
2014	7	14	5	10	9	31	0	0	0	0	0	0	0	74.91	0	0	12
2014	7	14	5	20	9	30	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	14	5	30	9	31	0	0	0	0	0	0	0	74.59	0	0	12
2014	7	14	5	40	9	31	0	0	0	0	0	0	0	74.46	0	0	12
2014	7	14	5	50	9	30	0	0	0	0	0	0	0	74.32	0	0	12
2014	7	14	6	0	9	31	0	0	0	0	0	0	0	74.21	0	0	12
2014	7	14	6	10	9	31	0	0	0	0	0	0	0	74.08	0	0	12
2014	7	14	6	20	9	31	0	0	0	0	0	0	0	73.98	0	0	11.8
2014	7	14	6	30	9	31	0	0	0	0	0	0	0	73.87	0	0	12
2014	7	14	6	40	9	30	0	0	0	0	0	0	0	73.8	0	0	12
2014	7	14	6	50	9	32	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	14	7	0	9	32	0	0	0	0	0	0	0	73.8	0	0	12.2
2014	7	14	7	10	9	31	0	0	0	0	0	0	0	73.72	0	0	12.2
2014	7	14	7	20	9	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	14	7	30	9	31	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	14	7	40	9	31	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	14	7	50	9	31	0	0	0	0	0	0	0	73.53	0	0	12.2
2014	7	14	8	0	9	31	0	0	0	0	0	0	0	73.63	0	0	12.2
2014	7	14	8	10	9	31	0	0	0	0	0	0	0	73.6	0	0	12.2
2014	7	14	8	20	9	31	0	0	0	0	0	0	0	73.58	0	0	12
2014	7	14	8	30	9	30	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	14	8	40	9	31	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	14	8	50	9	31	0	0	0	0	0	0	0	73.58	0	0	12.2
2014	7	14	9	0	9	31	0	0	0	0	0	0	0	73.78	0	0	12.4
2014	7	14	9	10	9	31	0	0	0	0	0	0	0	74.19	0	0	12.6
2014	7	14	9	20	9	30	0	0	0	0	0	0	0	74.55	0	0	12.8
2014	7	14	9	30	9	30	0	0	0	0	0	0	0	74.23	0	0	12.6
2014	7	14	9	40	9	31	0	0	0	0	0	0	0	74.21	0	0	12.6
2014	7	14	9	50	9	31	0	0	0	0	0	0	0	74.46	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	10	0	9	31	0	0	0	0	0	0	0	74.66	0	0	12.8
2014	7	14	10	10	9	31	0	0	0	0	0	0	0	74.88	0	0	13
2014	7	14	10	20	9	30	0	0	0	0	0	0	0	75.06	0	0	12.8
2014	7	14	10	30	9	31	0	0	0	0	0	0	0	74.93	0	0	12.8
2014	7	14	10	40	9	31	0	0	0	0	0	0	0	75.29	0	0	13
2014	7	14	10	50	9	31	0	0	0	0	0	0	0	75.25	0	0	12.6
2014	7	14	11	0	9	32	0	0	0	0	0	0	0	75.36	0	0	12.8
2014	7	14	11	10	9	31	0	0	0	0	0	0	0	75.7	0	0	12.8
2014	7	14	11	20	9	31	0	0	0	0	0	0	0	76.21	0	0	13
2014	7	14	11	30	9	31	0	0	0	0	0	0	0	76.39	0	0	13
2014	7	14	11	40	9	31	0	0	0	0	0	0	0	76.32	0	0	13
2014	7	14	11	50	9	31	0	0	0	0	0	0	0	76.48	0	0	13
2014	7	14	12	2	18	30	0	0	0	0	0	0	0	76.55	0	0	13.2
2014	7	14	12	12	18	31	0	0	0	0	0	0	0	76.68	0	0	13.2
2014	7	14	12	22	18	30	0	0	0	0	0	0	0	76.87	0	0	13.2
2014	7	14	12	32	18	31	0	0	0	0	0	0	0	77.02	0	0	13.2
2014	7	14	12	42	18	31	0	0	0	0	0	0	0	77.22	0	0	13
2014	7	14	12	52	18	30	0	0	0	0	0	0	0	77.56	0	0	12.8
2014	7	14	13	2	18	31	0	0	0	0	0	0	0	77.88	0	0	13
2014	7	14	13	12	18	31	0	0	0	0	0	0	0	78.24	0	0	13
2014	7	14	13	22	18	31	0	0	0	0	0	0	0	78.84	0	0	13
2014	7	14	13	32	18	31	0	0	0	0	0	0	0	79.02	0	0	13
2014	7	14	13	42	18	30	0	0	0	0	0	0	0	79.27	0	0	13
2014	7	14	13	52	18	30	0	0	0	0	0	0	0	79.11	0	0	12.6
2014	7	14	14	2	18	31	0	0	0	0	0	0	0	79.34	0	0	12.8
2014	7	14	14	12	18	30	0	0	0	0	0	0	0	79.57	0	0	12.8
2014	7	14	14	22	18	30	0	0	0	0	0	0	0	79.81	0	0	13
2014	7	14	14	32	18	30	0	0	0	0	0	0	0	80.1	0	0	13
2014	7	14	14	42	18	30	0	0	0	0	0	0	0	79.75	0	0	12.6
2014	7	14	14	52	18	30	0	0	0	0	0	0	0	79.83	0	0	12.6
2014	7	14	15	2	18	31	0	0	0	0	0	0	0	79.92	0	0	12.6
2014	7	14	15	12	18	30	0	0	0	0	0	0	0	79.99	0	0	12.6
2014	7	14	15	22	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	15	32	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	15	42	18	30	0	0	0	0	0	0	0	80.04	0	0	12.4
2014	7	14	15	52	18	30	0	0	0	0	0	0	0	80.02	0	0	12.4
2014	7	14	16	2	18	31	0	0	0	0	0	0	0	80.02	0	0	12.4
2014	7	14	16	12	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	16	22	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	16	32	18	30	0	0	0	0	0	0	0	80.1	0	0	12.4
2014	7	14	16	42	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	16	52	18	30	0	0	0	0	0	0	0	80.11	0	0	12.4
2014	7	14	17	2	18	30	0	0	0	0	0	0	0	80.08	0	0	12.4
2014	7	14	17	12	18	30	0	0	0	0	0	0	0	80.13	0	0	12.4
2014	7	14	17	22	18	30	0	0	0	0	0	0	0	80.2	0	0	12.2
2014	7	14	17	32	18	30	0	0	0	0	0	0	0	80.17	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	17	42	18	30	0	0	0	0	0	0	0	80.04	0	0	12.2
2014	7	14	17	52	18	29	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	14	18	2	18	30	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	14	18	12	18	30	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	14	18	22	18	30	0	0	0	0	0	0	0	80.01	0	0	12.2
2014	7	14	18	32	18	30	0	0	0	0	0	0	0	79.97	0	0	12.2
2014	7	14	18	42	18	31	0	0	0	0	0	0	0	79.93	0	0	12.2
2014	7	14	18	52	18	31	0	0	0	0	0	0	0	79.84	0	0	12.2
2014	7	14	19	2	18	30	0	0	0	0	0	0	0	79.75	0	0	12.2
2014	7	14	19	12	18	30	0	0	0	0	0	0	0	79.61	0	0	12.2
2014	7	14	19	22	18	30	0	0	0	0	0	0	0	79.47	0	0	12
2014	7	14	19	32	18	31	0	0	0	0	0	0	0	79.3	0	0	12.2
2014	7	14	19	42	18	31	0	0	0	0	0	0	0	79.14	0	0	12.2
2014	7	14	19	52	18	30	0	0	0	0	0	0	0	79	0	0	12.2
2014	7	14	20	2	18	30	0	0	0	0	0	0	0	78.84	0	0	12.2
2014	7	14	20	12	18	30	0	0	0	0	0	0	0	78.67	0	0	12.2
2014	7	14	20	22	18	30	0	0	0	0	0	0	0	78.51	0	0	12
2014	7	14	20	32	18	30	0	0	0	0	0	0	0	78.35	0	0	12.2
2014	7	14	20	42	18	30	0	0	0	0	0	0	0	78.19	0	0	12.2
2014	7	14	20	52	18	31	0	0	0	0	0	0	0	78.03	0	0	12.2
2014	7	14	21	2	18	31	0	0	0	0	0	0	0	77.88	0	0	12.2
2014	7	14	21	12	18	30	0	0	0	0	0	0	0	77.74	0	0	12.2
2014	7	14	21	22	18	30	0	0	0	0	0	0	0	77.59	0	0	12
2014	7	14	21	32	18	30	0	0	0	0	0	0	0	77.45	0	0	12
2014	7	14	21	42	18	30	0	0	0	0	0	0	0	77.31	0	0	12
2014	7	14	21	52	18	31	0	0	0	0	0	0	0	77.16	0	0	12
2014	7	14	22	2	18	30	0	0	0	0	0	0	0	77.02	0	0	12
2014	7	14	22	12	18	31	0	0	0	0	0	0	0	76.87	0	0	12
2014	7	14	22	22	18	30	0	0	0	0	0	0	0	76.71	0	0	12
2014	7	14	22	32	18	31	0	0	0	0	0	0	0	76.55	0	0	12
2014	7	14	22	42	18	31	0	0	0	0	0	0	0	76.39	0	0	12
2014	7	14	22	52	18	30	0	0	0	0	0	0	0	76.21	0	0	12
2014	7	14	23	2	18	30	0	0	0	0	0	0	0	76.05	0	0	12
2014	7	14	23	12	18	30	0	0	0	0	0	0	0	75.87	0	0	12
2014	7	14	23	22	18	31	0	0	0	0	0	0	0	75.7	0	0	12
2014	7	14	23	32	18	30	0	0	0	0	0	0	0	75.52	0	0	12
2014	7	14	23	42	18	31	0	0	0	0	0	0	0	75.38	0	0	12
2014	7	14	23	52	18	30	0	0	0	0	0	0	0	75.24	0	0	12
2014	7	15	0	2	18	31	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	15	0	12	18	30	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	15	0	22	18	30	0	0	0	0	0	0	0	74.82	0	0	11.8
2014	7	15	0	32	18	30	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	15	0	42	18	30	0	0	0	0	0	0	0	74.59	0	0	12
2014	7	15	0	52	18	31	0	0	0	0	0	0	0	74.46	0	0	12
2014	7	15	1	2	18	31	0	0	0	0	0	0	0	74.35	0	0	12
2014	7	15	1	12	18	31	0	0	0	0	0	0	0	74.26	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	1	22	18	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	15	1	32	18	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	7	15	1	42	18	31	0	0	0	0	0	0	0	73.99	0	0	12
2014	7	15	1	52	18	30	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	15	2	2	18	32	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	15	2	12	18	31	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	15	2	22	18	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	15	2	32	18	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	15	2	42	18	32	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	15	2	52	18	31	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	15	3	2	18	31	0	0	0	0	0	0	0	73.38	0	0	12
2014	7	15	3	12	18	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	15	3	22	18	31	0	0	0	0	0	0	0	73.26	0	0	11.8
2014	7	15	3	32	18	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	15	3	42	18	30	0	0	0	0	0	0	0	73.15	0	0	12
2014	7	15	3	52	18	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	15	4	2	18	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	15	4	12	18	31	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	15	4	22	18	31	0	0	0	0	0	0	0	72.97	0	0	11.8
2014	7	15	4	32	18	31	0	0	0	0	0	0	0	72.95	0	0	12
2014	7	15	4	42	18	31	0	0	0	0	0	0	0	72.91	0	0	12
2014	7	15	4	52	18	31	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	15	5	2	18	31	0	0	0	0	0	0	0	72.86	0	0	12
2014	7	15	5	12	18	31	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	15	5	22	18	30	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	15	5	32	18	30	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	15	5	42	18	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	15	5	52	18	31	0	0	0	0	0	0	0	72.7	0	0	12
2014	7	15	6	2	18	31	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	15	6	12	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	15	6	22	18	32	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	15	6	32	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	15	6	42	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	15	6	52	18	31	0	0	0	0	0	0	0	72.66	0	0	12.2
2014	7	15	7	2	18	31	0	0	0	0	0	0	0	72.82	0	0	12.2
2014	7	15	7	12	18	31	0	0	0	0	0	0	0	72.82	0	0	12.2
2014	7	15	7	22	18	31	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	15	7	32	18	31	0	0	0	0	0	0	0	73.09	0	0	12.4
2014	7	15	7	42	18	31	0	0	0	0	0	0	0	72.93	0	0	12.2
2014	7	15	7	52	18	31	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	7	15	8	2	18	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	7	15	8	12	18	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	15	8	22	18	30	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	15	8	32	18	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	15	8	42	18	31	0	0	0	0	0	0	0	72.82	0	0	12.2
2014	7	15	8	52	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	9	2	18	31	0	0	0	0	0	0	0	72.91	0	0	12.2
2014	7	15	9	12	18	31	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	7	15	9	22	18	31	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	7	15	9	32	18	31	0	0	0	0	0	0	0	72.97	0	0	12.2
2014	7	15	9	42	18	31	0	0	0	0	0	0	0	72.93	0	0	12.2
2014	7	15	9	52	18	31	0	0	0	0	0	0	0	72.95	0	0	12.2
2014	7	15	10	2	18	31	0	0	0	0	0	0	0	73.02	0	0	12.4
2014	7	15	10	12	18	31	0	0	0	0	0	0	0	73.17	0	0	12.4
2014	7	15	10	22	18	31	0	0	0	0	0	0	0	73.31	0	0	12.4
2014	7	15	10	32	18	31	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	7	15	10	42	18	31	0	0	0	0	0	0	0	73.49	0	0	12.6
2014	7	15	10	52	18	31	0	0	0	0	0	0	0	73.8	0	0	12.8
2014	7	15	11	2	18	32	0	0	0	0	0	0	0	74.03	0	0	12.8
2014	7	15	11	12	18	31	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	15	11	22	18	31	0	0	0	0	0	0	0	74.26	0	0	12.8
2014	7	15	11	32	18	31	0	0	0	0	0	0	0	74.26	0	0	12.8
2014	7	15	11	42	18	31	0	0	0	0	0	0	0	74.39	0	0	12.6
2014	7	15	11	52	18	31	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	15	12	2	18	31	0	0	0	0	0	0	0	74.84	0	0	13.2
2014	7	15	12	12	18	31	0	0	0	0	0	0	0	74.84	0	0	13.4
2014	7	15	12	22	18	31	0	0	0	0	0	0	0	74.97	0	0	13.2
2014	7	15	12	32	18	31	0	0	0	0	0	0	0	75.13	0	0	12.8
2014	7	15	12	42	18	31	0	0	0	0	0	0	0	75.38	0	0	13.2
2014	7	15	12	52	18	31	0	0	0	0	0	0	0	75.72	0	0	13.2
2014	7	15	13	2	18	31	0	0	0	0	0	0	0	76.03	0	0	13.2
2014	7	15	13	12	18	31	0	0	0	0	0	0	0	76.6	0	0	13.2
2014	7	15	13	22	18	31	0	0	0	0	0	0	0	77.02	0	0	12.8
2014	7	15	13	32	18	30	0	0	0	0	0	0	0	77.61	0	0	13.2
2014	7	15	13	42	18	31	0	0	0	0	0	0	0	77.74	0	0	13
2014	7	15	13	52	18	30	0	0	0	0	0	0	0	78.22	0	0	13
2014	7	15	14	2	18	30	0	0	0	0	0	0	0	78.53	0	0	13
2014	7	15	14	12	18	31	0	0	0	0	0	0	0	78.76	0	0	13
2014	7	15	14	22	18	30	0	0	0	0	0	0	0	79.03	0	0	12.8
2014	7	15	14	32	18	30	0	0	0	0	0	0	0	79.32	0	0	13
2014	7	15	14	42	18	30	0	0	0	0	0	0	0	79.63	0	0	13
2014	7	15	14	52	18	30	0	0	0	0	0	0	0	79.7	0	0	12.8
2014	7	15	15	2	18	30	0	0	0	0	0	0	0	79.81	0	0	12.8
2014	7	15	15	12	18	30	0	0	0	0	0	0	0	80.24	0	0	13
2014	7	15	15	22	18	30	0	0	0	0	0	0	0	80.53	0	0	12.8
2014	7	15	15	32	18	30	0	0	0	0	0	0	0	80.64	0	0	12.8
2014	7	15	15	42	18	31	0	0	0	0	0	0	0	80.8	0	0	12.6
2014	7	15	15	52	18	30	0	0	0	0	0	0	0	81.05	0	0	12.8
2014	7	15	16	2	18	31	0	0	0	0	0	0	0	81.23	0	0	12.6
2014	7	15	16	12	18	29	0	0	0	0	0	0	0	81.41	0	0	12.6
2014	7	15	16	22	18	30	0	0	0	0	0	0	0	81.5	0	0	12.4
2014	7	15	16	32	18	30	0	0	0	0	0	0	0	81.7	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	16	42	18	30	0	0	0	0	0	0	0	81.84	0	0	12.4
2014	7	15	16	52	18	30	0	0	0	0	0	0	0	82	0	0	12.4
2014	7	15	17	2	18	30	0	0	0	0	0	0	0	81.99	0	0	12.4
2014	7	15	17	12	18	30	0	0	0	0	0	0	0	82.06	0	0	12.4
2014	7	15	17	22	18	30	0	0	0	0	0	0	0	82.11	0	0	12.4
2014	7	15	17	32	18	30	0	0	0	0	0	0	0	82.11	0	0	12.4
2014	7	15	17	42	18	29	0	0	0	0	0	0	0	81.99	0	0	12.4
2014	7	15	17	52	18	30	0	0	0	0	0	0	0	81.99	0	0	12.4
2014	7	15	18	2	18	30	0	0	0	0	0	0	0	81.95	0	0	12.2
2014	7	15	18	12	18	29	0	0	0	0	0	0	0	81.91	0	0	12.2
2014	7	15	18	22	18	30	0	0	0	0	0	0	0	81.84	0	0	12.2
2014	7	15	18	32	18	30	0	0	0	0	0	0	0	81.77	0	0	12.2
2014	7	15	18	42	18	30	0	0	0	0	0	0	0	81.66	0	0	12.2
2014	7	15	18	52	18	30	0	0	0	0	0	0	0	81.54	0	0	12.2
2014	7	15	19	2	18	30	0	0	0	0	0	0	0	81.41	0	0	12.2
2014	7	15	19	12	18	30	0	0	0	0	0	0	0	81.23	0	0	12.2
2014	7	15	19	22	18	30	0	0	0	0	0	0	0	81.07	0	0	12.2
2014	7	15	19	32	18	31	0	0	0	0	0	0	0	80.91	0	0	12.2
2014	7	15	19	42	18	30	0	0	0	0	0	0	0	80.74	0	0	12.2
2014	7	15	19	52	18	30	0	0	0	0	0	0	0	80.6	0	0	12.2
2014	7	15	20	2	18	30	0	0	0	0	0	0	0	80.46	0	0	12.2
2014	7	15	20	12	18	30	0	0	0	0	0	0	0	80.28	0	0	12.2
2014	7	15	20	22	18	30	0	0	0	0	0	0	0	80.06	0	0	12
2014	7	15	20	32	18	30	0	0	0	0	0	0	0	79.83	0	0	12.2
2014	7	15	20	42	18	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2014	7	15	20	52	18	30	0	0	0	0	0	0	0	79.36	0	0	12.2
2014	7	15	21	2	18	30	0	0	0	0	0	0	0	79.11	0	0	12.2
2014	7	15	21	12	18	30	0	0	0	0	0	0	0	78.85	0	0	12.2
2014	7	15	21	22	18	30	0	0	0	0	0	0	0	78.6	0	0	12
2014	7	15	21	32	18	31	0	0	0	0	0	0	0	78.39	0	0	12
2014	7	15	21	42	18	30	0	0	0	0	0	0	0	78.17	0	0	12
2014	7	15	21	52	18	30	0	0	0	0	0	0	0	77.94	0	0	12
2014	7	15	22	2	18	31	0	0	0	0	0	0	0	77.72	0	0	12
2014	7	15	22	12	18	30	0	0	0	0	0	0	0	77.49	0	0	12
2014	7	15	22	22	18	30	0	0	0	0	0	0	0	77.29	0	0	12
2014	7	15	22	32	18	30	0	0	0	0	0	0	0	77.07	0	0	12
2014	7	15	22	42	18	30	0	0	0	0	0	0	0	76.87	0	0	12
2014	7	15	22	52	18	31	0	0	0	0	0	0	0	76.69	0	0	12
2014	7	15	23	2	18	30	0	0	0	0	0	0	0	76.48	0	0	12
2014	7	15	23	12	18	31	0	0	0	0	0	0	0	76.3	0	0	12
2014	7	15	23	22	18	30	0	0	0	0	0	0	0	76.12	0	0	12
2014	7	15	23	32	18	31	0	0	0	0	0	0	0	75.94	0	0	12
2014	7	15	23	42	18	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	15	23	52	18	31	0	0	0	0	0	0	0	75.6	0	0	12
2014	7	16	0	2	18	31	0	0	0	0	0	0	0	75.45	0	0	12
2014	7	16	0	12	18	31	0	0	0	0	0	0	0	75.29	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	0	22	18	30	0	0	0	0	0	0	0	75.15	0	0	12
2014	7	16	0	32	18	31	0	0	0	0	0	0	0	75	0	0	12
2014	7	16	0	42	18	30	0	0	0	0	0	0	0	74.88	0	0	12
2014	7	16	0	52	18	31	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	16	1	2	18	31	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	16	1	12	18	30	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	16	1	22	18	30	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	16	1	32	18	31	0	0	0	0	0	0	0	74.25	0	0	12
2014	7	16	1	42	18	32	0	0	0	0	0	0	0	74.16	0	0	12
2014	7	16	1	52	18	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	16	2	2	18	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	16	2	12	18	31	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	16	2	22	18	30	0	0	0	0	0	0	0	73.72	0	0	11.8
2014	7	16	2	32	18	31	0	0	0	0	0	0	0	73.62	0	0	12
2014	7	16	2	42	18	31	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	16	2	52	18	31	0	0	0	0	0	0	0	73.38	0	0	12
2014	7	16	3	2	18	32	0	0	0	0	0	0	0	73.26	0	0	12
2014	7	16	3	12	18	31	0	0	0	0	0	0	0	73.13	0	0	12
2014	7	16	3	22	18	31	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	16	3	32	18	31	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	16	3	42	18	31	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	16	3	52	18	31	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	16	4	2	18	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	16	4	12	18	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	16	4	22	18	31	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	16	4	32	18	31	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	16	4	42	18	31	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	16	4	52	18	31	0	0	0	0	0	0	0	72	0	0	12
2014	7	16	5	2	18	31	0	0	0	0	0	0	0	71.87	0	0	12
2014	7	16	5	12	18	31	0	0	0	0	0	0	0	71.76	0	0	12
2014	7	16	5	22	18	31	0	0	0	0	0	0	0	71.65	0	0	11.8
2014	7	16	5	32	18	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	16	5	42	18	31	0	0	0	0	0	0	0	71.38	0	0	12
2014	7	16	5	52	18	31	0	0	0	0	0	0	0	71.26	0	0	12
2014	7	16	6	2	18	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	16	6	12	18	31	0	0	0	0	0	0	0	71.01	0	0	12
2014	7	16	6	22	18	31	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	16	6	32	18	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	16	6	42	18	31	0	0	0	0	0	0	0	70.66	0	0	12
2014	7	16	6	52	18	31	0	0	0	0	0	0	0	70.57	0	0	12
2014	7	16	7	2	18	31	0	0	0	0	0	0	0	70.59	0	0	12.2
2014	7	16	7	12	18	31	0	0	0	0	0	0	0	70.56	0	0	12.2
2014	7	16	7	22	18	31	0	0	0	0	0	0	0	70.54	0	0	12.2
2014	7	16	7	32	18	32	0	0	0	0	0	0	0	70.54	0	0	12.4
2014	7	16	7	42	18	31	0	0	0	0	0	0	0	70.54	0	0	12.4
2014	7	16	7	52	18	31	0	0	0	0	0	0	0	70.5	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	8	2	18	32	0	0	0	0	0	0	0	70.36	0	0	12.4
2014	7	16	8	12	18	32	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	16	8	22	18	32	0	0	0	0	0	0	0	70.52	0	0	12.6
2014	7	16	8	32	18	31	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	16	8	42	18	31	0	0	0	0	0	0	0	70.68	0	0	12.8
2014	7	16	8	52	18	32	0	0	0	0	0	0	0	70.79	0	0	12.8
2014	7	16	9	2	18	31	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	16	9	12	18	32	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	16	9	22	18	32	0	0	0	0	0	0	0	71.2	0	0	13
2014	7	16	9	32	18	31	0	0	0	0	0	0	0	71.38	0	0	13
2014	7	16	9	42	18	31	0	0	0	0	0	0	0	71.58	0	0	13
2014	7	16	9	52	18	32	0	0	0	0	0	0	0	71.76	0	0	13
2014	7	16	10	2	18	31	0	0	0	0	0	0	0	72	0	0	13
2014	7	16	10	12	18	31	0	0	0	0	0	0	0	72.23	0	0	13
2014	7	16	10	22	18	31	0	0	0	0	0	0	0	72.48	0	0	13
2014	7	16	10	32	18	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2014	7	16	10	42	18	31	0	0	0	0	0	0	0	73.04	0	0	13.2
2014	7	16	10	52	18	31	0	0	0	0	0	0	0	73.31	0	0	13
2014	7	16	11	2	18	32	0	0	0	0	0	0	0	73.63	0	0	13.2
2014	7	16	11	12	18	31	0	0	0	0	0	0	0	73.98	0	0	13.2
2014	7	16	11	22	18	30	0	0	0	0	0	0	0	74.34	0	0	13
2014	7	16	11	32	18	32	0	0	0	0	0	0	0	74.66	0	0	13.2
2014	7	16	11	42	18	31	0	0	0	0	0	0	0	75	0	0	13.2
2014	7	16	11	52	18	30	0	0	0	0	0	0	0	74.82	0	0	13.2
2014	7	16	12	2	18	30	0	0	0	0	0	0	0	75.07	0	0	13.2
2014	7	16	12	12	18	30	0	0	0	0	0	0	0	75.4	0	0	13.2
2014	7	16	12	22	18	31	0	0	0	0	0	0	0	75.78	0	0	13
2014	7	16	12	32	18	31	0	0	0	0	0	0	0	76.15	0	0	13.2
2014	7	16	12	42	18	31	0	0	0	0	0	0	0	76.55	0	0	13.2
2014	7	16	12	52	18	31	0	0	0	0	0	0	0	76.96	0	0	13.2
2014	7	16	13	2	18	31	0	0	0	0	0	0	0	77.38	0	0	13.2
2014	7	16	13	12	18	30	0	0	0	0	0	0	0	77.99	0	0	13.2
2014	7	16	13	22	18	31	0	0	0	0	0	0	0	78.66	0	0	13
2014	7	16	13	32	18	31	0	0	0	0	0	0	0	79.11	0	0	13.2
2014	7	16	13	42	18	30	0	0	0	0	0	0	0	79.52	0	0	13.2
2014	7	16	13	52	18	30	0	0	0	0	0	0	0	79.84	0	0	13
2014	7	16	14	2	18	31	0	0	0	0	0	0	0	80.19	0	0	13
2014	7	16	14	12	18	30	0	0	0	0	0	0	0	80.51	0	0	13
2014	7	16	14	22	18	30	0	0	0	0	0	0	0	80.82	0	0	12.8
2014	7	16	14	32	18	30	0	0	0	0	0	0	0	81.1	0	0	13
2014	7	16	14	42	18	31	0	0	0	0	0	0	0	81.41	0	0	13
2014	7	16	14	52	18	30	0	0	0	0	0	0	0	81.66	0	0	13
2014	7	16	15	2	18	30	0	0	0	0	0	0	0	81.93	0	0	13
2014	7	16	15	12	18	30	0	0	0	0	0	0	0	82.15	0	0	12.8
2014	7	16	15	22	18	30	0	0	0	0	0	0	0	82.38	0	0	12.8
2014	7	16	15	32	18	30	0	0	0	0	0	0	0	82.62	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	15	42	18	30	0	0	0	0	0	0	0	82.78	0	0	12.8
2014	7	16	15	52	18	30	0	0	0	0	0	0	0	82.71	0	0	12.4
2014	7	16	16	2	18	30	0	0	0	0	0	0	0	82.72	0	0	12.4
2014	7	16	16	12	18	30	0	0	0	0	0	0	0	82.8	0	0	12.4
2014	7	16	16	22	18	30	0	0	0	0	0	0	0	82.89	0	0	12.4
2014	7	16	16	32	18	30	0	0	0	0	0	0	0	82.87	0	0	12.4
2014	7	16	16	42	18	30	0	0	0	0	0	0	0	82.83	0	0	12.4
2014	7	16	16	52	18	29	0	0	0	0	0	0	0	82.81	0	0	12.4
2014	7	16	17	2	18	30	0	0	0	0	0	0	0	82.76	0	0	12.4
2014	7	16	17	12	18	30	0	0	0	0	0	0	0	82.76	0	0	12.4
2014	7	16	17	22	18	30	0	0	0	0	0	0	0	82.76	0	0	12.2
2014	7	16	17	32	18	30	0	0	0	0	0	0	0	82.76	0	0	12.2
2014	7	16	17	42	18	29	0	0	0	0	0	0	0	82.72	0	0	12.2
2014	7	16	17	52	18	29	0	0	0	0	0	0	0	82.67	0	0	12.2
2014	7	16	18	2	18	30	0	0	0	0	0	0	0	82.58	0	0	12.2
2014	7	16	18	12	18	30	0	0	0	0	0	0	0	82.44	0	0	12.2
2014	7	16	18	22	18	30	0	0	0	0	0	0	0	82.27	0	0	12.2
2014	7	16	18	32	18	30	0	0	0	0	0	0	0	82.09	0	0	12.2
2014	7	16	18	42	18	30	0	0	0	0	0	0	0	81.91	0	0	12.2
2014	7	16	18	52	18	30	0	0	0	0	0	0	0	81.72	0	0	12.2
2014	7	16	19	2	18	30	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	16	19	12	18	30	0	0	0	0	0	0	0	81.3	0	0	12.2
2014	7	16	19	22	18	30	0	0	0	0	0	0	0	81.07	0	0	12
2014	7	16	19	32	18	30	0	0	0	0	0	0	0	80.85	0	0	12.2
2014	7	16	19	42	18	30	0	0	0	0	0	0	0	80.64	0	0	12.2
2014	7	16	19	52	18	30	0	0	0	0	0	0	0	80.42	0	0	12.2
2014	7	16	20	2	18	30	0	0	0	0	0	0	0	80.19	0	0	12.2
2014	7	16	20	12	18	31	0	0	0	0	0	0	0	79.97	0	0	12.2
2014	7	16	20	22	18	30	0	0	0	0	0	0	0	79.75	0	0	12.2
2014	7	16	20	32	18	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2014	7	16	20	42	18	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	16	20	52	18	31	0	0	0	0	0	0	0	79.11	0	0	12.2
2014	7	16	21	2	18	30	0	0	0	0	0	0	0	78.91	0	0	12.2
2014	7	16	21	12	18	30	0	0	0	0	0	0	0	78.67	0	0	12.2
2014	7	16	21	22	18	31	0	0	0	0	0	0	0	78.48	0	0	12
2014	7	16	21	32	18	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2014	7	16	21	42	18	30	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	16	21	52	18	30	0	0	0	0	0	0	0	77.86	0	0	12.2
2014	7	16	22	2	18	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	16	22	12	18	30	0	0	0	0	0	0	0	77.45	0	0	12
2014	7	16	22	22	18	30	0	0	0	0	0	0	0	77.23	0	0	12
2014	7	16	22	32	18	31	0	0	0	0	0	0	0	77.05	0	0	12
2014	7	16	22	42	18	30	0	0	0	0	0	0	0	76.87	0	0	12
2014	7	16	22	52	18	30	0	0	0	0	0	0	0	76.71	0	0	12
2014	7	16	23	2	18	31	0	0	0	0	0	0	0	76.55	0	0	12
2014	7	16	23	12	18	30	0	0	0	0	0	0	0	76.41	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	23	22	18	30	0	0	0	0	0	0	0	76.26	0	0	12
2014	7	16	23	32	18	30	0	0	0	0	0	0	0	76.08	0	0	12
2014	7	16	23	42	18	30	0	0	0	0	0	0	0	75.96	0	0	12
2014	7	16	23	52	18	30	0	0	0	0	0	0	0	75.79	0	0	12
2014	7	17	0	2	18	31	0	0	0	0	0	0	0	75.63	0	0	12
2014	7	17	0	12	18	31	0	0	0	0	0	0	0	75.49	0	0	12
2014	7	17	0	22	18	31	0	0	0	0	0	0	0	75.34	0	0	12
2014	7	17	0	32	18	30	0	0	0	0	0	0	0	75.22	0	0	12
2014	7	17	0	42	18	30	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	17	0	52	18	31	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	17	1	2	18	30	0	0	0	0	0	0	0	74.84	0	0	12
2014	7	17	1	12	18	31	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	17	1	22	18	30	0	0	0	0	0	0	0	74.61	0	0	11.8
2014	7	17	1	32	18	31	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	17	1	42	18	31	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	17	1	52	18	31	0	0	0	0	0	0	0	74.28	0	0	12
2014	7	17	2	2	18	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	17	2	12	18	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	7	17	2	22	18	31	0	0	0	0	0	0	0	73.96	0	0	11.8
2014	7	17	2	32	18	30	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	17	2	42	18	31	0	0	0	0	0	0	0	73.72	0	0	12
2014	7	17	2	52	18	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	17	3	2	18	31	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	17	3	12	18	31	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	17	3	22	18	31	0	0	0	0	0	0	0	73.22	0	0	12
2014	7	17	3	32	18	30	0	0	0	0	0	0	0	73.11	0	0	12
2014	7	17	3	42	18	31	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	17	3	52	18	31	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	17	4	2	18	31	0	0	0	0	0	0	0	72.75	0	0	12
2014	7	17	4	12	18	31	0	0	0	0	0	0	0	72.63	0	0	12
2014	7	17	4	22	18	31	0	0	0	0	0	0	0	72.5	0	0	12
2014	7	17	4	32	18	31	0	0	0	0	0	0	0	72.37	0	0	12
2014	7	17	4	42	18	31	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	17	4	52	18	31	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	17	5	2	18	31	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	17	5	12	18	31	0	0	0	0	0	0	0	71.83	0	0	12
2014	7	17	5	22	18	31	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	17	5	32	18	32	0	0	0	0	0	0	0	71.55	0	0	12
2014	7	17	5	42	18	32	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	17	5	52	18	32	0	0	0	0	0	0	0	71.26	0	0	12
2014	7	17	6	2	18	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	17	6	12	18	30	0	0	0	0	0	0	0	70.99	0	0	12
2014	7	17	6	22	18	31	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	17	6	32	18	32	0	0	0	0	0	0	0	70.74	0	0	12
2014	7	17	6	42	18	31	0	0	0	0	0	0	0	70.61	0	0	12
2014	7	17	6	52	18	32	0	0	0	0	0	0	0	70.52	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	7	7	2	18	31	0	0	0	0	0	0	70.52	0	0	12.2
2014	7	17	7	12	18	32		0	0	0	0	0	0	70.47	0	0	12.2
2014	7	17	7	22	18	30		0	0	0	0	0	0	70.43	0	0	12.2
2014	7	17	7	32	18	31		0	0	0	0	0	0	70.41	0	0	12.4
2014	7	17	7	42	18	31		0	0	0	0	0	0	70.43	0	0	12.4
2014	7	17	7	52	18	31		0	0	0	0	0	0	70.43	0	0	12.4
2014	7	17	8	2	18	32		0	0	0	0	0	0	70.45	0	0	12.6
2014	7	17	8	12	18	31		0	0	0	0	0	0	70.5	0	0	12.6
2014	7	17	8	22	18	31		0	0	0	0	0	0	70.56	0	0	12.6
2014	7	17	8	32	18	31		0	0	0	0	0	0	70.61	0	0	12.8
2014	7	17	8	42	18	31		0	0	0	0	0	0	70.74	0	0	12.8
2014	7	17	8	52	18	31		0	0	0	0	0	0	70.83	0	0	12.8
2014	7	17	9	2	18	31		0	0	0	0	0	0	70.95	0	0	13
2014	7	17	9	12	18	31		0	0	0	0	0	0	71.1	0	0	13
2014	7	17	9	22	18	32		0	0	0	0	0	0	71.24	0	0	12.8
2014	7	17	9	32	18	31		0	0	0	0	0	0	71.44	0	0	13
2014	7	17	9	42	18	31		0	0	0	0	0	0	71.6	0	0	13
2014	7	17	9	52	18	31		0	0	0	0	0	0	71.78	0	0	13
2014	7	17	10	2	18	31		0	0	0	0	0	0	72	0	0	13
2014	7	17	10	12	18	31		0	0	0	0	0	0	72.23	0	0	13
2014	7	17	10	22	18	31		0	0	0	0	0	0	72.46	0	0	13
2014	7	17	10	32	18	32		0	0	0	0	0	0	72.73	0	0	13.2
2014	7	17	10	42	18	31		0	0	0	0	0	0	73.02	0	0	13.2
2014	7	17	10	52	18	31		0	0	0	0	0	0	73.31	0	0	13.2
2014	7	17	11	2	18	31		0	0	0	0	0	0	73.63	0	0	13.2
2014	7	17	11	12	18	31		0	0	0	0	0	0	73.96	0	0	13.2
2014	7	17	11	22	18	31		0	0	0	0	0	0	74.3	0	0	13.2
2014	7	17	11	32	18	30		0	0	0	0	0	0	74.61	0	0	13.2
2014	7	17	11	42	18	31		0	0	0	0	0	0	74.93	0	0	13.2
2014	7	17	11	52	18	31		0	0	0	0	0	0	74.68	0	0	13.2
2014	7	17	12	2	18	30		0	0	0	0	0	0	74.88	0	0	13.2
2014	7	17	12	12	18	31		0	0	0	0	0	0	75.24	0	0	13.2
2014	7	17	12	22	18	31		0	0	0	0	0	0	75.6	0	0	13
2014	7	17	12	32	18	30		0	0	0	0	0	0	75.97	0	0	13.2
2014	7	17	12	42	18	31		0	0	0	0	0	0	76.42	0	0	13.2
2014	7	17	12	52	18	31		0	0	0	0	0	0	76.8	0	0	13.2
2014	7	17	13	2	18	31		0	0	0	0	0	0	77.23	0	0	13.2
2014	7	17	13	12	18	31		0	0	0	0	0	0	77.99	0	0	13.2
2014	7	17	13	22	18	31		0	0	0	0	0	0	78.66	0	0	13
2014	7	17	13	32	18	30		0	0	0	0	0	0	79.07	0	0	13.2
2014	7	17	13	42	18	31		0	0	0	0	0	0	79.47	0	0	13.2
2014	7	17	13	52	18	30		0	0	0	0	0	0	79.84	0	0	13.2
2014	7	17	14	2	18	31		0	0	0	0	0	0	80.17	0	0	13
2014	7	17	14	12	18	31		0	0	0	0	0	0	80.47	0	0	13
2014	7	17	14	22	18	31		0	0	0	0	0	0	80.76	0	0	12.8
2014	7	17	14	32	18	30		0	0	0	0	0	0	81.05	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	14	42	18	30	0	0	0	0	0	0	0	81.36	0	0	13
2014	7	17	14	52	18	30	0	0	0	0	0	0	0	81.61	0	0	13
2014	7	17	15	2	18	31	0	0	0	0	0	0	0	81.86	0	0	13
2014	7	17	15	12	18	30	0	0	0	0	0	0	0	82.08	0	0	12.8
2014	7	17	15	22	18	30	0	0	0	0	0	0	0	82.29	0	0	12.8
2014	7	17	15	32	18	30	0	0	0	0	0	0	0	82.49	0	0	12.8
2014	7	17	15	42	18	30	0	0	0	0	0	0	0	82.69	0	0	12.8
2014	7	17	15	52	18	30	0	0	0	0	0	0	0	82.81	0	0	12.6
2014	7	17	16	2	18	31	0	0	0	0	0	0	0	82.96	0	0	12.6
2014	7	17	16	12	18	30	0	0	0	0	0	0	0	83.08	0	0	12.6
2014	7	17	16	22	18	30	0	0	0	0	0	0	0	83.19	0	0	12.4
2014	7	17	16	32	18	31	0	0	0	0	0	0	0	83.28	0	0	12.4
2014	7	17	16	42	18	29	0	0	0	0	0	0	0	83.35	0	0	12.4
2014	7	17	16	52	18	30	0	0	0	0	0	0	0	83.41	0	0	12.4
2014	7	17	17	2	18	30	0	0	0	0	0	0	0	83.21	0	0	12.2
2014	7	17	17	12	18	30	0	0	0	0	0	0	0	83.07	0	0	12.2
2014	7	17	17	22	18	30	0	0	0	0	0	0	0	82.94	0	0	12.2
2014	7	17	17	32	18	30	0	0	0	0	0	0	0	82.78	0	0	12.2
2014	7	17	17	42	18	30	0	0	0	0	0	0	0	82.58	0	0	12.2
2014	7	17	17	52	18	30	0	0	0	0	0	0	0	82.42	0	0	12.2
2014	7	17	18	2	18	30	0	0	0	0	0	0	0	82.26	0	0	12.2
2014	7	17	18	12	18	30	0	0	0	0	0	0	0	82.06	0	0	12.2
2014	7	17	18	22	18	31	0	0	0	0	0	0	0	81.88	0	0	12.2
2014	7	17	18	32	18	30	0	0	0	0	0	0	0	81.64	0	0	12.2
2014	7	17	18	42	18	30	0	0	0	0	0	0	0	81.37	0	0	12.2
2014	7	17	18	52	18	30	0	0	0	0	0	0	0	81.12	0	0	12.2
2014	7	17	19	2	18	30	0	0	0	0	0	0	0	80.87	0	0	12.2
2014	7	17	19	12	18	30	0	0	0	0	0	0	0	80.6	0	0	12.2
2014	7	17	19	22	18	30	0	0	0	0	0	0	0	80.37	0	0	12
2014	7	17	19	32	18	30	0	0	0	0	0	0	0	80.1	0	0	12.2
2014	7	17	19	42	18	30	0	0	0	0	0	0	0	79.84	0	0	12.2
2014	7	17	19	52	18	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2014	7	17	20	2	18	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2014	7	17	20	12	18	30	0	0	0	0	0	0	0	79.07	0	0	12.2
2014	7	17	20	22	18	30	0	0	0	0	0	0	0	78.84	0	0	12
2014	7	17	20	32	18	30	0	0	0	0	0	0	0	78.58	0	0	12.2
2014	7	17	20	42	18	30	0	0	0	0	0	0	0	78.33	0	0	12.2
2014	7	17	20	52	18	30	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	17	21	2	18	30	0	0	0	0	0	0	0	77.83	0	0	12.2
2014	7	17	21	12	18	30	0	0	0	0	0	0	0	77.56	0	0	12.2
2014	7	17	21	22	18	30	0	0	0	0	0	0	0	77.32	0	0	12
2014	7	17	21	32	18	31	0	0	0	0	0	0	0	77.09	0	0	12.2
2014	7	17	21	42	18	31	0	0	0	0	0	0	0	76.86	0	0	12
2014	7	17	21	52	18	31	0	0	0	0	0	0	0	76.62	0	0	12
2014	7	17	22	2	18	30	0	0	0	0	0	0	0	76.39	0	0	12
2014	7	17	22	12	18	30	0	0	0	0	0	0	0	76.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	22	22	18	31	0	0	0	0	0	0	0	75.88	0	0	12
2014	7	17	22	32	18	31	0	0	0	0	0	0	0	75.63	0	0	12
2014	7	17	22	42	18	30	0	0	0	0	0	0	0	75.4	0	0	12
2014	7	17	22	52	18	31	0	0	0	0	0	0	0	75.16	0	0	12
2014	7	17	23	2	18	31	0	0	0	0	0	0	0	74.93	0	0	12
2014	7	17	23	12	18	31	0	0	0	0	0	0	0	74.71	0	0	12
2014	7	17	23	22	18	30	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	17	23	32	18	30	0	0	0	0	0	0	0	74.32	0	0	12
2014	7	17	23	42	18	31	0	0	0	0	0	0	0	74.16	0	0	12
2014	7	17	23	52	18	31	0	0	0	0	0	0	0	74.01	0	0	12
2014	7	18	0	2	18	31	0	0	0	0	0	0	0	73.87	0	0	12
2014	7	18	0	12	18	30	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	18	0	22	18	31	0	0	0	0	0	0	0	73.58	0	0	12
2014	7	18	0	32	18	31	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	18	0	42	18	31	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	18	0	52	18	31	0	0	0	0	0	0	0	73.22	0	0	12
2014	7	18	1	2	18	31	0	0	0	0	0	0	0	73.11	0	0	12
2014	7	18	1	12	18	32	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	18	1	22	18	32	0	0	0	0	0	0	0	72.91	0	0	11.8
2014	7	18	1	32	18	30	0	0	0	0	0	0	0	72.81	0	0	12
2014	7	18	1	42	18	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	18	1	52	18	32	0	0	0	0	0	0	0	72.63	0	0	12
2014	7	18	2	2	18	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	18	2	12	18	30	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	18	2	22	18	31	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	18	2	32	18	32	0	0	0	0	0	0	0	72.21	0	0	12
2014	7	18	2	42	18	30	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	18	2	52	18	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	18	3	2	18	31	0	0	0	0	0	0	0	71.92	0	0	12
2014	7	18	3	12	18	32	0	0	0	0	0	0	0	71.83	0	0	12
2014	7	18	3	22	18	31	0	0	0	0	0	0	0	71.74	0	0	12
2014	7	18	3	32	18	31	0	0	0	0	0	0	0	71.65	0	0	12
2014	7	18	3	42	18	32	0	0	0	0	0	0	0	71.58	0	0	12
2014	7	18	3	52	18	31	0	0	0	0	0	0	0	71.49	0	0	12
2014	7	18	4	2	18	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	18	4	12	18	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	7	18	4	22	18	32	0	0	0	0	0	0	0	71.22	0	0	11.8
2014	7	18	4	32	18	31	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	18	4	42	18	31	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	18	4	52	18	31	0	0	0	0	0	0	0	70.97	0	0	12
2014	7	18	5	2	18	32	0	0	0	0	0	0	0	70.88	0	0	12
2014	7	18	5	12	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	18	5	22	18	32	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	18	5	32	18	31	0	0	0	0	0	0	0	70.59	0	0	12
2014	7	18	5	42	18	30	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	18	5	52	18	31	0	0	0	0	0	0	0	70.36	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	6	2	18	32	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	18	6	12	18	32	0	0	0	0	0	0	0	70.14	0	0	12
2014	7	18	6	22	18	31	0	0	0	0	0	0	0	70.03	0	0	11.8
2014	7	18	6	32	18	32	0	0	0	0	0	0	0	69.93	0	0	12
2014	7	18	6	42	18	32	0	0	0	0	0	0	0	69.8	0	0	12
2014	7	18	6	52	18	31	0	0	0	0	0	0	0	69.71	0	0	12
2014	7	18	7	2	18	31	0	0	0	0	0	0	0	69.75	0	0	12.2
2014	7	18	7	12	18	31	0	0	0	0	0	0	0	69.69	0	0	12.2
2014	7	18	7	22	18	31	0	0	0	0	0	0	0	69.67	0	0	12.2
2014	7	18	7	32	18	31	0	0	0	0	0	0	0	69.66	0	0	12.4
2014	7	18	7	42	18	31	0	0	0	0	0	0	0	69.66	0	0	12.4
2014	7	18	7	52	18	32	0	0	0	0	0	0	0	69.67	0	0	12.4
2014	7	18	8	2	18	32	0	0	0	0	0	0	0	69.71	0	0	12.6
2014	7	18	8	12	18	31	0	0	0	0	0	0	0	69.75	0	0	12.6
2014	7	18	8	22	18	32	0	0	0	0	0	0	0	69.82	0	0	12.8
2014	7	18	8	32	18	31	0	0	0	0	0	0	0	69.89	0	0	12.8
2014	7	18	8	42	18	32	0	0	0	0	0	0	0	69.96	0	0	12.8
2014	7	18	8	52	18	31	0	0	0	0	0	0	0	70.05	0	0	13
2014	7	18	9	2	18	32	0	0	0	0	0	0	0	70.16	0	0	13
2014	7	18	9	12	18	31	0	0	0	0	0	0	0	70.29	0	0	13
2014	7	18	9	22	18	31	0	0	0	0	0	0	0	70.43	0	0	12.8
2014	7	18	9	32	18	32	0	0	0	0	0	0	0	70.57	0	0	13
2014	7	18	9	42	18	31	0	0	0	0	0	0	0	70.74	0	0	13
2014	7	18	9	52	18	30	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	18	10	2	18	32	0	0	0	0	0	0	0	71.11	0	0	13.2
2014	7	18	10	12	18	32	0	0	0	0	0	0	0	71.35	0	0	13.2
2014	7	18	10	22	18	31	0	0	0	0	0	0	0	71.56	0	0	13
2014	7	18	10	32	18	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	7	18	10	42	18	30	0	0	0	0	0	0	0	72.01	0	0	13.2
2014	7	18	10	52	18	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	18	11	2	18	32	0	0	0	0	0	0	0	72.52	0	0	13.2
2014	7	18	11	12	18	31	0	0	0	0	0	0	0	72.84	0	0	13.2
2014	7	18	11	22	18	31	0	0	0	0	0	0	0	73.15	0	0	13
2014	7	18	11	32	18	31	0	0	0	0	0	0	0	73.47	0	0	13.2
2014	7	18	11	42	18	31	0	0	0	0	0	0	0	73.74	0	0	13.2
2014	7	18	11	52	18	31	0	0	0	0	0	0	0	73.42	0	0	13.2
2014	7	18	12	2	18	31	0	0	0	0	0	0	0	73.6	0	0	13.2
2014	7	18	12	12	18	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	18	12	22	18	31	0	0	0	0	0	0	0	74.34	0	0	13.2
2014	7	18	12	32	18	31	0	0	0	0	0	0	0	74.73	0	0	13.2
2014	7	18	12	42	18	31	0	0	0	0	0	0	0	75.16	0	0	13.2
2014	7	18	12	52	18	30	0	0	0	0	0	0	0	75.56	0	0	13.2
2014	7	18	13	2	18	31	0	0	0	0	0	0	0	75.99	0	0	13.2
2014	7	18	13	12	18	31	0	0	0	0	0	0	0	76.82	0	0	13.2
2014	7	18	13	22	18	31	0	0	0	0	0	0	0	77.47	0	0	13
2014	7	18	13	32	18	30	0	0	0	0	0	0	0	77.92	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	13	42	18	31	0	0	0	0	0	0	0	78.35	0	0	13.2
2014	7	18	13	52	18	30	0	0	0	0	0	0	0	78.69	0	0	13.2
2014	7	18	14	2	18	30	0	0	0	0	0	0	0	79.02	0	0	13.2
2014	7	18	14	12	18	30	0	0	0	0	0	0	0	79.36	0	0	13
2014	7	18	14	22	18	30	0	0	0	0	0	0	0	79.66	0	0	13
2014	7	18	14	32	18	30	0	0	0	0	0	0	0	79.95	0	0	13
2014	7	18	14	42	18	31	0	0	0	0	0	0	0	80.22	0	0	13
2014	7	18	14	52	18	30	0	0	0	0	0	0	0	80.46	0	0	13
2014	7	18	15	2	18	30	0	0	0	0	0	0	0	80.71	0	0	13
2014	7	18	15	12	18	31	0	0	0	0	0	0	0	80.96	0	0	12.8
2014	7	18	15	22	18	30	0	0	0	0	0	0	0	81.18	0	0	12.8
2014	7	18	15	32	18	30	0	0	0	0	0	0	0	81.39	0	0	12.8
2014	7	18	15	42	18	30	0	0	0	0	0	0	0	81.59	0	0	12.8
2014	7	18	15	52	18	31	0	0	0	0	0	0	0	81.79	0	0	12.8
2014	7	18	16	2	18	30	0	0	0	0	0	0	0	81.93	0	0	12.6
2014	7	18	16	12	18	30	0	0	0	0	0	0	0	82.08	0	0	12.6
2014	7	18	16	22	18	31	0	0	0	0	0	0	0	82.17	0	0	12.4
2014	7	18	16	32	18	29	0	0	0	0	0	0	0	82.17	0	0	12.4
2014	7	18	16	42	18	31	0	0	0	0	0	0	0	82.31	0	0	12.4
2014	7	18	16	52	18	30	0	0	0	0	0	0	0	82.33	0	0	12.4
2014	7	18	17	2	18	30	0	0	0	0	0	0	0	82.36	0	0	12.4
2014	7	18	17	12	18	30	0	0	0	0	0	0	0	82.38	0	0	12.4
2014	7	18	17	22	18	30	0	0	0	0	0	0	0	82.35	0	0	12.2
2014	7	18	17	32	18	30	0	0	0	0	0	0	0	82.22	0	0	12.2
2014	7	18	17	42	18	30	0	0	0	0	0	0	0	81.95	0	0	12.2
2014	7	18	17	52	18	30	0	0	0	0	0	0	0	81.82	0	0	12.2
2014	7	18	18	2	18	30	0	0	0	0	0	0	0	81.68	0	0	12.2
2014	7	18	18	12	18	30	0	0	0	0	0	0	0	81.54	0	0	12.2
2014	7	18	18	22	18	30	0	0	0	0	0	0	0	81.37	0	0	12.2
2014	7	18	18	32	18	30	0	0	0	0	0	0	0	81.19	0	0	12.2
2014	7	18	18	42	18	30	0	0	0	0	0	0	0	81	0	0	12.2
2014	7	18	18	52	18	30	0	0	0	0	0	0	0	80.82	0	0	12.2
2014	7	18	19	2	18	30	0	0	0	0	0	0	0	80.62	0	0	12.2
2014	7	18	19	12	18	30	0	0	0	0	0	0	0	80.44	0	0	12.2
2014	7	18	19	22	18	30	0	0	0	0	0	0	0	80.22	0	0	12.2
2014	7	18	19	32	18	30	0	0	0	0	0	0	0	80.02	0	0	12.2
2014	7	18	19	42	18	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	18	19	52	18	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2014	7	18	20	2	18	30	0	0	0	0	0	0	0	79.39	0	0	12.2
2014	7	18	20	12	18	30	0	0	0	0	0	0	0	79.18	0	0	12.2
2014	7	18	20	22	18	31	0	0	0	0	0	0	0	78.98	0	0	12
2014	7	18	20	32	18	30	0	0	0	0	0	0	0	78.78	0	0	12.2
2014	7	18	20	42	18	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	18	20	52	18	30	0	0	0	0	0	0	0	78.35	0	0	12.2
2014	7	18	21	2	18	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2014	7	18	21	12	18	31	0	0	0	0	0	0	0	77.9	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	21	22	18	31	0	0	0	0	0	0	0	77.68	0	0	12.2
2014	7	18	21	32	18	30	0	0	0	0	0	0	0	77.45	0	0	12.2
2014	7	18	21	42	18	30	0	0	0	0	0	0	0	77.22	0	0	12.2
2014	7	18	21	52	18	30	0	0	0	0	0	0	0	77.02	0	0	12.2
2014	7	18	22	2	18	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2014	7	18	22	12	18	30	0	0	0	0	0	0	0	76.59	0	0	12.2
2014	7	18	22	22	18	31	0	0	0	0	0	0	0	76.37	0	0	12
2014	7	18	22	32	18	31	0	0	0	0	0	0	0	76.17	0	0	12.2
2014	7	18	22	42	18	30	0	0	0	0	0	0	0	75.97	0	0	12
2014	7	18	22	52	18	30	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	18	23	2	18	31	0	0	0	0	0	0	0	75.56	0	0	12
2014	7	18	23	12	18	31	0	0	0	0	0	0	0	75.38	0	0	12
2014	7	18	23	22	18	31	0	0	0	0	0	0	0	75.2	0	0	12
2014	7	18	23	32	18	31	0	0	0	0	0	0	0	75.02	0	0	12
2014	7	18	23	42	18	31	0	0	0	0	0	0	0	74.84	0	0	12
2014	7	18	23	52	18	31	0	0	0	0	0	0	0	74.68	0	0	12
2014	7	19	0	2	18	31	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	19	0	12	18	31	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	19	0	22	18	30	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	19	0	32	18	31	0	0	0	0	0	0	0	74.1	0	0	12
2014	7	19	0	42	18	31	0	0	0	0	0	0	0	73.98	0	0	12
2014	7	19	0	52	18	31	0	0	0	0	0	0	0	73.87	0	0	12
2014	7	19	1	2	18	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	19	1	12	18	32	0	0	0	0	0	0	0	73.67	0	0	12
2014	7	19	1	22	18	32	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	19	1	32	18	31	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	19	1	42	18	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	19	1	52	18	30	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	19	2	2	18	31	0	0	0	0	0	0	0	73.06	0	0	12
2014	7	19	2	12	18	31	0	0	0	0	0	0	0	72.95	0	0	12
2014	7	19	2	22	18	30	0	0	0	0	0	0	0	72.86	0	0	12
2014	7	19	2	32	18	31	0	0	0	0	0	0	0	72.75	0	0	12
2014	7	19	2	42	18	31	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	19	2	52	18	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	19	3	2	18	31	0	0	0	0	0	0	0	72.45	0	0	12
2014	7	19	3	12	18	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	19	3	22	18	31	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	19	3	32	18	31	0	0	0	0	0	0	0	72.16	0	0	12
2014	7	19	3	42	18	32	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	19	3	52	18	31	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	19	4	2	18	31	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	19	4	12	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	19	4	22	18	32	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	19	4	32	18	31	0	0	0	0	0	0	0	71.62	0	0	12
2014	7	19	4	42	18	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	7	19	4	52	18	32	0	0	0	0	0	0	0	71.44	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	5	2	18	31	0	0	0	0	0	0	0	71.33	0	0	12
2014	7	19	5	12	18	31	0	0	0	0	0	0	0	71.26	0	0	12
2014	7	19	5	22	18	31	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	19	5	32	18	32	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	19	5	42	18	32	0	0	0	0	0	0	0	70.99	0	0	12
2014	7	19	5	52	18	31	0	0	0	0	0	0	0	70.88	0	0	12
2014	7	19	6	2	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	19	6	12	18	31	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	19	6	22	18	30	0	0	0	0	0	0	0	70.59	0	0	11.8
2014	7	19	6	32	18	32	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	19	6	42	18	32	0	0	0	0	0	0	0	70.39	0	0	12
2014	7	19	6	52	18	31	0	0	0	0	0	0	0	70.29	0	0	12
2014	7	19	7	2	18	31	0	0	0	0	0	0	0	70.34	0	0	12.2
2014	7	19	7	12	18	31	0	0	0	0	0	0	0	70.3	0	0	12.2
2014	7	19	7	22	18	31	0	0	0	0	0	0	0	70.23	0	0	12.2
2014	7	19	7	32	18	31	0	0	0	0	0	0	0	70.25	0	0	12.4
2014	7	19	7	42	18	31	0	0	0	0	0	0	0	70.34	0	0	12.4
2014	7	19	7	52	18	31	0	0	0	0	0	0	0	70.32	0	0	12.6
2014	7	19	8	2	18	31	0	0	0	0	0	0	0	70.2	0	0	12.4
2014	7	19	8	12	18	32	0	0	0	0	0	0	0	70.16	0	0	12.6
2014	7	19	8	22	18	31	0	0	0	0	0	0	0	70.38	0	0	12.6
2014	7	19	8	32	18	31	0	0	0	0	0	0	0	70.43	0	0	12.8
2014	7	19	8	42	18	32	0	0	0	0	0	0	0	70.5	0	0	12.8
2014	7	19	8	52	18	32	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	19	9	2	18	31	0	0	0	0	0	0	0	70.68	0	0	13
2014	7	19	9	12	18	31	0	0	0	0	0	0	0	70.75	0	0	13
2014	7	19	9	22	18	32	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	19	9	32	18	31	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	19	9	42	18	31	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	19	9	52	18	32	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	19	10	2	18	31	0	0	0	0	0	0	0	71.53	0	0	13.2
2014	7	19	10	12	18	32	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	19	10	22	18	30	0	0	0	0	0	0	0	72.03	0	0	13
2014	7	19	10	32	18	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	19	10	42	18	31	0	0	0	0	0	0	0	72.46	0	0	13.2
2014	7	19	10	52	18	31	0	0	0	0	0	0	0	72.77	0	0	13.2
2014	7	19	11	2	18	31	0	0	0	0	0	0	0	73	0	0	13.2
2014	7	19	11	12	18	31	0	0	0	0	0	0	0	73.02	0	0	13
2014	7	19	11	22	18	31	0	0	0	0	0	0	0	73.67	0	0	13
2014	7	19	11	32	18	31	0	0	0	0	0	0	0	73.62	0	0	13
2014	7	19	11	42	18	31	0	0	0	0	0	0	0	73.83	0	0	13
2014	7	19	11	52	18	31	0	0	0	0	0	0	0	73.78	0	0	12.8
2014	7	19	12	2	18	31	0	0	0	0	0	0	0	74.05	0	0	13.2
2014	7	19	12	12	18	31	0	0	0	0	0	0	0	74.35	0	0	13
2014	7	19	12	22	18	31	0	0	0	0	0	0	0	74.64	0	0	12.8
2014	7	19	12	32	18	32	0	0	0	0	0	0	0	74.95	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	12	42	18	31	0	0	0	0	0	0	0	75.27	0	0	13.2
2014	7	19	12	52	18	31	0	0	0	0	0	0	0	75.58	0	0	13
2014	7	19	13	2	18	31	0	0	0	0	0	0	0	75.9	0	0	13
2014	7	19	13	12	18	31	0	0	0	0	0	0	0	76.08	0	0	12.6
2014	7	19	13	22	18	31	0	0	0	0	0	0	0	76.32	0	0	12.4
2014	7	19	13	32	18	31	0	0	0	0	0	0	0	76.53	0	0	12.6
2014	7	19	13	42	18	31	0	0	0	0	0	0	0	76.68	0	0	12.6
2014	7	19	13	52	18	32	0	0	0	0	0	0	0	77.23	0	0	13
2014	7	19	14	2	18	30	0	0	0	0	0	0	0	77.09	0	0	12.6
2014	7	19	14	12	18	31	0	0	0	0	0	0	0	77.13	0	0	12.6
2014	7	19	14	22	18	30	0	0	0	0	0	0	0	77.47	0	0	12.8
2014	7	19	14	32	18	30	0	0	0	0	0	0	0	78.01	0	0	13.2
2014	7	19	14	42	18	30	0	0	0	0	0	0	0	78.3	0	0	13
2014	7	19	14	52	18	30	0	0	0	0	0	0	0	78.48	0	0	13
2014	7	19	15	2	18	31	0	0	0	0	0	0	0	78.51	0	0	12.8
2014	7	19	15	12	18	31	0	0	0	0	0	0	0	78.62	0	0	12.8
2014	7	19	15	22	18	30	0	0	0	0	0	0	0	78.98	0	0	12.6
2014	7	19	15	32	18	30	0	0	0	0	0	0	0	79.2	0	0	12.8
2014	7	19	15	42	18	30	0	0	0	0	0	0	0	79.36	0	0	12.6
2014	7	19	15	52	18	31	0	0	0	0	0	0	0	79.57	0	0	12.8
2014	7	19	16	2	18	31	0	0	0	0	0	0	0	79.72	0	0	12.8
2014	7	19	16	12	18	30	0	0	0	0	0	0	0	79.57	0	0	12.4
2014	7	19	16	22	18	30	0	0	0	0	0	0	0	79.59	0	0	12.4
2014	7	19	16	32	18	30	0	0	0	0	0	0	0	79.57	0	0	12.4
2014	7	19	16	42	18	30	0	0	0	0	0	0	0	79.41	0	0	12.4
2014	7	19	16	52	18	31	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	19	17	2	18	31	0	0	0	0	0	0	0	79.18	0	0	12.4
2014	7	19	17	12	18	30	0	0	0	0	0	0	0	79.03	0	0	12.4
2014	7	19	17	22	18	30	0	0	0	0	0	0	0	78.93	0	0	12.2
2014	7	19	17	32	18	31	0	0	0	0	0	0	0	78.78	0	0	12.4
2014	7	19	17	42	18	30	0	0	0	0	0	0	0	78.64	0	0	12.4
2014	7	19	17	52	18	30	0	0	0	0	0	0	0	78.48	0	0	12.4
2014	7	19	18	2	18	31	0	0	0	0	0	0	0	78.33	0	0	12.2
2014	7	19	18	12	18	30	0	0	0	0	0	0	0	78.15	0	0	12.2
2014	7	19	18	22	18	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2014	7	19	18	32	18	31	0	0	0	0	0	0	0	77.79	0	0	12.2
2014	7	19	18	42	18	31	0	0	0	0	0	0	0	77.61	0	0	12.2
2014	7	19	18	52	18	30	0	0	0	0	0	0	0	77.43	0	0	12.2
2014	7	19	19	2	18	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2014	7	19	19	12	18	31	0	0	0	0	0	0	0	77.05	0	0	12.2
2014	7	19	19	22	18	30	0	0	0	0	0	0	0	76.86	0	0	12.2
2014	7	19	19	32	18	30	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	19	19	42	18	30	0	0	0	0	0	0	0	76.42	0	0	12.2
2014	7	19	19	52	18	31	0	0	0	0	0	0	0	76.19	0	0	12.2
2014	7	19	20	2	18	30	0	0	0	0	0	0	0	75.99	0	0	12.2
2014	7	19	20	12	18	30	0	0	0	0	0	0	0	75.79	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	20	22	18	30	0	0	0	0	0	0	0	75.61	0	0	12
2014	7	19	20	32	18	31	0	0	0	0	0	0	0	75.43	0	0	12.2
2014	7	19	20	42	18	31	0	0	0	0	0	0	0	75.27	0	0	12.2
2014	7	19	20	52	18	30	0	0	0	0	0	0	0	75.11	0	0	12.2
2014	7	19	21	2	18	31	0	0	0	0	0	0	0	74.95	0	0	12.2
2014	7	19	21	12	18	31	0	0	0	0	0	0	0	74.79	0	0	12.2
2014	7	19	21	22	18	31	0	0	0	0	0	0	0	74.62	0	0	12
2014	7	19	21	32	18	31	0	0	0	0	0	0	0	74.46	0	0	12
2014	7	19	21	42	18	31	0	0	0	0	0	0	0	74.3	0	0	12
2014	7	19	21	52	18	31	0	0	0	0	0	0	0	74.16	0	0	12
2014	7	19	22	2	18	30	0	0	0	0	0	0	0	73.99	0	0	12
2014	7	19	22	12	18	31	0	0	0	0	0	0	0	73.87	0	0	12
2014	7	19	22	22	18	31	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	19	22	32	18	31	0	0	0	0	0	0	0	73.58	0	0	12
2014	7	19	22	42	18	30	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	19	22	52	18	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	19	23	2	18	31	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	19	23	12	18	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	19	23	22	18	31	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	19	23	32	18	32	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	19	23	42	18	31	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	19	23	52	18	32	0	0	0	0	0	0	0	72.7	0	0	12
2014	7	20	0	2	18	31	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	20	0	12	18	30	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	20	0	22	18	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	20	0	32	18	31	0	0	0	0	0	0	0	72.32	0	0	12
2014	7	20	0	42	18	31	0	0	0	0	0	0	0	72.23	0	0	12
2014	7	20	0	52	18	31	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	20	1	2	18	31	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	20	1	12	18	31	0	0	0	0	0	0	0	71.94	0	0	12
2014	7	20	1	22	18	31	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	20	1	32	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	20	1	42	18	31	0	0	0	0	0	0	0	71.69	0	0	12
2014	7	20	1	52	18	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	7	20	2	2	18	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	20	2	12	18	31	0	0	0	0	0	0	0	71.49	0	0	12
2014	7	20	2	22	18	31	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	20	2	32	18	31	0	0	0	0	0	0	0	71.37	0	0	12
2014	7	20	2	42	18	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	7	20	2	52	18	32	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	20	3	2	18	31	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	20	3	12	18	32	0	0	0	0	0	0	0	71.11	0	0	12
2014	7	20	3	22	18	31	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	20	3	32	18	31	0	0	0	0	0	0	0	70.99	0	0	12
2014	7	20	3	42	18	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	20	3	52	18	32	0	0	0	0	0	0	0	70.86	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	4	2	18	31	0	0	0	0	0	0	0	70.81	0	0	12
2014	7	20	4	12	18	31	0	0	0	0	0	0	0	70.74	0	0	12
2014	7	20	4	22	18	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	20	4	32	18	31	0	0	0	0	0	0	0	70.57	0	0	12
2014	7	20	4	42	18	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	7	20	4	52	18	31	0	0	0	0	0	0	0	70.43	0	0	12
2014	7	20	5	2	18	32	0	0	0	0	0	0	0	70.34	0	0	12
2014	7	20	5	12	18	31	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	20	5	22	18	31	0	0	0	0	0	0	0	70.18	0	0	11.8
2014	7	20	5	32	18	32	0	0	0	0	0	0	0	70.09	0	0	12
2014	7	20	5	42	18	31	0	0	0	0	0	0	0	70	0	0	12
2014	7	20	5	52	18	31	0	0	0	0	0	0	0	69.91	0	0	12
2014	7	20	6	2	18	31	0	0	0	0	0	0	0	69.84	0	0	12
2014	7	20	6	12	18	31	0	0	0	0	0	0	0	69.75	0	0	12
2014	7	20	6	22	18	31	0	0	0	0	0	0	0	69.66	0	0	11.8
2014	7	20	6	32	18	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	7	20	6	42	18	31	0	0	0	0	0	0	0	69.49	0	0	12
2014	7	20	6	52	18	32	0	0	0	0	0	0	0	69.42	0	0	12
2014	7	20	7	2	18	31	0	0	0	0	0	0	0	69.48	0	0	12.2
2014	7	20	7	12	18	32	0	0	0	0	0	0	0	69.31	0	0	12
2014	7	20	7	22	18	31	0	0	0	0	0	0	0	69.19	0	0	11.8
2014	7	20	7	32	18	31	0	0	0	0	0	0	0	69.1	0	0	12
2014	7	20	7	42	18	32	0	0	0	0	0	0	0	69.03	0	0	12
2014	7	20	7	52	18	32	0	0	0	0	0	0	0	68.92	0	0	12
2014	7	20	8	2	18	31	0	0	0	0	0	0	0	68.83	0	0	12
2014	7	20	8	12	18	32	0	0	0	0	0	0	0	68.76	0	0	12
2014	7	20	8	22	18	31	0	0	0	0	0	0	0	68.68	0	0	11.8
2014	7	20	8	32	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	7	20	8	42	18	32	0	0	0	0	0	0	0	68.61	0	0	12.2
2014	7	20	8	52	18	31	0	0	0	0	0	0	0	68.7	0	0	12.2
2014	7	20	9	2	18	31	0	0	0	0	0	0	0	68.74	0	0	12.4
2014	7	20	9	12	18	31	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	7	20	9	22	18	32	0	0	0	0	0	0	0	69.55	0	0	13.2
2014	7	20	9	32	18	32	0	0	0	0	0	0	0	69.55	0	0	13.4
2014	7	20	9	42	18	31	0	0	0	0	0	0	0	69.71	0	0	13.2
2014	7	20	9	52	18	31	0	0	0	0	0	0	0	69.96	0	0	13.4
2014	7	20	10	2	18	32	0	0	0	0	0	0	0	70.25	0	0	13.4
2014	7	20	10	12	18	31	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	20	10	22	18	31	0	0	0	0	0	0	0	70.7	0	0	13.4
2014	7	20	10	32	18	31	0	0	0	0	0	0	0	70.88	0	0	13.4
2014	7	20	10	42	18	31	0	0	0	0	0	0	0	71.22	0	0	13.4
2014	7	20	10	52	18	32	0	0	0	0	0	0	0	71.33	0	0	13.4
2014	7	20	11	2	18	31	0	0	0	0	0	0	0	71.55	0	0	13.4
2014	7	20	11	12	18	32	0	0	0	0	0	0	0	71.92	0	0	13.4
2014	7	20	11	22	18	31	0	0	0	0	0	0	0	72.23	0	0	13.4
2014	7	20	11	32	18	32	0	0	0	0	0	0	0	72.52	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	11	42	18	32	0	0	0	0	0	0	0	72.72	0	0	13.4
2014	7	20	11	52	18	31	0	0	0	0	0	0	0	72.3	0	0	13
2014	7	20	12	2	18	31	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	20	12	12	18	30	0	0	0	0	0	0	0	72.79	0	0	13
2014	7	20	12	22	18	31	0	0	0	0	0	0	0	73.17	0	0	13.2
2014	7	20	12	32	18	31	0	0	0	0	0	0	0	73.38	0	0	13
2014	7	20	12	42	18	31	0	0	0	0	0	0	0	73.65	0	0	13
2014	7	20	12	52	18	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	20	13	2	18	31	0	0	0	0	0	0	0	74.12	0	0	13.2
2014	7	20	13	12	18	31	0	0	0	0	0	0	0	74.12	0	0	12.6
2014	7	20	13	22	18	31	0	0	0	0	0	0	0	74.35	0	0	12.6
2014	7	20	13	32	18	31	0	0	0	0	0	0	0	74.79	0	0	13.2
2014	7	20	13	42	18	31	0	0	0	0	0	0	0	75.61	0	0	13.4
2014	7	20	13	52	18	31	0	0	0	0	0	0	0	75.22	0	0	12.8
2014	7	20	14	2	18	31	0	0	0	0	0	0	0	75.85	0	0	13.4
2014	7	20	14	12	18	31	0	0	0	0	0	0	0	75.94	0	0	13
2014	7	20	14	22	18	31	0	0	0	0	0	0	0	76.42	0	0	13.2
2014	7	20	14	32	18	31	0	0	0	0	0	0	0	76.8	0	0	13.2
2014	7	20	14	42	18	31	0	0	0	0	0	0	0	77.11	0	0	13.2
2014	7	20	14	52	18	31	0	0	0	0	0	0	0	77.45	0	0	13.2
2014	7	20	15	2	18	31	0	0	0	0	0	0	0	77.61	0	0	13
2014	7	20	15	12	18	31	0	0	0	0	0	0	0	77.59	0	0	12.6
2014	7	20	15	22	18	30	0	0	0	0	0	0	0	77.77	0	0	12.4
2014	7	20	15	32	18	31	0	0	0	0	0	0	0	78.12	0	0	12.8
2014	7	20	15	42	18	30	0	0	0	0	0	0	0	78.22	0	0	12.6
2014	7	20	15	52	18	31	0	0	0	0	0	0	0	78.49	0	0	12.8
2014	7	20	16	2	18	30	0	0	0	0	0	0	0	78.71	0	0	12.6
2014	7	20	16	12	18	31	0	0	0	0	0	0	0	78.67	0	0	12.6
2014	7	20	16	22	18	30	0	0	0	0	0	0	0	78.73	0	0	12.4
2014	7	20	16	32	18	30	0	0	0	0	0	0	0	78.78	0	0	12.4
2014	7	20	16	42	18	30	0	0	0	0	0	0	0	78.85	0	0	12.4
2014	7	20	16	52	18	30	0	0	0	0	0	0	0	78.89	0	0	12.4
2014	7	20	17	2	18	31	0	0	0	0	0	0	0	79.07	0	0	12.4
2014	7	20	17	12	18	30	0	0	0	0	0	0	0	79.23	0	0	12.4
2014	7	20	17	22	18	31	0	0	0	0	0	0	0	79.27	0	0	12.2
2014	7	20	17	32	18	30	0	0	0	0	0	0	0	79.25	0	0	12.2
2014	7	20	17	42	18	30	0	0	0	0	0	0	0	79.05	0	0	12.2
2014	7	20	17	52	18	30	0	0	0	0	0	0	0	79.03	0	0	12.2
2014	7	20	18	2	18	30	0	0	0	0	0	0	0	79.03	0	0	12.2
2014	7	20	18	12	18	30	0	0	0	0	0	0	0	79.03	0	0	12.2
2014	7	20	18	22	18	30	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	20	18	32	18	30	0	0	0	0	0	0	0	78.98	0	0	12.2
2014	7	20	18	42	18	30	0	0	0	0	0	0	0	78.96	0	0	12.2
2014	7	20	18	52	18	30	0	0	0	0	0	0	0	78.87	0	0	12.2
2014	7	20	19	2	18	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2014	7	20	19	12	18	30	0	0	0	0	0	0	0	78.71	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	19	22	18	30	0	0	0	0	0	0	0	78.58	0	0	12.2
2014	7	20	19	32	18	30	0	0	0	0	0	0	0	78.42	0	0	12.2
2014	7	20	19	42	18	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2014	7	20	19	52	18	30	0	0	0	0	0	0	0	78.1	0	0	12.2
2014	7	20	20	2	18	30	0	0	0	0	0	0	0	77.9	0	0	12.2
2014	7	20	20	12	18	30	0	0	0	0	0	0	0	77.72	0	0	12.2
2014	7	20	20	22	18	30	0	0	0	0	0	0	0	77.54	0	0	12
2014	7	20	20	32	18	30	0	0	0	0	0	0	0	77.4	0	0	12.2
2014	7	20	20	42	18	31	0	0	0	0	0	0	0	77.23	0	0	12.2
2014	7	20	20	52	18	30	0	0	0	0	0	0	0	77.07	0	0	12.2
2014	7	20	21	2	18	31	0	0	0	0	0	0	0	76.91	0	0	12.2
2014	7	20	21	12	18	30	0	0	0	0	0	0	0	76.75	0	0	12.2
2014	7	20	21	22	18	31	0	0	0	0	0	0	0	76.57	0	0	12
2014	7	20	21	32	18	31	0	0	0	0	0	0	0	76.37	0	0	12.2
2014	7	20	21	42	18	30	0	0	0	0	0	0	0	76.19	0	0	12.2
2014	7	20	21	52	18	30	0	0	0	0	0	0	0	75.99	0	0	12.2
2014	7	20	22	2	18	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	20	22	12	18	30	0	0	0	0	0	0	0	75.56	0	0	12
2014	7	20	22	22	18	30	0	0	0	0	0	0	0	75.34	0	0	12
2014	7	20	22	32	18	30	0	0	0	0	0	0	0	75.11	0	0	12
2014	7	20	22	42	18	31	0	0	0	0	0	0	0	74.89	0	0	12
2014	7	20	22	52	18	30	0	0	0	0	0	0	0	74.66	0	0	12
2014	7	20	23	2	18	30	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	20	23	12	18	31	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	20	23	22	18	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	20	23	32	18	32	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	20	23	42	18	30	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	20	23	52	18	31	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	21	0	2	18	31	0	0	0	0	0	0	0	73.26	0	0	12
2014	7	21	0	12	18	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	21	0	22	18	31	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	21	0	32	18	32	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	21	0	42	18	32	0	0	0	0	0	0	0	72.59	0	0	12
2014	7	21	0	52	18	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	21	1	2	18	31	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	21	1	12	18	31	0	0	0	0	0	0	0	72.14	0	0	12
2014	7	21	1	22	18	30	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	21	1	32	18	31	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	21	1	42	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	21	1	52	18	31	0	0	0	0	0	0	0	71.65	0	0	12
2014	7	21	2	2	18	31	0	0	0	0	0	0	0	71.53	0	0	12
2014	7	21	2	12	18	30	0	0	0	0	0	0	0	71.38	0	0	12
2014	7	21	2	22	18	31	0	0	0	0	0	0	0	71.26	0	0	11.8
2014	7	21	2	32	18	31	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	21	2	42	18	31	0	0	0	0	0	0	0	71.02	0	0	12
2014	7	21	2	52	18	31	0	0	0	0	0	0	0	70.92	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	3	2	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	21	3	12	18	32	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	21	3	22	18	31	0	0	0	0	0	0	0	70.59	0	0	11.8
2014	7	21	3	32	18	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	21	3	42	18	31	0	0	0	0	0	0	0	70.38	0	0	12
2014	7	21	3	52	18	31	0	0	0	0	0	0	0	70.29	0	0	12
2014	7	21	4	2	18	31	0	0	0	0	0	0	0	70.18	0	0	12
2014	7	21	4	12	18	32	0	0	0	0	0	0	0	70.09	0	0	12
2014	7	21	4	22	18	31	0	0	0	0	0	0	0	69.98	0	0	11.8
2014	7	21	4	32	18	31	0	0	0	0	0	0	0	69.87	0	0	12
2014	7	21	4	42	18	31	0	0	0	0	0	0	0	69.78	0	0	12
2014	7	21	4	52	18	31	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	21	5	2	18	31	0	0	0	0	0	0	0	69.58	0	0	12
2014	7	21	5	12	18	31	0	0	0	0	0	0	0	69.48	0	0	12
2014	7	21	5	22	18	31	0	0	0	0	0	0	0	69.39	0	0	11.8
2014	7	21	5	32	18	32	0	0	0	0	0	0	0	69.28	0	0	12
2014	7	21	5	42	18	31	0	0	0	0	0	0	0	69.17	0	0	12
2014	7	21	5	52	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	7	21	6	2	18	32	0	0	0	0	0	0	0	68.99	0	0	12
2014	7	21	6	12	18	30	0	0	0	0	0	0	0	68.9	0	0	12
2014	7	21	6	22	18	31	0	0	0	0	0	0	0	68.81	0	0	11.8
2014	7	21	6	32	18	31	0	0	0	0	0	0	0	68.72	0	0	12
2014	7	21	6	42	18	33	0	0	0	0	0	0	0	68.63	0	0	12
2014	7	21	6	52	18	32	0	0	0	0	0	0	0	68.56	0	0	12
2014	7	21	7	2	18	31	0	0	0	0	0	0	0	68.58	0	0	12.2
2014	7	21	7	12	18	31	0	0	0	0	0	0	0	68.63	0	0	12.2
2014	7	21	7	22	18	32	0	0	0	0	0	0	0	68.61	0	0	12.2
2014	7	21	7	32	18	32	0	0	0	0	0	0	0	68.63	0	0	12.4
2014	7	21	7	42	18	32	0	0	0	0	0	0	0	68.7	0	0	12.6
2014	7	21	7	52	18	31	0	0	0	0	0	0	0	68.76	0	0	12.8
2014	7	21	8	2	18	31	0	0	0	0	0	0	0	68.83	0	0	12.8
2014	7	21	8	12	18	32	0	0	0	0	0	0	0	68.88	0	0	13
2014	7	21	8	22	18	33	0	0	0	0	0	0	0	68.97	0	0	12.8
2014	7	21	8	32	18	31	0	0	0	0	0	0	0	69.08	0	0	13
2014	7	21	8	42	18	32	0	0	0	0	0	0	0	69.17	0	0	13
2014	7	21	8	52	18	32	0	0	0	0	0	0	0	69.28	0	0	13.2
2014	7	21	9	2	18	32	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	7	21	9	12	18	31	0	0	0	0	0	0	0	69.55	0	0	13.2
2014	7	21	9	22	18	31	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	21	9	32	18	31	0	0	0	0	0	0	0	69.85	0	0	13.2
2014	7	21	9	42	18	31	0	0	0	0	0	0	0	70.03	0	0	13.4
2014	7	21	9	52	18	31	0	0	0	0	0	0	0	70.21	0	0	13.4
2014	7	21	10	2	18	30	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	21	10	12	18	31	0	0	0	0	0	0	0	70.57	0	0	13.4
2014	7	21	10	22	18	32	0	0	0	0	0	0	0	70.81	0	0	13.2
2014	7	21	10	32	18	32	0	0	0	0	0	0	0	71.01	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	10	42	18	31	0	0	0	0	0	0	0	71.24	0	0	13.4
2014	7	21	10	52	18	32	0	0	0	0	0	0	0	71.49	0	0	13.4
2014	7	21	11	2	18	31	0	0	0	0	0	0	0	71.76	0	0	13.4
2014	7	21	11	12	18	31	0	0	0	0	0	0	0	71.98	0	0	13.4
2014	7	21	11	22	18	31	0	0	0	0	0	0	0	72.27	0	0	13.4
2014	7	21	11	32	18	31	0	0	0	0	0	0	0	72.52	0	0	13.4
2014	7	21	11	42	18	31	0	0	0	0	0	0	0	72.66	0	0	13.4
2014	7	21	11	52	18	31	0	0	0	0	0	0	0	72.14	0	0	13.4
2014	7	21	12	2	18	31	0	0	0	0	0	0	0	72.3	0	0	13.4
2014	7	21	12	12	18	30	0	0	0	0	0	0	0	72.57	0	0	13.4
2014	7	21	12	22	18	31	0	0	0	0	0	0	0	72.88	0	0	13.4
2014	7	21	12	32	18	31	0	0	0	0	0	0	0	73.22	0	0	13.4
2014	7	21	12	42	18	31	0	0	0	0	0	0	0	73.56	0	0	13.4
2014	7	21	12	52	18	31	0	0	0	0	0	0	0	73.94	0	0	13.4
2014	7	21	13	2	18	31	0	0	0	0	0	0	0	74.34	0	0	13.4
2014	7	21	13	12	18	31	0	0	0	0	0	0	0	75.38	0	0	13.4
2014	7	21	13	22	18	31	0	0	0	0	0	0	0	75.97	0	0	13.2
2014	7	21	13	32	18	31	0	0	0	0	0	0	0	76.39	0	0	13.4
2014	7	21	13	42	18	30	0	0	0	0	0	0	0	76.66	0	0	13.4
2014	7	21	13	52	18	31	0	0	0	0	0	0	0	77.07	0	0	13.4
2014	7	21	14	2	18	30	0	0	0	0	0	0	0	77.41	0	0	13.4
2014	7	21	14	12	18	30	0	0	0	0	0	0	0	77.72	0	0	13.4
2014	7	21	14	22	18	30	0	0	0	0	0	0	0	78.06	0	0	13.2
2014	7	21	14	32	18	31	0	0	0	0	0	0	0	77.97	0	0	13
2014	7	21	14	42	18	31	0	0	0	0	0	0	0	78.21	0	0	12.8
2014	7	21	14	52	18	30	0	0	0	0	0	0	0	78.28	0	0	12.8
2014	7	21	15	2	18	30	0	0	0	0	0	0	0	78.85	0	0	13.2
2014	7	21	15	12	18	31	0	0	0	0	0	0	0	79.05	0	0	13.2
2014	7	21	15	22	18	31	0	0	0	0	0	0	0	79.21	0	0	13.2
2014	7	21	15	32	18	30	0	0	0	0	0	0	0	79.36	0	0	13.2
2014	7	21	15	42	18	31	0	0	0	0	0	0	0	79.5	0	0	13
2014	7	21	15	52	18	30	0	0	0	0	0	0	0	79.41	0	0	12.8
2014	7	21	16	2	18	30	0	0	0	0	0	0	0	79.77	0	0	13
2014	7	21	16	12	18	31	0	0	0	0	0	0	0	79.84	0	0	12.8
2014	7	21	16	22	18	30	0	0	0	0	0	0	0	80.02	0	0	12.8
2014	7	21	16	32	18	30	0	0	0	0	0	0	0	80.17	0	0	12.6
2014	7	21	16	42	18	30	0	0	0	0	0	0	0	80.24	0	0	12.6
2014	7	21	16	52	18	30	0	0	0	0	0	0	0	80.11	0	0	12.4
2014	7	21	17	2	18	30	0	0	0	0	0	0	0	80.26	0	0	12.4
2014	7	21	17	12	18	30	0	0	0	0	0	0	0	80.29	0	0	12.4
2014	7	21	17	22	18	30	0	0	0	0	0	0	0	80.28	0	0	12.2
2014	7	21	17	32	18	30	0	0	0	0	0	0	0	80.2	0	0	12.2
2014	7	21	17	42	18	30	0	0	0	0	0	0	0	79.99	0	0	12.2
2014	7	21	17	52	18	30	0	0	0	0	0	0	0	79.9	0	0	12.2
2014	7	21	18	2	18	31	0	0	0	0	0	0	0	79.77	0	0	12.2
2014	7	21	18	12	18	31	0	0	0	0	0	0	0	79.66	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	18	22	18	30	0	0	0	0	0	0	0	79.56	0	0	12.2
2014	7	21	18	32	18	31	0	0	0	0	0	0	0	79.43	0	0	12.2
2014	7	21	18	42	18	31	0	0	0	0	0	0	0	79.29	0	0	12.2
2014	7	21	18	52	18	30	0	0	0	0	0	0	0	79.14	0	0	12.2
2014	7	21	19	2	18	30	0	0	0	0	0	0	0	78.98	0	0	12.2
2014	7	21	19	12	18	31	0	0	0	0	0	0	0	78.82	0	0	12.2
2014	7	21	19	22	18	30	0	0	0	0	0	0	0	78.66	0	0	12.2
2014	7	21	19	32	18	30	0	0	0	0	0	0	0	78.46	0	0	12.2
2014	7	21	19	42	18	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2014	7	21	19	52	18	31	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	21	20	2	18	31	0	0	0	0	0	0	0	77.92	0	0	12.2
2014	7	21	20	12	18	31	0	0	0	0	0	0	0	77.72	0	0	12.2
2014	7	21	20	22	18	30	0	0	0	0	0	0	0	77.54	0	0	12.2
2014	7	21	20	32	18	31	0	0	0	0	0	0	0	77.36	0	0	12.2
2014	7	21	20	42	18	30	0	0	0	0	0	0	0	77.18	0	0	12.2
2014	7	21	20	52	18	30	0	0	0	0	0	0	0	76.98	0	0	12.2
2014	7	21	21	2	18	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2014	7	21	21	12	18	31	0	0	0	0	0	0	0	76.6	0	0	12.2
2014	7	21	21	22	18	31	0	0	0	0	0	0	0	76.37	0	0	12.2
2014	7	21	21	32	18	31	0	0	0	0	0	0	0	76.15	0	0	12.2
2014	7	21	21	42	18	31	0	0	0	0	0	0	0	75.92	0	0	12.2
2014	7	21	21	52	18	30	0	0	0	0	0	0	0	75.69	0	0	12.2
2014	7	21	22	2	18	30	0	0	0	0	0	0	0	75.45	0	0	12.2
2014	7	21	22	12	18	30	0	0	0	0	0	0	0	75.22	0	0	12.2
2014	7	21	22	22	18	31	0	0	0	0	0	0	0	75	0	0	12
2014	7	21	22	32	18	31	0	0	0	0	0	0	0	74.79	0	0	12.2
2014	7	21	22	42	18	31	0	0	0	0	0	0	0	74.59	0	0	12.2
2014	7	21	22	52	18	31	0	0	0	0	0	0	0	74.41	0	0	12.2
2014	7	21	23	2	18	31	0	0	0	0	0	0	0	74.25	0	0	12.2
2014	7	21	23	12	18	30	0	0	0	0	0	0	0	74.08	0	0	12
2014	7	21	23	22	18	31	0	0	0	0	0	0	0	73.92	0	0	12
2014	7	21	23	32	18	31	0	0	0	0	0	0	0	73.78	0	0	12
2014	7	21	23	42	18	30	0	0	0	0	0	0	0	73.62	0	0	12
2014	7	21	23	52	18	30	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	22	0	2	18	31	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	22	0	12	18	30	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	22	0	22	18	31	0	0	0	0	0	0	0	73.08	0	0	12
2014	7	22	0	32	18	30	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	22	0	42	18	31	0	0	0	0	0	0	0	72.81	0	0	12
2014	7	22	0	52	18	31	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	22	1	2	18	31	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	22	1	12	18	31	0	0	0	0	0	0	0	72.45	0	0	12
2014	7	22	1	22	18	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	22	1	32	18	31	0	0	0	0	0	0	0	72.23	0	0	12
2014	7	22	1	42	18	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	22	1	52	18	31	0	0	0	0	0	0	0	72	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	2	2	18	30	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	22	2	12	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	7	22	2	22	18	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	22	2	32	18	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	7	22	2	42	18	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	22	2	52	18	32	0	0	0	0	0	0	0	71.47	0	0	12
2014	7	22	3	2	18	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	22	3	12	18	30	0	0	0	0	0	0	0	71.33	0	0	12
2014	7	22	3	22	18	31	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	22	3	32	18	31	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	22	3	42	18	31	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	22	3	52	18	31	0	0	0	0	0	0	0	71.01	0	0	12
2014	7	22	4	2	18	30	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	22	4	12	18	31	0	0	0	0	0	0	0	70.84	0	0	12
2014	7	22	4	22	18	31	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	22	4	32	18	31	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	22	4	42	18	31	0	0	0	0	0	0	0	70.65	0	0	12
2014	7	22	4	52	18	31	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	22	5	2	18	31	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	22	5	12	18	31	0	0	0	0	0	0	0	70.39	0	0	12
2014	7	22	5	22	18	31	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	22	5	32	18	31	0	0	0	0	0	0	0	70.23	0	0	12
2014	7	22	5	42	18	31	0	0	0	0	0	0	0	70.14	0	0	12
2014	7	22	5	52	18	32	0	0	0	0	0	0	0	70.07	0	0	12
2014	7	22	6	2	18	31	0	0	0	0	0	0	0	70	0	0	12
2014	7	22	6	12	18	31	0	0	0	0	0	0	0	69.91	0	0	12
2014	7	22	6	22	18	31	0	0	0	0	0	0	0	69.84	0	0	11.8
2014	7	22	6	32	18	31	0	0	0	0	0	0	0	69.76	0	0	12
2014	7	22	6	42	18	31	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	22	6	52	18	31	0	0	0	0	0	0	0	69.6	0	0	12
2014	7	22	7	2	18	31	0	0	0	0	0	0	0	69.66	0	0	12.2
2014	7	22	7	12	18	31	0	0	0	0	0	0	0	69.73	0	0	12.4
2014	7	22	7	22	18	31	0	0	0	0	0	0	0	69.76	0	0	12.4
2014	7	22	7	32	18	31	0	0	0	0	0	0	0	69.75	0	0	12.6
2014	7	22	7	42	18	32	0	0	0	0	0	0	0	69.78	0	0	12.6
2014	7	22	7	52	18	31	0	0	0	0	0	0	0	69.84	0	0	12.8
2014	7	22	8	2	18	31	0	0	0	0	0	0	0	69.94	0	0	13
2014	7	22	8	12	18	32	0	0	0	0	0	0	0	70.07	0	0	13
2014	7	22	8	22	18	30	0	0	0	0	0	0	0	70	0	0	12.8
2014	7	22	8	32	18	31	0	0	0	0	0	0	0	70.2	0	0	13
2014	7	22	8	42	18	31	0	0	0	0	0	0	0	70.27	0	0	13
2014	7	22	8	52	18	31	0	0	0	0	0	0	0	70.38	0	0	13
2014	7	22	9	2	18	31	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	7	22	9	12	18	31	0	0	0	0	0	0	0	70.61	0	0	13.2
2014	7	22	9	22	18	32	0	0	0	0	0	0	0	70.65	0	0	13
2014	7	22	9	32	18	31	0	0	0	0	0	0	0	70.97	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	9	42	18	32	0	0	0	0	0	0	0	71.22	0	0	13.2
2014	7	22	9	52	18	32	0	0	0	0	0	0	0	71.37	0	0	13.2
2014	7	22	10	2	18	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	7	22	10	12	18	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	7	22	10	22	18	32	0	0	0	0	0	0	0	71.89	0	0	13.2
2014	7	22	10	32	18	32	0	0	0	0	0	0	0	72.03	0	0	13.2
2014	7	22	10	42	18	32	0	0	0	0	0	0	0	72.32	0	0	13.4
2014	7	22	10	52	18	31	0	0	0	0	0	0	0	72.63	0	0	13.4
2014	7	22	11	2	18	31	0	0	0	0	0	0	0	72.84	0	0	13.4
2014	7	22	11	12	18	32	0	0	0	0	0	0	0	73.13	0	0	13.4
2014	7	22	11	22	18	31	0	0	0	0	0	0	0	73.36	0	0	13.2
2014	7	22	11	32	18	31	0	0	0	0	0	0	0	73.62	0	0	13.4
2014	7	22	11	42	18	31	0	0	0	0	0	0	0	73.67	0	0	13.4
2014	7	22	11	52	18	31	0	0	0	0	0	0	0	73.08	0	0	13.4
2014	7	22	12	2	18	31	0	0	0	0	0	0	0	73.2	0	0	13.4
2014	7	22	12	12	18	31	0	0	0	0	0	0	0	73.44	0	0	13.4
2014	7	22	12	22	18	32	0	0	0	0	0	0	0	73.72	0	0	13.2
2014	7	22	12	32	18	30	0	0	0	0	0	0	0	74.01	0	0	13.4
2014	7	22	12	42	18	30	0	0	0	0	0	0	0	74.32	0	0	13.4
2014	7	22	12	52	18	31	0	0	0	0	0	0	0	74.66	0	0	13.4
2014	7	22	13	2	18	31	0	0	0	0	0	0	0	75.04	0	0	13.4
2014	7	22	13	12	18	32	0	0	0	0	0	0	0	76.21	0	0	13.4
2014	7	22	13	22	18	30	0	0	0	0	0	0	0	76.73	0	0	13.2
2014	7	22	13	32	18	30	0	0	0	0	0	0	0	77.09	0	0	13.4
2014	7	22	13	42	18	30	0	0	0	0	0	0	0	77.45	0	0	13.2
2014	7	22	13	52	18	31	0	0	0	0	0	0	0	77.74	0	0	13.2
2014	7	22	14	2	18	30	0	0	0	0	0	0	0	78.01	0	0	13.2
2014	7	22	14	12	18	30	0	0	0	0	0	0	0	78.33	0	0	13.2
2014	7	22	14	22	18	30	0	0	0	0	0	0	0	78.57	0	0	13.2
2014	7	22	14	32	18	30	0	0	0	0	0	0	0	78.82	0	0	13.2
2014	7	22	14	42	18	31	0	0	0	0	0	0	0	79.05	0	0	13.2
2014	7	22	14	52	18	31	0	0	0	0	0	0	0	79.29	0	0	13.2
2014	7	22	15	2	18	30	0	0	0	0	0	0	0	79.52	0	0	13.2
2014	7	22	15	12	18	30	0	0	0	0	0	0	0	79.72	0	0	13.2
2014	7	22	15	22	18	31	0	0	0	0	0	0	0	79.9	0	0	13
2014	7	22	15	32	18	31	0	0	0	0	0	0	0	80.02	0	0	13.2
2014	7	22	15	42	18	30	0	0	0	0	0	0	0	80.15	0	0	13
2014	7	22	15	52	18	30	0	0	0	0	0	0	0	80.28	0	0	13
2014	7	22	16	2	18	30	0	0	0	0	0	0	0	80.38	0	0	13
2014	7	22	16	12	18	30	0	0	0	0	0	0	0	80.44	0	0	12.8
2014	7	22	16	22	18	30	0	0	0	0	0	0	0	80.51	0	0	12.6
2014	7	22	16	32	18	30	0	0	0	0	0	0	0	80.53	0	0	12.6
2014	7	22	16	42	18	30	0	0	0	0	0	0	0	80.55	0	0	12.6
2014	7	22	16	52	18	30	0	0	0	0	0	0	0	80.56	0	0	12.4
2014	7	22	17	2	18	30	0	0	0	0	0	0	0	80.53	0	0	12.4
2014	7	22	17	12	18	30	0	0	0	0	0	0	0	80.46	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	17	22	18	30	0	0	0	0	0	0	0	80.42	0	0	12.2
2014	7	22	17	32	18	30	0	0	0	0	0	0	0	80.28	0	0	12.4
2014	7	22	17	42	18	30	0	0	0	0	0	0	0	79.99	0	0	12.2
2014	7	22	17	52	18	30	0	0	0	0	0	0	0	79.88	0	0	12.2
2014	7	22	18	2	18	30	0	0	0	0	0	0	0	79.79	0	0	12.2
2014	7	22	18	12	18	30	0	0	0	0	0	0	0	79.68	0	0	12.2
2014	7	22	18	22	18	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2014	7	22	18	32	18	30	0	0	0	0	0	0	0	79.45	0	0	12.2
2014	7	22	18	42	18	30	0	0	0	0	0	0	0	79.3	0	0	12.2
2014	7	22	18	52	18	31	0	0	0	0	0	0	0	79.16	0	0	12.2
2014	7	22	19	2	18	30	0	0	0	0	0	0	0	79	0	0	12.2
2014	7	22	19	12	18	31	0	0	0	0	0	0	0	78.84	0	0	12.2
2014	7	22	19	22	18	30	0	0	0	0	0	0	0	78.66	0	0	12.2
2014	7	22	19	32	18	30	0	0	0	0	0	0	0	78.46	0	0	12.2
2014	7	22	19	42	18	30	0	0	0	0	0	0	0	78.26	0	0	12.2
2014	7	22	19	52	18	30	0	0	0	0	0	0	0	78.06	0	0	12.2
2014	7	22	20	2	18	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2014	7	22	20	12	18	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2014	7	22	20	22	18	31	0	0	0	0	0	0	0	77.41	0	0	12
2014	7	22	20	32	18	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2014	7	22	20	42	18	31	0	0	0	0	0	0	0	77.02	0	0	12.2
2014	7	22	20	52	18	31	0	0	0	0	0	0	0	76.82	0	0	12.2
2014	7	22	21	2	18	30	0	0	0	0	0	0	0	76.66	0	0	12.2
2014	7	22	21	12	18	31	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	7	22	21	22	18	31	0	0	0	0	0	0	0	76.3	0	0	12
2014	7	22	21	32	18	31	0	0	0	0	0	0	0	76.12	0	0	12.2
2014	7	22	21	42	18	31	0	0	0	0	0	0	0	75.9	0	0	12.2
2014	7	22	21	52	18	30	0	0	0	0	0	0	0	75.72	0	0	12.2
2014	7	22	22	2	18	31	0	0	0	0	0	0	0	75.52	0	0	12.2
2014	7	22	22	12	18	31	0	0	0	0	0	0	0	75.33	0	0	12.2
2014	7	22	22	22	18	30	0	0	0	0	0	0	0	75.11	0	0	12
2014	7	22	22	32	18	30	0	0	0	0	0	0	0	74.93	0	0	12.2
2014	7	22	22	42	18	31	0	0	0	0	0	0	0	74.71	0	0	12.2
2014	7	22	22	52	18	31	0	0	0	0	0	0	0	74.5	0	0	12.2
2014	7	22	23	2	18	31	0	0	0	0	0	0	0	74.28	0	0	12
2014	7	22	23	12	18	31	0	0	0	0	0	0	0	74.05	0	0	12
2014	7	22	23	22	18	31	0	0	0	0	0	0	0	73.81	0	0	12
2014	7	22	23	32	18	31	0	0	0	0	0	0	0	73.58	0	0	12
2014	7	22	23	42	18	31	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	22	23	52	18	31	0	0	0	0	0	0	0	73.11	0	0	12
2014	7	23	0	2	18	30	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	23	0	12	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	23	0	22	18	31	0	0	0	0	0	0	0	72.43	0	0	12
2014	7	23	0	32	18	31	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	23	0	42	18	31	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	23	0	52	18	31	0	0	0	0	0	0	0	71.78	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	1	2	18	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	23	1	12	18	31	0	0	0	0	0	0	0	71.37	0	0	12
2014	7	23	1	22	18	31	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	23	1	32	18	31	0	0	0	0	0	0	0	70.99	0	0	12
2014	7	23	1	42	18	32	0	0	0	0	0	0	0	70.81	0	0	12
2014	7	23	1	52	18	31	0	0	0	0	0	0	0	70.63	0	0	12
2014	7	23	2	2	18	31	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	23	2	12	18	31	0	0	0	0	0	0	0	70.32	0	0	12
2014	7	23	2	22	18	31	0	0	0	0	0	0	0	70.16	0	0	12
2014	7	23	2	32	18	31	0	0	0	0	0	0	0	70	0	0	12
2014	7	23	2	42	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	23	2	52	18	31	0	0	0	0	0	0	0	69.73	0	0	12
2014	7	23	3	2	18	31	0	0	0	0	0	0	0	69.58	0	0	12
2014	7	23	3	12	18	31	0	0	0	0	0	0	0	69.46	0	0	12
2014	7	23	3	22	18	31	0	0	0	0	0	0	0	69.31	0	0	12
2014	7	23	3	32	18	32	0	0	0	0	0	0	0	69.19	0	0	12
2014	7	23	3	42	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	7	23	3	52	18	31	0	0	0	0	0	0	0	68.95	0	0	12
2014	7	23	4	2	18	32	0	0	0	0	0	0	0	68.85	0	0	12
2014	7	23	4	12	18	32	0	0	0	0	0	0	0	68.72	0	0	12
2014	7	23	4	22	18	32	0	0	0	0	0	0	0	68.61	0	0	12
2014	7	23	4	32	18	32	0	0	0	0	0	0	0	68.49	0	0	12
2014	7	23	4	42	18	32	0	0	0	0	0	0	0	68.38	0	0	12
2014	7	23	4	52	18	31	0	0	0	0	0	0	0	68.27	0	0	12
2014	7	23	5	2	18	31	0	0	0	0	0	0	0	68.14	0	0	12
2014	7	23	5	12	18	31	0	0	0	0	0	0	0	68.05	0	0	12
2014	7	23	5	22	18	32	0	0	0	0	0	0	0	67.95	0	0	11.8
2014	7	23	5	32	18	32	0	0	0	0	0	0	0	67.84	0	0	12
2014	7	23	5	42	18	32	0	0	0	0	0	0	0	67.73	0	0	12
2014	7	23	5	52	18	33	0	0	0	0	0	0	0	67.64	0	0	12
2014	7	23	6	2	18	32	0	0	0	0	0	0	0	67.51	0	0	12
2014	7	23	6	12	18	31	0	0	0	0	0	0	0	67.44	0	0	12
2014	7	23	6	22	18	32	0	0	0	0	0	0	0	67.33	0	0	11.8
2014	7	23	6	32	18	31	0	0	0	0	0	0	0	67.24	0	0	12
2014	7	23	6	42	18	32	0	0	0	0	0	0	0	67.15	0	0	12
2014	7	23	6	52	18	32	0	0	0	0	0	0	0	67.06	0	0	12
2014	7	23	7	2	18	32	0	0	0	0	0	0	0	67.19	0	0	12.2
2014	7	23	7	12	18	31	0	0	0	0	0	0	0	67.24	0	0	12.4
2014	7	23	7	22	18	32	0	0	0	0	0	0	0	67.26	0	0	12.2
2014	7	23	7	32	18	32	0	0	0	0	0	0	0	67.33	0	0	12.6
2014	7	23	7	42	18	32	0	0	0	0	0	0	0	67.33	0	0	12.8
2014	7	23	7	52	18	32	0	0	0	0	0	0	0	67.28	0	0	12.8
2014	7	23	8	2	18	33	0	0	0	0	0	0	0	67.44	0	0	13
2014	7	23	8	12	18	32	0	0	0	0	0	0	0	67.59	0	0	13
2014	7	23	8	22	18	32	0	0	0	0	0	0	0	67.77	0	0	13.2
2014	7	23	8	32	18	32	0	0	0	0	0	0	0	67.95	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	8	42	18	32	0	0	0	0	0	0	0	68.07	0	0	13.2
2014	7	23	8	52	18	32	0	0	0	0	0	0	0	68.22	0	0	13.4
2014	7	23	9	2	18	32	0	0	0	0	0	0	0	68.34	0	0	13.4
2014	7	23	9	12	18	33	0	0	0	0	0	0	0	68.47	0	0	13.4
2014	7	23	9	22	18	32	0	0	0	0	0	0	0	68.74	0	0	13.4
2014	7	23	9	32	18	32	0	0	0	0	0	0	0	68.9	0	0	13.4
2014	7	23	9	42	18	32	0	0	0	0	0	0	0	69.01	0	0	13.4
2014	7	23	9	52	18	31	0	0	0	0	0	0	0	69.24	0	0	13.4
2014	7	23	10	2	18	32	0	0	0	0	0	0	0	68.94	0	0	13.4
2014	7	23	10	12	18	32	0	0	0	0	0	0	0	69.4	0	0	13.4
2014	7	23	10	22	18	31	0	0	0	0	0	0	0	69.57	0	0	13.4
2014	7	23	10	32	18	32	0	0	0	0	0	0	0	69.73	0	0	13.4
2014	7	23	10	42	18	32	0	0	0	0	0	0	0	70.11	0	0	13.4
2014	7	23	10	52	18	31	0	0	0	0	0	0	0	70.32	0	0	13.4
2014	7	23	11	2	18	32	0	0	0	0	0	0	0	70.59	0	0	13.4
2014	7	23	11	12	18	31	0	0	0	0	0	0	0	70.86	0	0	13.4
2014	7	23	11	22	18	32	0	0	0	0	0	0	0	71.19	0	0	13.2
2014	7	23	11	32	18	31	0	0	0	0	0	0	0	71.4	0	0	13.4
2014	7	23	11	42	18	31	0	0	0	0	0	0	0	71.38	0	0	13.4
2014	7	23	11	52	18	31	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	7	23	12	2	18	32	0	0	0	0	0	0	0	71.33	0	0	13.4
2014	7	23	12	12	18	31	0	0	0	0	0	0	0	71.64	0	0	13.4
2014	7	23	12	22	18	31	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	23	12	32	18	31	0	0	0	0	0	0	0	72.27	0	0	13.4
2014	7	23	12	42	18	31	0	0	0	0	0	0	0	72.61	0	0	13.4
2014	7	23	12	52	18	30	0	0	0	0	0	0	0	73	0	0	13.4
2014	7	23	13	2	18	31	0	0	0	0	0	0	0	73.44	0	0	13.4
2014	7	23	13	12	18	31	0	0	0	0	0	0	0	74.39	0	0	13.4
2014	7	23	13	22	18	31	0	0	0	0	0	0	0	74.89	0	0	13.2
2014	7	23	13	32	18	31	0	0	0	0	0	0	0	75.27	0	0	13.2
2014	7	23	13	42	18	31	0	0	0	0	0	0	0	75.7	0	0	13.2
2014	7	23	13	52	18	30	0	0	0	0	0	0	0	76.06	0	0	13.2
2014	7	23	14	2	18	31	0	0	0	0	0	0	0	76.46	0	0	13.2
2014	7	23	14	12	18	31	0	0	0	0	0	0	0	76.84	0	0	13.2
2014	7	23	14	22	18	31	0	0	0	0	0	0	0	77.18	0	0	13.2
2014	7	23	14	32	18	31	0	0	0	0	0	0	0	77.52	0	0	13.2
2014	7	23	14	42	18	31	0	0	0	0	0	0	0	77.88	0	0	13.2
2014	7	23	14	52	18	31	0	0	0	0	0	0	0	78.21	0	0	13.2
2014	7	23	15	2	18	31	0	0	0	0	0	0	0	78.51	0	0	13.2
2014	7	23	15	12	18	31	0	0	0	0	0	0	0	78.84	0	0	13.2
2014	7	23	15	22	18	30	0	0	0	0	0	0	0	79.12	0	0	13.2
2014	7	23	15	32	18	30	0	0	0	0	0	0	0	79.38	0	0	13.2
2014	7	23	15	42	18	30	0	0	0	0	0	0	0	79.63	0	0	13
2014	7	23	15	52	18	30	0	0	0	0	0	0	0	79.83	0	0	13
2014	7	23	16	2	18	30	0	0	0	0	0	0	0	80.08	0	0	13
2014	7	23	16	12	18	31	0	0	0	0	0	0	0	80.31	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	16	22	18	30	0	0	0	0	0	0	0	80.44	0	0	12.6
2014	7	23	16	32	18	31	0	0	0	0	0	0	0	80.64	0	0	12.6
2014	7	23	16	42	18	30	0	0	0	0	0	0	0	80.76	0	0	12.6
2014	7	23	16	52	18	30	0	0	0	0	0	0	0	80.91	0	0	12.6
2014	7	23	17	2	18	30	0	0	0	0	0	0	0	81.01	0	0	12.4
2014	7	23	17	12	18	30	0	0	0	0	0	0	0	81.1	0	0	12.4
2014	7	23	17	22	18	30	0	0	0	0	0	0	0	81.18	0	0	12.2
2014	7	23	17	32	18	31	0	0	0	0	0	0	0	81.19	0	0	12.4
2014	7	23	17	42	18	30	0	0	0	0	0	0	0	81.07	0	0	12.4
2014	7	23	17	52	18	30	0	0	0	0	0	0	0	81.03	0	0	12.2
2014	7	23	18	2	18	30	0	0	0	0	0	0	0	81	0	0	12.2
2014	7	23	18	12	18	30	0	0	0	0	0	0	0	80.92	0	0	12.2
2014	7	23	18	22	18	30	0	0	0	0	0	0	0	80.85	0	0	12.2
2014	7	23	18	32	18	30	0	0	0	0	0	0	0	80.74	0	0	12.2
2014	7	23	18	42	18	30	0	0	0	0	0	0	0	80.62	0	0	12.2
2014	7	23	18	52	18	30	0	0	0	0	0	0	0	80.51	0	0	12.2
2014	7	23	19	2	18	29	0	0	0	0	0	0	0	80.33	0	0	12.2
2014	7	23	19	12	18	30	0	0	0	0	0	0	0	80.17	0	0	12.2
2014	7	23	19	22	18	30	0	0	0	0	0	0	0	80.06	0	0	12.2
2014	7	23	19	32	18	30	0	0	0	0	0	0	0	79.88	0	0	12.2
2014	7	23	19	42	18	29	0	0	0	0	0	0	0	79.74	0	0	12.2
2014	7	23	19	52	18	31	0	0	0	0	0	0	0	79.57	0	0	12.2
2014	7	23	20	2	18	30	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	23	20	12	18	30	0	0	0	0	0	0	0	79.23	0	0	12.2
2014	7	23	20	22	18	30	0	0	0	0	0	0	0	79.05	0	0	12
2014	7	23	20	32	18	30	0	0	0	0	0	0	0	78.87	0	0	12.2
2014	7	23	20	42	18	30	0	0	0	0	0	0	0	78.69	0	0	12.2
2014	7	23	20	52	18	30	0	0	0	0	0	0	0	78.49	0	0	12.2
2014	7	23	21	2	18	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2014	7	23	21	12	18	30	0	0	0	0	0	0	0	78.1	0	0	12.2
2014	7	23	21	22	18	31	0	0	0	0	0	0	0	77.88	0	0	12.2
2014	7	23	21	32	18	31	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	23	21	42	18	30	0	0	0	0	0	0	0	77.45	0	0	12.2
2014	7	23	21	52	18	31	0	0	0	0	0	0	0	77.25	0	0	12.2
2014	7	23	22	2	18	30	0	0	0	0	0	0	0	77.07	0	0	12.2
2014	7	23	22	12	18	30	0	0	0	0	0	0	0	76.87	0	0	12.2
2014	7	23	22	22	18	31	0	0	0	0	0	0	0	76.71	0	0	12.2
2014	7	23	22	32	18	30	0	0	0	0	0	0	0	76.55	0	0	12.2
2014	7	23	22	42	18	31	0	0	0	0	0	0	0	76.41	0	0	12.2
2014	7	23	22	52	18	31	0	0	0	0	0	0	0	76.23	0	0	12.2
2014	7	23	23	2	18	30	0	0	0	0	0	0	0	76.06	0	0	12.2
2014	7	23	23	12	18	30	0	0	0	0	0	0	0	75.9	0	0	12.2
2014	7	23	23	22	18	31	0	0	0	0	0	0	0	75.76	0	0	12
2014	7	23	23	32	18	30	0	0	0	0	0	0	0	75.61	0	0	12
2014	7	23	23	42	18	31	0	0	0	0	0	0	0	75.43	0	0	12
2014	7	23	23	52	18	31	0	0	0	0	0	0	0	75.27	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	0	2	18	31	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	24	0	12	18	31	0	0	0	0	0	0	0	74.93	0	0	12
2014	7	24	0	22	18	31	0	0	0	0	0	0	0	74.75	0	0	12
2014	7	24	0	32	18	31	0	0	0	0	0	0	0	74.55	0	0	12
2014	7	24	0	42	18	31	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	24	0	52	18	31	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	24	1	2	18	31	0	0	0	0	0	0	0	74.07	0	0	12
2014	7	24	1	12	18	31	0	0	0	0	0	0	0	73.9	0	0	12
2014	7	24	1	22	18	31	0	0	0	0	0	0	0	73.76	0	0	12
2014	7	24	1	32	18	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	24	1	42	18	31	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	24	1	52	18	31	0	0	0	0	0	0	0	73.29	0	0	12
2014	7	24	2	2	18	31	0	0	0	0	0	0	0	73.13	0	0	12
2014	7	24	2	12	18	30	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	24	2	22	18	31	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	24	2	32	18	31	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	24	2	42	18	31	0	0	0	0	0	0	0	72.52	0	0	12
2014	7	24	2	52	18	31	0	0	0	0	0	0	0	72.37	0	0	12
2014	7	24	3	2	18	31	0	0	0	0	0	0	0	72.23	0	0	12
2014	7	24	3	12	18	31	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	24	3	22	18	31	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	24	3	32	18	30	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	24	3	42	18	31	0	0	0	0	0	0	0	71.65	0	0	12
2014	7	24	3	52	18	32	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	24	4	2	18	31	0	0	0	0	0	0	0	71.35	0	0	12
2014	7	24	4	12	18	31	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	24	4	22	18	32	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	24	4	32	18	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	24	4	42	18	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	24	4	52	18	31	0	0	0	0	0	0	0	70.61	0	0	12
2014	7	24	5	2	18	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	7	24	5	12	18	31	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	24	5	22	18	32	0	0	0	0	0	0	0	70.14	0	0	12
2014	7	24	5	32	18	31	0	0	0	0	0	0	0	69.98	0	0	12
2014	7	24	5	42	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	7	24	5	52	18	31	0	0	0	0	0	0	0	69.64	0	0	12
2014	7	24	6	2	18	31	0	0	0	0	0	0	0	69.49	0	0	12
2014	7	24	6	12	18	31	0	0	0	0	0	0	0	69.31	0	0	12
2014	7	24	6	22	18	32	0	0	0	0	0	0	0	69.15	0	0	12
2014	7	24	6	32	18	31	0	0	0	0	0	0	0	68.99	0	0	12
2014	7	24	6	42	18	32	0	0	0	0	0	0	0	68.81	0	0	12
2014	7	24	6	52	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	7	24	7	2	18	32	0	0	0	0	0	0	0	68.58	0	0	12.2
2014	7	24	7	12	18	31	0	0	0	0	0	0	0	68.49	0	0	12.4
2014	7	24	7	22	18	31	0	0	0	0	0	0	0	68.4	0	0	12.4
2014	7	24	7	32	18	32	0	0	0	0	0	0	0	68.31	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	7	42	18	32	0	0	0	0	0	0	0	68.23	0	0	12.8
2014	7	24	7	52	18	32	0	0	0	0	0	0	0	68.09	0	0	12.8
2014	7	24	8	2	18	32	0	0	0	0	0	0	0	68.14	0	0	13
2014	7	24	8	12	18	31	0	0	0	0	0	0	0	68.14	0	0	13
2014	7	24	8	22	18	31	0	0	0	0	0	0	0	68.2	0	0	13
2014	7	24	8	32	18	32	0	0	0	0	0	0	0	68.22	0	0	13.2
2014	7	24	8	42	18	31	0	0	0	0	0	0	0	68.25	0	0	13.2
2014	7	24	8	52	18	31	0	0	0	0	0	0	0	68.31	0	0	13.2
2014	7	24	9	2	18	32	0	0	0	0	0	0	0	68.4	0	0	13.4
2014	7	24	9	12	18	33	0	0	0	0	0	0	0	68.5	0	0	13.4
2014	7	24	9	22	18	32	0	0	0	0	0	0	0	68.59	0	0	13.2
2014	7	24	9	32	18	32	0	0	0	0	0	0	0	68.68	0	0	13.4
2014	7	24	9	42	18	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2014	7	24	9	52	18	32	0	0	0	0	0	0	0	68.99	0	0	13.2
2014	7	24	10	2	18	31	0	0	0	0	0	0	0	69.19	0	0	13.2
2014	7	24	10	12	18	32	0	0	0	0	0	0	0	69.37	0	0	13.2
2014	7	24	10	22	18	31	0	0	0	0	0	0	0	69.6	0	0	13.2
2014	7	24	10	32	18	31	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	24	10	42	18	32	0	0	0	0	0	0	0	70.09	0	0	13.2
2014	7	24	10	52	18	32	0	0	0	0	0	0	0	70.36	0	0	13.2
2014	7	24	11	2	18	31	0	0	0	0	0	0	0	70.65	0	0	13.2
2014	7	24	11	12	18	32	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	24	11	22	18	32	0	0	0	0	0	0	0	71.28	0	0	13.2
2014	7	24	11	32	18	31	0	0	0	0	0	0	0	71.62	0	0	13.2
2014	7	24	11	42	18	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	7	24	11	52	18	31	0	0	0	0	0	0	0	71.55	0	0	13.2
2014	7	24	12	2	18	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	7	24	12	12	18	32	0	0	0	0	0	0	0	72.14	0	0	13.2
2014	7	24	12	22	18	30	0	0	0	0	0	0	0	72.5	0	0	13.2
2014	7	24	12	32	18	30	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	7	24	12	42	18	31	0	0	0	0	0	0	0	73.31	0	0	13.2
2014	7	24	12	52	18	30	0	0	0	0	0	0	0	73.71	0	0	13.2
2014	7	24	13	2	18	31	0	0	0	0	0	0	0	74.26	0	0	13.2
2014	7	24	13	12	18	31	0	0	0	0	0	0	0	75.2	0	0	13.2
2014	7	24	13	22	18	31	0	0	0	0	0	0	0	75.76	0	0	13.2
2014	7	24	13	32	18	30	0	0	0	0	0	0	0	76.17	0	0	13.2
2014	7	24	13	42	18	31	0	0	0	0	0	0	0	76.55	0	0	13.2
2014	7	24	13	52	18	31	0	0	0	0	0	0	0	76.89	0	0	13.2
2014	7	24	14	2	18	31	0	0	0	0	0	0	0	77.31	0	0	13.2
2014	7	24	14	12	18	31	0	0	0	0	0	0	0	77.65	0	0	13.2
2014	7	24	14	22	18	30	0	0	0	0	0	0	0	77.97	0	0	13.2
2014	7	24	14	32	18	30	0	0	0	0	0	0	0	78.26	0	0	13.2
2014	7	24	14	42	18	30	0	0	0	0	0	0	0	78.55	0	0	13.2
2014	7	24	14	52	18	31	0	0	0	0	0	0	0	78.8	0	0	13.2
2014	7	24	15	2	18	31	0	0	0	0	0	0	0	79.02	0	0	13.2
2014	7	24	15	12	18	30	0	0	0	0	0	0	0	79.2	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	15	22	18	30	0	0	0	0	0	0	0	79.41	0	0	13
2014	7	24	15	32	18	30	0	0	0	0	0	0	0	79.59	0	0	13.2
2014	7	24	15	42	18	30	0	0	0	0	0	0	0	79.77	0	0	13
2014	7	24	15	52	18	30	0	0	0	0	0	0	0	79.92	0	0	13
2014	7	24	16	2	18	30	0	0	0	0	0	0	0	80.04	0	0	13
2014	7	24	16	12	18	30	0	0	0	0	0	0	0	80.17	0	0	12.8
2014	7	24	16	22	18	30	0	0	0	0	0	0	0	80.26	0	0	12.6
2014	7	24	16	32	18	30	0	0	0	0	0	0	0	80.37	0	0	12.6
2014	7	24	16	42	18	30	0	0	0	0	0	0	0	80.44	0	0	12.6
2014	7	24	16	52	18	30	0	0	0	0	0	0	0	80.51	0	0	12.4
2014	7	24	17	2	18	30	0	0	0	0	0	0	0	80.58	0	0	12.4
2014	7	24	17	12	18	30	0	0	0	0	0	0	0	80.62	0	0	12.4
2014	7	24	17	22	18	30	0	0	0	0	0	0	0	80.65	0	0	12.2
2014	7	24	17	32	18	30	0	0	0	0	0	0	0	80.6	0	0	12.4
2014	7	24	17	42	18	29	0	0	0	0	0	0	0	80.38	0	0	12.2
2014	7	24	17	52	18	30	0	0	0	0	0	0	0	80.31	0	0	12.2
2014	7	24	18	2	18	30	0	0	0	0	0	0	0	80.2	0	0	12.2
2014	7	24	18	12	18	30	0	0	0	0	0	0	0	80.11	0	0	12.2
2014	7	24	18	22	18	31	0	0	0	0	0	0	0	80.04	0	0	12.2
2014	7	24	18	32	18	30	0	0	0	0	0	0	0	79.93	0	0	12.2
2014	7	24	18	42	18	31	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	24	18	52	18	30	0	0	0	0	0	0	0	79.7	0	0	12.2
2014	7	24	19	2	18	30	0	0	0	0	0	0	0	79.56	0	0	12.2
2014	7	24	19	12	18	30	0	0	0	0	0	0	0	79.41	0	0	12.2
2014	7	24	19	22	18	30	0	0	0	0	0	0	0	79.27	0	0	12.2
2014	7	24	19	32	18	30	0	0	0	0	0	0	0	79.11	0	0	12.2
2014	7	24	19	42	18	30	0	0	0	0	0	0	0	78.96	0	0	12.2
2014	7	24	19	52	18	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2014	7	24	20	2	18	31	0	0	0	0	0	0	0	78.66	0	0	12.2
2014	7	24	20	12	18	31	0	0	0	0	0	0	0	78.51	0	0	12.2
2014	7	24	20	22	18	31	0	0	0	0	0	0	0	78.37	0	0	12.2
2014	7	24	20	32	18	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2014	7	24	20	42	18	31	0	0	0	0	0	0	0	78.08	0	0	12.2
2014	7	24	20	52	18	30	0	0	0	0	0	0	0	77.9	0	0	12.2
2014	7	24	21	2	18	30	0	0	0	0	0	0	0	77.72	0	0	12.2
2014	7	24	21	12	18	31	0	0	0	0	0	0	0	77.56	0	0	12.2
2014	7	24	21	22	18	30	0	0	0	0	0	0	0	77.38	0	0	12
2014	7	24	21	32	18	30	0	0	0	0	0	0	0	77.18	0	0	12.2
2014	7	24	21	42	18	31	0	0	0	0	0	0	0	77	0	0	12.2
2014	7	24	21	52	18	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2014	7	24	22	2	18	31	0	0	0	0	0	0	0	76.6	0	0	12.2
2014	7	24	22	12	18	31	0	0	0	0	0	0	0	76.41	0	0	12.2
2014	7	24	22	22	18	30	0	0	0	0	0	0	0	76.19	0	0	12
2014	7	24	22	32	18	31	0	0	0	0	0	0	0	75.99	0	0	12.2
2014	7	24	22	42	18	31	0	0	0	0	0	0	0	75.79	0	0	12.2
2014	7	24	22	52	18	31	0	0	0	0	0	0	0	75.61	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	23	2	18	31	0	0	0	0	0	0	0	75.45	0	0	12.2
2014	7	24	23	12	18	31	0	0	0	0	0	0	0	75.27	0	0	12
2014	7	24	23	22	18	31	0	0	0	0	0	0	0	75.11	0	0	12
2014	7	24	23	32	18	30	0	0	0	0	0	0	0	74.93	0	0	12
2014	7	24	23	42	18	30	0	0	0	0	0	0	0	74.79	0	0	12
2014	7	24	23	52	18	31	0	0	0	0	0	0	0	74.62	0	0	12
2014	7	25	0	2	18	31	0	0	0	0	0	0	0	74.46	0	0	12
2014	7	25	0	12	18	31	0	0	0	0	0	0	0	74.32	0	0	12
2014	7	25	0	22	18	31	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	25	0	32	18	31	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	25	0	42	18	31	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	25	0	52	18	31	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	25	1	2	18	31	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	25	1	12	18	32	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	25	1	22	18	31	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	25	1	32	18	30	0	0	0	0	0	0	0	73.17	0	0	12
2014	7	25	1	42	18	31	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	25	1	52	18	31	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	25	2	2	18	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	25	2	12	18	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	25	2	22	18	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	25	2	32	18	31	0	0	0	0	0	0	0	72.3	0	0	12
2014	7	25	2	42	18	31	0	0	0	0	0	0	0	72.16	0	0	12
2014	7	25	2	52	18	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	25	3	2	18	31	0	0	0	0	0	0	0	71.87	0	0	12
2014	7	25	3	12	18	31	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	25	3	22	18	32	0	0	0	0	0	0	0	71.58	0	0	12
2014	7	25	3	32	18	31	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	25	3	42	18	31	0	0	0	0	0	0	0	71.28	0	0	12
2014	7	25	3	52	18	31	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	25	4	2	18	31	0	0	0	0	0	0	0	70.99	0	0	12
2014	7	25	4	12	18	30	0	0	0	0	0	0	0	70.83	0	0	12
2014	7	25	4	22	18	31	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	25	4	32	18	31	0	0	0	0	0	0	0	70.54	0	0	12
2014	7	25	4	42	18	31	0	0	0	0	0	0	0	70.39	0	0	12
2014	7	25	4	52	18	31	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	25	5	2	18	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	7	25	5	12	18	31	0	0	0	0	0	0	0	69.96	0	0	12
2014	7	25	5	22	18	31	0	0	0	0	0	0	0	69.84	0	0	11.8
2014	7	25	5	32	18	31	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	25	5	42	18	31	0	0	0	0	0	0	0	69.57	0	0	12
2014	7	25	5	52	18	32	0	0	0	0	0	0	0	69.44	0	0	12
2014	7	25	6	2	18	32	0	0	0	0	0	0	0	69.3	0	0	12
2014	7	25	6	12	18	32	0	0	0	0	0	0	0	69.15	0	0	12
2014	7	25	6	22	18	32	0	0	0	0	0	0	0	69.03	0	0	11.8
2014	7	25	6	32	18	32	0	0	0	0	0	0	0	68.9	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	6	42	18	31	0	0	0	0	0	0	0	68.76	0	0	12
2014	7	25	6	52	18	31	0	0	0	0	0	0	0	68.63	0	0	12
2014	7	25	7	2	18	32	0	0	0	0	0	0	0	68.63	0	0	12.2
2014	7	25	7	12	18	31	0	0	0	0	0	0	0	68.58	0	0	12.4
2014	7	25	7	22	18	32	0	0	0	0	0	0	0	68.5	0	0	12.4
2014	7	25	7	32	18	32	0	0	0	0	0	0	0	68.5	0	0	12.6
2014	7	25	7	42	18	32	0	0	0	0	0	0	0	68.56	0	0	12.8
2014	7	25	7	52	18	31	0	0	0	0	0	0	0	68.27	0	0	12.8
2014	7	25	8	2	18	31	0	0	0	0	0	0	0	68.5	0	0	13
2014	7	25	8	12	18	31	0	0	0	0	0	0	0	68.58	0	0	13
2014	7	25	8	22	18	31	0	0	0	0	0	0	0	68.67	0	0	13
2014	7	25	8	32	18	32	0	0	0	0	0	0	0	68.72	0	0	13.2
2014	7	25	8	42	18	31	0	0	0	0	0	0	0	68.83	0	0	13.2
2014	7	25	8	52	18	31	0	0	0	0	0	0	0	68.9	0	0	13.4
2014	7	25	9	2	18	31	0	0	0	0	0	0	0	69.01	0	0	13.4
2014	7	25	9	12	18	31	0	0	0	0	0	0	0	69.17	0	0	13.4
2014	7	25	9	22	18	32	0	0	0	0	0	0	0	69.28	0	0	13.2
2014	7	25	9	32	18	32	0	0	0	0	0	0	0	69.4	0	0	13.2
2014	7	25	9	42	18	31	0	0	0	0	0	0	0	69.58	0	0	13.2
2014	7	25	9	52	18	32	0	0	0	0	0	0	0	69.73	0	0	13.2
2014	7	25	10	2	18	31	0	0	0	0	0	0	0	69.91	0	0	13.2
2014	7	25	10	12	18	31	0	0	0	0	0	0	0	70.16	0	0	13.2
2014	7	25	10	22	18	32	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	7	25	10	32	18	31	0	0	0	0	0	0	0	70.47	0	0	13.2
2014	7	25	10	42	18	31	0	0	0	0	0	0	0	70.56	0	0	13.2
2014	7	25	10	52	18	31	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	7	25	11	2	18	31	0	0	0	0	0	0	0	71.26	0	0	13.2
2014	7	25	11	12	18	31	0	0	0	0	0	0	0	71.64	0	0	13.2
2014	7	25	11	22	18	31	0	0	0	0	0	0	0	71.85	0	0	13.2
2014	7	25	11	32	18	31	0	0	0	0	0	0	0	72.12	0	0	13.2
2014	7	25	11	42	18	31	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	25	11	52	18	31	0	0	0	0	0	0	0	71.85	0	0	13.2
2014	7	25	12	2	18	31	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	25	12	12	18	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2014	7	25	12	22	18	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2014	7	25	12	32	18	31	0	0	0	0	0	0	0	73.13	0	0	13.2
2014	7	25	12	42	18	32	0	0	0	0	0	0	0	73.51	0	0	13.2
2014	7	25	12	52	18	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2014	7	25	13	2	18	31	0	0	0	0	0	0	0	74.62	0	0	13.2
2014	7	25	13	12	18	31	0	0	0	0	0	0	0	75.51	0	0	13.2
2014	7	25	13	22	18	31	0	0	0	0	0	0	0	76.05	0	0	13.2
2014	7	25	13	32	18	30	0	0	0	0	0	0	0	76.46	0	0	13.2
2014	7	25	13	42	18	31	0	0	0	0	0	0	0	76.87	0	0	13.2
2014	7	25	13	52	18	30	0	0	0	0	0	0	0	77.2	0	0	13.2
2014	7	25	14	2	18	30	0	0	0	0	0	0	0	77.61	0	0	13.2
2014	7	25	14	12	18	31	0	0	0	0	0	0	0	77.92	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	14	22	18	31	0	0	0	0	0	0	0	78.26	0	0	13
2014	7	25	14	32	18	30	0	0	0	0	0	0	0	78.55	0	0	13.2
2014	7	25	14	42	18	31	0	0	0	0	0	0	0	78.84	0	0	13.2
2014	7	25	14	52	18	30	0	0	0	0	0	0	0	79.12	0	0	13.2
2014	7	25	15	2	18	31	0	0	0	0	0	0	0	79.43	0	0	13.2
2014	7	25	15	12	18	30	0	0	0	0	0	0	0	79.68	0	0	13.2
2014	7	25	15	22	18	30	0	0	0	0	0	0	0	79.9	0	0	13
2014	7	25	15	32	18	30	0	0	0	0	0	0	0	80.13	0	0	13.2
2014	7	25	15	42	18	30	0	0	0	0	0	0	0	80.28	0	0	13
2014	7	25	15	52	18	30	0	0	0	0	0	0	0	80.4	0	0	13
2014	7	25	16	2	18	30	0	0	0	0	0	0	0	80.55	0	0	12.8
2014	7	25	16	12	18	30	0	0	0	0	0	0	0	80.73	0	0	12.8
2014	7	25	16	22	18	30	0	0	0	0	0	0	0	80.85	0	0	12.6
2014	7	25	16	32	18	31	0	0	0	0	0	0	0	80.94	0	0	12.6
2014	7	25	16	42	18	30	0	0	0	0	0	0	0	81.03	0	0	12.6
2014	7	25	16	52	18	30	0	0	0	0	0	0	0	81.05	0	0	12.6
2014	7	25	17	2	18	30	0	0	0	0	0	0	0	81.03	0	0	12.4
2014	7	25	17	12	18	30	0	0	0	0	0	0	0	81	0	0	12.4
2014	7	25	17	22	18	31	0	0	0	0	0	0	0	80.96	0	0	12.2
2014	7	25	17	32	18	30	0	0	0	0	0	0	0	80.82	0	0	12.4
2014	7	25	17	42	18	30	0	0	0	0	0	0	0	80.6	0	0	12.4
2014	7	25	17	52	18	30	0	0	0	0	0	0	0	80.47	0	0	12.4
2014	7	25	18	2	18	30	0	0	0	0	0	0	0	80.35	0	0	12.2
2014	7	25	18	12	18	30	0	0	0	0	0	0	0	80.26	0	0	12.2
2014	7	25	18	22	18	31	0	0	0	0	0	0	0	80.19	0	0	12.2
2014	7	25	18	32	18	30	0	0	0	0	0	0	0	80.13	0	0	12.2
2014	7	25	18	42	18	30	0	0	0	0	0	0	0	80.02	0	0	12.2
2014	7	25	18	52	18	30	0	0	0	0	0	0	0	79.93	0	0	12.2
2014	7	25	19	2	18	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2014	7	25	19	12	18	30	0	0	0	0	0	0	0	79.68	0	0	12.2
2014	7	25	19	22	18	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2014	7	25	19	32	18	30	0	0	0	0	0	0	0	79.38	0	0	12.2
2014	7	25	19	42	18	31	0	0	0	0	0	0	0	79.18	0	0	12.2
2014	7	25	19	52	18	31	0	0	0	0	0	0	0	78.96	0	0	12.2
2014	7	25	20	2	18	30	0	0	0	0	0	0	0	78.76	0	0	12.2
2014	7	25	20	12	18	31	0	0	0	0	0	0	0	78.57	0	0	12.2
2014	7	25	20	22	18	31	0	0	0	0	0	0	0	78.37	0	0	12
2014	7	25	20	32	18	30	0	0	0	0	0	0	0	78.19	0	0	12.2
2014	7	25	20	42	18	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2014	7	25	20	52	18	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2014	7	25	21	2	18	31	0	0	0	0	0	0	0	77.65	0	0	12.2
2014	7	25	21	12	18	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2014	7	25	21	22	18	30	0	0	0	0	0	0	0	77.36	0	0	12.2
2014	7	25	21	32	18	31	0	0	0	0	0	0	0	77.18	0	0	12.2
2014	7	25	21	42	18	31	0	0	0	0	0	0	0	77.02	0	0	12.2
2014	7	25	21	52	18	31	0	0	0	0	0	0	0	76.84	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	22	2	18	31	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	25	22	12	18	30	0	0	0	0	0	0	0	76.44	0	0	12.2
2014	7	25	22	22	18	31	0	0	0	0	0	0	0	76.26	0	0	12
2014	7	25	22	32	18	31	0	0	0	0	0	0	0	76.06	0	0	12.2
2014	7	25	22	42	18	30	0	0	0	0	0	0	0	75.85	0	0	12.2
2014	7	25	22	52	18	30	0	0	0	0	0	0	0	75.6	0	0	12.2
2014	7	25	23	2	18	30	0	0	0	0	0	0	0	75.4	0	0	12.2
2014	7	25	23	12	18	31	0	0	0	0	0	0	0	75.16	0	0	12.2
2014	7	25	23	22	18	31	0	0	0	0	0	0	0	74.95	0	0	12
2014	7	25	23	32	18	31	0	0	0	0	0	0	0	74.71	0	0	12
2014	7	25	23	42	18	31	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	25	23	52	18	31	0	0	0	0	0	0	0	74.26	0	0	12
2014	7	26	0	2	18	31	0	0	0	0	0	0	0	74.05	0	0	12
2014	7	26	0	12	18	31	0	0	0	0	0	0	0	73.83	0	0	12
2014	7	26	0	22	18	31	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	26	0	32	18	31	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	26	0	42	18	31	0	0	0	0	0	0	0	73.27	0	0	12
2014	7	26	0	52	18	32	0	0	0	0	0	0	0	73.08	0	0	12
2014	7	26	1	2	18	31	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	26	1	12	18	31	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	26	1	22	18	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	26	1	32	18	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	26	1	42	18	31	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	26	1	52	18	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	26	2	2	18	31	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	26	2	12	18	31	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	26	2	22	18	31	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	26	2	32	18	31	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	26	2	42	18	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	26	2	52	18	32	0	0	0	0	0	0	0	71.26	0	0	12
2014	7	26	3	2	18	31	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	26	3	12	18	31	0	0	0	0	0	0	0	70.93	0	0	12
2014	7	26	3	22	18	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	26	3	32	18	31	0	0	0	0	0	0	0	70.61	0	0	12
2014	7	26	3	42	18	31	0	0	0	0	0	0	0	70.45	0	0	12
2014	7	26	3	52	18	31	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	26	4	2	18	31	0	0	0	0	0	0	0	70.12	0	0	12
2014	7	26	4	12	18	31	0	0	0	0	0	0	0	69.96	0	0	12
2014	7	26	4	22	18	31	0	0	0	0	0	0	0	69.8	0	0	12
2014	7	26	4	32	18	31	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	26	4	42	18	31	0	0	0	0	0	0	0	69.51	0	0	12
2014	7	26	4	52	18	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	7	26	5	2	18	31	0	0	0	0	0	0	0	69.22	0	0	12
2014	7	26	5	12	18	31	0	0	0	0	0	0	0	69.08	0	0	12
2014	7	26	5	22	18	32	0	0	0	0	0	0	0	68.95	0	0	11.8
2014	7	26	5	32	18	31	0	0	0	0	0	0	0	68.83	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	5	42	18	31	0	0	0	0	0	0	0	68.7	0	0	12
2014	7	26	5	52	18	32	0	0	0	0	0	0	0	68.59	0	0	12
2014	7	26	6	2	18	31	0	0	0	0	0	0	0	68.47	0	0	12
2014	7	26	6	12	18	31	0	0	0	0	0	0	0	68.36	0	0	12
2014	7	26	6	22	18	31	0	0	0	0	0	0	0	68.25	0	0	11.8
2014	7	26	6	32	18	32	0	0	0	0	0	0	0	68.16	0	0	12
2014	7	26	6	42	18	32	0	0	0	0	0	0	0	68.07	0	0	12
2014	7	26	6	52	18	32	0	0	0	0	0	0	0	68	0	0	12
2014	7	26	7	2	18	32	0	0	0	0	0	0	0	67.93	0	0	12.2
2014	7	26	7	12	18	31	0	0	0	0	0	0	0	68.02	0	0	12.4
2014	7	26	7	22	18	32	0	0	0	0	0	0	0	67.96	0	0	12.2
2014	7	26	7	32	18	31	0	0	0	0	0	0	0	67.95	0	0	12.4
2014	7	26	7	42	18	32	0	0	0	0	0	0	0	67.86	0	0	12.4
2014	7	26	7	52	18	31	0	0	0	0	0	0	0	67.69	0	0	12.6
2014	7	26	8	2	18	32	0	0	0	0	0	0	0	68.02	0	0	12.8
2014	7	26	8	12	18	31	0	0	0	0	0	0	0	68.25	0	0	13
2014	7	26	8	22	18	32	0	0	0	0	0	0	0	68.32	0	0	13
2014	7	26	8	32	18	31	0	0	0	0	0	0	0	68.56	0	0	13.2
2014	7	26	8	42	18	32	0	0	0	0	0	0	0	68.36	0	0	13
2014	7	26	8	52	18	32	0	0	0	0	0	0	0	68.32	0	0	12.8
2014	7	26	9	2	18	32	0	0	0	0	0	0	0	68.72	0	0	13.2
2014	7	26	9	12	18	32	0	0	0	0	0	0	0	68.79	0	0	13.2
2014	7	26	9	22	18	32	0	0	0	0	0	0	0	68.65	0	0	12.8
2014	7	26	9	32	18	32	0	0	0	0	0	0	0	69.26	0	0	13.4
2014	7	26	9	42	18	32	0	0	0	0	0	0	0	69.17	0	0	13.2
2014	7	26	9	52	18	31	0	0	0	0	0	0	0	68.99	0	0	12.8
2014	7	26	10	2	18	31	0	0	0	0	0	0	0	69.42	0	0	13.2
2014	7	26	10	12	18	32	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	26	10	22	18	32	0	0	0	0	0	0	0	69.66	0	0	13
2014	7	26	10	32	18	31	0	0	0	0	0	0	0	69.93	0	0	13.4
2014	7	26	10	42	18	31	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	26	10	52	18	31	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	7	26	11	2	18	32	0	0	0	0	0	0	0	70.81	0	0	13.4
2014	7	26	11	12	18	31	0	0	0	0	0	0	0	70.86	0	0	13.2
2014	7	26	11	22	18	31	0	0	0	0	0	0	0	71.17	0	0	13.2
2014	7	26	11	32	18	31	0	0	0	0	0	0	0	71.11	0	0	13.2
2014	7	26	11	42	18	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	7	26	11	52	18	30	0	0	0	0	0	0	0	71.31	0	0	13.2
2014	7	26	12	2	18	31	0	0	0	0	0	0	0	71.49	0	0	13.2
2014	7	26	12	12	18	31	0	0	0	0	0	0	0	71.78	0	0	13.2
2014	7	26	12	22	18	31	0	0	0	0	0	0	0	72.03	0	0	13
2014	7	26	12	32	18	31	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	26	12	42	18	31	0	0	0	0	0	0	0	72.61	0	0	13.2
2014	7	26	12	52	18	32	0	0	0	0	0	0	0	72.95	0	0	13.2
2014	7	26	13	2	18	31	0	0	0	0	0	0	0	73.44	0	0	13.2
2014	7	26	13	12	18	31	0	0	0	0	0	0	0	73.83	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	13	22	18	30	0	0	0	0	0	0	0	74.12	0	0	12.8
2014	7	26	13	32	18	31	0	0	0	0	0	0	0	74.41	0	0	13.2
2014	7	26	13	42	18	31	0	0	0	0	0	0	0	74.91	0	0	13.2
2014	7	26	13	52	18	30	0	0	0	0	0	0	0	74.97	0	0	13
2014	7	26	14	2	18	31	0	0	0	0	0	0	0	75.38	0	0	13.2
2014	7	26	14	12	18	31	0	0	0	0	0	0	0	75.52	0	0	13
2014	7	26	14	22	18	30	0	0	0	0	0	0	0	76.14	0	0	13.2
2014	7	26	14	32	18	31	0	0	0	0	0	0	0	76.44	0	0	13.2
2014	7	26	14	42	18	31	0	0	0	0	0	0	0	76.73	0	0	13.2
2014	7	26	14	52	18	30	0	0	0	0	0	0	0	77.07	0	0	13.2
2014	7	26	15	2	18	31	0	0	0	0	0	0	0	77.25	0	0	13.2
2014	7	26	15	12	18	30	0	0	0	0	0	0	0	77.54	0	0	13.2
2014	7	26	15	22	18	31	0	0	0	0	0	0	0	77.61	0	0	13
2014	7	26	15	32	18	30	0	0	0	0	0	0	0	77.88	0	0	13.2
2014	7	26	15	42	18	30	0	0	0	0	0	0	0	78.17	0	0	13.2
2014	7	26	15	52	18	31	0	0	0	0	0	0	0	78.4	0	0	13
2014	7	26	16	2	18	31	0	0	0	0	0	0	0	78.46	0	0	12.8
2014	7	26	16	12	18	31	0	0	0	0	0	0	0	78.71	0	0	12.8
2014	7	26	16	22	18	30	0	0	0	0	0	0	0	78.75	0	0	12.6
2014	7	26	16	32	18	30	0	0	0	0	0	0	0	79.07	0	0	12.8
2014	7	26	16	42	18	31	0	0	0	0	0	0	0	79.18	0	0	12.6
2014	7	26	16	52	18	31	0	0	0	0	0	0	0	79.23	0	0	12.6
2014	7	26	17	2	18	30	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	26	17	12	18	31	0	0	0	0	0	0	0	79.27	0	0	12.4
2014	7	26	17	22	18	31	0	0	0	0	0	0	0	79.21	0	0	12.2
2014	7	26	17	32	18	31	0	0	0	0	0	0	0	79.18	0	0	12.4
2014	7	26	17	42	18	30	0	0	0	0	0	0	0	79.03	0	0	12.2
2014	7	26	17	52	18	31	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	26	18	2	18	30	0	0	0	0	0	0	0	79.02	0	0	12.2
2014	7	26	18	12	18	30	0	0	0	0	0	0	0	79	0	0	12.2
2014	7	26	18	22	18	30	0	0	0	0	0	0	0	78.94	0	0	12.2
2014	7	26	18	32	18	30	0	0	0	0	0	0	0	78.85	0	0	12.2
2014	7	26	18	42	18	30	0	0	0	0	0	0	0	78.73	0	0	12.2
2014	7	26	18	52	18	30	0	0	0	0	0	0	0	78.66	0	0	12.2
2014	7	26	19	2	18	29	0	0	0	0	0	0	0	78.53	0	0	12.2
2014	7	26	19	12	18	30	0	0	0	0	0	0	0	78.42	0	0	12.2
2014	7	26	19	22	18	31	0	0	0	0	0	0	0	78.33	0	0	12.2
2014	7	26	19	32	18	31	0	0	0	0	0	0	0	78.24	0	0	12.2
2014	7	26	19	42	18	29	0	0	0	0	0	0	0	78.15	0	0	12.2
2014	7	26	19	52	18	30	0	0	0	0	0	0	0	78.06	0	0	12.2
2014	7	26	20	2	18	31	0	0	0	0	0	0	0	77.97	0	0	12.2
2014	7	26	20	12	18	31	0	0	0	0	0	0	0	77.88	0	0	12.2
2014	7	26	20	22	18	30	0	0	0	0	0	0	0	77.79	0	0	12
2014	7	26	20	32	18	31	0	0	0	0	0	0	0	77.67	0	0	12.2
2014	7	26	20	42	18	31	0	0	0	0	0	0	0	77.58	0	0	12.2
2014	7	26	20	52	18	31	0	0	0	0	0	0	0	77.45	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	21	2	18	31	0	0	0	0	0	0	0	77.36	0	0	12.2
2014	7	26	21	12	18	31	0	0	0	0	0	0	0	77.25	0	0	12.2
2014	7	26	21	22	18	30	0	0	0	0	0	0	0	77.13	0	0	12
2014	7	26	21	32	18	30	0	0	0	0	0	0	0	77	0	0	12.2
2014	7	26	21	42	18	31	0	0	0	0	0	0	0	76.86	0	0	12.2
2014	7	26	21	52	18	31	0	0	0	0	0	0	0	76.73	0	0	12.2
2014	7	26	22	2	18	31	0	0	0	0	0	0	0	76.59	0	0	12.2
2014	7	26	22	12	18	31	0	0	0	0	0	0	0	76.44	0	0	12.2
2014	7	26	22	22	18	30	0	0	0	0	0	0	0	76.28	0	0	12
2014	7	26	22	32	18	31	0	0	0	0	0	0	0	76.1	0	0	12.2
2014	7	26	22	42	18	30	0	0	0	0	0	0	0	75.94	0	0	12.2
2014	7	26	22	52	18	31	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	26	23	2	18	31	0	0	0	0	0	0	0	75.58	0	0	12
2014	7	26	23	12	18	31	0	0	0	0	0	0	0	75.36	0	0	12
2014	7	26	23	22	18	31	0	0	0	0	0	0	0	75.13	0	0	12
2014	7	26	23	32	18	30	0	0	0	0	0	0	0	74.91	0	0	12
2014	7	26	23	42	18	31	0	0	0	0	0	0	0	74.68	0	0	12
2014	7	26	23	52	18	31	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	27	0	2	18	31	0	0	0	0	0	0	0	74.23	0	0	12
2014	7	27	0	12	18	30	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	27	0	22	18	31	0	0	0	0	0	0	0	73.81	0	0	12
2014	7	27	0	32	18	31	0	0	0	0	0	0	0	73.63	0	0	12
2014	7	27	0	42	18	30	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	27	0	52	18	30	0	0	0	0	0	0	0	73.27	0	0	12
2014	7	27	1	2	18	31	0	0	0	0	0	0	0	73.13	0	0	12
2014	7	27	1	12	18	31	0	0	0	0	0	0	0	72.97	0	0	12
2014	7	27	1	22	18	32	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	27	1	32	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	27	1	42	18	31	0	0	0	0	0	0	0	72.48	0	0	12
2014	7	27	1	52	18	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	27	2	2	18	31	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	27	2	12	18	31	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	27	2	22	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	27	2	32	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	27	2	42	18	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	7	27	2	52	18	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	27	3	2	18	31	0	0	0	0	0	0	0	71.37	0	0	12
2014	7	27	3	12	18	31	0	0	0	0	0	0	0	71.24	0	0	12
2014	7	27	3	22	18	32	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	27	3	32	18	32	0	0	0	0	0	0	0	71.01	0	0	12
2014	7	27	3	42	18	31	0	0	0	0	0	0	0	70.9	0	0	12
2014	7	27	3	52	18	31	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	27	4	2	18	32	0	0	0	0	0	0	0	70.66	0	0	12
2014	7	27	4	12	18	32	0	0	0	0	0	0	0	70.56	0	0	12
2014	7	27	4	22	18	31	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	27	4	32	18	31	0	0	0	0	0	0	0	70.36	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	4	42	18	31	0	0	0	0	0	0	0	70.25	0	0	12
2014	7	27	4	52	18	31	0	0	0	0	0	0	0	70.14	0	0	12
2014	7	27	5	2	18	31	0	0	0	0	0	0	0	70.07	0	0	12
2014	7	27	5	12	18	31	0	0	0	0	0	0	0	70	0	0	12
2014	7	27	5	22	18	32	0	0	0	0	0	0	0	69.93	0	0	12
2014	7	27	5	32	18	31	0	0	0	0	0	0	0	69.84	0	0	12
2014	7	27	5	42	18	32	0	0	0	0	0	0	0	69.76	0	0	12
2014	7	27	5	52	18	32	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	27	6	2	18	31	0	0	0	0	0	0	0	69.64	0	0	12
2014	7	27	6	12	18	32	0	0	0	0	0	0	0	69.58	0	0	12
2014	7	27	6	22	18	32	0	0	0	0	0	0	0	69.53	0	0	11.8
2014	7	27	6	32	18	31	0	0	0	0	0	0	0	69.48	0	0	12
2014	7	27	6	42	18	31	0	0	0	0	0	0	0	69.42	0	0	12
2014	7	27	6	52	18	32	0	0	0	0	0	0	0	69.39	0	0	12
2014	7	27	7	2	18	31	0	0	0	0	0	0	0	69.35	0	0	12
2014	7	27	7	12	18	32	0	0	0	0	0	0	0	69.31	0	0	12
2014	7	27	7	22	18	31	0	0	0	0	0	0	0	69.31	0	0	11.8
2014	7	27	7	32	18	32	0	0	0	0	0	0	0	69.3	0	0	12
2014	7	27	7	42	18	32	0	0	0	0	0	0	0	69.35	0	0	12.2
2014	7	27	7	52	18	32	0	0	0	0	0	0	0	69.42	0	0	12.4
2014	7	27	8	2	18	31	0	0	0	0	0	0	0	69.69	0	0	12.8
2014	7	27	8	12	18	31	0	0	0	0	0	0	0	69.57	0	0	12.6
2014	7	27	8	22	18	31	0	0	0	0	0	0	0	69.64	0	0	12.4
2014	7	27	8	32	18	31	0	0	0	0	0	0	0	69.8	0	0	12.6
2014	7	27	8	42	18	30	0	0	0	0	0	0	0	70.3	0	0	13.2
2014	7	27	8	52	18	32	0	0	0	0	0	0	0	70.05	0	0	12.8
2014	7	27	9	2	18	32	0	0	0	0	0	0	0	70.52	0	0	13.2
2014	7	27	9	12	18	32	0	0	0	0	0	0	0	70.68	0	0	13.2
2014	7	27	9	22	18	32	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	27	9	32	18	32	0	0	0	0	0	0	0	70.38	0	0	12.8
2014	7	27	9	42	18	32	0	0	0	0	0	0	0	70.38	0	0	12.8
2014	7	27	9	52	18	31	0	0	0	0	0	0	0	71.1	0	0	13.2
2014	7	27	10	2	18	31	0	0	0	0	0	0	0	70.97	0	0	12.8
2014	7	27	10	12	18	31	0	0	0	0	0	0	0	71.24	0	0	13
2014	7	27	10	22	18	31	0	0	0	0	0	0	0	71.49	0	0	13
2014	7	27	10	32	18	32	0	0	0	0	0	0	0	72	0	0	13.2
2014	7	27	10	42	18	31	0	0	0	0	0	0	0	72.18	0	0	13.2
2014	7	27	10	52	18	31	0	0	0	0	0	0	0	72.3	0	0	13.2
2014	7	27	11	2	18	31	0	0	0	0	0	0	0	72.48	0	0	13.2
2014	7	27	11	12	18	31	0	0	0	0	0	0	0	72.86	0	0	13.2
2014	7	27	11	22	18	31	0	0	0	0	0	0	0	73.13	0	0	13.2
2014	7	27	11	32	18	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2014	7	27	11	42	18	32	0	0	0	0	0	0	0	73.08	0	0	13.2
2014	7	27	11	52	18	31	0	0	0	0	0	0	0	73.04	0	0	13.2
2014	7	27	12	2	18	31	0	0	0	0	0	0	0	73.26	0	0	13.2
2014	7	27	12	12	18	30	0	0	0	0	0	0	0	73.53	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	12	22	18	30	0	0	0	0	0	0	0	73.85	0	0	13
2014	7	27	12	32	18	31	0	0	0	0	0	0	0	74.19	0	0	13.2
2014	7	27	12	42	18	30	0	0	0	0	0	0	0	74.57	0	0	13.2
2014	7	27	12	52	18	31	0	0	0	0	0	0	0	74.93	0	0	13.2
2014	7	27	13	2	18	31	0	0	0	0	0	0	0	75.94	0	0	13.2
2014	7	27	13	12	18	31	0	0	0	0	0	0	0	76.06	0	0	13
2014	7	27	13	22	18	31	0	0	0	0	0	0	0	76.68	0	0	13.2
2014	7	27	13	32	18	31	0	0	0	0	0	0	0	77	0	0	13
2014	7	27	13	42	18	31	0	0	0	0	0	0	0	76.91	0	0	12.8
2014	7	27	13	52	18	31	0	0	0	0	0	0	0	77.43	0	0	13.2
2014	7	27	14	2	18	31	0	0	0	0	0	0	0	77.58	0	0	12.8
2014	7	27	14	12	18	31	0	0	0	0	0	0	0	77.9	0	0	13
2014	7	27	14	22	18	31	0	0	0	0	0	0	0	78.17	0	0	13
2014	7	27	14	32	18	31	0	0	0	0	0	0	0	78.66	0	0	13.2
2014	7	27	14	42	18	31	0	0	0	0	0	0	0	78.53	0	0	12.8
2014	7	27	14	52	18	30	0	0	0	0	0	0	0	78.49	0	0	12.6
2014	7	27	15	2	18	31	0	0	0	0	0	0	0	78.57	0	0	12.8
2014	7	27	15	12	18	30	0	0	0	0	0	0	0	78.73	0	0	12.8
2014	7	27	15	22	18	31	0	0	0	0	0	0	0	79.12	0	0	12.8
2014	7	27	15	32	18	30	0	0	0	0	0	0	0	79.5	0	0	13.2
2014	7	27	15	42	18	30	0	0	0	0	0	0	0	79.75	0	0	13.2
2014	7	27	15	52	18	31	0	0	0	0	0	0	0	80.01	0	0	13
2014	7	27	16	2	18	31	0	0	0	0	0	0	0	80.19	0	0	13
2014	7	27	16	12	18	30	0	0	0	0	0	0	0	80.38	0	0	13
2014	7	27	16	22	18	30	0	0	0	0	0	0	0	80.58	0	0	12.8
2014	7	27	16	32	18	30	0	0	0	0	0	0	0	80.69	0	0	12.8
2014	7	27	16	42	18	30	0	0	0	0	0	0	0	80.82	0	0	12.8
2014	7	27	16	52	18	30	0	0	0	0	0	0	0	80.76	0	0	12.6
2014	7	27	17	2	18	31	0	0	0	0	0	0	0	80.96	0	0	12.6
2014	7	27	17	12	18	30	0	0	0	0	0	0	0	81.07	0	0	12.4
2014	7	27	17	22	18	30	0	0	0	0	0	0	0	80.96	0	0	12.4
2014	7	27	17	32	18	30	0	0	0	0	0	0	0	81.14	0	0	12.4
2014	7	27	17	42	18	30	0	0	0	0	0	0	0	81.18	0	0	12.4
2014	7	27	17	52	18	30	0	0	0	0	0	0	0	81.23	0	0	12.4
2014	7	27	18	2	18	30	0	0	0	0	0	0	0	81.23	0	0	12.4
2014	7	27	18	12	18	30	0	0	0	0	0	0	0	81.23	0	0	12.4
2014	7	27	18	22	18	30	0	0	0	0	0	0	0	81.14	0	0	12.2
2014	7	27	18	32	18	30	0	0	0	0	0	0	0	81.19	0	0	12.4
2014	7	27	18	42	18	31	0	0	0	0	0	0	0	81.21	0	0	12.4
2014	7	27	18	52	18	30	0	0	0	0	0	0	0	81.16	0	0	12.2
2014	7	27	19	2	18	30	0	0	0	0	0	0	0	81.16	0	0	12.2
2014	7	27	19	12	18	30	0	0	0	0	0	0	0	81.1	0	0	12.2
2014	7	27	19	22	18	30	0	0	0	0	0	0	0	81.01	0	0	12.2
2014	7	27	19	32	18	30	0	0	0	0	0	0	0	80.92	0	0	12.2
2014	7	27	19	42	18	30	0	0	0	0	0	0	0	80.82	0	0	12.2
2014	7	27	19	52	18	30	0	0	0	0	0	0	0	80.65	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	20	2	18	30	0	0	0	0	0	0	0	80.56	0	0	12.2
2014	7	27	20	12	18	30	0	0	0	0	0	0	0	80.42	0	0	12.2
2014	7	27	20	22	18	30	0	0	0	0	0	0	0	80.26	0	0	12
2014	7	27	20	32	18	31	0	0	0	0	0	0	0	80.15	0	0	12.2
2014	7	27	20	42	18	30	0	0	0	0	0	0	0	80.04	0	0	12.2
2014	7	27	20	52	18	30	0	0	0	0	0	0	0	79.86	0	0	12.2
2014	7	27	21	2	18	30	0	0	0	0	0	0	0	79.72	0	0	12.2
2014	7	27	21	12	18	30	0	0	0	0	0	0	0	79.48	0	0	12.2
2014	7	27	21	22	18	30	0	0	0	0	0	0	0	79.32	0	0	12
2014	7	27	21	32	18	31	0	0	0	0	0	0	0	79.2	0	0	12.2
2014	7	27	21	42	18	31	0	0	0	0	0	0	0	79.05	0	0	12.2
2014	7	27	21	52	18	30	0	0	0	0	0	0	0	78.94	0	0	12.2
2014	7	27	22	2	18	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2014	7	27	22	12	18	30	0	0	0	0	0	0	0	78.66	0	0	12
2014	7	27	22	22	18	31	0	0	0	0	0	0	0	78.51	0	0	12
2014	7	27	22	32	18	31	0	0	0	0	0	0	0	78.39	0	0	12
2014	7	27	22	42	18	30	0	0	0	0	0	0	0	78.21	0	0	12
2014	7	27	22	52	18	30	0	0	0	0	0	0	0	78.08	0	0	12
2014	7	27	23	2	18	30	0	0	0	0	0	0	0	77.9	0	0	12
2014	7	27	23	12	18	30	0	0	0	0	0	0	0	77.72	0	0	12
2014	7	27	23	22	18	30	0	0	0	0	0	0	0	77.56	0	0	12
2014	7	27	23	32	18	31	0	0	0	0	0	0	0	77.36	0	0	12
2014	7	27	23	42	18	31	0	0	0	0	0	0	0	77.2	0	0	12
2014	7	27	23	52	18	30	0	0	0	0	0	0	0	77.02	0	0	12
2014	7	28	0	2	18	31	0	0	0	0	0	0	0	76.82	0	0	12
2014	7	28	0	12	18	31	0	0	0	0	0	0	0	76.6	0	0	12
2014	7	28	0	22	18	30	0	0	0	0	0	0	0	76.37	0	0	12
2014	7	28	0	32	18	31	0	0	0	0	0	0	0	76.15	0	0	12
2014	7	28	0	42	18	31	0	0	0	0	0	0	0	75.94	0	0	12
2014	7	28	0	52	18	30	0	0	0	0	0	0	0	75.74	0	0	12
2014	7	28	1	2	18	30	0	0	0	0	0	0	0	75.54	0	0	12
2014	7	28	1	12	18	31	0	0	0	0	0	0	0	75.36	0	0	12
2014	7	28	1	22	18	31	0	0	0	0	0	0	0	75.15	0	0	11.8
2014	7	28	1	32	18	31	0	0	0	0	0	0	0	74.98	0	0	12
2014	7	28	1	42	18	31	0	0	0	0	0	0	0	74.79	0	0	12
2014	7	28	1	52	18	30	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	28	2	2	18	31	0	0	0	0	0	0	0	74.43	0	0	12
2014	7	28	2	12	18	31	0	0	0	0	0	0	0	74.28	0	0	12
2014	7	28	2	22	18	31	0	0	0	0	0	0	0	74.14	0	0	11.8
2014	7	28	2	32	18	31	0	0	0	0	0	0	0	73.98	0	0	12
2014	7	28	2	42	18	31	0	0	0	0	0	0	0	73.85	0	0	12
2014	7	28	2	52	18	31	0	0	0	0	0	0	0	73.72	0	0	12
2014	7	28	3	2	18	31	0	0	0	0	0	0	0	73.62	0	0	12
2014	7	28	3	12	18	31	0	0	0	0	0	0	0	73.51	0	0	12
2014	7	28	3	22	18	30	0	0	0	0	0	0	0	73.4	0	0	12
2014	7	28	3	32	18	30	0	0	0	0	0	0	0	73.31	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	3	42	18	31	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	28	3	52	18	31	0	0	0	0	0	0	0	73.11	0	0	12
2014	7	28	4	2	18	31	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	28	4	12	18	31	0	0	0	0	0	0	0	72.91	0	0	12
2014	7	28	4	22	18	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	7	28	4	32	18	31	0	0	0	0	0	0	0	72.75	0	0	12
2014	7	28	4	42	18	31	0	0	0	0	0	0	0	72.66	0	0	12
2014	7	28	4	52	18	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	28	5	2	18	31	0	0	0	0	0	0	0	72.5	0	0	12
2014	7	28	5	12	18	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	28	5	22	18	31	0	0	0	0	0	0	0	72.34	0	0	12
2014	7	28	5	32	18	32	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	28	5	42	18	31	0	0	0	0	0	0	0	72.18	0	0	12
2014	7	28	5	52	18	31	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	28	6	2	18	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	28	6	12	18	31	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	28	6	22	18	31	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	28	6	32	18	30	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	28	6	42	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	7	28	6	52	18	31	0	0	0	0	0	0	0	71.8	0	0	12
2014	7	28	7	2	18	31	0	0	0	0	0	0	0	71.8	0	0	12
2014	7	28	7	12	18	32	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	28	7	22	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	7	28	7	32	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	7	28	7	42	18	31	0	0	0	0	0	0	0	71.91	0	0	12.2
2014	7	28	7	52	18	31	0	0	0	0	0	0	0	71.98	0	0	12.2
2014	7	28	8	2	18	31	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	28	8	12	18	31	0	0	0	0	0	0	0	72.05	0	0	12.2
2014	7	28	8	22	18	31	0	0	0	0	0	0	0	72.12	0	0	12.2
2014	7	28	8	32	18	31	0	0	0	0	0	0	0	72.18	0	0	12.2
2014	7	28	8	42	18	31	0	0	0	0	0	0	0	72.28	0	0	12.2
2014	7	28	8	52	18	31	0	0	0	0	0	0	0	72.43	0	0	12.4
2014	7	28	9	2	18	31	0	0	0	0	0	0	0	72.5	0	0	12.4
2014	7	28	9	12	18	31	0	0	0	0	0	0	0	72.59	0	0	12.4
2014	7	28	9	22	18	31	0	0	0	0	0	0	0	72.66	0	0	12.4
2014	7	28	9	32	18	30	0	0	0	0	0	0	0	72.73	0	0	12.4
2014	7	28	9	42	18	31	0	0	0	0	0	0	0	72.79	0	0	12.6
2014	7	28	9	52	18	31	0	0	0	0	0	0	0	72.91	0	0	12.6
2014	7	28	10	2	18	32	0	0	0	0	0	0	0	73.08	0	0	12.8
2014	7	28	10	12	18	31	0	0	0	0	0	0	0	74.01	0	0	13.4
2014	7	28	10	22	18	30	0	0	0	0	0	0	0	73.87	0	0	13
2014	7	28	10	32	18	31	0	0	0	0	0	0	0	73.67	0	0	13
2014	7	28	10	42	18	31	0	0	0	0	0	0	0	73.83	0	0	13
2014	7	28	10	52	18	31	0	0	0	0	0	0	0	74.21	0	0	13.2
2014	7	28	11	2	18	31	0	0	0	0	0	0	0	73.99	0	0	12.8
2014	7	28	11	12	18	31	0	0	0	0	0	0	0	74.03	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	11	22	18	31	0	0	0	0	0	0	0	74.16	0	0	12.6
2014	7	28	11	32	18	31	0	0	0	0	0	0	0	74.23	0	0	12.8
2014	7	28	11	42	18	31	0	0	0	0	0	0	0	74.35	0	0	12.8
2014	7	28	11	52	18	30	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	28	12	2	18	32	0	0	0	0	0	0	0	74.59	0	0	12.8
2014	7	28	12	12	18	31	0	0	0	0	0	0	0	74.66	0	0	12.8
2014	7	28	12	22	18	31	0	0	0	0	0	0	0	74.75	0	0	12.6
2014	7	28	12	32	18	31	0	0	0	0	0	0	0	74.88	0	0	12.8
2014	7	28	12	42	18	30	0	0	0	0	0	0	0	75	0	0	12.8
2014	7	28	12	52	18	31	0	0	0	0	0	0	0	75.13	0	0	12.8
2014	7	28	13	2	18	31	0	0	0	0	0	0	0	75.25	0	0	12.8
2014	7	28	13	12	18	30	0	0	0	0	0	0	0	75.43	0	0	12.8
2014	7	28	13	22	18	31	0	0	0	0	0	0	0	75.52	0	0	12.8
2014	7	28	13	32	18	31	0	0	0	0	0	0	0	75.65	0	0	12.8
2014	7	28	13	42	18	30	0	0	0	0	0	0	0	75.78	0	0	12.8
2014	7	28	13	52	18	30	0	0	0	0	0	0	0	75.97	0	0	13
2014	7	28	14	2	18	31	0	0	0	0	0	0	0	76.1	0	0	12.8
2014	7	28	14	12	18	30	0	0	0	0	0	0	0	76.17	0	0	12.8
2014	7	28	14	22	18	30	0	0	0	0	0	0	0	76.5	0	0	13
2014	7	28	14	32	18	31	0	0	0	0	0	0	0	76.57	0	0	12.8
2014	7	28	14	42	18	31	0	0	0	0	0	0	0	76.51	0	0	12.6
2014	7	28	14	52	18	31	0	0	0	0	0	0	0	76.46	0	0	12.4
2014	7	28	15	2	18	30	0	0	0	0	0	0	0	76.41	0	0	12.4
2014	7	28	15	12	18	30	0	0	0	0	0	0	0	76.41	0	0	12.2
2014	7	28	15	22	18	31	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	7	28	15	32	18	31	0	0	0	0	0	0	0	76.5	0	0	12.2
2014	7	28	15	42	18	31	0	0	0	0	0	0	0	76.55	0	0	12.2
2014	7	28	15	52	18	31	0	0	0	0	0	0	0	76.59	0	0	12.2
2014	7	28	16	2	18	30	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	28	16	12	18	31	0	0	0	0	0	0	0	76.66	0	0	12.2
2014	7	28	16	22	18	31	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	28	16	32	18	30	0	0	0	0	0	0	0	76.57	0	0	12.2
2014	7	28	16	42	18	30	0	0	0	0	0	0	0	76.53	0	0	12.2
2014	7	28	16	52	18	31	0	0	0	0	0	0	0	76.5	0	0	12.2
2014	7	28	17	2	18	30	0	0	0	0	0	0	0	76.48	0	0	12.2
2014	7	28	17	12	18	30	0	0	0	0	0	0	0	76.44	0	0	12.2
2014	7	28	17	22	18	30	0	0	0	0	0	0	0	76.39	0	0	12
2014	7	28	17	32	18	31	0	0	0	0	0	0	0	76.33	0	0	12.2
2014	7	28	17	42	18	31	0	0	0	0	0	0	0	76.32	0	0	12.2
2014	7	28	17	52	18	31	0	0	0	0	0	0	0	76.28	0	0	12.2
2014	7	28	18	2	18	31	0	0	0	0	0	0	0	76.26	0	0	12
2014	7	28	18	12	18	30	0	0	0	0	0	0	0	76.21	0	0	12
2014	7	28	18	22	18	31	0	0	0	0	0	0	0	76.15	0	0	12
2014	7	28	18	32	18	30	0	0	0	0	0	0	0	76.1	0	0	12
2014	7	28	18	42	18	30	0	0	0	0	0	0	0	76.01	0	0	12
2014	7	28	18	52	18	31	0	0	0	0	0	0	0	75.94	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	19	2	18	31	0	0	0	0	0	0	0	75.87	0	0	12
2014	7	28	19	12	18	31	0	0	0	0	0	0	0	75.79	0	0	12
2014	7	28	19	22	18	30	0	0	0	0	0	0	0	75.7	0	0	12
2014	7	28	19	32	18	31	0	0	0	0	0	0	0	75.6	0	0	12
2014	7	28	19	42	18	31	0	0	0	0	0	0	0	75.51	0	0	12
2014	7	28	19	52	18	31	0	0	0	0	0	0	0	75.4	0	0	12
2014	7	28	20	2	18	31	0	0	0	0	0	0	0	75.29	0	0	12
2014	7	28	20	12	18	31	0	0	0	0	0	0	0	75.18	0	0	12
2014	7	28	20	22	18	31	0	0	0	0	0	0	0	75.07	0	0	11.8
2014	7	28	20	32	18	30	0	0	0	0	0	0	0	74.97	0	0	12
2014	7	28	20	42	18	30	0	0	0	0	0	0	0	74.84	0	0	12
2014	7	28	20	52	18	31	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	28	21	2	18	31	0	0	0	0	0	0	0	74.61	0	0	12
2014	7	28	21	12	18	31	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	28	21	22	18	31	0	0	0	0	0	0	0	74.41	0	0	11.8
2014	7	28	21	32	18	31	0	0	0	0	0	0	0	74.3	0	0	12
2014	7	28	21	42	18	30	0	0	0	0	0	0	0	74.17	0	0	12
2014	7	28	21	52	18	30	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	28	22	2	18	31	0	0	0	0	0	0	0	73.94	0	0	12
2014	7	28	22	12	18	31	0	0	0	0	0	0	0	73.81	0	0	12
2014	7	28	22	22	18	30	0	0	0	0	0	0	0	73.69	0	0	11.8
2014	7	28	22	32	18	32	0	0	0	0	0	0	0	73.56	0	0	12
2014	7	28	22	42	18	31	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	28	22	52	18	30	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	28	23	2	18	31	0	0	0	0	0	0	0	73.22	0	0	12
2014	7	28	23	12	18	31	0	0	0	0	0	0	0	73.09	0	0	12
2014	7	28	23	22	18	32	0	0	0	0	0	0	0	72.99	0	0	11.8
2014	7	28	23	32	18	30	0	0	0	0	0	0	0	72.88	0	0	12
2014	7	28	23	42	18	31	0	0	0	0	0	0	0	72.75	0	0	12
2014	7	28	23	52	18	31	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	29	0	2	18	31	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	29	0	12	18	31	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	29	0	22	18	31	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	29	0	32	18	30	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	29	0	42	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	29	0	52	18	31	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	29	1	2	18	31	0	0	0	0	0	0	0	71.85	0	0	12
2014	7	29	1	12	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	29	1	22	18	31	0	0	0	0	0	0	0	71.65	0	0	11.8
2014	7	29	1	32	18	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	29	1	42	18	31	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	29	1	52	18	32	0	0	0	0	0	0	0	71.29	0	0	12
2014	7	29	2	2	18	32	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	29	2	12	18	31	0	0	0	0	0	0	0	71.04	0	0	12
2014	7	29	2	22	18	31	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	29	2	32	18	32	0	0	0	0	0	0	0	70.84	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	2	42	18	31	0	0	0	0	0	0	0	70.72	0	0	12
2014	7	29	2	52	18	32	0	0	0	0	0	0	0	70.65	0	0	12
2014	7	29	3	2	18	31	0	0	0	0	0	0	0	70.54	0	0	12
2014	7	29	3	12	18	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	7	29	3	22	18	31	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	29	3	32	18	32	0	0	0	0	0	0	0	70.21	0	0	12
2014	7	29	3	42	18	32	0	0	0	0	0	0	0	70.11	0	0	12
2014	7	29	3	52	18	31	0	0	0	0	0	0	0	70.03	0	0	12
2014	7	29	4	2	18	31	0	0	0	0	0	0	0	69.94	0	0	12
2014	7	29	4	12	18	31	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	29	4	22	18	31	0	0	0	0	0	0	0	69.76	0	0	11.8
2014	7	29	4	32	18	30	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	29	4	42	18	31	0	0	0	0	0	0	0	69.6	0	0	12
2014	7	29	4	52	18	31	0	0	0	0	0	0	0	69.53	0	0	12
2014	7	29	5	2	18	31	0	0	0	0	0	0	0	69.46	0	0	12
2014	7	29	5	12	18	32	0	0	0	0	0	0	0	69.39	0	0	12
2014	7	29	5	22	18	31	0	0	0	0	0	0	0	69.31	0	0	11.8
2014	7	29	5	32	18	31	0	0	0	0	0	0	0	69.24	0	0	12
2014	7	29	5	42	18	31	0	0	0	0	0	0	0	69.15	0	0	12
2014	7	29	5	52	18	32	0	0	0	0	0	0	0	69.08	0	0	12
2014	7	29	6	2	18	30	0	0	0	0	0	0	0	69.01	0	0	12
2014	7	29	6	12	18	32	0	0	0	0	0	0	0	68.99	0	0	12
2014	7	29	6	22	18	32	0	0	0	0	0	0	0	68.94	0	0	11.8
2014	7	29	6	32	18	32	0	0	0	0	0	0	0	68.92	0	0	12
2014	7	29	6	42	18	32	0	0	0	0	0	0	0	68.88	0	0	12
2014	7	29	6	52	18	31	0	0	0	0	0	0	0	68.83	0	0	12
2014	7	29	7	2	18	32	0	0	0	0	0	0	0	68.76	0	0	12.2
2014	7	29	7	12	18	32	0	0	0	0	0	0	0	68.77	0	0	12.2
2014	7	29	7	22	18	31	0	0	0	0	0	0	0	68.88	0	0	12.2
2014	7	29	7	32	18	32	0	0	0	0	0	0	0	69.28	0	0	12.6
2014	7	29	7	42	18	31	0	0	0	0	0	0	0	69.24	0	0	12.8
2014	7	29	7	52	18	32	0	0	0	0	0	0	0	68.97	0	0	12.4
2014	7	29	8	2	18	32	0	0	0	0	0	0	0	68.9	0	0	12.8
2014	7	29	8	12	18	32	0	0	0	0	0	0	0	69.55	0	0	13
2014	7	29	8	22	18	31	0	0	0	0	0	0	0	69.87	0	0	13.2
2014	7	29	8	32	18	32	0	0	0	0	0	0	0	70.07	0	0	13.2
2014	7	29	8	42	18	31	0	0	0	0	0	0	0	69.37	0	0	12.6
2014	7	29	8	52	18	32	0	0	0	0	0	0	0	69.4	0	0	12.6
2014	7	29	9	2	18	32	0	0	0	0	0	0	0	69.4	0	0	12.6
2014	7	29	9	12	18	31	0	0	0	0	0	0	0	69.76	0	0	13
2014	7	29	9	22	18	31	0	0	0	0	0	0	0	69.67	0	0	12.6
2014	7	29	9	32	18	31	0	0	0	0	0	0	0	70.65	0	0	13.4
2014	7	29	9	42	18	31	0	0	0	0	0	0	0	70.81	0	0	13.4
2014	7	29	9	52	18	31	0	0	0	0	0	0	0	71.01	0	0	13.4
2014	7	29	10	2	18	31	0	0	0	0	0	0	0	71.31	0	0	13.4
2014	7	29	10	12	18	32	0	0	0	0	0	0	0	71.56	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	10	22	18	31	0	0	0	0	0	0	0	71.98	0	0	13.4
2014	7	29	10	32	18	31	0	0	0	0	0	0	0	72.28	0	0	13.4
2014	7	29	10	42	18	31	0	0	0	0	0	0	0	72.61	0	0	13.4
2014	7	29	10	52	18	32	0	0	0	0	0	0	0	72.97	0	0	13.4
2014	7	29	11	2	18	31	0	0	0	0	0	0	0	73.18	0	0	13.4
2014	7	29	11	12	18	31	0	0	0	0	0	0	0	73.49	0	0	13.4
2014	7	29	11	22	18	32	0	0	0	0	0	0	0	73.87	0	0	13.4
2014	7	29	11	32	18	31	0	0	0	0	0	0	0	74.07	0	0	13.4
2014	7	29	11	42	18	30	0	0	0	0	0	0	0	73.11	0	0	13.4
2014	7	29	11	52	18	31	0	0	0	0	0	0	0	72.93	0	0	13.4
2014	7	29	12	2	18	31	0	0	0	0	0	0	0	73.11	0	0	13.4
2014	7	29	12	12	18	31	0	0	0	0	0	0	0	73.4	0	0	13.4
2014	7	29	12	22	18	31	0	0	0	0	0	0	0	73.76	0	0	13.4
2014	7	29	12	32	18	30	0	0	0	0	0	0	0	74.1	0	0	13.4
2014	7	29	12	42	18	31	0	0	0	0	0	0	0	74.44	0	0	13.4
2014	7	29	12	52	18	31	0	0	0	0	0	0	0	74.84	0	0	13.4
2014	7	29	13	2	18	31	0	0	0	0	0	0	0	76.15	0	0	13.4
2014	7	29	13	12	18	31	0	0	0	0	0	0	0	76.96	0	0	13.4
2014	7	29	13	22	18	31	0	0	0	0	0	0	0	77.34	0	0	13.2
2014	7	29	13	32	18	31	0	0	0	0	0	0	0	77.7	0	0	13.4
2014	7	29	13	42	18	31	0	0	0	0	0	0	0	78.06	0	0	13.4
2014	7	29	13	52	18	30	0	0	0	0	0	0	0	78.42	0	0	13.2
2014	7	29	14	2	18	31	0	0	0	0	0	0	0	78.75	0	0	13.4
2014	7	29	14	12	18	31	0	0	0	0	0	0	0	78.48	0	0	13.2
2014	7	29	14	22	18	31	0	0	0	0	0	0	0	79.09	0	0	13.2
2014	7	29	14	32	18	31	0	0	0	0	0	0	0	78.87	0	0	13
2014	7	29	14	42	18	30	0	0	0	0	0	0	0	79.36	0	0	13.2
2014	7	29	14	52	18	31	0	0	0	0	0	0	0	79.86	0	0	13.2
2014	7	29	15	2	18	30	0	0	0	0	0	0	0	80.17	0	0	13.2
2014	7	29	15	12	18	30	0	0	0	0	0	0	0	80.49	0	0	13.2
2014	7	29	15	22	18	30	0	0	0	0	0	0	0	80.76	0	0	13
2014	7	29	15	32	18	30	0	0	0	0	0	0	0	80.87	0	0	13.2
2014	7	29	15	42	18	30	0	0	0	0	0	0	0	81.05	0	0	13.2
2014	7	29	15	52	18	30	0	0	0	0	0	0	0	81.28	0	0	13
2014	7	29	16	2	18	30	0	0	0	0	0	0	0	81.46	0	0	13
2014	7	29	16	12	18	31	0	0	0	0	0	0	0	81.66	0	0	12.8
2014	7	29	16	22	18	31	0	0	0	0	0	0	0	81.75	0	0	12.8
2014	7	29	16	32	18	30	0	0	0	0	0	0	0	81.86	0	0	12.8
2014	7	29	16	42	18	30	0	0	0	0	0	0	0	82.04	0	0	12.8
2014	7	29	16	52	18	30	0	0	0	0	0	0	0	82.02	0	0	12.6
2014	7	29	17	2	18	30	0	0	0	0	0	0	0	82.15	0	0	12.6
2014	7	29	17	12	18	30	0	0	0	0	0	0	0	82.22	0	0	12.4
2014	7	29	17	22	18	30	0	0	0	0	0	0	0	82.2	0	0	12.2
2014	7	29	17	32	18	30	0	0	0	0	0	0	0	82.06	0	0	12.4
2014	7	29	17	42	18	30	0	0	0	0	0	0	0	82.02	0	0	12.4
2014	7	29	17	52	18	30	0	0	0	0	0	0	0	82.08	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	18	2	18	30	0	0	0	0	0	0	0	82.11	0	0	12.4
2014	7	29	18	12	18	30	0	0	0	0	0	0	0	82.08	0	0	12.4
2014	7	29	18	22	18	30	0	0	0	0	0	0	0	82.04	0	0	12.2
2014	7	29	18	32	18	29	0	0	0	0	0	0	0	82.06	0	0	12.4
2014	7	29	18	42	18	30	0	0	0	0	0	0	0	82.17	0	0	12.2
2014	7	29	18	52	18	30	0	0	0	0	0	0	0	82.13	0	0	12.2
2014	7	29	19	2	18	30	0	0	0	0	0	0	0	82	0	0	12.2
2014	7	29	19	12	18	30	0	0	0	0	0	0	0	81.9	0	0	12.2
2014	7	29	19	22	18	30	0	0	0	0	0	0	0	81.75	0	0	12.2
2014	7	29	19	32	18	30	0	0	0	0	0	0	0	81.68	0	0	12.2
2014	7	29	19	42	18	31	0	0	0	0	0	0	0	81.61	0	0	12.2
2014	7	29	19	52	18	29	0	0	0	0	0	0	0	81.52	0	0	12.2
2014	7	29	20	2	18	30	0	0	0	0	0	0	0	81.37	0	0	12.2
2014	7	29	20	12	18	31	0	0	0	0	0	0	0	81.25	0	0	12.2
2014	7	29	20	22	18	30	0	0	0	0	0	0	0	81.16	0	0	12
2014	7	29	20	32	18	29	0	0	0	0	0	0	0	81.14	0	0	12.2
2014	7	29	20	42	18	30	0	0	0	0	0	0	0	81.03	0	0	12.2
2014	7	29	20	52	18	30	0	0	0	0	0	0	0	80.94	0	0	12.2
2014	7	29	21	2	18	30	0	0	0	0	0	0	0	80.87	0	0	12.2
2014	7	29	21	12	18	30	0	0	0	0	0	0	0	80.78	0	0	12.2
2014	7	29	21	22	18	30	0	0	0	0	0	0	0	80.73	0	0	12
2014	7	29	21	32	18	30	0	0	0	0	0	0	0	80.64	0	0	12.2
2014	7	29	21	42	18	30	0	0	0	0	0	0	0	80.55	0	0	12.2
2014	7	29	21	52	18	30	0	0	0	0	0	0	0	80.49	0	0	12.2
2014	7	29	22	2	18	29	0	0	0	0	0	0	0	80.42	0	0	12.2
2014	7	29	22	12	18	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2014	7	29	22	22	18	30	0	0	0	0	0	0	0	80.26	0	0	12
2014	7	29	22	32	18	30	0	0	0	0	0	0	0	80.11	0	0	12.2
2014	7	29	22	42	18	30	0	0	0	0	0	0	0	79.95	0	0	12.2
2014	7	29	22	52	18	30	0	0	0	0	0	0	0	79.77	0	0	12.2
2014	7	29	23	2	18	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2014	7	29	23	12	18	30	0	0	0	0	0	0	0	79.38	0	0	12.2
2014	7	29	23	22	18	31	0	0	0	0	0	0	0	79.12	0	0	12
2014	7	29	23	32	18	30	0	0	0	0	0	0	0	78.84	0	0	12.2
2014	7	29	23	42	18	31	0	0	0	0	0	0	0	78.6	0	0	12
2014	7	29	23	52	18	30	0	0	0	0	0	0	0	78.33	0	0	12
2014	7	30	0	2	18	30	0	0	0	0	0	0	0	78.03	0	0	12
2014	7	30	0	12	18	31	0	0	0	0	0	0	0	77.7	0	0	12
2014	7	30	0	22	18	30	0	0	0	0	0	0	0	77.41	0	0	12
2014	7	30	0	32	18	31	0	0	0	0	0	0	0	77.13	0	0	12
2014	7	30	0	42	18	30	0	0	0	0	0	0	0	76.84	0	0	12
2014	7	30	0	52	18	30	0	0	0	0	0	0	0	76.57	0	0	12
2014	7	30	1	2	18	30	0	0	0	0	0	0	0	76.28	0	0	12
2014	7	30	1	12	18	31	0	0	0	0	0	0	0	76.03	0	0	12
2014	7	30	1	22	18	30	0	0	0	0	0	0	0	75.78	0	0	12
2014	7	30	1	32	18	31	0	0	0	0	0	0	0	75.54	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	1	42	18	31	0	0	0	0	0	0	0	75.33	0	0	12
2014	7	30	1	52	18	31	0	0	0	0	0	0	0	75.09	0	0	12
2014	7	30	2	2	18	31	0	0	0	0	0	0	0	74.88	0	0	12
2014	7	30	2	12	18	32	0	0	0	0	0	0	0	74.66	0	0	12
2014	7	30	2	22	18	31	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	30	2	32	18	31	0	0	0	0	0	0	0	74.25	0	0	12
2014	7	30	2	42	18	30	0	0	0	0	0	0	0	74.05	0	0	12
2014	7	30	2	52	18	31	0	0	0	0	0	0	0	73.85	0	0	12
2014	7	30	3	2	18	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	30	3	12	18	30	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	30	3	22	18	30	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	30	3	32	18	31	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	30	3	42	18	31	0	0	0	0	0	0	0	73.04	0	0	12
2014	7	30	3	52	18	31	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	30	4	2	18	31	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	30	4	12	18	31	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	30	4	22	18	31	0	0	0	0	0	0	0	72.64	0	0	12
2014	7	30	4	32	18	31	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	30	4	42	18	31	0	0	0	0	0	0	0	72.46	0	0	12
2014	7	30	4	52	18	31	0	0	0	0	0	0	0	72.39	0	0	12
2014	7	30	5	2	18	31	0	0	0	0	0	0	0	72.32	0	0	12
2014	7	30	5	12	18	31	0	0	0	0	0	0	0	72.25	0	0	12
2014	7	30	5	22	18	31	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	30	5	32	18	31	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	30	5	42	18	30	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	30	5	52	18	31	0	0	0	0	0	0	0	72.01	0	0	12
2014	7	30	6	2	18	31	0	0	0	0	0	0	0	71.94	0	0	12
2014	7	30	6	12	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	30	6	22	18	31	0	0	0	0	0	0	0	71.82	0	0	12
2014	7	30	6	32	18	31	0	0	0	0	0	0	0	71.78	0	0	12
2014	7	30	6	42	18	32	0	0	0	0	0	0	0	71.71	0	0	12
2014	7	30	6	52	18	31	0	0	0	0	0	0	0	71.64	0	0	12
2014	7	30	7	2	18	31	0	0	0	0	0	0	0	71.58	0	0	12
2014	7	30	7	12	18	31	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	30	7	22	18	31	0	0	0	0	0	0	0	71.38	0	0	12
2014	7	30	7	32	18	31	0	0	0	0	0	0	0	71.31	0	0	12
2014	7	30	7	42	18	31	0	0	0	0	0	0	0	71.28	0	0	12.2
2014	7	30	7	52	18	31	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	7	30	8	2	18	31	0	0	0	0	0	0	0	71.17	0	0	12.2
2014	7	30	8	12	18	31	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	7	30	8	22	18	31	0	0	0	0	0	0	0	71.02	0	0	12.2
2014	7	30	8	32	18	31	0	0	0	0	0	0	0	70.97	0	0	12.4
2014	7	30	8	42	18	31	0	0	0	0	0	0	0	70.9	0	0	12.4
2014	7	30	8	52	18	31	0	0	0	0	0	0	0	70.81	0	0	12.4
2014	7	30	9	2	18	31	0	0	0	0	0	0	0	70.81	0	0	12.4
2014	7	30	9	12	18	32	0	0	0	0	0	0	0	70.61	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	9	22	18	31	0	0	0	0	0	0	0	70.57	0	0	12.2
2014	7	30	9	32	18	32	0	0	0	0	0	0	0	70.54	0	0	12.4
2014	7	30	9	42	18	31	0	0	0	0	0	0	0	70.54	0	0	12.4
2014	7	30	9	52	18	32	0	0	0	0	0	0	0	70.52	0	0	12.6
2014	7	30	10	2	18	32	0	0	0	0	0	0	0	70.52	0	0	12.6
2014	7	30	10	12	18	32	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	30	10	22	18	31	0	0	0	0	0	0	0	70.95	0	0	13.2
2014	7	30	10	32	18	32	0	0	0	0	0	0	0	71.01	0	0	13
2014	7	30	10	42	18	31	0	0	0	0	0	0	0	71.4	0	0	13.4
2014	7	30	10	52	18	31	0	0	0	0	0	0	0	71.42	0	0	13.4
2014	7	30	11	2	18	31	0	0	0	0	0	0	0	71.56	0	0	13.2
2014	7	30	11	12	18	31	0	0	0	0	0	0	0	71.47	0	0	12.8
2014	7	30	11	22	18	31	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	30	11	32	18	31	0	0	0	0	0	0	0	71.62	0	0	12.6
2014	7	30	11	42	18	31	0	0	0	0	0	0	0	71.62	0	0	12.4
2014	7	30	11	52	18	31	0	0	0	0	0	0	0	71.58	0	0	12.4
2014	7	30	12	2	18	31	0	0	0	0	0	0	0	71.49	0	0	12.4
2014	7	30	12	12	18	31	0	0	0	0	0	0	0	71.42	0	0	12.4
2014	7	30	12	22	18	32	0	0	0	0	0	0	0	71.33	0	0	12.2
2014	7	30	12	32	18	31	0	0	0	0	0	0	0	71.24	0	0	12.2
2014	7	30	12	42	18	31	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	7	30	12	52	18	32	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	7	30	13	2	18	32	0	0	0	0	0	0	0	70.99	0	0	12.2
2014	7	30	13	12	18	30	0	0	0	0	0	0	0	70.95	0	0	12.2
2014	7	30	13	22	18	32	0	0	0	0	0	0	0	70.92	0	0	12.2
2014	7	30	13	32	18	31	0	0	0	0	0	0	0	70.9	0	0	12.2
2014	7	30	13	42	18	31	0	0	0	0	0	0	0	70.84	0	0	12.2
2014	7	30	13	52	18	31	0	0	0	0	0	0	0	70.75	0	0	12.2
2014	7	30	14	2	18	32	0	0	0	0	0	0	0	70.66	0	0	12.2
2014	7	30	14	12	18	31	0	0	0	0	0	0	0	70.59	0	0	12.2
2014	7	30	14	22	18	31	0	0	0	0	0	0	0	70.5	0	0	12
2014	7	30	14	32	18	31	0	0	0	0	0	0	0	70.41	0	0	12
2014	7	30	14	42	18	32	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	30	14	52	18	32	0	0	0	0	0	0	0	70.21	0	0	12
2014	7	30	15	2	18	31	0	0	0	0	0	0	0	70.11	0	0	12
2014	7	30	15	12	18	31	0	0	0	0	0	0	0	69.98	0	0	12
2014	7	30	15	22	18	31	0	0	0	0	0	0	0	69.85	0	0	11.8
2014	7	30	15	32	18	32	0	0	0	0	0	0	0	69.76	0	0	12
2014	7	30	15	42	18	32	0	0	0	0	0	0	0	69.66	0	0	12
2014	7	30	15	52	18	31	0	0	0	0	0	0	0	69.55	0	0	12
2014	7	30	16	2	18	32	0	0	0	0	0	0	0	69.46	0	0	12
2014	7	30	16	12	18	31	0	0	0	0	0	0	0	69.39	0	0	12
2014	7	30	16	22	18	31	0	0	0	0	0	0	0	69.33	0	0	12
2014	7	30	16	32	18	31	0	0	0	0	0	0	0	69.28	0	0	12
2014	7	30	16	42	18	32	0	0	0	0	0	0	0	69.21	0	0	12
2014	7	30	16	52	18	32	0	0	0	0	0	0	0	69.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	17	2	18	31	0	0	0	0	0	0	0	69.1	0	0	12
2014	7	30	17	12	18	31	0	0	0	0	0	0	0	69.06	0	0	12
2014	7	30	17	22	18	31	0	0	0	0	0	0	0	69.04	0	0	12
2014	7	30	17	32	18	32	0	0	0	0	0	0	0	69.03	0	0	12.2
2014	7	30	17	42	18	31	0	0	0	0	0	0	0	69.03	0	0	12.2
2014	7	30	17	52	18	32	0	0	0	0	0	0	0	68.99	0	0	12
2014	7	30	18	2	18	31	0	0	0	0	0	0	0	68.95	0	0	12
2014	7	30	18	12	18	32	0	0	0	0	0	0	0	68.94	0	0	12
2014	7	30	18	22	18	32	0	0	0	0	0	0	0	68.92	0	0	12
2014	7	30	18	32	18	31	0	0	0	0	0	0	0	68.9	0	0	12
2014	7	30	18	42	18	31	0	0	0	0	0	0	0	68.86	0	0	12
2014	7	30	18	52	18	31	0	0	0	0	0	0	0	68.86	0	0	12
2014	7	30	19	2	18	32	0	0	0	0	0	0	0	68.83	0	0	12
2014	7	30	19	12	18	31	0	0	0	0	0	0	0	68.81	0	0	12
2014	7	30	19	22	18	31	0	0	0	0	0	0	0	68.77	0	0	11.8
2014	7	30	19	32	18	32	0	0	0	0	0	0	0	68.74	0	0	12
2014	7	30	19	42	18	32	0	0	0	0	0	0	0	68.74	0	0	12
2014	7	30	19	52	18	31	0	0	0	0	0	0	0	68.72	0	0	12
2014	7	30	20	2	18	32	0	0	0	0	0	0	0	68.7	0	0	12
2014	7	30	20	12	18	32	0	0	0	0	0	0	0	68.7	0	0	12
2014	7	30	20	22	18	31	0	0	0	0	0	0	0	68.7	0	0	11.8
2014	7	30	20	32	18	32	0	0	0	0	0	0	0	68.68	0	0	12
2014	7	30	20	42	18	31	0	0	0	0	0	0	0	68.67	0	0	12
2014	7	30	20	52	18	32	0	0	0	0	0	0	0	68.65	0	0	12
2014	7	30	21	2	18	32	0	0	0	0	0	0	0	68.61	0	0	12
2014	7	30	21	12	18	31	0	0	0	0	0	0	0	68.56	0	0	12
2014	7	30	21	22	18	31	0	0	0	0	0	0	0	68.52	0	0	11.8
2014	7	30	21	32	18	31	0	0	0	0	0	0	0	68.47	0	0	12
2014	7	30	21	42	18	31	0	0	0	0	0	0	0	68.43	0	0	12
2014	7	30	21	52	18	32	0	0	0	0	0	0	0	68.36	0	0	12
2014	7	30	22	2	18	32	0	0	0	0	0	0	0	68.31	0	0	12
2014	7	30	22	12	18	31	0	0	0	0	0	0	0	68.25	0	0	12
2014	7	30	22	22	18	31	0	0	0	0	0	0	0	68.18	0	0	11.8
2014	7	30	22	32	18	32	0	0	0	0	0	0	0	68.14	0	0	12
2014	7	30	22	42	18	32	0	0	0	0	0	0	0	68.09	0	0	12
2014	7	30	22	52	18	33	0	0	0	0	0	0	0	68.04	0	0	12
2014	7	30	23	2	18	32	0	0	0	0	0	0	0	67.98	0	0	12
2014	7	30	23	12	18	32	0	0	0	0	0	0	0	67.93	0	0	12
2014	7	30	23	22	18	31	0	0	0	0	0	0	0	67.87	0	0	11.8
2014	7	30	23	32	18	31	0	0	0	0	0	0	0	67.84	0	0	12
2014	7	30	23	42	18	32	0	0	0	0	0	0	0	67.77	0	0	12
2014	7	30	23	52	18	32	0	0	0	0	0	0	0	67.71	0	0	12
2014	7	31	0	2	18	32	0	0	0	0	0	0	0	67.66	0	0	11.8
2014	7	31	0	12	18	31	0	0	0	0	0	0	0	67.59	0	0	11.8
2014	7	31	0	22	18	31	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	7	31	0	32	18	32	0	0	0	0	0	0	0	67.42	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	0	42	18	32	0	0	0	0	0	0	0	67.33	0	0	11.8
2014	7	31	0	52	18	32	0	0	0	0	0	0	0	67.24	0	0	11.8
2014	7	31	1	2	18	32	0	0	0	0	0	0	0	67.15	0	0	11.8
2014	7	31	1	12	18	32	0	0	0	0	0	0	0	67.06	0	0	11.8
2014	7	31	1	22	18	32	0	0	0	0	0	0	0	66.97	0	0	11.8
2014	7	31	1	32	18	31	0	0	0	0	0	0	0	66.88	0	0	11.8
2014	7	31	1	42	18	32	0	0	0	0	0	0	0	66.81	0	0	11.8
2014	7	31	1	52	18	32	0	0	0	0	0	0	0	66.72	0	0	11.8
2014	7	31	2	2	18	32	0	0	0	0	0	0	0	66.63	0	0	11.8
2014	7	31	2	12	18	32	0	0	0	0	0	0	0	66.54	0	0	11.8
2014	7	31	2	22	18	32	0	0	0	0	0	0	0	66.43	0	0	11.8
2014	7	31	2	32	18	31	0	0	0	0	0	0	0	66.36	0	0	11.8
2014	7	31	2	42	18	31	0	0	0	0	0	0	0	66.27	0	0	11.8
2014	7	31	2	52	18	32	0	0	0	0	0	0	0	66.18	0	0	11.8
2014	7	31	3	2	18	32	0	0	0	0	0	0	0	66.09	0	0	11.8
2014	7	31	3	12	18	32	0	0	0	0	0	0	0	66	0	0	11.8
2014	7	31	3	22	18	32	0	0	0	0	0	0	0	65.91	0	0	11.8
2014	7	31	3	32	18	33	0	0	0	0	0	0	0	65.84	0	0	11.8
2014	7	31	3	42	18	31	0	0	0	0	0	0	0	65.77	0	0	11.8
2014	7	31	3	52	18	32	0	0	0	0	0	0	0	65.68	0	0	11.8
2014	7	31	4	2	18	32	0	0	0	0	0	0	0	65.62	0	0	11.8
2014	7	31	4	12	18	33	0	0	0	0	0	0	0	65.53	0	0	11.8
2014	7	31	4	22	18	33	0	0	0	0	0	0	0	65.48	0	0	11.8
2014	7	31	4	32	18	32	0	0	0	0	0	0	0	65.41	0	0	11.8
2014	7	31	4	42	18	32	0	0	0	0	0	0	0	65.35	0	0	11.8
2014	7	31	4	52	18	32	0	0	0	0	0	0	0	65.28	0	0	11.8
2014	7	31	5	2	18	31	0	0	0	0	0	0	0	65.21	0	0	11.8
2014	7	31	5	12	18	32	0	0	0	0	0	0	0	65.14	0	0	11.8
2014	7	31	5	22	18	32	0	0	0	0	0	0	0	65.08	0	0	11.8
2014	7	31	5	32	18	32	0	0	0	0	0	0	0	65.01	0	0	11.8
2014	7	31	5	42	18	32	0	0	0	0	0	0	0	64.94	0	0	11.8
2014	7	31	5	52	18	32	0	0	0	0	0	0	0	64.87	0	0	11.8
2014	7	31	6	2	18	31	0	0	0	0	0	0	0	64.81	0	0	11.8
2014	7	31	6	12	18	32	0	0	0	0	0	0	0	64.74	0	0	11.8
2014	7	31	6	22	18	32	0	0	0	0	0	0	0	64.69	0	0	11.8
2014	7	31	6	32	18	32	0	0	0	0	0	0	0	64.63	0	0	11.8
2014	7	31	6	42	18	32	0	0	0	0	0	0	0	64.56	0	0	12
2014	7	31	6	52	18	32	0	0	0	0	0	0	0	64.53	0	0	12
2014	7	31	7	2	18	32	0	0	0	0	0	0	0	64.47	0	0	12
2014	7	31	7	12	18	32	0	0	0	0	0	0	0	64.45	0	0	12.2
2014	7	31	7	22	18	32	0	0	0	0	0	0	0	64.51	0	0	12.2
2014	7	31	7	32	18	32	0	0	0	0	0	0	0	64.56	0	0	12.4
2014	7	31	7	42	18	32	0	0	0	0	0	0	0	64.44	0	0	12.4
2014	7	31	7	52	18	32	0	0	0	0	0	0	0	64.4	0	0	12.6
2014	7	31	8	2	18	33	0	0	0	0	0	0	0	64.44	0	0	12.8
2014	7	31	8	12	18	31	0	0	0	0	0	0	0	64.76	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	8	22	18	32	0	0	0	0	0	0	0	64.89	0	0	12.8
2014	7	31	8	32	18	31	0	0	0	0	0	0	0	64.98	0	0	13
2014	7	31	8	42	18	32	0	0	0	0	0	0	0	65.12	0	0	13
2014	7	31	8	52	18	32	0	0	0	0	0	0	0	65.21	0	0	13
2014	7	31	9	2	18	32	0	0	0	0	0	0	0	65.37	0	0	13.2
2014	7	31	9	12	18	32	0	0	0	0	0	0	0	65.48	0	0	13.2
2014	7	31	9	22	18	32	0	0	0	0	0	0	0	65.66	0	0	13.2
2014	7	31	9	32	18	33	0	0	0	0	0	0	0	65.82	0	0	13.2
2014	7	31	9	42	18	31	0	0	0	0	0	0	0	66.04	0	0	13.2
2014	7	31	9	52	18	32	0	0	0	0	0	0	0	66.22	0	0	13.2
2014	7	31	10	2	18	32	0	0	0	0	0	0	0	66.45	0	0	13.4
2014	7	31	10	12	18	32	0	0	0	0	0	0	0	66.67	0	0	13.4
2014	7	31	10	22	18	32	0	0	0	0	0	0	0	66.96	0	0	13.4
2014	7	31	10	32	18	31	0	0	0	0	0	0	0	67.23	0	0	13.4
2014	7	31	10	42	18	32	0	0	0	0	0	0	0	67.51	0	0	13.4
2014	7	31	10	52	18	32	0	0	0	0	0	0	0	67.84	0	0	13.4
2014	7	31	11	2	18	32	0	0	0	0	0	0	0	68.13	0	0	13.4
2014	7	31	11	12	18	31	0	0	0	0	0	0	0	68.49	0	0	13.4
2014	7	31	11	22	18	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2014	7	31	11	32	18	31	0	0	0	0	0	0	0	69.22	0	0	13.4
2014	7	31	11	42	18	32	0	0	0	0	0	0	0	68.99	0	0	13.4
2014	7	31	11	52	18	32	0	0	0	0	0	0	0	69.28	0	0	13.4
2014	7	31	12	2	18	31	0	0	0	0	0	0	0	69.66	0	0	13.4
2014	7	31	12	12	18	32	0	0	0	0	0	0	0	70.09	0	0	13.2
2014	7	31	12	22	18	32	0	0	0	0	0	0	0	70.52	0	0	13.2
2014	7	31	12	32	18	31	0	0	0	0	0	0	0	71.01	0	0	13.2
2014	7	31	12	42	18	31	0	0	0	0	0	0	0	71.47	0	0	13.2
2014	7	31	12	52	18	31	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	31	13	2	18	32	0	0	0	0	0	0	0	73.08	0	0	13.2
2014	7	31	13	12	18	31	0	0	0	0	0	0	0	73.67	0	0	13.2
2014	7	31	13	22	18	31	0	0	0	0	0	0	0	74.17	0	0	13.2
2014	7	31	13	32	18	31	0	0	0	0	0	0	0	74.7	0	0	13.2
2014	7	31	13	42	18	31	0	0	0	0	0	0	0	75.16	0	0	13.2
2014	7	31	13	52	18	31	0	0	0	0	0	0	0	75.63	0	0	13.2
2014	7	31	14	2	18	31	0	0	0	0	0	0	0	76.08	0	0	13.2
2014	7	31	14	12	18	30	0	0	0	0	0	0	0	76.33	0	0	13
2014	7	31	14	22	18	30	0	0	0	0	0	0	0	76.98	0	0	13.2
2014	7	31	14	32	18	30	0	0	0	0	0	0	0	77.11	0	0	13
2014	7	31	14	42	18	30	0	0	0	0	0	0	0	77.5	0	0	12.8
2014	7	31	14	52	18	31	0	0	0	0	0	0	0	78.04	0	0	13.2
2014	7	31	15	2	18	31	0	0	0	0	0	0	0	78.08	0	0	12.8
2014	7	31	15	12	18	30	0	0	0	0	0	0	0	78.55	0	0	13.2
2014	7	31	15	22	18	31	0	0	0	0	0	0	0	78.6	0	0	12.6
2014	7	31	15	32	18	30	0	0	0	0	0	0	0	78.78	0	0	12.6
2014	7	31	15	42	18	30	0	0	0	0	0	0	0	78.91	0	0	12.6
2014	7	31	15	52	18	30	0	0	0	0	0	0	0	79.02	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	16	2	18	30	0	0	0	0	0	0	0	79.07	0	0	12.4
2014	7	31	16	12	18	31	0	0	0	0	0	0	0	79.12	0	0	12.4
2014	7	31	16	22	18	30	0	0	0	0	0	0	0	79.14	0	0	12.4
2014	7	31	16	32	18	30	0	0	0	0	0	0	0	79.18	0	0	12.4
2014	7	31	16	42	18	30	0	0	0	0	0	0	0	79.21	0	0	12.6
2014	7	31	16	52	18	30	0	0	0	0	0	0	0	79.32	0	0	12.6
2014	7	31	17	2	18	30	0	0	0	0	0	0	0	79.3	0	0	12.4
2014	7	31	17	12	18	30	0	0	0	0	0	0	0	79.27	0	0	12.4
2014	7	31	17	22	18	30	0	0	0	0	0	0	0	79.25	0	0	12.4
2014	7	31	17	32	18	31	0	0	0	0	0	0	0	79.18	0	0	12.4
2014	7	31	17	42	18	30	0	0	0	0	0	0	0	79.07	0	0	12.4
2014	7	31	17	52	18	30	0	0	0	0	0	0	0	78.98	0	0	12.4
2014	7	31	18	2	18	31	0	0	0	0	0	0	0	78.87	0	0	12.4
2014	7	31	18	12	18	30	0	0	0	0	0	0	0	78.76	0	0	12.4
2014	7	31	18	22	18	30	0	0	0	0	0	0	0	78.66	0	0	12.2
2014	7	31	18	32	18	30	0	0	0	0	0	0	0	78.53	0	0	12.2
2014	7	31	18	42	18	31	0	0	0	0	0	0	0	78.42	0	0	12.2
2014	7	31	18	52	18	31	0	0	0	0	0	0	0	78.33	0	0	12.2
2014	7	31	19	2	18	31	0	0	0	0	0	0	0	78.24	0	0	12.2
2014	7	31	19	12	18	30	0	0	0	0	0	0	0	78.15	0	0	12.2
2014	7	31	19	22	18	30	0	0	0	0	0	0	0	78.06	0	0	12.2
2014	7	31	19	32	18	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2014	7	31	19	42	18	31	0	0	0	0	0	0	0	77.94	0	0	12.2
2014	7	31	19	52	18	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2014	7	31	20	2	18	30	0	0	0	0	0	0	0	77.76	0	0	12.2
2014	7	31	20	12	18	31	0	0	0	0	0	0	0	77.65	0	0	12.2
2014	7	31	20	22	18	30	0	0	0	0	0	0	0	77.54	0	0	12
2014	7	31	20	32	18	30	0	0	0	0	0	0	0	77.43	0	0	12.2
2014	7	31	20	42	18	31	0	0	0	0	0	0	0	77.32	0	0	12.2
2014	7	31	20	52	18	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2014	7	31	21	2	18	30	0	0	0	0	0	0	0	77.13	0	0	12.2
2014	7	31	21	12	18	30	0	0	0	0	0	0	0	77.04	0	0	12.2
2014	7	31	21	22	18	31	0	0	0	0	0	0	0	76.93	0	0	12
2014	7	31	21	32	18	30	0	0	0	0	0	0	0	76.84	0	0	12.2
2014	7	31	21	42	18	31	0	0	0	0	0	0	0	76.75	0	0	12.2
2014	7	31	21	52	18	31	0	0	0	0	0	0	0	76.64	0	0	12.2
2014	7	31	22	2	18	31	0	0	0	0	0	0	0	76.55	0	0	12
2014	7	31	22	12	18	30	0	0	0	0	0	0	0	76.42	0	0	12
2014	7	31	22	22	18	31	0	0	0	0	0	0	0	76.33	0	0	12
2014	7	31	22	32	18	31	0	0	0	0	0	0	0	76.23	0	0	12
2014	7	31	22	42	18	31	0	0	0	0	0	0	0	76.12	0	0	12
2014	7	31	22	52	18	30	0	0	0	0	0	0	0	76.01	0	0	12
2014	7	31	23	2	18	31	0	0	0	0	0	0	0	75.9	0	0	12
2014	7	31	23	12	18	31	0	0	0	0	0	0	0	75.76	0	0	12
2014	7	31	23	22	18	30	0	0	0	0	0	0	0	75.63	0	0	12
2014	7	31	23	32	18	31	0	0	0	0	0	0	0	75.52	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	23	42	18	32	0	0	0	0	0	0	0	75.38	0	0	12
2014	7	31	23	52	18	31	0	0	0	0	0	0	0	75.24	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	0	0	9	0.3	1	0.4	82.4	6.4284	2.2373
2014	7	1	0	10	9	0.3	1	0.29	65.2	6.4284	1.4916
2014	7	1	0	20	9	0.3	1	0.22	96	6.4284	1.2492
2014	7	1	0	30	9	0.3	1	0.34	87.3	6.409	1.9514
2014	7	1	0	40	9	0.3	1	0.29	76.1	6.409	1.5797
2014	7	1	0	50	9	0.3	1	0.29	78.8	6.409	1.5983
2014	7	1	1	0	9	0.3	1	0.24	90	6.409	1.3752
2014	7	1	1	10	9	0.3	1	0.29	90	6.409	1.6168
2014	7	1	1	20	9	0.3	1	0.28	89.3	6.409	1.5983
2014	7	1	1	30	9	0.3	1	0.28	90.7	6.409	1.5983
2014	7	1	1	40	9	0.3	1	0.3	101.2	6.409	1.6912
2014	7	1	1	50	9	0.3	1	0.28	94	6.409	1.5797
2014	7	1	2	0	9	0.3	1	0.26	86.3	6.409	1.4496
2014	7	1	2	10	9	0.3	1	0.3	86.2	6.409	1.6912
2014	7	1	2	20	9	0.3	1	0.34	84.5	6.409	1.9142
2014	7	1	2	30	9	0.3	1	0.28	98.9	6.3897	1.5375
2014	7	1	2	40	9	0.3	1	0.29	88	6.409	1.6355
2014	7	1	2	50	9	0.3	1	0.34	81.6	6.3897	1.8895
2014	7	1	3	0	9	0.3	1	0.24	77.5	6.3897	1.3338
2014	7	1	3	10	9	0.3	1	0.31	91.8	6.3897	1.7598
2014	7	1	3	20	9	0.3	1	0.31	89.4	6.3897	1.7228
2014	7	1	3	30	9	0.3	1	0.28	88.7	6.3897	1.5746
2014	7	1	3	40	9	0.3	1	0.27	75.3	6.3897	1.482
2014	7	1	3	50	9	0.3	1	0.26	95	6.3897	1.482
2014	7	1	4	0	9	0.3	1	0.28	103.4	6.3897	1.5561
2014	7	1	4	10	9	0.3	1	0.31	91.2	6.3897	1.7413
2014	7	1	4	20	9	0.3	1	0.31	93	6.3897	1.7598
2014	7	1	4	30	9	0.3	1	0.29	88.7	6.3897	1.6487
2014	7	1	4	40	9	0.3	1	0.29	93.9	6.3897	1.6487
2014	7	1	4	50	9	0.3	1	0.29	86.1	6.3897	1.6302
2014	7	1	5	0	9	0.3	1	0.29	81.4	6.3897	1.5931
2014	7	1	5	10	9	0.3	1	0.33	87.1	6.3897	1.834
2014	7	1	5	20	9	0.3	1	0.26	95.9	6.3897	1.4449
2014	7	1	5	30	9	0.3	1	0.33	99.1	6.3703	1.8465
2014	7	1	5	40	9	0.3	1	0.26	87.8	6.3703	1.4403
2014	7	1	5	50	9	0.3	1	0.33	88.3	6.3703	1.8649
2014	7	1	6	0	9	0.3	1	0.32	93	6.3703	1.7726
2014	7	1	6	10	9	0.3	1	0.24	88.4	6.3703	1.3479
2014	7	1	6	20	9	0.3	1	0.24	91.6	6.3703	1.3479
2014	7	1	6	30	9	0.3	1	0.25	94.5	6.3703	1.4218
2014	7	1	6	40	9	0.3	1	0.33	86.5	6.3703	1.828
2014	7	1	6	50	9	0.3	1	0.24	82.2	6.3703	1.3479
2014	7	1	7	0	9	0.3	1	0.32	91.2	6.3703	1.7911
2014	7	1	7	10	9	0.3	1	0.34	92.2	6.3703	1.9204
2014	7	1	7	20	9	0.3	1	0.29	81	6.3509	1.6196
2014	7	1	7	30	9	0.3	1	0.31	80.1	6.3509	1.6932

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	7	40	9	0.3	1	0.21	84.6	6.3703	1.1818
2014	7	1	7	50	9	0.3	1	0.32	90	6.3509	1.7853
2014	7	1	8	0	9	0.3	1	0.23	84.3	6.3509	1.2883
2014	7	1	8	10	9	0.3	1	0.35	86.2	6.3509	1.9325
2014	7	1	8	20	9	0.3	1	0.28	89.3	6.3509	1.5828
2014	7	1	8	30	9	0.3	1	0.23	82.5	6.3509	1.2515
2014	7	1	8	40	9	0.3	1	0.31	85.7	6.3509	1.73
2014	7	1	8	50	9	0.3	1	0.27	87.9	6.3509	1.4908
2014	7	1	9	0	9	0.3	1	0.29	95.9	6.3509	1.6012
2014	7	1	9	10	9	0.3	1	0.27	85.2	6.3509	1.5276
2014	7	1	9	20	9	0.3	1	0.27	87.2	6.3509	1.5276
2014	7	1	9	30	9	0.3	1	0.28	94.1	6.3509	1.546
2014	7	1	9	40	9	0.3	1	0.24	83.8	6.3316	1.3575
2014	7	1	9	50	9	0.3	1	0.26	82	6.3316	1.4309
2014	7	1	10	0	9	0.3	1	0.32	103	6.3316	1.7427
2014	7	1	10	10	9	0.3	1	0.29	86.1	6.3316	1.6143
2014	7	1	10	20	9	0.3	1	0.35	93.2	6.3316	1.9812
2014	7	1	10	30	9	0.3	1	0.29	92.6	6.3316	1.6326
2014	7	1	10	40	9	0.3	1	0.34	93.9	6.3316	1.9078
2014	7	1	10	50	9	0.3	1	0.35	90.5	6.3122	1.9564
2014	7	1	11	0	9	0.3	1	0.27	87.9	6.3122	1.5175
2014	7	1	11	10	9	0.3	1	0.25	87	6.3122	1.4078
2014	7	1	11	20	9	0.3	1	0.29	84.1	6.2929	1.5854
2014	7	1	11	30	9	0.3	1	0.36	81.6	6.2929	1.9681
2014	7	1	11	40	9	0.3	1	0.24	72.8	6.2735	1.2896
2014	7	1	11	50	9	0.3	1	0.31	63.2	6.2735	1.5438
2014	7	1	12	0	9	0.3	1	0.36	76.8	6.2542	1.937
2014	7	1	12	10	9	0.3	1	0.3	89.4	6.2542	1.6292
2014	7	1	12	20	9	0.3	1	0.29	82.1	6.2348	1.5697
2014	7	1	12	30	9	0.3	1	0.29	79.6	6.2348	1.5697
2014	7	1	12	40	9	0.3	1	0.29	67.2	6.2348	1.4614
2014	7	1	12	50	9	0.3	1	0.37	78.8	6.2348	2.0027
2014	7	1	13	0	9	0.3	1	0.32	73.1	6.2348	1.6599
2014	7	1	13	10	9	0.3	1	0.38	68.3	6.2348	1.9485
2014	7	1	13	20	9	0.3	1	0.39	72.9	6.2154	2.0499
2014	7	1	13	30	9	0.3	1	0.43	69.5	6.2348	2.2191
2014	7	1	13	40	9	0.3	1	0.35	67.8	6.2154	1.7622
2014	7	1	13	50	9	0.3	1	0.34	74.4	6.2154	1.7981
2014	7	1	14	0	9	0.3	1	0.43	70.1	6.2154	2.2297
2014	7	1	14	10	9	0.3	1	0.29	75.5	6.2154	1.5284
2014	7	1	14	20	9	0.3	1	0.3	79.2	6.2154	1.6003
2014	7	1	14	30	9	0.3	1	0.37	79.8	6.2154	1.9959
2014	7	1	14	40	9	0.3	1	0.32	80.4	6.2154	1.7082
2014	7	1	14	50	9	0.3	1	0.34	79.5	6.2154	1.8521
2014	7	1	15	0	9	0.3	1	0.31	72.5	6.2154	1.6003
2014	7	1	15	10	9	0.3	1	0.29	67.5	6.2154	1.4745

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	15	20	9	0.3	1	0.28	85.2	6.2154	1.5104
2014	7	1	15	30	9	0.3	1	0.31	77.7	6.1961	1.6487
2014	7	1	15	40	9	0.3	1	0.21	58.7	6.2154	1.007
2014	7	1	15	50	9	0.3	1	0.32	79.9	6.1961	1.7025
2014	7	1	16	0	9	0.3	1	0.27	64.4	6.1961	1.3082
2014	7	1	16	10	9	0.3	1	0.28	75	6.1961	1.4695
2014	7	1	16	20	9	0.3	1	0.3	85	6.1961	1.6487
2014	7	1	16	30	9	0.3	1	0.31	82.7	6.1961	1.6846
2014	7	1	16	40	9	0.3	1	0.32	77	6.1961	1.7025
2014	7	1	16	50	9	0.3	1	0.35	71.4	6.1961	1.81
2014	7	1	17	0	9	0.3	1	0.3	79.2	6.1961	1.595
2014	7	1	17	10	9	0.3	1	0.26	78.6	6.1961	1.4158
2014	7	1	17	20	9	0.3	1	0.26	77.7	6.1961	1.3978
2014	7	1	17	30	9	0.3	1	0.38	75.8	6.1961	1.9892
2014	7	1	17	40	9	0.3	1	0.26	70.4	6.1961	1.362
2014	7	1	17	50	9	0.3	1	0.3	75.4	6.1767	1.5718
2014	7	1	18	0	9	0.3	1	0.28	79.8	6.1767	1.4825
2014	7	1	18	10	9	0.3	1	0.26	65	6.1767	1.3039
2014	7	1	18	20	9	0.3	1	0.23	87.6	6.1767	1.2681
2014	7	1	18	30	9	0.3	1	0.28	73.5	6.1767	1.4468
2014	7	1	18	40	9	0.3	1	0.23	100.8	6.1767	1.2146
2014	7	1	18	50	9	0.3	1	0.26	93.6	6.1767	1.4289
2014	7	1	19	0	9	0.3	1	0.33	87.1	6.1767	1.7683
2014	7	1	19	10	9	0.3	1	0.25	81.5	6.1767	1.3217
2014	7	1	19	20	9	0.3	1	0.23	97.3	6.1767	1.2503
2014	7	1	19	30	9	0.3	1	0.27	69.8	6.1767	1.3575
2014	7	1	19	40	9	0.3	1	0.28	75.6	6.1767	1.4646
2014	7	1	19	50	9	0.3	1	0.22	94.3	6.1767	1.1789
2014	7	1	20	0	9	0.3	1	0.23	82.7	6.1767	1.2503
2014	7	1	20	10	9	0.3	1	0.25	100.7	6.1961	1.3262
2014	7	1	20	20	9	0.3	1	0.24	89.2	6.1767	1.3039
2014	7	1	20	30	9	0.3	1	0.24	95.6	6.1961	1.2904
2014	7	1	20	40	9	0.3	1	0.19	96	6.1767	1.0181
2014	7	1	20	50	9	0.3	1	0.21	88.2	6.1961	1.1649
2014	7	1	21	0	9	0.3	1	0.26	82.1	6.1767	1.4111
2014	7	1	21	10	9	0.3	1	0.29	101.1	6.1767	1.554
2014	7	1	21	20	9	0.3	1	0.2	86.3	6.1961	1.1112
2014	7	1	21	30	9	0.3	1	0.29	100.9	6.1961	1.5771
2014	7	1	21	40	9	0.3	1	0.19	83.1	6.1961	1.0395
2014	7	1	21	50	9	0.3	1	0.23	85	6.1961	1.2366
2014	7	1	22	0	9	0.3	1	0.24	81.4	6.1961	1.3083
2014	7	1	22	10	9	0.3	1	0.23	99.1	6.1961	1.2366
2014	7	1	22	20	9	0.3	1	0.25	89.2	6.1961	1.3621
2014	7	1	22	30	9	0.3	1	0.23	93.3	6.1961	1.2545
2014	7	1	22	40	9	0.3	1	0.17	92.2	6.1961	0.914
2014	7	1	22	50	9	0.3	1	0.28	84.7	6.1961	1.5413

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	23	0	9	0.3	1	0.25	86.3	6.1961	1.38
2014	7	1	23	10	9	0.3	1	0.2	91.9	6.1961	1.0753
2014	7	1	23	20	9	0.3	1	0.21	74.7	6.1961	1.1112
2014	7	1	23	30	9	0.3	1	0.22	58.2	6.1961	1.0395
2014	7	1	23	40	9	0.3	1	0.27	86.5	6.1961	1.4696
2014	7	1	23	50	9	0.3	1	0.25	68.5	6.1961	1.2725
2014	7	2	0	0	9	0.3	1	0.21	104.3	6.2154	1.1329
2014	7	2	0	10	9	0.3	1	0.2	78	6.2154	1.0969
2014	7	2	0	20	9	0.3	1	0.31	74.6	6.2154	1.6364
2014	7	2	0	30	9	0.3	1	0.23	76.2	6.2154	1.2408
2014	7	2	0	40	9	0.3	1	0.22	102.8	6.2154	1.1868
2014	7	2	0	50	9	0.3	1	0.26	92.2	6.2154	1.4026
2014	7	2	1	0	9	0.3	1	0.31	87.6	6.2154	1.6904
2014	7	2	1	10	9	0.3	1	0.32	92.4	6.2154	1.7443
2014	7	2	1	20	9	0.3	1	0.31	93.1	6.2154	1.6724
2014	7	2	1	30	9	0.3	1	0.24	84.5	6.2154	1.3127
2014	7	2	1	40	9	0.3	1	0.24	83.8	6.2154	1.3307
2014	7	2	1	50	9	0.3	1	0.21	90	6.2154	1.1689
2014	7	2	2	0	9	0.3	1	0.23	94.9	6.2154	1.2588
2014	7	2	2	10	9	0.3	1	0.23	85.9	6.2154	1.2588
2014	7	2	2	20	9	0.3	1	0.26	88.6	6.2154	1.4386
2014	7	2	2	30	9	0.3	1	0.25	106	6.2154	1.3127
2014	7	2	2	40	9	0.3	1	0.37	82.4	6.2154	2.0141
2014	7	2	2	50	9	0.3	1	0.22	83.3	6.2154	1.2228
2014	7	2	3	0	9	0.3	1	0.33	91.7	6.2154	1.7983
2014	7	2	3	10	9	0.3	1	0.21	84.6	6.2348	1.1548
2014	7	2	3	20	9	0.3	1	0.24	88.4	6.2348	1.3171
2014	7	2	3	30	9	0.3	1	0.2	79.4	6.2348	1.0645
2014	7	2	3	40	9	0.3	1	0.32	82.9	6.2348	1.7502
2014	7	2	3	50	9	0.3	1	0.25	102.4	6.2348	1.3172
2014	7	2	4	0	9	0.3	1	0.25	95.3	6.2154	1.3487
2014	7	2	4	10	9	0.3	1	0.3	68.2	6.2348	1.5337
2014	7	2	4	20	9	0.3	1	0.25	90.8	6.2348	1.3713
2014	7	2	4	30	9	0.3	1	0.3	87.5	6.2348	1.66
2014	7	2	4	40	9	0.3	1	0.24	90.8	6.2348	1.2991
2014	7	2	4	50	9	0.3	1	0.26	99.5	6.2348	1.4074
2014	7	2	5	0	9	0.3	1	0.36	85.3	6.2348	1.9667
2014	7	2	5	10	9	0.3	1	0.26	79.7	6.2348	1.3893
2014	7	2	5	20	9	0.3	1	0.25	93.8	6.2542	1.3759
2014	7	2	5	30	9	0.3	1	0.26	95	6.2542	1.4483
2014	7	2	5	40	9	0.3	1	0.26	94.3	6.2542	1.4483
2014	7	2	5	50	9	0.3	1	0.29	79.6	6.2542	1.575
2014	7	2	6	0	9	0.3	1	0.29	78.4	6.2542	1.5931
2014	7	2	6	10	9	0.3	1	0.27	83	6.2542	1.4664
2014	7	2	6	20	9	0.3	1	0.29	77.7	6.2542	1.575
2014	7	2	6	30	9	0.3	1	0.3	83.8	6.2735	1.6711

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	6	40	9	0.3	1	0.17	96.6	6.2735	0.9445
2014	7	2	6	50	9	0.3	1	0.29	90	6.2735	1.5984
2014	7	2	7	0	9	0.3	1	0.23	86.8	6.2735	1.2897
2014	7	2	7	10	9	0.3	1	0.29	79.6	6.2735	1.5803
2014	7	2	7	20	9	0.3	1	0.31	93.7	6.2735	1.7074
2014	7	2	7	30	9	0.3	1	0.31	107.1	6.2735	1.6529
2014	7	2	7	40	9	0.3	1	0.31	76.1	6.2929	1.6949
2014	7	2	7	50	9	0.3	1	0.21	96.1	6.2929	1.1846
2014	7	2	8	0	9	0.3	1	0.23	81.6	6.2929	1.2393
2014	7	2	8	10	9	0.3	1	0.31	83.9	6.2929	1.6949
2014	7	2	8	20	9	0.3	1	0.29	91.9	6.2929	1.622
2014	7	2	8	30	9	0.3	1	0.28	89.3	6.2929	1.5308
2014	7	2	8	40	9	0.3	1	0.29	90	6.2735	1.6166
2014	7	2	8	50	9	0.3	1	0.23	97.2	6.2929	1.2939
2014	7	2	9	0	9	0.3	1	0.28	90	6.2735	1.5439
2014	7	2	9	10	9	0.3	1	0.3	88.1	6.2735	1.6529
2014	7	2	9	20	9	0.3	1	0.28	79.8	6.2735	1.5076
2014	7	2	9	30	9	0.3	1	0.28	88	6.3122	1.5724
2014	7	2	9	40	9	0.3	1	0.24	98.8	6.3122	1.2982
2014	7	2	9	50	9	0.3	1	0.33	86.6	6.3316	1.8528
2014	7	2	10	0	9	0.3	1	0.35	85.6	6.3122	1.9198
2014	7	2	10	10	9	0.3	1	0.28	87.3	6.3316	1.5593
2014	7	2	10	20	9	0.3	1	0.31	69.4	6.3122	1.609
2014	7	2	10	30	9	0.3	1	0.26	74.4	6.3122	1.3713
2014	7	2	10	40	9	0.3	1	0.21	85.5	6.2929	1.1481
2014	7	2	10	50	9	0.3	1	0.33	77.9	6.2929	1.7859
2014	7	2	11	0	9	0.3	1	0.26	71.3	6.2735	1.3441
2014	7	2	11	10	9	0.3	1	0.27	83	6.2735	1.4712
2014	7	2	11	20	9	0.3	1	0.25	85.5	6.2542	1.3758
2014	7	2	11	30	9	0.3	1	0.3	83	6.2542	1.6293
2014	7	2	11	40	9	0.3	1	0.28	90	6.2542	1.5388
2014	7	2	11	50	9	0.3	1	0.28	75	6.2542	1.4844
2014	7	2	12	0	9	0.3	1	0.33	87.7	6.2348	1.7862
2014	7	2	12	10	9	0.3	1	0.29	76.9	6.2348	1.5517
2014	7	2	12	20	9	0.3	1	0.29	89.3	6.2348	1.5878
2014	7	2	12	30	9	0.3	1	0.28	79.2	6.2154	1.5105
2014	7	2	12	40	9	0.3	1	0.36	85.8	6.2154	1.9421
2014	7	2	12	50	9	0.3	1	0.31	77.7	6.2154	1.6544
2014	7	2	13	0	9	0.3	1	0.35	84.1	6.2154	1.9061
2014	7	2	13	10	9	0.3	1	0.29	82.1	6.2154	1.5644
2014	7	2	13	20	9	0.3	1	0.27	87.9	6.2154	1.4565
2014	7	2	13	30	9	0.3	1	0.31	72.7	6.2154	1.6184
2014	7	2	13	40	9	0.3	1	0.32	77.1	6.2154	1.7262
2014	7	2	13	50	9	0.3	1	0.22	80.4	6.2154	1.1688
2014	7	2	14	0	9	0.3	1	0.32	71.9	6.2154	1.6543
2014	7	2	14	10	9	0.3	1	0.31	74.1	6.2154	1.6363

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	14	20	9	0.3	1	0.31	62.6	6.2154	1.5284
2014	7	2	14	30	9	0.3	1	0.25	64.4	6.1961	1.2366
2014	7	2	14	40	9	0.3	1	0.35	69.4	6.1961	1.81
2014	7	2	14	50	9	0.3	1	0.31	73.3	6.1961	1.6129
2014	7	2	15	0	9	0.3	1	0.33	71.9	6.1961	1.7025
2014	7	2	15	10	9	0.3	1	0.32	63.2	6.1961	1.5591
2014	7	2	15	20	9	0.3	1	0.41	69.2	6.1961	2.0788
2014	7	2	15	30	9	0.3	1	0.36	70.4	6.1961	1.8638
2014	7	2	15	40	9	0.3	1	0.34	75.4	6.1961	1.7921
2014	7	2	15	50	9	0.3	1	0.35	72.6	6.1961	1.8279
2014	7	2	16	0	9	0.3	1	0.35	71.7	6.1961	1.7921
2014	7	2	16	10	9	0.3	1	0.32	67.7	6.1767	1.6075
2014	7	2	16	20	9	0.3	1	0.31	57.7	6.1961	1.4157
2014	7	2	16	30	9	0.3	1	0.32	72.7	6.1767	1.6611
2014	7	2	16	40	9	0.3	1	0.29	69.1	6.1767	1.5003
2014	7	2	16	50	9	0.3	1	0.4	79.7	6.1767	2.1611
2014	7	2	17	0	9	0.3	1	0.28	83.3	6.1767	1.5182
2014	7	2	17	10	9	0.3	1	0.27	73.6	6.1767	1.3931
2014	7	2	17	20	9	0.3	1	0.33	74.8	6.1767	1.7146
2014	7	2	17	30	9	0.3	1	0.26	77.7	6.1767	1.3931
2014	7	2	17	40	9	0.3	1	0.31	84.5	6.1767	1.6611
2014	7	2	17	50	9	0.3	1	0.34	77.7	6.1767	1.8039
2014	7	2	18	0	9	0.3	1	0.31	97.9	6.1767	1.6789
2014	7	2	18	10	9	0.3	1	0.27	80.8	6.1574	1.4241
2014	7	2	18	20	9	0.3	1	0.29	78	6.1574	1.5131
2014	7	2	18	30	9	0.3	1	0.29	84.7	6.1574	1.5487
2014	7	2	18	40	9	0.3	1	0.3	91.9	6.1574	1.6021
2014	7	2	18	50	9	0.3	1	0.29	97.9	6.1574	1.5487
2014	7	2	19	0	9	0.3	1	0.32	87	6.1574	1.7267
2014	7	2	19	10	9	0.3	1	0.24	74.3	6.1574	1.2639
2014	7	2	19	20	9	0.3	1	0.29	86.8	6.1574	1.5843
2014	7	2	19	30	9	0.3	1	0.27	79.4	6.1574	1.4241
2014	7	2	19	40	9	0.3	1	0.25	46.6	6.1574	0.979
2014	7	2	19	50	9	0.3	1	0.25	64.8	6.1574	1.2105
2014	7	2	20	0	9	0.3	1	0.29	93.2	6.1574	1.5843
2014	7	2	20	10	9	0.3	1	0.21	90	6.1574	1.1571
2014	7	2	20	20	9	0.3	1	0.28	80.4	6.1574	1.4775
2014	7	2	20	30	9	0.3	1	0.23	90	6.1574	1.2639
2014	7	2	20	40	9	0.3	1	0.22	90	6.1574	1.2105
2014	7	2	20	50	9	0.3	1	0.3	98.2	6.1574	1.6021
2014	7	2	21	0	9	0.3	1	0.33	90	6.1767	1.7861
2014	7	2	21	10	9	0.3	1	0.2	98.5	6.1767	1.0717
2014	7	2	21	20	9	0.3	1	0.23	106.9	6.1767	1.1788
2014	7	2	21	30	9	0.3	1	0.22	85.8	6.1767	1.2146
2014	7	2	21	40	9	0.3	1	0.25	92.3	6.1767	1.3396
2014	7	2	21	50	9	0.3	1	0.24	77.1	6.1767	1.2503

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	22	0	9	0.3	1	0.29	74.1	6.1767	1.5004
2014	7	2	22	10	9	0.3	1	0.22	90	6.1767	1.1789
2014	7	2	22	20	9	0.3	1	0.17	96.7	6.1767	0.9109
2014	7	2	22	30	9	0.3	1	0.24	85.3	6.1767	1.3039
2014	7	2	22	40	9	0.3	1	0.24	82.9	6.1767	1.286
2014	7	2	22	50	9	0.3	1	0.22	78.2	6.1767	1.1967
2014	7	2	23	0	9	0.3	1	0.26	91.5	6.1767	1.4111
2014	7	2	23	10	9	0.3	1	0.2	86.3	6.1961	1.1112
2014	7	2	23	20	9	0.3	1	0.24	75.8	6.1961	1.2725
2014	7	2	23	30	9	0.3	1	0.23	92.4	6.1961	1.2725
2014	7	2	23	40	9	0.3	1	0.25	96.7	6.1961	1.38
2014	7	2	23	50	9	0.3	1	0.26	90	6.1961	1.4338
2014	7	3	0	0	9	0.3	1	0.23	90.8	6.1961	1.2366
2014	7	3	0	10	9	0.3	1	0.26	88.6	6.1961	1.4338
2014	7	3	0	20	9	0.3	1	0.24	94.6	6.1961	1.3262
2014	7	3	0	30	9	0.3	1	0.23	89.2	6.1961	1.2725
2014	7	3	0	40	9	0.3	1	0.3	90	6.1961	1.6309
2014	7	3	0	50	9	0.3	1	0.26	93.7	6.1961	1.3979
2014	7	3	1	0	9	0.3	1	0.25	80.9	6.1961	1.3442
2014	7	3	1	10	9	0.3	1	0.25	78.5	6.1961	1.3262
2014	7	3	1	20	9	0.3	1	0.19	92	6.1961	1.0395
2014	7	3	1	30	9	0.3	1	0.28	86.6	6.1961	1.5055
2014	7	3	1	40	9	0.3	1	0.22	87.4	6.1961	1.1829
2014	7	3	1	50	9	0.3	1	0.21	75.5	6.1961	1.1112
2014	7	3	2	0	9	0.3	1	0.22	70.8	6.1961	1.1291
2014	7	3	2	10	9	0.3	1	0.3	83.7	6.1961	1.613
2014	7	3	2	20	9	0.3	1	0.22	100.2	6.1961	1.2008
2014	7	3	2	30	9	0.3	1	0.2	79.8	6.1961	1.0933
2014	7	3	2	40	9	0.3	1	0.23	90	6.1961	1.2546
2014	7	3	2	50	9	0.3	1	0.28	72.8	6.1961	1.4517
2014	7	3	3	0	9	0.3	1	0.24	92.3	6.1961	1.3263
2014	7	3	3	10	9	0.3	1	0.24	93.1	6.1961	1.3083
2014	7	3	3	20	9	0.3	1	0.24	85.4	6.1961	1.3263
2014	7	3	3	30	9	0.3	1	0.26	87.8	6.1961	1.4159
2014	7	3	3	40	9	0.3	1	0.31	99.2	6.1961	1.6668
2014	7	3	3	50	9	0.3	1	0.29	83.5	6.1961	1.5772
2014	7	3	4	0	9	0.3	1	0.31	80.3	6.1961	1.6847
2014	7	3	4	10	9	0.3	1	0.3	95	6.1961	1.631
2014	7	3	4	20	9	0.3	1	0.28	80	6.1961	1.5234
2014	7	3	4	30	9	0.3	1	0.26	88.6	6.1961	1.4338
2014	7	3	4	40	9	0.3	1	0.34	84.5	6.1961	1.864
2014	7	3	4	50	9	0.3	1	0.27	85.8	6.1961	1.4518
2014	7	3	5	0	9	0.3	1	0.32	85.9	6.1961	1.7385
2014	7	3	5	10	9	0.3	1	0.25	95.3	6.1961	1.3442
2014	7	3	5	20	9	0.3	1	0.31	83.9	6.1961	1.6848
2014	7	3	5	30	9	0.3	1	0.22	95.2	6.1961	1.1829

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	5	40	9	0.3	1	0.26	95	6.1961	1.4338
2014	7	3	5	50	9	0.3	1	0.2	90	6.1961	1.0933
2014	7	3	6	0	9	0.3	1	0.23	97.3	6.1961	1.2546
2014	7	3	6	10	9	0.3	1	0.2	88.1	6.1961	1.0933
2014	7	3	6	20	9	0.3	1	0.31	82.7	6.1961	1.6848
2014	7	3	6	30	9	0.3	1	0.24	98.8	6.1961	1.2725
2014	7	3	6	40	9	0.3	1	0.25	86.2	6.1961	1.3622
2014	7	3	6	50	9	0.3	1	0.28	86.6	6.1961	1.5055
2014	7	3	7	0	9	0.3	1	0.28	89.3	6.1961	1.5056
2014	7	3	7	10	9	0.3	1	0.29	104.3	6.1961	1.5414
2014	7	3	7	20	9	0.3	1	0.22	98.5	6.1961	1.2009
2014	7	3	7	30	9	0.3	1	0.24	107.2	6.1961	1.2726
2014	7	3	7	40	9	0.3	1	0.3	96.8	6.1961	1.6489
2014	7	3	7	50	9	0.3	1	0.29	83	6.1961	1.5952
2014	7	3	8	0	9	0.3	1	0.29	82.9	6.1961	1.5772
2014	7	3	8	10	9	0.3	1	0.18	93.1	6.1961	0.9858
2014	7	3	8	20	9	0.3	1	0.31	96.6	6.1961	1.7027
2014	7	3	8	30	9	0.3	1	0.26	81.1	6.1961	1.3801
2014	7	3	8	40	9	0.3	1	0.32	88.8	6.1961	1.7744
2014	7	3	8	50	9	0.3	1	0.28	79.8	6.1961	1.4876
2014	7	3	9	0	9	0.3	1	0.25	87.7	6.1961	1.3622
2014	7	3	9	10	9	0.3	1	0.23	68.5	6.1961	1.1829
2014	7	3	9	20	9	0.3	1	0.31	72.5	6.1961	1.5952
2014	7	3	9	30	9	0.3	1	0.22	89.1	6.1961	1.2008
2014	7	3	9	40	9	0.3	1	0.26	90	6.1961	1.398
2014	7	3	9	50	9	0.3	1	0.2	93.8	6.1961	1.0754
2014	7	3	10	0	9	0.3	1	0.18	73.5	6.1961	0.9678
2014	7	3	10	10	9	0.3	1	0.27	98.3	6.1961	1.4697
2014	7	3	10	20	9	0.3	1	0.29	80.9	6.1961	1.5593
2014	7	3	10	30	9	0.3	1	0.22	82.3	6.1961	1.2008
2014	7	3	10	40	9	0.3	1	0.31	96.7	6.1961	1.6668
2014	7	3	10	50	9	0.3	1	0.29	84.2	6.1961	1.5951
2014	7	3	11	0	9	0.3	1	0.33	87.8	6.1961	1.8281
2014	7	3	11	10	9	0.3	1	0.29	86.7	6.1961	1.5593
2014	7	3	11	20	9	0.3	1	0.28	76.6	6.1767	1.5004
2014	7	3	11	30	9	0.3	1	0.31	89.4	6.1961	1.7026
2014	7	3	11	40	9	0.3	1	0.32	83.6	6.1767	1.7505
2014	7	3	11	50	9	0.3	1	0.33	75.5	6.1767	1.7326
2014	7	3	12	0	9	0.3	1	0.25	80.8	6.1767	1.3218
2014	7	3	12	10	9	0.3	1	0.34	84	6.1767	1.8577
2014	7	3	12	20	9	0.3	1	0.28	72.4	6.1767	1.4647
2014	7	3	12	30	9	0.3	1	0.29	81.4	6.1767	1.5361
2014	7	3	12	40	9	0.3	1	0.34	79	6.1767	1.8398
2014	7	3	12	50	9	0.3	1	0.26	83.5	6.1767	1.4111
2014	7	3	13	0	9	0.3	1	0.32	77.7	6.1767	1.7147
2014	7	3	13	10	9	0.3	1	0.27	76	6.1767	1.4289

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	13	20	9	0.3	1	0.28	86.7	6.1574	1.5309
2014	7	3	13	30	9	0.3	1	0.23	85.1	6.1574	1.2461
2014	7	3	13	40	9	0.3	1	0.36	80.6	6.1767	1.9469
2014	7	3	13	50	9	0.3	1	0.27	79.4	6.1574	1.4241
2014	7	3	14	0	9	0.3	1	0.28	82.5	6.1574	1.4953
2014	7	3	14	10	9	0.3	1	0.31	68.3	6.1574	1.5665
2014	7	3	14	20	9	0.3	1	0.37	63.7	6.1574	1.7979
2014	7	3	14	30	9	0.3	1	0.35	79.7	6.138	1.8628
2014	7	3	14	40	9	0.3	1	0.21	70.7	6.138	1.0644
2014	7	3	14	50	9	0.3	1	0.28	79.1	6.138	1.4725
2014	7	3	15	0	9	0.3	1	0.31	77.7	6.1187	1.6266
2014	7	3	15	10	9	0.3	1	0.31	74.5	6.1187	1.5912
2014	7	3	15	20	9	0.3	1	0.34	79.4	6.0993	1.7973
2014	7	3	15	30	9	0.3	1	0.23	72.1	6.0993	1.1982
2014	7	3	15	40	9	0.3	1	0.32	83.6	6.08	1.7209
2014	7	3	15	50	9	0.3	1	0.3	58.9	6.08	1.3697
2014	7	3	16	0	9	0.3	1	0.3	76.6	6.0606	1.54
2014	7	3	16	10	9	0.3	1	0.24	70.6	6.0606	1.19
2014	7	3	16	20	9	0.3	1	0.2	68.6	6.0412	0.9766
2014	7	3	16	30	9	0.3	1	0.33	76.8	6.0412	1.7091
2014	7	3	16	40	9	0.3	1	0.28	70.9	6.0412	1.4126
2014	7	3	16	50	9	0.3	1	0.28	55.6	6.0412	1.2208
2014	7	3	17	0	9	0.3	1	0.28	90	6.0412	1.4649
2014	7	3	17	10	9	0.3	1	0.24	87.6	6.0412	1.2731
2014	7	3	17	20	9	0.3	1	0.22	75.3	6.0412	1.1336
2014	7	3	17	30	9	0.3	1	0.3	80.5	6.0412	1.5696
2014	7	3	17	40	9	0.3	1	0.32	80.4	6.0219	1.6511
2014	7	3	17	50	9	0.3	1	0.26	49.2	6.0219	1.0254
2014	7	3	18	0	9	0.3	1	0.24	90	6.0219	1.2513
2014	7	3	18	10	9	0.3	1	0.18	84.9	6.0219	0.9733
2014	7	3	18	20	9	0.3	1	0.28	85.3	6.0219	1.4947
2014	7	3	18	30	9	0.3	1	0.26	80.4	6.0219	1.3382
2014	7	3	18	40	9	0.3	1	0.19	90	6.0219	1.0254
2014	7	3	18	50	9	0.3	1	0.21	69.9	6.0219	1.0428
2014	7	3	19	0	9	0.3	1	0.16	76	6.0025	0.8314
2014	7	3	19	10	9	0.3	1	0.19	81	6.0025	0.9872
2014	7	3	19	20	9	0.3	1	0.27	71.6	6.0025	1.3509
2014	7	3	19	30	9	0.3	1	0.18	77.7	6.0025	0.9526
2014	7	3	19	40	9	0.3	1	0.22	96.1	6.0219	1.1471
2014	7	3	19	50	9	0.3	1	0.24	91.6	6.0219	1.2514
2014	7	3	20	0	9	0.3	1	0.2	76.9	6.0025	1.0392
2014	7	3	20	10	9	0.3	1	0.2	92.8	6.0025	1.0565
2014	7	3	20	20	9	0.3	1	0.22	68.4	6.0219	1.0949
2014	7	3	20	30	9	0.3	1	0.23	67.8	6.0025	1.1431
2014	7	3	20	40	9	0.3	1	0.2	79.4	6.0025	1.0219
2014	7	3	20	50	9	0.3	1	0.26	72	6.0025	1.2817

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	21	0	9	0.3	1	0.21	112.1	6.0025	1.0219
2014	7	3	21	10	9	0.3	1	0.24	98.8	6.0025	1.2297
2014	7	3	21	20	9	0.3	1	0.28	98.7	6.0219	1.4773
2014	7	3	21	30	9	0.3	1	0.22	70.2	6.0219	1.1123
2014	7	3	21	40	9	0.3	1	0.16	84.2	6.0219	0.8516
2014	7	3	21	50	9	0.3	1	0.23	90	6.0219	1.234
2014	7	3	22	0	9	0.3	1	0.27	74.4	6.0219	1.3731
2014	7	3	22	10	9	0.3	1	0.22	75.3	6.0219	1.1297
2014	7	3	22	20	9	0.3	1	0.22	84	6.0219	1.1645
2014	7	3	22	30	9	0.3	1	0.29	90	6.0412	1.5522
2014	7	3	22	40	9	0.3	1	0.24	93.1	6.0412	1.2906
2014	7	3	22	50	9	0.3	1	0.27	94.1	6.0412	1.4476
2014	7	3	23	0	9	0.3	1	0.2	71.6	6.0412	0.9941
2014	7	3	23	10	9	0.3	1	0.18	90	6.0606	0.98
2014	7	3	23	20	9	0.3	1	0.27	88.6	6.0606	1.4176
2014	7	3	23	30	9	0.3	1	0.27	80.8	6.0606	1.4001
2014	7	3	23	40	9	0.3	1	0.22	79.7	6.08	1.159
2014	7	3	23	50	9	0.3	1	0.25	94.5	6.08	1.3522
2014	7	4	0	0	9	0.3	1	0.19	85.1	6.08	1.0185
2014	7	4	0	10	9	0.3	1	0.19	91	6.0993	1.0397
2014	7	4	0	20	9	0.3	1	0.22	85.8	6.0993	1.1982
2014	7	4	0	30	9	0.3	1	0.19	90	6.0993	1.022
2014	7	4	0	40	9	0.3	1	0.16	94.8	6.0993	0.8458
2014	7	4	0	50	9	0.3	1	0.24	104	6.1187	1.2731
2014	7	4	1	0	9	0.3	1	0.23	74.2	6.1187	1.1847
2014	7	4	1	10	9	0.3	1	0.28	90.7	6.1187	1.5206
2014	7	4	1	20	9	0.3	1	0.21	81.9	6.1187	1.1139
2014	7	4	1	30	9	0.3	1	0.19	90	6.1187	1.0255
2014	7	4	1	40	9	0.3	1	0.19	85	6.1187	1.0079
2014	7	4	1	50	9	0.3	1	0.27	90	6.1187	1.4676
2014	7	4	2	0	9	0.3	1	0.24	76.7	6.1187	1.2731
2014	7	4	2	10	9	0.3	1	0.21	80.1	6.1187	1.114
2014	7	4	2	20	9	0.3	1	0.24	86	6.1187	1.2731
2014	7	4	2	30	9	0.3	1	0.24	81.4	6.1187	1.2908
2014	7	4	2	40	9	0.3	1	0.26	85	6.1187	1.4145
2014	7	4	2	50	9	0.3	1	0.29	90	6.1187	1.5383
2014	7	4	3	0	9	0.3	1	0.28	84.6	6.1187	1.503
2014	7	4	3	10	9	0.3	1	0.3	96.3	6.1187	1.6091
2014	7	4	3	20	9	0.3	1	0.18	92.1	6.138	0.9758
2014	7	4	3	30	9	0.3	1	0.17	94.5	6.138	0.9048
2014	7	4	3	40	9	0.3	1	0.22	82.3	6.1187	1.1847
2014	7	4	3	50	9	0.3	1	0.22	77.8	6.138	1.1532
2014	7	4	4	0	9	0.3	1	0.27	78.7	6.138	1.4194
2014	7	4	4	10	9	0.3	1	0.22	85.8	6.138	1.2065
2014	7	4	4	20	9	0.3	1	0.19	85.2	6.138	1.0468
2014	7	4	4	30	9	0.3	1	0.28	89.3	6.138	1.5258

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	4	40	9	0.3	1	0.19	79.1	6.138	1.0113
2014	7	4	4	50	9	0.3	1	0.33	88.3	6.138	1.792
2014	7	4	5	0	9	0.3	1	0.24	82.1	6.138	1.2775
2014	7	4	5	10	9	0.3	1	0.28	71.6	6.138	1.4371
2014	7	4	5	20	9	0.3	1	0.25	79.4	6.138	1.3307
2014	7	4	5	30	9	0.3	1	0.23	90	6.138	1.2242
2014	7	4	5	40	9	0.3	1	0.26	78.4	6.138	1.3839
2014	7	4	5	50	9	0.3	1	0.23	76	6.138	1.2065
2014	7	4	6	0	9	0.3	1	0.28	79.3	6.138	1.5081
2014	7	4	6	10	9	0.3	1	0.23	87.6	6.138	1.2597
2014	7	4	6	20	9	0.3	1	0.18	75.2	6.138	0.9404
2014	7	4	6	30	9	0.3	1	0.24	79.1	6.138	1.2952
2014	7	4	6	40	9	0.3	1	0.26	88.5	6.138	1.3839
2014	7	4	6	50	9	0.3	1	0.3	95.7	6.138	1.5968
2014	7	4	7	0	9	0.3	1	0.25	85.5	6.138	1.3484
2014	7	4	7	10	9	0.3	1	0.26	92.2	6.138	1.4017
2014	7	4	7	20	9	0.3	1	0.2	104.9	6.138	1.0646
2014	7	4	7	30	9	0.3	1	0.21	76.2	6.1574	1.086
2014	7	4	7	40	9	0.3	1	0.23	87.6	6.138	1.2597
2014	7	4	7	50	9	0.3	1	0.3	65.4	6.138	1.4726
2014	7	4	8	0	9	0.3	1	0.26	86.3	6.138	1.3839
2014	7	4	8	10	9	0.3	1	0.26	77.7	6.138	1.3839
2014	7	4	8	20	9	0.3	1	0.23	85.9	6.138	1.242
2014	7	4	8	30	9	0.3	1	0.22	86.5	6.138	1.171
2014	7	4	8	40	9	0.3	1	0.28	71.6	6.138	1.4372
2014	7	4	8	50	9	0.3	1	0.26	76.7	6.138	1.3484
2014	7	4	9	0	9	0.3	1	0.22	85.8	6.138	1.2065
2014	7	4	9	10	9	0.3	1	0.18	83.8	6.138	0.9758
2014	7	4	9	20	9	0.3	1	0.27	79.5	6.138	1.4371
2014	7	4	9	30	9	0.3	1	0.31	63.2	6.138	1.5081
2014	7	4	9	40	9	0.3	1	0.19	89	6.138	1.0113
2014	7	4	9	50	9	0.3	1	0.28	78.6	6.138	1.4904
2014	7	4	10	0	9	0.3	1	0.21	91.8	6.138	1.1533
2014	7	4	10	10	9	0.3	1	0.24	80.7	6.138	1.2952
2014	7	4	10	20	9	0.3	1	0.21	87.3	6.138	1.1355
2014	7	4	10	30	9	0.3	1	0.32	73.1	6.138	1.6323
2014	7	4	10	40	9	0.3	1	0.27	83	6.138	1.4371
2014	7	4	10	50	9	0.3	1	0.25	85.5	6.1187	1.3438
2014	7	4	11	0	9	0.3	1	0.28	79.3	6.1187	1.503
2014	7	4	11	10	9	0.3	1	0.23	84.3	6.1187	1.2377
2014	7	4	11	20	9	0.3	1	0.2	90	6.1187	1.0963
2014	7	4	11	30	9	0.3	1	0.23	90.8	6.1187	1.2554
2014	7	4	11	40	9	0.3	1	0.2	76.9	6.1187	1.0609
2014	7	4	11	50	9	0.3	1	0.3	70.4	6.0993	1.5331
2014	7	4	12	0	9	0.3	1	0.26	78.4	6.0993	1.3745
2014	7	4	12	10	9	0.3	1	0.31	80.2	6.0993	1.6388

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	12	20	9	0.3	1	0.25	78	6.0993	1.3216
2014	7	4	12	30	9	0.3	1	0.3	81.1	6.08	1.563
2014	7	4	12	40	9	0.3	1	0.28	74.5	6.0993	1.4626
2014	7	4	12	50	9	0.3	1	0.22	63.8	6.08	1.0712
2014	7	4	13	0	9	0.3	1	0.32	80	6.0606	1.6801
2014	7	4	13	10	9	0.3	1	0.29	76.3	6.0606	1.5051
2014	7	4	13	20	9	0.3	1	0.32	68.7	6.0412	1.5697
2014	7	4	13	30	9	0.3	1	0.35	81.4	6.0412	1.8487
2014	7	4	13	40	9	0.3	1	0.29	78	6.0412	1.4825
2014	7	4	13	50	9	0.3	1	0.32	74.1	6.0412	1.6569
2014	7	4	14	0	9	0.3	1	0.33	71.4	6.0219	1.6511
2014	7	4	14	10	9	0.3	1	0.32	75.1	6.0219	1.6338
2014	7	4	14	20	9	0.3	1	0.29	78.3	6.0219	1.5121
2014	7	4	14	30	9	0.3	1	0.35	78.7	6.0219	1.8249
2014	7	4	14	40	9	0.3	1	0.24	54.4	6.0219	1.0428
2014	7	4	14	50	9	0.3	1	0.26	77.4	6.0219	1.3209
2014	7	4	15	0	9	0.3	1	0.28	90	6.0025	1.4549
2014	7	4	15	10	9	0.3	1	0.29	74.1	6.0025	1.4549
2014	7	4	15	20	9	0.3	1	0.27	85.1	6.0025	1.4029
2014	7	4	15	30	9	0.3	1	0.23	78.5	6.0025	1.1951
2014	7	4	15	40	9	0.3	1	0.27	81.6	6.0025	1.4029
2014	7	4	15	50	9	0.3	1	0.28	71.8	6.0025	1.4202
2014	7	4	16	0	9	0.3	1	0.28	80.5	6.0025	1.4549
2014	7	4	16	10	9	0.3	1	0.28	62.5	6.0025	1.299
2014	7	4	16	20	9	0.3	1	0.28	71.4	6.0025	1.3856
2014	7	4	16	30	9	0.3	1	0.27	67.8	6.0025	1.3163
2014	7	4	16	40	9	0.3	1	0.26	72	6.0025	1.2817
2014	7	4	16	50	9	0.3	1	0.25	71.3	6.0025	1.2297
2014	7	4	17	0	9	0.3	1	0.27	62.2	6.0025	1.247
2014	7	4	17	10	9	0.3	1	0.23	64.2	6.0025	1.1085
2014	7	4	17	20	9	0.3	1	0.25	69.4	6.0025	1.247
2014	7	4	17	30	9	0.3	1	0.21	70.7	5.9832	1.0356
2014	7	4	17	40	9	0.3	1	0.25	80.2	5.9832	1.2945
2014	7	4	17	50	9	0.3	1	0.27	61.6	5.9832	1.2427
2014	7	4	18	0	9	0.3	1	0.26	65	5.9638	1.2556
2014	7	4	18	10	9	0.3	1	0.29	56.8	5.9638	1.29
2014	7	4	18	20	9	0.3	1	0.33	53.6	5.9638	1.376
2014	7	4	18	30	9	0.3	1	0.2	79.6	5.9638	1.032
2014	7	4	18	40	9	0.3	1	0.31	59.9	5.9445	1.3883
2014	7	4	18	50	9	0.3	1	0.24	64.1	5.9445	1.1312
2014	7	4	19	0	9	0.3	1	0.27	72	5.9445	1.3198
2014	7	4	19	10	9	0.3	1	0.13	64.7	5.9251	0.6149
2014	7	4	19	20	9	0.3	1	0.24	64.5	5.9057	1.1063
2014	7	4	19	30	9	0.3	1	0.18	79.5	5.8864	0.9158
2014	7	4	19	40	9	0.3	1	0.22	48.1	5.8864	0.831
2014	7	4	19	50	9	0.3	1	0.16	64	5.8864	0.7293

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	20	0	9	0.3	1	0.2	79.8	5.867	1.0309
2014	7	4	20	10	9	0.3	1	0.21	79.4	5.867	1.0816
2014	7	4	20	20	9	0.3	1	0.18	71.2	5.8477	0.8925
2014	7	4	20	30	9	0.3	1	0.23	83.5	5.8283	1.1746
2014	7	4	20	40	9	0.3	1	0.21	81.7	5.8283	1.0404
2014	7	4	20	50	9	0.3	1	0.19	97	5.809	0.953
2014	7	4	21	0	9	0.3	1	0.13	82.9	5.8283	0.6712
2014	7	4	21	10	9	0.3	1	0.27	70.9	5.809	1.3042
2014	7	4	21	20	9	0.3	1	0.2	82.3	5.809	0.9865
2014	7	4	21	30	9	0.3	1	0.16	83.9	5.809	0.7859
2014	7	4	21	40	9	0.3	1	0.22	73.5	5.809	1.0701
2014	7	4	21	50	9	0.3	1	0.2	68.4	5.809	0.9698
2014	7	4	22	0	9	0.3	1	0.2	93.7	5.809	1.0367
2014	7	4	22	10	9	0.3	1	0.23	100.8	5.809	1.137
2014	7	4	22	20	9	0.3	1	0.26	76	5.809	1.2708
2014	7	4	22	30	9	0.3	1	0.18	90	5.809	0.9029
2014	7	4	22	40	9	0.3	1	0.17	90	5.809	0.8695
2014	7	4	22	50	9	0.3	1	0.26	92.2	5.809	1.3042
2014	7	4	23	0	9	0.3	1	0.12	91.5	5.809	0.6187
2014	7	4	23	10	9	0.3	1	0.15	100.3	5.7896	0.7331
2014	7	4	23	20	9	0.3	1	0.18	92.1	5.7896	0.9163
2014	7	4	23	30	9	0.3	1	0.18	114.2	5.7896	0.8164
2014	7	4	23	40	9	0.3	1	0.12	90	5.7896	0.5998
2014	7	4	23	50	9	0.3	1	0.16	79.4	5.7896	0.7997
2014	7	5	0	0	9	0.3	1	0.2	86.3	5.7896	1.033
2014	7	5	0	10	9	0.3	1	0.13	67.9	5.7896	0.6165
2014	7	5	0	20	9	0.3	1	0.16	83	5.7896	0.8164
2014	7	5	0	30	9	0.3	1	0.12	77.1	5.7896	0.5831
2014	7	5	0	40	9	0.3	1	0.18	77.2	5.7896	0.883
2014	7	5	0	50	9	0.3	1	0.14	81.9	5.809	0.7023
2014	7	5	1	0	9	0.3	1	0.14	76	5.809	0.6688
2014	7	5	1	10	9	0.3	1	0.18	106.1	5.809	0.8695
2014	7	5	1	20	9	0.3	1	0.22	80.4	5.809	1.0869
2014	7	5	1	30	9	0.3	1	0.16	83.9	5.809	0.7859
2014	7	5	1	40	9	0.3	1	0.2	74.2	5.809	1.0033
2014	7	5	1	50	9	0.3	1	0.26	81.1	5.809	1.2875
2014	7	5	2	0	9	0.3	1	0.16	65.6	5.8283	0.7384
2014	7	5	2	10	9	0.3	1	0.14	76	5.809	0.6688
2014	7	5	2	20	9	0.3	1	0.12	81.9	5.8283	0.5873
2014	7	5	2	30	9	0.3	1	0.22	85.7	5.8283	1.1243
2014	7	5	2	40	9	0.3	1	0.17	90	5.8283	0.8726
2014	7	5	2	50	9	0.3	1	0.17	96.7	5.8283	0.8558
2014	7	5	3	0	9	0.3	1	0.2	87.2	5.8477	1.0273
2014	7	5	3	10	9	0.3	1	0.19	67.1	5.8283	0.8726
2014	7	5	3	20	9	0.3	1	0.19	75	5.8283	0.9398
2014	7	5	3	30	9	0.3	1	0.13	100.4	5.8283	0.6377

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	3	40	9	0.3	1	0.19	79.3	5.8283	0.9733
2014	7	5	3	50	9	0.3	1	0.11	88.4	5.809	0.5852
2014	7	5	4	0	9	0.3	1	0.18	108.8	5.8283	0.8894
2014	7	5	4	10	9	0.3	1	0.25	80	5.8283	1.2418
2014	7	5	4	20	9	0.3	1	0.2	85.4	5.809	1.0367
2014	7	5	4	30	9	0.3	1	0.16	99.3	5.809	0.8194
2014	7	5	4	40	9	0.3	1	0.19	95.8	5.809	0.9866
2014	7	5	4	50	9	0.3	1	0.19	79.9	5.809	0.9364
2014	7	5	5	0	9	0.3	1	0.16	78	5.809	0.7859
2014	7	5	5	10	9	0.3	1	0.19	81	5.7896	0.9497
2014	7	5	5	20	9	0.3	1	0.27	83.1	5.7896	1.3829
2014	7	5	5	30	9	0.3	1	0.22	73.7	5.7896	1.083
2014	7	5	5	40	9	0.3	1	0.19	83.1	5.7896	0.9664
2014	7	5	5	50	9	0.3	1	0.18	90	5.7896	0.9331
2014	7	5	6	0	9	0.3	1	0.22	93.4	5.7896	1.1163
2014	7	5	6	10	9	0.3	1	0.15	68.9	5.7702	0.7305
2014	7	5	6	20	9	0.3	1	0.2	92.8	5.7702	1.0293
2014	7	5	6	30	9	0.3	1	0.22	94.3	5.7702	1.0957
2014	7	5	6	40	9	0.3	1	0.17	76.8	5.7702	0.8467
2014	7	5	6	50	9	0.3	1	0.18	93.2	5.7702	0.8965
2014	7	5	7	0	9	0.3	1	0.16	88.9	5.7702	0.8301
2014	7	5	7	10	9	0.3	1	0.27	99.1	5.7702	1.3448
2014	7	5	7	20	9	0.3	1	0.21	99.9	5.7702	1.0459
2014	7	5	7	30	9	0.3	1	0.23	83.4	5.7702	1.1455
2014	7	5	7	40	9	0.3	1	0.18	78.5	5.7702	0.8965
2014	7	5	7	50	9	0.3	1	0.23	95.7	5.7702	1.1621
2014	7	5	8	0	9	0.3	1	0.16	90	5.7702	0.7969
2014	7	5	8	10	9	0.3	1	0.24	82.9	5.7702	1.1953
2014	7	5	8	20	9	0.3	1	0.2	89.1	5.7702	1.0293
2014	7	5	8	30	9	0.3	1	0.18	83.7	5.7702	0.8965
2014	7	5	8	40	9	0.3	1	0.19	77.9	5.7702	0.9297
2014	7	5	8	50	9	0.3	1	0.12	94.6	5.7702	0.6143
2014	7	5	9	0	9	0.3	1	0.24	84.5	5.7702	1.2119
2014	7	5	9	10	9	0.3	1	0.18	70.9	5.7702	0.8633
2014	7	5	9	20	9	0.3	1	0.18	90	5.7702	0.9297
2014	7	5	9	30	9	0.3	1	0.28	79.1	5.7702	1.3779
2014	7	5	9	40	9	0.3	1	0.17	90	5.7702	0.8799
2014	7	5	9	50	9	0.3	1	0.22	70.2	5.7509	1.0587
2014	7	5	10	0	9	0.3	1	0.25	79.4	5.7509	1.2406
2014	7	5	10	10	9	0.3	1	0.27	66.3	5.7509	1.2406
2014	7	5	10	20	9	0.3	1	0.22	76.8	5.7509	1.0587
2014	7	5	10	30	9	0.3	1	0.18	75.2	5.7509	0.8767
2014	7	5	10	40	9	0.3	1	0.22	73.2	5.7509	1.0421
2014	7	5	10	50	9	0.3	1	0.1	75.1	5.7509	0.4962
2014	7	5	11	0	9	0.3	1	0.24	106.2	5.7509	1.1413
2014	7	5	11	10	9	0.3	1	0.21	77.3	5.7509	1.0256

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	11	20	9	0.3	1	0.23	77.6	5.7509	1.1248
2014	7	5	11	30	9	0.3	1	0.28	90	5.7702	1.4277
2014	7	5	11	40	9	0.3	1	0.23	80.9	5.7702	1.1455
2014	7	5	11	50	9	0.3	1	0.21	62.2	5.7702	0.9463
2014	7	5	12	0	9	0.3	1	0.21	74.9	5.7702	1.0459
2014	7	5	12	10	9	0.3	1	0.22	70.2	5.7702	1.0625
2014	7	5	12	20	9	0.3	1	0.19	89	5.7896	0.9663
2014	7	5	12	30	9	0.3	1	0.27	71.3	5.7896	1.2829
2014	7	5	12	40	9	0.3	1	0.22	81.4	5.809	1.1036
2014	7	5	12	50	9	0.3	1	0.2	83.6	5.809	1.0367
2014	7	5	13	0	9	0.3	1	0.2	73.4	5.8283	0.9565
2014	7	5	13	10	9	0.3	1	0.21	81	5.8477	1.0609
2014	7	5	13	20	9	0.3	1	0.26	58.9	5.867	1.1492
2014	7	5	13	30	9	0.3	1	0.18	82.5	5.8864	0.8989
2014	7	5	13	40	9	0.3	1	0.2	76.7	5.9057	1.0042
2014	7	5	13	50	9	0.3	1	0.31	77	5.9057	1.5488
2014	7	5	14	0	9	0.3	1	0.25	76.1	5.9251	1.2468
2014	7	5	14	10	9	0.3	1	0.24	81.2	5.9251	1.2127
2014	7	5	14	20	9	0.3	1	0.23	81.1	5.9445	1.1998
2014	7	5	14	30	9	0.3	1	0.25	73.7	5.9445	1.2341
2014	7	5	14	40	9	0.3	1	0.29	66.9	5.9445	1.4055
2014	7	5	14	50	9	0.3	1	0.36	62.3	5.9445	1.6625
2014	7	5	15	0	9	0.3	1	0.26	82	5.9638	1.3416
2014	7	5	15	10	9	0.3	1	0.3	65.4	5.9638	1.4276
2014	7	5	15	20	9	0.3	1	0.3	62.6	5.9638	1.3932
2014	7	5	15	30	9	0.3	1	0.29	66.6	5.9638	1.3932
2014	7	5	15	40	9	0.3	1	0.25	58.8	5.9638	1.1352
2014	7	5	15	50	9	0.3	1	0.26	52.7	5.9832	1.0873
2014	7	5	16	0	9	0.3	1	0.18	62.5	5.9832	0.863
2014	7	5	16	10	9	0.3	1	0.33	72.6	5.9832	1.6569
2014	7	5	16	20	9	0.3	1	0.29	65.8	5.9832	1.3807
2014	7	5	16	30	9	0.3	1	0.32	68.4	5.9832	1.5706
2014	7	5	16	40	9	0.3	1	0.29	62.9	6.0025	1.3855
2014	7	5	16	50	9	0.3	1	0.24	65.2	6.0025	1.1604
2014	7	5	17	0	9	0.3	1	0.31	63.7	6.0025	1.4721
2014	7	5	17	10	9	0.3	1	0.2	69.8	6.0025	0.9872
2014	7	5	17	20	9	0.3	1	0.28	67.6	6.0025	1.3855
2014	7	5	17	30	9	0.3	1	0.3	62.6	6.0025	1.4029
2014	7	5	17	40	9	0.3	1	0.19	74.3	6.0025	0.9872
2014	7	5	17	50	9	0.3	1	0.28	57.6	6.0025	1.2297
2014	7	5	18	0	9	0.3	1	0.26	66	6.0025	1.247
2014	7	5	18	10	9	0.3	1	0.26	67.3	6.0025	1.2816
2014	7	5	18	20	9	0.3	1	0.31	78.5	6.0025	1.6107
2014	7	5	18	30	9	0.3	1	0.28	66.7	6.0025	1.3682
2014	7	5	18	40	9	0.3	1	0.27	66.9	6.0025	1.299
2014	7	5	18	50	9	0.3	1	0.27	64.4	6.0025	1.2643

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	19	0	9	0.3	1	0.32	61.1	6.0219	1.4773
2014	7	5	19	10	9	0.3	1	0.29	71.4	6.0025	1.4375
2014	7	5	19	20	9	0.3	1	0.23	64.2	6.0025	1.0738
2014	7	5	19	30	9	0.3	1	0.17	49	6.0025	0.6581
2014	7	5	19	40	9	0.3	1	0.27	78	6.0025	1.3856
2014	7	5	19	50	9	0.3	1	0.21	68.7	6.0025	1.0219
2014	7	5	20	0	9	0.3	1	0.24	82.9	6.0219	1.2513
2014	7	5	20	10	9	0.3	1	0.2	55.2	6.0219	0.8516
2014	7	5	20	20	9	0.3	1	0.21	81.7	6.0219	1.0776
2014	7	5	20	30	9	0.3	1	0.26	80.5	6.0219	1.3556
2014	7	5	20	40	9	0.3	1	0.2	80.5	6.0219	1.0428
2014	7	5	20	50	9	0.3	1	0.2	79.8	6.0219	1.0602
2014	7	5	21	0	9	0.3	1	0.22	74.3	6.0412	1.1162
2014	7	5	21	10	9	0.3	1	0.3	77.8	6.0412	1.5347
2014	7	5	21	20	9	0.3	1	0.22	88.3	6.0412	1.1685
2014	7	5	21	30	9	0.3	1	0.24	92.4	6.0606	1.2775
2014	7	5	21	40	9	0.3	1	0.23	80.1	6.0606	1.2075
2014	7	5	21	50	9	0.3	1	0.2	75.1	6.08	1.0536
2014	7	5	22	0	9	0.3	1	0.19	91	6.0993	1.022
2014	7	5	22	10	9	0.3	1	0.28	92.7	6.0993	1.5154
2014	7	5	22	20	9	0.3	1	0.19	79.9	6.1187	0.9901
2014	7	5	22	30	9	0.3	1	0.24	82.9	6.138	1.2773
2014	7	5	22	40	9	0.3	1	0.22	101.1	6.138	1.1709
2014	7	5	22	50	9	0.3	1	0.15	83.8	6.138	0.8161
2014	7	5	23	0	9	0.3	1	0.23	92.4	6.138	1.2596
2014	7	5	23	10	9	0.3	1	0.25	90	6.1574	1.3529
2014	7	5	23	20	9	0.3	1	0.28	74.5	6.1574	1.4775
2014	7	5	23	30	9	0.3	1	0.27	97.7	6.1574	1.4419
2014	7	5	23	40	9	0.3	1	0.27	88.6	6.1574	1.4597
2014	7	5	23	50	9	0.3	1	0.25	84.7	6.1574	1.3351
2014	7	6	0	0	9	0.3	1	0.24	90	6.1574	1.2995
2014	7	6	0	10	9	0.3	1	0.21	100.8	6.1767	1.1253
2014	7	6	0	20	9	0.3	1	0.27	80.2	6.1767	1.4468
2014	7	6	0	30	9	0.3	1	0.23	94.9	6.1767	1.2503
2014	7	6	0	40	9	0.3	1	0.23	89.2	6.1767	1.2325
2014	7	6	0	50	9	0.3	1	0.22	95.2	6.1767	1.1789
2014	7	6	1	0	9	0.3	1	0.27	102.5	6.1767	1.4468
2014	7	6	1	10	9	0.3	1	0.22	94.2	6.1767	1.2146
2014	7	6	1	20	9	0.3	1	0.27	117.8	6.1961	1.2904
2014	7	6	1	30	9	0.3	1	0.26	78.6	6.1961	1.4158
2014	7	6	1	40	9	0.3	1	0.25	82.4	6.1961	1.3441
2014	7	6	1	50	9	0.3	1	0.29	86.7	6.1961	1.5592
2014	7	6	2	0	9	0.3	1	0.24	88.5	6.1961	1.3262
2014	7	6	2	10	9	0.3	1	0.25	88.5	6.1961	1.38
2014	7	6	2	20	9	0.3	1	0.28	92	6.1961	1.5234
2014	7	6	2	30	9	0.3	1	0.3	90	6.1961	1.613

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	2	40	9	0.3	1	0.27	85.8	6.1961	1.4517
2014	7	6	2	50	9	0.3	1	0.26	81.9	6.1961	1.38
2014	7	6	3	0	9	0.3	1	0.29	91.3	6.1961	1.5592
2014	7	6	3	10	9	0.3	1	0.3	93.2	6.1961	1.613
2014	7	6	3	20	9	0.3	1	0.27	76.5	6.2154	1.4206
2014	7	6	3	30	9	0.3	1	0.25	104.4	6.1961	1.3262
2014	7	6	3	40	9	0.3	1	0.27	90.7	6.1961	1.4517
2014	7	6	3	50	9	0.3	1	0.3	83.8	6.1961	1.6488
2014	7	6	4	0	9	0.3	1	0.25	94.6	6.1961	1.3442
2014	7	6	4	10	9	0.3	1	0.22	84	6.2154	1.2048
2014	7	6	4	20	9	0.3	1	0.26	70.6	6.1961	1.3262
2014	7	6	4	30	9	0.3	1	0.3	82	6.2154	1.6544
2014	7	6	4	40	9	0.3	1	0.27	97	6.2154	1.4566
2014	7	6	4	50	9	0.3	1	0.26	90	6.2154	1.4386
2014	7	6	5	0	9	0.3	1	0.28	88.6	6.2154	1.5105
2014	7	6	5	10	9	0.3	1	0.25	93	6.2154	1.3846
2014	7	6	5	20	9	0.3	1	0.25	86.2	6.2154	1.3667
2014	7	6	5	30	9	0.3	1	0.25	93.8	6.2154	1.3667
2014	7	6	5	40	9	0.3	1	0.29	98.6	6.2154	1.5465
2014	7	6	5	50	9	0.3	1	0.25	91.5	6.2154	1.3846
2014	7	6	6	0	9	0.3	1	0.21	79	6.2154	1.1149
2014	7	6	6	10	9	0.3	1	0.23	89.2	6.2154	1.2768
2014	7	6	6	20	9	0.3	1	0.29	77.5	6.2154	1.5465
2014	7	6	6	30	9	0.3	1	0.37	109.1	6.2154	1.9241
2014	7	6	6	40	9	0.3	1	0.34	85.1	6.2154	1.8702
2014	7	6	6	50	9	0.3	1	0.25	94.5	6.2154	1.3847
2014	7	6	7	0	9	0.3	1	0.27	92.1	6.2154	1.4926
2014	7	6	7	10	9	0.3	1	0.23	74.4	6.2154	1.2228
2014	7	6	7	20	9	0.3	1	0.3	81.1	6.2154	1.6004
2014	7	6	7	30	9	0.3	1	0.24	101.6	6.2154	1.3127
2014	7	6	7	40	9	0.3	1	0.32	87	6.2154	1.7443
2014	7	6	7	50	9	0.3	1	0.22	99.6	6.1961	1.165
2014	7	6	8	0	9	0.3	1	0.24	86.1	6.2154	1.3127
2014	7	6	8	10	9	0.3	1	0.24	68.1	6.2154	1.2048
2014	7	6	8	20	9	0.3	1	0.26	82.1	6.2154	1.4206
2014	7	6	8	30	9	0.3	1	0.21	101.5	6.2154	1.1509
2014	7	6	8	40	9	0.3	1	0.26	88.5	6.2154	1.4206
2014	7	6	8	50	9	0.3	1	0.31	90	6.2154	1.6724
2014	7	6	9	0	9	0.3	1	0.31	71.2	6.2154	1.5825
2014	7	6	9	10	9	0.3	1	0.25	83.2	6.2154	1.3487
2014	7	6	9	20	9	0.3	1	0.34	89.4	6.2154	1.8522
2014	7	6	9	30	9	0.3	1	0.27	75.1	6.2154	1.4206
2014	7	6	9	40	9	0.3	1	0.34	77.6	6.2154	1.7983
2014	7	6	9	50	9	0.3	1	0.27	82.4	6.2154	1.4746
2014	7	6	10	0	9	0.3	1	0.31	89.4	6.2154	1.7263
2014	7	6	10	10	9	0.3	1	0.27	62.2	6.2154	1.2948

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	10	20	9	0.3	1	0.34	82.3	6.2154	1.8702
2014	7	6	10	30	9	0.3	1	0.31	80.1	6.2154	1.6544
2014	7	6	10	40	9	0.3	1	0.3	86.2	6.2154	1.6184
2014	7	6	10	50	9	0.3	1	0.35	64.9	6.2154	1.7263
2014	7	6	11	0	9	0.3	1	0.26	90	6.2154	1.4386
2014	7	6	11	10	9	0.3	1	0.33	83.8	6.2154	1.8162
2014	7	6	11	20	9	0.3	1	0.27	77.2	6.2154	1.4206
2014	7	6	11	30	9	0.3	1	0.3	79.9	6.2154	1.6184
2014	7	6	11	40	9	0.3	1	0.31	85.2	6.2154	1.7083
2014	7	6	11	50	9	0.3	1	0.3	83.7	6.2154	1.6184
2014	7	6	12	0	9	0.3	1	0.25	88.5	6.2154	1.3846
2014	7	6	12	10	9	0.3	1	0.28	84.6	6.2154	1.5285
2014	7	6	12	20	9	0.3	1	0.27	68.1	6.2154	1.3846
2014	7	6	12	30	9	0.3	1	0.3	88.1	6.2154	1.6184
2014	7	6	12	40	9	0.3	1	0.37	83.8	6.2154	1.996
2014	7	6	12	50	9	0.3	1	0.29	86.7	6.1961	1.5592
2014	7	6	13	0	9	0.3	1	0.28	78.6	6.2154	1.5105
2014	7	6	13	10	9	0.3	1	0.27	78.1	6.2154	1.4565
2014	7	6	13	20	9	0.3	1	0.28	73.5	6.2154	1.4565
2014	7	6	13	30	9	0.3	1	0.32	83.6	6.2154	1.7622
2014	7	6	13	40	9	0.3	1	0.3	85	6.2154	1.6543
2014	7	6	13	50	9	0.3	1	0.34	83.9	6.2154	1.8521
2014	7	6	14	0	9	0.3	1	0.23	76.2	6.2154	1.2407
2014	7	6	14	10	9	0.3	1	0.29	90	6.2154	1.6004
2014	7	6	14	20	9	0.3	1	0.27	95.6	6.2154	1.4745
2014	7	6	14	30	9	0.3	1	0.25	79.3	6.2154	1.3306
2014	7	6	14	40	9	0.3	1	0.28	89.3	6.1961	1.5233
2014	7	6	14	50	9	0.3	1	0.31	67.3	6.1961	1.5412
2014	7	6	15	0	9	0.3	1	0.39	77.5	6.1961	2.0968
2014	7	6	15	10	9	0.3	1	0.3	75.2	6.1961	1.5591
2014	7	6	15	20	9	0.3	1	0.25	71.3	6.1961	1.2724
2014	7	6	15	30	9	0.3	1	0.23	79.2	6.1961	1.2186
2014	7	6	15	40	9	0.3	1	0.32	74.4	6.1961	1.6666
2014	7	6	15	50	9	0.3	1	0.31	72.1	6.1961	1.6129
2014	7	6	16	0	9	0.3	1	0.3	78.8	6.1961	1.6308
2014	7	6	16	10	9	0.3	1	0.27	69.4	6.1961	1.3799
2014	7	6	16	20	9	0.3	1	0.25	76.9	6.1961	1.3082
2014	7	6	16	30	9	0.3	1	0.28	68.2	6.1961	1.4337
2014	7	6	16	40	9	0.3	1	0.29	69.7	6.138	1.4902
2014	7	6	16	50	9	0.3	1	0.3	59.5	6.1767	1.3931
2014	7	6	17	0	9	0.3	1	0.32	47.1	6.1767	1.2681
2014	7	6	17	10	9	0.3	1	0.29	57	6.1767	1.3217
2014	7	6	17	20	9	0.3	1	0.39	56.4	6.1767	1.7503
2014	7	6	17	30	9	0.3	1	0.48	43	6.1767	1.7682
2014	7	6	17	40	9	0.3	1	0.44	47.1	6.1767	1.7682
2014	7	6	17	50	9	0.3	1	0.47	36.1	6.1767	1.5003

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	18	0	9	0.3	1	0.42	38	6.1767	1.411
2014	7	6	18	10	9	0.3	1	0.4	41.6	6.1767	1.4289
2014	7	6	18	20	9	0.3	1	0.49	37.9	6.1767	1.6253
2014	7	6	18	30	9	0.3	1	0.47	41.1	6.1767	1.6968
2014	7	6	18	40	9	0.3	1	0.54	39.1	6.1574	1.8513
2014	7	6	18	50	9	0.3	1	0.44	36.9	6.1574	1.4418
2014	7	6	19	0	9	0.3	1	0.35	45	6.1767	1.3396
2014	7	6	19	10	9	0.3	1	0.41	42.1	6.1767	1.4824
2014	7	6	19	20	9	0.3	1	0.36	60.8	6.1574	1.6911
2014	7	6	19	30	9	0.3	1	0.33	55.5	6.1767	1.4824
2014	7	6	19	40	9	0.3	1	0.29	62	6.1574	1.4063
2014	7	6	19	50	9	0.3	1	0.31	51.5	6.1767	1.3038
2014	7	6	20	0	9	0.3	1	0.3	64.3	6.1767	1.4825
2014	7	6	20	10	9	0.3	1	0.37	70.8	6.1767	1.8933
2014	7	6	20	20	9	0.3	1	0.29	61.4	6.1767	1.3753
2014	7	6	20	30	9	0.3	1	0.28	65.5	6.1767	1.411
2014	7	6	20	40	9	0.3	1	0.3	81.3	6.1767	1.6253
2014	7	6	20	50	9	0.3	1	0.2	74.8	6.1767	1.0538
2014	7	6	21	0	9	0.3	1	0.24	87.6	6.1767	1.3039
2014	7	6	21	10	9	0.3	1	0.24	76.5	6.1767	1.2681
2014	7	6	21	20	9	0.3	1	0.22	86.6	6.1961	1.2007
2014	7	6	21	30	9	0.3	1	0.25	71.6	6.1961	1.2903
2014	7	6	21	40	9	0.3	1	0.2	73.7	6.1767	1.0359
2014	7	6	21	50	9	0.3	1	0.25	96.1	6.1961	1.3441
2014	7	6	22	0	9	0.3	1	0.23	90	6.1961	1.2545
2014	7	6	22	10	9	0.3	1	0.22	84.8	6.1961	1.1828
2014	7	6	22	20	9	0.3	1	0.22	104.4	6.1961	1.1828
2014	7	6	22	30	9	0.3	1	0.28	97.9	6.1961	1.5412
2014	7	6	22	40	9	0.3	1	0.24	84.4	6.1961	1.2904
2014	7	6	22	50	9	0.3	1	0.27	79.6	6.1961	1.4696
2014	7	6	23	0	9	0.3	1	0.26	70.4	6.1961	1.362
2014	7	6	23	10	9	0.3	1	0.26	70.4	6.1961	1.362
2014	7	6	23	20	9	0.3	1	0.29	91.3	6.1961	1.5592
2014	7	6	23	30	9	0.3	1	0.23	78.5	6.1961	1.2366
2014	7	6	23	40	9	0.3	1	0.28	75	6.1961	1.4696
2014	7	6	23	50	9	0.3	1	0.31	72.9	6.1961	1.6309
2014	7	7	0	0	9	0.3	1	0.28	72.8	6.1961	1.4517
2014	7	7	0	10	9	0.3	1	0.34	71	6.1961	1.7743
2014	7	7	0	20	9	0.3	1	0.29	74.9	6.1961	1.5234
2014	7	7	0	30	9	0.3	1	0.26	66.7	6.1961	1.2904
2014	7	7	0	40	9	0.3	1	0.28	86	6.1961	1.5234
2014	7	7	0	50	9	0.3	1	0.33	77.5	6.1961	1.7743
2014	7	7	1	0	9	0.3	1	0.32	77.4	6.1961	1.6847
2014	7	7	1	10	9	0.3	1	0.29	64.3	6.1961	1.4158
2014	7	7	1	20	9	0.3	1	0.34	87.3	6.1961	1.8818
2014	7	7	1	30	9	0.3	1	0.32	74.1	6.1961	1.7026

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	1	40	9	0.3	1	0.3	64.3	6.1961	1.4875
2014	7	7	1	50	9	0.3	1	0.3	79.9	6.1961	1.613
2014	7	7	2	0	9	0.3	1	0.25	61.8	6.1961	1.2008
2014	7	7	2	10	9	0.3	1	0.33	73.9	6.1961	1.7384
2014	7	7	2	20	9	0.3	1	0.34	67.2	6.1961	1.7026
2014	7	7	2	30	9	0.3	1	0.24	75.8	6.1961	1.2725
2014	7	7	2	40	9	0.3	1	0.27	74.6	6.1961	1.4338
2014	7	7	2	50	9	0.3	1	0.28	64	6.1961	1.3621
2014	7	7	3	0	9	0.3	1	0.29	86.7	6.2154	1.5644
2014	7	7	3	10	9	0.3	1	0.29	85.4	6.2154	1.5644
2014	7	7	3	20	9	0.3	1	0.26	86.4	6.2154	1.4386
2014	7	7	3	30	9	0.3	1	0.3	93.2	6.2154	1.6184
2014	7	7	3	40	9	0.3	1	0.32	87	6.2154	1.7443
2014	7	7	3	50	9	0.3	1	0.34	90	6.2154	1.8881
2014	7	7	4	0	9	0.3	1	0.27	76.1	6.2154	1.4566
2014	7	7	4	10	9	0.3	1	0.24	82.3	6.2154	1.3307
2014	7	7	4	20	9	0.3	1	0.23	86	6.2154	1.2767
2014	7	7	4	30	9	0.3	1	0.23	92.5	6.2154	1.2408
2014	7	7	4	40	9	0.3	1	0.26	75.3	6.2154	1.3667
2014	7	7	4	50	9	0.3	1	0.37	76.8	6.2154	1.996
2014	7	7	5	0	9	0.3	1	0.25	83.2	6.2154	1.3487
2014	7	7	5	10	9	0.3	1	0.23	94.8	6.2154	1.2767
2014	7	7	5	20	9	0.3	1	0.3	93.2	6.2154	1.6184
2014	7	7	5	30	9	0.3	1	0.24	86	6.2154	1.2947
2014	7	7	5	40	9	0.3	1	0.25	69.2	6.2154	1.2767
2014	7	7	5	50	9	0.3	1	0.27	94.1	6.2154	1.4925
2014	7	7	6	0	9	0.3	1	0.32	83.6	6.2154	1.7623
2014	7	7	6	10	9	0.3	1	0.26	75.3	6.2154	1.3667
2014	7	7	6	20	9	0.3	1	0.29	83	6.2154	1.6004
2014	7	7	6	30	9	0.3	1	0.3	88.1	6.2154	1.6184
2014	7	7	6	40	9	0.3	1	0.26	91.5	6.2154	1.4206
2014	7	7	6	50	9	0.3	1	0.29	83	6.2154	1.6004
2014	7	7	7	0	9	0.3	1	0.27	87.9	6.2154	1.4566
2014	7	7	7	10	9	0.3	1	0.28	60.4	6.2154	1.3307
2014	7	7	7	20	9	0.3	1	0.32	101.2	6.2348	1.7321
2014	7	7	7	30	9	0.3	1	0.28	87.3	6.2154	1.5105
2014	7	7	7	40	9	0.3	1	0.28	66.7	6.2154	1.4206
2014	7	7	7	50	9	0.3	1	0.26	86.4	6.2154	1.4386
2014	7	7	8	0	9	0.3	1	0.24	87.7	6.2348	1.3352
2014	7	7	8	10	9	0.3	1	0.24	90	6.2154	1.3307
2014	7	7	8	20	9	0.3	1	0.24	90	6.2154	1.3127
2014	7	7	8	30	9	0.3	1	0.31	88.2	6.2348	1.678
2014	7	7	8	40	9	0.3	1	0.32	78.1	6.2348	1.7141
2014	7	7	8	50	9	0.3	1	0.22	92.6	6.2154	1.1869
2014	7	7	9	0	9	0.3	1	0.24	94.8	6.2154	1.2948
2014	7	7	9	10	9	0.3	1	0.27	89.3	6.2348	1.4615

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	9	20	9	0.3	1	0.24	79	6.2348	1.2991
2014	7	7	9	30	9	0.3	1	0.3	80.6	6.2154	1.6364
2014	7	7	9	40	9	0.3	1	0.2	78	6.2348	1.1006
2014	7	7	9	50	9	0.3	1	0.32	86.4	6.2348	1.7321
2014	7	7	10	0	9	0.3	1	0.27	91.4	6.2348	1.4795
2014	7	7	10	10	9	0.3	1	0.18	84.8	6.2348	0.9924
2014	7	7	10	20	9	0.3	1	0.34	73.7	6.2348	1.7863
2014	7	7	10	30	9	0.3	1	0.28	90	6.2348	1.5336
2014	7	7	10	40	9	0.3	1	0.26	94.3	6.2348	1.4254
2014	7	7	10	50	9	0.3	1	0.29	86.8	6.2348	1.6058
2014	7	7	11	0	9	0.3	1	0.33	93.5	6.2348	1.7863
2014	7	7	11	10	9	0.3	1	0.31	75.1	6.2348	1.6239
2014	7	7	11	20	9	0.3	1	0.2	87.2	6.2348	1.1187
2014	7	7	11	30	9	0.3	1	0.3	95	6.2348	1.6419
2014	7	7	11	40	9	0.3	1	0.17	90	6.2348	0.9563
2014	7	7	11	50	9	0.3	1	0.28	94	6.2348	1.5517
2014	7	7	12	0	9	0.3	1	0.19	90	6.2348	1.0645
2014	7	7	12	10	9	0.3	1	0.27	97.7	6.2348	1.4615
2014	7	7	12	20	9	0.3	1	0.24	81.4	6.2348	1.3171
2014	7	7	12	30	9	0.3	1	0.27	95.6	6.2348	1.4615
2014	7	7	12	40	9	0.3	1	0.28	90	6.2348	1.5517
2014	7	7	12	50	9	0.3	1	0.21	85.5	6.2348	1.1367
2014	7	7	13	0	9	0.3	1	0.28	90	6.2348	1.5336
2014	7	7	13	10	9	0.3	1	0.34	93.9	6.2348	1.8764
2014	7	7	13	20	9	0.3	1	0.25	89.2	6.2348	1.3712
2014	7	7	13	30	9	0.3	1	0.32	96.4	6.2348	1.7681
2014	7	7	13	40	9	0.3	1	0.28	88.7	6.2348	1.5516
2014	7	7	13	50	9	0.3	1	0.31	77.9	6.2348	1.6779
2014	7	7	14	0	9	0.3	1	0.33	80.3	6.2348	1.7862
2014	7	7	14	10	9	0.3	1	0.29	91.3	6.2348	1.5697
2014	7	7	14	20	9	0.3	1	0.27	71.8	6.2348	1.4253
2014	7	7	14	30	9	0.3	1	0.3	84.4	6.2348	1.6418
2014	7	7	14	40	9	0.3	1	0.29	78	6.2348	1.5336
2014	7	7	14	50	9	0.3	1	0.29	82.3	6.2348	1.6057
2014	7	7	15	0	9	0.3	1	0.28	79.8	6.2348	1.4975
2014	7	7	15	10	9	0.3	1	0.32	74	6.2154	1.6903
2014	7	7	15	20	9	0.3	1	0.33	63.7	6.2348	1.6418
2014	7	7	15	30	9	0.3	1	0.28	77.6	6.2154	1.4745
2014	7	7	15	40	9	0.3	1	0.32	88.8	6.2154	1.7622
2014	7	7	15	50	9	0.3	1	0.28	80	6.2154	1.5284
2014	7	7	16	0	9	0.3	1	0.28	73	6.2154	1.4745
2014	7	7	16	10	9	0.3	1	0.29	80.3	6.2154	1.5824
2014	7	7	16	20	9	0.3	1	0.26	73.9	6.2154	1.3666
2014	7	7	16	30	9	0.3	1	0.27	82.3	6.2154	1.4565
2014	7	7	16	40	9	0.3	1	0.28	70.1	6.2154	1.4385
2014	7	7	16	50	9	0.3	1	0.3	77.3	6.2154	1.6003

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	17	0	9	0.3	1	0.28	64.6	6.2154	1.4025
2014	7	7	17	10	9	0.3	1	0.28	78.6	6.2154	1.5104
2014	7	7	17	20	9	0.3	1	0.3	86.9	6.2154	1.6543
2014	7	7	17	30	9	0.3	1	0.28	69.1	6.2154	1.4565
2014	7	7	17	40	9	0.3	1	0.34	67.7	6.2154	1.7082
2014	7	7	17	50	9	0.3	1	0.26	77.6	6.2154	1.3846
2014	7	7	18	0	9	0.3	1	0.23	67.8	6.2154	1.1868
2014	7	7	18	10	9	0.3	1	0.26	72.5	6.1961	1.362
2014	7	7	18	20	9	0.3	1	0.29	82.2	6.1961	1.5771
2014	7	7	18	30	9	0.3	1	0.29	65.2	6.1961	1.4337
2014	7	7	18	40	9	0.3	1	0.22	83.3	6.1961	1.2186
2014	7	7	18	50	9	0.3	1	0.23	91.7	6.1961	1.2366
2014	7	7	19	0	9	0.3	1	0.24	81.2	6.1961	1.2724
2014	7	7	19	10	9	0.3	1	0.27	66.5	6.1961	1.362
2014	7	7	19	20	9	0.3	1	0.31	90	6.1961	1.7204
2014	7	7	19	30	9	0.3	1	0.27	81.6	6.1961	1.4516
2014	7	7	19	40	9	0.3	1	0.31	91.2	6.1961	1.6667
2014	7	7	19	50	9	0.3	1	0.21	84.6	6.1961	1.129
2014	7	7	20	0	9	0.3	1	0.21	90.9	6.1961	1.129
2014	7	7	20	10	9	0.3	1	0.23	87.6	6.1961	1.2724
2014	7	7	20	20	9	0.3	1	0.21	90.9	6.1961	1.129
2014	7	7	20	30	9	0.3	1	0.31	99.8	6.1767	1.6611
2014	7	7	20	40	9	0.3	1	0.25	90	6.1961	1.3799
2014	7	7	20	50	9	0.3	1	0.25	90	6.1767	1.3753
2014	7	7	21	0	9	0.3	1	0.22	89.1	6.1961	1.1828
2014	7	7	21	10	9	0.3	1	0.22	94.3	6.1961	1.1828
2014	7	7	21	20	9	0.3	1	0.23	90	6.1961	1.2724
2014	7	7	21	30	9	0.3	1	0.23	90	6.1961	1.2724
2014	7	7	21	40	9	0.3	1	0.22	99.6	6.1961	1.1649
2014	7	7	21	50	9	0.3	1	0.25	94.6	6.1961	1.3441
2014	7	7	22	0	9	0.3	1	0.21	95.3	6.1961	1.1649
2014	7	7	22	10	9	0.3	1	0.21	91.8	6.1961	1.1649
2014	7	7	22	20	9	0.3	1	0.19	99.8	6.1961	1.0395
2014	7	7	22	30	9	0.3	1	0.28	90.7	6.1961	1.5234
2014	7	7	22	40	9	0.3	1	0.26	94.3	6.1961	1.4158
2014	7	7	22	50	9	0.3	1	0.2	94.7	6.1961	1.0932
2014	7	7	23	0	9	0.3	1	0.28	90	6.1961	1.5054
2014	7	7	23	10	9	0.3	1	0.26	76.7	6.1961	1.3621
2014	7	7	23	20	9	0.3	1	0.24	101	6.1961	1.2904
2014	7	7	23	30	9	0.3	1	0.23	104	6.1961	1.2187
2014	7	7	23	40	9	0.3	1	0.26	91.5	6.1961	1.4158
2014	7	7	23	50	9	0.3	1	0.28	90	6.1961	1.5413
2014	7	8	0	0	9	0.3	1	0.26	76.7	6.1961	1.3621
2014	7	8	0	10	9	0.3	1	0.23	87.6	6.1961	1.2725
2014	7	8	0	20	9	0.3	1	0.28	90.7	6.1961	1.5413
2014	7	8	0	30	9	0.3	1	0.27	90	6.1961	1.4517

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	0	40	9	0.3	1	0.27	86.6	6.1961	1.4875
2014	7	8	0	50	9	0.3	1	0.24	90	6.1961	1.3262
2014	7	8	1	0	9	0.3	1	0.28	68.8	6.1961	1.4338
2014	7	8	1	10	9	0.3	1	0.29	76.9	6.1961	1.5413
2014	7	8	1	20	9	0.3	1	0.24	80.5	6.1961	1.2904
2014	7	8	1	30	9	0.3	1	0.29	84.1	6.1961	1.5592
2014	7	8	1	40	9	0.3	1	0.23	88.4	6.1961	1.2546
2014	7	8	1	50	9	0.3	1	0.26	97.9	6.1961	1.4159
2014	7	8	2	0	9	0.3	1	0.3	91.3	6.1961	1.6309
2014	7	8	2	10	9	0.3	1	0.3	93.1	6.1961	1.6309
2014	7	8	2	20	9	0.3	1	0.27	91.4	6.1961	1.4696
2014	7	8	2	30	9	0.3	1	0.23	90	6.1961	1.2367
2014	7	8	2	40	9	0.3	1	0.27	95.6	6.1961	1.4517
2014	7	8	2	50	9	0.3	1	0.29	92.6	6.1961	1.5593
2014	7	8	3	0	9	0.3	1	0.23	72.1	6.1961	1.2187
2014	7	8	3	10	9	0.3	1	0.29	101.8	6.1961	1.5413
2014	7	8	3	20	9	0.3	1	0.3	86.9	6.1961	1.6489
2014	7	8	3	30	9	0.3	1	0.26	79.1	6.1961	1.398
2014	7	8	3	40	9	0.3	1	0.26	77.6	6.1961	1.38
2014	7	8	3	50	9	0.3	1	0.3	89.4	6.1961	1.613
2014	7	8	4	0	9	0.3	1	0.35	83.1	6.1961	1.9177
2014	7	8	4	10	9	0.3	1	0.2	91.9	6.1961	1.0933
2014	7	8	4	20	9	0.3	1	0.17	85.7	6.2154	0.9531
2014	7	8	4	30	9	0.3	1	0.2	96.7	6.2154	1.079
2014	7	8	4	40	9	0.3	1	0.31	77.3	6.2154	1.6724
2014	7	8	4	50	9	0.3	1	0.26	87.8	6.2154	1.4207
2014	7	8	5	0	9	0.3	1	0.29	92	6.2154	1.5825
2014	7	8	5	10	9	0.3	1	0.35	87.3	6.2154	1.9422
2014	7	8	5	20	9	0.3	1	0.26	90	6.2154	1.4386
2014	7	8	5	30	9	0.3	1	0.33	99.8	6.2154	1.7623
2014	7	8	5	40	9	0.3	1	0.23	74.2	6.2154	1.2049
2014	7	8	5	50	9	0.3	1	0.29	90	6.2154	1.6005
2014	7	8	6	0	9	0.3	1	0.28	90	6.2154	1.5106
2014	7	8	6	10	9	0.3	1	0.28	104.7	6.2154	1.5106
2014	7	8	6	20	9	0.3	1	0.24	85.4	6.2154	1.3308
2014	7	8	6	30	9	0.3	1	0.24	89.2	6.2154	1.2948
2014	7	8	6	40	9	0.3	1	0.29	111.9	6.2154	1.4746
2014	7	8	6	50	9	0.3	1	0.25	99.2	6.2154	1.3308
2014	7	8	7	0	9	0.3	1	0.25	83.2	6.2154	1.3487
2014	7	8	7	10	9	0.3	1	0.24	97.7	6.2154	1.3308
2014	7	8	7	20	9	0.3	1	0.29	81.4	6.2154	1.5466
2014	7	8	7	30	9	0.3	1	0.26	99.3	6.2154	1.4207
2014	7	8	7	40	9	0.3	1	0.31	91.8	6.2154	1.7084
2014	7	8	7	50	9	0.3	1	0.25	81.7	6.2154	1.3487
2014	7	8	8	0	9	0.3	1	0.21	90	6.2154	1.1329
2014	7	8	8	10	9	0.3	1	0.26	75.3	6.2154	1.3667

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	8	20	9	0.3	1	0.22	97.9	6.2154	1.1689
2014	7	8	8	30	9	0.3	1	0.25	78.5	6.2154	1.3308
2014	7	8	8	40	9	0.3	1	0.29	77.7	6.2154	1.5645
2014	7	8	8	50	9	0.3	1	0.28	92.7	6.2154	1.5286
2014	7	8	9	0	9	0.3	1	0.25	89.2	6.2154	1.3667
2014	7	8	9	10	9	0.3	1	0.3	89.4	6.2154	1.6185
2014	7	8	9	20	9	0.3	1	0.22	83.2	6.2154	1.2049
2014	7	8	9	30	9	0.3	1	0.29	74.1	6.2154	1.5106
2014	7	8	9	40	9	0.3	1	0.28	101.4	6.2154	1.5106
2014	7	8	9	50	9	0.3	1	0.27	90	6.2154	1.4926
2014	7	8	10	0	9	0.3	1	0.29	98.6	6.2154	1.5465
2014	7	8	10	10	9	0.3	1	0.33	80.3	6.2154	1.7803
2014	7	8	10	20	9	0.3	1	0.3	86.8	6.2154	1.6184
2014	7	8	10	30	9	0.3	1	0.32	96.5	6.2154	1.7443
2014	7	8	10	40	9	0.3	1	0.31	90	6.2154	1.6904
2014	7	8	10	50	9	0.3	1	0.27	99.1	6.2154	1.4566
2014	7	8	11	0	9	0.3	1	0.3	80	6.2154	1.6364
2014	7	8	11	10	9	0.3	1	0.24	94.6	6.2154	1.3307
2014	7	8	11	20	9	0.3	1	0.3	88.7	6.2154	1.6364
2014	7	8	11	30	9	0.3	1	0.28	84	6.2154	1.5465
2014	7	8	11	40	9	0.3	1	0.28	92	6.2154	1.5285
2014	7	8	11	50	9	0.3	1	0.25	90.8	6.1961	1.3442
2014	7	8	12	0	9	0.3	1	0.32	84.8	6.1961	1.7564
2014	7	8	12	10	9	0.3	1	0.27	84.5	6.1961	1.4875
2014	7	8	12	20	9	0.3	1	0.3	84.4	6.1961	1.6488
2014	7	8	12	30	9	0.3	1	0.32	75.7	6.1961	1.6847
2014	7	8	12	40	9	0.3	1	0.25	80.2	6.1961	1.3441
2014	7	8	12	50	9	0.3	1	0.3	89.4	6.1961	1.6488
2014	7	8	13	0	9	0.3	1	0.26	83.5	6.1961	1.4158
2014	7	8	13	10	9	0.3	1	0.31	79.7	6.1961	1.6846
2014	7	8	13	20	9	0.3	1	0.29	71	6.1961	1.5054
2014	7	8	13	30	9	0.3	1	0.24	93.1	6.1961	1.3262
2014	7	8	13	40	9	0.3	1	0.31	67.3	6.1961	1.5412
2014	7	8	13	50	9	0.3	1	0.28	75.3	6.1961	1.5054
2014	7	8	14	0	9	0.3	1	0.29	84.2	6.1961	1.595
2014	7	8	14	10	9	0.3	1	0.25	83.2	6.1767	1.3574
2014	7	8	14	20	9	0.3	1	0.29	82.3	6.1767	1.5896
2014	7	8	14	30	9	0.3	1	0.26	82	6.1767	1.3932
2014	7	8	14	40	9	0.3	1	0.29	78.9	6.1767	1.5539
2014	7	8	14	50	9	0.3	1	0.27	85.9	6.1767	1.4825
2014	7	8	15	0	9	0.3	1	0.29	75.8	6.1767	1.5539
2014	7	8	15	10	9	0.3	1	0.35	85.1	6.1574	1.8869
2014	7	8	15	20	9	0.3	1	0.34	81.2	6.1574	1.8335
2014	7	8	15	30	9	0.3	1	0.34	81	6.1574	1.7979
2014	7	8	15	40	9	0.3	1	0.26	70.6	6.1574	1.3173
2014	7	8	15	50	9	0.3	1	0.3	69.8	6.1574	1.5487

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	16	0	9	0.3	1	0.23	71.6	6.1574	1.1749
2014	7	8	16	10	9	0.3	1	0.22	104.4	6.138	1.1709
2014	7	8	16	20	9	0.3	1	0.23	90	6.138	1.2596
2014	7	8	16	30	9	0.3	1	0.25	84.1	6.138	1.366
2014	7	8	16	40	9	0.3	1	0.26	89.3	6.138	1.3838
2014	7	8	16	50	9	0.3	1	0.25	74.7	6.138	1.2951
2014	7	8	17	0	9	0.3	1	0.3	60.3	6.138	1.4015
2014	7	8	17	10	9	0.3	1	0.27	66.9	6.1574	1.3351
2014	7	8	17	20	9	0.3	1	0.29	62.9	6.1574	1.4241
2014	7	8	17	30	9	0.3	1	0.28	75.2	6.138	1.4725
2014	7	8	17	40	9	0.3	1	0.29	64.3	6.1574	1.4063
2014	7	8	17	50	9	0.3	1	0.28	74.3	6.1574	1.4597
2014	7	8	18	0	9	0.3	1	0.23	69.7	6.138	1.1531
2014	7	8	18	10	9	0.3	1	0.2	73.9	6.0993	1.0396
2014	7	8	18	20	9	0.3	1	0.29	74.1	6.1187	1.4852
2014	7	8	18	30	9	0.3	1	0.23	67.9	6.1187	1.1316
2014	7	8	18	40	9	0.3	1	0.23	80.8	6.1187	1.2023
2014	7	8	18	50	9	0.3	1	0.24	62.7	6.1187	1.1669
2014	7	8	19	0	9	0.3	1	0.29	72.6	6.0993	1.4625
2014	7	8	19	10	9	0.3	1	0.29	75.5	6.0993	1.4978
2014	7	8	19	20	9	0.3	1	0.22	73.7	6.0993	1.1453
2014	7	8	19	30	9	0.3	1	0.32	79.9	6.1187	1.6797
2014	7	8	19	40	9	0.3	1	0.29	75.8	6.0993	1.533
2014	7	8	19	50	9	0.3	1	0.3	83	6.0993	1.5859
2014	7	8	20	0	9	0.3	1	0.26	73	6.0993	1.3216
2014	7	8	20	10	9	0.3	1	0.28	76	6.0993	1.4802
2014	7	8	20	20	9	0.3	1	0.14	96.8	6.08	0.7376
2014	7	8	20	30	9	0.3	1	0.25	113.2	6.0993	1.2335
2014	7	8	20	40	9	0.3	1	0.26	87.9	6.0993	1.4097
2014	7	8	20	50	9	0.3	1	0.17	100.9	6.1187	0.9194
2014	7	8	21	0	9	0.3	1	0.23	83.4	6.1187	1.22
2014	7	8	21	10	9	0.3	1	0.25	90	6.1187	1.3261
2014	7	8	21	20	9	0.3	1	0.31	67.5	6.1187	1.5383
2014	7	8	21	30	9	0.3	1	0.14	107.2	6.1187	0.7426
2014	7	8	21	40	9	0.3	1	0.23	95.8	6.138	1.2242
2014	7	8	21	50	9	0.3	1	0.28	90	6.138	1.4903
2014	7	8	22	0	9	0.3	1	0.28	94.1	6.138	1.4903
2014	7	8	22	10	9	0.3	1	0.25	84.7	6.138	1.3306
2014	7	8	22	20	9	0.3	1	0.25	109.4	6.138	1.2597
2014	7	8	22	30	9	0.3	1	0.2	90.9	6.138	1.0822
2014	7	8	22	40	9	0.3	1	0.23	86	6.1574	1.2639
2014	7	8	22	50	9	0.3	1	0.27	94.9	6.1574	1.4598
2014	7	8	23	0	9	0.3	1	0.18	101.7	6.1574	0.9435
2014	7	8	23	10	9	0.3	1	0.26	103.3	6.1574	1.3529
2014	7	8	23	20	9	0.3	1	0.24	93.2	6.1574	1.2817
2014	7	8	23	30	9	0.3	1	0.26	98	6.1574	1.3886

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	23	40	9	0.3	1	0.34	100.6	6.1574	1.8158
2014	7	8	23	50	9	0.3	1	0.23	94	6.1767	1.2682
2014	7	9	0	0	9	0.3	1	0.32	88.8	6.1767	1.7326
2014	7	9	0	10	9	0.3	1	0.26	90	6.1767	1.429
2014	7	9	0	20	9	0.3	1	0.24	98.8	6.1767	1.2682
2014	7	9	0	30	9	0.3	1	0.26	87.1	6.1767	1.429
2014	7	9	0	40	9	0.3	1	0.26	82.1	6.1767	1.4111
2014	7	9	0	50	9	0.3	1	0.25	93	6.1767	1.3754
2014	7	9	1	0	9	0.3	1	0.23	94.9	6.1767	1.2504
2014	7	9	1	10	9	0.3	1	0.31	88.8	6.1767	1.6791
2014	7	9	1	20	9	0.3	1	0.28	101.3	6.1767	1.5183
2014	7	9	1	30	9	0.3	1	0.17	88.9	6.1767	0.9288
2014	7	9	1	40	9	0.3	1	0.28	89.3	6.1767	1.5362
2014	7	9	1	50	9	0.3	1	0.16	87.7	6.1767	0.8931
2014	7	9	2	0	9	0.3	1	0.32	91.2	6.1767	1.7327
2014	7	9	2	10	9	0.3	1	0.27	86.6	6.1767	1.4826
2014	7	9	2	20	9	0.3	1	0.26	95.8	6.1767	1.4111
2014	7	9	2	30	9	0.3	1	0.26	82.7	6.1767	1.3933
2014	7	9	2	40	9	0.3	1	0.26	97.9	6.1767	1.4111
2014	7	9	2	50	9	0.3	1	0.31	79.7	6.1767	1.6791
2014	7	9	3	0	9	0.3	1	0.24	67.9	6.1767	1.2325
2014	7	9	3	10	9	0.3	1	0.26	102.3	6.1767	1.3933
2014	7	9	3	20	9	0.3	1	0.26	79.1	6.1767	1.3933
2014	7	9	3	30	9	0.3	1	0.26	94.4	6.1767	1.3933
2014	7	9	3	40	9	0.3	1	0.29	87.4	6.1767	1.5898
2014	7	9	3	50	9	0.3	1	0.21	71.3	6.1767	1.1075
2014	7	9	4	0	9	0.3	1	0.25	101.5	6.1767	1.3218
2014	7	9	4	10	9	0.3	1	0.26	90	6.1961	1.398
2014	7	9	4	20	9	0.3	1	0.21	93.6	6.1767	1.1254
2014	7	9	4	30	9	0.3	1	0.27	74.6	6.1961	1.4338
2014	7	9	4	40	9	0.3	1	0.23	80.9	6.1767	1.2325
2014	7	9	4	50	9	0.3	1	0.27	93.5	6.1767	1.4469
2014	7	9	5	0	9	0.3	1	0.28	90	6.1767	1.5005
2014	7	9	5	10	9	0.3	1	0.24	83.7	6.1767	1.2861
2014	7	9	5	20	9	0.3	1	0.24	115.2	6.1767	1.1789
2014	7	9	5	30	9	0.3	1	0.28	88.7	6.1767	1.5183
2014	7	9	5	40	9	0.3	1	0.31	87	6.1767	1.6791
2014	7	9	5	50	9	0.3	1	0.27	83.1	6.1767	1.4826
2014	7	9	6	0	9	0.3	1	0.27	96.2	6.1767	1.4826
2014	7	9	6	10	9	0.3	1	0.2	97.7	6.1767	1.0539
2014	7	9	6	20	9	0.3	1	0.29	76.9	6.1767	1.5362
2014	7	9	6	30	9	0.3	1	0.27	80.3	6.1767	1.4648
2014	7	9	6	40	9	0.3	1	0.25	83.2	6.1767	1.3397
2014	7	9	6	50	9	0.3	1	0.27	77.2	6.1767	1.4112
2014	7	9	7	0	9	0.3	1	0.27	90	6.1767	1.4826
2014	7	9	7	10	9	0.3	1	0.28	86	6.1767	1.5362

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	7	20	9	0.3	1	0.23	90	6.1767	1.2504
2014	7	9	7	30	9	0.3	1	0.27	97.7	6.1767	1.4469
2014	7	9	7	40	9	0.3	1	0.25	90	6.1767	1.3397
2014	7	9	7	50	9	0.3	1	0.17	93.3	6.1767	0.9289
2014	7	9	8	0	9	0.3	1	0.31	91.2	6.1767	1.697
2014	7	9	8	10	9	0.3	1	0.29	91.3	6.1767	1.5541
2014	7	9	8	20	9	0.3	1	0.27	83	6.1767	1.4648
2014	7	9	8	30	9	0.3	1	0.23	94.1	6.1767	1.2325
2014	7	9	8	40	9	0.3	1	0.3	77.3	6.1767	1.5898
2014	7	9	8	50	9	0.3	1	0.16	86.5	6.1961	0.8782
2014	7	9	9	0	9	0.3	1	0.31	90.6	6.2154	1.6724
2014	7	9	9	10	9	0.3	1	0.21	71.3	6.2154	1.115
2014	7	9	9	20	9	0.3	1	0.29	95.2	6.2154	1.5825
2014	7	9	9	30	9	0.3	1	0.31	88.8	6.1961	1.6848
2014	7	9	9	40	9	0.3	1	0.35	94.4	6.1961	1.8819
2014	7	9	9	50	9	0.3	1	0.24	98.7	6.1961	1.2904
2014	7	9	10	0	9	0.3	1	0.29	90	6.1961	1.5951
2014	7	9	10	10	9	0.3	1	0.33	83.8	6.1961	1.8102
2014	7	9	10	20	9	0.3	1	0.22	90	6.1961	1.2008
2014	7	9	10	30	9	0.3	1	0.27	81.5	6.1961	1.4338
2014	7	9	10	40	9	0.3	1	0.32	88.2	6.1961	1.7206
2014	7	9	10	50	9	0.3	1	0.21	101	6.1961	1.1112
2014	7	9	11	0	9	0.3	1	0.29	88.7	6.1961	1.5593
2014	7	9	11	10	9	0.3	1	0.23	90.8	6.1961	1.2366
2014	7	9	11	20	9	0.3	1	0.28	94	6.1961	1.5234
2014	7	9	11	30	9	0.3	1	0.29	96.5	6.1961	1.5772
2014	7	9	11	40	9	0.3	1	0.31	80.2	6.1961	1.6668
2014	7	9	11	50	9	0.3	1	0.23	80.3	6.1961	1.2546
2014	7	9	12	0	9	0.3	1	0.24	71.3	6.1767	1.2146
2014	7	9	12	10	9	0.3	1	0.26	69.7	6.1767	1.3039
2014	7	9	12	20	9	0.3	1	0.23	66	6.1767	1.1253
2014	7	9	12	30	9	0.3	1	0.29	79.6	6.1961	1.5592
2014	7	9	12	40	9	0.3	1	0.25	80.9	6.1961	1.3441
2014	7	9	12	50	9	0.3	1	0.2	80.4	6.1767	1.0538
2014	7	9	13	0	9	0.3	1	0.33	90	6.1767	1.8219
2014	7	9	13	10	9	0.3	1	0.31	89.4	6.1767	1.6968
2014	7	9	13	20	9	0.3	1	0.26	90	6.1767	1.411
2014	7	9	13	30	9	0.3	1	0.26	80	6.1767	1.411
2014	7	9	13	40	9	0.3	1	0.25	70.1	6.1767	1.286
2014	7	9	13	50	9	0.3	1	0.26	84.9	6.1767	1.411
2014	7	9	14	0	9	0.3	1	0.25	80.2	6.1767	1.3396
2014	7	9	14	10	9	0.3	1	0.28	102.2	6.1767	1.4825
2014	7	9	14	20	9	0.3	1	0.24	107.2	6.1574	1.2639
2014	7	9	14	30	9	0.3	1	0.33	75.4	6.1574	1.7089
2014	7	9	14	40	9	0.3	1	0.23	70.5	6.1574	1.157
2014	7	9	14	50	9	0.3	1	0.33	79.7	6.1574	1.7623

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	15	0	9	0.3	1	0.34	69.4	6.138	1.7031
2014	7	9	15	10	9	0.3	1	0.28	96.1	6.1574	1.4952
2014	7	9	15	20	9	0.3	1	0.22	69.1	6.138	1.1176
2014	7	9	15	30	9	0.3	1	0.28	77.9	6.1574	1.4952
2014	7	9	15	40	9	0.3	1	0.25	83.2	6.138	1.3483
2014	7	9	15	50	9	0.3	1	0.28	69.8	6.138	1.4015
2014	7	9	16	0	9	0.3	1	0.24	77.3	6.138	1.2596
2014	7	9	16	10	9	0.3	1	0.25	78.7	6.138	1.3305
2014	7	9	16	20	9	0.3	1	0.32	78	6.1187	1.6619
2014	7	9	16	30	9	0.3	1	0.28	81.9	6.1187	1.4851
2014	7	9	16	40	9	0.3	1	0.22	83.9	6.1187	1.1669
2014	7	9	16	50	9	0.3	1	0.25	72.3	6.0993	1.2686
2014	7	9	17	0	9	0.3	1	0.34	79.9	6.0993	1.7796
2014	7	9	17	10	9	0.3	1	0.27	85.2	6.0993	1.4625
2014	7	9	17	20	9	0.3	1	0.25	90	6.08	1.3346
2014	7	9	17	30	9	0.3	1	0.26	76.8	6.08	1.3521
2014	7	9	17	40	9	0.3	1	0.31	79	6.0606	1.6275
2014	7	9	17	50	9	0.3	1	0.33	76.1	6.08	1.7033
2014	7	9	18	0	9	0.3	1	0.23	71.6	6.08	1.159
2014	7	9	18	10	9	0.3	1	0.26	91.5	6.0606	1.365
2014	7	9	18	20	9	0.3	1	0.27	94.1	6.08	1.4575
2014	7	9	18	30	9	0.3	1	0.26	93.6	6.08	1.4048
2014	7	9	18	40	9	0.3	1	0.3	83.1	6.0606	1.5925
2014	7	9	18	50	9	0.3	1	0.3	71	6.08	1.5277
2014	7	9	19	0	9	0.3	1	0.24	90	6.08	1.2994
2014	7	9	19	10	9	0.3	1	0.22	85.7	6.0993	1.1629
2014	7	9	19	20	9	0.3	1	0.28	69.8	6.08	1.3872
2014	7	9	19	30	9	0.3	1	0.39	87.6	6.0993	2.0968
2014	7	9	19	40	9	0.3	1	0.31	80.7	6.1187	1.6266
2014	7	9	19	50	9	0.3	1	0.26	77.6	6.0993	1.3568
2014	7	9	20	0	9	0.3	1	0.24	85.3	6.1187	1.2907
2014	7	9	20	10	9	0.3	1	0.22	83.9	6.1187	1.1669
2014	7	9	20	20	9	0.3	1	0.25	93.8	6.1187	1.326
2014	7	9	20	30	9	0.3	1	0.2	79.8	6.1187	1.0785
2014	7	9	20	40	9	0.3	1	0.32	82.3	6.138	1.7031
2014	7	9	20	50	9	0.3	1	0.29	96.4	6.138	1.5789
2014	7	9	21	0	9	0.3	1	0.25	77.8	6.138	1.3128
2014	7	9	21	10	9	0.3	1	0.22	105.3	6.1574	1.1749
2014	7	9	21	20	9	0.3	1	0.26	106.3	6.1574	1.3351
2014	7	9	21	30	9	0.3	1	0.31	96	6.1574	1.6911
2014	7	9	21	40	9	0.3	1	0.17	80.2	6.1574	0.9256
2014	7	9	21	50	9	0.3	1	0.27	85.8	6.1574	1.4597
2014	7	9	22	0	9	0.3	1	0.23	84.2	6.1574	1.2283
2014	7	9	22	10	9	0.3	1	0.25	90.8	6.1574	1.3351
2014	7	9	22	20	9	0.3	1	0.25	81.5	6.1767	1.3217
2014	7	9	22	30	9	0.3	1	0.27	85.2	6.1767	1.4825

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	22	40	9	0.3	1	0.26	77.6	6.1767	1.3753
2014	7	9	22	50	9	0.3	1	0.21	80.2	6.1767	1.1431
2014	7	9	23	0	9	0.3	1	0.24	82.2	6.1767	1.3039
2014	7	9	23	10	9	0.3	1	0.27	90	6.1767	1.4646
2014	7	9	23	20	9	0.3	1	0.26	108.4	6.1767	1.3396
2014	7	9	23	30	9	0.3	1	0.22	93.4	6.1767	1.1967
2014	7	9	23	40	9	0.3	1	0.25	73.2	6.1767	1.3039
2014	7	9	23	50	9	0.3	1	0.23	97.3	6.1961	1.2545
2014	7	10	0	0	9	0.3	1	0.29	92	6.1961	1.5592
2014	7	10	0	10	9	0.3	1	0.24	92.4	6.1961	1.3083
2014	7	10	0	20	9	0.3	1	0.25	90	6.1961	1.38
2014	7	10	0	30	9	0.3	1	0.23	79.2	6.1961	1.2187
2014	7	10	0	40	9	0.3	1	0.2	87.2	6.1961	1.0932
2014	7	10	0	50	9	0.3	1	0.21	81.7	6.1961	1.1111
2014	7	10	1	0	9	0.3	1	0.26	98.9	6.1961	1.38
2014	7	10	1	10	9	0.3	1	0.23	97.4	6.1961	1.2366
2014	7	10	1	20	9	0.3	1	0.21	84.6	6.1961	1.147
2014	7	10	1	30	9	0.3	1	0.26	86.4	6.1961	1.4337
2014	7	10	1	40	9	0.3	1	0.23	104.6	6.1961	1.2366
2014	7	10	1	50	9	0.3	1	0.25	91.5	6.1961	1.38
2014	7	10	2	0	9	0.3	1	0.2	77.6	6.1961	1.0574
2014	7	10	2	10	9	0.3	1	0.27	93.5	6.1961	1.4696
2014	7	10	2	20	9	0.3	1	0.23	72.6	6.1961	1.2008
2014	7	10	2	30	9	0.3	1	0.28	98.1	6.1961	1.5054
2014	7	10	2	40	9	0.3	1	0.28	94.7	6.1961	1.5413
2014	7	10	2	50	9	0.3	1	0.31	96.7	6.1961	1.6667
2014	7	10	3	0	9	0.3	1	0.22	96.9	6.1961	1.1828
2014	7	10	3	10	9	0.3	1	0.2	98.5	6.2154	1.0789
2014	7	10	3	20	9	0.3	1	0.35	90.5	6.1961	1.9176
2014	7	10	3	30	9	0.3	1	0.26	111.7	6.1961	1.3083
2014	7	10	3	40	9	0.3	1	0.27	84.5	6.2154	1.4925
2014	7	10	3	50	9	0.3	1	0.26	96.4	6.2154	1.4386
2014	7	10	4	0	9	0.3	1	0.23	83.6	6.2154	1.2767
2014	7	10	4	10	9	0.3	1	0.26	105.6	6.1961	1.3442
2014	7	10	4	20	9	0.3	1	0.31	89.4	6.2154	1.6723
2014	7	10	4	30	9	0.3	1	0.21	90.9	6.2154	1.1509
2014	7	10	4	40	9	0.3	1	0.28	86.6	6.2154	1.5285
2014	7	10	4	50	9	0.3	1	0.18	92.1	6.2154	0.989
2014	7	10	5	0	9	0.3	1	0.26	102.6	6.2154	1.3667
2014	7	10	5	10	9	0.3	1	0.23	89.2	6.2154	1.2767
2014	7	10	5	20	9	0.3	1	0.27	98.3	6.2154	1.4746
2014	7	10	5	30	9	0.3	1	0.28	92.7	6.2154	1.5465
2014	7	10	5	40	9	0.3	1	0.25	94.5	6.2154	1.3667
2014	7	10	5	50	9	0.3	1	0.28	70.1	6.2154	1.4386
2014	7	10	6	0	9	0.3	1	0.31	91.2	6.2154	1.6904
2014	7	10	6	10	9	0.3	1	0.22	97.9	6.2154	1.1689

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	6	20	9	0.3	1	0.23	66	6.2154	1.1689
2014	7	10	6	30	9	0.3	1	0.31	82	6.2154	1.6724
2014	7	10	6	40	9	0.3	1	0.25	96	6.2154	1.3667
2014	7	10	6	50	9	0.3	1	0.22	92.6	6.2154	1.1869
2014	7	10	7	0	9	0.3	1	0.23	101.6	6.2154	1.2228
2014	7	10	7	10	9	0.3	1	0.21	97.4	6.2154	1.1149
2014	7	10	7	20	9	0.3	1	0.32	88.8	6.2154	1.7443
2014	7	10	7	30	9	0.3	1	0.22	90	6.2348	1.2269
2014	7	10	7	40	9	0.3	1	0.23	93.3	6.2348	1.263
2014	7	10	7	50	9	0.3	1	0.21	90	6.2348	1.1367
2014	7	10	8	0	9	0.3	1	0.28	82.5	6.2348	1.5156
2014	7	10	8	10	9	0.3	1	0.24	85.3	6.2348	1.3171
2014	7	10	8	20	9	0.3	1	0.3	97	6.2348	1.6239
2014	7	10	8	30	9	0.3	1	0.26	84.9	6.2348	1.4254
2014	7	10	8	40	9	0.3	1	0.28	90	6.2735	1.5257
2014	7	10	8	50	9	0.3	1	0.24	92.4	6.3122	1.3347
2014	7	10	9	0	9	0.3	1	0.33	96.8	6.3316	1.8527
2014	7	10	9	10	9	0.3	1	0.24	90.8	6.3509	1.3435
2014	7	10	9	20	9	0.3	1	0.34	87.2	6.3703	1.9203
2014	7	10	9	30	9	0.3	1	0.33	87.1	6.3897	1.8524
2014	7	10	9	40	9	0.3	1	0.32	80	6.3897	1.7783
2014	7	10	9	50	9	0.3	1	0.31	90	6.409	1.7469
2014	7	10	10	0	9	0.3	1	0.26	100.9	6.409	1.4496
2014	7	10	10	10	9	0.3	1	0.32	72.5	6.4284	1.7153
2014	7	10	10	20	9	0.3	1	0.28	89.3	6.4284	1.5848
2014	7	10	10	30	9	0.3	1	0.39	87.1	6.4477	2.2446
2014	7	10	10	40	9	0.3	1	0.31	89.4	6.4477	1.777
2014	7	10	10	50	9	0.3	1	0.32	80	6.4671	1.8014
2014	7	10	11	0	9	0.3	1	0.33	84.8	6.4671	1.8577
2014	7	10	11	10	9	0.3	1	0.31	81.3	6.4864	1.7319
2014	7	10	11	20	9	0.3	1	0.37	84.3	6.4864	2.0896
2014	7	10	11	30	9	0.3	1	0.4	71.1	6.5058	2.1529
2014	7	10	11	40	9	0.3	1	0.35	80.9	6.5445	2.0146
2014	7	10	11	50	9	0.3	1	0.4	82.5	6.5639	2.3261
2014	7	10	12	0	9	0.3	1	0.38	69.4	6.5639	2.0782
2014	7	10	12	10	9	0.3	1	0.39	82.3	6.5832	2.2761
2014	7	10	12	20	9	0.3	1	0.41	73.3	6.5832	2.2952
2014	7	10	12	30	9	0.3	1	0.32	77.1	6.6026	1.8419
2014	7	10	12	40	9	0.3	1	0.36	69.7	6.6026	1.9762
2014	7	10	12	50	9	0.3	1	0.39	70.3	6.6026	2.1489
2014	7	10	13	0	9	0.3	1	0.36	65.1	6.6026	1.8995
2014	7	10	13	10	9	0.3	1	0.39	77.9	6.6219	2.2519
2014	7	10	13	20	9	0.3	1	0.44	73.2	6.6219	2.4828
2014	7	10	13	30	9	0.3	1	0.4	74.8	6.6219	2.2711
2014	7	10	13	40	9	0.3	1	0.36	72.9	6.6219	2.0016
2014	7	10	13	50	9	0.3	1	0.44	73.1	6.6219	2.4636

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	14	0	9	0.3	1	0.36	72.6	6.6413	2.0272
2014	7	10	14	10	9	0.3	1	0.42	68	6.6413	2.2975
2014	7	10	14	20	9	0.3	1	0.37	71.6	6.6413	2.0851
2014	7	10	14	30	9	0.3	1	0.39	72	6.6413	2.201
2014	7	10	14	40	9	0.3	1	0.42	55.6	6.6413	2.0272
2014	7	10	14	50	9	0.3	1	0.44	67.8	6.6413	2.4134
2014	7	10	15	0	9	0.3	1	0.46	75	6.6413	2.5871
2014	7	10	15	10	9	0.3	1	0.4	68.3	6.6607	2.1885
2014	7	10	15	20	9	0.3	1	0.37	68.9	6.6607	2.0529
2014	7	10	15	30	9	0.3	1	0.44	58.2	6.6413	2.1817
2014	7	10	15	40	9	0.3	1	0.42	61	6.6607	2.1691
2014	7	10	15	50	9	0.3	1	0.48	58.8	6.6413	2.394
2014	7	10	16	0	9	0.3	1	0.35	69.9	6.6607	1.9561
2014	7	10	16	10	9	0.3	1	0.4	58.6	6.6607	2.0335
2014	7	10	16	20	9	0.3	1	0.38	60.4	6.6607	1.9754
2014	7	10	16	30	9	0.3	1	0.43	73	6.6607	2.4015
2014	7	10	16	40	9	0.3	1	0.4	73.9	6.6607	2.2853
2014	7	10	16	50	9	0.3	1	0.37	72.7	6.6607	2.111
2014	7	10	17	0	9	0.3	1	0.41	77	6.6607	2.3434
2014	7	10	17	10	9	0.3	1	0.42	76.3	6.6607	2.3822
2014	7	10	17	20	9	0.3	1	0.38	72.3	6.6607	2.1304
2014	7	10	17	30	9	0.3	1	0.31	81.4	6.6607	1.8012
2014	7	10	17	40	9	0.3	1	0.43	72.8	6.6607	2.4403
2014	7	10	17	50	9	0.3	1	0.39	80.2	6.6607	2.2466
2014	7	10	18	0	9	0.3	1	0.44	73.9	6.6607	2.479
2014	7	10	18	10	9	0.3	1	0.35	87.3	6.6607	2.0529
2014	7	10	18	20	9	0.3	1	0.4	80.5	6.6607	2.3047
2014	7	10	18	30	9	0.3	1	0.39	71.3	6.6607	2.1691
2014	7	10	18	40	9	0.3	1	0.4	82	6.6607	2.3435
2014	7	10	18	50	9	0.3	1	0.41	79.4	6.6607	2.3822
2014	7	10	19	0	9	0.3	1	0.34	96.7	6.6607	1.9755
2014	7	10	19	10	9	0.3	1	0.35	96.5	6.6607	2.0336
2014	7	10	19	20	9	0.3	1	0.4	87.7	6.6607	2.3628
2014	7	10	19	30	9	0.3	1	0.42	75.9	6.6607	2.3822
2014	7	10	19	40	9	0.3	1	0.4	81.9	6.6607	2.3241
2014	7	10	19	50	9	0.3	1	0.37	81.4	6.6607	2.1885
2014	7	10	20	0	9	0.3	1	0.37	98.6	6.6607	2.1886
2014	7	10	20	10	9	0.3	1	0.34	78.5	6.6607	1.9949
2014	7	10	20	20	9	0.3	1	0.37	104.3	6.6607	2.1305
2014	7	10	20	30	9	0.3	1	0.35	93.2	6.6607	2.0724
2014	7	10	20	40	9	0.3	1	0.43	90	6.6607	2.5566
2014	7	10	20	50	9	0.3	1	0.35	93.3	6.6607	2.0336
2014	7	10	21	0	9	0.3	1	0.38	79.7	6.6607	2.2273
2014	7	10	21	10	9	0.3	1	0.26	97.1	6.6607	1.5494
2014	7	10	21	20	9	0.3	1	0.44	95.6	6.6607	2.5566
2014	7	10	21	30	9	0.3	1	0.36	87.4	6.6607	2.1499

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	21	40	9	0.3	1	0.31	90	6.6607	1.8206
2014	7	10	21	50	9	0.3	1	0.37	94.6	6.6607	2.1499
2014	7	10	22	0	9	0.3	1	0.46	78	6.6607	2.6534
2014	7	10	22	10	9	0.3	1	0.31	99.3	6.6607	1.7819
2014	7	10	22	20	9	0.3	1	0.41	89.1	6.6607	2.4404
2014	7	10	22	30	9	0.3	1	0.38	82.5	6.6607	2.208
2014	7	10	22	40	9	0.3	1	0.29	88.7	6.68	1.6903
2014	7	10	22	50	9	0.3	1	0.33	95.2	6.68	1.9234
2014	7	10	23	0	9	0.3	1	0.39	84.2	6.68	2.2926
2014	7	10	23	10	9	0.3	1	0.39	82.3	6.68	2.2926
2014	7	10	23	20	9	0.3	1	0.37	91	6.68	2.2149
2014	7	10	23	30	9	0.3	1	0.34	96.6	6.68	2.0012
2014	7	10	23	40	9	0.3	1	0.41	87.7	6.68	2.448
2014	7	10	23	50	9	0.3	1	0.37	85.4	6.68	2.1566
2014	7	11	0	0	9	0.3	1	0.3	92.5	6.68	1.768
2014	7	11	0	10	9	0.3	1	0.4	93.3	6.68	2.3509
2014	7	11	0	20	9	0.3	1	0.37	97.2	6.68	2.1566
2014	7	11	0	30	9	0.3	1	0.39	88.1	6.68	2.2926
2014	7	11	0	40	9	0.3	1	0.38	92.5	6.68	2.2343
2014	7	11	0	50	9	0.3	1	0.35	98	6.68	2.0789
2014	7	11	1	0	9	0.3	1	0.41	98.2	6.68	2.4286
2014	7	11	1	10	9	0.3	1	0.39	90	6.68	2.2926
2014	7	11	1	20	9	0.3	1	0.35	90.5	6.68	2.0983
2014	7	11	1	30	9	0.3	1	0.39	86.6	6.68	2.3121
2014	7	11	1	40	9	0.3	1	0.39	83.3	6.68	2.3121
2014	7	11	1	50	9	0.3	1	0.39	91.4	6.68	2.3121
2014	7	11	2	0	9	0.3	1	0.36	77.2	6.68	2.0595
2014	7	11	2	10	9	0.3	1	0.42	91.4	6.68	2.4675
2014	7	11	2	20	9	0.3	1	0.37	89.5	6.68	2.1761
2014	7	11	2	30	9	0.3	1	0.36	88.9	6.68	2.1178
2014	7	11	2	40	9	0.3	1	0.46	90	6.68	2.7007
2014	7	11	2	50	9	0.3	1	0.38	96	6.68	2.2149
2014	7	11	3	0	9	0.3	1	0.33	86	6.68	1.9624
2014	7	11	3	10	9	0.3	1	0.38	93	6.68	2.2344
2014	7	11	3	20	9	0.3	1	0.36	76.7	6.68	2.0595
2014	7	11	3	30	9	0.3	1	0.36	96.3	6.68	2.1178
2014	7	11	3	40	9	0.3	1	0.37	96.6	6.68	2.1955
2014	7	11	3	50	9	0.3	1	0.37	80.9	6.68	2.1761
2014	7	11	4	0	9	0.3	1	0.39	95.4	6.68	2.2733
2014	7	11	4	10	9	0.3	1	0.33	99.8	6.68	1.9041
2014	7	11	4	20	9	0.3	1	0.33	99.2	6.68	1.9235
2014	7	11	4	30	9	0.3	1	0.3	79.3	6.68	1.7487
2014	7	11	4	40	9	0.3	1	0.4	88.1	6.68	2.351
2014	7	11	4	50	9	0.3	1	0.41	92.3	6.68	2.4287
2014	7	11	5	0	9	0.3	1	0.42	90	6.68	2.4676
2014	7	11	5	10	9	0.3	1	0.42	90.5	6.68	2.4676

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	5	20	9	0.3	1	0.48	83.7	6.68	2.8173
2014	7	11	5	30	9	0.3	1	0.35	99.3	6.6994	2.027
2014	7	11	5	40	9	0.3	1	0.33	90	6.6994	1.949
2014	7	11	5	50	9	0.3	1	0.26	90.7	6.6994	1.5397
2014	7	11	6	0	9	0.3	1	0.41	92.8	6.68	2.4093
2014	7	11	6	10	9	0.3	1	0.36	84.2	6.68	2.0984
2014	7	11	6	20	9	0.3	1	0.4	90.5	6.68	2.351
2014	7	11	6	30	9	0.3	1	0.35	80.4	6.68	2.0596
2014	7	11	6	40	9	0.3	1	0.43	94.4	6.68	2.5259
2014	7	11	6	50	9	0.3	1	0.38	94.4	6.68	2.2733
2014	7	11	7	0	9	0.3	1	0.29	89.3	6.6994	1.7152
2014	7	11	7	10	9	0.3	1	0.38	110.2	6.68	2.1179
2014	7	11	7	20	9	0.3	1	0.4	95.2	6.68	2.3316
2014	7	11	7	30	9	0.3	1	0.38	96	6.68	2.215
2014	7	11	7	40	9	0.3	1	0.33	87.2	6.6994	1.9685
2014	7	11	7	50	9	0.3	1	0.41	90.9	6.6994	2.4168
2014	7	11	8	0	9	0.3	1	0.33	87.7	6.6994	1.9491
2014	7	11	8	10	9	0.3	1	0.33	97.3	6.6994	1.9685
2014	7	11	8	20	9	0.3	1	0.33	103.9	6.68	1.8847
2014	7	11	8	30	9	0.3	1	0.34	96	6.68	2.0207
2014	7	11	8	40	9	0.3	1	0.33	87.8	6.6994	1.988
2014	7	11	8	50	9	0.3	1	0.38	87	6.68	2.2539
2014	7	11	9	0	9	0.3	1	0.31	89.4	6.68	1.8653
2014	7	11	9	10	9	0.3	1	0.32	93	6.68	1.8653
2014	7	11	9	20	9	0.3	1	0.38	92	6.68	2.2345
2014	7	11	9	30	9	0.3	1	0.39	92.9	6.68	2.3316
2014	7	11	9	40	9	0.3	1	0.3	96.3	6.68	1.7681
2014	7	11	9	50	9	0.3	1	0.37	101.2	6.68	2.1567
2014	7	11	10	0	9	0.3	1	0.3	98.8	6.68	1.7487
2014	7	11	10	10	9	0.3	1	0.38	95.4	6.68	2.2539
2014	7	11	10	20	9	0.3	1	0.32	100.1	6.6607	1.8401
2014	7	11	10	30	9	0.3	1	0.39	91.5	6.68	2.2927
2014	7	11	10	40	9	0.3	1	0.32	90	6.68	1.8847
2014	7	11	10	50	9	0.3	1	0.36	75.6	6.6607	2.0338
2014	7	11	11	0	9	0.3	1	0.37	88	6.6607	2.1887
2014	7	11	11	10	9	0.3	1	0.4	86.2	6.6607	2.363
2014	7	11	11	20	9	0.3	1	0.35	94.4	6.6607	2.0337
2014	7	11	11	30	9	0.3	1	0.3	79.9	6.6413	1.7378
2014	7	11	11	40	9	0.3	1	0.33	90	6.6413	1.9308
2014	7	11	11	50	9	0.3	1	0.32	100.7	6.6413	1.8343
2014	7	11	12	0	9	0.3	1	0.34	87.3	6.6413	2.0274
2014	7	11	12	10	9	0.3	1	0.34	89.5	6.6219	2.021
2014	7	11	12	20	9	0.3	1	0.3	90.6	6.6219	1.7516
2014	7	11	12	30	9	0.3	1	0.28	91.4	6.6026	1.6118
2014	7	11	12	40	9	0.3	1	0.33	70.5	6.6026	1.842
2014	7	11	12	50	9	0.3	1	0.39	84.7	6.5832	2.2761

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	13	0	9	0.3	1	0.45	85.4	6.5832	2.6013
2014	7	11	13	10	9	0.3	1	0.28	90	6.5639	1.6397
2014	7	11	13	20	9	0.3	1	0.3	79.4	6.5252	1.7241
2014	7	11	13	30	9	0.3	1	0.28	83.3	6.5252	1.6104
2014	7	11	13	40	9	0.3	1	0.39	73.5	6.5058	2.1718
2014	7	11	13	50	9	0.3	1	0.34	78.5	6.4864	1.939
2014	7	11	14	0	9	0.3	1	0.31	79.6	6.4671	1.7451
2014	7	11	14	10	9	0.3	1	0.38	73.9	6.4671	2.0829
2014	7	11	14	20	9	0.3	1	0.3	88.1	6.4671	1.7263
2014	7	11	14	30	9	0.3	1	0.45	77.1	6.4671	2.5332
2014	7	11	14	40	9	0.3	1	0.3	86.3	6.4477	1.7208
2014	7	11	14	50	9	0.3	1	0.35	79.3	6.4477	1.9826
2014	7	11	15	0	9	0.3	1	0.32	76.8	6.4477	1.7582
2014	7	11	15	10	9	0.3	1	0.37	81.4	6.4477	2.1135
2014	7	11	15	20	9	0.3	1	0.33	88.9	6.4284	1.883
2014	7	11	15	30	9	0.3	1	0.27	70	6.4284	1.4355
2014	7	11	15	40	9	0.3	1	0.34	81	6.4284	1.883
2014	7	11	15	50	9	0.3	1	0.28	87.3	6.4284	1.6033
2014	7	11	16	0	9	0.3	1	0.4	73.7	6.409	2.1556
2014	7	11	16	10	9	0.3	1	0.32	89.4	6.409	1.8026
2014	7	11	16	20	9	0.3	1	0.32	90	6.409	1.8026
2014	7	11	16	30	9	0.3	1	0.29	86.1	6.409	1.6167
2014	7	11	16	40	9	0.3	1	0.28	71.8	6.3897	1.5189
2014	7	11	16	50	9	0.3	1	0.34	67.4	6.3897	1.7782
2014	7	11	17	0	9	0.3	1	0.37	76.3	6.3897	2.056
2014	7	11	17	10	9	0.3	1	0.3	86.9	6.3703	1.6986
2014	7	11	17	20	9	0.3	1	0.3	78.2	6.3703	1.6801
2014	7	11	17	30	9	0.3	1	0.27	85.1	6.3509	1.4906
2014	7	11	17	40	9	0.3	1	0.42	75.2	6.3509	2.3003
2014	7	11	17	50	9	0.3	1	0.29	77.1	6.3316	1.5958
2014	7	11	18	0	9	0.3	1	0.36	72.9	6.3316	1.9076
2014	7	11	18	10	9	0.3	1	0.34	97.1	6.3122	1.9013
2014	7	11	18	20	9	0.3	1	0.37	84.9	6.3122	2.0293
2014	7	11	18	30	9	0.3	1	0.32	79.4	6.2929	1.7493
2014	7	11	18	40	9	0.3	1	0.3	74.7	6.2929	1.6035
2014	7	11	18	50	9	0.3	1	0.3	84.4	6.2929	1.6582
2014	7	11	19	0	9	0.3	1	0.33	69.4	6.2735	1.689
2014	7	11	19	10	9	0.3	1	0.34	93.4	6.2735	1.8525
2014	7	11	19	20	9	0.3	1	0.34	88.9	6.2735	1.907
2014	7	11	19	30	9	0.3	1	0.3	69	6.2735	1.5619
2014	7	11	19	40	9	0.3	1	0.33	94.6	6.2735	1.798
2014	7	11	19	50	9	0.3	1	0.25	87	6.2735	1.3803
2014	7	11	20	0	9	0.3	1	0.3	85.6	6.2735	1.6527
2014	7	11	20	10	9	0.3	1	0.31	82.7	6.2542	1.7016
2014	7	11	20	20	9	0.3	1	0.3	84.4	6.2542	1.6473
2014	7	11	20	30	9	0.3	1	0.29	86.7	6.2542	1.593

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	20	40	9	0.3	1	0.33	83.7	6.2542	1.8102
2014	7	11	20	50	9	0.3	1	0.3	98.2	6.2735	1.6346
2014	7	11	21	0	9	0.3	1	0.29	92	6.2542	1.593
2014	7	11	21	10	9	0.3	1	0.26	86.3	6.2542	1.412
2014	7	11	21	20	9	0.3	1	0.36	97.3	6.2542	1.9912
2014	7	11	21	30	9	0.3	1	0.21	93.5	6.2542	1.1766
2014	7	11	21	40	9	0.3	1	0.29	97.2	6.2735	1.5801
2014	7	11	21	50	9	0.3	1	0.27	94.2	6.2735	1.4893
2014	7	11	22	0	9	0.3	1	0.31	78.9	6.2735	1.6709
2014	7	11	22	10	9	0.3	1	0.33	93.5	6.2735	1.7981
2014	7	11	22	20	9	0.3	1	0.25	90	6.2735	1.3804
2014	7	11	22	30	9	0.3	1	0.31	83.4	6.2735	1.7254
2014	7	11	22	40	9	0.3	1	0.3	91.3	6.2929	1.6583
2014	7	11	22	50	9	0.3	1	0.31	91.2	6.2929	1.7129
2014	7	11	23	0	9	0.3	1	0.3	87.5	6.2929	1.6583
2014	7	11	23	10	9	0.3	1	0.24	97.8	6.2929	1.3303
2014	7	11	23	20	9	0.3	1	0.3	91.9	6.3122	1.6455
2014	7	11	23	30	9	0.3	1	0.33	85.4	6.3122	1.8283
2014	7	11	23	40	9	0.3	1	0.29	99.1	6.3316	1.5959
2014	7	11	23	50	9	0.3	1	0.24	86.9	6.3316	1.3574
2014	7	12	0	0	9	0.3	1	0.28	88	6.3122	1.5541
2014	7	12	0	10	9	0.3	1	0.31	103	6.3316	1.6693
2014	7	12	0	20	9	0.3	1	0.22	90	6.3316	1.2474
2014	7	12	0	30	9	0.3	1	0.3	94.4	6.3316	1.6693
2014	7	12	0	40	9	0.3	1	0.28	94	6.3122	1.5541
2014	7	12	0	50	9	0.3	1	0.33	91.7	6.3122	1.8283
2014	7	12	1	0	9	0.3	1	0.22	95	6.3122	1.2433
2014	7	12	1	10	9	0.3	1	0.3	90.6	6.2929	1.6583
2014	7	12	1	20	9	0.3	1	0.28	90.7	6.2929	1.549
2014	7	12	1	30	9	0.3	1	0.25	76.3	6.2735	1.3441
2014	7	12	1	40	9	0.3	1	0.34	80.4	6.2735	1.8345
2014	7	12	1	50	9	0.3	1	0.29	87.4	6.2542	1.575
2014	7	12	2	0	9	0.3	1	0.24	101	6.2542	1.3034
2014	7	12	2	10	9	0.3	1	0.29	87.4	6.2348	1.5697
2014	7	12	2	20	9	0.3	1	0.28	94.7	6.2348	1.5336
2014	7	12	2	30	9	0.3	1	0.25	76.1	6.2348	1.3171
2014	7	12	2	40	9	0.3	1	0.25	86.9	6.2348	1.3532
2014	7	12	2	50	9	0.3	1	0.28	98	6.2348	1.5336
2014	7	12	3	0	9	0.3	1	0.28	92.7	6.2154	1.5106
2014	7	12	3	10	9	0.3	1	0.24	93.2	6.2154	1.2948
2014	7	12	3	20	9	0.3	1	0.28	94	6.2154	1.5285
2014	7	12	3	30	9	0.3	1	0.17	91.1	6.2154	0.9351
2014	7	12	3	40	9	0.3	1	0.33	94.6	6.2154	1.7983
2014	7	12	3	50	9	0.3	1	0.3	98.8	6.1961	1.613
2014	7	12	4	0	9	0.3	1	0.22	69.1	6.1961	1.1291
2014	7	12	4	10	9	0.3	1	0.17	90	6.1961	0.9499

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	4	20	9	0.3	1	0.3	72.6	6.1961	1.5414
2014	7	12	4	30	9	0.3	1	0.29	86.7	6.1961	1.5593
2014	7	12	4	40	9	0.3	1	0.24	91.6	6.1961	1.3084
2014	7	12	4	50	9	0.3	1	0.3	97.4	6.1767	1.6434
2014	7	12	5	0	9	0.3	1	0.34	106.7	6.1767	1.7863
2014	7	12	5	10	9	0.3	1	0.32	76.8	6.1767	1.6791
2014	7	12	5	20	9	0.3	1	0.23	87.5	6.1767	1.2325
2014	7	12	5	30	9	0.3	1	0.24	94.7	6.1767	1.304
2014	7	12	5	40	9	0.3	1	0.31	100.5	6.1767	1.6434
2014	7	12	5	50	9	0.3	1	0.27	94.2	6.1767	1.4469
2014	7	12	6	0	9	0.3	1	0.3	88.8	6.1767	1.6434
2014	7	12	6	10	9	0.3	1	0.23	97.3	6.1767	1.2504
2014	7	12	6	20	9	0.3	1	0.21	108.4	6.1767	1.0718
2014	7	12	6	30	9	0.3	1	0.28	90.7	6.1767	1.5005
2014	7	12	6	40	9	0.3	1	0.31	87	6.1574	1.6735
2014	7	12	6	50	9	0.3	1	0.23	90	6.1574	1.2462
2014	7	12	7	0	9	0.3	1	0.26	102.4	6.1574	1.3708
2014	7	12	7	10	9	0.3	1	0.27	97	6.1574	1.442
2014	7	12	7	20	9	0.3	1	0.2	81.6	6.1574	1.086
2014	7	12	7	30	9	0.3	1	0.24	97.7	6.1574	1.3174
2014	7	12	7	40	9	0.3	1	0.21	100.8	6.1574	1.1216
2014	7	12	7	50	9	0.3	1	0.25	80.9	6.1574	1.3352
2014	7	12	8	0	9	0.3	1	0.16	81.9	6.1574	0.8723
2014	7	12	8	10	9	0.3	1	0.16	88.8	6.1574	0.8723
2014	7	12	8	20	9	0.3	1	0.16	97.3	6.1574	0.8367
2014	7	12	8	30	9	0.3	1	0.18	103.5	6.1574	0.9614
2014	7	12	8	40	9	0.3	1	0.21	90	6.1574	1.1572
2014	7	12	8	50	9	0.3	1	0.3	90	6.1574	1.6201
2014	7	12	9	0	9	0.3	1	0.27	90	6.1574	1.4776
2014	7	12	9	10	9	0.3	1	0.28	86	6.1574	1.531
2014	7	12	9	20	9	0.3	1	0.22	80.7	6.1574	1.1928
2014	7	12	9	30	9	0.3	1	0.24	92.4	6.1574	1.2818
2014	7	12	9	40	9	0.3	1	0.2	105.8	6.138	1.0646
2014	7	12	9	50	9	0.3	1	0.24	69.1	6.138	1.2065
2014	7	12	10	0	9	0.3	1	0.22	79.5	6.138	1.1533
2014	7	12	10	10	9	0.3	1	0.21	97.1	6.138	1.1355
2014	7	12	10	20	9	0.3	1	0.25	81.7	6.138	1.3307
2014	7	12	10	30	9	0.3	1	0.24	73.5	6.138	1.2597
2014	7	12	10	40	9	0.3	1	0.24	83	6.1187	1.2908
2014	7	12	10	50	9	0.3	1	0.17	79.8	6.1187	0.8841
2014	7	12	11	0	9	0.3	1	0.24	84.5	6.1187	1.2908
2014	7	12	11	10	9	0.3	1	0.25	84.7	6.1187	1.3262
2014	7	12	11	20	9	0.3	1	0.26	86.4	6.0993	1.3921
2014	7	12	11	30	9	0.3	1	0.23	81.6	6.0993	1.1983
2014	7	12	11	40	9	0.3	1	0.23	72.8	6.08	1.1942
2014	7	12	11	50	9	0.3	1	0.23	51.8	6.0219	0.9734

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	12	0	9	0.3	1	0.37	62.3	6.0219	1.7555
2014	7	12	12	10	9	0.3	1	0.3	63.4	6.0219	1.4253
2014	7	12	12	20	9	0.3	1	0.2	68.6	6.0025	0.97
2014	7	12	12	30	9	0.3	1	0.27	64.4	6.0025	1.2645
2014	7	12	12	40	9	0.3	1	0.23	76.8	6.0025	1.1778
2014	7	12	12	50	9	0.3	1	0.2	89.1	6.0025	1.0739
2014	7	12	13	0	9	0.3	1	0.18	57.4	5.9832	0.8113
2014	7	12	13	10	9	0.3	1	0.29	73.6	5.9832	1.4672
2014	7	12	13	20	9	0.3	1	0.23	66.7	5.9832	1.1219
2014	7	12	13	30	9	0.3	1	0.31	69.7	5.9832	1.5362
2014	7	12	13	40	9	0.3	1	0.27	89.3	5.9832	1.4326
2014	7	12	13	50	9	0.3	1	0.26	85.6	5.9832	1.3463
2014	7	12	14	0	9	0.3	1	0.28	75.3	5.9638	1.4448
2014	7	12	14	10	9	0.3	1	0.27	74.2	5.9638	1.3416
2014	7	12	14	20	9	0.3	1	0.31	88.8	5.9638	1.5996
2014	7	12	14	30	9	0.3	1	0.27	60.3	5.9638	1.2384
2014	7	12	14	40	9	0.3	1	0.24	79.9	5.9445	1.2512
2014	7	12	14	50	9	0.3	1	0.27	76.5	5.9445	1.3541
2014	7	12	15	0	9	0.3	1	0.3	76.1	5.9445	1.5255
2014	7	12	15	10	9	0.3	1	0.28	77.1	5.9251	1.4176
2014	7	12	15	20	9	0.3	1	0.22	64.9	5.9251	1.059
2014	7	12	15	30	9	0.3	1	0.25	72.3	5.9251	1.2297
2014	7	12	15	40	9	0.3	1	0.28	77.9	5.9251	1.4347
2014	7	12	15	50	9	0.3	1	0.24	75.2	5.9057	1.2254
2014	7	12	16	0	9	0.3	1	0.26	77.4	5.9057	1.2935
2014	7	12	16	10	9	0.3	1	0.23	78.5	5.9057	1.1744
2014	7	12	16	20	9	0.3	1	0.21	82.8	5.867	1.0647
2014	7	12	16	30	9	0.3	1	0.24	71.6	5.867	1.1661
2014	7	12	16	40	9	0.3	1	0.26	78.4	5.8477	1.3135
2014	7	12	16	50	9	0.3	1	0.23	71.6	5.8477	1.1114
2014	7	12	17	0	9	0.3	1	0.24	68.3	5.8283	1.141
2014	7	12	17	10	9	0.3	1	0.23	65.3	5.8283	1.0571
2014	7	12	17	20	9	0.3	1	0.25	63.4	5.8283	1.141
2014	7	12	17	30	9	0.3	1	0.29	57.6	5.809	1.2373
2014	7	12	17	40	9	0.3	1	0.25	59.4	5.809	1.1035
2014	7	12	17	50	9	0.3	1	0.26	67.4	5.809	1.2038
2014	7	12	18	0	9	0.3	1	0.28	82.7	5.809	1.4379
2014	7	12	18	10	9	0.3	1	0.23	77.6	5.809	1.1369
2014	7	12	18	20	9	0.3	1	0.21	68.2	5.7896	0.9996
2014	7	12	18	30	9	0.3	1	0.3	70.6	5.7896	1.4161
2014	7	12	18	40	9	0.3	1	0.28	66.4	5.7896	1.2995
2014	7	12	18	50	9	0.3	1	0.23	84.4	5.7896	1.1828
2014	7	12	19	0	9	0.3	1	0.2	49.7	5.7896	0.7664
2014	7	12	19	10	9	0.3	1	0.25	55.1	5.7896	1.0496
2014	7	12	19	20	9	0.3	1	0.18	74.2	5.7896	0.883
2014	7	12	19	30	9	0.3	1	0.2	74.2	5.7896	0.9996

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	19	40	9	0.3	1	0.19	79.1	5.7896	0.9496
2014	7	12	19	50	9	0.3	1	0.27	77.9	5.7896	1.3161
2014	7	12	20	0	9	0.3	1	0.24	76	5.7896	1.1995
2014	7	12	20	10	9	0.3	1	0.26	92.9	5.7702	1.3114
2014	7	12	20	20	9	0.3	1	0.13	94.2	5.7896	0.6831
2014	7	12	20	30	9	0.3	1	0.23	87.6	5.7896	1.1829
2014	7	12	20	40	9	0.3	1	0.23	90	5.7896	1.1662
2014	7	12	20	50	9	0.3	1	0.22	86.6	5.7896	1.1162
2014	7	12	21	0	9	0.3	1	0.19	73.1	5.7896	0.933
2014	7	12	21	10	9	0.3	1	0.23	85.9	5.7896	1.1662
2014	7	12	21	20	9	0.3	1	0.18	84.8	5.7896	0.9163
2014	7	12	21	30	9	0.3	1	0.25	85.4	5.7896	1.2495
2014	7	12	21	40	9	0.3	1	0.16	69.7	5.7896	0.7664
2014	7	12	21	50	9	0.3	1	0.24	79.9	5.7896	1.2162
2014	7	12	22	0	9	0.3	1	0.17	77.8	5.7896	0.8497
2014	7	12	22	10	9	0.3	1	0.21	89.1	5.7896	1.0496
2014	7	12	22	20	9	0.3	1	0.23	86.7	5.7896	1.1662
2014	7	12	22	30	9	0.3	1	0.16	102.9	5.7896	0.7997
2014	7	12	22	40	9	0.3	1	0.15	90	5.7896	0.7497
2014	7	12	22	50	9	0.3	1	0.17	81.3	5.7896	0.8663
2014	7	12	23	0	9	0.3	1	0.22	94.3	5.7896	1.0996
2014	7	12	23	10	9	0.3	1	0.15	83.8	5.7896	0.7664
2014	7	12	23	20	9	0.3	1	0.23	90.8	5.809	1.1872
2014	7	12	23	30	9	0.3	1	0.13	90	5.809	0.6688
2014	7	12	23	40	9	0.3	1	0.19	94.8	5.809	0.9865
2014	7	12	23	50	9	0.3	1	0.2	82.3	5.809	0.9865
2014	7	13	0	0	9	0.3	1	0.2	90	5.7896	0.9996
2014	7	13	0	10	9	0.3	1	0.16	129.2	5.809	0.6354
2014	7	13	0	20	9	0.3	1	0.17	95.5	5.809	0.8695
2014	7	13	0	30	9	0.3	1	0.23	85	5.809	1.1537
2014	7	13	0	40	9	0.3	1	0.18	85.8	5.809	0.9197
2014	7	13	0	50	9	0.3	1	0.19	86.1	5.7896	0.9663
2014	7	13	1	0	9	0.3	1	0.16	90	5.7896	0.7997
2014	7	13	1	10	9	0.3	1	0.17	88.9	5.7896	0.8664
2014	7	13	1	20	9	0.3	1	0.17	76.8	5.7896	0.8497
2014	7	13	1	30	9	0.3	1	0.22	77.2	5.7896	1.0996
2014	7	13	1	40	9	0.3	1	0.12	96.3	5.7896	0.5998
2014	7	13	1	50	9	0.3	1	0.22	75.3	5.7896	1.083
2014	7	13	2	0	9	0.3	1	0.19	90	5.7896	0.9664
2014	7	13	2	10	9	0.3	1	0.14	100.8	5.7896	0.6998
2014	7	13	2	20	9	0.3	1	0.2	77.6	5.7702	0.9795
2014	7	13	2	30	9	0.3	1	0.15	97.4	5.7702	0.7637
2014	7	13	2	40	9	0.3	1	0.2	90	5.7702	1.0293
2014	7	13	2	50	9	0.3	1	0.18	101.7	5.7702	0.8799
2014	7	13	3	0	9	0.3	1	0.16	75.4	5.7702	0.7637
2014	7	13	3	10	9	0.3	1	0.17	97.8	5.7702	0.8467

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	3	20	9	0.3	1	0.17	86.7	5.7702	0.8633
2014	7	13	3	30	9	0.3	1	0.17	96.5	5.7702	0.8799
2014	7	13	3	40	9	0.3	1	0.16	65	5.7702	0.7471
2014	7	13	3	50	9	0.3	1	0.12	66.8	5.7702	0.5811
2014	7	13	4	0	9	0.3	1	0.23	85.9	5.7509	1.1579
2014	7	13	4	10	9	0.3	1	0.17	87.8	5.7509	0.8767
2014	7	13	4	20	9	0.3	1	0.14	73.7	5.7509	0.6782
2014	7	13	4	30	9	0.3	1	0.15	98.8	5.7509	0.7444
2014	7	13	4	40	9	0.3	1	0.21	95.3	5.7509	1.0752
2014	7	13	4	50	9	0.3	1	0.22	74.3	5.7509	1.0587
2014	7	13	5	0	9	0.3	1	0.26	83.6	5.7509	1.3234
2014	7	13	5	10	9	0.3	1	0.2	92.8	5.7509	1.0256
2014	7	13	5	20	9	0.3	1	0.13	92.8	5.7509	0.6782
2014	7	13	5	30	9	0.3	1	0.19	95.9	5.7509	0.9594
2014	7	13	5	40	9	0.3	1	0.25	90.8	5.7509	1.2572
2014	7	13	5	50	9	0.3	1	0.14	80.3	5.7315	0.6758
2014	7	13	6	0	9	0.3	1	0.16	87.7	5.7315	0.8241
2014	7	13	6	10	9	0.3	1	0.18	83.7	5.7315	0.89
2014	7	13	6	20	9	0.3	1	0.17	90	5.7315	0.8406
2014	7	13	6	30	9	0.3	1	0.22	82.1	5.7315	1.0713
2014	7	13	6	40	9	0.3	1	0.27	99.9	5.7315	1.3186
2014	7	13	6	50	9	0.3	1	0.21	87.3	5.7315	1.0549
2014	7	13	7	0	9	0.3	1	0.14	93.9	5.7315	0.7252
2014	7	13	7	10	9	0.3	1	0.16	80.7	5.7315	0.8076
2014	7	13	7	20	9	0.3	1	0.12	83.7	5.7315	0.5934
2014	7	13	7	30	9	0.3	1	0.16	90	5.7315	0.8241
2014	7	13	7	40	9	0.3	1	0.2	73	5.7315	0.9725
2014	7	13	7	50	9	0.3	1	0.17	96.5	5.7315	0.8736
2014	7	13	8	0	9	0.3	1	0.19	101.9	5.7315	0.9395
2014	7	13	8	10	9	0.3	1	0.22	84.8	5.7315	1.0878
2014	7	13	8	20	9	0.3	1	0.19	90	5.7315	0.956
2014	7	13	8	30	9	0.3	1	0.13	94.3	5.7315	0.6593
2014	7	13	8	40	9	0.3	1	0.15	84.9	5.7315	0.7417
2014	7	13	8	50	9	0.3	1	0.2	84.4	5.7315	1.0054
2014	7	13	9	0	9	0.3	1	0.17	92.2	5.7315	0.8735
2014	7	13	9	10	9	0.3	1	0.18	117.5	5.7315	0.8241
2014	7	13	9	20	9	0.3	1	0.17	97.8	5.7315	0.8406
2014	7	13	9	30	9	0.3	1	0.2	93.7	5.7315	1.0219
2014	7	13	9	40	9	0.3	1	0.17	80.9	5.7315	0.8241
2014	7	13	9	50	9	0.3	1	0.16	97.3	5.7315	0.7746
2014	7	13	10	0	9	0.3	1	0.2	75.7	5.7315	0.9724
2014	7	13	10	10	9	0.3	1	0.18	73.2	5.7315	0.8735
2014	7	13	10	20	9	0.3	1	0.24	77.5	5.7315	1.1867
2014	7	13	10	30	9	0.3	1	0.22	77.8	5.7315	1.0713
2014	7	13	10	40	9	0.3	1	0.16	94.8	5.7122	0.7882
2014	7	13	10	50	9	0.3	1	0.13	74.9	5.7122	0.6076

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	11	0	9	0.3	1	0.24	93.2	5.7122	1.1824
2014	7	13	11	10	9	0.3	1	0.22	87.4	5.7122	1.0838
2014	7	13	11	20	9	0.3	1	0.21	73	5.7122	1.0181
2014	7	13	11	30	9	0.3	1	0.14	71.1	5.7122	0.6733
2014	7	13	11	40	9	0.3	1	0.17	82.2	5.6928	0.8344
2014	7	13	11	50	9	0.3	1	0.19	100.1	5.6928	0.9162
2014	7	13	12	0	9	0.3	1	0.16	71.2	5.6928	0.769
2014	7	13	12	10	9	0.3	1	0.21	75.5	5.6928	1.0144
2014	7	13	12	20	9	0.3	1	0.23	59	5.6928	0.9817
2014	7	13	12	30	9	0.3	1	0.17	73	5.6928	0.8017
2014	7	13	12	40	9	0.3	1	0.17	60.5	5.6735	0.7499
2014	7	13	12	50	9	0.3	1	0.14	67	5.6735	0.6521
2014	7	13	13	0	9	0.3	1	0.17	77.6	5.6735	0.8151
2014	7	13	13	10	9	0.3	1	0.19	54.1	5.6541	0.7633
2014	7	13	13	20	9	0.3	1	0.25	82.4	5.6347	1.2136
2014	7	13	13	30	9	0.3	1	0.2	79.4	5.6347	0.9547
2014	7	13	13	40	9	0.3	1	0.21	71.8	5.6347	0.9871
2014	7	13	13	50	9	0.3	1	0.26	82	5.596	1.2528
2014	7	13	14	0	9	0.3	1	0.23	66.4	5.596	1.0279
2014	7	13	14	10	9	0.3	1	0.26	86.3	5.5767	1.2481
2014	7	13	14	20	9	0.3	1	0.15	64.6	5.5767	0.6401
2014	7	13	14	30	9	0.3	1	0.19	70.9	5.5573	0.8768
2014	7	13	14	40	9	0.3	1	0.17	78.1	5.5573	0.829
2014	7	13	14	50	9	0.3	1	0.15	75.7	5.5573	0.6855
2014	7	13	15	0	9	0.3	1	0.2	78	5.5573	0.9724
2014	7	13	15	10	9	0.3	1	0.15	71.2	5.5573	0.7014
2014	7	13	15	20	9	0.3	1	0.22	78.2	5.538	1.0641
2014	7	13	15	30	9	0.3	1	0.19	60.4	5.538	0.81
2014	7	13	15	40	9	0.3	1	0.24	75.8	5.538	1.1276
2014	7	13	15	50	9	0.3	1	0.18	69.9	5.538	0.8258
2014	7	13	16	0	9	0.3	1	0.13	100.4	5.538	0.6035
2014	7	13	16	10	9	0.3	1	0.25	70.4	5.538	1.1593
2014	7	13	16	20	9	0.3	1	0.21	90	5.538	1.0005
2014	7	13	16	30	9	0.3	1	0.17	70.9	5.538	0.7782
2014	7	13	16	40	9	0.3	1	0.23	61.6	5.538	1.0005
2014	7	13	16	50	9	0.3	1	0.2	78.9	5.538	0.9688
2014	7	13	17	0	9	0.3	1	0.22	69.4	5.5186	1.0126
2014	7	13	17	10	9	0.3	1	0.15	74.7	5.5186	0.6961
2014	7	13	17	20	9	0.3	1	0.21	85.5	5.5186	1.0126
2014	7	13	17	30	9	0.3	1	0.19	75.7	5.5186	0.8702
2014	7	13	17	40	9	0.3	1	0.24	90	5.5186	1.155
2014	7	13	17	50	9	0.3	1	0.19	72.8	5.5186	0.8702
2014	7	13	18	0	9	0.3	1	0.18	68.6	5.4993	0.8038
2014	7	13	18	10	9	0.3	1	0.18	82.7	5.4993	0.8669
2014	7	13	18	20	9	0.3	1	0.18	91	5.4993	0.8669
2014	7	13	18	30	9	0.3	1	0.22	54.2	5.4993	0.8511

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	18	40	9	0.3	1	0.22	43.2	5.4993	0.7093
2014	7	13	18	50	9	0.3	1	0.3	70	5.4993	1.3397
2014	7	13	19	0	9	0.3	1	0.24	64.8	5.4993	1.0403
2014	7	13	19	10	9	0.3	1	0.19	43.6	5.4993	0.6305
2014	7	13	19	20	9	0.3	1	0.25	55.3	5.4993	0.9772
2014	7	13	19	30	9	0.3	1	0.11	59	5.4993	0.4728
2014	7	13	19	40	9	0.3	1	0.26	62.1	5.4993	1.1033
2014	7	13	19	50	9	0.3	1	0.18	60.6	5.4993	0.7566
2014	7	13	20	0	9	0.3	1	0.23	77.4	5.4799	1.052
2014	7	13	20	10	9	0.3	1	0.22	89.1	5.4799	1.052
2014	7	13	20	20	9	0.3	1	0.18	52.5	5.4799	0.6752
2014	7	13	20	30	9	0.3	1	0.15	82.2	5.4799	0.6909
2014	7	13	20	40	9	0.3	1	0.18	84.8	5.4799	0.8636
2014	7	13	20	50	9	0.3	1	0.12	76	5.4799	0.5653
2014	7	13	21	0	9	0.3	1	0.11	90	5.4799	0.5496
2014	7	13	21	10	9	0.3	1	0.12	94.8	5.4799	0.5653
2014	7	13	21	20	9	0.3	1	0.17	109.8	5.4993	0.7881
2014	7	13	21	30	9	0.3	1	0.11	68.8	5.4993	0.4886
2014	7	13	21	40	9	0.3	1	0.19	107.8	5.4993	0.8827
2014	7	13	21	50	9	0.3	1	0.12	71.6	5.4993	0.5674
2014	7	13	22	0	9	0.3	1	0.1	101.3	5.4993	0.4729
2014	7	13	22	10	9	0.3	1	0.18	74.5	5.4993	0.8511
2014	7	13	22	20	9	0.3	1	0.15	83.7	5.4993	0.7093
2014	7	13	22	30	9	0.3	1	0.23	86.7	5.5186	1.0917
2014	7	13	22	40	9	0.3	1	0.16	87.6	5.5186	0.7594
2014	7	13	22	50	9	0.3	1	0.18	84.7	5.5186	0.8544
2014	7	13	23	0	9	0.3	1	0.14	80.8	5.5186	0.6803
2014	7	13	23	10	9	0.3	1	0.09	102.1	5.5186	0.443
2014	7	13	23	20	9	0.3	1	0.11	90	5.5186	0.5538
2014	7	13	23	30	9	0.3	1	0.07	73.3	5.5186	0.3164
2014	7	13	23	40	9	0.3	1	0.14	81.7	5.5186	0.6487
2014	7	13	23	50	9	0.3	1	0.17	86.6	5.5186	0.8069
2014	7	14	0	0	9	0.3	1	0.17	101.9	5.5186	0.8227
2014	7	14	0	10	9	0.3	1	0.15	92.5	5.5186	0.712
2014	7	14	0	20	9	0.3	1	0.18	104.5	5.5186	0.8544
2014	7	14	0	30	9	0.3	1	0.21	77.7	5.5186	1.0126
2014	7	14	0	40	9	0.3	1	0.15	90	5.5186	0.7436
2014	7	14	0	50	9	0.3	1	0.13	120.5	5.5186	0.538
2014	7	14	1	0	9	0.3	1	0.23	90	5.5186	1.1234
2014	7	14	1	10	9	0.3	1	0.12	77.8	5.5186	0.5854
2014	7	14	1	20	9	0.3	1	0.16	55.7	5.5186	0.6487
2014	7	14	1	30	9	0.3	1	0.13	64.1	5.5186	0.5854
2014	7	14	1	40	9	0.3	1	0.17	78.1	5.5186	0.8228
2014	7	14	1	50	9	0.3	1	0.11	93.4	5.5186	0.538
2014	7	14	2	0	9	0.3	1	0.13	75.6	5.5186	0.6171
2014	7	14	2	10	9	0.3	1	0.15	69.6	5.5186	0.6804

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	2	20	9	0.3	1	0.12	83.7	5.5186	0.5696
2014	7	14	2	30	9	0.3	1	0.17	84.6	5.5186	0.8386
2014	7	14	2	40	9	0.3	1	0.13	90	5.5186	0.6329
2014	7	14	2	50	9	0.3	1	0.12	82.1	5.538	0.5718
2014	7	14	3	0	9	0.3	1	0.1	86.1	5.538	0.4606
2014	7	14	3	10	9	0.3	1	0.16	94.8	5.538	0.7624
2014	7	14	3	20	9	0.3	1	0.18	83.7	5.538	0.8577
2014	7	14	3	30	9	0.3	1	0.14	91.4	5.5573	0.6696
2014	7	14	3	40	9	0.3	1	0.17	98	5.5573	0.7971
2014	7	14	3	50	9	0.3	1	0.13	101.6	5.5767	0.6241
2014	7	14	4	0	9	0.3	1	0.13	99	5.596	0.6104
2014	7	14	4	10	9	0.3	1	0.09	114.6	5.6347	0.3884
2014	7	14	4	20	9	0.3	1	0.18	71.9	5.6541	0.8446
2014	7	14	4	30	9	0.3	1	0.24	90	5.6735	1.1737
2014	7	14	4	40	9	0.3	1	0.17	83.4	5.6735	0.8477
2014	7	14	4	50	9	0.3	1	0.17	92.2	5.6928	0.8672
2014	7	14	5	0	9	0.3	1	0.22	85.7	5.6928	1.0799
2014	7	14	5	10	9	0.3	1	0.14	84.7	5.7122	0.7061
2014	7	14	5	20	9	0.3	1	0.16	83	5.7122	0.8047
2014	7	14	5	30	9	0.3	1	0.15	78.9	5.7122	0.7554
2014	7	14	5	40	9	0.3	1	0.07	66.8	5.7315	0.3461
2014	7	14	5	50	9	0.3	1	0.17	108.4	5.7315	0.7911
2014	7	14	6	0	9	0.3	1	0.17	84.4	5.7315	0.8406
2014	7	14	6	10	9	0.3	1	0.17	101.1	5.7315	0.8406
2014	7	14	6	20	9	0.3	1	0.14	90	5.7315	0.7252
2014	7	14	6	30	9	0.3	1	0.17	100	5.7509	0.8436
2014	7	14	6	40	9	0.3	1	0.19	93.9	5.7509	0.9594
2014	7	14	6	50	9	0.3	1	0.16	88.8	5.7509	0.8105
2014	7	14	7	0	9	0.3	1	0.2	64.3	5.7509	0.9263
2014	7	14	7	10	9	0.3	1	0.2	82.5	5.7509	1.009
2014	7	14	7	20	9	0.3	1	0.16	51	5.7509	0.612
2014	7	14	7	30	9	0.3	1	0.15	79.7	5.7509	0.7278
2014	7	14	7	40	9	0.3	1	0.17	96.8	5.7509	0.8271
2014	7	14	7	50	9	0.3	1	0.17	82.2	5.7509	0.8436
2014	7	14	8	0	9	0.3	1	0.13	79.8	5.7509	0.6451
2014	7	14	8	10	9	0.3	1	0.11	83.3	5.7509	0.5624
2014	7	14	8	20	9	0.3	1	0.14	75.3	5.7509	0.6947
2014	7	14	8	30	9	0.3	1	0.17	96.5	5.7509	0.8767
2014	7	14	8	40	9	0.3	1	0.22	101.1	5.7509	1.0917
2014	7	14	8	50	9	0.3	1	0.2	73.9	5.7509	0.976
2014	7	14	9	0	9	0.3	1	0.21	85.5	5.7509	1.0421
2014	7	14	9	10	9	0.3	1	0.14	66.4	5.7509	0.6451
2014	7	14	9	20	9	0.3	1	0.18	70.3	5.7509	0.8767
2014	7	14	9	30	9	0.3	1	0.18	64.8	5.7509	0.8436
2014	7	14	9	40	9	0.3	1	0.16	62.4	5.7509	0.6947
2014	7	14	9	50	9	0.3	1	0.17	105.6	5.7509	0.8271

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	10	0	9	0.3	1	0.19	85	5.7509	0.9429
2014	7	14	10	10	9	0.3	1	0.17	100	5.7315	0.8406
2014	7	14	10	20	9	0.3	1	0.17	94.3	5.7315	0.8735
2014	7	14	10	30	9	0.3	1	0.24	73.8	5.7315	1.1372
2014	7	14	10	40	9	0.3	1	0.16	74.5	5.7509	0.7774
2014	7	14	10	50	9	0.3	1	0.22	87.4	5.7509	1.0917
2014	7	14	11	0	9	0.3	1	0.24	78.4	5.7509	1.2075
2014	7	14	11	10	9	0.3	1	0.25	73.2	5.7315	1.2031
2014	7	14	11	20	9	0.3	1	0.22	100.5	5.7315	1.0713
2014	7	14	11	30	9	0.3	1	0.19	58.5	5.7509	0.8105
2014	7	14	11	40	9	0.3	1	0.21	78.5	5.7509	1.0586
2014	7	14	11	50	9	0.3	1	0.24	75.8	5.7509	1.1744
2014	7	14	12	2	18	0.3	1	0.19	75.3	5.7509	0.9428
2014	7	14	12	12	18	0.3	1	0.24	90.8	5.7509	1.2075
2014	7	14	12	22	18	0.3	1	0.19	82.1	5.7509	0.9594
2014	7	14	12	32	18	0.3	1	0.17	77.8	5.7509	0.8436
2014	7	14	12	42	18	0.3	1	0.29	88	5.7509	1.4556
2014	7	14	12	52	18	0.3	1	0.25	82.5	5.7509	1.2571
2014	7	14	13	2	18	0.3	1	0.19	74.3	5.7509	0.9428
2014	7	14	13	12	18	0.3	1	0.2	87.2	5.7509	1.009
2014	7	14	13	22	18	0.3	1	0.27	78.1	5.7509	1.3398
2014	7	14	13	32	18	0.3	1	0.25	80.2	5.7509	1.2405
2014	7	14	13	42	18	0.3	1	0.21	90	5.7702	1.0458
2014	7	14	13	52	18	0.3	1	0.22	62.7	5.7702	0.996
2014	7	14	14	2	18	0.3	1	0.23	69.7	5.7702	1.079
2014	7	14	14	12	18	0.3	1	0.23	75.8	5.7702	1.1122
2014	7	14	14	22	18	0.3	1	0.24	72.6	5.7702	1.162
2014	7	14	14	32	18	0.3	1	0.3	63.7	5.7702	1.3778
2014	7	14	14	42	18	0.3	1	0.26	64.4	5.7702	1.1786
2014	7	14	14	52	18	0.3	1	0.17	67.8	5.7702	0.8134
2014	7	14	15	2	18	0.3	1	0.24	79	5.7702	1.1952
2014	7	14	15	12	18	0.3	1	0.25	70.6	5.7702	1.1786
2014	7	14	15	22	18	0.3	1	0.19	90	5.7702	0.9794
2014	7	14	15	32	18	0.3	1	0.2	57.9	5.7896	0.8497
2014	7	14	15	42	18	0.3	1	0.27	70	5.7896	1.2828
2014	7	14	15	52	18	0.3	1	0.22	74.3	5.7702	1.0624
2014	7	14	16	2	18	0.3	1	0.22	67.2	5.7896	1.0329
2014	7	14	16	12	18	0.3	1	0.24	75.8	5.7896	1.1829
2014	7	14	16	22	18	0.3	1	0.26	75.4	5.7896	1.2828
2014	7	14	16	32	18	0.3	1	0.19	63.9	5.7896	0.8497
2014	7	14	16	42	18	0.3	1	0.25	67.2	5.7896	1.1496
2014	7	14	16	52	18	0.3	1	0.22	61.5	5.7896	0.9829
2014	7	14	17	2	18	0.3	1	0.24	66.6	5.7896	1.1162
2014	7	14	17	12	18	0.3	1	0.23	58.6	5.7896	0.9829
2014	7	14	17	22	18	0.3	1	0.24	60.6	5.7896	1.0662
2014	7	14	17	32	18	0.3	1	0.24	75.8	5.7896	1.1829

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	17	42	18	0.3	1	0.24	53.3	5.7896	0.983
2014	7	14	17	52	18	0.3	1	0.3	66.6	5.7896	1.3828
2014	7	14	18	2	18	0.3	1	0.26	75.6	5.7896	1.2995
2014	7	14	18	12	18	0.3	1	0.31	85.7	5.7896	1.5494
2014	7	14	18	22	18	0.3	1	0.21	90	5.7896	1.0829
2014	7	14	18	32	18	0.3	1	0.34	68.8	5.809	1.6386
2014	7	14	18	42	18	0.3	1	0.25	80.8	5.809	1.2373
2014	7	14	18	52	18	0.3	1	0.16	94.6	5.809	0.836
2014	7	14	19	2	18	0.3	1	0.21	71.3	5.7896	1.0329
2014	7	14	19	12	18	0.3	1	0.25	86.3	5.809	1.2875
2014	7	14	19	22	18	0.3	1	0.25	84.1	5.809	1.2875
2014	7	14	19	32	18	0.3	1	0.17	85.7	5.809	0.8862
2014	7	14	19	42	18	0.3	1	0.22	94.3	5.8283	1.1075
2014	7	14	19	52	18	0.3	1	0.13	94.2	5.8283	0.688
2014	7	14	20	2	18	0.3	1	0.19	90	5.8283	0.99
2014	7	14	20	12	18	0.3	1	0.25	86.3	5.8477	1.2967
2014	7	14	20	22	18	0.3	1	0.2	98.5	5.8477	1.0104
2014	7	14	20	32	18	0.3	1	0.21	65.4	5.8477	0.9936
2014	7	14	20	42	18	0.3	1	0.25	98.5	5.8477	1.2462
2014	7	14	20	52	18	0.3	1	0.12	87	5.867	0.6422
2014	7	14	21	2	18	0.3	1	0.14	96.8	5.867	0.7098
2014	7	14	21	12	18	0.3	1	0.15	90	5.8864	0.7971
2014	7	14	21	22	18	0.3	1	0.22	90	5.8864	1.1363
2014	7	14	21	32	18	0.3	1	0.25	81.5	5.9057	1.2595
2014	7	14	21	42	18	0.3	1	0.2	70.3	5.9057	0.9531
2014	7	14	21	52	18	0.3	1	0.22	90	5.9057	1.1404
2014	7	14	22	2	18	0.3	1	0.21	100.1	5.9057	1.0553
2014	7	14	22	12	18	0.3	1	0.19	111.6	5.9251	0.9053
2014	7	14	22	22	18	0.3	1	0.19	83.1	5.9251	0.9907
2014	7	14	22	32	18	0.3	1	0.19	90	5.9251	0.9907
2014	7	14	22	42	18	0.3	1	0.19	103.8	5.9251	0.9736
2014	7	14	22	52	18	0.3	1	0.23	99.7	5.9251	1.1956
2014	7	14	23	2	18	0.3	1	0.25	86.2	5.9251	1.2811
2014	7	14	23	12	18	0.3	1	0.15	86.3	5.9251	0.8028
2014	7	14	23	22	18	0.3	1	0.28	89.3	5.9251	1.4519
2014	7	14	23	32	18	0.3	1	0.23	69.7	5.9445	1.1142
2014	7	14	23	42	18	0.3	1	0.18	78.3	5.9445	0.9085
2014	7	14	23	52	18	0.3	1	0.17	85.6	5.9445	0.8913
2014	7	15	0	2	18	0.3	1	0.16	90	5.9445	0.8228
2014	7	15	0	12	18	0.3	1	0.25	78	5.9445	1.2856
2014	7	15	0	22	18	0.3	1	0.2	95.6	5.9445	1.0456
2014	7	15	0	32	18	0.3	1	0.23	94.9	5.9445	1.1999
2014	7	15	0	42	18	0.3	1	0.23	73.1	5.9445	1.1313
2014	7	15	0	52	18	0.3	1	0.28	77.8	5.9445	1.4227
2014	7	15	1	2	18	0.3	1	0.15	66.8	5.9445	0.7199
2014	7	15	1	12	18	0.3	1	0.16	90	5.9445	0.8399

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	1	22	18	0.3	1	0.17	103.2	5.9445	0.8742
2014	7	15	1	32	18	0.3	1	0.2	110.2	5.9445	0.977
2014	7	15	1	42	18	0.3	1	0.18	89	5.9445	0.9599
2014	7	15	1	52	18	0.3	1	0.19	97	5.9445	0.977
2014	7	15	2	2	18	0.3	1	0.2	71.6	5.9445	0.977
2014	7	15	2	12	18	0.3	1	0.17	87.8	5.9445	0.9085
2014	7	15	2	22	18	0.3	1	0.24	74.8	5.9445	1.1999
2014	7	15	2	32	18	0.3	1	0.17	87.8	5.9445	0.8742
2014	7	15	2	42	18	0.3	1	0.15	88.8	5.9445	0.8056
2014	7	15	2	52	18	0.3	1	0.24	77.5	5.9445	1.2342
2014	7	15	3	2	18	0.3	1	0.26	86.4	5.9445	1.3542
2014	7	15	3	12	18	0.3	1	0.24	75.8	5.9445	1.217
2014	7	15	3	22	18	0.3	1	0.25	99.1	5.9445	1.2856
2014	7	15	3	32	18	0.3	1	0.25	93.8	5.9638	1.3073
2014	7	15	3	42	18	0.3	1	0.21	72.1	5.9445	1.0628
2014	7	15	3	52	18	0.3	1	0.23	72.1	5.9638	1.1697
2014	7	15	4	2	18	0.3	1	0.24	90	5.9445	1.2513
2014	7	15	4	12	18	0.3	1	0.2	98.5	5.9445	1.0285
2014	7	15	4	22	18	0.3	1	0.19	78.9	5.9445	0.9599
2014	7	15	4	32	18	0.3	1	0.24	82	5.9638	1.2213
2014	7	15	4	42	18	0.3	1	0.14	96.8	5.9445	0.7199
2014	7	15	4	52	18	0.3	1	0.25	84	5.9638	1.3073
2014	7	15	5	2	18	0.3	1	0.16	94.6	5.9638	0.8601
2014	7	15	5	12	18	0.3	1	0.11	91.7	5.9638	0.5676
2014	7	15	5	22	18	0.3	1	0.15	90	5.9638	0.7741
2014	7	15	5	32	18	0.3	1	0.15	90	5.9638	0.8085
2014	7	15	5	42	18	0.3	1	0.25	78.1	5.9638	1.3073
2014	7	15	5	52	18	0.3	1	0.23	85.9	5.9638	1.1869
2014	7	15	6	2	18	0.3	1	0.16	76.6	5.9638	0.7913
2014	7	15	6	12	18	0.3	1	0.24	107.2	5.9638	1.2213
2014	7	15	6	22	18	0.3	1	0.2	108.1	5.9638	0.9977
2014	7	15	6	32	18	0.3	1	0.27	89.3	5.9638	1.3933
2014	7	15	6	42	18	0.3	1	0.21	91.8	5.9638	1.1181
2014	7	15	6	52	18	0.3	1	0.19	76	5.9638	0.9633
2014	7	15	7	2	18	0.3	1	0.2	86.3	5.9638	1.0665
2014	7	15	7	12	18	0.3	1	0.19	113.9	5.9638	0.8945
2014	7	15	7	22	18	0.3	1	0.15	75.7	5.9638	0.7397
2014	7	15	7	32	18	0.3	1	0.17	85.7	5.9638	0.9117
2014	7	15	7	42	18	0.3	1	0.22	85.7	5.9638	1.1525
2014	7	15	7	52	18	0.3	1	0.24	98.7	5.9445	1.2342
2014	7	15	8	2	18	0.3	1	0.27	78.1	5.9445	1.3885
2014	7	15	8	12	18	0.3	1	0.14	91.3	5.9445	0.7542
2014	7	15	8	22	18	0.3	1	0.14	84.7	5.9445	0.7371
2014	7	15	8	32	18	0.3	1	0.27	78.1	5.9638	1.3933
2014	7	15	8	42	18	0.3	1	0.23	95	5.9638	1.1869
2014	7	15	8	52	18	0.3	1	0.17	83.4	5.9445	0.8914

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	9	2	18	0.3	1	0.17	86.6	5.9638	0.8773
2014	7	15	9	12	18	0.3	1	0.2	107	5.9638	1.0149
2014	7	15	9	22	18	0.3	1	0.13	91.5	5.9638	0.6709
2014	7	15	9	32	18	0.3	1	0.17	83.3	5.9638	0.8773
2014	7	15	9	42	18	0.3	1	0.21	100.8	5.9638	1.0837
2014	7	15	9	52	18	0.3	1	0.18	92	5.9638	0.9633
2014	7	15	10	2	18	0.3	1	0.25	76.3	5.9638	1.2729
2014	7	15	10	12	18	0.3	1	0.21	104.5	5.9832	1.0702
2014	7	15	10	22	18	0.3	1	0.21	95.4	5.9832	1.1047
2014	7	15	10	32	18	0.3	1	0.2	90	6.0025	1.0393
2014	7	15	10	42	18	0.3	1	0.24	72.8	6.0025	1.2298
2014	7	15	10	52	18	0.3	1	0.28	93.3	6.0219	1.4948
2014	7	15	11	2	18	0.3	1	0.28	95.4	6.08	1.4927
2014	7	15	11	12	18	0.3	1	0.23	97.3	6.0993	1.2335
2014	7	15	11	22	18	0.3	1	0.22	86.6	6.1187	1.1847
2014	7	15	11	32	18	0.3	1	0.25	79.4	6.138	1.3306
2014	7	15	11	42	18	0.3	1	0.23	74.2	6.1574	1.1927
2014	7	15	11	52	18	0.3	1	0.23	85	6.1767	1.2325
2014	7	15	12	2	18	0.3	1	0.26	88.5	6.1767	1.4111
2014	7	15	12	12	18	0.3	1	0.22	77.2	6.1767	1.1789
2014	7	15	12	22	18	0.3	1	0.32	83.5	6.1961	1.7205
2014	7	15	12	32	18	0.3	1	0.26	92.1	6.1961	1.4338
2014	7	15	12	42	18	0.3	1	0.27	86.5	6.1961	1.4517
2014	7	15	12	52	18	0.3	1	0.25	72.5	6.2154	1.3127
2014	7	15	13	2	18	0.3	1	0.35	65.3	6.2154	1.7622
2014	7	15	13	12	18	0.3	1	0.33	68	6.2154	1.6903
2014	7	15	13	22	18	0.3	1	0.31	91.8	6.2348	1.6779
2014	7	15	13	32	18	0.3	1	0.26	90.7	6.2348	1.4433
2014	7	15	13	42	18	0.3	1	0.27	86.5	6.2542	1.4844
2014	7	15	13	52	18	0.3	1	0.34	81	6.2542	1.8283
2014	7	15	14	2	18	0.3	1	0.31	85.8	6.2542	1.7197
2014	7	15	14	12	18	0.3	1	0.37	71.2	6.2735	1.9252
2014	7	15	14	22	18	0.3	1	0.3	59.5	6.2735	1.4166
2014	7	15	14	32	18	0.3	1	0.33	73.7	6.2735	1.7435
2014	7	15	14	42	18	0.3	1	0.33	71.9	6.2735	1.7254
2014	7	15	14	52	18	0.3	1	0.36	71.4	6.2929	1.8951
2014	7	15	15	2	18	0.3	1	0.29	80.8	6.2929	1.5671
2014	7	15	15	12	18	0.3	1	0.32	66.3	6.2929	1.6217
2014	7	15	15	22	18	0.3	1	0.4	66.8	6.3122	2.0476
2014	7	15	15	32	18	0.3	1	0.33	69.6	6.3122	1.7185
2014	7	15	15	42	18	0.3	1	0.44	67.5	6.3122	2.2487
2014	7	15	15	52	18	0.3	1	0.34	58.2	6.3122	1.5905
2014	7	15	16	2	18	0.3	1	0.32	75.8	6.3122	1.7368
2014	7	15	16	12	18	0.3	1	0.34	70	6.3122	1.7551
2014	7	15	16	22	18	0.3	1	0.38	56	6.3316	1.7425
2014	7	15	16	32	18	0.3	1	0.34	64.9	6.3509	1.7298

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	16	42	18	0.3	1	0.35	52.3	6.3509	1.5458
2014	7	15	16	52	18	0.3	1	0.32	70.8	6.3509	1.693
2014	7	15	17	2	18	0.3	1	0.38	61.7	6.3509	1.877
2014	7	15	17	12	18	0.3	1	0.43	65.4	6.3703	2.1786
2014	7	15	17	22	18	0.3	1	0.37	72.5	6.3703	1.9939
2014	7	15	17	32	18	0.3	1	0.29	71.6	6.3703	1.5508
2014	7	15	17	42	18	0.3	1	0.37	68.9	6.3703	1.957
2014	7	15	17	52	18	0.3	1	0.34	60.9	6.3897	1.667
2014	7	15	18	2	18	0.3	1	0.38	71.6	6.3897	2.056
2014	7	15	18	12	18	0.3	1	0.4	70.2	6.3897	2.1116
2014	7	15	18	22	18	0.3	1	0.31	70.6	6.3897	1.63
2014	7	15	18	32	18	0.3	1	0.3	67.6	6.3897	1.5744
2014	7	15	18	42	18	0.3	1	0.34	79.4	6.409	1.8955
2014	7	15	18	52	18	0.3	1	0.4	68	6.409	2.1185
2014	7	15	19	2	18	0.3	1	0.35	60.8	6.409	1.7282
2014	7	15	19	12	18	0.3	1	0.34	78.1	6.409	1.8583
2014	7	15	19	22	18	0.3	1	0.34	80	6.409	1.8955
2014	7	15	19	32	18	0.3	1	0.38	72.3	6.4284	2.0508
2014	7	15	19	42	18	0.3	1	0.24	77.5	6.4284	1.3423
2014	7	15	19	52	18	0.3	1	0.26	82	6.4284	1.4542
2014	7	15	20	2	18	0.3	1	0.3	75.2	6.4284	1.622
2014	7	15	20	12	18	0.3	1	0.25	82.6	6.3897	1.4263
2014	7	15	20	22	18	0.3	1	0.33	63.2	6.4284	1.6593
2014	7	15	20	32	18	0.3	1	0.28	75.8	6.409	1.5424
2014	7	15	20	42	18	0.3	1	0.35	76.9	6.4284	1.9203
2014	7	15	20	52	18	0.3	1	0.29	75.8	6.409	1.6167
2014	7	15	21	2	18	0.3	1	0.3	70.2	6.409	1.5982
2014	7	15	21	12	18	0.3	1	0.33	62.4	6.409	1.6725
2014	7	15	21	22	18	0.3	1	0.35	68	6.4284	1.8457
2014	7	15	21	32	18	0.3	1	0.26	82.2	6.4284	1.4915
2014	7	15	21	42	18	0.3	1	0.31	69.1	6.4284	1.6593
2014	7	15	21	52	18	0.3	1	0.34	73.3	6.409	1.8584
2014	7	15	22	2	18	0.3	1	0.35	70.7	6.409	1.8584
2014	7	15	22	12	18	0.3	1	0.39	70.2	6.409	2.0628
2014	7	15	22	22	18	0.3	1	0.39	61	6.409	1.9141
2014	7	15	22	32	18	0.3	1	0.32	72.7	6.409	1.7283
2014	7	15	22	42	18	0.3	1	0.4	65.5	6.409	2.0814
2014	7	15	22	52	18	0.3	1	0.38	65	6.409	1.9513
2014	7	15	23	2	18	0.3	1	0.35	59.6	6.409	1.7097
2014	7	15	23	12	18	0.3	1	0.4	56.6	6.4284	1.9204
2014	7	15	23	22	18	0.3	1	0.36	64.8	6.4284	1.8644
2014	7	15	23	32	18	0.3	1	0.34	69.8	6.4284	1.8271
2014	7	15	23	42	18	0.3	1	0.33	57.4	6.4284	1.6034
2014	7	15	23	52	18	0.3	1	0.4	52	6.4284	1.7899
2014	7	16	0	2	18	0.3	1	0.38	69.8	6.4284	2.0322
2014	7	16	0	12	18	0.3	1	0.29	78.3	6.4284	1.6221

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	0	22	18	0.3	1	0.34	78.9	6.4284	1.9017
2014	7	16	0	32	18	0.3	1	0.31	71.6	6.4284	1.678
2014	7	16	0	42	18	0.3	1	0.31	79.5	6.4284	1.7153
2014	7	16	0	52	18	0.3	1	0.33	86	6.4284	1.8831
2014	7	16	1	2	18	0.3	1	0.33	77.2	6.4284	1.8085
2014	7	16	1	12	18	0.3	1	0.31	90	6.4284	1.7526
2014	7	16	1	22	18	0.3	1	0.35	89.5	6.4284	2.0136
2014	7	16	1	32	18	0.3	1	0.35	84	6.4284	1.9577
2014	7	16	1	42	18	0.3	1	0.26	92.1	6.4284	1.4916
2014	7	16	1	52	18	0.3	1	0.24	89.2	6.4477	1.3842
2014	7	16	2	2	18	0.3	1	0.31	86.4	6.4477	1.777
2014	7	16	2	12	18	0.3	1	0.29	97	6.4477	1.6647
2014	7	16	2	22	18	0.3	1	0.31	90	6.4477	1.7957
2014	7	16	2	32	18	0.3	1	0.31	88.2	6.4477	1.7396
2014	7	16	2	42	18	0.3	1	0.31	85.2	6.4477	1.777
2014	7	16	2	52	18	0.3	1	0.31	89.4	6.4477	1.7396
2014	7	16	3	2	18	0.3	1	0.35	86.2	6.4477	1.9827
2014	7	16	3	12	18	0.3	1	0.3	76.3	6.4477	1.6835
2014	7	16	3	22	18	0.3	1	0.3	93.8	6.4477	1.6835
2014	7	16	3	32	18	0.3	1	0.29	93.3	6.4477	1.6461
2014	7	16	3	42	18	0.3	1	0.34	83.8	6.4477	1.9079
2014	7	16	3	52	18	0.3	1	0.31	81.5	6.4477	1.7583
2014	7	16	4	2	18	0.3	1	0.35	96.4	6.4477	2.0015
2014	7	16	4	12	18	0.3	1	0.31	98.5	6.4477	1.7583
2014	7	16	4	22	18	0.3	1	0.31	82.2	6.4477	1.777
2014	7	16	4	32	18	0.3	1	0.33	101.5	6.4477	1.8331
2014	7	16	4	42	18	0.3	1	0.24	91.6	6.4477	1.3468
2014	7	16	4	52	18	0.3	1	0.35	86.2	6.4477	1.9828
2014	7	16	5	2	18	0.3	1	0.3	84.4	6.4477	1.7209
2014	7	16	5	12	18	0.3	1	0.35	81.4	6.4477	1.9828
2014	7	16	5	22	18	0.3	1	0.32	99.5	6.4477	1.7957
2014	7	16	5	32	18	0.3	1	0.34	93.9	6.4477	1.908
2014	7	16	5	42	18	0.3	1	0.35	84	6.4477	1.9641
2014	7	16	5	52	18	0.3	1	0.31	93.1	6.4477	1.7396
2014	7	16	6	2	18	0.3	1	0.36	92.1	6.4477	2.0389
2014	7	16	6	12	18	0.3	1	0.33	87.1	6.4477	1.8706
2014	7	16	6	22	18	0.3	1	0.31	97.2	6.4477	1.777
2014	7	16	6	32	18	0.3	1	0.27	83.1	6.4477	1.5526
2014	7	16	6	42	18	0.3	1	0.32	92.9	6.4477	1.8332
2014	7	16	6	52	18	0.3	1	0.27	96.2	6.4477	1.5526
2014	7	16	7	2	18	0.3	1	0.33	87.1	6.4671	1.8766
2014	7	16	7	12	18	0.3	1	0.26	96.6	6.4477	1.459
2014	7	16	7	22	18	0.3	1	0.36	88.9	6.4671	2.0455
2014	7	16	7	32	18	0.3	1	0.39	103	6.4671	2.1956
2014	7	16	7	42	18	0.3	1	0.27	95.5	6.4671	1.5576
2014	7	16	7	52	18	0.3	1	0.23	90	6.4671	1.3136

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	8	2	18	0.3	1	0.3	91.3	6.5058	1.6998
2014	7	16	8	12	18	0.3	1	0.33	99.2	6.5252	1.8757
2014	7	16	8	22	18	0.3	1	0.34	95.5	6.5058	1.9453
2014	7	16	8	32	18	0.3	1	0.34	90	6.5058	1.9831
2014	7	16	8	42	18	0.3	1	0.37	92	6.5058	2.1153
2014	7	16	8	52	18	0.3	1	0.36	94.7	6.4864	2.0521
2014	7	16	9	2	18	0.3	1	0.34	89.4	6.4864	1.9391
2014	7	16	9	12	18	0.3	1	0.26	95.8	6.4864	1.4873
2014	7	16	9	22	18	0.3	1	0.36	89.5	6.4671	2.0642
2014	7	16	9	32	18	0.3	1	0.28	91.3	6.4671	1.5951
2014	7	16	9	42	18	0.3	1	0.34	93.9	6.4671	1.9141
2014	7	16	9	52	18	0.3	1	0.3	91.9	6.4671	1.7077
2014	7	16	10	2	18	0.3	1	0.28	81.1	6.4671	1.5575
2014	7	16	10	12	18	0.3	1	0.28	94.1	6.4671	1.5763
2014	7	16	10	22	18	0.3	1	0.3	100.8	6.4671	1.6701
2014	7	16	10	32	18	0.3	1	0.29	89.3	6.4671	1.6514
2014	7	16	10	42	18	0.3	1	0.34	97.2	6.4671	1.9328
2014	7	16	10	52	18	0.3	1	0.3	86.8	6.4671	1.6889
2014	7	16	11	2	18	0.3	1	0.32	82.4	6.4671	1.8202
2014	7	16	11	12	18	0.3	1	0.28	81.1	6.4671	1.5575
2014	7	16	11	22	18	0.3	1	0.23	87.5	6.4671	1.2948
2014	7	16	11	32	18	0.3	1	0.32	98.3	6.4671	1.8014
2014	7	16	11	42	18	0.3	1	0.28	87.3	6.4671	1.5763
2014	7	16	11	52	18	0.3	1	0.28	82.7	6.4477	1.6086
2014	7	16	12	2	18	0.3	1	0.34	77.3	6.4477	1.9079
2014	7	16	12	12	18	0.3	1	0.34	86.1	6.4477	1.9266
2014	7	16	12	22	18	0.3	1	0.3	82	6.4477	1.7208
2014	7	16	12	32	18	0.3	1	0.36	84.3	6.4477	2.0575
2014	7	16	12	42	18	0.3	1	0.24	86.9	6.4477	1.3841
2014	7	16	12	52	18	0.3	1	0.33	84.8	6.4477	1.8517
2014	7	16	13	2	18	0.3	1	0.33	90	6.4477	1.8704
2014	7	16	13	12	18	0.3	1	0.38	63.4	6.4477	1.9452
2014	7	16	13	22	18	0.3	1	0.35	79.1	6.4477	1.9452
2014	7	16	13	32	18	0.3	1	0.29	87.4	6.4477	1.6646
2014	7	16	13	42	18	0.3	1	0.26	68.9	6.4477	1.4028
2014	7	16	13	52	18	0.3	1	0.36	77.9	6.4477	2.0013
2014	7	16	14	2	18	0.3	1	0.36	82.7	6.4477	2.0574
2014	7	16	14	12	18	0.3	1	0.29	86.1	6.4477	1.6646
2014	7	16	14	22	18	0.3	1	0.38	90	6.4477	2.1509
2014	7	16	14	32	18	0.3	1	0.3	86.8	6.4477	1.6833
2014	7	16	14	42	18	0.3	1	0.34	70.3	6.4477	1.8329
2014	7	16	14	52	18	0.3	1	0.37	66.8	6.4477	1.9639
2014	7	16	15	2	18	0.3	1	0.36	84.2	6.4284	2.0135
2014	7	16	15	12	18	0.3	1	0.27	69.4	6.4284	1.4355
2014	7	16	15	22	18	0.3	1	0.39	72.2	6.4284	2.088
2014	7	16	15	32	18	0.3	1	0.31	71.8	6.4284	1.6965

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	15	42	18	0.3	1	0.24	70.3	6.4284	1.305
2014	7	16	15	52	18	0.3	1	0.35	75.7	6.4284	1.9016
2014	7	16	16	2	18	0.3	1	0.29	73.4	6.409	1.5609
2014	7	16	16	12	18	0.3	1	0.36	73.2	6.4284	1.9761
2014	7	16	16	22	18	0.3	1	0.37	79.2	6.409	2.0441
2014	7	16	16	32	18	0.3	1	0.32	86.5	6.409	1.8025
2014	7	16	16	42	18	0.3	1	0.35	84.1	6.409	1.9698
2014	7	16	16	52	18	0.3	1	0.37	87.5	6.409	2.1184
2014	7	16	17	2	18	0.3	1	0.31	86.3	6.409	1.7468
2014	7	16	17	12	18	0.3	1	0.3	91.9	6.409	1.691
2014	7	16	17	22	18	0.3	1	0.37	75.6	6.409	2.0255
2014	7	16	17	32	18	0.3	1	0.28	61.3	6.409	1.3937
2014	7	16	17	42	18	0.3	1	0.31	75.8	6.3897	1.6855
2014	7	16	17	52	18	0.3	1	0.3	88.7	6.409	1.6724
2014	7	16	18	2	18	0.3	1	0.32	78.9	6.3897	1.7967
2014	7	16	18	12	18	0.3	1	0.29	56.8	6.3897	1.3892
2014	7	16	18	22	18	0.3	1	0.31	75.2	6.3897	1.6855
2014	7	16	18	32	18	0.3	1	0.35	90	6.3703	1.957
2014	7	16	18	42	18	0.3	1	0.31	79	6.3703	1.717
2014	7	16	18	52	18	0.3	1	0.23	77.6	6.3703	1.2554
2014	7	16	19	2	18	0.3	1	0.31	90.6	6.3703	1.7355
2014	7	16	19	12	18	0.3	1	0.29	83.4	6.3703	1.6062
2014	7	16	19	22	18	0.3	1	0.3	90	6.3703	1.6801
2014	7	16	19	32	18	0.3	1	0.24	76.3	6.3897	1.2966
2014	7	16	19	42	18	0.3	1	0.31	78.9	6.3897	1.7041
2014	7	16	19	52	18	0.3	1	0.3	86.3	6.3897	1.7041
2014	7	16	20	2	18	0.3	1	0.27	79.6	6.3897	1.5189
2014	7	16	20	12	18	0.3	1	0.21	93.5	6.3897	1.204
2014	7	16	20	22	18	0.3	1	0.29	89.4	6.3897	1.6485
2014	7	16	20	32	18	0.3	1	0.31	85.7	6.3897	1.7226
2014	7	16	20	42	18	0.3	1	0.3	97.6	6.3897	1.6671
2014	7	16	20	52	18	0.3	1	0.38	85	6.409	2.1185
2014	7	16	21	2	18	0.3	1	0.34	82.7	6.409	1.8955
2014	7	16	21	12	18	0.3	1	0.35	84.7	6.409	1.9884
2014	7	16	21	22	18	0.3	1	0.34	83.8	6.409	1.8955
2014	7	16	21	32	18	0.3	1	0.38	90	6.409	2.1371
2014	7	16	21	42	18	0.3	1	0.31	83.9	6.409	1.7469
2014	7	16	21	52	18	0.3	1	0.27	93.4	6.409	1.5424
2014	7	16	22	2	18	0.3	1	0.3	93.1	6.409	1.7097
2014	7	16	22	12	18	0.3	1	0.28	86.6	6.409	1.5796
2014	7	16	22	22	18	0.3	1	0.31	72	6.409	1.654
2014	7	16	22	32	18	0.3	1	0.29	95.9	6.409	1.6168
2014	7	16	22	42	18	0.3	1	0.17	84.6	6.409	0.9849
2014	7	16	22	52	18	0.3	1	0.32	98.3	6.4284	1.7898
2014	7	16	23	2	18	0.3	1	0.31	96.7	6.4284	1.7339
2014	7	16	23	12	18	0.3	1	0.28	101.3	6.4284	1.5848

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	23	22	18	0.3	1	0.32	89.4	6.4284	1.8085
2014	7	16	23	32	18	0.3	1	0.35	93.3	6.4284	1.9576
2014	7	16	23	42	18	0.3	1	0.32	88.8	6.4284	1.8458
2014	7	16	23	52	18	0.3	1	0.31	103.3	6.4284	1.7339
2014	7	17	0	2	18	0.3	1	0.28	78.6	6.4284	1.5661
2014	7	17	0	12	18	0.3	1	0.28	96.1	6.4284	1.5661
2014	7	17	0	22	18	0.3	1	0.3	83.1	6.4284	1.6966
2014	7	17	0	32	18	0.3	1	0.29	90	6.4284	1.6221
2014	7	17	0	42	18	0.3	1	0.33	86	6.4284	1.8458
2014	7	17	0	52	18	0.3	1	0.32	75	6.4284	1.7339
2014	7	17	1	2	18	0.3	1	0.3	100.8	6.4284	1.6594
2014	7	17	1	12	18	0.3	1	0.4	90.5	6.4284	2.2746
2014	7	17	1	22	18	0.3	1	0.28	100.8	6.4284	1.5661
2014	7	17	1	32	18	0.3	1	0.37	93.1	6.4284	2.0882
2014	7	17	1	42	18	0.3	1	0.29	81.6	6.4284	1.6407
2014	7	17	1	52	18	0.3	1	0.32	95.3	6.4284	1.8085
2014	7	17	2	2	18	0.3	1	0.32	80.1	6.4284	1.8085
2014	7	17	2	12	18	0.3	1	0.26	82.2	6.4284	1.4916
2014	7	17	2	22	18	0.3	1	0.29	99.1	6.4284	1.6221
2014	7	17	2	32	18	0.3	1	0.3	104	6.4284	1.6407
2014	7	17	2	42	18	0.3	1	0.33	100.4	6.4284	1.8272
2014	7	17	2	52	18	0.3	1	0.35	84.1	6.4284	1.995
2014	7	17	3	2	18	0.3	1	0.19	90	6.4284	1.0814
2014	7	17	3	12	18	0.3	1	0.29	99.9	6.409	1.5983
2014	7	17	3	22	18	0.3	1	0.3	91.9	6.4284	1.6967
2014	7	17	3	32	18	0.3	1	0.31	97.8	6.4284	1.7713
2014	7	17	3	42	18	0.3	1	0.36	91.1	6.4284	2.0323
2014	7	17	3	52	18	0.3	1	0.35	87.3	6.409	1.97
2014	7	17	4	2	18	0.3	1	0.23	92.4	6.409	1.3195
2014	7	17	4	12	18	0.3	1	0.35	82.9	6.409	1.9514
2014	7	17	4	22	18	0.3	1	0.24	98.6	6.409	1.3567
2014	7	17	4	32	18	0.3	1	0.3	96.3	6.409	1.6726
2014	7	17	4	42	18	0.3	1	0.2	106.1	6.4284	1.1001
2014	7	17	4	52	18	0.3	1	0.31	99.9	6.409	1.7098
2014	7	17	5	2	18	0.3	1	0.29	94.6	6.409	1.6169
2014	7	17	5	12	18	0.3	1	0.27	94.2	6.409	1.5054
2014	7	17	5	22	18	0.3	1	0.26	84.1	6.409	1.4496
2014	7	17	5	32	18	0.3	1	0.33	85.4	6.409	1.8585
2014	7	17	5	42	18	0.3	1	0.33	75.4	6.409	1.7842
2014	7	17	5	52	18	0.3	1	0.26	83.6	6.409	1.4868
2014	7	17	6	2	18	0.3	1	0.31	72.5	6.409	1.6541
2014	7	17	6	12	18	0.3	1	0.33	91.7	6.409	1.8585
2014	7	17	6	22	18	0.3	1	0.32	92.9	6.409	1.8213
2014	7	17	6	32	18	0.3	1	0.29	90	6.409	1.6541
2014	7	17	6	42	18	0.3	1	0.31	83.9	6.409	1.747
2014	7	17	6	52	18	0.3	1	0.36	97.9	6.409	2.0072

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	7	2	18	0.3	1	0.36	90	6.409	2.063
2014	7	17	7	12	18	0.3	1	0.32	100	6.409	1.7842
2014	7	17	7	22	18	0.3	1	0.24	90.8	6.409	1.3753
2014	7	17	7	32	18	0.3	1	0.36	88.9	6.409	2.0258
2014	7	17	7	42	18	0.3	1	0.31	87	6.409	1.7656
2014	7	17	7	52	18	0.3	1	0.24	83.8	6.409	1.3753
2014	7	17	8	2	18	0.3	1	0.38	88.5	6.409	2.1745
2014	7	17	8	12	18	0.3	1	0.35	93.8	6.409	1.97
2014	7	17	8	22	18	0.3	1	0.3	87.5	6.409	1.7098
2014	7	17	8	32	18	0.3	1	0.32	88.8	6.409	1.8399
2014	7	17	8	42	18	0.3	1	0.27	85.8	6.409	1.5054
2014	7	17	8	52	18	0.3	1	0.29	83.5	6.409	1.6355
2014	7	17	9	2	18	0.3	1	0.34	89.4	6.409	1.9143
2014	7	17	9	12	18	0.3	1	0.25	76.9	6.409	1.3567
2014	7	17	9	22	18	0.3	1	0.31	90	6.409	1.7656
2014	7	17	9	32	18	0.3	1	0.31	82.2	6.409	1.7656
2014	7	17	9	42	18	0.3	1	0.34	87.2	6.409	1.9328
2014	7	17	9	52	18	0.3	1	0.31	94.9	6.409	1.7284
2014	7	17	10	2	18	0.3	1	0.29	93.3	6.409	1.6355
2014	7	17	10	12	18	0.3	1	0.31	90	6.409	1.7656
2014	7	17	10	22	18	0.3	1	0.32	97.7	6.409	1.7841
2014	7	17	10	32	18	0.3	1	0.29	95.8	6.409	1.654
2014	7	17	10	42	18	0.3	1	0.29	74.2	6.409	1.5797
2014	7	17	10	52	18	0.3	1	0.31	84	6.409	1.7655
2014	7	17	11	2	18	0.3	1	0.31	93.1	6.409	1.7284
2014	7	17	11	12	18	0.3	1	0.28	89.3	6.409	1.5983
2014	7	17	11	22	18	0.3	1	0.39	85.1	6.409	2.1744
2014	7	17	11	32	18	0.3	1	0.27	81.7	6.409	1.5239
2014	7	17	11	42	18	0.3	1	0.23	94.8	6.3897	1.3152
2014	7	17	11	52	18	0.3	1	0.28	98.1	6.3897	1.556
2014	7	17	12	2	18	0.3	1	0.33	64.9	6.3703	1.6987
2014	7	17	12	12	18	0.3	1	0.25	84.7	6.3703	1.3848
2014	7	17	12	22	18	0.3	1	0.34	96	6.3509	1.914
2014	7	17	12	32	18	0.3	1	0.27	74.4	6.3509	1.4539
2014	7	17	12	42	18	0.3	1	0.39	80.9	6.3316	2.1645
2014	7	17	12	52	18	0.3	1	0.27	66.8	6.3122	1.4078
2014	7	17	13	2	18	0.3	1	0.29	93.9	6.2929	1.6036
2014	7	17	13	12	18	0.3	1	0.3	76.6	6.2735	1.5983
2014	7	17	13	22	18	0.3	1	0.28	75.2	6.2542	1.5024
2014	7	17	13	32	18	0.3	1	0.3	83.2	6.2542	1.6654
2014	7	17	13	42	18	0.3	1	0.32	66.3	6.2542	1.611
2014	7	17	13	52	18	0.3	1	0.32	70.8	6.2542	1.6653
2014	7	17	14	2	18	0.3	1	0.34	76.1	6.2348	1.8222
2014	7	17	14	12	18	0.3	1	0.35	83.1	6.2348	1.9304
2014	7	17	14	22	18	0.3	1	0.26	72	6.2348	1.335
2014	7	17	14	32	18	0.3	1	0.32	74	6.2348	1.6959

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	14	42	18	0.3	1	0.28	80.5	6.2348	1.5155
2014	7	17	14	52	18	0.3	1	0.33	75.5	6.2154	1.7441
2014	7	17	15	2	18	0.3	1	0.3	80.4	6.2154	1.6003
2014	7	17	15	12	18	0.3	1	0.32	79.4	6.2154	1.7262
2014	7	17	15	22	18	0.3	1	0.27	67.8	6.2154	1.3665
2014	7	17	15	32	18	0.3	1	0.27	77.3	6.2154	1.4385
2014	7	17	15	42	18	0.3	1	0.33	69.6	6.1961	1.6845
2014	7	17	15	52	18	0.3	1	0.32	75.1	6.1961	1.6845
2014	7	17	16	2	18	0.3	1	0.32	81.6	6.1961	1.7024
2014	7	17	16	12	18	0.3	1	0.28	80.4	6.1767	1.4824
2014	7	17	16	22	18	0.3	1	0.25	78.1	6.1767	1.3574
2014	7	17	16	32	18	0.3	1	0.3	67.1	6.1767	1.4824
2014	7	17	16	42	18	0.3	1	0.34	76.5	6.1767	1.786
2014	7	17	16	52	18	0.3	1	0.32	65.3	6.1767	1.5896
2014	7	17	17	2	18	0.3	1	0.31	63.2	6.1574	1.4774
2014	7	17	17	12	18	0.3	1	0.25	66.8	6.1574	1.246
2014	7	17	17	22	18	0.3	1	0.27	58.8	6.1574	1.2638
2014	7	17	17	32	18	0.3	1	0.19	78.1	6.1574	1.0146
2014	7	17	17	42	18	0.3	1	0.33	67	6.1574	1.6376
2014	7	17	17	52	18	0.3	1	0.31	80.7	6.1574	1.6376
2014	7	17	18	2	18	0.3	1	0.23	87.5	6.138	1.2418
2014	7	17	18	12	18	0.3	1	0.3	80.4	6.138	1.5789
2014	7	17	18	22	18	0.3	1	0.21	63.8	6.0606	0.9975
2014	7	17	18	32	18	0.3	1	0.21	36	6.08	0.6497
2014	7	17	18	42	18	0.3	1	0.13	74.9	6.0606	0.6475
2014	7	17	18	52	18	0.3	1	0.13	61.5	6.0412	0.6104
2014	7	17	19	2	18	0.3	1	0.22	72.9	6.0412	1.1336
2014	7	17	19	12	18	0.3	1	0.24	64.5	6.0412	1.1336
2014	7	17	19	22	18	0.3	1	0.18	77.7	6.0412	0.9592
2014	7	17	19	32	18	0.3	1	0.24	90	6.0219	1.2514
2014	7	17	19	42	18	0.3	1	0.28	78.4	6.0219	1.4426
2014	7	17	19	52	18	0.3	1	0.28	70.1	6.0219	1.3904
2014	7	17	20	2	18	0.3	1	0.23	73.1	6.0412	1.1511
2014	7	17	20	12	18	0.3	1	0.2	90	6.0412	1.0639
2014	7	17	20	22	18	0.3	1	0.18	90	6.0412	0.9767
2014	7	17	20	32	18	0.3	1	0.23	88.4	6.0412	1.2208
2014	7	17	20	42	18	0.3	1	0.3	96.9	6.0606	1.5926
2014	7	17	20	52	18	0.3	1	0.27	80.8	6.08	1.4049
2014	7	17	21	2	18	0.3	1	0.2	83.3	6.0993	1.0573
2014	7	17	21	12	18	0.3	1	0.21	95.4	6.1187	1.1139
2014	7	17	21	22	18	0.3	1	0.23	99.7	6.138	1.2419
2014	7	17	21	32	18	0.3	1	0.24	71.3	6.138	1.2064
2014	7	17	21	42	18	0.3	1	0.25	83.2	6.138	1.3306
2014	7	17	21	52	18	0.3	1	0.28	87.3	6.1574	1.5309
2014	7	17	22	2	18	0.3	1	0.19	85	6.1574	1.0147
2014	7	17	22	12	18	0.3	1	0.17	90	6.1574	0.9257

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	22	22	18	0.3	1	0.25	82.5	6.1574	1.3529
2014	7	17	22	32	18	0.3	1	0.22	103.8	6.1574	1.1571
2014	7	17	22	42	18	0.3	1	0.21	94.5	6.1574	1.1215
2014	7	17	22	52	18	0.3	1	0.21	81	6.1574	1.1215
2014	7	17	23	2	18	0.3	1	0.28	83.4	6.1574	1.531
2014	7	17	23	12	18	0.3	1	0.23	75.4	6.1767	1.2325
2014	7	17	23	22	18	0.3	1	0.22	95.2	6.1767	1.1789
2014	7	17	23	32	18	0.3	1	0.25	94.6	6.1767	1.3397
2014	7	17	23	42	18	0.3	1	0.21	91.8	6.1767	1.161
2014	7	17	23	52	18	0.3	1	0.24	93.9	6.1767	1.3218
2014	7	18	0	2	18	0.3	1	0.32	102.6	6.1767	1.679
2014	7	18	0	12	18	0.3	1	0.23	71.6	6.1767	1.1789
2014	7	18	0	22	18	0.3	1	0.25	93.8	6.1767	1.3575
2014	7	18	0	32	18	0.3	1	0.23	110.7	6.1767	1.1789
2014	7	18	0	42	18	0.3	1	0.32	97.1	6.1767	1.7148
2014	7	18	0	52	18	0.3	1	0.25	99.2	6.1767	1.3218
2014	7	18	1	2	18	0.3	1	0.26	90	6.1767	1.429
2014	7	18	1	12	18	0.3	1	0.15	97.6	6.1767	0.8038
2014	7	18	1	22	18	0.3	1	0.31	104.8	6.1767	1.6255
2014	7	18	1	32	18	0.3	1	0.22	87.4	6.1767	1.1968
2014	7	18	1	42	18	0.3	1	0.24	81.2	6.1767	1.2682
2014	7	18	1	52	18	0.3	1	0.28	104.7	6.1961	1.5055
2014	7	18	2	2	18	0.3	1	0.25	94.5	6.1767	1.3754
2014	7	18	2	12	18	0.3	1	0.26	82.2	6.1961	1.4338
2014	7	18	2	22	18	0.3	1	0.26	86.4	6.1961	1.4338
2014	7	18	2	32	18	0.3	1	0.29	76.9	6.1961	1.5413
2014	7	18	2	42	18	0.3	1	0.24	89.2	6.1961	1.2904
2014	7	18	2	52	18	0.3	1	0.28	90	6.1961	1.5055
2014	7	18	3	2	18	0.3	1	0.28	102.7	6.1961	1.5055
2014	7	18	3	12	18	0.3	1	0.25	81.8	6.1961	1.3621
2014	7	18	3	22	18	0.3	1	0.22	86.6	6.1961	1.2187
2014	7	18	3	32	18	0.3	1	0.3	83.7	6.1961	1.631
2014	7	18	3	42	18	0.3	1	0.23	102.3	6.1961	1.2367
2014	7	18	3	52	18	0.3	1	0.27	86.5	6.1961	1.4517
2014	7	18	4	2	18	0.3	1	0.32	83.5	6.1961	1.7206
2014	7	18	4	12	18	0.3	1	0.18	97.3	6.2154	0.9891
2014	7	18	4	22	18	0.3	1	0.24	82.1	6.2154	1.2948
2014	7	18	4	32	18	0.3	1	0.3	88.1	6.1961	1.631
2014	7	18	4	42	18	0.3	1	0.22	90	6.2154	1.2049
2014	7	18	4	52	18	0.3	1	0.19	72.8	6.2154	0.9891
2014	7	18	5	2	18	0.3	1	0.21	89.1	6.2154	1.1509
2014	7	18	5	12	18	0.3	1	0.25	79.4	6.2154	1.3487
2014	7	18	5	22	18	0.3	1	0.24	97	6.2154	1.3128
2014	7	18	5	32	18	0.3	1	0.26	79.8	6.2154	1.4027
2014	7	18	5	42	18	0.3	1	0.15	91.2	6.2154	0.8452
2014	7	18	5	52	18	0.3	1	0.24	97.7	6.2154	1.3308

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	6	2	18	0.3	1	0.26	73.9	6.2154	1.3667
2014	7	18	6	12	18	0.3	1	0.22	95.2	6.2154	1.1869
2014	7	18	6	22	18	0.3	1	0.24	96.3	6.2154	1.2948
2014	7	18	6	32	18	0.3	1	0.27	94.1	6.2154	1.4926
2014	7	18	6	42	18	0.3	1	0.26	94.3	6.2154	1.4387
2014	7	18	6	52	18	0.3	1	0.17	98.7	6.2154	0.9351
2014	7	18	7	2	18	0.3	1	0.26	85	6.2154	1.4387
2014	7	18	7	12	18	0.3	1	0.23	80	6.2154	1.2229
2014	7	18	7	22	18	0.3	1	0.24	94	6.2154	1.2948
2014	7	18	7	32	18	0.3	1	0.31	93.7	6.2154	1.6904
2014	7	18	7	42	18	0.3	1	0.25	81.8	6.2154	1.3667
2014	7	18	7	52	18	0.3	1	0.29	70.5	6.2154	1.4746
2014	7	18	8	2	18	0.3	1	0.17	69.8	6.2154	0.8812
2014	7	18	8	12	18	0.3	1	0.25	88.5	6.2154	1.3847
2014	7	18	8	22	18	0.3	1	0.27	94.9	6.2154	1.4746
2014	7	18	8	32	18	0.3	1	0.27	83.7	6.2154	1.4746
2014	7	18	8	42	18	0.3	1	0.26	82.9	6.2154	1.4387
2014	7	18	8	52	18	0.3	1	0.31	99.8	6.2154	1.6724
2014	7	18	9	2	18	0.3	1	0.28	101.6	6.2154	1.4926
2014	7	18	9	12	18	0.3	1	0.25	79.4	6.2154	1.3487
2014	7	18	9	22	18	0.3	1	0.22	84.1	6.2154	1.2229
2014	7	18	9	32	18	0.3	1	0.18	96.1	6.2154	1.0071
2014	7	18	9	42	18	0.3	1	0.2	82.5	6.2154	1.097
2014	7	18	9	52	18	0.3	1	0.27	83.1	6.2154	1.4926
2014	7	18	10	2	18	0.3	1	0.21	63.4	6.2154	1.043
2014	7	18	10	12	18	0.3	1	0.24	76.3	6.2154	1.2588
2014	7	18	10	22	18	0.3	1	0.17	92.2	6.2154	0.9171
2014	7	18	10	32	18	0.3	1	0.28	98.9	6.2154	1.4926
2014	7	18	10	42	18	0.3	1	0.23	90	6.2154	1.2768
2014	7	18	10	52	18	0.3	1	0.22	76.4	6.1961	1.1829
2014	7	18	11	2	18	0.3	1	0.29	94.6	6.1961	1.5593
2014	7	18	11	12	18	0.3	1	0.25	78.1	6.2154	1.3667
2014	7	18	11	22	18	0.3	1	0.28	89.3	6.2154	1.5285
2014	7	18	11	32	18	0.3	1	0.23	80.3	6.1961	1.2546
2014	7	18	11	42	18	0.3	1	0.22	71	6.2154	1.1509
2014	7	18	11	52	18	0.3	1	0.27	76.1	6.1961	1.4517
2014	7	18	12	2	18	0.3	1	0.33	78.5	6.1961	1.7564
2014	7	18	12	12	18	0.3	1	0.16	101.5	6.1961	0.8782
2014	7	18	12	22	18	0.3	1	0.23	75.8	6.1961	1.2008
2014	7	18	12	32	18	0.3	1	0.14	51.5	6.1961	0.6094
2014	7	18	12	42	18	0.3	1	0.24	73.1	6.1961	1.2366
2014	7	18	12	52	18	0.3	1	0.25	89.2	6.1961	1.3621
2014	7	18	13	2	18	0.3	1	0.21	64.7	6.1961	1.0215
2014	7	18	13	12	18	0.3	1	0.25	63.8	6.1961	1.2366
2014	7	18	13	22	18	0.3	1	0.23	84.2	6.1961	1.2366
2014	7	18	13	32	18	0.3	1	0.27	65	6.1961	1.3441

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	13	42	18	0.3	1	0.28	81.1	6.1961	1.4875
2014	7	18	13	52	18	0.3	1	0.31	67.2	6.1961	1.5771
2014	7	18	14	2	18	0.3	1	0.3	69.8	6.1961	1.5591
2014	7	18	14	12	18	0.3	1	0.25	87	6.1961	1.362
2014	7	18	14	22	18	0.3	1	0.27	64.4	6.1961	1.3082
2014	7	18	14	32	18	0.3	1	0.33	56.6	6.1961	1.5233
2014	7	18	14	42	18	0.3	1	0.23	72.1	6.1767	1.2145
2014	7	18	14	52	18	0.3	1	0.31	61.5	6.1767	1.4824
2014	7	18	15	2	18	0.3	1	0.32	71.9	6.1767	1.6432
2014	7	18	15	12	18	0.3	1	0.31	76	6.1767	1.6432
2014	7	18	15	22	18	0.3	1	0.26	84.9	6.1767	1.3931
2014	7	18	15	32	18	0.3	1	0.29	69.1	6.1767	1.5003
2014	7	18	15	42	18	0.3	1	0.27	72	6.1767	1.3753
2014	7	18	15	52	18	0.3	1	0.27	81.6	6.1574	1.4418
2014	7	18	16	2	18	0.3	1	0.2	79.6	6.1574	1.068
2014	7	18	16	12	18	0.3	1	0.23	79.2	6.1574	1.2104
2014	7	18	16	22	18	0.3	1	0.3	80.4	6.1574	1.5842
2014	7	18	16	32	18	0.3	1	0.24	70.8	6.1574	1.2282
2014	7	18	16	42	18	0.3	1	0.3	74.7	6.1574	1.5664
2014	7	18	16	52	18	0.3	1	0.28	75.8	6.1574	1.4774
2014	7	18	17	2	18	0.3	1	0.26	77.7	6.138	1.3837
2014	7	18	17	12	18	0.3	1	0.19	71.6	6.138	0.958
2014	7	18	17	22	18	0.3	1	0.26	80.7	6.1187	1.3967
2014	7	18	17	32	18	0.3	1	0.31	76	6.0993	1.621
2014	7	18	17	42	18	0.3	1	0.31	68.1	6.1187	1.5382
2014	7	18	17	52	18	0.3	1	0.26	64.1	6.1187	1.273
2014	7	18	18	2	18	0.3	1	0.3	61.2	6.0993	1.4096
2014	7	18	18	12	18	0.3	1	0.27	66.5	6.0993	1.3391
2014	7	18	18	22	18	0.3	1	0.27	76.5	6.0993	1.392
2014	7	18	18	32	18	0.3	1	0.32	57.1	6.0993	1.4449
2014	7	18	18	42	18	0.3	1	0.31	70.2	6.0993	1.5682
2014	7	18	18	52	18	0.3	1	0.19	73.1	6.0993	0.9867
2014	7	18	19	2	18	0.3	1	0.24	67	6.0993	1.1629
2014	7	18	19	12	18	0.3	1	0.24	75.8	6.0993	1.251
2014	7	18	19	22	18	0.3	1	0.21	86.4	6.0993	1.1277
2014	7	18	19	32	18	0.3	1	0.3	97.6	6.0993	1.5858
2014	7	18	19	42	18	0.3	1	0.32	93.6	6.0993	1.6916
2014	7	18	19	52	18	0.3	1	0.26	92.1	6.0993	1.4096
2014	7	18	20	2	18	0.3	1	0.23	94.8	6.0993	1.2511
2014	7	18	20	12	18	0.3	1	0.25	99.8	6.0993	1.3215
2014	7	18	20	22	18	0.3	1	0.23	90	6.1187	1.2553
2014	7	18	20	32	18	0.3	1	0.28	94.7	6.1187	1.5205
2014	7	18	20	42	18	0.3	1	0.23	93.3	6.1187	1.22
2014	7	18	20	52	18	0.3	1	0.28	81.1	6.1187	1.4675
2014	7	18	21	2	18	0.3	1	0.26	86.3	6.138	1.3838
2014	7	18	21	12	18	0.3	1	0.25	88.5	6.138	1.3661

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	21	22	18	0.3	1	0.3	90	6.138	1.6144
2014	7	18	21	32	18	0.3	1	0.29	82.3	6.138	1.579
2014	7	18	21	42	18	0.3	1	0.26	86.4	6.138	1.4016
2014	7	18	21	52	18	0.3	1	0.21	85.5	6.138	1.1354
2014	7	18	22	2	18	0.3	1	0.19	81.2	6.138	1.029
2014	7	18	22	12	18	0.3	1	0.23	103.1	6.138	1.2242
2014	7	18	22	22	18	0.3	1	0.19	78.1	6.1574	1.0147
2014	7	18	22	32	18	0.3	1	0.32	89.4	6.1574	1.7267
2014	7	18	22	42	18	0.3	1	0.26	90	6.1574	1.4241
2014	7	18	22	52	18	0.3	1	0.31	79.5	6.1574	1.6377
2014	7	18	23	2	18	0.3	1	0.25	79.3	6.1574	1.3173
2014	7	18	23	12	18	0.3	1	0.26	83.6	6.1574	1.4241
2014	7	18	23	22	18	0.3	1	0.22	70.2	6.1574	1.1393
2014	7	18	23	32	18	0.3	1	0.24	95.4	6.1574	1.3173
2014	7	18	23	42	18	0.3	1	0.18	83.7	6.1574	0.9613
2014	7	18	23	52	18	0.3	1	0.25	90	6.1574	1.3351
2014	7	19	0	2	18	0.3	1	0.25	88.5	6.1574	1.3707
2014	7	19	0	12	18	0.3	1	0.21	82.9	6.1574	1.1393
2014	7	19	0	22	18	0.3	1	0.25	73.2	6.1574	1.2995
2014	7	19	0	32	18	0.3	1	0.23	81.6	6.1574	1.2105
2014	7	19	0	42	18	0.3	1	0.22	80.4	6.1767	1.161
2014	7	19	0	52	18	0.3	1	0.22	97.9	6.1767	1.161
2014	7	19	1	2	18	0.3	1	0.19	95.9	6.1767	1.036
2014	7	19	1	12	18	0.3	1	0.15	90	6.1767	0.8038
2014	7	19	1	22	18	0.3	1	0.19	89	6.1767	1.0539
2014	7	19	1	32	18	0.3	1	0.23	102.6	6.1767	1.1968
2014	7	19	1	42	18	0.3	1	0.3	86.2	6.1767	1.6255
2014	7	19	1	52	18	0.3	1	0.2	84.4	6.1767	1.0896
2014	7	19	2	2	18	0.3	1	0.25	82.5	6.1767	1.3575
2014	7	19	2	12	18	0.3	1	0.22	82.1	6.1767	1.1611
2014	7	19	2	22	18	0.3	1	0.15	92.5	6.1767	0.8038
2014	7	19	2	32	18	0.3	1	0.25	79.4	6.1767	1.3397
2014	7	19	2	42	18	0.3	1	0.19	85.2	6.1961	1.0574
2014	7	19	2	52	18	0.3	1	0.25	88.5	6.1767	1.3397
2014	7	19	3	2	18	0.3	1	0.24	86.8	6.1961	1.2904
2014	7	19	3	12	18	0.3	1	0.22	89.2	6.1961	1.2187
2014	7	19	3	22	18	0.3	1	0.24	95.5	6.1961	1.3084
2014	7	19	3	32	18	0.3	1	0.2	93.8	6.1961	1.0754
2014	7	19	3	42	18	0.3	1	0.21	91.8	6.1961	1.165
2014	7	19	3	52	18	0.3	1	0.2	88.1	6.1961	1.0933
2014	7	19	4	2	18	0.3	1	0.17	71.2	6.1961	0.8961
2014	7	19	4	12	18	0.3	1	0.2	84.4	6.1961	1.0933
2014	7	19	4	22	18	0.3	1	0.18	90	6.1961	0.9857
2014	7	19	4	32	18	0.3	1	0.2	78	6.1961	1.0933
2014	7	19	4	42	18	0.3	1	0.2	106.3	6.1961	1.0395
2014	7	19	4	52	18	0.3	1	0.14	86.1	6.1961	0.7886

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	5	2	18	0.3	1	0.24	79.6	6.1961	1.2725
2014	7	19	5	12	18	0.3	1	0.25	75.8	6.1961	1.3442
2014	7	19	5	22	18	0.3	1	0.2	73	6.1961	1.0574
2014	7	19	5	32	18	0.3	1	0.22	70.8	6.1961	1.1291
2014	7	19	5	42	18	0.3	1	0.22	80.4	6.1961	1.165
2014	7	19	5	52	18	0.3	1	0.17	85.7	6.2154	0.9531
2014	7	19	6	2	18	0.3	1	0.24	93.9	6.2154	1.3307
2014	7	19	6	12	18	0.3	1	0.24	86.1	6.2154	1.3307
2014	7	19	6	22	18	0.3	1	0.27	85.2	6.2154	1.4926
2014	7	19	6	32	18	0.3	1	0.31	93	6.2154	1.7084
2014	7	19	6	42	18	0.3	1	0.19	88	6.2154	1.043
2014	7	19	6	52	18	0.3	1	0.33	79.1	6.2154	1.7803
2014	7	19	7	2	18	0.3	1	0.28	88	6.2154	1.5106
2014	7	19	7	12	18	0.3	1	0.29	83.6	6.2154	1.6005
2014	7	19	7	22	18	0.3	1	0.24	90	6.2154	1.2948
2014	7	19	7	32	18	0.3	1	0.23	81.9	6.2348	1.263
2014	7	19	7	42	18	0.3	1	0.32	86.4	6.2348	1.7322
2014	7	19	7	52	18	0.3	1	0.21	72.4	6.2348	1.0826
2014	7	19	8	2	18	0.3	1	0.22	71.6	6.2348	1.1367
2014	7	19	8	12	18	0.3	1	0.22	83.1	6.2348	1.1909
2014	7	19	8	22	18	0.3	1	0.29	65.8	6.2348	1.4435
2014	7	19	8	32	18	0.3	1	0.21	70.2	6.2154	1.097
2014	7	19	8	42	18	0.3	1	0.27	80.9	6.2348	1.4615
2014	7	19	8	52	18	0.3	1	0.24	63.1	6.2348	1.1728
2014	7	19	9	2	18	0.3	1	0.27	75.1	6.2348	1.4254
2014	7	19	9	12	18	0.3	1	0.27	80.3	6.2348	1.4795
2014	7	19	9	22	18	0.3	1	0.3	83.1	6.2348	1.6419
2014	7	19	9	32	18	0.3	1	0.19	84	6.2348	1.0285
2014	7	19	9	42	18	0.3	1	0.28	83.9	6.2348	1.5156
2014	7	19	9	52	18	0.3	1	0.33	89.4	6.2348	1.8224
2014	7	19	10	2	18	0.3	1	0.31	90	6.2348	1.6961
2014	7	19	10	12	18	0.3	1	0.25	71.1	6.2348	1.3171
2014	7	19	10	22	18	0.3	1	0.25	72.3	6.2348	1.2991
2014	7	19	10	32	18	0.3	1	0.26	82.7	6.2348	1.4073
2014	7	19	10	42	18	0.3	1	0.32	74.1	6.2348	1.7141
2014	7	19	10	52	18	0.3	1	0.33	62.7	6.2348	1.6058
2014	7	19	11	2	18	0.3	1	0.24	93.2	6.2154	1.2947
2014	7	19	11	12	18	0.3	1	0.19	90	6.2154	1.025
2014	7	19	11	22	18	0.3	1	0.19	72.2	6.2348	1.0104
2014	7	19	11	32	18	0.3	1	0.2	77.6	6.2154	1.061
2014	7	19	11	42	18	0.3	1	0.29	105.9	6.2154	1.5105
2014	7	19	11	52	18	0.3	1	0.21	93.6	6.2154	1.1329
2014	7	19	12	2	18	0.3	1	0.28	92	6.2154	1.5465
2014	7	19	12	12	18	0.3	1	0.19	90	6.2154	1.043
2014	7	19	12	22	18	0.3	1	0.29	85.5	6.2154	1.6004
2014	7	19	12	32	18	0.3	1	0.32	80.4	6.2154	1.7083

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	12	42	18	0.3	1	0.18	85.8	6.2154	0.989
2014	7	19	12	52	18	0.3	1	0.32	67.3	6.2154	1.6364
2014	7	19	13	2	18	0.3	1	0.26	64.7	6.2154	1.2947
2014	7	19	13	12	18	0.3	1	0.26	87.8	6.2154	1.4026
2014	7	19	13	22	18	0.3	1	0.26	92.1	6.2154	1.4386
2014	7	19	13	32	18	0.3	1	0.27	90	6.2154	1.4745
2014	7	19	13	42	18	0.3	1	0.28	90	6.2154	1.5285
2014	7	19	13	52	18	0.3	1	0.18	76.5	6.2154	0.971
2014	7	19	14	2	18	0.3	1	0.25	98.3	6.1961	1.3441
2014	7	19	14	12	18	0.3	1	0.22	75.3	6.1961	1.1649
2014	7	19	14	22	18	0.3	1	0.27	82.5	6.1961	1.4875
2014	7	19	14	32	18	0.3	1	0.23	80.3	6.1961	1.2545
2014	7	19	14	42	18	0.3	1	0.32	88.2	6.1961	1.7384
2014	7	19	14	52	18	0.3	1	0.27	80.3	6.1961	1.4695
2014	7	19	15	2	18	0.3	1	0.24	85.3	6.1961	1.3083
2014	7	19	15	12	18	0.3	1	0.26	93.7	6.1961	1.3979
2014	7	19	15	22	18	0.3	1	0.35	90	6.1767	1.8933
2014	7	19	15	32	18	0.3	1	0.32	72.5	6.1961	1.6488
2014	7	19	15	42	18	0.3	1	0.31	70.2	6.1767	1.5896
2014	7	19	15	52	18	0.3	1	0.25	90	6.1767	1.3574
2014	7	19	16	2	18	0.3	1	0.3	72.2	6.1767	1.5539
2014	7	19	16	12	18	0.3	1	0.33	70.3	6.1767	1.6968
2014	7	19	16	22	18	0.3	1	0.31	70.8	6.1767	1.5896
2014	7	19	16	32	18	0.3	1	0.23	65.6	6.1767	1.1431
2014	7	19	16	42	18	0.3	1	0.26	67.7	6.1767	1.3039
2014	7	19	16	52	18	0.3	1	0.28	77.1	6.1767	1.4825
2014	7	19	17	2	18	0.3	1	0.28	79.8	6.1767	1.4825
2014	7	19	17	12	18	0.3	1	0.24	84.6	6.1574	1.3173
2014	7	19	17	22	18	0.3	1	0.21	76.2	6.1767	1.0895
2014	7	19	17	32	18	0.3	1	0.26	82.2	6.1767	1.4289
2014	7	19	17	42	18	0.3	1	0.2	90	6.1574	1.1037
2014	7	19	17	52	18	0.3	1	0.17	92.2	6.1574	0.9435
2014	7	19	18	2	18	0.3	1	0.21	90	6.1574	1.1215
2014	7	19	18	12	18	0.3	1	0.23	89.2	6.1574	1.2461
2014	7	19	18	22	18	0.3	1	0.24	79.9	6.1574	1.2995
2014	7	19	18	32	18	0.3	1	0.23	63.1	6.1574	1.1215
2014	7	19	18	42	18	0.3	1	0.28	82.5	6.1574	1.4953
2014	7	19	18	52	18	0.3	1	0.34	84.4	6.1574	1.8157
2014	7	19	19	2	18	0.3	1	0.23	89.2	6.1574	1.2461
2014	7	19	19	12	18	0.3	1	0.21	74.7	6.1574	1.1037
2014	7	19	19	22	18	0.3	1	0.31	82.6	6.1574	1.6555
2014	7	19	19	32	18	0.3	1	0.31	78.9	6.1574	1.6377
2014	7	19	19	42	18	0.3	1	0.27	79.4	6.1574	1.4241
2014	7	19	19	52	18	0.3	1	0.34	87.3	6.1574	1.8692
2014	7	19	20	2	18	0.3	1	0.27	92.8	6.1574	1.4419
2014	7	19	20	12	18	0.3	1	0.28	90	6.1574	1.4953

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	20	22	18	0.3	1	0.21	81.7	6.138	1.1
2014	7	19	20	32	18	0.3	1	0.23	70.5	6.138	1.1532
2014	7	19	20	42	18	0.3	1	0.27	89.3	6.138	1.4726
2014	7	19	20	52	18	0.3	1	0.19	81	6.138	1.0113
2014	7	19	21	2	18	0.3	1	0.18	111	6.138	0.9226
2014	7	19	21	12	18	0.3	1	0.26	94.3	6.138	1.4016
2014	7	19	21	22	18	0.3	1	0.26	92.9	6.138	1.4193
2014	7	19	21	32	18	0.3	1	0.23	82.6	6.138	1.2242
2014	7	19	21	42	18	0.3	1	0.3	93.8	6.138	1.6145
2014	7	19	21	52	18	0.3	1	0.29	90	6.138	1.5435
2014	7	19	22	2	18	0.3	1	0.21	88.2	6.138	1.1177
2014	7	19	22	12	18	0.3	1	0.25	84.8	6.138	1.3661
2014	7	19	22	22	18	0.3	1	0.22	95	6.138	1.2064
2014	7	19	22	32	18	0.3	1	0.28	75	6.138	1.4548
2014	7	19	22	42	18	0.3	1	0.29	105	6.138	1.5258
2014	7	19	22	52	18	0.3	1	0.26	86.4	6.138	1.4016
2014	7	19	23	2	18	0.3	1	0.18	92.1	6.138	0.9758
2014	7	19	23	12	18	0.3	1	0.26	90	6.138	1.4016
2014	7	19	23	22	18	0.3	1	0.25	74.9	6.138	1.3129
2014	7	19	23	32	18	0.3	1	0.2	85.3	6.138	1.0823
2014	7	19	23	42	18	0.3	1	0.2	89.1	6.138	1.0823
2014	7	19	23	52	18	0.3	1	0.21	102.5	6.138	1.1178
2014	7	20	0	2	18	0.3	1	0.26	87.8	6.138	1.4016
2014	7	20	0	12	18	0.3	1	0.23	90.8	6.138	1.2242
2014	7	20	0	22	18	0.3	1	0.28	94.7	6.138	1.5081
2014	7	20	0	32	18	0.3	1	0.23	82.5	6.138	1.2065
2014	7	20	0	42	18	0.3	1	0.12	108.9	6.138	0.621
2014	7	20	0	52	18	0.3	1	0.24	108.4	6.138	1.2242
2014	7	20	1	2	18	0.3	1	0.23	94	6.138	1.2597
2014	7	20	1	12	18	0.3	1	0.28	83.9	6.138	1.4904
2014	7	20	1	22	18	0.3	1	0.26	85.7	6.138	1.4016
2014	7	20	1	32	18	0.3	1	0.16	82.7	6.138	0.8339
2014	7	20	1	42	18	0.3	1	0.24	94.8	6.138	1.2774
2014	7	20	1	52	18	0.3	1	0.27	102.1	6.138	1.4016
2014	7	20	2	2	18	0.3	1	0.22	96	6.138	1.1887
2014	7	20	2	12	18	0.3	1	0.23	90	6.138	1.2597
2014	7	20	2	22	18	0.3	1	0.24	99.5	6.138	1.2775
2014	7	20	2	32	18	0.3	1	0.27	90.7	6.138	1.4726
2014	7	20	2	42	18	0.3	1	0.28	90	6.138	1.5081
2014	7	20	2	52	18	0.3	1	0.17	75.1	6.138	0.8694
2014	7	20	3	2	18	0.3	1	0.19	83.1	6.138	1.0291
2014	7	20	3	12	18	0.3	1	0.1	82.6	6.138	0.55
2014	7	20	3	22	18	0.3	1	0.26	92.9	6.138	1.3839
2014	7	20	3	32	18	0.3	1	0.23	84.3	6.138	1.242
2014	7	20	3	42	18	0.3	1	0.19	90	6.138	1.0113
2014	7	20	3	52	18	0.3	1	0.3	73.7	6.138	1.5791

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	4	2	18	0.3	1	0.24	87.6	6.138	1.2775
2014	7	20	4	12	18	0.3	1	0.21	87.3	6.138	1.1355
2014	7	20	4	22	18	0.3	1	0.17	79.8	6.138	0.8871
2014	7	20	4	32	18	0.3	1	0.24	98.7	6.138	1.2775
2014	7	20	4	42	18	0.3	1	0.26	103.9	6.138	1.3662
2014	7	20	4	52	18	0.3	1	0.27	101	6.138	1.4549
2014	7	20	5	2	18	0.3	1	0.2	90	6.138	1.0823
2014	7	20	5	12	18	0.3	1	0.2	80.7	6.138	1.0823
2014	7	20	5	22	18	0.3	1	0.21	97.1	6.138	1.1355
2014	7	20	5	32	18	0.3	1	0.28	84.6	6.138	1.4904
2014	7	20	5	42	18	0.3	1	0.25	91.5	6.138	1.3307
2014	7	20	5	52	18	0.3	1	0.28	89.3	6.138	1.4904
2014	7	20	6	2	18	0.3	1	0.22	88.3	6.138	1.171
2014	7	20	6	12	18	0.3	1	0.21	93.5	6.138	1.1533
2014	7	20	6	22	18	0.3	1	0.23	89.2	6.138	1.2243
2014	7	20	6	32	18	0.3	1	0.27	86.6	6.138	1.4727
2014	7	20	6	42	18	0.3	1	0.25	105.5	6.138	1.2775
2014	7	20	6	52	18	0.3	1	0.28	92	6.138	1.4904
2014	7	20	7	2	18	0.3	1	0.18	80.5	6.1187	0.9549
2014	7	20	7	12	18	0.3	1	0.24	102.5	6.138	1.2775
2014	7	20	7	22	18	0.3	1	0.27	93.4	6.1187	1.4677
2014	7	20	7	32	18	0.3	1	0.23	90	6.138	1.2597
2014	7	20	7	42	18	0.3	1	0.41	71	6.08	2.0899
2014	7	20	7	52	18	0.3	1	0.26	79.7	6.138	1.3662
2014	7	20	8	2	18	0.3	1	0.3	74.6	6.138	1.5436
2014	7	20	8	12	18	0.3	1	0.3	65.4	6.138	1.4727
2014	7	20	8	22	18	0.3	1	0.27	57.5	6.138	1.2243
2014	7	20	8	32	18	0.3	1	0.3	58.1	6.138	1.3662
2014	7	20	8	42	18	0.3	1	0.32	48.3	6.1574	1.2996
2014	7	20	8	52	18	0.3	1	0.26	63.1	6.1574	1.264
2014	7	20	9	2	18	0.3	1	0.34	55.1	6.138	1.5259
2014	7	20	9	12	18	0.3	1	0.42	43.1	6.1574	1.5489
2014	7	20	9	22	18	0.3	1	0.43	45.3	6.1574	1.6735
2014	7	20	9	32	18	0.3	1	0.37	35.2	6.1574	1.1572
2014	7	20	9	42	18	0.3	1	0.39	35.1	6.1574	1.2284
2014	7	20	9	52	18	0.3	1	0.46	48.8	6.1574	1.8693
2014	7	20	10	2	18	0.3	1	0.45	42.6	6.1574	1.6379
2014	7	20	10	12	18	0.3	1	0.47	42.2	6.138	1.721
2014	7	20	10	22	18	0.3	1	0.5	33.2	6.138	1.4726
2014	7	20	10	32	18	0.3	1	0.43	45.3	6.138	1.6678
2014	7	20	10	42	18	0.3	1	0.47	32.1	6.138	1.3484
2014	7	20	10	52	18	0.3	1	0.45	26.8	6.138	1.1
2014	7	20	11	2	18	0.3	1	0.44	38.3	6.138	1.4726
2014	7	20	11	12	18	0.3	1	0.54	40.6	6.138	1.9162
2014	7	20	11	22	18	0.3	1	0.5	35.4	6.138	1.5613
2014	7	20	11	32	18	0.3	1	0.47	35.4	6.138	1.4726

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	11	42	18	0.3	1	0.51	36.6	6.138	1.65
2014	7	20	11	52	18	0.3	1	0.32	44.2	6.1187	1.2201
2014	7	20	12	2	18	0.3	1	0.4	43	6.1187	1.4676
2014	7	20	12	12	18	0.3	1	0.5	35.9	6.1187	1.5737
2014	7	20	12	22	18	0.3	1	0.38	52.6	6.1187	1.6444
2014	7	20	12	32	18	0.3	1	0.32	49.6	6.1187	1.3085
2014	7	20	12	42	18	0.3	1	0.21	45.6	6.1187	0.7957
2014	7	20	12	52	18	0.3	1	0.28	52.1	6.1187	1.2024
2014	7	20	13	2	18	0.3	1	0.3	49.4	6.0993	1.2335
2014	7	20	13	12	18	0.3	1	0.26	64.1	6.0993	1.2335
2014	7	20	13	22	18	0.3	1	0.23	57	6.08	1.0537
2014	7	20	13	32	18	0.3	1	0.24	43.3	6.0606	0.8751
2014	7	20	13	42	18	0.3	1	0.26	56.3	6.0606	1.1551
2014	7	20	13	52	18	0.3	1	0.18	93.2	6.0412	0.9418
2014	7	20	14	2	18	0.3	1	0.24	51.1	6.0412	0.9941
2014	7	20	14	12	18	0.3	1	0.24	57.6	6.0219	1.095
2014	7	20	14	22	18	0.3	1	0.25	73	6.0219	1.2514
2014	7	20	14	32	18	0.3	1	0.25	64.4	6.0219	1.1993
2014	7	20	14	42	18	0.3	1	0.25	73.2	6.0219	1.2688
2014	7	20	14	52	18	0.3	1	0.25	73.2	6.0219	1.2688
2014	7	20	15	2	18	0.3	1	0.21	60.6	6.0025	0.9526
2014	7	20	15	12	18	0.3	1	0.22	74.3	6.0025	1.1085
2014	7	20	15	22	18	0.3	1	0.27	86.5	6.0025	1.4203
2014	7	20	15	32	18	0.3	1	0.17	83.4	6.0025	0.9007
2014	7	20	15	42	18	0.3	1	0.2	73.9	6.0025	1.0219
2014	7	20	15	52	18	0.3	1	0.24	87.6	6.0025	1.2644
2014	7	20	16	2	18	0.3	1	0.18	61	6.0025	0.8141
2014	7	20	16	12	18	0.3	1	0.3	83.1	6.0025	1.5762
2014	7	20	16	22	18	0.3	1	0.27	72.6	5.9832	1.3808
2014	7	20	16	32	18	0.3	1	0.25	87	5.9832	1.329
2014	7	20	16	42	18	0.3	1	0.18	77.2	5.9832	0.9148
2014	7	20	16	52	18	0.3	1	0.31	67.3	5.9832	1.4844
2014	7	20	17	2	18	0.3	1	0.31	83.3	5.9832	1.6225
2014	7	20	17	12	18	0.3	1	0.14	69	6.0025	0.6755
2014	7	20	17	22	18	0.3	1	0.25	83.3	5.9832	1.329
2014	7	20	17	32	18	0.3	1	0.25	87	5.9832	1.3118
2014	7	20	17	42	18	0.3	1	0.17	98.9	5.9832	0.8803
2014	7	20	17	52	18	0.3	1	0.22	85	5.9832	1.1737
2014	7	20	18	2	18	0.3	1	0.22	78.9	5.9832	1.1392
2014	7	20	18	12	18	0.3	1	0.2	63	5.9832	0.9493
2014	7	20	18	22	18	0.3	1	0.21	59.3	5.9832	0.9321
2014	7	20	18	32	18	0.3	1	0.28	61.1	5.9832	1.3118
2014	7	20	18	42	18	0.3	1	0.2	83.3	5.9832	1.0356
2014	7	20	18	52	18	0.3	1	0.12	83.7	5.9832	0.6214
2014	7	20	19	2	18	0.3	1	0.14	41.3	5.9638	0.4988
2014	7	20	19	12	18	0.3	1	0.15	98.8	5.9832	0.7767

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	19	22	18	0.3	1	0.08	85.2	5.9638	0.4128
2014	7	20	19	32	18	0.3	1	0.11	115.8	5.9638	0.4988
2014	7	20	19	42	18	0.3	1	0.16	77.3	5.9638	0.8428
2014	7	20	19	52	18	0.3	1	0.1	116.6	5.9638	0.4816
2014	7	20	20	2	18	0.3	1	0.16	125	5.9638	0.688
2014	7	20	20	12	18	0.3	1	0.15	97.4	5.9832	0.794
2014	7	20	20	22	18	0.3	1	0.11	95	5.9638	0.5848
2014	7	20	20	32	18	0.3	1	0.13	80.1	5.9638	0.688
2014	7	20	20	42	18	0.3	1	0.23	92.4	5.9638	1.2212
2014	7	20	20	52	18	0.3	1	0.12	83.7	5.9638	0.6192
2014	7	20	21	2	18	0.3	1	0.19	107.2	5.9638	0.946
2014	7	20	21	12	18	0.3	1	0.16	119.2	5.9638	0.7396
2014	7	20	21	22	18	0.3	1	0.14	95.6	5.9638	0.7052
2014	7	20	21	32	18	0.3	1	0.28	105.7	5.9638	1.4105
2014	7	20	21	42	18	0.3	1	0.17	101.1	5.9638	0.8772
2014	7	20	21	52	18	0.3	1	0.19	88	5.9638	0.9804
2014	7	20	22	2	18	0.3	1	0.19	112.9	5.9638	0.8944
2014	7	20	22	12	18	0.3	1	0.29	91.3	5.9638	1.4965
2014	7	20	22	22	18	0.3	1	0.18	104	5.9638	0.8944
2014	7	20	22	32	18	0.3	1	0.18	75.2	5.9638	0.9117
2014	7	20	22	42	18	0.3	1	0.19	73.8	5.9638	0.9461
2014	7	20	22	52	18	0.3	1	0.22	95	5.9638	1.1697
2014	7	20	23	2	18	0.3	1	0.17	83.4	5.9638	0.8945
2014	7	20	23	12	18	0.3	1	0.17	90	5.9832	0.8976
2014	7	20	23	22	18	0.3	1	0.17	85.7	5.9832	0.9148
2014	7	20	23	32	18	0.3	1	0.17	102.2	5.9638	0.8773
2014	7	20	23	42	18	0.3	1	0.18	82.5	5.9832	0.9148
2014	7	20	23	52	18	0.3	1	0.2	98.5	5.9832	1.0357
2014	7	21	0	2	18	0.3	1	0.23	76	5.9832	1.1738
2014	7	21	0	12	18	0.3	1	0.19	94.8	5.9832	1.0184
2014	7	21	0	22	18	0.3	1	0.21	82.6	5.9832	1.0702
2014	7	21	0	32	18	0.3	1	0.25	67.1	5.9832	1.2256
2014	7	21	0	42	18	0.3	1	0.2	94.6	5.9832	1.0702
2014	7	21	0	52	18	0.3	1	0.2	79.8	5.9832	1.053
2014	7	21	1	2	18	0.3	1	0.14	114.2	5.9832	0.6905
2014	7	21	1	12	18	0.3	1	0.21	82.9	6.0025	1.1086
2014	7	21	1	22	18	0.3	1	0.19	107.5	5.9832	0.9321
2014	7	21	1	32	18	0.3	1	0.18	101.7	5.9832	0.9149
2014	7	21	1	42	18	0.3	1	0.24	79.1	5.9832	1.2601
2014	7	21	1	52	18	0.3	1	0.27	78.7	6.0025	1.3857
2014	7	21	2	2	18	0.3	1	0.24	86.1	6.0025	1.2818
2014	7	21	2	12	18	0.3	1	0.21	92.7	5.9832	1.1048
2014	7	21	2	22	18	0.3	1	0.18	94.2	6.0025	0.9527
2014	7	21	2	32	18	0.3	1	0.16	110.3	5.9832	0.794
2014	7	21	2	42	18	0.3	1	0.19	100.1	6.0025	0.97
2014	7	21	2	52	18	0.3	1	0.29	93.9	6.0025	1.5416

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	3	2	18	0.3	1	0.19	75.7	6.0025	0.9527
2014	7	21	3	12	18	0.3	1	0.21	90	6.0025	1.1259
2014	7	21	3	22	18	0.3	1	0.28	94.7	6.0025	1.4724
2014	7	21	3	32	18	0.3	1	0.15	83.7	6.0025	0.7795
2014	7	21	3	42	18	0.3	1	0.14	84.8	6.0025	0.7622
2014	7	21	3	52	18	0.3	1	0.18	99.3	6.0025	0.9527
2014	7	21	4	2	18	0.3	1	0.24	76	6.0025	1.2472
2014	7	21	4	12	18	0.3	1	0.19	85	6.0025	0.9874
2014	7	21	4	22	18	0.3	1	0.17	70.5	6.0219	0.8343
2014	7	21	4	32	18	0.3	1	0.19	105.9	6.0219	0.9734
2014	7	21	4	42	18	0.3	1	0.27	86.6	6.0412	1.4477
2014	7	21	4	52	18	0.3	1	0.21	90	6.0412	1.0989
2014	7	21	5	2	18	0.3	1	0.19	105.7	6.0606	0.9976
2014	7	21	5	12	18	0.3	1	0.22	80.4	6.0606	1.1377
2014	7	21	5	22	18	0.3	1	0.17	96.6	6.0606	0.9101
2014	7	21	5	32	18	0.3	1	0.23	94.1	6.08	1.2118
2014	7	21	5	42	18	0.3	1	0.23	77.4	6.08	1.1767
2014	7	21	5	52	18	0.3	1	0.22	93.4	6.08	1.1943
2014	7	21	6	2	18	0.3	1	0.14	80.8	6.08	0.7552
2014	7	21	6	12	18	0.3	1	0.17	83.2	6.08	0.8781
2014	7	21	6	22	18	0.3	1	0.14	92.6	6.0993	0.7754
2014	7	21	6	32	18	0.3	1	0.25	90	6.0993	1.3217
2014	7	21	6	42	18	0.3	1	0.27	90	6.0993	1.4274
2014	7	21	6	52	18	0.3	1	0.25	81.8	6.08	1.3348
2014	7	21	7	2	18	0.3	1	0.24	69.1	6.08	1.1943
2014	7	21	7	12	18	0.3	1	0.26	101.4	6.0993	1.3922
2014	7	21	7	22	18	0.3	1	0.25	111.5	6.0993	1.2512
2014	7	21	7	32	18	0.3	1	0.15	79.9	6.0993	0.793
2014	7	21	7	42	18	0.3	1	0.16	102	6.0993	0.8283
2014	7	21	7	52	18	0.3	1	0.24	79.8	6.0993	1.2688
2014	7	21	8	2	18	0.3	1	0.29	79.7	6.0993	1.5508
2014	7	21	8	12	18	0.3	1	0.18	75.2	6.1187	0.9372
2014	7	21	8	22	18	0.3	1	0.25	67.8	6.1187	1.2555
2014	7	21	8	32	18	0.3	1	0.29	86.7	6.1187	1.5561
2014	7	21	8	42	18	0.3	1	0.21	65	6.1187	1.0256
2014	7	21	8	52	18	0.3	1	0.16	87.7	6.1187	0.8665
2014	7	21	9	2	18	0.3	1	0.22	80.7	6.1187	1.1847
2014	7	21	9	12	18	0.3	1	0.22	73.7	6.1187	1.1494
2014	7	21	9	22	18	0.3	1	0.22	84.1	6.1187	1.2024
2014	7	21	9	32	18	0.3	1	0.16	78.2	6.1187	0.8488
2014	7	21	9	42	18	0.3	1	0.29	61.7	6.1187	1.3792
2014	7	21	9	52	18	0.3	1	0.24	93.2	6.1187	1.2731
2014	7	21	10	2	18	0.3	1	0.2	80.7	6.1187	1.0786
2014	7	21	10	12	18	0.3	1	0.23	95	6.1187	1.2201
2014	7	21	10	22	18	0.3	1	0.25	67.5	6.1187	1.2378
2014	7	21	10	32	18	0.3	1	0.29	79.5	6.1187	1.5207

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	10	42	18	0.3	1	0.22	83.2	6.1187	1.1847
2014	7	21	10	52	18	0.3	1	0.16	73.1	6.1187	0.8134
2014	7	21	11	2	18	0.3	1	0.2	78.9	6.1187	1.0786
2014	7	21	11	12	18	0.3	1	0.27	81.5	6.1187	1.4146
2014	7	21	11	22	18	0.3	1	0.21	95.4	6.1187	1.114
2014	7	21	11	32	18	0.3	1	0.22	73.2	6.1187	1.114
2014	7	21	11	42	18	0.3	1	0.18	93.2	6.0993	0.9516
2014	7	21	11	52	18	0.3	1	0.16	76.8	6.0993	0.8282
2014	7	21	12	2	18	0.3	1	0.19	84	6.0993	1.0045
2014	7	21	12	12	18	0.3	1	0.2	83.3	6.0993	1.0573
2014	7	21	12	22	18	0.3	1	0.3	79.8	6.0993	1.5683
2014	7	21	12	32	18	0.3	1	0.28	74.1	6.08	1.4225
2014	7	21	12	42	18	0.3	1	0.26	82.2	6.08	1.4049
2014	7	21	12	52	18	0.3	1	0.24	77.1	6.0606	1.2251
2014	7	21	13	2	18	0.3	1	0.26	81.1	6.0606	1.3476
2014	7	21	13	12	18	0.3	1	0.24	83.7	6.0606	1.2776
2014	7	21	13	22	18	0.3	1	0.26	84.9	6.0606	1.3826
2014	7	21	13	32	18	0.3	1	0.15	87.5	6.0606	0.7875
2014	7	21	13	42	18	0.3	1	0.24	83.1	6.0412	1.2906
2014	7	21	13	52	18	0.3	1	0.18	72.2	6.0219	0.9212
2014	7	21	14	2	18	0.3	1	0.2	79.4	6.0219	1.0255
2014	7	21	14	12	18	0.3	1	0.2	95.5	6.0219	1.0776
2014	7	21	14	22	18	0.3	1	0.17	71.6	6.0219	0.8343
2014	7	21	14	32	18	0.3	1	0.23	85.2	6.0219	1.234
2014	7	21	14	42	18	0.3	1	0.27	83.7	6.0025	1.4203
2014	7	21	14	52	18	0.3	1	0.21	70.7	6.0025	1.0392
2014	7	21	15	2	18	0.3	1	0.17	96.5	6.0025	0.918
2014	7	21	15	12	18	0.3	1	0.21	73	6.0025	1.0739
2014	7	21	15	22	18	0.3	1	0.26	71.6	6.0025	1.299
2014	7	21	15	32	18	0.3	1	0.23	85.9	6.0025	1.1951
2014	7	21	15	42	18	0.3	1	0.24	80.4	6.0025	1.2297
2014	7	21	15	52	18	0.3	1	0.22	76.2	6.0025	1.1258
2014	7	21	16	2	18	0.3	1	0.22	75.6	6.0025	1.1431
2014	7	21	16	12	18	0.3	1	0.21	65	6.0025	1.0046
2014	7	21	16	22	18	0.3	1	0.25	73.2	6.0025	1.2644
2014	7	21	16	32	18	0.3	1	0.27	72.9	6.0025	1.351
2014	7	21	16	42	18	0.3	1	0.27	85.2	6.0025	1.4376
2014	7	21	16	52	18	0.3	1	0.25	67.5	6.0025	1.2124
2014	7	21	17	2	18	0.3	1	0.28	70.3	6.0025	1.4029
2014	7	21	17	12	18	0.3	1	0.21	90	6.0025	1.0912
2014	7	21	17	22	18	0.3	1	0.24	87.6	6.0025	1.2644
2014	7	21	17	32	18	0.3	1	0.19	88.1	6.0025	1.0219
2014	7	21	17	42	18	0.3	1	0.19	66.1	5.9832	0.8975
2014	7	21	17	52	18	0.3	1	0.19	73.1	6.0025	0.9699
2014	7	21	18	2	18	0.3	1	0.22	74.7	6.0025	1.1431
2014	7	21	18	12	18	0.3	1	0.25	82.6	6.0025	1.3337

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	18	22	18	0.3	1	0.25	74.7	5.9832	1.26
2014	7	21	18	32	18	0.3	1	0.18	65.7	5.9832	0.8803
2014	7	21	18	42	18	0.3	1	0.21	78.3	6.0025	1.0912
2014	7	21	18	52	18	0.3	1	0.22	87.5	5.9832	1.1737
2014	7	21	19	2	18	0.3	1	0.16	56.6	5.9832	0.7077
2014	7	21	19	12	18	0.3	1	0.14	123	6.0025	0.6409
2014	7	21	19	22	18	0.3	1	0.21	92.7	6.0025	1.0912
2014	7	21	19	32	18	0.3	1	0.18	103.5	6.0025	0.9353
2014	7	21	19	42	18	0.3	1	0.26	85.7	6.0025	1.3856
2014	7	21	19	52	18	0.3	1	0.18	107.1	5.9832	0.8975
2014	7	21	20	2	18	0.3	1	0.2	120.8	5.9832	0.8975
2014	7	21	20	12	18	0.3	1	0.17	63.4	6.0025	0.7967
2014	7	21	20	22	18	0.3	1	0.24	94.7	5.9832	1.26
2014	7	21	20	32	18	0.3	1	0.22	106.3	5.9832	1.1219
2014	7	21	20	42	18	0.3	1	0.18	95.1	5.9832	0.9666
2014	7	21	20	52	18	0.3	1	0.23	83.6	5.9832	1.2255
2014	7	21	21	2	18	0.3	1	0.23	103.1	6.0025	1.1951
2014	7	21	21	12	18	0.3	1	0.26	60.9	6.0025	1.2125
2014	7	21	21	22	18	0.3	1	0.23	85	6.0025	1.1951
2014	7	21	21	32	18	0.3	1	0.21	98.1	6.0025	1.0912
2014	7	21	21	42	18	0.3	1	0.28	97.3	6.0025	1.4896
2014	7	21	21	52	18	0.3	1	0.32	102.6	6.0025	1.6282
2014	7	21	22	2	18	0.3	1	0.27	90	6.0025	1.4203
2014	7	21	22	12	18	0.3	1	0.16	90	6.0025	0.8314
2014	7	21	22	22	18	0.3	1	0.19	90	6.0025	1.0046
2014	7	21	22	32	18	0.3	1	0.28	83.3	6.0219	1.4774
2014	7	21	22	42	18	0.3	1	0.2	93.7	6.0219	1.0776
2014	7	21	22	52	18	0.3	1	0.26	90	6.0219	1.3731
2014	7	21	23	2	18	0.3	1	0.2	97.5	6.0219	1.0603
2014	7	21	23	12	18	0.3	1	0.25	98.3	6.0219	1.3036
2014	7	21	23	22	18	0.3	1	0.28	93.4	6.0219	1.4774
2014	7	21	23	32	18	0.3	1	0.19	84	6.0219	0.9907
2014	7	21	23	42	18	0.3	1	0.19	73.1	6.0219	0.9734
2014	7	21	23	52	18	0.3	1	0.24	89.2	6.0412	1.2732
2014	7	22	0	2	18	0.3	1	0.26	93.6	6.0412	1.3779
2014	7	22	0	12	18	0.3	1	0.16	79.4	6.0412	0.8372
2014	7	22	0	22	18	0.3	1	0.29	95.8	6.0412	1.5523
2014	7	22	0	32	18	0.3	1	0.23	85.9	6.0606	1.2251
2014	7	22	0	42	18	0.3	1	0.23	90	6.0606	1.2076
2014	7	22	0	52	18	0.3	1	0.23	102.3	6.0606	1.2076
2014	7	22	1	2	18	0.3	1	0.28	90	6.0606	1.4701
2014	7	22	1	12	18	0.3	1	0.22	82.1	6.0606	1.1376
2014	7	22	1	22	18	0.3	1	0.24	87.7	6.08	1.2996
2014	7	22	1	32	18	0.3	1	0.21	84.6	6.08	1.124
2014	7	22	1	42	18	0.3	1	0.15	88.8	6.08	0.8254
2014	7	22	1	52	18	0.3	1	0.22	77.8	6.08	1.1415

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	2	2	18	0.3	1	0.25	100	6.08	1.2996
2014	7	22	2	12	18	0.3	1	0.2	92.8	6.08	1.0888
2014	7	22	2	22	18	0.3	1	0.25	82.6	6.08	1.3523
2014	7	22	2	32	18	0.3	1	0.21	95.4	6.0993	1.1278
2014	7	22	2	42	18	0.3	1	0.19	78.9	6.0993	0.9868
2014	7	22	2	52	18	0.3	1	0.23	81.8	6.0993	1.2159
2014	7	22	3	2	18	0.3	1	0.19	104.7	6.0993	1.0045
2014	7	22	3	12	18	0.3	1	0.19	77.2	6.0993	1.0045
2014	7	22	3	22	18	0.3	1	0.26	95.8	6.0993	1.3922
2014	7	22	3	32	18	0.3	1	0.24	108.9	6.0993	1.2336
2014	7	22	3	42	18	0.3	1	0.17	57.5	6.0993	0.7754
2014	7	22	3	52	18	0.3	1	0.18	90	6.0993	0.9692
2014	7	22	4	2	18	0.3	1	0.2	90.9	6.08	1.0713
2014	7	22	4	12	18	0.3	1	0.12	94.6	6.08	0.6498
2014	7	22	4	22	18	0.3	1	0.27	99.1	6.08	1.4225
2014	7	22	4	32	18	0.3	1	0.15	101.1	6.08	0.8079
2014	7	22	4	42	18	0.3	1	0.19	81.2	6.08	1.0186
2014	7	22	4	52	18	0.3	1	0.14	90	6.0606	0.7526
2014	7	22	5	2	18	0.3	1	0.14	81.9	6.0412	0.7326
2014	7	22	5	12	18	0.3	1	0.22	107.4	6.0412	1.1163
2014	7	22	5	22	18	0.3	1	0.21	103.8	6.0219	1.0603
2014	7	22	5	32	18	0.3	1	0.31	86.9	6.0219	1.6165
2014	7	22	5	42	18	0.3	1	0.28	104.4	6.0025	1.4204
2014	7	22	5	52	18	0.3	1	0.14	91.4	6.0025	0.7275
2014	7	22	6	2	18	0.3	1	0.15	134.1	6.0025	0.5716
2014	7	22	6	12	18	0.3	1	0.12	77.8	6.0025	0.6409
2014	7	22	6	22	18	0.3	1	0.2	105.4	5.9832	1.0012
2014	7	22	6	32	18	0.3	1	0.22	98.5	5.9832	1.1566
2014	7	22	6	42	18	0.3	1	0.23	109.5	5.9832	1.122
2014	7	22	6	52	18	0.3	1	0.18	100.5	5.9832	0.9322
2014	7	22	7	2	18	0.3	1	0.18	67.2	5.9832	0.8631
2014	7	22	7	12	18	0.3	1	0.24	63.1	5.9832	1.122
2014	7	22	7	22	18	0.3	1	0.19	106.2	5.9638	0.9461
2014	7	22	7	32	18	0.3	1	0.21	92.7	5.9638	1.1009
2014	7	22	7	42	18	0.3	1	0.26	80.4	5.9638	1.3246
2014	7	22	7	52	18	0.3	1	0.14	90	5.9638	0.7569
2014	7	22	8	2	18	0.3	1	0.21	59.3	5.9638	0.9289
2014	7	22	8	12	18	0.3	1	0.25	88.5	5.9638	1.3246
2014	7	22	8	22	18	0.3	1	0.26	100.2	5.9638	1.3418
2014	7	22	8	32	18	0.3	1	0.21	107.9	5.9638	1.0665
2014	7	22	8	42	18	0.3	1	0.17	63.9	5.9638	0.8085
2014	7	22	8	52	18	0.3	1	0.21	115.3	5.9638	0.9805
2014	7	22	9	2	18	0.3	1	0.15	88.7	5.9638	0.7741
2014	7	22	9	12	18	0.3	1	0.17	90	5.9445	0.8742
2014	7	22	9	22	18	0.3	1	0.25	97.5	5.9445	1.3028
2014	7	22	9	32	18	0.3	1	0.17	92.2	5.9445	0.9085

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	9	42	18	0.3	1	0.15	87.5	5.9445	0.7885
2014	7	22	9	52	18	0.3	1	0.24	79	5.9445	1.2342
2014	7	22	10	2	18	0.3	1	0.19	105.9	5.9445	0.9599
2014	7	22	10	12	18	0.3	1	0.26	94.4	5.9445	1.337
2014	7	22	10	22	18	0.3	1	0.22	68.8	5.9445	1.0628
2014	7	22	10	32	18	0.3	1	0.17	83.2	5.9445	0.8571
2014	7	22	10	42	18	0.3	1	0.15	105.6	5.9445	0.7371
2014	7	22	10	52	18	0.3	1	0.07	151.2	5.9445	0.1886
2014	7	22	11	2	18	0.3	1	0.16	160.8	5.9445	0.2743
2014	7	22	11	12	18	0.3	1	0.21	140.8	5.9251	0.6833
2014	7	22	11	22	18	0.3	1	0.14	112.3	5.9251	0.6662
2014	7	22	11	32	18	0.3	1	0.17	90	5.9251	0.8711
2014	7	22	11	42	18	0.3	1	0.17	80	5.9251	0.8711
2014	7	22	11	52	18	0.3	1	0.22	75.3	5.9057	1.1064
2014	7	22	12	2	18	0.3	1	0.22	76.4	5.9057	1.1234
2014	7	22	12	12	18	0.3	1	0.21	82.9	5.9057	1.0894
2014	7	22	12	22	18	0.3	1	0.22	83.3	5.9057	1.1574
2014	7	22	12	32	18	0.3	1	0.28	79.3	5.9057	1.4468
2014	7	22	12	42	18	0.3	1	0.25	84	5.9057	1.2936
2014	7	22	12	52	18	0.3	1	0.15	63.4	5.8864	0.6784
2014	7	22	13	2	18	0.3	1	0.2	73	5.8864	1.0007
2014	7	22	13	12	18	0.3	1	0.26	73.4	5.8864	1.306
2014	7	22	13	22	18	0.3	1	0.18	74.9	5.867	0.8788
2014	7	22	13	32	18	0.3	1	0.17	72.3	5.867	0.845
2014	7	22	13	42	18	0.3	1	0.22	75.3	5.8477	1.0946
2014	7	22	13	52	18	0.3	1	0.24	70.8	5.8283	1.1579
2014	7	22	14	2	18	0.3	1	0.17	90	5.8283	0.8894
2014	7	22	14	12	18	0.3	1	0.17	75.7	5.809	0.8527
2014	7	22	14	22	18	0.3	1	0.29	68.7	5.809	1.3711
2014	7	22	14	32	18	0.3	1	0.24	60.9	5.809	1.0534
2014	7	22	14	42	18	0.3	1	0.2	78	5.7896	1.0163
2014	7	22	14	52	18	0.3	1	0.26	67.7	5.7896	1.2162
2014	7	22	15	2	18	0.3	1	0.25	64.8	5.7896	1.1329
2014	7	22	15	12	18	0.3	1	0.24	68.8	5.7702	1.1122
2014	7	22	15	22	18	0.3	1	0.18	65.7	5.7702	0.8466
2014	7	22	15	32	18	0.3	1	0.27	72.6	5.7702	1.328
2014	7	22	15	42	18	0.3	1	0.22	77.2	5.7702	1.0956
2014	7	22	15	52	18	0.3	1	0.25	75.1	5.7702	1.245
2014	7	22	16	2	18	0.3	1	0.24	90	5.7702	1.2284
2014	7	22	16	12	18	0.3	1	0.18	86.8	5.7702	0.8964
2014	7	22	16	22	18	0.3	1	0.25	65.8	5.7702	1.1454
2014	7	22	16	32	18	0.3	1	0.21	73	5.7702	1.0292
2014	7	22	16	42	18	0.3	1	0.25	73.7	5.7702	1.1952
2014	7	22	16	52	18	0.3	1	0.19	74.3	5.7702	0.9462
2014	7	22	17	2	18	0.3	1	0.23	74.6	5.7702	1.1454
2014	7	22	17	12	18	0.3	1	0.19	76.2	5.7702	0.9462

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	17	22	18	0.3	1	0.25	62.1	5.7702	1.0956
2014	7	22	17	32	18	0.3	1	0.26	64.1	5.7702	1.162
2014	7	22	17	42	18	0.3	1	0.17	77.6	5.7509	0.827
2014	7	22	17	52	18	0.3	1	0.29	60.8	5.7509	1.2736
2014	7	22	18	2	18	0.3	1	0.2	63	5.7509	0.8766
2014	7	22	18	12	18	0.3	1	0.26	67.3	5.7509	1.224
2014	7	22	18	22	18	0.3	1	0.2	56.3	5.7509	0.8436
2014	7	22	18	32	18	0.3	1	0.19	69.1	5.7509	0.9097
2014	7	22	18	42	18	0.3	1	0.28	62.2	5.7509	1.2571
2014	7	22	18	52	18	0.3	1	0.23	66	5.7509	1.0751
2014	7	22	19	2	18	0.3	1	0.22	64.6	5.7315	1.0053
2014	7	22	19	12	18	0.3	1	0.19	63.4	5.7315	0.857
2014	7	22	19	22	18	0.3	1	0.2	85.3	5.7315	1.0053
2014	7	22	19	32	18	0.3	1	0.17	84.5	5.7315	0.857
2014	7	22	19	42	18	0.3	1	0.2	73	5.7315	0.9724
2014	7	22	19	52	18	0.3	1	0.23	86.7	5.7315	1.1537
2014	7	22	20	2	18	0.3	1	0.19	95.9	5.7315	0.9559
2014	7	22	20	12	18	0.3	1	0.22	85.7	5.7315	1.0877
2014	7	22	20	22	18	0.3	1	0.18	74.5	5.7315	0.89
2014	7	22	20	32	18	0.3	1	0.2	73.7	5.7315	0.9559
2014	7	22	20	42	18	0.3	1	0.16	78.5	5.7315	0.8076
2014	7	22	20	52	18	0.3	1	0.12	77.1	5.7315	0.5768
2014	7	22	21	2	18	0.3	1	0.2	90	5.7315	0.9889
2014	7	22	21	12	18	0.3	1	0.19	87.1	5.7315	0.9724
2014	7	22	21	22	18	0.3	1	0.18	78.3	5.7315	0.8735
2014	7	22	21	32	18	0.3	1	0.14	99.7	5.7315	0.6757
2014	7	22	21	42	18	0.3	1	0.11	80	5.7315	0.5604
2014	7	22	21	52	18	0.3	1	0.19	107.2	5.7315	0.9065
2014	7	22	22	2	18	0.3	1	0.15	90	5.7315	0.7417
2014	7	22	22	12	18	0.3	1	0.2	90	5.7315	0.9889
2014	7	22	22	22	18	0.3	1	0.18	80.4	5.7315	0.8735
2014	7	22	22	32	18	0.3	1	0.1	72.2	5.7315	0.4615
2014	7	22	22	42	18	0.3	1	0.15	70.3	5.7315	0.6922
2014	7	22	22	52	18	0.3	1	0.18	95.3	5.7315	0.89
2014	7	22	23	2	18	0.3	1	0.15	83.8	5.7315	0.7581
2014	7	22	23	12	18	0.3	1	0.16	90	5.7315	0.8241
2014	7	22	23	22	18	0.3	1	0.21	70.2	5.7315	1.0054
2014	7	22	23	32	18	0.3	1	0.19	106.2	5.7509	0.9098
2014	7	22	23	42	18	0.3	1	0.21	99.2	5.7509	1.0256
2014	7	22	23	52	18	0.3	1	0.09	102.5	5.7509	0.4466
2014	7	23	0	2	18	0.3	1	0.16	77.1	5.7509	0.794
2014	7	23	0	12	18	0.3	1	0.24	72.3	5.7509	1.1414
2014	7	23	0	22	18	0.3	1	0.15	66.8	5.7509	0.6948
2014	7	23	0	32	18	0.3	1	0.19	81.9	5.7509	0.9263
2014	7	23	0	42	18	0.3	1	0.16	78.2	5.7509	0.794
2014	7	23	0	52	18	0.3	1	0.13	58.3	5.7509	0.5624

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	1	2	18	0.3	1	0.14	80.3	5.7509	0.6782
2014	7	23	1	12	18	0.3	1	0.18	84.7	5.7509	0.8933
2014	7	23	1	22	18	0.3	1	0.13	87.1	5.7509	0.6451
2014	7	23	1	32	18	0.3	1	0.14	100.8	5.7702	0.6973
2014	7	23	1	42	18	0.3	1	0.14	98.1	5.7702	0.6973
2014	7	23	1	52	18	0.3	1	0.18	111.8	5.7702	0.8301
2014	7	23	2	2	18	0.3	1	0.23	99.1	5.7702	1.1455
2014	7	23	2	12	18	0.3	1	0.17	113.6	5.7702	0.7969
2014	7	23	2	22	18	0.3	1	0.12	94.9	5.7896	0.5832
2014	7	23	2	32	18	0.3	1	0.12	94.6	5.7896	0.6165
2014	7	23	2	42	18	0.3	1	0.21	94.5	5.809	1.0702
2014	7	23	2	52	18	0.3	1	0.12	112.4	5.8283	0.5706
2014	7	23	3	2	18	0.3	1	0.16	102.7	5.8283	0.8223
2014	7	23	3	12	18	0.3	1	0.14	114.1	5.8477	0.64
2014	7	23	3	22	18	0.3	1	0.16	77.3	5.8477	0.8253
2014	7	23	3	32	18	0.3	1	0.19	85.1	5.8477	0.9768
2014	7	23	3	42	18	0.3	1	0.15	108.8	5.867	0.7437
2014	7	23	3	52	18	0.3	1	0.14	92.7	5.867	0.7268
2014	7	23	4	2	18	0.3	1	0.18	118	5.867	0.8282
2014	7	23	4	12	18	0.3	1	0.18	97.3	5.867	0.9296
2014	7	23	4	22	18	0.3	1	0.14	90	5.867	0.7268
2014	7	23	4	32	18	0.3	1	0.14	103.1	5.867	0.7268
2014	7	23	4	42	18	0.3	1	0.16	119.2	5.867	0.7268
2014	7	23	4	52	18	0.3	1	0.21	91.8	5.867	1.0648
2014	7	23	5	2	18	0.3	1	0.23	82.5	5.867	1.1494
2014	7	23	5	12	18	0.3	1	0.2	83.5	5.867	1.031
2014	7	23	5	22	18	0.3	1	0.29	87.4	5.8864	1.4757
2014	7	23	5	32	18	0.3	1	0.16	80.7	5.8864	0.8312
2014	7	23	5	42	18	0.3	1	0.09	81.6	5.8864	0.458
2014	7	23	5	52	18	0.3	1	0.21	116.2	5.8864	0.9669
2014	7	23	6	2	18	0.3	1	0.19	85.1	5.8864	0.9838
2014	7	23	6	12	18	0.3	1	0.2	84.5	5.8864	1.0517
2014	7	23	6	22	18	0.3	1	0.15	90	5.8864	0.7633
2014	7	23	6	32	18	0.3	1	0.15	90	5.8864	0.7803
2014	7	23	6	42	18	0.3	1	0.16	76.8	5.8864	0.7972
2014	7	23	6	52	18	0.3	1	0.16	79.4	5.8864	0.8142
2014	7	23	7	2	18	0.3	1	0.14	88.6	5.8864	0.7124
2014	7	23	7	12	18	0.3	1	0.09	57.5	5.8864	0.3732
2014	7	23	7	22	18	0.3	1	0.2	97.7	5.8864	1.0008
2014	7	23	7	32	18	0.3	1	0.16	72.6	5.8864	0.8142
2014	7	23	7	42	18	0.3	1	0.13	109.4	5.8864	0.6276
2014	7	23	7	52	18	0.3	1	0.17	96.8	5.8864	0.8481
2014	7	23	8	2	18	0.3	1	0.18	77.5	5.8864	0.916
2014	7	23	8	12	18	0.3	1	0.17	90	5.8864	0.8651
2014	7	23	8	22	18	0.3	1	0.17	76.2	5.8864	0.8312
2014	7	23	8	32	18	0.3	1	0.18	106.5	5.8864	0.916

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	8	42	18	0.3	1	0.07	87.1	5.8864	0.3392
2014	7	23	8	52	18	0.3	1	0.16	80.3	5.8864	0.7972
2014	7	23	9	2	18	0.3	1	0.14	92.7	5.8864	0.7294
2014	7	23	9	12	18	0.3	1	0.06	78.1	5.8864	0.3223
2014	7	23	9	22	18	0.3	1	0.1	105.9	5.8864	0.4749
2014	7	23	9	32	18	0.3	1	0.11	122.7	5.8864	0.4749
2014	7	23	9	42	18	0.3	1	0.21	85.5	5.8864	1.0856
2014	7	23	9	52	18	0.3	1	0.14	99.2	5.8864	0.7294
2014	7	23	10	2	18	0.3	1	0.11	40.2	5.8477	0.3705
2014	7	23	10	12	18	0.3	1	0.21	106.7	5.9057	1.0213
2014	7	23	10	22	18	0.3	1	0.19	80.9	5.9251	0.9566
2014	7	23	10	32	18	0.3	1	0.2	95.5	5.9251	1.0591
2014	7	23	10	42	18	0.3	1	0.22	77.8	5.9251	1.1103
2014	7	23	10	52	18	0.3	1	0.19	89	5.9251	1.0078
2014	7	23	11	2	18	0.3	1	0.24	94.7	5.9251	1.247
2014	7	23	11	12	18	0.3	1	0.17	111.6	5.9445	0.8228
2014	7	23	11	22	18	0.3	1	0.17	84.4	5.9445	0.8742
2014	7	23	11	32	18	0.3	1	0.2	73	5.9445	1.0114
2014	7	23	11	42	18	0.3	1	0.25	77.6	5.9638	1.2557
2014	7	23	11	52	18	0.3	1	0.23	75	5.9638	1.1525
2014	7	23	12	2	18	0.3	1	0.21	97.1	5.9832	1.1048
2014	7	23	12	12	18	0.3	1	0.22	58	6.0025	0.97
2014	7	23	12	22	18	0.3	1	0.29	83.6	6.0025	1.5416
2014	7	23	12	32	18	0.3	1	0.28	79.1	6.0412	1.4477
2014	7	23	12	42	18	0.3	1	0.26	69.7	6.0606	1.2776
2014	7	23	12	52	18	0.3	1	0.27	76.6	6.08	1.4049
2014	7	23	13	2	18	0.3	1	0.28	83.4	6.08	1.5103
2014	7	23	13	12	18	0.3	1	0.25	60.7	6.1187	1.167
2014	7	23	13	22	18	0.3	1	0.26	74.7	6.0993	1.3569
2014	7	23	13	32	18	0.3	1	0.32	84.2	6.1187	1.7328
2014	7	23	13	42	18	0.3	1	0.24	70.6	6.1187	1.2023
2014	7	23	13	52	18	0.3	1	0.28	66.4	6.138	1.3838
2014	7	23	14	2	18	0.3	1	0.31	67.2	6.138	1.5612
2014	7	23	14	12	18	0.3	1	0.36	65.3	6.1574	1.7801
2014	7	23	14	22	18	0.3	1	0.29	55.1	6.1574	1.2995
2014	7	23	14	32	18	0.3	1	0.27	60.3	6.1574	1.2817
2014	7	23	14	42	18	0.3	1	0.28	69.8	6.1574	1.4063
2014	7	23	14	52	18	0.3	1	0.29	66	6.1574	1.4419
2014	7	23	15	2	18	0.3	1	0.23	62	6.1574	1.1037
2014	7	23	15	12	18	0.3	1	0.3	74.9	6.1767	1.5896
2014	7	23	15	22	18	0.3	1	0.35	71.1	6.1767	1.8218
2014	7	23	15	32	18	0.3	1	0.31	61.8	6.1767	1.4646
2014	7	23	15	42	18	0.3	1	0.31	68.1	6.1767	1.5539
2014	7	23	15	52	18	0.3	1	0.38	67.9	6.1767	1.8933
2014	7	23	16	2	18	0.3	1	0.2	63	6.1767	0.9823
2014	7	23	16	12	18	0.3	1	0.34	71	6.1961	1.7742

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	16	22	18	0.3	1	0.28	81.1	6.1767	1.4824
2014	7	23	16	32	18	0.3	1	0.26	75.4	6.1961	1.3799
2014	7	23	16	42	18	0.3	1	0.25	67.5	6.1767	1.2503
2014	7	23	16	52	18	0.3	1	0.25	64.4	6.1767	1.2324
2014	7	23	17	2	18	0.3	1	0.38	57.8	6.1767	1.7325
2014	7	23	17	12	18	0.3	1	0.28	69.8	6.1767	1.411
2014	7	23	17	22	18	0.3	1	0.4	72	6.1961	2.0967
2014	7	23	17	32	18	0.3	1	0.28	58.9	6.1961	1.3082
2014	7	23	17	42	18	0.3	1	0.32	76.5	6.1961	1.7204
2014	7	23	17	52	18	0.3	1	0.28	50.7	6.1961	1.1828
2014	7	23	18	2	18	0.3	1	0.39	62.2	6.1961	1.8996
2014	7	23	18	12	18	0.3	1	0.33	68.8	6.1961	1.6666
2014	7	23	18	22	18	0.3	1	0.31	67.3	6.1961	1.5412
2014	7	23	18	32	18	0.3	1	0.28	80.4	6.1961	1.4874
2014	7	23	18	42	18	0.3	1	0.26	68.6	6.1961	1.3261
2014	7	23	18	52	18	0.3	1	0.24	69.4	6.1961	1.2365
2014	7	23	19	2	18	0.3	1	0.27	70.3	6.1961	1.3978
2014	7	23	19	12	18	0.3	1	0.34	74.7	6.2154	1.7801
2014	7	23	19	22	18	0.3	1	0.27	49.9	6.2154	1.1328
2014	7	23	19	32	18	0.3	1	0.29	73.6	6.2154	1.5284
2014	7	23	19	42	18	0.3	1	0.3	83.1	6.2154	1.6363
2014	7	23	19	52	18	0.3	1	0.23	87.6	6.2154	1.2767
2014	7	23	20	2	18	0.3	1	0.28	81.9	6.2154	1.5104
2014	7	23	20	12	18	0.3	1	0.29	93.9	6.2154	1.6003
2014	7	23	20	22	18	0.3	1	0.27	95.5	6.2154	1.4925
2014	7	23	20	32	18	0.3	1	0.35	94.3	6.2154	1.906
2014	7	23	20	42	18	0.3	1	0.27	86.6	6.2154	1.4925
2014	7	23	20	52	18	0.3	1	0.33	87.1	6.2154	1.7981
2014	7	23	21	2	18	0.3	1	0.3	98.2	6.2154	1.6183
2014	7	23	21	12	18	0.3	1	0.3	97.5	6.2348	1.6418
2014	7	23	21	22	18	0.3	1	0.25	103.9	6.2154	1.3127
2014	7	23	21	32	18	0.3	1	0.25	95.3	6.2348	1.3712
2014	7	23	21	42	18	0.3	1	0.29	93.9	6.2348	1.5877
2014	7	23	21	52	18	0.3	1	0.2	95.7	6.2348	1.0825
2014	7	23	22	2	18	0.3	1	0.22	79.5	6.2348	1.1727
2014	7	23	22	12	18	0.3	1	0.28	70.1	6.2348	1.4434
2014	7	23	22	22	18	0.3	1	0.29	88.7	6.2348	1.5697
2014	7	23	22	32	18	0.3	1	0.23	90	6.2348	1.2629
2014	7	23	22	42	18	0.3	1	0.27	81.7	6.2348	1.4794
2014	7	23	22	52	18	0.3	1	0.24	84.4	6.2348	1.299
2014	7	23	23	2	18	0.3	1	0.3	89.4	6.2348	1.6238
2014	7	23	23	12	18	0.3	1	0.29	103.2	6.2348	1.5336
2014	7	23	23	22	18	0.3	1	0.29	95.9	6.2348	1.5697
2014	7	23	23	32	18	0.3	1	0.3	77.2	6.2348	1.5877
2014	7	23	23	42	18	0.3	1	0.27	86.5	6.2348	1.4614
2014	7	23	23	52	18	0.3	1	0.28	106.3	6.2348	1.4795

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	0	2	18	0.3	1	0.25	81.5	6.2542	1.3396
2014	7	24	0	12	18	0.3	1	0.27	87.9	6.2542	1.4663
2014	7	24	0	22	18	0.3	1	0.24	86.1	6.2542	1.3396
2014	7	24	0	32	18	0.3	1	0.32	91.2	6.2542	1.756
2014	7	24	0	42	18	0.3	1	0.28	92.7	6.2542	1.5206
2014	7	24	0	52	18	0.3	1	0.24	93.9	6.2542	1.3215
2014	7	24	1	2	18	0.3	1	0.26	92.2	6.2542	1.412
2014	7	24	1	12	18	0.3	1	0.3	85	6.2542	1.6474
2014	7	24	1	22	18	0.3	1	0.31	104.2	6.2735	1.6528
2014	7	24	1	32	18	0.3	1	0.24	79.6	6.2735	1.2896
2014	7	24	1	42	18	0.3	1	0.27	93.4	6.2735	1.5075
2014	7	24	1	52	18	0.3	1	0.26	95	6.2735	1.453
2014	7	24	2	2	18	0.3	1	0.28	89.3	6.2929	1.5672
2014	7	24	2	12	18	0.3	1	0.25	90.8	6.2929	1.385
2014	7	24	2	22	18	0.3	1	0.34	100	6.3122	1.8649
2014	7	24	2	32	18	0.3	1	0.27	86.5	6.3122	1.4993
2014	7	24	2	42	18	0.3	1	0.26	97.8	6.3122	1.4627
2014	7	24	2	52	18	0.3	1	0.29	86.7	6.3122	1.5907
2014	7	24	3	2	18	0.3	1	0.32	99	6.3122	1.7369
2014	7	24	3	12	18	0.3	1	0.26	100.3	6.3122	1.4078
2014	7	24	3	22	18	0.3	1	0.3	86.2	6.3122	1.6638
2014	7	24	3	32	18	0.3	1	0.3	90.6	6.3122	1.6638
2014	7	24	3	42	18	0.3	1	0.3	85	6.3122	1.6638
2014	7	24	3	52	18	0.3	1	0.25	90	6.3316	1.3758
2014	7	24	4	2	18	0.3	1	0.22	98.6	6.3316	1.2107
2014	7	24	4	12	18	0.3	1	0.24	82.1	6.3316	1.3208
2014	7	24	4	22	18	0.3	1	0.2	96.5	6.3316	1.119
2014	7	24	4	32	18	0.3	1	0.27	91.4	6.3316	1.5042
2014	7	24	4	42	18	0.3	1	0.22	89.1	6.3316	1.2291
2014	7	24	4	52	18	0.3	1	0.23	88.4	6.3316	1.2841
2014	7	24	5	2	18	0.3	1	0.26	98.7	6.3316	1.4309
2014	7	24	5	12	18	0.3	1	0.27	91.4	6.3316	1.5226
2014	7	24	5	22	18	0.3	1	0.28	103.5	6.3316	1.5226
2014	7	24	5	32	18	0.3	1	0.27	98.5	6.3316	1.4676
2014	7	24	5	42	18	0.3	1	0.25	84.8	6.3316	1.4125
2014	7	24	5	52	18	0.3	1	0.23	83.6	6.3316	1.3025
2014	7	24	6	2	18	0.3	1	0.24	100.2	6.3316	1.3208
2014	7	24	6	12	18	0.3	1	0.27	97.6	6.3316	1.5043
2014	7	24	6	22	18	0.3	1	0.29	93.3	6.3316	1.6143
2014	7	24	6	32	18	0.3	1	0.27	94.2	6.3316	1.5043
2014	7	24	6	42	18	0.3	1	0.21	93.5	6.3316	1.1924
2014	7	24	6	52	18	0.3	1	0.2	78.9	6.3316	1.119
2014	7	24	7	2	18	0.3	1	0.21	78.2	6.3316	1.1374
2014	7	24	7	12	18	0.3	1	0.28	96.8	6.3316	1.541
2014	7	24	7	22	18	0.3	1	0.27	82.4	6.3316	1.5043
2014	7	24	7	32	18	0.3	1	0.41	102.8	6.3316	2.2564

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	7	42	18	0.3	1	0.32	93.5	6.3316	1.7978
2014	7	24	7	52	18	0.3	1	0.28	108.4	6.3509	1.4908
2014	7	24	8	2	18	0.3	1	0.31	91.2	6.3509	1.7117
2014	7	24	8	12	18	0.3	1	0.25	81.8	6.3509	1.3988
2014	7	24	8	22	18	0.3	1	0.28	79.3	6.3509	1.5644
2014	7	24	8	32	18	0.3	1	0.22	104.7	6.3509	1.1963
2014	7	24	8	42	18	0.3	1	0.27	89.3	6.3509	1.5092
2014	7	24	8	52	18	0.3	1	0.31	94.9	6.3509	1.7117
2014	7	24	9	2	18	0.3	1	0.27	92.1	6.3509	1.4908
2014	7	24	9	12	18	0.3	1	0.28	88	6.3509	1.546
2014	7	24	9	22	18	0.3	1	0.26	95.8	6.3509	1.454
2014	7	24	9	32	18	0.3	1	0.29	86.7	6.3316	1.596
2014	7	24	9	42	18	0.3	1	0.25	78	6.3509	1.3804
2014	7	24	9	52	18	0.3	1	0.29	84.1	6.3509	1.6012
2014	7	24	10	2	18	0.3	1	0.28	97.9	6.3316	1.5776
2014	7	24	10	12	18	0.3	1	0.32	92.4	6.3316	1.7794
2014	7	24	10	22	18	0.3	1	0.3	85	6.3509	1.6748
2014	7	24	10	32	18	0.3	1	0.28	83.3	6.3509	1.5644
2014	7	24	10	42	18	0.3	1	0.26	95.1	6.3509	1.4356
2014	7	24	10	52	18	0.3	1	0.27	102.1	6.3316	1.4492
2014	7	24	11	2	18	0.3	1	0.29	83.5	6.3316	1.6143
2014	7	24	11	12	18	0.3	1	0.35	88.4	6.3316	1.9812
2014	7	24	11	22	18	0.3	1	0.26	81.3	6.3316	1.4308
2014	7	24	11	32	18	0.3	1	0.28	85.9	6.3316	1.5409
2014	7	24	11	42	18	0.3	1	0.37	68.9	6.3316	1.9445
2014	7	24	11	52	18	0.3	1	0.31	88.2	6.3316	1.7427
2014	7	24	12	2	18	0.3	1	0.29	71.4	6.3122	1.5176
2014	7	24	12	12	18	0.3	1	0.26	87.8	6.3122	1.4261
2014	7	24	12	22	18	0.3	1	0.32	82.9	6.3316	1.7794
2014	7	24	12	32	18	0.3	1	0.28	77.3	6.3316	1.5409
2014	7	24	12	42	18	0.3	1	0.28	87.3	6.3122	1.5541
2014	7	24	12	52	18	0.3	1	0.25	90	6.3122	1.4078
2014	7	24	13	2	18	0.3	1	0.32	85.9	6.3122	1.7735
2014	7	24	13	12	18	0.3	1	0.27	69	6.2929	1.4214
2014	7	24	13	22	18	0.3	1	0.31	90	6.2735	1.7436
2014	7	24	13	32	18	0.3	1	0.31	67	6.2542	1.5749
2014	7	24	13	42	18	0.3	1	0.34	85	6.2542	1.8645
2014	7	24	13	52	18	0.3	1	0.32	78.1	6.2542	1.7197
2014	7	24	14	2	18	0.3	1	0.3	71.8	6.2542	1.593
2014	7	24	14	12	18	0.3	1	0.32	78.3	6.2348	1.7501
2014	7	24	14	22	18	0.3	1	0.32	74.5	6.2348	1.6959
2014	7	24	14	32	18	0.3	1	0.3	86.8	6.2348	1.6238
2014	7	24	14	42	18	0.3	1	0.31	83.3	6.2348	1.6959
2014	7	24	14	52	18	0.3	1	0.36	73.6	6.2348	1.8944
2014	7	24	15	2	18	0.3	1	0.3	74.7	6.2154	1.5824
2014	7	24	15	12	18	0.3	1	0.3	76.7	6.2154	1.6003

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	15	22	18	0.3	1	0.41	77.2	6.2154	2.2117
2014	7	24	15	32	18	0.3	1	0.28	67.7	6.2154	1.4025
2014	7	24	15	42	18	0.3	1	0.36	65.3	6.2154	1.7981
2014	7	24	15	52	18	0.3	1	0.33	68.7	6.2154	1.7082
2014	7	24	16	2	18	0.3	1	0.34	66.4	6.1961	1.6846
2014	7	24	16	12	18	0.3	1	0.3	53.5	6.1961	1.3082
2014	7	24	16	22	18	0.3	1	0.31	72.7	6.1961	1.6129
2014	7	24	16	32	18	0.3	1	0.33	56.8	6.1961	1.5054
2014	7	24	16	42	18	0.3	1	0.32	73.2	6.1961	1.6666
2014	7	24	16	52	18	0.3	1	0.3	65.4	6.1961	1.4874
2014	7	24	17	2	18	0.3	1	0.36	60.8	6.1767	1.6968
2014	7	24	17	12	18	0.3	1	0.26	56.1	6.1767	1.1967
2014	7	24	17	22	18	0.3	1	0.3	58.7	6.1767	1.411
2014	7	24	17	32	18	0.3	1	0.33	62.2	6.1767	1.5896
2014	7	24	17	42	18	0.3	1	0.27	65.6	6.1767	1.3396
2014	7	24	17	52	18	0.3	1	0.32	60	6.1767	1.5182
2014	7	24	18	2	18	0.3	1	0.28	64	6.1767	1.3931
2014	7	24	18	12	18	0.3	1	0.26	61.2	6.1574	1.2283
2014	7	24	18	22	18	0.3	1	0.32	51.6	6.1574	1.3707
2014	7	24	18	32	18	0.3	1	0.27	61.9	6.1574	1.2995
2014	7	24	18	42	18	0.3	1	0.23	78.5	6.1574	1.2283
2014	7	24	18	52	18	0.3	1	0.31	71	6.1574	1.6021
2014	7	24	19	2	18	0.3	1	0.24	85.3	6.1574	1.2995
2014	7	24	19	12	18	0.3	1	0.28	77.6	6.1574	1.4597
2014	7	24	19	22	18	0.3	1	0.25	84.8	6.1574	1.3707
2014	7	24	19	32	18	0.3	1	0.24	74.3	6.1574	1.2639
2014	7	24	19	42	18	0.3	1	0.25	80.2	6.1574	1.3351
2014	7	24	19	52	18	0.3	1	0.27	81.6	6.1574	1.4419
2014	7	24	20	2	18	0.3	1	0.25	82.4	6.1574	1.3351
2014	7	24	20	12	18	0.3	1	0.21	78.3	6.1574	1.1215
2014	7	24	20	22	18	0.3	1	0.25	78.7	6.1574	1.3351
2014	7	24	20	32	18	0.3	1	0.25	97.6	6.1574	1.3351
2014	7	24	20	42	18	0.3	1	0.31	86.9	6.138	1.6499
2014	7	24	20	52	18	0.3	1	0.2	96.7	6.1574	1.0681
2014	7	24	21	2	18	0.3	1	0.24	97.8	6.1574	1.2995
2014	7	24	21	12	18	0.3	1	0.26	84.9	6.1574	1.4063
2014	7	24	21	22	18	0.3	1	0.29	94.5	6.1574	1.5665
2014	7	24	21	32	18	0.3	1	0.32	94.7	6.1574	1.7267
2014	7	24	21	42	18	0.3	1	0.26	94.4	6.1574	1.3885
2014	7	24	21	52	18	0.3	1	0.2	90	6.1574	1.0859
2014	7	24	22	2	18	0.3	1	0.21	81.9	6.1574	1.1215
2014	7	24	22	12	18	0.3	1	0.26	100.9	6.1574	1.3885
2014	7	24	22	22	18	0.3	1	0.2	85.3	6.1767	1.0896
2014	7	24	22	32	18	0.3	1	0.24	102.5	6.1767	1.286
2014	7	24	22	42	18	0.3	1	0.26	95.1	6.1767	1.4111
2014	7	24	22	52	18	0.3	1	0.19	95.9	6.1767	1.036

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	23	2	18	0.3	1	0.26	96.5	6.1574	1.4063
2014	7	24	23	12	18	0.3	1	0.26	92.2	6.1767	1.3932
2014	7	24	23	22	18	0.3	1	0.29	86.7	6.1767	1.5718
2014	7	24	23	32	18	0.3	1	0.28	82.5	6.1767	1.5004
2014	7	24	23	42	18	0.3	1	0.24	67	6.1767	1.1789
2014	7	24	23	52	18	0.3	1	0.26	81.4	6.1767	1.4111
2014	7	25	0	2	18	0.3	1	0.24	93.2	6.1767	1.2861
2014	7	25	0	12	18	0.3	1	0.23	98.9	6.1767	1.2503
2014	7	25	0	22	18	0.3	1	0.25	72.7	6.1767	1.3218
2014	7	25	0	32	18	0.3	1	0.3	79.9	6.1767	1.6076
2014	7	25	0	42	18	0.3	1	0.26	90.7	6.1767	1.429
2014	7	25	0	52	18	0.3	1	0.26	76.7	6.1767	1.3575
2014	7	25	1	2	18	0.3	1	0.25	77.2	6.1767	1.3397
2014	7	25	1	12	18	0.3	1	0.21	78.5	6.1767	1.1432
2014	7	25	1	22	18	0.3	1	0.26	94.3	6.1767	1.429
2014	7	25	1	32	18	0.3	1	0.28	108	6.1767	1.429
2014	7	25	1	42	18	0.3	1	0.26	88.6	6.1767	1.429
2014	7	25	1	52	18	0.3	1	0.21	98.9	6.1767	1.1432
2014	7	25	2	2	18	0.3	1	0.21	86.4	6.1767	1.1253
2014	7	25	2	12	18	0.3	1	0.3	92.5	6.1767	1.6255
2014	7	25	2	22	18	0.3	1	0.28	104.4	6.1767	1.4647
2014	7	25	2	32	18	0.3	1	0.26	97.8	6.1767	1.429
2014	7	25	2	42	18	0.3	1	0.29	94.5	6.1767	1.5898
2014	7	25	2	52	18	0.3	1	0.24	91.6	6.1767	1.2861
2014	7	25	3	2	18	0.3	1	0.2	112.7	6.1767	0.9824
2014	7	25	3	12	18	0.3	1	0.24	83.7	6.1767	1.2861
2014	7	25	3	22	18	0.3	1	0.22	90.9	6.1767	1.1968
2014	7	25	3	32	18	0.3	1	0.29	84.2	6.1767	1.5898
2014	7	25	3	42	18	0.3	1	0.24	93.9	6.1767	1.304
2014	7	25	3	52	18	0.3	1	0.27	96.3	6.1767	1.4647
2014	7	25	4	2	18	0.3	1	0.2	88.1	6.1767	1.0896
2014	7	25	4	12	18	0.3	1	0.25	94.5	6.1767	1.3754
2014	7	25	4	22	18	0.3	1	0.24	94.8	6.1767	1.2861
2014	7	25	4	32	18	0.3	1	0.22	86.6	6.1767	1.2147
2014	7	25	4	42	18	0.3	1	0.22	96.1	6.1767	1.1789
2014	7	25	4	52	18	0.3	1	0.25	69.2	6.1767	1.2683
2014	7	25	5	2	18	0.3	1	0.24	90	6.1767	1.2861
2014	7	25	5	12	18	0.3	1	0.22	88.3	6.1767	1.2147
2014	7	25	5	22	18	0.3	1	0.23	89.2	6.1767	1.2683
2014	7	25	5	32	18	0.3	1	0.29	97.9	6.1767	1.5541
2014	7	25	5	42	18	0.3	1	0.23	101.3	6.1767	1.2504
2014	7	25	5	52	18	0.3	1	0.26	87.8	6.1767	1.4112
2014	7	25	6	2	18	0.3	1	0.21	84.6	6.1767	1.1432
2014	7	25	6	12	18	0.3	1	0.28	102.9	6.1574	1.4777
2014	7	25	6	22	18	0.3	1	0.17	96.6	6.1574	0.9258
2014	7	25	6	32	18	0.3	1	0.2	87.2	6.1767	1.1075

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	6	42	18	0.3	1	0.27	95.6	6.1574	1.4599
2014	7	25	6	52	18	0.3	1	0.26	67.4	6.1574	1.2818
2014	7	25	7	2	18	0.3	1	0.29	89.4	6.1574	1.5845
2014	7	25	7	12	18	0.3	1	0.23	99.2	6.1574	1.2106
2014	7	25	7	22	18	0.3	1	0.2	94.7	6.1574	1.086
2014	7	25	7	32	18	0.3	1	0.26	87.1	6.1574	1.3886
2014	7	25	7	42	18	0.3	1	0.24	94.7	6.1574	1.2996
2014	7	25	7	52	18	0.3	1	0.26	88.5	6.1574	1.3887
2014	7	25	8	2	18	0.3	1	0.26	95.8	6.1574	1.4064
2014	7	25	8	12	18	0.3	1	0.2	94.6	6.1574	1.1038
2014	7	25	8	22	18	0.3	1	0.28	90.7	6.1574	1.4955
2014	7	25	8	32	18	0.3	1	0.22	90	6.1574	1.175
2014	7	25	8	42	18	0.3	1	0.21	79.9	6.1574	1.1038
2014	7	25	8	52	18	0.3	1	0.2	71.9	6.1574	1.0326
2014	7	25	9	2	18	0.3	1	0.21	79.9	6.1574	1.1038
2014	7	25	9	12	18	0.3	1	0.27	71.8	6.1574	1.4064
2014	7	25	9	22	18	0.3	1	0.24	87.7	6.1574	1.3174
2014	7	25	9	32	18	0.3	1	0.25	98.3	6.1574	1.3352
2014	7	25	9	42	18	0.3	1	0.26	89.3	6.1574	1.4064
2014	7	25	9	52	18	0.3	1	0.28	83.2	6.1574	1.4954
2014	7	25	10	2	18	0.3	1	0.18	72.2	6.1574	0.9436
2014	7	25	10	12	18	0.3	1	0.31	88.8	6.1574	1.6735
2014	7	25	10	22	18	0.3	1	0.28	81.8	6.138	1.4726
2014	7	25	10	32	18	0.3	1	0.23	90.8	6.138	1.2242
2014	7	25	10	42	18	0.3	1	0.29	84.2	6.138	1.5791
2014	7	25	10	52	18	0.3	1	0.19	101.1	6.138	0.9936
2014	7	25	11	2	18	0.3	1	0.3	82.4	6.138	1.5968
2014	7	25	11	12	18	0.3	1	0.23	106.6	6.138	1.1887
2014	7	25	11	22	18	0.3	1	0.26	70.4	6.138	1.3484
2014	7	25	11	32	18	0.3	1	0.28	90	6.138	1.4903
2014	7	25	11	42	18	0.3	1	0.22	95.1	6.1187	1.1847
2014	7	25	11	52	18	0.3	1	0.27	75.1	6.1187	1.3969
2014	7	25	12	2	18	0.3	1	0.22	85.7	6.1187	1.1847
2014	7	25	12	12	18	0.3	1	0.29	84.2	6.0993	1.5684
2014	7	25	12	22	18	0.3	1	0.3	83.7	6.0993	1.586
2014	7	25	12	32	18	0.3	1	0.26	81.9	6.08	1.3523
2014	7	25	12	42	18	0.3	1	0.17	58.5	6.0606	0.7701
2014	7	25	12	52	18	0.3	1	0.21	80.8	6.0412	1.0814
2014	7	25	13	2	18	0.3	1	0.28	84	6.0219	1.4948
2014	7	25	13	12	18	0.3	1	0.29	92	6.0219	1.5121
2014	7	25	13	22	18	0.3	1	0.2	67.7	6.0025	0.97
2014	7	25	13	32	18	0.3	1	0.2	68.4	6.0025	1.0046
2014	7	25	13	42	18	0.3	1	0.27	75.1	6.0025	1.3683
2014	7	25	13	52	18	0.3	1	0.29	74.1	5.9832	1.4499
2014	7	25	14	2	18	0.3	1	0.27	80.2	5.9832	1.3981
2014	7	25	14	12	18	0.3	1	0.28	74.5	5.9832	1.4326

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	14	22	18	0.3	1	0.3	83.8	5.9832	1.588
2014	7	25	14	32	18	0.3	1	0.29	76.8	5.9832	1.4671
2014	7	25	14	42	18	0.3	1	0.21	80.1	5.9832	1.0874
2014	7	25	14	52	18	0.3	1	0.26	92.9	5.9832	1.3636
2014	7	25	15	2	18	0.3	1	0.24	67	5.9638	1.1352
2014	7	25	15	12	18	0.3	1	0.16	83	5.9638	0.8428
2014	7	25	15	22	18	0.3	1	0.29	89.4	5.9638	1.5308
2014	7	25	15	32	18	0.3	1	0.24	84.6	5.9638	1.2728
2014	7	25	15	42	18	0.3	1	0.21	91.8	5.9445	1.097
2014	7	25	15	52	18	0.3	1	0.21	71.6	5.9638	1.032
2014	7	25	16	2	18	0.3	1	0.3	79.3	5.9445	1.5426
2014	7	25	16	12	18	0.3	1	0.22	80.4	5.9445	1.1141
2014	7	25	16	22	18	0.3	1	0.22	62.7	5.9251	1.0248
2014	7	25	16	32	18	0.3	1	0.24	70.8	5.9445	1.1826
2014	7	25	16	42	18	0.3	1	0.27	53	5.9251	1.1102
2014	7	25	16	52	18	0.3	1	0.2	57.9	5.9251	0.8711
2014	7	25	17	2	18	0.3	1	0.19	73.1	5.9057	0.9531
2014	7	25	17	12	18	0.3	1	0.18	72.2	5.9057	0.902
2014	7	25	17	22	18	0.3	1	0.23	67.8	5.8864	1.1193
2014	7	25	17	32	18	0.3	1	0.18	71.2	5.8864	0.8989
2014	7	25	17	42	18	0.3	1	0.29	75	5.8864	1.4585
2014	7	25	17	52	18	0.3	1	0.22	69.4	5.8864	1.0854
2014	7	25	18	2	18	0.3	1	0.31	56.8	5.8864	1.3229
2014	7	25	18	12	18	0.3	1	0.28	47.4	5.867	1.0647
2014	7	25	18	22	18	0.3	1	0.19	78.3	5.867	0.9802
2014	7	25	18	32	18	0.3	1	0.29	59.1	5.8477	1.2967
2014	7	25	18	42	18	0.3	1	0.3	75.2	5.8283	1.4599
2014	7	25	18	52	18	0.3	1	0.23	96.4	5.809	1.1871
2014	7	25	19	2	18	0.3	1	0.23	80.8	5.809	1.137
2014	7	25	19	12	18	0.3	1	0.14	83.4	5.809	0.719
2014	7	25	19	22	18	0.3	1	0.18	100.7	5.809	0.8862
2014	7	25	19	32	18	0.3	1	0.19	94.8	5.809	0.9865
2014	7	25	19	42	18	0.3	1	0.2	81.5	5.7896	0.9996
2014	7	25	19	52	18	0.3	1	0.18	90	5.7896	0.9163
2014	7	25	20	2	18	0.3	1	0.18	88.9	5.7896	0.8997
2014	7	25	20	12	18	0.3	1	0.15	105.6	5.7896	0.7164
2014	7	25	20	22	18	0.3	1	0.19	81	5.7896	0.9496
2014	7	25	20	32	18	0.3	1	0.18	97.5	5.7896	0.883
2014	7	25	20	42	18	0.3	1	0.15	85.1	5.7896	0.783
2014	7	25	20	52	18	0.3	1	0.19	99	5.7896	0.9497
2014	7	25	21	2	18	0.3	1	0.11	93.5	5.7896	0.5498
2014	7	25	21	12	18	0.3	1	0.21	106.4	5.7896	1.0163
2014	7	25	21	22	18	0.3	1	0.28	70.1	5.7896	1.3329
2014	7	25	21	32	18	0.3	1	0.26	81.1	5.7702	1.2783
2014	7	25	21	42	18	0.3	1	0.18	113.3	5.7702	0.8466
2014	7	25	21	52	18	0.3	1	0.19	90	5.7702	0.9462

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	22	2	18	0.3	1	0.18	91	5.7702	0.9296
2014	7	25	22	12	18	0.3	1	0.16	98.3	5.7702	0.7968
2014	7	25	22	22	18	0.3	1	0.21	97.1	5.7702	1.0625
2014	7	25	22	32	18	0.3	1	0.19	79.1	5.7702	0.9463
2014	7	25	22	42	18	0.3	1	0.15	90	5.7509	0.7443
2014	7	25	22	52	18	0.3	1	0.14	90	5.7509	0.7278
2014	7	25	23	2	18	0.3	1	0.14	108	5.7509	0.6616
2014	7	25	23	12	18	0.3	1	0.12	99.2	5.7509	0.612
2014	7	25	23	22	18	0.3	1	0.2	97.7	5.7509	0.9759
2014	7	25	23	32	18	0.3	1	0.13	107.1	5.7509	0.6451
2014	7	25	23	42	18	0.3	1	0.14	98.3	5.7509	0.6782
2014	7	25	23	52	18	0.3	1	0.15	90	5.7509	0.7609
2014	7	26	0	2	18	0.3	1	0.2	104.9	5.7315	0.9889
2014	7	26	0	12	18	0.3	1	0.17	96.7	5.7509	0.8436
2014	7	26	0	22	18	0.3	1	0.23	102.3	5.7509	1.1414
2014	7	26	0	32	18	0.3	1	0.23	86.7	5.7509	1.1579
2014	7	26	0	42	18	0.3	1	0.17	102.2	5.7509	0.8436
2014	7	26	0	52	18	0.3	1	0.21	95.3	5.7509	1.0752
2014	7	26	1	2	18	0.3	1	0.18	103.5	5.7315	0.89
2014	7	26	1	12	18	0.3	1	0.13	97.3	5.7315	0.6428
2014	7	26	1	22	18	0.3	1	0.16	82.7	5.7315	0.7746
2014	7	26	1	32	18	0.3	1	0.14	118.4	5.7315	0.6098
2014	7	26	1	42	18	0.3	1	0.1	101.7	5.7315	0.478
2014	7	26	1	52	18	0.3	1	0.19	101.9	5.7315	0.9395
2014	7	26	2	2	18	0.3	1	0.18	117.5	5.7315	0.8241
2014	7	26	2	12	18	0.3	1	0.18	96.1	5.7315	0.923
2014	7	26	2	22	18	0.3	1	0.16	85.4	5.7315	0.8241
2014	7	26	2	32	18	0.3	1	0.21	86.4	5.7315	1.0384
2014	7	26	2	42	18	0.3	1	0.17	80.9	5.7315	0.8241
2014	7	26	2	52	18	0.3	1	0.24	107.4	5.7315	1.1537
2014	7	26	3	2	18	0.3	1	0.21	108.2	5.7315	1.0054
2014	7	26	3	12	18	0.3	1	0.17	83.4	5.7315	0.8571
2014	7	26	3	22	18	0.3	1	0.14	79.2	5.7315	0.6923
2014	7	26	3	32	18	0.3	1	0.2	101.3	5.7315	0.9889
2014	7	26	3	42	18	0.3	1	0.14	95.6	5.7315	0.6758
2014	7	26	3	52	18	0.3	1	0.22	80.4	5.7315	1.0714
2014	7	26	4	2	18	0.3	1	0.17	72.3	5.7315	0.8241
2014	7	26	4	12	18	0.3	1	0.11	96.7	5.7315	0.5604
2014	7	26	4	22	18	0.3	1	0.19	81.2	5.7315	0.956
2014	7	26	4	32	18	0.3	1	0.18	77.7	5.7315	0.9065
2014	7	26	4	42	18	0.3	1	0.19	78.9	5.7315	0.923
2014	7	26	4	52	18	0.3	1	0.18	112.4	5.7315	0.8406
2014	7	26	5	2	18	0.3	1	0.12	86.8	5.7122	0.5912
2014	7	26	5	12	18	0.3	1	0.18	85.8	5.7315	0.9065
2014	7	26	5	22	18	0.3	1	0.15	104	5.7122	0.7226
2014	7	26	5	32	18	0.3	1	0.18	91	5.7122	0.9032

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	5	42	18	0.3	1	0.15	100.1	5.7122	0.739
2014	7	26	5	52	18	0.3	1	0.15	69.6	5.7122	0.7062
2014	7	26	6	2	18	0.3	1	0.19	100	5.7122	0.9361
2014	7	26	6	12	18	0.3	1	0.14	96.8	5.7122	0.6898
2014	7	26	6	22	18	0.3	1	0.18	96.3	5.7122	0.8868
2014	7	26	6	32	18	0.3	1	0.2	85.4	5.7122	1.0182
2014	7	26	6	42	18	0.3	1	0.14	86.1	5.7122	0.7226
2014	7	26	6	52	18	0.3	1	0.16	90	5.7122	0.7883
2014	7	26	7	2	18	0.3	1	0.18	90	5.7122	0.8868
2014	7	26	7	12	18	0.3	1	0.2	81.5	5.7122	0.9854
2014	7	26	7	22	18	0.3	1	0.2	108.7	5.7122	0.969
2014	7	26	7	32	18	0.3	1	0.21	89.1	5.7122	1.0511
2014	7	26	7	42	18	0.3	1	0.13	82.7	5.7122	0.6405
2014	7	26	7	52	18	0.3	1	0.19	83.1	5.7122	0.9525
2014	7	26	8	2	18	0.3	1	0.17	123.1	5.7122	0.7062
2014	7	26	8	12	18	0.3	1	0.2	88.1	5.7122	0.9854
2014	7	26	8	22	18	0.3	1	0.19	99.1	5.7122	0.9197
2014	7	26	8	32	18	0.3	1	0.19	90	5.7122	0.9689
2014	7	26	8	42	18	0.3	1	0.2	85.3	5.7122	1.0018
2014	7	26	8	52	18	0.3	1	0.19	71.3	5.7122	0.9197
2014	7	26	9	2	18	0.3	1	0.2	99.6	5.7122	0.9689
2014	7	26	9	12	18	0.3	1	0.15	83.5	5.7122	0.7226
2014	7	26	9	22	18	0.3	1	0.17	96.5	5.7122	0.8704
2014	7	26	9	32	18	0.3	1	0.2	93.8	5.7122	0.9854
2014	7	26	9	42	18	0.3	1	0.2	96.5	5.7122	1.0018
2014	7	26	9	52	18	0.3	1	0.24	107.9	5.7122	1.166
2014	7	26	10	2	18	0.3	1	0.14	92.6	5.7122	0.7226
2014	7	26	10	12	18	0.3	1	0.16	104.6	5.7122	0.7554
2014	7	26	10	22	18	0.3	1	0.17	120.6	5.7122	0.7226
2014	7	26	10	32	18	0.3	1	0.15	96.3	5.6928	0.7363
2014	7	26	10	42	18	0.3	1	0.13	98.5	5.7122	0.6569
2014	7	26	10	52	18	0.3	1	0.27	97.5	5.6928	1.3581
2014	7	26	11	2	18	0.3	1	0.16	81.7	5.6928	0.7854
2014	7	26	11	12	18	0.3	1	0.18	92	5.6928	0.9163
2014	7	26	11	22	18	0.3	1	0.15	132.4	5.6928	0.5563
2014	7	26	11	32	18	0.3	1	0.17	100	5.6928	0.8345
2014	7	26	11	42	18	0.3	1	0.16	84.2	5.6928	0.8018
2014	7	26	11	52	18	0.3	1	0.22	92.6	5.6735	1.076
2014	7	26	12	2	18	0.3	1	0.2	64.7	5.6735	0.8966
2014	7	26	12	12	18	0.3	1	0.16	65	5.6735	0.7336
2014	7	26	12	22	18	0.3	1	0.17	85.7	5.6735	0.864
2014	7	26	12	32	18	0.3	1	0.17	87.8	5.6541	0.8284
2014	7	26	12	42	18	0.3	1	0.12	62	5.6541	0.5198
2014	7	26	12	52	18	0.3	1	0.13	56.3	5.6541	0.536
2014	7	26	13	2	18	0.3	1	0.22	67.6	5.6541	1.0233
2014	7	26	13	12	18	0.3	1	0.2	74.2	5.6541	0.9745

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	13	22	18	0.3	1	0.2	70.3	5.6541	0.9096
2014	7	26	13	32	18	0.3	1	0.13	70.6	5.6347	0.5987
2014	7	26	13	42	18	0.3	1	0.18	84.8	5.6154	0.8867
2014	7	26	13	52	18	0.3	1	0.19	74.3	5.6154	0.919
2014	7	26	14	2	18	0.3	1	0.15	90	5.596	0.7228
2014	7	26	14	12	18	0.3	1	0.23	76.6	5.5767	1.0722
2014	7	26	14	22	18	0.3	1	0.17	69	5.5767	0.7521
2014	7	26	14	32	18	0.3	1	0.17	67.8	5.5767	0.7841
2014	7	26	14	42	18	0.3	1	0.22	76.2	5.5573	1.0363
2014	7	26	14	52	18	0.3	1	0.24	55.5	5.5573	0.9725
2014	7	26	15	2	18	0.3	1	0.17	115.1	5.5573	0.7493
2014	7	26	15	12	18	0.3	1	0.13	64.1	5.5573	0.558
2014	7	26	15	22	18	0.3	1	0.25	64.8	5.538	1.08
2014	7	26	15	32	18	0.3	1	0.28	80	5.538	1.35
2014	7	26	15	42	18	0.3	1	0.21	90	5.538	1.0165
2014	7	26	15	52	18	0.3	1	0.24	64.5	5.538	1.0323
2014	7	26	16	2	18	0.3	1	0.16	60.8	5.538	0.6829
2014	7	26	16	12	18	0.3	1	0.24	52.2	5.538	0.9212
2014	7	26	16	22	18	0.3	1	0.21	70.4	5.538	0.937
2014	7	26	16	32	18	0.3	1	0.15	66.2	5.538	0.6829
2014	7	26	16	42	18	0.3	1	0.2	87.2	5.538	0.9688
2014	7	26	16	52	18	0.3	1	0.19	46.4	5.538	0.6512
2014	7	26	17	2	18	0.3	1	0.21	57.5	5.538	0.8735
2014	7	26	17	12	18	0.3	1	0.31	68	5.538	1.4135
2014	7	26	17	22	18	0.3	1	0.19	69.1	5.538	0.8735
2014	7	26	17	32	18	0.3	1	0.19	59.9	5.538	0.7941
2014	7	26	17	42	18	0.3	1	0.25	67.2	5.538	1.0959
2014	7	26	17	52	18	0.3	1	0.21	81.7	5.538	0.9847
2014	7	26	18	2	18	0.3	1	0.23	65.6	5.538	1.0165
2014	7	26	18	12	18	0.3	1	0.15	75.7	5.538	0.6829
2014	7	26	18	22	18	0.3	1	0.28	62.8	5.5186	1.2025
2014	7	26	18	32	18	0.3	1	0.16	58.8	5.5186	0.6804
2014	7	26	18	42	18	0.3	1	0.14	73.7	5.5186	0.6487
2014	7	26	18	52	18	0.3	1	0.22	64.9	5.5186	0.981
2014	7	26	19	2	18	0.3	1	0.18	71.6	5.5186	0.8069
2014	7	26	19	12	18	0.3	1	0.23	94	5.538	1.1276
2014	7	26	19	22	18	0.3	1	0.18	69	5.538	0.8259
2014	7	26	19	32	18	0.3	1	0.21	51.5	5.5186	0.7753
2014	7	26	19	42	18	0.3	1	0.2	91.8	5.5186	0.981
2014	7	26	19	52	18	0.3	1	0.17	93.4	5.5186	0.8069
2014	7	26	20	2	18	0.3	1	0.13	90	5.5186	0.6487
2014	7	26	20	12	18	0.3	1	0.14	80.3	5.538	0.6512
2014	7	26	20	22	18	0.3	1	0.2	98.7	5.538	0.9371
2014	7	26	20	32	18	0.3	1	0.17	84.5	5.5186	0.8228
2014	7	26	20	42	18	0.3	1	0.2	104.5	5.5186	0.9177
2014	7	26	20	52	18	0.3	1	0.17	84.6	5.5186	0.8386

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	21	2	18	0.3	1	0.15	83.8	5.5186	0.7278
2014	7	26	21	12	18	0.3	1	0.15	98.8	5.538	0.7147
2014	7	26	21	22	18	0.3	1	0.18	86.8	5.538	0.8577
2014	7	26	21	32	18	0.3	1	0.1	101.7	5.538	0.4606
2014	7	26	21	42	18	0.3	1	0.19	68.4	5.538	0.8418
2014	7	26	21	52	18	0.3	1	0.18	79.5	5.538	0.8577
2014	7	26	22	2	18	0.3	1	0.09	70.9	5.538	0.4129
2014	7	26	22	12	18	0.3	1	0.14	94.1	5.538	0.6671
2014	7	26	22	22	18	0.3	1	0.15	78.7	5.538	0.7147
2014	7	26	22	32	18	0.3	1	0.21	90	5.538	1.0006
2014	7	26	22	42	18	0.3	1	0.16	78	5.538	0.7465
2014	7	26	22	52	18	0.3	1	0.16	116	5.538	0.683
2014	7	26	23	2	18	0.3	1	0.12	113.8	5.5573	0.542
2014	7	26	23	12	18	0.3	1	0.19	90	5.5573	0.9247
2014	7	26	23	22	18	0.3	1	0.19	90	5.5573	0.9087
2014	7	26	23	32	18	0.3	1	0.13	98.7	5.5573	0.6218
2014	7	26	23	42	18	0.3	1	0.16	80.7	5.5573	0.7812
2014	7	26	23	52	18	0.3	1	0.19	91	5.5573	0.9087
2014	7	27	0	2	18	0.3	1	0.21	83.9	5.5767	1.0402
2014	7	27	0	12	18	0.3	1	0.13	79.6	5.5767	0.6081
2014	7	27	0	22	18	0.3	1	0.16	95.8	5.5767	0.7841
2014	7	27	0	32	18	0.3	1	0.1	88.1	5.596	0.4819
2014	7	27	0	42	18	0.3	1	0.17	78.9	5.596	0.8192
2014	7	27	0	52	18	0.3	1	0.18	85.9	5.6154	0.9029
2014	7	27	1	2	18	0.3	1	0.15	68	5.6154	0.6771
2014	7	27	1	12	18	0.3	1	0.23	90	5.6347	1.1166
2014	7	27	1	22	18	0.3	1	0.16	102.9	5.6154	0.7739
2014	7	27	1	32	18	0.3	1	0.18	99.6	5.6154	0.8545
2014	7	27	1	42	18	0.3	1	0.19	106.9	5.6347	0.9062
2014	7	27	1	52	18	0.3	1	0.16	115	5.6347	0.7282
2014	7	27	2	2	18	0.3	1	0.16	90	5.6347	0.7929
2014	7	27	2	12	18	0.3	1	0.17	92.2	5.6347	0.8577
2014	7	27	2	22	18	0.3	1	0.19	97.1	5.6541	0.9096
2014	7	27	2	32	18	0.3	1	0.17	111.6	5.6541	0.7796
2014	7	27	2	42	18	0.3	1	0.2	100.6	5.6541	0.9583
2014	7	27	2	52	18	0.3	1	0.18	96.1	5.6541	0.9096
2014	7	27	3	2	18	0.3	1	0.17	72.3	5.6541	0.8121
2014	7	27	3	12	18	0.3	1	0.15	100.3	5.6541	0.7147
2014	7	27	3	22	18	0.3	1	0.09	72.3	5.6735	0.4076
2014	7	27	3	32	18	0.3	1	0.18	103.5	5.6735	0.8803
2014	7	27	3	42	18	0.3	1	0.17	101.9	5.6735	0.8477
2014	7	27	3	52	18	0.3	1	0.1	82.6	5.6735	0.5054
2014	7	27	4	2	18	0.3	1	0.25	112.5	5.6735	1.1412
2014	7	27	4	12	18	0.3	1	0.12	67.6	5.6735	0.5543
2014	7	27	4	22	18	0.3	1	0.23	87.6	5.6735	1.1575
2014	7	27	4	32	18	0.3	1	0.19	72.8	5.6735	0.8966

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	4	42	18	0.3	1	0.17	84.6	5.6735	0.864
2014	7	27	4	52	18	0.3	1	0.14	95.3	5.6928	0.7036
2014	7	27	5	2	18	0.3	1	0.23	75.4	5.6928	1.129
2014	7	27	5	12	18	0.3	1	0.15	83.5	5.6928	0.72
2014	7	27	5	22	18	0.3	1	0.14	102.4	5.6928	0.6709
2014	7	27	5	32	18	0.3	1	0.15	90	5.6928	0.7363
2014	7	27	5	42	18	0.3	1	0.14	95.3	5.6735	0.701
2014	7	27	5	52	18	0.3	1	0.17	118	5.6928	0.769
2014	7	27	6	2	18	0.3	1	0.15	78.9	5.6928	0.7527
2014	7	27	6	12	18	0.3	1	0.21	81.1	5.6928	1.0472
2014	7	27	6	22	18	0.3	1	0.16	94.7	5.6928	0.8018
2014	7	27	6	32	18	0.3	1	0.18	85.9	5.6928	0.9163
2014	7	27	6	42	18	0.3	1	0.16	88.8	5.6928	0.8018
2014	7	27	6	52	18	0.3	1	0.1	105.9	5.6928	0.4582
2014	7	27	7	2	18	0.3	1	0.11	91.8	5.6928	0.5236
2014	7	27	7	12	18	0.3	1	0.15	112	5.6928	0.6872
2014	7	27	7	22	18	0.3	1	0.13	67.9	5.6735	0.6032
2014	7	27	7	32	18	0.3	1	0.18	86.9	5.6928	0.9
2014	7	27	7	42	18	0.3	1	0.23	99.7	5.6928	1.1454
2014	7	27	7	52	18	0.3	1	0.14	90	5.6928	0.72
2014	7	27	8	2	18	0.3	1	0.12	90	5.6735	0.6195
2014	7	27	8	12	18	0.3	1	0.21	90	5.6735	1.0271
2014	7	27	8	22	18	0.3	1	0.19	92.9	5.6735	0.9619
2014	7	27	8	32	18	0.3	1	0.17	64.4	5.6735	0.7499
2014	7	27	8	42	18	0.3	1	0.2	73.7	5.6735	0.9456
2014	7	27	8	52	18	0.3	1	0.14	90	5.6735	0.7173
2014	7	27	9	2	18	0.3	1	0.12	104	5.6735	0.5869
2014	7	27	9	12	18	0.3	1	0.2	90	5.6735	0.9945
2014	7	27	9	22	18	0.3	1	0.17	71.6	5.6735	0.7825
2014	7	27	9	32	18	0.3	1	0.12	85.1	5.6735	0.5706
2014	7	27	9	42	18	0.3	1	0.16	90	5.6735	0.7988
2014	7	27	9	52	18	0.3	1	0.17	65.5	5.6735	0.7499
2014	7	27	10	2	18	0.3	1	0.24	90	5.6541	1.1695
2014	7	27	10	12	18	0.3	1	0.18	72.6	5.6541	0.8284
2014	7	27	10	22	18	0.3	1	0.16	100.6	5.6541	0.7796
2014	7	27	10	32	18	0.3	1	0.18	89	5.6541	0.9096
2014	7	27	10	42	18	0.3	1	0.21	93.6	5.6541	1.0233
2014	7	27	10	52	18	0.3	1	0.1	101	5.6541	0.5035
2014	7	27	11	2	18	0.3	1	0.18	71.6	5.6347	0.8253
2014	7	27	11	12	18	0.3	1	0.21	87.3	5.6347	1.0357
2014	7	27	11	22	18	0.3	1	0.17	93.4	5.6347	0.8253
2014	7	27	11	32	18	0.3	1	0.22	86.6	5.6154	1.0963
2014	7	27	11	42	18	0.3	1	0.18	96.1	5.6154	0.9029
2014	7	27	11	52	18	0.3	1	0.19	61.2	5.596	0.8192
2014	7	27	12	2	18	0.3	1	0.18	82.7	5.5767	0.8802
2014	7	27	12	12	18	0.3	1	0.13	103.3	5.5573	0.6058

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	12	22	18	0.3	1	0.16	63.4	5.5573	0.7015
2014	7	27	12	32	18	0.3	1	0.15	101.1	5.5573	0.7334
2014	7	27	12	42	18	0.3	1	0.24	90	5.5573	1.1479
2014	7	27	12	52	18	0.3	1	0.17	90	5.5573	0.8131
2014	7	27	13	2	18	0.3	1	0.18	101.7	5.538	0.8418
2014	7	27	13	12	18	0.3	1	0.22	76.4	5.538	1.0483
2014	7	27	13	22	18	0.3	1	0.22	76.8	5.538	1.0165
2014	7	27	13	32	18	0.3	1	0.23	77.7	5.538	1.0959
2014	7	27	13	42	18	0.3	1	0.19	85	5.538	0.9053
2014	7	27	13	52	18	0.3	1	0.23	74.6	5.538	1.0959
2014	7	27	14	2	18	0.3	1	0.19	86	5.538	0.9053
2014	7	27	14	12	18	0.3	1	0.25	79.6	5.538	1.2071
2014	7	27	14	22	18	0.3	1	0.2	54.5	5.538	0.7782
2014	7	27	14	32	18	0.3	1	0.16	87.7	5.5186	0.7911
2014	7	27	14	42	18	0.3	1	0.21	63.4	5.5186	0.9177
2014	7	27	14	52	18	0.3	1	0.16	73.7	5.5186	0.7595
2014	7	27	15	2	18	0.3	1	0.23	75.2	5.5186	1.0759
2014	7	27	15	12	18	0.3	1	0.19	66.9	5.5186	0.8544
2014	7	27	15	22	18	0.3	1	0.2	68	5.5186	0.9019
2014	7	27	15	32	18	0.3	1	0.22	62.7	5.5186	0.9493
2014	7	27	15	42	18	0.3	1	0.23	70.3	5.5186	1.0601
2014	7	27	15	52	18	0.3	1	0.23	69.3	5.5186	1.0443
2014	7	27	16	2	18	0.3	1	0.19	68.4	5.5186	0.8386
2014	7	27	16	12	18	0.3	1	0.2	76.7	5.5186	0.9335
2014	7	27	16	22	18	0.3	1	0.2	90	5.5186	0.981
2014	7	27	16	32	18	0.3	1	0.21	71.6	5.5186	0.9493
2014	7	27	16	42	18	0.3	1	0.18	90	5.5186	0.886
2014	7	27	16	52	18	0.3	1	0.14	57.8	5.5186	0.5538
2014	7	27	17	2	18	0.3	1	0.19	76.9	5.4993	0.8827
2014	7	27	17	12	18	0.3	1	0.26	77	5.4993	1.2295
2014	7	27	17	22	18	0.3	1	0.17	77.8	5.4993	0.8039
2014	7	27	17	32	18	0.3	1	0.14	57.8	5.4993	0.5517
2014	7	27	17	42	18	0.3	1	0.15	70.3	5.4993	0.662
2014	7	27	17	52	18	0.3	1	0.18	74.9	5.4993	0.8196
2014	7	27	18	2	18	0.3	1	0.22	45	5.4993	0.7566
2014	7	27	18	12	18	0.3	1	0.19	67.5	5.4993	0.8354
2014	7	27	18	22	18	0.3	1	0.14	46.8	5.4993	0.5044
2014	7	27	18	32	18	0.3	1	0.2	79.6	5.4993	0.9457
2014	7	27	18	42	18	0.3	1	0.15	55.6	5.4993	0.599
2014	7	27	18	52	18	0.3	1	0.12	90	5.4993	0.599
2014	7	27	19	2	18	0.3	1	0.2	60.9	5.4993	0.8196
2014	7	27	19	12	18	0.3	1	0.15	52.4	5.4993	0.5517
2014	7	27	19	22	18	0.3	1	0.19	62.1	5.4993	0.8039
2014	7	27	19	32	18	0.3	1	0.23	57.5	5.4993	0.9142
2014	7	27	19	42	18	0.3	1	0.13	65.4	5.4993	0.5517
2014	7	27	19	52	18	0.3	1	0.19	63.9	5.4993	0.8039

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	20	2	18	0.3	1	0.28	56.5	5.4993	1.1191
2014	7	27	20	12	18	0.3	1	0.16	80.5	5.4993	0.7566
2014	7	27	20	22	18	0.3	1	0.2	73.4	5.4993	0.8985
2014	7	27	20	32	18	0.3	1	0.21	86.4	5.4799	1.005
2014	7	27	20	42	18	0.3	1	0.36	45	5.4412	1.1999
2014	7	27	20	52	18	0.3	1	0.29	39.5	5.4993	0.8827
2014	7	27	21	2	18	0.3	1	0.31	39.8	5.4799	0.9422
2014	7	27	21	12	18	0.3	1	0.34	26.6	5.5573	0.7493
2014	7	27	21	22	18	0.3	1	0.31	33.2	5.6154	0.8222
2014	7	27	21	32	18	0.3	1	0.28	41.2	5.6541	0.9095
2014	7	27	21	42	18	0.3	1	0.3	49.1	5.6735	1.1085
2014	7	27	21	52	18	0.3	1	0.3	40.2	5.6928	0.9816
2014	7	27	22	2	18	0.3	1	0.28	50.8	5.7122	1.0673
2014	7	27	22	12	18	0.3	1	0.3	36.5	5.6928	0.8835
2014	7	27	22	22	18	0.3	1	0.3	39.2	5.7315	0.9394
2014	7	27	22	32	18	0.3	1	0.32	43.8	5.7315	1.1207
2014	7	27	22	42	18	0.3	1	0.34	31.8	5.7315	0.89
2014	7	27	22	52	18	0.3	1	0.33	44.2	5.7315	1.1537
2014	7	27	23	2	18	0.3	1	0.33	34.8	5.7122	0.936
2014	7	27	23	12	18	0.3	1	0.36	25.2	5.7315	0.7746
2014	7	27	23	22	18	0.3	1	0.42	41.8	5.7315	1.4009
2014	7	27	23	32	18	0.3	1	0.42	34.3	5.7315	1.2031
2014	7	27	23	42	18	0.3	1	0.35	40.4	5.7315	1.1372
2014	7	27	23	52	18	0.3	1	0.36	42.1	5.7315	1.2196
2014	7	28	0	2	18	0.3	1	0.37	29.1	5.7315	0.9065
2014	7	28	0	12	18	0.3	1	0.36	31.8	5.7315	0.9394
2014	7	28	0	22	18	0.3	1	0.34	34.9	5.7315	0.9889
2014	7	28	0	32	18	0.3	1	0.38	34.8	5.7315	1.0878
2014	7	28	0	42	18	0.3	1	0.38	34.9	5.7315	1.1042
2014	7	28	0	52	18	0.3	1	0.36	23.3	5.7315	0.7252
2014	7	28	1	2	18	0.3	1	0.39	27.2	5.7315	0.89
2014	7	28	1	12	18	0.3	1	0.42	29.2	5.7315	1.0218
2014	7	28	1	22	18	0.3	1	0.42	24.6	5.7315	0.8735
2014	7	28	1	32	18	0.3	1	0.42	25.2	5.7122	0.8868
2014	7	28	1	42	18	0.3	1	0.49	31.4	5.7315	1.2855
2014	7	28	1	52	18	0.3	1	0.43	26.2	5.7315	0.9559
2014	7	28	2	2	18	0.3	1	0.42	32.8	5.7315	1.1372
2014	7	28	2	12	18	0.3	1	0.38	32.3	5.7315	1.0219
2014	7	28	2	22	18	0.3	1	0.37	29.1	5.7315	0.9065
2014	7	28	2	32	18	0.3	1	0.4	41.7	5.7315	1.3515
2014	7	28	2	42	18	0.3	1	0.33	33.4	5.7315	0.923
2014	7	28	2	52	18	0.3	1	0.36	42.1	5.7122	1.2152
2014	7	28	3	2	18	0.3	1	0.39	39.3	5.7315	1.2526
2014	7	28	3	12	18	0.3	1	0.32	30.5	5.7315	0.8241
2014	7	28	3	22	18	0.3	1	0.42	45	5.7315	1.4834
2014	7	28	3	32	18	0.3	1	0.42	37.3	5.7315	1.2691

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	3	42	18	0.3	1	0.42	41.5	5.7122	1.3794
2014	7	28	3	52	18	0.3	1	0.36	43.9	5.7122	1.2645
2014	7	28	4	2	18	0.3	1	0.3	28.6	5.7122	0.7061
2014	7	28	4	12	18	0.3	1	0.33	49.9	5.7122	1.2481
2014	7	28	4	22	18	0.3	1	0.29	46.4	5.7122	1.0346
2014	7	28	4	32	18	0.3	1	0.34	55.7	5.7122	1.3959
2014	7	28	4	42	18	0.3	1	0.25	36.9	5.7122	0.739
2014	7	28	4	52	18	0.3	1	0.29	40.9	5.7122	0.9525
2014	7	28	5	2	18	0.3	1	0.23	61.6	5.7122	1.0017
2014	7	28	5	12	18	0.3	1	0.25	36	5.7122	0.739
2014	7	28	5	22	18	0.3	1	0.19	43.6	5.7122	0.6569
2014	7	28	5	32	18	0.3	1	0.21	50.8	5.7122	0.8047
2014	7	28	5	42	18	0.3	1	0.21	29	5.7122	0.5091
2014	7	28	5	52	18	0.3	1	0.19	60.8	5.7122	0.8211
2014	7	28	6	2	18	0.3	1	0.23	56.8	5.7122	0.9525
2014	7	28	6	12	18	0.3	1	0.28	63.1	5.7122	1.2645
2014	7	28	6	22	18	0.3	1	0.13	56.7	5.7122	0.5255
2014	7	28	6	32	18	0.3	1	0.19	66.9	5.7122	0.8868
2014	7	28	6	42	18	0.3	1	0.2	45	5.7122	0.7062
2014	7	28	6	52	18	0.3	1	0.2	57.9	5.6928	0.8345
2014	7	28	7	2	18	0.3	1	0.19	37.9	5.6928	0.5727
2014	7	28	7	12	18	0.3	1	0.19	52	5.6928	0.7527
2014	7	28	7	22	18	0.3	1	0.12	50.6	5.6928	0.4581
2014	7	28	7	32	18	0.3	1	0.21	57.3	5.6928	0.8672
2014	7	28	7	42	18	0.3	1	0.2	68.9	5.6928	0.9326
2014	7	28	7	52	18	0.3	1	0.15	56.3	5.6928	0.6381
2014	7	28	8	2	18	0.3	1	0.25	68.5	5.6928	1.1617
2014	7	28	8	12	18	0.3	1	0.17	50.6	5.6928	0.6381
2014	7	28	8	22	18	0.3	1	0.24	58.1	5.6735	0.9944
2014	7	28	8	32	18	0.3	1	0.22	61.5	5.6735	0.9618
2014	7	28	8	42	18	0.3	1	0.22	76.2	5.6735	1.0596
2014	7	28	8	52	18	0.3	1	0.19	72.8	5.6735	0.8966
2014	7	28	9	2	18	0.3	1	0.16	63.4	5.6735	0.7173
2014	7	28	9	12	18	0.3	1	0.21	85.5	5.6735	1.027
2014	7	28	9	22	18	0.3	1	0.21	52.6	5.6541	0.8284
2014	7	28	9	32	18	0.3	1	0.25	80.9	5.6541	1.2182
2014	7	28	9	42	18	0.3	1	0.24	63.1	5.6541	1.0557
2014	7	28	9	52	18	0.3	1	0.17	68.4	5.6347	0.7768
2014	7	28	10	2	18	0.3	1	0.22	52.1	5.6347	0.8738
2014	7	28	10	12	18	0.3	1	0.16	69.3	5.6347	0.7282
2014	7	28	10	22	18	0.3	1	0.21	67.5	5.6347	0.9386
2014	7	28	10	32	18	0.3	1	0.23	85.2	5.6154	1.1447
2014	7	28	10	42	18	0.3	1	0.19	75	5.6154	0.9029
2014	7	28	10	52	18	0.3	1	0.26	84.9	5.6154	1.2737
2014	7	28	11	2	18	0.3	1	0.23	63.4	5.596	0.9959
2014	7	28	11	12	18	0.3	1	0.23	58.8	5.596	0.9798

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	11	22	18	0.3	1	0.24	50.5	5.5767	0.9122
2014	7	28	11	32	18	0.3	1	0.23	64.9	5.5573	1.0203
2014	7	28	11	42	18	0.3	1	0.18	56	5.5573	0.7334
2014	7	28	11	52	18	0.3	1	0.17	78.1	5.5573	0.829
2014	7	28	12	2	18	0.3	1	0.16	65	5.5573	0.7174
2014	7	28	12	12	18	0.3	1	0.13	58.3	5.5573	0.5421
2014	7	28	12	22	18	0.3	1	0.19	63.9	5.5573	0.8131
2014	7	28	12	32	18	0.3	1	0.24	68.3	5.5573	1.0841
2014	7	28	12	42	18	0.3	1	0.23	59	5.5573	0.9566
2014	7	28	12	52	18	0.3	1	0.22	76	5.538	1.0165
2014	7	28	13	2	18	0.3	1	0.19	45	5.538	0.6353
2014	7	28	13	12	18	0.3	1	0.21	49.5	5.538	0.7624
2014	7	28	13	22	18	0.3	1	0.19	66.5	5.538	0.8418
2014	7	28	13	32	18	0.3	1	0.19	37.3	5.538	0.5559
2014	7	28	13	42	18	0.3	1	0.21	90.9	5.538	1.0006
2014	7	28	13	52	18	0.3	1	0.15	58	5.538	0.6353
2014	7	28	14	2	18	0.3	1	0.19	52.9	5.538	0.7147
2014	7	28	14	12	18	0.3	1	0.22	59.9	5.5186	0.9019
2014	7	28	14	22	18	0.3	1	0.22	45.6	5.5186	0.7437
2014	7	28	14	32	18	0.3	1	0.21	43.1	5.5186	0.6804
2014	7	28	14	42	18	0.3	1	0.23	45	5.5186	0.7753
2014	7	28	14	52	18	0.3	1	0.15	32.7	5.5186	0.3956
2014	7	28	15	2	18	0.3	1	0.22	69.4	5.5186	1.0127
2014	7	28	15	12	18	0.3	1	0.27	46.9	5.5186	0.9652
2014	7	28	15	22	18	0.3	1	0.23	45	5.5186	0.7753
2014	7	28	15	32	18	0.3	1	0.29	45	5.5186	0.981
2014	7	28	15	42	18	0.3	1	0.16	39	5.4993	0.4729
2014	7	28	15	52	18	0.3	1	0.22	31.6	5.4993	0.5517
2014	7	28	16	2	18	0.3	1	0.25	56.7	5.4993	1.0088
2014	7	28	16	12	18	0.3	1	0.23	76.6	5.4993	1.0561
2014	7	28	16	22	18	0.3	1	0.23	41.5	5.4993	0.7251
2014	7	28	16	32	18	0.3	1	0.23	47.8	5.4993	0.8354
2014	7	28	16	42	18	0.3	1	0.27	42.6	5.4993	0.8827
2014	7	28	16	52	18	0.3	1	0.28	47.4	5.5186	0.9968
2014	7	28	17	2	18	0.3	1	0.14	50.5	5.5186	0.538
2014	7	28	17	12	18	0.3	1	0.24	51.1	5.5186	0.9019
2014	7	28	17	22	18	0.3	1	0.29	46.4	5.5186	0.9968
2014	7	28	17	32	18	0.3	1	0.3	39.2	5.5186	0.9019
2014	7	28	17	42	18	0.3	1	0.24	37.8	5.5186	0.712
2014	7	28	17	52	18	0.3	1	0.34	35.5	5.5186	0.9494
2014	7	28	18	2	18	0.3	1	0.33	38.2	5.5186	0.9968
2014	7	28	18	12	18	0.3	1	0.31	39.9	5.5186	0.9652
2014	7	28	18	22	18	0.3	1	0.4	40.4	5.5186	1.2658
2014	7	28	18	32	18	0.3	1	0.32	30	5.5186	0.7753
2014	7	28	18	42	18	0.3	1	0.3	34.4	5.5186	0.8228
2014	7	28	18	52	18	0.3	1	0.31	43.3	5.5186	1.0285

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	19	2	18	0.3	1	0.3	26.3	5.5186	0.6329
2014	7	28	19	12	18	0.3	1	0.23	34.4	5.5186	0.6171
2014	7	28	19	22	18	0.3	1	0.34	36.8	5.538	0.9847
2014	7	28	19	32	18	0.3	1	0.25	37.5	5.538	0.7306
2014	7	28	19	42	18	0.3	1	0.29	37.3	5.538	0.8577
2014	7	28	19	52	18	0.3	1	0.26	27.5	5.538	0.5877
2014	7	28	20	2	18	0.3	1	0.24	38.9	5.538	0.7306
2014	7	28	20	12	18	0.3	1	0.33	49.1	5.538	1.1912
2014	7	28	20	22	18	0.3	1	0.25	47.6	5.538	0.9053
2014	7	28	20	32	18	0.3	1	0.2	30	5.538	0.4765
2014	7	28	20	42	18	0.3	1	0.16	42.6	5.538	0.54
2014	7	28	20	52	18	0.3	1	0.19	59.5	5.5573	0.8131
2014	7	28	21	2	18	0.3	1	0.21	60.3	5.5573	0.8928
2014	7	28	21	12	18	0.3	1	0.23	35.1	5.5767	0.6401
2014	7	28	21	22	18	0.3	1	0.23	45	5.596	0.7871
2014	7	28	21	32	18	0.3	1	0.22	50.9	5.6347	0.8577
2014	7	28	21	42	18	0.3	1	0.2	55.8	5.6347	0.8091
2014	7	28	21	52	18	0.3	1	0.27	48.5	5.6347	0.9871
2014	7	28	22	2	18	0.3	1	0.28	47.4	5.6541	1.007
2014	7	28	22	12	18	0.3	1	0.25	50.4	5.6541	0.942
2014	7	28	22	22	18	0.3	1	0.27	58.2	5.6541	1.1532
2014	7	28	22	32	18	0.3	1	0.3	51.7	5.6541	1.1532
2014	7	28	22	42	18	0.3	1	0.27	39.1	5.6541	0.8446
2014	7	28	22	52	18	0.3	1	0.31	40.3	5.6541	1.007
2014	7	28	23	2	18	0.3	1	0.24	45	5.6541	0.8284
2014	7	28	23	12	18	0.3	1	0.24	58.2	5.6541	1.0233
2014	7	28	23	22	18	0.3	1	0.29	52	5.6541	1.1207
2014	7	28	23	32	18	0.3	1	0.26	65.7	5.6541	1.1857
2014	7	28	23	42	18	0.3	1	0.32	58.7	5.6541	1.3644
2014	7	28	23	52	18	0.3	1	0.27	55.9	5.6735	1.1085
2014	7	29	0	2	18	0.3	1	0.27	46	5.6735	0.9781
2014	7	29	0	12	18	0.3	1	0.29	63.7	5.6541	1.2831
2014	7	29	0	22	18	0.3	1	0.2	63.4	5.6735	0.8803
2014	7	29	0	32	18	0.3	1	0.25	52.4	5.6735	0.9944
2014	7	29	0	42	18	0.3	1	0.23	36.9	5.6735	0.6847
2014	7	29	0	52	18	0.3	1	0.28	46.4	5.6735	0.9944
2014	7	29	1	2	18	0.3	1	0.31	34.7	5.6735	0.8803
2014	7	29	1	12	18	0.3	1	0.22	54	5.6735	0.8966
2014	7	29	1	22	18	0.3	1	0.29	54.2	5.6735	1.1738
2014	7	29	1	32	18	0.3	1	0.31	36.3	5.6735	0.8966
2014	7	29	1	42	18	0.3	1	0.27	43.5	5.6735	0.9129
2014	7	29	1	52	18	0.3	1	0.21	36.7	5.6735	0.6195
2014	7	29	2	2	18	0.3	1	0.24	38.8	5.6735	0.7336
2014	7	29	2	12	18	0.3	1	0.19	40.8	5.6735	0.6195
2014	7	29	2	22	18	0.3	1	0.19	57.4	5.6735	0.8151
2014	7	29	2	32	18	0.3	1	0.2	60	5.6735	0.8477

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	2	42	18	0.3	1	0.22	41.3	5.6735	0.7173
2014	7	29	2	52	18	0.3	1	0.22	66.9	5.6735	0.9945
2014	7	29	3	2	18	0.3	1	0.17	69	5.6735	0.7662
2014	7	29	3	12	18	0.3	1	0.19	48.4	5.6541	0.7147
2014	7	29	3	22	18	0.3	1	0.16	76.8	5.6541	0.7634
2014	7	29	3	32	18	0.3	1	0.13	58.3	5.6541	0.5523
2014	7	29	3	42	18	0.3	1	0.21	73.6	5.6541	0.9908
2014	7	29	3	52	18	0.3	1	0.08	66.5	5.6541	0.3736
2014	7	29	4	2	18	0.3	1	0.2	61.8	5.6347	0.8739
2014	7	29	4	12	18	0.3	1	0.18	79.7	5.6347	0.8901
2014	7	29	4	22	18	0.3	1	0.15	74.7	5.6347	0.7121
2014	7	29	4	32	18	0.3	1	0.2	75.1	5.6154	0.9674
2014	7	29	4	42	18	0.3	1	0.18	58.9	5.6347	0.7768
2014	7	29	4	52	18	0.3	1	0.21	70.7	5.6154	0.9674
2014	7	29	5	2	18	0.3	1	0.13	64.7	5.6154	0.5804
2014	7	29	5	12	18	0.3	1	0.14	59.9	5.6154	0.6127
2014	7	29	5	22	18	0.3	1	0.14	92.6	5.596	0.7068
2014	7	29	5	32	18	0.3	1	0.15	76	5.5767	0.7042
2014	7	29	5	42	18	0.3	1	0.15	70.3	5.5767	0.6722
2014	7	29	5	52	18	0.3	1	0.21	65.9	5.5573	0.9247
2014	7	29	6	2	18	0.3	1	0.17	78.1	5.5573	0.8291
2014	7	29	6	12	18	0.3	1	0.17	70.9	5.5573	0.7812
2014	7	29	6	22	18	0.3	1	0.21	81.1	5.5573	1.0204
2014	7	29	6	32	18	0.3	1	0.22	76.4	5.538	1.0483
2014	7	29	6	42	18	0.3	1	0.14	65.9	5.538	0.6036
2014	7	29	6	52	18	0.3	1	0.18	51.7	5.538	0.683
2014	7	29	7	2	18	0.3	1	0.13	87.1	5.5186	0.6171
2014	7	29	7	12	18	0.3	1	0.13	81.5	5.5186	0.633
2014	7	29	7	22	18	0.3	1	0.15	72	5.5186	0.6804
2014	7	29	7	32	18	0.3	1	0.16	74.5	5.5186	0.7437
2014	7	29	7	42	18	0.3	1	0.12	90	5.5186	0.6013
2014	7	29	7	52	18	0.3	1	0.11	78.4	5.5186	0.538
2014	7	29	8	2	18	0.3	1	0.12	53.7	5.4993	0.4729
2014	7	29	8	12	18	0.3	1	0.12	61.3	5.4993	0.4887
2014	7	29	8	22	18	0.3	1	0.13	53.1	5.4993	0.5045
2014	7	29	8	32	18	0.3	1	0.16	91.2	5.4993	0.7724
2014	7	29	8	42	18	0.3	1	0.17	80	5.4993	0.804
2014	7	29	8	52	18	0.3	1	0.13	47	5.4993	0.4572
2014	7	29	9	2	18	0.3	1	0.18	73.2	5.4993	0.8355
2014	7	29	9	12	18	0.3	1	0.1	62.6	5.4993	0.4256
2014	7	29	9	22	18	0.3	1	0.14	90	5.4799	0.691
2014	7	29	9	32	18	0.3	1	0.05	68.2	5.4799	0.2356
2014	7	29	9	42	18	0.3	1	0.1	76.4	5.4799	0.4554
2014	7	29	9	52	18	0.3	1	0.16	70.4	5.4799	0.7067
2014	7	29	10	2	18	0.3	1	0.15	66.8	5.4799	0.6596
2014	7	29	10	12	18	0.3	1	0.12	61.3	5.4799	0.4868

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	10	22	18	0.3	1	0.16	66.6	5.4799	0.691
2014	7	29	10	32	18	0.3	1	0.18	79.5	5.4799	0.848
2014	7	29	10	42	18	0.3	1	0.1	62.6	5.4605	0.4224
2014	7	29	10	52	18	0.3	1	0.15	78.4	5.4605	0.6883
2014	7	29	11	2	18	0.3	1	0.16	69.3	5.4605	0.704
2014	7	29	11	12	18	0.3	1	0.14	57.8	5.4605	0.5475
2014	7	29	11	22	18	0.3	1	0.13	64.7	5.4412	0.561
2014	7	29	11	32	18	0.3	1	0.14	67.7	5.4412	0.6078
2014	7	29	11	42	18	0.3	1	0.11	78	5.4218	0.5123
2014	7	29	11	52	18	0.3	1	0.12	85.4	5.4218	0.5744
2014	7	29	12	2	18	0.3	1	0.08	63.4	5.4218	0.3415
2014	7	29	12	12	18	0.3	1	0.09	19.1	5.4025	0.1392
2014	7	29	12	22	18	0.3	1	0.13	79.8	5.3831	0.6008
2014	7	29	12	32	18	0.3	1	0.05	348.7	5.3638	-0.046
2014	7	29	12	42	18	0.3	1	0.09	85.8	5.3444	0.4127
2014	7	29	12	52	18	0.3	1	0.07	18.4	5.325	0.1066
2014	7	29	13	2	18	0.3	1	0.1	3.9	5.325	0.0305
2014	7	29	13	12	18	0.3	1	0.03	90	5.325	0.1523
2014	7	29	13	22	18	0.3	1	0.07	59.9	5.325	0.2893
2014	7	29	13	32	18	0.3	1	0.08	66.5	5.3057	0.3488
2014	7	29	13	42	18	0.3	1	0.1	35.3	5.325	0.2588
2014	7	29	13	52	18	0.3	1	0.06	38.2	5.3057	0.1668
2014	7	29	14	2	18	0.3	1	0.11	61.1	5.3057	0.4398
2014	7	29	14	12	18	0.3	1	0.11	45	5.3057	0.3488
2014	7	29	14	22	18	0.3	1	0.1	80.8	5.3057	0.4701
2014	7	29	14	32	18	0.3	1	0.13	74.9	5.3057	0.5611
2014	7	29	14	42	18	0.3	1	0.13	59	5.2863	0.5287
2014	7	29	14	52	18	0.3	1	0.18	77.5	5.3057	0.8189
2014	7	29	15	2	18	0.3	1	0.14	68.7	5.3057	0.6218
2014	7	29	15	12	18	0.3	1	0.2	59.7	5.3057	0.8038
2014	7	29	15	22	18	0.3	1	0.13	80.1	5.2863	0.6042
2014	7	29	15	32	18	0.3	1	0.12	50.4	5.2863	0.4381
2014	7	29	15	42	18	0.3	1	0.21	66.7	5.2863	0.8761
2014	7	29	15	52	18	0.3	1	0.17	52.2	5.2863	0.6042
2014	7	29	16	2	18	0.3	1	0.22	54.2	5.2863	0.8157
2014	7	29	16	12	18	0.3	1	0.25	55.1	5.3057	0.9554
2014	7	29	16	22	18	0.3	1	0.2	45	5.2863	0.6495
2014	7	29	16	32	18	0.3	1	0.21	52.6	5.2863	0.7704
2014	7	29	16	42	18	0.3	1	0.18	61.1	5.2863	0.7402
2014	7	29	16	52	18	0.3	1	0.24	60.3	5.2863	0.9516
2014	7	29	17	2	18	0.3	1	0.15	48.5	5.2863	0.5287
2014	7	29	17	12	18	0.3	1	0.19	53.9	5.2863	0.7251
2014	7	29	17	22	18	0.3	1	0.2	59.2	5.2863	0.7855
2014	7	29	17	32	18	0.3	1	0.18	50.2	5.2863	0.6344
2014	7	29	17	42	18	0.3	1	0.2	50.9	5.2863	0.7251
2014	7	29	17	52	18	0.3	1	0.23	47.3	5.2863	0.7855

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	18	2	18	0.3	1	0.27	45	5.2863	0.8761
2014	7	29	18	12	18	0.3	1	0.17	52	5.2863	0.6193
2014	7	29	18	22	18	0.3	1	0.24	37.3	5.3057	0.6824
2014	7	29	18	32	18	0.3	1	0.18	43.5	5.3057	0.5763
2014	7	29	18	42	18	0.3	1	0.21	32.9	5.3057	0.5308
2014	7	29	18	52	18	0.3	1	0.22	43.2	5.3057	0.6976
2014	7	29	19	2	18	0.3	1	0.15	20.9	5.3057	0.2426
2014	7	29	19	12	18	0.3	1	0.18	32.6	5.325	0.4567
2014	7	29	19	22	18	0.3	1	0.2	19	5.325	0.3045
2014	7	29	19	32	18	0.3	1	0.18	69.2	5.3444	0.7642
2014	7	29	19	42	18	0.3	1	0.16	60.8	5.3638	0.6598
2014	7	29	19	52	18	0.3	1	0.07	35.2	5.4218	0.1863
2014	7	29	20	2	18	0.3	1	0.14	55.6	5.4412	0.5454
2014	7	29	20	12	18	0.3	1	0.17	53.6	5.4799	0.6595
2014	7	29	20	22	18	0.3	1	0.21	70.4	5.4993	0.93
2014	7	29	20	32	18	0.3	1	0.25	68.5	5.5186	1.1234
2014	7	29	20	42	18	0.3	1	0.14	57.4	5.538	0.5717
2014	7	29	20	52	18	0.3	1	0.2	79.4	5.5573	0.9406
2014	7	29	21	2	18	0.3	1	0.22	65.7	5.5767	0.9921
2014	7	29	21	12	18	0.3	1	0.24	71.3	5.596	1.0922
2014	7	29	21	22	18	0.3	1	0.2	60.5	5.6735	0.8639
2014	7	29	21	32	18	0.3	1	0.23	65.3	5.6928	1.0307
2014	7	29	21	42	18	0.3	1	0.2	63	5.7315	0.8735
2014	7	29	21	52	18	0.3	1	0.23	64.5	5.7509	1.042
2014	7	29	22	2	18	0.3	1	0.19	87	5.7509	0.9593
2014	7	29	22	12	18	0.3	1	0.09	96.1	5.7702	0.4648
2014	7	29	22	22	18	0.3	1	0.21	64.6	5.7896	0.9829
2014	7	29	22	32	18	0.3	1	0.18	64.4	5.809	0.836
2014	7	29	22	42	18	0.3	1	0.13	74.9	5.8283	0.6209
2014	7	29	22	52	18	0.3	1	0.19	83.2	5.8864	1.0006
2014	7	29	23	2	18	0.3	1	0.23	79.2	5.9057	1.1574
2014	7	29	23	12	18	0.3	1	0.2	76.7	5.9251	1.0077
2014	7	29	23	22	18	0.3	1	0.19	73.8	5.9445	0.9427
2014	7	29	23	32	18	0.3	1	0.16	72.3	5.9638	0.8084
2014	7	29	23	42	18	0.3	1	0.16	90	5.9832	0.8285
2014	7	29	23	52	18	0.3	1	0.18	91	5.9832	0.9666
2014	7	30	0	2	18	0.3	1	0.15	88.8	5.9832	0.794
2014	7	30	0	12	18	0.3	1	0.24	68.3	6.0025	1.1778
2014	7	30	0	22	18	0.3	1	0.12	56.3	6.0025	0.5196
2014	7	30	0	32	18	0.3	1	0.15	95	6.0025	0.7967
2014	7	30	0	42	18	0.3	1	0.24	81.4	6.0219	1.2688
2014	7	30	0	52	18	0.3	1	0.23	74.6	6.0219	1.1993
2014	7	30	1	2	18	0.3	1	0.22	68.4	6.0219	1.095
2014	7	30	1	12	18	0.3	1	0.25	89.2	6.0412	1.3081
2014	7	30	1	22	18	0.3	1	0.23	94.1	6.0606	1.2076
2014	7	30	1	32	18	0.3	1	0.17	104.3	6.08	0.8956

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	1	42	18	0.3	1	0.21	90.9	6.0993	1.1101
2014	7	30	1	52	18	0.3	1	0.22	93.4	6.1187	1.2023
2014	7	30	2	2	18	0.3	1	0.18	78.7	6.1187	0.9725
2014	7	30	2	12	18	0.3	1	0.17	85.6	6.138	0.9226
2014	7	30	2	22	18	0.3	1	0.17	98	6.138	0.8871
2014	7	30	2	32	18	0.3	1	0.24	84.4	6.1574	1.2817
2014	7	30	2	42	18	0.3	1	0.19	73.8	6.1574	0.9791
2014	7	30	2	52	18	0.3	1	0.22	88.3	6.1574	1.2105
2014	7	30	3	2	18	0.3	1	0.21	71.3	6.1767	1.1075
2014	7	30	3	12	18	0.3	1	0.35	81.3	6.1767	1.8577
2014	7	30	3	22	18	0.3	1	0.17	98	6.1767	0.8931
2014	7	30	3	32	18	0.3	1	0.26	82.1	6.1767	1.4111
2014	7	30	3	42	18	0.3	1	0.3	84.4	6.1961	1.6489
2014	7	30	3	52	18	0.3	1	0.25	93.8	6.1961	1.3621
2014	7	30	4	2	18	0.3	1	0.28	84.7	6.1961	1.5413
2014	7	30	4	12	18	0.3	1	0.24	74.3	6.1961	1.2725
2014	7	30	4	22	18	0.3	1	0.22	92.6	6.1961	1.1829
2014	7	30	4	32	18	0.3	1	0.22	104.7	6.2154	1.1689
2014	7	30	4	42	18	0.3	1	0.24	85.4	6.2154	1.3307
2014	7	30	4	52	18	0.3	1	0.25	101.5	6.2154	1.3307
2014	7	30	5	2	18	0.3	1	0.26	90	6.2348	1.4254
2014	7	30	5	12	18	0.3	1	0.2	79.8	6.2348	1.1006
2014	7	30	5	22	18	0.3	1	0.22	87.4	6.2348	1.2089
2014	7	30	5	32	18	0.3	1	0.27	90.7	6.2348	1.4976
2014	7	30	5	42	18	0.3	1	0.22	77.8	6.2348	1.1728
2014	7	30	5	52	18	0.3	1	0.28	79.1	6.2348	1.4976
2014	7	30	6	2	18	0.3	1	0.22	65	6.2542	1.0862
2014	7	30	6	12	18	0.3	1	0.25	75.4	6.2542	1.3215
2014	7	30	6	22	18	0.3	1	0.22	88.3	6.2542	1.2129
2014	7	30	6	32	18	0.3	1	0.25	90	6.2542	1.3758
2014	7	30	6	42	18	0.3	1	0.28	84.6	6.2735	1.5439
2014	7	30	6	52	18	0.3	1	0.28	76.5	6.2735	1.5076
2014	7	30	7	2	18	0.3	1	0.26	70.9	6.2735	1.3623
2014	7	30	7	12	18	0.3	1	0.21	90	6.2735	1.1806
2014	7	30	7	22	18	0.3	1	0.29	89.3	6.2542	1.5931
2014	7	30	7	32	18	0.3	1	0.22	84.8	6.2735	1.1988
2014	7	30	7	42	18	0.3	1	0.19	91	6.2542	1.0681
2014	7	30	7	52	18	0.3	1	0.26	83.4	6.2735	1.4168
2014	7	30	8	2	18	0.3	1	0.23	76.6	6.2735	1.217
2014	7	30	8	12	18	0.3	1	0.21	99.2	6.2542	1.1224
2014	7	30	8	22	18	0.3	1	0.2	97.5	6.2542	1.1043
2014	7	30	8	32	18	0.3	1	0.18	85.9	6.2542	1.0138
2014	7	30	8	42	18	0.3	1	0.21	74.4	6.2542	1.1043
2014	7	30	8	52	18	0.3	1	0.24	90.8	6.2348	1.2991
2014	7	30	9	2	18	0.3	1	0.29	101.1	6.2348	1.5698
2014	7	30	9	12	18	0.3	1	0.11	73.1	6.2348	0.5954

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	9	22	18	0.3	1	0.22	73.2	6.2735	1.1443
2014	7	30	9	32	18	0.3	1	0.27	81.5	6.2348	1.4435
2014	7	30	9	42	18	0.3	1	0.29	90	6.2154	1.5645
2014	7	30	9	52	18	0.3	1	0.27	91.4	6.2154	1.4926
2014	7	30	10	2	18	0.3	1	0.24	82.1	6.2154	1.2948
2014	7	30	10	12	18	0.3	1	0.25	81.5	6.1961	1.3263
2014	7	30	10	22	18	0.3	1	0.2	76.4	6.1961	1.0395
2014	7	30	10	32	18	0.3	1	0.21	70.2	6.1961	1.0933
2014	7	30	10	42	18	0.3	1	0.28	83.2	6.1961	1.5055
2014	7	30	10	52	18	0.3	1	0.24	76.7	6.1961	1.2904
2014	7	30	11	2	18	0.3	1	0.24	73.5	6.1961	1.2725
2014	7	30	11	12	18	0.3	1	0.24	96.3	6.1961	1.2904
2014	7	30	11	22	18	0.3	1	0.32	81.8	6.1767	1.7327
2014	7	30	11	32	18	0.3	1	0.26	76.1	6.1767	1.3754
2014	7	30	11	42	18	0.3	1	0.16	99.3	6.1767	0.8753
2014	7	30	11	52	18	0.3	1	0.2	61.3	6.1767	0.9467
2014	7	30	12	2	18	0.3	1	0.18	79.5	6.1767	0.9646
2014	7	30	12	12	18	0.3	1	0.28	72	6.1574	1.4242
2014	7	30	12	22	18	0.3	1	0.28	79.9	6.1574	1.4954
2014	7	30	12	32	18	0.3	1	0.29	59.9	6.1574	1.353
2014	7	30	12	42	18	0.3	1	0.22	82.1	6.1574	1.1572
2014	7	30	12	52	18	0.3	1	0.27	75.3	6.1574	1.4242
2014	7	30	13	2	18	0.3	1	0.21	72.7	6.1574	1.086
2014	7	30	13	12	18	0.3	1	0.24	67.9	6.1574	1.2284
2014	7	30	13	22	18	0.3	1	0.35	65.4	6.1574	1.7091
2014	7	30	13	32	18	0.3	1	0.19	41.6	6.08	0.6849
2014	7	30	13	42	18	0.3	1	0.39	44.3	6.138	1.4904
2014	7	30	13	52	18	0.3	1	0.33	53.8	6.1574	1.4598
2014	7	30	14	2	18	0.3	1	0.41	41.1	6.1574	1.4598
2014	7	30	14	12	18	0.3	1	0.38	52.7	6.1574	1.6378
2014	7	30	14	22	18	0.3	1	0.38	50.2	6.1574	1.6022
2014	7	30	14	32	18	0.3	1	0.32	49.2	6.1574	1.2996
2014	7	30	14	42	18	0.3	1	0.3	43.7	6.138	1.1178
2014	7	30	14	52	18	0.3	1	0.43	51.9	6.1574	1.8159
2014	7	30	15	2	18	0.3	1	0.4	42.7	6.1574	1.4776
2014	7	30	15	12	18	0.3	1	0.4	45	6.1767	1.5362
2014	7	30	15	22	18	0.3	1	0.32	50	6.1767	1.3397
2014	7	30	15	32	18	0.3	1	0.37	54.5	6.1961	1.631
2014	7	30	15	42	18	0.3	1	0.37	47.1	6.1961	1.4876
2014	7	30	15	52	18	0.3	1	0.43	51.9	6.1961	1.8282
2014	7	30	16	2	18	0.3	1	0.46	59.4	6.2154	2.158
2014	7	30	16	12	18	0.3	1	0.37	54.8	6.2542	1.6655
2014	7	30	16	22	18	0.3	1	0.36	49.1	6.2542	1.4845
2014	7	30	16	32	18	0.3	1	0.41	50.1	6.2542	1.7561
2014	7	30	16	42	18	0.3	1	0.46	43.6	6.2735	1.7619
2014	7	30	16	52	18	0.3	1	0.55	45.7	6.2735	2.1615

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	17	2	18	0.3	1	0.46	46.1	6.2735	1.8527
2014	7	30	17	12	18	0.3	1	0.44	55.1	6.2735	1.9799
2014	7	30	17	22	18	0.3	1	0.51	45	6.2735	1.9799
2014	7	30	17	32	18	0.3	1	0.46	43	6.2735	1.7256
2014	7	30	17	42	18	0.3	1	0.51	41.4	6.2735	1.8709
2014	7	30	17	52	18	0.3	1	0.45	45.9	6.2735	1.7982
2014	7	30	18	2	18	0.3	1	0.49	43.4	6.2735	1.8709
2014	7	30	18	12	18	0.3	1	0.46	42.1	6.2735	1.6893
2014	7	30	18	22	18	0.3	1	0.49	47.7	6.2735	1.998
2014	7	30	18	32	18	0.3	1	0.54	39.1	6.2735	1.8891
2014	7	30	18	42	18	0.3	1	0.5	45	6.2735	1.9617
2014	7	30	18	52	18	0.3	1	0.56	42.6	6.2735	2.0889
2014	7	30	19	2	18	0.3	1	0.48	51.2	6.2735	2.0525
2014	7	30	19	12	18	0.3	1	0.5	41.8	6.2735	1.8527
2014	7	30	19	22	18	0.3	1	0.46	43.6	6.2735	1.7619
2014	7	30	19	32	18	0.3	1	0.44	48.6	6.2735	1.8346
2014	7	30	19	42	18	0.3	1	0.47	45.8	6.2735	1.8709
2014	7	30	19	52	18	0.3	1	0.44	54.8	6.2735	1.9799
2014	7	30	20	2	18	0.3	1	0.48	42.5	6.2735	1.7801
2014	7	30	20	12	18	0.3	1	0.46	54.8	6.2735	2.0889
2014	7	30	20	22	18	0.3	1	0.41	55.2	6.2929	1.8589
2014	7	30	20	32	18	0.3	1	0.4	54.1	6.2929	1.786
2014	7	30	20	42	18	0.3	1	0.41	52.2	6.2735	1.7801
2014	7	30	20	52	18	0.3	1	0.45	52.4	6.2735	1.9799
2014	7	30	21	2	18	0.3	1	0.45	45.9	6.2929	1.786
2014	7	30	21	12	18	0.3	1	0.3	61.7	6.2929	1.4579
2014	7	30	21	22	18	0.3	1	0.35	77.4	6.2929	1.8771
2014	7	30	21	32	18	0.3	1	0.33	76.1	6.2929	1.7678
2014	7	30	21	42	18	0.3	1	0.31	60.4	6.2929	1.4762
2014	7	30	21	52	18	0.3	1	0.3	72.2	6.2929	1.5855
2014	7	30	22	2	18	0.3	1	0.3	78.8	6.2929	1.6584
2014	7	30	22	12	18	0.3	1	0.29	73.8	6.3122	1.5725
2014	7	30	22	22	18	0.3	1	0.32	70.1	6.2929	1.6584
2014	7	30	22	32	18	0.3	1	0.3	74.6	6.2929	1.5855
2014	7	30	22	42	18	0.3	1	0.31	76.7	6.2929	1.6949
2014	7	30	22	52	18	0.3	1	0.31	67	6.2929	1.5855
2014	7	30	23	2	18	0.3	1	0.28	89.3	6.3122	1.5359
2014	7	30	23	12	18	0.3	1	0.26	90	6.3122	1.4628
2014	7	30	23	22	18	0.3	1	0.24	86	6.3122	1.3165
2014	7	30	23	32	18	0.3	1	0.29	76.4	6.3122	1.5908
2014	7	30	23	42	18	0.3	1	0.29	86.1	6.2929	1.622
2014	7	30	23	52	18	0.3	1	0.34	87.2	6.3122	1.8833
2014	7	31	0	2	18	0.3	1	0.32	83.5	6.3122	1.7553
2014	7	31	0	12	18	0.3	1	0.32	71.6	6.3122	1.7005
2014	7	31	0	22	18	0.3	1	0.28	89.3	6.3122	1.5359
2014	7	31	0	32	18	0.3	1	0.29	72.8	6.3122	1.5359

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	0	42	18	0.3	1	0.3	76.3	6.3122	1.6456
2014	7	31	0	52	18	0.3	1	0.21	81.9	6.3122	1.1519
2014	7	31	1	2	18	0.3	1	0.31	81.4	6.3122	1.7005
2014	7	31	1	12	18	0.3	1	0.28	76.6	6.3122	1.5359
2014	7	31	1	22	18	0.3	1	0.26	85	6.3122	1.4628
2014	7	31	1	32	18	0.3	1	0.25	96.8	6.3122	1.3897
2014	7	31	1	42	18	0.3	1	0.25	81.5	6.3122	1.3531
2014	7	31	1	52	18	0.3	1	0.31	83.9	6.3122	1.7188
2014	7	31	2	2	18	0.3	1	0.26	90	6.3122	1.4262
2014	7	31	2	12	18	0.3	1	0.27	75.8	6.3122	1.4445
2014	7	31	2	22	18	0.3	1	0.25	80.2	6.3122	1.3714
2014	7	31	2	32	18	0.3	1	0.28	77.1	6.3122	1.5177
2014	7	31	2	42	18	0.3	1	0.33	86.6	6.3122	1.8468
2014	7	31	2	52	18	0.3	1	0.27	77.2	6.2929	1.4398
2014	7	31	3	2	18	0.3	1	0.22	107.1	6.2929	1.1846
2014	7	31	3	12	18	0.3	1	0.25	78.7	6.3122	1.3714
2014	7	31	3	22	18	0.3	1	0.27	84.4	6.2929	1.4762
2014	7	31	3	32	18	0.3	1	0.32	82.3	6.2929	1.7496
2014	7	31	3	42	18	0.3	1	0.32	88.8	6.2929	1.7678
2014	7	31	3	52	18	0.3	1	0.25	99.1	6.2929	1.3669
2014	7	31	4	2	18	0.3	1	0.25	83.9	6.2929	1.3669
2014	7	31	4	12	18	0.3	1	0.23	87.5	6.2929	1.2758
2014	7	31	4	22	18	0.3	1	0.23	90	6.2929	1.294
2014	7	31	4	32	18	0.3	1	0.23	89.2	6.2929	1.2758
2014	7	31	4	42	18	0.3	1	0.28	90	6.2735	1.5622
2014	7	31	4	52	18	0.3	1	0.31	92.5	6.2735	1.6893
2014	7	31	5	2	18	0.3	1	0.24	91.6	6.2735	1.326
2014	7	31	5	12	18	0.3	1	0.3	83.7	6.2735	1.653
2014	7	31	5	22	18	0.3	1	0.28	83.2	6.2735	1.5259
2014	7	31	5	32	18	0.3	1	0.29	80.1	6.2542	1.557
2014	7	31	5	42	18	0.3	1	0.29	92.6	6.2542	1.5932
2014	7	31	5	52	18	0.3	1	0.33	76.9	6.2542	1.7924
2014	7	31	6	2	18	0.3	1	0.25	82.6	6.2348	1.3894
2014	7	31	6	12	18	0.3	1	0.31	85.7	6.2348	1.6782
2014	7	31	6	22	18	0.3	1	0.3	77.2	6.2348	1.5879
2014	7	31	6	32	18	0.3	1	0.21	96.2	6.2348	1.1549
2014	7	31	6	42	18	0.3	1	0.25	74.9	6.2348	1.3353
2014	7	31	6	52	18	0.3	1	0.31	90.6	6.2154	1.6905
2014	7	31	7	2	18	0.3	1	0.34	81.7	6.2154	1.8524
2014	7	31	7	12	18	0.3	1	0.22	76	6.2154	1.151
2014	7	31	7	22	18	0.3	1	0.22	94.2	6.2154	1.2229
2014	7	31	7	32	18	0.3	1	0.28	100.1	6.2154	1.5107
2014	7	31	7	42	18	0.3	1	0.3	72.6	6.2154	1.5467
2014	7	31	7	52	18	0.3	1	0.26	86.4	6.1961	1.416
2014	7	31	8	2	18	0.3	1	0.24	95.5	6.2154	1.3129
2014	7	31	8	12	18	0.3	1	0.31	73.5	6.1961	1.6311

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	8	22	18	0.3	1	0.23	81.8	6.1961	1.2368
2014	7	31	8	32	18	0.3	1	0.23	77.6	6.1961	1.2189
2014	7	31	8	42	18	0.3	1	0.25	89.2	6.1961	1.3443
2014	7	31	8	52	18	0.3	1	0.26	86.4	6.1961	1.4339
2014	7	31	9	2	18	0.3	1	0.27	80.8	6.1961	1.4339
2014	7	31	9	12	18	0.3	1	0.23	86.8	6.1961	1.2726
2014	7	31	9	22	18	0.3	1	0.29	87.4	6.1961	1.5773
2014	7	31	9	32	18	0.3	1	0.32	74.1	6.1961	1.7028
2014	7	31	9	42	18	0.3	1	0.25	87.8	6.1961	1.3801
2014	7	31	9	52	18	0.3	1	0.3	68.6	6.1961	1.5056
2014	7	31	10	2	18	0.3	1	0.3	67.4	6.1961	1.5056
2014	7	31	10	12	18	0.3	1	0.34	66.9	6.1961	1.6848
2014	7	31	10	22	18	0.3	1	0.26	73	6.1767	1.3398
2014	7	31	10	32	18	0.3	1	0.24	78.2	6.1961	1.2905
2014	7	31	10	42	18	0.3	1	0.28	80.4	6.1767	1.4827
2014	7	31	10	52	18	0.3	1	0.28	68.2	6.1767	1.4291
2014	7	31	11	2	18	0.3	1	0.31	62.9	6.1767	1.5005
2014	7	31	11	12	18	0.3	1	0.28	74.1	6.1767	1.4469
2014	7	31	11	22	18	0.3	1	0.33	63.7	6.1767	1.6256
2014	7	31	11	32	18	0.3	1	0.27	52.3	6.1767	1.179
2014	7	31	11	42	18	0.3	1	0.32	76.5	6.1767	1.7149
2014	7	31	11	52	18	0.3	1	0.21	71	6.1767	1.0897
2014	7	31	12	2	18	0.3	1	0.22	86.5	6.1961	1.1829
2014	7	31	12	12	18	0.3	1	0.26	78.4	6.1961	1.398
2014	7	31	12	22	18	0.3	1	0.28	79.1	6.1961	1.4876
2014	7	31	12	32	18	0.3	1	0.19	80	6.2154	1.025
2014	7	31	12	42	18	0.3	1	0.27	75.5	6.2154	1.4566
2014	7	31	12	52	18	0.3	1	0.32	82.9	6.2154	1.7443
2014	7	31	13	2	18	0.3	1	0.35	68.3	6.2348	1.7682
2014	7	31	13	12	18	0.3	1	0.28	67.6	6.2542	1.4482
2014	7	31	13	22	18	0.3	1	0.33	69.8	6.2929	1.7312
2014	7	31	13	32	18	0.3	1	0.35	81.5	6.3122	1.9563
2014	7	31	13	42	18	0.3	1	0.33	77.9	6.3316	1.7976
2014	7	31	13	52	18	0.3	1	0.31	67.5	6.3509	1.6011
2014	7	31	14	2	18	0.3	1	0.33	64.4	6.3509	1.6931
2014	7	31	14	12	18	0.3	1	0.39	78.9	6.3703	2.1602
2014	7	31	14	22	18	0.3	1	0.4	75.6	6.3897	2.1673
2014	7	31	14	32	18	0.3	1	0.35	74.8	6.3897	1.9079
2014	7	31	14	42	18	0.3	1	0.36	77.5	6.409	2.007
2014	7	31	14	52	18	0.3	1	0.41	68.6	6.409	2.1371
2014	7	31	15	2	18	0.3	1	0.37	78.7	6.4284	2.0508
2014	7	31	15	12	18	0.3	1	0.4	68.3	6.4284	2.1067
2014	7	31	15	22	18	0.3	1	0.4	70.1	6.4284	2.1627
2014	7	31	15	32	18	0.3	1	0.32	71.9	6.4477	1.7208
2014	7	31	15	42	18	0.3	1	0.33	81.4	6.4477	1.8517
2014	7	31	15	52	18	0.3	1	0.45	63.6	6.4477	2.3006

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	16	2	18	0.3	1	0.35	68.2	6.4477	1.8704
2014	7	31	16	12	18	0.3	1	0.34	73.5	6.4671	1.8389
2014	7	31	16	22	18	0.3	1	0.33	62.7	6.4671	1.67
2014	7	31	16	32	18	0.3	1	0.4	75.9	6.4671	2.2329
2014	7	31	16	42	18	0.3	1	0.38	66.5	6.4671	1.989
2014	7	31	16	52	18	0.3	1	0.39	87.1	6.4671	2.2142
2014	7	31	17	2	18	0.3	1	0.43	72.3	6.4864	2.3531
2014	7	31	17	12	18	0.3	1	0.42	61.8	6.4864	2.146
2014	7	31	17	22	18	0.3	1	0.45	70.8	6.4864	2.4283
2014	7	31	17	32	18	0.3	1	0.37	73	6.4864	2.033
2014	7	31	17	42	18	0.3	1	0.35	71.6	6.4864	1.9201
2014	7	31	17	52	18	0.3	1	0.36	71.2	6.4864	1.9389
2014	7	31	18	2	18	0.3	1	0.42	60	6.4864	2.0895
2014	7	31	18	12	18	0.3	1	0.4	71.1	6.4864	2.146
2014	7	31	18	22	18	0.3	1	0.41	72.6	6.4864	2.2213
2014	7	31	18	32	18	0.3	1	0.38	81.6	6.5058	2.1718
2014	7	31	18	42	18	0.3	1	0.45	77.9	6.5058	2.5495
2014	7	31	18	52	18	0.3	1	0.36	74.3	6.5058	2.0207
2014	7	31	19	2	18	0.3	1	0.45	81.6	6.5058	2.5495
2014	7	31	19	12	18	0.3	1	0.32	80	6.5058	1.813
2014	7	31	19	22	18	0.3	1	0.35	80.9	6.5058	2.0018
2014	7	31	19	32	18	0.3	1	0.47	79.5	6.5058	2.6439
2014	7	31	19	42	18	0.3	1	0.38	78.4	6.5058	2.1151
2014	7	31	19	52	18	0.3	1	0.37	78.7	6.5058	2.0773
2014	7	31	20	2	18	0.3	1	0.33	78.7	6.5252	1.8945
2014	7	31	20	12	18	0.3	1	0.32	78.1	6.5252	1.7998
2014	7	31	20	22	18	0.3	1	0.34	88.9	6.5445	1.9956
2014	7	31	20	32	18	0.3	1	0.37	84.4	6.5445	2.1476
2014	7	31	20	42	18	0.3	1	0.4	85.2	6.5639	2.2879
2014	7	31	20	52	18	0.3	1	0.38	86.6	6.5639	2.2307
2014	7	31	21	2	18	0.3	1	0.37	82.4	6.5639	2.1354
2014	7	31	21	12	18	0.3	1	0.4	79.6	6.5639	2.2879
2014	7	31	21	22	18	0.3	1	0.4	83.5	6.5832	2.3334
2014	7	31	21	32	18	0.3	1	0.4	88.6	6.5832	2.3143
2014	7	31	21	42	18	0.3	1	0.34	92.2	6.5832	2.0083
2014	7	31	21	52	18	0.3	1	0.35	75.4	6.6026	1.9954
2014	7	31	22	2	18	0.3	1	0.35	92.7	6.6026	2.053
2014	7	31	22	12	18	0.3	1	0.38	89	6.6026	2.2065
2014	7	31	22	22	18	0.3	1	0.38	86.1	6.6026	2.2257
2014	7	31	22	32	18	0.3	1	0.34	81.8	6.6026	1.9954
2014	7	31	22	42	18	0.3	1	0.33	94	6.6026	1.8995
2014	7	31	22	52	18	0.3	1	0.4	90	6.6026	2.3216
2014	7	31	23	2	18	0.3	1	0.33	80.3	6.6026	1.8995
2014	7	31	23	12	18	0.3	1	0.38	90	6.6026	2.2065
2014	7	31	23	22	18	0.3	1	0.31	90	6.6026	1.842
2014	7	31	23	32	18	0.3	1	0.31	76.1	6.6219	1.79

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	23	42	18	0.3	1	0.33	92.3	6.6219	1.9055
2014	7	31	23	52	18	0.3	1	0.38	86	6.6219	2.2135

Goose Lake Return
Station 0367

Date	Flow (cfs)
7/1/2014	0.92
7/2/2014	0.933
7/3/2014	0.951
7/4/2014	0.969
7/5/2014	0.992
7/6/2014	1.043
7/7/2014	1.135
7/8/2014	1.191
7/9/2014	1.152
7/10/2014	1.057
7/11/2014	0.957
7/12/2014	0.861
7/13/2014	0.839
7/14/2014	0.902
7/15/2014	0.941
7/16/2014	1.007
7/17/2014	1.048
7/18/2014	1.032
7/19/2014	0.979
7/20/2014	0.988
7/21/2014	1.029
7/22/2014	1.052
7/23/2014	1.024
7/24/2014	0.98
7/25/2014	0.963
7/26/2014	0.926
7/27/2014	0.927
7/28/2014	0.993
7/29/2014	1.09
7/30/2014	1.117
7/31/2014	1.16

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2014	12:00:00 AM	0.38
7/1/2014	12:15:00 AM	0.38
7/1/2014	12:30:00 AM	0.39
7/1/2014	12:45:00 AM	0.39
7/1/2014	1:00:00 AM	0.39
7/1/2014	1:15:00 AM	0.39
7/1/2014	1:30:00 AM	0.39
7/1/2014	1:45:00 AM	0.39
7/1/2014	2:00:00 AM	0.39
7/1/2014	2:15:00 AM	0.39
7/1/2014	2:30:00 AM	0.4
7/1/2014	2:45:00 AM	0.4
7/1/2014	3:00:00 AM	0.4
7/1/2014	3:15:00 AM	0.4
7/1/2014	3:30:00 AM	0.4
7/1/2014	3:45:00 AM	0.4
7/1/2014	4:00:00 AM	0.4
7/1/2014	4:15:00 AM	0.4
7/1/2014	4:30:00 AM	0.4
7/1/2014	4:45:00 AM	0.4
7/1/2014	5:00:00 AM	0.4
7/1/2014	5:15:00 AM	0.4
7/1/2014	5:30:00 AM	0.4
7/1/2014	5:45:00 AM	0.4
7/1/2014	6:00:00 AM	0.4
7/1/2014	6:15:00 AM	0.4
7/1/2014	6:30:00 AM	0.4
7/1/2014	6:45:00 AM	0.4
7/1/2014	7:00:00 AM	0.4
7/1/2014	7:15:00 AM	0.4
7/1/2014	7:30:00 AM	0.4
7/1/2014	7:45:00 AM	0.4
7/1/2014	8:00:00 AM	0.4
7/1/2014	8:15:00 AM	0.4
7/1/2014	8:30:00 AM	0.4
7/1/2014	8:45:00 AM	0.4
7/1/2014	9:00:00 AM	0.4
7/1/2014	9:15:00 AM	0.4
7/1/2014	9:30:00 AM	0.4
7/1/2014	9:45:00 AM	0.4
7/1/2014	10:00:00 AM	0.4
7/1/2014	10:15:00 AM	0.4
7/1/2014	10:30:00 AM	0.4
7/1/2014	10:45:00 AM	0.4
7/1/2014	11:00:00 AM	0.4
7/1/2014	11:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2014	11:30:00 AM	0.4
7/1/2014	11:45:00 AM	0.4
7/1/2014	12:00:00 PM	0.4
7/1/2014	12:15:00 PM	0.4
7/1/2014	12:30:00 PM	0.4
7/1/2014	12:45:00 PM	0.4
7/1/2014	1:00:00 PM	0.4
7/1/2014	1:15:00 PM	0.4
7/1/2014	1:30:00 PM	0.4
7/1/2014	1:45:00 PM	0.39
7/1/2014	2:00:00 PM	0.39
7/1/2014	2:15:00 PM	0.39
7/1/2014	2:30:00 PM	0.38
7/1/2014	2:45:00 PM	0.38
7/1/2014	3:00:00 PM	0.38
7/1/2014	3:15:00 PM	0.38
7/1/2014	3:30:00 PM	0.38
7/1/2014	3:45:00 PM	0.38
7/1/2014	4:00:00 PM	0.38
7/1/2014	4:15:00 PM	0.38
7/1/2014	4:30:00 PM	0.38
7/1/2014	4:45:00 PM	0.38
7/1/2014	5:00:00 PM	0.38
7/1/2014	5:15:00 PM	0.38
7/1/2014	5:30:00 PM	0.38
7/1/2014	5:45:00 PM	0.38
7/1/2014	6:00:00 PM	0.38
7/1/2014	6:15:00 PM	0.38
7/1/2014	6:30:00 PM	0.38
7/1/2014	6:45:00 PM	0.38
7/1/2014	7:00:00 PM	0.38
7/1/2014	7:15:00 PM	0.38
7/1/2014	7:30:00 PM	0.38
7/1/2014	7:45:00 PM	0.38
7/1/2014	8:00:00 PM	0.38
7/1/2014	8:15:00 PM	0.38
7/1/2014	8:30:00 PM	0.38
7/1/2014	8:45:00 PM	0.38
7/1/2014	9:00:00 PM	0.38
7/1/2014	9:15:00 PM	0.38
7/1/2014	9:30:00 PM	0.38
7/1/2014	9:45:00 PM	0.38
7/1/2014	10:00:00 PM	0.38
7/1/2014	10:15:00 PM	0.38
7/1/2014	10:30:00 PM	0.38
7/1/2014	10:45:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2014	11:00:00 PM	0.38
7/1/2014	11:15:00 PM	0.38
7/1/2014	11:30:00 PM	0.38
7/1/2014	11:45:00 PM	0.38
7/2/2014	12:00:00 AM	0.39
7/2/2014	12:15:00 AM	0.4
7/2/2014	12:30:00 AM	0.4
7/2/2014	12:45:00 AM	0.4
7/2/2014	1:00:00 AM	0.4
7/2/2014	1:15:00 AM	0.4
7/2/2014	1:30:00 AM	0.4
7/2/2014	1:45:00 AM	0.4
7/2/2014	2:00:00 AM	0.4
7/2/2014	2:15:00 AM	0.4
7/2/2014	2:30:00 AM	0.4
7/2/2014	2:45:00 AM	0.4
7/2/2014	3:00:00 AM	0.4
7/2/2014	3:15:00 AM	0.4
7/2/2014	3:30:00 AM	0.4
7/2/2014	3:45:00 AM	0.4
7/2/2014	4:00:00 AM	0.4
7/2/2014	4:15:00 AM	0.4
7/2/2014	4:30:00 AM	0.4
7/2/2014	4:45:00 AM	0.4
7/2/2014	5:00:00 AM	0.4
7/2/2014	5:15:00 AM	0.4
7/2/2014	5:30:00 AM	0.4
7/2/2014	5:45:00 AM	0.4
7/2/2014	6:00:00 AM	0.4
7/2/2014	6:15:00 AM	0.4
7/2/2014	6:30:00 AM	0.4
7/2/2014	6:45:00 AM	0.4
7/2/2014	7:00:00 AM	0.4
7/2/2014	7:15:00 AM	0.4
7/2/2014	7:30:00 AM	0.4
7/2/2014	7:45:00 AM	0.4
7/2/2014	8:00:00 AM	0.4
7/2/2014	8:15:00 AM	0.4
7/2/2014	8:30:00 AM	0.4
7/2/2014	8:45:00 AM	0.4
7/2/2014	9:00:00 AM	0.41
7/2/2014	9:15:00 AM	0.41
7/2/2014	9:30:00 AM	0.41
7/2/2014	9:45:00 AM	0.41
7/2/2014	10:00:00 AM	0.41
7/2/2014	10:15:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/2/2014	10:30:00 AM	0.41
7/2/2014	10:45:00 AM	0.4
7/2/2014	11:00:00 AM	0.41
7/2/2014	11:15:00 AM	0.41
7/2/2014	11:30:00 AM	0.41
7/2/2014	11:45:00 AM	0.4
7/2/2014	12:00:00 PM	0.4
7/2/2014	12:15:00 PM	0.4
7/2/2014	12:30:00 PM	0.4
7/2/2014	12:45:00 PM	0.4
7/2/2014	1:00:00 PM	0.4
7/2/2014	1:15:00 PM	0.4
7/2/2014	1:30:00 PM	0.4
7/2/2014	1:45:00 PM	0.4
7/2/2014	2:00:00 PM	0.4
7/2/2014	2:15:00 PM	0.39
7/2/2014	2:30:00 PM	0.39
7/2/2014	2:45:00 PM	0.39
7/2/2014	3:00:00 PM	0.39
7/2/2014	3:15:00 PM	0.39
7/2/2014	3:30:00 PM	0.38
7/2/2014	3:45:00 PM	0.38
7/2/2014	4:00:00 PM	0.38
7/2/2014	4:15:00 PM	0.38
7/2/2014	4:30:00 PM	0.38
7/2/2014	4:45:00 PM	0.38
7/2/2014	5:00:00 PM	0.38
7/2/2014	5:15:00 PM	0.38
7/2/2014	5:30:00 PM	0.38
7/2/2014	5:45:00 PM	0.38
7/2/2014	6:00:00 PM	0.38
7/2/2014	6:15:00 PM	0.38
7/2/2014	6:30:00 PM	0.38
7/2/2014	6:45:00 PM	0.38
7/2/2014	7:00:00 PM	0.38
7/2/2014	7:15:00 PM	0.38
7/2/2014	7:30:00 PM	0.38
7/2/2014	7:45:00 PM	0.38
7/2/2014	8:00:00 PM	0.38
7/2/2014	8:15:00 PM	0.38
7/2/2014	8:30:00 PM	0.38
7/2/2014	8:45:00 PM	0.38
7/2/2014	9:00:00 PM	0.38
7/2/2014	9:15:00 PM	0.38
7/2/2014	9:30:00 PM	0.38
7/2/2014	9:45:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/2/2014	10:00:00 PM	0.38
7/2/2014	10:15:00 PM	0.38
7/2/2014	10:30:00 PM	0.39
7/2/2014	10:45:00 PM	0.39
7/2/2014	11:00:00 PM	0.39
7/2/2014	11:15:00 PM	0.39
7/2/2014	11:30:00 PM	0.39
7/2/2014	11:45:00 PM	0.39
7/3/2014	12:00:00 AM	0.39
7/3/2014	12:15:00 AM	0.39
7/3/2014	12:30:00 AM	0.39
7/3/2014	12:45:00 AM	0.4
7/3/2014	1:00:00 AM	0.4
7/3/2014	1:15:00 AM	0.4
7/3/2014	1:30:00 AM	0.4
7/3/2014	1:45:00 AM	0.4
7/3/2014	2:00:00 AM	0.4
7/3/2014	2:15:00 AM	0.4
7/3/2014	2:30:00 AM	0.4
7/3/2014	2:45:00 AM	0.4
7/3/2014	3:00:00 AM	0.4
7/3/2014	3:15:00 AM	0.4
7/3/2014	3:30:00 AM	0.4
7/3/2014	3:45:00 AM	0.4
7/3/2014	4:00:00 AM	0.4
7/3/2014	4:15:00 AM	0.4
7/3/2014	4:30:00 AM	0.4
7/3/2014	4:45:00 AM	0.4
7/3/2014	5:00:00 AM	0.4
7/3/2014	5:15:00 AM	0.4
7/3/2014	5:30:00 AM	0.4
7/3/2014	5:45:00 AM	0.4
7/3/2014	6:00:00 AM	0.41
7/3/2014	6:15:00 AM	0.41
7/3/2014	6:30:00 AM	0.41
7/3/2014	6:45:00 AM	0.41
7/3/2014	7:00:00 AM	0.41
7/3/2014	7:15:00 AM	0.41
7/3/2014	7:30:00 AM	0.41
7/3/2014	7:45:00 AM	0.41
7/3/2014	8:00:00 AM	0.41
7/3/2014	8:15:00 AM	0.41
7/3/2014	8:30:00 AM	0.42
7/3/2014	8:45:00 AM	0.42
7/3/2014	9:00:00 AM	0.42
7/3/2014	9:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/3/2014	9:30:00 AM	0.42
7/3/2014	9:45:00 AM	0.42
7/3/2014	10:00:00 AM	0.42
7/3/2014	10:15:00 AM	0.42
7/3/2014	10:30:00 AM	0.42
7/3/2014	10:45:00 AM	0.42
7/3/2014	11:00:00 AM	0.41
7/3/2014	11:15:00 AM	0.41
7/3/2014	11:30:00 AM	0.41
7/3/2014	11:45:00 AM	0.41
7/3/2014	12:00:00 PM	0.4
7/3/2014	12:15:00 PM	0.4
7/3/2014	12:30:00 PM	0.4
7/3/2014	12:45:00 PM	0.4
7/3/2014	1:00:00 PM	0.4
7/3/2014	1:15:00 PM	0.4
7/3/2014	1:30:00 PM	0.4
7/3/2014	1:45:00 PM	0.4
7/3/2014	2:00:00 PM	0.4
7/3/2014	2:15:00 PM	0.4
7/3/2014	2:30:00 PM	0.4
7/3/2014	2:45:00 PM	0.4
7/3/2014	3:00:00 PM	0.4
7/3/2014	3:15:00 PM	0.39
7/3/2014	3:30:00 PM	0.39
7/3/2014	3:45:00 PM	0.39
7/3/2014	4:00:00 PM	0.39
7/3/2014	4:15:00 PM	0.39
7/3/2014	4:30:00 PM	0.38
7/3/2014	4:45:00 PM	0.38
7/3/2014	5:00:00 PM	0.38
7/3/2014	5:15:00 PM	0.38
7/3/2014	5:30:00 PM	0.39
7/3/2014	5:45:00 PM	0.39
7/3/2014	6:00:00 PM	0.38
7/3/2014	6:15:00 PM	0.38
7/3/2014	6:30:00 PM	0.38
7/3/2014	6:45:00 PM	0.38
7/3/2014	7:00:00 PM	0.38
7/3/2014	7:15:00 PM	0.39
7/3/2014	7:30:00 PM	0.39
7/3/2014	7:45:00 PM	0.38
7/3/2014	8:00:00 PM	0.38
7/3/2014	8:15:00 PM	0.38
7/3/2014	8:30:00 PM	0.38
7/3/2014	8:45:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
7/3/2014	9:00:00 PM	0.39
7/3/2014	9:15:00 PM	0.39
7/3/2014	9:30:00 PM	0.39
7/3/2014	9:45:00 PM	0.39
7/3/2014	10:00:00 PM	0.39
7/3/2014	10:15:00 PM	0.39
7/3/2014	10:30:00 PM	0.4
7/3/2014	10:45:00 PM	0.4
7/3/2014	11:00:00 PM	0.4
7/3/2014	11:15:00 PM	0.4
7/3/2014	11:30:00 PM	0.4
7/3/2014	11:45:00 PM	0.4
7/4/2014	12:00:00 AM	0.4
7/4/2014	12:15:00 AM	0.4
7/4/2014	12:30:00 AM	0.4
7/4/2014	12:45:00 AM	0.4
7/4/2014	1:00:00 AM	0.4
7/4/2014	1:15:00 AM	0.4
7/4/2014	1:30:00 AM	0.4
7/4/2014	1:45:00 AM	0.4
7/4/2014	2:00:00 AM	0.4
7/4/2014	2:15:00 AM	0.4
7/4/2014	2:30:00 AM	0.4
7/4/2014	2:45:00 AM	0.4
7/4/2014	3:00:00 AM	0.4
7/4/2014	3:15:00 AM	0.4
7/4/2014	3:30:00 AM	0.4
7/4/2014	3:45:00 AM	0.4
7/4/2014	4:00:00 AM	0.4
7/4/2014	4:15:00 AM	0.4
7/4/2014	4:30:00 AM	0.41
7/4/2014	4:45:00 AM	0.41
7/4/2014	5:00:00 AM	0.41
7/4/2014	5:15:00 AM	0.41
7/4/2014	5:30:00 AM	0.42
7/4/2014	5:45:00 AM	0.42
7/4/2014	6:00:00 AM	0.42
7/4/2014	6:15:00 AM	0.42
7/4/2014	6:30:00 AM	0.42
7/4/2014	6:45:00 AM	0.42
7/4/2014	7:00:00 AM	0.42
7/4/2014	7:15:00 AM	0.42
7/4/2014	7:30:00 AM	0.42
7/4/2014	7:45:00 AM	0.42
7/4/2014	8:00:00 AM	0.42
7/4/2014	8:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/4/2014	8:30:00 AM	0.42
7/4/2014	8:45:00 AM	0.42
7/4/2014	9:00:00 AM	0.42
7/4/2014	9:15:00 AM	0.42
7/4/2014	9:30:00 AM	0.42
7/4/2014	9:45:00 AM	0.42
7/4/2014	10:00:00 AM	0.42
7/4/2014	10:15:00 AM	0.42
7/4/2014	10:30:00 AM	0.42
7/4/2014	10:45:00 AM	0.42
7/4/2014	11:00:00 AM	0.42
7/4/2014	11:15:00 AM	0.42
7/4/2014	11:30:00 AM	0.42
7/4/2014	11:45:00 AM	0.41
7/4/2014	12:00:00 PM	0.41
7/4/2014	12:15:00 PM	0.41
7/4/2014	12:30:00 PM	0.4
7/4/2014	12:45:00 PM	0.4
7/4/2014	1:00:00 PM	0.4
7/4/2014	1:15:00 PM	0.4
7/4/2014	1:30:00 PM	0.4
7/4/2014	1:45:00 PM	0.4
7/4/2014	2:00:00 PM	0.4
7/4/2014	2:15:00 PM	0.4
7/4/2014	2:30:00 PM	0.4
7/4/2014	2:45:00 PM	0.4
7/4/2014	3:00:00 PM	0.4
7/4/2014	3:15:00 PM	0.4
7/4/2014	3:30:00 PM	0.4
7/4/2014	3:45:00 PM	0.4
7/4/2014	4:00:00 PM	0.4
7/4/2014	4:15:00 PM	0.4
7/4/2014	4:30:00 PM	0.4
7/4/2014	4:45:00 PM	0.4
7/4/2014	5:00:00 PM	0.39
7/4/2014	5:15:00 PM	0.39
7/4/2014	5:30:00 PM	0.39
7/4/2014	5:45:00 PM	0.39
7/4/2014	6:00:00 PM	0.39
7/4/2014	6:15:00 PM	0.39
7/4/2014	6:30:00 PM	0.38
7/4/2014	6:45:00 PM	0.39
7/4/2014	7:00:00 PM	0.38
7/4/2014	7:15:00 PM	0.39
7/4/2014	7:30:00 PM	0.39
7/4/2014	7:45:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
7/4/2014	8:00:00 PM	0.39
7/4/2014	8:15:00 PM	0.39
7/4/2014	8:30:00 PM	0.39
7/4/2014	8:45:00 PM	0.39
7/4/2014	9:00:00 PM	0.39
7/4/2014	9:15:00 PM	0.39
7/4/2014	9:30:00 PM	0.4
7/4/2014	9:45:00 PM	0.4
7/4/2014	10:00:00 PM	0.4
7/4/2014	10:15:00 PM	0.4
7/4/2014	10:30:00 PM	0.4
7/4/2014	10:45:00 PM	0.4
7/4/2014	11:00:00 PM	0.4
7/4/2014	11:15:00 PM	0.4
7/4/2014	11:30:00 PM	0.4
7/4/2014	11:45:00 PM	0.4
7/5/2014	12:00:00 AM	0.4
7/5/2014	12:15:00 AM	0.4
7/5/2014	12:30:00 AM	0.4
7/5/2014	12:45:00 AM	0.4
7/5/2014	1:00:00 AM	0.41
7/5/2014	1:15:00 AM	0.41
7/5/2014	1:30:00 AM	0.41
7/5/2014	1:45:00 AM	0.41
7/5/2014	2:00:00 AM	0.41
7/5/2014	2:15:00 AM	0.41
7/5/2014	2:30:00 AM	0.41
7/5/2014	2:45:00 AM	0.41
7/5/2014	3:00:00 AM	0.41
7/5/2014	3:15:00 AM	0.41
7/5/2014	3:30:00 AM	0.41
7/5/2014	3:45:00 AM	0.41
7/5/2014	4:00:00 AM	0.41
7/5/2014	4:15:00 AM	0.41
7/5/2014	4:30:00 AM	0.42
7/5/2014	4:45:00 AM	0.42
7/5/2014	5:00:00 AM	0.42
7/5/2014	5:15:00 AM	0.42
7/5/2014	5:30:00 AM	0.42
7/5/2014	5:45:00 AM	0.42
7/5/2014	6:00:00 AM	0.42
7/5/2014	6:15:00 AM	0.42
7/5/2014	6:30:00 AM	0.42
7/5/2014	6:45:00 AM	0.42
7/5/2014	7:00:00 AM	0.42
7/5/2014	7:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/5/2014	7:30:00 AM	0.42
7/5/2014	7:45:00 AM	0.42
7/5/2014	8:00:00 AM	0.42
7/5/2014	8:15:00 AM	0.42
7/5/2014	8:30:00 AM	0.42
7/5/2014	8:45:00 AM	0.42
7/5/2014	9:00:00 AM	0.42
7/5/2014	9:15:00 AM	0.42
7/5/2014	9:30:00 AM	0.42
7/5/2014	9:45:00 AM	0.42
7/5/2014	10:00:00 AM	0.42
7/5/2014	10:15:00 AM	0.42
7/5/2014	10:30:00 AM	0.42
7/5/2014	10:45:00 AM	0.42
7/5/2014	11:00:00 AM	0.42
7/5/2014	11:15:00 AM	0.42
7/5/2014	11:30:00 AM	0.42
7/5/2014	11:45:00 AM	0.42
7/5/2014	12:00:00 PM	0.42
7/5/2014	12:15:00 PM	0.42
7/5/2014	12:30:00 PM	0.42
7/5/2014	12:45:00 PM	0.42
7/5/2014	1:00:00 PM	0.42
7/5/2014	1:15:00 PM	0.42
7/5/2014	1:30:00 PM	0.41
7/5/2014	1:45:00 PM	0.41
7/5/2014	2:00:00 PM	0.41
7/5/2014	2:15:00 PM	0.41
7/5/2014	2:30:00 PM	0.41
7/5/2014	2:45:00 PM	0.41
7/5/2014	3:00:00 PM	0.41
7/5/2014	3:15:00 PM	0.4
7/5/2014	3:30:00 PM	0.4
7/5/2014	3:45:00 PM	0.4
7/5/2014	4:00:00 PM	0.4
7/5/2014	4:15:00 PM	0.4
7/5/2014	4:30:00 PM	0.4
7/5/2014	4:45:00 PM	0.4
7/5/2014	5:00:00 PM	0.4
7/5/2014	5:15:00 PM	0.4
7/5/2014	5:30:00 PM	0.4
7/5/2014	5:45:00 PM	0.4
7/5/2014	6:00:00 PM	0.4
7/5/2014	6:15:00 PM	0.4
7/5/2014	6:30:00 PM	0.4
7/5/2014	6:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/5/2014	7:00:00 PM	0.4
7/5/2014	7:15:00 PM	0.4
7/5/2014	7:30:00 PM	0.4
7/5/2014	7:45:00 PM	0.4
7/5/2014	8:00:00 PM	0.4
7/5/2014	8:15:00 PM	0.4
7/5/2014	8:30:00 PM	0.4
7/5/2014	8:45:00 PM	0.4
7/5/2014	9:00:00 PM	0.4
7/5/2014	9:15:00 PM	0.4
7/5/2014	9:30:00 PM	0.4
7/5/2014	9:45:00 PM	0.4
7/5/2014	10:00:00 PM	0.4
7/5/2014	10:15:00 PM	0.4
7/5/2014	10:30:00 PM	0.4
7/5/2014	10:45:00 PM	0.4
7/5/2014	11:00:00 PM	0.4
7/5/2014	11:15:00 PM	0.4
7/5/2014	11:30:00 PM	0.41
7/5/2014	11:45:00 PM	0.41
7/6/2014	12:00:00 AM	0.41
7/6/2014	12:15:00 AM	0.41
7/6/2014	12:30:00 AM	0.42
7/6/2014	12:45:00 AM	0.42
7/6/2014	1:00:00 AM	0.42
7/6/2014	1:15:00 AM	0.42
7/6/2014	1:30:00 AM	0.42
7/6/2014	1:45:00 AM	0.42
7/6/2014	2:00:00 AM	0.42
7/6/2014	2:15:00 AM	0.42
7/6/2014	2:30:00 AM	0.42
7/6/2014	2:45:00 AM	0.42
7/6/2014	3:00:00 AM	0.42
7/6/2014	3:15:00 AM	0.42
7/6/2014	3:30:00 AM	0.42
7/6/2014	3:45:00 AM	0.42
7/6/2014	4:00:00 AM	0.42
7/6/2014	4:15:00 AM	0.42
7/6/2014	4:30:00 AM	0.42
7/6/2014	4:45:00 AM	0.42
7/6/2014	5:00:00 AM	0.42
7/6/2014	5:15:00 AM	0.42
7/6/2014	5:30:00 AM	0.42
7/6/2014	5:45:00 AM	0.42
7/6/2014	6:00:00 AM	0.42
7/6/2014	6:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/6/2014	6:30:00 AM	0.42
7/6/2014	6:45:00 AM	0.42
7/6/2014	7:00:00 AM	0.42
7/6/2014	7:15:00 AM	0.42
7/6/2014	7:30:00 AM	0.43
7/6/2014	7:45:00 AM	0.43
7/6/2014	8:00:00 AM	0.43
7/6/2014	8:15:00 AM	0.43
7/6/2014	8:30:00 AM	0.43
7/6/2014	8:45:00 AM	0.43
7/6/2014	9:00:00 AM	0.43
7/6/2014	9:15:00 AM	0.43
7/6/2014	9:30:00 AM	0.43
7/6/2014	9:45:00 AM	0.43
7/6/2014	10:00:00 AM	0.43
7/6/2014	10:15:00 AM	0.43
7/6/2014	10:30:00 AM	0.43
7/6/2014	10:45:00 AM	0.43
7/6/2014	11:00:00 AM	0.43
7/6/2014	11:15:00 AM	0.43
7/6/2014	11:30:00 AM	0.43
7/6/2014	11:45:00 AM	0.43
7/6/2014	12:00:00 PM	0.43
7/6/2014	12:15:00 PM	0.43
7/6/2014	12:30:00 PM	0.44
7/6/2014	12:45:00 PM	0.43
7/6/2014	1:00:00 PM	0.43
7/6/2014	1:15:00 PM	0.43
7/6/2014	1:30:00 PM	0.42
7/6/2014	1:45:00 PM	0.42
7/6/2014	2:00:00 PM	0.42
7/6/2014	2:15:00 PM	0.42
7/6/2014	2:30:00 PM	0.42
7/6/2014	2:45:00 PM	0.42
7/6/2014	3:00:00 PM	0.42
7/6/2014	3:15:00 PM	0.42
7/6/2014	3:30:00 PM	0.42
7/6/2014	3:45:00 PM	0.42
7/6/2014	4:00:00 PM	0.42
7/6/2014	4:15:00 PM	0.42
7/6/2014	4:30:00 PM	0.42
7/6/2014	4:45:00 PM	0.42
7/6/2014	5:00:00 PM	0.42
7/6/2014	5:15:00 PM	0.42
7/6/2014	5:30:00 PM	0.42
7/6/2014	5:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/6/2014	6:00:00 PM	0.42
7/6/2014	6:15:00 PM	0.42
7/6/2014	6:30:00 PM	0.42
7/6/2014	6:45:00 PM	0.42
7/6/2014	7:00:00 PM	0.42
7/6/2014	7:15:00 PM	0.42
7/6/2014	7:30:00 PM	0.42
7/6/2014	7:45:00 PM	0.42
7/6/2014	8:00:00 PM	0.42
7/6/2014	8:15:00 PM	0.42
7/6/2014	8:30:00 PM	0.42
7/6/2014	8:45:00 PM	0.42
7/6/2014	9:00:00 PM	0.42
7/6/2014	9:15:00 PM	0.42
7/6/2014	9:30:00 PM	0.42
7/6/2014	9:45:00 PM	0.42
7/6/2014	10:00:00 PM	0.42
7/6/2014	10:15:00 PM	0.43
7/6/2014	10:30:00 PM	0.42
7/6/2014	10:45:00 PM	0.43
7/6/2014	11:00:00 PM	0.44
7/6/2014	11:15:00 PM	0.44
7/6/2014	11:30:00 PM	0.44
7/6/2014	11:45:00 PM	0.44
7/7/2014	12:00:00 AM	0.43
7/7/2014	12:15:00 AM	0.44
7/7/2014	12:30:00 AM	0.43
7/7/2014	12:45:00 AM	0.44
7/7/2014	1:00:00 AM	0.44
7/7/2014	1:15:00 AM	0.44
7/7/2014	1:30:00 AM	0.44
7/7/2014	1:45:00 AM	0.44
7/7/2014	2:00:00 AM	0.44
7/7/2014	2:15:00 AM	0.44
7/7/2014	2:30:00 AM	0.44
7/7/2014	2:45:00 AM	0.44
7/7/2014	3:00:00 AM	0.44
7/7/2014	3:15:00 AM	0.44
7/7/2014	3:30:00 AM	0.44
7/7/2014	3:45:00 AM	0.44
7/7/2014	4:00:00 AM	0.44
7/7/2014	4:15:00 AM	0.44
7/7/2014	4:30:00 AM	0.44
7/7/2014	4:45:00 AM	0.44
7/7/2014	5:00:00 AM	0.45
7/7/2014	5:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/7/2014	5:30:00 AM	0.45
7/7/2014	5:45:00 AM	0.45
7/7/2014	6:00:00 AM	0.44
7/7/2014	6:15:00 AM	0.44
7/7/2014	6:30:00 AM	0.44
7/7/2014	6:45:00 AM	0.44
7/7/2014	7:00:00 AM	0.44
7/7/2014	7:15:00 AM	0.44
7/7/2014	7:30:00 AM	0.44
7/7/2014	7:45:00 AM	0.45
7/7/2014	8:00:00 AM	0.45
7/7/2014	8:15:00 AM	0.45
7/7/2014	8:30:00 AM	0.45
7/7/2014	8:45:00 AM	0.45
7/7/2014	9:00:00 AM	0.45
7/7/2014	9:15:00 AM	0.45
7/7/2014	9:30:00 AM	0.45
7/7/2014	9:45:00 AM	0.45
7/7/2014	10:00:00 AM	0.45
7/7/2014	10:15:00 AM	0.45
7/7/2014	10:30:00 AM	0.45
7/7/2014	10:45:00 AM	0.46
7/7/2014	11:00:00 AM	0.46
7/7/2014	11:15:00 AM	0.46
7/7/2014	11:30:00 AM	0.46
7/7/2014	11:45:00 AM	0.46
7/7/2014	12:00:00 PM	0.46
7/7/2014	12:15:00 PM	0.46
7/7/2014	12:30:00 PM	0.46
7/7/2014	12:45:00 PM	0.46
7/7/2014	1:00:00 PM	0.46
7/7/2014	1:15:00 PM	0.46
7/7/2014	1:30:00 PM	0.46
7/7/2014	1:45:00 PM	0.46
7/7/2014	2:00:00 PM	0.45
7/7/2014	2:15:00 PM	0.44
7/7/2014	2:30:00 PM	0.45
7/7/2014	2:45:00 PM	0.45
7/7/2014	3:00:00 PM	0.45
7/7/2014	3:15:00 PM	0.45
7/7/2014	3:30:00 PM	0.44
7/7/2014	3:45:00 PM	0.44
7/7/2014	4:00:00 PM	0.45
7/7/2014	4:15:00 PM	0.45
7/7/2014	4:30:00 PM	0.45
7/7/2014	4:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/7/2014	5:00:00 PM	0.44
7/7/2014	5:15:00 PM	0.44
7/7/2014	5:30:00 PM	0.44
7/7/2014	5:45:00 PM	0.44
7/7/2014	6:00:00 PM	0.44
7/7/2014	6:15:00 PM	0.44
7/7/2014	6:30:00 PM	0.45
7/7/2014	6:45:00 PM	0.44
7/7/2014	7:00:00 PM	0.44
7/7/2014	7:15:00 PM	0.44
7/7/2014	7:30:00 PM	0.44
7/7/2014	7:45:00 PM	0.44
7/7/2014	8:00:00 PM	0.44
7/7/2014	8:15:00 PM	0.44
7/7/2014	8:30:00 PM	0.45
7/7/2014	8:45:00 PM	0.45
7/7/2014	9:00:00 PM	0.46
7/7/2014	9:15:00 PM	0.45
7/7/2014	9:30:00 PM	0.45
7/7/2014	9:45:00 PM	0.45
7/7/2014	10:00:00 PM	0.45
7/7/2014	10:15:00 PM	0.45
7/7/2014	10:30:00 PM	0.46
7/7/2014	10:45:00 PM	0.46
7/7/2014	11:00:00 PM	0.46
7/7/2014	11:15:00 PM	0.46
7/7/2014	11:30:00 PM	0.46
7/7/2014	11:45:00 PM	0.46
7/8/2014	12:00:00 AM	0.46
7/8/2014	12:15:00 AM	0.46
7/8/2014	12:30:00 AM	0.46
7/8/2014	12:45:00 AM	0.46
7/8/2014	1:00:00 AM	0.46
7/8/2014	1:15:00 AM	0.46
7/8/2014	1:30:00 AM	0.46
7/8/2014	1:45:00 AM	0.46
7/8/2014	2:00:00 AM	0.46
7/8/2014	2:15:00 AM	0.46
7/8/2014	2:30:00 AM	0.46
7/8/2014	2:45:00 AM	0.46
7/8/2014	3:00:00 AM	0.46
7/8/2014	3:15:00 AM	0.46
7/8/2014	3:30:00 AM	0.46
7/8/2014	3:45:00 AM	0.46
7/8/2014	4:00:00 AM	0.46
7/8/2014	4:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/8/2014	4:30:00 AM	0.46
7/8/2014	4:45:00 AM	0.46
7/8/2014	5:00:00 AM	0.46
7/8/2014	5:15:00 AM	0.46
7/8/2014	5:30:00 AM	0.46
7/8/2014	5:45:00 AM	0.46
7/8/2014	6:00:00 AM	0.47
7/8/2014	6:15:00 AM	0.47
7/8/2014	6:30:00 AM	0.47
7/8/2014	6:45:00 AM	0.47
7/8/2014	7:00:00 AM	0.47
7/8/2014	7:15:00 AM	0.48
7/8/2014	7:30:00 AM	0.48
7/8/2014	7:45:00 AM	0.48
7/8/2014	8:00:00 AM	0.48
7/8/2014	8:15:00 AM	0.48
7/8/2014	8:30:00 AM	0.48
7/8/2014	8:45:00 AM	0.47
7/8/2014	9:00:00 AM	0.47
7/8/2014	9:15:00 AM	0.48
7/8/2014	9:30:00 AM	0.48
7/8/2014	9:45:00 AM	0.48
7/8/2014	10:00:00 AM	0.47
7/8/2014	10:15:00 AM	0.47
7/8/2014	10:30:00 AM	0.47
7/8/2014	10:45:00 AM	0.47
7/8/2014	11:00:00 AM	0.47
7/8/2014	11:15:00 AM	0.47
7/8/2014	11:30:00 AM	0.47
7/8/2014	11:45:00 AM	0.47
7/8/2014	12:00:00 PM	0.46
7/8/2014	12:15:00 PM	0.46
7/8/2014	12:30:00 PM	0.46
7/8/2014	12:45:00 PM	0.46
7/8/2014	1:00:00 PM	0.46
7/8/2014	1:15:00 PM	0.46
7/8/2014	1:30:00 PM	0.46
7/8/2014	1:45:00 PM	0.46
7/8/2014	2:00:00 PM	0.46
7/8/2014	2:15:00 PM	0.46
7/8/2014	2:30:00 PM	0.46
7/8/2014	2:45:00 PM	0.46
7/8/2014	3:00:00 PM	0.46
7/8/2014	3:15:00 PM	0.46
7/8/2014	3:30:00 PM	0.45
7/8/2014	3:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/8/2014	4:00:00 PM	0.46
7/8/2014	4:15:00 PM	0.46
7/8/2014	4:30:00 PM	0.46
7/8/2014	4:45:00 PM	0.46
7/8/2014	5:00:00 PM	0.46
7/8/2014	5:15:00 PM	0.45
7/8/2014	5:30:00 PM	0.45
7/8/2014	5:45:00 PM	0.45
7/8/2014	6:00:00 PM	0.45
7/8/2014	6:15:00 PM	0.45
7/8/2014	6:30:00 PM	0.45
7/8/2014	6:45:00 PM	0.45
7/8/2014	7:00:00 PM	0.45
7/8/2014	7:15:00 PM	0.46
7/8/2014	7:30:00 PM	0.45
7/8/2014	7:45:00 PM	0.46
7/8/2014	8:00:00 PM	0.45
7/8/2014	8:15:00 PM	0.46
7/8/2014	8:30:00 PM	0.45
7/8/2014	8:45:00 PM	0.45
7/8/2014	9:00:00 PM	0.45
7/8/2014	9:15:00 PM	0.45
7/8/2014	9:30:00 PM	0.45
7/8/2014	9:45:00 PM	0.45
7/8/2014	10:00:00 PM	0.45
7/8/2014	10:15:00 PM	0.46
7/8/2014	10:30:00 PM	0.45
7/8/2014	10:45:00 PM	0.46
7/8/2014	11:00:00 PM	0.46
7/8/2014	11:15:00 PM	0.46
7/8/2014	11:30:00 PM	0.46
7/8/2014	11:45:00 PM	0.46
7/9/2014	12:00:00 AM	0.46
7/9/2014	12:15:00 AM	0.46
7/9/2014	12:30:00 AM	0.46
7/9/2014	12:45:00 AM	0.46
7/9/2014	1:00:00 AM	0.46
7/9/2014	1:15:00 AM	0.46
7/9/2014	1:30:00 AM	0.46
7/9/2014	1:45:00 AM	0.46
7/9/2014	2:00:00 AM	0.46
7/9/2014	2:15:00 AM	0.46
7/9/2014	2:30:00 AM	0.46
7/9/2014	2:45:00 AM	0.46
7/9/2014	3:00:00 AM	0.46
7/9/2014	3:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/9/2014	3:30:00 AM	0.46
7/9/2014	3:45:00 AM	0.46
7/9/2014	4:00:00 AM	0.46
7/9/2014	4:15:00 AM	0.46
7/9/2014	4:30:00 AM	0.46
7/9/2014	4:45:00 AM	0.46
7/9/2014	5:00:00 AM	0.46
7/9/2014	5:15:00 AM	0.46
7/9/2014	5:30:00 AM	0.46
7/9/2014	5:45:00 AM	0.46
7/9/2014	6:00:00 AM	0.46
7/9/2014	6:15:00 AM	0.46
7/9/2014	6:30:00 AM	0.47
7/9/2014	6:45:00 AM	0.46
7/9/2014	7:00:00 AM	0.46
7/9/2014	7:15:00 AM	0.46
7/9/2014	7:30:00 AM	0.46
7/9/2014	7:45:00 AM	0.46
7/9/2014	8:00:00 AM	0.46
7/9/2014	8:15:00 AM	0.46
7/9/2014	8:30:00 AM	0.46
7/9/2014	8:45:00 AM	0.46
7/9/2014	9:00:00 AM	0.46
7/9/2014	9:15:00 AM	0.46
7/9/2014	9:30:00 AM	0.46
7/9/2014	9:45:00 AM	0.46
7/9/2014	10:00:00 AM	0.46
7/9/2014	10:15:00 AM	0.46
7/9/2014	10:30:00 AM	0.46
7/9/2014	10:45:00 AM	0.46
7/9/2014	11:00:00 AM	0.46
7/9/2014	11:15:00 AM	0.46
7/9/2014	11:30:00 AM	0.46
7/9/2014	11:45:00 AM	0.46
7/9/2014	12:00:00 PM	0.46
7/9/2014	12:15:00 PM	0.46
7/9/2014	12:30:00 PM	0.46
7/9/2014	12:45:00 PM	0.46
7/9/2014	1:00:00 PM	0.46
7/9/2014	1:15:00 PM	0.45
7/9/2014	1:30:00 PM	0.45
7/9/2014	1:45:00 PM	0.45
7/9/2014	2:00:00 PM	0.45
7/9/2014	2:15:00 PM	0.44
7/9/2014	2:30:00 PM	0.44
7/9/2014	2:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/9/2014	3:00:00 PM	0.44
7/9/2014	3:15:00 PM	0.44
7/9/2014	3:30:00 PM	0.44
7/9/2014	3:45:00 PM	0.44
7/9/2014	4:00:00 PM	0.44
7/9/2014	4:15:00 PM	0.44
7/9/2014	4:30:00 PM	0.44
7/9/2014	4:45:00 PM	0.44
7/9/2014	5:00:00 PM	0.44
7/9/2014	5:15:00 PM	0.44
7/9/2014	5:30:00 PM	0.44
7/9/2014	5:45:00 PM	0.44
7/9/2014	6:00:00 PM	0.43
7/9/2014	6:15:00 PM	0.44
7/9/2014	6:30:00 PM	0.44
7/9/2014	6:45:00 PM	0.44
7/9/2014	7:00:00 PM	0.44
7/9/2014	7:15:00 PM	0.44
7/9/2014	7:30:00 PM	0.44
7/9/2014	7:45:00 PM	0.44
7/9/2014	8:00:00 PM	0.44
7/9/2014	8:15:00 PM	0.44
7/9/2014	8:30:00 PM	0.44
7/9/2014	8:45:00 PM	0.44
7/9/2014	9:00:00 PM	0.44
7/9/2014	9:15:00 PM	0.44
7/9/2014	9:30:00 PM	0.44
7/9/2014	9:45:00 PM	0.44
7/9/2014	10:00:00 PM	0.44
7/9/2014	10:15:00 PM	0.44
7/9/2014	10:30:00 PM	0.44
7/9/2014	10:45:00 PM	0.44
7/9/2014	11:00:00 PM	0.44
7/9/2014	11:15:00 PM	0.44
7/9/2014	11:30:00 PM	0.44
7/9/2014	11:45:00 PM	0.44
7/10/2014	12:00:00 AM	0.44
7/10/2014	12:15:00 AM	0.44
7/10/2014	12:30:00 AM	0.44
7/10/2014	12:45:00 AM	0.44
7/10/2014	1:00:00 AM	0.44
7/10/2014	1:15:00 AM	0.44
7/10/2014	1:30:00 AM	0.44
7/10/2014	1:45:00 AM	0.44
7/10/2014	2:00:00 AM	0.44
7/10/2014	2:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/10/2014	2:30:00 AM	0.44
7/10/2014	2:45:00 AM	0.44
7/10/2014	3:00:00 AM	0.44
7/10/2014	3:15:00 AM	0.44
7/10/2014	3:30:00 AM	0.44
7/10/2014	3:45:00 AM	0.44
7/10/2014	4:00:00 AM	0.44
7/10/2014	4:15:00 AM	0.44
7/10/2014	4:30:00 AM	0.44
7/10/2014	4:45:00 AM	0.44
7/10/2014	5:00:00 AM	0.44
7/10/2014	5:15:00 AM	0.44
7/10/2014	5:30:00 AM	0.45
7/10/2014	5:45:00 AM	0.45
7/10/2014	6:00:00 AM	0.45
7/10/2014	6:15:00 AM	0.45
7/10/2014	6:30:00 AM	0.45
7/10/2014	6:45:00 AM	0.44
7/10/2014	7:00:00 AM	0.45
7/10/2014	7:15:00 AM	0.44
7/10/2014	7:30:00 AM	0.45
7/10/2014	7:45:00 AM	0.44
7/10/2014	8:00:00 AM	0.44
7/10/2014	8:15:00 AM	0.45
7/10/2014	8:30:00 AM	0.44
7/10/2014	8:45:00 AM	0.44
7/10/2014	9:00:00 AM	0.44
7/10/2014	9:15:00 AM	0.44
7/10/2014	9:30:00 AM	0.44
7/10/2014	9:45:00 AM	0.44
7/10/2014	10:00:00 AM	0.44
7/10/2014	10:15:00 AM	0.44
7/10/2014	10:30:00 AM	0.44
7/10/2014	10:45:00 AM	0.44
7/10/2014	11:00:00 AM	0.44
7/10/2014	11:15:00 AM	0.44
7/10/2014	11:30:00 AM	0.44
7/10/2014	11:45:00 AM	0.44
7/10/2014	12:00:00 PM	0.44
7/10/2014	12:15:00 PM	0.44
7/10/2014	12:30:00 PM	0.44
7/10/2014	12:45:00 PM	0.44
7/10/2014	1:00:00 PM	0.44
7/10/2014	1:15:00 PM	0.43
7/10/2014	1:30:00 PM	0.43
7/10/2014	1:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/10/2014	2:00:00 PM	0.43
7/10/2014	2:15:00 PM	0.42
7/10/2014	2:30:00 PM	0.42
7/10/2014	2:45:00 PM	0.42
7/10/2014	3:00:00 PM	0.42
7/10/2014	3:15:00 PM	0.42
7/10/2014	3:30:00 PM	0.42
7/10/2014	3:45:00 PM	0.42
7/10/2014	4:00:00 PM	0.41
7/10/2014	4:15:00 PM	0.41
7/10/2014	4:30:00 PM	0.41
7/10/2014	4:45:00 PM	0.41
7/10/2014	5:00:00 PM	0.41
7/10/2014	5:15:00 PM	0.4
7/10/2014	5:30:00 PM	0.4
7/10/2014	5:45:00 PM	0.41
7/10/2014	6:00:00 PM	0.41
7/10/2014	6:15:00 PM	0.4
7/10/2014	6:30:00 PM	0.4
7/10/2014	6:45:00 PM	0.4
7/10/2014	7:00:00 PM	0.4
7/10/2014	7:15:00 PM	0.4
7/10/2014	7:30:00 PM	0.4
7/10/2014	7:45:00 PM	0.4
7/10/2014	8:00:00 PM	0.4
7/10/2014	8:15:00 PM	0.4
7/10/2014	8:30:00 PM	0.4
7/10/2014	8:45:00 PM	0.4
7/10/2014	9:00:00 PM	0.4
7/10/2014	9:15:00 PM	0.4
7/10/2014	9:30:00 PM	0.41
7/10/2014	9:45:00 PM	0.4
7/10/2014	10:00:00 PM	0.41
7/10/2014	10:15:00 PM	0.41
7/10/2014	10:30:00 PM	0.41
7/10/2014	10:45:00 PM	0.4
7/10/2014	11:00:00 PM	0.41
7/10/2014	11:15:00 PM	0.41
7/10/2014	11:30:00 PM	0.41
7/10/2014	11:45:00 PM	0.41
7/11/2014	12:00:00 AM	0.4
7/11/2014	12:15:00 AM	0.41
7/11/2014	12:30:00 AM	0.41
7/11/2014	12:45:00 AM	0.41
7/11/2014	1:00:00 AM	0.41
7/11/2014	1:15:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/11/2014	1:30:00 AM	0.41
7/11/2014	1:45:00 AM	0.41
7/11/2014	2:00:00 AM	0.42
7/11/2014	2:15:00 AM	0.42
7/11/2014	2:30:00 AM	0.41
7/11/2014	2:45:00 AM	0.41
7/11/2014	3:00:00 AM	0.41
7/11/2014	3:15:00 AM	0.41
7/11/2014	3:30:00 AM	0.41
7/11/2014	3:45:00 AM	0.41
7/11/2014	4:00:00 AM	0.41
7/11/2014	4:15:00 AM	0.41
7/11/2014	4:30:00 AM	0.42
7/11/2014	4:45:00 AM	0.42
7/11/2014	5:00:00 AM	0.42
7/11/2014	5:15:00 AM	0.42
7/11/2014	5:30:00 AM	0.42
7/11/2014	5:45:00 AM	0.42
7/11/2014	6:00:00 AM	0.42
7/11/2014	6:15:00 AM	0.42
7/11/2014	6:30:00 AM	0.42
7/11/2014	6:45:00 AM	0.42
7/11/2014	7:00:00 AM	0.42
7/11/2014	7:15:00 AM	0.42
7/11/2014	7:30:00 AM	0.42
7/11/2014	7:45:00 AM	0.42
7/11/2014	8:00:00 AM	0.42
7/11/2014	8:15:00 AM	0.42
7/11/2014	8:30:00 AM	0.42
7/11/2014	8:45:00 AM	0.42
7/11/2014	9:00:00 AM	0.42
7/11/2014	9:15:00 AM	0.42
7/11/2014	9:30:00 AM	0.42
7/11/2014	9:45:00 AM	0.42
7/11/2014	10:00:00 AM	0.42
7/11/2014	10:15:00 AM	0.42
7/11/2014	10:30:00 AM	0.42
7/11/2014	10:45:00 AM	0.41
7/11/2014	11:00:00 AM	0.41
7/11/2014	11:15:00 AM	0.41
7/11/2014	11:30:00 AM	0.41
7/11/2014	11:45:00 AM	0.41
7/11/2014	12:00:00 PM	0.41
7/11/2014	12:15:00 PM	0.4
7/11/2014	12:30:00 PM	0.41
7/11/2014	12:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/11/2014	1:00:00 PM	0.4
7/11/2014	1:15:00 PM	0.4
7/11/2014	1:30:00 PM	0.4
7/11/2014	1:45:00 PM	0.4
7/11/2014	2:00:00 PM	0.4
7/11/2014	2:15:00 PM	0.4
7/11/2014	2:30:00 PM	0.39
7/11/2014	2:45:00 PM	0.39
7/11/2014	3:00:00 PM	0.39
7/11/2014	3:15:00 PM	0.38
7/11/2014	3:30:00 PM	0.39
7/11/2014	3:45:00 PM	0.39
7/11/2014	4:00:00 PM	0.38
7/11/2014	4:15:00 PM	0.38
7/11/2014	4:30:00 PM	0.38
7/11/2014	4:45:00 PM	0.38
7/11/2014	5:00:00 PM	0.38
7/11/2014	5:15:00 PM	0.38
7/11/2014	5:30:00 PM	0.38
7/11/2014	5:45:00 PM	0.38
7/11/2014	6:00:00 PM	0.38
7/11/2014	6:15:00 PM	0.38
7/11/2014	6:30:00 PM	0.38
7/11/2014	6:45:00 PM	0.38
7/11/2014	7:00:00 PM	0.38
7/11/2014	7:15:00 PM	0.38
7/11/2014	7:30:00 PM	0.38
7/11/2014	7:45:00 PM	0.38
7/11/2014	8:00:00 PM	0.38
7/11/2014	8:15:00 PM	0.38
7/11/2014	8:30:00 PM	0.38
7/11/2014	8:45:00 PM	0.38
7/11/2014	9:00:00 PM	0.38
7/11/2014	9:15:00 PM	0.38
7/11/2014	9:30:00 PM	0.38
7/11/2014	9:45:00 PM	0.38
7/11/2014	10:00:00 PM	0.38
7/11/2014	10:15:00 PM	0.38
7/11/2014	10:30:00 PM	0.38
7/11/2014	10:45:00 PM	0.38
7/11/2014	11:00:00 PM	0.38
7/11/2014	11:15:00 PM	0.38
7/11/2014	11:30:00 PM	0.38
7/11/2014	11:45:00 PM	0.38
7/12/2014	12:00:00 AM	0.38
7/12/2014	12:15:00 AM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2014	12:30:00 AM	0.38
7/12/2014	12:45:00 AM	0.38
7/12/2014	1:00:00 AM	0.38
7/12/2014	1:15:00 AM	0.38
7/12/2014	1:30:00 AM	0.38
7/12/2014	1:45:00 AM	0.38
7/12/2014	2:00:00 AM	0.38
7/12/2014	2:15:00 AM	0.38
7/12/2014	2:30:00 AM	0.38
7/12/2014	2:45:00 AM	0.38
7/12/2014	3:00:00 AM	0.39
7/12/2014	3:15:00 AM	0.38
7/12/2014	3:30:00 AM	0.38
7/12/2014	3:45:00 AM	0.38
7/12/2014	4:00:00 AM	0.38
7/12/2014	4:15:00 AM	0.38
7/12/2014	4:30:00 AM	0.38
7/12/2014	4:45:00 AM	0.38
7/12/2014	5:00:00 AM	0.38
7/12/2014	5:15:00 AM	0.38
7/12/2014	5:30:00 AM	0.38
7/12/2014	5:45:00 AM	0.38
7/12/2014	6:00:00 AM	0.38
7/12/2014	6:15:00 AM	0.38
7/12/2014	6:30:00 AM	0.39
7/12/2014	6:45:00 AM	0.39
7/12/2014	7:00:00 AM	0.39
7/12/2014	7:15:00 AM	0.39
7/12/2014	7:30:00 AM	0.39
7/12/2014	7:45:00 AM	0.39
7/12/2014	8:00:00 AM	0.39
7/12/2014	8:15:00 AM	0.39
7/12/2014	8:30:00 AM	0.39
7/12/2014	8:45:00 AM	0.39
7/12/2014	9:00:00 AM	0.39
7/12/2014	9:15:00 AM	0.39
7/12/2014	9:30:00 AM	0.39
7/12/2014	9:45:00 AM	0.39
7/12/2014	10:00:00 AM	0.39
7/12/2014	10:15:00 AM	0.39
7/12/2014	10:30:00 AM	0.38
7/12/2014	10:45:00 AM	0.38
7/12/2014	11:00:00 AM	0.38
7/12/2014	11:15:00 AM	0.38
7/12/2014	11:30:00 AM	0.38
7/12/2014	11:45:00 AM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2014	12:00:00 PM	0.38
7/12/2014	12:15:00 PM	0.38
7/12/2014	12:30:00 PM	0.38
7/12/2014	12:45:00 PM	0.38
7/12/2014	1:00:00 PM	0.38
7/12/2014	1:15:00 PM	0.38
7/12/2014	1:30:00 PM	0.38
7/12/2014	1:45:00 PM	0.38
7/12/2014	2:00:00 PM	0.38
7/12/2014	2:15:00 PM	0.38
7/12/2014	2:30:00 PM	0.37
7/12/2014	2:45:00 PM	0.37
7/12/2014	3:00:00 PM	0.37
7/12/2014	3:15:00 PM	0.36
7/12/2014	3:30:00 PM	0.36
7/12/2014	3:45:00 PM	0.36
7/12/2014	4:00:00 PM	0.36
7/12/2014	4:15:00 PM	0.36
7/12/2014	4:30:00 PM	0.36
7/12/2014	4:45:00 PM	0.36
7/12/2014	5:00:00 PM	0.36
7/12/2014	5:15:00 PM	0.36
7/12/2014	5:30:00 PM	0.36
7/12/2014	5:45:00 PM	0.36
7/12/2014	6:00:00 PM	0.36
7/12/2014	6:15:00 PM	0.36
7/12/2014	6:30:00 PM	0.36
7/12/2014	6:45:00 PM	0.36
7/12/2014	7:00:00 PM	0.36
7/12/2014	7:15:00 PM	0.36
7/12/2014	7:30:00 PM	0.36
7/12/2014	7:45:00 PM	0.36
7/12/2014	8:00:00 PM	0.36
7/12/2014	8:15:00 PM	0.36
7/12/2014	8:30:00 PM	0.36
7/12/2014	8:45:00 PM	0.36
7/12/2014	9:00:00 PM	0.36
7/12/2014	9:15:00 PM	0.36
7/12/2014	9:30:00 PM	0.36
7/12/2014	9:45:00 PM	0.36
7/12/2014	10:00:00 PM	0.36
7/12/2014	10:15:00 PM	0.36
7/12/2014	10:30:00 PM	0.36
7/12/2014	10:45:00 PM	0.36
7/12/2014	11:00:00 PM	0.36
7/12/2014	11:15:00 PM	0.36

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2014	11:30:00 PM	0.36
7/12/2014	11:45:00 PM	0.36
7/13/2014	12:00:00 AM	0.36
7/13/2014	12:15:00 AM	0.36
7/13/2014	12:30:00 AM	0.36
7/13/2014	12:45:00 AM	0.36
7/13/2014	1:00:00 AM	0.36
7/13/2014	1:15:00 AM	0.36
7/13/2014	1:30:00 AM	0.36
7/13/2014	1:45:00 AM	0.36
7/13/2014	2:00:00 AM	0.36
7/13/2014	2:15:00 AM	0.36
7/13/2014	2:30:00 AM	0.36
7/13/2014	2:45:00 AM	0.36
7/13/2014	3:00:00 AM	0.36
7/13/2014	3:15:00 AM	0.37
7/13/2014	3:30:00 AM	0.37
7/13/2014	3:45:00 AM	0.37
7/13/2014	4:00:00 AM	0.37
7/13/2014	4:15:00 AM	0.37
7/13/2014	4:30:00 AM	0.37
7/13/2014	4:45:00 AM	0.37
7/13/2014	5:00:00 AM	0.37
7/13/2014	5:15:00 AM	0.37
7/13/2014	5:30:00 AM	0.38
7/13/2014	5:45:00 AM	0.38
7/13/2014	6:00:00 AM	0.38
7/13/2014	6:15:00 AM	0.38
7/13/2014	6:30:00 AM	0.38
7/13/2014	6:45:00 AM	0.38
7/13/2014	7:00:00 AM	0.38
7/13/2014	7:15:00 AM	0.38
7/13/2014	7:30:00 AM	0.38
7/13/2014	7:45:00 AM	0.38
7/13/2014	8:00:00 AM	0.38
7/13/2014	8:15:00 AM	0.38
7/13/2014	8:30:00 AM	0.38
7/13/2014	8:45:00 AM	0.38
7/13/2014	9:00:00 AM	0.38
7/13/2014	9:15:00 AM	0.38
7/13/2014	9:30:00 AM	0.38
7/13/2014	9:45:00 AM	0.38
7/13/2014	10:00:00 AM	0.38
7/13/2014	10:15:00 AM	0.38
7/13/2014	10:30:00 AM	0.38
7/13/2014	10:45:00 AM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/13/2014	11:00:00 AM	0.38
7/13/2014	11:15:00 AM	0.38
7/13/2014	11:30:00 AM	0.38
7/13/2014	11:45:00 AM	0.38
7/13/2014	12:00:00 PM	0.38
7/13/2014	12:15:00 PM	0.38
7/13/2014	12:30:00 PM	0.37
7/13/2014	12:45:00 PM	0.37
7/13/2014	1:00:00 PM	0.37
7/13/2014	1:15:00 PM	0.37
7/13/2014	1:30:00 PM	0.37
7/13/2014	1:45:00 PM	0.37
7/13/2014	2:00:00 PM	0.37
7/13/2014	2:15:00 PM	0.36
7/13/2014	2:30:00 PM	0.36
7/13/2014	2:45:00 PM	0.36
7/13/2014	3:00:00 PM	0.36
7/13/2014	3:15:00 PM	0.36
7/13/2014	3:30:00 PM	0.36
7/13/2014	3:45:00 PM	0.36
7/13/2014	4:00:00 PM	0.36
7/13/2014	4:15:00 PM	0.36
7/13/2014	4:30:00 PM	0.36
7/13/2014	4:45:00 PM	0.36
7/13/2014	5:00:00 PM	0.36
7/13/2014	5:15:00 PM	0.36
7/13/2014	5:30:00 PM	0.36
7/13/2014	5:45:00 PM	0.36
7/13/2014	6:00:00 PM	0.36
7/13/2014	6:15:00 PM	0.36
7/13/2014	6:30:00 PM	0.36
7/13/2014	6:45:00 PM	0.36
7/13/2014	7:00:00 PM	0.36
7/13/2014	7:15:00 PM	0.36
7/13/2014	7:30:00 PM	0.36
7/13/2014	7:45:00 PM	0.36
7/13/2014	8:00:00 PM	0.36
7/13/2014	8:15:00 PM	0.36
7/13/2014	8:30:00 PM	0.36
7/13/2014	8:45:00 PM	0.36
7/13/2014	9:00:00 PM	0.36
7/13/2014	9:15:00 PM	0.36
7/13/2014	9:30:00 PM	0.36
7/13/2014	9:45:00 PM	0.36
7/13/2014	10:00:00 PM	0.36
7/13/2014	10:15:00 PM	0.36

Goose Lake Return Gage

DATE	TIME	GAGE
7/13/2014	10:30:00 PM	0.36
7/13/2014	10:45:00 PM	0.36
7/13/2014	11:00:00 PM	0.37
7/13/2014	11:15:00 PM	0.37
7/13/2014	11:30:00 PM	0.37
7/13/2014	11:45:00 PM	0.37
7/14/2014	12:00:00 AM	0.37
7/14/2014	12:15:00 AM	0.38
7/14/2014	12:30:00 AM	0.38
7/14/2014	12:45:00 AM	0.38
7/14/2014	1:00:00 AM	0.38
7/14/2014	1:15:00 AM	0.38
7/14/2014	1:30:00 AM	0.38
7/14/2014	1:45:00 AM	0.38
7/14/2014	2:00:00 AM	0.38
7/14/2014	2:15:00 AM	0.38
7/14/2014	2:30:00 AM	0.38
7/14/2014	2:45:00 AM	0.38
7/14/2014	3:00:00 AM	0.38
7/14/2014	3:15:00 AM	0.38
7/14/2014	3:30:00 AM	0.38
7/14/2014	3:45:00 AM	0.38
7/14/2014	4:00:00 AM	0.38
7/14/2014	4:15:00 AM	0.38
7/14/2014	4:30:00 AM	0.38
7/14/2014	4:45:00 AM	0.38
7/14/2014	5:00:00 AM	0.38
7/14/2014	5:15:00 AM	0.38
7/14/2014	5:30:00 AM	0.39
7/14/2014	5:45:00 AM	0.39
7/14/2014	6:00:00 AM	0.39
7/14/2014	6:15:00 AM	0.39
7/14/2014	6:30:00 AM	0.39
7/14/2014	6:45:00 AM	0.4
7/14/2014	7:00:00 AM	0.4
7/14/2014	7:15:00 AM	0.4
7/14/2014	7:30:00 AM	0.4
7/14/2014	7:45:00 AM	0.4
7/14/2014	8:00:00 AM	0.4
7/14/2014	8:15:00 AM	0.4
7/14/2014	8:30:00 AM	0.4
7/14/2014	8:45:00 AM	0.4
7/14/2014	9:00:00 AM	0.4
7/14/2014	9:15:00 AM	0.4
7/14/2014	9:30:00 AM	0.4
7/14/2014	9:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/14/2014	10:00:00 AM	0.4
7/14/2014	10:15:00 AM	0.4
7/14/2014	10:30:00 AM	0.4
7/14/2014	10:45:00 AM	0.4
7/14/2014	11:00:00 AM	0.4
7/14/2014	11:15:00 AM	0.4
7/14/2014	11:30:00 AM	0.4
7/14/2014	11:45:00 AM	0.4
7/14/2014	12:00:00 PM	0.39
7/14/2014	12:15:00 PM	0.39
7/14/2014	12:30:00 PM	0.39
7/14/2014	12:45:00 PM	0.39
7/14/2014	1:00:00 PM	0.39
7/14/2014	1:15:00 PM	0.39
7/14/2014	1:30:00 PM	0.39
7/14/2014	1:45:00 PM	0.38
7/14/2014	2:00:00 PM	0.38
7/14/2014	2:15:00 PM	0.38
7/14/2014	2:30:00 PM	0.38
7/14/2014	2:45:00 PM	0.38
7/14/2014	3:00:00 PM	0.38
7/14/2014	3:15:00 PM	0.38
7/14/2014	3:30:00 PM	0.38
7/14/2014	3:45:00 PM	0.38
7/14/2014	4:00:00 PM	0.38
7/14/2014	4:15:00 PM	0.38
7/14/2014	4:30:00 PM	0.38
7/14/2014	4:45:00 PM	0.38
7/14/2014	5:00:00 PM	0.38
7/14/2014	5:15:00 PM	0.38
7/14/2014	5:30:00 PM	0.38
7/14/2014	5:45:00 PM	0.38
7/14/2014	6:00:00 PM	0.38
7/14/2014	6:15:00 PM	0.38
7/14/2014	6:30:00 PM	0.38
7/14/2014	6:45:00 PM	0.38
7/14/2014	7:00:00 PM	0.38
7/14/2014	7:15:00 PM	0.38
7/14/2014	7:30:00 PM	0.38
7/14/2014	7:45:00 PM	0.38
7/14/2014	8:00:00 PM	0.38
7/14/2014	8:15:00 PM	0.38
7/14/2014	8:30:00 PM	0.38
7/14/2014	8:45:00 PM	0.38
7/14/2014	9:00:00 PM	0.38
7/14/2014	9:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/14/2014	9:30:00 PM	0.38
7/14/2014	9:45:00 PM	0.38
7/14/2014	10:00:00 PM	0.38
7/14/2014	10:15:00 PM	0.38
7/14/2014	10:30:00 PM	0.38
7/14/2014	10:45:00 PM	0.38
7/14/2014	11:00:00 PM	0.38
7/14/2014	11:15:00 PM	0.38
7/14/2014	11:30:00 PM	0.38
7/14/2014	11:45:00 PM	0.39
7/15/2014	12:00:00 AM	0.39
7/15/2014	12:15:00 AM	0.39
7/15/2014	12:30:00 AM	0.39
7/15/2014	12:45:00 AM	0.39
7/15/2014	1:00:00 AM	0.39
7/15/2014	1:15:00 AM	0.39
7/15/2014	1:30:00 AM	0.39
7/15/2014	1:45:00 AM	0.39
7/15/2014	2:00:00 AM	0.39
7/15/2014	2:15:00 AM	0.39
7/15/2014	2:30:00 AM	0.39
7/15/2014	2:45:00 AM	0.4
7/15/2014	3:00:00 AM	0.4
7/15/2014	3:15:00 AM	0.4
7/15/2014	3:30:00 AM	0.4
7/15/2014	3:45:00 AM	0.4
7/15/2014	4:00:00 AM	0.4
7/15/2014	4:15:00 AM	0.4
7/15/2014	4:30:00 AM	0.4
7/15/2014	4:45:00 AM	0.4
7/15/2014	5:00:00 AM	0.4
7/15/2014	5:15:00 AM	0.4
7/15/2014	5:30:00 AM	0.4
7/15/2014	5:45:00 AM	0.4
7/15/2014	6:00:00 AM	0.4
7/15/2014	6:15:00 AM	0.4
7/15/2014	6:30:00 AM	0.4
7/15/2014	6:45:00 AM	0.4
7/15/2014	7:00:00 AM	0.4
7/15/2014	7:15:00 AM	0.4
7/15/2014	7:30:00 AM	0.4
7/15/2014	7:45:00 AM	0.4
7/15/2014	8:00:00 AM	0.4
7/15/2014	8:15:00 AM	0.4
7/15/2014	8:30:00 AM	0.4
7/15/2014	8:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/15/2014	9:00:00 AM	0.4
7/15/2014	9:15:00 AM	0.4
7/15/2014	9:30:00 AM	0.41
7/15/2014	9:45:00 AM	0.4
7/15/2014	10:00:00 AM	0.4
7/15/2014	10:15:00 AM	0.4
7/15/2014	10:30:00 AM	0.4
7/15/2014	10:45:00 AM	0.4
7/15/2014	11:00:00 AM	0.4
7/15/2014	11:15:00 AM	0.4
7/15/2014	11:30:00 AM	0.4
7/15/2014	11:45:00 AM	0.4
7/15/2014	12:00:00 PM	0.4
7/15/2014	12:15:00 PM	0.4
7/15/2014	12:30:00 PM	0.41
7/15/2014	12:45:00 PM	0.4
7/15/2014	1:00:00 PM	0.4
7/15/2014	1:15:00 PM	0.4
7/15/2014	1:30:00 PM	0.4
7/15/2014	1:45:00 PM	0.4
7/15/2014	2:00:00 PM	0.4
7/15/2014	2:15:00 PM	0.4
7/15/2014	2:30:00 PM	0.4
7/15/2014	2:45:00 PM	0.4
7/15/2014	3:00:00 PM	0.4
7/15/2014	3:15:00 PM	0.4
7/15/2014	3:30:00 PM	0.4
7/15/2014	3:45:00 PM	0.4
7/15/2014	4:00:00 PM	0.39
7/15/2014	4:15:00 PM	0.39
7/15/2014	4:30:00 PM	0.39
7/15/2014	4:45:00 PM	0.39
7/15/2014	5:00:00 PM	0.39
7/15/2014	5:15:00 PM	0.39
7/15/2014	5:30:00 PM	0.39
7/15/2014	5:45:00 PM	0.39
7/15/2014	6:00:00 PM	0.39
7/15/2014	6:15:00 PM	0.39
7/15/2014	6:30:00 PM	0.38
7/15/2014	6:45:00 PM	0.38
7/15/2014	7:00:00 PM	0.38
7/15/2014	7:15:00 PM	0.38
7/15/2014	7:30:00 PM	0.38
7/15/2014	7:45:00 PM	0.38
7/15/2014	8:00:00 PM	0.38
7/15/2014	8:15:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/15/2014	8:30:00 PM	0.4
7/15/2014	8:45:00 PM	0.4
7/15/2014	9:00:00 PM	0.39
7/15/2014	9:15:00 PM	0.4
7/15/2014	9:30:00 PM	0.4
7/15/2014	9:45:00 PM	0.4
7/15/2014	10:00:00 PM	0.4
7/15/2014	10:15:00 PM	0.4
7/15/2014	10:30:00 PM	0.4
7/15/2014	10:45:00 PM	0.4
7/15/2014	11:00:00 PM	0.4
7/15/2014	11:15:00 PM	0.4
7/15/2014	11:30:00 PM	0.4
7/15/2014	11:45:00 PM	0.4
7/16/2014	12:00:00 AM	0.4
7/16/2014	12:15:00 AM	0.4
7/16/2014	12:30:00 AM	0.4
7/16/2014	12:45:00 AM	0.4
7/16/2014	1:00:00 AM	0.4
7/16/2014	1:15:00 AM	0.4
7/16/2014	1:30:00 AM	0.4
7/16/2014	1:45:00 AM	0.4
7/16/2014	2:00:00 AM	0.4
7/16/2014	2:15:00 AM	0.4
7/16/2014	2:30:00 AM	0.4
7/16/2014	2:45:00 AM	0.4
7/16/2014	3:00:00 AM	0.4
7/16/2014	3:15:00 AM	0.4
7/16/2014	3:30:00 AM	0.4
7/16/2014	3:45:00 AM	0.4
7/16/2014	4:00:00 AM	0.4
7/16/2014	4:15:00 AM	0.41
7/16/2014	4:30:00 AM	0.41
7/16/2014	4:45:00 AM	0.41
7/16/2014	5:00:00 AM	0.41
7/16/2014	5:15:00 AM	0.41
7/16/2014	5:30:00 AM	0.41
7/16/2014	5:45:00 AM	0.41
7/16/2014	6:00:00 AM	0.42
7/16/2014	6:15:00 AM	0.42
7/16/2014	6:30:00 AM	0.42
7/16/2014	6:45:00 AM	0.42
7/16/2014	7:00:00 AM	0.42
7/16/2014	7:15:00 AM	0.42
7/16/2014	7:30:00 AM	0.42
7/16/2014	7:45:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/16/2014	8:00:00 AM	0.42
7/16/2014	8:15:00 AM	0.42
7/16/2014	8:30:00 AM	0.42
7/16/2014	8:45:00 AM	0.42
7/16/2014	9:00:00 AM	0.43
7/16/2014	9:15:00 AM	0.43
7/16/2014	9:30:00 AM	0.43
7/16/2014	9:45:00 AM	0.43
7/16/2014	10:00:00 AM	0.43
7/16/2014	10:15:00 AM	0.43
7/16/2014	10:30:00 AM	0.43
7/16/2014	10:45:00 AM	0.43
7/16/2014	11:00:00 AM	0.43
7/16/2014	11:15:00 AM	0.43
7/16/2014	11:30:00 AM	0.43
7/16/2014	11:45:00 AM	0.43
7/16/2014	12:00:00 PM	0.43
7/16/2014	12:15:00 PM	0.43
7/16/2014	12:30:00 PM	0.42
7/16/2014	12:45:00 PM	0.43
7/16/2014	1:00:00 PM	0.43
7/16/2014	1:15:00 PM	0.42
7/16/2014	1:30:00 PM	0.42
7/16/2014	1:45:00 PM	0.41
7/16/2014	2:00:00 PM	0.42
7/16/2014	2:15:00 PM	0.41
7/16/2014	2:30:00 PM	0.41
7/16/2014	2:45:00 PM	0.41
7/16/2014	3:00:00 PM	0.41
7/16/2014	3:15:00 PM	0.41
7/16/2014	3:30:00 PM	0.41
7/16/2014	3:45:00 PM	0.41
7/16/2014	4:00:00 PM	0.41
7/16/2014	4:15:00 PM	0.41
7/16/2014	4:30:00 PM	0.41
7/16/2014	4:45:00 PM	0.41
7/16/2014	5:00:00 PM	0.41
7/16/2014	5:15:00 PM	0.41
7/16/2014	5:30:00 PM	0.41
7/16/2014	5:45:00 PM	0.41
7/16/2014	6:00:00 PM	0.41
7/16/2014	6:15:00 PM	0.41
7/16/2014	6:30:00 PM	0.41
7/16/2014	6:45:00 PM	0.41
7/16/2014	7:00:00 PM	0.41
7/16/2014	7:15:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/16/2014	7:30:00 PM	0.41
7/16/2014	7:45:00 PM	0.41
7/16/2014	8:00:00 PM	0.41
7/16/2014	8:15:00 PM	0.41
7/16/2014	8:30:00 PM	0.41
7/16/2014	8:45:00 PM	0.41
7/16/2014	9:00:00 PM	0.41
7/16/2014	9:15:00 PM	0.41
7/16/2014	9:30:00 PM	0.41
7/16/2014	9:45:00 PM	0.41
7/16/2014	10:00:00 PM	0.42
7/16/2014	10:15:00 PM	0.42
7/16/2014	10:30:00 PM	0.42
7/16/2014	10:45:00 PM	0.42
7/16/2014	11:00:00 PM	0.42
7/16/2014	11:15:00 PM	0.42
7/16/2014	11:30:00 PM	0.42
7/16/2014	11:45:00 PM	0.42
7/17/2014	12:00:00 AM	0.42
7/17/2014	12:15:00 AM	0.42
7/17/2014	12:30:00 AM	0.42
7/17/2014	12:45:00 AM	0.42
7/17/2014	1:00:00 AM	0.42
7/17/2014	1:15:00 AM	0.42
7/17/2014	1:30:00 AM	0.42
7/17/2014	1:45:00 AM	0.42
7/17/2014	2:00:00 AM	0.42
7/17/2014	2:15:00 AM	0.43
7/17/2014	2:30:00 AM	0.43
7/17/2014	2:45:00 AM	0.43
7/17/2014	3:00:00 AM	0.43
7/17/2014	3:15:00 AM	0.43
7/17/2014	3:30:00 AM	0.43
7/17/2014	3:45:00 AM	0.43
7/17/2014	4:00:00 AM	0.43
7/17/2014	4:15:00 AM	0.43
7/17/2014	4:30:00 AM	0.43
7/17/2014	4:45:00 AM	0.43
7/17/2014	5:00:00 AM	0.43
7/17/2014	5:15:00 AM	0.43
7/17/2014	5:30:00 AM	0.43
7/17/2014	5:45:00 AM	0.43
7/17/2014	6:00:00 AM	0.43
7/17/2014	6:15:00 AM	0.43
7/17/2014	6:30:00 AM	0.43
7/17/2014	6:45:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/17/2014	7:00:00 AM	0.44
7/17/2014	7:15:00 AM	0.44
7/17/2014	7:30:00 AM	0.44
7/17/2014	7:45:00 AM	0.44
7/17/2014	8:00:00 AM	0.44
7/17/2014	8:15:00 AM	0.44
7/17/2014	8:30:00 AM	0.44
7/17/2014	8:45:00 AM	0.44
7/17/2014	9:00:00 AM	0.44
7/17/2014	9:15:00 AM	0.44
7/17/2014	9:30:00 AM	0.44
7/17/2014	9:45:00 AM	0.44
7/17/2014	10:00:00 AM	0.44
7/17/2014	10:15:00 AM	0.44
7/17/2014	10:30:00 AM	0.44
7/17/2014	10:45:00 AM	0.44
7/17/2014	11:00:00 AM	0.44
7/17/2014	11:15:00 AM	0.44
7/17/2014	11:30:00 AM	0.44
7/17/2014	11:45:00 AM	0.43
7/17/2014	12:00:00 PM	0.43
7/17/2014	12:15:00 PM	0.43
7/17/2014	12:30:00 PM	0.43
7/17/2014	12:45:00 PM	0.43
7/17/2014	1:00:00 PM	0.43
7/17/2014	1:15:00 PM	0.43
7/17/2014	1:30:00 PM	0.43
7/17/2014	1:45:00 PM	0.43
7/17/2014	2:00:00 PM	0.42
7/17/2014	2:15:00 PM	0.42
7/17/2014	2:30:00 PM	0.43
7/17/2014	2:45:00 PM	0.43
7/17/2014	3:00:00 PM	0.41
7/17/2014	3:15:00 PM	0.41
7/17/2014	3:30:00 PM	0.42
7/17/2014	3:45:00 PM	0.41
7/17/2014	4:00:00 PM	0.41
7/17/2014	4:15:00 PM	0.41
7/17/2014	4:30:00 PM	0.41
7/17/2014	4:45:00 PM	0.41
7/17/2014	5:00:00 PM	0.41
7/17/2014	5:15:00 PM	0.41
7/17/2014	5:30:00 PM	0.41
7/17/2014	5:45:00 PM	0.41
7/17/2014	6:00:00 PM	0.41
7/17/2014	6:15:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/17/2014	6:30:00 PM	0.41
7/17/2014	6:45:00 PM	0.41
7/17/2014	7:00:00 PM	0.41
7/17/2014	7:15:00 PM	0.41
7/17/2014	7:30:00 PM	0.41
7/17/2014	7:45:00 PM	0.41
7/17/2014	8:00:00 PM	0.41
7/17/2014	8:15:00 PM	0.42
7/17/2014	8:30:00 PM	0.41
7/17/2014	8:45:00 PM	0.41
7/17/2014	9:00:00 PM	0.41
7/17/2014	9:15:00 PM	0.41
7/17/2014	9:30:00 PM	0.41
7/17/2014	9:45:00 PM	0.41
7/17/2014	10:00:00 PM	0.41
7/17/2014	10:15:00 PM	0.42
7/17/2014	10:30:00 PM	0.42
7/17/2014	10:45:00 PM	0.42
7/17/2014	11:00:00 PM	0.43
7/17/2014	11:15:00 PM	0.43
7/17/2014	11:30:00 PM	0.43
7/17/2014	11:45:00 PM	0.43
7/18/2014	12:00:00 AM	0.43
7/18/2014	12:15:00 AM	0.43
7/18/2014	12:30:00 AM	0.43
7/18/2014	12:45:00 AM	0.43
7/18/2014	1:00:00 AM	0.43
7/18/2014	1:15:00 AM	0.43
7/18/2014	1:30:00 AM	0.43
7/18/2014	1:45:00 AM	0.43
7/18/2014	2:00:00 AM	0.43
7/18/2014	2:15:00 AM	0.43
7/18/2014	2:30:00 AM	0.43
7/18/2014	2:45:00 AM	0.43
7/18/2014	3:00:00 AM	0.43
7/18/2014	3:15:00 AM	0.43
7/18/2014	3:30:00 AM	0.43
7/18/2014	3:45:00 AM	0.43
7/18/2014	4:00:00 AM	0.43
7/18/2014	4:15:00 AM	0.43
7/18/2014	4:30:00 AM	0.43
7/18/2014	4:45:00 AM	0.43
7/18/2014	5:00:00 AM	0.43
7/18/2014	5:15:00 AM	0.43
7/18/2014	5:30:00 AM	0.43
7/18/2014	5:45:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/18/2014	6:00:00 AM	0.43
7/18/2014	6:15:00 AM	0.43
7/18/2014	6:30:00 AM	0.43
7/18/2014	6:45:00 AM	0.43
7/18/2014	7:00:00 AM	0.43
7/18/2014	7:15:00 AM	0.43
7/18/2014	7:30:00 AM	0.43
7/18/2014	7:45:00 AM	0.43
7/18/2014	8:00:00 AM	0.43
7/18/2014	8:15:00 AM	0.43
7/18/2014	8:30:00 AM	0.43
7/18/2014	8:45:00 AM	0.43
7/18/2014	9:00:00 AM	0.43
7/18/2014	9:15:00 AM	0.43
7/18/2014	9:30:00 AM	0.43
7/18/2014	9:45:00 AM	0.44
7/18/2014	10:00:00 AM	0.44
7/18/2014	10:15:00 AM	0.44
7/18/2014	10:30:00 AM	0.44
7/18/2014	10:45:00 AM	0.44
7/18/2014	11:00:00 AM	0.43
7/18/2014	11:15:00 AM	0.43
7/18/2014	11:30:00 AM	0.43
7/18/2014	11:45:00 AM	0.43
7/18/2014	12:00:00 PM	0.43
7/18/2014	12:15:00 PM	0.43
7/18/2014	12:30:00 PM	0.43
7/18/2014	12:45:00 PM	0.43
7/18/2014	1:00:00 PM	0.43
7/18/2014	1:15:00 PM	0.43
7/18/2014	1:30:00 PM	0.42
7/18/2014	1:45:00 PM	0.42
7/18/2014	2:00:00 PM	0.42
7/18/2014	2:15:00 PM	0.42
7/18/2014	2:30:00 PM	0.41
7/18/2014	2:45:00 PM	0.41
7/18/2014	3:00:00 PM	0.41
7/18/2014	3:15:00 PM	0.41
7/18/2014	3:30:00 PM	0.41
7/18/2014	3:45:00 PM	0.41
7/18/2014	4:00:00 PM	0.41
7/18/2014	4:15:00 PM	0.41
7/18/2014	4:30:00 PM	0.41
7/18/2014	4:45:00 PM	0.41
7/18/2014	5:00:00 PM	0.41
7/18/2014	5:15:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/18/2014	5:30:00 PM	0.41
7/18/2014	5:45:00 PM	0.41
7/18/2014	6:00:00 PM	0.41
7/18/2014	6:15:00 PM	0.4
7/18/2014	6:30:00 PM	0.4
7/18/2014	6:45:00 PM	0.4
7/18/2014	7:00:00 PM	0.4
7/18/2014	7:15:00 PM	0.4
7/18/2014	7:30:00 PM	0.4
7/18/2014	7:45:00 PM	0.4
7/18/2014	8:00:00 PM	0.4
7/18/2014	8:15:00 PM	0.4
7/18/2014	8:30:00 PM	0.4
7/18/2014	8:45:00 PM	0.4
7/18/2014	9:00:00 PM	0.4
7/18/2014	9:15:00 PM	0.4
7/18/2014	9:30:00 PM	0.4
7/18/2014	9:45:00 PM	0.4
7/18/2014	10:00:00 PM	0.4
7/18/2014	10:15:00 PM	0.4
7/18/2014	10:30:00 PM	0.41
7/18/2014	10:45:00 PM	0.41
7/18/2014	11:00:00 PM	0.41
7/18/2014	11:15:00 PM	0.41
7/18/2014	11:30:00 PM	0.41
7/18/2014	11:45:00 PM	0.41
7/19/2014	12:00:00 AM	0.41
7/19/2014	12:15:00 AM	0.41
7/19/2014	12:30:00 AM	0.41
7/19/2014	12:45:00 AM	0.41
7/19/2014	1:00:00 AM	0.41
7/19/2014	1:15:00 AM	0.41
7/19/2014	1:30:00 AM	0.41
7/19/2014	1:45:00 AM	0.41
7/19/2014	2:00:00 AM	0.41
7/19/2014	2:15:00 AM	0.41
7/19/2014	2:30:00 AM	0.41
7/19/2014	2:45:00 AM	0.41
7/19/2014	3:00:00 AM	0.41
7/19/2014	3:15:00 AM	0.41
7/19/2014	3:30:00 AM	0.41
7/19/2014	3:45:00 AM	0.41
7/19/2014	4:00:00 AM	0.41
7/19/2014	4:15:00 AM	0.41
7/19/2014	4:30:00 AM	0.41
7/19/2014	4:45:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/19/2014	5:00:00 AM	0.42
7/19/2014	5:15:00 AM	0.42
7/19/2014	5:30:00 AM	0.42
7/19/2014	5:45:00 AM	0.42
7/19/2014	6:00:00 AM	0.42
7/19/2014	6:15:00 AM	0.42
7/19/2014	6:30:00 AM	0.42
7/19/2014	6:45:00 AM	0.42
7/19/2014	7:00:00 AM	0.42
7/19/2014	7:15:00 AM	0.42
7/19/2014	7:30:00 AM	0.42
7/19/2014	7:45:00 AM	0.42
7/19/2014	8:00:00 AM	0.42
7/19/2014	8:15:00 AM	0.42
7/19/2014	8:30:00 AM	0.42
7/19/2014	8:45:00 AM	0.42
7/19/2014	9:00:00 AM	0.42
7/19/2014	9:15:00 AM	0.43
7/19/2014	9:30:00 AM	0.43
7/19/2014	9:45:00 AM	0.43
7/19/2014	10:00:00 AM	0.43
7/19/2014	10:15:00 AM	0.43
7/19/2014	10:30:00 AM	0.43
7/19/2014	10:45:00 AM	0.42
7/19/2014	11:00:00 AM	0.42
7/19/2014	11:15:00 AM	0.42
7/19/2014	11:30:00 AM	0.41
7/19/2014	11:45:00 AM	0.41
7/19/2014	12:00:00 PM	0.41
7/19/2014	12:15:00 PM	0.41
7/19/2014	12:30:00 PM	0.41
7/19/2014	12:45:00 PM	0.41
7/19/2014	1:00:00 PM	0.41
7/19/2014	1:15:00 PM	0.41
7/19/2014	1:30:00 PM	0.41
7/19/2014	1:45:00 PM	0.41
7/19/2014	2:00:00 PM	0.41
7/19/2014	2:15:00 PM	0.41
7/19/2014	2:30:00 PM	0.41
7/19/2014	2:45:00 PM	0.4
7/19/2014	3:00:00 PM	0.4
7/19/2014	3:15:00 PM	0.4
7/19/2014	3:30:00 PM	0.41
7/19/2014	3:45:00 PM	0.4
7/19/2014	4:00:00 PM	0.39
7/19/2014	4:15:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
7/19/2014	4:30:00 PM	0.39
7/19/2014	4:45:00 PM	0.39
7/19/2014	5:00:00 PM	0.39
7/19/2014	5:15:00 PM	0.39
7/19/2014	5:30:00 PM	0.39
7/19/2014	5:45:00 PM	0.39
7/19/2014	6:00:00 PM	0.39
7/19/2014	6:15:00 PM	0.39
7/19/2014	6:30:00 PM	0.39
7/19/2014	6:45:00 PM	0.39
7/19/2014	7:00:00 PM	0.39
7/19/2014	7:15:00 PM	0.39
7/19/2014	7:30:00 PM	0.39
7/19/2014	7:45:00 PM	0.39
7/19/2014	8:00:00 PM	0.39
7/19/2014	8:15:00 PM	0.39
7/19/2014	8:30:00 PM	0.39
7/19/2014	8:45:00 PM	0.39
7/19/2014	9:00:00 PM	0.39
7/19/2014	9:15:00 PM	0.39
7/19/2014	9:30:00 PM	0.39
7/19/2014	9:45:00 PM	0.39
7/19/2014	10:00:00 PM	0.39
7/19/2014	10:15:00 PM	0.39
7/19/2014	10:30:00 PM	0.39
7/19/2014	10:45:00 PM	0.39
7/19/2014	11:00:00 PM	0.39
7/19/2014	11:15:00 PM	0.4
7/19/2014	11:30:00 PM	0.4
7/19/2014	11:45:00 PM	0.4
7/20/2014	12:00:00 AM	0.4
7/20/2014	12:15:00 AM	0.4
7/20/2014	12:30:00 AM	0.4
7/20/2014	12:45:00 AM	0.4
7/20/2014	1:00:00 AM	0.4
7/20/2014	1:15:00 AM	0.4
7/20/2014	1:30:00 AM	0.4
7/20/2014	1:45:00 AM	0.4
7/20/2014	2:00:00 AM	0.4
7/20/2014	2:15:00 AM	0.41
7/20/2014	2:30:00 AM	0.41
7/20/2014	2:45:00 AM	0.41
7/20/2014	3:00:00 AM	0.41
7/20/2014	3:15:00 AM	0.41
7/20/2014	3:30:00 AM	0.41
7/20/2014	3:45:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/20/2014	4:00:00 AM	0.41
7/20/2014	4:15:00 AM	0.41
7/20/2014	4:30:00 AM	0.41
7/20/2014	4:45:00 AM	0.41
7/20/2014	5:00:00 AM	0.41
7/20/2014	5:15:00 AM	0.41
7/20/2014	5:30:00 AM	0.41
7/20/2014	5:45:00 AM	0.41
7/20/2014	6:00:00 AM	0.41
7/20/2014	6:15:00 AM	0.41
7/20/2014	6:30:00 AM	0.41
7/20/2014	6:45:00 AM	0.41
7/20/2014	7:00:00 AM	0.41
7/20/2014	7:15:00 AM	0.41
7/20/2014	7:30:00 AM	0.41
7/20/2014	7:45:00 AM	0.41
7/20/2014	8:00:00 AM	0.41
7/20/2014	8:15:00 AM	0.41
7/20/2014	8:30:00 AM	0.41
7/20/2014	8:45:00 AM	0.41
7/20/2014	9:00:00 AM	0.41
7/20/2014	9:15:00 AM	0.42
7/20/2014	9:30:00 AM	0.42
7/20/2014	9:45:00 AM	0.42
7/20/2014	10:00:00 AM	0.42
7/20/2014	10:15:00 AM	0.42
7/20/2014	10:30:00 AM	0.41
7/20/2014	10:45:00 AM	0.41
7/20/2014	11:00:00 AM	0.41
7/20/2014	11:15:00 AM	0.41
7/20/2014	11:30:00 AM	0.41
7/20/2014	11:45:00 AM	0.41
7/20/2014	12:00:00 PM	0.41
7/20/2014	12:15:00 PM	0.41
7/20/2014	12:30:00 PM	0.41
7/20/2014	12:45:00 PM	0.41
7/20/2014	1:00:00 PM	0.41
7/20/2014	1:15:00 PM	0.41
7/20/2014	1:30:00 PM	0.41
7/20/2014	1:45:00 PM	0.41
7/20/2014	2:00:00 PM	0.41
7/20/2014	2:15:00 PM	0.41
7/20/2014	2:30:00 PM	0.41
7/20/2014	2:45:00 PM	0.41
7/20/2014	3:00:00 PM	0.4
7/20/2014	3:15:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/20/2014	3:30:00 PM	0.41
7/20/2014	3:45:00 PM	0.41
7/20/2014	4:00:00 PM	0.41
7/20/2014	4:15:00 PM	0.4
7/20/2014	4:30:00 PM	0.4
7/20/2014	4:45:00 PM	0.4
7/20/2014	5:00:00 PM	0.4
7/20/2014	5:15:00 PM	0.41
7/20/2014	5:30:00 PM	0.41
7/20/2014	5:45:00 PM	0.41
7/20/2014	6:00:00 PM	0.41
7/20/2014	6:15:00 PM	0.41
7/20/2014	6:30:00 PM	0.41
7/20/2014	6:45:00 PM	0.41
7/20/2014	7:00:00 PM	0.41
7/20/2014	7:15:00 PM	0.41
7/20/2014	7:30:00 PM	0.41
7/20/2014	7:45:00 PM	0.41
7/20/2014	8:00:00 PM	0.41
7/20/2014	8:15:00 PM	0.41
7/20/2014	8:30:00 PM	0.41
7/20/2014	8:45:00 PM	0.41
7/20/2014	9:00:00 PM	0.41
7/20/2014	9:15:00 PM	0.41
7/20/2014	9:30:00 PM	0.41
7/20/2014	9:45:00 PM	0.41
7/20/2014	10:00:00 PM	0.41
7/20/2014	10:15:00 PM	0.41
7/20/2014	10:30:00 PM	0.41
7/20/2014	10:45:00 PM	0.41
7/20/2014	11:00:00 PM	0.41
7/20/2014	11:15:00 PM	0.41
7/20/2014	11:30:00 PM	0.41
7/20/2014	11:45:00 PM	0.41
7/21/2014	12:00:00 AM	0.41
7/21/2014	12:15:00 AM	0.41
7/21/2014	12:30:00 AM	0.41
7/21/2014	12:45:00 AM	0.41
7/21/2014	1:00:00 AM	0.41
7/21/2014	1:15:00 AM	0.41
7/21/2014	1:30:00 AM	0.41
7/21/2014	1:45:00 AM	0.41
7/21/2014	2:00:00 AM	0.41
7/21/2014	2:15:00 AM	0.41
7/21/2014	2:30:00 AM	0.41
7/21/2014	2:45:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/21/2014	3:00:00 AM	0.41
7/21/2014	3:15:00 AM	0.42
7/21/2014	3:30:00 AM	0.42
7/21/2014	3:45:00 AM	0.42
7/21/2014	4:00:00 AM	0.42
7/21/2014	4:15:00 AM	0.42
7/21/2014	4:30:00 AM	0.42
7/21/2014	4:45:00 AM	0.42
7/21/2014	5:00:00 AM	0.42
7/21/2014	5:15:00 AM	0.43
7/21/2014	5:30:00 AM	0.43
7/21/2014	5:45:00 AM	0.43
7/21/2014	6:00:00 AM	0.43
7/21/2014	6:15:00 AM	0.43
7/21/2014	6:30:00 AM	0.43
7/21/2014	6:45:00 AM	0.43
7/21/2014	7:00:00 AM	0.43
7/21/2014	7:15:00 AM	0.43
7/21/2014	7:30:00 AM	0.43
7/21/2014	7:45:00 AM	0.43
7/21/2014	8:00:00 AM	0.43
7/21/2014	8:15:00 AM	0.43
7/21/2014	8:30:00 AM	0.43
7/21/2014	8:45:00 AM	0.43
7/21/2014	9:00:00 AM	0.43
7/21/2014	9:15:00 AM	0.43
7/21/2014	9:30:00 AM	0.43
7/21/2014	9:45:00 AM	0.43
7/21/2014	10:00:00 AM	0.43
7/21/2014	10:15:00 AM	0.43
7/21/2014	10:30:00 AM	0.43
7/21/2014	10:45:00 AM	0.43
7/21/2014	11:00:00 AM	0.43
7/21/2014	11:15:00 AM	0.43
7/21/2014	11:30:00 AM	0.43
7/21/2014	11:45:00 AM	0.43
7/21/2014	12:00:00 PM	0.43
7/21/2014	12:15:00 PM	0.43
7/21/2014	12:30:00 PM	0.43
7/21/2014	12:45:00 PM	0.43
7/21/2014	1:00:00 PM	0.43
7/21/2014	1:15:00 PM	0.43
7/21/2014	1:30:00 PM	0.43
7/21/2014	1:45:00 PM	0.42
7/21/2014	2:00:00 PM	0.42
7/21/2014	2:15:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/21/2014	2:30:00 PM	0.42
7/21/2014	2:45:00 PM	0.41
7/21/2014	3:00:00 PM	0.41
7/21/2014	3:15:00 PM	0.41
7/21/2014	3:30:00 PM	0.41
7/21/2014	3:45:00 PM	0.42
7/21/2014	4:00:00 PM	0.41
7/21/2014	4:15:00 PM	0.41
7/21/2014	4:30:00 PM	0.41
7/21/2014	4:45:00 PM	0.41
7/21/2014	5:00:00 PM	0.41
7/21/2014	5:15:00 PM	0.41
7/21/2014	5:30:00 PM	0.41
7/21/2014	5:45:00 PM	0.41
7/21/2014	6:00:00 PM	0.41
7/21/2014	6:15:00 PM	0.41
7/21/2014	6:30:00 PM	0.41
7/21/2014	6:45:00 PM	0.41
7/21/2014	7:00:00 PM	0.41
7/21/2014	7:15:00 PM	0.41
7/21/2014	7:30:00 PM	0.41
7/21/2014	7:45:00 PM	0.41
7/21/2014	8:00:00 PM	0.41
7/21/2014	8:15:00 PM	0.41
7/21/2014	8:30:00 PM	0.41
7/21/2014	8:45:00 PM	0.41
7/21/2014	9:00:00 PM	0.41
7/21/2014	9:15:00 PM	0.41
7/21/2014	9:30:00 PM	0.42
7/21/2014	9:45:00 PM	0.42
7/21/2014	10:00:00 PM	0.42
7/21/2014	10:15:00 PM	0.42
7/21/2014	10:30:00 PM	0.42
7/21/2014	10:45:00 PM	0.42
7/21/2014	11:00:00 PM	0.42
7/21/2014	11:15:00 PM	0.43
7/21/2014	11:30:00 PM	0.43
7/21/2014	11:45:00 PM	0.43
7/22/2014	12:00:00 AM	0.43
7/22/2014	12:15:00 AM	0.43
7/22/2014	12:30:00 AM	0.43
7/22/2014	12:45:00 AM	0.43
7/22/2014	1:00:00 AM	0.43
7/22/2014	1:15:00 AM	0.43
7/22/2014	1:30:00 AM	0.43
7/22/2014	1:45:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/22/2014	2:00:00 AM	0.43
7/22/2014	2:15:00 AM	0.43
7/22/2014	2:30:00 AM	0.43
7/22/2014	2:45:00 AM	0.43
7/22/2014	3:00:00 AM	0.43
7/22/2014	3:15:00 AM	0.43
7/22/2014	3:30:00 AM	0.43
7/22/2014	3:45:00 AM	0.43
7/22/2014	4:00:00 AM	0.43
7/22/2014	4:15:00 AM	0.43
7/22/2014	4:30:00 AM	0.43
7/22/2014	4:45:00 AM	0.43
7/22/2014	5:00:00 AM	0.43
7/22/2014	5:15:00 AM	0.43
7/22/2014	5:30:00 AM	0.44
7/22/2014	5:45:00 AM	0.44
7/22/2014	6:00:00 AM	0.44
7/22/2014	6:15:00 AM	0.44
7/22/2014	6:30:00 AM	0.44
7/22/2014	6:45:00 AM	0.44
7/22/2014	7:00:00 AM	0.44
7/22/2014	7:15:00 AM	0.44
7/22/2014	7:30:00 AM	0.44
7/22/2014	7:45:00 AM	0.44
7/22/2014	8:00:00 AM	0.44
7/22/2014	8:15:00 AM	0.44
7/22/2014	8:30:00 AM	0.44
7/22/2014	8:45:00 AM	0.44
7/22/2014	9:00:00 AM	0.44
7/22/2014	9:15:00 AM	0.44
7/22/2014	9:30:00 AM	0.44
7/22/2014	9:45:00 AM	0.44
7/22/2014	10:00:00 AM	0.44
7/22/2014	10:15:00 AM	0.44
7/22/2014	10:30:00 AM	0.44
7/22/2014	10:45:00 AM	0.44
7/22/2014	11:00:00 AM	0.44
7/22/2014	11:15:00 AM	0.44
7/22/2014	11:30:00 AM	0.44
7/22/2014	11:45:00 AM	0.43
7/22/2014	12:00:00 PM	0.43
7/22/2014	12:15:00 PM	0.43
7/22/2014	12:30:00 PM	0.43
7/22/2014	12:45:00 PM	0.43
7/22/2014	1:00:00 PM	0.43
7/22/2014	1:15:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/22/2014	1:30:00 PM	0.43
7/22/2014	1:45:00 PM	0.43
7/22/2014	2:00:00 PM	0.43
7/22/2014	2:15:00 PM	0.43
7/22/2014	2:30:00 PM	0.42
7/22/2014	2:45:00 PM	0.43
7/22/2014	3:00:00 PM	0.42
7/22/2014	3:15:00 PM	0.42
7/22/2014	3:30:00 PM	0.41
7/22/2014	3:45:00 PM	0.42
7/22/2014	4:00:00 PM	0.42
7/22/2014	4:15:00 PM	0.41
7/22/2014	4:30:00 PM	0.41
7/22/2014	4:45:00 PM	0.41
7/22/2014	5:00:00 PM	0.41
7/22/2014	5:15:00 PM	0.41
7/22/2014	5:30:00 PM	0.41
7/22/2014	5:45:00 PM	0.41
7/22/2014	6:00:00 PM	0.41
7/22/2014	6:15:00 PM	0.41
7/22/2014	6:30:00 PM	0.41
7/22/2014	6:45:00 PM	0.41
7/22/2014	7:00:00 PM	0.41
7/22/2014	7:15:00 PM	0.41
7/22/2014	7:30:00 PM	0.41
7/22/2014	7:45:00 PM	0.41
7/22/2014	8:00:00 PM	0.41
7/22/2014	8:15:00 PM	0.41
7/22/2014	8:30:00 PM	0.41
7/22/2014	8:45:00 PM	0.41
7/22/2014	9:00:00 PM	0.41
7/22/2014	9:15:00 PM	0.41
7/22/2014	9:30:00 PM	0.41
7/22/2014	9:45:00 PM	0.41
7/22/2014	10:00:00 PM	0.41
7/22/2014	10:15:00 PM	0.41
7/22/2014	10:30:00 PM	0.41
7/22/2014	10:45:00 PM	0.41
7/22/2014	11:00:00 PM	0.42
7/22/2014	11:15:00 PM	0.42
7/22/2014	11:30:00 PM	0.42
7/22/2014	11:45:00 PM	0.42
7/23/2014	12:00:00 AM	0.42
7/23/2014	12:15:00 AM	0.42
7/23/2014	12:30:00 AM	0.42
7/23/2014	12:45:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/23/2014	1:00:00 AM	0.42
7/23/2014	1:15:00 AM	0.42
7/23/2014	1:30:00 AM	0.42
7/23/2014	1:45:00 AM	0.42
7/23/2014	2:00:00 AM	0.42
7/23/2014	2:15:00 AM	0.42
7/23/2014	2:30:00 AM	0.43
7/23/2014	2:45:00 AM	0.43
7/23/2014	3:00:00 AM	0.43
7/23/2014	3:15:00 AM	0.43
7/23/2014	3:30:00 AM	0.43
7/23/2014	3:45:00 AM	0.43
7/23/2014	4:00:00 AM	0.43
7/23/2014	4:15:00 AM	0.43
7/23/2014	4:30:00 AM	0.43
7/23/2014	4:45:00 AM	0.43
7/23/2014	5:00:00 AM	0.43
7/23/2014	5:15:00 AM	0.43
7/23/2014	5:30:00 AM	0.43
7/23/2014	5:45:00 AM	0.43
7/23/2014	6:00:00 AM	0.43
7/23/2014	6:15:00 AM	0.43
7/23/2014	6:30:00 AM	0.43
7/23/2014	6:45:00 AM	0.43
7/23/2014	7:00:00 AM	0.43
7/23/2014	7:15:00 AM	0.43
7/23/2014	7:30:00 AM	0.43
7/23/2014	7:45:00 AM	0.43
7/23/2014	8:00:00 AM	0.43
7/23/2014	8:15:00 AM	0.43
7/23/2014	8:30:00 AM	0.43
7/23/2014	8:45:00 AM	0.43
7/23/2014	9:00:00 AM	0.44
7/23/2014	9:15:00 AM	0.43
7/23/2014	9:30:00 AM	0.43
7/23/2014	9:45:00 AM	0.43
7/23/2014	10:00:00 AM	0.43
7/23/2014	10:15:00 AM	0.43
7/23/2014	10:30:00 AM	0.43
7/23/2014	10:45:00 AM	0.43
7/23/2014	11:00:00 AM	0.43
7/23/2014	11:15:00 AM	0.43
7/23/2014	11:30:00 AM	0.43
7/23/2014	11:45:00 AM	0.43
7/23/2014	12:00:00 PM	0.43
7/23/2014	12:15:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/23/2014	12:30:00 PM	0.43
7/23/2014	12:45:00 PM	0.43
7/23/2014	1:00:00 PM	0.43
7/23/2014	1:15:00 PM	0.42
7/23/2014	1:30:00 PM	0.42
7/23/2014	1:45:00 PM	0.41
7/23/2014	2:00:00 PM	0.41
7/23/2014	2:15:00 PM	0.41
7/23/2014	2:30:00 PM	0.41
7/23/2014	2:45:00 PM	0.41
7/23/2014	3:00:00 PM	0.41
7/23/2014	3:15:00 PM	0.41
7/23/2014	3:30:00 PM	0.41
7/23/2014	3:45:00 PM	0.41
7/23/2014	4:00:00 PM	0.41
7/23/2014	4:15:00 PM	0.41
7/23/2014	4:30:00 PM	0.41
7/23/2014	4:45:00 PM	0.41
7/23/2014	5:00:00 PM	0.41
7/23/2014	5:15:00 PM	0.4
7/23/2014	5:30:00 PM	0.4
7/23/2014	5:45:00 PM	0.4
7/23/2014	6:00:00 PM	0.4
7/23/2014	6:15:00 PM	0.4
7/23/2014	6:30:00 PM	0.4
7/23/2014	6:45:00 PM	0.4
7/23/2014	7:00:00 PM	0.4
7/23/2014	7:15:00 PM	0.4
7/23/2014	7:30:00 PM	0.4
7/23/2014	7:45:00 PM	0.4
7/23/2014	8:00:00 PM	0.4
7/23/2014	8:15:00 PM	0.4
7/23/2014	8:30:00 PM	0.4
7/23/2014	8:45:00 PM	0.4
7/23/2014	9:00:00 PM	0.4
7/23/2014	9:15:00 PM	0.4
7/23/2014	9:30:00 PM	0.4
7/23/2014	9:45:00 PM	0.41
7/23/2014	10:00:00 PM	0.41
7/23/2014	10:15:00 PM	0.41
7/23/2014	10:30:00 PM	0.41
7/23/2014	10:45:00 PM	0.41
7/23/2014	11:00:00 PM	0.41
7/23/2014	11:15:00 PM	0.41
7/23/2014	11:30:00 PM	0.41
7/23/2014	11:45:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2014	12:00:00 AM	0.41
7/24/2014	12:15:00 AM	0.41
7/24/2014	12:30:00 AM	0.41
7/24/2014	12:45:00 AM	0.41
7/24/2014	1:00:00 AM	0.41
7/24/2014	1:15:00 AM	0.41
7/24/2014	1:30:00 AM	0.41
7/24/2014	1:45:00 AM	0.41
7/24/2014	2:00:00 AM	0.41
7/24/2014	2:15:00 AM	0.41
7/24/2014	2:30:00 AM	0.41
7/24/2014	2:45:00 AM	0.41
7/24/2014	3:00:00 AM	0.41
7/24/2014	3:15:00 AM	0.41
7/24/2014	3:30:00 AM	0.41
7/24/2014	3:45:00 AM	0.41
7/24/2014	4:00:00 AM	0.41
7/24/2014	4:15:00 AM	0.41
7/24/2014	4:30:00 AM	0.41
7/24/2014	4:45:00 AM	0.41
7/24/2014	5:00:00 AM	0.41
7/24/2014	5:15:00 AM	0.41
7/24/2014	5:30:00 AM	0.41
7/24/2014	5:45:00 AM	0.41
7/24/2014	6:00:00 AM	0.42
7/24/2014	6:15:00 AM	0.42
7/24/2014	6:30:00 AM	0.42
7/24/2014	6:45:00 AM	0.42
7/24/2014	7:00:00 AM	0.42
7/24/2014	7:15:00 AM	0.42
7/24/2014	7:30:00 AM	0.42
7/24/2014	7:45:00 AM	0.42
7/24/2014	8:00:00 AM	0.42
7/24/2014	8:15:00 AM	0.42
7/24/2014	8:30:00 AM	0.42
7/24/2014	8:45:00 AM	0.42
7/24/2014	9:00:00 AM	0.43
7/24/2014	9:15:00 AM	0.43
7/24/2014	9:30:00 AM	0.43
7/24/2014	9:45:00 AM	0.43
7/24/2014	10:00:00 AM	0.43
7/24/2014	10:15:00 AM	0.42
7/24/2014	10:30:00 AM	0.42
7/24/2014	10:45:00 AM	0.42
7/24/2014	11:00:00 AM	0.42
7/24/2014	11:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2014	11:30:00 AM	0.42
7/24/2014	11:45:00 AM	0.42
7/24/2014	12:00:00 PM	0.42
7/24/2014	12:15:00 PM	0.41
7/24/2014	12:30:00 PM	0.41
7/24/2014	12:45:00 PM	0.41
7/24/2014	1:00:00 PM	0.41
7/24/2014	1:15:00 PM	0.41
7/24/2014	1:30:00 PM	0.41
7/24/2014	1:45:00 PM	0.41
7/24/2014	2:00:00 PM	0.41
7/24/2014	2:15:00 PM	0.41
7/24/2014	2:30:00 PM	0.41
7/24/2014	2:45:00 PM	0.41
7/24/2014	3:00:00 PM	0.4
7/24/2014	3:15:00 PM	0.4
7/24/2014	3:30:00 PM	0.4
7/24/2014	3:45:00 PM	0.4
7/24/2014	4:00:00 PM	0.4
7/24/2014	4:15:00 PM	0.39
7/24/2014	4:30:00 PM	0.39
7/24/2014	4:45:00 PM	0.39
7/24/2014	5:00:00 PM	0.39
7/24/2014	5:15:00 PM	0.39
7/24/2014	5:30:00 PM	0.39
7/24/2014	5:45:00 PM	0.39
7/24/2014	6:00:00 PM	0.39
7/24/2014	6:15:00 PM	0.39
7/24/2014	6:30:00 PM	0.39
7/24/2014	6:45:00 PM	0.39
7/24/2014	7:00:00 PM	0.39
7/24/2014	7:15:00 PM	0.39
7/24/2014	7:30:00 PM	0.39
7/24/2014	7:45:00 PM	0.39
7/24/2014	8:00:00 PM	0.39
7/24/2014	8:15:00 PM	0.39
7/24/2014	8:30:00 PM	0.39
7/24/2014	8:45:00 PM	0.39
7/24/2014	9:00:00 PM	0.39
7/24/2014	9:15:00 PM	0.39
7/24/2014	9:30:00 PM	0.39
7/24/2014	9:45:00 PM	0.39
7/24/2014	10:00:00 PM	0.39
7/24/2014	10:15:00 PM	0.4
7/24/2014	10:30:00 PM	0.4
7/24/2014	10:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2014	11:00:00 PM	0.4
7/24/2014	11:15:00 PM	0.4
7/24/2014	11:30:00 PM	0.4
7/24/2014	11:45:00 PM	0.4
7/25/2014	12:00:00 AM	0.4
7/25/2014	12:15:00 AM	0.4
7/25/2014	12:30:00 AM	0.4
7/25/2014	12:45:00 AM	0.4
7/25/2014	1:00:00 AM	0.4
7/25/2014	1:15:00 AM	0.4
7/25/2014	1:30:00 AM	0.4
7/25/2014	1:45:00 AM	0.41
7/25/2014	2:00:00 AM	0.41
7/25/2014	2:15:00 AM	0.41
7/25/2014	2:30:00 AM	0.41
7/25/2014	2:45:00 AM	0.41
7/25/2014	3:00:00 AM	0.41
7/25/2014	3:15:00 AM	0.41
7/25/2014	3:30:00 AM	0.41
7/25/2014	3:45:00 AM	0.41
7/25/2014	4:00:00 AM	0.41
7/25/2014	4:15:00 AM	0.41
7/25/2014	4:30:00 AM	0.41
7/25/2014	4:45:00 AM	0.41
7/25/2014	5:00:00 AM	0.41
7/25/2014	5:15:00 AM	0.41
7/25/2014	5:30:00 AM	0.41
7/25/2014	5:45:00 AM	0.41
7/25/2014	6:00:00 AM	0.41
7/25/2014	6:15:00 AM	0.41
7/25/2014	6:30:00 AM	0.41
7/25/2014	6:45:00 AM	0.41
7/25/2014	7:00:00 AM	0.41
7/25/2014	7:15:00 AM	0.41
7/25/2014	7:30:00 AM	0.41
7/25/2014	7:45:00 AM	0.41
7/25/2014	8:00:00 AM	0.41
7/25/2014	8:15:00 AM	0.41
7/25/2014	8:30:00 AM	0.41
7/25/2014	8:45:00 AM	0.42
7/25/2014	9:00:00 AM	0.42
7/25/2014	9:15:00 AM	0.42
7/25/2014	9:30:00 AM	0.42
7/25/2014	9:45:00 AM	0.42
7/25/2014	10:00:00 AM	0.42
7/25/2014	10:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/25/2014	10:30:00 AM	0.41
7/25/2014	10:45:00 AM	0.41
7/25/2014	11:00:00 AM	0.41
7/25/2014	11:15:00 AM	0.41
7/25/2014	11:30:00 AM	0.41
7/25/2014	11:45:00 AM	0.41
7/25/2014	12:00:00 PM	0.41
7/25/2014	12:15:00 PM	0.41
7/25/2014	12:30:00 PM	0.41
7/25/2014	12:45:00 PM	0.41
7/25/2014	1:00:00 PM	0.41
7/25/2014	1:15:00 PM	0.41
7/25/2014	1:30:00 PM	0.41
7/25/2014	1:45:00 PM	0.4
7/25/2014	2:00:00 PM	0.4
7/25/2014	2:15:00 PM	0.4
7/25/2014	2:30:00 PM	0.4
7/25/2014	2:45:00 PM	0.4
7/25/2014	3:00:00 PM	0.39
7/25/2014	3:15:00 PM	0.4
7/25/2014	3:30:00 PM	0.39
7/25/2014	3:45:00 PM	0.39
7/25/2014	4:00:00 PM	0.39
7/25/2014	4:15:00 PM	0.39
7/25/2014	4:30:00 PM	0.39
7/25/2014	4:45:00 PM	0.39
7/25/2014	5:00:00 PM	0.39
7/25/2014	5:15:00 PM	0.39
7/25/2014	5:30:00 PM	0.39
7/25/2014	5:45:00 PM	0.39
7/25/2014	6:00:00 PM	0.39
7/25/2014	6:15:00 PM	0.39
7/25/2014	6:30:00 PM	0.39
7/25/2014	6:45:00 PM	0.39
7/25/2014	7:00:00 PM	0.39
7/25/2014	7:15:00 PM	0.39
7/25/2014	7:30:00 PM	0.39
7/25/2014	7:45:00 PM	0.39
7/25/2014	8:00:00 PM	0.39
7/25/2014	8:15:00 PM	0.39
7/25/2014	8:30:00 PM	0.39
7/25/2014	8:45:00 PM	0.39
7/25/2014	9:00:00 PM	0.39
7/25/2014	9:15:00 PM	0.39
7/25/2014	9:30:00 PM	0.39
7/25/2014	9:45:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
7/25/2014	10:00:00 PM	0.39
7/25/2014	10:15:00 PM	0.39
7/25/2014	10:30:00 PM	0.39
7/25/2014	10:45:00 PM	0.39
7/25/2014	11:00:00 PM	0.39
7/25/2014	11:15:00 PM	0.39
7/25/2014	11:30:00 PM	0.39
7/25/2014	11:45:00 PM	0.39
7/26/2014	12:00:00 AM	0.39
7/26/2014	12:15:00 AM	0.39
7/26/2014	12:30:00 AM	0.39
7/26/2014	12:45:00 AM	0.39
7/26/2014	1:00:00 AM	0.39
7/26/2014	1:15:00 AM	0.39
7/26/2014	1:30:00 AM	0.39
7/26/2014	1:45:00 AM	0.39
7/26/2014	2:00:00 AM	0.39
7/26/2014	2:15:00 AM	0.39
7/26/2014	2:30:00 AM	0.39
7/26/2014	2:45:00 AM	0.39
7/26/2014	3:00:00 AM	0.39
7/26/2014	3:15:00 AM	0.4
7/26/2014	3:30:00 AM	0.4
7/26/2014	3:45:00 AM	0.4
7/26/2014	4:00:00 AM	0.4
7/26/2014	4:15:00 AM	0.4
7/26/2014	4:30:00 AM	0.4
7/26/2014	4:45:00 AM	0.4
7/26/2014	5:00:00 AM	0.4
7/26/2014	5:15:00 AM	0.4
7/26/2014	5:30:00 AM	0.4
7/26/2014	5:45:00 AM	0.4
7/26/2014	6:00:00 AM	0.4
7/26/2014	6:15:00 AM	0.4
7/26/2014	6:30:00 AM	0.4
7/26/2014	6:45:00 AM	0.4
7/26/2014	7:00:00 AM	0.4
7/26/2014	7:15:00 AM	0.4
7/26/2014	7:30:00 AM	0.4
7/26/2014	7:45:00 AM	0.41
7/26/2014	8:00:00 AM	0.41
7/26/2014	8:15:00 AM	0.41
7/26/2014	8:30:00 AM	0.41
7/26/2014	8:45:00 AM	0.41
7/26/2014	9:00:00 AM	0.41
7/26/2014	9:15:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/26/2014	9:30:00 AM	0.41
7/26/2014	9:45:00 AM	0.41
7/26/2014	10:00:00 AM	0.41
7/26/2014	10:15:00 AM	0.41
7/26/2014	10:30:00 AM	0.41
7/26/2014	10:45:00 AM	0.41
7/26/2014	11:00:00 AM	0.41
7/26/2014	11:15:00 AM	0.4
7/26/2014	11:30:00 AM	0.4
7/26/2014	11:45:00 AM	0.4
7/26/2014	12:00:00 PM	0.4
7/26/2014	12:15:00 PM	0.4
7/26/2014	12:30:00 PM	0.4
7/26/2014	12:45:00 PM	0.39
7/26/2014	1:00:00 PM	0.39
7/26/2014	1:15:00 PM	0.39
7/26/2014	1:30:00 PM	0.39
7/26/2014	1:45:00 PM	0.39
7/26/2014	2:00:00 PM	0.39
7/26/2014	2:15:00 PM	0.39
7/26/2014	2:30:00 PM	0.39
7/26/2014	2:45:00 PM	0.39
7/26/2014	3:00:00 PM	0.39
7/26/2014	3:15:00 PM	0.39
7/26/2014	3:30:00 PM	0.39
7/26/2014	3:45:00 PM	0.39
7/26/2014	4:00:00 PM	0.39
7/26/2014	4:15:00 PM	0.38
7/26/2014	4:30:00 PM	0.38
7/26/2014	4:45:00 PM	0.39
7/26/2014	5:00:00 PM	0.38
7/26/2014	5:15:00 PM	0.38
7/26/2014	5:30:00 PM	0.38
7/26/2014	5:45:00 PM	0.38
7/26/2014	6:00:00 PM	0.38
7/26/2014	6:15:00 PM	0.38
7/26/2014	6:30:00 PM	0.38
7/26/2014	6:45:00 PM	0.38
7/26/2014	7:00:00 PM	0.38
7/26/2014	7:15:00 PM	0.38
7/26/2014	7:30:00 PM	0.38
7/26/2014	7:45:00 PM	0.38
7/26/2014	8:00:00 PM	0.38
7/26/2014	8:15:00 PM	0.38
7/26/2014	8:30:00 PM	0.38
7/26/2014	8:45:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/26/2014	9:00:00 PM	0.38
7/26/2014	9:15:00 PM	0.38
7/26/2014	9:30:00 PM	0.38
7/26/2014	9:45:00 PM	0.38
7/26/2014	10:00:00 PM	0.38
7/26/2014	10:15:00 PM	0.38
7/26/2014	10:30:00 PM	0.38
7/26/2014	10:45:00 PM	0.38
7/26/2014	11:00:00 PM	0.38
7/26/2014	11:15:00 PM	0.38
7/26/2014	11:30:00 PM	0.38
7/26/2014	11:45:00 PM	0.38
7/27/2014	12:00:00 AM	0.38
7/27/2014	12:15:00 AM	0.39
7/27/2014	12:30:00 AM	0.39
7/27/2014	12:45:00 AM	0.39
7/27/2014	1:00:00 AM	0.39
7/27/2014	1:15:00 AM	0.39
7/27/2014	1:30:00 AM	0.39
7/27/2014	1:45:00 AM	0.39
7/27/2014	2:00:00 AM	0.39
7/27/2014	2:15:00 AM	0.39
7/27/2014	2:30:00 AM	0.39
7/27/2014	2:45:00 AM	0.39
7/27/2014	3:00:00 AM	0.39
7/27/2014	3:15:00 AM	0.39
7/27/2014	3:30:00 AM	0.39
7/27/2014	3:45:00 AM	0.39
7/27/2014	4:00:00 AM	0.39
7/27/2014	4:15:00 AM	0.39
7/27/2014	4:30:00 AM	0.39
7/27/2014	4:45:00 AM	0.4
7/27/2014	5:00:00 AM	0.4
7/27/2014	5:15:00 AM	0.4
7/27/2014	5:30:00 AM	0.4
7/27/2014	5:45:00 AM	0.4
7/27/2014	6:00:00 AM	0.4
7/27/2014	6:15:00 AM	0.4
7/27/2014	6:30:00 AM	0.4
7/27/2014	6:45:00 AM	0.4
7/27/2014	7:00:00 AM	0.4
7/27/2014	7:15:00 AM	0.41
7/27/2014	7:30:00 AM	0.4
7/27/2014	7:45:00 AM	0.4
7/27/2014	8:00:00 AM	0.4
7/27/2014	8:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/27/2014	8:30:00 AM	0.4
7/27/2014	8:45:00 AM	0.4
7/27/2014	9:00:00 AM	0.41
7/27/2014	9:15:00 AM	0.41
7/27/2014	9:30:00 AM	0.41
7/27/2014	9:45:00 AM	0.41
7/27/2014	10:00:00 AM	0.41
7/27/2014	10:15:00 AM	0.41
7/27/2014	10:30:00 AM	0.41
7/27/2014	10:45:00 AM	0.4
7/27/2014	11:00:00 AM	0.4
7/27/2014	11:15:00 AM	0.4
7/27/2014	11:30:00 AM	0.4
7/27/2014	11:45:00 AM	0.4
7/27/2014	12:00:00 PM	0.4
7/27/2014	12:15:00 PM	0.4
7/27/2014	12:30:00 PM	0.39
7/27/2014	12:45:00 PM	0.39
7/27/2014	1:00:00 PM	0.39
7/27/2014	1:15:00 PM	0.39
7/27/2014	1:30:00 PM	0.39
7/27/2014	1:45:00 PM	0.39
7/27/2014	2:00:00 PM	0.39
7/27/2014	2:15:00 PM	0.39
7/27/2014	2:30:00 PM	0.39
7/27/2014	2:45:00 PM	0.39
7/27/2014	3:00:00 PM	0.39
7/27/2014	3:15:00 PM	0.39
7/27/2014	3:30:00 PM	0.39
7/27/2014	3:45:00 PM	0.39
7/27/2014	4:00:00 PM	0.39
7/27/2014	4:15:00 PM	0.39
7/27/2014	4:30:00 PM	0.38
7/27/2014	4:45:00 PM	0.38
7/27/2014	5:00:00 PM	0.38
7/27/2014	5:15:00 PM	0.38
7/27/2014	5:30:00 PM	0.39
7/27/2014	5:45:00 PM	0.38
7/27/2014	6:00:00 PM	0.38
7/27/2014	6:15:00 PM	0.38
7/27/2014	6:30:00 PM	0.38
7/27/2014	6:45:00 PM	0.39
7/27/2014	7:00:00 PM	0.38
7/27/2014	7:15:00 PM	0.38
7/27/2014	7:30:00 PM	0.38
7/27/2014	7:45:00 PM	0.38

Goose Lake Return Gage

DATE	TIME	GAGE
7/27/2014	8:00:00 PM	0.39
7/27/2014	8:15:00 PM	0.38
7/27/2014	8:30:00 PM	0.39
7/27/2014	8:45:00 PM	0.39
7/27/2014	9:00:00 PM	0.39
7/27/2014	9:15:00 PM	0.39
7/27/2014	9:30:00 PM	0.39
7/27/2014	9:45:00 PM	0.39
7/27/2014	10:00:00 PM	0.39
7/27/2014	10:15:00 PM	0.39
7/27/2014	10:30:00 PM	0.39
7/27/2014	10:45:00 PM	0.39
7/27/2014	11:00:00 PM	0.39
7/27/2014	11:15:00 PM	0.39
7/27/2014	11:30:00 PM	0.39
7/27/2014	11:45:00 PM	0.39
7/28/2014	12:00:00 AM	0.39
7/28/2014	12:15:00 AM	0.39
7/28/2014	12:30:00 AM	0.39
7/28/2014	12:45:00 AM	0.39
7/28/2014	1:00:00 AM	0.39
7/28/2014	1:15:00 AM	0.39
7/28/2014	1:30:00 AM	0.39
7/28/2014	1:45:00 AM	0.39
7/28/2014	2:00:00 AM	0.39
7/28/2014	2:15:00 AM	0.4
7/28/2014	2:30:00 AM	0.4
7/28/2014	2:45:00 AM	0.4
7/28/2014	3:00:00 AM	0.4
7/28/2014	3:15:00 AM	0.4
7/28/2014	3:30:00 AM	0.4
7/28/2014	3:45:00 AM	0.41
7/28/2014	4:00:00 AM	0.41
7/28/2014	4:15:00 AM	0.41
7/28/2014	4:30:00 AM	0.41
7/28/2014	4:45:00 AM	0.41
7/28/2014	5:00:00 AM	0.41
7/28/2014	5:15:00 AM	0.41
7/28/2014	5:30:00 AM	0.41
7/28/2014	5:45:00 AM	0.41
7/28/2014	6:00:00 AM	0.41
7/28/2014	6:15:00 AM	0.41
7/28/2014	6:30:00 AM	0.41
7/28/2014	6:45:00 AM	0.41
7/28/2014	7:00:00 AM	0.41
7/28/2014	7:15:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/28/2014	7:30:00 AM	0.41
7/28/2014	7:45:00 AM	0.41
7/28/2014	8:00:00 AM	0.41
7/28/2014	8:15:00 AM	0.41
7/28/2014	8:30:00 AM	0.41
7/28/2014	8:45:00 AM	0.41
7/28/2014	9:00:00 AM	0.41
7/28/2014	9:15:00 AM	0.41
7/28/2014	9:30:00 AM	0.41
7/28/2014	9:45:00 AM	0.41
7/28/2014	10:00:00 AM	0.41
7/28/2014	10:15:00 AM	0.41
7/28/2014	10:30:00 AM	0.41
7/28/2014	10:45:00 AM	0.41
7/28/2014	11:00:00 AM	0.41
7/28/2014	11:15:00 AM	0.41
7/28/2014	11:30:00 AM	0.41
7/28/2014	11:45:00 AM	0.41
7/28/2014	12:00:00 PM	0.41
7/28/2014	12:15:00 PM	0.41
7/28/2014	12:30:00 PM	0.41
7/28/2014	12:45:00 PM	0.41
7/28/2014	1:00:00 PM	0.41
7/28/2014	1:15:00 PM	0.41
7/28/2014	1:30:00 PM	0.41
7/28/2014	1:45:00 PM	0.41
7/28/2014	2:00:00 PM	0.41
7/28/2014	2:15:00 PM	0.41
7/28/2014	2:30:00 PM	0.41
7/28/2014	2:45:00 PM	0.41
7/28/2014	3:00:00 PM	0.41
7/28/2014	3:15:00 PM	0.41
7/28/2014	3:30:00 PM	0.41
7/28/2014	3:45:00 PM	0.41
7/28/2014	4:00:00 PM	0.41
7/28/2014	4:15:00 PM	0.41
7/28/2014	4:30:00 PM	0.41
7/28/2014	4:45:00 PM	0.41
7/28/2014	5:00:00 PM	0.41
7/28/2014	5:15:00 PM	0.41
7/28/2014	5:30:00 PM	0.41
7/28/2014	5:45:00 PM	0.41
7/28/2014	6:00:00 PM	0.41
7/28/2014	6:15:00 PM	0.41
7/28/2014	6:30:00 PM	0.41
7/28/2014	6:45:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/28/2014	7:00:00 PM	0.41
7/28/2014	7:15:00 PM	0.41
7/28/2014	7:30:00 PM	0.42
7/28/2014	7:45:00 PM	0.42
7/28/2014	8:00:00 PM	0.42
7/28/2014	8:15:00 PM	0.42
7/28/2014	8:30:00 PM	0.42
7/28/2014	8:45:00 PM	0.42
7/28/2014	9:00:00 PM	0.41
7/28/2014	9:15:00 PM	0.42
7/28/2014	9:30:00 PM	0.42
7/28/2014	9:45:00 PM	0.43
7/28/2014	10:00:00 PM	0.43
7/28/2014	10:15:00 PM	0.43
7/28/2014	10:30:00 PM	0.43
7/28/2014	10:45:00 PM	0.43
7/28/2014	11:00:00 PM	0.43
7/28/2014	11:15:00 PM	0.43
7/28/2014	11:30:00 PM	0.43
7/28/2014	11:45:00 PM	0.43
7/29/2014	12:00:00 AM	0.43
7/29/2014	12:15:00 AM	0.43
7/29/2014	12:30:00 AM	0.43
7/29/2014	12:45:00 AM	0.43
7/29/2014	1:00:00 AM	0.43
7/29/2014	1:15:00 AM	0.43
7/29/2014	1:30:00 AM	0.43
7/29/2014	1:45:00 AM	0.43
7/29/2014	2:00:00 AM	0.43
7/29/2014	2:15:00 AM	0.43
7/29/2014	2:30:00 AM	0.43
7/29/2014	2:45:00 AM	0.43
7/29/2014	3:00:00 AM	0.43
7/29/2014	3:15:00 AM	0.43
7/29/2014	3:30:00 AM	0.43
7/29/2014	3:45:00 AM	0.43
7/29/2014	4:00:00 AM	0.43
7/29/2014	4:15:00 AM	0.43
7/29/2014	4:30:00 AM	0.43
7/29/2014	4:45:00 AM	0.43
7/29/2014	5:00:00 AM	0.44
7/29/2014	5:15:00 AM	0.44
7/29/2014	5:30:00 AM	0.44
7/29/2014	5:45:00 AM	0.44
7/29/2014	6:00:00 AM	0.44
7/29/2014	6:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/29/2014	6:30:00 AM	0.44
7/29/2014	6:45:00 AM	0.44
7/29/2014	7:00:00 AM	0.44
7/29/2014	7:15:00 AM	0.44
7/29/2014	7:30:00 AM	0.44
7/29/2014	7:45:00 AM	0.44
7/29/2014	8:00:00 AM	0.44
7/29/2014	8:15:00 AM	0.44
7/29/2014	8:30:00 AM	0.45
7/29/2014	8:45:00 AM	0.45
7/29/2014	9:00:00 AM	0.45
7/29/2014	9:15:00 AM	0.45
7/29/2014	9:30:00 AM	0.45
7/29/2014	9:45:00 AM	0.45
7/29/2014	10:00:00 AM	0.45
7/29/2014	10:15:00 AM	0.45
7/29/2014	10:30:00 AM	0.45
7/29/2014	10:45:00 AM	0.45
7/29/2014	11:00:00 AM	0.45
7/29/2014	11:15:00 AM	0.44
7/29/2014	11:30:00 AM	0.45
7/29/2014	11:45:00 AM	0.45
7/29/2014	12:00:00 PM	0.45
7/29/2014	12:15:00 PM	0.45
7/29/2014	12:30:00 PM	0.44
7/29/2014	12:45:00 PM	0.44
7/29/2014	1:00:00 PM	0.43
7/29/2014	1:15:00 PM	0.44
7/29/2014	1:30:00 PM	0.44
7/29/2014	1:45:00 PM	0.44
7/29/2014	2:00:00 PM	0.44
7/29/2014	2:15:00 PM	0.43
7/29/2014	2:30:00 PM	0.43
7/29/2014	2:45:00 PM	0.43
7/29/2014	3:00:00 PM	0.43
7/29/2014	3:15:00 PM	0.43
7/29/2014	3:30:00 PM	0.43
7/29/2014	3:45:00 PM	0.43
7/29/2014	4:00:00 PM	0.43
7/29/2014	4:15:00 PM	0.43
7/29/2014	4:30:00 PM	0.43
7/29/2014	4:45:00 PM	0.43
7/29/2014	5:00:00 PM	0.43
7/29/2014	5:15:00 PM	0.43
7/29/2014	5:30:00 PM	0.43
7/29/2014	5:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/29/2014	6:00:00 PM	0.43
7/29/2014	6:15:00 PM	0.43
7/29/2014	6:30:00 PM	0.43
7/29/2014	6:45:00 PM	0.43
7/29/2014	7:00:00 PM	0.43
7/29/2014	7:15:00 PM	0.43
7/29/2014	7:30:00 PM	0.43
7/29/2014	7:45:00 PM	0.43
7/29/2014	8:00:00 PM	0.43
7/29/2014	8:15:00 PM	0.43
7/29/2014	8:30:00 PM	0.43
7/29/2014	8:45:00 PM	0.43
7/29/2014	9:00:00 PM	0.43
7/29/2014	9:15:00 PM	0.43
7/29/2014	9:30:00 PM	0.43
7/29/2014	9:45:00 PM	0.43
7/29/2014	10:00:00 PM	0.43
7/29/2014	10:15:00 PM	0.43
7/29/2014	10:30:00 PM	0.43
7/29/2014	10:45:00 PM	0.43
7/29/2014	11:00:00 PM	0.44
7/29/2014	11:15:00 PM	0.44
7/29/2014	11:30:00 PM	0.44
7/29/2014	11:45:00 PM	0.44
7/30/2014	12:00:00 AM	0.44
7/30/2014	12:15:00 AM	0.44
7/30/2014	12:30:00 AM	0.44
7/30/2014	12:45:00 AM	0.44
7/30/2014	1:00:00 AM	0.44
7/30/2014	1:15:00 AM	0.44
7/30/2014	1:30:00 AM	0.44
7/30/2014	1:45:00 AM	0.44
7/30/2014	2:00:00 AM	0.44
7/30/2014	2:15:00 AM	0.45
7/30/2014	2:30:00 AM	0.45
7/30/2014	2:45:00 AM	0.45
7/30/2014	3:00:00 AM	0.45
7/30/2014	3:15:00 AM	0.45
7/30/2014	3:30:00 AM	0.45
7/30/2014	3:45:00 AM	0.45
7/30/2014	4:00:00 AM	0.45
7/30/2014	4:15:00 AM	0.45
7/30/2014	4:30:00 AM	0.45
7/30/2014	4:45:00 AM	0.45
7/30/2014	5:00:00 AM	0.45
7/30/2014	5:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/30/2014	5:30:00 AM	0.45
7/30/2014	5:45:00 AM	0.45
7/30/2014	6:00:00 AM	0.45
7/30/2014	6:15:00 AM	0.45
7/30/2014	6:30:00 AM	0.45
7/30/2014	6:45:00 AM	0.45
7/30/2014	7:00:00 AM	0.45
7/30/2014	7:15:00 AM	0.45
7/30/2014	7:30:00 AM	0.45
7/30/2014	7:45:00 AM	0.45
7/30/2014	8:00:00 AM	0.45
7/30/2014	8:15:00 AM	0.45
7/30/2014	8:30:00 AM	0.45
7/30/2014	8:45:00 AM	0.45
7/30/2014	9:00:00 AM	0.45
7/30/2014	9:15:00 AM	0.45
7/30/2014	9:30:00 AM	0.45
7/30/2014	9:45:00 AM	0.45
7/30/2014	10:00:00 AM	0.45
7/30/2014	10:15:00 AM	0.45
7/30/2014	10:30:00 AM	0.45
7/30/2014	10:45:00 AM	0.44
7/30/2014	11:00:00 AM	0.44
7/30/2014	11:15:00 AM	0.44
7/30/2014	11:30:00 AM	0.44
7/30/2014	11:45:00 AM	0.44
7/30/2014	12:00:00 PM	0.44
7/30/2014	12:15:00 PM	0.43
7/30/2014	12:30:00 PM	0.43
7/30/2014	12:45:00 PM	0.44
7/30/2014	1:00:00 PM	0.43
7/30/2014	1:15:00 PM	0.43
7/30/2014	1:30:00 PM	0.44
7/30/2014	1:45:00 PM	0.43
7/30/2014	2:00:00 PM	0.43
7/30/2014	2:15:00 PM	0.43
7/30/2014	2:30:00 PM	0.43
7/30/2014	2:45:00 PM	0.43
7/30/2014	3:00:00 PM	0.44
7/30/2014	3:15:00 PM	0.44
7/30/2014	3:30:00 PM	0.44
7/30/2014	3:45:00 PM	0.44
7/30/2014	4:00:00 PM	0.44
7/30/2014	4:15:00 PM	0.44
7/30/2014	4:30:00 PM	0.44
7/30/2014	4:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/30/2014	5:00:00 PM	0.44
7/30/2014	5:15:00 PM	0.44
7/30/2014	5:30:00 PM	0.44
7/30/2014	5:45:00 PM	0.44
7/30/2014	6:00:00 PM	0.44
7/30/2014	6:15:00 PM	0.44
7/30/2014	6:30:00 PM	0.44
7/30/2014	6:45:00 PM	0.44
7/30/2014	7:00:00 PM	0.44
7/30/2014	7:15:00 PM	0.44
7/30/2014	7:30:00 PM	0.44
7/30/2014	7:45:00 PM	0.44
7/30/2014	8:00:00 PM	0.44
7/30/2014	8:15:00 PM	0.44
7/30/2014	8:30:00 PM	0.44
7/30/2014	8:45:00 PM	0.44
7/30/2014	9:00:00 PM	0.44
7/30/2014	9:15:00 PM	0.44
7/30/2014	9:30:00 PM	0.44
7/30/2014	9:45:00 PM	0.44
7/30/2014	10:00:00 PM	0.44
7/30/2014	10:15:00 PM	0.44
7/30/2014	10:30:00 PM	0.44
7/30/2014	10:45:00 PM	0.44
7/30/2014	11:00:00 PM	0.44
7/30/2014	11:15:00 PM	0.44
7/30/2014	11:30:00 PM	0.44
7/30/2014	11:45:00 PM	0.44
7/31/2014	12:00:00 AM	0.44
7/31/2014	12:15:00 AM	0.44
7/31/2014	12:30:00 AM	0.44
7/31/2014	12:45:00 AM	0.44
7/31/2014	1:00:00 AM	0.44
7/31/2014	1:15:00 AM	0.44
7/31/2014	1:30:00 AM	0.44
7/31/2014	1:45:00 AM	0.44
7/31/2014	2:00:00 AM	0.44
7/31/2014	2:15:00 AM	0.44
7/31/2014	2:30:00 AM	0.44
7/31/2014	2:45:00 AM	0.44
7/31/2014	3:00:00 AM	0.45
7/31/2014	3:15:00 AM	0.45
7/31/2014	3:30:00 AM	0.45
7/31/2014	3:45:00 AM	0.45
7/31/2014	4:00:00 AM	0.45
7/31/2014	4:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/31/2014	4:30:00 AM	0.45
7/31/2014	4:45:00 AM	0.45
7/31/2014	5:00:00 AM	0.45
7/31/2014	5:15:00 AM	0.45
7/31/2014	5:30:00 AM	0.45
7/31/2014	5:45:00 AM	0.45
7/31/2014	6:00:00 AM	0.45
7/31/2014	6:15:00 AM	0.46
7/31/2014	6:30:00 AM	0.46
7/31/2014	6:45:00 AM	0.46
7/31/2014	7:00:00 AM	0.46
7/31/2014	7:15:00 AM	0.46
7/31/2014	7:30:00 AM	0.46
7/31/2014	7:45:00 AM	0.46
7/31/2014	8:00:00 AM	0.46
7/31/2014	8:15:00 AM	0.46
7/31/2014	8:30:00 AM	0.46
7/31/2014	8:45:00 AM	0.46
7/31/2014	9:00:00 AM	0.46
7/31/2014	9:15:00 AM	0.46
7/31/2014	9:30:00 AM	0.46
7/31/2014	9:45:00 AM	0.46
7/31/2014	10:00:00 AM	0.46
7/31/2014	10:15:00 AM	0.46
7/31/2014	10:30:00 AM	0.46
7/31/2014	10:45:00 AM	0.46
7/31/2014	11:00:00 AM	0.46
7/31/2014	11:15:00 AM	0.46
7/31/2014	11:30:00 AM	0.46
7/31/2014	11:45:00 AM	0.46
7/31/2014	12:00:00 PM	0.46
7/31/2014	12:15:00 PM	0.46
7/31/2014	12:30:00 PM	0.46
7/31/2014	12:45:00 PM	0.46
7/31/2014	1:00:00 PM	0.45
7/31/2014	1:15:00 PM	0.46
7/31/2014	1:30:00 PM	0.46
7/31/2014	1:45:00 PM	0.46
7/31/2014	2:00:00 PM	0.46
7/31/2014	2:15:00 PM	0.45
7/31/2014	2:30:00 PM	0.45
7/31/2014	2:45:00 PM	0.45
7/31/2014	3:00:00 PM	0.45
7/31/2014	3:15:00 PM	0.45
7/31/2014	3:30:00 PM	0.44
7/31/2014	3:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/31/2014	4:00:00 PM	0.45
7/31/2014	4:15:00 PM	0.45
7/31/2014	4:30:00 PM	0.45
7/31/2014	4:45:00 PM	0.45
7/31/2014	5:00:00 PM	0.45
7/31/2014	5:15:00 PM	0.45
7/31/2014	5:30:00 PM	0.45
7/31/2014	5:45:00 PM	0.45
7/31/2014	6:00:00 PM	0.45
7/31/2014	6:15:00 PM	0.45
7/31/2014	6:30:00 PM	0.45
7/31/2014	6:45:00 PM	0.45
7/31/2014	7:00:00 PM	0.46
7/31/2014	7:15:00 PM	0.45
7/31/2014	7:30:00 PM	0.46
7/31/2014	7:45:00 PM	0.46
7/31/2014	8:00:00 PM	0.46
7/31/2014	8:15:00 PM	0.46
7/31/2014	8:30:00 PM	0.46
7/31/2014	8:45:00 PM	0.45
7/31/2014	9:00:00 PM	0.46
7/31/2014	9:15:00 PM	0.46
7/31/2014	9:30:00 PM	0.46
7/31/2014	9:45:00 PM	0.46
7/31/2014	10:00:00 PM	0.46
7/31/2014	10:15:00 PM	0.46
7/31/2014	10:30:00 PM	0.46
7/31/2014	10:45:00 PM	0.46
7/31/2014	11:00:00 PM	0.46
7/31/2014	11:15:00 PM	0.46
7/31/2014	11:30:00 PM	0.46
7/31/2014	11:45:00 PM	0.46
8/1/2014	12:00:00 AM	0.46

Billy Lake Return
Station 0213

Date	Flow (cfs)
7/1/2014	0.948
7/2/2014	0.997
7/3/2014	1.049
7/4/2014	1.038
7/5/2014	1.051
7/6/2014	1.051
7/7/2014	1.051
7/8/2014	1.028
7/9/2014	1.055
7/10/2014	1.115
7/11/2014	1.161
7/12/2014	1.193
7/13/2014	1.174
7/14/2014	1.174
7/15/2014	1.174
7/16/2014	1.178
7/17/2014	1.156
7/18/2014	1.166
7/19/2014	1.152
7/20/2014	1.165
7/21/2014	1.112
7/22/2014	1.093
7/23/2014	1.086
7/24/2014	1.078
7/25/2014	1.112
7/26/2014	1.112
7/27/2014	1.067
7/28/2014	1.012
7/29/2014	1.051
7/30/2014	1.022
7/31/2014	0.992

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2014	12:00:00 AM	0.25
7/1/2014	12:15:00 AM	0.25
7/1/2014	12:30:00 AM	0.25
7/1/2014	12:45:00 AM	0.25
7/1/2014	1:00:00 AM	0.25
7/1/2014	1:15:00 AM	0.25
7/1/2014	1:30:00 AM	0.25
7/1/2014	1:45:00 AM	0.25
7/1/2014	2:00:00 AM	0.25
7/1/2014	2:15:00 AM	0.25
7/1/2014	2:30:00 AM	0.25
7/1/2014	2:45:00 AM	0.25
7/1/2014	3:00:00 AM	0.25
7/1/2014	3:15:00 AM	0.25
7/1/2014	3:30:00 AM	0.25
7/1/2014	3:45:00 AM	0.25
7/1/2014	4:00:00 AM	0.25
7/1/2014	4:15:00 AM	0.25
7/1/2014	4:30:00 AM	0.25
7/1/2014	4:45:00 AM	0.25
7/1/2014	5:00:00 AM	0.25
7/1/2014	5:15:00 AM	0.25
7/1/2014	5:30:00 AM	0.25
7/1/2014	5:45:00 AM	0.25
7/1/2014	6:00:00 AM	0.25
7/1/2014	6:15:00 AM	0.26
7/1/2014	6:30:00 AM	0.26
7/1/2014	6:45:00 AM	0.26
7/1/2014	7:00:00 AM	0.26
7/1/2014	7:15:00 AM	0.26
7/1/2014	7:30:00 AM	0.26
7/1/2014	7:45:00 AM	0.26
7/1/2014	8:00:00 AM	0.26
7/1/2014	8:15:00 AM	0.26
7/1/2014	8:30:00 AM	0.26
7/1/2014	8:45:00 AM	0.26
7/1/2014	9:00:00 AM	0.26
7/1/2014	9:15:00 AM	0.26
7/1/2014	9:30:00 AM	0.26
7/1/2014	9:45:00 AM	0.26
7/1/2014	10:00:00 AM	0.26
7/1/2014	10:15:00 AM	0.26
7/1/2014	10:30:00 AM	0.26
7/1/2014	10:45:00 AM	0.26
7/1/2014	11:00:00 AM	0.26
7/1/2014	11:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2014	11:30:00 AM	0.26
7/1/2014	11:45:00 AM	0.26
7/1/2014	12:00:00 PM	0.26
7/1/2014	12:15:00 PM	0.25
7/1/2014	12:30:00 PM	0.25
7/1/2014	12:45:00 PM	0.25
7/1/2014	1:00:00 PM	0.25
7/1/2014	1:15:00 PM	0.25
7/1/2014	1:30:00 PM	0.25
7/1/2014	1:45:00 PM	0.25
7/1/2014	2:00:00 PM	0.25
7/1/2014	2:15:00 PM	0.25
7/1/2014	2:30:00 PM	0.25
7/1/2014	2:45:00 PM	0.25
7/1/2014	3:00:00 PM	0.25
7/1/2014	3:15:00 PM	0.25
7/1/2014	3:30:00 PM	0.25
7/1/2014	3:45:00 PM	0.25
7/1/2014	4:00:00 PM	0.25
7/1/2014	4:15:00 PM	0.25
7/1/2014	4:30:00 PM	0.25
7/1/2014	4:45:00 PM	0.25
7/1/2014	5:00:00 PM	0.25
7/1/2014	5:15:00 PM	0.25
7/1/2014	5:30:00 PM	0.25
7/1/2014	5:45:00 PM	0.25
7/1/2014	6:00:00 PM	0.25
7/1/2014	6:15:00 PM	0.25
7/1/2014	6:30:00 PM	0.25
7/1/2014	6:45:00 PM	0.25
7/1/2014	7:00:00 PM	0.25
7/1/2014	7:15:00 PM	0.25
7/1/2014	7:30:00 PM	0.25
7/1/2014	7:45:00 PM	0.25
7/1/2014	8:00:00 PM	0.25
7/1/2014	8:15:00 PM	0.25
7/1/2014	8:30:00 PM	0.25
7/1/2014	8:45:00 PM	0.25
7/1/2014	9:00:00 PM	0.25
7/1/2014	9:15:00 PM	0.25
7/1/2014	9:30:00 PM	0.25
7/1/2014	9:45:00 PM	0.25
7/1/2014	10:00:00 PM	0.25
7/1/2014	10:15:00 PM	0.25
7/1/2014	10:30:00 PM	0.25
7/1/2014	10:45:00 PM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2014	11:00:00 PM	0.25
7/1/2014	11:15:00 PM	0.25
7/1/2014	11:30:00 PM	0.25
7/1/2014	11:45:00 PM	0.25
7/2/2014	12:00:00 AM	0.25
7/2/2014	12:15:00 AM	0.25
7/2/2014	12:30:00 AM	0.25
7/2/2014	12:45:00 AM	0.25
7/2/2014	1:00:00 AM	0.25
7/2/2014	1:15:00 AM	0.25
7/2/2014	1:30:00 AM	0.25
7/2/2014	1:45:00 AM	0.25
7/2/2014	2:00:00 AM	0.26
7/2/2014	2:15:00 AM	0.26
7/2/2014	2:30:00 AM	0.26
7/2/2014	2:45:00 AM	0.26
7/2/2014	3:00:00 AM	0.26
7/2/2014	3:15:00 AM	0.26
7/2/2014	3:30:00 AM	0.26
7/2/2014	3:45:00 AM	0.26
7/2/2014	4:00:00 AM	0.26
7/2/2014	4:15:00 AM	0.26
7/2/2014	4:30:00 AM	0.26
7/2/2014	4:45:00 AM	0.26
7/2/2014	5:00:00 AM	0.26
7/2/2014	5:15:00 AM	0.26
7/2/2014	5:30:00 AM	0.26
7/2/2014	5:45:00 AM	0.26
7/2/2014	6:00:00 AM	0.26
7/2/2014	6:15:00 AM	0.26
7/2/2014	6:30:00 AM	0.26
7/2/2014	6:45:00 AM	0.26
7/2/2014	7:00:00 AM	0.26
7/2/2014	7:15:00 AM	0.26
7/2/2014	7:30:00 AM	0.26
7/2/2014	7:45:00 AM	0.26
7/2/2014	8:00:00 AM	0.26
7/2/2014	8:15:00 AM	0.26
7/2/2014	8:30:00 AM	0.26
7/2/2014	8:45:00 AM	0.26
7/2/2014	9:00:00 AM	0.26
7/2/2014	9:15:00 AM	0.26
7/2/2014	9:30:00 AM	0.26
7/2/2014	9:45:00 AM	0.26
7/2/2014	10:00:00 AM	0.26
7/2/2014	10:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/2/2014	10:30:00 AM	0.26
7/2/2014	10:45:00 AM	0.26
7/2/2014	11:00:00 AM	0.26
7/2/2014	11:15:00 AM	0.27
7/2/2014	11:30:00 AM	0.27
7/2/2014	11:45:00 AM	0.27
7/2/2014	12:00:00 PM	0.27
7/2/2014	12:15:00 PM	0.27
7/2/2014	12:30:00 PM	0.27
7/2/2014	12:45:00 PM	0.27
7/2/2014	1:00:00 PM	0.27
7/2/2014	1:15:00 PM	0.27
7/2/2014	1:30:00 PM	0.27
7/2/2014	1:45:00 PM	0.27
7/2/2014	2:00:00 PM	0.27
7/2/2014	2:15:00 PM	0.27
7/2/2014	2:30:00 PM	0.26
7/2/2014	2:45:00 PM	0.26
7/2/2014	3:00:00 PM	0.26
7/2/2014	3:15:00 PM	0.26
7/2/2014	3:30:00 PM	0.26
7/2/2014	3:45:00 PM	0.26
7/2/2014	4:00:00 PM	0.26
7/2/2014	4:15:00 PM	0.26
7/2/2014	4:30:00 PM	0.26
7/2/2014	4:45:00 PM	0.26
7/2/2014	5:00:00 PM	0.26
7/2/2014	5:15:00 PM	0.26
7/2/2014	5:30:00 PM	0.26
7/2/2014	5:45:00 PM	0.26
7/2/2014	6:00:00 PM	0.26
7/2/2014	6:15:00 PM	0.26
7/2/2014	6:30:00 PM	0.26
7/2/2014	6:45:00 PM	0.26
7/2/2014	7:00:00 PM	0.26
7/2/2014	7:15:00 PM	0.26
7/2/2014	7:30:00 PM	0.26
7/2/2014	7:45:00 PM	0.26
7/2/2014	8:00:00 PM	0.26
7/2/2014	8:15:00 PM	0.26
7/2/2014	8:30:00 PM	0.26
7/2/2014	8:45:00 PM	0.26
7/2/2014	9:00:00 PM	0.26
7/2/2014	9:15:00 PM	0.26
7/2/2014	9:30:00 PM	0.26
7/2/2014	9:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/2/2014	10:00:00 PM	0.26
7/2/2014	10:15:00 PM	0.26
7/2/2014	10:30:00 PM	0.26
7/2/2014	10:45:00 PM	0.26
7/2/2014	11:00:00 PM	0.27
7/2/2014	11:15:00 PM	0.27
7/2/2014	11:30:00 PM	0.27
7/2/2014	11:45:00 PM	0.27
7/3/2014	12:00:00 AM	0.27
7/3/2014	12:15:00 AM	0.27
7/3/2014	12:30:00 AM	0.27
7/3/2014	12:45:00 AM	0.27
7/3/2014	1:00:00 AM	0.27
7/3/2014	1:15:00 AM	0.27
7/3/2014	1:30:00 AM	0.27
7/3/2014	1:45:00 AM	0.27
7/3/2014	2:00:00 AM	0.27
7/3/2014	2:15:00 AM	0.27
7/3/2014	2:30:00 AM	0.27
7/3/2014	2:45:00 AM	0.27
7/3/2014	3:00:00 AM	0.27
7/3/2014	3:15:00 AM	0.27
7/3/2014	3:30:00 AM	0.27
7/3/2014	3:45:00 AM	0.27
7/3/2014	4:00:00 AM	0.27
7/3/2014	4:15:00 AM	0.27
7/3/2014	4:30:00 AM	0.27
7/3/2014	4:45:00 AM	0.27
7/3/2014	5:00:00 AM	0.27
7/3/2014	5:15:00 AM	0.27
7/3/2014	5:30:00 AM	0.27
7/3/2014	5:45:00 AM	0.27
7/3/2014	6:00:00 AM	0.27
7/3/2014	6:15:00 AM	0.27
7/3/2014	6:30:00 AM	0.27
7/3/2014	6:45:00 AM	0.27
7/3/2014	7:00:00 AM	0.27
7/3/2014	7:15:00 AM	0.27
7/3/2014	7:30:00 AM	0.27
7/3/2014	7:45:00 AM	0.27
7/3/2014	8:00:00 AM	0.27
7/3/2014	8:15:00 AM	0.27
7/3/2014	8:30:00 AM	0.27
7/3/2014	8:45:00 AM	0.27
7/3/2014	9:00:00 AM	0.27
7/3/2014	9:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/3/2014	9:30:00 AM	0.27
7/3/2014	9:45:00 AM	0.27
7/3/2014	10:00:00 AM	0.27
7/3/2014	10:15:00 AM	0.27
7/3/2014	10:30:00 AM	0.27
7/3/2014	10:45:00 AM	0.27
7/3/2014	11:00:00 AM	0.27
7/3/2014	11:15:00 AM	0.27
7/3/2014	11:30:00 AM	0.27
7/3/2014	11:45:00 AM	0.27
7/3/2014	12:00:00 PM	0.27
7/3/2014	12:15:00 PM	0.27
7/3/2014	12:30:00 PM	0.27
7/3/2014	12:45:00 PM	0.27
7/3/2014	1:00:00 PM	0.27
7/3/2014	1:15:00 PM	0.27
7/3/2014	1:30:00 PM	0.27
7/3/2014	1:45:00 PM	0.27
7/3/2014	2:00:00 PM	0.27
7/3/2014	2:15:00 PM	0.27
7/3/2014	2:30:00 PM	0.27
7/3/2014	2:45:00 PM	0.27
7/3/2014	3:00:00 PM	0.27
7/3/2014	3:15:00 PM	0.27
7/3/2014	3:30:00 PM	0.27
7/3/2014	3:45:00 PM	0.27
7/3/2014	4:00:00 PM	0.27
7/3/2014	4:15:00 PM	0.27
7/3/2014	4:30:00 PM	0.27
7/3/2014	4:45:00 PM	0.27
7/3/2014	5:00:00 PM	0.27
7/3/2014	5:15:00 PM	0.27
7/3/2014	5:30:00 PM	0.27
7/3/2014	5:45:00 PM	0.27
7/3/2014	6:00:00 PM	0.27
7/3/2014	6:15:00 PM	0.27
7/3/2014	6:30:00 PM	0.27
7/3/2014	6:45:00 PM	0.27
7/3/2014	7:00:00 PM	0.26
7/3/2014	7:15:00 PM	0.26
7/3/2014	7:30:00 PM	0.26
7/3/2014	7:45:00 PM	0.26
7/3/2014	8:00:00 PM	0.27
7/3/2014	8:15:00 PM	0.27
7/3/2014	8:30:00 PM	0.27
7/3/2014	8:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/3/2014	9:00:00 PM	0.27
7/3/2014	9:15:00 PM	0.27
7/3/2014	9:30:00 PM	0.27
7/3/2014	9:45:00 PM	0.27
7/3/2014	10:00:00 PM	0.27
7/3/2014	10:15:00 PM	0.27
7/3/2014	10:30:00 PM	0.27
7/3/2014	10:45:00 PM	0.27
7/3/2014	11:00:00 PM	0.27
7/3/2014	11:15:00 PM	0.27
7/3/2014	11:30:00 PM	0.27
7/3/2014	11:45:00 PM	0.27
7/4/2014	12:00:00 AM	0.27
7/4/2014	12:15:00 AM	0.27
7/4/2014	12:30:00 AM	0.27
7/4/2014	12:45:00 AM	0.27
7/4/2014	1:00:00 AM	0.27
7/4/2014	1:15:00 AM	0.27
7/4/2014	1:30:00 AM	0.27
7/4/2014	1:45:00 AM	0.27
7/4/2014	2:00:00 AM	0.27
7/4/2014	2:15:00 AM	0.27
7/4/2014	2:30:00 AM	0.27
7/4/2014	2:45:00 AM	0.27
7/4/2014	3:00:00 AM	0.27
7/4/2014	3:15:00 AM	0.27
7/4/2014	3:30:00 AM	0.27
7/4/2014	3:45:00 AM	0.27
7/4/2014	4:00:00 AM	0.27
7/4/2014	4:15:00 AM	0.27
7/4/2014	4:30:00 AM	0.27
7/4/2014	4:45:00 AM	0.27
7/4/2014	5:00:00 AM	0.27
7/4/2014	5:15:00 AM	0.27
7/4/2014	5:30:00 AM	0.27
7/4/2014	5:45:00 AM	0.27
7/4/2014	6:00:00 AM	0.27
7/4/2014	6:15:00 AM	0.27
7/4/2014	6:30:00 AM	0.27
7/4/2014	6:45:00 AM	0.27
7/4/2014	7:00:00 AM	0.27
7/4/2014	7:15:00 AM	0.27
7/4/2014	7:30:00 AM	0.27
7/4/2014	7:45:00 AM	0.27
7/4/2014	8:00:00 AM	0.27
7/4/2014	8:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/4/2014	8:30:00 AM	0.27
7/4/2014	8:45:00 AM	0.27
7/4/2014	9:00:00 AM	0.27
7/4/2014	9:15:00 AM	0.27
7/4/2014	9:30:00 AM	0.27
7/4/2014	9:45:00 AM	0.27
7/4/2014	10:00:00 AM	0.27
7/4/2014	10:15:00 AM	0.27
7/4/2014	10:30:00 AM	0.27
7/4/2014	10:45:00 AM	0.27
7/4/2014	11:00:00 AM	0.27
7/4/2014	11:15:00 AM	0.27
7/4/2014	11:30:00 AM	0.27
7/4/2014	11:45:00 AM	0.27
7/4/2014	12:00:00 PM	0.27
7/4/2014	12:15:00 PM	0.27
7/4/2014	12:30:00 PM	0.27
7/4/2014	12:45:00 PM	0.27
7/4/2014	1:00:00 PM	0.27
7/4/2014	1:15:00 PM	0.27
7/4/2014	1:30:00 PM	0.27
7/4/2014	1:45:00 PM	0.27
7/4/2014	2:00:00 PM	0.27
7/4/2014	2:15:00 PM	0.27
7/4/2014	2:30:00 PM	0.27
7/4/2014	2:45:00 PM	0.27
7/4/2014	3:00:00 PM	0.27
7/4/2014	3:15:00 PM	0.27
7/4/2014	3:30:00 PM	0.27
7/4/2014	3:45:00 PM	0.27
7/4/2014	4:00:00 PM	0.26
7/4/2014	4:15:00 PM	0.26
7/4/2014	4:30:00 PM	0.26
7/4/2014	4:45:00 PM	0.26
7/4/2014	5:00:00 PM	0.26
7/4/2014	5:15:00 PM	0.26
7/4/2014	5:30:00 PM	0.26
7/4/2014	5:45:00 PM	0.26
7/4/2014	6:00:00 PM	0.26
7/4/2014	6:15:00 PM	0.26
7/4/2014	6:30:00 PM	0.26
7/4/2014	6:45:00 PM	0.26
7/4/2014	7:00:00 PM	0.26
7/4/2014	7:15:00 PM	0.26
7/4/2014	7:30:00 PM	0.26
7/4/2014	7:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/4/2014	8:00:00 PM	0.26
7/4/2014	8:15:00 PM	0.26
7/4/2014	8:30:00 PM	0.26
7/4/2014	8:45:00 PM	0.26
7/4/2014	9:00:00 PM	0.26
7/4/2014	9:15:00 PM	0.26
7/4/2014	9:30:00 PM	0.27
7/4/2014	9:45:00 PM	0.27
7/4/2014	10:00:00 PM	0.27
7/4/2014	10:15:00 PM	0.27
7/4/2014	10:30:00 PM	0.27
7/4/2014	10:45:00 PM	0.27
7/4/2014	11:00:00 PM	0.27
7/4/2014	11:15:00 PM	0.27
7/4/2014	11:30:00 PM	0.27
7/4/2014	11:45:00 PM	0.27
7/5/2014	12:00:00 AM	0.27
7/5/2014	12:15:00 AM	0.27
7/5/2014	12:30:00 AM	0.27
7/5/2014	12:45:00 AM	0.27
7/5/2014	1:00:00 AM	0.27
7/5/2014	1:15:00 AM	0.27
7/5/2014	1:30:00 AM	0.27
7/5/2014	1:45:00 AM	0.27
7/5/2014	2:00:00 AM	0.27
7/5/2014	2:15:00 AM	0.27
7/5/2014	2:30:00 AM	0.27
7/5/2014	2:45:00 AM	0.27
7/5/2014	3:00:00 AM	0.27
7/5/2014	3:15:00 AM	0.27
7/5/2014	3:30:00 AM	0.27
7/5/2014	3:45:00 AM	0.27
7/5/2014	4:00:00 AM	0.27
7/5/2014	4:15:00 AM	0.27
7/5/2014	4:30:00 AM	0.27
7/5/2014	4:45:00 AM	0.27
7/5/2014	5:00:00 AM	0.27
7/5/2014	5:15:00 AM	0.27
7/5/2014	5:30:00 AM	0.27
7/5/2014	5:45:00 AM	0.27
7/5/2014	6:00:00 AM	0.27
7/5/2014	6:15:00 AM	0.27
7/5/2014	6:30:00 AM	0.27
7/5/2014	6:45:00 AM	0.27
7/5/2014	7:00:00 AM	0.27
7/5/2014	7:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/5/2014	7:30:00 AM	0.27
7/5/2014	7:45:00 AM	0.27
7/5/2014	8:00:00 AM	0.27
7/5/2014	8:15:00 AM	0.27
7/5/2014	8:30:00 AM	0.27
7/5/2014	8:45:00 AM	0.27
7/5/2014	9:00:00 AM	0.27
7/5/2014	9:15:00 AM	0.27
7/5/2014	9:30:00 AM	0.27
7/5/2014	9:45:00 AM	0.27
7/5/2014	10:00:00 AM	0.27
7/5/2014	10:15:00 AM	0.27
7/5/2014	10:30:00 AM	0.27
7/5/2014	10:45:00 AM	0.27
7/5/2014	11:00:00 AM	0.27
7/5/2014	11:15:00 AM	0.27
7/5/2014	11:30:00 AM	0.27
7/5/2014	11:45:00 AM	0.27
7/5/2014	12:00:00 PM	0.27
7/5/2014	12:15:00 PM	0.27
7/5/2014	12:30:00 PM	0.27
7/5/2014	12:45:00 PM	0.27
7/5/2014	1:00:00 PM	0.27
7/5/2014	1:15:00 PM	0.27
7/5/2014	1:30:00 PM	0.27
7/5/2014	1:45:00 PM	0.27
7/5/2014	2:00:00 PM	0.27
7/5/2014	2:15:00 PM	0.27
7/5/2014	2:30:00 PM	0.27
7/5/2014	2:45:00 PM	0.27
7/5/2014	3:00:00 PM	0.27
7/5/2014	3:15:00 PM	0.27
7/5/2014	3:30:00 PM	0.27
7/5/2014	3:45:00 PM	0.27
7/5/2014	4:00:00 PM	0.27
7/5/2014	4:15:00 PM	0.27
7/5/2014	4:30:00 PM	0.27
7/5/2014	4:45:00 PM	0.27
7/5/2014	5:00:00 PM	0.27
7/5/2014	5:15:00 PM	0.27
7/5/2014	5:30:00 PM	0.27
7/5/2014	5:45:00 PM	0.27
7/5/2014	6:00:00 PM	0.27
7/5/2014	6:15:00 PM	0.27
7/5/2014	6:30:00 PM	0.27
7/5/2014	6:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/5/2014	7:00:00 PM	0.27
7/5/2014	7:15:00 PM	0.27
7/5/2014	7:30:00 PM	0.27
7/5/2014	7:45:00 PM	0.27
7/5/2014	8:00:00 PM	0.27
7/5/2014	8:15:00 PM	0.27
7/5/2014	8:30:00 PM	0.27
7/5/2014	8:45:00 PM	0.27
7/5/2014	9:00:00 PM	0.27
7/5/2014	9:15:00 PM	0.27
7/5/2014	9:30:00 PM	0.27
7/5/2014	9:45:00 PM	0.27
7/5/2014	10:00:00 PM	0.27
7/5/2014	10:15:00 PM	0.27
7/5/2014	10:30:00 PM	0.27
7/5/2014	10:45:00 PM	0.27
7/5/2014	11:00:00 PM	0.27
7/5/2014	11:15:00 PM	0.27
7/5/2014	11:30:00 PM	0.27
7/5/2014	11:45:00 PM	0.27
7/6/2014	12:00:00 AM	0.27
7/6/2014	12:15:00 AM	0.27
7/6/2014	12:30:00 AM	0.27
7/6/2014	12:45:00 AM	0.27
7/6/2014	1:00:00 AM	0.27
7/6/2014	1:15:00 AM	0.27
7/6/2014	1:30:00 AM	0.27
7/6/2014	1:45:00 AM	0.27
7/6/2014	2:00:00 AM	0.27
7/6/2014	2:15:00 AM	0.27
7/6/2014	2:30:00 AM	0.27
7/6/2014	2:45:00 AM	0.27
7/6/2014	3:00:00 AM	0.27
7/6/2014	3:15:00 AM	0.27
7/6/2014	3:30:00 AM	0.27
7/6/2014	3:45:00 AM	0.27
7/6/2014	4:00:00 AM	0.27
7/6/2014	4:15:00 AM	0.27
7/6/2014	4:30:00 AM	0.27
7/6/2014	4:45:00 AM	0.27
7/6/2014	5:00:00 AM	0.27
7/6/2014	5:15:00 AM	0.27
7/6/2014	5:30:00 AM	0.27
7/6/2014	5:45:00 AM	0.27
7/6/2014	6:00:00 AM	0.27
7/6/2014	6:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/6/2014	6:30:00 AM	0.27
7/6/2014	6:45:00 AM	0.27
7/6/2014	7:00:00 AM	0.27
7/6/2014	7:15:00 AM	0.27
7/6/2014	7:30:00 AM	0.27
7/6/2014	7:45:00 AM	0.27
7/6/2014	8:00:00 AM	0.27
7/6/2014	8:15:00 AM	0.27
7/6/2014	8:30:00 AM	0.27
7/6/2014	8:45:00 AM	0.27
7/6/2014	9:00:00 AM	0.27
7/6/2014	9:15:00 AM	0.27
7/6/2014	9:30:00 AM	0.27
7/6/2014	9:45:00 AM	0.27
7/6/2014	10:00:00 AM	0.27
7/6/2014	10:15:00 AM	0.27
7/6/2014	10:30:00 AM	0.27
7/6/2014	10:45:00 AM	0.27
7/6/2014	11:00:00 AM	0.27
7/6/2014	11:15:00 AM	0.27
7/6/2014	11:30:00 AM	0.27
7/6/2014	11:45:00 AM	0.27
7/6/2014	12:00:00 PM	0.27
7/6/2014	12:15:00 PM	0.27
7/6/2014	12:30:00 PM	0.27
7/6/2014	12:45:00 PM	0.27
7/6/2014	1:00:00 PM	0.27
7/6/2014	1:15:00 PM	0.27
7/6/2014	1:30:00 PM	0.27
7/6/2014	1:45:00 PM	0.27
7/6/2014	2:00:00 PM	0.27
7/6/2014	2:15:00 PM	0.27
7/6/2014	2:30:00 PM	0.27
7/6/2014	2:45:00 PM	0.27
7/6/2014	3:00:00 PM	0.27
7/6/2014	3:15:00 PM	0.27
7/6/2014	3:30:00 PM	0.27
7/6/2014	3:45:00 PM	0.27
7/6/2014	4:00:00 PM	0.27
7/6/2014	4:15:00 PM	0.27
7/6/2014	4:30:00 PM	0.27
7/6/2014	4:45:00 PM	0.27
7/6/2014	5:00:00 PM	0.27
7/6/2014	5:15:00 PM	0.27
7/6/2014	5:30:00 PM	0.27
7/6/2014	5:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/6/2014	6:00:00 PM	0.27
7/6/2014	6:15:00 PM	0.27
7/6/2014	6:30:00 PM	0.27
7/6/2014	6:45:00 PM	0.27
7/6/2014	7:00:00 PM	0.27
7/6/2014	7:15:00 PM	0.27
7/6/2014	7:30:00 PM	0.27
7/6/2014	7:45:00 PM	0.27
7/6/2014	8:00:00 PM	0.27
7/6/2014	8:15:00 PM	0.27
7/6/2014	8:30:00 PM	0.27
7/6/2014	8:45:00 PM	0.27
7/6/2014	9:00:00 PM	0.27
7/6/2014	9:15:00 PM	0.27
7/6/2014	9:30:00 PM	0.27
7/6/2014	9:45:00 PM	0.27
7/6/2014	10:00:00 PM	0.27
7/6/2014	10:15:00 PM	0.27
7/6/2014	10:30:00 PM	0.27
7/6/2014	10:45:00 PM	0.27
7/6/2014	11:00:00 PM	0.27
7/6/2014	11:15:00 PM	0.27
7/6/2014	11:30:00 PM	0.27
7/6/2014	11:45:00 PM	0.27
7/7/2014	12:00:00 AM	0.27
7/7/2014	12:15:00 AM	0.27
7/7/2014	12:30:00 AM	0.27
7/7/2014	12:45:00 AM	0.27
7/7/2014	1:00:00 AM	0.27
7/7/2014	1:15:00 AM	0.27
7/7/2014	1:30:00 AM	0.27
7/7/2014	1:45:00 AM	0.27
7/7/2014	2:00:00 AM	0.27
7/7/2014	2:15:00 AM	0.27
7/7/2014	2:30:00 AM	0.27
7/7/2014	2:45:00 AM	0.27
7/7/2014	3:00:00 AM	0.27
7/7/2014	3:15:00 AM	0.27
7/7/2014	3:30:00 AM	0.27
7/7/2014	3:45:00 AM	0.27
7/7/2014	4:00:00 AM	0.27
7/7/2014	4:15:00 AM	0.27
7/7/2014	4:30:00 AM	0.27
7/7/2014	4:45:00 AM	0.27
7/7/2014	5:00:00 AM	0.27
7/7/2014	5:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/7/2014	5:30:00 AM	0.27
7/7/2014	5:45:00 AM	0.27
7/7/2014	6:00:00 AM	0.27
7/7/2014	6:15:00 AM	0.27
7/7/2014	6:30:00 AM	0.27
7/7/2014	6:45:00 AM	0.27
7/7/2014	7:00:00 AM	0.27
7/7/2014	7:15:00 AM	0.27
7/7/2014	7:30:00 AM	0.27
7/7/2014	7:45:00 AM	0.27
7/7/2014	8:00:00 AM	0.27
7/7/2014	8:15:00 AM	0.27
7/7/2014	8:30:00 AM	0.27
7/7/2014	8:45:00 AM	0.27
7/7/2014	9:00:00 AM	0.27
7/7/2014	9:15:00 AM	0.27
7/7/2014	9:30:00 AM	0.27
7/7/2014	9:45:00 AM	0.27
7/7/2014	10:00:00 AM	0.27
7/7/2014	10:15:00 AM	0.27
7/7/2014	10:30:00 AM	0.27
7/7/2014	10:45:00 AM	0.27
7/7/2014	11:00:00 AM	0.27
7/7/2014	11:15:00 AM	0.27
7/7/2014	11:30:00 AM	0.27
7/7/2014	11:45:00 AM	0.27
7/7/2014	12:00:00 PM	0.27
7/7/2014	12:15:00 PM	0.27
7/7/2014	12:30:00 PM	0.27
7/7/2014	12:45:00 PM	0.27
7/7/2014	1:00:00 PM	0.27
7/7/2014	1:15:00 PM	0.27
7/7/2014	1:30:00 PM	0.27
7/7/2014	1:45:00 PM	0.27
7/7/2014	2:00:00 PM	0.27
7/7/2014	2:15:00 PM	0.27
7/7/2014	2:30:00 PM	0.27
7/7/2014	2:45:00 PM	0.27
7/7/2014	3:00:00 PM	0.27
7/7/2014	3:15:00 PM	0.27
7/7/2014	3:30:00 PM	0.27
7/7/2014	3:45:00 PM	0.27
7/7/2014	4:00:00 PM	0.27
7/7/2014	4:15:00 PM	0.27
7/7/2014	4:30:00 PM	0.27
7/7/2014	4:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/7/2014	5:00:00 PM	0.27
7/7/2014	5:15:00 PM	0.27
7/7/2014	5:30:00 PM	0.27
7/7/2014	5:45:00 PM	0.27
7/7/2014	6:00:00 PM	0.27
7/7/2014	6:15:00 PM	0.27
7/7/2014	6:30:00 PM	0.27
7/7/2014	6:45:00 PM	0.27
7/7/2014	7:00:00 PM	0.27
7/7/2014	7:15:00 PM	0.27
7/7/2014	7:30:00 PM	0.27
7/7/2014	7:45:00 PM	0.27
7/7/2014	8:00:00 PM	0.27
7/7/2014	8:15:00 PM	0.27
7/7/2014	8:30:00 PM	0.27
7/7/2014	8:45:00 PM	0.27
7/7/2014	9:00:00 PM	0.27
7/7/2014	9:15:00 PM	0.27
7/7/2014	9:30:00 PM	0.27
7/7/2014	9:45:00 PM	0.27
7/7/2014	10:00:00 PM	0.27
7/7/2014	10:15:00 PM	0.27
7/7/2014	10:30:00 PM	0.27
7/7/2014	10:45:00 PM	0.27
7/7/2014	11:00:00 PM	0.27
7/7/2014	11:15:00 PM	0.27
7/7/2014	11:30:00 PM	0.27
7/7/2014	11:45:00 PM	0.27
7/8/2014	12:00:00 AM	0.27
7/8/2014	12:15:00 AM	0.27
7/8/2014	12:30:00 AM	0.27
7/8/2014	12:45:00 AM	0.27
7/8/2014	1:00:00 AM	0.27
7/8/2014	1:15:00 AM	0.27
7/8/2014	1:30:00 AM	0.27
7/8/2014	1:45:00 AM	0.27
7/8/2014	2:00:00 AM	0.27
7/8/2014	2:15:00 AM	0.27
7/8/2014	2:30:00 AM	0.27
7/8/2014	2:45:00 AM	0.27
7/8/2014	3:00:00 AM	0.27
7/8/2014	3:15:00 AM	0.27
7/8/2014	3:30:00 AM	0.27
7/8/2014	3:45:00 AM	0.27
7/8/2014	4:00:00 AM	0.27
7/8/2014	4:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/8/2014	4:30:00 AM	0.27
7/8/2014	4:45:00 AM	0.27
7/8/2014	5:00:00 AM	0.27
7/8/2014	5:15:00 AM	0.27
7/8/2014	5:30:00 AM	0.27
7/8/2014	5:45:00 AM	0.27
7/8/2014	6:00:00 AM	0.27
7/8/2014	6:15:00 AM	0.27
7/8/2014	6:30:00 AM	0.27
7/8/2014	6:45:00 AM	0.27
7/8/2014	7:00:00 AM	0.27
7/8/2014	7:15:00 AM	0.27
7/8/2014	7:30:00 AM	0.27
7/8/2014	7:45:00 AM	0.27
7/8/2014	8:00:00 AM	0.27
7/8/2014	8:15:00 AM	0.27
7/8/2014	8:30:00 AM	0.27
7/8/2014	8:45:00 AM	0.27
7/8/2014	9:00:00 AM	0.27
7/8/2014	9:15:00 AM	0.27
7/8/2014	9:30:00 AM	0.27
7/8/2014	9:45:00 AM	0.27
7/8/2014	10:00:00 AM	0.27
7/8/2014	10:15:00 AM	0.27
7/8/2014	10:30:00 AM	0.27
7/8/2014	10:45:00 AM	0.27
7/8/2014	11:00:00 AM	0.27
7/8/2014	11:15:00 AM	0.27
7/8/2014	11:30:00 AM	0.27
7/8/2014	11:45:00 AM	0.27
7/8/2014	12:00:00 PM	0.27
7/8/2014	12:15:00 PM	0.27
7/8/2014	12:30:00 PM	0.27
7/8/2014	12:45:00 PM	0.27
7/8/2014	1:00:00 PM	0.27
7/8/2014	1:15:00 PM	0.27
7/8/2014	1:30:00 PM	0.27
7/8/2014	1:45:00 PM	0.27
7/8/2014	2:00:00 PM	0.27
7/8/2014	2:15:00 PM	0.26
7/8/2014	2:30:00 PM	0.26
7/8/2014	2:45:00 PM	0.26
7/8/2014	3:00:00 PM	0.26
7/8/2014	3:15:00 PM	0.26
7/8/2014	3:30:00 PM	0.26
7/8/2014	3:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/8/2014	4:00:00 PM	0.26
7/8/2014	4:15:00 PM	0.26
7/8/2014	4:30:00 PM	0.26
7/8/2014	4:45:00 PM	0.26
7/8/2014	5:00:00 PM	0.26
7/8/2014	5:15:00 PM	0.26
7/8/2014	5:30:00 PM	0.26
7/8/2014	5:45:00 PM	0.26
7/8/2014	6:00:00 PM	0.26
7/8/2014	6:15:00 PM	0.26
7/8/2014	6:30:00 PM	0.26
7/8/2014	6:45:00 PM	0.26
7/8/2014	7:00:00 PM	0.26
7/8/2014	7:15:00 PM	0.26
7/8/2014	7:30:00 PM	0.26
7/8/2014	7:45:00 PM	0.26
7/8/2014	8:00:00 PM	0.26
7/8/2014	8:15:00 PM	0.26
7/8/2014	8:30:00 PM	0.26
7/8/2014	8:45:00 PM	0.26
7/8/2014	9:00:00 PM	0.26
7/8/2014	9:15:00 PM	0.26
7/8/2014	9:30:00 PM	0.26
7/8/2014	9:45:00 PM	0.26
7/8/2014	10:00:00 PM	0.26
7/8/2014	10:15:00 PM	0.26
7/8/2014	10:30:00 PM	0.26
7/8/2014	10:45:00 PM	0.26
7/8/2014	11:00:00 PM	0.26
7/8/2014	11:15:00 PM	0.26
7/8/2014	11:30:00 PM	0.26
7/8/2014	11:45:00 PM	0.27
7/9/2014	12:00:00 AM	0.27
7/9/2014	12:15:00 AM	0.27
7/9/2014	12:30:00 AM	0.27
7/9/2014	12:45:00 AM	0.27
7/9/2014	1:00:00 AM	0.27
7/9/2014	1:15:00 AM	0.27
7/9/2014	1:30:00 AM	0.27
7/9/2014	1:45:00 AM	0.27
7/9/2014	2:00:00 AM	0.27
7/9/2014	2:15:00 AM	0.27
7/9/2014	2:30:00 AM	0.27
7/9/2014	2:45:00 AM	0.27
7/9/2014	3:00:00 AM	0.27
7/9/2014	3:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/9/2014	3:30:00 AM	0.27
7/9/2014	3:45:00 AM	0.27
7/9/2014	4:00:00 AM	0.27
7/9/2014	4:15:00 AM	0.27
7/9/2014	4:30:00 AM	0.27
7/9/2014	4:45:00 AM	0.27
7/9/2014	5:00:00 AM	0.27
7/9/2014	5:15:00 AM	0.27
7/9/2014	5:30:00 AM	0.27
7/9/2014	5:45:00 AM	0.27
7/9/2014	6:00:00 AM	0.27
7/9/2014	6:15:00 AM	0.27
7/9/2014	6:30:00 AM	0.27
7/9/2014	6:45:00 AM	0.27
7/9/2014	7:00:00 AM	0.27
7/9/2014	7:15:00 AM	0.27
7/9/2014	7:30:00 AM	0.27
7/9/2014	7:45:00 AM	0.27
7/9/2014	8:00:00 AM	0.27
7/9/2014	8:15:00 AM	0.27
7/9/2014	8:30:00 AM	0.27
7/9/2014	8:45:00 AM	0.27
7/9/2014	9:00:00 AM	0.27
7/9/2014	9:15:00 AM	0.27
7/9/2014	9:30:00 AM	0.27
7/9/2014	9:45:00 AM	0.27
7/9/2014	10:00:00 AM	0.27
7/9/2014	10:15:00 AM	0.27
7/9/2014	10:30:00 AM	0.27
7/9/2014	10:45:00 AM	0.27
7/9/2014	11:00:00 AM	0.27
7/9/2014	11:15:00 AM	0.27
7/9/2014	11:30:00 AM	0.27
7/9/2014	11:45:00 AM	0.27
7/9/2014	12:00:00 PM	0.27
7/9/2014	12:15:00 PM	0.27
7/9/2014	12:30:00 PM	0.27
7/9/2014	12:45:00 PM	0.27
7/9/2014	1:00:00 PM	0.27
7/9/2014	1:15:00 PM	0.27
7/9/2014	1:30:00 PM	0.27
7/9/2014	1:45:00 PM	0.27
7/9/2014	2:00:00 PM	0.27
7/9/2014	2:15:00 PM	0.27
7/9/2014	2:30:00 PM	0.27
7/9/2014	2:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/9/2014	3:00:00 PM	0.27
7/9/2014	3:15:00 PM	0.27
7/9/2014	3:30:00 PM	0.27
7/9/2014	3:45:00 PM	0.27
7/9/2014	4:00:00 PM	0.27
7/9/2014	4:15:00 PM	0.27
7/9/2014	4:30:00 PM	0.27
7/9/2014	4:45:00 PM	0.27
7/9/2014	5:00:00 PM	0.27
7/9/2014	5:15:00 PM	0.27
7/9/2014	5:30:00 PM	0.27
7/9/2014	5:45:00 PM	0.27
7/9/2014	6:00:00 PM	0.27
7/9/2014	6:15:00 PM	0.27
7/9/2014	6:30:00 PM	0.27
7/9/2014	6:45:00 PM	0.27
7/9/2014	7:00:00 PM	0.27
7/9/2014	7:15:00 PM	0.27
7/9/2014	7:30:00 PM	0.27
7/9/2014	7:45:00 PM	0.27
7/9/2014	8:00:00 PM	0.27
7/9/2014	8:15:00 PM	0.27
7/9/2014	8:30:00 PM	0.27
7/9/2014	8:45:00 PM	0.27
7/9/2014	9:00:00 PM	0.27
7/9/2014	9:15:00 PM	0.27
7/9/2014	9:30:00 PM	0.27
7/9/2014	9:45:00 PM	0.27
7/9/2014	10:00:00 PM	0.27
7/9/2014	10:15:00 PM	0.27
7/9/2014	10:30:00 PM	0.28
7/9/2014	10:45:00 PM	0.28
7/9/2014	11:00:00 PM	0.28
7/9/2014	11:15:00 PM	0.28
7/9/2014	11:30:00 PM	0.28
7/9/2014	11:45:00 PM	0.28
7/10/2014	12:00:00 AM	0.28
7/10/2014	12:15:00 AM	0.28
7/10/2014	12:30:00 AM	0.28
7/10/2014	12:45:00 AM	0.28
7/10/2014	1:00:00 AM	0.28
7/10/2014	1:15:00 AM	0.28
7/10/2014	1:30:00 AM	0.28
7/10/2014	1:45:00 AM	0.28
7/10/2014	2:00:00 AM	0.28
7/10/2014	2:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/10/2014	2:30:00 AM	0.28
7/10/2014	2:45:00 AM	0.28
7/10/2014	3:00:00 AM	0.28
7/10/2014	3:15:00 AM	0.28
7/10/2014	3:30:00 AM	0.28
7/10/2014	3:45:00 AM	0.28
7/10/2014	4:00:00 AM	0.28
7/10/2014	4:15:00 AM	0.28
7/10/2014	4:30:00 AM	0.28
7/10/2014	4:45:00 AM	0.28
7/10/2014	5:00:00 AM	0.28
7/10/2014	5:15:00 AM	0.28
7/10/2014	5:30:00 AM	0.28
7/10/2014	5:45:00 AM	0.28
7/10/2014	6:00:00 AM	0.28
7/10/2014	6:15:00 AM	0.28
7/10/2014	6:30:00 AM	0.28
7/10/2014	6:45:00 AM	0.28
7/10/2014	7:00:00 AM	0.28
7/10/2014	7:15:00 AM	0.28
7/10/2014	7:30:00 AM	0.28
7/10/2014	7:45:00 AM	0.28
7/10/2014	8:00:00 AM	0.28
7/10/2014	8:15:00 AM	0.28
7/10/2014	8:30:00 AM	0.28
7/10/2014	8:45:00 AM	0.28
7/10/2014	9:00:00 AM	0.28
7/10/2014	9:15:00 AM	0.28
7/10/2014	9:30:00 AM	0.28
7/10/2014	9:45:00 AM	0.28
7/10/2014	10:00:00 AM	0.28
7/10/2014	10:15:00 AM	0.28
7/10/2014	10:30:00 AM	0.28
7/10/2014	10:45:00 AM	0.28
7/10/2014	11:00:00 AM	0.28
7/10/2014	11:15:00 AM	0.28
7/10/2014	11:30:00 AM	0.28
7/10/2014	11:45:00 AM	0.28
7/10/2014	12:00:00 PM	0.28
7/10/2014	12:15:00 PM	0.28
7/10/2014	12:30:00 PM	0.28
7/10/2014	12:45:00 PM	0.28
7/10/2014	1:00:00 PM	0.28
7/10/2014	1:15:00 PM	0.28
7/10/2014	1:30:00 PM	0.28
7/10/2014	1:45:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/10/2014	2:00:00 PM	0.28
7/10/2014	2:15:00 PM	0.28
7/10/2014	2:30:00 PM	0.28
7/10/2014	2:45:00 PM	0.28
7/10/2014	3:00:00 PM	0.28
7/10/2014	3:15:00 PM	0.28
7/10/2014	3:30:00 PM	0.28
7/10/2014	3:45:00 PM	0.28
7/10/2014	4:00:00 PM	0.28
7/10/2014	4:15:00 PM	0.28
7/10/2014	4:30:00 PM	0.28
7/10/2014	4:45:00 PM	0.28
7/10/2014	5:00:00 PM	0.28
7/10/2014	5:15:00 PM	0.28
7/10/2014	5:30:00 PM	0.28
7/10/2014	5:45:00 PM	0.28
7/10/2014	6:00:00 PM	0.28
7/10/2014	6:15:00 PM	0.28
7/10/2014	6:30:00 PM	0.28
7/10/2014	6:45:00 PM	0.28
7/10/2014	7:00:00 PM	0.28
7/10/2014	7:15:00 PM	0.28
7/10/2014	7:30:00 PM	0.28
7/10/2014	7:45:00 PM	0.28
7/10/2014	8:00:00 PM	0.28
7/10/2014	8:15:00 PM	0.28
7/10/2014	8:30:00 PM	0.28
7/10/2014	8:45:00 PM	0.28
7/10/2014	9:00:00 PM	0.28
7/10/2014	9:15:00 PM	0.28
7/10/2014	9:30:00 PM	0.28
7/10/2014	9:45:00 PM	0.28
7/10/2014	10:00:00 PM	0.28
7/10/2014	10:15:00 PM	0.28
7/10/2014	10:30:00 PM	0.28
7/10/2014	10:45:00 PM	0.28
7/10/2014	11:00:00 PM	0.29
7/10/2014	11:15:00 PM	0.29
7/10/2014	11:30:00 PM	0.29
7/10/2014	11:45:00 PM	0.29
7/11/2014	12:00:00 AM	0.29
7/11/2014	12:15:00 AM	0.29
7/11/2014	12:30:00 AM	0.29
7/11/2014	12:45:00 AM	0.29
7/11/2014	1:00:00 AM	0.29
7/11/2014	1:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/11/2014	1:30:00 AM	0.29
7/11/2014	1:45:00 AM	0.29
7/11/2014	2:00:00 AM	0.29
7/11/2014	2:15:00 AM	0.29
7/11/2014	2:30:00 AM	0.29
7/11/2014	2:45:00 AM	0.29
7/11/2014	3:00:00 AM	0.29
7/11/2014	3:15:00 AM	0.29
7/11/2014	3:30:00 AM	0.29
7/11/2014	3:45:00 AM	0.29
7/11/2014	4:00:00 AM	0.29
7/11/2014	4:15:00 AM	0.29
7/11/2014	4:30:00 AM	0.29
7/11/2014	4:45:00 AM	0.29
7/11/2014	5:00:00 AM	0.29
7/11/2014	5:15:00 AM	0.29
7/11/2014	5:30:00 AM	0.29
7/11/2014	5:45:00 AM	0.29
7/11/2014	6:00:00 AM	0.29
7/11/2014	6:15:00 AM	0.29
7/11/2014	6:30:00 AM	0.29
7/11/2014	6:45:00 AM	0.29
7/11/2014	7:00:00 AM	0.29
7/11/2014	7:15:00 AM	0.29
7/11/2014	7:30:00 AM	0.29
7/11/2014	7:45:00 AM	0.29
7/11/2014	8:00:00 AM	0.29
7/11/2014	8:15:00 AM	0.29
7/11/2014	8:30:00 AM	0.29
7/11/2014	8:45:00 AM	0.29
7/11/2014	9:00:00 AM	0.29
7/11/2014	9:15:00 AM	0.29
7/11/2014	9:30:00 AM	0.29
7/11/2014	9:45:00 AM	0.29
7/11/2014	10:00:00 AM	0.29
7/11/2014	10:15:00 AM	0.29
7/11/2014	10:30:00 AM	0.29
7/11/2014	10:45:00 AM	0.29
7/11/2014	11:00:00 AM	0.29
7/11/2014	11:15:00 AM	0.29
7/11/2014	11:30:00 AM	0.29
7/11/2014	11:45:00 AM	0.29
7/11/2014	12:00:00 PM	0.29
7/11/2014	12:15:00 PM	0.29
7/11/2014	12:30:00 PM	0.29
7/11/2014	12:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/11/2014	1:00:00 PM	0.29
7/11/2014	1:15:00 PM	0.29
7/11/2014	1:30:00 PM	0.29
7/11/2014	1:45:00 PM	0.29
7/11/2014	2:00:00 PM	0.29
7/11/2014	2:15:00 PM	0.29
7/11/2014	2:30:00 PM	0.29
7/11/2014	2:45:00 PM	0.29
7/11/2014	3:00:00 PM	0.28
7/11/2014	3:15:00 PM	0.28
7/11/2014	3:30:00 PM	0.28
7/11/2014	3:45:00 PM	0.28
7/11/2014	4:00:00 PM	0.28
7/11/2014	4:15:00 PM	0.28
7/11/2014	4:30:00 PM	0.28
7/11/2014	4:45:00 PM	0.28
7/11/2014	5:00:00 PM	0.28
7/11/2014	5:15:00 PM	0.28
7/11/2014	5:30:00 PM	0.28
7/11/2014	5:45:00 PM	0.28
7/11/2014	6:00:00 PM	0.28
7/11/2014	6:15:00 PM	0.28
7/11/2014	6:30:00 PM	0.28
7/11/2014	6:45:00 PM	0.28
7/11/2014	7:00:00 PM	0.28
7/11/2014	7:15:00 PM	0.28
7/11/2014	7:30:00 PM	0.28
7/11/2014	7:45:00 PM	0.28
7/11/2014	8:00:00 PM	0.29
7/11/2014	8:15:00 PM	0.29
7/11/2014	8:30:00 PM	0.29
7/11/2014	8:45:00 PM	0.28
7/11/2014	9:00:00 PM	0.29
7/11/2014	9:15:00 PM	0.29
7/11/2014	9:30:00 PM	0.29
7/11/2014	9:45:00 PM	0.29
7/11/2014	10:00:00 PM	0.29
7/11/2014	10:15:00 PM	0.29
7/11/2014	10:30:00 PM	0.29
7/11/2014	10:45:00 PM	0.29
7/11/2014	11:00:00 PM	0.29
7/11/2014	11:15:00 PM	0.29
7/11/2014	11:30:00 PM	0.29
7/11/2014	11:45:00 PM	0.29
7/12/2014	12:00:00 AM	0.29
7/12/2014	12:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2014	12:30:00 AM	0.29
7/12/2014	12:45:00 AM	0.29
7/12/2014	1:00:00 AM	0.29
7/12/2014	1:15:00 AM	0.29
7/12/2014	1:30:00 AM	0.29
7/12/2014	1:45:00 AM	0.29
7/12/2014	2:00:00 AM	0.29
7/12/2014	2:15:00 AM	0.29
7/12/2014	2:30:00 AM	0.29
7/12/2014	2:45:00 AM	0.29
7/12/2014	3:00:00 AM	0.29
7/12/2014	3:15:00 AM	0.29
7/12/2014	3:30:00 AM	0.29
7/12/2014	3:45:00 AM	0.29
7/12/2014	4:00:00 AM	0.29
7/12/2014	4:15:00 AM	0.29
7/12/2014	4:30:00 AM	0.29
7/12/2014	4:45:00 AM	0.29
7/12/2014	5:00:00 AM	0.29
7/12/2014	5:15:00 AM	0.29
7/12/2014	5:30:00 AM	0.29
7/12/2014	5:45:00 AM	0.29
7/12/2014	6:00:00 AM	0.29
7/12/2014	6:15:00 AM	0.29
7/12/2014	6:30:00 AM	0.29
7/12/2014	6:45:00 AM	0.29
7/12/2014	7:00:00 AM	0.29
7/12/2014	7:15:00 AM	0.29
7/12/2014	7:30:00 AM	0.29
7/12/2014	7:45:00 AM	0.29
7/12/2014	8:00:00 AM	0.29
7/12/2014	8:15:00 AM	0.3
7/12/2014	8:30:00 AM	0.3
7/12/2014	8:45:00 AM	0.3
7/12/2014	9:00:00 AM	0.3
7/12/2014	9:15:00 AM	0.3
7/12/2014	9:30:00 AM	0.3
7/12/2014	9:45:00 AM	0.3
7/12/2014	10:00:00 AM	0.3
7/12/2014	10:15:00 AM	0.3
7/12/2014	10:30:00 AM	0.3
7/12/2014	10:45:00 AM	0.3
7/12/2014	11:00:00 AM	0.3
7/12/2014	11:15:00 AM	0.3
7/12/2014	11:30:00 AM	0.3
7/12/2014	11:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2014	12:00:00 PM	0.3
7/12/2014	12:15:00 PM	0.3
7/12/2014	12:30:00 PM	0.3
7/12/2014	12:45:00 PM	0.3
7/12/2014	1:00:00 PM	0.3
7/12/2014	1:15:00 PM	0.3
7/12/2014	1:30:00 PM	0.3
7/12/2014	1:45:00 PM	0.3
7/12/2014	2:00:00 PM	0.3
7/12/2014	2:15:00 PM	0.3
7/12/2014	2:30:00 PM	0.3
7/12/2014	2:45:00 PM	0.3
7/12/2014	3:00:00 PM	0.3
7/12/2014	3:15:00 PM	0.29
7/12/2014	3:30:00 PM	0.29
7/12/2014	3:45:00 PM	0.29
7/12/2014	4:00:00 PM	0.29
7/12/2014	4:15:00 PM	0.29
7/12/2014	4:30:00 PM	0.29
7/12/2014	4:45:00 PM	0.29
7/12/2014	5:00:00 PM	0.29
7/12/2014	5:15:00 PM	0.29
7/12/2014	5:30:00 PM	0.29
7/12/2014	5:45:00 PM	0.29
7/12/2014	6:00:00 PM	0.29
7/12/2014	6:15:00 PM	0.29
7/12/2014	6:30:00 PM	0.29
7/12/2014	6:45:00 PM	0.29
7/12/2014	7:00:00 PM	0.29
7/12/2014	7:15:00 PM	0.29
7/12/2014	7:30:00 PM	0.29
7/12/2014	7:45:00 PM	0.29
7/12/2014	8:00:00 PM	0.29
7/12/2014	8:15:00 PM	0.29
7/12/2014	8:30:00 PM	0.29
7/12/2014	8:45:00 PM	0.29
7/12/2014	9:00:00 PM	0.29
7/12/2014	9:15:00 PM	0.29
7/12/2014	9:30:00 PM	0.29
7/12/2014	9:45:00 PM	0.29
7/12/2014	10:00:00 PM	0.29
7/12/2014	10:15:00 PM	0.29
7/12/2014	10:30:00 PM	0.29
7/12/2014	10:45:00 PM	0.29
7/12/2014	11:00:00 PM	0.29
7/12/2014	11:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2014	11:30:00 PM	0.29
7/12/2014	11:45:00 PM	0.29
7/13/2014	12:00:00 AM	0.29
7/13/2014	12:15:00 AM	0.29
7/13/2014	12:30:00 AM	0.29
7/13/2014	12:45:00 AM	0.29
7/13/2014	1:00:00 AM	0.29
7/13/2014	1:15:00 AM	0.29
7/13/2014	1:30:00 AM	0.29
7/13/2014	1:45:00 AM	0.29
7/13/2014	2:00:00 AM	0.29
7/13/2014	2:15:00 AM	0.29
7/13/2014	2:30:00 AM	0.29
7/13/2014	2:45:00 AM	0.29
7/13/2014	3:00:00 AM	0.29
7/13/2014	3:15:00 AM	0.29
7/13/2014	3:30:00 AM	0.29
7/13/2014	3:45:00 AM	0.29
7/13/2014	4:00:00 AM	0.29
7/13/2014	4:15:00 AM	0.29
7/13/2014	4:30:00 AM	0.29
7/13/2014	4:45:00 AM	0.29
7/13/2014	5:00:00 AM	0.29
7/13/2014	5:15:00 AM	0.29
7/13/2014	5:30:00 AM	0.29
7/13/2014	5:45:00 AM	0.29
7/13/2014	6:00:00 AM	0.29
7/13/2014	6:15:00 AM	0.29
7/13/2014	6:30:00 AM	0.29
7/13/2014	6:45:00 AM	0.29
7/13/2014	7:00:00 AM	0.29
7/13/2014	7:15:00 AM	0.29
7/13/2014	7:30:00 AM	0.29
7/13/2014	7:45:00 AM	0.29
7/13/2014	8:00:00 AM	0.29
7/13/2014	8:15:00 AM	0.29
7/13/2014	8:30:00 AM	0.29
7/13/2014	8:45:00 AM	0.29
7/13/2014	9:00:00 AM	0.29
7/13/2014	9:15:00 AM	0.29
7/13/2014	9:30:00 AM	0.29
7/13/2014	9:45:00 AM	0.29
7/13/2014	10:00:00 AM	0.29
7/13/2014	10:15:00 AM	0.29
7/13/2014	10:30:00 AM	0.29
7/13/2014	10:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/13/2014	11:00:00 AM	0.29
7/13/2014	11:15:00 AM	0.29
7/13/2014	11:30:00 AM	0.29
7/13/2014	11:45:00 AM	0.29
7/13/2014	12:00:00 PM	0.29
7/13/2014	12:15:00 PM	0.29
7/13/2014	12:30:00 PM	0.29
7/13/2014	12:45:00 PM	0.29
7/13/2014	1:00:00 PM	0.29
7/13/2014	1:15:00 PM	0.29
7/13/2014	1:30:00 PM	0.29
7/13/2014	1:45:00 PM	0.29
7/13/2014	2:00:00 PM	0.29
7/13/2014	2:15:00 PM	0.29
7/13/2014	2:30:00 PM	0.29
7/13/2014	2:45:00 PM	0.29
7/13/2014	3:00:00 PM	0.29
7/13/2014	3:15:00 PM	0.29
7/13/2014	3:30:00 PM	0.29
7/13/2014	3:45:00 PM	0.29
7/13/2014	4:00:00 PM	0.29
7/13/2014	4:15:00 PM	0.29
7/13/2014	4:30:00 PM	0.29
7/13/2014	4:45:00 PM	0.29
7/13/2014	5:00:00 PM	0.29
7/13/2014	5:15:00 PM	0.29
7/13/2014	5:30:00 PM	0.29
7/13/2014	5:45:00 PM	0.29
7/13/2014	6:00:00 PM	0.29
7/13/2014	6:15:00 PM	0.29
7/13/2014	6:30:00 PM	0.29
7/13/2014	6:45:00 PM	0.29
7/13/2014	7:00:00 PM	0.29
7/13/2014	7:15:00 PM	0.29
7/13/2014	7:30:00 PM	0.29
7/13/2014	7:45:00 PM	0.29
7/13/2014	8:00:00 PM	0.29
7/13/2014	8:15:00 PM	0.29
7/13/2014	8:30:00 PM	0.29
7/13/2014	8:45:00 PM	0.29
7/13/2014	9:00:00 PM	0.29
7/13/2014	9:15:00 PM	0.29
7/13/2014	9:30:00 PM	0.29
7/13/2014	9:45:00 PM	0.29
7/13/2014	10:00:00 PM	0.29
7/13/2014	10:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/13/2014	10:30:00 PM	0.29
7/13/2014	10:45:00 PM	0.29
7/13/2014	11:00:00 PM	0.29
7/13/2014	11:15:00 PM	0.29
7/13/2014	11:30:00 PM	0.29
7/13/2014	11:45:00 PM	0.29
7/14/2014	12:00:00 AM	0.29
7/14/2014	12:15:00 AM	0.29
7/14/2014	12:30:00 AM	0.29
7/14/2014	12:45:00 AM	0.29
7/14/2014	1:00:00 AM	0.29
7/14/2014	1:15:00 AM	0.29
7/14/2014	1:30:00 AM	0.29
7/14/2014	1:45:00 AM	0.29
7/14/2014	2:00:00 AM	0.29
7/14/2014	2:15:00 AM	0.29
7/14/2014	2:30:00 AM	0.29
7/14/2014	2:45:00 AM	0.29
7/14/2014	3:00:00 AM	0.29
7/14/2014	3:15:00 AM	0.29
7/14/2014	3:30:00 AM	0.29
7/14/2014	3:45:00 AM	0.29
7/14/2014	4:00:00 AM	0.29
7/14/2014	4:15:00 AM	0.29
7/14/2014	4:30:00 AM	0.29
7/14/2014	4:45:00 AM	0.29
7/14/2014	5:00:00 AM	0.29
7/14/2014	5:15:00 AM	0.29
7/14/2014	5:30:00 AM	0.29
7/14/2014	5:45:00 AM	0.29
7/14/2014	6:00:00 AM	0.29
7/14/2014	6:15:00 AM	0.29
7/14/2014	6:30:00 AM	0.29
7/14/2014	6:45:00 AM	0.29
7/14/2014	7:00:00 AM	0.29
7/14/2014	7:15:00 AM	0.29
7/14/2014	7:30:00 AM	0.29
7/14/2014	7:45:00 AM	0.29
7/14/2014	8:00:00 AM	0.29
7/14/2014	8:15:00 AM	0.29
7/14/2014	8:30:00 AM	0.29
7/14/2014	8:45:00 AM	0.29
7/14/2014	9:00:00 AM	0.29
7/14/2014	9:15:00 AM	0.29
7/14/2014	9:30:00 AM	0.29
7/14/2014	9:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/14/2014	10:00:00 AM	0.29
7/14/2014	10:15:00 AM	0.29
7/14/2014	10:30:00 AM	0.29
7/14/2014	10:45:00 AM	0.29
7/14/2014	11:00:00 AM	0.29
7/14/2014	11:15:00 AM	0.29
7/14/2014	11:30:00 AM	0.29
7/14/2014	11:45:00 AM	0.29
7/14/2014	12:00:00 PM	0.29
7/14/2014	12:15:00 PM	0.29
7/14/2014	12:30:00 PM	0.29
7/14/2014	12:45:00 PM	0.29
7/14/2014	1:00:00 PM	0.29
7/14/2014	1:15:00 PM	0.29
7/14/2014	1:30:00 PM	0.29
7/14/2014	1:45:00 PM	0.29
7/14/2014	2:00:00 PM	0.29
7/14/2014	2:15:00 PM	0.29
7/14/2014	2:30:00 PM	0.29
7/14/2014	2:45:00 PM	0.29
7/14/2014	3:00:00 PM	0.29
7/14/2014	3:15:00 PM	0.29
7/14/2014	3:30:00 PM	0.29
7/14/2014	3:45:00 PM	0.29
7/14/2014	4:00:00 PM	0.29
7/14/2014	4:15:00 PM	0.29
7/14/2014	4:30:00 PM	0.29
7/14/2014	4:45:00 PM	0.29
7/14/2014	5:00:00 PM	0.29
7/14/2014	5:15:00 PM	0.29
7/14/2014	5:30:00 PM	0.29
7/14/2014	5:45:00 PM	0.29
7/14/2014	6:00:00 PM	0.29
7/14/2014	6:15:00 PM	0.29
7/14/2014	6:30:00 PM	0.29
7/14/2014	6:45:00 PM	0.29
7/14/2014	7:00:00 PM	0.29
7/14/2014	7:15:00 PM	0.29
7/14/2014	7:30:00 PM	0.29
7/14/2014	7:45:00 PM	0.29
7/14/2014	8:00:00 PM	0.29
7/14/2014	8:15:00 PM	0.29
7/14/2014	8:30:00 PM	0.29
7/14/2014	8:45:00 PM	0.29
7/14/2014	9:00:00 PM	0.29
7/14/2014	9:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/14/2014	9:30:00 PM	0.29
7/14/2014	9:45:00 PM	0.29
7/14/2014	10:00:00 PM	0.29
7/14/2014	10:15:00 PM	0.29
7/14/2014	10:30:00 PM	0.29
7/14/2014	10:45:00 PM	0.29
7/14/2014	11:00:00 PM	0.29
7/14/2014	11:15:00 PM	0.29
7/14/2014	11:30:00 PM	0.29
7/14/2014	11:45:00 PM	0.29
7/15/2014	12:00:00 AM	0.29
7/15/2014	12:15:00 AM	0.29
7/15/2014	12:30:00 AM	0.29
7/15/2014	12:45:00 AM	0.29
7/15/2014	1:00:00 AM	0.29
7/15/2014	1:15:00 AM	0.29
7/15/2014	1:30:00 AM	0.29
7/15/2014	1:45:00 AM	0.29
7/15/2014	2:00:00 AM	0.29
7/15/2014	2:15:00 AM	0.29
7/15/2014	2:30:00 AM	0.29
7/15/2014	2:45:00 AM	0.29
7/15/2014	3:00:00 AM	0.29
7/15/2014	3:15:00 AM	0.29
7/15/2014	3:30:00 AM	0.29
7/15/2014	3:45:00 AM	0.29
7/15/2014	4:00:00 AM	0.29
7/15/2014	4:15:00 AM	0.29
7/15/2014	4:30:00 AM	0.29
7/15/2014	4:45:00 AM	0.29
7/15/2014	5:00:00 AM	0.29
7/15/2014	5:15:00 AM	0.29
7/15/2014	5:30:00 AM	0.29
7/15/2014	5:45:00 AM	0.29
7/15/2014	6:00:00 AM	0.29
7/15/2014	6:15:00 AM	0.29
7/15/2014	6:30:00 AM	0.29
7/15/2014	6:45:00 AM	0.29
7/15/2014	7:00:00 AM	0.29
7/15/2014	7:15:00 AM	0.29
7/15/2014	7:30:00 AM	0.29
7/15/2014	7:45:00 AM	0.29
7/15/2014	8:00:00 AM	0.29
7/15/2014	8:15:00 AM	0.29
7/15/2014	8:30:00 AM	0.29
7/15/2014	8:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/15/2014	9:00:00 AM	0.29
7/15/2014	9:15:00 AM	0.29
7/15/2014	9:30:00 AM	0.29
7/15/2014	9:45:00 AM	0.29
7/15/2014	10:00:00 AM	0.29
7/15/2014	10:15:00 AM	0.29
7/15/2014	10:30:00 AM	0.29
7/15/2014	10:45:00 AM	0.29
7/15/2014	11:00:00 AM	0.29
7/15/2014	11:15:00 AM	0.29
7/15/2014	11:30:00 AM	0.29
7/15/2014	11:45:00 AM	0.29
7/15/2014	12:00:00 PM	0.29
7/15/2014	12:15:00 PM	0.29
7/15/2014	12:30:00 PM	0.29
7/15/2014	12:45:00 PM	0.29
7/15/2014	1:00:00 PM	0.29
7/15/2014	1:15:00 PM	0.29
7/15/2014	1:30:00 PM	0.29
7/15/2014	1:45:00 PM	0.29
7/15/2014	2:00:00 PM	0.29
7/15/2014	2:15:00 PM	0.29
7/15/2014	2:30:00 PM	0.29
7/15/2014	2:45:00 PM	0.29
7/15/2014	3:00:00 PM	0.29
7/15/2014	3:15:00 PM	0.29
7/15/2014	3:30:00 PM	0.29
7/15/2014	3:45:00 PM	0.29
7/15/2014	4:00:00 PM	0.29
7/15/2014	4:15:00 PM	0.29
7/15/2014	4:30:00 PM	0.29
7/15/2014	4:45:00 PM	0.29
7/15/2014	5:00:00 PM	0.29
7/15/2014	5:15:00 PM	0.29
7/15/2014	5:30:00 PM	0.29
7/15/2014	5:45:00 PM	0.29
7/15/2014	6:00:00 PM	0.29
7/15/2014	6:15:00 PM	0.29
7/15/2014	6:30:00 PM	0.29
7/15/2014	6:45:00 PM	0.29
7/15/2014	7:00:00 PM	0.29
7/15/2014	7:15:00 PM	0.29
7/15/2014	7:30:00 PM	0.29
7/15/2014	7:45:00 PM	0.29
7/15/2014	8:00:00 PM	0.29
7/15/2014	8:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/15/2014	8:30:00 PM	0.29
7/15/2014	8:45:00 PM	0.29
7/15/2014	9:00:00 PM	0.29
7/15/2014	9:15:00 PM	0.29
7/15/2014	9:30:00 PM	0.29
7/15/2014	9:45:00 PM	0.29
7/15/2014	10:00:00 PM	0.29
7/15/2014	10:15:00 PM	0.29
7/15/2014	10:30:00 PM	0.29
7/15/2014	10:45:00 PM	0.29
7/15/2014	11:00:00 PM	0.29
7/15/2014	11:15:00 PM	0.29
7/15/2014	11:30:00 PM	0.29
7/15/2014	11:45:00 PM	0.29
7/16/2014	12:00:00 AM	0.29
7/16/2014	12:15:00 AM	0.29
7/16/2014	12:30:00 AM	0.29
7/16/2014	12:45:00 AM	0.29
7/16/2014	1:00:00 AM	0.29
7/16/2014	1:15:00 AM	0.29
7/16/2014	1:30:00 AM	0.29
7/16/2014	1:45:00 AM	0.29
7/16/2014	2:00:00 AM	0.29
7/16/2014	2:15:00 AM	0.29
7/16/2014	2:30:00 AM	0.29
7/16/2014	2:45:00 AM	0.29
7/16/2014	3:00:00 AM	0.29
7/16/2014	3:15:00 AM	0.29
7/16/2014	3:30:00 AM	0.29
7/16/2014	3:45:00 AM	0.29
7/16/2014	4:00:00 AM	0.29
7/16/2014	4:15:00 AM	0.29
7/16/2014	4:30:00 AM	0.29
7/16/2014	4:45:00 AM	0.29
7/16/2014	5:00:00 AM	0.29
7/16/2014	5:15:00 AM	0.29
7/16/2014	5:30:00 AM	0.29
7/16/2014	5:45:00 AM	0.29
7/16/2014	6:00:00 AM	0.29
7/16/2014	6:15:00 AM	0.29
7/16/2014	6:30:00 AM	0.29
7/16/2014	6:45:00 AM	0.29
7/16/2014	7:00:00 AM	0.29
7/16/2014	7:15:00 AM	0.29
7/16/2014	7:30:00 AM	0.29
7/16/2014	7:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/16/2014	8:00:00 AM	0.29
7/16/2014	8:15:00 AM	0.29
7/16/2014	8:30:00 AM	0.29
7/16/2014	8:45:00 AM	0.29
7/16/2014	9:00:00 AM	0.29
7/16/2014	9:15:00 AM	0.3
7/16/2014	9:30:00 AM	0.3
7/16/2014	9:45:00 AM	0.3
7/16/2014	10:00:00 AM	0.3
7/16/2014	10:15:00 AM	0.3
7/16/2014	10:30:00 AM	0.29
7/16/2014	10:45:00 AM	0.29
7/16/2014	11:00:00 AM	0.29
7/16/2014	11:15:00 AM	0.29
7/16/2014	11:30:00 AM	0.29
7/16/2014	11:45:00 AM	0.29
7/16/2014	12:00:00 PM	0.29
7/16/2014	12:15:00 PM	0.29
7/16/2014	12:30:00 PM	0.29
7/16/2014	12:45:00 PM	0.29
7/16/2014	1:00:00 PM	0.29
7/16/2014	1:15:00 PM	0.29
7/16/2014	1:30:00 PM	0.29
7/16/2014	1:45:00 PM	0.29
7/16/2014	2:00:00 PM	0.29
7/16/2014	2:15:00 PM	0.29
7/16/2014	2:30:00 PM	0.29
7/16/2014	2:45:00 PM	0.29
7/16/2014	3:00:00 PM	0.29
7/16/2014	3:15:00 PM	0.29
7/16/2014	3:30:00 PM	0.29
7/16/2014	3:45:00 PM	0.29
7/16/2014	4:00:00 PM	0.29
7/16/2014	4:15:00 PM	0.29
7/16/2014	4:30:00 PM	0.29
7/16/2014	4:45:00 PM	0.29
7/16/2014	5:00:00 PM	0.29
7/16/2014	5:15:00 PM	0.29
7/16/2014	5:30:00 PM	0.29
7/16/2014	5:45:00 PM	0.29
7/16/2014	6:00:00 PM	0.29
7/16/2014	6:15:00 PM	0.29
7/16/2014	6:30:00 PM	0.29
7/16/2014	6:45:00 PM	0.29
7/16/2014	7:00:00 PM	0.29
7/16/2014	7:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/16/2014	7:30:00 PM	0.29
7/16/2014	7:45:00 PM	0.29
7/16/2014	8:00:00 PM	0.29
7/16/2014	8:15:00 PM	0.29
7/16/2014	8:30:00 PM	0.29
7/16/2014	8:45:00 PM	0.29
7/16/2014	9:00:00 PM	0.29
7/16/2014	9:15:00 PM	0.29
7/16/2014	9:30:00 PM	0.29
7/16/2014	9:45:00 PM	0.29
7/16/2014	10:00:00 PM	0.29
7/16/2014	10:15:00 PM	0.29
7/16/2014	10:30:00 PM	0.29
7/16/2014	10:45:00 PM	0.29
7/16/2014	11:00:00 PM	0.29
7/16/2014	11:15:00 PM	0.29
7/16/2014	11:30:00 PM	0.29
7/16/2014	11:45:00 PM	0.29
7/17/2014	12:00:00 AM	0.29
7/17/2014	12:15:00 AM	0.29
7/17/2014	12:30:00 AM	0.29
7/17/2014	12:45:00 AM	0.29
7/17/2014	1:00:00 AM	0.29
7/17/2014	1:15:00 AM	0.29
7/17/2014	1:30:00 AM	0.29
7/17/2014	1:45:00 AM	0.29
7/17/2014	2:00:00 AM	0.29
7/17/2014	2:15:00 AM	0.29
7/17/2014	2:30:00 AM	0.29
7/17/2014	2:45:00 AM	0.29
7/17/2014	3:00:00 AM	0.29
7/17/2014	3:15:00 AM	0.29
7/17/2014	3:30:00 AM	0.29
7/17/2014	3:45:00 AM	0.29
7/17/2014	4:00:00 AM	0.29
7/17/2014	4:15:00 AM	0.29
7/17/2014	4:30:00 AM	0.29
7/17/2014	4:45:00 AM	0.29
7/17/2014	5:00:00 AM	0.29
7/17/2014	5:15:00 AM	0.29
7/17/2014	5:30:00 AM	0.29
7/17/2014	5:45:00 AM	0.29
7/17/2014	6:00:00 AM	0.29
7/17/2014	6:15:00 AM	0.29
7/17/2014	6:30:00 AM	0.29
7/17/2014	6:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/17/2014	7:00:00 AM	0.29
7/17/2014	7:15:00 AM	0.29
7/17/2014	7:30:00 AM	0.29
7/17/2014	7:45:00 AM	0.29
7/17/2014	8:00:00 AM	0.29
7/17/2014	8:15:00 AM	0.29
7/17/2014	8:30:00 AM	0.29
7/17/2014	8:45:00 AM	0.29
7/17/2014	9:00:00 AM	0.29
7/17/2014	9:15:00 AM	0.29
7/17/2014	9:30:00 AM	0.29
7/17/2014	9:45:00 AM	0.29
7/17/2014	10:00:00 AM	0.29
7/17/2014	10:15:00 AM	0.29
7/17/2014	10:30:00 AM	0.29
7/17/2014	10:45:00 AM	0.29
7/17/2014	11:00:00 AM	0.29
7/17/2014	11:15:00 AM	0.29
7/17/2014	11:30:00 AM	0.29
7/17/2014	11:45:00 AM	0.29
7/17/2014	12:00:00 PM	0.29
7/17/2014	12:15:00 PM	0.29
7/17/2014	12:30:00 PM	0.29
7/17/2014	12:45:00 PM	0.29
7/17/2014	1:00:00 PM	0.29
7/17/2014	1:15:00 PM	0.29
7/17/2014	1:30:00 PM	0.29
7/17/2014	1:45:00 PM	0.29
7/17/2014	2:00:00 PM	0.29
7/17/2014	2:15:00 PM	0.29
7/17/2014	2:30:00 PM	0.29
7/17/2014	2:45:00 PM	0.29
7/17/2014	3:00:00 PM	0.29
7/17/2014	3:15:00 PM	0.29
7/17/2014	3:30:00 PM	0.29
7/17/2014	3:45:00 PM	0.29
7/17/2014	4:00:00 PM	0.29
7/17/2014	4:15:00 PM	0.29
7/17/2014	4:30:00 PM	0.29
7/17/2014	4:45:00 PM	0.29
7/17/2014	5:00:00 PM	0.28
7/17/2014	5:15:00 PM	0.28
7/17/2014	5:30:00 PM	0.28
7/17/2014	5:45:00 PM	0.28
7/17/2014	6:00:00 PM	0.28
7/17/2014	6:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/17/2014	6:30:00 PM	0.28
7/17/2014	6:45:00 PM	0.28
7/17/2014	7:00:00 PM	0.28
7/17/2014	7:15:00 PM	0.28
7/17/2014	7:30:00 PM	0.28
7/17/2014	7:45:00 PM	0.28
7/17/2014	8:00:00 PM	0.28
7/17/2014	8:15:00 PM	0.28
7/17/2014	8:30:00 PM	0.28
7/17/2014	8:45:00 PM	0.28
7/17/2014	9:00:00 PM	0.28
7/17/2014	9:15:00 PM	0.28
7/17/2014	9:30:00 PM	0.28
7/17/2014	9:45:00 PM	0.28
7/17/2014	10:00:00 PM	0.28
7/17/2014	10:15:00 PM	0.28
7/17/2014	10:30:00 PM	0.28
7/17/2014	10:45:00 PM	0.28
7/17/2014	11:00:00 PM	0.28
7/17/2014	11:15:00 PM	0.28
7/17/2014	11:30:00 PM	0.28
7/17/2014	11:45:00 PM	0.28
7/18/2014	12:00:00 AM	0.29
7/18/2014	12:15:00 AM	0.29
7/18/2014	12:30:00 AM	0.29
7/18/2014	12:45:00 AM	0.29
7/18/2014	1:00:00 AM	0.29
7/18/2014	1:15:00 AM	0.29
7/18/2014	1:30:00 AM	0.29
7/18/2014	1:45:00 AM	0.29
7/18/2014	2:00:00 AM	0.29
7/18/2014	2:15:00 AM	0.29
7/18/2014	2:30:00 AM	0.29
7/18/2014	2:45:00 AM	0.29
7/18/2014	3:00:00 AM	0.29
7/18/2014	3:15:00 AM	0.29
7/18/2014	3:30:00 AM	0.29
7/18/2014	3:45:00 AM	0.29
7/18/2014	4:00:00 AM	0.29
7/18/2014	4:15:00 AM	0.29
7/18/2014	4:30:00 AM	0.29
7/18/2014	4:45:00 AM	0.29
7/18/2014	5:00:00 AM	0.29
7/18/2014	5:15:00 AM	0.29
7/18/2014	5:30:00 AM	0.29
7/18/2014	5:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/18/2014	6:00:00 AM	0.29
7/18/2014	6:15:00 AM	0.29
7/18/2014	6:30:00 AM	0.29
7/18/2014	6:45:00 AM	0.29
7/18/2014	7:00:00 AM	0.29
7/18/2014	7:15:00 AM	0.29
7/18/2014	7:30:00 AM	0.29
7/18/2014	7:45:00 AM	0.29
7/18/2014	8:00:00 AM	0.29
7/18/2014	8:15:00 AM	0.29
7/18/2014	8:30:00 AM	0.29
7/18/2014	8:45:00 AM	0.29
7/18/2014	9:00:00 AM	0.29
7/18/2014	9:15:00 AM	0.29
7/18/2014	9:30:00 AM	0.29
7/18/2014	9:45:00 AM	0.29
7/18/2014	10:00:00 AM	0.29
7/18/2014	10:15:00 AM	0.29
7/18/2014	10:30:00 AM	0.29
7/18/2014	10:45:00 AM	0.29
7/18/2014	11:00:00 AM	0.29
7/18/2014	11:15:00 AM	0.29
7/18/2014	11:30:00 AM	0.29
7/18/2014	11:45:00 AM	0.29
7/18/2014	12:00:00 PM	0.29
7/18/2014	12:15:00 PM	0.29
7/18/2014	12:30:00 PM	0.29
7/18/2014	12:45:00 PM	0.29
7/18/2014	1:00:00 PM	0.29
7/18/2014	1:15:00 PM	0.29
7/18/2014	1:30:00 PM	0.29
7/18/2014	1:45:00 PM	0.29
7/18/2014	2:00:00 PM	0.29
7/18/2014	2:15:00 PM	0.29
7/18/2014	2:30:00 PM	0.29
7/18/2014	2:45:00 PM	0.29
7/18/2014	3:00:00 PM	0.29
7/18/2014	3:15:00 PM	0.29
7/18/2014	3:30:00 PM	0.29
7/18/2014	3:45:00 PM	0.29
7/18/2014	4:00:00 PM	0.29
7/18/2014	4:15:00 PM	0.29
7/18/2014	4:30:00 PM	0.29
7/18/2014	4:45:00 PM	0.29
7/18/2014	5:00:00 PM	0.29
7/18/2014	5:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/18/2014	5:30:00 PM	0.29
7/18/2014	5:45:00 PM	0.29
7/18/2014	6:00:00 PM	0.29
7/18/2014	6:15:00 PM	0.29
7/18/2014	6:30:00 PM	0.29
7/18/2014	6:45:00 PM	0.28
7/18/2014	7:00:00 PM	0.28
7/18/2014	7:15:00 PM	0.28
7/18/2014	7:30:00 PM	0.28
7/18/2014	7:45:00 PM	0.28
7/18/2014	8:00:00 PM	0.28
7/18/2014	8:15:00 PM	0.28
7/18/2014	8:30:00 PM	0.28
7/18/2014	8:45:00 PM	0.28
7/18/2014	9:00:00 PM	0.28
7/18/2014	9:15:00 PM	0.28
7/18/2014	9:30:00 PM	0.28
7/18/2014	9:45:00 PM	0.28
7/18/2014	10:00:00 PM	0.29
7/18/2014	10:15:00 PM	0.29
7/18/2014	10:30:00 PM	0.29
7/18/2014	10:45:00 PM	0.29
7/18/2014	11:00:00 PM	0.29
7/18/2014	11:15:00 PM	0.29
7/18/2014	11:30:00 PM	0.29
7/18/2014	11:45:00 PM	0.29
7/19/2014	12:00:00 AM	0.29
7/19/2014	12:15:00 AM	0.29
7/19/2014	12:30:00 AM	0.29
7/19/2014	12:45:00 AM	0.29
7/19/2014	1:00:00 AM	0.29
7/19/2014	1:15:00 AM	0.29
7/19/2014	1:30:00 AM	0.29
7/19/2014	1:45:00 AM	0.29
7/19/2014	2:00:00 AM	0.29
7/19/2014	2:15:00 AM	0.29
7/19/2014	2:30:00 AM	0.29
7/19/2014	2:45:00 AM	0.29
7/19/2014	3:00:00 AM	0.29
7/19/2014	3:15:00 AM	0.29
7/19/2014	3:30:00 AM	0.29
7/19/2014	3:45:00 AM	0.29
7/19/2014	4:00:00 AM	0.29
7/19/2014	4:15:00 AM	0.29
7/19/2014	4:30:00 AM	0.29
7/19/2014	4:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/19/2014	5:00:00 AM	0.29
7/19/2014	5:15:00 AM	0.29
7/19/2014	5:30:00 AM	0.29
7/19/2014	5:45:00 AM	0.29
7/19/2014	6:00:00 AM	0.29
7/19/2014	6:15:00 AM	0.29
7/19/2014	6:30:00 AM	0.29
7/19/2014	6:45:00 AM	0.29
7/19/2014	7:00:00 AM	0.29
7/19/2014	7:15:00 AM	0.29
7/19/2014	7:30:00 AM	0.29
7/19/2014	7:45:00 AM	0.29
7/19/2014	8:00:00 AM	0.29
7/19/2014	8:15:00 AM	0.29
7/19/2014	8:30:00 AM	0.29
7/19/2014	8:45:00 AM	0.29
7/19/2014	9:00:00 AM	0.29
7/19/2014	9:15:00 AM	0.29
7/19/2014	9:30:00 AM	0.29
7/19/2014	9:45:00 AM	0.29
7/19/2014	10:00:00 AM	0.29
7/19/2014	10:15:00 AM	0.29
7/19/2014	10:30:00 AM	0.29
7/19/2014	10:45:00 AM	0.29
7/19/2014	11:00:00 AM	0.29
7/19/2014	11:15:00 AM	0.29
7/19/2014	11:30:00 AM	0.29
7/19/2014	11:45:00 AM	0.29
7/19/2014	12:00:00 PM	0.29
7/19/2014	12:15:00 PM	0.29
7/19/2014	12:30:00 PM	0.29
7/19/2014	12:45:00 PM	0.29
7/19/2014	1:00:00 PM	0.29
7/19/2014	1:15:00 PM	0.29
7/19/2014	1:30:00 PM	0.29
7/19/2014	1:45:00 PM	0.29
7/19/2014	2:00:00 PM	0.29
7/19/2014	2:15:00 PM	0.29
7/19/2014	2:30:00 PM	0.29
7/19/2014	2:45:00 PM	0.29
7/19/2014	3:00:00 PM	0.29
7/19/2014	3:15:00 PM	0.28
7/19/2014	3:30:00 PM	0.28
7/19/2014	3:45:00 PM	0.28
7/19/2014	4:00:00 PM	0.28
7/19/2014	4:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/19/2014	4:30:00 PM	0.28
7/19/2014	4:45:00 PM	0.28
7/19/2014	5:00:00 PM	0.28
7/19/2014	5:15:00 PM	0.28
7/19/2014	5:30:00 PM	0.28
7/19/2014	5:45:00 PM	0.28
7/19/2014	6:00:00 PM	0.28
7/19/2014	6:15:00 PM	0.28
7/19/2014	6:30:00 PM	0.28
7/19/2014	6:45:00 PM	0.28
7/19/2014	7:00:00 PM	0.28
7/19/2014	7:15:00 PM	0.28
7/19/2014	7:30:00 PM	0.28
7/19/2014	7:45:00 PM	0.28
7/19/2014	8:00:00 PM	0.28
7/19/2014	8:15:00 PM	0.28
7/19/2014	8:30:00 PM	0.28
7/19/2014	8:45:00 PM	0.28
7/19/2014	9:00:00 PM	0.28
7/19/2014	9:15:00 PM	0.28
7/19/2014	9:30:00 PM	0.28
7/19/2014	9:45:00 PM	0.28
7/19/2014	10:00:00 PM	0.28
7/19/2014	10:15:00 PM	0.28
7/19/2014	10:30:00 PM	0.28
7/19/2014	10:45:00 PM	0.28
7/19/2014	11:00:00 PM	0.28
7/19/2014	11:15:00 PM	0.28
7/19/2014	11:30:00 PM	0.28
7/19/2014	11:45:00 PM	0.28
7/20/2014	12:00:00 AM	0.29
7/20/2014	12:15:00 AM	0.29
7/20/2014	12:30:00 AM	0.29
7/20/2014	12:45:00 AM	0.29
7/20/2014	1:00:00 AM	0.28
7/20/2014	1:15:00 AM	0.28
7/20/2014	1:30:00 AM	0.28
7/20/2014	1:45:00 AM	0.28
7/20/2014	2:00:00 AM	0.28
7/20/2014	2:15:00 AM	0.29
7/20/2014	2:30:00 AM	0.29
7/20/2014	2:45:00 AM	0.29
7/20/2014	3:00:00 AM	0.29
7/20/2014	3:15:00 AM	0.29
7/20/2014	3:30:00 AM	0.29
7/20/2014	3:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/20/2014	4:00:00 AM	0.29
7/20/2014	4:15:00 AM	0.29
7/20/2014	4:30:00 AM	0.29
7/20/2014	4:45:00 AM	0.29
7/20/2014	5:00:00 AM	0.29
7/20/2014	5:15:00 AM	0.29
7/20/2014	5:30:00 AM	0.29
7/20/2014	5:45:00 AM	0.29
7/20/2014	6:00:00 AM	0.29
7/20/2014	6:15:00 AM	0.29
7/20/2014	6:30:00 AM	0.29
7/20/2014	6:45:00 AM	0.29
7/20/2014	7:00:00 AM	0.29
7/20/2014	7:15:00 AM	0.29
7/20/2014	7:30:00 AM	0.29
7/20/2014	7:45:00 AM	0.29
7/20/2014	8:00:00 AM	0.29
7/20/2014	8:15:00 AM	0.29
7/20/2014	8:30:00 AM	0.29
7/20/2014	8:45:00 AM	0.29
7/20/2014	9:00:00 AM	0.29
7/20/2014	9:15:00 AM	0.29
7/20/2014	9:30:00 AM	0.29
7/20/2014	9:45:00 AM	0.29
7/20/2014	10:00:00 AM	0.29
7/20/2014	10:15:00 AM	0.29
7/20/2014	10:30:00 AM	0.29
7/20/2014	10:45:00 AM	0.29
7/20/2014	11:00:00 AM	0.29
7/20/2014	11:15:00 AM	0.29
7/20/2014	11:30:00 AM	0.29
7/20/2014	11:45:00 AM	0.29
7/20/2014	12:00:00 PM	0.29
7/20/2014	12:15:00 PM	0.29
7/20/2014	12:30:00 PM	0.29
7/20/2014	12:45:00 PM	0.29
7/20/2014	1:00:00 PM	0.29
7/20/2014	1:15:00 PM	0.29
7/20/2014	1:30:00 PM	0.29
7/20/2014	1:45:00 PM	0.29
7/20/2014	2:00:00 PM	0.29
7/20/2014	2:15:00 PM	0.29
7/20/2014	2:30:00 PM	0.29
7/20/2014	2:45:00 PM	0.29
7/20/2014	3:00:00 PM	0.29
7/20/2014	3:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/20/2014	3:30:00 PM	0.29
7/20/2014	3:45:00 PM	0.29
7/20/2014	4:00:00 PM	0.29
7/20/2014	4:15:00 PM	0.29
7/20/2014	4:30:00 PM	0.29
7/20/2014	4:45:00 PM	0.29
7/20/2014	5:00:00 PM	0.29
7/20/2014	5:15:00 PM	0.29
7/20/2014	5:30:00 PM	0.29
7/20/2014	5:45:00 PM	0.29
7/20/2014	6:00:00 PM	0.29
7/20/2014	6:15:00 PM	0.29
7/20/2014	6:30:00 PM	0.29
7/20/2014	6:45:00 PM	0.29
7/20/2014	7:00:00 PM	0.29
7/20/2014	7:15:00 PM	0.29
7/20/2014	7:30:00 PM	0.29
7/20/2014	7:45:00 PM	0.29
7/20/2014	8:00:00 PM	0.29
7/20/2014	8:15:00 PM	0.29
7/20/2014	8:30:00 PM	0.29
7/20/2014	8:45:00 PM	0.29
7/20/2014	9:00:00 PM	0.29
7/20/2014	9:15:00 PM	0.29
7/20/2014	9:30:00 PM	0.29
7/20/2014	9:45:00 PM	0.28
7/20/2014	10:00:00 PM	0.28
7/20/2014	10:15:00 PM	0.28
7/20/2014	10:30:00 PM	0.28
7/20/2014	10:45:00 PM	0.28
7/20/2014	11:00:00 PM	0.28
7/20/2014	11:15:00 PM	0.28
7/20/2014	11:30:00 PM	0.28
7/20/2014	11:45:00 PM	0.28
7/21/2014	12:00:00 AM	0.28
7/21/2014	12:15:00 AM	0.28
7/21/2014	12:30:00 AM	0.28
7/21/2014	12:45:00 AM	0.28
7/21/2014	1:00:00 AM	0.28
7/21/2014	1:15:00 AM	0.28
7/21/2014	1:30:00 AM	0.28
7/21/2014	1:45:00 AM	0.28
7/21/2014	2:00:00 AM	0.28
7/21/2014	2:15:00 AM	0.28
7/21/2014	2:30:00 AM	0.28
7/21/2014	2:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/21/2014	3:00:00 AM	0.28
7/21/2014	3:15:00 AM	0.28
7/21/2014	3:30:00 AM	0.28
7/21/2014	3:45:00 AM	0.28
7/21/2014	4:00:00 AM	0.28
7/21/2014	4:15:00 AM	0.28
7/21/2014	4:30:00 AM	0.28
7/21/2014	4:45:00 AM	0.28
7/21/2014	5:00:00 AM	0.28
7/21/2014	5:15:00 AM	0.28
7/21/2014	5:30:00 AM	0.28
7/21/2014	5:45:00 AM	0.28
7/21/2014	6:00:00 AM	0.28
7/21/2014	6:15:00 AM	0.28
7/21/2014	6:30:00 AM	0.28
7/21/2014	6:45:00 AM	0.28
7/21/2014	7:00:00 AM	0.28
7/21/2014	7:15:00 AM	0.28
7/21/2014	7:30:00 AM	0.28
7/21/2014	7:45:00 AM	0.28
7/21/2014	8:00:00 AM	0.28
7/21/2014	8:15:00 AM	0.28
7/21/2014	8:30:00 AM	0.28
7/21/2014	8:45:00 AM	0.28
7/21/2014	9:00:00 AM	0.28
7/21/2014	9:15:00 AM	0.28
7/21/2014	9:30:00 AM	0.28
7/21/2014	9:45:00 AM	0.28
7/21/2014	10:00:00 AM	0.28
7/21/2014	10:15:00 AM	0.28
7/21/2014	10:30:00 AM	0.28
7/21/2014	10:45:00 AM	0.28
7/21/2014	11:00:00 AM	0.28
7/21/2014	11:15:00 AM	0.28
7/21/2014	11:30:00 AM	0.28
7/21/2014	11:45:00 AM	0.28
7/21/2014	12:00:00 PM	0.28
7/21/2014	12:15:00 PM	0.28
7/21/2014	12:30:00 PM	0.28
7/21/2014	12:45:00 PM	0.28
7/21/2014	1:00:00 PM	0.28
7/21/2014	1:15:00 PM	0.28
7/21/2014	1:30:00 PM	0.28
7/21/2014	1:45:00 PM	0.28
7/21/2014	2:00:00 PM	0.28
7/21/2014	2:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/21/2014	2:30:00 PM	0.28
7/21/2014	2:45:00 PM	0.28
7/21/2014	3:00:00 PM	0.28
7/21/2014	3:15:00 PM	0.28
7/21/2014	3:30:00 PM	0.28
7/21/2014	3:45:00 PM	0.28
7/21/2014	4:00:00 PM	0.28
7/21/2014	4:15:00 PM	0.28
7/21/2014	4:30:00 PM	0.28
7/21/2014	4:45:00 PM	0.28
7/21/2014	5:00:00 PM	0.28
7/21/2014	5:15:00 PM	0.28
7/21/2014	5:30:00 PM	0.28
7/21/2014	5:45:00 PM	0.28
7/21/2014	6:00:00 PM	0.28
7/21/2014	6:15:00 PM	0.28
7/21/2014	6:30:00 PM	0.28
7/21/2014	6:45:00 PM	0.28
7/21/2014	7:00:00 PM	0.28
7/21/2014	7:15:00 PM	0.28
7/21/2014	7:30:00 PM	0.28
7/21/2014	7:45:00 PM	0.28
7/21/2014	8:00:00 PM	0.28
7/21/2014	8:15:00 PM	0.28
7/21/2014	8:30:00 PM	0.28
7/21/2014	8:45:00 PM	0.28
7/21/2014	9:00:00 PM	0.28
7/21/2014	9:15:00 PM	0.28
7/21/2014	9:30:00 PM	0.28
7/21/2014	9:45:00 PM	0.28
7/21/2014	10:00:00 PM	0.28
7/21/2014	10:15:00 PM	0.28
7/21/2014	10:30:00 PM	0.28
7/21/2014	10:45:00 PM	0.28
7/21/2014	11:00:00 PM	0.28
7/21/2014	11:15:00 PM	0.28
7/21/2014	11:30:00 PM	0.28
7/21/2014	11:45:00 PM	0.28
7/22/2014	12:00:00 AM	0.28
7/22/2014	12:15:00 AM	0.28
7/22/2014	12:30:00 AM	0.28
7/22/2014	12:45:00 AM	0.28
7/22/2014	1:00:00 AM	0.28
7/22/2014	1:15:00 AM	0.28
7/22/2014	1:30:00 AM	0.28
7/22/2014	1:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/22/2014	2:00:00 AM	0.28
7/22/2014	2:15:00 AM	0.28
7/22/2014	2:30:00 AM	0.28
7/22/2014	2:45:00 AM	0.28
7/22/2014	3:00:00 AM	0.28
7/22/2014	3:15:00 AM	0.28
7/22/2014	3:30:00 AM	0.28
7/22/2014	3:45:00 AM	0.28
7/22/2014	4:00:00 AM	0.28
7/22/2014	4:15:00 AM	0.28
7/22/2014	4:30:00 AM	0.28
7/22/2014	4:45:00 AM	0.28
7/22/2014	5:00:00 AM	0.28
7/22/2014	5:15:00 AM	0.28
7/22/2014	5:30:00 AM	0.28
7/22/2014	5:45:00 AM	0.28
7/22/2014	6:00:00 AM	0.28
7/22/2014	6:15:00 AM	0.28
7/22/2014	6:30:00 AM	0.28
7/22/2014	6:45:00 AM	0.28
7/22/2014	7:00:00 AM	0.28
7/22/2014	7:15:00 AM	0.28
7/22/2014	7:30:00 AM	0.28
7/22/2014	7:45:00 AM	0.28
7/22/2014	8:00:00 AM	0.28
7/22/2014	8:15:00 AM	0.28
7/22/2014	8:30:00 AM	0.28
7/22/2014	8:45:00 AM	0.28
7/22/2014	9:00:00 AM	0.28
7/22/2014	9:15:00 AM	0.28
7/22/2014	9:30:00 AM	0.28
7/22/2014	9:45:00 AM	0.28
7/22/2014	10:00:00 AM	0.28
7/22/2014	10:15:00 AM	0.28
7/22/2014	10:30:00 AM	0.28
7/22/2014	10:45:00 AM	0.28
7/22/2014	11:00:00 AM	0.28
7/22/2014	11:15:00 AM	0.28
7/22/2014	11:30:00 AM	0.28
7/22/2014	11:45:00 AM	0.28
7/22/2014	12:00:00 PM	0.28
7/22/2014	12:15:00 PM	0.28
7/22/2014	12:30:00 PM	0.28
7/22/2014	12:45:00 PM	0.28
7/22/2014	1:00:00 PM	0.28
7/22/2014	1:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/22/2014	1:30:00 PM	0.28
7/22/2014	1:45:00 PM	0.28
7/22/2014	2:00:00 PM	0.28
7/22/2014	2:15:00 PM	0.28
7/22/2014	2:30:00 PM	0.28
7/22/2014	2:45:00 PM	0.28
7/22/2014	3:00:00 PM	0.28
7/22/2014	3:15:00 PM	0.28
7/22/2014	3:30:00 PM	0.28
7/22/2014	3:45:00 PM	0.28
7/22/2014	4:00:00 PM	0.28
7/22/2014	4:15:00 PM	0.28
7/22/2014	4:30:00 PM	0.27
7/22/2014	4:45:00 PM	0.27
7/22/2014	5:00:00 PM	0.27
7/22/2014	5:15:00 PM	0.27
7/22/2014	5:30:00 PM	0.27
7/22/2014	5:45:00 PM	0.27
7/22/2014	6:00:00 PM	0.27
7/22/2014	6:15:00 PM	0.27
7/22/2014	6:30:00 PM	0.27
7/22/2014	6:45:00 PM	0.27
7/22/2014	7:00:00 PM	0.27
7/22/2014	7:15:00 PM	0.27
7/22/2014	7:30:00 PM	0.27
7/22/2014	7:45:00 PM	0.27
7/22/2014	8:00:00 PM	0.27
7/22/2014	8:15:00 PM	0.27
7/22/2014	8:30:00 PM	0.27
7/22/2014	8:45:00 PM	0.27
7/22/2014	9:00:00 PM	0.27
7/22/2014	9:15:00 PM	0.27
7/22/2014	9:30:00 PM	0.27
7/22/2014	9:45:00 PM	0.27
7/22/2014	10:00:00 PM	0.27
7/22/2014	10:15:00 PM	0.27
7/22/2014	10:30:00 PM	0.27
7/22/2014	10:45:00 PM	0.27
7/22/2014	11:00:00 PM	0.27
7/22/2014	11:15:00 PM	0.27
7/22/2014	11:30:00 PM	0.27
7/22/2014	11:45:00 PM	0.27
7/23/2014	12:00:00 AM	0.27
7/23/2014	12:15:00 AM	0.27
7/23/2014	12:30:00 AM	0.27
7/23/2014	12:45:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/23/2014	1:00:00 AM	0.27
7/23/2014	1:15:00 AM	0.27
7/23/2014	1:30:00 AM	0.27
7/23/2014	1:45:00 AM	0.28
7/23/2014	2:00:00 AM	0.28
7/23/2014	2:15:00 AM	0.28
7/23/2014	2:30:00 AM	0.28
7/23/2014	2:45:00 AM	0.28
7/23/2014	3:00:00 AM	0.28
7/23/2014	3:15:00 AM	0.28
7/23/2014	3:30:00 AM	0.28
7/23/2014	3:45:00 AM	0.28
7/23/2014	4:00:00 AM	0.28
7/23/2014	4:15:00 AM	0.28
7/23/2014	4:30:00 AM	0.28
7/23/2014	4:45:00 AM	0.28
7/23/2014	5:00:00 AM	0.28
7/23/2014	5:15:00 AM	0.28
7/23/2014	5:30:00 AM	0.28
7/23/2014	5:45:00 AM	0.28
7/23/2014	6:00:00 AM	0.28
7/23/2014	6:15:00 AM	0.28
7/23/2014	6:30:00 AM	0.28
7/23/2014	6:45:00 AM	0.28
7/23/2014	7:00:00 AM	0.28
7/23/2014	7:15:00 AM	0.28
7/23/2014	7:30:00 AM	0.28
7/23/2014	7:45:00 AM	0.28
7/23/2014	8:00:00 AM	0.28
7/23/2014	8:15:00 AM	0.28
7/23/2014	8:30:00 AM	0.28
7/23/2014	8:45:00 AM	0.28
7/23/2014	9:00:00 AM	0.28
7/23/2014	9:15:00 AM	0.28
7/23/2014	9:30:00 AM	0.28
7/23/2014	9:45:00 AM	0.28
7/23/2014	10:00:00 AM	0.28
7/23/2014	10:15:00 AM	0.28
7/23/2014	10:30:00 AM	0.28
7/23/2014	10:45:00 AM	0.28
7/23/2014	11:00:00 AM	0.28
7/23/2014	11:15:00 AM	0.28
7/23/2014	11:30:00 AM	0.28
7/23/2014	11:45:00 AM	0.28
7/23/2014	12:00:00 PM	0.28
7/23/2014	12:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/23/2014	12:30:00 PM	0.28
7/23/2014	12:45:00 PM	0.28
7/23/2014	1:00:00 PM	0.28
7/23/2014	1:15:00 PM	0.28
7/23/2014	1:30:00 PM	0.28
7/23/2014	1:45:00 PM	0.28
7/23/2014	2:00:00 PM	0.28
7/23/2014	2:15:00 PM	0.28
7/23/2014	2:30:00 PM	0.28
7/23/2014	2:45:00 PM	0.28
7/23/2014	3:00:00 PM	0.28
7/23/2014	3:15:00 PM	0.28
7/23/2014	3:30:00 PM	0.27
7/23/2014	3:45:00 PM	0.27
7/23/2014	4:00:00 PM	0.27
7/23/2014	4:15:00 PM	0.27
7/23/2014	4:30:00 PM	0.27
7/23/2014	4:45:00 PM	0.27
7/23/2014	5:00:00 PM	0.27
7/23/2014	5:15:00 PM	0.27
7/23/2014	5:30:00 PM	0.27
7/23/2014	5:45:00 PM	0.27
7/23/2014	6:00:00 PM	0.27
7/23/2014	6:15:00 PM	0.27
7/23/2014	6:30:00 PM	0.27
7/23/2014	6:45:00 PM	0.27
7/23/2014	7:00:00 PM	0.27
7/23/2014	7:15:00 PM	0.27
7/23/2014	7:30:00 PM	0.27
7/23/2014	7:45:00 PM	0.27
7/23/2014	8:00:00 PM	0.27
7/23/2014	8:15:00 PM	0.27
7/23/2014	8:30:00 PM	0.27
7/23/2014	8:45:00 PM	0.27
7/23/2014	9:00:00 PM	0.27
7/23/2014	9:15:00 PM	0.27
7/23/2014	9:30:00 PM	0.27
7/23/2014	9:45:00 PM	0.27
7/23/2014	10:00:00 PM	0.27
7/23/2014	10:15:00 PM	0.27
7/23/2014	10:30:00 PM	0.27
7/23/2014	10:45:00 PM	0.27
7/23/2014	11:00:00 PM	0.27
7/23/2014	11:15:00 PM	0.27
7/23/2014	11:30:00 PM	0.27
7/23/2014	11:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2014	12:00:00 AM	0.27
7/24/2014	12:15:00 AM	0.27
7/24/2014	12:30:00 AM	0.27
7/24/2014	12:45:00 AM	0.27
7/24/2014	1:00:00 AM	0.27
7/24/2014	1:15:00 AM	0.27
7/24/2014	1:30:00 AM	0.27
7/24/2014	1:45:00 AM	0.27
7/24/2014	2:00:00 AM	0.27
7/24/2014	2:15:00 AM	0.27
7/24/2014	2:30:00 AM	0.27
7/24/2014	2:45:00 AM	0.27
7/24/2014	3:00:00 AM	0.27
7/24/2014	3:15:00 AM	0.27
7/24/2014	3:30:00 AM	0.27
7/24/2014	3:45:00 AM	0.27
7/24/2014	4:00:00 AM	0.27
7/24/2014	4:15:00 AM	0.27
7/24/2014	4:30:00 AM	0.27
7/24/2014	4:45:00 AM	0.27
7/24/2014	5:00:00 AM	0.27
7/24/2014	5:15:00 AM	0.27
7/24/2014	5:30:00 AM	0.27
7/24/2014	5:45:00 AM	0.27
7/24/2014	6:00:00 AM	0.27
7/24/2014	6:15:00 AM	0.27
7/24/2014	6:30:00 AM	0.27
7/24/2014	6:45:00 AM	0.27
7/24/2014	7:00:00 AM	0.27
7/24/2014	7:15:00 AM	0.27
7/24/2014	7:30:00 AM	0.27
7/24/2014	7:45:00 AM	0.28
7/24/2014	8:00:00 AM	0.28
7/24/2014	8:15:00 AM	0.28
7/24/2014	8:30:00 AM	0.28
7/24/2014	8:45:00 AM	0.28
7/24/2014	9:00:00 AM	0.28
7/24/2014	9:15:00 AM	0.28
7/24/2014	9:30:00 AM	0.28
7/24/2014	9:45:00 AM	0.28
7/24/2014	10:00:00 AM	0.28
7/24/2014	10:15:00 AM	0.28
7/24/2014	10:30:00 AM	0.28
7/24/2014	10:45:00 AM	0.28
7/24/2014	11:00:00 AM	0.28
7/24/2014	11:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2014	11:30:00 AM	0.28
7/24/2014	11:45:00 AM	0.28
7/24/2014	12:00:00 PM	0.28
7/24/2014	12:15:00 PM	0.28
7/24/2014	12:30:00 PM	0.28
7/24/2014	12:45:00 PM	0.28
7/24/2014	1:00:00 PM	0.28
7/24/2014	1:15:00 PM	0.28
7/24/2014	1:30:00 PM	0.28
7/24/2014	1:45:00 PM	0.28
7/24/2014	2:00:00 PM	0.28
7/24/2014	2:15:00 PM	0.28
7/24/2014	2:30:00 PM	0.28
7/24/2014	2:45:00 PM	0.28
7/24/2014	3:00:00 PM	0.28
7/24/2014	3:15:00 PM	0.28
7/24/2014	3:30:00 PM	0.28
7/24/2014	3:45:00 PM	0.28
7/24/2014	4:00:00 PM	0.28
7/24/2014	4:15:00 PM	0.28
7/24/2014	4:30:00 PM	0.28
7/24/2014	4:45:00 PM	0.27
7/24/2014	5:00:00 PM	0.27
7/24/2014	5:15:00 PM	0.27
7/24/2014	5:30:00 PM	0.27
7/24/2014	5:45:00 PM	0.27
7/24/2014	6:00:00 PM	0.27
7/24/2014	6:15:00 PM	0.27
7/24/2014	6:30:00 PM	0.27
7/24/2014	6:45:00 PM	0.27
7/24/2014	7:00:00 PM	0.27
7/24/2014	7:15:00 PM	0.27
7/24/2014	7:30:00 PM	0.27
7/24/2014	7:45:00 PM	0.27
7/24/2014	8:00:00 PM	0.27
7/24/2014	8:15:00 PM	0.27
7/24/2014	8:30:00 PM	0.27
7/24/2014	8:45:00 PM	0.27
7/24/2014	9:00:00 PM	0.27
7/24/2014	9:15:00 PM	0.27
7/24/2014	9:30:00 PM	0.27
7/24/2014	9:45:00 PM	0.27
7/24/2014	10:00:00 PM	0.27
7/24/2014	10:15:00 PM	0.27
7/24/2014	10:30:00 PM	0.28
7/24/2014	10:45:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2014	11:00:00 PM	0.28
7/24/2014	11:15:00 PM	0.28
7/24/2014	11:30:00 PM	0.28
7/24/2014	11:45:00 PM	0.28
7/25/2014	12:00:00 AM	0.28
7/25/2014	12:15:00 AM	0.28
7/25/2014	12:30:00 AM	0.28
7/25/2014	12:45:00 AM	0.28
7/25/2014	1:00:00 AM	0.28
7/25/2014	1:15:00 AM	0.28
7/25/2014	1:30:00 AM	0.28
7/25/2014	1:45:00 AM	0.28
7/25/2014	2:00:00 AM	0.28
7/25/2014	2:15:00 AM	0.28
7/25/2014	2:30:00 AM	0.28
7/25/2014	2:45:00 AM	0.28
7/25/2014	3:00:00 AM	0.28
7/25/2014	3:15:00 AM	0.28
7/25/2014	3:30:00 AM	0.28
7/25/2014	3:45:00 AM	0.28
7/25/2014	4:00:00 AM	0.28
7/25/2014	4:15:00 AM	0.28
7/25/2014	4:30:00 AM	0.28
7/25/2014	4:45:00 AM	0.28
7/25/2014	5:00:00 AM	0.28
7/25/2014	5:15:00 AM	0.28
7/25/2014	5:30:00 AM	0.28
7/25/2014	5:45:00 AM	0.28
7/25/2014	6:00:00 AM	0.28
7/25/2014	6:15:00 AM	0.28
7/25/2014	6:30:00 AM	0.28
7/25/2014	6:45:00 AM	0.28
7/25/2014	7:00:00 AM	0.28
7/25/2014	7:15:00 AM	0.28
7/25/2014	7:30:00 AM	0.28
7/25/2014	7:45:00 AM	0.28
7/25/2014	8:00:00 AM	0.28
7/25/2014	8:15:00 AM	0.28
7/25/2014	8:30:00 AM	0.28
7/25/2014	8:45:00 AM	0.28
7/25/2014	9:00:00 AM	0.28
7/25/2014	9:15:00 AM	0.28
7/25/2014	9:30:00 AM	0.28
7/25/2014	9:45:00 AM	0.28
7/25/2014	10:00:00 AM	0.28
7/25/2014	10:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/25/2014	10:30:00 AM	0.28
7/25/2014	10:45:00 AM	0.28
7/25/2014	11:00:00 AM	0.28
7/25/2014	11:15:00 AM	0.28
7/25/2014	11:30:00 AM	0.28
7/25/2014	11:45:00 AM	0.28
7/25/2014	12:00:00 PM	0.28
7/25/2014	12:15:00 PM	0.28
7/25/2014	12:30:00 PM	0.28
7/25/2014	12:45:00 PM	0.28
7/25/2014	1:00:00 PM	0.28
7/25/2014	1:15:00 PM	0.28
7/25/2014	1:30:00 PM	0.28
7/25/2014	1:45:00 PM	0.28
7/25/2014	2:00:00 PM	0.28
7/25/2014	2:15:00 PM	0.28
7/25/2014	2:30:00 PM	0.28
7/25/2014	2:45:00 PM	0.28
7/25/2014	3:00:00 PM	0.28
7/25/2014	3:15:00 PM	0.28
7/25/2014	3:30:00 PM	0.28
7/25/2014	3:45:00 PM	0.28
7/25/2014	4:00:00 PM	0.28
7/25/2014	4:15:00 PM	0.28
7/25/2014	4:30:00 PM	0.28
7/25/2014	4:45:00 PM	0.28
7/25/2014	5:00:00 PM	0.28
7/25/2014	5:15:00 PM	0.28
7/25/2014	5:30:00 PM	0.28
7/25/2014	5:45:00 PM	0.28
7/25/2014	6:00:00 PM	0.28
7/25/2014	6:15:00 PM	0.28
7/25/2014	6:30:00 PM	0.28
7/25/2014	6:45:00 PM	0.28
7/25/2014	7:00:00 PM	0.28
7/25/2014	7:15:00 PM	0.28
7/25/2014	7:30:00 PM	0.28
7/25/2014	7:45:00 PM	0.28
7/25/2014	8:00:00 PM	0.28
7/25/2014	8:15:00 PM	0.28
7/25/2014	8:30:00 PM	0.28
7/25/2014	8:45:00 PM	0.28
7/25/2014	9:00:00 PM	0.28
7/25/2014	9:15:00 PM	0.28
7/25/2014	9:30:00 PM	0.28
7/25/2014	9:45:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/25/2014	10:00:00 PM	0.28
7/25/2014	10:15:00 PM	0.28
7/25/2014	10:30:00 PM	0.28
7/25/2014	10:45:00 PM	0.28
7/25/2014	11:00:00 PM	0.28
7/25/2014	11:15:00 PM	0.28
7/25/2014	11:30:00 PM	0.28
7/25/2014	11:45:00 PM	0.28
7/26/2014	12:00:00 AM	0.28
7/26/2014	12:15:00 AM	0.28
7/26/2014	12:30:00 AM	0.28
7/26/2014	12:45:00 AM	0.28
7/26/2014	1:00:00 AM	0.28
7/26/2014	1:15:00 AM	0.28
7/26/2014	1:30:00 AM	0.28
7/26/2014	1:45:00 AM	0.28
7/26/2014	2:00:00 AM	0.28
7/26/2014	2:15:00 AM	0.28
7/26/2014	2:30:00 AM	0.28
7/26/2014	2:45:00 AM	0.28
7/26/2014	3:00:00 AM	0.28
7/26/2014	3:15:00 AM	0.28
7/26/2014	3:30:00 AM	0.28
7/26/2014	3:45:00 AM	0.28
7/26/2014	4:00:00 AM	0.28
7/26/2014	4:15:00 AM	0.28
7/26/2014	4:30:00 AM	0.28
7/26/2014	4:45:00 AM	0.28
7/26/2014	5:00:00 AM	0.28
7/26/2014	5:15:00 AM	0.28
7/26/2014	5:30:00 AM	0.28
7/26/2014	5:45:00 AM	0.28
7/26/2014	6:00:00 AM	0.28
7/26/2014	6:15:00 AM	0.28
7/26/2014	6:30:00 AM	0.28
7/26/2014	6:45:00 AM	0.28
7/26/2014	7:00:00 AM	0.28
7/26/2014	7:15:00 AM	0.28
7/26/2014	7:30:00 AM	0.28
7/26/2014	7:45:00 AM	0.28
7/26/2014	8:00:00 AM	0.28
7/26/2014	8:15:00 AM	0.28
7/26/2014	8:30:00 AM	0.28
7/26/2014	8:45:00 AM	0.28
7/26/2014	9:00:00 AM	0.28
7/26/2014	9:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/26/2014	9:30:00 AM	0.28
7/26/2014	9:45:00 AM	0.28
7/26/2014	10:00:00 AM	0.28
7/26/2014	10:15:00 AM	0.28
7/26/2014	10:30:00 AM	0.28
7/26/2014	10:45:00 AM	0.28
7/26/2014	11:00:00 AM	0.28
7/26/2014	11:15:00 AM	0.28
7/26/2014	11:30:00 AM	0.28
7/26/2014	11:45:00 AM	0.28
7/26/2014	12:00:00 PM	0.28
7/26/2014	12:15:00 PM	0.28
7/26/2014	12:30:00 PM	0.28
7/26/2014	12:45:00 PM	0.28
7/26/2014	1:00:00 PM	0.28
7/26/2014	1:15:00 PM	0.28
7/26/2014	1:30:00 PM	0.28
7/26/2014	1:45:00 PM	0.28
7/26/2014	2:00:00 PM	0.28
7/26/2014	2:15:00 PM	0.28
7/26/2014	2:30:00 PM	0.28
7/26/2014	2:45:00 PM	0.28
7/26/2014	3:00:00 PM	0.28
7/26/2014	3:15:00 PM	0.28
7/26/2014	3:30:00 PM	0.28
7/26/2014	3:45:00 PM	0.28
7/26/2014	4:00:00 PM	0.28
7/26/2014	4:15:00 PM	0.28
7/26/2014	4:30:00 PM	0.28
7/26/2014	4:45:00 PM	0.28
7/26/2014	5:00:00 PM	0.28
7/26/2014	5:15:00 PM	0.28
7/26/2014	5:30:00 PM	0.28
7/26/2014	5:45:00 PM	0.28
7/26/2014	6:00:00 PM	0.28
7/26/2014	6:15:00 PM	0.28
7/26/2014	6:30:00 PM	0.28
7/26/2014	6:45:00 PM	0.28
7/26/2014	7:00:00 PM	0.28
7/26/2014	7:15:00 PM	0.28
7/26/2014	7:30:00 PM	0.28
7/26/2014	7:45:00 PM	0.28
7/26/2014	8:00:00 PM	0.28
7/26/2014	8:15:00 PM	0.28
7/26/2014	8:30:00 PM	0.28
7/26/2014	8:45:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/26/2014	9:00:00 PM	0.28
7/26/2014	9:15:00 PM	0.28
7/26/2014	9:30:00 PM	0.28
7/26/2014	9:45:00 PM	0.28
7/26/2014	10:00:00 PM	0.28
7/26/2014	10:15:00 PM	0.28
7/26/2014	10:30:00 PM	0.28
7/26/2014	10:45:00 PM	0.28
7/26/2014	11:00:00 PM	0.28
7/26/2014	11:15:00 PM	0.28
7/26/2014	11:30:00 PM	0.28
7/26/2014	11:45:00 PM	0.28
7/27/2014	12:00:00 AM	0.28
7/27/2014	12:15:00 AM	0.28
7/27/2014	12:30:00 AM	0.28
7/27/2014	12:45:00 AM	0.28
7/27/2014	1:00:00 AM	0.28
7/27/2014	1:15:00 AM	0.28
7/27/2014	1:30:00 AM	0.28
7/27/2014	1:45:00 AM	0.28
7/27/2014	2:00:00 AM	0.28
7/27/2014	2:15:00 AM	0.28
7/27/2014	2:30:00 AM	0.28
7/27/2014	2:45:00 AM	0.28
7/27/2014	3:00:00 AM	0.28
7/27/2014	3:15:00 AM	0.28
7/27/2014	3:30:00 AM	0.28
7/27/2014	3:45:00 AM	0.28
7/27/2014	4:00:00 AM	0.28
7/27/2014	4:15:00 AM	0.28
7/27/2014	4:30:00 AM	0.28
7/27/2014	4:45:00 AM	0.28
7/27/2014	5:00:00 AM	0.28
7/27/2014	5:15:00 AM	0.28
7/27/2014	5:30:00 AM	0.28
7/27/2014	5:45:00 AM	0.28
7/27/2014	6:00:00 AM	0.28
7/27/2014	6:15:00 AM	0.28
7/27/2014	6:30:00 AM	0.28
7/27/2014	6:45:00 AM	0.28
7/27/2014	7:00:00 AM	0.28
7/27/2014	7:15:00 AM	0.28
7/27/2014	7:30:00 AM	0.28
7/27/2014	7:45:00 AM	0.28
7/27/2014	8:00:00 AM	0.28
7/27/2014	8:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/27/2014	8:30:00 AM	0.28
7/27/2014	8:45:00 AM	0.28
7/27/2014	9:00:00 AM	0.28
7/27/2014	9:15:00 AM	0.28
7/27/2014	9:30:00 AM	0.28
7/27/2014	9:45:00 AM	0.28
7/27/2014	10:00:00 AM	0.28
7/27/2014	10:15:00 AM	0.28
7/27/2014	10:30:00 AM	0.28
7/27/2014	10:45:00 AM	0.28
7/27/2014	11:00:00 AM	0.28
7/27/2014	11:15:00 AM	0.28
7/27/2014	11:30:00 AM	0.27
7/27/2014	11:45:00 AM	0.27
7/27/2014	12:00:00 PM	0.27
7/27/2014	12:15:00 PM	0.27
7/27/2014	12:30:00 PM	0.27
7/27/2014	12:45:00 PM	0.27
7/27/2014	1:00:00 PM	0.27
7/27/2014	1:15:00 PM	0.27
7/27/2014	1:30:00 PM	0.27
7/27/2014	1:45:00 PM	0.27
7/27/2014	2:00:00 PM	0.27
7/27/2014	2:15:00 PM	0.27
7/27/2014	2:30:00 PM	0.27
7/27/2014	2:45:00 PM	0.27
7/27/2014	3:00:00 PM	0.27
7/27/2014	3:15:00 PM	0.27
7/27/2014	3:30:00 PM	0.27
7/27/2014	3:45:00 PM	0.27
7/27/2014	4:00:00 PM	0.27
7/27/2014	4:15:00 PM	0.27
7/27/2014	4:30:00 PM	0.27
7/27/2014	4:45:00 PM	0.27
7/27/2014	5:00:00 PM	0.27
7/27/2014	5:15:00 PM	0.27
7/27/2014	5:30:00 PM	0.27
7/27/2014	5:45:00 PM	0.27
7/27/2014	6:00:00 PM	0.27
7/27/2014	6:15:00 PM	0.27
7/27/2014	6:30:00 PM	0.27
7/27/2014	6:45:00 PM	0.26
7/27/2014	7:00:00 PM	0.26
7/27/2014	7:15:00 PM	0.26
7/27/2014	7:30:00 PM	0.26
7/27/2014	7:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/27/2014	8:00:00 PM	0.26
7/27/2014	8:15:00 PM	0.26
7/27/2014	8:30:00 PM	0.26
7/27/2014	8:45:00 PM	0.26
7/27/2014	9:00:00 PM	0.26
7/27/2014	9:15:00 PM	0.26
7/27/2014	9:30:00 PM	0.26
7/27/2014	9:45:00 PM	0.26
7/27/2014	10:00:00 PM	0.26
7/27/2014	10:15:00 PM	0.26
7/27/2014	10:30:00 PM	0.26
7/27/2014	10:45:00 PM	0.26
7/27/2014	11:00:00 PM	0.26
7/27/2014	11:15:00 PM	0.26
7/27/2014	11:30:00 PM	0.26
7/27/2014	11:45:00 PM	0.26
7/28/2014	12:00:00 AM	0.26
7/28/2014	12:15:00 AM	0.26
7/28/2014	12:30:00 AM	0.26
7/28/2014	12:45:00 AM	0.26
7/28/2014	1:00:00 AM	0.26
7/28/2014	1:15:00 AM	0.26
7/28/2014	1:30:00 AM	0.26
7/28/2014	1:45:00 AM	0.26
7/28/2014	2:00:00 AM	0.26
7/28/2014	2:15:00 AM	0.26
7/28/2014	2:30:00 AM	0.26
7/28/2014	2:45:00 AM	0.26
7/28/2014	3:00:00 AM	0.26
7/28/2014	3:15:00 AM	0.26
7/28/2014	3:30:00 AM	0.26
7/28/2014	3:45:00 AM	0.26
7/28/2014	4:00:00 AM	0.26
7/28/2014	4:15:00 AM	0.26
7/28/2014	4:30:00 AM	0.26
7/28/2014	4:45:00 AM	0.26
7/28/2014	5:00:00 AM	0.26
7/28/2014	5:15:00 AM	0.26
7/28/2014	5:30:00 AM	0.26
7/28/2014	5:45:00 AM	0.26
7/28/2014	6:00:00 AM	0.26
7/28/2014	6:15:00 AM	0.26
7/28/2014	6:30:00 AM	0.26
7/28/2014	6:45:00 AM	0.26
7/28/2014	7:00:00 AM	0.27
7/28/2014	7:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/28/2014	7:30:00 AM	0.27
7/28/2014	7:45:00 AM	0.27
7/28/2014	8:00:00 AM	0.27
7/28/2014	8:15:00 AM	0.27
7/28/2014	8:30:00 AM	0.27
7/28/2014	8:45:00 AM	0.27
7/28/2014	9:00:00 AM	0.27
7/28/2014	9:15:00 AM	0.26
7/28/2014	9:30:00 AM	0.26
7/28/2014	9:45:00 AM	0.26
7/28/2014	10:00:00 AM	0.26
7/28/2014	10:15:00 AM	0.26
7/28/2014	10:30:00 AM	0.26
7/28/2014	10:45:00 AM	0.26
7/28/2014	11:00:00 AM	0.26
7/28/2014	11:15:00 AM	0.26
7/28/2014	11:30:00 AM	0.26
7/28/2014	11:45:00 AM	0.26
7/28/2014	12:00:00 PM	0.26
7/28/2014	12:15:00 PM	0.26
7/28/2014	12:30:00 PM	0.26
7/28/2014	12:45:00 PM	0.26
7/28/2014	1:00:00 PM	0.26
7/28/2014	1:15:00 PM	0.26
7/28/2014	1:30:00 PM	0.26
7/28/2014	1:45:00 PM	0.26
7/28/2014	2:00:00 PM	0.26
7/28/2014	2:15:00 PM	0.26
7/28/2014	2:30:00 PM	0.26
7/28/2014	2:45:00 PM	0.26
7/28/2014	3:00:00 PM	0.26
7/28/2014	3:15:00 PM	0.26
7/28/2014	3:30:00 PM	0.26
7/28/2014	3:45:00 PM	0.26
7/28/2014	4:00:00 PM	0.26
7/28/2014	4:15:00 PM	0.26
7/28/2014	4:30:00 PM	0.26
7/28/2014	4:45:00 PM	0.26
7/28/2014	5:00:00 PM	0.26
7/28/2014	5:15:00 PM	0.26
7/28/2014	5:30:00 PM	0.26
7/28/2014	5:45:00 PM	0.26
7/28/2014	6:00:00 PM	0.27
7/28/2014	6:15:00 PM	0.27
7/28/2014	6:30:00 PM	0.27
7/28/2014	6:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/28/2014	7:00:00 PM	0.27
7/28/2014	7:15:00 PM	0.27
7/28/2014	7:30:00 PM	0.27
7/28/2014	7:45:00 PM	0.27
7/28/2014	8:00:00 PM	0.27
7/28/2014	8:15:00 PM	0.27
7/28/2014	8:30:00 PM	0.27
7/28/2014	8:45:00 PM	0.27
7/28/2014	9:00:00 PM	0.27
7/28/2014	9:15:00 PM	0.27
7/28/2014	9:30:00 PM	0.27
7/28/2014	9:45:00 PM	0.27
7/28/2014	10:00:00 PM	0.27
7/28/2014	10:15:00 PM	0.27
7/28/2014	10:30:00 PM	0.27
7/28/2014	10:45:00 PM	0.27
7/28/2014	11:00:00 PM	0.27
7/28/2014	11:15:00 PM	0.27
7/28/2014	11:30:00 PM	0.27
7/28/2014	11:45:00 PM	0.27
7/29/2014	12:00:00 AM	0.27
7/29/2014	12:15:00 AM	0.27
7/29/2014	12:30:00 AM	0.27
7/29/2014	12:45:00 AM	0.27
7/29/2014	1:00:00 AM	0.27
7/29/2014	1:15:00 AM	0.27
7/29/2014	1:30:00 AM	0.27
7/29/2014	1:45:00 AM	0.27
7/29/2014	2:00:00 AM	0.27
7/29/2014	2:15:00 AM	0.27
7/29/2014	2:30:00 AM	0.27
7/29/2014	2:45:00 AM	0.27
7/29/2014	3:00:00 AM	0.27
7/29/2014	3:15:00 AM	0.27
7/29/2014	3:30:00 AM	0.27
7/29/2014	3:45:00 AM	0.27
7/29/2014	4:00:00 AM	0.27
7/29/2014	4:15:00 AM	0.27
7/29/2014	4:30:00 AM	0.27
7/29/2014	4:45:00 AM	0.27
7/29/2014	5:00:00 AM	0.27
7/29/2014	5:15:00 AM	0.27
7/29/2014	5:30:00 AM	0.27
7/29/2014	5:45:00 AM	0.27
7/29/2014	6:00:00 AM	0.27
7/29/2014	6:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/29/2014	6:30:00 AM	0.27
7/29/2014	6:45:00 AM	0.27
7/29/2014	7:00:00 AM	0.27
7/29/2014	7:15:00 AM	0.27
7/29/2014	7:30:00 AM	0.27
7/29/2014	7:45:00 AM	0.27
7/29/2014	8:00:00 AM	0.27
7/29/2014	8:15:00 AM	0.27
7/29/2014	8:30:00 AM	0.27
7/29/2014	8:45:00 AM	0.27
7/29/2014	9:00:00 AM	0.27
7/29/2014	9:15:00 AM	0.27
7/29/2014	9:30:00 AM	0.27
7/29/2014	9:45:00 AM	0.27
7/29/2014	10:00:00 AM	0.27
7/29/2014	10:15:00 AM	0.27
7/29/2014	10:30:00 AM	0.27
7/29/2014	10:45:00 AM	0.27
7/29/2014	11:00:00 AM	0.27
7/29/2014	11:15:00 AM	0.27
7/29/2014	11:30:00 AM	0.27
7/29/2014	11:45:00 AM	0.27
7/29/2014	12:00:00 PM	0.27
7/29/2014	12:15:00 PM	0.27
7/29/2014	12:30:00 PM	0.27
7/29/2014	12:45:00 PM	0.27
7/29/2014	1:00:00 PM	0.27
7/29/2014	1:15:00 PM	0.27
7/29/2014	1:30:00 PM	0.27
7/29/2014	1:45:00 PM	0.27
7/29/2014	2:00:00 PM	0.27
7/29/2014	2:15:00 PM	0.27
7/29/2014	2:30:00 PM	0.27
7/29/2014	2:45:00 PM	0.27
7/29/2014	3:00:00 PM	0.27
7/29/2014	3:15:00 PM	0.27
7/29/2014	3:30:00 PM	0.27
7/29/2014	3:45:00 PM	0.27
7/29/2014	4:00:00 PM	0.27
7/29/2014	4:15:00 PM	0.27
7/29/2014	4:30:00 PM	0.27
7/29/2014	4:45:00 PM	0.27
7/29/2014	5:00:00 PM	0.27
7/29/2014	5:15:00 PM	0.27
7/29/2014	5:30:00 PM	0.27
7/29/2014	5:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/29/2014	6:00:00 PM	0.27
7/29/2014	6:15:00 PM	0.27
7/29/2014	6:30:00 PM	0.27
7/29/2014	6:45:00 PM	0.27
7/29/2014	7:00:00 PM	0.27
7/29/2014	7:15:00 PM	0.27
7/29/2014	7:30:00 PM	0.27
7/29/2014	7:45:00 PM	0.27
7/29/2014	8:00:00 PM	0.27
7/29/2014	8:15:00 PM	0.27
7/29/2014	8:30:00 PM	0.27
7/29/2014	8:45:00 PM	0.27
7/29/2014	9:00:00 PM	0.27
7/29/2014	9:15:00 PM	0.27
7/29/2014	9:30:00 PM	0.27
7/29/2014	9:45:00 PM	0.27
7/29/2014	10:00:00 PM	0.27
7/29/2014	10:15:00 PM	0.27
7/29/2014	10:30:00 PM	0.27
7/29/2014	10:45:00 PM	0.27
7/29/2014	11:00:00 PM	0.27
7/29/2014	11:15:00 PM	0.27
7/29/2014	11:30:00 PM	0.27
7/29/2014	11:45:00 PM	0.27
7/30/2014	12:00:00 AM	0.27
7/30/2014	12:15:00 AM	0.27
7/30/2014	12:30:00 AM	0.27
7/30/2014	12:45:00 AM	0.27
7/30/2014	1:00:00 AM	0.27
7/30/2014	1:15:00 AM	0.27
7/30/2014	1:30:00 AM	0.27
7/30/2014	1:45:00 AM	0.27
7/30/2014	2:00:00 AM	0.27
7/30/2014	2:15:00 AM	0.27
7/30/2014	2:30:00 AM	0.27
7/30/2014	2:45:00 AM	0.27
7/30/2014	3:00:00 AM	0.27
7/30/2014	3:15:00 AM	0.27
7/30/2014	3:30:00 AM	0.27
7/30/2014	3:45:00 AM	0.27
7/30/2014	4:00:00 AM	0.27
7/30/2014	4:15:00 AM	0.27
7/30/2014	4:30:00 AM	0.27
7/30/2014	4:45:00 AM	0.27
7/30/2014	5:00:00 AM	0.27
7/30/2014	5:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/30/2014	5:30:00 AM	0.27
7/30/2014	5:45:00 AM	0.27
7/30/2014	6:00:00 AM	0.27
7/30/2014	6:15:00 AM	0.27
7/30/2014	6:30:00 AM	0.27
7/30/2014	6:45:00 AM	0.27
7/30/2014	7:00:00 AM	0.27
7/30/2014	7:15:00 AM	0.27
7/30/2014	7:30:00 AM	0.27
7/30/2014	7:45:00 AM	0.27
7/30/2014	8:00:00 AM	0.27
7/30/2014	8:15:00 AM	0.27
7/30/2014	8:30:00 AM	0.27
7/30/2014	8:45:00 AM	0.27
7/30/2014	9:00:00 AM	0.27
7/30/2014	9:15:00 AM	0.27
7/30/2014	9:30:00 AM	0.27
7/30/2014	9:45:00 AM	0.27
7/30/2014	10:00:00 AM	0.27
7/30/2014	10:15:00 AM	0.27
7/30/2014	10:30:00 AM	0.27
7/30/2014	10:45:00 AM	0.27
7/30/2014	11:00:00 AM	0.27
7/30/2014	11:15:00 AM	0.27
7/30/2014	11:30:00 AM	0.27
7/30/2014	11:45:00 AM	0.27
7/30/2014	12:00:00 PM	0.27
7/30/2014	12:15:00 PM	0.26
7/30/2014	12:30:00 PM	0.26
7/30/2014	12:45:00 PM	0.26
7/30/2014	1:00:00 PM	0.26
7/30/2014	1:15:00 PM	0.26
7/30/2014	1:30:00 PM	0.26
7/30/2014	1:45:00 PM	0.26
7/30/2014	2:00:00 PM	0.26
7/30/2014	2:15:00 PM	0.26
7/30/2014	2:30:00 PM	0.26
7/30/2014	2:45:00 PM	0.26
7/30/2014	3:00:00 PM	0.26
7/30/2014	3:15:00 PM	0.26
7/30/2014	3:30:00 PM	0.26
7/30/2014	3:45:00 PM	0.26
7/30/2014	4:00:00 PM	0.26
7/30/2014	4:15:00 PM	0.26
7/30/2014	4:30:00 PM	0.26
7/30/2014	4:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/30/2014	5:00:00 PM	0.26
7/30/2014	5:15:00 PM	0.26
7/30/2014	5:30:00 PM	0.26
7/30/2014	5:45:00 PM	0.26
7/30/2014	6:00:00 PM	0.26
7/30/2014	6:15:00 PM	0.26
7/30/2014	6:30:00 PM	0.26
7/30/2014	6:45:00 PM	0.26
7/30/2014	7:00:00 PM	0.26
7/30/2014	7:15:00 PM	0.26
7/30/2014	7:30:00 PM	0.26
7/30/2014	7:45:00 PM	0.26
7/30/2014	8:00:00 PM	0.26
7/30/2014	8:15:00 PM	0.26
7/30/2014	8:30:00 PM	0.26
7/30/2014	8:45:00 PM	0.26
7/30/2014	9:00:00 PM	0.26
7/30/2014	9:15:00 PM	0.26
7/30/2014	9:30:00 PM	0.26
7/30/2014	9:45:00 PM	0.26
7/30/2014	10:00:00 PM	0.26
7/30/2014	10:15:00 PM	0.26
7/30/2014	10:30:00 PM	0.26
7/30/2014	10:45:00 PM	0.26
7/30/2014	11:00:00 PM	0.26
7/30/2014	11:15:00 PM	0.26
7/30/2014	11:30:00 PM	0.26
7/30/2014	11:45:00 PM	0.26
7/31/2014	12:00:00 AM	0.26
7/31/2014	12:15:00 AM	0.26
7/31/2014	12:30:00 AM	0.26
7/31/2014	12:45:00 AM	0.26
7/31/2014	1:00:00 AM	0.26
7/31/2014	1:15:00 AM	0.26
7/31/2014	1:30:00 AM	0.26
7/31/2014	1:45:00 AM	0.26
7/31/2014	2:00:00 AM	0.26
7/31/2014	2:15:00 AM	0.26
7/31/2014	2:30:00 AM	0.26
7/31/2014	2:45:00 AM	0.26
7/31/2014	3:00:00 AM	0.26
7/31/2014	3:15:00 AM	0.26
7/31/2014	3:30:00 AM	0.26
7/31/2014	3:45:00 AM	0.26
7/31/2014	4:00:00 AM	0.26
7/31/2014	4:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/31/2014	4:30:00 AM	0.26
7/31/2014	4:45:00 AM	0.26
7/31/2014	5:00:00 AM	0.26
7/31/2014	5:15:00 AM	0.26
7/31/2014	5:30:00 AM	0.26
7/31/2014	5:45:00 AM	0.26
7/31/2014	6:00:00 AM	0.26
7/31/2014	6:15:00 AM	0.26
7/31/2014	6:30:00 AM	0.26
7/31/2014	6:45:00 AM	0.26
7/31/2014	7:00:00 AM	0.26
7/31/2014	7:15:00 AM	0.26
7/31/2014	7:30:00 AM	0.26
7/31/2014	7:45:00 AM	0.26
7/31/2014	8:00:00 AM	0.26
7/31/2014	8:15:00 AM	0.26
7/31/2014	8:30:00 AM	0.26
7/31/2014	8:45:00 AM	0.26
7/31/2014	9:00:00 AM	0.26
7/31/2014	9:15:00 AM	0.26
7/31/2014	9:30:00 AM	0.26
7/31/2014	9:45:00 AM	0.26
7/31/2014	10:00:00 AM	0.26
7/31/2014	10:15:00 AM	0.26
7/31/2014	10:30:00 AM	0.26
7/31/2014	10:45:00 AM	0.26
7/31/2014	11:00:00 AM	0.26
7/31/2014	11:15:00 AM	0.26
7/31/2014	11:30:00 AM	0.26
7/31/2014	11:45:00 AM	0.26
7/31/2014	12:00:00 PM	0.26
7/31/2014	12:15:00 PM	0.26
7/31/2014	12:30:00 PM	0.26
7/31/2014	12:45:00 PM	0.26
7/31/2014	1:00:00 PM	0.26
7/31/2014	1:15:00 PM	0.26
7/31/2014	1:30:00 PM	0.26
7/31/2014	1:45:00 PM	0.26
7/31/2014	2:00:00 PM	0.26
7/31/2014	2:15:00 PM	0.26
7/31/2014	2:30:00 PM	0.26
7/31/2014	2:45:00 PM	0.26
7/31/2014	3:00:00 PM	0.26
7/31/2014	3:15:00 PM	0.26
7/31/2014	3:30:00 PM	0.26
7/31/2014	3:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/31/2014	4:00:00 PM	0.26
7/31/2014	4:15:00 PM	0.26
7/31/2014	4:30:00 PM	0.26
7/31/2014	4:45:00 PM	0.26
7/31/2014	5:00:00 PM	0.26
7/31/2014	5:15:00 PM	0.26
7/31/2014	5:30:00 PM	0.26
7/31/2014	5:45:00 PM	0.26
7/31/2014	6:00:00 PM	0.26
7/31/2014	6:15:00 PM	0.26
7/31/2014	6:30:00 PM	0.26
7/31/2014	6:45:00 PM	0.26
7/31/2014	7:00:00 PM	0.26
7/31/2014	7:15:00 PM	0.26
7/31/2014	7:30:00 PM	0.26
7/31/2014	7:45:00 PM	0.26
7/31/2014	8:00:00 PM	0.26
7/31/2014	8:15:00 PM	0.26
7/31/2014	8:30:00 PM	0.26
7/31/2014	8:45:00 PM	0.26
7/31/2014	9:00:00 PM	0.26
7/31/2014	9:15:00 PM	0.26
7/31/2014	9:30:00 PM	0.26
7/31/2014	9:45:00 PM	0.26
7/31/2014	10:00:00 PM	0.26
7/31/2014	10:15:00 PM	0.26
7/31/2014	10:30:00 PM	0.26
7/31/2014	10:45:00 PM	0.26
7/31/2014	11:00:00 PM	0.26
7/31/2014	11:15:00 PM	0.26
7/31/2014	11:30:00 PM	0.26
7/31/2014	11:45:00 PM	0.26
8/1/2014	12:00:00 AM	0.26

Party: MKH/BJA	Width: 19.4 ft	Processed by: MKH/BJA
Boat/Motor:	Area: 88.4 ft ²	Mean Velocity: 0.781 ft/s
Gage Height: 4.97 ft	G.H.Change: 0.000 ft	Discharge: 68.9 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 1.54 ft/s	
Max. Depth: 8.55 ft	
Mean Depth: 4.54 ft	
% Meas.: 68.00	
Water Temp.: None	
ADCP Temp.: 70.9 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 140722 LOR @ MAZOURKA00
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	33	7.80	48.1	8.51	2.75	2.61	69.9	20	88	07:35	07:36	0.54	0.79	6	0
001	R	2	2	32	7.27	44.8	7.31	2.68	2.68	64.8	19	85	07:36	07:37	0.49	0.76	6	0
002	L	2	2	33	7.66	47.3	7.84	2.93	2.86	68.6	19	87	07:37	07:38	0.49	0.79	6	0
003	R	2	2	33	7.10	44.2	14.0	3.14	2.79	71.2	20	98	07:38	07:39	0.51	0.73	6	0
004	L	2	2	33	7.98	49.1	7.98	2.83	2.58	70.5	20	88	07:40	07:40	0.53	0.80	6	0
005	R	2	2	34	7.73	47.7	7.70	2.93	2.65	68.7	19	85	07:41	07:41	0.53	0.81	6	0
Mean		2	2	33	7.59	46.9	8.89	2.88	2.70	68.9	19	88	Total	00:05	0.52	0.78	6	0
SDev		0	0	1	0.337	1.94	2.53	0.162	0.109	2.28	0.2	4.7			0.02	0.03		
SD/M		0.00	0.00	0.02	0.04	0.04	0.28	0.06	0.04	0.03	0.01	0.05			0.04	0.04		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	0	8	42	0.843	-0.092	4.537	0.016	0.013	0	44.3	42.6	65.8	137	131	0	34	32
2014	7	1	0	18	42	0.833	-0.066	4.537	0.01	0.007	0	43.9	41.3	74	136	129	0	34	33
2014	7	1	0	28	42	0.85	-0.072	4.537	0.01	0.007	0	43	40.9	74	134	128	0	34	33
2014	7	1	0	38	42	0.863	-0.062	4.541	0.01	0.007	0	42.6	40.4	73.1	133	127	0	34	33
2014	7	1	0	48	42	0.863	-0.082	4.541	0.01	0.007	0	44.7	42.6	72.2	138	131	0	34	32
2014	7	1	0	58	42	0.863	-0.079	4.541	0.016	0.013	0	42.6	40.4	73.1	133	127	0	34	33
2014	7	1	1	8	42	0.84	-0.079	4.541	0.01	0.007	0	42.6	40.4	73.5	133	126	0	34	32
2014	7	1	1	18	42	0.804	-0.066	4.541	0.01	0.007	0	43	40.9	73.1	134	128	0	34	33
2014	7	1	1	28	42	0.856	-0.098	4.541	0.01	0.007	0	42.1	39.6	68.4	132	125	0	34	33
2014	7	1	1	38	42	0.846	-0.072	4.541	0.01	0.007	0	42.6	40.9	72.2	133	127	0	34	32
2014	7	1	1	48	42	0.81	-0.082	4.541	0.01	0.007	0	42.1	40	72.2	132	126	0	34	33
2014	7	1	1	58	42	0.85	-0.095	4.541	0.01	0.007	0	42.1	40	68.4	132	126	0	34	33
2014	7	1	2	8	42	0.866	-0.049	4.541	0.01	0.007	0	42.1	39.6	71.8	132	126	0	34	34
2014	7	1	2	18	42	0.863	-0.085	4.544	0.01	0.007	0	41.7	40	72.2	132	126	0	35	33
2014	7	1	2	28	42	0.85	-0.072	4.544	0.01	0.007	0	41.3	39.6	72.2	130	125	0	34	33
2014	7	1	2	38	42	0.833	-0.062	4.544	0.01	0.007	0	41.3	38.7	71.4	129	123	0	33	33
2014	7	1	2	48	42	0.823	-0.062	4.544	0.013	0.01	0	41.7	39.6	67.5	131	125	0	34	33
2014	7	1	2	58	42	0.833	-0.082	4.544	0.01	0.007	0	41.3	39.6	71.4	130	125	0	34	33
2014	7	1	3	8	42	0.817	-0.062	4.547	0.01	0.007	0	41.7	39.6	71	131	125	0	34	33
2014	7	1	3	18	42	0.843	-0.046	4.547	0.01	0.007	0	44.3	41.7	69.7	136	130	0	33	33
2014	7	1	3	28	42	0.866	-0.089	4.551	0.01	0.007	0	41.3	39.1	70.1	130	125	0	34	34
2014	7	1	3	38	42	0.837	-0.075	4.551	0.01	0.007	0	41.3	40	70.5	131	126	0	35	33
2014	7	1	3	48	42	0.837	-0.092	4.554	0.01	0.007	0	41.7	39.6	71	131	125	0	34	33
2014	7	1	3	58	42	0.863	-0.098	4.554	0.01	0.007	0	40.9	39.1	68.8	130	124	0	35	33
2014	7	1	4	8	42	0.846	-0.049	4.557	0.01	0.007	0	40.9	39.1	72.2	130	124	0	35	33
2014	7	1	4	18	42	0.843	-0.066	4.557	0.013	0.01	0	40.9	38.7	71.8	129	123	0	34	33
2014	7	1	4	28	42	0.827	-0.069	4.557	0.01	0.007	0	41.7	39.6	72.7	131	125	0	34	33
2014	7	1	4	38	42	0.843	-0.066	4.557	0.013	0.01	0	41.7	40	72.7	132	126	0	35	33
2014	7	1	4	48	42	0.85	-0.105	4.557	0.01	0.007	0	42.1	40	72.2	132	126	0	34	33
2014	7	1	4	58	42	0.843	-0.059	4.557	0.01	0.007	0	41.7	40	70.5	131	126	0	34	33
2014	7	1	5	8	42	0.814	-0.075	4.557	0.01	0.007	0	41.7	39.6	73.1	131	125	0	34	33
2014	7	1	5	18	42	0.843	-0.072	4.557	0.01	0.007	0	43.9	41.3	70.1	136	130	0	34	34
2014	7	1	5	28	42	0.843	-0.102	4.56	0.01	0.007	0	44.7	42.1	72.7	138	131	0	34	33
2014	7	1	5	38	42	0.84	-0.082	4.56	0.01	0.007	0	42.6	41.3	72.7	134	129	0	35	33
2014	7	1	5	48	42	0.86	-0.069	4.56	0.013	0.01	0	41.7	40	74.4	132	126	0	35	33
2014	7	1	5	58	42	0.853	-0.108	4.56	0.01	0.007	0	42.1	40	74	132	126	0	34	33
2014	7	1	6	8	42	0.837	-0.098	4.56	0.01	0.007	0	41.3	39.1	74.4	130	124	0	34	33
2014	7	1	6	18	42	0.84	-0.069	4.56	0.01	0.007	0	40.9	39.6	74.4	130	125	0	35	33
2014	7	1	6	28	42	0.823	-0.112	4.56	0.01	0.007	0	41.7	39.6	75.3	131	125	0	34	33
2014	7	1	6	38	42	0.81	-0.082	4.56	0.01	0.007	0	41.7	39.6	74.8	131	125	0	34	33
2014	7	1	6	48	42	0.86	-0.082	4.56	0.01	0.007	0	41.7	39.1	75.3	131	125	0	34	34
2014	7	1	6	58	42	0.837	-0.085	4.56	0.013	0.01	0	42.1	40	75.3	132	126	0	34	33
2014	7	1	7	8	42	0.83	-0.085	4.564	0.01	0.007	0	41.7	40	75.3	132	126	0	35	33
2014	7	1	7	18	42	0.84	-0.082	4.564	0.01	0.007	0	41.3	40	75.7	130	125	0	34	32
2014	7	1	7	28	42	0.837	-0.062	4.564	0.01	0.007	0	41.7	39.6	75.7	131	125	0	34	33
2014	7	1	7	38	42	0.856	-0.098	4.564	0.013	0.01	0	41.7	39.6	75.3	131	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	7	48	42	0.843	-0.066	4.564	0.01	0.007	0	41.3	39.1	76.1	130	124	0	34	33
2014	7	1	7	58	42	0.817	-0.079	4.564	0.01	0.007	0	42.1	40	75.7	132	126	0	34	33
2014	7	1	8	8	42	0.86	-0.052	4.564	0.013	0.01	0	41.7	40	75.7	131	126	0	34	33
2014	7	1	8	18	42	0.86	-0.082	4.564	0.01	0.007	0	41.3	39.6	76.1	131	125	0	35	33
2014	7	1	8	28	42	0.856	-0.112	4.564	0.01	0.007	0	41.7	39.6	75.7	131	125	0	34	33
2014	7	1	8	38	42	0.869	-0.092	4.564	0.01	0.007	0	41.3	39.6	76.5	130	125	0	34	33
2014	7	1	8	48	42	0.84	-0.102	4.564	0.013	0.01	0	41.3	39.6	75.7	130	125	0	34	33
2014	7	1	8	58	42	0.85	-0.082	4.564	0.01	0.007	0	40.9	39.1	76.1	129	124	0	34	33
2014	7	1	9	8	42	0.863	-0.108	4.564	0.013	0.01	0	40.9	39.1	76.1	129	124	0	34	33
2014	7	1	9	18	42	0.876	-0.128	4.564	0.01	0.007	0	40.9	39.1	75.7	129	124	0	34	33
2014	7	1	9	28	42	0.86	-0.121	4.564	0.01	0.007	0	40.4	38.7	75.7	129	123	0	35	33
2014	7	1	9	38	42	0.889	-0.135	4.564	0.01	0.007	0	40.9	39.1	76.1	129	124	0	34	33
2014	7	1	9	48	42	0.876	-0.112	4.564	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	1	9	58	42	0.83	-0.148	4.564	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33
2014	7	1	10	8	42	0.856	-0.164	4.564	0.01	0.007	0	40.9	38.7	75.7	129	123	0	34	33
2014	7	1	10	18	42	0.853	-0.108	4.564	0.01	0.007	0	40.9	39.6	75.3	130	125	0	35	33
2014	7	1	10	28	42	0.84	-0.121	4.564	0.01	0.007	0	40.4	39.1	75.3	129	124	0	35	33
2014	7	1	10	38	42	0.869	-0.118	4.564	0.013	0.01	0	40.4	38.7	76.1	129	123	0	35	33
2014	7	1	10	48	42	0.856	-0.138	4.564	0.01	0.007	0	40.4	39.1	75.7	129	124	0	35	33
2014	7	1	10	58	42	0.873	-0.115	4.564	0.013	0.01	0	40.4	39.6	76.1	129	124	0	35	32
2014	7	1	11	8	42	0.86	-0.148	4.564	0.013	0.01	0	40.4	38.7	74.8	129	123	0	35	33
2014	7	1	11	18	42	0.856	-0.135	4.564	0.01	0.007	0	40.4	39.1	71.4	129	124	0	35	33
2014	7	1	11	28	42	0.837	-0.157	4.564	0.01	0.007	0	40.9	38.7	66.7	129	123	0	34	33
2014	7	1	11	38	42	0.84	-0.151	4.564	0.013	0.01	0	40.9	38.7	74.4	129	123	0	34	33
2014	7	1	11	48	42	0.85	-0.164	4.564	0.01	0.007	0	41.3	39.1	74.4	130	124	0	34	33
2014	7	1	11	58	42	0.837	-0.148	4.564	0.016	0.013	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	1	12	8	42	0.843	-0.131	4.564	0.013	0.01	0	40.4	38.7	58.5	128	123	0	34	33
2014	7	1	12	18	42	0.837	-0.174	4.564	0.013	0.01	0	41.3	39.1	62.8	130	125	0	34	34
2014	7	1	12	28	42	0.833	-0.151	4.564	0.013	0.01	0	40.4	38.7	55.5	128	123	0	34	33
2014	7	1	12	38	42	0.85	-0.138	4.564	0.01	0.007	0	40.4	39.1	56.3	129	123	0	35	32
2014	7	1	12	48	42	0.85	-0.148	4.56	0.01	0.007	0	41.3	39.1	52	130	124	0	34	33
2014	7	1	12	58	42	0.866	-0.154	4.557	0.01	0.007	0	41.7	39.6	50.7	132	125	0	35	33
2014	7	1	13	8	42	0.873	-0.144	4.557	0.01	0.007	0	45.6	43.4	42.1	140	134	0	34	33
2014	7	1	13	18	42	0.797	-0.108	4.56	0.01	0.007	0	42.6	40.9	50.3	133	128	0	34	33
2014	7	1	13	28	42	0.85	-0.098	4.56	0.01	0.007	0	43	40.9	50.7	134	128	0	34	33
2014	7	1	13	38	42	0.85	-0.105	4.564	0.01	0.007	0	43.4	41.7	43.4	136	130	0	35	33
2014	7	1	13	48	42	0.85	-0.105	4.557	0.01	0.007	0	43.9	41.7	43.4	136	130	0	34	33
2014	7	1	13	58	42	0.856	-0.066	4.56	0.013	0.01	0	43	41.3	49.9	134	129	0	34	33
2014	7	1	14	8	42	0.846	-0.069	4.557	0.01	0.007	0	43.4	41.3	43.4	135	129	0	34	33
2014	7	1	14	18	42	0.82	-0.141	4.557	0.01	0.007	0	44.3	41.7	44.7	137	130	0	34	33
2014	7	1	14	28	42	0.863	-0.105	4.557	0.01	0.007	0	46.9	45.6	43.9	143	138	0	34	32
2014	7	1	14	38	42	0.846	-0.102	4.557	0.01	0.007	0	46.9	45.2	41.7	143	138	0	34	33
2014	7	1	14	48	42	0.869	-0.079	4.557	0.013	0.01	0	50.3	47.7	42.1	151	144	0	34	33
2014	7	1	14	58	42	0.797	-0.118	4.56	0.01	0.007	0	45.2	43	45.2	139	133	0	34	33
2014	7	1	15	8	42	0.83	-0.095	4.56	0.01	0.007	0	44.3	42.1	48.6	137	131	0	34	33
2014	7	1	15	18	42	0.833	-0.079	4.56	0.01	0.007	0	45.6	43.9	44.7	140	135	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	15	28	42	0.81	-0.052	4.557	0.01	0.007	0	45.2	43.4	51.6	139	134	0	34	33
2014	7	1	15	38	42	0.827	-0.138	4.56	0.01	0.007	0	43	41.3	49.5	135	129	0	35	33
2014	7	1	15	48	42	0.85	-0.062	4.56	0.01	0.007	0	41.7	40	52.9	132	126	0	35	33
2014	7	1	15	58	42	0.83	-0.098	4.56	0.01	0.007	0	42.1	40.4	51.6	132	127	0	34	33
2014	7	1	16	8	42	0.863	-0.108	4.56	0.01	0.007	0	40.9	39.6	53.3	130	125	0	35	33
2014	7	1	16	18	42	0.869	-0.115	4.56	0.01	0.007	0	40.4	38.7	49.5	128	123	0	34	33
2014	7	1	16	28	42	0.837	-0.125	4.56	0.01	0.007	0	40.9	38.7	49	129	123	0	34	33
2014	7	1	16	38	42	0.814	-0.125	4.56	0.01	0.007	0	40.9	39.1	53.3	129	124	0	34	33
2014	7	1	16	48	42	0.856	-0.131	4.56	0.013	0.01	0	40.9	39.1	57.2	129	124	0	34	33
2014	7	1	16	58	42	0.846	-0.128	4.557	0.01	0.007	0	40.4	38.7	51.2	128	123	0	34	33
2014	7	1	17	8	42	0.863	-0.112	4.56	0.01	0.007	0	40	38.3	56.3	127	122	0	34	33
2014	7	1	17	18	42	0.853	-0.059	4.56	0.01	0.007	0	40	38.3	54.6	127	122	0	34	33
2014	7	1	17	28	42	0.856	-0.089	4.56	0.01	0.007	0	40.4	39.1	56.3	128	123	0	34	32
2014	7	1	17	38	42	0.846	-0.089	4.56	0.013	0.01	0	40	37.8	53.3	127	121	0	34	33
2014	7	1	17	48	42	0.86	-0.131	4.56	0.013	0.01	0	40	37.8	55.5	127	121	0	34	33
2014	7	1	17	58	42	0.84	-0.082	4.56	0.01	0.007	0	40	37.8	54.2	127	121	0	34	33
2014	7	1	18	8	42	0.807	-0.056	4.564	0.01	0.007	0	40.9	38.7	52.5	129	123	0	34	33
2014	7	1	18	18	42	0.856	-0.072	4.56	0.01	0.007	0	39.6	38.3	55.9	127	122	0	35	33
2014	7	1	18	28	42	0.843	-0.092	4.564	0.01	0.007	0	40	38.3	54.6	127	122	0	34	33
2014	7	1	18	38	42	0.86	-0.085	4.564	0.01	0.007	0	41.3	39.6	54.6	130	124	0	34	32
2014	7	1	18	48	42	0.873	-0.089	4.564	0.01	0.007	0	40.9	38.7	55	129	123	0	34	33
2014	7	1	18	58	42	0.856	-0.112	4.564	0.01	0.007	0	40.4	38.7	58.9	128	123	0	34	33
2014	7	1	19	8	42	0.837	-0.085	4.56	0.01	0.007	0	40.9	38.7	60.2	128	123	0	33	33
2014	7	1	19	18	42	0.863	-0.079	4.564	0.01	0.007	0	40.9	38.3	71.8	129	123	0	34	34
2014	7	1	19	28	42	0.84	-0.062	4.564	0.01	0.007	0	41.3	39.1	67.1	130	124	0	34	33
2014	7	1	19	38	42	0.837	-0.085	4.564	0.01	0.007	0	40.9	39.1	71	129	124	0	34	33
2014	7	1	19	48	42	0.807	-0.079	4.564	0.01	0.007	0	41.3	39.1	64.5	130	125	0	34	34
2014	7	1	19	58	42	0.833	-0.052	4.564	0.01	0.007	0	41.3	39.6	69.2	130	125	0	34	33
2014	7	1	20	8	42	0.83	-0.039	4.564	0.01	0.007	0	40.9	39.1	64.5	129	124	0	34	33
2014	7	1	20	18	42	0.866	-0.049	4.567	0.01	0.007	0	41.7	39.6	73.1	130	125	0	33	33
2014	7	1	20	28	42	0.85	-0.082	4.567	0.01	0.007	0	41.7	39.6	71.4	131	125	0	34	33
2014	7	1	20	38	42	0.873	-0.072	4.564	0.013	0.01	0	42.1	40.4	64.9	133	127	0	35	33
2014	7	1	20	48	42	0.85	-0.072	4.567	0.01	0.007	0	41.7	40	68.4	131	126	0	34	33
2014	7	1	20	58	42	0.869	-0.102	4.567	0.01	0.007	0	40.9	39.1	63.2	129	124	0	34	33
2014	7	1	21	8	42	0.866	-0.072	4.567	0.01	0.007	0	41.3	39.1	70.1	130	124	0	34	33
2014	7	1	21	18	42	0.807	-0.056	4.567	0.01	0.007	0	41.7	40	67.1	131	126	0	34	33
2014	7	1	21	28	42	0.879	-0.089	4.567	0.01	0.007	0	41.3	39.6	72.2	130	125	0	34	33
2014	7	1	21	38	42	0.85	-0.072	4.567	0.01	0.007	0	40.4	39.1	72.7	129	124	0	35	33
2014	7	1	21	48	42	0.84	-0.056	4.567	0.01	0.007	0	40.9	39.1	73.5	129	124	0	34	33
2014	7	1	21	58	42	0.873	-0.072	4.57	0.01	0.007	0	40.9	39.1	74	129	124	0	34	33
2014	7	1	22	8	42	0.883	-0.056	4.57	0.01	0.007	0	40.9	38.7	62.8	129	123	0	34	33
2014	7	1	22	18	42	0.833	-0.069	4.57	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33
2014	7	1	22	28	42	0.856	-0.105	4.57	0.01	0.007	0	42.1	40.4	72.2	132	127	0	34	33
2014	7	1	22	38	42	0.833	-0.092	4.57	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33
2014	7	1	22	48	42	0.876	-0.108	4.57	0.013	0.01	0	40.4	38.7	75.7	128	123	0	34	33
2014	7	1	22	58	42	0.85	-0.079	4.57	0.01	0.007	0	40.9	39.1	75.7	129	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	23	8	42	0.85	-0.052	4.573	0.01	0.007	0	40.4	38.7	75.7	128	123	0	34	33
2014	7	1	23	18	42	0.85	-0.079	4.57	0.013	0.01	0	40.9	39.6	75.7	129	124	0	34	32
2014	7	1	23	28	42	0.846	-0.056	4.573	0.01	0.007	0	40.4	38.7	75.7	128	123	0	34	33
2014	7	1	23	38	42	0.866	-0.072	4.573	0.01	0.007	0	40.4	38.3	76.1	128	122	0	34	33
2014	7	1	23	48	42	0.85	-0.092	4.573	0.01	0.007	0	40.9	38.7	75.3	129	124	0	34	34
2014	7	1	23	58	42	0.863	-0.098	4.573	0.01	0.007	0	40.4	38.7	75.3	128	123	0	34	33
2014	7	2	0	8	42	0.846	-0.082	4.573	0.01	0.007	0	40.9	38.7	75.7	129	124	0	34	34
2014	7	2	0	18	42	0.853	-0.102	4.573	0.013	0.01	0	40.9	39.6	75.7	129	125	0	34	33
2014	7	2	0	28	42	0.863	-0.066	4.573	0.013	0.01	0	40	38.3	75.3	127	122	0	34	33
2014	7	2	0	38	42	0.869	-0.066	4.573	0.01	0.007	0	40	38.3	74.4	127	122	0	34	33
2014	7	2	0	48	42	0.827	-0.075	4.573	0.01	0.007	0	40	39.1	75.3	127	123	0	34	32
2014	7	2	0	58	42	0.85	-0.039	4.573	0.01	0.007	0	40.4	39.1	74.4	128	124	0	34	33
2014	7	2	1	8	42	0.843	-0.059	4.573	0.01	0.007	0	40.4	39.1	74	128	123	0	34	32
2014	7	2	1	18	42	0.866	-0.069	4.573	0.01	0.007	0	40	39.1	75.3	127	123	0	34	32
2014	7	2	1	28	42	0.869	-0.069	4.573	0.01	0.007	0	40.4	38.3	74.8	128	122	0	34	33
2014	7	2	1	38	42	0.86	-0.079	4.573	0.01	0.007	0	40.4	38.7	73.1	128	123	0	34	33
2014	7	2	1	48	42	0.833	-0.082	4.573	0.013	0.01	0	41.3	40	71.8	130	126	0	34	33
2014	7	2	1	58	42	0.846	-0.066	4.573	0.013	0.01	0	41.3	39.1	74.8	130	125	0	34	34
2014	7	2	2	8	42	0.846	-0.079	4.573	0.01	0.007	0	40	38.7	74.8	127	122	0	34	32
2014	7	2	2	18	42	0.846	-0.036	4.573	0.01	0.007	0	40.4	38.7	74.8	128	123	0	34	33
2014	7	2	2	28	42	0.843	-0.085	4.573	0.01	0.007	0	40.4	38.7	69.2	128	123	0	34	33
2014	7	2	2	38	42	0.856	-0.112	4.573	0.01	0.007	0	42.1	40	74	131	126	0	33	33
2014	7	2	2	48	42	0.84	-0.066	4.577	0.01	0.007	0	40	38.3	74	127	122	0	34	33
2014	7	2	2	58	42	0.866	-0.062	4.577	0.01	0.007	0	40.4	38.3	74.4	128	122	0	34	33
2014	7	2	3	8	42	0.86	-0.079	4.573	0.01	0.007	0	40.9	39.1	74.4	129	123	0	34	32
2014	7	2	3	18	42	0.853	-0.082	4.577	0.01	0.007	0	42.1	40.4	70.1	132	127	0	34	33
2014	7	2	3	28	42	0.837	-0.075	4.577	0.01	0.007	0	40.4	38.7	74.4	128	123	0	34	33
2014	7	2	3	38	42	0.85	-0.079	4.577	0.01	0.007	0	40	38.3	73.5	127	122	0	34	33
2014	7	2	3	48	42	0.833	-0.049	4.577	0.01	0.007	0	40	38.3	74	127	122	0	34	33
2014	7	2	3	58	42	0.853	-0.069	4.577	0.01	0.007	0	40.4	38.7	73.1	128	123	0	34	33
2014	7	2	4	8	42	0.827	-0.062	4.577	0.01	0.007	0	40	38.7	66.2	127	122	0	34	32
2014	7	2	4	18	42	0.856	-0.105	4.577	0.013	0.01	0	40.4	38.7	72.7	128	123	0	34	33
2014	7	2	4	28	42	0.84	-0.049	4.577	0.016	0.013	0	40	37.8	73.1	127	122	0	34	34
2014	7	2	4	38	42	0.86	-0.089	4.577	0.01	0.007	0	40	38.3	73.5	127	122	0	34	33
2014	7	2	4	48	42	0.86	-0.066	4.577	0.01	0.007	0	40	38.7	72.7	128	123	0	35	33
2014	7	2	4	58	42	0.866	-0.072	4.577	0.01	0.007	0	40.4	38.7	72.2	128	123	0	34	33
2014	7	2	5	8	42	0.843	-0.082	4.577	0.01	0.007	0	40	38.7	72.2	128	123	0	35	33
2014	7	2	5	18	42	0.863	-0.079	4.58	0.01	0.007	0	40.4	38.3	72.2	128	123	0	34	34
2014	7	2	5	28	42	0.85	-0.079	4.58	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	2	5	38	42	0.85	-0.062	4.58	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	2	5	48	42	0.85	-0.066	4.58	0.01	0.007	0	40.9	39.6	71.4	129	125	0	34	33
2014	7	2	5	58	42	0.876	-0.066	4.583	0.01	0.007	0	40	38.7	70.1	127	123	0	34	33
2014	7	2	6	8	42	0.886	-0.085	4.583	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	2	6	18	42	0.846	-0.059	4.583	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	2	6	28	42	0.856	-0.056	4.59	0.01	0.007	0	40	38.3	71.4	127	122	0	34	33
2014	7	2	6	38	42	0.833	-0.056	4.59	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	6	48	42	0.846	-0.082	4.59	0.01	0.007	0	40.4	38.7	71.8	128	123	0	34	33
2014	7	2	6	58	42	0.853	-0.075	4.59	0.01	0.007	0	40	38.3	71.8	127	122	0	34	33
2014	7	2	7	8	42	0.876	-0.056	4.59	0.01	0.007	0	40.4	38.7	72.2	128	123	0	34	33
2014	7	2	7	18	42	0.856	-0.089	4.593	0.01	0.007	0	39.6	37.8	71.8	126	122	0	34	34
2014	7	2	7	28	42	0.853	-0.062	4.593	0.01	0.007	0	39.6	38.3	72.2	126	122	0	34	33
2014	7	2	7	38	42	0.892	-0.095	4.593	0.01	0.007	0	39.6	38.3	71.8	126	122	0	34	33
2014	7	2	7	48	42	0.866	-0.105	4.593	0.01	0.007	0	39.6	38.3	72.7	126	122	0	34	33
2014	7	2	7	58	42	0.879	-0.075	4.593	0.01	0.007	0	39.6	37.8	72.7	126	121	0	34	33
2014	7	2	8	8	42	0.846	-0.069	4.593	0.01	0.007	0	40	38.7	72.2	127	123	0	34	33
2014	7	2	8	18	42	0.86	-0.098	4.593	0.01	0.007	0	39.1	37.4	73.1	126	121	0	35	34
2014	7	2	8	28	42	0.86	-0.075	4.593	0.016	0.013	0	40.4	38.3	72.2	127	122	0	33	33
2014	7	2	8	38	42	0.86	-0.121	4.593	0.01	0.007	0	39.1	38.3	72.7	126	121	0	35	32
2014	7	2	8	48	42	0.85	-0.066	4.593	0.01	0.007	0	40	38.3	72.7	127	122	0	34	33
2014	7	2	8	58	42	0.876	-0.098	4.593	0.01	0.007	0	39.6	38.3	71.4	126	122	0	34	33
2014	7	2	9	8	42	0.856	-0.125	4.593	0.01	0.007	0	40.4	38.7	72.2	128	123	0	34	33
2014	7	2	9	18	42	0.856	-0.144	4.593	0.01	0.007	0	40	37.8	71.8	127	121	0	34	33
2014	7	2	9	28	42	0.883	-0.112	4.593	0.013	0.01	0	40	38.3	71.8	127	122	0	34	33
2014	7	2	9	38	42	0.889	-0.128	4.593	0.01	0.007	0	39.6	38.3	72.2	126	122	0	34	33
2014	7	2	9	48	42	0.869	-0.118	4.593	0.01	0.007	0	40	38.3	71	127	122	0	34	33
2014	7	2	9	58	42	0.876	-0.082	4.593	0.01	0.007	0	40.4	38.3	71.4	128	123	0	34	34
2014	7	2	10	8	42	0.873	-0.115	4.593	0.013	0.01	0	40.9	38.7	71.8	129	124	0	34	34
2014	7	2	10	18	42	0.892	-0.112	4.593	0.01	0.007	0	40	38.3	72.2	128	123	0	35	34
2014	7	2	10	28	42	0.856	-0.164	4.59	0.01	0.007	0	40	38.7	70.5	128	123	0	35	33
2014	7	2	10	38	42	0.843	-0.131	4.59	0.01	0.007	0	40.4	38.7	70.1	128	123	0	34	33
2014	7	2	10	48	42	0.863	-0.167	4.59	0.01	0.007	0	40.4	39.6	70.1	128	124	0	34	32
2014	7	2	10	58	42	0.863	-0.151	4.59	0.01	0.007	0	40.4	38.7	71.4	128	123	0	34	33
2014	7	2	11	8	42	0.879	-0.118	4.587	0.01	0.007	0	40	38.3	70.1	127	122	0	34	33
2014	7	2	11	18	42	0.883	-0.121	4.587	0.01	0.007	0	40.4	38.7	61.5	128	123	0	34	33
2014	7	2	11	28	42	0.86	-0.131	4.587	0.01	0.007	0	40	38.7	56.3	128	123	0	35	33
2014	7	2	11	38	42	0.827	-0.151	4.587	0.013	0.01	0	40	38.7	52.9	128	123	0	35	33
2014	7	2	11	48	42	0.85	-0.194	4.587	0.01	0.007	0	40.4	38.7	52.9	128	123	0	34	33
2014	7	2	11	58	42	0.837	-0.19	4.583	0.01	0.007	0	40	38.7	57.6	128	123	0	35	33
2014	7	2	12	8	42	0.85	-0.138	4.583	0.013	0.01	0	40.4	38.7	61.1	128	123	0	34	33
2014	7	2	12	18	42	0.846	-0.19	4.587	0.01	0.007	0	40.4	38.7	55.9	128	123	0	34	33
2014	7	2	12	28	42	0.85	-0.128	4.587	0.013	0.01	0	40.9	39.1	52.5	129	124	0	34	33
2014	7	2	12	38	42	0.843	-0.115	4.583	0.01	0.007	0	40.4	39.1	57.6	128	124	0	34	33
2014	7	2	12	48	42	0.853	-0.164	4.583	0.01	0.007	0	40.4	39.1	53.8	128	123	0	34	32
2014	7	2	12	58	42	0.863	-0.151	4.583	0.01	0.007	0	40.4	38.7	53.8	128	123	0	34	33
2014	7	2	13	8	42	0.84	-0.154	4.583	0.013	0.01	0	40.9	39.1	52.9	129	124	0	34	33
2014	7	2	13	18	42	0.843	-0.187	4.583	0.01	0.007	0	40.9	39.1	52	129	124	0	34	33
2014	7	2	13	28	42	0.814	-0.135	4.587	0.01	0.007	0	41.3	39.6	51.2	130	125	0	34	33
2014	7	2	13	38	42	0.83	-0.148	4.587	0.01	0.007	0	41.3	39.6	50.7	130	125	0	34	33
2014	7	2	13	48	42	0.846	-0.19	4.587	0.01	0.007	0	41.3	39.6	50.7	130	125	0	34	33
2014	7	2	13	58	42	0.833	-0.161	4.583	0.01	0.007	0	40.4	39.1	52	129	124	0	35	33
2014	7	2	14	8	42	0.823	-0.197	4.583	0.01	0.007	0	40.9	38.7	52	129	124	0	34	34
2014	7	2	14	18	42	0.83	-0.085	4.583	0.01	0.007	0	40	38.3	53.8	128	123	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	14	28	42	0.833	-0.121	4.58	0.01	0.007	0	40.9	39.1	51.6	129	124	0	34	33
2014	7	2	14	38	42	0.84	-0.151	4.58	0.01	0.007	0	41.3	39.6	49.9	130	125	0	34	33
2014	7	2	14	48	42	0.846	-0.095	4.58	0.01	0.007	0	40.9	39.1	52.9	129	124	0	34	33
2014	7	2	14	58	42	0.876	-0.131	4.58	0.01	0.007	0	40.4	39.1	51.2	128	123	0	34	32
2014	7	2	15	8	42	0.827	-0.154	4.58	0.01	0.007	0	40.9	39.6	47.3	129	124	0	34	32
2014	7	2	15	18	42	0.83	-0.105	4.58	0.01	0.007	0	40.9	39.6	52.5	129	125	0	34	33
2014	7	2	15	28	42	0.863	-0.115	4.58	0.013	0.01	0	41.3	39.6	51.2	130	125	0	34	33
2014	7	2	15	38	42	0.84	-0.151	4.58	0.01	0.007	0	40.9	39.1	50.3	130	124	0	35	33
2014	7	2	15	48	42	0.84	-0.131	4.577	0.01	0.007	0	40.9	40	52	130	125	0	35	32
2014	7	2	15	58	42	0.883	-0.082	4.58	0.01	0.007	0	40.4	39.1	52.9	128	124	0	34	33
2014	7	2	16	8	42	0.886	-0.069	4.58	0.01	0.007	0	40.4	38.7	53.8	128	123	0	34	33
2014	7	2	16	18	42	0.86	-0.092	4.58	0.01	0.007	0	40	39.1	51.2	128	124	0	35	33
2014	7	2	16	28	42	0.84	-0.098	4.58	0.01	0.007	0	40.4	38.7	52.5	128	123	0	34	33
2014	7	2	16	38	42	0.846	-0.085	4.58	0.013	0.01	0	40	38.3	51.2	127	122	0	34	33
2014	7	2	16	48	42	0.843	-0.082	4.58	0.01	0.007	0	41.3	39.1	52.9	130	124	0	34	33
2014	7	2	16	58	42	0.833	-0.062	4.577	0.01	0.007	0	40.4	38.7	52.9	128	123	0	34	33
2014	7	2	17	8	42	0.86	-0.066	4.577	0.01	0.007	0	40.9	39.1	52.9	129	123	0	34	32
2014	7	2	17	18	42	0.879	-0.118	4.58	0.01	0.007	0	40.9	38.7	53.8	128	123	0	33	33
2014	7	2	17	28	42	0.889	-0.079	4.58	0.013	0.01	0	40.9	39.1	52.9	129	124	0	34	33
2014	7	2	17	38	42	0.85	-0.082	4.58	0.013	0.01	0	40	38.7	54.2	127	123	0	34	33
2014	7	2	17	48	42	0.837	-0.059	4.58	0.01	0.007	0	40.9	38.7	51.2	129	123	0	34	33
2014	7	2	17	58	42	0.85	-0.089	4.577	0.01	0.007	0	41.3	39.6	54.6	130	125	0	34	33
2014	7	2	18	8	42	0.86	-0.108	4.577	0.01	0.007	0	42.6	40.9	55.5	133	128	0	34	33
2014	7	2	18	18	42	0.863	-0.102	4.577	0.01	0.007	0	40.9	39.1	70.1	130	124	0	35	33
2014	7	2	18	28	42	0.837	-0.082	4.577	0.013	0.01	0	41.3	39.6	57.2	130	125	0	34	33
2014	7	2	18	38	42	0.837	-0.092	4.577	0.01	0.007	0	41.3	39.6	62.8	130	125	0	34	33
2014	7	2	18	48	42	0.83	-0.089	4.577	0.01	0.007	0	40.4	38.7	69.7	128	123	0	34	33
2014	7	2	18	58	42	0.856	-0.079	4.577	0.01	0.007	0	40.9	39.6	56.8	129	124	0	34	32
2014	7	2	19	8	42	0.863	-0.082	4.577	0.01	0.007	0	41.7	40	58	131	126	0	34	33
2014	7	2	19	18	42	0.853	-0.082	4.577	0.01	0.007	0	40.4	38.7	74	128	123	0	34	33
2014	7	2	19	28	42	0.86	-0.079	4.577	0.013	0.01	0	41.3	38.7	72.2	129	123	0	33	33
2014	7	2	19	38	42	0.843	-0.075	4.577	0.01	0.007	0	40.9	38.7	74	128	123	0	33	33
2014	7	2	19	48	42	0.863	-0.085	4.577	0.013	0.01	0	40.9	38.7	66.7	129	123	0	34	33
2014	7	2	19	58	42	0.827	-0.092	4.577	0.01	0.007	0	40.9	38.7	70.1	129	123	0	34	33
2014	7	2	20	8	42	0.82	-0.052	4.577	0.01	0.007	0	40	38.7	73.1	128	122	0	35	32
2014	7	2	20	18	42	0.83	-0.082	4.58	0.01	0.007	0	40.9	39.6	73.1	130	125	0	35	33
2014	7	2	20	28	42	0.843	-0.085	4.577	0.01	0.007	0	40.9	39.6	73.1	129	124	0	34	32
2014	7	2	20	38	42	0.846	-0.079	4.58	0.01	0.007	0	41.3	39.6	68.4	130	125	0	34	33
2014	7	2	20	48	42	0.866	-0.095	4.58	0.01	0.007	0	41.3	39.6	68.4	130	125	0	34	33
2014	7	2	20	58	42	0.84	-0.072	4.58	0.01	0.007	0	40.9	39.1	67.9	129	124	0	34	33
2014	7	2	21	8	42	0.85	-0.079	4.58	0.01	0.007	0	41.3	39.6	62.4	130	125	0	34	33
2014	7	2	21	18	42	0.873	-0.098	4.58	0.01	0.007	0	40.9	39.1	68.8	129	124	0	34	33
2014	7	2	21	28	42	0.853	-0.085	4.583	0.013	0.01	0	41.7	40	69.7	131	126	0	34	33
2014	7	2	21	38	42	0.873	-0.079	4.583	0.01	0.007	0	41.3	39.6	71.8	130	125	0	34	33
2014	7	2	21	48	42	0.889	-0.098	4.583	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	2	21	58	42	0.863	-0.092	4.583	0.01	0.007	0	41.7	39.6	71.4	131	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	22	8	42	0.843	-0.082	4.583	0.01	0.007	0	41.3	39.6	65.8	130	125	0	34	33
2014	7	2	22	18	42	0.886	-0.075	4.583	0.01	0.007	0	40.9	39.1	71.4	129	124	0	34	33
2014	7	2	22	28	42	0.869	-0.092	4.583	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	2	22	38	42	0.863	-0.049	4.587	0.01	0.007	0	41.3	39.6	67.9	130	125	0	34	33
2014	7	2	22	48	42	0.843	-0.108	4.587	0.013	0.01	0	40.9	39.1	67.9	129	124	0	34	33
2014	7	2	22	58	42	0.856	-0.098	4.587	0.01	0.007	0	41.3	39.1	69.7	129	124	0	33	33
2014	7	2	23	8	42	0.84	-0.056	4.59	0.01	0.007	0	40	38.7	63.2	127	123	0	34	33
2014	7	2	23	18	42	0.863	-0.049	4.59	0.01	0.007	0	40.4	39.1	70.5	128	124	0	34	33
2014	7	2	23	28	42	0.856	-0.062	4.59	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	2	23	38	42	0.83	-0.049	4.593	0.01	0.007	0	40.4	39.1	71	129	124	0	35	33
2014	7	2	23	48	42	0.873	-0.082	4.593	0.01	0.007	0	40.9	39.1	71	130	124	0	35	33
2014	7	2	23	58	42	0.876	-0.062	4.593	0.01	0.007	0	40.9	39.1	65.4	129	124	0	34	33
2014	7	3	0	8	42	0.873	-0.105	4.596	0.01	0.007	0	41.3	39.1	71.4	129	124	0	33	33
2014	7	3	0	18	42	0.853	-0.082	4.596	0.01	0.007	0	41.3	40	71.4	130	126	0	34	33
2014	7	3	0	28	42	0.853	-0.066	4.596	0.01	0.007	0	41.7	39.6	71.4	131	126	0	34	34
2014	7	3	0	38	42	0.869	-0.079	4.596	0.013	0.01	0	41.3	40	71.8	130	126	0	34	33
2014	7	3	0	48	42	0.84	-0.062	4.596	0.01	0.007	0	41.7	40	69.2	131	127	0	34	34
2014	7	3	0	58	42	0.886	-0.069	4.596	0.01	0.007	0	41.3	39.6	72.7	130	125	0	34	33
2014	7	3	1	8	42	0.866	-0.072	4.596	0.01	0.007	0	41.3	40	72.2	130	126	0	34	33
2014	7	3	1	18	42	0.817	-0.049	4.596	0.01	0.007	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	3	1	28	42	0.863	-0.092	4.6	0.01	0.007	0	40.4	38.7	73.5	128	123	0	34	33
2014	7	3	1	38	42	0.86	-0.069	4.6	0.01	0.007	0	40.4	38.7	74.4	128	123	0	34	33
2014	7	3	1	48	42	0.863	-0.079	4.603	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	3	1	58	42	0.866	-0.079	4.603	0.01	0.007	0	40.4	38.7	74	128	123	0	34	33
2014	7	3	2	8	42	0.856	-0.079	4.603	0.01	0.007	0	41.3	39.6	69.7	130	125	0	34	33
2014	7	3	2	18	42	0.833	-0.062	4.603	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	3	2	28	42	0.853	-0.075	4.603	0.01	0.007	0	40.9	39.6	75.3	129	125	0	34	33
2014	7	3	2	38	42	0.869	-0.062	4.603	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	3	2	48	42	0.85	-0.062	4.603	0.01	0.007	0	40	38.7	75.7	128	123	0	35	33
2014	7	3	2	58	42	0.837	-0.062	4.606	0.01	0.007	0	40.9	39.1	75.7	129	124	0	34	33
2014	7	3	3	8	42	0.817	-0.079	4.606	0.01	0.007	0	40.9	39.6	75.3	130	125	0	35	33
2014	7	3	3	18	42	0.823	-0.049	4.606	0.01	0.007	0	41.3	39.6	75.7	130	125	0	34	33
2014	7	3	3	28	42	0.873	-0.069	4.606	0.01	0.007	0	40.9	39.1	67.1	129	124	0	34	33
2014	7	3	3	38	42	0.866	-0.049	4.603	0.01	0.007	0	40.9	39.6	74.4	130	125	0	35	33
2014	7	3	3	48	42	0.853	-0.098	4.603	0.013	0.01	0	40.9	39.6	74.8	129	125	0	34	33
2014	7	3	3	58	42	0.86	-0.049	4.606	0.01	0.007	0	41.3	40	74.4	130	125	0	34	32
2014	7	3	4	8	42	0.846	-0.085	4.606	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	3	4	18	42	0.853	-0.075	4.603	0.01	0.007	0	40.9	39.6	74.4	129	125	0	34	33
2014	7	3	4	28	42	0.869	-0.085	4.606	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	3	4	38	42	0.879	-0.085	4.606	0.013	0.01	0	40.9	38.7	74.8	129	124	0	34	34
2014	7	3	4	48	42	0.843	-0.056	4.606	0.01	0.007	0	41.3	40	74.8	130	125	0	34	32
2014	7	3	4	58	42	0.86	-0.056	4.606	0.01	0.007	0	41.7	40	74	131	126	0	34	33
2014	7	3	5	8	42	0.85	-0.056	4.606	0.01	0.007	0	41.3	39.6	73.5	130	125	0	34	33
2014	7	3	5	18	42	0.837	-0.075	4.606	0.01	0.007	0	41.7	39.6	74	131	126	0	34	34
2014	7	3	5	28	42	0.853	-0.085	4.606	0.01	0.007	0	44.3	42.1	72.2	137	132	0	34	34
2014	7	3	5	38	42	0.85	-0.066	4.606	0.013	0.01	0	42.1	40.9	73.5	133	128	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	5	48	42	0.879	-0.075	4.606	0.01	0.007	0	41.7	40.4	73.1	132	127	0	35	33
2014	7	3	5	58	42	0.873	-0.079	4.61	0.01	0.007	0	41.7	40	73.1	131	126	0	34	33
2014	7	3	6	8	42	0.876	-0.072	4.61	0.01	0.007	0	42.1	40.4	73.1	132	127	0	34	33
2014	7	3	6	18	42	0.866	-0.115	4.61	0.013	0.01	0	40.9	39.1	72.7	129	124	0	34	33
2014	7	3	6	28	42	0.83	-0.062	4.61	0.01	0.007	0	40.9	39.1	72.7	129	125	0	34	34
2014	7	3	6	38	42	0.853	-0.062	4.61	0.013	0.01	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	3	6	48	42	0.846	-0.049	4.61	0.01	0.007	0	41.3	39.6	72.7	130	125	0	34	33
2014	7	3	6	58	42	0.833	-0.056	4.61	0.01	0.007	0	40.9	39.1	72.7	129	124	0	34	33
2014	7	3	7	8	42	0.873	-0.052	4.61	0.01	0.007	0	40.9	39.6	73.5	130	125	0	35	33
2014	7	3	7	18	42	0.889	-0.079	4.61	0.01	0.007	0	40	39.1	72.7	128	124	0	35	33
2014	7	3	7	28	42	0.869	-0.095	4.61	0.01	0.007	0	40	38.7	72.7	127	123	0	34	33
2014	7	3	7	38	42	0.866	-0.098	4.61	0.01	0.007	0	40.9	39.1	72.7	129	124	0	34	33
2014	7	3	7	48	42	0.856	-0.092	4.61	0.01	0.007	0	40.4	39.6	72.7	129	125	0	35	33
2014	7	3	7	58	42	0.86	-0.079	4.61	0.016	0.016	0	40.9	39.6	73.1	130	125	0	35	33
2014	7	3	8	8	42	0.879	-0.092	4.61	0.01	0.007	0	41.3	40	72.7	130	126	0	34	33
2014	7	3	8	18	42	0.886	-0.082	4.61	0.01	0.007	0	41.7	40	73.1	131	126	0	34	33
2014	7	3	8	28	42	0.846	-0.092	4.61	0.016	0.013	0	41.7	40	73.1	132	127	0	35	34
2014	7	3	8	38	42	0.883	-0.098	4.61	0.01	0.007	0	41.7	40.4	72.7	132	127	0	35	33
2014	7	3	8	48	42	0.876	-0.095	4.61	0.01	0.007	0	41.3	39.6	73.1	130	126	0	34	34
2014	7	3	8	58	42	0.863	-0.098	4.61	0.01	0.007	0	40.9	39.6	72.7	130	126	0	35	34
2014	7	3	9	8	42	0.902	-0.141	4.61	0.01	0.007	0	40.9	39.6	72.2	130	125	0	35	33
2014	7	3	9	18	42	0.866	-0.144	4.61	0.01	0.007	0	40.9	39.6	73.1	129	125	0	34	33
2014	7	3	9	28	42	0.866	-0.112	4.61	0.01	0.007	0	41.3	39.6	72.7	130	125	0	34	33
2014	7	3	9	38	42	0.846	-0.151	4.61	0.013	0.01	0	41.3	40	72.7	130	126	0	34	33
2014	7	3	9	48	42	0.863	-0.167	4.61	0.01	0.007	0	41.7	39.6	71.8	131	126	0	34	34
2014	7	3	9	58	42	0.869	-0.121	4.61	0.01	0.007	0	41.3	39.6	71.8	130	125	0	34	33
2014	7	3	10	8	42	0.86	-0.098	4.61	0.01	0.007	0	41.7	39.6	58.9	131	126	0	34	34
2014	7	3	10	18	42	0.86	-0.128	4.61	0.01	0.007	0	41.7	40	52.9	132	126	0	35	33
2014	7	3	10	28	42	0.889	-0.112	4.613	0.01	0.007	0	41.7	40.4	53.8	131	127	0	34	33
2014	7	3	10	38	42	0.883	-0.151	4.61	0.01	0.007	0	41.7	40.4	63.6	132	127	0	35	33
2014	7	3	10	48	42	0.866	-0.154	4.61	0.01	0.007	0	43	41.3	57.2	134	129	0	34	33
2014	7	3	10	58	42	0.866	-0.125	4.61	0.01	0.007	0	42.1	40.4	56.8	132	127	0	34	33
2014	7	3	11	8	42	0.856	-0.079	4.61	0.01	0.007	0	42.1	40	55.5	132	127	0	34	34
2014	7	3	11	18	42	0.85	-0.089	4.613	0.01	0.007	0	41.7	40.9	53.8	132	128	0	35	33
2014	7	3	11	28	42	0.869	-0.18	4.61	0.01	0.007	0	42.1	40.4	54.6	132	127	0	34	33
2014	7	3	11	38	42	0.85	-0.164	4.61	0.01	0.007	0	41.3	39.6	60.6	130	126	0	34	34
2014	7	3	11	48	42	0.879	-0.144	4.61	0.01	0.007	0	41.7	40	60.2	131	126	0	34	33
2014	7	3	11	58	42	0.84	-0.125	4.61	0.01	0.007	0	41.7	40.4	51.6	131	127	0	34	33
2014	7	3	12	8	42	0.846	-0.144	4.61	0.01	0.007	0	42.1	40.4	56.8	132	127	0	34	33
2014	7	3	12	18	42	0.863	-0.151	4.61	0.01	0.007	0	41.7	40.4	58	131	126	0	34	32
2014	7	3	12	28	42	0.856	-0.128	4.61	0.01	0.007	0	41.3	40	62.8	130	126	0	34	33
2014	7	3	12	38	42	0.876	-0.154	4.61	0.01	0.007	0	41.3	40.4	53.3	131	127	0	35	33
2014	7	3	12	48	42	0.869	-0.177	4.61	0.013	0.01	0	41.7	40	52.9	131	126	0	34	33
2014	7	3	12	58	42	0.846	-0.194	4.613	0.01	0.007	0	42.1	40.9	51.6	132	128	0	34	33
2014	7	3	13	8	42	0.827	-0.161	4.61	0.01	0.007	0	41.7	39.6	51.6	131	126	0	34	34
2014	7	3	13	18	42	0.889	-0.161	4.61	0.01	0.007	0	41.7	40	55	131	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	13	28	42	0.84	-0.144	4.606	0.013	0.01	0	41.3	40	59.3	130	126	0	34	33
2014	7	3	13	38	42	0.853	-0.154	4.61	0.01	0.007	0	41.7	40.4	55.9	131	126	0	34	32
2014	7	3	13	48	42	0.86	-0.105	4.61	0.01	0.007	0	41.7	40	59.8	131	126	0	34	33
2014	7	3	13	58	42	0.869	-0.19	4.61	0.013	0.01	0	41.7	40	51.2	131	126	0	34	33
2014	7	3	14	8	42	0.856	-0.128	4.606	0.01	0.007	0	41.3	40	60.2	131	126	0	35	33
2014	7	3	14	18	42	0.866	-0.148	4.606	0.01	0.007	0	41.7	40	55.9	130	126	0	33	33
2014	7	3	14	28	42	0.84	-0.089	4.61	0.013	0.01	0	41.7	40.4	49.5	131	127	0	34	33
2014	7	3	14	38	42	0.869	-0.102	4.606	0.01	0.007	0	42.1	40	52.5	132	127	0	34	34
2014	7	3	14	48	42	0.833	-0.151	4.606	0.01	0.007	0	41.3	40	52	130	126	0	34	33
2014	7	3	14	58	42	0.863	-0.157	4.606	0.01	0.007	0	41.7	40.4	52.5	132	127	0	35	33
2014	7	3	15	8	42	0.85	-0.066	4.606	0.013	0.01	0	41.7	40.4	50.7	131	127	0	34	33
2014	7	3	15	18	42	0.86	-0.072	4.606	0.01	0.007	0	42.1	40.9	53.8	131	128	0	33	33
2014	7	3	15	28	42	0.869	-0.131	4.606	0.01	0.007	0	41.3	39.6	53.8	130	125	0	34	33
2014	7	3	15	38	42	0.863	-0.118	4.606	0.01	0.007	0	41.3	39.6	52.9	130	125	0	34	33
2014	7	3	15	48	42	0.856	-0.115	4.606	0.01	0.007	0	41.3	40	74.8	130	126	0	34	33
2014	7	3	15	58	42	0.876	-0.121	4.606	0.013	0.01	0	40.9	39.6	58.9	129	125	0	34	33
2014	7	3	16	8	42	0.853	-0.118	4.606	0.01	0.007	0	41.3	40.4	51.6	130	126	0	34	32
2014	7	3	16	18	42	0.853	-0.098	4.606	0.013	0.01	0	41.3	40	53.3	130	126	0	34	33
2014	7	3	16	28	42	0.86	-0.138	4.606	0.01	0.007	0	40.9	40	53.8	130	125	0	35	32
2014	7	3	16	38	42	0.863	-0.075	4.606	0.01	0.007	0	41.3	40	56.8	130	125	0	34	32
2014	7	3	16	48	42	0.873	-0.072	4.606	0.01	0.007	0	41.3	39.6	50.7	130	125	0	34	33
2014	7	3	16	58	42	0.866	-0.115	4.606	0.01	0.007	0	40.4	38.7	60.6	128	123	0	34	33
2014	7	3	17	8	42	0.886	-0.098	4.606	0.01	0.007	0	40	38.7	58.5	128	123	0	35	33
2014	7	3	17	18	42	0.85	-0.082	4.606	0.01	0.007	0	40.4	38.7	52	128	123	0	34	33
2014	7	3	17	28	42	0.873	-0.095	4.606	0.01	0.007	0	40.4	38.3	61.5	127	122	0	33	33
2014	7	3	17	38	42	0.883	-0.148	4.606	0.01	0.007	0	40	38.3	71.4	127	122	0	34	33
2014	7	3	17	48	42	0.876	-0.131	4.603	0.01	0.007	0	39.1	37.8	64.1	126	122	0	35	34
2014	7	3	17	58	42	0.866	-0.098	4.603	0.01	0.007	0	40	38.7	55	127	122	0	34	32
2014	7	3	18	8	42	0.863	-0.085	4.606	0.01	0.007	0	40	38.3	76.1	127	122	0	34	33
2014	7	3	18	18	42	0.889	-0.082	4.606	0.01	0.007	0	40	38.3	56.8	126	122	0	33	33
2014	7	3	18	28	42	0.856	-0.089	4.606	0.01	0.007	0	39.6	38.3	73.1	126	122	0	34	33
2014	7	3	18	38	42	0.85	-0.131	4.603	0.01	0.007	0	39.1	37	60.6	125	120	0	34	34
2014	7	3	18	48	42	0.886	-0.144	4.606	0.01	0.007	0	39.6	38.3	62.4	126	122	0	34	33
2014	7	3	18	58	42	0.827	-0.095	4.606	0.01	0.007	0	39.6	38.3	75.3	126	122	0	34	33
2014	7	3	19	8	42	0.85	-0.105	4.606	0.01	0.007	0	40.9	38.7	70.1	129	124	0	34	34
2014	7	3	19	18	42	0.846	-0.085	4.606	0.01	0.007	0	40	38.3	75.7	127	122	0	34	33
2014	7	3	19	28	42	0.86	-0.069	4.606	0.01	0.007	0	40.9	39.6	74.4	129	124	0	34	32
2014	7	3	19	38	42	0.892	-0.102	4.606	0.01	0.007	0	40.4	39.1	71.8	128	124	0	34	33
2014	7	3	19	48	42	0.876	-0.046	4.606	0.01	0.007	0	40.9	39.1	67.5	129	124	0	34	33
2014	7	3	19	58	42	0.876	-0.098	4.606	0.01	0.007	0	41.3	40	74.4	130	125	0	34	32
2014	7	3	20	8	42	0.866	-0.082	4.606	0.01	0.007	0	40.9	39.6	70.5	129	125	0	34	33
2014	7	3	20	18	42	0.82	-0.069	4.606	0.01	0.007	0	43	41.3	70.1	134	129	0	34	33
2014	7	3	20	28	42	0.85	-0.072	4.606	0.01	0.007	0	41.7	40	74.4	131	126	0	34	33
2014	7	3	20	38	42	0.866	-0.039	4.606	0.01	0.007	0	41.7	39.6	73.1	130	125	0	33	33
2014	7	3	20	48	42	0.869	-0.085	4.606	0.01	0.007	0	42.1	40.4	68.8	132	127	0	34	33
2014	7	3	20	58	42	0.86	-0.079	4.606	0.013	0.01	0	42.6	40.9	70.5	133	128	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	21	8	42	0.833	-0.082	4.606	0.01	0.007	0	41.3	40	71.4	130	126	0	34	33
2014	7	3	21	18	42	0.827	-0.052	4.606	0.013	0.01	0	42.1	40.4	67.9	132	127	0	34	33
2014	7	3	21	28	42	0.896	-0.102	4.606	0.01	0.007	0	41.3	39.6	71.8	130	125	0	34	33
2014	7	3	21	38	42	0.843	-0.082	4.61	0.01	0.007	0	42.1	40.4	74	131	127	0	33	33
2014	7	3	21	48	42	0.85	-0.098	4.61	0.01	0.007	0	41.3	39.6	73.1	129	125	0	33	33
2014	7	3	21	58	42	0.846	-0.036	4.61	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	3	22	8	42	0.869	-0.079	4.61	0.01	0.007	0	40.9	39.6	74.8	129	125	0	34	33
2014	7	3	22	18	42	0.85	-0.089	4.61	0.01	0.007	0	41.3	39.1	71	130	125	0	34	34
2014	7	3	22	28	42	0.85	-0.095	4.61	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	3	22	38	42	0.876	-0.072	4.61	0.01	0.007	0	42.1	40.4	74.8	132	127	0	34	33
2014	7	3	22	48	42	0.873	-0.066	4.61	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	3	22	58	42	0.85	-0.066	4.61	0.013	0.01	0	41.3	39.6	74.4	130	126	0	34	34
2014	7	3	23	8	42	0.869	-0.079	4.61	0.01	0.007	0	41.3	39.6	75.3	130	125	0	34	33
2014	7	3	23	18	42	0.846	-0.082	4.61	0.01	0.007	0	41.7	40	74	131	126	0	34	33
2014	7	3	23	28	42	0.86	-0.118	4.61	0.01	0.007	0	40	38.7	68.8	128	123	0	35	33
2014	7	3	23	38	42	0.853	-0.092	4.61	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	3	23	48	42	0.876	-0.085	4.61	0.01	0.007	0	41.3	39.6	74	130	126	0	34	34
2014	7	3	23	58	42	0.833	-0.079	4.61	0.013	0.01	0	40.9	39.1	74.4	128	124	0	33	33
2014	7	4	0	8	42	0.86	-0.062	4.61	0.01	0.007	0	41.3	40	73.1	131	126	0	35	33
2014	7	4	0	18	42	0.853	-0.075	4.61	0.01	0.007	0	40.9	39.6	74	129	125	0	34	33
2014	7	4	0	28	42	0.84	-0.066	4.61	0.01	0.007	0	41.3	39.1	73.5	130	125	0	34	34
2014	7	4	0	38	42	0.83	-0.066	4.61	0.01	0.007	0	40.9	39.6	73.5	129	125	0	34	33
2014	7	4	0	48	42	0.86	-0.066	4.61	0.01	0.007	0	40.9	39.6	74.4	129	125	0	34	33
2014	7	4	0	58	42	0.846	-0.066	4.613	0.013	0.01	0	41.3	39.6	74	130	125	0	34	33
2014	7	4	1	8	42	0.843	-0.092	4.61	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	4	1	18	42	0.85	-0.082	4.61	0.01	0.007	0	41.3	39.6	74.4	130	125	0	34	33
2014	7	4	1	28	42	0.846	-0.082	4.61	0.01	0.007	0	40.9	39.6	69.7	129	125	0	34	33
2014	7	4	1	38	42	0.833	-0.072	4.613	0.01	0.007	0	41.3	39.1	73.5	130	125	0	34	34
2014	7	4	1	48	42	0.863	-0.069	4.61	0.01	0.007	0	41.3	40	74	130	126	0	34	33
2014	7	4	1	58	42	0.843	-0.066	4.61	0.01	0.007	0	42.6	40.9	71	133	128	0	34	33
2014	7	4	2	8	42	0.876	-0.043	4.61	0.01	0.007	0	41.3	39.6	74	130	126	0	34	34
2014	7	4	2	18	42	0.843	-0.066	4.613	0.01	0.007	0	41.7	40	72.7	131	126	0	34	33
2014	7	4	2	28	42	0.843	-0.079	4.613	0.01	0.007	0	41.7	39.6	72.7	131	126	0	34	34
2014	7	4	2	38	42	0.86	-0.069	4.613	0.01	0.007	0	41.7	40	73.1	131	126	0	34	33
2014	7	4	2	48	42	0.84	-0.036	4.613	0.01	0.007	0	42.1	40.4	73.1	132	127	0	34	33
2014	7	4	2	58	42	0.817	-0.062	4.613	0.016	0.013	0	42.1	40	72.7	132	126	0	34	33
2014	7	4	3	8	42	0.827	-0.072	4.613	0.01	0.007	0	41.7	40	72.2	131	126	0	34	33
2014	7	4	3	18	42	0.846	-0.085	4.613	0.01	0.007	0	41.7	40	72.7	131	126	0	34	33
2014	7	4	3	28	42	0.843	-0.098	4.613	0.01	0.007	0	42.1	40.4	72.2	132	127	0	34	33
2014	7	4	3	38	42	0.863	-0.059	4.613	0.01	0.007	0	41.7	39.6	71.8	131	125	0	34	33
2014	7	4	3	48	42	0.85	-0.049	4.613	0.013	0.01	0	42.1	40	71.8	132	126	0	34	33
2014	7	4	3	58	42	0.856	-0.062	4.616	0.01	0.007	0	42.1	40	67.5	132	127	0	34	34
2014	7	4	4	8	42	0.85	-0.062	4.616	0.01	0.007	0	42.1	40	71	132	127	0	34	34
2014	7	4	4	18	42	0.856	-0.056	4.616	0.01	0.007	0	41.7	40	71	131	126	0	34	33
2014	7	4	4	28	42	0.853	-0.075	4.616	0.013	0.01	0	41.3	39.1	71.4	130	125	0	34	34
2014	7	4	4	38	42	0.863	-0.059	4.619	0.01	0.007	0	40.9	39.6	66.2	129	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	4	48	42	0.846	-0.062	4.619	0.01	0.007	0	42.1	40.4	70.5	132	127	0	34	33
2014	7	4	4	58	42	0.853	-0.108	4.623	0.01	0.007	0	41.7	40	70.5	131	126	0	34	33
2014	7	4	5	8	42	0.82	-0.049	4.623	0.01	0.007	0	41.7	40	70.1	131	126	0	34	33
2014	7	4	5	18	42	0.863	-0.075	4.626	0.01	0.007	0	41.3	39.6	71	131	126	0	35	34
2014	7	4	5	28	42	0.86	-0.089	4.626	0.013	0.01	0	42.6	40.4	70.5	133	127	0	34	33
2014	7	4	5	38	42	0.866	-0.079	4.626	0.01	0.007	0	41.3	39.6	71.4	131	126	0	35	34
2014	7	4	5	48	42	0.827	-0.049	4.626	0.01	0.007	0	42.1	39.6	71	132	126	0	34	34
2014	7	4	5	58	42	0.85	-0.089	4.629	0.01	0.007	0	40.9	39.6	71.8	130	125	0	35	33
2014	7	4	6	8	42	0.86	-0.115	4.629	0.01	0.007	0	41.3	40	71.4	131	126	0	35	33
2014	7	4	6	18	42	0.84	-0.092	4.629	0.01	0.007	0	40.4	39.1	72.2	129	124	0	35	33
2014	7	4	6	28	42	0.896	-0.102	4.629	0.01	0.007	0	40.9	38.7	72.2	129	124	0	34	34
2014	7	4	6	38	42	0.876	-0.066	4.629	0.01	0.007	0	41.3	39.6	72.7	130	125	0	34	33
2014	7	4	6	48	42	0.869	-0.052	4.629	0.013	0.01	0	41.3	39.6	72.2	131	125	0	35	33
2014	7	4	6	58	42	0.83	-0.085	4.629	0.01	0.007	0	41.7	40	72.2	131	126	0	34	33
2014	7	4	7	8	42	0.853	-0.066	4.629	0.01	0.007	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	4	7	18	42	0.85	-0.039	4.629	0.01	0.007	0	40.9	40	72.7	130	125	0	35	32
2014	7	4	7	28	42	0.833	-0.118	4.629	0.01	0.007	0	41.7	40.4	72.2	131	127	0	34	33
2014	7	4	7	38	42	0.85	-0.092	4.629	0.01	0.007	0	41.7	40	72.2	131	126	0	34	33
2014	7	4	7	48	42	0.84	-0.052	4.629	0.013	0.01	0	41.7	40.4	72.7	132	127	0	35	33
2014	7	4	7	58	42	0.856	-0.079	4.629	0.013	0.01	0	41.7	40.4	72.7	132	127	0	35	33
2014	7	4	8	8	42	0.85	-0.082	4.629	0.01	0.007	0	42.1	40.4	72.2	132	127	0	34	33
2014	7	4	8	18	42	0.866	-0.121	4.629	0.01	0.007	0	41.3	40	72.7	131	126	0	35	33
2014	7	4	8	28	42	0.866	-0.089	4.629	0.01	0.007	0	42.6	40.9	72.2	133	129	0	34	34
2014	7	4	8	38	42	0.866	-0.089	4.629	0.013	0.01	0	42.1	40.4	71.4	133	128	0	35	34
2014	7	4	8	48	42	0.833	-0.098	4.629	0.01	0.007	0	41.7	39.6	72.2	131	126	0	34	34
2014	7	4	8	58	42	0.866	-0.112	4.626	0.01	0.007	0	41.7	40.4	67.1	131	127	0	34	33
2014	7	4	9	8	42	0.883	-0.098	4.626	0.01	0.007	0	41.3	40	67.9	131	126	0	35	33
2014	7	4	9	18	42	0.876	-0.128	4.626	0.01	0.007	0	41.3	39.1	65.4	130	125	0	34	34
2014	7	4	9	28	42	0.86	-0.148	4.626	0.01	0.007	0	40.9	39.1	65.8	130	125	0	35	34
2014	7	4	9	38	42	0.86	-0.138	4.623	0.01	0.007	0	41.7	39.1	58.5	130	125	0	33	34
2014	7	4	9	48	42	0.866	-0.112	4.623	0.013	0.01	0	41.3	39.6	56.8	130	125	0	34	33
2014	7	4	9	58	42	0.883	-0.138	4.623	0.01	0.007	0	41.3	39.6	54.2	130	125	0	34	33
2014	7	4	10	8	42	0.883	-0.115	4.623	0.01	0.007	0	41.3	40	53.8	130	126	0	34	33
2014	7	4	10	18	42	0.886	-0.079	4.623	0.01	0.007	0	41.7	39.6	55	131	126	0	34	34
2014	7	4	10	28	42	0.886	-0.102	4.623	0.01	0.007	0	41.3	39.6	55	131	126	0	35	34
2014	7	4	10	38	42	0.883	-0.154	4.623	0.013	0.01	0	40.9	39.6	52.5	130	125	0	35	33
2014	7	4	10	48	42	0.866	-0.115	4.623	0.01	0.007	0	40.9	39.6	54.2	129	125	0	34	33
2014	7	4	10	58	42	0.856	-0.144	4.619	0.01	0.007	0	40.9	39.1	52.5	129	124	0	34	33
2014	7	4	11	8	42	0.883	-0.144	4.619	0.01	0.007	0	40.9	39.6	52.5	129	125	0	34	33
2014	7	4	11	18	42	0.86	-0.171	4.616	0.01	0.007	0	40.4	39.1	56.8	129	124	0	35	33
2014	7	4	11	28	42	0.86	-0.161	4.616	0.01	0.007	0	40.9	39.1	53.3	129	124	0	34	33
2014	7	4	11	38	42	0.876	-0.138	4.619	0.01	0.007	0	42.1	40	42.6	132	127	0	34	34
2014	7	4	11	48	42	0.853	-0.154	4.616	0.013	0.01	0	41.3	39.6	50.3	130	125	0	34	33
2014	7	4	11	58	42	0.873	-0.118	4.616	0.01	0.007	0	46.4	44.3	35.7	143	136	0	35	33
2014	7	4	12	8	42	0.856	-0.079	4.616	0.013	0.01	0	47.3	45.2	37.4	145	139	0	35	34
2014	7	4	12	18	42	0.883	-0.138	4.616	0.01	0.007	0	42.6	40	50.7	133	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	12	28	42	0.889	-0.128	4.619	0.01	0.007	0	43	40.9	49.9	135	129	0	35	34
2014	7	4	12	38	42	0.876	-0.144	4.616	0.01	0.007	0	42.1	40.4	46	133	128	0	35	34
2014	7	4	12	48	42	0.892	-0.138	4.616	0.01	0.007	0	41.3	39.1	46	130	124	0	34	33
2014	7	4	12	58	42	0.863	-0.151	4.61	0.01	0.007	0	41.7	39.6	52	131	125	0	34	33
2014	7	4	13	8	42	0.869	-0.171	4.613	0.01	0.007	0	41.7	39.6	47.7	131	126	0	34	34
2014	7	4	13	18	42	0.879	-0.098	4.61	0.01	0.007	0	49.5	48.2	39.6	149	145	0	34	33
2014	7	4	13	28	42	0.879	-0.135	4.616	0.01	0.007	0	45.6	44.7	42.6	140	137	0	34	33
2014	7	4	13	38	42	0.823	-0.135	4.61	0.01	0.007	0	43.4	40.9	43	136	128	0	35	33
2014	7	4	13	48	42	0.886	-0.085	4.606	0.01	0.007	0	48.6	46	39.1	147	141	0	34	34
2014	7	4	13	58	42	0.869	-0.115	4.613	0.01	0.007	0	45.6	43.4	44.3	140	134	0	34	33
2014	7	4	14	8	42	0.883	-0.082	4.606	0.01	0.007	0	43	41.7	42.6	135	130	0	35	33
2014	7	4	14	18	42	0.883	-0.128	4.613	0.01	0.007	0	45.2	43	43	139	133	0	34	33
2014	7	4	14	28	42	0.846	-0.157	4.61	0.01	0.007	0	45.2	42.6	43.9	139	132	0	34	33
2014	7	4	14	38	42	0.869	-0.102	4.61	0.013	0.01	0	46.9	45.2	38.3	143	139	0	34	34
2014	7	4	14	48	42	0.85	-0.177	4.61	0.013	0.01	0	46	40.9	43.4	141	128	0	34	33
2014	7	4	14	58	42	0.873	-0.135	4.61	0.01	0.007	0	44.3	40.9	46.4	137	129	0	34	34
2014	7	4	15	8	42	0.827	-0.177	4.61	0.01	0.007	0	45.2	43	45.2	139	133	0	34	33
2014	7	4	15	18	42	0.843	-0.089	4.613	0.013	0.01	0	49	46	39.1	148	141	0	34	34
2014	7	4	15	28	42	0.866	-0.098	4.61	0.01	0.007	0	43.9	40	43.4	136	127	0	34	34
2014	7	4	15	38	42	0.909	-0.079	4.606	0.01	0.007	0	45.6	43	41.3	141	133	0	35	33
2014	7	4	15	48	42	0.86	-0.105	4.603	0.01	0.007	0	46	42.6	43	141	133	0	34	34
2014	7	4	15	58	42	0.889	-0.157	4.606	0.01	0.007	0	41.7	39.6	53.3	131	125	0	34	33
2014	7	4	16	8	42	0.919	-0.085	4.6	0.01	0.007	0	48.6	45.6	38.7	147	139	0	34	33
2014	7	4	16	18	42	0.869	-0.144	4.606	0.01	0.007	0	43	40.4	54.2	134	127	0	34	33
2014	7	4	16	28	42	0.843	-0.131	4.603	0.01	0.007	0	44.3	41.7	50.7	137	130	0	34	33
2014	7	4	16	38	42	0.846	-0.144	4.606	0.01	0.007	0	43.9	42.6	47.7	136	132	0	34	33
2014	7	4	16	48	42	0.899	-0.105	4.603	0.01	0.007	0	42.6	40.9	41.3	134	127	0	35	32
2014	7	4	16	58	42	0.896	-0.141	4.603	0.01	0.007	0	40.4	38.7	57.2	129	123	0	35	33
2014	7	4	17	8	42	0.883	-0.128	4.606	0.01	0.007	0	40.9	38.7	58	129	122	0	34	32
2014	7	4	17	18	42	0.899	-0.095	4.6	0.013	0.01	0	43	40.4	47.7	135	127	0	35	33
2014	7	4	17	28	42	0.86	-0.105	4.603	0.01	0.007	0	41.3	39.1	53.3	131	124	0	35	33
2014	7	4	17	38	42	0.899	-0.079	4.6	0.01	0.007	0	42.6	40	47.7	133	126	0	34	33
2014	7	4	17	48	42	0.85	-0.115	4.606	0.013	0.01	0	40.9	38.3	61.1	129	123	0	34	34
2014	7	4	17	58	42	0.856	-0.121	4.603	0.01	0.007	0	41.3	38.7	63.6	129	123	0	33	33
2014	7	4	18	8	42	0.886	-0.125	4.603	0.01	0.007	0	40.9	39.1	49.9	130	124	0	35	33
2014	7	4	18	18	42	0.85	-0.072	4.603	0.013	0.01	0	49	46.4	37.4	148	141	0	34	33
2014	7	4	18	28	42	0.886	-0.112	4.6	0.016	0.013	0	43.9	41.3	44.7	136	129	0	34	33
2014	7	4	18	38	42	0.869	-0.118	4.603	0.01	0.007	0	41.3	39.1	65.8	130	124	0	34	33
2014	7	4	18	48	42	0.869	-0.102	4.606	0.013	0.01	0	41.3	39.1	55.5	130	124	0	34	33
2014	7	4	18	58	42	0.863	-0.131	4.606	0.01	0.007	0	41.3	39.1	71	130	124	0	34	33
2014	7	4	19	8	42	0.892	-0.138	4.603	0.01	0.007	0	41.3	38.7	61.1	130	124	0	34	34
2014	7	4	19	18	42	0.879	-0.062	4.6	0.01	0.007	0	41.7	39.1	40.4	131	124	0	34	33
2014	7	4	19	28	42	0.883	-0.089	4.603	0.01	0.007	0	43.9	39.1	39.6	136	124	0	34	33
2014	7	4	19	38	42	0.85	-0.144	4.606	0.01	0.007	0	41.3	39.6	73.1	130	124	0	34	32
2014	7	4	19	48	42	0.866	-0.112	4.606	0.01	0.007	0	41.7	39.1	49.5	130	124	0	33	33
2014	7	4	19	58	42	0.873	-0.128	4.603	0.01	0.007	0	43.4	41.3	49	135	129	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	20	8	42	0.869	-0.118	4.606	0.01	0.007	0	41.3	39.6	56.3	130	125	0	34	33
2014	7	4	20	18	42	0.866	-0.082	4.603	0.01	0.007	0	41.7	40	58.9	131	125	0	34	32
2014	7	4	20	28	42	0.873	-0.072	4.606	0.01	0.007	0	42.1	40	66.7	133	126	0	35	33
2014	7	4	20	38	42	0.876	-0.098	4.606	0.01	0.007	0	42.1	40	57.6	132	126	0	34	33
2014	7	4	20	48	42	0.873	-0.098	4.606	0.01	0.007	0	42.6	40.4	70.1	133	127	0	34	33
2014	7	4	20	58	42	0.86	-0.075	4.606	0.01	0.007	0	43	40.4	72.2	133	127	0	33	33
2014	7	4	21	8	42	0.853	-0.059	4.606	0.01	0.007	0	42.1	40.9	73.1	133	128	0	35	33
2014	7	4	21	18	42	0.879	-0.085	4.606	0.01	0.007	0	42.6	40.4	74	133	127	0	34	33
2014	7	4	21	28	42	0.853	-0.082	4.606	0.01	0.007	0	43	40.9	75.3	134	128	0	34	33
2014	7	4	21	38	42	0.869	-0.085	4.606	0.01	0.007	0	42.6	40.4	74.8	133	127	0	34	33
2014	7	4	21	48	42	0.869	-0.069	4.61	0.01	0.007	0	42.1	40	75.3	132	126	0	34	33
2014	7	4	21	58	42	0.86	-0.089	4.606	0.01	0.007	0	41.7	39.6	66.2	131	125	0	34	33
2014	7	4	22	8	42	0.873	-0.089	4.61	0.01	0.007	0	42.1	39.6	74.8	132	125	0	34	33
2014	7	4	22	18	42	0.853	-0.052	4.606	0.01	0.007	0	42.1	40	74.8	132	126	0	34	33
2014	7	4	22	28	42	0.846	-0.075	4.61	0.01	0.007	0	42.6	40	74.8	133	126	0	34	33
2014	7	4	22	38	42	0.86	-0.089	4.61	0.013	0.01	0	42.1	40.4	69.2	132	126	0	34	32
2014	7	4	22	48	42	0.846	-0.075	4.61	0.01	0.007	0	42.1	40	74.8	132	126	0	34	33
2014	7	4	22	58	42	0.866	-0.082	4.61	0.01	0.007	0	41.7	40	75.3	131	126	0	34	33
2014	7	4	23	8	42	0.869	-0.092	4.61	0.01	0.007	0	42.1	39.6	75.3	132	125	0	34	33
2014	7	4	23	18	42	0.853	-0.059	4.61	0.01	0.007	0	41.7	39.6	75.3	131	125	0	34	33
2014	7	4	23	28	42	0.883	-0.089	4.61	0.01	0.007	0	40.9	39.1	75.3	130	124	0	35	33
2014	7	4	23	38	42	0.869	-0.075	4.61	0.01	0.007	0	42.1	40	75.3	132	126	0	34	33
2014	7	4	23	48	42	0.879	-0.075	4.61	0.01	0.007	0	42.1	40.4	74.4	132	126	0	34	32
2014	7	4	23	58	42	0.85	-0.082	4.61	0.01	0.007	0	42.1	40	75.3	132	126	0	34	33
2014	7	5	0	8	42	0.909	-0.072	4.61	0.01	0.007	0	41.7	39.6	72.7	132	125	0	35	33
2014	7	5	0	18	42	0.856	-0.082	4.61	0.01	0.007	0	41.7	40	74.4	132	126	0	35	33
2014	7	5	0	28	42	0.84	-0.082	4.61	0.01	0.007	0	42.1	40	73.5	132	126	0	34	33
2014	7	5	0	38	42	0.843	-0.052	4.61	0.01	0.007	0	42.1	40	70.1	133	126	0	35	33
2014	7	5	0	48	42	0.866	-0.066	4.61	0.01	0.007	0	42.1	40.4	74.8	133	127	0	35	33
2014	7	5	0	58	42	0.843	-0.085	4.61	0.01	0.007	0	42.1	39.6	74.4	132	125	0	34	33
2014	7	5	1	8	42	0.876	-0.056	4.61	0.01	0.007	0	41.3	39.1	74.8	131	125	0	35	34
2014	7	5	1	18	42	0.856	-0.072	4.61	0.016	0.013	0	41.3	39.6	74.4	131	125	0	35	33
2014	7	5	1	28	42	0.86	-0.066	4.61	0.01	0.007	0	42.1	40	74.8	132	126	0	34	33
2014	7	5	1	38	42	0.82	-0.075	4.61	0.01	0.007	0	42.6	40	73.5	132	126	0	33	33
2014	7	5	1	48	42	0.846	-0.059	4.61	0.01	0.007	0	42.6	40.4	66.2	133	127	0	34	33
2014	7	5	1	58	42	0.827	-0.089	4.61	0.01	0.007	0	42.1	40	74	132	126	0	34	33
2014	7	5	2	8	42	0.856	-0.072	4.61	0.01	0.007	0	42.6	40	72.7	133	126	0	34	33
2014	7	5	2	18	42	0.856	-0.066	4.61	0.013	0.01	0	42.6	40.4	74.4	133	127	0	34	33
2014	7	5	2	28	42	0.817	-0.066	4.61	0.01	0.007	0	42.1	40	74	132	126	0	34	33
2014	7	5	2	38	42	0.856	-0.072	4.61	0.01	0.007	0	42.6	40.4	69.2	133	127	0	34	33
2014	7	5	2	48	42	0.843	-0.066	4.613	0.01	0.007	0	43	40.4	73.5	133	128	0	33	34
2014	7	5	2	58	42	0.86	-0.069	4.61	0.01	0.007	0	42.6	40.4	70.1	133	127	0	34	33
2014	7	5	3	8	42	0.879	-0.085	4.61	0.01	0.007	0	41.7	39.6	73.5	132	126	0	35	34
2014	7	5	3	18	42	0.83	-0.059	4.613	0.01	0.007	0	43	40.9	72.7	134	128	0	34	33
2014	7	5	3	28	42	0.856	-0.092	4.613	0.01	0.007	0	43.4	40.9	73.1	134	128	0	33	33
2014	7	5	3	38	42	0.827	-0.056	4.613	0.01	0.007	0	42.6	40.4	73.5	133	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	3	48	42	0.853	-0.098	4.613	0.01	0.007	0	43	40.9	73.1	134	128	0	34	33
2014	7	5	3	58	42	0.85	-0.079	4.613	0.01	0.007	0	42.1	40.9	72.7	133	127	0	35	32
2014	7	5	4	8	42	0.873	-0.089	4.613	0.013	0.01	0	41.7	40	72.2	132	126	0	35	33
2014	7	5	4	18	42	0.843	-0.062	4.613	0.01	0.007	0	42.1	40.4	72.2	133	127	0	35	33
2014	7	5	4	28	42	0.879	-0.092	4.613	0.01	0.007	0	42.6	40.4	72.2	133	127	0	34	33
2014	7	5	4	38	42	0.837	-0.082	4.613	0.01	0.007	0	43.4	41.3	67.1	135	129	0	34	33
2014	7	5	4	48	42	0.86	-0.072	4.613	0.01	0.007	0	43	40.4	72.2	134	127	0	34	33
2014	7	5	4	58	42	0.869	-0.075	4.613	0.01	0.007	0	42.6	40.9	71.8	133	128	0	34	33
2014	7	5	5	8	42	0.86	-0.089	4.613	0.016	0.013	0	43	40.9	72.2	134	128	0	34	33
2014	7	5	5	18	42	0.85	-0.098	4.613	0.01	0.007	0	42.1	40	72.2	132	126	0	34	33
2014	7	5	5	28	42	0.856	-0.059	4.613	0.01	0.007	0	43	40.9	71.8	134	128	0	34	33
2014	7	5	5	38	42	0.876	-0.082	4.613	0.01	0.007	0	43	40.9	72.2	134	128	0	34	33
2014	7	5	5	48	42	0.846	-0.069	4.613	0.01	0.007	0	42.1	40.4	71.8	132	126	0	34	32
2014	7	5	5	58	42	0.856	-0.098	4.613	0.01	0.007	0	42.1	40.4	71.4	133	127	0	35	33
2014	7	5	6	8	42	0.853	-0.092	4.613	0.013	0.01	0	41.7	40	71.8	131	125	0	34	32
2014	7	5	6	18	42	0.856	-0.092	4.613	0.01	0.007	0	40.9	39.1	71.8	130	124	0	35	33
2014	7	5	6	28	42	0.866	-0.072	4.613	0.01	0.007	0	41.7	40	71.8	131	126	0	34	33
2014	7	5	6	38	42	0.853	-0.082	4.616	0.013	0.01	0	41.3	39.1	71.8	130	124	0	34	33
2014	7	5	6	48	42	0.85	-0.079	4.616	0.01	0.007	0	41.3	39.6	71.4	131	125	0	35	33
2014	7	5	6	58	42	0.843	-0.049	4.616	0.01	0.007	0	42.1	40	71	132	126	0	34	33
2014	7	5	7	8	42	0.856	-0.069	4.616	0.01	0.007	0	41.7	39.6	71	131	125	0	34	33
2014	7	5	7	18	42	0.833	-0.072	4.616	0.01	0.007	0	41.3	39.6	71.4	131	125	0	35	33
2014	7	5	7	28	42	0.85	-0.089	4.616	0.01	0.007	0	41.3	39.6	71	130	125	0	34	33
2014	7	5	7	38	42	0.869	-0.079	4.616	0.01	0.007	0	40.9	39.1	71.4	130	124	0	35	33
2014	7	5	7	48	42	0.83	-0.069	4.616	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	5	7	58	42	0.846	-0.082	4.616	0.01	0.007	0	41.3	39.1	70.5	130	124	0	34	33
2014	7	5	8	8	42	0.853	-0.082	4.616	0.01	0.007	0	40.9	38.7	71.8	129	124	0	34	34
2014	7	5	8	18	42	0.896	-0.085	4.613	0.01	0.007	0	41.3	39.1	71.4	130	125	0	34	34
2014	7	5	8	28	42	0.873	-0.059	4.613	0.013	0.01	0	41.3	38.7	72.2	130	124	0	34	34
2014	7	5	8	38	42	0.837	-0.082	4.616	0.01	0.007	0	40.4	38.3	72.2	129	123	0	35	34
2014	7	5	8	48	42	0.846	-0.075	4.613	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	5	8	58	42	0.863	-0.112	4.613	0.01	0.007	0	40.4	38.7	71.8	128	123	0	34	33
2014	7	5	9	8	42	0.876	-0.144	4.613	0.01	0.007	0	40.4	38.3	72.7	128	122	0	34	33
2014	7	5	9	18	42	0.896	-0.118	4.613	0.013	0.01	0	40	38.3	72.7	128	122	0	35	33
2014	7	5	9	28	42	0.889	-0.151	4.613	0.01	0.007	0	40.4	38.3	72.2	128	122	0	34	33
2014	7	5	9	38	42	0.84	-0.128	4.613	0.013	0.01	0	40.9	38.7	71.8	129	123	0	34	33
2014	7	5	9	48	42	0.873	-0.128	4.613	0.01	0.007	0	40.4	38.7	73.1	128	123	0	34	33
2014	7	5	9	58	42	0.883	-0.148	4.613	0.01	0.007	0	40.4	38.3	71.8	128	122	0	34	33
2014	7	5	10	8	42	0.886	-0.118	4.613	0.013	0.01	0	40.4	38.3	72.7	128	123	0	34	34
2014	7	5	10	18	42	0.869	-0.128	4.613	0.01	0.007	0	40.4	38.7	69.7	128	123	0	34	33
2014	7	5	10	28	42	0.886	-0.125	4.613	0.01	0.007	0	40	38.7	72.7	128	122	0	35	32
2014	7	5	10	38	42	0.873	-0.095	4.613	0.01	0.007	0	43	41.7	49.5	134	130	0	34	33
2014	7	5	10	48	42	0.866	-0.128	4.613	0.01	0.007	0	44.3	42.1	52.9	137	131	0	34	33
2014	7	5	10	58	42	0.873	-0.125	4.619	0.01	0.007	0	41.7	40	44.7	131	126	0	34	33
2014	7	5	11	8	42	0.889	-0.098	4.613	0.01	0.007	0	48.2	46	43	146	140	0	34	33
2014	7	5	11	18	42	0.866	-0.128	4.616	0.01	0.007	0	41.3	39.1	50.3	130	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	11	28	42	0.873	-0.128	4.613	0.01	0.007	0	40.4	38.3	58	128	123	0	34	34
2014	7	5	11	38	42	0.82	-0.161	4.61	0.01	0.007	0	40.4	38.7	64.1	128	123	0	34	33
2014	7	5	11	48	42	0.833	-0.154	4.613	0.01	0.007	0	40	38.3	67.5	127	122	0	34	33
2014	7	5	11	58	42	0.837	-0.19	4.613	0.01	0.007	0	40	38.3	61.9	127	122	0	34	33
2014	7	5	12	8	42	0.846	-0.184	4.61	0.01	0.007	0	40	38.3	67.1	127	122	0	34	33
2014	7	5	12	18	42	0.853	-0.157	4.61	0.01	0.007	0	40	38.3	71	127	122	0	34	33
2014	7	5	12	28	42	0.856	-0.121	4.61	0.01	0.007	0	40	38.3	60.2	127	122	0	34	33
2014	7	5	12	38	42	0.85	-0.154	4.61	0.01	0.007	0	40.4	38.3	59.8	128	122	0	34	33
2014	7	5	12	48	42	0.876	-0.161	4.61	0.013	0.01	0	41.3	39.1	59.3	130	124	0	34	33
2014	7	5	12	58	42	0.846	-0.115	4.61	0.01	0.007	0	40.4	38.7	58.9	128	123	0	34	33
2014	7	5	13	8	42	0.86	-0.131	4.61	0.013	0.01	0	39.6	38.3	63.6	127	123	0	35	34
2014	7	5	13	18	42	0.886	-0.174	4.61	0.01	0.007	0	40	37.8	68.4	127	122	0	34	34
2014	7	5	13	28	42	0.853	-0.184	4.61	0.01	0.007	0	40	37.8	61.1	127	121	0	34	33
2014	7	5	13	38	42	0.876	-0.171	4.61	0.01	0.007	0	40	38.3	69.2	127	122	0	34	33
2014	7	5	13	48	42	0.889	-0.089	4.61	0.01	0.007	0	40.4	38.3	63.6	128	122	0	34	33
2014	7	5	13	58	42	0.85	-0.089	4.61	0.01	0.007	0	39.6	38.3	56.3	127	122	0	35	33
2014	7	5	14	8	42	0.833	-0.098	4.61	0.01	0.007	0	40	38.3	73.1	127	122	0	34	33
2014	7	5	14	18	42	0.85	-0.154	4.606	0.013	0.01	0	40	38.3	64.5	127	122	0	34	33
2014	7	5	14	28	42	0.866	-0.177	4.606	0.01	0.007	0	40	37.8	69.7	127	121	0	34	33
2014	7	5	14	38	42	0.876	-0.164	4.606	0.01	0.007	0	40.9	39.1	61.1	129	125	0	34	34
2014	7	5	14	48	42	0.863	-0.118	4.606	0.01	0.007	0	39.6	37.8	59.3	126	121	0	34	33
2014	7	5	14	58	42	0.883	-0.121	4.606	0.01	0.007	0	40	38.7	57.6	127	122	0	34	32
2014	7	5	15	8	42	0.86	-0.138	4.603	0.01	0.007	0	43.4	40.9	47.7	135	129	0	34	34
2014	7	5	15	18	42	0.869	-0.135	4.603	0.01	0.007	0	44.7	43	58.9	138	132	0	34	32
2014	7	5	15	28	42	0.85	-0.138	4.606	0.01	0.007	0	40	38.3	62.4	128	122	0	35	33
2014	7	5	15	38	42	0.856	-0.128	4.606	0.01	0.007	0	39.1	37.8	61.9	126	121	0	35	33
2014	7	5	15	48	42	0.846	-0.144	4.603	0.01	0.007	0	42.1	40.4	56.3	132	127	0	34	33
2014	7	5	15	58	42	0.856	-0.18	4.606	0.01	0.007	0	40	38.3	57.6	127	122	0	34	33
2014	7	5	16	8	42	0.84	-0.187	4.606	0.01	0.007	0	40.4	38.7	57.6	128	123	0	34	33
2014	7	5	16	18	42	0.886	-0.108	4.6	0.01	0.007	0	43	41.3	55.9	134	129	0	34	33
2014	7	5	16	28	42	0.879	-0.102	4.603	0.01	0.007	0	42.6	40.4	55.9	132	127	0	33	33
2014	7	5	16	38	42	0.869	-0.049	4.603	0.013	0.01	0	40.4	38.7	55.9	128	123	0	34	33
2014	7	5	16	48	42	0.86	-0.164	4.603	0.01	0.007	0	41.3	39.1	56.3	130	124	0	34	33
2014	7	5	16	58	42	0.876	-0.135	4.603	0.013	0.01	0	41.7	39.6	67.1	131	126	0	34	34
2014	7	5	17	8	42	0.846	-0.118	4.603	0.01	0.007	0	40.4	38.7	55.5	128	123	0	34	33
2014	7	5	17	18	42	0.896	-0.135	4.6	0.01	0.007	0	40.4	38.7	53.8	128	123	0	34	33
2014	7	5	17	28	42	0.863	-0.135	4.603	0.01	0.007	0	40.4	38.7	55.5	128	123	0	34	33
2014	7	5	17	38	42	0.863	-0.098	4.603	0.01	0.007	0	40	38.3	51.6	128	122	0	35	33
2014	7	5	17	48	42	0.846	-0.112	4.6	0.01	0.007	0	40.9	38.7	53.3	129	123	0	34	33
2014	7	5	17	58	42	0.846	-0.066	4.6	0.013	0.01	0	40.9	38.7	53.8	129	124	0	34	34
2014	7	5	18	8	42	0.863	-0.082	4.596	0.016	0.013	0	40.9	39.1	54.2	129	124	0	34	33
2014	7	5	18	18	42	0.853	-0.098	4.6	0.01	0.007	0	40.9	39.1	52.9	129	124	0	34	33
2014	7	5	18	28	42	0.86	-0.066	4.6	0.01	0.007	0	41.7	39.1	50.3	130	124	0	33	33
2014	7	5	18	38	42	0.886	-0.102	4.6	0.01	0.007	0	40.9	39.6	55	129	124	0	34	32
2014	7	5	18	48	42	0.886	-0.108	4.6	0.01	0.007	0	40.4	38.3	60.2	128	122	0	34	33
2014	7	5	18	58	42	0.873	-0.144	4.596	0.01	0.007	0	40.4	38.7	52	128	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	19	8	42	0.899	-0.089	4.6	0.01	0.007	0	40.9	39.1	55	129	124	0	34	33
2014	7	5	19	18	42	0.85	-0.089	4.6	0.01	0.007	0	42.1	40.4	55	132	127	0	34	33
2014	7	5	19	28	42	0.84	-0.072	4.6	0.01	0.007	0	42.6	40.9	54.6	133	127	0	34	32
2014	7	5	19	38	42	0.853	-0.157	4.6	0.01	0.007	0	41.3	39.1	52	130	124	0	34	33
2014	7	5	19	48	42	0.82	-0.092	4.603	0.01	0.007	0	42.6	40.9	50.3	133	128	0	34	33
2014	7	5	19	58	42	0.896	-0.082	4.6	0.01	0.007	0	42.6	40.4	49.5	133	128	0	34	34
2014	7	5	20	8	42	0.863	-0.075	4.6	0.01	0.007	0	42.6	40.9	50.3	133	128	0	34	33
2014	7	5	20	18	42	0.883	-0.043	4.6	0.01	0.007	0	41.7	40	52.5	131	126	0	34	33
2014	7	5	20	28	42	0.879	-0.069	4.6	0.01	0.007	0	42.6	40	51.6	132	126	0	33	33
2014	7	5	20	38	42	0.866	-0.089	4.6	0.01	0.007	0	42.1	39.6	54.2	132	126	0	34	34
2014	7	5	20	48	42	0.863	-0.079	4.603	0.01	0.007	0	42.1	40.4	52.9	132	126	0	34	32
2014	7	5	20	58	42	0.873	-0.079	4.603	0.01	0.007	0	41.7	39.6	55	131	125	0	34	33
2014	7	5	21	8	42	0.853	-0.102	4.603	0.016	0.013	0	41.3	39.6	53.3	131	126	0	35	34
2014	7	5	21	18	42	0.863	-0.072	4.603	0.01	0.007	0	41.3	39.1	55	130	124	0	34	33
2014	7	5	21	28	42	0.837	-0.069	4.603	0.01	0.007	0	42.1	40	61.1	131	126	0	33	33
2014	7	5	21	38	42	0.883	-0.082	4.603	0.01	0.007	0	41.3	39.1	58.9	130	124	0	34	33
2014	7	5	21	48	42	0.846	-0.066	4.603	0.01	0.007	0	41.3	39.6	69.2	130	125	0	34	33
2014	7	5	21	58	42	0.886	-0.102	4.603	0.01	0.007	0	41.3	39.1	58	130	124	0	34	33
2014	7	5	22	8	42	0.866	-0.066	4.603	0.01	0.007	0	41.3	39.1	66.2	130	124	0	34	33
2014	7	5	22	18	42	0.86	-0.102	4.603	0.01	0.007	0	40.4	38.7	57.2	128	123	0	34	33
2014	7	5	22	28	42	0.863	-0.125	4.603	0.01	0.007	0	40	38.3	71.4	127	122	0	34	33
2014	7	5	22	38	42	0.853	-0.059	4.603	0.01	0.007	0	41.3	39.6	71.8	130	124	0	34	32
2014	7	5	22	48	42	0.866	-0.079	4.603	0.01	0.007	0	41.7	39.6	71.4	131	125	0	34	33
2014	7	5	22	58	42	0.86	-0.052	4.606	0.01	0.007	0	41.3	39.6	73.5	130	125	0	34	33
2014	7	5	23	8	42	0.856	-0.095	4.606	0.013	0.01	0	41.3	39.1	74.4	130	124	0	34	33
2014	7	5	23	18	42	0.843	-0.066	4.606	0.01	0.007	0	41.3	40	74.4	130	125	0	34	32
2014	7	5	23	28	42	0.879	-0.066	4.606	0.01	0.007	0	40.9	39.1	74	129	124	0	34	33
2014	7	5	23	38	42	0.84	-0.082	4.606	0.01	0.007	0	40.9	39.6	74.4	129	124	0	34	32
2014	7	5	23	48	42	0.833	-0.062	4.606	0.01	0.007	0	41.3	39.6	74.4	130	125	0	34	33
2014	7	5	23	58	42	0.876	-0.085	4.606	0.01	0.007	0	41.3	39.6	74.4	130	125	0	34	33
2014	7	6	0	8	42	0.86	-0.059	4.606	0.01	0.007	0	40.4	39.1	74.4	129	124	0	35	33
2014	7	6	0	18	42	0.85	-0.082	4.606	0.01	0.007	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	6	0	28	42	0.83	-0.072	4.606	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	6	0	38	42	0.84	-0.072	4.606	0.01	0.007	0	40.4	39.1	69.2	129	124	0	35	33
2014	7	6	0	48	42	0.869	-0.075	4.606	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33
2014	7	6	0	58	42	0.866	-0.069	4.606	0.01	0.007	0	41.3	39.6	74.8	130	124	0	34	32
2014	7	6	1	8	42	0.869	-0.092	4.606	0.01	0.007	0	40.9	39.1	71.4	129	124	0	34	33
2014	7	6	1	18	42	0.863	-0.066	4.606	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	6	1	28	42	0.863	-0.089	4.606	0.01	0.007	0	40.4	38.7	75.3	129	123	0	35	33
2014	7	6	1	38	42	0.876	-0.085	4.606	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	1	48	42	0.86	-0.079	4.606	0.01	0.007	0	41.3	38.7	75.3	129	124	0	33	34
2014	7	6	1	58	42	0.833	-0.089	4.606	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	2	8	42	0.873	-0.095	4.61	0.01	0.007	0	41.3	39.6	75.7	130	125	0	34	33
2014	7	6	2	18	42	0.856	-0.072	4.61	0.01	0.007	0	41.3	39.6	75.7	130	125	0	34	33
2014	7	6	2	28	42	0.863	-0.079	4.61	0.01	0.007	0	40.9	39.1	75.7	129	124	0	34	33
2014	7	6	2	38	42	0.869	-0.092	4.61	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	2	48	42	0.896	-0.075	4.61	0.01	0.007	0	41.3	39.6	75.3	130	125	0	34	33
2014	7	6	2	58	42	0.873	-0.056	4.61	0.01	0.007	0	41.3	40.4	75.7	130	126	0	34	32
2014	7	6	3	8	42	0.86	-0.079	4.61	0.01	0.007	0	41.3	40	65.8	130	125	0	34	32
2014	7	6	3	18	42	0.869	-0.059	4.61	0.01	0.007	0	41.3	39.6	75.7	131	125	0	35	33
2014	7	6	3	28	42	0.86	-0.085	4.61	0.01	0.007	0	42.6	40.9	74.4	133	127	0	34	32
2014	7	6	3	38	42	0.82	-0.082	4.61	0.01	0.007	0	43.4	41.7	67.5	135	129	0	34	32
2014	7	6	3	48	42	0.886	-0.092	4.61	0.013	0.01	0	42.6	40.9	71.4	133	127	0	34	32
2014	7	6	3	58	42	0.863	-0.069	4.61	0.01	0.007	0	42.1	40	75.7	132	126	0	34	33
2014	7	6	4	8	42	0.869	-0.085	4.61	0.01	0.007	0	42.1	40	75.3	131	126	0	33	33
2014	7	6	4	18	42	0.883	-0.089	4.61	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	6	4	28	42	0.863	-0.072	4.61	0.01	0.007	0	41.7	40	74.4	131	126	0	34	33
2014	7	6	4	38	42	0.866	-0.082	4.61	0.01	0.007	0	42.1	40.4	74.4	132	127	0	34	33
2014	7	6	4	48	42	0.843	-0.075	4.61	0.013	0.01	0	41.7	40	74.8	131	126	0	34	33
2014	7	6	4	58	42	0.863	-0.112	4.61	0.01	0.007	0	41.7	40	75.3	131	126	0	34	33
2014	7	6	5	8	42	0.833	-0.079	4.61	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	5	18	42	0.873	-0.056	4.61	0.013	0.01	0	42.1	40.4	73.5	132	127	0	34	33
2014	7	6	5	28	42	0.82	-0.052	4.61	0.01	0.007	0	43	40.9	74.4	134	128	0	34	33
2014	7	6	5	38	42	0.873	-0.056	4.61	0.01	0.007	0	42.1	40.9	75.3	132	127	0	34	32
2014	7	6	5	48	42	0.843	-0.043	4.61	0.016	0.013	0	41.7	39.6	74.4	131	126	0	34	34
2014	7	6	5	58	42	0.85	-0.072	4.61	0.01	0.007	0	41.7	40	74.4	131	126	0	34	33
2014	7	6	6	8	42	0.853	-0.108	4.61	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	6	18	42	0.84	-0.105	4.61	0.01	0.007	0	40.4	39.1	74	129	124	0	35	33
2014	7	6	6	28	42	0.83	-0.082	4.61	0.01	0.007	0	41.7	39.6	74.8	131	126	0	34	34
2014	7	6	6	38	42	0.86	-0.085	4.613	0.016	0.013	0	40.4	39.1	74.4	129	124	0	35	33
2014	7	6	6	48	42	0.86	-0.075	4.613	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	6	58	42	0.863	-0.085	4.613	0.01	0.007	0	40.9	38.7	74.8	129	123	0	34	33
2014	7	6	7	8	42	0.863	-0.066	4.61	0.01	0.007	0	40.4	38.7	75.3	128	123	0	34	33
2014	7	6	7	18	42	0.879	-0.085	4.613	0.01	0.007	0	40	38.3	74.8	127	122	0	34	33
2014	7	6	7	28	42	0.85	-0.079	4.613	0.01	0.007	0	40.4	38.3	74.8	128	122	0	34	33
2014	7	6	7	38	42	0.892	-0.085	4.613	0.01	0.007	0	40.4	38.7	74.4	128	123	0	34	33
2014	7	6	7	48	42	0.846	-0.102	4.613	0.01	0.007	0	40.4	38.3	74.4	128	123	0	34	34
2014	7	6	7	58	42	0.86	-0.092	4.613	0.01	0.007	0	40.4	38.7	70.5	128	123	0	34	33
2014	7	6	8	8	42	0.843	-0.075	4.613	0.01	0.007	0	40.4	38.7	74.8	128	123	0	34	33
2014	7	6	8	18	42	0.843	-0.049	4.613	0.01	0.007	0	39.6	38.3	74.4	127	122	0	35	33
2014	7	6	8	28	42	0.846	-0.125	4.613	0.01	0.007	0	40.4	37.8	72.7	127	122	0	33	34
2014	7	6	8	38	42	0.869	-0.118	4.613	0.01	0.007	0	40	37.4	74.8	127	121	0	34	34
2014	7	6	8	48	42	0.876	-0.085	4.613	0.01	0.007	0	40.4	39.1	75.3	128	123	0	34	32
2014	7	6	8	58	42	0.84	-0.121	4.613	0.013	0.01	0	40.4	38.7	74.4	128	123	0	34	33
2014	7	6	9	8	42	0.856	-0.072	4.613	0.01	0.007	0	40.4	38.7	75.7	128	123	0	34	33
2014	7	6	9	18	42	0.853	-0.108	4.613	0.01	0.007	0	40.4	38.3	74.4	128	123	0	34	34
2014	7	6	9	28	42	0.86	-0.075	4.613	0.01	0.007	0	40.4	38.3	74.8	128	123	0	34	34
2014	7	6	9	38	42	0.86	-0.115	4.613	0.01	0.007	0	40.9	38.7	75.3	129	123	0	34	33
2014	7	6	9	48	42	0.869	-0.066	4.613	0.01	0.007	0	40.9	38.7	75.3	129	124	0	34	34
2014	7	6	9	58	42	0.892	-0.079	4.613	0.013	0.01	0	40.4	38.7	75.3	128	124	0	34	34
2014	7	6	10	8	42	0.85	-0.095	4.613	0.01	0.007	0	40.4	39.1	75.3	128	124	0	34	33
2014	7	6	10	18	42	0.863	-0.079	4.613	0.01	0.007	0	40	38.7	75.3	128	123	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	10	28	42	0.863	-0.128	4.613	0.01	0.007	0	40.4	39.1	75.7	128	123	0	34	32
2014	7	6	10	38	42	0.876	-0.098	4.613	0.01	0.007	0	40.4	39.1	75.7	128	124	0	34	33
2014	7	6	10	48	42	0.863	-0.079	4.613	0.01	0.007	0	40.4	39.1	75.7	128	123	0	34	32
2014	7	6	10	58	42	0.863	-0.128	4.613	0.01	0.007	0	40	38.3	75.7	127	122	0	34	33
2014	7	6	11	8	42	0.846	-0.135	4.61	0.01	0.007	0	39.6	38.3	75.7	127	122	0	35	33
2014	7	6	11	18	42	0.876	-0.141	4.61	0.01	0.007	0	40	38.3	75.3	127	122	0	34	33
2014	7	6	11	28	42	0.879	-0.161	4.61	0.01	0.007	0	39.6	38.3	74	127	122	0	35	33
2014	7	6	11	38	42	0.892	-0.135	4.613	0.01	0.007	0	40	38.7	75.3	127	123	0	34	33
2014	7	6	11	48	42	0.876	-0.115	4.61	0.013	0.01	0	40	38.3	75.3	127	122	0	34	33
2014	7	6	11	58	42	0.886	-0.108	4.61	0.01	0.007	0	40.4	38.7	69.2	128	123	0	34	33
2014	7	6	12	8	42	0.84	-0.121	4.61	0.01	0.007	0	40	39.1	75.3	127	123	0	34	32
2014	7	6	12	18	42	0.869	-0.135	4.613	0.01	0.007	0	40.9	38.7	75.7	128	123	0	33	33
2014	7	6	12	28	42	0.876	-0.174	4.61	0.01	0.007	0	40	38.3	76.1	127	122	0	34	33
2014	7	6	12	38	42	0.879	-0.115	4.613	0.016	0.013	0	40	38.3	61.1	127	122	0	34	33
2014	7	6	12	48	42	0.879	-0.115	4.613	0.01	0.007	0	40.4	38.3	73.5	127	122	0	33	33
2014	7	6	12	58	42	0.876	-0.082	4.613	0.01	0.007	0	40	38.3	68.8	127	122	0	34	33
2014	7	6	13	8	42	0.85	-0.161	4.61	0.01	0.007	0	39.6	37.8	73.5	126	121	0	34	33
2014	7	6	13	18	42	0.86	-0.118	4.613	0.01	0.007	0	40	38.3	75.3	127	122	0	34	33
2014	7	6	13	28	42	0.833	-0.105	4.61	0.01	0.007	0	40	38.7	76.5	127	123	0	34	33
2014	7	6	13	38	42	0.869	-0.151	4.61	0.013	0.01	0	40.4	38.7	76.1	128	123	0	34	33
2014	7	6	13	48	42	0.853	-0.118	4.61	0.01	0.007	0	40	38.7	75.3	127	123	0	34	33
2014	7	6	13	58	42	0.883	-0.112	4.61	0.01	0.007	0	40	38.3	66.7	127	122	0	34	33
2014	7	6	14	8	42	0.863	-0.141	4.61	0.01	0.007	0	40	38.7	75.3	127	122	0	34	32
2014	7	6	14	18	42	0.866	-0.092	4.61	0.01	0.007	0	40.4	39.1	72.2	128	123	0	34	32
2014	7	6	14	28	42	0.843	-0.098	4.61	0.01	0.007	0	40	38.7	70.5	127	122	0	34	32
2014	7	6	14	38	42	0.833	-0.125	4.61	0.013	0.01	0	39.6	37.8	72.7	126	121	0	34	33
2014	7	6	14	48	42	0.846	-0.056	4.61	0.01	0.007	0	40	38.3	71.8	127	122	0	34	33
2014	7	6	14	58	42	0.879	-0.115	4.61	0.01	0.007	0	40	38.7	68.4	127	122	0	34	32
2014	7	6	15	8	42	0.837	-0.082	4.606	0.013	0.01	0	40.4	39.1	71.8	128	123	0	34	32
2014	7	6	15	18	42	0.873	-0.079	4.606	0.01	0.007	0	39.6	38.3	70.1	127	122	0	35	33
2014	7	6	15	28	42	0.886	-0.072	4.603	0.01	0.007	0	40.9	39.1	61.5	129	124	0	34	33
2014	7	6	15	38	42	0.866	-0.079	4.606	0.01	0.007	0	40	38.3	60.6	127	122	0	34	33
2014	7	6	15	48	42	0.883	-0.115	4.6	0.016	0.013	0	46	44.7	51.2	141	136	0	34	32
2014	7	6	15	58	42	0.915	-0.112	4.6	0.01	0.007	0	39.6	38.3	49.5	126	122	0	34	33
2014	7	6	16	8	42	0.866	-0.115	4.6	0.01	0.007	0	40	38.3	50.3	127	122	0	34	33
2014	7	6	16	18	42	0.883	-0.092	4.596	0.01	0.007	0	44.3	43	45.2	137	133	0	34	33
2014	7	6	16	28	42	0.883	-0.112	4.603	0.013	0.01	0	44.3	41.7	51.2	137	130	0	34	33
2014	7	6	16	38	42	0.856	-0.161	4.603	0.01	0.007	0	40.9	39.1	58.9	129	124	0	34	33
2014	7	6	16	48	42	0.86	-0.125	4.603	0.01	0.007	0	43.4	41.3	48.2	134	129	0	33	33
2014	7	6	16	58	42	0.853	-0.108	4.6	0.01	0.007	0	41.3	39.6	51.2	130	125	0	34	33
2014	7	6	17	8	42	0.883	-0.128	4.603	0.01	0.007	0	42.6	41.3	50.7	133	128	0	34	32
2014	7	6	17	18	42	0.879	-0.062	4.606	0.01	0.007	0	47.3	45.6	52	144	139	0	34	33
2014	7	6	17	28	42	0.876	-0.098	4.606	0.013	0.01	0	46.9	45.6	60.6	143	139	0	34	33
2014	7	6	17	38	42	0.863	-0.095	4.606	0.01	0.007	0	46	44.3	66.7	141	136	0	34	33
2014	7	6	17	48	42	0.886	-0.131	4.606	0.01	0.007	0	44.7	43	72.2	138	133	0	34	33
2014	7	6	17	58	42	0.883	-0.102	4.606	0.01	0.007	0	44.3	43	71.8	137	132	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	18	8	42	0.856	-0.112	4.61	0.01	0.007	0	43.9	42.1	72.2	136	131	0	34	33
2014	7	6	18	18	42	0.863	-0.062	4.61	0.01	0.007	0	43	41.3	74	134	129	0	34	33
2014	7	6	18	28	42	0.873	-0.066	4.61	0.013	0.01	0	42.1	41.3	74	132	128	0	34	32
2014	7	6	18	38	42	0.899	-0.052	4.61	0.01	0.007	0	41.7	40.4	74	131	127	0	34	33
2014	7	6	18	48	42	0.866	-0.092	4.61	0.01	0.007	0	41.7	40	74	131	126	0	34	33
2014	7	6	18	58	42	0.892	-0.075	4.61	0.01	0.007	0	41.3	39.6	74.4	130	125	0	34	33
2014	7	6	19	8	42	0.856	-0.066	4.61	0.01	0.007	0	41.7	40	74.8	131	126	0	34	33
2014	7	6	19	18	42	0.869	-0.098	4.61	0.01	0.007	0	41.3	40	74.8	130	126	0	34	33
2014	7	6	19	28	42	0.869	-0.085	4.61	0.01	0.007	0	41.3	40	74.8	130	126	0	34	33
2014	7	6	19	38	42	0.886	-0.056	4.61	0.01	0.007	0	41.3	40.4	74.8	130	126	0	34	32
2014	7	6	19	48	42	0.85	-0.046	4.61	0.01	0.007	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	19	58	42	0.856	-0.098	4.61	0.01	0.007	0	41.3	39.6	74.8	129	124	0	33	32
2014	7	6	20	8	42	0.85	-0.049	4.61	0.01	0.007	0	41.7	40.4	75.7	131	126	0	34	32
2014	7	6	20	18	42	0.853	-0.069	4.61	0.01	0.007	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	6	20	28	42	0.82	-0.095	4.606	0.01	0.007	0	42.1	40	52.9	132	127	0	34	34
2014	7	6	20	38	42	0.899	-0.082	4.61	0.01	0.007	0	41.3	39.6	61.5	130	126	0	34	34
2014	7	6	20	48	42	0.84	-0.066	4.61	0.01	0.007	0	41.3	39.6	67.9	130	125	0	34	33
2014	7	6	20	58	42	0.863	-0.072	4.61	0.01	0.007	0	41.3	39.6	70.5	130	125	0	34	33
2014	7	6	21	8	42	0.837	-0.075	4.613	0.013	0.01	0	40.4	38.7	72.7	128	123	0	34	33
2014	7	6	21	18	42	0.856	-0.079	4.613	0.01	0.007	0	40.9	39.6	75.3	129	125	0	34	33
2014	7	6	21	28	42	0.869	-0.066	4.613	0.01	0.007	0	40.9	39.1	72.7	129	124	0	34	33
2014	7	6	21	38	42	0.883	-0.059	4.613	0.013	0.01	0	41.7	40.4	66.2	131	127	0	34	33
2014	7	6	21	48	42	0.863	-0.056	4.613	0.01	0.007	0	42.1	40.9	58	132	128	0	34	33
2014	7	6	21	58	42	0.86	-0.085	4.61	0.013	0.01	0	43	42.1	55.9	135	131	0	35	33
2014	7	6	22	8	42	0.853	-0.072	4.61	0.01	0.007	0	43.4	41.7	65.4	135	130	0	34	33
2014	7	6	22	18	42	0.869	-0.079	4.613	0.01	0.007	0	43	41.3	58.5	134	129	0	34	33
2014	7	6	22	28	42	0.883	-0.085	4.61	0.01	0.007	0	42.6	41.3	70.5	133	128	0	34	32
2014	7	6	22	38	42	0.886	-0.062	4.613	0.01	0.007	0	43	40.9	74	133	128	0	33	33
2014	7	6	22	48	42	0.84	-0.082	4.613	0.01	0.007	0	42.1	40.9	71.8	132	128	0	34	33
2014	7	6	22	58	42	0.843	-0.075	4.613	0.01	0.007	0	41.7	40.4	73.1	131	127	0	34	33
2014	7	6	23	8	42	0.837	-0.066	4.613	0.013	0.01	0	40.9	39.6	75.7	129	125	0	34	33
2014	7	6	23	18	42	0.837	-0.066	4.613	0.013	0.01	0	41.7	40	75.3	131	126	0	34	33
2014	7	6	23	28	42	0.83	-0.079	4.613	0.013	0.01	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	6	23	38	42	0.886	-0.092	4.613	0.01	0.007	0	41.3	39.6	73.5	129	125	0	33	33
2014	7	6	23	48	42	0.853	-0.079	4.613	0.01	0.007	0	40.9	39.6	75.7	129	125	0	34	33
2014	7	6	23	58	42	0.869	-0.095	4.613	0.01	0.007	0	40.4	39.6	69.2	129	125	0	35	33
2014	7	7	0	8	42	0.873	-0.082	4.613	0.01	0.007	0	40.9	39.6	64.9	129	125	0	34	33
2014	7	7	0	18	42	0.876	-0.092	4.613	0.01	0.007	0	40.9	39.1	69.7	129	124	0	34	33
2014	7	7	0	28	42	0.85	-0.098	4.616	0.01	0.007	0	42.1	40.4	60.6	132	127	0	34	33
2014	7	7	0	38	42	0.876	-0.069	4.613	0.01	0.007	0	42.1	40.9	68.4	132	128	0	34	33
2014	7	7	0	48	42	0.843	-0.082	4.616	0.01	0.007	0	42.1	41.3	74.4	133	129	0	35	33
2014	7	7	0	58	42	0.86	-0.066	4.616	0.01	0.007	0	42.1	40.4	75.3	132	127	0	34	33
2014	7	7	1	8	42	0.853	-0.062	4.613	0.013	0.01	0	41.3	39.6	75.7	131	126	0	35	34
2014	7	7	1	18	42	0.879	-0.095	4.616	0.01	0.007	0	40.4	39.1	74	128	124	0	34	33
2014	7	7	1	28	42	0.863	-0.056	4.616	0.01	0.007	0	41.3	40	74.8	130	126	0	34	33
2014	7	7	1	38	42	0.886	-0.131	4.616	0.01	0.007	0	40.4	39.1	63.2	128	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	1	48	42	0.846	-0.062	4.616	0.01	0.007	0	41.3	40	73.5	130	126	0	34	33
2014	7	7	1	58	42	0.883	-0.066	4.616	0.016	0.013	0	40.9	39.1	67.5	129	124	0	34	33
2014	7	7	2	8	42	0.876	-0.085	4.616	0.01	0.007	0	40.9	39.6	75.7	128	124	0	33	32
2014	7	7	2	18	42	0.879	-0.066	4.616	0.01	0.007	0	40.4	39.1	75.7	128	124	0	34	33
2014	7	7	2	28	42	0.827	-0.069	4.616	0.01	0.007	0	40.4	39.1	75.3	129	124	0	35	33
2014	7	7	2	38	42	0.853	-0.049	4.616	0.01	0.007	0	40.9	39.6	72.7	129	124	0	34	32
2014	7	7	2	48	42	0.853	-0.049	4.616	0.01	0.007	0	40.9	40	74.8	129	125	0	34	32
2014	7	7	2	58	42	0.863	-0.095	4.616	0.01	0.007	0	40.9	39.6	75.7	129	125	0	34	33
2014	7	7	3	8	42	0.886	-0.052	4.616	0.01	0.007	0	40.9	39.1	75.7	128	124	0	33	33
2014	7	7	3	18	42	0.886	-0.089	4.616	0.01	0.007	0	40.9	39.6	75.3	129	125	0	34	33
2014	7	7	3	28	42	0.866	-0.069	4.616	0.013	0.01	0	41.3	39.6	75.3	129	125	0	33	33
2014	7	7	3	38	42	0.85	-0.085	4.616	0.013	0.01	0	40.4	39.1	74	128	124	0	34	33
2014	7	7	3	48	42	0.883	-0.092	4.616	0.01	0.007	0	40.9	39.1	75.3	129	124	0	34	33
2014	7	7	3	58	42	0.863	-0.082	4.616	0.013	0.01	0	41.3	39.6	74.8	130	125	0	34	33
2014	7	7	4	8	42	0.866	-0.069	4.616	0.01	0.007	0	41.3	40	74.8	130	126	0	34	33
2014	7	7	4	18	42	0.879	-0.062	4.616	0.01	0.007	0	40.9	39.6	74.4	129	125	0	34	33
2014	7	7	4	28	42	0.846	-0.089	4.616	0.01	0.007	0	40.9	40	74.4	129	125	0	34	32
2014	7	7	4	38	42	0.876	-0.092	4.616	0.01	0.007	0	40.9	39.1	74.8	129	124	0	34	33
2014	7	7	4	48	42	0.827	-0.049	4.616	0.01	0.007	0	41.7	40.4	74.8	131	127	0	34	33
2014	7	7	4	58	42	0.869	-0.115	4.616	0.01	0.007	0	41.7	40	74.8	130	126	0	33	33
2014	7	7	5	8	42	0.883	-0.085	4.616	0.01	0.007	0	41.7	39.6	74.4	131	126	0	34	34
2014	7	7	5	18	42	0.873	-0.079	4.616	0.01	0.007	0	41.7	40.4	74.8	131	127	0	34	33
2014	7	7	5	28	42	0.886	-0.105	4.616	0.01	0.007	0	41.3	40	74.4	130	126	0	34	33
2014	7	7	5	38	42	0.833	-0.062	4.616	0.01	0.007	0	40.4	39.6	74	128	125	0	34	33
2014	7	7	5	48	42	0.853	-0.052	4.619	0.01	0.007	0	40.9	40	73.5	129	125	0	34	32
2014	7	7	5	58	42	0.863	-0.082	4.619	0.01	0.007	0	40.9	39.6	74	129	125	0	34	33
2014	7	7	6	8	42	0.856	-0.098	4.619	0.01	0.007	0	40.4	39.1	74	128	124	0	34	33
2014	7	7	6	18	42	0.827	-0.052	4.619	0.01	0.007	0	41.3	40	74	130	126	0	34	33
2014	7	7	6	28	42	0.873	-0.089	4.619	0.01	0.007	0	40	39.1	74.4	128	124	0	35	33
2014	7	7	6	38	42	0.863	-0.072	4.619	0.01	0.007	0	39.6	38.7	68.8	127	123	0	35	33
2014	7	7	6	48	42	0.869	-0.108	4.619	0.01	0.007	0	40	37.8	74.4	127	122	0	34	34
2014	7	7	6	58	42	0.843	-0.075	4.619	0.01	0.007	0	40.4	39.1	74.4	127	123	0	33	32
2014	7	7	7	8	42	0.879	-0.082	4.619	0.01	0.007	0	39.6	38.3	74	126	122	0	34	33
2014	7	7	7	18	42	0.837	-0.066	4.619	0.01	0.007	0	39.6	38.3	74	126	122	0	34	33
2014	7	7	7	28	42	0.869	-0.082	4.619	0.01	0.007	0	39.6	38.3	74	127	122	0	35	33
2014	7	7	7	38	42	0.846	-0.056	4.619	0.01	0.007	0	39.6	38.3	73.5	126	122	0	34	33
2014	7	7	7	48	42	0.86	-0.059	4.619	0.01	0.007	0	39.6	38.7	73.5	126	122	0	34	32
2014	7	7	7	58	42	0.863	-0.066	4.619	0.01	0.007	0	40.9	39.6	73.5	129	125	0	34	33
2014	7	7	8	8	42	0.883	-0.069	4.619	0.01	0.007	0	40	38.7	73.1	127	123	0	34	33
2014	7	7	8	18	42	0.883	-0.095	4.619	0.01	0.007	0	39.6	38.3	74	126	122	0	34	33
2014	7	7	8	28	42	0.853	-0.108	4.619	0.013	0.01	0	39.6	38.7	74.4	126	122	0	34	32
2014	7	7	8	38	42	0.856	-0.095	4.619	0.01	0.007	0	39.1	38.3	74.4	125	121	0	34	32
2014	7	7	8	48	42	0.906	-0.072	4.619	0.013	0.01	0	39.6	38.7	74	126	122	0	34	32
2014	7	7	8	58	42	0.853	-0.082	4.619	0.01	0.007	0	39.6	38.3	74.4	126	122	0	34	33
2014	7	7	9	8	42	0.84	-0.079	4.619	0.01	0.007	0	39.6	38.7	74	126	123	0	34	33
2014	7	7	9	18	42	0.873	-0.066	4.619	0.01	0.007	0	39.6	38.3	74.4	126	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	9	28	42	0.883	-0.072	4.619	0.013	0.01	0	39.1	38.3	74	125	122	0	34	33
2014	7	7	9	38	42	0.853	-0.092	4.619	0.01	0.007	0	39.6	38.3	73.5	126	122	0	34	33
2014	7	7	9	48	42	0.873	-0.082	4.619	0.01	0.007	0	39.1	38.7	74	126	122	0	35	32
2014	7	7	9	58	42	0.869	-0.082	4.619	0.01	0.007	0	39.1	37.8	74	125	121	0	34	33
2014	7	7	10	8	42	0.856	-0.112	4.619	0.01	0.007	0	39.6	38.3	73.5	126	122	0	34	33
2014	7	7	10	18	42	0.85	-0.062	4.619	0.01	0.007	0	40	38.3	73.5	126	122	0	33	33
2014	7	7	10	28	42	0.837	-0.069	4.619	0.01	0.007	0	39.6	38.3	74	126	122	0	34	33
2014	7	7	10	38	42	0.866	-0.095	4.619	0.01	0.007	0	39.6	37.8	74	125	121	0	33	33
2014	7	7	10	48	42	0.873	-0.056	4.619	0.01	0.007	0	39.6	38.3	74	126	122	0	34	33
2014	7	7	10	58	42	0.879	-0.112	4.619	0.01	0.007	0	40	38.3	72.7	127	122	0	34	33
2014	7	7	11	8	42	0.896	-0.072	4.619	0.01	0.007	0	39.6	38.7	74.8	126	123	0	34	33
2014	7	7	11	18	42	0.846	-0.079	4.619	0.013	0.01	0	40	39.1	74.8	127	124	0	34	33
2014	7	7	11	28	42	0.876	-0.075	4.619	0.01	0.007	0	40	39.1	74.8	127	123	0	34	32
2014	7	7	11	38	42	0.866	-0.095	4.619	0.01	0.007	0	40.4	39.6	72.7	127	124	0	33	32
2014	7	7	11	48	42	0.899	-0.125	4.619	0.01	0.007	0	39.1	37.8	73.5	125	121	0	34	33
2014	7	7	11	58	42	0.846	-0.164	4.619	0.01	0.007	0	39.1	37.8	75.3	125	121	0	34	33
2014	7	7	12	8	42	0.866	-0.098	4.619	0.01	0.007	0	38.7	37.8	68.8	124	120	0	34	32
2014	7	7	12	18	42	0.876	-0.102	4.619	0.01	0.007	0	39.1	38.3	64.5	125	121	0	34	32
2014	7	7	12	28	42	0.837	-0.2	4.619	0.01	0.007	0	38.7	37.4	54.6	124	120	0	34	33
2014	7	7	12	38	42	0.883	-0.157	4.619	0.013	0.01	0	39.1	37.8	70.5	125	121	0	34	33
2014	7	7	12	48	42	0.853	-0.121	4.619	0.013	0.01	0	38.7	37.8	57.2	124	121	0	34	33
2014	7	7	12	58	42	0.876	-0.167	4.619	0.01	0.007	0	39.1	38.3	73.1	125	121	0	34	32
2014	7	7	13	8	42	0.843	-0.141	4.616	0.01	0.007	0	39.1	37.8	66.2	125	121	0	34	33
2014	7	7	13	18	42	0.866	-0.138	4.616	0.01	0.007	0	39.1	37.8	75.3	125	121	0	34	33
2014	7	7	13	28	42	0.873	-0.138	4.616	0.01	0.007	0	39.1	38.7	74.8	125	122	0	34	32
2014	7	7	13	38	42	0.86	-0.141	4.619	0.01	0.007	0	39.1	37.8	76.1	125	121	0	34	33
2014	7	7	13	48	42	0.866	-0.138	4.616	0.01	0.007	0	39.1	38.3	74.8	125	121	0	34	32
2014	7	7	13	58	42	0.902	-0.135	4.616	0.013	0.01	0	39.1	37.8	74	125	121	0	34	33
2014	7	7	14	8	42	0.873	-0.128	4.616	0.01	0.007	0	40	38.7	51.6	126	122	0	33	32
2014	7	7	14	18	42	0.886	-0.112	4.616	0.01	0.007	0	40.4	39.1	62.4	128	124	0	34	33
2014	7	7	14	28	42	0.899	-0.135	4.616	0.01	0.007	0	42.1	40	46.4	132	126	0	34	33
2014	7	7	14	40	59	0.738	-0.22	4.613	0.013	0.01	0	43	41.3	43.4	133	129	0	33	33
2014	7	7	14	50	59	0.814	-0.217	4.623	0.01	0.007	0	43.4	39.1	43.9	135	123	0	34	32
2014	7	7	15	0	59	0.873	-0.112	4.616	0.01	0.007	0	42.1	40	53.8	132	126	0	34	33
2014	7	7	15	10	59	0.866	-0.115	4.619	0.01	0.007	0	40.4	37.8	75.7	127	121	0	33	33
2014	7	7	15	20	59	0.853	-0.105	4.619	0.01	0.007	0	40.4	38.3	76.1	128	122	0	34	33
2014	7	7	15	30	59	0.866	-0.102	4.619	0.01	0.007	0	40.9	39.1	75.7	129	123	0	34	32
2014	7	7	15	40	59	0.883	-0.085	4.619	0.01	0.007	0	40.4	38.7	75.7	128	123	0	34	33
2014	7	7	15	50	59	0.876	-0.148	4.616	0.01	0.007	0	40.4	38.7	62.4	128	123	0	34	33
2014	7	7	16	0	59	0.876	-0.115	4.619	0.01	0.007	0	40.4	38.3	57.6	128	122	0	34	33
2014	7	7	16	10	59	0.876	-0.108	4.619	0.01	0.007	0	40.4	38.3	60.2	127	122	0	33	33
2014	7	7	16	20	59	0.85	-0.18	4.616	0.01	0.007	0	40	37.8	61.5	127	121	0	34	33
2014	7	7	16	30	59	0.883	-0.141	4.616	0.01	0.007	0	40.4	38.3	67.5	127	122	0	33	33
2014	7	7	16	40	59	0.863	-0.144	4.616	0.013	0.01	0	39.6	37.8	67.9	126	121	0	34	33
2014	7	7	16	50	59	0.879	-0.144	4.616	0.01	0.007	0	40.4	37.8	76.1	127	121	0	33	33
2014	7	7	17	0	59	0.856	-0.128	4.616	0.01	0.007	0	40	37.8	76.1	127	121	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	17	10	59	0.863	-0.138	4.616	0.01	0.007	0	40	37.8	75.7	127	121	0	34	33
2014	7	7	17	20	59	0.866	-0.135	4.616	0.01	0.007	0	40	38.3	76.1	127	122	0	34	33
2014	7	7	17	30	59	0.81	-0.075	4.616	0.01	0.007	0	40.4	38.3	75.7	128	122	0	34	33
2014	7	7	17	40	59	0.843	-0.075	4.616	0.01	0.007	0	40.4	38.7	75.7	128	122	0	34	32
2014	7	7	17	50	59	0.853	-0.089	4.619	0.013	0.01	0	40.4	39.1	75.7	128	123	0	34	32
2014	7	7	18	0	59	0.837	-0.098	4.619	0.01	0.007	0	40.4	39.1	75.3	128	123	0	34	32
2014	7	7	18	10	59	0.853	-0.098	4.616	0.01	0.007	0	40.4	38.7	74.8	128	123	0	34	33
2014	7	7	18	20	59	0.86	-0.098	4.616	0.01	0.007	0	40.9	38.7	75.7	129	123	0	34	33
2014	7	7	18	30	59	0.86	-0.075	4.616	0.016	0.013	0	40.4	38.7	75.3	128	122	0	34	32
2014	7	7	18	40	59	0.853	-0.079	4.619	0.01	0.007	0	40.9	38.7	75.3	129	123	0	34	33
2014	7	7	18	50	59	0.85	-0.102	4.619	0.01	0.007	0	41.3	38.7	76.1	129	123	0	33	33
2014	7	7	19	0	59	0.869	-0.079	4.619	0.01	0.007	0	41.3	38.7	75.3	129	123	0	33	33
2014	7	7	19	10	59	0.846	-0.082	4.619	0.01	0.007	0	40.9	38.7	75.7	129	123	0	34	33
2014	7	7	19	20	59	0.856	-0.082	4.619	0.01	0.007	0	40.9	39.1	75.7	129	123	0	34	32
2014	7	7	19	30	59	0.856	-0.095	4.619	0.01	0.007	0	40.9	39.6	75.7	130	125	0	35	33
2014	7	7	19	40	59	0.853	-0.092	4.619	0.01	0.007	0	40.4	39.1	75.3	129	124	0	35	33
2014	7	7	19	50	59	0.85	-0.098	4.619	0.013	0.01	0	41.3	39.6	75.7	130	124	0	34	32
2014	7	7	20	0	59	0.873	-0.089	4.619	0.013	0.01	0	40.9	39.1	74.8	130	124	0	35	33
2014	7	7	20	10	59	0.879	-0.082	4.619	0.01	0.007	0	41.3	39.1	74.8	130	124	0	34	33
2014	7	7	20	20	59	0.853	-0.062	4.619	0.01	0.007	0	41.3	39.6	74.4	130	125	0	34	33
2014	7	7	20	30	59	0.85	-0.082	4.619	0.01	0.007	0	41.7	39.6	74	131	125	0	34	33
2014	7	7	20	40	59	0.846	-0.079	4.619	0.01	0.007	0	41.7	40	71.8	131	125	0	34	32
2014	7	7	20	50	59	0.846	-0.112	4.619	0.013	0.01	0	41.7	39.1	70.5	130	124	0	33	33
2014	7	7	21	0	59	0.856	-0.066	4.619	0.01	0.007	0	41.3	39.6	71.8	130	125	0	34	33
2014	7	7	21	10	59	0.856	-0.062	4.619	0.01	0.007	0	41.3	40	71.4	130	125	0	34	32
2014	7	7	21	20	59	0.856	-0.085	4.619	0.01	0.007	0	41.3	39.1	71.8	130	124	0	34	33
2014	7	7	21	30	59	0.846	-0.105	4.619	0.01	0.007	0	41.3	39.6	71.8	129	124	0	33	32
2014	7	7	21	40	59	0.869	-0.056	4.619	0.016	0.013	0	40.9	39.1	74	129	124	0	34	33
2014	7	7	21	50	59	0.869	-0.098	4.619	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	7	22	0	59	0.856	-0.082	4.623	0.01	0.007	0	40.9	38.7	73.1	129	123	0	34	33
2014	7	7	22	10	59	0.863	-0.056	4.619	0.01	0.007	0	40.9	39.6	71.8	129	124	0	34	32
2014	7	7	22	20	59	0.853	-0.079	4.619	0.01	0.007	0	41.3	39.1	70.5	130	124	0	34	33
2014	7	7	22	30	59	0.866	-0.082	4.619	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	7	22	40	59	0.873	-0.046	4.623	0.01	0.007	0	40.9	39.1	73.5	130	125	0	35	34
2014	7	7	22	50	59	0.86	-0.085	4.619	0.01	0.007	0	41.7	39.6	74	131	125	0	34	33
2014	7	7	23	0	59	0.876	-0.082	4.619	0.01	0.007	0	42.1	40	71	132	126	0	34	33
2014	7	7	23	10	59	0.879	-0.095	4.623	0.01	0.007	0	41.3	39.6	73.1	130	125	0	34	33
2014	7	7	23	20	59	0.873	-0.082	4.623	0.013	0.01	0	41.3	39.1	67.9	130	124	0	34	33
2014	7	7	23	30	59	0.853	-0.082	4.623	0.01	0.007	0	40.9	38.7	74	129	123	0	34	33
2014	7	7	23	40	59	0.837	-0.066	4.623	0.01	0.007	0	41.7	40	74.4	131	125	0	34	32
2014	7	7	23	50	59	0.86	-0.098	4.623	0.01	0.007	0	41.7	39.6	74.4	131	125	0	34	33
2014	7	8	0	0	59	0.837	-0.092	4.623	0.01	0.007	0	41.7	39.6	74	131	125	0	34	33
2014	7	8	0	10	59	0.843	-0.082	4.623	0.01	0.007	0	41.3	39.6	73.1	130	124	0	34	32
2014	7	8	0	20	59	0.853	-0.072	4.623	0.01	0.007	0	42.1	39.6	73.1	132	125	0	34	33
2014	7	8	0	30	59	0.856	-0.095	4.623	0.013	0.01	0	42.1	40	73.1	132	126	0	34	33
2014	7	8	0	40	59	0.853	-0.105	4.623	0.01	0.007	0	41.3	39.6	74	130	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	0	50	59	0.863	-0.079	4.623	0.013	0.01	0	42.1	40	73.1	132	126	0	34	33
2014	7	8	1	0	59	0.837	-0.092	4.623	0.01	0.007	0	41.3	39.6	73.5	130	125	0	34	33
2014	7	8	1	10	59	0.833	-0.092	4.623	0.01	0.007	0	41.3	39.6	74	130	125	0	34	33
2014	7	8	1	20	59	0.853	-0.069	4.623	0.01	0.007	0	41.3	40	74	130	125	0	34	32
2014	7	8	1	30	59	0.853	-0.092	4.623	0.01	0.007	0	41.7	39.6	72.2	131	125	0	34	33
2014	7	8	1	40	59	0.879	-0.072	4.626	0.01	0.007	0	41.7	40	55.9	131	126	0	34	33
2014	7	8	1	50	59	0.853	-0.095	4.623	0.01	0.007	0	42.1	39.6	72.2	131	125	0	33	33
2014	7	8	2	0	59	0.876	-0.085	4.626	0.01	0.007	0	41.7	40	73.5	131	126	0	34	33
2014	7	8	2	10	59	0.84	-0.095	4.626	0.01	0.007	0	41.7	39.6	72.2	131	125	0	34	33
2014	7	8	2	20	59	0.856	-0.082	4.623	0.01	0.007	0	43	40.9	70.5	133	127	0	33	32
2014	7	8	2	30	59	0.85	-0.102	4.626	0.01	0.007	0	42.1	40.4	71.8	132	127	0	34	33
2014	7	8	2	40	59	0.863	-0.095	4.626	0.01	0.007	0	41.7	40	72.7	131	126	0	34	33
2014	7	8	2	50	59	0.837	-0.085	4.626	0.01	0.007	0	40.9	40	69.7	130	125	0	35	32
2014	7	8	3	0	59	0.856	-0.082	4.629	0.01	0.007	0	42.1	40	55.9	131	125	0	33	32
2014	7	8	3	10	59	0.84	-0.066	4.626	0.01	0.007	0	43	40.9	56.8	133	127	0	33	32
2014	7	8	3	20	59	0.853	-0.069	4.626	0.01	0.007	0	42.1	40	60.2	131	125	0	33	32
2014	7	8	3	30	59	0.846	-0.079	4.626	0.01	0.007	0	41.7	40	65.4	131	126	0	34	33
2014	7	8	3	40	59	0.866	-0.098	4.626	0.01	0.007	0	41.7	39.6	70.5	131	125	0	34	33
2014	7	8	3	50	59	0.843	-0.108	4.626	0.01	0.007	0	42.6	40	66.2	133	126	0	34	33
2014	7	8	4	0	59	0.837	-0.082	4.626	0.01	0.007	0	43	40.9	67.1	134	128	0	34	33
2014	7	8	4	10	59	0.85	-0.082	4.626	0.01	0.007	0	42.1	40	69.2	132	126	0	34	33
2014	7	8	4	20	59	0.869	-0.089	4.626	0.01	0.007	0	42.1	40.4	72.7	132	127	0	34	33
2014	7	8	4	30	59	0.833	-0.092	4.626	0.013	0.01	0	42.1	40	72.2	132	126	0	34	33
2014	7	8	4	40	59	0.866	-0.092	4.626	0.01	0.007	0	41.3	39.6	71.4	130	125	0	34	33
2014	7	8	4	50	59	0.853	-0.112	4.626	0.013	0.01	0	41.7	39.6	71.8	131	125	0	34	33
2014	7	8	5	0	59	0.843	-0.108	4.626	0.01	0.007	0	43	40.4	71.4	133	127	0	33	33
2014	7	8	5	10	59	0.846	-0.082	4.626	0.01	0.007	0	41.7	39.6	71.8	131	125	0	34	33
2014	7	8	5	20	59	0.856	-0.112	4.629	0.01	0.007	0	41.3	40	71	131	126	0	35	33
2014	7	8	5	30	59	0.837	-0.059	4.629	0.013	0.01	0	42.1	40	71.8	132	126	0	34	33
2014	7	8	5	40	59	0.85	-0.075	4.629	0.01	0.007	0	42.1	40	70.1	131	126	0	33	33
2014	7	8	5	50	59	0.827	-0.082	4.629	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	8	6	0	59	0.85	-0.079	4.629	0.01	0.007	0	40.4	39.1	71	129	124	0	35	33
2014	7	8	6	10	59	0.82	-0.092	4.633	0.01	0.007	0	41.3	38.7	71	130	124	0	34	34
2014	7	8	6	20	59	0.879	-0.112	4.633	0.01	0.007	0	41.3	39.1	71	130	124	0	34	33
2014	7	8	6	30	59	0.886	-0.098	4.636	0.01	0.007	0	42.1	39.6	70.5	131	125	0	33	33
2014	7	8	6	40	59	0.814	-0.089	4.639	0.01	0.007	0	41.3	38.7	71.4	130	123	0	34	33
2014	7	8	6	50	59	0.85	-0.072	4.639	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	8	7	0	59	0.846	-0.095	4.639	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	8	7	10	59	0.866	-0.075	4.639	0.01	0.007	0	40.9	38.7	71	129	123	0	34	33
2014	7	8	7	20	59	0.853	-0.102	4.639	0.01	0.007	0	40.9	38.3	71.4	129	122	0	34	33
2014	7	8	7	30	59	0.833	-0.069	4.639	0.01	0.007	0	41.3	39.6	71.4	130	124	0	34	32
2014	7	8	7	40	59	0.846	-0.098	4.639	0.01	0.007	0	40.4	38.3	71.8	128	122	0	34	33
2014	7	8	7	50	59	0.85	-0.115	4.639	0.01	0.007	0	40.9	39.6	71.8	129	124	0	34	32
2014	7	8	8	0	59	0.83	-0.089	4.639	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	8	8	10	59	0.876	-0.131	4.639	0.01	0.007	0	40.4	38.7	71	128	123	0	34	33
2014	7	8	8	20	59	0.889	-0.128	4.639	0.01	0.007	0	40.9	38.7	70.1	129	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	8	30	59	0.846	-0.115	4.639	0.01	0.007	0	40.9	39.1	71	129	124	0	34	33
2014	7	8	8	40	59	0.863	-0.131	4.639	0.01	0.007	0	40.4	39.1	71.4	129	123	0	35	32
2014	7	8	8	50	59	0.863	-0.131	4.636	0.01	0.007	0	40.4	38.7	70.5	128	122	0	34	32
2014	7	8	9	0	59	0.843	-0.118	4.636	0.01	0.007	0	40.4	38.7	71	128	122	0	34	32
2014	7	8	9	10	59	0.856	-0.115	4.636	0.01	0.007	0	40.9	39.1	70.5	129	124	0	34	33
2014	7	8	9	20	59	0.833	-0.135	4.636	0.013	0.01	0	40.4	38.3	71	128	122	0	34	33
2014	7	8	9	30	59	0.869	-0.148	4.636	0.016	0.013	0	40.4	38.3	71.4	128	122	0	34	33
2014	7	8	9	40	59	0.879	-0.18	4.633	0.01	0.007	0	40.4	38.3	70.5	127	122	0	33	33
2014	7	8	9	50	59	0.886	-0.082	4.629	0.016	0.013	0	40.9	39.1	70.5	129	124	0	34	33
2014	7	8	10	0	59	0.833	-0.151	4.629	0.01	0.007	0	40.4	38.3	71	128	122	0	34	33
2014	7	8	10	10	59	0.85	-0.141	4.629	0.013	0.01	0	40.4	38.7	70.5	128	122	0	34	32
2014	7	8	10	20	59	0.856	-0.138	4.629	0.01	0.007	0	40.4	38.7	71.8	127	122	0	33	32
2014	7	8	10	30	59	0.873	-0.148	4.629	0.01	0.007	0	40.4	38.3	69.7	128	122	0	34	33
2014	7	8	10	40	59	0.83	-0.144	4.629	0.01	0.007	0	40.4	38.3	71.4	128	122	0	34	33
2014	7	8	10	50	59	0.869	-0.164	4.629	0.01	0.007	0	40.4	38.3	71.4	128	122	0	34	33
2014	7	8	11	0	59	0.833	-0.157	4.626	0.01	0.007	0	40	38.3	68.8	127	122	0	34	33
2014	7	8	11	10	59	0.866	-0.161	4.629	0.01	0.007	0	40.9	38.7	62.4	128	122	0	33	32
2014	7	8	11	20	59	0.866	-0.135	4.633	0.01	0.007	0	40	38.3	54.2	127	122	0	34	33
2014	7	8	11	30	59	0.853	-0.151	4.626	0.01	0.007	0	40	37.8	64.1	127	121	0	34	33
2014	7	8	11	40	59	0.886	-0.148	4.626	0.01	0.007	0	40.9	38.7	58.9	128	122	0	33	32
2014	7	8	11	50	59	0.886	-0.105	4.629	0.01	0.007	0	40	38.7	56.8	128	123	0	35	33
2014	7	8	12	0	59	0.843	-0.135	4.629	0.01	0.007	0	40.4	38.3	52.9	128	123	0	34	34
2014	7	8	12	10	59	0.876	-0.102	4.633	0.01	0.007	0	41.7	39.1	49.9	130	124	0	33	33
2014	7	8	12	20	59	0.869	-0.098	4.629	0.01	0.007	0	40.9	39.1	51.6	129	124	0	34	33
2014	7	8	12	30	59	0.869	-0.131	4.629	0.01	0.007	0	41.3	38.7	48.2	130	122	0	34	32
2014	7	8	12	40	59	0.863	-0.121	4.629	0.01	0.007	0	40.4	39.1	52.9	128	123	0	34	32
2014	7	8	12	50	59	0.869	-0.108	4.626	0.01	0.007	0	40.4	38.7	58	128	123	0	34	33
2014	7	8	13	0	59	0.886	-0.128	4.629	0.01	0.007	0	40.9	38.3	53.3	128	122	0	33	33
2014	7	8	13	10	59	0.912	-0.105	4.629	0.01	0.007	0	40.9	38.7	54.2	129	123	0	34	33
2014	7	8	13	20	59	0.876	-0.141	4.626	0.01	0.007	0	40.4	38.7	55	128	123	0	34	33
2014	7	8	13	30	59	0.883	-0.174	4.629	0.013	0.01	0	40.4	38.7	48.6	128	123	0	34	33
2014	7	8	13	40	59	0.909	-0.161	4.629	0.01	0.007	0	40.9	38.7	48.6	129	123	0	34	33
2014	7	8	13	50	59	0.85	-0.167	4.626	0.01	0.007	0	42.1	40.9	49.5	132	127	0	34	32
2014	7	8	14	0	59	0.856	-0.125	4.626	0.01	0.007	0	42.6	41.3	50.7	133	128	0	34	32
2014	7	8	14	10	59	0.853	-0.098	4.629	0.01	0.007	0	43	41.3	51.2	134	129	0	34	33
2014	7	8	14	20	59	0.876	-0.108	4.626	0.01	0.007	0	42.6	41.3	50.7	134	129	0	35	33
2014	7	8	14	30	59	0.879	-0.098	4.629	0.013	0.01	0	43	40.4	51.6	133	127	0	33	33
2014	7	8	14	40	59	0.843	-0.066	4.629	0.01	0.007	0	42.1	40.4	51.6	132	127	0	34	33
2014	7	8	14	50	59	0.853	-0.072	4.626	0.01	0.007	0	41.7	40	53.3	131	126	0	34	33
2014	7	8	15	0	59	0.863	-0.121	4.626	0.013	0.01	0	41.3	39.6	53.3	131	125	0	35	33
2014	7	8	15	10	59	0.856	-0.059	4.626	0.01	0.007	0	42.1	40.4	61.9	132	127	0	34	33
2014	7	8	15	20	59	0.833	-0.085	4.626	0.01	0.007	0	42.1	40.9	51.6	132	127	0	34	32
2014	7	8	15	30	59	0.896	-0.112	4.629	0.01	0.007	0	42.6	40.9	54.2	132	127	0	33	32
2014	7	8	15	40	59	0.863	-0.095	4.626	0.01	0.007	0	41.3	40	55	130	125	0	34	32
2014	7	8	15	50	59	0.889	-0.102	4.626	0.01	0.007	0	41.3	39.1	55	129	124	0	33	33
2014	7	8	16	0	59	0.892	-0.108	4.623	0.01	0.007	0	40.9	39.1	54.6	129	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	16	10	59	0.853	-0.105	4.623	0.01	0.007	0	40.9	38.7	56.8	129	123	0	34	33
2014	7	8	16	20	59	0.866	-0.115	4.623	0.01	0.007	0	40.4	38.7	62.4	128	123	0	34	33
2014	7	8	16	30	59	0.863	-0.167	4.623	0.01	0.007	0	40.4	39.1	63.2	128	123	0	34	32
2014	7	8	16	40	59	0.863	-0.131	4.623	0.01	0.007	0	40.4	38.7	69.7	128	123	0	34	33
2014	7	8	16	50	59	0.889	-0.115	4.623	0.013	0.01	0	40.9	38.3	58.9	128	122	0	33	33
2014	7	8	17	0	59	0.889	-0.121	4.619	0.01	0.007	0	41.3	39.6	55.9	130	124	0	34	32
2014	7	8	17	10	59	0.833	-0.092	4.623	0.01	0.007	0	40.9	39.6	58	129	124	0	34	32
2014	7	8	17	20	59	0.873	-0.118	4.623	0.01	0.007	0	40.9	38.7	56.8	128	123	0	33	33
2014	7	8	17	30	59	0.873	-0.069	4.623	0.013	0.01	0	40.4	38.7	63.6	128	123	0	34	33
2014	7	8	17	40	59	0.873	-0.079	4.623	0.01	0.007	0	40.4	38.7	61.1	128	123	0	34	33
2014	7	8	17	50	59	0.86	-0.108	4.623	0.01	0.007	0	40.9	38.7	72.2	129	123	0	34	33
2014	7	8	18	0	59	0.889	-0.102	4.623	0.013	0.01	0	40.9	39.1	68.4	128	123	0	33	32
2014	7	8	18	10	59	0.869	-0.098	4.623	0.01	0.007	0	40.4	38.7	74	128	123	0	34	33
2014	7	8	18	20	59	0.84	-0.075	4.623	0.013	0.01	0	40.9	39.6	62.8	129	124	0	34	32
2014	7	8	18	30	59	0.876	-0.092	4.623	0.013	0.01	0	40.4	38.3	73.5	128	122	0	34	33
2014	7	8	18	40	59	0.889	-0.049	4.626	0.01	0.007	0	41.3	39.1	50.3	130	124	0	34	33
2014	7	8	18	50	59	0.85	-0.036	4.623	0.01	0.007	0	42.6	39.6	57.2	132	126	0	33	34
2014	7	8	19	0	59	0.889	-0.069	4.626	0.01	0.007	0	41.7	39.6	55	131	125	0	34	33
2014	7	8	19	10	59	0.892	-0.052	4.623	0.01	0.007	0	42.1	40.4	55.5	132	127	0	34	33
2014	7	8	19	20	59	0.883	-0.052	4.623	0.01	0.007	0	42.1	40.4	55.9	132	127	0	34	33
2014	7	8	19	30	59	0.863	-0.039	4.626	0.016	0.013	0	42.6	40.9	55.5	133	128	0	34	33
2014	7	8	19	40	59	0.86	-0.085	4.623	0.01	0.007	0	42.6	40	56.3	132	126	0	33	33
2014	7	8	19	50	59	0.873	-0.066	4.623	0.01	0.007	0	42.1	40	57.2	132	126	0	34	33
2014	7	8	20	0	59	0.863	-0.049	4.623	0.01	0.007	0	42.1	40.4	55.9	132	127	0	34	33
2014	7	8	20	10	59	0.879	-0.039	4.623	0.016	0.013	0	41.7	40.4	53.3	132	127	0	35	33
2014	7	8	20	20	59	0.837	-0.079	4.626	0.01	0.007	0	42.6	40.4	54.2	133	127	0	34	33
2014	7	8	20	30	59	0.853	-0.056	4.623	0.01	0.007	0	43	41.3	54.6	134	129	0	34	33
2014	7	8	20	40	59	0.86	-0.049	4.626	0.01	0.007	0	43.4	42.1	55	135	130	0	34	32
2014	7	8	20	50	59	0.883	-0.059	4.623	0.01	0.007	0	43.4	41.7	56.3	135	130	0	34	33
2014	7	8	21	0	59	0.853	-0.039	4.626	0.01	0.007	0	44.3	42.6	55.5	137	132	0	34	33
2014	7	8	21	10	59	0.843	-0.043	4.626	0.01	0.007	0	43.9	42.1	54.2	136	131	0	34	33
2014	7	8	21	20	59	0.843	-0.049	4.626	0.01	0.007	0	43.9	41.7	57.2	135	129	0	33	32
2014	7	8	21	30	59	0.873	-0.089	4.623	0.01	0.007	0	43	41.3	67.9	134	129	0	34	33
2014	7	8	21	40	59	0.876	-0.082	4.626	0.01	0.007	0	42.1	40	66.2	132	127	0	34	34
2014	7	8	21	50	59	0.869	-0.072	4.626	0.01	0.007	0	42.1	40.4	68.8	131	126	0	33	32
2014	7	8	22	0	59	0.869	-0.069	4.626	0.01	0.007	0	42.1	40.9	65.8	132	127	0	34	32
2014	7	8	22	10	59	0.883	-0.098	4.626	0.01	0.007	0	42.6	40	65.4	132	126	0	33	33
2014	7	8	22	20	59	0.902	-0.092	4.626	0.01	0.007	0	41.7	39.6	67.5	131	125	0	34	33
2014	7	8	22	30	59	0.86	-0.082	4.626	0.01	0.007	0	41.3	39.6	68.8	130	125	0	34	33
2014	7	8	22	40	59	0.866	-0.066	4.626	0.01	0.007	0	43	41.3	66.2	134	128	0	34	32
2014	7	8	22	50	59	0.814	-0.069	4.626	0.01	0.007	0	42.6	40.4	65.8	133	127	0	34	33
2014	7	8	23	0	59	0.84	-0.033	4.626	0.013	0.01	0	42.1	40.4	68.8	132	127	0	34	33
2014	7	8	23	10	59	0.889	-0.066	4.626	0.013	0.01	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	8	23	20	59	0.869	-0.062	4.626	0.013	0.01	0	41.7	40	72.2	131	126	0	34	33
2014	7	8	23	30	59	0.869	-0.082	4.626	0.013	0.01	0	42.1	39.6	72.2	132	125	0	34	33
2014	7	8	23	40	59	0.873	-0.079	4.626	0.01	0.007	0	42.1	39.6	73.1	131	125	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	23	50	59	0.873	-0.079	4.626	0.01	0.007	0	41.7	39.6	71.8	130	124	0	33	32
2014	7	9	0	0	59	0.902	-0.079	4.626	0.01	0.007	0	41.3	39.1	71.8	130	124	0	34	33
2014	7	9	0	10	59	0.846	-0.079	4.626	0.01	0.007	0	41.7	39.6	72.2	131	125	0	34	33
2014	7	9	0	20	59	0.896	-0.049	4.626	0.01	0.007	0	41.3	39.6	72.7	131	125	0	35	33
2014	7	9	0	30	59	0.863	-0.098	4.626	0.01	0.007	0	42.6	40.4	71.8	133	126	0	34	32
2014	7	9	0	40	59	0.886	-0.049	4.626	0.01	0.007	0	42.1	39.6	69.2	132	125	0	34	33
2014	7	9	0	50	59	0.889	-0.082	4.626	0.01	0.007	0	41.7	39.1	72.2	131	124	0	34	33
2014	7	9	1	0	59	0.873	-0.043	4.626	0.01	0.007	0	42.1	39.6	72.2	132	125	0	34	33
2014	7	9	1	10	59	0.879	-0.095	4.629	0.01	0.007	0	41.7	40	72.2	131	125	0	34	32
2014	7	9	1	20	59	0.853	-0.105	4.629	0.01	0.007	0	42.1	40	72.2	132	125	0	34	32
2014	7	9	1	30	59	0.889	-0.098	4.629	0.013	0.01	0	41.3	39.1	71.8	130	124	0	34	33
2014	7	9	1	40	59	0.85	-0.033	4.629	0.013	0.01	0	41.7	39.6	71.4	131	124	0	34	32
2014	7	9	1	50	59	0.85	-0.098	4.629	0.013	0.01	0	41.7	39.6	71.4	131	125	0	34	33
2014	7	9	2	0	59	0.876	-0.066	4.629	0.01	0.007	0	42.6	39.6	71	132	125	0	33	33
2014	7	9	2	10	59	0.896	-0.046	4.629	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	9	2	20	59	0.889	-0.069	4.629	0.01	0.007	0	41.7	39.1	71	131	125	0	34	34
2014	7	9	2	30	59	0.869	-0.098	4.629	0.01	0.007	0	41.7	39.1	71.4	131	124	0	34	33
2014	7	9	2	40	59	0.876	-0.102	4.629	0.013	0.01	0	42.1	39.6	71	132	125	0	34	33
2014	7	9	2	50	59	0.915	-0.049	4.633	0.01	0.007	0	42.6	40.4	70.1	133	127	0	34	33
2014	7	9	3	0	59	0.883	-0.066	4.633	0.01	0.007	0	41.7	39.1	71	131	124	0	34	33
2014	7	9	3	10	59	0.883	-0.075	4.633	0.01	0.007	0	41.7	39.6	66.7	131	124	0	34	32
2014	7	9	3	20	59	0.889	-0.082	4.636	0.013	0.01	0	41.7	39.6	69.2	131	125	0	34	33
2014	7	9	3	30	59	0.869	-0.079	4.636	0.013	0.01	0	41.7	39.1	71	130	123	0	33	32
2014	7	9	3	40	59	0.866	-0.079	4.636	0.01	0.007	0	41.3	38.7	71	130	123	0	34	33
2014	7	9	3	50	59	0.853	-0.082	4.639	0.01	0.007	0	42.1	39.6	71	132	125	0	34	33
2014	7	9	4	0	59	0.863	-0.079	4.642	0.01	0.007	0	41.3	38.7	71	130	123	0	34	33
2014	7	9	4	10	59	0.876	-0.085	4.639	0.01	0.007	0	41.7	39.6	71.8	131	125	0	34	33
2014	7	9	4	20	59	0.886	-0.105	4.642	0.01	0.007	0	41.7	39.6	71.4	131	125	0	34	33
2014	7	9	4	30	59	0.866	-0.085	4.639	0.01	0.007	0	42.1	40	67.9	132	126	0	34	33
2014	7	9	4	40	59	0.892	-0.085	4.642	0.01	0.007	0	42.6	40	71.4	133	126	0	34	33
2014	7	9	4	50	59	0.873	-0.079	4.642	0.01	0.007	0	42.1	39.6	72.2	132	125	0	34	33
2014	7	9	5	0	59	0.899	-0.082	4.642	0.01	0.007	0	43.4	40.9	71.8	135	128	0	34	33
2014	7	9	5	10	59	0.879	-0.066	4.642	0.013	0.01	0	42.6	40	72.2	133	126	0	34	33
2014	7	9	5	20	59	0.896	-0.089	4.642	0.01	0.007	0	42.1	40	71.4	132	125	0	34	32
2014	7	9	5	30	59	0.863	-0.089	4.646	0.01	0.007	0	42.1	39.6	72.7	132	125	0	34	33
2014	7	9	5	40	59	0.879	-0.066	4.646	0.01	0.007	0	42.6	39.6	72.7	132	125	0	33	33
2014	7	9	5	50	59	0.886	-0.059	4.646	0.01	0.007	0	41.7	39.6	73.5	131	125	0	34	33
2014	7	9	6	0	59	0.846	-0.056	4.646	0.01	0.007	0	42.1	39.6	73.5	132	125	0	34	33
2014	7	9	6	10	59	0.863	-0.112	4.646	0.01	0.007	0	42.6	40	72.7	133	126	0	34	33
2014	7	9	6	20	59	0.879	-0.066	4.646	0.01	0.007	0	41.7	39.6	74	131	125	0	34	33
2014	7	9	6	30	59	0.879	-0.066	4.646	0.01	0.007	0	42.1	40	74	132	125	0	34	32
2014	7	9	6	40	59	0.866	-0.049	4.646	0.01	0.007	0	41.7	38.7	74	130	123	0	33	33
2014	7	9	6	50	59	0.879	-0.079	4.646	0.013	0.01	0	41.3	38.7	74	130	123	0	34	33
2014	7	9	7	0	59	0.876	-0.052	4.646	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	9	7	10	59	0.883	-0.052	4.646	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	9	7	20	59	0.869	-0.092	4.646	0.013	0.01	0	40.9	38.3	74.8	129	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	7	30	59	0.879	-0.089	4.649	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	9	7	40	59	0.879	-0.085	4.646	0.01	0.007	0	40.4	38.3	75.3	129	122	0	35	33
2014	7	9	7	50	59	0.876	-0.092	4.646	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	9	8	0	59	0.873	-0.072	4.649	0.01	0.007	0	40.9	38.7	75.3	129	123	0	34	33
2014	7	9	8	10	59	0.883	-0.089	4.646	0.01	0.007	0	41.3	39.1	75.3	130	124	0	34	33
2014	7	9	8	20	59	0.863	-0.082	4.646	0.01	0.007	0	41.3	39.1	74.8	130	123	0	34	32
2014	7	9	8	30	59	0.886	-0.069	4.649	0.01	0.007	0	41.3	39.1	75.3	130	124	0	34	33
2014	7	9	8	40	59	0.853	-0.085	4.649	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	9	8	50	59	0.896	-0.082	4.646	0.01	0.007	0	41.3	38.7	75.3	130	123	0	34	33
2014	7	9	9	0	59	0.899	-0.066	4.649	0.01	0.007	0	41.7	38.7	74.4	130	123	0	33	33
2014	7	9	9	10	59	0.896	-0.098	4.649	0.01	0.007	0	40.9	38.7	74.4	129	123	0	34	33
2014	7	9	9	20	59	0.846	-0.128	4.646	0.01	0.007	0	41.3	38.7	71.4	129	122	0	33	32
2014	7	9	9	30	59	0.886	-0.108	4.646	0.01	0.007	0	40.9	38.3	74.4	129	122	0	34	33
2014	7	9	9	40	59	0.869	-0.085	4.646	0.01	0.007	0	41.3	38.3	74.4	129	122	0	33	33
2014	7	9	9	50	59	0.869	-0.075	4.646	0.01	0.007	0	40.9	39.1	73.5	129	123	0	34	32
2014	7	9	10	0	59	0.892	-0.125	4.646	0.01	0.007	0	40.4	38.3	74	128	122	0	34	33
2014	7	9	10	10	59	0.883	-0.125	4.646	0.01	0.007	0	40.9	38.3	74	129	122	0	34	33
2014	7	9	10	20	59	0.879	-0.112	4.646	0.01	0.007	0	40.4	38.3	74.4	128	122	0	34	33
2014	7	9	10	30	59	0.892	-0.141	4.646	0.01	0.007	0	40.4	37.8	74	128	122	0	34	34
2014	7	9	10	40	59	0.902	-0.118	4.646	0.01	0.007	0	40.9	38.3	71.4	129	122	0	34	33
2014	7	9	10	50	59	0.873	-0.112	4.646	0.01	0.007	0	40.9	38.7	71.8	129	123	0	34	33
2014	7	9	11	0	59	0.902	-0.082	4.646	0.01	0.007	0	40.4	38.7	71.8	129	123	0	35	33
2014	7	9	11	10	59	0.866	-0.151	4.646	0.01	0.007	0	40.9	38.3	71.8	129	122	0	34	33
2014	7	9	11	20	59	0.886	-0.125	4.646	0.013	0.01	0	40.9	38.7	72.7	129	123	0	34	33
2014	7	9	11	30	59	0.909	-0.092	4.646	0.01	0.007	0	40.9	38.7	69.7	129	123	0	34	33
2014	7	9	11	40	59	0.863	-0.121	4.646	0.01	0.007	0	40.9	38.3	72.2	129	122	0	34	33
2014	7	9	11	50	59	0.879	-0.213	4.646	0.01	0.007	0	40	38.3	65.8	128	122	0	35	33
2014	7	9	12	0	59	0.889	-0.138	4.642	0.01	0.007	0	40.4	37.8	64.9	128	121	0	34	33
2014	7	9	12	10	59	0.856	-0.154	4.642	0.01	0.007	0	40.4	38.3	55.5	128	121	0	34	32
2014	7	9	12	20	59	0.863	-0.148	4.642	0.01	0.007	0	40.4	38.3	61.1	128	122	0	34	33
2014	7	9	12	30	59	0.896	-0.138	4.639	0.01	0.007	0	40.9	38.7	52.9	129	123	0	34	33
2014	7	9	12	40	59	0.902	-0.082	4.639	0.013	0.01	0	44.7	42.6	46.4	137	132	0	33	33
2014	7	9	12	50	59	0.945	-0.144	4.639	0.01	0.007	0	40.4	39.1	48.6	128	123	0	34	32
2014	7	9	13	0	59	0.925	-0.167	4.636	0.01	0.007	0	40.9	38.7	52	129	123	0	34	33
2014	7	9	13	10	59	0.915	-0.161	4.636	0.01	0.007	0	40.4	38.3	52	128	122	0	34	33
2014	7	9	13	20	59	0.909	-0.167	4.636	0.01	0.007	0	40.9	38.3	58	128	122	0	33	33
2014	7	9	13	30	59	0.883	-0.131	4.639	0.01	0.007	0	40.4	38.3	52	127	122	0	33	33
2014	7	9	13	40	59	0.906	-0.164	4.636	0.01	0.007	0	40.4	38.3	59.8	128	122	0	34	33
2014	7	9	13	50	59	0.804	-0.207	4.639	0.01	0.007	0	43.9	38.3	45.6	136	122	0	34	33
2014	7	9	14	0	59	0.902	-0.062	4.639	0.01	0.007	0	43	40	49	134	125	0	34	32
2014	7	9	14	10	59	0.902	-0.115	4.636	0.01	0.007	0	40.9	38.3	58.9	129	122	0	34	33
2014	7	9	14	20	59	0.876	-0.108	4.636	0.013	0.01	0	40.9	38.7	59.3	129	122	0	34	32
2014	7	9	14	30	59	0.853	-0.062	4.633	0.01	0.007	0	48.6	46.9	50.3	147	141	0	34	32
2014	7	9	14	40	59	0.869	-0.095	4.636	0.01	0.007	0	45.2	43.4	51.6	139	133	0	34	32
2014	7	9	14	50	59	0.876	-0.049	4.636	0.01	0.007	0	47.3	45.6	53.8	144	139	0	34	33
2014	7	9	15	0	59	0.85	-0.049	4.636	0.01	0.007	0	44.3	42.1	53.8	138	131	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	15	10	59	0.856	-0.072	4.633	0.01	0.007	0	43.9	41.7	53.3	136	129	0	34	32
2014	7	9	15	20	59	0.856	-0.079	4.633	0.01	0.007	0	43.4	41.3	52.9	135	129	0	34	33
2014	7	9	15	30	59	0.876	-0.075	4.633	0.013	0.01	0	43	40	55.9	134	127	0	34	34
2014	7	9	15	40	59	0.856	-0.082	4.629	0.013	0.01	0	42.1	40.4	58	133	127	0	35	33
2014	7	9	15	50	59	0.896	-0.062	4.629	0.01	0.007	0	42.6	40	63.2	133	126	0	34	33
2014	7	9	16	0	59	0.883	-0.082	4.629	0.01	0.007	0	42.1	40	64.9	132	125	0	34	32
2014	7	9	16	10	59	0.873	-0.108	4.629	0.01	0.007	0	41.7	39.6	65.4	131	125	0	34	33
2014	7	9	16	20	59	0.879	-0.098	4.629	0.013	0.01	0	41.3	39.6	71	130	124	0	34	32
2014	7	9	16	30	59	0.886	-0.082	4.629	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	9	16	40	59	0.892	-0.118	4.629	0.01	0.007	0	41.3	39.6	67.5	130	124	0	34	32
2014	7	9	16	50	59	0.883	-0.118	4.629	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	9	17	0	59	0.889	-0.098	4.629	0.01	0.007	0	41.3	39.6	67.5	130	124	0	34	32
2014	7	9	17	10	59	0.886	-0.082	4.629	0.01	0.007	0	41.3	38.7	71	130	123	0	34	33
2014	7	9	17	20	59	0.86	-0.079	4.629	0.01	0.007	0	41.7	39.6	71.8	130	124	0	33	32
2014	7	9	17	30	59	0.889	-0.082	4.629	0.01	0.007	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	9	17	40	59	0.856	-0.098	4.629	0.01	0.007	0	41.7	39.1	67.5	130	124	0	33	33
2014	7	9	17	50	59	0.86	-0.043	4.626	0.01	0.007	0	41.3	38.7	67.1	130	123	0	34	33
2014	7	9	18	0	59	0.863	-0.072	4.629	0.01	0.007	0	41.3	38.7	70.5	130	124	0	34	34
2014	7	9	18	10	59	0.906	-0.072	4.629	0.01	0.007	0	41.3	39.1	70.1	130	124	0	34	33
2014	7	9	18	20	59	0.892	-0.069	4.629	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	9	18	30	59	0.886	-0.072	4.629	0.01	0.007	0	40.4	38.7	72.7	129	123	0	35	33
2014	7	9	18	40	59	0.883	-0.075	4.629	0.01	0.007	0	41.3	38.7	73.1	130	123	0	34	33
2014	7	9	18	50	59	0.892	-0.069	4.629	0.01	0.007	0	41.3	39.6	68.8	130	124	0	34	32
2014	7	9	19	0	59	0.869	-0.082	4.629	0.01	0.007	0	41.7	39.1	73.1	131	124	0	34	33
2014	7	9	19	10	59	0.896	-0.082	4.629	0.01	0.007	0	41.3	39.1	71	130	124	0	34	33
2014	7	9	19	20	59	0.889	-0.082	4.629	0.01	0.007	0	41.7	39.1	71.8	131	124	0	34	33
2014	7	9	19	30	59	0.925	-0.112	4.629	0.01	0.007	0	41.3	39.1	70.5	130	123	0	34	32
2014	7	9	19	40	59	0.827	-0.052	4.629	0.01	0.007	0	41.3	39.6	73.1	130	124	0	34	32
2014	7	9	19	50	59	0.869	-0.089	4.629	0.013	0.01	0	41.3	39.6	68.4	130	124	0	34	32
2014	7	9	20	0	59	0.843	-0.085	4.629	0.013	0.01	0	41.3	39.1	73.1	130	124	0	34	33
2014	7	9	20	10	59	0.879	-0.056	4.629	0.01	0.007	0	42.1	39.6	72.7	132	125	0	34	33
2014	7	9	20	20	59	0.873	-0.098	4.629	0.013	0.01	0	41.7	40	72.2	131	125	0	34	32
2014	7	9	20	30	59	0.863	-0.112	4.629	0.01	0.007	0	41.7	39.6	72.2	131	125	0	34	33
2014	7	9	20	40	59	0.869	-0.089	4.629	0.01	0.007	0	41.7	40	65.8	131	125	0	34	32
2014	7	9	20	50	59	0.866	-0.082	4.633	0.01	0.007	0	42.1	40.4	66.7	132	126	0	34	32
2014	7	9	21	0	59	0.856	-0.075	4.633	0.013	0.01	0	41.7	39.6	69.2	131	125	0	34	33
2014	7	9	21	10	59	0.873	-0.102	4.633	0.01	0.007	0	41.7	39.6	70.5	131	125	0	34	33
2014	7	9	21	20	59	0.873	-0.098	4.633	0.01	0.007	0	41.3	39.6	71	130	124	0	34	32
2014	7	9	21	30	59	0.853	-0.056	4.633	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	9	21	40	59	0.883	-0.066	4.633	0.01	0.007	0	42.1	39.6	72.2	131	124	0	33	32
2014	7	9	21	50	59	0.873	-0.072	4.633	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	9	22	0	59	0.873	-0.075	4.633	0.01	0.007	0	41.7	38.7	72.2	130	123	0	33	33
2014	7	9	22	10	59	0.863	-0.105	4.633	0.01	0.007	0	41.3	39.1	72.2	130	123	0	34	32
2014	7	9	22	20	59	0.843	-0.082	4.633	0.01	0.007	0	41.3	39.1	71.8	130	123	0	34	32
2014	7	9	22	30	59	0.896	-0.089	4.633	0.01	0.007	0	41.3	39.1	71	130	123	0	34	32
2014	7	9	22	40	59	0.892	-0.092	4.633	0.01	0.007	0	41.7	39.6	70.5	130	124	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	22	50	59	0.869	-0.089	4.633	0.01	0.007	0	40.9	38.7	70.5	130	123	0	35	33
2014	7	9	23	0	59	0.896	-0.066	4.636	0.01	0.007	0	41.3	38.7	71.4	130	123	0	34	33
2014	7	9	23	10	59	0.856	-0.066	4.636	0.01	0.007	0	42.1	39.1	71.4	131	124	0	33	33
2014	7	9	23	20	59	0.876	-0.075	4.636	0.01	0.007	0	41.7	38.7	71.4	131	124	0	34	34
2014	7	9	23	30	59	0.886	-0.062	4.636	0.01	0.007	0	41.7	39.6	71	131	125	0	34	33
2014	7	9	23	40	59	0.863	-0.095	4.636	0.01	0.007	0	41.7	39.1	69.2	131	124	0	34	33
2014	7	9	23	50	59	0.843	-0.085	4.636	0.01	0.007	0	41.3	39.1	71	130	124	0	34	33
2014	7	10	0	0	59	0.876	-0.075	4.639	0.01	0.007	0	41.3	39.1	70.1	130	123	0	34	32
2014	7	10	0	10	59	0.883	-0.085	4.639	0.01	0.007	0	41.7	39.6	71	131	124	0	34	32
2014	7	10	0	20	59	0.876	-0.092	4.639	0.01	0.007	0	41.7	39.1	66.7	131	124	0	34	33
2014	7	10	0	30	59	0.879	-0.049	4.642	0.01	0.007	0	41.7	39.6	71	131	124	0	34	32
2014	7	10	0	40	59	0.869	-0.082	4.642	0.013	0.01	0	41.3	39.1	71.4	130	124	0	34	33
2014	7	10	0	50	59	0.873	-0.075	4.642	0.01	0.007	0	42.1	39.1	70.5	131	124	0	33	33
2014	7	10	1	0	59	0.869	-0.049	4.642	0.01	0.007	0	41.7	39.1	71.4	131	124	0	34	33
2014	7	10	1	10	59	0.892	-0.062	4.642	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	10	1	20	59	0.886	-0.082	4.646	0.013	0.01	0	41.7	39.6	71.4	130	124	0	33	32
2014	7	10	1	30	59	0.873	-0.082	4.646	0.01	0.007	0	42.6	39.1	71.4	131	124	0	32	33
2014	7	10	1	40	59	0.86	-0.052	4.646	0.01	0.007	0	41.7	39.1	70.5	130	124	0	33	33
2014	7	10	1	50	59	0.876	-0.085	4.646	0.01	0.007	0	41.7	39.6	68.4	131	124	0	34	32
2014	7	10	2	0	59	0.883	-0.066	4.646	0.01	0.007	0	40.9	39.1	72.2	130	124	0	35	33
2014	7	10	2	10	59	0.876	-0.075	4.649	0.01	0.007	0	41.7	39.6	72.7	131	125	0	34	33
2014	7	10	2	20	59	0.866	-0.059	4.649	0.01	0.007	0	41.7	39.6	72.2	131	125	0	34	33
2014	7	10	2	30	59	0.876	-0.085	4.646	0.01	0.007	0	41.3	39.1	62.8	130	123	0	34	32
2014	7	10	2	40	59	0.863	-0.072	4.649	0.01	0.007	0	41.3	38.3	72.7	129	122	0	33	33
2014	7	10	2	50	59	0.889	-0.056	4.649	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	10	3	0	59	0.899	-0.118	4.649	0.01	0.007	0	40.9	38.7	73.5	129	123	0	34	33
2014	7	10	3	10	59	0.889	-0.082	4.649	0.01	0.007	0	41.3	38.7	73.5	129	123	0	33	33
2014	7	10	3	20	59	0.886	-0.062	4.649	0.01	0.007	0	42.1	39.6	74	132	125	0	34	33
2014	7	10	3	30	59	0.889	-0.072	4.649	0.013	0.01	0	41.3	39.6	72.7	130	124	0	34	32
2014	7	10	3	40	59	0.876	-0.082	4.649	0.01	0.007	0	41.3	39.1	74	130	123	0	34	32
2014	7	10	3	50	59	0.892	-0.085	4.649	0.01	0.007	0	40.9	38.3	74.4	129	123	0	34	34
2014	7	10	4	0	59	0.896	-0.098	4.649	0.01	0.007	0	41.3	38.7	70.1	129	123	0	33	33
2014	7	10	4	10	59	0.869	-0.082	4.649	0.013	0.01	0	41.3	39.1	74	130	124	0	34	33
2014	7	10	4	20	59	0.879	-0.089	4.649	0.01	0.007	0	41.3	39.1	73.5	130	124	0	34	33
2014	7	10	4	30	59	0.889	-0.082	4.649	0.016	0.013	0	41.3	39.1	73.5	130	124	0	34	33
2014	7	10	4	40	59	0.876	-0.085	4.649	0.01	0.007	0	42.1	40	74.4	132	126	0	34	33
2014	7	10	4	50	59	0.869	-0.056	4.649	0.01	0.007	0	43	40.9	73.5	134	127	0	34	32
2014	7	10	5	0	59	0.876	-0.066	4.649	0.01	0.007	0	42.1	40	74	132	126	0	34	33
2014	7	10	5	10	59	0.889	-0.072	4.649	0.013	0.01	0	42.1	40	73.5	132	126	0	34	33
2014	7	10	5	20	59	0.86	-0.082	4.649	0.013	0.01	0	42.6	40	73.5	133	126	0	34	33
2014	7	10	5	30	59	0.886	-0.066	4.652	0.01	0.007	0	42.1	39.6	74.8	132	125	0	34	33
2014	7	10	5	40	59	0.853	-0.075	4.652	0.01	0.007	0	41.7	39.1	74.4	130	124	0	33	33
2014	7	10	5	50	59	0.876	-0.052	4.652	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	10	6	0	59	0.912	-0.056	4.652	0.01	0.007	0	42.1	40	74.8	132	126	0	34	33
2014	7	10	6	10	59	0.837	-0.066	4.652	0.01	0.007	0	42.1	39.6	74.8	132	125	0	34	33
2014	7	10	6	20	59	0.863	-0.046	4.652	0.01	0.007	0	41.7	39.6	75.3	131	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	6	30	59	0.863	-0.079	4.652	0.01	0.007	0	41.7	39.6	75.7	131	125	0	34	33
2014	7	10	6	40	59	0.876	-0.092	4.652	0.01	0.007	0	41.7	39.6	74.8	131	125	0	34	33
2014	7	10	6	50	59	0.863	-0.082	4.652	0.01	0.007	0	42.6	40	75.7	132	126	0	33	33
2014	7	10	7	0	59	0.886	-0.066	4.652	0.01	0.007	0	40.9	38.7	76.1	129	123	0	34	33
2014	7	10	7	10	59	0.869	-0.085	4.652	0.01	0.007	0	40.9	38.7	75.3	129	123	0	34	33
2014	7	10	7	20	59	0.866	-0.098	4.652	0.01	0.007	0	40.4	38.3	75.7	128	123	0	34	34
2014	7	10	7	30	59	0.899	-0.075	4.652	0.01	0.007	0	40.9	38.3	75.7	129	122	0	34	33
2014	7	10	7	40	59	0.869	-0.069	4.652	0.01	0.007	0	40.9	38.7	76.1	129	123	0	34	33
2014	7	10	7	50	59	0.886	-0.072	4.652	0.013	0.01	0	40.9	38.3	76.5	129	122	0	34	33
2014	7	10	8	0	59	0.883	-0.075	4.652	0.013	0.01	0	40.4	38.3	75.7	128	122	0	34	33
2014	7	10	8	10	59	0.853	-0.085	4.652	0.01	0.007	0	40.9	38.7	76.5	129	123	0	34	33
2014	7	10	8	20	59	0.892	-0.069	4.652	0.01	0.007	0	41.3	38.7	76.5	129	123	0	33	33
2014	7	10	8	30	59	0.883	-0.069	4.652	0.013	0.01	0	40.4	38.3	76.5	128	122	0	34	33
2014	7	10	8	40	59	0.853	-0.098	4.652	0.01	0.007	0	40.9	38.3	74.8	128	122	0	33	33
2014	7	10	8	50	59	0.892	-0.098	4.652	0.01	0.007	0	40.4	38.3	76.1	128	122	0	34	33
2014	7	10	9	0	59	0.873	-0.105	4.652	0.01	0.007	0	40.4	38.3	75.3	128	122	0	34	33
2014	7	10	9	10	59	0.912	-0.046	4.652	0.01	0.007	0	40	38.3	75.7	128	122	0	35	33
2014	7	10	9	20	59	0.889	-0.098	4.652	0.01	0.007	0	40.4	38.3	74.8	128	122	0	34	33
2014	7	10	9	30	59	0.886	-0.108	4.652	0.01	0.007	0	40	38.3	76.5	127	122	0	34	33
2014	7	10	9	40	59	0.922	-0.095	4.652	0.01	0.007	0	40	37.8	75.7	127	121	0	34	33
2014	7	10	9	50	59	0.919	-0.135	4.652	0.01	0.007	0	39.6	37.4	74.4	126	120	0	34	33
2014	7	10	10	0	59	0.86	-0.082	4.652	0.01	0.007	0	40	38.3	75.7	127	121	0	34	32
2014	7	10	10	10	59	0.873	-0.115	4.652	0.01	0.007	0	40	37.8	75.3	127	121	0	34	33
2014	7	10	10	20	59	0.863	-0.082	4.652	0.013	0.01	0	40	38.3	75.3	127	121	0	34	32
2014	7	10	10	30	59	0.909	-0.108	4.652	0.013	0.01	0	40	38.3	75.7	128	122	0	35	33
2014	7	10	10	40	59	0.879	-0.079	4.652	0.01	0.007	0	39.6	38.3	74.4	127	122	0	35	33
2014	7	10	10	50	59	0.886	-0.075	4.652	0.01	0.007	0	40.9	38.3	75.3	128	122	0	33	33
2014	7	10	11	0	59	0.915	-0.108	4.652	0.01	0.007	0	40.4	38.3	73.1	128	122	0	34	33
2014	7	10	11	10	59	0.883	-0.125	4.649	0.01	0.007	0	40.9	38.7	63.6	128	122	0	33	32
2014	7	10	11	20	59	0.883	-0.112	4.652	0.01	0.007	0	40.4	37.8	74.4	127	121	0	33	33
2014	7	10	11	30	59	0.886	-0.144	4.649	0.01	0.007	0	40.4	38.3	62.8	128	122	0	34	33
2014	7	10	11	40	59	0.866	-0.138	4.649	0.01	0.007	0	40.4	38.7	71	128	122	0	34	32
2014	7	10	11	50	59	0.889	-0.128	4.649	0.013	0.01	0	39.6	37.4	64.5	126	120	0	34	33
2014	7	10	12	0	59	0.899	-0.125	4.649	0.01	0.007	0	40.4	37.4	66.2	127	120	0	33	33
2014	7	10	12	10	59	0.869	-0.082	4.649	0.01	0.007	0	40	37.8	55.5	127	121	0	34	33
2014	7	10	12	20	59	0.853	-0.144	4.649	0.01	0.007	0	40	37	49.9	127	120	0	34	34
2014	7	10	12	30	59	0.879	-0.154	4.646	0.01	0.007	0	40.4	38.3	52.9	127	121	0	33	32
2014	7	10	12	40	59	0.869	-0.105	4.646	0.01	0.007	0	40.9	39.1	53.3	129	123	0	34	32
2014	7	10	12	50	59	0.856	-0.161	4.649	0.01	0.007	0	41.3	39.1	50.7	130	123	0	34	32
2014	7	10	13	0	59	0.833	-0.171	4.646	0.01	0.007	0	41.3	39.1	49.9	130	124	0	34	33
2014	7	10	13	10	59	0.84	-0.069	4.646	0.01	0.007	0	41.3	39.6	51.6	130	124	0	34	32
2014	7	10	13	20	59	0.876	-0.18	4.646	0.01	0.007	0	41.3	39.1	50.3	130	124	0	34	33
2014	7	10	13	30	59	0.827	-0.108	4.642	0.01	0.007	0	41.3	40	52	130	125	0	34	32
2014	7	10	13	40	59	0.856	-0.112	4.642	0.01	0.007	0	41.7	40	52.5	131	125	0	34	32
2014	7	10	13	50	59	0.863	-0.105	4.639	0.01	0.007	0	41.7	39.6	50.7	131	125	0	34	33
2014	7	10	14	0	59	0.856	-0.112	4.642	0.01	0.007	0	41.3	39.6	51.2	130	124	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	14	10	59	0.85	-0.184	4.639	0.01	0.007	0	41.7	39.6	51.2	131	125	0	34	33
2014	7	10	14	20	59	0.82	-0.118	4.642	0.01	0.007	0	41.7	39.6	49.5	131	125	0	34	33
2014	7	10	14	30	59	0.843	-0.092	4.636	0.01	0.007	0	42.1	40.4	52.5	132	126	0	34	32
2014	7	10	14	40	59	0.86	-0.157	4.642	0.01	0.007	0	41.7	39.6	52	131	125	0	34	33
2014	7	10	14	50	59	0.843	-0.108	4.639	0.01	0.007	0	41.7	40	52.5	131	126	0	34	33
2014	7	10	15	0	59	0.83	-0.135	4.639	0.01	0.007	0	41.7	39.6	49.9	131	125	0	34	33
2014	7	10	15	10	59	0.863	-0.112	4.639	0.01	0.007	0	41.7	39.6	51.2	131	125	0	34	33
2014	7	10	15	20	59	0.85	-0.125	4.642	0.01	0.007	0	41.3	39.1	50.7	130	124	0	34	33
2014	7	10	15	30	59	0.856	-0.177	4.639	0.01	0.007	0	41.3	39.1	49.5	130	124	0	34	33
2014	7	10	15	40	59	0.869	-0.108	4.642	0.013	0.01	0	41.3	39.1	50.7	130	124	0	34	33
2014	7	10	15	50	59	0.883	-0.108	4.639	0.013	0.01	0	41.3	39.6	52.5	130	124	0	34	32
2014	7	10	16	0	59	0.886	-0.148	4.639	0.01	0.007	0	41.7	38.7	49.9	130	123	0	33	33
2014	7	10	16	10	59	0.896	-0.18	4.636	0.01	0.007	0	40.9	38.7	50.7	129	123	0	34	33
2014	7	10	16	20	59	0.892	-0.108	4.639	0.01	0.007	0	41.3	39.1	52	130	124	0	34	33
2014	7	10	16	30	59	0.876	-0.141	4.636	0.01	0.007	0	40.9	39.1	52	129	123	0	34	32
2014	7	10	16	40	59	0.869	-0.098	4.636	0.01	0.007	0	40.9	38.7	52.9	129	122	0	34	32
2014	7	10	16	50	59	0.856	-0.108	4.636	0.01	0.007	0	40.9	38.7	51.6	129	123	0	34	33
2014	7	10	17	0	59	0.879	-0.164	4.636	0.01	0.007	0	40.4	38.3	51.6	128	122	0	34	33
2014	7	10	17	10	59	0.886	-0.105	4.639	0.01	0.007	0	40.9	38.7	50.7	129	123	0	34	33
2014	7	10	17	20	59	0.902	-0.128	4.636	0.01	0.007	0	40.9	38.3	52.5	129	122	0	34	33
2014	7	10	17	30	59	0.876	-0.115	4.636	0.01	0.007	0	41.3	39.1	51.2	129	123	0	33	32
2014	7	10	17	40	59	0.889	-0.128	4.633	0.01	0.007	0	40.9	38.7	52	129	123	0	34	33
2014	7	10	17	50	59	0.889	-0.144	4.633	0.01	0.007	0	40.9	38.7	51.6	129	123	0	34	33
2014	7	10	18	0	59	0.889	-0.128	4.633	0.01	0.007	0	40.9	39.1	52	129	123	0	34	32
2014	7	10	18	10	59	0.869	-0.085	4.633	0.01	0.007	0	40.9	39.1	53.8	129	123	0	34	32
2014	7	10	18	20	59	0.892	-0.141	4.629	0.013	0.01	0	40.4	38.7	50.3	129	123	0	35	33
2014	7	10	18	30	59	0.879	-0.148	4.629	0.01	0.007	0	41.3	38.7	52.9	129	122	0	33	32
2014	7	10	18	40	59	0.896	-0.089	4.629	0.01	0.007	0	41.3	39.1	52.5	129	123	0	33	32
2014	7	10	18	50	59	0.886	-0.121	4.629	0.01	0.007	0	40.9	38.7	52.9	128	122	0	33	32
2014	7	10	19	0	59	0.86	-0.102	4.633	0.01	0.007	0	40.9	38.7	52.5	129	123	0	34	33
2014	7	10	19	10	59	0.892	-0.167	4.633	0.013	0.01	0	40.4	38.7	49.5	128	122	0	34	32
2014	7	10	19	20	59	0.873	-0.105	4.629	0.01	0.007	0	40.9	38.7	53.8	129	123	0	34	33
2014	7	10	19	30	59	0.869	-0.154	4.629	0.01	0.007	0	40.9	38.7	61.5	129	123	0	34	33
2014	7	10	19	40	59	0.879	-0.105	4.629	0.01	0.007	0	40.9	38.7	64.9	129	123	0	34	33
2014	7	10	19	50	59	0.886	-0.082	4.629	0.01	0.007	0	41.7	40	58	131	125	0	34	32
2014	7	10	20	0	59	0.899	-0.141	4.629	0.01	0.007	0	41.3	39.1	59.8	130	124	0	34	33
2014	7	10	20	10	59	0.896	-0.115	4.633	0.01	0.007	0	41.7	39.1	54.2	130	124	0	33	33
2014	7	10	20	20	59	0.876	-0.115	4.633	0.01	0.007	0	41.7	39.6	55	130	124	0	33	32
2014	7	10	20	30	59	0.86	-0.102	4.633	0.01	0.007	0	41.3	39.6	52	131	125	0	35	33
2014	7	10	20	40	59	0.846	-0.023	4.639	0.01	0.007	0	43	41.3	52	134	128	0	34	32
2014	7	10	20	50	59	0.869	-0.072	4.636	0.01	0.007	0	42.6	40.4	51.2	133	127	0	34	33
2014	7	10	21	0	59	0.886	-0.098	4.633	0.01	0.007	0	42.6	40.4	52	132	126	0	33	32
2014	7	10	21	10	59	0.873	-0.079	4.633	0.01	0.007	0	42.6	40	51.6	133	126	0	34	33
2014	7	10	21	20	59	0.856	-0.066	4.639	0.013	0.01	0	42.1	39.6	52.9	132	125	0	34	33
2014	7	10	21	30	59	0.883	-0.085	4.636	0.01	0.007	0	42.6	40.4	50.7	133	127	0	34	33
2014	7	10	21	40	59	0.863	-0.072	4.639	0.01	0.007	0	41.7	40	51.6	131	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	21	50	59	0.879	-0.089	4.636	0.01	0.007	0	41.7	40	52.5	131	126	0	34	33
2014	7	10	22	0	59	0.879	-0.095	4.633	0.01	0.007	0	41.7	39.6	53.8	131	125	0	34	33
2014	7	10	22	10	59	0.863	-0.098	4.633	0.01	0.007	0	41.7	39.1	64.5	131	125	0	34	34
2014	7	10	22	20	59	0.886	-0.112	4.636	0.01	0.007	0	41.3	39.1	58	130	124	0	34	33
2014	7	10	22	30	59	0.886	-0.095	4.636	0.01	0.007	0	41.7	39.1	61.1	131	124	0	34	33
2014	7	10	22	40	59	0.853	-0.095	4.636	0.01	0.007	0	41.3	39.1	65.8	130	124	0	34	33
2014	7	10	22	50	59	0.883	-0.069	4.636	0.01	0.007	0	41.7	39.1	64.5	131	124	0	34	33
2014	7	10	23	0	59	0.883	-0.108	4.636	0.01	0.007	0	40.9	38.7	56.3	129	123	0	34	33
2014	7	10	23	10	59	0.883	-0.075	4.639	0.01	0.007	0	40.9	38.7	58	129	123	0	34	33
2014	7	10	23	20	59	0.883	-0.112	4.636	0.01	0.007	0	40.9	38.7	58	129	123	0	34	33
2014	7	10	23	30	59	0.886	-0.102	4.639	0.01	0.007	0	40.9	38.3	58.9	129	123	0	34	34
2014	7	10	23	40	59	0.902	-0.066	4.639	0.01	0.007	0	41.7	39.1	65.4	130	124	0	33	33
2014	7	10	23	50	59	0.902	-0.079	4.642	0.01	0.007	0	40.9	39.1	71.8	129	123	0	34	32
2014	7	11	0	0	59	0.902	-0.098	4.642	0.01	0.007	0	40.9	39.1	70.5	129	122	0	34	31
2014	7	11	0	10	59	0.886	-0.056	4.642	0.01	0.007	0	40.4	39.1	71	129	123	0	35	32
2014	7	11	0	20	59	0.879	-0.066	4.642	0.01	0.007	0	40.9	38.7	72.2	129	123	0	34	33
2014	7	11	0	30	59	0.863	-0.098	4.642	0.01	0.007	0	40.9	38.3	72.2	129	122	0	34	33
2014	7	11	0	40	59	0.899	-0.092	4.642	0.01	0.007	0	40.9	38.3	72.7	129	122	0	34	33
2014	7	11	0	50	59	0.863	-0.115	4.642	0.01	0.007	0	40.9	39.1	70.5	129	123	0	34	32
2014	7	11	1	0	59	0.843	-0.059	4.642	0.01	0.007	0	40.9	38.3	71.4	128	122	0	33	33
2014	7	11	1	10	59	0.889	-0.079	4.646	0.01	0.007	0	40.9	38.3	71.4	129	122	0	34	33
2014	7	11	1	20	59	0.892	-0.102	4.646	0.01	0.007	0	40.9	39.1	69.2	129	123	0	34	32
2014	7	11	1	30	59	0.912	-0.079	4.646	0.01	0.007	0	40.9	38.7	73.5	129	123	0	34	33
2014	7	11	1	40	59	0.856	-0.072	4.646	0.013	0.01	0	41.3	39.1	71.8	130	124	0	34	33
2014	7	11	1	50	59	0.866	-0.085	4.646	0.01	0.007	0	40.9	39.1	74.4	129	124	0	34	33
2014	7	11	2	0	59	0.866	-0.092	4.649	0.01	0.007	0	41.3	38.7	73.5	130	123	0	34	33
2014	7	11	2	10	59	0.889	-0.089	4.649	0.013	0.01	0	41.3	38.7	70.5	129	123	0	33	33
2014	7	11	2	20	59	0.896	-0.095	4.649	0.01	0.007	0	41.3	39.1	72.7	130	124	0	34	33
2014	7	11	2	30	59	0.879	-0.082	4.652	0.01	0.007	0	41.7	39.1	76.1	130	124	0	33	33
2014	7	11	2	40	59	0.892	-0.069	4.652	0.01	0.007	0	41.7	38.7	73.5	130	123	0	33	33
2014	7	11	2	50	59	0.85	-0.075	4.652	0.01	0.007	0	41.7	39.6	76.1	131	125	0	34	33
2014	7	11	3	0	59	0.86	-0.066	4.652	0.01	0.007	0	40.9	38.3	77	129	122	0	34	33
2014	7	11	3	10	59	0.86	-0.059	4.652	0.01	0.007	0	41.3	38.7	76.5	130	123	0	34	33
2014	7	11	3	20	59	0.886	-0.089	4.652	0.013	0.01	0	40.4	38.7	76.5	129	123	0	35	33
2014	7	11	3	30	59	0.853	-0.075	4.652	0.01	0.007	0	41.7	39.6	75.7	131	125	0	34	33
2014	7	11	3	40	59	0.866	-0.075	4.656	0.01	0.007	0	41.3	39.1	76.1	130	124	0	34	33
2014	7	11	3	50	59	0.866	-0.049	4.656	0.007	0.007	0	41.3	39.1	75.3	130	124	0	34	33
2014	7	11	4	0	59	0.879	-0.072	4.656	0.01	0.007	0	41.3	39.1	75.7	130	124	0	34	33
2014	7	11	4	10	59	0.883	-0.066	4.656	0.013	0.01	0	41.3	39.1	75.7	130	124	0	34	33
2014	7	11	4	20	59	0.856	-0.089	4.656	0.01	0.007	0	43.4	41.7	71.8	135	129	0	34	32
2014	7	11	4	30	59	0.866	-0.089	4.656	0.01	0.007	0	41.3	39.1	74.8	130	124	0	34	33
2014	7	11	4	40	59	0.899	-0.082	4.656	0.01	0.007	0	41.3	39.1	75.7	130	124	0	34	33
2014	7	11	4	50	59	0.883	-0.066	4.656	0.01	0.007	0	42.1	39.6	75.3	131	125	0	33	33
2014	7	11	5	0	59	0.889	-0.056	4.656	0.01	0.007	0	42.1	40.4	75.7	132	126	0	34	32
2014	7	11	5	10	59	0.866	-0.066	4.656	0.01	0.007	0	41.7	39.6	74.8	131	125	0	34	33
2014	7	11	5	20	59	0.879	-0.082	4.656	0.01	0.007	0	41.7	39.6	74.8	131	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	5	30	59	0.899	-0.098	4.656	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	11	5	40	59	0.853	-0.069	4.656	0.01	0.007	0	41.3	39.1	75.3	130	124	0	34	33
2014	7	11	5	50	59	0.879	-0.082	4.656	0.01	0.007	0	40.9	38.3	75.3	129	123	0	34	34
2014	7	11	6	0	59	0.879	-0.098	4.656	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	11	6	10	59	0.853	-0.059	4.656	0.013	0.01	0	42.6	40	74.4	133	126	0	34	33
2014	7	11	6	20	59	0.873	-0.072	4.656	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	11	6	30	59	0.899	-0.079	4.656	0.01	0.007	0	40.4	38.7	75.3	128	122	0	34	32
2014	7	11	6	40	59	0.866	-0.049	4.656	0.01	0.007	0	41.3	38.7	74.8	130	124	0	34	34
2014	7	11	6	50	59	0.879	-0.089	4.656	0.01	0.007	0	41.3	39.6	74.4	131	125	0	35	33
2014	7	11	7	0	59	0.863	-0.072	4.656	0.01	0.007	0	41.7	39.1	74.8	131	124	0	34	33
2014	7	11	7	10	59	0.876	-0.052	4.656	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	11	7	20	59	0.899	-0.092	4.656	0.01	0.007	0	40.4	38.3	74.4	128	122	0	34	33
2014	7	11	7	30	59	0.892	-0.092	4.656	0.01	0.007	0	40.9	38.7	70.5	129	123	0	34	33
2014	7	11	7	40	59	0.869	-0.102	4.656	0.01	0.007	0	40.4	37.8	71	128	121	0	34	33
2014	7	11	7	50	59	0.866	-0.095	4.656	0.01	0.007	0	40	37.8	73.1	127	121	0	34	33
2014	7	11	8	0	59	0.896	-0.108	4.656	0.016	0.013	0	40	37.8	73.1	127	121	0	34	33
2014	7	11	8	10	59	0.896	-0.131	4.656	0.01	0.007	0	40	37.4	73.5	127	120	0	34	33
2014	7	11	8	20	59	0.892	-0.112	4.656	0.01	0.007	0	40	37.8	74.4	127	121	0	34	33
2014	7	11	8	30	59	0.889	-0.112	4.656	0.01	0.007	0	40	38.3	74	127	121	0	34	32
2014	7	11	8	40	59	0.889	-0.138	4.656	0.013	0.01	0	40.4	38.3	72.7	128	121	0	34	32
2014	7	11	8	50	59	0.879	-0.079	4.656	0.01	0.007	0	40.4	38.3	69.2	128	122	0	34	33
2014	7	11	9	0	59	0.873	-0.115	4.656	0.01	0.007	0	40.4	38.3	62.8	128	122	0	34	33
2014	7	11	9	10	59	0.879	-0.085	4.656	0.01	0.007	0	40.4	38.3	60.6	128	122	0	34	33
2014	7	11	9	20	59	0.883	-0.089	4.656	0.01	0.007	0	40.4	38.7	70.5	129	123	0	35	33
2014	7	11	9	30	59	0.889	-0.105	4.656	0.01	0.007	0	40.4	38.7	74	128	122	0	34	32
2014	7	11	9	40	59	0.912	-0.105	4.656	0.01	0.007	0	40.9	38.7	67.9	129	123	0	34	33
2014	7	11	9	50	59	0.883	-0.121	4.656	0.01	0.007	0	40.9	39.1	70.1	129	123	0	34	32
2014	7	11	10	0	59	0.863	-0.131	4.656	0.01	0.007	0	40.9	39.1	62.8	129	123	0	34	32
2014	7	11	10	10	59	0.879	-0.131	4.656	0.01	0.007	0	40.4	38.3	71	128	122	0	34	33
2014	7	11	10	20	59	0.879	-0.128	4.656	0.01	0.007	0	40.4	38.7	72.7	128	122	0	34	32
2014	7	11	10	30	59	0.886	-0.125	4.656	0.01	0.007	0	40.4	38.3	74	128	122	0	34	33
2014	7	11	10	40	59	0.896	-0.125	4.656	0.01	0.007	0	40.4	38.3	75.7	128	122	0	34	33
2014	7	11	10	50	59	0.906	-0.105	4.656	0.01	0.007	0	40.4	37.8	74.4	128	121	0	34	33
2014	7	11	11	0	59	0.873	-0.112	4.652	0.01	0.007	0	40.9	38.3	72.7	129	122	0	34	33
2014	7	11	11	10	59	0.866	-0.092	4.656	0.01	0.007	0	40.9	38.3	73.5	128	122	0	33	33
2014	7	11	11	20	59	0.866	-0.125	4.656	0.01	0.007	0	40	37.8	64.1	127	121	0	34	33
2014	7	11	11	30	59	0.896	-0.177	4.652	0.01	0.007	0	40.4	38.7	56.3	128	122	0	34	32
2014	7	11	11	40	59	0.863	-0.121	4.656	0.013	0.01	0	40.4	37.4	54.6	128	121	0	34	34
2014	7	11	11	50	59	0.837	-0.167	4.652	0.01	0.007	0	40.4	38.3	50.7	128	122	0	34	33
2014	7	11	12	0	59	0.846	-0.161	4.656	0.01	0.007	0	41.3	38.3	53.8	129	122	0	33	33
2014	7	11	12	10	59	0.879	-0.131	4.652	0.013	0.01	0	40.4	38.7	52.9	128	122	0	34	32
2014	7	11	12	20	59	0.843	-0.157	4.656	0.01	0.007	0	40.4	38.3	50.3	128	122	0	34	33
2014	7	11	12	30	59	0.873	-0.121	4.652	0.01	0.007	0	40.9	38.7	51.6	129	123	0	34	33
2014	7	11	12	40	59	0.883	-0.115	4.652	0.01	0.007	0	40.4	38.3	53.3	128	122	0	34	33
2014	7	11	12	50	59	0.873	-0.177	4.652	0.01	0.007	0	40.9	39.1	54.6	129	123	0	34	32
2014	7	11	13	0	59	0.85	-0.161	4.652	0.013	0.01	0	40.9	38.3	50.3	129	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	13	10	59	0.86	-0.184	4.652	0.01	0.007	0	40.9	38.7	54.2	129	123	0	34	33
2014	7	11	13	20	59	0.853	-0.135	4.652	0.01	0.007	0	40.9	38.7	52	129	123	0	34	33
2014	7	11	13	30	59	0.879	-0.098	4.652	0.01	0.007	0	40.9	38.7	52.5	129	123	0	34	33
2014	7	11	13	40	59	0.899	-0.095	4.652	0.01	0.007	0	41.3	39.1	49.9	130	124	0	34	33
2014	7	11	13	50	59	0.846	-0.154	4.649	0.013	0.01	0	41.3	38.3	55.5	129	122	0	33	33
2014	7	11	14	0	59	0.86	-0.164	4.649	0.01	0.007	0	40.9	38.3	50.3	129	122	0	34	33
2014	7	11	14	10	59	0.853	-0.098	4.652	0.01	0.007	0	40.9	38.7	50.3	129	123	0	34	33
2014	7	11	14	20	59	0.873	-0.177	4.649	0.01	0.007	0	40.9	38.3	53.8	129	122	0	34	33
2014	7	11	14	30	59	0.873	-0.161	4.649	0.01	0.007	0	40.9	38.3	51.2	129	122	0	34	33
2014	7	11	14	40	59	0.866	-0.131	4.649	0.01	0.007	0	40.9	38.3	52.9	129	122	0	34	33
2014	7	11	14	50	59	0.883	-0.131	4.649	0.01	0.007	0	41.3	38.3	52	129	122	0	33	33
2014	7	11	15	0	59	0.843	-0.157	4.649	0.01	0.007	0	41.3	38.7	51.6	129	122	0	33	32
2014	7	11	15	10	59	0.85	-0.092	4.646	0.01	0.007	0	41.3	38.7	52	130	123	0	34	33
2014	7	11	15	20	59	0.866	-0.131	4.646	0.01	0.007	0	41.3	38.7	50.7	130	123	0	34	33
2014	7	11	15	30	59	0.866	-0.151	4.646	0.01	0.007	0	41.3	38.7	50.7	130	123	0	34	33
2014	7	11	15	40	59	0.876	-0.157	4.649	0.01	0.007	0	41.3	38.7	50.7	130	123	0	34	33
2014	7	11	15	50	59	0.866	-0.135	4.646	0.013	0.01	0	41.3	38.7	50.7	130	123	0	34	33
2014	7	11	16	0	59	0.886	-0.102	4.646	0.01	0.007	0	41.7	38.7	52.9	130	123	0	33	33
2014	7	11	16	10	59	0.883	-0.151	4.646	0.01	0.007	0	42.1	38.7	49	131	123	0	33	33
2014	7	11	16	20	59	0.843	-0.157	4.646	0.01	0.007	0	41.3	38.7	52.5	130	122	0	34	32
2014	7	11	16	30	59	0.886	-0.121	4.646	0.01	0.007	0	40.9	37.8	52.9	129	122	0	34	34
2014	7	11	16	40	59	0.889	-0.138	4.642	0.01	0.007	0	40.9	38.3	52	129	122	0	34	33
2014	7	11	16	50	59	0.869	-0.085	4.646	0.01	0.007	0	42.6	39.6	49.9	133	126	0	34	34
2014	7	11	17	0	59	0.863	-0.128	4.642	0.01	0.007	0	41.3	39.1	50.3	130	123	0	34	32
2014	7	11	17	10	59	0.892	-0.102	4.642	0.01	0.007	0	40.9	38.3	51.2	129	122	0	34	33
2014	7	11	17	20	59	0.909	-0.085	4.642	0.01	0.007	0	46.9	43.9	50.7	143	134	0	34	32
2014	7	11	17	30	59	0.873	-0.128	4.642	0.013	0.01	0	41.7	39.1	49.9	131	124	0	34	33
2014	7	11	17	40	59	0.86	-0.151	4.642	0.01	0.007	0	41.7	40	51.6	131	125	0	34	32
2014	7	11	17	50	59	0.886	-0.105	4.646	0.01	0.007	0	40.9	38.3	54.6	129	122	0	34	33
2014	7	11	18	0	59	0.853	-0.115	4.642	0.01	0.007	0	42.6	39.6	50.3	133	125	0	34	33
2014	7	11	18	10	59	0.863	-0.112	4.642	0.01	0.007	0	41.3	38.7	52.5	129	122	0	33	32
2014	7	11	18	20	59	0.869	-0.118	4.642	0.01	0.007	0	41.3	38.3	51.2	129	122	0	33	33
2014	7	11	18	30	59	0.866	-0.148	4.642	0.01	0.007	0	40.4	38.3	52.9	128	121	0	34	32
2014	7	11	18	40	59	0.879	-0.131	4.642	0.01	0.007	0	40.9	37.8	54.2	129	121	0	34	33
2014	7	11	18	50	59	0.869	-0.108	4.642	0.01	0.007	0	40.9	37.8	59.8	129	122	0	34	34
2014	7	11	19	0	59	0.899	-0.115	4.642	0.01	0.007	0	40.9	38.3	56.8	129	122	0	34	33
2014	7	11	19	10	59	0.886	-0.131	4.642	0.01	0.007	0	41.3	38.3	62.8	130	122	0	34	33
2014	7	11	19	20	59	0.879	-0.105	4.636	0.01	0.007	0	44.3	41.3	49.5	137	129	0	34	33
2014	7	11	19	30	59	0.873	-0.095	4.642	0.01	0.007	0	40.9	38.3	52.9	129	122	0	34	33
2014	7	11	19	40	59	0.863	-0.128	4.646	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2014	7	11	19	50	59	0.899	-0.082	4.646	0.01	0.007	0	41.3	39.1	58	130	123	0	34	32
2014	7	11	20	0	59	0.906	-0.089	4.646	0.01	0.007	0	41.7	39.1	62.8	131	124	0	34	33
2014	7	11	20	10	59	0.886	-0.112	4.646	0.01	0.007	0	41.7	39.1	68.4	131	124	0	34	33
2014	7	11	20	20	59	0.902	-0.112	4.646	0.01	0.007	0	41.7	39.1	73.1	131	124	0	34	33
2014	7	11	20	30	59	0.876	-0.085	4.646	0.013	0.01	0	42.6	40	71	133	126	0	34	33
2014	7	11	20	40	59	0.902	-0.062	4.646	0.01	0.007	0	42.1	40	64.5	132	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	20	50	59	0.892	-0.108	4.646	0.01	0.007	0	42.6	40	62.8	132	126	0	33	33
2014	7	11	21	0	59	0.886	-0.112	4.646	0.013	0.01	0	42.1	39.1	61.9	132	124	0	34	33
2014	7	11	21	10	59	0.869	-0.079	4.646	0.01	0.007	0	41.7	39.6	71.8	131	124	0	34	32
2014	7	11	21	20	59	0.866	-0.075	4.649	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	11	21	30	59	0.883	-0.092	4.649	0.01	0.007	0	41.7	39.1	71.8	131	124	0	34	33
2014	7	11	21	40	59	0.853	-0.069	4.649	0.013	0.01	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	11	21	50	59	0.883	-0.098	4.649	0.01	0.007	0	41.3	39.1	68.8	130	123	0	34	32
2014	7	11	22	0	59	0.915	-0.092	4.649	0.01	0.007	0	41.3	38.7	69.2	130	123	0	34	33
2014	7	11	22	10	59	0.886	-0.112	4.649	0.01	0.007	0	41.7	39.6	73.1	131	124	0	34	32
2014	7	11	22	20	59	0.863	-0.066	4.649	0.01	0.007	0	41.7	39.1	75.7	131	123	0	34	32
2014	7	11	22	30	59	0.86	-0.108	4.649	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	11	22	40	59	0.866	-0.089	4.649	0.013	0.01	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	11	22	50	59	0.86	-0.066	4.649	0.01	0.007	0	41.7	39.1	76.5	131	124	0	34	33
2014	7	11	23	0	59	0.853	-0.098	4.649	0.01	0.007	0	41.3	38.3	76.5	130	122	0	34	33
2014	7	11	23	10	59	0.86	-0.085	4.649	0.01	0.007	0	41.3	39.1	76.5	130	123	0	34	32
2014	7	11	23	20	59	0.856	-0.072	4.649	0.01	0.007	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	11	23	30	59	0.886	-0.098	4.649	0.01	0.007	0	41.7	39.6	74	131	124	0	34	32
2014	7	11	23	40	59	0.86	-0.092	4.649	0.01	0.007	0	41.7	39.6	75.3	131	124	0	34	32
2014	7	11	23	50	59	0.889	-0.066	4.649	0.01	0.007	0	42.1	39.1	76.5	131	124	0	33	33
2014	7	12	0	0	59	0.869	-0.075	4.652	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	12	0	10	59	0.856	-0.095	4.652	0.01	0.007	0	42.1	39.6	76.1	132	124	0	34	32
2014	7	12	0	20	59	0.869	-0.085	4.652	0.01	0.007	0	42.1	39.1	76.5	131	124	0	33	33
2014	7	12	0	30	59	0.85	-0.079	4.652	0.01	0.007	0	41.7	39.1	77	131	124	0	34	33
2014	7	12	0	40	59	0.876	-0.098	4.652	0.013	0.01	0	41.7	39.6	74.4	131	124	0	34	32
2014	7	12	0	50	59	0.879	-0.066	4.652	0.01	0.007	0	42.1	39.6	76.1	132	125	0	34	33
2014	7	12	1	0	59	0.876	-0.092	4.652	0.01	0.007	0	42.6	39.6	74.4	132	125	0	33	33
2014	7	12	1	10	59	0.85	-0.098	4.652	0.01	0.007	0	41.7	39.1	76.1	132	124	0	35	33
2014	7	12	1	20	59	0.896	-0.079	4.652	0.01	0.007	0	41.7	39.6	77	131	124	0	34	32
2014	7	12	1	30	59	0.866	-0.079	4.652	0.013	0.01	0	42.1	39.1	76.5	132	124	0	34	33
2014	7	12	1	40	59	0.843	-0.092	4.652	0.01	0.007	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	12	1	50	59	0.879	-0.105	4.652	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	12	2	0	59	0.873	-0.082	4.652	0.01	0.007	0	41.3	39.1	73.1	131	124	0	35	33
2014	7	12	2	10	59	0.889	-0.095	4.652	0.01	0.007	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	12	2	20	59	0.846	-0.072	4.652	0.01	0.007	0	41.3	39.1	76.1	130	124	0	34	33
2014	7	12	2	30	59	0.883	-0.072	4.652	0.01	0.007	0	41.7	39.1	76.5	131	124	0	34	33
2014	7	12	2	40	59	0.879	-0.092	4.652	0.01	0.007	0	41.3	38.7	76.5	130	123	0	34	33
2014	7	12	2	50	59	0.876	-0.092	4.652	0.01	0.007	0	42.1	39.6	76.1	132	125	0	34	33
2014	7	12	3	0	59	0.879	-0.098	4.652	0.01	0.007	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	12	3	10	59	0.902	-0.102	4.652	0.01	0.007	0	42.1	39.6	75.3	132	125	0	34	33
2014	7	12	3	20	59	0.889	-0.089	4.652	0.01	0.007	0	41.7	38.7	73.5	131	124	0	34	34
2014	7	12	3	30	59	0.866	-0.062	4.652	0.01	0.007	0	41.7	38.7	75.7	131	124	0	34	34
2014	7	12	3	40	59	0.879	-0.072	4.652	0.01	0.007	0	42.1	39.1	66.7	132	124	0	34	33
2014	7	12	3	50	59	0.833	-0.079	4.652	0.01	0.007	0	42.6	40	73.5	133	126	0	34	33
2014	7	12	4	0	59	0.896	-0.082	4.652	0.01	0.007	0	42.6	40	74.8	132	125	0	33	32
2014	7	12	4	10	59	0.879	-0.072	4.652	0.01	0.007	0	43	40	75.3	133	126	0	33	33
2014	7	12	4	20	59	0.879	-0.066	4.652	0.01	0.007	0	42.6	40	72.2	133	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	4	30	59	0.853	-0.075	4.652	0.01	0.007	0	42.1	40	75.3	133	127	0	35	34
2014	7	12	4	40	59	0.863	-0.033	4.652	0.013	0.01	0	42.6	40	75.3	133	126	0	34	33
2014	7	12	4	50	59	0.833	-0.056	4.652	0.01	0.007	0	43	40.9	74.8	134	128	0	34	33
2014	7	12	5	0	59	0.883	-0.079	4.652	0.01	0.007	0	43	40.4	75.3	134	127	0	34	33
2014	7	12	5	10	59	0.889	-0.082	4.652	0.01	0.007	0	43	40.4	74.8	134	127	0	34	33
2014	7	12	5	20	59	0.896	-0.059	4.652	0.01	0.007	0	43	40.4	74.8	134	127	0	34	33
2014	7	12	5	30	59	0.889	-0.062	4.652	0.01	0.007	0	42.6	40.9	74.4	133	127	0	34	32
2014	7	12	5	40	59	0.876	-0.095	4.652	0.01	0.007	0	42.1	39.6	74.4	132	126	0	34	34
2014	7	12	5	50	59	0.892	-0.049	4.652	0.01	0.007	0	41.7	39.6	74.8	131	124	0	34	32
2014	7	12	6	0	59	0.873	-0.082	4.652	0.01	0.007	0	41.7	39.1	74	131	124	0	34	33
2014	7	12	6	10	59	0.879	-0.049	4.656	0.01	0.007	0	42.1	39.6	74	132	125	0	34	33
2014	7	12	6	20	59	0.879	-0.066	4.656	0.01	0.007	0	41.7	39.1	74.8	131	124	0	34	33
2014	7	12	6	30	59	0.85	-0.072	4.656	0.01	0.007	0	41.7	39.1	74	131	124	0	34	33
2014	7	12	6	40	59	0.879	-0.102	4.656	0.01	0.007	0	41.7	39.1	74.4	131	124	0	34	33
2014	7	12	6	50	59	0.873	-0.092	4.656	0.01	0.007	0	41.7	39.6	74	131	124	0	34	32
2014	7	12	7	0	59	0.856	-0.098	4.656	0.013	0.01	0	41.3	39.1	74.4	130	123	0	34	32
2014	7	12	7	10	59	0.863	-0.079	4.656	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	12	7	20	59	0.883	-0.095	4.656	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	12	7	30	59	0.892	-0.098	4.656	0.01	0.007	0	41.3	38.7	73.5	130	122	0	34	32
2014	7	12	7	40	59	0.866	-0.089	4.656	0.013	0.01	0	40.4	39.1	74	129	123	0	35	32
2014	7	12	7	50	59	0.866	-0.098	4.656	0.013	0.01	0	41.3	38.7	74	130	123	0	34	33
2014	7	12	8	0	59	0.856	-0.098	4.656	0.01	0.007	0	41.7	38.7	74	130	124	0	33	34
2014	7	12	8	10	59	0.856	-0.125	4.656	0.013	0.01	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	8	20	59	0.863	-0.115	4.656	0.01	0.007	0	41.3	39.1	73.5	130	124	0	34	33
2014	7	12	8	30	59	0.873	-0.085	4.656	0.01	0.007	0	41.3	39.1	74.4	130	123	0	34	32
2014	7	12	8	40	59	0.886	-0.085	4.656	0.016	0.013	0	41.3	38.7	73.5	130	123	0	34	33
2014	7	12	8	50	59	0.846	-0.108	4.656	0.01	0.007	0	41.3	38.7	73.5	130	123	0	34	33
2014	7	12	9	0	59	0.86	-0.095	4.652	0.01	0.007	0	41.3	38.3	72.7	130	123	0	34	34
2014	7	12	9	10	59	0.869	-0.075	4.656	0.013	0.01	0	41.3	39.1	73.1	130	124	0	34	33
2014	7	12	9	20	59	0.876	-0.092	4.652	0.013	0.01	0	40.9	39.1	74.4	130	124	0	35	33
2014	7	12	9	30	59	0.856	-0.095	4.656	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	12	9	40	59	0.866	-0.098	4.656	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	9	50	59	0.879	-0.069	4.656	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	10	0	59	0.889	-0.095	4.652	0.01	0.007	0	40.9	38.3	74.4	129	122	0	34	33
2014	7	12	10	10	59	0.866	-0.082	4.652	0.013	0.01	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	10	20	59	0.892	-0.092	4.652	0.01	0.007	0	40.9	38.3	73.5	129	122	0	34	33
2014	7	12	10	30	59	0.866	-0.062	4.652	0.01	0.007	0	40.9	38.7	74.4	129	123	0	34	33
2014	7	12	10	40	59	0.879	-0.102	4.652	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	10	50	59	0.86	-0.095	4.652	0.013	0.01	0	40.9	38.7	74	129	123	0	34	33
2014	7	12	11	0	59	0.889	-0.082	4.652	0.01	0.007	0	41.3	39.1	72.2	130	124	0	34	33
2014	7	12	11	10	59	0.889	-0.148	4.652	0.01	0.007	0	40.4	37.8	73.1	128	121	0	34	33
2014	7	12	11	20	59	0.892	-0.085	4.652	0.01	0.007	0	41.3	38.7	74.8	130	123	0	34	33
2014	7	12	11	30	59	0.915	-0.131	4.652	0.01	0.007	0	40.9	38.7	71.4	129	123	0	34	33
2014	7	12	11	40	59	0.876	-0.121	4.652	0.01	0.007	0	41.3	39.1	69.7	130	124	0	34	33
2014	7	12	11	50	59	0.902	-0.102	4.652	0.01	0.007	0	40.4	38.3	73.5	129	122	0	35	33
2014	7	12	12	0	59	0.886	-0.131	4.652	0.01	0.007	0	40.9	38.7	75.3	129	122	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	12	10	59	0.892	-0.177	4.652	0.013	0.01	0	40	37.8	58.5	127	120	0	34	32
2014	7	12	12	20	59	0.876	-0.148	4.652	0.01	0.007	0	40.4	37.8	73.1	128	121	0	34	33
2014	7	12	12	30	59	0.896	-0.089	4.652	0.01	0.007	0	40.4	37.8	64.5	128	121	0	34	33
2014	7	12	12	40	59	0.876	-0.118	4.652	0.01	0.007	0	40.4	38.3	56.3	128	122	0	34	33
2014	7	12	12	50	59	0.912	-0.112	4.652	0.01	0.007	0	40.9	38.7	67.5	129	123	0	34	33
2014	7	12	13	0	59	0.912	-0.128	4.652	0.01	0.007	0	40.9	38.7	75.3	129	123	0	34	33
2014	7	12	13	10	59	0.909	-0.135	4.652	0.01	0.007	0	41.3	38.7	74.8	130	123	0	34	33
2014	7	12	13	20	59	0.912	-0.118	4.652	0.01	0.007	0	40.9	38.7	69.7	129	123	0	34	33
2014	7	12	13	30	59	0.883	-0.131	4.652	0.01	0.007	0	41.3	39.1	75.7	130	124	0	34	33
2014	7	12	13	40	59	0.902	-0.131	4.652	0.013	0.01	0	40.9	37.8	72.2	129	122	0	34	34
2014	7	12	13	50	59	0.899	-0.144	4.652	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	12	14	0	59	0.863	-0.082	4.652	0.01	0.007	0	41.3	39.1	59.8	130	124	0	34	33
2014	7	12	14	10	59	0.886	-0.157	4.649	0.01	0.007	0	40.9	38.7	72.2	129	123	0	34	33
2014	7	12	14	20	59	0.886	-0.108	4.652	0.01	0.007	0	40.9	39.1	69.2	130	124	0	35	33
2014	7	12	14	30	59	0.899	-0.121	4.649	0.01	0.007	0	40.9	38.7	58	129	123	0	34	33
2014	7	12	14	40	59	0.879	-0.154	4.649	0.01	0.007	0	40.4	38.7	65.4	128	122	0	34	32
2014	7	12	14	50	59	0.928	-0.089	4.649	0.01	0.007	0	41.3	38.3	58.9	130	123	0	34	34
2014	7	12	15	0	59	0.866	-0.148	4.649	0.01	0.007	0	40.4	37.8	55.9	128	121	0	34	33
2014	7	12	15	10	59	0.889	-0.144	4.649	0.01	0.007	0	40.4	38.3	74.4	128	122	0	34	33
2014	7	12	15	20	59	0.896	-0.187	4.649	0.01	0.007	0	40.9	37.8	64.5	129	122	0	34	34
2014	7	12	15	30	59	0.883	-0.128	4.649	0.01	0.007	0	40.9	39.1	65.4	129	123	0	34	32
2014	7	12	15	40	59	0.879	-0.171	4.649	0.01	0.007	0	41.3	39.6	62.8	131	125	0	35	33
2014	7	12	15	50	59	0.876	-0.108	4.649	0.01	0.007	0	40.9	38.3	74.4	129	123	0	34	34
2014	7	12	16	0	59	0.876	-0.102	4.649	0.01	0.007	0	40.9	38.7	54.2	129	123	0	34	33
2014	7	12	16	10	59	0.883	-0.151	4.649	0.01	0.007	0	40.4	38.7	68.4	128	122	0	34	32
2014	7	12	16	20	59	0.892	-0.131	4.646	0.01	0.007	0	42.6	40	52	132	126	0	33	33
2014	7	12	16	30	59	0.886	-0.148	4.646	0.01	0.007	0	41.3	39.1	61.1	129	123	0	33	32
2014	7	12	16	40	59	0.896	-0.082	4.646	0.01	0.007	0	41.3	39.1	59.8	130	124	0	34	33
2014	7	12	16	50	59	0.909	-0.144	4.649	0.01	0.007	0	40.9	38.7	68.8	129	123	0	34	33
2014	7	12	17	0	59	0.892	-0.167	4.649	0.01	0.007	0	40.4	38.3	60.6	128	122	0	34	33
2014	7	12	17	10	59	0.879	-0.167	4.649	0.01	0.007	0	40.9	38.3	64.9	129	121	0	34	32
2014	7	12	17	20	59	0.896	-0.171	4.646	0.013	0.01	0	40.4	37.8	66.7	128	121	0	34	33
2014	7	12	17	30	59	0.889	-0.164	4.646	0.01	0.007	0	40.4	38.3	64.5	128	122	0	34	33
2014	7	12	17	40	59	0.915	-0.125	4.646	0.01	0.007	0	40.4	37.8	69.7	128	122	0	34	34
2014	7	12	17	50	59	0.889	-0.144	4.646	0.01	0.007	0	40.4	38.3	67.9	128	122	0	34	33
2014	7	12	18	0	59	0.863	-0.144	4.649	0.01	0.007	0	40.4	37.8	70.5	128	121	0	34	33
2014	7	12	18	10	59	0.899	-0.154	4.646	0.013	0.01	0	40.4	37.8	61.9	128	121	0	34	33
2014	7	12	18	20	59	0.906	-0.161	4.646	0.01	0.007	0	40.4	37.8	59.3	128	121	0	34	33
2014	7	12	18	30	59	0.876	-0.098	4.649	0.01	0.007	0	40.4	38.7	67.5	128	122	0	34	32
2014	7	12	18	40	59	0.883	-0.148	4.649	0.01	0.007	0	40.4	37.8	67.5	128	121	0	34	33
2014	7	12	18	50	59	0.889	-0.128	4.649	0.01	0.007	0	40.4	37.8	62.4	128	121	0	34	33
2014	7	12	19	0	59	0.899	-0.115	4.649	0.01	0.007	0	40.9	38.7	65.8	129	123	0	34	33
2014	7	12	19	10	59	0.886	-0.125	4.646	0.01	0.007	0	41.3	38.3	63.2	129	122	0	33	33
2014	7	12	19	20	59	0.866	-0.121	4.646	0.013	0.01	0	40.9	38.7	68.8	129	122	0	34	32
2014	7	12	19	30	59	0.86	-0.125	4.649	0.01	0.007	0	40.9	38.7	65.8	129	123	0	34	33
2014	7	12	19	40	59	0.873	-0.098	4.646	0.01	0.007	0	41.3	38.7	55.9	129	122	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	19	50	59	0.886	-0.105	4.646	0.01	0.007	0	41.3	38.7	57.2	130	123	0	34	33
2014	7	12	20	0	59	0.883	-0.082	4.649	0.01	0.007	0	41.3	39.6	56.3	131	125	0	35	33
2014	7	12	20	10	59	0.896	-0.089	4.649	0.01	0.007	0	41.7	39.6	56.3	131	124	0	34	32
2014	7	12	20	20	59	0.886	-0.069	4.649	0.01	0.007	0	41.7	39.6	57.6	131	124	0	34	32
2014	7	12	20	30	59	0.866	-0.072	4.649	0.01	0.007	0	41.7	39.6	57.2	131	125	0	34	33
2014	7	12	20	40	59	0.886	-0.095	4.649	0.01	0.007	0	42.6	40	57.2	133	126	0	34	33
2014	7	12	20	50	59	0.883	-0.085	4.649	0.016	0.013	0	42.1	40	55.9	132	125	0	34	32
2014	7	12	21	0	59	0.856	-0.082	4.649	0.01	0.007	0	42.6	40.4	60.6	133	126	0	34	32
2014	7	12	21	10	59	0.912	-0.112	4.649	0.01	0.007	0	42.1	39.1	62.8	131	124	0	33	33
2014	7	12	21	20	59	0.866	-0.098	4.649	0.01	0.007	0	41.3	39.1	70.5	130	124	0	34	33
2014	7	12	21	30	59	0.873	-0.066	4.649	0.01	0.007	0	41.7	39.1	73.5	131	124	0	34	33
2014	7	12	21	40	59	0.909	-0.112	4.652	0.01	0.007	0	40.9	38.7	73.1	130	123	0	35	33
2014	7	12	21	50	59	0.866	-0.079	4.652	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	12	22	0	59	0.902	-0.069	4.652	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	12	22	10	59	0.866	-0.089	4.652	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	12	22	20	59	0.856	-0.095	4.652	0.01	0.007	0	42.1	39.6	76.1	132	125	0	34	33
2014	7	12	22	30	59	0.876	-0.075	4.652	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	12	22	40	59	0.883	-0.056	4.652	0.01	0.007	0	42.6	40	75.7	133	126	0	34	33
2014	7	12	22	50	59	0.896	-0.079	4.652	0.01	0.007	0	42.1	39.6	73.5	131	124	0	33	32
2014	7	12	23	0	59	0.879	-0.095	4.652	0.013	0.01	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	12	23	10	59	0.883	-0.072	4.652	0.01	0.007	0	42.6	39.6	73.5	132	125	0	33	33
2014	7	12	23	20	59	0.856	-0.112	4.652	0.01	0.007	0	41.7	39.6	72.7	131	125	0	34	33
2014	7	12	23	30	59	0.899	-0.089	4.652	0.01	0.007	0	41.3	38.7	75.3	129	123	0	33	33
2014	7	12	23	40	59	0.866	-0.089	4.652	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	12	23	50	59	0.863	-0.072	4.652	0.01	0.007	0	41.7	38.7	76.1	131	123	0	34	33
2014	7	13	0	0	59	0.889	-0.072	4.652	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	13	0	10	59	0.892	-0.098	4.652	0.01	0.007	0	40.9	39.1	75.3	129	123	0	34	32
2014	7	13	0	20	59	0.899	-0.059	4.652	0.01	0.007	0	40.9	38.7	75.7	130	123	0	35	33
2014	7	13	0	30	59	0.866	-0.082	4.652	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	13	0	40	59	0.896	-0.079	4.652	0.01	0.007	0	42.1	38.7	74.8	131	124	0	33	34
2014	7	13	0	50	59	0.866	-0.102	4.652	0.01	0.007	0	41.3	39.1	75.7	130	123	0	34	32
2014	7	13	1	0	59	0.896	-0.056	4.652	0.01	0.007	0	41.3	39.6	75.7	131	124	0	35	32
2014	7	13	1	10	59	0.892	-0.075	4.652	0.01	0.007	0	42.1	39.6	75.7	132	125	0	34	33
2014	7	13	1	20	59	0.853	-0.075	4.652	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	13	1	30	59	0.869	-0.079	4.656	0.01	0.007	0	41.7	39.1	71.4	131	124	0	34	33
2014	7	13	1	40	59	0.879	-0.056	4.656	0.01	0.007	0	41.7	39.1	64.5	131	124	0	34	33
2014	7	13	1	50	59	0.873	-0.066	4.656	0.01	0.007	0	42.1	40	73.5	132	126	0	34	33
2014	7	13	2	0	59	0.879	-0.049	4.656	0.01	0.007	0	42.6	40.4	74.4	133	127	0	34	33
2014	7	13	2	10	59	0.883	-0.072	4.656	0.01	0.007	0	42.6	40	74	133	126	0	34	33
2014	7	13	2	20	59	0.869	-0.085	4.656	0.016	0.013	0	42.6	40.9	74.8	133	127	0	34	32
2014	7	13	2	30	59	0.876	-0.069	4.656	0.01	0.007	0	42.1	40	74.8	133	126	0	35	33
2014	7	13	2	40	59	0.873	-0.062	4.659	0.01	0.007	0	42.6	39.6	74.8	133	126	0	34	34
2014	7	13	2	50	59	0.899	-0.046	4.659	0.01	0.007	0	42.6	39.6	68.8	133	125	0	34	33
2014	7	13	3	0	59	0.873	-0.079	4.659	0.01	0.007	0	43	40.4	74	134	127	0	34	33
2014	7	13	3	10	59	0.876	-0.085	4.659	0.013	0.01	0	42.6	39.6	68.8	133	126	0	34	34
2014	7	13	3	20	59	0.902	-0.059	4.659	0.01	0.007	0	42.6	40	69.7	133	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	3	30	59	0.879	-0.082	4.659	0.01	0.007	0	42.6	40	73.5	133	126	0	34	33
2014	7	13	3	40	59	0.869	-0.069	4.659	0.01	0.007	0	42.1	39.6	73.1	132	125	0	34	33
2014	7	13	3	50	59	0.863	-0.062	4.659	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	13	4	0	59	0.876	-0.033	4.659	0.01	0.007	0	42.6	40.4	71.8	133	127	0	34	33
2014	7	13	4	10	59	0.879	-0.085	4.662	0.01	0.007	0	42.1	40.4	72.2	133	126	0	35	32
2014	7	13	4	20	59	0.876	-0.079	4.662	0.01	0.007	0	43	40.4	72.2	133	126	0	33	32
2014	7	13	4	30	59	0.879	-0.085	4.662	0.01	0.007	0	42.1	40.4	73.1	132	126	0	34	32
2014	7	13	4	40	59	0.869	-0.085	4.665	0.01	0.007	0	42.1	40	72.7	132	125	0	34	32
2014	7	13	4	50	59	0.925	-0.098	4.665	0.01	0.007	0	42.1	39.6	71.8	132	125	0	34	33
2014	7	13	5	0	59	0.866	-0.082	4.669	0.01	0.007	0	42.6	39.6	71.4	133	126	0	34	34
2014	7	13	5	10	59	0.876	-0.066	4.669	0.01	0.007	0	43	41.3	70.5	135	128	0	35	32
2014	7	13	5	20	59	0.889	-0.082	4.672	0.01	0.007	0	42.1	39.6	72.2	132	125	0	34	33
2014	7	13	5	30	59	0.873	-0.082	4.672	0.01	0.007	0	42.6	39.6	73.1	132	125	0	33	33
2014	7	13	5	40	59	0.873	-0.079	4.675	0.01	0.007	0	42.1	39.6	73.5	132	125	0	34	33
2014	7	13	5	50	59	0.892	-0.062	4.675	0.01	0.007	0	42.1	39.6	72.2	132	125	0	34	33
2014	7	13	6	0	59	0.86	-0.066	4.675	0.01	0.007	0	41.7	39.1	73.5	131	124	0	34	33
2014	7	13	6	10	59	0.869	-0.052	4.675	0.01	0.007	0	41.3	38.7	73.5	130	123	0	34	33
2014	7	13	6	20	59	0.879	-0.085	4.675	0.01	0.007	0	40.9	38.7	74	129	123	0	34	33
2014	7	13	6	30	59	0.889	-0.079	4.675	0.016	0.013	0	41.7	38.7	73.5	130	123	0	33	33
2014	7	13	6	40	59	0.889	-0.066	4.675	0.01	0.007	0	40.9	38.3	73.5	129	122	0	34	33
2014	7	13	6	50	59	0.896	-0.075	4.675	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	13	7	0	59	0.892	-0.069	4.675	0.01	0.007	0	40.4	38.7	74.8	129	123	0	35	33
2014	7	13	7	10	59	0.886	-0.092	4.675	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	13	7	20	59	0.86	-0.082	4.675	0.01	0.007	0	41.3	38.7	73.1	131	123	0	35	33
2014	7	13	7	30	59	0.883	-0.082	4.675	0.01	0.007	0	41.7	38.7	74.4	131	123	0	34	33
2014	7	13	7	40	59	0.863	-0.098	4.675	0.01	0.007	0	41.3	38.7	74	131	123	0	35	33
2014	7	13	7	50	59	0.879	-0.049	4.675	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	13	8	0	59	0.896	-0.092	4.675	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	13	8	10	59	0.892	-0.075	4.675	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	13	8	20	59	0.86	-0.033	4.675	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	13	8	30	59	0.896	-0.079	4.675	0.01	0.007	0	41.7	39.1	74.4	132	124	0	35	33
2014	7	13	8	40	59	0.883	-0.079	4.675	0.01	0.007	0	42.1	39.6	74.4	132	124	0	34	32
2014	7	13	8	50	59	0.902	-0.085	4.675	0.01	0.007	0	42.1	39.1	74.8	132	124	0	34	33
2014	7	13	9	0	59	0.892	-0.089	4.675	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	13	9	10	59	0.876	-0.079	4.675	0.01	0.007	0	41.7	39.6	74.4	131	124	0	34	32
2014	7	13	9	20	59	0.886	-0.069	4.675	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	13	9	30	59	0.873	-0.108	4.675	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	13	9	40	59	0.889	-0.108	4.675	0.01	0.007	0	41.7	39.1	74.4	131	123	0	34	32
2014	7	13	9	50	59	0.906	-0.082	4.675	0.01	0.007	0	41.7	38.7	74.4	131	123	0	34	33
2014	7	13	10	0	59	0.886	-0.085	4.675	0.01	0.007	0	41.3	38.7	68.8	131	124	0	35	34
2014	7	13	10	10	59	0.899	-0.115	4.669	0.01	0.007	0	42.1	38.7	43	132	123	0	34	33
2014	7	13	10	20	59	0.873	-0.079	4.675	0.01	0.007	0	42.1	39.1	74.4	132	124	0	34	33
2014	7	13	10	30	59	0.912	-0.092	4.675	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	13	10	40	59	0.935	-0.125	4.675	0.01	0.007	0	41.7	38.7	72.2	131	123	0	34	33
2014	7	13	10	50	59	0.906	-0.121	4.675	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	13	11	0	59	0.896	-0.157	4.672	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	11	10	59	0.892	-0.108	4.672	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	13	11	20	59	0.896	-0.125	4.669	0.01	0.007	0	41.7	38.7	71.8	131	123	0	34	33
2014	7	13	11	30	59	0.892	-0.177	4.669	0.01	0.007	0	41.3	37.8	71	129	121	0	33	33
2014	7	13	11	40	59	0.899	-0.177	4.669	0.01	0.007	0	41.3	38.3	49.9	130	122	0	34	33
2014	7	13	11	50	59	0.883	-0.148	4.665	0.01	0.007	0	40.9	38.7	68.8	130	122	0	35	32
2014	7	13	12	0	59	0.925	-0.128	4.662	0.01	0.007	0	41.7	38.7	71	131	122	0	34	32
2014	7	13	12	10	59	0.879	-0.144	4.662	0.01	0.007	0	41.3	38.3	72.2	130	122	0	34	33
2014	7	13	12	20	59	0.896	-0.161	4.662	0.01	0.007	0	40.9	37.8	71.4	129	121	0	34	33
2014	7	13	12	30	59	0.86	-0.148	4.659	0.01	0.007	0	40.9	37.4	70.5	129	121	0	34	34
2014	7	13	12	40	59	0.883	-0.18	4.659	0.01	0.007	0	40.9	37.8	72.2	129	121	0	34	33
2014	7	13	12	50	59	0.853	-0.167	4.659	0.01	0.007	0	40.9	37.8	71.8	129	121	0	34	33
2014	7	13	13	0	59	0.86	-0.138	4.659	0.01	0.007	0	40.9	37.8	72.7	129	121	0	34	33
2014	7	13	13	10	59	0.879	-0.148	4.659	0.01	0.007	0	40.9	37.8	67.5	129	121	0	34	33
2014	7	13	13	20	59	0.909	-0.154	4.659	0.01	0.007	0	41.3	38.3	70.5	130	122	0	34	33
2014	7	13	13	30	59	0.896	-0.135	4.659	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2014	7	13	13	40	59	0.863	-0.164	4.659	0.01	0.007	0	40.4	38.3	56.3	129	121	0	35	32
2014	7	13	13	50	59	0.886	-0.148	4.659	0.01	0.007	0	41.3	38.3	59.8	130	122	0	34	33
2014	7	13	14	0	59	0.889	-0.171	4.659	0.01	0.007	0	41.3	37.8	58	130	122	0	34	34
2014	7	13	14	10	59	0.886	-0.148	4.659	0.01	0.007	0	40.9	38.3	73.1	130	122	0	35	33
2014	7	13	14	20	59	0.886	-0.161	4.659	0.01	0.007	0	40.9	38.3	68.8	129	121	0	34	32
2014	7	13	14	30	59	0.902	-0.157	4.659	0.01	0.007	0	41.3	38.3	68.8	130	122	0	34	33
2014	7	13	14	40	59	0.876	-0.174	4.659	0.01	0.007	0	40.9	38.3	64.1	129	122	0	34	33
2014	7	13	14	50	59	0.889	-0.171	4.659	0.01	0.007	0	41.7	38.7	61.5	130	122	0	33	32
2014	7	13	15	0	59	0.879	-0.095	4.656	0.01	0.007	0	41.3	38.7	68.8	130	123	0	34	33
2014	7	13	15	10	59	0.902	-0.144	4.656	0.01	0.007	0	41.7	39.6	57.6	131	124	0	34	32
2014	7	13	15	20	59	0.902	-0.151	4.659	0.01	0.007	0	43	40	62.8	134	126	0	34	33
2014	7	13	15	30	59	0.892	-0.144	4.656	0.01	0.007	0	41.3	38.7	71.4	130	122	0	34	32
2014	7	13	15	40	59	0.873	-0.148	4.656	0.01	0.007	0	42.6	39.1	65.4	133	124	0	34	33
2014	7	13	15	50	59	0.889	-0.131	4.656	0.01	0.007	0	41.3	39.1	74	130	123	0	34	32
2014	7	13	16	0	59	0.879	-0.131	4.656	0.013	0.01	0	43.4	41.3	59.8	135	128	0	34	32
2014	7	13	16	10	59	0.886	-0.141	4.656	0.013	0.01	0	43	39.6	59.8	134	126	0	34	34
2014	7	13	16	20	59	0.883	-0.138	4.656	0.01	0.007	0	40.9	38.7	67.5	130	123	0	35	33
2014	7	13	16	30	59	0.896	-0.138	4.656	0.013	0.01	0	41.3	39.1	60.6	130	123	0	34	32
2014	7	13	16	40	59	0.902	-0.131	4.656	0.01	0.007	0	41.3	39.1	66.7	130	123	0	34	32
2014	7	13	16	50	59	0.889	-0.105	4.656	0.013	0.01	0	41.7	39.6	63.6	131	124	0	34	32
2014	7	13	17	0	59	0.919	-0.151	4.656	0.01	0.007	0	41.3	38.7	70.5	130	123	0	34	33
2014	7	13	17	10	59	0.873	-0.148	4.656	0.01	0.007	0	41.7	38.7	67.9	131	123	0	34	33
2014	7	13	17	20	59	0.886	-0.131	4.656	0.01	0.007	0	41.3	38.7	64.9	130	123	0	34	33
2014	7	13	17	30	59	0.876	-0.148	4.656	0.01	0.007	0	41.3	38.7	61.5	130	122	0	34	32
2014	7	13	17	40	59	0.902	-0.131	4.656	0.013	0.01	0	43	40	59.8	134	126	0	34	33
2014	7	13	17	50	59	0.876	-0.131	4.656	0.01	0.007	0	41.3	37.8	70.1	129	121	0	33	33
2014	7	13	18	0	59	0.909	-0.151	4.656	0.01	0.007	0	40.9	37.8	69.2	129	122	0	34	34
2014	7	13	18	10	59	0.892	-0.135	4.656	0.01	0.007	0	41.7	38.7	58	131	123	0	34	33
2014	7	13	18	20	59	0.876	-0.069	4.656	0.013	0.01	0	42.1	38.7	54.6	132	124	0	34	34
2014	7	13	18	30	59	0.883	-0.098	4.656	0.01	0.007	0	41.7	39.6	58.9	131	124	0	34	32
2014	7	13	18	40	59	0.866	-0.085	4.656	0.01	0.007	0	41.7	38.7	68.8	131	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	18	50	59	0.866	-0.075	4.656	0.01	0.007	0	44.7	41.7	52.9	138	130	0	34	33
2014	7	13	19	0	59	0.879	-0.105	4.656	0.01	0.007	0	43.9	40.9	64.1	136	128	0	34	33
2014	7	13	19	10	59	0.896	-0.072	4.656	0.01	0.007	0	43	38.7	53.8	134	124	0	34	34
2014	7	13	19	20	59	0.866	-0.069	4.652	0.01	0.007	0	43.9	40.4	50.3	136	128	0	34	34
2014	7	13	19	30	59	0.86	-0.059	4.656	0.013	0.01	0	43	40.4	56.8	134	127	0	34	33
2014	7	13	19	40	59	0.846	-0.062	4.659	0.01	0.007	0	41.7	39.1	74	131	123	0	34	32
2014	7	13	19	50	59	0.85	-0.089	4.659	0.01	0.007	0	42.1	38.7	74	132	124	0	34	34
2014	7	13	20	0	59	0.886	-0.092	4.659	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	13	20	10	59	0.902	-0.092	4.659	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	13	20	20	59	0.899	-0.079	4.659	0.013	0.01	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	13	20	30	59	0.883	-0.082	4.659	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	13	20	40	59	0.896	-0.056	4.659	0.013	0.01	0	43.4	40	70.1	134	126	0	33	33
2014	7	13	20	50	59	0.869	-0.098	4.659	0.01	0.007	0	43.4	40.4	69.7	134	127	0	33	33
2014	7	13	21	0	59	0.889	-0.095	4.659	0.01	0.007	0	43.9	40.4	71.8	135	127	0	33	33
2014	7	13	21	10	59	0.869	-0.062	4.659	0.01	0.007	0	42.6	39.6	71.8	133	125	0	34	33
2014	7	13	21	20	59	0.896	-0.079	4.659	0.01	0.007	0	42.1	39.6	74	132	125	0	34	33
2014	7	13	21	30	59	0.896	-0.072	4.659	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	13	21	40	59	0.892	-0.069	4.659	0.016	0.013	0	42.6	40	74	132	125	0	33	32
2014	7	13	21	50	59	0.866	-0.105	4.659	0.01	0.007	0	42.6	39.6	74	133	125	0	34	33
2014	7	13	22	0	59	0.869	-0.082	4.659	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	13	22	10	59	0.869	-0.066	4.662	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	13	22	20	59	0.883	-0.082	4.662	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	13	22	30	59	0.879	-0.072	4.662	0.01	0.007	0	41.7	39.1	74	131	123	0	34	32
2014	7	13	22	40	59	0.869	-0.052	4.662	0.01	0.007	0	42.1	39.6	73.5	132	124	0	34	32
2014	7	13	22	50	59	0.889	-0.072	4.662	0.013	0.01	0	41.7	39.1	71.8	131	123	0	34	32
2014	7	13	23	0	59	0.876	-0.059	4.662	0.01	0.007	0	41.7	39.1	66.7	131	124	0	34	33
2014	7	13	23	10	59	0.879	-0.098	4.662	0.01	0.007	0	41.7	38.7	72.7	131	123	0	34	33
2014	7	13	23	20	59	0.873	-0.046	4.662	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	13	23	30	59	0.869	-0.082	4.662	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	13	23	40	59	0.883	-0.059	4.662	0.01	0.007	0	41.3	39.1	72.2	130	123	0	34	32
2014	7	13	23	50	59	0.873	-0.082	4.662	0.01	0.007	0	42.1	39.1	73.1	131	123	0	33	32
2014	7	14	0	0	59	0.899	-0.095	4.662	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	14	0	10	59	0.892	-0.082	4.662	0.01	0.007	0	42.1	39.6	72.7	132	124	0	34	32
2014	7	14	0	20	59	0.876	-0.115	4.662	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	14	0	30	59	0.873	-0.082	4.662	0.013	0.01	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	14	0	40	59	0.866	-0.075	4.662	0.01	0.007	0	42.6	39.6	72.2	133	125	0	34	33
2014	7	14	0	50	59	0.873	-0.072	4.662	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	14	1	0	59	0.843	-0.102	4.665	0.01	0.007	0	42.1	39.1	67.5	131	124	0	33	33
2014	7	14	1	10	59	0.863	-0.095	4.665	0.01	0.007	0	42.6	40	72.2	133	125	0	34	32
2014	7	14	1	20	59	0.889	-0.098	4.665	0.01	0.007	0	41.7	38.7	72.7	131	123	0	34	33
2014	7	14	1	30	59	0.892	-0.098	4.665	0.01	0.007	0	41.7	38.7	71.4	131	123	0	34	33
2014	7	14	1	40	59	0.879	-0.098	4.665	0.013	0.01	0	43	40	71.8	134	126	0	34	33
2014	7	14	1	50	59	0.873	-0.089	4.665	0.01	0.007	0	42.6	39.6	72.2	133	125	0	34	33
2014	7	14	2	0	59	0.896	-0.056	4.665	0.01	0.007	0	41.7	39.6	71.4	131	124	0	34	32
2014	7	14	2	10	59	0.915	-0.079	4.665	0.01	0.007	0	41.3	38.7	69.2	131	123	0	35	33
2014	7	14	2	20	59	0.876	-0.069	4.665	0.01	0.007	0	42.1	39.1	71.8	132	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	2	30	59	0.896	-0.072	4.669	0.01	0.007	0	42.6	39.6	71	133	125	0	34	33
2014	7	14	2	40	59	0.879	-0.095	4.672	0.01	0.007	0	42.6	40	71.4	134	126	0	35	33
2014	7	14	2	50	59	0.86	-0.069	4.675	0.01	0.007	0	42.6	39.6	70.5	133	125	0	34	33
2014	7	14	3	0	59	0.883	-0.072	4.678	0.01	0.007	0	41.7	39.1	71.4	131	123	0	34	32
2014	7	14	3	10	59	0.889	-0.098	4.675	0.01	0.007	0	42.6	40	67.9	133	126	0	34	33
2014	7	14	3	20	59	0.899	-0.079	4.678	0.01	0.007	0	42.1	39.1	72.2	132	124	0	34	33
2014	7	14	3	30	59	0.883	-0.072	4.675	0.01	0.007	0	42.6	39.6	69.2	133	125	0	34	33
2014	7	14	3	40	59	0.899	-0.075	4.678	0.01	0.007	0	42.1	40	70.1	132	125	0	34	32
2014	7	14	3	50	59	0.883	-0.079	4.678	0.01	0.007	0	41.3	39.6	71	131	124	0	35	32
2014	7	14	4	0	59	0.879	-0.098	4.678	0.01	0.007	0	43	40	71.4	134	126	0	34	33
2014	7	14	4	10	59	0.889	-0.079	4.678	0.01	0.007	0	41.7	39.6	70.1	131	125	0	34	33
2014	7	14	4	20	59	0.892	-0.075	4.678	0.01	0.007	0	42.6	39.1	73.1	133	125	0	34	34
2014	7	14	4	30	59	0.886	-0.069	4.678	0.01	0.007	0	42.6	39.6	71.8	133	125	0	34	33
2014	7	14	4	40	59	0.896	-0.039	4.678	0.01	0.007	0	43.4	40	72.2	134	126	0	33	33
2014	7	14	4	50	59	0.883	-0.082	4.678	0.01	0.007	0	43	40	72.2	134	126	0	34	33
2014	7	14	5	0	59	0.896	-0.079	4.678	0.01	0.007	0	42.6	39.6	72.2	133	125	0	34	33
2014	7	14	5	10	59	0.883	-0.066	4.678	0.01	0.007	0	43	40	73.1	134	126	0	34	33
2014	7	14	5	20	59	0.883	-0.079	4.678	0.01	0.007	0	42.6	39.6	72.7	133	125	0	34	33
2014	7	14	5	30	59	0.906	-0.056	4.678	0.01	0.007	0	43	40.4	72.7	134	126	0	34	32
2014	7	14	5	40	59	0.906	-0.089	4.678	0.01	0.007	0	42.6	40	72.7	134	126	0	35	33
2014	7	14	5	50	59	0.873	-0.066	4.678	0.013	0.01	0	41.7	39.1	73.1	132	124	0	35	33
2014	7	14	6	0	59	0.876	-0.098	4.678	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	14	6	10	59	0.869	-0.066	4.678	0.01	0.007	0	42.6	39.1	74	132	124	0	33	33
2014	7	14	6	20	59	0.899	-0.072	4.678	0.01	0.007	0	42.1	39.1	74.4	132	124	0	34	33
2014	7	14	6	30	59	0.915	-0.072	4.678	0.01	0.007	0	42.1	38.3	74.4	131	123	0	33	34
2014	7	14	6	40	59	0.869	-0.066	4.682	0.01	0.007	0	41.3	39.1	74.4	130	123	0	34	32
2014	7	14	6	50	59	0.876	-0.072	4.682	0.01	0.007	0	42.6	39.1	74	133	125	0	34	34
2014	7	14	7	0	59	0.892	-0.098	4.682	0.01	0.007	0	41.7	39.1	73.1	131	124	0	34	33
2014	7	14	7	10	59	0.86	-0.085	4.682	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	14	7	20	59	0.86	-0.059	4.682	0.01	0.007	0	41.3	37.8	74	130	122	0	34	34
2014	7	14	7	30	59	0.889	-0.079	4.682	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	14	7	40	59	0.879	-0.056	4.682	0.01	0.007	0	40.9	38.3	74.8	129	122	0	34	33
2014	7	14	7	50	59	0.912	-0.105	4.682	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	14	8	0	59	0.899	-0.082	4.682	0.013	0.01	0	40.9	38.7	74.4	130	123	0	35	33
2014	7	14	8	10	59	0.876	-0.095	4.682	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	14	8	20	59	0.896	-0.089	4.682	0.01	0.007	0	41.3	37.8	74.4	130	121	0	34	33
2014	7	14	8	30	59	0.886	-0.092	4.682	0.013	0.01	0	40.9	37.8	73.1	129	122	0	34	34
2014	7	14	8	40	59	0.879	-0.085	4.682	0.01	0.007	0	41.3	38.7	74.8	130	123	0	34	33
2014	7	14	8	50	59	0.909	-0.102	4.682	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	14	9	0	59	0.909	-0.092	4.682	0.01	0.007	0	41.3	39.1	74.4	130	123	0	34	32
2014	7	14	9	10	59	0.896	-0.079	4.682	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	14	9	20	59	0.899	-0.079	4.682	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	14	9	30	59	0.866	-0.082	4.682	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	14	9	40	59	0.879	-0.082	4.682	0.01	0.007	0	41.7	39.1	74	131	123	0	34	32
2014	7	14	9	50	59	0.869	-0.098	4.682	0.01	0.007	0	41.3	38.3	73.1	130	122	0	34	33
2014	7	14	10	0	59	0.899	-0.066	4.682	0.01	0.007	0	41.3	38.3	73.5	131	123	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	10	10	59	0.902	-0.092	4.682	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	14	10	20	59	0.886	-0.125	4.682	0.01	0.007	0	40.9	38.3	74.4	129	122	0	34	33
2014	7	14	10	30	59	0.896	-0.118	4.678	0.01	0.007	0	40.9	37.8	73.1	129	121	0	34	33
2014	7	14	10	40	59	0.876	-0.161	4.678	0.01	0.007	0	41.3	38.3	69.7	130	122	0	34	33
2014	7	14	10	50	59	0.896	-0.125	4.678	0.01	0.007	0	40.9	38.3	65.4	130	122	0	35	33
2014	7	14	11	0	59	0.896	-0.102	4.675	0.01	0.007	0	44.3	40.9	51.6	137	129	0	34	34
2014	7	14	11	10	59	0.879	-0.151	4.672	0.01	0.007	0	42.6	39.1	52.5	132	124	0	33	33
2014	7	14	11	20	59	0.876	-0.131	4.675	0.01	0.007	0	44.3	41.3	60.2	137	129	0	34	33
2014	7	14	11	30	59	0.883	-0.138	4.675	0.01	0.007	0	40.9	38.3	59.3	129	122	0	34	33
2014	7	14	11	40	59	0.915	-0.089	4.675	0.013	0.01	0	40.9	38.3	54.2	129	122	0	34	33
2014	7	14	11	50	59	0.899	-0.082	4.675	0.01	0.007	0	41.3	38.7	56.8	130	123	0	34	33
2014	7	14	12	0	59	0.899	-0.154	4.675	0.01	0.007	0	41.3	38.7	51.6	130	123	0	34	33
2014	7	14	12	10	59	0.86	-0.148	4.672	0.01	0.007	0	40.9	38.3	52.5	129	122	0	34	33
2014	7	14	12	20	59	0.879	-0.151	4.675	0.01	0.007	0	40.9	37.8	51.6	129	121	0	34	33
2014	7	14	12	30	59	0.863	-0.19	4.672	0.01	0.007	0	40.9	37.8	50.3	129	121	0	34	33
2014	7	14	12	40	59	0.873	-0.154	4.672	0.01	0.007	0	41.3	38.3	51.2	130	122	0	34	33
2014	7	14	12	50	59	0.892	-0.154	4.669	0.01	0.007	0	41.3	38.7	53.8	130	123	0	34	33
2014	7	14	13	0	59	0.889	-0.138	4.669	0.01	0.007	0	41.3	38.3	52.5	130	122	0	34	33
2014	7	14	13	10	59	0.856	-0.144	4.669	0.01	0.007	0	40.4	38.7	52	129	122	0	35	32
2014	7	14	13	20	59	0.883	-0.098	4.669	0.01	0.007	0	40.9	38.7	55.5	129	122	0	34	32
2014	7	14	13	30	59	0.879	-0.131	4.665	0.01	0.007	0	40.4	37.8	59.8	128	121	0	34	33
2014	7	14	13	40	59	0.873	-0.144	4.665	0.01	0.007	0	41.3	39.1	60.6	130	123	0	34	32
2014	7	14	13	50	59	0.892	-0.174	4.665	0.01	0.007	0	40.9	38.3	60.6	129	122	0	34	33
2014	7	14	14	0	59	0.886	-0.177	4.665	0.01	0.007	0	40.9	37.8	52	129	121	0	34	33
2014	7	14	14	10	59	0.873	-0.138	4.662	0.01	0.007	0	41.3	38.3	55	129	122	0	33	33
2014	7	14	14	20	59	0.909	-0.118	4.662	0.01	0.007	0	41.3	38.3	60.2	130	122	0	34	33
2014	7	14	14	30	59	0.879	-0.157	4.665	0.013	0.01	0	40.9	38.3	54.6	129	122	0	34	33
2014	7	14	14	40	59	0.876	-0.161	4.669	0.01	0.007	0	40.9	38.3	53.3	129	122	0	34	33
2014	7	14	14	50	59	0.899	-0.161	4.665	0.01	0.007	0	40.9	38.3	52	129	122	0	34	33
2014	7	14	15	10	27	0.892	-0.18	4.662	0.01	0.007	0	40.9	38.3	55	129	122	0	34	33
2014	7	14	15	20	27	0.892	-0.125	4.665	0.01	0.007	0	47.3	45.2	48.6	144	138	0	34	33
2014	7	14	15	30	27	0.932	-0.138	4.662	0.01	0.007	0	41.3	38.7	55	130	123	0	34	33
2014	7	14	15	40	27	0.909	-0.128	4.665	0.01	0.007	0	40.9	38.3	53.8	129	122	0	34	33
2014	7	14	15	50	27	0.945	-0.112	4.669	0.01	0.007	0	43.4	40	47.7	135	126	0	34	33
2014	7	14	16	0	27	0.919	-0.118	4.665	0.01	0.007	0	43.4	40.9	54.2	135	128	0	34	33
2014	7	14	16	10	27	0.833	-0.21	4.665	0.01	0.007	0	42.1	38.3	54.6	132	122	0	34	33
2014	7	14	16	20	27	0.879	-0.079	4.662	0.013	0.01	0	41.3	38.7	53.8	130	123	0	34	33
2014	7	14	16	30	27	0.883	-0.112	4.665	0.01	0.007	0	40.9	38.3	55	129	122	0	34	33
2014	7	14	16	40	27	0.879	-0.151	4.662	0.01	0.007	0	40.9	38.3	56.3	129	122	0	34	33
2014	7	14	16	50	27	0.876	-0.131	4.662	0.01	0.007	0	41.3	38.3	56.3	130	122	0	34	33
2014	7	14	17	0	27	0.892	-0.125	4.662	0.01	0.007	0	40.9	38.3	55	129	121	0	34	32
2014	7	14	17	10	27	0.883	-0.18	4.662	0.013	0.01	0	40.9	37.8	55.9	129	121	0	34	33
2014	7	14	17	20	27	0.863	-0.141	4.659	0.01	0.007	0	40.4	37.8	55.9	128	121	0	34	33
2014	7	14	17	30	27	0.873	-0.095	4.662	0.01	0.007	0	40.4	37.8	55.5	128	121	0	34	33
2014	7	14	17	40	27	0.879	-0.105	4.665	0.01	0.007	0	40.9	38.3	54.2	129	122	0	34	33
2014	7	14	17	50	27	0.892	-0.131	4.662	0.01	0.007	0	41.3	38.3	55	129	121	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	18	0	27	0.879	-0.131	4.659	0.01	0.007	0	40.9	38.3	56.8	129	122	0	34	33
2014	7	14	18	10	27	0.879	-0.121	4.659	0.01	0.007	0	40.4	38.3	57.2	128	121	0	34	32
2014	7	14	18	20	27	0.853	-0.135	4.659	0.01	0.007	0	40.4	37.8	65.4	128	121	0	34	33
2014	7	14	18	30	27	0.873	-0.131	4.659	0.013	0.01	0	40.9	37.8	63.6	129	121	0	34	33
2014	7	14	18	40	27	0.879	-0.098	4.659	0.01	0.007	0	40.9	38.3	68.8	129	121	0	34	32
2014	7	14	18	50	27	0.892	-0.135	4.659	0.01	0.007	0	40.4	37.8	71.8	128	121	0	34	33
2014	7	14	19	0	27	0.899	-0.148	4.659	0.01	0.007	0	40.9	37.8	72.7	128	121	0	33	33
2014	7	14	19	10	27	0.889	-0.066	4.659	0.016	0.013	0	40.9	38.7	58.9	129	122	0	34	32
2014	7	14	19	20	27	0.879	-0.079	4.659	0.01	0.007	0	41.3	38.7	62.8	130	123	0	34	33
2014	7	14	19	30	27	0.902	-0.108	4.659	0.01	0.007	0	41.3	38.7	65.4	130	123	0	34	33
2014	7	14	19	40	27	0.912	-0.121	4.659	0.01	0.007	0	40.9	38.7	58	129	123	0	34	33
2014	7	14	19	50	27	0.879	-0.079	4.662	0.01	0.007	0	41.7	39.1	55.9	131	124	0	34	33
2014	7	14	20	0	27	0.896	-0.141	4.659	0.01	0.007	0	41.7	38.7	63.2	131	123	0	34	33
2014	7	14	20	10	27	0.906	-0.138	4.659	0.01	0.007	0	41.7	39.1	59.8	131	124	0	34	33
2014	7	14	20	20	27	0.892	-0.131	4.662	0.01	0.007	0	42.6	40	56.8	133	126	0	34	33
2014	7	14	20	30	27	0.906	-0.112	4.662	0.01	0.007	0	42.6	39.6	53.8	132	125	0	33	33
2014	7	14	20	40	27	0.896	-0.118	4.665	0.01	0.007	0	43.4	40.4	49	135	127	0	34	33
2014	7	14	20	50	27	0.909	-0.157	4.662	0.013	0.01	0	42.6	39.6	54.6	133	125	0	34	33
2014	7	14	21	0	27	0.879	-0.082	4.669	0.01	0.007	0	42.6	40	51.2	133	126	0	34	33
2014	7	14	21	10	27	0.866	-0.095	4.665	0.01	0.007	0	42.6	39.6	51.6	132	125	0	33	33
2014	7	14	21	20	27	0.866	-0.082	4.662	0.013	0.01	0	42.1	39.6	50.3	132	125	0	34	33
2014	7	14	21	30	27	0.912	-0.112	4.665	0.01	0.007	0	42.1	40	52.5	132	125	0	34	32
2014	7	14	21	40	27	0.902	-0.108	4.662	0.01	0.007	0	41.7	38.3	54.6	131	123	0	34	34
2014	7	14	21	50	27	0.892	-0.108	4.662	0.01	0.007	0	42.1	39.1	59.3	132	124	0	34	33
2014	7	14	22	0	27	0.919	-0.085	4.662	0.01	0.007	0	43	39.6	61.9	133	125	0	33	33
2014	7	14	22	10	27	0.892	-0.108	4.662	0.01	0.007	0	42.1	40	57.6	132	126	0	34	33
2014	7	14	22	20	27	0.892	-0.112	4.662	0.01	0.007	0	42.1	39.6	56.8	132	125	0	34	33
2014	7	14	22	30	27	0.899	-0.098	4.669	0.01	0.007	0	42.6	40.4	52	133	126	0	34	32
2014	7	14	22	40	27	0.902	-0.095	4.669	0.01	0.007	0	42.1	39.6	52.9	132	125	0	34	33
2014	7	14	22	50	27	0.899	-0.105	4.665	0.01	0.007	0	41.7	39.6	55.9	132	125	0	35	33
2014	7	14	23	0	27	0.902	-0.118	4.665	0.013	0.01	0	41.7	39.6	56.3	131	124	0	34	32
2014	7	14	23	10	27	0.896	-0.098	4.665	0.01	0.007	0	41.3	39.1	58.9	131	124	0	35	33
2014	7	14	23	20	27	0.899	-0.112	4.665	0.01	0.007	0	41.7	39.6	53.3	131	124	0	34	32
2014	7	14	23	30	27	0.866	-0.105	4.665	0.01	0.007	0	42.6	40	64.5	133	126	0	34	33
2014	7	14	23	40	27	0.896	-0.144	4.665	0.01	0.007	0	41.7	39.6	58	131	124	0	34	32
2014	7	14	23	50	27	0.892	-0.112	4.669	0.01	0.007	0	41.7	40	55.9	131	125	0	34	32
2014	7	15	0	0	27	0.906	-0.177	4.669	0.01	0.007	0	41.7	38.3	52.9	131	123	0	34	34
2014	7	15	0	10	27	0.922	-0.131	4.669	0.01	0.007	0	41.3	39.1	55	130	123	0	34	32
2014	7	15	0	20	27	0.919	-0.128	4.669	0.01	0.007	0	42.1	39.1	51.2	131	123	0	33	32
2014	7	15	0	30	27	0.889	-0.131	4.669	0.01	0.007	0	41.7	39.1	52	131	124	0	34	33
2014	7	15	0	40	27	0.912	-0.115	4.669	0.01	0.007	0	42.1	40	54.6	132	126	0	34	33
2014	7	15	0	50	27	0.892	-0.112	4.672	0.01	0.007	0	41.7	40	55.5	132	126	0	35	33
2014	7	15	1	0	27	0.896	-0.082	4.665	0.01	0.007	0	42.6	39.6	59.3	133	126	0	34	34
2014	7	15	1	10	27	0.866	-0.095	4.669	0.01	0.007	0	43	40.4	53.8	133	127	0	33	33
2014	7	15	1	20	27	0.909	-0.128	4.672	0.01	0.007	0	42.6	40	54.6	133	126	0	34	33
2014	7	15	1	30	27	0.899	-0.085	4.669	0.01	0.007	0	42.6	40	58.5	133	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	1	40	27	0.873	-0.082	4.672	0.01	0.007	0	43.4	40.4	53.3	135	128	0	34	34
2014	7	15	1	50	27	0.879	-0.049	4.672	0.01	0.007	0	43.4	40.9	53.8	134	127	0	33	32
2014	7	15	2	0	27	0.889	-0.115	4.672	0.013	0.01	0	41.7	39.1	64.1	131	124	0	34	33
2014	7	15	2	10	27	0.883	-0.098	4.675	0.01	0.007	0	41.7	39.1	71.4	131	124	0	34	33
2014	7	15	2	20	27	0.886	-0.075	4.678	0.013	0.01	0	43	40.4	71.4	134	127	0	34	33
2014	7	15	2	30	27	0.873	-0.095	4.678	0.01	0.007	0	41.7	39.6	70.5	131	125	0	34	33
2014	7	15	2	40	27	0.879	-0.082	4.678	0.01	0.007	0	43	40.4	71.4	134	127	0	34	33
2014	7	15	2	50	27	0.883	-0.095	4.678	0.01	0.007	0	43	40.4	71.8	134	126	0	34	32
2014	7	15	3	0	27	0.879	-0.069	4.678	0.01	0.007	0	43.4	40.9	71.4	135	127	0	34	32
2014	7	15	3	10	27	0.906	-0.066	4.678	0.01	0.007	0	43	40	71.8	134	126	0	34	33
2014	7	15	3	20	27	0.889	-0.089	4.678	0.01	0.007	0	43	40.9	71.4	133	127	0	33	32
2014	7	15	3	30	27	0.896	-0.079	4.678	0.01	0.007	0	43.9	41.3	71.4	135	128	0	33	32
2014	7	15	3	40	27	0.879	-0.092	4.678	0.01	0.007	0	43	40.4	72.2	133	126	0	33	32
2014	7	15	3	50	27	0.915	-0.082	4.678	0.013	0.01	0	43.4	40.4	72.2	135	127	0	34	33
2014	7	15	4	0	27	0.896	-0.079	4.678	0.013	0.01	0	43.4	40.9	71.8	135	128	0	34	33
2014	7	15	4	10	27	0.876	-0.059	4.678	0.01	0.007	0	43.9	40.9	66.2	135	128	0	33	33
2014	7	15	4	20	27	0.896	-0.095	4.682	0.01	0.007	0	43.9	41.3	72.7	136	129	0	34	33
2014	7	15	4	30	27	0.928	-0.085	4.682	0.01	0.007	0	43.9	40.9	72.7	135	128	0	33	33
2014	7	15	4	40	27	0.883	-0.095	4.682	0.01	0.007	0	43.4	40.4	72.7	135	127	0	34	33
2014	7	15	4	50	27	0.896	-0.062	4.682	0.013	0.01	0	43	40	73.5	134	126	0	34	33
2014	7	15	5	0	27	0.892	-0.069	4.682	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2014	7	15	5	10	27	0.899	-0.079	4.682	0.013	0.01	0	43.9	40.9	74	136	128	0	34	33
2014	7	15	5	20	27	0.883	-0.098	4.685	0.01	0.007	0	43.4	40.9	73.5	135	128	0	34	33
2014	7	15	5	30	27	0.879	-0.075	4.682	0.01	0.007	0	43	40.4	74.4	134	127	0	34	33
2014	7	15	5	40	27	0.883	-0.036	4.685	0.01	0.007	0	42.6	40	74	133	126	0	34	33
2014	7	15	5	50	27	0.876	-0.069	4.685	0.01	0.007	0	42.6	40	74	133	126	0	34	33
2014	7	15	6	0	27	0.873	-0.089	4.685	0.01	0.007	0	43.4	40	74	134	126	0	33	33
2014	7	15	6	10	27	0.889	-0.082	4.685	0.01	0.007	0	42.6	39.6	74.8	133	125	0	34	33
2014	7	15	6	20	27	0.899	-0.079	4.685	0.01	0.007	0	41.7	39.1	74.4	131	124	0	34	33
2014	7	15	6	30	27	0.886	-0.075	4.685	0.01	0.007	0	41.7	39.1	74.8	131	124	0	34	33
2014	7	15	6	40	27	0.876	-0.085	4.685	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	15	6	50	27	0.902	-0.069	4.685	0.01	0.007	0	42.1	39.1	74.8	132	124	0	34	33
2014	7	15	7	0	27	0.902	-0.075	4.685	0.013	0.01	0	42.6	40	70.1	133	126	0	34	33
2014	7	15	7	10	27	0.886	-0.079	4.685	0.01	0.007	0	42.6	40	73.5	133	126	0	34	33
2014	7	15	7	20	27	0.883	-0.112	4.685	0.01	0.007	0	42.1	38.7	58	131	123	0	33	33
2014	7	15	7	30	27	0.889	-0.066	4.682	0.01	0.007	0	41.7	39.1	54.6	131	124	0	34	33
2014	7	15	7	40	27	0.883	-0.089	4.682	0.01	0.007	0	41.7	38.7	53.8	131	124	0	34	34
2014	7	15	7	50	27	0.896	-0.112	4.682	0.01	0.007	0	45.2	42.1	48.6	139	130	0	34	32
2014	7	15	8	0	27	0.886	-0.069	4.685	0.01	0.007	0	45.6	43	51.2	140	133	0	34	33
2014	7	15	8	10	27	0.915	-0.049	4.685	0.01	0.007	0	45.6	42.6	55.5	140	132	0	34	33
2014	7	15	8	20	27	0.876	-0.102	4.685	0.01	0.007	0	44.7	42.1	63.2	138	130	0	34	32
2014	7	15	8	30	27	0.902	-0.079	4.685	0.01	0.007	0	43.9	40.9	69.2	136	128	0	34	33
2014	7	15	8	40	27	0.906	-0.079	4.685	0.01	0.007	0	43.4	40.9	67.5	135	128	0	34	33
2014	7	15	8	50	27	0.919	-0.108	4.685	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2014	7	15	9	0	27	0.889	-0.066	4.688	0.01	0.007	0	42.6	40.4	72.2	134	127	0	35	33
2014	7	15	9	10	27	0.873	-0.079	4.685	0.013	0.01	0	41.7	39.6	72.2	132	124	0	35	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	9	20	27	0.896	-0.095	4.685	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	15	9	30	27	0.879	-0.082	4.685	0.01	0.007	0	41.7	39.6	72.7	131	124	0	34	32
2014	7	15	9	40	27	0.889	-0.082	4.685	0.01	0.007	0	41.3	38.7	74	131	123	0	35	33
2014	7	15	9	50	27	0.889	-0.072	4.685	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	15	10	0	27	0.922	-0.046	4.685	0.01	0.007	0	41.7	39.1	71.8	131	124	0	34	33
2014	7	15	10	10	27	0.896	-0.089	4.688	0.01	0.007	0	41.7	39.1	72.2	131	124	0	34	33
2014	7	15	10	20	27	0.873	-0.089	4.688	0.01	0.007	0	41.7	39.1	74.4	131	124	0	34	33
2014	7	15	10	30	27	0.866	-0.089	4.685	0.01	0.007	0	42.1	39.6	74.8	132	125	0	34	33
2014	7	15	10	40	27	0.915	-0.164	4.685	0.013	0.01	0	41.3	38.3	75.3	130	122	0	34	33
2014	7	15	10	50	27	0.866	-0.112	4.685	0.01	0.007	0	41.7	38.7	64.1	131	123	0	34	33
2014	7	15	11	0	27	0.886	-0.098	4.685	0.01	0.007	0	41.3	38.7	57.6	130	123	0	34	33
2014	7	15	11	10	27	0.889	-0.131	4.685	0.01	0.007	0	41.3	38.7	67.1	130	122	0	34	32
2014	7	15	11	20	27	0.909	-0.144	4.685	0.01	0.007	0	40.9	38.7	73.5	129	122	0	34	32
2014	7	15	11	30	27	0.892	-0.131	4.685	0.01	0.007	0	41.3	38.3	71.4	129	123	0	33	34
2014	7	15	11	40	27	0.889	-0.154	4.685	0.01	0.007	0	41.3	38.3	74	130	123	0	34	34
2014	7	15	11	50	27	0.899	-0.128	4.685	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	15	12	0	27	0.892	-0.102	4.685	0.01	0.007	0	41.3	38.7	71.8	130	123	0	34	33
2014	7	15	12	10	27	0.883	-0.105	4.685	0.01	0.007	0	41.7	39.1	71.8	131	124	0	34	33
2014	7	15	12	20	27	0.876	-0.102	4.685	0.01	0.007	0	40.9	38.7	64.9	129	123	0	34	33
2014	7	15	12	30	27	0.883	-0.118	4.685	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2014	7	15	12	40	27	0.915	-0.148	4.685	0.01	0.007	0	40.9	38.3	62.8	129	121	0	34	32
2014	7	15	12	50	27	0.892	-0.167	4.685	0.01	0.007	0	40.4	38.3	62.4	128	122	0	34	33
2014	7	15	13	0	27	0.902	-0.144	4.685	0.01	0.007	0	40.4	38.3	58.5	128	122	0	34	33
2014	7	15	13	10	27	0.899	-0.075	4.682	0.01	0.007	0	40.4	37.8	55	128	121	0	34	33
2014	7	15	13	20	27	0.86	-0.19	4.682	0.01	0.007	0	40.4	37.8	60.6	128	121	0	34	33
2014	7	15	13	30	27	0.883	-0.148	4.682	0.01	0.007	0	40.4	37.8	56.8	128	121	0	34	33
2014	7	15	13	40	27	0.912	-0.18	4.682	0.01	0.007	0	40.4	37.4	58.9	128	121	0	34	34
2014	7	15	13	50	27	0.863	-0.197	4.682	0.01	0.007	0	41.3	38.3	56.3	129	122	0	33	33
2014	7	15	14	0	27	0.892	-0.135	4.682	0.013	0.01	0	40.4	38.3	58.9	129	122	0	35	33
2014	7	15	14	10	27	0.902	-0.167	4.682	0.01	0.007	0	40.4	37.8	57.2	128	121	0	34	33
2014	7	15	14	20	27	0.879	-0.066	4.678	0.01	0.007	0	40.9	38.7	55	129	122	0	34	32
2014	7	15	14	30	27	0.869	-0.164	4.678	0.013	0.01	0	40.9	37.8	54.2	129	121	0	34	33
2014	7	15	14	40	27	0.856	-0.135	4.682	0.01	0.007	0	40.9	38.3	51.6	129	122	0	34	33
2014	7	15	14	50	27	0.892	-0.085	4.678	0.01	0.007	0	40.4	37.8	55.5	128	121	0	34	33
2014	7	15	15	0	27	0.912	-0.131	4.678	0.01	0.007	0	40.4	37.8	53.8	129	121	0	35	33
2014	7	15	15	10	27	0.886	-0.141	4.678	0.01	0.007	0	40.9	37.8	54.2	129	122	0	34	34
2014	7	15	15	20	27	0.856	-0.135	4.678	0.01	0.007	0	42.6	38.7	52.9	133	123	0	34	33
2014	7	15	15	30	27	0.912	-0.089	4.678	0.01	0.007	0	42.6	40	52.9	133	126	0	34	33
2014	7	15	15	40	27	0.856	-0.138	4.678	0.01	0.007	0	41.7	38.7	52	130	123	0	33	33
2014	7	15	15	50	27	0.935	-0.135	4.675	0.01	0.007	0	41.7	39.1	54.6	131	124	0	34	33
2014	7	15	16	0	27	0.938	-0.079	4.675	0.01	0.007	0	44.7	42.1	51.2	138	131	0	34	33
2014	7	15	16	10	27	0.883	-0.138	4.675	0.01	0.007	0	41.7	38.3	49.9	131	122	0	34	33
2014	7	15	16	20	27	0.909	-0.128	4.675	0.01	0.007	0	40.9	38.3	52	129	122	0	34	33
2014	7	15	16	30	27	0.899	-0.125	4.675	0.01	0.007	0	40.4	37.8	55	128	121	0	34	33
2014	7	15	16	40	27	0.912	-0.154	4.672	0.01	0.007	0	40.9	38.7	55	129	122	0	34	32
2014	7	15	16	50	27	0.883	-0.148	4.672	0.01	0.007	0	40.9	38.3	52.9	129	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	17	0	27	0.886	-0.164	4.672	0.01	0.007	0	40.9	38.3	52.9	129	122	0	34	33
2014	7	15	17	10	27	0.876	-0.174	4.669	0.01	0.007	0	40.4	37.8	55.5	128	121	0	34	33
2014	7	15	17	20	27	0.886	-0.108	4.672	0.01	0.007	0	41.3	37.8	53.8	129	121	0	33	33
2014	7	15	17	30	27	0.876	-0.125	4.672	0.01	0.007	0	40.9	37.8	52.9	129	121	0	34	33
2014	7	15	17	40	27	0.906	-0.154	4.672	0.01	0.007	0	40.4	37.4	55.5	128	120	0	34	33
2014	7	15	17	50	27	0.892	-0.118	4.669	0.01	0.007	0	41.7	38.3	52	130	122	0	33	33
2014	7	15	18	0	27	0.889	-0.105	4.672	0.01	0.007	0	41.7	39.6	52.5	132	125	0	35	33
2014	7	15	18	10	27	0.896	-0.164	4.672	0.01	0.007	0	41.3	38.3	53.8	129	121	0	33	32
2014	7	15	18	20	27	0.915	-0.125	4.665	0.013	0.01	0	40.9	37.8	58.9	129	121	0	34	33
2014	7	15	18	30	27	0.873	-0.154	4.665	0.013	0.01	0	40.4	37.8	58.5	128	121	0	34	33
2014	7	15	18	40	27	0.876	-0.141	4.665	0.01	0.007	0	40.4	37.4	61.5	128	120	0	34	33
2014	7	15	18	50	27	0.876	-0.131	4.665	0.01	0.007	0	40.4	37.8	57.6	128	121	0	34	33
2014	7	15	19	0	27	0.896	-0.144	4.669	0.01	0.007	0	40.9	38.3	54.6	129	122	0	34	33
2014	7	15	19	10	27	0.892	-0.118	4.665	0.01	0.007	0	40.9	38.7	58.5	129	122	0	34	32
2014	7	15	19	20	27	0.876	-0.102	4.665	0.01	0.007	0	40.9	37.8	61.9	129	121	0	34	33
2014	7	15	19	30	27	0.902	-0.095	4.665	0.01	0.007	0	40.9	37.4	55.9	129	121	0	34	34
2014	7	15	19	40	27	0.899	-0.108	4.665	0.01	0.007	0	41.3	38.3	63.6	129	122	0	33	33
2014	7	15	19	50	27	0.919	-0.102	4.665	0.01	0.007	0	40.9	38.3	67.5	130	122	0	35	33
2014	7	15	20	0	27	0.899	-0.121	4.665	0.01	0.007	0	41.3	38.3	67.5	131	122	0	35	33
2014	7	15	20	10	27	0.886	-0.105	4.665	0.01	0.007	0	41.3	38.3	68.4	130	122	0	34	33
2014	7	15	20	20	27	0.902	-0.066	4.669	0.013	0.01	0	42.1	39.6	59.8	132	124	0	34	32
2014	7	15	20	30	27	0.902	-0.075	4.669	0.016	0.013	0	44.3	41.7	48.6	137	129	0	34	32
2014	7	15	20	40	27	0.896	-0.056	4.669	0.01	0.007	0	49.9	47.3	49	150	143	0	34	33
2014	7	15	20	50	27	0.873	-0.066	4.669	0.01	0.007	0	50.3	47.3	49.9	151	143	0	34	33
2014	7	15	21	0	27	0.869	-0.036	4.669	0.013	0.01	0	50.3	46.9	51.2	150	142	0	33	33
2014	7	15	21	10	27	0.889	-0.062	4.669	0.01	0.007	0	49	46	49	148	140	0	34	33
2014	7	15	21	20	27	0.902	-0.066	4.672	0.01	0.007	0	48.2	45.2	51.2	146	138	0	34	33
2014	7	15	21	30	27	0.883	-0.082	4.672	0.01	0.007	0	47.7	44.3	50.7	144	136	0	33	33
2014	7	15	21	40	27	0.869	-0.075	4.672	0.01	0.007	0	46.9	43.9	51.2	143	135	0	34	33
2014	7	15	21	50	27	0.899	-0.066	4.672	0.01	0.007	0	46.4	43.4	49	142	134	0	34	33
2014	7	15	22	0	27	0.906	-0.072	4.675	0.01	0.007	0	46.4	43.9	51.6	141	134	0	33	32
2014	7	15	22	10	27	0.863	-0.03	4.672	0.01	0.007	0	46.4	43.4	51.6	141	133	0	33	32
2014	7	15	22	20	27	0.869	-0.036	4.672	0.01	0.007	0	46	43	51.6	141	133	0	34	33
2014	7	15	22	30	27	0.886	-0.069	4.675	0.01	0.007	0	45.6	42.6	51.6	140	132	0	34	33
2014	7	15	22	40	27	0.899	-0.069	4.675	0.013	0.01	0	44.7	42.1	52.9	138	131	0	34	33
2014	7	15	22	50	27	0.869	-0.033	4.675	0.013	0.01	0	44.7	41.7	52.5	138	130	0	34	33
2014	7	15	23	0	27	0.886	-0.056	4.675	0.01	0.007	0	44.3	41.3	52.9	137	129	0	34	33
2014	7	15	23	10	27	0.866	-0.085	4.675	0.01	0.007	0	44.3	41.3	54.2	137	129	0	34	33
2014	7	15	23	20	27	0.876	-0.066	4.678	0.01	0.007	0	44.3	41.3	53.8	136	129	0	33	33
2014	7	15	23	30	27	0.902	-0.052	4.678	0.01	0.007	0	43.9	41.3	57.2	136	129	0	34	33
2014	7	15	23	40	27	0.869	-0.066	4.678	0.01	0.007	0	43.9	40.9	66.2	135	128	0	33	33
2014	7	15	23	50	27	0.909	-0.082	4.678	0.01	0.007	0	43.4	40.4	65.4	135	127	0	34	33
2014	7	16	0	0	27	0.873	-0.062	4.678	0.01	0.007	0	43.4	40.9	66.7	135	127	0	34	32
2014	7	16	0	10	27	0.869	-0.075	4.682	0.01	0.007	0	43.4	40.9	70.1	135	128	0	34	33
2014	7	16	0	20	27	0.892	-0.082	4.682	0.013	0.01	0	44.3	41.3	69.7	136	128	0	33	32
2014	7	16	0	30	27	0.869	-0.03	4.682	0.01	0.007	0	43.9	40	71.8	135	127	0	33	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	0	40	27	0.899	-0.092	4.682	0.01	0.007	0	43.4	40.9	71.4	135	128	0	34	33
2014	7	16	0	50	27	0.879	-0.082	4.682	0.01	0.007	0	43.9	40.9	71.4	136	128	0	34	33
2014	7	16	1	0	27	0.906	-0.072	4.682	0.01	0.007	0	43.4	40	71	134	126	0	33	33
2014	7	16	1	10	27	0.886	-0.075	4.685	0.01	0.007	0	42.6	40	71.4	133	126	0	34	33
2014	7	16	1	20	27	0.886	-0.066	4.685	0.01	0.007	0	43.4	40	72.7	134	126	0	33	33
2014	7	16	1	30	27	0.896	-0.098	4.682	0.01	0.007	0	42.6	40.4	72.2	133	126	0	34	32
2014	7	16	1	40	27	0.886	-0.072	4.685	0.01	0.007	0	42.6	39.6	72.2	133	125	0	34	33
2014	7	16	1	50	27	0.922	-0.062	4.685	0.01	0.007	0	43	40.4	72.2	134	127	0	34	33
2014	7	16	2	0	27	0.883	-0.082	4.685	0.01	0.007	0	43	40	72.2	134	126	0	34	33
2014	7	16	2	10	27	0.892	-0.092	4.685	0.01	0.007	0	42.6	39.6	72.7	132	125	0	33	33
2014	7	16	2	20	27	0.869	-0.033	4.685	0.01	0.007	0	43	40	72.2	134	126	0	34	33
2014	7	16	2	30	27	0.886	-0.072	4.685	0.01	0.007	0	43	40.4	71.4	134	127	0	34	33
2014	7	16	2	40	27	0.869	-0.069	4.685	0.01	0.007	0	43.4	40.9	72.7	135	128	0	34	33
2014	7	16	2	50	27	0.899	-0.092	4.685	0.01	0.007	0	43.4	41.3	74	135	128	0	34	32
2014	7	16	3	0	27	0.896	-0.062	4.685	0.01	0.007	0	43.4	40.9	72.7	136	129	0	35	34
2014	7	16	3	10	27	0.886	-0.069	4.685	0.01	0.007	0	43.4	40.4	72.7	134	127	0	33	33
2014	7	16	3	20	27	0.919	-0.075	4.685	0.01	0.007	0	42.6	40	74	133	126	0	34	33
2014	7	16	3	30	27	0.879	-0.079	4.685	0.01	0.007	0	43.4	40.4	73.1	135	127	0	34	33
2014	7	16	3	40	27	0.876	-0.069	4.685	0.01	0.007	0	43	40.4	74.4	134	127	0	34	33
2014	7	16	3	50	27	0.892	-0.108	4.685	0.01	0.007	0	42.6	40	74.4	133	126	0	34	33
2014	7	16	4	0	27	0.876	-0.082	4.685	0.01	0.007	0	43.4	40.4	73.5	134	127	0	33	33
2014	7	16	4	10	27	0.883	-0.118	4.685	0.01	0.007	0	42.6	40	74.4	133	126	0	34	33
2014	7	16	4	20	27	0.892	-0.082	4.688	0.01	0.007	0	43	40.4	74.8	134	126	0	34	32
2014	7	16	4	30	27	0.886	-0.082	4.688	0.01	0.007	0	42.6	40	74.8	133	126	0	34	33
2014	7	16	4	40	27	0.909	-0.069	4.685	0.01	0.007	0	43	40.9	74.8	134	127	0	34	32
2014	7	16	4	50	27	0.902	-0.085	4.688	0.013	0.01	0	43.4	40.4	73.1	135	127	0	34	33
2014	7	16	5	0	27	0.886	-0.092	4.688	0.01	0.007	0	43.4	40.9	73.5	136	128	0	35	33
2014	7	16	5	10	27	0.892	-0.066	4.688	0.01	0.007	0	43	40.9	75.3	135	128	0	35	33
2014	7	16	5	20	27	0.915	-0.089	4.688	0.013	0.01	0	43.4	40.9	74.8	135	128	0	34	33
2014	7	16	5	30	27	0.912	-0.075	4.688	0.01	0.007	0	43.4	40.9	74.4	135	128	0	34	33
2014	7	16	5	40	27	0.896	-0.056	4.688	0.01	0.007	0	42.1	40	75.7	133	126	0	35	33
2014	7	16	5	50	27	0.902	-0.069	4.688	0.01	0.007	0	43	39.6	74.4	133	125	0	33	33
2014	7	16	6	0	27	0.873	-0.079	4.688	0.01	0.007	0	42.1	40	75.7	132	125	0	34	32
2014	7	16	6	10	27	0.879	-0.059	4.688	0.01	0.007	0	41.3	39.1	75.7	131	124	0	35	33
2014	7	16	6	20	27	0.876	-0.066	4.688	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	16	6	30	27	0.906	-0.089	4.688	0.01	0.007	0	41.3	38.7	74	131	123	0	35	33
2014	7	16	6	40	27	0.856	-0.062	4.688	0.01	0.007	0	41.7	39.1	76.1	131	124	0	34	33
2014	7	16	6	50	27	0.856	-0.066	4.688	0.01	0.007	0	41.7	39.6	76.1	131	124	0	34	32
2014	7	16	7	0	27	0.889	-0.089	4.688	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	16	7	10	27	0.85	-0.049	4.688	0.01	0.007	0	42.1	39.1	75.3	132	124	0	34	33
2014	7	16	7	20	27	0.866	-0.062	4.688	0.01	0.007	0	41.3	39.1	75.7	131	124	0	35	33
2014	7	16	7	30	27	0.876	-0.092	4.688	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	16	7	40	27	0.896	-0.072	4.688	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	16	7	50	27	0.919	-0.069	4.688	0.01	0.007	0	41.7	38.7	75.7	131	124	0	34	34
2014	7	16	8	0	27	0.886	-0.069	4.688	0.01	0.007	0	42.1	40	75.7	132	125	0	34	32
2014	7	16	8	10	27	0.889	-0.066	4.688	0.01	0.007	0	41.7	39.6	75.7	131	124	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	8	20	27	0.892	-0.092	4.688	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	16	8	30	27	0.912	-0.121	4.688	0.01	0.007	0	41.3	38.7	74.4	130	123	0	34	33
2014	7	16	8	40	27	0.938	-0.112	4.688	0.01	0.007	0	40.9	38.7	75.3	130	123	0	35	33
2014	7	16	8	50	27	0.846	-0.092	4.688	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	16	9	0	27	0.869	-0.066	4.688	0.01	0.007	0	41.7	39.1	74.8	131	124	0	34	33
2014	7	16	9	10	27	0.922	-0.105	4.688	0.01	0.007	0	41.3	38.7	71.4	130	123	0	34	33
2014	7	16	9	20	27	0.896	-0.082	4.688	0.013	0.01	0	41.3	38.7	73.5	130	123	0	34	33
2014	7	16	9	30	27	0.922	-0.128	4.688	0.01	0.007	0	41.7	39.1	74	130	123	0	33	32
2014	7	16	9	40	27	0.906	-0.095	4.688	0.01	0.007	0	40.9	39.1	75.3	130	124	0	35	33
2014	7	16	9	50	27	0.896	-0.128	4.688	0.01	0.007	0	40.9	38.7	76.1	129	123	0	34	33
2014	7	16	10	0	27	0.876	-0.125	4.688	0.01	0.007	0	41.3	38.7	75.3	130	123	0	34	33
2014	7	16	10	10	27	0.906	-0.105	4.688	0.01	0.007	0	41.3	39.1	74	130	123	0	34	32
2014	7	16	10	20	27	0.912	-0.164	4.688	0.01	0.007	0	40.9	37.8	75.3	129	122	0	34	34
2014	7	16	10	30	27	0.912	-0.121	4.685	0.01	0.007	0	41.3	38.7	74	130	123	0	34	33
2014	7	16	10	40	27	0.922	-0.115	4.688	0.013	0.01	0	41.3	38.7	71.4	130	123	0	34	33
2014	7	16	10	50	27	0.886	-0.148	4.685	0.01	0.007	0	41.3	38.3	74.8	129	122	0	33	33
2014	7	16	11	0	27	0.883	-0.108	4.685	0.016	0.013	0	40.9	38.3	72.2	129	122	0	34	33
2014	7	16	11	10	27	0.883	-0.121	4.685	0.01	0.007	0	41.3	38.7	72.2	129	122	0	33	32
2014	7	16	11	20	27	0.883	-0.154	4.685	0.01	0.007	0	40.9	38.3	74	129	122	0	34	33
2014	7	16	11	30	27	0.912	-0.121	4.685	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	16	11	40	27	0.86	-0.115	4.685	0.01	0.007	0	40.9	38.3	72.2	129	121	0	34	32
2014	7	16	11	50	27	0.886	-0.108	4.682	0.01	0.007	0	40.9	38.7	64.1	129	122	0	34	32
2014	7	16	12	0	27	0.886	-0.157	4.685	0.01	0.007	0	40.4	37.8	70.1	128	121	0	34	33
2014	7	16	12	10	27	0.883	-0.161	4.682	0.01	0.007	0	40.4	37.8	71.4	128	121	0	34	33
2014	7	16	12	20	27	0.892	-0.151	4.682	0.013	0.01	0	40.4	37.8	62.4	128	121	0	34	33
2014	7	16	12	30	27	0.876	-0.131	4.682	0.01	0.007	0	40.9	37.8	69.2	129	121	0	34	33
2014	7	16	12	40	27	0.883	-0.135	4.682	0.01	0.007	0	40.9	38.3	55	128	121	0	33	32
2014	7	16	12	50	27	0.892	-0.151	4.682	0.01	0.007	0	40.4	37.8	65.4	128	121	0	34	33
2014	7	16	13	0	27	0.896	-0.144	4.678	0.01	0.007	0	40.9	38.3	57.2	129	122	0	34	33
2014	7	16	13	10	27	0.876	-0.157	4.678	0.01	0.007	0	40	37.8	63.2	128	121	0	35	33
2014	7	16	13	20	27	0.873	-0.154	4.682	0.01	0.007	0	40.4	37.8	52.9	128	121	0	34	33
2014	7	16	13	30	27	0.876	-0.164	4.678	0.01	0.007	0	40.9	38.7	54.2	129	122	0	34	32
2014	7	16	13	40	27	0.879	-0.148	4.675	0.01	0.007	0	40.9	38.3	55.9	129	121	0	34	32
2014	7	16	13	50	27	0.883	-0.148	4.675	0.01	0.007	0	40.4	38.3	58	128	121	0	34	32
2014	7	16	14	0	27	0.886	-0.161	4.675	0.01	0.007	0	40.4	38.3	56.8	128	121	0	34	32
2014	7	16	14	10	27	0.863	-0.128	4.672	0.01	0.007	0	41.3	38.3	56.8	129	122	0	33	33
2014	7	16	14	20	27	0.889	-0.144	4.672	0.01	0.007	0	40.4	37.8	56.8	128	121	0	34	33
2014	7	16	14	30	27	0.856	-0.167	4.672	0.01	0.007	0	40.9	37.8	56.3	128	121	0	33	33
2014	7	16	14	40	27	0.856	-0.161	4.672	0.01	0.007	0	41.3	38.3	54.6	129	121	0	33	32
2014	7	16	14	50	27	0.876	-0.18	4.669	0.01	0.007	0	40.9	37.8	59.3	128	121	0	33	33
2014	7	16	15	0	27	0.892	-0.098	4.669	0.01	0.007	0	41.3	38.3	62.8	129	122	0	33	33
2014	7	16	15	10	27	0.869	-0.148	4.669	0.01	0.007	0	40.9	37.8	57.2	129	121	0	34	33
2014	7	16	15	20	27	0.883	-0.148	4.669	0.01	0.007	0	40.4	38.3	60.6	128	121	0	34	32
2014	7	16	15	30	27	0.869	-0.131	4.665	0.01	0.007	0	40.9	38.7	64.9	129	122	0	34	32
2014	7	16	15	40	27	0.883	-0.135	4.669	0.01	0.007	0	40.9	38.7	54.6	129	122	0	34	32
2014	7	16	15	50	27	0.919	-0.161	4.665	0.01	0.007	0	40.9	38.7	55.9	129	122	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	16	0	27	0.919	-0.154	4.665	0.01	0.007	0	40.4	37.8	61.9	128	121	0	34	33
2014	7	16	16	10	27	0.892	-0.115	4.665	0.01	0.007	0	40.4	38.3	63.6	128	121	0	34	32
2014	7	16	16	20	27	0.906	-0.121	4.665	0.01	0.007	0	41.3	37.8	62.4	129	121	0	33	33
2014	7	16	16	30	27	0.912	-0.128	4.665	0.01	0.007	0	40.9	38.3	69.2	129	122	0	34	33
2014	7	16	16	40	27	0.856	-0.092	4.665	0.01	0.007	0	41.3	38.7	74	129	122	0	33	32
2014	7	16	16	50	27	0.883	-0.098	4.665	0.01	0.007	0	40.9	38.7	74	129	122	0	34	32
2014	7	16	17	0	27	0.889	-0.082	4.665	0.01	0.007	0	40.4	38.3	73.1	129	122	0	35	33
2014	7	16	17	10	27	0.906	-0.082	4.665	0.013	0.01	0	40.9	37.8	72.7	129	121	0	34	33
2014	7	16	17	20	27	0.879	-0.082	4.665	0.01	0.007	0	40.9	38.3	72.2	129	122	0	34	33
2014	7	16	17	30	27	0.889	-0.082	4.665	0.01	0.007	0	40.9	38.3	73.1	129	122	0	34	33
2014	7	16	17	40	27	0.889	-0.079	4.665	0.01	0.007	0	42.1	39.1	63.6	132	125	0	34	34
2014	7	16	17	50	27	0.915	-0.075	4.665	0.01	0.007	0	41.7	38.7	59.8	131	123	0	34	33
2014	7	16	18	0	27	0.876	-0.092	4.665	0.01	0.007	0	40.9	38.7	64.1	129	122	0	34	32
2014	7	16	18	10	27	0.889	-0.066	4.665	0.01	0.007	0	40.9	37.8	71.4	129	121	0	34	33
2014	7	16	18	20	27	0.876	-0.069	4.672	0.01	0.007	0	42.1	39.1	54.6	132	124	0	34	33
2014	7	16	18	30	27	0.876	-0.062	4.672	0.01	0.007	0	42.1	39.6	53.3	132	124	0	34	32
2014	7	16	18	40	27	0.922	-0.089	4.665	0.01	0.007	0	42.6	39.1	63.2	132	124	0	33	33
2014	7	16	18	50	27	0.909	-0.059	4.669	0.013	0.01	0	42.1	39.6	61.1	131	124	0	33	32
2014	7	16	19	0	27	0.876	-0.049	4.669	0.01	0.007	0	42.1	39.6	61.9	132	124	0	34	32
2014	7	16	19	10	27	0.889	-0.069	4.669	0.01	0.007	0	41.7	38.7	56.8	130	123	0	33	33
2014	7	16	19	20	27	0.889	-0.062	4.669	0.013	0.01	0	41.3	38.7	56.3	130	123	0	34	33
2014	7	16	19	30	27	0.873	-0.072	4.669	0.01	0.007	0	41.7	39.1	58	131	124	0	34	33
2014	7	16	19	40	27	0.883	-0.066	4.669	0.01	0.007	0	41.3	38.7	60.2	130	123	0	34	33
2014	7	16	19	50	27	0.896	-0.056	4.669	0.01	0.007	0	42.1	40	55.9	132	125	0	34	32
2014	7	16	20	0	27	0.883	-0.075	4.669	0.01	0.007	0	42.6	40	61.9	133	125	0	34	32
2014	7	16	20	10	27	0.886	-0.049	4.669	0.01	0.007	0	42.1	39.6	57.6	132	125	0	34	33
2014	7	16	20	20	27	0.892	-0.069	4.665	0.01	0.007	0	42.6	40.4	67.1	133	126	0	34	32
2014	7	16	20	30	27	0.869	-0.056	4.669	0.016	0.013	0	43	40.4	57.2	134	127	0	34	33
2014	7	16	20	40	27	0.86	-0.056	4.669	0.01	0.007	0	42.6	40	58.9	133	126	0	34	33
2014	7	16	20	50	27	0.902	-0.072	4.669	0.01	0.007	0	42.1	39.6	64.5	132	125	0	34	33
2014	7	16	21	0	27	0.869	-0.098	4.665	0.01	0.007	0	42.6	39.6	65.4	133	125	0	34	33
2014	7	16	21	10	27	0.902	-0.072	4.669	0.01	0.007	0	42.1	38.3	60.6	131	123	0	33	34
2014	7	16	21	20	27	0.883	-0.085	4.669	0.013	0.01	0	41.7	39.6	56.3	131	124	0	34	32
2014	7	16	21	30	27	0.853	-0.069	4.669	0.01	0.007	0	42.1	39.1	59.3	132	124	0	34	33
2014	7	16	21	40	27	0.886	-0.098	4.669	0.01	0.007	0	41.7	38.7	70.5	131	123	0	34	33
2014	7	16	21	50	27	0.879	-0.062	4.669	0.01	0.007	0	41.7	38.7	72.2	131	123	0	34	33
2014	7	16	22	0	27	0.896	-0.056	4.669	0.01	0.007	0	42.1	38.7	65.8	131	123	0	33	33
2014	7	16	22	10	27	0.892	-0.062	4.669	0.01	0.007	0	41.7	38.7	67.1	131	123	0	34	33
2014	7	16	22	20	27	0.889	-0.075	4.669	0.01	0.007	0	41.3	38.7	69.7	130	123	0	34	33
2014	7	16	22	30	27	0.892	-0.085	4.669	0.01	0.007	0	40.9	38.3	70.5	129	122	0	34	33
2014	7	16	22	40	27	0.873	-0.079	4.669	0.01	0.007	0	41.3	38.3	72.2	130	122	0	34	33
2014	7	16	22	50	27	0.902	-0.082	4.669	0.01	0.007	0	41.7	39.1	73.1	130	123	0	33	32
2014	7	16	23	0	27	0.906	-0.082	4.669	0.01	0.007	0	40.9	38.3	72.7	129	121	0	34	32
2014	7	16	23	10	27	0.899	-0.052	4.669	0.01	0.007	0	42.1	39.1	72.2	131	124	0	33	33
2014	7	16	23	20	27	0.892	-0.062	4.669	0.01	0.007	0	41.3	38.3	73.1	129	122	0	33	33
2014	7	16	23	30	27	0.896	-0.066	4.669	0.01	0.007	0	40.9	37.4	72.2	128	120	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	23	40	27	0.922	-0.075	4.669	0.01	0.007	0	40.9	38.3	72.7	129	122	0	34	33
2014	7	16	23	50	27	0.879	-0.089	4.669	0.01	0.007	0	40.9	38.7	73.1	129	122	0	34	32
2014	7	17	0	0	27	0.876	-0.082	4.669	0.01	0.007	0	40.9	38.3	73.1	129	122	0	34	33
2014	7	17	0	10	27	0.886	-0.079	4.669	0.01	0.007	0	40.9	37.8	72.7	128	121	0	33	33
2014	7	17	0	20	27	0.889	-0.059	4.669	0.01	0.007	0	41.3	38.7	73.1	130	122	0	34	32
2014	7	17	0	30	27	0.863	-0.069	4.669	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	17	0	40	27	0.86	-0.062	4.669	0.01	0.007	0	41.3	38.7	71.8	130	122	0	34	32
2014	7	17	0	50	27	0.876	-0.052	4.669	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	17	1	0	27	0.883	-0.102	4.669	0.01	0.007	0	40.4	38.3	72.2	129	121	0	35	32
2014	7	17	1	10	27	0.892	-0.082	4.669	0.01	0.007	0	40.9	38.3	72.7	129	122	0	34	33
2014	7	17	1	20	27	0.889	-0.075	4.669	0.01	0.007	0	40.9	38.3	71	129	122	0	34	33
2014	7	17	1	30	27	0.876	-0.069	4.669	0.01	0.007	0	41.7	39.1	71.4	131	124	0	34	33
2014	7	17	1	40	27	0.876	-0.069	4.669	0.01	0.007	0	41.7	39.1	71.4	131	123	0	34	32
2014	7	17	1	50	27	0.863	-0.069	4.669	0.01	0.007	0	42.1	39.1	71.4	131	123	0	33	32
2014	7	17	2	0	27	0.902	-0.072	4.669	0.01	0.007	0	40.9	38.7	66.2	129	122	0	34	32
2014	7	17	2	10	27	0.889	-0.049	4.672	0.01	0.007	0	42.1	39.1	71.4	132	124	0	34	33
2014	7	17	2	20	27	0.863	-0.082	4.678	0.013	0.01	0	41.3	39.1	70.5	130	123	0	34	32
2014	7	17	2	30	27	0.889	-0.072	4.682	0.01	0.007	0	41.7	39.6	71.4	131	124	0	34	32
2014	7	17	2	40	27	0.876	-0.049	4.682	0.013	0.01	0	42.6	40	70.5	133	125	0	34	32
2014	7	17	2	50	27	0.889	-0.082	4.682	0.01	0.007	0	41.7	38.7	71.8	131	123	0	34	33
2014	7	17	3	0	27	0.86	-0.092	4.685	0.01	0.007	0	42.6	39.6	72.7	133	125	0	34	33
2014	7	17	3	10	27	0.906	-0.075	4.685	0.01	0.007	0	42.1	39.1	72.7	131	124	0	33	33
2014	7	17	3	20	27	0.896	-0.082	4.685	0.01	0.007	0	42.1	39.1	68.4	131	124	0	33	33
2014	7	17	3	30	27	0.915	-0.075	4.685	0.01	0.007	0	42.6	40	72.7	132	125	0	33	32
2014	7	17	3	40	27	0.896	-0.082	4.688	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	17	3	50	27	0.896	-0.095	4.688	0.01	0.007	0	41.7	39.6	74	131	124	0	34	32
2014	7	17	4	0	27	0.906	-0.072	4.688	0.01	0.007	0	41.7	39.6	72.7	131	124	0	34	32
2014	7	17	4	10	27	0.886	-0.082	4.688	0.01	0.007	0	42.6	39.6	74	133	125	0	34	33
2014	7	17	4	20	27	0.899	-0.082	4.688	0.01	0.007	0	42.1	39.1	75.3	132	124	0	34	33
2014	7	17	4	30	27	0.902	-0.079	4.688	0.01	0.007	0	42.6	39.6	74.4	132	125	0	33	33
2014	7	17	4	40	27	0.902	-0.092	4.688	0.01	0.007	0	42.1	39.1	74	131	123	0	33	32
2014	7	17	4	50	27	0.883	-0.075	4.688	0.01	0.007	0	41.7	39.6	74	131	124	0	34	32
2014	7	17	5	0	27	0.883	-0.085	4.688	0.01	0.007	0	42.1	39.6	75.3	132	125	0	34	33
2014	7	17	5	10	27	0.896	-0.079	4.688	0.013	0.01	0	42.1	39.6	75.3	132	125	0	34	33
2014	7	17	5	20	27	0.909	-0.069	4.692	0.01	0.007	0	41.7	39.1	75.3	131	124	0	34	33
2014	7	17	5	30	27	0.892	-0.082	4.692	0.01	0.007	0	41.7	38.7	75.3	131	123	0	34	33
2014	7	17	5	40	27	0.896	-0.079	4.692	0.01	0.007	0	42.1	39.6	75.7	132	125	0	34	33
2014	7	17	5	50	27	0.873	-0.079	4.692	0.01	0.007	0	42.1	39.6	73.1	132	125	0	34	33
2014	7	17	6	0	27	0.883	-0.066	4.692	0.01	0.007	0	43	40	75.3	134	126	0	34	33
2014	7	17	6	10	27	0.896	-0.072	4.692	0.01	0.007	0	41.7	39.1	75.7	131	124	0	34	33
2014	7	17	6	20	27	0.883	-0.079	4.692	0.01	0.007	0	40.9	39.1	74.8	130	123	0	35	32
2014	7	17	6	30	27	0.856	-0.089	4.692	0.01	0.007	0	41.3	38.3	75.3	130	122	0	34	33
2014	7	17	6	40	27	0.889	-0.049	4.692	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	17	6	50	27	0.906	-0.062	4.692	0.01	0.007	0	41.7	38.7	75.7	131	123	0	34	33
2014	7	17	7	0	27	0.899	-0.082	4.692	0.01	0.007	0	40.9	38.3	75.7	129	122	0	34	33
2014	7	17	7	10	27	0.886	-0.075	4.692	0.01	0.007	0	41.3	38.7	75.3	130	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	7	20	27	0.912	-0.072	4.692	0.01	0.007	0	40.4	38.3	75.7	128	121	0	34	32
2014	7	17	7	30	27	0.902	-0.082	4.692	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	17	7	40	27	0.899	-0.066	4.692	0.01	0.007	0	40.9	38.3	75.3	128	122	0	33	33
2014	7	17	7	50	27	0.906	-0.082	4.692	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	17	8	0	27	0.892	-0.092	4.692	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	17	8	10	27	0.86	-0.052	4.692	0.016	0.013	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	17	8	20	27	0.883	-0.082	4.692	0.01	0.007	0	41.3	38.7	75.7	130	123	0	34	33
2014	7	17	8	30	27	0.879	-0.095	4.692	0.01	0.007	0	41.3	39.1	76.1	130	124	0	34	33
2014	7	17	8	40	27	0.899	-0.112	4.692	0.01	0.007	0	41.3	38.7	72.7	130	123	0	34	33
2014	7	17	8	50	27	0.899	-0.072	4.692	0.01	0.007	0	41.7	39.1	75.3	130	123	0	33	32
2014	7	17	9	0	27	0.889	-0.072	4.692	0.01	0.007	0	41.3	38.7	76.1	130	123	0	34	33
2014	7	17	9	10	27	0.902	-0.059	4.692	0.016	0.013	0	41.3	38.7	76.1	130	123	0	34	33
2014	7	17	9	20	27	0.932	-0.098	4.692	0.01	0.007	0	41.3	38.7	76.1	130	123	0	34	33
2014	7	17	9	30	27	0.892	-0.135	4.692	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	17	9	40	27	0.869	-0.082	4.692	0.01	0.007	0	40.9	38.3	75.3	129	122	0	34	33
2014	7	17	9	50	27	0.886	-0.151	4.692	0.01	0.007	0	40.9	38.7	76.1	129	122	0	34	32
2014	7	17	10	0	27	0.899	-0.125	4.692	0.01	0.007	0	40.9	38.3	74.4	129	122	0	34	33
2014	7	17	10	10	27	0.899	-0.112	4.692	0.01	0.007	0	40.9	38.3	74	129	122	0	34	33
2014	7	17	10	20	27	0.892	-0.118	4.692	0.013	0.01	0	40.9	38.7	76.1	129	123	0	34	33
2014	7	17	10	30	27	0.925	-0.157	4.692	0.01	0.007	0	40.9	38.3	74.8	128	122	0	33	33
2014	7	17	10	40	27	0.899	-0.177	4.692	0.01	0.007	0	40.4	38.3	75.7	129	122	0	35	33
2014	7	17	10	50	27	0.886	-0.066	4.685	0.01	0.007	0	46	42.6	45.2	141	132	0	34	33
2014	7	17	11	0	27	0.922	-0.148	4.685	0.01	0.007	0	50.3	48.2	51.6	151	144	0	34	32
2014	7	17	11	10	27	0.951	-0.125	4.685	0.01	0.007	0	46.4	44.7	45.6	142	137	0	34	33
2014	7	17	11	20	27	0.928	-0.187	4.685	0.01	0.007	0	44.3	42.1	46	138	131	0	35	33
2014	7	17	11	30	27	0.919	-0.098	4.685	0.01	0.007	0	43.4	41.3	43	135	129	0	34	33
2014	7	17	11	40	27	0.892	-0.167	4.688	0.01	0.007	0	40	38.3	60.6	127	122	0	34	33
2014	7	17	11	50	27	0.86	-0.148	4.685	0.01	0.007	0	42.6	40.9	49.5	133	128	0	34	33
2014	7	17	12	0	27	0.896	-0.121	4.682	0.01	0.007	0	49	43.9	31	147	135	0	33	33
2014	7	17	12	10	27	0.886	-0.121	4.685	0.01	0.007	0	47.3	44.3	38.7	144	136	0	34	33
2014	7	17	12	20	27	0.909	-0.118	4.685	0.01	0.007	0	48.6	47.3	47.3	147	142	0	34	32
2014	7	17	12	30	27	0.915	-0.184	4.685	0.01	0.007	0	42.1	40.4	48.6	132	127	0	34	33
2014	7	17	12	40	27	0.797	-0.112	4.685	0.01	0.007	0	43.4	41.7	46	135	130	0	34	33
2014	7	17	12	50	27	0.869	-0.046	4.688	0.01	0.007	0	44.7	41.3	44.3	138	129	0	34	33
2014	7	17	13	0	27	0.866	-0.151	4.685	0.01	0.007	0	46	42.1	47.7	140	131	0	33	33
2014	7	17	13	10	27	0.876	-0.18	4.688	0.01	0.007	0	41.7	38.7	57.6	131	122	0	34	32
2014	7	17	13	20	27	0.853	-0.23	4.685	0.01	0.007	0	41.3	37.8	60.6	130	121	0	34	33
2014	7	17	13	30	27	0.869	-0.141	4.682	0.01	0.007	0	46.9	43	41.3	143	133	0	34	33
2014	7	17	13	40	27	0.863	-0.177	4.685	0.01	0.007	0	42.6	39.6	47.3	134	125	0	35	33
2014	7	17	13	50	27	0.886	-0.135	4.682	0.01	0.007	0	45.2	40.9	41.3	139	128	0	34	33
2014	7	17	14	0	27	0.906	-0.121	4.685	0.01	0.007	0	43.9	40.9	45.2	136	128	0	34	33
2014	7	17	14	10	27	0.876	-0.131	4.685	0.01	0.007	0	41.3	38.3	54.6	130	122	0	34	33
2014	7	17	14	20	27	0.873	-0.171	4.685	0.013	0.01	0	41.7	38.3	59.8	130	122	0	33	33
2014	7	17	14	30	27	0.846	-0.151	4.685	0.013	0.01	0	41.7	38.3	55.9	130	122	0	33	33
2014	7	17	14	40	27	0.876	-0.167	4.682	0.01	0.007	0	40.9	38.3	62.4	129	122	0	34	33
2014	7	17	14	50	27	0.853	-0.171	4.682	0.01	0.007	0	41.3	38.3	55	130	121	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	15	0	27	0.902	-0.138	4.678	0.01	0.007	0	43.4	40	49.9	135	126	0	34	33
2014	7	17	15	10	27	0.899	-0.085	4.678	0.01	0.007	0	44.7	41.3	48.2	139	128	0	35	32
2014	7	17	15	20	27	0.869	-0.138	4.678	0.01	0.007	0	42.6	39.1	54.2	133	124	0	34	33
2014	7	17	15	30	27	0.856	-0.144	4.678	0.01	0.007	0	41.3	38.3	54.6	130	122	0	34	33
2014	7	17	15	40	27	0.83	-0.112	4.675	0.01	0.007	0	41.7	38.3	53.8	131	122	0	34	33
2014	7	17	15	50	27	0.827	-0.164	4.678	0.01	0.007	0	42.1	39.1	52	132	124	0	34	33
2014	7	17	16	0	27	0.873	-0.131	4.678	0.01	0.007	0	41.7	38.7	53.3	131	123	0	34	33
2014	7	17	16	10	27	0.84	-0.118	4.678	0.013	0.01	0	42.1	39.1	52	132	124	0	34	33
2014	7	17	16	20	27	0.843	-0.108	4.682	0.01	0.007	0	42.1	39.1	51.6	132	124	0	34	33
2014	7	17	16	30	27	0.892	-0.082	4.682	0.01	0.007	0	43	40.4	49.9	134	127	0	34	33
2014	7	17	16	40	27	0.873	-0.089	4.678	0.01	0.007	0	42.1	39.6	52.5	132	124	0	34	32
2014	7	17	16	50	27	0.85	-0.131	4.678	0.01	0.007	0	41.7	39.1	51.6	131	123	0	34	32
2014	7	17	17	0	27	0.853	-0.157	4.678	0.01	0.007	0	42.1	39.6	49.9	132	124	0	34	32
2014	7	17	17	10	27	0.889	-0.112	4.678	0.01	0.007	0	41.7	38.7	52	131	123	0	34	33
2014	7	17	17	20	27	0.86	-0.115	4.678	0.01	0.007	0	42.6	38.7	52	132	123	0	33	33
2014	7	17	17	30	27	0.889	-0.115	4.678	0.01	0.007	0	41.7	38.7	54.2	131	123	0	34	33
2014	7	17	17	40	27	0.873	-0.072	4.678	0.01	0.007	0	41.3	39.1	54.2	131	123	0	35	32
2014	7	17	17	50	27	0.869	-0.135	4.675	0.01	0.007	0	41.7	38.3	51.6	131	122	0	34	33
2014	7	17	18	0	27	0.863	-0.138	4.675	0.01	0.007	0	41.7	38.7	48.6	131	122	0	34	32
2014	7	17	18	10	27	0.869	-0.082	4.675	0.01	0.007	0	41.7	39.1	53.3	131	123	0	34	32
2014	7	17	18	20	27	0.889	-0.108	4.675	0.01	0.007	0	41.7	38.7	53.3	131	122	0	34	32
2014	7	17	18	30	27	0.889	-0.072	4.675	0.01	0.007	0	42.1	38.3	55.9	131	122	0	33	33
2014	7	17	18	40	27	0.866	-0.043	4.675	0.01	0.007	0	42.1	38.7	59.3	132	123	0	34	33
2014	7	17	18	50	27	0.902	-0.066	4.678	0.013	0.01	0	42.1	38.7	54.2	132	123	0	34	33
2014	7	17	19	0	27	0.886	-0.062	4.675	0.01	0.007	0	45.6	42.1	52	140	131	0	34	33
2014	7	17	19	10	27	0.899	-0.069	4.675	0.013	0.01	0	46.4	43.9	52.9	142	134	0	34	32
2014	7	17	19	20	27	0.899	-0.085	4.675	0.01	0.007	0	46	43	52.9	141	132	0	34	32
2014	7	17	19	30	27	0.863	-0.069	4.675	0.013	0.01	0	46	42.6	53.3	140	131	0	33	32
2014	7	17	19	40	27	0.86	-0.059	4.672	0.013	0.01	0	45.2	42.6	53.3	139	130	0	34	31
2014	7	17	19	50	27	0.866	-0.033	4.675	0.01	0.007	0	46	42.6	52.9	140	131	0	33	32
2014	7	17	20	0	27	0.863	-0.046	4.675	0.01	0.007	0	45.2	41.7	55	138	129	0	33	32
2014	7	17	20	10	27	0.889	-0.049	4.678	0.01	0.007	0	44.3	41.7	54.6	137	129	0	34	32
2014	7	17	20	20	27	0.869	-0.016	4.678	0.01	0.007	0	44.3	41.3	53.8	137	129	0	34	33
2014	7	17	20	30	27	0.909	-0.062	4.675	0.01	0.007	0	44.3	41.7	55	137	129	0	34	32
2014	7	17	20	40	27	0.892	-0.082	4.678	0.01	0.007	0	44.3	41.3	55.5	137	129	0	34	33
2014	7	17	20	50	27	0.886	-0.062	4.678	0.01	0.007	0	44.3	40.4	57.6	137	127	0	34	33
2014	7	17	21	0	27	0.869	-0.062	4.675	0.01	0.007	0	43.9	40.4	63.2	136	127	0	34	33
2014	7	17	21	10	27	0.85	-0.052	4.675	0.016	0.013	0	43.9	40.9	66.2	136	127	0	34	32
2014	7	17	21	20	27	0.846	-0.062	4.675	0.01	0.007	0	43.4	40.4	66.2	135	127	0	34	33
2014	7	17	21	30	27	0.869	-0.046	4.675	0.01	0.007	0	43	40	67.1	134	126	0	34	33
2014	7	17	21	40	27	0.876	-0.049	4.678	0.01	0.007	0	43	39.6	66.7	133	124	0	33	32
2014	7	17	21	50	27	0.86	-0.046	4.678	0.01	0.007	0	42.1	38.7	60.2	132	123	0	34	33
2014	7	17	22	0	27	0.86	-0.066	4.682	0.01	0.007	0	42.6	40	55.5	133	125	0	34	32
2014	7	17	22	10	27	0.899	-0.075	4.682	0.01	0.007	0	42.6	39.1	55.5	132	123	0	33	32
2014	7	17	22	20	27	0.892	-0.069	4.682	0.01	0.007	0	42.1	38.7	55.9	132	123	0	34	33
2014	7	17	22	30	27	0.883	-0.082	4.682	0.013	0.01	0	42.1	39.1	55.5	132	123	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	22	40	27	0.886	-0.066	4.682	0.01	0.007	0	42.1	39.1	58.9	132	123	0	34	32
2014	7	17	22	50	27	0.883	-0.066	4.682	0.01	0.007	0	42.6	39.1	71.4	132	123	0	33	32
2014	7	17	23	0	27	0.84	-0.082	4.685	0.01	0.007	0	42.1	38.7	71.4	131	123	0	33	33
2014	7	17	23	10	27	0.899	-0.082	4.685	0.013	0.01	0	42.1	38.3	71.8	131	122	0	33	33
2014	7	17	23	20	27	0.883	-0.085	4.685	0.01	0.007	0	41.7	38.3	70.5	131	122	0	34	33
2014	7	17	23	30	27	0.86	-0.062	4.685	0.01	0.007	0	42.1	39.1	71.4	131	123	0	33	32
2014	7	17	23	40	27	0.902	-0.066	4.685	0.013	0.01	0	42.1	39.1	72.2	132	123	0	34	32
2014	7	17	23	50	27	0.866	-0.075	4.685	0.01	0.007	0	40.9	38.3	72.2	130	121	0	35	32
2014	7	18	0	0	27	0.85	-0.066	4.685	0.01	0.007	0	41.3	37.8	72.2	130	121	0	34	33
2014	7	18	0	10	27	0.863	-0.056	4.685	0.01	0.007	0	42.1	38.3	72.2	131	122	0	33	33
2014	7	18	0	20	27	0.896	-0.062	4.688	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	18	0	30	27	0.886	-0.079	4.688	0.01	0.007	0	42.1	38.3	72.7	131	122	0	33	33
2014	7	18	0	40	27	0.889	-0.082	4.688	0.01	0.007	0	41.7	38.3	72.7	131	122	0	34	33
2014	7	18	0	50	27	0.876	-0.082	4.678	0.01	0.007	0	46	43	49	141	133	0	34	33
2014	7	18	1	0	27	0.876	-0.059	4.688	0.01	0.007	0	41.7	37.8	72.7	131	122	0	34	34
2014	7	18	1	10	27	0.889	-0.059	4.688	0.01	0.007	0	41.7	38.3	72.2	131	122	0	34	33
2014	7	18	1	20	27	0.879	-0.066	4.688	0.01	0.007	0	42.1	38.7	73.5	131	123	0	33	33
2014	7	18	1	30	27	0.883	-0.049	4.688	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	18	1	40	27	0.876	-0.098	4.688	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	18	1	50	27	0.869	-0.069	4.688	0.013	0.01	0	42.1	38.7	74	132	123	0	34	33
2014	7	18	2	0	27	0.883	-0.066	4.688	0.01	0.007	0	42.1	38.7	73.1	131	122	0	33	32
2014	7	18	2	10	27	0.876	-0.082	4.688	0.013	0.01	0	41.7	38.7	74	131	122	0	34	32
2014	7	18	2	20	27	0.856	-0.082	4.688	0.013	0.01	0	42.6	38.7	73.5	133	123	0	34	33
2014	7	18	2	30	27	0.85	-0.052	4.688	0.01	0.007	0	42.6	39.6	74	133	124	0	34	32
2014	7	18	2	40	27	0.886	-0.082	4.692	0.013	0.01	0	41.7	37.8	74.8	131	121	0	34	33
2014	7	18	2	50	27	0.889	-0.056	4.692	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	18	3	0	27	0.873	-0.066	4.688	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	18	3	10	27	0.876	-0.036	4.692	0.01	0.007	0	42.1	39.1	74.8	132	123	0	34	32
2014	7	18	3	20	27	0.853	-0.082	4.692	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	18	3	30	27	0.863	-0.072	4.692	0.01	0.007	0	43.4	39.6	74.4	134	125	0	33	33
2014	7	18	3	40	27	0.869	-0.046	4.692	0.01	0.007	0	43	39.1	75.3	133	124	0	33	33
2014	7	18	3	50	27	0.886	-0.072	4.692	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	18	4	0	27	0.899	-0.082	4.692	0.01	0.007	0	42.6	38.7	75.7	133	123	0	34	33
2014	7	18	4	10	27	0.883	-0.082	4.692	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	18	4	20	27	0.873	-0.095	4.692	0.01	0.007	0	43	39.1	75.3	134	124	0	34	33
2014	7	18	4	30	27	0.879	-0.105	4.692	0.01	0.007	0	42.1	39.1	75.3	132	124	0	34	33
2014	7	18	4	40	27	0.886	-0.046	4.692	0.01	0.007	0	43.4	40	75.7	135	126	0	34	33
2014	7	18	4	50	27	0.869	-0.069	4.692	0.01	0.007	0	42.6	39.1	76.1	133	124	0	34	33
2014	7	18	5	0	27	0.902	-0.069	4.692	0.01	0.007	0	43	39.6	76.1	133	124	0	33	32
2014	7	18	5	10	27	0.866	-0.069	4.692	0.01	0.007	0	42.1	39.1	76.1	132	123	0	34	32
2014	7	18	5	20	27	0.896	-0.079	4.692	0.01	0.007	0	42.6	38.7	75.7	133	123	0	34	33
2014	7	18	5	30	27	0.899	-0.059	4.692	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	18	5	40	27	0.889	-0.089	4.692	0.013	0.01	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	18	5	50	27	0.869	-0.082	4.692	0.013	0.01	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	18	6	0	27	0.879	-0.046	4.692	0.013	0.01	0	43.4	39.6	74.4	134	125	0	33	33
2014	7	18	6	10	27	0.886	-0.105	4.692	0.01	0.007	0	42.1	39.1	75.7	132	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	6	20	27	0.86	-0.059	4.692	0.01	0.007	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	18	6	30	27	0.866	-0.082	4.692	0.01	0.007	0	41.7	38.7	75.7	132	123	0	35	33
2014	7	18	6	40	27	0.873	-0.089	4.692	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	18	6	50	27	0.86	-0.069	4.692	0.01	0.007	0	42.1	38.3	75.3	131	122	0	33	33
2014	7	18	7	0	27	0.886	-0.059	4.692	0.01	0.007	0	41.7	38.3	74.4	131	122	0	34	33
2014	7	18	7	10	27	0.863	-0.023	4.692	0.013	0.01	0	41.7	38.7	75.3	131	122	0	34	32
2014	7	18	7	20	27	0.896	-0.066	4.695	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	18	7	30	27	0.876	-0.066	4.695	0.01	0.007	0	41.3	38.7	75.3	130	122	0	34	32
2014	7	18	7	40	27	0.883	-0.089	4.692	0.01	0.007	0	41.3	38.7	75.7	130	122	0	34	32
2014	7	18	7	50	27	0.873	-0.079	4.692	0.01	0.007	0	41.3	38.3	74.8	130	122	0	34	33
2014	7	18	8	0	27	0.866	-0.095	4.692	0.01	0.007	0	41.3	37.8	74.8	130	122	0	34	34
2014	7	18	8	10	27	0.856	-0.082	4.695	0.013	0.01	0	43	39.1	75.3	133	124	0	33	33
2014	7	18	8	20	27	0.869	-0.102	4.695	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	18	8	30	27	0.883	-0.082	4.695	0.016	0.013	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	18	8	40	27	0.879	-0.066	4.695	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	18	8	50	27	0.896	-0.056	4.695	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	18	9	0	27	0.896	-0.072	4.695	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	18	9	10	27	0.866	-0.085	4.695	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	18	9	20	27	0.899	-0.085	4.692	0.01	0.007	0	41.7	39.1	74.4	131	123	0	34	32
2014	7	18	9	30	27	0.909	-0.112	4.692	0.01	0.007	0	42.1	38.3	74.4	131	122	0	33	33
2014	7	18	9	40	27	0.873	-0.138	4.692	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	18	9	50	27	0.892	-0.135	4.695	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	18	10	0	27	0.886	-0.177	4.692	0.01	0.007	0	41.3	37.4	74.4	129	120	0	33	33
2014	7	18	10	10	27	0.922	-0.121	4.692	0.01	0.007	0	41.3	37.8	75.7	130	121	0	34	33
2014	7	18	10	20	27	0.879	-0.121	4.692	0.01	0.007	0	41.7	38.3	73.5	130	121	0	33	32
2014	7	18	10	30	27	0.909	-0.128	4.692	0.01	0.007	0	40.9	37.8	75.7	129	121	0	34	33
2014	7	18	10	40	27	0.886	-0.118	4.692	0.01	0.007	0	41.3	38.3	74.8	130	121	0	34	32
2014	7	18	10	50	27	0.892	-0.141	4.692	0.01	0.007	0	40.9	37	76.1	129	120	0	34	34
2014	7	18	11	0	27	0.896	-0.151	4.692	0.01	0.007	0	41.3	37.8	74	130	121	0	34	33
2014	7	18	11	10	27	0.883	-0.138	4.692	0.01	0.007	0	41.3	37.8	75.7	129	120	0	33	32
2014	7	18	11	20	27	0.899	-0.112	4.692	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	18	11	30	27	0.856	-0.171	4.692	0.01	0.007	0	40.4	37.4	75.7	128	120	0	34	33
2014	7	18	11	40	27	0.909	-0.082	4.692	0.013	0.01	0	40.9	38.3	75.7	129	121	0	34	32
2014	7	18	11	50	27	0.869	-0.167	4.692	0.01	0.007	0	40.4	36.5	72.7	128	119	0	34	34
2014	7	18	12	0	27	0.863	-0.19	4.692	0.01	0.007	0	40.9	37.8	65.8	129	121	0	34	33
2014	7	18	12	10	27	0.869	-0.157	4.692	0.01	0.007	0	40.9	37.8	68.8	129	120	0	34	32
2014	7	18	12	20	27	0.876	-0.148	4.692	0.01	0.007	0	40.4	37.4	62.4	128	120	0	34	33
2014	7	18	12	30	27	0.886	-0.144	4.692	0.01	0.007	0	40.4	37.8	59.8	128	120	0	34	32
2014	7	18	12	40	27	0.906	-0.177	4.692	0.01	0.007	0	40.9	37.4	61.5	128	120	0	33	33
2014	7	18	12	50	27	0.856	-0.135	4.688	0.013	0.01	0	40.4	37.4	57.2	128	119	0	34	32
2014	7	18	13	0	27	0.889	-0.161	4.688	0.01	0.007	0	40.9	37.4	58.5	129	120	0	34	33
2014	7	18	13	10	27	0.85	-0.184	4.688	0.01	0.007	0	40.9	37.4	56.3	129	120	0	34	33
2014	7	18	13	20	27	0.866	-0.092	4.692	0.01	0.007	0	40.9	37.8	55.9	129	121	0	34	33
2014	7	18	13	30	27	0.863	-0.131	4.688	0.01	0.007	0	40.9	37.8	56.8	129	120	0	34	32
2014	7	18	13	40	27	0.846	-0.128	4.678	0.013	0.01	0	50.7	46.4	37	152	140	0	34	32
2014	7	18	13	50	27	0.876	-0.151	4.688	0.01	0.007	0	42.1	39.1	53.3	132	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	14	0	27	0.85	-0.177	4.688	0.01	0.007	0	43.4	41.3	54.6	135	128	0	34	32
2014	7	18	14	10	27	0.876	-0.174	4.688	0.01	0.007	0	40.9	37.8	55	129	121	0	34	33
2014	7	18	14	20	27	0.863	-0.161	4.688	0.01	0.007	0	40.9	37.4	54.6	129	120	0	34	33
2014	7	18	14	30	27	0.856	-0.194	4.685	0.01	0.007	0	40.4	37.4	58.9	129	120	0	35	33
2014	7	18	14	40	27	0.833	-0.21	4.685	0.01	0.007	0	43	40.9	54.2	135	128	0	35	33
2014	7	18	14	50	27	0.869	-0.164	4.682	0.01	0.007	0	46	41.7	46.4	141	130	0	34	33
2014	7	18	15	0	27	0.945	-0.112	4.685	0.013	0.01	0	47.7	42.1	43.4	145	131	0	34	33
2014	7	18	15	10	27	0.866	-0.118	4.685	0.013	0.01	0	46.9	44.3	54.2	143	136	0	34	33
2014	7	18	15	20	27	0.889	-0.164	4.685	0.016	0.013	0	41.3	37.8	53.3	130	121	0	34	33
2014	7	18	15	30	27	0.866	-0.131	4.685	0.01	0.007	0	41.3	38.3	53.3	130	122	0	34	33
2014	7	18	15	40	27	0.83	-0.161	4.682	0.01	0.007	0	43	38.3	51.2	134	122	0	34	33
2014	7	18	15	50	27	0.863	-0.131	4.685	0.01	0.007	0	41.3	39.1	50.7	131	123	0	35	32
2014	7	18	16	0	27	0.856	-0.115	4.685	0.01	0.007	0	41.7	38.7	54.2	131	123	0	34	33
2014	7	18	16	10	27	0.863	-0.098	4.682	0.01	0.007	0	41.7	38.7	52.9	131	122	0	34	32
2014	7	18	16	20	27	0.886	-0.131	4.682	0.01	0.007	0	41.3	38.3	51.6	130	122	0	34	33
2014	7	18	16	30	27	0.883	-0.167	4.682	0.01	0.007	0	41.7	38.7	50.7	131	123	0	34	33
2014	7	18	16	40	27	0.886	-0.105	4.678	0.013	0.01	0	41.7	38.7	52	131	123	0	34	33
2014	7	18	16	50	27	0.883	-0.125	4.678	0.013	0.01	0	42.1	39.1	52.5	131	123	0	33	32
2014	7	18	17	0	27	0.853	-0.164	4.678	0.01	0.007	0	42.6	39.1	50.7	132	123	0	33	32
2014	7	18	17	10	27	0.873	-0.098	4.678	0.01	0.007	0	41.7	38.7	51.6	131	123	0	34	33
2014	7	18	17	20	27	0.869	-0.148	4.675	0.01	0.007	0	42.6	39.1	48.6	133	124	0	34	33
2014	7	18	17	30	27	0.86	-0.098	4.682	0.01	0.007	0	42.1	38.7	52.5	132	123	0	34	33
2014	7	18	17	40	27	0.906	-0.105	4.682	0.01	0.007	0	42.1	38.3	51.2	131	122	0	33	33
2014	7	18	17	50	27	0.863	-0.128	4.678	0.01	0.007	0	41.3	38.3	52.5	130	122	0	34	33
2014	7	18	18	0	27	0.873	-0.115	4.678	0.01	0.007	0	41.3	38.3	52.5	130	122	0	34	33
2014	7	18	18	10	27	0.866	-0.066	4.675	0.01	0.007	0	41.7	38.3	53.8	131	122	0	34	33
2014	7	18	18	20	27	0.919	-0.121	4.678	0.01	0.007	0	45.2	42.6	47.7	139	131	0	34	32
2014	7	18	18	30	27	0.906	-0.105	4.682	0.013	0.01	0	46.9	43.9	51.6	142	135	0	33	33
2014	7	18	18	40	27	0.902	-0.102	4.675	0.01	0.007	0	42.1	38.7	55	132	123	0	34	33
2014	7	18	18	50	27	0.909	-0.128	4.678	0.01	0.007	0	43	40.4	50.7	134	126	0	34	32
2014	7	18	19	0	27	0.892	-0.108	4.678	0.01	0.007	0	43	39.1	52.5	134	124	0	34	33
2014	7	18	19	10	27	0.892	-0.131	4.678	0.01	0.007	0	41.3	37.8	56.3	130	121	0	34	33
2014	7	18	19	20	27	0.879	-0.128	4.678	0.01	0.007	0	41.7	38.3	55	131	122	0	34	33
2014	7	18	19	30	27	0.899	-0.125	4.678	0.01	0.007	0	42.1	38.3	54.2	131	122	0	33	33
2014	7	18	19	40	27	0.892	-0.112	4.682	0.01	0.007	0	42.1	38.7	50.7	132	122	0	34	32
2014	7	18	19	50	27	0.863	-0.095	4.678	0.01	0.007	0	42.6	39.6	52	133	124	0	34	32
2014	7	18	20	0	27	0.925	-0.115	4.678	0.01	0.007	0	42.1	39.1	53.8	132	124	0	34	33
2014	7	18	20	10	27	0.899	-0.112	4.678	0.01	0.007	0	42.1	39.6	50.3	132	123	0	34	31
2014	7	18	20	20	27	0.866	-0.075	4.682	0.01	0.007	0	43	39.6	51.6	134	125	0	34	33
2014	7	18	20	30	27	0.892	-0.075	4.682	0.01	0.007	0	42.6	39.6	52.5	133	124	0	34	32
2014	7	18	20	40	27	0.853	-0.072	4.682	0.01	0.007	0	42.6	39.6	51.6	134	125	0	35	33
2014	7	18	20	50	27	0.876	-0.102	4.682	0.01	0.007	0	42.6	39.1	54.6	133	124	0	34	33
2014	7	18	21	0	27	0.896	-0.089	4.678	0.01	0.007	0	43	39.6	53.8	133	124	0	33	32
2014	7	18	21	10	27	0.889	-0.095	4.682	0.01	0.007	0	41.7	38.7	51.2	132	122	0	35	32
2014	7	18	21	20	27	0.86	-0.049	4.682	0.01	0.007	0	42.1	38.7	54.2	132	123	0	34	33
2014	7	18	21	30	27	0.889	-0.072	4.685	0.01	0.007	0	41.7	38.7	63.2	131	122	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	21	40	27	0.899	-0.069	4.685	0.01	0.007	0	42.1	39.1	61.1	132	123	0	34	32
2014	7	18	21	50	27	0.886	-0.089	4.685	0.01	0.007	0	43	39.1	70.1	134	125	0	34	34
2014	7	18	22	0	27	0.892	-0.059	4.685	0.01	0.007	0	42.6	39.1	71.4	133	124	0	34	33
2014	7	18	22	10	27	0.883	-0.059	4.685	0.01	0.007	0	42.1	39.1	64.1	132	123	0	34	32
2014	7	18	22	20	27	0.85	-0.052	4.685	0.01	0.007	0	42.1	38.7	62.8	132	123	0	34	33
2014	7	18	22	30	27	0.892	-0.125	4.685	0.01	0.007	0	40.9	36.5	52.9	129	119	0	34	34
2014	7	18	22	40	27	0.869	-0.112	4.685	0.01	0.007	0	42.1	38.7	53.8	132	123	0	34	33
2014	7	18	22	50	27	0.869	-0.108	4.685	0.01	0.007	0	41.7	38.3	66.7	131	122	0	34	33
2014	7	18	23	0	27	0.873	-0.082	4.688	0.01	0.007	0	42.6	40	72.7	133	125	0	34	32
2014	7	18	23	10	27	0.892	-0.082	4.688	0.01	0.007	0	42.6	38.7	74	132	123	0	33	33
2014	7	18	23	20	27	0.869	-0.079	4.688	0.01	0.007	0	42.1	38.3	74	131	122	0	33	33
2014	7	18	23	30	27	0.899	-0.069	4.688	0.01	0.007	0	41.7	38.7	73.5	131	122	0	34	32
2014	7	18	23	40	27	0.902	-0.062	4.688	0.01	0.007	0	42.6	39.1	69.7	133	124	0	34	33
2014	7	18	23	50	27	0.899	-0.082	4.688	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	19	0	0	27	0.869	-0.075	4.688	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	19	0	10	27	0.883	-0.075	4.688	0.013	0.01	0	42.1	38.7	73.5	132	122	0	34	32
2014	7	19	0	20	27	0.876	-0.082	4.688	0.01	0.007	0	42.6	38.7	74	132	122	0	33	32
2014	7	19	0	30	27	0.866	-0.049	4.688	0.01	0.007	0	42.6	39.1	74.4	132	124	0	33	33
2014	7	19	0	40	27	0.889	-0.046	4.692	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	19	0	50	27	0.889	-0.062	4.692	0.01	0.007	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	19	1	0	27	0.86	-0.082	4.692	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	19	1	10	27	0.876	-0.085	4.692	0.01	0.007	0	41.7	37.8	74.8	131	121	0	34	33
2014	7	19	1	20	27	0.869	-0.066	4.692	0.01	0.007	0	41.7	37.8	75.3	131	121	0	34	33
2014	7	19	1	30	27	0.879	-0.079	4.692	0.01	0.007	0	43	39.1	74.8	133	124	0	33	33
2014	7	19	1	40	27	0.86	-0.052	4.692	0.013	0.01	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	19	1	50	27	0.889	-0.098	4.692	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	19	2	0	27	0.892	-0.082	4.692	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	19	2	10	27	0.892	-0.108	4.692	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	19	2	20	27	0.892	-0.082	4.692	0.01	0.007	0	41.7	37.8	74.8	130	121	0	33	33
2014	7	19	2	30	27	0.886	-0.066	4.692	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	19	2	40	27	0.876	-0.118	4.692	0.01	0.007	0	41.3	38.3	75.3	131	122	0	35	33
2014	7	19	2	50	27	0.853	-0.072	4.692	0.01	0.007	0	43	39.6	74	134	125	0	34	33
2014	7	19	3	0	27	0.883	-0.069	4.692	0.01	0.007	0	43	39.6	75.7	134	124	0	34	32
2014	7	19	3	10	27	0.873	-0.079	4.692	0.013	0.01	0	42.6	39.6	75.7	133	124	0	34	32
2014	7	19	3	20	27	0.853	-0.092	4.692	0.01	0.007	0	42.6	38.7	74.8	132	123	0	33	33
2014	7	19	3	30	27	0.883	-0.066	4.692	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	19	3	40	27	0.866	-0.085	4.692	0.01	0.007	0	42.6	39.1	75.7	133	124	0	34	33
2014	7	19	3	50	27	0.856	-0.062	4.692	0.01	0.007	0	43	39.6	75.3	134	125	0	34	33
2014	7	19	4	0	27	0.863	-0.066	4.692	0.01	0.007	0	43.4	40.4	75.3	135	126	0	34	32
2014	7	19	4	10	27	0.889	-0.066	4.692	0.013	0.01	0	43	40	75.3	134	126	0	34	33
2014	7	19	4	20	27	0.886	-0.098	4.692	0.01	0.007	0	43.4	40	75.7	135	126	0	34	33
2014	7	19	4	30	27	0.889	-0.046	4.695	0.01	0.007	0	43.4	40	74.4	134	125	0	33	32
2014	7	19	4	40	27	0.889	-0.046	4.695	0.01	0.007	0	43.9	40.4	75.3	136	127	0	34	33
2014	7	19	4	50	27	0.909	-0.059	4.692	0.01	0.007	0	43	40	70.1	134	125	0	34	32
2014	7	19	5	0	27	0.866	-0.056	4.695	0.013	0.01	0	43	39.6	74.4	134	125	0	34	33
2014	7	19	5	10	27	0.896	-0.082	4.695	0.01	0.007	0	43	40	74.8	134	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	5	20	27	0.873	-0.062	4.695	0.01	0.007	0	43.4	40.4	74.4	135	126	0	34	32
2014	7	19	5	30	27	0.883	-0.062	4.695	0.01	0.007	0	42.6	39.1	74.4	133	124	0	34	33
2014	7	19	5	40	27	0.883	-0.066	4.695	0.01	0.007	0	43	40	74.4	134	125	0	34	32
2014	7	19	5	50	27	0.892	-0.066	4.695	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	19	6	0	27	0.883	-0.056	4.695	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	19	6	10	27	0.883	-0.079	4.695	0.01	0.007	0	42.1	39.1	74	132	123	0	34	32
2014	7	19	6	20	27	0.886	-0.092	4.695	0.01	0.007	0	42.6	38.7	74.4	132	123	0	33	33
2014	7	19	6	30	27	0.883	-0.079	4.695	0.01	0.007	0	41.3	38.3	73.5	130	122	0	34	33
2014	7	19	6	40	27	0.873	-0.049	4.695	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	19	6	50	27	0.912	-0.066	4.695	0.01	0.007	0	40.9	38.3	74.8	130	121	0	35	32
2014	7	19	7	0	27	0.892	-0.046	4.695	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	19	7	10	27	0.866	-0.036	4.695	0.01	0.007	0	41.7	38.7	74.4	131	122	0	34	32
2014	7	19	7	20	27	0.85	-0.079	4.695	0.01	0.007	0	41.3	37.8	74.4	130	121	0	34	33
2014	7	19	7	30	27	0.889	-0.046	4.695	0.01	0.007	0	41.3	38.7	73.5	130	122	0	34	32
2014	7	19	7	40	27	0.892	-0.079	4.695	0.01	0.007	0	41.7	37.8	74.8	130	121	0	33	33
2014	7	19	7	50	27	0.883	-0.066	4.695	0.013	0.01	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	19	8	0	27	0.866	-0.049	4.695	0.01	0.007	0	41.3	38.3	74.8	130	121	0	34	32
2014	7	19	8	10	27	0.856	-0.079	4.695	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	19	8	20	27	0.899	-0.039	4.695	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	19	8	30	27	0.873	-0.072	4.695	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	19	8	40	27	0.899	-0.085	4.695	0.01	0.007	0	41.7	38.7	74	131	122	0	34	32
2014	7	19	8	50	27	0.879	-0.079	4.695	0.01	0.007	0	41.7	38.3	73.1	131	122	0	34	33
2014	7	19	9	0	27	0.892	-0.112	4.695	0.01	0.007	0	40.9	37.8	74.8	129	121	0	34	33
2014	7	19	9	10	27	0.896	-0.102	4.695	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	19	9	20	27	0.883	-0.089	4.695	0.01	0.007	0	42.1	38.7	74.8	131	123	0	33	33
2014	7	19	9	30	27	0.886	-0.148	4.695	0.01	0.007	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	19	9	40	27	0.869	-0.131	4.695	0.01	0.007	0	40.9	37.4	74.8	129	120	0	34	33
2014	7	19	9	50	27	0.892	-0.151	4.692	0.01	0.007	0	40.9	37.4	75.3	129	120	0	34	33
2014	7	19	10	0	27	0.902	-0.092	4.695	0.01	0.007	0	41.3	37.8	75.7	130	121	0	34	33
2014	7	19	10	10	27	0.889	-0.154	4.692	0.01	0.007	0	40.4	37.8	74.8	129	121	0	35	33
2014	7	19	10	20	27	0.889	-0.144	4.692	0.01	0.007	0	41.3	38.3	74	129	121	0	33	32
2014	7	19	10	30	27	0.902	-0.157	4.692	0.01	0.007	0	40.9	38.3	75.3	129	121	0	34	32
2014	7	19	10	40	27	0.922	-0.128	4.692	0.01	0.007	0	41.3	37.4	74.8	129	120	0	33	33
2014	7	19	10	50	27	0.906	-0.138	4.692	0.01	0.007	0	40.9	37.8	75.7	129	120	0	34	32
2014	7	19	11	0	27	0.902	-0.108	4.692	0.01	0.007	0	41.3	37.4	72.2	129	121	0	33	34
2014	7	19	11	10	27	0.889	-0.148	4.692	0.01	0.007	0	40.9	38.3	75.3	129	121	0	34	32
2014	7	19	11	20	27	0.883	-0.177	4.692	0.01	0.007	0	40.9	37.4	75.7	129	120	0	34	33
2014	7	19	11	30	27	0.906	-0.154	4.692	0.01	0.007	0	40.9	37.8	64.9	128	120	0	33	32
2014	7	19	11	40	27	0.873	-0.144	4.692	0.01	0.007	0	40.9	38.3	64.9	129	121	0	34	32
2014	7	19	11	50	27	0.883	-0.177	4.692	0.01	0.007	0	40.4	37.8	59.3	128	120	0	34	32
2014	7	19	12	0	27	0.856	-0.21	4.692	0.01	0.007	0	40.4	37.4	58.9	128	120	0	34	33
2014	7	19	12	10	27	0.863	-0.154	4.692	0.01	0.007	0	40.9	37.4	63.2	129	120	0	34	33
2014	7	19	12	20	27	0.853	-0.141	4.692	0.01	0.007	0	40.4	37.4	57.6	128	120	0	34	33
2014	7	19	12	30	27	0.879	-0.157	4.688	0.01	0.007	0	41.3	37.8	62.4	129	121	0	33	33
2014	7	19	12	40	27	0.889	-0.131	4.692	0.01	0.007	0	41.3	38.3	68.8	130	122	0	34	33
2014	7	19	12	50	27	0.909	-0.102	4.692	0.01	0.007	0	41.3	38.3	59.3	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	13	0	27	0.85	-0.148	4.692	0.01	0.007	0	40.9	37.4	61.5	129	120	0	34	33
2014	7	19	13	10	27	0.896	-0.144	4.688	0.01	0.007	0	41.3	38.3	61.1	130	121	0	34	32
2014	7	19	13	20	27	0.883	-0.148	4.692	0.01	0.007	0	40.9	37.8	56.3	129	121	0	34	33
2014	7	19	13	30	27	0.873	-0.18	4.688	0.01	0.007	0	40.9	37.8	58	129	121	0	34	33
2014	7	19	13	40	27	0.889	-0.095	4.688	0.01	0.007	0	40.9	37.8	54.2	129	121	0	34	33
2014	7	19	13	50	27	0.896	-0.079	4.688	0.01	0.007	0	46.4	43.9	55.5	142	135	0	34	33
2014	7	19	14	0	27	0.883	-0.112	4.688	0.01	0.007	0	42.6	39.6	54.6	133	124	0	34	32
2014	7	19	14	10	27	0.892	-0.141	4.685	0.01	0.007	0	41.7	38.7	51.6	131	123	0	34	33
2014	7	19	14	20	27	0.915	-0.112	4.688	0.01	0.007	0	43.9	40.9	52.9	136	128	0	34	33
2014	7	19	14	30	27	0.892	-0.118	4.685	0.013	0.01	0	42.1	39.6	53.8	132	124	0	34	32
2014	7	19	14	40	27	0.896	-0.161	4.688	0.01	0.007	0	41.3	38.3	53.8	130	122	0	34	33
2014	7	19	14	50	27	0.915	-0.125	4.682	0.01	0.007	0	44.3	40	48.6	137	125	0	34	32
2014	7	19	15	0	27	0.873	-0.115	4.685	0.01	0.007	0	43	40.4	51.2	134	126	0	34	32
2014	7	19	15	10	27	0.869	-0.131	4.685	0.01	0.007	0	42.6	39.1	54.2	132	123	0	33	32
2014	7	19	15	20	27	0.879	-0.144	4.685	0.01	0.007	0	42.1	38.3	53.8	131	122	0	33	33
2014	7	19	15	30	27	0.883	-0.112	4.692	0.01	0.007	0	41.7	38.7	52.9	131	123	0	34	33
2014	7	19	15	40	27	0.827	-0.066	4.682	0.01	0.007	0	42.6	38.7	54.2	132	123	0	33	33
2014	7	19	15	50	27	0.866	-0.082	4.685	0.01	0.007	0	42.1	39.1	51.6	132	124	0	34	33
2014	7	19	16	0	27	0.886	-0.066	4.685	0.01	0.007	0	42.6	39.6	52.5	133	125	0	34	33
2014	7	19	16	10	27	0.86	-0.092	4.685	0.01	0.007	0	43	40	51.6	134	126	0	34	33
2014	7	19	16	20	27	0.869	-0.075	4.682	0.01	0.007	0	42.1	39.1	52.9	132	124	0	34	33
2014	7	19	16	30	27	0.866	-0.052	4.682	0.01	0.007	0	42.6	39.1	51.6	133	124	0	34	33
2014	7	19	16	40	27	0.866	-0.049	4.678	0.01	0.007	0	43	39.6	52.9	134	125	0	34	33
2014	7	19	16	50	27	0.866	-0.102	4.685	0.01	0.007	0	42.6	40	51.6	133	125	0	34	32
2014	7	19	17	0	27	0.883	-0.085	4.678	0.01	0.007	0	42.6	40	52	133	125	0	34	32
2014	7	19	17	10	27	0.853	-0.059	4.675	0.01	0.007	0	42.6	39.1	52.5	132	124	0	33	33
2014	7	19	17	20	27	0.863	-0.082	4.682	0.01	0.007	0	42.6	39.1	51.2	133	124	0	34	33
2014	7	19	17	30	27	0.869	-0.085	4.678	0.01	0.007	0	42.1	39.1	50.7	132	124	0	34	33
2014	7	19	17	40	27	0.863	-0.056	4.675	0.01	0.007	0	42.6	39.6	54.2	133	125	0	34	33
2014	7	19	17	50	27	0.892	-0.069	4.678	0.01	0.007	0	42.1	38.7	54.2	132	123	0	34	33
2014	7	19	18	0	27	0.873	-0.072	4.678	0.01	0.007	0	42.1	39.1	52	132	124	0	34	33
2014	7	19	18	10	27	0.846	-0.062	4.682	0.01	0.007	0	42.6	39.1	52	133	124	0	34	33
2014	7	19	18	20	27	0.85	-0.056	4.678	0.01	0.007	0	43	40	52.9	134	125	0	34	32
2014	7	19	18	30	27	0.85	-0.079	4.675	0.01	0.007	0	43	39.6	52.9	134	125	0	34	33
2014	7	19	18	40	27	0.846	-0.039	4.675	0.01	0.007	0	43.4	39.6	52.9	134	125	0	33	33
2014	7	19	18	50	27	0.83	-0.072	4.678	0.01	0.007	0	43	39.6	52.9	134	125	0	34	33
2014	7	19	19	0	27	0.873	-0.066	4.685	0.01	0.007	0	42.1	39.1	52	133	124	0	35	33
2014	7	19	19	10	27	0.85	-0.082	4.678	0.013	0.01	0	42.6	39.6	51.2	133	125	0	34	33
2014	7	19	19	20	27	0.879	-0.112	4.678	0.01	0.007	0	42.1	39.6	53.3	133	125	0	35	33
2014	7	19	19	30	27	0.889	-0.023	4.672	0.01	0.007	0	42.6	39.6	54.6	134	125	0	35	33
2014	7	19	19	40	27	0.869	-0.069	4.678	0.01	0.007	0	42.6	39.6	53.3	133	124	0	34	32
2014	7	19	19	50	27	0.886	-0.118	4.682	0.01	0.007	0	42.6	38.7	55.5	132	123	0	33	33
2014	7	19	20	0	27	0.873	-0.089	4.678	0.01	0.007	0	43	40.4	53.3	134	126	0	34	32
2014	7	19	20	10	27	0.866	-0.092	4.682	0.01	0.007	0	43	39.6	53.8	134	125	0	34	33
2014	7	19	20	20	27	0.869	-0.098	4.678	0.01	0.007	0	42.6	40	53.8	133	125	0	34	32
2014	7	19	20	30	27	0.86	-0.052	4.682	0.01	0.007	0	43.9	40	52.5	135	126	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	20	40	27	0.866	-0.085	4.678	0.01	0.007	0	43	39.6	52.9	134	125	0	34	33
2014	7	19	20	50	27	0.883	-0.112	4.678	0.01	0.007	0	42.6	39.6	55	133	125	0	34	33
2014	7	19	21	0	27	0.883	-0.079	4.682	0.01	0.007	0	43	39.6	55.9	134	125	0	34	33
2014	7	19	21	10	27	0.883	-0.092	4.682	0.01	0.007	0	42.6	39.1	61.1	133	124	0	34	33
2014	7	19	21	20	27	0.899	-0.069	4.682	0.01	0.007	0	43.9	41.3	64.9	136	128	0	34	32
2014	7	19	21	30	27	0.896	-0.095	4.682	0.01	0.007	0	42.6	39.1	66.7	133	124	0	34	33
2014	7	19	21	40	27	0.879	-0.072	4.682	0.01	0.007	0	43	39.6	63.2	134	125	0	34	33
2014	7	19	21	50	27	0.883	-0.108	4.682	0.01	0.007	0	42.6	39.1	53.8	133	124	0	34	33
2014	7	19	22	0	27	0.866	-0.102	4.678	0.013	0.01	0	41.7	38.3	55	131	122	0	34	33
2014	7	19	22	10	27	0.902	-0.095	4.682	0.01	0.007	0	42.1	38.7	56.3	132	123	0	34	33
2014	7	19	22	20	27	0.886	-0.069	4.682	0.01	0.007	0	42.1	39.1	71.4	132	124	0	34	33
2014	7	19	22	30	27	0.876	-0.082	4.685	0.01	0.007	0	42.1	38.7	70.1	132	123	0	34	33
2014	7	19	22	40	27	0.899	-0.098	4.685	0.01	0.007	0	42.1	39.1	74	133	124	0	35	33
2014	7	19	22	50	27	0.906	-0.079	4.685	0.01	0.007	0	43	39.6	72.2	134	125	0	34	33
2014	7	19	23	0	27	0.869	-0.085	4.685	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	19	23	10	27	0.896	-0.082	4.685	0.013	0.01	0	42.1	39.1	73.5	132	123	0	34	32
2014	7	19	23	20	27	0.883	-0.102	4.685	0.013	0.01	0	41.7	38.3	60.6	131	122	0	34	33
2014	7	19	23	30	27	0.879	-0.095	4.685	0.01	0.007	0	41.3	37.8	62.8	130	121	0	34	33
2014	7	19	23	40	27	0.883	-0.098	4.685	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	19	23	50	27	0.886	-0.085	4.685	0.01	0.007	0	40.9	38.3	74.4	130	122	0	35	33
2014	7	20	0	0	27	0.889	-0.072	4.685	0.013	0.01	0	41.3	38.7	74.8	131	123	0	35	33
2014	7	20	0	10	27	0.886	-0.075	4.685	0.01	0.007	0	42.6	39.1	74.4	133	124	0	34	33
2014	7	20	0	20	27	0.869	-0.066	4.685	0.01	0.007	0	43	39.6	74.4	134	125	0	34	33
2014	7	20	0	30	27	0.902	-0.082	4.685	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	20	0	40	27	0.866	-0.069	4.688	0.01	0.007	0	43	40	74	134	125	0	34	32
2014	7	20	0	50	27	0.866	-0.043	4.688	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	20	1	0	27	0.879	-0.056	4.688	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	20	1	10	27	0.892	-0.092	4.685	0.013	0.01	0	43	39.6	74.8	133	125	0	33	33
2014	7	20	1	20	27	0.863	-0.079	4.688	0.01	0.007	0	42.1	39.1	75.3	132	123	0	34	32
2014	7	20	1	30	27	0.886	-0.036	4.688	0.01	0.007	0	42.1	39.6	75.7	132	124	0	34	32
2014	7	20	1	40	27	0.873	-0.066	4.688	0.01	0.007	0	42.1	39.1	75.3	132	124	0	34	33
2014	7	20	1	50	27	0.869	-0.066	4.688	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	20	2	0	27	0.876	-0.085	4.688	0.013	0.01	0	42.1	39.1	74.8	132	124	0	34	33
2014	7	20	2	10	27	0.886	-0.066	4.688	0.01	0.007	0	43	39.6	75.7	134	125	0	34	33
2014	7	20	2	20	27	0.879	-0.075	4.688	0.01	0.007	0	43	39.6	70.1	134	125	0	34	33
2014	7	20	2	30	27	0.879	-0.056	4.688	0.01	0.007	0	43	39.6	75.7	134	125	0	34	33
2014	7	20	2	40	27	0.863	-0.082	4.688	0.01	0.007	0	43	40	76.1	134	125	0	34	32
2014	7	20	2	50	27	0.866	-0.079	4.688	0.013	0.01	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	20	3	0	27	0.892	-0.052	4.688	0.013	0.01	0	43.4	40	74.8	135	125	0	34	32
2014	7	20	3	10	27	0.86	-0.066	4.688	0.01	0.007	0	43.4	40.4	75.7	135	126	0	34	32
2014	7	20	3	20	27	0.873	-0.079	4.688	0.01	0.007	0	44.3	40.9	75.7	137	128	0	34	33
2014	7	20	3	30	27	0.899	-0.066	4.688	0.01	0.007	0	43	40.4	75.3	134	126	0	34	32
2014	7	20	3	40	27	0.879	-0.075	4.688	0.01	0.007	0	43	39.1	74.4	134	125	0	34	34
2014	7	20	3	50	27	0.902	-0.049	4.688	0.01	0.007	0	42.6	39.6	74.8	133	125	0	34	33
2014	7	20	4	0	27	0.925	-0.043	4.688	0.01	0.007	0	43	38.7	75.3	133	124	0	33	34
2014	7	20	4	10	27	0.873	-0.066	4.688	0.01	0.007	0	43.4	40.9	74.8	135	127	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	4	20	27	0.899	-0.066	4.688	0.01	0.007	0	43.4	40	75.3	135	126	0	34	33
2014	7	20	4	30	27	0.866	-0.049	4.688	0.01	0.007	0	44.3	40.9	74.4	137	128	0	34	33
2014	7	20	4	40	27	0.899	-0.046	4.688	0.01	0.007	0	45.2	41.3	67.1	138	129	0	33	33
2014	7	20	4	50	27	0.886	-0.098	4.688	0.013	0.01	0	45.2	41.7	71.8	139	130	0	34	33
2014	7	20	5	0	27	0.896	-0.085	4.688	0.01	0.007	0	43.9	40	75.3	135	126	0	33	33
2014	7	20	5	10	27	0.86	-0.075	4.688	0.01	0.007	0	44.3	40.4	74.8	136	127	0	33	33
2014	7	20	5	20	27	0.86	-0.069	4.688	0.013	0.01	0	43.9	40.4	74.8	136	127	0	34	33
2014	7	20	5	30	27	0.906	-0.033	4.688	0.016	0.013	0	43	40	68.4	134	126	0	34	33
2014	7	20	5	40	27	0.873	-0.082	4.688	0.01	0.007	0	43	39.1	74.4	134	125	0	34	34
2014	7	20	5	50	27	0.902	-0.079	4.688	0.013	0.01	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	20	6	0	27	0.879	-0.079	4.692	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	20	6	10	27	0.892	-0.075	4.692	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	20	6	20	27	0.883	-0.095	4.692	0.01	0.007	0	42.6	39.1	55.9	133	124	0	34	33
2014	7	20	6	30	27	0.902	-0.066	4.692	0.01	0.007	0	44.3	41.3	72.7	137	128	0	34	32
2014	7	20	6	40	27	0.869	-0.066	4.692	0.01	0.007	0	43.9	40.9	73.1	137	128	0	35	33
2014	7	20	6	50	27	0.889	-0.089	4.692	0.01	0.007	0	43.4	40	72.7	135	126	0	34	33
2014	7	20	7	0	27	0.892	-0.069	4.692	0.01	0.007	0	43	40	59.3	134	126	0	34	33
2014	7	20	7	10	27	0.846	-0.052	4.695	0.01	0.007	0	43.9	40.9	48.6	136	128	0	34	33
2014	7	20	7	20	27	0.889	-0.082	4.692	0.01	0.007	0	50.7	47.3	49.9	152	143	0	34	33
2014	7	20	7	30	27	0.876	-0.039	4.692	0.01	0.007	0	50.3	46.9	60.6	151	142	0	34	33
2014	7	20	7	40	27	0.883	-0.033	4.692	0.01	0.007	0	48.6	45.6	61.5	147	139	0	34	33
2014	7	20	7	50	27	0.866	-0.007	4.692	0.013	0.01	0	47.7	43.9	64.9	144	135	0	33	33
2014	7	20	8	0	27	0.889	-0.03	4.692	0.01	0.007	0	46	43	66.7	142	133	0	35	33
2014	7	20	8	10	27	0.912	-0.069	4.692	0.013	0.01	0	45.2	42.1	69.2	139	131	0	34	33
2014	7	20	8	20	27	0.873	-0.066	4.695	0.013	0.01	0	44.3	41.3	64.9	137	129	0	34	33
2014	7	20	8	30	27	0.883	-0.046	4.692	0.01	0.007	0	44.3	40.9	66.2	137	128	0	34	33
2014	7	20	8	40	27	0.876	-0.062	4.692	0.01	0.007	0	44.3	41.3	70.5	137	129	0	34	33
2014	7	20	8	50	27	0.873	-0.066	4.692	0.01	0.007	0	43.9	40.9	67.1	136	128	0	34	33
2014	7	20	9	0	27	0.883	-0.062	4.692	0.01	0.007	0	43.4	40.4	67.9	135	127	0	34	33
2014	7	20	9	10	27	0.866	-0.039	4.692	0.01	0.007	0	43	39.1	65.4	134	125	0	34	34
2014	7	20	9	20	27	0.876	-0.066	4.692	0.01	0.007	0	42.6	39.6	72.7	133	125	0	34	33
2014	7	20	9	30	27	0.902	-0.069	4.692	0.01	0.007	0	42.6	39.1	72.7	133	124	0	34	33
2014	7	20	9	40	27	0.886	-0.092	4.692	0.013	0.01	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	20	9	50	27	0.863	-0.085	4.692	0.013	0.01	0	42.6	39.6	72.2	133	124	0	34	32
2014	7	20	10	0	27	0.892	-0.052	4.692	0.01	0.007	0	42.1	38.7	72.7	132	123	0	34	33
2014	7	20	10	10	27	0.886	-0.059	4.692	0.01	0.007	0	42.6	39.6	72.2	133	125	0	34	33
2014	7	20	10	20	27	0.892	-0.069	4.692	0.013	0.01	0	42.1	39.6	72.2	132	124	0	34	32
2014	7	20	10	30	27	0.896	-0.075	4.692	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	20	10	40	27	0.876	-0.072	4.692	0.01	0.007	0	42.6	39.1	72.7	132	124	0	33	33
2014	7	20	10	50	27	0.906	-0.095	4.692	0.01	0.007	0	41.7	38.7	74	131	122	0	34	32
2014	7	20	11	0	27	0.866	-0.082	4.692	0.013	0.01	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	20	11	10	27	0.879	-0.075	4.692	0.01	0.007	0	41.3	38.3	70.1	131	122	0	35	33
2014	7	20	11	20	27	0.896	-0.095	4.692	0.01	0.007	0	41.7	38.3	73.5	131	123	0	34	34
2014	7	20	11	30	27	0.922	-0.066	4.692	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	20	11	40	27	0.915	-0.115	4.688	0.01	0.007	0	41.7	39.1	73.1	131	123	0	34	32
2014	7	20	11	50	27	0.886	-0.125	4.688	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	12	0	27	0.876	-0.108	4.688	0.01	0.007	0	43.4	40.4	51.2	136	127	0	35	33
2014	7	20	12	10	27	0.892	-0.092	4.685	0.013	0.01	0	44.3	40.9	49	137	128	0	34	33
2014	7	20	12	20	27	0.906	-0.154	4.688	0.01	0.007	0	40.9	37.8	58.9	129	121	0	34	33
2014	7	20	12	30	27	0.879	-0.177	4.688	0.01	0.007	0	40.9	37.4	73.1	129	121	0	34	34
2014	7	20	12	40	27	0.906	-0.164	4.688	0.01	0.007	0	40.9	37.4	70.1	129	120	0	34	33
2014	7	20	12	50	27	0.889	-0.131	4.688	0.013	0.01	0	40.9	37	67.5	129	120	0	34	34
2014	7	20	13	0	27	0.909	-0.141	4.688	0.01	0.007	0	40.9	37.8	63.2	129	121	0	34	33
2014	7	20	13	10	27	0.876	-0.072	4.688	0.01	0.007	0	41.3	38.3	64.1	130	122	0	34	33
2014	7	20	13	20	27	0.853	-0.085	4.688	0.01	0.007	0	41.3	38.3	65.8	130	122	0	34	33
2014	7	20	13	30	27	0.896	-0.079	4.688	0.01	0.007	0	41.3	38.3	64.1	130	122	0	34	33
2014	7	20	13	40	27	0.889	-0.089	4.688	0.01	0.007	0	41.3	37.4	69.2	130	121	0	34	34
2014	7	20	13	50	27	0.906	-0.066	4.688	0.01	0.007	0	47.3	43.9	49.5	144	135	0	34	33
2014	7	20	14	0	27	0.896	-0.079	4.688	0.016	0.013	0	42.1	38.3	49	132	122	0	34	33
2014	7	20	14	10	27	0.873	-0.095	4.688	0.01	0.007	0	42.1	39.6	73.5	132	124	0	34	32
2014	7	20	14	20	27	0.902	-0.066	4.685	0.01	0.007	0	41.7	38.7	53.8	131	123	0	34	33
2014	7	20	14	30	27	0.896	-0.079	4.685	0.016	0.013	0	42.1	39.1	53.3	132	124	0	34	33
2014	7	20	14	40	27	0.902	-0.108	4.685	0.013	0.01	0	41.7	38.7	61.5	131	123	0	34	33
2014	7	20	14	50	27	0.863	-0.085	4.685	0.01	0.007	0	41.7	37.8	61.5	131	122	0	34	34
2014	7	20	15	0	27	0.873	-0.187	4.685	0.01	0.007	0	40.4	37.4	71.8	128	120	0	34	33
2014	7	20	15	10	27	0.912	-0.157	4.685	0.01	0.007	0	40.9	37.8	69.7	129	121	0	34	33
2014	7	20	15	20	27	0.886	-0.131	4.685	0.01	0.007	0	41.7	38.3	52.5	131	122	0	34	33
2014	7	20	15	30	27	0.846	-0.115	4.682	0.01	0.007	0	47.7	43.9	38.7	145	135	0	34	33
2014	7	20	15	40	27	0.86	-0.164	4.682	0.01	0.007	0	42.6	38.7	50.3	133	123	0	34	33
2014	7	20	15	50	27	0.886	-0.157	4.685	0.01	0.007	0	41.3	38.3	54.2	130	121	0	34	32
2014	7	20	16	0	27	0.899	-0.128	4.682	0.01	0.007	0	43.4	38.3	51.2	135	122	0	34	33
2014	7	20	16	10	27	0.892	-0.128	4.685	0.01	0.007	0	41.7	37.8	59.3	131	121	0	34	33
2014	7	20	16	20	27	0.896	-0.082	4.682	0.013	0.01	0	42.6	38.7	54.2	132	123	0	33	33
2014	7	20	16	30	27	0.896	-0.112	4.682	0.013	0.01	0	45.6	42.6	52	140	131	0	34	32
2014	7	20	16	40	27	0.886	-0.108	4.685	0.01	0.007	0	41.7	38.3	62.4	131	122	0	34	33
2014	7	20	16	50	27	0.896	-0.082	4.685	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	20	17	0	27	0.919	-0.118	4.685	0.01	0.007	0	41.3	37.4	72.7	130	120	0	34	33
2014	7	20	17	10	27	0.876	-0.125	4.685	0.01	0.007	0	40.4	37.4	71.8	129	120	0	35	33
2014	7	20	17	20	27	0.863	-0.079	4.685	0.013	0.01	0	41.3	37.4	68.4	130	120	0	34	33
2014	7	20	17	30	27	0.892	-0.144	4.685	0.01	0.007	0	40.9	37	65.8	129	120	0	34	34
2014	7	20	17	40	27	0.879	-0.131	4.685	0.01	0.007	0	40.9	37.4	73.5	129	120	0	34	33
2014	7	20	17	50	27	0.906	-0.115	4.685	0.013	0.01	0	40.9	37.4	73.5	129	120	0	34	33
2014	7	20	18	0	27	0.902	-0.135	4.685	0.013	0.01	0	40.9	37.8	68.8	129	120	0	34	32
2014	7	20	18	10	27	0.892	-0.092	4.685	0.01	0.007	0	40.9	37.4	75.3	129	120	0	34	33
2014	7	20	18	20	27	0.906	-0.056	4.685	0.01	0.007	0	41.7	37.8	65.8	131	121	0	34	33
2014	7	20	18	30	27	0.876	-0.069	4.685	0.01	0.007	0	41.7	37.8	73.5	131	121	0	34	33
2014	7	20	18	40	27	0.892	-0.069	4.685	0.01	0.007	0	41.7	38.3	72.2	131	122	0	34	33
2014	7	20	18	50	27	0.892	-0.066	4.685	0.01	0.007	0	41.3	38.3	72.2	131	122	0	35	33
2014	7	20	19	0	27	0.863	-0.056	4.685	0.013	0.01	0	41.3	37.8	68.8	130	121	0	34	33
2014	7	20	19	10	27	0.886	-0.036	4.685	0.01	0.007	0	42.1	38.7	56.8	131	122	0	33	32
2014	7	20	19	20	27	0.892	-0.085	4.685	0.01	0.007	0	41.7	38.3	67.1	131	122	0	34	33
2014	7	20	19	30	27	0.896	-0.062	4.685	0.01	0.007	0	41.7	38.3	58.5	131	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	19	40	27	0.866	-0.089	4.685	0.013	0.01	0	41.7	37.8	71.8	131	121	0	34	33
2014	7	20	19	50	27	0.869	-0.066	4.685	0.01	0.007	0	43	38.7	71	133	123	0	33	33
2014	7	20	20	0	27	0.866	-0.066	4.685	0.01	0.007	0	42.1	38.3	71	132	122	0	34	33
2014	7	20	20	10	27	0.856	-0.046	4.685	0.01	0.007	0	42.6	39.6	73.1	133	124	0	34	32
2014	7	20	20	20	27	0.912	-0.072	4.685	0.01	0.007	0	43	39.1	72.2	134	124	0	34	33
2014	7	20	20	30	27	0.883	-0.072	4.685	0.01	0.007	0	43.4	39.6	74	134	125	0	33	33
2014	7	20	20	40	27	0.909	-0.052	4.685	0.01	0.007	0	43	39.6	71.8	134	125	0	34	33
2014	7	20	20	50	27	0.883	-0.052	4.685	0.01	0.007	0	43	39.6	72.7	134	125	0	34	33
2014	7	20	21	0	27	0.896	-0.066	4.685	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	20	21	10	27	0.879	-0.056	4.685	0.01	0.007	0	42.6	39.6	72.7	133	124	0	34	32
2014	7	20	21	20	27	0.879	-0.079	4.685	0.01	0.007	0	43	39.1	73.1	134	124	0	34	33
2014	7	20	21	30	27	0.886	-0.079	4.685	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	20	21	40	27	0.879	-0.062	4.685	0.01	0.007	0	42.6	38.7	65.8	133	123	0	34	33
2014	7	20	21	50	27	0.899	-0.066	4.685	0.01	0.007	0	42.6	39.1	72.2	133	124	0	34	33
2014	7	20	22	0	27	0.889	-0.089	4.685	0.01	0.007	0	43	39.6	73.5	134	124	0	34	32
2014	7	20	22	10	27	0.866	-0.049	4.685	0.01	0.007	0	42.1	39.6	72.7	132	124	0	34	32
2014	7	20	22	20	27	0.879	-0.079	4.685	0.013	0.01	0	43	39.1	73.1	134	124	0	34	33
2014	7	20	22	30	27	0.896	-0.056	4.685	0.01	0.007	0	42.6	38.7	74	133	124	0	34	34
2014	7	20	22	40	27	0.879	-0.072	4.685	0.01	0.007	0	42.1	38.3	74	132	122	0	34	33
2014	7	20	22	50	27	0.873	-0.066	4.685	0.01	0.007	0	41.7	38.3	75.3	132	122	0	35	33
2014	7	20	23	0	27	0.873	-0.098	4.685	0.01	0.007	0	42.6	38.7	68.8	132	123	0	33	33
2014	7	20	23	10	27	0.869	-0.079	4.685	0.01	0.007	0	42.1	38.3	73.1	131	122	0	33	33
2014	7	20	23	20	27	0.863	-0.056	4.685	0.013	0.01	0	42.1	38.3	69.7	132	122	0	34	33
2014	7	20	23	30	27	0.889	-0.082	4.685	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	20	23	40	27	0.889	-0.082	4.688	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	20	23	50	27	0.876	-0.079	4.688	0.013	0.01	0	42.1	38.3	74.4	132	122	0	34	33
2014	7	21	0	0	27	0.889	-0.062	4.688	0.013	0.01	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	21	0	10	27	0.896	-0.072	4.685	0.01	0.007	0	42.1	38.3	74.8	132	122	0	34	33
2014	7	21	0	20	27	0.889	-0.082	4.688	0.01	0.007	0	42.1	38.3	74.8	131	122	0	33	33
2014	7	21	0	30	27	0.879	-0.079	4.688	0.01	0.007	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	21	0	40	27	0.873	-0.079	4.685	0.01	0.007	0	42.6	39.6	75.7	133	124	0	34	32
2014	7	21	0	50	27	0.883	-0.082	4.688	0.01	0.007	0	42.1	39.1	75.7	132	124	0	34	33
2014	7	21	1	0	27	0.883	-0.062	4.688	0.01	0.007	0	42.6	38.7	75.7	133	123	0	34	33
2014	7	21	1	10	27	0.912	-0.098	4.685	0.01	0.007	0	41.7	38.7	75.7	132	122	0	35	32
2014	7	21	1	20	27	0.892	-0.066	4.685	0.01	0.007	0	42.1	38.3	76.1	132	122	0	34	33
2014	7	21	1	30	27	0.896	-0.089	4.688	0.01	0.007	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	21	1	40	27	0.863	-0.066	4.688	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	21	1	50	27	0.876	-0.072	4.688	0.01	0.007	0	43.4	40	75.7	134	125	0	33	32
2014	7	21	2	0	27	0.902	-0.066	4.688	0.01	0.007	0	42.6	39.1	75.7	133	124	0	34	33
2014	7	21	2	10	27	0.883	-0.072	4.688	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	21	2	20	27	0.873	-0.082	4.685	0.01	0.007	0	42.6	39.1	75.7	133	124	0	34	33
2014	7	21	2	30	27	0.869	-0.085	4.685	0.01	0.007	0	42.6	39.6	74.8	133	124	0	34	32
2014	7	21	2	40	27	0.883	-0.079	4.688	0.01	0.007	0	42.1	39.1	75.7	132	123	0	34	32
2014	7	21	2	50	27	0.892	-0.085	4.685	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	21	3	0	27	0.869	-0.075	4.688	0.01	0.007	0	41.7	37.8	74.8	131	122	0	34	34
2014	7	21	3	10	27	0.892	-0.108	4.685	0.01	0.007	0	42.1	38.7	74.4	132	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	3	20	27	0.892	-0.075	4.685	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	21	3	30	27	0.896	-0.085	4.685	0.01	0.007	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	21	3	40	27	0.879	-0.075	4.685	0.01	0.007	0	43.4	39.6	75.7	135	125	0	34	33
2014	7	21	3	50	27	0.889	-0.079	4.685	0.01	0.007	0	42.6	39.6	75.3	133	124	0	34	32
2014	7	21	4	0	27	0.873	-0.062	4.685	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	21	4	10	27	0.892	-0.095	4.685	0.01	0.007	0	43	39.6	75.3	134	125	0	34	33
2014	7	21	4	20	27	0.889	-0.089	4.685	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33
2014	7	21	4	30	27	0.896	-0.046	4.685	0.01	0.007	0	42.6	39.1	74.4	134	124	0	35	33
2014	7	21	4	40	27	0.889	-0.095	4.685	0.01	0.007	0	42.1	38.3	74.8	132	123	0	34	34
2014	7	21	4	50	27	0.873	-0.072	4.685	0.01	0.007	0	42.1	39.1	74.8	133	124	0	35	33
2014	7	21	5	0	27	0.873	-0.072	4.685	0.01	0.007	0	42.6	38.7	75.3	134	124	0	35	34
2014	7	21	5	10	27	0.866	-0.039	4.685	0.01	0.007	0	42.6	39.1	74.4	133	124	0	34	33
2014	7	21	5	20	27	0.906	-0.069	4.685	0.01	0.007	0	42.6	39.1	74	133	124	0	34	33
2014	7	21	5	30	27	0.869	-0.049	4.685	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	21	5	40	27	0.909	-0.079	4.688	0.01	0.007	0	43	39.1	74	134	124	0	34	33
2014	7	21	5	50	27	0.876	-0.095	4.688	0.01	0.007	0	42.1	39.1	74	133	124	0	35	33
2014	7	21	6	0	27	0.889	-0.089	4.688	0.01	0.007	0	43.4	39.6	74	135	125	0	34	33
2014	7	21	6	10	27	0.909	-0.062	4.688	0.01	0.007	0	42.6	38.7	74.4	133	123	0	34	33
2014	7	21	6	20	27	0.873	-0.079	4.688	0.01	0.007	0	42.1	38.3	74	132	123	0	34	34
2014	7	21	6	30	27	0.889	-0.085	4.688	0.01	0.007	0	41.7	39.1	74.4	132	123	0	35	32
2014	7	21	6	40	27	0.866	-0.066	4.688	0.013	0.01	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	21	6	50	27	0.886	-0.085	4.688	0.01	0.007	0	42.6	38.7	73.5	133	124	0	34	34
2014	7	21	7	0	27	0.909	-0.056	4.688	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	21	7	10	27	0.866	-0.062	4.688	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	21	7	20	27	0.892	-0.082	4.688	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	21	7	30	27	0.889	-0.049	4.688	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	21	7	40	27	0.876	-0.033	4.688	0.01	0.007	0	42.1	39.1	73.5	132	123	0	34	32
2014	7	21	7	50	27	0.889	-0.082	4.688	0.01	0.007	0	41.7	38.3	73.1	131	122	0	34	33
2014	7	21	8	0	27	0.889	-0.066	4.688	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	21	8	10	27	0.899	-0.089	4.688	0.01	0.007	0	41.7	38.7	72.7	131	122	0	34	32
2014	7	21	8	20	27	0.909	-0.138	4.688	0.01	0.007	0	41.7	38.7	73.5	131	122	0	34	32
2014	7	21	8	30	27	0.912	-0.108	4.688	0.01	0.007	0	41.3	38.7	72.2	131	123	0	35	33
2014	7	21	8	40	27	0.86	-0.062	4.688	0.01	0.007	0	41.7	38.7	72.7	131	123	0	34	33
2014	7	21	8	50	27	0.909	-0.112	4.688	0.01	0.007	0	40.9	37.8	74.8	130	122	0	35	34
2014	7	21	9	0	27	0.909	-0.131	4.688	0.01	0.007	0	40.9	37.8	74	129	121	0	34	33
2014	7	21	9	10	27	0.909	-0.105	4.685	0.01	0.007	0	40.4	37.8	73.1	129	121	0	35	33
2014	7	21	9	20	27	0.892	-0.105	4.688	0.013	0.01	0	41.3	37.8	73.1	130	121	0	34	33
2014	7	21	9	30	27	0.919	-0.095	4.688	0.01	0.007	0	41.3	37.8	72.2	130	121	0	34	33
2014	7	21	9	40	27	0.899	-0.089	4.685	0.01	0.007	0	41.7	38.7	71.4	131	123	0	34	33
2014	7	21	9	50	27	0.886	-0.135	4.685	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	21	10	0	27	0.876	-0.112	4.685	0.01	0.007	0	41.3	37.8	71.4	130	121	0	34	33
2014	7	21	10	10	27	0.869	-0.164	4.685	0.01	0.007	0	40.9	37.4	72.2	129	120	0	34	33
2014	7	21	10	20	27	0.902	-0.144	4.685	0.01	0.007	0	40.4	37.4	64.1	129	120	0	35	33
2014	7	21	10	30	27	0.899	-0.148	4.685	0.01	0.007	0	40.9	37.4	65.8	129	120	0	34	33
2014	7	21	10	40	27	0.873	-0.161	4.685	0.01	0.007	0	40.4	36.5	63.2	128	119	0	34	34
2014	7	21	10	50	27	0.902	-0.135	4.685	0.013	0.01	0	40.9	37.4	63.2	129	120	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	11	0	27	0.873	-0.174	4.685	0.01	0.007	0	40.9	37.8	61.1	129	120	0	34	32
2014	7	21	11	10	27	0.886	-0.151	4.685	0.01	0.007	0	40.9	37.4	68.8	129	120	0	34	33
2014	7	21	11	20	27	0.906	-0.095	4.685	0.013	0.01	0	41.3	38.7	58.9	130	122	0	34	32
2014	7	21	11	30	27	0.902	-0.118	4.685	0.01	0.007	0	40.9	37.4	56.8	129	120	0	34	33
2014	7	21	11	40	27	0.889	-0.118	4.685	0.01	0.007	0	40.9	37.8	56.8	129	121	0	34	33
2014	7	21	11	50	27	0.899	-0.095	4.685	0.01	0.007	0	41.3	38.3	60.2	130	122	0	34	33
2014	7	21	12	0	27	0.883	-0.154	4.685	0.01	0.007	0	40.9	37.8	57.2	129	121	0	34	33
2014	7	21	12	10	27	0.879	-0.135	4.685	0.01	0.007	0	40.9	37.4	68.4	129	120	0	34	33
2014	7	21	12	20	27	0.863	-0.174	4.685	0.01	0.007	0	40.9	37.4	63.6	129	120	0	34	33
2014	7	21	12	30	27	0.86	-0.144	4.685	0.01	0.007	0	40.9	37.8	55	129	121	0	34	33
2014	7	21	12	40	27	0.876	-0.18	4.685	0.013	0.01	0	40.9	37.4	57.6	129	120	0	34	33
2014	7	21	12	50	27	0.899	-0.138	4.685	0.01	0.007	0	40.4	37.4	62.8	129	120	0	35	33
2014	7	21	13	0	27	0.902	-0.207	4.682	0.01	0.007	0	40.4	37.8	64.9	128	120	0	34	32
2014	7	21	13	10	27	0.853	-0.19	4.682	0.01	0.007	0	40.9	37.4	61.1	129	120	0	34	33
2014	7	21	13	20	27	0.863	-0.118	4.682	0.013	0.01	0	40.9	37.8	54.2	129	121	0	34	33
2014	7	21	13	30	27	0.86	-0.164	4.682	0.01	0.007	0	40.9	37.8	55.5	129	121	0	34	33
2014	7	21	13	40	27	0.889	-0.167	4.678	0.01	0.007	0	40.9	37.8	53.8	129	121	0	34	33
2014	7	21	13	50	27	0.883	-0.187	4.682	0.01	0.007	0	40.9	37.8	54.6	129	121	0	34	33
2014	7	21	14	0	27	0.886	-0.161	4.682	0.01	0.007	0	40.4	37.8	53.3	129	121	0	35	33
2014	7	21	14	10	27	0.86	-0.164	4.678	0.01	0.007	0	41.3	37.8	52.9	130	121	0	34	33
2014	7	21	14	20	27	0.892	-0.187	4.678	0.01	0.007	0	41.3	38.3	54.6	130	122	0	34	33
2014	7	21	14	30	27	0.866	-0.131	4.675	0.013	0.01	0	41.3	37.4	54.2	130	120	0	34	33
2014	7	21	14	40	27	0.889	-0.131	4.678	0.01	0.007	0	41.3	37.8	55.5	130	122	0	34	34
2014	7	21	14	50	27	0.869	-0.174	4.678	0.01	0.007	0	40.9	37.8	52.9	129	121	0	34	33
2014	7	21	15	0	27	0.886	-0.19	4.678	0.01	0.007	0	40.9	37.8	54.6	129	121	0	34	33
2014	7	21	15	10	27	0.883	-0.112	4.675	0.01	0.007	0	41.3	37.8	53.3	130	121	0	34	33
2014	7	21	15	20	27	0.86	-0.121	4.675	0.01	0.007	0	40.9	38.3	52.5	130	122	0	35	33
2014	7	21	15	30	27	0.915	-0.105	4.678	0.01	0.007	0	41.7	38.3	54.2	131	122	0	34	33
2014	7	21	15	40	27	0.899	-0.128	4.675	0.01	0.007	0	41.3	38.3	53.3	130	122	0	34	33
2014	7	21	15	50	27	0.84	-0.095	4.678	0.01	0.007	0	41.3	38.3	55	130	122	0	34	33
2014	7	21	16	0	27	0.876	-0.118	4.675	0.01	0.007	0	41.7	38.7	54.2	131	123	0	34	33
2014	7	21	16	10	27	0.876	-0.154	4.675	0.01	0.007	0	45.6	43	49	141	133	0	35	33
2014	7	21	16	20	27	0.899	-0.148	4.675	0.01	0.007	0	43.9	41.3	51.2	136	128	0	34	32
2014	7	21	16	30	27	0.853	-0.108	4.672	0.01	0.007	0	47.3	43.4	46.9	144	134	0	34	33
2014	7	21	16	40	27	0.892	-0.121	4.675	0.01	0.007	0	49.5	46.9	43	150	141	0	35	32
2014	7	21	16	50	27	0.876	-0.105	4.672	0.01	0.007	0	44.7	41.3	48.6	138	129	0	34	33
2014	7	21	17	0	27	0.863	-0.131	4.672	0.013	0.01	0	46.9	43	49	143	133	0	34	33
2014	7	21	17	10	27	0.883	-0.128	4.675	0.01	0.007	0	41.3	38.3	51.2	130	121	0	34	32
2014	7	21	17	20	27	0.886	-0.131	4.675	0.01	0.007	0	41.3	37.8	53.3	130	122	0	34	34
2014	7	21	17	30	27	0.876	-0.115	4.675	0.013	0.01	0	41.3	37.8	53.3	130	121	0	34	33
2014	7	21	17	40	27	0.889	-0.105	4.675	0.01	0.007	0	41.3	38.3	50.7	130	122	0	34	33
2014	7	21	17	50	27	0.869	-0.115	4.675	0.01	0.007	0	41.3	38.7	52.9	130	122	0	34	32
2014	7	21	18	0	27	0.906	-0.095	4.672	0.01	0.007	0	41.3	38.3	53.3	130	121	0	34	32
2014	7	21	18	10	27	0.883	-0.131	4.675	0.01	0.007	0	41.3	38.3	53.8	130	122	0	34	33
2014	7	21	18	20	27	0.892	-0.125	4.675	0.01	0.007	0	41.3	37.4	51.6	130	120	0	34	33
2014	7	21	18	30	27	0.886	-0.125	4.672	0.01	0.007	0	40.9	37.4	52.9	129	120	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	18	40	27	0.86	-0.121	4.675	0.01	0.007	0	41.3	37.8	52.5	130	121	0	34	33
2014	7	21	18	50	27	0.912	-0.098	4.672	0.013	0.01	0	41.7	38.7	54.6	131	122	0	34	32
2014	7	21	19	0	27	0.909	-0.128	4.675	0.01	0.007	0	40.9	38.3	51.6	130	122	0	35	33
2014	7	21	19	10	27	0.902	-0.131	4.672	0.013	0.01	0	41.7	38.3	52	130	122	0	33	33
2014	7	21	19	20	27	0.886	-0.125	4.675	0.013	0.01	0	41.3	38.3	53.3	130	121	0	34	32
2014	7	21	19	30	27	0.876	-0.082	4.675	0.01	0.007	0	41.7	38.3	53.8	131	122	0	34	33
2014	7	21	19	40	27	0.896	-0.125	4.672	0.01	0.007	0	41.7	38.7	52.9	131	123	0	34	33
2014	7	21	19	50	27	0.896	-0.108	4.675	0.013	0.01	0	42.1	38.3	54.2	132	123	0	34	34
2014	7	21	20	0	27	0.906	-0.095	4.675	0.01	0.007	0	43	39.6	57.6	134	125	0	34	33
2014	7	21	20	10	27	0.896	-0.108	4.675	0.01	0.007	0	42.6	39.1	51.6	133	124	0	34	33
2014	7	21	20	20	27	0.912	-0.112	4.678	0.01	0.007	0	43.9	40.4	51.6	135	127	0	33	33
2014	7	21	20	30	27	0.912	-0.075	4.669	0.01	0.007	0	45.2	42.1	44.3	139	130	0	34	32
2014	7	21	20	40	27	0.873	-0.089	4.678	0.01	0.007	0	43.4	40	58.5	135	126	0	34	33
2014	7	21	20	50	27	0.892	-0.066	4.678	0.01	0.007	0	43	39.6	70.5	134	125	0	34	33
2014	7	21	21	0	27	0.886	-0.092	4.678	0.01	0.007	0	43	40	54.6	134	126	0	34	33
2014	7	21	21	10	27	0.886	-0.135	4.678	0.01	0.007	0	43.9	40.9	55.5	136	127	0	34	32
2014	7	21	21	20	27	0.935	-0.141	4.675	0.01	0.007	0	41.7	38.7	55.9	131	123	0	34	33
2014	7	21	21	30	27	0.912	-0.135	4.675	0.01	0.007	0	42.1	39.1	51.2	132	123	0	34	32
2014	7	21	21	40	27	0.922	-0.105	4.678	0.01	0.007	0	41.7	38.7	56.3	131	123	0	34	33
2014	7	21	21	50	27	0.912	-0.066	4.675	0.01	0.007	0	41.7	39.1	55.5	131	123	0	34	32
2014	7	21	22	0	27	0.876	-0.066	4.678	0.01	0.007	0	42.1	38.7	57.6	132	123	0	34	33
2014	7	21	22	10	27	0.892	-0.085	4.678	0.01	0.007	0	42.1	38.7	55.9	132	123	0	34	33
2014	7	21	22	20	27	0.863	-0.079	4.678	0.016	0.013	0	42.1	38.7	54.6	132	123	0	34	33
2014	7	21	22	30	27	0.889	-0.066	4.678	0.013	0.01	0	41.7	38.3	54.2	131	122	0	34	33
2014	7	21	22	40	27	0.866	-0.095	4.678	0.01	0.007	0	41.3	38.3	53.8	131	121	0	35	32
2014	7	21	22	50	27	0.879	-0.059	4.675	0.01	0.007	0	41.7	38.3	54.2	131	122	0	34	33
2014	7	21	23	0	27	0.869	-0.069	4.678	0.01	0.007	0	41.3	38.3	52.9	131	122	0	35	33
2014	7	21	23	10	27	0.892	-0.121	4.682	0.01	0.007	0	41.7	38.3	54.6	131	122	0	34	33
2014	7	21	23	20	27	0.879	-0.075	4.678	0.01	0.007	0	41.7	38.3	55.9	131	122	0	34	33
2014	7	21	23	30	27	0.873	-0.066	4.678	0.01	0.007	0	42.1	38.7	53.8	131	123	0	33	33
2014	7	21	23	40	27	0.833	-0.066	4.678	0.013	0.01	0	42.1	39.1	54.2	132	123	0	34	32
2014	7	21	23	50	27	0.863	-0.098	4.678	0.01	0.007	0	41.7	39.1	53.8	131	123	0	34	32
2014	7	22	0	0	27	0.883	-0.066	4.682	0.01	0.007	0	42.1	38.7	54.2	132	123	0	34	33
2014	7	22	0	10	27	0.883	-0.072	4.682	0.01	0.007	0	42.6	39.6	52.5	133	125	0	34	33
2014	7	22	0	20	27	0.915	-0.095	4.682	0.01	0.007	0	42.1	38.7	56.3	132	123	0	34	33
2014	7	22	0	30	27	0.892	-0.092	4.682	0.013	0.01	0	43	39.6	67.5	134	125	0	34	33
2014	7	22	0	40	27	0.879	-0.075	4.682	0.013	0.01	0	43.4	40.4	72.7	135	126	0	34	32
2014	7	22	0	50	27	0.889	-0.046	4.682	0.01	0.007	0	43.4	40	72.7	135	126	0	34	33
2014	7	22	1	0	27	0.892	-0.069	4.682	0.01	0.007	0	43.4	40.4	71.8	135	126	0	34	32
2014	7	22	1	10	27	0.873	-0.023	4.685	0.01	0.007	0	43.9	40.4	73.1	136	127	0	34	33
2014	7	22	1	20	27	0.896	-0.049	4.685	0.01	0.007	0	43	40	74.8	134	126	0	34	33
2014	7	22	1	30	27	0.899	-0.072	4.685	0.01	0.007	0	43.4	40	74.8	135	126	0	34	33
2014	7	22	1	40	27	0.886	-0.079	4.685	0.013	0.01	0	43	39.6	74.4	133	124	0	33	32
2014	7	22	1	50	27	0.886	-0.079	4.685	0.01	0.007	0	43.4	40	75.3	135	126	0	34	33
2014	7	22	2	0	27	0.892	-0.052	4.685	0.01	0.007	0	42.6	39.6	75.3	134	125	0	35	33
2014	7	22	2	10	27	0.899	-0.062	4.685	0.01	0.007	0	42.1	38.7	75.7	132	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	2	20	27	0.866	-0.066	4.685	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	22	2	30	27	0.889	-0.072	4.685	0.01	0.007	0	43	39.6	75.3	134	126	0	34	34
2014	7	22	2	40	27	0.892	-0.069	4.685	0.013	0.01	0	42.6	39.1	69.2	133	124	0	34	33
2014	7	22	2	50	27	0.869	-0.052	4.685	0.01	0.007	0	43	40	74.8	134	126	0	34	33
2014	7	22	3	0	27	0.879	-0.052	4.685	0.01	0.007	0	43	40	75.3	134	126	0	34	33
2014	7	22	3	10	27	0.889	-0.079	4.685	0.01	0.007	0	43.4	40	75.3	135	126	0	34	33
2014	7	22	3	20	27	0.899	-0.049	4.685	0.013	0.01	0	43.9	40.4	74.8	136	127	0	34	33
2014	7	22	3	30	27	0.866	-0.112	4.685	0.01	0.007	0	43	40	74.4	134	126	0	34	33
2014	7	22	3	40	27	0.915	-0.066	4.685	0.01	0.007	0	43	39.6	75.3	134	125	0	34	33
2014	7	22	3	50	27	0.909	-0.069	4.685	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	22	4	0	27	0.876	-0.066	4.685	0.01	0.007	0	43	39.1	74.8	134	125	0	34	34
2014	7	22	4	10	27	0.889	-0.046	4.685	0.01	0.007	0	43.9	41.3	73.5	137	128	0	35	32
2014	7	22	4	20	27	0.889	-0.082	4.685	0.01	0.007	0	43.4	40	74.4	135	126	0	34	33
2014	7	22	4	30	27	0.886	-0.069	4.685	0.01	0.007	0	43.4	40	74.4	135	126	0	34	33
2014	7	22	4	40	27	0.889	-0.072	4.685	0.01	0.007	0	43.9	40.4	74.8	136	127	0	34	33
2014	7	22	4	50	27	0.892	-0.075	4.685	0.013	0.01	0	43.4	40.4	74.4	136	127	0	35	33
2014	7	22	5	0	27	0.889	-0.066	4.685	0.01	0.007	0	43.4	40	74.4	135	126	0	34	33
2014	7	22	5	10	27	0.883	-0.049	4.685	0.013	0.01	0	43.4	40.4	74	135	127	0	34	33
2014	7	22	5	20	27	0.909	-0.066	4.685	0.01	0.007	0	43.4	40	74.4	135	126	0	34	33
2014	7	22	5	30	27	0.889	-0.089	4.685	0.013	0.01	0	43	40	73.5	134	126	0	34	33
2014	7	22	5	40	27	0.906	-0.082	4.685	0.01	0.007	0	43	39.6	74	134	125	0	34	33
2014	7	22	5	50	27	0.892	-0.049	4.685	0.01	0.007	0	42.6	40	73.5	134	126	0	35	33
2014	7	22	6	0	27	0.889	-0.052	4.685	0.01	0.007	0	43	38.7	74.4	134	124	0	34	34
2014	7	22	6	10	27	0.856	-0.062	4.685	0.01	0.007	0	42.1	39.6	74	133	124	0	35	32
2014	7	22	6	20	27	0.889	-0.059	4.685	0.013	0.01	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	22	6	30	27	0.889	-0.049	4.685	0.01	0.007	0	42.6	39.1	74.4	132	124	0	33	33
2014	7	22	6	40	27	0.912	-0.069	4.685	0.01	0.007	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	22	6	50	27	0.866	-0.082	4.685	0.01	0.007	0	43	39.6	73.1	134	125	0	34	33
2014	7	22	7	0	27	0.886	-0.043	4.685	0.01	0.007	0	43	39.1	74	134	125	0	34	34
2014	7	22	7	10	27	0.892	-0.095	4.685	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	22	7	20	27	0.919	-0.039	4.685	0.013	0.01	0	41.3	38.7	74	131	123	0	35	33
2014	7	22	7	30	27	0.869	-0.069	4.685	0.01	0.007	0	41.7	38.3	74.4	131	122	0	34	33
2014	7	22	7	40	27	0.935	-0.092	4.685	0.01	0.007	0	41.3	38.3	73.5	130	122	0	34	33
2014	7	22	7	50	27	0.889	-0.056	4.688	0.01	0.007	0	41.7	37.8	74.4	131	122	0	34	34
2014	7	22	8	0	27	0.876	-0.098	4.685	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	22	8	10	27	0.912	-0.075	4.685	0.01	0.007	0	42.6	38.7	73.5	132	123	0	33	33
2014	7	22	8	20	27	0.879	-0.085	4.685	0.013	0.01	0	41.3	38.3	74	131	123	0	35	34
2014	7	22	8	30	27	0.883	-0.062	4.685	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	22	8	40	27	0.889	-0.092	4.685	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	22	8	50	27	0.902	-0.062	4.685	0.01	0.007	0	41.7	38.3	74.4	131	122	0	34	33
2014	7	22	9	0	27	0.909	-0.072	4.685	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	22	9	10	27	0.876	-0.121	4.685	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	22	9	20	27	0.879	-0.141	4.685	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	22	9	30	27	0.912	-0.144	4.685	0.01	0.007	0	41.3	37.8	74.8	130	122	0	34	34
2014	7	22	9	40	27	0.892	-0.128	4.685	0.01	0.007	0	41.3	38.7	74	130	122	0	34	32
2014	7	22	9	50	27	0.869	-0.128	4.685	0.01	0.007	0	40.9	37.8	74.4	129	121	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	10	0	27	0.919	-0.171	4.685	0.01	0.007	0	41.3	38.7	74	130	122	0	34	32
2014	7	22	10	10	27	0.909	-0.095	4.685	0.01	0.007	0	41.3	37.8	61.9	130	121	0	34	33
2014	7	22	10	20	27	0.919	-0.125	4.685	0.013	0.01	0	40.9	38.3	60.6	130	121	0	35	32
2014	7	22	10	30	27	0.889	-0.161	4.685	0.01	0.007	0	41.3	37.4	64.1	130	121	0	34	34
2014	7	22	10	40	27	0.86	-0.164	4.685	0.01	0.007	0	40.4	37.8	63.6	129	121	0	35	33
2014	7	22	10	50	27	0.873	-0.154	4.685	0.01	0.007	0	41.3	38.3	61.9	130	122	0	34	33
2014	7	22	11	0	27	0.928	-0.095	4.685	0.01	0.007	0	41.7	38.7	58	131	122	0	34	32
2014	7	22	11	10	27	0.892	-0.089	4.685	0.01	0.007	0	41.3	38.3	56.8	130	122	0	34	33
2014	7	22	11	20	27	0.906	-0.174	4.682	0.01	0.007	0	40.9	37.4	61.5	129	121	0	34	34
2014	7	22	11	30	27	0.892	-0.187	4.685	0.01	0.007	0	40.9	37.4	67.5	129	121	0	34	34
2014	7	22	11	40	27	0.912	-0.144	4.682	0.01	0.007	0	41.3	37.8	63.6	130	121	0	34	33
2014	7	22	11	50	27	0.892	-0.164	4.685	0.01	0.007	0	40.9	37.4	54.6	129	120	0	34	33
2014	7	22	12	0	27	0.889	-0.118	4.682	0.01	0.007	0	40.9	37.8	60.6	129	121	0	34	33
2014	7	22	12	10	27	0.86	-0.128	4.682	0.013	0.01	0	40.9	37.8	56.3	129	121	0	34	33
2014	7	22	12	20	27	0.879	-0.174	4.682	0.013	0.01	0	40.9	38.3	55.9	129	121	0	34	32
2014	7	22	12	30	27	0.886	-0.161	4.682	0.01	0.007	0	40.9	37.4	52.9	129	121	0	34	34
2014	7	22	12	40	27	0.883	-0.164	4.682	0.01	0.007	0	44.7	41.7	49.5	138	129	0	34	32
2014	7	22	12	50	27	0.883	-0.171	4.678	0.01	0.007	0	40.9	37.8	53.3	129	121	0	34	33
2014	7	22	13	0	27	0.876	-0.115	4.682	0.01	0.007	0	41.3	38.7	52.9	130	122	0	34	32
2014	7	22	13	10	27	0.873	-0.154	4.682	0.01	0.007	0	41.3	37.8	52.9	130	121	0	34	33
2014	7	22	13	20	27	0.863	-0.108	4.678	0.013	0.01	0	41.3	38.7	53.3	131	123	0	35	33
2014	7	22	13	30	27	0.889	-0.157	4.678	0.013	0.01	0	41.7	38.7	53.8	131	123	0	34	33
2014	7	22	13	40	27	0.866	-0.187	4.678	0.01	0.007	0	40.9	38.3	52.9	130	122	0	35	33
2014	7	22	13	50	27	0.85	-0.177	4.675	0.01	0.007	0	41.3	38.3	53.3	130	122	0	34	33
2014	7	22	14	0	27	0.869	-0.167	4.678	0.01	0.007	0	41.7	38.7	52.9	131	123	0	34	33
2014	7	22	14	10	27	0.84	-0.144	4.678	0.01	0.007	0	41.3	38.7	53.3	131	123	0	35	33
2014	7	22	14	20	27	0.856	-0.164	4.675	0.013	0.01	0	41.7	39.1	52.9	131	123	0	34	32
2014	7	22	14	30	27	0.86	-0.082	4.672	0.01	0.007	0	45.2	41.3	47.3	139	130	0	34	34
2014	7	22	14	40	27	0.823	-0.167	4.672	0.01	0.007	0	44.3	40	50.3	137	126	0	34	33
2014	7	22	14	50	27	0.85	-0.128	4.672	0.01	0.007	0	43.4	40.4	49.9	135	127	0	34	33
2014	7	22	15	0	27	0.869	-0.167	4.672	0.01	0.007	0	44.3	41.3	44.7	137	129	0	34	33
2014	7	22	15	10	27	0.85	-0.18	4.672	0.01	0.007	0	43	39.6	53.3	134	125	0	34	33
2014	7	22	15	20	27	0.853	-0.167	4.672	0.01	0.007	0	43	40.4	52.9	134	126	0	34	32
2014	7	22	15	30	27	0.843	-0.18	4.675	0.01	0.007	0	42.6	39.6	50.7	133	125	0	34	33
2014	7	22	15	40	27	0.856	-0.105	4.669	0.01	0.007	0	43	40	49.9	134	126	0	34	33
2014	7	22	15	50	27	0.846	-0.082	4.675	0.01	0.007	0	43	40	50.3	134	126	0	34	33
2014	7	22	16	0	27	0.892	-0.102	4.672	0.01	0.007	0	47.3	44.3	47.3	144	136	0	34	33
2014	7	22	16	10	27	0.843	-0.092	4.669	0.01	0.007	0	43.4	40.4	52	135	127	0	34	33
2014	7	22	16	20	27	0.873	-0.082	4.672	0.01	0.007	0	43	40	51.6	134	126	0	34	33
2014	7	22	16	30	27	0.886	-0.036	4.672	0.013	0.01	0	43	40	52.9	134	126	0	34	33
2014	7	22	16	40	27	0.869	-0.069	4.672	0.01	0.007	0	43	40	53.8	134	126	0	34	33
2014	7	22	16	50	27	0.886	-0.085	4.672	0.01	0.007	0	42.6	39.6	53.8	133	125	0	34	33
2014	7	22	17	0	27	0.869	-0.092	4.669	0.013	0.01	0	42.1	39.1	51.6	132	124	0	34	33
2014	7	22	17	10	27	0.928	-0.079	4.665	0.01	0.007	0	42.1	39.1	52	133	124	0	35	33
2014	7	22	17	20	27	0.876	-0.062	4.672	0.01	0.007	0	42.6	39.6	52.9	133	125	0	34	33
2014	7	22	17	30	27	0.892	-0.066	4.672	0.01	0.007	0	42.1	39.1	51.2	132	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	17	40	27	0.863	-0.131	4.669	0.01	0.007	0	42.1	38.7	51.2	132	123	0	34	33
2014	7	22	17	50	27	0.883	-0.082	4.669	0.01	0.007	0	42.6	39.1	51.2	133	124	0	34	33
2014	7	22	18	0	27	0.876	-0.062	4.669	0.013	0.01	0	42.1	39.1	50.7	132	124	0	34	33
2014	7	22	18	10	27	0.892	-0.075	4.669	0.01	0.007	0	42.1	39.1	52.5	132	124	0	34	33
2014	7	22	18	20	27	0.879	-0.085	4.665	0.01	0.007	0	42.1	39.6	52.5	132	124	0	34	32
2014	7	22	18	30	27	0.906	-0.052	4.669	0.01	0.007	0	42.1	39.1	51.6	132	124	0	34	33
2014	7	22	18	40	27	0.86	-0.075	4.665	0.01	0.007	0	43	40	50.7	134	126	0	34	33
2014	7	22	18	50	27	0.876	-0.085	4.669	0.01	0.007	0	42.6	39.6	52	133	125	0	34	33
2014	7	22	19	0	27	0.876	-0.085	4.669	0.01	0.007	0	41.7	39.1	52.5	132	124	0	35	33
2014	7	22	19	10	27	0.876	-0.066	4.665	0.01	0.007	0	43	39.6	50.7	134	125	0	34	33
2014	7	22	19	20	27	0.879	-0.069	4.669	0.01	0.007	0	43	39.6	53.3	133	125	0	33	33
2014	7	22	19	30	27	0.892	-0.062	4.669	0.01	0.007	0	42.6	39.1	51.2	133	125	0	34	34
2014	7	22	19	40	27	0.876	-0.095	4.665	0.01	0.007	0	42.6	39.6	54.2	133	124	0	34	32
2014	7	22	19	50	27	0.856	-0.049	4.669	0.01	0.007	0	43	39.6	54.2	134	125	0	34	33
2014	7	22	20	0	27	0.873	-0.062	4.669	0.01	0.007	0	43	39.1	54.6	133	124	0	33	33
2014	7	22	20	10	27	0.876	-0.066	4.669	0.01	0.007	0	42.1	39.1	51.2	133	124	0	35	33
2014	7	22	20	20	27	0.896	-0.066	4.669	0.01	0.007	0	43	39.6	52.9	134	125	0	34	33
2014	7	22	20	30	27	0.902	-0.066	4.669	0.01	0.007	0	43	40	68.8	134	125	0	34	32
2014	7	22	20	40	27	0.886	-0.075	4.669	0.01	0.007	0	42.1	39.1	66.7	132	124	0	34	33
2014	7	22	20	50	27	0.876	-0.066	4.672	0.01	0.007	0	43	39.1	68.4	133	124	0	33	33
2014	7	22	21	0	27	0.876	-0.069	4.672	0.01	0.007	0	42.1	38.7	57.2	132	123	0	34	33
2014	7	22	21	10	27	0.906	-0.085	4.672	0.01	0.007	0	41.7	39.1	55.9	131	123	0	34	32
2014	7	22	21	20	27	0.876	-0.069	4.672	0.01	0.007	0	41.3	38.3	59.3	131	122	0	35	33
2014	7	22	21	30	27	0.906	-0.082	4.672	0.01	0.007	0	41.3	38.7	59.8	130	122	0	34	32
2014	7	22	21	40	27	0.889	-0.105	4.672	0.01	0.007	0	40.9	38.3	58.9	129	121	0	34	32
2014	7	22	21	50	27	0.892	-0.079	4.672	0.01	0.007	0	41.3	38.3	60.6	130	122	0	34	33
2014	7	22	22	0	27	0.906	-0.089	4.675	0.01	0.007	0	41.7	38.3	71	130	122	0	33	33
2014	7	22	22	10	27	0.896	-0.075	4.675	0.016	0.013	0	42.1	39.1	71.8	132	123	0	34	32
2014	7	22	22	20	27	0.892	-0.079	4.675	0.01	0.007	0	42.1	39.6	72.7	132	124	0	34	32
2014	7	22	22	30	27	0.876	-0.089	4.675	0.01	0.007	0	42.1	38.7	72.7	132	123	0	34	33
2014	7	22	22	40	27	0.892	-0.046	4.675	0.01	0.007	0	42.6	38.7	72.7	132	123	0	33	33
2014	7	22	22	50	27	0.873	-0.079	4.678	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	22	23	0	27	0.892	-0.072	4.678	0.01	0.007	0	41.3	38.3	73.1	130	122	0	34	33
2014	7	22	23	10	27	0.879	-0.098	4.678	0.01	0.007	0	42.6	39.1	72.7	133	124	0	34	33
2014	7	22	23	20	27	0.86	-0.066	4.678	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	22	23	30	27	0.896	-0.052	4.678	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	22	23	40	27	0.863	-0.052	4.678	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	22	23	50	27	0.879	-0.079	4.678	0.01	0.007	0	42.6	39.1	74	133	125	0	34	34
2014	7	23	0	0	27	0.876	-0.079	4.678	0.01	0.007	0	43	39.1	74.4	133	124	0	33	33
2014	7	23	0	10	27	0.896	-0.079	4.678	0.01	0.007	0	42.1	38.7	72.2	132	124	0	34	34
2014	7	23	0	20	27	0.866	-0.062	4.678	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	23	0	30	27	0.922	-0.092	4.678	0.013	0.01	0	42.6	38.3	74.8	132	123	0	33	34
2014	7	23	0	40	27	0.873	-0.062	4.678	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	23	0	50	27	0.883	-0.066	4.678	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	23	1	0	27	0.866	-0.056	4.678	0.013	0.01	0	43	39.6	74.4	134	125	0	34	33
2014	7	23	1	10	27	0.869	-0.059	4.678	0.013	0.01	0	42.6	39.6	74	133	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	1	20	27	0.896	-0.069	4.682	0.01	0.007	0	42.1	39.6	74	133	125	0	35	33
2014	7	23	1	30	27	0.892	-0.066	4.682	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	23	1	40	27	0.892	-0.066	4.682	0.01	0.007	0	42.1	39.1	75.7	132	124	0	34	33
2014	7	23	1	50	27	0.879	-0.049	4.682	0.01	0.007	0	42.6	39.6	74.8	133	125	0	34	33
2014	7	23	2	0	27	0.863	-0.052	4.682	0.01	0.007	0	42.6	39.1	74.8	133	125	0	34	34
2014	7	23	2	10	27	0.896	-0.079	4.682	0.01	0.007	0	43.9	40	73.5	136	127	0	34	34
2014	7	23	2	20	27	0.906	-0.082	4.682	0.01	0.007	0	42.6	40	74.4	134	126	0	35	33
2014	7	23	2	30	27	0.889	-0.059	4.682	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	23	2	40	27	0.906	-0.052	4.682	0.01	0.007	0	42.6	40	71	134	126	0	35	33
2014	7	23	2	50	27	0.892	-0.082	4.682	0.01	0.007	0	43.9	40.9	75.7	136	128	0	34	33
2014	7	23	3	0	27	0.889	-0.082	4.682	0.01	0.007	0	42.1	39.1	75.7	132	124	0	34	33
2014	7	23	3	10	27	0.896	-0.059	4.682	0.01	0.007	0	42.6	39.6	74.4	133	125	0	34	33
2014	7	23	3	20	27	0.889	-0.049	4.682	0.01	0.007	0	43.4	40.4	74.8	135	126	0	34	32
2014	7	23	3	30	27	0.889	-0.062	4.682	0.01	0.007	0	43.4	40.4	75.3	135	127	0	34	33
2014	7	23	3	40	27	0.883	-0.062	4.682	0.01	0.007	0	42.6	40	75.3	134	126	0	35	33
2014	7	23	3	50	27	0.873	-0.056	4.682	0.013	0.01	0	43	39.6	75.3	134	126	0	34	34
2014	7	23	4	0	27	0.886	-0.082	4.682	0.01	0.007	0	43	40	74.8	134	126	0	34	33
2014	7	23	4	10	27	0.889	-0.059	4.682	0.01	0.007	0	43.9	41.3	73.5	137	129	0	35	33
2014	7	23	4	20	27	0.879	-0.069	4.682	0.01	0.007	0	43.4	40	74.4	135	126	0	34	33
2014	7	23	4	30	27	0.902	-0.059	4.682	0.01	0.007	0	43	40.4	74.4	135	127	0	35	33
2014	7	23	4	40	27	0.902	-0.056	4.682	0.01	0.007	0	43.4	40	74.8	135	127	0	34	34
2014	7	23	4	50	27	0.879	-0.079	4.682	0.013	0.01	0	43.9	40.4	74.8	136	127	0	34	33
2014	7	23	5	0	27	0.889	-0.098	4.682	0.01	0.007	0	43	39.6	74	134	126	0	34	34
2014	7	23	5	10	27	0.873	-0.059	4.682	0.01	0.007	0	43	40.4	73.5	135	127	0	35	33
2014	7	23	5	20	27	0.896	-0.059	4.682	0.01	0.007	0	43.4	40	72.7	135	126	0	34	33
2014	7	23	5	30	27	0.906	-0.049	4.682	0.01	0.007	0	43.4	40	74.4	134	126	0	33	33
2014	7	23	5	40	27	0.873	-0.085	4.682	0.01	0.007	0	42.6	39.6	66.7	133	125	0	34	33
2014	7	23	5	50	27	0.886	-0.075	4.685	0.01	0.007	0	43	39.6	73.1	134	125	0	34	33
2014	7	23	6	0	27	0.883	-0.056	4.685	0.01	0.007	0	42.1	39.1	73.5	133	124	0	35	33
2014	7	23	6	10	27	0.863	-0.085	4.685	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	23	6	20	27	0.856	-0.085	4.685	0.01	0.007	0	42.1	38.7	73.1	132	124	0	34	34
2014	7	23	6	30	27	0.876	-0.049	4.685	0.01	0.007	0	43	39.6	73.1	134	125	0	34	33
2014	7	23	6	40	27	0.879	-0.059	4.685	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	23	6	50	27	0.899	-0.079	4.685	0.01	0.007	0	41.3	38.7	73.1	131	123	0	35	33
2014	7	23	7	0	27	0.892	-0.056	4.685	0.01	0.007	0	42.1	39.1	73.1	132	124	0	34	33
2014	7	23	7	10	27	0.86	-0.095	4.685	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	23	7	20	27	0.889	-0.069	4.685	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	23	7	30	27	0.889	-0.059	4.685	0.013	0.01	0	41.7	38.3	71.4	131	123	0	34	34
2014	7	23	7	40	27	0.873	-0.079	4.685	0.01	0.007	0	41.3	38.3	71.8	130	122	0	34	33
2014	7	23	7	50	27	0.843	-0.062	4.685	0.01	0.007	0	41.3	38.3	71.8	130	122	0	34	33
2014	7	23	8	0	27	0.899	-0.066	4.685	0.01	0.007	0	41.3	38.7	72.7	131	123	0	35	33
2014	7	23	8	10	27	0.902	-0.066	4.685	0.01	0.007	0	41.7	38.7	72.2	131	123	0	34	33
2014	7	23	8	20	27	0.85	-0.079	4.685	0.01	0.007	0	41.7	38.7	72.7	131	123	0	34	33
2014	7	23	8	30	27	0.883	-0.049	4.685	0.01	0.007	0	41.3	38.7	72.2	131	123	0	35	33
2014	7	23	8	40	27	0.925	-0.082	4.685	0.013	0.01	0	41.3	38.7	72.2	131	123	0	35	33
2014	7	23	8	50	27	0.883	-0.089	4.685	0.01	0.007	0	41.7	38.7	71.8	131	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	9	0	27	0.892	-0.066	4.685	0.01	0.007	0	41.7	38.7	71.8	131	123	0	34	33
2014	7	23	9	10	27	0.899	-0.082	4.685	0.01	0.007	0	41.7	38.7	72.2	131	123	0	34	33
2014	7	23	9	20	27	0.896	-0.069	4.685	0.01	0.007	0	41.7	38.7	72.7	131	123	0	34	33
2014	7	23	9	30	27	0.892	-0.095	4.685	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	23	9	40	27	0.883	-0.098	4.685	0.01	0.007	0	41.7	37.8	72.7	131	122	0	34	34
2014	7	23	9	50	27	0.915	-0.082	4.685	0.013	0.01	0	41.3	38.3	73.1	131	123	0	35	34
2014	7	23	10	0	27	0.899	-0.085	4.685	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	23	10	10	27	0.902	-0.062	4.685	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	23	10	20	27	0.915	-0.095	4.685	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	23	10	30	27	0.902	-0.121	4.685	0.01	0.007	0	41.3	38.3	73.5	130	122	0	34	33
2014	7	23	10	40	27	0.886	-0.138	4.682	0.01	0.007	0	40.9	37.8	74	129	122	0	34	34
2014	7	23	10	50	27	0.906	-0.128	4.682	0.016	0.013	0	40.9	37.8	72.7	129	121	0	34	33
2014	7	23	11	0	27	0.896	-0.167	4.682	0.01	0.007	0	40.9	37.8	73.1	129	121	0	34	33
2014	7	23	11	10	27	0.889	-0.135	4.682	0.01	0.007	0	40.4	37.4	73.5	129	121	0	35	34
2014	7	23	11	20	27	0.912	-0.125	4.682	0.013	0.01	0	40.9	37.8	74	129	121	0	34	33
2014	7	23	11	30	27	0.889	-0.135	4.682	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	23	11	40	27	0.906	-0.161	4.682	0.01	0.007	0	40.9	37.8	59.8	129	121	0	34	33
2014	7	23	11	50	27	0.912	-0.102	4.682	0.01	0.007	0	41.3	37.8	72.2	130	122	0	34	34
2014	7	23	12	0	27	0.869	-0.138	4.682	0.01	0.007	0	40.9	37.8	70.5	129	121	0	34	33
2014	7	23	12	10	27	0.892	-0.148	4.682	0.01	0.007	0	40.9	37.8	68.8	129	121	0	34	33
2014	7	23	12	20	27	0.879	-0.161	4.682	0.01	0.007	0	40.4	37.8	74.4	128	121	0	34	33
2014	7	23	12	30	27	0.945	-0.069	4.682	0.01	0.007	0	40.9	38.3	63.2	129	121	0	34	32
2014	7	23	12	40	27	0.906	-0.174	4.682	0.01	0.007	0	40.4	37.8	74	128	121	0	34	33
2014	7	23	12	50	27	0.919	-0.18	4.682	0.01	0.007	0	40.9	37.8	73.1	129	121	0	34	33
2014	7	23	13	0	27	0.915	-0.112	4.682	0.01	0.007	0	41.3	37.4	74.8	129	121	0	33	34
2014	7	23	13	10	27	0.863	-0.18	4.682	0.01	0.007	0	40	37.4	58	128	120	0	35	33
2014	7	23	13	20	27	0.896	-0.102	4.682	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	23	13	30	27	0.846	-0.144	4.682	0.01	0.007	0	40.9	37.4	55.9	128	120	0	33	33
2014	7	23	13	40	27	0.869	-0.203	4.682	0.01	0.007	0	40.4	37.4	60.2	128	120	0	34	33
2014	7	23	13	50	27	0.892	-0.128	4.682	0.01	0.007	0	40.9	37.4	73.1	129	121	0	34	34
2014	7	23	14	0	27	0.912	-0.128	4.682	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2014	7	23	14	10	27	0.896	-0.141	4.682	0.01	0.007	0	40.9	37.8	60.6	129	121	0	34	33
2014	7	23	14	20	27	0.902	-0.135	4.682	0.01	0.007	0	40.9	38.3	69.2	129	122	0	34	33
2014	7	23	14	30	27	0.902	-0.118	4.682	0.01	0.007	0	40.9	37.8	75.3	129	121	0	34	33
2014	7	23	14	40	27	0.906	-0.151	4.682	0.01	0.007	0	40.9	37.8	68.4	129	121	0	34	33
2014	7	23	14	50	27	0.886	-0.174	4.682	0.01	0.007	0	40.9	37.8	68.8	129	121	0	34	33
2014	7	23	15	0	27	0.922	-0.085	4.682	0.01	0.007	0	41.3	38.3	72.7	130	122	0	34	33
2014	7	23	15	10	27	0.906	-0.108	4.682	0.01	0.007	0	40.9	38.7	76.1	129	122	0	34	32
2014	7	23	15	20	27	0.915	-0.112	4.678	0.013	0.01	0	40.4	37.8	57.2	129	121	0	35	33
2014	7	23	15	30	27	0.889	-0.151	4.682	0.01	0.007	0	41.3	38.7	55	130	122	0	34	32
2014	7	23	15	40	27	0.883	-0.148	4.678	0.01	0.007	0	41.3	38.7	51.6	130	123	0	34	33
2014	7	23	15	50	27	0.899	-0.082	4.678	0.01	0.007	0	41.7	38.7	56.3	131	123	0	34	33
2014	7	23	16	0	27	0.879	-0.108	4.678	0.01	0.007	0	41.7	39.6	55.9	131	124	0	34	32
2014	7	23	16	10	27	0.886	-0.075	4.682	0.01	0.007	0	41.7	38.3	56.3	131	123	0	34	34
2014	7	23	16	20	27	0.889	-0.112	4.678	0.01	0.007	0	42.1	39.1	53.8	132	124	0	34	33
2014	7	23	16	30	27	0.873	-0.082	4.678	0.01	0.007	0	41.3	38.3	56.3	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	16	40	27	0.889	-0.138	4.678	0.01	0.007	0	41.3	37.8	58.9	130	122	0	34	34
2014	7	23	16	50	27	0.909	-0.082	4.675	0.01	0.007	0	41.7	38.7	53.8	131	123	0	34	33
2014	7	23	17	0	27	0.922	-0.075	4.678	0.01	0.007	0	41.3	38.3	55.9	130	122	0	34	33
2014	7	23	17	10	27	0.902	-0.095	4.675	0.01	0.007	0	41.3	37.8	53.8	130	122	0	34	34
2014	7	23	17	20	27	0.928	-0.049	4.675	0.01	0.007	0	41.7	38.7	54.6	131	123	0	34	33
2014	7	23	17	30	27	0.889	-0.059	4.675	0.01	0.007	0	42.1	39.1	55.5	132	124	0	34	33
2014	7	23	17	40	27	0.906	-0.095	4.678	0.013	0.01	0	41.3	38.7	53.3	131	123	0	35	33
2014	7	23	17	50	27	0.866	-0.03	4.672	0.01	0.007	0	46	43.9	45.6	142	135	0	35	33
2014	7	23	18	0	27	0.886	-0.092	4.675	0.01	0.007	0	43.4	39.6	52	135	125	0	34	33
2014	7	23	18	10	27	0.892	-0.105	4.678	0.01	0.007	0	42.1	37.8	55.5	132	121	0	34	33
2014	7	23	18	20	27	0.876	-0.098	4.678	0.01	0.007	0	41.7	37.8	57.6	131	122	0	34	34
2014	7	23	18	30	27	0.892	-0.112	4.678	0.01	0.007	0	41.7	38.3	57.6	131	122	0	34	33
2014	7	23	18	40	27	0.925	-0.105	4.678	0.01	0.007	0	41.7	38.3	55	131	122	0	34	33
2014	7	23	18	50	27	0.919	-0.092	4.678	0.01	0.007	0	42.1	38.3	54.6	132	122	0	34	33
2014	7	23	19	0	27	0.889	-0.095	4.678	0.01	0.007	0	41.7	37.8	70.1	131	122	0	34	34
2014	7	23	19	10	27	0.879	-0.098	4.678	0.01	0.007	0	41.7	38.3	59.8	132	123	0	35	34
2014	7	23	19	20	27	0.912	-0.092	4.678	0.01	0.007	0	42.1	38.7	59.8	132	123	0	34	33
2014	7	23	19	30	27	0.892	-0.105	4.678	0.01	0.007	0	42.1	38.7	67.1	132	123	0	34	33
2014	7	23	19	40	27	0.935	-0.049	4.678	0.01	0.007	0	43	39.6	56.3	134	125	0	34	33
2014	7	23	19	50	27	0.902	-0.079	4.678	0.01	0.007	0	43	39.1	66.7	134	124	0	34	33
2014	7	23	20	0	27	0.896	-0.079	4.678	0.013	0.01	0	43	39.1	74.4	134	124	0	34	33
2014	7	23	20	10	27	0.906	-0.079	4.678	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	23	20	20	27	0.889	-0.066	4.682	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	23	20	30	27	0.909	-0.089	4.678	0.01	0.007	0	43.4	40	73.1	135	126	0	34	33
2014	7	23	20	40	27	0.879	-0.098	4.682	0.01	0.007	0	43	39.1	70.5	134	124	0	34	33
2014	7	23	20	50	27	0.873	-0.075	4.682	0.013	0.01	0	43	39.6	74	134	125	0	34	33
2014	7	23	21	0	27	0.892	-0.062	4.682	0.01	0.007	0	43	38.7	75.7	134	124	0	34	34
2014	7	23	21	10	27	0.873	-0.079	4.682	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	23	21	20	27	0.902	-0.095	4.682	0.01	0.007	0	42.1	38.3	75.3	132	123	0	34	34
2014	7	23	21	30	27	0.899	-0.072	4.682	0.01	0.007	0	42.6	38.7	75.3	132	123	0	33	33
2014	7	23	21	40	27	0.883	-0.046	4.682	0.013	0.01	0	43.4	39.1	74.8	135	125	0	34	34
2014	7	23	21	50	27	0.883	-0.072	4.682	0.01	0.007	0	42.6	38.3	74.4	133	123	0	34	34
2014	7	23	22	0	27	0.906	-0.098	4.682	0.01	0.007	0	42.6	39.1	75.7	133	124	0	34	33
2014	7	23	22	10	27	0.873	-0.075	4.682	0.01	0.007	0	42.6	38.7	75.3	133	124	0	34	34
2014	7	23	22	20	27	0.886	-0.079	4.682	0.013	0.01	0	41.7	38.3	75.7	131	122	0	34	33
2014	7	23	22	30	27	0.912	-0.062	4.682	0.01	0.007	0	42.1	39.1	74	132	123	0	34	32
2014	7	23	22	40	27	0.906	-0.066	4.682	0.013	0.01	0	42.1	37.8	75.3	131	121	0	33	33
2014	7	23	22	50	27	0.86	-0.095	4.682	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	23	23	0	27	0.919	-0.085	4.682	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	23	23	10	27	0.935	-0.069	4.682	0.01	0.007	0	42.1	38.3	51.2	132	123	0	34	34
2014	7	23	23	20	27	0.965	-0.082	4.682	0.01	0.007	0	41.7	38.3	49.5	131	122	0	34	33
2014	7	23	23	30	27	0.883	-0.089	4.682	0.013	0.01	0	42.1	38.3	74.4	132	123	0	34	34
2014	7	23	23	40	27	0.866	-0.056	4.682	0.01	0.007	0	42.1	39.1	75.7	133	124	0	35	33
2014	7	23	23	50	27	0.919	-0.085	4.682	0.01	0.007	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	24	0	0	27	0.896	-0.069	4.685	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	24	0	10	27	0.886	-0.069	4.682	0.01	0.007	0	43.4	40	75.3	135	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	0	20	27	0.899	-0.082	4.685	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	24	0	30	27	0.873	-0.049	4.685	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	24	0	40	27	0.886	-0.052	4.685	0.013	0.01	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	24	0	50	27	0.883	-0.049	4.685	0.01	0.007	0	42.1	38.3	73.5	132	123	0	34	34
2014	7	24	1	0	27	0.883	-0.095	4.685	0.01	0.007	0	43	39.6	74.4	134	125	0	34	33
2014	7	24	1	10	27	0.896	-0.069	4.685	0.01	0.007	0	43	39.6	74.8	134	124	0	34	32
2014	7	24	1	20	27	0.919	-0.079	4.685	0.013	0.01	0	42.1	39.1	74.4	132	123	0	34	32
2014	7	24	1	30	27	0.869	-0.066	4.685	0.01	0.007	0	43	39.6	74.4	135	125	0	35	33
2014	7	24	1	40	27	0.899	-0.066	4.685	0.01	0.007	0	42.1	39.1	74	133	124	0	35	33
2014	7	24	1	50	27	0.889	-0.062	4.685	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33
2014	7	24	2	0	27	0.876	-0.098	4.685	0.013	0.01	0	43.4	39.6	74.4	134	125	0	33	33
2014	7	24	2	10	27	0.892	-0.056	4.685	0.01	0.007	0	43	39.1	73.5	134	124	0	34	33
2014	7	24	2	20	27	0.869	-0.072	4.685	0.01	0.007	0	43	40	73.5	135	126	0	35	33
2014	7	24	2	30	27	0.889	-0.056	4.685	0.01	0.007	0	43	39.6	74	135	125	0	35	33
2014	7	24	2	40	27	0.886	-0.079	4.685	0.01	0.007	0	42.6	38.7	72.2	133	123	0	34	33
2014	7	24	2	50	27	0.886	-0.066	4.685	0.013	0.01	0	42.1	39.1	71.8	133	124	0	35	33
2014	7	24	3	0	27	0.912	-0.069	4.685	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	24	3	10	27	0.902	-0.079	4.685	0.016	0.013	0	43	39.6	73.5	134	124	0	34	32
2014	7	24	3	20	27	0.906	-0.075	4.685	0.01	0.007	0	43	39.6	73.5	135	125	0	35	33
2014	7	24	3	30	27	0.879	-0.069	4.685	0.01	0.007	0	43.4	40	73.1	135	126	0	34	33
2014	7	24	3	40	27	0.909	-0.062	4.685	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	24	3	50	27	0.886	-0.069	4.685	0.01	0.007	0	43	39.1	72.7	134	125	0	34	34
2014	7	24	4	0	27	0.899	-0.089	4.685	0.01	0.007	0	43	39.6	72.2	134	125	0	34	33
2014	7	24	4	10	27	0.896	-0.069	4.688	0.01	0.007	0	43.4	40	72.7	135	126	0	34	33
2014	7	24	4	20	27	0.892	-0.023	4.688	0.01	0.007	0	43.9	40.4	72.2	136	127	0	34	33
2014	7	24	4	30	27	0.886	-0.046	4.688	0.01	0.007	0	43.4	40.4	71.4	135	126	0	34	32
2014	7	24	4	40	27	0.86	-0.046	4.688	0.013	0.01	0	43	38.7	71.8	134	124	0	34	34
2014	7	24	4	50	27	0.889	-0.069	4.688	0.01	0.007	0	43.9	40	71.8	136	126	0	34	33
2014	7	24	5	0	27	0.883	-0.082	4.688	0.01	0.007	0	43	39.6	71.8	135	125	0	35	33
2014	7	24	5	10	27	0.879	-0.026	4.688	0.013	0.01	0	43.4	39.6	71	135	126	0	34	34
2014	7	24	5	20	27	0.886	-0.062	4.688	0.01	0.007	0	43.9	40	70.5	136	126	0	34	33
2014	7	24	5	30	27	0.886	-0.046	4.688	0.01	0.007	0	43	39.6	71.4	134	125	0	34	33
2014	7	24	5	40	27	0.879	-0.115	4.688	0.01	0.007	0	43.4	39.1	71	135	125	0	34	34
2014	7	24	5	50	27	0.902	-0.062	4.688	0.01	0.007	0	43.4	39.6	71	135	125	0	34	33
2014	7	24	6	0	27	0.909	-0.072	4.688	0.01	0.007	0	43	39.6	70.5	134	125	0	34	33
2014	7	24	6	10	27	0.896	-0.033	4.688	0.01	0.007	0	43	39.1	69.7	134	124	0	34	33
2014	7	24	6	20	27	0.912	-0.059	4.692	0.01	0.007	0	42.6	39.1	70.5	134	124	0	35	33
2014	7	24	6	30	27	0.889	-0.046	4.695	0.013	0.01	0	43	39.1	70.5	134	124	0	34	33
2014	7	24	6	40	27	0.896	-0.062	4.695	0.01	0.007	0	42.1	38.7	70.5	133	123	0	35	33
2014	7	24	6	50	27	0.886	-0.046	4.695	0.01	0.007	0	42.1	39.1	71	133	124	0	35	33
2014	7	24	7	0	27	0.906	-0.069	4.698	0.01	0.007	0	42.6	38.7	70.5	133	123	0	34	33
2014	7	24	7	10	27	0.873	-0.079	4.698	0.01	0.007	0	42.1	38.3	71.4	132	122	0	34	33
2014	7	24	7	20	27	0.922	-0.069	4.698	0.013	0.01	0	41.7	38.3	71	132	122	0	35	33
2014	7	24	7	30	27	0.879	-0.043	4.698	0.01	0.007	0	42.1	38.3	71	132	122	0	34	33
2014	7	24	7	40	27	0.883	-0.059	4.698	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	24	7	50	27	0.879	-0.043	4.698	0.013	0.01	0	41.7	38.3	71.8	132	123	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	8	0	27	0.876	-0.089	4.698	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	24	8	10	27	0.873	-0.085	4.698	0.01	0.007	0	41.7	38.3	71.8	131	122	0	34	33
2014	7	24	8	20	27	0.912	-0.095	4.698	0.01	0.007	0	41.7	38.3	71.4	131	122	0	34	33
2014	7	24	8	30	27	0.902	-0.082	4.698	0.01	0.007	0	41.7	37.8	71.8	131	122	0	34	34
2014	7	24	8	40	27	0.879	-0.066	4.698	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	24	8	50	27	0.896	-0.056	4.695	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	24	9	0	27	0.892	-0.079	4.695	0.01	0.007	0	41.3	38.3	71	131	122	0	35	33
2014	7	24	9	10	27	0.876	-0.079	4.695	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	24	9	20	27	0.909	-0.066	4.695	0.01	0.007	0	41.7	38.3	71	132	122	0	35	33
2014	7	24	9	30	27	0.912	-0.082	4.692	0.01	0.007	0	41.7	38.7	71	131	122	0	34	32
2014	7	24	9	40	27	0.892	-0.079	4.692	0.01	0.007	0	41.7	38.3	70.5	131	122	0	34	33
2014	7	24	9	50	27	0.909	-0.098	4.688	0.01	0.007	0	40.9	37.4	71	130	121	0	35	34
2014	7	24	10	0	27	0.892	-0.138	4.688	0.01	0.007	0	41.7	37.8	70.1	131	121	0	34	33
2014	7	24	10	10	27	0.899	-0.151	4.688	0.01	0.007	0	40.9	37.8	71.8	130	122	0	35	34
2014	7	24	10	20	27	0.883	-0.141	4.688	0.01	0.007	0	41.3	37.4	71.4	130	121	0	34	34
2014	7	24	10	30	27	0.912	-0.138	4.688	0.01	0.007	0	42.1	38.3	71.8	131	122	0	33	33
2014	7	24	10	40	27	0.896	-0.118	4.688	0.01	0.007	0	41.7	37.8	72.2	131	121	0	34	33
2014	7	24	10	50	27	0.879	-0.144	4.688	0.01	0.007	0	41.3	37.8	71.8	130	121	0	34	33
2014	7	24	11	0	27	0.892	-0.121	4.688	0.01	0.007	0	40.9	37.8	72.2	130	122	0	35	34
2014	7	24	11	10	27	0.902	-0.115	4.688	0.01	0.007	0	41.3	37.8	71.8	130	122	0	34	34
2014	7	24	11	20	27	0.899	-0.144	4.688	0.01	0.007	0	40.9	37.4	71.8	130	121	0	35	34
2014	7	24	11	30	27	0.876	-0.131	4.685	0.01	0.007	0	41.3	38.3	72.7	131	122	0	35	33
2014	7	24	11	40	27	0.892	-0.141	4.685	0.01	0.007	0	41.3	37.8	70.1	130	121	0	34	33
2014	7	24	11	50	27	0.909	-0.125	4.688	0.01	0.007	0	41.7	38.3	72.7	131	122	0	34	33
2014	7	24	12	0	27	0.883	-0.131	4.685	0.013	0.01	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	24	12	10	27	0.892	-0.154	4.685	0.01	0.007	0	41.3	38.3	71	130	121	0	34	32
2014	7	24	12	20	27	0.886	-0.187	4.685	0.01	0.007	0	40.4	37.4	71.4	129	120	0	35	33
2014	7	24	12	30	27	0.883	-0.112	4.682	0.01	0.007	0	41.3	37.8	60.6	130	121	0	34	33
2014	7	24	12	40	27	0.899	-0.144	4.682	0.01	0.007	0	40.9	37.4	59.8	129	120	0	34	33
2014	7	24	12	50	27	0.886	-0.161	4.682	0.01	0.007	0	41.3	37.8	69.7	130	121	0	34	33
2014	7	24	13	0	27	0.883	-0.167	4.682	0.01	0.007	0	40.9	37.4	59.8	129	120	0	34	33
2014	7	24	13	10	27	0.915	-0.144	4.682	0.01	0.007	0	41.3	37.8	62.8	130	121	0	34	33
2014	7	24	13	20	27	0.909	-0.141	4.685	0.01	0.007	0	40.9	37	59.3	129	120	0	34	34
2014	7	24	13	30	27	0.896	-0.157	4.685	0.01	0.007	0	40.9	37.4	58.5	129	120	0	34	33
2014	7	24	13	40	27	0.886	-0.21	4.685	0.01	0.007	0	40.9	37.8	60.2	129	120	0	34	32
2014	7	24	13	50	27	0.866	-0.144	4.682	0.01	0.007	0	40.9	37.4	63.2	129	120	0	34	33
2014	7	24	14	0	27	0.889	-0.141	4.682	0.01	0.007	0	40.9	37	59.3	129	120	0	34	34
2014	7	24	14	10	27	0.906	-0.161	4.682	0.01	0.007	0	40.9	37.4	60.6	129	120	0	34	33
2014	7	24	14	20	27	0.892	-0.131	4.682	0.01	0.007	0	41.3	37.8	60.2	130	121	0	34	33
2014	7	24	14	30	27	0.869	-0.171	4.682	0.01	0.007	0	40.9	37.4	59.8	129	120	0	34	33
2014	7	24	14	40	27	0.873	-0.177	4.682	0.01	0.007	0	40.9	37.4	58.9	129	120	0	34	33
2014	7	24	14	50	27	0.906	-0.112	4.682	0.01	0.007	0	41.3	37	55	130	120	0	34	34
2014	7	24	15	0	27	0.876	-0.115	4.682	0.01	0.007	0	40.9	37	56.3	129	120	0	34	34
2014	7	24	15	10	27	0.883	-0.141	4.682	0.01	0.007	0	40.9	37.8	55.5	129	121	0	34	33
2014	7	24	15	20	27	0.889	-0.157	4.682	0.01	0.007	0	41.7	37.8	55.5	130	121	0	33	33
2014	7	24	15	30	27	0.909	-0.154	4.678	0.01	0.007	0	40.9	37.4	61.1	130	121	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	15	40	27	0.925	-0.105	4.682	0.013	0.01	0	41.3	37.8	61.5	130	121	0	34	33
2014	7	24	15	50	27	0.896	-0.135	4.678	0.01	0.007	0	40.9	37.4	59.8	129	120	0	34	33
2014	7	24	16	0	27	0.912	-0.151	4.678	0.01	0.007	0	41.3	37.8	65.8	130	121	0	34	33
2014	7	24	16	10	27	0.879	-0.141	4.678	0.01	0.007	0	40.9	37.8	55.9	129	120	0	34	32
2014	7	24	16	20	27	0.879	-0.174	4.678	0.01	0.007	0	41.3	38.3	55.5	130	122	0	34	33
2014	7	24	16	30	27	0.883	-0.095	4.678	0.01	0.007	0	41.3	37.8	55.5	130	121	0	34	33
2014	7	24	16	40	27	0.866	-0.128	4.678	0.01	0.007	0	41.7	38.3	54.6	131	122	0	34	33
2014	7	24	16	50	27	0.876	-0.121	4.678	0.01	0.007	0	41.3	37.4	53.3	130	121	0	34	34
2014	7	24	17	0	27	0.886	-0.112	4.678	0.01	0.007	0	40.9	37.8	54.2	130	121	0	35	33
2014	7	24	17	10	27	0.909	-0.141	4.678	0.01	0.007	0	41.3	38.3	55	131	122	0	35	33
2014	7	24	17	20	27	0.892	-0.089	4.682	0.01	0.007	0	41.7	37.8	52.9	131	121	0	34	33
2014	7	24	17	30	27	0.892	-0.072	4.678	0.01	0.007	0	41.7	37.8	56.8	131	121	0	34	33
2014	7	24	17	40	27	0.86	-0.098	4.678	0.01	0.007	0	41.7	37.8	52.9	131	121	0	34	33
2014	7	24	17	50	27	0.876	-0.066	4.678	0.013	0.01	0	40.9	38.3	55.9	130	121	0	35	32
2014	7	24	18	0	27	0.919	-0.112	4.678	0.01	0.007	0	41.7	38.3	56.3	131	122	0	34	33
2014	7	24	18	10	27	0.906	-0.102	4.678	0.01	0.007	0	41.3	38.3	60.2	130	121	0	34	32
2014	7	24	18	20	27	0.889	-0.069	4.678	0.01	0.007	0	43.4	40	50.7	136	126	0	35	33
2014	7	24	18	30	27	0.922	-0.102	4.675	0.01	0.007	0	42.1	38.7	55.5	132	123	0	34	33
2014	7	24	18	40	27	0.869	-0.079	4.678	0.01	0.007	0	49	45.6	46.4	149	139	0	35	33
2014	7	24	18	50	27	0.906	-0.095	4.678	0.01	0.007	0	41.7	37.8	59.8	131	122	0	34	34
2014	7	24	19	0	27	0.889	-0.069	4.678	0.01	0.007	0	43	39.6	53.8	134	124	0	34	32
2014	7	24	19	10	27	0.879	-0.079	4.675	0.01	0.007	0	44.7	40.9	51.6	138	128	0	34	33
2014	7	24	19	20	27	0.883	-0.062	4.682	0.01	0.007	0	43.4	39.6	52.9	135	125	0	34	33
2014	7	24	19	30	27	0.873	-0.069	4.682	0.01	0.007	0	43	39.6	56.8	134	125	0	34	33
2014	7	24	19	40	27	0.909	-0.079	4.682	0.013	0.01	0	42.6	39.1	58	133	124	0	34	33
2014	7	24	19	50	27	0.883	-0.079	4.678	0.01	0.007	0	42.6	38.7	75.7	133	123	0	34	33
2014	7	24	20	0	27	0.889	-0.052	4.682	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	24	20	10	27	0.912	-0.052	4.678	0.01	0.007	0	42.6	39.1	74.8	133	124	0	34	33
2014	7	24	20	20	27	0.876	-0.095	4.682	0.01	0.007	0	43	39.1	75.3	134	124	0	34	33
2014	7	24	20	30	27	0.892	-0.072	4.678	0.01	0.007	0	43	40	74.4	134	125	0	34	32
2014	7	24	20	40	27	0.886	-0.075	4.682	0.01	0.007	0	43	39.6	71	134	125	0	34	33
2014	7	24	20	50	27	0.906	-0.079	4.682	0.01	0.007	0	43	39.6	73.5	133	124	0	33	32
2014	7	24	21	0	27	0.919	-0.092	4.682	0.013	0.01	0	42.1	38.3	66.7	132	123	0	34	34
2014	7	24	21	10	27	0.919	-0.095	4.682	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	24	21	20	27	0.883	-0.066	4.682	0.01	0.007	0	42.1	39.1	73.5	133	124	0	35	33
2014	7	24	21	30	27	0.879	-0.085	4.682	0.01	0.007	0	41.3	39.1	74.8	131	123	0	35	32
2014	7	24	21	40	27	0.922	-0.069	4.682	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	24	21	50	27	0.932	-0.105	4.682	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	24	22	0	27	0.919	-0.102	4.682	0.013	0.01	0	41.7	38.3	74.8	131	121	0	34	32
2014	7	24	22	10	27	0.856	-0.085	4.682	0.01	0.007	0	41.3	38.3	75.3	131	122	0	35	33
2014	7	24	22	20	27	0.86	-0.072	4.682	0.01	0.007	0	42.6	38.7	73.1	133	123	0	34	33
2014	7	24	22	30	27	0.889	-0.098	4.682	0.013	0.01	0	42.1	38.7	72.2	132	123	0	34	33
2014	7	24	22	40	27	0.883	-0.066	4.682	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	24	22	50	27	0.899	-0.072	4.682	0.01	0.007	0	41.7	37.8	74.4	131	121	0	34	33
2014	7	24	23	0	27	0.886	-0.039	4.682	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	24	23	10	27	0.869	-0.062	4.682	0.01	0.007	0	42.6	38.7	74.8	132	123	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	23	20	27	0.902	-0.079	4.682	0.01	0.007	0	41.7	38.3	73.5	131	122	0	34	33
2014	7	24	23	30	27	0.906	-0.069	4.682	0.01	0.007	0	41.7	37.8	74	131	121	0	34	33
2014	7	24	23	40	27	0.909	-0.082	4.682	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33
2014	7	24	23	50	27	0.899	-0.079	4.682	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	25	0	0	27	0.886	-0.095	4.682	0.01	0.007	0	42.6	39.1	74.4	133	124	0	34	33
2014	7	25	0	10	27	0.909	-0.066	4.682	0.01	0.007	0	42.6	39.1	74	133	124	0	34	33
2014	7	25	0	20	27	0.892	-0.089	4.682	0.01	0.007	0	41.7	38.7	73.5	132	123	0	35	33
2014	7	25	0	30	27	0.873	-0.052	4.682	0.01	0.007	0	42.6	39.6	74.4	133	124	0	34	32
2014	7	25	0	40	27	0.892	-0.062	4.682	0.01	0.007	0	42.6	38.7	74.4	133	123	0	34	33
2014	7	25	0	50	27	0.879	-0.079	4.682	0.013	0.01	0	43	39.6	74.4	134	125	0	34	33
2014	7	25	1	0	27	0.912	-0.062	4.682	0.01	0.007	0	43.4	39.6	74.4	135	125	0	34	33
2014	7	25	1	10	27	0.892	-0.082	4.682	0.01	0.007	0	43	39.1	74.4	134	125	0	34	34
2014	7	25	1	20	27	0.899	-0.092	4.682	0.01	0.007	0	43.4	40.4	74	135	126	0	34	32
2014	7	25	1	30	27	0.889	-0.069	4.682	0.01	0.007	0	42.1	39.1	74	133	124	0	35	33
2014	7	25	1	40	27	0.906	-0.095	4.682	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	25	1	50	27	0.902	-0.079	4.682	0.01	0.007	0	43	39.6	73.1	134	124	0	34	32
2014	7	25	2	0	27	0.896	-0.085	4.682	0.01	0.007	0	43	39.6	74	134	125	0	34	33
2014	7	25	2	10	27	0.889	-0.069	4.685	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	25	2	20	27	0.899	-0.072	4.685	0.01	0.007	0	42.1	39.1	73.5	133	124	0	35	33
2014	7	25	2	30	27	0.883	-0.082	4.685	0.01	0.007	0	42.6	39.6	73.5	134	125	0	35	33
2014	7	25	2	40	27	0.879	-0.069	4.685	0.016	0.013	0	42.6	39.1	73.1	134	125	0	35	34
2014	7	25	2	50	27	0.915	-0.059	4.685	0.016	0.013	0	43	39.6	72.7	134	125	0	34	33
2014	7	25	3	0	27	0.883	-0.059	4.685	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	25	3	10	27	0.883	-0.075	4.685	0.013	0.01	0	43.4	39.6	72.2	135	125	0	34	33
2014	7	25	3	20	27	0.889	-0.036	4.685	0.013	0.01	0	43.4	40	72.2	135	126	0	34	33
2014	7	25	3	30	27	0.886	-0.066	4.685	0.01	0.007	0	43.4	40	72.2	135	126	0	34	33
2014	7	25	3	40	27	0.906	-0.052	4.685	0.013	0.01	0	43.4	39.6	72.2	135	125	0	34	33
2014	7	25	3	50	27	0.889	-0.069	4.685	0.01	0.007	0	42.6	39.6	72.7	134	125	0	35	33
2014	7	25	4	0	27	0.915	-0.069	4.685	0.01	0.007	0	42.6	39.1	72.7	134	124	0	35	33
2014	7	25	4	10	27	0.899	-0.059	4.685	0.013	0.01	0	43	40	71.4	134	125	0	34	32
2014	7	25	4	20	27	0.896	-0.043	4.685	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2014	7	25	4	30	27	0.899	-0.079	4.685	0.01	0.007	0	43.4	39.6	71.8	135	126	0	34	34
2014	7	25	4	40	27	0.906	-0.069	4.685	0.013	0.01	0	43	39.6	71.8	135	125	0	35	33
2014	7	25	4	50	27	0.896	-0.062	4.685	0.01	0.007	0	43.4	40.4	70.5	136	127	0	35	33
2014	7	25	5	0	27	0.886	-0.062	4.685	0.01	0.007	0	43.4	40	71.4	135	127	0	34	34
2014	7	25	5	10	27	0.886	-0.072	4.688	0.01	0.007	0	43.9	40.4	70.5	136	127	0	34	33
2014	7	25	5	20	27	0.906	-0.052	4.688	0.01	0.007	0	43.4	40	70.1	135	126	0	34	33
2014	7	25	5	30	27	0.889	-0.062	4.692	0.01	0.007	0	43	39.1	67.9	134	125	0	34	34
2014	7	25	5	40	27	0.889	-0.092	4.692	0.01	0.007	0	44.3	40.4	69.7	138	128	0	35	34
2014	7	25	5	50	27	0.899	-0.079	4.695	0.01	0.007	0	43.9	40	69.7	136	127	0	34	34
2014	7	25	6	0	27	0.896	-0.033	4.698	0.01	0.007	0	43	39.6	70.5	135	126	0	35	34
2014	7	25	6	10	27	0.909	-0.049	4.698	0.01	0.007	0	43	39.1	70.5	134	124	0	34	33
2014	7	25	6	20	27	0.886	-0.056	4.698	0.01	0.007	0	41.7	38.7	70.5	132	123	0	35	33
2014	7	25	6	30	27	0.912	-0.089	4.698	0.01	0.007	0	42.1	38.7	71	132	123	0	34	33
2014	7	25	6	40	27	0.922	-0.092	4.701	0.01	0.007	0	42.6	38.7	71.4	133	123	0	34	33
2014	7	25	6	50	27	0.896	-0.082	4.701	0.01	0.007	0	41.7	38.7	71.8	132	123	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	7	0	27	0.906	-0.059	4.701	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	25	7	10	27	0.863	-0.072	4.698	0.01	0.007	0	41.7	38.3	71.4	131	122	0	34	33
2014	7	25	7	20	27	0.879	-0.066	4.698	0.01	0.007	0	41.7	38.3	72.2	131	122	0	34	33
2014	7	25	7	30	27	0.892	-0.062	4.698	0.01	0.007	0	41.3	38.3	71.4	131	122	0	35	33
2014	7	25	7	40	27	0.892	-0.082	4.698	0.01	0.007	0	41.7	38.7	71.8	132	123	0	35	33
2014	7	25	7	50	27	0.899	-0.102	4.701	0.01	0.007	0	41.7	38.3	71.8	131	122	0	34	33
2014	7	25	8	0	27	0.909	-0.095	4.698	0.01	0.007	0	41.3	38.3	71.8	131	122	0	35	33
2014	7	25	8	10	27	0.886	-0.098	4.698	0.01	0.007	0	41.7	37.8	69.7	131	122	0	34	34
2014	7	25	8	20	27	0.892	-0.072	4.698	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	25	8	30	27	0.919	-0.056	4.698	0.01	0.007	0	41.7	38.7	71.4	131	123	0	34	33
2014	7	25	8	40	27	0.892	-0.095	4.698	0.013	0.01	0	41.3	38.7	70.5	131	123	0	35	33
2014	7	25	8	50	27	0.886	-0.082	4.698	0.01	0.007	0	41.7	38.3	71.8	131	122	0	34	33
2014	7	25	9	0	27	0.886	-0.049	4.698	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	25	9	10	27	0.876	-0.085	4.698	0.01	0.007	0	41.7	38.3	71.4	132	123	0	35	34
2014	7	25	9	20	27	0.896	-0.072	4.695	0.013	0.01	0	42.1	38.7	70.5	132	123	0	34	33
2014	7	25	9	30	27	0.902	-0.072	4.692	0.01	0.007	0	41.7	38.3	71	131	123	0	34	34
2014	7	25	9	40	27	0.932	-0.102	4.692	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	25	9	50	27	0.879	-0.098	4.688	0.01	0.007	0	41.7	37.8	71.4	131	122	0	34	34
2014	7	25	10	0	27	0.906	-0.079	4.688	0.01	0.007	0	41.7	38.3	70.5	131	122	0	34	33
2014	7	25	10	10	27	0.906	-0.102	4.685	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	25	10	20	27	0.912	-0.092	4.685	0.01	0.007	0	41.3	38.7	71.4	131	123	0	35	33
2014	7	25	10	30	27	0.912	-0.102	4.688	0.01	0.007	0	41.7	38.3	71	131	122	0	34	33
2014	7	25	10	41	39	0.889	-0.085	4.685	0.01	0.007	0	41.3	37.8	72.2	131	122	0	35	34
2014	7	25	10	51	39	0.889	-0.125	4.685	0.01	0.007	0	40.9	38.3	71	130	122	0	35	33
2014	7	25	11	1	39	0.896	-0.164	4.685	0.01	0.007	0	40.9	37.8	70.1	129	121	0	34	33
2014	7	25	11	11	39	0.909	-0.131	4.685	0.01	0.007	0	41.7	37.8	70.5	131	122	0	34	34
2014	7	25	11	21	39	0.906	-0.085	4.685	0.01	0.007	0	41.7	38.7	71.8	132	123	0	35	33
2014	7	25	11	31	39	0.896	-0.131	4.688	0.01	0.007	0	41.7	38.7	53.8	131	123	0	34	33
2014	7	25	11	41	39	0.896	-0.079	4.685	0.01	0.007	0	42.1	38.7	52.9	132	123	0	34	33
2014	7	25	11	51	39	0.899	-0.135	4.685	0.01	0.007	0	41.7	38.7	60.6	132	123	0	35	33
2014	7	25	12	1	39	0.853	-0.115	4.682	0.01	0.007	0	43.4	39.6	55	135	125	0	34	33
2014	7	25	12	11	39	0.889	-0.161	4.685	0.01	0.007	0	40.9	37.8	50.3	129	121	0	34	33
2014	7	25	12	21	39	0.889	-0.102	4.682	0.01	0.007	0	42.1	38.7	56.8	132	123	0	34	33
2014	7	25	12	31	39	0.912	-0.102	4.685	0.01	0.007	0	41.3	37.8	55	131	122	0	35	34
2014	7	25	12	41	39	0.876	-0.128	4.685	0.01	0.007	0	42.1	39.1	54.6	133	124	0	35	33
2014	7	25	12	51	39	0.912	-0.121	4.682	0.01	0.007	0	41.3	38.7	64.5	131	123	0	35	33
2014	7	25	13	1	39	0.896	-0.112	4.682	0.01	0.007	0	41.7	38.3	57.2	131	122	0	34	33
2014	7	25	13	14	19	0.928	-0.072	4.682	0.01	0.007	0	41.7	37.8	63.2	131	122	0	34	34
2014	7	25	13	24	19	0.922	-0.079	4.682	0.01	0.007	0	43	40	50.3	134	126	0	34	33
2014	7	25	13	34	19	0.928	-0.131	4.678	0.01	0.007	0	43	39.1	49.9	134	124	0	34	33
2014	7	25	13	44	19	0.889	-0.098	4.682	0.01	0.007	0	41.7	38.3	55.9	131	122	0	34	33
2014	7	25	13	54	19	0.909	-0.112	4.678	0.01	0.007	0	42.6	39.6	55.5	134	125	0	35	33
2014	7	25	14	4	19	0.892	-0.066	4.678	0.01	0.007	0	42.6	39.1	64.9	133	124	0	34	33
2014	7	25	14	14	19	0.873	-0.102	4.682	0.01	0.007	0	42.6	38.7	57.2	133	124	0	34	34
2014	7	25	14	24	19	0.915	-0.082	4.678	0.01	0.007	0	42.6	38.7	62.8	133	124	0	34	34
2014	7	25	14	34	19	0.906	-0.075	4.678	0.01	0.007	0	43	40	58	134	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	14	44	19	0.906	-0.095	4.678	0.01	0.007	0	43.4	40	58	135	126	0	34	33
2014	7	25	14	54	19	0.883	-0.072	4.678	0.01	0.007	0	44.3	40.4	52	137	127	0	34	33
2014	7	25	15	4	19	0.823	-0.112	4.678	0.01	0.007	0	43	40.4	50.3	135	127	0	35	33
2014	7	25	15	14	19	0.876	-0.062	4.675	0.016	0.013	0	53.3	48.6	39.1	157	146	0	33	33
2014	7	25	15	24	19	0.902	-0.098	4.675	0.01	0.007	0	46.4	43	53.3	142	133	0	34	33
2014	7	25	15	34	19	0.886	-0.056	4.672	0.013	0.01	0	43.9	40.9	51.6	137	128	0	35	33
2014	7	25	15	44	19	0.886	-0.066	4.678	0.013	0.01	0	43	39.6	58	134	125	0	34	33
2014	7	25	15	54	19	0.886	-0.075	4.678	0.01	0.007	0	43	39.1	61.5	134	124	0	34	33
2014	7	25	16	4	19	0.86	-0.105	4.678	0.01	0.007	0	42.1	39.1	60.6	133	124	0	35	33
2014	7	25	16	14	19	0.886	-0.033	4.678	0.01	0.007	0	42.6	39.1	60.2	133	124	0	34	33
2014	7	25	16	24	19	0.902	-0.056	4.678	0.01	0.007	0	42.1	38.7	58.9	133	123	0	35	33
2014	7	25	16	34	19	0.892	-0.095	4.675	0.01	0.007	0	42.6	39.1	57.2	133	124	0	34	33
2014	7	25	16	44	19	0.889	-0.092	4.675	0.01	0.007	0	43.4	39.6	55.9	134	125	0	33	33
2014	7	25	16	54	19	0.892	-0.082	4.675	0.01	0.007	0	42.6	39.6	57.6	134	125	0	35	33
2014	7	25	17	4	19	0.909	-0.079	4.675	0.01	0.007	0	43	39.6	57.6	134	125	0	34	33
2014	7	25	17	14	19	0.899	-0.072	4.675	0.01	0.007	0	43	39.1	58.5	134	124	0	34	33
2014	7	25	17	24	19	0.928	-0.075	4.675	0.01	0.007	0	42.6	39.1	58.5	133	124	0	34	33
2014	7	25	17	34	19	0.873	-0.098	4.672	0.01	0.007	0	43	39.1	58.9	134	124	0	34	33
2014	7	25	17	44	19	0.863	-0.069	4.672	0.01	0.007	0	45.6	41.7	57.2	140	130	0	34	33
2014	7	25	17	54	19	0.915	-0.062	4.672	0.01	0.007	0	43	39.1	59.8	134	124	0	34	33
2014	7	25	18	4	19	0.892	-0.095	4.669	0.01	0.007	0	48.6	44.7	50.7	147	137	0	34	33
2014	7	25	18	14	19	0.856	-0.043	4.665	0.01	0.007	0	51.2	47.3	46	153	143	0	34	33
2014	7	25	18	24	19	0.879	-0.079	4.675	0.01	0.007	0	43	39.1	57.2	134	125	0	34	34
2014	7	25	18	34	19	0.879	-0.052	4.672	0.01	0.007	0	44.7	41.3	54.2	138	129	0	34	33
2014	7	25	18	44	19	0.876	-0.049	4.672	0.01	0.007	0	43	39.6	58.9	134	125	0	34	33
2014	7	25	18	54	19	0.919	-0.079	4.669	0.01	0.007	0	49.9	46	45.2	150	140	0	34	33
2014	7	25	19	4	19	0.889	-0.069	4.669	0.01	0.007	0	45.6	41.3	48.2	141	129	0	35	33
2014	7	25	19	14	19	0.873	-0.118	4.675	0.01	0.007	0	42.1	39.1	61.5	133	124	0	35	33
2014	7	25	19	24	19	0.863	-0.079	4.675	0.01	0.007	0	42.1	39.1	66.2	133	124	0	35	33
2014	7	25	19	34	19	0.902	-0.075	4.675	0.01	0.007	0	42.1	38.7	71	133	123	0	35	33
2014	7	25	19	44	19	0.902	-0.085	4.675	0.013	0.01	0	42.1	38.7	65.4	132	123	0	34	33
2014	7	25	19	54	19	0.896	-0.079	4.675	0.013	0.01	0	42.6	39.1	71.8	133	124	0	34	33
2014	7	25	20	4	19	0.876	-0.072	4.675	0.01	0.007	0	43	40	69.7	134	125	0	34	32
2014	7	25	20	14	19	0.886	-0.082	4.675	0.01	0.007	0	42.6	39.1	67.9	133	124	0	34	33
2014	7	25	20	24	19	0.853	-0.079	4.675	0.01	0.007	0	43	39.6	58	134	125	0	34	33
2014	7	25	20	34	19	0.899	-0.072	4.675	0.01	0.007	0	43.4	39.6	67.9	135	125	0	34	33
2014	7	25	20	44	19	0.909	-0.072	4.675	0.01	0.007	0	43	39.6	67.5	135	125	0	35	33
2014	7	25	20	54	19	0.902	-0.069	4.675	0.01	0.007	0	43.4	39.6	67.5	135	125	0	34	33
2014	7	25	21	4	19	0.869	-0.056	4.675	0.013	0.01	0	43	39.1	72.7	134	124	0	34	33
2014	7	25	21	14	19	0.869	-0.079	4.675	0.013	0.01	0	42.6	39.6	74.4	133	124	0	34	32
2014	7	25	21	24	19	0.886	-0.082	4.675	0.01	0.007	0	43	39.1	74.4	134	124	0	34	33
2014	7	25	21	34	19	0.902	-0.062	4.675	0.01	0.007	0	42.6	38.7	74	133	123	0	34	33
2014	7	25	21	44	19	0.856	-0.075	4.675	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	25	21	54	19	0.896	-0.092	4.675	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	25	22	4	19	0.899	-0.089	4.675	0.01	0.007	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	25	22	14	19	0.863	-0.075	4.675	0.013	0.01	0	42.1	38.7	74.8	132	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	22	24	19	0.873	-0.075	4.675	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	25	22	34	19	0.886	-0.092	4.678	0.01	0.007	0	41.7	38.3	74.4	131	122	0	34	33
2014	7	25	22	44	19	0.86	-0.066	4.675	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	25	22	54	19	0.889	-0.092	4.678	0.013	0.01	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	25	23	4	19	0.889	-0.085	4.678	0.01	0.007	0	42.1	38.3	75.7	132	122	0	34	33
2014	7	25	23	14	19	0.919	-0.105	4.675	0.01	0.007	0	41.7	37.8	74.4	131	122	0	34	34
2014	7	25	23	24	19	0.86	-0.066	4.675	0.01	0.007	0	42.6	37.8	73.1	132	122	0	33	34
2014	7	25	23	34	19	0.886	-0.079	4.678	0.01	0.007	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	25	23	44	19	0.873	-0.069	4.678	0.013	0.01	0	41.7	39.1	75.7	132	123	0	35	32
2014	7	25	23	54	19	0.886	-0.085	4.678	0.01	0.007	0	42.1	38.7	74.8	133	123	0	35	33
2014	7	26	0	4	19	0.906	-0.069	4.678	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	26	0	14	19	0.876	-0.089	4.678	0.013	0.01	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	26	0	24	19	0.892	-0.039	4.678	0.01	0.007	0	42.6	38.7	68.8	133	124	0	34	34
2014	7	26	0	34	19	0.922	-0.079	4.675	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	26	0	44	19	0.909	-0.082	4.678	0.013	0.01	0	42.1	38.7	75.3	132	123	0	34	33
2014	7	26	0	54	19	0.879	-0.085	4.678	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33
2014	7	26	1	4	19	0.886	-0.062	4.678	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	26	1	14	19	0.883	-0.112	4.678	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	26	1	24	19	0.912	-0.069	4.678	0.01	0.007	0	43	39.1	75.7	133	124	0	33	33
2014	7	26	1	34	19	0.886	-0.105	4.678	0.01	0.007	0	43	39.1	74.8	134	124	0	34	33
2014	7	26	1	44	19	0.899	-0.092	4.678	0.01	0.007	0	42.6	39.1	75.7	133	124	0	34	33
2014	7	26	1	54	19	0.883	-0.072	4.678	0.01	0.007	0	42.6	38.3	75.3	133	123	0	34	34
2014	7	26	2	4	19	0.892	-0.072	4.678	0.01	0.007	0	42.6	38.7	74.8	133	124	0	34	34
2014	7	26	2	14	19	0.879	-0.079	4.678	0.01	0.007	0	43	39.1	75.7	134	124	0	34	33
2014	7	26	2	24	19	0.883	-0.056	4.678	0.013	0.01	0	43	39.1	74.8	134	124	0	34	33
2014	7	26	2	34	19	0.883	-0.075	4.678	0.01	0.007	0	43	39.6	74.8	134	125	0	34	33
2014	7	26	2	44	19	0.876	-0.098	4.675	0.01	0.007	0	43	39.1	74	134	124	0	34	33
2014	7	26	2	54	19	0.876	-0.056	4.675	0.01	0.007	0	43.4	40	75.3	135	125	0	34	32
2014	7	26	3	4	19	0.896	-0.075	4.678	0.01	0.007	0	43	39.1	74.8	134	124	0	34	33
2014	7	26	3	14	19	0.866	-0.095	4.678	0.01	0.007	0	42.6	39.1	74.8	134	125	0	35	34
2014	7	26	3	24	19	0.886	-0.089	4.678	0.013	0.01	0	43	39.6	75.3	135	125	0	35	33
2014	7	26	3	34	19	0.896	-0.095	4.678	0.01	0.007	0	43.9	40	74.4	136	127	0	34	34
2014	7	26	3	44	19	0.863	-0.079	4.678	0.01	0.007	0	43.4	40	74.8	135	126	0	34	33
2014	7	26	3	54	19	0.869	-0.079	4.678	0.01	0.007	0	43.4	39.6	74.8	135	125	0	34	33
2014	7	26	4	4	19	0.883	-0.075	4.678	0.013	0.01	0	43.4	40	74.8	135	126	0	34	33
2014	7	26	4	14	19	0.902	-0.072	4.675	0.01	0.007	0	43	39.6	74.8	135	125	0	35	33
2014	7	26	4	24	19	0.879	-0.079	4.675	0.01	0.007	0	43.9	40	74	136	126	0	34	33
2014	7	26	4	34	19	0.909	-0.095	4.678	0.013	0.01	0	43.4	40	74.8	136	126	0	35	33
2014	7	26	4	44	19	0.912	-0.075	4.675	0.01	0.007	0	43.4	40.4	73.1	136	127	0	35	33
2014	7	26	4	54	19	0.886	-0.072	4.675	0.01	0.007	0	43.9	40	67.1	136	126	0	34	33
2014	7	26	5	4	19	0.879	-0.072	4.675	0.013	0.01	0	43.9	40.4	74	136	127	0	34	33
2014	7	26	5	14	19	0.879	-0.089	4.675	0.013	0.01	0	44.3	40.4	74	137	127	0	34	33
2014	7	26	5	24	19	0.886	-0.089	4.678	0.01	0.007	0	43.4	40.4	73.5	135	126	0	34	32
2014	7	26	5	34	19	0.879	-0.079	4.678	0.01	0.007	0	44.3	40.9	73.5	137	128	0	34	33
2014	7	26	5	44	19	0.892	-0.095	4.675	0.01	0.007	0	43.9	40.4	73.5	136	127	0	34	33
2014	7	26	5	54	19	0.899	-0.079	4.678	0.01	0.007	0	43	39.1	73.5	135	125	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	6	4	19	0.892	-0.062	4.678	0.01	0.007	0	42.6	39.6	73.5	134	125	0	35	33
2014	7	26	6	14	19	0.883	-0.095	4.678	0.01	0.007	0	42.6	39.1	74	133	124	0	34	33
2014	7	26	6	24	19	0.873	-0.062	4.678	0.013	0.01	0	42.1	38.7	74	132	123	0	34	33
2014	7	26	6	34	19	0.876	-0.059	4.678	0.016	0.013	0	42.6	38.7	73.5	133	123	0	34	33
2014	7	26	6	44	19	0.892	-0.095	4.678	0.013	0.01	0	42.6	38.7	74	133	123	0	34	33
2014	7	26	6	54	19	0.892	-0.075	4.678	0.01	0.007	0	41.7	38.3	73.5	131	122	0	34	33
2014	7	26	7	4	19	0.853	-0.062	4.678	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	26	7	14	19	0.876	-0.092	4.678	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	26	7	24	19	0.879	-0.052	4.675	0.013	0.01	0	41.3	37.8	74.4	131	122	0	35	34
2014	7	26	7	34	19	0.892	-0.079	4.675	0.01	0.007	0	41.7	38.3	73.5	131	122	0	34	33
2014	7	26	7	44	19	0.909	-0.089	4.678	0.013	0.01	0	41.3	37.8	73.5	130	122	0	34	34
2014	7	26	7	54	19	0.902	-0.089	4.675	0.013	0.01	0	41.7	37.8	74.4	131	122	0	34	34
2014	7	26	8	4	19	0.922	-0.095	4.675	0.01	0.007	0	41.7	37.8	74	131	122	0	34	34
2014	7	26	8	14	19	0.892	-0.095	4.678	0.01	0.007	0	41.3	38.3	73.5	131	122	0	35	33
2014	7	26	8	24	19	0.892	-0.075	4.678	0.01	0.007	0	41.7	38.3	74.4	131	122	0	34	33
2014	7	26	8	34	19	0.879	-0.052	4.675	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	26	8	44	19	0.915	-0.095	4.675	0.01	0.007	0	41.3	38.7	74.4	130	122	0	34	32
2014	7	26	8	54	19	0.909	-0.075	4.675	0.01	0.007	0	41.3	37.4	74.8	130	121	0	34	34
2014	7	26	9	4	19	0.886	-0.098	4.675	0.01	0.007	0	41.3	37.8	74.8	131	122	0	35	34
2014	7	26	9	14	19	0.899	-0.095	4.675	0.01	0.007	0	41.7	37.8	74.4	131	122	0	34	34
2014	7	26	9	24	19	0.86	-0.079	4.675	0.01	0.007	0	41.3	37.8	74.8	130	121	0	34	33
2014	7	26	9	34	19	0.922	-0.095	4.675	0.01	0.007	0	41.3	37.4	73.5	130	121	0	34	34
2014	7	26	9	44	19	0.899	-0.075	4.675	0.01	0.007	0	41.7	38.3	74.8	131	122	0	34	33
2014	7	26	9	54	19	0.886	-0.105	4.675	0.01	0.007	0	41.3	37.8	71.4	131	122	0	35	34
2014	7	26	10	4	19	0.869	-0.112	4.675	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	26	10	14	19	0.906	-0.151	4.675	0.01	0.007	0	40.9	37.4	74.8	129	120	0	34	33
2014	7	26	10	24	19	0.892	-0.144	4.675	0.01	0.007	0	40.9	37.4	74.4	129	120	0	34	33
2014	7	26	10	34	19	0.909	-0.148	4.675	0.01	0.007	0	40.4	37.4	71.8	129	121	0	35	34
2014	7	26	10	44	19	0.899	-0.157	4.675	0.013	0.01	0	40.4	37.4	74.8	129	120	0	35	33
2014	7	26	10	54	19	0.906	-0.174	4.675	0.013	0.01	0	40.9	37.4	75.3	129	120	0	34	33
2014	7	26	11	4	19	0.909	-0.138	4.675	0.01	0.007	0	40.9	37.8	74.8	129	121	0	34	33
2014	7	26	11	14	19	0.906	-0.141	4.675	0.01	0.007	0	40.4	37.8	74	129	121	0	35	33
2014	7	26	11	24	19	0.909	-0.144	4.672	0.01	0.007	0	41.3	37.4	67.9	130	121	0	34	34
2014	7	26	11	34	19	0.909	-0.148	4.672	0.01	0.007	0	40.9	37.8	67.1	130	121	0	35	33
2014	7	26	11	44	19	0.892	-0.187	4.675	0.01	0.007	0	40.9	37.4	71.8	129	120	0	34	33
2014	7	26	11	54	19	0.896	-0.148	4.672	0.016	0.013	0	40.4	37.8	68.4	129	121	0	35	33
2014	7	26	12	4	19	0.876	-0.131	4.672	0.01	0.007	0	41.7	38.7	57.2	131	123	0	34	33
2014	7	26	12	14	19	0.892	-0.098	4.672	0.01	0.007	0	41.3	37.8	61.1	130	121	0	34	33
2014	7	26	12	24	19	0.896	-0.141	4.672	0.01	0.007	0	41.3	37.8	69.2	130	121	0	34	33
2014	7	26	12	34	19	0.892	-0.21	4.672	0.01	0.007	0	40.9	37.4	73.5	129	120	0	34	33
2014	7	26	12	44	19	0.909	-0.157	4.672	0.01	0.007	0	41.3	38.3	71.8	130	121	0	34	32
2014	7	26	12	54	19	0.906	-0.135	4.672	0.01	0.007	0	40.4	37.4	67.1	128	120	0	34	33
2014	7	26	13	4	19	0.896	-0.171	4.672	0.01	0.007	0	40	37.4	63.2	128	120	0	35	33
2014	7	26	13	14	19	0.902	-0.138	4.672	0.01	0.007	0	40.4	37.4	59.3	129	121	0	35	34
2014	7	26	13	24	19	0.892	-0.174	4.669	0.01	0.007	0	40.9	37.8	63.2	129	121	0	34	33
2014	7	26	13	34	19	0.892	-0.171	4.669	0.01	0.007	0	40.4	37	60.6	129	120	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	13	44	19	0.906	-0.135	4.669	0.01	0.007	0	40.9	37.8	56.8	129	121	0	34	33
2014	7	26	13	54	19	0.883	-0.184	4.669	0.01	0.007	0	40.4	37.4	64.9	128	120	0	34	33
2014	7	26	14	4	19	0.876	-0.138	4.669	0.01	0.007	0	40.4	37.8	58	129	121	0	35	33
2014	7	26	14	14	19	0.886	-0.18	4.665	0.01	0.007	0	40	37.4	59.3	128	120	0	35	33
2014	7	26	14	24	19	0.863	-0.194	4.665	0.01	0.007	0	41.3	37.4	53.8	130	120	0	34	33
2014	7	26	14	34	19	0.879	-0.131	4.662	0.01	0.007	0	41.3	38.3	47.7	130	121	0	34	32
2014	7	26	14	44	19	0.853	-0.138	4.659	0.01	0.007	0	41.3	37.8	54.2	130	121	0	34	33
2014	7	26	14	54	19	0.843	-0.148	4.665	0.01	0.007	0	41.3	38.3	53.8	130	122	0	34	33
2014	7	26	15	4	19	0.883	-0.148	4.662	0.01	0.007	0	41.7	37.8	52.5	131	121	0	34	33
2014	7	26	15	14	19	0.863	-0.141	4.659	0.01	0.007	0	41.3	38.3	52	130	122	0	34	33
2014	7	26	15	24	19	0.892	-0.164	4.659	0.01	0.007	0	41.3	37.8	55.5	130	121	0	34	33
2014	7	26	15	34	19	0.863	-0.164	4.659	0.013	0.01	0	41.7	38.3	52.9	131	122	0	34	33
2014	7	26	15	44	19	0.869	-0.115	4.656	0.01	0.007	0	40.9	37.4	52.9	129	121	0	34	34
2014	7	26	15	54	19	0.866	-0.151	4.656	0.01	0.007	0	42.6	39.6	52.9	134	125	0	35	33
2014	7	26	16	4	19	0.876	-0.144	4.656	0.01	0.007	0	45.2	41.3	49	139	130	0	34	34
2014	7	26	16	14	19	0.873	-0.108	4.659	0.01	0.007	0	42.6	39.1	50.3	134	124	0	35	33
2014	7	26	16	24	19	0.866	-0.157	4.656	0.01	0.007	0	41.3	38.3	50.7	131	122	0	35	33
2014	7	26	16	34	19	0.879	-0.112	4.659	0.01	0.007	0	40.9	37.8	54.6	129	121	0	34	33
2014	7	26	16	44	19	0.853	-0.128	4.659	0.01	0.007	0	42.1	38.7	52.9	132	123	0	34	33
2014	7	26	16	54	19	0.915	-0.112	4.344	0.013	0.01	0	42.1	38.7	30.5	132	123	0	34	33
2014	7	26	17	4	19	0.892	-0.167	4.659	0.01	0.007	0	43.4	38.7	44.7	135	124	0	34	34
2014	7	26	17	14	19	0.883	-0.118	4.652	0.01	0.007	0	43.9	40.4	46.4	137	127	0	35	33
2014	7	26	17	24	19	0.896	-0.112	4.659	0.01	0.007	0	40.9	37.4	52.9	129	121	0	34	34
2014	7	26	17	34	19	0.896	-0.148	4.656	0.01	0.007	0	41.7	38.7	52.5	131	123	0	34	33
2014	7	26	17	44	19	0.896	-0.135	4.656	0.01	0.007	0	42.6	38.7	52.5	133	123	0	34	33
2014	7	26	17	54	19	0.906	-0.069	4.656	0.01	0.007	0	43.9	40.9	48.6	137	128	0	35	33
2014	7	26	18	4	19	0.886	-0.148	4.656	0.01	0.007	0	41.7	37.8	54.6	131	121	0	34	33
2014	7	26	18	14	19	0.873	-0.112	4.659	0.01	0.007	0	41.3	37.8	52.9	130	121	0	34	33
2014	7	26	18	24	19	0.81	-0.164	4.656	0.013	0.01	0	42.1	37	55.5	132	120	0	34	34
2014	7	26	18	34	19	0.86	-0.138	4.652	0.01	0.007	0	40.4	37	54.6	129	120	0	35	34
2014	7	26	18	44	19	0.876	-0.144	4.652	0.01	0.007	0	41.3	37	48.2	130	119	0	34	33
2014	7	26	18	54	19	0.883	-0.118	4.652	0.01	0.007	0	41.7	37.4	56.3	131	120	0	34	33
2014	7	26	19	4	19	0.896	-0.121	4.656	0.013	0.01	0	40.9	37.8	56.3	130	121	0	35	33
2014	7	26	19	14	19	0.922	-0.118	4.652	0.016	0.013	0	41.3	37.8	52.9	130	121	0	34	33
2014	7	26	19	24	19	0.853	-0.112	4.652	0.01	0.007	0	40.9	37.8	56.8	130	121	0	35	33
2014	7	26	19	34	19	0.869	-0.105	4.652	0.01	0.007	0	40.9	37.8	61.9	129	121	0	34	33
2014	7	26	19	44	19	0.896	-0.079	4.652	0.01	0.007	0	42.1	38.7	69.2	132	123	0	34	33
2014	7	26	19	54	19	0.876	-0.105	4.652	0.01	0.007	0	41.7	38.3	71	132	123	0	35	34
2014	7	26	20	4	19	0.896	-0.095	4.652	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	26	20	14	19	0.896	-0.075	4.652	0.01	0.007	0	42.6	39.1	71	133	124	0	34	33
2014	7	26	20	24	19	0.899	-0.079	4.656	0.013	0.01	0	42.6	39.1	70.1	133	124	0	34	33
2014	7	26	20	34	19	0.86	-0.082	4.652	0.01	0.007	0	43	39.6	61.9	134	125	0	34	33
2014	7	26	20	44	19	0.896	-0.102	4.652	0.01	0.007	0	43.4	40	61.9	135	126	0	34	33
2014	7	26	20	54	19	0.922	-0.085	4.652	0.01	0.007	0	43.4	40.4	68.8	135	126	0	34	32
2014	7	26	21	4	19	0.906	-0.092	4.656	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2014	7	26	21	14	19	0.896	-0.079	4.656	0.01	0.007	0	42.1	39.1	70.1	133	124	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	21	24	19	0.912	-0.062	4.656	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	26	21	34	19	0.869	-0.079	4.659	0.013	0.01	0	42.1	38.7	70.5	132	123	0	34	33
2014	7	26	21	44	19	0.86	-0.105	4.659	0.013	0.01	0	42.1	38.7	71	132	123	0	34	33
2014	7	26	21	54	19	0.883	-0.072	4.659	0.013	0.01	0	41.7	38.3	70.1	131	122	0	34	33
2014	7	26	22	4	19	0.846	-0.092	4.659	0.01	0.007	0	41.7	38.7	70.1	131	123	0	34	33
2014	7	26	22	14	19	0.896	-0.085	4.659	0.01	0.007	0	42.1	38.7	69.7	132	123	0	34	33
2014	7	26	22	24	19	0.866	-0.082	4.662	0.01	0.007	0	42.1	38.7	70.1	132	123	0	34	33
2014	7	26	22	34	19	0.902	-0.079	4.662	0.01	0.007	0	41.7	38.3	70.1	131	122	0	34	33
2014	7	26	22	44	19	0.909	-0.066	4.659	0.01	0.007	0	42.1	38.3	70.5	132	123	0	34	34
2014	7	26	22	54	19	0.883	-0.108	4.662	0.01	0.007	0	42.1	39.1	70.1	132	124	0	34	33
2014	7	26	23	4	19	0.883	-0.062	4.662	0.01	0.007	0	42.1	38.3	71.4	132	123	0	34	34
2014	7	26	23	14	19	0.886	-0.082	4.662	0.013	0.01	0	42.6	38.7	70.5	133	123	0	34	33
2014	7	26	23	24	19	0.909	-0.039	4.662	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	26	23	34	19	0.879	-0.075	4.662	0.013	0.01	0	42.6	39.6	71.4	133	125	0	34	33
2014	7	26	23	44	19	0.902	-0.079	4.662	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	26	23	54	19	0.902	-0.072	4.665	0.01	0.007	0	43	39.1	71	134	124	0	34	33
2014	7	27	0	4	19	0.883	-0.075	4.665	0.01	0.007	0	42.6	39.1	71.8	133	124	0	34	33
2014	7	27	0	14	19	0.866	-0.049	4.665	0.01	0.007	0	42.1	38.7	71.8	132	123	0	34	33
2014	7	27	0	24	19	0.873	-0.092	4.662	0.01	0.007	0	42.6	38.7	68.4	133	124	0	34	34
2014	7	27	0	34	19	0.899	-0.066	4.662	0.01	0.007	0	42.6	38.7	71	133	124	0	34	34
2014	7	27	0	44	19	0.883	-0.092	4.662	0.013	0.01	0	42.6	39.1	71	133	124	0	34	33
2014	7	27	0	54	19	0.889	-0.062	4.662	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	27	1	4	19	0.922	-0.102	4.665	0.01	0.007	0	43	39.6	71.4	134	125	0	34	33
2014	7	27	1	14	19	0.896	-0.079	4.662	0.01	0.007	0	42.6	39.6	65.8	133	125	0	34	33
2014	7	27	1	24	19	0.906	-0.069	4.662	0.01	0.007	0	42.6	39.1	71.4	133	124	0	34	33
2014	7	27	1	34	19	0.866	-0.049	4.662	0.01	0.007	0	42.1	39.1	71	133	124	0	35	33
2014	7	27	1	44	19	0.886	-0.121	4.662	0.01	0.007	0	43	39.6	71	134	125	0	34	33
2014	7	27	1	54	19	0.896	-0.108	4.662	0.01	0.007	0	42.6	39.1	71	134	124	0	35	33
2014	7	27	2	4	19	0.889	-0.075	4.662	0.013	0.01	0	43	39.1	71.4	134	124	0	34	33
2014	7	27	2	14	19	0.899	-0.079	4.662	0.01	0.007	0	43	39.6	71.4	134	125	0	34	33
2014	7	27	2	24	19	0.899	-0.069	4.665	0.01	0.007	0	43	39.6	71	134	125	0	34	33
2014	7	27	2	34	19	0.873	-0.085	4.662	0.013	0.01	0	42.6	39.1	72.2	133	124	0	34	33
2014	7	27	2	44	19	0.863	-0.095	4.665	0.01	0.007	0	42.6	39.1	71.8	133	124	0	34	33
2014	7	27	2	54	19	0.909	-0.098	4.665	0.01	0.007	0	43	39.6	71.8	134	125	0	34	33
2014	7	27	3	4	19	0.896	-0.069	4.665	0.01	0.007	0	43	39.6	71.8	134	125	0	34	33
2014	7	27	3	14	19	0.879	-0.079	4.665	0.01	0.007	0	43	39.6	72.2	134	125	0	34	33
2014	7	27	3	24	19	0.873	-0.069	4.665	0.01	0.007	0	42.6	40	72.2	134	125	0	35	32
2014	7	27	3	34	19	0.869	-0.039	4.665	0.01	0.007	0	42.6	38.7	72.7	133	124	0	34	34
2014	7	27	3	44	19	0.879	-0.072	4.665	0.01	0.007	0	42.6	39.6	71.8	133	125	0	34	33
2014	7	27	3	54	19	0.889	-0.059	4.665	0.01	0.007	0	43	39.6	72.2	134	125	0	34	33
2014	7	27	4	4	19	0.889	-0.059	4.665	0.013	0.01	0	43.4	39.6	72.2	135	125	0	34	33
2014	7	27	4	14	19	0.886	-0.082	4.665	0.01	0.007	0	43	39.6	72.2	134	125	0	34	33
2014	7	27	4	24	19	0.876	-0.079	4.665	0.01	0.007	0	43	39.1	72.2	134	125	0	34	34
2014	7	27	4	34	19	0.883	-0.092	4.665	0.01	0.007	0	43	40	72.7	135	126	0	35	33
2014	7	27	4	44	19	0.883	-0.059	4.665	0.01	0.007	0	43	39.1	72.7	134	125	0	34	34
2014	7	27	4	54	19	0.886	-0.112	4.665	0.01	0.007	0	43	39.6	72.7	134	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	5	4	19	0.876	-0.062	4.665	0.01	0.007	0	43.4	40	71.4	135	126	0	34	33
2014	7	27	5	14	19	0.853	-0.066	4.665	0.01	0.007	0	43.4	39.1	72.2	135	125	0	34	34
2014	7	27	5	24	19	0.892	-0.046	4.665	0.01	0.007	0	43.4	40	71.4	135	126	0	34	33
2014	7	27	5	34	19	0.879	-0.095	4.665	0.01	0.007	0	44.3	40.4	72.7	137	128	0	34	34
2014	7	27	5	44	19	0.909	-0.059	4.665	0.01	0.007	0	43.4	39.6	73.5	135	126	0	34	34
2014	7	27	5	54	19	0.902	-0.082	4.665	0.01	0.007	0	43.4	39.6	73.1	135	125	0	34	33
2014	7	27	6	4	19	0.896	-0.066	4.665	0.01	0.007	0	42.6	39.1	73.1	133	124	0	34	33
2014	7	27	6	14	19	0.906	-0.079	4.665	0.01	0.007	0	42.1	39.1	73.1	133	124	0	35	33
2014	7	27	6	24	19	0.866	-0.069	4.665	0.01	0.007	0	43	39.6	74	134	125	0	34	33
2014	7	27	6	34	19	0.876	-0.075	4.665	0.01	0.007	0	42.6	38.7	73.5	133	124	0	34	34
2014	7	27	6	44	19	0.876	-0.062	4.665	0.016	0.013	0	43.4	40	73.1	135	126	0	34	33
2014	7	27	6	54	19	0.896	-0.046	4.665	0.01	0.007	0	42.6	38.7	73.1	133	123	0	34	33
2014	7	27	7	4	19	0.883	-0.092	4.665	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	27	7	14	19	0.906	-0.075	4.665	0.01	0.007	0	42.1	37.8	73.1	132	122	0	34	34
2014	7	27	7	24	19	0.886	-0.095	4.665	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	27	7	34	19	0.876	-0.059	4.665	0.01	0.007	0	41.3	38.3	74.4	131	122	0	35	33
2014	7	27	7	44	19	0.899	-0.092	4.665	0.01	0.007	0	41.3	37.8	73.1	130	121	0	34	33
2014	7	27	7	54	19	0.86	-0.056	4.665	0.013	0.01	0	41.3	38.3	71	130	122	0	34	33
2014	7	27	8	4	19	0.873	-0.069	4.665	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	27	8	14	19	0.876	-0.046	4.665	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	27	8	24	19	0.886	-0.082	4.665	0.01	0.007	0	41.3	37.4	74	130	121	0	34	34
2014	7	27	8	34	19	0.896	-0.079	4.665	0.01	0.007	0	40.9	37.8	74.4	130	121	0	35	33
2014	7	27	8	44	19	0.863	-0.072	4.665	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	27	8	54	19	0.863	-0.089	4.665	0.01	0.007	0	41.3	37.8	74	130	121	0	34	33
2014	7	27	9	4	19	0.866	-0.085	4.665	0.013	0.01	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	27	9	14	19	0.892	-0.056	4.665	0.013	0.01	0	41.3	37.8	74	130	121	0	34	33
2014	7	27	9	24	19	0.879	-0.089	4.665	0.01	0.007	0	41.3	37.8	73.5	130	122	0	34	34
2014	7	27	9	34	19	0.912	-0.082	4.665	0.01	0.007	0	41.7	38.3	73.1	131	122	0	34	33
2014	7	27	9	44	19	0.866	-0.075	4.665	0.01	0.007	0	41.3	38.3	73.5	131	122	0	35	33
2014	7	27	9	54	19	0.906	-0.085	4.665	0.01	0.007	0	41.7	38.3	72.7	131	122	0	34	33
2014	7	27	10	4	19	0.892	-0.072	4.662	0.01	0.007	0	41.7	38.3	72.7	131	121	0	34	32
2014	7	27	10	14	19	0.879	-0.075	4.662	0.01	0.007	0	41.7	38.7	71.8	130	122	0	33	32
2014	7	27	10	24	19	0.909	-0.112	4.662	0.01	0.007	0	40.9	37.8	71.8	130	122	0	35	34
2014	7	27	10	34	19	0.896	-0.148	4.662	0.01	0.007	0	40.9	37.8	70.5	130	121	0	35	33
2014	7	27	10	44	19	0.896	-0.112	4.662	0.01	0.007	0	41.3	37.4	70.1	130	121	0	34	34
2014	7	27	10	54	19	0.902	-0.164	4.659	0.01	0.007	0	40.9	37.4	71	129	120	0	34	33
2014	7	27	11	4	19	0.879	-0.135	4.659	0.01	0.007	0	40.9	38.3	66.7	130	122	0	35	33
2014	7	27	11	14	19	0.879	-0.144	4.656	0.01	0.007	0	40.9	37.8	67.1	129	121	0	34	33
2014	7	27	11	24	19	0.879	-0.144	4.656	0.016	0.013	0	40.9	37.8	65.8	129	121	0	34	33
2014	7	27	11	34	19	0.873	-0.177	4.652	0.01	0.007	0	40.9	37.4	58	129	120	0	34	33
2014	7	27	11	44	19	0.925	-0.112	4.649	0.013	0.01	0	40.9	37.4	64.5	129	121	0	34	34
2014	7	27	11	54	19	0.919	-0.125	4.649	0.01	0.007	0	40.9	37.8	71.4	129	121	0	34	33
2014	7	27	12	4	19	0.928	-0.108	4.652	0.01	0.007	0	40.9	37.8	52.9	129	121	0	34	33
2014	7	27	12	14	19	0.899	-0.151	4.649	0.01	0.007	0	40.4	37	54.2	129	120	0	35	34
2014	7	27	12	24	19	0.879	-0.197	4.652	0.01	0.007	0	40	37	55	127	119	0	34	33
2014	7	27	12	34	19	0.883	-0.102	4.649	0.013	0.01	0	40.9	37.8	58.5	129	121	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	12	44	19	0.869	-0.148	4.652	0.01	0.007	0	40.4	37	53.3	128	119	0	34	33
2014	7	27	12	54	19	0.846	-0.167	4.649	0.013	0.01	0	40.9	37.4	55	129	120	0	34	33
2014	7	27	13	4	19	0.879	-0.174	4.652	0.01	0.007	0	40.9	37	51.6	129	120	0	34	34
2014	7	27	13	14	19	0.856	-0.135	4.649	0.01	0.007	0	41.3	37.8	51.6	130	121	0	34	33
2014	7	27	13	24	19	0.883	-0.151	4.649	0.01	0.007	0	40.4	37.8	54.6	129	121	0	35	33
2014	7	27	13	34	19	0.869	-0.079	4.646	0.01	0.007	0	45.2	40.4	51.2	139	128	0	34	34
2014	7	27	13	44	19	0.856	-0.062	4.646	0.01	0.007	0	46	42.6	53.8	141	132	0	34	33
2014	7	27	13	54	19	0.886	-0.03	4.646	0.013	0.01	0	45.2	42.1	54.6	140	131	0	35	33
2014	7	27	14	4	19	0.846	-0.085	4.646	0.01	0.007	0	43.9	41.7	58	137	129	0	35	32
2014	7	27	14	14	19	0.896	-0.062	4.646	0.01	0.007	0	43.4	40.4	56.3	136	127	0	35	33
2014	7	27	14	24	19	0.899	-0.082	4.642	0.01	0.007	0	43	39.6	59.3	134	125	0	34	33
2014	7	27	14	34	19	0.899	-0.043	4.646	0.013	0.01	0	42.6	39.6	56.3	133	125	0	34	33
2014	7	27	14	44	19	0.876	-0.072	4.646	0.01	0.007	0	42.1	39.1	58.9	133	124	0	35	33
2014	7	27	14	54	19	0.866	-0.102	4.642	0.01	0.007	0	42.1	39.1	61.1	132	124	0	34	33
2014	7	27	15	4	19	0.902	-0.098	4.642	0.01	0.007	0	41.7	39.1	67.5	131	123	0	34	32
2014	7	27	15	14	19	0.873	-0.079	4.642	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	27	15	24	19	0.902	-0.085	4.642	0.01	0.007	0	42.1	38.7	74.4	132	123	0	34	33
2014	7	27	15	34	19	0.873	-0.085	4.642	0.01	0.007	0	41.7	38.7	70.1	131	123	0	34	33
2014	7	27	15	44	19	0.886	-0.121	4.642	0.01	0.007	0	44.3	41.3	55.9	137	129	0	34	33
2014	7	27	15	54	19	0.886	-0.062	4.639	0.01	0.007	0	45.6	41.7	46.4	140	130	0	34	33
2014	7	27	16	4	19	0.899	-0.089	4.642	0.01	0.007	0	48.2	45.2	52.5	146	138	0	34	33
2014	7	27	16	14	19	0.886	-0.105	4.642	0.01	0.007	0	42.6	39.6	64.1	133	124	0	34	32
2014	7	27	16	24	19	0.876	-0.121	4.642	0.01	0.007	0	42.1	39.1	66.2	132	124	0	34	33
2014	7	27	16	34	19	0.899	-0.098	4.642	0.016	0.013	0	42.1	38.3	73.1	132	123	0	34	34
2014	7	27	16	44	19	0.883	-0.115	4.642	0.01	0.007	0	41.7	38.7	68.8	131	123	0	34	33
2014	7	27	16	54	19	0.886	-0.089	4.642	0.01	0.007	0	42.1	39.6	68.8	133	124	0	35	32
2014	7	27	17	4	19	0.866	-0.112	4.642	0.01	0.007	0	42.1	39.1	64.5	132	124	0	34	33
2014	7	27	17	14	19	0.899	-0.072	4.642	0.01	0.007	0	41.3	38.3	71	130	122	0	34	33
2014	7	27	17	24	19	0.879	-0.112	4.642	0.01	0.007	0	41.3	37.4	68.4	130	121	0	34	34
2014	7	27	17	34	19	0.925	-0.072	4.642	0.01	0.007	0	41.3	38.3	64.5	131	122	0	35	33
2014	7	27	17	44	19	0.886	-0.112	4.639	0.01	0.007	0	42.1	38.7	65.8	132	123	0	34	33
2014	7	27	17	54	19	0.886	-0.115	4.642	0.01	0.007	0	41.7	38.3	64.1	131	122	0	34	33
2014	7	27	18	4	19	0.896	-0.118	4.639	0.01	0.007	0	41.7	38.3	63.6	132	123	0	35	34
2014	7	27	18	14	19	0.889	-0.085	4.642	0.01	0.007	0	41.7	38.7	69.7	132	123	0	35	33
2014	7	27	18	24	19	0.886	-0.102	4.642	0.01	0.007	0	42.1	38.7	67.5	132	123	0	34	33
2014	7	27	18	34	19	0.902	-0.079	4.642	0.01	0.007	0	41.7	38.7	64.9	131	123	0	34	33
2014	7	27	18	44	19	0.863	-0.052	4.639	0.01	0.007	0	42.6	39.6	65.8	133	125	0	34	33
2014	7	27	18	54	19	0.902	-0.089	4.639	0.01	0.007	0	42.6	39.1	55	133	124	0	34	33
2014	7	27	19	4	19	0.876	-0.049	4.642	0.01	0.007	0	43.4	40.4	60.6	135	127	0	34	33
2014	7	27	19	14	19	0.879	-0.075	4.642	0.01	0.007	0	43.4	40	62.4	135	126	0	34	33
2014	7	27	19	24	19	0.853	-0.062	4.639	0.01	0.007	0	43.4	40.4	69.7	135	127	0	34	33
2014	7	27	19	34	19	0.876	-0.049	4.642	0.01	0.007	0	43	39.6	65.8	134	125	0	34	33
2014	7	27	19	44	19	0.856	-0.072	4.642	0.01	0.007	0	43	39.6	69.2	134	125	0	34	33
2014	7	27	19	54	19	0.869	-0.095	4.642	0.01	0.007	0	43	39.6	64.5	134	125	0	34	33
2014	7	27	20	4	19	0.915	-0.118	4.642	0.01	0.007	0	43	40	65.4	134	125	0	34	32
2014	7	27	20	14	19	0.889	-0.102	4.642	0.01	0.007	0	43	40	71	134	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	20	24	19	0.869	-0.075	4.642	0.01	0.007	0	43	39.6	65.4	134	125	0	34	33
2014	7	27	20	34	19	0.899	-0.066	4.642	0.01	0.007	0	43.4	40	54.6	135	126	0	34	33
2014	7	27	20	44	19	0.876	-0.062	4.642	0.01	0.007	0	44.3	40.9	52.5	137	128	0	34	33
2014	7	27	20	54	19	0.873	-0.069	4.642	0.01	0.007	0	44.3	40.9	55	137	128	0	34	33
2014	7	27	21	4	19	0.856	-0.075	4.642	0.01	0.007	0	44.7	41.3	55.5	138	129	0	34	33
2014	7	27	21	14	19	0.883	-0.016	4.646	0.01	0.007	0	44.7	41.7	54.6	139	130	0	35	33
2014	7	27	21	24	19	0.879	-0.059	4.646	0.01	0.007	0	44.3	40.9	56.8	137	128	0	34	33
2014	7	27	21	34	19	0.873	-0.039	4.646	0.01	0.007	0	44.7	40.9	56.3	138	128	0	34	33
2014	7	27	21	44	19	0.879	-0.062	4.646	0.01	0.007	0	43.4	40	58.5	136	126	0	35	33
2014	7	27	21	54	19	0.843	-0.062	4.646	0.01	0.007	0	43.9	40	58	136	126	0	34	33
2014	7	27	22	4	19	0.889	-0.079	4.646	0.01	0.007	0	43	39.6	65.8	134	125	0	34	33
2014	7	27	22	14	19	0.883	-0.079	4.646	0.01	0.007	0	43	39.6	64.5	134	125	0	34	33
2014	7	27	22	24	19	0.86	-0.056	4.646	0.01	0.007	0	43	40	66.2	134	125	0	34	32
2014	7	27	22	34	19	0.846	-0.043	4.646	0.01	0.007	0	43	39.6	69.7	134	125	0	34	33
2014	7	27	22	44	19	0.84	-0.056	4.646	0.01	0.007	0	42.6	38.7	73.1	134	124	0	35	34
2014	7	27	22	54	19	0.906	-0.079	4.646	0.01	0.007	0	43	40	67.5	134	126	0	34	33
2014	7	27	23	4	19	0.899	-0.062	4.646	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	27	23	14	19	0.869	-0.098	4.646	0.01	0.007	0	42.6	39.1	69.2	133	124	0	34	33
2014	7	27	23	24	19	0.86	-0.039	4.646	0.01	0.007	0	43	39.6	68.8	134	125	0	34	33
2014	7	27	23	34	19	0.863	-0.075	4.646	0.01	0.007	0	42.6	39.1	67.1	133	124	0	34	33
2014	7	27	23	44	19	0.906	-0.059	4.646	0.01	0.007	0	42.6	39.1	64.9	133	124	0	34	33
2014	7	27	23	54	19	0.863	-0.062	4.646	0.01	0.007	0	42.6	39.1	71.4	134	124	0	35	33
2014	7	28	0	4	19	0.889	-0.072	4.646	0.01	0.007	0	43.4	40	72.2	135	125	0	34	32
2014	7	28	0	14	19	0.876	-0.056	4.646	0.01	0.007	0	43	39.6	66.2	134	125	0	34	33
2014	7	28	0	24	19	0.873	-0.049	4.649	0.01	0.007	0	42.6	39.1	63.2	133	124	0	34	33
2014	7	28	0	34	19	0.883	-0.033	4.646	0.01	0.007	0	43.4	39.6	63.2	134	126	0	33	34
2014	7	28	0	44	19	0.869	-0.092	4.646	0.01	0.007	0	43	39.6	69.2	134	125	0	34	33
2014	7	28	0	54	19	0.86	-0.062	4.646	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	28	1	4	19	0.866	-0.049	4.646	0.01	0.007	0	42.6	39.1	66.7	133	124	0	34	33
2014	7	28	1	14	19	0.869	-0.062	4.646	0.013	0.01	0	42.6	39.6	66.7	133	125	0	34	33
2014	7	28	1	24	19	0.873	-0.052	4.646	0.01	0.007	0	43	39.1	70.1	134	125	0	34	34
2014	7	28	1	34	19	0.889	-0.079	4.646	0.01	0.007	0	43.4	40	69.2	135	126	0	34	33
2014	7	28	1	44	19	0.879	-0.069	4.646	0.01	0.007	0	43.4	40	66.7	135	126	0	34	33
2014	7	28	1	54	19	0.879	-0.085	4.646	0.01	0.007	0	42.6	39.6	68.8	134	125	0	35	33
2014	7	28	2	4	19	0.889	-0.082	4.649	0.013	0.01	0	43.4	40	61.5	135	126	0	34	33
2014	7	28	2	14	19	0.899	-0.082	4.649	0.013	0.01	0	43	39.6	71	134	125	0	34	33
2014	7	28	2	24	19	0.883	-0.066	4.649	0.01	0.007	0	43.4	39.6	73.5	135	126	0	34	34
2014	7	28	2	34	19	0.886	-0.075	4.649	0.01	0.007	0	43	39.6	73.5	134	125	0	34	33
2014	7	28	2	44	19	0.873	-0.089	4.649	0.01	0.007	0	42.6	39.6	74	133	124	0	34	32
2014	7	28	2	54	19	0.909	-0.062	4.649	0.01	0.007	0	42.6	39.1	74	133	124	0	34	33
2014	7	28	3	4	19	0.866	-0.082	4.649	0.01	0.007	0	43	40	73.5	135	126	0	35	33
2014	7	28	3	14	19	0.889	-0.075	4.649	0.01	0.007	0	43.4	39.6	73.5	135	126	0	34	34
2014	7	28	3	24	19	0.902	-0.059	4.649	0.01	0.007	0	42.1	39.1	73.1	133	124	0	35	33
2014	7	28	3	34	19	0.886	-0.105	4.649	0.01	0.007	0	41.7	39.1	73.5	132	123	0	35	32
2014	7	28	3	44	19	0.873	-0.075	4.649	0.013	0.01	0	42.6	39.1	74	133	124	0	34	33
2014	7	28	3	54	19	0.869	-0.052	4.649	0.01	0.007	0	43.9	39.6	70.5	135	125	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	4	4	19	0.879	-0.075	4.649	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	28	4	14	19	0.889	-0.062	4.649	0.01	0.007	0	43	39.1	73.5	134	125	0	34	34
2014	7	28	4	24	19	0.879	-0.059	4.649	0.01	0.007	0	43	39.6	72.7	134	125	0	34	33
2014	7	28	4	34	19	0.889	-0.079	4.649	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	28	4	44	19	0.853	-0.059	4.649	0.013	0.01	0	43.4	40.4	73.1	136	127	0	35	33
2014	7	28	4	54	19	0.889	-0.075	4.649	0.01	0.007	0	43.4	40	73.1	135	126	0	34	33
2014	7	28	5	4	19	0.896	-0.075	4.649	0.01	0.007	0	43	39.6	73.1	134	125	0	34	33
2014	7	28	5	14	19	0.883	-0.082	4.649	0.01	0.007	0	43.4	40	73.1	135	126	0	34	33
2014	7	28	5	24	19	0.912	-0.062	4.649	0.01	0.007	0	43	39.1	71.4	134	125	0	34	34
2014	7	28	5	34	19	0.886	-0.059	4.652	0.01	0.007	0	43.9	40.4	71.4	136	127	0	34	33
2014	7	28	5	44	19	0.892	-0.046	4.652	0.01	0.007	0	43.4	40	70.1	134	125	0	33	32
2014	7	28	5	54	19	0.902	-0.079	4.652	0.01	0.007	0	43	39.6	71	134	125	0	34	33
2014	7	28	6	4	19	0.896	-0.052	4.656	0.013	0.01	0	42.6	39.1	71.4	133	124	0	34	33
2014	7	28	6	14	19	0.902	-0.085	4.656	0.01	0.007	0	42.1	38.7	71	132	123	0	34	33
2014	7	28	6	24	19	0.876	-0.066	4.656	0.01	0.007	0	42.1	38.7	70.1	132	123	0	34	33
2014	7	28	6	34	19	0.896	-0.095	4.659	0.01	0.007	0	41.7	38.7	70.1	131	123	0	34	33
2014	7	28	6	44	19	0.886	-0.056	4.659	0.01	0.007	0	41.7	38.3	70.5	131	123	0	34	34
2014	7	28	6	54	19	0.896	-0.092	4.662	0.016	0.013	0	41.3	37.8	71	130	121	0	34	33
2014	7	28	7	4	19	0.883	-0.072	4.662	0.01	0.007	0	41.3	37.8	71	130	121	0	34	33
2014	7	28	7	14	19	0.902	-0.095	4.662	0.01	0.007	0	41.3	37.4	71	130	121	0	34	34
2014	7	28	7	24	19	0.869	-0.089	4.665	0.01	0.007	0	40.9	37.8	71.4	129	121	0	34	33
2014	7	28	7	34	19	0.879	-0.098	4.665	0.01	0.007	0	41.3	37.8	71.4	130	121	0	34	33
2014	7	28	7	44	19	0.896	-0.069	4.665	0.01	0.007	0	41.3	37.4	71.4	130	121	0	34	34
2014	7	28	7	54	19	0.892	-0.079	4.665	0.013	0.01	0	40.9	37.4	71.4	129	120	0	34	33
2014	7	28	8	4	19	0.86	-0.072	4.665	0.013	0.01	0	40.4	37.4	71.8	129	120	0	35	33
2014	7	28	8	14	19	0.866	-0.095	4.665	0.01	0.007	0	41.3	37.8	71	130	121	0	34	33
2014	7	28	8	24	19	0.886	-0.062	4.665	0.01	0.007	0	40.9	37.8	70.5	129	121	0	34	33
2014	7	28	8	34	19	0.886	-0.062	4.665	0.01	0.007	0	40.9	37.4	70.5	129	120	0	34	33
2014	7	28	8	44	19	0.899	-0.125	4.665	0.013	0.01	0	40.4	37.4	71	128	120	0	34	33
2014	7	28	8	54	19	0.909	-0.121	4.662	0.013	0.01	0	40.4	37.4	71.4	128	120	0	34	33
2014	7	28	9	4	19	0.906	-0.125	4.662	0.013	0.01	0	40.4	37.4	67.5	128	120	0	34	33
2014	7	28	9	14	19	0.902	-0.141	4.662	0.01	0.007	0	40	37.4	63.2	128	120	0	35	33
2014	7	28	9	24	19	0.886	-0.128	4.659	0.013	0.01	0	40.4	37.4	60.6	128	120	0	34	33
2014	7	28	9	34	19	0.909	-0.089	4.659	0.013	0.01	0	40.4	37	58.9	128	119	0	34	33
2014	7	28	9	44	19	0.899	-0.112	4.659	0.01	0.007	0	40	37.4	59.8	128	120	0	35	33
2014	7	28	9	54	19	0.906	-0.151	4.659	0.01	0.007	0	40.9	37.4	60.6	128	120	0	33	33
2014	7	28	10	4	19	0.932	-0.148	4.659	0.01	0.007	0	40.9	37	59.8	129	120	0	34	34
2014	7	28	10	14	19	0.892	-0.072	4.659	0.01	0.007	0	40.9	37.4	58.5	129	121	0	34	34
2014	7	28	10	24	19	0.906	-0.102	4.656	0.01	0.007	0	40.9	37.8	59.3	129	121	0	34	33
2014	7	28	10	34	19	0.902	-0.121	4.659	0.01	0.007	0	40.9	37.8	57.2	129	121	0	34	33
2014	7	28	10	44	19	0.902	-0.095	4.656	0.01	0.007	0	40.4	37	60.2	129	120	0	35	34
2014	7	28	10	54	19	0.912	-0.125	4.656	0.01	0.007	0	40.9	37.8	58.5	129	121	0	34	33
2014	7	28	11	4	19	0.876	-0.128	4.656	0.01	0.007	0	40.4	37.8	56.8	128	120	0	34	32
2014	7	28	11	14	19	0.889	-0.144	4.659	0.01	0.007	0	40.9	37.4	55.9	129	120	0	34	33
2014	7	28	11	24	19	0.892	-0.154	4.656	0.01	0.007	0	40.9	37.8	57.2	129	121	0	34	33
2014	7	28	11	34	19	0.892	-0.164	4.656	0.013	0.01	0	40	37.4	56.3	128	120	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	11	44	19	0.902	-0.121	4.656	0.01	0.007	0	40.9	37.8	56.3	129	121	0	34	33
2014	7	28	11	54	19	0.909	-0.105	4.659	0.01	0.007	0	41.3	37.8	55	129	120	0	33	32
2014	7	28	12	4	19	0.906	-0.082	4.659	0.01	0.007	0	40.4	37.4	54.6	128	120	0	34	33
2014	7	28	12	14	19	0.869	-0.128	4.659	0.01	0.007	0	40.9	37.8	54.6	129	121	0	34	33
2014	7	28	12	24	19	0.876	-0.121	4.659	0.01	0.007	0	40.9	37.8	52.5	129	121	0	34	33
2014	7	28	12	34	19	0.869	-0.128	4.659	0.01	0.007	0	40.9	37.8	53.8	129	121	0	34	33
2014	7	28	12	44	19	0.892	-0.112	4.656	0.01	0.007	0	40.4	37.4	55	128	120	0	34	33
2014	7	28	12	54	19	0.879	-0.118	4.652	0.01	0.007	0	40.9	37.8	61.9	129	121	0	34	33
2014	7	28	13	4	19	0.883	-0.148	4.656	0.01	0.007	0	40.9	37.4	53.3	129	120	0	34	33
2014	7	28	13	14	19	0.856	-0.184	4.656	0.01	0.007	0	40	37	53.8	128	120	0	35	34
2014	7	28	13	24	19	0.879	-0.118	4.656	0.01	0.007	0	40	37.4	54.2	128	120	0	35	33
2014	7	28	13	34	19	0.889	-0.108	4.652	0.01	0.007	0	41.3	37.4	61.9	129	120	0	33	33
2014	7	28	13	44	19	0.886	-0.112	4.652	0.013	0.01	0	40.9	37.4	55	129	120	0	34	33
2014	7	28	13	54	19	0.886	-0.135	4.652	0.01	0.007	0	40.4	37.4	59.3	128	120	0	34	33
2014	7	28	14	4	19	0.892	-0.138	4.649	0.01	0.007	0	40.4	37	62.4	128	119	0	34	33
2014	7	28	14	14	19	0.915	-0.082	4.652	0.01	0.007	0	40.9	37.4	60.2	128	120	0	33	33
2014	7	28	14	24	19	0.902	-0.115	4.652	0.01	0.007	0	40.9	37.4	64.5	129	120	0	34	33
2014	7	28	14	34	19	0.899	-0.138	4.652	0.01	0.007	0	40.9	37.4	60.6	129	120	0	34	33
2014	7	28	14	44	19	0.902	-0.112	4.652	0.01	0.007	0	40	37	61.5	128	119	0	35	33
2014	7	28	14	54	19	0.86	-0.154	4.652	0.01	0.007	0	40	36.5	73.5	127	118	0	34	33
2014	7	28	15	4	19	0.902	-0.095	4.652	0.01	0.007	0	40	37	74	127	119	0	34	33
2014	7	28	15	14	19	0.909	-0.079	4.656	0.01	0.007	0	40.4	37.8	53.8	129	120	0	35	32
2014	7	28	15	24	19	0.889	-0.056	4.652	0.01	0.007	0	41.3	37.8	55.9	130	121	0	34	33
2014	7	28	15	34	19	0.896	-0.062	4.652	0.01	0.007	0	41.7	38.3	56.3	131	122	0	34	33
2014	7	28	15	44	19	0.873	-0.079	4.652	0.013	0.01	0	44.7	41.3	60.2	138	129	0	34	33
2014	7	28	15	54	19	0.942	-0.066	4.652	0.01	0.007	0	40.9	37.8	56.8	129	121	0	34	33
2014	7	28	16	4	19	0.873	-0.075	4.652	0.01	0.007	0	42.1	38.7	59.3	132	123	0	34	33
2014	7	28	16	14	19	0.876	-0.049	4.656	0.01	0.007	0	41.3	37.8	55.5	130	121	0	34	33
2014	7	28	16	24	19	0.876	-0.046	4.652	0.01	0.007	0	42.1	38.3	60.2	132	122	0	34	33
2014	7	28	16	34	19	0.886	-0.059	4.656	0.01	0.007	0	42.1	38.3	55.5	132	122	0	34	33
2014	7	28	16	44	19	0.883	-0.072	4.656	0.01	0.007	0	43	39.6	54.2	134	125	0	34	33
2014	7	28	16	54	19	0.883	-0.049	4.656	0.01	0.007	0	44.3	40.9	52	137	128	0	34	33
2014	7	28	17	4	19	0.889	-0.082	4.656	0.01	0.007	0	44.7	41.3	52.5	138	129	0	34	33
2014	7	28	17	14	19	0.873	-0.046	4.656	0.01	0.007	0	44.7	41.7	59.3	139	130	0	35	33
2014	7	28	17	24	19	0.84	-0.049	4.656	0.01	0.007	0	44.3	41.7	65.8	137	129	0	34	32
2014	7	28	17	34	19	0.883	-0.049	4.656	0.013	0.01	0	43.9	40.4	67.1	136	127	0	34	33
2014	7	28	17	44	19	0.892	-0.066	4.656	0.01	0.007	0	43.9	40	66.7	135	126	0	33	33
2014	7	28	17	54	19	0.896	-0.079	4.656	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2014	7	28	18	4	19	0.899	-0.072	4.656	0.013	0.01	0	42.1	39.6	63.6	132	124	0	34	32
2014	7	28	18	14	19	0.902	-0.049	4.659	0.01	0.007	0	42.1	38.7	58.9	132	123	0	34	33
2014	7	28	18	24	19	0.889	-0.066	4.659	0.01	0.007	0	41.7	38.7	59.3	131	123	0	34	33
2014	7	28	18	34	19	0.915	-0.072	4.659	0.01	0.007	0	41.7	39.1	62.8	131	123	0	34	32
2014	7	28	18	44	19	0.889	-0.092	4.656	0.01	0.007	0	41.7	38.7	63.6	131	123	0	34	33
2014	7	28	18	54	19	0.899	-0.056	4.656	0.01	0.007	0	41.7	38.7	67.1	131	123	0	34	33
2014	7	28	19	4	19	0.889	-0.052	4.659	0.01	0.007	0	41.7	38.7	66.2	131	123	0	34	33
2014	7	28	19	14	19	0.873	-0.069	4.659	0.01	0.007	0	41.7	38.7	66.7	131	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	19	24	19	0.873	-0.066	4.659	0.01	0.007	0	41.7	38.7	67.9	132	123	0	35	33
2014	7	28	19	34	19	0.879	-0.085	4.659	0.01	0.007	0	41.7	38.7	67.1	131	123	0	34	33
2014	7	28	19	44	19	0.866	-0.066	4.659	0.01	0.007	0	42.6	39.1	62.4	133	124	0	34	33
2014	7	28	19	54	19	0.869	-0.043	4.662	0.01	0.007	0	42.1	39.6	62.8	133	124	0	35	32
2014	7	28	20	4	19	0.879	-0.098	4.665	0.01	0.007	0	41.7	38.7	58.9	132	123	0	35	33
2014	7	28	20	14	19	0.896	-0.046	4.665	0.01	0.007	0	42.6	39.6	54.6	133	125	0	34	33
2014	7	28	20	24	19	0.883	-0.062	4.669	0.01	0.007	0	43.4	40.4	53.8	135	127	0	34	33
2014	7	28	20	34	19	0.876	-0.039	4.669	0.01	0.007	0	44.3	40.9	55.5	137	128	0	34	33
2014	7	28	20	44	19	0.896	-0.102	4.669	0.01	0.007	0	44.3	40.9	57.6	137	128	0	34	33
2014	7	28	20	54	19	0.886	-0.075	4.669	0.01	0.007	0	44.7	41.3	55.9	138	129	0	34	33
2014	7	28	21	4	19	0.889	-0.059	4.672	0.01	0.007	0	43.9	40.4	59.3	136	127	0	34	33
2014	7	28	21	14	19	0.896	-0.062	4.672	0.01	0.007	0	44.3	40.9	64.9	136	128	0	33	33
2014	7	28	21	24	19	0.902	-0.052	4.672	0.01	0.007	0	43	40	64.9	135	126	0	35	33
2014	7	28	21	34	19	0.899	-0.082	4.672	0.01	0.007	0	42.1	39.1	67.1	133	124	0	35	33
2014	7	28	21	44	19	0.925	-0.105	4.672	0.01	0.007	0	41.7	38.7	66.2	131	123	0	34	33
2014	7	28	21	54	19	0.906	-0.085	4.672	0.01	0.007	0	41.7	38.3	67.5	131	122	0	34	33
2014	7	28	22	4	19	0.886	-0.049	4.672	0.01	0.007	0	42.1	38.7	66.7	132	123	0	34	33
2014	7	28	22	14	19	0.876	-0.095	4.672	0.01	0.007	0	41.3	38.3	67.9	131	122	0	35	33
2014	7	28	22	24	19	0.899	-0.066	4.672	0.01	0.007	0	41.3	37.8	68.8	130	121	0	34	33
2014	7	28	22	34	19	0.892	-0.079	4.672	0.01	0.007	0	41.3	37.4	69.2	130	121	0	34	34
2014	7	28	22	44	19	0.863	-0.075	4.672	0.01	0.007	0	41.3	37.8	68.8	130	121	0	34	33
2014	7	28	22	54	19	0.922	-0.082	4.672	0.01	0.007	0	41.3	37.8	70.1	130	121	0	34	33
2014	7	28	23	4	19	0.899	-0.095	4.672	0.01	0.007	0	40.9	37.4	70.1	129	120	0	34	33
2014	7	28	23	14	19	0.889	-0.056	4.675	0.01	0.007	0	41.3	37.8	70.5	130	122	0	34	34
2014	7	28	23	24	19	0.876	-0.079	4.675	0.01	0.007	0	41.7	37.8	71	130	121	0	33	33
2014	7	28	23	34	19	0.876	-0.089	4.675	0.01	0.007	0	40.4	37.8	71	129	120	0	35	32
2014	7	28	23	44	19	0.902	-0.085	4.675	0.01	0.007	0	40.9	37.4	71.4	129	120	0	34	33
2014	7	28	23	54	19	0.876	-0.089	4.675	0.01	0.007	0	40.9	37.8	71.8	129	121	0	34	33
2014	7	29	0	4	19	0.879	-0.052	4.675	0.01	0.007	0	41.7	38.3	71.4	131	122	0	34	33
2014	7	29	0	14	19	0.876	-0.089	4.675	0.013	0.01	0	41.3	37.8	72.2	130	121	0	34	33
2014	7	29	0	24	19	0.889	-0.089	4.675	0.013	0.01	0	41.3	37.8	71.8	130	121	0	34	33
2014	7	29	0	34	19	0.889	-0.066	4.675	0.013	0.01	0	42.1	37.8	73.1	131	122	0	33	34
2014	7	29	0	44	19	0.876	-0.049	4.675	0.01	0.007	0	41.7	38.7	73.1	131	122	0	34	32
2014	7	29	0	54	19	0.886	-0.062	4.675	0.01	0.007	0	40.9	37.4	72.2	128	120	0	33	33
2014	7	29	1	4	19	0.889	-0.066	4.675	0.01	0.007	0	40.9	38.3	73.1	129	121	0	34	32
2014	7	29	1	14	19	0.879	-0.062	4.675	0.013	0.01	0	40.9	37.8	72.7	130	121	0	35	33
2014	7	29	1	24	19	0.879	-0.043	4.675	0.01	0.007	0	40.4	38.3	73.5	129	121	0	35	32
2014	7	29	1	34	19	0.873	-0.033	4.675	0.01	0.007	0	41.3	37.8	74	131	122	0	35	34
2014	7	29	1	44	19	0.879	-0.043	4.675	0.013	0.01	0	41.3	38.3	74.8	130	122	0	34	33
2014	7	29	1	54	19	0.866	-0.082	4.675	0.01	0.007	0	40.9	37.8	73.5	130	121	0	35	33
2014	7	29	2	4	19	0.866	-0.082	4.675	0.013	0.01	0	41.3	38.7	74.4	130	122	0	34	32
2014	7	29	2	14	19	0.883	-0.062	4.675	0.01	0.007	0	41.3	38.3	69.7	130	122	0	34	33
2014	7	29	2	24	19	0.873	-0.092	4.675	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	29	2	34	19	0.909	-0.072	4.675	0.013	0.01	0	41.3	37.8	74.4	130	121	0	34	33
2014	7	29	2	44	19	0.879	-0.075	4.675	0.01	0.007	0	41.3	38.3	73.1	130	121	0	34	32
2014	7	29	2	54	19	0.876	-0.098	4.675	0.013	0.01	0	41.3	37.4	71.4	130	121	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	3	4	19	0.883	-0.066	4.675	0.01	0.007	0	42.1	38.7	61.9	132	123	0	34	33
2014	7	29	3	14	19	0.892	-0.046	4.678	0.01	0.007	0	41.7	38.7	55.9	131	123	0	34	33
2014	7	29	3	24	19	0.909	-0.095	4.675	0.01	0.007	0	42.6	38.7	55.5	133	124	0	34	34
2014	7	29	3	34	19	0.869	-0.059	4.678	0.01	0.007	0	42.1	38.7	57.2	132	123	0	34	33
2014	7	29	3	44	19	0.892	-0.056	4.675	0.01	0.007	0	41.7	38.3	55.5	131	122	0	34	33
2014	7	29	3	54	19	0.892	-0.066	4.675	0.01	0.007	0	42.1	38.7	57.2	132	123	0	34	33
2014	7	29	4	4	19	0.896	-0.059	4.675	0.01	0.007	0	42.1	39.1	55	133	124	0	35	33
2014	7	29	4	14	19	0.879	-0.062	4.678	0.01	0.007	0	43.9	40	55.9	135	126	0	33	33
2014	7	29	4	24	19	0.866	-0.062	4.675	0.01	0.007	0	42.6	39.6	69.2	134	125	0	35	33
2014	7	29	4	34	19	0.886	-0.007	4.675	0.01	0.007	0	43	39.1	71	134	125	0	34	34
2014	7	29	4	44	19	0.883	-0.095	4.678	0.01	0.007	0	41.7	39.1	71	132	124	0	35	33
2014	7	29	4	54	19	0.892	-0.072	4.678	0.01	0.007	0	42.6	39.1	69.7	133	124	0	34	33
2014	7	29	5	4	19	0.886	-0.036	4.678	0.01	0.007	0	42.6	39.1	73.1	133	124	0	34	33
2014	7	29	5	14	19	0.876	-0.072	4.678	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	29	5	24	19	0.879	-0.075	4.678	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	29	5	34	19	0.899	-0.105	4.678	0.01	0.007	0	42.1	38.7	71	132	123	0	34	33
2014	7	29	5	44	19	0.902	-0.069	4.678	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2014	7	29	5	54	19	0.876	-0.079	4.678	0.01	0.007	0	42.1	39.1	74.4	132	124	0	34	33
2014	7	29	6	4	19	0.889	-0.075	4.678	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	29	6	14	19	0.889	-0.085	4.678	0.01	0.007	0	41.3	38.3	75.3	130	122	0	34	33
2014	7	29	6	24	19	0.873	-0.108	4.678	0.01	0.007	0	41.7	38.7	74.8	131	123	0	34	33
2014	7	29	6	34	19	0.869	-0.052	4.678	0.01	0.007	0	42.1	39.6	74	132	124	0	34	32
2014	7	29	6	44	19	0.909	-0.039	4.678	0.01	0.007	0	41.7	38.7	73.5	132	123	0	35	33
2014	7	29	6	54	19	0.886	-0.098	4.678	0.013	0.01	0	41.3	38.3	75.3	130	122	0	34	33
2014	7	29	7	4	19	0.902	-0.062	4.678	0.01	0.007	0	40.9	37.4	74.8	129	120	0	34	33
2014	7	29	7	14	19	0.879	-0.075	4.678	0.01	0.007	0	40.4	37.4	74.8	128	120	0	34	33
2014	7	29	7	24	19	0.869	-0.03	4.678	0.01	0.007	0	40.9	37.4	73.5	129	121	0	34	34
2014	7	29	7	34	19	0.883	-0.03	4.678	0.01	0.007	0	40.9	38.3	75.3	129	121	0	34	32
2014	7	29	7	44	19	0.899	-0.095	4.678	0.01	0.007	0	40.4	37.4	75.3	128	120	0	34	33
2014	7	29	7	54	19	0.899	-0.066	4.678	0.01	0.007	0	40.4	37.8	70.5	129	121	0	35	33
2014	7	29	8	4	19	0.863	-0.069	4.678	0.01	0.007	0	41.3	37.8	70.5	130	122	0	34	34
2014	7	29	8	14	19	0.886	-0.036	4.678	0.01	0.007	0	41.3	38.3	71	130	122	0	34	33
2014	7	29	8	24	19	0.869	-0.059	4.678	0.01	0.007	0	41.3	38.3	70.5	130	122	0	34	33
2014	7	29	8	34	19	0.892	-0.082	4.678	0.01	0.007	0	41.7	37.8	66.7	130	122	0	33	34
2014	7	29	8	44	19	0.856	-0.062	4.678	0.01	0.007	0	41.3	37.8	66.7	130	122	0	34	34
2014	7	29	8	54	19	0.883	-0.082	4.678	0.01	0.007	0	41.7	38.7	61.5	131	123	0	34	33
2014	7	29	9	4	19	0.876	-0.066	4.678	0.01	0.007	0	40.9	38.7	67.9	130	123	0	35	33
2014	7	29	9	14	19	0.889	-0.062	4.675	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2014	7	29	9	24	19	0.886	-0.079	4.678	0.01	0.007	0	40.9	37.8	60.2	129	121	0	34	33
2014	7	29	9	34	19	0.866	-0.079	4.675	0.01	0.007	0	41.3	38.3	63.2	130	122	0	34	33
2014	7	29	9	44	19	0.873	-0.039	4.678	0.01	0.007	0	40.9	38.3	61.9	129	122	0	34	33
2014	7	29	9	54	19	0.879	-0.052	4.678	0.01	0.007	0	41.3	38.3	58	130	122	0	34	33
2014	7	29	10	4	19	0.883	-0.066	4.675	0.01	0.007	0	40.9	37.8	62.4	129	121	0	34	33
2014	7	29	10	14	19	0.876	-0.023	4.675	0.01	0.007	0	40.9	37.8	67.1	129	121	0	34	33
2014	7	29	10	24	19	0.856	-0.039	4.675	0.01	0.007	0	40.9	37.8	64.9	129	121	0	34	33
2014	7	29	10	34	19	0.886	-0.059	4.675	0.01	0.007	0	41.3	38.3	58	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	10	44	19	0.886	-0.049	4.675	0.01	0.007	0	41.3	38.3	58	130	122	0	34	33
2014	7	29	10	54	19	0.902	-0.069	4.675	0.01	0.007	0	40.9	37.8	59.8	129	121	0	34	33
2014	7	29	11	4	19	0.919	-0.049	4.675	0.01	0.007	0	41.7	38.3	56.8	130	122	0	33	33
2014	7	29	11	14	19	0.892	-0.089	4.675	0.01	0.007	0	41.3	37.8	60.2	130	122	0	34	34
2014	7	29	11	24	19	0.896	-0.085	4.675	0.01	0.007	0	41.3	38.3	62.8	130	122	0	34	33
2014	7	29	11	34	19	0.889	-0.079	4.672	0.01	0.007	0	41.3	38.3	61.9	130	122	0	34	33
2014	7	29	11	44	19	0.889	-0.075	4.672	0.01	0.007	0	40.4	38.3	61.5	129	122	0	35	33
2014	7	29	11	54	19	0.886	-0.085	4.672	0.01	0.007	0	41.3	38.3	63.2	130	122	0	34	33
2014	7	29	12	4	19	0.912	-0.085	4.672	0.01	0.007	0	40.9	37.8	66.7	129	121	0	34	33
2014	7	29	12	14	19	0.928	-0.079	4.672	0.01	0.007	0	41.3	38.7	67.1	130	122	0	34	32
2014	7	29	12	24	19	0.876	-0.082	4.672	0.01	0.007	0	40.9	38.7	68.4	129	122	0	34	32
2014	7	29	12	34	19	0.889	-0.059	4.662	0.01	0.007	0	46.4	42.6	43.9	142	131	0	34	32
2014	7	29	12	44	19	0.899	-0.072	4.665	0.01	0.007	0	43	39.1	47.7	134	124	0	34	33
2014	7	29	12	54	19	0.915	-0.062	4.662	0.01	0.007	0	44.3	41.3	48.2	138	129	0	35	33
2014	7	29	13	4	19	0.909	-0.066	4.662	0.01	0.007	0	42.6	39.1	48.2	133	124	0	34	33
2014	7	29	13	14	19	0.906	-0.072	4.662	0.01	0.007	0	41.7	38.7	61.1	131	123	0	34	33
2014	7	29	13	24	19	0.906	-0.089	4.665	0.01	0.007	0	42.6	39.1	46	133	125	0	34	34
2014	7	29	13	34	19	0.892	-0.115	4.659	0.01	0.007	0	42.1	38.7	45.6	132	122	0	34	32
2014	7	29	13	44	19	0.886	-0.079	4.659	0.013	0.01	0	40.9	37.4	68.4	129	121	0	34	34
2014	7	29	13	54	19	0.863	-0.079	4.659	0.01	0.007	0	41.3	37.8	64.1	130	122	0	34	34
2014	7	29	14	4	19	0.889	-0.079	4.659	0.01	0.007	0	40.9	38.7	72.2	129	122	0	34	32
2014	7	29	14	14	19	0.892	-0.085	4.659	0.01	0.007	0	40.9	38.3	71.4	129	122	0	34	33
2014	7	29	14	24	19	0.892	-0.056	4.659	0.01	0.007	0	41.3	38.7	63.2	130	122	0	34	32
2014	7	29	14	34	19	0.896	-0.095	4.659	0.013	0.01	0	41.3	38.3	61.1	130	122	0	34	33
2014	7	29	14	44	19	0.892	-0.082	4.659	0.013	0.01	0	40.9	37.8	63.2	129	121	0	34	33
2014	7	29	14	54	19	0.902	-0.075	4.656	0.01	0.007	0	40.9	37.8	67.1	129	121	0	34	33
2014	7	29	15	4	19	0.886	-0.085	4.656	0.01	0.007	0	40.4	38.3	66.7	129	122	0	35	33
2014	7	29	15	14	19	0.896	-0.062	4.656	0.01	0.007	0	41.3	38.3	68.8	130	122	0	34	33
2014	7	29	15	24	19	0.889	-0.082	4.656	0.01	0.007	0	41.3	39.1	61.9	130	123	0	34	32
2014	7	29	15	34	19	0.915	-0.066	4.656	0.01	0.007	0	41.7	38.3	69.2	130	122	0	33	33
2014	7	29	15	44	19	0.869	-0.066	4.656	0.01	0.007	0	41.3	37.8	66.2	130	122	0	34	34
2014	7	29	15	54	19	0.86	-0.082	4.656	0.01	0.007	0	41.3	38.3	69.7	130	122	0	34	33
2014	7	29	16	4	19	0.876	-0.036	4.656	0.01	0.007	0	41.7	38.7	67.5	131	123	0	34	33
2014	7	29	16	14	19	0.889	-0.066	4.659	0.01	0.007	0	42.1	38.3	57.2	131	122	0	33	33
2014	7	29	16	24	19	0.879	-0.056	4.656	0.01	0.007	0	41.7	38.3	67.5	130	122	0	33	33
2014	7	29	16	34	19	0.892	-0.112	4.656	0.01	0.007	0	41.3	37.8	61.5	130	121	0	34	33
2014	7	29	16	44	19	0.906	-0.089	4.656	0.01	0.007	0	40.9	38.3	59.8	129	121	0	34	32
2014	7	29	16	54	19	0.906	-0.098	4.652	0.01	0.007	0	40.9	37.8	67.9	129	121	0	34	33
2014	7	29	17	4	19	0.889	-0.066	4.656	0.01	0.007	0	41.3	38.3	57.2	130	122	0	34	33
2014	7	29	17	14	19	0.896	-0.056	4.652	0.01	0.007	0	41.3	38.3	69.7	130	122	0	34	33
2014	7	29	17	24	19	0.892	-0.085	4.652	0.01	0.007	0	40.9	37.8	73.5	129	121	0	34	33
2014	7	29	17	34	19	0.873	-0.049	4.652	0.01	0.007	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	29	17	44	19	0.902	-0.075	4.652	0.01	0.007	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	29	17	54	19	0.896	-0.092	4.652	0.01	0.007	0	40.4	37.4	71	128	120	0	34	33
2014	7	29	18	4	19	0.876	-0.079	4.652	0.01	0.007	0	40.9	37.8	68.8	129	121	0	34	33
2014	7	29	18	14	19	0.896	-0.052	4.652	0.01	0.007	0	41.7	38.7	73.1	130	122	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	18	24	19	0.856	-0.089	4.652	0.013	0.01	0	41.3	38.3	71.4	130	122	0	34	33
2014	7	29	18	34	19	0.879	-0.079	4.652	0.01	0.007	0	40.9	37.8	72.2	129	121	0	34	33
2014	7	29	18	44	19	0.876	-0.069	4.652	0.01	0.007	0	41.3	37.8	74	129	121	0	33	33
2014	7	29	18	54	19	0.879	-0.069	4.652	0.01	0.007	0	40.4	37.8	73.5	129	121	0	35	33
2014	7	29	19	4	19	0.879	-0.062	4.652	0.01	0.007	0	40.9	37.8	73.5	129	121	0	34	33
2014	7	29	19	14	19	0.899	-0.079	4.652	0.01	0.007	0	41.7	37.8	74	130	121	0	33	33
2014	7	29	19	24	19	0.886	-0.075	4.652	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	29	19	34	19	0.886	-0.069	4.652	0.01	0.007	0	41.3	38.3	71.8	130	122	0	34	33
2014	7	29	19	44	19	0.876	-0.069	4.652	0.01	0.007	0	41.7	39.1	73.1	131	123	0	34	32
2014	7	29	19	54	19	0.896	-0.062	4.652	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	29	20	4	19	0.886	-0.098	4.652	0.01	0.007	0	41.7	38.7	73.1	131	123	0	34	33
2014	7	29	20	14	19	0.919	-0.079	4.652	0.01	0.007	0	41.7	38.7	61.1	131	123	0	34	33
2014	7	29	20	24	19	0.883	-0.066	4.652	0.01	0.007	0	42.1	38.7	71	131	123	0	33	33
2014	7	29	20	34	19	0.879	-0.049	4.652	0.01	0.007	0	42.1	38.7	62.8	132	123	0	34	33
2014	7	29	20	44	19	0.879	-0.082	4.656	0.01	0.007	0	42.1	38.7	62.8	132	123	0	34	33
2014	7	29	20	54	19	0.902	-0.108	4.652	0.01	0.007	0	42.1	38.7	68.8	132	123	0	34	33
2014	7	29	21	4	19	0.906	-0.089	4.652	0.01	0.007	0	41.7	38.3	68.8	131	122	0	34	33
2014	7	29	21	14	19	0.889	-0.072	4.652	0.013	0.01	0	41.3	38.3	64.5	130	122	0	34	33
2014	7	29	21	24	19	0.866	-0.036	4.652	0.01	0.007	0	42.1	38.3	72.2	131	122	0	33	33
2014	7	29	21	34	19	0.866	-0.049	4.652	0.01	0.007	0	41.3	38.3	73.1	131	122	0	35	33
2014	7	29	21	44	19	0.866	-0.079	4.652	0.01	0.007	0	40.9	37.8	73.1	129	121	0	34	33
2014	7	29	21	54	19	0.856	-0.039	4.656	0.01	0.007	0	41.3	37.8	74	130	121	0	34	33
2014	7	29	22	4	19	0.876	-0.052	4.652	0.013	0.01	0	40.9	37.4	74.4	129	120	0	34	33
2014	7	29	22	14	19	0.889	-0.056	4.652	0.013	0.01	0	40.4	37	73.5	128	119	0	34	33
2014	7	29	22	24	19	0.876	-0.085	4.656	0.01	0.007	0	40.9	37.8	70.5	129	121	0	34	33
2014	7	29	22	34	19	0.879	-0.066	4.656	0.01	0.007	0	40.9	37.8	74	129	121	0	34	33
2014	7	29	22	44	19	0.889	-0.049	4.656	0.01	0.007	0	40.9	37.8	74.4	129	120	0	34	32
2014	7	29	22	54	19	0.876	-0.069	4.652	0.01	0.007	0	41.3	37.4	73.1	129	121	0	33	34
2014	7	29	23	4	19	0.892	-0.066	4.656	0.01	0.007	0	41.3	38.7	74.4	130	122	0	34	32
2014	7	29	23	14	19	0.853	-0.052	4.652	0.01	0.007	0	41.3	37.8	72.2	130	121	0	34	33
2014	7	29	23	24	19	0.909	-0.059	4.652	0.01	0.007	0	41.3	37.8	74.4	130	121	0	34	33
2014	7	29	23	34	19	0.873	-0.079	4.656	0.013	0.01	0	41.3	38.7	74	130	122	0	34	32
2014	7	29	23	44	19	0.915	-0.062	4.652	0.01	0.007	0	41.3	37.8	74.4	130	121	0	34	33
2014	7	29	23	54	19	0.856	-0.062	4.652	0.01	0.007	0	41.3	38.7	73.1	131	122	0	35	32
2014	7	30	0	4	19	0.892	-0.075	4.656	0.01	0.007	0	41.3	37.8	74	130	121	0	34	33
2014	7	30	0	14	19	0.902	-0.066	4.656	0.013	0.01	0	41.3	38.3	72.2	130	121	0	34	32
2014	7	30	0	24	19	0.886	-0.043	4.656	0.013	0.01	0	41.3	38.3	73.1	130	122	0	34	33
2014	7	30	0	34	19	0.873	-0.023	4.656	0.01	0.007	0	40.9	38.3	73.1	129	121	0	34	32
2014	7	30	0	44	19	0.883	-0.082	4.656	0.01	0.007	0	40.9	37.4	73.1	129	120	0	34	33
2014	7	30	0	54	19	0.928	-0.098	4.652	0.01	0.007	0	40.9	38.3	71.4	129	121	0	34	32
2014	7	30	1	4	19	0.889	-0.072	4.652	0.01	0.007	0	41.3	37.8	71.8	130	121	0	34	33
2014	7	30	1	14	19	0.879	-0.079	4.656	0.013	0.01	0	40.9	38.3	73.1	129	122	0	34	33
2014	7	30	1	24	19	0.902	-0.075	4.656	0.01	0.007	0	40.9	38.3	74	129	121	0	34	32
2014	7	30	1	34	19	0.899	-0.039	4.656	0.01	0.007	0	41.3	38.3	74.4	130	122	0	34	33
2014	7	30	1	44	19	0.879	-0.066	4.656	0.013	0.01	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	30	1	54	19	0.883	-0.098	4.656	0.01	0.007	0	40.9	37.4	74.8	128	120	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	2	4	19	0.886	-0.085	4.656	0.01	0.007	0	40.9	37.8	74	129	121	0	34	33
2014	7	30	2	14	19	0.909	-0.079	4.656	0.01	0.007	0	40.9	37.8	74.4	129	121	0	34	33
2014	7	30	2	24	19	0.846	-0.059	4.652	0.01	0.007	0	40.9	37.4	72.2	129	120	0	34	33
2014	7	30	2	34	19	0.906	-0.095	4.652	0.01	0.007	0	41.7	37.8	74.4	130	122	0	33	34
2014	7	30	2	44	19	0.896	-0.082	4.652	0.01	0.007	0	40.9	37.8	72.2	129	121	0	34	33
2014	7	30	2	54	19	0.86	-0.059	4.652	0.01	0.007	0	41.3	38.7	67.9	130	123	0	34	33
2014	7	30	3	4	19	0.889	-0.056	4.652	0.01	0.007	0	41.3	38.7	73.1	131	123	0	35	33
2014	7	30	3	14	19	0.902	-0.085	4.652	0.01	0.007	0	41.7	38.3	72.2	131	122	0	34	33
2014	7	30	3	24	19	0.899	-0.082	4.652	0.01	0.007	0	42.1	38.7	65.4	132	123	0	34	33
2014	7	30	3	34	19	0.892	-0.075	4.656	0.01	0.007	0	42.1	39.1	58.9	132	124	0	34	33
2014	7	30	3	44	19	0.863	-0.069	4.652	0.01	0.007	0	42.6	39.1	71.4	133	124	0	34	33
2014	7	30	3	54	19	0.902	-0.102	4.652	0.01	0.007	0	41.7	38.7	71.4	131	123	0	34	33
2014	7	30	4	4	19	0.869	-0.085	4.652	0.01	0.007	0	42.1	39.6	70.5	132	124	0	34	32
2014	7	30	4	14	19	0.876	-0.079	4.652	0.01	0.007	0	41.7	38.7	73.1	132	124	0	35	34
2014	7	30	4	24	19	0.886	-0.059	4.652	0.01	0.007	0	42.1	39.1	73.5	132	124	0	34	33
2014	7	30	4	34	19	0.863	-0.066	4.652	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	30	4	44	19	0.922	-0.095	4.652	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	30	4	54	19	0.879	-0.069	4.652	0.01	0.007	0	41.7	39.1	74	131	123	0	34	32
2014	7	30	5	4	19	0.906	-0.089	4.652	0.01	0.007	0	42.1	39.1	74	132	124	0	34	33
2014	7	30	5	14	19	0.909	-0.079	4.652	0.01	0.007	0	41.7	39.1	72.7	131	124	0	34	33
2014	7	30	5	24	19	0.889	-0.089	4.652	0.01	0.007	0	41.7	39.1	73.5	131	124	0	34	33
2014	7	30	5	34	19	0.876	-0.098	4.652	0.01	0.007	0	41.7	38.7	73.5	131	123	0	34	33
2014	7	30	5	44	19	0.886	-0.059	4.652	0.01	0.007	0	44.3	41.7	73.1	137	129	0	34	32
2014	7	30	5	54	19	0.899	-0.089	4.652	0.01	0.007	0	41.7	38.7	74	131	123	0	34	33
2014	7	30	6	4	19	0.892	-0.079	4.652	0.013	0.01	0	40.9	37.8	73.5	129	121	0	34	33
2014	7	30	6	14	19	0.896	-0.066	4.652	0.01	0.007	0	41.3	38.3	73.1	130	122	0	34	33
2014	7	30	6	24	19	0.856	-0.072	4.652	0.01	0.007	0	41.3	38.3	74	130	122	0	34	33
2014	7	30	6	34	19	0.892	-0.082	4.652	0.01	0.007	0	40.9	37.8	73.5	129	121	0	34	33
2014	7	30	6	44	19	0.876	-0.082	4.652	0.01	0.007	0	40.4	38.3	73.5	129	122	0	35	33
2014	7	30	6	54	19	0.886	-0.085	4.652	0.01	0.007	0	40.4	37.8	73.5	128	120	0	34	32
2014	7	30	7	4	19	0.889	-0.072	4.652	0.013	0.01	0	38.3	36.5	57.6	124	118	0	35	33
2014	7	30	7	14	19	0.909	-0.089	4.652	0.01	0.007	0	40.9	37	74	129	119	0	34	33
2014	7	30	7	24	19	0.876	-0.069	4.652	0.01	0.007	0	40.4	36.5	74	128	118	0	34	33
2014	7	30	7	34	19	0.899	-0.082	4.652	0.01	0.007	0	40.4	36.5	73.1	128	118	0	34	33
2014	7	30	7	44	19	0.866	-0.049	4.652	0.01	0.007	0	40.9	37.4	73.1	129	120	0	34	33
2014	7	30	7	54	19	0.889	-0.072	4.652	0.01	0.007	0	41.3	37.4	73.1	130	120	0	34	33
2014	7	30	8	4	19	0.892	-0.089	4.652	0.013	0.01	0	41.3	37	74.4	130	120	0	34	34
2014	7	30	8	14	19	0.886	-0.052	4.652	0.01	0.007	0	41.3	37	72.2	130	120	0	34	34
2014	7	30	8	24	19	0.896	-0.092	4.649	0.01	0.007	0	41.3	37	69.7	129	119	0	33	33
2014	7	30	8	34	19	0.889	-0.079	4.652	0.01	0.007	0	41.3	37.4	56.3	130	120	0	34	33
2014	7	30	8	44	19	0.912	-0.069	4.652	0.01	0.007	0	40.9	37	60.6	129	119	0	34	33
2014	7	30	8	54	19	0.883	-0.066	4.652	0.01	0.007	0	40.9	37	56.8	129	119	0	34	33
2014	7	30	9	4	19	0.906	-0.072	4.652	0.01	0.007	0	40.9	37.4	57.2	130	120	0	35	33
2014	7	30	9	14	19	0.889	-0.039	4.652	0.01	0.007	0	41.3	37.4	57.6	130	119	0	34	32
2014	7	30	9	24	19	0.892	-0.033	4.649	0.01	0.007	0	41.3	37.4	60.6	130	120	0	34	33
2014	7	30	9	34	19	0.909	-0.056	4.649	0.01	0.007	0	40.9	37	58.5	129	119	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	9	44	19	0.892	-0.056	4.649	0.01	0.007	0	41.3	37.4	64.9	130	120	0	34	33
2014	7	30	9	54	19	0.912	-0.069	4.649	0.01	0.007	0	41.7	37.8	58	131	121	0	34	33
2014	7	30	10	4	19	0.892	-0.052	4.649	0.01	0.007	0	41.7	38.3	58.5	131	122	0	34	33
2014	7	30	10	14	19	0.879	-0.066	4.649	0.01	0.007	0	42.1	38.7	58	132	123	0	34	33
2014	7	30	10	24	19	0.902	-0.059	4.649	0.01	0.007	0	42.1	37.8	58.5	132	122	0	34	34
2014	7	30	10	34	19	0.896	-0.052	4.649	0.01	0.007	0	41.7	38.3	58.9	131	122	0	34	33
2014	7	30	10	44	19	0.906	-0.082	4.646	0.01	0.007	0	41.3	38.3	63.2	131	122	0	35	33
2014	7	30	10	54	19	0.876	-0.062	4.646	0.01	0.007	0	42.1	38.7	64.5	132	122	0	34	32
2014	7	30	11	4	19	0.879	-0.059	4.646	0.01	0.007	0	41.7	38.3	59.3	131	122	0	34	33
2014	7	30	11	14	19	0.892	-0.079	4.646	0.01	0.007	0	42.1	37.8	65.8	131	121	0	33	33
2014	7	30	11	24	19	0.892	-0.062	4.646	0.01	0.007	0	41.7	37.8	64.1	131	121	0	34	33
2014	7	30	11	34	19	0.899	-0.082	4.646	0.01	0.007	0	42.1	38.3	63.6	132	121	0	34	32
2014	7	30	11	44	19	0.915	-0.039	4.646	0.01	0.007	0	41.7	37.8	55.9	131	121	0	34	33
2014	7	30	11	54	19	0.899	-0.039	4.646	0.01	0.007	0	42.1	38.3	55.5	131	121	0	33	32
2014	7	30	12	4	19	0.922	-0.046	4.642	0.01	0.007	0	43	40	53.8	134	125	0	34	32
2014	7	30	12	14	19	0.866	-0.013	4.642	0.01	0.007	0	44.3	40.4	53.3	137	127	0	34	33
2014	7	30	12	24	19	0.876	-0.052	4.639	0.01	0.007	0	45.6	41.7	55	140	130	0	34	33
2014	7	30	12	34	19	0.85	-0.066	4.639	0.01	0.007	0	46	41.7	53.8	141	130	0	34	33
2014	7	30	12	44	19	0.873	-0.092	4.642	0.013	0.01	0	47.3	43.9	52	145	135	0	35	33
2014	7	30	12	54	19	0.909	-0.03	4.646	0.01	0.007	0	51.6	47.3	50.7	154	143	0	34	33
2014	7	30	13	4	19	0.896	-0.052	4.646	0.01	0.007	0	51.2	46.4	47.3	153	142	0	34	34
2014	7	30	13	14	19	0.856	-0.023	4.646	0.01	0.007	0	49.9	46	49	150	140	0	34	33
2014	7	30	13	24	19	0.922	-0.062	4.642	0.01	0.007	0	48.6	44.7	50.3	147	137	0	34	33
2014	7	30	13	34	19	0.869	-0.036	4.646	0.01	0.007	0	47.7	44.3	52.9	145	135	0	34	32
2014	7	30	13	44	19	0.886	-0.075	4.642	0.01	0.007	0	46.9	43.4	52	144	133	0	35	32
2014	7	30	13	54	19	0.876	-0.049	4.642	0.01	0.007	0	46	42.6	52.9	142	132	0	35	33
2014	7	30	14	4	19	0.886	-0.049	4.642	0.01	0.007	0	46	41.7	52.5	141	130	0	34	33
2014	7	30	14	14	19	0.86	-0.016	4.642	0.01	0.007	0	45.6	41.7	61.5	140	130	0	34	33
2014	7	30	14	24	19	0.856	-0.007	4.642	0.01	0.007	0	45.2	41.3	60.2	139	129	0	34	33
2014	7	30	14	34	19	0.863	-0.059	4.642	0.013	0.01	0	44.7	40.9	60.2	138	128	0	34	33
2014	7	30	14	44	19	0.856	-0.033	4.642	0.01	0.007	0	44.7	40.4	64.5	138	127	0	34	33
2014	7	30	14	54	19	0.84	-0.052	4.642	0.01	0.007	0	44.3	40	61.1	137	126	0	34	33
2014	7	30	15	4	19	0.873	-0.062	4.642	0.01	0.007	0	43.9	40	55.5	136	126	0	34	33
2014	7	30	15	14	19	0.892	-0.039	4.642	0.01	0.007	0	44.7	40.9	59.3	138	128	0	34	33
2014	7	30	15	24	19	0.876	-0.033	4.642	0.01	0.007	0	44.7	40.9	68.8	138	128	0	34	33
2014	7	30	15	34	19	0.889	-0.066	4.642	0.013	0.01	0	44.3	40.4	70.5	137	127	0	34	33
2014	7	30	15	44	19	0.886	-0.036	4.642	0.01	0.007	0	43.9	40.4	54.6	136	126	0	34	32
2014	7	30	15	54	19	0.883	-0.066	4.642	0.01	0.007	0	44.3	40.4	65.8	137	127	0	34	33
2014	7	30	16	4	19	0.892	-0.056	4.642	0.01	0.007	0	43.9	40.4	67.1	136	127	0	34	33
2014	7	30	16	14	19	0.906	-0.092	4.642	0.01	0.007	0	43.4	39.6	61.9	135	125	0	34	33
2014	7	30	16	24	19	0.853	-0.033	4.642	0.01	0.007	0	43.4	39.6	68.8	135	125	0	34	33
2014	7	30	16	34	19	0.896	-0.043	4.642	0.01	0.007	0	43	39.6	63.6	134	125	0	34	33
2014	7	30	16	44	19	0.892	-0.023	4.642	0.01	0.007	0	43	39.6	70.1	134	125	0	34	33
2014	7	30	16	54	19	0.84	-0.082	4.642	0.01	0.007	0	42.1	39.1	71.8	133	124	0	35	33
2014	7	30	17	4	19	0.886	-0.069	4.642	0.01	0.007	0	43	38.7	71.8	133	123	0	33	33
2014	7	30	17	14	19	0.856	-0.03	4.642	0.016	0.013	0	42.6	38.7	68.4	133	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	17	24	19	0.86	-0.052	4.642	0.01	0.007	0	42.1	38.3	71.8	132	122	0	34	33
2014	7	30	17	34	19	0.876	-0.072	4.642	0.01	0.007	0	42.1	38.3	69.2	132	122	0	34	33
2014	7	30	17	44	19	0.883	-0.049	4.642	0.01	0.007	0	42.1	38.3	64.5	132	122	0	34	33
2014	7	30	17	54	19	0.869	-0.059	4.642	0.01	0.007	0	42.1	38.3	73.1	132	122	0	34	33
2014	7	30	18	4	19	0.896	-0.075	4.639	0.01	0.007	0	42.1	38.3	74	132	122	0	34	33
2014	7	30	18	14	19	0.889	-0.082	4.639	0.01	0.007	0	42.6	38.3	74.4	133	123	0	34	34
2014	7	30	18	24	19	0.876	-0.052	4.642	0.01	0.007	0	41.7	38.3	73.5	131	121	0	34	32
2014	7	30	18	34	19	0.879	-0.079	4.639	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	30	18	44	19	0.889	-0.079	4.639	0.01	0.007	0	42.1	38.3	74.4	132	122	0	34	33
2014	7	30	18	54	19	0.883	-0.056	4.639	0.01	0.007	0	42.6	38.7	72.2	132	122	0	33	32
2014	7	30	19	4	19	0.883	-0.082	4.639	0.01	0.007	0	41.7	37.8	73.1	131	121	0	34	33
2014	7	30	19	14	19	0.896	-0.062	4.639	0.01	0.007	0	42.1	38.3	74.8	132	122	0	34	33
2014	7	30	19	24	19	0.879	-0.036	4.639	0.01	0.007	0	41.7	38.3	74.8	132	122	0	35	33
2014	7	30	19	34	19	0.889	-0.046	4.639	0.01	0.007	0	42.6	38.3	74.8	133	122	0	34	33
2014	7	30	19	44	19	0.863	-0.062	4.639	0.01	0.007	0	42.6	38.7	72.2	133	123	0	34	33
2014	7	30	19	54	19	0.86	-0.062	4.639	0.01	0.007	0	43	39.1	74.8	134	124	0	34	33
2014	7	30	20	4	19	0.889	-0.039	4.639	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33
2014	7	30	20	14	19	0.896	-0.043	4.639	0.01	0.007	0	43	39.1	74.4	134	124	0	34	33
2014	7	30	20	24	19	0.889	-0.072	4.639	0.01	0.007	0	43	39.1	74	134	124	0	34	33
2014	7	30	20	34	19	0.883	-0.066	4.639	0.01	0.007	0	43	39.1	74	134	125	0	34	34
2014	7	30	20	44	19	0.909	-0.062	4.639	0.01	0.007	0	43	39.1	74.4	134	124	0	34	33
2014	7	30	20	54	19	0.896	-0.052	4.639	0.01	0.007	0	43	38.7	74.8	134	123	0	34	33
2014	7	30	21	4	19	0.883	-0.066	4.639	0.01	0.007	0	42.6	38.7	74.4	133	123	0	34	33
2014	7	30	21	14	19	0.869	-0.069	4.639	0.016	0.013	0	43	38.7	74	134	124	0	34	34
2014	7	30	21	24	19	0.889	-0.046	4.639	0.01	0.007	0	42.1	38.7	74.8	132	122	0	34	32
2014	7	30	21	34	19	0.883	-0.079	4.639	0.01	0.007	0	41.3	37.8	74.8	131	121	0	35	33
2014	7	30	21	44	19	0.902	-0.049	4.639	0.01	0.007	0	42.1	37.8	74.4	132	121	0	34	33
2014	7	30	21	54	19	0.883	-0.095	4.639	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	30	22	4	19	0.853	-0.033	4.639	0.01	0.007	0	42.1	38.3	71.4	132	122	0	34	33
2014	7	30	22	14	19	0.873	-0.069	4.639	0.01	0.007	0	41.7	38.3	75.3	132	122	0	35	33
2014	7	30	22	24	19	0.889	-0.069	4.639	0.01	0.007	0	41.7	37.8	74.8	131	121	0	34	33
2014	7	30	22	34	19	0.899	-0.072	4.639	0.01	0.007	0	42.1	37.8	74.8	131	121	0	33	33
2014	7	30	22	44	19	0.879	-0.059	4.639	0.01	0.007	0	41.7	37.8	75.3	131	121	0	34	33
2014	7	30	22	54	19	0.886	-0.062	4.636	0.01	0.007	0	42.1	38.3	74.4	132	122	0	34	33
2014	7	30	23	4	19	0.892	-0.066	4.639	0.01	0.007	0	42.1	38.7	75.3	133	123	0	35	33
2014	7	30	23	14	19	0.909	-0.079	4.639	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	30	23	24	19	0.873	-0.069	4.636	0.013	0.01	0	42.1	38.3	74.8	132	122	0	34	33
2014	7	30	23	34	19	0.883	-0.062	4.636	0.01	0.007	0	42.1	38.7	74.4	133	123	0	35	33
2014	7	30	23	44	19	0.899	-0.072	4.636	0.01	0.007	0	42.1	37.8	74.4	131	121	0	33	33
2014	7	30	23	54	19	0.915	-0.079	4.636	0.01	0.007	0	42.1	37.8	74.8	132	121	0	34	33
2014	7	31	0	4	19	0.899	-0.062	4.636	0.01	0.007	0	42.6	38.7	74.8	132	122	0	33	32
2014	7	31	0	14	19	0.853	-0.052	4.636	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	31	0	24	19	0.853	-0.013	4.636	0.01	0.007	0	41.7	38.3	72.7	132	122	0	35	33
2014	7	31	0	34	19	0.896	-0.079	4.636	0.016	0.013	0	42.1	38.7	74.8	132	122	0	34	32
2014	7	31	0	44	19	0.873	-0.059	4.639	0.01	0.007	0	42.6	39.1	75.3	133	124	0	34	33
2014	7	31	0	54	19	0.906	-0.069	4.636	0.01	0.007	0	42.6	38.7	74.8	133	123	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	1	4	19	0.863	-0.069	4.636	0.013	0.01	0	42.6	38.7	75.3	133	123	0	34	33
2014	7	31	1	14	19	0.899	-0.062	4.636	0.01	0.007	0	42.1	38.7	74.4	133	123	0	35	33
2014	7	31	1	24	19	0.919	-0.092	4.636	0.01	0.007	0	42.1	38.3	74.4	132	122	0	34	33
2014	7	31	1	34	19	0.879	-0.036	4.636	0.01	0.007	0	43	39.6	74.4	134	124	0	34	32
2014	7	31	1	44	19	0.869	-0.066	4.636	0.01	0.007	0	43.4	39.6	74.8	135	125	0	34	33
2014	7	31	1	54	19	0.86	-0.066	4.636	0.01	0.007	0	42.6	39.6	74	134	125	0	35	33
2014	7	31	2	4	19	0.886	-0.062	4.636	0.01	0.007	0	43	38.7	74.8	134	123	0	34	33
2014	7	31	2	14	19	0.866	-0.098	4.636	0.01	0.007	0	42.6	38.7	75.3	133	123	0	34	33
2014	7	31	2	24	19	0.902	-0.079	4.636	0.013	0.01	0	43.4	39.6	74.8	135	125	0	34	33
2014	7	31	2	34	19	0.869	-0.062	4.636	0.01	0.007	0	42.1	38.3	75.7	132	122	0	34	33
2014	7	31	2	44	19	0.879	-0.092	4.636	0.013	0.01	0	43	39.6	75.3	134	124	0	34	32
2014	7	31	2	54	19	0.873	-0.092	4.636	0.01	0.007	0	43	38.7	75.7	133	123	0	33	33
2014	7	31	3	4	19	0.873	-0.075	4.636	0.013	0.01	0	43	39.1	74.8	134	124	0	34	33
2014	7	31	3	14	19	0.889	-0.062	4.636	0.01	0.007	0	42.6	39.1	75.3	134	124	0	35	33
2014	7	31	3	24	19	0.853	-0.052	4.636	0.01	0.007	0	43	39.6	75.7	135	125	0	35	33
2014	7	31	3	34	19	0.86	-0.056	4.636	0.01	0.007	0	43.4	39.1	74.8	135	125	0	34	34
2014	7	31	3	44	19	0.899	-0.079	4.636	0.01	0.007	0	43	39.1	75.7	134	124	0	34	33
2014	7	31	3	54	19	0.863	-0.036	4.636	0.013	0.01	0	42.6	39.6	74.4	133	124	0	34	32
2014	7	31	4	4	19	0.899	-0.089	4.636	0.013	0.01	0	42.1	38.7	75.7	132	123	0	34	33
2014	7	31	4	14	19	0.876	-0.089	4.636	0.01	0.007	0	43	39.1	75.3	134	124	0	34	33
2014	7	31	4	24	19	0.883	-0.039	4.636	0.01	0.007	0	43.4	39.6	75.7	135	125	0	34	33
2014	7	31	4	34	19	0.883	-0.049	4.636	0.01	0.007	0	43.4	39.6	75.7	135	125	0	34	33
2014	7	31	4	44	19	0.869	-0.089	4.636	0.013	0.01	0	43.9	39.6	75.3	136	126	0	34	34
2014	7	31	4	54	19	0.85	-0.043	4.636	0.01	0.007	0	43	39.6	75.3	134	125	0	34	33
2014	7	31	5	4	19	0.889	-0.069	4.636	0.01	0.007	0	43	39.6	75.7	134	124	0	34	32
2014	7	31	5	14	19	0.869	-0.066	4.636	0.01	0.007	0	44.3	40.4	75.3	137	127	0	34	33
2014	7	31	5	24	19	0.876	-0.079	4.636	0.013	0.01	0	43.9	39.6	75.3	136	126	0	34	34
2014	7	31	5	34	19	0.892	-0.072	4.636	0.01	0.007	0	43	39.1	75.3	134	125	0	34	34
2014	7	31	5	44	19	0.866	-0.069	4.636	0.01	0.007	0	42.6	38.7	75.3	133	123	0	34	33
2014	7	31	5	54	19	0.869	-0.049	4.636	0.01	0.007	0	43	39.1	75.3	134	124	0	34	33
2014	7	31	6	4	19	0.853	-0.046	4.636	0.016	0.013	0	43	38.7	75.3	134	124	0	34	34
2014	7	31	6	14	19	0.899	-0.056	4.636	0.01	0.007	0	41.7	37.8	75.3	132	122	0	35	34
2014	7	31	6	24	19	0.876	-0.079	4.636	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33
2014	7	31	6	34	19	0.866	-0.085	4.636	0.01	0.007	0	41.7	38.3	76.1	132	122	0	35	33
2014	7	31	6	44	19	0.866	-0.085	4.636	0.01	0.007	0	41.7	37.8	75.3	131	121	0	34	33
2014	7	31	6	54	19	0.869	-0.062	4.636	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	31	7	4	19	0.889	-0.062	4.636	0.013	0.01	0	41.7	37.8	75.3	131	121	0	34	33
2014	7	31	7	14	19	0.889	-0.092	4.636	0.01	0.007	0	41.3	38.3	76.1	130	121	0	34	32
2014	7	31	7	24	19	0.866	-0.069	4.636	0.01	0.007	0	41.7	37.8	76.1	131	121	0	34	33
2014	7	31	7	34	19	0.879	-0.075	4.636	0.01	0.007	0	40.9	37.8	76.1	130	121	0	35	33
2014	7	31	7	44	19	0.899	-0.066	4.636	0.013	0.01	0	41.3	37.8	75.7	130	121	0	34	33
2014	7	31	7	54	19	0.922	-0.069	4.636	0.01	0.007	0	41.7	37.8	75.7	131	121	0	34	33
2014	7	31	8	4	19	0.879	-0.049	4.633	0.01	0.007	0	41.3	37.8	75.7	131	121	0	35	33
2014	7	31	8	14	19	0.896	-0.075	4.633	0.01	0.007	0	41.7	37.8	76.1	131	122	0	34	34
2014	7	31	8	24	19	0.896	-0.085	4.633	0.01	0.007	0	42.1	38.3	75.3	131	122	0	33	33
2014	7	31	8	34	19	0.856	-0.092	4.633	0.01	0.007	0	41.7	37.8	75.7	131	122	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	8	44	19	0.879	-0.092	4.633	0.013	0.01	0	41.7	38.3	75.7	131	122	0	34	33
2014	7	31	8	54	19	0.869	-0.105	4.633	0.01	0.007	0	42.1	38.3	74.8	132	123	0	34	34
2014	7	31	9	4	19	0.869	-0.105	4.633	0.01	0.007	0	41.7	38.3	75.3	131	122	0	34	33
2014	7	31	9	14	19	0.889	-0.118	4.633	0.01	0.007	0	41.7	38.3	74	131	122	0	34	33
2014	7	31	9	24	19	0.892	-0.115	4.633	0.013	0.01	0	41.3	38.3	74	131	122	0	35	33
2014	7	31	9	34	19	0.883	-0.102	4.633	0.01	0.007	0	42.1	38.3	72.7	132	123	0	34	34
2014	7	31	9	44	19	0.873	-0.108	4.633	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	31	9	54	19	0.899	-0.072	4.633	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	31	10	4	19	0.896	-0.115	4.633	0.01	0.007	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	31	10	14	19	0.879	-0.049	4.633	0.013	0.01	0	42.1	38.7	74.8	132	123	0	34	33
2014	7	31	10	24	19	0.869	-0.082	4.633	0.013	0.01	0	42.1	38.3	74	132	123	0	34	34
2014	7	31	10	34	19	0.866	-0.072	4.629	0.01	0.007	0	41.7	38.7	73.5	132	123	0	35	33
2014	7	31	10	44	19	0.876	-0.066	4.629	0.013	0.01	0	41.7	38.7	74.4	132	123	0	35	33
2014	7	31	10	54	19	0.879	-0.108	4.629	0.01	0.007	0	42.1	38.7	72.7	132	123	0	34	33
2014	7	31	11	4	19	0.899	-0.072	4.629	0.01	0.007	0	42.1	38.3	73.5	132	123	0	34	34
2014	7	31	11	14	19	0.896	-0.105	4.629	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	31	11	24	19	0.876	-0.082	4.629	0.01	0.007	0	42.1	38.7	71.4	132	123	0	34	33
2014	7	31	11	34	19	0.899	-0.108	4.629	0.01	0.007	0	42.1	38.7	72.2	132	123	0	34	33
2014	7	31	11	44	19	0.892	-0.121	4.629	0.01	0.007	0	41.7	38.7	72.2	132	123	0	35	33
2014	7	31	11	54	19	0.902	-0.105	4.629	0.01	0.007	0	42.1	39.1	72.7	132	123	0	34	32
2014	7	31	12	4	19	0.902	-0.105	4.626	0.01	0.007	0	41.7	38.7	70.5	131	123	0	34	33
2014	7	31	12	14	19	0.896	-0.095	4.626	0.01	0.007	0	42.1	38.7	71.8	132	123	0	34	33
2014	7	31	12	24	19	0.912	-0.118	4.626	0.01	0.007	0	41.7	37.8	71.8	131	121	0	34	33
2014	7	31	12	34	19	0.892	-0.154	4.623	0.01	0.007	0	40.9	38.3	67.5	130	122	0	35	33
2014	7	31	12	44	19	0.883	-0.177	4.619	0.01	0.007	0	40.9	37.8	70.1	129	121	0	34	33
2014	7	31	12	54	19	0.856	-0.19	4.616	0.01	0.007	0	41.3	38.3	70.5	130	121	0	34	32
2014	7	31	13	4	19	0.902	-0.148	4.616	0.01	0.007	0	41.3	37.8	70.1	130	121	0	34	33
2014	7	31	13	14	19	0.886	-0.154	4.613	0.01	0.007	0	40.9	37.8	72.7	129	121	0	34	33
2014	7	31	13	24	19	0.886	-0.115	4.613	0.01	0.007	0	43	39.6	59.3	134	125	0	34	33
2014	7	31	13	34	19	0.919	-0.121	4.613	0.01	0.007	0	42.6	38.7	64.9	133	124	0	34	34
2014	7	31	13	44	19	0.873	-0.092	4.613	0.01	0.007	0	42.6	40	62.8	134	125	0	35	32
2014	7	31	13	54	19	0.906	-0.184	4.613	0.01	0.007	0	41.7	38.3	70.1	131	122	0	34	33
2014	7	31	14	4	19	0.873	-0.144	4.61	0.01	0.007	0	41.3	37.8	69.7	130	121	0	34	33
2014	7	31	14	14	19	0.876	-0.138	4.613	0.01	0.007	0	41.7	38.3	73.1	131	122	0	34	33
2014	7	31	14	24	19	0.925	-0.089	4.613	0.01	0.007	0	42.1	39.1	72.7	132	124	0	34	33
2014	7	31	14	34	19	0.915	-0.144	4.613	0.01	0.007	0	41.3	38.7	72.7	131	122	0	35	32
2014	7	31	14	44	19	0.886	-0.115	4.61	0.01	0.007	0	41.3	37.8	73.1	131	122	0	35	34
2014	7	31	14	54	19	0.899	-0.108	4.61	0.01	0.007	0	41.7	38.3	73.5	131	122	0	34	33
2014	7	31	15	4	19	0.886	-0.085	4.61	0.01	0.007	0	42.1	38.7	73.1	132	123	0	34	33
2014	7	31	15	14	19	0.876	-0.138	4.61	0.01	0.007	0	41.7	38.3	73.5	131	122	0	34	33
2014	7	31	15	24	19	0.886	-0.098	4.61	0.013	0.01	0	42.1	38.7	73.1	132	122	0	34	32
2014	7	31	15	34	19	0.915	-0.095	4.61	0.013	0.01	0	42.1	38.7	72.2	132	123	0	34	33
2014	7	31	15	44	19	0.906	-0.118	4.61	0.01	0.007	0	41.7	38.7	73.1	131	122	0	34	32
2014	7	31	15	54	19	0.879	-0.085	4.61	0.01	0.007	0	42.1	37.8	73.5	132	122	0	34	34
2014	7	31	16	4	19	0.879	-0.085	4.61	0.01	0.007	0	41.3	37.8	72.7	131	121	0	35	33
2014	7	31	16	14	19	0.873	-0.062	4.61	0.01	0.007	0	41.7	38.3	72.7	131	121	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	16	24	19	0.892	-0.089	4.61	0.01	0.007	0	41.7	37.8	72.7	131	121	0	34	33
2014	7	31	16	34	19	0.899	-0.128	4.61	0.01	0.007	0	41.7	37.8	74	131	121	0	34	33
2014	7	31	16	44	19	0.889	-0.102	4.61	0.013	0.01	0	41.7	38.3	73.1	132	123	0	35	34
2014	7	31	16	54	19	0.886	-0.135	4.61	0.01	0.007	0	40.9	37.8	74	130	121	0	35	33
2014	7	31	17	4	19	0.899	-0.141	4.61	0.01	0.007	0	41.3	37.8	73.5	130	121	0	34	33
2014	7	31	17	14	19	0.886	-0.056	4.61	0.01	0.007	0	41.3	38.3	74	131	122	0	35	33
2014	7	31	17	24	19	0.886	-0.089	4.61	0.01	0.007	0	41.7	37.8	74	131	121	0	34	33
2014	7	31	17	34	19	0.873	-0.075	4.61	0.01	0.007	0	42.6	38.3	73.1	132	122	0	33	33
2014	7	31	17	44	19	0.873	-0.056	4.61	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	31	17	54	19	0.892	-0.082	4.61	0.01	0.007	0	42.1	38.7	73.5	132	122	0	34	32
2014	7	31	18	4	19	0.863	-0.059	4.61	0.01	0.007	0	42.6	38.3	74	132	122	0	33	33
2014	7	31	18	14	19	0.896	-0.075	4.61	0.013	0.01	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	31	18	24	19	0.873	-0.079	4.61	0.01	0.007	0	42.1	38.3	74	132	122	0	34	33
2014	7	31	18	34	19	0.846	-0.052	4.61	0.01	0.007	0	42.6	38.3	74	133	123	0	34	34
2014	7	31	18	44	19	0.863	-0.069	4.61	0.01	0.007	0	42.1	38.7	73.5	132	123	0	34	33
2014	7	31	18	54	19	0.899	-0.062	4.61	0.01	0.007	0	42.1	38.7	74	132	123	0	34	33
2014	7	31	19	4	19	0.889	-0.056	4.61	0.013	0.01	0	42.6	38.7	74.4	133	123	0	34	33
2014	7	31	19	14	19	0.856	-0.056	4.61	0.01	0.007	0	42.1	38.7	73.1	133	123	0	35	33
2014	7	31	19	24	19	0.873	-0.085	4.61	0.01	0.007	0	42.1	38.7	74	133	123	0	35	33
2014	7	31	19	34	19	0.889	-0.066	4.61	0.01	0.007	0	42.6	39.1	73.5	133	124	0	34	33
2014	7	31	19	44	19	0.869	-0.079	4.61	0.01	0.007	0	42.6	38.7	73.5	133	123	0	34	33
2014	7	31	19	54	19	0.886	-0.108	4.61	0.01	0.007	0	43	39.1	73.5	134	124	0	34	33
2014	7	31	20	4	19	0.889	-0.079	4.61	0.013	0.01	0	42.6	39.6	74	134	125	0	35	33
2014	7	31	20	14	19	0.883	-0.095	4.61	0.013	0.01	0	43.4	39.6	73.1	135	125	0	34	33
2014	7	31	20	24	19	0.853	-0.085	4.61	0.01	0.007	0	43.4	39.6	72.7	135	125	0	34	33
2014	7	31	20	34	19	0.886	-0.052	4.61	0.013	0.01	0	43	39.1	72.7	134	125	0	34	34
2014	7	31	20	44	19	0.886	-0.085	4.61	0.01	0.007	0	43.4	39.1	73.1	135	125	0	34	34
2014	7	31	20	54	19	0.863	-0.079	4.613	0.01	0.007	0	43.4	39.6	72.7	135	125	0	34	33
2014	7	31	21	4	19	0.853	-0.069	4.61	0.016	0.013	0	43.4	39.6	72.2	135	125	0	34	33
2014	7	31	21	14	19	0.879	-0.075	4.613	0.01	0.007	0	43	39.1	73.1	134	124	0	34	33
2014	7	31	21	24	19	0.873	-0.079	4.613	0.01	0.007	0	43	39.6	73.1	134	125	0	34	33
2014	7	31	21	34	19	0.889	-0.085	4.613	0.01	0.007	0	42.6	39.1	72.7	133	124	0	34	33
2014	7	31	21	44	19	0.876	-0.046	4.61	0.01	0.007	0	42.6	39.1	72.2	133	124	0	34	33
2014	7	31	21	54	19	0.869	-0.098	4.613	0.01	0.007	0	43	39.1	72.2	134	124	0	34	33
2014	7	31	22	4	19	0.869	-0.085	4.613	0.01	0.007	0	42.6	38.7	72.7	133	124	0	34	34
2014	7	31	22	14	19	0.879	-0.049	4.613	0.01	0.007	0	42.1	38.7	72.7	133	123	0	35	33
2014	7	31	22	24	19	0.892	-0.066	4.613	0.013	0.01	0	43	40	72.2	134	125	0	34	32
2014	7	31	22	34	19	0.876	-0.056	4.61	0.013	0.01	0	42.6	38.7	72.7	133	123	0	34	33
2014	7	31	22	44	19	0.86	-0.056	4.613	0.013	0.01	0	42.1	39.6	72.7	133	124	0	35	32
2014	7	31	22	54	19	0.902	-0.082	4.613	0.01	0.007	0	43	39.1	70.5	134	124	0	34	33
2014	7	31	23	4	19	0.846	-0.082	4.613	0.01	0.007	0	43	39.1	69.2	133	124	0	33	33
2014	7	31	23	14	19	0.873	-0.049	4.613	0.01	0.007	0	42.6	39.1	71.8	134	124	0	35	33
2014	7	31	23	24	19	0.86	-0.03	4.613	0.01	0.007	0	43	39.1	72.2	134	124	0	34	33
2014	7	31	23	34	19	0.886	-0.052	4.613	0.01	0.007	0	42.1	38.7	72.7	132	123	0	34	33
2014	7	31	23	44	19	0.866	-0.049	4.613	0.01	0.007	0	42.6	38.7	72.2	133	123	0	34	33
2014	7	31	23	54	19	0.84	-0.036	4.613	0.01	0.007	0	42.1	39.1	71	133	124	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	0	8	42	34	0	0	0	0	0	0	0	73.06	0	0	11.4
2014	7	1	0	18	42	35	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	1	0	28	42	34	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	1	0	38	42	35	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	1	0	48	42	34	0	0	0	0	0	0	0	72.99	0	0	11.4
2014	7	1	0	58	42	35	0	0	0	0	0	0	0	72.95	0	0	11.4
2014	7	1	1	8	42	34	0	0	0	0	0	0	0	72.91	0	0	11.4
2014	7	1	1	18	42	34	0	0	0	0	0	0	0	72.9	0	0	11.4
2014	7	1	1	28	42	34	0	0	0	0	0	0	0	72.88	0	0	11.4
2014	7	1	1	38	42	35	0	0	0	0	0	0	0	72.84	0	0	11.4
2014	7	1	1	48	42	35	0	0	0	0	0	0	0	72.79	0	0	11.4
2014	7	1	1	58	42	35	0	0	0	0	0	0	0	72.75	0	0	11.4
2014	7	1	2	8	42	35	0	0	0	0	0	0	0	72.72	0	0	11.4
2014	7	1	2	18	42	34	0	0	0	0	0	0	0	72.68	0	0	11.4
2014	7	1	2	28	42	34	0	0	0	0	0	0	0	72.64	0	0	11.4
2014	7	1	2	38	42	34	0	0	0	0	0	0	0	72.61	0	0	11.2
2014	7	1	2	48	42	34	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	1	2	58	42	34	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	1	3	8	42	35	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	1	3	18	42	34	0	0	0	0	0	0	0	72.46	0	0	11.4
2014	7	1	3	28	42	34	0	0	0	0	0	0	0	72.43	0	0	11.4
2014	7	1	3	38	42	35	0	0	0	0	0	0	0	72.39	0	0	11.2
2014	7	1	3	48	42	34	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	1	3	58	42	35	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	1	4	8	42	34	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	1	4	18	42	34	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	1	4	28	42	34	0	0	0	0	0	0	0	72.19	0	0	11.4
2014	7	1	4	38	42	34	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	1	4	48	42	35	0	0	0	0	0	0	0	72.12	0	0	11.2
2014	7	1	4	58	42	34	0	0	0	0	0	0	0	72.09	0	0	11.2
2014	7	1	5	8	42	34	0	0	0	0	0	0	0	72.05	0	0	11.2
2014	7	1	5	18	42	34	0	0	0	0	0	0	0	72	0	0	11.2
2014	7	1	5	28	42	34	0	0	0	0	0	0	0	71.96	0	0	11.2
2014	7	1	5	38	42	35	0	0	0	0	0	0	0	71.92	0	0	11.2
2014	7	1	5	48	42	34	0	0	0	0	0	0	0	71.89	0	0	11.4
2014	7	1	5	58	42	35	0	0	0	0	0	0	0	71.87	0	0	11.4
2014	7	1	6	8	42	35	0	0	0	0	0	0	0	71.83	0	0	11.4
2014	7	1	6	18	42	35	0	0	0	0	0	0	0	71.8	0	0	11.4
2014	7	1	6	28	42	34	0	0	0	0	0	0	0	71.76	0	0	11.4
2014	7	1	6	38	42	34	0	0	0	0	0	0	0	71.73	0	0	11.4
2014	7	1	6	48	42	34	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	1	6	58	42	34	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	1	7	8	42	35	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	1	7	18	42	34	0	0	0	0	0	0	0	71.67	0	0	12
2014	7	1	7	28	42	34	0	0	0	0	0	0	0	71.65	0	0	12.2
2014	7	1	7	38	42	34	0	0	0	0	0	0	0	71.65	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	7	48	42	34	0	0	0	0	0	0	0	71.65	0	0	12.6
2014	7	1	7	58	42	35	0	0	0	0	0	0	0	71.67	0	0	12.6
2014	7	1	8	8	42	35	0	0	0	0	0	0	0	71.67	0	0	12.8
2014	7	1	8	18	42	34	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	1	8	28	42	35	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	1	8	38	42	34	0	0	0	0	0	0	0	71.73	0	0	12.8
2014	7	1	8	48	42	35	0	0	0	0	0	0	0	71.74	0	0	12.8
2014	7	1	8	58	42	34	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	1	9	8	42	34	0	0	0	0	0	0	0	71.8	0	0	12.8
2014	7	1	9	18	42	35	0	0	0	0	0	0	0	71.82	0	0	12.6
2014	7	1	9	28	42	35	0	0	0	0	0	0	0	71.85	0	0	12.8
2014	7	1	9	38	42	35	0	0	0	0	0	0	0	71.87	0	0	12.8
2014	7	1	9	48	42	35	0	0	0	0	0	0	0	71.91	0	0	13
2014	7	1	9	58	42	35	0	0	0	0	0	0	0	71.92	0	0	13
2014	7	1	10	8	42	34	0	0	0	0	0	0	0	71.96	0	0	13.2
2014	7	1	10	18	42	35	0	0	0	0	0	0	0	72.01	0	0	13.2
2014	7	1	10	28	42	35	0	0	0	0	0	0	0	72.05	0	0	13.2
2014	7	1	10	38	42	34	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	1	10	48	42	34	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	7	1	10	58	42	34	0	0	0	0	0	0	0	72.14	0	0	13
2014	7	1	11	8	42	35	0	0	0	0	0	0	0	72.19	0	0	13
2014	7	1	11	18	42	34	0	0	0	0	0	0	0	72.23	0	0	13
2014	7	1	11	28	42	34	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	1	11	38	42	35	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	1	11	48	42	35	0	0	0	0	0	0	0	72.36	0	0	12.8
2014	7	1	11	58	42	34	0	0	0	0	0	0	0	72.41	0	0	13
2014	7	1	12	8	42	35	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	1	12	18	42	35	0	0	0	0	0	0	0	72.52	0	0	13
2014	7	1	12	28	42	35	0	0	0	0	0	0	0	72.55	0	0	13.2
2014	7	1	12	38	42	34	0	0	0	0	0	0	0	72.59	0	0	13.2
2014	7	1	12	48	42	34	0	0	0	0	0	0	0	72.64	0	0	13.2
2014	7	1	12	58	42	35	0	0	0	0	0	0	0	72.7	0	0	13.2
2014	7	1	13	8	42	34	0	0	0	0	0	0	0	72.7	0	0	13.2
2014	7	1	13	18	42	35	0	0	0	0	0	0	0	72.73	0	0	13.4
2014	7	1	13	28	42	35	0	0	0	0	0	0	0	72.77	0	0	13.2
2014	7	1	13	38	42	34	0	0	0	0	0	0	0	72.81	0	0	13.2
2014	7	1	13	48	42	34	0	0	0	0	0	0	0	72.84	0	0	13.4
2014	7	1	13	58	42	34	0	0	0	0	0	0	0	72.86	0	0	13.2
2014	7	1	14	8	42	34	0	0	0	0	0	0	0	72.88	0	0	13.2
2014	7	1	14	18	42	34	0	0	0	0	0	0	0	72.9	0	0	13.2
2014	7	1	14	28	42	34	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	7	1	14	38	42	34	0	0	0	0	0	0	0	72.91	0	0	13
2014	7	1	14	48	42	35	0	0	0	0	0	0	0	72.9	0	0	13
2014	7	1	14	58	42	34	0	0	0	0	0	0	0	72.9	0	0	13
2014	7	1	15	8	42	34	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	7	1	15	18	42	34	0	0	0	0	0	0	0	72.91	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	15	28	42	34	0	0	0	0	0	0	0	72.95	0	0	13
2014	7	1	15	38	42	35	0	0	0	0	0	0	0	72.93	0	0	12.8
2014	7	1	15	48	42	34	0	0	0	0	0	0	0	72.95	0	0	13
2014	7	1	15	58	42	35	0	0	0	0	0	0	0	72.99	0	0	13
2014	7	1	16	8	42	34	0	0	0	0	0	0	0	72.99	0	0	13
2014	7	1	16	18	42	34	0	0	0	0	0	0	0	72.91	0	0	11.4
2014	7	1	16	28	42	35	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	1	16	38	42	34	0	0	0	0	0	0	0	72.86	0	0	11.8
2014	7	1	16	48	42	34	0	0	0	0	0	0	0	72.97	0	0	12.2
2014	7	1	16	58	42	35	0	0	0	0	0	0	0	72.99	0	0	11.8
2014	7	1	17	8	42	35	0	0	0	0	0	0	0	72.93	0	0	11.4
2014	7	1	17	18	42	34	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	1	17	28	42	35	0	0	0	0	0	0	0	72.99	0	0	11.8
2014	7	1	17	38	42	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	1	17	48	42	35	0	0	0	0	0	0	0	73	0	0	11.8
2014	7	1	17	58	42	34	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	1	18	8	42	34	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	1	18	18	42	34	0	0	0	0	0	0	0	73.02	0	0	11.6
2014	7	1	18	28	42	34	0	0	0	0	0	0	0	73.06	0	0	11.6
2014	7	1	18	38	42	34	0	0	0	0	0	0	0	73.08	0	0	11.6
2014	7	1	18	48	42	34	0	0	0	0	0	0	0	73.09	0	0	11.8
2014	7	1	18	58	42	34	0	0	0	0	0	0	0	73.09	0	0	11.6
2014	7	1	19	8	42	34	0	0	0	0	0	0	0	73.11	0	0	11.6
2014	7	1	19	18	42	34	0	0	0	0	0	0	0	73.11	0	0	11.6
2014	7	1	19	28	42	34	0	0	0	0	0	0	0	73.13	0	0	11.6
2014	7	1	19	38	42	35	0	0	0	0	0	0	0	73.15	0	0	11.4
2014	7	1	19	48	42	35	0	0	0	0	0	0	0	73.15	0	0	11.6
2014	7	1	19	58	42	35	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	1	20	8	42	35	0	0	0	0	0	0	0	73.18	0	0	11.6
2014	7	1	20	18	42	35	0	0	0	0	0	0	0	73.18	0	0	11.4
2014	7	1	20	28	42	34	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	1	20	38	42	34	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	1	20	48	42	34	0	0	0	0	0	0	0	73.24	0	0	11.6
2014	7	1	20	58	42	35	0	0	0	0	0	0	0	73.26	0	0	11.6
2014	7	1	21	8	42	34	0	0	0	0	0	0	0	73.26	0	0	11.6
2014	7	1	21	18	42	34	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	21	28	42	34	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	21	38	42	35	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	21	48	42	35	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	21	58	42	35	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	22	8	42	34	0	0	0	0	0	0	0	73.29	0	0	11.6
2014	7	1	22	18	42	35	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	22	28	42	34	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	22	38	42	35	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	22	48	42	34	0	0	0	0	0	0	0	73.27	0	0	11.6
2014	7	1	22	58	42	34	0	0	0	0	0	0	0	73.26	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	23	8	42	34	0	0	0	0	0	0	0	73.24	0	0	11.6
2014	7	1	23	18	42	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	1	23	28	42	35	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	1	23	38	42	34	0	0	0	0	0	0	0	73.17	0	0	11.4
2014	7	1	23	48	42	34	0	0	0	0	0	0	0	73.15	0	0	11.6
2014	7	1	23	58	42	35	0	0	0	0	0	0	0	73.13	0	0	11.6
2014	7	2	0	8	42	34	0	0	0	0	0	0	0	73.11	0	0	11.6
2014	7	2	0	18	42	34	0	0	0	0	0	0	0	73.08	0	0	11.6
2014	7	2	0	28	42	34	0	0	0	0	0	0	0	73.06	0	0	11.6
2014	7	2	0	38	42	34	0	0	0	0	0	0	0	73.02	0	0	11.6
2014	7	2	0	48	42	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	2	0	58	42	35	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	2	1	8	42	34	0	0	0	0	0	0	0	72.91	0	0	11.6
2014	7	2	1	18	42	35	0	0	0	0	0	0	0	72.88	0	0	11.6
2014	7	2	1	28	42	35	0	0	0	0	0	0	0	72.84	0	0	11.6
2014	7	2	1	38	42	34	0	0	0	0	0	0	0	72.82	0	0	11.4
2014	7	2	1	48	42	35	0	0	0	0	0	0	0	72.77	0	0	11.6
2014	7	2	1	58	42	34	0	0	0	0	0	0	0	72.73	0	0	11.6
2014	7	2	2	8	42	34	0	0	0	0	0	0	0	72.7	0	0	11.6
2014	7	2	2	18	42	34	0	0	0	0	0	0	0	72.66	0	0	11.6
2014	7	2	2	28	42	34	0	0	0	0	0	0	0	72.63	0	0	11.6
2014	7	2	2	38	42	35	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	2	2	48	42	34	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	2	2	58	42	34	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	2	3	8	42	34	0	0	0	0	0	0	0	72.48	0	0	11.4
2014	7	2	3	18	42	33	0	0	0	0	0	0	0	72.43	0	0	11.4
2014	7	2	3	28	42	34	0	0	0	0	0	0	0	72.39	0	0	11.4
2014	7	2	3	38	42	35	0	0	0	0	0	0	0	72.36	0	0	11.2
2014	7	2	3	48	42	34	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	2	3	58	42	35	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	2	4	8	42	35	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	2	4	18	42	34	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	2	4	28	42	35	0	0	0	0	0	0	0	72.16	0	0	11.4
2014	7	2	4	38	42	34	0	0	0	0	0	0	0	72.1	0	0	11.4
2014	7	2	4	48	42	35	0	0	0	0	0	0	0	72.07	0	0	11.4
2014	7	2	4	58	42	35	0	0	0	0	0	0	0	72.01	0	0	11.2
2014	7	2	5	8	42	34	0	0	0	0	0	0	0	71.98	0	0	11.2
2014	7	2	5	18	42	34	0	0	0	0	0	0	0	71.92	0	0	11.2
2014	7	2	5	28	42	35	0	0	0	0	0	0	0	71.91	0	0	11.4
2014	7	2	5	38	42	35	0	0	0	0	0	0	0	71.85	0	0	11.2
2014	7	2	5	48	42	34	0	0	0	0	0	0	0	71.83	0	0	11.4
2014	7	2	5	58	42	34	0	0	0	0	0	0	0	71.78	0	0	11.2
2014	7	2	6	8	42	35	0	0	0	0	0	0	0	71.76	0	0	11.4
2014	7	2	6	18	42	34	0	0	0	0	0	0	0	71.73	0	0	11.4
2014	7	2	6	28	42	35	0	0	0	0	0	0	0	71.67	0	0	11.4
2014	7	2	6	38	42	35	0	0	0	0	0	0	0	71.64	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	6	48	42	34	0	0	0	0	0	0	0	71.62	0	0	11.8
2014	7	2	6	58	42	34	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	2	7	8	42	35	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	2	7	18	42	35	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	2	7	28	42	34	0	0	0	0	0	0	0	71.55	0	0	12.2
2014	7	2	7	38	42	35	0	0	0	0	0	0	0	71.55	0	0	12.2
2014	7	2	7	48	42	34	0	0	0	0	0	0	0	71.55	0	0	12.6
2014	7	2	7	58	42	34	0	0	0	0	0	0	0	71.56	0	0	12.8
2014	7	2	8	8	42	35	0	0	0	0	0	0	0	71.58	0	0	12.8
2014	7	2	8	18	42	34	0	0	0	0	0	0	0	71.58	0	0	12.6
2014	7	2	8	28	42	35	0	0	0	0	0	0	0	71.6	0	0	13
2014	7	2	8	38	42	34	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	2	8	48	42	34	0	0	0	0	0	0	0	71.64	0	0	13
2014	7	2	8	58	42	35	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	2	9	8	42	35	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	2	9	18	42	35	0	0	0	0	0	0	0	71.71	0	0	12.8
2014	7	2	9	28	42	35	0	0	0	0	0	0	0	71.73	0	0	12.8
2014	7	2	9	38	42	34	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	2	9	48	42	35	0	0	0	0	0	0	0	71.8	0	0	13
2014	7	2	9	58	42	35	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	2	10	8	42	35	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	2	10	18	42	33	0	0	0	0	0	0	0	71.89	0	0	13
2014	7	2	10	28	42	35	0	0	0	0	0	0	0	71.92	0	0	13
2014	7	2	10	38	42	34	0	0	0	0	0	0	0	71.94	0	0	13
2014	7	2	10	48	42	35	0	0	0	0	0	0	0	71.98	0	0	13
2014	7	2	10	58	42	35	0	0	0	0	0	0	0	72.01	0	0	13
2014	7	2	11	8	42	34	0	0	0	0	0	0	0	72.05	0	0	13
2014	7	2	11	18	42	35	0	0	0	0	0	0	0	72.09	0	0	13
2014	7	2	11	28	42	35	0	0	0	0	0	0	0	72.12	0	0	13.2
2014	7	2	11	38	42	35	0	0	0	0	0	0	0	72.16	0	0	13
2014	7	2	11	48	42	34	0	0	0	0	0	0	0	72.18	0	0	13.2
2014	7	2	11	58	42	34	0	0	0	0	0	0	0	72.21	0	0	13.2
2014	7	2	12	8	42	35	0	0	0	0	0	0	0	72.27	0	0	13.4
2014	7	2	12	18	42	34	0	0	0	0	0	0	0	72.28	0	0	13.4
2014	7	2	12	28	42	35	0	0	0	0	0	0	0	72.32	0	0	13.4
2014	7	2	12	38	42	35	0	0	0	0	0	0	0	72.39	0	0	13.2
2014	7	2	12	48	42	35	0	0	0	0	0	0	0	72.41	0	0	13.4
2014	7	2	12	58	42	34	0	0	0	0	0	0	0	72.45	0	0	13.4
2014	7	2	13	8	42	35	0	0	0	0	0	0	0	72.5	0	0	13.4
2014	7	2	13	18	42	35	0	0	0	0	0	0	0	72.52	0	0	13.4
2014	7	2	13	28	42	35	0	0	0	0	0	0	0	72.55	0	0	13.4
2014	7	2	13	38	42	35	0	0	0	0	0	0	0	72.57	0	0	13.2
2014	7	2	13	48	42	35	0	0	0	0	0	0	0	72.59	0	0	13.4
2014	7	2	13	58	42	35	0	0	0	0	0	0	0	72.63	0	0	13
2014	7	2	14	8	42	35	0	0	0	0	0	0	0	72.64	0	0	13
2014	7	2	14	18	42	34	0	0	0	0	0	0	0	72.66	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	14	28	42	34	0	0	0	0	0	0	0	72.68	0	0	13
2014	7	2	14	38	42	35	0	0	0	0	0	0	0	72.68	0	0	12.8
2014	7	2	14	48	42	34	0	0	0	0	0	0	0	72.7	0	0	13
2014	7	2	14	58	42	35	0	0	0	0	0	0	0	72.72	0	0	13
2014	7	2	15	8	42	35	0	0	0	0	0	0	0	72.72	0	0	12.8
2014	7	2	15	18	42	34	0	0	0	0	0	0	0	72.73	0	0	12.8
2014	7	2	15	28	42	34	0	0	0	0	0	0	0	72.72	0	0	12.8
2014	7	2	15	38	42	35	0	0	0	0	0	0	0	72.72	0	0	12.6
2014	7	2	15	48	42	34	0	0	0	0	0	0	0	72.73	0	0	12.8
2014	7	2	15	58	42	34	0	0	0	0	0	0	0	72.66	0	0	12.2
2014	7	2	16	8	42	34	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	2	16	18	42	34	0	0	0	0	0	0	0	72.63	0	0	12.6
2014	7	2	16	28	42	34	0	0	0	0	0	0	0	72.63	0	0	12
2014	7	2	16	38	42	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	2	16	48	42	34	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	2	16	58	42	35	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	2	17	8	42	34	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	2	17	18	42	34	0	0	0	0	0	0	0	72.54	0	0	12
2014	7	2	17	28	42	34	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	2	17	38	42	34	0	0	0	0	0	0	0	72.54	0	0	11.6
2014	7	2	17	48	42	35	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	2	17	58	42	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	2	18	8	42	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	2	18	18	42	34	0	0	0	0	0	0	0	72.59	0	0	11.8
2014	7	2	18	28	42	34	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	2	18	38	42	34	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	2	18	48	42	34	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	2	18	58	42	33	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	2	19	8	42	35	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	2	19	18	42	34	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	2	19	28	42	34	0	0	0	0	0	0	0	72.7	0	0	11.8
2014	7	2	19	38	42	34	0	0	0	0	0	0	0	72.7	0	0	11.6
2014	7	2	19	48	42	34	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	2	19	58	42	35	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	2	20	8	42	34	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	2	20	18	42	34	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	2	20	28	42	35	0	0	0	0	0	0	0	72.73	0	0	11.6
2014	7	2	20	38	42	34	0	0	0	0	0	0	0	72.73	0	0	11.6
2014	7	2	20	48	42	34	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	2	20	58	42	34	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	2	21	8	42	34	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	2	21	18	42	35	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	2	21	28	42	35	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	2	21	38	42	34	0	0	0	0	0	0	0	72.7	0	0	11.4
2014	7	2	21	48	42	35	0	0	0	0	0	0	0	72.7	0	0	11.6
2014	7	2	21	58	42	34	0	0	0	0	0	0	0	72.68	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	22	8	42	34	0	0	0	0	0	0	0	72.68	0	0	11.4
2014	7	2	22	18	42	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	2	22	28	42	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	2	22	38	42	34	0	0	0	0	0	0	0	72.64	0	0	11.4
2014	7	2	22	48	42	34	0	0	0	0	0	0	0	72.63	0	0	11.4
2014	7	2	22	58	42	35	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	2	23	8	42	35	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	2	23	18	42	34	0	0	0	0	0	0	0	72.59	0	0	11.4
2014	7	2	23	28	42	35	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	2	23	38	42	34	0	0	0	0	0	0	0	72.55	0	0	11.2
2014	7	2	23	48	42	35	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	2	23	58	42	34	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	3	0	8	42	34	0	0	0	0	0	0	0	72.48	0	0	11.4
2014	7	3	0	18	42	34	0	0	0	0	0	0	0	72.45	0	0	11.4
2014	7	3	0	28	42	34	0	0	0	0	0	0	0	72.43	0	0	11.4
2014	7	3	0	38	42	34	0	0	0	0	0	0	0	72.39	0	0	11.4
2014	7	3	0	48	42	34	0	0	0	0	0	0	0	72.37	0	0	11.4
2014	7	3	0	58	42	34	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	3	1	8	42	35	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	3	1	18	42	34	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	3	1	28	42	34	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	3	1	38	42	34	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	3	1	48	42	34	0	0	0	0	0	0	0	72.14	0	0	11.4
2014	7	3	1	58	42	35	0	0	0	0	0	0	0	72.1	0	0	11.4
2014	7	3	2	8	42	34	0	0	0	0	0	0	0	72.07	0	0	11.4
2014	7	3	2	18	42	35	0	0	0	0	0	0	0	72.03	0	0	11.4
2014	7	3	2	28	42	35	0	0	0	0	0	0	0	71.98	0	0	11.4
2014	7	3	2	38	42	35	0	0	0	0	0	0	0	71.94	0	0	11.2
2014	7	3	2	48	42	35	0	0	0	0	0	0	0	71.91	0	0	11.4
2014	7	3	2	58	42	34	0	0	0	0	0	0	0	71.87	0	0	11.4
2014	7	3	3	8	42	35	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	3	3	18	42	34	0	0	0	0	0	0	0	71.76	0	0	11.2
2014	7	3	3	28	42	35	0	0	0	0	0	0	0	71.73	0	0	11.2
2014	7	3	3	38	42	35	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	3	3	48	42	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	3	3	58	42	35	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	3	4	8	42	34	0	0	0	0	0	0	0	71.55	0	0	11.2
2014	7	3	4	18	42	35	0	0	0	0	0	0	0	71.53	0	0	11.2
2014	7	3	4	28	42	35	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	3	4	38	42	34	0	0	0	0	0	0	0	71.42	0	0	11.2
2014	7	3	4	48	42	34	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	3	4	58	42	35	0	0	0	0	0	0	0	71.35	0	0	11.4
2014	7	3	5	8	42	34	0	0	0	0	0	0	0	71.28	0	0	11.4
2014	7	3	5	18	42	35	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	3	5	28	42	35	0	0	0	0	0	0	0	71.2	0	0	11.2
2014	7	3	5	38	42	35	0	0	0	0	0	0	0	71.15	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	5	48	42	35	0	0	0	0	0	0	0	71.11	0	0	11.4
2014	7	3	5	58	42	35	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	3	6	8	42	35	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	3	6	18	42	34	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	3	6	28	42	34	0	0	0	0	0	0	0	70.93	0	0	11.4
2014	7	3	6	38	42	34	0	0	0	0	0	0	0	70.88	0	0	11.4
2014	7	3	6	48	42	35	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	3	6	58	42	35	0	0	0	0	0	0	0	70.83	0	0	11.8
2014	7	3	7	8	42	34	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	3	7	18	42	35	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	3	7	28	42	35	0	0	0	0	0	0	0	70.77	0	0	12.2
2014	7	3	7	38	42	35	0	0	0	0	0	0	0	70.77	0	0	12.2
2014	7	3	7	48	42	35	0	0	0	0	0	0	0	70.77	0	0	12.4
2014	7	3	7	58	42	34	0	0	0	0	0	0	0	70.77	0	0	12.6
2014	7	3	8	8	42	34	0	0	0	0	0	0	0	70.77	0	0	12.8
2014	7	3	8	18	42	34	0	0	0	0	0	0	0	70.79	0	0	12.8
2014	7	3	8	28	42	34	0	0	0	0	0	0	0	70.79	0	0	12.8
2014	7	3	8	38	42	35	0	0	0	0	0	0	0	70.81	0	0	12.8
2014	7	3	8	48	42	34	0	0	0	0	0	0	0	70.83	0	0	12.8
2014	7	3	8	58	42	35	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	3	9	8	42	34	0	0	0	0	0	0	0	70.88	0	0	12.8
2014	7	3	9	18	42	34	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	3	9	28	42	35	0	0	0	0	0	0	0	70.93	0	0	12.8
2014	7	3	9	38	42	34	0	0	0	0	0	0	0	70.95	0	0	12.6
2014	7	3	9	48	42	35	0	0	0	0	0	0	0	70.99	0	0	12.6
2014	7	3	9	58	42	35	0	0	0	0	0	0	0	71.04	0	0	12.6
2014	7	3	10	8	42	35	0	0	0	0	0	0	0	71.08	0	0	12.6
2014	7	3	10	18	42	34	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	3	10	28	42	35	0	0	0	0	0	0	0	71.13	0	0	12.8
2014	7	3	10	38	42	34	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	3	10	48	42	34	0	0	0	0	0	0	0	71.19	0	0	12.8
2014	7	3	10	58	42	34	0	0	0	0	0	0	0	71.22	0	0	12.8
2014	7	3	11	8	42	34	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	3	11	18	42	35	0	0	0	0	0	0	0	71.31	0	0	12.6
2014	7	3	11	28	42	35	0	0	0	0	0	0	0	71.33	0	0	12.6
2014	7	3	11	38	42	35	0	0	0	0	0	0	0	71.38	0	0	12.8
2014	7	3	11	48	42	34	0	0	0	0	0	0	0	71.42	0	0	12.8
2014	7	3	11	58	42	35	0	0	0	0	0	0	0	71.47	0	0	12.8
2014	7	3	12	8	42	34	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	3	12	18	42	34	0	0	0	0	0	0	0	71.53	0	0	12.8
2014	7	3	12	28	42	35	0	0	0	0	0	0	0	71.6	0	0	12.8
2014	7	3	12	38	42	35	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	3	12	48	42	34	0	0	0	0	0	0	0	71.67	0	0	12.8
2014	7	3	12	58	42	35	0	0	0	0	0	0	0	71.73	0	0	13
2014	7	3	13	8	42	35	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	3	13	18	42	34	0	0	0	0	0	0	0	71.82	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	13	28	42	34	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	3	13	38	42	34	0	0	0	0	0	0	0	71.89	0	0	12.8
2014	7	3	13	48	42	34	0	0	0	0	0	0	0	71.92	0	0	12.8
2014	7	3	13	58	42	35	0	0	0	0	0	0	0	71.94	0	0	12.8
2014	7	3	14	8	42	35	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	3	14	18	42	34	0	0	0	0	0	0	0	72.01	0	0	12.8
2014	7	3	14	28	42	33	0	0	0	0	0	0	0	72.03	0	0	12.8
2014	7	3	14	38	42	35	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	3	14	48	42	35	0	0	0	0	0	0	0	72.07	0	0	12.8
2014	7	3	14	58	42	34	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	3	15	8	42	35	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	3	15	18	42	34	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	3	15	28	42	34	0	0	0	0	0	0	0	72.12	0	0	12.8
2014	7	3	15	38	42	35	0	0	0	0	0	0	0	72.12	0	0	12.6
2014	7	3	15	48	42	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	3	15	58	42	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	3	16	8	42	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	3	16	18	42	35	0	0	0	0	0	0	0	72.16	0	0	12.8
2014	7	3	16	28	42	35	0	0	0	0	0	0	0	72.16	0	0	12.6
2014	7	3	16	38	42	35	0	0	0	0	0	0	0	72.18	0	0	12.4
2014	7	3	16	48	42	35	0	0	0	0	0	0	0	72.19	0	0	12.2
2014	7	3	16	58	42	35	0	0	0	0	0	0	0	72.18	0	0	12
2014	7	3	17	8	42	34	0	0	0	0	0	0	0	72.18	0	0	12
2014	7	3	17	18	42	34	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	3	17	28	42	34	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	3	17	38	42	35	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	3	17	48	42	35	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	3	17	58	42	34	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	3	18	8	42	34	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	3	18	18	42	34	0	0	0	0	0	0	0	72.21	0	0	11.6
2014	7	3	18	28	42	34	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	3	18	38	42	34	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	3	18	48	42	35	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	3	18	58	42	34	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	3	19	8	42	35	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	3	19	18	42	35	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	3	19	28	42	34	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	3	19	38	42	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	3	19	48	42	35	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	3	19	58	42	34	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	3	20	8	42	35	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	3	20	18	42	34	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	3	20	28	42	35	0	0	0	0	0	0	0	72.34	0	0	11.6
2014	7	3	20	38	42	34	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	3	20	48	42	34	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	3	20	58	42	34	0	0	0	0	0	0	0	72.36	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	21	8	42	35	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	21	18	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	21	28	42	35	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	21	38	42	34	0	0	0	0	0	0	0	72.37	0	0	11.4
2014	7	3	21	48	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	21	58	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	22	8	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	22	18	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	22	28	42	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	3	22	38	42	34	0	0	0	0	0	0	0	72.36	0	0	11.4
2014	7	3	22	48	42	35	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	3	22	58	42	35	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	3	23	8	42	34	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	3	23	18	42	35	0	0	0	0	0	0	0	72.32	0	0	11.4
2014	7	3	23	28	42	35	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	3	23	38	42	34	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	3	23	48	42	35	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	3	23	58	42	35	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	4	0	8	42	34	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	4	0	18	42	34	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	4	0	28	42	34	0	0	0	0	0	0	0	72.21	0	0	11.4
2014	7	4	0	38	42	35	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	4	0	48	42	35	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	4	0	58	42	35	0	0	0	0	0	0	0	72.12	0	0	11.2
2014	7	4	1	8	42	34	0	0	0	0	0	0	0	72.1	0	0	11.2
2014	7	4	1	18	42	34	0	0	0	0	0	0	0	72.07	0	0	11.2
2014	7	4	1	28	42	35	0	0	0	0	0	0	0	72.03	0	0	11.2
2014	7	4	1	38	42	35	0	0	0	0	0	0	0	72	0	0	11.2
2014	7	4	1	48	42	35	0	0	0	0	0	0	0	71.96	0	0	11.2
2014	7	4	1	58	42	34	0	0	0	0	0	0	0	71.94	0	0	11.2
2014	7	4	2	8	42	34	0	0	0	0	0	0	0	71.89	0	0	11.2
2014	7	4	2	18	42	34	0	0	0	0	0	0	0	71.85	0	0	11.2
2014	7	4	2	28	42	35	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	4	2	38	42	34	0	0	0	0	0	0	0	71.78	0	0	11
2014	7	4	2	48	42	35	0	0	0	0	0	0	0	71.73	0	0	11.2
2014	7	4	2	58	42	35	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	4	3	8	42	35	0	0	0	0	0	0	0	71.65	0	0	11.2
2014	7	4	3	18	42	34	0	0	0	0	0	0	0	71.6	0	0	11.2
2014	7	4	3	28	42	35	0	0	0	0	0	0	0	71.56	0	0	11.2
2014	7	4	3	38	42	35	0	0	0	0	0	0	0	71.53	0	0	11
2014	7	4	3	48	42	34	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	4	3	58	42	34	0	0	0	0	0	0	0	71.44	0	0	11.2
2014	7	4	4	8	42	34	0	0	0	0	0	0	0	71.38	0	0	11.2
2014	7	4	4	18	42	35	0	0	0	0	0	0	0	71.35	0	0	11.2
2014	7	4	4	28	42	34	0	0	0	0	0	0	0	71.31	0	0	11.2
2014	7	4	4	38	42	35	0	0	0	0	0	0	0	71.28	0	0	10.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	4	48	42	35	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	4	4	58	42	35	0	0	0	0	0	0	0	71.19	0	0	11.2
2014	7	4	5	8	42	35	0	0	0	0	0	0	0	71.15	0	0	11.2
2014	7	4	5	18	42	35	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	4	5	28	42	35	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	4	5	38	42	34	0	0	0	0	0	0	0	71.02	0	0	11.2
2014	7	4	5	48	42	34	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	4	5	58	42	34	0	0	0	0	0	0	0	70.95	0	0	11.2
2014	7	4	6	8	42	35	0	0	0	0	0	0	0	70.92	0	0	11.2
2014	7	4	6	18	42	34	0	0	0	0	0	0	0	70.86	0	0	11.2
2014	7	4	6	28	42	34	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	4	6	38	42	34	0	0	0	0	0	0	0	70.79	0	0	11
2014	7	4	6	48	42	35	0	0	0	0	0	0	0	70.75	0	0	11.4
2014	7	4	6	58	42	34	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	4	7	8	42	34	0	0	0	0	0	0	0	70.7	0	0	11.8
2014	7	4	7	18	42	34	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	4	7	28	42	35	0	0	0	0	0	0	0	70.68	0	0	12.2
2014	7	4	7	38	42	35	0	0	0	0	0	0	0	70.68	0	0	12.4
2014	7	4	7	48	42	35	0	0	0	0	0	0	0	70.68	0	0	12.6
2014	7	4	7	58	42	35	0	0	0	0	0	0	0	70.68	0	0	12.8
2014	7	4	8	8	42	35	0	0	0	0	0	0	0	70.7	0	0	13
2014	7	4	8	18	42	35	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	4	8	28	42	35	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	4	8	38	42	35	0	0	0	0	0	0	0	70.74	0	0	13
2014	7	4	8	48	42	34	0	0	0	0	0	0	0	70.77	0	0	13
2014	7	4	8	58	42	35	0	0	0	0	0	0	0	70.79	0	0	13
2014	7	4	9	8	42	35	0	0	0	0	0	0	0	70.81	0	0	13
2014	7	4	9	18	42	35	0	0	0	0	0	0	0	70.84	0	0	13
2014	7	4	9	28	42	35	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	4	9	38	42	35	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	4	9	48	42	34	0	0	0	0	0	0	0	70.93	0	0	13
2014	7	4	9	58	42	35	0	0	0	0	0	0	0	70.97	0	0	13
2014	7	4	10	8	42	35	0	0	0	0	0	0	0	71.01	0	0	13
2014	7	4	10	18	42	34	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	4	10	28	42	35	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	4	10	38	42	35	0	0	0	0	0	0	0	71.1	0	0	13
2014	7	4	10	48	42	35	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	4	10	58	42	35	0	0	0	0	0	0	0	71.15	0	0	13
2014	7	4	11	8	42	35	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	4	11	18	42	35	0	0	0	0	0	0	0	71.22	0	0	13
2014	7	4	11	28	42	34	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	4	11	38	42	34	0	0	0	0	0	0	0	71.29	0	0	13
2014	7	4	11	48	42	34	0	0	0	0	0	0	0	71.33	0	0	13
2014	7	4	11	58	42	34	0	0	0	0	0	0	0	71.38	0	0	12.8
2014	7	4	12	8	42	35	0	0	0	0	0	0	0	71.42	0	0	13
2014	7	4	12	18	42	34	0	0	0	0	0	0	0	71.44	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	12	28	42	35	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	4	12	38	42	35	0	0	0	0	0	0	0	71.58	0	0	12.8
2014	7	4	12	48	42	34	0	0	0	0	0	0	0	71.64	0	0	13
2014	7	4	12	58	42	35	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	4	13	8	42	35	0	0	0	0	0	0	0	71.73	0	0	12.8
2014	7	4	13	18	42	34	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	4	13	28	42	34	0	0	0	0	0	0	0	71.8	0	0	13
2014	7	4	13	38	42	35	0	0	0	0	0	0	0	71.82	0	0	12.8
2014	7	4	13	48	42	34	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	4	13	58	42	35	0	0	0	0	0	0	0	71.89	0	0	13
2014	7	4	14	8	42	34	0	0	0	0	0	0	0	71.89	0	0	12.2
2014	7	4	14	18	42	35	0	0	0	0	0	0	0	71.91	0	0	12.2
2014	7	4	14	28	42	35	0	0	0	0	0	0	0	71.92	0	0	12
2014	7	4	14	38	42	35	0	0	0	0	0	0	0	71.94	0	0	12.2
2014	7	4	14	48	42	35	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	4	14	58	42	35	0	0	0	0	0	0	0	71.96	0	0	12.4
2014	7	4	15	8	42	34	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	4	15	18	42	35	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	4	15	28	42	35	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	4	15	38	42	34	0	0	0	0	0	0	0	72	0	0	12.6
2014	7	4	15	48	42	34	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	4	15	58	42	35	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	4	16	8	42	34	0	0	0	0	0	0	0	72.01	0	0	12.8
2014	7	4	16	18	42	35	0	0	0	0	0	0	0	72.01	0	0	12.6
2014	7	4	16	28	42	35	0	0	0	0	0	0	0	72	0	0	12.6
2014	7	4	16	38	42	34	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	4	16	48	42	34	0	0	0	0	0	0	0	72.03	0	0	12
2014	7	4	16	58	42	34	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	17	8	42	34	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	4	17	18	42	34	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	4	17	28	42	34	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	4	17	38	42	34	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	17	48	42	35	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	17	58	42	34	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	18	8	42	35	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	4	18	18	42	35	0	0	0	0	0	0	0	72.09	0	0	11.8
2014	7	4	18	28	42	34	0	0	0	0	0	0	0	72.09	0	0	11.8
2014	7	4	18	38	42	34	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	4	18	48	42	34	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	4	18	58	42	35	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	4	19	8	42	34	0	0	0	0	0	0	0	72.16	0	0	11.8
2014	7	4	19	18	42	35	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	4	19	28	42	35	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	4	19	38	42	34	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	4	19	48	42	35	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	4	19	58	42	34	0	0	0	0	0	0	0	72.21	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	20	8	42	35	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	4	20	18	42	34	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	4	20	28	42	35	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	4	20	38	42	35	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	4	20	48	42	34	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	4	20	58	42	34	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	4	21	8	42	34	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	4	21	18	42	35	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	4	21	28	42	34	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	4	21	38	42	35	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	4	21	48	42	34	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	4	21	58	42	35	0	0	0	0	0	0	0	72.32	0	0	11.4
2014	7	4	22	8	42	35	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	4	22	18	42	34	0	0	0	0	0	0	0	72.34	0	0	11.8
2014	7	4	22	28	42	35	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	4	22	38	42	34	0	0	0	0	0	0	0	72.34	0	0	11.4
2014	7	4	22	48	42	35	0	0	0	0	0	0	0	72.34	0	0	11.6
2014	7	4	22	58	42	35	0	0	0	0	0	0	0	72.34	0	0	11.6
2014	7	4	23	8	42	34	0	0	0	0	0	0	0	72.32	0	0	11.4
2014	7	4	23	18	42	35	0	0	0	0	0	0	0	72.32	0	0	11.4
2014	7	4	23	28	42	35	0	0	0	0	0	0	0	72.32	0	0	11.2
2014	7	4	23	38	42	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	4	23	48	42	35	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	4	23	58	42	34	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	5	0	8	42	35	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	5	0	18	42	34	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	5	0	28	42	35	0	0	0	0	0	0	0	72.25	0	0	11.4
2014	7	5	0	38	42	35	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	5	0	48	42	34	0	0	0	0	0	0	0	72.23	0	0	11.2
2014	7	5	0	58	42	35	0	0	0	0	0	0	0	72.19	0	0	11.4
2014	7	5	1	8	42	35	0	0	0	0	0	0	0	72.18	0	0	11.4
2014	7	5	1	18	42	35	0	0	0	0	0	0	0	72.16	0	0	11.4
2014	7	5	1	28	42	34	0	0	0	0	0	0	0	72.14	0	0	11.4
2014	7	5	1	38	42	34	0	0	0	0	0	0	0	72.1	0	0	11.2
2014	7	5	1	48	42	35	0	0	0	0	0	0	0	72.1	0	0	11.4
2014	7	5	1	58	42	35	0	0	0	0	0	0	0	72.07	0	0	11.4
2014	7	5	2	8	42	35	0	0	0	0	0	0	0	72.03	0	0	11.4
2014	7	5	2	18	42	34	0	0	0	0	0	0	0	72	0	0	11.4
2014	7	5	2	28	42	34	0	0	0	0	0	0	0	71.98	0	0	11.4
2014	7	5	2	38	42	35	0	0	0	0	0	0	0	71.94	0	0	11.2
2014	7	5	2	48	42	35	0	0	0	0	0	0	0	71.92	0	0	11.4
2014	7	5	2	58	42	34	0	0	0	0	0	0	0	71.89	0	0	11.2
2014	7	5	3	8	42	35	0	0	0	0	0	0	0	71.85	0	0	11.2
2014	7	5	3	18	42	34	0	0	0	0	0	0	0	71.83	0	0	11.2
2014	7	5	3	28	42	35	0	0	0	0	0	0	0	71.8	0	0	11.2
2014	7	5	3	38	42	34	0	0	0	0	0	0	0	71.76	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	3	48	42	35	0	0	0	0	0	0	0	71.73	0	0	11.4
2014	7	5	3	58	42	35	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	5	4	8	42	35	0	0	0	0	0	0	0	71.67	0	0	11.2
2014	7	5	4	18	42	35	0	0	0	0	0	0	0	71.64	0	0	11.2
2014	7	5	4	28	42	34	0	0	0	0	0	0	0	71.6	0	0	11.2
2014	7	5	4	38	42	34	0	0	0	0	0	0	0	71.58	0	0	11.2
2014	7	5	4	48	42	35	0	0	0	0	0	0	0	71.55	0	0	11.2
2014	7	5	4	58	42	34	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	5	5	8	42	35	0	0	0	0	0	0	0	71.47	0	0	11
2014	7	5	5	18	42	35	0	0	0	0	0	0	0	71.44	0	0	11
2014	7	5	5	28	42	35	0	0	0	0	0	0	0	71.42	0	0	11
2014	7	5	5	38	42	34	0	0	0	0	0	0	0	71.38	0	0	11
2014	7	5	5	48	42	35	0	0	0	0	0	0	0	71.35	0	0	11
2014	7	5	5	58	42	34	0	0	0	0	0	0	0	71.31	0	0	11
2014	7	5	6	8	42	35	0	0	0	0	0	0	0	71.28	0	0	11
2014	7	5	6	18	42	35	0	0	0	0	0	0	0	71.26	0	0	11
2014	7	5	6	28	42	34	0	0	0	0	0	0	0	71.22	0	0	11
2014	7	5	6	38	42	34	0	0	0	0	0	0	0	71.2	0	0	11.2
2014	7	5	6	48	42	35	0	0	0	0	0	0	0	71.17	0	0	11.6
2014	7	5	6	58	42	35	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	5	7	8	42	35	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	5	7	18	42	34	0	0	0	0	0	0	0	71.13	0	0	11.8
2014	7	5	7	28	42	35	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	7	5	7	38	42	34	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	7	5	7	48	42	34	0	0	0	0	0	0	0	71.15	0	0	12.4
2014	7	5	7	58	42	35	0	0	0	0	0	0	0	71.15	0	0	12.6
2014	7	5	8	8	42	34	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	5	8	18	42	35	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	5	8	28	42	34	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	5	8	38	42	35	0	0	0	0	0	0	0	71.2	0	0	12.8
2014	7	5	8	48	42	34	0	0	0	0	0	0	0	71.22	0	0	12.8
2014	7	5	8	58	42	34	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	5	9	8	42	34	0	0	0	0	0	0	0	71.28	0	0	12.8
2014	7	5	9	18	42	34	0	0	0	0	0	0	0	71.31	0	0	12.8
2014	7	5	9	28	42	35	0	0	0	0	0	0	0	71.35	0	0	12.8
2014	7	5	9	38	42	35	0	0	0	0	0	0	0	71.38	0	0	12.6
2014	7	5	9	48	42	34	0	0	0	0	0	0	0	71.4	0	0	12.8
2014	7	5	9	58	42	35	0	0	0	0	0	0	0	71.44	0	0	12.6
2014	7	5	10	8	42	34	0	0	0	0	0	0	0	71.47	0	0	12.6
2014	7	5	10	18	42	35	0	0	0	0	0	0	0	71.53	0	0	12.6
2014	7	5	10	28	42	35	0	0	0	0	0	0	0	71.56	0	0	12.6
2014	7	5	10	38	42	34	0	0	0	0	0	0	0	71.6	0	0	12.6
2014	7	5	10	48	42	35	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	5	10	58	42	35	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	5	11	8	42	35	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	5	11	18	42	35	0	0	0	0	0	0	0	71.71	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	11	28	42	35	0	0	0	0	0	0	0	71.74	0	0	12.8
2014	7	5	11	38	42	34	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	5	11	48	42	34	0	0	0	0	0	0	0	71.83	0	0	12.8
2014	7	5	11	58	42	34	0	0	0	0	0	0	0	71.89	0	0	12.8
2014	7	5	12	8	42	34	0	0	0	0	0	0	0	71.94	0	0	12.8
2014	7	5	12	18	42	34	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	5	12	28	42	34	0	0	0	0	0	0	0	72.07	0	0	12.8
2014	7	5	12	38	42	35	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	5	12	48	42	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	5	12	58	42	34	0	0	0	0	0	0	0	72.19	0	0	12.8
2014	7	5	13	8	42	35	0	0	0	0	0	0	0	72.25	0	0	12.8
2014	7	5	13	18	42	35	0	0	0	0	0	0	0	72.28	0	0	12.8
2014	7	5	13	28	42	35	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	5	13	38	42	35	0	0	0	0	0	0	0	72.36	0	0	12.8
2014	7	5	13	48	42	34	0	0	0	0	0	0	0	72.39	0	0	12.8
2014	7	5	13	58	42	35	0	0	0	0	0	0	0	72.43	0	0	12.8
2014	7	5	14	8	42	35	0	0	0	0	0	0	0	72.45	0	0	12.8
2014	7	5	14	18	42	34	0	0	0	0	0	0	0	72.46	0	0	12.8
2014	7	5	14	28	42	35	0	0	0	0	0	0	0	72.48	0	0	12.8
2014	7	5	14	38	42	35	0	0	0	0	0	0	0	72.5	0	0	12.6
2014	7	5	14	48	42	34	0	0	0	0	0	0	0	72.52	0	0	12.6
2014	7	5	14	58	42	34	0	0	0	0	0	0	0	72.54	0	0	12.6
2014	7	5	15	8	42	34	0	0	0	0	0	0	0	72.55	0	0	12.6
2014	7	5	15	18	42	34	0	0	0	0	0	0	0	72.55	0	0	12.6
2014	7	5	15	28	42	34	0	0	0	0	0	0	0	72.59	0	0	12.6
2014	7	5	15	38	42	35	0	0	0	0	0	0	0	72.59	0	0	12.6
2014	7	5	15	48	42	34	0	0	0	0	0	0	0	72.61	0	0	12.6
2014	7	5	15	58	42	34	0	0	0	0	0	0	0	72.64	0	0	12.6
2014	7	5	16	8	42	34	0	0	0	0	0	0	0	72.64	0	0	12.6
2014	7	5	16	18	42	35	0	0	0	0	0	0	0	72.66	0	0	12.6
2014	7	5	16	28	42	34	0	0	0	0	0	0	0	72.66	0	0	12.6
2014	7	5	16	38	42	34	0	0	0	0	0	0	0	72.68	0	0	12.2
2014	7	5	16	48	42	35	0	0	0	0	0	0	0	72.68	0	0	12.2
2014	7	5	16	58	42	35	0	0	0	0	0	0	0	72.68	0	0	12.2
2014	7	5	17	8	42	35	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	5	17	18	42	35	0	0	0	0	0	0	0	72.68	0	0	12.2
2014	7	5	17	28	42	34	0	0	0	0	0	0	0	72.72	0	0	12.2
2014	7	5	17	38	42	34	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	5	17	48	42	35	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	5	17	58	42	34	0	0	0	0	0	0	0	72.73	0	0	12
2014	7	5	18	8	42	35	0	0	0	0	0	0	0	72.75	0	0	12
2014	7	5	18	18	42	35	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	5	18	28	42	34	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	5	18	38	42	34	0	0	0	0	0	0	0	72.77	0	0	11.8
2014	7	5	18	48	42	35	0	0	0	0	0	0	0	72.79	0	0	11.8
2014	7	5	18	58	42	34	0	0	0	0	0	0	0	72.81	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	19	8	42	35	0	0	0	0	0	0	0	72.81	0	0	11.8
2014	7	5	19	18	42	34	0	0	0	0	0	0	0	72.82	0	0	11.6
2014	7	5	19	28	42	35	0	0	0	0	0	0	0	72.82	0	0	11.6
2014	7	5	19	38	42	35	0	0	0	0	0	0	0	72.84	0	0	11.6
2014	7	5	19	48	42	34	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	5	19	58	42	35	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	5	20	8	42	34	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	5	20	18	42	34	0	0	0	0	0	0	0	72.88	0	0	11.6
2014	7	5	20	28	42	35	0	0	0	0	0	0	0	72.9	0	0	11.4
2014	7	5	20	38	42	34	0	0	0	0	0	0	0	72.91	0	0	11.4
2014	7	5	20	48	42	34	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	5	20	58	42	34	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	5	21	8	42	34	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	5	21	18	42	35	0	0	0	0	0	0	0	72.97	0	0	11.4
2014	7	5	21	28	42	34	0	0	0	0	0	0	0	72.97	0	0	11.4
2014	7	5	21	38	42	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	5	21	48	42	34	0	0	0	0	0	0	0	73	0	0	11.4
2014	7	5	21	58	42	34	0	0	0	0	0	0	0	73	0	0	11.4
2014	7	5	22	8	42	34	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	5	22	18	42	35	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	5	22	28	42	34	0	0	0	0	0	0	0	73.06	0	0	11.4
2014	7	5	22	38	42	35	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	5	22	48	42	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	5	22	58	42	35	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	5	23	8	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	5	23	18	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	5	23	28	42	34	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	5	23	38	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	5	23	48	42	34	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	5	23	58	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	6	0	8	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	6	0	18	42	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	6	0	28	42	33	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	6	0	38	42	34	0	0	0	0	0	0	0	73.11	0	0	11.2
2014	7	6	0	48	42	35	0	0	0	0	0	0	0	73.09	0	0	11.2
2014	7	6	0	58	42	34	0	0	0	0	0	0	0	73.09	0	0	11
2014	7	6	1	8	42	34	0	0	0	0	0	0	0	73.08	0	0	11.2
2014	7	6	1	18	42	34	0	0	0	0	0	0	0	73.08	0	0	11.2
2014	7	6	1	28	42	34	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	6	1	38	42	35	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	6	1	48	42	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	6	1	58	42	34	0	0	0	0	0	0	0	73.02	0	0	11
2014	7	6	2	8	42	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	6	2	18	42	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	6	2	28	42	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	6	2	38	42	35	0	0	0	0	0	0	0	72.95	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	2	48	42	34	0	0	0	0	0	0	0	72.95	0	0	11.2
2014	7	6	2	58	42	35	0	0	0	0	0	0	0	72.93	0	0	11.2
2014	7	6	3	8	42	34	0	0	0	0	0	0	0	72.9	0	0	11.2
2014	7	6	3	18	42	34	0	0	0	0	0	0	0	72.88	0	0	11.2
2014	7	6	3	28	42	35	0	0	0	0	0	0	0	72.86	0	0	11.2
2014	7	6	3	38	42	34	0	0	0	0	0	0	0	72.82	0	0	11
2014	7	6	3	48	42	34	0	0	0	0	0	0	0	72.81	0	0	11.2
2014	7	6	3	58	42	34	0	0	0	0	0	0	0	72.79	0	0	11.2
2014	7	6	4	8	42	35	0	0	0	0	0	0	0	72.77	0	0	11.2
2014	7	6	4	18	42	35	0	0	0	0	0	0	0	72.75	0	0	11.2
2014	7	6	4	28	42	35	0	0	0	0	0	0	0	72.73	0	0	11.2
2014	7	6	4	38	42	35	0	0	0	0	0	0	0	72.7	0	0	11
2014	7	6	4	48	42	35	0	0	0	0	0	0	0	72.68	0	0	11.4
2014	7	6	4	58	42	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	6	5	8	42	34	0	0	0	0	0	0	0	72.64	0	0	11.4
2014	7	6	5	18	42	35	0	0	0	0	0	0	0	72.64	0	0	11.4
2014	7	6	5	28	42	35	0	0	0	0	0	0	0	72.63	0	0	11.4
2014	7	6	5	38	42	34	0	0	0	0	0	0	0	72.61	0	0	11.2
2014	7	6	5	48	42	35	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	6	5	58	42	35	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	6	6	8	42	35	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	6	6	18	42	34	0	0	0	0	0	0	0	72.55	0	0	11.4
2014	7	6	6	28	42	34	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	6	6	38	42	34	0	0	0	0	0	0	0	72.54	0	0	11.2
2014	7	6	6	48	42	34	0	0	0	0	0	0	0	72.52	0	0	11.4
2014	7	6	6	58	42	34	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	8	42	34	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	18	42	35	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	28	42	35	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	38	42	35	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	48	42	34	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	7	58	42	35	0	0	0	0	0	0	0	72.5	0	0	11.4
2014	7	6	8	8	42	34	0	0	0	0	0	0	0	72.5	0	0	11.6
2014	7	6	8	18	42	35	0	0	0	0	0	0	0	72.5	0	0	11.6
2014	7	6	8	28	42	35	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	6	8	38	42	35	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	6	8	48	42	34	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	6	8	58	42	35	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	6	9	8	42	34	0	0	0	0	0	0	0	72.55	0	0	11.6
2014	7	6	9	18	42	35	0	0	0	0	0	0	0	72.55	0	0	11.6
2014	7	6	9	28	42	35	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	6	9	38	42	34	0	0	0	0	0	0	0	72.59	0	0	11.8
2014	7	6	9	48	42	34	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	6	9	58	42	35	0	0	0	0	0	0	0	72.66	0	0	12.4
2014	7	6	10	8	42	35	0	0	0	0	0	0	0	72.72	0	0	12.6
2014	7	6	10	18	42	34	0	0	0	0	0	0	0	72.72	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	10	28	42	34	0	0	0	0	0	0	0	72.72	0	0	12.4
2014	7	6	10	38	42	34	0	0	0	0	0	0	0	72.73	0	0	12.2
2014	7	6	10	48	42	34	0	0	0	0	0	0	0	72.77	0	0	12.4
2014	7	6	10	58	42	34	0	0	0	0	0	0	0	72.79	0	0	12.6
2014	7	6	11	8	42	34	0	0	0	0	0	0	0	72.81	0	0	12.6
2014	7	6	11	18	42	35	0	0	0	0	0	0	0	72.81	0	0	12.4
2014	7	6	11	28	42	35	0	0	0	0	0	0	0	72.81	0	0	12.4
2014	7	6	11	38	42	35	0	0	0	0	0	0	0	72.84	0	0	12.4
2014	7	6	11	48	42	35	0	0	0	0	0	0	0	72.9	0	0	12.8
2014	7	6	11	58	42	35	0	0	0	0	0	0	0	72.91	0	0	12.8
2014	7	6	12	8	42	35	0	0	0	0	0	0	0	72.93	0	0	12.8
2014	7	6	12	18	42	35	0	0	0	0	0	0	0	72.95	0	0	12.8
2014	7	6	12	28	42	34	0	0	0	0	0	0	0	73.04	0	0	12.8
2014	7	6	12	38	42	34	0	0	0	0	0	0	0	73.22	0	0	13
2014	7	6	12	48	42	35	0	0	0	0	0	0	0	73.24	0	0	13
2014	7	6	12	58	42	34	0	0	0	0	0	0	0	73.33	0	0	13
2014	7	6	13	8	42	34	0	0	0	0	0	0	0	73.36	0	0	13
2014	7	6	13	18	42	34	0	0	0	0	0	0	0	73.42	0	0	13
2014	7	6	13	28	42	34	0	0	0	0	0	0	0	73.45	0	0	13
2014	7	6	13	38	42	34	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	6	13	48	42	35	0	0	0	0	0	0	0	73.53	0	0	13
2014	7	6	13	58	42	34	0	0	0	0	0	0	0	73.56	0	0	13
2014	7	6	14	8	42	34	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	6	14	18	42	34	0	0	0	0	0	0	0	73.63	0	0	12.8
2014	7	6	14	28	42	34	0	0	0	0	0	0	0	73.65	0	0	12.8
2014	7	6	14	38	42	34	0	0	0	0	0	0	0	73.67	0	0	12.6
2014	7	6	14	48	42	34	0	0	0	0	0	0	0	73.69	0	0	12.8
2014	7	6	14	58	42	34	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	6	15	8	42	35	0	0	0	0	0	0	0	73.72	0	0	12.6
2014	7	6	15	18	42	35	0	0	0	0	0	0	0	73.72	0	0	12.6
2014	7	6	15	28	42	35	0	0	0	0	0	0	0	73.72	0	0	12.6
2014	7	6	15	38	42	35	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	6	15	48	42	34	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	6	15	58	42	34	0	0	0	0	0	0	0	73.69	0	0	12.2
2014	7	6	16	8	42	34	0	0	0	0	0	0	0	73.71	0	0	12.6
2014	7	6	16	18	42	34	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	6	16	28	42	34	0	0	0	0	0	0	0	73.67	0	0	12.6
2014	7	6	16	38	42	34	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	6	16	48	42	34	0	0	0	0	0	0	0	73.74	0	0	12.4
2014	7	6	16	58	42	34	0	0	0	0	0	0	0	73.67	0	0	12
2014	7	6	17	8	42	35	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	6	17	18	42	35	0	0	0	0	0	0	0	73.62	0	0	11.8
2014	7	6	17	28	42	35	0	0	0	0	0	0	0	73.62	0	0	11.8
2014	7	6	17	38	42	34	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	6	17	48	42	34	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	6	17	58	42	34	0	0	0	0	0	0	0	73.63	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	18	8	42	35	0	0	0	0	0	0	0	73.67	0	0	11.8
2014	7	6	18	18	42	34	0	0	0	0	0	0	0	73.69	0	0	11.8
2014	7	6	18	28	42	35	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	6	18	38	42	35	0	0	0	0	0	0	0	73.72	0	0	11.6
2014	7	6	18	48	42	35	0	0	0	0	0	0	0	73.72	0	0	11.8
2014	7	6	18	58	42	34	0	0	0	0	0	0	0	73.72	0	0	11.8
2014	7	6	19	8	42	34	0	0	0	0	0	0	0	73.76	0	0	11.8
2014	7	6	19	18	42	34	0	0	0	0	0	0	0	73.76	0	0	11.8
2014	7	6	19	28	42	34	0	0	0	0	0	0	0	73.78	0	0	11.8
2014	7	6	19	38	42	34	0	0	0	0	0	0	0	73.8	0	0	11.6
2014	7	6	19	48	42	34	0	0	0	0	0	0	0	73.8	0	0	11.8
2014	7	6	19	58	42	35	0	0	0	0	0	0	0	73.81	0	0	11.6
2014	7	6	20	8	42	33	0	0	0	0	0	0	0	73.83	0	0	11.6
2014	7	6	20	18	42	34	0	0	0	0	0	0	0	73.85	0	0	11.6
2014	7	6	20	28	42	34	0	0	0	0	0	0	0	73.85	0	0	11.6
2014	7	6	20	38	42	34	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	6	20	48	42	34	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	6	20	58	42	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	6	21	8	42	35	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	6	21	18	42	34	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	6	21	28	42	34	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	6	21	38	42	35	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	6	21	48	42	34	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	6	21	58	42	35	0	0	0	0	0	0	0	73.96	0	0	11.6
2014	7	6	22	8	42	34	0	0	0	0	0	0	0	73.96	0	0	11.6
2014	7	6	22	18	42	34	0	0	0	0	0	0	0	73.98	0	0	11.6
2014	7	6	22	28	42	34	0	0	0	0	0	0	0	73.98	0	0	11.6
2014	7	6	22	38	42	35	0	0	0	0	0	0	0	73.98	0	0	11.4
2014	7	6	22	48	42	35	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	6	22	58	42	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	6	23	8	42	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	6	23	18	42	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	6	23	28	42	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	6	23	38	42	35	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	6	23	48	42	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	6	23	58	42	35	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	7	0	8	42	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	7	0	18	42	35	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	7	0	28	42	33	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	7	0	38	42	34	0	0	0	0	0	0	0	74.01	0	0	11.4
2014	7	7	0	48	42	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	7	0	58	42	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	7	1	8	42	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	7	1	18	42	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	7	1	28	42	34	0	0	0	0	0	0	0	73.98	0	0	11.6
2014	7	7	1	38	42	34	0	0	0	0	0	0	0	73.98	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	1	48	42	35	0	0	0	0	0	0	0	73.98	0	0	11.6
2014	7	7	1	58	42	34	0	0	0	0	0	0	0	73.96	0	0	11.6
2014	7	7	2	8	42	34	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	7	2	18	42	34	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	7	2	28	42	34	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	7	2	38	42	34	0	0	0	0	0	0	0	73.89	0	0	11.4
2014	7	7	2	48	42	35	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	7	2	58	42	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	7	3	8	42	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	7	3	18	42	34	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	7	3	28	42	34	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	7	3	38	42	34	0	0	0	0	0	0	0	73.78	0	0	11.4
2014	7	7	3	48	42	34	0	0	0	0	0	0	0	73.76	0	0	11.6
2014	7	7	3	58	42	35	0	0	0	0	0	0	0	73.76	0	0	11.6
2014	7	7	4	8	42	34	0	0	0	0	0	0	0	73.72	0	0	11.4
2014	7	7	4	18	42	35	0	0	0	0	0	0	0	73.71	0	0	11.4
2014	7	7	4	28	42	35	0	0	0	0	0	0	0	73.69	0	0	11.4
2014	7	7	4	38	42	34	0	0	0	0	0	0	0	73.67	0	0	11.4
2014	7	7	4	48	42	34	0	0	0	0	0	0	0	73.65	0	0	11.6
2014	7	7	4	58	42	34	0	0	0	0	0	0	0	73.63	0	0	11.4
2014	7	7	5	8	42	34	0	0	0	0	0	0	0	73.62	0	0	11.4
2014	7	7	5	18	42	33	0	0	0	0	0	0	0	73.6	0	0	11.4
2014	7	7	5	28	42	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	7	5	38	42	35	0	0	0	0	0	0	0	73.56	0	0	11.4
2014	7	7	5	48	42	35	0	0	0	0	0	0	0	73.56	0	0	11.6
2014	7	7	5	58	42	35	0	0	0	0	0	0	0	73.54	0	0	11.6
2014	7	7	6	8	42	35	0	0	0	0	0	0	0	73.54	0	0	11.6
2014	7	7	6	18	42	34	0	0	0	0	0	0	0	73.53	0	0	11.6
2014	7	7	6	28	42	34	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	7	6	38	42	35	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	7	6	48	42	34	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	7	6	58	42	34	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	7	7	8	42	35	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	7	7	18	42	35	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	7	28	42	34	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	7	38	42	34	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	7	48	42	35	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	7	58	42	34	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	8	8	42	34	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	7	8	18	42	34	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	7	8	28	42	33	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	7	8	38	42	34	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	7	8	48	42	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	7	8	58	42	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	7	9	8	42	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	7	9	18	42	35	0	0	0	0	0	0	0	73.54	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	9	28	42	35	0	0	0	0	0	0	0	73.54	0	0	11.8
2014	7	7	9	38	42	35	0	0	0	0	0	0	0	73.56	0	0	11.6
2014	7	7	9	48	42	35	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	7	9	58	42	35	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	7	10	8	42	34	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	7	10	18	42	35	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	7	10	28	42	33	0	0	0	0	0	0	0	73.6	0	0	12
2014	7	7	10	38	42	34	0	0	0	0	0	0	0	73.62	0	0	11.8
2014	7	7	10	48	42	34	0	0	0	0	0	0	0	73.63	0	0	12
2014	7	7	10	58	42	34	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	7	11	8	42	34	0	0	0	0	0	0	0	73.71	0	0	12.4
2014	7	7	11	18	42	34	0	0	0	0	0	0	0	73.8	0	0	12.8
2014	7	7	11	28	42	34	0	0	0	0	0	0	0	73.81	0	0	12.8
2014	7	7	11	38	42	35	0	0	0	0	0	0	0	73.81	0	0	12.6
2014	7	7	11	48	42	34	0	0	0	0	0	0	0	73.92	0	0	12.8
2014	7	7	11	58	42	34	0	0	0	0	0	0	0	73.99	0	0	12.6
2014	7	7	12	8	42	35	0	0	0	0	0	0	0	74.16	0	0	12.6
2014	7	7	12	18	42	35	0	0	0	0	0	0	0	74.21	0	0	12.6
2014	7	7	12	28	42	34	0	0	0	0	0	0	0	74.21	0	0	12.6
2014	7	7	12	38	42	34	0	0	0	0	0	0	0	74.1	0	0	12.6
2014	7	7	12	48	42	34	0	0	0	0	0	0	0	74.17	0	0	12.8
2014	7	7	12	58	42	34	0	0	0	0	0	0	0	74.16	0	0	12.8
2014	7	7	13	8	42	34	0	0	0	0	0	0	0	74.14	0	0	12.8
2014	7	7	13	18	42	34	0	0	0	0	0	0	0	74.12	0	0	12.8
2014	7	7	13	28	42	34	0	0	0	0	0	0	0	74.12	0	0	12.6
2014	7	7	13	38	42	34	0	0	0	0	0	0	0	74.12	0	0	12.4
2014	7	7	13	48	42	34	0	0	0	0	0	0	0	74.12	0	0	12.6
2014	7	7	13	58	42	34	0	0	0	0	0	0	0	74.12	0	0	12.4
2014	7	7	14	8	42	35	0	0	0	0	0	0	0	74.12	0	0	12.2
2014	7	7	14	18	42	34	0	0	0	0	0	0	0	74.12	0	0	12.2
2014	7	7	14	28	42	34	0	0	0	0	0	0	0	74.1	0	0	12.2
2014	7	7	14	40	59	33	0	0	0	0	0	0	0	74.12	0	0	12.2
2014	7	7	14	50	59	34	0	0	0	0	0	0	0	74.12	0	0	12.4
2014	7	7	15	0	59	34	0	0	0	0	0	0	0	74.14	0	0	12.4
2014	7	7	15	10	59	34	0	0	0	0	0	0	0	74.16	0	0	12.4
2014	7	7	15	20	59	34	0	0	0	0	0	0	0	74.17	0	0	12.6
2014	7	7	15	30	59	34	0	0	0	0	0	0	0	74.19	0	0	12.6
2014	7	7	15	40	59	34	0	0	0	0	0	0	0	74.21	0	0	12.6
2014	7	7	15	50	59	34	0	0	0	0	0	0	0	74.28	0	0	13
2014	7	7	16	0	59	34	0	0	0	0	0	0	0	74.34	0	0	13
2014	7	7	16	10	59	34	0	0	0	0	0	0	0	74.41	0	0	13
2014	7	7	16	20	59	35	0	0	0	0	0	0	0	74.44	0	0	13
2014	7	7	16	30	59	34	0	0	0	0	0	0	0	74.41	0	0	12.6
2014	7	7	16	40	59	34	0	0	0	0	0	0	0	74.35	0	0	12.4
2014	7	7	16	50	59	34	0	0	0	0	0	0	0	74.34	0	0	12.2
2014	7	7	17	0	59	34	0	0	0	0	0	0	0	74.34	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	17	10	59	34	0	0	0	0	0	0	0	74.34	0	0	12
2014	7	7	17	20	59	34	0	0	0	0	0	0	0	74.34	0	0	12
2014	7	7	17	30	59	34	0	0	0	0	0	0	0	74.34	0	0	12
2014	7	7	17	40	59	34	0	0	0	0	0	0	0	74.34	0	0	12
2014	7	7	17	50	59	34	0	0	0	0	0	0	0	74.35	0	0	12
2014	7	7	18	0	59	35	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	7	18	10	59	35	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	7	18	20	59	35	0	0	0	0	0	0	0	74.37	0	0	12
2014	7	7	18	30	59	34	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	7	18	40	59	35	0	0	0	0	0	0	0	74.39	0	0	11.8
2014	7	7	18	50	59	34	0	0	0	0	0	0	0	74.39	0	0	11.8
2014	7	7	19	0	59	34	0	0	0	0	0	0	0	74.41	0	0	11.8
2014	7	7	19	10	59	34	0	0	0	0	0	0	0	74.41	0	0	11.8
2014	7	7	19	20	59	34	0	0	0	0	0	0	0	74.41	0	0	11.8
2014	7	7	19	30	59	34	0	0	0	0	0	0	0	74.43	0	0	11.8
2014	7	7	19	40	59	34	0	0	0	0	0	0	0	74.43	0	0	11.8
2014	7	7	19	50	59	34	0	0	0	0	0	0	0	74.43	0	0	11.8
2014	7	7	20	0	59	35	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	20	10	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	20	20	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	20	30	59	34	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	7	20	40	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	20	50	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	0	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	10	59	35	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	20	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	30	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	40	59	34	0	0	0	0	0	0	0	74.44	0	0	11.6
2014	7	7	21	50	59	35	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	7	22	0	59	34	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	7	22	10	59	35	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	7	22	20	59	34	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	7	22	30	59	34	0	0	0	0	0	0	0	74.41	0	0	11.6
2014	7	7	22	40	59	34	0	0	0	0	0	0	0	74.41	0	0	11.6
2014	7	7	22	50	59	34	0	0	0	0	0	0	0	74.41	0	0	11.6
2014	7	7	23	0	59	35	0	0	0	0	0	0	0	74.41	0	0	11.6
2014	7	7	23	10	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	7	23	20	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	7	23	30	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	7	23	40	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	7	23	50	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	8	0	0	59	34	0	0	0	0	0	0	0	74.37	0	0	11.6
2014	7	8	0	10	59	35	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	8	0	20	59	34	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	8	0	30	59	34	0	0	0	0	0	0	0	74.34	0	0	11.6
2014	7	8	0	40	59	34	0	0	0	0	0	0	0	74.34	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	0	50	59	34	0	0	0	0	0	0	0	74.32	0	0	11.4
2014	7	8	1	0	59	35	0	0	0	0	0	0	0	74.32	0	0	11.4
2014	7	8	1	10	59	34	0	0	0	0	0	0	0	74.3	0	0	11.4
2014	7	8	1	20	59	35	0	0	0	0	0	0	0	74.3	0	0	11.4
2014	7	8	1	30	59	35	0	0	0	0	0	0	0	74.28	0	0	11.4
2014	7	8	1	40	59	35	0	0	0	0	0	0	0	74.28	0	0	11.4
2014	7	8	1	50	59	34	0	0	0	0	0	0	0	74.26	0	0	11.4
2014	7	8	2	0	59	33	0	0	0	0	0	0	0	74.25	0	0	11.4
2014	7	8	2	10	59	34	0	0	0	0	0	0	0	74.25	0	0	11.4
2014	7	8	2	20	59	34	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	8	2	30	59	34	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	8	2	40	59	34	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	8	2	50	59	34	0	0	0	0	0	0	0	74.17	0	0	11.4
2014	7	8	3	0	59	34	0	0	0	0	0	0	0	74.16	0	0	11.4
2014	7	8	3	10	59	35	0	0	0	0	0	0	0	74.14	0	0	11.4
2014	7	8	3	20	59	34	0	0	0	0	0	0	0	74.12	0	0	11.4
2014	7	8	3	30	59	34	0	0	0	0	0	0	0	74.1	0	0	11.4
2014	7	8	3	40	59	34	0	0	0	0	0	0	0	74.1	0	0	11.4
2014	7	8	3	50	59	35	0	0	0	0	0	0	0	74.08	0	0	11.4
2014	7	8	4	0	59	34	0	0	0	0	0	0	0	74.07	0	0	11.4
2014	7	8	4	10	59	34	0	0	0	0	0	0	0	74.05	0	0	11.4
2014	7	8	4	20	59	34	0	0	0	0	0	0	0	74.03	0	0	11.4
2014	7	8	4	30	59	34	0	0	0	0	0	0	0	74.01	0	0	11.4
2014	7	8	4	40	59	35	0	0	0	0	0	0	0	73.98	0	0	11.4
2014	7	8	4	50	59	34	0	0	0	0	0	0	0	73.96	0	0	11.4
2014	7	8	5	0	59	35	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	8	5	10	59	35	0	0	0	0	0	0	0	73.92	0	0	11.4
2014	7	8	5	20	59	35	0	0	0	0	0	0	0	73.9	0	0	11.4
2014	7	8	5	30	59	34	0	0	0	0	0	0	0	73.87	0	0	11.4
2014	7	8	5	40	59	35	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	8	5	50	59	34	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	8	6	0	59	35	0	0	0	0	0	0	0	73.8	0	0	11.6
2014	7	8	6	10	59	35	0	0	0	0	0	0	0	73.78	0	0	11.6
2014	7	8	6	20	59	34	0	0	0	0	0	0	0	73.76	0	0	11.6
2014	7	8	6	30	59	35	0	0	0	0	0	0	0	73.74	0	0	11.6
2014	7	8	6	40	59	34	0	0	0	0	0	0	0	73.72	0	0	11.8
2014	7	8	6	50	59	34	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	8	7	0	59	35	0	0	0	0	0	0	0	73.69	0	0	11.8
2014	7	8	7	10	59	35	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	8	7	20	59	34	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	8	7	30	59	35	0	0	0	0	0	0	0	73.69	0	0	12.2
2014	7	8	7	40	59	34	0	0	0	0	0	0	0	73.69	0	0	12.2
2014	7	8	7	50	59	34	0	0	0	0	0	0	0	73.69	0	0	12.8
2014	7	8	8	0	59	35	0	0	0	0	0	0	0	73.72	0	0	12.8
2014	7	8	8	10	59	34	0	0	0	0	0	0	0	73.72	0	0	13
2014	7	8	8	20	59	34	0	0	0	0	0	0	0	73.74	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	8	30	59	34	0	0	0	0	0	0	0	73.74	0	0	13
2014	7	8	8	40	59	34	0	0	0	0	0	0	0	73.76	0	0	13
2014	7	8	8	50	59	35	0	0	0	0	0	0	0	73.78	0	0	13
2014	7	8	9	0	59	34	0	0	0	0	0	0	0	73.8	0	0	13
2014	7	8	9	10	59	34	0	0	0	0	0	0	0	73.81	0	0	13
2014	7	8	9	20	59	34	0	0	0	0	0	0	0	73.83	0	0	13
2014	7	8	9	30	59	34	0	0	0	0	0	0	0	73.87	0	0	13
2014	7	8	9	40	59	35	0	0	0	0	0	0	0	73.89	0	0	13
2014	7	8	9	50	59	34	0	0	0	0	0	0	0	73.92	0	0	13
2014	7	8	10	0	59	34	0	0	0	0	0	0	0	73.94	0	0	13
2014	7	8	10	10	59	34	0	0	0	0	0	0	0	73.94	0	0	12.8
2014	7	8	10	20	59	34	0	0	0	0	0	0	0	73.92	0	0	12.8
2014	7	8	10	30	59	34	0	0	0	0	0	0	0	74.01	0	0	13
2014	7	8	10	40	59	34	0	0	0	0	0	0	0	74.08	0	0	12.8
2014	7	8	10	50	59	35	0	0	0	0	0	0	0	74.05	0	0	13
2014	7	8	11	0	59	34	0	0	0	0	0	0	0	74.12	0	0	13
2014	7	8	11	10	59	35	0	0	0	0	0	0	0	74.19	0	0	13
2014	7	8	11	20	59	34	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	8	11	30	59	34	0	0	0	0	0	0	0	74.16	0	0	12.8
2014	7	8	11	40	59	34	0	0	0	0	0	0	0	74.14	0	0	12.8
2014	7	8	11	50	59	34	0	0	0	0	0	0	0	74.14	0	0	12.8
2014	7	8	12	0	59	34	0	0	0	0	0	0	0	74.12	0	0	12.8
2014	7	8	12	10	59	34	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	8	12	20	59	34	0	0	0	0	0	0	0	74.16	0	0	12.6
2014	7	8	12	30	59	34	0	0	0	0	0	0	0	74.14	0	0	12.6
2014	7	8	12	40	59	35	0	0	0	0	0	0	0	74.17	0	0	12.8
2014	7	8	12	50	59	34	0	0	0	0	0	0	0	74.23	0	0	13
2014	7	8	13	0	59	35	0	0	0	0	0	0	0	74.35	0	0	13
2014	7	8	13	10	59	35	0	0	0	0	0	0	0	74.32	0	0	13
2014	7	8	13	20	59	34	0	0	0	0	0	0	0	74.53	0	0	13.4
2014	7	8	13	30	59	34	0	0	0	0	0	0	0	74.61	0	0	13.4
2014	7	8	13	40	59	35	0	0	0	0	0	0	0	74.66	0	0	13.2
2014	7	8	13	50	59	34	0	0	0	0	0	0	0	74.7	0	0	13.4
2014	7	8	14	0	59	34	0	0	0	0	0	0	0	74.48	0	0	13
2014	7	8	14	10	59	34	0	0	0	0	0	0	0	74.44	0	0	12.8
2014	7	8	14	20	59	35	0	0	0	0	0	0	0	74.43	0	0	12.6
2014	7	8	14	30	59	34	0	0	0	0	0	0	0	74.41	0	0	12.2
2014	7	8	14	40	59	35	0	0	0	0	0	0	0	74.37	0	0	12.2
2014	7	8	14	50	59	34	0	0	0	0	0	0	0	74.35	0	0	12.2
2014	7	8	15	0	59	35	0	0	0	0	0	0	0	74.37	0	0	12.2
2014	7	8	15	10	59	34	0	0	0	0	0	0	0	74.43	0	0	13
2014	7	8	15	20	59	35	0	0	0	0	0	0	0	74.61	0	0	13.4
2014	7	8	15	30	59	34	0	0	0	0	0	0	0	74.64	0	0	12.8
2014	7	8	15	40	59	34	0	0	0	0	0	0	0	74.57	0	0	12.6
2014	7	8	15	50	59	34	0	0	0	0	0	0	0	74.55	0	0	12.6
2014	7	8	16	0	59	34	0	0	0	0	0	0	0	74.55	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	16	10	59	34	0	0	0	0	0	0	0	74.55	0	0	12.4
2014	7	8	16	20	59	34	0	0	0	0	0	0	0	74.57	0	0	12.4
2014	7	8	16	30	59	34	0	0	0	0	0	0	0	74.57	0	0	12.4
2014	7	8	16	40	59	35	0	0	0	0	0	0	0	74.59	0	0	12.6
2014	7	8	16	50	59	34	0	0	0	0	0	0	0	74.61	0	0	12.4
2014	7	8	17	0	59	34	0	0	0	0	0	0	0	74.61	0	0	12.6
2014	7	8	17	10	59	34	0	0	0	0	0	0	0	74.66	0	0	12.4
2014	7	8	17	20	59	33	0	0	0	0	0	0	0	74.68	0	0	12.4
2014	7	8	17	30	59	34	0	0	0	0	0	0	0	74.7	0	0	12.2
2014	7	8	17	40	59	35	0	0	0	0	0	0	0	74.7	0	0	12.2
2014	7	8	17	50	59	34	0	0	0	0	0	0	0	74.71	0	0	12.2
2014	7	8	18	0	59	35	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	8	18	10	59	34	0	0	0	0	0	0	0	74.73	0	0	12
2014	7	8	18	20	59	35	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	8	18	30	59	34	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	8	18	40	59	34	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	8	18	50	59	34	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	8	19	0	59	34	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	8	19	10	59	34	0	0	0	0	0	0	0	74.73	0	0	11.8
2014	7	8	19	20	59	35	0	0	0	0	0	0	0	74.73	0	0	11.8
2014	7	8	19	30	59	34	0	0	0	0	0	0	0	74.71	0	0	11.8
2014	7	8	19	40	59	34	0	0	0	0	0	0	0	74.71	0	0	11.8
2014	7	8	19	50	59	34	0	0	0	0	0	0	0	74.7	0	0	11.6
2014	7	8	20	0	59	34	0	0	0	0	0	0	0	74.7	0	0	11.6
2014	7	8	20	10	59	35	0	0	0	0	0	0	0	74.68	0	0	11.6
2014	7	8	20	20	59	34	0	0	0	0	0	0	0	74.68	0	0	11.6
2014	7	8	20	30	59	34	0	0	0	0	0	0	0	74.68	0	0	11.6
2014	7	8	20	40	59	34	0	0	0	0	0	0	0	74.66	0	0	11.8
2014	7	8	20	50	59	34	0	0	0	0	0	0	0	74.66	0	0	11.8
2014	7	8	21	0	59	34	0	0	0	0	0	0	0	74.64	0	0	11.8
2014	7	8	21	10	59	35	0	0	0	0	0	0	0	74.62	0	0	11.8
2014	7	8	21	20	59	35	0	0	0	0	0	0	0	74.62	0	0	11.8
2014	7	8	21	30	59	34	0	0	0	0	0	0	0	74.62	0	0	11.6
2014	7	8	21	40	59	34	0	0	0	0	0	0	0	74.61	0	0	11.8
2014	7	8	21	50	59	34	0	0	0	0	0	0	0	74.59	0	0	11.8
2014	7	8	22	0	59	34	0	0	0	0	0	0	0	74.57	0	0	11.8
2014	7	8	22	10	59	34	0	0	0	0	0	0	0	74.57	0	0	11.8
2014	7	8	22	20	59	34	0	0	0	0	0	0	0	74.55	0	0	11.8
2014	7	8	22	30	59	34	0	0	0	0	0	0	0	74.55	0	0	11.8
2014	7	8	22	40	59	34	0	0	0	0	0	0	0	74.53	0	0	11.6
2014	7	8	22	50	59	34	0	0	0	0	0	0	0	74.52	0	0	11.6
2014	7	8	23	0	59	34	0	0	0	0	0	0	0	74.5	0	0	11.6
2014	7	8	23	10	59	34	0	0	0	0	0	0	0	74.48	0	0	11.6
2014	7	8	23	20	59	35	0	0	0	0	0	0	0	74.48	0	0	11.6
2014	7	8	23	30	59	35	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	8	23	40	59	33	0	0	0	0	0	0	0	74.44	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	23	50	59	33	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	9	0	0	59	34	0	0	0	0	0	0	0	74.41	0	0	11.6
2014	7	9	0	10	59	34	0	0	0	0	0	0	0	74.39	0	0	11.6
2014	7	9	0	20	59	35	0	0	0	0	0	0	0	74.37	0	0	11.6
2014	7	9	0	30	59	35	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	9	0	40	59	35	0	0	0	0	0	0	0	74.34	0	0	11.6
2014	7	9	0	50	59	35	0	0	0	0	0	0	0	74.32	0	0	11.4
2014	7	9	1	0	59	34	0	0	0	0	0	0	0	74.28	0	0	11.4
2014	7	9	1	10	59	34	0	0	0	0	0	0	0	74.26	0	0	11.4
2014	7	9	1	20	59	34	0	0	0	0	0	0	0	74.25	0	0	11.4
2014	7	9	1	30	59	34	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	9	1	40	59	34	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	9	1	50	59	34	0	0	0	0	0	0	0	74.16	0	0	11.4
2014	7	9	2	0	59	35	0	0	0	0	0	0	0	74.14	0	0	11.4
2014	7	9	2	10	59	34	0	0	0	0	0	0	0	74.1	0	0	11.4
2014	7	9	2	20	59	33	0	0	0	0	0	0	0	74.07	0	0	11.4
2014	7	9	2	30	59	34	0	0	0	0	0	0	0	74.05	0	0	11.4
2014	7	9	2	40	59	34	0	0	0	0	0	0	0	74.01	0	0	11.4
2014	7	9	2	50	59	34	0	0	0	0	0	0	0	73.99	0	0	11.4
2014	7	9	3	0	59	34	0	0	0	0	0	0	0	73.98	0	0	11.4
2014	7	9	3	10	59	35	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	9	3	20	59	34	0	0	0	0	0	0	0	73.92	0	0	11.4
2014	7	9	3	30	59	34	0	0	0	0	0	0	0	73.89	0	0	11.4
2014	7	9	3	40	59	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	9	3	50	59	34	0	0	0	0	0	0	0	73.83	0	0	11.4
2014	7	9	4	0	59	34	0	0	0	0	0	0	0	73.8	0	0	11.4
2014	7	9	4	10	59	34	0	0	0	0	0	0	0	73.78	0	0	11.4
2014	7	9	4	20	59	34	0	0	0	0	0	0	0	73.74	0	0	11.4
2014	7	9	4	30	59	34	0	0	0	0	0	0	0	73.71	0	0	11.4
2014	7	9	4	40	59	34	0	0	0	0	0	0	0	73.69	0	0	11.4
2014	7	9	4	50	59	34	0	0	0	0	0	0	0	73.69	0	0	11.4
2014	7	9	5	0	59	34	0	0	0	0	0	0	0	73.65	0	0	11.4
2014	7	9	5	10	59	34	0	0	0	0	0	0	0	73.62	0	0	11.4
2014	7	9	5	20	59	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	9	5	30	59	34	0	0	0	0	0	0	0	73.56	0	0	11.4
2014	7	9	5	40	59	35	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	9	5	50	59	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	9	6	0	59	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	9	6	10	59	35	0	0	0	0	0	0	0	73.44	0	0	11.4
2014	7	9	6	20	59	34	0	0	0	0	0	0	0	73.42	0	0	11.4
2014	7	9	6	30	59	34	0	0	0	0	0	0	0	73.38	0	0	11.4
2014	7	9	6	40	59	35	0	0	0	0	0	0	0	73.36	0	0	11.6
2014	7	9	6	50	59	35	0	0	0	0	0	0	0	73.35	0	0	11.8
2014	7	9	7	0	59	35	0	0	0	0	0	0	0	73.33	0	0	11.8
2014	7	9	7	10	59	35	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	9	7	20	59	34	0	0	0	0	0	0	0	73.33	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	7	30	59	34	0	0	0	0	0	0	0	73.33	0	0	12.2
2014	7	9	7	40	59	34	0	0	0	0	0	0	0	73.33	0	0	12.4
2014	7	9	7	50	59	34	0	0	0	0	0	0	0	73.33	0	0	12.6
2014	7	9	8	0	59	34	0	0	0	0	0	0	0	73.35	0	0	12.8
2014	7	9	8	10	59	34	0	0	0	0	0	0	0	73.35	0	0	12.8
2014	7	9	8	20	59	34	0	0	0	0	0	0	0	73.36	0	0	13
2014	7	9	8	30	59	34	0	0	0	0	0	0	0	73.38	0	0	13
2014	7	9	8	40	59	35	0	0	0	0	0	0	0	73.4	0	0	13
2014	7	9	8	50	59	34	0	0	0	0	0	0	0	73.42	0	0	13
2014	7	9	9	0	59	34	0	0	0	0	0	0	0	73.44	0	0	13
2014	7	9	9	10	59	34	0	0	0	0	0	0	0	73.47	0	0	13
2014	7	9	9	20	59	35	0	0	0	0	0	0	0	73.51	0	0	13
2014	7	9	9	30	59	34	0	0	0	0	0	0	0	73.51	0	0	12.8
2014	7	9	9	40	59	34	0	0	0	0	0	0	0	73.54	0	0	12.8
2014	7	9	9	50	59	34	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	9	10	0	59	34	0	0	0	0	0	0	0	73.62	0	0	12.8
2014	7	9	10	10	59	34	0	0	0	0	0	0	0	73.65	0	0	13
2014	7	9	10	20	59	34	0	0	0	0	0	0	0	73.67	0	0	13
2014	7	9	10	30	59	34	0	0	0	0	0	0	0	73.67	0	0	13
2014	7	9	10	40	59	34	0	0	0	0	0	0	0	73.71	0	0	13
2014	7	9	10	50	59	34	0	0	0	0	0	0	0	73.72	0	0	13
2014	7	9	11	0	59	34	0	0	0	0	0	0	0	73.8	0	0	13
2014	7	9	11	10	59	34	0	0	0	0	0	0	0	73.83	0	0	13
2014	7	9	11	20	59	34	0	0	0	0	0	0	0	73.89	0	0	13
2014	7	9	11	30	59	34	0	0	0	0	0	0	0	73.92	0	0	13
2014	7	9	11	40	59	34	0	0	0	0	0	0	0	73.94	0	0	13
2014	7	9	11	50	59	34	0	0	0	0	0	0	0	73.98	0	0	13
2014	7	9	12	0	59	34	0	0	0	0	0	0	0	74.01	0	0	13
2014	7	9	12	10	59	34	0	0	0	0	0	0	0	74.08	0	0	13
2014	7	9	12	20	59	34	0	0	0	0	0	0	0	74.14	0	0	13
2014	7	9	12	30	59	34	0	0	0	0	0	0	0	74.19	0	0	13
2014	7	9	12	40	59	35	0	0	0	0	0	0	0	74.19	0	0	13
2014	7	9	12	50	59	34	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	9	13	0	59	33	0	0	0	0	0	0	0	74.28	0	0	12.8
2014	7	9	13	10	59	35	0	0	0	0	0	0	0	74.32	0	0	13
2014	7	9	13	20	59	34	0	0	0	0	0	0	0	74.37	0	0	13
2014	7	9	13	30	59	35	0	0	0	0	0	0	0	74.43	0	0	12.8
2014	7	9	13	40	59	34	0	0	0	0	0	0	0	74.48	0	0	12.8
2014	7	9	13	50	59	34	0	0	0	0	0	0	0	74.48	0	0	13
2014	7	9	14	0	59	34	0	0	0	0	0	0	0	74.55	0	0	13
2014	7	9	14	10	59	35	0	0	0	0	0	0	0	74.44	0	0	12.2
2014	7	9	14	20	59	34	0	0	0	0	0	0	0	74.35	0	0	12.4
2014	7	9	14	30	59	34	0	0	0	0	0	0	0	74.59	0	0	12.8
2014	7	9	14	40	59	34	0	0	0	0	0	0	0	74.53	0	0	12.4
2014	7	9	14	50	59	35	0	0	0	0	0	0	0	74.57	0	0	12.8
2014	7	9	15	0	59	34	0	0	0	0	0	0	0	74.52	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	15	10	59	34	0	0	0	0	0	0	0	74.46	0	0	12.6
2014	7	9	15	20	59	34	0	0	0	0	0	0	0	74.59	0	0	12.8
2014	7	9	15	30	59	34	0	0	0	0	0	0	0	74.61	0	0	12.6
2014	7	9	15	40	59	34	0	0	0	0	0	0	0	74.57	0	0	12.6
2014	7	9	15	50	59	34	0	0	0	0	0	0	0	74.61	0	0	12.6
2014	7	9	16	0	59	34	0	0	0	0	0	0	0	74.59	0	0	12.6
2014	7	9	16	10	59	34	0	0	0	0	0	0	0	74.59	0	0	12
2014	7	9	16	20	59	35	0	0	0	0	0	0	0	74.64	0	0	12.6
2014	7	9	16	30	59	34	0	0	0	0	0	0	0	74.66	0	0	12.6
2014	7	9	16	40	59	34	0	0	0	0	0	0	0	74.7	0	0	12.4
2014	7	9	16	50	59	34	0	0	0	0	0	0	0	74.71	0	0	12.2
2014	7	9	17	0	59	34	0	0	0	0	0	0	0	74.73	0	0	12.2
2014	7	9	17	10	59	34	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	9	17	20	59	34	0	0	0	0	0	0	0	74.7	0	0	12
2014	7	9	17	30	59	34	0	0	0	0	0	0	0	74.75	0	0	12
2014	7	9	17	40	59	34	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	9	17	50	59	34	0	0	0	0	0	0	0	74.79	0	0	12
2014	7	9	18	0	59	34	0	0	0	0	0	0	0	74.8	0	0	12
2014	7	9	18	10	59	34	0	0	0	0	0	0	0	74.82	0	0	12
2014	7	9	18	20	59	34	0	0	0	0	0	0	0	74.82	0	0	11.8
2014	7	9	18	30	59	34	0	0	0	0	0	0	0	74.84	0	0	11.8
2014	7	9	18	40	59	33	0	0	0	0	0	0	0	74.88	0	0	11.8
2014	7	9	18	50	59	34	0	0	0	0	0	0	0	74.89	0	0	11.8
2014	7	9	19	0	59	34	0	0	0	0	0	0	0	74.91	0	0	11.8
2014	7	9	19	10	59	34	0	0	0	0	0	0	0	74.93	0	0	11.8
2014	7	9	19	20	59	34	0	0	0	0	0	0	0	74.93	0	0	11.8
2014	7	9	19	30	59	34	0	0	0	0	0	0	0	74.95	0	0	11.8
2014	7	9	19	40	59	34	0	0	0	0	0	0	0	74.95	0	0	11.8
2014	7	9	19	50	59	34	0	0	0	0	0	0	0	74.98	0	0	11.8
2014	7	9	20	0	59	34	0	0	0	0	0	0	0	75	0	0	11.6
2014	7	9	20	10	59	34	0	0	0	0	0	0	0	74.98	0	0	11.6
2014	7	9	20	20	59	34	0	0	0	0	0	0	0	75.02	0	0	11.6
2014	7	9	20	30	59	34	0	0	0	0	0	0	0	75.02	0	0	11.6
2014	7	9	20	40	59	34	0	0	0	0	0	0	0	75.04	0	0	11.6
2014	7	9	20	50	59	34	0	0	0	0	0	0	0	75.06	0	0	11.6
2014	7	9	21	0	59	34	0	0	0	0	0	0	0	75.06	0	0	11.6
2014	7	9	21	10	59	34	0	0	0	0	0	0	0	75.07	0	0	11.6
2014	7	9	21	20	59	34	0	0	0	0	0	0	0	75.07	0	0	11.6
2014	7	9	21	30	59	34	0	0	0	0	0	0	0	75.09	0	0	11.6
2014	7	9	21	40	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	21	50	59	33	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	22	0	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	22	10	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	22	20	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	22	30	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6
2014	7	9	22	40	59	34	0	0	0	0	0	0	0	75.11	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	22	50	59	34	0	0	0	0	0	0	0	75.09	0	0	11.6
2014	7	9	23	0	59	34	0	0	0	0	0	0	0	75.07	0	0	11.6
2014	7	9	23	10	59	34	0	0	0	0	0	0	0	75.07	0	0	11.6
2014	7	9	23	20	59	35	0	0	0	0	0	0	0	75.06	0	0	11.6
2014	7	9	23	30	59	34	0	0	0	0	0	0	0	75.06	0	0	11.6
2014	7	9	23	40	59	34	0	0	0	0	0	0	0	75.04	0	0	11.4
2014	7	9	23	50	59	34	0	0	0	0	0	0	0	75.02	0	0	11.4
2014	7	10	0	0	59	34	0	0	0	0	0	0	0	75	0	0	11.4
2014	7	10	0	10	59	35	0	0	0	0	0	0	0	74.97	0	0	11.4
2014	7	10	0	20	59	35	0	0	0	0	0	0	0	74.97	0	0	11.4
2014	7	10	0	30	59	35	0	0	0	0	0	0	0	74.95	0	0	11.4
2014	7	10	0	40	59	34	0	0	0	0	0	0	0	74.93	0	0	11.4
2014	7	10	0	50	59	34	0	0	0	0	0	0	0	74.91	0	0	11.4
2014	7	10	1	0	59	33	0	0	0	0	0	0	0	74.88	0	0	11.4
2014	7	10	1	10	59	34	0	0	0	0	0	0	0	74.86	0	0	11.4
2014	7	10	1	20	59	34	0	0	0	0	0	0	0	74.82	0	0	11.4
2014	7	10	1	30	59	34	0	0	0	0	0	0	0	74.8	0	0	11.4
2014	7	10	1	40	59	33	0	0	0	0	0	0	0	74.79	0	0	11.4
2014	7	10	1	50	59	34	0	0	0	0	0	0	0	74.75	0	0	11.4
2014	7	10	2	0	59	34	0	0	0	0	0	0	0	74.71	0	0	11.4
2014	7	10	2	10	59	34	0	0	0	0	0	0	0	74.68	0	0	11.4
2014	7	10	2	20	59	34	0	0	0	0	0	0	0	74.66	0	0	11.4
2014	7	10	2	30	59	34	0	0	0	0	0	0	0	74.62	0	0	11.4
2014	7	10	2	40	59	35	0	0	0	0	0	0	0	74.59	0	0	11.4
2014	7	10	2	50	59	34	0	0	0	0	0	0	0	74.55	0	0	11.4
2014	7	10	3	0	59	34	0	0	0	0	0	0	0	74.53	0	0	11.4
2014	7	10	3	10	59	34	0	0	0	0	0	0	0	74.5	0	0	11.2
2014	7	10	3	20	59	33	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	10	3	30	59	34	0	0	0	0	0	0	0	74.41	0	0	11.2
2014	7	10	3	40	59	34	0	0	0	0	0	0	0	74.37	0	0	11.2
2014	7	10	3	50	59	34	0	0	0	0	0	0	0	74.34	0	0	11.2
2014	7	10	4	0	59	34	0	0	0	0	0	0	0	74.3	0	0	11.2
2014	7	10	4	10	59	34	0	0	0	0	0	0	0	74.26	0	0	11.2
2014	7	10	4	20	59	35	0	0	0	0	0	0	0	74.23	0	0	11.2
2014	7	10	4	30	59	34	0	0	0	0	0	0	0	74.19	0	0	11.2
2014	7	10	4	40	59	34	0	0	0	0	0	0	0	74.16	0	0	11.4
2014	7	10	4	50	59	34	0	0	0	0	0	0	0	74.12	0	0	11.2
2014	7	10	5	0	59	34	0	0	0	0	0	0	0	74.08	0	0	11.2
2014	7	10	5	10	59	35	0	0	0	0	0	0	0	74.05	0	0	11.2
2014	7	10	5	20	59	34	0	0	0	0	0	0	0	74.03	0	0	11.2
2014	7	10	5	30	59	34	0	0	0	0	0	0	0	73.99	0	0	11.2
2014	7	10	5	40	59	35	0	0	0	0	0	0	0	73.98	0	0	11.2
2014	7	10	5	50	59	35	0	0	0	0	0	0	0	73.94	0	0	11.2
2014	7	10	6	0	59	34	0	0	0	0	0	0	0	73.9	0	0	11.2
2014	7	10	6	10	59	34	0	0	0	0	0	0	0	73.89	0	0	11.2
2014	7	10	6	20	59	34	0	0	0	0	0	0	0	73.87	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	6	30	59	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	10	6	40	59	35	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	10	6	50	59	34	0	0	0	0	0	0	0	73.78	0	0	11.4
2014	7	10	7	0	59	34	0	0	0	0	0	0	0	73.76	0	0	11.4
2014	7	10	7	10	59	35	0	0	0	0	0	0	0	73.76	0	0	11.8
2014	7	10	7	20	59	34	0	0	0	0	0	0	0	73.74	0	0	12
2014	7	10	7	30	59	34	0	0	0	0	0	0	0	73.74	0	0	12.2
2014	7	10	7	40	59	34	0	0	0	0	0	0	0	73.74	0	0	12.4
2014	7	10	7	50	59	34	0	0	0	0	0	0	0	73.74	0	0	12.4
2014	7	10	8	0	59	35	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	10	8	10	59	33	0	0	0	0	0	0	0	73.76	0	0	12.8
2014	7	10	8	20	59	34	0	0	0	0	0	0	0	73.78	0	0	12.8
2014	7	10	8	30	59	34	0	0	0	0	0	0	0	73.8	0	0	12.8
2014	7	10	8	40	59	34	0	0	0	0	0	0	0	73.81	0	0	12.8
2014	7	10	8	50	59	35	0	0	0	0	0	0	0	73.83	0	0	12.8
2014	7	10	9	0	59	34	0	0	0	0	0	0	0	73.85	0	0	12.8
2014	7	10	9	10	59	35	0	0	0	0	0	0	0	73.89	0	0	12.8
2014	7	10	9	20	59	34	0	0	0	0	0	0	0	73.92	0	0	12.8
2014	7	10	9	30	59	34	0	0	0	0	0	0	0	73.94	0	0	12.6
2014	7	10	9	40	59	34	0	0	0	0	0	0	0	73.92	0	0	12.6
2014	7	10	9	50	59	34	0	0	0	0	0	0	0	73.98	0	0	12
2014	7	10	10	0	59	34	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	10	10	10	59	33	0	0	0	0	0	0	0	74.07	0	0	11.8
2014	7	10	10	20	59	34	0	0	0	0	0	0	0	74.08	0	0	11.8
2014	7	10	10	30	59	34	0	0	0	0	0	0	0	74.08	0	0	11.8
2014	7	10	10	40	59	34	0	0	0	0	0	0	0	74.14	0	0	12.6
2014	7	10	10	50	59	34	0	0	0	0	0	0	0	74.17	0	0	12.6
2014	7	10	11	0	59	34	0	0	0	0	0	0	0	74.23	0	0	12.6
2014	7	10	11	10	59	34	0	0	0	0	0	0	0	74.25	0	0	12.8
2014	7	10	11	20	59	34	0	0	0	0	0	0	0	74.14	0	0	12.8
2014	7	10	11	30	59	34	0	0	0	0	0	0	0	74.28	0	0	13
2014	7	10	11	40	59	34	0	0	0	0	0	0	0	74.35	0	0	13
2014	7	10	11	50	59	34	0	0	0	0	0	0	0	74.3	0	0	11.6
2014	7	10	12	0	59	34	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	10	12	10	59	34	0	0	0	0	0	0	0	74.43	0	0	11.8
2014	7	10	12	20	59	35	0	0	0	0	0	0	0	74.5	0	0	11.6
2014	7	10	12	30	59	34	0	0	0	0	0	0	0	74.52	0	0	11.6
2014	7	10	12	40	59	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	10	12	50	59	34	0	0	0	0	0	0	0	74.57	0	0	13
2014	7	10	13	0	59	34	0	0	0	0	0	0	0	74.61	0	0	13
2014	7	10	13	10	59	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	10	13	20	59	35	0	0	0	0	0	0	0	74.46	0	0	12.8
2014	7	10	13	30	59	34	0	0	0	0	0	0	0	74.61	0	0	13
2014	7	10	13	40	59	34	0	0	0	0	0	0	0	74.52	0	0	13
2014	7	10	13	50	59	34	0	0	0	0	0	0	0	74.46	0	0	13
2014	7	10	14	0	59	34	0	0	0	0	0	0	0	74.66	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	14	10	59	34	0	0	0	0	0	0	0	74.66	0	0	13
2014	7	10	14	20	59	34	0	0	0	0	0	0	0	74.59	0	0	13
2014	7	10	14	30	59	34	0	0	0	0	0	0	0	74.46	0	0	13
2014	7	10	14	40	59	34	0	0	0	0	0	0	0	74.52	0	0	13
2014	7	10	14	50	59	34	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	10	15	0	59	34	0	0	0	0	0	0	0	74.44	0	0	12.8
2014	7	10	15	10	59	34	0	0	0	0	0	0	0	74.43	0	0	12.8
2014	7	10	15	20	59	34	0	0	0	0	0	0	0	74.39	0	0	12.8
2014	7	10	15	30	59	34	0	0	0	0	0	0	0	74.43	0	0	12.8
2014	7	10	15	40	59	34	0	0	0	0	0	0	0	74.43	0	0	12.8
2014	7	10	15	50	59	33	0	0	0	0	0	0	0	74.44	0	0	12.8
2014	7	10	16	0	59	34	0	0	0	0	0	0	0	74.48	0	0	13
2014	7	10	16	10	59	34	0	0	0	0	0	0	0	74.5	0	0	13
2014	7	10	16	20	59	34	0	0	0	0	0	0	0	74.52	0	0	13
2014	7	10	16	30	59	34	0	0	0	0	0	0	0	74.48	0	0	12.4
2014	7	10	16	40	59	34	0	0	0	0	0	0	0	74.48	0	0	12.4
2014	7	10	16	50	59	34	0	0	0	0	0	0	0	74.48	0	0	12.2
2014	7	10	17	0	59	34	0	0	0	0	0	0	0	74.48	0	0	12
2014	7	10	17	10	59	34	0	0	0	0	0	0	0	74.46	0	0	12
2014	7	10	17	20	59	34	0	0	0	0	0	0	0	74.44	0	0	12
2014	7	10	17	30	59	34	0	0	0	0	0	0	0	74.43	0	0	12
2014	7	10	17	40	59	34	0	0	0	0	0	0	0	74.41	0	0	12
2014	7	10	17	50	59	34	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	10	18	0	59	34	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	10	18	10	59	35	0	0	0	0	0	0	0	74.39	0	0	12
2014	7	10	18	20	59	34	0	0	0	0	0	0	0	74.37	0	0	11.8
2014	7	10	18	30	59	34	0	0	0	0	0	0	0	74.37	0	0	11.8
2014	7	10	18	40	59	35	0	0	0	0	0	0	0	74.37	0	0	11.6
2014	7	10	18	50	59	34	0	0	0	0	0	0	0	74.37	0	0	11.6
2014	7	10	19	0	59	34	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	10	19	10	59	35	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	10	19	20	59	34	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	10	19	30	59	34	0	0	0	0	0	0	0	74.35	0	0	11.6
2014	7	10	19	40	59	34	0	0	0	0	0	0	0	74.34	0	0	11.8
2014	7	10	19	50	59	35	0	0	0	0	0	0	0	74.34	0	0	11.8
2014	7	10	20	0	59	34	0	0	0	0	0	0	0	74.34	0	0	11.6
2014	7	10	20	10	59	34	0	0	0	0	0	0	0	74.32	0	0	11.6
2014	7	10	20	20	59	34	0	0	0	0	0	0	0	74.32	0	0	11.6
2014	7	10	20	30	59	35	0	0	0	0	0	0	0	74.32	0	0	11.6
2014	7	10	20	40	59	34	0	0	0	0	0	0	0	74.3	0	0	11.6
2014	7	10	20	50	59	34	0	0	0	0	0	0	0	74.28	0	0	11.4
2014	7	10	21	0	59	34	0	0	0	0	0	0	0	74.26	0	0	11.4
2014	7	10	21	10	59	34	0	0	0	0	0	0	0	74.26	0	0	11.6
2014	7	10	21	20	59	35	0	0	0	0	0	0	0	74.25	0	0	11.6
2014	7	10	21	30	59	35	0	0	0	0	0	0	0	74.23	0	0	11.6
2014	7	10	21	40	59	34	0	0	0	0	0	0	0	74.21	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	21	50	59	34	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	10	22	0	59	35	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	10	22	10	59	34	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	10	22	20	59	35	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	10	22	30	59	34	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	10	22	40	59	34	0	0	0	0	0	0	0	74.19	0	0	11.4
2014	7	10	22	50	59	34	0	0	0	0	0	0	0	74.17	0	0	11.4
2014	7	10	23	0	59	33	0	0	0	0	0	0	0	74.16	0	0	11.4
2014	7	10	23	10	59	34	0	0	0	0	0	0	0	74.16	0	0	11.4
2014	7	10	23	20	59	34	0	0	0	0	0	0	0	74.14	0	0	11.4
2014	7	10	23	30	59	34	0	0	0	0	0	0	0	74.14	0	0	11.4
2014	7	10	23	40	59	34	0	0	0	0	0	0	0	74.12	0	0	11.4
2014	7	10	23	50	59	34	0	0	0	0	0	0	0	74.12	0	0	11
2014	7	11	0	0	59	35	0	0	0	0	0	0	0	74.1	0	0	11
2014	7	11	0	10	59	35	0	0	0	0	0	0	0	74.1	0	0	11
2014	7	11	0	20	59	34	0	0	0	0	0	0	0	74.08	0	0	11
2014	7	11	0	30	59	35	0	0	0	0	0	0	0	74.07	0	0	11
2014	7	11	0	40	59	34	0	0	0	0	0	0	0	74.05	0	0	11.2
2014	7	11	0	50	59	35	0	0	0	0	0	0	0	74.05	0	0	11
2014	7	11	1	0	59	35	0	0	0	0	0	0	0	74.03	0	0	11
2014	7	11	1	10	59	34	0	0	0	0	0	0	0	73.99	0	0	11
2014	7	11	1	20	59	34	0	0	0	0	0	0	0	73.99	0	0	11.2
2014	7	11	1	30	59	34	0	0	0	0	0	0	0	73.98	0	0	11.2
2014	7	11	1	40	59	34	0	0	0	0	0	0	0	73.94	0	0	11
2014	7	11	1	50	59	34	0	0	0	0	0	0	0	73.92	0	0	11.2
2014	7	11	2	0	59	34	0	0	0	0	0	0	0	73.89	0	0	11
2014	7	11	2	10	59	34	0	0	0	0	0	0	0	73.89	0	0	11.2
2014	7	11	2	20	59	35	0	0	0	0	0	0	0	73.87	0	0	11.2
2014	7	11	2	30	59	34	0	0	0	0	0	0	0	73.83	0	0	11.2
2014	7	11	2	40	59	34	0	0	0	0	0	0	0	73.81	0	0	11
2014	7	11	2	50	59	35	0	0	0	0	0	0	0	73.78	0	0	11
2014	7	11	3	0	59	34	0	0	0	0	0	0	0	73.76	0	0	11
2014	7	11	3	10	59	34	0	0	0	0	0	0	0	73.72	0	0	11
2014	7	11	3	20	59	34	0	0	0	0	0	0	0	73.71	0	0	11
2014	7	11	3	30	59	35	0	0	0	0	0	0	0	73.67	0	0	11
2014	7	11	3	40	59	34	0	0	0	0	0	0	0	73.63	0	0	11.2
2014	7	11	3	50	59	34	0	0	0	0	0	0	0	73.6	0	0	11
2014	7	11	4	0	59	34	0	0	0	0	0	0	0	73.58	0	0	11.2
2014	7	11	4	10	59	34	0	0	0	0	0	0	0	73.53	0	0	11.2
2014	7	11	4	20	59	35	0	0	0	0	0	0	0	73.49	0	0	11.2
2014	7	11	4	30	59	34	0	0	0	0	0	0	0	73.47	0	0	11.2
2014	7	11	4	40	59	34	0	0	0	0	0	0	0	73.44	0	0	11.2
2014	7	11	4	50	59	35	0	0	0	0	0	0	0	73.4	0	0	11.2
2014	7	11	5	0	59	34	0	0	0	0	0	0	0	73.36	0	0	11.2
2014	7	11	5	10	59	35	0	0	0	0	0	0	0	73.33	0	0	11.2
2014	7	11	5	20	59	34	0	0	0	0	0	0	0	73.31	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	5	30	59	35	0	0	0	0	0	0	0	73.27	0	0	11.2
2014	7	11	5	40	59	34	0	0	0	0	0	0	0	73.26	0	0	11.2
2014	7	11	5	50	59	34	0	0	0	0	0	0	0	73.22	0	0	11.2
2014	7	11	6	0	59	34	0	0	0	0	0	0	0	73.2	0	0	11.2
2014	7	11	6	10	59	35	0	0	0	0	0	0	0	73.18	0	0	11.2
2014	7	11	6	20	59	34	0	0	0	0	0	0	0	73.15	0	0	11.2
2014	7	11	6	30	59	34	0	0	0	0	0	0	0	73.13	0	0	11.2
2014	7	11	6	40	59	34	0	0	0	0	0	0	0	73.11	0	0	11.2
2014	7	11	6	50	59	35	0	0	0	0	0	0	0	73.09	0	0	11.6
2014	7	11	7	0	59	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	11	7	10	59	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	11	7	20	59	34	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	11	7	30	59	34	0	0	0	0	0	0	0	73.09	0	0	12.2
2014	7	11	7	40	59	33	0	0	0	0	0	0	0	73.11	0	0	12.4
2014	7	11	7	50	59	34	0	0	0	0	0	0	0	73.11	0	0	12.4
2014	7	11	8	0	59	34	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	11	8	10	59	35	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	11	8	20	59	34	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	11	8	30	59	34	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	11	8	40	59	35	0	0	0	0	0	0	0	73.04	0	0	11.8
2014	7	11	8	50	59	34	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	11	9	0	59	35	0	0	0	0	0	0	0	73.08	0	0	12.6
2014	7	11	9	10	59	34	0	0	0	0	0	0	0	73.08	0	0	12.2
2014	7	11	9	20	59	34	0	0	0	0	0	0	0	73.15	0	0	12.6
2014	7	11	9	30	59	34	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	11	9	40	59	35	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	11	9	50	59	35	0	0	0	0	0	0	0	73.27	0	0	12.8
2014	7	11	10	0	59	34	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	11	10	10	59	34	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	11	10	20	59	34	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	11	10	30	59	35	0	0	0	0	0	0	0	73.33	0	0	12.8
2014	7	11	10	40	59	34	0	0	0	0	0	0	0	73.36	0	0	12.6
2014	7	11	10	50	59	35	0	0	0	0	0	0	0	73.36	0	0	12.6
2014	7	11	11	0	59	34	0	0	0	0	0	0	0	73.42	0	0	12.8
2014	7	11	11	10	59	34	0	0	0	0	0	0	0	73.47	0	0	12.8
2014	7	11	11	20	59	34	0	0	0	0	0	0	0	73.47	0	0	12.8
2014	7	11	11	30	59	34	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	11	11	40	59	34	0	0	0	0	0	0	0	73.53	0	0	12.8
2014	7	11	11	50	59	34	0	0	0	0	0	0	0	73.56	0	0	12.8
2014	7	11	12	0	59	34	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	11	12	10	59	35	0	0	0	0	0	0	0	73.62	0	0	12.8
2014	7	11	12	20	59	34	0	0	0	0	0	0	0	73.65	0	0	13
2014	7	11	12	30	59	34	0	0	0	0	0	0	0	73.69	0	0	13
2014	7	11	12	40	59	34	0	0	0	0	0	0	0	73.71	0	0	13
2014	7	11	12	50	59	35	0	0	0	0	0	0	0	73.76	0	0	13
2014	7	11	13	0	59	35	0	0	0	0	0	0	0	73.8	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	13	10	59	34	0	0	0	0	0	0	0	73.85	0	0	13
2014	7	11	13	20	59	35	0	0	0	0	0	0	0	73.89	0	0	13
2014	7	11	13	30	59	34	0	0	0	0	0	0	0	73.89	0	0	13
2014	7	11	13	40	59	34	0	0	0	0	0	0	0	73.96	0	0	13
2014	7	11	13	50	59	34	0	0	0	0	0	0	0	73.99	0	0	13
2014	7	11	14	0	59	34	0	0	0	0	0	0	0	73.99	0	0	13
2014	7	11	14	10	59	34	0	0	0	0	0	0	0	74.01	0	0	13
2014	7	11	14	20	59	34	0	0	0	0	0	0	0	73.99	0	0	13
2014	7	11	14	30	59	34	0	0	0	0	0	0	0	74.03	0	0	13
2014	7	11	14	40	59	34	0	0	0	0	0	0	0	74.03	0	0	13
2014	7	11	14	50	59	35	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	15	0	59	35	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	15	10	59	34	0	0	0	0	0	0	0	74.07	0	0	12.8
2014	7	11	15	20	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	15	30	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	15	40	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	15	50	59	35	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	16	0	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	16	10	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	16	20	59	34	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	11	16	30	59	33	0	0	0	0	0	0	0	74.05	0	0	12.6
2014	7	11	16	40	59	34	0	0	0	0	0	0	0	74.03	0	0	12.4
2014	7	11	16	50	59	34	0	0	0	0	0	0	0	74.03	0	0	12.2
2014	7	11	17	0	59	35	0	0	0	0	0	0	0	74.03	0	0	12
2014	7	11	17	10	59	34	0	0	0	0	0	0	0	74.03	0	0	11.8
2014	7	11	17	20	59	34	0	0	0	0	0	0	0	74.01	0	0	11.8
2014	7	11	17	30	59	35	0	0	0	0	0	0	0	74.01	0	0	11.8
2014	7	11	17	40	59	34	0	0	0	0	0	0	0	73.99	0	0	11.8
2014	7	11	17	50	59	34	0	0	0	0	0	0	0	73.99	0	0	11.8
2014	7	11	18	0	59	35	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	11	18	10	59	35	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	11	18	20	59	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	11	18	30	59	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	11	18	40	59	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	11	18	50	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	0	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	10	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	20	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	30	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	40	59	35	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	19	50	59	33	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	20	0	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	20	10	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	20	20	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	20	30	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6
2014	7	11	20	40	59	34	0	0	0	0	0	0	0	74.03	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	20	50	59	34	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	11	21	0	59	35	0	0	0	0	0	0	0	74.01	0	0	11.6
2014	7	11	21	10	59	34	0	0	0	0	0	0	0	73.99	0	0	11.6
2014	7	11	21	20	59	34	0	0	0	0	0	0	0	73.99	0	0	11.4
2014	7	11	21	30	59	35	0	0	0	0	0	0	0	73.98	0	0	11.4
2014	7	11	21	40	59	34	0	0	0	0	0	0	0	73.98	0	0	11.4
2014	7	11	21	50	59	33	0	0	0	0	0	0	0	73.96	0	0	11.4
2014	7	11	22	0	59	33	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	11	22	10	59	35	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	11	22	20	59	34	0	0	0	0	0	0	0	73.92	0	0	11.4
2014	7	11	22	30	59	34	0	0	0	0	0	0	0	73.92	0	0	11.4
2014	7	11	22	40	59	35	0	0	0	0	0	0	0	73.9	0	0	11.4
2014	7	11	22	50	59	34	0	0	0	0	0	0	0	73.89	0	0	11.4
2014	7	11	23	0	59	34	0	0	0	0	0	0	0	73.87	0	0	11.4
2014	7	11	23	10	59	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	11	23	20	59	34	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	11	23	30	59	35	0	0	0	0	0	0	0	73.8	0	0	11.4
2014	7	11	23	40	59	34	0	0	0	0	0	0	0	73.78	0	0	11.4
2014	7	11	23	50	59	34	0	0	0	0	0	0	0	73.76	0	0	11.4
2014	7	12	0	0	59	34	0	0	0	0	0	0	0	73.72	0	0	11.4
2014	7	12	0	10	59	34	0	0	0	0	0	0	0	73.71	0	0	11.4
2014	7	12	0	20	59	34	0	0	0	0	0	0	0	73.67	0	0	11.4
2014	7	12	0	30	59	34	0	0	0	0	0	0	0	73.67	0	0	11.4
2014	7	12	0	40	59	34	0	0	0	0	0	0	0	73.62	0	0	11.4
2014	7	12	0	50	59	34	0	0	0	0	0	0	0	73.6	0	0	11.4
2014	7	12	1	0	59	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	12	1	10	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	12	1	20	59	34	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	12	1	30	59	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	12	1	40	59	34	0	0	0	0	0	0	0	73.44	0	0	11.4
2014	7	12	1	50	59	35	0	0	0	0	0	0	0	73.4	0	0	11.4
2014	7	12	2	0	59	34	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	12	2	10	59	34	0	0	0	0	0	0	0	73.33	0	0	11.4
2014	7	12	2	20	59	34	0	0	0	0	0	0	0	73.27	0	0	11.4
2014	7	12	2	30	59	34	0	0	0	0	0	0	0	73.26	0	0	11.4
2014	7	12	2	40	59	34	0	0	0	0	0	0	0	73.18	0	0	11.4
2014	7	12	2	50	59	34	0	0	0	0	0	0	0	73.17	0	0	11.4
2014	7	12	3	0	59	34	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	12	3	10	59	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	12	3	20	59	34	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	12	3	30	59	34	0	0	0	0	0	0	0	72.99	0	0	11.4
2014	7	12	3	40	59	34	0	0	0	0	0	0	0	72.95	0	0	11.4
2014	7	12	3	50	59	34	0	0	0	0	0	0	0	72.9	0	0	11.4
2014	7	12	4	0	59	35	0	0	0	0	0	0	0	72.86	0	0	11.4
2014	7	12	4	10	59	34	0	0	0	0	0	0	0	72.82	0	0	11.4
2014	7	12	4	20	59	34	0	0	0	0	0	0	0	72.77	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	4	30	59	34	0	0	0	0	0	0	0	72.72	0	0	11.4
2014	7	12	4	40	59	34	0	0	0	0	0	0	0	72.68	0	0	11.4
2014	7	12	4	50	59	34	0	0	0	0	0	0	0	72.63	0	0	11.2
2014	7	12	5	0	59	34	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	12	5	10	59	34	0	0	0	0	0	0	0	72.55	0	0	11.2
2014	7	12	5	20	59	34	0	0	0	0	0	0	0	72.48	0	0	11.2
2014	7	12	5	30	59	35	0	0	0	0	0	0	0	72.45	0	0	11.2
2014	7	12	5	40	59	34	0	0	0	0	0	0	0	72.41	0	0	11.2
2014	7	12	5	50	59	34	0	0	0	0	0	0	0	72.37	0	0	11.2
2014	7	12	6	0	59	35	0	0	0	0	0	0	0	72.34	0	0	11.2
2014	7	12	6	10	59	35	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	12	6	20	59	34	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	12	6	30	59	35	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	12	6	40	59	34	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	12	6	50	59	34	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	12	7	0	59	34	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	12	7	10	59	34	0	0	0	0	0	0	0	72.12	0	0	12
2014	7	12	7	20	59	34	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	12	7	30	59	34	0	0	0	0	0	0	0	72.09	0	0	12.2
2014	7	12	7	40	59	34	0	0	0	0	0	0	0	72.09	0	0	12.4
2014	7	12	7	50	59	34	0	0	0	0	0	0	0	72.09	0	0	12.6
2014	7	12	8	0	59	34	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	12	8	10	59	34	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	12	8	20	59	35	0	0	0	0	0	0	0	72.09	0	0	13
2014	7	12	8	30	59	34	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	12	8	40	59	34	0	0	0	0	0	0	0	72.12	0	0	12.8
2014	7	12	8	50	59	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	12	9	0	59	35	0	0	0	0	0	0	0	72.16	0	0	12.8
2014	7	12	9	10	59	35	0	0	0	0	0	0	0	72.18	0	0	12.8
2014	7	12	9	20	59	34	0	0	0	0	0	0	0	72.19	0	0	12.8
2014	7	12	9	30	59	34	0	0	0	0	0	0	0	72.21	0	0	12.8
2014	7	12	9	40	59	34	0	0	0	0	0	0	0	72.25	0	0	12.8
2014	7	12	9	50	59	34	0	0	0	0	0	0	0	72.28	0	0	12.6
2014	7	12	10	0	59	34	0	0	0	0	0	0	0	72.3	0	0	12.6
2014	7	12	10	10	59	34	0	0	0	0	0	0	0	72.34	0	0	12.6
2014	7	12	10	20	59	35	0	0	0	0	0	0	0	72.37	0	0	12.4
2014	7	12	10	30	59	34	0	0	0	0	0	0	0	72.39	0	0	12.4
2014	7	12	10	40	59	34	0	0	0	0	0	0	0	72.34	0	0	12.6
2014	7	12	10	50	59	35	0	0	0	0	0	0	0	72.43	0	0	12.8
2014	7	12	11	0	59	34	0	0	0	0	0	0	0	72.5	0	0	12.8
2014	7	12	11	10	59	35	0	0	0	0	0	0	0	72.55	0	0	12.8
2014	7	12	11	20	59	34	0	0	0	0	0	0	0	72.61	0	0	12.8
2014	7	12	11	30	59	35	0	0	0	0	0	0	0	72.64	0	0	12.8
2014	7	12	11	40	59	34	0	0	0	0	0	0	0	72.66	0	0	12.6
2014	7	12	11	50	59	34	0	0	0	0	0	0	0	72.72	0	0	12.2
2014	7	12	12	0	59	35	0	0	0	0	0	0	0	72.75	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	12	10	59	35	0	0	0	0	0	0	0	72.79	0	0	12.2
2014	7	12	12	20	59	34	0	0	0	0	0	0	0	72.82	0	0	12.2
2014	7	12	12	30	59	35	0	0	0	0	0	0	0	72.86	0	0	12
2014	7	12	12	40	59	35	0	0	0	0	0	0	0	72.91	0	0	12.8
2014	7	12	12	50	59	34	0	0	0	0	0	0	0	72.97	0	0	12.8
2014	7	12	13	0	59	34	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	12	13	10	59	34	0	0	0	0	0	0	0	73.09	0	0	12.8
2014	7	12	13	20	59	34	0	0	0	0	0	0	0	73.11	0	0	12.8
2014	7	12	13	30	59	34	0	0	0	0	0	0	0	73.17	0	0	12.8
2014	7	12	13	40	59	35	0	0	0	0	0	0	0	73.18	0	0	12.8
2014	7	12	13	50	59	34	0	0	0	0	0	0	0	73.2	0	0	12.8
2014	7	12	14	0	59	35	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	12	14	10	59	34	0	0	0	0	0	0	0	73.27	0	0	12.8
2014	7	12	14	20	59	35	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	12	14	30	59	34	0	0	0	0	0	0	0	73.33	0	0	12.8
2014	7	12	14	40	59	34	0	0	0	0	0	0	0	73.33	0	0	12.8
2014	7	12	14	50	59	34	0	0	0	0	0	0	0	73.35	0	0	12.8
2014	7	12	15	0	59	34	0	0	0	0	0	0	0	73.36	0	0	12.8
2014	7	12	15	10	59	34	0	0	0	0	0	0	0	73.36	0	0	12.8
2014	7	12	15	20	59	34	0	0	0	0	0	0	0	73.36	0	0	12.8
2014	7	12	15	30	59	35	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	7	12	15	40	59	34	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	7	12	15	50	59	34	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	7	12	16	0	59	35	0	0	0	0	0	0	0	73.44	0	0	12.6
2014	7	12	16	10	59	34	0	0	0	0	0	0	0	73.44	0	0	12.6
2014	7	12	16	20	59	34	0	0	0	0	0	0	0	73.44	0	0	12.6
2014	7	12	16	30	59	34	0	0	0	0	0	0	0	73.45	0	0	12.6
2014	7	12	16	40	59	34	0	0	0	0	0	0	0	73.45	0	0	12.6
2014	7	12	16	50	59	34	0	0	0	0	0	0	0	73.45	0	0	12.4
2014	7	12	17	0	59	34	0	0	0	0	0	0	0	73.45	0	0	12.2
2014	7	12	17	10	59	34	0	0	0	0	0	0	0	73.49	0	0	12
2014	7	12	17	20	59	35	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	12	17	30	59	34	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	12	17	40	59	34	0	0	0	0	0	0	0	73.47	0	0	12
2014	7	12	17	50	59	34	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	12	18	0	59	33	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	12	18	10	59	34	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	12	18	20	59	35	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	12	18	30	59	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	12	18	40	59	34	0	0	0	0	0	0	0	73.54	0	0	11.8
2014	7	12	18	50	59	35	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	12	19	0	59	34	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	12	19	10	59	34	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	12	19	20	59	34	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	12	19	30	59	34	0	0	0	0	0	0	0	73.58	0	0	11.6
2014	7	12	19	40	59	35	0	0	0	0	0	0	0	73.6	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	19	50	59	34	0	0	0	0	0	0	0	73.6	0	0	11.6
2014	7	12	20	0	59	34	0	0	0	0	0	0	0	73.6	0	0	11.6
2014	7	12	20	10	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	20	20	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	20	30	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	20	40	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	20	50	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	21	0	59	34	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	12	21	10	59	34	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	12	21	20	59	34	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	12	21	30	59	35	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	12	21	40	59	34	0	0	0	0	0	0	0	73.63	0	0	11.6
2014	7	12	21	50	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	22	0	59	35	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	22	10	59	34	0	0	0	0	0	0	0	73.62	0	0	11.6
2014	7	12	22	20	59	34	0	0	0	0	0	0	0	73.6	0	0	11.6
2014	7	12	22	30	59	35	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	12	22	40	59	35	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	12	22	50	59	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	12	23	0	59	34	0	0	0	0	0	0	0	73.56	0	0	11.4
2014	7	12	23	10	59	35	0	0	0	0	0	0	0	73.54	0	0	11.4
2014	7	12	23	20	59	34	0	0	0	0	0	0	0	73.54	0	0	11.4
2014	7	12	23	30	59	35	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	12	23	40	59	34	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	12	23	50	59	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	13	0	0	59	35	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	13	0	10	59	35	0	0	0	0	0	0	0	73.45	0	0	11.4
2014	7	13	0	20	59	34	0	0	0	0	0	0	0	73.42	0	0	11.4
2014	7	13	0	30	59	34	0	0	0	0	0	0	0	73.4	0	0	11.4
2014	7	13	0	40	59	35	0	0	0	0	0	0	0	73.38	0	0	11.4
2014	7	13	0	50	59	34	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	13	1	0	59	33	0	0	0	0	0	0	0	73.33	0	0	11.4
2014	7	13	1	10	59	34	0	0	0	0	0	0	0	73.31	0	0	11.4
2014	7	13	1	20	59	34	0	0	0	0	0	0	0	73.27	0	0	11.4
2014	7	13	1	30	59	34	0	0	0	0	0	0	0	73.24	0	0	11.4
2014	7	13	1	40	59	34	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	13	1	50	59	35	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	13	2	0	59	34	0	0	0	0	0	0	0	73.15	0	0	11.4
2014	7	13	2	10	59	34	0	0	0	0	0	0	0	73.13	0	0	11.4
2014	7	13	2	20	59	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	13	2	30	59	34	0	0	0	0	0	0	0	73.06	0	0	11.4
2014	7	13	2	40	59	34	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	13	2	50	59	34	0	0	0	0	0	0	0	72.97	0	0	11.4
2014	7	13	3	0	59	34	0	0	0	0	0	0	0	72.93	0	0	11.4
2014	7	13	3	10	59	34	0	0	0	0	0	0	0	72.9	0	0	11.4
2014	7	13	3	20	59	35	0	0	0	0	0	0	0	72.84	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	3	30	59	34	0	0	0	0	0	0	0	72.81	0	0	11.2
2014	7	13	3	40	59	34	0	0	0	0	0	0	0	72.75	0	0	11.2
2014	7	13	3	50	59	34	0	0	0	0	0	0	0	72.72	0	0	11.2
2014	7	13	4	0	59	34	0	0	0	0	0	0	0	72.68	0	0	11.2
2014	7	13	4	10	59	34	0	0	0	0	0	0	0	72.63	0	0	11.2
2014	7	13	4	20	59	34	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	13	4	30	59	33	0	0	0	0	0	0	0	72.54	0	0	11.2
2014	7	13	4	40	59	34	0	0	0	0	0	0	0	72.48	0	0	11.2
2014	7	13	4	50	59	35	0	0	0	0	0	0	0	72.45	0	0	11.2
2014	7	13	5	0	59	34	0	0	0	0	0	0	0	72.39	0	0	11.2
2014	7	13	5	10	59	34	0	0	0	0	0	0	0	72.36	0	0	11.2
2014	7	13	5	20	59	34	0	0	0	0	0	0	0	72.32	0	0	11.2
2014	7	13	5	30	59	34	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	13	5	40	59	34	0	0	0	0	0	0	0	72.25	0	0	11
2014	7	13	5	50	59	34	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	13	6	0	59	34	0	0	0	0	0	0	0	72.14	0	0	11.2
2014	7	13	6	10	59	35	0	0	0	0	0	0	0	72.1	0	0	11.2
2014	7	13	6	20	59	34	0	0	0	0	0	0	0	72.07	0	0	11.2
2014	7	13	6	30	59	35	0	0	0	0	0	0	0	72.03	0	0	11.2
2014	7	13	6	40	59	34	0	0	0	0	0	0	0	72	0	0	11.4
2014	7	13	6	50	59	34	0	0	0	0	0	0	0	71.96	0	0	11.4
2014	7	13	7	0	59	33	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	13	7	10	59	34	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	13	7	20	59	35	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	13	7	30	59	34	0	0	0	0	0	0	0	71.91	0	0	12.2
2014	7	13	7	40	59	34	0	0	0	0	0	0	0	71.89	0	0	12.2
2014	7	13	7	50	59	35	0	0	0	0	0	0	0	71.89	0	0	12.6
2014	7	13	8	0	59	34	0	0	0	0	0	0	0	71.89	0	0	12.6
2014	7	13	8	10	59	35	0	0	0	0	0	0	0	71.89	0	0	12.8
2014	7	13	8	20	59	34	0	0	0	0	0	0	0	71.91	0	0	12.8
2014	7	13	8	30	59	34	0	0	0	0	0	0	0	71.94	0	0	12.8
2014	7	13	8	40	59	34	0	0	0	0	0	0	0	71.94	0	0	13
2014	7	13	8	50	59	34	0	0	0	0	0	0	0	71.96	0	0	12.8
2014	7	13	9	0	59	35	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	13	9	10	59	34	0	0	0	0	0	0	0	72.01	0	0	12.8
2014	7	13	9	20	59	35	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	13	9	30	59	34	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	13	9	40	59	34	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	13	9	50	59	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	13	10	0	59	34	0	0	0	0	0	0	0	72.16	0	0	12.6
2014	7	13	10	10	59	34	0	0	0	0	0	0	0	72.16	0	0	12.6
2014	7	13	10	20	59	34	0	0	0	0	0	0	0	72.18	0	0	12.6
2014	7	13	10	30	59	34	0	0	0	0	0	0	0	72.19	0	0	12.6
2014	7	13	10	40	59	34	0	0	0	0	0	0	0	72.16	0	0	12.6
2014	7	13	10	50	59	34	0	0	0	0	0	0	0	72.27	0	0	12.6
2014	7	13	11	0	59	34	0	0	0	0	0	0	0	72.34	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	11	10	59	35	0	0	0	0	0	0	0	72.39	0	0	12.6
2014	7	13	11	20	59	34	0	0	0	0	0	0	0	72.45	0	0	12.6
2014	7	13	11	30	59	34	0	0	0	0	0	0	0	72.48	0	0	12.6
2014	7	13	11	40	59	34	0	0	0	0	0	0	0	72.5	0	0	12.6
2014	7	13	11	50	59	34	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	13	12	0	59	35	0	0	0	0	0	0	0	72.61	0	0	12.6
2014	7	13	12	10	59	34	0	0	0	0	0	0	0	72.64	0	0	12.6
2014	7	13	12	20	59	35	0	0	0	0	0	0	0	72.68	0	0	12.6
2014	7	13	12	30	59	34	0	0	0	0	0	0	0	72.7	0	0	12.6
2014	7	13	12	40	59	34	0	0	0	0	0	0	0	72.72	0	0	12.6
2014	7	13	12	50	59	35	0	0	0	0	0	0	0	72.81	0	0	12.6
2014	7	13	13	0	59	34	0	0	0	0	0	0	0	72.86	0	0	12.6
2014	7	13	13	10	59	35	0	0	0	0	0	0	0	72.91	0	0	12.6
2014	7	13	13	20	59	34	0	0	0	0	0	0	0	72.95	0	0	12.6
2014	7	13	13	30	59	34	0	0	0	0	0	0	0	73	0	0	12.6
2014	7	13	13	40	59	35	0	0	0	0	0	0	0	73.02	0	0	12.6
2014	7	13	13	50	59	34	0	0	0	0	0	0	0	73.04	0	0	12.6
2014	7	13	14	0	59	35	0	0	0	0	0	0	0	73.08	0	0	12.6
2014	7	13	14	10	59	34	0	0	0	0	0	0	0	73.09	0	0	12.6
2014	7	13	14	20	59	34	0	0	0	0	0	0	0	73.13	0	0	12.6
2014	7	13	14	30	59	34	0	0	0	0	0	0	0	73.13	0	0	12.6
2014	7	13	14	40	59	35	0	0	0	0	0	0	0	73.17	0	0	12.6
2014	7	13	14	50	59	34	0	0	0	0	0	0	0	73.18	0	0	12.6
2014	7	13	15	0	59	35	0	0	0	0	0	0	0	73.18	0	0	12.6
2014	7	13	15	10	59	34	0	0	0	0	0	0	0	73.2	0	0	12.6
2014	7	13	15	20	59	34	0	0	0	0	0	0	0	73.2	0	0	12.6
2014	7	13	15	30	59	35	0	0	0	0	0	0	0	73.22	0	0	12.6
2014	7	13	15	40	59	35	0	0	0	0	0	0	0	73.24	0	0	12.6
2014	7	13	15	50	59	34	0	0	0	0	0	0	0	73.24	0	0	12.6
2014	7	13	16	0	59	34	0	0	0	0	0	0	0	73.24	0	0	12.6
2014	7	13	16	10	59	35	0	0	0	0	0	0	0	73.26	0	0	12.6
2014	7	13	16	20	59	34	0	0	0	0	0	0	0	73.26	0	0	12.6
2014	7	13	16	30	59	34	0	0	0	0	0	0	0	73.27	0	0	12.6
2014	7	13	16	40	59	35	0	0	0	0	0	0	0	73.27	0	0	12.2
2014	7	13	16	50	59	34	0	0	0	0	0	0	0	73.27	0	0	12.2
2014	7	13	17	0	59	34	0	0	0	0	0	0	0	73.29	0	0	12.2
2014	7	13	17	10	59	34	0	0	0	0	0	0	0	73.27	0	0	12
2014	7	13	17	20	59	34	0	0	0	0	0	0	0	73.27	0	0	12
2014	7	13	17	30	59	35	0	0	0	0	0	0	0	73.29	0	0	12
2014	7	13	17	40	59	34	0	0	0	0	0	0	0	73.29	0	0	12
2014	7	13	17	50	59	34	0	0	0	0	0	0	0	73.29	0	0	12
2014	7	13	18	0	59	35	0	0	0	0	0	0	0	73.31	0	0	12
2014	7	13	18	10	59	34	0	0	0	0	0	0	0	73.33	0	0	12
2014	7	13	18	20	59	34	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	13	18	30	59	34	0	0	0	0	0	0	0	73.35	0	0	12
2014	7	13	18	40	59	35	0	0	0	0	0	0	0	73.38	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	18	50	59	34	0	0	0	0	0	0	0	73.4	0	0	12
2014	7	13	19	0	59	34	0	0	0	0	0	0	0	73.4	0	0	12
2014	7	13	19	10	59	34	0	0	0	0	0	0	0	73.42	0	0	12
2014	7	13	19	20	59	34	0	0	0	0	0	0	0	73.42	0	0	12
2014	7	13	19	30	59	35	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	13	19	40	59	35	0	0	0	0	0	0	0	73.45	0	0	11.2
2014	7	13	19	50	59	34	0	0	0	0	0	0	0	73.45	0	0	10.8
2014	7	13	20	0	59	34	0	0	0	0	0	0	0	73.47	0	0	10.4
2014	7	13	20	10	59	35	0	0	0	0	0	0	0	73.49	0	0	10.4
2014	7	13	20	20	59	34	0	0	0	0	0	0	0	73.49	0	0	10.4
2014	7	13	20	30	59	34	0	0	0	0	0	0	0	73.49	0	0	10.2
2014	7	13	20	40	59	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	13	20	50	59	35	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	13	21	0	59	35	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	21	10	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	21	20	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	21	30	59	33	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	21	40	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	21	50	59	34	0	0	0	0	0	0	0	73.54	0	0	11.8
2014	7	13	22	0	59	35	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	22	10	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	22	20	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	22	30	59	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	13	22	40	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	22	50	59	35	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	23	0	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	23	10	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	23	20	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	23	30	59	34	0	0	0	0	0	0	0	73.53	0	0	11.4
2014	7	13	23	40	59	35	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	13	23	50	59	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	14	0	0	59	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	14	0	10	59	34	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	14	0	20	59	34	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	14	0	30	59	34	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	14	0	40	59	35	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	14	0	50	59	34	0	0	0	0	0	0	0	73.45	0	0	11.8
2014	7	14	1	0	59	35	0	0	0	0	0	0	0	73.44	0	0	11.8
2014	7	14	1	10	59	35	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	14	1	20	59	34	0	0	0	0	0	0	0	73.4	0	0	11.8
2014	7	14	1	30	59	35	0	0	0	0	0	0	0	73.4	0	0	11.8
2014	7	14	1	40	59	34	0	0	0	0	0	0	0	73.36	0	0	11.8
2014	7	14	1	50	59	34	0	0	0	0	0	0	0	73.35	0	0	11.8
2014	7	14	2	0	59	34	0	0	0	0	0	0	0	73.33	0	0	11.8
2014	7	14	2	10	59	34	0	0	0	0	0	0	0	73.31	0	0	11.8
2014	7	14	2	20	59	34	0	0	0	0	0	0	0	73.27	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	2	30	59	35	0	0	0	0	0	0	0	73.26	0	0	11.8
2014	7	14	2	40	59	34	0	0	0	0	0	0	0	73.24	0	0	11.8
2014	7	14	2	50	59	35	0	0	0	0	0	0	0	73.2	0	0	11.8
2014	7	14	3	0	59	35	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	3	10	59	34	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	3	20	59	34	0	0	0	0	0	0	0	73.13	0	0	11.8
2014	7	14	3	30	59	35	0	0	0	0	0	0	0	73.11	0	0	11.8
2014	7	14	3	40	59	35	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	14	3	50	59	34	0	0	0	0	0	0	0	73.04	0	0	11.8
2014	7	14	4	0	59	35	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	14	4	10	59	34	0	0	0	0	0	0	0	73	0	0	11.6
2014	7	14	4	20	59	34	0	0	0	0	0	0	0	72.97	0	0	11.6
2014	7	14	4	30	59	35	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	14	4	40	59	35	0	0	0	0	0	0	0	72.91	0	0	11.6
2014	7	14	4	50	59	34	0	0	0	0	0	0	0	72.9	0	0	11.6
2014	7	14	5	0	59	34	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	14	5	10	59	35	0	0	0	0	0	0	0	72.84	0	0	11.6
2014	7	14	5	20	59	35	0	0	0	0	0	0	0	72.82	0	0	11.6
2014	7	14	5	30	59	34	0	0	0	0	0	0	0	72.79	0	0	11.6
2014	7	14	5	40	59	34	0	0	0	0	0	0	0	72.77	0	0	11.6
2014	7	14	5	50	59	35	0	0	0	0	0	0	0	72.75	0	0	11.6
2014	7	14	6	0	59	35	0	0	0	0	0	0	0	72.73	0	0	11.6
2014	7	14	6	10	59	34	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	14	6	20	59	34	0	0	0	0	0	0	0	72.7	0	0	11.6
2014	7	14	6	30	59	34	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	14	6	40	59	34	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	14	6	50	59	35	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	14	7	0	59	35	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	14	7	10	59	34	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	14	7	20	59	35	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	7	30	59	34	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	7	40	59	34	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	14	7	50	59	35	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	8	0	59	34	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	8	10	59	35	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	8	20	59	34	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	14	8	30	59	35	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	14	8	40	59	34	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	14	8	50	59	34	0	0	0	0	0	0	0	72.68	0	0	12
2014	7	14	9	0	59	34	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	14	9	10	59	34	0	0	0	0	0	0	0	72.73	0	0	12.2
2014	7	14	9	20	59	35	0	0	0	0	0	0	0	72.72	0	0	12
2014	7	14	9	30	59	35	0	0	0	0	0	0	0	72.77	0	0	12.2
2014	7	14	9	40	59	35	0	0	0	0	0	0	0	72.88	0	0	12.6
2014	7	14	9	50	59	35	0	0	0	0	0	0	0	72.88	0	0	12.4
2014	7	14	10	0	59	35	0	0	0	0	0	0	0	72.82	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	10	10	59	34	0	0	0	0	0	0	0	72.9	0	0	12.4
2014	7	14	10	20	59	34	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	7	14	10	30	59	35	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	14	10	40	59	34	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	14	10	50	59	35	0	0	0	0	0	0	0	72.84	0	0	12.2
2014	7	14	11	0	59	34	0	0	0	0	0	0	0	72.99	0	0	12.6
2014	7	14	11	10	59	34	0	0	0	0	0	0	0	72.95	0	0	12.4
2014	7	14	11	20	59	34	0	0	0	0	0	0	0	73.04	0	0	12.8
2014	7	14	11	30	59	34	0	0	0	0	0	0	0	72.97	0	0	12.4
2014	7	14	11	40	59	34	0	0	0	0	0	0	0	72.99	0	0	12.6
2014	7	14	11	50	59	34	0	0	0	0	0	0	0	73.06	0	0	12.8
2014	7	14	12	0	59	34	0	0	0	0	0	0	0	73.15	0	0	13
2014	7	14	12	10	59	34	0	0	0	0	0	0	0	73.2	0	0	12.2
2014	7	14	12	20	59	34	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	14	12	30	59	34	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	12	40	59	33	0	0	0	0	0	0	0	73.17	0	0	12.8
2014	7	14	12	50	59	34	0	0	0	0	0	0	0	73.18	0	0	12.8
2014	7	14	13	0	59	34	0	0	0	0	0	0	0	73.13	0	0	12.6
2014	7	14	13	10	59	34	0	0	0	0	0	0	0	73.09	0	0	12.4
2014	7	14	13	20	59	33	0	0	0	0	0	0	0	73.09	0	0	12.6
2014	7	14	13	30	59	34	0	0	0	0	0	0	0	73.15	0	0	11.6
2014	7	14	13	40	59	34	0	0	0	0	0	0	0	73.11	0	0	12.6
2014	7	14	13	50	59	35	0	0	0	0	0	0	0	73.08	0	0	12.4
2014	7	14	14	0	59	34	0	0	0	0	0	0	0	73.08	0	0	12.4
2014	7	14	14	10	59	34	0	0	0	0	0	0	0	73.04	0	0	12.4
2014	7	14	14	20	59	34	0	0	0	0	0	0	0	73.08	0	0	12.4
2014	7	14	14	30	59	34	0	0	0	0	0	0	0	73.08	0	0	12.6
2014	7	14	14	40	59	34	0	0	0	0	0	0	0	73.08	0	0	12.6
2014	7	14	14	50	59	34	0	0	0	0	0	0	0	73.09	0	0	12.8
2014	7	14	15	10	27	34	0	0	0	0	0	0	0	73.08	0	0	12.6
2014	7	14	15	20	27	35	0	0	0	0	0	0	0	73.08	0	0	12.4
2014	7	14	15	30	27	34	0	0	0	0	0	0	0	73.06	0	0	12.6
2014	7	14	15	40	27	34	0	0	0	0	0	0	0	73.08	0	0	12.4
2014	7	14	15	50	27	34	0	0	0	0	0	0	0	73.15	0	0	13.2
2014	7	14	16	0	27	34	0	0	0	0	0	0	0	73.17	0	0	13
2014	7	14	16	10	27	34	0	0	0	0	0	0	0	73.13	0	0	12.8
2014	7	14	16	20	27	34	0	0	0	0	0	0	0	73.11	0	0	12.6
2014	7	14	16	30	27	34	0	0	0	0	0	0	0	73.13	0	0	12.6
2014	7	14	16	40	27	34	0	0	0	0	0	0	0	73.15	0	0	12.6
2014	7	14	16	50	27	34	0	0	0	0	0	0	0	73.2	0	0	12.8
2014	7	14	17	0	27	34	0	0	0	0	0	0	0	73.18	0	0	12.6
2014	7	14	17	10	27	34	0	0	0	0	0	0	0	73.17	0	0	12.2
2014	7	14	17	20	27	35	0	0	0	0	0	0	0	73.18	0	0	12.2
2014	7	14	17	30	27	34	0	0	0	0	0	0	0	73.18	0	0	12.2
2014	7	14	17	40	27	35	0	0	0	0	0	0	0	73.18	0	0	12.2
2014	7	14	17	50	27	34	0	0	0	0	0	0	0	73.18	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	18	0	27	35	0	0	0	0	0	0	0	73.17	0	0	12
2014	7	14	18	10	27	34	0	0	0	0	0	0	0	73.17	0	0	12
2014	7	14	18	20	27	34	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	18	30	27	34	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	18	40	27	34	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	18	50	27	34	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	19	0	27	35	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	19	10	27	35	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	14	19	20	27	34	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	19	30	27	34	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	19	40	27	35	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	19	50	27	33	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	20	0	27	34	0	0	0	0	0	0	0	73.17	0	0	11.6
2014	7	14	20	10	27	34	0	0	0	0	0	0	0	73.18	0	0	11.6
2014	7	14	20	20	27	34	0	0	0	0	0	0	0	73.18	0	0	11.4
2014	7	14	20	30	27	34	0	0	0	0	0	0	0	73.18	0	0	11.6
2014	7	14	20	40	27	34	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	20	50	27	34	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	21	0	27	35	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	21	10	27	34	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	21	20	27	35	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	21	30	27	35	0	0	0	0	0	0	0	73.18	0	0	11.6
2014	7	14	21	40	27	34	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	14	21	50	27	34	0	0	0	0	0	0	0	73.18	0	0	11.6
2014	7	14	22	0	27	34	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	14	22	10	27	35	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	14	22	20	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	14	22	30	27	34	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	14	22	40	27	34	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	14	22	50	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	14	23	0	27	34	0	0	0	0	0	0	0	73.2	0	0	11.6
2014	7	14	23	10	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	14	23	20	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	14	23	30	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	14	23	40	27	34	0	0	0	0	0	0	0	73.24	0	0	11.6
2014	7	14	23	50	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	0	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	10	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	20	27	35	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	30	27	33	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	40	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	0	50	27	34	0	0	0	0	0	0	0	73.24	0	0	11.6
2014	7	15	1	0	27	34	0	0	0	0	0	0	0	73.24	0	0	11.6
2014	7	15	1	10	27	34	0	0	0	0	0	0	0	73.24	0	0	11.4
2014	7	15	1	20	27	35	0	0	0	0	0	0	0	73.24	0	0	11.4
2014	7	15	1	30	27	34	0	0	0	0	0	0	0	73.24	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	1	40	27	35	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	1	50	27	34	0	0	0	0	0	0	0	73.22	0	0	11.6
2014	7	15	2	0	27	34	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	15	2	10	27	35	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	15	2	20	27	34	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	15	2	30	27	35	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	15	2	40	27	34	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	15	2	50	27	34	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	15	3	0	27	35	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	15	3	10	27	34	0	0	0	0	0	0	0	73.18	0	0	11.4
2014	7	15	3	20	27	34	0	0	0	0	0	0	0	73.17	0	0	11.4
2014	7	15	3	30	27	35	0	0	0	0	0	0	0	73.15	0	0	11.4
2014	7	15	3	40	27	34	0	0	0	0	0	0	0	73.15	0	0	11.4
2014	7	15	3	50	27	34	0	0	0	0	0	0	0	73.13	0	0	11.4
2014	7	15	4	0	27	34	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	15	4	10	27	33	0	0	0	0	0	0	0	73.11	0	0	11.4
2014	7	15	4	20	27	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	15	4	30	27	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	15	4	40	27	35	0	0	0	0	0	0	0	73.08	0	0	10.8
2014	7	15	4	50	27	34	0	0	0	0	0	0	0	73.06	0	0	10.8
2014	7	15	5	0	27	34	0	0	0	0	0	0	0	73.04	0	0	10.8
2014	7	15	5	10	27	34	0	0	0	0	0	0	0	73.04	0	0	10.8
2014	7	15	5	20	27	35	0	0	0	0	0	0	0	73.04	0	0	10.8
2014	7	15	5	30	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	15	5	40	27	35	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	15	5	50	27	35	0	0	0	0	0	0	0	73	0	0	11.4
2014	7	15	6	0	27	35	0	0	0	0	0	0	0	73	0	0	11.4
2014	7	15	6	10	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	6	20	27	35	0	0	0	0	0	0	0	73	0	0	11.6
2014	7	15	6	30	27	34	0	0	0	0	0	0	0	73	0	0	11.6
2014	7	15	6	40	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	6	50	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	7	0	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	7	10	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	7	20	27	34	0	0	0	0	0	0	0	72.99	0	0	11.6
2014	7	15	7	30	27	34	0	0	0	0	0	0	0	72.97	0	0	11.4
2014	7	15	7	40	27	34	0	0	0	0	0	0	0	72.95	0	0	11.4
2014	7	15	7	50	27	34	0	0	0	0	0	0	0	72.95	0	0	11.4
2014	7	15	8	0	27	34	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	15	8	10	27	34	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	15	8	20	27	35	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	15	8	30	27	35	0	0	0	0	0	0	0	72.95	0	0	11.8
2014	7	15	8	40	27	34	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	15	8	50	27	34	0	0	0	0	0	0	0	73	0	0	12
2014	7	15	9	0	27	34	0	0	0	0	0	0	0	73	0	0	12
2014	7	15	9	10	27	35	0	0	0	0	0	0	0	73.02	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	9	20	27	35	0	0	0	0	0	0	0	73.04	0	0	12
2014	7	15	9	30	27	35	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	15	9	40	27	35	0	0	0	0	0	0	0	73.04	0	0	12.2
2014	7	15	9	50	27	34	0	0	0	0	0	0	0	73.11	0	0	12.6
2014	7	15	10	0	27	35	0	0	0	0	0	0	0	73.11	0	0	12.4
2014	7	15	10	10	27	34	0	0	0	0	0	0	0	73.11	0	0	12.4
2014	7	15	10	20	27	34	0	0	0	0	0	0	0	73.11	0	0	12.4
2014	7	15	10	30	27	34	0	0	0	0	0	0	0	73.11	0	0	12.6
2014	7	15	10	40	27	34	0	0	0	0	0	0	0	73.15	0	0	12.8
2014	7	15	10	50	27	35	0	0	0	0	0	0	0	73.27	0	0	13.4
2014	7	15	11	0	27	34	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	15	11	10	27	34	0	0	0	0	0	0	0	73.22	0	0	12.6
2014	7	15	11	20	27	34	0	0	0	0	0	0	0	73.18	0	0	12.6
2014	7	15	11	30	27	35	0	0	0	0	0	0	0	73.2	0	0	12.6
2014	7	15	11	40	27	35	0	0	0	0	0	0	0	73.2	0	0	12.4
2014	7	15	11	50	27	35	0	0	0	0	0	0	0	73.2	0	0	12.4
2014	7	15	12	0	27	34	0	0	0	0	0	0	0	73.22	0	0	12.6
2014	7	15	12	10	27	34	0	0	0	0	0	0	0	73.27	0	0	12.8
2014	7	15	12	20	27	34	0	0	0	0	0	0	0	73.36	0	0	13
2014	7	15	12	30	27	35	0	0	0	0	0	0	0	73.4	0	0	13
2014	7	15	12	40	27	35	0	0	0	0	0	0	0	73.58	0	0	13.2
2014	7	15	12	50	27	35	0	0	0	0	0	0	0	73.53	0	0	13
2014	7	15	13	0	27	34	0	0	0	0	0	0	0	73.74	0	0	13.2
2014	7	15	13	10	27	34	0	0	0	0	0	0	0	73.71	0	0	13
2014	7	15	13	20	27	34	0	0	0	0	0	0	0	73.71	0	0	13
2014	7	15	13	30	27	35	0	0	0	0	0	0	0	73.65	0	0	13
2014	7	15	13	40	27	34	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	15	13	50	27	34	0	0	0	0	0	0	0	73.56	0	0	12.6
2014	7	15	14	0	27	35	0	0	0	0	0	0	0	73.67	0	0	13.2
2014	7	15	14	10	27	34	0	0	0	0	0	0	0	73.81	0	0	13.2
2014	7	15	14	20	27	35	0	0	0	0	0	0	0	73.78	0	0	13
2014	7	15	14	30	27	35	0	0	0	0	0	0	0	73.76	0	0	12.8
2014	7	15	14	40	27	35	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	15	14	50	27	34	0	0	0	0	0	0	0	73.67	0	0	12.6
2014	7	15	15	0	27	35	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	15	15	10	27	34	0	0	0	0	0	0	0	73.76	0	0	13
2014	7	15	15	20	27	34	0	0	0	0	0	0	0	73.8	0	0	13
2014	7	15	15	30	27	34	0	0	0	0	0	0	0	73.85	0	0	13
2014	7	15	15	40	27	34	0	0	0	0	0	0	0	73.87	0	0	13
2014	7	15	15	50	27	34	0	0	0	0	0	0	0	73.9	0	0	13
2014	7	15	16	0	27	34	0	0	0	0	0	0	0	73.92	0	0	13
2014	7	15	16	10	27	35	0	0	0	0	0	0	0	73.92	0	0	12.8
2014	7	15	16	20	27	34	0	0	0	0	0	0	0	73.94	0	0	12.8
2014	7	15	16	30	27	34	0	0	0	0	0	0	0	73.94	0	0	12.8
2014	7	15	16	40	27	33	0	0	0	0	0	0	0	73.94	0	0	12.6
2014	7	15	16	50	27	34	0	0	0	0	0	0	0	73.94	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	17	0	27	35	0	0	0	0	0	0	0	73.92	0	0	12.2
2014	7	15	17	10	27	34	0	0	0	0	0	0	0	73.92	0	0	12.2
2014	7	15	17	20	27	34	0	0	0	0	0	0	0	73.9	0	0	12
2014	7	15	17	30	27	34	0	0	0	0	0	0	0	73.9	0	0	12
2014	7	15	17	40	27	34	0	0	0	0	0	0	0	73.89	0	0	12
2014	7	15	17	50	27	34	0	0	0	0	0	0	0	73.87	0	0	11.8
2014	7	15	18	0	27	33	0	0	0	0	0	0	0	73.87	0	0	11.8
2014	7	15	18	10	27	34	0	0	0	0	0	0	0	73.85	0	0	11.8
2014	7	15	18	20	27	34	0	0	0	0	0	0	0	73.89	0	0	11.8
2014	7	15	18	30	27	34	0	0	0	0	0	0	0	73.87	0	0	11.8
2014	7	15	18	40	27	35	0	0	0	0	0	0	0	73.89	0	0	11.8
2014	7	15	18	50	27	34	0	0	0	0	0	0	0	73.9	0	0	11.8
2014	7	15	19	0	27	34	0	0	0	0	0	0	0	73.9	0	0	11.8
2014	7	15	19	10	27	35	0	0	0	0	0	0	0	73.9	0	0	11.8
2014	7	15	19	20	27	35	0	0	0	0	0	0	0	73.92	0	0	11.8
2014	7	15	19	30	27	34	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	15	19	40	27	34	0	0	0	0	0	0	0	73.92	0	0	11.8
2014	7	15	19	50	27	35	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	15	20	0	27	34	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	15	20	10	27	34	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	15	20	20	27	34	0	0	0	0	0	0	0	73.96	0	0	11.6
2014	7	15	20	30	27	35	0	0	0	0	0	0	0	73.96	0	0	11.6
2014	7	15	20	40	27	35	0	0	0	0	0	0	0	73.96	0	0	11.8
2014	7	15	20	50	27	35	0	0	0	0	0	0	0	73.96	0	0	11.8
2014	7	15	21	0	27	34	0	0	0	0	0	0	0	73.94	0	0	11.8
2014	7	15	21	10	27	35	0	0	0	0	0	0	0	73.94	0	0	11.8
2014	7	15	21	20	27	34	0	0	0	0	0	0	0	73.94	0	0	11.8
2014	7	15	21	30	27	35	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	15	21	40	27	34	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	15	21	50	27	34	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	15	22	0	27	33	0	0	0	0	0	0	0	73.94	0	0	11.6
2014	7	15	22	10	27	34	0	0	0	0	0	0	0	73.92	0	0	11.6
2014	7	15	22	20	27	35	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	15	22	30	27	34	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	15	22	40	27	34	0	0	0	0	0	0	0	73.9	0	0	11.6
2014	7	15	22	50	27	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	0	27	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	10	27	35	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	20	27	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	30	27	35	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	40	27	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	15	23	50	27	34	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	16	0	0	27	35	0	0	0	0	0	0	0	73.89	0	0	11.6
2014	7	16	0	10	27	35	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	16	0	20	27	34	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	16	0	30	27	34	0	0	0	0	0	0	0	73.87	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	0	40	27	34	0	0	0	0	0	0	0	73.87	0	0	11.6
2014	7	16	0	50	27	34	0	0	0	0	0	0	0	73.85	0	0	11.6
2014	7	16	1	0	27	34	0	0	0	0	0	0	0	73.83	0	0	11.6
2014	7	16	1	10	27	34	0	0	0	0	0	0	0	73.83	0	0	11.6
2014	7	16	1	20	27	34	0	0	0	0	0	0	0	73.81	0	0	11.6
2014	7	16	1	30	27	34	0	0	0	0	0	0	0	73.8	0	0	11.6
2014	7	16	1	40	27	34	0	0	0	0	0	0	0	73.78	0	0	11.6
2014	7	16	1	50	27	35	0	0	0	0	0	0	0	73.76	0	0	11.6
2014	7	16	2	0	27	35	0	0	0	0	0	0	0	73.74	0	0	11.6
2014	7	16	2	10	27	35	0	0	0	0	0	0	0	73.71	0	0	11.6
2014	7	16	2	20	27	35	0	0	0	0	0	0	0	73.71	0	0	11.4
2014	7	16	2	30	27	34	0	0	0	0	0	0	0	73.67	0	0	11.4
2014	7	16	2	40	27	34	0	0	0	0	0	0	0	73.65	0	0	11.4
2014	7	16	2	50	27	34	0	0	0	0	0	0	0	73.62	0	0	11.4
2014	7	16	3	0	27	35	0	0	0	0	0	0	0	73.6	0	0	11.4
2014	7	16	3	10	27	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	16	3	20	27	34	0	0	0	0	0	0	0	73.54	0	0	11.4
2014	7	16	3	30	27	34	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	16	3	40	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	16	3	50	27	34	0	0	0	0	0	0	0	73.45	0	0	11.4
2014	7	16	4	0	27	34	0	0	0	0	0	0	0	73.44	0	0	11.4
2014	7	16	4	10	27	35	0	0	0	0	0	0	0	73.4	0	0	11.4
2014	7	16	4	20	27	34	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	16	4	30	27	34	0	0	0	0	0	0	0	73.33	0	0	11.4
2014	7	16	4	40	27	34	0	0	0	0	0	0	0	73.33	0	0	11.4
2014	7	16	4	50	27	34	0	0	0	0	0	0	0	73.27	0	0	11.4
2014	7	16	5	0	27	34	0	0	0	0	0	0	0	73.26	0	0	11.4
2014	7	16	5	10	27	34	0	0	0	0	0	0	0	73.22	0	0	11.4
2014	7	16	5	20	27	34	0	0	0	0	0	0	0	73.2	0	0	11.4
2014	7	16	5	30	27	34	0	0	0	0	0	0	0	73.17	0	0	11.4
2014	7	16	5	40	27	34	0	0	0	0	0	0	0	73.13	0	0	11.4
2014	7	16	5	50	27	35	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	16	6	0	27	34	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	16	6	10	27	34	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	16	6	20	27	35	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	16	6	30	27	35	0	0	0	0	0	0	0	72.99	0	0	11.4
2014	7	16	6	40	27	34	0	0	0	0	0	0	0	72.97	0	0	11.6
2014	7	16	6	50	27	34	0	0	0	0	0	0	0	72.93	0	0	11.8
2014	7	16	7	0	27	34	0	0	0	0	0	0	0	72.91	0	0	11.8
2014	7	16	7	10	27	34	0	0	0	0	0	0	0	72.93	0	0	12
2014	7	16	7	20	27	34	0	0	0	0	0	0	0	72.93	0	0	12.2
2014	7	16	7	30	27	35	0	0	0	0	0	0	0	72.93	0	0	12.4
2014	7	16	7	40	27	35	0	0	0	0	0	0	0	72.95	0	0	12.4
2014	7	16	7	50	27	34	0	0	0	0	0	0	0	72.97	0	0	12.6
2014	7	16	8	0	27	34	0	0	0	0	0	0	0	72.97	0	0	12.8
2014	7	16	8	10	27	34	0	0	0	0	0	0	0	72.99	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	8	20	27	34	0	0	0	0	0	0	0	72.99	0	0	13
2014	7	16	8	30	27	34	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	16	8	40	27	35	0	0	0	0	0	0	0	73.04	0	0	12.8
2014	7	16	8	50	27	34	0	0	0	0	0	0	0	73.09	0	0	12.8
2014	7	16	9	0	27	34	0	0	0	0	0	0	0	73.11	0	0	12.8
2014	7	16	9	10	27	35	0	0	0	0	0	0	0	73.15	0	0	12.8
2014	7	16	9	20	27	34	0	0	0	0	0	0	0	73.18	0	0	12.8
2014	7	16	9	30	27	35	0	0	0	0	0	0	0	73.2	0	0	12.8
2014	7	16	9	40	27	34	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	16	9	50	27	34	0	0	0	0	0	0	0	73.27	0	0	12.8
2014	7	16	10	0	27	35	0	0	0	0	0	0	0	73.31	0	0	12.8
2014	7	16	10	10	27	35	0	0	0	0	0	0	0	73.31	0	0	12.8
2014	7	16	10	20	27	34	0	0	0	0	0	0	0	73.38	0	0	12.8
2014	7	16	10	30	27	35	0	0	0	0	0	0	0	73.44	0	0	12.8
2014	7	16	10	40	27	35	0	0	0	0	0	0	0	73.49	0	0	12.6
2014	7	16	10	50	27	34	0	0	0	0	0	0	0	73.54	0	0	12.6
2014	7	16	11	0	27	34	0	0	0	0	0	0	0	73.53	0	0	12.8
2014	7	16	11	10	27	34	0	0	0	0	0	0	0	73.47	0	0	12.8
2014	7	16	11	20	27	35	0	0	0	0	0	0	0	73.47	0	0	12.6
2014	7	16	11	30	27	35	0	0	0	0	0	0	0	73.49	0	0	12.6
2014	7	16	11	40	27	35	0	0	0	0	0	0	0	73.54	0	0	12.6
2014	7	16	11	50	27	34	0	0	0	0	0	0	0	73.58	0	0	12.6
2014	7	16	12	0	27	34	0	0	0	0	0	0	0	73.63	0	0	12.6
2014	7	16	12	10	27	35	0	0	0	0	0	0	0	73.69	0	0	12.6
2014	7	16	12	20	27	34	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	16	12	30	27	34	0	0	0	0	0	0	0	73.96	0	0	12.6
2014	7	16	12	40	27	33	0	0	0	0	0	0	0	74.05	0	0	12.8
2014	7	16	12	50	27	34	0	0	0	0	0	0	0	74.1	0	0	12.8
2014	7	16	13	0	27	34	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	16	13	10	27	34	0	0	0	0	0	0	0	74.26	0	0	12.8
2014	7	16	13	20	27	35	0	0	0	0	0	0	0	74.3	0	0	12.8
2014	7	16	13	30	27	34	0	0	0	0	0	0	0	74.35	0	0	12.8
2014	7	16	13	40	27	34	0	0	0	0	0	0	0	74.41	0	0	12.8
2014	7	16	13	50	27	34	0	0	0	0	0	0	0	74.44	0	0	12.8
2014	7	16	14	0	27	34	0	0	0	0	0	0	0	74.48	0	0	12.8
2014	7	16	14	10	27	34	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	16	14	20	27	35	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	16	14	30	27	34	0	0	0	0	0	0	0	74.57	0	0	12.8
2014	7	16	14	40	27	34	0	0	0	0	0	0	0	74.59	0	0	12.8
2014	7	16	14	50	27	34	0	0	0	0	0	0	0	74.59	0	0	12.6
2014	7	16	15	0	27	34	0	0	0	0	0	0	0	74.62	0	0	12.6
2014	7	16	15	10	27	34	0	0	0	0	0	0	0	74.64	0	0	12.8
2014	7	16	15	20	27	34	0	0	0	0	0	0	0	74.61	0	0	12.6
2014	7	16	15	30	27	34	0	0	0	0	0	0	0	74.57	0	0	12.8
2014	7	16	15	40	27	34	0	0	0	0	0	0	0	74.57	0	0	12.8
2014	7	16	15	50	27	35	0	0	0	0	0	0	0	74.61	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	16	0	27	34	0	0	0	0	0	0	0	74.59	0	0	12.6
2014	7	16	16	10	27	34	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	16	16	20	27	34	0	0	0	0	0	0	0	74.5	0	0	12.2
2014	7	16	16	30	27	35	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	16	16	40	27	34	0	0	0	0	0	0	0	74.52	0	0	12
2014	7	16	16	50	27	33	0	0	0	0	0	0	0	74.53	0	0	11.8
2014	7	16	17	0	27	35	0	0	0	0	0	0	0	74.53	0	0	11.8
2014	7	16	17	10	27	35	0	0	0	0	0	0	0	74.57	0	0	11.8
2014	7	16	17	20	27	34	0	0	0	0	0	0	0	74.57	0	0	11.8
2014	7	16	17	30	27	34	0	0	0	0	0	0	0	74.61	0	0	11.8
2014	7	16	17	40	27	34	0	0	0	0	0	0	0	74.62	0	0	11.8
2014	7	16	17	50	27	34	0	0	0	0	0	0	0	74.62	0	0	11.6
2014	7	16	18	0	27	34	0	0	0	0	0	0	0	74.64	0	0	11.6
2014	7	16	18	10	27	34	0	0	0	0	0	0	0	74.66	0	0	11
2014	7	16	18	20	27	34	0	0	0	0	0	0	0	74.66	0	0	11.6
2014	7	16	18	30	27	35	0	0	0	0	0	0	0	74.68	0	0	11.6
2014	7	16	18	40	27	35	0	0	0	0	0	0	0	74.7	0	0	11.6
2014	7	16	18	50	27	35	0	0	0	0	0	0	0	74.71	0	0	11.6
2014	7	16	19	0	27	35	0	0	0	0	0	0	0	74.73	0	0	11.6
2014	7	16	19	10	27	34	0	0	0	0	0	0	0	74.75	0	0	11.4
2014	7	16	19	20	27	34	0	0	0	0	0	0	0	74.77	0	0	11.4
2014	7	16	19	30	27	34	0	0	0	0	0	0	0	74.77	0	0	11.4
2014	7	16	19	40	27	34	0	0	0	0	0	0	0	74.79	0	0	11.4
2014	7	16	19	50	27	34	0	0	0	0	0	0	0	74.8	0	0	11.4
2014	7	16	20	0	27	34	0	0	0	0	0	0	0	74.8	0	0	11.2
2014	7	16	20	10	27	35	0	0	0	0	0	0	0	74.8	0	0	11.2
2014	7	16	20	20	27	34	0	0	0	0	0	0	0	74.8	0	0	11.2
2014	7	16	20	30	27	34	0	0	0	0	0	0	0	74.82	0	0	11.2
2014	7	16	20	40	27	35	0	0	0	0	0	0	0	74.82	0	0	11.2
2014	7	16	20	50	27	34	0	0	0	0	0	0	0	74.82	0	0	11
2014	7	16	21	0	27	35	0	0	0	0	0	0	0	74.84	0	0	11
2014	7	16	21	10	27	34	0	0	0	0	0	0	0	74.84	0	0	11
2014	7	16	21	20	27	34	0	0	0	0	0	0	0	74.84	0	0	11.2
2014	7	16	21	30	27	34	0	0	0	0	0	0	0	74.86	0	0	11.2
2014	7	16	21	40	27	35	0	0	0	0	0	0	0	74.86	0	0	11
2014	7	16	21	50	27	34	0	0	0	0	0	0	0	74.86	0	0	11.2
2014	7	16	22	0	27	35	0	0	0	0	0	0	0	74.86	0	0	10.8
2014	7	16	22	10	27	34	0	0	0	0	0	0	0	74.86	0	0	11
2014	7	16	22	20	27	34	0	0	0	0	0	0	0	74.88	0	0	11
2014	7	16	22	30	27	34	0	0	0	0	0	0	0	74.88	0	0	11
2014	7	16	22	40	27	34	0	0	0	0	0	0	0	74.88	0	0	10.8
2014	7	16	22	50	27	34	0	0	0	0	0	0	0	74.86	0	0	11
2014	7	16	23	0	27	34	0	0	0	0	0	0	0	74.86	0	0	10.6
2014	7	16	23	10	27	34	0	0	0	0	0	0	0	74.86	0	0	11
2014	7	16	23	20	27	33	0	0	0	0	0	0	0	74.86	0	0	11
2014	7	16	23	30	27	35	0	0	0	0	0	0	0	74.82	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	23	40	27	34	0	0	0	0	0	0	0	74.82	0	0	11.2
2014	7	16	23	50	27	34	0	0	0	0	0	0	0	74.8	0	0	11.2
2014	7	17	0	0	27	33	0	0	0	0	0	0	0	74.79	0	0	11
2014	7	17	0	10	27	35	0	0	0	0	0	0	0	74.77	0	0	11.2
2014	7	17	0	20	27	33	0	0	0	0	0	0	0	74.75	0	0	11.2
2014	7	17	0	30	27	34	0	0	0	0	0	0	0	74.73	0	0	11.2
2014	7	17	0	40	27	34	0	0	0	0	0	0	0	74.7	0	0	11
2014	7	17	0	50	27	34	0	0	0	0	0	0	0	74.66	0	0	11
2014	7	17	1	0	27	34	0	0	0	0	0	0	0	74.64	0	0	11
2014	7	17	1	10	27	34	0	0	0	0	0	0	0	74.61	0	0	11.2
2014	7	17	1	20	27	34	0	0	0	0	0	0	0	74.59	0	0	11
2014	7	17	1	30	27	34	0	0	0	0	0	0	0	74.57	0	0	11.2
2014	7	17	1	40	27	34	0	0	0	0	0	0	0	74.53	0	0	11.2
2014	7	17	1	50	27	35	0	0	0	0	0	0	0	74.5	0	0	11.2
2014	7	17	2	0	27	34	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	17	2	10	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	17	2	20	27	35	0	0	0	0	0	0	0	74.41	0	0	11.2
2014	7	17	2	30	27	34	0	0	0	0	0	0	0	74.37	0	0	11.2
2014	7	17	2	40	27	35	0	0	0	0	0	0	0	74.35	0	0	11
2014	7	17	2	50	27	34	0	0	0	0	0	0	0	74.32	0	0	11.2
2014	7	17	3	0	27	33	0	0	0	0	0	0	0	74.28	0	0	11.2
2014	7	17	3	10	27	34	0	0	0	0	0	0	0	74.25	0	0	11.2
2014	7	17	3	20	27	35	0	0	0	0	0	0	0	74.21	0	0	11.2
2014	7	17	3	30	27	34	0	0	0	0	0	0	0	74.17	0	0	11
2014	7	17	3	40	27	34	0	0	0	0	0	0	0	74.14	0	0	11.2
2014	7	17	3	50	27	34	0	0	0	0	0	0	0	74.1	0	0	11.2
2014	7	17	4	0	27	34	0	0	0	0	0	0	0	74.07	0	0	11.2
2014	7	17	4	10	27	35	0	0	0	0	0	0	0	74.03	0	0	11.2
2014	7	17	4	20	27	33	0	0	0	0	0	0	0	73.99	0	0	11.2
2014	7	17	4	30	27	34	0	0	0	0	0	0	0	73.96	0	0	11.2
2014	7	17	4	40	27	35	0	0	0	0	0	0	0	73.92	0	0	11
2014	7	17	4	50	27	34	0	0	0	0	0	0	0	73.89	0	0	11
2014	7	17	5	0	27	33	0	0	0	0	0	0	0	73.85	0	0	11
2014	7	17	5	10	27	34	0	0	0	0	0	0	0	73.81	0	0	11
2014	7	17	5	20	27	34	0	0	0	0	0	0	0	73.78	0	0	11
2014	7	17	5	30	27	34	0	0	0	0	0	0	0	73.74	0	0	11
2014	7	17	5	40	27	34	0	0	0	0	0	0	0	73.71	0	0	11
2014	7	17	5	50	27	35	0	0	0	0	0	0	0	73.67	0	0	11
2014	7	17	6	0	27	34	0	0	0	0	0	0	0	73.63	0	0	11.2
2014	7	17	6	10	27	34	0	0	0	0	0	0	0	73.6	0	0	11
2014	7	17	6	20	27	35	0	0	0	0	0	0	0	73.58	0	0	11.2
2014	7	17	6	30	27	35	0	0	0	0	0	0	0	73.54	0	0	11.2
2014	7	17	6	40	27	35	0	0	0	0	0	0	0	73.51	0	0	11.4
2014	7	17	6	50	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	17	7	0	27	34	0	0	0	0	0	0	0	73.47	0	0	11.6
2014	7	17	7	10	27	35	0	0	0	0	0	0	0	73.45	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	7	20	27	34	0	0	0	0	0	0	0	73.45	0	0	11.8
2014	7	17	7	30	27	35	0	0	0	0	0	0	0	73.45	0	0	12
2014	7	17	7	40	27	35	0	0	0	0	0	0	0	73.47	0	0	12.2
2014	7	17	7	50	27	35	0	0	0	0	0	0	0	73.47	0	0	12.4
2014	7	17	8	0	27	34	0	0	0	0	0	0	0	73.49	0	0	12.6
2014	7	17	8	10	27	34	0	0	0	0	0	0	0	73.51	0	0	12.6
2014	7	17	8	20	27	34	0	0	0	0	0	0	0	73.53	0	0	12.8
2014	7	17	8	30	27	34	0	0	0	0	0	0	0	73.53	0	0	13
2014	7	17	8	40	27	34	0	0	0	0	0	0	0	73.56	0	0	13
2014	7	17	8	50	27	35	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	17	9	0	27	34	0	0	0	0	0	0	0	73.6	0	0	12.8
2014	7	17	9	10	27	34	0	0	0	0	0	0	0	73.65	0	0	12.8
2014	7	17	9	20	27	34	0	0	0	0	0	0	0	73.67	0	0	12.8
2014	7	17	9	30	27	35	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	17	9	40	27	34	0	0	0	0	0	0	0	73.74	0	0	12.8
2014	7	17	9	50	27	34	0	0	0	0	0	0	0	73.76	0	0	12.6
2014	7	17	10	0	27	35	0	0	0	0	0	0	0	73.78	0	0	12.6
2014	7	17	10	10	27	35	0	0	0	0	0	0	0	73.81	0	0	12.6
2014	7	17	10	20	27	34	0	0	0	0	0	0	0	73.87	0	0	12.6
2014	7	17	10	30	27	34	0	0	0	0	0	0	0	73.9	0	0	12.6
2014	7	17	10	40	27	34	0	0	0	0	0	0	0	73.94	0	0	12.6
2014	7	17	10	50	27	35	0	0	0	0	0	0	0	73.9	0	0	12.6
2014	7	17	11	0	27	34	0	0	0	0	0	0	0	73.9	0	0	12.6
2014	7	17	11	10	27	34	0	0	0	0	0	0	0	73.94	0	0	12.6
2014	7	17	11	20	27	34	0	0	0	0	0	0	0	73.96	0	0	12.6
2014	7	17	11	30	27	34	0	0	0	0	0	0	0	73.98	0	0	12.8
2014	7	17	11	40	27	34	0	0	0	0	0	0	0	73.98	0	0	12.8
2014	7	17	11	50	27	33	0	0	0	0	0	0	0	73.99	0	0	12.8
2014	7	17	12	0	27	35	0	0	0	0	0	0	0	74.08	0	0	12.8
2014	7	17	12	10	27	34	0	0	0	0	0	0	0	74.16	0	0	12.8
2014	7	17	12	20	27	34	0	0	0	0	0	0	0	74.16	0	0	12.8
2014	7	17	12	30	27	34	0	0	0	0	0	0	0	74.21	0	0	12.8
2014	7	17	12	40	27	34	0	0	0	0	0	0	0	74.32	0	0	13
2014	7	17	12	50	27	35	0	0	0	0	0	0	0	74.39	0	0	13
2014	7	17	13	0	27	34	0	0	0	0	0	0	0	74.43	0	0	13
2014	7	17	13	10	27	35	0	0	0	0	0	0	0	74.5	0	0	13
2014	7	17	13	20	27	34	0	0	0	0	0	0	0	74.55	0	0	13
2014	7	17	13	30	27	33	0	0	0	0	0	0	0	74.57	0	0	13
2014	7	17	13	40	27	34	0	0	0	0	0	0	0	74.61	0	0	13
2014	7	17	13	50	27	35	0	0	0	0	0	0	0	74.62	0	0	13
2014	7	17	14	0	27	35	0	0	0	0	0	0	0	74.66	0	0	13
2014	7	17	14	10	27	34	0	0	0	0	0	0	0	74.7	0	0	13
2014	7	17	14	20	27	34	0	0	0	0	0	0	0	74.73	0	0	13
2014	7	17	14	30	27	34	0	0	0	0	0	0	0	74.75	0	0	13
2014	7	17	14	40	27	35	0	0	0	0	0	0	0	74.75	0	0	13
2014	7	17	14	50	27	34	0	0	0	0	0	0	0	74.77	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	15	0	27	34	0	0	0	0	0	0	0	74.79	0	0	13
2014	7	17	15	10	27	33	0	0	0	0	0	0	0	74.77	0	0	13
2014	7	17	15	20	27	34	0	0	0	0	0	0	0	74.8	0	0	13
2014	7	17	15	30	27	34	0	0	0	0	0	0	0	74.82	0	0	13
2014	7	17	15	40	27	34	0	0	0	0	0	0	0	74.8	0	0	13
2014	7	17	15	50	27	34	0	0	0	0	0	0	0	74.82	0	0	12.8
2014	7	17	16	0	27	34	0	0	0	0	0	0	0	74.8	0	0	12.8
2014	7	17	16	10	27	34	0	0	0	0	0	0	0	74.8	0	0	12.8
2014	7	17	16	20	27	34	0	0	0	0	0	0	0	74.8	0	0	12.8
2014	7	17	16	30	27	34	0	0	0	0	0	0	0	74.82	0	0	12.8
2014	7	17	16	40	27	34	0	0	0	0	0	0	0	74.82	0	0	12.6
2014	7	17	16	50	27	34	0	0	0	0	0	0	0	74.82	0	0	12.4
2014	7	17	17	0	27	34	0	0	0	0	0	0	0	74.82	0	0	12.2
2014	7	17	17	10	27	34	0	0	0	0	0	0	0	74.8	0	0	12
2014	7	17	17	20	27	34	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	17	17	30	27	34	0	0	0	0	0	0	0	74.77	0	0	12
2014	7	17	17	40	27	34	0	0	0	0	0	0	0	74.79	0	0	12
2014	7	17	17	50	27	33	0	0	0	0	0	0	0	74.77	0	0	11.8
2014	7	17	18	0	27	35	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	17	18	10	27	34	0	0	0	0	0	0	0	74.75	0	0	11.8
2014	7	17	18	20	27	34	0	0	0	0	0	0	0	74.75	0	0	11.6
2014	7	17	18	30	27	34	0	0	0	0	0	0	0	74.75	0	0	11.4
2014	7	17	18	40	27	34	0	0	0	0	0	0	0	74.77	0	0	11.6
2014	7	17	18	50	27	34	0	0	0	0	0	0	0	74.8	0	0	11.8
2014	7	17	19	0	27	34	0	0	0	0	0	0	0	74.79	0	0	11.8
2014	7	17	19	10	27	34	0	0	0	0	0	0	0	74.79	0	0	11.8
2014	7	17	19	20	27	34	0	0	0	0	0	0	0	74.8	0	0	11.8
2014	7	17	19	30	27	34	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	19	40	27	35	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	19	50	27	34	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	20	0	27	34	0	0	0	0	0	0	0	74.79	0	0	11.6
2014	7	17	20	10	27	34	0	0	0	0	0	0	0	74.79	0	0	11.6
2014	7	17	20	20	27	35	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	20	30	27	34	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	20	40	27	34	0	0	0	0	0	0	0	74.8	0	0	11.6
2014	7	17	20	50	27	34	0	0	0	0	0	0	0	74.82	0	0	11.6
2014	7	17	21	0	27	35	0	0	0	0	0	0	0	74.82	0	0	11.6
2014	7	17	21	10	27	34	0	0	0	0	0	0	0	74.82	0	0	11.6
2014	7	17	21	20	27	34	0	0	0	0	0	0	0	74.84	0	0	11.6
2014	7	17	21	30	27	34	0	0	0	0	0	0	0	74.84	0	0	11.6
2014	7	17	21	40	27	33	0	0	0	0	0	0	0	74.84	0	0	11.6
2014	7	17	21	50	27	35	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	22	0	27	34	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	22	10	27	34	0	0	0	0	0	0	0	74.88	0	0	11.6
2014	7	17	22	20	27	35	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	22	30	27	34	0	0	0	0	0	0	0	74.86	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	22	40	27	35	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	22	50	27	34	0	0	0	0	0	0	0	74.88	0	0	11.6
2014	7	17	23	0	27	34	0	0	0	0	0	0	0	74.88	0	0	11.6
2014	7	17	23	10	27	34	0	0	0	0	0	0	0	74.88	0	0	11.6
2014	7	17	23	20	27	34	0	0	0	0	0	0	0	74.88	0	0	11.6
2014	7	17	23	30	27	34	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	23	40	27	34	0	0	0	0	0	0	0	74.86	0	0	11.6
2014	7	17	23	50	27	34	0	0	0	0	0	0	0	74.84	0	0	11.6
2014	7	18	0	0	27	34	0	0	0	0	0	0	0	74.82	0	0	11.6
2014	7	18	0	10	27	34	0	0	0	0	0	0	0	74.82	0	0	11.6
2014	7	18	0	20	27	34	0	0	0	0	0	0	0	74.79	0	0	11.6
2014	7	18	0	30	27	34	0	0	0	0	0	0	0	74.77	0	0	11.6
2014	7	18	0	40	27	34	0	0	0	0	0	0	0	74.75	0	0	11.6
2014	7	18	0	50	27	34	0	0	0	0	0	0	0	74.73	0	0	11.6
2014	7	18	1	0	27	34	0	0	0	0	0	0	0	74.7	0	0	11.6
2014	7	18	1	10	27	35	0	0	0	0	0	0	0	74.66	0	0	11.6
2014	7	18	1	20	27	33	0	0	0	0	0	0	0	74.64	0	0	11.6
2014	7	18	1	30	27	35	0	0	0	0	0	0	0	74.61	0	0	11.6
2014	7	18	1	40	27	34	0	0	0	0	0	0	0	74.59	0	0	11.6
2014	7	18	1	50	27	34	0	0	0	0	0	0	0	74.55	0	0	11.6
2014	7	18	2	0	27	34	0	0	0	0	0	0	0	74.52	0	0	11.6
2014	7	18	2	10	27	34	0	0	0	0	0	0	0	74.48	0	0	11.6
2014	7	18	2	20	27	34	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	18	2	30	27	34	0	0	0	0	0	0	0	74.43	0	0	11.6
2014	7	18	2	40	27	34	0	0	0	0	0	0	0	74.39	0	0	11.4
2014	7	18	2	50	27	35	0	0	0	0	0	0	0	74.35	0	0	11.4
2014	7	18	3	0	27	34	0	0	0	0	0	0	0	74.32	0	0	11.4
2014	7	18	3	10	27	34	0	0	0	0	0	0	0	74.28	0	0	11.4
2014	7	18	3	20	27	34	0	0	0	0	0	0	0	74.25	0	0	11.4
2014	7	18	3	30	27	34	0	0	0	0	0	0	0	74.21	0	0	11.4
2014	7	18	3	40	27	34	0	0	0	0	0	0	0	74.17	0	0	11.4
2014	7	18	3	50	27	34	0	0	0	0	0	0	0	74.14	0	0	11.4
2014	7	18	4	0	27	34	0	0	0	0	0	0	0	74.1	0	0	11.4
2014	7	18	4	10	27	35	0	0	0	0	0	0	0	74.07	0	0	11.4
2014	7	18	4	20	27	34	0	0	0	0	0	0	0	74.03	0	0	11.4
2014	7	18	4	30	27	34	0	0	0	0	0	0	0	73.99	0	0	11.4
2014	7	18	4	40	27	34	0	0	0	0	0	0	0	73.94	0	0	11.4
2014	7	18	4	50	27	34	0	0	0	0	0	0	0	73.9	0	0	11.4
2014	7	18	5	0	27	34	0	0	0	0	0	0	0	73.85	0	0	11.4
2014	7	18	5	10	27	34	0	0	0	0	0	0	0	73.81	0	0	11.4
2014	7	18	5	20	27	34	0	0	0	0	0	0	0	73.78	0	0	11.4
2014	7	18	5	30	27	34	0	0	0	0	0	0	0	73.74	0	0	11.4
2014	7	18	5	40	27	35	0	0	0	0	0	0	0	73.71	0	0	11.4
2014	7	18	5	50	27	34	0	0	0	0	0	0	0	73.67	0	0	11.4
2014	7	18	6	0	27	34	0	0	0	0	0	0	0	73.63	0	0	11.4
2014	7	18	6	10	27	34	0	0	0	0	0	0	0	73.62	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	6	20	27	34	0	0	0	0	0	0	0	73.58	0	0	11.4
2014	7	18	6	30	27	34	0	0	0	0	0	0	0	73.54	0	0	11.4
2014	7	18	6	40	27	35	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	18	6	50	27	34	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	18	7	0	27	35	0	0	0	0	0	0	0	73.44	0	0	11.8
2014	7	18	7	10	27	34	0	0	0	0	0	0	0	73.42	0	0	12
2014	7	18	7	20	27	35	0	0	0	0	0	0	0	73.42	0	0	12.2
2014	7	18	7	30	27	34	0	0	0	0	0	0	0	73.4	0	0	12.2
2014	7	18	7	40	27	34	0	0	0	0	0	0	0	73.4	0	0	12.4
2014	7	18	7	50	27	35	0	0	0	0	0	0	0	73.4	0	0	12.6
2014	7	18	8	0	27	34	0	0	0	0	0	0	0	73.4	0	0	12.8
2014	7	18	8	10	27	34	0	0	0	0	0	0	0	73.4	0	0	12.8
2014	7	18	8	20	27	35	0	0	0	0	0	0	0	73.42	0	0	13
2014	7	18	8	30	27	35	0	0	0	0	0	0	0	73.42	0	0	13
2014	7	18	8	40	27	34	0	0	0	0	0	0	0	73.44	0	0	13
2014	7	18	8	50	27	34	0	0	0	0	0	0	0	73.45	0	0	12.8
2014	7	18	9	0	27	34	0	0	0	0	0	0	0	73.47	0	0	12.8
2014	7	18	9	10	27	34	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	18	9	20	27	34	0	0	0	0	0	0	0	73.53	0	0	12.8
2014	7	18	9	30	27	35	0	0	0	0	0	0	0	73.54	0	0	12.8
2014	7	18	9	40	27	34	0	0	0	0	0	0	0	73.56	0	0	12.8
2014	7	18	9	50	27	34	0	0	0	0	0	0	0	73.58	0	0	12.8
2014	7	18	10	0	27	34	0	0	0	0	0	0	0	73.6	0	0	12.8
2014	7	18	10	10	27	34	0	0	0	0	0	0	0	73.65	0	0	12.8
2014	7	18	10	20	27	35	0	0	0	0	0	0	0	73.67	0	0	12.8
2014	7	18	10	30	27	34	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	18	10	40	27	34	0	0	0	0	0	0	0	73.74	0	0	12.8
2014	7	18	10	50	27	34	0	0	0	0	0	0	0	73.72	0	0	12.8
2014	7	18	11	0	27	34	0	0	0	0	0	0	0	73.72	0	0	12.8
2014	7	18	11	10	27	35	0	0	0	0	0	0	0	73.76	0	0	12.8
2014	7	18	11	20	27	34	0	0	0	0	0	0	0	73.78	0	0	12.8
2014	7	18	11	30	27	34	0	0	0	0	0	0	0	73.76	0	0	12.8
2014	7	18	11	40	27	34	0	0	0	0	0	0	0	73.78	0	0	12.8
2014	7	18	11	50	27	34	0	0	0	0	0	0	0	73.8	0	0	12.8
2014	7	18	12	0	27	34	0	0	0	0	0	0	0	73.85	0	0	12.8
2014	7	18	12	10	27	34	0	0	0	0	0	0	0	73.87	0	0	12.8
2014	7	18	12	20	27	35	0	0	0	0	0	0	0	73.92	0	0	12.8
2014	7	18	12	30	27	35	0	0	0	0	0	0	0	73.98	0	0	12.8
2014	7	18	12	40	27	34	0	0	0	0	0	0	0	74.03	0	0	12.8
2014	7	18	12	50	27	34	0	0	0	0	0	0	0	74.12	0	0	12.8
2014	7	18	13	0	27	35	0	0	0	0	0	0	0	74.23	0	0	12.8
2014	7	18	13	10	27	34	0	0	0	0	0	0	0	74.32	0	0	12.8
2014	7	18	13	20	27	34	0	0	0	0	0	0	0	74.35	0	0	12.8
2014	7	18	13	30	27	34	0	0	0	0	0	0	0	74.41	0	0	12.8
2014	7	18	13	40	27	34	0	0	0	0	0	0	0	74.39	0	0	12.8
2014	7	18	13	50	27	34	0	0	0	0	0	0	0	74.44	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	14	0	27	34	0	0	0	0	0	0	0	74.48	0	0	12.8
2014	7	18	14	10	27	34	0	0	0	0	0	0	0	74.5	0	0	12.8
2014	7	18	14	20	27	34	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	18	14	30	27	34	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	18	14	40	27	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	14	50	27	34	0	0	0	0	0	0	0	74.5	0	0	12.8
2014	7	18	15	0	27	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	15	10	27	34	0	0	0	0	0	0	0	74.48	0	0	12.8
2014	7	18	15	20	27	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	15	30	27	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	15	40	27	35	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	15	50	27	35	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	16	0	27	33	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	16	10	27	34	0	0	0	0	0	0	0	74.52	0	0	12.8
2014	7	18	16	20	27	34	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	16	30	27	35	0	0	0	0	0	0	0	74.53	0	0	12.8
2014	7	18	16	40	27	35	0	0	0	0	0	0	0	74.53	0	0	12.6
2014	7	18	16	50	27	34	0	0	0	0	0	0	0	74.52	0	0	12.4
2014	7	18	17	0	27	34	0	0	0	0	0	0	0	74.52	0	0	12.2
2014	7	18	17	10	27	34	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	18	17	20	27	34	0	0	0	0	0	0	0	74.5	0	0	12
2014	7	18	17	30	27	33	0	0	0	0	0	0	0	74.48	0	0	11.8
2014	7	18	17	40	27	34	0	0	0	0	0	0	0	74.48	0	0	11.8
2014	7	18	17	50	27	34	0	0	0	0	0	0	0	74.46	0	0	11.8
2014	7	18	18	0	27	34	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	18	18	10	27	34	0	0	0	0	0	0	0	74.46	0	0	11.8
2014	7	18	18	20	27	35	0	0	0	0	0	0	0	74.46	0	0	11.8
2014	7	18	18	30	27	34	0	0	0	0	0	0	0	74.46	0	0	11.8
2014	7	18	18	40	27	34	0	0	0	0	0	0	0	74.48	0	0	11.8
2014	7	18	18	50	27	34	0	0	0	0	0	0	0	74.46	0	0	11.8
2014	7	18	19	0	27	34	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	18	19	10	27	34	0	0	0	0	0	0	0	74.46	0	0	11.6
2014	7	18	19	20	27	34	0	0	0	0	0	0	0	74.48	0	0	11.4
2014	7	18	19	30	27	35	0	0	0	0	0	0	0	74.48	0	0	11.6
2014	7	18	19	40	27	34	0	0	0	0	0	0	0	74.46	0	0	11.4
2014	7	18	19	50	27	35	0	0	0	0	0	0	0	74.46	0	0	11.4
2014	7	18	20	0	27	34	0	0	0	0	0	0	0	74.48	0	0	11.4
2014	7	18	20	10	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	20	20	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	20	30	27	34	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	18	20	40	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	18	20	50	27	35	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	18	21	0	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	18	21	10	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	18	21	20	27	34	0	0	0	0	0	0	0	74.44	0	0	11
2014	7	18	21	30	27	34	0	0	0	0	0	0	0	74.46	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	21	40	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	21	50	27	35	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	22	0	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	22	10	27	34	0	0	0	0	0	0	0	74.48	0	0	11
2014	7	18	22	20	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	22	30	27	34	0	0	0	0	0	0	0	74.48	0	0	11
2014	7	18	22	40	27	34	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	18	22	50	27	35	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	18	23	0	27	34	0	0	0	0	0	0	0	74.48	0	0	11.2
2014	7	18	23	10	27	34	0	0	0	0	0	0	0	74.46	0	0	11.2
2014	7	18	23	20	27	34	0	0	0	0	0	0	0	74.46	0	0	11.4
2014	7	18	23	30	27	34	0	0	0	0	0	0	0	74.44	0	0	11.4
2014	7	18	23	40	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	18	23	50	27	34	0	0	0	0	0	0	0	74.44	0	0	11.2
2014	7	19	0	0	27	34	0	0	0	0	0	0	0	74.41	0	0	11.2
2014	7	19	0	10	27	34	0	0	0	0	0	0	0	74.41	0	0	11
2014	7	19	0	20	27	34	0	0	0	0	0	0	0	74.39	0	0	11.2
2014	7	19	0	30	27	34	0	0	0	0	0	0	0	74.37	0	0	11.2
2014	7	19	0	40	27	35	0	0	0	0	0	0	0	74.35	0	0	11.2
2014	7	19	0	50	27	35	0	0	0	0	0	0	0	74.34	0	0	11.2
2014	7	19	1	0	27	34	0	0	0	0	0	0	0	74.32	0	0	11.2
2014	7	19	1	10	27	34	0	0	0	0	0	0	0	74.3	0	0	11.2
2014	7	19	1	20	27	34	0	0	0	0	0	0	0	74.26	0	0	11.2
2014	7	19	1	30	27	35	0	0	0	0	0	0	0	74.25	0	0	11.2
2014	7	19	1	40	27	34	0	0	0	0	0	0	0	74.21	0	0	11.2
2014	7	19	1	50	27	33	0	0	0	0	0	0	0	74.19	0	0	11.2
2014	7	19	2	0	27	34	0	0	0	0	0	0	0	74.16	0	0	11.2
2014	7	19	2	10	27	34	0	0	0	0	0	0	0	74.12	0	0	11
2014	7	19	2	20	27	35	0	0	0	0	0	0	0	74.08	0	0	11
2014	7	19	2	30	27	35	0	0	0	0	0	0	0	74.05	0	0	11
2014	7	19	2	40	27	34	0	0	0	0	0	0	0	74.01	0	0	11
2014	7	19	2	50	27	34	0	0	0	0	0	0	0	73.98	0	0	11.2
2014	7	19	3	0	27	34	0	0	0	0	0	0	0	73.92	0	0	11.2
2014	7	19	3	10	27	34	0	0	0	0	0	0	0	73.89	0	0	11.2
2014	7	19	3	20	27	34	0	0	0	0	0	0	0	73.83	0	0	11.2
2014	7	19	3	30	27	34	0	0	0	0	0	0	0	73.8	0	0	11.2
2014	7	19	3	40	27	34	0	0	0	0	0	0	0	73.74	0	0	11.2
2014	7	19	3	50	27	35	0	0	0	0	0	0	0	73.71	0	0	11.2
2014	7	19	4	0	27	34	0	0	0	0	0	0	0	73.69	0	0	11.2
2014	7	19	4	10	27	34	0	0	0	0	0	0	0	73.63	0	0	11.2
2014	7	19	4	20	27	34	0	0	0	0	0	0	0	73.6	0	0	11.2
2014	7	19	4	30	27	35	0	0	0	0	0	0	0	73.56	0	0	11.2
2014	7	19	4	40	27	34	0	0	0	0	0	0	0	73.53	0	0	11.2
2014	7	19	4	50	27	34	0	0	0	0	0	0	0	73.47	0	0	11.2
2014	7	19	5	0	27	34	0	0	0	0	0	0	0	73.42	0	0	11.2
2014	7	19	5	10	27	34	0	0	0	0	0	0	0	73.4	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	5	20	27	35	0	0	0	0	0	0	0	73.36	0	0	11.2
2014	7	19	5	30	27	35	0	0	0	0	0	0	0	73.33	0	0	11.2
2014	7	19	5	40	27	34	0	0	0	0	0	0	0	73.29	0	0	11.2
2014	7	19	5	50	27	34	0	0	0	0	0	0	0	73.26	0	0	11.2
2014	7	19	6	0	27	34	0	0	0	0	0	0	0	73.2	0	0	11.2
2014	7	19	6	10	27	35	0	0	0	0	0	0	0	73.18	0	0	11.2
2014	7	19	6	20	27	35	0	0	0	0	0	0	0	73.17	0	0	11.2
2014	7	19	6	30	27	34	0	0	0	0	0	0	0	73.13	0	0	11.2
2014	7	19	6	40	27	34	0	0	0	0	0	0	0	73.09	0	0	11.4
2014	7	19	6	50	27	34	0	0	0	0	0	0	0	73.06	0	0	11.6
2014	7	19	7	0	27	34	0	0	0	0	0	0	0	73.04	0	0	11.6
2014	7	19	7	10	27	34	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	19	7	20	27	34	0	0	0	0	0	0	0	73.02	0	0	12
2014	7	19	7	30	27	35	0	0	0	0	0	0	0	72.99	0	0	12
2014	7	19	7	40	27	34	0	0	0	0	0	0	0	72.99	0	0	12.2
2014	7	19	7	50	27	35	0	0	0	0	0	0	0	72.99	0	0	12.2
2014	7	19	8	0	27	34	0	0	0	0	0	0	0	72.99	0	0	12.6
2014	7	19	8	10	27	34	0	0	0	0	0	0	0	72.99	0	0	12.8
2014	7	19	8	20	27	34	0	0	0	0	0	0	0	73	0	0	12.8
2014	7	19	8	30	27	34	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	19	8	40	27	34	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	19	8	50	27	35	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	19	9	0	27	34	0	0	0	0	0	0	0	73.06	0	0	12.8
2014	7	19	9	10	27	34	0	0	0	0	0	0	0	73.08	0	0	12.8
2014	7	19	9	20	27	34	0	0	0	0	0	0	0	73.09	0	0	12.8
2014	7	19	9	30	27	35	0	0	0	0	0	0	0	73.11	0	0	12.8
2014	7	19	9	40	27	34	0	0	0	0	0	0	0	73.15	0	0	12.8
2014	7	19	9	50	27	34	0	0	0	0	0	0	0	73.15	0	0	12.8
2014	7	19	10	0	27	34	0	0	0	0	0	0	0	73.18	0	0	12.8
2014	7	19	10	10	27	34	0	0	0	0	0	0	0	73.2	0	0	12.8
2014	7	19	10	20	27	34	0	0	0	0	0	0	0	73.22	0	0	12.8
2014	7	19	10	30	27	34	0	0	0	0	0	0	0	73.27	0	0	12.8
2014	7	19	10	40	27	34	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	19	10	50	27	34	0	0	0	0	0	0	0	73.26	0	0	12.8
2014	7	19	11	0	27	35	0	0	0	0	0	0	0	73.26	0	0	12.8
2014	7	19	11	10	27	34	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	19	11	20	27	34	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	19	11	30	27	34	0	0	0	0	0	0	0	73.33	0	0	12.8
2014	7	19	11	40	27	35	0	0	0	0	0	0	0	73.35	0	0	13
2014	7	19	11	50	27	34	0	0	0	0	0	0	0	73.45	0	0	13
2014	7	19	12	0	27	35	0	0	0	0	0	0	0	73.44	0	0	12.8
2014	7	19	12	10	27	35	0	0	0	0	0	0	0	73.45	0	0	12.8
2014	7	19	12	20	27	35	0	0	0	0	0	0	0	73.47	0	0	12.8
2014	7	19	12	30	27	35	0	0	0	0	0	0	0	73.4	0	0	12.8
2014	7	19	12	40	27	34	0	0	0	0	0	0	0	73.42	0	0	12.8
2014	7	19	12	50	27	34	0	0	0	0	0	0	0	73.45	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	13	0	27	34	0	0	0	0	0	0	0	73.44	0	0	12.8
2014	7	19	13	10	27	35	0	0	0	0	0	0	0	73.42	0	0	13
2014	7	19	13	20	27	34	0	0	0	0	0	0	0	73.45	0	0	12.8
2014	7	19	13	30	27	34	0	0	0	0	0	0	0	73.56	0	0	13
2014	7	19	13	40	27	33	0	0	0	0	0	0	0	73.44	0	0	12.6
2014	7	19	13	50	27	35	0	0	0	0	0	0	0	73.49	0	0	13
2014	7	19	14	0	27	34	0	0	0	0	0	0	0	73.6	0	0	12.8
2014	7	19	14	10	27	35	0	0	0	0	0	0	0	73.63	0	0	12.8
2014	7	19	14	20	27	34	0	0	0	0	0	0	0	73.67	0	0	12.8
2014	7	19	14	30	27	34	0	0	0	0	0	0	0	73.72	0	0	12.8
2014	7	19	14	40	27	34	0	0	0	0	0	0	0	73.65	0	0	12.8
2014	7	19	14	50	27	34	0	0	0	0	0	0	0	73.67	0	0	12.8
2014	7	19	15	0	27	35	0	0	0	0	0	0	0	73.74	0	0	13
2014	7	19	15	10	27	34	0	0	0	0	0	0	0	73.72	0	0	13
2014	7	19	15	20	27	34	0	0	0	0	0	0	0	73.62	0	0	12.6
2014	7	19	15	30	27	34	0	0	0	0	0	0	0	73.65	0	0	13
2014	7	19	15	40	27	34	0	0	0	0	0	0	0	73.74	0	0	13
2014	7	19	15	50	27	34	0	0	0	0	0	0	0	73.65	0	0	12.8
2014	7	19	16	0	27	34	0	0	0	0	0	0	0	73.63	0	0	12.6
2014	7	19	16	10	27	35	0	0	0	0	0	0	0	73.67	0	0	13
2014	7	19	16	20	27	35	0	0	0	0	0	0	0	73.69	0	0	12.6
2014	7	19	16	30	27	35	0	0	0	0	0	0	0	73.71	0	0	13
2014	7	19	16	40	27	34	0	0	0	0	0	0	0	73.72	0	0	13
2014	7	19	16	50	27	34	0	0	0	0	0	0	0	73.71	0	0	12.8
2014	7	19	17	0	27	34	0	0	0	0	0	0	0	73.67	0	0	12.6
2014	7	19	17	10	27	34	0	0	0	0	0	0	0	73.63	0	0	12.4
2014	7	19	17	20	27	34	0	0	0	0	0	0	0	73.62	0	0	12.4
2014	7	19	17	30	27	35	0	0	0	0	0	0	0	73.62	0	0	12.4
2014	7	19	17	40	27	35	0	0	0	0	0	0	0	73.62	0	0	12.2
2014	7	19	17	50	27	34	0	0	0	0	0	0	0	73.58	0	0	12.2
2014	7	19	18	0	27	34	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	19	18	10	27	34	0	0	0	0	0	0	0	73.56	0	0	11.6
2014	7	19	18	20	27	35	0	0	0	0	0	0	0	73.53	0	0	11.6
2014	7	19	18	30	27	34	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	19	18	40	27	34	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	19	18	50	27	34	0	0	0	0	0	0	0	73.53	0	0	11.6
2014	7	19	19	0	27	35	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	19	19	10	27	35	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	19	19	20	27	34	0	0	0	0	0	0	0	73.51	0	0	11.6
2014	7	19	19	30	27	34	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	19	19	40	27	34	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	19	19	50	27	33	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	19	20	0	27	34	0	0	0	0	0	0	0	73.49	0	0	11.6
2014	7	19	20	10	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	20	20	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	20	30	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	20	40	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	20	50	27	35	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	21	0	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	21	10	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	21	20	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	21	30	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	21	40	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	21	50	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	22	0	27	34	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	22	10	27	35	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	22	20	27	35	0	0	0	0	0	0	0	73.49	0	0	11.4
2014	7	19	22	30	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	22	40	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	22	50	27	35	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	23	0	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	23	10	27	34	0	0	0	0	0	0	0	73.47	0	0	11.4
2014	7	19	23	20	27	34	0	0	0	0	0	0	0	73.45	0	0	11.4
2014	7	19	23	30	27	34	0	0	0	0	0	0	0	73.44	0	0	11.4
2014	7	19	23	40	27	34	0	0	0	0	0	0	0	73.44	0	0	11.4
2014	7	19	23	50	27	34	0	0	0	0	0	0	0	73.42	0	0	11.4
2014	7	20	0	0	27	34	0	0	0	0	0	0	0	73.42	0	0	11.4
2014	7	20	0	10	27	34	0	0	0	0	0	0	0	73.38	0	0	11.4
2014	7	20	0	20	27	35	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	20	0	30	27	34	0	0	0	0	0	0	0	73.35	0	0	11.2
2014	7	20	0	40	27	35	0	0	0	0	0	0	0	73.33	0	0	11.2
2014	7	20	0	50	27	34	0	0	0	0	0	0	0	73.29	0	0	11.2
2014	7	20	1	0	27	35	0	0	0	0	0	0	0	73.27	0	0	11.2
2014	7	20	1	10	27	34	0	0	0	0	0	0	0	73.24	0	0	11.2
2014	7	20	1	20	27	34	0	0	0	0	0	0	0	73.22	0	0	11.2
2014	7	20	1	30	27	34	0	0	0	0	0	0	0	73.18	0	0	11
2014	7	20	1	40	27	34	0	0	0	0	0	0	0	73.15	0	0	11.2
2014	7	20	1	50	27	34	0	0	0	0	0	0	0	73.13	0	0	11.4
2014	7	20	2	0	27	35	0	0	0	0	0	0	0	73.08	0	0	11.4
2014	7	20	2	10	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	2	20	27	34	0	0	0	0	0	0	0	73.02	0	0	11
2014	7	20	2	30	27	35	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	20	2	40	27	34	0	0	0	0	0	0	0	72.97	0	0	11.2
2014	7	20	2	50	27	35	0	0	0	0	0	0	0	72.91	0	0	11.2
2014	7	20	3	0	27	35	0	0	0	0	0	0	0	72.88	0	0	11.2
2014	7	20	3	10	27	34	0	0	0	0	0	0	0	72.84	0	0	11.2
2014	7	20	3	20	27	34	0	0	0	0	0	0	0	72.81	0	0	11.2
2014	7	20	3	30	27	34	0	0	0	0	0	0	0	72.77	0	0	11.2
2014	7	20	3	40	27	35	0	0	0	0	0	0	0	72.73	0	0	11.2
2014	7	20	3	50	27	34	0	0	0	0	0	0	0	72.7	0	0	11
2014	7	20	4	0	27	35	0	0	0	0	0	0	0	72.66	0	0	11.2
2014	7	20	4	10	27	34	0	0	0	0	0	0	0	72.63	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	4	20	27	34	0	0	0	0	0	0	0	72.61	0	0	11.2
2014	7	20	4	30	27	35	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	20	4	40	27	35	0	0	0	0	0	0	0	72.55	0	0	11.2
2014	7	20	4	50	27	34	0	0	0	0	0	0	0	72.52	0	0	11.2
2014	7	20	5	0	27	34	0	0	0	0	0	0	0	72.48	0	0	11.2
2014	7	20	5	10	27	34	0	0	0	0	0	0	0	72.45	0	0	11.2
2014	7	20	5	20	27	34	0	0	0	0	0	0	0	72.43	0	0	11.2
2014	7	20	5	30	27	34	0	0	0	0	0	0	0	72.39	0	0	11.2
2014	7	20	5	40	27	34	0	0	0	0	0	0	0	72.36	0	0	11.2
2014	7	20	5	50	27	34	0	0	0	0	0	0	0	72.34	0	0	11.2
2014	7	20	6	0	27	35	0	0	0	0	0	0	0	72.32	0	0	11.2
2014	7	20	6	10	27	35	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	20	6	20	27	35	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	20	6	30	27	35	0	0	0	0	0	0	0	72.25	0	0	11.2
2014	7	20	6	40	27	34	0	0	0	0	0	0	0	72.21	0	0	11.2
2014	7	20	6	50	27	35	0	0	0	0	0	0	0	72.19	0	0	11.2
2014	7	20	7	0	27	35	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	20	7	10	27	34	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	20	7	20	27	35	0	0	0	0	0	0	0	72.1	0	0	11.2
2014	7	20	7	30	27	34	0	0	0	0	0	0	0	72.09	0	0	11.2
2014	7	20	7	40	27	34	0	0	0	0	0	0	0	72.07	0	0	11.2
2014	7	20	7	50	27	34	0	0	0	0	0	0	0	72.05	0	0	11.2
2014	7	20	8	0	27	34	0	0	0	0	0	0	0	72.03	0	0	11.4
2014	7	20	8	10	27	34	0	0	0	0	0	0	0	72.03	0	0	11.4
2014	7	20	8	20	27	34	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	20	8	30	27	34	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	20	8	40	27	34	0	0	0	0	0	0	0	72.18	0	0	13.4
2014	7	20	8	50	27	34	0	0	0	0	0	0	0	72.21	0	0	13.4
2014	7	20	9	0	27	35	0	0	0	0	0	0	0	72.23	0	0	13.4
2014	7	20	9	10	27	34	0	0	0	0	0	0	0	72.19	0	0	12.6
2014	7	20	9	20	27	34	0	0	0	0	0	0	0	72.16	0	0	12.8
2014	7	20	9	30	27	34	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	20	9	40	27	34	0	0	0	0	0	0	0	72.12	0	0	12.6
2014	7	20	9	50	27	34	0	0	0	0	0	0	0	72.09	0	0	12.4
2014	7	20	10	0	27	34	0	0	0	0	0	0	0	72.12	0	0	12.6
2014	7	20	10	10	27	35	0	0	0	0	0	0	0	72.12	0	0	13
2014	7	20	10	20	27	34	0	0	0	0	0	0	0	72.23	0	0	13
2014	7	20	10	30	27	35	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	20	10	40	27	34	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	20	10	50	27	34	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	20	11	0	27	35	0	0	0	0	0	0	0	72.3	0	0	13
2014	7	20	11	10	27	34	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	20	11	20	27	35	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	20	11	30	27	34	0	0	0	0	0	0	0	72.43	0	0	12.8
2014	7	20	11	40	27	35	0	0	0	0	0	0	0	72.39	0	0	12.8
2014	7	20	11	50	27	34	0	0	0	0	0	0	0	72.39	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	12	0	27	34	0	0	0	0	0	0	0	72.45	0	0	12.8
2014	7	20	12	10	27	34	0	0	0	0	0	0	0	72.54	0	0	12.8
2014	7	20	12	20	27	34	0	0	0	0	0	0	0	72.54	0	0	12.8
2014	7	20	12	30	27	34	0	0	0	0	0	0	0	72.46	0	0	12.8
2014	7	20	12	40	27	34	0	0	0	0	0	0	0	72.41	0	0	12.6
2014	7	20	12	50	27	35	0	0	0	0	0	0	0	72.37	0	0	12.4
2014	7	20	13	0	27	35	0	0	0	0	0	0	0	72.37	0	0	12.6
2014	7	20	13	10	27	34	0	0	0	0	0	0	0	72.54	0	0	13
2014	7	20	13	20	27	35	0	0	0	0	0	0	0	72.68	0	0	13
2014	7	20	13	30	27	34	0	0	0	0	0	0	0	72.77	0	0	13
2014	7	20	13	40	27	34	0	0	0	0	0	0	0	72.79	0	0	13
2014	7	20	13	50	27	34	0	0	0	0	0	0	0	72.81	0	0	13
2014	7	20	14	0	27	34	0	0	0	0	0	0	0	72.84	0	0	13
2014	7	20	14	10	27	35	0	0	0	0	0	0	0	72.9	0	0	12.8
2014	7	20	14	20	27	34	0	0	0	0	0	0	0	72.9	0	0	12.8
2014	7	20	14	30	27	34	0	0	0	0	0	0	0	72.88	0	0	12.8
2014	7	20	14	40	27	34	0	0	0	0	0	0	0	72.84	0	0	12.8
2014	7	20	14	50	27	35	0	0	0	0	0	0	0	72.84	0	0	12.8
2014	7	20	15	0	27	34	0	0	0	0	0	0	0	72.82	0	0	12.8
2014	7	20	15	10	27	34	0	0	0	0	0	0	0	72.82	0	0	12.8
2014	7	20	15	20	27	34	0	0	0	0	0	0	0	72.77	0	0	12.8
2014	7	20	15	30	27	34	0	0	0	0	0	0	0	72.81	0	0	12.8
2014	7	20	15	40	27	34	0	0	0	0	0	0	0	72.88	0	0	12.8
2014	7	20	15	50	27	34	0	0	0	0	0	0	0	72.88	0	0	12.6
2014	7	20	16	0	27	34	0	0	0	0	0	0	0	72.86	0	0	12.6
2014	7	20	16	10	27	34	0	0	0	0	0	0	0	72.86	0	0	12.4
2014	7	20	16	20	27	35	0	0	0	0	0	0	0	72.9	0	0	12.6
2014	7	20	16	30	27	34	0	0	0	0	0	0	0	72.88	0	0	12.4
2014	7	20	16	40	27	34	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	7	20	16	50	27	34	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	7	20	17	0	27	35	0	0	0	0	0	0	0	72.9	0	0	12
2014	7	20	17	10	27	34	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	20	17	20	27	35	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	20	17	30	27	34	0	0	0	0	0	0	0	72.86	0	0	11.8
2014	7	20	17	40	27	34	0	0	0	0	0	0	0	72.88	0	0	11.6
2014	7	20	17	50	27	34	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	20	18	0	27	34	0	0	0	0	0	0	0	72.88	0	0	11.6
2014	7	20	18	10	27	35	0	0	0	0	0	0	0	72.9	0	0	11.6
2014	7	20	18	20	27	34	0	0	0	0	0	0	0	72.9	0	0	11.6
2014	7	20	18	30	27	35	0	0	0	0	0	0	0	72.93	0	0	11.6
2014	7	20	18	40	27	34	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	20	18	50	27	34	0	0	0	0	0	0	0	72.95	0	0	11.6
2014	7	20	19	0	27	34	0	0	0	0	0	0	0	72.97	0	0	11.4
2014	7	20	19	10	27	35	0	0	0	0	0	0	0	72.99	0	0	11.4
2014	7	20	19	20	27	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	20	19	30	27	34	0	0	0	0	0	0	0	72.99	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	19	40	27	35	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	20	19	50	27	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	20	20	0	27	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	20	20	10	27	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	20	20	20	27	34	0	0	0	0	0	0	0	73	0	0	11.4
2014	7	20	20	30	27	35	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	20	40	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	20	50	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	21	0	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	21	10	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	21	20	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	21	30	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	21	40	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	21	50	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	22	0	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	22	10	27	34	0	0	0	0	0	0	0	73.04	0	0	11.2
2014	7	20	22	20	27	34	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	20	22	30	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	22	40	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	22	50	27	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	23	0	27	35	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	20	23	10	27	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	20	23	20	27	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	20	23	30	27	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	20	23	40	27	34	0	0	0	0	0	0	0	72.99	0	0	10.6
2014	7	20	23	50	27	35	0	0	0	0	0	0	0	72.97	0	0	11
2014	7	21	0	0	27	34	0	0	0	0	0	0	0	72.97	0	0	11.2
2014	7	21	0	10	27	35	0	0	0	0	0	0	0	72.95	0	0	11
2014	7	21	0	20	27	35	0	0	0	0	0	0	0	72.93	0	0	11
2014	7	21	0	30	27	34	0	0	0	0	0	0	0	72.91	0	0	11
2014	7	21	0	40	27	34	0	0	0	0	0	0	0	72.9	0	0	11
2014	7	21	0	50	27	34	0	0	0	0	0	0	0	72.88	0	0	11
2014	7	21	1	0	27	34	0	0	0	0	0	0	0	72.86	0	0	11
2014	7	21	1	10	27	34	0	0	0	0	0	0	0	72.84	0	0	11
2014	7	21	1	20	27	34	0	0	0	0	0	0	0	72.81	0	0	11
2014	7	21	1	30	27	34	0	0	0	0	0	0	0	72.79	0	0	11
2014	7	21	1	40	27	35	0	0	0	0	0	0	0	72.73	0	0	11
2014	7	21	1	50	27	35	0	0	0	0	0	0	0	72.7	0	0	11
2014	7	21	2	0	27	34	0	0	0	0	0	0	0	72.7	0	0	10.8
2014	7	21	2	10	27	34	0	0	0	0	0	0	0	72.64	0	0	11
2014	7	21	2	20	27	34	0	0	0	0	0	0	0	72.61	0	0	11
2014	7	21	2	30	27	34	0	0	0	0	0	0	0	72.57	0	0	11
2014	7	21	2	40	27	34	0	0	0	0	0	0	0	72.54	0	0	11
2014	7	21	2	50	27	34	0	0	0	0	0	0	0	72.5	0	0	11
2014	7	21	3	0	27	34	0	0	0	0	0	0	0	72.46	0	0	11
2014	7	21	3	10	27	35	0	0	0	0	0	0	0	72.41	0	0	11

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	3	20	27	34	0	0	0	0	0	0	0	72.37	0	0	11.2
2014	7	21	3	30	27	34	0	0	0	0	0	0	0	72.34	0	0	11.2
2014	7	21	3	40	27	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	21	3	50	27	34	0	0	0	0	0	0	0	72.25	0	0	11.4
2014	7	21	4	0	27	34	0	0	0	0	0	0	0	72.21	0	0	11.2
2014	7	21	4	10	27	34	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	21	4	20	27	35	0	0	0	0	0	0	0	72.14	0	0	11.2
2014	7	21	4	30	27	35	0	0	0	0	0	0	0	72.09	0	0	11.2
2014	7	21	4	40	27	35	0	0	0	0	0	0	0	72.03	0	0	11.4
2014	7	21	4	50	27	35	0	0	0	0	0	0	0	72	0	0	11.4
2014	7	21	5	0	27	34	0	0	0	0	0	0	0	71.96	0	0	11.4
2014	7	21	5	10	27	35	0	0	0	0	0	0	0	71.92	0	0	11.2
2014	7	21	5	20	27	34	0	0	0	0	0	0	0	71.89	0	0	11.2
2014	7	21	5	30	27	34	0	0	0	0	0	0	0	71.85	0	0	11.2
2014	7	21	5	40	27	35	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	21	5	50	27	35	0	0	0	0	0	0	0	71.76	0	0	11.4
2014	7	21	6	0	27	34	0	0	0	0	0	0	0	71.73	0	0	11.4
2014	7	21	6	10	27	34	0	0	0	0	0	0	0	71.69	0	0	11.4
2014	7	21	6	20	27	34	0	0	0	0	0	0	0	71.65	0	0	11.4
2014	7	21	6	30	27	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	21	6	40	27	35	0	0	0	0	0	0	0	71.58	0	0	11.4
2014	7	21	6	50	27	35	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	21	7	0	27	34	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	21	7	10	27	35	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	21	7	20	27	35	0	0	0	0	0	0	0	71.47	0	0	12
2014	7	21	7	30	27	35	0	0	0	0	0	0	0	71.46	0	0	12.2
2014	7	21	7	40	27	35	0	0	0	0	0	0	0	71.46	0	0	12.4
2014	7	21	7	50	27	34	0	0	0	0	0	0	0	71.46	0	0	12.6
2014	7	21	8	0	27	34	0	0	0	0	0	0	0	71.47	0	0	12.8
2014	7	21	8	10	27	35	0	0	0	0	0	0	0	71.47	0	0	13
2014	7	21	8	20	27	34	0	0	0	0	0	0	0	71.47	0	0	13
2014	7	21	8	30	27	34	0	0	0	0	0	0	0	71.49	0	0	13
2014	7	21	8	40	27	35	0	0	0	0	0	0	0	71.51	0	0	13
2014	7	21	8	50	27	34	0	0	0	0	0	0	0	71.53	0	0	12.8
2014	7	21	9	0	27	34	0	0	0	0	0	0	0	71.55	0	0	12.6
2014	7	21	9	10	27	34	0	0	0	0	0	0	0	71.56	0	0	12.6
2014	7	21	9	20	27	34	0	0	0	0	0	0	0	71.58	0	0	12.6
2014	7	21	9	30	27	35	0	0	0	0	0	0	0	71.62	0	0	12.6
2014	7	21	9	40	27	35	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	21	9	50	27	34	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	21	10	0	27	35	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	21	10	10	27	34	0	0	0	0	0	0	0	71.73	0	0	12.8
2014	7	21	10	20	27	35	0	0	0	0	0	0	0	71.74	0	0	12.6
2014	7	21	10	30	27	35	0	0	0	0	0	0	0	71.78	0	0	12.6
2014	7	21	10	40	27	34	0	0	0	0	0	0	0	71.82	0	0	12.8
2014	7	21	10	50	27	35	0	0	0	0	0	0	0	71.85	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	11	0	27	34	0	0	0	0	0	0	0	71.91	0	0	12.8
2014	7	21	11	10	27	34	0	0	0	0	0	0	0	71.96	0	0	12.8
2014	7	21	11	20	27	35	0	0	0	0	0	0	0	71.98	0	0	13
2014	7	21	11	30	27	35	0	0	0	0	0	0	0	72.01	0	0	13
2014	7	21	11	40	27	35	0	0	0	0	0	0	0	72.07	0	0	13
2014	7	21	11	50	27	34	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	21	12	0	27	34	0	0	0	0	0	0	0	72.16	0	0	13
2014	7	21	12	10	27	34	0	0	0	0	0	0	0	72.19	0	0	13
2014	7	21	12	20	27	34	0	0	0	0	0	0	0	72.21	0	0	13
2014	7	21	12	30	27	35	0	0	0	0	0	0	0	72.25	0	0	13
2014	7	21	12	40	27	35	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	21	12	50	27	34	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	21	13	0	27	34	0	0	0	0	0	0	0	72.37	0	0	13
2014	7	21	13	10	27	34	0	0	0	0	0	0	0	72.39	0	0	13
2014	7	21	13	20	27	34	0	0	0	0	0	0	0	72.43	0	0	13
2014	7	21	13	30	27	35	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	21	13	40	27	34	0	0	0	0	0	0	0	72.5	0	0	13
2014	7	21	13	50	27	34	0	0	0	0	0	0	0	72.52	0	0	13
2014	7	21	14	0	27	34	0	0	0	0	0	0	0	72.5	0	0	13
2014	7	21	14	10	27	34	0	0	0	0	0	0	0	72.54	0	0	13
2014	7	21	14	20	27	34	0	0	0	0	0	0	0	72.37	0	0	12.8
2014	7	21	14	30	27	34	0	0	0	0	0	0	0	72.34	0	0	12.8
2014	7	21	14	40	27	34	0	0	0	0	0	0	0	72.43	0	0	13
2014	7	21	14	50	27	34	0	0	0	0	0	0	0	72.54	0	0	13
2014	7	21	15	0	27	34	0	0	0	0	0	0	0	72.55	0	0	13
2014	7	21	15	10	27	34	0	0	0	0	0	0	0	72.57	0	0	13
2014	7	21	15	20	27	35	0	0	0	0	0	0	0	72.55	0	0	12.8
2014	7	21	15	30	27	35	0	0	0	0	0	0	0	72.59	0	0	12.8
2014	7	21	15	40	27	34	0	0	0	0	0	0	0	72.57	0	0	12.8
2014	7	21	15	50	27	34	0	0	0	0	0	0	0	72.54	0	0	12.6
2014	7	21	16	0	27	34	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	21	16	10	27	35	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	21	16	20	27	34	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	21	16	30	27	34	0	0	0	0	0	0	0	72.57	0	0	12.8
2014	7	21	16	40	27	34	0	0	0	0	0	0	0	72.57	0	0	12.6
2014	7	21	16	50	27	34	0	0	0	0	0	0	0	72.57	0	0	12.2
2014	7	21	17	0	27	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	21	17	10	27	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	21	17	20	27	35	0	0	0	0	0	0	0	72.59	0	0	11.8
2014	7	21	17	30	27	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	21	17	40	27	35	0	0	0	0	0	0	0	72.57	0	0	11.6
2014	7	21	17	50	27	35	0	0	0	0	0	0	0	72.57	0	0	11.6
2014	7	21	18	0	27	35	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	21	18	10	27	34	0	0	0	0	0	0	0	72.59	0	0	11.6
2014	7	21	18	20	27	34	0	0	0	0	0	0	0	72.59	0	0	11.4
2014	7	21	18	30	27	35	0	0	0	0	0	0	0	72.59	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	18	40	27	34	0	0	0	0	0	0	0	72.59	0	0	11.4
2014	7	21	18	50	27	34	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	21	19	0	27	34	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	21	19	10	27	34	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	21	19	20	27	35	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	21	19	30	27	34	0	0	0	0	0	0	0	72.61	0	0	11.6
2014	7	21	19	40	27	34	0	0	0	0	0	0	0	72.61	0	0	11.6
2014	7	21	19	50	27	34	0	0	0	0	0	0	0	72.63	0	0	11.6
2014	7	21	20	0	27	34	0	0	0	0	0	0	0	72.63	0	0	11.4
2014	7	21	20	10	27	35	0	0	0	0	0	0	0	72.63	0	0	11.4
2014	7	21	20	20	27	34	0	0	0	0	0	0	0	72.64	0	0	11.4
2014	7	21	20	30	27	35	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	20	40	27	35	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	20	50	27	33	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	21	0	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	21	10	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	21	20	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	21	30	27	34	0	0	0	0	0	0	0	72.68	0	0	11.4
2014	7	21	21	40	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	21	50	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	22	0	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	22	10	27	35	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	22	20	27	35	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	22	30	27	34	0	0	0	0	0	0	0	72.66	0	0	11.4
2014	7	21	22	40	27	35	0	0	0	0	0	0	0	72.66	0	0	11
2014	7	21	22	50	27	33	0	0	0	0	0	0	0	72.64	0	0	10.8
2014	7	21	23	0	27	35	0	0	0	0	0	0	0	72.64	0	0	10.8
2014	7	21	23	10	27	35	0	0	0	0	0	0	0	72.64	0	0	11
2014	7	21	23	20	27	35	0	0	0	0	0	0	0	72.63	0	0	10.8
2014	7	21	23	30	27	34	0	0	0	0	0	0	0	72.63	0	0	11
2014	7	21	23	40	27	34	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	21	23	50	27	34	0	0	0	0	0	0	0	72.61	0	0	11.4
2014	7	22	0	0	27	34	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	22	0	10	27	34	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	22	0	20	27	34	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	22	0	30	27	34	0	0	0	0	0	0	0	72.59	0	0	11.2
2014	7	22	0	40	27	34	0	0	0	0	0	0	0	72.57	0	0	11.4
2014	7	22	0	50	27	34	0	0	0	0	0	0	0	72.55	0	0	11.4
2014	7	22	1	0	27	34	0	0	0	0	0	0	0	72.55	0	0	11.4
2014	7	22	1	10	27	34	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	22	1	20	27	34	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	22	1	30	27	34	0	0	0	0	0	0	0	72.52	0	0	11.4
2014	7	22	1	40	27	35	0	0	0	0	0	0	0	72.48	0	0	11.2
2014	7	22	1	50	27	34	0	0	0	0	0	0	0	72.46	0	0	11.2
2014	7	22	2	0	27	35	0	0	0	0	0	0	0	72.45	0	0	11.2
2014	7	22	2	10	27	34	0	0	0	0	0	0	0	72.41	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	2	20	27	35	0	0	0	0	0	0	0	72.39	0	0	11.2
2014	7	22	2	30	27	34	0	0	0	0	0	0	0	72.37	0	0	11.2
2014	7	22	2	40	27	34	0	0	0	0	0	0	0	72.34	0	0	11.2
2014	7	22	2	50	27	35	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	22	3	0	27	34	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	22	3	10	27	34	0	0	0	0	0	0	0	72.25	0	0	11.2
2014	7	22	3	20	27	34	0	0	0	0	0	0	0	72.23	0	0	11.2
2014	7	22	3	30	27	36	0	0	0	0	0	0	0	72.19	0	0	11.4
2014	7	22	3	40	27	34	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	22	3	50	27	34	0	0	0	0	0	0	0	72.12	0	0	11.2
2014	7	22	4	0	27	35	0	0	0	0	0	0	0	72.1	0	0	11.2
2014	7	22	4	10	27	35	0	0	0	0	0	0	0	72.07	0	0	11.2
2014	7	22	4	20	27	34	0	0	0	0	0	0	0	72.03	0	0	11.2
2014	7	22	4	30	27	35	0	0	0	0	0	0	0	72.01	0	0	11.2
2014	7	22	4	40	27	34	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	22	4	50	27	35	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	22	5	0	27	35	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	22	5	10	27	35	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	22	5	20	27	35	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	22	5	30	27	35	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	22	5	40	27	35	0	0	0	0	0	0	0	71.76	0	0	11.4
2014	7	22	5	50	27	34	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	22	6	0	27	34	0	0	0	0	0	0	0	71.69	0	0	11.4
2014	7	22	6	10	27	35	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	22	6	20	27	35	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	22	6	30	27	35	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	22	6	40	27	34	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	22	6	50	27	35	0	0	0	0	0	0	0	71.51	0	0	11.8
2014	7	22	7	0	27	35	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	22	7	10	27	34	0	0	0	0	0	0	0	71.46	0	0	11.8
2014	7	22	7	20	27	35	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	22	7	30	27	34	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	22	7	40	27	34	0	0	0	0	0	0	0	71.44	0	0	12.2
2014	7	22	7	50	27	34	0	0	0	0	0	0	0	71.42	0	0	12.2
2014	7	22	8	0	27	35	0	0	0	0	0	0	0	71.44	0	0	12.4
2014	7	22	8	10	27	35	0	0	0	0	0	0	0	71.46	0	0	12.8
2014	7	22	8	20	27	35	0	0	0	0	0	0	0	71.46	0	0	13
2014	7	22	8	30	27	35	0	0	0	0	0	0	0	71.46	0	0	12.8
2014	7	22	8	40	27	35	0	0	0	0	0	0	0	71.49	0	0	12.8
2014	7	22	8	50	27	34	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	22	9	0	27	34	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	22	9	10	27	35	0	0	0	0	0	0	0	71.55	0	0	12.8
2014	7	22	9	20	27	35	0	0	0	0	0	0	0	71.56	0	0	12.8
2014	7	22	9	30	27	34	0	0	0	0	0	0	0	71.58	0	0	12.8
2014	7	22	9	40	27	35	0	0	0	0	0	0	0	71.58	0	0	12.8
2014	7	22	9	50	27	34	0	0	0	0	0	0	0	71.62	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	10	0	27	35	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	22	10	10	27	34	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	22	10	20	27	34	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	22	10	30	27	35	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	22	10	40	27	34	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	22	10	50	27	34	0	0	0	0	0	0	0	71.67	0	0	12.8
2014	7	22	11	0	27	34	0	0	0	0	0	0	0	71.73	0	0	12.8
2014	7	22	11	10	27	34	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	22	11	20	27	34	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	22	11	30	27	34	0	0	0	0	0	0	0	71.82	0	0	12.8
2014	7	22	11	40	27	34	0	0	0	0	0	0	0	71.87	0	0	12.8
2014	7	22	11	50	27	35	0	0	0	0	0	0	0	71.91	0	0	12.8
2014	7	22	12	0	27	34	0	0	0	0	0	0	0	71.87	0	0	12.8
2014	7	22	12	10	27	34	0	0	0	0	0	0	0	71.91	0	0	12.8
2014	7	22	12	20	27	34	0	0	0	0	0	0	0	71.91	0	0	12.8
2014	7	22	12	30	27	35	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	22	12	40	27	34	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	22	12	50	27	35	0	0	0	0	0	0	0	72.03	0	0	13
2014	7	22	13	0	27	34	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	22	13	10	27	34	0	0	0	0	0	0	0	72.18	0	0	13
2014	7	22	13	20	27	34	0	0	0	0	0	0	0	72.25	0	0	13
2014	7	22	13	30	27	34	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	22	13	40	27	34	0	0	0	0	0	0	0	72.3	0	0	13
2014	7	22	13	50	27	35	0	0	0	0	0	0	0	72.34	0	0	13
2014	7	22	14	0	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	14	10	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	14	20	27	34	0	0	0	0	0	0	0	72.37	0	0	13
2014	7	22	14	30	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	14	40	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	14	50	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	15	0	27	35	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	15	10	27	35	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	15	20	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	15	30	27	34	0	0	0	0	0	0	0	72.36	0	0	13
2014	7	22	15	40	27	34	0	0	0	0	0	0	0	72.36	0	0	12.8
2014	7	22	15	50	27	34	0	0	0	0	0	0	0	72.34	0	0	12.8
2014	7	22	16	0	27	34	0	0	0	0	0	0	0	72.34	0	0	12.8
2014	7	22	16	10	27	34	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	22	16	20	27	34	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	22	16	30	27	34	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	22	16	40	27	34	0	0	0	0	0	0	0	72.3	0	0	12.6
2014	7	22	16	50	27	34	0	0	0	0	0	0	0	72.3	0	0	12.4
2014	7	22	17	0	27	34	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	7	22	17	10	27	34	0	0	0	0	0	0	0	72.3	0	0	12
2014	7	22	17	20	27	34	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	22	17	30	27	34	0	0	0	0	0	0	0	72.28	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	17	40	27	35	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	22	17	50	27	34	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	22	18	0	27	34	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	22	18	10	27	34	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	22	18	20	27	35	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	18	30	27	34	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	18	40	27	34	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	18	50	27	34	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	19	0	27	35	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	19	10	27	35	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	19	20	27	34	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	19	30	27	35	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	22	19	40	27	35	0	0	0	0	0	0	0	72.27	0	0	11.2
2014	7	22	19	50	27	34	0	0	0	0	0	0	0	72.27	0	0	11
2014	7	22	20	0	27	34	0	0	0	0	0	0	0	72.28	0	0	11
2014	7	22	20	10	27	34	0	0	0	0	0	0	0	72.28	0	0	11
2014	7	22	20	20	27	35	0	0	0	0	0	0	0	72.28	0	0	11
2014	7	22	20	30	27	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	22	20	40	27	35	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	22	20	50	27	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	22	21	0	27	34	0	0	0	0	0	0	0	72.3	0	0	11.4
2014	7	22	21	10	27	34	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	22	21	20	27	34	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	22	21	30	27	34	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	22	21	40	27	34	0	0	0	0	0	0	0	72.3	0	0	11.2
2014	7	22	21	50	27	35	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	22	22	0	27	35	0	0	0	0	0	0	0	72.28	0	0	11.2
2014	7	22	22	10	27	34	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	22	22	20	27	34	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	22	22	30	27	35	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	22	22	40	27	35	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	22	50	27	34	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	22	23	0	27	35	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	22	23	10	27	35	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	22	23	20	27	34	0	0	0	0	0	0	0	72.21	0	0	11.4
2014	7	22	23	30	27	34	0	0	0	0	0	0	0	72.19	0	0	11.4
2014	7	22	23	40	27	35	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	22	23	50	27	34	0	0	0	0	0	0	0	72.14	0	0	11.6
2014	7	23	0	0	27	34	0	0	0	0	0	0	0	72.12	0	0	11.6
2014	7	23	0	10	27	34	0	0	0	0	0	0	0	72.1	0	0	11.6
2014	7	23	0	20	27	34	0	0	0	0	0	0	0	72.09	0	0	11.6
2014	7	23	0	30	27	34	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	23	0	40	27	34	0	0	0	0	0	0	0	72.01	0	0	11.6
2014	7	23	0	50	27	35	0	0	0	0	0	0	0	71.98	0	0	11.6
2014	7	23	1	0	27	35	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	23	1	10	27	34	0	0	0	0	0	0	0	71.92	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	1	20	27	35	0	0	0	0	0	0	0	71.89	0	0	11.6
2014	7	23	1	30	27	35	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	23	1	40	27	34	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	23	1	50	27	34	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	23	2	0	27	34	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	23	2	10	27	35	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	23	2	20	27	35	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	23	2	30	27	34	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	23	2	40	27	35	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	23	2	50	27	34	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	23	3	0	27	34	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	23	3	10	27	33	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	23	3	20	27	34	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	23	3	30	27	34	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	23	3	40	27	34	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	23	3	50	27	34	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	23	4	0	27	34	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	23	4	10	27	34	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	23	4	20	27	35	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	23	4	30	27	35	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	23	4	40	27	34	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	23	4	50	27	34	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	23	5	0	27	35	0	0	0	0	0	0	0	70.93	0	0	11.4
2014	7	23	5	10	27	35	0	0	0	0	0	0	0	70.88	0	0	11.4
2014	7	23	5	20	27	35	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	23	5	30	27	34	0	0	0	0	0	0	0	70.77	0	0	11.4
2014	7	23	5	40	27	35	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	23	5	50	27	35	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	23	6	0	27	34	0	0	0	0	0	0	0	70.66	0	0	11.4
2014	7	23	6	10	27	34	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	23	6	20	27	34	0	0	0	0	0	0	0	70.57	0	0	11.4
2014	7	23	6	30	27	34	0	0	0	0	0	0	0	70.52	0	0	11.4
2014	7	23	6	40	27	35	0	0	0	0	0	0	0	70.48	0	0	11.2
2014	7	23	6	50	27	34	0	0	0	0	0	0	0	70.45	0	0	11.6
2014	7	23	7	0	27	34	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	23	7	10	27	34	0	0	0	0	0	0	0	70.38	0	0	12
2014	7	23	7	20	27	34	0	0	0	0	0	0	0	70.36	0	0	12.2
2014	7	23	7	30	27	35	0	0	0	0	0	0	0	70.36	0	0	12.4
2014	7	23	7	40	27	35	0	0	0	0	0	0	0	70.34	0	0	12.4
2014	7	23	7	50	27	35	0	0	0	0	0	0	0	70.34	0	0	12.6
2014	7	23	8	0	27	34	0	0	0	0	0	0	0	70.34	0	0	13
2014	7	23	8	10	27	35	0	0	0	0	0	0	0	70.34	0	0	13
2014	7	23	8	20	27	34	0	0	0	0	0	0	0	70.36	0	0	13
2014	7	23	8	30	27	34	0	0	0	0	0	0	0	70.36	0	0	13
2014	7	23	8	40	27	34	0	0	0	0	0	0	0	70.38	0	0	13
2014	7	23	8	50	27	35	0	0	0	0	0	0	0	70.39	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	9	0	27	35	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	23	9	10	27	35	0	0	0	0	0	0	0	70.43	0	0	13
2014	7	23	9	20	27	34	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	23	9	30	27	35	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	23	9	40	27	35	0	0	0	0	0	0	0	70.52	0	0	13
2014	7	23	9	50	27	35	0	0	0	0	0	0	0	70.56	0	0	13
2014	7	23	10	0	27	34	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	23	10	10	27	35	0	0	0	0	0	0	0	70.61	0	0	12.8
2014	7	23	10	20	27	34	0	0	0	0	0	0	0	70.57	0	0	12.8
2014	7	23	10	30	27	34	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	23	10	40	27	34	0	0	0	0	0	0	0	70.66	0	0	12.8
2014	7	23	10	50	27	35	0	0	0	0	0	0	0	70.74	0	0	12.8
2014	7	23	11	0	27	35	0	0	0	0	0	0	0	70.77	0	0	12.8
2014	7	23	11	10	27	34	0	0	0	0	0	0	0	70.83	0	0	12.8
2014	7	23	11	20	27	35	0	0	0	0	0	0	0	70.88	0	0	12.8
2014	7	23	11	30	27	34	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	23	11	40	27	35	0	0	0	0	0	0	0	70.88	0	0	12.8
2014	7	23	11	50	27	35	0	0	0	0	0	0	0	70.9	0	0	12.8
2014	7	23	12	0	27	35	0	0	0	0	0	0	0	70.9	0	0	12.8
2014	7	23	12	10	27	34	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	23	12	20	27	34	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	23	12	30	27	34	0	0	0	0	0	0	0	70.97	0	0	12.8
2014	7	23	12	40	27	35	0	0	0	0	0	0	0	70.97	0	0	12.8
2014	7	23	12	50	27	34	0	0	0	0	0	0	0	71.01	0	0	12.8
2014	7	23	13	0	27	34	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	23	13	10	27	34	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	23	13	20	27	34	0	0	0	0	0	0	0	71.29	0	0	12.8
2014	7	23	13	30	27	34	0	0	0	0	0	0	0	71.38	0	0	12.8
2014	7	23	13	40	27	34	0	0	0	0	0	0	0	71.42	0	0	12.8
2014	7	23	13	50	27	35	0	0	0	0	0	0	0	71.46	0	0	12.8
2014	7	23	14	0	27	34	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	23	14	10	27	34	0	0	0	0	0	0	0	71.53	0	0	12.8
2014	7	23	14	20	27	35	0	0	0	0	0	0	0	71.56	0	0	12.8
2014	7	23	14	30	27	35	0	0	0	0	0	0	0	71.58	0	0	12.8
2014	7	23	14	40	27	35	0	0	0	0	0	0	0	71.6	0	0	12.8
2014	7	23	14	50	27	34	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	23	15	0	27	34	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	23	15	10	27	34	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	23	15	20	27	35	0	0	0	0	0	0	0	71.65	0	0	12.6
2014	7	23	15	30	27	35	0	0	0	0	0	0	0	71.65	0	0	12.6
2014	7	23	15	40	27	34	0	0	0	0	0	0	0	71.65	0	0	12.6
2014	7	23	15	50	27	34	0	0	0	0	0	0	0	71.65	0	0	12.6
2014	7	23	16	0	27	35	0	0	0	0	0	0	0	71.67	0	0	12.8
2014	7	23	16	10	27	35	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	23	16	20	27	34	0	0	0	0	0	0	0	71.67	0	0	12.8
2014	7	23	16	30	27	34	0	0	0	0	0	0	0	71.67	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	16	40	27	34	0	0	0	0	0	0	0	71.67	0	0	12.6
2014	7	23	16	50	27	35	0	0	0	0	0	0	0	71.67	0	0	12.4
2014	7	23	17	0	27	34	0	0	0	0	0	0	0	71.67	0	0	12
2014	7	23	17	10	27	34	0	0	0	0	0	0	0	71.69	0	0	12
2014	7	23	17	20	27	35	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	23	17	30	27	35	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	23	17	40	27	35	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	23	17	50	27	35	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	23	18	0	27	34	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	23	18	10	27	35	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	23	18	20	27	35	0	0	0	0	0	0	0	71.67	0	0	11.4
2014	7	23	18	30	27	34	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	23	18	40	27	34	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	23	18	50	27	33	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	23	19	0	27	34	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	23	19	10	27	34	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	23	19	20	27	35	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	23	19	30	27	35	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	23	19	40	27	35	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	23	19	50	27	34	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	23	20	0	27	35	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	23	20	10	27	35	0	0	0	0	0	0	0	71.78	0	0	11.4
2014	7	23	20	20	27	35	0	0	0	0	0	0	0	71.8	0	0	11.4
2014	7	23	20	30	27	35	0	0	0	0	0	0	0	71.8	0	0	11.4
2014	7	23	20	40	27	34	0	0	0	0	0	0	0	71.82	0	0	11.4
2014	7	23	20	50	27	35	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	23	21	0	27	34	0	0	0	0	0	0	0	71.83	0	0	11
2014	7	23	21	10	27	34	0	0	0	0	0	0	0	71.82	0	0	11
2014	7	23	21	20	27	34	0	0	0	0	0	0	0	71.82	0	0	10.8
2014	7	23	21	30	27	34	0	0	0	0	0	0	0	71.82	0	0	10
2014	7	23	21	40	27	34	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	23	21	50	27	35	0	0	0	0	0	0	0	71.82	0	0	11.2
2014	7	23	22	0	27	34	0	0	0	0	0	0	0	71.8	0	0	11.2
2014	7	23	22	10	27	35	0	0	0	0	0	0	0	71.8	0	0	11.2
2014	7	23	22	20	27	34	0	0	0	0	0	0	0	71.8	0	0	11.2
2014	7	23	22	30	27	34	0	0	0	0	0	0	0	71.78	0	0	11
2014	7	23	22	40	27	35	0	0	0	0	0	0	0	71.78	0	0	10.4
2014	7	23	22	50	27	34	0	0	0	0	0	0	0	71.78	0	0	11.2
2014	7	23	23	0	27	35	0	0	0	0	0	0	0	71.76	0	0	11.2
2014	7	23	23	10	27	34	0	0	0	0	0	0	0	71.76	0	0	11.2
2014	7	23	23	20	27	35	0	0	0	0	0	0	0	71.73	0	0	11.2
2014	7	23	23	30	27	35	0	0	0	0	0	0	0	71.73	0	0	11.2
2014	7	23	23	40	27	34	0	0	0	0	0	0	0	71.71	0	0	11.2
2014	7	23	23	50	27	34	0	0	0	0	0	0	0	71.71	0	0	11.4
2014	7	24	0	0	27	34	0	0	0	0	0	0	0	71.69	0	0	11.4
2014	7	24	0	10	27	34	0	0	0	0	0	0	0	71.67	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	0	20	27	35	0	0	0	0	0	0	0	71.65	0	0	11.4
2014	7	24	0	30	27	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	24	0	40	27	35	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	24	0	50	27	35	0	0	0	0	0	0	0	71.58	0	0	11.4
2014	7	24	1	0	27	34	0	0	0	0	0	0	0	71.56	0	0	11.4
2014	7	24	1	10	27	34	0	0	0	0	0	0	0	71.53	0	0	11.2
2014	7	24	1	20	27	35	0	0	0	0	0	0	0	71.49	0	0	11.2
2014	7	24	1	30	27	35	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	24	1	40	27	34	0	0	0	0	0	0	0	71.42	0	0	11.2
2014	7	24	1	50	27	34	0	0	0	0	0	0	0	71.38	0	0	11.2
2014	7	24	2	0	27	34	0	0	0	0	0	0	0	71.33	0	0	11.2
2014	7	24	2	10	27	35	0	0	0	0	0	0	0	71.29	0	0	11.2
2014	7	24	2	20	27	34	0	0	0	0	0	0	0	71.26	0	0	11.2
2014	7	24	2	30	27	34	0	0	0	0	0	0	0	71.22	0	0	11.2
2014	7	24	2	40	27	35	0	0	0	0	0	0	0	71.17	0	0	11.2
2014	7	24	2	50	27	34	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	3	0	27	35	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	24	3	10	27	34	0	0	0	0	0	0	0	71.02	0	0	11.2
2014	7	24	3	20	27	34	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	24	3	30	27	35	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	24	3	40	27	34	0	0	0	0	0	0	0	70.9	0	0	11.2
2014	7	24	3	50	27	35	0	0	0	0	0	0	0	70.84	0	0	11.2
2014	7	24	4	0	27	35	0	0	0	0	0	0	0	70.81	0	0	11.2
2014	7	24	4	10	27	34	0	0	0	0	0	0	0	70.75	0	0	11.2
2014	7	24	4	20	27	34	0	0	0	0	0	0	0	70.72	0	0	11.2
2014	7	24	4	30	27	35	0	0	0	0	0	0	0	70.68	0	0	11.2
2014	7	24	4	40	27	35	0	0	0	0	0	0	0	70.63	0	0	11.2
2014	7	24	4	50	27	35	0	0	0	0	0	0	0	70.59	0	0	11.2
2014	7	24	5	0	27	34	0	0	0	0	0	0	0	70.54	0	0	11.2
2014	7	24	5	10	27	35	0	0	0	0	0	0	0	70.5	0	0	11.2
2014	7	24	5	20	27	35	0	0	0	0	0	0	0	70.47	0	0	11.2
2014	7	24	5	30	27	34	0	0	0	0	0	0	0	70.41	0	0	11.2
2014	7	24	5	40	27	35	0	0	0	0	0	0	0	70.36	0	0	11.2
2014	7	24	5	50	27	34	0	0	0	0	0	0	0	70.32	0	0	11.2
2014	7	24	6	0	27	35	0	0	0	0	0	0	0	70.27	0	0	11.2
2014	7	24	6	10	27	35	0	0	0	0	0	0	0	70.23	0	0	11.2
2014	7	24	6	20	27	34	0	0	0	0	0	0	0	70.18	0	0	11.2
2014	7	24	6	30	27	35	0	0	0	0	0	0	0	70.12	0	0	11.2
2014	7	24	6	40	27	35	0	0	0	0	0	0	0	70.11	0	0	11.2
2014	7	24	6	50	27	34	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	24	7	0	27	34	0	0	0	0	0	0	0	70.02	0	0	11.8
2014	7	24	7	10	27	34	0	0	0	0	0	0	0	70	0	0	12
2014	7	24	7	20	27	35	0	0	0	0	0	0	0	69.98	0	0	12.2
2014	7	24	7	30	27	35	0	0	0	0	0	0	0	69.96	0	0	12.4
2014	7	24	7	40	27	35	0	0	0	0	0	0	0	69.96	0	0	12.4
2014	7	24	7	50	27	34	0	0	0	0	0	0	0	69.94	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	8	0	27	35	0	0	0	0	0	0	0	69.96	0	0	12.8
2014	7	24	8	10	27	34	0	0	0	0	0	0	0	69.96	0	0	13
2014	7	24	8	20	27	35	0	0	0	0	0	0	0	69.96	0	0	13.2
2014	7	24	8	30	27	34	0	0	0	0	0	0	0	69.98	0	0	13
2014	7	24	8	40	27	35	0	0	0	0	0	0	0	70	0	0	13
2014	7	24	8	50	27	35	0	0	0	0	0	0	0	70.02	0	0	13
2014	7	24	9	0	27	35	0	0	0	0	0	0	0	70.02	0	0	13
2014	7	24	9	10	27	35	0	0	0	0	0	0	0	70.05	0	0	13
2014	7	24	9	20	27	35	0	0	0	0	0	0	0	70.09	0	0	12.8
2014	7	24	9	30	27	34	0	0	0	0	0	0	0	70.07	0	0	12.8
2014	7	24	9	40	27	35	0	0	0	0	0	0	0	70.14	0	0	12.8
2014	7	24	9	50	27	35	0	0	0	0	0	0	0	70.16	0	0	12.8
2014	7	24	10	0	27	35	0	0	0	0	0	0	0	70.18	0	0	12.8
2014	7	24	10	10	27	34	0	0	0	0	0	0	0	70.14	0	0	12.8
2014	7	24	10	20	27	35	0	0	0	0	0	0	0	70.12	0	0	12.8
2014	7	24	10	30	27	35	0	0	0	0	0	0	0	70.2	0	0	12.8
2014	7	24	10	40	27	34	0	0	0	0	0	0	0	70.29	0	0	12.8
2014	7	24	10	50	27	35	0	0	0	0	0	0	0	70.36	0	0	12.8
2014	7	24	11	0	27	35	0	0	0	0	0	0	0	70.41	0	0	12.8
2014	7	24	11	10	27	35	0	0	0	0	0	0	0	70.45	0	0	12.8
2014	7	24	11	20	27	35	0	0	0	0	0	0	0	70.48	0	0	12.8
2014	7	24	11	30	27	34	0	0	0	0	0	0	0	70.5	0	0	12.8
2014	7	24	11	40	27	35	0	0	0	0	0	0	0	70.52	0	0	12.8
2014	7	24	11	50	27	35	0	0	0	0	0	0	0	70.56	0	0	12.8
2014	7	24	12	0	27	34	0	0	0	0	0	0	0	70.57	0	0	12.8
2014	7	24	12	10	27	35	0	0	0	0	0	0	0	70.54	0	0	12.8
2014	7	24	12	20	27	35	0	0	0	0	0	0	0	70.5	0	0	12.8
2014	7	24	12	30	27	35	0	0	0	0	0	0	0	70.52	0	0	12.8
2014	7	24	12	40	27	34	0	0	0	0	0	0	0	70.56	0	0	12.8
2014	7	24	12	50	27	35	0	0	0	0	0	0	0	70.56	0	0	12.8
2014	7	24	13	0	27	35	0	0	0	0	0	0	0	70.65	0	0	12.8
2014	7	24	13	10	27	34	0	0	0	0	0	0	0	70.79	0	0	12.8
2014	7	24	13	20	27	35	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	24	13	30	27	35	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	24	13	40	27	34	0	0	0	0	0	0	0	70.97	0	0	13
2014	7	24	13	50	27	35	0	0	0	0	0	0	0	71.01	0	0	13
2014	7	24	14	0	27	35	0	0	0	0	0	0	0	71.02	0	0	12.8
2014	7	24	14	10	27	34	0	0	0	0	0	0	0	71.04	0	0	12.8
2014	7	24	14	20	27	35	0	0	0	0	0	0	0	71.08	0	0	12.8
2014	7	24	14	30	27	35	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	24	14	40	27	34	0	0	0	0	0	0	0	71.08	0	0	12.8
2014	7	24	14	50	27	35	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	24	15	0	27	34	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	24	15	10	27	34	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	24	15	20	27	35	0	0	0	0	0	0	0	71.08	0	0	12.8
2014	7	24	15	30	27	34	0	0	0	0	0	0	0	71.1	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	15	40	27	35	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	24	15	50	27	34	0	0	0	0	0	0	0	71.11	0	0	12.4
2014	7	24	16	0	27	34	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	24	16	10	27	34	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	24	16	20	27	34	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	24	16	30	27	34	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	24	16	40	27	34	0	0	0	0	0	0	0	71.11	0	0	12.6
2014	7	24	16	50	27	34	0	0	0	0	0	0	0	71.11	0	0	12.4
2014	7	24	17	0	27	35	0	0	0	0	0	0	0	71.11	0	0	12
2014	7	24	17	10	27	34	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	24	17	20	27	34	0	0	0	0	0	0	0	71.1	0	0	11.8
2014	7	24	17	30	27	34	0	0	0	0	0	0	0	71.1	0	0	11.8
2014	7	24	17	40	27	34	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	24	17	50	27	34	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	24	18	0	27	34	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	24	18	10	27	35	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	24	18	20	27	34	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	24	18	30	27	35	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	24	18	40	27	34	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	24	18	50	27	35	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	24	19	0	27	35	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	24	19	10	27	35	0	0	0	0	0	0	0	71.13	0	0	11.4
2014	7	24	19	20	27	34	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	24	19	30	27	34	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	24	19	40	27	35	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	24	19	50	27	34	0	0	0	0	0	0	0	71.17	0	0	11.4
2014	7	24	20	0	27	34	0	0	0	0	0	0	0	71.17	0	0	11.4
2014	7	24	20	10	27	34	0	0	0	0	0	0	0	71.19	0	0	11.4
2014	7	24	20	20	27	34	0	0	0	0	0	0	0	71.19	0	0	11.4
2014	7	24	20	30	27	34	0	0	0	0	0	0	0	71.2	0	0	11.2
2014	7	24	20	40	27	35	0	0	0	0	0	0	0	71.22	0	0	11.2
2014	7	24	20	50	27	35	0	0	0	0	0	0	0	71.22	0	0	11.4
2014	7	24	21	0	27	34	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	24	21	10	27	34	0	0	0	0	0	0	0	71.24	0	0	11.4
2014	7	24	21	20	27	34	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	24	21	30	27	35	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	24	21	40	27	35	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	24	21	50	27	34	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	24	22	0	27	35	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	24	22	10	27	35	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	24	22	20	27	34	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	24	22	30	27	35	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	24	22	40	27	34	0	0	0	0	0	0	0	71.2	0	0	10.4
2014	7	24	22	50	27	35	0	0	0	0	0	0	0	71.19	0	0	10.4
2014	7	24	23	0	27	35	0	0	0	0	0	0	0	71.19	0	0	10.4
2014	7	24	23	10	27	35	0	0	0	0	0	0	0	71.17	0	0	11.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	23	20	27	34	0	0	0	0	0	0	0	71.17	0	0	10.6
2014	7	24	23	30	27	34	0	0	0	0	0	0	0	71.15	0	0	10.6
2014	7	24	23	40	27	34	0	0	0	0	0	0	0	71.15	0	0	11.2
2014	7	24	23	50	27	35	0	0	0	0	0	0	0	71.13	0	0	11.2
2014	7	25	0	0	27	34	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	25	0	10	27	35	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	25	0	20	27	35	0	0	0	0	0	0	0	71.1	0	0	11.2
2014	7	25	0	30	27	34	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	25	0	40	27	35	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	25	0	50	27	34	0	0	0	0	0	0	0	71.04	0	0	11.4
2014	7	25	1	0	27	34	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	25	1	10	27	34	0	0	0	0	0	0	0	71.01	0	0	11.4
2014	7	25	1	20	27	33	0	0	0	0	0	0	0	70.97	0	0	11.4
2014	7	25	1	30	27	34	0	0	0	0	0	0	0	70.93	0	0	11.4
2014	7	25	1	40	27	35	0	0	0	0	0	0	0	70.9	0	0	11.4
2014	7	25	1	50	27	35	0	0	0	0	0	0	0	70.88	0	0	11.4
2014	7	25	2	0	27	34	0	0	0	0	0	0	0	70.84	0	0	11.4
2014	7	25	2	10	27	34	0	0	0	0	0	0	0	70.81	0	0	11.2
2014	7	25	2	20	27	34	0	0	0	0	0	0	0	70.77	0	0	11.2
2014	7	25	2	30	27	34	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	25	2	40	27	35	0	0	0	0	0	0	0	70.7	0	0	11.2
2014	7	25	2	50	27	34	0	0	0	0	0	0	0	70.66	0	0	11.2
2014	7	25	3	0	27	34	0	0	0	0	0	0	0	70.63	0	0	11.2
2014	7	25	3	10	27	35	0	0	0	0	0	0	0	70.57	0	0	11
2014	7	25	3	20	27	35	0	0	0	0	0	0	0	70.54	0	0	11.2
2014	7	25	3	30	27	35	0	0	0	0	0	0	0	70.52	0	0	11.4
2014	7	25	3	40	27	35	0	0	0	0	0	0	0	70.47	0	0	11.4
2014	7	25	3	50	27	34	0	0	0	0	0	0	0	70.43	0	0	11.4
2014	7	25	4	0	27	34	0	0	0	0	0	0	0	70.39	0	0	11.4
2014	7	25	4	10	27	34	0	0	0	0	0	0	0	70.36	0	0	11.4
2014	7	25	4	20	27	35	0	0	0	0	0	0	0	70.3	0	0	11.4
2014	7	25	4	30	27	35	0	0	0	0	0	0	0	70.29	0	0	11.4
2014	7	25	4	40	27	34	0	0	0	0	0	0	0	70.25	0	0	11.4
2014	7	25	4	50	27	34	0	0	0	0	0	0	0	70.18	0	0	11.4
2014	7	25	5	0	27	34	0	0	0	0	0	0	0	70.16	0	0	11.4
2014	7	25	5	10	27	35	0	0	0	0	0	0	0	70.12	0	0	11.4
2014	7	25	5	20	27	35	0	0	0	0	0	0	0	70.09	0	0	11.4
2014	7	25	5	30	27	35	0	0	0	0	0	0	0	70.03	0	0	11.4
2014	7	25	5	40	27	35	0	0	0	0	0	0	0	70	0	0	11.4
2014	7	25	5	50	27	34	0	0	0	0	0	0	0	69.94	0	0	11.4
2014	7	25	6	0	27	35	0	0	0	0	0	0	0	69.91	0	0	11.4
2014	7	25	6	10	27	35	0	0	0	0	0	0	0	69.87	0	0	11.4
2014	7	25	6	20	27	35	0	0	0	0	0	0	0	69.84	0	0	11.4
2014	7	25	6	30	27	35	0	0	0	0	0	0	0	69.8	0	0	11.4
2014	7	25	6	40	27	35	0	0	0	0	0	0	0	69.76	0	0	11.4
2014	7	25	6	50	27	34	0	0	0	0	0	0	0	69.73	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	7	0	27	35	0	0	0	0	0	0	0	69.71	0	0	12
2014	7	25	7	10	27	35	0	0	0	0	0	0	0	69.67	0	0	12.2
2014	7	25	7	20	27	34	0	0	0	0	0	0	0	69.67	0	0	12.2
2014	7	25	7	30	27	35	0	0	0	0	0	0	0	69.67	0	0	12.6
2014	7	25	7	40	27	34	0	0	0	0	0	0	0	69.67	0	0	12.8
2014	7	25	7	50	27	35	0	0	0	0	0	0	0	69.67	0	0	13
2014	7	25	8	0	27	34	0	0	0	0	0	0	0	69.67	0	0	13
2014	7	25	8	10	27	35	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	25	8	20	27	35	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	25	8	30	27	34	0	0	0	0	0	0	0	69.69	0	0	13.2
2014	7	25	8	40	27	35	0	0	0	0	0	0	0	69.69	0	0	13.4
2014	7	25	8	50	27	34	0	0	0	0	0	0	0	69.73	0	0	13.2
2014	7	25	9	0	27	34	0	0	0	0	0	0	0	69.75	0	0	13
2014	7	25	9	10	27	34	0	0	0	0	0	0	0	69.76	0	0	13.2
2014	7	25	9	20	27	35	0	0	0	0	0	0	0	69.8	0	0	13.2
2014	7	25	9	30	27	34	0	0	0	0	0	0	0	69.82	0	0	13
2014	7	25	9	40	27	34	0	0	0	0	0	0	0	69.85	0	0	13
2014	7	25	9	50	27	34	0	0	0	0	0	0	0	69.89	0	0	13
2014	7	25	10	0	27	35	0	0	0	0	0	0	0	69.85	0	0	13
2014	7	25	10	10	27	35	0	0	0	0	0	0	0	69.85	0	0	13
2014	7	25	10	20	27	35	0	0	0	0	0	0	0	69.91	0	0	12.8
2014	7	25	10	30	27	35	0	0	0	0	0	0	0	70.02	0	0	12.8
2014	7	25	10	41	39	34	0	0	0	0	0	0	0	70.07	0	0	12.8
2014	7	25	10	51	39	35	0	0	0	0	0	0	0	70.11	0	0	13
2014	7	25	11	1	39	35	0	0	0	0	0	0	0	70.14	0	0	12.8
2014	7	25	11	11	39	34	0	0	0	0	0	0	0	70.2	0	0	12.8
2014	7	25	11	21	39	35	0	0	0	0	0	0	0	70.23	0	0	12.8
2014	7	25	11	31	39	34	0	0	0	0	0	0	0	70.25	0	0	12.8
2014	7	25	11	41	39	35	0	0	0	0	0	0	0	70.29	0	0	12.8
2014	7	25	11	51	39	34	0	0	0	0	0	0	0	70.32	0	0	12.8
2014	7	25	12	1	39	35	0	0	0	0	0	0	0	70.34	0	0	12.8
2014	7	25	12	11	39	34	0	0	0	0	0	0	0	70.36	0	0	12.8
2014	7	25	12	21	39	35	0	0	0	0	0	0	0	70.36	0	0	12.8
2014	7	25	12	31	39	34	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	25	12	41	39	34	0	0	0	0	0	0	0	70.48	0	0	12.8
2014	7	25	12	51	39	34	0	0	0	0	0	0	0	70.56	0	0	12.8
2014	7	25	13	1	39	35	0	0	0	0	0	0	0	70.59	0	0	12.6
2014	7	25	13	14	19	34	0	0	0	0	0	0	0	70.66	0	0	12.6
2014	7	25	13	24	19	34	0	0	0	0	0	0	0	70.7	0	0	13.2
2014	7	25	13	34	19	35	0	0	0	0	0	0	0	70.75	0	0	13.2
2014	7	25	13	44	19	34	0	0	0	0	0	0	0	70.77	0	0	13
2014	7	25	13	54	19	34	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	7	25	14	4	19	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2014	7	25	14	14	19	35	0	0	0	0	0	0	0	70.9	0	0	13.2
2014	7	25	14	24	19	34	0	0	0	0	0	0	0	70.93	0	0	13.2
2014	7	25	14	34	19	34	0	0	0	0	0	0	0	70.95	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	14	44	19	34	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	25	14	54	19	35	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	25	15	4	19	35	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	25	15	14	19	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	7	25	15	24	19	34	0	0	0	0	0	0	0	70.86	0	0	13
2014	7	25	15	34	19	35	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	25	15	44	19	35	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	25	15	54	19	34	0	0	0	0	0	0	0	70.9	0	0	12.8
2014	7	25	16	4	19	34	0	0	0	0	0	0	0	70.93	0	0	12.8
2014	7	25	16	14	19	35	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	25	16	24	19	34	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	25	16	34	19	34	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	25	16	44	19	35	0	0	0	0	0	0	0	70.92	0	0	12.4
2014	7	25	16	54	19	35	0	0	0	0	0	0	0	70.92	0	0	12.2
2014	7	25	17	4	19	35	0	0	0	0	0	0	0	70.9	0	0	12.2
2014	7	25	17	14	19	34	0	0	0	0	0	0	0	70.9	0	0	12
2014	7	25	17	24	19	35	0	0	0	0	0	0	0	70.9	0	0	12
2014	7	25	17	34	19	34	0	0	0	0	0	0	0	70.88	0	0	12
2014	7	25	17	44	19	34	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	25	17	54	19	35	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	25	18	4	19	35	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	25	18	14	19	34	0	0	0	0	0	0	0	70.88	0	0	11.8
2014	7	25	18	24	19	34	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	25	18	34	19	35	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	25	18	44	19	34	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	25	18	54	19	35	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	25	19	4	19	34	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	25	19	14	19	34	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	25	19	24	19	34	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	25	19	34	19	34	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	25	19	44	19	35	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	25	19	54	19	34	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	25	20	4	19	34	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	25	20	14	19	35	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	25	20	24	19	34	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	25	20	34	19	34	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	25	20	44	19	35	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	25	20	54	19	35	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	25	21	4	19	34	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	25	21	14	19	35	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	25	21	24	19	35	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	25	21	34	19	35	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	21	44	19	35	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	21	54	19	34	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	22	4	19	35	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	25	22	14	19	35	0	0	0	0	0	0	0	71.06	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	22	24	19	35	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	25	22	34	19	34	0	0	0	0	0	0	0	71.08	0	0	11.4
2014	7	25	22	44	19	34	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	22	54	19	35	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	23	4	19	34	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	23	14	19	34	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	25	23	24	19	34	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	25	23	34	19	35	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	25	23	44	19	34	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	25	23	54	19	34	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	26	0	4	19	35	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	26	0	14	19	35	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	26	0	24	19	35	0	0	0	0	0	0	0	70.97	0	0	11.2
2014	7	26	0	34	19	34	0	0	0	0	0	0	0	70.95	0	0	11.2
2014	7	26	0	44	19	35	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	26	0	54	19	34	0	0	0	0	0	0	0	70.9	0	0	11.2
2014	7	26	1	4	19	35	0	0	0	0	0	0	0	70.88	0	0	11.2
2014	7	26	1	14	19	35	0	0	0	0	0	0	0	70.86	0	0	11.2
2014	7	26	1	24	19	34	0	0	0	0	0	0	0	70.84	0	0	11.2
2014	7	26	1	34	19	35	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	26	1	44	19	34	0	0	0	0	0	0	0	70.77	0	0	11.2
2014	7	26	1	54	19	35	0	0	0	0	0	0	0	70.75	0	0	11.2
2014	7	26	2	4	19	35	0	0	0	0	0	0	0	70.72	0	0	11.2
2014	7	26	2	14	19	34	0	0	0	0	0	0	0	70.68	0	0	11.2
2014	7	26	2	24	19	35	0	0	0	0	0	0	0	70.66	0	0	11.2
2014	7	26	2	34	19	35	0	0	0	0	0	0	0	70.63	0	0	11.2
2014	7	26	2	44	19	35	0	0	0	0	0	0	0	70.59	0	0	11.4
2014	7	26	2	54	19	34	0	0	0	0	0	0	0	70.54	0	0	11.4
2014	7	26	3	4	19	35	0	0	0	0	0	0	0	70.5	0	0	11.4
2014	7	26	3	14	19	34	0	0	0	0	0	0	0	70.47	0	0	11.4
2014	7	26	3	24	19	34	0	0	0	0	0	0	0	70.43	0	0	11.4
2014	7	26	3	34	19	35	0	0	0	0	0	0	0	70.38	0	0	11.4
2014	7	26	3	44	19	34	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	26	3	54	19	34	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	26	4	4	19	34	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	26	4	14	19	34	0	0	0	0	0	0	0	70.21	0	0	11.6
2014	7	26	4	24	19	34	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	26	4	34	19	34	0	0	0	0	0	0	0	70.14	0	0	11.6
2014	7	26	4	44	19	34	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	26	4	54	19	34	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	26	5	4	19	34	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	26	5	14	19	35	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	26	5	24	19	35	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	26	5	34	19	34	0	0	0	0	0	0	0	69.91	0	0	11.6
2014	7	26	5	44	19	35	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	26	5	54	19	35	0	0	0	0	0	0	0	69.84	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	6	4	19	35	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	26	6	14	19	35	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	26	6	24	19	35	0	0	0	0	0	0	0	69.73	0	0	11.6
2014	7	26	6	34	19	35	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	26	6	44	19	34	0	0	0	0	0	0	0	69.66	0	0	11.6
2014	7	26	6	54	19	35	0	0	0	0	0	0	0	69.64	0	0	11.8
2014	7	26	7	4	19	35	0	0	0	0	0	0	0	69.6	0	0	12
2014	7	26	7	14	19	35	0	0	0	0	0	0	0	69.58	0	0	12
2014	7	26	7	24	19	34	0	0	0	0	0	0	0	69.57	0	0	12
2014	7	26	7	34	19	34	0	0	0	0	0	0	0	69.57	0	0	12.2
2014	7	26	7	44	19	35	0	0	0	0	0	0	0	69.57	0	0	12.4
2014	7	26	7	54	19	34	0	0	0	0	0	0	0	69.57	0	0	12.4
2014	7	26	8	4	19	35	0	0	0	0	0	0	0	69.57	0	0	12.6
2014	7	26	8	14	19	35	0	0	0	0	0	0	0	69.6	0	0	12.8
2014	7	26	8	24	19	34	0	0	0	0	0	0	0	69.6	0	0	12.6
2014	7	26	8	34	19	34	0	0	0	0	0	0	0	69.6	0	0	12.8
2014	7	26	8	44	19	34	0	0	0	0	0	0	0	69.55	0	0	12.4
2014	7	26	8	54	19	34	0	0	0	0	0	0	0	69.53	0	0	12.2
2014	7	26	9	4	19	34	0	0	0	0	0	0	0	69.55	0	0	12.6
2014	7	26	9	14	19	35	0	0	0	0	0	0	0	69.58	0	0	13
2014	7	26	9	24	19	34	0	0	0	0	0	0	0	69.53	0	0	12.4
2014	7	26	9	34	19	35	0	0	0	0	0	0	0	69.57	0	0	12.6
2014	7	26	9	44	19	34	0	0	0	0	0	0	0	69.6	0	0	13
2014	7	26	9	54	19	35	0	0	0	0	0	0	0	69.64	0	0	13.2
2014	7	26	10	4	19	35	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	26	10	14	19	34	0	0	0	0	0	0	0	69.73	0	0	13
2014	7	26	10	24	19	35	0	0	0	0	0	0	0	69.8	0	0	13
2014	7	26	10	34	19	35	0	0	0	0	0	0	0	69.87	0	0	13
2014	7	26	10	44	19	35	0	0	0	0	0	0	0	69.8	0	0	12.8
2014	7	26	10	54	19	34	0	0	0	0	0	0	0	69.76	0	0	12.8
2014	7	26	11	4	19	35	0	0	0	0	0	0	0	69.8	0	0	13
2014	7	26	11	14	19	35	0	0	0	0	0	0	0	69.8	0	0	12.8
2014	7	26	11	24	19	35	0	0	0	0	0	0	0	69.87	0	0	13
2014	7	26	11	34	19	34	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	7	26	11	44	19	34	0	0	0	0	0	0	0	70	0	0	13
2014	7	26	11	54	19	35	0	0	0	0	0	0	0	70.05	0	0	13
2014	7	26	12	4	19	35	0	0	0	0	0	0	0	70.07	0	0	13.2
2014	7	26	12	14	19	34	0	0	0	0	0	0	0	70.12	0	0	13.2
2014	7	26	12	24	19	35	0	0	0	0	0	0	0	70.16	0	0	13.2
2014	7	26	12	34	19	35	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	7	26	12	44	19	35	0	0	0	0	0	0	0	70.25	0	0	13.2
2014	7	26	12	54	19	34	0	0	0	0	0	0	0	70.27	0	0	13.2
2014	7	26	13	4	19	34	0	0	0	0	0	0	0	70.3	0	0	13
2014	7	26	13	14	19	35	0	0	0	0	0	0	0	70.32	0	0	13
2014	7	26	13	24	19	35	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	26	13	34	19	35	0	0	0	0	0	0	0	70.41	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	13	44	19	34	0	0	0	0	0	0	0	70.48	0	0	13
2014	7	26	13	54	19	34	0	0	0	0	0	0	0	70.47	0	0	12.8
2014	7	26	14	4	19	34	0	0	0	0	0	0	0	70.5	0	0	13
2014	7	26	14	14	19	34	0	0	0	0	0	0	0	70.48	0	0	13
2014	7	26	14	24	19	34	0	0	0	0	0	0	0	70.54	0	0	13
2014	7	26	14	34	19	35	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	26	14	44	19	34	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	26	14	54	19	35	0	0	0	0	0	0	0	70.57	0	0	13
2014	7	26	15	4	19	35	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	26	15	14	19	35	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	26	15	24	19	34	0	0	0	0	0	0	0	70.56	0	0	12.8
2014	7	26	15	34	19	34	0	0	0	0	0	0	0	70.57	0	0	12.8
2014	7	26	15	44	19	35	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	26	15	54	19	35	0	0	0	0	0	0	0	70.57	0	0	12.8
2014	7	26	16	4	19	35	0	0	0	0	0	0	0	70.57	0	0	12.6
2014	7	26	16	14	19	34	0	0	0	0	0	0	0	70.41	0	0	12
2014	7	26	16	24	19	35	0	0	0	0	0	0	0	70.39	0	0	12
2014	7	26	16	34	19	35	0	0	0	0	0	0	0	70.43	0	0	12.2
2014	7	26	16	44	19	34	0	0	0	0	0	0	0	70.47	0	0	12.2
2014	7	26	16	54	19	35	0	0	0	0	0	0	0	70.45	0	0	12.2
2014	7	26	17	4	19	34	0	0	0	0	0	0	0	70.43	0	0	12.2
2014	7	26	17	14	19	34	0	0	0	0	0	0	0	70.48	0	0	12.2
2014	7	26	17	24	19	35	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	26	17	34	19	35	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	26	17	44	19	35	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	26	17	54	19	34	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	26	18	4	19	34	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	26	18	14	19	35	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	26	18	24	19	35	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	26	18	34	19	34	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	26	18	44	19	35	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	26	18	54	19	34	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	26	19	4	19	35	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	26	19	14	19	34	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	26	19	24	19	35	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	26	19	34	19	34	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	26	19	44	19	35	0	0	0	0	0	0	0	70.48	0	0	12
2014	7	26	19	54	19	35	0	0	0	0	0	0	0	70.5	0	0	12
2014	7	26	20	4	19	34	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	20	14	19	34	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	20	24	19	34	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	20	34	19	35	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	20	44	19	35	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	20	54	19	34	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	21	4	19	34	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	26	21	14	19	35	0	0	0	0	0	0	0	70.54	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	21	24	19	34	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	26	21	34	19	35	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	26	21	44	19	34	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	26	21	54	19	34	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	26	22	4	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	22	14	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	22	24	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	22	34	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	22	44	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	22	54	19	35	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	23	4	19	34	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	26	23	14	19	35	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	26	23	24	19	34	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	26	23	34	19	34	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	26	23	44	19	35	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	26	23	54	19	34	0	0	0	0	0	0	0	70.52	0	0	11.6
2014	7	27	0	4	19	34	0	0	0	0	0	0	0	70.52	0	0	11.6
2014	7	27	0	14	19	35	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	27	0	24	19	35	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	27	0	34	19	34	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	27	0	44	19	34	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	27	0	54	19	34	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	27	1	4	19	35	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	27	1	14	19	35	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	27	1	24	19	34	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	27	1	34	19	35	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	27	1	44	19	35	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	27	1	54	19	34	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	27	2	4	19	34	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	27	2	14	19	35	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	27	2	24	19	35	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	27	2	34	19	34	0	0	0	0	0	0	0	70.23	0	0	11.4
2014	7	27	2	44	19	35	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	27	2	54	19	34	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	27	3	4	19	35	0	0	0	0	0	0	0	70.16	0	0	11.6
2014	7	27	3	14	19	34	0	0	0	0	0	0	0	70.14	0	0	11.6
2014	7	27	3	24	19	34	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	27	3	34	19	34	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	27	3	44	19	34	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	27	3	54	19	34	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	27	4	4	19	34	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	27	4	14	19	35	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	27	4	24	19	34	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	27	4	34	19	35	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	27	4	44	19	35	0	0	0	0	0	0	0	69.89	0	0	11.6
2014	7	27	4	54	19	34	0	0	0	0	0	0	0	69.87	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	5	4	19	35	0	0	0	0	0	0	0	69.84	0	0	11.6
2014	7	27	5	14	19	35	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	27	5	24	19	35	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	27	5	34	19	34	0	0	0	0	0	0	0	69.78	0	0	11.6
2014	7	27	5	44	19	34	0	0	0	0	0	0	0	69.76	0	0	11.4
2014	7	27	5	54	19	34	0	0	0	0	0	0	0	69.73	0	0	11.4
2014	7	27	6	4	19	35	0	0	0	0	0	0	0	69.71	0	0	11.4
2014	7	27	6	14	19	35	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	27	6	24	19	34	0	0	0	0	0	0	0	69.67	0	0	11.6
2014	7	27	6	34	19	35	0	0	0	0	0	0	0	69.67	0	0	11.6
2014	7	27	6	44	19	34	0	0	0	0	0	0	0	69.64	0	0	11.6
2014	7	27	6	54	19	35	0	0	0	0	0	0	0	69.64	0	0	11.6
2014	7	27	7	4	19	35	0	0	0	0	0	0	0	69.62	0	0	11.6
2014	7	27	7	14	19	35	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	27	7	24	19	35	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	27	7	34	19	34	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	27	7	44	19	35	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	27	7	54	19	35	0	0	0	0	0	0	0	69.66	0	0	11.8
2014	7	27	8	4	19	34	0	0	0	0	0	0	0	69.64	0	0	11.8
2014	7	27	8	14	19	35	0	0	0	0	0	0	0	69.66	0	0	11.8
2014	7	27	8	24	19	35	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	27	8	34	19	34	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	27	8	44	19	35	0	0	0	0	0	0	0	69.75	0	0	12.2
2014	7	27	8	54	19	34	0	0	0	0	0	0	0	69.71	0	0	12
2014	7	27	9	4	19	35	0	0	0	0	0	0	0	69.66	0	0	12
2014	7	27	9	14	19	34	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	27	9	24	19	34	0	0	0	0	0	0	0	69.78	0	0	12.2
2014	7	27	9	34	19	34	0	0	0	0	0	0	0	69.84	0	0	12.2
2014	7	27	9	44	19	34	0	0	0	0	0	0	0	69.89	0	0	12.4
2014	7	27	9	54	19	35	0	0	0	0	0	0	0	69.87	0	0	12.8
2014	7	27	10	4	19	35	0	0	0	0	0	0	0	69.84	0	0	12.4
2014	7	27	10	14	19	35	0	0	0	0	0	0	0	70	0	0	12.8
2014	7	27	10	24	19	35	0	0	0	0	0	0	0	70.03	0	0	12.8
2014	7	27	10	34	19	35	0	0	0	0	0	0	0	70.07	0	0	12.6
2014	7	27	10	44	19	34	0	0	0	0	0	0	0	70.12	0	0	12.8
2014	7	27	10	54	19	35	0	0	0	0	0	0	0	70.12	0	0	12.8
2014	7	27	11	4	19	35	0	0	0	0	0	0	0	70.18	0	0	12.8
2014	7	27	11	14	19	35	0	0	0	0	0	0	0	70.21	0	0	12.8
2014	7	27	11	24	19	34	0	0	0	0	0	0	0	70.27	0	0	12.6
2014	7	27	11	34	19	35	0	0	0	0	0	0	0	70.3	0	0	12.6
2014	7	27	11	44	19	34	0	0	0	0	0	0	0	70.36	0	0	12.6
2014	7	27	11	54	19	35	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	27	12	4	19	34	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	27	12	14	19	35	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	27	12	24	19	35	0	0	0	0	0	0	0	70.54	0	0	12.8
2014	7	27	12	34	19	34	0	0	0	0	0	0	0	70.57	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	12	44	19	35	0	0	0	0	0	0	0	70.61	0	0	12.8
2014	7	27	12	54	19	35	0	0	0	0	0	0	0	70.65	0	0	12.8
2014	7	27	13	4	19	35	0	0	0	0	0	0	0	70.7	0	0	12.8
2014	7	27	13	14	19	34	0	0	0	0	0	0	0	70.72	0	0	12.8
2014	7	27	13	24	19	34	0	0	0	0	0	0	0	70.74	0	0	12.8
2014	7	27	13	34	19	33	0	0	0	0	0	0	0	70.83	0	0	12.8
2014	7	27	13	44	19	34	0	0	0	0	0	0	0	70.83	0	0	12.8
2014	7	27	13	54	19	33	0	0	0	0	0	0	0	70.84	0	0	12.8
2014	7	27	14	4	19	34	0	0	0	0	0	0	0	70.84	0	0	12.8
2014	7	27	14	14	19	34	0	0	0	0	0	0	0	70.74	0	0	12.6
2014	7	27	14	24	19	35	0	0	0	0	0	0	0	70.72	0	0	12.4
2014	7	27	14	34	19	35	0	0	0	0	0	0	0	70.74	0	0	12.6
2014	7	27	14	44	19	35	0	0	0	0	0	0	0	70.74	0	0	12.6
2014	7	27	14	54	19	34	0	0	0	0	0	0	0	70.74	0	0	12.6
2014	7	27	15	4	19	34	0	0	0	0	0	0	0	70.74	0	0	12.6
2014	7	27	15	14	19	34	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	27	15	24	19	35	0	0	0	0	0	0	0	70.93	0	0	12.8
2014	7	27	15	34	19	34	0	0	0	0	0	0	0	70.99	0	0	12.8
2014	7	27	15	44	19	34	0	0	0	0	0	0	0	71.01	0	0	12.6
2014	7	27	15	54	19	35	0	0	0	0	0	0	0	71.06	0	0	12.6
2014	7	27	16	4	19	35	0	0	0	0	0	0	0	71.11	0	0	12.6
2014	7	27	16	14	19	34	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	27	16	24	19	35	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	27	16	34	19	35	0	0	0	0	0	0	0	71.11	0	0	12.6
2014	7	27	16	44	19	35	0	0	0	0	0	0	0	71.13	0	0	12.6
2014	7	27	16	54	19	34	0	0	0	0	0	0	0	71.15	0	0	12.6
2014	7	27	17	4	19	35	0	0	0	0	0	0	0	71.13	0	0	12.2
2014	7	27	17	14	19	34	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	7	27	17	24	19	34	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	7	27	17	34	19	35	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	27	17	44	19	35	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	27	17	54	19	35	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	27	18	4	19	34	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	27	18	14	19	34	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	27	18	24	19	34	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	27	18	34	19	34	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	27	18	44	19	34	0	0	0	0	0	0	0	71.2	0	0	11.4
2014	7	27	18	54	19	34	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	27	19	4	19	35	0	0	0	0	0	0	0	71.22	0	0	11.4
2014	7	27	19	14	19	35	0	0	0	0	0	0	0	71.24	0	0	11.4
2014	7	27	19	24	19	34	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	27	19	34	19	34	0	0	0	0	0	0	0	71.26	0	0	11.4
2014	7	27	19	44	19	35	0	0	0	0	0	0	0	71.28	0	0	11.2
2014	7	27	19	54	19	35	0	0	0	0	0	0	0	71.29	0	0	11.4
2014	7	27	20	4	19	34	0	0	0	0	0	0	0	71.33	0	0	11.4
2014	7	27	20	14	19	35	0	0	0	0	0	0	0	71.33	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	20	24	19	35	0	0	0	0	0	0	0	71.35	0	0	11.2
2014	7	27	20	34	19	35	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	27	20	44	19	35	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	27	20	54	19	34	0	0	0	0	0	0	0	71.4	0	0	11.4
2014	7	27	21	4	19	34	0	0	0	0	0	0	0	71.42	0	0	11.4
2014	7	27	21	14	19	34	0	0	0	0	0	0	0	71.42	0	0	11.4
2014	7	27	21	24	19	34	0	0	0	0	0	0	0	71.44	0	0	11.4
2014	7	27	21	34	19	35	0	0	0	0	0	0	0	71.46	0	0	11.4
2014	7	27	21	44	19	35	0	0	0	0	0	0	0	71.46	0	0	11.4
2014	7	27	21	54	19	34	0	0	0	0	0	0	0	71.46	0	0	11.4
2014	7	27	22	4	19	35	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	27	22	14	19	34	0	0	0	0	0	0	0	71.49	0	0	11.4
2014	7	27	22	24	19	35	0	0	0	0	0	0	0	71.51	0	0	11.4
2014	7	27	22	34	19	35	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	27	22	44	19	34	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	27	22	54	19	34	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	27	23	4	19	34	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	27	23	14	19	35	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	27	23	24	19	34	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	27	23	34	19	34	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	27	23	44	19	35	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	27	23	54	19	34	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	28	0	4	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	0	14	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	0	24	19	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	0	34	19	34	0	0	0	0	0	0	0	71.64	0	0	11.6
2014	7	28	0	44	19	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	0	54	19	34	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	1	4	19	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	1	14	19	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	1	24	19	34	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	1	34	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	1	44	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	1	54	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	2	4	19	35	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	2	14	19	35	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	28	2	24	19	34	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	28	2	34	19	35	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	28	2	44	19	34	0	0	0	0	0	0	0	71.58	0	0	11.4
2014	7	28	2	54	19	34	0	0	0	0	0	0	0	71.56	0	0	11.4
2014	7	28	3	4	19	34	0	0	0	0	0	0	0	71.55	0	0	11.4
2014	7	28	3	14	19	34	0	0	0	0	0	0	0	71.55	0	0	11.4
2014	7	28	3	24	19	34	0	0	0	0	0	0	0	71.53	0	0	11.4
2014	7	28	3	34	19	34	0	0	0	0	0	0	0	71.51	0	0	11.4
2014	7	28	3	44	19	34	0	0	0	0	0	0	0	71.49	0	0	11.4
2014	7	28	3	54	19	35	0	0	0	0	0	0	0	71.47	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	4	4	19	34	0	0	0	0	0	0	0	71.46	0	0	11.4
2014	7	28	4	14	19	34	0	0	0	0	0	0	0	71.44	0	0	11.4
2014	7	28	4	24	19	35	0	0	0	0	0	0	0	71.42	0	0	11.4
2014	7	28	4	34	19	34	0	0	0	0	0	0	0	71.4	0	0	11.4
2014	7	28	4	44	19	34	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	28	4	54	19	34	0	0	0	0	0	0	0	71.37	0	0	11.4
2014	7	28	5	4	19	34	0	0	0	0	0	0	0	71.35	0	0	11.4
2014	7	28	5	14	19	33	0	0	0	0	0	0	0	71.35	0	0	11.4
2014	7	28	5	24	19	35	0	0	0	0	0	0	0	71.33	0	0	11.4
2014	7	28	5	34	19	35	0	0	0	0	0	0	0	71.31	0	0	11.4
2014	7	28	5	44	19	34	0	0	0	0	0	0	0	71.28	0	0	11.4
2014	7	28	5	54	19	34	0	0	0	0	0	0	0	71.28	0	0	11.4
2014	7	28	6	4	19	34	0	0	0	0	0	0	0	71.26	0	0	11.4
2014	7	28	6	14	19	34	0	0	0	0	0	0	0	71.24	0	0	11.4
2014	7	28	6	24	19	35	0	0	0	0	0	0	0	71.22	0	0	11.4
2014	7	28	6	34	19	35	0	0	0	0	0	0	0	71.2	0	0	11.4
2014	7	28	6	44	19	35	0	0	0	0	0	0	0	71.19	0	0	11.4
2014	7	28	6	54	19	35	0	0	0	0	0	0	0	71.19	0	0	11.4
2014	7	28	7	4	19	35	0	0	0	0	0	0	0	71.17	0	0	11.4
2014	7	28	7	14	19	35	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	28	7	24	19	34	0	0	0	0	0	0	0	71.17	0	0	11.4
2014	7	28	7	34	19	34	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	28	7	44	19	34	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	28	7	54	19	34	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	28	8	4	19	34	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	28	8	14	19	35	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	28	8	24	19	35	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	28	8	34	19	35	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	28	8	44	19	35	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	28	8	54	19	34	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	28	9	4	19	35	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	28	9	14	19	35	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	28	9	24	19	34	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	28	9	34	19	34	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	7	28	9	44	19	35	0	0	0	0	0	0	0	71.24	0	0	12.4
2014	7	28	9	54	19	34	0	0	0	0	0	0	0	71.28	0	0	12.4
2014	7	28	10	4	19	34	0	0	0	0	0	0	0	71.28	0	0	12.4
2014	7	28	10	14	19	35	0	0	0	0	0	0	0	71.29	0	0	12.6
2014	7	28	10	24	19	34	0	0	0	0	0	0	0	71.37	0	0	13
2014	7	28	10	34	19	35	0	0	0	0	0	0	0	71.4	0	0	13.2
2014	7	28	10	44	19	34	0	0	0	0	0	0	0	71.44	0	0	13
2014	7	28	10	54	19	34	0	0	0	0	0	0	0	71.51	0	0	13.2
2014	7	28	11	4	19	35	0	0	0	0	0	0	0	71.55	0	0	13
2014	7	28	11	14	19	34	0	0	0	0	0	0	0	71.56	0	0	13
2014	7	28	11	24	19	34	0	0	0	0	0	0	0	71.55	0	0	13
2014	7	28	11	34	19	34	0	0	0	0	0	0	0	71.47	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	11	44	19	34	0	0	0	0	0	0	0	71.49	0	0	13
2014	7	28	11	54	19	35	0	0	0	0	0	0	0	71.51	0	0	13
2014	7	28	12	4	19	34	0	0	0	0	0	0	0	71.55	0	0	12.8
2014	7	28	12	14	19	34	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	7	28	12	24	19	35	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	7	28	12	34	19	34	0	0	0	0	0	0	0	71.78	0	0	13.2
2014	7	28	12	44	19	35	0	0	0	0	0	0	0	71.67	0	0	13
2014	7	28	12	54	19	34	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	28	13	4	19	35	0	0	0	0	0	0	0	71.65	0	0	12.8
2014	7	28	13	14	19	35	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	28	13	24	19	34	0	0	0	0	0	0	0	71.71	0	0	13.2
2014	7	28	13	34	19	34	0	0	0	0	0	0	0	71.73	0	0	13
2014	7	28	13	44	19	35	0	0	0	0	0	0	0	71.67	0	0	13
2014	7	28	13	54	19	35	0	0	0	0	0	0	0	71.64	0	0	12.6
2014	7	28	14	4	19	35	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	28	14	14	19	35	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	28	14	24	19	34	0	0	0	0	0	0	0	71.65	0	0	13.2
2014	7	28	14	34	19	35	0	0	0	0	0	0	0	71.64	0	0	12.6
2014	7	28	14	44	19	35	0	0	0	0	0	0	0	71.62	0	0	12.2
2014	7	28	14	54	19	34	0	0	0	0	0	0	0	71.62	0	0	12
2014	7	28	15	4	19	34	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	28	15	14	19	34	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	15	24	19	35	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	15	34	19	35	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	15	44	19	34	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	28	15	54	19	34	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	28	16	4	19	35	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	28	16	14	19	34	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	28	16	24	19	35	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	28	16	34	19	35	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	16	44	19	33	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	16	54	19	35	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	28	17	4	19	35	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	28	17	14	19	34	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	28	17	24	19	34	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	28	17	34	19	35	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	28	17	44	19	34	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	28	17	54	19	35	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	28	18	4	19	34	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	28	18	14	19	33	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	28	18	24	19	35	0	0	0	0	0	0	0	71.64	0	0	11.4
2014	7	28	18	34	19	35	0	0	0	0	0	0	0	71.65	0	0	11.4
2014	7	28	18	44	19	35	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	28	18	54	19	34	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	28	19	4	19	34	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	28	19	14	19	33	0	0	0	0	0	0	0	71.67	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	19	24	19	35	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	28	19	34	19	35	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	28	19	44	19	35	0	0	0	0	0	0	0	71.69	0	0	11.4
2014	7	28	19	54	19	35	0	0	0	0	0	0	0	71.69	0	0	11.4
2014	7	28	20	4	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	20	14	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	20	24	19	35	0	0	0	0	0	0	0	71.69	0	0	11
2014	7	28	20	34	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	20	44	19	35	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	20	54	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	21	4	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	21	14	19	35	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	21	24	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	28	21	34	19	34	0	0	0	0	0	0	0	71.67	0	0	11
2014	7	28	21	44	19	35	0	0	0	0	0	0	0	71.67	0	0	11
2014	7	28	21	54	19	34	0	0	0	0	0	0	0	71.67	0	0	11
2014	7	28	22	4	19	35	0	0	0	0	0	0	0	71.67	0	0	11
2014	7	28	22	14	19	35	0	0	0	0	0	0	0	71.65	0	0	11
2014	7	28	22	24	19	34	0	0	0	0	0	0	0	71.65	0	0	11
2014	7	28	22	34	19	35	0	0	0	0	0	0	0	71.65	0	0	11
2014	7	28	22	44	19	35	0	0	0	0	0	0	0	71.64	0	0	10.8
2014	7	28	22	54	19	34	0	0	0	0	0	0	0	71.64	0	0	11
2014	7	28	23	4	19	34	0	0	0	0	0	0	0	71.62	0	0	11
2014	7	28	23	14	19	34	0	0	0	0	0	0	0	71.6	0	0	11
2014	7	28	23	24	19	35	0	0	0	0	0	0	0	71.6	0	0	11
2014	7	28	23	34	19	34	0	0	0	0	0	0	0	71.58	0	0	11
2014	7	28	23	44	19	35	0	0	0	0	0	0	0	71.56	0	0	11
2014	7	28	23	54	19	34	0	0	0	0	0	0	0	71.56	0	0	11
2014	7	29	0	4	19	35	0	0	0	0	0	0	0	71.55	0	0	11
2014	7	29	0	14	19	34	0	0	0	0	0	0	0	71.55	0	0	11
2014	7	29	0	24	19	35	0	0	0	0	0	0	0	71.53	0	0	11.2
2014	7	29	0	34	19	34	0	0	0	0	0	0	0	71.53	0	0	11.2
2014	7	29	0	44	19	34	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	29	0	54	19	35	0	0	0	0	0	0	0	71.49	0	0	10.8
2014	7	29	1	4	19	35	0	0	0	0	0	0	0	71.47	0	0	11
2014	7	29	1	14	19	34	0	0	0	0	0	0	0	71.46	0	0	11
2014	7	29	1	24	19	34	0	0	0	0	0	0	0	71.46	0	0	10.8
2014	7	29	1	34	19	34	0	0	0	0	0	0	0	71.44	0	0	10.8
2014	7	29	1	44	19	33	0	0	0	0	0	0	0	71.44	0	0	10.8
2014	7	29	1	54	19	35	0	0	0	0	0	0	0	71.42	0	0	10.8
2014	7	29	2	4	19	34	0	0	0	0	0	0	0	71.42	0	0	10.8
2014	7	29	2	14	19	34	0	0	0	0	0	0	0	71.4	0	0	10.8
2014	7	29	2	24	19	34	0	0	0	0	0	0	0	71.4	0	0	10.8
2014	7	29	2	34	19	34	0	0	0	0	0	0	0	71.38	0	0	10.8
2014	7	29	2	44	19	34	0	0	0	0	0	0	0	71.38	0	0	10.8
2014	7	29	2	54	19	34	0	0	0	0	0	0	0	71.37	0	0	10.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	3	4	19	34	0	0	0	0	0	0	0	71.35	0	0	10.8
2014	7	29	3	14	19	34	0	0	0	0	0	0	0	71.33	0	0	10.8
2014	7	29	3	24	19	34	0	0	0	0	0	0	0	71.33	0	0	11
2014	7	29	3	34	19	35	0	0	0	0	0	0	0	71.31	0	0	10.8
2014	7	29	3	44	19	34	0	0	0	0	0	0	0	71.29	0	0	11
2014	7	29	3	54	19	35	0	0	0	0	0	0	0	71.28	0	0	11
2014	7	29	4	4	19	34	0	0	0	0	0	0	0	71.26	0	0	11
2014	7	29	4	14	19	34	0	0	0	0	0	0	0	71.26	0	0	11
2014	7	29	4	24	19	35	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	29	4	34	19	35	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	29	4	44	19	34	0	0	0	0	0	0	0	71.22	0	0	11
2014	7	29	4	54	19	35	0	0	0	0	0	0	0	71.2	0	0	10.8
2014	7	29	5	4	19	35	0	0	0	0	0	0	0	71.19	0	0	10.8
2014	7	29	5	14	19	35	0	0	0	0	0	0	0	71.19	0	0	10.8
2014	7	29	5	24	19	34	0	0	0	0	0	0	0	71.17	0	0	10.8
2014	7	29	5	34	19	34	0	0	0	0	0	0	0	71.15	0	0	10.8
2014	7	29	5	44	19	35	0	0	0	0	0	0	0	71.13	0	0	11.4
2014	7	29	5	54	19	34	0	0	0	0	0	0	0	71.11	0	0	11.4
2014	7	29	6	4	19	35	0	0	0	0	0	0	0	71.11	0	0	11.4
2014	7	29	6	14	19	34	0	0	0	0	0	0	0	71.1	0	0	11.4
2014	7	29	6	24	19	34	0	0	0	0	0	0	0	71.1	0	0	11.4
2014	7	29	6	34	19	35	0	0	0	0	0	0	0	71.08	0	0	11.4
2014	7	29	6	44	19	35	0	0	0	0	0	0	0	71.08	0	0	11.4
2014	7	29	6	54	19	34	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	29	7	4	19	34	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	29	7	14	19	35	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	29	7	24	19	35	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	29	7	34	19	34	0	0	0	0	0	0	0	71.06	0	0	12.2
2014	7	29	7	44	19	34	0	0	0	0	0	0	0	71.06	0	0	12.4
2014	7	29	7	54	19	35	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	29	8	4	19	35	0	0	0	0	0	0	0	71.1	0	0	13.2
2014	7	29	8	14	19	35	0	0	0	0	0	0	0	71.11	0	0	13.4
2014	7	29	8	24	19	34	0	0	0	0	0	0	0	71.15	0	0	13.4
2014	7	29	8	34	19	35	0	0	0	0	0	0	0	71.15	0	0	13.4
2014	7	29	8	44	19	35	0	0	0	0	0	0	0	71.19	0	0	13.4
2014	7	29	8	54	19	34	0	0	0	0	0	0	0	71.19	0	0	13.4
2014	7	29	9	4	19	35	0	0	0	0	0	0	0	71.2	0	0	13.4
2014	7	29	9	14	19	34	0	0	0	0	0	0	0	71.22	0	0	12.8
2014	7	29	9	24	19	35	0	0	0	0	0	0	0	71.26	0	0	12.6
2014	7	29	9	34	19	35	0	0	0	0	0	0	0	71.24	0	0	12.6
2014	7	29	9	44	19	35	0	0	0	0	0	0	0	71.29	0	0	12.6
2014	7	29	9	54	19	34	0	0	0	0	0	0	0	71.31	0	0	12.8
2014	7	29	10	4	19	34	0	0	0	0	0	0	0	71.33	0	0	12.8
2014	7	29	10	14	19	34	0	0	0	0	0	0	0	71.38	0	0	12.8
2014	7	29	10	24	19	35	0	0	0	0	0	0	0	71.4	0	0	13
2014	7	29	10	34	19	35	0	0	0	0	0	0	0	71.44	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	10	44	19	35	0	0	0	0	0	0	0	71.47	0	0	13.4
2014	7	29	10	54	19	35	0	0	0	0	0	0	0	71.51	0	0	13.2
2014	7	29	11	4	19	34	0	0	0	0	0	0	0	71.53	0	0	13.2
2014	7	29	11	14	19	34	0	0	0	0	0	0	0	71.56	0	0	13.4
2014	7	29	11	24	19	34	0	0	0	0	0	0	0	71.6	0	0	13.4
2014	7	29	11	34	19	34	0	0	0	0	0	0	0	71.64	0	0	13.4
2014	7	29	11	44	19	35	0	0	0	0	0	0	0	71.67	0	0	13.4
2014	7	29	11	54	19	34	0	0	0	0	0	0	0	71.73	0	0	13.6
2014	7	29	12	4	19	35	0	0	0	0	0	0	0	71.74	0	0	12.8
2014	7	29	12	14	19	34	0	0	0	0	0	0	0	71.76	0	0	13.2
2014	7	29	12	24	19	34	0	0	0	0	0	0	0	71.83	0	0	13.2
2014	7	29	12	34	19	34	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	29	12	44	19	35	0	0	0	0	0	0	0	71.89	0	0	13
2014	7	29	12	54	19	34	0	0	0	0	0	0	0	71.91	0	0	13
2014	7	29	13	4	19	35	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	29	13	14	19	35	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	29	13	24	19	34	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	7	29	13	34	19	35	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	7	29	13	44	19	34	0	0	0	0	0	0	0	72.05	0	0	13
2014	7	29	13	54	19	34	0	0	0	0	0	0	0	72.16	0	0	13.4
2014	7	29	14	4	19	34	0	0	0	0	0	0	0	72.21	0	0	13.2
2014	7	29	14	14	19	34	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	29	14	24	19	34	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	29	14	34	19	34	0	0	0	0	0	0	0	72.34	0	0	13.2
2014	7	29	14	44	19	34	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	7	29	14	54	19	35	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	7	29	15	4	19	34	0	0	0	0	0	0	0	72.41	0	0	13.2
2014	7	29	15	14	19	34	0	0	0	0	0	0	0	72.41	0	0	13.2
2014	7	29	15	24	19	34	0	0	0	0	0	0	0	72.43	0	0	13
2014	7	29	15	34	19	34	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	29	15	44	19	34	0	0	0	0	0	0	0	72.45	0	0	13
2014	7	29	15	54	19	34	0	0	0	0	0	0	0	72.46	0	0	12.6
2014	7	29	16	4	19	34	0	0	0	0	0	0	0	72.46	0	0	12.6
2014	7	29	16	14	19	34	0	0	0	0	0	0	0	72.48	0	0	12.6
2014	7	29	16	24	19	35	0	0	0	0	0	0	0	72.5	0	0	12.4
2014	7	29	16	34	19	34	0	0	0	0	0	0	0	72.5	0	0	12.4
2014	7	29	16	44	19	35	0	0	0	0	0	0	0	72.52	0	0	12.8
2014	7	29	16	54	19	35	0	0	0	0	0	0	0	72.54	0	0	12.8
2014	7	29	17	4	19	35	0	0	0	0	0	0	0	72.55	0	0	12.6
2014	7	29	17	14	19	35	0	0	0	0	0	0	0	72.57	0	0	12.4
2014	7	29	17	24	19	34	0	0	0	0	0	0	0	72.57	0	0	12.2
2014	7	29	17	34	19	34	0	0	0	0	0	0	0	72.55	0	0	11.6
2014	7	29	17	44	19	34	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	29	17	54	19	34	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	29	18	4	19	35	0	0	0	0	0	0	0	72.61	0	0	11.6
2014	7	29	18	14	19	34	0	0	0	0	0	0	0	72.61	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	18	24	19	34	0	0	0	0	0	0	0	72.63	0	0	11.6
2014	7	29	18	34	19	34	0	0	0	0	0	0	0	72.64	0	0	11.6
2014	7	29	18	44	19	34	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	29	18	54	19	34	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	29	19	4	19	34	0	0	0	0	0	0	0	72.72	0	0	11.4
2014	7	29	19	14	19	34	0	0	0	0	0	0	0	72.73	0	0	11.4
2014	7	29	19	24	19	34	0	0	0	0	0	0	0	72.75	0	0	11.4
2014	7	29	19	34	19	34	0	0	0	0	0	0	0	72.77	0	0	11.4
2014	7	29	19	44	19	34	0	0	0	0	0	0	0	72.79	0	0	11.2
2014	7	29	19	54	19	34	0	0	0	0	0	0	0	72.81	0	0	11
2014	7	29	20	4	19	34	0	0	0	0	0	0	0	72.82	0	0	11
2014	7	29	20	14	19	34	0	0	0	0	0	0	0	72.84	0	0	11
2014	7	29	20	24	19	34	0	0	0	0	0	0	0	72.88	0	0	11
2014	7	29	20	34	19	35	0	0	0	0	0	0	0	72.88	0	0	11
2014	7	29	20	44	19	34	0	0	0	0	0	0	0	72.9	0	0	11
2014	7	29	20	54	19	34	0	0	0	0	0	0	0	72.91	0	0	11
2014	7	29	21	4	19	35	0	0	0	0	0	0	0	72.93	0	0	10.8
2014	7	29	21	14	19	34	0	0	0	0	0	0	0	72.95	0	0	10.8
2014	7	29	21	24	19	34	0	0	0	0	0	0	0	72.95	0	0	11
2014	7	29	21	34	19	34	0	0	0	0	0	0	0	72.97	0	0	11
2014	7	29	21	44	19	35	0	0	0	0	0	0	0	72.99	0	0	11
2014	7	29	21	54	19	33	0	0	0	0	0	0	0	73	0	0	10.8
2014	7	29	22	4	19	34	0	0	0	0	0	0	0	73.02	0	0	10.8
2014	7	29	22	14	19	35	0	0	0	0	0	0	0	73.02	0	0	10.8
2014	7	29	22	24	19	34	0	0	0	0	0	0	0	73.02	0	0	10.8
2014	7	29	22	34	19	35	0	0	0	0	0	0	0	73.04	0	0	11
2014	7	29	22	44	19	34	0	0	0	0	0	0	0	73.04	0	0	11
2014	7	29	22	54	19	34	0	0	0	0	0	0	0	73.06	0	0	11
2014	7	29	23	4	19	34	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	29	23	14	19	34	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	29	23	24	19	34	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	29	23	34	19	34	0	0	0	0	0	0	0	73.06	0	0	11.4
2014	7	29	23	44	19	34	0	0	0	0	0	0	0	73.06	0	0	11.2
2014	7	29	23	54	19	34	0	0	0	0	0	0	0	73.06	0	0	11.4
2014	7	30	0	4	19	34	0	0	0	0	0	0	0	73.06	0	0	11.6
2014	7	30	0	14	19	35	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	30	0	24	19	35	0	0	0	0	0	0	0	73.04	0	0	11.4
2014	7	30	0	34	19	34	0	0	0	0	0	0	0	73.02	0	0	11.4
2014	7	30	0	44	19	34	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	30	0	54	19	34	0	0	0	0	0	0	0	73	0	0	11.2
2014	7	30	1	4	19	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	30	1	14	19	34	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	30	1	24	19	34	0	0	0	0	0	0	0	72.97	0	0	11.2
2014	7	30	1	34	19	34	0	0	0	0	0	0	0	72.95	0	0	11.2
2014	7	30	1	44	19	34	0	0	0	0	0	0	0	72.93	0	0	11.2
2014	7	30	1	54	19	33	0	0	0	0	0	0	0	72.91	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	2	4	19	34	0	0	0	0	0	0	0	72.9	0	0	11.2
2014	7	30	2	14	19	34	0	0	0	0	0	0	0	72.9	0	0	11
2014	7	30	2	24	19	35	0	0	0	0	0	0	0	72.86	0	0	11
2014	7	30	2	34	19	34	0	0	0	0	0	0	0	72.84	0	0	11.2
2014	7	30	2	44	19	34	0	0	0	0	0	0	0	72.81	0	0	11.2
2014	7	30	2	54	19	34	0	0	0	0	0	0	0	72.79	0	0	11.2
2014	7	30	3	4	19	34	0	0	0	0	0	0	0	72.77	0	0	11.2
2014	7	30	3	14	19	35	0	0	0	0	0	0	0	72.73	0	0	11.2
2014	7	30	3	24	19	35	0	0	0	0	0	0	0	72.72	0	0	11.2
2014	7	30	3	34	19	34	0	0	0	0	0	0	0	72.68	0	0	11
2014	7	30	3	44	19	34	0	0	0	0	0	0	0	72.66	0	0	10.8
2014	7	30	3	54	19	35	0	0	0	0	0	0	0	72.64	0	0	11
2014	7	30	4	4	19	34	0	0	0	0	0	0	0	72.61	0	0	11
2014	7	30	4	14	19	34	0	0	0	0	0	0	0	72.59	0	0	11
2014	7	30	4	24	19	35	0	0	0	0	0	0	0	72.57	0	0	11
2014	7	30	4	34	19	35	0	0	0	0	0	0	0	72.54	0	0	11
2014	7	30	4	44	19	35	0	0	0	0	0	0	0	72.52	0	0	11
2014	7	30	4	54	19	34	0	0	0	0	0	0	0	72.5	0	0	10.8
2014	7	30	5	4	19	34	0	0	0	0	0	0	0	72.48	0	0	10.8
2014	7	30	5	14	19	35	0	0	0	0	0	0	0	72.45	0	0	10.8
2014	7	30	5	24	19	34	0	0	0	0	0	0	0	72.43	0	0	11
2014	7	30	5	34	19	34	0	0	0	0	0	0	0	72.41	0	0	11
2014	7	30	5	44	19	34	0	0	0	0	0	0	0	72.39	0	0	11.4
2014	7	30	5	54	19	34	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	30	6	4	19	34	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	30	6	14	19	34	0	0	0	0	0	0	0	72.34	0	0	11.6
2014	7	30	6	24	19	34	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	30	6	34	19	34	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	30	6	44	19	34	0	0	0	0	0	0	0	72.28	0	0	10.8
2014	7	30	6	54	19	34	0	0	0	0	0	0	0	72.28	0	0	10.8
2014	7	30	7	4	19	34	0	0	0	0	0	0	0	72.23	0	0	11
2014	7	30	7	14	19	34	0	0	0	0	0	0	0	72.21	0	0	10.8
2014	7	30	7	24	19	34	0	0	0	0	0	0	0	72.19	0	0	10.8
2014	7	30	7	34	19	34	0	0	0	0	0	0	0	72.18	0	0	10.8
2014	7	30	7	44	19	35	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	30	7	54	19	35	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	30	8	4	19	34	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	30	8	14	19	35	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	30	8	24	19	35	0	0	0	0	0	0	0	72.16	0	0	11.8
2014	7	30	8	34	19	34	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	30	8	44	19	34	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	30	8	54	19	34	0	0	0	0	0	0	0	72.18	0	0	11.2
2014	7	30	9	4	19	34	0	0	0	0	0	0	0	72.16	0	0	11.4
2014	7	30	9	14	19	34	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	30	9	24	19	35	0	0	0	0	0	0	0	72.16	0	0	11.2
2014	7	30	9	34	19	34	0	0	0	0	0	0	0	72.16	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	9	44	19	35	0	0	0	0	0	0	0	72.16	0	0	12.2
2014	7	30	9	54	19	34	0	0	0	0	0	0	0	72.16	0	0	12.4
2014	7	30	10	4	19	35	0	0	0	0	0	0	0	72.19	0	0	12.6
2014	7	30	10	14	19	35	0	0	0	0	0	0	0	72.27	0	0	13.2
2014	7	30	10	24	19	34	0	0	0	0	0	0	0	72.3	0	0	12.8
2014	7	30	10	34	19	34	0	0	0	0	0	0	0	72.25	0	0	12.6
2014	7	30	10	44	19	34	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	30	10	54	19	35	0	0	0	0	0	0	0	72.25	0	0	13
2014	7	30	11	4	19	35	0	0	0	0	0	0	0	72.25	0	0	13.2
2014	7	30	11	14	19	34	0	0	0	0	0	0	0	72.25	0	0	12.8
2014	7	30	11	24	19	34	0	0	0	0	0	0	0	72.21	0	0	12.6
2014	7	30	11	34	19	35	0	0	0	0	0	0	0	72.21	0	0	12.6
2014	7	30	11	44	19	35	0	0	0	0	0	0	0	72.21	0	0	12.2
2014	7	30	11	54	19	34	0	0	0	0	0	0	0	72.19	0	0	12
2014	7	30	12	4	19	34	0	0	0	0	0	0	0	72.18	0	0	12
2014	7	30	12	14	19	34	0	0	0	0	0	0	0	72.14	0	0	11.8
2014	7	30	12	24	19	35	0	0	0	0	0	0	0	72.14	0	0	11.8
2014	7	30	12	34	19	34	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	30	12	44	19	35	0	0	0	0	0	0	0	72.09	0	0	11.8
2014	7	30	12	54	19	34	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	30	13	4	19	35	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	30	13	14	19	34	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	30	13	24	19	34	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	30	13	34	19	34	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	30	13	44	19	34	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	30	13	54	19	34	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	30	14	4	19	35	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	30	14	14	19	34	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	30	14	24	19	34	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	30	14	34	19	35	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	30	14	44	19	34	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	30	14	54	19	35	0	0	0	0	0	0	0	71.91	0	0	11.4
2014	7	30	15	4	19	35	0	0	0	0	0	0	0	71.91	0	0	11.4
2014	7	30	15	14	19	34	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	30	15	24	19	34	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	30	15	34	19	34	0	0	0	0	0	0	0	71.89	0	0	11.6
2014	7	30	15	44	19	34	0	0	0	0	0	0	0	71.89	0	0	11.4
2014	7	30	15	54	19	35	0	0	0	0	0	0	0	71.87	0	0	11.4
2014	7	30	16	4	19	34	0	0	0	0	0	0	0	71.89	0	0	11.4
2014	7	30	16	14	19	34	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	30	16	24	19	34	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	30	16	34	19	34	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	30	16	44	19	35	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	30	16	54	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	17	4	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	17	14	19	33	0	0	0	0	0	0	0	71.83	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	17	24	19	34	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	30	17	34	19	35	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	30	17	44	19	35	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	30	17	54	19	34	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	30	18	4	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	18	14	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	18	24	19	35	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	18	34	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	18	44	19	34	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	18	54	19	34	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	30	19	4	19	35	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	30	19	14	19	34	0	0	0	0	0	0	0	71.8	0	0	11.6
2014	7	30	19	24	19	34	0	0	0	0	0	0	0	71.8	0	0	11.6
2014	7	30	19	34	19	35	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	30	19	44	19	35	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	30	19	54	19	34	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	30	20	4	19	34	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	30	20	14	19	35	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	30	20	24	19	34	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	30	20	34	19	34	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	30	20	44	19	34	0	0	0	0	0	0	0	71.69	0	0	11.2
2014	7	30	20	54	19	34	0	0	0	0	0	0	0	71.67	0	0	11.2
2014	7	30	21	4	19	35	0	0	0	0	0	0	0	71.65	0	0	11.2
2014	7	30	21	14	19	35	0	0	0	0	0	0	0	71.64	0	0	11.2
2014	7	30	21	24	19	34	0	0	0	0	0	0	0	71.62	0	0	11.2
2014	7	30	21	34	19	35	0	0	0	0	0	0	0	71.6	0	0	11.2
2014	7	30	21	44	19	35	0	0	0	0	0	0	0	71.58	0	0	11.2
2014	7	30	21	54	19	34	0	0	0	0	0	0	0	71.56	0	0	11.2
2014	7	30	22	4	19	35	0	0	0	0	0	0	0	71.55	0	0	11.2
2014	7	30	22	14	19	34	0	0	0	0	0	0	0	71.53	0	0	11.2
2014	7	30	22	24	19	34	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	30	22	34	19	34	0	0	0	0	0	0	0	71.49	0	0	11.2
2014	7	30	22	44	19	34	0	0	0	0	0	0	0	71.47	0	0	11.4
2014	7	30	22	54	19	35	0	0	0	0	0	0	0	71.46	0	0	11.4
2014	7	30	23	4	19	34	0	0	0	0	0	0	0	71.42	0	0	11.4
2014	7	30	23	14	19	34	0	0	0	0	0	0	0	71.42	0	0	11.4
2014	7	30	23	24	19	34	0	0	0	0	0	0	0	71.4	0	0	11.4
2014	7	30	23	34	19	35	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	30	23	44	19	35	0	0	0	0	0	0	0	71.37	0	0	10.4
2014	7	30	23	54	19	35	0	0	0	0	0	0	0	71.35	0	0	11.4
2014	7	31	0	4	19	35	0	0	0	0	0	0	0	71.33	0	0	11.4
2014	7	31	0	14	19	34	0	0	0	0	0	0	0	71.31	0	0	11.4
2014	7	31	0	24	19	34	0	0	0	0	0	0	0	71.29	0	0	11.2
2014	7	31	0	34	19	35	0	0	0	0	0	0	0	71.26	0	0	11.4
2014	7	31	0	44	19	34	0	0	0	0	0	0	0	71.24	0	0	11.4
2014	7	31	0	54	19	34	0	0	0	0	0	0	0	71.24	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	1	4	19	34	0	0	0	0	0	0	0	71.22	0	0	11.2
2014	7	31	1	14	19	34	0	0	0	0	0	0	0	71.2	0	0	11.4
2014	7	31	1	24	19	35	0	0	0	0	0	0	0	71.19	0	0	11.2
2014	7	31	1	34	19	35	0	0	0	0	0	0	0	71.17	0	0	11.2
2014	7	31	1	44	19	34	0	0	0	0	0	0	0	71.15	0	0	11.2
2014	7	31	1	54	19	35	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	31	2	4	19	35	0	0	0	0	0	0	0	71.11	0	0	11
2014	7	31	2	14	19	34	0	0	0	0	0	0	0	71.1	0	0	11.2
2014	7	31	2	24	19	35	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	31	2	34	19	34	0	0	0	0	0	0	0	71.06	0	0	11.2
2014	7	31	2	44	19	34	0	0	0	0	0	0	0	71.02	0	0	11.2
2014	7	31	2	54	19	34	0	0	0	0	0	0	0	71.01	0	0	11.2
2014	7	31	3	4	19	35	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	31	3	14	19	34	0	0	0	0	0	0	0	70.97	0	0	11.2
2014	7	31	3	24	19	34	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	31	3	34	19	35	0	0	0	0	0	0	0	70.92	0	0	11.2
2014	7	31	3	44	19	34	0	0	0	0	0	0	0	70.9	0	0	11.4
2014	7	31	3	54	19	34	0	0	0	0	0	0	0	70.86	0	0	11.4
2014	7	31	4	4	19	34	0	0	0	0	0	0	0	70.84	0	0	11.4
2014	7	31	4	14	19	35	0	0	0	0	0	0	0	70.81	0	0	11.2
2014	7	31	4	24	19	34	0	0	0	0	0	0	0	70.79	0	0	11.4
2014	7	31	4	34	19	34	0	0	0	0	0	0	0	70.77	0	0	11.4
2014	7	31	4	44	19	35	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	31	4	54	19	35	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	31	5	4	19	34	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	31	5	14	19	35	0	0	0	0	0	0	0	70.66	0	0	11.4
2014	7	31	5	24	19	34	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	31	5	34	19	34	0	0	0	0	0	0	0	70.59	0	0	11.4
2014	7	31	5	44	19	34	0	0	0	0	0	0	0	70.56	0	0	11.4
2014	7	31	5	54	19	34	0	0	0	0	0	0	0	70.54	0	0	11.4
2014	7	31	6	4	19	34	0	0	0	0	0	0	0	70.5	0	0	11.4
2014	7	31	6	14	19	35	0	0	0	0	0	0	0	70.47	0	0	11.4
2014	7	31	6	24	19	35	0	0	0	0	0	0	0	70.45	0	0	11.4
2014	7	31	6	34	19	34	0	0	0	0	0	0	0	70.43	0	0	11.4
2014	7	31	6	44	19	35	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	31	6	54	19	35	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	31	7	4	19	34	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	31	7	14	19	34	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	31	7	24	19	34	0	0	0	0	0	0	0	70.32	0	0	12
2014	7	31	7	34	19	34	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	31	7	44	19	35	0	0	0	0	0	0	0	70.3	0	0	12.2
2014	7	31	7	54	19	35	0	0	0	0	0	0	0	70.3	0	0	12.2
2014	7	31	8	4	19	34	0	0	0	0	0	0	0	70.3	0	0	12.4
2014	7	31	8	14	19	34	0	0	0	0	0	0	0	70.3	0	0	12.6
2014	7	31	8	24	19	35	0	0	0	0	0	0	0	70.3	0	0	12.8
2014	7	31	8	34	19	35	0	0	0	0	0	0	0	70.3	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	8	44	19	34	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	7	31	8	54	19	35	0	0	0	0	0	0	0	70.3	0	0	13
2014	7	31	9	4	19	34	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	7	31	9	14	19	35	0	0	0	0	0	0	0	70.34	0	0	13.2
2014	7	31	9	24	19	34	0	0	0	0	0	0	0	70.36	0	0	13.2
2014	7	31	9	34	19	35	0	0	0	0	0	0	0	70.38	0	0	13.4
2014	7	31	9	44	19	34	0	0	0	0	0	0	0	70.39	0	0	13.4
2014	7	31	9	54	19	34	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	31	10	4	19	34	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	31	10	14	19	34	0	0	0	0	0	0	0	70.47	0	0	13.4
2014	7	31	10	24	19	35	0	0	0	0	0	0	0	70.5	0	0	13.4
2014	7	31	10	34	19	34	0	0	0	0	0	0	0	70.52	0	0	13.4
2014	7	31	10	44	19	34	0	0	0	0	0	0	0	70.56	0	0	13.4
2014	7	31	10	54	19	35	0	0	0	0	0	0	0	70.57	0	0	13.4
2014	7	31	11	4	19	35	0	0	0	0	0	0	0	70.61	0	0	13.4
2014	7	31	11	14	19	34	0	0	0	0	0	0	0	70.65	0	0	13.4
2014	7	31	11	24	19	35	0	0	0	0	0	0	0	70.68	0	0	13.4
2014	7	31	11	34	19	35	0	0	0	0	0	0	0	70.7	0	0	13.4
2014	7	31	11	44	19	35	0	0	0	0	0	0	0	70.74	0	0	13.4
2014	7	31	11	54	19	34	0	0	0	0	0	0	0	70.77	0	0	13.4
2014	7	31	12	4	19	35	0	0	0	0	0	0	0	70.83	0	0	13.4
2014	7	31	12	14	19	34	0	0	0	0	0	0	0	70.86	0	0	13.4
2014	7	31	12	24	19	35	0	0	0	0	0	0	0	70.88	0	0	13.4
2014	7	31	12	34	19	34	0	0	0	0	0	0	0	70.93	0	0	13.4
2014	7	31	12	44	19	34	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	31	12	54	19	35	0	0	0	0	0	0	0	70.99	0	0	13.2
2014	7	31	13	4	19	35	0	0	0	0	0	0	0	70.99	0	0	13.4
2014	7	31	13	14	19	34	0	0	0	0	0	0	0	70.95	0	0	13.2
2014	7	31	13	24	19	34	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	31	13	34	19	35	0	0	0	0	0	0	0	70.99	0	0	13.4
2014	7	31	13	44	19	34	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	7	31	13	54	19	34	0	0	0	0	0	0	0	71.15	0	0	13.2
2014	7	31	14	4	19	34	0	0	0	0	0	0	0	71.08	0	0	12.8
2014	7	31	14	14	19	34	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	31	14	24	19	35	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	31	14	34	19	34	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	31	14	44	19	34	0	0	0	0	0	0	0	71.06	0	0	12.4
2014	7	31	14	54	19	34	0	0	0	0	0	0	0	71.06	0	0	12.8
2014	7	31	15	4	19	34	0	0	0	0	0	0	0	71.04	0	0	12.8
2014	7	31	15	14	19	34	0	0	0	0	0	0	0	71.02	0	0	12.6
2014	7	31	15	24	19	34	0	0	0	0	0	0	0	71.04	0	0	12.6
2014	7	31	15	34	19	35	0	0	0	0	0	0	0	71.04	0	0	12.4
2014	7	31	15	44	19	35	0	0	0	0	0	0	0	71.04	0	0	12
2014	7	31	15	54	19	34	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	31	16	4	19	35	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	31	16	14	19	35	0	0	0	0	0	0	0	71.06	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	16	24	19	34	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	31	16	34	19	34	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	31	16	44	19	35	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	31	16	54	19	34	0	0	0	0	0	0	0	71.17	0	0	12.2
2014	7	31	17	4	19	35	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	31	17	14	19	34	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	31	17	24	19	34	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	31	17	34	19	35	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	31	17	44	19	35	0	0	0	0	0	0	0	71.22	0	0	11.8
2014	7	31	17	54	19	34	0	0	0	0	0	0	0	71.24	0	0	11.8
2014	7	31	18	4	19	34	0	0	0	0	0	0	0	71.26	0	0	11.8
2014	7	31	18	14	19	34	0	0	0	0	0	0	0	71.28	0	0	11.8
2014	7	31	18	24	19	34	0	0	0	0	0	0	0	71.28	0	0	11.8
2014	7	31	18	34	19	34	0	0	0	0	0	0	0	71.31	0	0	11.8
2014	7	31	18	44	19	35	0	0	0	0	0	0	0	71.33	0	0	11.8
2014	7	31	18	54	19	34	0	0	0	0	0	0	0	71.35	0	0	11.8
2014	7	31	19	4	19	33	0	0	0	0	0	0	0	71.35	0	0	11.8
2014	7	31	19	14	19	34	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	31	19	24	19	34	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	31	19	34	19	34	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	31	19	44	19	34	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	31	19	54	19	34	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	31	20	4	19	33	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	20	14	19	35	0	0	0	0	0	0	0	71.44	0	0	11.4
2014	7	31	20	24	19	35	0	0	0	0	0	0	0	71.44	0	0	11.2
2014	7	31	20	34	19	35	0	0	0	0	0	0	0	71.46	0	0	11.2
2014	7	31	20	44	19	35	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	20	54	19	35	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	21	4	19	34	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	21	14	19	34	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	21	24	19	34	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	31	21	34	19	34	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	31	21	44	19	34	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	31	21	54	19	35	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	31	22	4	19	34	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	31	22	14	19	35	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	31	22	24	19	34	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	31	22	34	19	34	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	31	22	44	19	34	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	31	22	54	19	35	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	31	23	4	19	34	0	0	0	0	0	0	0	71.31	0	0	11.6
2014	7	31	23	14	19	34	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	31	23	24	19	34	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	31	23	34	19	35	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	31	23	44	19	35	0	0	0	0	0	0	0	71.24	0	0	11.4
2014	7	31	23	54	19	35	0	0	0	0	0	0	0	71.24	0	0	11.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	0	8	42	0.3	4.6	0.85	96.2	96.7454	77.5751
2014	7	1	0	18	42	0.3	4.6	0.84	94.5	96.7454	76.6696
2014	7	1	0	28	42	0.3	4.6	0.85	94.9	96.7454	78.1788
2014	7	1	0	38	42	0.3	4.6	0.87	94.1	96.811	79.4419
2014	7	1	0	48	42	0.3	4.6	0.87	95.4	96.811	79.442
2014	7	1	0	58	42	0.3	4.6	0.87	95.2	96.811	79.442
2014	7	1	1	8	42	0.3	4.6	0.84	95.4	96.811	77.3276
2014	7	1	1	18	42	0.3	4.6	0.81	94.7	96.811	74.0049
2014	7	1	1	28	42	0.3	4.6	0.86	96.6	96.811	78.8379
2014	7	1	1	38	42	0.3	4.6	0.85	94.9	96.811	77.9317
2014	7	1	1	48	42	0.3	4.6	0.81	95.8	96.811	74.6091
2014	7	1	1	58	42	0.3	4.6	0.86	96.4	96.811	78.2338
2014	7	1	2	8	42	0.3	4.6	0.87	93.3	96.811	79.7441
2014	7	1	2	18	42	0.3	4.6	0.87	95.6	96.8766	79.4978
2014	7	1	2	28	42	0.3	4.6	0.85	94.9	96.8766	78.2887
2014	7	1	2	38	42	0.3	4.6	0.84	94.3	96.8766	76.7774
2014	7	1	2	48	42	0.3	4.6	0.83	94.3	96.8766	75.8706
2014	7	1	2	58	42	0.3	4.6	0.84	95.6	96.8766	76.7774
2014	7	1	3	8	42	0.3	4.6	0.82	94.4	96.9423	75.3189
2014	7	1	3	18	42	0.3	4.6	0.84	93.1	96.9423	77.7388
2014	7	1	3	28	42	0.3	4.6	0.87	95.8	97.0079	79.9121
2014	7	1	3	38	42	0.3	4.6	0.84	95.2	97.0079	77.1879
2014	7	1	3	48	42	0.3	4.6	0.84	96.3	97.0735	77.2419
2014	7	1	3	58	42	0.3	4.6	0.87	96.5	97.0735	79.6652
2014	7	1	4	8	42	0.3	4.6	0.85	93.3	97.1391	78.2054
2014	7	1	4	18	42	0.3	4.6	0.85	94.4	97.1391	77.9023
2014	7	1	4	28	42	0.3	4.6	0.83	94.8	97.1391	76.3867
2014	7	1	4	38	42	0.3	4.6	0.85	94.4	97.1391	77.9023
2014	7	1	4	48	42	0.3	4.6	0.86	97	97.1391	78.5086
2014	7	1	4	58	42	0.3	4.6	0.85	94	97.1391	77.9023
2014	7	1	5	8	42	0.3	4.6	0.82	95.3	97.1391	75.1743
2014	7	1	5	18	42	0.3	4.6	0.85	94.9	97.1391	77.9024
2014	7	1	5	28	42	0.3	4.6	0.85	96.9	97.2047	77.9569
2014	7	1	5	38	42	0.3	4.6	0.84	95.6	97.2047	77.6536
2014	7	1	5	48	42	0.3	4.6	0.86	94.6	97.2047	79.4736
2014	7	1	5	58	42	0.3	4.6	0.86	97.2	97.2047	78.8669
2014	7	1	6	8	42	0.3	4.6	0.84	96.7	97.2047	77.3503
2014	7	1	6	18	42	0.3	4.6	0.84	94.7	97.2047	77.6536
2014	7	1	6	28	42	0.3	4.6	0.83	97.7	97.2047	76.137
2014	7	1	6	38	42	0.3	4.6	0.81	95.8	97.2047	74.9236
2014	7	1	6	48	42	0.3	4.6	0.86	95.5	97.2047	79.4736
2014	7	1	6	58	42	0.3	4.6	0.84	95.8	97.2047	77.3503
2014	7	1	7	8	42	0.3	4.6	0.83	95.9	97.2703	76.7973
2014	7	1	7	18	42	0.3	4.6	0.84	95.6	97.2703	77.7079
2014	7	1	7	28	42	0.3	4.6	0.84	94.3	97.2703	77.4044
2014	7	1	7	38	42	0.3	4.6	0.86	96.6	97.2703	79.2257

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	7	48	42	0.3	4.6	0.85	94.4	97.2703	78.0115
2014	7	1	7	58	42	0.3	4.6	0.82	95.5	97.2703	75.5831
2014	7	1	8	8	42	0.3	4.6	0.86	93.5	97.2703	79.5292
2014	7	1	8	18	42	0.3	4.6	0.86	95.5	97.2703	79.5292
2014	7	1	8	28	42	0.3	4.6	0.86	97.4	97.2703	79.2256
2014	7	1	8	38	42	0.3	4.6	0.87	96	97.2703	80.4398
2014	7	1	8	48	42	0.3	4.6	0.85	96.9	97.2703	77.7079
2014	7	1	8	58	42	0.3	4.6	0.85	95.5	97.2703	78.6185
2014	7	1	9	8	42	0.3	4.6	0.87	97.2	97.2703	79.8327
2014	7	1	9	18	42	0.3	4.6	0.89	98.3	97.2703	81.0469
2014	7	1	9	28	42	0.3	4.6	0.87	98	97.2703	79.5291
2014	7	1	9	38	42	0.3	4.6	0.9	98.6	97.2703	82.261
2014	7	1	9	48	42	0.3	4.6	0.88	97.3	97.2703	81.0468
2014	7	1	9	58	42	0.3	4.6	0.84	100.1	97.2703	76.7972
2014	7	1	10	8	42	0.3	4.6	0.87	100.8	97.2703	79.2255
2014	7	1	10	18	42	0.3	4.6	0.86	97.2	97.2703	78.922
2014	7	1	10	28	42	0.3	4.6	0.85	98.2	97.2703	77.7078
2014	7	1	10	38	42	0.3	4.6	0.88	97.7	97.2703	80.4397
2014	7	1	10	48	42	0.3	4.6	0.87	99.1	97.2703	79.2255
2014	7	1	10	58	42	0.3	4.6	0.88	97.5	97.2703	80.7432
2014	7	1	11	8	42	0.3	4.6	0.87	99.7	97.2703	79.529
2014	7	1	11	18	42	0.3	4.6	0.87	98.9	97.2703	79.2254
2014	7	1	11	28	42	0.3	4.6	0.85	100.7	97.2703	77.4041
2014	7	1	11	38	42	0.3	4.6	0.85	100.2	97.2703	77.7077
2014	7	1	11	48	42	0.3	4.6	0.87	100.9	97.2703	78.6183
2014	7	1	11	58	42	0.3	4.6	0.85	100	97.2703	77.4041
2014	7	1	12	8	42	0.3	4.6	0.85	98.8	97.2703	78.0112
2014	7	1	12	18	42	0.3	4.6	0.85	101.7	97.2703	77.404
2014	7	1	12	28	42	0.3	4.6	0.85	100.3	97.2703	77.1005
2014	7	1	12	38	42	0.3	4.6	0.86	99.2	97.2703	78.6182
2014	7	1	12	48	42	0.3	4.6	0.86	99.9	97.2047	78.5633
2014	7	1	12	58	42	0.3	4.6	0.88	100.1	97.1391	80.0239
2014	7	1	13	8	42	0.3	4.6	0.88	99.4	97.1391	80.6302
2014	7	1	13	18	42	0.3	4.6	0.8	97.7	97.2047	73.7099
2014	7	1	13	28	42	0.3	4.6	0.86	96.6	97.2047	78.5632
2014	7	1	13	38	42	0.3	4.6	0.86	97	97.2703	78.6181
2014	7	1	13	48	42	0.3	4.6	0.86	97	97.1391	78.5083
2014	7	1	13	58	42	0.3	4.6	0.86	94.4	97.2047	79.1698
2014	7	1	14	8	42	0.3	4.6	0.85	94.7	97.1391	78.2051
2014	7	1	14	18	42	0.3	4.6	0.83	99.8	97.1391	75.7802
2014	7	1	14	28	42	0.3	4.6	0.87	96.9	97.1391	79.7207
2014	7	1	14	38	42	0.3	4.6	0.85	96.9	97.1391	78.2051
2014	7	1	14	48	42	0.3	4.6	0.87	95.2	97.1391	80.327
2014	7	1	14	58	42	0.3	4.6	0.81	98.4	97.2047	73.7098
2014	7	1	15	8	42	0.3	4.6	0.84	96.5	97.2047	76.7432
2014	7	1	15	18	42	0.3	4.6	0.84	95.4	97.2047	77.0465

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	15	28	42	0.3	4.6	0.81	93.7	97.1391	74.8708
2014	7	1	15	38	42	0.3	4.6	0.84	99.5	97.2047	76.4398
2014	7	1	15	48	42	0.3	4.6	0.85	94.2	97.2047	78.5631
2014	7	1	15	58	42	0.3	4.6	0.84	96.8	97.2047	76.7431
2014	7	1	16	8	42	0.3	4.6	0.87	97.2	97.2047	79.7765
2014	7	1	16	18	42	0.3	4.6	0.88	97.5	97.2047	80.3832
2014	7	1	16	28	42	0.3	4.6	0.85	98.5	97.2047	77.3498
2014	7	1	16	38	42	0.3	4.6	0.82	98.7	97.2047	75.2265
2014	7	1	16	48	42	0.3	4.6	0.87	98.7	97.2047	79.1698
2014	7	1	16	58	42	0.3	4.6	0.86	98.6	97.1391	78.2051
2014	7	1	17	8	42	0.3	4.6	0.87	97.4	97.2047	79.7765
2014	7	1	17	18	42	0.3	4.6	0.86	94	97.2047	78.8665
2014	7	1	17	28	42	0.3	4.6	0.86	95.9	97.2047	79.1698
2014	7	1	17	38	42	0.3	4.6	0.85	96	97.2047	78.2598
2014	7	1	17	48	42	0.3	4.6	0.87	98.7	97.2047	79.4731
2014	7	1	17	58	42	0.3	4.6	0.84	95.6	97.2047	77.6531
2014	7	1	18	8	42	0.3	4.6	0.81	94	97.2703	74.6719
2014	7	1	18	18	42	0.3	4.6	0.86	94.8	97.2047	79.1698
2014	7	1	18	28	42	0.3	4.6	0.85	96.2	97.2703	78.0109
2014	7	1	18	38	42	0.3	4.6	0.86	95.7	97.2703	79.5286
2014	7	1	18	48	42	0.3	4.6	0.88	95.8	97.2703	80.7428
2014	7	1	18	58	42	0.3	4.6	0.86	97.4	97.2703	79.2251
2014	7	1	19	8	42	0.3	4.6	0.84	95.8	97.2047	77.3497
2014	7	1	19	18	42	0.3	4.6	0.87	95.2	97.2703	79.8322
2014	7	1	19	28	42	0.3	4.6	0.84	94.2	97.2703	77.7073
2014	7	1	19	38	42	0.3	4.6	0.84	95.8	97.2703	77.4038
2014	7	1	19	48	42	0.3	4.6	0.81	95.6	97.2703	74.6719
2014	7	1	19	58	42	0.3	4.6	0.83	93.6	97.2703	77.1002
2014	7	1	20	8	42	0.3	4.6	0.83	92.7	97.2703	76.7967
2014	7	1	20	18	42	0.3	4.6	0.87	93.3	97.336	80.1916
2014	7	1	20	28	42	0.3	4.6	0.85	95.5	97.336	78.6728
2014	7	1	20	38	42	0.3	4.6	0.88	94.7	97.2703	80.7427
2014	7	1	20	48	42	0.3	4.6	0.85	94.9	97.336	78.6728
2014	7	1	20	58	42	0.3	4.6	0.88	96.7	97.336	80.4954
2014	7	1	21	8	42	0.3	4.6	0.87	94.8	97.336	80.1916
2014	7	1	21	18	42	0.3	4.6	0.81	94	97.336	74.724
2014	7	1	21	28	42	0.3	4.6	0.88	95.8	97.336	81.4066
2014	7	1	21	38	42	0.3	4.6	0.85	94.9	97.336	78.6728
2014	7	1	21	48	42	0.3	4.6	0.84	93.8	97.336	77.7615
2014	7	1	21	58	42	0.3	4.6	0.88	94.7	97.4016	80.8555
2014	7	1	22	8	42	0.3	4.6	0.88	93.6	97.4016	81.7674
2014	7	1	22	18	42	0.3	4.6	0.84	94.7	97.4016	77.2079
2014	7	1	22	28	42	0.3	4.6	0.86	97	97.4016	79.3357
2014	7	1	22	38	42	0.3	4.6	0.84	96.3	97.4016	77.2079
2014	7	1	22	48	42	0.3	4.6	0.88	97	97.4016	81.1595
2014	7	1	22	58	42	0.3	4.6	0.85	95.3	97.4016	78.7277

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	23	8	42	0.3	4.6	0.85	93.5	97.4672	78.7826
2014	7	1	23	18	42	0.3	4.6	0.85	95.3	97.4016	78.7277
2014	7	1	23	28	42	0.3	4.6	0.85	93.8	97.4672	78.4785
2014	7	1	23	38	42	0.3	4.6	0.87	94.8	97.4672	80.3036
2014	7	1	23	48	42	0.3	4.6	0.85	96.2	97.4672	78.7827
2014	7	1	23	58	42	0.3	4.6	0.87	96.5	97.4672	79.9994
2014	7	2	0	8	42	0.3	4.6	0.85	95.5	97.4672	78.4785
2014	7	2	0	18	42	0.3	4.6	0.86	96.8	97.4672	79.0869
2014	7	2	0	28	42	0.3	4.6	0.87	94.3	97.4672	79.9994
2014	7	2	0	38	42	0.3	4.6	0.87	94.3	97.4672	80.6078
2014	7	2	0	48	42	0.3	4.6	0.83	95.2	97.4672	76.6535
2014	7	2	0	58	42	0.3	4.6	0.85	92.7	97.4672	78.7828
2014	7	2	1	8	42	0.3	4.6	0.85	94	97.4672	78.1744
2014	7	2	1	18	42	0.3	4.6	0.87	94.5	97.4672	80.3037
2014	7	2	1	28	42	0.3	4.6	0.87	94.5	97.4672	80.6079
2014	7	2	1	38	42	0.3	4.6	0.86	95.2	97.4672	79.6953
2014	7	2	1	48	42	0.3	4.6	0.84	95.6	97.4672	77.2619
2014	7	2	1	58	42	0.3	4.6	0.85	94.4	97.4672	78.4787
2014	7	2	2	8	42	0.3	4.6	0.85	95.3	97.4672	78.4787
2014	7	2	2	18	42	0.3	4.6	0.85	92.4	97.4672	78.4787
2014	7	2	2	28	42	0.3	4.6	0.85	95.8	97.4672	78.1745
2014	7	2	2	38	42	0.3	4.6	0.86	97.4	97.4672	79.3913
2014	7	2	2	48	42	0.3	4.6	0.84	94.5	97.5328	77.9246
2014	7	2	2	58	42	0.3	4.6	0.87	94.1	97.5328	80.3598
2014	7	2	3	8	42	0.3	4.6	0.86	95.2	97.4672	79.6955
2014	7	2	3	18	42	0.3	4.6	0.86	95.5	97.5328	79.1423
2014	7	2	3	28	42	0.3	4.6	0.84	95.2	97.5328	77.6203
2014	7	2	3	38	42	0.3	4.6	0.85	95.3	97.5328	78.8379
2014	7	2	3	48	42	0.3	4.6	0.83	93.4	97.5328	77.3159
2014	7	2	3	58	42	0.3	4.6	0.86	94.6	97.5328	79.1423
2014	7	2	4	8	42	0.3	4.6	0.83	94.3	97.5328	76.7072
2014	7	2	4	18	42	0.3	4.6	0.86	97	97.5328	79.4468
2014	7	2	4	28	42	0.3	4.6	0.84	93.4	97.5328	77.9248
2014	7	2	4	38	42	0.3	4.6	0.86	95.9	97.5328	79.7512
2014	7	2	4	48	42	0.3	4.6	0.86	94.4	97.5328	79.7512
2014	7	2	4	58	42	0.3	4.6	0.87	94.8	97.5328	80.36
2014	7	2	5	8	42	0.3	4.6	0.85	95.6	97.5328	78.2293
2014	7	2	5	18	42	0.3	4.6	0.87	95.2	97.5984	80.1114
2014	7	2	5	28	42	0.3	4.6	0.85	95.3	97.5984	78.893
2014	7	2	5	38	42	0.3	4.6	0.85	94.2	97.5984	78.893
2014	7	2	5	48	42	0.3	4.6	0.85	94.4	97.5984	78.893
2014	7	2	5	58	42	0.3	4.6	0.88	94.3	97.664	81.3865
2014	7	2	6	8	42	0.3	4.6	0.89	95.5	97.664	82.3009
2014	7	2	6	18	42	0.3	4.6	0.85	94	97.664	78.6431
2014	7	2	6	28	42	0.3	4.6	0.86	93.7	97.7953	79.6683
2014	7	2	6	38	42	0.3	4.6	0.84	93.8	97.7953	77.5316

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	6	48	42	0.3	4.6	0.85	95.5	97.7953	78.7526
2014	7	2	6	58	42	0.3	4.6	0.86	95.1	97.7953	79.3631
2014	7	2	7	8	42	0.3	4.6	0.88	93.6	97.7953	81.4998
2014	7	2	7	18	42	0.3	4.6	0.86	95.9	97.8609	79.7237
2014	7	2	7	28	42	0.3	4.6	0.86	94.2	97.8609	79.4182
2014	7	2	7	38	42	0.3	4.6	0.9	96.1	97.8609	83.0837
2014	7	2	7	48	42	0.3	4.6	0.87	96.9	97.8609	80.64
2014	7	2	7	58	42	0.3	4.6	0.88	94.9	97.8609	81.8618
2014	7	2	8	8	42	0.3	4.6	0.85	94.7	97.8609	78.8073
2014	7	2	8	18	42	0.3	4.6	0.87	96.5	97.8609	80.0291
2014	7	2	8	28	42	0.3	4.6	0.86	95	97.8609	80.0291
2014	7	2	8	38	42	0.3	4.6	0.87	98	97.8609	80.0291
2014	7	2	8	48	42	0.3	4.6	0.85	94.4	97.8609	79.1127
2014	7	2	8	58	42	0.3	4.6	0.88	96.4	97.8609	81.5564
2014	7	2	9	8	42	0.3	4.6	0.87	98.3	97.8609	79.7236
2014	7	2	9	18	42	0.3	4.6	0.87	99.6	97.8609	79.7236
2014	7	2	9	28	42	0.3	4.6	0.89	97.2	97.8609	82.1672
2014	7	2	9	38	42	0.3	4.6	0.9	98.2	97.8609	82.7781
2014	7	2	9	48	42	0.3	4.6	0.88	97.7	97.8609	80.9454
2014	7	2	9	58	42	0.3	4.6	0.88	95.3	97.8609	81.5563
2014	7	2	10	8	42	0.3	4.6	0.88	97.5	97.8609	81.2508
2014	7	2	10	18	42	0.3	4.6	0.9	97.1	97.8609	83.0835
2014	7	2	10	28	42	0.3	4.6	0.87	100.8	97.7953	79.6682
2014	7	2	10	38	42	0.3	4.6	0.85	98.8	97.7953	78.4472
2014	7	2	10	48	42	0.3	4.6	0.88	101	97.7953	80.2786
2014	7	2	10	58	42	0.3	4.6	0.88	99.9	97.7953	80.2786
2014	7	2	11	8	42	0.3	4.6	0.89	97.7	97.7297	81.748
2014	7	2	11	18	42	0.3	4.6	0.89	97.8	97.7297	82.053
2014	7	2	11	28	42	0.3	4.6	0.87	98.7	97.7297	79.9178
2014	7	2	11	38	42	0.3	4.6	0.84	100.3	97.7297	76.8675
2014	7	2	11	48	42	0.3	4.6	0.87	102.8	97.7297	79.0027
2014	7	2	11	58	42	0.3	4.6	0.86	102.8	97.664	77.7285
2014	7	2	12	8	42	0.3	4.6	0.86	99.2	97.664	78.9477
2014	7	2	12	18	42	0.3	4.6	0.87	102.7	97.7297	78.6976
2014	7	2	12	28	42	0.3	4.6	0.86	98.6	97.7297	79.0026
2014	7	2	12	38	42	0.3	4.6	0.85	97.8	97.664	78.3381
2014	7	2	12	48	42	0.3	4.6	0.87	100.9	97.664	79.2525
2014	7	2	12	58	42	0.3	4.6	0.88	99.9	97.664	80.1669
2014	7	2	13	8	42	0.3	4.6	0.85	100.4	97.664	78.0332
2014	7	2	13	18	42	0.3	4.6	0.86	102.5	97.664	78.338
2014	7	2	13	28	42	0.3	4.6	0.82	99.4	97.7297	75.6472
2014	7	2	13	38	42	0.3	4.6	0.84	100.1	97.7297	77.1724
2014	7	2	13	48	42	0.3	4.6	0.87	102.7	97.7297	78.6975
2014	7	2	13	58	42	0.3	4.6	0.85	100.9	97.664	77.4235
2014	7	2	14	8	42	0.3	4.6	0.85	103.4	97.664	76.509
2014	7	2	14	18	42	0.3	4.6	0.83	95.9	97.664	77.1187

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	14	28	42	0.3	4.6	0.84	98.3	97.5984	77.3697
2014	7	2	14	38	42	0.3	4.6	0.85	100.2	97.5984	77.9789
2014	7	2	14	48	42	0.3	4.6	0.85	96.4	97.5984	78.5881
2014	7	2	14	58	42	0.3	4.6	0.89	98.5	97.5984	81.3295
2014	7	2	15	8	42	0.3	4.6	0.84	100.6	97.5984	76.7604
2014	7	2	15	18	42	0.3	4.6	0.84	97.2	97.5984	77.065
2014	7	2	15	28	42	0.3	4.6	0.87	97.6	97.5984	80.1111
2014	7	2	15	38	42	0.3	4.6	0.85	100.2	97.5984	77.9789
2014	7	2	15	48	42	0.3	4.6	0.85	98.9	97.5328	77.9246
2014	7	2	15	58	42	0.3	4.6	0.89	95.3	97.5984	81.9387
2014	7	2	16	8	42	0.3	4.6	0.89	94.4	97.5984	82.2434
2014	7	2	16	18	42	0.3	4.6	0.86	96.1	97.5984	79.8065
2014	7	2	16	28	42	0.3	4.6	0.85	96.7	97.5984	77.9789
2014	7	2	16	38	42	0.3	4.6	0.85	95.8	97.5984	78.5881
2014	7	2	16	48	42	0.3	4.6	0.85	95.6	97.5984	78.2835
2014	7	2	16	58	42	0.3	4.6	0.84	94.3	97.5328	77.3159
2014	7	2	17	8	42	0.3	4.6	0.86	94.4	97.5328	79.751
2014	7	2	17	18	42	0.3	4.6	0.89	97.7	97.5984	81.6342
2014	7	2	17	28	42	0.3	4.6	0.89	95.1	97.5984	82.548
2014	7	2	17	38	42	0.3	4.6	0.85	95.5	97.5984	78.8927
2014	7	2	17	48	42	0.3	4.6	0.84	94	97.5984	77.6743
2014	7	2	17	58	42	0.3	4.6	0.85	96	97.5328	78.8378
2014	7	2	18	8	42	0.3	4.6	0.87	97.2	97.5328	79.751
2014	7	2	18	18	42	0.3	4.6	0.87	96.7	97.5328	80.0554
2014	7	2	18	28	42	0.3	4.6	0.84	95.6	97.5328	77.6202
2014	7	2	18	38	42	0.3	4.6	0.84	96.3	97.5328	77.6202
2014	7	2	18	48	42	0.3	4.6	0.83	96.1	97.5328	77.0114
2014	7	2	18	58	42	0.3	4.6	0.86	95.3	97.5328	79.4466
2014	7	2	19	8	42	0.3	4.6	0.87	95.4	97.5328	80.0553
2014	7	2	19	18	42	0.3	4.6	0.86	95.5	97.5328	79.1422
2014	7	2	19	28	42	0.3	4.6	0.86	95.2	97.5328	79.7509
2014	7	2	19	38	42	0.3	4.6	0.85	95.1	97.5328	78.229
2014	7	2	19	48	42	0.3	4.6	0.87	95.6	97.5328	80.0553
2014	7	2	19	58	42	0.3	4.6	0.83	96.3	97.5328	76.707
2014	7	2	20	8	42	0.3	4.6	0.82	93.7	97.5328	76.0982
2014	7	2	20	18	42	0.3	4.6	0.83	95.6	97.5984	77.065
2014	7	2	20	28	42	0.3	4.6	0.85	95.8	97.5328	78.229
2014	7	2	20	38	42	0.3	4.6	0.85	95.3	97.5984	78.5881
2014	7	2	20	48	42	0.3	4.6	0.87	96.3	97.5984	80.4157
2014	7	2	20	58	42	0.3	4.6	0.84	94.9	97.5984	77.9789
2014	7	2	21	8	42	0.3	4.6	0.85	95.3	97.5984	78.8927
2014	7	2	21	18	42	0.3	4.6	0.88	96.4	97.5984	81.0249
2014	7	2	21	28	42	0.3	4.6	0.86	95.7	97.664	79.2524
2014	7	2	21	38	42	0.3	4.6	0.88	95.2	97.664	81.0813
2014	7	2	21	48	42	0.3	4.6	0.89	96.3	97.664	82.6054
2014	7	2	21	58	42	0.3	4.6	0.87	96.1	97.664	80.1668

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	22	8	42	0.3	4.6	0.85	95.6	97.664	78.3379
2014	7	2	22	18	42	0.3	4.6	0.89	94.9	97.664	82.3006
2014	7	2	22	28	42	0.3	4.6	0.87	96	97.664	80.7765
2014	7	2	22	38	42	0.3	4.6	0.86	93.3	97.7297	80.2226
2014	7	2	22	48	42	0.3	4.6	0.85	97.3	97.7297	78.3924
2014	7	2	22	58	42	0.3	4.6	0.86	96.6	97.7297	79.6126
2014	7	2	23	8	42	0.3	4.6	0.84	93.8	97.7953	78.1417
2014	7	2	23	18	42	0.3	4.6	0.86	93.3	97.7953	80.2784
2014	7	2	23	28	42	0.3	4.6	0.86	94.2	97.7953	79.6679
2014	7	2	23	38	42	0.3	4.6	0.83	93.4	97.8609	77.2796
2014	7	2	23	48	42	0.3	4.6	0.88	95.4	97.8609	81.2505
2014	7	2	23	58	42	0.3	4.6	0.88	94.1	97.8609	81.556
2014	7	3	0	8	42	0.3	4.6	0.88	96.9	97.9265	81.3069
2014	7	3	0	18	42	0.3	4.6	0.86	95.5	97.9265	79.473
2014	7	3	0	28	42	0.3	4.6	0.86	94.4	97.9265	79.473
2014	7	3	0	38	42	0.3	4.6	0.87	95.2	97.9265	81.0013
2014	7	3	0	48	42	0.3	4.6	0.84	94.2	97.9265	78.2503
2014	7	3	0	58	42	0.3	4.6	0.89	94.4	97.9265	82.5297
2014	7	3	1	8	42	0.3	4.6	0.87	94.8	97.9265	80.6957
2014	7	3	1	18	42	0.3	4.6	0.82	93.4	97.9265	76.1107
2014	7	3	1	28	42	0.3	4.6	0.87	96.1	97.9921	80.4458
2014	7	3	1	38	42	0.3	4.6	0.86	94.6	97.9921	80.14
2014	7	3	1	48	42	0.3	4.6	0.87	95.2	98.0577	80.5016
2014	7	3	1	58	42	0.3	4.6	0.87	95.2	98.0577	80.8077
2014	7	3	2	8	42	0.3	4.6	0.86	95.3	98.0577	79.8895
2014	7	3	2	18	42	0.3	4.6	0.84	94.3	98.0577	77.7468
2014	7	3	2	28	42	0.3	4.6	0.86	95.1	98.0577	79.5834
2014	7	3	2	38	42	0.3	4.6	0.87	94.1	98.0577	81.1139
2014	7	3	2	48	42	0.3	4.6	0.85	94.2	98.0577	79.2773
2014	7	3	2	58	42	0.3	4.6	0.84	94.3	98.1234	78.1071
2014	7	3	3	8	42	0.3	4.6	0.82	95.5	98.1234	76.2693
2014	7	3	3	18	42	0.3	4.6	0.82	93.4	98.1234	76.8819
2014	7	3	3	28	42	0.3	4.6	0.88	94.5	98.1234	81.4764
2014	7	3	3	38	42	0.3	4.6	0.87	93.3	98.0577	80.8079
2014	7	3	3	48	42	0.3	4.6	0.86	96.6	98.0577	79.5835
2014	7	3	3	58	42	0.3	4.6	0.86	93.3	98.1234	80.2513
2014	7	3	4	8	42	0.3	4.6	0.85	95.8	98.1234	79.0261
2014	7	3	4	18	42	0.3	4.6	0.86	95.1	98.0577	79.5836
2014	7	3	4	28	42	0.3	4.6	0.87	95.6	98.1234	81.1703
2014	7	3	4	38	42	0.3	4.6	0.88	95.5	98.1234	82.0892
2014	7	3	4	48	42	0.3	4.6	0.85	93.8	98.1234	78.7199
2014	7	3	4	58	42	0.3	4.6	0.86	93.7	98.1234	80.2514
2014	7	3	5	8	42	0.3	4.6	0.85	93.8	98.1234	79.3325
2014	7	3	5	18	42	0.3	4.6	0.84	95.2	98.1234	78.1073
2014	7	3	5	28	42	0.3	4.6	0.86	95.7	98.1234	79.6388
2014	7	3	5	38	42	0.3	4.6	0.85	94.4	98.1234	79.3326

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	5	48	42	0.3	4.6	0.88	94.9	98.1234	82.0893
2014	7	3	5	58	42	0.3	4.6	0.88	95.2	98.189	81.5331
2014	7	3	6	8	42	0.3	4.6	0.88	94.7	98.189	81.8397
2014	7	3	6	18	42	0.3	4.6	0.87	97.6	98.189	80.9201
2014	7	3	6	28	42	0.3	4.6	0.83	94.3	98.189	77.5485
2014	7	3	6	38	42	0.3	4.6	0.86	94.2	98.189	79.6941
2014	7	3	6	48	42	0.3	4.6	0.85	93.3	98.189	79.0811
2014	7	3	6	58	42	0.3	4.6	0.84	93.8	98.189	77.855
2014	7	3	7	8	42	0.3	4.6	0.87	93.4	98.189	81.5332
2014	7	3	7	18	42	0.3	4.6	0.89	95.1	98.189	83.0658
2014	7	3	7	28	42	0.3	4.6	0.87	96.2	98.189	81.2267
2014	7	3	7	38	42	0.3	4.6	0.87	96.5	98.189	80.9202
2014	7	3	7	48	42	0.3	4.6	0.86	96.1	98.189	80.0007
2014	7	3	7	58	42	0.3	4.6	0.86	95.2	98.189	80.3072
2014	7	3	8	8	42	0.3	4.6	0.88	96	98.189	82.1463
2014	7	3	8	18	42	0.3	4.6	0.89	95.3	98.189	82.7593
2014	7	3	8	28	42	0.3	4.6	0.85	96.2	98.189	79.0811
2014	7	3	8	38	42	0.3	4.6	0.89	96.4	98.189	82.4528
2014	7	3	8	48	42	0.3	4.6	0.88	96.2	98.189	81.8397
2014	7	3	8	58	42	0.3	4.6	0.87	96.5	98.189	80.6137
2014	7	3	9	8	42	0.3	4.6	0.91	98.9	98.189	84.2918
2014	7	3	9	18	42	0.3	4.6	0.88	99.5	98.189	80.9202
2014	7	3	9	28	42	0.3	4.6	0.87	97.3	98.189	80.9201
2014	7	3	9	38	42	0.3	4.6	0.86	100.1	98.189	79.081
2014	7	3	9	48	42	0.3	4.6	0.88	101	98.189	80.6136
2014	7	3	9	58	42	0.3	4.6	0.88	97.9	98.189	81.2266
2014	7	3	10	8	42	0.3	4.6	0.87	96.5	98.189	80.307
2014	7	3	10	18	42	0.3	4.6	0.87	98.5	98.189	80.307
2014	7	3	10	28	42	0.3	4.6	0.9	97.2	98.2546	83.1231
2014	7	3	10	38	42	0.3	4.6	0.9	99.7	98.189	82.4526
2014	7	3	10	48	42	0.3	4.6	0.88	100.1	98.189	80.92
2014	7	3	10	58	42	0.3	4.6	0.88	98.2	98.189	80.92
2014	7	3	11	8	42	0.3	4.6	0.86	95.3	98.189	80.0005
2014	7	3	11	18	42	0.3	4.6	0.85	96	98.2546	79.4423
2014	7	3	11	28	42	0.3	4.6	0.89	101.7	98.189	81.2265
2014	7	3	11	38	42	0.3	4.6	0.87	100.9	98.189	79.3874
2014	7	3	11	48	42	0.3	4.6	0.89	99.3	98.189	82.146
2014	7	3	11	58	42	0.3	4.6	0.85	98.4	98.189	78.4678
2014	7	3	12	8	42	0.3	4.6	0.86	99.7	98.189	79.0808
2014	7	3	12	18	42	0.3	4.6	0.88	99.9	98.189	80.6134
2014	7	3	12	28	42	0.3	4.6	0.87	98.5	98.189	80.0003
2014	7	3	12	38	42	0.3	4.6	0.89	100	98.189	81.8394
2014	7	3	12	48	42	0.3	4.6	0.89	101.5	98.189	81.2263
2014	7	3	12	58	42	0.3	4.6	0.87	102.9	98.2546	79.1354
2014	7	3	13	8	42	0.3	4.6	0.84	101	98.189	77.2416
2014	7	3	13	18	42	0.3	4.6	0.9	100.2	98.189	83.0654

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	13	28	42	0.3	4.6	0.85	99.8	98.1234	78.4134
2014	7	3	13	38	42	0.3	4.6	0.87	100.2	98.189	79.6937
2014	7	3	13	48	42	0.3	4.6	0.87	97	98.189	80.3067
2014	7	3	13	58	42	0.3	4.6	0.89	102.3	98.189	81.2262
2014	7	3	14	8	42	0.3	4.6	0.87	98.5	98.1234	79.9448
2014	7	3	14	18	42	0.3	4.6	0.88	99.7	98.1234	80.8637
2014	7	3	14	28	42	0.3	4.6	0.84	96	98.189	78.4676
2014	7	3	14	38	42	0.3	4.6	0.88	96.7	98.1234	81.17
2014	7	3	14	48	42	0.3	4.6	0.85	100.3	98.1234	77.8007
2014	7	3	14	58	42	0.3	4.6	0.88	100.3	98.1234	80.5574
2014	7	3	15	8	42	0.3	4.6	0.85	94.4	98.1234	79.3322
2014	7	3	15	18	42	0.3	4.6	0.86	94.8	98.1234	80.2511
2014	7	3	15	28	42	0.3	4.6	0.88	98.6	98.1234	81.17
2014	7	3	15	38	42	0.3	4.6	0.87	97.8	98.1234	80.5574
2014	7	3	15	48	42	0.3	4.6	0.86	97.6	98.1234	79.9448
2014	7	3	15	58	42	0.3	4.6	0.88	97.9	98.1234	81.7826
2014	7	3	16	8	42	0.3	4.6	0.86	97.9	98.1234	79.6385
2014	7	3	16	18	42	0.3	4.6	0.86	96.6	98.1234	79.6385
2014	7	3	16	28	42	0.3	4.6	0.87	99.1	98.1234	80.2511
2014	7	3	16	38	42	0.3	4.6	0.87	95	98.1234	80.5574
2014	7	3	16	48	42	0.3	4.6	0.88	94.7	98.1234	81.4763
2014	7	3	16	58	42	0.3	4.6	0.87	97.6	98.1234	80.8637
2014	7	3	17	8	42	0.3	4.6	0.89	96.3	98.1234	82.7015
2014	7	3	17	18	42	0.3	4.6	0.85	95.5	98.1234	79.3322
2014	7	3	17	28	42	0.3	4.6	0.88	96.2	98.1234	81.4763
2014	7	3	17	38	42	0.3	4.6	0.89	99.5	98.1234	82.3952
2014	7	3	17	48	42	0.3	4.6	0.89	98.5	98.0577	81.7259
2014	7	3	17	58	42	0.3	4.6	0.87	96.5	98.0577	80.8077
2014	7	3	18	8	42	0.3	4.6	0.87	95.6	98.1234	80.5574
2014	7	3	18	18	42	0.3	4.6	0.89	95.3	98.1234	83.0078
2014	7	3	18	28	42	0.3	4.6	0.86	95.9	98.1234	79.9447
2014	7	3	18	38	42	0.3	4.6	0.86	98.8	98.0577	79.2772
2014	7	3	18	48	42	0.3	4.6	0.9	99.3	98.1234	82.7014
2014	7	3	18	58	42	0.3	4.6	0.83	96.6	98.1234	77.188
2014	7	3	19	8	42	0.3	4.6	0.86	97	98.1234	79.3321
2014	7	3	19	18	42	0.3	4.6	0.85	95.8	98.1234	79.0258
2014	7	3	19	28	42	0.3	4.6	0.86	94.6	98.1234	80.251
2014	7	3	19	38	42	0.3	4.6	0.9	96.5	98.1234	83.314
2014	7	3	19	48	42	0.3	4.6	0.88	93	98.1234	81.7825
2014	7	3	19	58	42	0.3	4.6	0.88	96.4	98.1234	81.7825
2014	7	3	20	8	42	0.3	4.6	0.87	95.4	98.1234	80.8636
2014	7	3	20	18	42	0.3	4.6	0.82	94.8	98.1234	76.5754
2014	7	3	20	28	42	0.3	4.6	0.85	94.9	98.1234	79.3321
2014	7	3	20	38	42	0.3	4.6	0.87	92.6	98.1234	80.8636
2014	7	3	20	48	42	0.3	4.6	0.87	95.6	98.1234	81.1699
2014	7	3	20	58	42	0.3	4.6	0.86	95.2	98.1234	80.251

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	21	8	42	0.3	4.6	0.84	95.6	98.1234	77.8006
2014	7	3	21	18	42	0.3	4.6	0.83	93.6	98.1234	77.188
2014	7	3	21	28	42	0.3	4.6	0.9	96.5	98.1234	83.6203
2014	7	3	21	38	42	0.3	4.6	0.85	95.6	98.189	78.7739
2014	7	3	21	48	42	0.3	4.6	0.86	96.6	98.189	79.387
2014	7	3	21	58	42	0.3	4.6	0.85	92.4	98.189	79.0805
2014	7	3	22	8	42	0.3	4.6	0.87	95.2	98.189	81.226
2014	7	3	22	18	42	0.3	4.6	0.85	96	98.189	79.387
2014	7	3	22	28	42	0.3	4.6	0.86	96.4	98.189	79.387
2014	7	3	22	38	42	0.3	4.6	0.88	94.7	98.189	81.8391
2014	7	3	22	48	42	0.3	4.6	0.88	94.3	98.189	81.5326
2014	7	3	22	58	42	0.3	4.6	0.85	94.4	98.189	79.387
2014	7	3	23	8	42	0.3	4.6	0.87	95.2	98.189	81.2261
2014	7	3	23	18	42	0.3	4.6	0.85	95.5	98.189	79.0805
2014	7	3	23	28	42	0.3	4.6	0.87	97.8	98.189	80.3065
2014	7	3	23	38	42	0.3	4.6	0.86	96.1	98.189	79.6935
2014	7	3	23	48	42	0.3	4.6	0.88	95.6	98.189	81.8391
2014	7	3	23	58	42	0.3	4.6	0.84	95.4	98.189	77.8544
2014	7	4	0	8	42	0.3	4.6	0.86	94.1	98.189	80.3065
2014	7	4	0	18	42	0.3	4.6	0.86	95.1	98.189	79.6935
2014	7	4	0	28	42	0.3	4.6	0.84	94.5	98.189	78.4675
2014	7	4	0	38	42	0.3	4.6	0.83	94.5	98.189	77.548
2014	7	4	0	48	42	0.3	4.6	0.86	94.4	98.189	80.3066
2014	7	4	0	58	42	0.3	4.6	0.85	94.4	98.2546	79.1353
2014	7	4	1	8	42	0.3	4.6	0.85	96.2	98.189	78.7741
2014	7	4	1	18	42	0.3	4.6	0.85	95.5	98.189	79.3871
2014	7	4	1	28	42	0.3	4.6	0.85	95.5	98.189	79.0806
2014	7	4	1	38	42	0.3	4.6	0.84	95	98.2546	77.9084
2014	7	4	1	48	42	0.3	4.6	0.87	94.6	98.189	80.6132
2014	7	4	1	58	42	0.3	4.6	0.85	94.4	98.189	78.7741
2014	7	4	2	8	42	0.3	4.6	0.88	92.8	98.189	81.8393
2014	7	4	2	18	42	0.3	4.6	0.85	94.4	98.2546	78.8286
2014	7	4	2	28	42	0.3	4.6	0.85	95.3	98.2546	78.8287
2014	7	4	2	38	42	0.3	4.6	0.86	94.6	98.2546	80.3623
2014	7	4	2	48	42	0.3	4.6	0.84	92.5	98.2546	78.522
2014	7	4	2	58	42	0.3	4.6	0.82	94.4	98.2546	76.3749
2014	7	4	3	8	42	0.3	4.6	0.83	95	98.2546	77.2951
2014	7	4	3	18	42	0.3	4.6	0.85	95.8	98.2546	79.1355
2014	7	4	3	28	42	0.3	4.6	0.85	96.7	98.2546	78.8288
2014	7	4	3	38	42	0.3	4.6	0.86	93.9	98.2546	80.6691
2014	7	4	3	48	42	0.3	4.6	0.85	93.3	98.2546	79.4423
2014	7	4	3	58	42	0.3	4.6	0.86	94.2	98.3202	80.1111
2014	7	4	4	8	42	0.3	4.6	0.85	94.2	98.3202	79.4972
2014	7	4	4	18	42	0.3	4.6	0.86	93.7	98.3202	80.1111
2014	7	4	4	28	42	0.3	4.6	0.86	95.1	98.3202	79.8042
2014	7	4	4	38	42	0.3	4.6	0.86	93.9	98.3858	80.7808

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	4	48	42	0.3	4.6	0.85	94.2	98.3858	79.245
2014	7	4	4	58	42	0.3	4.6	0.86	97.2	98.4515	79.9145
2014	7	4	5	8	42	0.3	4.6	0.82	93.4	98.4515	76.8409
2014	7	4	5	18	42	0.3	4.6	0.87	95	98.5171	80.8924
2014	7	4	5	28	42	0.3	4.6	0.86	95.9	98.5171	80.5848
2014	7	4	5	38	42	0.3	4.6	0.87	95.2	98.5171	81.2
2014	7	4	5	48	42	0.3	4.6	0.83	93.4	98.5171	77.5091
2014	7	4	5	58	42	0.3	4.6	0.85	96	98.5827	79.717
2014	7	4	6	8	42	0.3	4.6	0.87	97.6	98.5827	80.6404
2014	7	4	6	18	42	0.3	4.6	0.84	96.2	98.5827	78.7937
2014	7	4	6	28	42	0.3	4.6	0.9	96.5	98.5827	84.0261
2014	7	4	6	38	42	0.3	4.6	0.88	94.3	98.5827	82.1794
2014	7	4	6	48	42	0.3	4.6	0.87	93.5	98.5827	81.5639
2014	7	4	6	58	42	0.3	4.6	0.83	95.9	98.5827	77.8704
2014	7	4	7	8	42	0.3	4.6	0.86	94.4	98.5827	80.0249
2014	7	4	7	18	42	0.3	4.6	0.85	92.7	98.5827	79.7171
2014	7	4	7	28	42	0.3	4.6	0.84	98.1	98.5827	78.1782
2014	7	4	7	38	42	0.3	4.6	0.85	96.2	98.5827	79.7171
2014	7	4	7	48	42	0.3	4.6	0.84	93.6	98.5827	78.7938
2014	7	4	7	58	42	0.3	4.6	0.86	95.3	98.5827	80.3327
2014	7	4	8	8	42	0.3	4.6	0.85	95.5	98.5827	79.7171
2014	7	4	8	18	42	0.3	4.6	0.87	98	98.5827	81.2561
2014	7	4	8	28	42	0.3	4.6	0.87	95.8	98.5827	81.2561
2014	7	4	8	38	42	0.3	4.6	0.87	95.8	98.5827	81.2561
2014	7	4	8	48	42	0.3	4.6	0.84	96.7	98.5827	78.1782
2014	7	4	8	58	42	0.3	4.6	0.87	97.3	98.5171	81.2001
2014	7	4	9	8	42	0.3	4.6	0.89	96.4	98.5171	82.7379
2014	7	4	9	18	42	0.3	4.6	0.89	98.3	98.5171	82.1228
2014	7	4	9	28	42	0.3	4.6	0.87	99.7	98.5171	80.5849
2014	7	4	9	38	42	0.3	4.6	0.87	99.1	98.4515	80.5293
2014	7	4	9	48	42	0.3	4.6	0.87	97.3	98.4515	81.144
2014	7	4	9	58	42	0.3	4.6	0.89	98.9	98.4515	82.6808
2014	7	4	10	8	42	0.3	4.6	0.89	97.4	98.4515	82.6808
2014	7	4	10	18	42	0.3	4.6	0.89	95.1	98.4515	82.9882
2014	7	4	10	28	42	0.3	4.6	0.89	96.5	98.4515	82.9882
2014	7	4	10	38	42	0.3	4.6	0.9	99.9	98.4515	82.6808
2014	7	4	10	48	42	0.3	4.6	0.87	97.6	98.4515	81.144
2014	7	4	10	58	42	0.3	4.6	0.87	99.6	98.3858	80.1665
2014	7	4	11	8	42	0.3	4.6	0.89	99.3	98.3858	82.6237
2014	7	4	11	18	42	0.3	4.6	0.88	101.2	98.3202	80.4181
2014	7	4	11	28	42	0.3	4.6	0.87	100.6	98.3202	80.4181
2014	7	4	11	38	42	0.3	4.6	0.89	98.9	98.3858	82.0094
2014	7	4	11	48	42	0.3	4.6	0.87	100.2	98.3202	79.8042
2014	7	4	11	58	42	0.3	4.6	0.88	97.7	98.3202	81.6458
2014	7	4	12	8	42	0.3	4.6	0.86	95.3	98.3202	80.1111
2014	7	4	12	18	42	0.3	4.6	0.89	98.9	98.3202	82.5666

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	12	28	42	0.3	4.6	0.9	98.2	98.3858	83.2379
2014	7	4	12	38	42	0.3	4.6	0.89	99.4	98.3202	81.9526
2014	7	4	12	48	42	0.3	4.6	0.9	98.8	98.3202	83.4873
2014	7	4	12	58	42	0.3	4.6	0.88	99.9	98.189	80.6133
2014	7	4	13	8	42	0.3	4.6	0.89	101.1	98.2546	81.2825
2014	7	4	13	18	42	0.3	4.6	0.88	96.4	98.189	82.1458
2014	7	4	13	28	42	0.3	4.6	0.89	98.7	98.3202	82.2595
2014	7	4	13	38	42	0.3	4.6	0.83	99.3	98.189	76.9351
2014	7	4	13	48	42	0.3	4.6	0.89	95.5	98.1234	82.7016
2014	7	4	13	58	42	0.3	4.6	0.88	97.5	98.2546	81.2824
2014	7	4	14	8	42	0.3	4.6	0.89	95.3	98.1234	82.3953
2014	7	4	14	18	42	0.3	4.6	0.89	98.2	98.2546	82.5093
2014	7	4	14	28	42	0.3	4.6	0.86	100.5	98.189	79.0806
2014	7	4	14	38	42	0.3	4.6	0.88	96.7	98.189	81.2262
2014	7	4	14	48	42	0.3	4.6	0.87	101.8	98.189	79.3871
2014	7	4	14	58	42	0.3	4.6	0.88	98.8	98.189	81.5327
2014	7	4	15	8	42	0.3	4.6	0.85	102.1	98.189	77.2415
2014	7	4	15	18	42	0.3	4.6	0.85	96	98.2546	78.8286
2014	7	4	15	28	42	0.3	4.6	0.87	96.5	98.189	80.9197
2014	7	4	15	38	42	0.3	4.6	0.91	95	98.1234	84.8457
2014	7	4	15	48	42	0.3	4.6	0.87	97	98.0577	80.1956
2014	7	4	15	58	42	0.3	4.6	0.9	100	98.1234	83.0078
2014	7	4	16	8	42	0.3	4.6	0.92	95.3	97.9921	85.6458
2014	7	4	16	18	42	0.3	4.6	0.88	99.4	98.1234	81.17
2014	7	4	16	28	42	0.3	4.6	0.85	98.8	98.0577	78.6651
2014	7	4	16	38	42	0.3	4.6	0.86	99.7	98.1234	79.0259
2014	7	4	16	48	42	0.3	4.6	0.91	96.7	98.0577	83.8686
2014	7	4	16	58	42	0.3	4.6	0.91	99	98.0577	83.5625
2014	7	4	17	8	42	0.3	4.6	0.89	98.2	98.1234	82.3952
2014	7	4	17	18	42	0.3	4.6	0.9	96	97.9921	83.8105
2014	7	4	17	28	42	0.3	4.6	0.87	97	98.0577	80.1955
2014	7	4	17	38	42	0.3	4.6	0.9	95	97.9921	83.8105
2014	7	4	17	48	42	0.3	4.6	0.86	97.7	98.1234	79.3322
2014	7	4	17	58	42	0.3	4.6	0.86	98.1	98.0577	79.8895
2014	7	4	18	8	42	0.3	4.6	0.89	98	98.0577	82.6443
2014	7	4	18	18	42	0.3	4.6	0.85	94.9	98.0577	79.2773
2014	7	4	18	28	42	0.3	4.6	0.89	97.2	97.9921	82.587
2014	7	4	18	38	42	0.3	4.6	0.88	97.7	98.0577	81.1138
2014	7	4	18	48	42	0.3	4.6	0.88	96.7	98.1234	81.17
2014	7	4	18	58	42	0.3	4.6	0.87	98.6	98.1234	80.5574
2014	7	4	19	8	42	0.3	4.6	0.9	98.8	98.0577	83.2564
2014	7	4	19	18	42	0.3	4.6	0.88	94.1	97.9921	81.9752
2014	7	4	19	28	42	0.3	4.6	0.89	95.7	98.0577	82.3381
2014	7	4	19	38	42	0.3	4.6	0.86	99.6	98.1234	79.3322
2014	7	4	19	48	42	0.3	4.6	0.87	97.3	98.1234	80.8636
2014	7	4	19	58	42	0.3	4.6	0.88	98.3	98.0577	81.4198

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	20	8	42	0.3	4.6	0.88	97.7	98.1234	81.1699
2014	7	4	20	18	42	0.3	4.6	0.87	95.4	98.0577	80.8077
2014	7	4	20	28	42	0.3	4.6	0.88	94.7	98.1234	81.4762
2014	7	4	20	38	42	0.3	4.6	0.88	96.4	98.1234	81.7825
2014	7	4	20	48	42	0.3	4.6	0.88	96.4	98.1234	81.4762
2014	7	4	20	58	42	0.3	4.6	0.86	95	98.1234	80.251
2014	7	4	21	8	42	0.3	4.6	0.86	94	98.1234	79.6384
2014	7	4	21	18	42	0.3	4.6	0.88	95.5	98.1234	82.0888
2014	7	4	21	28	42	0.3	4.6	0.86	95.5	98.1234	79.6384
2014	7	4	21	38	42	0.3	4.6	0.87	95.6	98.1234	81.1699
2014	7	4	21	48	42	0.3	4.6	0.87	94.5	98.189	81.2261
2014	7	4	21	58	42	0.3	4.6	0.86	95.9	98.1234	80.251
2014	7	4	22	8	42	0.3	4.6	0.88	95.8	98.189	81.5326
2014	7	4	22	18	42	0.3	4.6	0.85	93.5	98.1234	79.6384
2014	7	4	22	28	42	0.3	4.6	0.85	95.1	98.189	79.0805
2014	7	4	22	38	42	0.3	4.6	0.86	95.9	98.189	80.3065
2014	7	4	22	48	42	0.3	4.6	0.85	95.1	98.189	79.0805
2014	7	4	22	58	42	0.3	4.6	0.87	95.4	98.189	80.9195
2014	7	4	23	8	42	0.3	4.6	0.87	96	98.189	81.2261
2014	7	4	23	18	42	0.3	4.6	0.86	94	98.189	79.6935
2014	7	4	23	28	42	0.3	4.6	0.89	95.7	98.189	82.4521
2014	7	4	23	38	42	0.3	4.6	0.87	95	98.189	81.2261
2014	7	4	23	48	42	0.3	4.6	0.88	94.9	98.189	82.1456
2014	7	4	23	58	42	0.3	4.6	0.85	95.5	98.189	79.387
2014	7	5	0	8	42	0.3	4.6	0.91	94.5	98.189	84.9043
2014	7	5	0	18	42	0.3	4.6	0.86	95.5	98.189	80
2014	7	5	0	28	42	0.3	4.6	0.84	95.6	98.189	78.4675
2014	7	5	0	38	42	0.3	4.6	0.84	93.6	98.189	78.774
2014	7	5	0	48	42	0.3	4.6	0.87	94.3	98.189	80.9196
2014	7	5	0	58	42	0.3	4.6	0.85	95.8	98.189	78.774
2014	7	5	1	8	42	0.3	4.6	0.88	93.6	98.189	81.8392
2014	7	5	1	18	42	0.3	4.6	0.86	94.8	98.189	80.0001
2014	7	5	1	28	42	0.3	4.6	0.86	94.4	98.189	80.3066
2014	7	5	1	38	42	0.3	4.6	0.82	95.3	98.189	76.6284
2014	7	5	1	48	42	0.3	4.6	0.85	94	98.189	79.0806
2014	7	5	1	58	42	0.3	4.6	0.83	96.1	98.189	77.2415
2014	7	5	2	8	42	0.3	4.6	0.86	94.8	98.189	80.0001
2014	7	5	2	18	42	0.3	4.6	0.86	94.4	98.189	80.0002
2014	7	5	2	28	42	0.3	4.6	0.82	94.6	98.189	76.322
2014	7	5	2	38	42	0.3	4.6	0.86	94.8	98.189	80.0002
2014	7	5	2	48	42	0.3	4.6	0.85	94.4	98.2546	78.8286
2014	7	5	2	58	42	0.3	4.6	0.86	94.6	98.189	80.3067
2014	7	5	3	8	42	0.3	4.6	0.88	95.5	98.189	82.1458
2014	7	5	3	18	42	0.3	4.6	0.83	94.1	98.2546	77.6018
2014	7	5	3	28	42	0.3	4.6	0.86	96.1	98.2546	80.0556
2014	7	5	3	38	42	0.3	4.6	0.83	93.9	98.2546	77.2951

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	3	48	42	0.3	4.6	0.86	96.6	98.2546	79.7489
2014	7	5	3	58	42	0.3	4.6	0.85	95.3	98.2546	79.4422
2014	7	5	4	8	42	0.3	4.6	0.88	95.8	98.2546	81.5893
2014	7	5	4	18	42	0.3	4.6	0.85	94.2	98.2546	78.8287
2014	7	5	4	28	42	0.3	4.6	0.88	96	98.2546	82.2027
2014	7	5	4	38	42	0.3	4.6	0.84	95.6	98.2546	78.2153
2014	7	5	4	48	42	0.3	4.6	0.86	94.8	98.2546	80.3624
2014	7	5	4	58	42	0.3	4.6	0.87	95	98.2546	81.2826
2014	7	5	5	8	42	0.3	4.6	0.86	95.9	98.2546	80.3624
2014	7	5	5	18	42	0.3	4.6	0.86	96.6	98.2546	79.4423
2014	7	5	5	28	42	0.3	4.6	0.86	93.9	98.2546	80.0557
2014	7	5	5	38	42	0.3	4.6	0.88	95.3	98.2546	81.8961
2014	7	5	5	48	42	0.3	4.6	0.85	94.7	98.2546	79.1356
2014	7	5	5	58	42	0.3	4.6	0.86	96.6	98.2546	80.0558
2014	7	5	6	8	42	0.3	4.6	0.86	96.1	98.2546	79.7491
2014	7	5	6	18	42	0.3	4.6	0.86	96.1	98.2546	80.0558
2014	7	5	6	28	42	0.3	4.6	0.87	94.8	98.2546	80.976
2014	7	5	6	38	42	0.3	4.6	0.86	95.5	98.3202	79.8042
2014	7	5	6	48	42	0.3	4.6	0.85	95.3	98.3202	79.4973
2014	7	5	6	58	42	0.3	4.6	0.84	93.3	98.3202	78.8834
2014	7	5	7	8	42	0.3	4.6	0.86	94.6	98.3202	80.1112
2014	7	5	7	18	42	0.3	4.6	0.84	95	98.3202	77.9626
2014	7	5	7	28	42	0.3	4.6	0.85	96	98.3202	79.4973
2014	7	5	7	38	42	0.3	4.6	0.87	95.2	98.3202	81.3389
2014	7	5	7	48	42	0.3	4.6	0.83	94.7	98.3202	77.6557
2014	7	5	7	58	42	0.3	4.6	0.85	95.5	98.3202	79.1904
2014	7	5	8	8	42	0.3	4.6	0.86	95.5	98.3202	79.8042
2014	7	5	8	18	42	0.3	4.6	0.9	95.4	98.2546	83.7366
2014	7	5	8	28	42	0.3	4.6	0.87	93.9	98.2546	81.5895
2014	7	5	8	38	42	0.3	4.6	0.84	95.6	98.3202	78.2695
2014	7	5	8	48	42	0.3	4.6	0.85	95.1	98.2546	79.1356
2014	7	5	8	58	42	0.3	4.6	0.87	97.4	98.2546	80.6693
2014	7	5	9	8	42	0.3	4.6	0.89	99.4	98.2546	81.8962
2014	7	5	9	18	42	0.3	4.6	0.9	97.5	98.2546	83.7365
2014	7	5	9	28	42	0.3	4.6	0.9	99.6	98.2546	83.123
2014	7	5	9	38	42	0.3	4.6	0.85	98.7	98.2546	78.5221
2014	7	5	9	48	42	0.3	4.6	0.88	98.3	98.2546	81.5894
2014	7	5	9	58	42	0.3	4.6	0.89	99.5	98.2546	82.5095
2014	7	5	10	8	42	0.3	4.6	0.89	97.6	98.2546	82.8163
2014	7	5	10	18	42	0.3	4.6	0.88	98.4	98.2546	81.2826
2014	7	5	10	28	42	0.3	4.6	0.89	98	98.2546	82.8162
2014	7	5	10	38	42	0.3	4.6	0.88	96.2	98.2546	81.5893
2014	7	5	10	48	42	0.3	4.6	0.88	98.4	98.2546	80.9758
2014	7	5	10	58	42	0.3	4.6	0.88	98.1	98.3858	81.7021
2014	7	5	11	8	42	0.3	4.6	0.89	96.3	98.2546	83.1229
2014	7	5	11	18	42	0.3	4.6	0.88	98.4	98.3202	81.0318

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	11	28	42	0.3	4.6	0.88	98.3	98.2546	81.5892
2014	7	5	11	38	42	0.3	4.6	0.84	101.1	98.189	76.6286
2014	7	5	11	48	42	0.3	4.6	0.85	100.5	98.2546	77.9085
2014	7	5	11	58	42	0.3	4.6	0.86	102.8	98.2546	78.2152
2014	7	5	12	8	42	0.3	4.6	0.87	102.2	98.189	79.0806
2014	7	5	12	18	42	0.3	4.6	0.87	100.5	98.189	79.6936
2014	7	5	12	28	42	0.3	4.6	0.86	98.1	98.189	80.0001
2014	7	5	12	38	42	0.3	4.6	0.86	100.3	98.189	79.3871
2014	7	5	12	48	42	0.3	4.6	0.89	100.4	98.189	81.8392
2014	7	5	12	58	42	0.3	4.6	0.85	97.7	98.189	79.0805
2014	7	5	13	8	42	0.3	4.6	0.87	98.7	98.189	80.3066
2014	7	5	13	18	42	0.3	4.6	0.9	101.1	98.189	82.7587
2014	7	5	13	28	42	0.3	4.6	0.87	102.2	98.189	79.6935
2014	7	5	13	38	42	0.3	4.6	0.89	101	98.189	81.8391
2014	7	5	13	48	42	0.3	4.6	0.89	95.7	98.189	83.0651
2014	7	5	13	58	42	0.3	4.6	0.85	96	98.189	79.3869
2014	7	5	14	8	42	0.3	4.6	0.84	96.7	98.189	77.8544
2014	7	5	14	18	42	0.3	4.6	0.86	100.3	98.1234	79.332
2014	7	5	14	28	42	0.3	4.6	0.88	101.6	98.1234	80.8635
2014	7	5	14	38	42	0.3	4.6	0.89	100.6	98.1234	81.7824
2014	7	5	14	48	42	0.3	4.6	0.87	97.8	98.1234	80.5572
2014	7	5	14	58	42	0.3	4.6	0.89	97.8	98.1234	82.395
2014	7	5	15	8	42	0.3	4.6	0.87	99.1	98.0577	80.1953
2014	7	5	15	18	42	0.3	4.6	0.88	98.8	98.0577	81.1136
2014	7	5	15	28	42	0.3	4.6	0.86	99.2	98.1234	79.332
2014	7	5	15	38	42	0.3	4.6	0.87	98.5	98.1234	79.9446
2014	7	5	15	48	42	0.3	4.6	0.86	99.7	98.0577	78.971
2014	7	5	15	58	42	0.3	4.6	0.88	101.9	98.1234	79.9446
2014	7	5	16	8	42	0.3	4.6	0.86	102.6	98.1234	78.413
2014	7	5	16	18	42	0.3	4.6	0.89	97	97.9921	82.5868
2014	7	5	16	28	42	0.3	4.6	0.89	96.6	98.0577	82.0318
2014	7	5	16	38	42	0.3	4.6	0.87	93.2	98.0577	81.1136
2014	7	5	16	48	42	0.3	4.6	0.88	100.8	98.0577	80.1953
2014	7	5	16	58	42	0.3	4.6	0.89	98.7	98.0577	81.7257
2014	7	5	17	8	42	0.3	4.6	0.85	97.9	98.0577	78.9709
2014	7	5	17	18	42	0.3	4.6	0.91	98.5	97.9921	83.5044
2014	7	5	17	28	42	0.3	4.6	0.87	98.9	98.0577	80.5014
2014	7	5	17	38	42	0.3	4.6	0.87	96.5	98.0577	80.5014
2014	7	5	17	48	42	0.3	4.6	0.85	97.5	97.9921	78.9162
2014	7	5	17	58	42	0.3	4.6	0.85	94.4	97.9921	78.9162
2014	7	5	18	8	42	0.3	4.6	0.87	95.4	97.9265	80.3898
2014	7	5	18	18	42	0.3	4.6	0.86	96.6	97.9921	79.528
2014	7	5	18	28	42	0.3	4.6	0.86	94.4	97.9921	80.1397
2014	7	5	18	38	42	0.3	4.6	0.89	96.5	97.9921	82.5867
2014	7	5	18	48	42	0.3	4.6	0.89	97	97.9921	82.5867
2014	7	5	18	58	42	0.3	4.6	0.88	99.4	97.9265	81.3068

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	19	8	42	0.3	4.6	0.9	95.6	97.9921	83.8102
2014	7	5	19	18	42	0.3	4.6	0.85	96	97.9921	79.2221
2014	7	5	19	28	42	0.3	4.6	0.84	94.9	97.9921	78.3044
2014	7	5	19	38	42	0.3	4.6	0.87	100.5	97.9921	79.5279
2014	7	5	19	48	42	0.3	4.6	0.83	96.4	98.0577	76.5221
2014	7	5	19	58	42	0.3	4.6	0.9	95.2	97.9921	83.5043
2014	7	5	20	8	42	0.3	4.6	0.87	95	97.9921	80.4455
2014	7	5	20	18	42	0.3	4.6	0.88	92.8	97.9921	82.2808
2014	7	5	20	28	42	0.3	4.6	0.88	94.5	97.9921	81.9749
2014	7	5	20	38	42	0.3	4.6	0.87	95.8	97.9921	80.7514
2014	7	5	20	48	42	0.3	4.6	0.87	95.2	98.0577	80.5013
2014	7	5	20	58	42	0.3	4.6	0.88	95.2	98.0577	81.4195
2014	7	5	21	8	42	0.3	4.6	0.86	96.8	98.0577	79.583
2014	7	5	21	18	42	0.3	4.6	0.87	94.8	98.0577	80.5013
2014	7	5	21	28	42	0.3	4.6	0.84	94.7	98.0577	78.0525
2014	7	5	21	38	42	0.3	4.6	0.89	95.3	98.0577	82.3378
2014	7	5	21	48	42	0.3	4.6	0.85	94.4	98.0577	78.9708
2014	7	5	21	58	42	0.3	4.6	0.89	96.5	98.0577	82.6439
2014	7	5	22	8	42	0.3	4.6	0.87	94.3	98.0577	80.8073
2014	7	5	22	18	42	0.3	4.6	0.87	96.7	98.0577	80.1951
2014	7	5	22	28	42	0.3	4.6	0.87	98.2	98.0577	80.5012
2014	7	5	22	38	42	0.3	4.6	0.86	94	98.0577	79.583
2014	7	5	22	48	42	0.3	4.6	0.87	95.2	98.0577	80.8073
2014	7	5	22	58	42	0.3	4.6	0.86	93.5	98.1234	80.2507
2014	7	5	23	8	42	0.3	4.6	0.86	96.3	98.1234	79.9444
2014	7	5	23	18	42	0.3	4.6	0.85	94.4	98.1234	78.7192
2014	7	5	23	28	42	0.3	4.6	0.88	94.3	98.1234	82.0885
2014	7	5	23	38	42	0.3	4.6	0.84	95.6	98.1234	78.4129
2014	7	5	23	48	42	0.3	4.6	0.84	94.3	98.1234	77.8003
2014	7	5	23	58	42	0.3	4.6	0.88	95.6	98.1234	81.7822
2014	7	6	0	8	42	0.3	4.6	0.86	93.9	98.1234	80.2507
2014	7	6	0	18	42	0.3	4.6	0.85	95.5	98.1234	79.3318
2014	7	6	0	28	42	0.3	4.6	0.83	95	98.1234	77.494
2014	7	6	0	38	42	0.3	4.6	0.84	94.9	98.1234	78.4129
2014	7	6	0	48	42	0.3	4.6	0.87	95	98.1234	81.1696
2014	7	6	0	58	42	0.3	4.6	0.87	94.5	98.1234	80.8633
2014	7	6	1	8	42	0.3	4.6	0.87	96	98.1234	81.1696
2014	7	6	1	18	42	0.3	4.6	0.87	94.3	98.1234	80.557
2014	7	6	1	28	42	0.3	4.6	0.87	95.9	98.1234	80.557
2014	7	6	1	38	42	0.3	4.6	0.88	95.6	98.1234	81.7822
2014	7	6	1	48	42	0.3	4.6	0.86	95.2	98.1234	80.2507
2014	7	6	1	58	42	0.3	4.6	0.84	96.1	98.1234	77.8003
2014	7	6	2	8	42	0.3	4.6	0.88	96.2	98.189	81.5323
2014	7	6	2	18	42	0.3	4.6	0.86	94.8	98.189	79.9997
2014	7	6	2	28	42	0.3	4.6	0.87	95.2	98.189	80.6128
2014	7	6	2	38	42	0.3	4.6	0.87	96	98.189	81.2258

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	2	48	42	0.3	4.6	0.9	94.8	98.189	83.6779
2014	7	6	2	58	42	0.3	4.6	0.87	93.7	98.189	81.5323
2014	7	6	3	8	42	0.3	4.6	0.86	95.2	98.189	80.3063
2014	7	6	3	18	42	0.3	4.6	0.87	93.9	98.189	81.2258
2014	7	6	3	28	42	0.3	4.6	0.86	95.7	98.189	80.3063
2014	7	6	3	38	42	0.3	4.6	0.82	95.7	98.189	76.6282
2014	7	6	3	48	42	0.3	4.6	0.89	95.9	98.189	82.7584
2014	7	6	3	58	42	0.3	4.6	0.87	94.6	98.189	80.6128
2014	7	6	4	8	42	0.3	4.6	0.87	95.6	98.189	81.2259
2014	7	6	4	18	42	0.3	4.6	0.89	95.7	98.189	82.4519
2014	7	6	4	28	42	0.3	4.6	0.87	94.8	98.189	80.6129
2014	7	6	4	38	42	0.3	4.6	0.87	95.4	98.189	80.9194
2014	7	6	4	48	42	0.3	4.6	0.85	95.1	98.189	78.7738
2014	7	6	4	58	42	0.3	4.6	0.87	97.4	98.189	80.6129
2014	7	6	5	8	42	0.3	4.6	0.84	95.4	98.189	77.8543
2014	7	6	5	18	42	0.3	4.6	0.87	93.7	98.189	81.5324
2014	7	6	5	28	42	0.3	4.6	0.82	93.7	98.189	76.6283
2014	7	6	5	38	42	0.3	4.6	0.87	93.7	98.189	81.5325
2014	7	6	5	48	42	0.3	4.6	0.84	92.9	98.189	78.7738
2014	7	6	5	58	42	0.3	4.6	0.85	94.9	98.189	79.3869
2014	7	6	6	8	42	0.3	4.6	0.86	97.2	98.189	79.6934
2014	7	6	6	18	42	0.3	4.6	0.85	97.1	98.189	78.4674
2014	7	6	6	28	42	0.3	4.6	0.83	95.6	98.189	77.5478
2014	7	6	6	38	42	0.3	4.6	0.86	95.7	98.2546	80.362
2014	7	6	6	48	42	0.3	4.6	0.86	95	98.2546	80.362
2014	7	6	6	58	42	0.3	4.6	0.87	95.6	98.2546	80.6687
2014	7	6	7	8	42	0.3	4.6	0.87	94.3	98.189	80.613
2014	7	6	7	18	42	0.3	4.6	0.88	95.5	98.2546	82.2024
2014	7	6	7	28	42	0.3	4.6	0.85	95.3	98.2546	79.4418
2014	7	6	7	38	42	0.3	4.6	0.9	95.5	98.2546	83.4293
2014	7	6	7	48	42	0.3	4.6	0.85	96.9	98.2546	79.1351
2014	7	6	7	58	42	0.3	4.6	0.86	96.1	98.2546	80.362
2014	7	6	8	8	42	0.3	4.6	0.85	95.1	98.2546	78.8284
2014	7	6	8	18	42	0.3	4.6	0.84	93.3	98.2546	78.8284
2014	7	6	8	28	42	0.3	4.6	0.86	98.4	98.2546	79.1351
2014	7	6	8	38	42	0.3	4.6	0.88	97.7	98.2546	81.2822
2014	7	6	8	48	42	0.3	4.6	0.88	95.6	98.2546	81.8956
2014	7	6	8	58	42	0.3	4.6	0.85	98.2	98.2546	78.5216
2014	7	6	9	8	42	0.3	4.6	0.86	94.8	98.2546	80.0553
2014	7	6	9	18	42	0.3	4.6	0.86	97.2	98.2546	79.7485
2014	7	6	9	28	42	0.3	4.6	0.86	95	98.2546	80.362
2014	7	6	9	38	42	0.3	4.6	0.87	97.6	98.2546	80.362
2014	7	6	9	48	42	0.3	4.6	0.87	94.3	98.2546	81.2822
2014	7	6	9	58	42	0.3	4.6	0.9	95	98.2546	83.4292
2014	7	6	10	8	42	0.3	4.6	0.86	96.4	98.2546	79.4417
2014	7	6	10	18	42	0.3	4.6	0.87	95.2	98.2546	80.6686

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	10	28	42	0.3	4.6	0.87	98.4	98.2546	80.6686
2014	7	6	10	38	42	0.3	4.6	0.88	96.4	98.2546	81.8955
2014	7	6	10	48	42	0.3	4.6	0.87	95.2	98.2546	80.6686
2014	7	6	10	58	42	0.3	4.6	0.87	98.4	98.2546	80.6686
2014	7	6	11	8	42	0.3	4.6	0.86	99	98.189	79.0803
2014	7	6	11	18	42	0.3	4.6	0.89	99.1	98.189	81.8389
2014	7	6	11	28	42	0.3	4.6	0.89	100.4	98.189	82.1454
2014	7	6	11	38	42	0.3	4.6	0.9	98.6	98.2546	83.4291
2014	7	6	11	48	42	0.3	4.6	0.88	97.5	98.189	81.8389
2014	7	6	11	58	42	0.3	4.6	0.89	97	98.189	82.7584
2014	7	6	12	8	42	0.3	4.6	0.85	98.2	98.189	78.4672
2014	7	6	12	18	42	0.3	4.6	0.88	98.8	98.2546	81.282
2014	7	6	12	28	42	0.3	4.6	0.89	101.2	98.189	81.8388
2014	7	6	12	38	42	0.3	4.6	0.89	97.4	98.2546	82.2021
2014	7	6	12	48	42	0.3	4.6	0.89	97.4	98.2546	82.202
2014	7	6	12	58	42	0.3	4.6	0.88	95.3	98.2546	81.8953
2014	7	6	13	8	42	0.3	4.6	0.86	100.7	98.189	79.3866
2014	7	6	13	18	42	0.3	4.6	0.87	97.8	98.2546	80.3616
2014	7	6	13	28	42	0.3	4.6	0.84	97.2	98.189	77.854
2014	7	6	13	38	42	0.3	4.6	0.88	99.8	98.189	81.2256
2014	7	6	13	48	42	0.3	4.6	0.86	97.9	98.189	79.693
2014	7	6	13	58	42	0.3	4.6	0.89	97.2	98.189	82.4516
2014	7	6	14	8	42	0.3	4.6	0.87	99.3	98.189	80.6125
2014	7	6	14	18	42	0.3	4.6	0.87	96.1	98.189	80.919
2014	7	6	14	28	42	0.3	4.6	0.85	96.7	98.189	78.7734
2014	7	6	14	38	42	0.3	4.6	0.84	98.5	98.189	77.8539
2014	7	6	14	48	42	0.3	4.6	0.85	93.8	98.189	79.0799
2014	7	6	14	58	42	0.3	4.6	0.89	97.4	98.189	82.145
2014	7	6	15	8	42	0.3	4.6	0.84	95.6	98.1234	78.1063
2014	7	6	15	18	42	0.3	4.6	0.88	95.2	98.1234	81.4756
2014	7	6	15	28	42	0.3	4.6	0.89	94.7	98.0577	82.6436
2014	7	6	15	38	42	0.3	4.6	0.87	95.2	98.1234	80.863
2014	7	6	15	48	42	0.3	4.6	0.89	97.4	97.9921	82.2804
2014	7	6	15	58	42	0.3	4.6	0.92	96.9	97.9921	85.3392
2014	7	6	16	8	42	0.3	4.6	0.87	97.6	97.9921	80.7511
2014	7	6	16	18	42	0.3	4.6	0.89	95.9	97.9265	82.2234
2014	7	6	16	28	42	0.3	4.6	0.89	97.2	98.0577	82.3375
2014	7	6	16	38	42	0.3	4.6	0.87	100.6	98.0577	79.8888
2014	7	6	16	48	42	0.3	4.6	0.87	98.3	98.0577	80.1949
2014	7	6	16	58	42	0.3	4.6	0.86	97.2	97.9921	79.5276
2014	7	6	17	8	42	0.3	4.6	0.89	98.2	98.0577	82.3375
2014	7	6	17	18	42	0.3	4.6	0.88	94.1	98.1234	82.0883
2014	7	6	17	28	42	0.3	4.6	0.88	96.4	98.1234	81.782
2014	7	6	17	38	42	0.3	4.6	0.87	96.3	98.1234	80.5568
2014	7	6	17	48	42	0.3	4.6	0.9	98.4	98.1234	82.7009
2014	7	6	17	58	42	0.3	4.6	0.89	96.6	98.1234	82.3945

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	18	8	42	0.3	4.6	0.86	97.4	98.189	79.9995
2014	7	6	18	18	42	0.3	4.6	0.87	94.1	98.189	80.6125
2014	7	6	18	28	42	0.3	4.6	0.88	94.3	98.189	81.532
2014	7	6	18	38	42	0.3	4.6	0.9	93.3	98.189	83.9841
2014	7	6	18	48	42	0.3	4.6	0.87	96.1	98.189	80.919
2014	7	6	18	58	42	0.3	4.6	0.9	94.8	98.189	83.3711
2014	7	6	19	8	42	0.3	4.6	0.86	94.4	98.189	79.9994
2014	7	6	19	18	42	0.3	4.6	0.87	96.5	98.189	81.2255
2014	7	6	19	28	42	0.3	4.6	0.87	95.6	98.189	81.2255
2014	7	6	19	38	42	0.3	4.6	0.89	93.6	98.189	82.758
2014	7	6	19	48	42	0.3	4.6	0.85	93.1	98.189	79.3864
2014	7	6	19	58	42	0.3	4.6	0.86	96.6	98.189	79.9994
2014	7	6	20	8	42	0.3	4.6	0.85	93.3	98.189	79.3864
2014	7	6	20	18	42	0.3	4.6	0.86	94.6	98.189	79.6929
2014	7	6	20	28	42	0.3	4.6	0.83	96.6	98.1234	76.5748
2014	7	6	20	38	42	0.3	4.6	0.9	95.2	98.189	83.984
2014	7	6	20	48	42	0.3	4.6	0.84	94.5	98.189	78.4668
2014	7	6	20	58	42	0.3	4.6	0.87	94.8	98.189	80.6124
2014	7	6	21	8	42	0.3	4.6	0.84	95.2	98.2546	78.2144
2014	7	6	21	18	42	0.3	4.6	0.86	95.3	98.2546	80.0547
2014	7	6	21	28	42	0.3	4.6	0.87	94.3	98.2546	81.2816
2014	7	6	21	38	42	0.3	4.6	0.88	93.8	98.2546	82.5085
2014	7	6	21	48	42	0.3	4.6	0.86	93.7	98.2546	80.6681
2014	7	6	21	58	42	0.3	4.6	0.86	95.7	98.189	80.3059
2014	7	6	22	8	42	0.3	4.6	0.86	94.8	98.189	79.6928
2014	7	6	22	18	42	0.3	4.6	0.87	95.2	98.2546	81.2816
2014	7	6	22	28	42	0.3	4.6	0.89	95.5	98.189	82.4514
2014	7	6	22	38	42	0.3	4.6	0.89	94	98.2546	82.8152
2014	7	6	22	48	42	0.3	4.6	0.84	95.6	98.2546	78.5211
2014	7	6	22	58	42	0.3	4.6	0.85	95.1	98.2546	78.8278
2014	7	6	23	8	42	0.3	4.6	0.84	94.5	98.2546	78.2143
2014	7	6	23	18	42	0.3	4.6	0.84	94.5	98.2546	78.2143
2014	7	6	23	28	42	0.3	4.6	0.83	95.4	98.2546	77.6009
2014	7	6	23	38	42	0.3	4.6	0.89	95.9	98.2546	82.8152
2014	7	6	23	48	42	0.3	4.6	0.86	95.3	98.2546	79.7479
2014	7	6	23	58	42	0.3	4.6	0.87	96.2	98.2546	81.2816
2014	7	7	0	8	42	0.3	4.6	0.88	95.4	98.2546	81.5883
2014	7	7	0	18	42	0.3	4.6	0.88	96	98.2546	81.895
2014	7	7	0	28	42	0.3	4.6	0.86	96.6	98.3202	79.4961
2014	7	7	0	38	42	0.3	4.6	0.88	94.5	98.2546	81.895
2014	7	7	0	48	42	0.3	4.6	0.85	95.6	98.3202	78.8823
2014	7	7	0	58	42	0.3	4.6	0.86	94.4	98.3202	80.4169
2014	7	7	1	8	42	0.3	4.6	0.86	94.2	98.2546	79.7479
2014	7	7	1	18	42	0.3	4.6	0.88	96.2	98.3202	82.2585
2014	7	7	1	28	42	0.3	4.6	0.86	93.7	98.3202	80.7239
2014	7	7	1	38	42	0.3	4.6	0.9	98.4	98.3202	82.8724

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	1	48	42	0.3	4.6	0.85	94.2	98.3202	79.1892
2014	7	7	1	58	42	0.3	4.6	0.88	94.3	98.3202	82.5655
2014	7	7	2	8	42	0.3	4.6	0.88	95.6	98.3202	81.9516
2014	7	7	2	18	42	0.3	4.6	0.88	94.3	98.3202	82.2586
2014	7	7	2	28	42	0.3	4.6	0.83	94.8	98.3202	77.3476
2014	7	7	2	38	42	0.3	4.6	0.85	93.3	98.3202	79.8031
2014	7	7	2	48	42	0.3	4.6	0.85	93.3	98.3202	79.8031
2014	7	7	2	58	42	0.3	4.6	0.87	96.3	98.3202	80.7239
2014	7	7	3	8	42	0.3	4.6	0.89	93.4	98.3202	82.8725
2014	7	7	3	18	42	0.3	4.6	0.89	95.7	98.3202	82.8725
2014	7	7	3	28	42	0.3	4.6	0.87	94.5	98.3202	81.0309
2014	7	7	3	38	42	0.3	4.6	0.85	95.7	98.3202	79.4962
2014	7	7	3	48	42	0.3	4.6	0.89	95.9	98.3202	82.5656
2014	7	7	3	58	42	0.3	4.6	0.87	95.4	98.3202	80.724
2014	7	7	4	8	42	0.3	4.6	0.87	94.5	98.3202	81.0309
2014	7	7	4	18	42	0.3	4.6	0.88	94.1	98.3202	82.2587
2014	7	7	4	28	42	0.3	4.6	0.85	96	98.3202	79.1893
2014	7	7	4	38	42	0.3	4.6	0.88	96	98.3202	81.9517
2014	7	7	4	48	42	0.3	4.6	0.83	93.4	98.3202	77.3477
2014	7	7	4	58	42	0.3	4.6	0.88	97.5	98.3202	81.3379
2014	7	7	5	8	42	0.3	4.6	0.89	95.5	98.3202	82.5656
2014	7	7	5	18	42	0.3	4.6	0.88	95.2	98.3202	81.6448
2014	7	7	5	28	42	0.3	4.6	0.89	96.8	98.3202	82.8726
2014	7	7	5	38	42	0.3	4.6	0.84	94.3	98.3202	77.9616
2014	7	7	5	48	42	0.3	4.6	0.85	93.5	98.3858	79.8584
2014	7	7	5	58	42	0.3	4.6	0.87	95.4	98.3858	80.7798
2014	7	7	6	8	42	0.3	4.6	0.86	96.6	98.3858	80.1655
2014	7	7	6	18	42	0.3	4.6	0.83	93.6	98.3858	77.4012
2014	7	7	6	28	42	0.3	4.6	0.88	95.8	98.3858	81.7013
2014	7	7	6	38	42	0.3	4.6	0.87	94.8	98.3858	80.7798
2014	7	7	6	48	42	0.3	4.6	0.88	97.1	98.3858	81.3941
2014	7	7	6	58	42	0.3	4.6	0.85	95.1	98.3858	78.937
2014	7	7	7	8	42	0.3	4.6	0.88	95.3	98.3858	82.3156
2014	7	7	7	18	42	0.3	4.6	0.84	94.5	98.3858	78.3227
2014	7	7	7	28	42	0.3	4.6	0.87	95.4	98.3858	81.3942
2014	7	7	7	38	42	0.3	4.6	0.85	93.8	98.3858	79.2441
2014	7	7	7	48	42	0.3	4.6	0.86	93.9	98.3858	80.4727
2014	7	7	7	58	42	0.3	4.6	0.87	94.3	98.3858	80.7799
2014	7	7	8	8	42	0.3	4.6	0.89	94.5	98.3858	82.6227
2014	7	7	8	18	42	0.3	4.6	0.89	96.2	98.3858	82.6227
2014	7	7	8	28	42	0.3	4.6	0.86	97.2	98.3858	79.8584
2014	7	7	8	38	42	0.3	4.6	0.86	96.3	98.3858	80.1656
2014	7	7	8	48	42	0.3	4.6	0.91	94.6	98.3858	84.7728
2014	7	7	8	58	42	0.3	4.6	0.86	95.5	98.3858	79.8584
2014	7	7	9	8	42	0.3	4.6	0.84	95.4	98.3858	78.6298
2014	7	7	9	18	42	0.3	4.6	0.88	94.3	98.3858	81.7013

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	9	28	42	0.3	4.6	0.89	94.7	98.3858	82.6227
2014	7	7	9	38	42	0.3	4.6	0.86	96.1	98.3858	79.8584
2014	7	7	9	48	42	0.3	4.6	0.88	95.4	98.3858	81.7013
2014	7	7	9	58	42	0.3	4.6	0.87	95.4	98.3858	81.3941
2014	7	7	10	8	42	0.3	4.6	0.86	97.4	98.3858	80.1655
2014	7	7	10	18	42	0.3	4.6	0.85	94.2	98.3858	79.5512
2014	7	7	10	28	42	0.3	4.6	0.84	94.7	98.3858	78.3226
2014	7	7	10	38	42	0.3	4.6	0.87	96.3	98.3858	81.0869
2014	7	7	10	48	42	0.3	4.6	0.87	93.7	98.3858	81.7012
2014	7	7	10	58	42	0.3	4.6	0.89	97.2	98.3858	82.3155
2014	7	7	11	8	42	0.3	4.6	0.9	94.6	98.3858	83.8512
2014	7	7	11	18	42	0.3	4.6	0.85	95.3	98.3858	79.244
2014	7	7	11	28	42	0.3	4.6	0.88	94.9	98.3858	82.0083
2014	7	7	11	38	42	0.3	4.6	0.87	96.3	98.3858	81.0869
2014	7	7	11	48	42	0.3	4.6	0.91	97.9	98.3858	84.1583
2014	7	7	11	58	42	0.3	4.6	0.86	101	98.3858	79.2439
2014	7	7	12	8	42	0.3	4.6	0.87	96.5	98.3858	81.0867
2014	7	7	12	18	42	0.3	4.6	0.88	96.6	98.3858	82.0081
2014	7	7	12	28	42	0.3	4.6	0.86	103.5	98.3858	78.3224
2014	7	7	12	38	42	0.3	4.6	0.9	100.1	98.3858	82.6225
2014	7	7	12	48	42	0.3	4.6	0.86	98.1	98.3858	79.8581
2014	7	7	12	58	42	0.3	4.6	0.89	100.8	98.3858	82.0082
2014	7	7	13	8	42	0.3	4.6	0.85	99.5	98.3202	78.8822
2014	7	7	13	18	42	0.3	4.6	0.88	99	98.3202	81.0308
2014	7	7	13	28	42	0.3	4.6	0.88	99	98.3202	81.6446
2014	7	7	13	38	42	0.3	4.6	0.87	99.3	98.3858	80.4724
2014	7	7	13	48	42	0.3	4.6	0.88	99	98.3202	81.0308
2014	7	7	13	58	42	0.3	4.6	0.91	98.5	98.3202	84.407
2014	7	7	14	8	42	0.3	4.6	0.88	98.3	98.3202	81.6446
2014	7	7	14	18	42	0.3	4.6	0.89	97.2	98.3202	82.8724
2014	7	7	14	28	42	0.3	4.6	0.91	98.5	98.3202	84.1001
2014	7	7	14	40	59	0.3	4.6	0.77	106.6	98.2546	69.0126
2014	7	7	14	50	59	0.3	4.6	0.84	104.9	98.4515	76.225
2014	7	7	15	0	59	0.3	4.6	0.88	97.3	98.3202	81.6446
2014	7	7	15	10	59	0.3	4.6	0.87	97.6	98.3858	81.0867
2014	7	7	15	20	59	0.3	4.6	0.86	97	98.3858	79.8581
2014	7	7	15	30	59	0.3	4.6	0.87	96.7	98.3858	81.0867
2014	7	7	15	40	59	0.3	4.6	0.89	95.5	98.3858	82.6224
2014	7	7	15	50	59	0.3	4.6	0.89	99.6	98.3202	81.9515
2014	7	7	16	0	59	0.3	4.6	0.88	97.5	98.3858	82.0081
2014	7	7	16	10	59	0.3	4.6	0.88	97	98.3858	82.0081
2014	7	7	16	20	59	0.3	4.6	0.87	102	98.3202	79.496
2014	7	7	16	30	59	0.3	4.6	0.89	99.1	98.3202	82.5653
2014	7	7	16	40	59	0.3	4.6	0.87	99.5	98.3202	80.7237
2014	7	7	16	50	59	0.3	4.6	0.89	99.3	98.3202	82.2584
2014	7	7	17	0	59	0.3	4.6	0.87	98.5	98.3202	80.1099

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	17	10	59	0.3	4.6	0.87	99.1	98.3202	80.7237
2014	7	7	17	20	59	0.3	4.6	0.88	98.8	98.3202	81.0307
2014	7	7	17	30	59	0.3	4.6	0.81	95.3	98.3202	75.8128
2014	7	7	17	40	59	0.3	4.6	0.85	95.1	98.3202	78.8821
2014	7	7	17	50	59	0.3	4.6	0.86	95.9	98.3858	79.8581
2014	7	7	18	0	59	0.3	4.6	0.84	96.7	98.3858	78.3223
2014	7	7	18	10	59	0.3	4.6	0.86	96.6	98.3202	79.8029
2014	7	7	18	20	59	0.3	4.6	0.87	96.5	98.3202	80.4168
2014	7	7	18	30	59	0.3	4.6	0.86	95	98.3202	80.4168
2014	7	7	18	40	59	0.3	4.6	0.86	95.3	98.3858	79.858
2014	7	7	18	50	59	0.3	4.6	0.86	96.8	98.3858	79.5509
2014	7	7	19	0	59	0.3	4.6	0.87	95.2	98.3858	81.3938
2014	7	7	19	10	59	0.3	4.6	0.85	95.5	98.3858	79.2437
2014	7	7	19	20	59	0.3	4.6	0.86	95.5	98.3858	80.1652
2014	7	7	19	30	59	0.3	4.6	0.86	96.3	98.3858	80.1652
2014	7	7	19	40	59	0.3	4.6	0.86	96.1	98.3858	79.858
2014	7	7	19	50	59	0.3	4.6	0.86	96.6	98.3858	79.5509
2014	7	7	20	0	59	0.3	4.6	0.88	95.8	98.3858	81.7009
2014	7	7	20	10	59	0.3	4.6	0.88	95.3	98.3858	82.3152
2014	7	7	20	20	59	0.3	4.6	0.86	94.2	98.3858	79.858
2014	7	7	20	30	59	0.3	4.6	0.85	95.5	98.3858	79.5509
2014	7	7	20	40	59	0.3	4.6	0.85	95.3	98.3858	79.2437
2014	7	7	20	50	59	0.3	4.6	0.85	97.5	98.3858	79.2437
2014	7	7	21	0	59	0.3	4.6	0.86	94.4	98.3858	80.1652
2014	7	7	21	10	59	0.3	4.6	0.86	94.2	98.3858	80.1652
2014	7	7	21	20	59	0.3	4.6	0.86	95.7	98.3858	80.1652
2014	7	7	21	30	59	0.3	4.6	0.85	97.1	98.3858	79.2437
2014	7	7	21	40	59	0.3	4.6	0.87	93.7	98.3858	81.3938
2014	7	7	21	50	59	0.3	4.6	0.87	96.5	98.3858	81.3938
2014	7	7	22	0	59	0.3	4.6	0.86	95.5	98.4515	80.2205
2014	7	7	22	10	59	0.3	4.6	0.86	93.7	98.3858	80.7795
2014	7	7	22	20	59	0.3	4.6	0.86	95.3	98.3858	79.858
2014	7	7	22	30	59	0.3	4.6	0.87	95.4	98.3858	81.0866
2014	7	7	22	40	59	0.3	4.6	0.87	93	98.4515	81.7573
2014	7	7	22	50	59	0.3	4.6	0.86	95.7	98.3858	80.4723
2014	7	7	23	0	59	0.3	4.6	0.88	95.3	98.3858	82.0081
2014	7	7	23	10	59	0.3	4.6	0.88	96.2	98.4515	82.372
2014	7	7	23	20	59	0.3	4.6	0.88	95.4	98.4515	81.7573
2014	7	7	23	30	59	0.3	4.6	0.86	95.5	98.4515	79.9132
2014	7	7	23	40	59	0.3	4.6	0.84	94.5	98.4515	78.3764
2014	7	7	23	50	59	0.3	4.6	0.87	96.5	98.4515	80.5279
2014	7	8	0	0	59	0.3	4.6	0.84	96.3	98.4515	78.3764
2014	7	8	0	10	59	0.3	4.6	0.85	95.6	98.4515	78.9911
2014	7	8	0	20	59	0.3	4.6	0.86	94.8	98.4515	79.9132
2014	7	8	0	30	59	0.3	4.6	0.86	96.3	98.4515	80.2206
2014	7	8	0	40	59	0.3	4.6	0.86	97	98.4515	79.9132

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	0	50	59	0.3	4.6	0.87	95.2	98.4515	80.8353
2014	7	8	1	0	59	0.3	4.6	0.84	96.3	98.4515	78.3764
2014	7	8	1	10	59	0.3	4.6	0.84	96.3	98.4515	78.0691
2014	7	8	1	20	59	0.3	4.6	0.86	94.6	98.4515	79.9132
2014	7	8	1	30	59	0.3	4.6	0.86	96.1	98.4515	79.9132
2014	7	8	1	40	59	0.3	4.6	0.88	94.7	98.5171	82.4289
2014	7	8	1	50	59	0.3	4.6	0.86	96.4	98.4515	79.9132
2014	7	8	2	0	59	0.3	4.6	0.88	95.6	98.5171	82.1213
2014	7	8	2	10	59	0.3	4.6	0.85	96.5	98.5171	78.7381
2014	7	8	2	20	59	0.3	4.6	0.86	95.5	98.4515	80.2206
2014	7	8	2	30	59	0.3	4.6	0.86	96.8	98.5171	79.6608
2014	7	8	2	40	59	0.3	4.6	0.87	96.3	98.5171	80.8911
2014	7	8	2	50	59	0.3	4.6	0.84	95.8	98.5171	78.4305
2014	7	8	3	0	59	0.3	4.6	0.86	95.5	98.5827	80.3313
2014	7	8	3	10	59	0.3	4.6	0.84	94.5	98.5171	78.7381
2014	7	8	3	20	59	0.3	4.6	0.86	94.6	98.5171	79.9684
2014	7	8	3	30	59	0.3	4.6	0.85	95.3	98.5171	79.3533
2014	7	8	3	40	59	0.3	4.6	0.87	96.5	98.5171	81.1987
2014	7	8	3	50	59	0.3	4.6	0.85	97.3	98.5171	79.0457
2014	7	8	4	0	59	0.3	4.6	0.84	95.6	98.5171	78.4306
2014	7	8	4	10	59	0.3	4.6	0.85	95.5	98.5171	79.6609
2014	7	8	4	20	59	0.3	4.6	0.87	95.8	98.5171	81.5063
2014	7	8	4	30	59	0.3	4.6	0.84	96.3	98.5171	78.123
2014	7	8	4	40	59	0.3	4.6	0.87	96.1	98.5171	81.1987
2014	7	8	4	50	59	0.3	4.6	0.86	97.5	98.5171	79.9685
2014	7	8	5	0	59	0.3	4.6	0.85	97.3	98.5171	79.0458
2014	7	8	5	10	59	0.3	4.6	0.85	95.5	98.5171	79.3533
2014	7	8	5	20	59	0.3	4.6	0.86	97.4	98.5827	80.3314
2014	7	8	5	30	59	0.3	4.6	0.84	94	98.5827	78.4847
2014	7	8	5	40	59	0.3	4.6	0.85	95.1	98.5827	79.7158
2014	7	8	5	50	59	0.3	4.6	0.83	95.7	98.5827	77.5614
2014	7	8	6	0	59	0.3	4.6	0.85	95.3	98.5827	79.7159
2014	7	8	6	10	59	0.3	4.6	0.83	96.4	98.6483	76.9988
2014	7	8	6	20	59	0.3	4.6	0.89	97.2	98.6483	82.5428
2014	7	8	6	30	59	0.3	4.6	0.89	96.3	98.7139	83.216
2014	7	8	6	40	59	0.3	4.6	0.82	96.2	98.7795	76.488
2014	7	8	6	50	59	0.3	4.6	0.85	94.9	98.7795	79.8807
2014	7	8	7	0	59	0.3	4.6	0.85	96.4	98.7795	79.5723
2014	7	8	7	10	59	0.3	4.6	0.87	95	98.7795	81.4228
2014	7	8	7	20	59	0.3	4.6	0.86	96.8	98.7795	80.1891
2014	7	8	7	30	59	0.3	4.6	0.84	94.7	98.7795	78.3386
2014	7	8	7	40	59	0.3	4.6	0.85	96.6	98.7795	79.5723
2014	7	8	7	50	59	0.3	4.6	0.86	97.7	98.7795	79.8807
2014	7	8	8	0	59	0.3	4.6	0.83	96.1	98.7795	78.0301
2014	7	8	8	10	59	0.3	4.6	0.89	98.5	98.7795	82.348
2014	7	8	8	20	59	0.3	4.6	0.9	98.2	98.7795	83.5817

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	8	30	59	0.3	4.6	0.85	97.7	98.7795	79.5722
2014	7	8	8	40	59	0.3	4.6	0.87	98.6	98.7795	81.1143
2014	7	8	8	50	59	0.3	4.6	0.87	98.6	98.7139	81.0585
2014	7	8	9	0	59	0.3	4.6	0.85	98	98.7139	79.2093
2014	7	8	9	10	59	0.3	4.6	0.86	97.6	98.7139	80.4421
2014	7	8	9	20	59	0.3	4.6	0.84	99.2	98.7139	78.2846
2014	7	8	9	30	59	0.3	4.6	0.88	99.6	98.7139	81.6749
2014	7	8	9	40	59	0.3	4.6	0.9	101.6	98.6483	82.5427
2014	7	8	9	50	59	0.3	4.6	0.89	95.3	98.5827	83.1014
2014	7	8	10	0	59	0.3	4.6	0.85	100.3	98.5827	78.1769
2014	7	8	10	10	59	0.3	4.6	0.86	99.4	98.5827	79.7158
2014	7	8	10	20	59	0.3	4.6	0.87	99.1	98.5827	80.3314
2014	7	8	10	30	59	0.3	4.6	0.89	99.6	98.5827	81.8703
2014	7	8	10	40	59	0.3	4.6	0.84	99.9	98.5827	77.8691
2014	7	8	10	50	59	0.3	4.6	0.88	100.7	98.5827	81.5625
2014	7	8	11	0	59	0.3	4.6	0.85	100.7	98.5171	78.123
2014	7	8	11	10	59	0.3	4.6	0.88	100.5	98.5827	81.2546
2014	7	8	11	20	59	0.3	4.6	0.88	98.8	98.6483	81.3106
2014	7	8	11	30	59	0.3	4.6	0.87	100	98.5171	79.9684
2014	7	8	11	40	59	0.3	4.6	0.9	99.5	98.5171	83.0441
2014	7	8	11	50	59	0.3	4.6	0.89	96.8	98.5827	83.1013
2014	7	8	12	0	59	0.3	4.6	0.85	99.1	98.5827	79.1002
2014	7	8	12	10	59	0.3	4.6	0.88	96.6	98.6483	82.2346
2014	7	8	12	20	59	0.3	4.6	0.87	96.5	98.5827	81.5624
2014	7	8	12	30	59	0.3	4.6	0.88	98.6	98.5827	81.5624
2014	7	8	12	40	59	0.3	4.6	0.87	98	98.5827	80.9469
2014	7	8	12	50	59	0.3	4.6	0.88	97.1	98.5171	81.5062
2014	7	8	13	0	59	0.3	4.6	0.9	98.2	98.5827	83.1012
2014	7	8	13	10	59	0.3	4.6	0.92	96.6	98.5827	85.5635
2014	7	8	13	20	59	0.3	4.6	0.89	99.1	98.5171	82.1212
2014	7	8	13	30	59	0.3	4.6	0.9	101.1	98.5827	82.7934
2014	7	8	13	40	59	0.3	4.6	0.92	100	98.5827	85.2556
2014	7	8	13	50	59	0.3	4.6	0.87	101.1	98.5171	79.6606
2014	7	8	14	0	59	0.3	4.6	0.87	98.3	98.5171	80.2758
2014	7	8	14	10	59	0.3	4.6	0.86	96.6	98.5827	80.0234
2014	7	8	14	20	59	0.3	4.6	0.88	97	98.5171	82.1213
2014	7	8	14	30	59	0.3	4.6	0.88	96.4	98.5827	82.4857
2014	7	8	14	40	59	0.3	4.6	0.85	94.4	98.5827	79.1001
2014	7	8	14	50	59	0.3	4.6	0.86	94.8	98.5171	79.9683
2014	7	8	15	0	59	0.3	4.6	0.87	98	98.5171	80.891
2014	7	8	15	10	59	0.3	4.6	0.86	93.9	98.5171	80.2758
2014	7	8	15	20	59	0.3	4.6	0.84	95.8	98.5171	78.1228
2014	7	8	15	30	59	0.3	4.6	0.9	97.1	98.5827	84.0245
2014	7	8	15	40	59	0.3	4.6	0.87	96.3	98.5171	80.8909
2014	7	8	15	50	59	0.3	4.6	0.89	96.5	98.5171	83.3515
2014	7	8	16	0	59	0.3	4.6	0.9	96.9	98.4515	83.6014

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	16	10	59	0.3	4.6	0.86	97	98.4515	79.9131
2014	7	8	16	20	59	0.3	4.6	0.87	97.6	98.4515	81.1425
2014	7	8	16	30	59	0.3	4.6	0.88	101	98.4515	80.8352
2014	7	8	16	40	59	0.3	4.6	0.87	98.6	98.4515	80.8352
2014	7	8	16	50	59	0.3	4.6	0.9	97.4	98.4515	83.294
2014	7	8	17	0	59	0.3	4.6	0.9	97.8	98.3858	83.2366
2014	7	8	17	10	59	0.3	4.6	0.84	96.3	98.4515	78.0689
2014	7	8	17	20	59	0.3	4.6	0.88	97.7	98.4515	81.7572
2014	7	8	17	30	59	0.3	4.6	0.88	94.5	98.4515	81.7572
2014	7	8	17	40	59	0.3	4.6	0.88	95.2	98.4515	81.7572
2014	7	8	17	50	59	0.3	4.6	0.87	97.2	98.4515	80.5278
2014	7	8	18	0	59	0.3	4.6	0.89	96.5	98.4515	83.294
2014	7	8	18	10	59	0.3	4.6	0.87	96.5	98.4515	81.4498
2014	7	8	18	20	59	0.3	4.6	0.84	95.1	98.4515	78.6836
2014	7	8	18	30	59	0.3	4.6	0.88	96	98.4515	82.0645
2014	7	8	18	40	59	0.3	4.6	0.89	93.2	98.5171	83.3514
2014	7	8	18	50	59	0.3	4.6	0.85	92.4	98.4515	79.6057
2014	7	8	19	0	59	0.3	4.6	0.89	94.4	98.5171	83.3514
2014	7	8	19	10	59	0.3	4.6	0.89	93.4	98.4515	83.6013
2014	7	8	19	20	59	0.3	4.6	0.88	93.4	98.4515	82.6793
2014	7	8	19	30	59	0.3	4.6	0.86	92.6	98.5171	80.8909
2014	7	8	19	40	59	0.3	4.6	0.86	95.7	98.4515	80.5278
2014	7	8	19	50	59	0.3	4.6	0.88	94.3	98.4515	81.7572
2014	7	8	20	0	59	0.3	4.6	0.86	93.3	98.4515	80.8351
2014	7	8	20	10	59	0.3	4.6	0.88	92.6	98.4515	82.3719
2014	7	8	20	20	59	0.3	4.6	0.84	95.4	98.5171	78.4303
2014	7	8	20	30	59	0.3	4.6	0.85	93.7	98.4515	79.9131
2014	7	8	20	40	59	0.3	4.6	0.86	93.3	98.5171	80.5833
2014	7	8	20	50	59	0.3	4.6	0.88	93.8	98.4515	82.6793
2014	7	8	21	0	59	0.3	4.6	0.85	92.6	98.5171	79.9682
2014	7	8	21	10	59	0.3	4.6	0.84	92.9	98.5171	79.0455
2014	7	8	21	20	59	0.3	4.6	0.84	93.3	98.5171	79.0455
2014	7	8	21	30	59	0.3	4.6	0.88	95.8	98.4515	81.7572
2014	7	8	21	40	59	0.3	4.6	0.88	95.3	98.5171	82.1212
2014	7	8	21	50	59	0.3	4.6	0.87	94.7	98.5171	81.5061
2014	7	8	22	0	59	0.3	4.6	0.87	94.5	98.5171	81.5061
2014	7	8	22	10	59	0.3	4.6	0.89	96.4	98.5171	82.7363
2014	7	8	22	20	59	0.3	4.6	0.91	95.8	98.5171	84.5818
2014	7	8	22	30	59	0.3	4.6	0.86	95.5	98.5171	80.5834
2014	7	8	22	40	59	0.3	4.6	0.87	94.3	98.5171	81.1985
2014	7	8	22	50	59	0.3	4.6	0.82	94.8	98.5171	76.2774
2014	7	8	23	0	59	0.3	4.6	0.84	92.2	98.5171	78.738
2014	7	8	23	10	59	0.3	4.6	0.89	94.2	98.5171	83.3515
2014	7	8	23	20	59	0.3	4.6	0.87	94.1	98.5171	81.5061
2014	7	8	23	30	59	0.3	4.6	0.87	95.4	98.5171	81.5061
2014	7	8	23	40	59	0.3	4.6	0.88	95.2	98.5171	81.8137

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	23	50	59	0.3	4.6	0.88	95.2	98.5171	81.8137
2014	7	9	0	0	59	0.3	4.6	0.91	95	98.5171	84.5818
2014	7	9	0	10	59	0.3	4.6	0.85	95.3	98.5171	79.3531
2014	7	9	0	20	59	0.3	4.6	0.9	93.1	98.5171	83.9667
2014	7	9	0	30	59	0.3	4.6	0.87	96.5	98.5171	80.891
2014	7	9	0	40	59	0.3	4.6	0.89	93.2	98.5171	83.044
2014	7	9	0	50	59	0.3	4.6	0.89	95.3	98.5171	83.3516
2014	7	9	1	0	59	0.3	4.6	0.87	92.8	98.5171	81.8138
2014	7	9	1	10	59	0.3	4.6	0.88	96.2	98.5827	82.4857
2014	7	9	1	20	59	0.3	4.6	0.86	97	98.5827	80.0235
2014	7	9	1	30	59	0.3	4.6	0.89	96.3	98.5827	83.4091
2014	7	9	1	40	59	0.3	4.6	0.85	92.2	98.5827	79.7157
2014	7	9	1	50	59	0.3	4.6	0.86	96.6	98.5827	79.7157
2014	7	9	2	0	59	0.3	4.6	0.88	94.3	98.5827	82.178
2014	7	9	2	10	59	0.3	4.6	0.9	92.9	98.5827	84.0247
2014	7	9	2	20	59	0.3	4.6	0.89	94.4	98.5827	83.4091
2014	7	9	2	30	59	0.3	4.6	0.87	96.5	98.5827	81.5625
2014	7	9	2	40	59	0.3	4.6	0.88	96.6	98.5827	82.178
2014	7	9	2	50	59	0.3	4.6	0.92	93.1	98.6483	85.9306
2014	7	9	3	0	59	0.3	4.6	0.88	94.3	98.6483	82.8507
2014	7	9	3	10	59	0.3	4.6	0.89	94.9	98.6483	82.8507
2014	7	9	3	20	59	0.3	4.6	0.89	95.3	98.7139	83.5241
2014	7	9	3	30	59	0.3	4.6	0.87	95.2	98.7139	81.6749
2014	7	9	3	40	59	0.3	4.6	0.87	95.2	98.7139	81.3667
2014	7	9	3	50	59	0.3	4.6	0.86	95.5	98.7795	80.189
2014	7	9	4	0	59	0.3	4.6	0.87	95.2	98.8452	81.1701
2014	7	9	4	10	59	0.3	4.6	0.88	95.6	98.7795	82.348
2014	7	9	4	20	59	0.3	4.6	0.89	96.8	98.8452	83.3305
2014	7	9	4	30	59	0.3	4.6	0.87	95.6	98.7795	81.4228
2014	7	9	4	40	59	0.3	4.6	0.9	95.5	98.8452	83.9478
2014	7	9	4	50	59	0.3	4.6	0.88	95.2	98.8452	82.096
2014	7	9	5	0	59	0.3	4.6	0.9	95.2	98.8452	84.5651
2014	7	9	5	10	59	0.3	4.6	0.88	94.3	98.8452	82.7133
2014	7	9	5	20	59	0.3	4.6	0.9	95.6	98.8452	84.2565
2014	7	9	5	30	59	0.3	4.6	0.87	95.9	98.9108	81.2259
2014	7	9	5	40	59	0.3	4.6	0.88	94.3	98.9108	82.7702
2014	7	9	5	50	59	0.3	4.6	0.89	93.8	98.9108	83.3879
2014	7	9	6	0	59	0.3	4.6	0.85	93.8	98.9108	79.6817
2014	7	9	6	10	59	0.3	4.6	0.87	97.4	98.9108	81.226
2014	7	9	6	20	59	0.3	4.6	0.88	94.3	98.9108	82.7702
2014	7	9	6	30	59	0.3	4.6	0.88	94.3	98.9108	82.7702
2014	7	9	6	40	59	0.3	4.6	0.87	93.3	98.9108	81.5348
2014	7	9	6	50	59	0.3	4.6	0.88	95.1	98.9108	82.7702
2014	7	9	7	0	59	0.3	4.6	0.88	93.4	98.9108	82.4614
2014	7	9	7	10	59	0.3	4.6	0.88	93.4	98.9108	83.0791
2014	7	9	7	20	59	0.3	4.6	0.87	96	98.9108	81.8437

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	7	30	59	0.3	4.6	0.88	95.8	98.9764	82.8271
2014	7	9	7	40	59	0.3	4.6	0.88	95.5	98.9108	82.7702
2014	7	9	7	50	59	0.3	4.6	0.88	96	98.9108	82.4614
2014	7	9	8	0	59	0.3	4.6	0.88	94.7	98.9764	82.2089
2014	7	9	8	10	59	0.3	4.6	0.89	95.7	98.9108	83.0791
2014	7	9	8	20	59	0.3	4.6	0.87	95.4	98.9108	81.226
2014	7	9	8	30	59	0.3	4.6	0.89	94.4	98.9764	83.4452
2014	7	9	8	40	59	0.3	4.6	0.86	95.7	98.9764	80.3546
2014	7	9	8	50	59	0.3	4.6	0.9	95.2	98.9108	84.3144
2014	7	9	9	0	59	0.3	4.6	0.9	94.2	98.9764	84.6813
2014	7	9	9	10	59	0.3	4.6	0.9	96.3	98.9764	84.3723
2014	7	9	9	20	59	0.3	4.6	0.86	98.6	98.9108	79.6817
2014	7	9	9	30	59	0.3	4.6	0.89	97	98.9108	83.3878
2014	7	9	9	40	59	0.3	4.6	0.87	95.6	98.9108	81.8436
2014	7	9	9	50	59	0.3	4.6	0.87	95	98.9108	81.8436
2014	7	9	10	0	59	0.3	4.6	0.9	98	98.9108	84.0055
2014	7	9	10	10	59	0.3	4.6	0.89	98	98.9108	83.0789
2014	7	9	10	20	59	0.3	4.6	0.89	97.2	98.9108	82.7701
2014	7	9	10	30	59	0.3	4.6	0.9	99	98.9108	84.0055
2014	7	9	10	40	59	0.3	4.6	0.91	97.5	98.9108	84.932
2014	7	9	10	50	59	0.3	4.6	0.88	97.3	98.9108	82.1524
2014	7	9	11	0	59	0.3	4.6	0.91	95.2	98.9108	84.9319
2014	7	9	11	10	59	0.3	4.6	0.88	99.9	98.9108	81.5347
2014	7	9	11	20	59	0.3	4.6	0.89	98	98.9108	83.3877
2014	7	9	11	30	59	0.3	4.6	0.91	95.8	98.9108	85.5496
2014	7	9	11	40	59	0.3	4.6	0.87	98	98.9108	81.2258
2014	7	9	11	50	59	0.3	4.6	0.9	103.6	98.9108	82.77
2014	7	9	12	0	59	0.3	4.6	0.9	98.8	98.8452	83.639
2014	7	9	12	10	59	0.3	4.6	0.87	100.2	98.8452	80.5527
2014	7	9	12	20	59	0.3	4.6	0.88	99.7	98.8452	81.1699
2014	7	9	12	30	59	0.3	4.6	0.91	98.7	98.7795	84.1983
2014	7	9	12	40	59	0.3	4.6	0.91	95.2	98.7795	84.8152
2014	7	9	12	50	59	0.3	4.6	0.96	98.7	98.7795	88.8246
2014	7	9	13	0	59	0.3	4.6	0.94	100.3	98.7139	86.9143
2014	7	9	13	10	59	0.3	4.6	0.93	100	98.7139	85.9896
2014	7	9	13	20	59	0.3	4.6	0.92	100.4	98.7139	85.3732
2014	7	9	13	30	59	0.3	4.6	0.89	98.5	98.7795	82.9646
2014	7	9	13	40	59	0.3	4.6	0.92	100.3	98.7139	85.0649
2014	7	9	13	50	59	0.3	4.6	0.83	104.4	98.7795	75.5625
2014	7	9	14	0	59	0.3	4.6	0.9	94	98.7795	84.815
2014	7	9	14	10	59	0.3	4.6	0.91	97.3	98.7139	84.7567
2014	7	9	14	20	59	0.3	4.6	0.88	97	98.7139	82.2911
2014	7	9	14	30	59	0.3	4.6	0.86	94.2	98.6483	80.0785
2014	7	9	14	40	59	0.3	4.6	0.87	96.2	98.7139	81.6746
2014	7	9	14	50	59	0.3	4.6	0.88	93.2	98.7139	82.291
2014	7	9	15	0	59	0.3	4.6	0.85	93.3	98.7139	79.8254

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	15	10	59	0.3	4.6	0.86	94.8	98.6483	80.3865
2014	7	9	15	20	59	0.3	4.6	0.86	95.3	98.6483	80.3865
2014	7	9	15	30	59	0.3	4.6	0.88	94.9	98.6483	82.2344
2014	7	9	15	40	59	0.3	4.6	0.86	95.5	98.5827	80.3311
2014	7	9	15	50	59	0.3	4.6	0.9	94	98.5827	84.0245
2014	7	9	16	0	59	0.3	4.6	0.89	95.3	98.5827	82.7934
2014	7	9	16	10	59	0.3	4.6	0.88	97.1	98.5827	81.87
2014	7	9	16	20	59	0.3	4.6	0.88	96.4	98.5827	82.4856
2014	7	9	16	30	59	0.3	4.6	0.89	95.3	98.5827	83.1011
2014	7	9	16	40	59	0.3	4.6	0.9	97.5	98.5827	83.7167
2014	7	9	16	50	59	0.3	4.6	0.89	97.6	98.5827	82.7933
2014	7	9	17	0	59	0.3	4.6	0.89	96.3	98.5827	83.4089
2014	7	9	17	10	59	0.3	4.6	0.89	95.3	98.5827	83.1011
2014	7	9	17	20	59	0.3	4.6	0.86	95.2	98.5827	80.6388
2014	7	9	17	30	59	0.3	4.6	0.89	95.3	98.5827	83.4089
2014	7	9	17	40	59	0.3	4.6	0.86	96.6	98.5827	80.331
2014	7	9	17	50	59	0.3	4.6	0.86	92.8	98.5171	80.5833
2014	7	9	18	0	59	0.3	4.6	0.87	94.8	98.5827	80.9466
2014	7	9	18	10	59	0.3	4.6	0.91	94.6	98.5827	84.9477
2014	7	9	18	20	59	0.3	4.6	0.9	94.4	98.5827	83.7166
2014	7	9	18	30	59	0.3	4.6	0.89	94.7	98.5827	83.1011
2014	7	9	18	40	59	0.3	4.6	0.89	94.9	98.5827	82.7933
2014	7	9	18	50	59	0.3	4.6	0.9	94.4	98.5827	83.7166
2014	7	9	19	0	59	0.3	4.6	0.87	95.4	98.5827	81.5621
2014	7	9	19	10	59	0.3	4.6	0.9	95.2	98.5827	84.0244
2014	7	9	19	20	59	0.3	4.6	0.89	95.3	98.5827	83.4088
2014	7	9	19	30	59	0.3	4.6	0.93	96.9	98.5827	86.7944
2014	7	9	19	40	59	0.3	4.6	0.83	93.6	98.5827	77.5609
2014	7	9	19	50	59	0.3	4.6	0.87	95.8	98.5827	81.5621
2014	7	9	20	0	59	0.3	4.6	0.85	95.8	98.5827	79.0998
2014	7	9	20	10	59	0.3	4.6	0.88	93.6	98.5827	82.4854
2014	7	9	20	20	59	0.3	4.6	0.88	96.4	98.5827	81.8699
2014	7	9	20	30	59	0.3	4.6	0.87	97.4	98.5827	80.9465
2014	7	9	20	40	59	0.3	4.6	0.87	95.8	98.5827	81.5621
2014	7	9	20	50	59	0.3	4.6	0.87	95.4	98.6483	81.3102
2014	7	9	21	0	59	0.3	4.6	0.86	95	98.6483	80.3863
2014	7	9	21	10	59	0.3	4.6	0.88	96.6	98.6483	81.9262
2014	7	9	21	20	59	0.3	4.6	0.88	96.4	98.6483	81.9262
2014	7	9	21	30	59	0.3	4.6	0.85	93.7	98.6483	80.0783
2014	7	9	21	40	59	0.3	4.6	0.88	94.3	98.6483	82.8502
2014	7	9	21	50	59	0.3	4.6	0.88	94.7	98.6483	81.9262
2014	7	9	22	0	59	0.3	4.6	0.88	94.9	98.6483	81.9262
2014	7	9	22	10	59	0.3	4.6	0.87	96.9	98.6483	81.0022
2014	7	9	22	20	59	0.3	4.6	0.85	95.6	98.6483	79.1543
2014	7	9	22	30	59	0.3	4.6	0.9	95.6	98.6483	84.0822
2014	7	9	22	40	59	0.3	4.6	0.9	95.9	98.6483	83.7742

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	22	50	59	0.3	4.6	0.87	95.8	98.6483	81.6182
2014	7	9	23	0	59	0.3	4.6	0.9	94.2	98.7139	84.1401
2014	7	9	23	10	59	0.3	4.6	0.86	94.4	98.7139	80.4416
2014	7	9	23	20	59	0.3	4.6	0.88	94.9	98.7139	82.2908
2014	7	9	23	30	59	0.3	4.6	0.89	94	98.7139	83.2155
2014	7	9	23	40	59	0.3	4.6	0.87	96.3	98.7139	81.058
2014	7	9	23	50	59	0.3	4.6	0.85	95.8	98.7139	79.2088
2014	7	10	0	0	59	0.3	4.6	0.88	94.9	98.7795	82.3475
2014	7	10	0	10	59	0.3	4.6	0.89	95.5	98.7795	82.9643
2014	7	10	0	20	59	0.3	4.6	0.88	96	98.7795	82.3475
2014	7	10	0	30	59	0.3	4.6	0.88	93.2	98.8452	82.7127
2014	7	10	0	40	59	0.3	4.6	0.87	95.4	98.8452	81.7869
2014	7	10	0	50	59	0.3	4.6	0.88	94.9	98.8452	82.0955
2014	7	10	1	0	59	0.3	4.6	0.87	93.2	98.8452	81.7869
2014	7	10	1	10	59	0.3	4.6	0.89	94	98.8452	83.9473
2014	7	10	1	20	59	0.3	4.6	0.89	95.3	98.9108	83.3873
2014	7	10	1	30	59	0.3	4.6	0.88	95.4	98.9108	82.1519
2014	7	10	1	40	59	0.3	4.6	0.86	93.5	98.9108	80.9166
2014	7	10	1	50	59	0.3	4.6	0.88	95.6	98.9108	82.4608
2014	7	10	2	0	59	0.3	4.6	0.88	94.3	98.9108	83.0785
2014	7	10	2	10	59	0.3	4.6	0.88	94.9	98.9764	82.5174
2014	7	10	2	20	59	0.3	4.6	0.87	93.9	98.9764	81.5903
2014	7	10	2	30	59	0.3	4.6	0.88	95.6	98.9108	82.4609
2014	7	10	2	40	59	0.3	4.6	0.87	94.8	98.9764	81.2813
2014	7	10	2	50	59	0.3	4.6	0.89	93.6	98.9764	83.7537
2014	7	10	3	0	59	0.3	4.6	0.91	97.5	98.9764	84.6809
2014	7	10	3	10	59	0.3	4.6	0.89	95.3	98.9764	83.7537
2014	7	10	3	20	59	0.3	4.6	0.89	94	98.9764	83.4447
2014	7	10	3	30	59	0.3	4.6	0.89	94.6	98.9764	83.7538
2014	7	10	3	40	59	0.3	4.6	0.88	95.3	98.9764	82.5176
2014	7	10	3	50	59	0.3	4.6	0.9	95.5	98.9764	84.0629
2014	7	10	4	0	59	0.3	4.6	0.9	96.3	98.9764	84.3719
2014	7	10	4	10	59	0.3	4.6	0.87	95.4	98.9764	81.8995
2014	7	10	4	20	59	0.3	4.6	0.88	95.8	98.9764	82.8267
2014	7	10	4	30	59	0.3	4.6	0.89	95.3	98.9764	83.7539
2014	7	10	4	40	59	0.3	4.6	0.88	95.6	98.9764	82.5177
2014	7	10	4	50	59	0.3	4.6	0.87	93.7	98.9764	81.8996
2014	7	10	5	0	59	0.3	4.6	0.88	94.3	98.9764	82.5177
2014	7	10	5	10	59	0.3	4.6	0.89	94.6	98.9764	83.7539
2014	7	10	5	20	59	0.3	4.6	0.86	95.5	98.9764	80.9724
2014	7	10	5	30	59	0.3	4.6	0.89	94.2	99.042	83.5021
2014	7	10	5	40	59	0.3	4.6	0.86	95.1	99.042	80.4095
2014	7	10	5	50	59	0.3	4.6	0.88	93.4	99.042	82.5744
2014	7	10	6	0	59	0.3	4.6	0.91	93.5	99.042	85.9763
2014	7	10	6	10	59	0.3	4.6	0.84	94.5	99.042	78.8632
2014	7	10	6	20	59	0.3	4.6	0.86	93	99.042	81.3373

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	6	30	59	0.3	4.6	0.87	95.2	99.042	81.3373
2014	7	10	6	40	59	0.3	4.6	0.88	96	99.042	82.5744
2014	7	10	6	50	59	0.3	4.6	0.87	95.4	99.042	81.3374
2014	7	10	7	0	59	0.3	4.6	0.89	94.2	99.042	83.5022
2014	7	10	7	10	59	0.3	4.6	0.87	95.6	99.042	81.9559
2014	7	10	7	20	59	0.3	4.6	0.87	96.5	99.042	81.6466
2014	7	10	7	30	59	0.3	4.6	0.9	94.8	99.042	84.7393
2014	7	10	7	40	59	0.3	4.6	0.87	94.5	99.042	81.9559
2014	7	10	7	50	59	0.3	4.6	0.89	94.7	99.042	83.5022
2014	7	10	8	0	59	0.3	4.6	0.89	94.9	99.042	83.193
2014	7	10	8	10	59	0.3	4.6	0.86	95.7	99.042	80.4096
2014	7	10	8	20	59	0.3	4.6	0.9	94.4	99.042	84.1208
2014	7	10	8	30	59	0.3	4.6	0.89	94.5	99.042	83.1929
2014	7	10	8	40	59	0.3	4.6	0.86	96.6	99.042	80.4095
2014	7	10	8	50	59	0.3	4.6	0.9	96.3	99.042	84.1208
2014	7	10	9	0	59	0.3	4.6	0.88	96.9	99.042	82.2651
2014	7	10	9	10	59	0.3	4.6	0.91	92.9	99.042	85.9763
2014	7	10	9	20	59	0.3	4.6	0.89	96.3	99.042	83.8114
2014	7	10	9	30	59	0.3	4.6	0.89	97	99.042	83.5022
2014	7	10	9	40	59	0.3	4.6	0.93	95.9	99.042	86.9041
2014	7	10	9	50	59	0.3	4.6	0.93	98.3	99.042	86.5948
2014	7	10	10	0	59	0.3	4.6	0.86	95.5	99.042	81.028
2014	7	10	10	10	59	0.3	4.6	0.88	97.5	99.042	82.265
2014	7	10	10	20	59	0.3	4.6	0.87	95.4	99.042	81.3372
2014	7	10	10	30	59	0.3	4.6	0.92	96.8	99.042	85.667
2014	7	10	10	40	59	0.3	4.6	0.88	95.1	99.042	82.8835
2014	7	10	10	50	59	0.3	4.6	0.89	94.9	99.042	83.5021
2014	7	10	11	0	59	0.3	4.6	0.92	96.7	99.042	86.2854
2014	7	10	11	10	59	0.3	4.6	0.89	98	98.9764	83.1357
2014	7	10	11	20	59	0.3	4.6	0.89	97.2	99.042	83.1928
2014	7	10	11	30	59	0.3	4.6	0.9	99.3	98.9764	83.4448
2014	7	10	11	40	59	0.3	4.6	0.88	99	98.9764	81.5904
2014	7	10	11	50	59	0.3	4.6	0.9	98.2	98.9764	83.7538
2014	7	10	12	0	59	0.3	4.6	0.91	97.9	98.9764	84.681
2014	7	10	12	10	59	0.3	4.6	0.87	95.4	98.9764	81.8994
2014	7	10	12	20	59	0.3	4.6	0.87	99.6	98.9764	80.3541
2014	7	10	12	30	59	0.3	4.6	0.89	99.9	98.9108	82.7697
2014	7	10	12	40	59	0.3	4.6	0.88	96.9	98.9108	81.8432
2014	7	10	12	50	59	0.3	4.6	0.87	100.6	98.9764	80.6632
2014	7	10	13	0	59	0.3	4.6	0.85	101.6	98.9108	78.4459
2014	7	10	13	10	59	0.3	4.6	0.84	94.7	98.9108	79.0636
2014	7	10	13	20	59	0.3	4.6	0.89	101.6	98.9108	82.4609
2014	7	10	13	30	59	0.3	4.6	0.83	97.5	98.8452	77.7748
2014	7	10	13	40	59	0.3	4.6	0.86	97.4	98.8452	80.5525
2014	7	10	13	50	59	0.3	4.6	0.87	96.9	98.7795	81.114
2014	7	10	14	0	59	0.3	4.6	0.86	97.4	98.8452	80.5524

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	14	10	59	0.3	4.6	0.87	102.2	98.7795	79.8803
2014	7	10	14	20	59	0.3	4.6	0.83	98.2	98.8452	77.1575
2014	7	10	14	30	59	0.3	4.6	0.85	96.2	98.7139	79.209
2014	7	10	14	40	59	0.3	4.6	0.87	100.4	98.8452	80.8611
2014	7	10	14	50	59	0.3	4.6	0.85	97.3	98.7795	79.2635
2014	7	10	15	0	59	0.3	4.6	0.84	99.2	98.7795	78.0299
2014	7	10	15	10	59	0.3	4.6	0.87	97.4	98.7795	81.1141
2014	7	10	15	20	59	0.3	4.6	0.86	98.3	98.8452	79.9353
2014	7	10	15	30	59	0.3	4.6	0.87	101.7	98.7795	80.4972
2014	7	10	15	40	59	0.3	4.6	0.88	97.1	98.8452	81.7871
2014	7	10	15	50	59	0.3	4.6	0.89	97	98.7795	82.9645
2014	7	10	16	0	59	0.3	4.6	0.9	99.5	98.7795	83.273
2014	7	10	16	10	59	0.3	4.6	0.91	101.4	98.7139	84.1403
2014	7	10	16	20	59	0.3	4.6	0.9	96.9	98.7795	83.8898
2014	7	10	16	30	59	0.3	4.6	0.89	99.1	98.7139	82.2911
2014	7	10	16	40	59	0.3	4.6	0.87	96.5	98.7139	81.6747
2014	7	10	16	50	59	0.3	4.6	0.86	97.2	98.7139	80.4418
2014	7	10	17	0	59	0.3	4.6	0.89	100.6	98.7139	82.5993
2014	7	10	17	10	59	0.3	4.6	0.89	96.8	98.7795	83.273
2014	7	10	17	20	59	0.3	4.6	0.91	98.1	98.7139	84.7567
2014	7	10	17	30	59	0.3	4.6	0.88	97.5	98.7139	82.2911
2014	7	10	17	40	59	0.3	4.6	0.9	98.2	98.6483	83.4665
2014	7	10	17	50	59	0.3	4.6	0.9	99.2	98.6483	83.4665
2014	7	10	18	0	59	0.3	4.6	0.9	98.2	98.6483	83.4665
2014	7	10	18	10	59	0.3	4.6	0.87	95.6	98.6483	81.6185
2014	7	10	18	20	59	0.3	4.6	0.9	99	98.5827	83.7168
2014	7	10	18	30	59	0.3	4.6	0.89	99.5	98.5827	82.4857
2014	7	10	18	40	59	0.3	4.6	0.9	95.6	98.5827	84.0246
2014	7	10	18	50	59	0.3	4.6	0.89	97.8	98.5827	83.1012
2014	7	10	19	0	59	0.3	4.6	0.87	96.7	98.6483	80.6945
2014	7	10	19	10	59	0.3	4.6	0.91	100.6	98.6483	83.7745
2014	7	10	19	20	59	0.3	4.6	0.88	96.9	98.5827	81.8701
2014	7	10	19	30	59	0.3	4.6	0.88	100.1	98.5827	81.5623
2014	7	10	19	40	59	0.3	4.6	0.89	96.8	98.5827	82.4857
2014	7	10	19	50	59	0.3	4.6	0.89	95.3	98.5827	83.1013
2014	7	10	20	0	59	0.3	4.6	0.91	98.9	98.5827	84.3324
2014	7	10	20	10	59	0.3	4.6	0.9	97.3	98.6483	84.0825
2014	7	10	20	20	59	0.3	4.6	0.88	97.5	98.6483	82.2345
2014	7	10	20	30	59	0.3	4.6	0.87	96.7	98.6483	80.6946
2014	7	10	20	40	59	0.3	4.6	0.85	91.6	98.7795	79.572
2014	7	10	20	50	59	0.3	4.6	0.87	94.7	98.7139	81.6747
2014	7	10	21	0	59	0.3	4.6	0.89	96.3	98.6483	83.1585
2014	7	10	21	10	59	0.3	4.6	0.88	95.2	98.6483	81.9266
2014	7	10	21	20	59	0.3	4.6	0.86	94.4	98.7795	80.4973
2014	7	10	21	30	59	0.3	4.6	0.89	95.5	98.7139	82.9076
2014	7	10	21	40	59	0.3	4.6	0.87	94.8	98.7795	81.1141

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	21	50	59	0.3	4.6	0.88	95.8	98.7139	82.5994
2014	7	10	22	0	59	0.3	4.6	0.88	96.2	98.6483	82.5426
2014	7	10	22	10	59	0.3	4.6	0.87	96.5	98.6483	81.0026
2014	7	10	22	20	59	0.3	4.6	0.89	97.2	98.7139	83.2158
2014	7	10	22	30	59	0.3	4.6	0.89	96.1	98.7139	83.2158
2014	7	10	22	40	59	0.3	4.6	0.86	96.4	98.7139	80.1337
2014	7	10	22	50	59	0.3	4.6	0.89	94.5	98.7139	82.9076
2014	7	10	23	0	59	0.3	4.6	0.89	97	98.7139	82.9076
2014	7	10	23	10	59	0.3	4.6	0.89	94.9	98.7795	82.9647
2014	7	10	23	20	59	0.3	4.6	0.89	97.2	98.7139	82.9076
2014	7	10	23	30	59	0.3	4.6	0.89	96.5	98.7795	83.2731
2014	7	10	23	40	59	0.3	4.6	0.9	94.2	98.7795	84.8152
2014	7	10	23	50	59	0.3	4.6	0.91	95	98.8452	84.8735
2014	7	11	0	0	59	0.3	4.6	0.91	96.2	98.8452	84.8735
2014	7	11	0	10	59	0.3	4.6	0.89	93.6	98.8452	83.3304
2014	7	11	0	20	59	0.3	4.6	0.88	94.3	98.8452	82.7131
2014	7	11	0	30	59	0.3	4.6	0.87	96.5	98.8452	81.17
2014	7	11	0	40	59	0.3	4.6	0.9	95.8	98.8452	84.5649
2014	7	11	0	50	59	0.3	4.6	0.87	97.6	98.8452	81.17
2014	7	11	1	0	59	0.3	4.6	0.85	94	98.8452	79.3182
2014	7	11	1	10	59	0.3	4.6	0.89	95.1	98.9108	83.6965
2014	7	11	1	20	59	0.3	4.6	0.9	96.5	98.9108	84.0053
2014	7	11	1	30	59	0.3	4.6	0.92	94.9	98.9108	85.8584
2014	7	11	1	40	59	0.3	4.6	0.86	94.8	98.9108	80.6081
2014	7	11	1	50	59	0.3	4.6	0.87	95.6	98.9108	81.5346
2014	7	11	2	0	59	0.3	4.6	0.87	96.1	98.9764	81.5906
2014	7	11	2	10	59	0.3	4.6	0.89	95.7	98.9764	83.754
2014	7	11	2	20	59	0.3	4.6	0.9	96.1	98.9764	84.3721
2014	7	11	2	30	59	0.3	4.6	0.88	95.3	99.042	82.8837
2014	7	11	2	40	59	0.3	4.6	0.9	94.4	99.042	84.1208
2014	7	11	2	50	59	0.3	4.6	0.85	95.1	99.042	80.1003
2014	7	11	3	0	59	0.3	4.6	0.86	94.4	99.042	81.0281
2014	7	11	3	10	59	0.3	4.6	0.86	93.9	99.042	81.0281
2014	7	11	3	20	59	0.3	4.6	0.89	95.7	99.042	83.5023
2014	7	11	3	30	59	0.3	4.6	0.86	95.1	99.042	80.4096
2014	7	11	3	40	59	0.3	4.6	0.87	95	99.1076	81.7027
2014	7	11	3	50	59	0.3	4.6	0.87	93.3	99.1076	81.7027
2014	7	11	4	0	59	0.3	4.6	0.88	94.7	99.1076	82.9406
2014	7	11	4	10	59	0.3	4.6	0.88	94.3	99.1076	83.2501
2014	7	11	4	20	59	0.3	4.6	0.86	95.9	99.1076	80.7743
2014	7	11	4	30	59	0.3	4.6	0.87	95.8	99.1076	81.7027
2014	7	11	4	40	59	0.3	4.6	0.9	95.2	99.1076	84.7975
2014	7	11	4	50	59	0.3	4.6	0.88	94.3	99.1076	83.2502
2014	7	11	5	0	59	0.3	4.6	0.89	93.6	99.1076	83.8691
2014	7	11	5	10	59	0.3	4.6	0.87	94.3	99.1076	81.7028
2014	7	11	5	20	59	0.3	4.6	0.88	95.3	99.1076	82.9407

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	5	30	59	0.3	4.6	0.9	96.2	99.1076	84.7976
2014	7	11	5	40	59	0.3	4.6	0.86	94.6	99.1076	80.4649
2014	7	11	5	50	59	0.3	4.6	0.88	95.3	99.1076	82.9408
2014	7	11	6	0	59	0.3	4.6	0.88	96.4	99.1076	82.9408
2014	7	11	6	10	59	0.3	4.6	0.86	94	99.1076	80.4649
2014	7	11	6	20	59	0.3	4.6	0.88	94.7	99.1076	82.3218
2014	7	11	6	30	59	0.3	4.6	0.9	95	99.1076	84.7977
2014	7	11	6	40	59	0.3	4.6	0.87	93.3	99.1076	81.7029
2014	7	11	6	50	59	0.3	4.6	0.88	95.8	99.1076	82.9408
2014	7	11	7	0	59	0.3	4.6	0.87	94.8	99.1076	81.3934
2014	7	11	7	10	59	0.3	4.6	0.88	93.4	99.1076	82.6313
2014	7	11	7	20	59	0.3	4.6	0.9	95.8	99.1076	84.7977
2014	7	11	7	30	59	0.3	4.6	0.9	95.9	99.1076	84.1787
2014	7	11	7	40	59	0.3	4.6	0.88	96.7	99.1076	82.0124
2014	7	11	7	50	59	0.3	4.6	0.87	96.3	99.1076	81.7029
2014	7	11	8	0	59	0.3	4.6	0.9	96.9	99.1076	84.4882
2014	7	11	8	10	59	0.3	4.6	0.91	98.3	99.1076	84.4882
2014	7	11	8	20	59	0.3	4.6	0.9	97.1	99.1076	84.1787
2014	7	11	8	30	59	0.3	4.6	0.9	97.2	99.1076	83.8693
2014	7	11	8	40	59	0.3	4.6	0.9	98.8	99.1076	83.8693
2014	7	11	8	50	59	0.3	4.6	0.88	95.1	99.1076	82.9408
2014	7	11	9	0	59	0.3	4.6	0.88	97.5	99.1076	82.3219
2014	7	11	9	10	59	0.3	4.6	0.88	95.5	99.1076	82.9408
2014	7	11	9	20	59	0.3	4.6	0.89	95.7	99.1076	83.2503
2014	7	11	9	30	59	0.3	4.6	0.9	96.7	99.1076	83.8692
2014	7	11	9	40	59	0.3	4.6	0.92	96.6	99.1076	86.0356
2014	7	11	9	50	59	0.3	4.6	0.89	97.8	99.1076	83.2502
2014	7	11	10	0	59	0.3	4.6	0.87	98.6	99.1076	81.3933
2014	7	11	10	10	59	0.3	4.6	0.89	98.5	99.1076	82.9407
2014	7	11	10	20	59	0.3	4.6	0.89	98.3	99.1076	82.9407
2014	7	11	10	30	59	0.3	4.6	0.89	98	99.1076	83.5597
2014	7	11	10	40	59	0.3	4.6	0.9	97.9	99.1076	84.4881
2014	7	11	10	50	59	0.3	4.6	0.91	96.6	99.1076	85.4165
2014	7	11	11	0	59	0.3	4.6	0.88	97.3	99.042	82.2653
2014	7	11	11	10	59	0.3	4.6	0.87	96.1	99.1076	81.7027
2014	7	11	11	20	59	0.3	4.6	0.88	98.2	99.1076	81.7027
2014	7	11	11	30	59	0.3	4.6	0.91	101.2	99.042	84.4302
2014	7	11	11	40	59	0.3	4.6	0.87	98	99.1076	81.3932
2014	7	11	11	50	59	0.3	4.6	0.85	101.3	99.042	78.8633
2014	7	11	12	0	59	0.3	4.6	0.86	100.8	99.1076	79.8458
2014	7	11	12	10	59	0.3	4.6	0.89	98.5	99.042	82.8838
2014	7	11	12	20	59	0.3	4.6	0.86	100.6	99.1076	79.5363
2014	7	11	12	30	59	0.3	4.6	0.88	97.9	99.042	82.2652
2014	7	11	12	40	59	0.3	4.6	0.89	97.4	99.042	83.193
2014	7	11	12	50	59	0.3	4.6	0.89	101.5	99.042	82.2652
2014	7	11	13	0	59	0.3	4.6	0.86	100.7	99.042	80.1003

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	13	10	59	0.3	4.6	0.88	102.1	99.042	81.0281
2014	7	11	13	20	59	0.3	4.6	0.86	99	99.042	80.4095
2014	7	11	13	30	59	0.3	4.6	0.88	96.4	99.042	82.8837
2014	7	11	13	40	59	0.3	4.6	0.9	96	99.042	84.7392
2014	7	11	13	50	59	0.3	4.6	0.86	100.3	98.9764	79.7362
2014	7	11	14	0	59	0.3	4.6	0.88	100.8	98.9764	80.9724
2014	7	11	14	10	59	0.3	4.6	0.86	96.6	99.042	80.4095
2014	7	11	14	20	59	0.3	4.6	0.89	101.5	98.9764	82.2087
2014	7	11	14	30	59	0.3	4.6	0.89	100.4	98.9764	82.2087
2014	7	11	14	40	59	0.3	4.6	0.88	98.6	98.9764	81.5905
2014	7	11	14	50	59	0.3	4.6	0.89	98.5	98.9764	83.1358
2014	7	11	15	0	59	0.3	4.6	0.86	100.6	98.9764	79.4271
2014	7	11	15	10	59	0.3	4.6	0.85	96.2	98.9108	79.9903
2014	7	11	15	20	59	0.3	4.6	0.88	98.6	98.9108	81.5346
2014	7	11	15	30	59	0.3	4.6	0.88	99.9	98.9108	81.5346
2014	7	11	15	40	59	0.3	4.6	0.89	100.2	98.9764	82.5177
2014	7	11	15	50	59	0.3	4.6	0.88	98.8	98.9108	81.5346
2014	7	11	16	0	59	0.3	4.6	0.89	96.5	98.9108	83.3876
2014	7	11	16	10	59	0.3	4.6	0.9	99.7	98.9108	83.0788
2014	7	11	16	20	59	0.3	4.6	0.86	100.6	98.9108	79.3727
2014	7	11	16	30	59	0.3	4.6	0.89	97.8	98.9108	83.3876
2014	7	11	16	40	59	0.3	4.6	0.9	98.8	98.8452	83.639
2014	7	11	16	50	59	0.3	4.6	0.87	95.6	98.9108	81.8434
2014	7	11	17	0	59	0.3	4.6	0.87	98.4	98.8452	81.17
2014	7	11	17	10	59	0.3	4.6	0.9	96.5	98.8452	83.9476
2014	7	11	17	20	59	0.3	4.6	0.91	95.4	98.8452	85.4908
2014	7	11	17	30	59	0.3	4.6	0.88	98.3	98.8452	82.0959
2014	7	11	17	40	59	0.3	4.6	0.87	100	98.8452	80.8613
2014	7	11	17	50	59	0.3	4.6	0.89	96.8	98.9108	83.3876
2014	7	11	18	0	59	0.3	4.6	0.86	97.7	98.8452	80.2441
2014	7	11	18	10	59	0.3	4.6	0.87	97.4	98.8452	81.17
2014	7	11	18	20	59	0.3	4.6	0.88	97.7	98.8452	81.7872
2014	7	11	18	30	59	0.3	4.6	0.88	99.7	98.8452	81.4786
2014	7	11	18	40	59	0.3	4.6	0.89	98.5	98.8452	82.7131
2014	7	11	18	50	59	0.3	4.6	0.88	97.1	98.8452	81.7872
2014	7	11	19	0	59	0.3	4.6	0.91	97.3	98.8452	84.5649
2014	7	11	19	10	59	0.3	4.6	0.9	98.4	98.8452	83.3304
2014	7	11	19	20	59	0.3	4.6	0.89	96.8	98.7139	82.5995
2014	7	11	19	30	59	0.3	4.6	0.88	96.2	98.8452	82.0959
2014	7	11	19	40	59	0.3	4.6	0.87	98.4	98.9108	81.2257
2014	7	11	19	50	59	0.3	4.6	0.9	95.2	98.9108	84.623
2014	7	11	20	0	59	0.3	4.6	0.91	95.6	98.9108	85.2407
2014	7	11	20	10	59	0.3	4.6	0.89	97.2	98.9108	83.3876
2014	7	11	20	20	59	0.3	4.6	0.91	97	98.9108	84.9318
2014	7	11	20	30	59	0.3	4.6	0.88	95.6	98.9108	82.4611
2014	7	11	20	40	59	0.3	4.6	0.9	94	98.9108	84.9318

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	20	50	59	0.3	4.6	0.9	96.9	98.9108	84.0053
2014	7	11	21	0	59	0.3	4.6	0.89	97.2	98.9108	83.3876
2014	7	11	21	10	59	0.3	4.6	0.87	95.2	98.9108	81.8434
2014	7	11	21	20	59	0.3	4.6	0.87	95	98.9764	81.5906
2014	7	11	21	30	59	0.3	4.6	0.89	95.9	98.9764	83.1358
2014	7	11	21	40	59	0.3	4.6	0.86	94.6	98.9764	80.3543
2014	7	11	21	50	59	0.3	4.6	0.89	96.4	98.9764	83.1358
2014	7	11	22	0	59	0.3	4.6	0.92	95.7	98.9764	86.2264
2014	7	11	22	10	59	0.3	4.6	0.89	97.2	98.9764	83.4449
2014	7	11	22	20	59	0.3	4.6	0.87	94.3	98.9764	81.2815
2014	7	11	22	30	59	0.3	4.6	0.87	97.2	98.9764	80.9725
2014	7	11	22	40	59	0.3	4.6	0.87	95.8	98.9764	81.5906
2014	7	11	22	50	59	0.3	4.6	0.86	94.4	98.9764	80.9725
2014	7	11	23	0	59	0.3	4.6	0.86	96.6	98.9764	80.3544
2014	7	11	23	10	59	0.3	4.6	0.86	95.7	98.9764	80.9725
2014	7	11	23	20	59	0.3	4.6	0.86	94.8	98.9764	80.6635
2014	7	11	23	30	59	0.3	4.6	0.89	96.3	98.9764	83.445
2014	7	11	23	40	59	0.3	4.6	0.86	96.1	98.9764	80.9725
2014	7	11	23	50	59	0.3	4.6	0.89	94.2	98.9764	83.754
2014	7	12	0	0	59	0.3	4.6	0.87	95	99.042	81.9559
2014	7	12	0	10	59	0.3	4.6	0.86	96.3	99.042	80.7189
2014	7	12	0	20	59	0.3	4.6	0.87	95.6	99.042	81.9559
2014	7	12	0	30	59	0.3	4.6	0.85	95.3	99.042	80.1003
2014	7	12	0	40	59	0.3	4.6	0.88	96.4	99.042	82.5745
2014	7	12	0	50	59	0.3	4.6	0.88	94.3	99.042	82.8838
2014	7	12	1	0	59	0.3	4.6	0.88	96	99.042	82.5745
2014	7	12	1	10	59	0.3	4.6	0.86	96.6	99.042	80.1004
2014	7	12	1	20	59	0.3	4.6	0.9	95	99.042	84.4301
2014	7	12	1	30	59	0.3	4.6	0.87	95.2	99.042	81.6468
2014	7	12	1	40	59	0.3	4.6	0.85	96.2	99.042	79.4819
2014	7	12	1	50	59	0.3	4.6	0.89	96.8	99.042	82.8839
2014	7	12	2	0	59	0.3	4.6	0.88	95.4	99.042	82.2653
2014	7	12	2	10	59	0.3	4.6	0.89	96.1	99.042	83.8117
2014	7	12	2	20	59	0.3	4.6	0.85	94.9	99.042	79.7912
2014	7	12	2	30	59	0.3	4.6	0.89	94.7	99.042	83.1932
2014	7	12	2	40	59	0.3	4.6	0.88	96	99.042	82.8839
2014	7	12	2	50	59	0.3	4.6	0.88	96	99.042	82.5747
2014	7	12	3	0	59	0.3	4.6	0.88	96.4	99.042	82.884
2014	7	12	3	10	59	0.3	4.6	0.91	96.4	99.042	85.0489
2014	7	12	3	20	59	0.3	4.6	0.89	95.7	99.042	83.8118
2014	7	12	3	30	59	0.3	4.6	0.87	94.1	99.042	81.647
2014	7	12	3	40	59	0.3	4.6	0.88	94.7	99.042	82.884
2014	7	12	3	50	59	0.3	4.6	0.84	95.4	99.042	78.5543
2014	7	12	4	0	59	0.3	4.6	0.9	95.2	99.042	84.4304
2014	7	12	4	10	59	0.3	4.6	0.88	94.7	99.042	82.8841
2014	7	12	4	20	59	0.3	4.6	0.88	94.3	99.042	82.8841

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	4	30	59	0.3	4.6	0.86	95.1	99.042	80.41
2014	7	12	4	40	59	0.3	4.6	0.86	92.2	99.042	81.3378
2014	7	12	4	50	59	0.3	4.6	0.84	93.8	99.042	78.5544
2014	7	12	5	0	59	0.3	4.6	0.89	95.1	99.042	83.1935
2014	7	12	5	10	59	0.3	4.6	0.89	95.3	99.042	83.812
2014	7	12	5	20	59	0.3	4.6	0.9	93.8	99.042	84.4306
2014	7	12	5	30	59	0.3	4.6	0.89	94	99.042	83.8121
2014	7	12	5	40	59	0.3	4.6	0.88	96.2	99.042	82.575
2014	7	12	5	50	59	0.3	4.6	0.89	93.2	99.042	84.1214
2014	7	12	6	0	59	0.3	4.6	0.88	95.4	99.042	82.2658
2014	7	12	6	10	59	0.3	4.6	0.88	93.2	99.1076	82.9411
2014	7	12	6	20	59	0.3	4.6	0.88	94.3	99.1076	82.9412
2014	7	12	6	30	59	0.3	4.6	0.85	94.9	99.1076	80.1558
2014	7	12	6	40	59	0.3	4.6	0.89	96.6	99.1076	82.9412
2014	7	12	6	50	59	0.3	4.6	0.88	96	99.1076	82.3222
2014	7	12	7	0	59	0.3	4.6	0.86	96.6	99.1076	80.7748
2014	7	12	7	10	59	0.3	4.6	0.87	95.2	99.1076	81.3938
2014	7	12	7	20	59	0.3	4.6	0.89	96.2	99.1076	83.2507
2014	7	12	7	30	59	0.3	4.6	0.9	96.3	99.1076	84.1792
2014	7	12	7	40	59	0.3	4.6	0.87	95.8	99.1076	81.7033
2014	7	12	7	50	59	0.3	4.6	0.87	96.5	99.1076	81.7033
2014	7	12	8	0	59	0.3	4.6	0.86	96.6	99.1076	80.7749
2014	7	12	8	10	59	0.3	4.6	0.87	98.3	99.1076	80.7749
2014	7	12	8	20	59	0.3	4.6	0.87	97.6	99.1076	81.3938
2014	7	12	8	30	59	0.3	4.6	0.88	95.6	99.1076	82.3223
2014	7	12	8	40	59	0.3	4.6	0.89	95.5	99.1076	83.5602
2014	7	12	8	50	59	0.3	4.6	0.85	97.3	99.1076	79.8464
2014	7	12	9	0	59	0.3	4.6	0.86	96.3	99.042	81.0288
2014	7	12	9	10	59	0.3	4.6	0.87	95	99.1076	82.0128
2014	7	12	9	20	59	0.3	4.6	0.88	96	99.042	82.5751
2014	7	12	9	30	59	0.3	4.6	0.86	96.3	99.1076	80.7748
2014	7	12	9	40	59	0.3	4.6	0.87	96.5	99.1076	81.7032
2014	7	12	9	50	59	0.3	4.6	0.88	94.5	99.1076	82.9412
2014	7	12	10	0	59	0.3	4.6	0.89	96.1	99.042	83.8121
2014	7	12	10	10	59	0.3	4.6	0.87	95.4	99.042	81.6472
2014	7	12	10	20	59	0.3	4.6	0.9	95.9	99.042	84.1214
2014	7	12	10	30	59	0.3	4.6	0.87	94.1	99.042	81.6472
2014	7	12	10	40	59	0.3	4.6	0.89	96.6	99.042	82.8843
2014	7	12	10	50	59	0.3	4.6	0.86	96.3	99.042	81.0286
2014	7	12	11	0	59	0.3	4.6	0.89	95.3	99.042	83.812
2014	7	12	11	10	59	0.3	4.6	0.9	99.4	99.042	83.812
2014	7	12	11	20	59	0.3	4.6	0.9	95.5	99.042	84.1213
2014	7	12	11	30	59	0.3	4.6	0.92	98.2	99.042	86.2861
2014	7	12	11	40	59	0.3	4.6	0.88	97.9	99.042	82.5749
2014	7	12	11	50	59	0.3	4.6	0.91	96.4	99.042	85.049
2014	7	12	12	0	59	0.3	4.6	0.9	98.4	99.042	83.5027

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	12	10	59	0.3	4.6	0.91	101.2	99.042	84.1212
2014	7	12	12	20	59	0.3	4.6	0.89	99.6	99.042	82.5748
2014	7	12	12	30	59	0.3	4.6	0.9	95.6	99.042	84.4304
2014	7	12	12	40	59	0.3	4.6	0.88	97.7	99.042	82.5748
2014	7	12	12	50	59	0.3	4.6	0.92	97	99.042	85.9767
2014	7	12	13	0	59	0.3	4.6	0.92	98	99.042	85.9767
2014	7	12	13	10	59	0.3	4.6	0.92	98.4	99.042	85.6674
2014	7	12	13	20	59	0.3	4.6	0.92	97.4	99.042	85.9767
2014	7	12	13	30	59	0.3	4.6	0.89	98.5	99.042	83.1932
2014	7	12	13	40	59	0.3	4.6	0.91	98.3	99.042	85.0488
2014	7	12	13	50	59	0.3	4.6	0.91	99.1	99.042	84.7395
2014	7	12	14	0	59	0.3	4.6	0.87	95.4	99.042	81.3376
2014	7	12	14	10	59	0.3	4.6	0.9	100.1	98.9764	83.4452
2014	7	12	14	20	59	0.3	4.6	0.89	97	99.042	83.5024
2014	7	12	14	30	59	0.3	4.6	0.91	97.7	98.9764	84.6814
2014	7	12	14	40	59	0.3	4.6	0.89	99.9	98.9764	82.8271
2014	7	12	14	50	59	0.3	4.6	0.93	95.4	98.9764	87.4629
2014	7	12	15	0	59	0.3	4.6	0.88	99.7	98.9764	81.5908
2014	7	12	15	10	59	0.3	4.6	0.9	99.2	98.9764	83.7542
2014	7	12	15	20	59	0.3	4.6	0.91	101.8	98.9764	84.3723
2014	7	12	15	30	59	0.3	4.6	0.89	98.2	98.9764	83.1361
2014	7	12	15	40	59	0.3	4.6	0.9	101	98.9764	82.827
2014	7	12	15	50	59	0.3	4.6	0.88	97	98.9764	82.518
2014	7	12	16	0	59	0.3	4.6	0.88	96.6	98.9764	82.518
2014	7	12	16	10	59	0.3	4.6	0.9	99.7	98.9764	83.1361
2014	7	12	16	20	59	0.3	4.6	0.9	98.4	98.9108	84.0056
2014	7	12	16	30	59	0.3	4.6	0.9	99.5	98.9108	83.3879
2014	7	12	16	40	59	0.3	4.6	0.9	95.2	98.9108	84.3144
2014	7	12	16	50	59	0.3	4.6	0.92	99	98.9764	85.6085
2014	7	12	17	0	59	0.3	4.6	0.91	100.6	98.9764	84.0632
2014	7	12	17	10	59	0.3	4.6	0.9	100.8	98.9764	82.827
2014	7	12	17	20	59	0.3	4.6	0.91	100.8	98.9108	84.3144
2014	7	12	17	30	59	0.3	4.6	0.9	100.5	98.9108	83.6967
2014	7	12	17	40	59	0.3	4.6	0.92	97.8	98.9108	86.1675
2014	7	12	17	50	59	0.3	4.6	0.9	99.2	98.9108	83.6967
2014	7	12	18	0	59	0.3	4.6	0.87	99.5	98.9764	81.2817
2014	7	12	18	10	59	0.3	4.6	0.91	99.7	98.9108	84.6232
2014	7	12	18	20	59	0.3	4.6	0.92	100.1	98.9108	85.2409
2014	7	12	18	30	59	0.3	4.6	0.88	96.4	98.9764	82.5179
2014	7	12	18	40	59	0.3	4.6	0.89	99.5	98.9764	83.136
2014	7	12	18	50	59	0.3	4.6	0.9	98.2	98.9764	83.7541
2014	7	12	19	0	59	0.3	4.6	0.91	97.3	98.9764	84.6813
2014	7	12	19	10	59	0.3	4.6	0.89	98	98.9108	83.3878
2014	7	12	19	20	59	0.3	4.6	0.87	98	98.9108	81.5348
2014	7	12	19	30	59	0.3	4.6	0.87	98.3	98.9764	80.9726
2014	7	12	19	40	59	0.3	4.6	0.88	96.4	98.9108	82.1524

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	19	50	59	0.3	4.6	0.89	96.8	98.9108	83.3878
2014	7	12	20	0	59	0.3	4.6	0.89	95.3	98.9764	83.136
2014	7	12	20	10	59	0.3	4.6	0.9	95.6	98.9764	84.3722
2014	7	12	20	20	59	0.3	4.6	0.89	94.4	98.9764	83.4451
2014	7	12	20	30	59	0.3	4.6	0.87	94.8	98.9764	81.5907
2014	7	12	20	40	59	0.3	4.6	0.89	96.1	98.9764	83.4451
2014	7	12	20	50	59	0.3	4.6	0.89	95.5	98.9764	83.136
2014	7	12	21	0	59	0.3	4.6	0.86	95.5	98.9764	80.6635
2014	7	12	21	10	59	0.3	4.6	0.92	97	98.9764	85.9175
2014	7	12	21	20	59	0.3	4.6	0.87	96.5	98.9764	81.5907
2014	7	12	21	30	59	0.3	4.6	0.88	94.3	98.9764	82.2088
2014	7	12	21	40	59	0.3	4.6	0.92	97	99.042	85.6672
2014	7	12	21	50	59	0.3	4.6	0.87	95.2	99.042	81.6467
2014	7	12	22	0	59	0.3	4.6	0.9	94.4	99.042	85.0486
2014	7	12	22	10	59	0.3	4.6	0.87	95.8	99.042	81.6467
2014	7	12	22	20	59	0.3	4.6	0.86	96.3	99.042	80.7189
2014	7	12	22	30	59	0.3	4.6	0.88	94.9	99.042	82.5745
2014	7	12	22	40	59	0.3	4.6	0.88	93.6	99.042	83.193
2014	7	12	22	50	59	0.3	4.6	0.9	95	99.042	84.4301
2014	7	12	23	0	59	0.3	4.6	0.88	96.2	99.042	82.8838
2014	7	12	23	10	59	0.3	4.6	0.89	94.7	99.042	83.1931
2014	7	12	23	20	59	0.3	4.6	0.86	97.4	99.042	80.7189
2014	7	12	23	30	59	0.3	4.6	0.9	95.6	99.042	84.7394
2014	7	12	23	40	59	0.3	4.6	0.87	95.8	99.042	81.6467
2014	7	12	23	50	59	0.3	4.6	0.87	94.8	99.042	81.3375
2014	7	13	0	0	59	0.3	4.6	0.89	94.6	99.042	83.8116
2014	7	13	0	10	59	0.3	4.6	0.9	96.3	99.042	84.1209
2014	7	13	0	20	59	0.3	4.6	0.9	93.8	99.042	84.7394
2014	7	13	0	30	59	0.3	4.6	0.87	95.4	99.042	81.6468
2014	7	13	0	40	59	0.3	4.6	0.9	95	99.042	84.4302
2014	7	13	0	50	59	0.3	4.6	0.87	96.7	99.042	81.6468
2014	7	13	1	0	59	0.3	4.6	0.9	93.6	99.042	84.4302
2014	7	13	1	10	59	0.3	4.6	0.9	94.8	99.042	84.121
2014	7	13	1	20	59	0.3	4.6	0.86	95.1	99.042	80.4098
2014	7	13	1	30	59	0.3	4.6	0.87	95.2	99.1076	82.0123
2014	7	13	1	40	59	0.3	4.6	0.88	93.6	99.1076	82.9408
2014	7	13	1	50	59	0.3	4.6	0.88	94.3	99.1076	82.3218
2014	7	13	2	0	59	0.3	4.6	0.88	93.2	99.1076	82.9408
2014	7	13	2	10	59	0.3	4.6	0.89	94.7	99.1076	83.2503
2014	7	13	2	20	59	0.3	4.6	0.87	95.6	99.1076	82.0124
2014	7	13	2	30	59	0.3	4.6	0.88	94.5	99.1076	82.6313
2014	7	13	2	40	59	0.3	4.6	0.87	94.1	99.1732	82.3783
2014	7	13	2	50	59	0.3	4.6	0.9	92.9	99.1732	84.8559
2014	7	13	3	0	59	0.3	4.6	0.88	95.2	99.1732	82.3783
2014	7	13	3	10	59	0.3	4.6	0.88	95.6	99.1732	82.688
2014	7	13	3	20	59	0.3	4.6	0.9	93.7	99.1732	85.1656

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	3	30	59	0.3	4.6	0.88	95.3	99.1732	82.9978
2014	7	13	3	40	59	0.3	4.6	0.87	94.5	99.1732	82.0687
2014	7	13	3	50	59	0.3	4.6	0.87	94.1	99.1732	81.4493
2014	7	13	4	0	59	0.3	4.6	0.88	92.1	99.1732	82.6881
2014	7	13	4	10	59	0.3	4.6	0.88	95.5	99.2388	83.0547
2014	7	13	4	20	59	0.3	4.6	0.88	95.1	99.2388	82.7448
2014	7	13	4	30	59	0.3	4.6	0.88	95.5	99.2388	83.0547
2014	7	13	4	40	59	0.3	4.6	0.87	95.6	99.3045	82.1812
2014	7	13	4	50	59	0.3	4.6	0.93	96.1	99.3045	87.4532
2014	7	13	5	0	59	0.3	4.6	0.87	95.4	99.3701	81.9271
2014	7	13	5	10	59	0.3	4.6	0.88	94.3	99.3701	82.8581
2014	7	13	5	20	59	0.3	4.6	0.89	95.3	99.4357	84.1569
2014	7	13	5	30	59	0.3	4.6	0.88	95.4	99.4357	82.6042
2014	7	13	5	40	59	0.3	4.6	0.88	95.2	99.5013	82.6606
2014	7	13	5	50	59	0.3	4.6	0.89	94	99.5013	84.5252
2014	7	13	6	0	59	0.3	4.6	0.86	94.4	99.5013	81.4177
2014	7	13	6	10	59	0.3	4.6	0.87	93.5	99.5013	82.3499
2014	7	13	6	20	59	0.3	4.6	0.88	95.5	99.5013	83.2822
2014	7	13	6	30	59	0.3	4.6	0.89	95.1	99.5013	84.2145
2014	7	13	6	40	59	0.3	4.6	0.89	94.2	99.5013	84.2145
2014	7	13	6	50	59	0.3	4.6	0.9	94.8	99.5013	84.836
2014	7	13	7	0	59	0.3	4.6	0.9	94.4	99.5013	84.5253
2014	7	13	7	10	59	0.3	4.6	0.89	95.9	99.5013	83.9038
2014	7	13	7	20	59	0.3	4.6	0.86	95.5	99.5013	81.4178
2014	7	13	7	30	59	0.3	4.6	0.89	95.3	99.5013	83.593
2014	7	13	7	40	59	0.3	4.6	0.87	96.5	99.5013	81.7285
2014	7	13	7	50	59	0.3	4.6	0.88	93.2	99.5013	83.2823
2014	7	13	8	0	59	0.3	4.6	0.9	95.9	99.5013	84.8361
2014	7	13	8	10	59	0.3	4.6	0.9	94.8	99.5013	84.5253
2014	7	13	8	20	59	0.3	4.6	0.86	92.2	99.5013	81.4178
2014	7	13	8	30	59	0.3	4.6	0.9	95	99.5013	84.8361
2014	7	13	8	40	59	0.3	4.6	0.89	95.1	99.5013	83.593
2014	7	13	8	50	59	0.3	4.6	0.91	95.4	99.5013	85.4576
2014	7	13	9	0	59	0.3	4.6	0.9	95.7	99.5013	84.5253
2014	7	13	9	10	59	0.3	4.6	0.88	95.1	99.5013	82.9715
2014	7	13	9	20	59	0.3	4.6	0.89	94.4	99.5013	83.9037
2014	7	13	9	30	59	0.3	4.6	0.88	97.1	99.5013	82.6607
2014	7	13	9	40	59	0.3	4.6	0.9	96.9	99.5013	84.2145
2014	7	13	9	50	59	0.3	4.6	0.91	95.2	99.5013	85.7682
2014	7	13	10	0	59	0.3	4.6	0.89	95.5	99.5013	83.9037
2014	7	13	10	10	59	0.3	4.6	0.91	97.3	99.3701	85.0305
2014	7	13	10	20	59	0.3	4.6	0.88	95.2	99.5013	82.6607
2014	7	13	10	30	59	0.3	4.6	0.92	95.8	99.5013	86.3897
2014	7	13	10	40	59	0.3	4.6	0.94	97.6	99.5013	88.565
2014	7	13	10	50	59	0.3	4.6	0.91	97.6	99.5013	85.7682
2014	7	13	11	0	59	0.3	4.6	0.91	100	99.4357	84.778

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	11	10	59	0.3	4.6	0.9	96.9	99.4357	84.4674
2014	7	13	11	20	59	0.3	4.6	0.9	97.9	99.3701	84.72
2014	7	13	11	30	59	0.3	4.6	0.91	101.2	99.3701	84.4097
2014	7	13	11	40	59	0.3	4.6	0.92	101.1	99.3701	85.0303
2014	7	13	11	50	59	0.3	4.6	0.89	99.5	99.3045	83.4216
2014	7	13	12	0	59	0.3	4.6	0.93	97.9	99.2388	87.3933
2014	7	13	12	10	59	0.3	4.6	0.89	99.3	99.2388	83.0546
2014	7	13	12	20	59	0.3	4.6	0.91	100.2	99.2388	84.6042
2014	7	13	12	30	59	0.3	4.6	0.87	99.7	99.1732	81.1396
2014	7	13	12	40	59	0.3	4.6	0.9	101.6	99.1732	83.3075
2014	7	13	12	50	59	0.3	4.6	0.87	101.1	99.1732	80.5202
2014	7	13	13	0	59	0.3	4.6	0.87	99.1	99.1732	81.1396
2014	7	13	13	10	59	0.3	4.6	0.89	99.5	99.1732	82.9977
2014	7	13	13	20	59	0.3	4.6	0.92	99.6	99.1732	85.7849
2014	7	13	13	30	59	0.3	4.6	0.91	98.5	99.1732	84.5461
2014	7	13	13	40	59	0.3	4.6	0.88	100.8	99.1732	81.4492
2014	7	13	13	50	59	0.3	4.6	0.9	99.5	99.1732	83.6171
2014	7	13	14	0	59	0.3	4.6	0.91	100.9	99.1732	83.9267
2014	7	13	14	10	59	0.3	4.6	0.9	99.5	99.1732	83.617
2014	7	13	14	20	59	0.3	4.6	0.9	100.3	99.1732	83.617
2014	7	13	14	30	59	0.3	4.6	0.92	99.9	99.1732	85.1655
2014	7	13	14	40	59	0.3	4.6	0.89	101.2	99.1732	82.6879
2014	7	13	14	50	59	0.3	4.6	0.91	100.9	99.1732	83.9267
2014	7	13	15	0	59	0.3	4.6	0.88	96.2	99.1076	82.9408
2014	7	13	15	10	59	0.3	4.6	0.91	99.1	99.1076	85.1071
2014	7	13	15	20	59	0.3	4.6	0.91	99.5	99.1732	85.1654
2014	7	13	15	30	59	0.3	4.6	0.9	99.2	99.1076	84.1787
2014	7	13	15	40	59	0.3	4.6	0.89	99.6	99.1076	82.3218
2014	7	13	15	50	59	0.3	4.6	0.9	98.4	99.1076	83.8692
2014	7	13	16	0	59	0.3	4.6	0.89	98.5	99.1076	82.9408
2014	7	13	16	10	59	0.3	4.6	0.9	99	99.1076	83.5597
2014	7	13	16	20	59	0.3	4.6	0.89	98.9	99.1076	83.2502
2014	7	13	16	30	59	0.3	4.6	0.91	98.7	99.1076	84.4881
2014	7	13	16	40	59	0.3	4.6	0.91	98.3	99.1076	85.1071
2014	7	13	16	50	59	0.3	4.6	0.9	96.7	99.1076	83.8692
2014	7	13	17	0	59	0.3	4.6	0.93	99.3	99.1076	86.6545
2014	7	13	17	10	59	0.3	4.6	0.89	99.6	99.1076	82.3218
2014	7	13	17	20	59	0.3	4.6	0.9	98.4	99.1076	83.5597
2014	7	13	17	30	59	0.3	4.6	0.89	99.6	99.1076	82.6312
2014	7	13	17	40	59	0.3	4.6	0.91	98.3	99.1076	85.1071
2014	7	13	17	50	59	0.3	4.6	0.89	98.5	99.1076	82.6312
2014	7	13	18	0	59	0.3	4.6	0.92	99.4	99.1076	85.726
2014	7	13	18	10	59	0.3	4.6	0.9	98.6	99.1076	84.1786
2014	7	13	18	20	59	0.3	4.6	0.88	94.5	99.1076	82.6312
2014	7	13	18	30	59	0.3	4.6	0.89	96.4	99.1076	83.2502
2014	7	13	18	40	59	0.3	4.6	0.87	95.6	99.1076	81.7028

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	18	50	59	0.3	4.6	0.87	95	99.1076	81.7028
2014	7	13	19	0	59	0.3	4.6	0.89	96.8	99.1076	82.9407
2014	7	13	19	10	59	0.3	4.6	0.9	94.6	99.1076	84.4881
2014	7	13	19	20	59	0.3	4.6	0.87	94.5	99.042	81.6468
2014	7	13	19	30	59	0.3	4.6	0.86	93.9	99.1076	81.0838
2014	7	13	19	40	59	0.3	4.6	0.85	94.2	99.1732	79.9006
2014	7	13	19	50	59	0.3	4.6	0.85	96	99.1732	80.2103
2014	7	13	20	0	59	0.3	4.6	0.89	95.9	99.1732	83.6169
2014	7	13	20	10	59	0.3	4.6	0.91	95.8	99.1732	85.1653
2014	7	13	20	20	59	0.3	4.6	0.9	95	99.1732	84.8556
2014	7	13	20	30	59	0.3	4.6	0.89	95.3	99.1732	83.3072
2014	7	13	20	40	59	0.3	4.6	0.9	93.6	99.1732	84.5459
2014	7	13	20	50	59	0.3	4.6	0.87	96.5	99.1732	82.0684
2014	7	13	21	0	59	0.3	4.6	0.89	96.1	99.1732	83.9265
2014	7	13	21	10	59	0.3	4.6	0.87	94.1	99.1732	82.0684
2014	7	13	21	20	59	0.3	4.6	0.9	95	99.1732	84.5459
2014	7	13	21	30	59	0.3	4.6	0.9	94.6	99.1732	84.5459
2014	7	13	21	40	59	0.3	4.6	0.9	94.4	99.1732	84.2362
2014	7	13	21	50	59	0.3	4.6	0.87	96.9	99.1732	81.7587
2014	7	13	22	0	59	0.3	4.6	0.87	95.4	99.1732	82.0684
2014	7	13	22	10	59	0.3	4.6	0.87	94.3	99.2388	82.1246
2014	7	13	22	20	59	0.3	4.6	0.89	95.3	99.2388	83.3642
2014	7	13	22	30	59	0.3	4.6	0.88	94.7	99.2388	83.0543
2014	7	13	22	40	59	0.3	4.6	0.87	93.5	99.2388	82.1246
2014	7	13	22	50	59	0.3	4.6	0.89	94.6	99.2388	83.984
2014	7	13	23	0	59	0.3	4.6	0.88	93.9	99.2388	82.7444
2014	7	13	23	10	59	0.3	4.6	0.88	96.4	99.2388	83.0543
2014	7	13	23	20	59	0.3	4.6	0.87	93	99.2388	82.4345
2014	7	13	23	30	59	0.3	4.6	0.87	95.4	99.2388	82.1246
2014	7	13	23	40	59	0.3	4.6	0.88	93.8	99.2388	83.3642
2014	7	13	23	50	59	0.3	4.6	0.88	95.4	99.2388	82.4345
2014	7	14	0	0	59	0.3	4.6	0.9	96	99.2388	84.9137
2014	7	14	0	10	59	0.3	4.6	0.9	95.3	99.2388	84.2939
2014	7	14	0	20	59	0.3	4.6	0.88	97.5	99.2388	82.7444
2014	7	14	0	30	59	0.3	4.6	0.88	95.4	99.2388	82.4345
2014	7	14	0	40	59	0.3	4.6	0.87	95	99.2388	81.8147
2014	7	14	0	50	59	0.3	4.6	0.88	94.7	99.2388	82.4345
2014	7	14	1	0	59	0.3	4.6	0.85	96.9	99.3045	79.6999
2014	7	14	1	10	59	0.3	4.6	0.87	96.3	99.3045	81.5606
2014	7	14	1	20	59	0.3	4.6	0.89	96.3	99.3045	84.0415
2014	7	14	1	30	59	0.3	4.6	0.9	96.3	99.3045	84.3516
2014	7	14	1	40	59	0.3	4.6	0.88	96.4	99.3045	83.1112
2014	7	14	1	50	59	0.3	4.6	0.88	95.8	99.3045	82.491
2014	7	14	2	0	59	0.3	4.6	0.9	93.6	99.3045	84.6618
2014	7	14	2	10	59	0.3	4.6	0.92	94.9	99.3045	86.5225
2014	7	14	2	20	59	0.3	4.6	0.88	94.5	99.3045	82.8011

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	2	30	59	0.3	4.6	0.9	94.6	99.3701	84.7197
2014	7	14	2	40	59	0.3	4.6	0.88	96.2	99.4357	83.2249
2014	7	14	2	50	59	0.3	4.6	0.86	94.6	99.5013	81.4172
2014	7	14	3	0	59	0.3	4.6	0.89	94.7	99.5669	83.6496
2014	7	14	3	10	59	0.3	4.6	0.89	96.3	99.5013	84.214
2014	7	14	3	20	59	0.3	4.6	0.9	95	99.5669	85.2044
2014	7	14	3	30	59	0.3	4.6	0.89	94.7	99.5013	83.5925
2014	7	14	3	40	59	0.3	4.6	0.9	94.8	99.5669	85.2044
2014	7	14	3	50	59	0.3	4.6	0.89	95.1	99.5669	83.6496
2014	7	14	4	0	59	0.3	4.6	0.88	96.4	99.5669	83.3387
2014	7	14	4	10	59	0.3	4.6	0.89	95.1	99.5669	84.2716
2014	7	14	4	20	59	0.3	4.6	0.9	94.8	99.5669	84.5825
2014	7	14	4	30	59	0.3	4.6	0.89	94.4	99.5669	83.9606
2014	7	14	4	40	59	0.3	4.6	0.9	92.5	99.5669	84.8935
2014	7	14	4	50	59	0.3	4.6	0.89	95.3	99.5669	83.6497
2014	7	14	5	0	59	0.3	4.6	0.9	95	99.5669	84.8935
2014	7	14	5	10	59	0.3	4.6	0.88	94.3	99.5669	83.6497
2014	7	14	5	20	59	0.3	4.6	0.89	95.1	99.5669	83.6497
2014	7	14	5	30	59	0.3	4.6	0.91	93.5	99.5669	85.8265
2014	7	14	5	40	59	0.3	4.6	0.91	95.6	99.5669	85.8265
2014	7	14	5	50	59	0.3	4.6	0.88	94.3	99.5669	82.7168
2014	7	14	6	0	59	0.3	4.6	0.88	96.4	99.5669	83.0278
2014	7	14	6	10	59	0.3	4.6	0.87	94.3	99.5669	82.4059
2014	7	14	6	20	59	0.3	4.6	0.9	94.6	99.5669	85.2046
2014	7	14	6	30	59	0.3	4.6	0.92	94.5	99.5669	86.7594
2014	7	14	6	40	59	0.3	4.6	0.87	94.3	99.6326	82.4621
2014	7	14	6	50	59	0.3	4.6	0.88	94.7	99.6326	83.0845
2014	7	14	7	0	59	0.3	4.6	0.9	96.3	99.6326	84.6403
2014	7	14	7	10	59	0.3	4.6	0.86	95.7	99.6326	81.5286
2014	7	14	7	20	59	0.3	4.6	0.86	93.9	99.6326	81.5286
2014	7	14	7	30	59	0.3	4.6	0.89	95.1	99.6326	84.3292
2014	7	14	7	40	59	0.3	4.6	0.88	93.6	99.6326	83.3956
2014	7	14	7	50	59	0.3	4.6	0.92	96.6	99.6326	86.5074
2014	7	14	8	0	59	0.3	4.6	0.9	95.2	99.6326	85.2627
2014	7	14	8	10	59	0.3	4.6	0.88	96.2	99.6326	83.0845
2014	7	14	8	20	59	0.3	4.6	0.9	95.6	99.6326	84.9515
2014	7	14	8	30	59	0.3	4.6	0.89	95.9	99.6326	84.018
2014	7	14	8	40	59	0.3	4.6	0.88	95.5	99.6326	83.3956
2014	7	14	8	50	59	0.3	4.6	0.91	96.4	99.6326	86.1962
2014	7	14	9	0	59	0.3	4.6	0.91	95.8	99.6326	86.1962
2014	7	14	9	10	59	0.3	4.6	0.9	95	99.6326	84.9515
2014	7	14	9	20	59	0.3	4.6	0.9	95	99.6326	85.2627
2014	7	14	9	30	59	0.3	4.6	0.87	95.4	99.6326	82.1509
2014	7	14	9	40	59	0.3	4.6	0.88	95.3	99.6326	83.3955
2014	7	14	9	50	59	0.3	4.6	0.87	96.5	99.6326	82.462
2014	7	14	10	0	59	0.3	4.6	0.9	94.2	99.6326	85.2626

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	10	10	59	0.3	4.6	0.91	95.8	99.6326	85.5738
2014	7	14	10	20	59	0.3	4.6	0.89	98	99.6326	84.0179
2014	7	14	10	30	59	0.3	4.6	0.9	97.5	99.5669	84.8936
2014	7	14	10	40	59	0.3	4.6	0.89	100.4	99.5669	83.0278
2014	7	14	10	50	59	0.3	4.6	0.9	97.9	99.5669	84.8936
2014	7	14	11	0	59	0.3	4.6	0.9	96.5	99.5013	84.8356
2014	7	14	11	10	59	0.3	4.6	0.89	99.7	99.4357	83.225
2014	7	14	11	20	59	0.3	4.6	0.89	98.5	99.5013	82.9711
2014	7	14	11	30	59	0.3	4.6	0.89	98.9	99.5013	83.5926
2014	7	14	11	40	59	0.3	4.6	0.92	95.5	99.5013	86.7001
2014	7	14	11	50	59	0.3	4.6	0.9	95.2	99.5013	85.1463
2014	7	14	12	0	59	0.3	4.6	0.91	99.7	99.5013	85.1463
2014	7	14	12	10	59	0.3	4.6	0.87	99.7	99.4357	81.3617
2014	7	14	12	20	59	0.3	4.6	0.89	99.7	99.5013	83.2817
2014	7	14	12	30	59	0.3	4.6	0.88	102.4	99.4357	81.6722
2014	7	14	12	40	59	0.3	4.6	0.89	100	99.4357	82.6038
2014	7	14	12	50	59	0.3	4.6	0.91	99.8	99.3701	84.4094
2014	7	14	13	0	59	0.3	4.6	0.9	98.8	99.3701	84.0991
2014	7	14	13	10	59	0.3	4.6	0.87	99.6	99.3701	80.9958
2014	7	14	13	20	59	0.3	4.6	0.89	96.4	99.3701	83.4784
2014	7	14	13	30	59	0.3	4.6	0.89	98.5	99.3045	83.1113
2014	7	14	13	40	59	0.3	4.6	0.88	99.4	99.3045	82.491
2014	7	14	13	50	59	0.3	4.6	0.91	101	99.3045	84.3518
2014	7	14	14	0	59	0.3	4.6	0.9	101.3	99.3045	83.7315
2014	7	14	14	10	59	0.3	4.6	0.88	99	99.2388	82.4347
2014	7	14	14	20	59	0.3	4.6	0.92	97.4	99.2388	85.8436
2014	7	14	14	30	59	0.3	4.6	0.89	100.2	99.3045	83.1113
2014	7	14	14	40	59	0.3	4.6	0.89	100.4	99.3701	82.8578
2014	7	14	14	50	59	0.3	4.6	0.91	100.1	99.3045	84.972
2014	7	14	15	10	27	0.3	4.6	0.91	101.4	99.2388	84.2941
2014	7	14	15	20	27	0.3	4.6	0.9	98	99.3045	84.3518
2014	7	14	15	30	27	0.3	4.6	0.94	98.4	99.2388	88.0129
2014	7	14	15	40	27	0.3	4.6	0.92	98	99.3045	85.9024
2014	7	14	15	50	27	0.3	4.6	0.95	96.7	99.3701	89.3747
2014	7	14	16	0	27	0.3	4.6	0.93	97.3	99.3045	86.8327
2014	7	14	16	10	27	0.3	4.6	0.86	104.1	99.3045	78.7696
2014	7	14	16	20	27	0.3	4.6	0.88	95.1	99.2388	83.0545
2014	7	14	16	30	27	0.3	4.6	0.89	97.2	99.3045	83.4214
2014	7	14	16	40	27	0.3	4.6	0.89	99.7	99.2388	83.0544
2014	7	14	16	50	27	0.3	4.6	0.89	98.5	99.2388	82.7445
2014	7	14	17	0	27	0.3	4.6	0.9	98	99.2388	84.294
2014	7	14	17	10	27	0.3	4.6	0.9	101.6	99.2388	83.3643
2014	7	14	17	20	27	0.3	4.6	0.87	99.3	99.1732	81.4491
2014	7	14	17	30	27	0.3	4.6	0.88	96.2	99.2388	82.4346
2014	7	14	17	40	27	0.3	4.6	0.89	96.8	99.3045	83.1113
2014	7	14	17	50	27	0.3	4.6	0.9	98.4	99.2388	84.294

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	18	0	27	0.3	4.6	0.89	98.5	99.1732	82.9976
2014	7	14	18	10	27	0.3	4.6	0.89	97.9	99.1732	82.9976
2014	7	14	18	20	27	0.3	4.6	0.86	99	99.1732	80.5201
2014	7	14	18	30	27	0.3	4.6	0.88	98.6	99.1732	82.3782
2014	7	14	18	40	27	0.3	4.6	0.88	96.4	99.1732	82.9976
2014	7	14	18	50	27	0.3	4.6	0.9	98.6	99.1732	84.2364
2014	7	14	19	0	27	0.3	4.6	0.91	99.3	99.1732	84.8558
2014	7	14	19	10	27	0.3	4.6	0.89	94.2	99.1732	83.9267
2014	7	14	19	20	27	0.3	4.6	0.88	95.1	99.1732	82.9976
2014	7	14	19	30	27	0.3	4.6	0.91	96.8	99.1732	85.1655
2014	7	14	19	40	27	0.3	4.6	0.92	97.6	99.1732	86.0945
2014	7	14	19	50	27	0.3	4.6	0.88	95.1	99.2388	83.0544
2014	7	14	20	0	27	0.3	4.6	0.91	99	99.1732	84.5461
2014	7	14	20	10	27	0.3	4.6	0.92	98.7	99.1732	85.4751
2014	7	14	20	20	27	0.3	4.6	0.9	98.4	99.2388	84.294
2014	7	14	20	30	27	0.3	4.6	0.91	97	99.2388	85.5337
2014	7	14	20	40	27	0.3	4.6	0.9	97.5	99.3045	84.6618
2014	7	14	20	50	27	0.3	4.6	0.92	99.8	99.2388	85.8436
2014	7	14	21	0	27	0.3	4.6	0.88	95.3	99.3701	83.1681
2014	7	14	21	10	27	0.3	4.6	0.87	96.3	99.3045	81.8708
2014	7	14	21	20	27	0.3	4.6	0.87	95.4	99.2388	81.8148
2014	7	14	21	30	27	0.3	4.6	0.92	97	99.3045	86.2124
2014	7	14	21	40	27	0.3	4.6	0.91	96.8	99.2388	85.2238
2014	7	14	21	50	27	0.3	4.6	0.9	96.9	99.2388	84.294
2014	7	14	22	0	27	0.3	4.6	0.92	95.3	99.2388	86.7733
2014	7	14	22	10	27	0.3	4.6	0.9	96.9	99.2388	84.294
2014	7	14	22	20	27	0.3	4.6	0.9	97.1	99.2388	84.294
2014	7	14	22	30	27	0.3	4.6	0.9	96.2	99.3701	85.03
2014	7	14	22	40	27	0.3	4.6	0.91	96	99.3701	85.3404
2014	7	14	22	50	27	0.3	4.6	0.91	96.7	99.3045	84.9719
2014	7	14	23	0	27	0.3	4.6	0.91	97.5	99.3045	85.2821
2014	7	14	23	10	27	0.3	4.6	0.9	96.3	99.3045	84.6618
2014	7	14	23	20	27	0.3	4.6	0.91	97.1	99.3045	84.9719
2014	7	14	23	30	27	0.3	4.6	0.87	96.9	99.3045	81.8708
2014	7	14	23	40	27	0.3	4.6	0.91	99.2	99.3045	84.6618
2014	7	14	23	50	27	0.3	4.6	0.9	97.1	99.3701	84.4094
2014	7	15	0	0	27	0.3	4.6	0.92	101.1	99.3701	85.6507
2014	7	15	0	10	27	0.3	4.6	0.93	98.1	99.3701	87.2023
2014	7	15	0	20	27	0.3	4.6	0.93	97.9	99.3701	86.892
2014	7	15	0	30	27	0.3	4.6	0.9	98.4	99.3701	84.0991
2014	7	15	0	40	27	0.3	4.6	0.92	97.2	99.3701	86.2713
2014	7	15	0	50	27	0.3	4.6	0.9	97.1	99.4357	84.4671
2014	7	15	1	0	27	0.3	4.6	0.9	95.2	99.3045	84.6618
2014	7	15	1	10	27	0.3	4.6	0.87	96.3	99.3701	81.9267
2014	7	15	1	20	27	0.3	4.6	0.92	98	99.4357	86.0198
2014	7	15	1	30	27	0.3	4.6	0.9	95.4	99.3701	85.03

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	1	40	27	0.3	4.6	0.88	95.4	99.4357	82.6038
2014	7	15	1	50	27	0.3	4.6	0.88	93.2	99.4357	83.2249
2014	7	15	2	0	27	0.3	4.6	0.9	97.4	99.4357	84.1565
2014	7	15	2	10	27	0.3	4.6	0.89	96.4	99.5013	83.5925
2014	7	15	2	20	27	0.3	4.6	0.89	94.9	99.5669	83.9605
2014	7	15	2	30	27	0.3	4.6	0.88	96.2	99.5669	82.7167
2014	7	15	2	40	27	0.3	4.6	0.88	95.3	99.5669	83.3386
2014	7	15	2	50	27	0.3	4.6	0.89	96.2	99.5669	83.6495
2014	7	15	3	0	27	0.3	4.6	0.88	94.5	99.5669	83.3386
2014	7	15	3	10	27	0.3	4.6	0.91	94.1	99.5669	85.8263
2014	7	15	3	20	27	0.3	4.6	0.89	95.7	99.5669	84.2715
2014	7	15	3	30	27	0.3	4.6	0.9	95	99.5669	84.8934
2014	7	15	3	40	27	0.3	4.6	0.88	96	99.5669	83.3386
2014	7	15	3	50	27	0.3	4.6	0.92	95.1	99.5669	86.7592
2014	7	15	4	0	27	0.3	4.6	0.9	95	99.5669	84.8934
2014	7	15	4	10	27	0.3	4.6	0.88	93.9	99.5669	83.0277
2014	7	15	4	20	27	0.3	4.6	0.9	96.1	99.6326	84.9513
2014	7	15	4	30	27	0.3	4.6	0.93	95.2	99.6326	88.0631
2014	7	15	4	40	27	0.3	4.6	0.89	96.2	99.6326	83.7066
2014	7	15	4	50	27	0.3	4.6	0.9	94	99.6326	84.9513
2014	7	15	5	0	27	0.3	4.6	0.9	94.4	99.6326	84.6402
2014	7	15	5	10	27	0.3	4.6	0.9	95	99.6326	85.2625
2014	7	15	5	20	27	0.3	4.6	0.89	96.4	99.6982	83.7637
2014	7	15	5	30	27	0.3	4.6	0.88	94.9	99.6326	83.3955
2014	7	15	5	40	27	0.3	4.6	0.88	92.3	99.6982	83.7637
2014	7	15	5	50	27	0.3	4.6	0.88	94.5	99.6982	83.1409
2014	7	15	6	0	27	0.3	4.6	0.88	95.8	99.6982	82.8295
2014	7	15	6	10	27	0.3	4.6	0.89	95.3	99.6982	84.3865
2014	7	15	6	20	27	0.3	4.6	0.9	95	99.6982	85.3206
2014	7	15	6	30	27	0.3	4.6	0.89	94.9	99.6982	84.0751
2014	7	15	6	40	27	0.3	4.6	0.88	95.6	99.6982	83.1409
2014	7	15	6	50	27	0.3	4.6	0.9	94.4	99.6982	85.632
2014	7	15	7	0	27	0.3	4.6	0.91	94.8	99.6982	85.632
2014	7	15	7	10	27	0.3	4.6	0.89	95.1	99.6982	84.0751
2014	7	15	7	20	27	0.3	4.6	0.89	97.2	99.6982	83.7637
2014	7	15	7	30	27	0.3	4.6	0.89	94.2	99.6326	84.329
2014	7	15	7	40	27	0.3	4.6	0.89	95.7	99.6326	83.7067
2014	7	15	7	50	27	0.3	4.6	0.9	97.1	99.6326	84.9514
2014	7	15	8	0	27	0.3	4.6	0.89	94.4	99.6982	84.0751
2014	7	15	8	10	27	0.3	4.6	0.92	93.1	99.6982	86.8776
2014	7	15	8	20	27	0.3	4.6	0.88	96.6	99.6982	83.141
2014	7	15	8	30	27	0.3	4.6	0.91	95	99.6982	85.6321
2014	7	15	8	40	27	0.3	4.6	0.91	95	99.6982	85.9434
2014	7	15	8	50	27	0.3	4.6	0.92	96.7	99.6982	87.189
2014	7	15	9	0	27	0.3	4.6	0.89	94.2	99.7638	84.4439
2014	7	15	9	10	27	0.3	4.6	0.88	95.2	99.6982	82.8295

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	9	20	27	0.3	4.6	0.9	96.1	99.6982	85.0092
2014	7	15	9	30	27	0.3	4.6	0.88	95.3	99.6982	83.4523
2014	7	15	9	40	27	0.3	4.6	0.89	95.3	99.6982	84.3865
2014	7	15	9	50	27	0.3	4.6	0.89	94.6	99.6982	84.3864
2014	7	15	10	0	27	0.3	4.6	0.92	92.9	99.6982	87.5003
2014	7	15	10	10	27	0.3	4.6	0.9	95.6	99.7638	85.0671
2014	7	15	10	20	27	0.3	4.6	0.88	95.8	99.7638	82.8859
2014	7	15	10	30	27	0.3	4.6	0.87	95.8	99.6982	82.2067
2014	7	15	10	40	27	0.3	4.6	0.93	100.2	99.6982	86.8775
2014	7	15	10	50	27	0.3	4.6	0.87	97.3	99.6982	82.2066
2014	7	15	11	0	27	0.3	4.6	0.89	96.3	99.6982	84.075
2014	7	15	11	10	27	0.3	4.6	0.9	98.4	99.6982	84.3864
2014	7	15	11	20	27	0.3	4.6	0.92	99	99.6982	86.2547
2014	7	15	11	30	27	0.3	4.6	0.9	98.4	99.6982	84.6978
2014	7	15	11	40	27	0.3	4.6	0.9	99.8	99.6982	84.3864
2014	7	15	11	50	27	0.3	4.6	0.91	98.1	99.6982	85.3206
2014	7	15	12	0	27	0.3	4.6	0.9	96.5	99.6982	84.6978
2014	7	15	12	10	27	0.3	4.6	0.89	96.8	99.6982	83.7636
2014	7	15	12	20	27	0.3	4.6	0.88	96.6	99.6982	83.1408
2014	7	15	12	30	27	0.3	4.6	0.89	97.6	99.6982	83.7635
2014	7	15	12	40	27	0.3	4.6	0.93	99.2	99.6982	86.8773
2014	7	15	12	50	27	0.3	4.6	0.91	100.6	99.6982	84.6976
2014	7	15	13	0	27	0.3	4.6	0.91	99.1	99.6982	85.6317
2014	7	15	13	10	27	0.3	4.6	0.9	94.8	99.6326	85.2622
2014	7	15	13	20	27	0.3	4.6	0.88	102.5	99.6326	81.5281
2014	7	15	13	30	27	0.3	4.6	0.89	99.5	99.6326	83.7064
2014	7	15	13	40	27	0.3	4.6	0.93	101.2	99.6326	86.507
2014	7	15	13	50	27	0.3	4.6	0.89	102.9	99.6326	81.8394
2014	7	15	14	0	27	0.3	4.6	0.9	98.6	99.6326	84.6399
2014	7	15	14	10	27	0.3	4.6	0.92	100.5	99.6326	85.5734
2014	7	15	14	20	27	0.3	4.6	0.88	94.3	99.5669	83.3383
2014	7	15	14	30	27	0.3	4.6	0.88	100.7	99.5669	82.4054
2014	7	15	14	40	27	0.3	4.6	0.87	98.9	99.6326	81.217
2014	7	15	14	50	27	0.3	4.6	0.9	95.5	99.5669	84.5822
2014	7	15	15	0	27	0.3	4.6	0.92	98.2	99.5669	86.448
2014	7	15	15	10	27	0.3	4.6	0.9	99	99.5669	83.9603
2014	7	15	15	20	27	0.3	4.6	0.87	98.9	99.5669	81.1616
2014	7	15	15	30	27	0.3	4.6	0.92	95.5	99.5669	86.4479
2014	7	15	15	40	27	0.3	4.6	0.87	99.1	99.5669	81.1616
2014	7	15	15	50	27	0.3	4.6	0.94	98.2	99.5013	88.5642
2014	7	15	16	0	27	0.3	4.6	0.94	94.8	99.5013	88.875
2014	7	15	16	10	27	0.3	4.6	0.89	98.9	99.5013	83.5922
2014	7	15	16	20	27	0.3	4.6	0.92	98	99.5013	86.0782
2014	7	15	16	30	27	0.3	4.6	0.91	97.9	99.5013	85.1459
2014	7	15	16	40	27	0.3	4.6	0.93	99.6	99.4357	86.33
2014	7	15	16	50	27	0.3	4.6	0.89	99.5	99.4357	83.5351

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	17	0	27	0.3	4.6	0.9	100.5	99.4357	83.8457
2014	7	15	17	10	27	0.3	4.6	0.89	101.2	99.3701	82.8574
2014	7	15	17	20	27	0.3	4.6	0.89	97	99.4357	83.8457
2014	7	15	17	30	27	0.3	4.6	0.88	98.1	99.4357	82.9141
2014	7	15	17	40	27	0.3	4.6	0.92	99.7	99.4357	85.7089
2014	7	15	17	50	27	0.3	4.6	0.9	97.5	99.3701	84.4091
2014	7	15	18	0	27	0.3	4.6	0.9	96.7	99.4357	84.1562
2014	7	15	18	10	27	0.3	4.6	0.91	100.4	99.4357	84.7773
2014	7	15	18	20	27	0.3	4.6	0.92	97.8	99.3045	86.5222
2014	7	15	18	30	27	0.3	4.6	0.89	100	99.3045	82.4907
2014	7	15	18	40	27	0.3	4.6	0.89	99.1	99.3045	82.8008
2014	7	15	18	50	27	0.3	4.6	0.89	98.5	99.3045	82.8008
2014	7	15	19	0	27	0.3	4.6	0.91	99.2	99.3701	84.7194
2014	7	15	19	10	27	0.3	4.6	0.9	97.5	99.3045	84.3514
2014	7	15	19	20	27	0.3	4.6	0.88	96.6	99.3045	82.8008
2014	7	15	19	30	27	0.3	4.6	0.91	96	99.3045	85.2818
2014	7	15	19	40	27	0.3	4.6	0.91	96.9	99.3045	84.9716
2014	7	15	19	50	27	0.3	4.6	0.92	96.3	99.3045	86.8323
2014	7	15	20	0	27	0.3	4.6	0.91	97.7	99.3045	84.9716
2014	7	15	20	10	27	0.3	4.6	0.89	96.8	99.3045	83.7312
2014	7	15	20	20	27	0.3	4.6	0.9	94.2	99.3701	85.34
2014	7	15	20	30	27	0.3	4.6	0.91	94.8	99.3701	85.34
2014	7	15	20	40	27	0.3	4.6	0.9	93.6	99.3701	84.7194
2014	7	15	20	50	27	0.3	4.6	0.88	94.3	99.3701	82.5471
2014	7	15	21	0	27	0.3	4.6	0.87	92.4	99.3701	82.2368
2014	7	15	21	10	27	0.3	4.6	0.89	94	99.3701	84.0987
2014	7	15	21	20	27	0.3	4.6	0.9	94.2	99.4357	85.3984
2014	7	15	21	30	27	0.3	4.6	0.89	95.3	99.4357	83.5351
2014	7	15	21	40	27	0.3	4.6	0.87	95	99.4357	82.293
2014	7	15	21	50	27	0.3	4.6	0.9	94.2	99.4357	85.0878
2014	7	15	22	0	27	0.3	4.6	0.91	94.6	99.5013	85.7674
2014	7	15	22	10	27	0.3	4.6	0.86	92	99.4357	81.6719
2014	7	15	22	20	27	0.3	4.6	0.87	92.4	99.4357	82.293
2014	7	15	22	30	27	0.3	4.6	0.89	94.4	99.5013	83.9029
2014	7	15	22	40	27	0.3	4.6	0.9	94.4	99.5013	85.146
2014	7	15	22	50	27	0.3	4.6	0.87	92.2	99.5013	82.3492
2014	7	15	23	0	27	0.3	4.6	0.89	93.6	99.5013	83.903
2014	7	15	23	10	27	0.3	4.6	0.87	95.6	99.5013	82.0384
2014	7	15	23	20	27	0.3	4.6	0.88	94.3	99.5669	83.0273
2014	7	15	23	30	27	0.3	4.6	0.9	93.3	99.5669	85.515
2014	7	15	23	40	27	0.3	4.6	0.87	94.3	99.5669	82.4054
2014	7	15	23	50	27	0.3	4.6	0.91	95.2	99.5669	86.137
2014	7	16	0	0	27	0.3	4.6	0.87	94.1	99.5669	82.7164
2014	7	16	0	10	27	0.3	4.6	0.87	95	99.6326	82.4616
2014	7	16	0	20	27	0.3	4.6	0.9	95.3	99.6326	84.6398
2014	7	16	0	30	27	0.3	4.6	0.87	91.9	99.6326	82.4616

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	0	40	27	0.3	4.6	0.9	95.8	99.6326	85.2622
2014	7	16	0	50	27	0.3	4.6	0.88	95.3	99.6326	83.3951
2014	7	16	1	0	27	0.3	4.6	0.91	94.6	99.6326	85.8845
2014	7	16	1	10	27	0.3	4.6	0.89	94.9	99.6982	84.0747
2014	7	16	1	20	27	0.3	4.6	0.89	94.2	99.6982	84.0748
2014	7	16	1	30	27	0.3	4.6	0.9	96.3	99.6326	84.951
2014	7	16	1	40	27	0.3	4.6	0.89	94.7	99.6982	84.0748
2014	7	16	1	50	27	0.3	4.6	0.92	93.9	99.6982	87.5
2014	7	16	2	0	27	0.3	4.6	0.89	95.3	99.6982	83.7634
2014	7	16	2	10	27	0.3	4.6	0.9	95.9	99.6982	84.6976
2014	7	16	2	20	27	0.3	4.6	0.87	92.2	99.6982	82.5179
2014	7	16	2	30	27	0.3	4.6	0.89	94.7	99.6982	84.0748
2014	7	16	2	40	27	0.3	4.6	0.87	94.5	99.6982	82.5179
2014	7	16	2	50	27	0.3	4.6	0.9	95.8	99.6982	85.3204
2014	7	16	3	0	27	0.3	4.6	0.9	94	99.6982	85.009
2014	7	16	3	10	27	0.3	4.6	0.89	94.4	99.6982	84.0748
2014	7	16	3	20	27	0.3	4.6	0.92	94.7	99.6982	87.1887
2014	7	16	3	30	27	0.3	4.6	0.88	95.1	99.6982	83.4521
2014	7	16	3	40	27	0.3	4.6	0.88	94.5	99.6982	83.1407
2014	7	16	3	50	27	0.3	4.6	0.9	96.9	99.6982	84.6977
2014	7	16	4	0	27	0.3	4.6	0.88	95.3	99.6982	83.1407
2014	7	16	4	10	27	0.3	4.6	0.89	97.6	99.6982	83.7635
2014	7	16	4	20	27	0.3	4.6	0.9	95.3	99.7638	84.7554
2014	7	16	4	30	27	0.3	4.6	0.89	95.3	99.7638	84.1322
2014	7	16	4	40	27	0.3	4.6	0.91	94.3	99.6982	86.2547
2014	7	16	4	50	27	0.3	4.6	0.91	95.4	99.7638	85.6902
2014	7	16	5	0	27	0.3	4.6	0.89	95.9	99.7638	84.1322
2014	7	16	5	10	27	0.3	4.6	0.89	94.2	99.7638	84.7555
2014	7	16	5	20	27	0.3	4.6	0.92	95.5	99.7638	86.9367
2014	7	16	5	30	27	0.3	4.6	0.92	94.7	99.7638	86.6251
2014	7	16	5	40	27	0.3	4.6	0.9	93.6	99.7638	85.0671
2014	7	16	5	50	27	0.3	4.6	0.9	94.4	99.7638	85.6903
2014	7	16	6	0	27	0.3	4.6	0.88	95.2	99.7638	82.8859
2014	7	16	6	10	27	0.3	4.6	0.88	93.8	99.7638	83.5091
2014	7	16	6	20	27	0.3	4.6	0.88	94.3	99.7638	83.1975
2014	7	16	6	30	27	0.3	4.6	0.91	95.6	99.7638	86.002
2014	7	16	6	40	27	0.3	4.6	0.86	94.2	99.7638	81.3279
2014	7	16	6	50	27	0.3	4.6	0.86	94.4	99.7638	81.328
2014	7	16	7	0	27	0.3	4.6	0.89	95.7	99.7638	84.444
2014	7	16	7	10	27	0.3	4.6	0.85	93.3	99.7638	80.7048
2014	7	16	7	20	27	0.3	4.6	0.87	94.1	99.7638	82.2628
2014	7	16	7	30	27	0.3	4.6	0.88	96	99.7638	83.1976
2014	7	16	7	40	27	0.3	4.6	0.9	94.6	99.7638	85.0672
2014	7	16	7	50	27	0.3	4.6	0.92	94.3	99.7638	87.2484
2014	7	16	8	0	27	0.3	4.6	0.89	94.4	99.7638	84.1324
2014	7	16	8	10	27	0.3	4.6	0.89	94.2	99.7638	84.444

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	8	20	27	0.3	4.6	0.9	95.9	99.7638	84.7556
2014	7	16	8	30	27	0.3	4.6	0.92	97.6	99.7638	86.6251
2014	7	16	8	40	27	0.3	4.6	0.94	96.8	99.7638	89.118
2014	7	16	8	50	27	0.3	4.6	0.85	96.2	99.7638	80.3931
2014	7	16	9	0	27	0.3	4.6	0.87	94.3	99.7638	82.5743
2014	7	16	9	10	27	0.3	4.6	0.93	96.5	99.7638	87.5599
2014	7	16	9	20	27	0.3	4.6	0.9	95.2	99.7638	85.0671
2014	7	16	9	30	27	0.3	4.6	0.93	97.9	99.7638	87.5599
2014	7	16	9	40	27	0.3	4.6	0.91	96	99.7638	86.0018
2014	7	16	9	50	27	0.3	4.6	0.9	98.1	99.7638	85.067
2014	7	16	10	0	27	0.3	4.6	0.88	98.1	99.7638	83.1974
2014	7	16	10	10	27	0.3	4.6	0.91	96.6	99.7638	86.0018
2014	7	16	10	20	27	0.3	4.6	0.93	100.2	99.7638	86.625
2014	7	16	10	30	27	0.3	4.6	0.92	97.6	99.6982	86.566
2014	7	16	10	40	27	0.3	4.6	0.93	97.1	99.7638	87.5597
2014	7	16	10	50	27	0.3	4.6	0.9	99.5	99.6982	84.0749
2014	7	16	11	0	27	0.3	4.6	0.89	97	99.6982	83.7635
2014	7	16	11	10	27	0.3	4.6	0.89	97.8	99.6982	83.7635
2014	7	16	11	20	27	0.3	4.6	0.9	99.9	99.6982	83.7635
2014	7	16	11	30	27	0.3	4.6	0.92	97.6	99.6982	86.566
2014	7	16	11	40	27	0.3	4.6	0.87	97.6	99.6982	81.5837
2014	7	16	11	50	27	0.3	4.6	0.89	97	99.6326	84.0176
2014	7	16	12	0	27	0.3	4.6	0.9	100.1	99.6982	84.0748
2014	7	16	12	10	27	0.3	4.6	0.9	100.3	99.6326	83.7064
2014	7	16	12	20	27	0.3	4.6	0.91	99.6	99.6326	84.6399
2014	7	16	12	30	27	0.3	4.6	0.89	98.5	99.6326	83.0839
2014	7	16	12	40	27	0.3	4.6	0.89	98.7	99.6326	83.7062
2014	7	16	12	50	27	0.3	4.6	0.91	99.6	99.6326	84.6397
2014	7	16	13	0	27	0.3	4.6	0.91	99.2	99.5669	84.893
2014	7	16	13	10	27	0.3	4.6	0.89	100.2	99.5669	83.0272
2014	7	16	13	20	27	0.3	4.6	0.89	100	99.6326	82.7726
2014	7	16	13	30	27	0.3	4.6	0.89	100.6	99.5669	83.0271
2014	7	16	13	40	27	0.3	4.6	0.89	99.5	99.5013	83.2812
2014	7	16	13	50	27	0.3	4.6	0.89	99.5	99.5013	83.592
2014	7	16	14	0	27	0.3	4.6	0.9	100.3	99.5013	83.9027
2014	7	16	14	10	27	0.3	4.6	0.87	98.4	99.4357	81.6717
2014	7	16	14	20	27	0.3	4.6	0.9	99.2	99.4357	84.156
2014	7	16	14	30	27	0.3	4.6	0.87	101.1	99.4357	81.0506
2014	7	16	14	40	27	0.3	4.6	0.87	100.6	99.4357	81.0506
2014	7	16	14	50	27	0.3	4.6	0.89	101.6	99.3701	82.8572
2014	7	16	15	0	27	0.3	4.6	0.9	96.3	99.3701	84.4088
2014	7	16	15	10	27	0.3	4.6	0.88	99.6	99.3701	82.2365
2014	7	16	15	20	27	0.3	4.6	0.89	99.5	99.3701	83.4778
2014	7	16	15	30	27	0.3	4.6	0.88	98.6	99.3045	82.1803
2014	7	16	15	40	27	0.3	4.6	0.89	98.7	99.3701	83.4778
2014	7	16	15	50	27	0.3	4.6	0.93	99.9	99.3045	86.832

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	16	0	27	0.3	4.6	0.93	99.5	99.3045	86.832
2014	7	16	16	10	27	0.3	4.6	0.9	97.3	99.3045	84.3512
2014	7	16	16	20	27	0.3	4.6	0.91	97.6	99.3045	85.5916
2014	7	16	16	30	27	0.3	4.6	0.92	98	99.3045	86.2118
2014	7	16	16	40	27	0.3	4.6	0.86	96.1	99.3045	80.9399
2014	7	16	16	50	27	0.3	4.6	0.89	96.4	99.3045	83.4208
2014	7	16	17	0	27	0.3	4.6	0.89	95.3	99.3045	84.041
2014	7	16	17	10	27	0.3	4.6	0.91	95.2	99.3045	85.5916
2014	7	16	17	20	27	0.3	4.6	0.88	95.3	99.3045	83.1107
2014	7	16	17	30	27	0.3	4.6	0.89	95.3	99.3045	84.041
2014	7	16	17	40	27	0.3	4.6	0.89	95.1	99.3045	84.041
2014	7	16	17	50	27	0.3	4.6	0.92	94.7	99.3045	86.5219
2014	7	16	18	0	27	0.3	4.6	0.88	96	99.3045	82.8005
2014	7	16	18	10	27	0.3	4.6	0.89	94.2	99.3045	84.041
2014	7	16	18	20	27	0.3	4.6	0.88	94.5	99.4357	82.9138
2014	7	16	18	30	27	0.3	4.6	0.88	94.1	99.4357	82.9138
2014	7	16	18	40	27	0.3	4.6	0.93	95.5	99.3045	87.1421
2014	7	16	18	50	27	0.3	4.6	0.91	93.7	99.3701	85.9604
2014	7	16	19	0	27	0.3	4.6	0.88	93.2	99.3701	82.8571
2014	7	16	19	10	27	0.3	4.6	0.89	94.4	99.3701	84.0984
2014	7	16	19	20	27	0.3	4.6	0.89	94	99.3701	84.0984
2014	7	16	19	30	27	0.3	4.6	0.88	94.7	99.3701	82.5468
2014	7	16	19	40	27	0.3	4.6	0.88	94.3	99.3701	83.4777
2014	7	16	19	50	27	0.3	4.6	0.9	93.6	99.3701	84.719
2014	7	16	20	0	27	0.3	4.6	0.89	94.9	99.3701	83.4777
2014	7	16	20	10	27	0.3	4.6	0.89	93.2	99.3701	83.7881
2014	7	16	20	20	27	0.3	4.6	0.9	94.4	99.3045	84.351
2014	7	16	20	30	27	0.3	4.6	0.87	93.7	99.3701	82.2364
2014	7	16	20	40	27	0.3	4.6	0.86	93.7	99.3701	81.3054
2014	7	16	20	50	27	0.3	4.6	0.91	94.6	99.3701	85.3397
2014	7	16	21	0	27	0.3	4.6	0.87	96.5	99.3045	82.1802
2014	7	16	21	10	27	0.3	4.6	0.91	94.6	99.3701	85.3397
2014	7	16	21	20	27	0.3	4.6	0.89	95.5	99.3701	83.4777
2014	7	16	21	30	27	0.3	4.6	0.86	94.6	99.3701	80.6848
2014	7	16	21	40	27	0.3	4.6	0.89	96.3	99.3701	83.788
2014	7	16	21	50	27	0.3	4.6	0.88	94.1	99.3701	83.1674
2014	7	16	22	0	27	0.3	4.6	0.9	93.6	99.3701	84.719
2014	7	16	22	10	27	0.3	4.6	0.89	94	99.3701	84.4087
2014	7	16	22	20	27	0.3	4.6	0.89	94.9	99.3701	84.0984
2014	7	16	22	30	27	0.3	4.6	0.9	95.5	99.3701	84.4087
2014	7	16	22	40	27	0.3	4.6	0.88	95.2	99.3701	82.5467
2014	7	16	22	50	27	0.3	4.6	0.91	95.2	99.3701	85.3397
2014	7	16	23	0	27	0.3	4.6	0.91	95.2	99.3701	85.65
2014	7	16	23	10	27	0.3	4.6	0.9	93.3	99.3701	85.0293
2014	7	16	23	20	27	0.3	4.6	0.89	94	99.3701	84.4087
2014	7	16	23	30	27	0.3	4.6	0.9	94.2	99.3701	84.719

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	23	40	27	0.3	4.6	0.92	94.7	99.3701	87.2016
2014	7	16	23	50	27	0.3	4.6	0.88	95.8	99.3701	83.1674
2014	7	17	0	0	27	0.3	4.6	0.88	95.3	99.3701	82.8571
2014	7	17	0	10	27	0.3	4.6	0.89	95.1	99.3701	83.7881
2014	7	17	0	20	27	0.3	4.6	0.89	93.8	99.3701	84.0984
2014	7	17	0	30	27	0.3	4.6	0.87	94.6	99.3701	81.6158
2014	7	17	0	40	27	0.3	4.6	0.86	94.1	99.3701	81.3055
2014	7	17	0	50	27	0.3	4.6	0.88	93.4	99.3701	82.8571
2014	7	17	1	0	27	0.3	4.6	0.89	96.6	99.3701	83.4778
2014	7	17	1	10	27	0.3	4.6	0.9	95.3	99.3701	84.4088
2014	7	17	1	20	27	0.3	4.6	0.89	94.9	99.3701	84.0985
2014	7	17	1	30	27	0.3	4.6	0.88	94.5	99.3701	82.8572
2014	7	17	1	40	27	0.3	4.6	0.88	94.5	99.3701	82.8572
2014	7	17	1	50	27	0.3	4.6	0.87	94.6	99.3701	81.6159
2014	7	17	2	0	27	0.3	4.6	0.91	94.6	99.3701	85.3398
2014	7	17	2	10	27	0.3	4.6	0.89	93.2	99.4357	84.156
2014	7	17	2	20	27	0.3	4.6	0.87	95.4	99.5669	81.7833
2014	7	17	2	30	27	0.3	4.6	0.89	94.6	99.6326	84.3284
2014	7	17	2	40	27	0.3	4.6	0.88	93.2	99.6326	83.0837
2014	7	17	2	50	27	0.3	4.6	0.89	95.3	99.6326	84.3285
2014	7	17	3	0	27	0.3	4.6	0.86	96.1	99.6982	81.5835
2014	7	17	3	10	27	0.3	4.6	0.91	94.8	99.6982	85.9429
2014	7	17	3	20	27	0.3	4.6	0.9	95.2	99.6982	85.0087
2014	7	17	3	30	27	0.3	4.6	0.92	94.7	99.6982	86.8771
2014	7	17	3	40	27	0.3	4.6	0.9	95.2	99.7638	85.0667
2014	7	17	3	50	27	0.3	4.6	0.9	96.1	99.7638	85.0667
2014	7	17	4	0	27	0.3	4.6	0.91	94.6	99.7638	86.0015
2014	7	17	4	10	27	0.3	4.6	0.89	95.3	99.7638	84.1319
2014	7	17	4	20	27	0.3	4.6	0.9	95.2	99.7638	85.3783
2014	7	17	4	30	27	0.3	4.6	0.91	95	99.7638	85.6899
2014	7	17	4	40	27	0.3	4.6	0.91	95.8	99.7638	85.69
2014	7	17	4	50	27	0.3	4.6	0.89	94.9	99.7638	83.8204
2014	7	17	5	0	27	0.3	4.6	0.89	95.5	99.7638	83.8204
2014	7	17	5	10	27	0.3	4.6	0.9	95	99.7638	85.0668
2014	7	17	5	20	27	0.3	4.6	0.91	94.3	99.8294	86.372
2014	7	17	5	30	27	0.3	4.6	0.9	95.3	99.8294	84.8129
2014	7	17	5	40	27	0.3	4.6	0.9	95	99.8294	85.1247
2014	7	17	5	50	27	0.3	4.6	0.88	95.2	99.8294	82.9421
2014	7	17	6	0	27	0.3	4.6	0.88	94.3	99.8294	83.8775
2014	7	17	6	10	27	0.3	4.6	0.9	94.6	99.8294	85.1248
2014	7	17	6	20	27	0.3	4.6	0.89	95.1	99.8294	83.8775
2014	7	17	6	30	27	0.3	4.6	0.86	95.9	99.8294	81.3831
2014	7	17	6	40	27	0.3	4.6	0.89	93.2	99.8294	84.5012
2014	7	17	6	50	27	0.3	4.6	0.91	93.9	99.8294	86.0603
2014	7	17	7	0	27	0.3	4.6	0.9	95.2	99.8294	85.4367
2014	7	17	7	10	27	0.3	4.6	0.89	94.9	99.8294	84.1894

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	7	20	27	0.3	4.6	0.91	94.5	99.8294	86.6839
2014	7	17	7	30	27	0.3	4.6	0.91	95.2	99.8294	85.7485
2014	7	17	7	40	27	0.3	4.6	0.9	94.2	99.8294	85.4367
2014	7	17	7	50	27	0.3	4.6	0.91	95.2	99.8294	86.0603
2014	7	17	8	0	27	0.3	4.6	0.9	95.9	99.8294	84.813
2014	7	17	8	10	27	0.3	4.6	0.86	93.5	99.8294	81.6949
2014	7	17	8	20	27	0.3	4.6	0.89	95.3	99.8294	83.8776
2014	7	17	8	30	27	0.3	4.6	0.88	96.2	99.8294	83.5658
2014	7	17	8	40	27	0.3	4.6	0.91	97.1	99.8294	85.4366
2014	7	17	8	50	27	0.3	4.6	0.9	94.6	99.8294	85.4366
2014	7	17	9	0	27	0.3	4.6	0.89	94.6	99.8294	84.5012
2014	7	17	9	10	27	0.3	4.6	0.9	93.7	99.8294	85.7484
2014	7	17	9	20	27	0.3	4.6	0.94	96	99.8294	88.5547
2014	7	17	9	30	27	0.3	4.6	0.9	98.6	99.8294	84.8129
2014	7	17	9	40	27	0.3	4.6	0.87	95.4	99.8294	82.6302
2014	7	17	9	50	27	0.3	4.6	0.9	99.7	99.8294	84.1893
2014	7	17	10	0	27	0.3	4.6	0.91	97.9	99.8294	85.4365
2014	7	17	10	10	27	0.3	4.6	0.91	97.1	99.8294	85.4365
2014	7	17	10	20	27	0.3	4.6	0.9	97.5	99.8294	84.8129
2014	7	17	10	30	27	0.3	4.6	0.94	99.7	99.8294	87.931
2014	7	17	10	40	27	0.3	4.6	0.92	101.1	99.8294	85.4364
2014	7	17	10	50	27	0.3	4.6	0.89	94.2	99.6982	84.0747
2014	7	17	11	0	27	0.3	4.6	0.93	99.1	99.6982	87.5
2014	7	17	11	10	27	0.3	4.6	0.96	97.5	99.6982	90.3024
2014	7	17	11	20	27	0.3	4.6	0.95	101.4	99.6982	88.1227
2014	7	17	11	30	27	0.3	4.6	0.92	96.1	99.6982	87.1886
2014	7	17	11	40	27	0.3	4.6	0.91	100.6	99.7638	84.7551
2014	7	17	11	50	27	0.3	4.6	0.87	99.7	99.6982	81.5836
2014	7	17	12	0	27	0.3	4.6	0.9	97.7	99.6326	84.9509
2014	7	17	12	10	27	0.3	4.6	0.89	97.8	99.6982	84.0746
2014	7	17	12	20	27	0.3	4.6	0.92	97.4	99.6982	86.2543
2014	7	17	12	30	27	0.3	4.6	0.93	101.3	99.6982	86.8771
2014	7	17	12	40	27	0.3	4.6	0.81	98	99.6982	75.6671
2014	7	17	12	50	27	0.3	4.6	0.87	93	99.7638	82.5738
2014	7	17	13	0	27	0.3	4.6	0.88	99.9	99.6982	82.2062
2014	7	17	13	10	27	0.3	4.6	0.89	101.6	99.7638	83.1969
2014	7	17	13	20	27	0.3	4.6	0.88	105.1	99.6982	80.9606
2014	7	17	13	30	27	0.3	4.6	0.88	99.2	99.6326	82.4613
2014	7	17	13	40	27	0.3	4.6	0.88	101.6	99.6982	81.8947
2014	7	17	13	50	27	0.3	4.6	0.9	98.6	99.6326	84.0172
2014	7	17	14	0	27	0.3	4.6	0.91	97.6	99.6982	85.9427
2014	7	17	14	10	27	0.3	4.6	0.89	98.5	99.6982	83.1402
2014	7	17	14	20	27	0.3	4.6	0.89	101.1	99.6982	82.8288
2014	7	17	14	30	27	0.3	4.6	0.86	100.1	99.6982	80.3377
2014	7	17	14	40	27	0.3	4.6	0.89	100.8	99.6326	83.0836
2014	7	17	14	50	27	0.3	4.6	0.87	101.3	99.6326	80.9053

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	15	0	27	0.3	4.6	0.91	98.7	99.5669	85.5146
2014	7	17	15	10	27	0.3	4.6	0.9	95.4	99.5669	85.2037
2014	7	17	15	20	27	0.3	4.6	0.88	99	99.5669	82.405
2014	7	17	15	30	27	0.3	4.6	0.87	99.6	99.5669	81.1612
2014	7	17	15	40	27	0.3	4.6	0.84	97.7	99.5013	78.6198
2014	7	17	15	50	27	0.3	4.6	0.84	101.2	99.5669	78.3625
2014	7	17	16	0	27	0.3	4.6	0.88	98.6	99.5669	82.716
2014	7	17	16	10	27	0.3	4.6	0.85	98	99.5669	79.6064
2014	7	17	16	20	27	0.3	4.6	0.85	97.3	99.6326	79.9718
2014	7	17	16	30	27	0.3	4.6	0.9	95.3	99.6326	84.6394
2014	7	17	16	40	27	0.3	4.6	0.88	95.8	99.5669	82.716
2014	7	17	16	50	27	0.3	4.6	0.86	98.8	99.5669	80.5392
2014	7	17	17	0	27	0.3	4.6	0.87	100.5	99.5669	80.8502
2014	7	17	17	10	27	0.3	4.6	0.9	97.2	99.5669	84.2708
2014	7	17	17	20	27	0.3	4.6	0.87	97.6	99.5669	81.4721
2014	7	17	17	30	27	0.3	4.6	0.9	97.4	99.5669	84.2708
2014	7	17	17	40	27	0.3	4.6	0.88	94.7	99.5669	82.716
2014	7	17	17	50	27	0.3	4.6	0.88	98.8	99.5013	82.3488
2014	7	17	18	0	27	0.3	4.6	0.87	99.1	99.5013	81.7273
2014	7	17	18	10	27	0.3	4.6	0.87	95.4	99.5013	82.3488
2014	7	17	18	20	27	0.3	4.6	0.9	96.9	99.5013	84.2133
2014	7	17	18	30	27	0.3	4.6	0.89	94.6	99.5013	84.2133
2014	7	17	18	40	27	0.3	4.6	0.87	92.8	99.5013	82.0381
2014	7	17	18	50	27	0.3	4.6	0.9	94.2	99.5669	85.5146
2014	7	17	19	0	27	0.3	4.6	0.89	94	99.5013	83.9026
2014	7	17	19	10	27	0.3	4.6	0.9	94.4	99.5013	85.1456
2014	7	17	19	20	27	0.3	4.6	0.9	95.4	99.5013	85.1456
2014	7	17	19	30	27	0.3	4.6	0.87	94.6	99.5013	81.7273
2014	7	17	19	40	27	0.3	4.6	0.86	93.9	99.4357	81.361
2014	7	17	19	50	27	0.3	4.6	0.87	92.2	99.5013	82.0381
2014	7	17	20	0	27	0.3	4.6	0.86	93	99.5013	81.7273
2014	7	17	20	10	27	0.3	4.6	0.89	93.2	99.5669	84.2708
2014	7	17	20	20	27	0.3	4.6	0.87	91.1	99.5669	82.405
2014	7	17	20	30	27	0.3	4.6	0.91	93.9	99.5013	86.0778
2014	7	17	20	40	27	0.3	4.6	0.9	95.3	99.5669	84.5818
2014	7	17	20	50	27	0.3	4.6	0.89	94	99.5669	83.9598
2014	7	17	21	0	27	0.3	4.6	0.87	94.1	99.5013	82.3488
2014	7	17	21	10	27	0.3	4.6	0.85	93.5	99.5013	80.4843
2014	7	17	21	20	27	0.3	4.6	0.85	94.2	99.5013	80.1736
2014	7	17	21	30	27	0.3	4.6	0.87	93	99.5013	82.3488
2014	7	17	21	40	27	0.3	4.6	0.88	93.2	99.5669	83.0269
2014	7	17	21	50	27	0.3	4.6	0.86	93.1	99.5669	81.4721
2014	7	17	22	0	27	0.3	4.6	0.86	94.4	99.6326	81.5277
2014	7	17	22	10	27	0.3	4.6	0.9	94.8	99.6326	85.2617
2014	7	17	22	20	27	0.3	4.6	0.9	94.4	99.6326	84.6394
2014	7	17	22	30	27	0.3	4.6	0.89	95.3	99.6326	83.7059

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	22	40	27	0.3	4.6	0.89	94.2	99.6326	84.0171
2014	7	17	22	50	27	0.3	4.6	0.88	94.3	99.6326	83.7059
2014	7	17	23	0	27	0.3	4.6	0.84	95.6	99.6982	79.7149
2014	7	17	23	10	27	0.3	4.6	0.9	95.2	99.6982	85.3198
2014	7	17	23	20	27	0.3	4.6	0.89	95.5	99.6982	83.7629
2014	7	17	23	30	27	0.3	4.6	0.86	94.1	99.6982	81.5832
2014	7	17	23	40	27	0.3	4.6	0.9	94.2	99.6982	85.6312
2014	7	17	23	50	27	0.3	4.6	0.87	95	99.6982	82.206
2014	7	18	0	0	27	0.3	4.6	0.85	94.4	99.6982	80.6491
2014	7	18	0	10	27	0.3	4.6	0.86	93.7	99.6982	81.8946
2014	7	18	0	20	27	0.3	4.6	0.9	94	99.7638	85.0664
2014	7	18	0	30	27	0.3	4.6	0.89	95.1	99.7638	84.1316
2014	7	18	0	40	27	0.3	4.6	0.89	95.3	99.7638	84.4432
2014	7	18	0	50	27	0.3	4.6	0.88	95.3	99.5669	83.027
2014	7	18	1	0	27	0.3	4.6	0.88	93.9	99.7638	83.1968
2014	7	18	1	10	27	0.3	4.6	0.89	93.8	99.7638	84.4432
2014	7	18	1	20	27	0.3	4.6	0.88	94.3	99.7638	83.5085
2014	7	18	1	30	27	0.3	4.6	0.88	93.2	99.7638	83.8201
2014	7	18	1	40	27	0.3	4.6	0.88	96.4	99.7638	83.1969
2014	7	18	1	50	27	0.3	4.6	0.87	94.5	99.7638	82.5737
2014	7	18	2	0	27	0.3	4.6	0.88	94.3	99.7638	83.8201
2014	7	18	2	10	27	0.3	4.6	0.88	95.3	99.7638	83.1969
2014	7	18	2	20	27	0.3	4.6	0.86	95.5	99.7638	81.3273
2014	7	18	2	30	27	0.3	4.6	0.85	93.5	99.7638	80.7042
2014	7	18	2	40	27	0.3	4.6	0.89	95.3	99.8294	84.189
2014	7	18	2	50	27	0.3	4.6	0.89	93.6	99.8294	84.5008
2014	7	18	3	0	27	0.3	4.6	0.88	94.3	99.7638	82.8854
2014	7	18	3	10	27	0.3	4.6	0.88	92.4	99.8294	83.2536
2014	7	18	3	20	27	0.3	4.6	0.86	95.5	99.8294	81.071
2014	7	18	3	30	27	0.3	4.6	0.87	94.8	99.8294	82.0064
2014	7	18	3	40	27	0.3	4.6	0.87	93	99.8294	82.6301
2014	7	18	3	50	27	0.3	4.6	0.89	94.7	99.8294	84.1891
2014	7	18	4	0	27	0.3	4.6	0.9	95.2	99.8294	85.4364
2014	7	18	4	10	27	0.3	4.6	0.89	95.3	99.8294	83.8773
2014	7	18	4	20	27	0.3	4.6	0.88	96.2	99.8294	82.9419
2014	7	18	4	30	27	0.3	4.6	0.89	96.8	99.8294	83.5656
2014	7	18	4	40	27	0.3	4.6	0.89	93	99.8294	84.1892
2014	7	18	4	50	27	0.3	4.6	0.87	94.5	99.8294	82.6302
2014	7	18	5	0	27	0.3	4.6	0.9	94.4	99.8294	85.7483
2014	7	18	5	10	27	0.3	4.6	0.87	94.5	99.8294	82.3184
2014	7	18	5	20	27	0.3	4.6	0.9	95	99.8294	85.1247
2014	7	18	5	30	27	0.3	4.6	0.9	93.8	99.8294	85.4365
2014	7	18	5	40	27	0.3	4.6	0.89	95.7	99.8294	84.5011
2014	7	18	5	50	27	0.3	4.6	0.87	95.4	99.8294	82.6303
2014	7	18	6	0	27	0.3	4.6	0.88	93	99.8294	83.5657
2014	7	18	6	10	27	0.3	4.6	0.89	96.8	99.8294	84.1893

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	6	20	27	0.3	4.6	0.86	93.9	99.8294	81.6949
2014	7	18	6	30	27	0.3	4.6	0.87	95.4	99.8294	82.3185
2014	7	18	6	40	27	0.3	4.6	0.88	95.8	99.8294	82.9421
2014	7	18	6	50	27	0.3	4.6	0.86	94.6	99.8294	81.6949
2014	7	18	7	0	27	0.3	4.6	0.89	93.8	99.8294	84.1894
2014	7	18	7	10	27	0.3	4.6	0.86	91.5	99.8294	82.0067
2014	7	18	7	20	27	0.3	4.6	0.9	94.2	99.895	85.1828
2014	7	18	7	30	27	0.3	4.6	0.88	94.3	99.895	83.3106
2014	7	18	7	40	27	0.3	4.6	0.89	95.7	99.8294	83.8776
2014	7	18	7	50	27	0.3	4.6	0.88	95.2	99.8294	82.9422
2014	7	18	8	0	27	0.3	4.6	0.87	96.3	99.8294	82.3186
2014	7	18	8	10	27	0.3	4.6	0.86	95.5	99.895	81.4385
2014	7	18	8	20	27	0.3	4.6	0.88	96.7	99.895	82.6866
2014	7	18	8	30	27	0.3	4.6	0.89	95.3	99.895	83.9347
2014	7	18	8	40	27	0.3	4.6	0.88	94.3	99.895	83.6226
2014	7	18	8	50	27	0.3	4.6	0.9	93.6	99.895	85.1827
2014	7	18	9	0	27	0.3	4.6	0.9	94.6	99.895	85.1827
2014	7	18	9	10	27	0.3	4.6	0.87	95.6	99.895	82.3745
2014	7	18	9	20	27	0.3	4.6	0.9	95.4	99.8294	85.4366
2014	7	18	9	30	27	0.3	4.6	0.92	97	99.8294	86.3721
2014	7	18	9	40	27	0.3	4.6	0.88	99	99.8294	82.9421
2014	7	18	9	50	27	0.3	4.6	0.9	98.6	99.895	84.8707
2014	7	18	10	0	27	0.3	4.6	0.9	101.3	99.8294	84.1894
2014	7	18	10	10	27	0.3	4.6	0.93	97.5	99.8294	87.6193
2014	7	18	10	20	27	0.3	4.6	0.89	97.9	99.8294	83.5657
2014	7	18	10	30	27	0.3	4.6	0.92	98	99.8294	86.372
2014	7	18	10	40	27	0.3	4.6	0.89	97.6	99.8294	84.1893
2014	7	18	10	50	27	0.3	4.6	0.9	99	99.8294	84.8129
2014	7	18	11	0	27	0.3	4.6	0.91	99.6	99.8294	85.1247
2014	7	18	11	10	27	0.3	4.6	0.89	98.9	99.8294	83.8775
2014	7	18	11	20	27	0.3	4.6	0.91	97.1	99.8294	85.4365
2014	7	18	11	30	27	0.3	4.6	0.87	101.3	99.8294	81.383
2014	7	18	11	40	27	0.3	4.6	0.91	95.2	99.8294	86.372
2014	7	18	11	50	27	0.3	4.6	0.89	100.9	99.8294	82.6302
2014	7	18	12	0	27	0.3	4.6	0.88	102.4	99.8294	82.0066
2014	7	18	12	10	27	0.3	4.6	0.88	100.3	99.8294	82.6302
2014	7	18	12	20	27	0.3	4.6	0.89	99.6	99.8294	83.2538
2014	7	18	12	30	27	0.3	4.6	0.9	99.3	99.8294	84.1892
2014	7	18	12	40	27	0.3	4.6	0.92	101.1	99.8294	86.06
2014	7	18	12	50	27	0.3	4.6	0.87	98.9	99.7638	81.3275
2014	7	18	13	0	27	0.3	4.6	0.9	100.2	99.7638	84.4434
2014	7	18	13	10	27	0.3	4.6	0.87	102.2	99.7638	80.7042
2014	7	18	13	20	27	0.3	4.6	0.87	96.1	99.8294	82.3182
2014	7	18	13	30	27	0.3	4.6	0.87	98.6	99.7638	81.9506
2014	7	18	13	40	27	0.3	4.6	0.86	98.6	99.5669	80.2284
2014	7	18	13	50	27	0.3	4.6	0.89	99.8	99.7638	83.1969

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	14	0	27	0.3	4.6	0.87	101.8	99.7638	80.7041
2014	7	18	14	10	27	0.3	4.6	0.89	101.2	99.7638	83.1969
2014	7	18	14	20	27	0.3	4.6	0.88	100.6	99.7638	81.9505
2014	7	18	14	30	27	0.3	4.6	0.88	102.7	99.6982	81.272
2014	7	18	14	40	27	0.3	4.6	0.86	104.1	99.6982	79.0923
2014	7	18	14	50	27	0.3	4.6	0.88	100.7	99.6326	82.4613
2014	7	18	15	0	27	0.3	4.6	0.95	96.7	99.6982	89.6794
2014	7	18	15	10	27	0.3	4.6	0.87	97.8	99.6982	82.2061
2014	7	18	15	20	27	0.3	4.6	0.9	100.5	99.6982	84.3858
2014	7	18	15	30	27	0.3	4.6	0.88	98.6	99.6982	82.2061
2014	7	18	15	40	27	0.3	4.6	0.85	101	99.6326	78.7272
2014	7	18	15	50	27	0.3	4.6	0.87	98.6	99.6982	81.8947
2014	7	18	16	0	27	0.3	4.6	0.86	97.6	99.6982	81.272
2014	7	18	16	10	27	0.3	4.6	0.87	96.5	99.6326	81.839
2014	7	18	16	20	27	0.3	4.6	0.9	98.4	99.6326	84.0172
2014	7	18	16	30	27	0.3	4.6	0.9	100.7	99.6326	83.706
2014	7	18	16	40	27	0.3	4.6	0.89	96.8	99.5669	83.9599
2014	7	18	16	50	27	0.3	4.6	0.89	98	99.5669	83.649
2014	7	18	17	0	27	0.3	4.6	0.87	100.9	99.5669	80.8503
2014	7	18	17	10	27	0.3	4.6	0.88	96.4	99.5669	82.7161
2014	7	18	17	20	27	0.3	4.6	0.88	99.6	99.5013	82.3489
2014	7	18	17	30	27	0.3	4.6	0.87	96.5	99.6326	81.5278
2014	7	18	17	40	27	0.3	4.6	0.91	96.6	99.6326	85.8843
2014	7	18	17	50	27	0.3	4.6	0.87	98.4	99.5669	81.7832
2014	7	18	18	0	27	0.3	4.6	0.88	97.5	99.5669	82.7161
2014	7	18	18	10	27	0.3	4.6	0.87	94.3	99.5013	82.0382
2014	7	18	18	20	27	0.3	4.6	0.93	97.5	99.5669	87.0696
2014	7	18	18	30	27	0.3	4.6	0.91	96.6	99.6326	85.8843
2014	7	18	18	40	27	0.3	4.6	0.91	96.4	99.5013	85.4565
2014	7	18	18	50	27	0.3	4.6	0.92	98	99.5669	86.1367
2014	7	18	19	0	27	0.3	4.6	0.9	96.9	99.5669	84.5819
2014	7	18	19	10	27	0.3	4.6	0.9	98.4	99.5669	84.5819
2014	7	18	19	20	27	0.3	4.6	0.89	98.3	99.5669	83.338
2014	7	18	19	30	27	0.3	4.6	0.91	97.9	99.5669	85.2038
2014	7	18	19	40	27	0.3	4.6	0.9	97.1	99.6326	84.6396
2014	7	18	19	50	27	0.3	4.6	0.87	96.3	99.5669	81.7832
2014	7	18	20	0	27	0.3	4.6	0.93	97.1	99.5669	87.6915
2014	7	18	20	10	27	0.3	4.6	0.91	97.1	99.5669	85.2038
2014	7	18	20	20	27	0.3	4.6	0.87	95	99.6326	82.1502
2014	7	18	20	30	27	0.3	4.6	0.9	94.8	99.6326	84.6396
2014	7	18	20	40	27	0.3	4.6	0.86	94.8	99.6326	80.9055
2014	7	18	20	50	27	0.3	4.6	0.88	96.6	99.6326	83.0837
2014	7	18	21	0	27	0.3	4.6	0.9	95.6	99.5669	84.8929
2014	7	18	21	10	27	0.3	4.6	0.89	96.1	99.6326	84.3284
2014	7	18	21	20	27	0.3	4.6	0.86	93.3	99.6326	81.5278
2014	7	18	21	30	27	0.3	4.6	0.89	94.6	99.6982	84.3859

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	21	40	27	0.3	4.6	0.9	94.4	99.6982	85.32
2014	7	18	21	50	27	0.3	4.6	0.89	95.7	99.6982	84.0745
2014	7	18	22	0	27	0.3	4.6	0.89	93.8	99.6982	84.6972
2014	7	18	22	10	27	0.3	4.6	0.88	93.8	99.6982	83.7631
2014	7	18	22	20	27	0.3	4.6	0.85	93.5	99.6982	80.6492
2014	7	18	22	30	27	0.3	4.6	0.9	98	99.6982	84.6972
2014	7	18	22	40	27	0.3	4.6	0.88	97.3	99.6982	82.5175
2014	7	18	22	50	27	0.3	4.6	0.88	97.1	99.6982	82.5175
2014	7	18	23	0	27	0.3	4.6	0.88	95.4	99.7638	82.8853
2014	7	18	23	10	27	0.3	4.6	0.9	95.3	99.7638	84.7549
2014	7	18	23	20	27	0.3	4.6	0.87	95.2	99.7638	82.5737
2014	7	18	23	30	27	0.3	4.6	0.9	94.4	99.7638	85.3781
2014	7	18	23	40	27	0.3	4.6	0.9	94	99.7638	85.6897
2014	7	18	23	50	27	0.3	4.6	0.9	95.2	99.7638	85.3781
2014	7	19	0	0	27	0.3	4.6	0.87	95	99.7638	82.5738
2014	7	19	0	10	27	0.3	4.6	0.89	94.9	99.7638	83.8201
2014	7	19	0	20	27	0.3	4.6	0.88	95.3	99.7638	83.197
2014	7	19	0	30	27	0.3	4.6	0.87	93.3	99.7638	82.2622
2014	7	19	0	40	27	0.3	4.6	0.89	93	99.8294	84.5008
2014	7	19	0	50	27	0.3	4.6	0.89	94	99.8294	84.5008
2014	7	19	1	0	27	0.3	4.6	0.86	95.5	99.8294	81.6945
2014	7	19	1	10	27	0.3	4.6	0.88	95.6	99.8294	83.2536
2014	7	19	1	20	27	0.3	4.6	0.87	94.3	99.8294	82.63
2014	7	19	1	30	27	0.3	4.6	0.88	95.1	99.8294	83.5655
2014	7	19	1	40	27	0.3	4.6	0.86	93.5	99.8294	81.6946
2014	7	19	1	50	27	0.3	4.6	0.89	96.3	99.8294	84.5009
2014	7	19	2	0	27	0.3	4.6	0.9	95.3	99.8294	84.8127
2014	7	19	2	10	27	0.3	4.6	0.9	96.9	99.8294	84.8128
2014	7	19	2	20	27	0.3	4.6	0.9	95.3	99.8294	84.8128
2014	7	19	2	30	27	0.3	4.6	0.89	94.2	99.8294	84.1892
2014	7	19	2	40	27	0.3	4.6	0.88	97.7	99.8294	83.2537
2014	7	19	2	50	27	0.3	4.6	0.86	94.8	99.8294	81.0711
2014	7	19	3	0	27	0.3	4.6	0.89	94.5	99.8294	83.8774
2014	7	19	3	10	27	0.3	4.6	0.88	95.2	99.8294	82.942
2014	7	19	3	20	27	0.3	4.6	0.86	96.1	99.8294	81.0711
2014	7	19	3	30	27	0.3	4.6	0.88	94.3	99.8294	83.8774
2014	7	19	3	40	27	0.3	4.6	0.87	95.6	99.8294	82.3184
2014	7	19	3	50	27	0.3	4.6	0.86	94.2	99.8294	81.383
2014	7	19	4	0	27	0.3	4.6	0.87	94.3	99.8294	82.0066
2014	7	19	4	10	27	0.3	4.6	0.89	94.2	99.8294	84.5011
2014	7	19	4	20	27	0.3	4.6	0.89	96.3	99.8294	84.1894
2014	7	19	4	30	27	0.3	4.6	0.89	93	99.895	84.5587
2014	7	19	4	40	27	0.3	4.6	0.89	93	99.895	84.5587
2014	7	19	4	50	27	0.3	4.6	0.91	93.7	99.8294	86.3721
2014	7	19	5	0	27	0.3	4.6	0.87	93.7	99.895	82.3745
2014	7	19	5	10	27	0.3	4.6	0.9	95.2	99.895	85.1828

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	5	20	27	0.3	4.6	0.87	94.1	99.895	82.9986
2014	7	19	5	30	27	0.3	4.6	0.88	94	99.895	83.9347
2014	7	19	5	40	27	0.3	4.6	0.88	94.3	99.895	83.9347
2014	7	19	5	50	27	0.3	4.6	0.89	94.2	99.895	84.8708
2014	7	19	6	0	27	0.3	4.6	0.88	93.6	99.895	83.9348
2014	7	19	6	10	27	0.3	4.6	0.89	95.1	99.895	83.9348
2014	7	19	6	20	27	0.3	4.6	0.89	95.9	99.895	84.2468
2014	7	19	6	30	27	0.3	4.6	0.89	95.1	99.895	83.9348
2014	7	19	6	40	27	0.3	4.6	0.87	93.2	99.895	82.9987
2014	7	19	6	50	27	0.3	4.6	0.91	94.1	99.895	86.743
2014	7	19	7	0	27	0.3	4.6	0.89	92.9	99.895	84.8709
2014	7	19	7	10	27	0.3	4.6	0.87	92.4	99.895	82.3747
2014	7	19	7	20	27	0.3	4.6	0.85	95.3	99.895	80.8146
2014	7	19	7	30	27	0.3	4.6	0.89	93	99.895	84.5589
2014	7	19	7	40	27	0.3	4.6	0.9	95	99.895	84.8709
2014	7	19	7	50	27	0.3	4.6	0.88	94.3	99.895	83.9348
2014	7	19	8	0	27	0.3	4.6	0.87	93.3	99.895	82.3747
2014	7	19	8	10	27	0.3	4.6	0.86	95.3	99.895	81.4386
2014	7	19	8	20	27	0.3	4.6	0.9	92.5	99.895	85.495
2014	7	19	8	30	27	0.3	4.6	0.88	94.7	99.895	82.9988
2014	7	19	8	40	27	0.3	4.6	0.9	95.4	99.895	85.495
2014	7	19	8	50	27	0.3	4.6	0.88	95.1	99.895	83.6228
2014	7	19	9	0	27	0.3	4.6	0.9	97.1	99.895	84.8709
2014	7	19	9	10	27	0.3	4.6	0.9	96.5	99.895	85.1829
2014	7	19	9	20	27	0.3	4.6	0.89	95.7	99.895	83.9348
2014	7	19	9	30	27	0.3	4.6	0.9	99.5	99.895	84.2468
2014	7	19	9	40	27	0.3	4.6	0.88	98.6	99.895	82.6867
2014	7	19	9	50	27	0.3	4.6	0.91	99.6	99.8294	84.8132
2014	7	19	10	0	27	0.3	4.6	0.91	95.8	99.895	85.8069
2014	7	19	10	10	27	0.3	4.6	0.9	99.8	99.8294	84.5013
2014	7	19	10	20	27	0.3	4.6	0.9	99.2	99.8294	84.5013
2014	7	19	10	30	27	0.3	4.6	0.92	99.9	99.8294	85.7486
2014	7	19	10	40	27	0.3	4.6	0.93	97.9	99.8294	87.6194
2014	7	19	10	50	27	0.3	4.6	0.92	98.7	99.8294	86.0604
2014	7	19	11	0	27	0.3	4.6	0.91	96.8	99.8294	85.7486
2014	7	19	11	10	27	0.3	4.6	0.9	99.4	99.8294	84.5013
2014	7	19	11	20	27	0.3	4.6	0.9	101.4	99.8294	83.8777
2014	7	19	11	30	27	0.3	4.6	0.92	99.7	99.8294	86.0603
2014	7	19	11	40	27	0.3	4.6	0.88	99.4	99.8294	82.9422
2014	7	19	11	50	27	0.3	4.6	0.9	101.4	99.8294	83.8776
2014	7	19	12	0	27	0.3	4.6	0.88	103.8	99.8294	81.3831
2014	7	19	12	10	27	0.3	4.6	0.88	100.1	99.8294	82.0067
2014	7	19	12	20	27	0.3	4.6	0.86	99.4	99.8294	81.0713
2014	7	19	12	30	27	0.3	4.6	0.89	100.2	99.7638	83.509
2014	7	19	12	40	27	0.3	4.6	0.9	98.4	99.8294	84.5012
2014	7	19	12	50	27	0.3	4.6	0.91	96.4	99.8294	86.3721

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	13	0	27	0.3	4.6	0.86	99.9	99.8294	80.7595
2014	7	19	13	10	27	0.3	4.6	0.91	99.2	99.7638	85.067
2014	7	19	13	20	27	0.3	4.6	0.89	99.5	99.8294	83.8776
2014	7	19	13	30	27	0.3	4.6	0.89	101.7	99.7638	82.8857
2014	7	19	13	40	27	0.3	4.6	0.89	96.1	99.7638	84.4438
2014	7	19	13	50	27	0.3	4.6	0.9	95	99.7638	85.0669
2014	7	19	14	0	27	0.3	4.6	0.89	97.2	99.7638	83.8205
2014	7	19	14	10	27	0.3	4.6	0.9	99	99.6982	84.6976
2014	7	19	14	20	27	0.3	4.6	0.92	96.9	99.7638	86.9365
2014	7	19	14	30	27	0.3	4.6	0.9	97.5	99.6982	84.6976
2014	7	19	14	40	27	0.3	4.6	0.91	100.2	99.7638	85.0669
2014	7	19	14	50	27	0.3	4.6	0.92	97.8	99.6326	86.8181
2014	7	19	15	0	27	0.3	4.6	0.88	97.5	99.6982	82.8292
2014	7	19	15	10	27	0.3	4.6	0.88	98.6	99.6982	82.5178
2014	7	19	15	20	27	0.3	4.6	0.89	99.3	99.6982	83.4521
2014	7	19	15	30	27	0.3	4.6	0.89	97.2	99.8294	83.8775
2014	7	19	15	40	27	0.3	4.6	0.83	94.5	99.6326	78.4164
2014	7	19	15	50	27	0.3	4.6	0.87	95.4	99.6982	82.2065
2014	7	19	16	0	27	0.3	4.6	0.89	94.2	99.6982	84.0748
2014	7	19	16	10	27	0.3	4.6	0.86	96.1	99.6982	81.5837
2014	7	19	16	20	27	0.3	4.6	0.87	95	99.6326	82.4617
2014	7	19	16	30	27	0.3	4.6	0.87	93.5	99.6326	82.1505
2014	7	19	16	40	27	0.3	4.6	0.87	93.3	99.5669	82.0945
2014	7	19	16	50	27	0.3	4.6	0.87	96.7	99.6982	82.2065
2014	7	19	17	0	27	0.3	4.6	0.89	95.5	99.5669	83.6493
2014	7	19	17	10	27	0.3	4.6	0.86	94	99.5013	80.7955
2014	7	19	17	20	27	0.3	4.6	0.87	95.4	99.6326	81.8393
2014	7	19	17	30	27	0.3	4.6	0.87	95.6	99.5669	82.4055
2014	7	19	17	40	27	0.3	4.6	0.86	93.7	99.5013	81.7278
2014	7	19	17	50	27	0.3	4.6	0.9	94.4	99.5669	84.5823
2014	7	19	18	0	27	0.3	4.6	0.88	94.7	99.5669	82.7165
2014	7	19	18	10	27	0.3	4.6	0.85	94.2	99.6326	80.2835
2014	7	19	18	20	27	0.3	4.6	0.85	93.8	99.5669	80.5398
2014	7	19	18	30	27	0.3	4.6	0.85	95.3	99.5013	80.4848
2014	7	19	18	40	27	0.3	4.6	0.85	92.7	99.5013	80.1741
2014	7	19	18	50	27	0.3	4.6	0.83	95	99.5669	78.674
2014	7	19	19	0	27	0.3	4.6	0.88	94.3	99.6982	82.8293
2014	7	19	19	10	27	0.3	4.6	0.85	95.5	99.5669	80.5398
2014	7	19	19	20	27	0.3	4.6	0.89	97.2	99.5669	83.3384
2014	7	19	19	30	27	0.3	4.6	0.89	91.5	99.4357	84.1564
2014	7	19	19	40	27	0.3	4.6	0.87	94.5	99.5669	82.4056
2014	7	19	19	50	27	0.3	4.6	0.89	97.6	99.6326	84.0176
2014	7	19	20	0	27	0.3	4.6	0.88	95.8	99.5669	82.7165
2014	7	19	20	10	27	0.3	4.6	0.87	96.1	99.6326	82.1506
2014	7	19	20	20	27	0.3	4.6	0.87	96.5	99.5669	82.4056
2014	7	19	20	30	27	0.3	4.6	0.86	93.5	99.6326	81.5282

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	20	40	27	0.3	4.6	0.87	95.6	99.5669	82.0946
2014	7	19	20	50	27	0.3	4.6	0.89	97.2	99.5669	83.6494
2014	7	19	21	0	27	0.3	4.6	0.89	95.1	99.6326	83.7065
2014	7	19	21	10	27	0.3	4.6	0.89	95.9	99.6326	83.7065
2014	7	19	21	20	27	0.3	4.6	0.9	94.4	99.6326	85.2623
2014	7	19	21	30	27	0.3	4.6	0.9	96.1	99.6326	84.9512
2014	7	19	21	40	27	0.3	4.6	0.88	94.7	99.6326	83.3953
2014	7	19	21	50	27	0.3	4.6	0.89	97	99.6326	83.7065
2014	7	19	22	0	27	0.3	4.6	0.87	96.7	99.5669	82.0946
2014	7	19	22	10	27	0.3	4.6	0.91	96	99.6326	85.5735
2014	7	19	22	20	27	0.3	4.6	0.89	94.4	99.6326	84.0176
2014	7	19	22	30	27	0.3	4.6	0.88	95.3	99.6982	83.1407
2014	7	19	22	40	27	0.3	4.6	0.9	96.2	99.6982	85.3204
2014	7	19	22	50	27	0.3	4.6	0.91	95	99.6982	85.9432
2014	7	19	23	0	27	0.3	4.6	0.87	95.6	99.6982	82.518
2014	7	19	23	10	27	0.3	4.6	0.9	95.2	99.6982	85.0091
2014	7	19	23	20	27	0.3	4.6	0.89	96.6	99.6982	83.7635
2014	7	19	23	30	27	0.3	4.6	0.88	96.2	99.6982	83.4521
2014	7	19	23	40	27	0.3	4.6	0.89	96.4	99.6982	83.7635
2014	7	19	23	50	27	0.3	4.6	0.89	95.5	99.6982	84.0749
2014	7	20	0	0	27	0.3	4.6	0.89	94.6	99.6982	84.3863
2014	7	20	0	10	27	0.3	4.6	0.89	94.9	99.6982	84.0749
2014	7	20	0	20	27	0.3	4.6	0.87	94.3	99.6982	82.518
2014	7	20	0	30	27	0.3	4.6	0.91	95.2	99.6982	85.6319
2014	7	20	0	40	27	0.3	4.6	0.87	94.5	99.7638	82.2626
2014	7	20	0	50	27	0.3	4.6	0.87	92.8	99.7638	82.2626
2014	7	20	1	0	27	0.3	4.6	0.88	93.6	99.7638	83.509
2014	7	20	1	10	27	0.3	4.6	0.9	95.9	99.6982	84.6978
2014	7	20	1	20	27	0.3	4.6	0.87	95.2	99.7638	81.951
2014	7	20	1	30	27	0.3	4.6	0.89	92.3	99.7638	84.1323
2014	7	20	1	40	27	0.3	4.6	0.88	94.3	99.7638	82.8859
2014	7	20	1	50	27	0.3	4.6	0.87	94.3	99.7638	82.5743
2014	7	20	2	0	27	0.3	4.6	0.88	95.6	99.7638	83.1975
2014	7	20	2	10	27	0.3	4.6	0.89	94.2	99.7638	84.1323
2014	7	20	2	20	27	0.3	4.6	0.88	94.9	99.7638	83.5091
2014	7	20	2	30	27	0.3	4.6	0.88	93.6	99.7638	83.5091
2014	7	20	2	40	27	0.3	4.6	0.87	95.4	99.7638	81.9511
2014	7	20	2	50	27	0.3	4.6	0.87	95.2	99.7638	82.2628
2014	7	20	3	0	27	0.3	4.6	0.89	93.4	99.7638	84.7556
2014	7	20	3	10	27	0.3	4.6	0.86	94.4	99.7638	81.6396
2014	7	20	3	20	27	0.3	4.6	0.88	95.2	99.7638	82.886
2014	7	20	3	30	27	0.3	4.6	0.9	94.2	99.7638	85.3788
2014	7	20	3	40	27	0.3	4.6	0.88	94.9	99.7638	83.5093
2014	7	20	3	50	27	0.3	4.6	0.9	93.1	99.7638	85.6905
2014	7	20	4	0	27	0.3	4.6	0.93	92.6	99.7638	87.8717
2014	7	20	4	10	27	0.3	4.6	0.88	94.3	99.7638	82.8861

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	4	20	27	0.3	4.6	0.9	94.2	99.7638	85.3789
2014	7	20	4	30	27	0.3	4.6	0.87	93.3	99.7638	82.2629
2014	7	20	4	40	27	0.3	4.6	0.9	92.9	99.7638	85.3789
2014	7	20	4	50	27	0.3	4.6	0.89	96.3	99.7638	84.1326
2014	7	20	5	0	27	0.3	4.6	0.9	95.4	99.7638	85.0674
2014	7	20	5	10	27	0.3	4.6	0.86	95	99.7638	81.6398
2014	7	20	5	20	27	0.3	4.6	0.86	94.6	99.7638	81.6398
2014	7	20	5	30	27	0.3	4.6	0.91	92.1	99.7638	86.0022
2014	7	20	5	40	27	0.3	4.6	0.88	95.4	99.7638	82.8862
2014	7	20	5	50	27	0.3	4.6	0.91	95	99.7638	85.6906
2014	7	20	6	0	27	0.3	4.6	0.88	95.1	99.8294	83.5663
2014	7	20	6	10	27	0.3	4.6	0.9	94.8	99.8294	84.8135
2014	7	20	6	20	27	0.3	4.6	0.89	96.2	99.8294	83.8781
2014	7	20	6	30	27	0.3	4.6	0.9	94.2	99.8294	85.749
2014	7	20	6	40	27	0.3	4.6	0.87	94.3	99.8294	82.6309
2014	7	20	6	50	27	0.3	4.6	0.89	95.7	99.8294	84.5018
2014	7	20	7	0	27	0.3	4.6	0.9	94.4	99.8294	84.8136
2014	7	20	7	10	27	0.3	4.6	0.85	93.5	99.895	80.5029
2014	7	20	7	20	27	0.3	4.6	0.89	95.3	99.8294	84.5018
2014	7	20	7	30	27	0.3	4.6	0.88	92.6	99.8294	83.2546
2014	7	20	7	40	27	0.3	4.6	0.88	92.1	99.8294	83.8782
2014	7	20	7	50	27	0.3	4.6	0.87	90.4	99.8294	82.3191
2014	7	20	8	0	27	0.3	4.6	0.89	91.9	99.8294	84.5018
2014	7	20	8	10	27	0.3	4.6	0.91	94.3	99.8294	86.6845
2014	7	20	8	20	27	0.3	4.6	0.88	94.3	99.895	82.9992
2014	7	20	8	30	27	0.3	4.6	0.88	93	99.8294	83.8782
2014	7	20	8	40	27	0.3	4.6	0.88	94.1	99.8294	83.2545
2014	7	20	8	50	27	0.3	4.6	0.88	94.3	99.8294	82.9427
2014	7	20	9	0	27	0.3	4.6	0.88	94	99.8294	83.8781
2014	7	20	9	10	27	0.3	4.6	0.87	92.6	99.8294	82.3191
2014	7	20	9	20	27	0.3	4.6	0.88	94.3	99.8294	83.2545
2014	7	20	9	30	27	0.3	4.6	0.9	94.4	99.8294	85.749
2014	7	20	9	40	27	0.3	4.6	0.89	95.9	99.8294	84.19
2014	7	20	9	50	27	0.3	4.6	0.87	95.6	99.8294	82.0073
2014	7	20	10	0	27	0.3	4.6	0.89	93.4	99.8294	84.8136
2014	7	20	10	10	27	0.3	4.6	0.89	93.8	99.8294	84.19
2014	7	20	10	20	27	0.3	4.6	0.9	94.4	99.8294	84.8136
2014	7	20	10	30	27	0.3	4.6	0.9	94.8	99.8294	85.1254
2014	7	20	10	40	27	0.3	4.6	0.88	94.7	99.8294	83.2545
2014	7	20	10	50	27	0.3	4.6	0.91	96	99.8294	86.0608
2014	7	20	11	0	27	0.3	4.6	0.87	95.4	99.8294	82.319
2014	7	20	11	10	27	0.3	4.6	0.88	94.9	99.8294	83.5663
2014	7	20	11	20	27	0.3	4.6	0.9	96.1	99.8294	85.1253
2014	7	20	11	30	27	0.3	4.6	0.92	94.1	99.8294	87.6198
2014	7	20	11	40	27	0.3	4.6	0.92	97.2	99.7638	86.937
2014	7	20	11	50	27	0.3	4.6	0.89	98	99.7638	84.1326

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	12	0	27	0.3	4.6	0.88	97	99.7638	83.1978
2014	7	20	12	10	27	0.3	4.6	0.9	95.9	99.6982	84.6981
2014	7	20	12	20	27	0.3	4.6	0.92	99.7	99.7638	86.0022
2014	7	20	12	30	27	0.3	4.6	0.9	101.4	99.7638	83.5094
2014	7	20	12	40	27	0.3	4.6	0.92	100.3	99.7638	86.0022
2014	7	20	12	50	27	0.3	4.6	0.9	98.4	99.7638	84.4442
2014	7	20	13	0	27	0.3	4.6	0.92	98.8	99.7638	86.3138
2014	7	20	13	10	27	0.3	4.6	0.88	94.7	99.7638	83.1977
2014	7	20	13	20	27	0.3	4.6	0.86	95.7	99.7638	81.0165
2014	7	20	13	30	27	0.3	4.6	0.9	95	99.7638	85.0672
2014	7	20	13	40	27	0.3	4.6	0.89	95.7	99.7638	84.444
2014	7	20	13	50	27	0.3	4.6	0.91	94.1	99.7638	86.002
2014	7	20	14	0	27	0.3	4.6	0.9	95	99.7638	85.0672
2014	7	20	14	10	27	0.3	4.6	0.88	96.2	99.7638	82.886
2014	7	20	14	20	27	0.3	4.6	0.9	94.2	99.6982	85.6321
2014	7	20	14	30	27	0.3	4.6	0.9	95	99.6982	85.0093
2014	7	20	14	40	27	0.3	4.6	0.91	96.8	99.6982	85.6321
2014	7	20	14	50	27	0.3	4.6	0.87	95.6	99.6982	81.8954
2014	7	20	15	0	27	0.3	4.6	0.89	102.1	99.6982	82.8296
2014	7	20	15	10	27	0.3	4.6	0.93	99.8	99.6982	86.5663
2014	7	20	15	20	27	0.3	4.6	0.9	98.4	99.6982	84.0752
2014	7	20	15	30	27	0.3	4.6	0.85	97.7	99.6326	80.2838
2014	7	20	15	40	27	0.3	4.6	0.88	100.8	99.6326	81.5285
2014	7	20	15	50	27	0.3	4.6	0.9	100.1	99.6982	84.0751
2014	7	20	16	0	27	0.3	4.6	0.91	98.1	99.6326	85.2626
2014	7	20	16	10	27	0.3	4.6	0.9	98.2	99.6982	84.6979
2014	7	20	16	20	27	0.3	4.6	0.9	95.2	99.6326	84.9514
2014	7	20	16	30	27	0.3	4.6	0.9	97.1	99.6326	84.9514
2014	7	20	16	40	27	0.3	4.6	0.89	97	99.6982	84.0751
2014	7	20	16	50	27	0.3	4.6	0.9	95.2	99.6982	85.0093
2014	7	20	17	0	27	0.3	4.6	0.93	97.3	99.6982	87.189
2014	7	20	17	10	27	0.3	4.6	0.88	98.1	99.6982	83.141
2014	7	20	17	20	27	0.3	4.6	0.87	95.2	99.6982	81.8954
2014	7	20	17	30	27	0.3	4.6	0.9	99.2	99.6982	84.6979
2014	7	20	17	40	27	0.3	4.6	0.89	98.5	99.6982	83.4524
2014	7	20	17	50	27	0.3	4.6	0.91	97.2	99.6982	85.9435
2014	7	20	18	0	27	0.3	4.6	0.91	98.5	99.6982	85.6321
2014	7	20	18	10	27	0.3	4.6	0.9	95.9	99.6982	84.6979
2014	7	20	18	20	27	0.3	4.6	0.91	93.5	99.6982	85.9435
2014	7	20	18	30	27	0.3	4.6	0.88	94.5	99.6982	83.141
2014	7	20	18	40	27	0.3	4.6	0.9	94.4	99.6982	84.6979
2014	7	20	18	50	27	0.3	4.6	0.89	94.2	99.6982	84.6979
2014	7	20	19	0	27	0.3	4.6	0.86	93.7	99.6982	81.8954
2014	7	20	19	10	27	0.3	4.6	0.89	92.3	99.6982	84.0751
2014	7	20	19	20	27	0.3	4.6	0.9	95.5	99.6982	84.6979
2014	7	20	19	30	27	0.3	4.6	0.9	94	99.6982	85.0093

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	19	40	27	0.3	4.6	0.87	95.8	99.6982	82.2068
2014	7	20	19	50	27	0.3	4.6	0.87	94.3	99.6982	82.5181
2014	7	20	20	0	27	0.3	4.6	0.87	94.3	99.6982	82.2068
2014	7	20	20	10	27	0.3	4.6	0.86	93.1	99.6982	81.2726
2014	7	20	20	20	27	0.3	4.6	0.91	94.5	99.6982	86.5662
2014	7	20	20	30	27	0.3	4.6	0.89	94.7	99.6982	83.7637
2014	7	20	20	40	27	0.3	4.6	0.91	93.3	99.6982	86.2548
2014	7	20	20	50	27	0.3	4.6	0.88	93.4	99.6982	83.7637
2014	7	20	21	0	27	0.3	4.6	0.9	94.2	99.6982	85.0092
2014	7	20	21	10	27	0.3	4.6	0.88	93.6	99.6982	83.4523
2014	7	20	21	20	27	0.3	4.6	0.88	95.1	99.6982	83.4523
2014	7	20	21	30	27	0.3	4.6	0.89	95.1	99.6982	84.0751
2014	7	20	21	40	27	0.3	4.6	0.88	94.1	99.6982	83.4523
2014	7	20	21	50	27	0.3	4.6	0.9	94.2	99.6982	85.3206
2014	7	20	22	0	27	0.3	4.6	0.89	95.7	99.6982	84.3865
2014	7	20	22	10	27	0.3	4.6	0.87	93.3	99.6982	82.2067
2014	7	20	22	20	27	0.3	4.6	0.88	95.1	99.6982	83.4523
2014	7	20	22	30	27	0.3	4.6	0.9	93.6	99.6982	85.0092
2014	7	20	22	40	27	0.3	4.6	0.88	94.7	99.6982	83.4523
2014	7	20	22	50	27	0.3	4.6	0.88	94.3	99.6982	82.8295
2014	7	20	23	0	27	0.3	4.6	0.88	96.4	99.6982	82.8295
2014	7	20	23	10	27	0.3	4.6	0.87	95.2	99.6982	82.5181
2014	7	20	23	20	27	0.3	4.6	0.86	93.7	99.6982	81.8954
2014	7	20	23	30	27	0.3	4.6	0.89	95.3	99.6982	84.3865
2014	7	20	23	40	27	0.3	4.6	0.89	95.3	99.7638	84.444
2014	7	20	23	50	27	0.3	4.6	0.88	95.1	99.7638	83.1976
2014	7	21	0	0	27	0.3	4.6	0.89	94	99.7638	84.444
2014	7	21	0	10	27	0.3	4.6	0.9	94.6	99.6982	85.0093
2014	7	21	0	20	27	0.3	4.6	0.89	95.3	99.7638	84.444
2014	7	21	0	30	27	0.3	4.6	0.88	95.1	99.7638	83.5092
2014	7	21	0	40	27	0.3	4.6	0.88	95.2	99.6982	82.8296
2014	7	21	0	50	27	0.3	4.6	0.89	95.3	99.7638	83.8208
2014	7	21	1	0	27	0.3	4.6	0.88	94	99.7638	83.8208
2014	7	21	1	10	27	0.3	4.6	0.92	96.2	99.6982	86.5663
2014	7	21	1	20	27	0.3	4.6	0.89	94.2	99.6982	84.698
2014	7	21	1	30	27	0.3	4.6	0.9	95.6	99.7638	85.0672
2014	7	21	1	40	27	0.3	4.6	0.87	94.3	99.7638	81.9512
2014	7	21	1	50	27	0.3	4.6	0.88	94.7	99.7638	83.1977
2014	7	21	2	0	27	0.3	4.6	0.9	94.2	99.7638	85.6905
2014	7	21	2	10	27	0.3	4.6	0.89	94.7	99.7638	83.8209
2014	7	21	2	20	27	0.3	4.6	0.88	95.4	99.6982	82.8297
2014	7	21	2	30	27	0.3	4.6	0.87	95.6	99.6982	82.5183
2014	7	21	2	40	27	0.3	4.6	0.89	95.1	99.7638	83.8209
2014	7	21	2	50	27	0.3	4.6	0.9	95.5	99.6982	84.6981
2014	7	21	3	0	27	0.3	4.6	0.87	95	99.7638	82.5746
2014	7	21	3	10	27	0.3	4.6	0.9	96.9	99.6982	84.6981

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	3	20	27	0.3	4.6	0.9	94.8	99.6982	84.6981
2014	7	21	3	30	27	0.3	4.6	0.9	95.4	99.6982	85.0095
2014	7	21	3	40	27	0.3	4.6	0.88	94.9	99.6982	83.4526
2014	7	21	3	50	27	0.3	4.6	0.89	95.1	99.6982	84.3868
2014	7	21	4	0	27	0.3	4.6	0.87	94.1	99.6982	82.8299
2014	7	21	4	10	27	0.3	4.6	0.9	96.1	99.6982	84.6982
2014	7	21	4	20	27	0.3	4.6	0.89	95.7	99.6982	84.3868
2014	7	21	4	30	27	0.3	4.6	0.9	92.9	99.6982	85.0097
2014	7	21	4	40	27	0.3	4.6	0.89	96.1	99.6982	84.3869
2014	7	21	4	50	27	0.3	4.6	0.88	94.7	99.6982	82.83
2014	7	21	5	0	27	0.3	4.6	0.88	94.7	99.6982	82.83
2014	7	21	5	10	27	0.3	4.6	0.87	92.6	99.6982	82.2072
2014	7	21	5	20	27	0.3	4.6	0.91	94.4	99.6982	85.9439
2014	7	21	5	30	27	0.3	4.6	0.87	93.2	99.6982	82.5186
2014	7	21	5	40	27	0.3	4.6	0.91	95	99.7638	86.3141
2014	7	21	5	50	27	0.3	4.6	0.88	96.2	99.7638	83.1981
2014	7	21	6	0	27	0.3	4.6	0.89	95.7	99.7638	84.4445
2014	7	21	6	10	27	0.3	4.6	0.91	93.9	99.7638	86.3141
2014	7	21	6	20	27	0.3	4.6	0.88	95.2	99.7638	82.8865
2014	7	21	6	30	27	0.3	4.6	0.89	95.5	99.7638	84.4445
2014	7	21	6	40	27	0.3	4.6	0.87	94.3	99.7638	82.2633
2014	7	21	6	50	27	0.3	4.6	0.89	95.5	99.7638	84.133
2014	7	21	7	0	27	0.3	4.6	0.91	93.5	99.7638	86.3142
2014	7	21	7	10	27	0.3	4.6	0.87	94.1	99.7638	82.2634
2014	7	21	7	20	27	0.3	4.6	0.9	95.3	99.7638	84.7562
2014	7	21	7	30	27	0.3	4.6	0.89	93.2	99.7638	84.4446
2014	7	21	7	40	27	0.3	4.6	0.88	92.1	99.7638	83.1982
2014	7	21	7	50	27	0.3	4.6	0.89	95.3	99.7638	84.4446
2014	7	21	8	0	27	0.3	4.6	0.89	94.2	99.7638	84.4446
2014	7	21	8	10	27	0.3	4.6	0.9	95.6	99.7638	85.3794
2014	7	21	8	20	27	0.3	4.6	0.92	98.6	99.7638	86.3142
2014	7	21	8	30	27	0.3	4.6	0.92	96.8	99.7638	86.6258
2014	7	21	8	40	27	0.3	4.6	0.86	94.1	99.7638	81.6402
2014	7	21	8	50	27	0.3	4.6	0.92	97	99.7638	86.3142
2014	7	21	9	0	27	0.3	4.6	0.92	98.2	99.7638	86.3142
2014	7	21	9	10	27	0.3	4.6	0.91	96.6	99.6982	86.2555
2014	7	21	9	20	27	0.3	4.6	0.9	96.7	99.7638	84.7562
2014	7	21	9	30	27	0.3	4.6	0.92	95.9	99.7638	87.249
2014	7	21	9	40	27	0.3	4.6	0.9	95.6	99.6982	85.3212
2014	7	21	9	50	27	0.3	4.6	0.9	98.6	99.6982	84.0757
2014	7	21	10	0	27	0.3	4.6	0.88	97.3	99.6982	83.1415
2014	7	21	10	10	27	0.3	4.6	0.88	100.7	99.6982	82.5187
2014	7	21	10	20	27	0.3	4.6	0.91	99.1	99.6982	85.6326
2014	7	21	10	30	27	0.3	4.6	0.91	99.3	99.6982	85.3212
2014	7	21	10	40	27	0.3	4.6	0.89	100.4	99.6982	82.83
2014	7	21	10	50	27	0.3	4.6	0.91	98.5	99.6982	85.6325

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	11	0	27	0.3	4.6	0.89	101.3	99.6982	82.83
2014	7	21	11	10	27	0.3	4.6	0.9	99.7	99.6982	84.0755
2014	7	21	11	20	27	0.3	4.6	0.91	96	99.6982	85.9439
2014	7	21	11	30	27	0.3	4.6	0.91	97.5	99.6982	85.6325
2014	7	21	11	40	27	0.3	4.6	0.9	97.6	99.6982	84.3869
2014	7	21	11	50	27	0.3	4.6	0.9	96	99.6982	85.321
2014	7	21	12	0	27	0.3	4.6	0.9	99.9	99.6982	83.7641
2014	7	21	12	10	27	0.3	4.6	0.89	98.7	99.6982	83.4527
2014	7	21	12	20	27	0.3	4.6	0.88	101.4	99.6982	81.8957
2014	7	21	12	30	27	0.3	4.6	0.87	99.5	99.6982	81.5843
2014	7	21	12	40	27	0.3	4.6	0.89	101.6	99.6982	83.1412
2014	7	21	12	50	27	0.3	4.6	0.91	98.7	99.6982	85.3209
2014	7	21	13	0	27	0.3	4.6	0.93	102.9	99.6326	85.574
2014	7	21	13	10	27	0.3	4.6	0.87	102.6	99.6326	80.9063
2014	7	21	13	20	27	0.3	4.6	0.87	97.8	99.6326	81.8398
2014	7	21	13	30	27	0.3	4.6	0.88	100.8	99.6326	81.5286
2014	7	21	13	40	27	0.3	4.6	0.9	100.7	99.5669	84.2718
2014	7	21	13	50	27	0.3	4.6	0.9	102	99.6326	83.7069
2014	7	21	14	0	27	0.3	4.6	0.9	100.3	99.6326	84.0181
2014	7	21	14	10	27	0.3	4.6	0.88	100.8	99.5669	81.4731
2014	7	21	14	20	27	0.3	4.6	0.91	101.8	99.5669	84.5828
2014	7	21	14	30	27	0.3	4.6	0.88	98.6	99.5013	82.0391
2014	7	21	14	40	27	0.3	4.6	0.9	98.4	99.5669	84.2718
2014	7	21	14	50	27	0.3	4.6	0.89	101.3	99.5669	82.406
2014	7	21	15	0	27	0.3	4.6	0.91	102.1	99.5669	83.9608
2014	7	21	15	10	27	0.3	4.6	0.89	97.2	99.5013	83.5928
2014	7	21	15	20	27	0.3	4.6	0.87	98	99.5013	81.4175
2014	7	21	15	30	27	0.3	4.6	0.92	96.5	99.5669	86.7595
2014	7	21	15	40	27	0.3	4.6	0.91	98.1	99.5013	85.1465
2014	7	21	15	50	27	0.3	4.6	0.85	96.5	99.5669	79.6073
2014	7	21	16	0	27	0.3	4.6	0.88	97.7	99.5013	82.9713
2014	7	21	16	10	27	0.3	4.6	0.89	100	99.5013	82.9713
2014	7	21	16	20	27	0.3	4.6	0.91	99.3	99.5013	85.1465
2014	7	21	16	30	27	0.3	4.6	0.86	97.2	99.4357	80.7408
2014	7	21	16	40	27	0.3	4.6	0.9	97.7	99.5013	84.525
2014	7	21	16	50	27	0.3	4.6	0.88	96.8	99.4357	82.9146
2014	7	21	17	0	27	0.3	4.6	0.87	98.6	99.4357	81.6725
2014	7	21	17	10	27	0.3	4.6	0.89	98.2	99.5013	83.5928
2014	7	21	17	20	27	0.3	4.6	0.9	98.4	99.5013	83.9035
2014	7	21	17	30	27	0.3	4.6	0.88	97.5	99.5013	82.9713
2014	7	21	17	40	27	0.3	4.6	0.9	96.7	99.5013	84.2143
2014	7	21	17	50	27	0.3	4.6	0.88	97.5	99.5013	82.3497
2014	7	21	18	0	27	0.3	4.6	0.91	96	99.4357	85.7095
2014	7	21	18	10	27	0.3	4.6	0.89	98.5	99.5013	83.5928
2014	7	21	18	20	27	0.3	4.6	0.9	98	99.5013	84.525
2014	7	21	18	30	27	0.3	4.6	0.89	98	99.4357	83.8463

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	18	40	27	0.3	4.6	0.87	98	99.5013	81.4175
2014	7	21	18	50	27	0.3	4.6	0.92	96.2	99.4357	86.3306
2014	7	21	19	0	27	0.3	4.6	0.92	98	99.5013	86.0788
2014	7	21	19	10	27	0.3	4.6	0.91	98.3	99.4357	85.399
2014	7	21	19	20	27	0.3	4.6	0.89	98	99.5013	83.9035
2014	7	21	19	30	27	0.3	4.6	0.88	95.3	99.5013	82.9712
2014	7	21	19	40	27	0.3	4.6	0.9	97.9	99.4357	84.7779
2014	7	21	19	50	27	0.3	4.6	0.9	96.9	99.5013	84.8357
2014	7	21	20	0	27	0.3	4.6	0.91	96	99.5013	85.768
2014	7	21	20	10	27	0.3	4.6	0.9	96.9	99.5013	84.8357
2014	7	21	20	20	27	0.3	4.6	0.92	97	99.5669	86.4485
2014	7	21	20	30	27	0.3	4.6	0.92	94.7	99.3701	86.2716
2014	7	21	20	40	27	0.3	4.6	0.88	95.8	99.5669	82.7169
2014	7	21	20	50	27	0.3	4.6	0.89	94.2	99.5669	84.5827
2014	7	21	21	0	27	0.3	4.6	0.89	95.9	99.5669	83.9607
2014	7	21	21	10	27	0.3	4.6	0.9	98.6	99.5669	83.9607
2014	7	21	21	20	27	0.3	4.6	0.95	98.6	99.5013	88.5648
2014	7	21	21	30	27	0.3	4.6	0.92	98.4	99.5013	86.3895
2014	7	21	21	40	27	0.3	4.6	0.93	96.5	99.5669	87.3814
2014	7	21	21	50	27	0.3	4.6	0.91	94.1	99.5013	86.3895
2014	7	21	22	0	27	0.3	4.6	0.88	94.3	99.5669	83.0278
2014	7	21	22	10	27	0.3	4.6	0.9	95.5	99.5669	84.5827
2014	7	21	22	20	27	0.3	4.6	0.87	95.2	99.5669	81.784
2014	7	21	22	30	27	0.3	4.6	0.89	94.2	99.5669	84.2717
2014	7	21	22	40	27	0.3	4.6	0.87	96.3	99.5669	82.0949
2014	7	21	22	50	27	0.3	4.6	0.88	93.8	99.5013	83.282
2014	7	21	23	0	27	0.3	4.6	0.87	94.5	99.5669	82.4059
2014	7	21	23	10	27	0.3	4.6	0.9	97.7	99.6326	84.6403
2014	7	21	23	20	27	0.3	4.6	0.88	94.9	99.5669	83.3388
2014	7	21	23	30	27	0.3	4.6	0.88	94.3	99.5669	82.7169
2014	7	21	23	40	27	0.3	4.6	0.84	94.5	99.5669	78.9853
2014	7	21	23	50	27	0.3	4.6	0.87	96.5	99.5669	81.784
2014	7	22	0	0	27	0.3	4.6	0.88	94.3	99.6326	83.7068
2014	7	22	0	10	27	0.3	4.6	0.89	94.7	99.6326	83.7068
2014	7	22	0	20	27	0.3	4.6	0.92	95.9	99.6326	86.8186
2014	7	22	0	30	27	0.3	4.6	0.9	95.9	99.6326	84.6404
2014	7	22	0	40	27	0.3	4.6	0.88	94.9	99.6326	83.3957
2014	7	22	0	50	27	0.3	4.6	0.89	93	99.6326	84.3292
2014	7	22	1	0	27	0.3	4.6	0.9	94.4	99.6326	84.6404
2014	7	22	1	10	27	0.3	4.6	0.87	91.5	99.6982	82.8297
2014	7	22	1	20	27	0.3	4.6	0.9	93.1	99.6982	85.0095
2014	7	22	1	30	27	0.3	4.6	0.9	94.6	99.6982	85.3209
2014	7	22	1	40	27	0.3	4.6	0.89	95.1	99.6982	84.0753
2014	7	22	1	50	27	0.3	4.6	0.89	95.1	99.6982	84.0753
2014	7	22	2	0	27	0.3	4.6	0.89	93.4	99.6982	84.6981
2014	7	22	2	10	27	0.3	4.6	0.9	94	99.6982	85.3209

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	2	20	27	0.3	4.6	0.87	94.3	99.6982	82.207
2014	7	22	2	30	27	0.3	4.6	0.89	94.6	99.6982	84.3867
2014	7	22	2	40	27	0.3	4.6	0.9	94.4	99.6982	84.6982
2014	7	22	2	50	27	0.3	4.6	0.87	93.5	99.6982	82.5184
2014	7	22	3	0	27	0.3	4.6	0.88	93.4	99.6982	83.4526
2014	7	22	3	10	27	0.3	4.6	0.89	95.1	99.6982	84.3868
2014	7	22	3	20	27	0.3	4.6	0.9	93.1	99.6982	85.321
2014	7	22	3	30	27	0.3	4.6	0.87	97.3	99.6982	82.2071
2014	7	22	3	40	27	0.3	4.6	0.92	94.1	99.6982	86.878
2014	7	22	3	50	27	0.3	4.6	0.91	94.3	99.6982	86.2552
2014	7	22	4	0	27	0.3	4.6	0.88	94.3	99.6982	83.1413
2014	7	22	4	10	27	0.3	4.6	0.89	93	99.6982	84.3869
2014	7	22	4	20	27	0.3	4.6	0.89	95.3	99.6982	84.3869
2014	7	22	4	30	27	0.3	4.6	0.89	94.4	99.6982	84.0755
2014	7	22	4	40	27	0.3	4.6	0.89	94.6	99.6982	84.3869
2014	7	22	4	50	27	0.3	4.6	0.9	94.8	99.6982	84.6983
2014	7	22	5	0	27	0.3	4.6	0.89	94.2	99.6982	84.387
2014	7	22	5	10	27	0.3	4.6	0.88	93.2	99.6982	83.7642
2014	7	22	5	20	27	0.3	4.6	0.91	94.1	99.6982	86.2553
2014	7	22	5	30	27	0.3	4.6	0.89	95.7	99.6982	84.387
2014	7	22	5	40	27	0.3	4.6	0.91	95.2	99.6982	85.944
2014	7	22	5	50	27	0.3	4.6	0.89	93.2	99.6982	84.6984
2014	7	22	6	0	27	0.3	4.6	0.89	93.4	99.6982	84.387
2014	7	22	6	10	27	0.3	4.6	0.86	94.2	99.6982	81.2731
2014	7	22	6	20	27	0.3	4.6	0.89	93.8	99.6982	84.3871
2014	7	22	6	30	27	0.3	4.6	0.89	93.2	99.6982	84.3871
2014	7	22	6	40	27	0.3	4.6	0.91	94.3	99.6982	86.5668
2014	7	22	6	50	27	0.3	4.6	0.87	95.4	99.6982	82.2074
2014	7	22	7	0	27	0.3	4.6	0.89	92.8	99.6982	84.0758
2014	7	22	7	10	27	0.3	4.6	0.9	96.1	99.6982	84.6985
2014	7	22	7	20	27	0.3	4.6	0.92	92.5	99.6982	87.1897
2014	7	22	7	30	27	0.3	4.6	0.87	94.5	99.6982	82.5188
2014	7	22	7	40	27	0.3	4.6	0.94	95.6	99.6982	88.7466
2014	7	22	7	50	27	0.3	4.6	0.89	93.6	99.7638	84.4446
2014	7	22	8	0	27	0.3	4.6	0.88	96.4	99.6982	83.1416
2014	7	22	8	10	27	0.3	4.6	0.92	94.7	99.6982	86.5669
2014	7	22	8	20	27	0.3	4.6	0.88	95.5	99.6982	83.453
2014	7	22	8	30	27	0.3	4.6	0.88	94	99.6982	83.7644
2014	7	22	8	40	27	0.3	4.6	0.89	95.9	99.6982	84.3871
2014	7	22	8	50	27	0.3	4.6	0.9	94	99.6982	85.6327
2014	7	22	9	0	27	0.3	4.6	0.91	94.5	99.6982	86.2555
2014	7	22	9	10	27	0.3	4.6	0.88	97.9	99.6982	83.1415
2014	7	22	9	20	27	0.3	4.6	0.89	99.1	99.6982	83.4529
2014	7	22	9	30	27	0.3	4.6	0.92	99	99.6982	86.5668
2014	7	22	9	40	27	0.3	4.6	0.9	98.2	99.6982	84.6985
2014	7	22	9	50	27	0.3	4.6	0.88	98.4	99.6982	82.5187

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	10	0	27	0.3	4.6	0.93	100.5	99.6982	87.1896
2014	7	22	10	10	27	0.3	4.6	0.91	96	99.6982	86.2554
2014	7	22	10	20	27	0.3	4.6	0.93	97.7	99.6982	87.1896
2014	7	22	10	30	27	0.3	4.6	0.9	100.2	99.6982	84.3871
2014	7	22	10	40	27	0.3	4.6	0.88	100.8	99.6982	81.5845
2014	7	22	10	50	27	0.3	4.6	0.89	100	99.6982	82.8301
2014	7	22	11	0	27	0.3	4.6	0.93	95.9	99.6982	88.1237
2014	7	22	11	10	27	0.3	4.6	0.9	95.7	99.6982	84.6984
2014	7	22	11	20	27	0.3	4.6	0.92	100.9	99.6326	85.8854
2014	7	22	11	30	27	0.3	4.6	0.91	101.8	99.6982	84.6984
2014	7	22	11	40	27	0.3	4.6	0.92	99	99.6326	86.5078
2014	7	22	11	50	27	0.3	4.6	0.91	100.4	99.6982	84.6983
2014	7	22	12	0	27	0.3	4.6	0.9	97.6	99.6326	84.3295
2014	7	22	12	10	27	0.3	4.6	0.87	98.5	99.6326	81.5289
2014	7	22	12	20	27	0.3	4.6	0.9	101.2	99.6326	83.396
2014	7	22	12	30	27	0.3	4.6	0.9	100.3	99.6326	84.0183
2014	7	22	12	40	27	0.3	4.6	0.9	100.5	99.6326	83.7071
2014	7	22	12	50	27	0.3	4.6	0.9	100.9	99.5669	83.65
2014	7	22	13	0	27	0.3	4.6	0.88	97.5	99.6326	83.0847
2014	7	22	13	10	27	0.3	4.6	0.89	100	99.6326	82.7735
2014	7	22	13	20	27	0.3	4.6	0.87	97.2	99.5669	81.7842
2014	7	22	13	30	27	0.3	4.6	0.9	100	99.5669	84.2719
2014	7	22	13	40	27	0.3	4.6	0.89	102.2	99.5669	82.0951
2014	7	22	13	50	27	0.3	4.6	0.87	101.8	99.5013	80.4853
2014	7	22	14	0	27	0.3	4.6	0.89	100.9	99.5669	82.406
2014	7	22	14	10	27	0.3	4.6	0.85	99.8	99.5669	79.6073
2014	7	22	14	20	27	0.3	4.6	0.87	100.8	99.5013	81.1068
2014	7	22	14	30	27	0.3	4.6	0.86	95.5	99.4357	81.362
2014	7	22	14	40	27	0.3	4.6	0.84	101.5	99.4357	77.9461
2014	7	22	14	50	27	0.3	4.6	0.86	98.6	99.4357	80.4304
2014	7	22	15	0	27	0.3	4.6	0.89	100.9	99.4357	82.2936
2014	7	22	15	10	27	0.3	4.6	0.87	102	99.4357	80.4304
2014	7	22	15	20	27	0.3	4.6	0.87	101.1	99.4357	80.7409
2014	7	22	15	30	27	0.3	4.6	0.86	102.1	99.5013	79.8638
2014	7	22	15	40	27	0.3	4.6	0.86	97	99.3701	80.9961
2014	7	22	15	50	27	0.3	4.6	0.85	95.5	99.5013	80.1746
2014	7	22	16	0	27	0.3	4.6	0.9	96.5	99.4357	84.4674
2014	7	22	16	10	27	0.3	4.6	0.85	96.2	99.3701	79.7548
2014	7	22	16	20	27	0.3	4.6	0.88	95.4	99.4357	82.6042
2014	7	22	16	30	27	0.3	4.6	0.89	92.3	99.4357	83.8464
2014	7	22	16	40	27	0.3	4.6	0.87	94.5	99.4357	82.2937
2014	7	22	16	50	27	0.3	4.6	0.89	95.5	99.4357	83.8464
2014	7	22	17	0	27	0.3	4.6	0.87	96	99.3701	82.2375
2014	7	22	17	10	27	0.3	4.6	0.93	94.8	99.3045	87.7634
2014	7	22	17	20	27	0.3	4.6	0.88	94.1	99.4357	82.9148
2014	7	22	17	30	27	0.3	4.6	0.89	94.2	99.4357	84.4675

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	17	40	27	0.3	4.6	0.87	98.6	99.3701	81.6168
2014	7	22	17	50	27	0.3	4.6	0.89	95.3	99.3701	83.4788
2014	7	22	18	0	27	0.3	4.6	0.88	94.1	99.3701	82.8581
2014	7	22	18	10	27	0.3	4.6	0.9	94.8	99.3701	84.4098
2014	7	22	18	20	27	0.3	4.6	0.88	95.5	99.3045	83.1116
2014	7	22	18	30	27	0.3	4.6	0.91	93.3	99.3701	85.6511
2014	7	22	18	40	27	0.3	4.6	0.86	95	99.3045	81.2509
2014	7	22	18	50	27	0.3	4.6	0.88	95.6	99.3701	82.8581
2014	7	22	19	0	27	0.3	4.6	0.88	95.6	99.3701	82.8581
2014	7	22	19	10	27	0.3	4.6	0.88	94.3	99.3045	82.8015
2014	7	22	19	20	27	0.3	4.6	0.88	94.5	99.3701	83.1685
2014	7	22	19	30	27	0.3	4.6	0.89	94	99.3701	84.4098
2014	7	22	19	40	27	0.3	4.6	0.88	96.2	99.3045	82.8015
2014	7	22	19	50	27	0.3	4.6	0.86	93.3	99.3701	80.9962
2014	7	22	20	0	27	0.3	4.6	0.87	94.1	99.3701	82.5478
2014	7	22	20	10	27	0.3	4.6	0.88	94.3	99.3701	82.8581
2014	7	22	20	20	27	0.3	4.6	0.9	94.2	99.3701	84.7201
2014	7	22	20	30	27	0.3	4.6	0.9	94.2	99.3701	85.3408
2014	7	22	20	40	27	0.3	4.6	0.89	94.9	99.3701	83.7891
2014	7	22	20	50	27	0.3	4.6	0.88	94.3	99.4357	82.9148
2014	7	22	21	0	27	0.3	4.6	0.88	94.5	99.4357	82.9148
2014	7	22	21	10	27	0.3	4.6	0.91	95.4	99.4357	85.7096
2014	7	22	21	20	27	0.3	4.6	0.88	94.5	99.4357	82.9148
2014	7	22	21	30	27	0.3	4.6	0.91	95.2	99.4357	85.7096
2014	7	22	21	40	27	0.3	4.6	0.9	96.7	99.4357	84.1569
2014	7	22	21	50	27	0.3	4.6	0.9	95	99.4357	84.4675
2014	7	22	22	0	27	0.3	4.6	0.91	95.6	99.5013	85.7682
2014	7	22	22	10	27	0.3	4.6	0.9	94.8	99.5013	84.8359
2014	7	22	22	20	27	0.3	4.6	0.9	95	99.5013	84.5251
2014	7	22	22	30	27	0.3	4.6	0.88	95.8	99.5013	82.9714
2014	7	22	22	40	27	0.3	4.6	0.89	92.9	99.5013	84.5252
2014	7	22	22	50	27	0.3	4.6	0.88	95.2	99.5669	82.7117
2014	7	22	23	0	27	0.3	4.6	0.9	94.6	99.5669	84.5829
2014	7	22	23	10	27	0.3	4.6	0.88	96.4	99.5669	83.339
2014	7	22	23	20	27	0.3	4.6	0.86	94.4	99.5669	81.4732
2014	7	22	23	30	27	0.3	4.6	0.9	93.4	99.5669	84.8938
2014	7	22	23	40	27	0.3	4.6	0.86	93.5	99.5669	81.7842
2014	7	22	23	50	27	0.3	4.6	0.88	95.1	99.5669	83.339
2014	7	23	0	0	27	0.3	4.6	0.88	95.1	99.5669	83.0281
2014	7	23	0	10	27	0.3	4.6	0.9	95	99.5669	84.8939
2014	7	23	0	20	27	0.3	4.6	0.87	94.1	99.5669	82.0952
2014	7	23	0	30	27	0.3	4.6	0.93	95.7	99.5669	87.3816
2014	7	23	0	40	27	0.3	4.6	0.87	94.1	99.5669	82.7171
2014	7	23	0	50	27	0.3	4.6	0.88	94.3	99.5669	83.6501
2014	7	23	1	0	27	0.3	4.6	0.87	93.7	99.5669	82.0952
2014	7	23	1	10	27	0.3	4.6	0.87	93.9	99.5669	82.4062

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	1	20	27	0.3	4.6	0.9	94.4	99.6326	84.9519
2014	7	23	1	30	27	0.3	4.6	0.89	94.2	99.6326	84.6407
2014	7	23	1	40	27	0.3	4.6	0.89	94.2	99.6326	84.6407
2014	7	23	1	50	27	0.3	4.6	0.88	93.2	99.6326	83.396
2014	7	23	2	0	27	0.3	4.6	0.86	93.5	99.6326	81.8401
2014	7	23	2	10	27	0.3	4.6	0.9	95	99.6326	84.9519
2014	7	23	2	20	27	0.3	4.6	0.91	95.2	99.6326	85.8855
2014	7	23	2	30	27	0.3	4.6	0.89	93.8	99.6326	84.3296
2014	7	23	2	40	27	0.3	4.6	0.91	93.3	99.6326	85.8855
2014	7	23	2	50	27	0.3	4.6	0.9	95.3	99.6326	84.6408
2014	7	23	3	0	27	0.3	4.6	0.89	95.3	99.6326	84.3297
2014	7	23	3	10	27	0.3	4.6	0.9	93.8	99.6326	84.952
2014	7	23	3	20	27	0.3	4.6	0.89	93.2	99.6326	84.3297
2014	7	23	3	30	27	0.3	4.6	0.89	94	99.6326	84.3297
2014	7	23	3	40	27	0.3	4.6	0.88	94	99.6326	83.7074
2014	7	23	3	50	27	0.3	4.6	0.87	93.7	99.6326	82.7739
2014	7	23	4	0	27	0.3	4.6	0.89	95.3	99.6326	84.0186
2014	7	23	4	10	27	0.3	4.6	0.89	93.8	99.6326	84.3298
2014	7	23	4	20	27	0.3	4.6	0.88	94.5	99.6326	83.3963
2014	7	23	4	30	27	0.3	4.6	0.9	93.7	99.6326	85.5746
2014	7	23	4	40	27	0.3	4.6	0.9	93.5	99.6326	85.5746
2014	7	23	4	50	27	0.3	4.6	0.88	95.1	99.6326	83.3963
2014	7	23	5	0	27	0.3	4.6	0.89	96.3	99.6326	84.3299
2014	7	23	5	10	27	0.3	4.6	0.87	93.9	99.6326	82.774
2014	7	23	5	20	27	0.3	4.6	0.9	93.8	99.6326	84.9523
2014	7	23	5	30	27	0.3	4.6	0.91	93.1	99.6326	85.8859
2014	7	23	5	40	27	0.3	4.6	0.88	95.6	99.6326	82.7741
2014	7	23	5	50	27	0.3	4.6	0.89	94.9	99.6982	84.0761
2014	7	23	6	0	27	0.3	4.6	0.88	93.6	99.6982	83.7647
2014	7	23	6	10	27	0.3	4.6	0.87	95.6	99.6982	81.8964
2014	7	23	6	20	27	0.3	4.6	0.86	95.7	99.6982	81.2736
2014	7	23	6	30	27	0.3	4.6	0.88	93.2	99.6982	83.142
2014	7	23	6	40	27	0.3	4.6	0.88	93.8	99.6982	83.4534
2014	7	23	6	50	27	0.3	4.6	0.9	95	99.6982	85.3218
2014	7	23	7	0	27	0.3	4.6	0.89	93.6	99.6982	84.699
2014	7	23	7	10	27	0.3	4.6	0.86	96.3	99.6982	81.5851
2014	7	23	7	20	27	0.3	4.6	0.89	94.4	99.6982	84.3876
2014	7	23	7	30	27	0.3	4.6	0.89	93.8	99.6982	84.3876
2014	7	23	7	40	27	0.3	4.6	0.88	95.2	99.6982	82.8307
2014	7	23	7	50	27	0.3	4.6	0.85	94.2	99.6982	80.0281
2014	7	23	8	0	27	0.3	4.6	0.9	94.2	99.6982	85.3218
2014	7	23	8	10	27	0.3	4.6	0.9	94.2	99.6982	85.6332
2014	7	23	8	20	27	0.3	4.6	0.85	95.3	99.6982	80.6509
2014	7	23	8	30	27	0.3	4.6	0.88	93.2	99.6982	83.7648
2014	7	23	8	40	27	0.3	4.6	0.93	95.1	99.6982	87.813
2014	7	23	8	50	27	0.3	4.6	0.89	95.7	99.6982	83.7648

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	9	0	27	0.3	4.6	0.89	94.2	99.6982	84.699
2014	7	23	9	10	27	0.3	4.6	0.9	95.2	99.6982	85.3218
2014	7	23	9	20	27	0.3	4.6	0.9	94.4	99.6982	85.0104
2014	7	23	9	30	27	0.3	4.6	0.9	96.1	99.6982	84.699
2014	7	23	9	40	27	0.3	4.6	0.89	96.4	99.6982	83.7648
2014	7	23	9	50	27	0.3	4.6	0.92	95.1	99.6982	86.8787
2014	7	23	10	0	27	0.3	4.6	0.9	95.4	99.6982	85.3217
2014	7	23	10	10	27	0.3	4.6	0.9	94	99.6982	85.6331
2014	7	23	10	20	27	0.3	4.6	0.92	95.9	99.6982	86.8787
2014	7	23	10	30	27	0.3	4.6	0.91	97.7	99.6982	85.6331
2014	7	23	10	40	27	0.3	4.6	0.9	98.8	99.6326	84.0189
2014	7	23	10	50	27	0.3	4.6	0.91	98	99.6326	85.8859
2014	7	23	11	0	27	0.3	4.6	0.91	100.6	99.6326	84.9523
2014	7	23	11	10	27	0.3	4.6	0.9	98.6	99.6326	84.33
2014	7	23	11	20	27	0.3	4.6	0.92	97.8	99.6326	86.5082
2014	7	23	11	30	27	0.3	4.6	0.9	98.6	99.6326	84.3299
2014	7	23	11	40	27	0.3	4.6	0.92	100.1	99.6326	85.8858
2014	7	23	11	50	27	0.3	4.6	0.92	96.4	99.6326	86.5082
2014	7	23	12	0	27	0.3	4.6	0.88	99	99.6326	82.4628
2014	7	23	12	10	27	0.3	4.6	0.9	99.4	99.6326	84.6411
2014	7	23	12	20	27	0.3	4.6	0.89	100.4	99.6326	83.3964
2014	7	23	12	30	27	0.3	4.6	0.95	94.2	99.6326	89.62
2014	7	23	12	40	27	0.3	4.6	0.92	100.9	99.6326	85.8858
2014	7	23	12	50	27	0.3	4.6	0.94	101.1	99.6326	87.1305
2014	7	23	13	0	27	0.3	4.6	0.92	96.9	99.6326	86.8193
2014	7	23	13	10	27	0.3	4.6	0.88	101.8	99.6326	81.8403
2014	7	23	13	20	27	0.3	4.6	0.9	96.5	99.6326	84.9521
2014	7	23	13	30	27	0.3	4.6	0.86	99.7	99.6326	80.2844
2014	7	23	13	40	27	0.3	4.6	0.89	103.2	99.6326	82.4626
2014	7	23	13	50	27	0.3	4.6	0.9	98.2	99.6326	84.6409
2014	7	23	14	0	27	0.3	4.6	0.92	98	99.6326	86.5079
2014	7	23	14	10	27	0.3	4.6	0.91	99	99.6326	84.952
2014	7	23	14	20	27	0.3	4.6	0.91	98.5	99.6326	85.5744
2014	7	23	14	30	27	0.3	4.6	0.91	97.5	99.6326	85.5743
2014	7	23	14	40	27	0.3	4.6	0.92	99.5	99.6326	85.8855
2014	7	23	14	50	27	0.3	4.6	0.9	101.1	99.6326	84.0184
2014	7	23	15	0	27	0.3	4.6	0.93	95.3	99.6326	87.4414
2014	7	23	15	10	27	0.3	4.6	0.91	96.8	99.6326	85.8855
2014	7	23	15	20	27	0.3	4.6	0.92	96.9	99.5669	86.7599
2014	7	23	15	30	27	0.3	4.6	0.9	99.6	99.6326	84.3296
2014	7	23	15	40	27	0.3	4.6	0.89	99.5	99.5669	83.6502
2014	7	23	15	50	27	0.3	4.6	0.9	95.2	99.5669	85.205
2014	7	23	16	0	27	0.3	4.6	0.89	97	99.5669	83.3392
2014	7	23	16	10	27	0.3	4.6	0.89	94.9	99.6326	84.0184
2014	7	23	16	20	27	0.3	4.6	0.9	97.2	99.5669	84.2721
2014	7	23	16	30	27	0.3	4.6	0.88	95.4	99.5669	82.7173

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	16	40	27	0.3	4.6	0.9	98.8	99.5669	84.2721
2014	7	23	16	50	27	0.3	4.6	0.91	95.2	99.5013	86.0792
2014	7	23	17	0	27	0.3	4.6	0.92	94.7	99.5669	87.3818
2014	7	23	17	10	27	0.3	4.6	0.91	96	99.5013	85.4577
2014	7	23	17	20	27	0.3	4.6	0.93	93	99.5013	87.9437
2014	7	23	17	30	27	0.3	4.6	0.89	93.8	99.5013	84.2146
2014	7	23	17	40	27	0.3	4.6	0.91	96	99.5669	85.827
2014	7	23	17	50	27	0.3	4.6	0.87	92	99.4357	81.9834
2014	7	23	18	0	27	0.3	4.6	0.89	95.9	99.5013	83.9039
2014	7	23	18	10	27	0.3	4.6	0.9	96.7	99.5669	84.5831
2014	7	23	18	20	27	0.3	4.6	0.88	96.4	99.5669	83.0283
2014	7	23	18	30	27	0.3	4.6	0.9	97.1	99.5669	84.5831
2014	7	23	18	40	27	0.3	4.6	0.93	96.5	99.5669	87.6928
2014	7	23	18	50	27	0.3	4.6	0.92	95.7	99.5669	87.0708
2014	7	23	19	0	27	0.3	4.6	0.89	96.1	99.5669	84.2721
2014	7	23	19	10	27	0.3	4.6	0.88	96.4	99.5669	83.3392
2014	7	23	19	20	27	0.3	4.6	0.92	95.8	99.5669	86.4489
2014	7	23	19	30	27	0.3	4.6	0.9	96.7	99.5669	84.5831
2014	7	23	19	40	27	0.3	4.6	0.94	93	99.5669	88.6256
2014	7	23	19	50	27	0.3	4.6	0.91	95	99.5669	85.516
2014	7	23	20	0	27	0.3	4.6	0.9	95	99.5669	84.894
2014	7	23	20	10	27	0.3	4.6	0.91	95	99.5669	85.8269
2014	7	23	20	20	27	0.3	4.6	0.89	94.2	99.6326	84.3295
2014	7	23	20	30	27	0.3	4.6	0.91	95.6	99.5669	86.1379
2014	7	23	20	40	27	0.3	4.6	0.88	96.4	99.6326	83.396
2014	7	23	20	50	27	0.3	4.6	0.88	94.9	99.6326	82.7736
2014	7	23	21	0	27	0.3	4.6	0.89	94	99.6326	84.6407
2014	7	23	21	10	27	0.3	4.6	0.88	95.2	99.6326	82.7736
2014	7	23	21	20	27	0.3	4.6	0.91	96	99.6326	85.5742
2014	7	23	21	30	27	0.3	4.6	0.9	94.6	99.6326	85.2631
2014	7	23	21	40	27	0.3	4.6	0.88	93	99.6326	83.7072
2014	7	23	21	50	27	0.3	4.6	0.89	94.7	99.6326	83.7072
2014	7	23	22	0	27	0.3	4.6	0.91	96.2	99.6326	85.8854
2014	7	23	22	10	27	0.3	4.6	0.88	94.9	99.6326	82.7736
2014	7	23	22	20	27	0.3	4.6	0.89	95.1	99.6326	84.0184
2014	7	23	22	30	27	0.3	4.6	0.91	93.9	99.6326	86.5078
2014	7	23	22	40	27	0.3	4.6	0.91	94.1	99.6326	85.8854
2014	7	23	22	50	27	0.3	4.6	0.86	96.3	99.6326	81.5289
2014	7	23	23	0	27	0.3	4.6	0.92	95.3	99.6326	87.1302
2014	7	23	23	10	27	0.3	4.6	0.94	94.2	99.6326	88.6861
2014	7	23	23	20	27	0.3	4.6	0.97	94.9	99.6326	91.4867
2014	7	23	23	30	27	0.3	4.6	0.89	95.7	99.6326	83.7072
2014	7	23	23	40	27	0.3	4.6	0.87	93.7	99.6326	82.1513
2014	7	23	23	50	27	0.3	4.6	0.92	95.3	99.6326	87.1302
2014	7	24	0	0	27	0.3	4.6	0.9	94.4	99.6982	85.0098
2014	7	24	0	10	27	0.3	4.6	0.89	94.4	99.6326	84.0184

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	0	20	27	0.3	4.6	0.9	95.2	99.6982	85.3212
2014	7	24	0	30	27	0.3	4.6	0.87	93.2	99.6982	82.8301
2014	7	24	0	40	27	0.3	4.6	0.89	93.4	99.6982	84.0757
2014	7	24	0	50	27	0.3	4.6	0.88	93.2	99.6982	83.7643
2014	7	24	1	0	27	0.3	4.6	0.89	96.2	99.6982	83.7643
2014	7	24	1	10	27	0.3	4.6	0.9	94.4	99.6982	85.0099
2014	7	24	1	20	27	0.3	4.6	0.92	94.9	99.6982	87.1897
2014	7	24	1	30	27	0.3	4.6	0.87	94.3	99.6982	82.5188
2014	7	24	1	40	27	0.3	4.6	0.9	94.2	99.6982	85.3213
2014	7	24	1	50	27	0.3	4.6	0.89	94	99.6982	84.3872
2014	7	24	2	0	27	0.3	4.6	0.88	96.4	99.6982	83.1416
2014	7	24	2	10	27	0.3	4.6	0.89	93.6	99.6982	84.6986
2014	7	24	2	20	27	0.3	4.6	0.87	94.7	99.6982	82.5189
2014	7	24	2	30	27	0.3	4.6	0.89	93.6	99.6982	84.3872
2014	7	24	2	40	27	0.3	4.6	0.89	95.1	99.6982	84.0759
2014	7	24	2	50	27	0.3	4.6	0.89	94.2	99.6982	84.0759
2014	7	24	3	0	27	0.3	4.6	0.91	94.3	99.6982	86.5671
2014	7	24	3	10	27	0.3	4.6	0.91	95	99.6982	85.6329
2014	7	24	3	20	27	0.3	4.6	0.91	94.8	99.6982	85.9443
2014	7	24	3	30	27	0.3	4.6	0.88	94.5	99.6982	83.4532
2014	7	24	3	40	27	0.3	4.6	0.91	93.9	99.6982	86.2558
2014	7	24	3	50	27	0.3	4.6	0.89	94.4	99.6982	84.076
2014	7	24	4	0	27	0.3	4.6	0.9	95.6	99.6982	85.3216
2014	7	24	4	10	27	0.3	4.6	0.9	94.4	99.7638	85.0681
2014	7	24	4	20	27	0.3	4.6	0.89	91.5	99.7638	84.7566
2014	7	24	4	30	27	0.3	4.6	0.89	93	99.7638	84.1334
2014	7	24	4	40	27	0.3	4.6	0.86	93.1	99.7638	81.6405
2014	7	24	4	50	27	0.3	4.6	0.89	94.4	99.7638	84.445
2014	7	24	5	0	27	0.3	4.6	0.89	95.3	99.7638	83.8218
2014	7	24	5	10	27	0.3	4.6	0.88	91.7	99.7638	83.5102
2014	7	24	5	20	27	0.3	4.6	0.89	94	99.7638	84.1335
2014	7	24	5	30	27	0.3	4.6	0.89	93	99.7638	84.1335
2014	7	24	5	40	27	0.3	4.6	0.89	97.4	99.7638	83.5103
2014	7	24	5	50	27	0.3	4.6	0.9	94	99.7638	85.6915
2014	7	24	6	0	27	0.3	4.6	0.91	94.5	99.7638	86.3148
2014	7	24	6	10	27	0.3	4.6	0.9	92.1	99.7638	85.0684
2014	7	24	6	20	27	0.3	4.6	0.91	93.7	99.8294	86.6854
2014	7	24	6	30	27	0.3	4.6	0.89	93	99.895	84.5602
2014	7	24	6	40	27	0.3	4.6	0.9	94	99.895	85.1842
2014	7	24	6	50	27	0.3	4.6	0.89	93	99.895	84.2482
2014	7	24	7	0	27	0.3	4.6	0.91	94.4	99.9606	86.1789
2014	7	24	7	10	27	0.3	4.6	0.88	95.2	99.9606	83.0565
2014	7	24	7	20	27	0.3	4.6	0.92	94.3	99.9606	87.7401
2014	7	24	7	30	27	0.3	4.6	0.88	92.8	99.9606	83.681
2014	7	24	7	40	27	0.3	4.6	0.88	93.8	99.9606	83.9932
2014	7	24	7	50	27	0.3	4.6	0.88	92.8	99.9606	83.681

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	8	0	27	0.3	4.6	0.88	95.8	99.9606	83.3687
2014	7	24	8	10	27	0.3	4.6	0.88	95.6	99.9606	83.0565
2014	7	24	8	20	27	0.3	4.6	0.92	96	99.9606	86.8034
2014	7	24	8	30	27	0.3	4.6	0.91	95.2	99.9606	85.8666
2014	7	24	8	40	27	0.3	4.6	0.88	94.3	99.9606	83.6809
2014	7	24	8	50	27	0.3	4.6	0.9	93.6	99.895	85.1843
2014	7	24	9	0	27	0.3	4.6	0.9	95	99.895	84.8722
2014	7	24	9	10	27	0.3	4.6	0.88	95.1	99.895	83.3121
2014	7	24	9	20	27	0.3	4.6	0.91	94.1	99.895	86.4324
2014	7	24	9	30	27	0.3	4.6	0.92	95.1	99.8294	86.6854
2014	7	24	9	40	27	0.3	4.6	0.9	95	99.8294	84.8145
2014	7	24	9	50	27	0.3	4.6	0.91	96.2	99.7638	86.3148
2014	7	24	10	0	27	0.3	4.6	0.9	98.8	99.7638	84.7568
2014	7	24	10	10	27	0.3	4.6	0.91	99.5	99.7638	85.38
2014	7	24	10	20	27	0.3	4.6	0.89	99.1	99.7638	83.822
2014	7	24	10	30	27	0.3	4.6	0.92	98.6	99.7638	86.6264
2014	7	24	10	40	27	0.3	4.6	0.9	97.5	99.7638	85.0683
2014	7	24	10	50	27	0.3	4.6	0.89	99.3	99.7638	83.5103
2014	7	24	11	0	27	0.3	4.6	0.9	97.7	99.7638	84.7567
2014	7	24	11	10	27	0.3	4.6	0.91	97.3	99.7638	85.6915
2014	7	24	11	20	27	0.3	4.6	0.91	99.1	99.7638	85.3799
2014	7	24	11	30	27	0.3	4.6	0.89	98.5	99.6982	83.142
2014	7	24	11	40	27	0.3	4.6	0.9	99	99.6982	84.699
2014	7	24	11	50	27	0.3	4.6	0.92	97.8	99.7638	86.3146
2014	7	24	12	0	27	0.3	4.6	0.89	98.5	99.6982	83.7647
2014	7	24	12	10	27	0.3	4.6	0.91	99.8	99.6982	84.699
2014	7	24	12	20	27	0.3	4.6	0.91	101.9	99.6982	84.0762
2014	7	24	12	30	27	0.3	4.6	0.89	97.2	99.6326	83.7077
2014	7	24	12	40	27	0.3	4.6	0.91	99.1	99.6326	85.2636
2014	7	24	12	50	27	0.3	4.6	0.9	100.3	99.6326	84.0189
2014	7	24	13	0	27	0.3	4.6	0.9	100.7	99.6326	83.7077
2014	7	24	13	10	27	0.3	4.6	0.93	99	99.6326	86.8194
2014	7	24	13	20	27	0.3	4.6	0.92	98.8	99.6982	86.2558
2014	7	24	13	30	27	0.3	4.6	0.91	100	99.6982	85.0102
2014	7	24	13	40	27	0.3	4.6	0.91	103.3	99.6982	84.076
2014	7	24	13	50	27	0.3	4.6	0.88	99.5	99.6326	82.1516
2014	7	24	14	0	27	0.3	4.6	0.9	99	99.6326	84.3299
2014	7	24	14	10	27	0.3	4.6	0.92	100.1	99.6326	85.8858
2014	7	24	14	20	27	0.3	4.6	0.9	98.4	99.6326	84.641
2014	7	24	14	30	27	0.3	4.6	0.89	101.1	99.6326	82.4628
2014	7	24	14	40	27	0.3	4.6	0.89	101.5	99.6326	82.7739
2014	7	24	14	50	27	0.3	4.6	0.91	97	99.6326	85.8857
2014	7	24	15	0	27	0.3	4.6	0.88	97.5	99.6326	83.0851
2014	7	24	15	10	27	0.3	4.6	0.89	99.1	99.6326	83.7075
2014	7	24	15	20	27	0.3	4.6	0.9	100	99.6326	84.3298
2014	7	24	15	30	27	0.3	4.6	0.92	99.6	99.5669	86.1382

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	15	40	27	0.3	4.6	0.93	96.5	99.6326	87.7528
2014	7	24	15	50	27	0.3	4.6	0.91	98.5	99.5669	84.8943
2014	7	24	16	0	27	0.3	4.6	0.92	99.4	99.5669	86.4492
2014	7	24	16	10	27	0.3	4.6	0.89	99.1	99.5669	83.3395
2014	7	24	16	20	27	0.3	4.6	0.9	101.2	99.5669	83.3395
2014	7	24	16	30	27	0.3	4.6	0.89	96.2	99.5669	83.6504
2014	7	24	16	40	27	0.3	4.6	0.88	98.4	99.5669	82.0956
2014	7	24	16	50	27	0.3	4.6	0.88	97.9	99.5669	83.0285
2014	7	24	17	0	27	0.3	4.6	0.89	97.2	99.5669	83.9614
2014	7	24	17	10	27	0.3	4.6	0.92	98.8	99.5669	86.1382
2014	7	24	17	20	27	0.3	4.6	0.9	95.7	99.6326	84.641
2014	7	24	17	30	27	0.3	4.6	0.9	94.6	99.5669	84.5834
2014	7	24	17	40	27	0.3	4.6	0.87	96.5	99.5669	81.4737
2014	7	24	17	50	27	0.3	4.6	0.88	94.3	99.5669	83.0285
2014	7	24	18	0	27	0.3	4.6	0.93	96.9	99.5669	87.0711
2014	7	24	18	10	27	0.3	4.6	0.91	96.4	99.5669	85.8272
2014	7	24	18	20	27	0.3	4.6	0.89	94.4	99.5669	84.2724
2014	7	24	18	30	27	0.3	4.6	0.93	96.3	99.5013	87.3225
2014	7	24	18	40	27	0.3	4.6	0.87	95.2	99.5669	82.4066
2014	7	24	18	50	27	0.3	4.6	0.91	96	99.5669	85.8272
2014	7	24	19	0	27	0.3	4.6	0.89	94.4	99.5669	84.2724
2014	7	24	19	10	27	0.3	4.6	0.88	95.1	99.5013	83.2826
2014	7	24	19	20	27	0.3	4.6	0.88	94	99.6326	83.7075
2014	7	24	19	30	27	0.3	4.6	0.88	94.5	99.6326	82.7739
2014	7	24	19	40	27	0.3	4.6	0.91	95	99.6326	86.1969
2014	7	24	19	50	27	0.3	4.6	0.89	95.1	99.5669	83.6504
2014	7	24	20	0	27	0.3	4.6	0.89	93.4	99.6326	84.3298
2014	7	24	20	10	27	0.3	4.6	0.91	93.3	99.5669	86.4491
2014	7	24	20	20	27	0.3	4.6	0.88	96.2	99.6326	83.0851
2014	7	24	20	30	27	0.3	4.6	0.9	94.6	99.5669	84.5833
2014	7	24	20	40	27	0.3	4.6	0.89	94.9	99.6326	84.0186
2014	7	24	20	50	27	0.3	4.6	0.91	95	99.6326	85.8857
2014	7	24	21	0	27	0.3	4.6	0.92	95.7	99.6326	87.1304
2014	7	24	21	10	27	0.3	4.6	0.92	95.9	99.6326	87.1304
2014	7	24	21	20	27	0.3	4.6	0.88	94.3	99.6326	83.7074
2014	7	24	21	30	27	0.3	4.6	0.88	95.5	99.6326	83.3962
2014	7	24	21	40	27	0.3	4.6	0.92	94.3	99.6326	87.4416
2014	7	24	21	50	27	0.3	4.6	0.94	96.4	99.6326	88.3751
2014	7	24	22	0	27	0.3	4.6	0.92	96.3	99.6326	87.1304
2014	7	24	22	10	27	0.3	4.6	0.86	95.7	99.6326	81.218
2014	7	24	22	20	27	0.3	4.6	0.86	94.8	99.6326	81.5292
2014	7	24	22	30	27	0.3	4.6	0.89	96.3	99.6326	84.3298
2014	7	24	22	40	27	0.3	4.6	0.88	94.3	99.6326	83.7074
2014	7	24	22	50	27	0.3	4.6	0.9	94.6	99.6326	85.2633
2014	7	24	23	0	27	0.3	4.6	0.89	92.5	99.6326	84.0186
2014	7	24	23	10	27	0.3	4.6	0.87	94.1	99.6326	82.4627

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	23	20	27	0.3	4.6	0.91	95	99.6326	85.5745
2014	7	24	23	30	27	0.3	4.6	0.91	94.4	99.6326	85.8857
2014	7	24	23	40	27	0.3	4.6	0.91	95.2	99.6326	86.1969
2014	7	24	23	50	27	0.3	4.6	0.9	95	99.6326	85.2634
2014	7	25	0	0	27	0.3	4.6	0.89	96.1	99.6326	84.0187
2014	7	25	0	10	27	0.3	4.6	0.91	94.1	99.6326	86.1969
2014	7	25	0	20	27	0.3	4.6	0.9	95.7	99.6326	84.641
2014	7	25	0	30	27	0.3	4.6	0.87	93.4	99.6326	82.7739
2014	7	25	0	40	27	0.3	4.6	0.89	94	99.6326	84.641
2014	7	25	0	50	27	0.3	4.6	0.88	95.1	99.6326	83.3963
2014	7	25	1	0	27	0.3	4.6	0.91	93.9	99.6326	86.5081
2014	7	25	1	10	27	0.3	4.6	0.9	95.3	99.6326	84.6411
2014	7	25	1	20	27	0.3	4.6	0.9	95.8	99.6326	85.2634
2014	7	25	1	30	27	0.3	4.6	0.89	94.4	99.6326	84.3299
2014	7	25	1	40	27	0.3	4.6	0.91	96	99.6326	85.8858
2014	7	25	1	50	27	0.3	4.6	0.91	95	99.6326	85.5747
2014	7	25	2	0	27	0.3	4.6	0.9	95.4	99.6326	84.9523
2014	7	25	2	10	27	0.3	4.6	0.89	94.4	99.6982	84.3874
2014	7	25	2	20	27	0.3	4.6	0.9	94.6	99.6982	85.3216
2014	7	25	2	30	27	0.3	4.6	0.89	95.3	99.6982	83.7647
2014	7	25	2	40	27	0.3	4.6	0.88	94.5	99.6982	83.4533
2014	7	25	2	50	27	0.3	4.6	0.92	93.7	99.6982	86.8786
2014	7	25	3	0	27	0.3	4.6	0.88	93.8	99.6982	83.7647
2014	7	25	3	10	27	0.3	4.6	0.89	94.9	99.6982	83.7647
2014	7	25	3	20	27	0.3	4.6	0.89	92.3	99.6982	84.3876
2014	7	25	3	30	27	0.3	4.6	0.89	94.2	99.6982	84.0762
2014	7	25	3	40	27	0.3	4.6	0.91	93.3	99.6982	85.9445
2014	7	25	3	50	27	0.3	4.6	0.89	94.4	99.6982	84.3876
2014	7	25	4	0	27	0.3	4.6	0.92	94.3	99.6982	86.8788
2014	7	25	4	10	27	0.3	4.6	0.9	93.8	99.6982	85.3218
2014	7	25	4	20	27	0.3	4.6	0.9	92.7	99.6982	85.0104
2014	7	25	4	30	27	0.3	4.6	0.9	95	99.6982	85.3218
2014	7	25	4	40	27	0.3	4.6	0.91	94.4	99.6982	85.9446
2014	7	25	4	50	27	0.3	4.6	0.9	94	99.6982	85.0105
2014	7	25	5	0	27	0.3	4.6	0.89	94.7	99.6982	84.0763
2014	7	25	5	10	27	0.3	4.6	0.89	94.7	99.7638	84.1336
2014	7	25	5	20	27	0.3	4.6	0.91	93.3	99.7638	86.0033
2014	7	25	5	30	27	0.3	4.6	0.89	94	99.8294	84.5027
2014	7	25	5	40	27	0.3	4.6	0.89	95.9	99.8294	84.5027
2014	7	25	5	50	27	0.3	4.6	0.9	95	99.895	85.4963
2014	7	25	6	0	27	0.3	4.6	0.9	92.1	99.9606	85.2422
2014	7	25	6	10	27	0.3	4.6	0.91	93.1	99.9606	86.4912
2014	7	25	6	20	27	0.3	4.6	0.89	93.6	99.9606	84.3055
2014	7	25	6	30	27	0.3	4.6	0.92	95.5	99.9606	86.8035
2014	7	25	6	40	27	0.3	4.6	0.93	95.7	100.0525	87.8228
2014	7	25	6	50	27	0.3	4.6	0.9	95.2	100.0525	85.3226

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow	
2014	7	25	7	7	0	27	0.3	4.6	0.91	93.7	100.0525	86.2602
2014	7	25	7	10	10	27	0.3	4.6	0.87	94.8	99.9606	82.1199
2014	7	25	7	20	20	27	0.3	4.6	0.88	94.3	99.9606	83.6811
2014	7	25	7	30	30	27	0.3	4.6	0.89	94	99.9606	84.9301
2014	7	25	7	40	40	27	0.3	4.6	0.9	95.3	99.9606	84.9301
2014	7	25	7	50	50	27	0.3	4.6	0.9	96.5	100.0525	85.6351
2014	7	25	8	0	0	27	0.3	4.6	0.91	96	99.9606	86.4913
2014	7	25	8	10	10	27	0.3	4.6	0.89	96.3	99.9606	84.3056
2014	7	25	8	20	20	27	0.3	4.6	0.9	94.6	99.9606	84.9301
2014	7	25	8	30	30	27	0.3	4.6	0.92	93.5	99.9606	87.428
2014	7	25	8	40	40	27	0.3	4.6	0.9	96.1	99.9606	84.9301
2014	7	25	8	50	50	27	0.3	4.6	0.89	95.3	99.9606	84.3055
2014	7	25	9	0	0	27	0.3	4.6	0.89	93.2	99.9606	84.3055
2014	7	25	9	10	10	27	0.3	4.6	0.88	95.6	99.9606	83.3688
2014	7	25	9	20	20	27	0.3	4.6	0.9	94.6	99.895	85.1844
2014	7	25	9	30	30	27	0.3	4.6	0.91	94.6	99.8294	85.7501
2014	7	25	9	40	40	27	0.3	4.6	0.94	96.2	99.8294	88.5564
2014	7	25	9	50	50	27	0.3	4.6	0.88	96.4	99.7638	83.5105
2014	7	25	10	0	0	27	0.3	4.6	0.91	95	99.7638	86.0033
2014	7	25	10	10	10	27	0.3	4.6	0.91	96.4	99.6982	85.9448
2014	7	25	10	20	20	27	0.3	4.6	0.92	95.8	99.6982	86.5676
2014	7	25	10	30	30	27	0.3	4.6	0.92	96.4	99.7638	86.6265
2014	7	25	10	41	41	39	0.3	4.6	0.89	95.5	99.6982	84.3878
2014	7	25	10	51	51	39	0.3	4.6	0.9	98	99.6982	84.3877
2014	7	25	11	1	1	39	0.3	4.6	0.91	100.4	99.6982	85.0105
2014	7	25	11	11	11	39	0.3	4.6	0.92	98.2	99.6982	86.2561
2014	7	25	11	21	21	39	0.3	4.6	0.91	95.4	99.6982	85.9446
2014	7	25	11	31	31	39	0.3	4.6	0.91	98.3	99.7638	85.0684
2014	7	25	11	41	41	39	0.3	4.6	0.9	95	99.6982	85.0105
2014	7	25	11	51	51	39	0.3	4.6	0.91	98.5	99.6982	85.3218
2014	7	25	12	1	1	39	0.3	4.6	0.86	97.7	99.6326	80.9072
2014	7	25	12	11	11	39	0.3	4.6	0.9	100.2	99.6982	84.3876
2014	7	25	12	21	21	39	0.3	4.6	0.89	96.5	99.6326	84.3302
2014	7	25	12	31	31	39	0.3	4.6	0.92	96.4	99.6982	86.5674
2014	7	25	12	41	41	39	0.3	4.6	0.89	98.3	99.6982	83.142
2014	7	25	12	51	51	39	0.3	4.6	0.92	97.6	99.6326	86.5083
2014	7	25	13	1	1	39	0.3	4.6	0.9	97.1	99.6326	84.9524
2014	7	25	13	14	14	19	0.3	4.6	0.93	94.4	99.6326	88.0642
2014	7	25	13	24	24	19	0.3	4.6	0.93	94.9	99.6326	87.4418
2014	7	25	13	34	34	19	0.3	4.6	0.94	98	99.5669	88.0042
2014	7	25	13	44	44	19	0.3	4.6	0.89	96.3	99.6326	84.33
2014	7	25	13	54	54	19	0.3	4.6	0.92	97	99.5669	86.1383
2014	7	25	14	4	4	19	0.3	4.6	0.89	94.2	99.5669	84.5835
2014	7	25	14	14	14	19	0.3	4.6	0.88	96.6	99.6326	82.774
2014	7	25	14	24	24	19	0.3	4.6	0.92	95.1	99.5669	86.7602
2014	7	25	14	34	34	19	0.3	4.6	0.91	94.8	99.5669	85.8273

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	14	44	19	0.3	4.6	0.91	96	99.5669	85.8273
2014	7	25	14	54	19	0.3	4.6	0.89	94.7	99.5669	83.6505
2014	7	25	15	4	19	0.3	4.6	0.83	97.7	99.5669	78.0531
2014	7	25	15	14	19	0.3	4.6	0.88	94.1	99.5013	82.972
2014	7	25	15	24	19	0.3	4.6	0.91	96.2	99.5013	85.458
2014	7	25	15	34	19	0.3	4.6	0.89	93.6	99.4357	83.847
2014	7	25	15	44	19	0.3	4.6	0.89	94.2	99.5669	83.9615
2014	7	25	15	54	19	0.3	4.6	0.89	94.9	99.5669	83.9615
2014	7	25	16	4	19	0.3	4.6	0.87	97	99.5669	81.4737
2014	7	25	16	14	19	0.3	4.6	0.89	92.1	99.5669	83.9615
2014	7	25	16	24	19	0.3	4.6	0.9	93.5	99.5669	85.5163
2014	7	25	16	34	19	0.3	4.6	0.9	96.1	99.5013	84.5257
2014	7	25	16	44	19	0.3	4.6	0.89	95.9	99.5013	84.215
2014	7	25	16	54	19	0.3	4.6	0.9	95.3	99.5013	84.5257
2014	7	25	17	4	19	0.3	4.6	0.91	95	99.5013	86.0795
2014	7	25	17	14	19	0.3	4.6	0.9	94.6	99.5013	85.1473
2014	7	25	17	24	19	0.3	4.6	0.93	94.6	99.5013	87.9441
2014	7	25	17	34	19	0.3	4.6	0.88	96.4	99.4357	82.6048
2014	7	25	17	44	19	0.3	4.6	0.87	94.6	99.4357	81.6732
2014	7	25	17	54	19	0.3	4.6	0.92	93.9	99.4357	86.6419
2014	7	25	18	4	19	0.3	4.6	0.9	96.1	99.3701	84.4104
2014	7	25	18	14	19	0.3	4.6	0.86	92.9	99.3045	80.9414
2014	7	25	18	24	19	0.3	4.6	0.88	95.1	99.5013	83.2827
2014	7	25	18	34	19	0.3	4.6	0.88	93.4	99.4357	83.2259
2014	7	25	18	44	19	0.3	4.6	0.88	93.2	99.4357	82.9154
2014	7	25	18	54	19	0.3	4.6	0.92	94.9	99.3701	86.893
2014	7	25	19	4	19	0.3	4.6	0.89	94.4	99.3701	84.1
2014	7	25	19	14	19	0.3	4.6	0.88	97.7	99.5013	82.6612
2014	7	25	19	24	19	0.3	4.6	0.87	95.2	99.5013	81.7289
2014	7	25	19	34	19	0.3	4.6	0.91	94.8	99.5013	85.458
2014	7	25	19	44	19	0.3	4.6	0.91	95.4	99.5013	85.458
2014	7	25	19	54	19	0.3	4.6	0.9	95	99.5013	84.8365
2014	7	25	20	4	19	0.3	4.6	0.88	94.7	99.5013	82.9719
2014	7	25	20	14	19	0.3	4.6	0.89	95.3	99.5013	83.9042
2014	7	25	20	24	19	0.3	4.6	0.86	95.3	99.5013	80.7966
2014	7	25	20	34	19	0.3	4.6	0.9	94.6	99.5013	85.1472
2014	7	25	20	44	19	0.3	4.6	0.91	94.5	99.5013	86.0795
2014	7	25	20	54	19	0.3	4.6	0.9	94.4	99.5013	85.458
2014	7	25	21	4	19	0.3	4.6	0.87	93.7	99.5013	82.3504
2014	7	25	21	14	19	0.3	4.6	0.87	95.2	99.5013	82.3504
2014	7	25	21	24	19	0.3	4.6	0.89	95.3	99.5013	83.9042
2014	7	25	21	34	19	0.3	4.6	0.9	94	99.5013	85.458
2014	7	25	21	44	19	0.3	4.6	0.86	95	99.5013	81.1074
2014	7	25	21	54	19	0.3	4.6	0.9	95.9	99.5013	84.8364
2014	7	25	22	4	19	0.3	4.6	0.9	95.6	99.5013	85.1472
2014	7	25	22	14	19	0.3	4.6	0.87	95	99.5013	81.7289

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	22	24	19	0.3	4.6	0.88	94.9	99.5013	82.6611
2014	7	25	22	34	19	0.3	4.6	0.89	95.9	99.5669	83.9614
2014	7	25	22	44	19	0.3	4.6	0.86	94.4	99.5013	81.4181
2014	7	25	22	54	19	0.3	4.6	0.89	95.9	99.5669	84.2724
2014	7	25	23	4	19	0.3	4.6	0.89	95.5	99.5669	84.2724
2014	7	25	23	14	19	0.3	4.6	0.92	96.5	99.5013	87.0117
2014	7	25	23	24	19	0.3	4.6	0.86	94.4	99.5013	81.4181
2014	7	25	23	34	19	0.3	4.6	0.89	95.1	99.5669	83.9614
2014	7	25	23	44	19	0.3	4.6	0.88	94.5	99.5669	82.7176
2014	7	25	23	54	19	0.3	4.6	0.89	95.5	99.5669	83.9615
2014	7	26	0	4	19	0.3	4.6	0.91	94.4	99.5669	85.8273
2014	7	26	0	14	19	0.3	4.6	0.88	95.8	99.5669	83.0286
2014	7	26	0	24	19	0.3	4.6	0.89	92.5	99.5669	84.5834
2014	7	26	0	34	19	0.3	4.6	0.93	94.9	99.5013	87.3225
2014	7	26	0	44	19	0.3	4.6	0.91	95.2	99.5669	86.1383
2014	7	26	0	54	19	0.3	4.6	0.88	95.5	99.5669	83.3396
2014	7	26	1	4	19	0.3	4.6	0.89	94	99.5669	83.9615
2014	7	26	1	14	19	0.3	4.6	0.89	97.2	99.5669	83.6505
2014	7	26	1	24	19	0.3	4.6	0.91	94.3	99.5669	86.4493
2014	7	26	1	34	19	0.3	4.6	0.89	96.8	99.5669	83.9615
2014	7	26	1	44	19	0.3	4.6	0.9	95.8	99.5669	85.2054
2014	7	26	1	54	19	0.3	4.6	0.89	94.7	99.5669	83.6506
2014	7	26	2	4	19	0.3	4.6	0.9	94.6	99.5669	84.5835
2014	7	26	2	14	19	0.3	4.6	0.88	95.1	99.5669	83.3397
2014	7	26	2	24	19	0.3	4.6	0.88	93.6	99.5669	83.6506
2014	7	26	2	34	19	0.3	4.6	0.89	94.9	99.5669	83.6507
2014	7	26	2	44	19	0.3	4.6	0.88	96.4	99.5013	82.9721
2014	7	26	2	54	19	0.3	4.6	0.88	93.6	99.5013	82.9721
2014	7	26	3	4	19	0.3	4.6	0.9	94.8	99.5669	84.8946
2014	7	26	3	14	19	0.3	4.6	0.87	96.3	99.5669	82.0959
2014	7	26	3	24	19	0.3	4.6	0.89	95.7	99.5669	83.9617
2014	7	26	3	34	19	0.3	4.6	0.9	96.1	99.5669	84.8946
2014	7	26	3	44	19	0.3	4.6	0.87	95.2	99.5669	81.785
2014	7	26	3	54	19	0.3	4.6	0.87	95.2	99.5669	82.4069
2014	7	26	4	4	19	0.3	4.6	0.89	94.9	99.5669	83.6508
2014	7	26	4	14	19	0.3	4.6	0.91	94.6	99.5013	85.4583
2014	7	26	4	24	19	0.3	4.6	0.88	95.1	99.5013	83.283
2014	7	26	4	34	19	0.3	4.6	0.91	96	99.5669	86.1386
2014	7	26	4	44	19	0.3	4.6	0.92	94.7	99.5013	86.3906
2014	7	26	4	54	19	0.3	4.6	0.89	94.7	99.5013	83.9046
2014	7	26	5	4	19	0.3	4.6	0.88	94.7	99.5013	83.2831
2014	7	26	5	14	19	0.3	4.6	0.88	95.8	99.5013	83.2831
2014	7	26	5	24	19	0.3	4.6	0.89	95.7	99.5669	83.9619
2014	7	26	5	34	19	0.3	4.6	0.88	95.1	99.5669	83.34
2014	7	26	5	44	19	0.3	4.6	0.9	96.1	99.5013	84.5262
2014	7	26	5	54	19	0.3	4.6	0.9	95	99.5669	85.2058

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	6	4	19	0.3	4.6	0.89	94	99.5669	84.5839
2014	7	26	6	14	19	0.3	4.6	0.89	96.2	99.5669	83.651
2014	7	26	6	24	19	0.3	4.6	0.87	94.1	99.5669	82.7181
2014	7	26	6	34	19	0.3	4.6	0.88	93.9	99.5669	83.0291
2014	7	26	6	44	19	0.3	4.6	0.9	96.1	99.5669	84.584
2014	7	26	6	54	19	0.3	4.6	0.9	94.8	99.5669	84.584
2014	7	26	7	4	19	0.3	4.6	0.86	94.2	99.5669	80.8524
2014	7	26	7	14	19	0.3	4.6	0.88	96	99.5669	83.0292
2014	7	26	7	24	19	0.3	4.6	0.88	93.4	99.5013	83.2833
2014	7	26	7	34	19	0.3	4.6	0.9	95	99.5013	84.5263
2014	7	26	7	44	19	0.3	4.6	0.91	95.6	99.5669	86.1389
2014	7	26	7	54	19	0.3	4.6	0.91	95.6	99.5013	85.4586
2014	7	26	8	4	19	0.3	4.6	0.93	95.9	99.5013	87.3232
2014	7	26	8	14	19	0.3	4.6	0.9	96.1	99.5669	84.584
2014	7	26	8	24	19	0.3	4.6	0.9	94.8	99.5669	84.584
2014	7	26	8	34	19	0.3	4.6	0.88	93.4	99.5013	83.2833
2014	7	26	8	44	19	0.3	4.6	0.92	95.9	99.5013	86.7017
2014	7	26	8	54	19	0.3	4.6	0.91	94.7	99.5013	86.0802
2014	7	26	9	4	19	0.3	4.6	0.89	96.3	99.5013	83.9048
2014	7	26	9	14	19	0.3	4.6	0.9	96	99.5013	85.1479
2014	7	26	9	24	19	0.3	4.6	0.86	95.2	99.5013	81.4188
2014	7	26	9	34	19	0.3	4.6	0.93	95.9	99.5013	87.3232
2014	7	26	9	44	19	0.3	4.6	0.9	94.8	99.5013	85.1479
2014	7	26	9	54	19	0.3	4.6	0.89	96.8	99.5013	83.9048
2014	7	26	10	4	19	0.3	4.6	0.88	97.3	99.5013	82.351
2014	7	26	10	14	19	0.3	4.6	0.92	99.5	99.5013	85.7693
2014	7	26	10	24	19	0.3	4.6	0.9	99.2	99.5013	84.5262
2014	7	26	10	34	19	0.3	4.6	0.92	99.2	99.5013	86.08
2014	7	26	10	44	19	0.3	4.6	0.91	99.9	99.5013	85.1478
2014	7	26	10	54	19	0.3	4.6	0.92	100.9	99.5013	85.7693
2014	7	26	11	4	19	0.3	4.6	0.92	98.6	99.5013	86.08
2014	7	26	11	14	19	0.3	4.6	0.92	98.9	99.5013	85.7693
2014	7	26	11	24	19	0.3	4.6	0.92	99	99.4357	86.0213
2014	7	26	11	34	19	0.3	4.6	0.92	99.2	99.4357	86.0212
2014	7	26	11	44	19	0.3	4.6	0.91	101.8	99.5013	84.5262
2014	7	26	11	54	19	0.3	4.6	0.91	99.4	99.4357	84.779
2014	7	26	12	4	19	0.3	4.6	0.89	98.5	99.4357	82.9157
2014	7	26	12	14	19	0.3	4.6	0.9	96.3	99.4357	84.4684
2014	7	26	12	24	19	0.3	4.6	0.91	99	99.4357	84.7789
2014	7	26	12	34	19	0.3	4.6	0.92	103.2	99.4357	84.4684
2014	7	26	12	44	19	0.3	4.6	0.92	99.8	99.4357	86.0211
2014	7	26	12	54	19	0.3	4.6	0.92	98.4	99.4357	85.7105
2014	7	26	13	4	19	0.3	4.6	0.91	100.8	99.4357	84.7789
2014	7	26	13	14	19	0.3	4.6	0.91	98.7	99.4357	85.4
2014	7	26	13	24	19	0.3	4.6	0.91	101	99.3701	84.4106
2014	7	26	13	34	19	0.3	4.6	0.91	100.8	99.3701	84.4106

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	13	44	19	0.3	4.6	0.92	98.4	99.3701	85.6519
2014	7	26	13	54	19	0.3	4.6	0.9	101.8	99.3701	83.4796
2014	7	26	14	4	19	0.3	4.6	0.89	98.9	99.3701	82.8589
2014	7	26	14	14	19	0.3	4.6	0.9	101.5	99.3045	83.7327
2014	7	26	14	24	19	0.3	4.6	0.88	102.6	99.3045	81.5618
2014	7	26	14	34	19	0.3	4.6	0.89	98.5	99.2388	83.0556
2014	7	26	14	44	19	0.3	4.6	0.86	99.2	99.1732	80.5212
2014	7	26	14	54	19	0.3	4.6	0.86	99.9	99.3045	79.701
2014	7	26	15	4	19	0.3	4.6	0.89	99.5	99.2388	83.3654
2014	7	26	15	14	19	0.3	4.6	0.87	99.3	99.1732	81.4502
2014	7	26	15	24	19	0.3	4.6	0.91	100.4	99.1732	84.2375
2014	7	26	15	34	19	0.3	4.6	0.88	100.8	99.1732	81.4502
2014	7	26	15	44	19	0.3	4.6	0.88	97.5	99.1076	82.0134
2014	7	26	15	54	19	0.3	4.6	0.88	99.9	99.1076	81.7039
2014	7	26	16	4	19	0.3	4.6	0.89	99.4	99.1076	82.6324
2014	7	26	16	14	19	0.3	4.6	0.88	97.1	99.1732	82.3794
2014	7	26	16	24	19	0.3	4.6	0.88	100.3	99.1076	81.704
2014	7	26	16	34	19	0.3	4.6	0.89	97.2	99.1732	82.9988
2014	7	26	16	44	19	0.3	4.6	0.86	98.5	99.1732	80.5212
2014	7	26	16	54	19	0.3	4.3	0.92	96.9	92.874	80.7289
2014	7	26	17	4	19	0.3	4.6	0.91	100.6	99.1732	84.2376
2014	7	26	17	14	19	0.3	4.6	0.89	97.6	99.042	83.1944
2014	7	26	17	24	19	0.3	4.6	0.9	97.1	99.1732	84.5473
2014	7	26	17	34	19	0.3	4.6	0.91	99.4	99.1076	84.4894
2014	7	26	17	44	19	0.3	4.6	0.91	98.5	99.1076	84.4894
2014	7	26	17	54	19	0.3	4.6	0.91	94.4	99.1076	85.4178
2014	7	26	18	4	19	0.3	4.6	0.9	99.5	99.1076	83.5609
2014	7	26	18	14	19	0.3	4.6	0.88	97.3	99.1732	82.3794
2014	7	26	18	24	19	0.3	4.6	0.83	101.4	99.1076	76.4428
2014	7	26	18	34	19	0.3	4.6	0.87	99.1	99.042	81.0295
2014	7	26	18	44	19	0.3	4.6	0.89	99.4	99.042	82.5758
2014	7	26	18	54	19	0.3	4.6	0.89	97.6	99.042	83.1944
2014	7	26	19	4	19	0.3	4.6	0.9	97.7	99.1076	84.4894
2014	7	26	19	14	19	0.3	4.6	0.93	97.3	99.042	86.9057
2014	7	26	19	24	19	0.3	4.6	0.86	97.5	99.042	80.4109
2014	7	26	19	34	19	0.3	4.6	0.88	96.9	99.042	81.9573
2014	7	26	19	44	19	0.3	4.6	0.9	95	99.042	84.4315
2014	7	26	19	54	19	0.3	4.6	0.88	96.8	99.042	82.5758
2014	7	26	20	4	19	0.3	4.6	0.9	96.1	99.042	84.4314
2014	7	26	20	14	19	0.3	4.6	0.9	94.8	99.042	84.4314
2014	7	26	20	24	19	0.3	4.6	0.9	95	99.1076	84.7988
2014	7	26	20	34	19	0.3	4.6	0.86	95.5	99.042	81.0294
2014	7	26	20	44	19	0.3	4.6	0.9	96.5	99.042	84.4314
2014	7	26	20	54	19	0.3	4.6	0.93	95.3	99.042	86.9056
2014	7	26	21	4	19	0.3	4.6	0.91	95.8	99.1076	85.4178
2014	7	26	21	14	19	0.3	4.6	0.9	95	99.1076	84.4893

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	21	24	19	0.3	4.6	0.91	93.9	99.1076	86.0368
2014	7	26	21	34	19	0.3	4.6	0.87	95.2	99.1732	82.0697
2014	7	26	21	44	19	0.3	4.6	0.87	97	99.1732	81.1406
2014	7	26	21	54	19	0.3	4.6	0.89	94.7	99.1732	83.3084
2014	7	26	22	4	19	0.3	4.6	0.85	96.2	99.1732	79.9018
2014	7	26	22	14	19	0.3	4.6	0.9	95.4	99.1732	84.5472
2014	7	26	22	24	19	0.3	4.6	0.87	95.4	99.2388	81.8159
2014	7	26	22	34	19	0.3	4.6	0.91	95	99.2388	85.2249
2014	7	26	22	44	19	0.3	4.6	0.91	94.1	99.1732	85.786
2014	7	26	22	54	19	0.3	4.6	0.89	97	99.2388	83.3655
2014	7	26	23	4	19	0.3	4.6	0.88	94	99.2388	83.3655
2014	7	26	23	14	19	0.3	4.6	0.89	95.3	99.2388	83.6754
2014	7	26	23	24	19	0.3	4.6	0.91	92.5	99.2388	85.8447
2014	7	26	23	34	19	0.3	4.6	0.88	94.9	99.2388	83.0555
2014	7	26	23	44	19	0.3	4.6	0.91	95	99.2388	85.2249
2014	7	26	23	54	19	0.3	4.6	0.91	94.6	99.3045	85.2832
2014	7	27	0	4	19	0.3	4.6	0.89	94.9	99.3045	83.4225
2014	7	27	0	14	19	0.3	4.6	0.87	93.3	99.3045	81.8719
2014	7	27	0	24	19	0.3	4.6	0.88	96	99.2388	82.4358
2014	7	27	0	34	19	0.3	4.6	0.9	94.2	99.2388	84.915
2014	7	27	0	44	19	0.3	4.6	0.89	95.9	99.2388	83.3655
2014	7	27	0	54	19	0.3	4.6	0.89	94	99.2388	83.9853
2014	7	27	1	4	19	0.3	4.6	0.93	96.3	99.3045	87.144
2014	7	27	1	14	19	0.3	4.6	0.9	95	99.2388	84.6052
2014	7	27	1	24	19	0.3	4.6	0.91	94.4	99.2388	85.5349
2014	7	27	1	34	19	0.3	4.6	0.87	93.3	99.2388	81.816
2014	7	27	1	44	19	0.3	4.6	0.89	97.8	99.2388	83.6755
2014	7	27	1	54	19	0.3	4.6	0.9	96.9	99.2388	84.6052
2014	7	27	2	4	19	0.3	4.6	0.89	94.9	99.2388	83.9854
2014	7	27	2	14	19	0.3	4.6	0.9	95	99.2388	84.9151
2014	7	27	2	24	19	0.3	4.6	0.9	94.4	99.3045	84.9732
2014	7	27	2	34	19	0.3	4.6	0.88	95.6	99.2388	82.4359
2014	7	27	2	44	19	0.3	4.6	0.87	96.3	99.3045	81.5619
2014	7	27	2	54	19	0.3	4.6	0.91	96.2	99.3045	85.9036
2014	7	27	3	4	19	0.3	4.6	0.9	94.4	99.3045	84.6632
2014	7	27	3	14	19	0.3	4.6	0.88	95.1	99.3045	83.1126
2014	7	27	3	24	19	0.3	4.6	0.88	94.5	99.3045	82.4923
2014	7	27	3	34	19	0.3	4.6	0.87	92.6	99.3045	82.1822
2014	7	27	3	44	19	0.3	4.6	0.88	94.7	99.3045	83.1126
2014	7	27	3	54	19	0.3	4.6	0.89	93.8	99.3045	84.043
2014	7	27	4	4	19	0.3	4.6	0.89	93.8	99.3045	84.043
2014	7	27	4	14	19	0.3	4.6	0.89	95.3	99.3045	83.7329
2014	7	27	4	24	19	0.3	4.6	0.88	95.1	99.3045	82.8025
2014	7	27	4	34	19	0.3	4.6	0.89	95.9	99.3045	83.4228
2014	7	27	4	44	19	0.3	4.6	0.88	93.8	99.3045	83.4228
2014	7	27	4	54	19	0.3	4.6	0.89	97.2	99.3045	83.7329

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	5	4	19	0.3	4.6	0.88	94.1	99.3045	82.8026
2014	7	27	5	14	19	0.3	4.6	0.86	94.4	99.3045	80.6317
2014	7	27	5	24	19	0.3	4.6	0.89	92.9	99.3045	84.3532
2014	7	27	5	34	19	0.3	4.6	0.88	96.2	99.3045	83.1127
2014	7	27	5	44	19	0.3	4.6	0.91	93.7	99.3045	85.9038
2014	7	27	5	54	19	0.3	4.6	0.91	95.2	99.3045	85.2836
2014	7	27	6	4	19	0.3	4.6	0.9	94.2	99.3045	84.6634
2014	7	27	6	14	19	0.3	4.6	0.91	95	99.3045	85.5937
2014	7	27	6	24	19	0.3	4.6	0.87	94.5	99.3045	81.8723
2014	7	27	6	34	19	0.3	4.6	0.88	94.9	99.3045	82.8027
2014	7	27	6	44	19	0.3	4.6	0.88	94.1	99.3045	82.8027
2014	7	27	6	54	19	0.3	4.6	0.9	92.9	99.3045	84.6634
2014	7	27	7	4	19	0.3	4.6	0.89	95.9	99.3045	83.4229
2014	7	27	7	14	19	0.3	4.6	0.91	94.8	99.3045	85.5938
2014	7	27	7	24	19	0.3	4.6	0.89	96.1	99.3045	83.733
2014	7	27	7	34	19	0.3	4.6	0.88	93.9	99.3045	82.8027
2014	7	27	7	44	19	0.3	4.6	0.9	95.8	99.3045	84.9735
2014	7	27	7	54	19	0.3	4.6	0.86	93.7	99.3045	81.252
2014	7	27	8	4	19	0.3	4.6	0.88	94.5	99.3045	82.4925
2014	7	27	8	14	19	0.3	4.6	0.88	93	99.3045	82.8027
2014	7	27	8	24	19	0.3	4.6	0.89	95.3	99.3045	83.733
2014	7	27	8	34	19	0.3	4.6	0.9	95	99.3045	84.6634
2014	7	27	8	44	19	0.3	4.6	0.87	94.8	99.3045	81.5621
2014	7	27	8	54	19	0.3	4.6	0.87	95.9	99.3045	81.5621
2014	7	27	9	4	19	0.3	4.6	0.87	95.6	99.3045	81.8723
2014	7	27	9	14	19	0.3	4.6	0.89	93.6	99.3045	84.3533
2014	7	27	9	24	19	0.3	4.6	0.88	95.8	99.3045	83.1127
2014	7	27	9	34	19	0.3	4.6	0.92	95.1	99.3045	86.2139
2014	7	27	9	44	19	0.3	4.6	0.87	95	99.3045	81.8722
2014	7	27	9	54	19	0.3	4.6	0.91	95.4	99.3045	85.5937
2014	7	27	10	4	19	0.3	4.6	0.9	94.6	99.2388	84.2955
2014	7	27	10	14	19	0.3	4.6	0.88	94.9	99.2388	83.0558
2014	7	27	10	24	19	0.3	4.6	0.92	97	99.2388	85.845
2014	7	27	10	34	19	0.3	4.6	0.91	99.4	99.2388	84.6053
2014	7	27	10	44	19	0.3	4.6	0.9	97.1	99.2388	84.6053
2014	7	27	10	54	19	0.3	4.6	0.92	100.3	99.1732	85.1668
2014	7	27	11	4	19	0.3	4.6	0.89	98.7	99.1732	82.9989
2014	7	27	11	14	19	0.3	4.6	0.89	99.3	99.1076	82.9421
2014	7	27	11	24	19	0.3	4.6	0.89	99.3	99.1076	82.942
2014	7	27	11	34	19	0.3	4.6	0.89	101.5	99.042	82.2666
2014	7	27	11	44	19	0.3	4.6	0.93	96.9	98.9764	87.1552
2014	7	27	11	54	19	0.3	4.6	0.93	97.7	98.9764	86.537
2014	7	27	12	4	19	0.3	4.6	0.93	96.7	99.042	87.5242
2014	7	27	12	14	19	0.3	4.6	0.91	99.5	98.9764	84.6826
2014	7	27	12	24	19	0.3	4.6	0.9	102.6	99.042	82.8851
2014	7	27	12	34	19	0.3	4.6	0.89	96.6	98.9764	83.1373

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	12	44	19	0.3	4.6	0.88	99.6	99.042	81.9572
2014	7	27	12	54	19	0.3	4.6	0.86	101.2	98.9764	79.7376
2014	7	27	13	4	19	0.3	4.6	0.9	101.2	99.042	82.885
2014	7	27	13	14	19	0.3	4.6	0.87	98.9	98.9764	80.6648
2014	7	27	13	24	19	0.3	4.6	0.9	99.7	98.9764	83.1372
2014	7	27	13	34	19	0.3	4.6	0.87	95.2	98.9108	81.8448
2014	7	27	13	44	19	0.3	4.6	0.86	94.2	98.9108	80.6094
2014	7	27	13	54	19	0.3	4.6	0.89	91.9	98.9108	83.389
2014	7	27	14	4	19	0.3	4.6	0.85	95.8	98.9108	79.6828
2014	7	27	14	14	19	0.3	4.6	0.9	94	98.9108	84.3156
2014	7	27	14	24	19	0.3	4.6	0.9	95.2	98.8452	84.5663
2014	7	27	14	34	19	0.3	4.6	0.9	92.7	98.9108	84.6244
2014	7	27	14	44	19	0.3	4.6	0.88	94.7	98.9108	82.4625
2014	7	27	14	54	19	0.3	4.6	0.87	96.7	98.8452	81.48
2014	7	27	15	4	19	0.3	4.6	0.91	96.2	98.8452	84.875
2014	7	27	15	14	19	0.3	4.6	0.88	95.2	98.8452	82.0972
2014	7	27	15	24	19	0.3	4.6	0.91	95.4	98.8452	84.8749
2014	7	27	15	34	19	0.3	4.6	0.88	95.6	98.8452	82.0971
2014	7	27	15	44	19	0.3	4.6	0.89	97.8	98.8452	83.3317
2014	7	27	15	54	19	0.3	4.6	0.89	94	98.7795	83.2744
2014	7	27	16	4	19	0.3	4.6	0.9	95.6	98.8452	84.5662
2014	7	27	16	14	19	0.3	4.6	0.89	96.8	98.8452	83.3316
2014	7	27	16	24	19	0.3	4.6	0.88	97.9	98.8452	82.4057
2014	7	27	16	34	19	0.3	4.6	0.9	96.2	98.8452	84.5662
2014	7	27	16	44	19	0.3	4.6	0.89	97.4	98.8452	83.023
2014	7	27	16	54	19	0.3	4.6	0.89	95.7	98.8452	83.3316
2014	7	27	17	4	19	0.3	4.6	0.87	97.3	98.8452	81.4798
2014	7	27	17	14	19	0.3	4.6	0.9	94.6	98.8452	84.5661
2014	7	27	17	24	19	0.3	4.6	0.89	97.2	98.8452	82.7143
2014	7	27	17	34	19	0.3	4.6	0.93	94.5	98.8452	87.0352
2014	7	27	17	44	19	0.3	4.6	0.89	97.2	98.7795	83.2744
2014	7	27	17	54	19	0.3	4.6	0.89	97.4	98.8452	83.3316
2014	7	27	18	4	19	0.3	4.6	0.9	97.5	98.7795	84.1996
2014	7	27	18	14	19	0.3	4.6	0.89	95.5	98.8452	83.6402
2014	7	27	18	24	19	0.3	4.6	0.89	96.5	98.8452	83.3316
2014	7	27	18	34	19	0.3	4.6	0.91	95	98.8452	84.8748
2014	7	27	18	44	19	0.3	4.6	0.86	93.5	98.7795	81.1154
2014	7	27	18	54	19	0.3	4.6	0.91	95.6	98.7795	84.8165
2014	7	27	19	4	19	0.3	4.6	0.88	93.2	98.8452	82.4057
2014	7	27	19	14	19	0.3	4.6	0.88	94.9	98.8452	82.7143
2014	7	27	19	24	19	0.3	4.6	0.86	94.2	98.7795	80.1901
2014	7	27	19	34	19	0.3	4.6	0.88	93.2	98.8452	82.4057
2014	7	27	19	44	19	0.3	4.6	0.86	94.8	98.8452	80.5538
2014	7	27	19	54	19	0.3	4.6	0.87	96.2	98.8452	81.7884
2014	7	27	20	4	19	0.3	4.6	0.92	97.4	98.8452	86.1093
2014	7	27	20	14	19	0.3	4.6	0.89	96.5	98.8452	83.6402

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	20	24	19	0.3	4.6	0.87	95	98.8452	81.7884
2014	7	27	20	34	19	0.3	4.6	0.9	94.2	98.8452	84.566
2014	7	27	20	44	19	0.3	4.6	0.88	94.1	98.8452	82.4056
2014	7	27	20	54	19	0.3	4.6	0.88	94.5	98.8452	82.097
2014	7	27	21	4	19	0.3	4.6	0.86	95	98.8452	80.5538
2014	7	27	21	14	19	0.3	4.6	0.88	91.1	98.9108	83.0799
2014	7	27	21	24	19	0.3	4.6	0.88	93.8	98.9108	82.771
2014	7	27	21	34	19	0.3	4.6	0.87	92.6	98.9108	82.1533
2014	7	27	21	44	19	0.3	4.6	0.88	94.1	98.9108	82.771
2014	7	27	21	54	19	0.3	4.6	0.85	94.2	98.9108	79.3737
2014	7	27	22	4	19	0.3	4.6	0.89	95.1	98.9108	83.6976
2014	7	27	22	14	19	0.3	4.6	0.89	95.1	98.9108	83.0799
2014	7	27	22	24	19	0.3	4.6	0.86	93.7	98.9108	80.9179
2014	7	27	22	34	19	0.3	4.6	0.85	92.9	98.9108	79.6825
2014	7	27	22	44	19	0.3	4.6	0.84	93.8	98.9108	79.0648
2014	7	27	22	54	19	0.3	4.6	0.91	95	98.9108	85.2418
2014	7	27	23	4	19	0.3	4.6	0.9	94	98.9108	84.6241
2014	7	27	23	14	19	0.3	4.6	0.87	96.5	98.9108	81.8444
2014	7	27	23	24	19	0.3	4.6	0.86	92.6	98.9108	80.9179
2014	7	27	23	34	19	0.3	4.6	0.87	95	98.9108	81.2267
2014	7	27	23	44	19	0.3	4.6	0.91	93.7	98.9108	85.2417
2014	7	27	23	54	19	0.3	4.6	0.87	94.1	98.9108	81.2267
2014	7	28	0	4	19	0.3	4.6	0.89	94.6	98.9108	83.6975
2014	7	28	0	14	19	0.3	4.6	0.88	93.6	98.9108	82.4621
2014	7	28	0	24	19	0.3	4.6	0.87	93.2	98.9764	82.2097
2014	7	28	0	34	19	0.3	4.6	0.88	92.1	98.9108	83.0798
2014	7	28	0	44	19	0.3	4.6	0.87	96	98.9108	81.8444
2014	7	28	0	54	19	0.3	4.6	0.86	94.1	98.9108	80.9179
2014	7	28	1	4	19	0.3	4.6	0.87	93.3	98.9108	81.5356
2014	7	28	1	14	19	0.3	4.6	0.87	94.1	98.9108	81.8444
2014	7	28	1	24	19	0.3	4.6	0.87	93.4	98.9108	82.1533
2014	7	28	1	34	19	0.3	4.6	0.89	95.1	98.9108	83.6975
2014	7	28	1	44	19	0.3	4.6	0.88	94.5	98.9108	82.771
2014	7	28	1	54	19	0.3	4.6	0.88	95.5	98.9108	82.771
2014	7	28	2	4	19	0.3	4.6	0.89	95.3	98.9764	83.755
2014	7	28	2	14	19	0.3	4.6	0.9	95.2	98.9764	84.6821
2014	7	28	2	24	19	0.3	4.6	0.88	94.3	98.9764	83.1368
2014	7	28	2	34	19	0.3	4.6	0.89	94.9	98.9764	83.4459
2014	7	28	2	44	19	0.3	4.6	0.88	95.8	98.9764	82.2097
2014	7	28	2	54	19	0.3	4.6	0.91	93.9	98.9764	85.6093
2014	7	28	3	4	19	0.3	4.6	0.87	95.4	98.9764	81.5916
2014	7	28	3	14	19	0.3	4.6	0.89	94.9	98.9764	83.755
2014	7	28	3	24	19	0.3	4.6	0.9	93.7	98.9764	84.9912
2014	7	28	3	34	19	0.3	4.6	0.89	96.8	98.9764	83.446
2014	7	28	3	44	19	0.3	4.6	0.88	94.9	98.9764	82.2097
2014	7	28	3	54	19	0.3	4.6	0.87	93.5	98.9764	81.9007

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	4	4	19	0.3	4.6	0.88	94.9	98.9764	82.8279
2014	7	28	4	14	19	0.3	4.6	0.89	94	98.9764	83.755
2014	7	28	4	24	19	0.3	4.6	0.88	93.8	98.9764	82.8279
2014	7	28	4	34	19	0.3	4.6	0.89	95.1	98.9764	83.7551
2014	7	28	4	44	19	0.3	4.6	0.86	94	98.9764	80.3554
2014	7	28	4	54	19	0.3	4.6	0.89	94.9	98.9764	83.7551
2014	7	28	5	4	19	0.3	4.6	0.9	94.8	98.9764	84.3732
2014	7	28	5	14	19	0.3	4.6	0.89	95.3	98.9764	83.137
2014	7	28	5	24	19	0.3	4.6	0.91	93.9	98.9764	85.9185
2014	7	28	5	34	19	0.3	4.6	0.89	93.8	99.042	83.5033
2014	7	28	5	44	19	0.3	4.6	0.89	92.9	99.042	84.1218
2014	7	28	5	54	19	0.3	4.6	0.91	95	99.042	85.0497
2014	7	28	6	4	19	0.3	4.6	0.9	93.4	99.1076	84.489
2014	7	28	6	14	19	0.3	4.6	0.91	95.4	99.1076	85.108
2014	7	28	6	24	19	0.3	4.6	0.88	94.3	99.1076	82.6321
2014	7	28	6	34	19	0.3	4.6	0.9	96.1	99.1732	84.5469
2014	7	28	6	44	19	0.3	4.6	0.89	93.6	99.1732	83.6179
2014	7	28	6	54	19	0.3	4.6	0.9	95.9	99.2388	84.6048
2014	7	28	7	4	19	0.3	4.6	0.89	94.7	99.2388	83.3652
2014	7	28	7	14	19	0.3	4.6	0.91	96	99.2388	85.2246
2014	7	28	7	24	19	0.3	4.6	0.87	95.8	99.3045	82.1818
2014	7	28	7	34	19	0.3	4.6	0.88	96.4	99.3045	83.1121
2014	7	28	7	44	19	0.3	4.6	0.9	94.4	99.3045	84.6627
2014	7	28	7	54	19	0.3	4.6	0.9	95	99.3045	84.3526
2014	7	28	8	4	19	0.3	4.6	0.86	94.8	99.3045	81.2514
2014	7	28	8	14	19	0.3	4.6	0.87	96.3	99.3045	81.8717
2014	7	28	8	24	19	0.3	4.6	0.89	94	99.3045	83.7324
2014	7	28	8	34	19	0.3	4.6	0.89	94	99.3045	83.7324
2014	7	28	8	44	19	0.3	4.6	0.91	97.9	99.3045	84.9728
2014	7	28	8	54	19	0.3	4.6	0.92	97.6	99.2388	85.8445
2014	7	28	9	4	19	0.3	4.6	0.91	97.8	99.2388	85.5345
2014	7	28	9	14	19	0.3	4.6	0.91	98.9	99.2388	85.2246
2014	7	28	9	24	19	0.3	4.6	0.9	98.2	99.1732	83.6179
2014	7	28	9	34	19	0.3	4.6	0.91	95.6	99.1732	85.7857
2014	7	28	9	44	19	0.3	4.6	0.91	97.1	99.1732	84.8566
2014	7	28	9	54	19	0.3	4.6	0.92	99.5	99.1732	85.476
2014	7	28	10	4	19	0.3	4.6	0.94	99	99.1732	87.9535
2014	7	28	10	14	19	0.3	4.6	0.9	94.6	99.1732	84.2372
2014	7	28	10	24	19	0.3	4.6	0.91	96.4	99.1076	85.4174
2014	7	28	10	34	19	0.3	4.6	0.91	97.7	99.1732	85.1662
2014	7	28	10	44	19	0.3	4.6	0.91	96	99.1076	85.1079
2014	7	28	10	54	19	0.3	4.6	0.92	97.8	99.1076	86.0363
2014	7	28	11	4	19	0.3	4.6	0.89	98.3	99.1076	82.632
2014	7	28	11	14	19	0.3	4.6	0.9	99.2	99.1732	83.9274
2014	7	28	11	24	19	0.3	4.6	0.91	99.8	99.1076	84.1794
2014	7	28	11	34	19	0.3	4.6	0.91	100.4	99.1076	84.1794

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	11	44	19	0.3	4.6	0.91	97.7	99.1076	85.1079
2014	7	28	11	54	19	0.3	4.6	0.91	96.6	99.1732	85.7856
2014	7	28	12	4	19	0.3	4.6	0.91	95.2	99.1732	85.4759
2014	7	28	12	14	19	0.3	4.6	0.88	98.4	99.1732	82.0691
2014	7	28	12	24	19	0.3	4.6	0.88	97.9	99.1732	82.6885
2014	7	28	12	34	19	0.3	4.6	0.88	98.4	99.1732	82.0691
2014	7	28	12	44	19	0.3	4.6	0.9	97.1	99.1076	84.1794
2014	7	28	12	54	19	0.3	4.6	0.89	97.7	99.042	82.8846
2014	7	28	13	4	19	0.3	4.6	0.89	99.5	99.1076	83.2509
2014	7	28	13	14	19	0.3	4.6	0.88	102.1	99.1076	80.775
2014	7	28	13	24	19	0.3	4.6	0.89	97.7	99.1076	82.9414
2014	7	28	13	34	19	0.3	4.6	0.9	96.9	99.042	83.8124
2014	7	28	13	44	19	0.3	4.6	0.89	97.2	99.042	83.5031
2014	7	28	13	54	19	0.3	4.6	0.9	98.6	99.042	83.5032
2014	7	28	14	4	19	0.3	4.6	0.9	98.8	98.9764	84.064
2014	7	28	14	14	19	0.3	4.6	0.92	95.1	99.042	86.2866
2014	7	28	14	24	19	0.3	4.6	0.91	97.3	99.042	85.0495
2014	7	28	14	34	19	0.3	4.6	0.91	98.7	99.042	84.7402
2014	7	28	14	44	19	0.3	4.6	0.91	97	99.042	85.0495
2014	7	28	14	54	19	0.3	4.6	0.87	100.2	99.042	81.029
2014	7	28	15	4	19	0.3	4.6	0.91	96	99.042	85.0495
2014	7	28	15	14	19	0.3	4.6	0.91	95	99.1076	85.7268
2014	7	28	15	24	19	0.3	4.6	0.89	93.6	99.042	83.8124
2014	7	28	15	34	19	0.3	4.6	0.9	94	99.042	84.431
2014	7	28	15	44	19	0.3	4.6	0.88	95.2	99.042	82.2661
2014	7	28	15	54	19	0.3	4.6	0.94	94	99.042	88.7608
2014	7	28	16	4	19	0.3	4.6	0.88	94.9	99.042	82.2661
2014	7	28	16	14	19	0.3	4.6	0.88	93.2	99.1076	82.632
2014	7	28	16	24	19	0.3	4.6	0.88	93	99.042	82.5754
2014	7	28	16	34	19	0.3	4.6	0.89	93.8	99.1076	83.5604
2014	7	28	16	44	19	0.3	4.6	0.89	94.7	99.1076	83.2509
2014	7	28	16	54	19	0.3	4.6	0.88	93.2	99.1076	83.2509
2014	7	28	17	4	19	0.3	4.6	0.89	95.3	99.1076	83.8699
2014	7	28	17	14	19	0.3	4.6	0.87	93	99.1076	82.3225
2014	7	28	17	24	19	0.3	4.6	0.84	93.4	99.1076	79.2277
2014	7	28	17	34	19	0.3	4.6	0.88	93.2	99.1076	83.2509
2014	7	28	17	44	19	0.3	4.6	0.89	94.2	99.1076	84.1794
2014	7	28	17	54	19	0.3	4.6	0.9	95	99.1076	84.4888
2014	7	28	18	4	19	0.3	4.6	0.9	94.6	99.1076	84.7983
2014	7	28	18	14	19	0.3	4.6	0.9	93.1	99.1732	85.1661
2014	7	28	18	24	19	0.3	4.6	0.89	94.2	99.1732	83.9273
2014	7	28	18	34	19	0.3	4.6	0.92	94.5	99.1732	86.4049
2014	7	28	18	44	19	0.3	4.6	0.89	95.9	99.1076	83.8699
2014	7	28	18	54	19	0.3	4.6	0.9	93.6	99.1076	84.7983
2014	7	28	19	4	19	0.3	4.6	0.89	93.4	99.1732	83.9273
2014	7	28	19	14	19	0.3	4.6	0.88	94.5	99.1732	82.3789

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	19	24	19	0.3	4.6	0.88	94.3	99.1732	82.3789
2014	7	28	19	34	19	0.3	4.6	0.88	95.5	99.1732	82.9983
2014	7	28	19	44	19	0.3	4.6	0.87	94.3	99.1732	81.7595
2014	7	28	19	54	19	0.3	4.6	0.87	92.8	99.2388	82.1253
2014	7	28	20	4	19	0.3	4.6	0.88	96.4	99.3045	83.1119
2014	7	28	20	14	19	0.3	4.6	0.9	92.9	99.3045	84.6625
2014	7	28	20	24	19	0.3	4.6	0.88	94	99.3701	83.479
2014	7	28	20	34	19	0.3	4.6	0.88	92.6	99.3701	82.8584
2014	7	28	20	44	19	0.3	4.6	0.9	96.5	99.3701	84.7204
2014	7	28	20	54	19	0.3	4.6	0.89	94.9	99.3701	83.7894
2014	7	28	21	4	19	0.3	4.6	0.89	93.8	99.4357	84.1572
2014	7	28	21	14	19	0.3	4.6	0.9	94	99.4357	84.7783
2014	7	28	21	24	19	0.3	4.6	0.9	93.3	99.4357	85.3994
2014	7	28	21	34	19	0.3	4.6	0.9	95.2	99.4357	85.0888
2014	7	28	21	44	19	0.3	4.6	0.93	96.5	99.4357	87.5732
2014	7	28	21	54	19	0.3	4.6	0.91	95.4	99.4357	85.7099
2014	7	28	22	4	19	0.3	4.6	0.89	93.2	99.4357	83.8466
2014	7	28	22	14	19	0.3	4.6	0.88	96.2	99.4357	82.915
2014	7	28	22	24	19	0.3	4.6	0.9	94.2	99.4357	85.0888
2014	7	28	22	34	19	0.3	4.6	0.9	95	99.4357	84.4678
2014	7	28	22	44	19	0.3	4.6	0.87	95	99.4357	81.6729
2014	7	28	22	54	19	0.3	4.6	0.93	95.1	99.4357	87.2626
2014	7	28	23	4	19	0.3	4.6	0.9	96	99.4357	85.0888
2014	7	28	23	14	19	0.3	4.6	0.89	93.6	99.5013	84.2147
2014	7	28	23	24	19	0.3	4.6	0.88	95.1	99.5013	82.9717
2014	7	28	23	34	19	0.3	4.6	0.88	95.8	99.5013	82.9717
2014	7	28	23	44	19	0.3	4.6	0.91	95.4	99.5013	85.4577
2014	7	28	23	54	19	0.3	4.6	0.88	95.8	99.5013	82.9717
2014	7	29	0	4	19	0.3	4.6	0.88	93.4	99.5013	83.2824
2014	7	29	0	14	19	0.3	4.6	0.88	95.8	99.5013	82.9717
2014	7	29	0	24	19	0.3	4.6	0.89	95.7	99.5013	84.2147
2014	7	29	0	34	19	0.3	4.6	0.89	94.2	99.5013	84.2147
2014	7	29	0	44	19	0.3	4.6	0.88	93.2	99.5013	82.9717
2014	7	29	0	54	19	0.3	4.6	0.89	94	99.5013	83.904
2014	7	29	1	4	19	0.3	4.6	0.89	94.2	99.5013	84.2147
2014	7	29	1	14	19	0.3	4.6	0.88	94.1	99.5013	83.2825
2014	7	29	1	24	19	0.3	4.6	0.88	92.8	99.5013	83.2825
2014	7	29	1	34	19	0.3	4.6	0.87	92.2	99.5013	82.661
2014	7	29	1	44	19	0.3	4.6	0.88	92.8	99.5013	83.2825
2014	7	29	1	54	19	0.3	4.6	0.87	95.4	99.5013	82.0395
2014	7	29	2	4	19	0.3	4.6	0.87	95.4	99.5013	82.0395
2014	7	29	2	14	19	0.3	4.6	0.88	94	99.5013	83.5933
2014	7	29	2	24	19	0.3	4.6	0.88	96	99.5013	82.661
2014	7	29	2	34	19	0.3	4.6	0.91	94.5	99.5013	86.0793
2014	7	29	2	44	19	0.3	4.6	0.88	94.9	99.5013	83.2825
2014	7	29	2	54	19	0.3	4.6	0.88	96.4	99.5013	82.9718

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	3	4	19	0.3	4.6	0.88	94.3	99.5013	83.5933
2014	7	29	3	14	19	0.3	4.6	0.89	92.9	99.5669	84.5833
2014	7	29	3	24	19	0.3	4.6	0.91	96	99.5013	86.0793
2014	7	29	3	34	19	0.3	4.6	0.87	93.9	99.5669	82.4065
2014	7	29	3	44	19	0.3	4.6	0.89	93.6	99.5013	84.5256
2014	7	29	3	54	19	0.3	4.6	0.89	94.2	99.5013	84.5256
2014	7	29	4	4	19	0.3	4.6	0.9	93.8	99.5013	84.8363
2014	7	29	4	14	19	0.3	4.6	0.88	94.1	99.5669	83.3394
2014	7	29	4	24	19	0.3	4.6	0.87	94.1	99.5013	82.0396
2014	7	29	4	34	19	0.3	4.6	0.89	90.4	99.5013	83.9041
2014	7	29	4	44	19	0.3	4.6	0.89	96.2	99.5669	83.6504
2014	7	29	4	54	19	0.3	4.6	0.9	94.6	99.5669	84.5833
2014	7	29	5	4	19	0.3	4.6	0.89	92.3	99.5669	83.9614
2014	7	29	5	14	19	0.3	4.6	0.88	94.7	99.5669	83.0285
2014	7	29	5	24	19	0.3	4.6	0.88	94.9	99.5669	83.3394
2014	7	29	5	34	19	0.3	4.6	0.91	96.7	99.5669	85.2053
2014	7	29	5	44	19	0.3	4.6	0.9	94.4	99.5669	85.5162
2014	7	29	5	54	19	0.3	4.6	0.88	95.1	99.5669	83.0285
2014	7	29	6	4	19	0.3	4.6	0.89	94.9	99.5669	84.2724
2014	7	29	6	14	19	0.3	4.6	0.89	95.5	99.5669	84.2724
2014	7	29	6	24	19	0.3	4.6	0.88	97.1	99.5669	82.7175
2014	7	29	6	34	19	0.3	4.6	0.87	93.5	99.5669	82.4066
2014	7	29	6	44	19	0.3	4.6	0.91	92.5	99.5669	86.1382
2014	7	29	6	54	19	0.3	4.6	0.89	96.3	99.5669	83.9614
2014	7	29	7	4	19	0.3	4.6	0.9	94	99.5669	85.5163
2014	7	29	7	14	19	0.3	4.6	0.88	94.9	99.5669	83.3395
2014	7	29	7	24	19	0.3	4.6	0.87	91.9	99.5669	82.4066
2014	7	29	7	34	19	0.3	4.6	0.88	91.9	99.5669	83.6505
2014	7	29	7	44	19	0.3	4.6	0.9	96	99.5669	85.2053
2014	7	29	7	54	19	0.3	4.6	0.9	94.2	99.5669	85.2053
2014	7	29	8	4	19	0.3	4.6	0.87	94.6	99.5669	81.7846
2014	7	29	8	14	19	0.3	4.6	0.89	92.3	99.5669	83.9614
2014	7	29	8	24	19	0.3	4.6	0.87	93.9	99.5669	82.4066
2014	7	29	8	34	19	0.3	4.6	0.9	95.3	99.5669	84.5833
2014	7	29	8	44	19	0.3	4.6	0.86	94.2	99.5669	81.1627
2014	7	29	8	54	19	0.3	4.6	0.89	95.3	99.5669	83.6504
2014	7	29	9	4	19	0.3	4.6	0.88	94.3	99.5669	83.0285
2014	7	29	9	14	19	0.3	4.6	0.89	94	99.5013	84.2148
2014	7	29	9	24	19	0.3	4.6	0.89	95.1	99.5669	83.9613
2014	7	29	9	34	19	0.3	4.6	0.87	95.2	99.5013	82.0396
2014	7	29	9	44	19	0.3	4.6	0.87	92.6	99.5669	82.7175
2014	7	29	9	54	19	0.3	4.6	0.88	93.4	99.5669	83.3394
2014	7	29	10	4	19	0.3	4.6	0.88	94.3	99.5013	83.5933
2014	7	29	10	14	19	0.3	4.6	0.88	91.5	99.5013	82.9718
2014	7	29	10	24	19	0.3	4.6	0.86	92.6	99.5013	81.1072
2014	7	29	10	34	19	0.3	4.6	0.89	93.8	99.5013	83.904

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	10	44	19	0.3	4.6	0.89	93.2	99.5013	83.904
2014	7	29	10	54	19	0.3	4.6	0.9	94.4	99.5013	85.4577
2014	7	29	11	4	19	0.3	4.6	0.92	93.1	99.5013	87.0115
2014	7	29	11	14	19	0.3	4.6	0.9	95.7	99.5013	84.5255
2014	7	29	11	24	19	0.3	4.6	0.9	95.4	99.5013	84.8362
2014	7	29	11	34	19	0.3	4.6	0.89	95.1	99.4357	84.1572
2014	7	29	11	44	19	0.3	4.6	0.89	94.9	99.4357	84.1572
2014	7	29	11	54	19	0.3	4.6	0.89	95.5	99.4357	83.8466
2014	7	29	12	4	19	0.3	4.6	0.92	95.3	99.4357	86.331
2014	7	29	12	14	19	0.3	4.6	0.93	94.8	99.4357	87.8837
2014	7	29	12	24	19	0.3	4.6	0.88	95.3	99.4357	82.9149
2014	7	29	12	34	19	0.3	4.6	0.89	93.8	99.2388	83.9847
2014	7	29	12	44	19	0.3	4.6	0.9	94.6	99.3045	84.9725
2014	7	29	12	54	19	0.3	4.6	0.92	93.9	99.2388	86.4639
2014	7	29	13	4	19	0.3	4.6	0.91	94.1	99.2388	85.8441
2014	7	29	13	14	19	0.3	4.6	0.91	94.6	99.2388	85.5342
2014	7	29	13	24	19	0.3	4.6	0.91	95.6	99.3045	85.5927
2014	7	29	13	34	19	0.3	4.6	0.9	97.3	99.1732	84.2369
2014	7	29	13	44	19	0.3	4.6	0.89	95.1	99.1732	83.6175
2014	7	29	13	54	19	0.3	4.6	0.87	95.2	99.1732	81.4496
2014	7	29	14	4	19	0.3	4.6	0.89	95.1	99.1732	83.9271
2014	7	29	14	14	19	0.3	4.6	0.9	95.5	99.1732	84.2368
2014	7	29	14	24	19	0.3	4.6	0.89	93.6	99.1732	84.2368
2014	7	29	14	34	19	0.3	4.6	0.9	96.1	99.1732	84.5464
2014	7	29	14	44	19	0.3	4.6	0.9	95.3	99.1732	84.2367
2014	7	29	14	54	19	0.3	4.6	0.91	94.8	99.1076	85.1075
2014	7	29	15	4	19	0.3	4.6	0.89	95.5	99.1076	83.5601
2014	7	29	15	14	19	0.3	4.6	0.9	94	99.1076	84.4885
2014	7	29	15	24	19	0.3	4.6	0.89	95.3	99.1076	83.8695
2014	7	29	15	34	19	0.3	4.6	0.92	94.1	99.1076	86.3454
2014	7	29	15	44	19	0.3	4.6	0.87	94.3	99.1076	82.0126
2014	7	29	15	54	19	0.3	4.6	0.86	95.5	99.1076	81.0842
2014	7	29	16	4	19	0.3	4.6	0.88	92.4	99.1076	82.6316
2014	7	29	16	14	19	0.3	4.6	0.89	94.2	99.1732	83.927
2014	7	29	16	24	19	0.3	4.6	0.88	93.6	99.1076	82.9411
2014	7	29	16	34	19	0.3	4.6	0.9	97.1	99.1076	84.179
2014	7	29	16	44	19	0.3	4.6	0.91	95.6	99.1076	85.4169
2014	7	29	16	54	19	0.3	4.6	0.91	96.2	99.042	85.3584
2014	7	29	17	4	19	0.3	4.6	0.89	94.2	99.1076	83.8695
2014	7	29	17	14	19	0.3	4.6	0.9	93.6	99.042	84.4305
2014	7	29	17	24	19	0.3	4.6	0.9	95.5	99.042	84.1213
2014	7	29	17	34	19	0.3	4.6	0.87	93.2	99.042	82.2657
2014	7	29	17	44	19	0.3	4.6	0.91	94.8	99.042	85.0491
2014	7	29	17	54	19	0.3	4.6	0.9	95.9	99.042	84.4305
2014	7	29	18	4	19	0.3	4.6	0.88	95.1	99.042	82.5749
2014	7	29	18	14	19	0.3	4.6	0.9	93.4	99.042	84.4305

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	18	24	19	0.3	4.6	0.86	95.9	99.042	80.7193
2014	7	29	18	34	19	0.3	4.6	0.88	95.1	99.042	82.8842
2014	7	29	18	44	19	0.3	4.6	0.88	94.5	99.042	82.5749
2014	7	29	18	54	19	0.3	4.6	0.88	94.5	99.042	82.8842
2014	7	29	19	4	19	0.3	4.6	0.88	94.1	99.042	82.8841
2014	7	29	19	14	19	0.3	4.6	0.9	95	99.042	84.7397
2014	7	29	19	24	19	0.3	4.6	0.89	94.9	99.042	83.5027
2014	7	29	19	34	19	0.3	4.6	0.89	94.4	99.042	83.5027
2014	7	29	19	44	19	0.3	4.6	0.88	94.5	99.042	82.5748
2014	7	29	19	54	19	0.3	4.6	0.9	94	99.042	84.4305
2014	7	29	20	4	19	0.3	4.6	0.89	96.3	99.042	83.5026
2014	7	29	20	14	19	0.3	4.6	0.92	94.9	99.042	86.5953
2014	7	29	20	24	19	0.3	4.6	0.88	94.3	99.042	83.1933
2014	7	29	20	34	19	0.3	4.6	0.88	93.2	99.042	82.8841
2014	7	29	20	44	19	0.3	4.6	0.88	95.3	99.1076	82.9409
2014	7	29	20	54	19	0.3	4.6	0.91	96.8	99.042	85.0489
2014	7	29	21	4	19	0.3	4.6	0.91	95.6	99.042	85.3582
2014	7	29	21	14	19	0.3	4.6	0.89	94.6	99.042	83.8118
2014	7	29	21	24	19	0.3	4.6	0.87	92.4	99.042	81.647
2014	7	29	21	34	19	0.3	4.6	0.87	93.3	99.042	81.647
2014	7	29	21	44	19	0.3	4.6	0.87	95.2	99.042	81.647
2014	7	29	21	54	19	0.3	4.6	0.86	92.6	99.1076	80.7745
2014	7	29	22	4	19	0.3	4.6	0.88	93.4	99.042	82.5748
2014	7	29	22	14	19	0.3	4.6	0.89	93.6	99.042	83.8118
2014	7	29	22	24	19	0.3	4.6	0.88	95.6	99.1076	82.6314
2014	7	29	22	34	19	0.3	4.6	0.88	94.3	99.1076	82.9408
2014	7	29	22	44	19	0.3	4.6	0.89	93.2	99.1076	83.8693
2014	7	29	22	54	19	0.3	4.6	0.88	94.5	99.042	82.5747
2014	7	29	23	4	19	0.3	4.6	0.89	94.2	99.1076	84.1787
2014	7	29	23	14	19	0.3	4.6	0.85	93.5	99.042	80.4098
2014	7	29	23	24	19	0.3	4.6	0.91	93.7	99.042	85.6674
2014	7	29	23	34	19	0.3	4.6	0.88	95.2	99.1076	82.3219
2014	7	29	23	44	19	0.3	4.6	0.92	93.9	99.042	86.286
2014	7	29	23	54	19	0.3	4.6	0.86	94.2	99.042	80.7191
2014	7	30	0	4	19	0.3	4.6	0.9	94.8	99.1076	84.1787
2014	7	30	0	14	19	0.3	4.6	0.9	94.2	99.1076	85.1072
2014	7	30	0	24	19	0.3	4.6	0.89	92.8	99.1076	83.5598
2014	7	30	0	34	19	0.3	4.6	0.87	91.5	99.1076	82.3219
2014	7	30	0	44	19	0.3	4.6	0.89	95.3	99.1076	83.2503
2014	7	30	0	54	19	0.3	4.6	0.93	96.1	99.042	87.5231
2014	7	30	1	4	19	0.3	4.6	0.89	94.6	99.042	83.8118
2014	7	30	1	14	19	0.3	4.6	0.88	95.1	99.1076	82.9409
2014	7	30	1	24	19	0.3	4.6	0.91	94.8	99.1076	85.1072
2014	7	30	1	34	19	0.3	4.6	0.9	92.5	99.1076	84.7977
2014	7	30	1	44	19	0.3	4.6	0.88	94.3	99.1076	82.9409
2014	7	30	1	54	19	0.3	4.6	0.89	96.4	99.1076	83.2504

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	2	4	19	0.3	4.6	0.89	95.5	99.1076	83.5599
2014	7	30	2	14	19	0.3	4.6	0.91	95	99.1076	85.7262
2014	7	30	2	24	19	0.3	4.6	0.85	94	99.042	79.7914
2014	7	30	2	34	19	0.3	4.6	0.91	96	99.042	85.3582
2014	7	30	2	44	19	0.3	4.6	0.9	95.2	99.042	84.4305
2014	7	30	2	54	19	0.3	4.6	0.86	93.9	99.042	81.0285
2014	7	30	3	4	19	0.3	4.6	0.89	93.6	99.042	83.8119
2014	7	30	3	14	19	0.3	4.6	0.91	95.4	99.042	85.049
2014	7	30	3	24	19	0.3	4.6	0.9	95.2	99.042	84.7398
2014	7	30	3	34	19	0.3	4.6	0.9	94.8	99.1076	84.1789
2014	7	30	3	44	19	0.3	4.6	0.87	94.6	99.042	81.3378
2014	7	30	3	54	19	0.3	4.6	0.91	96.4	99.042	85.0491
2014	7	30	4	4	19	0.3	4.6	0.87	95.6	99.042	81.9564
2014	7	30	4	14	19	0.3	4.6	0.88	95.1	99.042	82.5749
2014	7	30	4	24	19	0.3	4.6	0.89	93.8	99.042	83.5027
2014	7	30	4	34	19	0.3	4.6	0.87	94.3	99.042	81.3379
2014	7	30	4	44	19	0.3	4.6	0.93	95.9	99.042	86.9047
2014	7	30	4	54	19	0.3	4.6	0.88	94.5	99.042	82.8842
2014	7	30	5	4	19	0.3	4.6	0.91	95.6	99.042	85.3584
2014	7	30	5	14	19	0.3	4.6	0.91	95	99.042	85.6677
2014	7	30	5	24	19	0.3	4.6	0.89	95.7	99.042	83.8121
2014	7	30	5	34	19	0.3	4.6	0.88	96.4	99.042	82.575
2014	7	30	5	44	19	0.3	4.6	0.89	93.8	99.042	83.5028
2014	7	30	5	54	19	0.3	4.6	0.9	95.6	99.042	84.7399
2014	7	30	6	4	19	0.3	4.6	0.9	95	99.042	84.1214
2014	7	30	6	14	19	0.3	4.6	0.9	94.2	99.042	84.4306
2014	7	30	6	24	19	0.3	4.6	0.86	94.8	99.042	80.7194
2014	7	30	6	34	19	0.3	4.6	0.9	95.3	99.042	84.1214
2014	7	30	6	44	19	0.3	4.6	0.88	95.3	99.042	82.5751
2014	7	30	6	54	19	0.3	4.6	0.89	95.5	99.042	83.5029
2014	7	30	7	4	19	0.3	4.6	0.89	94.6	99.042	83.8122
2014	7	30	7	14	19	0.3	4.6	0.91	95.6	99.042	85.6678
2014	7	30	7	24	19	0.3	4.6	0.88	94.5	99.042	82.5751
2014	7	30	7	34	19	0.3	4.6	0.9	95.2	99.042	84.74
2014	7	30	7	44	19	0.3	4.6	0.87	93.3	99.042	81.6473
2014	7	30	7	54	19	0.3	4.6	0.89	94.6	99.042	83.8122
2014	7	30	8	4	19	0.3	4.6	0.9	95.7	99.042	84.1215
2014	7	30	8	14	19	0.3	4.6	0.89	93.4	99.042	83.5029
2014	7	30	8	24	19	0.3	4.6	0.9	95.9	98.9764	84.3728
2014	7	30	8	34	19	0.3	4.6	0.89	95.1	99.042	83.8122
2014	7	30	8	44	19	0.3	4.6	0.91	94.3	99.042	85.9771
2014	7	30	8	54	19	0.3	4.6	0.88	94.3	99.042	83.1936
2014	7	30	9	4	19	0.3	4.6	0.91	94.6	99.042	85.3585
2014	7	30	9	14	19	0.3	4.6	0.89	92.5	99.042	83.8122
2014	7	30	9	24	19	0.3	4.6	0.89	92.1	98.9764	84.0638
2014	7	30	9	34	19	0.3	4.6	0.91	93.5	98.9764	85.6091

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	9	44	19	0.3	4.6	0.89	93.6	98.9764	84.0638
2014	7	30	9	54	19	0.3	4.6	0.91	94.3	98.9764	85.9181
2014	7	30	10	4	19	0.3	4.6	0.89	93.4	98.9764	84.0638
2014	7	30	10	14	19	0.3	4.6	0.88	94.3	98.9764	82.8275
2014	7	30	10	24	19	0.3	4.6	0.9	93.7	98.9764	84.9909
2014	7	30	10	34	19	0.3	4.6	0.9	93.4	98.9764	84.3728
2014	7	30	10	44	19	0.3	4.6	0.91	95.2	98.9108	85.2414
2014	7	30	10	54	19	0.3	4.6	0.88	94.1	98.9108	82.4619
2014	7	30	11	4	19	0.3	4.6	0.88	93.8	98.9108	82.7707
2014	7	30	11	14	19	0.3	4.6	0.9	95	98.9108	84.0061
2014	7	30	11	24	19	0.3	4.6	0.89	94	98.9108	84.0061
2014	7	30	11	34	19	0.3	4.6	0.9	95.2	98.9108	84.6238
2014	7	30	11	44	19	0.3	4.6	0.92	92.5	98.9108	86.168
2014	7	30	11	54	19	0.3	4.6	0.9	92.5	98.9108	84.6238
2014	7	30	12	4	19	0.3	4.6	0.92	92.9	98.8452	86.7261
2014	7	30	12	14	19	0.3	4.6	0.87	90.9	98.8452	81.4794
2014	7	30	12	24	19	0.3	4.6	0.88	93.4	98.7795	82.3487
2014	7	30	12	34	19	0.3	4.6	0.85	94.4	98.7795	79.8813
2014	7	30	12	44	19	0.3	4.6	0.88	96	98.8452	82.0967
2014	7	30	12	54	19	0.3	4.6	0.91	91.9	98.9108	85.5504
2014	7	30	13	4	19	0.3	4.6	0.9	93.4	98.9108	84.315
2014	7	30	13	14	19	0.3	4.6	0.86	91.5	98.9108	80.6088
2014	7	30	13	24	19	0.3	4.6	0.92	93.9	98.8452	86.7262
2014	7	30	13	34	19	0.3	4.6	0.87	92.4	98.9108	81.8443
2014	7	30	13	44	19	0.3	4.6	0.89	94.9	98.8452	83.3312
2014	7	30	13	54	19	0.3	4.6	0.88	93.2	98.8452	82.4054
2014	7	30	14	4	19	0.3	4.6	0.89	93.2	98.8452	83.3313
2014	7	30	14	14	19	0.3	4.6	0.86	91.1	98.8452	80.8622
2014	7	30	14	24	19	0.3	4.6	0.86	90.4	98.8452	80.5536
2014	7	30	14	34	19	0.3	4.6	0.86	93.9	98.8452	81.1708
2014	7	30	14	44	19	0.3	4.6	0.86	92.2	98.8452	80.5536
2014	7	30	14	54	19	0.3	4.6	0.84	93.6	98.8452	79.0104
2014	7	30	15	4	19	0.3	4.6	0.87	94.1	98.8452	82.0967
2014	7	30	15	14	19	0.3	4.6	0.89	92.5	98.8452	83.9486
2014	7	30	15	24	19	0.3	4.6	0.88	92.1	98.8452	82.4054
2014	7	30	15	34	19	0.3	4.6	0.89	94.2	98.8452	83.6399
2014	7	30	15	44	19	0.3	4.6	0.89	92.3	98.8452	83.3313
2014	7	30	15	54	19	0.3	4.6	0.88	94.3	98.8452	83.0227
2014	7	30	16	4	19	0.3	4.6	0.89	93.6	98.8452	83.9486
2014	7	30	16	14	19	0.3	4.6	0.91	95.8	98.8452	85.1831
2014	7	30	16	24	19	0.3	4.6	0.85	92.2	98.8452	80.245
2014	7	30	16	34	19	0.3	4.6	0.9	92.7	98.8452	84.2572
2014	7	30	16	44	19	0.3	4.6	0.89	91.5	98.8452	83.9486
2014	7	30	16	54	19	0.3	4.6	0.84	95.6	98.8452	79.0104
2014	7	30	17	4	19	0.3	4.6	0.89	94.4	98.8452	83.3313
2014	7	30	17	14	19	0.3	4.6	0.86	92	98.8452	80.5536

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	17	24	19	0.3	4.6	0.86	93.5	98.8452	80.8622
2014	7	30	17	34	19	0.3	4.6	0.88	94.7	98.8452	82.4054
2014	7	30	17	44	19	0.3	4.6	0.88	93.2	98.8452	83.0227
2014	7	30	17	54	19	0.3	4.6	0.87	93.9	98.8452	81.7881
2014	7	30	18	4	19	0.3	4.6	0.9	94.8	98.7795	84.1993
2014	7	30	18	14	19	0.3	4.6	0.89	95.3	98.7795	83.5825
2014	7	30	18	24	19	0.3	4.6	0.88	93.4	98.8452	82.4054
2014	7	30	18	34	19	0.3	4.6	0.88	95.1	98.7795	82.6572
2014	7	30	18	44	19	0.3	4.6	0.89	95.1	98.7795	83.5825
2014	7	30	18	54	19	0.3	4.6	0.88	93.6	98.7795	82.9657
2014	7	30	19	4	19	0.3	4.6	0.89	95.3	98.7795	82.9657
2014	7	30	19	14	19	0.3	4.6	0.9	94	98.7795	84.1994
2014	7	30	19	24	19	0.3	4.6	0.88	92.4	98.7795	82.6572
2014	7	30	19	34	19	0.3	4.6	0.89	93	98.7795	83.5825
2014	7	30	19	44	19	0.3	4.6	0.87	94.1	98.7795	81.1151
2014	7	30	19	54	19	0.3	4.6	0.86	94.1	98.7795	80.8067
2014	7	30	20	4	19	0.3	4.6	0.89	92.5	98.7795	83.5825
2014	7	30	20	14	19	0.3	4.6	0.9	92.7	98.7795	84.1994
2014	7	30	20	24	19	0.3	4.6	0.89	94.6	98.7795	83.5825
2014	7	30	20	34	19	0.3	4.6	0.88	94.3	98.7795	82.9657
2014	7	30	20	44	19	0.3	4.6	0.91	93.9	98.7795	85.4331
2014	7	30	20	54	19	0.3	4.6	0.9	93.4	98.7795	84.1994
2014	7	30	21	4	19	0.3	4.6	0.88	94.3	98.7795	82.9657
2014	7	30	21	14	19	0.3	4.6	0.87	94.5	98.7795	81.7321
2014	7	30	21	24	19	0.3	4.6	0.89	93	98.7795	83.5826
2014	7	30	21	34	19	0.3	4.6	0.89	95.1	98.7795	82.9658
2014	7	30	21	44	19	0.3	4.6	0.9	93.1	98.7795	84.8163
2014	7	30	21	54	19	0.3	4.6	0.89	96.2	98.7795	82.9658
2014	7	30	22	4	19	0.3	4.6	0.85	92.2	98.7795	80.19
2014	7	30	22	14	19	0.3	4.6	0.88	94.5	98.7795	82.0405
2014	7	30	22	24	19	0.3	4.6	0.89	94.4	98.7795	83.5826
2014	7	30	22	34	19	0.3	4.6	0.9	94.6	98.7795	84.5079
2014	7	30	22	44	19	0.3	4.6	0.88	93.8	98.7795	82.6574
2014	7	30	22	54	19	0.3	4.6	0.89	94	98.7139	83.217
2014	7	30	23	4	19	0.3	4.6	0.89	94.2	98.7795	83.8911
2014	7	30	23	14	19	0.3	4.6	0.91	95	98.7795	85.4332
2014	7	30	23	24	19	0.3	4.6	0.88	94.5	98.7139	81.9842
2014	7	30	23	34	19	0.3	4.6	0.88	94	98.7139	82.9088
2014	7	30	23	44	19	0.3	4.6	0.9	94.6	98.7139	84.4499
2014	7	30	23	54	19	0.3	4.6	0.92	94.9	98.7139	85.9909
2014	7	31	0	4	19	0.3	4.6	0.9	94	98.7139	84.4499
2014	7	31	0	14	19	0.3	4.6	0.85	93.5	98.7139	80.1349
2014	7	31	0	24	19	0.3	4.6	0.85	90.9	98.7139	80.1349
2014	7	31	0	34	19	0.3	4.6	0.9	95	98.7139	84.1417
2014	7	31	0	44	19	0.3	4.6	0.87	93.9	98.7795	82.0406
2014	7	31	0	54	19	0.3	4.6	0.91	94.4	98.7139	85.0663

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	1	4	19	0.3	4.6	0.87	94.6	98.7139	81.0596
2014	7	31	1	14	19	0.3	4.6	0.9	94	98.7139	84.4499
2014	7	31	1	24	19	0.3	4.6	0.92	95.7	98.7139	86.2992
2014	7	31	1	34	19	0.3	4.6	0.88	92.4	98.7139	82.6007
2014	7	31	1	44	19	0.3	4.6	0.87	94.3	98.7139	81.6761
2014	7	31	1	54	19	0.3	4.6	0.86	94.4	98.7139	80.7514
2014	7	31	2	4	19	0.3	4.6	0.89	94	98.7139	83.2171
2014	7	31	2	14	19	0.3	4.6	0.87	96.5	98.7139	81.3679
2014	7	31	2	24	19	0.3	4.6	0.91	95	98.7139	84.7582
2014	7	31	2	34	19	0.3	4.6	0.87	94.1	98.7139	81.6761
2014	7	31	2	44	19	0.3	4.6	0.88	96	98.7139	82.6007
2014	7	31	2	54	19	0.3	4.6	0.88	96	98.7139	81.9843
2014	7	31	3	4	19	0.3	4.6	0.88	94.9	98.7139	81.9843
2014	7	31	3	14	19	0.3	4.6	0.89	94	98.7139	83.5254
2014	7	31	3	24	19	0.3	4.6	0.85	93.5	98.7139	80.1351
2014	7	31	3	34	19	0.3	4.6	0.86	93.7	98.7139	80.7515
2014	7	31	3	44	19	0.3	4.6	0.9	95	98.7139	84.4501
2014	7	31	3	54	19	0.3	4.6	0.86	92.4	98.7139	81.0597
2014	7	31	4	4	19	0.3	4.6	0.9	95.6	98.7139	84.4501
2014	7	31	4	14	19	0.3	4.6	0.88	95.8	98.7139	82.2926
2014	7	31	4	24	19	0.3	4.6	0.88	92.6	98.7139	82.909
2014	7	31	4	34	19	0.3	4.6	0.88	93.2	98.7139	82.9091
2014	7	31	4	44	19	0.3	4.6	0.87	95.8	98.7139	81.6762
2014	7	31	4	54	19	0.3	4.6	0.85	92.9	98.7139	79.827
2014	7	31	5	4	19	0.3	4.6	0.89	94.4	98.7139	83.5255
2014	7	31	5	14	19	0.3	4.6	0.87	94.3	98.7139	81.6763
2014	7	31	5	24	19	0.3	4.6	0.88	95.1	98.7139	82.2927
2014	7	31	5	34	19	0.3	4.6	0.9	94.6	98.7139	83.8338
2014	7	31	5	44	19	0.3	4.6	0.87	94.5	98.7139	81.3681
2014	7	31	5	54	19	0.3	4.6	0.87	93.2	98.7139	81.6763
2014	7	31	6	4	19	0.3	4.6	0.85	93.1	98.7139	80.1353
2014	7	31	6	14	19	0.3	4.6	0.9	93.6	98.7139	84.4502
2014	7	31	6	24	19	0.3	4.6	0.88	95.1	98.7139	82.2928
2014	7	31	6	34	19	0.3	4.6	0.87	95.6	98.7139	81.3681
2014	7	31	6	44	19	0.3	4.6	0.87	95.6	98.7139	81.3682
2014	7	31	6	54	19	0.3	4.6	0.87	94.1	98.7139	81.6764
2014	7	31	7	4	19	0.3	4.6	0.89	94	98.7139	83.5257
2014	7	31	7	14	19	0.3	4.6	0.89	95.9	98.7139	83.5257
2014	7	31	7	24	19	0.3	4.6	0.87	94.5	98.7139	81.3682
2014	7	31	7	34	19	0.3	4.6	0.88	94.9	98.7139	82.6011
2014	7	31	7	44	19	0.3	4.6	0.9	94.2	98.7139	84.4503
2014	7	31	7	54	19	0.3	4.6	0.92	94.3	98.7139	86.6078
2014	7	31	8	4	19	0.3	4.6	0.88	93.2	98.6483	82.5442
2014	7	31	8	14	19	0.3	4.6	0.9	94.8	98.6483	84.0842
2014	7	31	8	24	19	0.3	4.6	0.9	95.4	98.6483	84.0842
2014	7	31	8	34	19	0.3	4.6	0.86	96.1	98.6483	80.3882

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	8	44	19	0.3	4.6	0.88	96	98.6483	82.5442
2014	7	31	8	54	19	0.3	4.6	0.88	96.9	98.6483	81.6202
2014	7	31	9	4	19	0.3	4.6	0.88	96.9	98.6483	81.6202
2014	7	31	9	14	19	0.3	4.6	0.9	97.6	98.6483	83.4682
2014	7	31	9	24	19	0.3	4.6	0.9	97.3	98.6483	83.7762
2014	7	31	9	34	19	0.3	4.6	0.89	96.6	98.6483	82.8522
2014	7	31	9	44	19	0.3	4.6	0.88	97.1	98.6483	81.9282
2014	7	31	9	54	19	0.3	4.6	0.9	94.6	98.6483	84.3922
2014	7	31	10	4	19	0.3	4.6	0.9	97.3	98.6483	84.0842
2014	7	31	10	14	19	0.3	4.6	0.88	93.2	98.6483	82.5442
2014	7	31	10	24	19	0.3	4.6	0.87	95.4	98.6483	81.6201
2014	7	31	10	34	19	0.3	4.6	0.87	94.8	98.5827	81.2562
2014	7	31	10	44	19	0.3	4.6	0.88	94.3	98.5827	82.1795
2014	7	31	10	54	19	0.3	4.6	0.89	97	98.5827	82.4873
2014	7	31	11	4	19	0.3	4.6	0.9	94.6	98.5827	84.334
2014	7	31	11	14	19	0.3	4.6	0.9	96.7	98.5827	84.0262
2014	7	31	11	24	19	0.3	4.6	0.88	95.3	98.5827	82.1795
2014	7	31	11	34	19	0.3	4.6	0.91	96.9	98.5827	84.334
2014	7	31	11	44	19	0.3	4.6	0.9	97.7	98.5827	83.7184
2014	7	31	11	54	19	0.3	4.6	0.91	96.6	98.5827	84.6417
2014	7	31	12	4	19	0.3	4.6	0.91	96.6	98.5171	84.5834
2014	7	31	12	14	19	0.3	4.6	0.9	96.1	98.5171	83.9682
2014	7	31	12	24	19	0.3	4.6	0.92	97.4	98.5171	85.5061
2014	7	31	12	34	19	0.3	4.6	0.91	99.8	98.4515	83.603
2014	7	31	12	44	19	0.3	4.6	0.9	101.4	98.3858	82.6238
2014	7	31	12	54	19	0.3	4.6	0.88	102.5	98.3202	80.1112
2014	7	31	13	4	19	0.3	4.6	0.91	99.3	98.3202	84.4084
2014	7	31	13	14	19	0.3	4.6	0.9	99.9	98.2546	82.8165
2014	7	31	13	24	19	0.3	4.6	0.89	97.4	98.2546	82.8165
2014	7	31	13	34	19	0.3	4.6	0.93	97.5	98.2546	85.8837
2014	7	31	13	44	19	0.3	4.6	0.88	96	98.2546	81.5895
2014	7	31	13	54	19	0.3	4.6	0.92	101.5	98.2546	84.6568
2014	7	31	14	4	19	0.3	4.6	0.88	99.4	98.189	81.5331
2014	7	31	14	14	19	0.3	4.6	0.89	98.9	98.2546	81.8962
2014	7	31	14	24	19	0.3	4.6	0.93	95.5	98.2546	86.4972
2014	7	31	14	34	19	0.3	4.6	0.93	99	98.2546	85.577
2014	7	31	14	44	19	0.3	4.6	0.89	97.4	98.189	82.7592
2014	7	31	14	54	19	0.3	4.6	0.91	96.9	98.189	83.9852
2014	7	31	15	4	19	0.3	4.6	0.89	95.5	98.189	82.7592
2014	7	31	15	14	19	0.3	4.6	0.89	98.9	98.189	81.8397
2014	7	31	15	24	19	0.3	4.6	0.89	96.3	98.189	82.7592
2014	7	31	15	34	19	0.3	4.6	0.92	95.9	98.189	85.5178
2014	7	31	15	44	19	0.3	4.6	0.91	97.4	98.189	84.5983
2014	7	31	15	54	19	0.3	4.6	0.88	95.5	98.189	82.1461
2014	7	31	16	4	19	0.3	4.6	0.88	95.5	98.189	82.1461
2014	7	31	16	14	19	0.3	4.6	0.87	94.1	98.189	81.5331

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	16	24	19	0.3	4.6	0.9	95.7	98.189	83.3722
2014	7	31	16	34	19	0.3	4.6	0.91	98.1	98.189	83.9852
2014	7	31	16	44	19	0.3	4.6	0.89	96.5	98.189	83.0656
2014	7	31	16	54	19	0.3	4.6	0.9	98.6	98.189	82.7591
2014	7	31	17	4	19	0.3	4.6	0.91	98.9	98.189	83.9852
2014	7	31	17	14	19	0.3	4.6	0.89	93.6	98.189	82.7591
2014	7	31	17	24	19	0.3	4.6	0.89	95.7	98.189	82.7591
2014	7	31	17	34	19	0.3	4.6	0.88	94.9	98.189	81.5331
2014	7	31	17	44	19	0.3	4.6	0.87	93.7	98.189	81.5331
2014	7	31	17	54	19	0.3	4.6	0.9	95.3	98.189	83.3721
2014	7	31	18	4	19	0.3	4.6	0.86	93.9	98.189	80.6135
2014	7	31	18	14	19	0.3	4.6	0.9	94.8	98.189	83.6786
2014	7	31	18	24	19	0.3	4.6	0.88	95.2	98.189	81.533
2014	7	31	18	34	19	0.3	4.6	0.85	93.5	98.189	79.0809
2014	7	31	18	44	19	0.3	4.6	0.87	94.6	98.189	80.6135
2014	7	31	18	54	19	0.3	4.6	0.9	94	98.189	83.9851
2014	7	31	19	4	19	0.3	4.6	0.89	93.6	98.189	83.0656
2014	7	31	19	14	19	0.3	4.6	0.86	93.7	98.189	80.0004
2014	7	31	19	24	19	0.3	4.6	0.88	95.6	98.189	81.533
2014	7	31	19	34	19	0.3	4.6	0.89	94.2	98.189	83.0655
2014	7	31	19	44	19	0.3	4.6	0.87	95.2	98.189	81.2265
2014	7	31	19	54	19	0.3	4.6	0.89	97	98.189	82.759
2014	7	31	20	4	19	0.3	4.6	0.89	95.1	98.189	83.0655
2014	7	31	20	14	19	0.3	4.6	0.89	96.2	98.189	82.4525
2014	7	31	20	24	19	0.3	4.6	0.86	95.7	98.189	79.6939
2014	7	31	20	34	19	0.3	4.6	0.89	93.4	98.189	82.759
2014	7	31	20	44	19	0.3	4.6	0.89	95.5	98.189	82.759
2014	7	31	20	54	19	0.3	4.6	0.87	95.2	98.2546	80.6692
2014	7	31	21	4	19	0.3	4.6	0.86	94.6	98.189	79.6939
2014	7	31	21	14	19	0.3	4.6	0.88	94.9	98.2546	82.2028
2014	7	31	21	24	19	0.3	4.6	0.88	95.2	98.2546	81.5894
2014	7	31	21	34	19	0.3	4.6	0.89	95.5	98.2546	83.123
2014	7	31	21	44	19	0.3	4.6	0.88	93	98.189	81.8395
2014	7	31	21	54	19	0.3	4.6	0.87	96.5	98.2546	81.2827
2014	7	31	22	4	19	0.3	4.6	0.87	95.6	98.2546	81.2827
2014	7	31	22	14	19	0.3	4.6	0.88	93.2	98.2546	82.2028
2014	7	31	22	24	19	0.3	4.6	0.89	94.2	98.2546	83.4298
2014	7	31	22	34	19	0.3	4.6	0.88	93.6	98.189	81.8395
2014	7	31	22	44	19	0.3	4.6	0.86	93.7	98.2546	80.3625
2014	7	31	22	54	19	0.3	4.6	0.91	95.2	98.2546	84.3499
2014	7	31	23	4	19	0.3	4.6	0.85	95.5	98.2546	79.1356
2014	7	31	23	14	19	0.3	4.6	0.87	93.2	98.2546	81.5894
2014	7	31	23	24	19	0.3	4.6	0.86	92	98.2546	80.3625
2014	7	31	23	34	19	0.3	4.6	0.89	93.4	98.2546	82.8163
2014	7	31	23	44	19	0.3	4.6	0.87	93.3	98.2546	80.976
2014	7	31	23	54	19	0.3	4.6	0.84	92.5	98.2546	78.5222

Locust Ditch Return

Station 0215

Date	Flow (cfs)
7/1/2014	0
7/2/2014	0
7/3/2014	0
7/4/2014	0
7/5/2014	0
7/6/2014	0
7/7/2014	0
7/8/2014	0
7/9/2014	0
7/10/2014	0
7/11/2014	0
7/12/2014	0
7/13/2014	0
7/14/2014	0
7/15/2014	0
7/16/2014	0
7/17/2014	0
7/18/2014	0
7/19/2014	0
7/20/2014	0
7/21/2014	0
7/22/2014	0
7/23/2014	0
7/24/2014	0
7/25/2014	0
7/26/2014	0
7/27/2014	0
7/28/2014	0
7/29/2014	0
7/30/2014	0
7/31/2014	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	12:00:00 AM	0
7/1/2014	12:15:00 AM	0
7/1/2014	12:30:00 AM	0
7/1/2014	12:45:00 AM	0
7/1/2014	1:00:00 AM	0
7/1/2014	1:15:00 AM	0
7/1/2014	1:30:00 AM	0
7/1/2014	1:45:00 AM	0
7/1/2014	2:00:00 AM	0
7/1/2014	2:15:00 AM	0
7/1/2014	2:30:00 AM	0
7/1/2014	2:45:00 AM	0
7/1/2014	3:00:00 AM	0
7/1/2014	3:15:00 AM	0
7/1/2014	3:30:00 AM	0
7/1/2014	3:45:00 AM	0
7/1/2014	4:00:00 AM	0
7/1/2014	4:15:00 AM	0
7/1/2014	4:30:00 AM	0
7/1/2014	4:45:00 AM	0
7/1/2014	5:00:00 AM	0
7/1/2014	5:15:00 AM	0
7/1/2014	5:30:00 AM	0
7/1/2014	5:45:00 AM	0
7/1/2014	6:00:00 AM	0
7/1/2014	6:15:00 AM	0
7/1/2014	6:30:00 AM	0
7/1/2014	6:45:00 AM	0
7/1/2014	7:00:00 AM	0
7/1/2014	7:15:00 AM	0
7/1/2014	7:30:00 AM	0
7/1/2014	7:45:00 AM	0
7/1/2014	8:00:00 AM	0
7/1/2014	8:15:00 AM	0
7/1/2014	8:30:00 AM	0
7/1/2014	8:45:00 AM	0
7/1/2014	9:00:00 AM	0
7/1/2014	9:15:00 AM	0
7/1/2014	9:30:00 AM	0
7/1/2014	9:45:00 AM	0
7/1/2014	10:00:00 AM	0
7/1/2014	10:15:00 AM	0
7/1/2014	10:30:00 AM	0
7/1/2014	10:45:00 AM	0
7/1/2014	11:00:00 AM	0
7/1/2014	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	11:30:00 AM	0
7/1/2014	11:45:00 AM	0
7/1/2014	12:00:00 PM	0
7/1/2014	12:15:00 PM	0
7/1/2014	12:30:00 PM	0
7/1/2014	12:45:00 PM	0
7/1/2014	1:00:00 PM	0
7/1/2014	1:15:00 PM	0
7/1/2014	1:30:00 PM	0
7/1/2014	1:45:00 PM	0
7/1/2014	2:00:00 PM	0
7/1/2014	2:15:00 PM	0
7/1/2014	2:30:00 PM	0
7/1/2014	2:45:00 PM	0
7/1/2014	3:00:00 PM	0
7/1/2014	3:15:00 PM	0
7/1/2014	3:30:00 PM	0
7/1/2014	3:45:00 PM	0
7/1/2014	4:00:00 PM	0
7/1/2014	4:15:00 PM	0
7/1/2014	4:30:00 PM	0
7/1/2014	4:45:00 PM	0
7/1/2014	5:00:00 PM	0
7/1/2014	5:15:00 PM	0
7/1/2014	5:30:00 PM	0
7/1/2014	5:45:00 PM	0
7/1/2014	6:00:00 PM	0
7/1/2014	6:15:00 PM	0
7/1/2014	6:30:00 PM	0
7/1/2014	6:45:00 PM	0
7/1/2014	7:00:00 PM	0
7/1/2014	7:15:00 PM	0
7/1/2014	7:30:00 PM	0
7/1/2014	7:45:00 PM	0
7/1/2014	8:00:00 PM	0
7/1/2014	8:15:00 PM	0
7/1/2014	8:30:00 PM	0
7/1/2014	8:45:00 PM	0
7/1/2014	9:00:00 PM	0
7/1/2014	9:15:00 PM	0
7/1/2014	9:30:00 PM	0
7/1/2014	9:45:00 PM	0
7/1/2014	10:00:00 PM	0
7/1/2014	10:15:00 PM	0
7/1/2014	10:30:00 PM	0
7/1/2014	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	11:00:00 PM	0
7/1/2014	11:15:00 PM	0
7/1/2014	11:30:00 PM	0
7/1/2014	11:45:00 PM	0
7/2/2014	12:00:00 AM	0
7/2/2014	12:15:00 AM	0
7/2/2014	12:30:00 AM	0
7/2/2014	12:45:00 AM	0
7/2/2014	1:00:00 AM	0
7/2/2014	1:15:00 AM	0
7/2/2014	1:30:00 AM	0
7/2/2014	1:45:00 AM	0
7/2/2014	2:00:00 AM	0
7/2/2014	2:15:00 AM	0
7/2/2014	2:30:00 AM	0
7/2/2014	2:45:00 AM	0
7/2/2014	3:00:00 AM	0
7/2/2014	3:15:00 AM	0
7/2/2014	3:30:00 AM	0
7/2/2014	3:45:00 AM	0
7/2/2014	4:00:00 AM	0
7/2/2014	4:15:00 AM	0
7/2/2014	4:30:00 AM	0
7/2/2014	4:45:00 AM	0
7/2/2014	5:00:00 AM	0
7/2/2014	5:15:00 AM	0
7/2/2014	5:30:00 AM	0
7/2/2014	5:45:00 AM	0
7/2/2014	6:00:00 AM	0
7/2/2014	6:15:00 AM	0
7/2/2014	6:30:00 AM	0
7/2/2014	6:45:00 AM	0
7/2/2014	7:00:00 AM	0
7/2/2014	7:15:00 AM	0
7/2/2014	7:30:00 AM	0
7/2/2014	7:45:00 AM	0
7/2/2014	8:00:00 AM	0
7/2/2014	8:15:00 AM	0
7/2/2014	8:30:00 AM	0
7/2/2014	8:45:00 AM	0
7/2/2014	9:00:00 AM	0
7/2/2014	9:15:00 AM	0
7/2/2014	9:30:00 AM	0
7/2/2014	9:45:00 AM	0
7/2/2014	10:00:00 AM	0
7/2/2014	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/2/2014	10:30:00 AM	0
7/2/2014	10:45:00 AM	0
7/2/2014	11:00:00 AM	0
7/2/2014	11:15:00 AM	0
7/2/2014	11:30:00 AM	0
7/2/2014	11:45:00 AM	0
7/2/2014	12:00:00 PM	0
7/2/2014	12:15:00 PM	0
7/2/2014	12:30:00 PM	0
7/2/2014	12:45:00 PM	0
7/2/2014	1:00:00 PM	0
7/2/2014	1:15:00 PM	0
7/2/2014	1:30:00 PM	0
7/2/2014	1:45:00 PM	0
7/2/2014	2:00:00 PM	0
7/2/2014	2:15:00 PM	0
7/2/2014	2:30:00 PM	0
7/2/2014	2:45:00 PM	0
7/2/2014	3:00:00 PM	0
7/2/2014	3:15:00 PM	0
7/2/2014	3:30:00 PM	0
7/2/2014	3:45:00 PM	0
7/2/2014	4:00:00 PM	0
7/2/2014	4:15:00 PM	0
7/2/2014	4:30:00 PM	0
7/2/2014	4:45:00 PM	0
7/2/2014	5:00:00 PM	0
7/2/2014	5:15:00 PM	0
7/2/2014	5:30:00 PM	0
7/2/2014	5:45:00 PM	0
7/2/2014	6:00:00 PM	0
7/2/2014	6:15:00 PM	0
7/2/2014	6:30:00 PM	0
7/2/2014	6:45:00 PM	0
7/2/2014	7:00:00 PM	0
7/2/2014	7:15:00 PM	0
7/2/2014	7:30:00 PM	0
7/2/2014	7:45:00 PM	0
7/2/2014	8:00:00 PM	0
7/2/2014	8:15:00 PM	0
7/2/2014	8:30:00 PM	0
7/2/2014	8:45:00 PM	0
7/2/2014	9:00:00 PM	0
7/2/2014	9:15:00 PM	0
7/2/2014	9:30:00 PM	0
7/2/2014	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/2/2014	10:00:00 PM	0
7/2/2014	10:15:00 PM	0
7/2/2014	10:30:00 PM	0
7/2/2014	10:45:00 PM	0
7/2/2014	11:00:00 PM	0
7/2/2014	11:15:00 PM	0
7/2/2014	11:30:00 PM	0
7/2/2014	11:45:00 PM	0
7/3/2014	12:00:00 AM	0
7/3/2014	12:15:00 AM	0
7/3/2014	12:30:00 AM	0
7/3/2014	12:45:00 AM	0
7/3/2014	1:00:00 AM	0
7/3/2014	1:15:00 AM	0
7/3/2014	1:30:00 AM	0
7/3/2014	1:45:00 AM	0
7/3/2014	2:00:00 AM	0
7/3/2014	2:15:00 AM	0
7/3/2014	2:30:00 AM	0
7/3/2014	2:45:00 AM	0
7/3/2014	3:00:00 AM	0
7/3/2014	3:15:00 AM	0
7/3/2014	3:30:00 AM	0
7/3/2014	3:45:00 AM	0
7/3/2014	4:00:00 AM	0
7/3/2014	4:15:00 AM	0
7/3/2014	4:30:00 AM	0
7/3/2014	4:45:00 AM	0
7/3/2014	5:00:00 AM	0
7/3/2014	5:15:00 AM	0
7/3/2014	5:30:00 AM	0
7/3/2014	5:45:00 AM	0
7/3/2014	6:00:00 AM	0
7/3/2014	6:15:00 AM	0
7/3/2014	6:30:00 AM	0
7/3/2014	6:45:00 AM	0
7/3/2014	7:00:00 AM	0
7/3/2014	7:15:00 AM	0
7/3/2014	7:30:00 AM	0
7/3/2014	7:45:00 AM	0
7/3/2014	8:00:00 AM	0
7/3/2014	8:15:00 AM	0
7/3/2014	8:30:00 AM	0
7/3/2014	8:45:00 AM	0
7/3/2014	9:00:00 AM	0
7/3/2014	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/3/2014	9:30:00 AM	0
7/3/2014	9:45:00 AM	0
7/3/2014	10:00:00 AM	0
7/3/2014	10:15:00 AM	0
7/3/2014	10:30:00 AM	0
7/3/2014	10:45:00 AM	0
7/3/2014	11:00:00 AM	0
7/3/2014	11:15:00 AM	0
7/3/2014	11:30:00 AM	0
7/3/2014	11:45:00 AM	0
7/3/2014	12:00:00 PM	0
7/3/2014	12:15:00 PM	0
7/3/2014	12:30:00 PM	0
7/3/2014	12:45:00 PM	0
7/3/2014	1:00:00 PM	0
7/3/2014	1:15:00 PM	0
7/3/2014	1:30:00 PM	0
7/3/2014	1:45:00 PM	0
7/3/2014	2:00:00 PM	0
7/3/2014	2:15:00 PM	0
7/3/2014	2:30:00 PM	0
7/3/2014	2:45:00 PM	0
7/3/2014	3:00:00 PM	0
7/3/2014	3:15:00 PM	0
7/3/2014	3:30:00 PM	0
7/3/2014	3:45:00 PM	0
7/3/2014	4:00:00 PM	0
7/3/2014	4:15:00 PM	0
7/3/2014	4:30:00 PM	0
7/3/2014	4:45:00 PM	0
7/3/2014	5:00:00 PM	0
7/3/2014	5:15:00 PM	0
7/3/2014	5:30:00 PM	0
7/3/2014	5:45:00 PM	0
7/3/2014	6:00:00 PM	0
7/3/2014	6:15:00 PM	0
7/3/2014	6:30:00 PM	0
7/3/2014	6:45:00 PM	0
7/3/2014	7:00:00 PM	0
7/3/2014	7:15:00 PM	0
7/3/2014	7:30:00 PM	0
7/3/2014	7:45:00 PM	0
7/3/2014	8:00:00 PM	0
7/3/2014	8:15:00 PM	0
7/3/2014	8:30:00 PM	0
7/3/2014	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/3/2014	9:00:00 PM	0
7/3/2014	9:15:00 PM	0
7/3/2014	9:30:00 PM	0
7/3/2014	9:45:00 PM	0
7/3/2014	10:00:00 PM	0
7/3/2014	10:15:00 PM	0
7/3/2014	10:30:00 PM	0
7/3/2014	10:45:00 PM	0
7/3/2014	11:00:00 PM	0
7/3/2014	11:15:00 PM	0
7/3/2014	11:30:00 PM	0
7/3/2014	11:45:00 PM	0
7/4/2014	12:00:00 AM	0
7/4/2014	12:15:00 AM	0
7/4/2014	12:30:00 AM	0
7/4/2014	12:45:00 AM	0
7/4/2014	1:00:00 AM	0
7/4/2014	1:15:00 AM	0
7/4/2014	1:30:00 AM	0
7/4/2014	1:45:00 AM	0
7/4/2014	2:00:00 AM	0
7/4/2014	2:15:00 AM	0
7/4/2014	2:30:00 AM	0
7/4/2014	2:45:00 AM	0
7/4/2014	3:00:00 AM	0
7/4/2014	3:15:00 AM	0
7/4/2014	3:30:00 AM	0
7/4/2014	3:45:00 AM	0
7/4/2014	4:00:00 AM	0
7/4/2014	4:15:00 AM	0
7/4/2014	4:30:00 AM	0
7/4/2014	4:45:00 AM	0
7/4/2014	5:00:00 AM	0
7/4/2014	5:15:00 AM	0
7/4/2014	5:30:00 AM	0
7/4/2014	5:45:00 AM	0
7/4/2014	6:00:00 AM	0
7/4/2014	6:15:00 AM	0
7/4/2014	6:30:00 AM	0
7/4/2014	6:45:00 AM	0
7/4/2014	7:00:00 AM	0
7/4/2014	7:15:00 AM	0
7/4/2014	7:30:00 AM	0
7/4/2014	7:45:00 AM	0
7/4/2014	8:00:00 AM	0
7/4/2014	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/4/2014	8:30:00 AM	0
7/4/2014	8:45:00 AM	0
7/4/2014	9:00:00 AM	0
7/4/2014	9:15:00 AM	0
7/4/2014	9:30:00 AM	0
7/4/2014	9:45:00 AM	0
7/4/2014	10:00:00 AM	0
7/4/2014	10:15:00 AM	0
7/4/2014	10:30:00 AM	0
7/4/2014	10:45:00 AM	0
7/4/2014	11:00:00 AM	0
7/4/2014	11:15:00 AM	0
7/4/2014	11:30:00 AM	0
7/4/2014	11:45:00 AM	0
7/4/2014	12:00:00 PM	0
7/4/2014	12:15:00 PM	0
7/4/2014	12:30:00 PM	0
7/4/2014	12:45:00 PM	0
7/4/2014	1:00:00 PM	0
7/4/2014	1:15:00 PM	0
7/4/2014	1:30:00 PM	0
7/4/2014	1:45:00 PM	0
7/4/2014	2:00:00 PM	0
7/4/2014	2:15:00 PM	0
7/4/2014	2:30:00 PM	0
7/4/2014	2:45:00 PM	0
7/4/2014	3:00:00 PM	0
7/4/2014	3:15:00 PM	0
7/4/2014	3:30:00 PM	0
7/4/2014	3:45:00 PM	0
7/4/2014	4:00:00 PM	0
7/4/2014	4:15:00 PM	0
7/4/2014	4:30:00 PM	0
7/4/2014	4:45:00 PM	0
7/4/2014	5:00:00 PM	0
7/4/2014	5:15:00 PM	0
7/4/2014	5:30:00 PM	0
7/4/2014	5:45:00 PM	0
7/4/2014	6:00:00 PM	0
7/4/2014	6:15:00 PM	0
7/4/2014	6:30:00 PM	0
7/4/2014	6:45:00 PM	0
7/4/2014	7:00:00 PM	0
7/4/2014	7:15:00 PM	0
7/4/2014	7:30:00 PM	0
7/4/2014	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/4/2014	8:00:00 PM	0
7/4/2014	8:15:00 PM	0
7/4/2014	8:30:00 PM	0
7/4/2014	8:45:00 PM	0
7/4/2014	9:00:00 PM	0
7/4/2014	9:15:00 PM	0
7/4/2014	9:30:00 PM	0
7/4/2014	9:45:00 PM	0
7/4/2014	10:00:00 PM	0
7/4/2014	10:15:00 PM	0
7/4/2014	10:30:00 PM	0
7/4/2014	10:45:00 PM	0
7/4/2014	11:00:00 PM	0
7/4/2014	11:15:00 PM	0
7/4/2014	11:30:00 PM	0
7/4/2014	11:45:00 PM	0
7/5/2014	12:00:00 AM	0
7/5/2014	12:15:00 AM	0
7/5/2014	12:30:00 AM	0
7/5/2014	12:45:00 AM	0
7/5/2014	1:00:00 AM	0
7/5/2014	1:15:00 AM	0
7/5/2014	1:30:00 AM	0
7/5/2014	1:45:00 AM	0
7/5/2014	2:00:00 AM	0
7/5/2014	2:15:00 AM	0
7/5/2014	2:30:00 AM	0
7/5/2014	2:45:00 AM	0
7/5/2014	3:00:00 AM	0
7/5/2014	3:15:00 AM	0
7/5/2014	3:30:00 AM	0
7/5/2014	3:45:00 AM	0
7/5/2014	4:00:00 AM	0
7/5/2014	4:15:00 AM	0
7/5/2014	4:30:00 AM	0
7/5/2014	4:45:00 AM	0
7/5/2014	5:00:00 AM	0
7/5/2014	5:15:00 AM	0
7/5/2014	5:30:00 AM	0
7/5/2014	5:45:00 AM	0
7/5/2014	6:00:00 AM	0
7/5/2014	6:15:00 AM	0
7/5/2014	6:30:00 AM	0
7/5/2014	6:45:00 AM	0
7/5/2014	7:00:00 AM	0
7/5/2014	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/5/2014	7:30:00 AM	0
7/5/2014	7:45:00 AM	0
7/5/2014	8:00:00 AM	0
7/5/2014	8:15:00 AM	0
7/5/2014	8:30:00 AM	0
7/5/2014	8:45:00 AM	0
7/5/2014	9:00:00 AM	0
7/5/2014	9:15:00 AM	0
7/5/2014	9:30:00 AM	0
7/5/2014	9:45:00 AM	0
7/5/2014	10:00:00 AM	0
7/5/2014	10:15:00 AM	0
7/5/2014	10:30:00 AM	0
7/5/2014	10:45:00 AM	0
7/5/2014	11:00:00 AM	0
7/5/2014	11:15:00 AM	0
7/5/2014	11:30:00 AM	0
7/5/2014	11:45:00 AM	0
7/5/2014	12:00:00 PM	0
7/5/2014	12:15:00 PM	0
7/5/2014	12:30:00 PM	0
7/5/2014	12:45:00 PM	0
7/5/2014	1:00:00 PM	0
7/5/2014	1:15:00 PM	0
7/5/2014	1:30:00 PM	0
7/5/2014	1:45:00 PM	0
7/5/2014	2:00:00 PM	0
7/5/2014	2:15:00 PM	0
7/5/2014	2:30:00 PM	0
7/5/2014	2:45:00 PM	0
7/5/2014	3:00:00 PM	0
7/5/2014	3:15:00 PM	0
7/5/2014	3:30:00 PM	0
7/5/2014	3:45:00 PM	0
7/5/2014	4:00:00 PM	0
7/5/2014	4:15:00 PM	0
7/5/2014	4:30:00 PM	0
7/5/2014	4:45:00 PM	0
7/5/2014	5:00:00 PM	0
7/5/2014	5:15:00 PM	0
7/5/2014	5:30:00 PM	0
7/5/2014	5:45:00 PM	0
7/5/2014	6:00:00 PM	0
7/5/2014	6:15:00 PM	0
7/5/2014	6:30:00 PM	0
7/5/2014	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/5/2014	7:00:00 PM	0
7/5/2014	7:15:00 PM	0
7/5/2014	7:30:00 PM	0
7/5/2014	7:45:00 PM	0
7/5/2014	8:00:00 PM	0
7/5/2014	8:15:00 PM	0
7/5/2014	8:30:00 PM	0
7/5/2014	8:45:00 PM	0
7/5/2014	9:00:00 PM	0
7/5/2014	9:15:00 PM	0
7/5/2014	9:30:00 PM	0
7/5/2014	9:45:00 PM	0
7/5/2014	10:00:00 PM	0
7/5/2014	10:15:00 PM	0
7/5/2014	10:30:00 PM	0
7/5/2014	10:45:00 PM	0
7/5/2014	11:00:00 PM	0
7/5/2014	11:15:00 PM	0
7/5/2014	11:30:00 PM	0
7/5/2014	11:45:00 PM	0
7/6/2014	12:00:00 AM	0
7/6/2014	12:15:00 AM	0
7/6/2014	12:30:00 AM	0
7/6/2014	12:45:00 AM	0
7/6/2014	1:00:00 AM	0
7/6/2014	1:15:00 AM	0
7/6/2014	1:30:00 AM	0
7/6/2014	1:45:00 AM	0
7/6/2014	2:00:00 AM	0
7/6/2014	2:15:00 AM	0
7/6/2014	2:30:00 AM	0
7/6/2014	2:45:00 AM	0
7/6/2014	3:00:00 AM	0
7/6/2014	3:15:00 AM	0
7/6/2014	3:30:00 AM	0
7/6/2014	3:45:00 AM	0
7/6/2014	4:00:00 AM	0
7/6/2014	4:15:00 AM	0
7/6/2014	4:30:00 AM	0
7/6/2014	4:45:00 AM	0
7/6/2014	5:00:00 AM	0
7/6/2014	5:15:00 AM	0
7/6/2014	5:30:00 AM	0
7/6/2014	5:45:00 AM	0
7/6/2014	6:00:00 AM	0
7/6/2014	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/6/2014	6:30:00 AM	0
7/6/2014	6:45:00 AM	0
7/6/2014	7:00:00 AM	0
7/6/2014	7:15:00 AM	0
7/6/2014	7:30:00 AM	0
7/6/2014	7:45:00 AM	0
7/6/2014	8:00:00 AM	0
7/6/2014	8:15:00 AM	0
7/6/2014	8:30:00 AM	0
7/6/2014	8:45:00 AM	0
7/6/2014	9:00:00 AM	0
7/6/2014	9:15:00 AM	0
7/6/2014	9:30:00 AM	0
7/6/2014	9:45:00 AM	0
7/6/2014	10:00:00 AM	0
7/6/2014	10:15:00 AM	0
7/6/2014	10:30:00 AM	0
7/6/2014	10:45:00 AM	0
7/6/2014	11:00:00 AM	0
7/6/2014	11:15:00 AM	0
7/6/2014	11:30:00 AM	0
7/6/2014	11:45:00 AM	0
7/6/2014	12:00:00 PM	0
7/6/2014	12:15:00 PM	0
7/6/2014	12:30:00 PM	0
7/6/2014	12:45:00 PM	0
7/6/2014	1:00:00 PM	0
7/6/2014	1:15:00 PM	0
7/6/2014	1:30:00 PM	0
7/6/2014	1:45:00 PM	0
7/6/2014	2:00:00 PM	0
7/6/2014	2:15:00 PM	0
7/6/2014	2:30:00 PM	0
7/6/2014	2:45:00 PM	0
7/6/2014	3:00:00 PM	0
7/6/2014	3:15:00 PM	0
7/6/2014	3:30:00 PM	0
7/6/2014	3:45:00 PM	0
7/6/2014	4:00:00 PM	0
7/6/2014	4:15:00 PM	0
7/6/2014	4:30:00 PM	0
7/6/2014	4:45:00 PM	0
7/6/2014	5:00:00 PM	0
7/6/2014	5:15:00 PM	0
7/6/2014	5:30:00 PM	0
7/6/2014	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/6/2014	6:00:00 PM	0
7/6/2014	6:15:00 PM	0
7/6/2014	6:30:00 PM	0
7/6/2014	6:45:00 PM	0
7/6/2014	7:00:00 PM	0
7/6/2014	7:15:00 PM	0
7/6/2014	7:30:00 PM	0
7/6/2014	7:45:00 PM	0
7/6/2014	8:00:00 PM	0
7/6/2014	8:15:00 PM	0
7/6/2014	8:30:00 PM	0
7/6/2014	8:45:00 PM	0
7/6/2014	9:00:00 PM	0
7/6/2014	9:15:00 PM	0
7/6/2014	9:30:00 PM	0
7/6/2014	9:45:00 PM	0
7/6/2014	10:00:00 PM	0
7/6/2014	10:15:00 PM	0
7/6/2014	10:30:00 PM	0
7/6/2014	10:45:00 PM	0
7/6/2014	11:00:00 PM	0
7/6/2014	11:15:00 PM	0
7/6/2014	11:30:00 PM	0
7/6/2014	11:45:00 PM	0
7/7/2014	12:00:00 AM	0
7/7/2014	12:15:00 AM	0
7/7/2014	12:30:00 AM	0
7/7/2014	12:45:00 AM	0
7/7/2014	1:00:00 AM	0
7/7/2014	1:15:00 AM	0
7/7/2014	1:30:00 AM	0
7/7/2014	1:45:00 AM	0
7/7/2014	2:00:00 AM	0
7/7/2014	2:15:00 AM	0
7/7/2014	2:30:00 AM	0
7/7/2014	2:45:00 AM	0
7/7/2014	3:00:00 AM	0
7/7/2014	3:15:00 AM	0
7/7/2014	3:30:00 AM	0
7/7/2014	3:45:00 AM	0
7/7/2014	4:00:00 AM	0
7/7/2014	4:15:00 AM	0
7/7/2014	4:30:00 AM	0
7/7/2014	4:45:00 AM	0
7/7/2014	5:00:00 AM	0
7/7/2014	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/7/2014	5:30:00 AM	0
7/7/2014	5:45:00 AM	0
7/7/2014	6:00:00 AM	0
7/7/2014	6:15:00 AM	0
7/7/2014	6:30:00 AM	0
7/7/2014	6:45:00 AM	0
7/7/2014	7:00:00 AM	0
7/7/2014	7:15:00 AM	0
7/7/2014	7:30:00 AM	0
7/7/2014	7:45:00 AM	0
7/7/2014	8:00:00 AM	0
7/7/2014	8:15:00 AM	0
7/7/2014	8:30:00 AM	0
7/7/2014	8:45:00 AM	0
7/7/2014	9:00:00 AM	0
7/7/2014	9:15:00 AM	0
7/7/2014	9:30:00 AM	0
7/7/2014	9:45:00 AM	0
7/7/2014	10:00:00 AM	0
7/7/2014	10:15:00 AM	0
7/7/2014	10:30:00 AM	0
7/7/2014	10:45:00 AM	0
7/7/2014	11:00:00 AM	0
7/7/2014	11:15:00 AM	0
7/7/2014	11:30:00 AM	0
7/7/2014	11:45:00 AM	0
7/7/2014	12:00:00 PM	0
7/7/2014	12:15:00 PM	0
7/7/2014	12:30:00 PM	0
7/7/2014	12:45:00 PM	0
7/7/2014	1:00:00 PM	0
7/7/2014	1:15:00 PM	0
7/7/2014	1:30:00 PM	0
7/7/2014	1:45:00 PM	0
7/7/2014	2:00:00 PM	0
7/7/2014	2:15:00 PM	0
7/7/2014	2:30:00 PM	0
7/7/2014	2:45:00 PM	0
7/7/2014	3:00:00 PM	0
7/7/2014	3:15:00 PM	0
7/7/2014	3:30:00 PM	0
7/7/2014	3:45:00 PM	0
7/7/2014	4:00:00 PM	0
7/7/2014	4:15:00 PM	0
7/7/2014	4:30:00 PM	0
7/7/2014	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/7/2014	5:00:00 PM	0
7/7/2014	5:15:00 PM	0
7/7/2014	5:30:00 PM	0
7/7/2014	5:45:00 PM	0
7/7/2014	6:00:00 PM	0
7/7/2014	6:15:00 PM	0
7/7/2014	6:30:00 PM	0
7/7/2014	6:45:00 PM	0
7/7/2014	7:00:00 PM	0
7/7/2014	7:15:00 PM	0
7/7/2014	7:30:00 PM	0
7/7/2014	7:45:00 PM	0
7/7/2014	8:00:00 PM	0
7/7/2014	8:15:00 PM	0
7/7/2014	8:30:00 PM	0
7/7/2014	8:45:00 PM	0
7/7/2014	9:00:00 PM	0
7/7/2014	9:15:00 PM	0
7/7/2014	9:30:00 PM	0
7/7/2014	9:45:00 PM	0
7/7/2014	10:00:00 PM	0
7/7/2014	10:15:00 PM	0
7/7/2014	10:30:00 PM	0
7/7/2014	10:45:00 PM	0
7/7/2014	11:00:00 PM	0
7/7/2014	11:15:00 PM	0
7/7/2014	11:30:00 PM	0
7/7/2014	11:45:00 PM	0
7/8/2014	12:00:00 AM	0
7/8/2014	12:15:00 AM	0
7/8/2014	12:30:00 AM	0
7/8/2014	12:45:00 AM	0
7/8/2014	1:00:00 AM	0
7/8/2014	1:15:00 AM	0
7/8/2014	1:30:00 AM	0
7/8/2014	1:45:00 AM	0
7/8/2014	2:00:00 AM	0
7/8/2014	2:15:00 AM	0
7/8/2014	2:30:00 AM	0
7/8/2014	2:45:00 AM	0
7/8/2014	3:00:00 AM	0
7/8/2014	3:15:00 AM	0
7/8/2014	3:30:00 AM	0
7/8/2014	3:45:00 AM	0
7/8/2014	4:00:00 AM	0
7/8/2014	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/8/2014	4:30:00 AM	0
7/8/2014	4:45:00 AM	0
7/8/2014	5:00:00 AM	0
7/8/2014	5:15:00 AM	0
7/8/2014	5:30:00 AM	0
7/8/2014	5:45:00 AM	0
7/8/2014	6:00:00 AM	0
7/8/2014	6:15:00 AM	0
7/8/2014	6:30:00 AM	0
7/8/2014	6:45:00 AM	0
7/8/2014	7:00:00 AM	0
7/8/2014	7:15:00 AM	0
7/8/2014	7:30:00 AM	0
7/8/2014	7:45:00 AM	0
7/8/2014	8:00:00 AM	0
7/8/2014	8:15:00 AM	0
7/8/2014	8:30:00 AM	0
7/8/2014	8:45:00 AM	0
7/8/2014	9:00:00 AM	0
7/8/2014	9:15:00 AM	0
7/8/2014	9:30:00 AM	0
7/8/2014	9:45:00 AM	0
7/8/2014	10:00:00 AM	0
7/8/2014	10:15:00 AM	0
7/8/2014	10:30:00 AM	0
7/8/2014	10:45:00 AM	0
7/8/2014	11:00:00 AM	0
7/8/2014	11:15:00 AM	0
7/8/2014	11:30:00 AM	0
7/8/2014	11:45:00 AM	0
7/8/2014	12:00:00 PM	0
7/8/2014	12:15:00 PM	0
7/8/2014	12:30:00 PM	0
7/8/2014	12:45:00 PM	0
7/8/2014	1:00:00 PM	0
7/8/2014	1:15:00 PM	0
7/8/2014	1:30:00 PM	0
7/8/2014	1:45:00 PM	0
7/8/2014	2:00:00 PM	0
7/8/2014	2:15:00 PM	0
7/8/2014	2:30:00 PM	0
7/8/2014	2:45:00 PM	0
7/8/2014	3:00:00 PM	0
7/8/2014	3:15:00 PM	0
7/8/2014	3:30:00 PM	0
7/8/2014	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/8/2014	4:00:00 PM	0
7/8/2014	4:15:00 PM	0
7/8/2014	4:30:00 PM	0
7/8/2014	4:45:00 PM	0
7/8/2014	5:00:00 PM	0
7/8/2014	5:15:00 PM	0
7/8/2014	5:30:00 PM	0
7/8/2014	5:45:00 PM	0
7/8/2014	6:00:00 PM	0
7/8/2014	6:15:00 PM	0
7/8/2014	6:30:00 PM	0
7/8/2014	6:45:00 PM	0
7/8/2014	7:00:00 PM	0
7/8/2014	7:15:00 PM	0
7/8/2014	7:30:00 PM	0
7/8/2014	7:45:00 PM	0
7/8/2014	8:00:00 PM	0
7/8/2014	8:15:00 PM	0
7/8/2014	8:30:00 PM	0
7/8/2014	8:45:00 PM	0
7/8/2014	9:00:00 PM	0
7/8/2014	9:15:00 PM	0
7/8/2014	9:30:00 PM	0
7/8/2014	9:45:00 PM	0
7/8/2014	10:00:00 PM	0
7/8/2014	10:15:00 PM	0
7/8/2014	10:30:00 PM	0
7/8/2014	10:45:00 PM	0
7/8/2014	11:00:00 PM	0
7/8/2014	11:15:00 PM	0
7/8/2014	11:30:00 PM	0
7/8/2014	11:45:00 PM	0
7/9/2014	12:00:00 AM	0
7/9/2014	12:15:00 AM	0
7/9/2014	12:30:00 AM	0
7/9/2014	12:45:00 AM	0
7/9/2014	1:00:00 AM	0
7/9/2014	1:15:00 AM	0
7/9/2014	1:30:00 AM	0
7/9/2014	1:45:00 AM	0
7/9/2014	2:00:00 AM	0
7/9/2014	2:15:00 AM	0
7/9/2014	2:30:00 AM	0
7/9/2014	2:45:00 AM	0
7/9/2014	3:00:00 AM	0
7/9/2014	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/9/2014	3:30:00 AM	0
7/9/2014	3:45:00 AM	0
7/9/2014	4:00:00 AM	0
7/9/2014	4:15:00 AM	0
7/9/2014	4:30:00 AM	0
7/9/2014	4:45:00 AM	0
7/9/2014	5:00:00 AM	0
7/9/2014	5:15:00 AM	0
7/9/2014	5:30:00 AM	0
7/9/2014	5:45:00 AM	0
7/9/2014	6:00:00 AM	0
7/9/2014	6:15:00 AM	0
7/9/2014	6:30:00 AM	0
7/9/2014	6:45:00 AM	0
7/9/2014	7:00:00 AM	0
7/9/2014	7:15:00 AM	0
7/9/2014	7:30:00 AM	0
7/9/2014	7:45:00 AM	0
7/9/2014	8:00:00 AM	0
7/9/2014	8:15:00 AM	0
7/9/2014	8:30:00 AM	0
7/9/2014	8:45:00 AM	0
7/9/2014	9:00:00 AM	0
7/9/2014	9:15:00 AM	0
7/9/2014	9:30:00 AM	0
7/9/2014	9:45:00 AM	0
7/9/2014	10:00:00 AM	0
7/9/2014	10:15:00 AM	0
7/9/2014	10:30:00 AM	0
7/9/2014	10:45:00 AM	0
7/9/2014	11:00:00 AM	0
7/9/2014	11:15:00 AM	0
7/9/2014	11:30:00 AM	0
7/9/2014	11:45:00 AM	0
7/9/2014	12:00:00 PM	0
7/9/2014	12:15:00 PM	0
7/9/2014	12:30:00 PM	0
7/9/2014	12:45:00 PM	0
7/9/2014	1:00:00 PM	0
7/9/2014	1:15:00 PM	0
7/9/2014	1:30:00 PM	0
7/9/2014	1:45:00 PM	0
7/9/2014	2:00:00 PM	0
7/9/2014	2:15:00 PM	0
7/9/2014	2:30:00 PM	0
7/9/2014	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/9/2014	3:00:00 PM	0
7/9/2014	3:15:00 PM	0
7/9/2014	3:30:00 PM	0
7/9/2014	3:45:00 PM	0
7/9/2014	4:00:00 PM	0
7/9/2014	4:15:00 PM	0
7/9/2014	4:30:00 PM	0
7/9/2014	4:45:00 PM	0
7/9/2014	5:00:00 PM	0
7/9/2014	5:15:00 PM	0
7/9/2014	5:30:00 PM	0
7/9/2014	5:45:00 PM	0
7/9/2014	6:00:00 PM	0
7/9/2014	6:15:00 PM	0
7/9/2014	6:30:00 PM	0
7/9/2014	6:45:00 PM	0
7/9/2014	7:00:00 PM	0
7/9/2014	7:15:00 PM	0
7/9/2014	7:30:00 PM	0
7/9/2014	7:45:00 PM	0
7/9/2014	8:00:00 PM	0
7/9/2014	8:15:00 PM	0
7/9/2014	8:30:00 PM	0
7/9/2014	8:45:00 PM	0
7/9/2014	9:00:00 PM	0
7/9/2014	9:15:00 PM	0
7/9/2014	9:30:00 PM	0
7/9/2014	9:45:00 PM	0
7/9/2014	10:00:00 PM	0
7/9/2014	10:15:00 PM	0
7/9/2014	10:30:00 PM	0
7/9/2014	10:45:00 PM	0
7/9/2014	11:00:00 PM	0
7/9/2014	11:15:00 PM	0
7/9/2014	11:30:00 PM	0
7/9/2014	11:45:00 PM	0
7/10/2014	12:00:00 AM	0
7/10/2014	12:15:00 AM	0
7/10/2014	12:30:00 AM	0
7/10/2014	12:45:00 AM	0
7/10/2014	1:00:00 AM	0
7/10/2014	1:15:00 AM	0
7/10/2014	1:30:00 AM	0
7/10/2014	1:45:00 AM	0
7/10/2014	2:00:00 AM	0
7/10/2014	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/10/2014	2:30:00 AM	0
7/10/2014	2:45:00 AM	0
7/10/2014	3:00:00 AM	0
7/10/2014	3:15:00 AM	0
7/10/2014	3:30:00 AM	0
7/10/2014	3:45:00 AM	0
7/10/2014	4:00:00 AM	0
7/10/2014	4:15:00 AM	0
7/10/2014	4:30:00 AM	0
7/10/2014	4:45:00 AM	0
7/10/2014	5:00:00 AM	0
7/10/2014	5:15:00 AM	0
7/10/2014	5:30:00 AM	0
7/10/2014	5:45:00 AM	0
7/10/2014	6:00:00 AM	0
7/10/2014	6:15:00 AM	0
7/10/2014	6:30:00 AM	0
7/10/2014	6:45:00 AM	0
7/10/2014	7:00:00 AM	0
7/10/2014	7:15:00 AM	0
7/10/2014	7:30:00 AM	0
7/10/2014	7:45:00 AM	0
7/10/2014	8:00:00 AM	0
7/10/2014	8:15:00 AM	0
7/10/2014	8:30:00 AM	0
7/10/2014	8:45:00 AM	0
7/10/2014	9:00:00 AM	0
7/10/2014	9:15:00 AM	0
7/10/2014	9:30:00 AM	0
7/10/2014	9:45:00 AM	0
7/10/2014	10:00:00 AM	0
7/10/2014	10:15:00 AM	0
7/10/2014	10:30:00 AM	0
7/10/2014	10:45:00 AM	0
7/10/2014	11:00:00 AM	0
7/10/2014	11:15:00 AM	0
7/10/2014	11:30:00 AM	0
7/10/2014	11:45:00 AM	0
7/10/2014	12:00:00 PM	0
7/10/2014	12:15:00 PM	0
7/10/2014	12:30:00 PM	0
7/10/2014	12:45:00 PM	0
7/10/2014	1:00:00 PM	0
7/10/2014	1:15:00 PM	0
7/10/2014	1:30:00 PM	0
7/10/2014	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/10/2014	2:00:00 PM	0
7/10/2014	2:15:00 PM	0
7/10/2014	2:30:00 PM	0
7/10/2014	2:45:00 PM	0
7/10/2014	3:00:00 PM	0
7/10/2014	3:15:00 PM	0
7/10/2014	3:30:00 PM	0
7/10/2014	3:45:00 PM	0
7/10/2014	4:00:00 PM	0
7/10/2014	4:15:00 PM	0
7/10/2014	4:30:00 PM	0
7/10/2014	4:45:00 PM	0
7/10/2014	5:00:00 PM	0
7/10/2014	5:15:00 PM	0
7/10/2014	5:30:00 PM	0
7/10/2014	5:45:00 PM	0
7/10/2014	6:00:00 PM	0
7/10/2014	6:15:00 PM	0
7/10/2014	6:30:00 PM	0
7/10/2014	6:45:00 PM	0
7/10/2014	7:00:00 PM	0
7/10/2014	7:15:00 PM	0
7/10/2014	7:30:00 PM	0
7/10/2014	7:45:00 PM	0
7/10/2014	8:00:00 PM	0
7/10/2014	8:15:00 PM	0
7/10/2014	8:30:00 PM	0
7/10/2014	8:45:00 PM	0
7/10/2014	9:00:00 PM	0
7/10/2014	9:15:00 PM	0
7/10/2014	9:30:00 PM	0
7/10/2014	9:45:00 PM	0
7/10/2014	10:00:00 PM	0
7/10/2014	10:15:00 PM	0
7/10/2014	10:30:00 PM	0
7/10/2014	10:45:00 PM	0
7/10/2014	11:00:00 PM	0
7/10/2014	11:15:00 PM	0
7/10/2014	11:30:00 PM	0
7/10/2014	11:45:00 PM	0
7/11/2014	12:00:00 AM	0
7/11/2014	12:15:00 AM	0
7/11/2014	12:30:00 AM	0
7/11/2014	12:45:00 AM	0
7/11/2014	1:00:00 AM	0
7/11/2014	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/11/2014	1:30:00 AM	0
7/11/2014	1:45:00 AM	0
7/11/2014	2:00:00 AM	0
7/11/2014	2:15:00 AM	0
7/11/2014	2:30:00 AM	0
7/11/2014	2:45:00 AM	0
7/11/2014	3:00:00 AM	0
7/11/2014	3:15:00 AM	0
7/11/2014	3:30:00 AM	0
7/11/2014	3:45:00 AM	0
7/11/2014	4:00:00 AM	0
7/11/2014	4:15:00 AM	0
7/11/2014	4:30:00 AM	0
7/11/2014	4:45:00 AM	0
7/11/2014	5:00:00 AM	0
7/11/2014	5:15:00 AM	0
7/11/2014	5:30:00 AM	0
7/11/2014	5:45:00 AM	0
7/11/2014	6:00:00 AM	0
7/11/2014	6:15:00 AM	0
7/11/2014	6:30:00 AM	0
7/11/2014	6:45:00 AM	0
7/11/2014	7:00:00 AM	0
7/11/2014	7:15:00 AM	0
7/11/2014	7:30:00 AM	0
7/11/2014	7:45:00 AM	0
7/11/2014	8:00:00 AM	0
7/11/2014	8:15:00 AM	0
7/11/2014	8:30:00 AM	0
7/11/2014	8:45:00 AM	0
7/11/2014	9:00:00 AM	0
7/11/2014	9:15:00 AM	0
7/11/2014	9:30:00 AM	0
7/11/2014	9:45:00 AM	0
7/11/2014	10:00:00 AM	0
7/11/2014	10:15:00 AM	0
7/11/2014	10:30:00 AM	0
7/11/2014	10:45:00 AM	0
7/11/2014	11:00:00 AM	0
7/11/2014	11:15:00 AM	0
7/11/2014	11:30:00 AM	0
7/11/2014	11:45:00 AM	0
7/11/2014	12:00:00 PM	0
7/11/2014	12:15:00 PM	0
7/11/2014	12:30:00 PM	0
7/11/2014	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/11/2014	1:00:00 PM	0
7/11/2014	1:15:00 PM	0
7/11/2014	1:30:00 PM	0
7/11/2014	1:45:00 PM	0
7/11/2014	2:00:00 PM	0
7/11/2014	2:15:00 PM	0
7/11/2014	2:30:00 PM	0
7/11/2014	2:45:00 PM	0
7/11/2014	3:00:00 PM	0
7/11/2014	3:15:00 PM	0
7/11/2014	3:30:00 PM	0
7/11/2014	3:45:00 PM	0
7/11/2014	4:00:00 PM	0
7/11/2014	4:15:00 PM	0
7/11/2014	4:30:00 PM	0
7/11/2014	4:45:00 PM	0
7/11/2014	5:00:00 PM	0
7/11/2014	5:15:00 PM	0
7/11/2014	5:30:00 PM	0
7/11/2014	5:45:00 PM	0
7/11/2014	6:00:00 PM	0
7/11/2014	6:15:00 PM	0
7/11/2014	6:30:00 PM	0
7/11/2014	6:45:00 PM	0
7/11/2014	7:00:00 PM	0
7/11/2014	7:15:00 PM	0
7/11/2014	7:30:00 PM	0
7/11/2014	7:45:00 PM	0
7/11/2014	8:00:00 PM	0
7/11/2014	8:15:00 PM	0
7/11/2014	8:30:00 PM	0
7/11/2014	8:45:00 PM	0
7/11/2014	9:00:00 PM	0
7/11/2014	9:15:00 PM	0
7/11/2014	9:30:00 PM	0
7/11/2014	9:45:00 PM	0
7/11/2014	10:00:00 PM	0
7/11/2014	10:15:00 PM	0
7/11/2014	10:30:00 PM	0
7/11/2014	10:45:00 PM	0
7/11/2014	11:00:00 PM	0
7/11/2014	11:15:00 PM	0
7/11/2014	11:30:00 PM	0
7/11/2014	11:45:00 PM	0
7/12/2014	12:00:00 AM	0
7/12/2014	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	12:30:00 AM	0
7/12/2014	12:45:00 AM	0
7/12/2014	1:00:00 AM	0
7/12/2014	1:15:00 AM	0
7/12/2014	1:30:00 AM	0
7/12/2014	1:45:00 AM	0
7/12/2014	2:00:00 AM	0
7/12/2014	2:15:00 AM	0
7/12/2014	2:30:00 AM	0
7/12/2014	2:45:00 AM	0
7/12/2014	3:00:00 AM	0
7/12/2014	3:15:00 AM	0
7/12/2014	3:30:00 AM	0
7/12/2014	3:45:00 AM	0
7/12/2014	4:00:00 AM	0
7/12/2014	4:15:00 AM	0
7/12/2014	4:30:00 AM	0
7/12/2014	4:45:00 AM	0
7/12/2014	5:00:00 AM	0
7/12/2014	5:15:00 AM	0
7/12/2014	5:30:00 AM	0
7/12/2014	5:45:00 AM	0
7/12/2014	6:00:00 AM	0
7/12/2014	6:15:00 AM	0
7/12/2014	6:30:00 AM	0
7/12/2014	6:45:00 AM	0
7/12/2014	7:00:00 AM	0
7/12/2014	7:15:00 AM	0
7/12/2014	7:30:00 AM	0
7/12/2014	7:45:00 AM	0
7/12/2014	8:00:00 AM	0
7/12/2014	8:15:00 AM	0
7/12/2014	8:30:00 AM	0
7/12/2014	8:45:00 AM	0
7/12/2014	9:00:00 AM	0
7/12/2014	9:15:00 AM	0
7/12/2014	9:30:00 AM	0
7/12/2014	9:45:00 AM	0
7/12/2014	10:00:00 AM	0
7/12/2014	10:15:00 AM	0
7/12/2014	10:30:00 AM	0
7/12/2014	10:45:00 AM	0
7/12/2014	11:00:00 AM	0
7/12/2014	11:15:00 AM	0
7/12/2014	11:30:00 AM	0
7/12/2014	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	12:00:00 PM	0
7/12/2014	12:15:00 PM	0
7/12/2014	12:30:00 PM	0
7/12/2014	12:45:00 PM	0
7/12/2014	1:00:00 PM	0
7/12/2014	1:15:00 PM	0
7/12/2014	1:30:00 PM	0
7/12/2014	1:45:00 PM	0
7/12/2014	2:00:00 PM	0
7/12/2014	2:15:00 PM	0
7/12/2014	2:30:00 PM	0
7/12/2014	2:45:00 PM	0
7/12/2014	3:00:00 PM	0
7/12/2014	3:15:00 PM	0
7/12/2014	3:30:00 PM	0
7/12/2014	3:45:00 PM	0
7/12/2014	4:00:00 PM	0
7/12/2014	4:15:00 PM	0
7/12/2014	4:30:00 PM	0
7/12/2014	4:45:00 PM	0
7/12/2014	5:00:00 PM	0
7/12/2014	5:15:00 PM	0
7/12/2014	5:30:00 PM	0
7/12/2014	5:45:00 PM	0
7/12/2014	6:00:00 PM	0
7/12/2014	6:15:00 PM	0
7/12/2014	6:30:00 PM	0
7/12/2014	6:45:00 PM	0
7/12/2014	7:00:00 PM	0
7/12/2014	7:15:00 PM	0
7/12/2014	7:30:00 PM	0
7/12/2014	7:45:00 PM	0
7/12/2014	8:00:00 PM	0
7/12/2014	8:15:00 PM	0
7/12/2014	8:30:00 PM	0
7/12/2014	8:45:00 PM	0
7/12/2014	9:00:00 PM	0
7/12/2014	9:15:00 PM	0
7/12/2014	9:30:00 PM	0
7/12/2014	9:45:00 PM	0
7/12/2014	10:00:00 PM	0
7/12/2014	10:15:00 PM	0
7/12/2014	10:30:00 PM	0
7/12/2014	10:45:00 PM	0
7/12/2014	11:00:00 PM	0
7/12/2014	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	11:30:00 PM	0
7/12/2014	11:45:00 PM	0
7/13/2014	12:00:00 AM	0
7/13/2014	12:15:00 AM	0
7/13/2014	12:30:00 AM	0
7/13/2014	12:45:00 AM	0
7/13/2014	1:00:00 AM	0
7/13/2014	1:15:00 AM	0
7/13/2014	1:30:00 AM	0
7/13/2014	1:45:00 AM	0
7/13/2014	2:00:00 AM	0
7/13/2014	2:15:00 AM	0
7/13/2014	2:30:00 AM	0
7/13/2014	2:45:00 AM	0
7/13/2014	3:00:00 AM	0
7/13/2014	3:15:00 AM	0
7/13/2014	3:30:00 AM	0
7/13/2014	3:45:00 AM	0
7/13/2014	4:00:00 AM	0
7/13/2014	4:15:00 AM	0
7/13/2014	4:30:00 AM	0
7/13/2014	4:45:00 AM	0
7/13/2014	5:00:00 AM	0
7/13/2014	5:15:00 AM	0
7/13/2014	5:30:00 AM	0
7/13/2014	5:45:00 AM	0
7/13/2014	6:00:00 AM	0
7/13/2014	6:15:00 AM	0
7/13/2014	6:30:00 AM	0
7/13/2014	6:45:00 AM	0
7/13/2014	7:00:00 AM	0
7/13/2014	7:15:00 AM	0
7/13/2014	7:30:00 AM	0
7/13/2014	7:45:00 AM	0
7/13/2014	8:00:00 AM	0
7/13/2014	8:15:00 AM	0
7/13/2014	8:30:00 AM	0
7/13/2014	8:45:00 AM	0
7/13/2014	9:00:00 AM	0
7/13/2014	9:15:00 AM	0
7/13/2014	9:30:00 AM	0
7/13/2014	9:45:00 AM	0
7/13/2014	10:00:00 AM	0
7/13/2014	10:15:00 AM	0
7/13/2014	10:30:00 AM	0
7/13/2014	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/13/2014	11:00:00 AM	0
7/13/2014	11:15:00 AM	0
7/13/2014	11:30:00 AM	0
7/13/2014	11:45:00 AM	0
7/13/2014	12:00:00 PM	0
7/13/2014	12:15:00 PM	0
7/13/2014	12:30:00 PM	0
7/13/2014	12:45:00 PM	0
7/13/2014	1:00:00 PM	0
7/13/2014	1:15:00 PM	0
7/13/2014	1:30:00 PM	0
7/13/2014	1:45:00 PM	0
7/13/2014	2:00:00 PM	0
7/13/2014	2:15:00 PM	0
7/13/2014	2:30:00 PM	0
7/13/2014	2:45:00 PM	0
7/13/2014	3:00:00 PM	0
7/13/2014	3:15:00 PM	0
7/13/2014	3:30:00 PM	0
7/13/2014	3:45:00 PM	0
7/13/2014	4:00:00 PM	0
7/13/2014	4:15:00 PM	0
7/13/2014	4:30:00 PM	0
7/13/2014	4:45:00 PM	0
7/13/2014	5:00:00 PM	0
7/13/2014	5:15:00 PM	0
7/13/2014	5:30:00 PM	0
7/13/2014	5:45:00 PM	0
7/13/2014	6:00:00 PM	0
7/13/2014	6:15:00 PM	0
7/13/2014	6:30:00 PM	0
7/13/2014	6:45:00 PM	0
7/13/2014	7:00:00 PM	0
7/13/2014	7:15:00 PM	0
7/13/2014	7:30:00 PM	0
7/13/2014	7:45:00 PM	0
7/13/2014	8:00:00 PM	0
7/13/2014	8:15:00 PM	0
7/13/2014	8:30:00 PM	0
7/13/2014	8:45:00 PM	0
7/13/2014	9:00:00 PM	0
7/13/2014	9:15:00 PM	0
7/13/2014	9:30:00 PM	0
7/13/2014	9:45:00 PM	0
7/13/2014	10:00:00 PM	0
7/13/2014	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/13/2014	10:30:00 PM	0
7/13/2014	10:45:00 PM	0
7/13/2014	11:00:00 PM	0
7/13/2014	11:15:00 PM	0
7/13/2014	11:30:00 PM	0
7/13/2014	11:45:00 PM	0
7/14/2014	12:00:00 AM	0
7/14/2014	12:15:00 AM	0
7/14/2014	12:30:00 AM	0
7/14/2014	12:45:00 AM	0
7/14/2014	1:00:00 AM	0
7/14/2014	1:15:00 AM	0
7/14/2014	1:30:00 AM	0
7/14/2014	1:45:00 AM	0
7/14/2014	2:00:00 AM	0
7/14/2014	2:15:00 AM	0
7/14/2014	2:30:00 AM	0
7/14/2014	2:45:00 AM	0
7/14/2014	3:00:00 AM	0
7/14/2014	3:15:00 AM	0
7/14/2014	3:30:00 AM	0
7/14/2014	3:45:00 AM	0
7/14/2014	4:00:00 AM	0
7/14/2014	4:15:00 AM	0
7/14/2014	4:30:00 AM	0
7/14/2014	4:45:00 AM	0
7/14/2014	5:00:00 AM	0
7/14/2014	5:15:00 AM	0
7/14/2014	5:30:00 AM	0
7/14/2014	5:45:00 AM	0
7/14/2014	6:00:00 AM	0
7/14/2014	6:15:00 AM	0
7/14/2014	6:30:00 AM	0
7/14/2014	6:45:00 AM	0
7/14/2014	7:00:00 AM	0
7/14/2014	7:15:00 AM	0
7/14/2014	7:30:00 AM	0
7/14/2014	7:45:00 AM	0
7/14/2014	8:00:00 AM	0
7/14/2014	8:15:00 AM	0
7/14/2014	8:30:00 AM	0
7/14/2014	8:45:00 AM	0
7/14/2014	9:00:00 AM	0
7/14/2014	9:15:00 AM	0
7/14/2014	9:30:00 AM	0
7/14/2014	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/14/2014	10:00:00 AM	0
7/14/2014	10:15:00 AM	0
7/14/2014	10:30:00 AM	0
7/14/2014	10:45:00 AM	0
7/14/2014	11:00:00 AM	0
7/14/2014	11:15:00 AM	0
7/14/2014	11:30:00 AM	0
7/14/2014	11:45:00 AM	0
7/14/2014	12:00:00 PM	0
7/14/2014	12:15:00 PM	0
7/14/2014	12:30:00 PM	0
7/14/2014	12:45:00 PM	0
7/14/2014	1:00:00 PM	0
7/14/2014	1:15:00 PM	0
7/14/2014	1:30:00 PM	0
7/14/2014	1:45:00 PM	0
7/14/2014	2:00:00 PM	0
7/14/2014	2:15:00 PM	0
7/14/2014	2:30:00 PM	0
7/14/2014	2:45:00 PM	0
7/14/2014	3:00:00 PM	0
7/14/2014	3:15:00 PM	0
7/14/2014	3:30:00 PM	0
7/14/2014	3:45:00 PM	0
7/14/2014	4:00:00 PM	0
7/14/2014	4:15:00 PM	0
7/14/2014	4:30:00 PM	0
7/14/2014	4:45:00 PM	0
7/14/2014	5:00:00 PM	0
7/14/2014	5:15:00 PM	0
7/14/2014	5:30:00 PM	0
7/14/2014	5:45:00 PM	0
7/14/2014	6:00:00 PM	0
7/14/2014	6:15:00 PM	0
7/14/2014	6:30:00 PM	0
7/14/2014	6:45:00 PM	0
7/14/2014	7:00:00 PM	0
7/14/2014	7:15:00 PM	0
7/14/2014	7:30:00 PM	0
7/14/2014	7:45:00 PM	0
7/14/2014	8:00:00 PM	0
7/14/2014	8:15:00 PM	0
7/14/2014	8:30:00 PM	0
7/14/2014	8:45:00 PM	0
7/14/2014	9:00:00 PM	0
7/14/2014	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/14/2014	9:30:00 PM	0
7/14/2014	9:45:00 PM	0
7/14/2014	10:00:00 PM	0
7/14/2014	10:15:00 PM	0
7/14/2014	10:30:00 PM	0
7/14/2014	10:45:00 PM	0
7/14/2014	11:00:00 PM	0
7/14/2014	11:15:00 PM	0
7/14/2014	11:30:00 PM	0
7/14/2014	11:45:00 PM	0
7/15/2014	12:00:00 AM	0
7/15/2014	12:15:00 AM	0
7/15/2014	12:30:00 AM	0
7/15/2014	12:45:00 AM	0
7/15/2014	1:00:00 AM	0
7/15/2014	1:15:00 AM	0
7/15/2014	1:30:00 AM	0
7/15/2014	1:45:00 AM	0
7/15/2014	2:00:00 AM	0
7/15/2014	2:15:00 AM	0
7/15/2014	2:30:00 AM	0
7/15/2014	2:45:00 AM	0
7/15/2014	3:00:00 AM	0
7/15/2014	3:15:00 AM	0
7/15/2014	3:30:00 AM	0
7/15/2014	3:45:00 AM	0
7/15/2014	4:00:00 AM	0
7/15/2014	4:15:00 AM	0
7/15/2014	4:30:00 AM	0
7/15/2014	4:45:00 AM	0
7/15/2014	5:00:00 AM	0
7/15/2014	5:15:00 AM	0
7/15/2014	5:30:00 AM	0
7/15/2014	5:45:00 AM	0
7/15/2014	6:00:00 AM	0
7/15/2014	6:15:00 AM	0
7/15/2014	6:30:00 AM	0
7/15/2014	6:45:00 AM	0
7/15/2014	7:00:00 AM	0
7/15/2014	7:15:00 AM	0
7/15/2014	7:30:00 AM	0
7/15/2014	7:45:00 AM	0
7/15/2014	8:00:00 AM	0
7/15/2014	8:15:00 AM	0
7/15/2014	8:30:00 AM	0
7/15/2014	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/15/2014	9:00:00 AM	0
7/15/2014	9:15:00 AM	0
7/15/2014	9:30:00 AM	0
7/15/2014	9:45:00 AM	0
7/15/2014	10:00:00 AM	0
7/15/2014	10:15:00 AM	0
7/15/2014	10:30:00 AM	0
7/15/2014	10:45:00 AM	0
7/15/2014	11:00:00 AM	0
7/15/2014	11:15:00 AM	0
7/15/2014	11:30:00 AM	0
7/15/2014	11:45:00 AM	0
7/15/2014	12:00:00 PM	0
7/15/2014	12:15:00 PM	0
7/15/2014	12:30:00 PM	0
7/15/2014	12:45:00 PM	0
7/15/2014	1:00:00 PM	0
7/15/2014	1:15:00 PM	0
7/15/2014	1:30:00 PM	0
7/15/2014	1:45:00 PM	0
7/15/2014	2:00:00 PM	0
7/15/2014	2:15:00 PM	0
7/15/2014	2:30:00 PM	0
7/15/2014	2:45:00 PM	0
7/15/2014	3:00:00 PM	0
7/15/2014	3:15:00 PM	0
7/15/2014	3:30:00 PM	0
7/15/2014	3:45:00 PM	0
7/15/2014	4:00:00 PM	0
7/15/2014	4:15:00 PM	0
7/15/2014	4:30:00 PM	0
7/15/2014	4:45:00 PM	0
7/15/2014	5:00:00 PM	0
7/15/2014	5:15:00 PM	0
7/15/2014	5:30:00 PM	0
7/15/2014	5:45:00 PM	0
7/15/2014	6:00:00 PM	0
7/15/2014	6:15:00 PM	0
7/15/2014	6:30:00 PM	0
7/15/2014	6:45:00 PM	0
7/15/2014	7:00:00 PM	0
7/15/2014	7:15:00 PM	0
7/15/2014	7:30:00 PM	0
7/15/2014	7:45:00 PM	0
7/15/2014	8:00:00 PM	0
7/15/2014	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/15/2014	8:30:00 PM	0
7/15/2014	8:45:00 PM	0
7/15/2014	9:00:00 PM	0
7/15/2014	9:15:00 PM	0
7/15/2014	9:30:00 PM	0
7/15/2014	9:45:00 PM	0
7/15/2014	10:00:00 PM	0
7/15/2014	10:15:00 PM	0
7/15/2014	10:30:00 PM	0
7/15/2014	10:45:00 PM	0
7/15/2014	11:00:00 PM	0
7/15/2014	11:15:00 PM	0
7/15/2014	11:30:00 PM	0
7/15/2014	11:45:00 PM	0
7/16/2014	12:00:00 AM	0
7/16/2014	12:15:00 AM	0
7/16/2014	12:30:00 AM	0
7/16/2014	12:45:00 AM	0
7/16/2014	1:00:00 AM	0
7/16/2014	1:15:00 AM	0
7/16/2014	1:30:00 AM	0
7/16/2014	1:45:00 AM	0
7/16/2014	2:00:00 AM	0
7/16/2014	2:15:00 AM	0
7/16/2014	2:30:00 AM	0
7/16/2014	2:45:00 AM	0
7/16/2014	3:00:00 AM	0
7/16/2014	3:15:00 AM	0
7/16/2014	3:30:00 AM	0
7/16/2014	3:45:00 AM	0
7/16/2014	4:00:00 AM	0
7/16/2014	4:15:00 AM	0
7/16/2014	4:30:00 AM	0
7/16/2014	4:45:00 AM	0
7/16/2014	5:00:00 AM	0
7/16/2014	5:15:00 AM	0
7/16/2014	5:30:00 AM	0
7/16/2014	5:45:00 AM	0
7/16/2014	6:00:00 AM	0
7/16/2014	6:15:00 AM	0
7/16/2014	6:30:00 AM	0
7/16/2014	6:45:00 AM	0
7/16/2014	7:00:00 AM	0
7/16/2014	7:15:00 AM	0
7/16/2014	7:30:00 AM	0
7/16/2014	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/16/2014	8:00:00 AM	0
7/16/2014	8:15:00 AM	0
7/16/2014	8:30:00 AM	0
7/16/2014	8:45:00 AM	0
7/16/2014	9:00:00 AM	0
7/16/2014	9:15:00 AM	0
7/16/2014	9:30:00 AM	0
7/16/2014	9:45:00 AM	0
7/16/2014	10:00:00 AM	0
7/16/2014	10:15:00 AM	0
7/16/2014	10:30:00 AM	0
7/16/2014	10:45:00 AM	0
7/16/2014	11:00:00 AM	0
7/16/2014	11:15:00 AM	0
7/16/2014	11:30:00 AM	0
7/16/2014	11:45:00 AM	0
7/16/2014	12:00:00 PM	0
7/16/2014	12:15:00 PM	0
7/16/2014	12:30:00 PM	0
7/16/2014	12:45:00 PM	0
7/16/2014	1:00:00 PM	0
7/16/2014	1:15:00 PM	0
7/16/2014	1:30:00 PM	0
7/16/2014	1:45:00 PM	0
7/16/2014	2:00:00 PM	0
7/16/2014	2:15:00 PM	0
7/16/2014	2:30:00 PM	0
7/16/2014	2:45:00 PM	0
7/16/2014	3:00:00 PM	0
7/16/2014	3:15:00 PM	0
7/16/2014	3:30:00 PM	0
7/16/2014	3:45:00 PM	0
7/16/2014	4:00:00 PM	0
7/16/2014	4:15:00 PM	0
7/16/2014	4:30:00 PM	0
7/16/2014	4:45:00 PM	0
7/16/2014	5:00:00 PM	0
7/16/2014	5:15:00 PM	0
7/16/2014	5:30:00 PM	0
7/16/2014	5:45:00 PM	0
7/16/2014	6:00:00 PM	0
7/16/2014	6:15:00 PM	0
7/16/2014	6:30:00 PM	0
7/16/2014	6:45:00 PM	0
7/16/2014	7:00:00 PM	0
7/16/2014	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/16/2014	7:30:00 PM	0
7/16/2014	7:45:00 PM	0
7/16/2014	8:00:00 PM	0
7/16/2014	8:15:00 PM	0
7/16/2014	8:30:00 PM	0
7/16/2014	8:45:00 PM	0
7/16/2014	9:00:00 PM	0
7/16/2014	9:15:00 PM	0
7/16/2014	9:30:00 PM	0
7/16/2014	9:45:00 PM	0
7/16/2014	10:00:00 PM	0
7/16/2014	10:15:00 PM	0
7/16/2014	10:30:00 PM	0
7/16/2014	10:45:00 PM	0
7/16/2014	11:00:00 PM	0
7/16/2014	11:15:00 PM	0
7/16/2014	11:30:00 PM	0
7/16/2014	11:45:00 PM	0
7/17/2014	12:00:00 AM	0
7/17/2014	12:15:00 AM	0
7/17/2014	12:30:00 AM	0
7/17/2014	12:45:00 AM	0
7/17/2014	1:00:00 AM	0
7/17/2014	1:15:00 AM	0
7/17/2014	1:30:00 AM	0
7/17/2014	1:45:00 AM	0
7/17/2014	2:00:00 AM	0
7/17/2014	2:15:00 AM	0
7/17/2014	2:30:00 AM	0
7/17/2014	2:45:00 AM	0
7/17/2014	3:00:00 AM	0
7/17/2014	3:15:00 AM	0
7/17/2014	3:30:00 AM	0
7/17/2014	3:45:00 AM	0
7/17/2014	4:00:00 AM	0
7/17/2014	4:15:00 AM	0
7/17/2014	4:30:00 AM	0
7/17/2014	4:45:00 AM	0
7/17/2014	5:00:00 AM	0
7/17/2014	5:15:00 AM	0
7/17/2014	5:30:00 AM	0
7/17/2014	5:45:00 AM	0
7/17/2014	6:00:00 AM	0
7/17/2014	6:15:00 AM	0
7/17/2014	6:30:00 AM	0
7/17/2014	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/17/2014	7:00:00 AM	0
7/17/2014	7:15:00 AM	0
7/17/2014	7:30:00 AM	0
7/17/2014	7:45:00 AM	0
7/17/2014	8:00:00 AM	0
7/17/2014	8:15:00 AM	0
7/17/2014	8:30:00 AM	0
7/17/2014	8:45:00 AM	0
7/17/2014	9:00:00 AM	0
7/17/2014	9:15:00 AM	0
7/17/2014	9:30:00 AM	0
7/17/2014	9:45:00 AM	0
7/17/2014	10:00:00 AM	0
7/17/2014	10:15:00 AM	0
7/17/2014	10:30:00 AM	0
7/17/2014	10:45:00 AM	0
7/17/2014	11:00:00 AM	0
7/17/2014	11:15:00 AM	0
7/17/2014	11:30:00 AM	0
7/17/2014	11:45:00 AM	0
7/17/2014	12:00:00 PM	0
7/17/2014	12:15:00 PM	0
7/17/2014	12:30:00 PM	0
7/17/2014	12:45:00 PM	0
7/17/2014	1:00:00 PM	0
7/17/2014	1:15:00 PM	0
7/17/2014	1:30:00 PM	0
7/17/2014	1:45:00 PM	0
7/17/2014	2:00:00 PM	0
7/17/2014	2:15:00 PM	0
7/17/2014	2:30:00 PM	0
7/17/2014	2:45:00 PM	0
7/17/2014	3:00:00 PM	0
7/17/2014	3:15:00 PM	0
7/17/2014	3:30:00 PM	0
7/17/2014	3:45:00 PM	0
7/17/2014	4:00:00 PM	0
7/17/2014	4:15:00 PM	0
7/17/2014	4:30:00 PM	0
7/17/2014	4:45:00 PM	0
7/17/2014	5:00:00 PM	0
7/17/2014	5:15:00 PM	0
7/17/2014	5:30:00 PM	0
7/17/2014	5:45:00 PM	0
7/17/2014	6:00:00 PM	0
7/17/2014	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/17/2014	6:30:00 PM	0
7/17/2014	6:45:00 PM	0
7/17/2014	7:00:00 PM	0
7/17/2014	7:15:00 PM	0
7/17/2014	7:30:00 PM	0
7/17/2014	7:45:00 PM	0
7/17/2014	8:00:00 PM	0
7/17/2014	8:15:00 PM	0
7/17/2014	8:30:00 PM	0
7/17/2014	8:45:00 PM	0
7/17/2014	9:00:00 PM	0
7/17/2014	9:15:00 PM	0
7/17/2014	9:30:00 PM	0
7/17/2014	9:45:00 PM	0
7/17/2014	10:00:00 PM	0
7/17/2014	10:15:00 PM	0
7/17/2014	10:30:00 PM	0
7/17/2014	10:45:00 PM	0
7/17/2014	11:00:00 PM	0
7/17/2014	11:15:00 PM	0
7/17/2014	11:30:00 PM	0
7/17/2014	11:45:00 PM	0
7/18/2014	12:00:00 AM	0
7/18/2014	12:15:00 AM	0
7/18/2014	12:30:00 AM	0
7/18/2014	12:45:00 AM	0
7/18/2014	1:00:00 AM	0
7/18/2014	1:15:00 AM	0
7/18/2014	1:30:00 AM	0
7/18/2014	1:45:00 AM	0
7/18/2014	2:00:00 AM	0
7/18/2014	2:15:00 AM	0
7/18/2014	2:30:00 AM	0
7/18/2014	2:45:00 AM	0
7/18/2014	3:00:00 AM	0
7/18/2014	3:15:00 AM	0
7/18/2014	3:30:00 AM	0
7/18/2014	3:45:00 AM	0
7/18/2014	4:00:00 AM	0
7/18/2014	4:15:00 AM	0
7/18/2014	4:30:00 AM	0
7/18/2014	4:45:00 AM	0
7/18/2014	5:00:00 AM	0
7/18/2014	5:15:00 AM	0
7/18/2014	5:30:00 AM	0
7/18/2014	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/18/2014	6:00:00 AM	0
7/18/2014	6:15:00 AM	0
7/18/2014	6:30:00 AM	0
7/18/2014	6:45:00 AM	0
7/18/2014	7:00:00 AM	0
7/18/2014	7:15:00 AM	0
7/18/2014	7:30:00 AM	0
7/18/2014	7:45:00 AM	0
7/18/2014	8:00:00 AM	0
7/18/2014	8:15:00 AM	0
7/18/2014	8:30:00 AM	0
7/18/2014	8:45:00 AM	0
7/18/2014	9:00:00 AM	0
7/18/2014	9:15:00 AM	0
7/18/2014	9:30:00 AM	0
7/18/2014	9:45:00 AM	0
7/18/2014	10:00:00 AM	0
7/18/2014	10:15:00 AM	0
7/18/2014	10:30:00 AM	0
7/18/2014	10:45:00 AM	0
7/18/2014	11:00:00 AM	0
7/18/2014	11:15:00 AM	0
7/18/2014	11:30:00 AM	0
7/18/2014	11:45:00 AM	0
7/18/2014	12:00:00 PM	0
7/18/2014	12:15:00 PM	0
7/18/2014	12:30:00 PM	0
7/18/2014	12:45:00 PM	0
7/18/2014	1:00:00 PM	0
7/18/2014	1:15:00 PM	0
7/18/2014	1:30:00 PM	0
7/18/2014	1:45:00 PM	0
7/18/2014	2:00:00 PM	0
7/18/2014	2:15:00 PM	0
7/18/2014	2:30:00 PM	0
7/18/2014	2:45:00 PM	0
7/18/2014	3:00:00 PM	0
7/18/2014	3:15:00 PM	0
7/18/2014	3:30:00 PM	0
7/18/2014	3:45:00 PM	0
7/18/2014	4:00:00 PM	0
7/18/2014	4:15:00 PM	0
7/18/2014	4:30:00 PM	0
7/18/2014	4:45:00 PM	0
7/18/2014	5:00:00 PM	0
7/18/2014	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/18/2014	5:30:00 PM	0
7/18/2014	5:45:00 PM	0
7/18/2014	6:00:00 PM	0
7/18/2014	6:15:00 PM	0
7/18/2014	6:30:00 PM	0
7/18/2014	6:45:00 PM	0
7/18/2014	7:00:00 PM	0
7/18/2014	7:15:00 PM	0
7/18/2014	7:30:00 PM	0
7/18/2014	7:45:00 PM	0
7/18/2014	8:00:00 PM	0
7/18/2014	8:15:00 PM	0
7/18/2014	8:30:00 PM	0
7/18/2014	8:45:00 PM	0
7/18/2014	9:00:00 PM	0
7/18/2014	9:15:00 PM	0
7/18/2014	9:30:00 PM	0
7/18/2014	9:45:00 PM	0
7/18/2014	10:00:00 PM	0
7/18/2014	10:15:00 PM	0
7/18/2014	10:30:00 PM	0
7/18/2014	10:45:00 PM	0
7/18/2014	11:00:00 PM	0
7/18/2014	11:15:00 PM	0
7/18/2014	11:30:00 PM	0
7/18/2014	11:45:00 PM	0
7/19/2014	12:00:00 AM	0
7/19/2014	12:15:00 AM	0
7/19/2014	12:30:00 AM	0
7/19/2014	12:45:00 AM	0
7/19/2014	1:00:00 AM	0
7/19/2014	1:15:00 AM	0
7/19/2014	1:30:00 AM	0
7/19/2014	1:45:00 AM	0
7/19/2014	2:00:00 AM	0
7/19/2014	2:15:00 AM	0
7/19/2014	2:30:00 AM	0
7/19/2014	2:45:00 AM	0
7/19/2014	3:00:00 AM	0
7/19/2014	3:15:00 AM	0
7/19/2014	3:30:00 AM	0
7/19/2014	3:45:00 AM	0
7/19/2014	4:00:00 AM	0
7/19/2014	4:15:00 AM	0
7/19/2014	4:30:00 AM	0
7/19/2014	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/19/2014	5:00:00 AM	0
7/19/2014	5:15:00 AM	0
7/19/2014	5:30:00 AM	0
7/19/2014	5:45:00 AM	0
7/19/2014	6:00:00 AM	0
7/19/2014	6:15:00 AM	0
7/19/2014	6:30:00 AM	0
7/19/2014	6:45:00 AM	0
7/19/2014	7:00:00 AM	0
7/19/2014	7:15:00 AM	0
7/19/2014	7:30:00 AM	0
7/19/2014	7:45:00 AM	0
7/19/2014	8:00:00 AM	0
7/19/2014	8:15:00 AM	0
7/19/2014	8:30:00 AM	0
7/19/2014	8:45:00 AM	0
7/19/2014	9:00:00 AM	0
7/19/2014	9:15:00 AM	0
7/19/2014	9:30:00 AM	0
7/19/2014	9:45:00 AM	0
7/19/2014	10:00:00 AM	0
7/19/2014	10:15:00 AM	0
7/19/2014	10:30:00 AM	0
7/19/2014	10:45:00 AM	0
7/19/2014	11:00:00 AM	0
7/19/2014	11:15:00 AM	0
7/19/2014	11:30:00 AM	0
7/19/2014	11:45:00 AM	0
7/19/2014	12:00:00 PM	0
7/19/2014	12:15:00 PM	0
7/19/2014	12:30:00 PM	0
7/19/2014	12:45:00 PM	0
7/19/2014	1:00:00 PM	0
7/19/2014	1:15:00 PM	0
7/19/2014	1:30:00 PM	0
7/19/2014	1:45:00 PM	0
7/19/2014	2:00:00 PM	0
7/19/2014	2:15:00 PM	0
7/19/2014	2:30:00 PM	0
7/19/2014	2:45:00 PM	0
7/19/2014	3:00:00 PM	0
7/19/2014	3:15:00 PM	0
7/19/2014	3:30:00 PM	0
7/19/2014	3:45:00 PM	0
7/19/2014	4:00:00 PM	0
7/19/2014	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/19/2014	4:30:00 PM	0
7/19/2014	4:45:00 PM	0
7/19/2014	5:00:00 PM	0
7/19/2014	5:15:00 PM	0
7/19/2014	5:30:00 PM	0
7/19/2014	5:45:00 PM	0
7/19/2014	6:00:00 PM	0
7/19/2014	6:15:00 PM	0
7/19/2014	6:30:00 PM	0
7/19/2014	6:45:00 PM	0
7/19/2014	7:00:00 PM	0
7/19/2014	7:15:00 PM	0
7/19/2014	7:30:00 PM	0
7/19/2014	7:45:00 PM	0
7/19/2014	8:00:00 PM	0
7/19/2014	8:15:00 PM	0
7/19/2014	8:30:00 PM	0
7/19/2014	8:45:00 PM	0
7/19/2014	9:00:00 PM	0
7/19/2014	9:15:00 PM	0
7/19/2014	9:30:00 PM	0
7/19/2014	9:45:00 PM	0
7/19/2014	10:00:00 PM	0
7/19/2014	10:15:00 PM	0
7/19/2014	10:30:00 PM	0
7/19/2014	10:45:00 PM	0
7/19/2014	11:00:00 PM	0
7/19/2014	11:15:00 PM	0
7/19/2014	11:30:00 PM	0
7/19/2014	11:45:00 PM	0
7/20/2014	12:00:00 AM	0
7/20/2014	12:15:00 AM	0
7/20/2014	12:30:00 AM	0
7/20/2014	12:45:00 AM	0
7/20/2014	1:00:00 AM	0
7/20/2014	1:15:00 AM	0
7/20/2014	1:30:00 AM	0
7/20/2014	1:45:00 AM	0
7/20/2014	2:00:00 AM	0
7/20/2014	2:15:00 AM	0
7/20/2014	2:30:00 AM	0
7/20/2014	2:45:00 AM	0
7/20/2014	3:00:00 AM	0
7/20/2014	3:15:00 AM	0
7/20/2014	3:30:00 AM	0
7/20/2014	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/20/2014	4:00:00 AM	0
7/20/2014	4:15:00 AM	0
7/20/2014	4:30:00 AM	0
7/20/2014	4:45:00 AM	0
7/20/2014	5:00:00 AM	0
7/20/2014	5:15:00 AM	0
7/20/2014	5:30:00 AM	0
7/20/2014	5:45:00 AM	0
7/20/2014	6:00:00 AM	0
7/20/2014	6:15:00 AM	0
7/20/2014	6:30:00 AM	0
7/20/2014	6:45:00 AM	0
7/20/2014	7:00:00 AM	0
7/20/2014	7:15:00 AM	0
7/20/2014	7:30:00 AM	0
7/20/2014	7:45:00 AM	0
7/20/2014	8:00:00 AM	0
7/20/2014	8:15:00 AM	0
7/20/2014	8:30:00 AM	0
7/20/2014	8:45:00 AM	0
7/20/2014	9:00:00 AM	0
7/20/2014	9:15:00 AM	0
7/20/2014	9:30:00 AM	0
7/20/2014	9:45:00 AM	0
7/20/2014	10:00:00 AM	0
7/20/2014	10:15:00 AM	0
7/20/2014	10:30:00 AM	0
7/20/2014	10:45:00 AM	0
7/20/2014	11:00:00 AM	0
7/20/2014	11:15:00 AM	0
7/20/2014	11:30:00 AM	0
7/20/2014	11:45:00 AM	0
7/20/2014	12:00:00 PM	0
7/20/2014	12:15:00 PM	0
7/20/2014	12:30:00 PM	0
7/20/2014	12:45:00 PM	0
7/20/2014	1:00:00 PM	0
7/20/2014	1:15:00 PM	0
7/20/2014	1:30:00 PM	0
7/20/2014	1:45:00 PM	0
7/20/2014	2:00:00 PM	0
7/20/2014	2:15:00 PM	0
7/20/2014	2:30:00 PM	0
7/20/2014	2:45:00 PM	0
7/20/2014	3:00:00 PM	0
7/20/2014	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/20/2014	3:30:00 PM	0
7/20/2014	3:45:00 PM	0
7/20/2014	4:00:00 PM	0
7/20/2014	4:15:00 PM	0
7/20/2014	4:30:00 PM	0
7/20/2014	4:45:00 PM	0
7/20/2014	5:00:00 PM	0
7/20/2014	5:15:00 PM	0
7/20/2014	5:30:00 PM	0
7/20/2014	5:45:00 PM	0
7/20/2014	6:00:00 PM	0
7/20/2014	6:15:00 PM	0
7/20/2014	6:30:00 PM	0
7/20/2014	6:45:00 PM	0
7/20/2014	7:00:00 PM	0
7/20/2014	7:15:00 PM	0
7/20/2014	7:30:00 PM	0
7/20/2014	7:45:00 PM	0
7/20/2014	8:00:00 PM	0
7/20/2014	8:15:00 PM	0
7/20/2014	8:30:00 PM	0
7/20/2014	8:45:00 PM	0
7/20/2014	9:00:00 PM	0
7/20/2014	9:15:00 PM	0
7/20/2014	9:30:00 PM	0
7/20/2014	9:45:00 PM	0
7/20/2014	10:00:00 PM	0
7/20/2014	10:15:00 PM	0
7/20/2014	10:30:00 PM	0
7/20/2014	10:45:00 PM	0
7/20/2014	11:00:00 PM	0
7/20/2014	11:15:00 PM	0
7/20/2014	11:30:00 PM	0
7/20/2014	11:45:00 PM	0
7/21/2014	12:00:00 AM	0
7/21/2014	12:15:00 AM	0
7/21/2014	12:30:00 AM	0
7/21/2014	12:45:00 AM	0
7/21/2014	1:00:00 AM	0
7/21/2014	1:15:00 AM	0
7/21/2014	1:30:00 AM	0
7/21/2014	1:45:00 AM	0
7/21/2014	2:00:00 AM	0
7/21/2014	2:15:00 AM	0
7/21/2014	2:30:00 AM	0
7/21/2014	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/21/2014	3:00:00 AM	0
7/21/2014	3:15:00 AM	0
7/21/2014	3:30:00 AM	0
7/21/2014	3:45:00 AM	0
7/21/2014	4:00:00 AM	0
7/21/2014	4:15:00 AM	0
7/21/2014	4:30:00 AM	0
7/21/2014	4:45:00 AM	0
7/21/2014	5:00:00 AM	0
7/21/2014	5:15:00 AM	0
7/21/2014	5:30:00 AM	0
7/21/2014	5:45:00 AM	0
7/21/2014	6:00:00 AM	0
7/21/2014	6:15:00 AM	0
7/21/2014	6:30:00 AM	0
7/21/2014	6:45:00 AM	0
7/21/2014	7:00:00 AM	0
7/21/2014	7:15:00 AM	0
7/21/2014	7:30:00 AM	0
7/21/2014	7:45:00 AM	0
7/21/2014	8:00:00 AM	0
7/21/2014	8:15:00 AM	0
7/21/2014	8:30:00 AM	0
7/21/2014	8:45:00 AM	0
7/21/2014	9:00:00 AM	0
7/21/2014	9:15:00 AM	0
7/21/2014	9:30:00 AM	0
7/21/2014	9:45:00 AM	0
7/21/2014	10:00:00 AM	0
7/21/2014	10:15:00 AM	0
7/21/2014	10:30:00 AM	0
7/21/2014	10:45:00 AM	0
7/21/2014	11:00:00 AM	0
7/21/2014	11:15:00 AM	0
7/21/2014	11:30:00 AM	0
7/21/2014	11:45:00 AM	0
7/21/2014	12:00:00 PM	0
7/21/2014	12:15:00 PM	0
7/21/2014	12:30:00 PM	0
7/21/2014	12:45:00 PM	0
7/21/2014	1:00:00 PM	0
7/21/2014	1:15:00 PM	0
7/21/2014	1:30:00 PM	0
7/21/2014	1:45:00 PM	0
7/21/2014	2:00:00 PM	0
7/21/2014	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/21/2014	2:30:00 PM	0
7/21/2014	2:45:00 PM	0
7/21/2014	3:00:00 PM	0
7/21/2014	3:15:00 PM	0
7/21/2014	3:30:00 PM	0
7/21/2014	3:45:00 PM	0
7/21/2014	4:00:00 PM	0
7/21/2014	4:15:00 PM	0
7/21/2014	4:30:00 PM	0
7/21/2014	4:45:00 PM	0
7/21/2014	5:00:00 PM	0
7/21/2014	5:15:00 PM	0
7/21/2014	5:30:00 PM	0
7/21/2014	5:45:00 PM	0
7/21/2014	6:00:00 PM	0
7/21/2014	6:15:00 PM	0
7/21/2014	6:30:00 PM	0
7/21/2014	6:45:00 PM	0
7/21/2014	7:00:00 PM	0
7/21/2014	7:15:00 PM	0
7/21/2014	7:30:00 PM	0
7/21/2014	7:45:00 PM	0
7/21/2014	8:00:00 PM	0
7/21/2014	8:15:00 PM	0
7/21/2014	8:30:00 PM	0
7/21/2014	8:45:00 PM	0
7/21/2014	9:00:00 PM	0
7/21/2014	9:15:00 PM	0
7/21/2014	9:30:00 PM	0
7/21/2014	9:45:00 PM	0
7/21/2014	10:00:00 PM	0
7/21/2014	10:15:00 PM	0
7/21/2014	10:30:00 PM	0
7/21/2014	10:45:00 PM	0
7/21/2014	11:00:00 PM	0
7/21/2014	11:15:00 PM	0
7/21/2014	11:30:00 PM	0
7/21/2014	11:45:00 PM	0
7/22/2014	12:00:00 AM	0
7/22/2014	12:15:00 AM	0
7/22/2014	12:30:00 AM	0
7/22/2014	12:45:00 AM	0
7/22/2014	1:00:00 AM	0
7/22/2014	1:15:00 AM	0
7/22/2014	1:30:00 AM	0
7/22/2014	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/22/2014	2:00:00 AM	0
7/22/2014	2:15:00 AM	0
7/22/2014	2:30:00 AM	0
7/22/2014	2:45:00 AM	0
7/22/2014	3:00:00 AM	0
7/22/2014	3:15:00 AM	0
7/22/2014	3:30:00 AM	0
7/22/2014	3:45:00 AM	0
7/22/2014	4:00:00 AM	0
7/22/2014	4:15:00 AM	0
7/22/2014	4:30:00 AM	0
7/22/2014	4:45:00 AM	0
7/22/2014	5:00:00 AM	0
7/22/2014	5:15:00 AM	0
7/22/2014	5:30:00 AM	0
7/22/2014	5:45:00 AM	0
7/22/2014	6:00:00 AM	0
7/22/2014	6:15:00 AM	0
7/22/2014	6:30:00 AM	0
7/22/2014	6:45:00 AM	0
7/22/2014	7:00:00 AM	0
7/22/2014	7:15:00 AM	0
7/22/2014	7:30:00 AM	0
7/22/2014	7:45:00 AM	0
7/22/2014	8:00:00 AM	0
7/22/2014	8:15:00 AM	0
7/22/2014	8:30:00 AM	0
7/22/2014	8:45:00 AM	0
7/22/2014	9:00:00 AM	0
7/22/2014	9:15:00 AM	0
7/22/2014	9:30:00 AM	0
7/22/2014	9:45:00 AM	0
7/22/2014	10:00:00 AM	0
7/22/2014	10:15:00 AM	0
7/22/2014	10:30:00 AM	0
7/22/2014	10:45:00 AM	0
7/22/2014	11:00:00 AM	0
7/22/2014	11:15:00 AM	0
7/22/2014	11:30:00 AM	0
7/22/2014	11:45:00 AM	0
7/22/2014	12:00:00 PM	0
7/22/2014	12:15:00 PM	0
7/22/2014	12:30:00 PM	0
7/22/2014	12:45:00 PM	0
7/22/2014	1:00:00 PM	0
7/22/2014	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/22/2014	1:30:00 PM	0
7/22/2014	1:45:00 PM	0
7/22/2014	2:00:00 PM	0
7/22/2014	2:15:00 PM	0
7/22/2014	2:30:00 PM	0
7/22/2014	2:45:00 PM	0
7/22/2014	3:00:00 PM	0
7/22/2014	3:15:00 PM	0
7/22/2014	3:30:00 PM	0
7/22/2014	3:45:00 PM	0
7/22/2014	4:00:00 PM	0
7/22/2014	4:15:00 PM	0
7/22/2014	4:30:00 PM	0
7/22/2014	4:45:00 PM	0
7/22/2014	5:00:00 PM	0
7/22/2014	5:15:00 PM	0
7/22/2014	5:30:00 PM	0
7/22/2014	5:45:00 PM	0
7/22/2014	6:00:00 PM	0
7/22/2014	6:15:00 PM	0
7/22/2014	6:30:00 PM	0
7/22/2014	6:45:00 PM	0
7/22/2014	7:00:00 PM	0
7/22/2014	7:15:00 PM	0
7/22/2014	7:30:00 PM	0
7/22/2014	7:45:00 PM	0
7/22/2014	8:00:00 PM	0
7/22/2014	8:15:00 PM	0
7/22/2014	8:30:00 PM	0
7/22/2014	8:45:00 PM	0
7/22/2014	9:00:00 PM	0
7/22/2014	9:15:00 PM	0
7/22/2014	9:30:00 PM	0
7/22/2014	9:45:00 PM	0
7/22/2014	10:00:00 PM	0
7/22/2014	10:15:00 PM	0
7/22/2014	10:30:00 PM	0
7/22/2014	10:45:00 PM	0
7/22/2014	11:00:00 PM	0
7/22/2014	11:15:00 PM	0
7/22/2014	11:30:00 PM	0
7/22/2014	11:45:00 PM	0
7/23/2014	12:00:00 AM	0
7/23/2014	12:15:00 AM	0
7/23/2014	12:30:00 AM	0
7/23/2014	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/23/2014	1:00:00 AM	0
7/23/2014	1:15:00 AM	0
7/23/2014	1:30:00 AM	0
7/23/2014	1:45:00 AM	0
7/23/2014	2:00:00 AM	0
7/23/2014	2:15:00 AM	0
7/23/2014	2:30:00 AM	0
7/23/2014	2:45:00 AM	0
7/23/2014	3:00:00 AM	0
7/23/2014	3:15:00 AM	0
7/23/2014	3:30:00 AM	0
7/23/2014	3:45:00 AM	0
7/23/2014	4:00:00 AM	0
7/23/2014	4:15:00 AM	0
7/23/2014	4:30:00 AM	0
7/23/2014	4:45:00 AM	0
7/23/2014	5:00:00 AM	0
7/23/2014	5:15:00 AM	0
7/23/2014	5:30:00 AM	0
7/23/2014	5:45:00 AM	0
7/23/2014	6:00:00 AM	0
7/23/2014	6:15:00 AM	0
7/23/2014	6:30:00 AM	0
7/23/2014	6:45:00 AM	0
7/23/2014	7:00:00 AM	0
7/23/2014	7:15:00 AM	0
7/23/2014	7:30:00 AM	0
7/23/2014	7:45:00 AM	0
7/23/2014	8:00:00 AM	0
7/23/2014	8:15:00 AM	0
7/23/2014	8:30:00 AM	0
7/23/2014	8:45:00 AM	0
7/23/2014	9:00:00 AM	0
7/23/2014	9:15:00 AM	0
7/23/2014	9:30:00 AM	0
7/23/2014	9:45:00 AM	0
7/23/2014	10:00:00 AM	0
7/23/2014	10:15:00 AM	0
7/23/2014	10:30:00 AM	0
7/23/2014	10:45:00 AM	0
7/23/2014	11:00:00 AM	0
7/23/2014	11:15:00 AM	0
7/23/2014	11:30:00 AM	0
7/23/2014	11:45:00 AM	0
7/23/2014	12:00:00 PM	0
7/23/2014	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/23/2014	12:30:00 PM	0
7/23/2014	12:45:00 PM	0
7/23/2014	1:00:00 PM	0
7/23/2014	1:15:00 PM	0
7/23/2014	1:30:00 PM	0
7/23/2014	1:45:00 PM	0
7/23/2014	2:00:00 PM	0
7/23/2014	2:15:00 PM	0
7/23/2014	2:30:00 PM	0
7/23/2014	2:45:00 PM	0
7/23/2014	3:00:00 PM	0
7/23/2014	3:15:00 PM	0
7/23/2014	3:30:00 PM	0
7/23/2014	3:45:00 PM	0
7/23/2014	4:00:00 PM	0
7/23/2014	4:15:00 PM	0
7/23/2014	4:30:00 PM	0
7/23/2014	4:45:00 PM	0
7/23/2014	5:00:00 PM	0
7/23/2014	5:15:00 PM	0
7/23/2014	5:30:00 PM	0
7/23/2014	5:45:00 PM	0
7/23/2014	6:00:00 PM	0
7/23/2014	6:15:00 PM	0
7/23/2014	6:30:00 PM	0
7/23/2014	6:45:00 PM	0
7/23/2014	7:00:00 PM	0
7/23/2014	7:15:00 PM	0
7/23/2014	7:30:00 PM	0
7/23/2014	7:45:00 PM	0
7/23/2014	8:00:00 PM	0
7/23/2014	8:15:00 PM	0
7/23/2014	8:30:00 PM	0
7/23/2014	8:45:00 PM	0
7/23/2014	9:00:00 PM	0
7/23/2014	9:15:00 PM	0
7/23/2014	9:30:00 PM	0
7/23/2014	9:45:00 PM	0
7/23/2014	10:00:00 PM	0
7/23/2014	10:15:00 PM	0
7/23/2014	10:30:00 PM	0
7/23/2014	10:45:00 PM	0
7/23/2014	11:00:00 PM	0
7/23/2014	11:15:00 PM	0
7/23/2014	11:30:00 PM	0
7/23/2014	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	12:00:00 AM	0
7/24/2014	12:15:00 AM	0
7/24/2014	12:30:00 AM	0
7/24/2014	12:45:00 AM	0
7/24/2014	1:00:00 AM	0
7/24/2014	1:15:00 AM	0
7/24/2014	1:30:00 AM	0
7/24/2014	1:45:00 AM	0
7/24/2014	2:00:00 AM	0
7/24/2014	2:15:00 AM	0
7/24/2014	2:30:00 AM	0
7/24/2014	2:45:00 AM	0
7/24/2014	3:00:00 AM	0
7/24/2014	3:15:00 AM	0
7/24/2014	3:30:00 AM	0
7/24/2014	3:45:00 AM	0
7/24/2014	4:00:00 AM	0
7/24/2014	4:15:00 AM	0
7/24/2014	4:30:00 AM	0
7/24/2014	4:45:00 AM	0
7/24/2014	5:00:00 AM	0
7/24/2014	5:15:00 AM	0
7/24/2014	5:30:00 AM	0
7/24/2014	5:45:00 AM	0
7/24/2014	6:00:00 AM	0
7/24/2014	6:15:00 AM	0
7/24/2014	6:30:00 AM	0
7/24/2014	6:45:00 AM	0
7/24/2014	7:00:00 AM	0
7/24/2014	7:15:00 AM	0
7/24/2014	7:30:00 AM	0
7/24/2014	7:45:00 AM	0
7/24/2014	8:00:00 AM	0
7/24/2014	8:15:00 AM	0
7/24/2014	8:30:00 AM	0
7/24/2014	8:45:00 AM	0
7/24/2014	9:00:00 AM	0
7/24/2014	9:15:00 AM	0
7/24/2014	9:30:00 AM	0
7/24/2014	9:45:00 AM	0
7/24/2014	10:00:00 AM	0
7/24/2014	10:15:00 AM	0
7/24/2014	10:30:00 AM	0
7/24/2014	10:45:00 AM	0
7/24/2014	11:00:00 AM	0
7/24/2014	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	11:30:00 AM	0
7/24/2014	11:45:00 AM	0
7/24/2014	12:00:00 PM	0
7/24/2014	12:15:00 PM	0
7/24/2014	12:30:00 PM	0
7/24/2014	12:45:00 PM	0
7/24/2014	1:00:00 PM	0
7/24/2014	1:15:00 PM	0
7/24/2014	1:30:00 PM	0
7/24/2014	1:45:00 PM	0
7/24/2014	2:00:00 PM	0
7/24/2014	2:15:00 PM	0
7/24/2014	2:30:00 PM	0
7/24/2014	2:45:00 PM	0
7/24/2014	3:00:00 PM	0
7/24/2014	3:15:00 PM	0
7/24/2014	3:30:00 PM	0
7/24/2014	3:45:00 PM	0
7/24/2014	4:00:00 PM	0
7/24/2014	4:15:00 PM	0
7/24/2014	4:30:00 PM	0
7/24/2014	4:45:00 PM	0
7/24/2014	5:00:00 PM	0
7/24/2014	5:15:00 PM	0
7/24/2014	5:30:00 PM	0
7/24/2014	5:45:00 PM	0
7/24/2014	6:00:00 PM	0
7/24/2014	6:15:00 PM	0
7/24/2014	6:30:00 PM	0
7/24/2014	6:45:00 PM	0
7/24/2014	7:00:00 PM	0
7/24/2014	7:15:00 PM	0
7/24/2014	7:30:00 PM	0
7/24/2014	7:45:00 PM	0
7/24/2014	8:00:00 PM	0
7/24/2014	8:15:00 PM	0
7/24/2014	8:30:00 PM	0
7/24/2014	8:45:00 PM	0
7/24/2014	9:00:00 PM	0
7/24/2014	9:15:00 PM	0
7/24/2014	9:30:00 PM	0
7/24/2014	9:45:00 PM	0
7/24/2014	10:00:00 PM	0
7/24/2014	10:15:00 PM	0
7/24/2014	10:30:00 PM	0
7/24/2014	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	11:00:00 PM	0
7/24/2014	11:15:00 PM	0
7/24/2014	11:30:00 PM	0
7/24/2014	11:45:00 PM	0
7/25/2014	12:00:00 AM	0
7/25/2014	12:15:00 AM	0
7/25/2014	12:30:00 AM	0
7/25/2014	12:45:00 AM	0
7/25/2014	1:00:00 AM	0
7/25/2014	1:15:00 AM	0
7/25/2014	1:30:00 AM	0
7/25/2014	1:45:00 AM	0
7/25/2014	2:00:00 AM	0
7/25/2014	2:15:00 AM	0
7/25/2014	2:30:00 AM	0
7/25/2014	2:45:00 AM	0
7/25/2014	3:00:00 AM	0
7/25/2014	3:15:00 AM	0
7/25/2014	3:30:00 AM	0
7/25/2014	3:45:00 AM	0
7/25/2014	4:00:00 AM	0
7/25/2014	4:15:00 AM	0
7/25/2014	4:30:00 AM	0
7/25/2014	4:45:00 AM	0
7/25/2014	5:00:00 AM	0
7/25/2014	5:15:00 AM	0
7/25/2014	5:30:00 AM	0
7/25/2014	5:45:00 AM	0
7/25/2014	6:00:00 AM	0
7/25/2014	6:15:00 AM	0
7/25/2014	6:30:00 AM	0
7/25/2014	6:45:00 AM	0
7/25/2014	7:00:00 AM	0
7/25/2014	7:15:00 AM	0
7/25/2014	7:30:00 AM	0
7/25/2014	7:45:00 AM	0
7/25/2014	8:00:00 AM	0
7/25/2014	8:15:00 AM	0
7/25/2014	8:30:00 AM	0
7/25/2014	8:45:00 AM	0
7/25/2014	9:00:00 AM	0
7/25/2014	9:15:00 AM	0
7/25/2014	9:30:00 AM	0
7/25/2014	9:45:00 AM	0
7/25/2014	10:00:00 AM	0
7/25/2014	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/25/2014	10:30:00 AM	0
7/25/2014	10:45:00 AM	0
7/25/2014	11:00:00 AM	0
7/25/2014	11:15:00 AM	0
7/25/2014	11:30:00 AM	0
7/25/2014	11:45:00 AM	0
7/25/2014	12:00:00 PM	0
7/25/2014	12:15:00 PM	0
7/25/2014	12:30:00 PM	0
7/25/2014	12:45:00 PM	0
7/25/2014	1:00:00 PM	0
7/25/2014	1:15:00 PM	0
7/25/2014	1:30:00 PM	0
7/25/2014	1:45:00 PM	0
7/25/2014	2:00:00 PM	0
7/25/2014	2:15:00 PM	0
7/25/2014	2:30:00 PM	0
7/25/2014	2:45:00 PM	0
7/25/2014	3:00:00 PM	0
7/25/2014	3:15:00 PM	0
7/25/2014	3:30:00 PM	0
7/25/2014	3:45:00 PM	0
7/25/2014	4:00:00 PM	0
7/25/2014	4:15:00 PM	0
7/25/2014	4:30:00 PM	0
7/25/2014	4:45:00 PM	0
7/25/2014	5:00:00 PM	0
7/25/2014	5:15:00 PM	0
7/25/2014	5:30:00 PM	0
7/25/2014	5:45:00 PM	0
7/25/2014	6:00:00 PM	0
7/25/2014	6:15:00 PM	0
7/25/2014	6:30:00 PM	0
7/25/2014	6:45:00 PM	0
7/25/2014	7:00:00 PM	0
7/25/2014	7:15:00 PM	0
7/25/2014	7:30:00 PM	0
7/25/2014	7:45:00 PM	0
7/25/2014	8:00:00 PM	0
7/25/2014	8:15:00 PM	0
7/25/2014	8:30:00 PM	0
7/25/2014	8:45:00 PM	0
7/25/2014	9:00:00 PM	0
7/25/2014	9:15:00 PM	0
7/25/2014	9:30:00 PM	0
7/25/2014	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/25/2014	10:00:00 PM	0
7/25/2014	10:15:00 PM	0
7/25/2014	10:30:00 PM	0
7/25/2014	10:45:00 PM	0
7/25/2014	11:00:00 PM	0
7/25/2014	11:15:00 PM	0
7/25/2014	11:30:00 PM	0
7/25/2014	11:45:00 PM	0
7/26/2014	12:00:00 AM	0
7/26/2014	12:15:00 AM	0
7/26/2014	12:30:00 AM	0
7/26/2014	12:45:00 AM	0
7/26/2014	1:00:00 AM	0
7/26/2014	1:15:00 AM	0
7/26/2014	1:30:00 AM	0
7/26/2014	1:45:00 AM	0
7/26/2014	2:00:00 AM	0
7/26/2014	2:15:00 AM	0
7/26/2014	2:30:00 AM	0
7/26/2014	2:45:00 AM	0
7/26/2014	3:00:00 AM	0
7/26/2014	3:15:00 AM	0
7/26/2014	3:30:00 AM	0
7/26/2014	3:45:00 AM	0
7/26/2014	4:00:00 AM	0
7/26/2014	4:15:00 AM	0
7/26/2014	4:30:00 AM	0
7/26/2014	4:45:00 AM	0
7/26/2014	5:00:00 AM	0
7/26/2014	5:15:00 AM	0
7/26/2014	5:30:00 AM	0
7/26/2014	5:45:00 AM	0
7/26/2014	6:00:00 AM	0
7/26/2014	6:15:00 AM	0
7/26/2014	6:30:00 AM	0
7/26/2014	6:45:00 AM	0
7/26/2014	7:00:00 AM	0
7/26/2014	7:15:00 AM	0
7/26/2014	7:30:00 AM	0
7/26/2014	7:45:00 AM	0
7/26/2014	8:00:00 AM	0
7/26/2014	8:15:00 AM	0
7/26/2014	8:30:00 AM	0
7/26/2014	8:45:00 AM	0
7/26/2014	9:00:00 AM	0
7/26/2014	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/26/2014	9:30:00 AM	0
7/26/2014	9:45:00 AM	0
7/26/2014	10:00:00 AM	0
7/26/2014	10:15:00 AM	0
7/26/2014	10:30:00 AM	0
7/26/2014	10:45:00 AM	0
7/26/2014	11:00:00 AM	0
7/26/2014	11:15:00 AM	0
7/26/2014	11:30:00 AM	0
7/26/2014	11:45:00 AM	0
7/26/2014	12:00:00 PM	0
7/26/2014	12:15:00 PM	0
7/26/2014	12:30:00 PM	0
7/26/2014	12:45:00 PM	0
7/26/2014	1:00:00 PM	0
7/26/2014	1:15:00 PM	0
7/26/2014	1:30:00 PM	0
7/26/2014	1:45:00 PM	0
7/26/2014	2:00:00 PM	0
7/26/2014	2:15:00 PM	0
7/26/2014	2:30:00 PM	0
7/26/2014	2:45:00 PM	0
7/26/2014	3:00:00 PM	0
7/26/2014	3:15:00 PM	0
7/26/2014	3:30:00 PM	0
7/26/2014	3:45:00 PM	0
7/26/2014	4:00:00 PM	0
7/26/2014	4:15:00 PM	0
7/26/2014	4:30:00 PM	0
7/26/2014	4:45:00 PM	0
7/26/2014	5:00:00 PM	0
7/26/2014	5:15:00 PM	0
7/26/2014	5:30:00 PM	0
7/26/2014	5:45:00 PM	0
7/26/2014	6:00:00 PM	0
7/26/2014	6:15:00 PM	0
7/26/2014	6:30:00 PM	0
7/26/2014	6:45:00 PM	0
7/26/2014	7:00:00 PM	0
7/26/2014	7:15:00 PM	0
7/26/2014	7:30:00 PM	0
7/26/2014	7:45:00 PM	0
7/26/2014	8:00:00 PM	0
7/26/2014	8:15:00 PM	0
7/26/2014	8:30:00 PM	0
7/26/2014	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/26/2014	9:00:00 PM	0
7/26/2014	9:15:00 PM	0
7/26/2014	9:30:00 PM	0
7/26/2014	9:45:00 PM	0
7/26/2014	10:00:00 PM	0
7/26/2014	10:15:00 PM	0
7/26/2014	10:30:00 PM	0
7/26/2014	10:45:00 PM	0
7/26/2014	11:00:00 PM	0
7/26/2014	11:15:00 PM	0
7/26/2014	11:30:00 PM	0
7/26/2014	11:45:00 PM	0
7/27/2014	12:00:00 AM	0
7/27/2014	12:15:00 AM	0
7/27/2014	12:30:00 AM	0
7/27/2014	12:45:00 AM	0
7/27/2014	1:00:00 AM	0
7/27/2014	1:15:00 AM	0
7/27/2014	1:30:00 AM	0
7/27/2014	1:45:00 AM	0
7/27/2014	2:00:00 AM	0
7/27/2014	2:15:00 AM	0
7/27/2014	2:30:00 AM	0
7/27/2014	2:45:00 AM	0
7/27/2014	3:00:00 AM	0
7/27/2014	3:15:00 AM	0
7/27/2014	3:30:00 AM	0
7/27/2014	3:45:00 AM	0
7/27/2014	4:00:00 AM	0
7/27/2014	4:15:00 AM	0
7/27/2014	4:30:00 AM	0
7/27/2014	4:45:00 AM	0
7/27/2014	5:00:00 AM	0
7/27/2014	5:15:00 AM	0
7/27/2014	5:30:00 AM	0
7/27/2014	5:45:00 AM	0
7/27/2014	6:00:00 AM	0
7/27/2014	6:15:00 AM	0
7/27/2014	6:30:00 AM	0
7/27/2014	6:45:00 AM	0
7/27/2014	7:00:00 AM	0
7/27/2014	7:15:00 AM	0
7/27/2014	7:30:00 AM	0
7/27/2014	7:45:00 AM	0
7/27/2014	8:00:00 AM	0
7/27/2014	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/27/2014	8:30:00 AM	0
7/27/2014	8:45:00 AM	0
7/27/2014	9:00:00 AM	0
7/27/2014	9:15:00 AM	0
7/27/2014	9:30:00 AM	0
7/27/2014	9:45:00 AM	0
7/27/2014	10:00:00 AM	0
7/27/2014	10:15:00 AM	0
7/27/2014	10:30:00 AM	0
7/27/2014	10:45:00 AM	0
7/27/2014	11:00:00 AM	0
7/27/2014	11:15:00 AM	0
7/27/2014	11:30:00 AM	0
7/27/2014	11:45:00 AM	0
7/27/2014	12:00:00 PM	0
7/27/2014	12:15:00 PM	0
7/27/2014	12:30:00 PM	0
7/27/2014	12:45:00 PM	0
7/27/2014	1:00:00 PM	0
7/27/2014	1:15:00 PM	0
7/27/2014	1:30:00 PM	0
7/27/2014	1:45:00 PM	0
7/27/2014	2:00:00 PM	0
7/27/2014	2:15:00 PM	0
7/27/2014	2:30:00 PM	0
7/27/2014	2:45:00 PM	0
7/27/2014	3:00:00 PM	0
7/27/2014	3:15:00 PM	0
7/27/2014	3:30:00 PM	0
7/27/2014	3:45:00 PM	0
7/27/2014	4:00:00 PM	0
7/27/2014	4:15:00 PM	0
7/27/2014	4:30:00 PM	0
7/27/2014	4:45:00 PM	0
7/27/2014	5:00:00 PM	0
7/27/2014	5:15:00 PM	0
7/27/2014	5:30:00 PM	0
7/27/2014	5:45:00 PM	0
7/27/2014	6:00:00 PM	0
7/27/2014	6:15:00 PM	0
7/27/2014	6:30:00 PM	0
7/27/2014	6:45:00 PM	0
7/27/2014	7:00:00 PM	0
7/27/2014	7:15:00 PM	0
7/27/2014	7:30:00 PM	0
7/27/2014	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/27/2014	8:00:00 PM	0
7/27/2014	8:15:00 PM	0
7/27/2014	8:30:00 PM	0
7/27/2014	8:45:00 PM	0
7/27/2014	9:00:00 PM	0
7/27/2014	9:15:00 PM	0
7/27/2014	9:30:00 PM	0
7/27/2014	9:45:00 PM	0
7/27/2014	10:00:00 PM	0
7/27/2014	10:15:00 PM	0
7/27/2014	10:30:00 PM	0
7/27/2014	10:45:00 PM	0
7/27/2014	11:00:00 PM	0
7/27/2014	11:15:00 PM	0
7/27/2014	11:30:00 PM	0
7/27/2014	11:45:00 PM	0
7/28/2014	12:00:00 AM	0
7/28/2014	12:15:00 AM	0
7/28/2014	12:30:00 AM	0
7/28/2014	12:45:00 AM	0
7/28/2014	1:00:00 AM	0
7/28/2014	1:15:00 AM	0
7/28/2014	1:30:00 AM	0
7/28/2014	1:45:00 AM	0
7/28/2014	2:00:00 AM	0
7/28/2014	2:15:00 AM	0
7/28/2014	2:30:00 AM	0
7/28/2014	2:45:00 AM	0
7/28/2014	3:00:00 AM	0
7/28/2014	3:15:00 AM	0
7/28/2014	3:30:00 AM	0
7/28/2014	3:45:00 AM	0
7/28/2014	4:00:00 AM	0
7/28/2014	4:15:00 AM	0
7/28/2014	4:30:00 AM	0
7/28/2014	4:45:00 AM	0
7/28/2014	5:00:00 AM	0
7/28/2014	5:15:00 AM	0
7/28/2014	5:30:00 AM	0
7/28/2014	5:45:00 AM	0
7/28/2014	6:00:00 AM	0
7/28/2014	6:15:00 AM	0
7/28/2014	6:30:00 AM	0
7/28/2014	6:45:00 AM	0
7/28/2014	7:00:00 AM	0
7/28/2014	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/28/2014	7:30:00 AM	0
7/28/2014	7:45:00 AM	0
7/28/2014	8:00:00 AM	0
7/28/2014	8:15:00 AM	0
7/28/2014	8:30:00 AM	0
7/28/2014	8:45:00 AM	0
7/28/2014	9:00:00 AM	0
7/28/2014	9:15:00 AM	0
7/28/2014	9:30:00 AM	0
7/28/2014	9:45:00 AM	0
7/28/2014	10:00:00 AM	0
7/28/2014	10:15:00 AM	0
7/28/2014	10:30:00 AM	0
7/28/2014	10:45:00 AM	0
7/28/2014	11:00:00 AM	0
7/28/2014	11:15:00 AM	0
7/28/2014	11:30:00 AM	0
7/28/2014	11:45:00 AM	0
7/28/2014	12:00:00 PM	0
7/28/2014	12:15:00 PM	0
7/28/2014	12:30:00 PM	0
7/28/2014	12:45:00 PM	0
7/28/2014	1:00:00 PM	0
7/28/2014	1:15:00 PM	0
7/28/2014	1:30:00 PM	0
7/28/2014	1:45:00 PM	0
7/28/2014	2:00:00 PM	0
7/28/2014	2:15:00 PM	0
7/28/2014	2:30:00 PM	0
7/28/2014	2:45:00 PM	0
7/28/2014	3:00:00 PM	0
7/28/2014	3:15:00 PM	0
7/28/2014	3:30:00 PM	0
7/28/2014	3:45:00 PM	0
7/28/2014	4:00:00 PM	0
7/28/2014	4:15:00 PM	0
7/28/2014	4:30:00 PM	0
7/28/2014	4:45:00 PM	0
7/28/2014	5:00:00 PM	0
7/28/2014	5:15:00 PM	0
7/28/2014	5:30:00 PM	0
7/28/2014	5:45:00 PM	0
7/28/2014	6:00:00 PM	0
7/28/2014	6:15:00 PM	0
7/28/2014	6:30:00 PM	0
7/28/2014	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/28/2014	7:00:00 PM	0
7/28/2014	7:15:00 PM	0
7/28/2014	7:30:00 PM	0
7/28/2014	7:45:00 PM	0
7/28/2014	8:00:00 PM	0
7/28/2014	8:15:00 PM	0
7/28/2014	8:30:00 PM	0
7/28/2014	8:45:00 PM	0
7/28/2014	9:00:00 PM	0
7/28/2014	9:15:00 PM	0
7/28/2014	9:30:00 PM	0
7/28/2014	9:45:00 PM	0
7/28/2014	10:00:00 PM	0
7/28/2014	10:15:00 PM	0
7/28/2014	10:30:00 PM	0
7/28/2014	10:45:00 PM	0
7/28/2014	11:00:00 PM	0
7/28/2014	11:15:00 PM	0
7/28/2014	11:30:00 PM	0
7/28/2014	11:45:00 PM	0
7/29/2014	12:00:00 AM	0
7/29/2014	12:15:00 AM	0
7/29/2014	12:30:00 AM	0
7/29/2014	12:45:00 AM	0
7/29/2014	1:00:00 AM	0
7/29/2014	1:15:00 AM	0
7/29/2014	1:30:00 AM	0
7/29/2014	1:45:00 AM	0
7/29/2014	2:00:00 AM	0
7/29/2014	2:15:00 AM	0
7/29/2014	2:30:00 AM	0
7/29/2014	2:45:00 AM	0
7/29/2014	3:00:00 AM	0
7/29/2014	3:15:00 AM	0
7/29/2014	3:30:00 AM	0
7/29/2014	3:45:00 AM	0
7/29/2014	4:00:00 AM	0
7/29/2014	4:15:00 AM	0
7/29/2014	4:30:00 AM	0
7/29/2014	4:45:00 AM	0
7/29/2014	5:00:00 AM	0
7/29/2014	5:15:00 AM	0
7/29/2014	5:30:00 AM	0
7/29/2014	5:45:00 AM	0
7/29/2014	6:00:00 AM	0
7/29/2014	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/29/2014	6:30:00 AM	0
7/29/2014	6:45:00 AM	0
7/29/2014	7:00:00 AM	0
7/29/2014	7:15:00 AM	0
7/29/2014	7:30:00 AM	0
7/29/2014	7:45:00 AM	0
7/29/2014	8:00:00 AM	0
7/29/2014	8:15:00 AM	0
7/29/2014	8:30:00 AM	0
7/29/2014	8:45:00 AM	0
7/29/2014	9:00:00 AM	0
7/29/2014	9:15:00 AM	0
7/29/2014	9:30:00 AM	0
7/29/2014	9:45:00 AM	0
7/29/2014	10:00:00 AM	0
7/29/2014	10:15:00 AM	0
7/29/2014	10:30:00 AM	0
7/29/2014	10:45:00 AM	0
7/29/2014	11:00:00 AM	0
7/29/2014	11:15:00 AM	0
7/29/2014	11:30:00 AM	0
7/29/2014	11:45:00 AM	0
7/29/2014	12:00:00 PM	0
7/29/2014	12:15:00 PM	0
7/29/2014	12:30:00 PM	0
7/29/2014	12:45:00 PM	0
7/29/2014	1:00:00 PM	0
7/29/2014	1:15:00 PM	0
7/29/2014	1:30:00 PM	0
7/29/2014	1:45:00 PM	0
7/29/2014	2:00:00 PM	0
7/29/2014	2:15:00 PM	0
7/29/2014	2:30:00 PM	0
7/29/2014	2:45:00 PM	0
7/29/2014	3:00:00 PM	0
7/29/2014	3:15:00 PM	0
7/29/2014	3:30:00 PM	0
7/29/2014	3:45:00 PM	0
7/29/2014	4:00:00 PM	0
7/29/2014	4:15:00 PM	0
7/29/2014	4:30:00 PM	0
7/29/2014	4:45:00 PM	0
7/29/2014	5:00:00 PM	0
7/29/2014	5:15:00 PM	0
7/29/2014	5:30:00 PM	0
7/29/2014	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/29/2014	6:00:00 PM	0
7/29/2014	6:15:00 PM	0
7/29/2014	6:30:00 PM	0
7/29/2014	6:45:00 PM	0
7/29/2014	7:00:00 PM	0
7/29/2014	7:15:00 PM	0
7/29/2014	7:30:00 PM	0
7/29/2014	7:45:00 PM	0
7/29/2014	8:00:00 PM	0
7/29/2014	8:15:00 PM	0
7/29/2014	8:30:00 PM	0
7/29/2014	8:45:00 PM	0
7/29/2014	9:00:00 PM	0
7/29/2014	9:15:00 PM	0
7/29/2014	9:30:00 PM	0
7/29/2014	9:45:00 PM	0
7/29/2014	10:00:00 PM	0
7/29/2014	10:15:00 PM	0
7/29/2014	10:30:00 PM	0
7/29/2014	10:45:00 PM	0
7/29/2014	11:00:00 PM	0
7/29/2014	11:15:00 PM	0
7/29/2014	11:30:00 PM	0
7/29/2014	11:45:00 PM	0
7/30/2014	12:00:00 AM	0
7/30/2014	12:15:00 AM	0
7/30/2014	12:30:00 AM	0
7/30/2014	12:45:00 AM	0
7/30/2014	1:00:00 AM	0
7/30/2014	1:15:00 AM	0
7/30/2014	1:30:00 AM	0
7/30/2014	1:45:00 AM	0
7/30/2014	2:00:00 AM	0
7/30/2014	2:15:00 AM	0
7/30/2014	2:30:00 AM	0
7/30/2014	2:45:00 AM	0
7/30/2014	3:00:00 AM	0
7/30/2014	3:15:00 AM	0
7/30/2014	3:30:00 AM	0
7/30/2014	3:45:00 AM	0
7/30/2014	4:00:00 AM	0
7/30/2014	4:15:00 AM	0
7/30/2014	4:30:00 AM	0
7/30/2014	4:45:00 AM	0
7/30/2014	5:00:00 AM	0
7/30/2014	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/30/2014	5:30:00 AM	0
7/30/2014	5:45:00 AM	0
7/30/2014	6:00:00 AM	0
7/30/2014	6:15:00 AM	0
7/30/2014	6:30:00 AM	0
7/30/2014	6:45:00 AM	0
7/30/2014	7:00:00 AM	0
7/30/2014	7:15:00 AM	0
7/30/2014	7:30:00 AM	0
7/30/2014	7:45:00 AM	0
7/30/2014	8:00:00 AM	0
7/30/2014	8:15:00 AM	0
7/30/2014	8:30:00 AM	0
7/30/2014	8:45:00 AM	0
7/30/2014	9:00:00 AM	0
7/30/2014	9:15:00 AM	0
7/30/2014	9:30:00 AM	0
7/30/2014	9:45:00 AM	0
7/30/2014	10:00:00 AM	0
7/30/2014	10:15:00 AM	0
7/30/2014	10:30:00 AM	0
7/30/2014	10:45:00 AM	0
7/30/2014	11:00:00 AM	0
7/30/2014	11:15:00 AM	0
7/30/2014	11:30:00 AM	0
7/30/2014	11:45:00 AM	0
7/30/2014	12:00:00 PM	0
7/30/2014	12:15:00 PM	0
7/30/2014	12:30:00 PM	0
7/30/2014	12:45:00 PM	0
7/30/2014	1:00:00 PM	0
7/30/2014	1:15:00 PM	0
7/30/2014	1:30:00 PM	0
7/30/2014	1:45:00 PM	0
7/30/2014	2:00:00 PM	0
7/30/2014	2:15:00 PM	0
7/30/2014	2:30:00 PM	0
7/30/2014	2:45:00 PM	0
7/30/2014	3:00:00 PM	0
7/30/2014	3:15:00 PM	0
7/30/2014	3:30:00 PM	0
7/30/2014	3:45:00 PM	0
7/30/2014	4:00:00 PM	0
7/30/2014	4:15:00 PM	0
7/30/2014	4:30:00 PM	0
7/30/2014	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/30/2014	5:00:00 PM	0
7/30/2014	5:15:00 PM	0
7/30/2014	5:30:00 PM	0
7/30/2014	5:45:00 PM	0
7/30/2014	6:00:00 PM	0
7/30/2014	6:15:00 PM	0
7/30/2014	6:30:00 PM	0
7/30/2014	6:45:00 PM	0
7/30/2014	7:00:00 PM	0
7/30/2014	7:15:00 PM	0
7/30/2014	7:30:00 PM	0
7/30/2014	7:45:00 PM	0
7/30/2014	8:00:00 PM	0
7/30/2014	8:15:00 PM	0
7/30/2014	8:30:00 PM	0
7/30/2014	8:45:00 PM	0
7/30/2014	9:00:00 PM	0
7/30/2014	9:15:00 PM	0
7/30/2014	9:30:00 PM	0
7/30/2014	9:45:00 PM	0
7/30/2014	10:00:00 PM	0
7/30/2014	10:15:00 PM	0
7/30/2014	10:30:00 PM	0
7/30/2014	10:45:00 PM	0
7/30/2014	11:00:00 PM	0
7/30/2014	11:15:00 PM	0
7/30/2014	11:30:00 PM	0
7/30/2014	11:45:00 PM	0
7/31/2014	12:00:00 AM	0
7/31/2014	12:15:00 AM	0
7/31/2014	12:30:00 AM	0
7/31/2014	12:45:00 AM	0
7/31/2014	1:00:00 AM	0
7/31/2014	1:15:00 AM	0
7/31/2014	1:30:00 AM	0
7/31/2014	1:45:00 AM	0
7/31/2014	2:00:00 AM	0
7/31/2014	2:15:00 AM	0
7/31/2014	2:30:00 AM	0
7/31/2014	2:45:00 AM	0
7/31/2014	3:00:00 AM	0
7/31/2014	3:15:00 AM	0
7/31/2014	3:30:00 AM	0
7/31/2014	3:45:00 AM	0
7/31/2014	4:00:00 AM	0
7/31/2014	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/31/2014	4:30:00 AM	0
7/31/2014	4:45:00 AM	0
7/31/2014	5:00:00 AM	0
7/31/2014	5:15:00 AM	0
7/31/2014	5:30:00 AM	0
7/31/2014	5:45:00 AM	0
7/31/2014	6:00:00 AM	0
7/31/2014	6:15:00 AM	0
7/31/2014	6:30:00 AM	0
7/31/2014	6:45:00 AM	0
7/31/2014	7:00:00 AM	0
7/31/2014	7:15:00 AM	0
7/31/2014	7:30:00 AM	0
7/31/2014	7:45:00 AM	0
7/31/2014	8:00:00 AM	0
7/31/2014	8:15:00 AM	0
7/31/2014	8:30:00 AM	0
7/31/2014	8:45:00 AM	0
7/31/2014	9:00:00 AM	0
7/31/2014	9:15:00 AM	0
7/31/2014	9:30:00 AM	0
7/31/2014	9:45:00 AM	0
7/31/2014	10:00:00 AM	0
7/31/2014	10:15:00 AM	0
7/31/2014	10:30:00 AM	0
7/31/2014	10:45:00 AM	0
7/31/2014	11:00:00 AM	0
7/31/2014	11:15:00 AM	0
7/31/2014	11:30:00 AM	0
7/31/2014	11:45:00 AM	0
7/31/2014	12:00:00 PM	0
7/31/2014	12:15:00 PM	0
7/31/2014	12:30:00 PM	0
7/31/2014	12:45:00 PM	0
7/31/2014	1:00:00 PM	0
7/31/2014	1:15:00 PM	0
7/31/2014	1:30:00 PM	0
7/31/2014	1:45:00 PM	0
7/31/2014	2:00:00 PM	0
7/31/2014	2:15:00 PM	0
7/31/2014	2:30:00 PM	0
7/31/2014	2:45:00 PM	0
7/31/2014	3:00:00 PM	0
7/31/2014	3:15:00 PM	0
7/31/2014	3:30:00 PM	0
7/31/2014	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
7/31/2014	4:00:00 PM	0
7/31/2014	4:15:00 PM	0
7/31/2014	4:30:00 PM	0
7/31/2014	4:45:00 PM	0
7/31/2014	5:00:00 PM	0
7/31/2014	5:15:00 PM	0
7/31/2014	5:30:00 PM	0
7/31/2014	5:45:00 PM	0
7/31/2014	6:00:00 PM	0
7/31/2014	6:15:00 PM	0
7/31/2014	6:30:00 PM	0
7/31/2014	6:45:00 PM	0
7/31/2014	7:00:00 PM	0
7/31/2014	7:15:00 PM	0
7/31/2014	7:30:00 PM	0
7/31/2014	7:45:00 PM	0
7/31/2014	8:00:00 PM	0
7/31/2014	8:15:00 PM	0
7/31/2014	8:30:00 PM	0
7/31/2014	8:45:00 PM	0
7/31/2014	9:00:00 PM	0
7/31/2014	9:15:00 PM	0
7/31/2014	9:30:00 PM	0
7/31/2014	9:45:00 PM	0
7/31/2014	10:00:00 PM	0
7/31/2014	10:15:00 PM	0
7/31/2014	10:30:00 PM	0
7/31/2014	10:45:00 PM	0
7/31/2014	11:00:00 PM	0
7/31/2014	11:15:00 PM	0
7/31/2014	11:30:00 PM	0
7/31/2014	11:45:00 PM	0
8/1/2014	12:00:00 AM	0

Georges Ditch Return
Station 0217

Date	Flow (cfs)
7/1/2014	0.019
7/2/2014	0.004
7/3/2014	0.003
7/4/2014	0.005
7/5/2014	0
7/6/2014	0
7/7/2014	0.006
7/8/2014	0.014
7/9/2014	0.05
7/10/2014	0.024
7/11/2014	0.019
7/12/2014	0.007
7/13/2014	0
7/14/2014	0.2
7/15/2014	0.15
7/16/2014	0.067
7/17/2014	0.017
7/18/2014	0.013
7/19/2014	0
7/20/2014	0
7/21/2014	0
7/22/2014	0.105
7/23/2014	0.052
7/24/2014	0.009
7/25/2014	1.005
7/26/2014	4.663
7/27/2014	4.806
7/28/2014	5.24
7/29/2014	11.729
7/30/2014	9.909
7/31/2014	2.978

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	12:00:00 AM	0
7/1/2014	12:15:00 AM	0
7/1/2014	12:30:00 AM	0
7/1/2014	12:45:00 AM	0
7/1/2014	1:00:00 AM	0
7/1/2014	1:15:00 AM	0
7/1/2014	1:30:00 AM	0
7/1/2014	1:45:00 AM	0
7/1/2014	2:00:00 AM	0
7/1/2014	2:15:00 AM	0
7/1/2014	2:30:00 AM	0
7/1/2014	2:45:00 AM	0
7/1/2014	3:00:00 AM	0
7/1/2014	3:15:00 AM	0
7/1/2014	3:30:00 AM	0
7/1/2014	3:45:00 AM	0
7/1/2014	4:00:00 AM	0
7/1/2014	4:15:00 AM	0
7/1/2014	4:30:00 AM	0
7/1/2014	4:45:00 AM	0
7/1/2014	5:00:00 AM	0
7/1/2014	5:15:00 AM	0
7/1/2014	5:30:00 AM	0
7/1/2014	5:45:00 AM	0.01
7/1/2014	6:00:00 AM	0.01
7/1/2014	6:15:00 AM	0.02
7/1/2014	6:30:00 AM	0.02
7/1/2014	6:45:00 AM	0.03
7/1/2014	7:00:00 AM	0.03
7/1/2014	7:15:00 AM	0.03
7/1/2014	7:30:00 AM	0.03
7/1/2014	7:45:00 AM	0.03
7/1/2014	8:00:00 AM	0.03
7/1/2014	8:15:00 AM	0.03
7/1/2014	8:30:00 AM	0.03
7/1/2014	8:45:00 AM	0.03
7/1/2014	9:00:00 AM	0.03
7/1/2014	9:15:00 AM	0.03
7/1/2014	9:30:00 AM	0.02
7/1/2014	9:45:00 AM	0.02
7/1/2014	10:00:00 AM	0.02
7/1/2014	10:15:00 AM	0.02
7/1/2014	10:30:00 AM	0.02
7/1/2014	10:45:00 AM	0.02
7/1/2014	11:00:00 AM	0.02
7/1/2014	11:15:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	11:30:00 AM	0.02
7/1/2014	11:45:00 AM	0.02
7/1/2014	12:00:00 PM	0.02
7/1/2014	12:15:00 PM	0.02
7/1/2014	12:30:00 PM	0.02
7/1/2014	12:45:00 PM	0.01
7/1/2014	1:00:00 PM	0.01
7/1/2014	1:15:00 PM	0.01
7/1/2014	1:30:00 PM	0.01
7/1/2014	1:45:00 PM	0.01
7/1/2014	2:00:00 PM	0.01
7/1/2014	2:15:00 PM	0
7/1/2014	2:30:00 PM	0
7/1/2014	2:45:00 PM	0
7/1/2014	3:00:00 PM	0
7/1/2014	3:15:00 PM	0
7/1/2014	3:30:00 PM	0
7/1/2014	3:45:00 PM	0
7/1/2014	4:00:00 PM	0
7/1/2014	4:15:00 PM	0
7/1/2014	4:30:00 PM	0
7/1/2014	4:45:00 PM	0
7/1/2014	5:00:00 PM	0
7/1/2014	5:15:00 PM	0
7/1/2014	5:30:00 PM	0
7/1/2014	5:45:00 PM	0
7/1/2014	6:00:00 PM	0
7/1/2014	6:15:00 PM	0
7/1/2014	6:30:00 PM	0
7/1/2014	6:45:00 PM	0
7/1/2014	7:00:00 PM	0
7/1/2014	7:15:00 PM	0
7/1/2014	7:30:00 PM	0
7/1/2014	7:45:00 PM	0
7/1/2014	8:00:00 PM	0
7/1/2014	8:15:00 PM	0
7/1/2014	8:30:00 PM	0
7/1/2014	8:45:00 PM	0
7/1/2014	9:00:00 PM	0
7/1/2014	9:15:00 PM	0
7/1/2014	9:30:00 PM	0
7/1/2014	9:45:00 PM	0
7/1/2014	10:00:00 PM	0
7/1/2014	10:15:00 PM	0
7/1/2014	10:30:00 PM	0
7/1/2014	10:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2014	11:00:00 PM	0
7/1/2014	11:15:00 PM	0
7/1/2014	11:30:00 PM	0
7/1/2014	11:45:00 PM	0
7/2/2014	12:00:00 AM	0
7/2/2014	12:15:00 AM	0
7/2/2014	12:30:00 AM	0
7/2/2014	12:45:00 AM	0
7/2/2014	1:00:00 AM	0
7/2/2014	1:15:00 AM	0
7/2/2014	1:30:00 AM	0
7/2/2014	1:45:00 AM	0
7/2/2014	2:00:00 AM	0
7/2/2014	2:15:00 AM	0
7/2/2014	2:30:00 AM	0
7/2/2014	2:45:00 AM	0
7/2/2014	3:00:00 AM	0
7/2/2014	3:15:00 AM	0
7/2/2014	3:30:00 AM	0
7/2/2014	3:45:00 AM	0
7/2/2014	4:00:00 AM	0
7/2/2014	4:15:00 AM	0
7/2/2014	4:30:00 AM	0
7/2/2014	4:45:00 AM	0
7/2/2014	5:00:00 AM	0
7/2/2014	5:15:00 AM	0
7/2/2014	5:30:00 AM	0
7/2/2014	5:45:00 AM	0
7/2/2014	6:00:00 AM	0
7/2/2014	6:15:00 AM	0.01
7/2/2014	6:30:00 AM	0.01
7/2/2014	6:45:00 AM	0.01
7/2/2014	7:00:00 AM	0.01
7/2/2014	7:15:00 AM	0.01
7/2/2014	7:30:00 AM	0.01
7/2/2014	7:45:00 AM	0.01
7/2/2014	8:00:00 AM	0.01
7/2/2014	8:15:00 AM	0.01
7/2/2014	8:30:00 AM	0.01
7/2/2014	8:45:00 AM	0.01
7/2/2014	9:00:00 AM	0.01
7/2/2014	9:15:00 AM	0.01
7/2/2014	9:30:00 AM	0.01
7/2/2014	9:45:00 AM	0.01
7/2/2014	10:00:00 AM	0.01
7/2/2014	10:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/2/2014	10:30:00 AM	0.01
7/2/2014	10:45:00 AM	0.01
7/2/2014	11:00:00 AM	0.01
7/2/2014	11:15:00 AM	0.01
7/2/2014	11:30:00 AM	0.01
7/2/2014	11:45:00 AM	0.01
7/2/2014	12:00:00 PM	0.01
7/2/2014	12:15:00 PM	0
7/2/2014	12:30:00 PM	0
7/2/2014	12:45:00 PM	0
7/2/2014	1:00:00 PM	0
7/2/2014	1:15:00 PM	0
7/2/2014	1:30:00 PM	0
7/2/2014	1:45:00 PM	0
7/2/2014	2:00:00 PM	0
7/2/2014	2:15:00 PM	0
7/2/2014	2:30:00 PM	0
7/2/2014	2:45:00 PM	0
7/2/2014	3:00:00 PM	0
7/2/2014	3:15:00 PM	0
7/2/2014	3:30:00 PM	0
7/2/2014	3:45:00 PM	0
7/2/2014	4:00:00 PM	0
7/2/2014	4:15:00 PM	0
7/2/2014	4:30:00 PM	0
7/2/2014	4:45:00 PM	0
7/2/2014	5:00:00 PM	0
7/2/2014	5:15:00 PM	0
7/2/2014	5:30:00 PM	0
7/2/2014	5:45:00 PM	0
7/2/2014	6:00:00 PM	0
7/2/2014	6:15:00 PM	0
7/2/2014	6:30:00 PM	0
7/2/2014	6:45:00 PM	0
7/2/2014	7:00:00 PM	0
7/2/2014	7:15:00 PM	0
7/2/2014	7:30:00 PM	0
7/2/2014	7:45:00 PM	0
7/2/2014	8:00:00 PM	0
7/2/2014	8:15:00 PM	0
7/2/2014	8:30:00 PM	0
7/2/2014	8:45:00 PM	0
7/2/2014	9:00:00 PM	0
7/2/2014	9:15:00 PM	0
7/2/2014	9:30:00 PM	0
7/2/2014	9:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/2/2014	10:00:00 PM	0
7/2/2014	10:15:00 PM	0
7/2/2014	10:30:00 PM	0
7/2/2014	10:45:00 PM	0
7/2/2014	11:00:00 PM	0
7/2/2014	11:15:00 PM	0
7/2/2014	11:30:00 PM	0
7/2/2014	11:45:00 PM	0
7/3/2014	12:00:00 AM	0
7/3/2014	12:15:00 AM	0
7/3/2014	12:30:00 AM	0
7/3/2014	12:45:00 AM	0
7/3/2014	1:00:00 AM	0
7/3/2014	1:15:00 AM	0
7/3/2014	1:30:00 AM	0
7/3/2014	1:45:00 AM	0
7/3/2014	2:00:00 AM	0
7/3/2014	2:15:00 AM	0
7/3/2014	2:30:00 AM	0
7/3/2014	2:45:00 AM	0
7/3/2014	3:00:00 AM	0
7/3/2014	3:15:00 AM	0
7/3/2014	3:30:00 AM	0
7/3/2014	3:45:00 AM	0
7/3/2014	4:00:00 AM	0
7/3/2014	4:15:00 AM	0
7/3/2014	4:30:00 AM	0
7/3/2014	4:45:00 AM	0
7/3/2014	5:00:00 AM	0
7/3/2014	5:15:00 AM	0
7/3/2014	5:30:00 AM	0
7/3/2014	5:45:00 AM	0
7/3/2014	6:00:00 AM	0
7/3/2014	6:15:00 AM	0
7/3/2014	6:30:00 AM	0
7/3/2014	6:45:00 AM	0
7/3/2014	7:00:00 AM	0
7/3/2014	7:15:00 AM	0
7/3/2014	7:30:00 AM	0
7/3/2014	7:45:00 AM	0
7/3/2014	8:00:00 AM	0
7/3/2014	8:15:00 AM	0
7/3/2014	8:30:00 AM	0
7/3/2014	8:45:00 AM	0
7/3/2014	9:00:00 AM	0
7/3/2014	9:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/3/2014	9:30:00 AM	0
7/3/2014	9:45:00 AM	0
7/3/2014	10:00:00 AM	0
7/3/2014	10:15:00 AM	0
7/3/2014	10:30:00 AM	0
7/3/2014	10:45:00 AM	0
7/3/2014	11:00:00 AM	0
7/3/2014	11:15:00 AM	0
7/3/2014	11:30:00 AM	0
7/3/2014	11:45:00 AM	0
7/3/2014	12:00:00 PM	0
7/3/2014	12:15:00 PM	0
7/3/2014	12:30:00 PM	0
7/3/2014	12:45:00 PM	0.01
7/3/2014	1:00:00 PM	0.01
7/3/2014	1:15:00 PM	0.01
7/3/2014	1:30:00 PM	0.02
7/3/2014	1:45:00 PM	0.02
7/3/2014	2:00:00 PM	0.01
7/3/2014	2:15:00 PM	0.01
7/3/2014	2:30:00 PM	0.01
7/3/2014	2:45:00 PM	0.01
7/3/2014	3:00:00 PM	0.01
7/3/2014	3:15:00 PM	0.01
7/3/2014	3:30:00 PM	0.01
7/3/2014	3:45:00 PM	0.01
7/3/2014	4:00:00 PM	0.01
7/3/2014	4:15:00 PM	0.01
7/3/2014	4:30:00 PM	0.01
7/3/2014	4:45:00 PM	0
7/3/2014	5:00:00 PM	0
7/3/2014	5:15:00 PM	0
7/3/2014	5:30:00 PM	0
7/3/2014	5:45:00 PM	0
7/3/2014	6:00:00 PM	0
7/3/2014	6:15:00 PM	0
7/3/2014	6:30:00 PM	0
7/3/2014	6:45:00 PM	0
7/3/2014	7:00:00 PM	0
7/3/2014	7:15:00 PM	0
7/3/2014	7:30:00 PM	0
7/3/2014	7:45:00 PM	0
7/3/2014	8:00:00 PM	0
7/3/2014	8:15:00 PM	0
7/3/2014	8:30:00 PM	0
7/3/2014	8:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/3/2014	9:00:00 PM	0
7/3/2014	9:15:00 PM	0
7/3/2014	9:30:00 PM	0
7/3/2014	9:45:00 PM	0
7/3/2014	10:00:00 PM	0
7/3/2014	10:15:00 PM	0
7/3/2014	10:30:00 PM	0
7/3/2014	10:45:00 PM	0
7/3/2014	11:00:00 PM	0
7/3/2014	11:15:00 PM	0
7/3/2014	11:30:00 PM	0
7/3/2014	11:45:00 PM	0
7/4/2014	12:00:00 AM	0
7/4/2014	12:15:00 AM	0
7/4/2014	12:30:00 AM	0
7/4/2014	12:45:00 AM	0
7/4/2014	1:00:00 AM	0
7/4/2014	1:15:00 AM	0
7/4/2014	1:30:00 AM	0
7/4/2014	1:45:00 AM	0
7/4/2014	2:00:00 AM	0
7/4/2014	2:15:00 AM	0
7/4/2014	2:30:00 AM	0
7/4/2014	2:45:00 AM	0
7/4/2014	3:00:00 AM	0
7/4/2014	3:15:00 AM	0
7/4/2014	3:30:00 AM	0.01
7/4/2014	3:45:00 AM	0.01
7/4/2014	4:00:00 AM	0.01
7/4/2014	4:15:00 AM	0.01
7/4/2014	4:30:00 AM	0.01
7/4/2014	4:45:00 AM	0.01
7/4/2014	5:00:00 AM	0.01
7/4/2014	5:15:00 AM	0.01
7/4/2014	5:30:00 AM	0.01
7/4/2014	5:45:00 AM	0.01
7/4/2014	6:00:00 AM	0.01
7/4/2014	6:15:00 AM	0.01
7/4/2014	6:30:00 AM	0.01
7/4/2014	6:45:00 AM	0.01
7/4/2014	7:00:00 AM	0.01
7/4/2014	7:15:00 AM	0.01
7/4/2014	7:30:00 AM	0.01
7/4/2014	7:45:00 AM	0.01
7/4/2014	8:00:00 AM	0.01
7/4/2014	8:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/4/2014	8:30:00 AM	0.01
7/4/2014	8:45:00 AM	0.01
7/4/2014	9:00:00 AM	0.01
7/4/2014	9:15:00 AM	0.01
7/4/2014	9:30:00 AM	0.01
7/4/2014	9:45:00 AM	0.01
7/4/2014	10:00:00 AM	0.01
7/4/2014	10:15:00 AM	0.01
7/4/2014	10:30:00 AM	0.01
7/4/2014	10:45:00 AM	0.01
7/4/2014	11:00:00 AM	0
7/4/2014	11:15:00 AM	0.01
7/4/2014	11:30:00 AM	0
7/4/2014	11:45:00 AM	0
7/4/2014	12:00:00 PM	0
7/4/2014	12:15:00 PM	0
7/4/2014	12:30:00 PM	0
7/4/2014	12:45:00 PM	0
7/4/2014	1:00:00 PM	0
7/4/2014	1:15:00 PM	0
7/4/2014	1:30:00 PM	0
7/4/2014	1:45:00 PM	0
7/4/2014	2:00:00 PM	0
7/4/2014	2:15:00 PM	0
7/4/2014	2:30:00 PM	0
7/4/2014	2:45:00 PM	0
7/4/2014	3:00:00 PM	0
7/4/2014	3:15:00 PM	0
7/4/2014	3:30:00 PM	0
7/4/2014	3:45:00 PM	0
7/4/2014	4:00:00 PM	0
7/4/2014	4:15:00 PM	0
7/4/2014	4:30:00 PM	0
7/4/2014	4:45:00 PM	0
7/4/2014	5:00:00 PM	0
7/4/2014	5:15:00 PM	0
7/4/2014	5:30:00 PM	0
7/4/2014	5:45:00 PM	0
7/4/2014	6:00:00 PM	0
7/4/2014	6:15:00 PM	0
7/4/2014	6:30:00 PM	0
7/4/2014	6:45:00 PM	0
7/4/2014	7:00:00 PM	0
7/4/2014	7:15:00 PM	0
7/4/2014	7:30:00 PM	0
7/4/2014	7:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/4/2014	8:00:00 PM	0
7/4/2014	8:15:00 PM	0
7/4/2014	8:30:00 PM	0
7/4/2014	8:45:00 PM	0
7/4/2014	9:00:00 PM	0
7/4/2014	9:15:00 PM	0
7/4/2014	9:30:00 PM	0
7/4/2014	9:45:00 PM	0
7/4/2014	10:00:00 PM	0
7/4/2014	10:15:00 PM	0
7/4/2014	10:30:00 PM	0
7/4/2014	10:45:00 PM	0
7/4/2014	11:00:00 PM	0
7/4/2014	11:15:00 PM	0
7/4/2014	11:30:00 PM	0
7/4/2014	11:45:00 PM	0
7/5/2014	12:00:00 AM	0
7/5/2014	12:15:00 AM	0
7/5/2014	12:30:00 AM	0
7/5/2014	12:45:00 AM	0
7/5/2014	1:00:00 AM	0
7/5/2014	1:15:00 AM	0
7/5/2014	1:30:00 AM	0
7/5/2014	1:45:00 AM	0
7/5/2014	2:00:00 AM	0
7/5/2014	2:15:00 AM	0
7/5/2014	2:30:00 AM	0
7/5/2014	2:45:00 AM	0
7/5/2014	3:00:00 AM	0
7/5/2014	3:15:00 AM	0
7/5/2014	3:30:00 AM	0
7/5/2014	3:45:00 AM	0
7/5/2014	4:00:00 AM	0
7/5/2014	4:15:00 AM	0
7/5/2014	4:30:00 AM	0
7/5/2014	4:45:00 AM	0
7/5/2014	5:00:00 AM	0
7/5/2014	5:15:00 AM	0
7/5/2014	5:30:00 AM	0
7/5/2014	5:45:00 AM	0
7/5/2014	6:00:00 AM	0
7/5/2014	6:15:00 AM	0
7/5/2014	6:30:00 AM	0
7/5/2014	6:45:00 AM	0
7/5/2014	7:00:00 AM	0
7/5/2014	7:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/5/2014	7:30:00 AM	0
7/5/2014	7:45:00 AM	0
7/5/2014	8:00:00 AM	0
7/5/2014	8:15:00 AM	0
7/5/2014	8:30:00 AM	0
7/5/2014	8:45:00 AM	0
7/5/2014	9:00:00 AM	0
7/5/2014	9:15:00 AM	0
7/5/2014	9:30:00 AM	0
7/5/2014	9:45:00 AM	0
7/5/2014	10:00:00 AM	0
7/5/2014	10:15:00 AM	0
7/5/2014	10:30:00 AM	0
7/5/2014	10:45:00 AM	0
7/5/2014	11:00:00 AM	0
7/5/2014	11:15:00 AM	0
7/5/2014	11:30:00 AM	0
7/5/2014	11:45:00 AM	0
7/5/2014	12:00:00 PM	0
7/5/2014	12:15:00 PM	0
7/5/2014	12:30:00 PM	0
7/5/2014	12:45:00 PM	0
7/5/2014	1:00:00 PM	0
7/5/2014	1:15:00 PM	0
7/5/2014	1:30:00 PM	0
7/5/2014	1:45:00 PM	0
7/5/2014	2:00:00 PM	0
7/5/2014	2:15:00 PM	0
7/5/2014	2:30:00 PM	0
7/5/2014	2:45:00 PM	0
7/5/2014	3:00:00 PM	0
7/5/2014	3:15:00 PM	0
7/5/2014	3:30:00 PM	0
7/5/2014	3:45:00 PM	0
7/5/2014	4:00:00 PM	0
7/5/2014	4:15:00 PM	0
7/5/2014	4:30:00 PM	0
7/5/2014	4:45:00 PM	0
7/5/2014	5:00:00 PM	0
7/5/2014	5:15:00 PM	0
7/5/2014	5:30:00 PM	0
7/5/2014	5:45:00 PM	0
7/5/2014	6:00:00 PM	0
7/5/2014	6:15:00 PM	0
7/5/2014	6:30:00 PM	0
7/5/2014	6:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/5/2014	7:00:00 PM	0
7/5/2014	7:15:00 PM	0
7/5/2014	7:30:00 PM	0
7/5/2014	7:45:00 PM	0
7/5/2014	8:00:00 PM	0
7/5/2014	8:15:00 PM	0
7/5/2014	8:30:00 PM	0
7/5/2014	8:45:00 PM	0
7/5/2014	9:00:00 PM	0
7/5/2014	9:15:00 PM	0
7/5/2014	9:30:00 PM	0
7/5/2014	9:45:00 PM	0
7/5/2014	10:00:00 PM	0
7/5/2014	10:15:00 PM	0
7/5/2014	10:30:00 PM	0
7/5/2014	10:45:00 PM	0
7/5/2014	11:00:00 PM	0
7/5/2014	11:15:00 PM	0
7/5/2014	11:30:00 PM	0
7/5/2014	11:45:00 PM	0
7/6/2014	12:00:00 AM	0
7/6/2014	12:15:00 AM	0
7/6/2014	12:30:00 AM	0
7/6/2014	12:45:00 AM	0
7/6/2014	1:00:00 AM	0
7/6/2014	1:15:00 AM	0
7/6/2014	1:30:00 AM	0
7/6/2014	1:45:00 AM	0
7/6/2014	2:00:00 AM	0
7/6/2014	2:15:00 AM	0
7/6/2014	2:30:00 AM	0
7/6/2014	2:45:00 AM	0
7/6/2014	3:00:00 AM	0
7/6/2014	3:15:00 AM	0
7/6/2014	3:30:00 AM	0
7/6/2014	3:45:00 AM	0
7/6/2014	4:00:00 AM	0
7/6/2014	4:15:00 AM	0
7/6/2014	4:30:00 AM	0
7/6/2014	4:45:00 AM	0
7/6/2014	5:00:00 AM	0
7/6/2014	5:15:00 AM	0
7/6/2014	5:30:00 AM	0
7/6/2014	5:45:00 AM	0
7/6/2014	6:00:00 AM	0
7/6/2014	6:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/6/2014	6:30:00 AM	0
7/6/2014	6:45:00 AM	0
7/6/2014	7:00:00 AM	0
7/6/2014	7:15:00 AM	0
7/6/2014	7:30:00 AM	0
7/6/2014	7:45:00 AM	0
7/6/2014	8:00:00 AM	0
7/6/2014	8:15:00 AM	0
7/6/2014	8:30:00 AM	0
7/6/2014	8:45:00 AM	0
7/6/2014	9:00:00 AM	0
7/6/2014	9:15:00 AM	0
7/6/2014	9:30:00 AM	0
7/6/2014	9:45:00 AM	0
7/6/2014	10:00:00 AM	0
7/6/2014	10:15:00 AM	0
7/6/2014	10:30:00 AM	0
7/6/2014	10:45:00 AM	0
7/6/2014	11:00:00 AM	0
7/6/2014	11:15:00 AM	0
7/6/2014	11:30:00 AM	0
7/6/2014	11:45:00 AM	0
7/6/2014	12:00:00 PM	0
7/6/2014	12:15:00 PM	0
7/6/2014	12:30:00 PM	0
7/6/2014	12:45:00 PM	0
7/6/2014	1:00:00 PM	0
7/6/2014	1:15:00 PM	0
7/6/2014	1:30:00 PM	0
7/6/2014	1:45:00 PM	0
7/6/2014	2:00:00 PM	0
7/6/2014	2:15:00 PM	0
7/6/2014	2:30:00 PM	0
7/6/2014	2:45:00 PM	0
7/6/2014	3:00:00 PM	0
7/6/2014	3:15:00 PM	0
7/6/2014	3:30:00 PM	0
7/6/2014	3:45:00 PM	0
7/6/2014	4:00:00 PM	0
7/6/2014	4:15:00 PM	0
7/6/2014	4:30:00 PM	0
7/6/2014	4:45:00 PM	0
7/6/2014	5:00:00 PM	0
7/6/2014	5:15:00 PM	0
7/6/2014	5:30:00 PM	0
7/6/2014	5:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/6/2014	6:00:00 PM	0
7/6/2014	6:15:00 PM	0
7/6/2014	6:30:00 PM	0
7/6/2014	6:45:00 PM	0
7/6/2014	7:00:00 PM	0
7/6/2014	7:15:00 PM	0
7/6/2014	7:30:00 PM	0
7/6/2014	7:45:00 PM	0
7/6/2014	8:00:00 PM	0
7/6/2014	8:15:00 PM	0
7/6/2014	8:30:00 PM	0
7/6/2014	8:45:00 PM	0
7/6/2014	9:00:00 PM	0
7/6/2014	9:15:00 PM	0
7/6/2014	9:30:00 PM	0
7/6/2014	9:45:00 PM	0
7/6/2014	10:00:00 PM	0
7/6/2014	10:15:00 PM	0
7/6/2014	10:30:00 PM	0
7/6/2014	10:45:00 PM	0
7/6/2014	11:00:00 PM	0
7/6/2014	11:15:00 PM	0
7/6/2014	11:30:00 PM	0
7/6/2014	11:45:00 PM	0
7/7/2014	12:00:00 AM	0
7/7/2014	12:15:00 AM	0
7/7/2014	12:30:00 AM	0
7/7/2014	12:45:00 AM	0
7/7/2014	1:00:00 AM	0
7/7/2014	1:15:00 AM	0
7/7/2014	1:30:00 AM	0
7/7/2014	1:45:00 AM	0
7/7/2014	2:00:00 AM	0
7/7/2014	2:15:00 AM	0
7/7/2014	2:30:00 AM	0
7/7/2014	2:45:00 AM	0
7/7/2014	3:00:00 AM	0
7/7/2014	3:15:00 AM	0
7/7/2014	3:30:00 AM	0
7/7/2014	3:45:00 AM	0
7/7/2014	4:00:00 AM	0
7/7/2014	4:15:00 AM	0
7/7/2014	4:30:00 AM	0
7/7/2014	4:45:00 AM	0
7/7/2014	5:00:00 AM	0
7/7/2014	5:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/7/2014	5:30:00 AM	0
7/7/2014	5:45:00 AM	0.01
7/7/2014	6:00:00 AM	0.01
7/7/2014	6:15:00 AM	0.01
7/7/2014	6:30:00 AM	0.01
7/7/2014	6:45:00 AM	0.01
7/7/2014	7:00:00 AM	0.01
7/7/2014	7:15:00 AM	0.01
7/7/2014	7:30:00 AM	0.01
7/7/2014	7:45:00 AM	0.01
7/7/2014	8:00:00 AM	0.01
7/7/2014	8:15:00 AM	0.01
7/7/2014	8:30:00 AM	0.01
7/7/2014	8:45:00 AM	0.01
7/7/2014	9:00:00 AM	0.01
7/7/2014	9:15:00 AM	0.01
7/7/2014	9:30:00 AM	0.01
7/7/2014	9:45:00 AM	0.01
7/7/2014	10:00:00 AM	0.01
7/7/2014	10:15:00 AM	0.01
7/7/2014	10:30:00 AM	0.01
7/7/2014	10:45:00 AM	0.01
7/7/2014	11:00:00 AM	0.01
7/7/2014	11:15:00 AM	0.01
7/7/2014	11:30:00 AM	0.01
7/7/2014	11:45:00 AM	0.01
7/7/2014	12:00:00 PM	0.01
7/7/2014	12:15:00 PM	0.01
7/7/2014	12:30:00 PM	0.01
7/7/2014	12:45:00 PM	0.01
7/7/2014	1:00:00 PM	0.01
7/7/2014	1:15:00 PM	0.01
7/7/2014	1:30:00 PM	0.01
7/7/2014	1:45:00 PM	0.01
7/7/2014	2:00:00 PM	0.01
7/7/2014	2:15:00 PM	0.01
7/7/2014	2:30:00 PM	0
7/7/2014	2:45:00 PM	0
7/7/2014	3:00:00 PM	0
7/7/2014	3:15:00 PM	0
7/7/2014	3:30:00 PM	0
7/7/2014	3:45:00 PM	0
7/7/2014	4:00:00 PM	0
7/7/2014	4:15:00 PM	0
7/7/2014	4:30:00 PM	0
7/7/2014	4:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/7/2014	5:00:00 PM	0
7/7/2014	5:15:00 PM	0
7/7/2014	5:30:00 PM	0
7/7/2014	5:45:00 PM	0
7/7/2014	6:00:00 PM	0
7/7/2014	6:15:00 PM	0
7/7/2014	6:30:00 PM	0
7/7/2014	6:45:00 PM	0
7/7/2014	7:00:00 PM	0
7/7/2014	7:15:00 PM	0
7/7/2014	7:30:00 PM	0
7/7/2014	7:45:00 PM	0
7/7/2014	8:00:00 PM	0
7/7/2014	8:15:00 PM	0
7/7/2014	8:30:00 PM	0
7/7/2014	8:45:00 PM	0
7/7/2014	9:00:00 PM	0
7/7/2014	9:15:00 PM	0
7/7/2014	9:30:00 PM	0
7/7/2014	9:45:00 PM	0
7/7/2014	10:00:00 PM	0
7/7/2014	10:15:00 PM	0
7/7/2014	10:30:00 PM	0
7/7/2014	10:45:00 PM	0
7/7/2014	11:00:00 PM	0
7/7/2014	11:15:00 PM	0
7/7/2014	11:30:00 PM	0
7/7/2014	11:45:00 PM	0
7/8/2014	12:00:00 AM	0.01
7/8/2014	12:15:00 AM	0.01
7/8/2014	12:30:00 AM	0.01
7/8/2014	12:45:00 AM	0.01
7/8/2014	1:00:00 AM	0.01
7/8/2014	1:15:00 AM	0.01
7/8/2014	1:30:00 AM	0.01
7/8/2014	1:45:00 AM	0.01
7/8/2014	2:00:00 AM	0.01
7/8/2014	2:15:00 AM	0.01
7/8/2014	2:30:00 AM	0.01
7/8/2014	2:45:00 AM	0.01
7/8/2014	3:00:00 AM	0.01
7/8/2014	3:15:00 AM	0.01
7/8/2014	3:30:00 AM	0.01
7/8/2014	3:45:00 AM	0.01
7/8/2014	4:00:00 AM	0.01
7/8/2014	4:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/8/2014	4:30:00 AM	0.01
7/8/2014	4:45:00 AM	0.01
7/8/2014	5:00:00 AM	0.01
7/8/2014	5:15:00 AM	0.01
7/8/2014	5:30:00 AM	0.01
7/8/2014	5:45:00 AM	0.01
7/8/2014	6:00:00 AM	0.01
7/8/2014	6:15:00 AM	0.01
7/8/2014	6:30:00 AM	0.01
7/8/2014	6:45:00 AM	0.01
7/8/2014	7:00:00 AM	0.01
7/8/2014	7:15:00 AM	0.01
7/8/2014	7:30:00 AM	0.01
7/8/2014	7:45:00 AM	0.01
7/8/2014	8:00:00 AM	0.01
7/8/2014	8:15:00 AM	0.01
7/8/2014	8:30:00 AM	0.01
7/8/2014	8:45:00 AM	0.01
7/8/2014	9:00:00 AM	0.01
7/8/2014	9:15:00 AM	0.01
7/8/2014	9:30:00 AM	0.01
7/8/2014	9:45:00 AM	0.01
7/8/2014	10:00:00 AM	0.01
7/8/2014	10:15:00 AM	0.01
7/8/2014	10:30:00 AM	0.01
7/8/2014	10:45:00 AM	0.01
7/8/2014	11:00:00 AM	0.01
7/8/2014	11:15:00 AM	0.01
7/8/2014	11:30:00 AM	0.01
7/8/2014	11:45:00 AM	0
7/8/2014	12:00:00 PM	0
7/8/2014	12:15:00 PM	0
7/8/2014	12:30:00 PM	0
7/8/2014	12:45:00 PM	0
7/8/2014	1:00:00 PM	0
7/8/2014	1:15:00 PM	0
7/8/2014	1:30:00 PM	0
7/8/2014	1:45:00 PM	0
7/8/2014	2:00:00 PM	0
7/8/2014	2:15:00 PM	0
7/8/2014	2:30:00 PM	0
7/8/2014	2:45:00 PM	0
7/8/2014	3:00:00 PM	0
7/8/2014	3:15:00 PM	0
7/8/2014	3:30:00 PM	0
7/8/2014	3:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/8/2014	4:00:00 PM	0
7/8/2014	4:15:00 PM	0
7/8/2014	4:30:00 PM	0
7/8/2014	4:45:00 PM	0
7/8/2014	5:00:00 PM	0
7/8/2014	5:15:00 PM	0
7/8/2014	5:30:00 PM	0
7/8/2014	5:45:00 PM	0
7/8/2014	6:00:00 PM	0
7/8/2014	6:15:00 PM	0
7/8/2014	6:30:00 PM	0
7/8/2014	6:45:00 PM	0
7/8/2014	7:00:00 PM	0
7/8/2014	7:15:00 PM	0
7/8/2014	7:30:00 PM	0
7/8/2014	7:45:00 PM	0
7/8/2014	8:00:00 PM	0
7/8/2014	8:15:00 PM	0
7/8/2014	8:30:00 PM	0
7/8/2014	8:45:00 PM	0
7/8/2014	9:00:00 PM	0
7/8/2014	9:15:00 PM	0
7/8/2014	9:30:00 PM	0
7/8/2014	9:45:00 PM	0
7/8/2014	10:00:00 PM	0
7/8/2014	10:15:00 PM	0
7/8/2014	10:30:00 PM	0.03
7/8/2014	10:45:00 PM	0.03
7/8/2014	11:00:00 PM	0.03
7/8/2014	11:15:00 PM	0.03
7/8/2014	11:30:00 PM	0.03
7/8/2014	11:45:00 PM	0.03
7/9/2014	12:00:00 AM	0.03
7/9/2014	12:15:00 AM	0.03
7/9/2014	12:30:00 AM	0.03
7/9/2014	12:45:00 AM	0.03
7/9/2014	1:00:00 AM	0.03
7/9/2014	1:15:00 AM	0.03
7/9/2014	1:30:00 AM	0.03
7/9/2014	1:45:00 AM	0.03
7/9/2014	2:00:00 AM	0.03
7/9/2014	2:15:00 AM	0.03
7/9/2014	2:30:00 AM	0.03
7/9/2014	2:45:00 AM	0.03
7/9/2014	3:00:00 AM	0.03
7/9/2014	3:15:00 AM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
7/9/2014	3:30:00 AM	0.03
7/9/2014	3:45:00 AM	0.03
7/9/2014	4:00:00 AM	0.03
7/9/2014	4:15:00 AM	0.03
7/9/2014	4:30:00 AM	0.03
7/9/2014	4:45:00 AM	0.03
7/9/2014	5:00:00 AM	0.03
7/9/2014	5:15:00 AM	0.03
7/9/2014	5:30:00 AM	0.03
7/9/2014	5:45:00 AM	0.03
7/9/2014	6:00:00 AM	0.03
7/9/2014	6:15:00 AM	0.03
7/9/2014	6:30:00 AM	0.03
7/9/2014	6:45:00 AM	0.03
7/9/2014	7:00:00 AM	0.03
7/9/2014	7:15:00 AM	0.03
7/9/2014	7:30:00 AM	0.03
7/9/2014	7:45:00 AM	0.03
7/9/2014	8:00:00 AM	0.03
7/9/2014	8:15:00 AM	0.03
7/9/2014	8:30:00 AM	0.03
7/9/2014	8:45:00 AM	0.03
7/9/2014	9:00:00 AM	0.03
7/9/2014	9:15:00 AM	0.03
7/9/2014	9:30:00 AM	0.03
7/9/2014	9:45:00 AM	0.03
7/9/2014	10:00:00 AM	0.03
7/9/2014	10:15:00 AM	0.03
7/9/2014	10:30:00 AM	0.03
7/9/2014	10:45:00 AM	0.03
7/9/2014	11:00:00 AM	0.03
7/9/2014	11:15:00 AM	0.03
7/9/2014	11:30:00 AM	0.03
7/9/2014	11:45:00 AM	0.02
7/9/2014	12:00:00 PM	0.02
7/9/2014	12:15:00 PM	0.02
7/9/2014	12:30:00 PM	0.02
7/9/2014	12:45:00 PM	0.02
7/9/2014	1:00:00 PM	0.02
7/9/2014	1:15:00 PM	0.02
7/9/2014	1:30:00 PM	0.02
7/9/2014	1:45:00 PM	0.02
7/9/2014	2:00:00 PM	0.02
7/9/2014	2:15:00 PM	0.02
7/9/2014	2:30:00 PM	0.01
7/9/2014	2:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/9/2014	3:00:00 PM	0.01
7/9/2014	3:15:00 PM	0.01
7/9/2014	3:30:00 PM	0.01
7/9/2014	3:45:00 PM	0.01
7/9/2014	4:00:00 PM	0.01
7/9/2014	4:15:00 PM	0.01
7/9/2014	4:30:00 PM	0.01
7/9/2014	4:45:00 PM	0.01
7/9/2014	5:00:00 PM	0.01
7/9/2014	5:15:00 PM	0
7/9/2014	5:30:00 PM	0
7/9/2014	5:45:00 PM	0
7/9/2014	6:00:00 PM	0
7/9/2014	6:15:00 PM	0
7/9/2014	6:30:00 PM	0
7/9/2014	6:45:00 PM	0
7/9/2014	7:00:00 PM	0
7/9/2014	7:15:00 PM	0
7/9/2014	7:30:00 PM	0
7/9/2014	7:45:00 PM	0
7/9/2014	8:00:00 PM	0
7/9/2014	8:15:00 PM	0
7/9/2014	8:30:00 PM	0
7/9/2014	8:45:00 PM	0
7/9/2014	9:00:00 PM	0
7/9/2014	9:15:00 PM	0
7/9/2014	9:30:00 PM	0
7/9/2014	9:45:00 PM	0
7/9/2014	10:00:00 PM	0
7/9/2014	10:15:00 PM	0
7/9/2014	10:30:00 PM	0
7/9/2014	10:45:00 PM	0
7/9/2014	11:00:00 PM	0
7/9/2014	11:15:00 PM	0
7/9/2014	11:30:00 PM	0
7/9/2014	11:45:00 PM	0
7/10/2014	12:00:00 AM	0.01
7/10/2014	12:15:00 AM	0.01
7/10/2014	12:30:00 AM	0.01
7/10/2014	12:45:00 AM	0.01
7/10/2014	1:00:00 AM	0.01
7/10/2014	1:15:00 AM	0.01
7/10/2014	1:30:00 AM	0.01
7/10/2014	1:45:00 AM	0.01
7/10/2014	2:00:00 AM	0.01
7/10/2014	2:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/10/2014	2:30:00 AM	0.01
7/10/2014	2:45:00 AM	0.01
7/10/2014	3:00:00 AM	0.01
7/10/2014	3:15:00 AM	0.01
7/10/2014	3:30:00 AM	0.01
7/10/2014	3:45:00 AM	0.01
7/10/2014	4:00:00 AM	0.01
7/10/2014	4:15:00 AM	0.01
7/10/2014	4:30:00 AM	0.01
7/10/2014	4:45:00 AM	0.01
7/10/2014	5:00:00 AM	0.01
7/10/2014	5:15:00 AM	0.01
7/10/2014	5:30:00 AM	0.01
7/10/2014	5:45:00 AM	0.01
7/10/2014	6:00:00 AM	0.01
7/10/2014	6:15:00 AM	0.01
7/10/2014	6:30:00 AM	0.01
7/10/2014	6:45:00 AM	0.01
7/10/2014	7:00:00 AM	0.01
7/10/2014	7:15:00 AM	0.02
7/10/2014	7:30:00 AM	0.02
7/10/2014	7:45:00 AM	0.02
7/10/2014	8:00:00 AM	0.02
7/10/2014	8:15:00 AM	0.02
7/10/2014	8:30:00 AM	0.02
7/10/2014	8:45:00 AM	0.02
7/10/2014	9:00:00 AM	0.03
7/10/2014	9:15:00 AM	0.03
7/10/2014	9:30:00 AM	0.03
7/10/2014	9:45:00 AM	0.03
7/10/2014	10:00:00 AM	0.03
7/10/2014	10:15:00 AM	0.03
7/10/2014	10:30:00 AM	0.03
7/10/2014	10:45:00 AM	0.03
7/10/2014	11:00:00 AM	0.03
7/10/2014	11:15:00 AM	0.03
7/10/2014	11:30:00 AM	0.02
7/10/2014	11:45:00 AM	0.02
7/10/2014	12:00:00 PM	0.02
7/10/2014	12:15:00 PM	0.02
7/10/2014	12:30:00 PM	0.02
7/10/2014	12:45:00 PM	0.02
7/10/2014	1:00:00 PM	0.02
7/10/2014	1:15:00 PM	0.02
7/10/2014	1:30:00 PM	0.02
7/10/2014	1:45:00 PM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/10/2014	2:00:00 PM	0.02
7/10/2014	2:15:00 PM	0.01
7/10/2014	2:30:00 PM	0.01
7/10/2014	2:45:00 PM	0.01
7/10/2014	3:00:00 PM	0.01
7/10/2014	3:15:00 PM	0.01
7/10/2014	3:30:00 PM	0.01
7/10/2014	3:45:00 PM	0.01
7/10/2014	4:00:00 PM	0
7/10/2014	4:15:00 PM	0
7/10/2014	4:30:00 PM	0
7/10/2014	4:45:00 PM	0
7/10/2014	5:00:00 PM	0
7/10/2014	5:15:00 PM	0
7/10/2014	5:30:00 PM	0
7/10/2014	5:45:00 PM	0
7/10/2014	6:00:00 PM	0
7/10/2014	6:15:00 PM	0
7/10/2014	6:30:00 PM	0
7/10/2014	6:45:00 PM	0
7/10/2014	7:00:00 PM	0
7/10/2014	7:15:00 PM	0
7/10/2014	7:30:00 PM	0
7/10/2014	7:45:00 PM	0
7/10/2014	8:00:00 PM	0
7/10/2014	8:15:00 PM	0
7/10/2014	8:30:00 PM	0
7/10/2014	8:45:00 PM	0
7/10/2014	9:00:00 PM	0
7/10/2014	9:15:00 PM	0
7/10/2014	9:30:00 PM	0
7/10/2014	9:45:00 PM	0
7/10/2014	10:00:00 PM	0
7/10/2014	10:15:00 PM	0
7/10/2014	10:30:00 PM	0
7/10/2014	10:45:00 PM	0
7/10/2014	11:00:00 PM	0
7/10/2014	11:15:00 PM	0
7/10/2014	11:30:00 PM	0
7/10/2014	11:45:00 PM	0
7/11/2014	12:00:00 AM	0
7/11/2014	12:15:00 AM	0
7/11/2014	12:30:00 AM	0
7/11/2014	12:45:00 AM	0
7/11/2014	1:00:00 AM	0
7/11/2014	1:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/11/2014	1:30:00 AM	0
7/11/2014	1:45:00 AM	0
7/11/2014	2:00:00 AM	0
7/11/2014	2:15:00 AM	0
7/11/2014	2:30:00 AM	0
7/11/2014	2:45:00 AM	0
7/11/2014	3:00:00 AM	0
7/11/2014	3:15:00 AM	0
7/11/2014	3:30:00 AM	0
7/11/2014	3:45:00 AM	0
7/11/2014	4:00:00 AM	0.01
7/11/2014	4:15:00 AM	0.01
7/11/2014	4:30:00 AM	0.01
7/11/2014	4:45:00 AM	0.01
7/11/2014	5:00:00 AM	0.01
7/11/2014	5:15:00 AM	0.01
7/11/2014	5:30:00 AM	0.01
7/11/2014	5:45:00 AM	0.01
7/11/2014	6:00:00 AM	0.01
7/11/2014	6:15:00 AM	0.01
7/11/2014	6:30:00 AM	0.01
7/11/2014	6:45:00 AM	0.01
7/11/2014	7:00:00 AM	0.01
7/11/2014	7:15:00 AM	0.01
7/11/2014	7:30:00 AM	0.01
7/11/2014	7:45:00 AM	0.01
7/11/2014	8:00:00 AM	0.02
7/11/2014	8:15:00 AM	0.02
7/11/2014	8:30:00 AM	0.02
7/11/2014	8:45:00 AM	0.02
7/11/2014	9:00:00 AM	0.03
7/11/2014	9:15:00 AM	0.02
7/11/2014	9:30:00 AM	0.02
7/11/2014	9:45:00 AM	0.02
7/11/2014	10:00:00 AM	0.03
7/11/2014	10:15:00 AM	0.03
7/11/2014	10:30:00 AM	0.03
7/11/2014	10:45:00 AM	0.02
7/11/2014	11:00:00 AM	0.02
7/11/2014	11:15:00 AM	0.02
7/11/2014	11:30:00 AM	0.02
7/11/2014	11:45:00 AM	0.02
7/11/2014	12:00:00 PM	0.02
7/11/2014	12:15:00 PM	0.02
7/11/2014	12:30:00 PM	0.02
7/11/2014	12:45:00 PM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/11/2014	1:00:00 PM	0.02
7/11/2014	1:15:00 PM	0.02
7/11/2014	1:30:00 PM	0.02
7/11/2014	1:45:00 PM	0.02
7/11/2014	2:00:00 PM	0.02
7/11/2014	2:15:00 PM	0.02
7/11/2014	2:30:00 PM	0.01
7/11/2014	2:45:00 PM	0.01
7/11/2014	3:00:00 PM	0.01
7/11/2014	3:15:00 PM	0.01
7/11/2014	3:30:00 PM	0.01
7/11/2014	3:45:00 PM	0.01
7/11/2014	4:00:00 PM	0.01
7/11/2014	4:15:00 PM	0.01
7/11/2014	4:30:00 PM	0.01
7/11/2014	4:45:00 PM	0.01
7/11/2014	5:00:00 PM	0.01
7/11/2014	5:15:00 PM	0
7/11/2014	5:30:00 PM	0
7/11/2014	5:45:00 PM	0
7/11/2014	6:00:00 PM	0
7/11/2014	6:15:00 PM	0
7/11/2014	6:30:00 PM	0
7/11/2014	6:45:00 PM	0
7/11/2014	7:00:00 PM	0
7/11/2014	7:15:00 PM	0
7/11/2014	7:30:00 PM	0
7/11/2014	7:45:00 PM	0
7/11/2014	8:00:00 PM	0
7/11/2014	8:15:00 PM	0
7/11/2014	8:30:00 PM	0
7/11/2014	8:45:00 PM	0
7/11/2014	9:00:00 PM	0
7/11/2014	9:15:00 PM	0
7/11/2014	9:30:00 PM	0
7/11/2014	9:45:00 PM	0
7/11/2014	10:00:00 PM	0
7/11/2014	10:15:00 PM	0
7/11/2014	10:30:00 PM	0
7/11/2014	10:45:00 PM	0
7/11/2014	11:00:00 PM	0
7/11/2014	11:15:00 PM	0
7/11/2014	11:30:00 PM	0
7/11/2014	11:45:00 PM	0
7/12/2014	12:00:00 AM	0
7/12/2014	12:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	12:30:00 AM	0
7/12/2014	12:45:00 AM	0
7/12/2014	1:00:00 AM	0
7/12/2014	1:15:00 AM	0
7/12/2014	1:30:00 AM	0
7/12/2014	1:45:00 AM	0.01
7/12/2014	2:00:00 AM	0.01
7/12/2014	2:15:00 AM	0.01
7/12/2014	2:30:00 AM	0.01
7/12/2014	2:45:00 AM	0.01
7/12/2014	3:00:00 AM	0.01
7/12/2014	3:15:00 AM	0.01
7/12/2014	3:30:00 AM	0.01
7/12/2014	3:45:00 AM	0.01
7/12/2014	4:00:00 AM	0.01
7/12/2014	4:15:00 AM	0.01
7/12/2014	4:30:00 AM	0.01
7/12/2014	4:45:00 AM	0.01
7/12/2014	5:00:00 AM	0.01
7/12/2014	5:15:00 AM	0.01
7/12/2014	5:30:00 AM	0.01
7/12/2014	5:45:00 AM	0.01
7/12/2014	6:00:00 AM	0.01
7/12/2014	6:15:00 AM	0.01
7/12/2014	6:30:00 AM	0.01
7/12/2014	6:45:00 AM	0.01
7/12/2014	7:00:00 AM	0.01
7/12/2014	7:15:00 AM	0.01
7/12/2014	7:30:00 AM	0.01
7/12/2014	7:45:00 AM	0.01
7/12/2014	8:00:00 AM	0.01
7/12/2014	8:15:00 AM	0.01
7/12/2014	8:30:00 AM	0.01
7/12/2014	8:45:00 AM	0.01
7/12/2014	9:00:00 AM	0.01
7/12/2014	9:15:00 AM	0.01
7/12/2014	9:30:00 AM	0.01
7/12/2014	9:45:00 AM	0.01
7/12/2014	10:00:00 AM	0.01
7/12/2014	10:15:00 AM	0.01
7/12/2014	10:30:00 AM	0.01
7/12/2014	10:45:00 AM	0.01
7/12/2014	11:00:00 AM	0.01
7/12/2014	11:15:00 AM	0.01
7/12/2014	11:30:00 AM	0.01
7/12/2014	11:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	12:00:00 PM	0
7/12/2014	12:15:00 PM	0
7/12/2014	12:30:00 PM	0
7/12/2014	12:45:00 PM	0
7/12/2014	1:00:00 PM	0
7/12/2014	1:15:00 PM	0
7/12/2014	1:30:00 PM	0
7/12/2014	1:45:00 PM	0
7/12/2014	2:00:00 PM	0
7/12/2014	2:15:00 PM	0
7/12/2014	2:30:00 PM	0
7/12/2014	2:45:00 PM	0
7/12/2014	3:00:00 PM	0
7/12/2014	3:15:00 PM	0
7/12/2014	3:30:00 PM	0
7/12/2014	3:45:00 PM	0
7/12/2014	4:00:00 PM	0
7/12/2014	4:15:00 PM	0
7/12/2014	4:30:00 PM	0
7/12/2014	4:45:00 PM	0
7/12/2014	5:00:00 PM	0
7/12/2014	5:15:00 PM	0
7/12/2014	5:30:00 PM	0
7/12/2014	5:45:00 PM	0
7/12/2014	6:00:00 PM	0
7/12/2014	6:15:00 PM	0
7/12/2014	6:30:00 PM	0
7/12/2014	6:45:00 PM	0
7/12/2014	7:00:00 PM	0
7/12/2014	7:15:00 PM	0
7/12/2014	7:30:00 PM	0
7/12/2014	7:45:00 PM	0
7/12/2014	8:00:00 PM	0
7/12/2014	8:15:00 PM	0
7/12/2014	8:30:00 PM	0
7/12/2014	8:45:00 PM	0
7/12/2014	9:00:00 PM	0
7/12/2014	9:15:00 PM	0
7/12/2014	9:30:00 PM	0
7/12/2014	9:45:00 PM	0
7/12/2014	10:00:00 PM	0
7/12/2014	10:15:00 PM	0
7/12/2014	10:30:00 PM	0
7/12/2014	10:45:00 PM	0
7/12/2014	11:00:00 PM	0
7/12/2014	11:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2014	11:30:00 PM	0
7/12/2014	11:45:00 PM	0
7/13/2014	12:00:00 AM	0
7/13/2014	12:15:00 AM	0
7/13/2014	12:30:00 AM	0
7/13/2014	12:45:00 AM	0
7/13/2014	1:00:00 AM	0
7/13/2014	1:15:00 AM	0
7/13/2014	1:30:00 AM	0
7/13/2014	1:45:00 AM	0
7/13/2014	2:00:00 AM	0
7/13/2014	2:15:00 AM	0
7/13/2014	2:30:00 AM	0
7/13/2014	2:45:00 AM	0
7/13/2014	3:00:00 AM	0
7/13/2014	3:15:00 AM	0
7/13/2014	3:30:00 AM	0
7/13/2014	3:45:00 AM	0
7/13/2014	4:00:00 AM	0
7/13/2014	4:15:00 AM	0
7/13/2014	4:30:00 AM	0
7/13/2014	4:45:00 AM	0
7/13/2014	5:00:00 AM	0
7/13/2014	5:15:00 AM	0
7/13/2014	5:30:00 AM	0
7/13/2014	5:45:00 AM	0
7/13/2014	6:00:00 AM	0
7/13/2014	6:15:00 AM	0
7/13/2014	6:30:00 AM	0
7/13/2014	6:45:00 AM	0
7/13/2014	7:00:00 AM	0
7/13/2014	7:15:00 AM	0
7/13/2014	7:30:00 AM	0
7/13/2014	7:45:00 AM	0
7/13/2014	8:00:00 AM	0
7/13/2014	8:15:00 AM	0
7/13/2014	8:30:00 AM	0
7/13/2014	8:45:00 AM	0
7/13/2014	9:00:00 AM	0
7/13/2014	9:15:00 AM	0
7/13/2014	9:30:00 AM	0
7/13/2014	9:45:00 AM	0
7/13/2014	10:00:00 AM	0
7/13/2014	10:15:00 AM	0
7/13/2014	10:30:00 AM	0
7/13/2014	10:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/13/2014	11:00:00 AM	0
7/13/2014	11:15:00 AM	0
7/13/2014	11:30:00 AM	0
7/13/2014	11:45:00 AM	0
7/13/2014	12:00:00 PM	0
7/13/2014	12:15:00 PM	0
7/13/2014	12:30:00 PM	0
7/13/2014	12:45:00 PM	0
7/13/2014	1:00:00 PM	0
7/13/2014	1:15:00 PM	0
7/13/2014	1:30:00 PM	0
7/13/2014	1:45:00 PM	0
7/13/2014	2:00:00 PM	0
7/13/2014	2:15:00 PM	0
7/13/2014	2:30:00 PM	0
7/13/2014	2:45:00 PM	0
7/13/2014	3:00:00 PM	0
7/13/2014	3:15:00 PM	0
7/13/2014	3:30:00 PM	0
7/13/2014	3:45:00 PM	0
7/13/2014	4:00:00 PM	0
7/13/2014	4:15:00 PM	0
7/13/2014	4:30:00 PM	0
7/13/2014	4:45:00 PM	0
7/13/2014	5:00:00 PM	0
7/13/2014	5:15:00 PM	0
7/13/2014	5:30:00 PM	0
7/13/2014	5:45:00 PM	0
7/13/2014	6:00:00 PM	0
7/13/2014	6:15:00 PM	0
7/13/2014	6:30:00 PM	0
7/13/2014	6:45:00 PM	0
7/13/2014	7:00:00 PM	0
7/13/2014	7:15:00 PM	0
7/13/2014	7:30:00 PM	0
7/13/2014	7:45:00 PM	0
7/13/2014	8:00:00 PM	0
7/13/2014	8:15:00 PM	0
7/13/2014	8:30:00 PM	0
7/13/2014	8:45:00 PM	0
7/13/2014	9:00:00 PM	0
7/13/2014	9:15:00 PM	0
7/13/2014	9:30:00 PM	0
7/13/2014	9:45:00 PM	0
7/13/2014	10:00:00 PM	0
7/13/2014	10:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/13/2014	10:30:00 PM	0
7/13/2014	10:45:00 PM	0
7/13/2014	11:00:00 PM	0
7/13/2014	11:15:00 PM	0
7/13/2014	11:30:00 PM	0
7/13/2014	11:45:00 PM	0
7/14/2014	12:00:00 AM	0
7/14/2014	12:15:00 AM	0
7/14/2014	12:30:00 AM	0
7/14/2014	12:45:00 AM	0
7/14/2014	1:00:00 AM	0
7/14/2014	1:15:00 AM	0
7/14/2014	1:30:00 AM	0.03
7/14/2014	1:45:00 AM	0.05
7/14/2014	2:00:00 AM	0.05
7/14/2014	2:15:00 AM	0.06
7/14/2014	2:30:00 AM	0.06
7/14/2014	2:45:00 AM	0.06
7/14/2014	3:00:00 AM	0.06
7/14/2014	3:15:00 AM	0.07
7/14/2014	3:30:00 AM	0.07
7/14/2014	3:45:00 AM	0.07
7/14/2014	4:00:00 AM	0.07
7/14/2014	4:15:00 AM	0.07
7/14/2014	4:30:00 AM	0.07
7/14/2014	4:45:00 AM	0.07
7/14/2014	5:00:00 AM	0.07
7/14/2014	5:15:00 AM	0.07
7/14/2014	5:30:00 AM	0.07
7/14/2014	5:45:00 AM	0.07
7/14/2014	6:00:00 AM	0.07
7/14/2014	6:15:00 AM	0.07
7/14/2014	6:30:00 AM	0.08
7/14/2014	6:45:00 AM	0.08
7/14/2014	7:00:00 AM	0.08
7/14/2014	7:15:00 AM	0.08
7/14/2014	7:30:00 AM	0.08
7/14/2014	7:45:00 AM	0.08
7/14/2014	8:00:00 AM	0.08
7/14/2014	8:15:00 AM	0.07
7/14/2014	8:30:00 AM	0.07
7/14/2014	8:45:00 AM	0.07
7/14/2014	9:00:00 AM	0.07
7/14/2014	9:15:00 AM	0.07
7/14/2014	9:30:00 AM	0.07
7/14/2014	9:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
7/14/2014	10:00:00 AM	0.06
7/14/2014	10:15:00 AM	0.06
7/14/2014	10:30:00 AM	0.06
7/14/2014	10:45:00 AM	0.06
7/14/2014	11:00:00 AM	0.06
7/14/2014	11:15:00 AM	0.06
7/14/2014	11:30:00 AM	0.06
7/14/2014	11:45:00 AM	0.06
7/14/2014	12:00:00 PM	0.06
7/14/2014	12:15:00 PM	0.05
7/14/2014	12:30:00 PM	0.05
7/14/2014	12:45:00 PM	0.05
7/14/2014	1:00:00 PM	0.05
7/14/2014	1:15:00 PM	0.05
7/14/2014	1:30:00 PM	0.05
7/14/2014	1:45:00 PM	0.04
7/14/2014	2:00:00 PM	0.04
7/14/2014	2:15:00 PM	0.04
7/14/2014	2:30:00 PM	0.04
7/14/2014	2:45:00 PM	0.04
7/14/2014	3:00:00 PM	0.04
7/14/2014	3:15:00 PM	0.04
7/14/2014	3:30:00 PM	0.04
7/14/2014	3:45:00 PM	0.04
7/14/2014	4:00:00 PM	0.04
7/14/2014	4:15:00 PM	0.04
7/14/2014	4:30:00 PM	0.04
7/14/2014	4:45:00 PM	0.04
7/14/2014	5:00:00 PM	0.04
7/14/2014	5:15:00 PM	0.04
7/14/2014	5:30:00 PM	0.04
7/14/2014	5:45:00 PM	0.04
7/14/2014	6:00:00 PM	0.04
7/14/2014	6:15:00 PM	0.04
7/14/2014	6:30:00 PM	0.04
7/14/2014	6:45:00 PM	0.04
7/14/2014	7:00:00 PM	0.04
7/14/2014	7:15:00 PM	0.04
7/14/2014	7:30:00 PM	0.04
7/14/2014	7:45:00 PM	0.04
7/14/2014	8:00:00 PM	0.04
7/14/2014	8:15:00 PM	0.04
7/14/2014	8:30:00 PM	0.04
7/14/2014	8:45:00 PM	0.04
7/14/2014	9:00:00 PM	0.04
7/14/2014	9:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
7/14/2014	9:30:00 PM	0.04
7/14/2014	9:45:00 PM	0.04
7/14/2014	10:00:00 PM	0.04
7/14/2014	10:15:00 PM	0.04
7/14/2014	10:30:00 PM	0.04
7/14/2014	10:45:00 PM	0.04
7/14/2014	11:00:00 PM	0.04
7/14/2014	11:15:00 PM	0.04
7/14/2014	11:30:00 PM	0.04
7/14/2014	11:45:00 PM	0.04
7/15/2014	12:00:00 AM	0.04
7/15/2014	12:15:00 AM	0.04
7/15/2014	12:30:00 AM	0.04
7/15/2014	12:45:00 AM	0.04
7/15/2014	1:00:00 AM	0.04
7/15/2014	1:15:00 AM	0.04
7/15/2014	1:30:00 AM	0.04
7/15/2014	1:45:00 AM	0.04
7/15/2014	2:00:00 AM	0.04
7/15/2014	2:15:00 AM	0.04
7/15/2014	2:30:00 AM	0.04
7/15/2014	2:45:00 AM	0.04
7/15/2014	3:00:00 AM	0.04
7/15/2014	3:15:00 AM	0.04
7/15/2014	3:30:00 AM	0.04
7/15/2014	3:45:00 AM	0.04
7/15/2014	4:00:00 AM	0.04
7/15/2014	4:15:00 AM	0.04
7/15/2014	4:30:00 AM	0.05
7/15/2014	4:45:00 AM	0.05
7/15/2014	5:00:00 AM	0.05
7/15/2014	5:15:00 AM	0.05
7/15/2014	5:30:00 AM	0.05
7/15/2014	5:45:00 AM	0.05
7/15/2014	6:00:00 AM	0.05
7/15/2014	6:15:00 AM	0.05
7/15/2014	6:30:00 AM	0.05
7/15/2014	6:45:00 AM	0.05
7/15/2014	7:00:00 AM	0.05
7/15/2014	7:15:00 AM	0.05
7/15/2014	7:30:00 AM	0.05
7/15/2014	7:45:00 AM	0.05
7/15/2014	8:00:00 AM	0.05
7/15/2014	8:15:00 AM	0.05
7/15/2014	8:30:00 AM	0.05
7/15/2014	8:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
7/15/2014	9:00:00 AM	0.05
7/15/2014	9:15:00 AM	0.05
7/15/2014	9:30:00 AM	0.05
7/15/2014	9:45:00 AM	0.05
7/15/2014	10:00:00 AM	0.05
7/15/2014	10:15:00 AM	0.05
7/15/2014	10:30:00 AM	0.05
7/15/2014	10:45:00 AM	0.05
7/15/2014	11:00:00 AM	0.05
7/15/2014	11:15:00 AM	0.05
7/15/2014	11:30:00 AM	0.05
7/15/2014	11:45:00 AM	0.05
7/15/2014	12:00:00 PM	0.05
7/15/2014	12:15:00 PM	0.05
7/15/2014	12:30:00 PM	0.05
7/15/2014	12:45:00 PM	0.05
7/15/2014	1:00:00 PM	0.05
7/15/2014	1:15:00 PM	0.05
7/15/2014	1:30:00 PM	0.04
7/15/2014	1:45:00 PM	0.04
7/15/2014	2:00:00 PM	0.04
7/15/2014	2:15:00 PM	0.04
7/15/2014	2:30:00 PM	0.04
7/15/2014	2:45:00 PM	0.04
7/15/2014	3:00:00 PM	0.04
7/15/2014	3:15:00 PM	0.04
7/15/2014	3:30:00 PM	0.04
7/15/2014	3:45:00 PM	0.04
7/15/2014	4:00:00 PM	0.04
7/15/2014	4:15:00 PM	0.04
7/15/2014	4:30:00 PM	0.04
7/15/2014	4:45:00 PM	0.04
7/15/2014	5:00:00 PM	0.04
7/15/2014	5:15:00 PM	0.04
7/15/2014	5:30:00 PM	0.04
7/15/2014	5:45:00 PM	0.04
7/15/2014	6:00:00 PM	0.04
7/15/2014	6:15:00 PM	0.04
7/15/2014	6:30:00 PM	0.04
7/15/2014	6:45:00 PM	0.04
7/15/2014	7:00:00 PM	0.04
7/15/2014	7:15:00 PM	0.04
7/15/2014	7:30:00 PM	0.04
7/15/2014	7:45:00 PM	0.04
7/15/2014	8:00:00 PM	0.04
7/15/2014	8:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
7/15/2014	8:30:00 PM	0.04
7/15/2014	8:45:00 PM	0.04
7/15/2014	9:00:00 PM	0.03
7/15/2014	9:15:00 PM	0.04
7/15/2014	9:30:00 PM	0.04
7/15/2014	9:45:00 PM	0.03
7/15/2014	10:00:00 PM	0.04
7/15/2014	10:15:00 PM	0.03
7/15/2014	10:30:00 PM	0.03
7/15/2014	10:45:00 PM	0.03
7/15/2014	11:00:00 PM	0.03
7/15/2014	11:15:00 PM	0.03
7/15/2014	11:30:00 PM	0.03
7/15/2014	11:45:00 PM	0.03
7/16/2014	12:00:00 AM	0.03
7/16/2014	12:15:00 AM	0.03
7/16/2014	12:30:00 AM	0.03
7/16/2014	12:45:00 AM	0.03
7/16/2014	1:00:00 AM	0.03
7/16/2014	1:15:00 AM	0.03
7/16/2014	1:30:00 AM	0.03
7/16/2014	1:45:00 AM	0.03
7/16/2014	2:00:00 AM	0.03
7/16/2014	2:15:00 AM	0.03
7/16/2014	2:30:00 AM	0.03
7/16/2014	2:45:00 AM	0.03
7/16/2014	3:00:00 AM	0.03
7/16/2014	3:15:00 AM	0.03
7/16/2014	3:30:00 AM	0.03
7/16/2014	3:45:00 AM	0.03
7/16/2014	4:00:00 AM	0.03
7/16/2014	4:15:00 AM	0.03
7/16/2014	4:30:00 AM	0.03
7/16/2014	4:45:00 AM	0.04
7/16/2014	5:00:00 AM	0.04
7/16/2014	5:15:00 AM	0.04
7/16/2014	5:30:00 AM	0.04
7/16/2014	5:45:00 AM	0.04
7/16/2014	6:00:00 AM	0.04
7/16/2014	6:15:00 AM	0.04
7/16/2014	6:30:00 AM	0.04
7/16/2014	6:45:00 AM	0.04
7/16/2014	7:00:00 AM	0.04
7/16/2014	7:15:00 AM	0.04
7/16/2014	7:30:00 AM	0.04
7/16/2014	7:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
7/16/2014	8:00:00 AM	0.04
7/16/2014	8:15:00 AM	0.04
7/16/2014	8:30:00 AM	0.04
7/16/2014	8:45:00 AM	0.04
7/16/2014	9:00:00 AM	0.04
7/16/2014	9:15:00 AM	0.04
7/16/2014	9:30:00 AM	0.04
7/16/2014	9:45:00 AM	0.03
7/16/2014	10:00:00 AM	0.03
7/16/2014	10:15:00 AM	0.03
7/16/2014	10:30:00 AM	0.03
7/16/2014	10:45:00 AM	0.03
7/16/2014	11:00:00 AM	0.03
7/16/2014	11:15:00 AM	0.03
7/16/2014	11:30:00 AM	0.03
7/16/2014	11:45:00 AM	0.03
7/16/2014	12:00:00 PM	0.03
7/16/2014	12:15:00 PM	0.03
7/16/2014	12:30:00 PM	0.02
7/16/2014	12:45:00 PM	0.02
7/16/2014	1:00:00 PM	0.02
7/16/2014	1:15:00 PM	0.02
7/16/2014	1:30:00 PM	0.02
7/16/2014	1:45:00 PM	0.02
7/16/2014	2:00:00 PM	0.02
7/16/2014	2:15:00 PM	0.02
7/16/2014	2:30:00 PM	0.02
7/16/2014	2:45:00 PM	0.02
7/16/2014	3:00:00 PM	0.02
7/16/2014	3:15:00 PM	0.02
7/16/2014	3:30:00 PM	0.01
7/16/2014	3:45:00 PM	0.01
7/16/2014	4:00:00 PM	0.01
7/16/2014	4:15:00 PM	0.01
7/16/2014	4:30:00 PM	0.01
7/16/2014	4:45:00 PM	0.01
7/16/2014	5:00:00 PM	0.01
7/16/2014	5:15:00 PM	0.01
7/16/2014	5:30:00 PM	0.01
7/16/2014	5:45:00 PM	0.01
7/16/2014	6:00:00 PM	0.01
7/16/2014	6:15:00 PM	0.01
7/16/2014	6:30:00 PM	0.01
7/16/2014	6:45:00 PM	0.01
7/16/2014	7:00:00 PM	0.01
7/16/2014	7:15:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/16/2014	7:30:00 PM	0.01
7/16/2014	7:45:00 PM	0.01
7/16/2014	8:00:00 PM	0.01
7/16/2014	8:15:00 PM	0.01
7/16/2014	8:30:00 PM	0.01
7/16/2014	8:45:00 PM	0.01
7/16/2014	9:00:00 PM	0.01
7/16/2014	9:15:00 PM	0.01
7/16/2014	9:30:00 PM	0.01
7/16/2014	9:45:00 PM	0.01
7/16/2014	10:00:00 PM	0.01
7/16/2014	10:15:00 PM	0.01
7/16/2014	10:30:00 PM	0.01
7/16/2014	10:45:00 PM	0.01
7/16/2014	11:00:00 PM	0.01
7/16/2014	11:15:00 PM	0.01
7/16/2014	11:30:00 PM	0.01
7/16/2014	11:45:00 PM	0.01
7/17/2014	12:00:00 AM	0.01
7/17/2014	12:15:00 AM	0.01
7/17/2014	12:30:00 AM	0.01
7/17/2014	12:45:00 AM	0.01
7/17/2014	1:00:00 AM	0.01
7/17/2014	1:15:00 AM	0.01
7/17/2014	1:30:00 AM	0.01
7/17/2014	1:45:00 AM	0.01
7/17/2014	2:00:00 AM	0.01
7/17/2014	2:15:00 AM	0.01
7/17/2014	2:30:00 AM	0.01
7/17/2014	2:45:00 AM	0.01
7/17/2014	3:00:00 AM	0.01
7/17/2014	3:15:00 AM	0.02
7/17/2014	3:30:00 AM	0.02
7/17/2014	3:45:00 AM	0.02
7/17/2014	4:00:00 AM	0.02
7/17/2014	4:15:00 AM	0.02
7/17/2014	4:30:00 AM	0.02
7/17/2014	4:45:00 AM	0.02
7/17/2014	5:00:00 AM	0.02
7/17/2014	5:15:00 AM	0.02
7/17/2014	5:30:00 AM	0.02
7/17/2014	5:45:00 AM	0.02
7/17/2014	6:00:00 AM	0.02
7/17/2014	6:15:00 AM	0.02
7/17/2014	6:30:00 AM	0.02
7/17/2014	6:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/17/2014	7:00:00 AM	0.02
7/17/2014	7:15:00 AM	0.02
7/17/2014	7:30:00 AM	0.02
7/17/2014	7:45:00 AM	0.02
7/17/2014	8:00:00 AM	0.02
7/17/2014	8:15:00 AM	0.02
7/17/2014	8:30:00 AM	0.02
7/17/2014	8:45:00 AM	0.01
7/17/2014	9:00:00 AM	0.01
7/17/2014	9:15:00 AM	0.01
7/17/2014	9:30:00 AM	0.01
7/17/2014	9:45:00 AM	0.01
7/17/2014	10:00:00 AM	0.01
7/17/2014	10:15:00 AM	0.01
7/17/2014	10:30:00 AM	0.01
7/17/2014	10:45:00 AM	0.01
7/17/2014	11:00:00 AM	0.01
7/17/2014	11:15:00 AM	0.01
7/17/2014	11:30:00 AM	0.01
7/17/2014	11:45:00 AM	0.01
7/17/2014	12:00:00 PM	0.01
7/17/2014	12:15:00 PM	0.01
7/17/2014	12:30:00 PM	0.01
7/17/2014	12:45:00 PM	0.01
7/17/2014	1:00:00 PM	0.01
7/17/2014	1:15:00 PM	0
7/17/2014	1:30:00 PM	0
7/17/2014	1:45:00 PM	0.01
7/17/2014	2:00:00 PM	0.01
7/17/2014	2:15:00 PM	0.01
7/17/2014	2:30:00 PM	0.01
7/17/2014	2:45:00 PM	0.01
7/17/2014	3:00:00 PM	0.01
7/17/2014	3:15:00 PM	0
7/17/2014	3:30:00 PM	0
7/17/2014	3:45:00 PM	0
7/17/2014	4:00:00 PM	0
7/17/2014	4:15:00 PM	0
7/17/2014	4:30:00 PM	0
7/17/2014	4:45:00 PM	0
7/17/2014	5:00:00 PM	0
7/17/2014	5:15:00 PM	0
7/17/2014	5:30:00 PM	0
7/17/2014	5:45:00 PM	0
7/17/2014	6:00:00 PM	0
7/17/2014	6:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/17/2014	6:30:00 PM	0
7/17/2014	6:45:00 PM	0
7/17/2014	7:00:00 PM	0
7/17/2014	7:15:00 PM	0
7/17/2014	7:30:00 PM	0
7/17/2014	7:45:00 PM	0
7/17/2014	8:00:00 PM	0
7/17/2014	8:15:00 PM	0
7/17/2014	8:30:00 PM	0
7/17/2014	8:45:00 PM	0
7/17/2014	9:00:00 PM	0
7/17/2014	9:15:00 PM	0
7/17/2014	9:30:00 PM	0
7/17/2014	9:45:00 PM	0
7/17/2014	10:00:00 PM	0
7/17/2014	10:15:00 PM	0
7/17/2014	10:30:00 PM	0
7/17/2014	10:45:00 PM	0
7/17/2014	11:00:00 PM	0
7/17/2014	11:15:00 PM	0
7/17/2014	11:30:00 PM	0
7/17/2014	11:45:00 PM	0
7/18/2014	12:00:00 AM	0
7/18/2014	12:15:00 AM	0
7/18/2014	12:30:00 AM	0
7/18/2014	12:45:00 AM	0
7/18/2014	1:00:00 AM	0
7/18/2014	1:15:00 AM	0
7/18/2014	1:30:00 AM	0
7/18/2014	1:45:00 AM	0
7/18/2014	2:00:00 AM	0
7/18/2014	2:15:00 AM	0
7/18/2014	2:30:00 AM	0
7/18/2014	2:45:00 AM	0
7/18/2014	3:00:00 AM	0
7/18/2014	3:15:00 AM	0
7/18/2014	3:30:00 AM	0.01
7/18/2014	3:45:00 AM	0.01
7/18/2014	4:00:00 AM	0.01
7/18/2014	4:15:00 AM	0.01
7/18/2014	4:30:00 AM	0.01
7/18/2014	4:45:00 AM	0.01
7/18/2014	5:00:00 AM	0.02
7/18/2014	5:15:00 AM	0.02
7/18/2014	5:30:00 AM	0.02
7/18/2014	5:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/18/2014	6:00:00 AM	0.02
7/18/2014	6:15:00 AM	0.02
7/18/2014	6:30:00 AM	0.02
7/18/2014	6:45:00 AM	0.02
7/18/2014	7:00:00 AM	0.02
7/18/2014	7:15:00 AM	0.02
7/18/2014	7:30:00 AM	0.02
7/18/2014	7:45:00 AM	0.02
7/18/2014	8:00:00 AM	0.02
7/18/2014	8:15:00 AM	0.02
7/18/2014	8:30:00 AM	0.02
7/18/2014	8:45:00 AM	0.02
7/18/2014	9:00:00 AM	0.02
7/18/2014	9:15:00 AM	0.02
7/18/2014	9:30:00 AM	0.02
7/18/2014	9:45:00 AM	0.02
7/18/2014	10:00:00 AM	0.01
7/18/2014	10:15:00 AM	0.01
7/18/2014	10:30:00 AM	0.01
7/18/2014	10:45:00 AM	0.01
7/18/2014	11:00:00 AM	0.01
7/18/2014	11:15:00 AM	0.01
7/18/2014	11:30:00 AM	0.01
7/18/2014	11:45:00 AM	0.01
7/18/2014	12:00:00 PM	0.01
7/18/2014	12:15:00 PM	0.01
7/18/2014	12:30:00 PM	0.01
7/18/2014	12:45:00 PM	0.01
7/18/2014	1:00:00 PM	0.01
7/18/2014	1:15:00 PM	0
7/18/2014	1:30:00 PM	0
7/18/2014	1:45:00 PM	0
7/18/2014	2:00:00 PM	0
7/18/2014	2:15:00 PM	0
7/18/2014	2:30:00 PM	0
7/18/2014	2:45:00 PM	0
7/18/2014	3:00:00 PM	0
7/18/2014	3:15:00 PM	0
7/18/2014	3:30:00 PM	0
7/18/2014	3:45:00 PM	0
7/18/2014	4:00:00 PM	0
7/18/2014	4:15:00 PM	0
7/18/2014	4:30:00 PM	0
7/18/2014	4:45:00 PM	0
7/18/2014	5:00:00 PM	0
7/18/2014	5:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/18/2014	5:30:00 PM	0
7/18/2014	5:45:00 PM	0
7/18/2014	6:00:00 PM	0
7/18/2014	6:15:00 PM	0
7/18/2014	6:30:00 PM	0
7/18/2014	6:45:00 PM	0
7/18/2014	7:00:00 PM	0
7/18/2014	7:15:00 PM	0
7/18/2014	7:30:00 PM	0
7/18/2014	7:45:00 PM	0
7/18/2014	8:00:00 PM	0
7/18/2014	8:15:00 PM	0
7/18/2014	8:30:00 PM	0
7/18/2014	8:45:00 PM	0
7/18/2014	9:00:00 PM	0
7/18/2014	9:15:00 PM	0
7/18/2014	9:30:00 PM	0
7/18/2014	9:45:00 PM	0
7/18/2014	10:00:00 PM	0
7/18/2014	10:15:00 PM	0
7/18/2014	10:30:00 PM	0
7/18/2014	10:45:00 PM	0
7/18/2014	11:00:00 PM	0
7/18/2014	11:15:00 PM	0
7/18/2014	11:30:00 PM	0
7/18/2014	11:45:00 PM	0
7/19/2014	12:00:00 AM	0
7/19/2014	12:15:00 AM	0
7/19/2014	12:30:00 AM	0
7/19/2014	12:45:00 AM	0
7/19/2014	1:00:00 AM	0
7/19/2014	1:15:00 AM	0
7/19/2014	1:30:00 AM	0
7/19/2014	1:45:00 AM	0
7/19/2014	2:00:00 AM	0
7/19/2014	2:15:00 AM	0
7/19/2014	2:30:00 AM	0
7/19/2014	2:45:00 AM	0
7/19/2014	3:00:00 AM	0
7/19/2014	3:15:00 AM	0
7/19/2014	3:30:00 AM	0
7/19/2014	3:45:00 AM	0
7/19/2014	4:00:00 AM	0
7/19/2014	4:15:00 AM	0
7/19/2014	4:30:00 AM	0
7/19/2014	4:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/19/2014	5:00:00 AM	0
7/19/2014	5:15:00 AM	0
7/19/2014	5:30:00 AM	0
7/19/2014	5:45:00 AM	0
7/19/2014	6:00:00 AM	0
7/19/2014	6:15:00 AM	0
7/19/2014	6:30:00 AM	0
7/19/2014	6:45:00 AM	0
7/19/2014	7:00:00 AM	0
7/19/2014	7:15:00 AM	0
7/19/2014	7:30:00 AM	0
7/19/2014	7:45:00 AM	0
7/19/2014	8:00:00 AM	0
7/19/2014	8:15:00 AM	0
7/19/2014	8:30:00 AM	0
7/19/2014	8:45:00 AM	0
7/19/2014	9:00:00 AM	0
7/19/2014	9:15:00 AM	0
7/19/2014	9:30:00 AM	0
7/19/2014	9:45:00 AM	0
7/19/2014	10:00:00 AM	0
7/19/2014	10:15:00 AM	0
7/19/2014	10:30:00 AM	0
7/19/2014	10:45:00 AM	0
7/19/2014	11:00:00 AM	0
7/19/2014	11:15:00 AM	0
7/19/2014	11:30:00 AM	0
7/19/2014	11:45:00 AM	0
7/19/2014	12:00:00 PM	0
7/19/2014	12:15:00 PM	0
7/19/2014	12:30:00 PM	0
7/19/2014	12:45:00 PM	0
7/19/2014	1:00:00 PM	0
7/19/2014	1:15:00 PM	0
7/19/2014	1:30:00 PM	0
7/19/2014	1:45:00 PM	0
7/19/2014	2:00:00 PM	0
7/19/2014	2:15:00 PM	0
7/19/2014	2:30:00 PM	0
7/19/2014	2:45:00 PM	0
7/19/2014	3:00:00 PM	0
7/19/2014	3:15:00 PM	0
7/19/2014	3:30:00 PM	0
7/19/2014	3:45:00 PM	0
7/19/2014	4:00:00 PM	0
7/19/2014	4:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/19/2014	4:30:00 PM	0
7/19/2014	4:45:00 PM	0
7/19/2014	5:00:00 PM	0
7/19/2014	5:15:00 PM	0
7/19/2014	5:30:00 PM	0
7/19/2014	5:45:00 PM	0
7/19/2014	6:00:00 PM	0
7/19/2014	6:15:00 PM	0
7/19/2014	6:30:00 PM	0
7/19/2014	6:45:00 PM	0
7/19/2014	7:00:00 PM	0
7/19/2014	7:15:00 PM	0
7/19/2014	7:30:00 PM	0
7/19/2014	7:45:00 PM	0
7/19/2014	8:00:00 PM	0
7/19/2014	8:15:00 PM	0
7/19/2014	8:30:00 PM	0
7/19/2014	8:45:00 PM	0
7/19/2014	9:00:00 PM	0
7/19/2014	9:15:00 PM	0
7/19/2014	9:30:00 PM	0
7/19/2014	9:45:00 PM	0
7/19/2014	10:00:00 PM	0
7/19/2014	10:15:00 PM	0
7/19/2014	10:30:00 PM	0
7/19/2014	10:45:00 PM	0
7/19/2014	11:00:00 PM	0
7/19/2014	11:15:00 PM	0
7/19/2014	11:30:00 PM	0
7/19/2014	11:45:00 PM	0
7/20/2014	12:00:00 AM	0
7/20/2014	12:15:00 AM	0
7/20/2014	12:30:00 AM	0
7/20/2014	12:45:00 AM	0
7/20/2014	1:00:00 AM	0
7/20/2014	1:15:00 AM	0
7/20/2014	1:30:00 AM	0
7/20/2014	1:45:00 AM	0
7/20/2014	2:00:00 AM	0
7/20/2014	2:15:00 AM	0
7/20/2014	2:30:00 AM	0
7/20/2014	2:45:00 AM	0
7/20/2014	3:00:00 AM	0
7/20/2014	3:15:00 AM	0
7/20/2014	3:30:00 AM	0
7/20/2014	3:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/20/2014	4:00:00 AM	0
7/20/2014	4:15:00 AM	0
7/20/2014	4:30:00 AM	0
7/20/2014	4:45:00 AM	0
7/20/2014	5:00:00 AM	0
7/20/2014	5:15:00 AM	0
7/20/2014	5:30:00 AM	0
7/20/2014	5:45:00 AM	0
7/20/2014	6:00:00 AM	0
7/20/2014	6:15:00 AM	0
7/20/2014	6:30:00 AM	0
7/20/2014	6:45:00 AM	0
7/20/2014	7:00:00 AM	0
7/20/2014	7:15:00 AM	0
7/20/2014	7:30:00 AM	0
7/20/2014	7:45:00 AM	0
7/20/2014	8:00:00 AM	0
7/20/2014	8:15:00 AM	0
7/20/2014	8:30:00 AM	0
7/20/2014	8:45:00 AM	0
7/20/2014	9:00:00 AM	0
7/20/2014	9:15:00 AM	0
7/20/2014	9:30:00 AM	0
7/20/2014	9:45:00 AM	0
7/20/2014	10:00:00 AM	0
7/20/2014	10:15:00 AM	0
7/20/2014	10:30:00 AM	0
7/20/2014	10:45:00 AM	0
7/20/2014	11:00:00 AM	0
7/20/2014	11:15:00 AM	0
7/20/2014	11:30:00 AM	0
7/20/2014	11:45:00 AM	0
7/20/2014	12:00:00 PM	0
7/20/2014	12:15:00 PM	0
7/20/2014	12:30:00 PM	0
7/20/2014	12:45:00 PM	0
7/20/2014	1:00:00 PM	0
7/20/2014	1:15:00 PM	0
7/20/2014	1:30:00 PM	0
7/20/2014	1:45:00 PM	0
7/20/2014	2:00:00 PM	0
7/20/2014	2:15:00 PM	0
7/20/2014	2:30:00 PM	0
7/20/2014	2:45:00 PM	0
7/20/2014	3:00:00 PM	0
7/20/2014	3:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/20/2014	3:30:00 PM	0
7/20/2014	3:45:00 PM	0
7/20/2014	4:00:00 PM	0
7/20/2014	4:15:00 PM	0
7/20/2014	4:30:00 PM	0
7/20/2014	4:45:00 PM	0
7/20/2014	5:00:00 PM	0
7/20/2014	5:15:00 PM	0
7/20/2014	5:30:00 PM	0
7/20/2014	5:45:00 PM	0
7/20/2014	6:00:00 PM	0
7/20/2014	6:15:00 PM	0
7/20/2014	6:30:00 PM	0
7/20/2014	6:45:00 PM	0
7/20/2014	7:00:00 PM	0
7/20/2014	7:15:00 PM	0
7/20/2014	7:30:00 PM	0
7/20/2014	7:45:00 PM	0
7/20/2014	8:00:00 PM	0
7/20/2014	8:15:00 PM	0
7/20/2014	8:30:00 PM	0
7/20/2014	8:45:00 PM	0
7/20/2014	9:00:00 PM	0
7/20/2014	9:15:00 PM	0
7/20/2014	9:30:00 PM	0
7/20/2014	9:45:00 PM	0
7/20/2014	10:00:00 PM	0
7/20/2014	10:15:00 PM	0
7/20/2014	10:30:00 PM	0
7/20/2014	10:45:00 PM	0
7/20/2014	11:00:00 PM	0
7/20/2014	11:15:00 PM	0
7/20/2014	11:30:00 PM	0
7/20/2014	11:45:00 PM	0
7/21/2014	12:00:00 AM	0
7/21/2014	12:15:00 AM	0
7/21/2014	12:30:00 AM	0
7/21/2014	12:45:00 AM	0
7/21/2014	1:00:00 AM	0
7/21/2014	1:15:00 AM	0
7/21/2014	1:30:00 AM	0
7/21/2014	1:45:00 AM	0
7/21/2014	2:00:00 AM	0
7/21/2014	2:15:00 AM	0
7/21/2014	2:30:00 AM	0
7/21/2014	2:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/21/2014	3:00:00 AM	0
7/21/2014	3:15:00 AM	0
7/21/2014	3:30:00 AM	0
7/21/2014	3:45:00 AM	0
7/21/2014	4:00:00 AM	0
7/21/2014	4:15:00 AM	0
7/21/2014	4:30:00 AM	0
7/21/2014	4:45:00 AM	0
7/21/2014	5:00:00 AM	0
7/21/2014	5:15:00 AM	0
7/21/2014	5:30:00 AM	0
7/21/2014	5:45:00 AM	0
7/21/2014	6:00:00 AM	0
7/21/2014	6:15:00 AM	0
7/21/2014	6:30:00 AM	0
7/21/2014	6:45:00 AM	0
7/21/2014	7:00:00 AM	0
7/21/2014	7:15:00 AM	0
7/21/2014	7:30:00 AM	0
7/21/2014	7:45:00 AM	0
7/21/2014	8:00:00 AM	0
7/21/2014	8:15:00 AM	0
7/21/2014	8:30:00 AM	0
7/21/2014	8:45:00 AM	0
7/21/2014	9:00:00 AM	0
7/21/2014	9:15:00 AM	0
7/21/2014	9:30:00 AM	0
7/21/2014	9:45:00 AM	0
7/21/2014	10:00:00 AM	0
7/21/2014	10:15:00 AM	0
7/21/2014	10:30:00 AM	0
7/21/2014	10:45:00 AM	0
7/21/2014	11:00:00 AM	0
7/21/2014	11:15:00 AM	0
7/21/2014	11:30:00 AM	0
7/21/2014	11:45:00 AM	0
7/21/2014	12:00:00 PM	0
7/21/2014	12:15:00 PM	0
7/21/2014	12:30:00 PM	0
7/21/2014	12:45:00 PM	0
7/21/2014	1:00:00 PM	0
7/21/2014	1:15:00 PM	0
7/21/2014	1:30:00 PM	0
7/21/2014	1:45:00 PM	0
7/21/2014	2:00:00 PM	0
7/21/2014	2:15:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/21/2014	2:30:00 PM	0
7/21/2014	2:45:00 PM	0
7/21/2014	3:00:00 PM	0
7/21/2014	3:15:00 PM	0
7/21/2014	3:30:00 PM	0
7/21/2014	3:45:00 PM	0
7/21/2014	4:00:00 PM	0
7/21/2014	4:15:00 PM	0
7/21/2014	4:30:00 PM	0
7/21/2014	4:45:00 PM	0
7/21/2014	5:00:00 PM	0
7/21/2014	5:15:00 PM	0
7/21/2014	5:30:00 PM	0
7/21/2014	5:45:00 PM	0
7/21/2014	6:00:00 PM	0
7/21/2014	6:15:00 PM	0
7/21/2014	6:30:00 PM	0
7/21/2014	6:45:00 PM	0
7/21/2014	7:00:00 PM	0
7/21/2014	7:15:00 PM	0
7/21/2014	7:30:00 PM	0
7/21/2014	7:45:00 PM	0
7/21/2014	8:00:00 PM	0
7/21/2014	8:15:00 PM	0
7/21/2014	8:30:00 PM	0
7/21/2014	8:45:00 PM	0
7/21/2014	9:00:00 PM	0
7/21/2014	9:15:00 PM	0
7/21/2014	9:30:00 PM	0
7/21/2014	9:45:00 PM	0
7/21/2014	10:00:00 PM	0
7/21/2014	10:15:00 PM	0
7/21/2014	10:30:00 PM	0
7/21/2014	10:45:00 PM	0
7/21/2014	11:00:00 PM	0
7/21/2014	11:15:00 PM	0
7/21/2014	11:30:00 PM	0
7/21/2014	11:45:00 PM	0
7/22/2014	12:00:00 AM	0
7/22/2014	12:15:00 AM	0
7/22/2014	12:30:00 AM	0
7/22/2014	12:45:00 AM	0
7/22/2014	1:00:00 AM	0
7/22/2014	1:15:00 AM	0
7/22/2014	1:30:00 AM	0
7/22/2014	1:45:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/22/2014	2:00:00 AM	0
7/22/2014	2:15:00 AM	0
7/22/2014	2:30:00 AM	0.02
7/22/2014	2:45:00 AM	0.04
7/22/2014	3:00:00 AM	0.04
7/22/2014	3:15:00 AM	0.04
7/22/2014	3:30:00 AM	0.04
7/22/2014	3:45:00 AM	0.04
7/22/2014	4:00:00 AM	0.04
7/22/2014	4:15:00 AM	0.04
7/22/2014	4:30:00 AM	0.04
7/22/2014	4:45:00 AM	0.05
7/22/2014	5:00:00 AM	0.05
7/22/2014	5:15:00 AM	0.05
7/22/2014	5:30:00 AM	0.05
7/22/2014	5:45:00 AM	0.05
7/22/2014	6:00:00 AM	0.05
7/22/2014	6:15:00 AM	0.05
7/22/2014	6:30:00 AM	0.05
7/22/2014	6:45:00 AM	0.05
7/22/2014	7:00:00 AM	0.05
7/22/2014	7:15:00 AM	0.05
7/22/2014	7:30:00 AM	0.05
7/22/2014	7:45:00 AM	0.05
7/22/2014	8:00:00 AM	0.05
7/22/2014	8:15:00 AM	0.05
7/22/2014	8:30:00 AM	0.05
7/22/2014	8:45:00 AM	0.05
7/22/2014	9:00:00 AM	0.05
7/22/2014	9:15:00 AM	0.05
7/22/2014	9:30:00 AM	0.05
7/22/2014	9:45:00 AM	0.05
7/22/2014	10:00:00 AM	0.05
7/22/2014	10:15:00 AM	0.05
7/22/2014	10:30:00 AM	0.05
7/22/2014	10:45:00 AM	0.05
7/22/2014	11:00:00 AM	0.04
7/22/2014	11:15:00 AM	0.04
7/22/2014	11:30:00 AM	0.04
7/22/2014	11:45:00 AM	0.04
7/22/2014	12:00:00 PM	0.04
7/22/2014	12:15:00 PM	0.04
7/22/2014	12:30:00 PM	0.04
7/22/2014	12:45:00 PM	0.04
7/22/2014	1:00:00 PM	0.04
7/22/2014	1:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
7/22/2014	1:30:00 PM	0.04
7/22/2014	1:45:00 PM	0.04
7/22/2014	2:00:00 PM	0.04
7/22/2014	2:15:00 PM	0.04
7/22/2014	2:30:00 PM	0.04
7/22/2014	2:45:00 PM	0.04
7/22/2014	3:00:00 PM	0.03
7/22/2014	3:15:00 PM	0.03
7/22/2014	3:30:00 PM	0.03
7/22/2014	3:45:00 PM	0.03
7/22/2014	4:00:00 PM	0.03
7/22/2014	4:15:00 PM	0.03
7/22/2014	4:30:00 PM	0.03
7/22/2014	4:45:00 PM	0.03
7/22/2014	5:00:00 PM	0.03
7/22/2014	5:15:00 PM	0.02
7/22/2014	5:30:00 PM	0.03
7/22/2014	5:45:00 PM	0.02
7/22/2014	6:00:00 PM	0.02
7/22/2014	6:15:00 PM	0.02
7/22/2014	6:30:00 PM	0.02
7/22/2014	6:45:00 PM	0.02
7/22/2014	7:00:00 PM	0.02
7/22/2014	7:15:00 PM	0.02
7/22/2014	7:30:00 PM	0.02
7/22/2014	7:45:00 PM	0.02
7/22/2014	8:00:00 PM	0.02
7/22/2014	8:15:00 PM	0.02
7/22/2014	8:30:00 PM	0.02
7/22/2014	8:45:00 PM	0.02
7/22/2014	9:00:00 PM	0.02
7/22/2014	9:15:00 PM	0.02
7/22/2014	9:30:00 PM	0.02
7/22/2014	9:45:00 PM	0.02
7/22/2014	10:00:00 PM	0.02
7/22/2014	10:15:00 PM	0.02
7/22/2014	10:30:00 PM	0.02
7/22/2014	10:45:00 PM	0.02
7/22/2014	11:00:00 PM	0.02
7/22/2014	11:15:00 PM	0.02
7/22/2014	11:30:00 PM	0.02
7/22/2014	11:45:00 PM	0.02
7/23/2014	12:00:00 AM	0.02
7/23/2014	12:15:00 AM	0.02
7/23/2014	12:30:00 AM	0.02
7/23/2014	12:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
7/23/2014	1:00:00 AM	0.02
7/23/2014	1:15:00 AM	0.02
7/23/2014	1:30:00 AM	0.02
7/23/2014	1:45:00 AM	0.02
7/23/2014	2:00:00 AM	0.02
7/23/2014	2:15:00 AM	0.02
7/23/2014	2:30:00 AM	0.02
7/23/2014	2:45:00 AM	0.02
7/23/2014	3:00:00 AM	0.02
7/23/2014	3:15:00 AM	0.02
7/23/2014	3:30:00 AM	0.02
7/23/2014	3:45:00 AM	0.02
7/23/2014	4:00:00 AM	0.02
7/23/2014	4:15:00 AM	0.02
7/23/2014	4:30:00 AM	0.03
7/23/2014	4:45:00 AM	0.03
7/23/2014	5:00:00 AM	0.03
7/23/2014	5:15:00 AM	0.03
7/23/2014	5:30:00 AM	0.03
7/23/2014	5:45:00 AM	0.03
7/23/2014	6:00:00 AM	0.03
7/23/2014	6:15:00 AM	0.03
7/23/2014	6:30:00 AM	0.03
7/23/2014	6:45:00 AM	0.03
7/23/2014	7:00:00 AM	0.03
7/23/2014	7:15:00 AM	0.03
7/23/2014	7:30:00 AM	0.03
7/23/2014	7:45:00 AM	0.03
7/23/2014	8:00:00 AM	0.03
7/23/2014	8:15:00 AM	0.03
7/23/2014	8:30:00 AM	0.03
7/23/2014	8:45:00 AM	0.03
7/23/2014	9:00:00 AM	0.03
7/23/2014	9:15:00 AM	0.03
7/23/2014	9:30:00 AM	0.03
7/23/2014	9:45:00 AM	0.03
7/23/2014	10:00:00 AM	0.03
7/23/2014	10:15:00 AM	0.03
7/23/2014	10:30:00 AM	0.03
7/23/2014	10:45:00 AM	0.03
7/23/2014	11:00:00 AM	0.03
7/23/2014	11:15:00 AM	0.03
7/23/2014	11:30:00 AM	0.03
7/23/2014	11:45:00 AM	0.03
7/23/2014	12:00:00 PM	0.03
7/23/2014	12:15:00 PM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
7/23/2014	12:30:00 PM	0.03
7/23/2014	12:45:00 PM	0.03
7/23/2014	1:00:00 PM	0.03
7/23/2014	1:15:00 PM	0.03
7/23/2014	1:30:00 PM	0.02
7/23/2014	1:45:00 PM	0.02
7/23/2014	2:00:00 PM	0.02
7/23/2014	2:15:00 PM	0.02
7/23/2014	2:30:00 PM	0.02
7/23/2014	2:45:00 PM	0.02
7/23/2014	3:00:00 PM	0.02
7/23/2014	3:15:00 PM	0.02
7/23/2014	3:30:00 PM	0.02
7/23/2014	3:45:00 PM	0.02
7/23/2014	4:00:00 PM	0.02
7/23/2014	4:15:00 PM	0.01
7/23/2014	4:30:00 PM	0.01
7/23/2014	4:45:00 PM	0.01
7/23/2014	5:00:00 PM	0.01
7/23/2014	5:15:00 PM	0.01
7/23/2014	5:30:00 PM	0.01
7/23/2014	5:45:00 PM	0.01
7/23/2014	6:00:00 PM	0.01
7/23/2014	6:15:00 PM	0.01
7/23/2014	6:30:00 PM	0.01
7/23/2014	6:45:00 PM	0.01
7/23/2014	7:00:00 PM	0.01
7/23/2014	7:15:00 PM	0.01
7/23/2014	7:30:00 PM	0
7/23/2014	7:45:00 PM	0
7/23/2014	8:00:00 PM	0
7/23/2014	8:15:00 PM	0.01
7/23/2014	8:30:00 PM	0.01
7/23/2014	8:45:00 PM	0.01
7/23/2014	9:00:00 PM	0.01
7/23/2014	9:15:00 PM	0.01
7/23/2014	9:30:00 PM	0.01
7/23/2014	9:45:00 PM	0.01
7/23/2014	10:00:00 PM	0.01
7/23/2014	10:15:00 PM	0.01
7/23/2014	10:30:00 PM	0.01
7/23/2014	10:45:00 PM	0.01
7/23/2014	11:00:00 PM	0.01
7/23/2014	11:15:00 PM	0.01
7/23/2014	11:30:00 PM	0.01
7/23/2014	11:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	12:00:00 AM	0.01
7/24/2014	12:15:00 AM	0.01
7/24/2014	12:30:00 AM	0.01
7/24/2014	12:45:00 AM	0.01
7/24/2014	1:00:00 AM	0.01
7/24/2014	1:15:00 AM	0.01
7/24/2014	1:30:00 AM	0.01
7/24/2014	1:45:00 AM	0.01
7/24/2014	2:00:00 AM	0.01
7/24/2014	2:15:00 AM	0.01
7/24/2014	2:30:00 AM	0.01
7/24/2014	2:45:00 AM	0.01
7/24/2014	3:00:00 AM	0.01
7/24/2014	3:15:00 AM	0.01
7/24/2014	3:30:00 AM	0.01
7/24/2014	3:45:00 AM	0.01
7/24/2014	4:00:00 AM	0.01
7/24/2014	4:15:00 AM	0.01
7/24/2014	4:30:00 AM	0.01
7/24/2014	4:45:00 AM	0.01
7/24/2014	5:00:00 AM	0.01
7/24/2014	5:15:00 AM	0.01
7/24/2014	5:30:00 AM	0.01
7/24/2014	5:45:00 AM	0.01
7/24/2014	6:00:00 AM	0.01
7/24/2014	6:15:00 AM	0.01
7/24/2014	6:30:00 AM	0.01
7/24/2014	6:45:00 AM	0.01
7/24/2014	7:00:00 AM	0.01
7/24/2014	7:15:00 AM	0.01
7/24/2014	7:30:00 AM	0.01
7/24/2014	7:45:00 AM	0.01
7/24/2014	8:00:00 AM	0.01
7/24/2014	8:15:00 AM	0.01
7/24/2014	8:30:00 AM	0.01
7/24/2014	8:45:00 AM	0.01
7/24/2014	9:00:00 AM	0.01
7/24/2014	9:15:00 AM	0.01
7/24/2014	9:30:00 AM	0.01
7/24/2014	9:45:00 AM	0.01
7/24/2014	10:00:00 AM	0.01
7/24/2014	10:15:00 AM	0.01
7/24/2014	10:30:00 AM	0.01
7/24/2014	10:45:00 AM	0.01
7/24/2014	11:00:00 AM	0.01
7/24/2014	11:15:00 AM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	11:30:00 AM	0.01
7/24/2014	11:45:00 AM	0.01
7/24/2014	12:00:00 PM	0.01
7/24/2014	12:15:00 PM	0.01
7/24/2014	12:30:00 PM	0.01
7/24/2014	12:45:00 PM	0
7/24/2014	1:00:00 PM	0
7/24/2014	1:15:00 PM	0
7/24/2014	1:30:00 PM	0
7/24/2014	1:45:00 PM	0
7/24/2014	2:00:00 PM	0
7/24/2014	2:15:00 PM	0
7/24/2014	2:30:00 PM	0
7/24/2014	2:45:00 PM	0
7/24/2014	3:00:00 PM	0
7/24/2014	3:15:00 PM	0
7/24/2014	3:30:00 PM	0
7/24/2014	3:45:00 PM	0
7/24/2014	4:00:00 PM	0
7/24/2014	4:15:00 PM	0
7/24/2014	4:30:00 PM	0
7/24/2014	4:45:00 PM	0
7/24/2014	5:00:00 PM	0
7/24/2014	5:15:00 PM	0
7/24/2014	5:30:00 PM	0
7/24/2014	5:45:00 PM	0
7/24/2014	6:00:00 PM	0
7/24/2014	6:15:00 PM	0
7/24/2014	6:30:00 PM	0
7/24/2014	6:45:00 PM	0
7/24/2014	7:00:00 PM	0
7/24/2014	7:15:00 PM	0
7/24/2014	7:30:00 PM	0
7/24/2014	7:45:00 PM	0
7/24/2014	8:00:00 PM	0
7/24/2014	8:15:00 PM	0
7/24/2014	8:30:00 PM	0
7/24/2014	8:45:00 PM	0
7/24/2014	9:00:00 PM	0
7/24/2014	9:15:00 PM	0
7/24/2014	9:30:00 PM	0
7/24/2014	9:45:00 PM	0
7/24/2014	10:00:00 PM	0
7/24/2014	10:15:00 PM	0
7/24/2014	10:30:00 PM	0
7/24/2014	10:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2014	11:00:00 PM	0
7/24/2014	11:15:00 PM	0
7/24/2014	11:30:00 PM	0
7/24/2014	11:45:00 PM	0
7/25/2014	12:00:00 AM	0
7/25/2014	12:15:00 AM	0
7/25/2014	12:30:00 AM	0
7/25/2014	12:45:00 AM	0
7/25/2014	1:00:00 AM	0
7/25/2014	1:15:00 AM	0
7/25/2014	1:30:00 AM	0
7/25/2014	1:45:00 AM	0
7/25/2014	2:00:00 AM	0
7/25/2014	2:15:00 AM	0
7/25/2014	2:30:00 AM	0
7/25/2014	2:45:00 AM	0
7/25/2014	3:00:00 AM	0
7/25/2014	3:15:00 AM	0
7/25/2014	3:30:00 AM	0
7/25/2014	3:45:00 AM	0
7/25/2014	4:00:00 AM	0
7/25/2014	4:15:00 AM	0
7/25/2014	4:30:00 AM	0
7/25/2014	4:45:00 AM	0
7/25/2014	5:00:00 AM	0
7/25/2014	5:15:00 AM	0
7/25/2014	5:30:00 AM	0
7/25/2014	5:45:00 AM	0
7/25/2014	6:00:00 AM	0
7/25/2014	6:15:00 AM	0
7/25/2014	6:30:00 AM	0
7/25/2014	6:45:00 AM	0
7/25/2014	7:00:00 AM	0
7/25/2014	7:15:00 AM	0
7/25/2014	7:30:00 AM	0
7/25/2014	7:45:00 AM	0
7/25/2014	8:00:00 AM	0
7/25/2014	8:15:00 AM	0
7/25/2014	8:30:00 AM	0
7/25/2014	8:45:00 AM	0
7/25/2014	9:00:00 AM	0
7/25/2014	9:15:00 AM	0
7/25/2014	9:30:00 AM	0
7/25/2014	9:45:00 AM	0
7/25/2014	10:00:00 AM	0
7/25/2014	10:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/25/2014	10:30:00 AM	0
7/25/2014	10:45:00 AM	0
7/25/2014	11:00:00 AM	0
7/25/2014	11:15:00 AM	0
7/25/2014	11:30:00 AM	0
7/25/2014	11:45:00 AM	0
7/25/2014	12:00:00 PM	0
7/25/2014	12:15:00 PM	0
7/25/2014	12:30:00 PM	0
7/25/2014	12:45:00 PM	0
7/25/2014	1:00:00 PM	0
7/25/2014	1:15:00 PM	0
7/25/2014	1:30:00 PM	0
7/25/2014	1:45:00 PM	0
7/25/2014	2:00:00 PM	0
7/25/2014	2:15:00 PM	0
7/25/2014	2:30:00 PM	0
7/25/2014	2:45:00 PM	0
7/25/2014	3:00:00 PM	0
7/25/2014	3:15:00 PM	0
7/25/2014	3:30:00 PM	0
7/25/2014	3:45:00 PM	0
7/25/2014	4:00:00 PM	0
7/25/2014	4:15:00 PM	0
7/25/2014	4:30:00 PM	0
7/25/2014	4:45:00 PM	0
7/25/2014	5:00:00 PM	0
7/25/2014	5:15:00 PM	0
7/25/2014	5:30:00 PM	0
7/25/2014	5:45:00 PM	0
7/25/2014	6:00:00 PM	0
7/25/2014	6:15:00 PM	0
7/25/2014	6:30:00 PM	0
7/25/2014	6:45:00 PM	0
7/25/2014	7:00:00 PM	0.3
7/25/2014	7:15:00 PM	0.38
7/25/2014	7:30:00 PM	0.4
7/25/2014	7:45:00 PM	0.4
7/25/2014	8:00:00 PM	0.41
7/25/2014	8:15:00 PM	0.41
7/25/2014	8:30:00 PM	0.42
7/25/2014	8:45:00 PM	0.42
7/25/2014	9:00:00 PM	0.43
7/25/2014	9:15:00 PM	0.43
7/25/2014	9:30:00 PM	0.44
7/25/2014	9:45:00 PM	0.45

Georges Ditch Return Gage

DATE	TIME	GAGE
7/25/2014	10:00:00 PM	0.46
7/25/2014	10:15:00 PM	0.46
7/25/2014	10:30:00 PM	0.47
7/25/2014	10:45:00 PM	0.47
7/25/2014	11:00:00 PM	0.48
7/25/2014	11:15:00 PM	0.48
7/25/2014	11:30:00 PM	0.48
7/25/2014	11:45:00 PM	0.48
7/26/2014	12:00:00 AM	0.49
7/26/2014	12:15:00 AM	0.49
7/26/2014	12:30:00 AM	0.49
7/26/2014	12:45:00 AM	0.49
7/26/2014	1:00:00 AM	0.49
7/26/2014	1:15:00 AM	0.49
7/26/2014	1:30:00 AM	0.49
7/26/2014	1:45:00 AM	0.49
7/26/2014	2:00:00 AM	0.49
7/26/2014	2:15:00 AM	0.49
7/26/2014	2:30:00 AM	0.49
7/26/2014	2:45:00 AM	0.5
7/26/2014	3:00:00 AM	0.5
7/26/2014	3:15:00 AM	0.5
7/26/2014	3:30:00 AM	0.5
7/26/2014	3:45:00 AM	0.5
7/26/2014	4:00:00 AM	0.5
7/26/2014	4:15:00 AM	0.5
7/26/2014	4:30:00 AM	0.5
7/26/2014	4:45:00 AM	0.5
7/26/2014	5:00:00 AM	0.5
7/26/2014	5:15:00 AM	0.5
7/26/2014	5:30:00 AM	0.5
7/26/2014	5:45:00 AM	0.5
7/26/2014	6:00:00 AM	0.5
7/26/2014	6:15:00 AM	0.5
7/26/2014	6:30:00 AM	0.5
7/26/2014	6:45:00 AM	0.5
7/26/2014	7:00:00 AM	0.5
7/26/2014	7:15:00 AM	0.5
7/26/2014	7:30:00 AM	0.5
7/26/2014	7:45:00 AM	0.5
7/26/2014	8:00:00 AM	0.5
7/26/2014	8:15:00 AM	0.5
7/26/2014	8:30:00 AM	0.5
7/26/2014	8:45:00 AM	0.5
7/26/2014	9:00:00 AM	0.5
7/26/2014	9:15:00 AM	0.5

Georges Ditch Return Gage

DATE	TIME	GAGE
7/26/2014	9:30:00 AM	0.5
7/26/2014	9:45:00 AM	0.5
7/26/2014	10:00:00 AM	0.5
7/26/2014	10:15:00 AM	0.5
7/26/2014	10:30:00 AM	0.5
7/26/2014	10:45:00 AM	0.5
7/26/2014	11:00:00 AM	0.5
7/26/2014	11:15:00 AM	0.5
7/26/2014	11:30:00 AM	0.5
7/26/2014	11:45:00 AM	0.5
7/26/2014	12:00:00 PM	0.5
7/26/2014	12:15:00 PM	0.5
7/26/2014	12:30:00 PM	0.49
7/26/2014	12:45:00 PM	0.49
7/26/2014	1:00:00 PM	0.49
7/26/2014	1:15:00 PM	0.49
7/26/2014	1:30:00 PM	0.48
7/26/2014	1:45:00 PM	0.49
7/26/2014	2:00:00 PM	0.48
7/26/2014	2:15:00 PM	0.48
7/26/2014	2:30:00 PM	0.48
7/26/2014	2:45:00 PM	0.48
7/26/2014	3:00:00 PM	0.46
7/26/2014	3:15:00 PM	0.4
7/26/2014	3:30:00 PM	0.34
7/26/2014	3:45:00 PM	0.27
7/26/2014	4:00:00 PM	0.22
7/26/2014	4:15:00 PM	0.2
7/26/2014	4:30:00 PM	0.17
7/26/2014	4:45:00 PM	0.16
7/26/2014	5:00:00 PM	0.16
7/26/2014	5:15:00 PM	0.18
7/26/2014	5:30:00 PM	0.2
7/26/2014	5:45:00 PM	0.21
7/26/2014	6:00:00 PM	0.21
7/26/2014	6:15:00 PM	0.21
7/26/2014	6:30:00 PM	0.21
7/26/2014	6:45:00 PM	0.21
7/26/2014	7:00:00 PM	0.2
7/26/2014	7:15:00 PM	0.2
7/26/2014	7:30:00 PM	0.21
7/26/2014	7:45:00 PM	0.23
7/26/2014	8:00:00 PM	0.25
7/26/2014	8:15:00 PM	0.27
7/26/2014	8:30:00 PM	0.29
7/26/2014	8:45:00 PM	0.31

Georges Ditch Return Gage

DATE	TIME	GAGE
7/26/2014	9:00:00 PM	0.33
7/26/2014	9:15:00 PM	0.34
7/26/2014	9:30:00 PM	0.34
7/26/2014	9:45:00 PM	0.36
7/26/2014	10:00:00 PM	0.36
7/26/2014	10:15:00 PM	0.37
7/26/2014	10:30:00 PM	0.38
7/26/2014	10:45:00 PM	0.39
7/26/2014	11:00:00 PM	0.39
7/26/2014	11:15:00 PM	0.4
7/26/2014	11:30:00 PM	0.4
7/26/2014	11:45:00 PM	0.41
7/27/2014	12:00:00 AM	0.41
7/27/2014	12:15:00 AM	0.42
7/27/2014	12:30:00 AM	0.42
7/27/2014	12:45:00 AM	0.43
7/27/2014	1:00:00 AM	0.44
7/27/2014	1:15:00 AM	0.44
7/27/2014	1:30:00 AM	0.44
7/27/2014	1:45:00 AM	0.45
7/27/2014	2:00:00 AM	0.45
7/27/2014	2:15:00 AM	0.46
7/27/2014	2:30:00 AM	0.46
7/27/2014	2:45:00 AM	0.46
7/27/2014	3:00:00 AM	0.46
7/27/2014	3:15:00 AM	0.47
7/27/2014	3:30:00 AM	0.47
7/27/2014	3:45:00 AM	0.47
7/27/2014	4:00:00 AM	0.47
7/27/2014	4:15:00 AM	0.47
7/27/2014	4:30:00 AM	0.47
7/27/2014	4:45:00 AM	0.47
7/27/2014	5:00:00 AM	0.47
7/27/2014	5:15:00 AM	0.47
7/27/2014	5:30:00 AM	0.47
7/27/2014	5:45:00 AM	0.47
7/27/2014	6:00:00 AM	0.47
7/27/2014	6:15:00 AM	0.48
7/27/2014	6:30:00 AM	0.48
7/27/2014	6:45:00 AM	0.48
7/27/2014	7:00:00 AM	0.48
7/27/2014	7:15:00 AM	0.48
7/27/2014	7:30:00 AM	0.48
7/27/2014	7:45:00 AM	0.48
7/27/2014	8:00:00 AM	0.48
7/27/2014	8:15:00 AM	0.48

Georges Ditch Return Gage

DATE	TIME	GAGE
7/27/2014	8:30:00 AM	0.48
7/27/2014	8:45:00 AM	0.48
7/27/2014	9:00:00 AM	0.48
7/27/2014	9:15:00 AM	0.48
7/27/2014	9:30:00 AM	0.48
7/27/2014	9:45:00 AM	0.48
7/27/2014	10:00:00 AM	0.48
7/27/2014	10:15:00 AM	0.48
7/27/2014	10:30:00 AM	0.48
7/27/2014	10:45:00 AM	0.48
7/27/2014	11:00:00 AM	0.48
7/27/2014	11:15:00 AM	0.48
7/27/2014	11:30:00 AM	0.48
7/27/2014	11:45:00 AM	0.48
7/27/2014	12:00:00 PM	0.47
7/27/2014	12:15:00 PM	0.47
7/27/2014	12:30:00 PM	0.47
7/27/2014	12:45:00 PM	0.47
7/27/2014	1:00:00 PM	0.47
7/27/2014	1:15:00 PM	0.47
7/27/2014	1:30:00 PM	0.47
7/27/2014	1:45:00 PM	0.47
7/27/2014	2:00:00 PM	0.47
7/27/2014	2:15:00 PM	0.46
7/27/2014	2:30:00 PM	0.46
7/27/2014	2:45:00 PM	0.46
7/27/2014	3:00:00 PM	0.46
7/27/2014	3:15:00 PM	0.46
7/27/2014	3:30:00 PM	0.46
7/27/2014	3:45:00 PM	0.46
7/27/2014	4:00:00 PM	0.46
7/27/2014	4:15:00 PM	0.46
7/27/2014	4:30:00 PM	0.46
7/27/2014	4:45:00 PM	0.45
7/27/2014	5:00:00 PM	0.45
7/27/2014	5:15:00 PM	0.45
7/27/2014	5:30:00 PM	0.44
7/27/2014	5:45:00 PM	0.42
7/27/2014	6:00:00 PM	0.4
7/27/2014	6:15:00 PM	0.38
7/27/2014	6:30:00 PM	0.37
7/27/2014	6:45:00 PM	0.35
7/27/2014	7:00:00 PM	0.34
7/27/2014	7:15:00 PM	0.34
7/27/2014	7:30:00 PM	0.33
7/27/2014	7:45:00 PM	0.32

Georges Ditch Return Gage

DATE	TIME	GAGE
7/27/2014	8:00:00 PM	0.32
7/27/2014	8:15:00 PM	0.32
7/27/2014	8:30:00 PM	0.32
7/27/2014	8:45:00 PM	0.32
7/27/2014	9:00:00 PM	0.32
7/27/2014	9:15:00 PM	0.32
7/27/2014	9:30:00 PM	0.32
7/27/2014	9:45:00 PM	0.32
7/27/2014	10:00:00 PM	0.32
7/27/2014	10:15:00 PM	0.32
7/27/2014	10:30:00 PM	0.32
7/27/2014	10:45:00 PM	0.32
7/27/2014	11:00:00 PM	0.32
7/27/2014	11:15:00 PM	0.32
7/27/2014	11:30:00 PM	0.32
7/27/2014	11:45:00 PM	0.32
7/28/2014	12:00:00 AM	0.32
7/28/2014	12:15:00 AM	0.32
7/28/2014	12:30:00 AM	0.32
7/28/2014	12:45:00 AM	0.32
7/28/2014	1:00:00 AM	0.32
7/28/2014	1:15:00 AM	0.32
7/28/2014	1:30:00 AM	0.32
7/28/2014	1:45:00 AM	0.32
7/28/2014	2:00:00 AM	0.32
7/28/2014	2:15:00 AM	0.32
7/28/2014	2:30:00 AM	0.32
7/28/2014	2:45:00 AM	0.32
7/28/2014	3:00:00 AM	0.32
7/28/2014	3:15:00 AM	0.32
7/28/2014	3:30:00 AM	0.32
7/28/2014	3:45:00 AM	0.32
7/28/2014	4:00:00 AM	0.32
7/28/2014	4:15:00 AM	0.32
7/28/2014	4:30:00 AM	0.32
7/28/2014	4:45:00 AM	0.32
7/28/2014	5:00:00 AM	0.32
7/28/2014	5:15:00 AM	0.33
7/28/2014	5:30:00 AM	0.33
7/28/2014	5:45:00 AM	0.33
7/28/2014	6:00:00 AM	0.33
7/28/2014	6:15:00 AM	0.33
7/28/2014	6:30:00 AM	0.33
7/28/2014	6:45:00 AM	0.33
7/28/2014	7:00:00 AM	0.33
7/28/2014	7:15:00 AM	0.33

Georges Ditch Return Gage

DATE	TIME	GAGE
7/28/2014	7:30:00 AM	0.33
7/28/2014	7:45:00 AM	0.33
7/28/2014	8:00:00 AM	0.33
7/28/2014	8:15:00 AM	0.33
7/28/2014	8:30:00 AM	0.33
7/28/2014	8:45:00 AM	0.33
7/28/2014	9:00:00 AM	0.33
7/28/2014	9:15:00 AM	0.33
7/28/2014	9:30:00 AM	0.33
7/28/2014	9:45:00 AM	0.33
7/28/2014	10:00:00 AM	0.33
7/28/2014	10:15:00 AM	0.33
7/28/2014	10:30:00 AM	0.33
7/28/2014	10:45:00 AM	0.33
7/28/2014	11:00:00 AM	0.33
7/28/2014	11:15:00 AM	0.33
7/28/2014	11:30:00 AM	0.33
7/28/2014	11:45:00 AM	0.33
7/28/2014	12:00:00 PM	0.33
7/28/2014	12:15:00 PM	0.33
7/28/2014	12:30:00 PM	0.33
7/28/2014	12:45:00 PM	0.33
7/28/2014	1:00:00 PM	0.32
7/28/2014	1:15:00 PM	0.32
7/28/2014	1:30:00 PM	0.32
7/28/2014	1:45:00 PM	0.32
7/28/2014	2:00:00 PM	0.32
7/28/2014	2:15:00 PM	0.32
7/28/2014	2:30:00 PM	0.32
7/28/2014	2:45:00 PM	0.32
7/28/2014	3:00:00 PM	0.32
7/28/2014	3:15:00 PM	0.32
7/28/2014	3:30:00 PM	0.32
7/28/2014	3:45:00 PM	0.32
7/28/2014	4:00:00 PM	0.32
7/28/2014	4:15:00 PM	0.34
7/28/2014	4:30:00 PM	0.38
7/28/2014	4:45:00 PM	0.42
7/28/2014	5:00:00 PM	0.45
7/28/2014	5:15:00 PM	0.49
7/28/2014	5:30:00 PM	0.58
7/28/2014	5:45:00 PM	0.68
7/28/2014	6:00:00 PM	0.73
7/28/2014	6:15:00 PM	0.74
7/28/2014	6:30:00 PM	0.75
7/28/2014	6:45:00 PM	0.75

Georges Ditch Return Gage

DATE	TIME	GAGE
7/28/2014	7:00:00 PM	0.75
7/28/2014	7:15:00 PM	0.74
7/28/2014	7:30:00 PM	0.74
7/28/2014	7:45:00 PM	0.74
7/28/2014	8:00:00 PM	0.74
7/28/2014	8:15:00 PM	0.74
7/28/2014	8:30:00 PM	0.74
7/28/2014	8:45:00 PM	0.74
7/28/2014	9:00:00 PM	0.74
7/28/2014	9:15:00 PM	0.75
7/28/2014	9:30:00 PM	0.75
7/28/2014	9:45:00 PM	0.75
7/28/2014	10:00:00 PM	0.75
7/28/2014	10:15:00 PM	0.75
7/28/2014	10:30:00 PM	0.75
7/28/2014	10:45:00 PM	0.75
7/28/2014	11:00:00 PM	0.76
7/28/2014	11:15:00 PM	0.76
7/28/2014	11:30:00 PM	0.76
7/28/2014	11:45:00 PM	0.76
7/29/2014	12:00:00 AM	0.76
7/29/2014	12:15:00 AM	0.76
7/29/2014	12:30:00 AM	0.76
7/29/2014	12:45:00 AM	0.76
7/29/2014	1:00:00 AM	0.76
7/29/2014	1:15:00 AM	0.76
7/29/2014	1:30:00 AM	0.76
7/29/2014	1:45:00 AM	0.76
7/29/2014	2:00:00 AM	0.76
7/29/2014	2:15:00 AM	0.77
7/29/2014	2:30:00 AM	0.77
7/29/2014	2:45:00 AM	0.77
7/29/2014	3:00:00 AM	0.77
7/29/2014	3:15:00 AM	0.77
7/29/2014	3:30:00 AM	0.77
7/29/2014	3:45:00 AM	0.77
7/29/2014	4:00:00 AM	0.77
7/29/2014	4:15:00 AM	0.77
7/29/2014	4:30:00 AM	0.77
7/29/2014	4:45:00 AM	0.77
7/29/2014	5:00:00 AM	0.78
7/29/2014	5:15:00 AM	0.78
7/29/2014	5:30:00 AM	0.78
7/29/2014	5:45:00 AM	0.78
7/29/2014	6:00:00 AM	0.78
7/29/2014	6:15:00 AM	0.78

Georges Ditch Return Gage

DATE	TIME	GAGE
7/29/2014	6:30:00 AM	0.78
7/29/2014	6:45:00 AM	0.78
7/29/2014	7:00:00 AM	0.78
7/29/2014	7:15:00 AM	0.78
7/29/2014	7:30:00 AM	0.78
7/29/2014	7:45:00 AM	0.78
7/29/2014	8:00:00 AM	0.78
7/29/2014	8:15:00 AM	0.78
7/29/2014	8:30:00 AM	0.78
7/29/2014	8:45:00 AM	0.78
7/29/2014	9:00:00 AM	0.78
7/29/2014	9:15:00 AM	0.78
7/29/2014	9:30:00 AM	0.78
7/29/2014	9:45:00 AM	0.78
7/29/2014	10:00:00 AM	0.78
7/29/2014	10:15:00 AM	0.78
7/29/2014	10:30:00 AM	0.78
7/29/2014	10:45:00 AM	0.78
7/29/2014	11:00:00 AM	0.78
7/29/2014	11:15:00 AM	0.78
7/29/2014	11:30:00 AM	0.78
7/29/2014	11:45:00 AM	0.78
7/29/2014	12:00:00 PM	0.78
7/29/2014	12:15:00 PM	0.78
7/29/2014	12:30:00 PM	0.78
7/29/2014	12:45:00 PM	0.78
7/29/2014	1:00:00 PM	0.78
7/29/2014	1:15:00 PM	0.78
7/29/2014	1:30:00 PM	0.78
7/29/2014	1:45:00 PM	0.78
7/29/2014	2:00:00 PM	0.78
7/29/2014	2:15:00 PM	0.78
7/29/2014	2:30:00 PM	0.78
7/29/2014	2:45:00 PM	0.78
7/29/2014	3:00:00 PM	0.78
7/29/2014	3:15:00 PM	0.78
7/29/2014	3:30:00 PM	0.79
7/29/2014	3:45:00 PM	0.79
7/29/2014	4:00:00 PM	0.79
7/29/2014	4:15:00 PM	0.8
7/29/2014	4:30:00 PM	0.8
7/29/2014	4:45:00 PM	0.8
7/29/2014	5:00:00 PM	0.8
7/29/2014	5:15:00 PM	0.8
7/29/2014	5:30:00 PM	0.8
7/29/2014	5:45:00 PM	0.8

Georges Ditch Return Gage

DATE	TIME	GAGE
7/29/2014	6:00:00 PM	0.8
7/29/2014	6:15:00 PM	0.8
7/29/2014	6:30:00 PM	0.8
7/29/2014	6:45:00 PM	0.81
7/29/2014	7:00:00 PM	0.8
7/29/2014	7:15:00 PM	0.81
7/29/2014	7:30:00 PM	0.81
7/29/2014	7:45:00 PM	0.81
7/29/2014	8:00:00 PM	0.81
7/29/2014	8:15:00 PM	0.81
7/29/2014	8:30:00 PM	0.81
7/29/2014	8:45:00 PM	0.81
7/29/2014	9:00:00 PM	0.81
7/29/2014	9:15:00 PM	0.81
7/29/2014	9:30:00 PM	0.81
7/29/2014	9:45:00 PM	0.81
7/29/2014	10:00:00 PM	0.81
7/29/2014	10:15:00 PM	0.81
7/29/2014	10:30:00 PM	0.81
7/29/2014	10:45:00 PM	0.81
7/29/2014	11:00:00 PM	0.81
7/29/2014	11:15:00 PM	0.81
7/29/2014	11:30:00 PM	0.81
7/29/2014	11:45:00 PM	0.81
7/30/2014	12:00:00 AM	0.81
7/30/2014	12:15:00 AM	0.81
7/30/2014	12:30:00 AM	0.81
7/30/2014	12:45:00 AM	0.81
7/30/2014	1:00:00 AM	0.81
7/30/2014	1:15:00 AM	0.81
7/30/2014	1:30:00 AM	0.81
7/30/2014	1:45:00 AM	0.8
7/30/2014	2:00:00 AM	0.8
7/30/2014	2:15:00 AM	0.8
7/30/2014	2:30:00 AM	0.8
7/30/2014	2:45:00 AM	0.8
7/30/2014	3:00:00 AM	0.8
7/30/2014	3:15:00 AM	0.8
7/30/2014	3:30:00 AM	0.8
7/30/2014	3:45:00 AM	0.8
7/30/2014	4:00:00 AM	0.79
7/30/2014	4:15:00 AM	0.79
7/30/2014	4:30:00 AM	0.79
7/30/2014	4:45:00 AM	0.79
7/30/2014	5:00:00 AM	0.79
7/30/2014	5:15:00 AM	0.79

Georges Ditch Return Gage

DATE	TIME	GAGE
7/30/2014	5:30:00 AM	0.79
7/30/2014	5:45:00 AM	0.79
7/30/2014	6:00:00 AM	0.79
7/30/2014	6:15:00 AM	0.79
7/30/2014	6:30:00 AM	0.79
7/30/2014	6:45:00 AM	0.79
7/30/2014	7:00:00 AM	0.79
7/30/2014	7:15:00 AM	0.79
7/30/2014	7:30:00 AM	0.79
7/30/2014	7:45:00 AM	0.79
7/30/2014	8:00:00 AM	0.78
7/30/2014	8:15:00 AM	0.78
7/30/2014	8:30:00 AM	0.78
7/30/2014	8:45:00 AM	0.78
7/30/2014	9:00:00 AM	0.77
7/30/2014	9:15:00 AM	0.77
7/30/2014	9:30:00 AM	0.77
7/30/2014	9:45:00 AM	0.77
7/30/2014	10:00:00 AM	0.77
7/30/2014	10:15:00 AM	0.77
7/30/2014	10:30:00 AM	0.77
7/30/2014	10:45:00 AM	0.77
7/30/2014	11:00:00 AM	0.76
7/30/2014	11:15:00 AM	0.76
7/30/2014	11:30:00 AM	0.76
7/30/2014	11:45:00 AM	0.75
7/30/2014	12:00:00 PM	0.75
7/30/2014	12:15:00 PM	0.74
7/30/2014	12:30:00 PM	0.74
7/30/2014	12:45:00 PM	0.74
7/30/2014	1:00:00 PM	0.74
7/30/2014	1:15:00 PM	0.74
7/30/2014	1:30:00 PM	0.73
7/30/2014	1:45:00 PM	0.73
7/30/2014	2:00:00 PM	0.73
7/30/2014	2:15:00 PM	0.72
7/30/2014	2:30:00 PM	0.72
7/30/2014	2:45:00 PM	0.72
7/30/2014	3:00:00 PM	0.72
7/30/2014	3:15:00 PM	0.72
7/30/2014	3:30:00 PM	0.72
7/30/2014	3:45:00 PM	0.72
7/30/2014	4:00:00 PM	0.72
7/30/2014	4:15:00 PM	0.72
7/30/2014	4:30:00 PM	0.72
7/30/2014	4:45:00 PM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/30/2014	5:00:00 PM	0.72
7/30/2014	5:15:00 PM	0.72
7/30/2014	5:30:00 PM	0.72
7/30/2014	5:45:00 PM	0.71
7/30/2014	6:00:00 PM	0.71
7/30/2014	6:15:00 PM	0.69
7/30/2014	6:30:00 PM	0.64
7/30/2014	6:45:00 PM	0.59
7/30/2014	7:00:00 PM	0.55
7/30/2014	7:15:00 PM	0.54
7/30/2014	7:30:00 PM	0.53
7/30/2014	7:45:00 PM	0.52
7/30/2014	8:00:00 PM	0.51
7/30/2014	8:15:00 PM	0.49
7/30/2014	8:30:00 PM	0.47
7/30/2014	8:45:00 PM	0.45
7/30/2014	9:00:00 PM	0.44
7/30/2014	9:15:00 PM	0.43
7/30/2014	9:30:00 PM	0.42
7/30/2014	9:45:00 PM	0.41
7/30/2014	10:00:00 PM	0.4
7/30/2014	10:15:00 PM	0.4
7/30/2014	10:30:00 PM	0.39
7/30/2014	10:45:00 PM	0.39
7/30/2014	11:00:00 PM	0.38
7/30/2014	11:15:00 PM	0.38
7/30/2014	11:30:00 PM	0.38
7/30/2014	11:45:00 PM	0.38
7/31/2014	12:00:00 AM	0.38
7/31/2014	12:15:00 AM	0.37
7/31/2014	12:30:00 AM	0.37
7/31/2014	12:45:00 AM	0.37
7/31/2014	1:00:00 AM	0.37
7/31/2014	1:15:00 AM	0.37
7/31/2014	1:30:00 AM	0.37
7/31/2014	1:45:00 AM	0.37
7/31/2014	2:00:00 AM	0.37
7/31/2014	2:15:00 AM	0.37
7/31/2014	2:30:00 AM	0.37
7/31/2014	2:45:00 AM	0.37
7/31/2014	3:00:00 AM	0.37
7/31/2014	3:15:00 AM	0.37
7/31/2014	3:30:00 AM	0.37
7/31/2014	3:45:00 AM	0.37
7/31/2014	4:00:00 AM	0.37
7/31/2014	4:15:00 AM	0.37

Georges Ditch Return Gage

DATE	TIME	GAGE
7/31/2014	4:30:00 AM	0.37
7/31/2014	4:45:00 AM	0.37
7/31/2014	5:00:00 AM	0.37
7/31/2014	5:15:00 AM	0.37
7/31/2014	5:30:00 AM	0.37
7/31/2014	5:45:00 AM	0.37
7/31/2014	6:00:00 AM	0.37
7/31/2014	6:15:00 AM	0.37
7/31/2014	6:30:00 AM	0.37
7/31/2014	6:45:00 AM	0.37
7/31/2014	7:00:00 AM	0.37
7/31/2014	7:15:00 AM	0.37
7/31/2014	7:30:00 AM	0.37
7/31/2014	7:45:00 AM	0.37
7/31/2014	8:00:00 AM	0.37
7/31/2014	8:15:00 AM	0.37
7/31/2014	8:30:00 AM	0.37
7/31/2014	8:45:00 AM	0.38
7/31/2014	9:00:00 AM	0.38
7/31/2014	9:15:00 AM	0.38
7/31/2014	9:30:00 AM	0.38
7/31/2014	9:45:00 AM	0.38
7/31/2014	10:00:00 AM	0.38
7/31/2014	10:15:00 AM	0.38
7/31/2014	10:30:00 AM	0.38
7/31/2014	10:45:00 AM	0.38
7/31/2014	11:00:00 AM	0.38
7/31/2014	11:15:00 AM	0.38
7/31/2014	11:30:00 AM	0.38
7/31/2014	11:45:00 AM	0.38
7/31/2014	12:00:00 PM	0.37
7/31/2014	12:15:00 PM	0.37
7/31/2014	12:30:00 PM	0.37
7/31/2014	12:45:00 PM	0.37
7/31/2014	1:00:00 PM	0.37
7/31/2014	1:15:00 PM	0.37
7/31/2014	1:30:00 PM	0.36
7/31/2014	1:45:00 PM	0.35
7/31/2014	2:00:00 PM	0.33
7/31/2014	2:15:00 PM	0.31
7/31/2014	2:30:00 PM	0.3
7/31/2014	2:45:00 PM	0.29
7/31/2014	3:00:00 PM	0.28
7/31/2014	3:15:00 PM	0.28
7/31/2014	3:30:00 PM	0.27
7/31/2014	3:45:00 PM	0.27

Georges Ditch Return Gage

DATE	TIME	GAGE
7/31/2014	4:00:00 PM	0.27
7/31/2014	4:15:00 PM	0.26
7/31/2014	4:30:00 PM	0.26
7/31/2014	4:45:00 PM	0.26
7/31/2014	5:00:00 PM	0.25
7/31/2014	5:15:00 PM	0.25
7/31/2014	5:30:00 PM	0.25
7/31/2014	5:45:00 PM	0.25
7/31/2014	6:00:00 PM	0.25
7/31/2014	6:15:00 PM	0.25
7/31/2014	6:30:00 PM	0.24
7/31/2014	6:45:00 PM	0.24
7/31/2014	7:00:00 PM	0.24
7/31/2014	7:15:00 PM	0.24
7/31/2014	7:30:00 PM	0.24
7/31/2014	7:45:00 PM	0.24
7/31/2014	8:00:00 PM	0.24
7/31/2014	8:15:00 PM	0.24
7/31/2014	8:30:00 PM	0.23
7/31/2014	8:45:00 PM	0.21
7/31/2014	9:00:00 PM	0.18
7/31/2014	9:15:00 PM	0.17
7/31/2014	9:30:00 PM	0.15
7/31/2014	9:45:00 PM	0.14
7/31/2014	10:00:00 PM	0.13
7/31/2014	10:15:00 PM	0.13
7/31/2014	10:30:00 PM	0.12
7/31/2014	10:45:00 PM	0.12
7/31/2014	11:00:00 PM	0.11
7/31/2014	11:15:00 PM	0.11
7/31/2014	11:30:00 PM	0.11
7/31/2014	11:45:00 PM	0.11
8/1/2014	12:00:00 AM	0.11

Party: MKH/BJA	Width: 20.7 ft	Processed by: MKH/BJA
Boat/Motor:	Area: 85.6 ft ²	Mean Velocity: 0.762 ft/s
Gage Height: 4.55 ft	G.H.Change: 0.000 ft	Discharge: 65.2 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 1.73 ft/s	
Max. Depth: 8.50 ft	
Mean Depth: 4.14 ft	
% Meas.: 68.84	
Water Temp.: None	
ADCP Temp.: 71.4 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 140722 LOR @ REINHACKLE
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	32	8.23	46.2	7.73	2.47	2.08	66.7	20	84	09:16	09:17	0.56	0.79	6	0
001	R	2	2	32	7.73	43.4	7.45	2.65	2.19	63.4	20	85	09:17	09:18	0.54	0.75	6	0
002	L	2	2	32	8.05	45.1	7.49	2.51	2.08	65.2	21	86	09:18	09:19	0.54	0.76	6	0
003	R	2	2	32	7.45	41.7	6.99	2.54	1.94	60.6	21	84	09:19	09:19	0.53	0.72	6	0
004	L	2	2	31	7.66	43.1	7.59	2.83	2.12	63.3	21	87	09:20	09:21	0.57	0.72	6	0
005	R	2	2	32	8.93	50.0	8.90	2.26	2.05	72.1	21	87	09:21	09:21	0.55	0.83	6	0
Mean		2	2	31	8.01	44.9	7.69	2.54	2.08	65.2	21	86	Total	00:05	0.55	0.76	6	0
SDev		0	0	1	0.532	2.95	0.642	0.188	0.082	3.97	0.3	1.5			0.02	0.04		
SD/M		0.00	0.00	0.03	0.07	0.07	0.08	0.07	0.04	0.06	0.01	0.02			0.03	0.06		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	0	8	18	0.81	-0.056	4.003	0.01	0.007	0	42.6	38.7	75.3	133	121	0	34	31
2014	7	1	0	18	18	0.837	-0.079	4.003	0.01	0.007	0	42.6	38.7	75.7	133	122	0	34	32
2014	7	1	0	28	18	0.82	-0.049	4.003	0.01	0.007	0	42.6	38.3	75.7	133	121	0	34	32
2014	7	1	0	38	18	0.83	-0.062	4.003	0.01	0.007	0	42.6	37.8	75.3	133	121	0	34	33
2014	7	1	0	48	18	0.82	-0.062	4.003	0.01	0.007	0	42.6	38.7	76.1	134	122	0	35	32
2014	7	1	0	58	18	0.83	-0.105	4.003	0.01	0.007	0	42.6	38.7	75.7	133	122	0	34	32
2014	7	1	1	8	18	0.83	-0.062	4.003	0.01	0.007	0	42.1	39.1	76.1	133	122	0	35	31
2014	7	1	1	18	18	0.84	-0.095	4.003	0.01	0.007	0	42.6	38.3	76.1	133	121	0	34	32
2014	7	1	1	28	18	0.823	-0.069	4.003	0.01	0.007	0	43	38.7	77.4	134	122	0	34	32
2014	7	1	1	38	18	0.823	-0.059	4.003	0.013	0.01	0	43	38.7	77	134	122	0	34	32
2014	7	1	1	48	18	0.83	-0.056	4.003	0.01	0.007	0	42.6	39.1	76.5	133	122	0	34	31
2014	7	1	1	58	18	0.82	-0.095	4.003	0.01	0.007	0	43	38.7	77.4	133	122	0	33	32
2014	7	1	2	8	18	0.817	-0.085	4.003	0.01	0.007	0	42.6	39.1	77	133	122	0	34	31
2014	7	1	2	18	18	0.771	-0.046	4.003	0.016	0.013	0	42.6	38.7	77	134	122	0	35	32
2014	7	1	2	28	18	0.794	-0.082	4.003	0.016	0.013	0	42.6	38.3	77.4	133	121	0	34	32
2014	7	1	2	38	18	0.797	-0.079	4.003	0.013	0.01	0	42.6	38.7	76.5	134	122	0	35	32
2014	7	1	2	48	18	0.83	-0.089	4.003	0.01	0.007	0	43	38.7	76.5	133	121	0	33	31
2014	7	1	2	58	18	0.801	-0.118	4.003	0.013	0.01	0	43	38.7	77	134	122	0	34	32
2014	7	1	3	8	18	0.794	-0.062	4.003	0.013	0.01	0	42.6	38.3	77	133	121	0	34	32
2014	7	1	3	18	18	0.84	-0.095	4.003	0.01	0.007	0	42.6	38.3	77	133	121	0	34	32
2014	7	1	3	28	18	0.787	-0.062	4.003	0.01	0.007	0	43	38.7	77	134	122	0	34	32
2014	7	1	3	38	18	0.83	-0.079	4.003	0.013	0.01	0	43	38.7	76.5	134	122	0	34	32
2014	7	1	3	48	18	0.807	-0.036	4.003	0.013	0.01	0	43.4	39.1	77	134	123	0	33	32
2014	7	1	3	58	18	0.817	-0.069	4.003	0.013	0.01	0	43	38.7	76.5	134	122	0	34	32
2014	7	1	4	8	18	0.856	-0.066	4.003	0.013	0.01	0	42.6	38.7	77.4	134	122	0	35	32
2014	7	1	4	18	18	0.837	-0.062	4.003	0.013	0.01	0	43	38.7	76.5	134	122	0	34	32
2014	7	1	4	28	18	0.846	-0.089	4.003	0.01	0.007	0	42.6	38.7	76.1	134	122	0	35	32
2014	7	1	4	38	18	0.846	-0.079	4.003	0.016	0.013	0	42.6	38.3	76.1	134	122	0	35	33
2014	7	1	4	48	18	0.797	-0.066	4.003	0.01	0.007	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	1	4	58	18	0.843	-0.112	4.003	0.013	0.01	0	42.6	39.1	76.5	134	122	0	35	31
2014	7	1	5	8	18	0.82	-0.066	4.003	0.013	0.01	0	43.4	39.1	77	135	123	0	34	32
2014	7	1	5	18	18	0.814	-0.079	4.003	0.01	0.007	0	43.4	40	74	135	124	0	34	31
2014	7	1	5	28	18	0.85	-0.098	4.003	0.013	0.01	0	43	40	75.3	135	124	0	35	31
2014	7	1	5	38	18	0.83	-0.079	4.003	0.01	0.007	0	43.4	39.6	76.1	136	124	0	35	32
2014	7	1	5	48	18	0.807	-0.089	4.003	0.01	0.007	0	43.4	39.6	76.1	136	124	0	35	32
2014	7	1	5	58	18	0.86	-0.079	4.003	0.01	0.007	0	43	40	76.5	135	124	0	35	31
2014	7	1	6	8	18	0.794	-0.085	4.003	0.01	0.007	0	43.9	39.6	76.5	136	124	0	34	32
2014	7	1	6	18	18	0.85	-0.052	4.003	0.01	0.007	0	43.4	38.7	76.5	135	123	0	34	33
2014	7	1	6	28	18	0.83	-0.062	4.003	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	7	1	6	38	18	0.807	-0.082	4.003	0.01	0.007	0	43.4	39.1	76.1	135	123	0	34	32
2014	7	1	6	48	18	0.846	-0.062	4.003	0.01	0.007	0	43.4	39.1	76.1	135	123	0	34	32
2014	7	1	6	58	18	0.778	-0.098	4.003	0.013	0.01	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	1	7	8	18	0.82	-0.039	4.003	0.01	0.007	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	1	7	18	18	0.833	-0.075	4.003	0.016	0.013	0	43.4	39.6	76.1	135	123	0	34	31
2014	7	1	7	28	18	0.807	-0.072	4.003	0.01	0.007	0	43	39.6	75.7	135	123	0	35	31
2014	7	1	7	38	18	0.801	-0.075	4.003	0.01	0.007	0	43.4	39.1	75.7	135	123	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	7	48	18	0.817	-0.089	4.003	0.01	0.007	0	43.4	39.6	75.7	135	124	0	34	32
2014	7	1	7	58	18	0.804	-0.102	4.003	0.013	0.01	0	43.4	38.7	76.1	135	123	0	34	33
2014	7	1	8	8	18	0.817	-0.082	4.003	0.013	0.01	0	43	39.6	76.1	135	124	0	35	32
2014	7	1	8	18	18	0.804	-0.075	4.003	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	7	1	8	28	18	0.85	-0.062	4.003	0.01	0.007	0	43	39.1	76.1	135	123	0	35	32
2014	7	1	8	38	18	0.86	-0.079	4.003	0.01	0.007	0	43.9	39.6	76.1	136	124	0	34	32
2014	7	1	8	48	18	0.833	-0.062	4.003	0.01	0.007	0	43	39.6	76.5	135	124	0	35	32
2014	7	1	8	58	18	0.837	-0.085	4.003	0.01	0.007	0	43.9	39.6	75.7	136	124	0	34	32
2014	7	1	9	8	18	0.814	-0.062	4.003	0.01	0.007	0	43.4	39.6	76.1	135	124	0	34	32
2014	7	1	9	18	18	0.83	-0.082	4.003	0.016	0.013	0	43	39.6	76.5	135	124	0	35	32
2014	7	1	9	28	18	0.82	-0.062	4.003	0.01	0.007	0	43.4	40	76.1	136	124	0	35	31
2014	7	1	9	38	18	0.837	-0.066	4.003	0.013	0.01	0	43.9	40	75.7	136	125	0	34	32
2014	7	1	9	48	18	0.82	-0.062	4.006	0.01	0.007	0	43.4	39.6	76.1	135	124	0	34	32
2014	7	1	9	58	18	0.85	-0.079	4.003	0.01	0.007	0	43.9	39.6	76.1	136	124	0	34	32
2014	7	1	10	8	18	0.843	-0.102	4.003	0.013	0.01	0	43.9	40	77	136	124	0	34	31
2014	7	1	10	18	18	0.853	-0.046	4.003	0.013	0.01	0	43.9	40.4	76.5	136	125	0	34	31
2014	7	1	10	28	18	0.827	-0.075	4.006	0.01	0.007	0	43.4	39.6	76.5	135	124	0	34	32
2014	7	1	10	38	18	0.801	-0.079	4.006	0.013	0.01	0	43.4	39.6	76.1	136	124	0	35	32
2014	7	1	10	48	18	0.781	-0.072	4.003	0.013	0.01	0	43	39.6	76.5	135	124	0	35	32
2014	7	1	10	58	18	0.83	-0.089	4.006	0.01	0.007	0	43	39.1	76.5	135	123	0	35	32
2014	7	1	11	8	18	0.748	-0.082	4.006	0.013	0.01	0	43.4	39.1	76.1	135	123	0	34	32
2014	7	1	11	18	18	0.794	-0.095	4.006	0.01	0.007	0	43	39.1	76.5	134	123	0	34	32
2014	7	1	11	28	18	0.791	-0.079	4.006	0.013	0.01	0	42.6	38.7	77	133	122	0	34	32
2014	7	1	11	38	18	0.823	-0.089	4.006	0.01	0.007	0	42.6	38.7	77.4	133	122	0	34	32
2014	7	1	11	48	18	0.814	-0.098	3.999	0.01	0.007	0	42.6	39.1	52.9	133	122	0	34	31
2014	7	1	11	58	18	0.781	-0.098	4.003	0.01	0.007	0	42.1	38.7	60.2	133	122	0	35	32
2014	7	1	12	8	18	0.755	-0.098	4.003	0.013	0.01	0	43.9	39.6	50.7	136	123	0	34	31
2014	7	1	12	18	18	0.784	-0.082	4.003	0.01	0.007	0	43	38.7	51.6	134	122	0	34	32
2014	7	1	12	28	18	0.794	-0.066	4.003	0.01	0.007	0	42.1	38.7	57.2	133	122	0	35	32
2014	7	1	12	38	18	0.814	-0.108	4.003	0.013	0.01	0	42.6	38.7	56.3	133	122	0	34	32
2014	7	1	12	48	18	0.804	-0.066	4.003	0.013	0.01	0	43	39.1	53.8	134	123	0	34	32
2014	7	1	12	58	18	0.761	-0.089	3.996	0.01	0.007	0	45.6	39.6	44.3	140	124	0	34	32
2014	7	1	13	8	18	0.722	-0.069	3.967	0.013	0.01	0	46.4	43	43	142	131	0	34	31
2014	7	1	13	18	18	0.748	-0.066	3.996	0.013	0.01	0	44.7	41.7	50.7	138	129	0	34	32
2014	7	1	13	28	18	0.719	-0.131	3.99	0.01	0.007	0	45.6	41.3	46	140	128	0	34	32
2014	7	1	13	38	18	0.801	-0.092	3.996	0.01	0.007	0	44.7	41.3	53.8	138	128	0	34	32
2014	7	1	13	48	18	0.823	-0.082	3.996	0.016	0.013	0	45.2	42.6	55	139	130	0	34	31
2014	7	1	13	58	18	0.745	-0.079	3.993	0.01	0.007	0	46	42.6	49.9	141	131	0	34	32
2014	7	1	14	8	18	0.797	-0.052	3.993	0.01	0.007	0	44.7	42.1	50.3	138	129	0	34	31
2014	7	1	14	18	18	0.738	-0.089	3.99	0.01	0.007	0	46.4	42.1	45.2	142	129	0	34	31
2014	7	1	14	28	18	0.778	-0.072	3.99	0.01	0.007	0	44.7	41.3	49.9	139	128	0	35	32
2014	7	1	14	38	18	0.732	-0.098	3.993	0.01	0.007	0	46.4	41.3	48.2	143	128	0	35	32
2014	7	1	14	48	18	0.771	-0.072	3.99	0.01	0.007	0	44.3	40.9	52.9	137	127	0	34	32
2014	7	1	14	58	18	0.787	-0.066	3.99	0.013	0.01	0	44.3	41.3	54.2	137	128	0	34	32
2014	7	1	15	8	18	0.784	-0.062	3.986	0.01	0.007	0	44.3	41.3	56.3	137	127	0	34	31
2014	7	1	15	18	18	0.764	-0.085	3.986	0.01	0.007	0	43.9	40.9	55.5	136	126	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	15	28	18	0.748	-0.085	3.986	0.01	0.007	0	43.4	40.4	53.8	135	125	0	34	31
2014	7	1	15	38	18	0.774	-0.075	3.983	0.01	0.007	0	43.4	40	55.9	135	124	0	34	31
2014	7	1	15	48	18	0.801	-0.089	3.983	0.01	0.007	0	43.9	40	55.9	135	125	0	33	32
2014	7	1	15	58	18	0.764	-0.082	3.983	0.013	0.01	0	43.4	40.4	55	135	125	0	34	31
2014	7	1	16	8	18	0.778	-0.066	3.98	0.01	0.007	0	43	40	58	134	124	0	34	31
2014	7	1	16	18	18	0.807	-0.102	3.98	0.01	0.007	0	43	39.6	56.8	134	123	0	34	31
2014	7	1	16	28	18	0.817	-0.098	3.98	0.01	0.007	0	43	40	58	134	124	0	34	31
2014	7	1	16	38	18	0.801	-0.089	3.98	0.01	0.007	0	43	40	56.8	134	124	0	34	31
2014	7	1	16	48	18	0.768	-0.095	3.98	0.01	0.007	0	43.4	40.4	55.9	135	125	0	34	31
2014	7	1	16	58	18	0.781	-0.085	3.98	0.01	0.007	0	43.4	40	55	135	125	0	34	32
2014	7	1	17	8	18	0.771	-0.082	3.98	0.016	0.013	0	43	40.4	54.2	135	125	0	35	31
2014	7	1	17	18	18	0.774	-0.092	3.976	0.01	0.007	0	43.9	40.9	55.5	136	126	0	34	31
2014	7	1	17	28	18	0.801	-0.098	3.976	0.013	0.01	0	43.4	39.6	58.5	135	125	0	34	33
2014	7	1	17	38	18	0.741	-0.108	3.976	0.013	0.01	0	43.4	40.4	56.8	135	125	0	34	31
2014	7	1	17	48	18	0.797	-0.059	3.973	0.013	0.01	0	43.4	40.4	55.5	135	125	0	34	31
2014	7	1	17	58	18	0.771	-0.069	3.976	0.013	0.01	0	43	39.6	56.3	134	124	0	34	32
2014	7	1	18	8	18	0.81	-0.072	3.973	0.013	0.01	0	43.4	40	55	135	124	0	34	31
2014	7	1	18	18	18	0.801	-0.075	3.976	0.013	0.01	0	43	40	54.2	134	124	0	34	31
2014	7	1	18	28	18	0.82	-0.115	3.973	0.013	0.01	0	43.4	39.6	58	135	124	0	34	32
2014	7	1	18	38	18	0.758	-0.102	3.973	0.01	0.007	0	43.9	40.4	55.9	135	125	0	33	31
2014	7	1	18	48	18	0.794	-0.082	3.973	0.01	0.007	0	43.9	40.9	57.2	136	126	0	34	31
2014	7	1	18	58	18	0.794	-0.082	3.973	0.016	0.013	0	43.4	40	59.8	135	125	0	34	32
2014	7	1	19	8	18	0.781	-0.075	3.973	0.01	0.007	0	43.4	40.4	60.2	135	125	0	34	31
2014	7	1	19	18	18	0.797	-0.098	3.97	0.01	0.007	0	43.9	40.4	55	136	126	0	34	32
2014	7	1	19	28	18	0.82	-0.062	3.973	0.01	0.007	0	43.4	40	76.1	135	125	0	34	32
2014	7	1	19	38	18	0.83	-0.085	3.973	0.01	0.007	0	43	40	75.7	134	124	0	34	31
2014	7	1	19	48	18	0.827	-0.089	3.973	0.013	0.01	0	43.4	40	77	134	124	0	33	31
2014	7	1	19	58	18	0.843	-0.066	3.973	0.01	0.007	0	43	39.6	77.4	134	124	0	34	32
2014	7	1	20	8	18	0.82	-0.049	3.973	0.013	0.01	0	43.4	40	77.4	135	125	0	34	32
2014	7	1	20	18	18	0.866	-0.046	3.973	0.01	0.007	0	43	40	77.4	134	124	0	34	31
2014	7	1	20	28	18	0.81	-0.089	3.973	0.013	0.01	0	43	39.6	77.4	134	124	0	34	32
2014	7	1	20	38	18	0.823	-0.092	3.973	0.01	0.007	0	43	40	75.3	134	124	0	34	31
2014	7	1	20	48	18	0.837	-0.079	3.973	0.013	0.01	0	43.4	40.4	73.5	135	125	0	34	31
2014	7	1	20	58	18	0.84	-0.092	3.973	0.013	0.01	0	43.4	40	74.8	135	125	0	34	32
2014	7	1	21	8	18	0.843	-0.066	3.973	0.01	0.007	0	43	40	74.4	134	125	0	34	32
2014	7	1	21	18	18	0.817	-0.082	3.973	0.01	0.007	0	43	39.6	75.7	134	124	0	34	32
2014	7	1	21	28	18	0.82	-0.072	3.973	0.016	0.013	0	43	39.6	76.5	134	124	0	34	32
2014	7	1	21	38	18	0.837	-0.082	3.973	0.01	0.007	0	42.6	39.1	77	133	123	0	34	32
2014	7	1	21	48	18	0.81	-0.082	3.973	0.01	0.007	0	42.6	39.6	76.1	133	123	0	34	31
2014	7	1	21	58	18	0.843	-0.115	3.973	0.013	0.01	0	42.6	39.6	76.1	133	123	0	34	31
2014	7	1	22	8	18	0.774	-0.066	3.973	0.013	0.01	0	42.6	39.6	77	133	123	0	34	31
2014	7	1	22	18	18	0.843	-0.082	3.973	0.01	0.007	0	42.1	38.7	77	132	122	0	34	32
2014	7	1	22	28	18	0.784	-0.082	3.973	0.013	0.01	0	42.1	38.7	77.4	132	122	0	34	32
2014	7	1	22	38	18	0.833	-0.056	3.973	0.01	0.007	0	42.1	39.6	77	132	123	0	34	31
2014	7	1	22	48	18	0.843	-0.056	3.973	0.01	0.007	0	42.1	39.1	77.4	132	122	0	34	31
2014	7	1	22	58	18	0.833	-0.102	3.973	0.013	0.01	0	42.6	38.7	76.1	132	122	0	33	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	1	23	8	18	0.823	-0.052	3.973	0.016	0.013	0	42.1	38.7	76.1	132	122	0	34	32
2014	7	1	23	18	18	0.797	-0.062	3.973	0.016	0.013	0	42.1	39.6	76.1	132	123	0	34	31
2014	7	1	23	28	18	0.863	-0.075	3.973	0.01	0.007	0	42.1	38.7	76.5	132	122	0	34	32
2014	7	1	23	38	18	0.846	-0.079	3.973	0.013	0.01	0	42.1	38.7	76.1	132	122	0	34	32
2014	7	1	23	48	18	0.827	-0.089	3.973	0.01	0.007	0	42.1	38.7	76.5	132	122	0	34	32
2014	7	1	23	58	18	0.804	-0.095	3.973	0.01	0.007	0	41.7	39.1	76.5	132	122	0	35	31
2014	7	2	0	8	18	0.807	-0.075	3.973	0.016	0.013	0	42.6	39.1	76.1	132	123	0	33	32
2014	7	2	0	18	18	0.837	-0.089	3.973	0.013	0.01	0	42.1	39.1	76.5	132	122	0	34	31
2014	7	2	0	28	18	0.82	-0.089	3.973	0.01	0.007	0	42.6	39.6	77	133	123	0	34	31
2014	7	2	0	38	18	0.833	-0.075	3.973	0.013	0.01	0	42.1	39.1	76.5	132	122	0	34	31
2014	7	2	0	48	18	0.853	-0.072	3.973	0.01	0.007	0	42.1	39.1	76.5	132	123	0	34	32
2014	7	2	0	58	18	0.827	-0.069	3.97	0.01	0.007	0	42.1	39.1	77	133	123	0	35	32
2014	7	2	1	8	18	0.837	-0.056	3.973	0.01	0.007	0	42.6	39.1	76.5	133	123	0	34	32
2014	7	2	1	18	18	0.801	-0.062	3.97	0.01	0.007	0	42.6	39.1	76.5	133	123	0	34	32
2014	7	2	1	28	18	0.82	-0.056	3.973	0.01	0.007	0	43	39.6	76.1	134	124	0	34	32
2014	7	2	1	38	18	0.853	-0.066	3.97	0.01	0.007	0	42.6	39.6	76.5	133	123	0	34	31
2014	7	2	1	48	18	0.86	-0.056	3.973	0.01	0.007	0	42.6	40	75.7	133	124	0	34	31
2014	7	2	1	58	18	0.853	-0.105	3.97	0.01	0.007	0	42.1	39.6	76.5	133	123	0	35	31
2014	7	2	2	8	18	0.827	-0.072	3.97	0.013	0.01	0	42.6	39.1	76.1	133	123	0	34	32
2014	7	2	2	18	18	0.804	-0.112	3.973	0.013	0.01	0	43	39.6	76.1	134	123	0	34	31
2014	7	2	2	28	18	0.83	-0.066	3.97	0.016	0.013	0	42.6	39.6	75.7	133	123	0	34	31
2014	7	2	2	38	18	0.804	-0.062	3.973	0.01	0.007	0	42.6	39.1	74.8	133	123	0	34	32
2014	7	2	2	48	18	0.81	-0.046	3.973	0.013	0.01	0	43	39.6	75.3	134	124	0	34	32
2014	7	2	2	58	18	0.833	-0.102	3.973	0.01	0.007	0	43	39.6	75.7	134	124	0	34	32
2014	7	2	3	8	18	0.823	-0.059	3.973	0.01	0.007	0	42.6	39.1	75.7	134	123	0	35	32
2014	7	2	3	18	18	0.837	-0.115	3.973	0.013	0.01	0	43	40	75.3	134	124	0	34	31
2014	7	2	3	28	18	0.823	-0.095	3.973	0.013	0.01	0	43	39.1	75.7	134	123	0	34	32
2014	7	2	3	38	18	0.833	-0.069	3.973	0.013	0.01	0	43	40	75.3	134	124	0	34	31
2014	7	2	3	48	18	0.804	-0.062	3.973	0.01	0.007	0	43	39.6	75.3	134	124	0	34	32
2014	7	2	3	58	18	0.837	-0.095	3.973	0.016	0.013	0	43	39.6	74.4	134	124	0	34	32
2014	7	2	4	8	18	0.843	-0.095	3.973	0.013	0.01	0	43	40	74.4	134	124	0	34	31
2014	7	2	4	18	18	0.863	-0.072	3.973	0.01	0.007	0	42.1	39.1	73.5	133	123	0	35	32
2014	7	2	4	28	18	0.817	-0.075	3.973	0.01	0.007	0	43	40	73.5	134	124	0	34	31
2014	7	2	4	38	18	0.791	-0.049	3.973	0.013	0.01	0	43.4	40	74	135	124	0	34	31
2014	7	2	4	48	18	0.81	-0.069	3.973	0.013	0.01	0	43	39.6	73.1	134	124	0	34	32
2014	7	2	4	58	18	0.804	-0.079	3.973	0.01	0.007	0	42.6	39.6	73.1	134	124	0	35	32
2014	7	2	5	8	18	0.81	-0.085	3.973	0.01	0.007	0	43	39.6	72.2	134	124	0	34	32
2014	7	2	5	18	18	0.84	-0.079	3.976	0.01	0.007	0	43	39.6	72.7	134	124	0	34	32
2014	7	2	5	28	18	0.833	-0.072	3.976	0.01	0.007	0	43	39.1	73.1	134	123	0	34	32
2014	7	2	5	38	18	0.853	-0.066	3.976	0.013	0.01	0	43	39.6	71.8	134	124	0	34	32
2014	7	2	5	48	18	0.833	-0.115	3.976	0.01	0.007	0	43	40	72.7	134	124	0	34	31
2014	7	2	5	58	18	0.817	-0.072	3.98	0.01	0.007	0	43	39.6	72.2	134	124	0	34	32
2014	7	2	6	8	18	0.807	-0.105	3.986	0.01	0.007	0	43	39.6	72.2	134	124	0	34	32
2014	7	2	6	18	18	0.807	-0.072	3.986	0.01	0.007	0	43	40	72.7	134	124	0	34	31
2014	7	2	6	28	18	0.823	-0.082	3.986	0.01	0.007	0	43	39.1	73.1	134	123	0	34	32
2014	7	2	6	38	18	0.843	-0.079	3.986	0.01	0.007	0	42.6	39.6	72.7	133	123	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	6	48	18	0.807	-0.089	3.986	0.013	0.01	0	42.6	38.7	73.5	133	122	0	34	32
2014	7	2	6	58	18	0.833	-0.079	3.986	0.01	0.007	0	42.6	39.1	74.4	133	123	0	34	32
2014	7	2	7	8	18	0.794	-0.052	3.986	0.01	0.007	0	42.1	38.7	74.4	132	122	0	34	32
2014	7	2	7	18	18	0.837	-0.095	3.99	0.013	0.01	0	42.6	39.1	74.4	133	123	0	34	32
2014	7	2	7	28	18	0.869	-0.102	3.99	0.01	0.007	0	41.7	38.7	74.4	132	122	0	35	32
2014	7	2	7	38	18	0.827	-0.069	3.99	0.01	0.007	0	42.1	38.7	74.8	133	123	0	35	33
2014	7	2	7	48	18	0.846	-0.102	3.99	0.01	0.007	0	41.7	38.7	74.4	132	122	0	35	32
2014	7	2	7	58	18	0.833	-0.082	3.99	0.01	0.007	0	42.1	39.1	74.8	132	123	0	34	32
2014	7	2	8	8	18	0.814	-0.082	3.99	0.01	0.007	0	42.1	38.7	74.4	132	122	0	34	32
2014	7	2	8	18	18	0.81	-0.085	3.99	0.01	0.007	0	42.6	39.1	75.3	133	123	0	34	32
2014	7	2	8	28	18	0.83	-0.066	3.99	0.013	0.01	0	42.1	39.6	74.8	133	123	0	35	31
2014	7	2	8	38	18	0.814	-0.072	3.99	0.013	0.01	0	42.1	39.1	73.5	132	123	0	34	32
2014	7	2	8	48	18	0.817	-0.049	3.99	0.01	0.007	0	42.1	39.1	74.8	132	123	0	34	32
2014	7	2	8	58	18	0.81	-0.046	3.99	0.01	0.007	0	42.1	39.6	75.3	133	123	0	35	31
2014	7	2	9	8	18	0.85	-0.112	3.99	0.013	0.01	0	41.7	39.1	74.8	132	123	0	35	32
2014	7	2	9	18	18	0.807	-0.098	3.99	0.01	0.007	0	42.6	39.1	74.4	133	123	0	34	32
2014	7	2	9	28	18	0.846	-0.072	3.99	0.01	0.007	0	42.1	39.1	75.7	133	123	0	35	32
2014	7	2	9	38	18	0.873	-0.072	3.993	0.01	0.007	0	42.1	39.1	74.8	133	123	0	35	32
2014	7	2	9	48	18	0.804	-0.095	3.993	0.01	0.007	0	42.6	39.1	74.8	133	123	0	34	32
2014	7	2	9	58	18	0.853	-0.046	3.993	0.01	0.007	0	42.6	39.6	74.8	133	124	0	34	32
2014	7	2	10	8	18	0.82	-0.118	3.99	0.01	0.007	0	42.6	39.1	74.4	133	123	0	34	32
2014	7	2	10	18	18	0.827	-0.052	3.993	0.01	0.007	0	42.6	39.6	74.4	134	124	0	35	32
2014	7	2	10	28	18	0.761	-0.082	3.99	0.01	0.007	0	42.1	39.1	73.5	133	123	0	35	32
2014	7	2	10	38	18	0.81	-0.079	3.993	0.01	0.007	0	41.7	39.1	73.5	132	123	0	35	32
2014	7	2	10	48	18	0.804	-0.049	3.99	0.01	0.007	0	42.1	39.1	72.7	133	123	0	35	32
2014	7	2	10	58	18	0.817	-0.075	3.993	0.01	0.007	0	42.1	38.7	73.5	132	122	0	34	32
2014	7	2	11	8	18	0.787	-0.082	3.986	0.01	0.007	0	42.1	39.1	58	132	122	0	34	31
2014	7	2	11	18	18	0.781	-0.098	3.986	0.016	0.013	0	41.3	38.3	69.2	131	121	0	35	32
2014	7	2	11	28	18	0.794	-0.108	3.986	0.01	0.007	0	41.7	38.7	62.8	132	122	0	35	32
2014	7	2	11	38	18	0.804	-0.062	3.986	0.01	0.007	0	41.3	37.8	65.8	130	121	0	34	33
2014	7	2	11	48	18	0.807	-0.085	3.986	0.01	0.007	0	41.7	38.3	58	131	121	0	34	32
2014	7	2	11	58	18	0.791	-0.062	3.983	0.01	0.007	0	41.7	38.7	62.8	132	122	0	35	32
2014	7	2	12	8	18	0.768	-0.075	3.983	0.01	0.007	0	41.7	38.7	57.6	131	122	0	34	32
2014	7	2	12	18	18	0.771	-0.079	3.986	0.013	0.01	0	41.3	38.7	52.9	131	122	0	35	32
2014	7	2	12	28	18	0.807	-0.108	3.98	0.01	0.007	0	42.1	39.1	52.9	132	123	0	34	32
2014	7	2	12	38	18	0.768	-0.085	3.983	0.01	0.007	0	42.1	39.6	55.9	133	123	0	35	31
2014	7	2	12	48	18	0.778	-0.108	3.98	0.01	0.007	0	42.6	38.7	55	133	122	0	34	32
2014	7	2	12	58	18	0.774	-0.075	3.98	0.013	0.01	0	42.6	39.1	54.6	133	123	0	34	32
2014	7	2	13	8	18	0.781	-0.079	3.98	0.013	0.01	0	42.6	39.6	55.9	134	124	0	35	32
2014	7	2	13	18	18	0.755	-0.089	3.98	0.013	0.01	0	43	40	55	134	125	0	34	32
2014	7	2	13	28	18	0.778	-0.102	3.976	0.01	0.007	0	43.4	40.4	56.8	135	125	0	34	31
2014	7	2	13	38	18	0.771	-0.121	3.98	0.01	0.007	0	43	40	55.9	134	125	0	34	32
2014	7	2	13	48	18	0.761	-0.092	3.976	0.013	0.01	0	43.4	40.4	55	135	126	0	34	32
2014	7	2	13	58	18	0.791	-0.092	3.98	0.013	0.01	0	43.4	40	55.5	135	125	0	34	32
2014	7	2	14	8	18	0.791	-0.108	3.976	0.013	0.01	0	43	40	56.8	134	125	0	34	32
2014	7	2	14	18	18	0.751	-0.115	3.976	0.01	0.007	0	43	40	57.2	134	125	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	14	28	18	0.787	-0.112	3.976	0.01	0.007	0	43	39.6	55.5	134	124	0	34	32
2014	7	2	14	38	18	0.781	-0.089	3.976	0.013	0.01	0	43	40	54.2	134	125	0	34	32
2014	7	2	14	48	18	0.781	-0.118	3.976	0.013	0.01	0	43	39.6	55.9	134	124	0	34	32
2014	7	2	14	58	18	0.771	-0.056	3.976	0.01	0.007	0	43	39.6	56.3	134	124	0	34	32
2014	7	2	15	8	18	0.784	-0.082	3.976	0.013	0.01	0	43	40	56.3	134	124	0	34	31
2014	7	2	15	18	18	0.787	-0.095	3.973	0.016	0.016	0	43	39.6	58	134	124	0	34	32
2014	7	2	15	28	18	0.768	-0.066	3.973	0.01	0.007	0	43.4	40	56.8	135	125	0	34	32
2014	7	2	15	38	18	0.837	-0.072	3.973	0.013	0.01	0	43.4	40.4	55.9	135	126	0	34	32
2014	7	2	15	48	18	0.758	-0.082	3.973	0.01	0.007	0	43.4	40	54.6	135	125	0	34	32
2014	7	2	15	58	18	0.768	-0.062	3.973	0.013	0.01	0	43.4	40.9	55.9	136	127	0	35	32
2014	7	2	16	8	18	0.791	-0.108	3.973	0.01	0.007	0	43.4	40.9	52.9	136	127	0	35	32
2014	7	2	16	18	18	0.751	-0.082	3.973	0.01	0.007	0	43	40	55.9	134	124	0	34	31
2014	7	2	16	28	18	0.801	-0.079	3.97	0.016	0.013	0	43.9	40.9	56.3	136	126	0	34	31
2014	7	2	16	38	18	0.781	-0.098	3.97	0.01	0.007	0	44.3	40.9	54.6	137	127	0	34	32
2014	7	2	16	48	18	0.794	-0.072	3.97	0.016	0.013	0	44.7	41.7	54.6	138	128	0	34	31
2014	7	2	16	58	18	0.82	-0.079	3.97	0.013	0.01	0	43.9	41.3	53.3	136	127	0	34	31
2014	7	2	17	8	18	0.807	-0.092	3.97	0.016	0.013	0	43.9	40.4	53.8	136	126	0	34	32
2014	7	2	17	18	18	0.771	-0.095	3.97	0.01	0.007	0	43.4	40.4	56.8	135	125	0	34	31
2014	7	2	17	28	18	0.768	-0.069	3.967	0.016	0.013	0	43.9	40	57.2	135	125	0	33	32
2014	7	2	17	38	18	0.804	-0.066	3.967	0.013	0.01	0	44.3	41.3	54.2	137	128	0	34	32
2014	7	2	17	48	18	0.787	-0.089	3.967	0.013	0.01	0	43.9	40.9	54.6	136	126	0	34	31
2014	7	2	17	58	18	0.804	-0.095	3.967	0.013	0.01	0	43.4	40	56.8	135	125	0	34	32
2014	7	2	18	8	18	0.758	-0.069	3.967	0.016	0.013	0	43.4	40.9	55.5	135	126	0	34	31
2014	7	2	18	18	18	0.755	-0.056	3.963	0.01	0.007	0	46	43	52.9	141	131	0	34	31
2014	7	2	18	28	18	0.794	-0.056	3.967	0.01	0.007	0	43	39.6	69.2	134	124	0	34	32
2014	7	2	18	38	18	0.801	-0.092	3.967	0.01	0.007	0	42.6	39.6	58.5	133	123	0	34	31
2014	7	2	18	48	18	0.801	-0.082	3.967	0.013	0.01	0	42.6	39.6	63.6	133	123	0	34	31
2014	7	2	18	58	18	0.791	-0.082	3.967	0.013	0.01	0	42.1	38.7	70.1	132	122	0	34	32
2014	7	2	19	8	18	0.761	-0.062	3.967	0.01	0.007	0	42.6	39.1	70.1	133	122	0	34	31
2014	7	2	19	18	18	0.755	-0.082	3.967	0.01	0.007	0	42.6	39.6	69.7	133	123	0	34	31
2014	7	2	19	28	18	0.778	-0.066	3.967	0.01	0.007	0	42.6	39.6	75.7	133	123	0	34	31
2014	7	2	19	38	18	0.781	-0.131	3.967	0.01	0.007	0	42.6	39.1	76.1	133	123	0	34	32
2014	7	2	19	48	18	0.768	-0.085	3.967	0.013	0.01	0	42.1	39.6	75.3	133	123	0	35	31
2014	7	2	19	58	18	0.843	-0.112	3.967	0.01	0.007	0	42.6	39.6	75.3	133	123	0	34	31
2014	7	2	20	8	18	0.81	-0.098	3.967	0.01	0.007	0	43	39.6	72.7	134	124	0	34	32
2014	7	2	20	18	18	0.797	-0.105	3.97	0.013	0.01	0	43	39.6	75.3	134	124	0	34	32
2014	7	2	20	28	18	0.817	-0.079	3.97	0.013	0.01	0	43	40	76.1	134	124	0	34	31
2014	7	2	20	38	18	0.797	-0.082	3.97	0.01	0.007	0	43	39.6	74.4	134	123	0	34	31
2014	7	2	20	48	18	0.768	-0.052	3.97	0.016	0.016	0	43.4	39.6	72.7	135	124	0	34	32
2014	7	2	20	58	18	0.807	-0.102	3.967	0.01	0.007	0	43	40.4	71.8	134	124	0	34	30
2014	7	2	21	8	18	0.827	-0.079	3.967	0.013	0.01	0	43	39.6	72.2	134	123	0	34	31
2014	7	2	21	18	18	0.807	-0.092	3.967	0.013	0.01	0	43	40	71.8	134	124	0	34	31
2014	7	2	21	28	18	0.833	-0.102	3.97	0.01	0.007	0	43	40	71.8	134	124	0	34	31
2014	7	2	21	38	18	0.797	-0.049	3.97	0.01	0.007	0	42.1	39.6	76.1	133	123	0	35	31
2014	7	2	21	48	18	0.814	-0.082	3.97	0.01	0.007	0	42.6	39.1	77.4	133	123	0	34	32
2014	7	2	21	58	18	0.778	-0.098	3.97	0.01	0.007	0	42.1	39.1	77	133	123	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	2	22	8	18	0.794	-0.118	3.97	0.01	0.007	0	42.6	39.1	77	133	123	0	34	32
2014	7	2	22	18	18	0.794	-0.079	3.97	0.013	0.01	0	43	39.6	77	134	123	0	34	31
2014	7	2	22	28	18	0.863	-0.085	3.97	0.01	0.007	0	42.6	39.6	77	133	123	0	34	31
2014	7	2	22	38	18	0.823	-0.082	3.97	0.01	0.007	0	42.6	39.1	77	133	123	0	34	32
2014	7	2	22	48	18	0.787	-0.098	3.97	0.013	0.01	0	42.6	39.6	77	133	123	0	34	31
2014	7	2	22	58	18	0.797	-0.089	3.97	0.01	0.007	0	43	39.1	77	134	123	0	34	32
2014	7	2	23	8	18	0.807	-0.102	3.97	0.01	0.007	0	42.6	39.1	76.5	133	123	0	34	32
2014	7	2	23	18	18	0.735	-0.118	3.97	0.01	0.007	0	42.6	39.1	76.1	133	123	0	34	32
2014	7	2	23	28	18	0.784	-0.118	3.97	0.01	0.007	0	42.1	39.1	61.5	132	123	0	34	32
2014	7	2	23	38	18	0.748	-0.089	3.97	0.01	0.007	0	43	39.6	53.3	134	124	0	34	32
2014	7	2	23	48	18	0.794	-0.082	3.97	0.01	0.007	0	43.4	39.6	76.1	135	124	0	34	32
2014	7	2	23	58	18	0.794	-0.105	3.97	0.013	0.01	0	42.1	39.1	76.5	133	123	0	35	32
2014	7	3	0	8	18	0.807	-0.069	3.97	0.01	0.007	0	42.6	39.1	76.5	133	123	0	34	32
2014	7	3	0	18	18	0.846	-0.079	3.97	0.01	0.007	0	43	39.1	76.1	134	123	0	34	32
2014	7	3	0	28	18	0.827	-0.095	3.97	0.01	0.007	0	42.6	39.6	76.1	133	123	0	34	31
2014	7	3	0	38	18	0.814	-0.095	3.97	0.01	0.007	0	43	39.6	76.5	134	123	0	34	31
2014	7	3	0	48	18	0.827	-0.095	3.97	0.013	0.01	0	42.6	39.6	76.5	133	123	0	34	31
2014	7	3	0	58	18	0.797	-0.062	3.97	0.013	0.01	0	42.1	39.6	76.1	133	123	0	35	31
2014	7	3	1	8	18	0.81	-0.085	3.97	0.01	0.007	0	42.6	39.1	76.1	133	123	0	34	32
2014	7	3	1	18	18	0.81	-0.069	3.97	0.013	0.01	0	42.1	39.6	76.5	133	123	0	35	31
2014	7	3	1	28	18	0.778	-0.115	3.97	0.01	0.007	0	43	39.6	75.3	134	124	0	34	32
2014	7	3	1	38	18	0.82	-0.098	3.973	0.01	0.007	0	42.6	39.6	76.1	133	123	0	34	31
2014	7	3	1	48	18	0.843	-0.059	3.973	0.01	0.007	0	42.6	39.6	75.7	133	123	0	34	31
2014	7	3	1	58	18	0.82	-0.072	3.973	0.013	0.01	0	42.6	39.1	75.3	133	123	0	34	32
2014	7	3	2	8	18	0.827	-0.095	3.973	0.01	0.007	0	42.6	39.1	75.7	133	123	0	34	32
2014	7	3	2	18	18	0.81	-0.115	3.973	0.01	0.007	0	43	40	75.3	134	124	0	34	31
2014	7	3	2	28	18	0.823	-0.075	3.973	0.01	0.007	0	42.6	39.6	75.3	133	123	0	34	31
2014	7	3	2	38	18	0.833	-0.092	3.973	0.01	0.007	0	42.6	39.6	74.4	133	124	0	34	32
2014	7	3	2	48	18	0.797	-0.089	3.973	0.01	0.007	0	43	40	75.3	134	124	0	34	31
2014	7	3	2	58	18	0.81	-0.069	3.973	0.01	0.007	0	42.6	39.6	75.3	134	124	0	35	32
2014	7	3	3	8	18	0.853	-0.089	3.973	0.013	0.01	0	42.6	39.1	74.4	133	123	0	34	32
2014	7	3	3	18	18	0.814	-0.095	3.973	0.013	0.01	0	43	39.6	74.4	134	124	0	34	32
2014	7	3	3	28	18	0.837	-0.069	3.973	0.01	0.007	0	42.6	40	74	134	124	0	35	31
2014	7	3	3	38	18	0.791	-0.056	3.973	0.013	0.01	0	43.4	39.6	74.4	134	124	0	33	32
2014	7	3	3	48	18	0.814	-0.079	3.976	0.013	0.01	0	43	39.1	73.1	134	123	0	34	32
2014	7	3	3	58	18	0.797	-0.105	3.976	0.01	0.007	0	42.6	39.1	73.5	133	123	0	34	32
2014	7	3	4	8	18	0.801	-0.108	3.976	0.01	0.007	0	42.6	39.6	73.1	133	123	0	34	31
2014	7	3	4	18	18	0.771	-0.092	3.976	0.01	0.007	0	42.6	39.1	73.5	134	123	0	35	32
2014	7	3	4	28	18	0.81	-0.095	3.98	0.01	0.007	0	42.6	39.1	72.7	133	123	0	34	32
2014	7	3	4	38	18	0.85	-0.079	3.983	0.01	0.007	0	42.6	39.1	72.7	133	123	0	34	32
2014	7	3	4	48	18	0.81	-0.052	3.986	0.01	0.007	0	42.1	39.1	72.7	133	123	0	35	32
2014	7	3	4	58	18	0.843	-0.085	3.986	0.013	0.01	0	43	39.6	71.8	134	124	0	34	32
2014	7	3	5	8	18	0.814	-0.135	3.99	0.016	0.013	0	42.6	39.1	73.5	134	123	0	35	32
2014	7	3	5	18	18	0.837	-0.095	3.99	0.01	0.007	0	43	39.6	72.2	134	124	0	34	32
2014	7	3	5	28	18	0.817	-0.121	3.99	0.01	0.007	0	43.9	40	73.5	135	125	0	33	32
2014	7	3	5	38	18	0.801	-0.112	3.99	0.01	0.007	0	43.4	40	73.5	135	125	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	5	48	18	0.83	-0.112	3.99	0.01	0.007	0	43.4	40	74	135	125	0	34	32
2014	7	3	5	58	18	0.804	-0.079	3.99	0.01	0.007	0	43.4	40	74	135	125	0	34	32
2014	7	3	6	8	18	0.787	-0.079	3.99	0.01	0.007	0	42.6	40	74.4	134	124	0	35	31
2014	7	3	6	18	18	0.781	-0.125	3.993	0.013	0.01	0	43	39.6	74.8	134	123	0	34	31
2014	7	3	6	28	18	0.801	-0.069	3.993	0.01	0.007	0	42.6	39.6	75.7	133	124	0	34	32
2014	7	3	6	38	18	0.833	-0.079	3.993	0.01	0.007	0	42.6	39.6	76.1	133	124	0	34	32
2014	7	3	6	48	18	0.83	-0.075	3.993	0.01	0.007	0	42.1	39.1	75.7	133	123	0	35	32
2014	7	3	6	58	18	0.846	-0.089	3.993	0.016	0.013	0	42.1	39.1	76.1	133	123	0	35	32
2014	7	3	7	8	18	0.814	-0.105	3.993	0.013	0.01	0	42.1	38.7	76.1	132	122	0	34	32
2014	7	3	7	18	18	0.82	-0.062	3.993	0.01	0.007	0	42.1	38.7	77	132	122	0	34	32
2014	7	3	7	28	18	0.81	-0.092	3.996	0.01	0.007	0	41.7	38.7	77.4	132	122	0	35	32
2014	7	3	7	38	18	0.814	-0.072	3.996	0.013	0.01	0	42.1	38.7	77	132	122	0	34	32
2014	7	3	7	48	18	0.82	-0.079	3.996	0.013	0.01	0	41.7	38.7	77	132	122	0	35	32
2014	7	3	7	58	18	0.817	-0.085	3.996	0.013	0.01	0	42.1	38.7	77	132	122	0	34	32
2014	7	3	8	8	18	0.84	-0.098	3.996	0.013	0.01	0	42.6	39.1	77.4	133	123	0	34	32
2014	7	3	8	18	18	0.837	-0.095	3.996	0.01	0.007	0	41.7	38.7	76.5	132	122	0	35	32
2014	7	3	8	28	18	0.83	-0.121	3.996	0.01	0.007	0	42.1	39.1	77.4	132	122	0	34	31
2014	7	3	8	38	18	0.791	-0.079	3.996	0.01	0.007	0	42.1	39.1	77	132	123	0	34	32
2014	7	3	8	48	18	0.81	-0.095	3.996	0.013	0.01	0	42.1	39.1	77	132	123	0	34	32
2014	7	3	8	58	18	0.781	-0.098	3.996	0.01	0.007	0	42.1	39.6	77	132	123	0	34	31
2014	7	3	9	8	18	0.771	-0.118	3.996	0.01	0.007	0	41.7	38.7	77	132	122	0	35	32
2014	7	3	9	18	18	0.83	-0.115	3.996	0.01	0.007	0	42.1	39.1	76.5	133	123	0	35	32
2014	7	3	9	28	18	0.787	-0.112	3.996	0.013	0.01	0	42.6	39.1	76.5	133	123	0	34	32
2014	7	3	9	38	18	0.807	-0.072	3.999	0.013	0.01	0	42.6	39.6	77	133	123	0	34	31
2014	7	3	9	48	18	0.761	-0.098	3.996	0.013	0.01	0	42.1	39.6	75.7	133	124	0	35	32
2014	7	3	9	58	18	0.758	-0.105	3.996	0.01	0.007	0	43	39.6	73.1	134	124	0	34	32
2014	7	3	10	8	18	0.768	-0.112	3.999	0.01	0.007	0	43	39.6	72.7	134	124	0	34	32
2014	7	3	10	18	18	0.758	-0.079	3.996	0.013	0.01	0	43	39.1	72.2	133	124	0	33	33
2014	7	3	10	28	18	0.787	-0.085	3.996	0.013	0.01	0	42.6	39.6	58	133	124	0	34	32
2014	7	3	10	38	18	0.768	-0.112	3.999	0.013	0.01	0	43	40	59.3	134	125	0	34	32
2014	7	3	10	48	18	0.81	-0.092	3.996	0.013	0.01	0	42.6	40.4	58.5	134	125	0	35	31
2014	7	3	10	58	18	0.751	-0.108	3.999	0.01	0.007	0	42.1	39.1	61.5	133	124	0	35	33
2014	7	3	11	8	18	0.778	-0.135	3.996	0.013	0.01	0	42.6	39.1	58.9	133	123	0	34	32
2014	7	3	11	18	18	0.764	-0.066	3.999	0.01	0.007	0	42.1	39.1	62.8	132	123	0	34	32
2014	7	3	11	28	18	0.781	-0.098	3.999	0.01	0.007	0	41.7	38.7	63.2	132	122	0	35	32
2014	7	3	11	38	18	0.784	-0.108	3.996	0.01	0.007	0	41.7	38.7	58.5	132	122	0	35	32
2014	7	3	11	48	18	0.755	-0.095	3.999	0.01	0.007	0	41.7	38.7	63.6	132	122	0	35	32
2014	7	3	11	58	18	0.794	-0.102	3.996	0.01	0.007	0	41.7	38.7	55.9	131	122	0	34	32
2014	7	3	12	8	18	0.787	-0.098	3.996	0.013	0.01	0	42.1	38.7	58.9	132	122	0	34	32
2014	7	3	12	18	18	0.794	-0.092	3.996	0.01	0.007	0	42.1	38.7	56.8	132	122	0	34	32
2014	7	3	12	28	18	0.761	-0.092	3.996	0.01	0.007	0	41.3	38.7	56.8	131	122	0	35	32
2014	7	3	12	38	18	0.787	-0.089	3.996	0.01	0.007	0	42.1	39.1	56.3	132	123	0	34	32
2014	7	3	12	48	18	0.738	-0.082	3.996	0.01	0.007	0	42.1	39.6	59.8	132	123	0	34	31
2014	7	3	12	58	18	0.771	-0.098	3.996	0.01	0.007	0	42.1	39.1	60.6	132	123	0	34	32
2014	7	3	13	8	18	0.771	-0.115	3.996	0.013	0.01	0	42.1	38.3	56.8	132	122	0	34	33
2014	7	3	13	18	18	0.797	-0.115	3.993	0.01	0.007	0	42.1	39.6	58	132	123	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	13	28	18	0.728	-0.082	3.993	0.01	0.007	0	42.6	39.6	53.8	133	124	0	34	32
2014	7	3	13	38	18	0.735	-0.043	3.993	0.01	0.007	0	43	39.6	55	134	124	0	34	32
2014	7	3	13	48	18	0.768	-0.125	3.993	0.01	0.007	0	43	40	56.3	134	125	0	34	32
2014	7	3	13	58	18	0.745	-0.115	3.993	0.013	0.01	0	42.6	39.6	53.8	133	124	0	34	32
2014	7	3	14	8	18	0.794	-0.079	3.993	0.013	0.01	0	42.6	40	55.9	133	124	0	34	31
2014	7	3	14	18	18	0.771	-0.079	3.99	0.01	0.007	0	42.1	39.6	55.5	132	123	0	34	31
2014	7	3	14	28	18	0.781	-0.072	3.99	0.016	0.016	0	43	39.6	56.8	134	124	0	34	32
2014	7	3	14	38	18	0.748	-0.105	3.99	0.01	0.007	0	42.1	39.6	55.5	133	124	0	35	32
2014	7	3	14	48	18	0.791	-0.098	3.986	0.01	0.007	0	42.1	39.1	54.6	132	123	0	34	32
2014	7	3	14	58	18	0.771	-0.118	3.986	0.013	0.01	0	42.6	39.1	55.9	132	123	0	33	32
2014	7	3	15	8	18	0.791	-0.085	3.986	0.01	0.007	0	42.1	39.6	55	132	123	0	34	31
2014	7	3	15	18	18	0.781	-0.082	3.983	0.01	0.007	0	42.6	39.6	58.9	133	123	0	34	31
2014	7	3	15	28	18	0.758	-0.075	3.986	0.01	0.007	0	42.1	39.1	56.8	132	123	0	34	32
2014	7	3	15	38	18	0.748	-0.108	3.983	0.01	0.007	0	42.6	40	53.8	133	124	0	34	31
2014	7	3	15	48	18	0.827	-0.095	3.983	0.016	0.013	0	41.7	39.1	57.6	132	123	0	35	32
2014	7	3	15	58	18	0.755	-0.089	3.98	0.01	0.007	0	42.6	39.1	58.5	133	123	0	34	32
2014	7	3	16	8	18	0.764	-0.118	3.983	0.013	0.01	0	42.6	39.6	57.6	133	123	0	34	31
2014	7	3	16	18	18	0.755	-0.079	3.983	0.01	0.007	0	42.6	40	58	133	124	0	34	31
2014	7	3	16	28	18	0.784	-0.066	3.983	0.013	0.01	0	43	40	56.8	134	125	0	34	32
2014	7	3	16	38	18	0.778	-0.066	3.98	0.016	0.016	0	43	40	58.9	134	125	0	34	32
2014	7	3	16	48	18	0.791	-0.082	3.98	0.01	0.007	0	43	40	58.5	134	125	0	34	32
2014	7	3	16	58	18	0.784	-0.062	3.98	0.01	0.007	0	43	40.4	58	134	125	0	34	31
2014	7	3	17	8	18	0.797	-0.079	3.976	0.013	0.01	0	43	40	60.6	134	124	0	34	31
2014	7	3	17	18	18	0.781	-0.095	3.976	0.01	0.007	0	42.6	40	58.9	133	124	0	34	31
2014	7	3	17	28	18	0.817	-0.056	3.976	0.01	0.007	0	42.6	39.6	71	133	123	0	34	31
2014	7	3	17	38	18	0.768	-0.062	3.976	0.016	0.013	0	42.1	39.1	68.4	132	123	0	34	32
2014	7	3	17	48	18	0.791	-0.082	3.976	0.01	0.007	0	42.6	39.1	59.3	133	123	0	34	32
2014	7	3	17	58	18	0.801	-0.062	3.976	0.013	0.01	0	43	39.6	67.1	133	123	0	33	31
2014	7	3	18	8	18	0.758	-0.075	3.976	0.01	0.007	0	42.1	38.7	65.4	132	123	0	34	33
2014	7	3	18	18	18	0.804	-0.033	3.976	0.013	0.01	0	42.6	39.1	56.8	133	123	0	34	32
2014	7	3	18	28	18	0.814	-0.082	3.976	0.01	0.007	0	42.1	39.6	63.2	132	123	0	34	31
2014	7	3	18	38	18	0.758	-0.092	3.976	0.013	0.01	0	43	39.6	62.4	134	123	0	34	31
2014	7	3	18	48	18	0.807	-0.085	3.976	0.013	0.01	0	42.6	39.1	58.9	133	123	0	34	32
2014	7	3	18	58	18	0.84	-0.102	3.976	0.01	0.007	0	42.6	39.1	60.6	133	123	0	34	32
2014	7	3	19	8	18	0.801	-0.095	3.976	0.01	0.007	0	42.6	39.1	58	132	123	0	33	32
2014	7	3	19	18	18	0.827	-0.115	3.976	0.01	0.007	0	42.6	39.1	60.2	133	123	0	34	32
2014	7	3	19	28	18	0.817	-0.098	3.976	0.013	0.01	0	42.6	39.1	60.6	133	123	0	34	32
2014	7	3	19	38	18	0.837	-0.095	3.976	0.013	0.01	0	42.6	39.6	67.5	133	124	0	34	32
2014	7	3	19	48	18	0.797	-0.072	3.973	0.016	0.016	0	43	40	61.9	134	124	0	34	31
2014	7	3	19	58	18	0.791	-0.098	3.976	0.013	0.01	0	42.6	39.1	70.5	133	123	0	34	32
2014	7	3	20	8	18	0.817	-0.115	3.973	0.01	0.007	0	43	40	69.7	134	124	0	34	31
2014	7	3	20	18	18	0.81	-0.062	3.976	0.01	0.007	0	43	40	70.1	134	124	0	34	31
2014	7	3	20	28	18	0.81	-0.098	3.976	0.01	0.007	0	43.9	40	66.2	136	124	0	34	31
2014	7	3	20	38	18	0.794	-0.062	3.976	0.013	0.01	0	43.4	39.1	74	135	123	0	34	32
2014	7	3	20	48	18	0.801	-0.069	3.976	0.013	0.01	0	43.4	39.1	73.5	135	123	0	34	32
2014	7	3	20	58	18	0.781	-0.075	3.976	0.01	0.007	0	43.4	39.1	73.5	135	123	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	3	21	8	18	0.817	-0.062	3.976	0.013	0.01	0	43	39.1	74.4	135	123	0	35	32
2014	7	3	21	18	18	0.869	-0.066	3.976	0.01	0.007	0	43.4	39.6	75.7	135	123	0	34	31
2014	7	3	21	28	18	0.863	-0.075	3.976	0.01	0.007	0	43	39.6	75.3	134	123	0	34	31
2014	7	3	21	38	18	0.846	-0.062	3.976	0.01	0.007	0	43	39.1	75.3	134	123	0	34	32
2014	7	3	21	48	18	0.83	-0.098	3.976	0.013	0.01	0	43	38.7	74.4	134	122	0	34	32
2014	7	3	21	58	18	0.823	-0.082	3.976	0.013	0.01	0	43	39.1	75.3	134	122	0	34	31
2014	7	3	22	8	18	0.837	-0.079	3.976	0.01	0.007	0	42.6	38.7	75.7	134	122	0	35	32
2014	7	3	22	18	18	0.81	-0.095	3.98	0.01	0.007	0	43.4	39.1	74.8	134	122	0	33	31
2014	7	3	22	28	18	0.82	-0.072	3.976	0.01	0.007	0	43	39.1	74.4	134	122	0	34	31
2014	7	3	22	38	18	0.833	-0.092	3.976	0.01	0.007	0	42.6	38.3	74.8	133	121	0	34	32
2014	7	3	22	48	18	0.781	-0.089	3.976	0.01	0.007	0	42.6	38.7	74	133	122	0	34	32
2014	7	3	22	58	18	0.83	-0.102	3.976	0.013	0.01	0	42.6	38.3	67.5	133	121	0	34	32
2014	7	3	23	8	18	0.81	-0.098	3.98	0.01	0.007	0	42.6	38.3	67.5	133	121	0	34	32
2014	7	3	23	18	18	0.814	-0.085	3.98	0.013	0.01	0	43	38.7	72.2	134	122	0	34	32
2014	7	3	23	28	18	0.856	-0.102	3.98	0.01	0.007	0	42.6	38.7	72.7	133	121	0	34	31
2014	7	3	23	38	18	0.81	-0.056	3.98	0.013	0.01	0	42.6	39.1	70.5	133	122	0	34	31
2014	7	3	23	48	18	0.784	-0.102	3.98	0.016	0.013	0	42.6	38.7	73.1	133	122	0	34	32
2014	7	3	23	58	18	0.82	-0.049	3.98	0.013	0.01	0	42.6	38.3	74	133	121	0	34	32
2014	7	4	0	8	18	0.827	-0.069	3.98	0.01	0.007	0	42.6	38.3	73.5	133	121	0	34	32
2014	7	4	0	18	18	0.758	-0.102	3.98	0.01	0.007	0	42.6	38.7	73.1	133	121	0	34	31
2014	7	4	0	28	18	0.833	-0.112	3.98	0.013	0.01	0	42.6	38.3	72.2	133	121	0	34	32
2014	7	4	0	38	18	0.801	-0.092	3.983	0.013	0.01	0	42.6	38.7	72.7	133	121	0	34	31
2014	7	4	0	48	18	0.843	-0.049	3.99	0.01	0.007	0	42.1	38.3	73.1	132	121	0	34	32
2014	7	4	0	58	18	0.814	-0.105	3.99	0.01	0.007	0	42.1	38.7	72.7	132	121	0	34	31
2014	7	4	1	8	18	0.784	-0.092	3.993	0.01	0.007	0	42.6	38.7	73.1	133	121	0	34	31
2014	7	4	1	18	18	0.827	-0.082	3.993	0.01	0.007	0	43	38.7	73.5	134	122	0	34	32
2014	7	4	1	28	18	0.83	-0.072	3.993	0.01	0.007	0	42.1	37.8	73.1	132	121	0	34	33
2014	7	4	1	38	18	0.846	-0.082	3.996	0.01	0.007	0	42.6	38.3	74	133	121	0	34	32
2014	7	4	1	48	18	0.843	-0.069	3.996	0.016	0.013	0	42.1	38.7	73.1	133	121	0	35	31
2014	7	4	1	58	18	0.853	-0.062	3.996	0.01	0.007	0	43	38.7	74	133	122	0	33	32
2014	7	4	2	8	18	0.823	-0.052	3.996	0.01	0.007	0	43	38.7	75.3	133	122	0	33	32
2014	7	4	2	18	18	0.853	-0.066	3.996	0.013	0.01	0	42.6	38.7	74.4	133	121	0	34	31
2014	7	4	2	28	18	0.83	-0.089	3.996	0.016	0.013	0	42.6	38.3	75.7	133	121	0	34	32
2014	7	4	2	38	18	0.814	-0.072	3.999	0.01	0.007	0	42.6	38.7	75.3	133	122	0	34	32
2014	7	4	2	48	18	0.83	-0.062	3.999	0.01	0.007	0	42.1	38.7	76.1	133	122	0	35	32
2014	7	4	2	58	18	0.814	-0.049	3.999	0.016	0.016	0	42.6	38.7	75.7	133	122	0	34	32
2014	7	4	3	8	18	0.833	-0.069	3.999	0.01	0.007	0	43	38.7	76.5	134	122	0	34	32
2014	7	4	3	18	18	0.837	-0.095	3.999	0.013	0.01	0	43	39.1	76.5	134	123	0	34	32
2014	7	4	3	28	18	0.846	-0.049	3.999	0.013	0.01	0	43.4	39.1	77	135	123	0	34	32
2014	7	4	3	38	18	0.843	-0.052	3.999	0.01	0.007	0	43	39.6	76.5	134	123	0	34	31
2014	7	4	3	48	18	0.81	-0.092	3.999	0.01	0.007	0	43	39.1	75.7	134	123	0	34	32
2014	7	4	3	58	18	0.82	-0.082	3.999	0.01	0.007	0	42.6	38.7	76.1	134	122	0	35	32
2014	7	4	4	8	18	0.84	-0.072	3.999	0.016	0.013	0	43	39.1	76.5	134	123	0	34	32
2014	7	4	4	18	18	0.84	-0.082	3.999	0.01	0.007	0	43.4	40	76.1	135	124	0	34	31
2014	7	4	4	28	18	0.807	-0.098	3.999	0.01	0.007	0	43.4	39.6	76.1	135	123	0	34	31
2014	7	4	4	38	18	0.846	-0.089	4.003	0.01	0.007	0	43.4	39.1	76.5	135	123	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	4	48	18	0.84	-0.079	4.003	0.013	0.01	0	43	39.6	75.7	135	124	0	35	32
2014	7	4	4	58	18	0.833	-0.079	4.003	0.01	0.007	0	43.4	39.1	77	135	123	0	34	32
2014	7	4	5	8	18	0.82	-0.079	4.003	0.01	0.007	0	43.9	39.6	76.1	136	124	0	34	32
2014	7	4	5	18	18	0.817	-0.069	4.003	0.013	0.01	0	43	39.6	76.5	135	124	0	35	32
2014	7	4	5	28	18	0.833	-0.072	4.003	0.016	0.013	0	43.4	39.1	76.1	135	124	0	34	33
2014	7	4	5	38	18	0.866	-0.052	4.003	0.013	0.01	0	43.9	39.6	76.5	136	124	0	34	32
2014	7	4	5	48	18	0.856	-0.089	4.003	0.016	0.013	0	43.9	39.6	75.3	136	124	0	34	32
2014	7	4	5	58	18	0.817	-0.059	4.003	0.01	0.007	0	44.3	40	76.1	137	125	0	34	32
2014	7	4	6	8	18	0.83	-0.056	4.003	0.01	0.007	0	43.9	38.7	75.7	136	123	0	34	33
2014	7	4	6	18	18	0.837	-0.085	4.003	0.01	0.007	0	43.9	39.1	74.8	136	123	0	34	32
2014	7	4	6	28	18	0.817	-0.095	4.003	0.01	0.007	0	43.9	38.7	75.7	136	123	0	34	33
2014	7	4	6	38	18	0.81	-0.085	4.003	0.01	0.007	0	43.4	39.1	75.3	135	123	0	34	32
2014	7	4	6	48	18	0.863	-0.085	4.003	0.01	0.007	0	43.4	38.7	75.3	136	122	0	35	32
2014	7	4	6	58	18	0.81	-0.052	4.003	0.013	0.01	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	4	7	8	18	0.84	-0.082	4.006	0.016	0.013	0	43.4	39.1	74.8	136	123	0	35	32
2014	7	4	7	18	18	0.84	-0.062	4.006	0.013	0.01	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	4	7	28	18	0.823	-0.098	4.006	0.01	0.007	0	43	39.1	74.4	135	123	0	35	32
2014	7	4	7	38	18	0.817	-0.072	4.006	0.016	0.013	0	43.4	39.6	74.8	136	123	0	35	31
2014	7	4	7	48	18	0.856	-0.082	4.006	0.01	0.007	0	43.9	39.1	74	136	123	0	34	32
2014	7	4	7	58	18	0.83	-0.082	4.006	0.016	0.013	0	43.9	39.1	74.4	136	123	0	34	32
2014	7	4	8	8	18	0.807	-0.089	4.006	0.013	0.01	0	44.3	39.6	72.7	137	124	0	34	32
2014	7	4	8	18	18	0.807	-0.066	4.006	0.01	0.007	0	43.9	40	73.5	137	124	0	35	31
2014	7	4	8	28	18	0.804	-0.092	4.009	0.01	0.007	0	44.3	39.6	73.5	137	124	0	34	32
2014	7	4	8	38	18	0.817	-0.079	4.009	0.01	0.007	0	43.9	39.6	71.8	137	124	0	35	32
2014	7	4	8	48	18	0.84	-0.046	4.009	0.013	0.01	0	44.3	39.1	73.1	137	124	0	34	33
2014	7	4	8	58	18	0.784	-0.089	4.009	0.01	0.007	0	44.3	39.6	73.1	137	125	0	34	33
2014	7	4	9	8	18	0.83	-0.082	4.009	0.01	0.007	0	44.3	40	67.9	137	125	0	34	32
2014	7	4	9	18	18	0.764	-0.112	4.009	0.01	0.007	0	44.3	40	69.2	137	125	0	34	32
2014	7	4	9	28	18	0.768	-0.056	4.009	0.01	0.007	0	44.3	39.6	68.4	137	124	0	34	32
2014	7	4	9	38	18	0.781	-0.108	4.009	0.01	0.007	0	44.3	40	60.6	137	125	0	34	32
2014	7	4	9	48	18	0.801	-0.098	4.012	0.01	0.007	0	43.9	39.6	71.4	137	125	0	35	33
2014	7	4	9	58	18	0.804	-0.128	4.009	0.01	0.007	0	43.4	40	70.1	136	125	0	35	32
2014	7	4	10	8	18	0.768	-0.098	4.009	0.01	0.007	0	43.9	40	61.9	136	125	0	34	32
2014	7	4	10	18	18	0.758	-0.095	4.012	0.01	0.007	0	43.9	40	52.9	137	125	0	35	32
2014	7	4	10	28	18	0.784	-0.072	4.012	0.01	0.007	0	44.3	39.1	59.3	137	124	0	34	33
2014	7	4	10	38	18	0.791	-0.105	4.009	0.016	0.013	0	44.3	40	61.1	137	125	0	34	32
2014	7	4	10	48	18	0.791	-0.115	4.012	0.013	0.01	0	43.9	39.6	56.3	137	124	0	35	32
2014	7	4	10	58	18	0.817	-0.102	4.012	0.01	0.007	0	44.3	40	56.8	137	125	0	34	32
2014	7	4	11	8	18	0.778	-0.059	4.016	0.01	0.007	0	43.4	39.6	54.2	136	124	0	35	32
2014	7	4	11	18	18	0.784	-0.079	4.012	0.013	0.01	0	43.9	40	53.8	137	125	0	35	32
2014	7	4	11	28	18	0.768	-0.082	4.012	0.01	0.007	0	44.7	40	55.5	138	125	0	34	32
2014	7	4	11	38	18	0.764	-0.082	4.012	0.01	0.007	0	44.3	40	56.3	137	125	0	34	32
2014	7	4	11	48	18	0.764	-0.089	4.012	0.01	0.007	0	43.4	39.6	54.2	136	124	0	35	32
2014	7	4	11	58	18	0.794	-0.079	4.012	0.01	0.007	0	43.4	39.6	55.5	136	124	0	35	32
2014	7	4	12	8	18	0.797	-0.082	4.012	0.013	0.01	0	43	39.1	56.8	135	123	0	35	32
2014	7	4	12	18	18	0.758	-0.066	4.012	0.01	0.007	0	43.4	39.1	55.5	135	123	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	12	28	18	0.794	-0.125	4.012	0.01	0.007	0	43.4	39.6	55	136	124	0	35	32
2014	7	4	12	38	18	0.755	-0.102	4.012	0.01	0.007	0	43.4	39.1	54.6	135	123	0	34	32
2014	7	4	12	48	18	0.768	-0.092	4.012	0.016	0.013	0	44.3	40	55	136	124	0	33	31
2014	7	4	12	58	18	0.774	-0.066	4.012	0.013	0.01	0	43.9	39.6	57.2	136	124	0	34	32
2014	7	4	13	8	18	0.801	-0.095	4.009	0.01	0.007	0	43.9	40	55.5	136	124	0	34	31
2014	7	4	13	18	18	0.768	-0.082	4.012	0.013	0.01	0	44.3	39.6	58	137	124	0	34	32
2014	7	4	13	28	18	0.791	-0.098	4.009	0.01	0.007	0	43.9	39.1	55.9	136	124	0	34	33
2014	7	4	13	38	18	0.758	-0.089	4.009	0.013	0.01	0	43.4	39.6	57.6	135	123	0	34	31
2014	7	4	13	48	18	0.758	-0.075	4.009	0.01	0.007	0	43.9	39.6	55.5	137	125	0	35	33
2014	7	4	13	58	18	0.745	-0.069	4.009	0.013	0.01	0	44.3	40	57.2	137	125	0	34	32
2014	7	4	14	8	18	0.771	-0.095	4.009	0.013	0.01	0	44.3	39.6	58	137	124	0	34	32
2014	7	4	14	18	18	0.778	-0.075	4.009	0.01	0.007	0	43.9	39.6	56.8	136	124	0	34	32
2014	7	4	14	28	18	0.764	-0.095	4.009	0.013	0.01	0	43.4	39.1	56.3	135	123	0	34	32
2014	7	4	14	38	18	0.787	-0.082	4.009	0.013	0.01	0	43.4	39.6	56.3	135	123	0	34	31
2014	7	4	14	48	18	0.771	-0.098	4.009	0.01	0.007	0	43.4	39.1	54.6	135	122	0	34	31
2014	7	4	14	58	18	0.764	-0.098	4.006	0.013	0.01	0	43.4	38.7	56.3	135	122	0	34	32
2014	7	4	15	8	18	0.787	-0.062	4.009	0.013	0.01	0	43	38.7	58	134	121	0	34	31
2014	7	4	15	18	18	0.781	-0.089	4.006	0.013	0.01	0	43	39.1	58	134	122	0	34	31
2014	7	4	15	28	18	0.778	-0.098	4.006	0.01	0.007	0	43	39.1	56.3	134	122	0	34	31
2014	7	4	15	38	18	0.791	-0.085	4.006	0.01	0.007	0	43.4	39.6	60.6	136	124	0	35	32
2014	7	4	15	48	18	0.791	-0.075	4.006	0.01	0.007	0	43.4	38.7	54.6	135	123	0	34	33
2014	7	4	15	58	18	0.846	-0.092	4.006	0.01	0.007	0	43.4	39.1	58.9	136	123	0	35	32
2014	7	4	16	8	18	0.774	-0.069	4.006	0.013	0.01	0	43.4	39.1	59.8	135	123	0	34	32
2014	7	4	16	18	18	0.797	-0.072	4.006	0.016	0.013	0	43.4	39.6	55.9	135	123	0	34	31
2014	7	4	16	28	18	0.771	-0.105	4.003	0.013	0.01	0	43	39.1	57.6	134	122	0	34	31
2014	7	4	16	38	18	0.787	-0.072	4.003	0.01	0.007	0	43	38.7	57.2	134	122	0	34	32
2014	7	4	16	48	18	0.774	-0.098	4.003	0.01	0.007	0	43	39.6	56.8	135	123	0	35	31
2014	7	4	16	58	18	0.768	-0.098	3.999	0.01	0.007	0	43.4	39.1	57.2	135	122	0	34	31
2014	7	4	17	8	18	0.781	-0.066	4.003	0.013	0.01	0	43.4	39.1	56.8	135	123	0	34	32
2014	7	4	17	18	18	0.781	-0.089	3.999	0.016	0.013	0	43.4	39.6	55.5	135	123	0	34	31
2014	7	4	17	28	18	0.817	-0.102	4.003	0.01	0.007	0	43.4	39.1	61.9	135	123	0	34	32
2014	7	4	17	38	18	0.817	-0.095	4.003	0.013	0.01	0	43.9	39.6	55.5	136	124	0	34	32
2014	7	4	17	48	18	0.81	-0.095	3.999	0.01	0.007	0	43.9	39.1	55.5	136	123	0	34	32
2014	7	4	17	58	18	0.797	-0.062	3.999	0.016	0.013	0	43.9	39.1	55.9	136	123	0	34	32
2014	7	4	18	8	18	0.823	-0.085	3.999	0.01	0.007	0	43.9	39.6	58.5	136	123	0	34	31
2014	7	4	18	18	18	0.801	-0.062	3.999	0.013	0.01	0	43.4	39.1	54.2	135	123	0	34	32
2014	7	4	18	28	18	0.768	-0.059	3.999	0.016	0.013	0	43.4	39.1	53.3	135	123	0	34	32
2014	7	4	18	38	18	0.791	-0.052	3.996	0.01	0.007	0	43.4	38.7	58.5	135	122	0	34	32
2014	7	4	18	48	18	0.804	-0.105	3.996	0.01	0.007	0	43.4	39.1	60.2	135	123	0	34	32
2014	7	4	18	58	18	0.794	-0.079	3.999	0.01	0.007	0	43.9	39.1	54.6	136	123	0	34	32
2014	7	4	19	8	18	0.814	-0.062	3.999	0.013	0.01	0	43.4	40	55.9	136	124	0	35	31
2014	7	4	19	18	18	0.801	-0.095	3.999	0.01	0.007	0	44.7	39.6	55.5	137	124	0	33	32
2014	7	4	19	28	18	0.797	-0.056	3.999	0.013	0.01	0	44.3	39.6	55.5	137	124	0	34	32
2014	7	4	19	38	18	0.791	-0.059	3.999	0.01	0.007	0	43.9	39.1	63.6	136	123	0	34	32
2014	7	4	19	48	18	0.801	-0.085	4.003	0.013	0.01	0	43	39.6	70.1	135	123	0	35	31
2014	7	4	19	58	18	0.778	-0.062	3.999	0.013	0.01	0	43.9	39.6	60.2	136	123	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	4	20	8	18	0.814	-0.062	3.999	0.01	0.007	0	43.4	39.1	71.4	135	123	0	34	32
2014	7	4	20	18	18	0.84	-0.052	4.003	0.016	0.013	0	43.4	39.1	72.7	135	123	0	34	32
2014	7	4	20	28	18	0.814	-0.059	4.003	0.013	0.01	0	43.9	39.6	74	136	124	0	34	32
2014	7	4	20	38	18	0.863	-0.089	4.003	0.01	0.007	0	43.9	40	71	136	124	0	34	31
2014	7	4	20	48	18	0.791	-0.069	4.003	0.01	0.007	0	44.3	40	65.4	137	125	0	34	32
2014	7	4	20	58	18	0.837	-0.056	4.003	0.01	0.007	0	44.3	39.6	71.8	137	124	0	34	32
2014	7	4	21	8	18	0.83	-0.082	4.003	0.01	0.007	0	44.3	39.6	75.3	136	123	0	33	31
2014	7	4	21	18	18	0.82	-0.056	4.006	0.01	0.007	0	43.9	39.1	75.7	136	123	0	34	32
2014	7	4	21	28	18	0.82	-0.056	4.006	0.016	0.013	0	43.9	39.6	76.1	135	123	0	33	31
2014	7	4	21	38	18	0.801	-0.095	4.006	0.01	0.007	0	43.4	39.6	75.7	135	123	0	34	31
2014	7	4	21	48	18	0.814	-0.069	4.006	0.013	0.01	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	4	21	58	18	0.817	-0.092	4.006	0.01	0.007	0	43.4	38.7	76.1	135	122	0	34	32
2014	7	4	22	8	18	0.853	-0.095	4.006	0.013	0.01	0	43.4	38.7	77	135	122	0	34	32
2014	7	4	22	18	18	0.81	-0.089	4.006	0.01	0.007	0	43.4	39.1	77	135	122	0	34	31
2014	7	4	22	28	18	0.827	-0.089	4.006	0.013	0.01	0	43	38.7	77.4	134	122	0	34	32
2014	7	4	22	38	18	0.85	-0.085	4.006	0.013	0.01	0	43	38.7	77.4	134	121	0	34	31
2014	7	4	22	48	18	0.814	-0.092	4.006	0.013	0.01	0	43	39.1	76.1	134	122	0	34	31
2014	7	4	22	58	18	0.82	-0.046	4.009	0.01	0.007	0	42.6	38.3	76.5	134	121	0	35	32
2014	7	4	23	8	18	0.823	-0.082	4.006	0.01	0.007	0	43	39.1	73.1	134	122	0	34	31
2014	7	4	23	18	18	0.787	-0.089	4.006	0.016	0.013	0	43	38.7	76.5	134	122	0	34	32
2014	7	4	23	28	18	0.774	-0.125	4.009	0.013	0.01	0	43	39.1	76.1	134	122	0	34	31
2014	7	4	23	38	18	0.781	-0.098	4.006	0.013	0.01	0	43	38.7	77	134	122	0	34	32
2014	7	4	23	48	18	0.82	-0.066	4.009	0.01	0.007	0	43	39.1	76.5	134	122	0	34	31
2014	7	4	23	58	18	0.827	-0.082	4.009	0.01	0.007	0	43	38.3	77.4	134	121	0	34	32
2014	7	5	0	8	18	0.837	-0.072	4.009	0.01	0.007	0	42.6	38.7	77	134	121	0	35	31
2014	7	5	0	18	18	0.827	-0.072	4.009	0.01	0.007	0	43.4	39.1	77	135	122	0	34	31
2014	7	5	0	28	18	0.817	-0.085	4.009	0.01	0.007	0	43	38.7	77	135	122	0	35	32
2014	7	5	0	38	18	0.869	-0.082	4.009	0.01	0.007	0	43	38.3	77	134	121	0	34	32
2014	7	5	0	48	18	0.837	-0.072	4.009	0.013	0.01	0	43	39.1	76.5	134	122	0	34	31
2014	7	5	0	58	18	0.82	-0.089	4.009	0.01	0.007	0	42.6	39.1	76.1	134	122	0	35	31
2014	7	5	1	8	18	0.82	-0.072	4.009	0.01	0.007	0	43.4	38.7	75.7	135	122	0	34	32
2014	7	5	1	18	18	0.81	-0.059	4.009	0.01	0.007	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	5	1	28	18	0.814	-0.095	4.009	0.01	0.007	0	43	38.7	76.1	135	122	0	35	32
2014	7	5	1	38	18	0.804	-0.082	4.009	0.01	0.007	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	5	1	48	18	0.814	-0.072	4.012	0.01	0.007	0	43	38.7	75.7	134	122	0	34	32
2014	7	5	1	58	18	0.801	-0.062	4.012	0.01	0.007	0	43	38.7	76.1	135	122	0	35	32
2014	7	5	2	8	18	0.84	-0.079	4.012	0.01	0.007	0	43.4	39.1	74.4	135	122	0	34	31
2014	7	5	2	18	18	0.846	-0.079	4.012	0.01	0.007	0	43	38.7	75.3	134	122	0	34	32
2014	7	5	2	28	18	0.823	-0.115	4.012	0.01	0.007	0	43.4	39.1	74.8	135	122	0	34	31
2014	7	5	2	38	18	0.86	-0.085	4.016	0.01	0.007	0	43	38.7	74.4	135	122	0	35	32
2014	7	5	2	48	18	0.837	-0.095	4.016	0.013	0.01	0	43.4	39.1	74	135	122	0	34	31
2014	7	5	2	58	18	0.801	-0.092	4.016	0.01	0.007	0	43.4	39.1	74	135	123	0	34	32
2014	7	5	3	8	18	0.797	-0.105	4.016	0.01	0.007	0	43.4	39.1	73.5	135	123	0	34	32
2014	7	5	3	18	18	0.827	-0.059	4.016	0.013	0.01	0	43.4	38.7	73.5	135	122	0	34	32
2014	7	5	3	28	18	0.84	-0.108	4.016	0.01	0.007	0	43.4	38.7	72.2	135	122	0	34	32
2014	7	5	3	38	18	0.837	-0.075	4.019	0.01	0.007	0	43.4	38.3	71.8	135	122	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	3	48	18	0.843	-0.046	4.026	0.013	0.01	0	43.4	39.1	73.1	135	123	0	34	32
2014	7	5	3	58	18	0.856	-0.075	4.026	0.013	0.01	0	43.4	38.7	72.7	135	122	0	34	32
2014	7	5	4	8	18	0.827	-0.112	4.029	0.01	0.007	0	43.4	38.7	73.1	135	122	0	34	32
2014	7	5	4	18	18	0.837	-0.079	4.029	0.01	0.007	0	43.4	39.1	73.1	135	123	0	34	32
2014	7	5	4	28	18	0.846	-0.098	4.032	0.01	0.007	0	43.9	39.1	73.5	136	123	0	34	32
2014	7	5	4	38	18	0.853	-0.095	4.032	0.013	0.01	0	43	39.1	73.5	135	123	0	35	32
2014	7	5	4	48	18	0.781	-0.082	4.032	0.01	0.007	0	43.4	39.6	74.4	136	123	0	35	31
2014	7	5	4	58	18	0.817	-0.079	4.032	0.013	0.01	0	43.9	39.6	74.8	136	124	0	34	32
2014	7	5	5	8	18	0.86	-0.075	4.032	0.013	0.01	0	43.9	40	74.4	136	124	0	34	31
2014	7	5	5	18	18	0.833	-0.079	4.035	0.013	0.01	0	43.9	40	75.3	136	124	0	34	31
2014	7	5	5	28	18	0.86	-0.095	4.035	0.01	0.007	0	44.3	39.6	75.7	137	124	0	34	32
2014	7	5	5	38	18	0.817	-0.095	4.035	0.01	0.007	0	44.3	39.6	75.7	137	124	0	34	32
2014	7	5	5	48	18	0.843	-0.085	4.035	0.01	0.007	0	44.3	39.6	75.7	137	124	0	34	32
2014	7	5	5	58	18	0.823	-0.062	4.035	0.01	0.007	0	44.3	40	76.5	137	125	0	34	32
2014	7	5	6	8	18	0.833	-0.079	4.035	0.01	0.007	0	44.3	39.6	76.5	137	124	0	34	32
2014	7	5	6	18	18	0.804	-0.108	4.039	0.01	0.007	0	44.3	39.6	76.1	137	124	0	34	32
2014	7	5	6	28	18	0.853	-0.085	4.035	0.013	0.01	0	43.4	40	77	136	124	0	35	31
2014	7	5	6	38	18	0.837	-0.079	4.039	0.01	0.007	0	43.9	39.1	76.1	136	123	0	34	32
2014	7	5	6	48	18	0.837	-0.092	4.039	0.01	0.007	0	43.9	39.1	77	136	123	0	34	32
2014	7	5	6	58	18	0.801	-0.046	4.039	0.01	0.007	0	43.4	39.1	76.5	136	123	0	35	32
2014	7	5	7	8	18	0.837	-0.092	4.039	0.01	0.007	0	43	39.1	77	135	123	0	35	32
2014	7	5	7	18	18	0.846	-0.105	4.039	0.016	0.013	0	43	39.1	76.5	135	123	0	35	32
2014	7	5	7	28	18	0.843	-0.092	4.039	0.01	0.007	0	43	38.7	75.7	135	122	0	35	32
2014	7	5	7	38	18	0.84	-0.056	4.039	0.01	0.007	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	5	7	48	18	0.801	-0.072	4.039	0.016	0.016	0	43.4	39.6	76.5	135	123	0	34	31
2014	7	5	7	58	18	0.879	-0.105	4.039	0.013	0.01	0	43.4	38.7	76.1	135	122	0	34	32
2014	7	5	8	8	18	0.801	-0.082	4.039	0.01	0.007	0	43.4	38.7	76.5	135	123	0	34	33
2014	7	5	8	18	18	0.856	-0.089	4.039	0.013	0.01	0	43.4	39.1	75.3	135	123	0	34	32
2014	7	5	8	28	18	0.823	-0.066	4.039	0.01	0.007	0	42.6	38.7	76.5	134	122	0	35	32
2014	7	5	8	38	18	0.837	-0.079	4.042	0.016	0.013	0	43	38.7	76.1	134	122	0	34	32
2014	7	5	8	48	18	0.804	-0.039	4.042	0.013	0.01	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	5	8	58	18	0.823	-0.072	4.042	0.01	0.007	0	43.4	38.7	76.5	135	123	0	34	33
2014	7	5	9	8	18	0.84	-0.082	4.042	0.01	0.007	0	43.4	39.6	76.1	135	123	0	34	31
2014	7	5	9	18	18	0.83	-0.089	4.042	0.01	0.007	0	43.4	39.1	75.7	135	123	0	34	32
2014	7	5	9	28	18	0.801	-0.079	4.042	0.01	0.007	0	43.4	39.6	74.8	135	123	0	34	31
2014	7	5	9	38	18	0.784	-0.092	4.042	0.01	0.007	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	5	9	48	18	0.787	-0.085	4.042	0.01	0.007	0	43.9	40	74.8	136	124	0	34	31
2014	7	5	9	58	18	0.837	-0.092	4.042	0.013	0.01	0	43.4	39.6	76.1	136	124	0	35	32
2014	7	5	10	8	18	0.768	-0.112	4.042	0.01	0.007	0	43.4	39.6	72.7	135	124	0	34	32
2014	7	5	10	18	18	0.797	-0.066	4.045	0.01	0.007	0	43	39.1	75.7	135	123	0	35	32
2014	7	5	10	28	18	0.764	-0.089	4.045	0.01	0.007	0	43.9	39.6	75.7	135	123	0	33	31
2014	7	5	10	38	18	0.797	-0.095	4.045	0.013	0.01	0	43.4	39.1	75.7	135	123	0	34	32
2014	7	5	10	48	18	0.787	-0.075	4.045	0.01	0.007	0	43	39.1	75.7	134	122	0	34	31
2014	7	5	10	58	18	0.781	-0.098	4.045	0.013	0.01	0	42.6	38.7	72.7	134	122	0	35	32
2014	7	5	11	8	18	0.784	-0.092	4.045	0.01	0.007	0	42.6	38.3	75.7	134	122	0	35	33
2014	7	5	11	18	18	0.781	-0.079	4.045	0.01	0.007	0	42.6	38.3	76.1	133	121	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	11	28	18	0.817	-0.079	4.045	0.013	0.01	0	43	38.7	75.3	134	122	0	34	32
2014	7	5	11	38	18	0.771	-0.079	4.045	0.01	0.007	0	42.6	38.3	69.7	133	121	0	34	32
2014	7	5	11	48	18	0.801	-0.102	4.045	0.01	0.007	0	42.6	38.3	68.8	133	121	0	34	32
2014	7	5	11	58	18	0.801	-0.108	4.045	0.01	0.007	0	42.6	38.3	60.2	134	121	0	35	32
2014	7	5	12	8	18	0.794	-0.095	4.045	0.01	0.007	0	43	38.3	68.8	134	121	0	34	32
2014	7	5	12	18	18	0.794	-0.092	4.045	0.01	0.007	0	42.6	38.3	65.8	133	121	0	34	32
2014	7	5	12	28	18	0.787	-0.082	4.045	0.016	0.013	0	42.6	38.7	71	133	121	0	34	31
2014	7	5	12	38	18	0.797	-0.115	4.045	0.013	0.01	0	42.1	37.8	68.4	132	120	0	34	32
2014	7	5	12	48	18	0.81	-0.092	4.049	0.013	0.01	0	42.1	37.8	77	132	120	0	34	32
2014	7	5	12	58	18	0.764	-0.112	4.045	0.01	0.007	0	41.7	38.3	64.1	132	120	0	35	31
2014	7	5	13	8	18	0.778	-0.098	4.049	0.013	0.01	0	41.7	37	68.4	131	118	0	34	32
2014	7	5	13	18	18	0.774	-0.075	4.045	0.013	0.01	0	41.7	37.8	66.7	131	119	0	34	31
2014	7	5	13	28	18	0.797	-0.112	4.049	0.01	0.007	0	41.7	37.8	66.7	131	119	0	34	31
2014	7	5	13	38	18	0.807	-0.095	4.049	0.01	0.007	0	41.7	37.4	70.5	131	119	0	34	32
2014	7	5	13	48	18	0.784	-0.085	4.049	0.013	0.01	0	41.7	37.4	66.7	131	119	0	34	32
2014	7	5	13	58	18	0.814	-0.066	4.049	0.013	0.01	0	42.1	37.8	67.9	132	120	0	34	32
2014	7	5	14	8	18	0.801	-0.082	4.049	0.01	0.007	0	42.1	37.4	65.8	132	119	0	34	32
2014	7	5	14	18	18	0.817	-0.102	4.049	0.013	0.01	0	41.7	37.8	74	131	119	0	34	31
2014	7	5	14	28	18	0.817	-0.085	4.049	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	5	14	38	18	0.814	-0.102	4.049	0.016	0.013	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	5	14	48	18	0.774	-0.092	4.049	0.01	0.007	0	41.3	37.8	76.5	131	119	0	35	31
2014	7	5	14	58	18	0.817	-0.108	4.049	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	5	15	8	18	0.82	-0.079	4.049	0.01	0.007	0	41.3	37	65.4	130	118	0	34	32
2014	7	5	15	18	18	0.82	-0.062	4.049	0.013	0.01	0	41.7	37.4	76.1	131	119	0	34	32
2014	7	5	15	28	18	0.817	-0.062	4.049	0.01	0.007	0	42.1	37.8	76.1	131	119	0	33	31
2014	7	5	15	38	18	0.807	-0.098	4.045	0.01	0.007	0	41.7	37	60.2	131	118	0	34	32
2014	7	5	15	48	18	0.85	-0.085	4.045	0.01	0.007	0	42.1	37.8	67.9	132	119	0	34	31
2014	7	5	15	58	18	0.791	-0.085	4.045	0.01	0.007	0	42.1	38.3	67.9	132	120	0	34	31
2014	7	5	16	8	18	0.807	-0.115	4.045	0.013	0.01	0	42.1	37.4	59.3	132	119	0	34	32
2014	7	5	16	18	18	0.814	-0.098	4.042	0.013	0.01	0	42.1	37.8	53.3	132	120	0	34	32
2014	7	5	16	28	18	0.81	-0.095	4.039	0.013	0.01	0	42.1	37.8	49.9	132	120	0	34	32
2014	7	5	16	38	18	0.778	-0.095	4.042	0.01	0.007	0	42.1	37.8	51.2	132	119	0	34	31
2014	7	5	16	48	18	0.794	-0.105	4.045	0.01	0.007	0	42.1	38.3	65.4	132	120	0	34	31
2014	7	5	16	58	18	0.833	-0.089	4.039	0.013	0.01	0	42.6	37.8	52	133	120	0	34	32
2014	7	5	17	8	18	0.82	-0.052	4.045	0.01	0.007	0	44.3	39.1	51.2	137	122	0	34	31
2014	7	5	17	18	18	0.741	-0.069	4.042	0.013	0.01	0	43.9	39.6	54.2	136	123	0	34	31
2014	7	5	17	28	18	0.797	-0.098	4.042	0.01	0.007	0	43.4	39.6	55	135	123	0	34	31
2014	7	5	17	38	18	0.801	-0.059	4.039	0.01	0.007	0	46.4	42.6	51.6	142	130	0	34	31
2014	7	5	17	48	18	0.794	-0.049	4.042	0.01	0.007	0	44.7	40.9	55.5	138	126	0	34	31
2014	7	5	17	58	18	0.804	-0.059	4.039	0.01	0.007	0	45.6	42.1	54.2	140	129	0	34	31
2014	7	5	18	8	18	0.801	-0.082	4.042	0.01	0.007	0	45.2	40.9	55	139	126	0	34	31
2014	7	5	18	18	18	0.837	-0.092	4.042	0.01	0.007	0	44.3	40.4	53.3	137	125	0	34	31
2014	7	5	18	28	18	0.781	-0.085	4.042	0.01	0.007	0	44.3	40	58	136	124	0	33	31
2014	7	5	18	38	18	0.837	-0.066	4.039	0.01	0.007	0	46.4	42.1	51.2	142	129	0	34	31
2014	7	5	18	48	18	0.807	-0.062	4.042	0.01	0.007	0	43.9	39.1	56.8	136	123	0	34	32
2014	7	5	18	58	18	0.807	-0.059	4.042	0.01	0.007	0	43.9	39.6	57.6	136	123	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	5	19	8	18	0.82	-0.052	4.042	0.01	0.007	0	43.4	39.1	59.8	135	123	0	34	32
2014	7	5	19	18	18	0.823	-0.098	4.045	0.01	0.007	0	43.9	39.1	64.1	136	123	0	34	32
2014	7	5	19	28	18	0.751	-0.095	4.039	0.01	0.007	0	44.3	40	52	137	125	0	34	32
2014	7	5	19	38	18	0.791	-0.052	4.042	0.01	0.007	0	45.6	40.9	52.5	140	127	0	34	32
2014	7	5	19	48	18	0.804	-0.062	4.042	0.01	0.007	0	45.6	41.7	52.5	140	128	0	34	31
2014	7	5	19	58	18	0.794	-0.079	4.045	0.01	0.007	0	45.2	40.9	50.7	139	126	0	34	31
2014	7	5	20	8	18	0.781	-0.098	4.045	0.01	0.007	0	44.7	40.9	58.9	138	126	0	34	31
2014	7	5	20	18	18	0.823	-0.082	4.045	0.01	0.007	0	44.7	40.9	61.9	138	126	0	34	31
2014	7	5	20	28	18	0.827	-0.066	4.045	0.01	0.007	0	44.3	40.4	58.9	137	125	0	34	31
2014	7	5	20	38	18	0.807	-0.062	4.045	0.013	0.01	0	44.3	40	58	137	125	0	34	32
2014	7	5	20	48	18	0.787	-0.072	4.045	0.01	0.007	0	43.9	40	56.8	136	124	0	34	31
2014	7	5	20	58	18	0.774	-0.052	4.045	0.01	0.007	0	44.3	40	53.8	137	125	0	34	32
2014	7	5	21	8	18	0.837	-0.079	4.045	0.01	0.007	0	44.3	40.4	58.9	137	125	0	34	31
2014	7	5	21	18	18	0.794	-0.072	4.049	0.01	0.007	0	43.9	39.6	66.2	136	124	0	34	32
2014	7	5	21	28	18	0.86	-0.089	4.049	0.013	0.01	0	43.9	39.6	70.5	135	123	0	33	31
2014	7	5	21	38	18	0.797	-0.075	4.049	0.013	0.01	0	43.4	38.7	72.7	135	122	0	34	32
2014	7	5	21	48	18	0.86	-0.056	4.049	0.01	0.007	0	43	38.7	76.1	134	122	0	34	32
2014	7	5	21	58	18	0.81	-0.082	4.052	0.01	0.007	0	43	38.7	74.8	134	122	0	34	32
2014	7	5	22	8	18	0.81	-0.098	4.052	0.01	0.007	0	43	38.3	74.4	134	121	0	34	32
2014	7	5	22	18	18	0.84	-0.092	4.052	0.013	0.01	0	43	39.1	76.1	134	122	0	34	31
2014	7	5	22	28	18	0.814	-0.085	4.052	0.01	0.007	0	43	38.7	77	133	121	0	33	31
2014	7	5	22	38	18	0.82	-0.079	4.052	0.01	0.007	0	42.6	38.3	77	134	121	0	35	32
2014	7	5	22	48	18	0.86	-0.079	4.052	0.013	0.01	0	42.6	38.3	77	133	121	0	34	32
2014	7	5	22	58	18	0.804	-0.095	4.052	0.01	0.007	0	43	38.3	77.4	134	121	0	34	32
2014	7	5	23	8	18	0.833	-0.098	4.052	0.01	0.007	0	42.6	38.7	76.5	133	121	0	34	31
2014	7	5	23	18	18	0.82	-0.056	4.052	0.013	0.01	0	42.6	38.3	77	133	121	0	34	32
2014	7	5	23	28	18	0.83	-0.075	4.052	0.01	0.007	0	42.6	38.7	77.4	133	121	0	34	31
2014	7	5	23	38	18	0.81	-0.082	4.052	0.013	0.01	0	43	38.7	77	134	121	0	34	31
2014	7	5	23	48	18	0.817	-0.062	4.052	0.013	0.01	0	42.6	38.7	77	133	121	0	34	31
2014	7	5	23	58	18	0.827	-0.095	4.052	0.01	0.007	0	42.1	38.3	77	133	121	0	35	32
2014	7	6	0	8	18	0.823	-0.082	4.052	0.01	0.007	0	42.6	38.3	77.4	133	120	0	34	31
2014	7	6	0	18	18	0.84	-0.082	4.055	0.01	0.007	0	42.1	38.7	76.1	132	121	0	34	31
2014	7	6	0	28	18	0.83	-0.092	4.055	0.01	0.007	0	42.6	38.7	77	133	121	0	34	31
2014	7	6	0	38	18	0.837	-0.095	4.055	0.013	0.01	0	42.6	38.3	77	133	121	0	34	32
2014	7	6	0	48	18	0.889	-0.108	4.055	0.01	0.007	0	42.6	38.3	76.5	133	120	0	34	31
2014	7	6	0	58	18	0.83	-0.072	4.055	0.01	0.007	0	42.1	37.8	76.1	132	120	0	34	32
2014	7	6	1	8	18	0.866	-0.069	4.055	0.01	0.007	0	42.1	37.8	76.1	132	120	0	34	32
2014	7	6	1	18	18	0.866	-0.069	4.055	0.01	0.007	0	42.1	37.8	76.1	132	120	0	34	32
2014	7	6	1	28	18	0.83	-0.089	4.055	0.01	0.007	0	42.6	38.3	75.3	133	121	0	34	32
2014	7	6	1	38	18	0.833	-0.059	4.058	0.01	0.007	0	42.6	38.3	74.8	133	121	0	34	32
2014	7	6	1	48	18	0.82	-0.062	4.058	0.01	0.007	0	43	38.7	75.3	134	121	0	34	31
2014	7	6	1	58	18	0.804	-0.056	4.058	0.01	0.007	0	43	39.1	74.4	134	122	0	34	31
2014	7	6	2	8	18	0.863	-0.075	4.058	0.01	0.007	0	42.6	38.7	74.8	133	121	0	34	31
2014	7	6	2	18	18	0.863	-0.059	4.058	0.01	0.007	0	43	39.1	74.8	134	122	0	34	31
2014	7	6	2	28	18	0.846	-0.082	4.058	0.01	0.007	0	42.6	38.3	74.4	134	121	0	35	32
2014	7	6	2	38	18	0.82	-0.095	4.062	0.013	0.01	0	42.6	38.7	73.5	133	121	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	2	48	18	0.84	-0.059	4.062	0.01	0.007	0	42.6	38.7	74	133	122	0	34	32
2014	7	6	2	58	18	0.846	-0.066	4.062	0.01	0.007	0	42.6	37.8	73.5	133	120	0	34	32
2014	7	6	3	8	18	0.817	-0.069	4.062	0.01	0.007	0	42.6	38.3	73.1	133	121	0	34	32
2014	7	6	3	18	18	0.83	-0.072	4.068	0.01	0.007	0	42.6	38.3	72.2	133	121	0	34	32
2014	7	6	3	28	18	0.814	-0.108	4.072	0.01	0.007	0	42.6	38.7	73.5	133	121	0	34	31
2014	7	6	3	38	18	0.86	-0.039	4.075	0.01	0.007	0	42.6	38.7	73.5	133	121	0	34	31
2014	7	6	3	48	18	0.886	-0.089	4.075	0.013	0.01	0	42.6	38.3	73.5	133	121	0	34	32
2014	7	6	3	58	18	0.843	-0.095	4.075	0.01	0.007	0	42.1	38.3	73.5	133	121	0	35	32
2014	7	6	4	8	18	0.85	-0.092	4.075	0.013	0.01	0	42.6	38.3	74.8	133	121	0	34	32
2014	7	6	4	18	18	0.83	-0.082	4.075	0.01	0.007	0	43	38.7	74	134	122	0	34	32
2014	7	6	4	28	18	0.807	-0.043	4.078	0.01	0.007	0	43	38.3	75.3	134	121	0	34	32
2014	7	6	4	38	18	0.856	-0.108	4.078	0.01	0.007	0	43.4	38.7	75.7	135	122	0	34	32
2014	7	6	4	48	18	0.843	-0.118	4.078	0.01	0.007	0	43	38.7	74	134	122	0	34	32
2014	7	6	4	58	18	0.827	-0.069	4.078	0.01	0.007	0	43	39.1	75.7	134	122	0	34	31
2014	7	6	5	8	18	0.827	-0.085	4.078	0.01	0.007	0	43	38.7	76.1	134	122	0	34	32
2014	7	6	5	18	18	0.83	-0.079	4.081	0.016	0.016	0	43.4	39.1	76.1	135	123	0	34	32
2014	7	6	5	28	18	0.843	-0.075	4.081	0.013	0.01	0	43.9	39.1	76.1	136	123	0	34	32
2014	7	6	5	38	18	0.843	-0.075	4.081	0.013	0.01	0	43.4	39.6	77.4	135	123	0	34	31
2014	7	6	5	48	18	0.853	-0.079	4.081	0.01	0.007	0	43.4	39.1	77	135	123	0	34	32
2014	7	6	5	58	18	0.81	-0.112	4.081	0.01	0.007	0	43.4	39.1	76.5	135	122	0	34	31
2014	7	6	6	8	18	0.827	-0.102	4.081	0.01	0.007	0	43.9	39.6	76.5	136	123	0	34	31
2014	7	6	6	18	18	0.866	-0.052	4.085	0.01	0.007	0	43	38.7	77.4	134	122	0	34	32
2014	7	6	6	28	18	0.892	-0.095	4.085	0.01	0.007	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	6	6	38	18	0.866	-0.085	4.085	0.01	0.007	0	43.4	39.1	76.5	135	123	0	34	32
2014	7	6	6	48	18	0.801	-0.046	4.085	0.01	0.007	0	43	38.7	77	134	121	0	34	31
2014	7	6	6	58	18	0.804	-0.128	4.085	0.013	0.01	0	43	38.7	77	134	122	0	34	32
2014	7	6	7	8	18	0.81	-0.095	4.085	0.01	0.007	0	43	37.8	77	134	121	0	34	33
2014	7	6	7	18	18	0.827	-0.085	4.085	0.01	0.007	0	42.1	38.3	77.4	133	121	0	35	32
2014	7	6	7	28	18	0.853	-0.079	4.085	0.01	0.007	0	43	38.3	77	134	121	0	34	32
2014	7	6	7	38	18	0.886	-0.089	4.085	0.013	0.01	0	42.1	37.8	77	133	120	0	35	32
2014	7	6	7	48	18	0.837	-0.049	4.085	0.01	0.007	0	43	38.7	77.4	134	121	0	34	31
2014	7	6	7	58	18	0.827	-0.092	4.085	0.01	0.007	0	43	38.3	77	133	121	0	33	32
2014	7	6	8	8	18	0.86	-0.069	4.085	0.01	0.007	0	42.6	38.3	75.7	133	121	0	34	32
2014	7	6	8	18	18	0.879	-0.072	4.088	0.01	0.007	0	42.1	37.8	72.7	133	120	0	35	32
2014	7	6	8	28	18	0.827	-0.075	4.088	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	6	8	38	18	0.837	-0.062	4.088	0.01	0.007	0	43	38.3	74.8	134	121	0	34	32
2014	7	6	8	48	18	0.869	-0.072	4.088	0.01	0.007	0	42.6	38.3	74.8	134	121	0	35	32
2014	7	6	8	58	18	0.837	-0.066	4.088	0.013	0.01	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	6	9	8	18	0.876	-0.062	4.088	0.01	0.007	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	6	9	18	18	0.827	-0.082	4.088	0.013	0.01	0	42.6	37.8	77	133	120	0	34	32
2014	7	6	9	28	18	0.84	-0.075	4.088	0.01	0.007	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	6	9	38	18	0.837	-0.046	4.088	0.013	0.01	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	6	9	48	18	0.863	-0.098	4.091	0.01	0.007	0	42.6	38.3	75.7	133	120	0	34	31
2014	7	6	9	58	18	0.814	-0.062	4.091	0.01	0.007	0	43	38.3	75.7	134	121	0	34	32
2014	7	6	10	8	18	0.814	-0.069	4.091	0.013	0.01	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	6	10	18	18	0.843	-0.066	4.091	0.01	0.007	0	42.1	37.8	76.5	133	120	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	10	28	18	0.823	-0.115	4.091	0.01	0.007	0	42.1	37.8	75.7	132	120	0	34	32
2014	7	6	10	38	18	0.863	-0.089	4.091	0.01	0.007	0	42.1	37.8	75.3	132	119	0	34	31
2014	7	6	10	48	18	0.853	-0.056	4.091	0.01	0.007	0	42.1	37.8	76.1	132	120	0	34	32
2014	7	6	10	58	18	0.889	-0.069	4.091	0.013	0.01	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	6	11	8	18	0.879	-0.089	4.091	0.01	0.007	0	42.1	37.8	74.4	132	119	0	34	31
2014	7	6	11	18	18	0.856	-0.092	4.094	0.01	0.007	0	42.6	37.8	71.8	133	120	0	34	32
2014	7	6	11	28	18	0.846	-0.066	4.094	0.016	0.013	0	43	38.3	75.3	134	121	0	34	32
2014	7	6	11	38	18	0.823	-0.062	4.094	0.013	0.01	0	43	38.3	75.7	134	121	0	34	32
2014	7	6	11	48	18	0.879	-0.072	4.094	0.01	0.007	0	43	38.3	75.3	134	121	0	34	32
2014	7	6	11	58	18	0.83	-0.089	4.094	0.01	0.007	0	42.6	37.8	74.8	133	120	0	34	32
2014	7	6	12	8	18	0.81	-0.089	4.094	0.01	0.007	0	42.6	37.8	75.3	133	120	0	34	32
2014	7	6	12	18	18	0.853	-0.046	4.098	0.01	0.007	0	42.6	38.3	74	133	121	0	34	32
2014	7	6	12	28	18	0.853	-0.095	4.098	0.01	0.007	0	42.6	38.3	74	133	121	0	34	32
2014	7	6	12	38	18	0.833	-0.082	4.098	0.01	0.007	0	42.1	38.3	74.4	132	120	0	34	31
2014	7	6	12	48	18	0.85	-0.092	4.098	0.013	0.01	0	42.1	37.4	75.3	132	119	0	34	32
2014	7	6	12	58	18	0.804	-0.079	4.098	0.01	0.007	0	42.1	37.8	74	132	120	0	34	32
2014	7	6	13	8	18	0.817	-0.075	4.098	0.01	0.007	0	42.1	37.8	75.7	132	120	0	34	32
2014	7	6	13	18	18	0.823	-0.092	4.098	0.01	0.007	0	41.7	37.4	75.7	131	119	0	34	32
2014	7	6	13	28	18	0.814	-0.108	4.098	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	6	13	38	18	0.866	-0.095	4.098	0.013	0.01	0	41.7	37.4	75.7	131	119	0	34	32
2014	7	6	13	48	18	0.823	-0.092	4.098	0.01	0.007	0	40.9	37.4	76.1	130	118	0	35	31
2014	7	6	13	58	18	0.85	-0.033	4.098	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	6	14	8	18	0.873	-0.108	4.098	0.013	0.01	0	41.3	37	76.1	130	117	0	34	31
2014	7	6	14	18	18	0.794	-0.082	4.098	0.01	0.007	0	40.9	37	75.7	129	117	0	34	31
2014	7	6	14	28	18	0.869	-0.085	4.098	0.01	0.007	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	6	14	38	18	0.86	-0.112	4.098	0.01	0.007	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	6	14	48	18	0.83	-0.092	4.098	0.01	0.007	0	40.9	37	75.7	129	117	0	34	31
2014	7	6	14	58	18	0.804	-0.102	4.098	0.01	0.007	0	40.9	36.5	76.5	130	117	0	35	32
2014	7	6	15	8	18	0.899	-0.079	4.098	0.013	0.01	0	41.3	37	76.5	130	117	0	34	31
2014	7	6	15	18	18	0.837	-0.098	4.098	0.01	0.007	0	40.9	37.4	76.1	129	118	0	34	31
2014	7	6	15	28	18	0.823	-0.092	4.098	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	6	15	38	18	0.85	-0.072	4.098	0.013	0.01	0	41.3	37	76.1	130	118	0	34	32
2014	7	6	15	48	18	0.837	-0.082	4.098	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	6	15	58	18	0.863	-0.069	4.098	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	6	16	8	18	0.827	-0.098	4.098	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	6	16	18	18	0.84	-0.098	4.098	0.01	0.007	0	41.3	36.5	58.9	130	117	0	34	32
2014	7	6	16	28	18	0.83	-0.059	4.101	0.01	0.007	0	41.7	37.4	53.8	131	119	0	34	32
2014	7	6	16	38	18	0.804	-0.102	4.098	0.01	0.007	0	43	38.7	55.9	134	121	0	34	31
2014	7	6	16	48	18	0.856	-0.079	4.098	0.01	0.007	0	42.6	38.3	63.2	133	120	0	34	31
2014	7	6	16	58	18	0.807	-0.085	4.098	0.013	0.01	0	42.1	38.3	65.8	132	120	0	34	31
2014	7	6	17	8	18	0.86	-0.095	4.098	0.01	0.007	0	42.1	37.8	67.9	132	119	0	34	31
2014	7	6	17	18	18	0.817	-0.066	4.098	0.013	0.01	0	43.4	38.3	75.3	134	121	0	33	32
2014	7	6	17	28	18	0.837	-0.105	4.098	0.01	0.007	0	43.4	39.6	71	135	123	0	34	31
2014	7	6	17	38	18	0.83	-0.059	4.098	0.01	0.007	0	43.4	38.7	71.8	135	122	0	34	32
2014	7	6	17	48	18	0.84	-0.072	4.098	0.01	0.007	0	42.6	38.7	76.5	133	121	0	34	31
2014	7	6	17	58	18	0.807	-0.092	4.098	0.01	0.007	0	42.1	38.3	76.1	132	120	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	6	18	8	18	0.873	-0.092	4.098	0.013	0.01	0	41.7	37.8	74.4	132	119	0	35	31
2014	7	6	18	18	18	0.869	-0.098	4.098	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	6	18	28	18	0.846	-0.098	4.098	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	6	18	38	18	0.866	-0.082	4.098	0.016	0.013	0	41.3	37	76.1	130	118	0	34	32
2014	7	6	18	48	18	0.889	-0.085	4.101	0.013	0.01	0	42.1	37.8	75.7	132	120	0	34	32
2014	7	6	18	58	18	0.869	-0.092	4.101	0.01	0.007	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	6	19	8	18	0.837	-0.098	4.101	0.013	0.01	0	42.6	37.4	76.5	132	119	0	33	32
2014	7	6	19	18	18	0.846	-0.092	4.101	0.01	0.007	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	6	19	28	18	0.84	-0.085	4.101	0.013	0.01	0	42.1	38.3	75.7	132	120	0	34	31
2014	7	6	19	38	18	0.837	-0.098	4.101	0.01	0.007	0	42.1	38.3	76.1	132	120	0	34	31
2014	7	6	19	48	18	0.81	-0.062	4.101	0.016	0.013	0	42.1	38.3	76.1	132	120	0	34	31
2014	7	6	19	58	18	0.846	-0.059	4.101	0.01	0.007	0	42.1	38.3	76.1	132	120	0	34	31
2014	7	6	20	8	18	0.856	-0.062	4.101	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	6	20	18	18	0.856	-0.079	4.101	0.01	0.007	0	43	38.3	74.8	133	120	0	33	31
2014	7	6	20	28	18	0.84	-0.098	4.101	0.01	0.007	0	42.1	38.3	74.4	132	120	0	34	31
2014	7	6	20	38	18	0.856	-0.072	4.101	0.01	0.007	0	42.6	38.7	70.5	133	121	0	34	31
2014	7	6	20	48	18	0.863	-0.092	4.101	0.01	0.007	0	42.6	37.8	70.5	133	120	0	34	32
2014	7	6	20	58	18	0.84	-0.039	4.101	0.013	0.01	0	42.6	38.7	71.4	133	121	0	34	31
2014	7	6	21	8	18	0.843	-0.095	4.104	0.016	0.013	0	42.1	38.7	74	133	121	0	35	31
2014	7	6	21	18	18	0.866	-0.095	4.104	0.01	0.007	0	42.1	38.3	74	132	120	0	34	31
2014	7	6	21	28	18	0.84	-0.075	4.104	0.01	0.007	0	42.6	38.3	74.4	133	120	0	34	31
2014	7	6	21	38	18	0.856	-0.072	4.104	0.013	0.01	0	42.1	37.8	74.8	132	119	0	34	31
2014	7	6	21	48	18	0.866	-0.095	4.104	0.01	0.007	0	41.7	37.8	74.8	131	119	0	34	31
2014	7	6	21	58	18	0.86	-0.046	4.104	0.01	0.007	0	42.1	38.3	72.2	132	120	0	34	31
2014	7	6	22	8	18	0.873	-0.059	4.104	0.01	0.007	0	43	38.7	71.4	134	121	0	34	31
2014	7	6	22	18	18	0.85	-0.089	4.104	0.01	0.007	0	43	38.3	73.1	134	121	0	34	32
2014	7	6	22	28	18	0.837	-0.085	4.104	0.01	0.007	0	42.6	38.3	73.5	133	121	0	34	32
2014	7	6	22	38	18	0.899	-0.095	4.108	0.01	0.007	0	42.6	38.3	61.9	133	120	0	34	31
2014	7	6	22	48	18	0.892	-0.066	4.108	0.01	0.007	0	43.4	38.3	66.2	134	121	0	33	32
2014	7	6	22	58	18	0.833	-0.023	4.108	0.013	0.01	0	43.4	39.1	69.2	135	122	0	34	31
2014	7	6	23	8	18	0.86	-0.079	4.108	0.01	0.007	0	44.3	39.6	68.4	137	124	0	34	32
2014	7	6	23	18	18	0.863	-0.049	4.114	0.01	0.007	0	45.2	41.3	59.8	139	127	0	34	31
2014	7	6	23	28	18	0.863	-0.079	4.111	0.01	0.007	0	46	41.7	70.5	141	129	0	34	32
2014	7	6	23	38	18	0.853	-0.082	4.114	0.01	0.007	0	46	41.3	71	141	128	0	34	32
2014	7	6	23	48	18	0.853	-0.062	4.117	0.01	0.007	0	45.2	40.4	71.8	139	126	0	34	32
2014	7	6	23	58	18	0.869	-0.079	4.117	0.013	0.01	0	44.3	40.4	72.2	137	125	0	34	31
2014	7	7	0	8	18	0.85	-0.062	4.117	0.01	0.007	0	43.9	39.1	73.1	136	123	0	34	32
2014	7	7	0	18	18	0.86	-0.079	4.121	0.01	0.007	0	43	38.7	73.1	135	122	0	35	32
2014	7	7	0	28	18	0.846	-0.059	4.121	0.01	0.007	0	43.4	38.3	73.5	134	121	0	33	32
2014	7	7	0	38	18	0.83	-0.036	4.121	0.013	0.01	0	42.1	38.3	74.4	133	121	0	35	32
2014	7	7	0	48	18	0.837	-0.079	4.121	0.01	0.007	0	42.6	38.3	74.4	133	121	0	34	32
2014	7	7	0	58	18	0.85	-0.079	4.121	0.01	0.007	0	41.7	38.3	74.4	132	120	0	35	31
2014	7	7	1	8	18	0.84	-0.098	4.124	0.013	0.01	0	42.6	37.8	73.1	132	120	0	33	32
2014	7	7	1	18	18	0.84	-0.092	4.124	0.013	0.01	0	42.1	38.3	72.7	132	120	0	34	31
2014	7	7	1	28	18	0.801	-0.072	4.124	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	7	1	38	18	0.889	-0.075	4.124	0.01	0.007	0	42.1	37.8	75.3	132	119	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	1	48	18	0.873	-0.062	4.124	0.013	0.01	0	42.1	37.4	75.7	132	119	0	34	32
2014	7	7	1	58	18	0.837	-0.046	4.124	0.01	0.007	0	42.6	37.8	76.1	132	119	0	33	31
2014	7	7	2	8	18	0.869	-0.098	4.124	0.01	0.007	0	42.1	38.3	76.1	132	120	0	34	31
2014	7	7	2	18	18	0.856	-0.092	4.127	0.01	0.007	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	7	2	28	18	0.869	-0.056	4.127	0.01	0.007	0	42.6	37.8	77	133	120	0	34	32
2014	7	7	2	38	18	0.873	-0.098	4.127	0.013	0.01	0	42.1	37.8	77	132	119	0	34	31
2014	7	7	2	48	18	0.869	-0.049	4.127	0.013	0.01	0	41.7	38.3	75.7	132	120	0	35	31
2014	7	7	2	58	18	0.833	-0.072	4.127	0.01	0.007	0	42.6	38.3	77	133	120	0	34	31
2014	7	7	3	8	18	0.856	-0.092	4.127	0.01	0.007	0	42.1	37.8	77	132	120	0	34	32
2014	7	7	3	18	18	0.86	-0.066	4.127	0.013	0.01	0	42.6	38.7	77	133	121	0	34	31
2014	7	7	3	28	18	0.873	-0.085	4.127	0.01	0.007	0	42.1	37.8	77.4	132	120	0	34	32
2014	7	7	3	38	18	0.886	-0.079	4.127	0.01	0.007	0	42.6	38.3	77	133	120	0	34	31
2014	7	7	3	48	18	0.912	-0.069	4.131	0.01	0.007	0	42.6	38.7	77.4	133	121	0	34	31
2014	7	7	3	58	18	0.837	-0.066	4.127	0.01	0.007	0	42.6	37.8	77	133	120	0	34	32
2014	7	7	4	8	18	0.797	-0.069	4.127	0.013	0.01	0	42.6	38.3	75.7	133	121	0	34	32
2014	7	7	4	18	18	0.896	-0.085	4.131	0.01	0.007	0	42.1	38.3	76.5	132	120	0	34	31
2014	7	7	4	28	18	0.876	-0.049	4.131	0.013	0.01	0	42.6	38.7	76.5	133	121	0	34	31
2014	7	7	4	38	18	0.86	-0.046	4.131	0.013	0.01	0	42.6	38.7	77	133	121	0	34	31
2014	7	7	4	48	18	0.84	-0.075	4.131	0.013	0.01	0	43	38.3	77	134	121	0	34	32
2014	7	7	4	58	18	0.883	-0.046	4.131	0.01	0.007	0	43	38.3	76.1	134	121	0	34	32
2014	7	7	5	8	18	0.863	-0.069	4.131	0.01	0.007	0	42.6	38.3	76.5	133	121	0	34	32
2014	7	7	5	18	18	0.807	-0.069	4.131	0.013	0.01	0	42.6	38.3	75.3	133	121	0	34	32
2014	7	7	5	28	18	0.86	-0.062	4.131	0.01	0.007	0	42.6	38.3	76.5	133	120	0	34	31
2014	7	7	5	38	18	0.873	-0.062	4.131	0.016	0.013	0	43	38.7	75.7	134	121	0	34	31
2014	7	7	5	48	18	0.856	-0.095	4.131	0.013	0.01	0	43	38.7	76.1	134	121	0	34	31
2014	7	7	5	58	18	0.853	-0.046	4.131	0.013	0.01	0	43	38.7	76.1	134	122	0	34	32
2014	7	7	6	8	18	0.866	-0.095	4.131	0.01	0.007	0	43.4	38.7	76.5	134	122	0	33	32
2014	7	7	6	18	18	0.883	-0.062	4.134	0.013	0.01	0	43.4	38.3	75.3	134	121	0	33	32
2014	7	7	6	28	18	0.86	-0.098	4.131	0.01	0.007	0	42.1	38.3	75.3	133	121	0	35	32
2014	7	7	6	38	18	0.823	-0.036	4.134	0.013	0.01	0	42.1	37.8	75.3	133	120	0	35	32
2014	7	7	6	48	18	0.83	-0.072	4.134	0.01	0.007	0	42.1	38.3	74.4	132	120	0	34	31
2014	7	7	6	58	18	0.833	-0.059	4.134	0.013	0.01	0	42.1	37.8	65.8	133	120	0	35	32
2014	7	7	7	8	18	0.846	-0.023	4.134	0.01	0.007	0	43.4	39.1	75.3	135	122	0	34	31
2014	7	7	7	18	18	0.846	-0.059	4.134	0.01	0.007	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	7	7	28	18	0.84	-0.102	4.134	0.01	0.007	0	43.4	38.7	74	134	121	0	33	31
2014	7	7	7	38	18	0.873	-0.102	4.134	0.01	0.007	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	7	7	48	18	0.846	-0.108	4.137	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	7	7	58	18	0.873	-0.095	4.137	0.01	0.007	0	42.1	38.3	74	132	120	0	34	31
2014	7	7	8	8	18	0.833	-0.052	4.137	0.013	0.01	0	42.6	37.8	74.4	133	120	0	34	32
2014	7	7	8	18	18	0.853	-0.062	4.137	0.016	0.013	0	41.7	37.8	74.8	132	120	0	35	32
2014	7	7	8	28	18	0.823	-0.069	4.137	0.01	0.007	0	41.7	37.8	74	132	120	0	35	32
2014	7	7	8	38	18	0.843	-0.056	4.137	0.01	0.007	0	42.1	37.8	73.5	132	120	0	34	32
2014	7	7	8	48	18	0.853	-0.082	4.137	0.013	0.01	0	42.1	37.8	74.8	132	120	0	34	32
2014	7	7	8	58	18	0.879	-0.082	4.137	0.01	0.007	0	41.7	37.8	74	131	119	0	34	31
2014	7	7	9	8	18	0.866	-0.079	4.14	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	7	9	18	18	0.82	-0.066	4.14	0.01	0.007	0	41.7	37.8	74	131	119	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	9	28	18	0.846	-0.092	4.14	0.01	0.007	0	42.1	37.4	74	131	119	0	33	32
2014	7	7	9	38	18	0.886	-0.072	4.14	0.01	0.007	0	41.7	37.8	73.5	131	119	0	34	31
2014	7	7	9	48	18	0.823	-0.059	4.14	0.01	0.007	0	41.7	38.3	73.1	131	120	0	34	31
2014	7	7	9	58	18	0.843	-0.095	4.14	0.013	0.01	0	41.3	37.4	73.5	131	119	0	35	32
2014	7	7	10	8	18	0.846	-0.052	4.144	0.01	0.007	0	41.7	37	73.1	131	118	0	34	32
2014	7	7	10	18	18	0.85	-0.085	4.144	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	7	10	28	18	0.843	-0.079	4.144	0.013	0.01	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	7	10	38	18	0.869	-0.066	4.147	0.01	0.007	0	41.7	37.4	72.7	131	119	0	34	32
2014	7	7	10	48	18	0.876	-0.066	4.147	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	7	10	58	18	0.896	-0.092	4.147	0.013	0.01	0	42.6	37.8	73.1	132	119	0	33	31
2014	7	7	11	8	18	0.879	-0.075	4.15	0.01	0.007	0	42.1	37	73.1	132	119	0	34	33
2014	7	7	11	18	18	0.863	-0.062	4.15	0.01	0.007	0	42.1	37.8	72.7	132	119	0	34	31
2014	7	7	11	28	18	0.856	-0.069	4.15	0.01	0.007	0	42.6	38.3	71.8	132	120	0	33	31
2014	7	7	11	38	18	0.879	-0.069	4.154	0.01	0.007	0	42.1	38.3	71	132	120	0	34	31
2014	7	7	11	48	18	0.899	-0.079	4.154	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	7	11	58	18	0.827	-0.095	4.157	0.013	0.01	0	41.7	38.3	73.1	131	120	0	34	31
2014	7	7	12	8	18	0.84	-0.125	4.157	0.01	0.007	0	41.7	37	74.4	130	118	0	33	32
2014	7	7	12	18	18	0.866	-0.105	4.157	0.01	0.007	0	41.3	37.4	74	130	118	0	34	31
2014	7	7	12	28	18	0.84	-0.052	4.157	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	7	12	38	18	0.86	-0.066	4.157	0.016	0.013	0	40.9	37.4	74	129	117	0	34	30
2014	7	7	12	48	18	0.846	-0.059	4.157	0.01	0.007	0	41.3	37	74	130	118	0	34	32
2014	7	7	12	58	18	0.866	-0.075	4.157	0.013	0.01	0	41.3	37.4	73.5	130	118	0	34	31
2014	7	7	13	8	18	0.863	-0.092	4.157	0.01	0.007	0	40.9	37	73.1	130	118	0	35	32
2014	7	7	13	18	18	0.85	-0.105	4.157	0.01	0.007	0	40.9	37.4	74	130	118	0	35	31
2014	7	7	13	28	18	0.843	-0.105	4.157	0.01	0.007	0	40.4	36.5	73.5	129	117	0	35	32
2014	7	7	13	38	18	0.873	-0.102	4.15	0.01	0.007	0	40.9	37	73.5	129	117	0	34	31
2014	7	7	13	48	18	0.886	-0.092	4.15	0.01	0.007	0	40.9	36.5	72.7	129	117	0	34	32
2014	7	7	13	58	18	0.801	-0.049	4.15	0.013	0.01	0	40.4	36.5	74	128	116	0	34	31
2014	7	7	14	8	18	0.837	-0.066	4.15	0.01	0.007	0	40.4	37	73.5	129	117	0	35	31
2014	7	7	14	18	18	0.863	-0.108	4.15	0.013	0.01	0	40.4	36.1	72.7	128	116	0	34	32
2014	7	7	14	28	18	0.883	-0.072	4.15	0.01	0.007	0	40.4	36.5	73.5	128	116	0	34	31
2014	7	7	14	38	18	0.83	-0.075	4.15	0.01	0.007	0	40.4	36.1	74	128	116	0	34	32
2014	7	7	14	48	18	0.869	-0.118	4.147	0.01	0.007	0	40	35.7	73.5	127	115	0	34	32
2014	7	7	14	58	18	0.843	-0.089	4.147	0.01	0.007	0	40	36.1	74	127	115	0	34	31
2014	7	7	15	8	18	0.853	-0.085	4.15	0.01	0.007	0	40	36.1	73.5	127	115	0	34	31
2014	7	7	15	18	18	0.876	-0.105	4.15	0.013	0.01	0	40	35.7	69.7	127	115	0	34	32
2014	7	7	15	28	18	0.791	-0.075	4.147	0.013	0.01	0	41.7	37.8	63.6	131	119	0	34	31
2014	7	7	15	38	18	0.837	-0.125	4.147	0.01	0.007	0	42.6	37.8	71.8	133	120	0	34	32
2014	7	7	15	48	18	0.843	-0.082	4.15	0.01	0.007	0	42.6	37.8	72.2	132	120	0	33	32
2014	7	7	15	58	18	0.833	-0.095	4.15	0.01	0.007	0	41.7	37.8	73.1	131	119	0	34	31
2014	7	7	16	8	18	0.873	-0.089	4.15	0.01	0.007	0	41.3	37.4	73.5	130	118	0	34	31
2014	7	7	16	18	18	0.896	-0.059	4.15	0.013	0.01	0	41.3	36.5	73.5	130	118	0	34	33
2014	7	7	16	28	18	0.82	-0.085	4.154	0.013	0.01	0	41.3	37.4	72.7	130	118	0	34	31
2014	7	7	16	38	18	0.856	-0.098	4.154	0.01	0.007	0	41.7	37	73.1	130	118	0	33	32
2014	7	7	16	48	18	0.876	-0.105	4.157	0.01	0.007	0	41.3	37	73.5	130	118	0	34	32
2014	7	7	16	58	18	0.866	-0.082	4.157	0.013	0.01	0	41.3	37	74	129	117	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	7	17	8	18	0.883	-0.098	4.157	0.013	0.01	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	7	17	18	18	0.86	-0.062	4.157	0.01	0.007	0	40.9	37	73.5	129	117	0	34	31
2014	7	7	17	28	18	0.846	-0.059	4.16	0.01	0.007	0	41.3	37	74	129	117	0	33	31
2014	7	7	17	38	18	0.883	-0.079	4.16	0.016	0.013	0	40.9	36.5	74	129	117	0	34	32
2014	7	7	17	48	18	0.86	-0.059	4.16	0.013	0.01	0	41.3	36.5	74	130	117	0	34	32
2014	7	7	17	58	18	0.86	-0.079	4.16	0.013	0.01	0	41.3	36.5	74.4	130	116	0	34	31
2014	7	7	18	8	18	0.86	-0.056	4.16	0.01	0.007	0	40.9	36.5	74	129	117	0	34	32
2014	7	7	18	18	18	0.846	-0.085	4.16	0.01	0.007	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	7	18	28	18	0.896	-0.079	4.163	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	7	18	38	18	0.873	-0.075	4.163	0.01	0.007	0	41.7	36.5	74.8	130	117	0	33	32
2014	7	7	18	48	18	0.833	-0.098	4.163	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	7	18	58	18	0.889	-0.085	4.163	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	7	19	8	18	0.889	-0.075	4.163	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	7	19	18	18	0.82	-0.075	4.163	0.013	0.01	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	7	19	28	18	0.86	-0.075	4.163	0.01	0.007	0	42.1	37	75.3	131	118	0	33	32
2014	7	7	19	38	18	0.863	-0.062	4.163	0.01	0.007	0	41.7	37.4	75.3	131	118	0	34	31
2014	7	7	19	48	18	0.899	-0.062	4.167	0.01	0.007	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	7	19	58	18	0.883	-0.066	4.167	0.01	0.007	0	41.7	37	74.4	130	117	0	33	31
2014	7	7	20	8	18	0.873	-0.112	4.167	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2014	7	7	20	18	18	0.869	-0.085	4.167	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	7	20	28	18	0.873	-0.075	4.167	0.01	0.007	0	42.6	37.8	74.8	133	119	0	34	31
2014	7	7	20	38	18	0.879	-0.098	4.167	0.01	0.007	0	41.7	37	72.2	131	118	0	34	32
2014	7	7	20	48	18	0.873	-0.062	4.167	0.01	0.007	0	42.6	37.8	72.7	132	119	0	33	31
2014	7	7	20	58	18	0.889	-0.052	4.167	0.013	0.01	0	42.1	37.4	72.2	132	118	0	34	31
2014	7	7	21	8	18	0.883	-0.089	4.167	0.016	0.016	0	42.6	37.4	74.4	132	118	0	33	31
2014	7	7	21	18	18	0.86	-0.072	4.167	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2014	7	7	21	28	18	0.85	-0.049	4.17	0.01	0.007	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	7	21	38	18	0.866	-0.046	4.17	0.01	0.007	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	7	21	48	18	0.837	-0.069	4.17	0.01	0.007	0	42.1	37.4	77	132	118	0	34	31
2014	7	7	21	58	18	0.902	-0.095	4.17	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	7	22	8	18	0.856	-0.085	4.17	0.013	0.01	0	41.7	37	77.4	131	118	0	34	32
2014	7	7	22	18	18	0.883	-0.062	4.17	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	7	22	28	18	0.876	-0.066	4.17	0.01	0.007	0	41.7	37	77.8	131	117	0	34	31
2014	7	7	22	38	18	0.873	-0.049	4.17	0.01	0.007	0	41.7	37	77.8	131	118	0	34	32
2014	7	7	22	48	18	0.886	-0.059	4.17	0.01	0.007	0	41.7	37.4	76.5	131	118	0	34	31
2014	7	7	22	58	18	0.886	-0.033	4.17	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	7	23	8	18	0.902	-0.075	4.17	0.013	0.01	0	41.3	37	77	130	117	0	34	31
2014	7	7	23	18	18	0.863	-0.108	4.17	0.01	0.007	0	41.3	37	77	130	117	0	34	31
2014	7	7	23	28	18	0.889	-0.052	4.17	0.01	0.007	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	7	23	38	18	0.873	-0.075	4.17	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	7	23	48	18	0.863	-0.059	4.17	0.01	0.007	0	41.3	37	77.4	130	118	0	34	32
2014	7	7	23	58	18	0.843	-0.046	4.17	0.01	0.007	0	41.7	37.4	77.4	131	118	0	34	31
2014	7	8	0	8	18	0.883	-0.082	4.173	0.013	0.01	0	41.3	36.5	77.4	130	117	0	34	32
2014	7	8	0	18	18	0.85	-0.095	4.173	0.01	0.007	0	42.1	37	77.4	131	117	0	33	31
2014	7	8	0	28	18	0.853	-0.059	4.173	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	8	0	38	18	0.876	-0.066	4.173	0.01	0.007	0	41.3	37	77	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	0	48	18	0.866	-0.079	4.173	0.013	0.01	0	41.7	37	76.5	131	118	0	34	32
2014	7	8	0	58	18	0.843	-0.082	4.173	0.013	0.01	0	41.7	37	76.5	131	118	0	34	32
2014	7	8	1	8	18	0.823	-0.085	4.173	0.01	0.007	0	41.7	37.4	77.4	131	118	0	34	31
2014	7	8	1	18	18	0.846	-0.075	4.173	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	8	1	28	18	0.883	-0.049	4.173	0.013	0.01	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	8	1	38	18	0.833	-0.098	4.173	0.01	0.007	0	41.7	37.4	75.3	131	118	0	34	31
2014	7	8	1	48	18	0.866	-0.085	4.173	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	8	1	58	18	0.873	-0.052	4.173	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	8	2	8	18	0.866	-0.079	4.173	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	8	2	18	18	0.886	-0.082	4.173	0.01	0.007	0	41.7	37.4	75.3	131	118	0	34	31
2014	7	8	2	28	18	0.883	-0.079	4.173	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	8	2	38	18	0.85	-0.095	4.173	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	8	2	48	18	0.86	-0.049	4.173	0.01	0.007	0	41.7	36.5	74.4	131	117	0	34	32
2014	7	8	2	58	18	0.883	-0.069	4.173	0.016	0.013	0	41.7	37	74.8	131	117	0	34	31
2014	7	8	3	8	18	0.853	-0.079	4.177	0.013	0.01	0	41.7	37	74.8	131	118	0	34	32
2014	7	8	3	18	18	0.886	-0.082	4.177	0.013	0.01	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	8	3	28	18	0.856	-0.069	4.177	0.013	0.01	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	8	3	38	18	0.866	-0.079	4.177	0.016	0.013	0	41.3	37.4	75.3	130	118	0	34	31
2014	7	8	3	48	18	0.853	-0.066	4.177	0.013	0.01	0	41.3	37	75.7	130	117	0	34	31
2014	7	8	3	58	18	0.876	-0.095	4.177	0.01	0.007	0	41.3	36.5	74.4	130	117	0	34	32
2014	7	8	4	8	18	0.892	-0.089	4.177	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2014	7	8	4	18	18	0.919	-0.089	4.177	0.01	0.007	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	8	4	28	18	0.873	-0.079	4.18	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	8	4	38	18	0.883	-0.095	4.18	0.013	0.01	0	42.1	37.4	74.4	131	119	0	33	32
2014	7	8	4	48	18	0.886	-0.105	4.18	0.01	0.007	0	41.7	37.4	71	131	118	0	34	31
2014	7	8	4	58	18	0.84	-0.036	4.18	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	8	5	8	18	0.863	-0.072	4.18	0.016	0.013	0	42.1	37.8	71.8	132	119	0	34	31
2014	7	8	5	18	18	0.833	-0.075	4.18	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	8	5	28	18	0.932	-0.075	4.18	0.01	0.007	0	43	37.8	72.7	134	120	0	34	32
2014	7	8	5	38	18	0.892	-0.115	4.183	0.01	0.007	0	42.1	37.8	72.7	132	119	0	34	31
2014	7	8	5	48	18	0.866	-0.062	4.183	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	8	5	58	18	0.866	-0.062	4.186	0.01	0.007	0	41.7	37.4	72.7	132	119	0	35	32
2014	7	8	6	8	18	0.856	-0.095	4.19	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	8	6	18	18	0.866	-0.049	4.193	0.01	0.007	0	42.1	37.4	72.7	132	119	0	34	32
2014	7	8	6	28	18	0.863	-0.062	4.193	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	8	6	38	18	0.869	-0.039	4.193	0.01	0.007	0	41.7	37.4	74	131	118	0	34	31
2014	7	8	6	48	18	0.846	-0.079	4.193	0.01	0.007	0	41.7	37.4	73.1	131	118	0	34	31
2014	7	8	6	58	18	0.863	-0.059	4.193	0.013	0.01	0	42.1	37.4	74	132	119	0	34	32
2014	7	8	7	8	18	0.886	-0.056	4.196	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	8	7	18	18	0.863	-0.089	4.196	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2014	7	8	7	28	18	0.873	-0.052	4.196	0.01	0.007	0	41.7	37	74.8	130	118	0	33	32
2014	7	8	7	38	18	0.899	-0.108	4.196	0.01	0.007	0	41.7	37	75.3	130	118	0	33	32
2014	7	8	7	48	18	0.889	-0.046	4.196	0.01	0.007	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	8	7	58	18	0.863	-0.075	4.196	0.013	0.01	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	8	8	8	18	0.843	-0.079	4.196	0.01	0.007	0	41.7	37.4	75.7	131	119	0	34	32
2014	7	8	8	18	18	0.853	-0.089	4.196	0.01	0.007	0	41.7	37.4	75.3	131	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	8	28	18	0.856	-0.079	4.196	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	8	8	38	18	0.853	-0.072	4.196	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	8	8	48	18	0.853	-0.079	4.199	0.01	0.007	0	42.1	37.4	75.7	131	118	0	33	31
2014	7	8	8	58	18	0.846	-0.072	4.199	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	8	9	8	18	0.86	-0.056	4.199	0.01	0.007	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	8	9	18	18	0.873	-0.095	4.199	0.01	0.007	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	8	9	28	18	0.873	-0.092	4.199	0.01	0.007	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	8	9	38	18	0.843	-0.049	4.199	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	8	9	48	18	0.909	-0.062	4.199	0.013	0.01	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	8	9	58	18	0.889	-0.108	4.199	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	8	10	8	18	0.879	-0.115	4.199	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	8	10	18	18	0.817	-0.079	4.199	0.01	0.007	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	8	10	28	18	0.84	-0.098	4.199	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	8	10	38	18	0.879	-0.092	4.199	0.013	0.01	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	8	10	48	18	0.886	-0.095	4.199	0.01	0.007	0	40.9	36.5	75.3	129	116	0	34	31
2014	7	8	10	58	18	0.902	-0.115	4.199	0.01	0.007	0	41.3	36.5	72.2	129	117	0	33	32
2014	7	8	11	8	18	0.83	-0.098	4.199	0.01	0.007	0	40.9	36.5	73.1	129	116	0	34	31
2014	7	8	11	18	18	0.85	-0.075	4.199	0.01	0.007	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	8	11	28	18	0.866	-0.092	4.196	0.01	0.007	0	40.9	36.5	71	129	116	0	34	31
2014	7	8	11	38	18	0.833	-0.056	4.196	0.016	0.013	0	40.9	36.5	67.9	129	117	0	34	32
2014	7	8	11	48	18	0.853	-0.112	4.196	0.01	0.007	0	40.9	36.5	71.8	129	117	0	34	32
2014	7	8	11	58	18	0.869	-0.066	4.193	0.013	0.01	0	40.9	35.7	61.1	129	116	0	34	33
2014	7	8	12	8	18	0.853	-0.089	4.193	0.013	0.01	0	40.4	36.5	58.5	128	116	0	34	31
2014	7	8	12	18	18	0.837	-0.072	4.193	0.01	0.007	0	40	35.7	64.9	128	115	0	35	32
2014	7	8	12	28	18	0.86	-0.082	4.193	0.01	0.007	0	40.4	36.1	63.6	128	115	0	34	31
2014	7	8	12	38	18	0.83	-0.098	4.19	0.013	0.01	0	40	35.7	60.2	127	115	0	34	32
2014	7	8	12	48	18	0.837	-0.062	4.19	0.01	0.007	0	40.4	36.5	61.5	128	116	0	34	31
2014	7	8	12	58	18	0.879	-0.075	4.186	0.01	0.007	0	40.4	35.7	71	128	115	0	34	32
2014	7	8	13	8	18	0.823	-0.098	4.19	0.013	0.01	0	40	36.1	59.3	127	115	0	34	31
2014	7	8	13	18	18	0.823	-0.105	4.186	0.01	0.007	0	40	35.3	66.7	127	114	0	34	32
2014	7	8	13	28	18	0.833	-0.062	4.186	0.01	0.007	0	40.4	36.5	57.6	128	116	0	34	31
2014	7	8	13	38	18	0.804	-0.062	4.19	0.01	0.007	0	47.3	42.6	52	144	131	0	34	32
2014	7	8	13	48	18	0.827	-0.049	4.19	0.01	0.007	0	46.4	42.1	53.8	142	129	0	34	31
2014	7	8	13	58	18	0.853	-0.102	4.19	0.01	0.007	0	46	41.3	54.2	141	128	0	34	32
2014	7	8	14	8	18	0.853	-0.102	4.19	0.01	0.007	0	45.2	40.9	55.5	139	126	0	34	31
2014	7	8	14	18	18	0.866	-0.115	4.19	0.01	0.007	0	44.7	40	52.9	138	125	0	34	32
2014	7	8	14	28	18	0.856	-0.066	4.19	0.01	0.007	0	44.3	39.6	54.6	136	124	0	33	32
2014	7	8	14	38	18	0.866	-0.072	4.19	0.013	0.01	0	43.9	39.1	55.5	136	123	0	34	32
2014	7	8	14	48	18	0.856	-0.062	4.186	0.01	0.007	0	43.4	39.1	56.3	135	122	0	34	31
2014	7	8	14	58	18	0.886	-0.052	4.19	0.01	0.007	0	44.3	40	55	137	124	0	34	31
2014	7	8	15	8	18	0.856	-0.033	4.183	0.01	0.007	0	44.7	40.4	70.1	138	126	0	34	32
2014	7	8	15	18	18	0.889	-0.085	4.183	0.01	0.007	0	44.7	40.9	62.4	138	126	0	34	31
2014	7	8	15	28	18	0.86	-0.079	4.183	0.013	0.01	0	44.3	40	62.8	137	124	0	34	31
2014	7	8	15	38	18	0.883	-0.082	4.183	0.01	0.007	0	43.4	39.6	58.5	135	123	0	34	31
2014	7	8	15	48	18	0.827	-0.062	4.183	0.013	0.01	0	43	38.3	62.8	134	121	0	34	32
2014	7	8	15	58	18	0.823	-0.089	4.183	0.01	0.007	0	42.1	38.3	58.9	132	120	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	16	8	18	0.843	-0.072	4.183	0.01	0.007	0	42.1	38.3	60.2	132	120	0	34	31
2014	7	8	16	18	18	0.853	-0.085	4.183	0.01	0.007	0	41.3	37.4	71	130	118	0	34	31
2014	7	8	16	28	18	0.837	-0.098	4.183	0.01	0.007	0	41.3	37	66.2	130	117	0	34	31
2014	7	8	16	38	18	0.899	-0.098	4.183	0.01	0.007	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	8	16	48	18	0.86	-0.049	4.183	0.01	0.007	0	41.3	37	74	130	117	0	34	31
2014	7	8	16	58	18	0.86	-0.066	4.183	0.01	0.007	0	41.7	36.5	74.4	130	117	0	33	32
2014	7	8	17	8	18	0.846	-0.108	4.183	0.01	0.007	0	41.3	37	74	130	118	0	34	32
2014	7	8	17	18	18	0.817	-0.023	4.183	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	8	17	28	18	0.833	-0.079	4.183	0.013	0.01	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	8	17	38	18	0.846	-0.036	4.183	0.01	0.007	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	8	17	48	18	0.823	-0.082	4.183	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	8	17	58	18	0.85	-0.072	4.183	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	8	18	8	18	0.896	-0.095	4.183	0.013	0.01	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	8	18	18	18	0.853	-0.033	4.183	0.01	0.007	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	8	18	28	18	0.856	-0.085	4.183	0.013	0.01	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	8	18	38	18	0.889	-0.062	4.183	0.01	0.007	0	41.7	37.4	75.7	130	118	0	33	31
2014	7	8	18	48	18	0.833	-0.056	4.183	0.01	0.007	0	41.7	37	74.8	131	118	0	34	32
2014	7	8	18	58	18	0.922	-0.062	4.183	0.01	0.007	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	8	19	8	18	0.837	-0.075	4.183	0.01	0.007	0	42.1	38.3	68.4	132	120	0	34	31
2014	7	8	19	18	18	0.909	-0.062	4.183	0.01	0.007	0	43	38.3	66.2	133	120	0	33	31
2014	7	8	19	28	18	0.879	-0.062	4.183	0.013	0.01	0	42.6	38.7	61.9	133	121	0	34	31
2014	7	8	19	38	18	0.853	-0.059	4.183	0.01	0.007	0	43	38.7	68.4	134	121	0	34	31
2014	7	8	19	48	18	0.837	-0.059	4.183	0.01	0.007	0	42.6	37.8	73.5	133	120	0	34	32
2014	7	8	19	58	18	0.879	-0.036	4.183	0.01	0.007	0	42.6	38.7	74	133	121	0	34	31
2014	7	8	20	8	18	0.866	-0.066	4.183	0.01	0.007	0	42.1	38.3	73.5	132	120	0	34	31
2014	7	8	20	18	18	0.856	-0.079	4.183	0.01	0.007	0	43	38.3	73.5	133	120	0	33	31
2014	7	8	20	28	18	0.83	-0.059	4.183	0.01	0.007	0	43	38.3	74.4	133	120	0	33	31
2014	7	8	20	38	18	0.837	-0.075	4.183	0.01	0.007	0	42.6	38.3	66.7	133	120	0	34	31
2014	7	8	20	48	18	0.869	-0.062	4.183	0.01	0.007	0	43.4	38.3	69.7	134	121	0	33	32
2014	7	8	20	58	18	0.86	-0.066	4.183	0.013	0.01	0	42.6	38.7	71	133	121	0	34	31
2014	7	8	21	8	18	0.846	-0.092	4.183	0.01	0.007	0	43	37.8	72.2	133	120	0	33	32
2014	7	8	21	18	18	0.915	-0.082	4.183	0.013	0.01	0	42.6	37.4	72.7	132	119	0	33	32
2014	7	8	21	28	18	0.86	-0.066	4.183	0.013	0.01	0	42.1	37.8	74	132	119	0	34	31
2014	7	8	21	38	18	0.856	-0.098	4.183	0.01	0.007	0	42.6	37.8	74	132	119	0	33	31
2014	7	8	21	48	18	0.827	-0.082	4.183	0.01	0.007	0	42.1	37.8	74.4	131	119	0	33	31
2014	7	8	21	58	18	0.896	-0.085	4.186	0.013	0.01	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	8	22	8	18	0.866	-0.089	4.186	0.01	0.007	0	41.7	37	73.5	131	118	0	34	32
2014	7	8	22	18	18	0.846	-0.102	4.186	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	8	22	28	18	0.866	-0.089	4.186	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	8	22	38	18	0.853	-0.098	4.186	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	8	22	48	18	0.869	-0.079	4.186	0.01	0.007	0	41.7	37.8	73.1	131	119	0	34	31
2014	7	8	22	58	18	0.869	-0.098	4.186	0.01	0.007	0	41.7	37.4	74	131	118	0	34	31
2014	7	8	23	8	18	0.886	-0.102	4.186	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	8	23	18	18	0.899	-0.098	4.19	0.01	0.007	0	42.6	37.8	73.1	132	119	0	33	31
2014	7	8	23	28	18	0.889	-0.066	4.193	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	8	23	38	18	0.902	-0.079	4.193	0.01	0.007	0	42.1	37.8	72.2	132	119	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	8	23	48	18	0.873	-0.043	4.196	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	8	23	58	18	0.866	-0.062	4.196	0.013	0.01	0	42.6	37.8	74	132	119	0	33	31
2014	7	9	0	8	18	0.853	-0.075	4.199	0.01	0.007	0	42.1	37.4	74.4	131	119	0	33	32
2014	7	9	0	18	18	0.853	-0.062	4.199	0.01	0.007	0	42.1	37.8	74.4	132	119	0	34	31
2014	7	9	0	28	18	0.866	-0.072	4.199	0.01	0.007	0	41.7	37.4	73.5	131	119	0	34	32
2014	7	9	0	38	18	0.889	-0.079	4.199	0.01	0.007	0	42.1	37.4	74.4	131	119	0	33	32
2014	7	9	0	48	18	0.883	-0.112	4.199	0.01	0.007	0	41.7	37.8	74.4	132	119	0	35	31
2014	7	9	0	58	18	0.846	-0.082	4.199	0.013	0.01	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	9	1	8	18	0.866	-0.069	4.199	0.01	0.007	0	41.7	37.4	74	131	119	0	34	32
2014	7	9	1	18	18	0.866	-0.062	4.199	0.01	0.007	0	42.6	38.3	74.8	133	120	0	34	31
2014	7	9	1	28	18	0.869	-0.066	4.199	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	9	1	38	18	0.866	-0.069	4.203	0.01	0.007	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	9	1	48	18	0.889	-0.059	4.199	0.01	0.007	0	42.1	37.8	75.3	132	119	0	34	31
2014	7	9	1	58	18	0.886	-0.089	4.203	0.01	0.007	0	42.1	37.4	76.1	132	119	0	34	32
2014	7	9	2	8	18	0.863	-0.092	4.203	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	9	2	18	18	0.886	-0.089	4.203	0.01	0.007	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	9	2	28	18	0.892	-0.089	4.203	0.01	0.007	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	9	2	38	18	0.856	-0.069	4.203	0.01	0.007	0	42.1	37.8	76.5	132	120	0	34	32
2014	7	9	2	48	18	0.856	-0.125	4.203	0.013	0.01	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	9	2	58	18	0.876	-0.079	4.203	0.01	0.007	0	42.1	37.8	76.1	132	119	0	34	31
2014	7	9	3	8	18	0.846	-0.102	4.203	0.01	0.007	0	41.7	37	77	131	118	0	34	32
2014	7	9	3	18	18	0.85	-0.052	4.203	0.01	0.007	0	42.6	38.3	77.4	133	120	0	34	31
2014	7	9	3	28	18	0.85	-0.105	4.203	0.013	0.01	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	9	3	38	18	0.899	-0.062	4.206	0.01	0.007	0	42.1	37.8	77.4	132	119	0	34	31
2014	7	9	3	48	18	0.896	-0.095	4.206	0.01	0.007	0	41.7	37.4	77.4	131	118	0	34	31
2014	7	9	3	58	18	0.883	-0.098	4.206	0.01	0.007	0	42.1	37	77	131	118	0	33	32
2014	7	9	4	8	18	0.925	-0.072	4.206	0.01	0.007	0	42.1	37.4	78.3	132	119	0	34	32
2014	7	9	4	18	18	0.883	-0.098	4.206	0.01	0.007	0	42.1	37.4	77.8	132	119	0	34	32
2014	7	9	4	28	18	0.873	-0.092	4.206	0.016	0.013	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	9	4	38	18	0.856	-0.092	4.206	0.01	0.007	0	42.1	37.8	77.4	132	119	0	34	31
2014	7	9	4	48	18	0.899	-0.092	4.206	0.013	0.01	0	42.1	37.8	77	132	119	0	34	31
2014	7	9	4	58	18	0.896	-0.108	4.206	0.01	0.007	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	9	5	8	18	0.896	-0.075	4.206	0.013	0.01	0	42.1	37.8	76.5	132	120	0	34	32
2014	7	9	5	18	18	0.827	-0.039	4.206	0.013	0.01	0	42.6	37.8	77	133	120	0	34	32
2014	7	9	5	28	18	0.866	-0.085	4.206	0.01	0.007	0	42.1	38.3	77	132	120	0	34	31
2014	7	9	5	38	18	0.84	-0.092	4.206	0.01	0.007	0	42.6	38.3	76.5	133	120	0	34	31
2014	7	9	5	48	18	0.869	-0.082	4.206	0.01	0.007	0	42.6	38.3	76.5	133	120	0	34	31
2014	7	9	5	58	18	0.83	-0.062	4.206	0.013	0.01	0	42.6	38.3	76.5	132	120	0	33	31
2014	7	9	6	8	18	0.873	-0.052	4.206	0.01	0.007	0	42.6	37.8	77.4	133	120	0	34	32
2014	7	9	6	18	18	0.843	-0.095	4.209	0.01	0.007	0	42.6	37.8	77	132	119	0	33	31
2014	7	9	6	28	18	0.866	-0.079	4.206	0.013	0.01	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	6	38	18	0.879	-0.072	4.209	0.01	0.007	0	42.1	37.4	77	132	119	0	34	32
2014	7	9	6	48	18	0.843	-0.062	4.209	0.01	0.007	0	42.1	37.8	77	132	119	0	34	31
2014	7	9	6	58	18	0.876	-0.066	4.209	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	7	8	18	0.863	-0.056	4.209	0.01	0.007	0	41.3	37.8	76.1	131	119	0	35	31
2014	7	9	7	18	18	0.876	-0.062	4.209	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	7	28	18	0.896	-0.075	4.209	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	7	38	18	0.869	-0.056	4.209	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	9	7	48	18	0.866	-0.079	4.209	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	7	58	18	0.906	-0.102	4.209	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	8	8	18	0.909	-0.056	4.209	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	9	8	18	18	0.938	-0.069	4.209	0.016	0.013	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	9	8	28	18	0.912	-0.092	4.209	0.01	0.007	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	9	8	38	18	0.896	-0.079	4.209	0.013	0.01	0	42.1	37.8	76.1	131	119	0	33	31
2014	7	9	8	48	18	0.889	-0.079	4.213	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	8	58	18	0.879	-0.075	4.209	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	9	9	8	18	0.846	-0.108	4.213	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	9	9	18	18	0.83	-0.112	4.213	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	9	9	28	18	0.899	-0.079	4.213	0.01	0.007	0	41.7	37.4	76.5	131	118	0	34	31
2014	7	9	9	38	18	0.873	-0.095	4.213	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	9	9	48	18	0.873	-0.085	4.213	0.01	0.007	0	41.7	37.4	76.5	130	118	0	33	31
2014	7	9	9	58	18	0.823	-0.075	4.213	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	9	10	8	18	0.879	-0.098	4.213	0.013	0.01	0	41.3	36.5	77	130	117	0	34	32
2014	7	9	10	18	18	0.85	-0.075	4.213	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	9	10	28	18	0.902	-0.072	4.213	0.013	0.01	0	41.7	37	76.1	130	117	0	33	31
2014	7	9	10	38	18	0.879	-0.075	4.213	0.01	0.007	0	41.3	37	77	130	118	0	34	32
2014	7	9	10	48	18	0.879	-0.098	4.213	0.013	0.01	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	9	10	58	18	0.863	-0.059	4.213	0.01	0.007	0	41.7	37.4	76.1	131	119	0	34	32
2014	7	9	11	8	18	0.843	-0.066	4.213	0.01	0.007	0	41.7	37.4	76.5	131	118	0	34	31
2014	7	9	11	18	18	0.837	-0.075	4.216	0.01	0.007	0	40.9	36.5	76.5	130	117	0	35	32
2014	7	9	11	28	18	0.837	-0.066	4.213	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	9	11	38	18	0.873	-0.079	4.213	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	9	11	48	18	0.823	-0.085	4.213	0.01	0.007	0	41.3	37	76.1	130	117	0	34	31
2014	7	9	11	58	18	0.84	-0.069	4.213	0.01	0.007	0	41.3	36.5	62.8	130	117	0	34	32
2014	7	9	12	8	18	0.84	-0.069	4.213	0.01	0.007	0	40.4	37	73.5	129	117	0	35	31
2014	7	9	12	18	18	0.817	-0.112	4.213	0.013	0.01	0	40.9	36.1	75.7	128	116	0	33	32
2014	7	9	12	28	18	0.869	-0.069	4.213	0.01	0.007	0	41.3	36.5	70.5	129	116	0	33	31
2014	7	9	12	38	18	0.846	-0.059	4.213	0.01	0.007	0	40.9	36.5	64.5	128	116	0	33	31
2014	7	9	12	48	18	0.827	-0.079	4.213	0.013	0.01	0	40.9	36.5	69.2	129	116	0	34	31
2014	7	9	12	58	18	0.85	-0.121	4.213	0.013	0.01	0	40.9	36.5	63.2	129	117	0	34	32
2014	7	9	13	8	18	0.873	-0.072	4.213	0.01	0.007	0	40.4	36.5	63.2	128	116	0	34	31
2014	7	9	13	18	18	0.827	-0.062	4.213	0.01	0.007	0	40.4	36.5	69.2	128	116	0	34	31
2014	7	9	13	28	18	0.873	-0.082	4.216	0.01	0.007	0	40	35.7	71.4	127	115	0	34	32
2014	7	9	13	38	18	0.86	-0.062	4.213	0.013	0.01	0	40.9	36.5	69.7	128	116	0	33	31
2014	7	9	13	48	18	0.833	-0.115	4.213	0.013	0.01	0	40	36.1	59.3	127	115	0	34	31
2014	7	9	13	58	18	0.81	-0.075	4.213	0.01	0.007	0	40.4	36.5	58.5	128	116	0	34	31
2014	7	9	14	8	18	0.856	-0.062	4.216	0.01	0.007	0	40	35.7	74	127	115	0	34	32
2014	7	9	14	18	18	0.856	-0.098	4.213	0.01	0.007	0	40.4	36.5	74	128	116	0	34	31
2014	7	9	14	28	18	0.843	-0.066	4.213	0.01	0.007	0	40.9	36.1	63.6	128	116	0	33	32
2014	7	9	14	38	18	0.853	-0.069	4.213	0.013	0.01	0	40.4	35.7	76.1	127	115	0	33	32
2014	7	9	14	48	18	0.843	-0.079	4.213	0.013	0.01	0	39.6	35.7	77.4	126	114	0	34	31
2014	7	9	14	58	18	0.86	-0.118	4.213	0.01	0.007	0	39.6	35.7	65.8	126	114	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	15	8	18	0.807	-0.072	4.213	0.016	0.016	0	40	35.7	64.5	127	115	0	34	32
2014	7	9	15	18	18	0.869	-0.115	4.213	0.013	0.01	0	40.9	36.1	77	128	115	0	33	31
2014	7	9	15	28	18	0.863	-0.075	4.213	0.01	0.007	0	40	36.1	76.1	127	115	0	34	31
2014	7	9	15	38	18	0.833	-0.082	4.213	0.01	0.007	0	40.9	36.1	77.4	128	115	0	33	31
2014	7	9	15	48	18	0.876	-0.079	4.213	0.01	0.007	0	40.9	36.1	75.3	128	115	0	33	31
2014	7	9	15	58	18	0.879	-0.092	4.213	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	9	16	8	18	0.853	-0.082	4.213	0.016	0.013	0	40.4	36.5	74	128	116	0	34	31
2014	7	9	16	18	18	0.833	-0.066	4.213	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	9	16	28	18	0.863	-0.056	4.213	0.013	0.01	0	40.4	36.5	76.1	128	116	0	34	31
2014	7	9	16	38	18	0.807	-0.112	4.213	0.013	0.01	0	40.9	36.5	76.1	128	116	0	33	31
2014	7	9	16	48	18	0.902	-0.102	4.209	0.01	0.007	0	41.3	37	75.3	129	117	0	33	31
2014	7	9	16	58	18	0.883	-0.089	4.209	0.01	0.007	0	41.3	36.1	74	129	116	0	33	32
2014	7	9	17	8	18	0.853	-0.069	4.209	0.01	0.007	0	40.9	36.5	74	129	116	0	34	31
2014	7	9	17	18	18	0.833	-0.072	4.209	0.01	0.007	0	40.9	36.5	73.5	129	116	0	34	31
2014	7	9	17	28	18	0.84	-0.082	4.209	0.013	0.01	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	9	17	38	18	0.879	-0.095	4.209	0.01	0.007	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	9	17	48	18	0.869	-0.085	4.209	0.01	0.007	0	40.4	36.1	71	128	115	0	34	31
2014	7	9	17	58	18	0.814	-0.082	4.209	0.01	0.007	0	40.9	36.5	71.4	129	116	0	34	31
2014	7	9	18	8	18	0.833	-0.072	4.209	0.013	0.01	0	40.9	36.5	74	129	116	0	34	31
2014	7	9	18	18	18	0.827	-0.075	4.209	0.01	0.007	0	40.9	36.5	74	128	116	0	33	31
2014	7	9	18	28	18	0.837	-0.102	4.209	0.01	0.007	0	41.3	36.5	72.7	129	116	0	33	31
2014	7	9	18	38	18	0.846	-0.115	4.209	0.01	0.007	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	9	18	48	18	0.876	-0.069	4.209	0.013	0.01	0	40.9	37	74	129	117	0	34	31
2014	7	9	18	58	18	0.876	-0.092	4.209	0.01	0.007	0	41.3	37	74	130	117	0	34	31
2014	7	9	19	8	18	0.84	-0.112	4.209	0.01	0.007	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	9	19	18	18	0.876	-0.102	4.209	0.01	0.007	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	9	19	28	18	0.879	-0.112	4.209	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	9	19	38	18	0.856	-0.098	4.209	0.01	0.007	0	41.3	36.5	75.3	129	116	0	33	31
2014	7	9	19	48	18	0.896	-0.095	4.209	0.016	0.013	0	41.3	37	76.1	130	117	0	34	31
2014	7	9	19	58	18	0.873	-0.079	4.209	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	9	20	8	18	0.912	-0.098	4.209	0.013	0.01	0	41.7	37.4	75.3	130	118	0	33	31
2014	7	9	20	18	18	0.889	-0.072	4.209	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	9	20	28	18	0.863	-0.089	4.213	0.01	0.007	0	41.7	36.5	74.8	130	117	0	33	32
2014	7	9	20	38	18	0.866	-0.095	4.213	0.01	0.007	0	42.1	37.4	73.1	131	118	0	33	31
2014	7	9	20	48	18	0.879	-0.052	4.213	0.01	0.007	0	42.1	37.8	72.7	132	119	0	34	31
2014	7	9	20	58	18	0.879	-0.052	4.213	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	9	21	8	18	0.856	-0.072	4.213	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	9	21	18	18	0.833	-0.082	4.213	0.01	0.007	0	41.7	36.5	76.1	130	117	0	33	32
2014	7	9	21	28	18	0.846	-0.069	4.213	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	9	21	38	18	0.896	-0.085	4.213	0.01	0.007	0	41.3	36.5	76.1	130	116	0	34	31
2014	7	9	21	48	18	0.876	-0.043	4.213	0.01	0.007	0	41.7	36.5	76.1	130	117	0	33	32
2014	7	9	21	58	18	0.922	-0.089	4.213	0.013	0.01	0	41.7	36.5	77	130	116	0	33	31
2014	7	9	22	8	18	0.866	-0.049	4.213	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	9	22	18	18	0.912	-0.075	4.213	0.013	0.01	0	41.3	37	77	130	117	0	34	31
2014	7	9	22	28	18	0.853	-0.049	4.213	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	9	22	38	18	0.866	-0.089	4.213	0.01	0.007	0	41.7	37	77	130	117	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	9	22	48	18	0.886	-0.069	4.213	0.013	0.01	0	40.9	37	77	129	117	0	34	31
2014	7	9	22	58	18	0.886	-0.066	4.213	0.01	0.007	0	40.9	36.1	77.4	129	116	0	34	32
2014	7	9	23	8	18	0.896	-0.085	4.213	0.01	0.007	0	41.7	37.4	77.4	130	118	0	33	31
2014	7	9	23	18	18	0.843	-0.095	4.216	0.013	0.01	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	9	23	28	18	0.886	-0.052	4.216	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	9	23	38	18	0.876	-0.079	4.216	0.01	0.007	0	41.3	36.5	76.5	129	116	0	33	31
2014	7	9	23	48	18	0.846	-0.069	4.213	0.01	0.007	0	41.3	36.5	77.4	130	117	0	34	32
2014	7	9	23	58	18	0.892	-0.072	4.216	0.01	0.007	0	40.9	36.5	77.4	129	117	0	34	32
2014	7	10	0	8	18	0.879	-0.059	4.216	0.01	0.007	0	41.7	37	77	130	117	0	33	31
2014	7	10	0	18	18	0.846	-0.102	4.216	0.01	0.007	0	41.3	37	77	130	117	0	34	31
2014	7	10	0	28	18	0.84	-0.062	4.216	0.01	0.007	0	41.7	37	76.1	130	117	0	33	31
2014	7	10	0	38	18	0.827	-0.075	4.216	0.01	0.007	0	42.6	37.8	77	132	119	0	33	31
2014	7	10	0	48	18	0.856	-0.066	4.216	0.01	0.007	0	41.7	37	76.5	130	118	0	33	32
2014	7	10	0	58	18	0.883	-0.066	4.216	0.01	0.007	0	41.3	37.4	77.4	130	118	0	34	31
2014	7	10	1	8	18	0.85	-0.121	4.216	0.01	0.007	0	41.3	37	76.1	130	117	0	34	31
2014	7	10	1	18	18	0.876	-0.082	4.216	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	10	1	28	18	0.869	-0.049	4.216	0.013	0.01	0	41.3	37	77.4	130	117	0	34	31
2014	7	10	1	38	18	0.889	-0.062	4.216	0.013	0.01	0	41.3	37	77.4	130	117	0	34	31
2014	7	10	1	48	18	0.892	-0.066	4.216	0.01	0.007	0	41.3	37	77	129	117	0	33	31
2014	7	10	1	58	18	0.846	-0.062	4.216	0.013	0.01	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	10	2	8	18	0.889	-0.059	4.216	0.016	0.013	0	41.7	37	76.5	130	117	0	33	31
2014	7	10	2	18	18	0.856	-0.098	4.216	0.01	0.007	0	41.3	37	77	130	117	0	34	31
2014	7	10	2	28	18	0.869	-0.062	4.216	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	10	2	38	18	0.876	-0.066	4.216	0.013	0.01	0	41.3	37	76.5	130	117	0	34	31
2014	7	10	2	48	18	0.883	-0.089	4.216	0.013	0.01	0	40.9	37	76.5	129	117	0	34	31
2014	7	10	2	58	18	0.876	-0.056	4.216	0.01	0.007	0	41.3	37	76.1	130	117	0	34	31
2014	7	10	3	8	18	0.886	-0.069	4.216	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	10	3	18	18	0.84	-0.098	4.216	0.013	0.01	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	10	3	28	18	0.896	-0.062	4.219	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	10	3	38	18	0.902	-0.062	4.219	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	10	3	48	18	0.912	-0.062	4.219	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	10	3	58	18	0.873	-0.062	4.219	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	10	4	8	18	0.902	-0.079	4.219	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	10	4	18	18	0.889	-0.075	4.219	0.01	0.007	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	10	4	28	18	0.843	-0.062	4.219	0.016	0.013	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	10	4	38	18	0.873	-0.052	4.219	0.013	0.01	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	10	4	48	18	0.876	-0.082	4.219	0.01	0.007	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	10	4	58	18	0.886	-0.082	4.219	0.013	0.01	0	41.7	37	74.4	131	118	0	34	32
2014	7	10	5	8	18	0.902	-0.098	4.219	0.01	0.007	0	41.7	37.8	73.5	131	119	0	34	31
2014	7	10	5	18	18	0.879	-0.098	4.219	0.013	0.01	0	41.7	37.4	71.8	131	118	0	34	31
2014	7	10	5	28	18	0.86	-0.098	4.219	0.016	0.013	0	42.1	37.8	72.7	132	119	0	34	31
2014	7	10	5	38	18	0.866	-0.079	4.222	0.01	0.007	0	42.1	38.3	73.5	132	120	0	34	31
2014	7	10	5	48	18	0.889	-0.079	4.226	0.01	0.007	0	42.1	38.3	73.1	132	120	0	34	31
2014	7	10	5	58	18	0.906	-0.102	4.226	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	10	6	8	18	0.86	-0.066	4.229	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	10	6	18	18	0.899	-0.079	4.229	0.016	0.013	0	42.1	37.4	73.5	132	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	6	28	18	0.899	-0.043	4.232	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	10	6	38	18	0.909	-0.082	4.232	0.016	0.013	0	41.7	37	74	131	118	0	34	32
2014	7	10	6	48	18	0.902	-0.095	4.232	0.01	0.007	0	41.3	37.4	74.4	130	118	0	34	31
2014	7	10	6	58	18	0.879	-0.062	4.236	0.013	0.01	0	41.7	37	73.5	131	118	0	34	32
2014	7	10	7	8	18	0.856	-0.043	4.236	0.016	0.013	0	41.7	37	74	131	118	0	34	32
2014	7	10	7	18	18	0.896	-0.085	4.236	0.013	0.01	0	41.7	37	74.8	131	118	0	34	32
2014	7	10	7	28	18	0.873	-0.128	4.236	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	10	7	38	18	0.817	-0.075	4.236	0.01	0.007	0	41.3	37	74.8	131	118	0	35	32
2014	7	10	7	48	18	0.843	-0.072	4.236	0.01	0.007	0	41.3	37.4	75.3	130	118	0	34	31
2014	7	10	7	58	18	0.879	-0.095	4.236	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	10	8	8	18	0.856	-0.085	4.236	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	10	8	18	18	0.902	-0.089	4.236	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	10	8	28	18	0.889	-0.085	4.236	0.013	0.01	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	10	8	38	18	0.869	-0.082	4.236	0.013	0.01	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	10	8	48	18	0.876	-0.062	4.236	0.01	0.007	0	41.3	37.4	75.3	130	118	0	34	31
2014	7	10	8	58	18	0.883	-0.108	4.236	0.01	0.007	0	41.3	36.5	74.4	130	117	0	34	32
2014	7	10	9	8	18	0.846	-0.049	4.239	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	10	9	18	18	0.86	-0.079	4.236	0.01	0.007	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	10	9	28	18	0.899	-0.108	4.236	0.01	0.007	0	40.9	37.4	74.8	130	118	0	35	31
2014	7	10	9	38	18	0.86	-0.072	4.239	0.013	0.01	0	41.3	37	75.7	130	118	0	34	32
2014	7	10	9	48	18	0.873	-0.059	4.239	0.01	0.007	0	41.3	37	74.8	130	118	0	34	32
2014	7	10	9	58	18	0.899	-0.072	4.239	0.01	0.007	0	41.7	37	75.3	130	118	0	33	32
2014	7	10	10	8	18	0.85	-0.082	4.239	0.01	0.007	0	40.9	37	74.8	130	118	0	35	32
2014	7	10	10	18	18	0.853	-0.046	4.239	0.01	0.007	0	41.7	37.4	74	130	118	0	33	31
2014	7	10	10	28	18	0.827	-0.105	4.239	0.01	0.007	0	41.3	37	74.8	130	118	0	34	32
2014	7	10	10	38	18	0.843	-0.079	4.239	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	10	10	48	18	0.837	-0.095	4.239	0.01	0.007	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	10	10	58	18	0.817	-0.105	4.236	0.01	0.007	0	41.3	37	73.1	130	117	0	34	31
2014	7	10	11	8	18	0.876	-0.089	4.236	0.01	0.007	0	41.3	36.5	73.1	130	117	0	34	32
2014	7	10	11	18	18	0.86	-0.105	4.232	0.01	0.007	0	40.9	36.5	61.5	129	117	0	34	32
2014	7	10	11	28	18	0.814	-0.085	4.236	0.01	0.007	0	40.9	37	72.7	129	117	0	34	31
2014	7	10	11	38	18	0.82	-0.108	4.232	0.01	0.007	0	40.9	37	70.5	129	117	0	34	31
2014	7	10	11	48	18	0.833	-0.089	4.232	0.01	0.007	0	40.9	37	71.8	129	117	0	34	31
2014	7	10	11	58	18	0.876	-0.079	4.232	0.013	0.01	0	40.9	36.5	65.4	129	117	0	34	32
2014	7	10	12	8	18	0.856	-0.108	4.229	0.013	0.01	0	40.9	36.5	69.7	129	116	0	34	31
2014	7	10	12	18	18	0.866	-0.095	4.229	0.01	0.007	0	40.9	37	58.5	129	117	0	34	31
2014	7	10	12	28	18	0.823	-0.085	4.229	0.01	0.007	0	41.3	36.5	54.6	130	117	0	34	32
2014	7	10	12	38	18	0.869	-0.072	4.229	0.013	0.01	0	41.3	37	54.2	130	117	0	34	31
2014	7	10	12	48	18	0.823	-0.098	4.229	0.01	0.007	0	41.7	37.4	54.2	131	119	0	34	32
2014	7	10	12	58	18	0.886	-0.135	4.226	0.01	0.007	0	40.9	36.5	58	129	117	0	34	32
2014	7	10	13	8	18	0.82	-0.098	4.229	0.013	0.01	0	41.7	37.4	55	130	118	0	33	31
2014	7	10	13	18	18	0.853	-0.082	4.229	0.013	0.01	0	41.3	37	55.9	130	118	0	34	32
2014	7	10	13	28	18	0.869	-0.062	4.229	0.01	0.007	0	41.3	37.4	54.6	130	118	0	34	31
2014	7	10	13	38	18	0.823	-0.085	4.226	0.01	0.007	0	42.1	37.4	55.5	131	118	0	33	31
2014	7	10	13	48	18	0.869	-0.095	4.229	0.01	0.007	0	42.1	37.8	52.5	132	120	0	34	32
2014	7	10	13	58	18	0.794	-0.056	4.226	0.01	0.007	0	42.1	38.3	55	132	120	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	14	8	18	0.856	-0.085	4.226	0.01	0.007	0	41.7	38.3	53.3	131	120	0	34	31
2014	7	10	14	18	18	0.817	-0.089	4.226	0.01	0.007	0	41.7	37.8	53.8	131	119	0	34	31
2014	7	10	14	28	18	0.784	-0.072	4.226	0.01	0.007	0	42.1	38.3	56.8	132	120	0	34	31
2014	7	10	14	38	18	0.846	-0.085	4.222	0.01	0.007	0	42.1	38.3	53.3	132	120	0	34	31
2014	7	10	14	48	18	0.794	-0.052	4.226	0.01	0.007	0	41.3	37	55	131	118	0	35	32
2014	7	10	14	58	18	0.837	-0.062	4.222	0.01	0.007	0	41.7	37.4	57.2	130	118	0	33	31
2014	7	10	15	8	18	0.846	-0.075	4.222	0.013	0.01	0	41.7	37.4	59.8	130	118	0	33	31
2014	7	10	15	18	18	0.892	-0.072	4.222	0.013	0.01	0	41.3	37.4	61.5	130	118	0	34	31
2014	7	10	15	28	18	0.843	-0.072	4.222	0.013	0.01	0	41.7	37.4	52.5	130	118	0	33	31
2014	7	10	15	38	18	0.863	-0.085	4.219	0.01	0.007	0	40.9	37	58.9	129	117	0	34	31
2014	7	10	15	48	18	0.807	-0.079	4.219	0.01	0.007	0	41.3	37	59.8	130	117	0	34	31
2014	7	10	15	58	18	0.82	-0.085	4.219	0.01	0.007	0	41.3	37.4	57.6	130	118	0	34	31
2014	7	10	16	8	18	0.869	-0.085	4.219	0.013	0.01	0	41.3	37	63.6	129	117	0	33	31
2014	7	10	16	18	18	0.856	-0.092	4.219	0.013	0.01	0	40.9	36.5	60.6	129	117	0	34	32
2014	7	10	16	28	18	0.833	-0.079	4.219	0.013	0.01	0	40.9	37	61.9	129	117	0	34	31
2014	7	10	16	38	18	0.833	-0.082	4.219	0.013	0.01	0	40.9	37	58.9	129	117	0	34	31
2014	7	10	16	48	18	0.886	-0.062	4.216	0.013	0.01	0	40.9	37	64.5	129	117	0	34	31
2014	7	10	16	58	18	0.86	-0.089	4.219	0.01	0.007	0	41.7	37	57.2	130	117	0	33	31
2014	7	10	17	8	18	0.866	-0.098	4.216	0.01	0.007	0	40.9	37	58.9	129	117	0	34	31
2014	7	10	17	18	18	0.823	-0.049	4.216	0.01	0.007	0	40.9	37	66.7	129	117	0	34	31
2014	7	10	17	28	18	0.827	-0.072	4.216	0.01	0.007	0	41.3	37.4	58.9	130	118	0	34	31
2014	7	10	17	38	18	0.869	-0.075	4.216	0.01	0.007	0	41.3	37	61.5	130	118	0	34	32
2014	7	10	17	48	18	0.856	-0.079	4.216	0.01	0.007	0	41.3	37	62.4	130	118	0	34	32
2014	7	10	17	58	18	0.873	-0.075	4.216	0.01	0.007	0	42.1	37.4	59.3	131	118	0	33	31
2014	7	10	18	8	18	0.846	-0.085	4.216	0.013	0.01	0	41.3	37	68.4	130	118	0	34	32
2014	7	10	18	18	18	0.869	-0.059	4.216	0.01	0.007	0	40.9	37	59.8	129	117	0	34	31
2014	7	10	18	28	18	0.827	-0.112	4.216	0.013	0.01	0	41.3	37	65.8	130	118	0	34	32
2014	7	10	18	38	18	0.853	-0.108	4.216	0.01	0.007	0	41.3	37	63.2	130	117	0	34	31
2014	7	10	18	48	18	0.84	-0.079	4.216	0.01	0.007	0	41.3	37	65.4	130	118	0	34	32
2014	7	10	18	58	18	0.866	-0.089	4.216	0.013	0.01	0	41.7	37.4	59.3	131	118	0	34	31
2014	7	10	19	8	18	0.863	-0.098	4.216	0.01	0.007	0	40.9	37	69.2	130	118	0	35	32
2014	7	10	19	18	18	0.866	-0.062	4.216	0.01	0.007	0	41.3	37.4	68.8	130	118	0	34	31
2014	7	10	19	28	18	0.85	-0.056	4.216	0.01	0.007	0	41.3	37	68.8	130	118	0	34	32
2014	7	10	19	38	18	0.883	-0.089	4.213	0.01	0.007	0	41.3	37.4	63.6	130	118	0	34	31
2014	7	10	19	48	18	0.873	-0.062	4.216	0.01	0.007	0	41.3	37.4	66.2	130	118	0	34	31
2014	7	10	19	58	18	0.873	-0.056	4.216	0.013	0.01	0	41.7	37.4	66.7	131	118	0	34	31
2014	7	10	20	8	18	0.843	-0.079	4.216	0.016	0.013	0	41.7	37.8	67.9	131	119	0	34	31
2014	7	10	20	18	18	0.856	-0.066	4.213	0.013	0.01	0	42.1	37.8	67.5	132	119	0	34	31
2014	7	10	20	28	18	0.866	-0.079	4.216	0.01	0.007	0	41.3	37.4	73.5	131	119	0	35	32
2014	7	10	20	38	18	0.833	-0.072	4.213	0.01	0.007	0	42.1	37.8	65.8	132	119	0	34	31
2014	7	10	20	48	18	0.879	-0.092	4.213	0.01	0.007	0	42.1	37.8	59.8	132	119	0	34	31
2014	7	10	20	58	18	0.85	-0.079	4.216	0.016	0.013	0	42.6	38.3	59.3	133	120	0	34	31
2014	7	10	21	8	18	0.823	-0.056	4.216	0.013	0.01	0	41.7	38.3	61.1	132	120	0	35	31
2014	7	10	21	18	18	0.823	-0.105	4.216	0.01	0.007	0	43	38.3	59.3	133	120	0	33	31
2014	7	10	21	28	18	0.856	-0.066	4.216	0.016	0.013	0	42.1	38.3	58.9	132	120	0	34	31
2014	7	10	21	38	18	0.817	-0.056	4.213	0.01	0.007	0	42.1	37.8	60.6	132	120	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	10	21	48	18	0.83	-0.062	4.213	0.01	0.007	0	42.1	37.8	61.1	132	119	0	34	31
2014	7	10	21	58	18	0.83	-0.098	4.213	0.01	0.007	0	41.7	37	67.1	131	118	0	34	32
2014	7	10	22	8	18	0.846	-0.075	4.216	0.013	0.01	0	41.3	37	66.2	130	117	0	34	31
2014	7	10	22	18	18	0.843	-0.016	4.216	0.01	0.007	0	40.9	37	77.4	129	117	0	34	31
2014	7	10	22	28	18	0.869	-0.092	4.216	0.01	0.007	0	40.9	37	77	129	117	0	34	31
2014	7	10	22	38	18	0.804	-0.052	4.216	0.01	0.007	0	41.3	37	77	129	117	0	33	31
2014	7	10	22	48	18	0.843	-0.066	4.216	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	10	22	58	18	0.823	-0.066	4.216	0.01	0.007	0	40.9	37	74.8	129	117	0	34	31
2014	7	10	23	8	18	0.889	-0.102	4.216	0.01	0.007	0	41.3	36.1	75.7	129	116	0	33	32
2014	7	10	23	18	18	0.82	-0.059	4.216	0.01	0.007	0	40.9	36.5	75.7	129	116	0	34	31
2014	7	10	23	28	18	0.869	-0.066	4.216	0.013	0.01	0	40.9	36.5	74.8	129	116	0	34	31
2014	7	10	23	38	18	0.856	-0.066	4.216	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	10	23	48	18	0.886	-0.098	4.216	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	10	23	58	18	0.837	-0.089	4.216	0.01	0.007	0	40.9	36.5	71	129	116	0	34	31
2014	7	11	0	8	18	0.856	-0.112	4.213	0.01	0.007	0	41.3	37	67.9	130	118	0	34	32
2014	7	11	0	18	18	0.883	-0.066	4.216	0.013	0.01	0	41.3	37	67.9	130	117	0	34	31
2014	7	11	0	28	18	0.889	-0.079	4.216	0.01	0.007	0	40.9	37	74	129	117	0	34	31
2014	7	11	0	38	18	0.856	-0.066	4.216	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	11	0	48	18	0.886	-0.098	4.216	0.013	0.01	0	40.9	37	76.1	129	117	0	34	31
2014	7	11	0	58	18	0.837	-0.082	4.216	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	11	1	8	18	0.876	-0.079	4.216	0.01	0.007	0	40.9	36.5	75.3	129	117	0	34	32
2014	7	11	1	18	18	0.866	-0.085	4.216	0.016	0.013	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	11	1	28	18	0.876	-0.115	4.216	0.013	0.01	0	41.3	36.5	74	129	116	0	33	31
2014	7	11	1	38	18	0.84	-0.092	4.216	0.01	0.007	0	40.4	37	74.4	129	117	0	35	31
2014	7	11	1	48	18	0.833	-0.066	4.216	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	11	1	58	18	0.85	-0.108	4.216	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	11	2	8	18	0.866	-0.085	4.216	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	11	2	18	18	0.873	-0.098	4.219	0.013	0.01	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	11	2	28	18	0.902	-0.049	4.219	0.01	0.007	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	11	2	38	18	0.873	-0.098	4.216	0.01	0.007	0	40.4	36.1	75.7	128	116	0	34	32
2014	7	11	2	48	18	0.843	-0.033	4.219	0.01	0.007	0	40.9	37	75.7	129	117	0	34	31
2014	7	11	2	58	18	0.876	-0.138	4.219	0.01	0.007	0	40.9	36.5	75.3	129	116	0	34	31
2014	7	11	3	8	18	0.84	-0.059	4.219	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	11	3	18	18	0.85	-0.108	4.219	0.01	0.007	0	40.9	36.5	74.8	129	117	0	34	32
2014	7	11	3	28	18	0.863	-0.069	4.219	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	11	3	38	18	0.846	-0.082	4.219	0.01	0.007	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	11	3	48	18	0.866	-0.075	4.219	0.01	0.007	0	41.3	36.5	74.4	130	117	0	34	32
2014	7	11	3	58	18	0.902	-0.079	4.219	0.013	0.01	0	41.3	36.5	75.3	129	117	0	33	32
2014	7	11	4	8	18	0.866	-0.072	4.219	0.01	0.007	0	40.9	36.5	74.4	129	117	0	34	32
2014	7	11	4	18	18	0.85	-0.098	4.219	0.01	0.007	0	40.9	36.5	74.4	129	117	0	34	32
2014	7	11	4	28	18	0.85	-0.072	4.219	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	11	4	38	18	0.869	-0.062	4.222	0.01	0.007	0	41.3	36.5	74	130	117	0	34	32
2014	7	11	4	48	18	0.853	-0.066	4.222	0.013	0.01	0	41.3	36.5	73.1	129	117	0	33	32
2014	7	11	4	58	18	0.83	-0.069	4.222	0.01	0.007	0	40.9	37	73.5	129	117	0	34	31
2014	7	11	5	8	18	0.833	-0.039	4.226	0.01	0.007	0	41.3	37	74.4	130	118	0	34	32
2014	7	11	5	18	18	0.846	-0.082	4.229	0.01	0.007	0	41.7	37.8	73.5	131	119	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	5	28	18	0.873	-0.062	4.229	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	11	5	38	18	0.899	-0.052	4.232	0.013	0.01	0	41.7	37.8	74	131	119	0	34	31
2014	7	11	5	48	18	0.873	-0.059	4.232	0.01	0.007	0	41.7	37.4	74.4	131	119	0	34	32
2014	7	11	5	58	18	0.886	-0.079	4.232	0.01	0.007	0	41.7	37.4	74.8	131	119	0	34	32
2014	7	11	6	8	18	0.873	-0.062	4.232	0.01	0.007	0	42.1	37.8	74.4	131	119	0	33	31
2014	7	11	6	18	18	0.863	-0.079	4.232	0.01	0.007	0	41.7	37.8	74.8	131	119	0	34	31
2014	7	11	6	28	18	0.853	-0.082	4.232	0.01	0.007	0	41.7	37.4	74.4	131	119	0	34	32
2014	7	11	6	38	18	0.86	-0.082	4.232	0.01	0.007	0	41.7	37.4	74	130	118	0	33	31
2014	7	11	6	48	18	0.876	-0.069	4.236	0.01	0.007	0	41.3	37.4	75.3	130	118	0	34	31
2014	7	11	6	58	18	0.876	-0.072	4.236	0.013	0.01	0	40.9	36.5	75.3	129	117	0	34	32
2014	7	11	7	8	18	0.846	-0.079	4.236	0.013	0.01	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	11	7	18	18	0.853	-0.082	4.236	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	11	7	28	18	0.892	-0.095	4.236	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	11	7	38	18	0.853	-0.079	4.236	0.01	0.007	0	41.3	36.1	75.3	129	116	0	33	32
2014	7	11	7	48	18	0.86	-0.072	4.236	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	11	7	58	18	0.873	-0.043	4.236	0.01	0.007	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	11	8	8	18	0.873	-0.075	4.236	0.01	0.007	0	41.3	37.4	71.8	130	118	0	34	31
2014	7	11	8	18	18	0.879	-0.089	4.236	0.01	0.007	0	41.3	37.4	75.7	131	119	0	35	32
2014	7	11	8	28	18	0.833	-0.062	4.236	0.01	0.007	0	41.7	37.8	73.5	131	119	0	34	31
2014	7	11	8	38	18	0.902	-0.072	4.236	0.01	0.007	0	41.7	37.4	72.2	131	119	0	34	32
2014	7	11	8	48	18	0.846	-0.095	4.236	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	11	8	58	18	0.892	-0.056	4.236	0.013	0.01	0	41.3	37.4	74.4	130	118	0	34	31
2014	7	11	9	8	18	0.853	-0.066	4.236	0.013	0.01	0	41.3	37	76.5	130	117	0	34	31
2014	7	11	9	18	18	0.873	-0.075	4.236	0.016	0.013	0	41.3	37	76.5	130	118	0	34	32
2014	7	11	9	28	18	0.883	-0.092	4.239	0.01	0.007	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	11	9	38	18	0.856	-0.062	4.236	0.013	0.01	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	11	9	48	18	0.873	-0.069	4.236	0.013	0.01	0	40.9	37	76.1	130	118	0	35	32
2014	7	11	9	58	18	0.853	-0.062	4.236	0.01	0.007	0	40.9	37	75.7	129	117	0	34	31
2014	7	11	10	8	18	0.869	-0.079	4.239	0.016	0.013	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	11	10	18	18	0.873	-0.079	4.239	0.013	0.01	0	40.9	37	75.3	129	118	0	34	32
2014	7	11	10	28	18	0.817	-0.082	4.236	0.01	0.007	0	40.9	37	67.9	129	117	0	34	31
2014	7	11	10	38	18	0.843	-0.105	4.232	0.013	0.01	0	41.3	37.4	58.5	130	118	0	34	31
2014	7	11	10	48	18	0.827	-0.079	4.232	0.01	0.007	0	41.3	37	54.6	130	118	0	34	32
2014	7	11	10	58	18	0.837	-0.089	4.236	0.013	0.01	0	40.9	36.5	59.8	129	117	0	34	32
2014	7	11	11	8	18	0.833	-0.059	4.232	0.01	0.007	0	40.4	36.5	58.9	128	117	0	34	32
2014	7	11	11	18	18	0.853	-0.066	4.232	0.01	0.007	0	40.9	37	56.8	129	117	0	34	31
2014	7	11	11	28	18	0.846	-0.075	4.229	0.01	0.007	0	40.9	36.1	58.5	129	116	0	34	32
2014	7	11	11	38	18	0.892	-0.079	4.229	0.01	0.007	0	40.9	36.5	55.9	129	117	0	34	32
2014	7	11	11	48	18	0.83	-0.059	4.232	0.016	0.013	0	40.9	37	53.8	129	117	0	34	31
2014	7	11	11	58	18	0.82	-0.089	4.229	0.01	0.007	0	41.3	37	57.6	129	117	0	33	31
2014	7	11	12	8	18	0.804	-0.049	4.229	0.013	0.01	0	40.9	37	57.2	129	118	0	34	32
2014	7	11	12	18	18	0.823	-0.062	4.232	0.016	0.013	0	41.3	37.4	54.6	130	118	0	34	31
2014	7	11	12	28	18	0.804	-0.056	4.226	0.01	0.007	0	41.3	37	56.3	130	118	0	34	32
2014	7	11	12	38	18	0.869	-0.092	4.229	0.01	0.007	0	40.4	36.5	54.6	129	117	0	35	32
2014	7	11	12	48	18	0.853	-0.049	4.229	0.016	0.013	0	41.3	37.4	54.2	130	118	0	34	31
2014	7	11	12	58	18	0.791	-0.069	4.226	0.01	0.007	0	41.3	37.4	53.8	130	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	13	8	18	0.823	-0.066	4.222	0.01	0.007	0	41.3	37	63.2	129	117	0	33	31
2014	7	11	13	18	18	0.853	-0.115	4.222	0.01	0.007	0	40.9	37.4	55.5	129	118	0	34	31
2014	7	11	13	28	18	0.873	-0.082	4.226	0.016	0.013	0	40.9	36.5	55	129	117	0	34	32
2014	7	11	13	38	18	0.83	-0.082	4.222	0.01	0.007	0	40.4	36.5	55	128	116	0	34	31
2014	7	11	13	48	18	0.84	-0.082	4.226	0.01	0.007	0	40.9	37	55	129	117	0	34	31
2014	7	11	13	58	18	0.86	-0.095	4.222	0.01	0.007	0	41.3	37	57.2	129	117	0	33	31
2014	7	11	14	8	18	0.83	-0.102	4.226	0.013	0.01	0	40.9	36.1	54.6	129	116	0	34	32
2014	7	11	14	18	18	0.84	-0.082	4.222	0.01	0.007	0	40.9	37	57.6	129	117	0	34	31
2014	7	11	14	28	18	0.873	-0.092	4.222	0.01	0.007	0	40.4	36.5	56.3	128	116	0	34	31
2014	7	11	14	38	18	0.807	-0.079	4.222	0.01	0.007	0	40.4	36.5	54.2	128	116	0	34	31
2014	7	11	14	48	18	0.86	-0.072	4.222	0.016	0.013	0	40.4	36.5	55	128	117	0	34	32
2014	7	11	14	58	18	0.827	-0.098	4.219	0.01	0.007	0	40.9	37	55	129	117	0	34	31
2014	7	11	15	8	18	0.817	-0.079	4.219	0.01	0.007	0	40.9	37	55.5	129	117	0	34	31
2014	7	11	15	18	18	0.82	-0.066	4.219	0.013	0.01	0	40.9	37	61.5	129	117	0	34	31
2014	7	11	15	28	18	0.84	-0.082	4.219	0.01	0.007	0	40.4	37	58.9	128	117	0	34	31
2014	7	11	15	38	18	0.843	-0.098	4.219	0.01	0.007	0	40.9	37	59.3	129	117	0	34	31
2014	7	11	15	48	18	0.833	-0.079	4.219	0.01	0.007	0	40.9	37	55.9	129	117	0	34	31
2014	7	11	15	58	18	0.883	-0.079	4.219	0.016	0.013	0	40.4	36.5	55	128	117	0	34	32
2014	7	11	16	8	18	0.846	-0.075	4.219	0.013	0.01	0	40.9	37	54.6	129	117	0	34	31
2014	7	11	16	18	18	0.837	-0.092	4.216	0.01	0.007	0	40.9	36.1	58.5	128	116	0	33	32
2014	7	11	16	28	18	0.823	-0.098	4.216	0.01	0.007	0	40.4	36.5	58.5	128	116	0	34	31
2014	7	11	16	38	18	0.82	-0.069	4.216	0.01	0.007	0	40.9	37.4	55.9	129	118	0	34	31
2014	7	11	16	48	18	0.827	-0.112	4.213	0.01	0.007	0	44.3	39.1	55.9	137	123	0	34	32
2014	7	11	16	58	18	0.876	-0.079	4.213	0.01	0.007	0	43	39.1	57.2	134	122	0	34	31
2014	7	11	17	8	18	0.814	-0.092	4.213	0.01	0.007	0	43.9	40.4	58	136	125	0	34	31
2014	7	11	17	18	18	0.827	-0.092	4.213	0.01	0.007	0	45.6	41.7	57.2	140	128	0	34	31
2014	7	11	17	28	18	0.856	-0.066	4.213	0.01	0.007	0	42.6	38.7	56.3	133	121	0	34	31
2014	7	11	17	38	18	0.827	-0.092	4.213	0.013	0.01	0	41.7	37.8	61.9	130	118	0	33	30
2014	7	11	17	48	18	0.843	-0.089	4.213	0.013	0.01	0	41.3	36.1	58	129	116	0	33	32
2014	7	11	17	58	18	0.807	-0.079	4.213	0.01	0.007	0	41.3	37	57.6	129	118	0	33	32
2014	7	11	18	8	18	0.846	-0.102	4.213	0.01	0.007	0	40.9	37	67.5	129	117	0	34	31
2014	7	11	18	18	18	0.817	-0.062	4.213	0.01	0.007	0	41.3	37.4	62.8	130	118	0	34	31
2014	7	11	18	28	18	0.85	-0.079	4.213	0.01	0.007	0	41.3	37.4	63.2	130	118	0	34	31
2014	7	11	18	38	18	0.856	-0.062	4.213	0.01	0.007	0	41.3	37.4	74.4	130	118	0	34	31
2014	7	11	18	48	18	0.892	-0.105	4.213	0.01	0.007	0	41.7	37	74.4	130	117	0	33	31
2014	7	11	18	58	18	0.837	-0.085	4.213	0.013	0.01	0	41.7	37.4	73.5	130	118	0	33	31
2014	7	11	19	8	18	0.83	-0.075	4.213	0.01	0.007	0	41.3	37.4	69.7	130	118	0	34	31
2014	7	11	19	18	18	0.85	-0.056	4.213	0.01	0.007	0	41.3	37.4	74	130	118	0	34	31
2014	7	11	19	28	18	0.86	-0.089	4.213	0.016	0.013	0	41.3	37	77	130	118	0	34	32
2014	7	11	19	38	18	0.873	-0.079	4.213	0.01	0.007	0	41.7	37	78.3	130	118	0	33	32
2014	7	11	19	48	18	0.915	-0.072	4.213	0.01	0.007	0	41.3	37.8	78.7	130	119	0	34	31
2014	7	11	19	58	18	0.85	-0.089	4.213	0.013	0.01	0	41.7	37	78.7	130	118	0	33	32
2014	7	11	20	8	18	0.846	-0.052	4.216	0.01	0.007	0	41.3	37	77.4	129	117	0	33	31
2014	7	11	20	18	18	0.863	-0.069	4.216	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	11	20	28	18	0.906	-0.089	4.213	0.016	0.013	0	40.9	37.4	78.3	129	118	0	34	31
2014	7	11	20	38	18	0.876	-0.049	4.216	0.01	0.007	0	40.9	36.5	72.7	129	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	11	20	48	18	0.879	-0.075	4.213	0.01	0.007	0	41.3	37	64.1	130	118	0	34	32
2014	7	11	20	58	18	0.856	-0.098	4.213	0.01	0.007	0	41.7	37.4	68.8	130	118	0	33	31
2014	7	11	21	8	18	0.876	-0.095	4.216	0.01	0.007	0	40.9	36.5	74.4	129	117	0	34	32
2014	7	11	21	18	18	0.86	-0.075	4.216	0.01	0.007	0	40.4	37	78.3	128	117	0	34	31
2014	7	11	21	28	18	0.843	-0.079	4.216	0.01	0.007	0	40.4	37	78.7	128	117	0	34	31
2014	7	11	21	38	18	0.876	-0.056	4.216	0.01	0.007	0	40.4	36.5	78.7	128	117	0	34	32
2014	7	11	21	48	18	0.86	-0.069	4.216	0.01	0.007	0	40.4	36.5	79.1	128	116	0	34	31
2014	7	11	21	58	18	0.883	-0.062	4.216	0.01	0.007	0	40	35.7	78.3	127	115	0	34	32
2014	7	11	22	8	18	0.846	-0.082	4.216	0.013	0.01	0	40.4	36.1	78.3	127	116	0	33	32
2014	7	11	22	18	18	0.85	-0.072	4.216	0.01	0.007	0	40	35.7	77.8	127	115	0	34	32
2014	7	11	22	28	18	0.873	-0.075	4.216	0.01	0.007	0	40.4	36.5	77.4	127	115	0	33	30
2014	7	11	22	38	18	0.873	-0.049	4.216	0.01	0.007	0	40	36.1	77.8	127	116	0	34	32
2014	7	11	22	48	18	0.889	-0.092	4.216	0.01	0.007	0	40.4	36.1	78.7	127	115	0	33	31
2014	7	11	22	58	18	0.889	-0.092	4.216	0.01	0.007	0	40	36.1	78.3	127	116	0	34	32
2014	7	11	23	8	18	0.853	-0.085	4.216	0.013	0.01	0	40	36.1	77.8	127	116	0	34	32
2014	7	11	23	18	18	0.856	-0.105	4.216	0.013	0.01	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	11	23	28	18	0.863	-0.075	4.216	0.01	0.007	0	40.9	36.1	77.4	128	116	0	33	32
2014	7	11	23	38	18	0.869	-0.102	4.216	0.01	0.007	0	40.4	35.7	77.4	128	114	0	34	31
2014	7	11	23	48	18	0.84	-0.085	4.216	0.01	0.007	0	40.4	35.3	77.4	127	114	0	33	32
2014	7	11	23	58	18	0.889	-0.098	4.216	0.01	0.007	0	40	35.7	76.5	127	115	0	34	32
2014	7	12	0	8	18	0.863	-0.069	4.216	0.01	0.007	0	40	35.3	77	127	114	0	34	32
2014	7	12	0	18	18	0.879	-0.092	4.216	0.01	0.007	0	40	35.7	77	127	114	0	34	31
2014	7	12	0	28	18	0.837	-0.098	4.216	0.01	0.007	0	40	36.5	77.4	127	116	0	34	31
2014	7	12	0	38	18	0.866	-0.049	4.216	0.01	0.007	0	39.6	36.1	77.4	127	115	0	35	31
2014	7	12	0	48	18	0.892	-0.112	4.216	0.01	0.007	0	40.9	35.7	77.4	128	115	0	33	32
2014	7	12	0	58	18	0.833	-0.066	4.216	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	12	1	8	18	0.869	-0.082	4.216	0.01	0.007	0	40	36.1	77.8	127	115	0	34	31
2014	7	12	1	18	18	0.873	-0.062	4.216	0.01	0.007	0	40	35.7	77.8	127	115	0	34	32
2014	7	12	1	28	18	0.863	-0.052	4.216	0.01	0.007	0	39.6	35.3	77.8	126	114	0	34	32
2014	7	12	1	38	18	0.906	-0.102	4.216	0.01	0.007	0	40	35.7	77.4	127	115	0	34	32
2014	7	12	1	48	18	0.883	-0.082	4.216	0.01	0.007	0	40	36.1	77	127	116	0	34	32
2014	7	12	1	58	18	0.869	-0.079	4.216	0.01	0.007	0	40	36.5	76.5	127	116	0	34	31
2014	7	12	2	8	18	0.886	-0.102	4.216	0.01	0.007	0	40	35.7	77	127	115	0	34	32
2014	7	12	2	18	18	0.883	-0.082	4.216	0.016	0.013	0	40	35.7	76.1	127	115	0	34	32
2014	7	12	2	28	18	0.869	-0.089	4.216	0.01	0.007	0	40	36.1	76.1	127	115	0	34	31
2014	7	12	2	38	18	0.879	-0.052	4.216	0.01	0.007	0	40.4	36.5	76.5	128	116	0	34	31
2014	7	12	2	48	18	0.869	-0.082	4.216	0.01	0.007	0	39.6	36.1	76.5	127	116	0	35	32
2014	7	12	2	58	18	0.833	-0.075	4.216	0.01	0.007	0	40.4	36.1	75.7	128	116	0	34	32
2014	7	12	3	8	18	0.86	-0.072	4.216	0.01	0.007	0	40	36.1	76.5	128	116	0	35	32
2014	7	12	3	18	18	0.873	-0.079	4.216	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	12	3	28	18	0.866	-0.108	4.216	0.01	0.007	0	40.4	37	75.7	128	117	0	34	31
2014	7	12	3	38	18	0.873	-0.069	4.216	0.01	0.007	0	40	37	75.7	128	117	0	35	31
2014	7	12	3	48	18	0.817	-0.085	4.216	0.01	0.007	0	40	36.5	75.3	128	117	0	35	32
2014	7	12	3	58	18	0.833	-0.069	4.216	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	12	4	8	18	0.863	-0.095	4.216	0.013	0.01	0	41.3	37	75.7	129	117	0	33	31
2014	7	12	4	18	18	0.853	-0.089	4.216	0.01	0.007	0	40.9	37.4	75.7	129	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	4	28	18	0.876	-0.079	4.216	0.01	0.007	0	40.9	37	75.3	129	118	0	34	32
2014	7	12	4	38	18	0.879	-0.082	4.216	0.01	0.007	0	41.7	37	75.3	131	117	0	34	31
2014	7	12	4	48	18	0.876	-0.049	4.216	0.013	0.01	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	12	4	58	18	0.86	-0.079	4.219	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	12	5	8	18	0.899	-0.062	4.219	0.01	0.007	0	42.1	37.8	74	132	119	0	34	31
2014	7	12	5	18	18	0.86	-0.056	4.222	0.013	0.01	0	42.1	37.8	74.8	132	119	0	34	31
2014	7	12	5	28	18	0.879	-0.066	4.226	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	12	5	38	18	0.86	-0.108	4.226	0.013	0.01	0	42.6	37.4	75.3	133	119	0	34	32
2014	7	12	5	48	18	0.906	-0.108	4.226	0.013	0.01	0	42.6	37.8	74.8	133	120	0	34	32
2014	7	12	5	58	18	0.869	-0.082	4.229	0.013	0.01	0	42.6	37.4	75.7	133	119	0	34	32
2014	7	12	6	8	18	0.846	-0.089	4.229	0.016	0.013	0	42.1	37.4	75.3	132	119	0	34	32
2014	7	12	6	18	18	0.876	-0.059	4.229	0.01	0.007	0	42.6	37.8	75.3	133	119	0	34	31
2014	7	12	6	28	18	0.866	-0.059	4.229	0.01	0.007	0	41.7	37	76.1	132	118	0	35	32
2014	7	12	6	38	18	0.873	-0.089	4.229	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2014	7	12	6	48	18	0.86	-0.062	4.229	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2014	7	12	6	58	18	0.869	-0.072	4.229	0.013	0.01	0	41.7	37	77	131	118	0	34	32
2014	7	12	7	8	18	0.873	-0.105	4.232	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	12	7	18	18	0.856	-0.085	4.229	0.01	0.007	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	12	7	28	18	0.85	-0.108	4.232	0.01	0.007	0	41.7	37	77.4	131	118	0	34	32
2014	7	12	7	38	18	0.873	-0.089	4.232	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	12	7	48	18	0.856	-0.105	4.232	0.013	0.01	0	41.3	36.5	77.4	130	117	0	34	32
2014	7	12	7	58	18	0.843	-0.092	4.232	0.01	0.007	0	41.7	37	77.4	131	117	0	34	31
2014	7	12	8	8	18	0.843	-0.118	4.232	0.01	0.007	0	41.7	37.4	77.4	131	118	0	34	31
2014	7	12	8	18	18	0.873	-0.075	4.232	0.013	0.01	0	41.7	37	77.8	131	118	0	34	32
2014	7	12	8	28	18	0.883	-0.075	4.232	0.013	0.01	0	41.7	37	77.8	131	118	0	34	32
2014	7	12	8	38	18	0.873	-0.062	4.232	0.01	0.007	0	42.1	37.4	77	132	119	0	34	32
2014	7	12	8	48	18	0.922	-0.075	4.232	0.01	0.007	0	42.6	38.3	77	133	120	0	34	31
2014	7	12	8	58	18	0.85	-0.092	4.232	0.01	0.007	0	42.1	37.8	76.5	133	120	0	35	32
2014	7	12	9	8	18	0.846	-0.079	4.232	0.01	0.007	0	42.6	37.8	77.4	133	120	0	34	32
2014	7	12	9	18	18	0.856	-0.069	4.232	0.01	0.007	0	42.1	38.3	76.5	132	120	0	34	31
2014	7	12	9	28	18	0.896	-0.062	4.232	0.01	0.007	0	42.1	37.8	77	132	119	0	34	31
2014	7	12	9	38	18	0.863	-0.098	4.232	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	12	9	48	18	0.86	-0.095	4.232	0.01	0.007	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	12	9	58	18	0.873	-0.043	4.232	0.01	0.007	0	41.3	37.8	75.7	131	119	0	35	31
2014	7	12	10	8	18	0.899	-0.069	4.232	0.016	0.013	0	41.7	37	75.7	131	118	0	34	32
2014	7	12	10	18	18	0.843	-0.075	4.232	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2014	7	12	10	28	18	0.853	-0.095	4.232	0.01	0.007	0	41.7	36.5	76.5	131	118	0	34	33
2014	7	12	10	38	18	0.876	-0.085	4.232	0.01	0.007	0	41.7	37.4	76.1	131	118	0	34	31
2014	7	12	10	48	18	0.86	-0.085	4.232	0.013	0.01	0	41.3	37.4	75.7	131	118	0	35	31
2014	7	12	10	58	18	0.863	-0.095	4.232	0.01	0.007	0	41.7	37	74.8	131	118	0	34	32
2014	7	12	11	8	18	0.833	-0.112	4.229	0.01	0.007	0	41.3	37.4	74.8	130	118	0	34	31
2014	7	12	11	18	18	0.863	-0.095	4.232	0.01	0.007	0	41.3	37.4	74.4	131	119	0	35	32
2014	7	12	11	28	18	0.892	-0.089	4.229	0.016	0.013	0	42.1	37.4	74	132	119	0	34	32
2014	7	12	11	38	18	0.85	-0.102	4.226	0.013	0.01	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	12	11	48	18	0.837	-0.098	4.229	0.01	0.007	0	41.3	37.4	74.4	131	118	0	35	31
2014	7	12	11	58	18	0.896	-0.052	4.226	0.013	0.01	0	41.7	37.4	74.8	131	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	12	8	18	0.883	-0.082	4.222	0.01	0.007	0	41.7	37	73.1	131	118	0	34	32
2014	7	12	12	18	18	0.869	-0.066	4.219	0.01	0.007	0	41.7	37.4	74	131	118	0	34	31
2014	7	12	12	28	18	0.889	-0.092	4.222	0.013	0.01	0	41.3	37	74.4	130	118	0	34	32
2014	7	12	12	38	18	0.883	-0.108	4.219	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	12	12	48	18	0.846	-0.098	4.222	0.01	0.007	0	41.7	36.5	72.7	130	117	0	33	32
2014	7	12	12	58	18	0.86	-0.105	4.219	0.01	0.007	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	12	13	8	18	0.879	-0.085	4.219	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	12	13	18	18	0.85	-0.082	4.219	0.01	0.007	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	12	13	28	18	0.873	-0.075	4.219	0.01	0.007	0	41.3	37	73.5	130	118	0	34	32
2014	7	12	13	38	18	0.837	-0.098	4.219	0.013	0.01	0	41.3	36.5	69.7	130	117	0	34	32
2014	7	12	13	48	18	0.843	-0.105	4.219	0.01	0.007	0	41.3	37.4	73.5	130	118	0	34	31
2014	7	12	13	58	18	0.833	-0.079	4.219	0.01	0.007	0	40.9	36.1	73.5	129	116	0	34	32
2014	7	12	14	8	18	0.86	-0.098	4.219	0.01	0.007	0	40.9	36.1	73.5	129	116	0	34	32
2014	7	12	14	18	18	0.807	-0.072	4.219	0.01	0.007	0	40.4	36.1	72.7	128	115	0	34	31
2014	7	12	14	28	18	0.83	-0.085	4.219	0.013	0.01	0	40.9	36.1	73.5	129	115	0	34	31
2014	7	12	14	38	18	0.833	-0.082	4.219	0.013	0.01	0	41.3	35.7	71.8	130	114	0	34	31
2014	7	12	14	48	18	0.843	-0.095	4.219	0.01	0.007	0	41.7	36.1	61.5	131	115	0	34	31
2014	7	12	14	58	18	0.837	-0.062	4.219	0.01	0.007	0	41.3	36.1	71.8	130	115	0	34	31
2014	7	12	15	8	18	0.833	-0.089	4.219	0.01	0.007	0	41.7	36.1	64.9	131	115	0	34	31
2014	7	12	15	18	18	0.82	-0.075	4.219	0.01	0.007	0	41.3	36.1	66.7	130	115	0	34	31
2014	7	12	15	28	18	0.892	-0.059	4.219	0.01	0.007	0	42.6	36.5	74.4	133	117	0	34	32
2014	7	12	15	38	18	0.86	-0.079	4.216	0.01	0.007	0	41.3	36.1	74	131	115	0	35	31
2014	7	12	15	48	18	0.827	-0.069	4.216	0.013	0.01	0	41.3	35.7	72.7	130	114	0	34	31
2014	7	12	15	58	18	0.853	-0.075	4.216	0.01	0.007	0	41.3	35.3	67.1	130	114	0	34	32
2014	7	12	16	8	18	0.856	-0.082	4.216	0.013	0.01	0	42.1	36.1	73.5	131	115	0	33	31
2014	7	12	16	18	18	0.866	-0.082	4.216	0.01	0.007	0	41.3	35.7	73.5	130	114	0	34	31
2014	7	12	16	28	18	0.866	-0.072	4.216	0.01	0.007	0	41.3	35.7	72.2	130	114	0	34	31
2014	7	12	16	38	18	0.837	-0.085	4.216	0.013	0.01	0	41.3	35.7	71.4	130	114	0	34	31
2014	7	12	16	48	18	0.82	-0.066	4.216	0.01	0.007	0	41.7	36.1	72.2	131	115	0	34	31
2014	7	12	16	58	18	0.85	-0.098	4.216	0.01	0.007	0	41.7	35.7	72.7	131	115	0	34	32
2014	7	12	17	8	18	0.902	-0.069	4.216	0.013	0.01	0	41.7	35.7	73.1	130	114	0	33	31
2014	7	12	17	18	18	0.823	-0.115	4.216	0.01	0.007	0	42.1	35.7	76.1	131	115	0	33	32
2014	7	12	17	28	18	0.86	-0.075	4.216	0.01	0.007	0	41.3	36.1	73.5	130	115	0	34	31
2014	7	12	17	38	18	0.879	-0.066	4.216	0.013	0.01	0	41.7	35.3	76.1	131	114	0	34	32
2014	7	12	17	48	18	0.892	-0.089	4.216	0.01	0.007	0	42.1	35.7	72.7	131	114	0	33	31
2014	7	12	17	58	18	0.83	-0.085	4.216	0.013	0.01	0	41.3	35.7	76.1	130	114	0	34	31
2014	7	12	18	8	18	0.817	-0.098	4.216	0.01	0.007	0	41.7	35.7	76.1	131	115	0	34	32
2014	7	12	18	18	18	0.791	-0.108	4.216	0.016	0.013	0	41.7	35.7	77.4	131	115	0	34	32
2014	7	12	18	28	18	0.827	-0.098	4.216	0.01	0.007	0	42.1	36.1	77	131	115	0	33	31
2014	7	12	18	38	18	0.827	-0.098	4.216	0.013	0.01	0	41.7	36.1	79.1	131	115	0	34	31
2014	7	12	18	48	18	0.83	-0.059	4.213	0.01	0.007	0	43	37	65.4	134	118	0	34	32
2014	7	12	18	58	18	0.843	-0.036	4.213	0.013	0.01	0	46.9	41.3	46	143	127	0	34	31
2014	7	12	19	8	18	0.846	-0.085	4.213	0.01	0.007	0	42.6	37	67.9	133	117	0	34	31
2014	7	12	19	18	18	0.879	-0.108	4.206	0.01	0.007	0	46.4	42.1	50.3	143	129	0	35	31
2014	7	12	19	28	18	0.856	-0.072	4.209	0.01	0.007	0	44.3	39.1	60.2	136	123	0	33	32
2014	7	12	19	38	18	0.866	-0.066	4.209	0.01	0.007	0	44.3	40	52.5	137	124	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	12	19	48	18	0.86	-0.059	4.209	0.01	0.007	0	45.6	41.3	51.2	140	127	0	34	31
2014	7	12	19	58	18	0.892	-0.092	4.216	0.01	0.007	0	42.6	38.3	78.3	133	120	0	34	31
2014	7	12	20	8	18	0.873	-0.079	4.209	0.01	0.007	0	44.7	40.4	53.8	138	125	0	34	31
2014	7	12	20	18	18	0.876	-0.098	4.213	0.01	0.007	0	44.3	39.6	63.2	137	123	0	34	31
2014	7	12	20	28	18	0.86	-0.085	4.216	0.013	0.01	0	42.6	37.4	75.3	132	119	0	33	32
2014	7	12	20	38	18	0.876	-0.102	4.216	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2014	7	12	20	48	18	0.876	-0.066	4.216	0.013	0.01	0	42.6	37	74.8	132	118	0	33	32
2014	7	12	20	58	18	0.902	-0.049	4.216	0.01	0.007	0	42.6	37.4	74.8	132	118	0	33	31
2014	7	12	21	8	18	0.86	-0.033	4.216	0.013	0.01	0	42.1	37.4	77.8	132	118	0	34	31
2014	7	12	21	18	18	0.876	-0.062	4.216	0.01	0.007	0	41.7	37.4	78.3	131	118	0	34	31
2014	7	12	21	28	18	0.889	-0.079	4.216	0.01	0.007	0	41.7	37	78.3	131	117	0	34	31
2014	7	12	21	38	18	0.869	-0.069	4.216	0.01	0.007	0	41.3	37	79.6	130	117	0	34	31
2014	7	12	21	48	18	0.873	-0.085	4.216	0.016	0.016	0	41.3	37	78.7	130	117	0	34	31
2014	7	12	21	58	18	0.827	-0.082	4.216	0.01	0.007	0	41.3	37	79.6	130	117	0	34	31
2014	7	12	22	8	18	0.843	-0.066	4.216	0.01	0.007	0	41.3	36.5	78.3	130	117	0	34	32
2014	7	12	22	18	18	0.883	-0.072	4.216	0.01	0.007	0	41.3	37	78.3	130	117	0	34	31
2014	7	12	22	28	18	0.856	-0.108	4.216	0.01	0.007	0	41.3	36.5	79.1	130	117	0	34	32
2014	7	12	22	38	18	0.866	-0.072	4.216	0.01	0.007	0	41.7	36.5	79.1	130	117	0	33	32
2014	7	12	22	48	18	0.827	-0.079	4.216	0.01	0.007	0	41.3	36.5	79.1	130	117	0	34	32
2014	7	12	22	58	18	0.876	-0.098	4.216	0.01	0.007	0	41.3	36.5	79.1	129	116	0	33	31
2014	7	12	23	8	18	0.889	-0.039	4.216	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	12	23	18	18	0.817	-0.056	4.216	0.01	0.007	0	41.3	37	78.7	130	117	0	34	31
2014	7	12	23	28	18	0.833	-0.066	4.216	0.013	0.01	0	41.3	36.5	79.1	130	117	0	34	32
2014	7	12	23	38	18	0.919	-0.085	4.216	0.01	0.007	0	41.3	37	78.3	130	117	0	34	31
2014	7	12	23	48	18	0.863	-0.098	4.216	0.01	0.007	0	41.7	36.5	77.8	130	117	0	33	32
2014	7	12	23	58	18	0.883	-0.089	4.216	0.01	0.007	0	41.7	37	77.8	130	117	0	33	31
2014	7	13	0	8	18	0.869	-0.075	4.216	0.01	0.007	0	41.7	37.4	76.5	131	118	0	34	31
2014	7	13	0	18	18	0.879	-0.069	4.216	0.01	0.007	0	41.3	37	78.3	130	117	0	34	31
2014	7	13	0	28	18	0.856	-0.059	4.216	0.01	0.007	0	42.1	37.8	77.8	131	118	0	33	30
2014	7	13	0	38	18	0.866	-0.079	4.216	0.01	0.007	0	41.7	37.4	77.8	131	118	0	34	31
2014	7	13	0	48	18	0.869	-0.121	4.216	0.01	0.007	0	41.3	37	78.3	130	117	0	34	31
2014	7	13	0	58	18	0.889	-0.069	4.216	0.01	0.007	0	41.3	36.5	77.4	130	117	0	34	32
2014	7	13	1	8	18	0.869	-0.079	4.216	0.01	0.007	0	41.7	37	76.5	131	117	0	34	31
2014	7	13	1	18	18	0.886	-0.062	4.216	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2014	7	13	1	28	18	0.846	-0.052	4.216	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	13	1	38	18	0.896	-0.075	4.216	0.01	0.007	0	41.7	36.5	77	130	117	0	33	32
2014	7	13	1	48	18	0.902	-0.062	4.216	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	13	1	58	18	0.883	-0.085	4.216	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	13	2	8	18	0.873	-0.069	4.216	0.01	0.007	0	41.3	37	77	130	117	0	34	31
2014	7	13	2	18	18	0.85	-0.079	4.219	0.01	0.007	0	41.3	37	77.4	130	118	0	34	32
2014	7	13	2	28	18	0.856	-0.075	4.219	0.01	0.007	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	13	2	38	18	0.876	-0.062	4.219	0.013	0.01	0	41.3	36.5	77	130	117	0	34	32
2014	7	13	2	48	18	0.866	-0.056	4.219	0.013	0.01	0	42.1	37.4	76.5	131	118	0	33	31
2014	7	13	2	58	18	0.863	-0.092	4.219	0.013	0.01	0	41.3	37	75.7	130	118	0	34	32
2014	7	13	3	8	18	0.896	-0.079	4.219	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	13	3	18	18	0.879	-0.095	4.219	0.013	0.01	0	41.7	37.4	76.1	131	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	3	28	18	0.902	-0.089	4.219	0.01	0.007	0	41.3	37.4	75.7	131	118	0	35	31
2014	7	13	3	38	18	0.879	-0.082	4.219	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	13	3	48	18	0.912	-0.056	4.222	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	13	3	58	18	0.892	-0.108	4.222	0.01	0.007	0	41.7	37.4	75.7	131	119	0	34	32
2014	7	13	4	8	18	0.853	-0.095	4.226	0.013	0.01	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	13	4	18	18	0.833	-0.069	4.226	0.01	0.007	0	42.1	37.8	74.4	132	119	0	34	31
2014	7	13	4	28	18	0.86	-0.075	4.229	0.016	0.016	0	42.1	37.4	75.3	132	119	0	34	32
2014	7	13	4	38	18	0.896	-0.095	4.229	0.01	0.007	0	42.1	37.8	74.8	132	119	0	34	31
2014	7	13	4	48	18	0.863	-0.112	4.229	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	13	4	58	18	0.889	-0.079	4.229	0.01	0.007	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	13	5	8	18	0.869	-0.105	4.229	0.01	0.007	0	42.1	37.4	74	132	119	0	34	32
2014	7	13	5	18	18	0.873	-0.095	4.229	0.01	0.007	0	42.1	37.8	75.7	132	120	0	34	32
2014	7	13	5	28	18	0.873	-0.089	4.232	0.013	0.01	0	42.1	37.8	75.3	133	120	0	35	32
2014	7	13	5	38	18	0.853	-0.105	4.232	0.01	0.007	0	42.6	38.3	74	132	120	0	33	31
2014	7	13	5	48	18	0.912	-0.095	4.232	0.01	0.007	0	42.1	37.8	75.7	132	120	0	34	32
2014	7	13	5	58	18	0.863	-0.095	4.232	0.01	0.007	0	42.6	38.7	74.8	133	121	0	34	31
2014	7	13	6	8	18	0.843	-0.108	4.232	0.013	0.01	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	13	6	18	18	0.902	-0.095	4.232	0.01	0.007	0	42.1	37.8	76.5	132	120	0	34	32
2014	7	13	6	28	18	0.876	-0.069	4.232	0.01	0.007	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	13	6	38	18	0.876	-0.085	4.232	0.01	0.007	0	42.1	37.4	76.1	132	119	0	34	32
2014	7	13	6	48	18	0.919	-0.062	4.232	0.01	0.007	0	41.7	37.8	77.4	131	119	0	34	31
2014	7	13	6	58	18	0.866	-0.095	4.232	0.01	0.007	0	41.7	37.4	77.8	131	118	0	34	31
2014	7	13	7	8	18	0.876	-0.085	4.232	0.01	0.007	0	41.7	37	78.3	131	118	0	34	32
2014	7	13	7	18	18	0.896	-0.072	4.236	0.013	0.01	0	42.1	37	76.1	131	118	0	33	32
2014	7	13	7	28	18	0.86	-0.079	4.236	0.016	0.016	0	41.3	37	77.8	130	118	0	34	32
2014	7	13	7	38	18	0.892	-0.125	4.236	0.01	0.007	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	13	7	48	18	0.856	-0.069	4.236	0.013	0.01	0	41.7	37.4	78.3	131	119	0	34	32
2014	7	13	7	58	18	0.843	-0.062	4.236	0.01	0.007	0	41.7	37	78.3	131	118	0	34	32
2014	7	13	8	8	18	0.84	-0.075	4.236	0.01	0.007	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	13	8	18	18	0.863	-0.105	4.236	0.01	0.007	0	41.7	37.4	78.3	131	119	0	34	32
2014	7	13	8	28	18	0.873	-0.095	4.236	0.01	0.007	0	41.7	37.4	78.7	131	119	0	34	32
2014	7	13	8	38	18	0.879	-0.098	4.236	0.01	0.007	0	41.7	37.8	77	131	119	0	34	31
2014	7	13	8	48	18	0.879	-0.089	4.236	0.01	0.007	0	41.3	37	77.4	130	118	0	34	32
2014	7	13	8	58	18	0.883	-0.079	4.236	0.01	0.007	0	42.1	37.8	78.7	132	120	0	34	32
2014	7	13	9	8	18	0.866	-0.069	4.236	0.013	0.01	0	42.1	37.4	78.3	132	119	0	34	32
2014	7	13	9	18	18	0.85	-0.112	4.236	0.01	0.007	0	41.7	37	77.4	131	118	0	34	32
2014	7	13	9	28	18	0.873	-0.098	4.236	0.013	0.01	0	41.7	37.8	78.3	131	119	0	34	31
2014	7	13	9	38	18	0.873	-0.089	4.236	0.01	0.007	0	42.1	38.3	77.8	132	120	0	34	31
2014	7	13	9	48	18	0.892	-0.108	4.236	0.01	0.007	0	41.3	37.4	77.4	130	119	0	34	32
2014	7	13	9	58	18	0.873	-0.069	4.236	0.01	0.007	0	41.7	37.4	78.3	131	119	0	34	32
2014	7	13	10	8	18	0.906	-0.089	4.236	0.01	0.007	0	41.7	37.4	77.8	131	119	0	34	32
2014	7	13	10	18	18	0.84	-0.062	4.236	0.01	0.007	0	41.7	37.4	77.8	131	119	0	34	32
2014	7	13	10	28	18	0.873	-0.072	4.236	0.01	0.007	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	13	10	38	18	0.873	-0.098	4.236	0.01	0.007	0	41.3	37.8	77.4	131	119	0	35	31
2014	7	13	10	48	18	0.869	-0.112	4.236	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	13	10	58	18	0.886	-0.095	4.239	0.01	0.007	0	41.3	37.8	77	130	119	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	11	8	18	0.876	-0.072	4.239	0.01	0.007	0	41.3	37	77	130	118	0	34	32
2014	7	13	11	18	18	0.846	-0.102	4.236	0.01	0.007	0	40.9	37	77	129	118	0	34	32
2014	7	13	11	28	18	0.886	-0.079	4.236	0.01	0.007	0	41.3	37	76.5	130	118	0	34	32
2014	7	13	11	38	18	0.863	-0.095	4.236	0.01	0.007	0	40.4	37	76.5	129	117	0	35	31
2014	7	13	11	48	18	0.869	-0.082	4.236	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	13	11	58	18	0.896	-0.105	4.236	0.016	0.013	0	41.3	37	75.7	130	118	0	34	32
2014	7	13	12	8	18	0.814	-0.102	4.236	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	13	12	18	18	0.883	-0.072	4.236	0.013	0.01	0	41.3	37	74.8	130	118	0	34	32
2014	7	13	12	28	18	0.856	-0.108	4.236	0.01	0.007	0	41.7	37	74.8	130	118	0	33	32
2014	7	13	12	38	18	0.896	-0.095	4.236	0.01	0.007	0	40.9	37	74.4	129	117	0	34	31
2014	7	13	12	48	18	0.807	-0.082	4.232	0.01	0.007	0	40.9	36.5	73.5	129	117	0	34	32
2014	7	13	12	58	18	0.866	-0.079	4.232	0.01	0.007	0	41.3	37	73.5	130	117	0	34	31
2014	7	13	13	8	18	0.853	-0.095	4.232	0.016	0.013	0	40.9	36.5	73.1	129	117	0	34	32
2014	7	13	13	18	18	0.82	-0.098	4.226	0.01	0.007	0	40.9	37	73.1	129	117	0	34	31
2014	7	13	13	28	18	0.85	-0.095	4.226	0.013	0.01	0	40.4	36.5	73.5	128	117	0	34	32
2014	7	13	13	38	18	0.883	-0.072	4.226	0.01	0.007	0	41.3	37	68.4	129	117	0	33	31
2014	7	13	13	48	18	0.837	-0.085	4.222	0.01	0.007	0	41.3	36.5	72.7	129	117	0	33	32
2014	7	13	13	58	18	0.889	-0.059	4.222	0.013	0.01	0	40.4	36.1	73.5	128	116	0	34	32
2014	7	13	14	8	18	0.846	-0.092	4.222	0.01	0.007	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	13	14	18	18	0.84	-0.023	4.222	0.01	0.007	0	40.4	36.1	74.8	128	116	0	34	32
2014	7	13	14	28	18	0.843	-0.089	4.222	0.01	0.007	0	40	35.7	70.5	127	115	0	34	32
2014	7	13	14	38	18	0.869	-0.095	4.222	0.01	0.007	0	40	36.1	70.1	127	115	0	34	31
2014	7	13	14	48	18	0.873	-0.079	4.222	0.01	0.007	0	40	35.7	74.4	127	115	0	34	32
2014	7	13	14	58	18	0.85	-0.066	4.219	0.01	0.007	0	40.4	35.7	68.8	128	115	0	34	32
2014	7	13	15	8	18	0.873	-0.092	4.222	0.013	0.01	0	40.9	36.5	75.7	128	116	0	33	31
2014	7	13	15	18	18	0.886	-0.085	4.222	0.01	0.007	0	40.4	36.5	76.5	128	116	0	34	31
2014	7	13	15	28	18	0.843	-0.105	4.219	0.01	0.007	0	40	35.7	77	127	115	0	34	32
2014	7	13	15	38	18	0.873	-0.079	4.219	0.013	0.01	0	40.4	36.5	77	128	116	0	34	31
2014	7	13	15	48	18	0.853	-0.092	4.219	0.01	0.007	0	40	36.5	74	127	116	0	34	31
2014	7	13	15	58	18	0.817	-0.072	4.219	0.01	0.007	0	40.4	36.5	74.4	128	117	0	34	32
2014	7	13	16	8	18	0.856	-0.095	4.219	0.01	0.007	0	40.4	36.5	76.5	128	116	0	34	31
2014	7	13	16	18	18	0.856	-0.079	4.219	0.01	0.007	0	40.4	36.5	64.5	128	116	0	34	31
2014	7	13	16	28	18	0.843	-0.075	4.219	0.01	0.007	0	40.4	36.5	67.5	128	116	0	34	31
2014	7	13	16	38	18	0.896	-0.059	4.216	0.013	0.01	0	43	38.7	44.7	134	121	0	34	31
2014	7	13	16	48	18	0.879	-0.069	4.219	0.01	0.007	0	40.9	37	64.5	129	117	0	34	31
2014	7	13	16	58	18	0.886	-0.052	4.216	0.01	0.007	0	41.3	37	57.6	129	117	0	33	31
2014	7	13	17	8	18	0.866	-0.066	4.216	0.01	0.007	0	42.6	38.3	53.3	133	120	0	34	31
2014	7	13	17	18	18	0.889	-0.108	4.216	0.01	0.007	0	40.4	36.5	51.6	128	116	0	34	31
2014	7	13	17	28	18	0.886	-0.075	4.216	0.01	0.007	0	43.4	39.6	48.6	135	123	0	34	31
2014	7	13	17	38	18	0.86	-0.066	4.216	0.01	0.007	0	40.4	37	55.9	128	117	0	34	31
2014	7	13	17	48	18	0.846	-0.01	4.216	0.01	0.007	0	43	38.7	48.6	134	121	0	34	31
2014	7	13	17	58	18	0.84	-0.079	4.213	0.013	0.01	0	41.3	37	47.7	130	117	0	34	31
2014	7	13	18	8	18	0.863	-0.102	4.209	0.01	0.007	0	41.7	37.8	49.5	131	119	0	34	31
2014	7	13	18	18	18	0.866	-0.082	4.216	0.01	0.007	0	40.4	36.1	61.5	127	115	0	33	31
2014	7	13	18	28	18	0.856	-0.089	4.216	0.01	0.007	0	40.4	36.5	56.8	128	116	0	34	31
2014	7	13	18	38	18	0.883	-0.095	4.216	0.01	0.007	0	41.7	37	52	130	117	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	13	18	48	18	0.873	-0.062	4.213	0.01	0.007	0	41.7	37.8	49	131	119	0	34	31
2014	7	13	18	58	18	0.837	-0.075	4.216	0.01	0.007	0	40	36.5	66.7	127	116	0	34	31
2014	7	13	19	8	18	0.902	-0.079	4.216	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	13	19	18	18	0.899	-0.089	4.216	0.013	0.01	0	41.3	37	78.3	129	117	0	33	31
2014	7	13	19	28	18	0.892	-0.075	4.219	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	13	19	38	18	0.873	-0.092	4.216	0.01	0.007	0	40.9	36.5	78.7	128	116	0	33	31
2014	7	13	19	48	18	0.886	-0.075	4.216	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	13	19	58	18	0.869	-0.069	4.216	0.01	0.007	0	40.9	36.5	77.8	128	116	0	33	31
2014	7	13	20	8	18	0.873	-0.079	4.216	0.013	0.01	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	13	20	18	18	0.879	-0.075	4.216	0.01	0.007	0	40.9	37	78.7	129	117	0	34	31
2014	7	13	20	28	18	0.869	-0.049	4.219	0.013	0.01	0	40.9	36.5	77.8	129	117	0	34	32
2014	7	13	20	38	18	0.86	-0.066	4.219	0.01	0.007	0	40.9	37	74	129	117	0	34	31
2014	7	13	20	48	18	0.866	-0.079	4.216	0.01	0.007	0	40.9	37	73.1	129	118	0	34	32
2014	7	13	20	58	18	0.869	-0.049	4.219	0.01	0.007	0	40.9	36.5	74	129	117	0	34	32
2014	7	13	21	8	18	0.906	-0.066	4.219	0.01	0.007	0	40.9	36.5	73.5	128	116	0	33	31
2014	7	13	21	18	18	0.879	-0.069	4.219	0.016	0.013	0	40.9	36.5	76.5	128	116	0	33	31
2014	7	13	21	28	18	0.843	-0.079	4.219	0.01	0.007	0	40.4	36.1	77.8	128	116	0	34	32
2014	7	13	21	38	18	0.922	-0.092	4.219	0.013	0.01	0	40	35.7	77.4	127	115	0	34	32
2014	7	13	21	48	18	0.876	-0.095	4.219	0.013	0.01	0	40	36.5	77	127	116	0	34	31
2014	7	13	21	58	18	0.863	-0.075	4.219	0.013	0.01	0	40.9	36.1	77	128	116	0	33	32
2014	7	13	22	8	18	0.876	-0.049	4.219	0.013	0.01	0	40	36.1	77.8	127	115	0	34	31
2014	7	13	22	18	18	0.873	-0.039	4.219	0.01	0.007	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	13	22	28	18	0.899	-0.128	4.219	0.01	0.007	0	40	35.7	77.4	127	115	0	34	32
2014	7	13	22	38	18	0.856	-0.082	4.219	0.016	0.013	0	40	36.5	77.4	127	116	0	34	31
2014	7	13	22	48	18	0.873	-0.098	4.219	0.01	0.007	0	40.4	36.1	77.8	128	115	0	34	31
2014	7	13	22	58	18	0.846	-0.043	4.219	0.01	0.007	0	40.9	36.5	77.8	128	116	0	33	31
2014	7	13	23	8	18	0.879	-0.075	4.219	0.01	0.007	0	40.4	36.1	77.4	128	116	0	34	32
2014	7	13	23	18	18	0.873	-0.062	4.219	0.013	0.01	0	40.4	36.5	77.8	128	116	0	34	31
2014	7	13	23	28	18	0.866	-0.105	4.219	0.01	0.007	0	40.9	36.1	77	128	116	0	33	32
2014	7	13	23	38	18	0.922	-0.098	4.219	0.01	0.007	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	13	23	48	18	0.873	-0.069	4.219	0.01	0.007	0	40.4	36.5	76.1	128	116	0	34	31
2014	7	13	23	58	18	0.909	-0.082	4.219	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	14	0	8	18	0.896	-0.085	4.219	0.01	0.007	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	14	0	18	18	0.883	-0.056	4.219	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	14	0	28	18	0.873	-0.085	4.222	0.013	0.01	0	40.4	37	77	128	117	0	34	31
2014	7	14	0	38	18	0.86	-0.066	4.222	0.013	0.01	0	40.9	37	76.5	129	117	0	34	31
2014	7	14	0	48	18	0.866	-0.098	4.222	0.01	0.007	0	40.4	36.1	76.5	128	116	0	34	32
2014	7	14	0	58	18	0.823	-0.066	4.222	0.013	0.01	0	40.9	37	76.5	129	117	0	34	31
2014	7	14	1	8	18	0.863	-0.049	4.222	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	14	1	18	18	0.912	-0.075	4.222	0.01	0.007	0	40.9	36.5	76.1	128	116	0	33	31
2014	7	14	1	28	18	0.869	-0.062	4.222	0.01	0.007	0	41.3	37	76.1	129	117	0	33	31
2014	7	14	1	38	18	0.902	-0.072	4.222	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	14	1	48	18	0.886	-0.102	4.222	0.01	0.007	0	40.9	37	74.4	129	117	0	34	31
2014	7	14	1	58	18	0.925	-0.072	4.222	0.01	0.007	0	40.4	36.5	74.8	129	117	0	35	32
2014	7	14	2	8	18	0.883	-0.056	4.222	0.01	0.007	0	41.3	37	74.4	130	118	0	34	32
2014	7	14	2	18	18	0.856	-0.069	4.226	0.01	0.007	0	41.3	36.5	74.4	130	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	2	28	18	0.886	-0.056	4.226	0.013	0.01	0	41.3	36.5	74	129	117	0	33	32
2014	7	14	2	38	18	0.876	-0.046	4.229	0.01	0.007	0	41.3	37	73.5	129	117	0	33	31
2014	7	14	2	48	18	0.873	-0.079	4.229	0.01	0.007	0	40.9	36.5	74.4	129	117	0	34	32
2014	7	14	2	58	18	0.879	-0.059	4.232	0.013	0.01	0	40.9	36.5	74.8	129	117	0	34	32
2014	7	14	3	8	18	0.869	-0.062	4.236	0.01	0.007	0	41.7	37.4	74.8	130	118	0	33	31
2014	7	14	3	18	18	0.876	-0.072	4.236	0.016	0.013	0	41.3	37	74.8	130	118	0	34	32
2014	7	14	3	28	18	0.906	-0.092	4.236	0.01	0.007	0	41.7	37.4	74.4	130	118	0	33	31
2014	7	14	3	38	18	0.85	-0.082	4.236	0.01	0.007	0	40.9	36.5	74.8	129	117	0	34	32
2014	7	14	3	48	18	0.86	-0.039	4.236	0.01	0.007	0	41.3	37	76.1	130	118	0	34	32
2014	7	14	3	58	18	0.886	-0.072	4.236	0.01	0.007	0	40.9	37	75.3	129	118	0	34	32
2014	7	14	4	8	18	0.853	-0.098	4.236	0.01	0.007	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	14	4	18	18	0.876	-0.049	4.236	0.013	0.01	0	41.3	37	75.3	130	118	0	34	32
2014	7	14	4	28	18	0.909	-0.062	4.239	0.013	0.01	0	40.9	37.4	76.5	130	118	0	35	31
2014	7	14	4	38	18	0.902	-0.112	4.239	0.01	0.007	0	41.7	37	76.5	130	118	0	33	32
2014	7	14	4	48	18	0.846	-0.085	4.239	0.013	0.01	0	41.3	37.4	77	130	119	0	34	32
2014	7	14	4	58	18	0.863	-0.075	4.239	0.01	0.007	0	42.1	37.8	76.1	131	119	0	33	31
2014	7	14	5	8	18	0.902	-0.049	4.239	0.01	0.007	0	41.7	37.4	77	131	119	0	34	32
2014	7	14	5	18	18	0.928	-0.092	4.239	0.013	0.01	0	41.7	37.8	77.4	131	119	0	34	31
2014	7	14	5	28	18	0.883	-0.075	4.239	0.01	0.007	0	41.3	37.4	75.7	131	119	0	35	32
2014	7	14	5	38	18	0.866	-0.108	4.239	0.01	0.007	0	41.7	37.8	77.4	131	119	0	34	31
2014	7	14	5	48	18	0.86	-0.082	4.239	0.01	0.007	0	41.7	37.4	75.3	131	119	0	34	32
2014	7	14	5	58	18	0.863	-0.095	4.239	0.01	0.007	0	41.7	37.8	76.1	131	119	0	34	31
2014	7	14	6	8	18	0.889	-0.069	4.242	0.013	0.01	0	41.7	37.4	77.8	131	119	0	34	32
2014	7	14	6	18	18	0.876	-0.066	4.242	0.01	0.007	0	41.3	37.4	77.4	130	119	0	34	32
2014	7	14	6	28	18	0.856	-0.075	4.242	0.013	0.01	0	40.9	36.5	77	129	117	0	34	32
2014	7	14	6	38	18	0.896	-0.082	4.242	0.013	0.01	0	40.9	37	78.3	129	118	0	34	32
2014	7	14	6	48	18	0.896	-0.075	4.242	0.01	0.007	0	41.3	37	77	129	117	0	33	31
2014	7	14	6	58	18	0.856	-0.075	4.242	0.016	0.016	0	40.9	37	78.3	129	117	0	34	31
2014	7	14	7	8	18	0.86	-0.105	4.242	0.01	0.007	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	14	7	18	18	0.876	-0.072	4.242	0.01	0.007	0	40.4	36.5	78.3	128	117	0	34	32
2014	7	14	7	28	18	0.899	-0.085	4.242	0.01	0.007	0	40.4	36.1	78.7	128	116	0	34	32
2014	7	14	7	38	18	0.889	-0.085	4.242	0.01	0.007	0	40.4	36.1	78.3	128	116	0	34	32
2014	7	14	7	48	18	0.889	-0.075	4.242	0.013	0.01	0	40.4	36.1	79.1	128	116	0	34	32
2014	7	14	7	58	18	0.886	-0.098	4.242	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	14	8	8	18	0.879	-0.072	4.245	0.01	0.007	0	40.4	36.1	78.3	128	116	0	34	32
2014	7	14	8	18	18	0.879	-0.052	4.245	0.01	0.007	0	40.4	36.5	77.8	128	116	0	34	31
2014	7	14	8	28	18	0.853	-0.098	4.242	0.013	0.01	0	40.9	36.5	78.3	129	117	0	34	32
2014	7	14	8	38	18	0.873	-0.085	4.245	0.013	0.01	0	40	36.5	79.1	128	116	0	35	31
2014	7	14	8	48	18	0.82	-0.105	4.245	0.01	0.007	0	40.4	36.1	79.1	128	116	0	34	32
2014	7	14	8	58	18	0.873	-0.075	4.245	0.01	0.007	0	40.4	36.5	77.8	128	116	0	34	31
2014	7	14	9	8	18	0.896	-0.121	4.245	0.01	0.007	0	40.9	36.5	78.7	129	117	0	34	32
2014	7	14	9	18	18	0.879	-0.089	4.245	0.01	0.007	0	40	36.1	79.1	128	116	0	35	32
2014	7	14	9	28	18	0.892	-0.095	4.245	0.01	0.007	0	40	36.5	78.7	128	117	0	35	32
2014	7	14	9	38	18	0.879	-0.128	4.245	0.013	0.01	0	40.9	36.5	79.1	129	117	0	34	32
2014	7	14	9	48	18	0.856	-0.085	4.245	0.013	0.01	0	40.9	36.5	79.1	129	117	0	34	32
2014	7	14	9	58	18	0.889	-0.102	4.245	0.01	0.007	0	40.4	37	77.8	128	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	10	8	18	0.873	-0.102	4.245	0.01	0.007	0	40.4	36.5	79.1	128	117	0	34	32
2014	7	14	10	18	18	0.883	-0.089	4.245	0.013	0.01	0	40	36.1	79.6	127	116	0	34	32
2014	7	14	10	28	18	0.856	-0.085	4.245	0.01	0.007	0	40.4	36.1	79.1	128	116	0	34	32
2014	7	14	10	38	18	0.843	-0.082	4.249	0.01	0.007	0	40.4	36.5	79.6	128	116	0	34	31
2014	7	14	10	48	18	0.853	-0.095	4.249	0.01	0.007	0	40.4	36.1	79.6	128	116	0	34	32
2014	7	14	10	58	18	0.883	-0.089	4.249	0.013	0.01	0	40	36.1	77.8	127	116	0	34	32
2014	7	14	11	8	18	0.85	-0.098	4.249	0.01	0.007	0	41.3	36.5	72.7	129	117	0	33	32
2014	7	14	11	18	18	0.843	-0.098	4.249	0.01	0.007	0	40.4	36.5	76.1	128	116	0	34	31
2014	7	14	11	28	18	0.837	-0.089	4.249	0.01	0.007	0	40.4	36.5	78.3	128	117	0	34	32
2014	7	14	11	38	18	0.856	-0.112	4.249	0.013	0.01	0	40	36.1	68.4	127	115	0	34	31
2014	7	14	11	48	18	0.889	-0.046	4.249	0.01	0.007	0	40.4	36.5	66.2	128	116	0	34	31
2014	7	14	11	58	18	0.86	-0.098	4.245	0.01	0.007	0	40.9	37.4	61.1	129	118	0	34	31
2014	7	14	12	8	18	0.833	-0.079	4.249	0.01	0.007	0	41.3	37.4	58.9	130	118	0	34	31
2014	7	14	12	18	18	0.833	-0.118	4.245	0.01	0.007	0	41.7	37.4	52.9	131	119	0	34	32
2014	7	14	12	28	18	0.794	-0.112	4.249	0.01	0.007	0	41.3	37.8	58.9	130	119	0	34	31
2014	7	14	12	38	18	0.823	-0.098	4.249	0.01	0.007	0	41.7	37.8	55.9	131	119	0	34	31
2014	7	14	12	48	18	0.837	-0.072	4.249	0.01	0.007	0	40.9	37.4	59.3	129	118	0	34	31
2014	7	14	12	58	18	0.863	-0.062	4.249	0.01	0.007	0	40.9	37.4	60.6	129	118	0	34	31
2014	7	14	13	8	18	0.856	-0.056	4.249	0.013	0.01	0	40.4	37	57.6	128	117	0	34	31
2014	7	14	13	18	18	0.853	-0.082	4.249	0.01	0.007	0	40.4	37	57.2	128	117	0	34	31
2014	7	14	13	28	18	0.866	-0.079	4.249	0.01	0.007	0	40.9	36.5	60.6	129	117	0	34	32
2014	7	14	13	38	18	0.823	-0.085	4.249	0.01	0.007	0	40.4	36.5	58.9	128	116	0	34	31
2014	7	14	13	48	18	0.833	-0.098	4.249	0.01	0.007	0	40	36.1	59.3	127	116	0	34	32
2014	7	14	13	58	18	0.837	-0.115	4.245	0.01	0.007	0	39.6	36.5	59.8	127	116	0	35	31
2014	7	14	14	8	18	0.863	-0.069	4.249	0.01	0.007	0	40	36.1	57.6	127	116	0	34	32
2014	7	14	14	27	0	0.84	-0.095	4.245	0.01	0.007	0	40.4	36.1	56.8	128	116	0	34	32
2014	7	14	14	37	0	0.817	-0.098	4.245	0.01	0.007	0	40.4	37	62.4	128	117	0	34	31
2014	7	14	14	47	0	0.84	-0.079	4.245	0.013	0.01	0	40.4	37	62.8	128	117	0	34	31
2014	7	14	14	57	0	0.856	-0.098	4.245	0.01	0.007	0	40	36.1	62.4	127	116	0	34	32
2014	7	14	15	7	0	0.86	-0.072	4.245	0.01	0.007	0	40.4	36.1	70.5	128	116	0	34	32
2014	7	14	15	17	0	0.833	-0.056	4.245	0.01	0.007	0	40.4	36.5	64.9	128	116	0	34	31
2014	7	14	15	27	0	0.843	-0.095	4.245	0.01	0.007	0	40.4	36.5	62.4	128	117	0	34	32
2014	7	14	15	37	0	0.807	-0.089	4.245	0.01	0.007	0	40.9	37.4	55.9	129	118	0	34	31
2014	7	14	15	47	0	0.797	-0.075	4.245	0.01	0.007	0	40.9	37	60.6	129	117	0	34	31
2014	7	14	15	57	0	0.843	-0.079	4.245	0.01	0.007	0	40.9	37	58.9	129	117	0	34	31
2014	7	14	16	7	0	0.82	-0.082	4.245	0.01	0.007	0	40.9	37	60.6	129	117	0	34	31
2014	7	14	16	17	0	0.869	-0.115	4.245	0.01	0.007	0	40.4	37	64.9	128	117	0	34	31
2014	7	14	16	27	0	0.843	-0.069	4.245	0.013	0.01	0	40.4	36.5	62.4	128	116	0	34	31
2014	7	14	16	37	0	0.843	-0.089	4.245	0.013	0.01	0	40.9	37	74	128	117	0	33	31
2014	7	14	16	47	0	0.85	-0.072	4.245	0.01	0.007	0	40.4	37	59.8	128	117	0	34	31
2014	7	14	16	57	0	0.843	-0.098	4.245	0.01	0.007	0	40.4	37	59.8	128	117	0	34	31
2014	7	14	17	7	0	0.86	-0.049	4.245	0.01	0.007	0	40.4	36.5	62.8	128	116	0	34	31
2014	7	14	17	17	0	0.823	-0.079	4.245	0.01	0.007	0	40.4	36.1	71.8	128	116	0	34	32
2014	7	14	17	27	0	0.883	-0.095	4.245	0.013	0.01	0	40.4	36.1	71.8	128	116	0	34	32
2014	7	14	17	37	0	0.84	-0.079	4.245	0.01	0.007	0	40.9	36.5	75.7	128	116	0	33	31
2014	7	14	17	47	0	0.873	-0.085	4.245	0.01	0.007	0	40.9	36.5	73.5	128	116	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	14	17	57	0	0.866	-0.072	4.245	0.01	0.007	0	40.4	37	67.5	128	117	0	34	31
2014	7	14	18	7	0	0.886	-0.092	4.245	0.01	0.007	0	40.4	36.5	71.4	128	116	0	34	31
2014	7	14	18	17	0	0.846	-0.052	4.242	0.013	0.01	0	40.4	36.5	61.9	128	116	0	34	31
2014	7	14	18	27	0	0.86	-0.105	4.245	0.016	0.013	0	40.9	37	75.3	129	117	0	34	31
2014	7	14	18	37	0	0.883	-0.089	4.245	0.01	0.007	0	40.9	36.5	73.5	129	116	0	34	31
2014	7	14	18	47	0	0.817	-0.072	4.242	0.01	0.007	0	41.7	36.1	64.1	130	116	0	33	32
2014	7	14	18	57	0	0.85	-0.066	4.242	0.013	0.01	0	41.7	37.4	66.2	131	118	0	34	31
2014	7	14	19	7	0	0.873	-0.062	4.239	0.013	0.01	0	42.1	37.4	61.9	132	119	0	34	32
2014	7	14	19	17	0	0.863	-0.059	4.239	0.01	0.007	0	42.6	37.8	61.5	133	120	0	34	32
2014	7	14	19	27	0	0.892	-0.085	4.239	0.01	0.007	0	43	38.3	57.2	134	121	0	34	32
2014	7	14	19	37	0	0.889	-0.049	4.242	0.013	0.01	0	43	38.3	65.4	133	120	0	33	31
2014	7	14	19	47	0	0.876	-0.079	4.242	0.01	0.007	0	41.7	37.4	67.1	131	118	0	34	31
2014	7	14	19	57	0	0.856	-0.098	4.245	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	14	20	7	0	0.84	-0.095	4.245	0.01	0.007	0	41.3	37.4	69.7	131	118	0	35	31
2014	7	14	20	17	0	0.889	-0.072	4.242	0.01	0.007	0	42.1	37.8	66.2	132	119	0	34	31
2014	7	14	20	27	0	0.853	-0.115	4.242	0.01	0.007	0	42.1	37.8	58	132	119	0	34	31
2014	7	14	20	37	0	0.892	-0.072	4.242	0.01	0.007	0	43	37.4	56.3	133	119	0	33	32
2014	7	14	20	47	0	0.807	-0.082	4.242	0.01	0.007	0	43.4	38.7	56.3	134	121	0	33	31
2014	7	14	20	57	0	0.85	-0.072	4.242	0.013	0.01	0	42.6	38.3	59.3	133	120	0	34	31
2014	7	14	21	7	0	0.883	-0.079	4.242	0.01	0.007	0	43	37.8	56.3	133	119	0	33	31
2014	7	14	21	17	0	0.853	-0.062	4.242	0.01	0.007	0	42.6	37.8	58.5	132	119	0	33	31
2014	7	14	21	27	0	0.883	-0.062	4.245	0.013	0.01	0	42.1	37.4	57.6	131	118	0	33	31
2014	7	14	21	37	0	0.856	-0.092	4.245	0.01	0.007	0	41.7	37	57.2	131	117	0	34	31
2014	7	14	21	47	0	0.866	-0.066	4.242	0.016	0.013	0	41.3	37	57.6	130	117	0	34	31
2014	7	14	21	57	0	0.82	-0.059	4.245	0.01	0.007	0	41.3	37	66.7	130	117	0	34	31
2014	7	14	22	7	0	0.85	-0.089	4.245	0.01	0.007	0	41.3	36.5	71.4	130	117	0	34	32
2014	7	14	22	17	0	0.86	-0.098	4.245	0.01	0.007	0	41.3	36.5	63.6	130	117	0	34	32
2014	7	14	22	27	0	0.856	-0.082	4.245	0.01	0.007	0	41.7	36.5	67.1	130	116	0	33	31
2014	7	14	22	37	0	0.833	-0.095	4.245	0.01	0.007	0	41.7	36.5	58.9	130	116	0	33	31
2014	7	14	22	47	0	0.856	-0.072	4.245	0.01	0.007	0	41.3	36.5	66.2	130	116	0	34	31
2014	7	14	22	57	0	0.86	-0.082	4.245	0.01	0.007	0	41.3	36.5	65.8	130	116	0	34	31
2014	7	14	23	7	0	0.889	-0.046	4.245	0.01	0.007	0	40.9	36.1	62.8	129	116	0	34	32
2014	7	14	23	17	0	0.853	-0.059	4.249	0.01	0.007	0	40.9	36.5	64.5	129	116	0	34	31
2014	7	14	23	27	0	0.853	-0.082	4.249	0.01	0.007	0	40.9	36.5	64.5	129	116	0	34	31
2014	7	14	23	37	0	0.84	-0.062	4.249	0.01	0.007	0	41.3	36.1	61.1	130	116	0	34	32
2014	7	14	23	47	0	0.856	-0.098	4.249	0.01	0.007	0	41.3	36.5	63.6	130	116	0	34	31
2014	7	14	23	57	0	0.84	-0.049	4.249	0.01	0.007	0	41.7	36.1	63.6	130	116	0	33	32
2014	7	15	0	7	0	0.873	-0.092	4.249	0.01	0.007	0	40.9	36.5	65.8	129	116	0	34	31
2014	7	15	0	17	0	0.84	-0.075	4.249	0.01	0.007	0	41.3	36.5	61.1	130	116	0	34	31
2014	7	15	0	27	0	0.886	-0.079	4.249	0.01	0.007	0	40.9	36.5	62.8	129	116	0	34	31
2014	7	15	0	37	0	0.837	-0.049	4.249	0.013	0.01	0	40.9	36.5	61.5	130	116	0	35	31
2014	7	15	0	47	0	0.856	-0.079	4.249	0.01	0.007	0	41.7	36.5	68.8	130	116	0	33	31
2014	7	15	0	57	0	0.846	-0.069	4.249	0.013	0.01	0	41.7	36.1	73.1	130	116	0	33	32
2014	7	15	1	7	0	0.853	-0.092	4.249	0.01	0.007	0	40.9	36.5	70.5	129	116	0	34	31
2014	7	15	1	17	0	0.866	-0.082	4.252	0.01	0.007	0	40.9	36.5	71.4	129	116	0	34	31
2014	7	15	1	27	0	0.846	-0.052	4.252	0.01	0.007	0	41.3	36.1	72.7	130	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	1	37	0	0.889	-0.089	4.252	0.01	0.007	0	41.3	36.1	77	130	116	0	34	32
2014	7	15	1	47	0	0.837	-0.121	4.252	0.01	0.007	0	41.3	36.1	77.4	130	116	0	34	32
2014	7	15	1	57	0	0.873	-0.059	4.252	0.013	0.01	0	40.9	36.5	78.3	129	116	0	34	31
2014	7	15	2	7	0	0.85	-0.112	4.252	0.01	0.007	0	41.3	36.5	78.3	130	116	0	34	31
2014	7	15	2	17	0	0.856	-0.079	4.252	0.01	0.007	0	41.3	37	78.3	130	117	0	34	31
2014	7	15	2	27	0	0.892	-0.072	4.252	0.013	0.01	0	41.3	37	79.1	130	117	0	34	31
2014	7	15	2	37	0	0.85	-0.079	4.252	0.01	0.007	0	41.7	37	78.7	130	117	0	33	31
2014	7	15	2	47	0	0.843	-0.062	4.252	0.01	0.007	0	40.9	37	78.7	130	117	0	35	31
2014	7	15	2	57	0	0.883	-0.066	4.252	0.01	0.007	0	41.3	36.1	78.3	130	116	0	34	32
2014	7	15	3	7	0	0.84	-0.092	4.252	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	15	3	17	0	0.856	-0.069	4.252	0.01	0.007	0	40.9	36.5	77.4	130	117	0	35	32
2014	7	15	3	27	0	0.863	-0.098	4.252	0.01	0.007	0	41.7	36.5	77.8	130	117	0	33	32
2014	7	15	3	37	0	0.856	-0.079	4.252	0.016	0.013	0	41.3	37	78.3	130	117	0	34	31
2014	7	15	3	47	0	0.85	-0.095	4.252	0.01	0.007	0	41.7	36.5	77.8	131	117	0	34	32
2014	7	15	3	57	0	0.912	-0.079	4.252	0.01	0.007	0	41.7	37	78.3	131	117	0	34	31
2014	7	15	4	7	0	0.866	-0.089	4.252	0.01	0.007	0	41.7	37	77.8	131	117	0	34	31
2014	7	15	4	17	0	0.869	-0.075	4.255	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	15	4	27	0	0.843	-0.112	4.252	0.01	0.007	0	42.1	37.4	77.4	132	119	0	34	32
2014	7	15	4	37	0	0.86	-0.079	4.252	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	15	4	47	0	0.866	-0.062	4.252	0.01	0.007	0	41.7	37.4	77.8	131	118	0	34	31
2014	7	15	4	57	0	0.886	-0.072	4.252	0.01	0.007	0	42.1	37.8	77.8	132	119	0	34	31
2014	7	15	5	7	0	0.837	-0.095	4.252	0.013	0.01	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	15	5	17	0	0.869	-0.049	4.255	0.013	0.01	0	42.6	37.8	76.1	133	119	0	34	31
2014	7	15	5	27	0	0.83	-0.059	4.255	0.013	0.01	0	43.4	37.8	75.7	134	120	0	33	32
2014	7	15	5	37	0	0.837	-0.069	4.255	0.01	0.007	0	43	38.3	77.4	133	120	0	33	31
2014	7	15	5	47	0	0.85	-0.062	4.255	0.01	0.007	0	42.6	38.3	77.4	133	120	0	34	31
2014	7	15	5	57	0	0.827	-0.066	4.255	0.01	0.007	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	15	6	7	0	0.863	-0.085	4.255	0.01	0.007	0	42.6	38.3	76.5	133	120	0	34	31
2014	7	15	6	17	0	0.856	-0.062	4.255	0.01	0.007	0	42.6	37.8	77	133	120	0	34	32
2014	7	15	6	27	0	0.84	-0.075	4.255	0.01	0.007	0	42.6	37.8	75.7	133	119	0	34	31
2014	7	15	6	37	0	0.876	-0.082	4.255	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2014	7	15	6	47	0	0.912	-0.085	4.255	0.01	0.007	0	42.1	37	75.7	132	118	0	34	32
2014	7	15	6	57	0	0.853	-0.108	4.255	0.01	0.007	0	42.1	37.8	72.2	132	119	0	34	31
2014	7	15	7	7	0	0.856	-0.112	4.255	0.013	0.01	0	42.1	37.4	66.2	132	118	0	34	31
2014	7	15	7	17	0	0.856	-0.079	4.255	0.016	0.013	0	43	38.3	61.1	133	120	0	33	31
2014	7	15	7	27	0	0.84	-0.108	4.255	0.01	0.007	0	42.6	38.3	60.6	134	121	0	35	32
2014	7	15	7	37	0	0.82	-0.049	4.259	0.01	0.007	0	42.6	38.3	57.2	133	120	0	34	31
2014	7	15	7	47	0	0.879	-0.075	4.259	0.01	0.007	0	43.9	38.7	66.2	136	122	0	34	32
2014	7	15	7	57	0	0.879	-0.075	4.259	0.01	0.007	0	45.6	40.9	59.8	140	127	0	34	32
2014	7	15	8	7	0	0.863	-0.043	4.259	0.013	0.01	0	46	41.3	63.2	141	128	0	34	32
2014	7	15	8	17	0	0.853	-0.059	4.259	0.01	0.007	0	46.4	41.3	64.5	142	128	0	34	32
2014	7	15	8	27	0	0.876	-0.046	4.259	0.01	0.007	0	46.4	41.3	59.8	142	128	0	34	32
2014	7	15	8	37	0	0.879	-0.043	4.259	0.01	0.007	0	46	41.7	66.2	141	128	0	34	31
2014	7	15	8	47	0	0.902	-0.033	4.259	0.01	0.007	0	45.2	40.9	68.8	139	126	0	34	31
2014	7	15	8	57	0	0.856	-0.049	4.262	0.01	0.007	0	44.3	39.6	71.4	137	124	0	34	32
2014	7	15	9	7	0	0.886	-0.062	4.262	0.01	0.007	0	43.4	38.7	72.2	135	122	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	9	17	0	0.869	-0.079	4.262	0.013	0.01	0	43	38.3	73.1	133	120	0	33	31
2014	7	15	9	27	0	0.869	-0.069	4.262	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	15	9	37	0	0.86	-0.079	4.262	0.01	0.007	0	41.3	37	74	130	117	0	34	31
2014	7	15	9	47	0	0.886	-0.046	4.265	0.016	0.013	0	41.3	36.5	74.4	130	117	0	34	32
2014	7	15	9	57	0	0.879	-0.069	4.265	0.01	0.007	0	41.3	37	74	130	117	0	34	31
2014	7	15	10	7	0	0.873	-0.098	4.265	0.01	0.007	0	40.9	36.5	74	129	116	0	34	31
2014	7	15	10	17	0	0.869	-0.072	4.268	0.013	0.01	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	15	10	27	0	0.876	-0.079	4.265	0.01	0.007	0	41.7	36.5	73.1	130	117	0	33	32
2014	7	15	10	37	0	0.837	-0.069	4.268	0.01	0.007	0	40.9	36.5	73.5	129	116	0	34	31
2014	7	15	10	47	0	0.889	-0.079	4.268	0.01	0.007	0	40.9	36.5	74	129	116	0	34	31
2014	7	15	10	57	0	0.86	-0.089	4.272	0.01	0.007	0	40.9	36.5	75.3	129	116	0	34	31
2014	7	15	11	7	0	0.846	-0.075	4.272	0.013	0.01	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	15	11	17	0	0.85	-0.062	4.268	0.01	0.007	0	41.3	36.1	75.3	129	116	0	33	32
2014	7	15	11	27	0	0.863	-0.092	4.268	0.01	0.007	0	40.9	36.5	74.8	129	116	0	34	31
2014	7	15	11	37	0	0.873	-0.069	4.268	0.01	0.007	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	15	11	47	0	0.84	-0.085	4.268	0.013	0.01	0	40	36.1	73.5	128	115	0	35	31
2014	7	15	11	57	0	0.856	-0.082	4.268	0.01	0.007	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	15	12	7	0	0.853	-0.098	4.268	0.01	0.007	0	40.9	37	74.8	130	117	0	35	31
2014	7	15	12	17	0	0.81	-0.128	4.268	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	15	12	27	0	0.856	-0.085	4.268	0.013	0.01	0	41.3	37	74.4	130	117	0	34	31
2014	7	15	12	37	0	0.86	-0.072	4.268	0.01	0.007	0	40.9	36.5	73.5	129	116	0	34	31
2014	7	15	12	47	0	0.873	-0.075	4.268	0.013	0.01	0	40.4	36.1	74.8	128	115	0	34	31
2014	7	15	12	57	0	0.86	-0.102	4.268	0.01	0.007	0	40.4	35.7	74	128	115	0	34	32
2014	7	15	13	7	0	0.876	-0.075	4.268	0.01	0.007	0	40.9	37	60.6	129	117	0	34	31
2014	7	15	13	17	0	0.843	-0.089	4.268	0.01	0.007	0	40.9	36.5	67.9	129	116	0	34	31
2014	7	15	13	27	0	0.85	-0.082	4.265	0.01	0.007	0	40.9	37	64.5	129	117	0	34	31
2014	7	15	13	37	0	0.873	-0.098	4.268	0.013	0.01	0	40.9	36.5	71.8	129	116	0	34	31
2014	7	15	13	47	0	0.879	-0.112	4.268	0.01	0.007	0	40.9	36.1	62.8	129	116	0	34	32
2014	7	15	13	57	0	0.866	-0.062	4.268	0.013	0.01	0	40.9	36.5	56.8	128	116	0	33	31
2014	7	15	14	7	0	0.86	-0.036	4.268	0.016	0.013	0	40.9	37	55.9	129	117	0	34	31
2014	7	15	14	17	0	0.86	-0.118	4.268	0.01	0.007	0	41.3	37	58.5	130	118	0	34	32
2014	7	15	14	27	0	0.853	-0.082	4.265	0.013	0.01	0	40.9	36.5	61.9	129	116	0	34	31
2014	7	15	14	37	0	0.81	-0.072	4.268	0.01	0.007	0	40.9	36.5	56.8	129	117	0	34	32
2014	7	15	14	47	0	0.869	-0.102	4.265	0.01	0.007	0	40.9	37	61.5	129	117	0	34	31
2014	7	15	14	57	0	0.863	-0.102	4.265	0.01	0.007	0	41.7	37	56.8	130	117	0	33	31
2014	7	15	15	7	0	0.866	-0.069	4.265	0.01	0.007	0	41.3	37	60.2	129	117	0	33	31
2014	7	15	15	17	0	0.83	-0.089	4.265	0.01	0.007	0	40.4	37	57.6	129	117	0	35	31
2014	7	15	15	27	0	0.827	-0.075	4.265	0.01	0.007	0	40.9	37	59.8	129	117	0	34	31
2014	7	15	15	37	0	0.85	-0.098	4.265	0.01	0.007	0	41.3	37	61.5	130	117	0	34	31
2014	7	15	15	47	0	0.846	-0.082	4.265	0.01	0.007	0	40.9	36.5	57.6	129	116	0	34	31
2014	7	15	15	57	0	0.84	-0.072	4.265	0.01	0.007	0	40.9	37	58	129	117	0	34	31
2014	7	15	16	7	0	0.83	-0.056	4.265	0.01	0.007	0	40.9	37	59.3	129	117	0	34	31
2014	7	15	16	17	0	0.823	-0.066	4.265	0.01	0.007	0	40.9	36.5	56.8	129	116	0	34	31
2014	7	15	16	27	0	0.85	-0.079	4.265	0.01	0.007	0	40.9	36.5	57.2	129	116	0	34	31
2014	7	15	16	37	0	0.85	-0.072	4.265	0.01	0.007	0	41.7	37	58	130	117	0	33	31
2014	7	15	16	47	0	0.85	-0.085	4.262	0.01	0.007	0	41.3	37	59.3	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	15	16	57	0	0.856	-0.082	4.262	0.016	0.013	0	41.3	37.4	63.2	130	118	0	34	31
2014	7	15	17	7	0	0.84	-0.105	4.262	0.013	0.01	0	41.3	36.5	60.6	129	116	0	33	31
2014	7	15	17	17	0	0.827	-0.066	4.262	0.01	0.007	0	40.4	36.1	59.8	128	115	0	34	31
2014	7	15	17	27	0	0.86	-0.069	4.262	0.01	0.007	0	40.9	36.5	61.5	129	116	0	34	31
2014	7	15	17	37	0	0.85	-0.089	4.262	0.01	0.007	0	40.4	36.1	61.1	128	115	0	34	31
2014	7	15	17	47	0	0.801	-0.118	4.262	0.013	0.01	0	40.4	36.1	66.7	128	115	0	34	31
2014	7	15	17	57	0	0.837	-0.066	4.262	0.01	0.007	0	40.4	35.7	62.4	128	114	0	34	31
2014	7	15	18	7	0	0.866	-0.059	4.262	0.01	0.007	0	40	35.7	62.8	127	114	0	34	31
2014	7	15	18	17	0	0.846	-0.092	4.262	0.01	0.007	0	40.9	35.7	70.1	128	115	0	33	32
2014	7	15	18	27	0	0.879	-0.112	4.262	0.013	0.01	0	40.9	37	69.7	130	117	0	35	31
2014	7	15	18	37	0	0.85	-0.079	4.262	0.01	0.007	0	40.4	36.1	72.2	128	115	0	34	31
2014	7	15	18	47	0	0.843	-0.102	4.262	0.01	0.007	0	40.9	36.1	77	128	115	0	33	31
2014	7	15	18	57	0	0.863	-0.082	4.262	0.013	0.01	0	40.4	36.5	65.8	128	115	0	34	30
2014	7	15	19	7	0	0.823	-0.089	4.262	0.01	0.007	0	40.4	36.1	76.5	128	115	0	34	31
2014	7	15	19	17	0	0.866	-0.056	4.262	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	15	19	27	0	0.856	-0.072	4.262	0.013	0.01	0	41.3	37	76.1	130	117	0	34	31
2014	7	15	19	37	0	0.873	-0.089	4.262	0.013	0.01	0	40.9	36.5	77.4	129	116	0	34	31
2014	7	15	19	47	0	0.843	-0.098	4.262	0.013	0.01	0	40.9	36.1	77	129	116	0	34	32
2014	7	15	19	57	0	0.869	-0.092	4.262	0.01	0.007	0	41.3	37	77	130	117	0	34	31
2014	7	15	20	7	0	0.883	-0.082	4.262	0.01	0.007	0	41.3	36.5	77.8	129	116	0	33	31
2014	7	15	20	17	0	0.892	-0.098	4.262	0.01	0.007	0	41.7	36.5	77.4	130	116	0	33	31
2014	7	15	20	27	0	0.846	-0.049	4.262	0.01	0.007	0	41.3	36.1	72.2	129	116	0	33	32
2014	7	15	20	37	0	0.843	-0.082	4.262	0.01	0.007	0	41.3	36.5	70.5	130	116	0	34	31
2014	7	15	20	47	0	0.856	-0.082	4.262	0.013	0.01	0	41.7	37	61.5	131	117	0	34	31
2014	7	15	20	57	0	0.866	-0.069	4.262	0.01	0.007	0	47.3	42.1	53.3	144	130	0	34	32
2014	7	15	21	7	0	0.863	-0.062	4.262	0.01	0.007	0	48.6	43.4	65.8	146	132	0	33	31
2014	7	15	21	17	0	0.863	-0.046	4.262	0.01	0.007	0	46.9	42.1	56.3	142	129	0	33	31
2014	7	15	21	27	0	0.856	-0.082	4.262	0.01	0.007	0	45.6	41.3	58.9	140	127	0	34	31
2014	7	15	21	37	0	0.869	-0.016	4.262	0.01	0.007	0	45.2	40.4	57.2	139	125	0	34	31
2014	7	15	21	47	0	0.873	-0.072	4.262	0.01	0.007	0	44.7	40	54.6	137	124	0	33	31
2014	7	15	21	57	0	0.896	-0.062	4.262	0.013	0.01	0	43.9	39.6	63.6	136	123	0	34	31
2014	7	15	22	7	0	0.843	-0.066	4.262	0.01	0.007	0	43	38.7	58.9	134	121	0	34	31
2014	7	15	22	17	0	0.86	-0.069	4.262	0.01	0.007	0	42.6	38.3	70.1	133	120	0	34	31
2014	7	15	22	27	0	0.892	-0.046	4.262	0.013	0.01	0	41.7	37.4	61.5	131	118	0	34	31
2014	7	15	22	37	0	0.846	-0.062	4.262	0.016	0.013	0	42.1	37.4	58	132	118	0	34	31
2014	7	15	22	47	0	0.876	-0.075	4.262	0.01	0.007	0	41.7	37.4	71.4	131	118	0	34	31
2014	7	15	22	57	0	0.876	-0.092	4.262	0.013	0.01	0	41.3	36.5	74	130	116	0	34	31
2014	7	15	23	7	0	0.892	-0.059	4.262	0.01	0.007	0	40.4	36.1	76.1	129	116	0	35	32
2014	7	15	23	17	0	0.873	-0.062	4.262	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	15	23	27	0	0.876	-0.089	4.262	0.01	0.007	0	40.9	36.1	75.7	129	115	0	34	31
2014	7	15	23	37	0	0.883	-0.079	4.262	0.01	0.007	0	40.4	35.3	76.1	128	114	0	34	32
2014	7	15	23	47	0	0.863	-0.072	4.262	0.01	0.007	0	40.9	36.1	76.1	128	115	0	33	31
2014	7	15	23	57	0	0.876	-0.075	4.262	0.01	0.007	0	40.4	35.7	76.5	128	115	0	34	32
2014	7	16	0	7	0	0.879	-0.098	4.262	0.013	0.01	0	40.9	36.1	75.7	129	115	0	34	31
2014	7	16	0	17	0	0.896	-0.066	4.262	0.01	0.007	0	40.4	36.1	76.1	128	115	0	34	31
2014	7	16	0	27	0	0.886	-0.085	4.262	0.013	0.01	0	40.4	36.1	75.3	128	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	0	37	0	0.869	-0.069	4.262	0.01	0.007	0	40.9	35.7	75.7	129	115	0	34	32
2014	7	16	0	47	0	0.843	-0.066	4.262	0.01	0.007	0	40.9	36.5	75.7	129	116	0	34	31
2014	7	16	0	57	0	0.899	-0.046	4.262	0.01	0.007	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	16	1	7	0	0.889	-0.082	4.262	0.01	0.007	0	40.9	36.1	76.1	129	115	0	34	31
2014	7	16	1	17	0	0.866	-0.072	4.265	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	16	1	27	0	0.876	-0.059	4.265	0.01	0.007	0	40.9	36.1	75.7	129	115	0	34	31
2014	7	16	1	37	0	0.863	-0.092	4.265	0.01	0.007	0	40.4	36.1	75.3	128	115	0	34	31
2014	7	16	1	47	0	0.892	-0.069	4.262	0.01	0.007	0	41.3	35.7	74.8	129	115	0	33	32
2014	7	16	1	57	0	0.912	-0.095	4.265	0.013	0.01	0	40.4	36.1	75.7	128	115	0	34	31
2014	7	16	2	7	0	0.85	-0.049	4.265	0.01	0.007	0	41.3	36.1	75.7	129	116	0	33	32
2014	7	16	2	17	0	0.906	-0.079	4.265	0.01	0.007	0	41.3	36.5	75.3	129	116	0	33	31
2014	7	16	2	27	0	0.856	-0.118	4.265	0.01	0.007	0	40.9	35.7	74.4	128	115	0	33	32
2014	7	16	2	37	0	0.896	-0.059	4.265	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	16	2	47	0	0.837	-0.102	4.265	0.01	0.007	0	41.3	36.5	74.8	129	116	0	33	31
2014	7	16	2	57	0	0.892	-0.082	4.265	0.013	0.01	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	16	3	7	0	0.869	-0.098	4.265	0.01	0.007	0	40.9	36.1	74.4	129	116	0	34	32
2014	7	16	3	17	0	0.876	-0.105	4.268	0.01	0.007	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	16	3	27	0	0.869	-0.052	4.272	0.013	0.01	0	40.9	36.5	74.4	129	116	0	34	31
2014	7	16	3	37	0	0.896	-0.095	4.272	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	16	3	47	0	0.899	-0.072	4.275	0.01	0.007	0	41.3	37	74	130	117	0	34	31
2014	7	16	3	57	0	0.912	-0.069	4.278	0.01	0.007	0	40.9	36.5	75.7	129	116	0	34	31
2014	7	16	4	7	0	0.866	-0.072	4.278	0.013	0.01	0	41.7	36.1	75.7	130	116	0	33	32
2014	7	16	4	17	0	0.912	-0.049	4.278	0.01	0.007	0	41.3	36.5	75.3	129	116	0	33	31
2014	7	16	4	27	0	0.853	-0.089	4.278	0.01	0.007	0	40.9	35.7	75.3	129	115	0	34	32
2014	7	16	4	37	0	0.869	-0.079	4.278	0.01	0.007	0	41.3	37	76.1	130	117	0	34	31
2014	7	16	4	47	0	0.869	-0.079	4.278	0.01	0.007	0	41.3	36.5	75.7	130	116	0	34	31
2014	7	16	4	57	0	0.889	-0.082	4.278	0.013	0.01	0	41.3	36.5	75.7	130	116	0	34	31
2014	7	16	5	7	0	0.892	-0.079	4.281	0.01	0.007	0	40.9	37	75.7	130	117	0	35	31
2014	7	16	5	17	0	0.863	-0.079	4.278	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	16	5	27	0	0.902	-0.052	4.278	0.013	0.01	0	41.3	37	77	130	118	0	34	32
2014	7	16	5	37	0	0.883	-0.049	4.281	0.013	0.01	0	41.3	36.5	77	130	117	0	34	32
2014	7	16	5	47	0	0.873	-0.079	4.281	0.01	0.007	0	41.7	36.5	75.7	130	117	0	33	32
2014	7	16	5	57	0	0.889	-0.075	4.281	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	16	6	7	0	0.889	-0.092	4.281	0.01	0.007	0	41.3	36.5	77	130	117	0	34	32
2014	7	16	6	17	0	0.879	-0.075	4.281	0.01	0.007	0	41.3	36.5	77	129	116	0	33	31
2014	7	16	6	27	0	0.83	-0.049	4.281	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	16	6	37	0	0.883	-0.066	4.281	0.01	0.007	0	41.3	36.1	77	130	116	0	34	32
2014	7	16	6	47	0	0.869	-0.079	4.281	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	16	6	57	0	0.846	-0.043	4.281	0.01	0.007	0	41.3	36.5	77.4	129	116	0	33	31
2014	7	16	7	7	0	0.873	-0.075	4.281	0.013	0.01	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	16	7	17	0	0.863	-0.075	4.281	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	16	7	27	0	0.886	-0.085	4.281	0.013	0.01	0	40.9	36.5	78.3	129	117	0	34	32
2014	7	16	7	37	0	0.86	-0.066	4.285	0.01	0.007	0	41.3	36.5	78.3	129	116	0	33	31
2014	7	16	7	47	0	0.837	-0.079	4.285	0.01	0.007	0	41.7	36.5	78.3	130	116	0	33	31
2014	7	16	7	57	0	0.853	-0.062	4.285	0.01	0.007	0	40.4	36.5	77.4	129	116	0	35	31
2014	7	16	8	7	0	0.909	-0.072	4.285	0.013	0.01	0	40.9	36.5	79.1	129	116	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	8	17	0	0.866	-0.075	4.285	0.01	0.007	0	40.9	36.5	78.7	129	116	0	34	31
2014	7	16	8	27	0	0.912	-0.062	4.285	0.013	0.01	0	41.3	36.5	78.3	130	117	0	34	32
2014	7	16	8	37	0	0.889	-0.059	4.285	0.01	0.007	0	41.3	36.5	77.8	130	117	0	34	32
2014	7	16	8	47	0	0.902	-0.072	4.285	0.013	0.01	0	40.9	36.1	77.8	129	116	0	34	32
2014	7	16	8	57	0	0.899	-0.082	4.285	0.01	0.007	0	40.9	36.5	79.6	129	116	0	34	31
2014	7	16	9	7	0	0.886	-0.079	4.285	0.01	0.007	0	40.9	36.5	79.6	129	116	0	34	31
2014	7	16	9	17	0	0.869	-0.072	4.285	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	16	9	27	0	0.856	-0.069	4.285	0.01	0.007	0	40.9	36.5	79.1	129	116	0	34	31
2014	7	16	9	37	0	0.922	-0.069	4.285	0.01	0.007	0	40.9	37	79.1	129	117	0	34	31
2014	7	16	9	47	0	0.886	-0.072	4.285	0.01	0.007	0	40.4	36.5	78.3	128	116	0	34	31
2014	7	16	9	57	0	0.873	-0.092	4.285	0.01	0.007	0	40.9	36.5	79.1	129	116	0	34	31
2014	7	16	10	7	0	0.886	-0.059	4.285	0.01	0.007	0	41.3	36.5	78.7	129	117	0	33	32
2014	7	16	10	17	0	0.896	-0.079	4.285	0.013	0.01	0	40.4	36.5	77	128	116	0	34	31
2014	7	16	10	27	0	0.879	-0.062	4.285	0.01	0.007	0	40.4	36.1	77	128	115	0	34	31
2014	7	16	10	37	0	0.879	-0.069	4.285	0.01	0.007	0	40.4	36.1	77.8	128	115	0	34	31
2014	7	16	10	47	0	0.866	-0.082	4.285	0.01	0.007	0	40.4	36.1	77.8	128	115	0	34	31
2014	7	16	10	57	0	0.86	-0.082	4.285	0.01	0.007	0	40.4	35.7	77.4	128	115	0	34	32
2014	7	16	11	7	0	0.876	-0.062	4.285	0.01	0.007	0	40	36.1	77	127	115	0	34	31
2014	7	16	11	17	0	0.876	-0.056	4.285	0.01	0.007	0	40.9	36.1	77.4	129	116	0	34	32
2014	7	16	11	27	0	0.879	-0.062	4.285	0.013	0.01	0	40.4	36.1	77.8	128	115	0	34	31
2014	7	16	11	37	0	0.873	-0.072	4.285	0.01	0.007	0	40	36.1	77	127	115	0	34	31
2014	7	16	11	47	0	0.853	-0.092	4.285	0.01	0.007	0	40.9	35.7	76.5	128	115	0	33	32
2014	7	16	11	57	0	0.843	-0.089	4.285	0.01	0.007	0	40.4	35.7	76.5	128	115	0	34	32
2014	7	16	12	7	0	0.889	-0.066	4.285	0.01	0.007	0	40	35.7	77	127	115	0	34	32
2014	7	16	12	17	0	0.853	-0.075	4.285	0.01	0.007	0	39.6	35.7	76.5	126	114	0	34	31
2014	7	16	12	27	0	0.843	-0.079	4.285	0.01	0.007	0	40	35.7	75.3	127	114	0	34	31
2014	7	16	12	37	0	0.843	-0.098	4.285	0.01	0.007	0	40	35.7	67.1	127	114	0	34	31
2014	7	16	12	47	0	0.873	-0.079	4.285	0.01	0.007	0	40.4	35.7	72.2	127	114	0	33	31
2014	7	16	12	57	0	0.823	-0.082	4.281	0.01	0.007	0	39.6	34.8	64.1	126	113	0	34	32
2014	7	16	13	7	0	0.82	-0.115	4.281	0.016	0.013	0	40.4	35.7	61.9	127	114	0	33	31
2014	7	16	13	17	0	0.863	-0.108	4.278	0.01	0.007	0	40	35.7	56.8	127	114	0	34	31
2014	7	16	13	27	0	0.866	-0.079	4.278	0.01	0.007	0	40.4	35.7	65.8	128	115	0	34	32
2014	7	16	13	37	0	0.863	-0.092	4.275	0.01	0.007	0	40	36.1	57.6	127	115	0	34	31
2014	7	16	13	47	0	0.869	-0.085	4.275	0.013	0.01	0	40	35.7	64.9	127	114	0	34	31
2014	7	16	13	57	0	0.869	-0.098	4.275	0.01	0.007	0	40	36.1	55.9	127	115	0	34	31
2014	7	16	14	7	0	0.843	-0.108	4.275	0.01	0.007	0	40.4	36.1	64.1	128	115	0	34	31
2014	7	16	14	17	0	0.869	-0.079	4.275	0.01	0.007	0	43.9	39.1	52.9	136	123	0	34	32
2014	7	16	14	27	0	0.85	-0.062	4.272	0.013	0.01	0	41.7	37.8	61.1	131	119	0	34	31
2014	7	16	14	37	0	0.833	-0.102	4.272	0.01	0.007	0	40.4	36.1	64.1	128	115	0	34	31
2014	7	16	14	47	0	0.85	-0.052	4.272	0.01	0.007	0	40	35.7	74	127	114	0	34	31
2014	7	16	14	57	0	0.879	-0.089	4.268	0.01	0.007	0	40	35.7	62.4	127	114	0	34	31
2014	7	16	15	7	0	0.823	-0.089	4.268	0.013	0.01	0	39.6	35.7	58.5	126	114	0	34	31
2014	7	16	15	17	0	0.846	-0.105	4.268	0.01	0.007	0	39.6	35.3	65.8	126	113	0	34	31
2014	7	16	15	27	0	0.837	-0.069	4.268	0.01	0.007	0	40	35.3	67.5	126	113	0	33	31
2014	7	16	15	37	0	0.86	-0.082	4.268	0.01	0.007	0	39.6	35.7	64.1	126	114	0	34	31
2014	7	16	15	47	0	0.837	-0.102	4.268	0.016	0.013	0	40	35.7	67.1	126	114	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	15	57	0	0.823	-0.072	4.268	0.01	0.007	0	40	35.7	70.5	127	114	0	34	31
2014	7	16	16	7	0	0.846	-0.072	4.268	0.01	0.007	0	39.1	35.3	69.7	125	113	0	34	31
2014	7	16	16	17	0	0.869	-0.125	4.265	0.01	0.007	0	39.1	34.8	72.7	125	113	0	34	32
2014	7	16	16	27	0	0.886	-0.082	4.265	0.01	0.007	0	39.6	34.8	67.9	126	112	0	34	31
2014	7	16	16	37	0	0.883	-0.085	4.265	0.01	0.007	0	39.6	35.7	64.9	126	114	0	34	31
2014	7	16	16	47	0	0.869	-0.075	4.265	0.01	0.007	0	39.6	35.3	69.7	126	113	0	34	31
2014	7	16	16	57	0	0.807	-0.095	4.268	0.013	0.01	0	39.6	35.3	77	126	113	0	34	31
2014	7	16	17	7	0	0.866	-0.066	4.268	0.01	0.007	0	40	35.7	77.4	127	114	0	34	31
2014	7	16	17	17	0	0.853	-0.098	4.265	0.01	0.007	0	40.4	35.7	77.4	127	114	0	33	31
2014	7	16	17	27	0	0.846	-0.049	4.265	0.01	0.007	0	40	35.7	77	127	114	0	34	31
2014	7	16	17	37	0	0.873	-0.082	4.265	0.01	0.007	0	40	35.7	77	127	114	0	34	31
2014	7	16	17	47	0	0.889	-0.089	4.265	0.013	0.01	0	40	35.7	77.4	127	114	0	34	31
2014	7	16	17	57	0	0.85	-0.098	4.268	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	16	18	7	0	0.899	-0.082	4.268	0.013	0.01	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	16	18	17	0	0.863	-0.079	4.268	0.01	0.007	0	40.4	35.7	77.4	128	115	0	34	32
2014	7	16	18	27	0	0.886	-0.052	4.268	0.01	0.007	0	40.4	36.1	77.8	128	116	0	34	32
2014	7	16	18	37	0	0.876	-0.043	4.265	0.013	0.01	0	40.4	35.7	77	128	115	0	34	32
2014	7	16	18	47	0	0.886	-0.066	4.265	0.01	0.007	0	40.9	36.1	75.3	129	116	0	34	32
2014	7	16	18	57	0	0.869	-0.026	4.265	0.01	0.007	0	40.9	36.5	71	129	116	0	34	31
2014	7	16	19	7	0	0.879	-0.066	4.265	0.01	0.007	0	42.1	37.4	60.6	131	118	0	33	31
2014	7	16	19	17	0	0.846	-0.049	4.265	0.01	0.007	0	41.7	37	68.4	130	117	0	33	31
2014	7	16	19	27	0	0.899	-0.033	4.268	0.01	0.007	0	41.3	36.5	69.7	129	116	0	33	31
2014	7	16	19	37	0	0.889	-0.066	4.268	0.01	0.007	0	40.9	36.1	74	129	116	0	34	32
2014	7	16	19	47	0	0.879	-0.095	4.268	0.013	0.01	0	41.7	36.5	74	130	116	0	33	31
2014	7	16	19	57	0	0.886	-0.069	4.268	0.01	0.007	0	40.9	36.5	74	129	116	0	34	31
2014	7	16	20	7	0	0.873	-0.072	4.268	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	16	20	17	0	0.863	-0.062	4.268	0.013	0.01	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	16	20	27	0	0.863	-0.082	4.268	0.01	0.007	0	41.3	35.7	77	129	115	0	33	32
2014	7	16	20	37	0	0.886	-0.092	4.268	0.01	0.007	0	40.9	36.1	73.1	128	115	0	33	31
2014	7	16	20	47	0	0.863	-0.072	4.268	0.01	0.007	0	40.9	36.1	71.4	129	115	0	34	31
2014	7	16	20	57	0	0.883	-0.036	4.268	0.01	0.007	0	40.9	35.7	73.5	128	115	0	33	32
2014	7	16	21	7	0	0.922	-0.089	4.268	0.013	0.01	0	40.9	35.3	74	128	114	0	33	32
2014	7	16	21	17	0	0.846	-0.075	4.268	0.013	0.01	0	40	35.3	77	127	113	0	34	31
2014	7	16	21	27	0	0.846	-0.089	4.268	0.01	0.007	0	40	34.8	76.1	126	112	0	33	31
2014	7	16	21	37	0	0.879	-0.066	4.268	0.01	0.007	0	40	34.8	76.1	126	113	0	33	32
2014	7	16	21	47	0	0.919	-0.079	4.268	0.01	0.007	0	39.6	34.8	76.5	126	112	0	34	31
2014	7	16	21	57	0	0.889	-0.095	4.268	0.01	0.007	0	39.6	34.8	77	126	112	0	34	31
2014	7	16	22	7	0	0.86	-0.069	4.268	0.01	0.007	0	39.6	34.8	76.1	126	113	0	34	32
2014	7	16	22	17	0	0.879	-0.039	4.268	0.01	0.007	0	40	34.4	76.5	126	112	0	33	32
2014	7	16	22	27	0	0.869	-0.085	4.268	0.01	0.007	0	40	35.3	76.1	127	113	0	34	31
2014	7	16	22	37	0	0.912	-0.066	4.272	0.01	0.007	0	39.6	34.8	76.1	126	112	0	34	31
2014	7	16	22	47	0	0.883	-0.082	4.268	0.01	0.007	0	40	34.8	75.7	126	112	0	33	31
2014	7	16	22	57	0	0.889	-0.089	4.272	0.01	0.007	0	39.6	34.4	75.7	126	112	0	34	32
2014	7	16	23	7	0	0.922	-0.056	4.272	0.01	0.007	0	40	34.8	75.3	126	112	0	33	31
2014	7	16	23	17	0	0.896	-0.069	4.272	0.013	0.01	0	39.6	34.8	75.7	126	112	0	34	31
2014	7	16	23	27	0	0.883	-0.046	4.272	0.01	0.007	0	40	34.8	74.4	126	112	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	16	23	37	0	0.906	-0.095	4.275	0.01	0.007	0	39.6	34.8	76.1	126	113	0	34	32
2014	7	16	23	47	0	0.909	-0.052	4.272	0.01	0.007	0	40	34.8	74	126	112	0	33	31
2014	7	16	23	57	0	0.85	-0.072	4.275	0.01	0.007	0	39.6	34.8	75.3	126	113	0	34	32
2014	7	17	0	7	0	0.892	-0.069	4.275	0.01	0.007	0	39.1	34.8	74.4	126	113	0	35	32
2014	7	17	0	17	0	0.883	-0.072	4.278	0.01	0.007	0	39.6	35.3	75.7	126	113	0	34	31
2014	7	17	0	27	0	0.873	-0.039	4.281	0.01	0.007	0	40	35.3	74	127	113	0	34	31
2014	7	17	0	37	0	0.81	-0.039	4.278	0.01	0.007	0	40	35.7	75.3	127	114	0	34	31
2014	7	17	0	47	0	0.889	-0.082	4.281	0.01	0.007	0	40	35.3	75.7	127	113	0	34	31
2014	7	17	0	57	0	0.876	-0.089	4.281	0.01	0.007	0	40	35.7	76.1	127	114	0	34	31
2014	7	17	1	7	0	0.883	-0.095	4.281	0.013	0.01	0	40.4	36.1	75.3	128	115	0	34	31
2014	7	17	1	17	0	0.915	-0.072	4.285	0.01	0.007	0	40	35.7	76.5	127	114	0	34	31
2014	7	17	1	27	0	0.873	-0.079	4.285	0.013	0.01	0	40.4	35.3	76.5	127	113	0	33	31
2014	7	17	1	37	0	0.863	-0.085	4.285	0.01	0.007	0	40	35.3	77.4	127	113	0	34	31
2014	7	17	1	47	0	0.883	-0.082	4.285	0.013	0.01	0	40	35.7	74.4	127	114	0	34	31
2014	7	17	1	57	0	0.876	-0.072	4.285	0.016	0.013	0	40.4	35.7	77.8	128	114	0	34	31
2014	7	17	2	7	0	0.853	-0.052	4.285	0.01	0.007	0	40.9	35.7	77.8	128	114	0	33	31
2014	7	17	2	17	0	0.889	-0.049	4.285	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	17	2	27	0	0.866	-0.066	4.288	0.01	0.007	0	40.9	36.1	78.3	129	115	0	34	31
2014	7	17	2	37	0	0.86	-0.075	4.288	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	17	2	47	0	0.863	-0.108	4.285	0.01	0.007	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	17	2	57	0	0.873	-0.079	4.285	0.01	0.007	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	17	3	7	0	0.912	-0.069	4.288	0.01	0.007	0	40.4	36.1	78.7	129	115	0	35	31
2014	7	17	3	17	0	0.883	-0.082	4.288	0.01	0.007	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	17	3	27	0	0.873	-0.075	4.288	0.01	0.007	0	40.9	36.1	78.7	129	115	0	34	31
2014	7	17	3	37	0	0.889	-0.046	4.288	0.01	0.007	0	40.9	36.1	77.8	129	116	0	34	32
2014	7	17	3	47	0	0.866	-0.046	4.288	0.01	0.007	0	41.3	36.5	79.1	130	116	0	34	31
2014	7	17	3	57	0	0.843	-0.082	4.288	0.013	0.01	0	41.3	36.1	79.6	130	116	0	34	32
2014	7	17	4	7	0	0.833	-0.039	4.288	0.013	0.01	0	41.3	36.1	78.7	130	116	0	34	32
2014	7	17	4	17	0	0.915	-0.072	4.288	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	17	4	27	0	0.86	-0.062	4.288	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	17	4	37	0	0.889	-0.052	4.288	0.01	0.007	0	41.3	36.5	80	129	116	0	33	31
2014	7	17	4	47	0	0.892	-0.072	4.288	0.01	0.007	0	41.7	37	79.6	131	117	0	34	31
2014	7	17	4	57	0	0.896	-0.075	4.288	0.01	0.007	0	41.7	37	80	131	117	0	34	31
2014	7	17	5	7	0	0.892	-0.049	4.291	0.01	0.007	0	41.7	37	79.1	131	118	0	34	32
2014	7	17	5	17	0	0.869	-0.098	4.291	0.01	0.007	0	41.7	36.5	78.3	131	117	0	34	32
2014	7	17	5	27	0	0.886	-0.056	4.288	0.01	0.007	0	41.3	37.4	79.6	131	118	0	35	31
2014	7	17	5	37	0	0.889	-0.059	4.291	0.01	0.007	0	41.7	36.5	79.1	131	117	0	34	32
2014	7	17	5	47	0	0.86	-0.039	4.291	0.01	0.007	0	41.7	37.4	79.6	131	118	0	34	31
2014	7	17	5	57	0	0.876	-0.082	4.291	0.01	0.007	0	41.7	37.8	77.8	131	118	0	34	30
2014	7	17	6	7	0	0.866	-0.095	4.291	0.01	0.007	0	41.7	37	79.1	131	117	0	34	31
2014	7	17	6	17	0	0.899	-0.092	4.291	0.01	0.007	0	41.7	37	78.7	131	117	0	34	31
2014	7	17	6	27	0	0.869	-0.03	4.291	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	17	6	37	0	0.886	-0.066	4.291	0.01	0.007	0	40.9	37	79.1	130	116	0	35	30
2014	7	17	6	47	0	0.883	-0.072	4.291	0.01	0.007	0	41.3	36.5	79.1	130	117	0	34	32
2014	7	17	6	57	0	0.866	-0.079	4.291	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	17	7	7	0	0.86	-0.056	4.291	0.01	0.007	0	41.3	37	78.7	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	7	17	0	0.925	-0.056	4.291	0.01	0.007	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	17	7	27	0	0.853	-0.079	4.291	0.01	0.007	0	41.3	37	78.7	130	117	0	34	31
2014	7	17	7	37	0	0.899	-0.056	4.291	0.01	0.007	0	40.4	36.1	78.3	129	116	0	35	32
2014	7	17	7	47	0	0.873	-0.075	4.291	0.013	0.01	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	17	7	57	0	0.879	-0.108	4.291	0.01	0.007	0	40.9	36.1	78.3	129	115	0	34	31
2014	7	17	8	7	0	0.915	-0.03	4.291	0.01	0.007	0	41.3	36.5	78.3	129	116	0	33	31
2014	7	17	8	17	0	0.86	-0.033	4.291	0.01	0.007	0	40.9	36.5	78.3	129	116	0	34	31
2014	7	17	8	27	0	0.896	-0.059	4.291	0.013	0.01	0	41.3	36.5	77.8	130	117	0	34	32
2014	7	17	8	37	0	0.85	-0.082	4.291	0.01	0.007	0	41.3	36.5	77.8	130	117	0	34	32
2014	7	17	8	47	0	0.846	-0.102	4.291	0.01	0.007	0	40.9	36.5	78.3	129	116	0	34	31
2014	7	17	8	57	0	0.833	-0.049	4.291	0.01	0.007	0	40.9	36.1	77.4	129	116	0	34	32
2014	7	17	9	7	0	0.833	-0.102	4.291	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	17	9	17	0	0.853	-0.066	4.291	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	17	9	27	0	0.896	-0.075	4.291	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	17	9	37	0	0.866	-0.062	4.295	0.01	0.007	0	41.3	36.5	77	129	116	0	33	31
2014	7	17	9	47	0	0.879	-0.075	4.291	0.013	0.01	0	40.9	35.7	77.4	129	115	0	34	32
2014	7	17	9	57	0	0.892	-0.079	4.291	0.016	0.013	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	17	10	7	0	0.856	-0.069	4.295	0.013	0.01	0	40.9	36.5	78.3	129	116	0	34	31
2014	7	17	10	17	0	0.883	-0.066	4.295	0.01	0.007	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	17	10	27	0	0.909	-0.066	4.291	0.01	0.007	0	40.4	35.7	77.4	128	115	0	34	32
2014	7	17	10	37	0	0.856	-0.036	4.291	0.013	0.01	0	40.9	36.1	77	129	115	0	34	31
2014	7	17	10	47	0	0.879	-0.092	4.291	0.01	0.007	0	40.9	35.7	77.4	129	115	0	34	32
2014	7	17	10	57	0	0.883	-0.079	4.295	0.01	0.007	0	40.9	35.7	76.5	129	115	0	34	32
2014	7	17	11	7	0	0.863	-0.085	4.295	0.01	0.007	0	40	36.1	76.5	128	115	0	35	31
2014	7	17	11	17	0	0.873	-0.102	4.295	0.01	0.007	0	40.9	35.7	77.8	129	115	0	34	32
2014	7	17	11	27	0	0.889	-0.072	4.295	0.01	0.007	0	40.4	36.1	76.1	128	115	0	34	31
2014	7	17	11	37	0	0.883	-0.095	4.295	0.01	0.007	0	41.3	36.5	76.5	129	116	0	33	31
2014	7	17	11	47	0	0.869	-0.079	4.295	0.01	0.007	0	40.4	35.7	76.1	128	114	0	34	31
2014	7	17	11	57	0	0.84	-0.098	4.295	0.01	0.007	0	40.4	36.1	76.5	128	115	0	34	31
2014	7	17	12	7	0	0.856	-0.089	4.295	0.013	0.01	0	40.9	35.7	78.3	128	114	0	33	31
2014	7	17	12	17	0	0.84	-0.072	4.295	0.013	0.01	0	40.4	35.3	77.8	128	114	0	34	32
2014	7	17	12	27	0	0.879	-0.108	4.295	0.01	0.007	0	40.9	35.3	78.3	128	114	0	33	32
2014	7	17	12	37	0	0.876	-0.082	4.295	0.01	0.007	0	40	35.3	71	127	114	0	34	32
2014	7	17	12	47	0	0.833	-0.082	4.295	0.013	0.01	0	39.6	35.7	77.8	126	114	0	34	31
2014	7	17	12	57	0	0.81	-0.112	4.295	0.01	0.007	0	39.6	34.8	74	126	113	0	34	32
2014	7	17	13	7	0	0.823	-0.082	4.295	0.01	0.007	0	40	35.7	64.9	126	114	0	33	31
2014	7	17	13	17	0	0.837	-0.066	4.295	0.01	0.007	0	40	35.7	63.6	127	115	0	34	32
2014	7	17	13	27	0	0.823	-0.062	4.295	0.01	0.007	0	39.6	35.3	59.8	126	113	0	34	31
2014	7	17	13	37	0	0.85	-0.098	4.291	0.013	0.01	0	39.6	36.1	60.6	126	114	0	34	30
2014	7	17	13	47	0	0.827	-0.108	4.291	0.01	0.007	0	39.6	35.7	58.9	126	114	0	34	31
2014	7	17	13	57	0	0.82	-0.075	4.291	0.01	0.007	0	40.4	35.7	56.8	127	114	0	33	31
2014	7	17	14	7	0	0.814	-0.092	4.291	0.01	0.007	0	40	35.3	58.5	127	114	0	34	32
2014	7	17	14	17	0	0.846	-0.082	4.291	0.01	0.007	0	40	35.7	54.2	127	115	0	34	32
2014	7	17	14	27	0	0.833	-0.095	4.291	0.01	0.007	0	40.4	35.7	56.3	127	115	0	33	32
2014	7	17	14	37	0	0.81	-0.085	4.291	0.01	0.007	0	40	36.1	57.2	127	115	0	34	31
2014	7	17	14	47	0	0.856	-0.079	4.291	0.013	0.01	0	40	35.3	56.3	126	114	0	33	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	14	57	0	0.84	-0.056	4.291	0.01	0.007	0	39.6	36.1	53.8	126	115	0	34	31
2014	7	17	15	7	0	0.81	-0.082	4.288	0.013	0.01	0	40	36.1	54.6	127	115	0	34	31
2014	7	17	15	17	0	0.863	-0.095	4.288	0.01	0.007	0	40	35.7	55.9	127	115	0	34	32
2014	7	17	15	27	0	0.817	-0.102	4.288	0.01	0.007	0	40	36.1	54.2	127	116	0	34	32
2014	7	17	15	37	0	0.86	-0.092	4.281	0.01	0.007	0	40.4	36.5	52.9	127	116	0	33	31
2014	7	17	15	47	0	0.873	-0.062	4.285	0.01	0.007	0	40.9	37	52	129	117	0	34	31
2014	7	17	15	57	0	0.81	-0.066	4.278	0.013	0.01	0	44.3	41.3	49	137	127	0	34	31
2014	7	17	16	7	0	0.84	-0.066	4.281	0.013	0.01	0	44.7	40.9	50.7	138	126	0	34	31
2014	7	17	16	17	0	0.797	-0.062	4.285	0.01	0.007	0	40	36.1	53.3	127	115	0	34	31
2014	7	17	16	27	0	0.86	-0.098	4.281	0.01	0.007	0	41.7	37.4	53.8	130	119	0	33	32
2014	7	17	16	37	0	0.883	-0.075	4.281	0.01	0.007	0	41.3	37	53.3	130	118	0	34	32
2014	7	17	16	47	0	0.833	-0.092	4.285	0.013	0.01	0	40.9	36.5	53.3	128	116	0	33	31
2014	7	17	16	57	0	0.833	-0.059	4.281	0.01	0.007	0	40	36.1	53.8	127	115	0	34	31
2014	7	17	17	7	0	0.846	-0.105	4.278	0.01	0.007	0	40	36.1	51.2	127	115	0	34	31
2014	7	17	17	17	0	0.81	-0.069	4.281	0.01	0.007	0	40.4	36.1	50.3	127	115	0	33	31
2014	7	17	17	27	0	0.837	-0.098	4.278	0.01	0.007	0	40.9	36.5	53.8	128	116	0	33	31
2014	7	17	17	37	0	0.846	-0.066	4.278	0.013	0.01	0	40.4	36.1	51.6	128	115	0	34	31
2014	7	17	17	47	0	0.82	-0.102	4.278	0.01	0.007	0	40.4	35.7	54.6	127	115	0	33	32
2014	7	17	17	57	0	0.853	-0.052	4.278	0.01	0.007	0	40	36.1	53.8	127	115	0	34	31
2014	7	17	18	7	0	0.804	-0.092	4.275	0.013	0.01	0	40.4	35.7	52.9	127	115	0	33	32
2014	7	17	18	17	0	0.827	-0.085	4.275	0.013	0.01	0	40.4	36.1	54.6	128	115	0	34	31
2014	7	17	18	27	0	0.873	-0.082	4.275	0.01	0.007	0	40.4	36.1	57.6	128	116	0	34	32
2014	7	17	18	37	0	0.889	-0.079	4.275	0.01	0.007	0	40.9	37	55.5	129	117	0	34	31
2014	7	17	18	47	0	0.83	-0.095	4.272	0.01	0.007	0	40.4	36.5	55.9	128	116	0	34	31
2014	7	17	18	57	0	0.876	-0.059	4.272	0.01	0.007	0	41.3	36.5	64.1	129	116	0	33	31
2014	7	17	19	7	0	0.856	-0.082	4.272	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	17	19	17	0	0.873	-0.105	4.272	0.01	0.007	0	40.4	35.7	75.7	128	115	0	34	32
2014	7	17	19	27	0	0.833	-0.069	4.272	0.01	0.007	0	40.9	37	71	129	117	0	34	31
2014	7	17	19	37	0	0.886	-0.066	4.275	0.016	0.013	0	41.7	37	61.1	130	117	0	33	31
2014	7	17	19	47	0	0.846	-0.062	4.275	0.01	0.007	0	43.9	40	55.5	136	124	0	34	31
2014	7	17	19	57	0	0.853	-0.075	4.272	0.013	0.01	0	44.7	40	55.5	137	124	0	33	31
2014	7	17	20	7	0	0.846	-0.066	4.275	0.01	0.007	0	44.3	40	55.9	136	124	0	33	31
2014	7	17	20	17	0	0.886	-0.075	4.275	0.013	0.01	0	44.7	40.4	64.1	138	125	0	34	31
2014	7	17	20	27	0	0.856	-0.062	4.272	0.01	0.007	0	43.4	38.7	66.2	135	122	0	34	32
2014	7	17	20	37	0	0.873	-0.062	4.275	0.01	0.007	0	43	37.8	69.7	133	120	0	33	32
2014	7	17	20	47	0	0.856	-0.039	4.275	0.01	0.007	0	42.1	38.3	67.9	132	120	0	34	31
2014	7	17	20	57	0	0.896	-0.056	4.272	0.01	0.007	0	41.3	37	69.2	130	117	0	34	31
2014	7	17	21	7	0	0.846	-0.075	4.275	0.013	0.01	0	41.3	37	74.4	130	117	0	34	31
2014	7	17	21	17	0	0.863	-0.098	4.275	0.01	0.007	0	41.3	36.5	75.7	129	116	0	33	31
2014	7	17	21	27	0	0.846	-0.079	4.275	0.01	0.007	0	40.9	36.1	76.5	128	115	0	33	31
2014	7	17	21	37	0	0.876	-0.092	4.281	0.01	0.007	0	40	36.1	77.4	127	115	0	34	31
2014	7	17	21	47	0	0.85	-0.046	4.281	0.01	0.007	0	40	35.3	77	127	114	0	34	32
2014	7	17	21	57	0	0.896	-0.046	4.275	0.013	0.01	0	40.4	35.7	74.8	127	115	0	33	32
2014	7	17	22	7	0	0.846	-0.066	4.275	0.01	0.007	0	40	35.7	74	127	114	0	34	31
2014	7	17	22	17	0	0.876	-0.066	4.285	0.01	0.007	0	40	35.7	77.8	127	114	0	34	31
2014	7	17	22	27	0	0.883	-0.072	4.285	0.013	0.01	0	40.4	35.7	77.8	127	114	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	17	22	37	0	0.883	-0.095	4.285	0.016	0.013	0	40	35.3	78.7	127	113	0	34	31
2014	7	17	22	47	0	0.889	-0.056	4.285	0.01	0.007	0	40	35.7	79.1	127	114	0	34	31
2014	7	17	22	57	0	0.853	-0.066	4.285	0.013	0.01	0	40.4	35.7	77.8	127	114	0	33	31
2014	7	17	23	7	0	0.892	-0.075	4.285	0.01	0.007	0	40.4	36.1	78.7	128	115	0	34	31
2014	7	17	23	17	0	0.883	-0.082	4.285	0.01	0.007	0	40	35.3	79.1	127	114	0	34	32
2014	7	17	23	27	0	0.876	-0.072	4.285	0.01	0.007	0	40	35.7	78.7	127	114	0	34	31
2014	7	17	23	37	0	0.873	-0.089	4.285	0.01	0.007	0	40.4	35.3	79.1	127	113	0	33	31
2014	7	17	23	47	0	0.909	-0.079	4.288	0.013	0.01	0	39.6	35.7	79.6	126	114	0	34	31
2014	7	17	23	57	0	0.896	-0.075	4.285	0.013	0.01	0	40.4	34.8	78.7	127	113	0	33	32
2014	7	18	0	7	0	0.879	-0.069	4.285	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	18	0	17	0	0.886	-0.098	4.285	0.01	0.007	0	40.4	35.7	78.3	127	114	0	33	31
2014	7	18	0	27	0	0.863	-0.052	4.288	0.013	0.01	0	40.4	35.7	78.3	128	114	0	34	31
2014	7	18	0	37	0	0.873	-0.095	4.288	0.01	0.007	0	40	35.7	78.3	127	114	0	34	31
2014	7	18	0	47	0	0.84	-0.046	4.288	0.01	0.007	0	40.4	35.7	79.1	128	114	0	34	31
2014	7	18	0	57	0	0.909	-0.079	4.288	0.013	0.01	0	40.4	35.7	80	127	114	0	33	31
2014	7	18	1	7	0	0.866	-0.062	4.288	0.01	0.007	0	40	35.7	79.1	127	114	0	34	31
2014	7	18	1	17	0	0.873	-0.095	4.288	0.013	0.01	0	40.4	35.3	78.7	127	114	0	33	32
2014	7	18	1	27	0	0.883	-0.089	4.288	0.01	0.007	0	40.4	35.7	77.8	128	114	0	34	31
2014	7	18	1	37	0	0.912	-0.085	4.288	0.01	0.007	0	40.4	36.1	79.1	128	115	0	34	31
2014	7	18	1	47	0	0.899	-0.098	4.288	0.01	0.007	0	40.4	35.7	78.7	128	115	0	34	32
2014	7	18	1	57	0	0.935	-0.079	4.288	0.01	0.007	0	40.4	36.1	79.1	128	115	0	34	31
2014	7	18	2	7	0	0.883	-0.089	4.291	0.01	0.007	0	40.4	36.1	79.6	128	115	0	34	31
2014	7	18	2	17	0	0.899	-0.072	4.288	0.01	0.007	0	40.4	36.1	78.7	128	115	0	34	31
2014	7	18	2	27	0	0.938	-0.075	4.291	0.01	0.007	0	40.4	36.1	79.6	128	115	0	34	31
2014	7	18	2	37	0	0.896	-0.092	4.288	0.01	0.007	0	40.9	36.1	79.6	129	116	0	34	32
2014	7	18	2	47	0	0.896	-0.095	4.291	0.013	0.01	0	40.9	36.5	80	129	116	0	34	31
2014	7	18	2	57	0	0.902	-0.043	4.291	0.013	0.01	0	40.4	36.1	78.7	128	115	0	34	31
2014	7	18	3	7	0	0.889	-0.049	4.291	0.01	0.007	0	40.4	36.5	80	128	116	0	34	31
2014	7	18	3	17	0	0.876	-0.095	4.291	0.01	0.007	0	40	36.1	80	127	115	0	34	31
2014	7	18	3	27	0	0.919	-0.049	4.291	0.01	0.007	0	40.4	36.1	79.6	128	116	0	34	32
2014	7	18	3	37	0	0.896	-0.125	4.291	0.013	0.01	0	41.3	36.5	80.4	129	116	0	33	31
2014	7	18	3	47	0	0.84	-0.082	4.291	0.01	0.007	0	40.9	37	80.4	129	117	0	34	31
2014	7	18	3	57	0	0.876	-0.082	4.291	0.01	0.007	0	40.9	37	80.8	129	117	0	34	31
2014	7	18	4	7	0	0.873	-0.092	4.291	0.01	0.007	0	40.9	36.5	80	129	117	0	34	32
2014	7	18	4	17	0	0.912	-0.092	4.291	0.01	0.007	0	40.9	37	80.8	129	117	0	34	31
2014	7	18	4	27	0	0.932	-0.079	4.291	0.01	0.007	0	40.9	37	80	129	117	0	34	31
2014	7	18	4	37	0	0.856	-0.079	4.291	0.01	0.007	0	41.3	37.4	80	130	118	0	34	31
2014	7	18	4	47	0	0.879	-0.059	4.291	0.01	0.007	0	41.3	37.4	79.6	130	118	0	34	31
2014	7	18	4	57	0	0.853	-0.059	4.291	0.01	0.007	0	41.3	37	79.6	130	118	0	34	32
2014	7	18	5	7	0	0.892	-0.062	4.291	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	18	5	17	0	0.866	-0.082	4.291	0.01	0.007	0	41.3	37	77.8	130	118	0	34	32
2014	7	18	5	27	0	0.902	-0.062	4.291	0.013	0.01	0	41.3	37	78.7	130	118	0	34	32
2014	7	18	5	37	0	0.873	-0.075	4.291	0.01	0.007	0	41.7	37.8	78.3	131	119	0	34	31
2014	7	18	5	47	0	0.902	-0.089	4.291	0.013	0.01	0	41.7	37.4	76.1	131	119	0	34	32
2014	7	18	5	57	0	0.886	-0.092	4.295	0.01	0.007	0	41.3	37.4	77.8	130	118	0	34	31
2014	7	18	6	7	0	0.902	-0.089	4.295	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	6	17	0	0.86	-0.066	4.295	0.01	0.007	0	41.3	37	77.8	130	118	0	34	32
2014	7	18	6	27	0	0.899	-0.082	4.295	0.01	0.007	0	41.7	37.4	77.4	131	118	0	34	31
2014	7	18	6	37	0	0.856	-0.052	4.295	0.01	0.007	0	41.3	37	78.3	130	118	0	34	32
2014	7	18	6	47	0	0.879	-0.059	4.295	0.01	0.007	0	40.9	36.5	78.7	130	117	0	35	32
2014	7	18	6	57	0	0.856	-0.092	4.298	0.013	0.01	0	41.7	37.4	78.7	131	118	0	34	31
2014	7	18	7	7	0	0.892	-0.062	4.298	0.013	0.01	0	40.9	36.1	79.1	129	116	0	34	32
2014	7	18	7	17	0	0.935	-0.072	4.298	0.013	0.01	0	40.9	36.5	78.3	130	117	0	35	32
2014	7	18	7	27	0	0.899	-0.095	4.298	0.016	0.013	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	18	7	37	0	0.886	-0.089	4.298	0.016	0.013	0	41.3	36.5	78.3	130	117	0	34	32
2014	7	18	7	47	0	0.883	-0.075	4.298	0.013	0.01	0	40.9	36.1	78.7	129	116	0	34	32
2014	7	18	7	57	0	0.889	-0.046	4.298	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	18	8	7	0	0.876	-0.066	4.298	0.01	0.007	0	41.7	36.1	77.8	130	116	0	33	32
2014	7	18	8	17	0	0.85	-0.092	4.298	0.01	0.007	0	41.3	36.5	78.3	130	117	0	34	32
2014	7	18	8	27	0	0.899	-0.108	4.298	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	18	8	37	0	0.863	-0.069	4.298	0.01	0.007	0	41.3	37	77.8	130	118	0	34	32
2014	7	18	8	47	0	0.853	-0.072	4.298	0.01	0.007	0	41.7	37	77.4	131	118	0	34	32
2014	7	18	8	57	0	0.899	-0.059	4.298	0.01	0.007	0	41.7	37	77.8	131	118	0	34	32
2014	7	18	9	7	0	0.866	-0.072	4.301	0.01	0.007	0	42.1	37	77	131	118	0	33	32
2014	7	18	9	17	0	0.883	-0.066	4.301	0.01	0.007	0	40.9	37	78.3	130	117	0	35	31
2014	7	18	9	27	0	0.883	-0.052	4.301	0.013	0.01	0	41.3	37	77.8	130	117	0	34	31
2014	7	18	9	37	0	0.919	-0.095	4.301	0.01	0.007	0	40.9	37	77.8	129	117	0	34	31
2014	7	18	9	47	0	0.886	-0.069	4.301	0.01	0.007	0	40.9	37	77.8	130	117	0	35	31
2014	7	18	9	57	0	0.886	-0.082	4.301	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	18	10	7	0	0.909	-0.056	4.301	0.01	0.007	0	41.3	36.5	77.4	130	117	0	34	32
2014	7	18	10	17	0	0.869	-0.082	4.301	0.01	0.007	0	40.9	36.1	78.3	129	116	0	34	32
2014	7	18	10	27	0	0.863	-0.108	4.301	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	18	10	37	0	0.896	-0.085	4.301	0.01	0.007	0	40.9	36.1	77.4	129	116	0	34	32
2014	7	18	10	47	0	0.906	-0.108	4.301	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	18	10	57	0	0.869	-0.102	4.298	0.01	0.007	0	40.9	36.5	76.1	129	116	0	34	31
2014	7	18	11	7	0	0.833	-0.072	4.301	0.01	0.007	0	41.3	36.1	77.8	129	116	0	33	32
2014	7	18	11	17	0	0.843	-0.098	4.301	0.013	0.01	0	40.9	36.1	77	129	116	0	34	32
2014	7	18	11	27	0	0.869	-0.108	4.301	0.01	0.007	0	40.4	35.7	77	128	115	0	34	32
2014	7	18	11	37	0	0.853	-0.128	4.301	0.01	0.007	0	40.4	35.7	77.8	128	115	0	34	32
2014	7	18	11	47	0	0.886	-0.085	4.301	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	18	11	57	0	0.843	-0.072	4.301	0.013	0.01	0	40.4	36.5	77	128	116	0	34	31
2014	7	18	12	7	0	0.889	-0.089	4.301	0.01	0.007	0	40.9	36.1	74.4	128	116	0	33	32
2014	7	18	12	17	0	0.781	-0.075	4.298	0.01	0.007	0	41.3	36.5	77	129	116	0	33	31
2014	7	18	12	27	0	0.83	-0.043	4.298	0.01	0.007	0	40.4	36.5	72.7	128	116	0	34	31
2014	7	18	12	37	0	0.869	-0.075	4.301	0.01	0.007	0	40.4	36.5	76.5	128	116	0	34	31
2014	7	18	12	47	0	0.866	-0.082	4.301	0.013	0.01	0	40.4	36.1	74	128	115	0	34	31
2014	7	18	12	57	0	0.85	-0.098	4.298	0.01	0.007	0	40	35.7	74	127	115	0	34	32
2014	7	18	13	7	0	0.853	-0.085	4.298	0.01	0.007	0	40	36.1	65.8	127	115	0	34	31
2014	7	18	13	17	0	0.86	-0.098	4.298	0.01	0.007	0	40.4	36.5	67.1	128	116	0	34	31
2014	7	18	13	27	0	0.82	-0.075	4.298	0.01	0.007	0	41.3	36.5	58	130	117	0	34	32
2014	7	18	13	37	0	0.856	-0.082	4.298	0.01	0.007	0	40.4	36.1	64.1	128	116	0	34	32
2014	7	18	13	47	0	0.876	-0.095	4.298	0.01	0.007	0	40.9	37	58.5	129	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	13	57	0	0.843	-0.066	4.298	0.01	0.007	0	43.4	38.7	57.6	135	122	0	34	32
2014	7	18	14	7	0	0.804	-0.059	4.298	0.01	0.007	0	41.3	37	58.9	130	117	0	34	31
2014	7	18	14	17	0	0.84	-0.062	4.298	0.013	0.01	0	41.3	37	55	130	118	0	34	32
2014	7	18	14	27	0	0.85	-0.072	4.298	0.01	0.007	0	41.3	37	61.1	129	117	0	33	31
2014	7	18	14	37	0	0.846	-0.092	4.298	0.013	0.01	0	40.4	36.5	60.6	128	116	0	34	31
2014	7	18	14	47	0	0.866	-0.069	4.298	0.01	0.007	0	40.4	36.1	56.8	128	115	0	34	31
2014	7	18	14	57	0	0.896	-0.089	4.298	0.01	0.007	0	41.3	36.1	54.6	129	116	0	33	32
2014	7	18	15	7	0	0.853	-0.098	4.298	0.01	0.007	0	40.9	36.5	59.8	129	116	0	34	31
2014	7	18	15	17	0	0.853	-0.085	4.295	0.01	0.007	0	44.3	40	51.6	137	124	0	34	31
2014	7	18	15	27	0	0.863	-0.046	4.295	0.01	0.007	0	42.1	37	52.5	131	118	0	33	32
2014	7	18	15	37	0	0.853	-0.075	4.295	0.016	0.013	0	42.6	37.8	53.3	132	119	0	33	31
2014	7	18	15	47	0	0.814	-0.072	4.295	0.01	0.007	0	41.7	37.4	52.5	131	118	0	34	31
2014	7	18	15	57	0	0.846	-0.066	4.295	0.01	0.007	0	41.7	37.4	56.8	130	118	0	33	31
2014	7	18	16	7	0	0.853	-0.066	4.295	0.013	0.01	0	41.3	37	53.3	130	117	0	34	31
2014	7	18	16	17	0	0.883	-0.098	4.295	0.01	0.007	0	41.3	37	52.5	130	117	0	34	31
2014	7	18	16	27	0	0.866	-0.079	4.291	0.01	0.007	0	41.3	37	51.6	130	117	0	34	31
2014	7	18	16	37	0	0.873	-0.079	4.291	0.013	0.01	0	41.3	36.5	52	130	117	0	34	32
2014	7	18	16	47	0	0.817	-0.049	4.291	0.013	0.01	0	40.9	37	52.5	130	117	0	35	31
2014	7	18	16	57	0	0.827	-0.066	4.291	0.01	0.007	0	41.3	36.1	52.9	129	116	0	33	32
2014	7	18	17	7	0	0.843	-0.085	4.291	0.01	0.007	0	41.3	36.5	53.8	129	116	0	33	31
2014	7	18	17	17	0	0.863	-0.089	4.291	0.01	0.007	0	41.3	37	55	130	117	0	34	31
2014	7	18	17	27	0	0.846	-0.082	4.291	0.01	0.007	0	41.3	37.4	55.9	130	118	0	34	31
2014	7	18	17	37	0	0.83	-0.079	4.291	0.01	0.007	0	41.7	37	53.3	130	117	0	33	31
2014	7	18	17	47	0	0.886	-0.069	4.288	0.01	0.007	0	41.3	37	56.8	130	117	0	34	31
2014	7	18	17	57	0	0.833	-0.062	4.288	0.016	0.016	0	40.9	36.5	55	129	116	0	34	31
2014	7	18	18	7	0	0.846	-0.075	4.288	0.01	0.007	0	40.9	36.1	54.6	128	115	0	33	31
2014	7	18	18	17	0	0.846	-0.079	4.285	0.01	0.007	0	43	37.8	49.5	133	120	0	33	32
2014	7	18	18	27	0	0.869	-0.092	4.281	0.01	0.007	0	42.1	37.8	50.7	132	119	0	34	31
2014	7	18	18	37	0	0.873	-0.121	4.281	0.01	0.007	0	43.9	39.6	48.6	136	123	0	34	31
2014	7	18	18	47	0	0.84	-0.098	4.285	0.013	0.01	0	43	38.3	56.3	133	120	0	33	31
2014	7	18	18	57	0	0.883	-0.079	4.288	0.013	0.01	0	42.6	37.8	60.6	132	119	0	33	31
2014	7	18	19	7	0	0.863	-0.082	4.288	0.01	0.007	0	41.3	37	60.6	130	117	0	34	31
2014	7	18	19	17	0	0.814	-0.082	4.288	0.01	0.007	0	40.9	36.1	61.1	129	116	0	34	32
2014	7	18	19	27	0	0.866	-0.079	4.281	0.01	0.007	0	44.7	40	51.2	137	124	0	33	31
2014	7	18	19	37	0	0.879	-0.105	4.285	0.016	0.013	0	42.1	38.3	55.5	132	120	0	34	31
2014	7	18	19	47	0	0.886	-0.066	4.278	0.01	0.007	0	43	39.1	49	134	122	0	34	31
2014	7	18	19	57	0	0.846	-0.072	4.285	0.01	0.007	0	41.3	37.4	60.6	130	118	0	34	31
2014	7	18	20	7	0	0.892	-0.079	4.285	0.01	0.007	0	41.7	37.8	55	131	119	0	34	31
2014	7	18	20	17	0	0.843	-0.075	4.285	0.016	0.016	0	42.1	37.8	58.9	131	119	0	33	31
2014	7	18	20	27	0	0.827	-0.082	4.285	0.01	0.007	0	42.1	37.8	53.8	131	119	0	33	31
2014	7	18	20	37	0	0.843	-0.085	4.285	0.01	0.007	0	41.7	37.8	53.8	131	119	0	34	31
2014	7	18	20	47	0	0.804	-0.108	4.285	0.01	0.007	0	42.1	38.3	53.8	132	120	0	34	31
2014	7	18	20	57	0	0.804	-0.066	4.285	0.013	0.01	0	42.6	37.8	53.8	132	119	0	33	31
2014	7	18	21	7	0	0.856	-0.089	4.285	0.01	0.007	0	41.3	37	57.2	130	117	0	34	31
2014	7	18	21	17	0	0.896	-0.085	4.285	0.01	0.007	0	40.9	37	55.9	129	117	0	34	31
2014	7	18	21	27	0	0.853	-0.069	4.288	0.01	0.007	0	40.9	36.5	56.8	129	116	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	18	21	37	0	0.846	-0.069	4.288	0.013	0.01	0	40.4	36.5	58	128	116	0	34	31
2014	7	18	21	47	0	0.83	-0.098	4.288	0.013	0.01	0	40.9	36.1	65.4	128	115	0	33	31
2014	7	18	21	57	0	0.823	-0.079	4.288	0.01	0.007	0	40.9	36.1	62.8	128	115	0	33	31
2014	7	18	22	7	0	0.843	-0.079	4.288	0.01	0.007	0	40.4	36.5	61.5	128	116	0	34	31
2014	7	18	22	17	0	0.823	-0.112	4.288	0.01	0.007	0	40.4	35.7	74.8	128	115	0	34	32
2014	7	18	22	27	0	0.873	-0.072	4.291	0.016	0.016	0	40.4	36.1	75.7	128	115	0	34	31
2014	7	18	22	37	0	0.853	-0.092	4.288	0.01	0.007	0	40.9	36.1	62.8	128	115	0	33	31
2014	7	18	22	47	0	0.827	-0.069	4.288	0.01	0.007	0	40.4	35.7	66.2	128	115	0	34	32
2014	7	18	22	57	0	0.876	-0.072	4.291	0.01	0.007	0	40	35.3	71.8	127	114	0	34	32
2014	7	18	23	7	0	0.86	-0.098	4.291	0.013	0.01	0	40	36.1	73.1	127	115	0	34	31
2014	7	18	23	17	0	0.843	-0.082	4.291	0.01	0.007	0	40	36.1	79.6	127	115	0	34	31
2014	7	18	23	27	0	0.896	-0.069	4.291	0.01	0.007	0	40	36.1	80	127	115	0	34	31
2014	7	18	23	37	0	0.84	-0.066	4.291	0.01	0.007	0	40.4	36.1	80	128	115	0	34	31
2014	7	18	23	47	0	0.856	-0.095	4.291	0.013	0.01	0	40.4	36.1	80.4	128	115	0	34	31
2014	7	18	23	57	0	0.886	-0.092	4.291	0.01	0.007	0	40.9	36.1	80.4	128	115	0	33	31
2014	7	19	0	7	0	0.912	-0.066	4.291	0.01	0.007	0	40.4	36.1	81.3	128	115	0	34	31
2014	7	19	0	17	0	0.896	-0.092	4.291	0.01	0.007	0	40.4	36.1	81.3	128	115	0	34	31
2014	7	19	0	27	0	0.889	-0.098	4.291	0.01	0.007	0	40.4	35.7	81.3	128	115	0	34	32
2014	7	19	0	37	0	0.86	-0.075	4.291	0.01	0.007	0	40.9	35.7	81.3	128	115	0	33	32
2014	7	19	0	47	0	0.85	-0.072	4.291	0.01	0.007	0	40.9	36.1	80.8	129	115	0	34	31
2014	7	19	0	57	0	0.843	-0.095	4.291	0.01	0.007	0	40.9	36.5	80	129	116	0	34	31
2014	7	19	1	7	0	0.873	-0.066	4.291	0.01	0.007	0	40.4	36.1	80.4	128	115	0	34	31
2014	7	19	1	17	0	0.846	-0.043	4.291	0.01	0.007	0	41.3	36.1	80.4	129	115	0	33	31
2014	7	19	1	27	0	0.833	-0.046	4.291	0.013	0.01	0	40	36.5	80.8	127	116	0	34	31
2014	7	19	1	37	0	0.912	-0.075	4.291	0.01	0.007	0	40.9	35.7	80.4	129	115	0	34	32
2014	7	19	1	47	0	0.873	-0.082	4.291	0.013	0.01	0	40.4	36.1	81.3	129	115	0	35	31
2014	7	19	1	57	0	0.945	-0.128	4.291	0.01	0.007	0	40.9	35.7	80	128	114	0	33	31
2014	7	19	2	7	0	0.899	-0.072	4.291	0.01	0.007	0	40.9	36.1	80	129	115	0	34	31
2014	7	19	2	17	0	0.86	-0.079	4.291	0.01	0.007	0	40.9	36.1	79.6	129	115	0	34	31
2014	7	19	2	27	0	0.846	-0.059	4.291	0.01	0.007	0	41.7	36.1	80	130	115	0	33	31
2014	7	19	2	37	0	0.869	-0.075	4.291	0.01	0.007	0	40.9	36.1	79.6	129	115	0	34	31
2014	7	19	2	47	0	0.873	-0.075	4.291	0.01	0.007	0	41.3	36.1	79.6	130	116	0	34	32
2014	7	19	2	57	0	0.889	-0.056	4.291	0.01	0.007	0	41.3	36.5	79.1	130	116	0	34	31
2014	7	19	3	7	0	0.866	-0.056	4.291	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	19	3	17	0	0.899	-0.072	4.291	0.013	0.01	0	41.7	37	78.7	131	117	0	34	31
2014	7	19	3	27	0	0.886	-0.062	4.291	0.01	0.007	0	41.7	37	78.7	131	117	0	34	31
2014	7	19	3	37	0	0.925	-0.066	4.295	0.01	0.007	0	41.3	36.5	79.6	130	116	0	34	31
2014	7	19	3	47	0	0.886	-0.059	4.295	0.01	0.007	0	41.7	36.5	80	130	116	0	33	31
2014	7	19	3	57	0	0.856	-0.062	4.295	0.016	0.013	0	41.7	36.1	80	131	116	0	34	32
2014	7	19	4	7	0	0.906	-0.079	4.295	0.013	0.01	0	41.7	36.5	79.6	131	117	0	34	32
2014	7	19	4	17	0	0.925	-0.075	4.295	0.01	0.007	0	41.3	36.5	80.4	130	117	0	34	32
2014	7	19	4	27	0	0.869	-0.092	4.295	0.013	0.01	0	41.7	36.5	79.1	131	117	0	34	32
2014	7	19	4	37	0	0.879	-0.033	4.295	0.01	0.007	0	41.7	37	79.1	131	117	0	34	31
2014	7	19	4	47	0	0.856	-0.079	4.295	0.01	0.007	0	41.3	36.5	79.6	131	117	0	35	32
2014	7	19	4	57	0	0.896	-0.118	4.295	0.01	0.007	0	41.7	36.5	79.1	131	117	0	34	32
2014	7	19	5	7	0	0.912	-0.059	4.295	0.013	0.01	0	41.7	37	78.7	131	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	5	17	0	0.883	-0.069	4.295	0.01	0.007	0	42.1	37.4	78.7	132	118	0	34	31
2014	7	19	5	27	0	0.915	-0.062	4.295	0.01	0.007	0	42.1	37	78.7	132	118	0	34	32
2014	7	19	5	37	0	0.883	-0.079	4.295	0.01	0.007	0	42.1	37.4	79.1	132	118	0	34	31
2014	7	19	5	47	0	0.869	-0.059	4.298	0.01	0.007	0	42.1	37	78.3	132	118	0	34	32
2014	7	19	5	57	0	0.873	-0.069	4.298	0.01	0.007	0	42.1	37	78.3	132	118	0	34	32
2014	7	19	6	7	0	0.896	-0.069	4.298	0.01	0.007	0	41.7	37	78.3	131	117	0	34	31
2014	7	19	6	17	0	0.899	-0.075	4.298	0.01	0.007	0	41.7	37	79.6	131	117	0	34	31
2014	7	19	6	27	0	0.85	-0.062	4.301	0.01	0.007	0	41.7	37	79.1	131	117	0	34	31
2014	7	19	6	37	0	0.883	-0.062	4.298	0.01	0.007	0	41.3	36.5	78.3	130	116	0	34	31
2014	7	19	6	47	0	0.909	-0.066	4.298	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	19	6	57	0	0.899	-0.079	4.298	0.01	0.007	0	40.9	36.1	77.8	130	116	0	35	32
2014	7	19	7	7	0	0.928	-0.082	4.298	0.01	0.007	0	41.3	36.1	77.8	130	116	0	34	32
2014	7	19	7	17	0	0.922	-0.079	4.298	0.01	0.007	0	41.7	36.1	77.4	130	116	0	33	32
2014	7	19	7	27	0	0.883	-0.062	4.301	0.01	0.007	0	41.3	36.1	78.3	130	116	0	34	32
2014	7	19	7	37	0	0.896	-0.069	4.298	0.01	0.007	0	40.9	36.5	77.4	130	116	0	35	31
2014	7	19	7	47	0	0.833	-0.062	4.301	0.013	0.01	0	41.3	36.1	76.5	130	116	0	34	32
2014	7	19	7	57	0	0.919	-0.066	4.298	0.013	0.01	0	41.7	36.1	77.4	131	116	0	34	32
2014	7	19	8	7	0	0.873	-0.085	4.301	0.01	0.007	0	41.3	36.1	77.4	130	116	0	34	32
2014	7	19	8	17	0	0.906	-0.059	4.301	0.013	0.01	0	41.3	36.1	77.8	130	116	0	34	32
2014	7	19	8	27	0	0.902	-0.089	4.301	0.01	0.007	0	41.3	36.5	77.8	130	116	0	34	31
2014	7	19	8	37	0	0.892	-0.095	4.301	0.01	0.007	0	41.3	36.5	77	130	116	0	34	31
2014	7	19	8	47	0	0.906	-0.108	4.301	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	19	8	57	0	0.935	-0.112	4.301	0.013	0.01	0	41.3	36.1	77.4	130	116	0	34	32
2014	7	19	9	7	0	0.866	-0.062	4.301	0.01	0.007	0	41.3	36.1	77.8	130	116	0	34	32
2014	7	19	9	17	0	0.919	-0.089	4.301	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	19	9	27	0	0.896	-0.059	4.301	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	19	9	37	0	0.915	-0.066	4.301	0.013	0.01	0	41.7	37	76.5	131	117	0	34	31
2014	7	19	9	47	0	0.889	-0.075	4.301	0.01	0.007	0	41.7	36.5	77.8	131	117	0	34	32
2014	7	19	9	57	0	0.866	-0.079	4.301	0.01	0.007	0	41.7	37.4	77	131	118	0	34	31
2014	7	19	10	7	0	0.925	-0.082	4.301	0.01	0.007	0	41.7	37	77.8	131	117	0	34	31
2014	7	19	10	17	0	0.896	-0.043	4.301	0.013	0.01	0	42.1	37	77.8	131	117	0	33	31
2014	7	19	10	27	0	0.843	-0.062	4.301	0.01	0.007	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	19	10	37	0	0.886	-0.072	4.301	0.01	0.007	0	41.7	37	77.4	131	117	0	34	31
2014	7	19	10	47	0	0.886	-0.089	4.301	0.01	0.007	0	41.7	37	75.7	131	117	0	34	31
2014	7	19	10	57	0	0.85	-0.098	4.301	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	19	11	7	0	0.863	-0.075	4.298	0.013	0.01	0	41.7	37	74	130	117	0	33	31
2014	7	19	11	17	0	0.873	-0.069	4.298	0.01	0.007	0	40.4	36.1	66.7	129	116	0	35	32
2014	7	19	11	27	0	0.906	-0.092	4.298	0.01	0.007	0	41.3	37	66.2	130	117	0	34	31
2014	7	19	11	37	0	0.846	-0.102	4.298	0.01	0.007	0	40.4	36.1	70.5	129	116	0	35	32
2014	7	19	11	47	0	0.869	-0.072	4.298	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	19	11	57	0	0.899	-0.082	4.295	0.01	0.007	0	40.9	36.1	61.9	129	116	0	34	32
2014	7	19	12	7	0	0.856	-0.066	4.295	0.01	0.007	0	40.9	36.5	65.4	129	116	0	34	31
2014	7	19	12	17	0	0.846	-0.098	4.298	0.01	0.007	0	40.9	36.1	68.4	129	116	0	34	32
2014	7	19	12	27	0	0.856	-0.102	4.295	0.01	0.007	0	40.9	36.5	69.2	129	116	0	34	31
2014	7	19	12	37	0	0.866	-0.082	4.298	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	19	12	47	0	0.873	-0.092	4.295	0.01	0.007	0	41.3	37	72.7	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	12	57	0	0.863	-0.075	4.295	0.01	0.007	0	41.3	36.5	62.8	130	117	0	34	32
2014	7	19	13	7	0	0.85	-0.056	4.295	0.01	0.007	0	41.7	37	55	131	118	0	34	32
2014	7	19	13	17	0	0.814	-0.075	4.295	0.01	0.007	0	41.3	36.5	53.8	130	117	0	34	32
2014	7	19	13	27	0	0.837	-0.082	4.295	0.013	0.01	0	41.3	37	65.4	130	117	0	34	31
2014	7	19	13	37	0	0.869	-0.079	4.295	0.01	0.007	0	42.1	36.5	64.1	130	116	0	32	31
2014	7	19	13	47	0	0.823	-0.079	4.295	0.013	0.01	0	40.4	36.1	60.6	128	115	0	34	31
2014	7	19	13	57	0	0.791	-0.039	4.295	0.01	0.007	0	40.4	36.1	64.9	128	115	0	34	31
2014	7	19	14	7	0	0.846	-0.092	4.295	0.01	0.007	0	40	35.7	56.8	127	114	0	34	31
2014	7	19	14	17	0	0.843	-0.121	4.295	0.01	0.007	0	40.4	35.7	59.8	128	115	0	34	32
2014	7	19	14	27	0	0.84	-0.056	4.291	0.01	0.007	0	40.4	36.1	53.8	128	115	0	34	31
2014	7	19	14	37	0	0.843	-0.079	4.291	0.013	0.01	0	40.9	36.5	58.5	129	116	0	34	31
2014	7	19	14	47	0	0.863	-0.066	4.291	0.01	0.007	0	41.7	37	58	131	117	0	34	31
2014	7	19	14	57	0	0.827	-0.062	4.291	0.01	0.007	0	40.9	36.5	51.6	129	116	0	34	31
2014	7	19	15	7	0	0.853	-0.052	4.291	0.01	0.007	0	42.1	37	56.3	131	118	0	33	32
2014	7	19	15	17	0	0.856	-0.072	4.288	0.01	0.007	0	42.1	37.4	55.5	132	118	0	34	31
2014	7	19	15	27	0	0.837	-0.085	4.288	0.01	0.007	0	42.1	37.4	54.2	131	118	0	33	31
2014	7	19	15	37	0	0.876	-0.075	4.288	0.01	0.007	0	41.3	37	58.5	130	117	0	34	31
2014	7	19	15	47	0	0.814	-0.092	4.288	0.013	0.01	0	42.6	37.4	55.5	132	118	0	33	31
2014	7	19	15	57	0	0.82	-0.098	4.285	0.01	0.007	0	42.1	37.4	55	131	118	0	33	31
2014	7	19	16	7	0	0.823	-0.046	4.285	0.013	0.01	0	42.6	37.4	53.8	132	118	0	33	31
2014	7	19	16	17	0	0.837	-0.092	4.285	0.013	0.01	0	41.3	37	59.8	130	117	0	34	31
2014	7	19	16	27	0	0.823	-0.082	4.285	0.01	0.007	0	41.3	37	52	130	117	0	34	31
2014	7	19	16	37	0	0.817	-0.062	4.285	0.01	0.007	0	41.3	36.5	54.2	130	117	0	34	32
2014	7	19	16	47	0	0.883	-0.089	4.281	0.01	0.007	0	42.1	37	52.9	131	117	0	33	31
2014	7	19	16	57	0	0.778	-0.095	4.281	0.016	0.013	0	45.2	40.4	48.2	139	126	0	34	32
2014	7	19	17	7	0	0.804	-0.118	4.278	0.013	0.01	0	47.3	44.3	45.6	144	134	0	34	31
2014	7	19	17	17	0	0.846	-0.079	4.278	0.013	0.01	0	43	39.1	52.5	134	123	0	34	32
2014	7	19	17	27	0	0.827	-0.082	4.281	0.01	0.007	0	42.6	38.7	51.2	133	121	0	34	31
2014	7	19	17	37	0	0.85	-0.062	4.278	0.01	0.007	0	43	39.1	49.9	134	122	0	34	31
2014	7	19	17	47	0	0.823	-0.079	4.278	0.013	0.01	0	42.6	38.7	49.9	133	121	0	34	31
2014	7	19	17	57	0	0.804	-0.075	4.278	0.01	0.007	0	42.1	37.8	51.2	131	119	0	33	31
2014	7	19	18	7	0	0.853	-0.075	4.278	0.01	0.007	0	42.1	37.8	52	131	119	0	33	31
2014	7	19	18	17	0	0.801	-0.066	4.278	0.01	0.007	0	42.1	38.3	50.7	132	120	0	34	31
2014	7	19	18	27	0	0.781	-0.052	4.278	0.013	0.01	0	41.7	37.8	50.7	131	119	0	34	31
2014	7	19	18	37	0	0.843	-0.098	4.278	0.013	0.01	0	41.7	37.8	54.2	131	119	0	34	31
2014	7	19	18	47	0	0.807	-0.095	4.278	0.013	0.01	0	41.3	37.8	50.7	130	119	0	34	31
2014	7	19	18	57	0	0.817	-0.072	4.278	0.01	0.007	0	41.3	37	52.5	130	118	0	34	32
2014	7	19	19	7	0	0.83	-0.075	4.278	0.013	0.01	0	41.3	37.4	52.9	130	118	0	34	31
2014	7	19	19	17	0	0.843	-0.082	4.278	0.013	0.01	0	41.7	37.8	54.2	131	119	0	34	31
2014	7	19	19	27	0	0.846	-0.108	4.275	0.01	0.007	0	43	39.1	47.7	134	122	0	34	31
2014	7	19	19	37	0	0.846	-0.082	4.275	0.01	0.007	0	43.9	39.6	45.2	136	124	0	34	32
2014	7	19	19	47	0	0.876	-0.075	4.278	0.01	0.007	0	43	37.8	46.9	133	119	0	33	31
2014	7	19	19	57	0	0.866	-0.098	4.278	0.01	0.007	0	41.3	37.8	52.9	130	119	0	34	31
2014	7	19	20	7	0	0.843	-0.075	4.278	0.013	0.01	0	41.3	37.4	52.5	130	118	0	34	31
2014	7	19	20	17	0	0.843	-0.098	4.278	0.01	0.007	0	41.3	37.4	54.2	130	118	0	34	31
2014	7	19	20	27	0	0.801	-0.089	4.278	0.01	0.007	0	41.7	37.4	53.8	131	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	19	20	37	0	0.827	-0.062	4.275	0.013	0.01	0	41.7	37.4	51.6	131	118	0	34	31
2014	7	19	20	47	0	0.814	-0.066	4.278	0.01	0.007	0	42.6	37.8	53.8	133	119	0	34	31
2014	7	19	20	57	0	0.85	-0.082	4.275	0.01	0.007	0	42.1	37.4	55.9	132	118	0	34	31
2014	7	19	21	7	0	0.86	-0.049	4.275	0.01	0.007	0	42.1	37	58	131	117	0	33	31
2014	7	19	21	17	0	0.827	-0.112	4.278	0.01	0.007	0	41.3	36.1	62.8	130	116	0	34	32
2014	7	19	21	27	0	0.837	-0.052	4.275	0.01	0.007	0	41.3	36.5	58.5	130	116	0	34	31
2014	7	19	21	37	0	0.804	-0.059	4.278	0.01	0.007	0	41.3	36.1	55.5	130	116	0	34	32
2014	7	19	21	47	0	0.843	-0.082	4.278	0.01	0.007	0	41.3	36.1	53.8	130	115	0	34	31
2014	7	19	21	57	0	0.827	-0.059	4.281	0.01	0.007	0	41.3	36.5	59.3	130	116	0	34	31
2014	7	19	22	7	0	0.827	-0.033	4.285	0.013	0.01	0	40.9	35.7	77.8	129	115	0	34	32
2014	7	19	22	17	0	0.879	-0.049	4.285	0.013	0.01	0	40.9	36.1	78.3	129	115	0	34	31
2014	7	19	22	27	0	0.843	-0.066	4.285	0.01	0.007	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	19	22	37	0	0.837	-0.098	4.285	0.013	0.01	0	40.9	36.1	78.7	129	115	0	34	31
2014	7	19	22	47	0	0.886	-0.092	4.285	0.01	0.007	0	40.4	35.3	78.3	128	114	0	34	32
2014	7	19	22	57	0	0.853	-0.102	4.285	0.013	0.01	0	40.4	35.7	77.4	128	114	0	34	31
2014	7	19	23	7	0	0.86	-0.082	4.285	0.01	0.007	0	40.9	36.1	78.3	128	115	0	33	31
2014	7	19	23	17	0	0.846	-0.085	4.285	0.01	0.007	0	40.4	36.1	76.5	128	115	0	34	31
2014	7	19	23	27	0	0.869	-0.098	4.285	0.01	0.007	0	40.9	36.1	77.4	129	115	0	34	31
2014	7	19	23	37	0	0.846	-0.108	4.285	0.016	0.013	0	40.4	35.7	74.8	128	114	0	34	31
2014	7	19	23	47	0	0.892	-0.079	4.285	0.01	0.007	0	40.9	35.7	78.7	129	115	0	34	32
2014	7	19	23	57	0	0.879	-0.069	4.285	0.01	0.007	0	40.4	35.3	77	128	114	0	34	32
2014	7	20	0	7	0	0.846	-0.062	4.285	0.013	0.01	0	40.4	35.3	76.5	128	114	0	34	32
2014	7	20	0	17	0	0.846	-0.115	4.285	0.01	0.007	0	40.4	35.3	77.8	128	114	0	34	32
2014	7	20	0	27	0	0.846	-0.059	4.285	0.01	0.007	0	40.9	36.1	79.1	129	115	0	34	31
2014	7	20	0	37	0	0.843	-0.049	4.285	0.01	0.007	0	40.9	36.1	78.7	129	115	0	34	31
2014	7	20	0	47	0	0.846	-0.052	4.288	0.013	0.01	0	40.9	36.1	81.3	129	115	0	34	31
2014	7	20	0	57	0	0.843	-0.072	4.288	0.013	0.01	0	40.9	35.7	82.1	129	115	0	34	32
2014	7	20	1	7	0	0.856	-0.112	4.288	0.013	0.01	0	40	36.1	80.4	128	115	0	35	31
2014	7	20	1	17	0	0.85	-0.062	4.288	0.01	0.007	0	41.3	36.1	80.8	130	115	0	34	31
2014	7	20	1	27	0	0.889	-0.072	4.288	0.01	0.007	0	41.3	36.1	80.8	130	116	0	34	32
2014	7	20	1	37	0	0.879	-0.059	4.288	0.01	0.007	0	40.9	36.5	80.4	129	116	0	34	31
2014	7	20	1	47	0	0.869	-0.072	4.288	0.01	0.007	0	40.9	36.5	80	129	116	0	34	31
2014	7	20	1	57	0	0.866	-0.049	4.288	0.01	0.007	0	40.9	36.1	80.8	129	116	0	34	32
2014	7	20	2	7	0	0.846	-0.098	4.288	0.013	0.01	0	40.9	36.5	80.4	129	116	0	34	31
2014	7	20	2	17	0	0.873	-0.079	4.288	0.01	0.007	0	41.3	36.1	80.4	130	116	0	34	32
2014	7	20	2	27	0	0.856	-0.046	4.288	0.01	0.007	0	40.9	36.5	80.4	129	116	0	34	31
2014	7	20	2	37	0	0.902	-0.079	4.288	0.01	0.007	0	41.3	36.5	80	130	116	0	34	31
2014	7	20	2	47	0	0.843	-0.089	4.288	0.01	0.007	0	41.3	36.1	79.1	130	116	0	34	32
2014	7	20	2	57	0	0.86	-0.033	4.288	0.01	0.007	0	41.7	37	79.6	131	117	0	34	31
2014	7	20	3	7	0	0.869	-0.115	4.288	0.01	0.007	0	41.7	37	80	131	117	0	34	31
2014	7	20	3	17	0	0.886	-0.082	4.288	0.01	0.007	0	41.7	36.5	80	131	117	0	34	32
2014	7	20	3	27	0	0.909	-0.072	4.288	0.01	0.007	0	41.7	37	80.4	131	117	0	34	31
2014	7	20	3	37	0	0.896	-0.108	4.288	0.01	0.007	0	41.7	37	80.8	131	117	0	34	31
2014	7	20	3	47	0	0.879	-0.079	4.288	0.01	0.007	0	41.3	37	80.4	131	117	0	35	31
2014	7	20	3	57	0	0.837	-0.085	4.288	0.01	0.007	0	41.7	37	80.8	132	118	0	35	32
2014	7	20	4	7	0	0.892	-0.095	4.288	0.01	0.007	0	42.1	36.5	80.8	131	117	0	33	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	4	17	0	0.879	-0.092	4.288	0.01	0.007	0	41.7	36.5	80.8	131	117	0	34	32
2014	7	20	4	27	0	0.912	-0.043	4.288	0.01	0.007	0	41.7	37	80.4	131	118	0	34	32
2014	7	20	4	37	0	0.909	-0.072	4.288	0.013	0.01	0	42.1	37	80.4	132	118	0	34	32
2014	7	20	4	47	0	0.846	-0.059	4.288	0.01	0.007	0	42.1	37	80	132	118	0	34	32
2014	7	20	4	57	0	0.869	-0.062	4.288	0.01	0.007	0	41.7	37.4	80.4	131	118	0	34	31
2014	7	20	5	7	0	0.866	-0.059	4.288	0.013	0.01	0	42.1	37	80.8	132	118	0	34	32
2014	7	20	5	17	0	0.853	-0.062	4.288	0.016	0.013	0	42.1	37	75.3	132	118	0	34	32
2014	7	20	5	27	0	0.899	-0.033	4.291	0.01	0.007	0	42.1	37	80.4	132	118	0	34	32
2014	7	20	5	37	0	0.863	-0.059	4.291	0.01	0.007	0	42.1	37.4	80.4	132	118	0	34	31
2014	7	20	5	47	0	0.922	-0.049	4.291	0.013	0.01	0	42.1	37	80	132	118	0	34	32
2014	7	20	5	57	0	0.866	-0.049	4.291	0.013	0.01	0	42.1	37	80.4	132	118	0	34	32
2014	7	20	6	7	0	0.869	-0.112	4.288	0.01	0.007	0	41.3	37.4	80	131	118	0	35	31
2014	7	20	6	17	0	0.886	-0.039	4.291	0.01	0.007	0	41.7	37	79.6	131	118	0	34	32
2014	7	20	6	27	0	0.879	-0.069	4.288	0.01	0.007	0	41.7	36.5	78.7	131	117	0	34	32
2014	7	20	6	37	0	0.863	-0.079	4.288	0.013	0.01	0	41.3	37	79.6	131	117	0	35	31
2014	7	20	6	47	0	0.837	-0.062	4.288	0.016	0.013	0	41.7	37	77.4	131	117	0	34	31
2014	7	20	6	57	0	0.85	-0.046	4.288	0.013	0.01	0	42.6	37.4	52.5	132	118	0	33	31
2014	7	20	7	7	0	0.866	-0.085	4.288	0.01	0.007	0	47.7	42.6	62.4	145	131	0	34	32
2014	7	20	7	17	0	0.883	-0.043	4.291	0.01	0.007	0	48.6	43.9	71.8	147	133	0	34	31
2014	7	20	7	27	0	0.922	-0.043	4.291	0.01	0.007	0	47.3	42.6	74.4	144	130	0	34	31
2014	7	20	7	37	0	0.866	-0.046	4.291	0.01	0.007	0	46	41.3	73.5	141	127	0	34	31
2014	7	20	7	47	0	0.873	-0.052	4.291	0.01	0.007	0	44.7	39.6	74	138	124	0	34	32
2014	7	20	7	57	0	0.912	-0.052	4.291	0.01	0.007	0	43.4	39.1	74.8	136	123	0	35	32
2014	7	20	8	7	0	0.873	-0.059	4.291	0.01	0.007	0	43.4	38.3	74.8	135	121	0	34	32
2014	7	20	8	17	0	0.909	-0.056	4.291	0.01	0.007	0	42.6	37.8	75.3	133	120	0	34	32
2014	7	20	8	27	0	0.902	-0.072	4.291	0.01	0.007	0	42.6	37.4	76.1	133	119	0	34	32
2014	7	20	8	37	0	0.866	-0.033	4.291	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	20	8	47	0	0.896	-0.095	4.291	0.01	0.007	0	42.1	37.8	76.1	132	120	0	34	32
2014	7	20	8	57	0	0.902	-0.062	4.295	0.01	0.007	0	42.6	38.3	73.5	133	120	0	34	31
2014	7	20	9	7	0	0.896	-0.085	4.295	0.01	0.007	0	42.1	37.8	74.4	132	119	0	34	31
2014	7	20	9	17	0	0.896	-0.089	4.295	0.01	0.007	0	42.1	37.4	71	132	119	0	34	32
2014	7	20	9	27	0	0.892	-0.056	4.295	0.01	0.007	0	42.1	37	72.7	132	118	0	34	32
2014	7	20	9	37	0	0.823	-0.069	4.295	0.01	0.007	0	41.7	37.8	70.1	131	119	0	34	31
2014	7	20	9	47	0	0.883	-0.059	4.295	0.013	0.01	0	42.1	37.4	72.2	131	118	0	33	31
2014	7	20	9	57	0	0.856	-0.059	4.295	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	20	10	7	0	0.856	-0.049	4.295	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	20	10	17	0	0.853	-0.095	4.295	0.01	0.007	0	41.3	37	75.7	130	118	0	34	32
2014	7	20	10	27	0	0.863	-0.072	4.295	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	20	10	37	0	0.856	-0.079	4.295	0.01	0.007	0	41.7	37	75.3	130	118	0	33	32
2014	7	20	10	47	0	0.883	-0.066	4.295	0.01	0.007	0	41.3	37	75.7	130	118	0	34	32
2014	7	20	10	57	0	0.883	-0.075	4.295	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	20	11	7	0	0.85	-0.089	4.295	0.01	0.007	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	20	11	17	0	0.86	-0.082	4.295	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	20	11	27	0	0.846	-0.059	4.295	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	20	11	37	0	0.866	-0.066	4.295	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	20	11	47	0	0.889	-0.079	4.295	0.013	0.01	0	41.3	36.5	77.4	129	116	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	11	57	0	0.823	-0.082	4.295	0.01	0.007	0	41.3	36.5	77	130	117	0	34	32
2014	7	20	12	7	0	0.925	-0.095	4.295	0.013	0.01	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	20	12	17	0	0.853	-0.082	4.295	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	20	12	27	0	0.853	-0.066	4.295	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	20	12	37	0	0.866	-0.085	4.295	0.01	0.007	0	40.9	36.1	77.4	128	115	0	33	31
2014	7	20	12	47	0	0.846	-0.102	4.295	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	20	12	57	0	0.843	-0.049	4.291	0.01	0.007	0	40	36.1	76.1	128	115	0	35	31
2014	7	20	13	7	0	0.906	-0.059	4.295	0.013	0.01	0	40.9	36.5	77	129	117	0	34	32
2014	7	20	13	17	0	0.843	-0.082	4.295	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	20	13	27	0	0.869	-0.079	4.295	0.01	0.007	0	40.9	36.1	75.3	129	116	0	34	32
2014	7	20	13	37	0	0.876	-0.082	4.295	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	20	13	47	0	0.886	-0.092	4.295	0.013	0.01	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	20	13	57	0	0.876	-0.049	4.295	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	20	14	7	0	0.86	-0.098	4.295	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	20	14	17	0	0.833	-0.062	4.295	0.01	0.007	0	40.9	37	77.4	129	117	0	34	31
2014	7	20	14	27	0	0.853	-0.095	4.295	0.01	0.007	0	40.4	36.1	78.7	128	115	0	34	31
2014	7	20	14	37	0	0.837	-0.036	4.295	0.01	0.007	0	40.9	36.1	78.7	129	116	0	34	32
2014	7	20	14	47	0	0.899	-0.072	4.295	0.01	0.007	0	40.9	36.5	77.8	129	116	0	34	31
2014	7	20	14	57	0	0.883	-0.082	4.291	0.013	0.01	0	40.9	37	61.1	129	117	0	34	31
2014	7	20	15	7	0	0.846	-0.085	4.295	0.01	0.007	0	40.9	36.5	79.1	129	116	0	34	31
2014	7	20	15	17	0	0.853	-0.098	4.295	0.01	0.007	0	40.4	36.1	77	128	115	0	34	31
2014	7	20	15	27	0	0.804	-0.092	4.295	0.01	0.007	0	40.4	36.1	79.1	128	115	0	34	31
2014	7	20	15	37	0	0.876	-0.046	4.295	0.01	0.007	0	40.4	36.1	75.7	128	115	0	34	31
2014	7	20	15	47	0	0.869	-0.098	4.295	0.01	0.007	0	40.4	36.1	79.1	128	115	0	34	31
2014	7	20	15	57	0	0.906	-0.066	4.295	0.01	0.007	0	41.3	37	80	129	117	0	33	31
2014	7	20	16	7	0	0.827	-0.098	4.291	0.01	0.007	0	41.3	37	64.5	129	117	0	33	31
2014	7	20	16	17	0	0.823	-0.115	4.288	0.01	0.007	0	44.7	38.3	43.9	138	120	0	34	31
2014	7	20	16	27	0	0.83	-0.102	4.288	0.01	0.007	0	45.6	38.3	45.2	140	120	0	34	31
2014	7	20	16	37	0	0.84	-0.138	4.291	0.01	0.007	0	45.2	37.8	40.9	138	120	0	33	32
2014	7	20	16	47	0	0.82	-0.118	4.288	0.01	0.007	0	43.9	38.7	54.6	136	122	0	34	32
2014	7	20	16	57	0	0.856	-0.125	4.288	0.01	0.007	0	44.7	39.6	47.3	138	124	0	34	32
2014	7	20	17	7	0	0.81	-0.131	4.288	0.016	0.013	0	43.9	38.7	51.6	136	121	0	34	31
2014	7	20	17	17	0	0.794	-0.095	4.285	0.01	0.007	0	47.3	43	41.7	144	131	0	34	31
2014	7	20	17	27	0	0.804	-0.125	4.288	0.01	0.007	0	41.7	37.4	47.7	131	118	0	34	31
2014	7	20	17	37	0	0.794	-0.154	4.288	0.01	0.007	0	43.9	39.6	51.6	136	123	0	34	31
2014	7	20	17	47	0	0.781	-0.135	4.291	0.01	0.007	0	43	37	62.4	133	118	0	33	32
2014	7	20	17	57	0	0.761	-0.138	4.285	0.01	0.007	0	44.3	38.7	52.9	137	122	0	34	32
2014	7	20	18	7	0	0.758	-0.141	4.285	0.013	0.01	0	45.6	42.6	44.7	139	130	0	33	31
2014	7	20	18	17	0	0.787	-0.148	4.281	0.013	0.01	0	46.4	41.3	46	142	128	0	34	32
2014	7	20	18	27	0	0.801	-0.144	4.288	0.01	0.007	0	45.2	39.6	49.9	138	123	0	33	31
2014	7	20	18	37	0	0.748	-0.135	4.285	0.01	0.007	0	43.9	40	49	136	124	0	34	31
2014	7	20	18	47	0	0.863	-0.092	4.285	0.013	0.01	0	40	37	49	127	117	0	34	31
2014	7	20	18	57	0	0.827	-0.082	4.288	0.01	0.007	0	38.7	36.1	62.8	124	116	0	34	32
2014	7	20	19	7	0	0.807	-0.079	4.288	0.01	0.007	0	39.1	37	76.1	125	117	0	34	31
2014	7	20	19	17	0	0.873	-0.105	4.288	0.013	0.01	0	38.7	36.5	77	124	116	0	34	31
2014	7	20	19	27	0	0.86	-0.095	4.288	0.01	0.007	0	39.1	37	77.4	125	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	20	19	37	0	0.84	-0.108	4.288	0.01	0.007	0	39.1	37	77	125	117	0	34	31
2014	7	20	19	47	0	0.856	-0.108	4.288	0.01	0.007	0	39.1	37	77	125	117	0	34	31
2014	7	20	19	57	0	0.856	-0.085	4.288	0.01	0.007	0	39.1	36.5	77.8	125	117	0	34	32
2014	7	20	20	7	0	0.866	-0.066	4.288	0.01	0.007	0	39.6	36.5	78.3	126	117	0	34	32
2014	7	20	20	17	0	0.876	-0.079	4.288	0.01	0.007	0	39.6	37	77.8	126	118	0	34	32
2014	7	20	20	27	0	0.86	-0.082	4.288	0.01	0.007	0	39.6	37	75.3	126	118	0	34	32
2014	7	20	20	37	0	0.899	-0.098	4.288	0.01	0.007	0	39.1	37	73.5	125	117	0	34	31
2014	7	20	20	47	0	0.889	-0.039	4.288	0.013	0.01	0	39.1	37	74.4	125	117	0	34	31
2014	7	20	20	57	0	0.86	-0.049	4.288	0.01	0.007	0	39.1	37	75.7	125	117	0	34	31
2014	7	20	21	7	0	0.866	-0.079	4.288	0.01	0.007	0	38.7	36.5	76.5	124	116	0	34	31
2014	7	20	21	17	0	0.84	-0.092	4.291	0.01	0.007	0	38.3	36.5	77.4	123	116	0	34	31
2014	7	20	21	27	0	0.86	-0.052	4.288	0.013	0.01	0	38.3	36.1	77.8	123	115	0	34	31
2014	7	20	21	37	0	0.883	-0.112	4.288	0.01	0.007	0	38.3	36.1	77	123	115	0	34	31
2014	7	20	21	47	0	0.883	-0.072	4.288	0.01	0.007	0	38.3	35.7	70.5	123	114	0	34	31
2014	7	20	21	57	0	0.827	-0.062	4.291	0.01	0.007	0	38.3	36.1	78.3	123	115	0	34	31
2014	7	20	22	7	0	0.886	-0.075	4.291	0.01	0.007	0	37.8	35.7	77.8	122	114	0	34	31
2014	7	20	22	17	0	0.879	-0.125	4.291	0.01	0.007	0	38.7	35.7	77.8	123	114	0	33	31
2014	7	20	22	27	0	0.856	-0.098	4.291	0.01	0.007	0	38.3	36.1	78.3	123	115	0	34	31
2014	7	20	22	37	0	0.883	-0.128	4.288	0.01	0.007	0	37.8	35.7	77.8	122	114	0	34	31
2014	7	20	22	47	0	0.837	-0.075	4.291	0.01	0.007	0	38.3	36.1	77.8	123	115	0	34	31
2014	7	20	22	57	0	0.84	-0.079	4.291	0.01	0.007	0	38.3	35.7	77	122	114	0	33	31
2014	7	20	23	7	0	0.879	-0.079	4.288	0.01	0.007	0	38.3	35.3	77.8	122	114	0	33	32
2014	7	20	23	17	0	0.869	-0.105	4.288	0.01	0.007	0	37.8	36.1	77	122	115	0	34	31
2014	7	20	23	27	0	0.869	-0.079	4.288	0.01	0.007	0	38.3	36.1	77.4	123	115	0	34	31
2014	7	20	23	37	0	0.866	-0.089	4.288	0.01	0.007	0	37.8	35.7	77.4	122	114	0	34	31
2014	7	20	23	47	0	0.915	-0.089	4.288	0.01	0.007	0	37.8	35.7	77.8	122	114	0	34	31
2014	7	20	23	57	0	0.886	-0.085	4.288	0.013	0.01	0	37.8	35.7	77	122	114	0	34	31
2014	7	21	0	7	0	0.856	-0.079	4.288	0.01	0.007	0	37.8	35.3	77.4	122	114	0	34	32
2014	7	21	0	17	0	0.869	-0.092	4.288	0.01	0.007	0	37.8	35.3	77.4	122	114	0	34	32
2014	7	21	0	27	0	0.886	-0.098	4.288	0.013	0.01	0	37.8	35.7	77	122	114	0	34	31
2014	7	21	0	37	0	0.883	-0.049	4.288	0.013	0.01	0	38.3	35.3	76.1	123	114	0	34	32
2014	7	21	0	47	0	0.869	-0.098	4.288	0.013	0.01	0	37.8	35.7	76.5	122	114	0	34	31
2014	7	21	0	57	0	0.853	-0.098	4.288	0.01	0.007	0	37.8	35.7	77.8	122	114	0	34	31
2014	7	21	1	7	0	0.879	-0.075	4.288	0.01	0.007	0	38.3	35.7	77	123	115	0	34	32
2014	7	21	1	17	0	0.876	-0.066	4.288	0.016	0.013	0	38.3	36.1	77	123	115	0	34	31
2014	7	21	1	27	0	0.82	-0.056	4.291	0.01	0.007	0	38.7	36.1	75.3	124	116	0	34	32
2014	7	21	1	37	0	0.873	-0.069	4.288	0.01	0.007	0	38.3	36.1	76.1	123	115	0	34	31
2014	7	21	1	47	0	0.915	-0.089	4.288	0.013	0.01	0	38.3	36.1	76.5	123	115	0	34	31
2014	7	21	1	57	0	0.879	-0.062	4.288	0.01	0.007	0	38.3	36.1	77	123	116	0	34	32
2014	7	21	2	7	0	0.866	-0.085	4.291	0.01	0.007	0	38.3	36.5	77	123	116	0	34	31
2014	7	21	2	17	0	0.85	-0.062	4.291	0.01	0.007	0	38.7	36.1	76.5	124	116	0	34	32
2014	7	21	2	27	0	0.85	-0.052	4.291	0.01	0.007	0	38.7	36.5	76.5	124	116	0	34	31
2014	7	21	2	37	0	0.909	-0.095	4.291	0.01	0.007	0	38.7	36.1	76.1	124	116	0	34	32
2014	7	21	2	47	0	0.856	-0.098	4.291	0.01	0.007	0	38.7	36.5	76.5	124	116	0	34	31
2014	7	21	2	57	0	0.876	-0.089	4.291	0.013	0.01	0	38.7	36.1	77	124	116	0	34	32
2014	7	21	3	7	0	0.879	-0.092	4.291	0.01	0.007	0	38.7	36.1	76.5	124	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	3	17	0	0.873	-0.075	4.291	0.01	0.007	0	38.7	36.5	76.1	124	116	0	34	31
2014	7	21	3	27	0	0.863	-0.092	4.291	0.01	0.007	0	38.7	36.1	76.1	124	116	0	34	32
2014	7	21	3	37	0	0.912	-0.085	4.291	0.01	0.007	0	38.7	36.5	76.1	124	117	0	34	32
2014	7	21	3	47	0	0.876	-0.066	4.291	0.01	0.007	0	38.7	37	76.1	124	117	0	34	31
2014	7	21	3	57	0	0.853	-0.115	4.291	0.013	0.01	0	38.3	36.5	76.1	124	116	0	35	31
2014	7	21	4	7	0	0.846	-0.072	4.291	0.013	0.01	0	38.3	37	76.1	124	117	0	35	31
2014	7	21	4	17	0	0.856	-0.069	4.291	0.013	0.01	0	38.7	37	76.1	124	117	0	34	31
2014	7	21	4	27	0	0.866	-0.079	4.291	0.01	0.007	0	39.1	37	76.1	125	117	0	34	31
2014	7	21	4	37	0	0.883	-0.092	4.291	0.013	0.01	0	39.1	37	75.3	125	117	0	34	31
2014	7	21	4	47	0	0.883	-0.069	4.291	0.01	0.007	0	39.6	36.5	74.8	126	117	0	34	32
2014	7	21	4	57	0	0.853	-0.039	4.291	0.01	0.007	0	39.6	37	75.7	126	118	0	34	32
2014	7	21	5	7	0	0.84	-0.062	4.291	0.01	0.007	0	40	37	75.7	127	118	0	34	32
2014	7	21	5	17	0	0.846	-0.102	4.291	0.013	0.01	0	40	37	75.3	127	118	0	34	32
2014	7	21	5	27	0	0.869	-0.072	4.291	0.01	0.007	0	40	37.4	74.4	127	119	0	34	32
2014	7	21	5	37	0	0.846	-0.069	4.291	0.01	0.007	0	40.4	37.8	74.4	128	119	0	34	31
2014	7	21	5	47	0	0.873	-0.092	4.291	0.01	0.007	0	40.4	37.4	74.4	128	119	0	34	32
2014	7	21	5	57	0	0.879	-0.049	4.291	0.01	0.007	0	40.4	37.8	73.1	128	119	0	34	31
2014	7	21	6	7	0	0.856	-0.085	4.291	0.01	0.007	0	40	37.4	74.4	127	118	0	34	31
2014	7	21	6	17	0	0.909	-0.079	4.291	0.01	0.007	0	40	37.4	74	127	118	0	34	31
2014	7	21	6	27	0	0.866	-0.075	4.291	0.01	0.007	0	39.6	37	73.5	126	117	0	34	31
2014	7	21	6	37	0	0.886	-0.082	4.295	0.01	0.007	0	39.6	36.5	74	126	117	0	34	32
2014	7	21	6	47	0	0.889	-0.108	4.295	0.01	0.007	0	39.6	37	72.7	126	118	0	34	32
2014	7	21	6	57	0	0.843	-0.052	4.295	0.01	0.007	0	39.6	36.5	72.7	126	117	0	34	32
2014	7	21	7	7	0	0.863	-0.079	4.298	0.01	0.007	0	40	37	74	126	118	0	33	32
2014	7	21	7	17	0	0.889	-0.085	4.298	0.01	0.007	0	38.7	36.5	73.1	125	117	0	35	32
2014	7	21	7	27	0	0.886	-0.079	4.298	0.01	0.007	0	39.1	36.5	72.7	125	117	0	34	32
2014	7	21	7	37	0	0.837	-0.079	4.298	0.01	0.007	0	39.1	37.4	72.7	126	118	0	35	31
2014	7	21	7	47	0	0.892	-0.069	4.301	0.01	0.007	0	39.1	36.5	73.5	125	117	0	34	32
2014	7	21	7	57	0	0.86	-0.069	4.301	0.01	0.007	0	39.1	36.1	74	125	116	0	34	32
2014	7	21	8	7	0	0.883	-0.085	4.304	0.01	0.007	0	39.1	37	73.5	125	117	0	34	31
2014	7	21	8	17	0	0.915	-0.079	4.301	0.013	0.01	0	39.1	37	73.1	125	117	0	34	31
2014	7	21	8	27	0	0.892	-0.079	4.304	0.01	0.007	0	39.1	36.5	73.5	125	117	0	34	32
2014	7	21	8	37	0	0.86	-0.072	4.301	0.01	0.007	0	38.3	36.1	73.1	124	116	0	35	32
2014	7	21	8	47	0	0.873	-0.092	4.304	0.013	0.01	0	39.1	36.5	74	125	117	0	34	32
2014	7	21	8	57	0	0.915	-0.095	4.304	0.01	0.007	0	38.7	36.5	71.8	125	117	0	35	32
2014	7	21	9	7	0	0.873	-0.066	4.301	0.01	0.007	0	39.1	36.5	70.5	125	117	0	34	32
2014	7	21	9	17	0	0.892	-0.089	4.304	0.01	0.007	0	39.6	37	72.7	126	118	0	34	32
2014	7	21	9	27	0	0.876	-0.052	4.301	0.01	0.007	0	39.6	37.4	72.7	126	118	0	34	31
2014	7	21	9	37	0	0.866	-0.075	4.301	0.013	0.01	0	39.1	36.5	72.7	125	117	0	34	32
2014	7	21	9	47	0	0.86	-0.072	4.301	0.01	0.007	0	39.6	37	72.7	126	118	0	34	32
2014	7	21	9	57	0	0.876	-0.049	4.301	0.01	0.007	0	39.1	37.4	72.7	126	119	0	35	32
2014	7	21	10	7	0	0.873	-0.092	4.301	0.01	0.007	0	39.6	37	73.1	126	118	0	34	32
2014	7	21	10	17	0	0.892	-0.095	4.298	0.01	0.007	0	39.6	37	69.2	126	118	0	34	32
2014	7	21	10	27	0	0.925	-0.075	4.298	0.01	0.007	0	39.1	37	72.2	126	118	0	35	32
2014	7	21	10	37	0	0.85	-0.102	4.295	0.01	0.007	0	39.1	36.5	72.2	125	117	0	34	32
2014	7	21	10	47	0	0.853	-0.089	4.295	0.013	0.01	0	39.6	37	69.2	126	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	10	57	0	0.84	-0.069	4.295	0.013	0.01	0	40	37	70.5	126	118	0	33	32
2014	7	21	11	7	0	0.833	-0.118	4.295	0.01	0.007	0	39.6	37.4	57.2	126	118	0	34	31
2014	7	21	11	17	0	0.853	-0.112	4.295	0.01	0.007	0	39.6	36.5	62.4	126	117	0	34	32
2014	7	21	11	27	0	0.843	-0.128	4.295	0.01	0.007	0	39.1	37	56.3	125	117	0	34	31
2014	7	21	11	37	0	0.85	-0.102	4.295	0.01	0.007	0	39.1	36.5	61.5	126	117	0	35	32
2014	7	21	11	47	0	0.846	-0.125	4.295	0.01	0.007	0	39.6	36.5	58.9	126	117	0	34	32
2014	7	21	11	57	0	0.85	-0.112	4.291	0.01	0.007	0	39.1	36.5	65.4	125	117	0	34	32
2014	7	21	12	7	0	0.856	-0.075	4.295	0.013	0.01	0	39.1	37	55.9	125	117	0	34	31
2014	7	21	12	17	0	0.843	-0.095	4.295	0.01	0.007	0	39.6	36.5	56.3	126	117	0	34	32
2014	7	21	12	27	0	0.827	-0.066	4.295	0.013	0.01	0	40	37.8	58.9	127	119	0	34	31
2014	7	21	12	37	0	0.863	-0.079	4.291	0.013	0.01	0	40	37.4	65.8	126	118	0	33	31
2014	7	21	12	47	0	0.863	-0.075	4.291	0.01	0.007	0	39.1	36.5	63.6	125	117	0	34	32
2014	7	21	12	57	0	0.82	-0.085	4.295	0.01	0.007	0	39.1	37	55.9	125	117	0	34	31
2014	7	21	13	7	0	0.84	-0.082	4.291	0.01	0.007	0	39.1	37	62.8	125	117	0	34	31
2014	7	21	13	17	0	0.817	-0.046	4.295	0.01	0.007	0	39.6	37	57.6	126	117	0	34	31
2014	7	21	13	27	0	0.853	-0.075	4.295	0.016	0.013	0	39.6	36.5	55	126	117	0	34	32
2014	7	21	13	37	0	0.856	-0.079	4.291	0.013	0.01	0	39.6	36.5	56.3	126	117	0	34	32
2014	7	21	13	47	0	0.814	-0.102	4.295	0.013	0.01	0	40	37	55.5	126	117	0	33	31
2014	7	21	13	57	0	0.863	-0.085	4.295	0.013	0.01	0	40	36.5	55.9	126	117	0	33	32
2014	7	21	14	7	0	0.801	-0.079	4.291	0.01	0.007	0	39.6	36.5	55.9	126	117	0	34	32
2014	7	21	14	17	0	0.837	-0.075	4.291	0.01	0.007	0	39.6	37	57.6	126	117	0	34	31
2014	7	21	14	27	0	0.846	-0.069	4.291	0.016	0.016	0	38.7	36.5	60.6	124	116	0	34	31
2014	7	21	14	37	0	0.883	-0.082	4.291	0.01	0.007	0	39.6	37.4	58.9	126	118	0	34	31
2014	7	21	14	47	0	0.807	-0.085	4.291	0.01	0.007	0	39.1	36.5	59.8	125	117	0	34	32
2014	7	21	14	57	0	0.814	-0.098	4.291	0.01	0.007	0	39.1	37	58	125	117	0	34	31
2014	7	21	15	7	0	0.833	-0.072	4.291	0.013	0.01	0	39.1	37	58.5	125	117	0	34	31
2014	7	21	15	17	0	0.873	-0.079	4.291	0.01	0.007	0	39.1	36.5	60.6	125	117	0	34	32
2014	7	21	15	27	0	0.81	-0.112	4.291	0.01	0.007	0	39.6	37.4	51.6	126	118	0	34	31
2014	7	21	15	37	0	0.837	-0.098	4.288	0.013	0.01	0	39.6	37	56.8	126	118	0	34	32
2014	7	21	15	47	0	0.83	-0.092	4.288	0.01	0.007	0	39.6	37.4	55.5	126	118	0	34	31
2014	7	21	15	57	0	0.856	-0.092	4.288	0.01	0.007	0	39.6	37	52.9	126	118	0	34	32
2014	7	21	16	7	0	0.807	-0.089	4.288	0.01	0.007	0	40	37.4	54.6	127	119	0	34	32
2014	7	21	16	17	0	0.889	-0.046	4.288	0.01	0.007	0	40.4	37.4	55.5	128	119	0	34	32
2014	7	21	16	27	0	0.823	-0.072	4.285	0.01	0.007	0	40.9	38.3	55.9	128	120	0	33	31
2014	7	21	16	37	0	0.83	-0.069	4.288	0.01	0.007	0	40.4	37.8	56.3	128	120	0	34	32
2014	7	21	16	47	0	0.833	-0.105	4.288	0.01	0.007	0	40.4	37.4	57.2	128	119	0	34	32
2014	7	21	16	57	0	0.797	-0.052	4.285	0.01	0.007	0	40	37	56.3	127	118	0	34	32
2014	7	21	17	7	0	0.823	-0.066	4.285	0.016	0.013	0	39.6	37.4	57.2	126	118	0	34	31
2014	7	21	17	17	0	0.833	-0.105	4.285	0.013	0.01	0	40	37	54.2	127	118	0	34	32
2014	7	21	17	27	0	0.83	-0.069	4.285	0.013	0.01	0	40.4	37.4	54.6	128	119	0	34	32
2014	7	21	17	37	0	0.869	-0.075	4.285	0.01	0.007	0	40	37.4	52.9	127	119	0	34	32
2014	7	21	17	47	0	0.817	-0.072	4.285	0.013	0.01	0	40.4	37.4	56.3	127	118	0	33	31
2014	7	21	17	57	0	0.791	-0.085	4.285	0.01	0.007	0	40	37.8	56.8	127	119	0	34	31
2014	7	21	18	7	0	0.81	-0.105	4.281	0.01	0.007	0	40	37.4	54.2	127	118	0	34	31
2014	7	21	18	17	0	0.827	-0.079	4.281	0.01	0.007	0	40	37.8	55	127	119	0	34	31
2014	7	21	18	27	0	0.843	-0.089	4.281	0.01	0.007	0	40	37.4	53.8	127	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	21	18	37	0	0.837	-0.062	4.281	0.013	0.01	0	40	37.8	54.6	127	119	0	34	31
2014	7	21	18	47	0	0.856	-0.079	4.281	0.01	0.007	0	40.9	37.8	54.2	128	119	0	33	31
2014	7	21	18	57	0	0.856	-0.105	4.281	0.01	0.007	0	40.4	37.4	53.8	127	119	0	33	32
2014	7	21	19	7	0	0.86	-0.079	4.281	0.016	0.013	0	40.9	37.4	55.5	129	119	0	34	32
2014	7	21	19	17	0	0.83	-0.102	4.281	0.01	0.007	0	41.3	37.8	53.3	130	120	0	34	32
2014	7	21	19	27	0	0.856	-0.085	4.281	0.01	0.007	0	41.7	37.8	55.9	130	120	0	33	32
2014	7	21	19	37	0	0.863	-0.085	4.281	0.01	0.007	0	41.7	37.8	55.5	130	120	0	33	32
2014	7	21	19	47	0	0.837	-0.112	4.281	0.013	0.01	0	41.7	37.8	55.9	131	120	0	34	32
2014	7	21	19	57	0	0.837	-0.105	4.281	0.01	0.007	0	41.7	37.8	55.9	131	120	0	34	32
2014	7	21	20	7	0	0.846	-0.092	4.281	0.01	0.007	0	42.1	38.3	58.9	131	120	0	33	31
2014	7	21	20	17	0	0.81	-0.098	4.281	0.01	0.007	0	41.7	37.8	57.2	131	120	0	34	32
2014	7	21	20	27	0	0.833	-0.095	4.281	0.01	0.007	0	41.3	38.3	56.8	130	120	0	34	31
2014	7	21	20	37	0	0.86	-0.066	4.281	0.013	0.01	0	41.3	37.8	57.2	130	120	0	34	32
2014	7	21	20	47	0	0.837	-0.108	4.285	0.01	0.007	0	41.7	37.4	59.8	130	119	0	33	32
2014	7	21	20	57	0	0.814	-0.085	4.281	0.016	0.013	0	41.7	38.3	56.8	131	120	0	34	31
2014	7	21	21	7	0	0.837	-0.089	4.281	0.01	0.007	0	41.3	37.4	57.2	130	119	0	34	32
2014	7	21	21	17	0	0.843	-0.082	4.281	0.01	0.007	0	40.9	37.8	59.3	129	119	0	34	31
2014	7	21	21	27	0	0.85	-0.062	4.281	0.01	0.007	0	40.4	37.8	60.2	129	119	0	35	31
2014	7	21	21	37	0	0.837	-0.069	4.285	0.013	0.01	0	40.4	37.4	66.2	128	118	0	34	31
2014	7	21	21	47	0	0.85	-0.121	4.285	0.013	0.01	0	40.4	37	70.5	128	118	0	34	32
2014	7	21	21	57	0	0.804	-0.085	4.281	0.01	0.007	0	40.9	36.5	64.5	128	117	0	33	32
2014	7	21	22	7	0	0.823	-0.082	4.281	0.01	0.007	0	40.4	36.5	56.3	128	117	0	34	32
2014	7	21	22	17	0	0.804	-0.118	4.281	0.01	0.007	0	40.9	37.4	56.8	129	118	0	34	31
2014	7	21	22	27	0	0.85	-0.098	4.285	0.013	0.01	0	40.9	37.8	56.8	129	119	0	34	31
2014	7	21	22	37	0	0.827	-0.098	4.281	0.01	0.007	0	40.9	37.8	55.5	129	119	0	34	31
2014	7	21	22	47	0	0.804	-0.098	4.285	0.01	0.007	0	40.4	37.4	58	128	118	0	34	31
2014	7	21	22	57	0	0.82	-0.092	4.281	0.01	0.007	0	40.9	37	55.5	128	118	0	33	32
2014	7	21	23	7	0	0.837	-0.072	4.285	0.01	0.007	0	40.4	37	57.2	128	117	0	34	31
2014	7	21	23	17	0	0.797	-0.062	4.285	0.01	0.007	0	40.4	37	56.8	128	118	0	34	32
2014	7	21	23	27	0	0.804	-0.082	4.285	0.01	0.007	0	40.9	37.4	56.8	129	118	0	34	31
2014	7	21	23	37	0	0.876	-0.062	4.285	0.01	0.007	0	40.4	37	66.7	128	117	0	34	31
2014	7	21	23	47	0	0.84	-0.069	4.285	0.01	0.007	0	40.4	36.5	74	128	117	0	34	32
2014	7	21	23	57	0	0.866	-0.092	4.285	0.01	0.007	0	40.4	37	61.9	128	117	0	34	31
2014	7	22	0	7	0	0.869	-0.066	4.285	0.013	0.01	0	40	37	62.8	127	117	0	34	31
2014	7	22	0	17	0	0.86	-0.098	4.285	0.01	0.007	0	40	36.1	74	127	116	0	34	32
2014	7	22	0	27	0	0.837	-0.089	4.285	0.013	0.01	0	40	36.1	77.4	127	116	0	34	32
2014	7	22	0	37	0	0.856	-0.049	4.285	0.01	0.007	0	40.4	36.5	77	128	117	0	34	32
2014	7	22	0	47	0	0.863	-0.059	4.285	0.01	0.007	0	40.4	37	77.8	127	117	0	33	31
2014	7	22	0	57	0	0.823	-0.069	4.285	0.01	0.007	0	40	36.5	77	127	117	0	34	32
2014	7	22	1	7	0	0.843	-0.079	4.285	0.01	0.007	0	40	36.5	73.1	127	117	0	34	32
2014	7	22	1	17	0	0.889	-0.075	4.285	0.01	0.007	0	40	36.1	70.5	127	116	0	34	32
2014	7	22	1	27	0	0.85	-0.056	4.285	0.01	0.007	0	40.4	37	77	128	117	0	34	31
2014	7	22	1	37	0	0.876	-0.082	4.285	0.01	0.007	0	40.4	37	76.5	128	117	0	34	31
2014	7	22	1	47	0	0.883	-0.089	4.285	0.01	0.007	0	40	36.5	77	127	116	0	34	31
2014	7	22	1	57	0	0.902	-0.03	4.285	0.013	0.01	0	40.4	36.5	77.4	128	117	0	34	32
2014	7	22	2	7	0	0.869	-0.079	4.288	0.01	0.007	0	40	36.5	77.8	127	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	2	17	0	0.85	-0.069	4.288	0.01	0.007	0	40	36.5	77	127	117	0	34	32
2014	7	22	2	27	0	0.879	-0.043	4.288	0.01	0.007	0	40.4	37.4	77.4	128	118	0	34	31
2014	7	22	2	37	0	0.876	-0.089	4.285	0.013	0.01	0	40	37.4	77.4	128	118	0	35	31
2014	7	22	2	47	0	0.833	-0.069	4.285	0.013	0.01	0	40.4	36.5	75.7	128	117	0	34	32
2014	7	22	2	57	0	0.856	-0.075	4.285	0.01	0.007	0	40.4	37	76.1	127	117	0	33	31
2014	7	22	3	7	0	0.912	-0.085	4.288	0.01	0.007	0	40	37	76.5	127	117	0	34	31
2014	7	22	3	17	0	0.912	-0.079	4.288	0.01	0.007	0	40	37	75.3	127	117	0	34	31
2014	7	22	3	27	0	0.866	-0.056	4.288	0.01	0.007	0	40.4	37.4	76.5	128	118	0	34	31
2014	7	22	3	37	0	0.801	-0.085	4.288	0.013	0.01	0	40.4	37	74.8	128	117	0	34	31
2014	7	22	3	47	0	0.86	-0.072	4.288	0.01	0.007	0	40.4	36.5	76.5	128	117	0	34	32
2014	7	22	3	57	0	0.856	-0.062	4.288	0.01	0.007	0	40.4	37.4	76.5	128	118	0	34	31
2014	7	22	4	7	0	0.869	-0.062	4.288	0.01	0.007	0	40.4	37	77	128	117	0	34	31
2014	7	22	4	17	0	0.896	-0.079	4.288	0.01	0.007	0	40.4	36.5	76.5	128	117	0	34	32
2014	7	22	4	27	0	0.846	-0.062	4.288	0.01	0.007	0	41.3	37.8	74.8	129	119	0	33	31
2014	7	22	4	37	0	0.896	-0.062	4.288	0.01	0.007	0	40.4	37.4	76.5	128	118	0	34	31
2014	7	22	4	47	0	0.853	-0.072	4.288	0.01	0.007	0	40.9	37	76.1	129	118	0	34	32
2014	7	22	4	57	0	0.896	-0.085	4.288	0.01	0.007	0	40.9	37.4	75.7	129	119	0	34	32
2014	7	22	5	7	0	0.869	-0.066	4.288	0.01	0.007	0	40	37.4	75.3	128	118	0	35	31
2014	7	22	5	17	0	0.86	-0.075	4.288	0.01	0.007	0	40.4	37.8	75.3	129	119	0	35	31
2014	7	22	5	27	0	0.85	-0.062	4.288	0.013	0.01	0	41.3	37.8	75.7	130	120	0	34	32
2014	7	22	5	37	0	0.879	-0.079	4.288	0.01	0.007	0	41.3	37.8	74.4	130	120	0	34	32
2014	7	22	5	47	0	0.866	-0.075	4.288	0.013	0.01	0	41.7	38.7	74.8	131	121	0	34	31
2014	7	22	5	57	0	0.823	-0.082	4.288	0.01	0.007	0	40.9	38.3	75.3	130	121	0	35	32
2014	7	22	6	7	0	0.869	-0.066	4.291	0.016	0.013	0	40.9	37.8	75.7	129	120	0	34	32
2014	7	22	6	17	0	0.883	-0.092	4.291	0.013	0.01	0	40.4	37.4	75.3	129	119	0	35	32
2014	7	22	6	27	0	0.906	-0.069	4.291	0.01	0.007	0	40.9	37.4	74.8	129	119	0	34	32
2014	7	22	6	37	0	0.876	-0.062	4.291	0.013	0.01	0	40.4	37	73.1	128	119	0	34	33
2014	7	22	6	47	0	0.863	-0.066	4.291	0.01	0.007	0	40.4	37	74.4	128	118	0	34	32
2014	7	22	6	57	0	0.925	-0.075	4.291	0.013	0.01	0	39.6	37.4	74.8	127	118	0	35	31
2014	7	22	7	7	0	0.853	-0.105	4.291	0.01	0.007	0	40	37	74	127	118	0	34	32
2014	7	22	7	17	0	0.84	-0.082	4.291	0.01	0.007	0	40.4	37.4	73.5	128	118	0	34	31
2014	7	22	7	27	0	0.912	-0.075	4.291	0.01	0.007	0	40	37.4	74	127	118	0	34	31
2014	7	22	7	37	0	0.869	-0.079	4.291	0.01	0.007	0	40	37	74	127	118	0	34	32
2014	7	22	7	47	0	0.843	-0.059	4.295	0.01	0.007	0	40	37.4	73.1	127	118	0	34	31
2014	7	22	7	57	0	0.869	-0.082	4.295	0.01	0.007	0	40.4	37.4	74	128	118	0	34	31
2014	7	22	8	7	0	0.843	-0.062	4.295	0.01	0.007	0	40.9	37.4	72.7	128	119	0	33	32
2014	7	22	8	17	0	0.896	-0.082	4.295	0.016	0.013	0	40	37.4	73.5	127	118	0	34	31
2014	7	22	8	27	0	0.843	-0.062	4.295	0.01	0.007	0	40.4	37	73.5	128	118	0	34	32
2014	7	22	8	37	0	0.846	-0.062	4.298	0.013	0.01	0	39.6	37	73.5	127	118	0	35	32
2014	7	22	8	47	0	0.886	-0.089	4.298	0.01	0.007	0	40	37.4	74	127	118	0	34	31
2014	7	22	8	57	0	0.856	-0.131	4.298	0.01	0.007	0	40	37	73.5	127	118	0	34	32
2014	7	22	9	7	0	0.814	-0.095	4.298	0.013	0.01	0	40	37	71.8	127	118	0	34	32
2014	7	22	9	17	0	0.876	-0.079	4.295	0.01	0.007	0	40	37	64.9	127	118	0	34	32
2014	7	22	9	27	0	0.846	-0.095	4.298	0.01	0.007	0	40.4	37	73.5	128	118	0	34	32
2014	7	22	9	37	0	0.84	-0.075	4.298	0.01	0.007	0	40.9	37.8	73.1	129	119	0	34	31
2014	7	22	9	47	0	0.886	-0.089	4.298	0.01	0.007	0	40.4	37.4	73.1	128	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	9	57	0	0.873	-0.092	4.295	0.01	0.007	0	40.4	37.4	71.4	128	118	0	34	31
2014	7	22	10	7	0	0.879	-0.082	4.295	0.01	0.007	0	41.3	37.8	73.1	129	119	0	33	31
2014	7	22	10	17	0	0.873	-0.095	4.295	0.013	0.01	0	40.9	37.4	73.5	129	119	0	34	32
2014	7	22	10	27	0	0.85	-0.082	4.295	0.013	0.01	0	40.9	37.4	72.2	128	118	0	33	31
2014	7	22	10	37	0	0.85	-0.059	4.295	0.01	0.007	0	40.4	37	71.4	128	118	0	34	32
2014	7	22	10	47	0	0.869	-0.095	4.295	0.01	0.007	0	40.4	37.8	73.5	128	119	0	34	31
2014	7	22	10	57	0	0.906	-0.075	4.295	0.013	0.01	0	40.4	37.4	61.5	128	119	0	34	32
2014	7	22	11	7	0	0.896	-0.066	4.295	0.01	0.007	0	40.9	37.8	58.5	129	119	0	34	31
2014	7	22	11	17	0	0.853	-0.095	4.295	0.01	0.007	0	40.4	37.8	73.1	128	119	0	34	31
2014	7	22	11	27	0	0.876	-0.082	4.295	0.013	0.01	0	40.4	37.4	62.8	128	118	0	34	31
2014	7	22	11	37	0	0.85	-0.072	4.295	0.01	0.007	0	40.4	37.8	58	128	119	0	34	31
2014	7	22	11	47	0	0.863	-0.079	4.295	0.01	0.007	0	40.9	37.8	67.5	129	119	0	34	31
2014	7	22	11	57	0	0.863	-0.075	4.295	0.01	0.007	0	40	37	59.3	127	117	0	34	31
2014	7	22	12	7	0	0.833	-0.095	4.295	0.013	0.01	0	40.4	37	62.4	128	118	0	34	32
2014	7	22	12	17	0	0.863	-0.102	4.295	0.013	0.01	0	40	37	60.2	127	118	0	34	32
2014	7	22	12	27	0	0.883	-0.102	4.295	0.01	0.007	0	40.4	37.4	58	128	118	0	34	31
2014	7	22	12	37	0	0.833	-0.059	4.295	0.01	0.007	0	40.4	37.4	55.9	128	119	0	34	32
2014	7	22	12	47	0	0.86	-0.072	4.295	0.013	0.01	0	40.9	37.4	57.6	128	118	0	33	31
2014	7	22	12	57	0	0.823	-0.092	4.291	0.013	0.01	0	40.4	37.8	53.8	128	120	0	34	32
2014	7	22	13	7	0	0.856	-0.069	4.295	0.013	0.01	0	40.9	37.8	55.9	129	120	0	34	32
2014	7	22	13	17	0	0.85	-0.121	4.295	0.01	0.007	0	40.9	38.7	55.9	130	121	0	35	31
2014	7	22	13	27	0	0.86	-0.079	4.295	0.01	0.007	0	41.3	38.3	56.3	130	120	0	34	31
2014	7	22	13	37	0	0.846	-0.098	4.295	0.01	0.007	0	41.7	38.3	54.2	130	121	0	33	32
2014	7	22	13	47	0	0.837	-0.062	4.295	0.01	0.007	0	41.3	38.3	55.9	130	121	0	34	32
2014	7	22	13	57	0	0.81	-0.079	4.295	0.013	0.01	0	41.3	38.3	55	130	121	0	34	32
2014	7	22	14	7	0	0.83	-0.075	4.295	0.016	0.013	0	40.4	38.3	55.9	129	120	0	35	31
2014	7	22	14	17	0	0.856	-0.075	4.295	0.016	0.013	0	40.9	37.8	57.2	129	120	0	34	32
2014	7	22	14	27	0	0.837	-0.082	4.295	0.013	0.01	0	40.4	37.4	54.6	128	119	0	34	32
2014	7	22	14	37	0	0.833	-0.098	4.295	0.01	0.007	0	41.7	37.8	54.6	130	120	0	33	32
2014	7	22	14	47	0	0.846	-0.049	4.291	0.01	0.007	0	41.7	39.1	53.8	131	122	0	34	31
2014	7	22	14	57	0	0.807	-0.085	4.291	0.01	0.007	0	41.7	39.1	55	131	122	0	34	31
2014	7	22	15	7	0	0.856	-0.075	4.291	0.01	0.007	0	41.7	38.3	52.5	131	121	0	34	32
2014	7	22	15	17	0	0.84	-0.089	4.291	0.013	0.01	0	41.7	38.7	53.3	131	121	0	34	31
2014	7	22	15	27	0	0.846	-0.062	4.291	0.016	0.013	0	41.7	38.7	53.8	131	121	0	34	31
2014	7	22	15	37	0	0.82	-0.049	4.291	0.013	0.01	0	42.1	39.1	53.3	132	122	0	34	31
2014	7	22	15	47	0	0.804	-0.082	4.291	0.01	0.007	0	42.1	38.7	55.9	132	122	0	34	32
2014	7	22	15	57	0	0.83	-0.085	4.291	0.01	0.007	0	41.7	38.7	54.2	131	121	0	34	31
2014	7	22	16	7	0	0.83	-0.075	4.288	0.01	0.007	0	41.7	38.3	54.2	131	121	0	34	32
2014	7	22	16	17	0	0.83	-0.062	4.288	0.01	0.007	0	43	39.6	55	133	123	0	33	31
2014	7	22	16	27	0	0.833	-0.072	4.288	0.01	0.007	0	42.1	38.7	54.6	132	122	0	34	32
2014	7	22	16	37	0	0.85	-0.082	4.288	0.01	0.007	0	42.1	39.1	54.2	132	122	0	34	31
2014	7	22	16	47	0	0.843	-0.072	4.285	0.01	0.007	0	42.1	39.1	53.8	132	122	0	34	31
2014	7	22	16	57	0	0.814	-0.098	4.288	0.013	0.01	0	41.7	38.7	53.8	131	121	0	34	31
2014	7	22	17	7	0	0.84	-0.085	4.288	0.013	0.01	0	41.3	38.7	55.5	130	121	0	34	31
2014	7	22	17	17	0	0.817	-0.095	4.288	0.01	0.007	0	41.3	38.3	52.5	130	120	0	34	31
2014	7	22	17	27	0	0.84	-0.069	4.288	0.01	0.007	0	41.3	38.3	54.2	130	121	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	22	17	37	0	0.833	-0.072	4.281	0.01	0.007	0	41.7	38.3	54.6	131	121	0	34	32
2014	7	22	17	47	0	0.846	-0.085	4.285	0.01	0.007	0	41.7	38.7	54.2	131	122	0	34	32
2014	7	22	17	57	0	0.827	-0.066	4.285	0.01	0.007	0	41.7	38.7	53.8	131	121	0	34	31
2014	7	22	18	7	0	0.84	-0.095	4.285	0.01	0.007	0	41.7	38.7	55	131	121	0	34	31
2014	7	22	18	17	0	0.807	-0.075	4.285	0.01	0.007	0	42.1	38.7	53.8	131	121	0	33	31
2014	7	22	18	27	0	0.84	-0.089	4.285	0.01	0.007	0	41.3	37.8	55.5	130	120	0	34	32
2014	7	22	18	37	0	0.866	-0.095	4.285	0.01	0.007	0	41.3	38.3	56.3	130	120	0	34	31
2014	7	22	18	47	0	0.81	-0.062	4.285	0.01	0.007	0	41.7	37.8	57.2	131	120	0	34	32
2014	7	22	18	57	0	0.883	-0.072	4.281	0.01	0.007	0	41.7	38.3	58	131	120	0	34	31
2014	7	22	19	7	0	0.837	-0.092	4.285	0.013	0.01	0	41.7	38.3	55.9	130	120	0	33	31
2014	7	22	19	17	0	0.889	-0.079	4.285	0.01	0.007	0	41.7	37.8	60.2	131	119	0	34	31
2014	7	22	19	27	0	0.883	-0.072	4.281	0.01	0.007	0	41.7	38.3	61.1	131	120	0	34	31
2014	7	22	19	37	0	0.833	-0.089	4.285	0.016	0.013	0	41.7	38.3	67.1	131	120	0	34	31
2014	7	22	19	47	0	0.86	-0.082	4.285	0.01	0.007	0	41.7	37.8	74.4	131	120	0	34	32
2014	7	22	19	57	0	0.86	-0.095	4.285	0.01	0.007	0	41.7	38.3	74.8	131	120	0	34	31
2014	7	22	20	7	0	0.883	-0.079	4.285	0.01	0.007	0	41.7	38.3	74.8	131	120	0	34	31
2014	7	22	20	17	0	0.876	-0.072	4.285	0.013	0.01	0	41.7	38.3	76.5	131	120	0	34	31
2014	7	22	20	27	0	0.906	-0.062	4.285	0.01	0.007	0	42.1	38.3	74	131	120	0	33	31
2014	7	22	20	37	0	0.886	-0.092	4.285	0.013	0.01	0	41.7	38.7	72.2	131	121	0	34	31
2014	7	22	20	47	0	0.86	-0.049	4.285	0.01	0.007	0	41.3	37.4	74	130	119	0	34	32
2014	7	22	20	57	0	0.876	-0.072	4.285	0.01	0.007	0	41.3	37.8	75.3	130	119	0	34	31
2014	7	22	21	7	0	0.879	-0.069	4.285	0.013	0.01	0	40.9	37.4	75.7	129	118	0	34	31
2014	7	22	21	17	0	0.853	-0.049	4.285	0.01	0.007	0	40.9	37	76.5	129	118	0	34	32
2014	7	22	21	27	0	0.869	-0.075	4.285	0.013	0.01	0	40.4	36.5	77	128	117	0	34	32
2014	7	22	21	37	0	0.892	-0.066	4.285	0.01	0.007	0	40.9	37	77	129	118	0	34	32
2014	7	22	21	47	0	0.856	-0.069	4.285	0.013	0.01	0	40.9	37	76.1	128	117	0	33	31
2014	7	22	21	57	0	0.869	-0.082	4.285	0.01	0.007	0	40.4	36.5	68.8	128	117	0	34	32
2014	7	22	22	7	0	0.856	-0.079	4.285	0.01	0.007	0	40.9	37	67.5	128	117	0	33	31
2014	7	22	22	17	0	0.869	-0.098	4.285	0.01	0.007	0	40.9	37	58.9	129	118	0	34	32
2014	7	22	22	27	0	0.837	-0.079	4.285	0.01	0.007	0	40.4	37	67.5	128	117	0	34	31
2014	7	22	22	37	0	0.853	-0.056	4.285	0.013	0.01	0	40.4	37	67.9	128	117	0	34	31
2014	7	22	22	47	0	0.853	-0.082	4.285	0.01	0.007	0	40.9	37	58.5	129	117	0	34	31
2014	7	22	22	57	0	0.856	-0.069	4.285	0.01	0.007	0	40.9	37.4	55	129	118	0	34	31
2014	7	22	23	7	0	0.925	-0.075	4.285	0.01	0.007	0	40.4	37	58.9	128	117	0	34	31
2014	7	22	23	17	0	0.837	-0.072	4.285	0.01	0.007	0	40.4	36.5	57.2	128	117	0	34	32
2014	7	22	23	27	0	0.86	-0.082	4.285	0.01	0.007	0	40.4	37	58.5	128	118	0	34	32
2014	7	22	23	37	0	0.837	-0.098	4.285	0.01	0.007	0	40.4	37	60.2	128	117	0	34	31
2014	7	22	23	47	0	0.846	-0.085	4.285	0.01	0.007	0	40.4	37	59.3	128	117	0	34	31
2014	7	22	23	57	0	0.84	-0.098	4.285	0.01	0.007	0	40.4	37	69.7	128	118	0	34	32
2014	7	23	0	7	0	0.866	-0.079	4.285	0.01	0.007	0	40.4	36.5	65.4	128	117	0	34	32
2014	7	23	0	17	0	0.86	-0.089	4.285	0.013	0.01	0	40.9	36.5	69.2	128	117	0	33	32
2014	7	23	0	27	0	0.827	-0.046	4.285	0.01	0.007	0	40.4	37	72.7	128	118	0	34	32
2014	7	23	0	37	0	0.837	-0.062	4.288	0.01	0.007	0	40	37	74	128	117	0	35	31
2014	7	23	0	47	0	0.866	-0.059	4.285	0.01	0.007	0	40.4	36.5	77	128	117	0	34	32
2014	7	23	0	57	0	0.876	-0.082	4.288	0.01	0.007	0	40.9	36.5	77.4	128	117	0	33	32
2014	7	23	1	7	0	0.879	-0.079	4.285	0.01	0.007	0	40.9	37	76.1	129	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	1	17	0	0.843	-0.079	4.288	0.01	0.007	0	40.4	37	77	128	117	0	34	31
2014	7	23	1	27	0	0.85	-0.059	4.288	0.01	0.007	0	40.4	37	75.7	129	118	0	35	32
2014	7	23	1	37	0	0.889	-0.092	4.288	0.013	0.01	0	40.4	36.5	76.5	128	117	0	34	32
2014	7	23	1	47	0	0.873	-0.079	4.288	0.013	0.01	0	40.4	36.5	76.5	128	117	0	34	32
2014	7	23	1	57	0	0.833	-0.059	4.288	0.01	0.007	0	40.4	37	76.5	128	117	0	34	31
2014	7	23	2	7	0	0.856	-0.069	4.288	0.01	0.007	0	40.9	37	76.1	129	118	0	34	32
2014	7	23	2	17	0	0.886	-0.072	4.288	0.013	0.01	0	40.4	37	76.1	128	118	0	34	32
2014	7	23	2	27	0	0.899	-0.079	4.288	0.013	0.01	0	40.4	37	76.5	128	118	0	34	32
2014	7	23	2	37	0	0.86	-0.098	4.288	0.01	0.007	0	40.4	37.4	76.1	129	118	0	35	31
2014	7	23	2	47	0	0.846	-0.069	4.288	0.01	0.007	0	40.4	37.4	76.5	129	118	0	35	31
2014	7	23	2	57	0	0.896	-0.079	4.288	0.01	0.007	0	40.9	37.4	76.1	129	118	0	34	31
2014	7	23	3	7	0	0.889	-0.079	4.288	0.01	0.007	0	40.9	37	76.1	129	118	0	34	32
2014	7	23	3	17	0	0.853	-0.062	4.288	0.01	0.007	0	40.4	36.5	74.8	128	117	0	34	32
2014	7	23	3	27	0	0.886	-0.108	4.288	0.013	0.01	0	40.4	37	75.3	129	118	0	35	32
2014	7	23	3	37	0	0.84	-0.075	4.288	0.013	0.01	0	40.9	37	76.1	129	118	0	34	32
2014	7	23	3	47	0	0.892	-0.095	4.288	0.01	0.007	0	40.4	37	75.7	128	117	0	34	31
2014	7	23	3	57	0	0.892	-0.062	4.288	0.01	0.007	0	40.4	36.5	75.7	128	117	0	34	32
2014	7	23	4	7	0	0.869	-0.066	4.288	0.01	0.007	0	40.4	37.4	75.3	128	118	0	34	31
2014	7	23	4	17	0	0.909	-0.105	4.288	0.016	0.013	0	40.9	37	74.8	129	118	0	34	32
2014	7	23	4	27	0	0.873	-0.108	4.288	0.01	0.007	0	40.9	37	74	129	118	0	34	32
2014	7	23	4	37	0	0.86	-0.089	4.288	0.01	0.007	0	40.9	37.4	74.8	129	118	0	34	31
2014	7	23	4	47	0	0.915	-0.085	4.288	0.01	0.007	0	41.3	37.4	74.4	130	119	0	34	32
2014	7	23	4	57	0	0.846	-0.062	4.291	0.013	0.01	0	41.3	37.4	74.4	130	119	0	34	32
2014	7	23	5	7	0	0.846	-0.082	4.291	0.01	0.007	0	41.3	38.3	74.4	130	119	0	34	30
2014	7	23	5	17	0	0.886	-0.105	4.291	0.01	0.007	0	40.9	37.4	74	130	119	0	35	32
2014	7	23	5	27	0	0.873	-0.072	4.291	0.01	0.007	0	41.3	38.3	73.1	131	120	0	35	31
2014	7	23	5	37	0	0.856	-0.079	4.291	0.01	0.007	0	41.3	37.8	73.1	131	120	0	35	32
2014	7	23	5	47	0	0.876	-0.092	4.291	0.01	0.007	0	41.7	37.4	73.1	131	120	0	34	33
2014	7	23	5	57	0	0.883	-0.092	4.291	0.013	0.01	0	41.7	37.8	72.7	131	120	0	34	32
2014	7	23	6	7	0	0.896	-0.108	4.298	0.01	0.007	0	41.7	37.8	72.7	131	120	0	34	32
2014	7	23	6	17	0	0.892	-0.095	4.301	0.01	0.007	0	41.3	37.8	72.7	130	120	0	34	32
2014	7	23	6	27	0	0.866	-0.092	4.301	0.013	0.01	0	41.3	37.8	72.7	130	119	0	34	31
2014	7	23	6	37	0	0.869	-0.033	4.304	0.01	0.007	0	40.9	37.4	73.5	130	119	0	35	32
2014	7	23	6	47	0	0.833	-0.036	4.304	0.013	0.01	0	40.9	37.8	74.4	130	119	0	35	31
2014	7	23	6	57	0	0.876	-0.079	4.304	0.013	0.01	0	40.9	37	74.4	129	118	0	34	32
2014	7	23	7	7	0	0.883	-0.085	4.304	0.016	0.013	0	40.4	37	74.4	129	118	0	35	32
2014	7	23	7	17	0	0.892	-0.102	4.304	0.013	0.01	0	40.4	36.5	74.4	128	117	0	34	32
2014	7	23	7	27	0	0.902	-0.062	4.304	0.01	0.007	0	40.9	37	75.3	129	118	0	34	32
2014	7	23	7	37	0	0.879	-0.079	4.304	0.01	0.007	0	40.9	37	74.4	129	118	0	34	32
2014	7	23	7	47	0	0.902	-0.092	4.304	0.01	0.007	0	40.9	37.8	75.3	129	119	0	34	31
2014	7	23	7	57	0	0.889	-0.046	4.304	0.016	0.013	0	40.9	37	75.3	129	118	0	34	32
2014	7	23	8	7	0	0.866	-0.085	4.308	0.013	0.01	0	41.3	37.4	75.3	130	119	0	34	32
2014	7	23	8	17	0	0.879	-0.079	4.304	0.013	0.01	0	40.9	37.8	74.8	130	119	0	35	31
2014	7	23	8	27	0	0.876	-0.079	4.308	0.01	0.007	0	40.4	37.4	75.7	129	118	0	35	31
2014	7	23	8	37	0	0.873	-0.062	4.308	0.01	0.007	0	40.9	37.4	75.3	129	119	0	34	32
2014	7	23	8	47	0	0.886	-0.089	4.308	0.01	0.007	0	40.9	37.4	76.1	129	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	8	57	0	0.866	-0.052	4.308	0.013	0.01	0	40.4	37.4	76.1	128	118	0	34	31
2014	7	23	9	7	0	0.883	-0.085	4.308	0.01	0.007	0	40.4	37.4	75.7	129	118	0	35	31
2014	7	23	9	17	0	0.922	-0.056	4.308	0.01	0.007	0	41.3	37.4	74.8	130	119	0	34	32
2014	7	23	9	27	0	0.942	-0.102	4.308	0.01	0.007	0	40.9	37.4	75.7	129	119	0	34	32
2014	7	23	9	37	0	0.899	-0.075	4.308	0.01	0.007	0	40.9	37.4	76.5	129	119	0	34	32
2014	7	23	9	47	0	0.915	-0.075	4.308	0.016	0.013	0	40.4	37	75.3	128	118	0	34	32
2014	7	23	9	57	0	0.856	-0.095	4.308	0.01	0.007	0	40.9	37.4	76.1	129	119	0	34	32
2014	7	23	10	7	0	0.912	-0.039	4.308	0.01	0.007	0	40.9	37.8	76.5	129	119	0	34	31
2014	7	23	10	17	0	0.886	-0.072	4.308	0.013	0.01	0	40.9	37	76.5	129	118	0	34	32
2014	7	23	10	27	0	0.869	-0.095	4.308	0.01	0.007	0	40.9	37.8	76.1	129	119	0	34	31
2014	7	23	10	37	0	0.892	-0.059	4.308	0.01	0.007	0	40.9	37.4	75.7	129	119	0	34	32
2014	7	23	10	47	0	0.83	-0.066	4.308	0.013	0.01	0	40.9	37.4	75.7	129	119	0	34	32
2014	7	23	10	57	0	0.846	-0.105	4.308	0.01	0.007	0	40.9	37.4	74.8	129	118	0	34	31
2014	7	23	11	7	0	0.863	-0.082	4.308	0.01	0.007	0	41.3	37.8	74.8	130	119	0	34	31
2014	7	23	11	17	0	0.846	-0.105	4.308	0.013	0.01	0	40.9	37.8	75.7	129	119	0	34	31
2014	7	23	11	27	0	0.899	-0.052	4.308	0.01	0.007	0	41.3	37.8	74.4	130	119	0	34	31
2014	7	23	11	37	0	0.886	-0.079	4.308	0.013	0.01	0	40.9	37.8	75.3	129	119	0	34	31
2014	7	23	11	47	0	0.876	-0.072	4.308	0.013	0.01	0	42.1	37.8	72.7	131	120	0	33	32
2014	7	23	11	57	0	0.876	-0.062	4.308	0.013	0.01	0	41.3	37.4	74	130	119	0	34	32
2014	7	23	12	7	0	0.886	-0.062	4.308	0.016	0.013	0	40.9	37	73.1	129	118	0	34	32
2014	7	23	12	17	0	0.863	-0.079	4.301	0.01	0.007	0	40.9	37.4	62.4	129	119	0	34	32
2014	7	23	12	27	0	0.879	-0.062	4.301	0.01	0.007	0	40.9	37.4	66.2	129	119	0	34	32
2014	7	23	12	37	0	0.902	-0.062	4.301	0.01	0.007	0	40.9	37	72.2	129	118	0	34	32
2014	7	23	12	47	0	0.85	-0.118	4.298	0.01	0.007	0	40.4	37	70.1	128	118	0	34	32
2014	7	23	12	57	0	0.866	-0.092	4.298	0.01	0.007	0	40.9	37	65.4	129	118	0	34	32
2014	7	23	13	7	0	0.876	-0.098	4.295	0.01	0.007	0	40	37.4	70.1	128	118	0	35	31
2014	7	23	13	17	0	0.837	-0.066	4.295	0.01	0.007	0	40	37	64.5	127	117	0	34	31
2014	7	23	13	27	0	0.909	-0.079	4.295	0.013	0.01	0	40.4	37	68.8	128	118	0	34	32
2014	7	23	13	37	0	0.866	-0.079	4.295	0.013	0.01	0	40.4	37	62.8	128	117	0	34	31
2014	7	23	13	47	0	0.883	-0.112	4.295	0.01	0.007	0	40.4	36.5	69.2	128	117	0	34	32
2014	7	23	13	57	0	0.869	-0.105	4.295	0.013	0.01	0	40.4	36.5	63.6	128	117	0	34	32
2014	7	23	14	7	0	0.846	-0.059	4.295	0.01	0.007	0	40	36.5	69.2	127	117	0	34	32
2014	7	23	14	17	0	0.889	-0.085	4.295	0.01	0.007	0	40	36.5	75.3	127	116	0	34	31
2014	7	23	14	27	0	0.869	-0.072	4.295	0.013	0.01	0	40	36.5	71.4	127	116	0	34	31
2014	7	23	14	37	0	0.869	-0.098	4.295	0.013	0.01	0	40	36.1	63.6	127	116	0	34	32
2014	7	23	14	47	0	0.866	-0.075	4.295	0.01	0.007	0	40.4	37.4	56.8	128	118	0	34	31
2014	7	23	14	57	0	0.85	-0.082	4.298	0.01	0.007	0	40.9	37.8	53.8	129	119	0	34	31
2014	7	23	15	7	0	0.869	-0.089	4.295	0.01	0.007	0	41.7	37.8	58	130	119	0	33	31
2014	7	23	15	17	0	0.846	-0.062	4.295	0.01	0.007	0	41.3	37.8	55.9	130	119	0	34	31
2014	7	23	15	27	0	0.827	-0.089	4.295	0.013	0.01	0	41.3	37.8	58.5	130	119	0	34	31
2014	7	23	15	37	0	0.827	-0.105	4.291	0.01	0.007	0	40.9	37.8	58.9	129	119	0	34	31
2014	7	23	15	47	0	0.853	-0.102	4.295	0.01	0.007	0	40.9	37	57.6	129	118	0	34	32
2014	7	23	15	57	0	0.869	-0.056	4.291	0.01	0.007	0	40.9	37.8	58.5	129	119	0	34	31
2014	7	23	16	7	0	0.915	-0.056	4.291	0.01	0.007	0	41.3	37.8	54.6	130	119	0	34	31
2014	7	23	16	17	0	0.886	-0.075	4.291	0.01	0.007	0	41.3	37.8	58	129	119	0	33	31
2014	7	23	16	27	0	0.846	-0.082	4.291	0.01	0.007	0	41.3	38.3	55	130	120	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	23	16	37	0	0.85	-0.072	4.295	0.01	0.007	0	41.7	37.8	55.5	130	119	0	33	31
2014	7	23	16	47	0	0.876	-0.066	4.291	0.01	0.007	0	41.7	37.8	56.8	131	120	0	34	32
2014	7	23	16	57	0	0.846	-0.085	4.291	0.01	0.007	0	41.7	37.8	55.9	131	120	0	34	32
2014	7	23	17	7	0	0.82	-0.066	4.291	0.01	0.007	0	41.7	38.7	56.3	131	121	0	34	31
2014	7	23	17	17	0	0.863	-0.092	4.291	0.01	0.007	0	41.7	38.7	56.3	131	121	0	34	31
2014	7	23	17	27	0	0.833	-0.082	4.288	0.01	0.007	0	41.7	38.7	56.8	131	121	0	34	31
2014	7	23	17	37	0	0.84	-0.085	4.288	0.01	0.007	0	41.7	38.3	56.8	131	120	0	34	31
2014	7	23	17	47	0	0.863	-0.075	4.288	0.01	0.007	0	41.7	38.3	57.2	131	120	0	34	31
2014	7	23	17	57	0	0.837	-0.098	4.288	0.013	0.01	0	41.7	37.8	59.3	131	119	0	34	31
2014	7	23	18	7	0	0.833	-0.082	4.288	0.01	0.007	0	42.1	37.8	57.2	132	120	0	34	32
2014	7	23	18	17	0	0.886	-0.098	4.288	0.01	0.007	0	41.7	37.8	57.6	131	119	0	34	31
2014	7	23	18	27	0	0.853	-0.102	4.288	0.013	0.01	0	42.1	37.8	57.6	131	119	0	33	31
2014	7	23	18	37	0	0.82	-0.098	4.288	0.01	0.007	0	41.7	37.4	64.9	131	119	0	34	32
2014	7	23	18	47	0	0.856	-0.085	4.288	0.01	0.007	0	41.3	37.8	69.2	131	120	0	35	32
2014	7	23	18	57	0	0.866	-0.089	4.288	0.01	0.007	0	41.7	37.8	71.4	131	120	0	34	32
2014	7	23	19	7	0	0.837	-0.079	4.285	0.01	0.007	0	41.7	37.4	58	131	119	0	34	32
2014	7	23	19	17	0	0.866	-0.062	4.285	0.01	0.007	0	41.7	37.8	60.6	131	119	0	34	31
2014	7	23	19	27	0	0.82	-0.092	4.288	0.013	0.01	0	41.7	37.4	67.9	131	119	0	34	32
2014	7	23	19	37	0	0.856	-0.062	4.288	0.013	0.01	0	41.7	37.4	74.8	130	119	0	33	32
2014	7	23	19	47	0	0.886	-0.095	4.288	0.01	0.007	0	41.7	37.4	77	131	119	0	34	32
2014	7	23	19	57	0	0.869	-0.066	4.288	0.01	0.007	0	41.7	37.4	77.4	131	119	0	34	32
2014	7	23	20	7	0	0.886	-0.089	4.288	0.01	0.007	0	41.7	38.3	77	131	120	0	34	31
2014	7	23	20	17	0	0.876	-0.089	4.288	0.01	0.007	0	41.7	38.3	71	131	120	0	34	31
2014	7	23	20	27	0	0.899	-0.072	4.288	0.01	0.007	0	41.7	38.3	74.4	131	120	0	34	31
2014	7	23	20	37	0	0.866	-0.082	4.288	0.01	0.007	0	41.7	38.3	71.8	131	120	0	34	31
2014	7	23	20	47	0	0.856	-0.079	4.288	0.01	0.007	0	42.1	38.3	70.5	132	121	0	34	32
2014	7	23	20	57	0	0.853	-0.069	4.285	0.01	0.007	0	41.3	37.8	61.5	130	119	0	34	31
2014	7	23	21	7	0	0.902	-0.075	4.288	0.01	0.007	0	41.3	37	76.5	130	118	0	34	32
2014	7	23	21	17	0	0.856	-0.108	4.288	0.01	0.007	0	41.3	37.4	72.2	130	119	0	34	32
2014	7	23	21	27	0	0.823	-0.069	4.288	0.01	0.007	0	41.3	37	74.4	130	118	0	34	32
2014	7	23	21	37	0	0.86	-0.049	4.288	0.01	0.007	0	41.3	37	74.4	129	117	0	33	31
2014	7	23	21	47	0	0.886	-0.049	4.288	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	23	21	57	0	0.817	-0.105	4.285	0.01	0.007	0	40.9	37	65.4	129	118	0	34	32
2014	7	23	22	7	0	0.856	-0.092	4.285	0.01	0.007	0	40.4	36.5	63.6	128	117	0	34	32
2014	7	23	22	17	0	0.84	-0.075	4.285	0.01	0.007	0	40.4	37	72.2	128	117	0	34	31
2014	7	23	22	27	0	0.892	-0.095	4.288	0.01	0.007	0	40.4	37	67.5	128	117	0	34	31
2014	7	23	22	37	0	0.863	-0.033	4.288	0.01	0.007	0	41.3	37	72.2	130	117	0	34	31
2014	7	23	22	47	0	0.853	-0.089	4.288	0.013	0.01	0	41.3	37	62.4	130	117	0	34	31
2014	7	23	22	57	0	0.879	-0.079	4.288	0.01	0.007	0	41.3	36.5	72.2	130	117	0	34	32
2014	7	23	23	7	0	0.883	-0.105	4.288	0.01	0.007	0	41.3	36.5	67.1	130	117	0	34	32
2014	7	23	23	17	0	0.873	-0.052	4.285	0.01	0.007	0	40.9	36.1	65.4	129	116	0	34	32
2014	7	23	23	27	0	0.843	-0.062	4.285	0.01	0.007	0	40.9	37	69.7	129	117	0	34	31
2014	7	23	23	37	0	0.853	-0.056	4.288	0.01	0.007	0	41.3	36.5	68.4	130	117	0	34	32
2014	7	23	23	47	0	0.833	-0.089	4.285	0.01	0.007	0	41.3	37	61.9	130	117	0	34	31
2014	7	23	23	57	0	0.853	-0.049	4.285	0.01	0.007	0	41.3	37	68.4	130	117	0	34	31
2014	7	24	0	7	0	0.856	-0.075	4.288	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	0	17	0	0.899	-0.092	4.288	0.01	0.007	0	41.3	36.1	76.1	129	116	0	33	32
2014	7	24	0	27	0	0.883	-0.079	4.288	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	24	0	37	0	0.827	-0.066	4.288	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	24	0	47	0	0.892	-0.072	4.288	0.01	0.007	0	40.9	36.5	75.7	129	116	0	34	31
2014	7	24	0	57	0	0.892	-0.046	4.288	0.013	0.01	0	40.9	36.5	75.3	129	117	0	34	32
2014	7	24	1	7	0	0.879	-0.075	4.288	0.013	0.01	0	40.9	36.1	76.5	129	116	0	34	32
2014	7	24	1	17	0	0.896	-0.062	4.288	0.013	0.01	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	24	1	27	0	0.906	-0.052	4.288	0.013	0.01	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	24	1	37	0	0.883	-0.095	4.288	0.01	0.007	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	24	1	47	0	0.879	-0.049	4.288	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31
2014	7	24	1	57	0	0.883	-0.095	4.288	0.01	0.007	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	24	2	7	0	0.876	-0.069	4.288	0.01	0.007	0	40.9	36.1	75.7	129	116	0	34	32
2014	7	24	2	17	0	0.896	-0.069	4.288	0.01	0.007	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	24	2	27	0	0.843	-0.072	4.288	0.013	0.01	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	24	2	37	0	0.886	-0.062	4.288	0.01	0.007	0	40	35.7	76.1	128	115	0	35	32
2014	7	24	2	47	0	0.896	-0.089	4.291	0.01	0.007	0	40.9	36.5	76.1	129	116	0	34	31
2014	7	24	2	57	0	0.925	-0.046	4.291	0.01	0.007	0	40.9	36.1	76.5	129	116	0	34	32
2014	7	24	3	7	0	0.853	-0.072	4.288	0.016	0.016	0	41.3	37	75.3	130	117	0	34	31
2014	7	24	3	17	0	0.843	-0.072	4.291	0.01	0.007	0	41.3	36.5	74.8	130	117	0	34	32
2014	7	24	3	27	0	0.853	-0.072	4.291	0.01	0.007	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	24	3	37	0	0.886	-0.082	4.291	0.01	0.007	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	24	3	47	0	0.889	-0.046	4.291	0.013	0.01	0	41.3	37	74	130	117	0	34	31
2014	7	24	3	57	0	0.86	-0.059	4.291	0.01	0.007	0	41.3	36.1	74.8	130	117	0	34	33
2014	7	24	4	7	0	0.902	-0.056	4.291	0.01	0.007	0	40.9	37	74.4	130	118	0	35	32
2014	7	24	4	17	0	0.873	-0.095	4.291	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	24	4	27	0	0.902	-0.095	4.291	0.01	0.007	0	41.7	37.4	74	131	118	0	34	31
2014	7	24	4	37	0	0.896	-0.079	4.291	0.01	0.007	0	41.3	37	74	131	118	0	35	32
2014	7	24	4	47	0	0.866	-0.085	4.291	0.01	0.007	0	41.7	37.4	74	131	118	0	34	31
2014	7	24	4	57	0	0.869	-0.062	4.295	0.01	0.007	0	41.7	37	73.1	131	118	0	34	32
2014	7	24	5	7	0	0.879	-0.079	4.298	0.01	0.007	0	41.7	37.4	72.7	131	119	0	34	32
2014	7	24	5	17	0	0.919	-0.069	4.298	0.01	0.007	0	41.3	37.4	73.1	131	118	0	35	31
2014	7	24	5	27	0	0.896	-0.066	4.298	0.013	0.01	0	41.7	37.4	73.1	132	119	0	35	32
2014	7	24	5	37	0	0.886	-0.062	4.301	0.013	0.01	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	24	5	47	0	0.869	-0.062	4.304	0.013	0.01	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	24	5	57	0	0.902	-0.072	4.304	0.01	0.007	0	42.1	37.4	74	132	119	0	34	32
2014	7	24	6	7	0	0.85	-0.052	4.304	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	24	6	17	0	0.899	-0.062	4.304	0.01	0.007	0	41.7	37	74.8	131	118	0	34	32
2014	7	24	6	27	0	0.85	-0.102	4.304	0.01	0.007	0	42.1	37.4	74.8	132	118	0	34	31
2014	7	24	6	37	0	0.915	-0.085	4.304	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	24	6	47	0	0.876	-0.085	4.304	0.01	0.007	0	42.1	37.4	74.8	132	118	0	34	31
2014	7	24	6	57	0	0.912	-0.082	4.304	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	24	7	7	0	0.889	-0.098	4.304	0.01	0.007	0	40.9	37.4	74.4	130	118	0	35	31
2014	7	24	7	17	0	0.869	-0.062	4.304	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	24	7	27	0	0.906	-0.092	4.304	0.016	0.013	0	41.7	37	75.7	131	118	0	34	32
2014	7	24	7	37	0	0.883	-0.095	4.304	0.01	0.007	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	24	7	47	0	0.883	-0.095	4.308	0.01	0.007	0	41.3	37	76.5	131	118	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	7	57	0	0.846	-0.062	4.308	0.013	0.01	0	41.7	37	75.7	131	118	0	34	32
2014	7	24	8	7	0	0.866	-0.085	4.308	0.013	0.01	0	41.7	37	76.1	131	118	0	34	32
2014	7	24	8	17	0	0.883	-0.115	4.308	0.01	0.007	0	41.3	36.5	75.7	130	118	0	34	33
2014	7	24	8	27	0	0.925	-0.102	4.308	0.01	0.007	0	41.3	37	75.3	131	118	0	35	32
2014	7	24	8	37	0	0.883	-0.082	4.308	0.013	0.01	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	24	8	47	0	0.866	-0.072	4.308	0.01	0.007	0	43	38.3	76.1	134	122	0	34	33
2014	7	24	8	57	0	0.909	-0.079	4.308	0.01	0.007	0	41.7	37.4	76.5	132	119	0	35	32
2014	7	24	9	7	0	0.86	-0.075	4.308	0.013	0.01	0	42.1	37.8	76.5	132	119	0	34	31
2014	7	24	9	17	0	0.902	-0.095	4.308	0.013	0.01	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	24	9	27	0	0.863	-0.082	4.308	0.013	0.01	0	42.1	37.8	76.5	133	120	0	35	32
2014	7	24	9	37	0	0.879	-0.046	4.308	0.01	0.007	0	42.1	38.7	77.4	133	122	0	35	32
2014	7	24	9	47	0	0.866	-0.079	4.308	0.013	0.01	0	42.1	38.3	76.5	133	121	0	35	32
2014	7	24	9	57	0	0.892	-0.079	4.308	0.01	0.007	0	41.7	37.8	76.5	132	120	0	35	32
2014	7	24	10	7	0	0.869	-0.098	4.308	0.013	0.01	0	41.3	37.8	75.7	131	120	0	35	32
2014	7	24	10	17	0	0.869	-0.072	4.308	0.01	0.007	0	42.1	37.8	76.5	132	120	0	34	32
2014	7	24	10	27	0	0.886	-0.082	4.308	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	24	10	37	0	0.889	-0.089	4.308	0.01	0.007	0	41.7	37.4	77	131	119	0	34	32
2014	7	24	10	47	0	0.879	-0.072	4.308	0.01	0.007	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	24	10	57	0	0.896	-0.082	4.308	0.01	0.007	0	41.3	37.4	77	131	119	0	35	32
2014	7	24	11	7	0	0.84	-0.036	4.308	0.01	0.007	0	41.7	37	76.1	131	119	0	34	33
2014	7	24	11	17	0	0.83	-0.089	4.308	0.01	0.007	0	41.7	37.4	74.4	131	119	0	34	32
2014	7	24	11	27	0	0.889	-0.049	4.308	0.013	0.01	0	41.7	37.8	75.3	131	119	0	34	31
2014	7	24	11	37	0	0.873	-0.089	4.308	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	24	11	47	0	0.889	-0.062	4.308	0.01	0.007	0	41.7	37	75.7	131	118	0	34	32
2014	7	24	11	57	0	0.879	-0.062	4.308	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	24	12	7	0	0.869	-0.112	4.308	0.01	0.007	0	41.7	37.4	74.8	131	119	0	34	32
2014	7	24	12	17	0	0.892	-0.092	4.308	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	24	12	27	0	0.892	-0.095	4.304	0.01	0.007	0	45.6	41.3	70.1	141	128	0	35	32
2014	7	24	12	37	0	0.804	-0.082	4.308	0.01	0.007	0	54.6	50.3	65.8	161	148	0	34	31
2014	7	24	12	47	0	0.915	-0.112	4.298	0.016	0.013	0	51.2	49	52.5	153	146	0	34	32
2014	7	24	12	57	0	0.797	-0.115	4.298	0.01	0.007	0	40.9	41.7	55.9	129	129	0	34	32
2014	7	24	13	7	0	0.974	32767	4.301	0.023	0.837	0	0	38.7	45.2	0	122	0	35	32
2014	7	24	13	17	0	0.879	-0.072	4.295	0.01	0.007	0	42.6	38.7	57.6	133	121	0	34	31
2014	7	24	13	27	0	0.83	-0.069	4.301	0.01	0.007	0	42.6	37.8	53.8	133	119	0	34	31
2014	7	24	13	37	0	0.83	-0.079	4.295	0.01	0.007	0	42.1	37.8	71	132	120	0	34	32
2014	7	24	13	47	0	0.846	-0.082	4.295	0.016	0.013	0	41.7	37.8	65.8	131	119	0	34	31
2014	7	24	13	57	0	0.85	-0.075	4.295	0.01	0.007	0	42.1	37.8	66.2	132	119	0	34	31
2014	7	24	14	7	0	0.833	-0.089	4.295	0.016	0.013	0	41.7	37	72.2	131	118	0	34	32
2014	7	24	14	17	0	0.86	-0.079	4.295	0.01	0.007	0	41.3	37.4	63.2	131	119	0	35	32
2014	7	24	14	27	0	0.899	-0.059	4.295	0.01	0.007	0	41.7	37.4	74.4	131	119	0	34	32
2014	7	24	14	37	0	0.84	-0.085	4.291	0.01	0.007	0	41.7	37	59.3	131	118	0	34	32
2014	7	24	14	47	0	0.817	-0.108	4.291	0.01	0.007	0	41.3	37	57.6	131	118	0	35	32
2014	7	24	14	57	0	0.86	-0.079	4.291	0.01	0.007	0	41.7	37.4	71.8	131	118	0	34	31
2014	7	24	15	7	0	0.833	-0.075	4.291	0.01	0.007	0	41.3	37	75.3	130	118	0	34	32
2014	7	24	15	17	0	0.84	-0.092	4.291	0.01	0.007	0	41.7	37	74.8	131	118	0	34	32
2014	7	24	15	27	0	0.827	-0.079	4.291	0.01	0.007	0	41.7	37	68.8	131	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	15	37	0	0.827	-0.082	4.291	0.013	0.01	0	41.7	37.4	60.6	131	119	0	34	32
2014	7	24	15	47	0	0.837	-0.056	4.291	0.01	0.007	0	41.7	38.3	57.2	132	120	0	35	31
2014	7	24	15	57	0	0.83	-0.082	4.291	0.01	0.007	0	42.6	37.8	55.5	133	120	0	34	32
2014	7	24	16	7	0	0.814	-0.043	4.295	0.01	0.007	0	43.4	39.1	53.8	135	122	0	34	31
2014	7	24	16	17	0	0.814	-0.069	4.291	0.01	0.007	0	43.4	38.7	58	135	122	0	34	32
2014	7	24	16	27	0	0.846	-0.069	4.291	0.01	0.007	0	43	38.3	55.5	134	121	0	34	32
2014	7	24	16	37	0	0.794	-0.062	4.288	0.01	0.007	0	43	38.7	56.8	134	121	0	34	31
2014	7	24	16	47	0	0.82	-0.069	4.288	0.01	0.007	0	43	38.7	57.2	134	121	0	34	31
2014	7	24	16	57	0	0.843	-0.079	4.288	0.013	0.01	0	43	38.7	57.6	134	121	0	34	31
2014	7	24	17	7	0	0.807	-0.059	4.288	0.01	0.007	0	42.6	38.3	58	133	120	0	34	31
2014	7	24	17	17	0	0.833	-0.056	4.288	0.01	0.007	0	42.6	37.8	57.2	133	120	0	34	32
2014	7	24	17	27	0	0.84	-0.069	4.288	0.013	0.01	0	43	37.8	58	133	120	0	33	32
2014	7	24	17	37	0	0.807	-0.075	4.288	0.01	0.007	0	42.6	38.7	57.2	133	121	0	34	31
2014	7	24	17	47	0	0.82	-0.062	4.288	0.013	0.01	0	43	37.8	58.5	133	120	0	33	32
2014	7	24	17	57	0	0.827	-0.082	4.288	0.013	0.01	0	42.6	38.3	59.3	133	120	0	34	31
2014	7	24	18	7	0	0.85	-0.079	4.285	0.01	0.007	0	42.6	38.3	57.2	133	120	0	34	31
2014	7	24	18	17	0	0.817	-0.062	4.285	0.01	0.007	0	42.6	38.3	60.6	133	120	0	34	31
2014	7	24	18	27	0	0.863	-0.079	4.285	0.01	0.007	0	42.6	38.3	68.8	133	120	0	34	31
2014	7	24	18	37	0	0.85	-0.072	4.285	0.01	0.007	0	43.4	37.8	62.4	134	120	0	33	32
2014	7	24	18	47	0	0.84	-0.082	4.285	0.01	0.007	0	42.6	37.8	74.8	133	120	0	34	32
2014	7	24	18	57	0	0.85	-0.056	4.285	0.01	0.007	0	42.6	38.3	74.8	133	120	0	34	31
2014	7	24	19	7	0	0.833	-0.069	4.285	0.01	0.007	0	42.6	38.3	77	133	120	0	34	31
2014	7	24	19	17	0	0.853	-0.066	4.285	0.013	0.01	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	24	19	27	0	0.883	-0.098	4.285	0.01	0.007	0	42.1	37.4	75.7	132	119	0	34	32
2014	7	24	19	37	0	0.837	-0.072	4.285	0.013	0.01	0	42.6	37.8	76.1	133	119	0	34	31
2014	7	24	19	47	0	0.843	-0.066	4.285	0.01	0.007	0	42.1	37.8	74.4	133	119	0	35	31
2014	7	24	19	57	0	0.83	-0.062	4.285	0.01	0.007	0	42.1	37.8	73.1	133	120	0	35	32
2014	7	24	20	7	0	0.843	-0.079	4.285	0.016	0.013	0	42.6	37.8	68.8	133	120	0	34	32
2014	7	24	20	17	0	0.843	-0.062	4.285	0.013	0.01	0	43	38.7	75.7	134	121	0	34	31
2014	7	24	20	27	0	0.81	-0.046	4.285	0.01	0.007	0	43.4	38.7	74	135	122	0	34	32
2014	7	24	20	37	0	0.853	-0.039	4.285	0.013	0.01	0	43	38.7	74	134	121	0	34	31
2014	7	24	20	47	0	0.879	-0.079	4.285	0.01	0.007	0	43	38.7	71.8	133	121	0	33	31
2014	7	24	20	57	0	0.869	-0.049	4.285	0.01	0.007	0	42.6	38.3	74.8	133	120	0	34	31
2014	7	24	21	7	0	0.846	-0.036	4.285	0.01	0.007	0	43	38.7	75.7	134	121	0	34	31
2014	7	24	21	17	0	0.869	-0.095	4.285	0.01	0.007	0	42.6	38.3	73.1	133	120	0	34	31
2014	7	24	21	27	0	0.869	-0.082	4.285	0.01	0.007	0	42.1	37.8	76.1	132	119	0	34	31
2014	7	24	21	37	0	0.915	-0.082	4.285	0.01	0.007	0	42.6	37.8	76.1	132	119	0	33	31
2014	7	24	21	47	0	0.902	-0.066	4.285	0.013	0.01	0	42.1	37	76.5	132	118	0	34	32
2014	7	24	21	57	0	0.833	-0.082	4.285	0.013	0.01	0	42.1	37.4	66.7	132	119	0	34	32
2014	7	24	22	7	0	0.853	-0.082	4.285	0.01	0.007	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	24	22	17	0	0.86	-0.082	4.285	0.01	0.007	0	41.7	37.4	69.2	131	118	0	34	31
2014	7	24	22	27	0	0.856	-0.043	4.285	0.016	0.013	0	42.6	38.3	75.7	133	120	0	34	31
2014	7	24	22	37	0	0.883	-0.062	4.285	0.013	0.01	0	42.1	38.3	75.7	132	120	0	34	31
2014	7	24	22	47	0	0.797	-0.085	4.285	0.013	0.01	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	24	22	57	0	0.886	-0.089	4.285	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	24	23	7	0	0.85	-0.062	4.285	0.01	0.007	0	42.1	37.8	75.7	133	120	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	24	23	17	0	0.85	-0.092	4.285	0.01	0.007	0	42.1	37.8	72.7	132	119	0	34	31
2014	7	24	23	27	0	0.83	-0.082	4.285	0.01	0.007	0	42.1	37.8	61.5	132	119	0	34	31
2014	7	24	23	37	0	0.794	-0.098	4.285	0.01	0.007	0	43	37.8	76.1	133	120	0	33	32
2014	7	24	23	47	0	0.843	-0.062	4.285	0.01	0.007	0	41.7	37.4	68.4	131	118	0	34	31
2014	7	24	23	57	0	0.843	-0.066	4.285	0.01	0.007	0	42.1	37.4	71	132	119	0	34	32
2014	7	25	0	7	0	0.84	-0.059	4.285	0.013	0.01	0	42.1	37.4	69.2	132	119	0	34	32
2014	7	25	0	17	0	0.846	-0.102	4.285	0.01	0.007	0	42.1	37.4	70.1	132	119	0	34	32
2014	7	25	0	27	0	0.886	-0.066	4.285	0.01	0.007	0	42.6	37.8	72.7	133	120	0	34	32
2014	7	25	0	37	0	0.85	-0.062	4.285	0.01	0.007	0	42.1	37.8	71.8	132	119	0	34	31
2014	7	25	0	47	0	0.853	-0.082	4.285	0.01	0.007	0	42.1	37.4	65.4	132	119	0	34	32
2014	7	25	0	57	0	0.889	-0.092	4.285	0.01	0.007	0	42.1	37.8	63.6	132	119	0	34	31
2014	7	25	1	7	0	0.892	-0.079	4.285	0.013	0.01	0	42.1	37.4	62.8	132	119	0	34	32
2014	7	25	1	17	0	0.833	-0.043	4.285	0.013	0.01	0	42.6	37.8	61.9	133	120	0	34	32
2014	7	25	1	27	0	0.863	-0.033	4.285	0.013	0.01	0	42.6	38.3	67.5	133	120	0	34	31
2014	7	25	1	37	0	0.86	-0.056	4.285	0.01	0.007	0	42.6	38.3	58.5	133	120	0	34	31
2014	7	25	1	47	0	0.866	-0.112	4.285	0.01	0.007	0	42.6	37.8	66.2	133	120	0	34	32
2014	7	25	1	57	0	0.83	-0.079	4.285	0.01	0.007	0	42.6	37.4	58	133	119	0	34	32
2014	7	25	2	7	0	0.85	-0.062	4.285	0.01	0.007	0	42.1	37.8	64.1	132	119	0	34	31
2014	7	25	2	17	0	0.853	-0.062	4.285	0.01	0.007	0	42.1	37.8	75.3	132	119	0	34	31
2014	7	25	2	27	0	0.85	-0.085	4.285	0.013	0.01	0	42.6	37.4	74.4	133	119	0	34	32
2014	7	25	2	37	0	0.837	-0.095	4.285	0.01	0.007	0	42.1	37.8	74.8	132	119	0	34	31
2014	7	25	2	47	0	0.814	-0.089	4.285	0.01	0.007	0	42.1	37.4	71.4	132	119	0	34	32
2014	7	25	2	57	0	0.879	-0.128	4.285	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	25	3	7	0	0.843	-0.089	4.285	0.013	0.01	0	42.6	37.4	75.7	133	119	0	34	32
2014	7	25	3	17	0	0.863	-0.072	4.285	0.01	0.007	0	42.6	37.4	74	133	119	0	34	32
2014	7	25	3	27	0	0.863	-0.082	4.285	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	25	3	37	0	0.843	-0.069	4.285	0.01	0.007	0	42.1	37.4	74.4	133	119	0	35	32
2014	7	25	3	47	0	0.879	-0.082	4.285	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	25	3	57	0	0.873	-0.079	4.285	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	25	4	7	0	0.863	-0.056	4.288	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	25	4	17	0	0.866	-0.052	4.288	0.016	0.013	0	43	38.3	73.1	134	121	0	34	32
2014	7	25	4	27	0	0.85	-0.062	4.285	0.01	0.007	0	43	38.7	74.4	134	121	0	34	31
2014	7	25	4	37	0	0.869	-0.062	4.288	0.01	0.007	0	42.6	38.3	74	133	120	0	34	31
2014	7	25	4	47	0	0.879	-0.082	4.288	0.01	0.007	0	43	37.8	74.4	134	120	0	34	32
2014	7	25	4	57	0	0.869	-0.075	4.288	0.01	0.007	0	43	38.3	73.1	134	121	0	34	32
2014	7	25	5	7	0	0.853	-0.095	4.288	0.01	0.007	0	43	38.7	72.2	134	121	0	34	31
2014	7	25	5	17	0	0.869	-0.098	4.288	0.01	0.007	0	43	38.7	72.2	135	122	0	35	32
2014	7	25	5	27	0	0.827	-0.075	4.288	0.013	0.01	0	43	38.7	72.2	135	122	0	35	32
2014	7	25	5	37	0	0.886	-0.108	4.288	0.013	0.01	0	43.4	39.1	71.8	135	122	0	34	31
2014	7	25	5	47	0	0.83	-0.062	4.288	0.013	0.01	0	43	38.7	73.1	135	122	0	35	32
2014	7	25	5	57	0	0.869	-0.095	4.288	0.013	0.01	0	43.4	38.3	71.8	135	121	0	34	32
2014	7	25	6	7	0	0.866	-0.062	4.288	0.01	0.007	0	42.6	38.3	72.2	134	121	0	35	32
2014	7	25	6	17	0	0.886	-0.062	4.291	0.013	0.01	0	43	38.3	71.8	134	121	0	34	32
2014	7	25	6	27	0	0.886	-0.082	4.295	0.01	0.007	0	43	38.3	72.7	134	121	0	34	32
2014	7	25	6	37	0	0.902	-0.052	4.298	0.01	0.007	0	42.6	38.3	73.1	133	120	0	34	31
2014	7	25	6	47	0	0.873	-0.039	4.298	0.01	0.007	0	42.6	37.4	71.4	133	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	6	57	0	0.866	-0.079	4.301	0.01	0.007	0	42.1	37.8	72.2	132	119	0	34	31
2014	7	25	7	7	0	0.827	-0.052	4.301	0.01	0.007	0	41.7	37.4	72.7	132	119	0	35	32
2014	7	25	7	17	0	0.879	-0.072	4.301	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	25	7	27	0	0.873	-0.089	4.301	0.01	0.007	0	42.6	37.4	73.5	133	119	0	34	32
2014	7	25	7	37	0	0.889	-0.105	4.301	0.01	0.007	0	41.7	37	73.5	132	119	0	35	33
2014	7	25	7	47	0	0.853	-0.079	4.301	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	25	7	57	0	0.85	-0.085	4.301	0.01	0.007	0	41.7	38.3	73.1	132	120	0	35	31
2014	7	25	8	7	0	0.86	-0.075	4.301	0.016	0.016	0	41.7	37.4	73.1	132	119	0	35	32
2014	7	25	8	17	0	0.883	-0.098	4.301	0.01	0.007	0	41.7	37.8	73.1	132	119	0	35	31
2014	7	25	8	27	0	0.876	-0.043	4.301	0.013	0.01	0	42.1	37.4	74	132	119	0	34	32
2014	7	25	8	37	0	0.876	-0.075	4.301	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	25	8	47	0	0.886	-0.075	4.301	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	25	8	57	0	0.866	-0.095	4.301	0.016	0.013	0	41.3	37.4	73.1	131	119	0	35	32
2014	7	25	9	7	0	0.853	-0.092	4.301	0.01	0.007	0	42.1	37	73.1	132	119	0	34	33
2014	7	25	9	17	0	0.869	-0.043	4.301	0.01	0.007	0	42.6	38.3	74	133	120	0	34	31
2014	7	25	9	27	0	0.899	-0.079	4.301	0.01	0.007	0	42.6	38.3	74	133	121	0	34	32
2014	7	25	9	37	0	0.879	-0.072	4.301	0.01	0.007	0	42.6	37.8	74.4	132	120	0	33	32
2014	7	25	9	47	0	0.883	-0.085	4.301	0.01	0.007	0	42.6	37.8	73.5	133	120	0	34	32
2014	7	25	9	57	0	0.892	-0.069	4.301	0.01	0.007	0	42.6	38.7	73.5	133	121	0	34	31
2014	7	25	10	7	0	0.873	-0.079	4.301	0.01	0.007	0	43	39.1	73.1	134	122	0	34	31
2014	7	25	10	17	0	0.84	-0.095	4.301	0.013	0.01	0	42.6	37.4	72.2	133	120	0	34	33
2014	7	25	10	27	0	0.827	-0.075	4.301	0.01	0.007	0	42.6	38.3	73.1	133	121	0	34	32
2014	7	25	10	37	0	0.869	-0.092	4.301	0.013	0.01	0	42.6	37.8	73.1	133	120	0	34	32
2014	7	25	10	47	0	0.886	-0.072	4.301	0.01	0.007	0	42.6	38.3	72.2	133	121	0	34	32
2014	7	25	10	57	0	0.889	-0.075	4.295	0.01	0.007	0	42.1	37.8	72.7	133	120	0	35	32
2014	7	25	11	7	0	0.876	-0.075	4.295	0.01	0.007	0	42.1	37.8	71.8	133	120	0	35	32
2014	7	25	11	17	0	0.876	-0.092	4.295	0.013	0.01	0	42.1	38.3	72.7	132	120	0	34	31
2014	7	25	11	27	0	0.863	-0.079	4.291	0.013	0.01	0	42.1	37.8	73.1	132	120	0	34	32
2014	7	25	11	37	0	0.846	-0.089	4.291	0.016	0.013	0	41.7	37.8	58.9	131	119	0	34	31
2014	7	25	11	47	0	0.85	-0.092	4.291	0.01	0.007	0	42.1	37.4	62.4	132	119	0	34	32
2014	7	25	11	57	0	0.873	-0.066	4.291	0.016	0.013	0	41.7	37.8	60.6	132	120	0	35	32
2014	7	25	12	7	0	0.876	-0.095	4.291	0.013	0.01	0	42.1	38.3	60.2	132	120	0	34	31
2014	7	25	12	17	0	0.85	-0.069	4.288	0.01	0.007	0	42.1	37	62.4	132	119	0	34	33
2014	7	25	12	27	0	0.81	-0.108	4.288	0.01	0.007	0	42.1	37.4	71.8	132	119	0	34	32
2014	7	25	12	37	0	0.843	-0.089	4.288	0.013	0.01	0	42.1	37.8	73.1	132	120	0	34	32
2014	7	25	12	47	0	0.86	-0.072	4.291	0.01	0.007	0	42.1	37.4	65.8	132	119	0	34	32
2014	7	25	12	57	0	0.84	-0.075	4.288	0.01	0.007	0	42.1	38.3	65.4	132	120	0	34	31
2014	7	25	13	7	0	0.86	-0.085	4.288	0.01	0.007	0	41.7	38.3	66.7	132	120	0	35	31
2014	7	25	13	17	0	0.856	-0.085	4.288	0.013	0.01	0	42.1	37.8	60.2	132	120	0	34	32
2014	7	25	13	27	0	0.86	-0.085	4.288	0.01	0.007	0	44.3	40	58	137	124	0	34	31
2014	7	25	13	37	0	0.876	-0.066	4.288	0.01	0.007	0	43.4	39.6	62.4	136	123	0	35	31
2014	7	25	13	47	0	0.83	-0.072	4.288	0.013	0.01	0	43.4	38.7	63.2	135	122	0	34	32
2014	7	25	13	57	0	0.876	-0.062	4.288	0.013	0.01	0	43	38.7	74	134	122	0	34	32
2014	7	25	14	7	0	0.86	-0.066	4.285	0.01	0.007	0	43.4	39.1	63.6	135	123	0	34	32
2014	7	25	14	17	0	0.883	-0.095	4.285	0.013	0.01	0	43.4	38.7	65.8	135	122	0	34	32
2014	7	25	14	27	0	0.879	-0.043	4.285	0.01	0.007	0	43	38.7	64.1	134	122	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	14	37	0	0.843	-0.072	4.285	0.01	0.007	0	42.6	38.7	74	133	121	0	34	31
2014	7	25	14	47	0	0.909	-0.105	4.285	0.016	0.013	0	42.6	37.8	77	132	119	0	33	31
2014	7	25	14	57	0	0.866	-0.079	4.285	0.013	0.01	0	43	38.3	63.6	134	121	0	34	32
2014	7	25	15	7	0	0.866	-0.062	4.285	0.01	0.007	0	42.1	37.8	70.5	132	120	0	34	32
2014	7	25	15	17	0	0.866	-0.043	4.285	0.01	0.007	0	42.6	38.3	70.1	133	121	0	34	32
2014	7	25	15	27	0	0.869	-0.049	4.285	0.013	0.01	0	42.6	39.1	68.8	134	122	0	35	31
2014	7	25	15	37	0	0.85	-0.092	4.285	0.01	0.007	0	43.4	38.7	69.7	135	122	0	34	32
2014	7	25	15	47	0	0.833	-0.075	4.285	0.01	0.007	0	43.4	38.7	67.9	135	122	0	34	32
2014	7	25	15	57	0	0.876	-0.056	4.285	0.01	0.007	0	43.4	39.6	67.9	135	123	0	34	31
2014	7	25	16	7	0	0.873	-0.049	4.281	0.01	0.007	0	43	38.7	67.1	134	122	0	34	32
2014	7	25	16	17	0	0.883	-0.075	4.281	0.01	0.007	0	43.4	38.7	67.1	135	122	0	34	32
2014	7	25	16	27	0	0.863	-0.079	4.281	0.01	0.007	0	43.4	38.7	67.9	135	122	0	34	32
2014	7	25	16	37	0	0.896	-0.043	4.275	0.01	0.007	0	46.4	42.1	48.6	142	130	0	34	32
2014	7	25	16	47	0	0.896	-0.062	4.275	0.013	0.01	0	45.6	41.3	49.5	140	127	0	34	31
2014	7	25	16	57	0	0.889	-0.052	4.275	0.01	0.007	0	45.6	40.9	50.7	140	126	0	34	31
2014	7	25	17	7	0	0.85	-0.059	4.278	0.01	0.007	0	43.4	39.1	57.6	135	122	0	34	31
2014	7	25	17	17	0	0.807	-0.036	4.275	0.01	0.007	0	44.3	40	57.2	137	124	0	34	31
2014	7	25	17	27	0	0.85	-0.043	4.278	0.01	0.007	0	43	39.1	66.2	134	122	0	34	31
2014	7	25	17	37	0	0.869	-0.059	4.272	0.013	0.01	0	46	41.7	49.9	141	128	0	34	31
2014	7	25	17	47	0	0.866	-0.079	4.278	0.01	0.007	0	42.6	38.3	68.4	133	121	0	34	32
2014	7	25	17	57	0	0.866	-0.072	4.278	0.01	0.007	0	42.6	38.3	68.8	133	121	0	34	32
2014	7	25	18	7	0	0.906	-0.079	4.275	0.01	0.007	0	43	38.7	67.1	134	121	0	34	31
2014	7	25	18	17	0	0.873	-0.069	4.275	0.01	0.007	0	42.6	37.8	70.5	133	120	0	34	32
2014	7	25	18	27	0	0.879	-0.059	4.275	0.01	0.007	0	42.6	37.8	70.1	133	120	0	34	32
2014	7	25	18	37	0	0.82	-0.049	4.275	0.013	0.01	0	42.6	38.3	64.1	134	121	0	35	32
2014	7	25	18	47	0	0.886	-0.066	4.275	0.01	0.007	0	42.6	37.8	70.1	133	120	0	34	32
2014	7	25	18	57	0	0.906	-0.085	4.272	0.01	0.007	0	42.6	37.8	69.7	133	120	0	34	32
2014	7	25	19	7	0	0.896	-0.105	4.275	0.01	0.007	0	42.6	38.3	73.5	133	120	0	34	31
2014	7	25	19	17	0	0.85	-0.062	4.275	0.01	0.007	0	42.1	38.3	73.1	133	120	0	35	31
2014	7	25	19	27	0	0.889	-0.069	4.275	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	25	19	37	0	0.873	-0.085	4.275	0.01	0.007	0	42.6	37.4	74	133	119	0	34	32
2014	7	25	19	47	0	0.86	-0.072	4.275	0.01	0.007	0	43	38.3	73.5	133	120	0	33	31
2014	7	25	19	57	0	0.869	-0.072	4.275	0.01	0.007	0	42.6	38.3	73.5	133	120	0	34	31
2014	7	25	20	7	0	0.883	-0.056	4.275	0.01	0.007	0	42.6	37.8	73.1	133	120	0	34	32
2014	7	25	20	17	0	0.827	-0.046	4.275	0.01	0.007	0	43	39.1	73.1	134	122	0	34	31
2014	7	25	20	27	0	0.866	-0.085	4.275	0.01	0.007	0	43.4	38.3	69.7	135	121	0	34	32
2014	7	25	20	37	0	0.853	-0.072	4.275	0.01	0.007	0	43.4	38.7	70.5	135	121	0	34	31
2014	7	25	20	47	0	0.886	-0.089	4.275	0.013	0.01	0	43	38.7	68.8	134	121	0	34	31
2014	7	25	20	57	0	0.912	-0.075	4.275	0.013	0.01	0	43	38.3	73.5	134	121	0	34	32
2014	7	25	21	7	0	0.85	-0.062	4.275	0.01	0.007	0	43	38.3	73.5	134	120	0	34	31
2014	7	25	21	17	0	0.879	-0.059	4.275	0.01	0.007	0	42.6	37.8	73.5	133	120	0	34	32
2014	7	25	21	27	0	0.896	-0.075	4.275	0.01	0.007	0	42.6	37.4	70.1	133	119	0	34	32
2014	7	25	21	37	0	0.863	-0.075	4.275	0.013	0.01	0	41.7	37.8	74.8	132	119	0	35	31
2014	7	25	21	47	0	0.82	-0.046	4.275	0.013	0.01	0	42.1	37.8	74	132	119	0	34	31
2014	7	25	21	57	0	0.896	-0.085	4.278	0.013	0.01	0	42.1	37.4	75.3	132	119	0	34	32
2014	7	25	22	7	0	0.833	-0.046	4.275	0.01	0.007	0	42.6	37.8	74.4	132	119	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	25	22	17	0	0.837	-0.082	4.275	0.01	0.007	0	42.1	37.8	74.8	132	119	0	34	31
2014	7	25	22	27	0	0.869	-0.079	4.278	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	25	22	37	0	0.892	-0.046	4.275	0.01	0.007	0	42.1	37.4	75.3	132	119	0	34	32
2014	7	25	22	47	0	0.83	-0.072	4.278	0.01	0.007	0	43	37.8	75.3	133	120	0	33	32
2014	7	25	22	57	0	0.883	-0.062	4.275	0.013	0.01	0	42.1	37.4	69.2	132	119	0	34	32
2014	7	25	23	7	0	0.925	-0.105	4.278	0.013	0.01	0	42.1	37.4	76.1	132	119	0	34	32
2014	7	25	23	17	0	0.853	-0.089	4.278	0.01	0.007	0	42.1	37.4	76.1	132	119	0	34	32
2014	7	25	23	27	0	0.863	-0.089	4.278	0.016	0.013	0	42.1	37.8	75.7	132	119	0	34	31
2014	7	25	23	37	0	0.879	-0.062	4.278	0.013	0.01	0	42.1	37.4	74	132	119	0	34	32
2014	7	25	23	47	0	0.833	-0.085	4.278	0.01	0.007	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	25	23	57	0	0.909	-0.056	4.278	0.01	0.007	0	42.1	37.4	76.1	132	119	0	34	32
2014	7	26	0	7	0	0.827	-0.039	4.278	0.01	0.007	0	42.6	37.8	77	133	119	0	34	31
2014	7	26	0	17	0	0.853	-0.062	4.278	0.01	0.007	0	42.6	37.4	77.4	133	119	0	34	32
2014	7	26	0	27	0	0.879	-0.079	4.278	0.01	0.007	0	42.1	37.4	77	132	119	0	34	32
2014	7	26	0	37	0	0.892	-0.085	4.278	0.016	0.013	0	42.1	37.4	75.7	132	119	0	34	32
2014	7	26	0	47	0	0.873	-0.085	4.278	0.01	0.007	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	26	0	57	0	0.843	-0.082	4.278	0.01	0.007	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	26	1	7	0	0.843	-0.059	4.278	0.013	0.01	0	42.1	38.3	77	133	120	0	35	31
2014	7	26	1	17	0	0.827	-0.069	4.278	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2014	7	26	1	27	0	0.879	-0.056	4.278	0.01	0.007	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	26	1	37	0	0.925	-0.108	4.278	0.01	0.007	0	42.1	37.4	76.5	132	119	0	34	32
2014	7	26	1	47	0	0.899	-0.085	4.278	0.01	0.007	0	42.6	37.8	77.4	133	120	0	34	32
2014	7	26	1	57	0	0.853	-0.049	4.281	0.01	0.007	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	26	2	7	0	0.873	-0.062	4.278	0.01	0.007	0	42.6	37.8	76.1	133	120	0	34	32
2014	7	26	2	17	0	0.889	-0.072	4.281	0.013	0.01	0	43	37.8	76.5	134	120	0	34	32
2014	7	26	2	27	0	0.906	-0.062	4.281	0.01	0.007	0	42.1	37.8	76.1	133	120	0	35	32
2014	7	26	2	37	0	0.915	-0.095	4.281	0.01	0.007	0	43	38.3	75.7	134	121	0	34	32
2014	7	26	2	47	0	0.915	-0.075	4.281	0.01	0.007	0	43	37.8	75.7	134	120	0	34	32
2014	7	26	2	57	0	0.846	-0.066	4.281	0.01	0.007	0	43.4	38.3	75.7	134	121	0	33	32
2014	7	26	3	7	0	0.902	-0.046	4.281	0.013	0.01	0	43	38.3	75.3	134	121	0	34	32
2014	7	26	3	17	0	0.85	-0.079	4.281	0.01	0.007	0	42.6	38.3	76.1	133	120	0	34	31
2014	7	26	3	27	0	0.863	-0.128	4.285	0.016	0.013	0	42.6	37.8	75.3	133	120	0	34	32
2014	7	26	3	37	0	0.886	-0.056	4.285	0.013	0.01	0	43	38.3	75.3	134	121	0	34	32
2014	7	26	3	47	0	0.883	-0.085	4.285	0.01	0.007	0	42.6	38.7	74.8	134	121	0	35	31
2014	7	26	3	57	0	0.925	-0.052	4.288	0.01	0.007	0	43	37.8	73.1	133	120	0	33	32
2014	7	26	4	7	0	0.837	-0.089	4.288	0.013	0.01	0	42.6	38.3	73.5	134	121	0	35	32
2014	7	26	4	17	0	0.833	-0.062	4.288	0.013	0.01	0	43	38.7	73.1	134	121	0	34	31
2014	7	26	4	27	0	0.84	-0.046	4.298	0.01	0.007	0	43	38.3	73.1	134	121	0	34	32
2014	7	26	4	37	0	0.853	-0.095	4.301	0.01	0.007	0	42.6	38.3	73.1	134	121	0	35	32
2014	7	26	4	47	0	0.899	-0.089	4.301	0.013	0.01	0	43.4	38.7	74	135	122	0	34	32
2014	7	26	4	57	0	0.915	-0.046	4.304	0.01	0.007	0	43.4	39.1	74	135	122	0	34	31
2014	7	26	5	7	0	0.873	-0.049	4.308	0.01	0.007	0	43.4	39.1	75.7	135	122	0	34	31
2014	7	26	5	17	0	0.892	-0.075	4.308	0.013	0.01	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	26	5	27	0	0.863	-0.112	4.308	0.01	0.007	0	43.4	38.7	74.8	135	122	0	34	32
2014	7	26	5	37	0	0.935	-0.075	4.311	0.01	0.007	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	26	5	47	0	0.873	-0.079	4.311	0.01	0.007	0	43.9	38.3	75.7	136	122	0	34	33

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	5	57	0	0.866	-0.095	4.311	0.013	0.01	0	43.9	38.7	77	136	123	0	34	33
2014	7	26	6	7	0	0.883	-0.092	4.311	0.01	0.007	0	43.4	38.7	76.5	135	122	0	34	32
2014	7	26	6	17	0	0.892	-0.092	4.314	0.01	0.007	0	43	38.3	76.5	134	121	0	34	32
2014	7	26	6	27	0	0.896	-0.079	4.314	0.01	0.007	0	43	38.3	75.7	134	121	0	34	32
2014	7	26	6	37	0	0.866	-0.059	4.314	0.013	0.01	0	43	38.3	75.7	134	121	0	34	32
2014	7	26	6	47	0	0.928	-0.082	4.318	0.01	0.007	0	43	38.3	74.8	134	121	0	34	32
2014	7	26	6	57	0	0.886	-0.079	4.318	0.01	0.007	0	42.6	38.3	74	134	121	0	35	32
2014	7	26	7	7	0	0.869	-0.118	4.318	0.01	0.007	0	43	38.3	74.4	134	121	0	34	32
2014	7	26	7	17	0	0.922	-0.075	4.321	0.01	0.007	0	43	38.3	74	134	121	0	34	32
2014	7	26	7	27	0	0.912	-0.059	4.321	0.01	0.007	0	42.6	38.7	73.1	134	121	0	35	31
2014	7	26	7	37	0	0.889	-0.079	4.327	0.01	0.007	0	43	38.3	72.2	134	121	0	34	32
2014	7	26	7	47	0	0.863	-0.102	4.334	0.01	0.007	0	43	38.7	72.2	134	121	0	34	31
2014	7	26	7	57	0	0.896	-0.066	4.337	0.01	0.007	0	42.6	37.8	74	133	120	0	34	32
2014	7	26	8	7	0	0.896	-0.082	4.341	0.01	0.007	0	42.6	38.3	74.4	133	121	0	34	32
2014	7	26	8	17	0	0.925	-0.092	4.341	0.01	0.007	0	42.6	38.3	75.3	133	121	0	34	32
2014	7	26	8	27	0	0.876	-0.095	4.344	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2014	7	26	8	37	0	0.912	-0.075	4.344	0.01	0.007	0	42.1	37.8	76.5	133	120	0	35	32
2014	7	26	8	47	0	0.899	-0.079	4.347	0.01	0.007	0	42.6	38.3	77	134	121	0	35	32
2014	7	26	8	57	0	0.869	-0.092	4.347	0.01	0.007	0	42.6	38.3	76.5	133	121	0	34	32
2014	7	26	9	7	0	0.863	-0.072	4.347	0.01	0.007	0	42.6	38.7	76.5	133	121	0	34	31
2014	7	26	9	17	0	0.919	-0.102	4.35	0.01	0.007	0	42.6	37.8	76.5	133	120	0	34	32
2014	7	26	9	27	0	0.906	-0.092	4.35	0.01	0.007	0	42.1	37.8	76.5	132	120	0	34	32
2014	7	26	9	37	0	0.906	-0.092	4.35	0.01	0.007	0	42.1	38.3	75.7	133	121	0	35	32
2014	7	26	9	47	0	0.902	-0.108	4.354	0.01	0.007	0	42.1	38.3	75.7	133	120	0	35	31
2014	7	26	9	57	0	0.928	-0.082	4.354	0.01	0.007	0	42.1	37.8	76.1	133	121	0	35	33
2014	7	26	10	7	0	0.879	-0.089	4.354	0.01	0.007	0	42.1	37.8	75.7	133	120	0	35	32
2014	7	26	10	17	0	0.863	-0.089	4.357	0.01	0.007	0	42.1	38.7	74	133	121	0	35	31
2014	7	26	10	27	0	0.876	-0.092	4.357	0.01	0.007	0	42.1	37.8	74.4	133	120	0	35	32
2014	7	26	10	37	0	0.899	-0.069	4.36	0.01	0.007	0	42.6	37.8	74	133	120	0	34	32
2014	7	26	10	47	0	0.892	-0.102	4.36	0.013	0.01	0	41.7	37.8	74.8	131	119	0	34	31
2014	7	26	10	57	0	0.922	-0.098	4.36	0.01	0.007	0	42.1	37.8	73.5	132	120	0	34	32
2014	7	26	11	7	0	0.886	-0.049	4.364	0.016	0.013	0	42.1	37.4	72.7	132	119	0	34	32
2014	7	26	11	17	0	0.886	-0.069	4.364	0.01	0.007	0	41.7	37.4	73.1	131	119	0	34	32
2014	7	26	11	27	0	0.85	-0.102	4.367	0.01	0.007	0	41.7	37.4	72.7	131	118	0	34	31
2014	7	26	11	37	0	0.932	-0.079	4.37	0.01	0.007	0	41.7	37	71.8	131	118	0	34	32
2014	7	26	11	47	0	0.892	-0.052	4.373	0.01	0.007	0	41.7	37	71.4	131	118	0	34	32
2014	7	26	11	57	0	0.873	-0.052	4.38	0.01	0.007	0	41.3	36.5	73.1	130	118	0	34	33
2014	7	26	12	7	0	0.86	-0.052	4.38	0.01	0.007	0	40.9	37	72.7	130	118	0	35	32
2014	7	26	12	17	0	0.902	-0.102	4.383	0.01	0.007	0	41.3	37	73.1	130	118	0	34	32
2014	7	26	12	27	0	0.928	-0.066	4.383	0.01	0.007	0	41.3	37	74	130	118	0	34	32
2014	7	26	12	37	0	0.843	-0.075	4.386	0.013	0.01	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	26	12	47	0	0.919	-0.095	4.386	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	26	12	57	0	0.879	-0.089	4.386	0.01	0.007	0	40.4	36.5	73.5	129	117	0	35	32
2014	7	26	13	7	0	0.876	-0.075	4.386	0.01	0.007	0	40.9	37	72.2	129	117	0	34	31
2014	7	26	13	17	0	0.873	-0.079	4.39	0.01	0.007	0	40.9	36.5	71.4	129	117	0	34	32
2014	7	26	13	27	0	0.886	-0.095	4.39	0.01	0.007	0	40.9	37	61.9	129	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	13	37	0	0.899	-0.118	4.39	0.01	0.007	0	40.9	36.5	64.9	129	117	0	34	32
2014	7	26	13	47	0	0.915	-0.095	4.393	0.01	0.007	0	41.3	37	72.2	130	118	0	34	32
2014	7	26	13	57	0	0.863	-0.079	4.393	0.01	0.007	0	41.3	37.4	65.4	130	118	0	34	31
2014	7	26	14	7	0	0.892	-0.085	4.393	0.01	0.007	0	40.9	36.5	69.2	130	117	0	35	32
2014	7	26	14	17	0	0.876	-0.089	4.393	0.01	0.007	0	40.9	37	67.1	129	117	0	34	31
2014	7	26	14	27	0	0.833	-0.092	4.393	0.01	0.007	0	41.7	37.4	61.1	131	118	0	34	31
2014	7	26	14	37	0	0.876	-0.046	4.396	0.01	0.007	0	41.3	37	58.5	130	118	0	34	32
2014	7	26	14	47	0	0.846	-0.066	4.396	0.01	0.007	0	41.7	37.4	55.9	131	118	0	34	31
2014	7	26	14	57	0	0.863	-0.059	4.396	0.01	0.007	0	41.7	37.4	56.8	131	119	0	34	32
2014	7	26	15	7	0	0.853	-0.082	4.396	0.01	0.007	0	41.7	37	60.6	131	118	0	34	32
2014	7	26	15	17	0	0.863	-0.062	4.396	0.013	0.01	0	41.7	37	60.2	131	118	0	34	32
2014	7	26	15	27	0	0.925	-0.075	4.396	0.01	0.007	0	41.7	37	60.2	131	118	0	34	32
2014	7	26	15	37	0	0.866	-0.079	4.396	0.01	0.007	0	41.7	37	63.2	131	118	0	34	32
2014	7	26	15	47	0	0.879	-0.072	4.396	0.01	0.007	0	42.1	37.4	58	131	119	0	33	32
2014	7	26	15	57	0	0.896	-0.066	4.4	0.01	0.007	0	41.7	37	61.9	131	118	0	34	32
2014	7	26	16	7	0	0.925	-0.079	4.4	0.01	0.007	0	41.3	36.5	58	130	117	0	34	32
2014	7	26	16	17	0	0.873	-0.079	4.4	0.01	0.007	0	41.3	37.4	59.3	130	118	0	34	31
2014	7	26	16	27	0	0.869	-0.066	4.4	0.01	0.007	0	41.7	37	61.5	131	118	0	34	32
2014	7	26	16	37	0	0.883	-0.092	4.4	0.01	0.007	0	41.7	37.4	61.1	132	119	0	35	32
2014	7	26	16	47	0	0.827	-0.049	4.403	0.01	0.007	0	41.7	37.8	57.6	131	119	0	34	31
2014	7	26	16	57	0	0.846	-0.115	4.403	0.01	0.007	0	42.1	37.8	62.4	132	119	0	34	31
2014	7	26	17	7	0	0.879	-0.066	4.4	0.01	0.007	0	42.1	37.8	65.8	132	119	0	34	31
2014	7	26	17	17	0	0.873	-0.092	4.403	0.01	0.007	0	42.1	37.4	68.8	132	119	0	34	32
2014	7	26	17	27	0	0.853	-0.082	4.403	0.01	0.007	0	42.1	37.4	57.6	132	119	0	34	32
2014	7	26	17	37	0	0.866	-0.095	4.403	0.01	0.007	0	42.1	37.4	61.1	132	119	0	34	32
2014	7	26	17	47	0	0.86	-0.079	4.403	0.01	0.007	0	42.1	37.4	56.8	132	119	0	34	32
2014	7	26	17	57	0	0.879	-0.102	4.403	0.01	0.007	0	42.6	37.8	58.9	133	120	0	34	32
2014	7	26	18	7	0	0.863	-0.095	4.403	0.01	0.007	0	42.6	38.3	64.5	133	120	0	34	31
2014	7	26	18	17	0	0.896	-0.069	4.403	0.01	0.007	0	42.6	37.4	63.6	132	119	0	33	32
2014	7	26	18	27	0	0.892	-0.056	4.403	0.01	0.007	0	41.7	37.4	64.5	132	119	0	35	32
2014	7	26	18	37	0	0.863	-0.082	4.403	0.01	0.007	0	42.1	37.8	67.1	132	119	0	34	31
2014	7	26	18	47	0	0.886	-0.066	4.406	0.01	0.007	0	42.6	37.4	60.6	133	119	0	34	32
2014	7	26	18	57	0	0.843	-0.079	4.406	0.013	0.01	0	42.6	38.3	74.4	133	120	0	34	31
2014	7	26	19	7	0	0.876	-0.056	4.406	0.01	0.007	0	43	38.3	74	134	121	0	34	32
2014	7	26	19	17	0	0.879	-0.056	4.406	0.01	0.007	0	42.6	37.8	74	133	119	0	34	31
2014	7	26	19	27	0	0.86	-0.056	4.409	0.01	0.007	0	42.6	38.3	74	133	120	0	34	31
2014	7	26	19	37	0	0.853	-0.039	4.409	0.016	0.016	0	42.1	37.4	75.3	133	119	0	35	32
2014	7	26	19	47	0	0.912	-0.075	4.409	0.01	0.007	0	42.1	37.4	74.4	132	119	0	34	32
2014	7	26	19	57	0	0.899	-0.046	4.409	0.013	0.01	0	42.6	37.8	74	133	119	0	34	31
2014	7	26	20	7	0	0.892	-0.089	4.409	0.01	0.007	0	42.6	37.4	73.1	133	119	0	34	32
2014	7	26	20	17	0	0.873	-0.062	4.409	0.01	0.007	0	42.6	37.8	74	133	120	0	34	32
2014	7	26	20	27	0	0.896	-0.092	4.413	0.013	0.01	0	42.1	37.8	71.4	133	119	0	35	31
2014	7	26	20	37	0	0.86	-0.072	4.413	0.013	0.01	0	42.6	37.4	70.1	133	119	0	34	32
2014	7	26	20	47	0	0.879	-0.056	4.413	0.013	0.01	0	42.6	37.4	68.4	133	119	0	34	32
2014	7	26	20	57	0	0.866	-0.079	4.416	0.01	0.007	0	42.6	37.8	70.1	133	119	0	34	31
2014	7	26	21	7	0	0.886	-0.062	4.419	0.01	0.007	0	42.1	37.4	71	132	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	26	21	17	0	0.84	-0.036	4.419	0.01	0.007	0	42.6	37.8	68.8	133	120	0	34	32
2014	7	26	21	27	0	0.863	-0.046	4.419	0.01	0.007	0	42.1	37.8	64.1	133	120	0	35	32
2014	7	26	21	37	0	0.863	-0.062	4.419	0.01	0.007	0	43	38.3	68.4	134	121	0	34	32
2014	7	26	21	47	0	0.876	-0.075	4.423	0.01	0.007	0	42.6	38.3	67.5	133	120	0	34	31
2014	7	26	21	57	0	0.886	-0.046	4.423	0.013	0.01	0	42.6	37.8	64.9	133	120	0	34	32
2014	7	26	22	7	0	0.892	-0.079	4.426	0.01	0.007	0	42.6	37.8	64.5	133	120	0	34	32
2014	7	26	22	17	0	0.86	-0.075	4.426	0.01	0.007	0	43	37.8	73.1	134	120	0	34	32
2014	7	26	22	27	0	0.876	-0.033	4.426	0.01	0.007	0	43	38.7	73.5	134	121	0	34	31
2014	7	26	22	37	0	0.85	-0.043	4.426	0.01	0.007	0	43	38.3	73.5	133	120	0	33	31
2014	7	26	22	47	0	0.85	-0.036	4.429	0.01	0.007	0	42.1	37.8	74	133	120	0	35	32
2014	7	26	22	57	0	0.899	-0.052	4.429	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	26	23	7	0	0.892	-0.062	4.429	0.01	0.007	0	42.6	38.3	73.5	133	120	0	34	31
2014	7	26	23	17	0	0.86	-0.062	4.429	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	26	23	27	0	0.837	-0.039	4.429	0.013	0.01	0	42.6	38.3	73.5	133	120	0	34	31
2014	7	26	23	37	0	0.837	-0.046	4.429	0.01	0.007	0	42.1	38.3	74.4	132	120	0	34	31
2014	7	26	23	47	0	0.866	-0.069	4.426	0.013	0.01	0	42.1	38.3	65.8	133	120	0	35	31
2014	7	26	23	57	0	0.889	-0.069	4.429	0.01	0.007	0	42.6	38.3	74.4	133	120	0	34	31
2014	7	27	0	7	0	0.863	-0.043	4.429	0.01	0.007	0	42.6	38.3	74	133	121	0	34	32
2014	7	27	0	17	0	0.899	-0.069	4.429	0.01	0.007	0	42.1	37.4	73.1	132	119	0	34	32
2014	7	27	0	27	0	0.883	-0.062	4.429	0.01	0.007	0	41.7	37.4	74.4	132	119	0	35	32
2014	7	27	0	37	0	0.912	-0.072	4.429	0.013	0.01	0	41.3	37	74.4	131	118	0	35	32
2014	7	27	0	47	0	0.86	-0.033	4.429	0.01	0.007	0	41.3	36.5	74.4	131	117	0	35	32
2014	7	27	0	57	0	0.925	-0.062	4.429	0.01	0.007	0	41.7	37	75.3	131	118	0	34	32
2014	7	27	1	7	0	0.856	-0.069	4.429	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	27	1	17	0	0.889	-0.036	4.426	0.01	0.007	0	42.1	37.4	74.8	132	119	0	34	32
2014	7	27	1	27	0	0.896	-0.082	4.426	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	27	1	37	0	0.932	-0.092	4.426	0.01	0.007	0	42.6	37	74.4	132	118	0	33	32
2014	7	27	1	47	0	0.909	-0.059	4.426	0.01	0.007	0	42.1	37.4	73.5	131	118	0	33	31
2014	7	27	1	57	0	0.883	-0.079	4.426	0.01	0.007	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	27	2	7	0	0.889	-0.066	4.426	0.01	0.007	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	27	2	17	0	0.886	-0.049	4.426	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	27	2	27	0	0.873	-0.075	4.426	0.013	0.01	0	41.3	37.4	74.8	131	118	0	35	31
2014	7	27	2	37	0	0.879	-0.049	4.426	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	27	2	47	0	0.915	-0.059	4.426	0.01	0.007	0	41.7	37.4	74.4	131	118	0	34	31
2014	7	27	2	57	0	0.889	-0.098	4.426	0.01	0.007	0	42.1	37	74.4	131	118	0	33	32
2014	7	27	3	7	0	0.873	-0.089	4.423	0.01	0.007	0	41.7	37	74	131	118	0	34	32
2014	7	27	3	17	0	0.906	-0.069	4.423	0.01	0.007	0	41.7	37	74.4	131	118	0	34	32
2014	7	27	3	27	0	0.906	-0.072	4.423	0.01	0.007	0	41.7	37	71	131	118	0	34	32
2014	7	27	3	37	0	0.86	-0.069	4.423	0.01	0.007	0	41.3	37	74	131	118	0	35	32
2014	7	27	3	47	0	0.873	-0.059	4.423	0.01	0.007	0	41.7	37.4	73.5	131	118	0	34	31
2014	7	27	3	57	0	0.883	-0.069	4.423	0.01	0.007	0	41.7	37	72.7	131	118	0	34	32
2014	7	27	4	7	0	0.902	-0.105	4.423	0.01	0.007	0	41.7	37.4	74	131	119	0	34	32
2014	7	27	4	17	0	0.863	-0.062	4.419	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	27	4	27	0	0.846	-0.079	4.423	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	27	4	37	0	0.886	-0.079	4.419	0.01	0.007	0	42.1	37.4	74	132	119	0	34	32
2014	7	27	4	47	0	0.886	-0.062	4.419	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	4	57	0	0.899	-0.079	4.419	0.01	0.007	0	42.6	37.8	73.1	133	120	0	34	32
2014	7	27	5	7	0	0.856	-0.062	4.419	0.01	0.007	0	42.1	37.8	73.5	132	119	0	34	31
2014	7	27	5	17	0	0.912	-0.056	4.419	0.01	0.007	0	42.1	37.8	73.5	132	120	0	34	32
2014	7	27	5	27	0	0.86	-0.069	4.419	0.01	0.007	0	42.1	37.8	73.1	132	120	0	34	32
2014	7	27	5	37	0	0.922	-0.046	4.419	0.01	0.007	0	42.1	37.4	72.7	132	119	0	34	32
2014	7	27	5	47	0	0.833	-0.085	4.419	0.01	0.007	0	42.1	38.3	72.7	132	120	0	34	31
2014	7	27	5	57	0	0.84	-0.072	4.419	0.01	0.007	0	42.6	37.4	72.7	133	119	0	34	32
2014	7	27	6	7	0	0.915	-0.056	4.416	0.01	0.007	0	42.1	37.4	72.7	132	119	0	34	32
2014	7	27	6	17	0	0.892	-0.079	4.416	0.016	0.013	0	42.1	37	71.8	132	119	0	34	33
2014	7	27	6	27	0	0.906	-0.092	4.416	0.01	0.007	0	42.1	37.4	71.4	132	119	0	34	32
2014	7	27	6	37	0	0.876	-0.046	4.416	0.01	0.007	0	41.3	37.8	72.2	131	119	0	35	31
2014	7	27	6	47	0	0.866	-0.043	4.416	0.01	0.007	0	41.3	37	72.7	131	118	0	35	32
2014	7	27	6	57	0	0.843	-0.062	4.416	0.01	0.007	0	41.7	37	73.1	131	118	0	34	32
2014	7	27	7	7	0	0.879	-0.049	4.416	0.013	0.01	0	41.3	36.5	72.7	130	117	0	34	32
2014	7	27	7	17	0	0.922	-0.082	4.416	0.01	0.007	0	41.7	37	73.5	131	118	0	34	32
2014	7	27	7	27	0	0.886	-0.079	4.416	0.01	0.007	0	40.9	36.5	73.5	130	117	0	35	32
2014	7	27	7	37	0	0.899	-0.046	4.416	0.013	0.01	0	41.3	36.5	72.2	130	117	0	34	32
2014	7	27	7	47	0	0.906	-0.046	4.416	0.01	0.007	0	40.9	37	72.7	130	117	0	35	31
2014	7	27	7	57	0	0.886	-0.079	4.416	0.01	0.007	0	40.9	36.5	72.2	130	117	0	35	32
2014	7	27	8	7	0	0.902	-0.072	4.419	0.01	0.007	0	40.9	37	72.7	129	117	0	34	31
2014	7	27	8	17	0	0.879	-0.056	4.419	0.01	0.007	0	41.3	36.5	72.7	130	117	0	34	32
2014	7	27	8	27	0	0.879	-0.082	4.416	0.01	0.007	0	41.3	37	73.1	130	118	0	34	32
2014	7	27	8	37	0	0.863	-0.082	4.416	0.013	0.01	0	41.3	37	73.5	130	117	0	34	31
2014	7	27	8	47	0	0.856	-0.049	4.419	0.01	0.007	0	41.3	36.5	72.2	130	117	0	34	32
2014	7	27	8	57	0	0.932	-0.052	4.419	0.01	0.007	0	40.9	36.5	73.5	129	117	0	34	32
2014	7	27	9	7	0	0.886	-0.059	4.419	0.013	0.01	0	40.9	36.5	73.1	130	117	0	35	32
2014	7	27	9	17	0	0.899	-0.089	4.419	0.01	0.007	0	41.3	36.5	73.1	130	117	0	34	32
2014	7	27	9	27	0	0.932	-0.066	4.419	0.01	0.007	0	41.3	36.5	73.1	130	117	0	34	32
2014	7	27	9	37	0	0.899	-0.085	4.419	0.01	0.007	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	27	9	47	0	0.912	-0.098	4.419	0.01	0.007	0	40.9	36.1	72.7	129	116	0	34	32
2014	7	27	9	57	0	0.932	-0.069	4.419	0.013	0.01	0	40.9	36.5	73.5	130	117	0	35	32
2014	7	27	10	7	0	0.879	-0.079	4.419	0.01	0.007	0	40.9	36.5	73.5	129	117	0	34	32
2014	7	27	10	17	0	0.909	-0.085	4.419	0.01	0.007	0	40.9	36.1	74	129	116	0	34	32
2014	7	27	10	27	0	0.86	-0.095	4.419	0.01	0.007	0	40.9	37	72.7	129	117	0	34	31
2014	7	27	10	37	0	0.856	-0.095	4.419	0.01	0.007	0	41.3	37	71.8	130	117	0	34	31
2014	7	27	10	47	0	0.883	-0.052	4.419	0.013	0.01	0	40.9	36.5	72.2	129	116	0	34	31
2014	7	27	10	57	0	0.886	-0.049	4.419	0.01	0.007	0	40.9	36.5	72.2	129	117	0	34	32
2014	7	27	11	7	0	0.928	-0.089	4.423	0.016	0.013	0	41.3	36.5	72.7	130	117	0	34	32
2014	7	27	11	17	0	0.906	-0.098	4.419	0.01	0.007	0	40.4	36.5	71.8	129	117	0	35	32
2014	7	27	11	27	0	0.906	-0.082	4.419	0.01	0.007	0	40.9	37	73.1	129	117	0	34	31
2014	7	27	11	37	0	0.909	-0.059	4.419	0.01	0.007	0	40.9	36.1	72.7	129	116	0	34	32
2014	7	27	11	47	0	0.896	-0.079	4.416	0.01	0.007	0	40.9	36.1	68.4	129	116	0	34	32
2014	7	27	11	57	0	0.892	-0.062	4.419	0.01	0.007	0	40.9	36.5	72.7	129	117	0	34	32
2014	7	27	12	7	0	0.846	-0.046	4.416	0.01	0.007	0	40.4	36.1	65.4	129	116	0	35	32
2014	7	27	12	17	0	0.889	-0.075	4.413	0.01	0.007	0	40.9	37	67.1	129	117	0	34	31
2014	7	27	12	27	0	0.889	-0.085	4.416	0.01	0.007	0	40.9	36.1	57.2	129	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	12	37	0	0.886	-0.095	4.416	0.01	0.007	0	41.3	37.4	57.6	130	118	0	34	31
2014	7	27	12	47	0	0.879	-0.046	4.416	0.01	0.007	0	41.3	37.4	54.2	130	118	0	34	31
2014	7	27	12	57	0	0.863	-0.112	4.413	0.01	0.007	0	41.3	37	58.5	130	118	0	34	32
2014	7	27	13	7	0	0.899	-0.092	4.413	0.01	0.007	0	41.3	37.4	55.9	130	118	0	34	31
2014	7	27	13	17	0	0.879	-0.072	4.413	0.01	0.007	0	41.3	37	71	130	118	0	34	32
2014	7	27	13	27	0	0.879	-0.066	4.413	0.01	0.007	0	40.9	37	62.4	130	118	0	35	32
2014	7	27	13	37	0	0.86	-0.079	4.413	0.016	0.013	0	41.7	37	65.8	131	118	0	34	32
2014	7	27	13	47	0	0.912	-0.092	4.413	0.01	0.007	0	41.3	37	58.9	130	118	0	34	32
2014	7	27	13	57	0	0.856	-0.043	4.413	0.01	0.007	0	40.9	36.1	61.1	129	116	0	34	32
2014	7	27	14	7	0	0.902	-0.082	4.416	0.01	0.007	0	42.1	38.3	55	132	120	0	34	31
2014	7	27	14	17	0	0.906	-0.059	4.413	0.013	0.01	0	42.6	38.3	59.8	133	120	0	34	31
2014	7	27	14	27	0	0.873	-0.052	4.413	0.013	0.01	0	41.7	37.4	56.8	131	119	0	34	32
2014	7	27	14	37	0	0.906	-0.052	4.413	0.01	0.007	0	42.1	37.8	60.6	132	120	0	34	32
2014	7	27	14	47	0	0.873	-0.043	4.413	0.01	0.007	0	41.7	37.8	68.8	131	119	0	34	31
2014	7	27	14	57	0	0.915	-0.069	4.413	0.01	0.007	0	41.3	37.4	73.1	130	118	0	34	31
2014	7	27	15	7	0	0.899	-0.069	4.413	0.01	0.007	0	41.7	37	71.4	131	118	0	34	32
2014	7	27	15	17	0	0.938	-0.075	4.413	0.01	0.007	0	41.3	37	74.8	130	117	0	34	31
2014	7	27	15	27	0	0.892	-0.089	4.409	0.01	0.007	0	42.1	37.8	48.6	132	119	0	34	31
2014	7	27	15	37	0	0.942	-0.072	4.413	0.01	0.007	0	41.7	38.3	53.3	132	120	0	35	31
2014	7	27	15	47	0	0.863	-0.085	4.413	0.01	0.007	0	41.3	36.5	70.1	130	117	0	34	32
2014	7	27	15	57	0	0.896	-0.092	4.413	0.01	0.007	0	40.9	36.5	61.1	129	117	0	34	32
2014	7	27	16	7	0	0.85	-0.033	4.413	0.01	0.007	0	42.6	38.3	51.6	133	120	0	34	31
2014	7	27	16	17	0	0.899	-0.062	4.413	0.016	0.013	0	41.3	37	51.2	130	118	0	34	32
2014	7	27	16	27	0	0.886	-0.085	4.413	0.01	0.007	0	40.4	36.1	59.3	128	115	0	34	31
2014	7	27	16	37	0	0.892	-0.112	4.413	0.01	0.007	0	40.4	36.1	68.4	128	115	0	34	31
2014	7	27	16	47	0	0.866	-0.03	4.413	0.016	0.013	0	40.4	36.1	65.4	128	116	0	34	32
2014	7	27	16	57	0	0.886	-0.095	4.413	0.01	0.007	0	49	44.7	42.6	148	136	0	34	32
2014	7	27	17	7	0	0.942	-0.082	4.416	0.01	0.007	0	49.5	45.6	41.3	149	137	0	34	31
2014	7	27	17	17	0	0.928	-0.036	4.419	0.01	0.007	0	43.4	38.3	47.3	135	121	0	34	32
2014	7	27	17	27	0	0.899	-0.085	4.416	0.01	0.007	0	42.6	38.3	53.3	133	120	0	34	31
2014	7	27	17	37	0	0.886	-0.079	4.416	0.01	0.007	0	42.6	38.3	48.6	133	121	0	34	32
2014	7	27	17	47	0	0.866	-0.033	4.416	0.01	0.007	0	40.9	37	57.6	129	117	0	34	31
2014	7	27	17	57	0	0.869	-0.043	4.416	0.01	0.007	0	41.3	36.5	72.7	129	117	0	33	32
2014	7	27	18	7	0	0.906	-0.059	4.419	0.01	0.007	0	42.6	38.3	46.9	133	120	0	34	31
2014	7	27	18	17	0	0.866	-0.092	4.419	0.01	0.007	0	42.1	37.8	54.6	132	119	0	34	31
2014	7	27	18	27	0	0.899	-0.079	4.416	0.01	0.007	0	40.9	37	73.5	129	117	0	34	31
2014	7	27	18	37	0	0.856	-0.052	4.419	0.01	0.007	0	40.9	37	70.1	129	117	0	34	31
2014	7	27	18	47	0	0.886	-0.072	4.419	0.01	0.007	0	40.4	36.5	71.8	129	116	0	35	31
2014	7	27	18	57	0	0.85	-0.056	4.419	0.01	0.007	0	41.3	37	72.2	130	117	0	34	31
2014	7	27	19	7	0	0.879	-0.052	4.419	0.013	0.01	0	41.3	37	72.7	130	117	0	34	31
2014	7	27	19	17	0	0.869	-0.089	4.426	0.01	0.007	0	41.3	36.5	70.5	130	117	0	34	32
2014	7	27	19	27	0	0.846	-0.098	4.423	0.016	0.013	0	40.9	36.5	71.8	129	117	0	34	32
2014	7	27	19	37	0	0.876	-0.089	4.426	0.01	0.007	0	42.1	38.3	55	132	120	0	34	31
2014	7	27	19	47	0	0.804	-0.056	4.426	0.01	0.007	0	43	38.7	55.5	134	122	0	34	32
2014	7	27	19	57	0	0.853	-0.089	4.423	0.013	0.01	0	42.6	38.3	55.9	133	121	0	34	32
2014	7	27	20	7	0	0.85	-0.095	4.426	0.01	0.007	0	43.9	40	54.2	136	124	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	27	20	17	0	0.879	-0.069	4.429	0.01	0.007	0	43.9	39.6	58.5	136	124	0	34	32
2014	7	27	20	27	0	0.876	-0.049	4.432	0.01	0.007	0	43	39.1	66.7	135	123	0	35	32
2014	7	27	20	37	0	0.85	-0.079	4.432	0.01	0.007	0	43.4	38.7	59.8	134	121	0	33	31
2014	7	27	20	47	0	0.846	-0.02	4.432	0.01	0.007	0	42.6	38.3	59.8	133	120	0	34	31
2014	7	27	20	57	0	0.902	-0.079	4.436	0.01	0.007	0	42.6	37.8	64.9	132	120	0	33	32
2014	7	27	21	7	0	0.899	-0.049	4.436	0.01	0.007	0	41.7	37.8	74	131	119	0	34	31
2014	7	27	21	17	0	0.919	-0.098	4.436	0.01	0.007	0	41.7	37.4	61.1	131	118	0	34	31
2014	7	27	21	27	0	0.974	-0.075	4.436	0.01	0.007	0	42.1	37.8	63.2	132	120	0	34	32
2014	7	27	21	37	0	0.906	-0.033	4.436	0.01	0.007	0	41.7	37.4	72.7	131	119	0	34	32
2014	7	27	21	47	0	0.909	-0.056	4.436	0.01	0.007	0	41.3	37.4	70.5	130	118	0	34	31
2014	7	27	21	57	0	0.932	-0.082	4.436	0.01	0.007	0	40.9	36.5	73.5	129	117	0	34	32
2014	7	27	22	7	0	0.932	-0.075	4.439	0.01	0.007	0	40.4	36.5	74.8	129	116	0	35	31
2014	7	27	22	17	0	0.876	-0.072	4.439	0.013	0.01	0	40.9	36.5	75.3	129	116	0	34	31
2014	7	27	22	27	0	0.909	-0.105	4.439	0.01	0.007	0	40.4	36.1	75.7	128	116	0	34	32
2014	7	27	22	37	0	0.906	-0.079	4.439	0.01	0.007	0	40.4	36.1	75.7	128	116	0	34	32
2014	7	27	22	47	0	0.912	-0.069	4.439	0.01	0.007	0	40	36.1	76.1	128	116	0	35	32
2014	7	27	22	57	0	0.899	-0.052	4.439	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	27	23	7	0	0.869	-0.03	4.439	0.01	0.007	0	40.9	37	77	129	117	0	34	31
2014	7	27	23	17	0	0.879	-0.059	4.439	0.01	0.007	0	40.4	36.1	77	128	116	0	34	32
2014	7	27	23	27	0	0.915	-0.098	4.439	0.01	0.007	0	40.9	36.1	76.5	129	115	0	34	31
2014	7	27	23	37	0	0.883	-0.052	4.442	0.01	0.007	0	40.4	36.1	77	128	116	0	34	32
2014	7	27	23	47	0	0.902	-0.089	4.442	0.01	0.007	0	40	36.1	77	128	116	0	35	32
2014	7	27	23	57	0	0.906	-0.052	4.442	0.013	0.01	0	40.4	36.1	75.7	128	116	0	34	32
2014	7	28	0	7	0	0.86	-0.049	4.442	0.01	0.007	0	40.9	36.5	71.8	129	117	0	34	32
2014	7	28	0	17	0	0.922	-0.059	4.442	0.01	0.007	0	40.4	37	74.8	128	117	0	34	31
2014	7	28	0	27	0	0.892	-0.056	4.442	0.01	0.007	0	40.4	36.5	72.2	128	116	0	34	31
2014	7	28	0	37	0	0.938	-0.062	4.442	0.01	0.007	0	40.9	36.5	71.8	129	116	0	34	31
2014	7	28	0	47	0	0.896	-0.046	4.442	0.01	0.007	0	40.9	36.1	72.7	129	116	0	34	32
2014	7	28	0	57	0	0.876	-0.082	4.442	0.01	0.007	0	40.9	36.1	72.7	129	116	0	34	32
2014	7	28	1	7	0	0.883	-0.062	4.442	0.01	0.007	0	40.9	37	72.2	129	117	0	34	31
2014	7	28	1	17	0	0.886	-0.039	4.442	0.01	0.007	0	40.9	36.5	73.5	129	117	0	34	32
2014	7	28	1	27	0	0.945	-0.089	4.442	0.01	0.007	0	40.9	36.5	75.3	129	116	0	34	31
2014	7	28	1	37	0	0.906	-0.069	4.442	0.01	0.007	0	40.4	36.5	75.7	128	116	0	34	31
2014	7	28	1	47	0	0.912	-0.075	4.442	0.01	0.007	0	40.9	36.1	76.5	129	116	0	34	32
2014	7	28	1	57	0	0.886	-0.049	4.442	0.01	0.007	0	40.9	36.1	76.5	129	116	0	34	32
2014	7	28	2	7	0	0.892	-0.079	4.442	0.01	0.007	0	40.4	36.1	76.1	128	115	0	34	31
2014	7	28	2	17	0	0.886	-0.033	4.442	0.01	0.007	0	40.4	36.1	76.5	128	116	0	34	32
2014	7	28	2	27	0	0.866	-0.049	4.442	0.01	0.007	0	40.9	36.5	75.7	129	116	0	34	31
2014	7	28	2	37	0	0.883	-0.062	4.442	0.01	0.007	0	41.3	37.4	76.5	130	118	0	34	31
2014	7	28	2	47	0	0.86	-0.033	4.442	0.01	0.007	0	41.3	36.5	76.1	130	118	0	34	33
2014	7	28	2	57	0	0.863	-0.069	4.442	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	28	3	7	0	0.896	-0.095	4.442	0.01	0.007	0	41.7	37.4	76.1	131	119	0	34	32
2014	7	28	3	17	0	0.886	-0.079	4.442	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	28	3	27	0	0.935	-0.066	4.442	0.013	0.01	0	41.3	37	75.7	130	117	0	34	31
2014	7	28	3	37	0	0.912	-0.079	4.442	0.01	0.007	0	40.4	36.5	76.1	129	117	0	35	32
2014	7	28	3	47	0	0.883	-0.052	4.442	0.01	0.007	0	41.3	37	75.7	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	3	57	0	0.863	-0.092	4.442	0.01	0.007	0	41.3	37.4	76.1	130	118	0	34	31
2014	7	28	4	7	0	0.899	-0.079	4.442	0.01	0.007	0	40.9	36.5	76.1	130	117	0	35	32
2014	7	28	4	17	0	0.896	-0.072	4.442	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	28	4	27	0	0.873	-0.062	4.442	0.01	0.007	0	40.9	37	76.1	129	117	0	34	31
2014	7	28	4	37	0	0.899	-0.085	4.442	0.01	0.007	0	41.3	37	76.5	130	118	0	34	32
2014	7	28	4	47	0	0.925	-0.066	4.442	0.01	0.007	0	41.7	37	73.5	131	118	0	34	32
2014	7	28	4	57	0	0.945	-0.062	4.442	0.013	0.01	0	41.3	37	74.4	130	118	0	34	32
2014	7	28	5	7	0	0.883	-0.036	4.442	0.01	0.007	0	41.3	37.8	76.1	131	119	0	35	31
2014	7	28	5	17	0	0.909	-0.095	4.442	0.01	0.007	0	41.7	37.8	75.3	131	119	0	34	31
2014	7	28	5	27	0	0.853	-0.062	4.442	0.01	0.007	0	41.3	37	76.1	130	118	0	34	32
2014	7	28	5	37	0	0.889	-0.079	4.442	0.01	0.007	0	41.3	37	76.5	130	118	0	34	32
2014	7	28	5	47	0	0.889	-0.062	4.442	0.01	0.007	0	41.7	37.8	76.5	131	119	0	34	31
2014	7	28	5	57	0	0.886	-0.072	4.442	0.01	0.007	0	41.7	37.8	76.1	131	119	0	34	31
2014	7	28	6	7	0	0.883	-0.075	4.442	0.01	0.007	0	41.3	37.4	76.5	131	119	0	35	32
2014	7	28	6	17	0	0.912	-0.082	4.442	0.01	0.007	0	41.7	37.4	76.5	131	119	0	34	32
2014	7	28	6	27	0	0.86	-0.066	4.442	0.013	0.01	0	41.7	37.8	77	130	119	0	33	31
2014	7	28	6	37	0	0.876	-0.062	4.439	0.01	0.007	0	42.1	37	77	131	118	0	33	32
2014	7	28	6	47	0	0.902	-0.066	4.442	0.01	0.007	0	41.3	37	76.5	130	118	0	34	32
2014	7	28	6	57	0	0.879	-0.105	4.439	0.013	0.01	0	41.3	37	75.7	130	117	0	34	31
2014	7	28	7	7	0	0.846	-0.082	4.442	0.01	0.007	0	41.3	36.5	76.5	130	117	0	34	32
2014	7	28	7	17	0	0.896	-0.052	4.439	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	28	7	27	0	0.837	-0.079	4.439	0.01	0.007	0	40.9	37	77	129	117	0	34	31
2014	7	28	7	37	0	0.879	-0.066	4.439	0.01	0.007	0	40.4	36.5	77.4	128	116	0	34	31
2014	7	28	7	47	0	0.794	-0.046	4.439	0.01	0.007	0	40.9	36.5	76.5	129	116	0	34	31
2014	7	28	7	57	0	0.876	-0.049	4.439	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	28	8	7	0	0.86	-0.062	4.439	0.013	0.01	0	40.4	36.5	77	128	116	0	34	31
2014	7	28	8	17	0	0.886	-0.056	4.439	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	28	8	27	0	0.876	-0.059	4.439	0.013	0.01	0	40.4	36.1	75.7	128	115	0	34	31
2014	7	28	8	37	0	0.856	-0.062	4.439	0.013	0.01	0	40.4	35.7	76.5	128	115	0	34	32
2014	7	28	8	47	0	0.912	-0.082	4.439	0.01	0.007	0	40.4	35.7	76.5	127	115	0	33	32
2014	7	28	8	57	0	0.906	-0.079	4.439	0.01	0.007	0	40	36.1	76.5	127	115	0	34	31
2014	7	28	9	7	0	0.886	-0.079	4.439	0.01	0.007	0	40	36.1	77	127	115	0	34	31
2014	7	28	9	17	0	0.863	-0.075	4.439	0.013	0.01	0	40.9	36.5	73.1	129	116	0	34	31
2014	7	28	9	27	0	0.863	-0.075	4.439	0.013	0.01	0	41.3	36.1	73.1	130	116	0	34	32
2014	7	28	9	37	0	0.86	-0.098	4.439	0.01	0.007	0	41.3	37	73.5	130	117	0	34	31
2014	7	28	9	47	0	0.879	-0.069	4.439	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	28	9	57	0	0.866	-0.069	4.439	0.013	0.01	0	40.9	36.1	76.1	129	116	0	34	32
2014	7	28	10	7	0	0.856	-0.075	4.436	0.01	0.007	0	40.4	36.1	75.7	129	116	0	35	32
2014	7	28	10	17	0	0.846	-0.033	4.436	0.01	0.007	0	40.9	37	75.7	130	117	0	35	31
2014	7	28	10	27	0	0.902	-0.079	4.436	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	28	10	37	0	0.883	-0.079	4.436	0.013	0.01	0	41.3	36.5	67.5	130	117	0	34	32
2014	7	28	10	47	0	0.83	-0.046	4.436	0.01	0.007	0	40.9	36.5	64.5	129	117	0	34	32
2014	7	28	10	57	0	0.866	-0.108	4.436	0.01	0.007	0	40.9	36.1	62.4	129	115	0	34	31
2014	7	28	11	7	0	0.856	-0.036	4.432	0.01	0.007	0	40.9	36.5	64.1	129	117	0	34	32
2014	7	28	11	17	0	0.892	-0.089	4.432	0.01	0.007	0	40.4	36.5	61.5	128	116	0	34	31
2014	7	28	11	27	0	0.866	-0.095	4.432	0.01	0.007	0	40.9	36.1	62.4	129	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	11	37	0	0.863	-0.092	4.432	0.01	0.007	0	40.9	36.1	59.8	129	115	0	34	31
2014	7	28	11	47	0	0.853	-0.046	4.432	0.01	0.007	0	40.4	36.1	67.5	128	115	0	34	31
2014	7	28	11	57	0	0.912	-0.075	4.432	0.01	0.007	0	40.4	36.1	64.1	128	115	0	34	31
2014	7	28	12	7	0	0.856	-0.079	4.432	0.01	0.007	0	40	36.5	58.5	128	116	0	35	31
2014	7	28	12	17	0	0.899	-0.092	4.429	0.01	0.007	0	40.9	35.7	61.1	129	115	0	34	32
2014	7	28	12	27	0	0.896	-0.092	4.432	0.01	0.007	0	40	35.3	67.1	127	114	0	34	32
2014	7	28	12	37	0	0.84	-0.069	4.426	0.016	0.013	0	40.4	36.1	58.5	128	115	0	34	31
2014	7	28	12	47	0	0.896	-0.095	4.426	0.01	0.007	0	40.9	36.5	58	129	116	0	34	31
2014	7	28	12	57	0	0.873	-0.059	4.426	0.01	0.007	0	40.4	36.5	58	128	116	0	34	31
2014	7	28	13	7	0	0.84	-0.036	4.426	0.01	0.007	0	40.9	36.5	55.5	129	116	0	34	31
2014	7	28	13	17	0	0.873	-0.079	4.423	0.013	0.01	0	40.9	35.7	59.3	129	116	0	34	33
2014	7	28	13	27	0	0.902	-0.115	4.419	0.013	0.01	0	40.4	36.1	60.6	128	115	0	34	31
2014	7	28	13	37	0	0.906	-0.069	4.419	0.01	0.007	0	40.4	36.5	65.8	128	116	0	34	31
2014	7	28	13	47	0	0.863	-0.079	4.419	0.01	0.007	0	40	35.7	66.7	128	115	0	35	32
2014	7	28	13	57	0	0.869	-0.082	4.419	0.013	0.01	0	40.4	35.7	59.8	128	115	0	34	32
2014	7	28	14	7	0	0.869	-0.049	4.416	0.01	0.007	0	40.9	36.1	58.9	128	115	0	33	31
2014	7	28	14	17	0	0.846	-0.082	4.416	0.01	0.007	0	40.4	35.7	60.6	128	115	0	34	32
2014	7	28	14	27	0	0.84	-0.092	4.416	0.01	0.007	0	40.4	36.1	63.6	128	115	0	34	31
2014	7	28	14	37	0	0.892	-0.095	4.413	0.01	0.007	0	40.4	36.1	58.9	128	115	0	34	31
2014	7	28	14	47	0	0.896	-0.085	4.413	0.013	0.01	0	40.4	35.7	69.7	128	115	0	34	32
2014	7	28	14	57	0	0.866	-0.072	4.413	0.01	0.007	0	40	35.3	70.5	127	114	0	34	32
2014	7	28	15	7	0	0.863	-0.092	4.413	0.01	0.007	0	39.6	35.3	73.1	127	114	0	35	32
2014	7	28	15	17	0	0.883	-0.075	4.413	0.01	0.007	0	40.9	35.7	68.8	128	115	0	33	32
2014	7	28	15	27	0	0.869	-0.049	4.413	0.01	0.007	0	40	35.7	71.8	127	114	0	34	31
2014	7	28	15	37	0	0.889	-0.092	4.413	0.01	0.007	0	40	35.7	74.4	127	114	0	34	31
2014	7	28	15	47	0	0.909	-0.049	4.413	0.013	0.01	0	40.4	36.1	72.2	128	115	0	34	31
2014	7	28	15	57	0	0.928	-0.108	4.409	0.01	0.007	0	40.9	36.1	69.7	129	116	0	34	32
2014	7	28	16	7	0	0.938	-0.085	4.413	0.01	0.007	0	40.9	36.1	65.4	129	116	0	34	32
2014	7	28	16	17	0	0.915	-0.059	4.413	0.01	0.007	0	41.3	37	57.6	130	117	0	34	31
2014	7	28	16	27	0	0.899	-0.075	4.413	0.01	0.007	0	41.3	37	69.2	130	117	0	34	31
2014	7	28	16	37	0	0.86	-0.079	4.413	0.01	0.007	0	41.3	36.5	73.5	130	117	0	34	32
2014	7	28	16	47	0	0.906	-0.062	4.413	0.01	0.007	0	41.3	36.5	75.7	130	117	0	34	32
2014	7	28	16	57	0	0.873	-0.059	4.413	0.01	0.007	0	41.3	36.5	72.7	130	117	0	34	32
2014	7	28	17	7	0	0.935	-0.098	4.409	0.01	0.007	0	41.7	37.4	70.5	131	118	0	34	31
2014	7	28	17	17	0	0.889	-0.098	4.409	0.01	0.007	0	41.7	37	72.7	130	117	0	33	31
2014	7	28	17	27	0	0.909	-0.056	4.409	0.01	0.007	0	41.3	36.5	72.2	130	117	0	34	32
2014	7	28	17	37	0	0.899	-0.062	4.413	0.013	0.01	0	40.9	36.1	73.1	129	116	0	34	32
2014	7	28	17	47	0	0.892	-0.056	4.409	0.01	0.007	0	41.3	37	65.8	130	117	0	34	31
2014	7	28	17	57	0	0.837	-0.062	4.409	0.01	0.007	0	41.7	37	73.5	131	118	0	34	32
2014	7	28	18	7	0	0.883	-0.079	4.409	0.01	0.007	0	41.7	37	74	130	118	0	33	32
2014	7	28	18	17	0	0.899	-0.089	4.409	0.01	0.007	0	41.3	36.5	75.3	130	117	0	34	32
2014	7	28	18	27	0	0.915	-0.039	4.409	0.01	0.007	0	41.3	37.4	75.7	130	118	0	34	31
2014	7	28	18	37	0	0.869	-0.043	4.413	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	28	18	47	0	0.896	-0.043	4.409	0.013	0.01	0	40.9	37	75.7	129	117	0	34	31
2014	7	28	18	57	0	0.938	-0.059	4.409	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	28	19	7	0	0.85	-0.062	4.409	0.013	0.01	0	41.3	37	74.8	130	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	28	19	17	0	0.915	-0.046	4.409	0.01	0.007	0	41.3	37	74.4	130	117	0	34	31
2014	7	28	19	27	0	0.896	-0.105	4.409	0.01	0.007	0	41.3	37	73.5	130	117	0	34	31
2014	7	28	19	37	0	0.945	-0.079	4.409	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	28	19	47	0	0.892	-0.082	4.409	0.01	0.007	0	41.7	37	74	130	117	0	33	31
2014	7	28	19	57	0	0.945	-0.075	4.409	0.01	0.007	0	41.7	37	73.5	131	118	0	34	32
2014	7	28	20	7	0	0.876	-0.079	4.413	0.01	0.007	0	41.3	37	72.7	130	118	0	34	32
2014	7	28	20	17	0	0.915	-0.089	4.413	0.01	0.007	0	41.7	37.4	63.6	131	118	0	34	31
2014	7	28	20	27	0	0.899	-0.092	4.413	0.013	0.01	0	42.1	37	70.5	131	118	0	33	32
2014	7	28	20	37	0	0.883	-0.062	4.413	0.01	0.007	0	41.7	37.8	72.7	131	119	0	34	31
2014	7	28	20	47	0	0.919	-0.049	4.413	0.016	0.013	0	41.7	37	71.4	131	118	0	34	32
2014	7	28	20	57	0	0.899	-0.072	4.413	0.01	0.007	0	41.3	36.5	72.7	130	117	0	34	32
2014	7	28	21	7	0	0.883	-0.079	4.413	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	28	21	17	0	0.896	-0.095	4.413	0.01	0.007	0	40.4	36.1	74	128	115	0	34	31
2014	7	28	21	27	0	0.85	-0.052	4.413	0.01	0.007	0	40.9	36.1	74	129	116	0	34	32
2014	7	28	21	37	0	0.899	-0.102	4.413	0.01	0.007	0	40.4	35.7	74.4	128	115	0	34	32
2014	7	28	21	47	0	0.909	-0.056	4.413	0.01	0.007	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	28	21	57	0	0.902	-0.072	4.413	0.01	0.007	0	40.4	36.1	73.5	128	115	0	34	31
2014	7	28	22	7	0	0.899	-0.069	4.413	0.01	0.007	0	40.4	36.5	73.5	128	116	0	34	31
2014	7	28	22	17	0	0.886	-0.098	4.413	0.013	0.01	0	40.4	35.3	73.5	128	115	0	34	33
2014	7	28	22	27	0	0.919	-0.056	4.413	0.01	0.007	0	40	35.7	74	128	115	0	35	32
2014	7	28	22	37	0	0.886	-0.072	4.416	0.01	0.007	0	40.4	36.1	74	128	115	0	34	31
2014	7	28	22	47	0	0.883	-0.046	4.416	0.01	0.007	0	40.4	35.7	73.1	128	115	0	34	32
2014	7	28	22	57	0	0.892	-0.066	4.419	0.01	0.007	0	40.4	36.1	73.1	128	115	0	34	31
2014	7	28	23	7	0	0.909	-0.082	4.423	0.01	0.007	0	40.4	36.5	73.5	128	116	0	34	31
2014	7	28	23	17	0	0.896	-0.079	4.426	0.013	0.01	0	41.3	36.5	73.1	129	116	0	33	31
2014	7	28	23	27	0	0.928	-0.079	4.426	0.016	0.013	0	40.4	36.1	74	128	115	0	34	31
2014	7	28	23	37	0	0.902	-0.079	4.429	0.01	0.007	0	40.4	36.1	74.8	128	115	0	34	31
2014	7	28	23	47	0	0.853	-0.066	4.429	0.01	0.007	0	40.9	36.1	71	129	116	0	34	32
2014	7	28	23	57	0	0.899	-0.092	4.429	0.01	0.007	0	40.4	36.5	75.3	128	116	0	34	31
2014	7	29	0	7	0	0.896	-0.075	4.429	0.01	0.007	0	40.4	35.7	75.7	128	115	0	34	32
2014	7	29	0	17	0	0.879	-0.079	4.432	0.01	0.007	0	40.9	36.1	75.7	128	116	0	33	32
2014	7	29	0	27	0	0.912	-0.033	4.432	0.01	0.007	0	40.4	35.7	76.5	128	115	0	34	32
2014	7	29	0	37	0	0.902	-0.072	4.432	0.01	0.007	0	40.4	36.5	76.5	128	116	0	34	31
2014	7	29	0	47	0	0.883	-0.085	4.432	0.01	0.007	0	40.4	35.7	76.5	128	115	0	34	32
2014	7	29	0	57	0	0.938	-0.108	4.436	0.01	0.007	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	29	1	7	0	0.879	-0.066	4.436	0.01	0.007	0	41.3	37	77.4	130	117	0	34	31
2014	7	29	1	17	0	0.928	-0.072	4.436	0.01	0.007	0	41.3	36.5	77.8	130	117	0	34	32
2014	7	29	1	27	0	0.912	-0.085	4.439	0.01	0.007	0	41.3	37	77.8	130	117	0	34	31
2014	7	29	1	37	0	0.902	-0.056	4.439	0.01	0.007	0	40.4	36.5	77.8	129	117	0	35	32
2014	7	29	1	47	0	0.928	-0.082	4.439	0.01	0.007	0	40.9	36.5	77.4	129	116	0	34	31
2014	7	29	1	57	0	0.853	-0.082	4.439	0.01	0.007	0	40.9	36.1	77	129	116	0	34	32
2014	7	29	2	7	0	0.873	-0.059	4.442	0.01	0.007	0	40.9	36.5	77.4	129	116	0	34	31
2014	7	29	2	17	0	0.869	-0.066	4.442	0.01	0.007	0	40.9	36.1	77.4	129	116	0	34	32
2014	7	29	2	27	0	0.892	-0.108	4.442	0.01	0.007	0	40.9	36.5	77	129	116	0	34	31
2014	7	29	2	37	0	0.912	-0.105	4.442	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	29	2	47	0	0.902	-0.046	4.446	0.01	0.007	0	41.3	36.5	74.8	130	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	2	57	0	0.909	-0.062	4.446	0.01	0.007	0	40.4	36.1	75.3	128	116	0	34	32
2014	7	29	3	7	0	0.955	-0.092	4.449	0.01	0.007	0	40.9	36.5	74	129	116	0	34	31
2014	7	29	3	17	0	0.958	-0.062	4.449	0.013	0.01	0	40.4	36.1	74.8	128	116	0	34	32
2014	7	29	3	27	0	0.945	-0.062	4.452	0.01	0.007	0	40.4	36.1	73.1	129	116	0	35	32
2014	7	29	3	37	0	0.902	-0.062	4.462	0.016	0.013	0	40.9	36.5	71.8	129	117	0	34	32
2014	7	29	3	47	0	0.906	-0.092	4.465	0.01	0.007	0	40.9	36.1	74	129	116	0	34	32
2014	7	29	3	57	0	0.922	-0.079	4.469	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	29	4	7	0	0.922	-0.085	4.469	0.01	0.007	0	40.9	36.5	76.1	129	116	0	34	31
2014	7	29	4	17	0	0.906	-0.069	4.472	0.01	0.007	0	40.4	36.5	77.4	129	116	0	35	31
2014	7	29	4	27	0	0.932	-0.059	4.472	0.01	0.007	0	41.3	37	77	130	118	0	34	32
2014	7	29	4	37	0	0.938	-0.079	4.475	0.013	0.01	0	40.9	37	77	130	117	0	35	31
2014	7	29	4	47	0	0.906	-0.075	4.475	0.01	0.007	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	29	4	57	0	0.902	-0.072	4.478	0.013	0.01	0	41.7	37	77.4	131	118	0	34	32
2014	7	29	5	7	0	0.961	-0.108	4.478	0.01	0.007	0	41.3	37	77.8	130	118	0	34	32
2014	7	29	5	17	0	0.892	-0.069	4.482	0.01	0.007	0	41.7	37.4	76.5	131	118	0	34	31
2014	7	29	5	27	0	0.909	-0.079	4.482	0.01	0.007	0	41.7	37.4	77	132	119	0	35	32
2014	7	29	5	37	0	0.919	-0.066	4.485	0.01	0.007	0	41.7	37.4	75.7	131	118	0	34	31
2014	7	29	5	47	0	0.909	-0.095	4.485	0.01	0.007	0	41.7	37.4	75.7	131	119	0	34	32
2014	7	29	5	57	0	0.915	-0.075	4.485	0.01	0.007	0	41.7	37.4	74.4	131	119	0	34	32
2014	7	29	6	7	0	0.902	-0.082	4.488	0.013	0.01	0	42.1	38.3	74	132	120	0	34	31
2014	7	29	6	17	0	0.909	-0.089	4.495	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2014	7	29	6	27	0	0.915	-0.095	4.501	0.01	0.007	0	41.3	37.4	74	130	118	0	34	31
2014	7	29	6	37	0	0.928	-0.046	4.505	0.01	0.007	0	41.7	37.4	74.8	131	118	0	34	31
2014	7	29	6	47	0	0.922	-0.079	4.508	0.01	0.007	0	41.3	37	75.3	130	117	0	34	31
2014	7	29	6	57	0	0.948	-0.069	4.511	0.016	0.013	0	40.9	36.5	77	130	117	0	35	32
2014	7	29	7	7	0	0.915	-0.052	4.511	0.013	0.01	0	40.9	36.5	77.8	129	117	0	34	32
2014	7	29	7	17	0	0.912	-0.095	4.514	0.01	0.007	0	40.9	36.1	76.5	129	116	0	34	32
2014	7	29	7	27	0	0.889	-0.085	4.514	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	29	7	37	0	0.906	-0.059	4.514	0.01	0.007	0	40.9	36.5	77	129	117	0	34	32
2014	7	29	7	47	0	0.919	-0.082	4.518	0.013	0.01	0	40.9	36.5	77.4	129	117	0	34	32
2014	7	29	7	57	0	0.945	-0.082	4.518	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	29	8	7	0	0.915	-0.059	4.518	0.01	0.007	0	40.9	36.5	76.5	129	117	0	34	32
2014	7	29	8	17	0	0.938	-0.075	4.521	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	29	8	27	0	0.942	-0.098	4.521	0.01	0.007	0	40.4	36.1	74	129	116	0	35	32
2014	7	29	8	37	0	0.925	-0.062	4.524	0.01	0.007	0	40.9	36.1	74.8	129	116	0	34	32
2014	7	29	8	47	0	0.938	-0.118	4.524	0.01	0.007	0	40.9	37	74.4	129	117	0	34	31
2014	7	29	8	57	0	0.928	-0.095	4.528	0.01	0.007	0	40.9	36.5	72.7	129	117	0	34	32
2014	7	29	9	7	0	0.919	-0.125	4.528	0.013	0.01	0	40.9	37	71.4	129	117	0	34	31
2014	7	29	9	17	0	0.925	-0.085	4.534	0.01	0.007	0	40.4	35.7	71.4	129	116	0	35	33
2014	7	29	9	27	0	0.925	-0.118	4.541	0.01	0.007	0	40.9	36.5	71.4	129	117	0	34	32
2014	7	29	9	37	0	0.938	-0.059	4.544	0.01	0.007	0	40.9	36.5	73.1	129	116	0	34	31
2014	7	29	9	47	0	0.942	-0.095	4.547	0.01	0.007	0	40.9	36.5	72.7	129	117	0	34	32
2014	7	29	9	57	0	0.922	-0.108	4.547	0.01	0.007	0	40.4	35.7	73.5	128	115	0	34	32
2014	7	29	10	7	0	0.942	-0.052	4.551	0.01	0.007	0	40.9	37	68.8	129	117	0	34	31
2014	7	29	10	17	0	0.932	-0.052	4.551	0.01	0.007	0	40.4	36.1	73.5	128	116	0	34	32
2014	7	29	10	27	0	0.866	-0.102	4.554	0.01	0.007	0	40	35.7	76.1	127	115	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	10	37	0	0.942	-0.062	4.554	0.01	0.007	0	40	36.1	77.4	127	115	0	34	31
2014	7	29	10	47	0	0.945	-0.095	4.554	0.01	0.007	0	40	36.1	77	127	115	0	34	31
2014	7	29	10	57	0	0.932	-0.052	4.557	0.01	0.007	0	40	35.7	76.5	127	115	0	34	32
2014	7	29	11	7	0	0.915	-0.108	4.557	0.01	0.007	0	40	35.7	76.5	127	115	0	34	32
2014	7	29	11	17	0	0.899	-0.082	4.557	0.01	0.007	0	40.4	36.1	74.8	128	116	0	34	32
2014	7	29	11	27	0	0.883	-0.095	4.557	0.01	0.007	0	40.4	35.7	74.4	127	115	0	33	32
2014	7	29	11	37	0	0.925	-0.072	4.56	0.01	0.007	0	40.4	36.1	74.4	128	116	0	34	32
2014	7	29	11	47	0	0.922	-0.125	4.56	0.01	0.007	0	40	36.1	73.5	128	115	0	35	31
2014	7	29	11	57	0	0.915	-0.075	4.56	0.01	0.007	0	40	36.1	75.7	127	116	0	34	32
2014	7	29	12	7	0	0.938	-0.085	4.56	0.01	0.007	0	40	36.1	73.5	128	115	0	35	31
2014	7	29	12	17	0	0.938	-0.079	4.564	0.013	0.01	0	40	35.7	76.1	127	115	0	34	32
2014	7	29	12	27	0	0.942	-0.092	4.564	0.01	0.007	0	40	36.1	75.7	127	115	0	34	31
2014	7	29	12	37	0	0.922	-0.085	4.567	0.01	0.007	0	39.1	35.3	75.3	126	114	0	35	32
2014	7	29	12	47	0	0.965	-0.085	4.567	0.01	0.007	0	39.6	35.3	73.1	126	114	0	34	32
2014	7	29	12	57	0	0.902	-0.079	4.567	0.01	0.007	0	40	35.7	74	127	114	0	34	31
2014	7	29	13	7	0	0.938	-0.102	4.567	0.01	0.007	0	39.6	35.3	74.8	126	114	0	34	32
2014	7	29	13	17	0	0.935	-0.082	4.57	0.01	0.007	0	39.1	35.3	74	125	113	0	34	31
2014	7	29	13	27	0	0.961	-0.102	4.57	0.01	0.007	0	39.6	34.8	75.7	126	113	0	34	32
2014	7	29	13	37	0	0.955	-0.059	4.57	0.01	0.007	0	39.6	34.8	74.8	126	112	0	34	31
2014	7	29	13	47	0	0.935	-0.092	4.573	0.01	0.007	0	39.1	35.3	71.8	125	113	0	34	31
2014	7	29	13	57	0	0.968	-0.079	4.573	0.01	0.007	0	39.1	34.8	74.8	125	113	0	34	32
2014	7	29	14	7	0	0.896	-0.079	4.573	0.01	0.007	0	39.1	35.3	74.4	125	113	0	34	31
2014	7	29	14	17	0	0.909	-0.095	4.573	0.013	0.01	0	39.1	35.3	73.1	125	113	0	34	31
2014	7	29	14	27	0	0.906	-0.108	4.573	0.01	0.007	0	39.1	35.3	73.1	125	113	0	34	31
2014	7	29	14	37	0	0.945	-0.085	4.577	0.01	0.007	0	39.1	35.3	72.7	125	113	0	34	31
2014	7	29	14	47	0	0.928	-0.075	4.577	0.01	0.007	0	39.1	35.3	71.4	125	114	0	34	32
2014	7	29	14	57	0	0.965	-0.089	4.577	0.01	0.007	0	39.1	35.3	71.8	125	113	0	34	31
2014	7	29	15	7	0	0.889	-0.089	4.58	0.01	0.007	0	39.6	35.3	72.2	126	114	0	34	32
2014	7	29	15	17	0	0.971	-0.062	4.58	0.01	0.007	0	39.6	35.3	71.4	126	114	0	34	32
2014	7	29	15	27	0	0.922	-0.079	4.583	0.01	0.007	0	39.1	34.8	71.4	125	113	0	34	32
2014	7	29	15	37	0	0.919	-0.102	4.583	0.01	0.007	0	39.6	35.3	72.2	125	113	0	33	31
2014	7	29	15	47	0	0.938	-0.056	4.587	0.01	0.007	0	39.1	35.3	69.7	125	113	0	34	31
2014	7	29	15	57	0	0.955	-0.092	4.59	0.01	0.007	0	39.1	35.3	71.4	125	113	0	34	31
2014	7	29	16	7	0	0.909	-0.082	4.593	0.016	0.013	0	39.1	34.8	73.1	125	113	0	34	32
2014	7	29	16	17	0	0.951	-0.089	4.593	0.01	0.007	0	39.1	35.3	74.4	125	113	0	34	31
2014	7	29	16	27	0	0.912	-0.079	4.593	0.013	0.01	0	39.1	35.3	73.1	125	113	0	34	31
2014	7	29	16	37	0	0.971	-0.069	4.593	0.01	0.007	0	39.1	35.3	74.8	125	113	0	34	31
2014	7	29	16	47	0	0.935	-0.069	4.596	0.01	0.007	0	40	35.3	75.3	126	113	0	33	31
2014	7	29	16	57	0	0.922	-0.079	4.596	0.01	0.007	0	39.6	35.7	71.8	126	114	0	34	31
2014	7	29	17	7	0	0.988	-0.056	4.596	0.013	0.01	0	39.6	35.3	72.7	126	113	0	34	31
2014	7	29	17	17	0	0.942	-0.066	4.596	0.01	0.007	0	39.6	35.3	75.3	126	114	0	34	32
2014	7	29	17	27	0	0.951	-0.033	4.596	0.01	0.007	0	39.6	35.7	74.8	126	114	0	34	31
2014	7	29	17	37	0	0.958	-0.089	4.6	0.01	0.007	0	40	35.7	75.3	126	114	0	33	31
2014	7	29	17	47	0	0.938	-0.075	4.6	0.01	0.007	0	39.6	35.3	75.3	126	113	0	34	31
2014	7	29	17	57	0	0.928	-0.079	4.6	0.01	0.007	0	39.1	35.3	72.7	126	113	0	35	31
2014	7	29	18	7	0	0.922	-0.082	4.6	0.01	0.007	0	40	35.7	70.1	126	114	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	29	18	17	0	0.935	-0.102	4.603	0.01	0.007	0	39.6	35.3	76.5	126	114	0	34	32
2014	7	29	18	27	0	0.958	-0.066	4.603	0.01	0.007	0	39.6	35.3	77.8	126	113	0	34	31
2014	7	29	18	37	0	0.922	-0.082	4.603	0.01	0.007	0	40	35.7	77.8	127	114	0	34	31
2014	7	29	18	47	0	0.922	-0.062	4.603	0.01	0.007	0	40	35.7	76.5	127	114	0	34	31
2014	7	29	18	57	0	0.951	-0.089	4.603	0.01	0.007	0	40.4	36.1	77.8	128	115	0	34	31
2014	7	29	19	7	0	0.922	-0.066	4.603	0.013	0.01	0	40	36.1	77.4	127	115	0	34	31
2014	7	29	19	17	0	0.938	-0.066	4.606	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	29	19	27	0	0.968	-0.079	4.606	0.01	0.007	0	40.4	36.1	77.4	128	115	0	34	31
2014	7	29	19	37	0	0.971	-0.066	4.606	0.01	0.007	0	40.4	35.7	76.5	127	115	0	33	32
2014	7	29	19	47	0	0.974	-0.105	4.606	0.01	0.007	0	40.9	35.7	75.3	128	115	0	33	32
2014	7	29	19	57	0	0.984	-0.075	4.606	0.01	0.007	0	40.4	36.1	76.1	128	115	0	34	31
2014	7	29	20	7	0	0.912	-0.085	4.606	0.01	0.007	0	40.4	36.1	74.8	128	115	0	34	31
2014	7	29	20	17	0	0.968	-0.062	4.606	0.01	0.007	0	40.9	36.5	73.1	129	116	0	34	31
2014	7	29	20	27	0	0.945	-0.052	4.606	0.01	0.007	0	40.9	36.5	70.1	129	117	0	34	32
2014	7	29	20	37	0	0.961	-0.125	4.606	0.01	0.007	0	40.9	37	70.5	129	117	0	34	31
2014	7	29	20	47	0	0.991	-0.092	4.606	0.01	0.007	0	40.4	36.1	71.4	129	116	0	35	32
2014	7	29	20	57	0	0.968	-0.079	4.61	0.013	0.01	0	40.4	36.1	74.4	128	116	0	34	32
2014	7	29	21	7	0	0.984	-0.062	4.61	0.01	0.007	0	40	36.1	75.3	127	115	0	34	31
2014	7	29	21	17	0	0.971	-0.062	4.61	0.01	0.007	0	40	36.1	74.8	127	115	0	34	31
2014	7	29	21	27	0	0.945	-0.085	4.61	0.01	0.007	0	40	35.7	74.4	127	114	0	34	31
2014	7	29	21	37	0	0.935	-0.079	4.61	0.013	0.01	0	39.6	35.3	75.3	126	114	0	34	32
2014	7	29	21	47	0	0.922	-0.089	4.613	0.01	0.007	0	39.6	35.7	75.3	126	114	0	34	31
2014	7	29	21	57	0	0.938	-0.066	4.613	0.013	0.01	0	40	34.8	74.8	126	113	0	33	32
2014	7	29	22	7	0	0.935	-0.095	4.613	0.01	0.007	0	39.1	35.3	74.4	125	113	0	34	31
2014	7	29	22	17	0	0.958	-0.062	4.613	0.01	0.007	0	39.6	34.8	74.8	125	113	0	33	32
2014	7	29	22	27	0	0.955	-0.062	4.613	0.01	0.007	0	39.1	35.3	74.8	125	113	0	34	31
2014	7	29	22	37	0	0.951	-0.079	4.616	0.01	0.007	0	39.1	34.8	73.1	125	112	0	34	31
2014	7	29	22	47	0	0.915	-0.03	4.616	0.01	0.007	0	39.1	35.3	74.4	125	113	0	34	31
2014	7	29	22	57	0	0.922	-0.062	4.616	0.01	0.007	0	39.1	34.8	73.1	125	113	0	34	32
2014	7	29	23	7	0	0.951	-0.062	4.616	0.01	0.007	0	39.6	34.8	73.5	126	113	0	34	32
2014	7	29	23	17	0	0.968	-0.092	4.619	0.01	0.007	0	39.6	35.3	72.7	126	113	0	34	31
2014	7	29	23	27	0	0.922	-0.062	4.623	0.01	0.007	0	39.6	35.3	73.1	126	113	0	34	31
2014	7	29	23	37	0	0.942	-0.039	4.626	0.013	0.01	0	39.6	34.8	73.5	126	113	0	34	32
2014	7	29	23	47	0	0.932	-0.079	4.629	0.01	0.007	0	39.1	34.8	73.1	125	112	0	34	31
2014	7	29	23	57	0	0.965	-0.082	4.629	0.01	0.007	0	39.6	35.7	74	126	114	0	34	31
2014	7	30	0	7	0	0.935	-0.049	4.633	0.01	0.007	0	40	36.1	73.1	127	115	0	34	31
2014	7	30	0	17	0	0.978	-0.052	4.633	0.01	0.007	0	40.4	35.7	74.4	127	114	0	33	31
2014	7	30	0	27	0	0.981	-0.066	4.633	0.01	0.007	0	39.1	35.3	74.8	125	113	0	34	31
2014	7	30	0	37	0	0.909	-0.072	4.633	0.01	0.007	0	39.6	35.3	74.8	126	114	0	34	32
2014	7	30	0	47	0	0.945	-0.059	4.636	0.01	0.007	0	39.6	34.8	75.3	126	113	0	34	32
2014	7	30	0	57	0	0.958	-0.056	4.636	0.01	0.007	0	40.4	36.1	76.5	128	115	0	34	31
2014	7	30	1	7	0	0.948	-0.092	4.636	0.01	0.007	0	40	35.3	75.7	127	114	0	34	32
2014	7	30	1	17	0	0.981	-0.072	4.636	0.013	0.01	0	40	35.7	76.5	127	114	0	34	31
2014	7	30	1	27	0	0.968	-0.066	4.636	0.01	0.007	0	39.6	35.3	77.4	126	113	0	34	31
2014	7	30	1	37	0	0.932	-0.079	4.639	0.01	0.007	0	40	34.8	77	126	113	0	33	32
2014	7	30	1	47	0	0.981	-0.085	4.639	0.01	0.007	0	39.1	35.3	77.4	125	113	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	1	57	0	0.948	-0.105	4.639	0.01	0.007	0	40	35.7	75.7	126	113	0	33	30
2014	7	30	2	7	0	0.928	-0.043	4.639	0.01	0.007	0	39.6	35.7	78.3	126	114	0	34	31
2014	7	30	2	17	0	0.961	-0.092	4.639	0.016	0.013	0	39.6	35.3	77.8	126	114	0	34	32
2014	7	30	2	27	0	0.981	-0.092	4.639	0.01	0.007	0	39.1	35.3	77.8	125	114	0	34	32
2014	7	30	2	37	0	0.958	-0.095	4.639	0.01	0.007	0	39.6	35.7	76.5	126	114	0	34	31
2014	7	30	2	47	0	0.955	-0.079	4.639	0.01	0.007	0	39.1	35.3	77.4	125	113	0	34	31
2014	7	30	2	57	0	0.961	-0.062	4.642	0.01	0.007	0	39.1	34.8	75.7	125	113	0	34	32
2014	7	30	3	7	0	0.925	-0.098	4.642	0.01	0.007	0	39.1	34.8	77.4	125	112	0	34	31
2014	7	30	3	17	0	0.965	-0.046	4.642	0.01	0.007	0	39.6	35.3	77	125	113	0	33	31
2014	7	30	3	27	0	0.958	-0.049	4.642	0.01	0.007	0	39.6	35.3	74.4	125	113	0	33	31
2014	7	30	3	37	0	0.984	-0.092	4.642	0.01	0.007	0	39.6	35.3	74.4	126	113	0	34	31
2014	7	30	3	47	0	0.922	-0.062	4.642	0.01	0.007	0	39.6	34.8	75.7	126	113	0	34	32
2014	7	30	3	57	0	0.951	-0.066	4.642	0.01	0.007	0	40	34.8	75.3	126	113	0	33	32
2014	7	30	4	7	0	0.948	-0.082	4.642	0.01	0.007	0	39.1	34.8	76.1	125	113	0	34	32
2014	7	30	4	17	0	0.928	-0.075	4.642	0.01	0.007	0	39.6	35.7	76.1	126	114	0	34	31
2014	7	30	4	27	0	0.932	-0.069	4.646	0.01	0.007	0	39.1	35.3	76.5	125	113	0	34	31
2014	7	30	4	37	0	0.942	-0.079	4.646	0.01	0.007	0	40	35.7	75.3	126	114	0	33	31
2014	7	30	4	47	0	0.948	-0.079	4.646	0.01	0.007	0	39.1	35.3	76.1	125	113	0	34	31
2014	7	30	4	57	0	0.958	-0.039	4.646	0.013	0.01	0	39.6	35.3	76.1	126	113	0	34	31
2014	7	30	5	7	0	0.994	-0.092	4.646	0.01	0.007	0	39.1	35.3	75.3	125	113	0	34	31
2014	7	30	5	17	0	0.925	-0.049	4.646	0.01	0.007	0	39.6	35.7	75.7	126	115	0	34	32
2014	7	30	5	27	0	0.978	-0.052	4.646	0.01	0.007	0	40	36.1	75.3	127	115	0	34	31
2014	7	30	5	37	0	0.945	-0.085	4.646	0.01	0.007	0	40	36.1	74.8	127	115	0	34	31
2014	7	30	5	47	0	0.955	-0.125	4.646	0.01	0.007	0	39.6	35.7	74.4	127	115	0	35	32
2014	7	30	5	57	0	0.942	-0.049	4.649	0.01	0.007	0	40.4	36.5	74.8	128	116	0	34	31
2014	7	30	6	7	0	0.948	-0.105	4.649	0.01	0.007	0	40.4	36.1	74.4	128	115	0	34	31
2014	7	30	6	17	0	0.965	-0.069	4.649	0.01	0.007	0	40	36.1	74	127	115	0	34	31
2014	7	30	6	27	0	0.997	-0.066	4.649	0.01	0.007	0	40	35.7	74	127	115	0	34	32
2014	7	30	6	37	0	0.955	-0.079	4.649	0.01	0.007	0	40	36.1	74	127	115	0	34	31
2014	7	30	6	47	0	0.974	-0.082	4.649	0.01	0.007	0	40	36.1	74	127	115	0	34	31
2014	7	30	6	57	0	0.932	-0.079	4.652	0.016	0.013	0	40	35.3	74	127	114	0	34	32
2014	7	30	7	7	0	0.948	-0.046	4.652	0.01	0.007	0	40	36.1	73.5	127	115	0	34	31
2014	7	30	7	17	0	0.965	-0.075	4.652	0.01	0.007	0	40	35.7	72.2	127	114	0	34	31
2014	7	30	7	27	0	0.958	-0.082	4.652	0.01	0.007	0	39.6	35.3	74	126	113	0	34	31
2014	7	30	7	37	0	0.951	-0.079	4.652	0.01	0.007	0	39.1	35.3	72.7	125	113	0	34	31
2014	7	30	7	47	0	0.938	-0.085	4.656	0.013	0.01	0	39.6	34.8	72.7	125	113	0	33	32
2014	7	30	7	57	0	0.968	-0.075	4.659	0.01	0.007	0	39.6	35.3	72.7	126	114	0	34	32
2014	7	30	8	7	0	0.978	-0.085	4.659	0.01	0.007	0	39.6	35.3	72.7	126	113	0	34	31
2014	7	30	8	17	0	0.965	-0.092	4.659	0.01	0.007	0	39.6	35.3	72.2	126	114	0	34	32
2014	7	30	8	27	0	0.961	-0.085	4.659	0.01	0.007	0	40	36.1	72.7	127	115	0	34	31
2014	7	30	8	37	0	0.932	-0.095	4.662	0.013	0.01	0	39.6	35.7	73.1	127	114	0	35	31
2014	7	30	8	47	0	0.981	-0.043	4.662	0.01	0.007	0	39.6	35.7	73.1	127	114	0	35	31
2014	7	30	8	57	0	0.988	-0.075	4.662	0.01	0.007	0	40.4	36.1	72.2	128	115	0	34	31
2014	7	30	9	7	0	0.978	-0.085	4.662	0.01	0.007	0	40	36.1	71.4	127	115	0	34	31
2014	7	30	9	17	0	0.965	-0.095	4.662	0.01	0.007	0	40	35.7	72.7	127	115	0	34	32
2014	7	30	9	27	0	0.988	-0.059	4.662	0.01	0.007	0	40	35.7	71.4	127	115	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	9	37	0	0.958	-0.072	4.665	0.016	0.013	0	40.4	36.1	71.4	127	115	0	33	31
2014	7	30	9	47	0	1.004	-0.085	4.662	0.01	0.007	0	39.6	35.7	71.8	126	114	0	34	31
2014	7	30	9	57	0	0.948	-0.115	4.665	0.01	0.007	0	39.6	34.8	72.7	126	113	0	34	32
2014	7	30	10	7	0	1.004	-0.118	4.662	0.01	0.007	0	39.6	35.3	73.1	126	114	0	34	32
2014	7	30	10	17	0	0.955	-0.118	4.662	0.01	0.007	0	39.1	35.3	72.2	125	113	0	34	31
2014	7	30	10	27	0	0.974	-0.062	4.662	0.01	0.007	0	39.6	35.3	71.8	126	113	0	34	31
2014	7	30	10	37	0	0.948	-0.082	4.662	0.01	0.007	0	39.1	35.3	71.8	125	113	0	34	31
2014	7	30	10	47	0	0.971	-0.075	4.662	0.01	0.007	0	39.1	34.4	71.4	125	112	0	34	32
2014	7	30	10	57	0	0.919	-0.082	4.659	0.01	0.007	0	39.1	35.3	70.5	125	113	0	34	31
2014	7	30	11	7	0	0.935	-0.112	4.662	0.01	0.007	0	38.3	34.8	70.1	124	112	0	35	31
2014	7	30	11	17	0	0.958	-0.066	4.659	0.01	0.007	0	39.1	34.8	70.5	125	112	0	34	31
2014	7	30	11	27	0	0.919	-0.049	4.662	0.01	0.007	0	39.1	34.8	70.5	125	112	0	34	31
2014	7	30	11	37	0	0.968	-0.095	4.662	0.01	0.007	0	39.1	35.3	72.2	125	113	0	34	31
2014	7	30	11	47	0	0.922	-0.079	4.659	0.013	0.01	0	39.6	34.8	72.7	125	112	0	33	31
2014	7	30	11	57	0	0.965	-0.079	4.659	0.01	0.007	0	38.7	34.4	72.2	124	112	0	34	32
2014	7	30	12	7	0	0.978	-0.085	4.659	0.01	0.007	0	39.1	34.8	69.2	124	112	0	33	31
2014	7	30	12	17	0	0.981	-0.079	4.659	0.01	0.007	0	40.9	36.1	61.5	128	116	0	33	32
2014	7	30	12	27	0	0.925	-0.072	4.662	0.01	0.007	0	42.1	37.8	57.2	132	120	0	34	32
2014	7	30	12	37	0	0.932	-0.082	4.662	0.01	0.007	0	42.1	37.8	56.3	132	120	0	34	32
2014	7	30	12	47	0	0.968	-0.089	4.662	0.01	0.007	0	42.6	37.8	57.6	133	120	0	34	32
2014	7	30	12	57	0	0.978	-0.069	4.662	0.01	0.007	0	43	39.1	61.5	134	122	0	34	31
2014	7	30	13	7	0	0.965	-0.102	4.662	0.013	0.01	0	42.1	37.4	59.3	132	119	0	34	32
2014	7	30	13	17	0	0.988	-0.075	4.665	0.01	0.007	0	41.7	37.4	61.1	130	118	0	33	31
2014	7	30	13	27	0	0.991	-0.135	4.662	0.01	0.007	0	40.9	37	64.1	129	117	0	34	31
2014	7	30	13	37	0	0.968	-0.112	4.662	0.01	0.007	0	40.9	36.5	64.9	129	117	0	34	32
2014	7	30	13	47	0	0.961	-0.059	4.662	0.01	0.007	0	40.9	37	58.9	129	117	0	34	31
2014	7	30	13	57	0	0.948	-0.046	4.665	0.01	0.007	0	40.9	36.1	61.9	128	116	0	33	32
2014	7	30	14	7	0	0.978	-0.062	4.662	0.01	0.007	0	40.4	36.1	57.6	128	115	0	34	31
2014	7	30	14	17	0	0.945	-0.062	4.662	0.01	0.007	0	40.4	36.1	65.8	128	115	0	34	31
2014	7	30	14	27	0	0.961	-0.059	4.665	0.01	0.007	0	40.4	36.1	56.8	128	116	0	34	32
2014	7	30	14	37	0	0.965	-0.092	4.665	0.01	0.007	0	40.9	36.5	59.3	129	116	0	34	31
2014	7	30	14	47	0	0.978	-0.069	4.665	0.01	0.007	0	41.7	37.4	54.6	130	118	0	33	31
2014	7	30	14	57	0	1.01	-0.092	4.669	0.01	0.007	0	41.7	37.4	57.2	131	119	0	34	32
2014	7	30	15	7	0	0.984	-0.072	4.665	0.01	0.007	0	42.1	37.8	70.1	132	119	0	34	31
2014	7	30	15	17	0	0.997	-0.069	4.669	0.01	0.007	0	41.7	37.4	71.8	131	118	0	34	31
2014	7	30	15	27	0	0.961	-0.095	4.669	0.01	0.007	0	40.9	36.5	71.4	129	117	0	34	32
2014	7	30	15	37	0	0.948	-0.082	4.669	0.01	0.007	0	40.4	36.1	69.7	128	116	0	34	32
2014	7	30	15	47	0	0.951	-0.066	4.669	0.016	0.013	0	41.7	37	54.2	130	117	0	33	31
2014	7	30	15	57	0	0.951	-0.072	4.669	0.01	0.007	0	41.7	37.8	65.4	131	119	0	34	31
2014	7	30	16	7	0	0.958	-0.075	4.669	0.01	0.007	0	42.6	37.8	67.9	132	119	0	33	31
2014	7	30	16	17	0	0.978	-0.085	4.669	0.01	0.007	0	41.3	37.4	73.5	130	118	0	34	31
2014	7	30	16	27	0	0.978	-0.056	4.669	0.01	0.007	0	40.9	37	72.7	129	117	0	34	31
2014	7	30	16	37	0	0.938	-0.092	4.669	0.01	0.007	0	40	36.1	73.5	127	115	0	34	31
2014	7	30	16	47	0	0.984	-0.082	4.669	0.01	0.007	0	39.6	35.3	63.2	126	114	0	34	32
2014	7	30	16	57	0	0.971	-0.062	4.672	0.01	0.007	0	41.7	37.8	55.9	131	119	0	34	31
2014	7	30	17	7	0	0.997	-0.062	4.672	0.01	0.007	0	42.6	37.8	67.1	133	120	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	30	17	17	0	0.968	-0.072	4.672	0.01	0.007	0	41.7	37.8	72.7	132	119	0	35	31
2014	7	30	17	27	0	0.968	-0.049	4.672	0.01	0.007	0	40.9	37	70.1	130	118	0	35	32
2014	7	30	17	37	0	0.942	-0.072	4.672	0.01	0.007	0	40.9	36.1	73.1	128	116	0	33	32
2014	7	30	17	47	0	0.938	-0.085	4.672	0.01	0.007	0	40	35.7	74.4	127	115	0	34	32
2014	7	30	17	57	0	0.984	-0.092	4.672	0.013	0.01	0	39.1	34.8	74.8	125	113	0	34	32
2014	7	30	18	7	0	0.942	-0.082	4.672	0.01	0.007	0	38.7	34.8	76.1	124	112	0	34	31
2014	7	30	18	17	0	0.945	-0.098	4.672	0.01	0.007	0	39.1	34.8	75.7	125	112	0	34	31
2014	7	30	18	27	0	0.968	-0.098	4.672	0.01	0.007	0	39.1	34.8	76.5	125	113	0	34	32
2014	7	30	18	37	0	0.928	-0.112	4.672	0.01	0.007	0	39.1	34.4	76.5	125	112	0	34	32
2014	7	30	18	47	0	0.925	-0.095	4.672	0.01	0.007	0	39.1	34.4	75.7	125	112	0	34	32
2014	7	30	18	57	0	0.948	-0.112	4.672	0.01	0.007	0	39.1	35.3	74.8	125	113	0	34	31
2014	7	30	19	7	0	0.958	-0.062	4.672	0.01	0.007	0	39.1	34.8	77.4	125	113	0	34	32
2014	7	30	19	17	0	0.971	-0.092	4.672	0.01	0.007	0	39.1	34.8	77	125	113	0	34	32
2014	7	30	19	27	0	0.945	-0.095	4.672	0.013	0.01	0	39.6	35.3	77	126	113	0	34	31
2014	7	30	19	37	0	0.965	-0.095	4.672	0.01	0.007	0	39.6	34.8	77.4	126	113	0	34	32
2014	7	30	19	47	0	0.981	-0.102	4.672	0.01	0.007	0	39.1	34.8	77.4	125	113	0	34	32
2014	7	30	19	57	0	0.961	-0.115	4.672	0.013	0.01	0	39.6	34.8	77.8	126	113	0	34	32
2014	7	30	20	7	0	0.974	-0.089	4.672	0.01	0.007	0	39.6	34.8	77.4	126	113	0	34	32
2014	7	30	20	17	0	0.945	-0.115	4.672	0.01	0.007	0	39.6	35.3	76.1	126	114	0	34	32
2014	7	30	20	27	0	0.981	-0.069	4.675	0.01	0.007	0	40	35.3	77.4	127	114	0	34	32
2014	7	30	20	37	0	0.919	-0.056	4.672	0.01	0.007	0	40	35.3	77	127	114	0	34	32
2014	7	30	20	47	0	0.938	-0.079	4.672	0.01	0.007	0	39.6	34.4	75.7	126	113	0	34	33
2014	7	30	20	57	0	0.948	-0.075	4.672	0.01	0.007	0	39.6	35.3	77	126	114	0	34	32
2014	7	30	21	7	0	0.925	-0.069	4.672	0.01	0.007	0	39.1	34.8	77	125	112	0	34	31
2014	7	30	21	17	0	0.971	-0.095	4.672	0.01	0.007	0	38.7	34.4	77	124	111	0	34	31
2014	7	30	21	27	0	0.935	-0.098	4.672	0.01	0.007	0	38.3	34.4	77.4	123	111	0	34	31
2014	7	30	21	37	0	0.925	-0.108	4.672	0.01	0.007	0	38.7	34	77	124	111	0	34	32
2014	7	30	21	47	0	0.971	-0.108	4.672	0.01	0.007	0	38.3	34.4	77.4	123	111	0	34	31
2014	7	30	21	57	0	0.928	-0.112	4.672	0.01	0.007	0	39.1	34	76.5	124	111	0	33	32
2014	7	30	22	7	0	0.978	-0.075	4.672	0.01	0.007	0	38.7	34.4	76.1	124	111	0	34	31
2014	7	30	22	17	0	0.935	-0.056	4.672	0.01	0.007	0	38.3	34.8	77.4	124	112	0	35	31
2014	7	30	22	27	0	0.948	-0.085	4.672	0.01	0.007	0	38.7	34.8	75.7	124	112	0	34	31
2014	7	30	22	37	0	0.984	-0.098	4.672	0.01	0.007	0	38.7	34.8	76.5	124	112	0	34	31
2014	7	30	22	47	0	0.912	-0.098	4.672	0.01	0.007	0	38.7	34.4	77	124	112	0	34	32
2014	7	30	22	57	0	0.915	-0.059	4.672	0.01	0.007	0	38.7	34.4	76.1	124	112	0	34	32
2014	7	30	23	7	0	0.978	-0.049	4.672	0.01	0.007	0	38.7	34.4	77	124	112	0	34	32
2014	7	30	23	17	0	0.945	-0.072	4.672	0.01	0.007	0	38.7	34	76.5	124	111	0	34	32
2014	7	30	23	27	0	0.961	-0.046	4.672	0.01	0.007	0	39.1	34	77	124	111	0	33	32
2014	7	30	23	37	0	0.965	-0.079	4.672	0.01	0.007	0	39.1	34.8	77.4	125	112	0	34	31
2014	7	30	23	47	0	0.948	-0.135	4.672	0.01	0.007	0	38.3	34	76.5	124	111	0	35	32
2014	7	30	23	57	0	0.961	-0.105	4.672	0.01	0.007	0	38.7	34.8	76.5	124	112	0	34	31
2014	7	31	0	7	0	0.942	-0.066	4.672	0.01	0.007	0	38.7	34.4	76.5	124	112	0	34	32
2014	7	31	0	17	0	0.955	-0.089	4.672	0.01	0.007	0	38.7	34.8	77.4	124	112	0	34	31
2014	7	31	0	27	0	0.928	-0.079	4.672	0.01	0.007	0	38.7	34.4	76.5	124	112	0	34	32
2014	7	31	0	37	0	0.951	-0.125	4.672	0.01	0.007	0	38.7	34.4	76.1	124	111	0	34	31
2014	7	31	0	47	0	0.938	-0.108	4.672	0.01	0.007	0	38.3	34.8	77	124	112	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	0	57	0	0.994	-0.082	4.672	0.01	0.007	0	38.7	34.8	77	124	112	0	34	31
2014	7	31	1	7	0	0.919	-0.082	4.672	0.01	0.007	0	38.7	34.4	77	124	112	0	34	32
2014	7	31	1	17	0	0.978	-0.046	4.669	0.01	0.007	0	38.7	34	77.8	124	111	0	34	32
2014	7	31	1	27	0	0.919	-0.115	4.672	0.01	0.007	0	39.1	34.4	77	124	112	0	33	32
2014	7	31	1	37	0	0.912	-0.098	4.669	0.01	0.007	0	38.3	34	77	124	111	0	35	32
2014	7	31	1	47	0	0.961	-0.075	4.669	0.01	0.007	0	38.7	34.8	77	124	112	0	34	31
2014	7	31	1	57	0	0.961	-0.105	4.669	0.01	0.007	0	38.3	34	76.5	123	111	0	34	32
2014	7	31	2	7	0	0.988	-0.092	4.669	0.01	0.007	0	38.7	34.8	76.1	124	112	0	34	31
2014	7	31	2	17	0	0.961	-0.108	4.669	0.01	0.007	0	38.3	34	76.1	124	111	0	35	32
2014	7	31	2	27	0	0.938	-0.085	4.669	0.01	0.007	0	38.7	34.8	76.5	124	112	0	34	31
2014	7	31	2	37	0	0.965	-0.075	4.669	0.01	0.007	0	38.7	34.8	77.4	124	112	0	34	31
2014	7	31	2	47	0	0.938	-0.072	4.669	0.01	0.007	0	38.7	34.8	77.4	124	112	0	34	31
2014	7	31	2	57	0	0.951	-0.079	4.669	0.01	0.007	0	39.1	34.4	77.4	125	112	0	34	32
2014	7	31	3	7	0	0.951	-0.039	4.669	0.01	0.007	0	39.1	34.4	77.4	125	112	0	34	32
2014	7	31	3	17	0	0.942	-0.043	4.665	0.01	0.007	0	38.7	34.4	77.4	124	112	0	34	32
2014	7	31	3	27	0	0.925	-0.092	4.665	0.01	0.007	0	38.7	34.4	76.1	124	112	0	34	32
2014	7	31	3	37	0	0.935	-0.095	4.665	0.01	0.007	0	38.7	34.8	76.1	124	112	0	34	31
2014	7	31	3	47	0	0.971	-0.075	4.665	0.01	0.007	0	38.7	34.4	77	124	112	0	34	32
2014	7	31	3	57	0	0.948	-0.082	4.665	0.01	0.007	0	38.7	34.4	77	124	112	0	34	32
2014	7	31	4	7	0	0.965	-0.108	4.662	0.01	0.007	0	38.7	34.8	76.1	124	112	0	34	31
2014	7	31	4	17	0	0.974	-0.121	4.662	0.01	0.007	0	38.7	34.8	76.1	125	113	0	35	32
2014	7	31	4	27	0	0.912	-0.082	4.662	0.01	0.007	0	39.1	34.4	75.7	125	112	0	34	32
2014	7	31	4	37	0	0.932	-0.095	4.662	0.013	0.01	0	39.1	34.8	74.8	124	112	0	33	31
2014	7	31	4	47	0	0.988	-0.115	4.659	0.013	0.01	0	39.1	34.4	76.1	125	112	0	34	32
2014	7	31	4	57	0	0.951	-0.075	4.659	0.01	0.007	0	39.1	35.3	75.7	125	113	0	34	31
2014	7	31	5	7	0	0.922	-0.105	4.659	0.01	0.007	0	38.7	35.3	74.4	125	113	0	35	31
2014	7	31	5	17	0	0.938	-0.092	4.656	0.01	0.007	0	39.6	35.3	73.5	126	114	0	34	32
2014	7	31	5	27	0	1.01	-0.072	4.656	0.01	0.007	0	39.6	34.8	73.5	126	113	0	34	32
2014	7	31	5	37	0	0.938	-0.089	4.656	0.01	0.007	0	40	36.1	73.1	127	115	0	34	31
2014	7	31	5	47	0	0.948	-0.079	4.656	0.01	0.007	0	40	35.7	73.5	127	115	0	34	32
2014	7	31	5	57	0	0.938	-0.115	4.649	0.01	0.007	0	39.6	35.3	71.4	126	114	0	34	32
2014	7	31	6	7	0	0.902	-0.108	4.646	0.01	0.007	0	39.6	35.3	72.7	126	114	0	34	32
2014	7	31	6	17	0	0.951	-0.085	4.642	0.01	0.007	0	40	35.3	72.7	127	114	0	34	32
2014	7	31	6	27	0	0.938	-0.082	4.639	0.013	0.01	0	40	35.7	72.7	127	115	0	34	32
2014	7	31	6	37	0	0.932	-0.092	4.639	0.01	0.007	0	40	36.1	72.2	127	115	0	34	31
2014	7	31	6	47	0	0.974	-0.102	4.636	0.01	0.007	0	40.4	35.7	73.5	128	115	0	34	32
2014	7	31	6	57	0	0.909	-0.079	4.636	0.01	0.007	0	40	35.7	73.5	127	115	0	34	32
2014	7	31	7	7	0	0.974	-0.102	4.636	0.01	0.007	0	39.6	35.7	74.8	127	115	0	35	32
2014	7	31	7	17	0	0.906	-0.105	4.633	0.01	0.007	0	39.6	35.3	74.4	126	114	0	34	32
2014	7	31	7	27	0	0.945	-0.079	4.633	0.01	0.007	0	39.6	35.7	74.8	126	114	0	34	31
2014	7	31	7	37	0	0.899	-0.125	4.633	0.01	0.007	0	40.4	36.1	74.8	128	116	0	34	32
2014	7	31	7	47	0	0.955	-0.075	4.629	0.01	0.007	0	40	36.1	74	127	115	0	34	31
2014	7	31	7	57	0	0.925	-0.095	4.629	0.01	0.007	0	40	35.7	75.7	127	115	0	34	32
2014	7	31	8	7	0	0.915	-0.069	4.629	0.01	0.007	0	39.6	35.3	74.8	126	115	0	34	33
2014	7	31	8	17	0	0.948	-0.079	4.626	0.01	0.007	0	40	36.1	76.5	127	115	0	34	31
2014	7	31	8	27	0	0.866	-0.069	4.626	0.01	0.007	0	39.6	35.7	75.7	126	114	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	8	37	0	0.928	-0.075	4.626	0.01	0.007	0	40	35.3	76.5	127	114	0	34	32
2014	7	31	8	47	0	0.919	-0.075	4.626	0.01	0.007	0	39.6	35.7	77	127	115	0	35	32
2014	7	31	8	57	0	0.915	-0.052	4.626	0.01	0.007	0	40	36.1	76.5	127	115	0	34	31
2014	7	31	9	7	0	0.965	-0.079	4.623	0.01	0.007	0	40.4	36.1	77.8	128	116	0	34	32
2014	7	31	9	17	0	0.932	-0.049	4.623	0.013	0.01	0	40	36.1	77	127	116	0	34	32
2014	7	31	9	27	0	0.945	-0.098	4.623	0.01	0.007	0	40.4	35.7	77	128	115	0	34	32
2014	7	31	9	37	0	0.961	-0.082	4.623	0.01	0.007	0	39.6	35.7	76.5	127	115	0	35	32
2014	7	31	9	47	0	0.919	-0.108	4.619	0.01	0.007	0	40	36.1	75.3	127	115	0	34	31
2014	7	31	9	57	0	0.935	-0.085	4.619	0.01	0.007	0	39.6	35.7	74.8	126	115	0	34	32
2014	7	31	10	7	0	0.902	-0.108	4.616	0.01	0.007	0	40	35.7	74.4	127	115	0	34	32
2014	7	31	10	17	0	0.919	-0.102	4.613	0.013	0.01	0	40	35.3	71.8	127	114	0	34	32
2014	7	31	10	27	0	0.915	-0.092	4.61	0.01	0.007	0	39.1	35.3	72.7	126	114	0	35	32
2014	7	31	10	37	0	0.948	-0.115	4.603	0.01	0.007	0	40.4	36.1	72.2	128	116	0	34	32
2014	7	31	10	47	0	0.945	-0.095	4.6	0.01	0.007	0	40	35.7	74	128	115	0	35	32
2014	7	31	10	57	0	0.932	-0.112	4.6	0.01	0.007	0	40	36.5	74.8	127	116	0	34	31
2014	7	31	11	7	0	0.948	-0.102	4.6	0.01	0.007	0	39.6	35.7	73.5	127	115	0	35	32
2014	7	31	11	17	0	0.922	-0.102	4.596	0.01	0.007	0	40	35.7	75.7	127	115	0	34	32
2014	7	31	11	27	0	0.889	-0.105	4.596	0.01	0.007	0	40	35.7	76.1	127	115	0	34	32
2014	7	31	11	37	0	0.906	-0.125	4.596	0.01	0.007	0	39.6	35.3	75.3	126	114	0	34	32
2014	7	31	11	47	0	0.935	-0.082	4.593	0.01	0.007	0	39.1	35.3	76.5	126	114	0	35	32
2014	7	31	11	57	0	0.925	-0.118	4.593	0.01	0.007	0	39.6	35.3	77	126	114	0	34	32
2014	7	31	12	7	0	0.902	-0.098	4.593	0.01	0.007	0	39.1	34.8	77.8	125	113	0	34	32
2014	7	31	12	17	0	0.938	-0.118	4.59	0.013	0.01	0	39.6	35.3	77.4	126	114	0	34	32
2014	7	31	12	27	0	0.935	-0.095	4.59	0.01	0.007	0	39.1	35.3	76.1	125	113	0	34	31
2014	7	31	12	37	0	0.886	-0.089	4.59	0.01	0.007	0	40	35.7	79.6	127	115	0	34	32
2014	7	31	12	47	0	0.899	-0.102	4.59	0.01	0.007	0	39.6	35.3	78.7	126	114	0	34	32
2014	7	31	12	57	0	0.948	-0.069	4.587	0.01	0.007	0	39.6	34.8	77	126	113	0	34	32
2014	7	31	13	7	0	0.915	-0.069	4.587	0.01	0.007	0	38.7	34.8	77	125	113	0	35	32
2014	7	31	13	17	0	0.935	-0.108	4.583	0.01	0.007	0	39.1	34.8	76.5	125	113	0	34	32
2014	7	31	13	27	0	0.925	-0.082	4.583	0.01	0.007	0	39.6	35.3	74.8	125	113	0	33	31
2014	7	31	13	37	0	0.886	-0.072	4.58	0.01	0.007	0	39.1	34.8	74.8	125	113	0	34	32
2014	7	31	13	47	0	0.958	-0.075	4.57	0.01	0.007	0	39.1	35.3	74	126	114	0	35	32
2014	7	31	13	57	0	0.928	-0.092	4.57	0.013	0.01	0	39.6	35.7	74.8	126	114	0	34	31
2014	7	31	14	7	0	0.915	-0.062	4.567	0.013	0.01	0	40	36.1	74.8	127	115	0	34	31
2014	7	31	14	17	0	0.922	-0.102	4.567	0.01	0.007	0	39.1	35.3	76.1	125	113	0	34	31
2014	7	31	14	27	0	0.876	-0.056	4.564	0.01	0.007	0	39.6	35.3	75.3	126	113	0	34	31
2014	7	31	14	37	0	0.925	-0.112	4.564	0.01	0.007	0	39.1	34.8	74.8	126	113	0	35	32
2014	7	31	14	47	0	0.915	-0.069	4.56	0.01	0.007	0	39.1	34.8	76.5	125	113	0	34	32
2014	7	31	14	57	0	0.866	-0.066	4.56	0.01	0.007	0	39.1	34.8	76.5	125	113	0	34	32
2014	7	31	15	7	0	0.896	-0.092	4.56	0.01	0.007	0	39.1	35.3	76.5	125	113	0	34	31
2014	7	31	15	17	0	0.942	-0.092	4.557	0.01	0.007	0	38.7	34.4	78.3	124	112	0	34	32
2014	7	31	15	27	0	0.915	-0.092	4.557	0.01	0.007	0	38.7	34.8	78.3	124	112	0	34	31
2014	7	31	15	37	0	0.892	-0.062	4.557	0.01	0.007	0	39.1	34.8	76.1	125	113	0	34	32
2014	7	31	15	47	0	0.883	-0.079	4.557	0.01	0.007	0	39.6	35.3	78.7	126	113	0	34	31
2014	7	31	15	57	0	0.896	-0.075	4.557	0.016	0.013	0	39.1	35.3	77.8	126	113	0	35	31
2014	7	31	16	7	0	0.955	-0.092	4.554	0.01	0.007	0	40	35.7	77	127	114	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	16	17	0	0.902	-0.066	4.547	0.01	0.007	0	43	38.3	50.7	134	121	0	34	32
2014	7	31	16	27	0	0.919	-0.075	4.551	0.01	0.007	0	40.9	37	60.6	129	117	0	34	31
2014	7	31	16	37	0	0.942	-0.049	4.547	0.01	0.007	0	40.4	36.1	56.3	128	115	0	34	31
2014	7	31	16	47	0	0.971	-0.059	4.547	0.01	0.007	0	43	38.7	49.5	134	122	0	34	32
2014	7	31	16	57	0	0.899	-0.069	4.544	0.01	0.007	0	42.1	37.4	55.9	132	119	0	34	32
2014	7	31	17	7	0	0.883	-0.089	4.541	0.013	0.01	0	41.3	37	49	130	117	0	34	31
2014	7	31	17	17	0	0.892	-0.072	4.551	0.01	0.007	0	40.9	36.1	76.1	128	116	0	33	32
2014	7	31	17	27	0	0.932	-0.069	4.547	0.01	0.007	0	40.9	37	75.3	129	117	0	34	31
2014	7	31	17	37	0	0.919	-0.066	4.547	0.01	0.007	0	40.9	36.5	75.7	129	117	0	34	32
2014	7	31	17	47	0	0.928	-0.049	4.547	0.01	0.007	0	40.9	36.5	74.4	128	116	0	33	31
2014	7	31	17	57	0	0.955	-0.095	4.541	0.013	0.01	0	40.4	36.5	73.5	128	116	0	34	31
2014	7	31	18	7	0	0.896	-0.095	4.537	0.01	0.007	0	40.4	36.5	74.4	128	116	0	34	31
2014	7	31	18	17	0	0.932	-0.059	4.534	0.013	0.01	0	40.4	36.5	74	128	116	0	34	31
2014	7	31	18	27	0	0.938	-0.102	4.534	0.013	0.01	0	40	35.7	74	127	115	0	34	32
2014	7	31	18	37	0	0.948	-0.059	4.531	0.01	0.007	0	40.4	36.5	75.3	128	116	0	34	31
2014	7	31	18	47	0	0.892	-0.066	4.531	0.01	0.007	0	40	37	74.8	128	117	0	35	31
2014	7	31	18	57	0	0.915	-0.095	4.531	0.01	0.007	0	40.4	36.1	76.1	128	116	0	34	32
2014	7	31	19	7	0	0.978	-0.085	4.531	0.01	0.007	0	40.4	36.1	75.3	128	116	0	34	32
2014	7	31	19	17	0	0.902	-0.098	4.528	0.01	0.007	0	40.9	36.5	75.3	129	117	0	34	32
2014	7	31	19	27	0	0.896	-0.052	4.531	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	31	19	37	0	0.991	-0.082	4.528	0.01	0.007	0	40.9	37	76.5	129	117	0	34	31
2014	7	31	19	47	0	0.922	-0.052	4.528	0.01	0.007	0	41.3	36.5	76.1	130	117	0	34	32
2014	7	31	19	57	0	0.942	-0.056	4.528	0.01	0.007	0	41.3	37	76.5	130	117	0	34	31
2014	7	31	20	7	0	0.906	-0.062	4.528	0.013	0.01	0	40.9	37	76.5	129	117	0	34	31
2014	7	31	20	17	0	0.928	-0.056	4.528	0.01	0.007	0	40.9	36.5	76.1	129	117	0	34	32
2014	7	31	20	27	0	0.863	-0.046	4.524	0.01	0.007	0	40.9	36.5	74.8	129	117	0	34	32
2014	7	31	20	37	0	0.928	-0.082	4.524	0.01	0.007	0	40.9	36.5	74.8	129	117	0	34	32
2014	7	31	20	47	0	0.912	-0.089	4.524	0.013	0.01	0	40.9	36.5	75.7	128	117	0	33	32
2014	7	31	20	57	0	0.899	-0.056	4.524	0.01	0.007	0	40.4	36.5	77	128	116	0	34	31
2014	7	31	21	7	0	0.945	-0.095	4.524	0.01	0.007	0	40	36.5	77.4	127	116	0	34	31
2014	7	31	21	17	0	0.915	-0.062	4.524	0.01	0.007	0	40	36.1	77.4	127	115	0	34	31
2014	7	31	21	27	0	0.942	-0.089	4.524	0.01	0.007	0	40	36.1	77	127	115	0	34	31
2014	7	31	21	37	0	0.915	-0.046	4.524	0.01	0.007	0	40	35.3	77	127	114	0	34	32
2014	7	31	21	47	0	0.883	-0.066	4.524	0.01	0.007	0	40	34.8	77.4	127	114	0	34	33
2014	7	31	21	57	0	0.909	-0.072	4.521	0.01	0.007	0	39.6	36.1	77	127	115	0	35	31
2014	7	31	22	7	0	0.932	-0.085	4.521	0.01	0.007	0	39.6	36.1	77.8	126	115	0	34	31
2014	7	31	22	17	0	0.919	-0.062	4.521	0.01	0.007	0	39.6	36.1	78.3	127	115	0	35	31
2014	7	31	22	27	0	0.883	-0.075	4.521	0.01	0.007	0	39.6	35.7	77	126	114	0	34	31
2014	7	31	22	37	0	0.869	-0.03	4.521	0.013	0.01	0	40	35.7	77.8	127	115	0	34	32
2014	7	31	22	47	0	0.925	-0.049	4.521	0.01	0.007	0	39.6	35.7	77.8	126	114	0	34	31
2014	7	31	22	57	0	0.948	-0.092	4.521	0.01	0.007	0	39.6	35.7	77.8	126	114	0	34	31
2014	7	31	23	7	0	0.951	-0.079	4.518	0.01	0.007	0	39.6	35.3	78.3	126	114	0	34	32
2014	7	31	23	17	0	0.909	-0.066	4.518	0.01	0.007	0	39.6	35.3	78.3	126	114	0	34	32
2014	7	31	23	27	0	0.912	-0.075	4.518	0.01	0.007	0	39.6	35.3	77.8	126	114	0	34	32
2014	7	31	23	37	0	0.879	-0.03	4.518	0.01	0.007	0	40	35.7	79.1	127	115	0	34	32
2014	7	31	23	47	0	0.909	-0.082	4.518	0.01	0.007	0	39.6	35.3	72.7	126	114	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2014	7	31	23	57	0	0.925	-0.062	4.518	0.01	0.007	0	39.1	35.3	78.3	125	113	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	0	8	18	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	1	0	18	18	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	1	0	28	18	33	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	1	0	38	18	33	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	1	0	48	18	33	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	1	0	58	18	32	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	1	1	8	18	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	1	1	18	18	32	0	0	0	0	0	0	0	69.71	0	0	11.6
2014	7	1	1	28	18	31	0	0	0	0	0	0	0	69.66	0	0	11.6
2014	7	1	1	38	18	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	1	1	48	18	33	0	0	0	0	0	0	0	69.57	0	0	11.6
2014	7	1	1	58	18	32	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	1	2	8	18	33	0	0	0	0	0	0	0	69.44	0	0	11.6
2014	7	1	2	18	18	32	0	0	0	0	0	0	0	69.4	0	0	11.6
2014	7	1	2	28	18	32	0	0	0	0	0	0	0	69.33	0	0	11.4
2014	7	1	2	38	18	33	0	0	0	0	0	0	0	69.3	0	0	11.2
2014	7	1	2	48	18	33	0	0	0	0	0	0	0	69.24	0	0	11.2
2014	7	1	2	58	18	33	0	0	0	0	0	0	0	69.19	0	0	11.2
2014	7	1	3	8	18	32	0	0	0	0	0	0	0	69.13	0	0	11.2
2014	7	1	3	18	18	33	0	0	0	0	0	0	0	69.08	0	0	11.4
2014	7	1	3	28	18	33	0	0	0	0	0	0	0	69.03	0	0	11.2
2014	7	1	3	38	18	33	0	0	0	0	0	0	0	68.97	0	0	11.4
2014	7	1	3	48	18	33	0	0	0	0	0	0	0	68.92	0	0	11.4
2014	7	1	3	58	18	33	0	0	0	0	0	0	0	68.88	0	0	11.4
2014	7	1	4	8	18	32	0	0	0	0	0	0	0	68.83	0	0	11.4
2014	7	1	4	18	18	32	0	0	0	0	0	0	0	68.79	0	0	11.4
2014	7	1	4	28	18	33	0	0	0	0	0	0	0	68.74	0	0	11.4
2014	7	1	4	38	18	33	0	0	0	0	0	0	0	68.7	0	0	11.6
2014	7	1	4	48	18	32	0	0	0	0	0	0	0	68.67	0	0	11.4
2014	7	1	4	58	18	33	0	0	0	0	0	0	0	68.61	0	0	11.4
2014	7	1	5	8	18	32	0	0	0	0	0	0	0	68.58	0	0	11.4
2014	7	1	5	18	18	33	0	0	0	0	0	0	0	68.52	0	0	11.4
2014	7	1	5	28	18	33	0	0	0	0	0	0	0	68.49	0	0	11.4
2014	7	1	5	38	18	33	0	0	0	0	0	0	0	68.43	0	0	11.4
2014	7	1	5	48	18	32	0	0	0	0	0	0	0	68.38	0	0	11.4
2014	7	1	5	58	18	33	0	0	0	0	0	0	0	68.32	0	0	11.4
2014	7	1	6	8	18	32	0	0	0	0	0	0	0	68.29	0	0	11.4
2014	7	1	6	18	18	32	0	0	0	0	0	0	0	68.25	0	0	11.4
2014	7	1	6	28	18	33	0	0	0	0	0	0	0	68.22	0	0	11.4
2014	7	1	6	38	18	33	0	0	0	0	0	0	0	68.16	0	0	11.4
2014	7	1	6	48	18	33	0	0	0	0	0	0	0	68.13	0	0	11.4
2014	7	1	6	58	18	32	0	0	0	0	0	0	0	68.09	0	0	11.6
2014	7	1	7	8	18	32	0	0	0	0	0	0	0	68.05	0	0	11.8
2014	7	1	7	18	18	33	0	0	0	0	0	0	0	68.05	0	0	11.8
2014	7	1	7	28	18	33	0	0	0	0	0	0	0	68.05	0	0	11.8
2014	7	1	7	38	18	33	0	0	0	0	0	0	0	68.04	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	7	48	18	34	0	0	0	0	0	0	0	68.05	0	0	12.2
2014	7	1	7	58	18	32	0	0	0	0	0	0	0	68.05	0	0	12.2
2014	7	1	8	8	18	33	0	0	0	0	0	0	0	68.07	0	0	12.2
2014	7	1	8	18	18	33	0	0	0	0	0	0	0	68.09	0	0	12.4
2014	7	1	8	28	18	33	0	0	0	0	0	0	0	68.11	0	0	12.4
2014	7	1	8	38	18	32	0	0	0	0	0	0	0	68.13	0	0	12.4
2014	7	1	8	48	18	32	0	0	0	0	0	0	0	68.16	0	0	12.4
2014	7	1	8	58	18	32	0	0	0	0	0	0	0	68.18	0	0	12.6
2014	7	1	9	8	18	33	0	0	0	0	0	0	0	68.23	0	0	12.6
2014	7	1	9	18	18	32	0	0	0	0	0	0	0	68.27	0	0	12.6
2014	7	1	9	28	18	33	0	0	0	0	0	0	0	68.32	0	0	12.6
2014	7	1	9	38	18	33	0	0	0	0	0	0	0	68.38	0	0	12.6
2014	7	1	9	48	18	32	0	0	0	0	0	0	0	68.45	0	0	12.8
2014	7	1	9	58	18	33	0	0	0	0	0	0	0	68.5	0	0	13
2014	7	1	10	8	18	32	0	0	0	0	0	0	0	68.58	0	0	13.2
2014	7	1	10	18	18	33	0	0	0	0	0	0	0	68.63	0	0	13
2014	7	1	10	28	18	32	0	0	0	0	0	0	0	68.7	0	0	13
2014	7	1	10	38	18	33	0	0	0	0	0	0	0	68.77	0	0	13
2014	7	1	10	48	18	33	0	0	0	0	0	0	0	68.86	0	0	13
2014	7	1	10	58	18	32	0	0	0	0	0	0	0	68.92	0	0	13
2014	7	1	11	8	18	33	0	0	0	0	0	0	0	69.03	0	0	13
2014	7	1	11	18	18	33	0	0	0	0	0	0	0	69.1	0	0	13
2014	7	1	11	28	18	33	0	0	0	0	0	0	0	69.21	0	0	13
2014	7	1	11	38	18	32	0	0	0	0	0	0	0	69.28	0	0	13
2014	7	1	11	48	18	32	0	0	0	0	0	0	0	69.37	0	0	12.8
2014	7	1	11	58	18	32	0	0	0	0	0	0	0	69.44	0	0	13
2014	7	1	12	8	18	32	0	0	0	0	0	0	0	69.49	0	0	13
2014	7	1	12	18	18	32	0	0	0	0	0	0	0	69.58	0	0	13
2014	7	1	12	28	18	33	0	0	0	0	0	0	0	69.75	0	0	13
2014	7	1	12	38	18	33	0	0	0	0	0	0	0	69.84	0	0	13
2014	7	1	12	48	18	32	0	0	0	0	0	0	0	69.93	0	0	13
2014	7	1	12	58	18	32	0	0	0	0	0	0	0	70	0	0	13
2014	7	1	13	8	18	32	0	0	0	0	0	0	0	70.05	0	0	13.2
2014	7	1	13	18	18	33	0	0	0	0	0	0	0	70.12	0	0	13
2014	7	1	13	28	18	33	0	0	0	0	0	0	0	70.21	0	0	13
2014	7	1	13	38	18	33	0	0	0	0	0	0	0	70.32	0	0	13.2
2014	7	1	13	48	18	32	0	0	0	0	0	0	0	70.36	0	0	13.4
2014	7	1	13	58	18	32	0	0	0	0	0	0	0	70.39	0	0	13.2
2014	7	1	14	8	18	33	0	0	0	0	0	0	0	70.54	0	0	13.4
2014	7	1	14	18	18	33	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	1	14	28	18	32	0	0	0	0	0	0	0	70.66	0	0	13
2014	7	1	14	38	18	33	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	1	14	48	18	33	0	0	0	0	0	0	0	70.83	0	0	13
2014	7	1	14	58	18	32	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	7	1	15	8	18	31	0	0	0	0	0	0	0	70.93	0	0	13
2014	7	1	15	18	18	33	0	0	0	0	0	0	0	70.97	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	15	28	18	32	0	0	0	0	0	0	0	71.02	0	0	13
2014	7	1	15	38	18	32	0	0	0	0	0	0	0	71.06	0	0	12.8
2014	7	1	15	48	18	33	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	1	15	58	18	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	1	16	8	18	32	0	0	0	0	0	0	0	71.13	0	0	13
2014	7	1	16	18	18	33	0	0	0	0	0	0	0	71.15	0	0	13
2014	7	1	16	28	18	32	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	1	16	38	18	32	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	1	16	48	18	33	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	1	16	58	18	32	0	0	0	0	0	0	0	71.19	0	0	12.8
2014	7	1	17	8	18	33	0	0	0	0	0	0	0	71.19	0	0	12.6
2014	7	1	17	18	18	32	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	7	1	17	28	18	32	0	0	0	0	0	0	0	71.11	0	0	12
2014	7	1	17	38	18	33	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	1	17	48	18	32	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	1	17	58	18	32	0	0	0	0	0	0	0	71.08	0	0	12
2014	7	1	18	8	18	32	0	0	0	0	0	0	0	71.1	0	0	12
2014	7	1	18	18	18	32	0	0	0	0	0	0	0	71.08	0	0	12
2014	7	1	18	28	18	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	1	18	38	18	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	1	18	48	18	32	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	1	18	58	18	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	1	19	8	18	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	1	19	18	18	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	1	19	28	18	32	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	1	19	38	18	33	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	1	19	48	18	33	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	1	19	58	18	32	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	1	20	8	18	32	0	0	0	0	0	0	0	71.01	0	0	11.8
2014	7	1	20	18	18	32	0	0	0	0	0	0	0	71.01	0	0	11.8
2014	7	1	20	28	18	32	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	1	20	38	18	32	0	0	0	0	0	0	0	70.97	0	0	11.8
2014	7	1	20	48	18	32	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	1	20	58	18	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	1	21	8	18	33	0	0	0	0	0	0	0	70.88	0	0	11.8
2014	7	1	21	18	18	33	0	0	0	0	0	0	0	70.84	0	0	11.8
2014	7	1	21	28	18	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	1	21	38	18	32	0	0	0	0	0	0	0	70.77	0	0	11.8
2014	7	1	21	48	18	33	0	0	0	0	0	0	0	70.75	0	0	11.8
2014	7	1	21	58	18	33	0	0	0	0	0	0	0	70.72	0	0	11.8
2014	7	1	22	8	18	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	1	22	18	18	32	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	1	22	28	18	32	0	0	0	0	0	0	0	70.59	0	0	11.8
2014	7	1	22	38	18	32	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	1	22	48	18	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	1	22	58	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	1	23	8	18	33	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	1	23	18	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	1	23	28	18	33	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	1	23	38	18	33	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	1	23	48	18	33	0	0	0	0	0	0	0	70.2	0	0	11.8
2014	7	1	23	58	18	32	0	0	0	0	0	0	0	70.16	0	0	11.8
2014	7	2	0	8	18	33	0	0	0	0	0	0	0	70.11	0	0	11.8
2014	7	2	0	18	18	33	0	0	0	0	0	0	0	70.05	0	0	11.8
2014	7	2	0	28	18	32	0	0	0	0	0	0	0	70	0	0	11.8
2014	7	2	0	38	18	33	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	2	0	48	18	32	0	0	0	0	0	0	0	69.89	0	0	11.8
2014	7	2	0	58	18	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2014	7	2	1	8	18	32	0	0	0	0	0	0	0	69.78	0	0	11.8
2014	7	2	1	18	18	33	0	0	0	0	0	0	0	69.73	0	0	11.8
2014	7	2	1	28	18	33	0	0	0	0	0	0	0	69.67	0	0	11.8
2014	7	2	1	38	18	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	2	1	48	18	32	0	0	0	0	0	0	0	69.55	0	0	11.6
2014	7	2	1	58	18	32	0	0	0	0	0	0	0	69.48	0	0	11.6
2014	7	2	2	8	18	32	0	0	0	0	0	0	0	69.42	0	0	11.6
2014	7	2	2	18	18	32	0	0	0	0	0	0	0	69.37	0	0	11.6
2014	7	2	2	28	18	33	0	0	0	0	0	0	0	69.31	0	0	11.6
2014	7	2	2	38	18	33	0	0	0	0	0	0	0	69.24	0	0	11.6
2014	7	2	2	48	18	33	0	0	0	0	0	0	0	69.17	0	0	11.6
2014	7	2	2	58	18	32	0	0	0	0	0	0	0	69.12	0	0	11.6
2014	7	2	3	8	18	32	0	0	0	0	0	0	0	69.04	0	0	11.6
2014	7	2	3	18	18	32	0	0	0	0	0	0	0	68.97	0	0	11.6
2014	7	2	3	28	18	32	0	0	0	0	0	0	0	68.92	0	0	11.6
2014	7	2	3	38	18	32	0	0	0	0	0	0	0	68.85	0	0	11.6
2014	7	2	3	48	18	32	0	0	0	0	0	0	0	68.79	0	0	11.6
2014	7	2	3	58	18	32	0	0	0	0	0	0	0	68.72	0	0	11.6
2014	7	2	4	8	18	33	0	0	0	0	0	0	0	68.65	0	0	11.6
2014	7	2	4	18	18	33	0	0	0	0	0	0	0	68.59	0	0	11.6
2014	7	2	4	28	18	33	0	0	0	0	0	0	0	68.54	0	0	11.6
2014	7	2	4	38	18	33	0	0	0	0	0	0	0	68.47	0	0	11.6
2014	7	2	4	48	18	33	0	0	0	0	0	0	0	68.41	0	0	11.6
2014	7	2	4	58	18	33	0	0	0	0	0	0	0	68.36	0	0	11.6
2014	7	2	5	8	18	33	0	0	0	0	0	0	0	68.29	0	0	11.6
2014	7	2	5	18	18	32	0	0	0	0	0	0	0	68.22	0	0	11.6
2014	7	2	5	28	18	32	0	0	0	0	0	0	0	68.18	0	0	11.6
2014	7	2	5	38	18	33	0	0	0	0	0	0	0	68.11	0	0	11.6
2014	7	2	5	48	18	32	0	0	0	0	0	0	0	68.05	0	0	11.6
2014	7	2	5	58	18	33	0	0	0	0	0	0	0	68	0	0	11.6
2014	7	2	6	8	18	33	0	0	0	0	0	0	0	67.93	0	0	11.6
2014	7	2	6	18	18	33	0	0	0	0	0	0	0	67.89	0	0	11.6
2014	7	2	6	28	18	33	0	0	0	0	0	0	0	67.82	0	0	11.6
2014	7	2	6	38	18	33	0	0	0	0	0	0	0	67.77	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	6	48	18	32	0	0	0	0	0	0	0	67.73	0	0	11.8
2014	7	2	6	58	18	32	0	0	0	0	0	0	0	67.68	0	0	11.8
2014	7	2	7	8	18	32	0	0	0	0	0	0	0	67.64	0	0	11.8
2014	7	2	7	18	18	32	0	0	0	0	0	0	0	67.64	0	0	12
2014	7	2	7	28	18	32	0	0	0	0	0	0	0	67.62	0	0	12
2014	7	2	7	38	18	32	0	0	0	0	0	0	0	67.62	0	0	12
2014	7	2	7	48	18	33	0	0	0	0	0	0	0	67.62	0	0	12.2
2014	7	2	7	58	18	32	0	0	0	0	0	0	0	67.62	0	0	12.4
2014	7	2	8	8	18	33	0	0	0	0	0	0	0	67.64	0	0	12.4
2014	7	2	8	18	18	32	0	0	0	0	0	0	0	67.64	0	0	12.4
2014	7	2	8	28	18	32	0	0	0	0	0	0	0	67.68	0	0	12.6
2014	7	2	8	38	18	34	0	0	0	0	0	0	0	67.69	0	0	12.6
2014	7	2	8	48	18	33	0	0	0	0	0	0	0	67.73	0	0	12.6
2014	7	2	8	58	18	32	0	0	0	0	0	0	0	67.78	0	0	12.6
2014	7	2	9	8	18	32	0	0	0	0	0	0	0	67.8	0	0	12.6
2014	7	2	9	18	18	32	0	0	0	0	0	0	0	67.87	0	0	12.8
2014	7	2	9	28	18	32	0	0	0	0	0	0	0	67.93	0	0	12.8
2014	7	2	9	38	18	33	0	0	0	0	0	0	0	67.98	0	0	12.8
2014	7	2	9	48	18	33	0	0	0	0	0	0	0	68.04	0	0	12.8
2014	7	2	9	58	18	33	0	0	0	0	0	0	0	68.11	0	0	13
2014	7	2	10	8	18	32	0	0	0	0	0	0	0	68.18	0	0	13
2014	7	2	10	18	18	33	0	0	0	0	0	0	0	68.23	0	0	13
2014	7	2	10	28	18	33	0	0	0	0	0	0	0	68.31	0	0	13
2014	7	2	10	38	18	32	0	0	0	0	0	0	0	68.4	0	0	13
2014	7	2	10	48	18	33	0	0	0	0	0	0	0	68.47	0	0	13
2014	7	2	10	58	18	32	0	0	0	0	0	0	0	68.54	0	0	13
2014	7	2	11	8	18	32	0	0	0	0	0	0	0	68.63	0	0	13
2014	7	2	11	18	18	33	0	0	0	0	0	0	0	68.7	0	0	13
2014	7	2	11	28	18	33	0	0	0	0	0	0	0	68.77	0	0	13
2014	7	2	11	38	18	32	0	0	0	0	0	0	0	68.86	0	0	13
2014	7	2	11	48	18	33	0	0	0	0	0	0	0	68.95	0	0	13
2014	7	2	11	58	18	33	0	0	0	0	0	0	0	69.03	0	0	13
2014	7	2	12	8	18	33	0	0	0	0	0	0	0	69.13	0	0	13
2014	7	2	12	18	18	33	0	0	0	0	0	0	0	69.22	0	0	13
2014	7	2	12	28	18	33	0	0	0	0	0	0	0	69.3	0	0	13.4
2014	7	2	12	38	18	32	0	0	0	0	0	0	0	69.39	0	0	13.4
2014	7	2	12	48	18	32	0	0	0	0	0	0	0	69.48	0	0	13.4
2014	7	2	12	58	18	33	0	0	0	0	0	0	0	69.57	0	0	13.4
2014	7	2	13	8	18	32	0	0	0	0	0	0	0	69.66	0	0	13.4
2014	7	2	13	18	18	33	0	0	0	0	0	0	0	69.75	0	0	13.8
2014	7	2	13	28	18	32	0	0	0	0	0	0	0	69.84	0	0	13.8
2014	7	2	13	38	18	33	0	0	0	0	0	0	0	69.91	0	0	13.8
2014	7	2	13	48	18	33	0	0	0	0	0	0	0	70	0	0	13.8
2014	7	2	13	58	18	32	0	0	0	0	0	0	0	70.09	0	0	13.4
2014	7	2	14	8	18	32	0	0	0	0	0	0	0	70.16	0	0	13.4
2014	7	2	14	18	18	33	0	0	0	0	0	0	0	70.23	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	14	28	18	33	0	0	0	0	0	0	0	70.3	0	0	13.4
2014	7	2	14	38	18	31	0	0	0	0	0	0	0	70.38	0	0	13.4
2014	7	2	14	48	18	32	0	0	0	0	0	0	0	70.43	0	0	13.4
2014	7	2	14	58	18	33	0	0	0	0	0	0	0	70.5	0	0	13.4
2014	7	2	15	8	18	32	0	0	0	0	0	0	0	70.56	0	0	13.4
2014	7	2	15	18	18	32	0	0	0	0	0	0	0	70.59	0	0	13.6
2014	7	2	15	28	18	33	0	0	0	0	0	0	0	70.63	0	0	13.4
2014	7	2	15	38	18	33	0	0	0	0	0	0	0	70.68	0	0	13.6
2014	7	2	15	48	18	32	0	0	0	0	0	0	0	70.68	0	0	13.4
2014	7	2	15	58	18	32	0	0	0	0	0	0	0	70.74	0	0	13.6
2014	7	2	16	8	18	32	0	0	0	0	0	0	0	70.75	0	0	13.4
2014	7	2	16	18	18	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	2	16	28	18	32	0	0	0	0	0	0	0	70.72	0	0	13.2
2014	7	2	16	38	18	32	0	0	0	0	0	0	0	70.74	0	0	13.4
2014	7	2	16	48	18	31	0	0	0	0	0	0	0	70.68	0	0	12.4
2014	7	2	16	58	18	33	0	0	0	0	0	0	0	70.74	0	0	13
2014	7	2	17	8	18	33	0	0	0	0	0	0	0	70.77	0	0	12.8
2014	7	2	17	18	18	32	0	0	0	0	0	0	0	70.77	0	0	12.6
2014	7	2	17	28	18	32	0	0	0	0	0	0	0	70.77	0	0	12.4
2014	7	2	17	38	18	32	0	0	0	0	0	0	0	70.77	0	0	12.2
2014	7	2	17	48	18	32	0	0	0	0	0	0	0	70.75	0	0	12
2014	7	2	17	58	18	32	0	0	0	0	0	0	0	70.74	0	0	11.8
2014	7	2	18	8	18	32	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	2	18	18	18	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	2	18	28	18	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	2	18	38	18	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	2	18	48	18	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	2	18	58	18	33	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	2	19	8	18	33	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	2	19	18	18	32	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	2	19	28	18	32	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	2	19	38	18	32	0	0	0	0	0	0	0	70.68	0	0	11.4
2014	7	2	19	48	18	32	0	0	0	0	0	0	0	70.68	0	0	11.2
2014	7	2	19	58	18	33	0	0	0	0	0	0	0	70.66	0	0	11.2
2014	7	2	20	8	18	32	0	0	0	0	0	0	0	70.65	0	0	11.2
2014	7	2	20	18	18	32	0	0	0	0	0	0	0	70.63	0	0	11.2
2014	7	2	20	28	18	31	0	0	0	0	0	0	0	70.61	0	0	11
2014	7	2	20	38	18	33	0	0	0	0	0	0	0	70.59	0	0	11
2014	7	2	20	48	18	33	0	0	0	0	0	0	0	70.59	0	0	11
2014	7	2	20	58	18	32	0	0	0	0	0	0	0	70.56	0	0	11
2014	7	2	21	8	18	32	0	0	0	0	0	0	0	70.52	0	0	11
2014	7	2	21	18	18	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	2	21	28	18	33	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	2	21	38	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	2	21	48	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	2	21	58	18	33	0	0	0	0	0	0	0	70.39	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	2	22	8	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	2	22	18	18	32	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	2	22	28	18	32	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	2	22	38	18	33	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	2	22	48	18	32	0	0	0	0	0	0	0	70.2	0	0	11.8
2014	7	2	22	58	18	32	0	0	0	0	0	0	0	70.16	0	0	11.8
2014	7	2	23	8	18	33	0	0	0	0	0	0	0	70.11	0	0	11.8
2014	7	2	23	18	18	33	0	0	0	0	0	0	0	70.07	0	0	11.8
2014	7	2	23	28	18	33	0	0	0	0	0	0	0	70.02	0	0	11.8
2014	7	2	23	38	18	32	0	0	0	0	0	0	0	69.96	0	0	11.8
2014	7	2	23	48	18	33	0	0	0	0	0	0	0	69.93	0	0	11.8
2014	7	2	23	58	18	33	0	0	0	0	0	0	0	69.89	0	0	11.8
2014	7	3	0	8	18	33	0	0	0	0	0	0	0	69.87	0	0	11.8
2014	7	3	0	18	18	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2014	7	3	0	28	18	34	0	0	0	0	0	0	0	69.8	0	0	11.8
2014	7	3	0	38	18	33	0	0	0	0	0	0	0	69.76	0	0	11.8
2014	7	3	0	48	18	32	0	0	0	0	0	0	0	69.73	0	0	11.8
2014	7	3	0	58	18	33	0	0	0	0	0	0	0	69.67	0	0	11.8
2014	7	3	1	8	18	33	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	3	1	18	18	33	0	0	0	0	0	0	0	69.57	0	0	11.8
2014	7	3	1	28	18	33	0	0	0	0	0	0	0	69.53	0	0	11.8
2014	7	3	1	38	18	33	0	0	0	0	0	0	0	69.48	0	0	11.8
2014	7	3	1	48	18	32	0	0	0	0	0	0	0	69.44	0	0	11.8
2014	7	3	1	58	18	32	0	0	0	0	0	0	0	69.39	0	0	11.8
2014	7	3	2	8	18	33	0	0	0	0	0	0	0	69.33	0	0	11.8
2014	7	3	2	18	18	32	0	0	0	0	0	0	0	69.26	0	0	11.8
2014	7	3	2	28	18	33	0	0	0	0	0	0	0	69.22	0	0	11.8
2014	7	3	2	38	18	33	0	0	0	0	0	0	0	69.15	0	0	11.6
2014	7	3	2	48	18	32	0	0	0	0	0	0	0	69.1	0	0	11.6
2014	7	3	2	58	18	32	0	0	0	0	0	0	0	69.03	0	0	11.6
2014	7	3	3	8	18	32	0	0	0	0	0	0	0	68.95	0	0	11.6
2014	7	3	3	18	18	32	0	0	0	0	0	0	0	68.9	0	0	11.6
2014	7	3	3	28	18	32	0	0	0	0	0	0	0	68.83	0	0	11.6
2014	7	3	3	38	18	32	0	0	0	0	0	0	0	68.76	0	0	11.6
2014	7	3	3	48	18	33	0	0	0	0	0	0	0	68.68	0	0	11.6
2014	7	3	3	58	18	32	0	0	0	0	0	0	0	68.63	0	0	11.6
2014	7	3	4	8	18	33	0	0	0	0	0	0	0	68.56	0	0	11.6
2014	7	3	4	18	18	32	0	0	0	0	0	0	0	68.49	0	0	11.6
2014	7	3	4	28	18	33	0	0	0	0	0	0	0	68.41	0	0	11.6
2014	7	3	4	38	18	32	0	0	0	0	0	0	0	68.34	0	0	11.6
2014	7	3	4	48	18	33	0	0	0	0	0	0	0	68.29	0	0	11.6
2014	7	3	4	58	18	33	0	0	0	0	0	0	0	68.22	0	0	11.6
2014	7	3	5	8	18	32	0	0	0	0	0	0	0	68.16	0	0	11.6
2014	7	3	5	18	18	33	0	0	0	0	0	0	0	68.11	0	0	11.6
2014	7	3	5	28	18	33	0	0	0	0	0	0	0	68.05	0	0	11.6
2014	7	3	5	38	18	33	0	0	0	0	0	0	0	67.98	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	5	48	18	33	0	0	0	0	0	0	0	67.93	0	0	11.6
2014	7	3	5	58	18	33	0	0	0	0	0	0	0	67.87	0	0	11.6
2014	7	3	6	8	18	33	0	0	0	0	0	0	0	67.82	0	0	11.6
2014	7	3	6	18	18	32	0	0	0	0	0	0	0	67.75	0	0	11.6
2014	7	3	6	28	18	32	0	0	0	0	0	0	0	67.71	0	0	11.6
2014	7	3	6	38	18	32	0	0	0	0	0	0	0	67.66	0	0	11.6
2014	7	3	6	48	18	33	0	0	0	0	0	0	0	67.6	0	0	11.8
2014	7	3	6	58	18	32	0	0	0	0	0	0	0	67.55	0	0	11.8
2014	7	3	7	8	18	33	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	7	3	7	18	18	33	0	0	0	0	0	0	0	67.51	0	0	11.8
2014	7	3	7	28	18	33	0	0	0	0	0	0	0	67.5	0	0	11.8
2014	7	3	7	38	18	33	0	0	0	0	0	0	0	67.5	0	0	12
2014	7	3	7	48	18	33	0	0	0	0	0	0	0	67.5	0	0	12.2
2014	7	3	7	58	18	33	0	0	0	0	0	0	0	67.5	0	0	12.2
2014	7	3	8	8	18	32	0	0	0	0	0	0	0	67.5	0	0	12.4
2014	7	3	8	18	18	33	0	0	0	0	0	0	0	67.51	0	0	12.4
2014	7	3	8	28	18	33	0	0	0	0	0	0	0	67.53	0	0	12.4
2014	7	3	8	38	18	33	0	0	0	0	0	0	0	67.57	0	0	12.4
2014	7	3	8	48	18	33	0	0	0	0	0	0	0	67.59	0	0	12.6
2014	7	3	8	58	18	33	0	0	0	0	0	0	0	67.62	0	0	12.6
2014	7	3	9	8	18	32	0	0	0	0	0	0	0	67.66	0	0	12.6
2014	7	3	9	18	18	32	0	0	0	0	0	0	0	67.69	0	0	12.6
2014	7	3	9	28	18	34	0	0	0	0	0	0	0	67.77	0	0	12.8
2014	7	3	9	38	18	33	0	0	0	0	0	0	0	67.8	0	0	12.8
2014	7	3	9	48	18	33	0	0	0	0	0	0	0	67.86	0	0	13.2
2014	7	3	9	58	18	33	0	0	0	0	0	0	0	67.93	0	0	13.2
2014	7	3	10	8	18	33	0	0	0	0	0	0	0	67.98	0	0	13.2
2014	7	3	10	18	18	32	0	0	0	0	0	0	0	68.05	0	0	13
2014	7	3	10	28	18	32	0	0	0	0	0	0	0	68.13	0	0	13.2
2014	7	3	10	38	18	33	0	0	0	0	0	0	0	68.18	0	0	13.8
2014	7	3	10	48	18	33	0	0	0	0	0	0	0	68.25	0	0	13.8
2014	7	3	10	58	18	33	0	0	0	0	0	0	0	68.34	0	0	13.8
2014	7	3	11	8	18	33	0	0	0	0	0	0	0	68.41	0	0	13.8
2014	7	3	11	18	18	33	0	0	0	0	0	0	0	68.5	0	0	13.6
2014	7	3	11	28	18	33	0	0	0	0	0	0	0	68.58	0	0	13.6
2014	7	3	11	38	18	33	0	0	0	0	0	0	0	68.67	0	0	13.6
2014	7	3	11	48	18	33	0	0	0	0	0	0	0	68.74	0	0	13.6
2014	7	3	11	58	18	32	0	0	0	0	0	0	0	68.85	0	0	13.8
2014	7	3	12	8	18	32	0	0	0	0	0	0	0	68.92	0	0	13.6
2014	7	3	12	18	18	32	0	0	0	0	0	0	0	69.01	0	0	13.6
2014	7	3	12	28	18	33	0	0	0	0	0	0	0	69.1	0	0	13.8
2014	7	3	12	38	18	32	0	0	0	0	0	0	0	69.19	0	0	13.6
2014	7	3	12	48	18	32	0	0	0	0	0	0	0	69.28	0	0	13.6
2014	7	3	12	58	18	32	0	0	0	0	0	0	0	69.35	0	0	13.6
2014	7	3	13	8	18	32	0	0	0	0	0	0	0	69.44	0	0	13.6
2014	7	3	13	18	18	33	0	0	0	0	0	0	0	69.53	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	13	28	18	32	0	0	0	0	0	0	0	69.6	0	0	13.8
2014	7	3	13	38	18	32	0	0	0	0	0	0	0	69.69	0	0	13.8
2014	7	3	13	48	18	33	0	0	0	0	0	0	0	69.76	0	0	13.8
2014	7	3	13	58	18	33	0	0	0	0	0	0	0	69.85	0	0	14
2014	7	3	14	8	18	32	0	0	0	0	0	0	0	69.93	0	0	13.6
2014	7	3	14	18	18	33	0	0	0	0	0	0	0	70	0	0	13.6
2014	7	3	14	28	18	32	0	0	0	0	0	0	0	70.07	0	0	13.6
2014	7	3	14	38	18	32	0	0	0	0	0	0	0	70.12	0	0	13.4
2014	7	3	14	48	18	33	0	0	0	0	0	0	0	70.21	0	0	13.6
2014	7	3	14	58	18	33	0	0	0	0	0	0	0	70.27	0	0	13.6
2014	7	3	15	8	18	32	0	0	0	0	0	0	0	70.32	0	0	13.4
2014	7	3	15	18	18	32	0	0	0	0	0	0	0	70.39	0	0	13.4
2014	7	3	15	28	18	32	0	0	0	0	0	0	0	70.41	0	0	13.4
2014	7	3	15	38	18	34	0	0	0	0	0	0	0	70.45	0	0	13.4
2014	7	3	15	48	18	32	0	0	0	0	0	0	0	70.5	0	0	13.4
2014	7	3	15	58	18	32	0	0	0	0	0	0	0	70.54	0	0	13.4
2014	7	3	16	8	18	32	0	0	0	0	0	0	0	70.57	0	0	13.6
2014	7	3	16	18	18	32	0	0	0	0	0	0	0	70.59	0	0	13.4
2014	7	3	16	28	18	33	0	0	0	0	0	0	0	70.61	0	0	13.4
2014	7	3	16	38	18	32	0	0	0	0	0	0	0	70.63	0	0	13.4
2014	7	3	16	48	18	32	0	0	0	0	0	0	0	70.63	0	0	13.2
2014	7	3	16	58	18	32	0	0	0	0	0	0	0	70.63	0	0	13.2
2014	7	3	17	8	18	32	0	0	0	0	0	0	0	70.65	0	0	12.8
2014	7	3	17	18	18	32	0	0	0	0	0	0	0	70.63	0	0	12.6
2014	7	3	17	28	18	33	0	0	0	0	0	0	0	70.63	0	0	12.4
2014	7	3	17	38	18	33	0	0	0	0	0	0	0	70.65	0	0	12.2
2014	7	3	17	48	18	32	0	0	0	0	0	0	0	70.63	0	0	12
2014	7	3	17	58	18	32	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	3	18	8	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	3	18	18	18	33	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	3	18	28	18	32	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	3	18	38	18	32	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	3	18	48	18	32	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	3	18	58	18	32	0	0	0	0	0	0	0	70.61	0	0	11.4
2014	7	3	19	8	18	33	0	0	0	0	0	0	0	70.61	0	0	11.2
2014	7	3	19	18	18	33	0	0	0	0	0	0	0	70.59	0	0	11.2
2014	7	3	19	28	18	33	0	0	0	0	0	0	0	70.59	0	0	11.2
2014	7	3	19	38	18	32	0	0	0	0	0	0	0	70.59	0	0	11.2
2014	7	3	19	48	18	33	0	0	0	0	0	0	0	70.59	0	0	11
2014	7	3	19	58	18	32	0	0	0	0	0	0	0	70.57	0	0	11
2014	7	3	20	8	18	33	0	0	0	0	0	0	0	70.57	0	0	11
2014	7	3	20	18	18	32	0	0	0	0	0	0	0	70.56	0	0	11
2014	7	3	20	28	18	32	0	0	0	0	0	0	0	70.54	0	0	10.8
2014	7	3	20	38	18	33	0	0	0	0	0	0	0	70.52	0	0	10.6
2014	7	3	20	48	18	32	0	0	0	0	0	0	0	70.5	0	0	10.6
2014	7	3	20	58	18	32	0	0	0	0	0	0	0	70.5	0	0	10.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	3	21	8	18	33	0	0	0	0	0	0	0	70.48	0	0	10.6
2014	7	3	21	18	18	32	0	0	0	0	0	0	0	70.47	0	0	11
2014	7	3	21	28	18	33	0	0	0	0	0	0	0	70.45	0	0	11
2014	7	3	21	38	18	32	0	0	0	0	0	0	0	70.41	0	0	11
2014	7	3	21	48	18	33	0	0	0	0	0	0	0	70.38	0	0	11
2014	7	3	21	58	18	32	0	0	0	0	0	0	0	70.34	0	0	11
2014	7	3	22	8	18	32	0	0	0	0	0	0	0	70.3	0	0	10.8
2014	7	3	22	18	18	33	0	0	0	0	0	0	0	70.25	0	0	11
2014	7	3	22	28	18	33	0	0	0	0	0	0	0	70.21	0	0	11
2014	7	3	22	38	18	33	0	0	0	0	0	0	0	70.16	0	0	11
2014	7	3	22	48	18	32	0	0	0	0	0	0	0	70.12	0	0	10.8
2014	7	3	22	58	18	33	0	0	0	0	0	0	0	70.07	0	0	10.8
2014	7	3	23	8	18	32	0	0	0	0	0	0	0	70.03	0	0	10.8
2014	7	3	23	18	18	33	0	0	0	0	0	0	0	69.98	0	0	10.8
2014	7	3	23	28	18	33	0	0	0	0	0	0	0	69.94	0	0	10.8
2014	7	3	23	38	18	32	0	0	0	0	0	0	0	69.89	0	0	10.8
2014	7	3	23	48	18	32	0	0	0	0	0	0	0	69.84	0	0	10.8
2014	7	3	23	58	18	32	0	0	0	0	0	0	0	69.8	0	0	10.8
2014	7	4	0	8	18	32	0	0	0	0	0	0	0	69.76	0	0	10.8
2014	7	4	0	18	18	32	0	0	0	0	0	0	0	69.73	0	0	10.8
2014	7	4	0	28	18	33	0	0	0	0	0	0	0	69.67	0	0	10.8
2014	7	4	0	38	18	32	0	0	0	0	0	0	0	69.64	0	0	10.8
2014	7	4	0	48	18	32	0	0	0	0	0	0	0	69.6	0	0	10.8
2014	7	4	0	58	18	33	0	0	0	0	0	0	0	69.57	0	0	10.6
2014	7	4	1	8	18	32	0	0	0	0	0	0	0	69.51	0	0	10.6
2014	7	4	1	18	18	32	0	0	0	0	0	0	0	69.48	0	0	11.4
2014	7	4	1	28	18	33	0	0	0	0	0	0	0	69.42	0	0	11
2014	7	4	1	38	18	32	0	0	0	0	0	0	0	69.39	0	0	11
2014	7	4	1	48	18	33	0	0	0	0	0	0	0	69.33	0	0	11
2014	7	4	1	58	18	32	0	0	0	0	0	0	0	69.28	0	0	11
2014	7	4	2	8	18	32	0	0	0	0	0	0	0	69.22	0	0	11
2014	7	4	2	18	18	33	0	0	0	0	0	0	0	69.17	0	0	10.8
2014	7	4	2	28	18	32	0	0	0	0	0	0	0	69.1	0	0	10.8
2014	7	4	2	38	18	32	0	0	0	0	0	0	0	69.04	0	0	10.8
2014	7	4	2	48	18	32	0	0	0	0	0	0	0	68.99	0	0	10.8
2014	7	4	2	58	18	32	0	0	0	0	0	0	0	68.94	0	0	10.8
2014	7	4	3	8	18	32	0	0	0	0	0	0	0	68.88	0	0	10.8
2014	7	4	3	18	18	32	0	0	0	0	0	0	0	68.81	0	0	11.6
2014	7	4	3	28	18	32	0	0	0	0	0	0	0	68.76	0	0	11.6
2014	7	4	3	38	18	32	0	0	0	0	0	0	0	68.68	0	0	11.6
2014	7	4	3	48	18	32	0	0	0	0	0	0	0	68.63	0	0	11.6
2014	7	4	3	58	18	33	0	0	0	0	0	0	0	68.56	0	0	11.6
2014	7	4	4	8	18	33	0	0	0	0	0	0	0	68.49	0	0	11.6
2014	7	4	4	18	18	33	0	0	0	0	0	0	0	68.43	0	0	11.4
2014	7	4	4	28	18	33	0	0	0	0	0	0	0	68.36	0	0	11.4
2014	7	4	4	38	18	33	0	0	0	0	0	0	0	68.29	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	4	48	18	33	0	0	0	0	0	0	0	68.23	0	0	11.4
2014	7	4	4	58	18	32	0	0	0	0	0	0	0	68.18	0	0	11.4
2014	7	4	5	8	18	33	0	0	0	0	0	0	0	68.09	0	0	11.4
2014	7	4	5	18	18	33	0	0	0	0	0	0	0	68.05	0	0	11.6
2014	7	4	5	28	18	33	0	0	0	0	0	0	0	67.98	0	0	11.6
2014	7	4	5	38	18	32	0	0	0	0	0	0	0	67.93	0	0	11.6
2014	7	4	5	48	18	33	0	0	0	0	0	0	0	67.86	0	0	11.6
2014	7	4	5	58	18	32	0	0	0	0	0	0	0	67.8	0	0	11.6
2014	7	4	6	8	18	32	0	0	0	0	0	0	0	67.75	0	0	11.6
2014	7	4	6	18	18	34	0	0	0	0	0	0	0	67.69	0	0	11.6
2014	7	4	6	28	18	33	0	0	0	0	0	0	0	67.62	0	0	11.6
2014	7	4	6	38	18	33	0	0	0	0	0	0	0	67.57	0	0	11.6
2014	7	4	6	48	18	33	0	0	0	0	0	0	0	67.51	0	0	11.6
2014	7	4	6	58	18	33	0	0	0	0	0	0	0	67.46	0	0	11.8
2014	7	4	7	8	18	33	0	0	0	0	0	0	0	67.42	0	0	11.8
2014	7	4	7	18	18	33	0	0	0	0	0	0	0	67.42	0	0	12
2014	7	4	7	28	18	33	0	0	0	0	0	0	0	67.42	0	0	12
2014	7	4	7	38	18	32	0	0	0	0	0	0	0	67.41	0	0	12.2
2014	7	4	7	48	18	33	0	0	0	0	0	0	0	67.41	0	0	12.4
2014	7	4	7	58	18	33	0	0	0	0	0	0	0	67.41	0	0	12.4
2014	7	4	8	8	18	33	0	0	0	0	0	0	0	67.41	0	0	12.6
2014	7	4	8	18	18	33	0	0	0	0	0	0	0	67.42	0	0	12.6
2014	7	4	8	28	18	33	0	0	0	0	0	0	0	67.42	0	0	12.8
2014	7	4	8	38	18	33	0	0	0	0	0	0	0	67.46	0	0	13
2014	7	4	8	48	18	33	0	0	0	0	0	0	0	67.48	0	0	13
2014	7	4	8	58	18	33	0	0	0	0	0	0	0	67.5	0	0	13
2014	7	4	9	8	18	33	0	0	0	0	0	0	0	67.53	0	0	13.2
2014	7	4	9	18	18	33	0	0	0	0	0	0	0	67.57	0	0	13.2
2014	7	4	9	28	18	33	0	0	0	0	0	0	0	67.62	0	0	13.4
2014	7	4	9	38	18	32	0	0	0	0	0	0	0	67.68	0	0	13.4
2014	7	4	9	48	18	33	0	0	0	0	0	0	0	67.73	0	0	13.4
2014	7	4	9	58	18	33	0	0	0	0	0	0	0	67.8	0	0	13.4
2014	7	4	10	8	18	33	0	0	0	0	0	0	0	67.87	0	0	13.4
2014	7	4	10	18	18	33	0	0	0	0	0	0	0	67.93	0	0	13
2014	7	4	10	28	18	32	0	0	0	0	0	0	0	68.02	0	0	13
2014	7	4	10	38	18	33	0	0	0	0	0	0	0	68.09	0	0	13.2
2014	7	4	10	48	18	33	0	0	0	0	0	0	0	68.14	0	0	13.2
2014	7	4	10	58	18	33	0	0	0	0	0	0	0	68.23	0	0	13.2
2014	7	4	11	8	18	33	0	0	0	0	0	0	0	68.31	0	0	13.2
2014	7	4	11	18	18	33	0	0	0	0	0	0	0	68.38	0	0	13
2014	7	4	11	28	18	33	0	0	0	0	0	0	0	68.45	0	0	13
2014	7	4	11	38	18	33	0	0	0	0	0	0	0	68.54	0	0	13
2014	7	4	11	48	18	32	0	0	0	0	0	0	0	68.61	0	0	13
2014	7	4	11	58	18	33	0	0	0	0	0	0	0	68.7	0	0	13
2014	7	4	12	8	18	33	0	0	0	0	0	0	0	68.79	0	0	13
2014	7	4	12	18	18	33	0	0	0	0	0	0	0	68.86	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	12	28	18	32	0	0	0	0	0	0	0	68.95	0	0	13.4
2014	7	4	12	38	18	33	0	0	0	0	0	0	0	69.03	0	0	13.4
2014	7	4	12	48	18	33	0	0	0	0	0	0	0	69.12	0	0	13.4
2014	7	4	12	58	18	32	0	0	0	0	0	0	0	69.19	0	0	13.4
2014	7	4	13	8	18	33	0	0	0	0	0	0	0	69.28	0	0	13.4
2014	7	4	13	18	18	32	0	0	0	0	0	0	0	69.35	0	0	13.4
2014	7	4	13	28	18	33	0	0	0	0	0	0	0	69.44	0	0	13.2
2014	7	4	13	38	18	33	0	0	0	0	0	0	0	69.51	0	0	13.2
2014	7	4	13	48	18	33	0	0	0	0	0	0	0	69.58	0	0	13.4
2014	7	4	13	58	18	32	0	0	0	0	0	0	0	69.66	0	0	13
2014	7	4	14	8	18	33	0	0	0	0	0	0	0	69.73	0	0	13.4
2014	7	4	14	18	18	32	0	0	0	0	0	0	0	69.8	0	0	13.4
2014	7	4	14	28	18	32	0	0	0	0	0	0	0	69.87	0	0	13.4
2014	7	4	14	38	18	32	0	0	0	0	0	0	0	69.94	0	0	13.4
2014	7	4	14	48	18	33	0	0	0	0	0	0	0	70	0	0	13.4
2014	7	4	14	58	18	32	0	0	0	0	0	0	0	70.07	0	0	13
2014	7	4	15	8	18	32	0	0	0	0	0	0	0	70.11	0	0	13
2014	7	4	15	18	18	33	0	0	0	0	0	0	0	70.16	0	0	13
2014	7	4	15	28	18	33	0	0	0	0	0	0	0	70.21	0	0	13
2014	7	4	15	38	18	32	0	0	0	0	0	0	0	70.25	0	0	13
2014	7	4	15	48	18	33	0	0	0	0	0	0	0	70.3	0	0	13
2014	7	4	15	58	18	32	0	0	0	0	0	0	0	70.3	0	0	13
2014	7	4	16	8	18	33	0	0	0	0	0	0	0	70.34	0	0	13
2014	7	4	16	18	18	32	0	0	0	0	0	0	0	70.38	0	0	13
2014	7	4	16	28	18	32	0	0	0	0	0	0	0	70.39	0	0	13
2014	7	4	16	38	18	33	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	4	16	48	18	32	0	0	0	0	0	0	0	70.41	0	0	12.8
2014	7	4	16	58	18	32	0	0	0	0	0	0	0	70.43	0	0	12.8
2014	7	4	17	8	18	32	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	4	17	18	18	32	0	0	0	0	0	0	0	70.43	0	0	12.4
2014	7	4	17	28	18	32	0	0	0	0	0	0	0	70.43	0	0	12.4
2014	7	4	17	38	18	32	0	0	0	0	0	0	0	70.43	0	0	12.2
2014	7	4	17	48	18	32	0	0	0	0	0	0	0	70.41	0	0	12.2
2014	7	4	17	58	18	32	0	0	0	0	0	0	0	70.41	0	0	12.2
2014	7	4	18	8	18	32	0	0	0	0	0	0	0	70.43	0	0	12
2014	7	4	18	18	18	33	0	0	0	0	0	0	0	70.43	0	0	12
2014	7	4	18	28	18	33	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	4	18	38	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	4	18	48	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	4	18	58	18	33	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	4	19	8	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	4	19	18	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	4	19	28	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	4	19	38	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	4	19	48	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	4	19	58	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	4	20	8	18	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	4	20	18	18	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	4	20	28	18	33	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	4	20	38	18	33	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	4	20	48	18	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	4	20	58	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	4	21	8	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	4	21	18	18	32	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	4	21	28	18	32	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	4	21	38	18	33	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	4	21	48	18	32	0	0	0	0	0	0	0	70.29	0	0	11.8
2014	7	4	21	58	18	33	0	0	0	0	0	0	0	70.27	0	0	11.8
2014	7	4	22	8	18	32	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	4	22	18	18	32	0	0	0	0	0	0	0	70.21	0	0	11.8
2014	7	4	22	28	18	32	0	0	0	0	0	0	0	70.18	0	0	11.8
2014	7	4	22	38	18	32	0	0	0	0	0	0	0	70.14	0	0	11.8
2014	7	4	22	48	18	33	0	0	0	0	0	0	0	70.11	0	0	11.8
2014	7	4	22	58	18	33	0	0	0	0	0	0	0	70.07	0	0	11.8
2014	7	4	23	8	18	32	0	0	0	0	0	0	0	70.02	0	0	11.8
2014	7	4	23	18	18	32	0	0	0	0	0	0	0	70	0	0	11.8
2014	7	4	23	28	18	33	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	4	23	38	18	32	0	0	0	0	0	0	0	69.91	0	0	11.8
2014	7	4	23	48	18	33	0	0	0	0	0	0	0	69.87	0	0	11.8
2014	7	4	23	58	18	31	0	0	0	0	0	0	0	69.84	0	0	11.8
2014	7	5	0	8	18	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2014	7	5	0	18	18	32	0	0	0	0	0	0	0	69.76	0	0	11.8
2014	7	5	0	28	18	32	0	0	0	0	0	0	0	69.73	0	0	11.8
2014	7	5	0	38	18	32	0	0	0	0	0	0	0	69.69	0	0	11.8
2014	7	5	0	48	18	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2014	7	5	0	58	18	32	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	7	5	1	8	18	33	0	0	0	0	0	0	0	69.57	0	0	11.8
2014	7	5	1	18	18	32	0	0	0	0	0	0	0	69.51	0	0	11.8
2014	7	5	1	28	18	32	0	0	0	0	0	0	0	69.48	0	0	11.8
2014	7	5	1	38	18	32	0	0	0	0	0	0	0	69.42	0	0	11.8
2014	7	5	1	48	18	33	0	0	0	0	0	0	0	69.39	0	0	11.6
2014	7	5	1	58	18	32	0	0	0	0	0	0	0	69.33	0	0	11.6
2014	7	5	2	8	18	33	0	0	0	0	0	0	0	69.3	0	0	11.6
2014	7	5	2	18	18	32	0	0	0	0	0	0	0	69.24	0	0	11.6
2014	7	5	2	28	18	33	0	0	0	0	0	0	0	69.21	0	0	11.6
2014	7	5	2	38	18	33	0	0	0	0	0	0	0	69.17	0	0	11.6
2014	7	5	2	48	18	32	0	0	0	0	0	0	0	69.12	0	0	11.6
2014	7	5	2	58	18	33	0	0	0	0	0	0	0	69.06	0	0	11.6
2014	7	5	3	8	18	32	0	0	0	0	0	0	0	69.03	0	0	11.6
2014	7	5	3	18	18	32	0	0	0	0	0	0	0	68.95	0	0	11.6
2014	7	5	3	28	18	33	0	0	0	0	0	0	0	68.9	0	0	11.6
2014	7	5	3	38	18	32	0	0	0	0	0	0	0	68.86	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	3	48	18	32	0	0	0	0	0	0	0	68.81	0	0	11.6
2014	7	5	3	58	18	32	0	0	0	0	0	0	0	68.76	0	0	11.6
2014	7	5	4	8	18	33	0	0	0	0	0	0	0	68.7	0	0	11.6
2014	7	5	4	18	18	32	0	0	0	0	0	0	0	68.67	0	0	11.6
2014	7	5	4	28	18	33	0	0	0	0	0	0	0	68.61	0	0	11.6
2014	7	5	4	38	18	33	0	0	0	0	0	0	0	68.56	0	0	11.6
2014	7	5	4	48	18	33	0	0	0	0	0	0	0	68.5	0	0	11.6
2014	7	5	4	58	18	32	0	0	0	0	0	0	0	68.45	0	0	11.6
2014	7	5	5	8	18	33	0	0	0	0	0	0	0	68.4	0	0	11.6
2014	7	5	5	18	18	33	0	0	0	0	0	0	0	68.34	0	0	11.6
2014	7	5	5	28	18	32	0	0	0	0	0	0	0	68.31	0	0	11.6
2014	7	5	5	38	18	33	0	0	0	0	0	0	0	68.25	0	0	11.6
2014	7	5	5	48	18	33	0	0	0	0	0	0	0	68.22	0	0	11.6
2014	7	5	5	58	18	32	0	0	0	0	0	0	0	68.16	0	0	11.6
2014	7	5	6	8	18	33	0	0	0	0	0	0	0	68.13	0	0	11.6
2014	7	5	6	18	18	33	0	0	0	0	0	0	0	68.07	0	0	11.6
2014	7	5	6	28	18	32	0	0	0	0	0	0	0	68.04	0	0	11.6
2014	7	5	6	38	18	33	0	0	0	0	0	0	0	68	0	0	11.6
2014	7	5	6	48	18	32	0	0	0	0	0	0	0	67.96	0	0	11.8
2014	7	5	6	58	18	33	0	0	0	0	0	0	0	67.93	0	0	11.8
2014	7	5	7	8	18	33	0	0	0	0	0	0	0	67.89	0	0	11.8
2014	7	5	7	18	18	33	0	0	0	0	0	0	0	67.89	0	0	12
2014	7	5	7	28	18	33	0	0	0	0	0	0	0	67.87	0	0	12
2014	7	5	7	38	18	33	0	0	0	0	0	0	0	67.87	0	0	12.2
2014	7	5	7	48	18	32	0	0	0	0	0	0	0	67.86	0	0	12.2
2014	7	5	7	58	18	33	0	0	0	0	0	0	0	67.87	0	0	12.4
2014	7	5	8	8	18	32	0	0	0	0	0	0	0	67.87	0	0	12.4
2014	7	5	8	18	18	33	0	0	0	0	0	0	0	67.89	0	0	12.6
2014	7	5	8	28	18	33	0	0	0	0	0	0	0	67.91	0	0	12.6
2014	7	5	8	38	18	33	0	0	0	0	0	0	0	67.95	0	0	12.6
2014	7	5	8	48	18	33	0	0	0	0	0	0	0	67.98	0	0	12.6
2014	7	5	8	58	18	33	0	0	0	0	0	0	0	68.02	0	0	12.8
2014	7	5	9	8	18	33	0	0	0	0	0	0	0	68.05	0	0	12.8
2014	7	5	9	18	18	32	0	0	0	0	0	0	0	68.11	0	0	12.8
2014	7	5	9	28	18	33	0	0	0	0	0	0	0	68.14	0	0	13
2014	7	5	9	38	18	33	0	0	0	0	0	0	0	68.2	0	0	13
2014	7	5	9	48	18	32	0	0	0	0	0	0	0	68.25	0	0	13.4
2014	7	5	9	58	18	32	0	0	0	0	0	0	0	68.31	0	0	13.4
2014	7	5	10	8	18	32	0	0	0	0	0	0	0	68.38	0	0	13.6
2014	7	5	10	18	18	32	0	0	0	0	0	0	0	68.45	0	0	13.4
2014	7	5	10	28	18	33	0	0	0	0	0	0	0	68.52	0	0	13.4
2014	7	5	10	38	18	32	0	0	0	0	0	0	0	68.58	0	0	13.2
2014	7	5	10	48	18	32	0	0	0	0	0	0	0	68.67	0	0	13.2
2014	7	5	10	58	18	33	0	0	0	0	0	0	0	68.76	0	0	13.4
2014	7	5	11	8	18	33	0	0	0	0	0	0	0	68.83	0	0	13.4
2014	7	5	11	18	18	32	0	0	0	0	0	0	0	68.9	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	11	28	18	33	0	0	0	0	0	0	0	68.99	0	0	13
2014	7	5	11	38	18	32	0	0	0	0	0	0	0	69.08	0	0	13.2
2014	7	5	11	48	18	33	0	0	0	0	0	0	0	69.17	0	0	13.2
2014	7	5	11	58	18	33	0	0	0	0	0	0	0	69.24	0	0	13
2014	7	5	12	8	18	33	0	0	0	0	0	0	0	69.31	0	0	13
2014	7	5	12	18	18	33	0	0	0	0	0	0	0	69.4	0	0	13
2014	7	5	12	28	18	32	0	0	0	0	0	0	0	69.48	0	0	13.2
2014	7	5	12	38	18	33	0	0	0	0	0	0	0	69.57	0	0	13.2
2014	7	5	12	48	18	32	0	0	0	0	0	0	0	69.67	0	0	13.2
2014	7	5	12	58	18	32	0	0	0	0	0	0	0	69.76	0	0	13.2
2014	7	5	13	8	18	32	0	0	0	0	0	0	0	69.85	0	0	13.4
2014	7	5	13	18	18	32	0	0	0	0	0	0	0	69.94	0	0	13.2
2014	7	5	13	28	18	33	0	0	0	0	0	0	0	70.03	0	0	13
2014	7	5	13	38	18	32	0	0	0	0	0	0	0	70.14	0	0	13
2014	7	5	13	48	18	33	0	0	0	0	0	0	0	70.21	0	0	13
2014	7	5	13	58	18	32	0	0	0	0	0	0	0	70.3	0	0	13.2
2014	7	5	14	8	18	32	0	0	0	0	0	0	0	70.39	0	0	13.2
2014	7	5	14	18	18	32	0	0	0	0	0	0	0	70.47	0	0	13.2
2014	7	5	14	28	18	32	0	0	0	0	0	0	0	70.54	0	0	13.2
2014	7	5	14	38	18	33	0	0	0	0	0	0	0	70.63	0	0	13.2
2014	7	5	14	48	18	32	0	0	0	0	0	0	0	70.7	0	0	13.2
2014	7	5	14	58	18	32	0	0	0	0	0	0	0	70.75	0	0	13
2014	7	5	15	8	18	32	0	0	0	0	0	0	0	70.81	0	0	13
2014	7	5	15	18	18	32	0	0	0	0	0	0	0	70.86	0	0	13
2014	7	5	15	28	18	32	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	5	15	38	18	32	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	5	15	48	18	32	0	0	0	0	0	0	0	71.01	0	0	13
2014	7	5	15	58	18	32	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	5	16	8	18	32	0	0	0	0	0	0	0	71.04	0	0	12.8
2014	7	5	16	18	18	31	0	0	0	0	0	0	0	71.01	0	0	12.8
2014	7	5	16	28	18	32	0	0	0	0	0	0	0	71.13	0	0	13
2014	7	5	16	38	18	33	0	0	0	0	0	0	0	71.08	0	0	12.6
2014	7	5	16	48	18	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	5	16	58	18	32	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	5	17	8	18	32	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	5	17	18	18	32	0	0	0	0	0	0	0	71.19	0	0	12.8
2014	7	5	17	28	18	32	0	0	0	0	0	0	0	71.2	0	0	12.8
2014	7	5	17	38	18	32	0	0	0	0	0	0	0	71.22	0	0	12.8
2014	7	5	17	48	18	32	0	0	0	0	0	0	0	71.22	0	0	12.6
2014	7	5	17	58	18	32	0	0	0	0	0	0	0	71.22	0	0	12.6
2014	7	5	18	8	18	33	0	0	0	0	0	0	0	71.22	0	0	12.4
2014	7	5	18	18	18	33	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	7	5	18	28	18	32	0	0	0	0	0	0	0	71.22	0	0	12.2
2014	7	5	18	38	18	32	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	5	18	48	18	32	0	0	0	0	0	0	0	71.2	0	0	12
2014	7	5	18	58	18	32	0	0	0	0	0	0	0	71.19	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	5	19	8	18	32	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	5	19	18	18	32	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	5	19	28	18	32	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	5	19	38	18	32	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	5	19	48	18	33	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	5	19	58	18	33	0	0	0	0	0	0	0	71.13	0	0	11.8
2014	7	5	20	8	18	33	0	0	0	0	0	0	0	71.13	0	0	11.8
2014	7	5	20	18	18	32	0	0	0	0	0	0	0	71.11	0	0	11.8
2014	7	5	20	28	18	31	0	0	0	0	0	0	0	71.11	0	0	11.8
2014	7	5	20	38	18	33	0	0	0	0	0	0	0	71.1	0	0	11.8
2014	7	5	20	48	18	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	5	20	58	18	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	5	21	8	18	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	5	21	18	18	33	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	5	21	28	18	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	5	21	38	18	33	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	5	21	48	18	32	0	0	0	0	0	0	0	71.01	0	0	11.8
2014	7	5	21	58	18	32	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	5	22	8	18	33	0	0	0	0	0	0	0	70.97	0	0	11.8
2014	7	5	22	18	18	33	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	5	22	28	18	32	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	5	22	38	18	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	5	22	48	18	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	5	22	58	18	32	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	5	23	8	18	32	0	0	0	0	0	0	0	70.84	0	0	11.8
2014	7	5	23	18	18	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	5	23	28	18	32	0	0	0	0	0	0	0	70.77	0	0	11.8
2014	7	5	23	38	18	32	0	0	0	0	0	0	0	70.75	0	0	11.8
2014	7	5	23	48	18	32	0	0	0	0	0	0	0	70.72	0	0	11.8
2014	7	5	23	58	18	32	0	0	0	0	0	0	0	70.68	0	0	11.8
2014	7	6	0	8	18	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	6	0	18	18	33	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	6	0	28	18	32	0	0	0	0	0	0	0	70.59	0	0	11.8
2014	7	6	0	38	18	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2014	7	6	0	48	18	32	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	6	0	58	18	33	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	6	1	8	18	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	6	1	18	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	6	1	28	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	6	1	38	18	33	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	6	1	48	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	6	1	58	18	32	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	6	2	8	18	33	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	6	2	18	18	32	0	0	0	0	0	0	0	70.27	0	0	11.8
2014	7	6	2	28	18	32	0	0	0	0	0	0	0	70.23	0	0	11.8
2014	7	6	2	38	18	33	0	0	0	0	0	0	0	70.2	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	2	48	18	32	0	0	0	0	0	0	0	70.16	0	0	11.8
2014	7	6	2	58	18	32	0	0	0	0	0	0	0	70.14	0	0	11.8
2014	7	6	3	8	18	32	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	6	3	18	18	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	6	3	28	18	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	6	3	38	18	33	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	6	3	48	18	33	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	6	3	58	18	32	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	6	4	8	18	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	6	4	18	18	33	0	0	0	0	0	0	0	69.91	0	0	11.6
2014	7	6	4	28	18	33	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	6	4	38	18	32	0	0	0	0	0	0	0	69.84	0	0	11.6
2014	7	6	4	48	18	33	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	6	4	58	18	32	0	0	0	0	0	0	0	69.78	0	0	11.6
2014	7	6	5	8	18	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	6	5	18	18	32	0	0	0	0	0	0	0	69.73	0	0	11.6
2014	7	6	5	28	18	33	0	0	0	0	0	0	0	69.71	0	0	11.6
2014	7	6	5	38	18	31	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	6	5	48	18	32	0	0	0	0	0	0	0	69.67	0	0	11.6
2014	7	6	5	58	18	32	0	0	0	0	0	0	0	69.64	0	0	11.6
2014	7	6	6	8	18	33	0	0	0	0	0	0	0	69.62	0	0	11.6
2014	7	6	6	18	18	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	6	6	28	18	33	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	6	6	38	18	32	0	0	0	0	0	0	0	69.58	0	0	11.6
2014	7	6	6	48	18	33	0	0	0	0	0	0	0	69.57	0	0	11.6
2014	7	6	6	58	18	32	0	0	0	0	0	0	0	69.57	0	0	11.6
2014	7	6	7	8	18	33	0	0	0	0	0	0	0	69.55	0	0	11.6
2014	7	6	7	18	18	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	7	28	18	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	7	38	18	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	7	48	18	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	7	58	18	33	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	8	8	18	33	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	6	8	18	18	33	0	0	0	0	0	0	0	69.55	0	0	11.8
2014	7	6	8	28	18	32	0	0	0	0	0	0	0	69.57	0	0	11.8
2014	7	6	8	38	18	33	0	0	0	0	0	0	0	69.57	0	0	11.8
2014	7	6	8	48	18	33	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	7	6	8	58	18	32	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	7	6	9	8	18	33	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	7	6	9	18	18	32	0	0	0	0	0	0	0	69.6	0	0	11.8
2014	7	6	9	28	18	32	0	0	0	0	0	0	0	69.62	0	0	11.8
2014	7	6	9	38	18	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2014	7	6	9	48	18	33	0	0	0	0	0	0	0	69.66	0	0	11.8
2014	7	6	9	58	18	32	0	0	0	0	0	0	0	69.69	0	0	12
2014	7	6	10	8	18	32	0	0	0	0	0	0	0	69.73	0	0	12
2014	7	6	10	18	18	32	0	0	0	0	0	0	0	69.75	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	10	28	18	32	0	0	0	0	0	0	0	69.76	0	0	12
2014	7	6	10	38	18	33	0	0	0	0	0	0	0	69.78	0	0	12
2014	7	6	10	48	18	32	0	0	0	0	0	0	0	69.8	0	0	12
2014	7	6	10	58	18	33	0	0	0	0	0	0	0	69.82	0	0	12
2014	7	6	11	8	18	33	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	6	11	18	18	33	0	0	0	0	0	0	0	69.85	0	0	12
2014	7	6	11	28	18	33	0	0	0	0	0	0	0	69.89	0	0	12
2014	7	6	11	38	18	32	0	0	0	0	0	0	0	69.91	0	0	12
2014	7	6	11	48	18	32	0	0	0	0	0	0	0	69.94	0	0	12
2014	7	6	11	58	18	32	0	0	0	0	0	0	0	69.98	0	0	12.2
2014	7	6	12	8	18	32	0	0	0	0	0	0	0	70.05	0	0	12.4
2014	7	6	12	18	18	33	0	0	0	0	0	0	0	70.3	0	0	13.2
2014	7	6	12	28	18	32	0	0	0	0	0	0	0	70.43	0	0	13
2014	7	6	12	38	18	32	0	0	0	0	0	0	0	70.52	0	0	13.2
2014	7	6	12	48	18	32	0	0	0	0	0	0	0	70.65	0	0	13.2
2014	7	6	12	58	18	32	0	0	0	0	0	0	0	70.74	0	0	13.4
2014	7	6	13	8	18	32	0	0	0	0	0	0	0	70.81	0	0	13.2
2014	7	6	13	18	18	33	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	7	6	13	28	18	33	0	0	0	0	0	0	0	70.95	0	0	13.2
2014	7	6	13	38	18	32	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	7	6	13	48	18	32	0	0	0	0	0	0	0	71.1	0	0	13.2
2014	7	6	13	58	18	32	0	0	0	0	0	0	0	71.17	0	0	13.2
2014	7	6	14	8	18	32	0	0	0	0	0	0	0	71.24	0	0	13.2
2014	7	6	14	18	18	32	0	0	0	0	0	0	0	71.31	0	0	13
2014	7	6	14	28	18	32	0	0	0	0	0	0	0	71.4	0	0	13
2014	7	6	14	38	18	32	0	0	0	0	0	0	0	71.46	0	0	13
2014	7	6	14	48	18	32	0	0	0	0	0	0	0	71.55	0	0	13
2014	7	6	14	58	18	32	0	0	0	0	0	0	0	71.62	0	0	13
2014	7	6	15	8	18	32	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	6	15	18	18	33	0	0	0	0	0	0	0	71.76	0	0	13
2014	7	6	15	28	18	32	0	0	0	0	0	0	0	71.8	0	0	12.8
2014	7	6	15	38	18	33	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	6	15	48	18	32	0	0	0	0	0	0	0	71.92	0	0	13
2014	7	6	15	58	18	32	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	6	16	8	18	32	0	0	0	0	0	0	0	71.89	0	0	12.4
2014	7	6	16	18	18	32	0	0	0	0	0	0	0	71.94	0	0	12.6
2014	7	6	16	28	18	33	0	0	0	0	0	0	0	71.89	0	0	12.2
2014	7	6	16	38	18	32	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	6	16	48	18	32	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	6	16	58	18	32	0	0	0	0	0	0	0	71.89	0	0	12
2014	7	6	17	8	18	31	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	6	17	18	18	33	0	0	0	0	0	0	0	71.94	0	0	12.2
2014	7	6	17	28	18	32	0	0	0	0	0	0	0	71.94	0	0	12
2014	7	6	17	38	18	32	0	0	0	0	0	0	0	71.94	0	0	12
2014	7	6	17	48	18	32	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	6	17	58	18	32	0	0	0	0	0	0	0	71.96	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	6	18	8	18	32	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	6	18	18	18	32	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	6	18	28	18	32	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	6	18	38	18	33	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	6	18	48	18	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	6	18	58	18	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	6	19	8	18	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	6	19	18	18	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	6	19	28	18	33	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	6	19	38	18	32	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	6	19	48	18	32	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	6	19	58	18	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	6	20	8	18	31	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	6	20	18	18	32	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	6	20	28	18	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	6	20	38	18	32	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	6	20	48	18	33	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	6	20	58	18	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	6	21	8	18	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	6	21	18	18	31	0	0	0	0	0	0	0	71.76	0	0	11.8
2014	7	6	21	28	18	32	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	6	21	38	18	32	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	6	21	48	18	32	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	6	21	58	18	32	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	6	22	8	18	32	0	0	0	0	0	0	0	71.64	0	0	11.8
2014	7	6	22	18	18	32	0	0	0	0	0	0	0	71.62	0	0	11.8
2014	7	6	22	28	18	32	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	6	22	38	18	33	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	6	22	48	18	32	0	0	0	0	0	0	0	71.55	0	0	11.8
2014	7	6	22	58	18	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	6	23	8	18	32	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	6	23	18	18	32	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	6	23	28	18	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	6	23	38	18	33	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	6	23	48	18	32	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	6	23	58	18	33	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	7	0	8	18	32	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	7	0	18	18	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	7	0	28	18	33	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	7	0	38	18	32	0	0	0	0	0	0	0	71.31	0	0	11.6
2014	7	7	0	48	18	32	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	7	0	58	18	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	7	1	8	18	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	7	1	18	18	32	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	7	1	28	18	32	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	7	1	38	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	1	48	18	32	0	0	0	0	0	0	0	71.17	0	0	11.6
2014	7	7	1	58	18	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	7	2	8	18	32	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	7	2	18	18	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	7	2	28	18	31	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	7	2	38	18	32	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	7	2	48	18	33	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	7	2	58	18	32	0	0	0	0	0	0	0	70.99	0	0	11.6
2014	7	7	3	8	18	32	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	7	3	18	18	32	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	7	3	28	18	32	0	0	0	0	0	0	0	70.88	0	0	11.6
2014	7	7	3	38	18	32	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	7	3	48	18	32	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	7	3	58	18	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	7	4	8	18	32	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	7	4	18	18	32	0	0	0	0	0	0	0	70.72	0	0	11.6
2014	7	7	4	28	18	33	0	0	0	0	0	0	0	70.68	0	0	11.6
2014	7	7	4	38	18	32	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	7	4	48	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	7	4	58	18	33	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	7	5	8	18	32	0	0	0	0	0	0	0	70.57	0	0	11.6
2014	7	7	5	18	18	32	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	7	5	28	18	33	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	7	5	38	18	32	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	7	5	48	18	32	0	0	0	0	0	0	0	70.45	0	0	11.6
2014	7	7	5	58	18	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	7	6	8	18	32	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	7	6	18	18	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	7	6	28	18	33	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	7	6	38	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	7	6	48	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	7	6	58	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	7	7	8	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	7	7	18	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	7	7	28	18	32	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	7	7	38	18	32	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	7	7	48	18	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	7	7	58	18	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	7	8	8	18	33	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	7	8	18	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	7	8	28	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	7	8	38	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	7	8	48	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	7	8	58	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	7	9	8	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	7	9	18	18	32	0	0	0	0	0	0	0	70.47	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	9	28	18	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	7	9	38	18	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	7	9	48	18	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	7	9	58	18	32	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	7	10	8	18	32	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	7	10	18	18	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2014	7	7	10	28	18	32	0	0	0	0	0	0	0	70.59	0	0	11.8
2014	7	7	10	38	18	33	0	0	0	0	0	0	0	70.63	0	0	12
2014	7	7	10	48	18	32	0	0	0	0	0	0	0	70.65	0	0	12
2014	7	7	10	58	18	32	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	7	11	8	18	33	0	0	0	0	0	0	0	70.7	0	0	12
2014	7	7	11	18	18	32	0	0	0	0	0	0	0	70.72	0	0	12
2014	7	7	11	28	18	32	0	0	0	0	0	0	0	70.75	0	0	12.2
2014	7	7	11	38	18	32	0	0	0	0	0	0	0	70.79	0	0	12.2
2014	7	7	11	48	18	32	0	0	0	0	0	0	0	70.84	0	0	12.4
2014	7	7	11	58	18	32	0	0	0	0	0	0	0	70.9	0	0	12.4
2014	7	7	12	8	18	32	0	0	0	0	0	0	0	70.93	0	0	12.4
2014	7	7	12	18	18	33	0	0	0	0	0	0	0	70.99	0	0	12.4
2014	7	7	12	28	18	33	0	0	0	0	0	0	0	71.06	0	0	12.6
2014	7	7	12	38	18	32	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	7	12	48	18	32	0	0	0	0	0	0	0	71.17	0	0	12.6
2014	7	7	12	58	18	32	0	0	0	0	0	0	0	71.28	0	0	13
2014	7	7	13	8	18	33	0	0	0	0	0	0	0	71.33	0	0	13
2014	7	7	13	18	18	32	0	0	0	0	0	0	0	71.51	0	0	13
2014	7	7	13	28	18	32	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	7	13	38	18	32	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	7	13	48	18	33	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	7	13	58	18	32	0	0	0	0	0	0	0	71.71	0	0	12.8
2014	7	7	14	8	18	32	0	0	0	0	0	0	0	71.67	0	0	12.6
2014	7	7	14	18	18	33	0	0	0	0	0	0	0	71.71	0	0	12.6
2014	7	7	14	28	18	32	0	0	0	0	0	0	0	71.74	0	0	12.8
2014	7	7	14	38	18	32	0	0	0	0	0	0	0	71.82	0	0	12.8
2014	7	7	14	48	18	32	0	0	0	0	0	0	0	71.82	0	0	12.6
2014	7	7	14	58	18	32	0	0	0	0	0	0	0	71.82	0	0	12.4
2014	7	7	15	8	18	33	0	0	0	0	0	0	0	71.82	0	0	12.2
2014	7	7	15	18	18	32	0	0	0	0	0	0	0	71.83	0	0	12.2
2014	7	7	15	28	18	32	0	0	0	0	0	0	0	71.85	0	0	12.2
2014	7	7	15	38	18	32	0	0	0	0	0	0	0	71.89	0	0	12.2
2014	7	7	15	48	18	32	0	0	0	0	0	0	0	71.92	0	0	12.2
2014	7	7	15	58	18	33	0	0	0	0	0	0	0	71.94	0	0	12.2
2014	7	7	16	8	18	32	0	0	0	0	0	0	0	71.98	0	0	12.2
2014	7	7	16	18	18	32	0	0	0	0	0	0	0	72	0	0	12.2
2014	7	7	16	28	18	33	0	0	0	0	0	0	0	72.03	0	0	12.4
2014	7	7	16	38	18	32	0	0	0	0	0	0	0	72.05	0	0	12.2
2014	7	7	16	48	18	33	0	0	0	0	0	0	0	72.05	0	0	12.2
2014	7	7	16	58	18	32	0	0	0	0	0	0	0	72.05	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	7	17	8	18	32	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	7	17	18	18	33	0	0	0	0	0	0	0	72.07	0	0	12.2
2014	7	7	17	28	18	32	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	7	17	38	18	32	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	7	17	48	18	32	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	7	17	58	18	32	0	0	0	0	0	0	0	72.05	0	0	12
2014	7	7	18	8	18	33	0	0	0	0	0	0	0	72.07	0	0	12
2014	7	7	18	18	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	7	18	28	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	7	18	38	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	7	18	48	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	7	18	58	18	32	0	0	0	0	0	0	0	72.09	0	0	12
2014	7	7	19	8	18	32	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	7	19	18	18	32	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	7	19	28	18	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	7	19	38	18	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	7	19	48	18	32	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	7	19	58	18	32	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	7	20	8	18	31	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	7	20	18	18	32	0	0	0	0	0	0	0	72	0	0	11.8
2014	7	7	20	28	18	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	7	20	38	18	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	7	20	48	18	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	7	20	58	18	32	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	7	21	8	18	32	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	7	21	18	18	32	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	7	21	28	18	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	7	21	38	18	33	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	7	21	48	18	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	7	21	58	18	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	7	22	8	18	32	0	0	0	0	0	0	0	71.74	0	0	11.8
2014	7	7	22	18	18	33	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	7	22	28	18	32	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	7	22	38	18	32	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	7	22	48	18	32	0	0	0	0	0	0	0	71.64	0	0	11.8
2014	7	7	22	58	18	32	0	0	0	0	0	0	0	71.62	0	0	11.8
2014	7	7	23	8	18	32	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	7	23	18	18	33	0	0	0	0	0	0	0	71.56	0	0	11.8
2014	7	7	23	28	18	33	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	7	23	38	18	33	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	7	23	48	18	32	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	7	23	58	18	32	0	0	0	0	0	0	0	71.46	0	0	11.8
2014	7	8	0	8	18	32	0	0	0	0	0	0	0	71.42	0	0	11.8
2014	7	8	0	18	18	32	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	8	0	28	18	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	8	0	38	18	33	0	0	0	0	0	0	0	71.31	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	0	48	18	33	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	8	0	58	18	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	8	1	8	18	32	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	8	1	18	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	8	1	28	18	33	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	8	1	38	18	33	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	8	1	48	18	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	8	1	58	18	33	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	8	2	8	18	32	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	8	2	18	18	33	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	8	2	28	18	32	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	8	2	38	18	32	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	8	2	48	18	33	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	8	2	58	18	33	0	0	0	0	0	0	0	70.88	0	0	11.6
2014	7	8	3	8	18	32	0	0	0	0	0	0	0	70.86	0	0	11.6
2014	7	8	3	18	18	33	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	8	3	28	18	33	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	8	3	38	18	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	8	3	48	18	32	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	8	3	58	18	33	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	8	4	8	18	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	8	4	18	18	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	8	4	28	18	33	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	8	4	38	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	8	4	48	18	33	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	8	4	58	18	33	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	8	5	8	18	32	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	8	5	18	18	32	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	8	5	28	18	32	0	0	0	0	0	0	0	70.47	0	0	11.6
2014	7	8	5	38	18	32	0	0	0	0	0	0	0	70.45	0	0	11.6
2014	7	8	5	48	18	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	8	5	58	18	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	8	6	8	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	8	6	18	18	32	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	8	6	28	18	32	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	8	6	38	18	32	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	8	6	48	18	33	0	0	0	0	0	0	0	70.29	0	0	11.8
2014	7	8	6	58	18	33	0	0	0	0	0	0	0	70.27	0	0	11.8
2014	7	8	7	8	18	33	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	8	7	18	18	32	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	8	7	28	18	32	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	8	7	38	18	33	0	0	0	0	0	0	0	70.27	0	0	12
2014	7	8	7	48	18	33	0	0	0	0	0	0	0	70.29	0	0	12.2
2014	7	8	7	58	18	32	0	0	0	0	0	0	0	70.3	0	0	12.4
2014	7	8	8	8	18	32	0	0	0	0	0	0	0	70.32	0	0	12.4
2014	7	8	8	18	18	32	0	0	0	0	0	0	0	70.34	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	8	28	18	32	0	0	0	0	0	0	0	70.36	0	0	12.4
2014	7	8	8	38	18	32	0	0	0	0	0	0	0	70.39	0	0	12.6
2014	7	8	8	48	18	32	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	8	8	58	18	33	0	0	0	0	0	0	0	70.45	0	0	12.6
2014	7	8	9	8	18	32	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	8	9	18	18	32	0	0	0	0	0	0	0	70.54	0	0	13
2014	7	8	9	28	18	32	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	8	9	38	18	33	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	8	9	48	18	33	0	0	0	0	0	0	0	70.66	0	0	13
2014	7	8	9	58	18	32	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	8	10	8	18	32	0	0	0	0	0	0	0	70.79	0	0	13
2014	7	8	10	18	18	32	0	0	0	0	0	0	0	70.86	0	0	13
2014	7	8	10	28	18	32	0	0	0	0	0	0	0	70.92	0	0	12.8
2014	7	8	10	38	18	32	0	0	0	0	0	0	0	70.99	0	0	12.8
2014	7	8	10	48	18	33	0	0	0	0	0	0	0	71.06	0	0	12.8
2014	7	8	10	58	18	33	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	8	11	8	18	32	0	0	0	0	0	0	0	71.22	0	0	12.8
2014	7	8	11	18	18	32	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	8	11	28	18	32	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	8	11	38	18	32	0	0	0	0	0	0	0	71.31	0	0	12.8
2014	7	8	11	48	18	33	0	0	0	0	0	0	0	71.46	0	0	12.8
2014	7	8	11	58	18	33	0	0	0	0	0	0	0	71.46	0	0	12.8
2014	7	8	12	8	18	33	0	0	0	0	0	0	0	71.51	0	0	13
2014	7	8	12	18	18	32	0	0	0	0	0	0	0	71.67	0	0	13
2014	7	8	12	28	18	33	0	0	0	0	0	0	0	71.78	0	0	13
2014	7	8	12	38	18	32	0	0	0	0	0	0	0	71.83	0	0	12.8
2014	7	8	12	48	18	32	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	8	12	58	18	32	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	8	13	8	18	32	0	0	0	0	0	0	0	71.8	0	0	12.6
2014	7	8	13	18	18	32	0	0	0	0	0	0	0	71.78	0	0	12.4
2014	7	8	13	28	18	32	0	0	0	0	0	0	0	71.82	0	0	12.6
2014	7	8	13	38	18	32	0	0	0	0	0	0	0	72	0	0	12.8
2014	7	8	13	48	18	32	0	0	0	0	0	0	0	71.87	0	0	12.6
2014	7	8	13	58	18	32	0	0	0	0	0	0	0	71.87	0	0	12.2
2014	7	8	14	8	18	32	0	0	0	0	0	0	0	71.87	0	0	12.2
2014	7	8	14	18	18	32	0	0	0	0	0	0	0	71.91	0	0	12.6
2014	7	8	14	28	18	32	0	0	0	0	0	0	0	71.92	0	0	12.4
2014	7	8	14	38	18	32	0	0	0	0	0	0	0	71.92	0	0	12.2
2014	7	8	14	48	18	32	0	0	0	0	0	0	0	71.94	0	0	12.4
2014	7	8	14	58	18	32	0	0	0	0	0	0	0	71.94	0	0	12.4
2014	7	8	15	8	18	32	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	8	15	18	18	32	0	0	0	0	0	0	0	72.07	0	0	13.4
2014	7	8	15	28	18	32	0	0	0	0	0	0	0	72.12	0	0	13.4
2014	7	8	15	38	18	32	0	0	0	0	0	0	0	72.16	0	0	13.4
2014	7	8	15	48	18	33	0	0	0	0	0	0	0	72.09	0	0	12.8
2014	7	8	15	58	18	32	0	0	0	0	0	0	0	72.07	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	16	8	18	32	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	8	16	18	18	33	0	0	0	0	0	0	0	72.05	0	0	12.4
2014	7	8	16	28	18	33	0	0	0	0	0	0	0	72.03	0	0	12.4
2014	7	8	16	38	18	32	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	8	16	48	18	33	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	8	16	58	18	33	0	0	0	0	0	0	0	72.03	0	0	12.4
2014	7	8	17	8	18	32	0	0	0	0	0	0	0	72.05	0	0	12.6
2014	7	8	17	18	18	32	0	0	0	0	0	0	0	72.07	0	0	12.4
2014	7	8	17	28	18	32	0	0	0	0	0	0	0	72.1	0	0	12.4
2014	7	8	17	38	18	32	0	0	0	0	0	0	0	72.12	0	0	12.4
2014	7	8	17	48	18	32	0	0	0	0	0	0	0	72.1	0	0	12.4
2014	7	8	17	58	18	32	0	0	0	0	0	0	0	72.1	0	0	12.2
2014	7	8	18	8	18	32	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	8	18	18	18	31	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	8	18	28	18	32	0	0	0	0	0	0	0	72.1	0	0	12
2014	7	8	18	38	18	32	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	8	18	48	18	32	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	8	18	58	18	33	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	8	19	8	18	32	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	8	19	18	18	32	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	8	19	28	18	32	0	0	0	0	0	0	0	72.09	0	0	11.8
2014	7	8	19	38	18	32	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	8	19	48	18	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	8	19	58	18	33	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	8	20	8	18	32	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	8	20	18	18	32	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	8	20	28	18	32	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	8	20	38	18	32	0	0	0	0	0	0	0	72	0	0	11.8
2014	7	8	20	48	18	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	8	20	58	18	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	8	21	8	18	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	8	21	18	18	33	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	8	21	28	18	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	8	21	38	18	33	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	8	21	48	18	32	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	8	21	58	18	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	8	22	8	18	33	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	8	22	18	18	32	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	8	22	28	18	33	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	8	22	38	18	32	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	8	22	48	18	33	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	8	22	58	18	31	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	8	23	8	18	32	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	8	23	18	18	32	0	0	0	0	0	0	0	71.64	0	0	11.6
2014	7	8	23	28	18	33	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	8	23	38	18	33	0	0	0	0	0	0	0	71.58	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	8	23	48	18	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	8	23	58	18	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	9	0	8	18	32	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	9	0	18	18	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	9	0	28	18	33	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	9	0	38	18	32	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	9	0	48	18	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	9	0	58	18	33	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	9	1	8	18	33	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	9	1	18	18	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	9	1	28	18	32	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	9	1	38	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	9	1	48	18	32	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	9	1	58	18	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	9	2	8	18	32	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	9	2	18	18	32	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	9	2	28	18	33	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	9	2	38	18	33	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	9	2	48	18	32	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	9	2	58	18	33	0	0	0	0	0	0	0	70.99	0	0	11.6
2014	7	9	3	8	18	33	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	9	3	18	18	32	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	9	3	28	18	33	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	9	3	38	18	32	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	9	3	48	18	33	0	0	0	0	0	0	0	70.88	0	0	11.6
2014	7	9	3	58	18	32	0	0	0	0	0	0	0	70.86	0	0	11.6
2014	7	9	4	8	18	31	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	9	4	18	18	32	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	9	4	28	18	33	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	9	4	38	18	32	0	0	0	0	0	0	0	70.79	0	0	11.6
2014	7	9	4	48	18	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	9	4	58	18	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	9	5	8	18	33	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	9	5	18	18	33	0	0	0	0	0	0	0	70.68	0	0	11.6
2014	7	9	5	28	18	33	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	9	5	38	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	9	5	48	18	32	0	0	0	0	0	0	0	70.61	0	0	11.6
2014	7	9	5	58	18	32	0	0	0	0	0	0	0	70.57	0	0	11.6
2014	7	9	6	8	18	32	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	9	6	18	18	32	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	9	6	28	18	32	0	0	0	0	0	0	0	70.47	0	0	11.6
2014	7	9	6	38	18	32	0	0	0	0	0	0	0	70.45	0	0	11.6
2014	7	9	6	48	18	32	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	9	6	58	18	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	9	7	8	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	9	7	18	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	7	28	18	32	0	0	0	0	0	0	0	70.36	0	0	12
2014	7	9	7	38	18	32	0	0	0	0	0	0	0	70.34	0	0	12
2014	7	9	7	48	18	33	0	0	0	0	0	0	0	70.34	0	0	12.2
2014	7	9	7	58	18	32	0	0	0	0	0	0	0	70.36	0	0	12.2
2014	7	9	8	8	18	32	0	0	0	0	0	0	0	70.36	0	0	12.4
2014	7	9	8	18	18	32	0	0	0	0	0	0	0	70.38	0	0	12.4
2014	7	9	8	28	18	32	0	0	0	0	0	0	0	70.38	0	0	12.4
2014	7	9	8	38	18	32	0	0	0	0	0	0	0	70.39	0	0	12.4
2014	7	9	8	48	18	32	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	9	8	58	18	32	0	0	0	0	0	0	0	70.47	0	0	12.6
2014	7	9	9	8	18	32	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	9	9	18	18	33	0	0	0	0	0	0	0	70.54	0	0	13
2014	7	9	9	28	18	32	0	0	0	0	0	0	0	70.57	0	0	13
2014	7	9	9	38	18	33	0	0	0	0	0	0	0	70.63	0	0	13
2014	7	9	9	48	18	33	0	0	0	0	0	0	0	70.68	0	0	13
2014	7	9	9	58	18	32	0	0	0	0	0	0	0	70.74	0	0	13
2014	7	9	10	8	18	32	0	0	0	0	0	0	0	70.79	0	0	13
2014	7	9	10	18	18	33	0	0	0	0	0	0	0	70.86	0	0	13
2014	7	9	10	28	18	33	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	9	10	38	18	32	0	0	0	0	0	0	0	70.99	0	0	13
2014	7	9	10	48	18	32	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	9	10	58	18	33	0	0	0	0	0	0	0	71.13	0	0	12.8
2014	7	9	11	8	18	32	0	0	0	0	0	0	0	71.2	0	0	12.8
2014	7	9	11	18	18	32	0	0	0	0	0	0	0	71.28	0	0	12.8
2014	7	9	11	28	18	32	0	0	0	0	0	0	0	71.35	0	0	12.8
2014	7	9	11	38	18	33	0	0	0	0	0	0	0	71.42	0	0	12.8
2014	7	9	11	48	18	32	0	0	0	0	0	0	0	71.51	0	0	12.8
2014	7	9	11	58	18	33	0	0	0	0	0	0	0	71.6	0	0	12.8
2014	7	9	12	8	18	32	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	9	12	18	18	32	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	9	12	28	18	33	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	9	12	38	18	33	0	0	0	0	0	0	0	71.94	0	0	13
2014	7	9	12	48	18	32	0	0	0	0	0	0	0	72.01	0	0	13
2014	7	9	12	58	18	31	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	9	13	8	18	32	0	0	0	0	0	0	0	72.19	0	0	13
2014	7	9	13	18	18	32	0	0	0	0	0	0	0	72.28	0	0	13
2014	7	9	13	28	18	32	0	0	0	0	0	0	0	72.36	0	0	12.8
2014	7	9	13	38	18	32	0	0	0	0	0	0	0	72.45	0	0	12.8
2014	7	9	13	48	18	32	0	0	0	0	0	0	0	72.52	0	0	12.8
2014	7	9	13	58	18	32	0	0	0	0	0	0	0	72.61	0	0	12.8
2014	7	9	14	8	18	32	0	0	0	0	0	0	0	72.66	0	0	12.8
2014	7	9	14	18	18	33	0	0	0	0	0	0	0	72.75	0	0	12.8
2014	7	9	14	28	18	33	0	0	0	0	0	0	0	72.81	0	0	12.8
2014	7	9	14	38	18	32	0	0	0	0	0	0	0	72.79	0	0	12.6
2014	7	9	14	48	18	32	0	0	0	0	0	0	0	72.9	0	0	12.8
2014	7	9	14	58	18	32	0	0	0	0	0	0	0	72.97	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	15	8	18	33	0	0	0	0	0	0	0	73.02	0	0	12.8
2014	7	9	15	18	18	32	0	0	0	0	0	0	0	73.08	0	0	12.8
2014	7	9	15	28	18	33	0	0	0	0	0	0	0	73.02	0	0	12.2
2014	7	9	15	38	18	32	0	0	0	0	0	0	0	72.97	0	0	12.2
2014	7	9	15	48	18	33	0	0	0	0	0	0	0	73.08	0	0	12.8
2014	7	9	15	58	18	32	0	0	0	0	0	0	0	73.13	0	0	12.8
2014	7	9	16	8	18	32	0	0	0	0	0	0	0	73.17	0	0	12.8
2014	7	9	16	18	18	32	0	0	0	0	0	0	0	73.2	0	0	12.8
2014	7	9	16	28	18	32	0	0	0	0	0	0	0	73.18	0	0	12.8
2014	7	9	16	38	18	31	0	0	0	0	0	0	0	73.24	0	0	12.8
2014	7	9	16	48	18	32	0	0	0	0	0	0	0	73.26	0	0	12.8
2014	7	9	16	58	18	32	0	0	0	0	0	0	0	73.29	0	0	12.8
2014	7	9	17	8	18	32	0	0	0	0	0	0	0	73.26	0	0	12.4
2014	7	9	17	18	18	32	0	0	0	0	0	0	0	73.24	0	0	12.2
2014	7	9	17	28	18	32	0	0	0	0	0	0	0	73.2	0	0	12.2
2014	7	9	17	38	18	32	0	0	0	0	0	0	0	73.2	0	0	12.2
2014	7	9	17	48	18	32	0	0	0	0	0	0	0	73.2	0	0	12
2014	7	9	17	58	18	32	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	9	18	8	18	33	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	9	18	18	18	31	0	0	0	0	0	0	0	73.18	0	0	12
2014	7	9	18	28	18	32	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	9	18	38	18	31	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	18	48	18	31	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	18	58	18	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	19	8	18	31	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	19	18	18	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	19	28	18	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	19	38	18	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	9	19	48	18	31	0	0	0	0	0	0	0	73.15	0	0	11.8
2014	7	9	19	58	18	32	0	0	0	0	0	0	0	73.15	0	0	11.8
2014	7	9	20	8	18	32	0	0	0	0	0	0	0	73.13	0	0	11.8
2014	7	9	20	18	18	32	0	0	0	0	0	0	0	73.13	0	0	11.8
2014	7	9	20	28	18	32	0	0	0	0	0	0	0	73.11	0	0	11.8
2014	7	9	20	38	18	32	0	0	0	0	0	0	0	73.09	0	0	11.8
2014	7	9	20	48	18	32	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	9	20	58	18	32	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	9	21	8	18	32	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	9	21	18	18	32	0	0	0	0	0	0	0	73	0	0	11.8
2014	7	9	21	28	18	31	0	0	0	0	0	0	0	72.99	0	0	11.8
2014	7	9	21	38	18	32	0	0	0	0	0	0	0	72.97	0	0	11.8
2014	7	9	21	48	18	32	0	0	0	0	0	0	0	72.95	0	0	11.8
2014	7	9	21	58	18	32	0	0	0	0	0	0	0	72.91	0	0	11.8
2014	7	9	22	8	18	32	0	0	0	0	0	0	0	72.88	0	0	11.6
2014	7	9	22	18	18	32	0	0	0	0	0	0	0	72.86	0	0	11.6
2014	7	9	22	28	18	32	0	0	0	0	0	0	0	72.81	0	0	11.6
2014	7	9	22	38	18	31	0	0	0	0	0	0	0	72.79	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	9	22	48	18	32	0	0	0	0	0	0	0	72.75	0	0	11.6
2014	7	9	22	58	18	32	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	9	23	8	18	32	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	9	23	18	18	32	0	0	0	0	0	0	0	72.64	0	0	11.6
2014	7	9	23	28	18	32	0	0	0	0	0	0	0	72.59	0	0	11.6
2014	7	9	23	38	18	32	0	0	0	0	0	0	0	72.57	0	0	11.6
2014	7	9	23	48	18	32	0	0	0	0	0	0	0	72.52	0	0	11.6
2014	7	9	23	58	18	32	0	0	0	0	0	0	0	72.48	0	0	11.6
2014	7	10	0	8	18	32	0	0	0	0	0	0	0	72.45	0	0	11.6
2014	7	10	0	18	18	32	0	0	0	0	0	0	0	72.41	0	0	11.6
2014	7	10	0	28	18	32	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	10	0	38	18	32	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	10	0	48	18	32	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	10	0	58	18	31	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	10	1	8	18	32	0	0	0	0	0	0	0	72.21	0	0	11.6
2014	7	10	1	18	18	32	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	10	1	28	18	32	0	0	0	0	0	0	0	72.1	0	0	11.6
2014	7	10	1	38	18	32	0	0	0	0	0	0	0	72.07	0	0	11.6
2014	7	10	1	48	18	32	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	10	1	58	18	32	0	0	0	0	0	0	0	71.98	0	0	11.6
2014	7	10	2	8	18	32	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	10	2	18	18	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	10	2	28	18	32	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	10	2	38	18	32	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	10	2	48	18	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	10	2	58	18	32	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	10	3	8	18	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	10	3	18	18	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	10	3	28	18	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	10	3	38	18	33	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	10	3	48	18	32	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	10	3	58	18	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	10	4	8	18	32	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	10	4	18	18	32	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	10	4	28	18	32	0	0	0	0	0	0	0	71.17	0	0	11.6
2014	7	10	4	38	18	32	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	10	4	48	18	31	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	10	4	58	18	32	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	10	5	8	18	32	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	10	5	18	18	33	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	10	5	28	18	32	0	0	0	0	0	0	0	70.86	0	0	11.6
2014	7	10	5	38	18	32	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	10	5	48	18	33	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	10	5	58	18	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	10	6	8	18	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	10	6	18	18	32	0	0	0	0	0	0	0	70.66	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	6	28	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	10	6	38	18	32	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	10	6	48	18	32	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	10	6	58	18	32	0	0	0	0	0	0	0	70.52	0	0	11.6
2014	7	10	7	8	18	32	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	10	7	18	18	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2014	7	10	7	28	18	33	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	10	7	38	18	32	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	10	7	48	18	32	0	0	0	0	0	0	0	70.45	0	0	12.2
2014	7	10	7	58	18	32	0	0	0	0	0	0	0	70.45	0	0	12.4
2014	7	10	8	8	18	33	0	0	0	0	0	0	0	70.47	0	0	12.4
2014	7	10	8	18	18	32	0	0	0	0	0	0	0	70.48	0	0	12.4
2014	7	10	8	28	18	32	0	0	0	0	0	0	0	70.48	0	0	12.4
2014	7	10	8	38	18	32	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	10	8	48	18	33	0	0	0	0	0	0	0	70.54	0	0	12.6
2014	7	10	8	58	18	33	0	0	0	0	0	0	0	70.57	0	0	12.6
2014	7	10	9	8	18	33	0	0	0	0	0	0	0	70.57	0	0	12.4
2014	7	10	9	18	18	33	0	0	0	0	0	0	0	70.61	0	0	12.8
2014	7	10	9	28	18	33	0	0	0	0	0	0	0	70.66	0	0	13
2014	7	10	9	38	18	32	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	10	9	48	18	33	0	0	0	0	0	0	0	70.77	0	0	13
2014	7	10	9	58	18	33	0	0	0	0	0	0	0	70.83	0	0	13
2014	7	10	10	8	18	32	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	10	10	18	18	33	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	10	10	28	18	33	0	0	0	0	0	0	0	70.99	0	0	13
2014	7	10	10	38	18	32	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	10	10	48	18	32	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	10	10	58	18	33	0	0	0	0	0	0	0	71.2	0	0	12.8
2014	7	10	11	8	18	32	0	0	0	0	0	0	0	71.19	0	0	12.8
2014	7	10	11	18	18	33	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	10	11	28	18	32	0	0	0	0	0	0	0	71.42	0	0	12.8
2014	7	10	11	38	18	33	0	0	0	0	0	0	0	71.4	0	0	13
2014	7	10	11	48	18	32	0	0	0	0	0	0	0	71.4	0	0	12.8
2014	7	10	11	58	18	32	0	0	0	0	0	0	0	71.44	0	0	13
2014	7	10	12	8	18	32	0	0	0	0	0	0	0	71.46	0	0	13
2014	7	10	12	18	18	33	0	0	0	0	0	0	0	71.55	0	0	13
2014	7	10	12	28	18	33	0	0	0	0	0	0	0	71.65	0	0	13.4
2014	7	10	12	38	18	32	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	10	12	48	18	32	0	0	0	0	0	0	0	71.67	0	0	13.2
2014	7	10	12	58	18	32	0	0	0	0	0	0	0	71.71	0	0	13
2014	7	10	13	8	18	32	0	0	0	0	0	0	0	71.73	0	0	13.4
2014	7	10	13	18	18	32	0	0	0	0	0	0	0	71.78	0	0	13.4
2014	7	10	13	28	18	33	0	0	0	0	0	0	0	71.8	0	0	13.4
2014	7	10	13	38	18	33	0	0	0	0	0	0	0	71.82	0	0	13.4
2014	7	10	13	48	18	32	0	0	0	0	0	0	0	71.89	0	0	13.4
2014	7	10	13	58	18	32	0	0	0	0	0	0	0	71.91	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	14	8	18	32	0	0	0	0	0	0	0	71.92	0	0	13.4
2014	7	10	14	18	18	32	0	0	0	0	0	0	0	72.07	0	0	13.4
2014	7	10	14	28	18	32	0	0	0	0	0	0	0	72.1	0	0	13.4
2014	7	10	14	38	18	32	0	0	0	0	0	0	0	72.21	0	0	13
2014	7	10	14	48	18	32	0	0	0	0	0	0	0	72.21	0	0	13
2014	7	10	14	58	18	32	0	0	0	0	0	0	0	72.19	0	0	13
2014	7	10	15	8	18	32	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	10	15	18	18	32	0	0	0	0	0	0	0	72.27	0	0	13
2014	7	10	15	28	18	32	0	0	0	0	0	0	0	72.3	0	0	13
2014	7	10	15	38	18	32	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	10	15	48	18	32	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	10	15	58	18	33	0	0	0	0	0	0	0	72.34	0	0	12.8
2014	7	10	16	8	18	31	0	0	0	0	0	0	0	72.32	0	0	12.8
2014	7	10	16	18	18	32	0	0	0	0	0	0	0	72.32	0	0	13.2
2014	7	10	16	28	18	32	0	0	0	0	0	0	0	72.37	0	0	12.8
2014	7	10	16	38	18	32	0	0	0	0	0	0	0	72.39	0	0	13.2
2014	7	10	16	48	18	32	0	0	0	0	0	0	0	72.41	0	0	12.8
2014	7	10	16	58	18	33	0	0	0	0	0	0	0	72.43	0	0	12.6
2014	7	10	17	8	18	32	0	0	0	0	0	0	0	72.43	0	0	12.6
2014	7	10	17	18	18	32	0	0	0	0	0	0	0	72.43	0	0	12.4
2014	7	10	17	28	18	32	0	0	0	0	0	0	0	72.43	0	0	12.4
2014	7	10	17	38	18	32	0	0	0	0	0	0	0	72.43	0	0	12.2
2014	7	10	17	48	18	32	0	0	0	0	0	0	0	72.41	0	0	12.2
2014	7	10	17	58	18	32	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	10	18	8	18	32	0	0	0	0	0	0	0	72.41	0	0	12
2014	7	10	18	18	18	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	10	18	28	18	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	10	18	38	18	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	10	18	48	18	33	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	10	18	58	18	32	0	0	0	0	0	0	0	72.37	0	0	11.8
2014	7	10	19	8	18	32	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	10	19	18	18	32	0	0	0	0	0	0	0	72.34	0	0	11.8
2014	7	10	19	28	18	32	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	10	19	38	18	33	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	10	19	48	18	31	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	10	19	58	18	32	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	10	20	8	18	32	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	10	20	18	18	32	0	0	0	0	0	0	0	72.23	0	0	11.8
2014	7	10	20	28	18	32	0	0	0	0	0	0	0	72.21	0	0	11.8
2014	7	10	20	38	18	32	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	10	20	48	18	32	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	10	20	58	18	32	0	0	0	0	0	0	0	72.14	0	0	11.6
2014	7	10	21	8	18	32	0	0	0	0	0	0	0	72.1	0	0	11.6
2014	7	10	21	18	18	32	0	0	0	0	0	0	0	72.07	0	0	11.6
2014	7	10	21	28	18	32	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	10	21	38	18	33	0	0	0	0	0	0	0	72.03	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	10	21	48	18	31	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	10	21	58	18	32	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	10	22	8	18	32	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	10	22	18	18	32	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	10	22	28	18	32	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	10	22	38	18	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	10	22	48	18	32	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	10	22	58	18	33	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	10	23	8	18	32	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	10	23	18	18	32	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	10	23	28	18	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	10	23	38	18	32	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	10	23	48	18	32	0	0	0	0	0	0	0	71.64	0	0	11.6
2014	7	10	23	58	18	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	11	0	8	18	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	11	0	18	18	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	11	0	28	18	33	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	11	0	38	18	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	11	0	48	18	32	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	11	0	58	18	32	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	11	1	8	18	33	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	11	1	18	18	33	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	11	1	28	18	31	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	11	1	38	18	32	0	0	0	0	0	0	0	71.31	0	0	11.6
2014	7	11	1	48	18	32	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	11	1	58	18	33	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	11	2	8	18	32	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	11	2	18	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	11	2	28	18	32	0	0	0	0	0	0	0	71.17	0	0	11.6
2014	7	11	2	38	18	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	11	2	48	18	32	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	11	2	58	18	32	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	11	3	8	18	32	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	11	3	18	18	33	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	11	3	28	18	33	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	11	3	38	18	33	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	11	3	48	18	32	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	11	3	58	18	32	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	11	4	8	18	32	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	11	4	18	18	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	11	4	28	18	31	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	11	4	38	18	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	11	4	48	18	33	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	11	4	58	18	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	11	5	8	18	31	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	11	5	18	18	33	0	0	0	0	0	0	0	70.57	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	5	28	18	33	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	11	5	38	18	32	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	11	5	48	18	32	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	11	5	58	18	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	11	6	8	18	31	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	11	6	18	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	11	6	28	18	33	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	11	6	38	18	33	0	0	0	0	0	0	0	70.34	0	0	11.6
2014	7	11	6	48	18	32	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	11	6	58	18	33	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	11	7	8	18	32	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	11	7	18	18	33	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	11	7	28	18	32	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	11	7	38	18	33	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	11	7	48	18	33	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	11	7	58	18	33	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	11	8	8	18	32	0	0	0	0	0	0	0	70.29	0	0	12.2
2014	7	11	8	18	18	32	0	0	0	0	0	0	0	70.34	0	0	12.8
2014	7	11	8	28	18	33	0	0	0	0	0	0	0	70.34	0	0	13
2014	7	11	8	38	18	33	0	0	0	0	0	0	0	70.36	0	0	13
2014	7	11	8	48	18	32	0	0	0	0	0	0	0	70.38	0	0	12.6
2014	7	11	8	58	18	32	0	0	0	0	0	0	0	70.41	0	0	12.8
2014	7	11	9	8	18	32	0	0	0	0	0	0	0	70.38	0	0	12.4
2014	7	11	9	18	18	32	0	0	0	0	0	0	0	70.39	0	0	12.8
2014	7	11	9	28	18	32	0	0	0	0	0	0	0	70.45	0	0	12.4
2014	7	11	9	38	18	33	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	11	9	48	18	32	0	0	0	0	0	0	0	70.54	0	0	13
2014	7	11	9	58	18	33	0	0	0	0	0	0	0	70.57	0	0	12.6
2014	7	11	10	8	18	33	0	0	0	0	0	0	0	70.63	0	0	13.4
2014	7	11	10	18	18	33	0	0	0	0	0	0	0	70.7	0	0	13.4
2014	7	11	10	28	18	33	0	0	0	0	0	0	0	70.77	0	0	13.4
2014	7	11	10	38	18	32	0	0	0	0	0	0	0	70.83	0	0	13.4
2014	7	11	10	48	18	33	0	0	0	0	0	0	0	70.9	0	0	13.4
2014	7	11	10	58	18	32	0	0	0	0	0	0	0	70.99	0	0	13.4
2014	7	11	11	8	18	32	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	11	11	18	18	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	11	11	28	18	32	0	0	0	0	0	0	0	71.19	0	0	13
2014	7	11	11	38	18	32	0	0	0	0	0	0	0	71.26	0	0	13
2014	7	11	11	48	18	32	0	0	0	0	0	0	0	71.31	0	0	13
2014	7	11	11	58	18	32	0	0	0	0	0	0	0	71.38	0	0	13
2014	7	11	12	8	18	32	0	0	0	0	0	0	0	71.47	0	0	13.2
2014	7	11	12	18	18	32	0	0	0	0	0	0	0	71.55	0	0	13.4
2014	7	11	12	28	18	32	0	0	0	0	0	0	0	71.62	0	0	13.2
2014	7	11	12	38	18	32	0	0	0	0	0	0	0	71.67	0	0	13
2014	7	11	12	48	18	33	0	0	0	0	0	0	0	71.76	0	0	13.2
2014	7	11	12	58	18	33	0	0	0	0	0	0	0	71.83	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	13	8	18	33	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	7	11	13	18	18	33	0	0	0	0	0	0	0	71.98	0	0	13.2
2014	7	11	13	28	18	32	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	11	13	38	18	32	0	0	0	0	0	0	0	72.12	0	0	13.4
2014	7	11	13	48	18	32	0	0	0	0	0	0	0	72.21	0	0	13.4
2014	7	11	13	58	18	32	0	0	0	0	0	0	0	72.27	0	0	13.6
2014	7	11	14	8	18	32	0	0	0	0	0	0	0	72.34	0	0	13.4
2014	7	11	14	18	18	32	0	0	0	0	0	0	0	72.39	0	0	13.4
2014	7	11	14	28	18	32	0	0	0	0	0	0	0	72.45	0	0	13.4
2014	7	11	14	38	18	32	0	0	0	0	0	0	0	72.5	0	0	13.4
2014	7	11	14	48	18	32	0	0	0	0	0	0	0	72.57	0	0	13.6
2014	7	11	14	58	18	32	0	0	0	0	0	0	0	72.61	0	0	13.6
2014	7	11	15	8	18	32	0	0	0	0	0	0	0	72.64	0	0	13.6
2014	7	11	15	18	18	32	0	0	0	0	0	0	0	72.68	0	0	13.6
2014	7	11	15	28	18	32	0	0	0	0	0	0	0	72.72	0	0	13.6
2014	7	11	15	38	18	32	0	0	0	0	0	0	0	72.73	0	0	13.6
2014	7	11	15	48	18	32	0	0	0	0	0	0	0	72.77	0	0	13.6
2014	7	11	15	58	18	32	0	0	0	0	0	0	0	72.79	0	0	13.4
2014	7	11	16	8	18	32	0	0	0	0	0	0	0	72.81	0	0	13.4
2014	7	11	16	18	18	32	0	0	0	0	0	0	0	72.82	0	0	13.4
2014	7	11	16	28	18	32	0	0	0	0	0	0	0	72.84	0	0	13
2014	7	11	16	38	18	32	0	0	0	0	0	0	0	72.84	0	0	13.2
2014	7	11	16	48	18	32	0	0	0	0	0	0	0	72.84	0	0	13
2014	7	11	16	58	18	32	0	0	0	0	0	0	0	72.84	0	0	13
2014	7	11	17	8	18	32	0	0	0	0	0	0	0	72.84	0	0	12.8
2014	7	11	17	18	18	32	0	0	0	0	0	0	0	72.84	0	0	12.4
2014	7	11	17	28	18	32	0	0	0	0	0	0	0	72.82	0	0	12.4
2014	7	11	17	38	18	32	0	0	0	0	0	0	0	72.82	0	0	12.2
2014	7	11	17	48	18	32	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	11	17	58	18	32	0	0	0	0	0	0	0	72.79	0	0	12
2014	7	11	18	8	18	33	0	0	0	0	0	0	0	72.77	0	0	11.8
2014	7	11	18	18	18	32	0	0	0	0	0	0	0	72.77	0	0	11.8
2014	7	11	18	28	18	32	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	11	18	38	18	32	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	11	18	48	18	31	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	11	18	58	18	32	0	0	0	0	0	0	0	72.73	0	0	11.8
2014	7	11	19	8	18	32	0	0	0	0	0	0	0	72.73	0	0	11.8
2014	7	11	19	18	18	32	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	11	19	28	18	32	0	0	0	0	0	0	0	72.72	0	0	11.6
2014	7	11	19	38	18	32	0	0	0	0	0	0	0	72.7	0	0	11.6
2014	7	11	19	48	18	32	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	11	19	58	18	31	0	0	0	0	0	0	0	72.68	0	0	11.6
2014	7	11	20	8	18	32	0	0	0	0	0	0	0	72.64	0	0	11.6
2014	7	11	20	18	18	33	0	0	0	0	0	0	0	72.63	0	0	11.6
2014	7	11	20	28	18	32	0	0	0	0	0	0	0	72.61	0	0	11.6
2014	7	11	20	38	18	32	0	0	0	0	0	0	0	72.59	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	11	20	48	18	32	0	0	0	0	0	0	0	72.55	0	0	11.6
2014	7	11	20	58	18	33	0	0	0	0	0	0	0	72.52	0	0	11.6
2014	7	11	21	8	18	32	0	0	0	0	0	0	0	72.5	0	0	11.6
2014	7	11	21	18	18	32	0	0	0	0	0	0	0	72.46	0	0	11.6
2014	7	11	21	28	18	32	0	0	0	0	0	0	0	72.45	0	0	11.6
2014	7	11	21	38	18	32	0	0	0	0	0	0	0	72.41	0	0	11.6
2014	7	11	21	48	18	31	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	11	21	58	18	32	0	0	0	0	0	0	0	72.34	0	0	11.6
2014	7	11	22	8	18	32	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	11	22	18	18	32	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	11	22	28	18	32	0	0	0	0	0	0	0	72.21	0	0	11.6
2014	7	11	22	38	18	32	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	11	22	48	18	32	0	0	0	0	0	0	0	72.12	0	0	11.6
2014	7	11	22	58	18	32	0	0	0	0	0	0	0	72.07	0	0	11.6
2014	7	11	23	8	18	32	0	0	0	0	0	0	0	72.03	0	0	11.6
2014	7	11	23	18	18	32	0	0	0	0	0	0	0	71.98	0	0	11.6
2014	7	11	23	28	18	32	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	11	23	38	18	31	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	11	23	48	18	32	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	11	23	58	18	33	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	12	0	8	18	32	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	12	0	18	18	32	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	12	0	28	18	33	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	12	0	38	18	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	12	0	48	18	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	12	0	58	18	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	12	1	8	18	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	12	1	18	18	32	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	12	1	28	18	32	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	12	1	38	18	32	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	12	1	48	18	32	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	12	1	58	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	12	2	8	18	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	12	2	18	18	32	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	12	2	28	18	32	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	12	2	38	18	32	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	12	2	48	18	32	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	12	2	58	18	33	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	12	3	8	18	32	0	0	0	0	0	0	0	70.79	0	0	11.6
2014	7	12	3	18	18	32	0	0	0	0	0	0	0	70.72	0	0	11.6
2014	7	12	3	28	18	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	12	3	38	18	32	0	0	0	0	0	0	0	70.61	0	0	11.6
2014	7	12	3	48	18	33	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	12	3	58	18	33	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	12	4	8	18	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	12	4	18	18	31	0	0	0	0	0	0	0	70.38	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	4	28	18	32	0	0	0	0	0	0	0	70.3	0	0	11.4
2014	7	12	4	38	18	32	0	0	0	0	0	0	0	70.23	0	0	11.4
2014	7	12	4	48	18	32	0	0	0	0	0	0	0	70.16	0	0	11.4
2014	7	12	4	58	18	32	0	0	0	0	0	0	0	70.11	0	0	11.4
2014	7	12	5	8	18	33	0	0	0	0	0	0	0	70.05	0	0	11.4
2014	7	12	5	18	18	32	0	0	0	0	0	0	0	70	0	0	11.4
2014	7	12	5	28	18	32	0	0	0	0	0	0	0	69.93	0	0	11.4
2014	7	12	5	38	18	32	0	0	0	0	0	0	0	69.85	0	0	11.4
2014	7	12	5	48	18	32	0	0	0	0	0	0	0	69.8	0	0	11.4
2014	7	12	5	58	18	32	0	0	0	0	0	0	0	69.76	0	0	11.4
2014	7	12	6	8	18	33	0	0	0	0	0	0	0	69.71	0	0	11.4
2014	7	12	6	18	18	33	0	0	0	0	0	0	0	69.66	0	0	11.4
2014	7	12	6	28	18	32	0	0	0	0	0	0	0	69.6	0	0	11.4
2014	7	12	6	38	18	32	0	0	0	0	0	0	0	69.57	0	0	11.4
2014	7	12	6	48	18	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	12	6	58	18	32	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	12	7	8	18	32	0	0	0	0	0	0	0	69.46	0	0	11.6
2014	7	12	7	18	18	33	0	0	0	0	0	0	0	69.42	0	0	11.8
2014	7	12	7	28	18	32	0	0	0	0	0	0	0	69.4	0	0	12
2014	7	12	7	38	18	33	0	0	0	0	0	0	0	69.39	0	0	12
2014	7	12	7	48	18	32	0	0	0	0	0	0	0	69.39	0	0	12.2
2014	7	12	7	58	18	33	0	0	0	0	0	0	0	69.39	0	0	12.4
2014	7	12	8	8	18	32	0	0	0	0	0	0	0	69.39	0	0	12.8
2014	7	12	8	18	18	32	0	0	0	0	0	0	0	69.4	0	0	13
2014	7	12	8	28	18	32	0	0	0	0	0	0	0	69.42	0	0	13.4
2014	7	12	8	38	18	32	0	0	0	0	0	0	0	69.42	0	0	13.4
2014	7	12	8	48	18	32	0	0	0	0	0	0	0	69.46	0	0	13.6
2014	7	12	8	58	18	33	0	0	0	0	0	0	0	69.49	0	0	13.8
2014	7	12	9	8	18	32	0	0	0	0	0	0	0	69.53	0	0	13.6
2014	7	12	9	18	18	32	0	0	0	0	0	0	0	69.57	0	0	13.8
2014	7	12	9	28	18	32	0	0	0	0	0	0	0	69.6	0	0	13.8
2014	7	12	9	38	18	32	0	0	0	0	0	0	0	69.66	0	0	13.6
2014	7	12	9	48	18	33	0	0	0	0	0	0	0	69.71	0	0	13.8
2014	7	12	9	58	18	33	0	0	0	0	0	0	0	69.76	0	0	13.8
2014	7	12	10	8	18	32	0	0	0	0	0	0	0	69.84	0	0	13.4
2014	7	12	10	18	18	32	0	0	0	0	0	0	0	69.91	0	0	13.4
2014	7	12	10	28	18	32	0	0	0	0	0	0	0	69.96	0	0	13.4
2014	7	12	10	38	18	33	0	0	0	0	0	0	0	70.03	0	0	13.4
2014	7	12	10	48	18	32	0	0	0	0	0	0	0	70.11	0	0	13.4
2014	7	12	10	58	18	33	0	0	0	0	0	0	0	70.2	0	0	13.4
2014	7	12	11	8	18	32	0	0	0	0	0	0	0	70.27	0	0	13.4
2014	7	12	11	18	18	32	0	0	0	0	0	0	0	70.36	0	0	13.4
2014	7	12	11	28	18	33	0	0	0	0	0	0	0	70.43	0	0	13.2
2014	7	12	11	38	18	33	0	0	0	0	0	0	0	70.52	0	0	13.2
2014	7	12	11	48	18	32	0	0	0	0	0	0	0	70.61	0	0	13.2
2014	7	12	11	58	18	31	0	0	0	0	0	0	0	70.68	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	12	8	18	32	0	0	0	0	0	0	0	70.77	0	0	13.2
2014	7	12	12	18	18	32	0	0	0	0	0	0	0	70.86	0	0	13.4
2014	7	12	12	28	18	32	0	0	0	0	0	0	0	70.97	0	0	13.4
2014	7	12	12	38	18	31	0	0	0	0	0	0	0	71.02	0	0	13.2
2014	7	12	12	48	18	32	0	0	0	0	0	0	0	71.13	0	0	13.2
2014	7	12	12	58	18	32	0	0	0	0	0	0	0	71.22	0	0	13.4
2014	7	12	13	8	18	32	0	0	0	0	0	0	0	71.31	0	0	13.4
2014	7	12	13	18	18	32	0	0	0	0	0	0	0	71.4	0	0	13.4
2014	7	12	13	28	18	32	0	0	0	0	0	0	0	71.49	0	0	13.4
2014	7	12	13	38	18	32	0	0	0	0	0	0	0	71.58	0	0	13.4
2014	7	12	13	48	18	32	0	0	0	0	0	0	0	71.67	0	0	13.4
2014	7	12	13	58	18	32	0	0	0	0	0	0	0	71.73	0	0	13.2
2014	7	12	14	8	18	32	0	0	0	0	0	0	0	71.83	0	0	13.2
2014	7	12	14	18	18	32	0	0	0	0	0	0	0	71.89	0	0	12.8
2014	7	12	14	28	18	31	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	12	14	38	18	32	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	12	14	48	18	32	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	12	14	58	18	32	0	0	0	0	0	0	0	72.16	0	0	12.8
2014	7	12	15	8	18	32	0	0	0	0	0	0	0	72.21	0	0	12.8
2014	7	12	15	18	18	32	0	0	0	0	0	0	0	72.28	0	0	12.8
2014	7	12	15	28	18	32	0	0	0	0	0	0	0	72.34	0	0	12.8
2014	7	12	15	38	18	32	0	0	0	0	0	0	0	72.36	0	0	12.8
2014	7	12	15	48	18	31	0	0	0	0	0	0	0	72.41	0	0	12.8
2014	7	12	15	58	18	33	0	0	0	0	0	0	0	72.45	0	0	12.8
2014	7	12	16	8	18	32	0	0	0	0	0	0	0	72.46	0	0	13
2014	7	12	16	18	18	32	0	0	0	0	0	0	0	72.5	0	0	12.8
2014	7	12	16	28	18	32	0	0	0	0	0	0	0	72.54	0	0	13
2014	7	12	16	38	18	32	0	0	0	0	0	0	0	72.54	0	0	12.8
2014	7	12	16	48	18	32	0	0	0	0	0	0	0	72.54	0	0	12.8
2014	7	12	16	58	18	32	0	0	0	0	0	0	0	72.55	0	0	12.8
2014	7	12	17	8	18	32	0	0	0	0	0	0	0	72.57	0	0	12.8
2014	7	12	17	18	18	32	0	0	0	0	0	0	0	72.57	0	0	12.4
2014	7	12	17	28	18	32	0	0	0	0	0	0	0	72.59	0	0	12.2
2014	7	12	17	38	18	32	0	0	0	0	0	0	0	72.59	0	0	12.2
2014	7	12	17	48	18	32	0	0	0	0	0	0	0	72.59	0	0	12.2
2014	7	12	17	58	18	32	0	0	0	0	0	0	0	72.59	0	0	12.2
2014	7	12	18	8	18	33	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	12	18	18	18	32	0	0	0	0	0	0	0	72.61	0	0	12
2014	7	12	18	28	18	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	18	38	18	31	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	18	48	18	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	18	58	18	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	19	8	18	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	19	18	18	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	19	28	18	33	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	12	19	38	18	32	0	0	0	0	0	0	0	72.61	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	12	19	48	18	32	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	12	19	58	18	32	0	0	0	0	0	0	0	72.59	0	0	11.8
2014	7	12	20	8	18	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	12	20	18	18	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	12	20	28	18	32	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	12	20	38	18	31	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	12	20	48	18	32	0	0	0	0	0	0	0	72.5	0	0	11.6
2014	7	12	20	58	18	32	0	0	0	0	0	0	0	72.48	0	0	11.6
2014	7	12	21	8	18	32	0	0	0	0	0	0	0	72.45	0	0	11.6
2014	7	12	21	18	18	32	0	0	0	0	0	0	0	72.43	0	0	11.6
2014	7	12	21	28	18	33	0	0	0	0	0	0	0	72.41	0	0	11.6
2014	7	12	21	38	18	31	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	12	21	48	18	32	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	12	21	58	18	31	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	12	22	8	18	32	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	12	22	18	18	32	0	0	0	0	0	0	0	72.21	0	0	11.6
2014	7	12	22	28	18	32	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	12	22	38	18	32	0	0	0	0	0	0	0	72.12	0	0	11.6
2014	7	12	22	48	18	32	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	12	22	58	18	32	0	0	0	0	0	0	0	72.01	0	0	11.6
2014	7	12	23	8	18	32	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	12	23	18	18	32	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	12	23	28	18	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	12	23	38	18	33	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	12	23	48	18	32	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	12	23	58	18	32	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	13	0	8	18	33	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	13	0	18	18	31	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	13	0	28	18	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	13	0	38	18	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	13	0	48	18	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	13	0	58	18	33	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	13	1	8	18	33	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	13	1	18	18	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	13	1	28	18	32	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	13	1	38	18	32	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	13	1	48	18	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	13	1	58	18	32	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	13	2	8	18	32	0	0	0	0	0	0	0	70.95	0	0	11.6
2014	7	13	2	18	18	32	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	13	2	28	18	33	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	13	2	38	18	31	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	13	2	48	18	33	0	0	0	0	0	0	0	70.68	0	0	11.6
2014	7	13	2	58	18	33	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	13	3	8	18	32	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	13	3	18	18	32	0	0	0	0	0	0	0	70.5	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	3	28	18	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	13	3	38	18	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	13	3	48	18	32	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	13	3	58	18	31	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	13	4	8	18	31	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	13	4	18	18	33	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	13	4	28	18	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	13	4	38	18	32	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	13	4	48	18	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	13	4	58	18	32	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	13	5	8	18	32	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	13	5	18	18	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	13	5	28	18	33	0	0	0	0	0	0	0	69.71	0	0	11.6
2014	7	13	5	38	18	33	0	0	0	0	0	0	0	69.66	0	0	11.6
2014	7	13	5	48	18	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	13	5	58	18	33	0	0	0	0	0	0	0	69.55	0	0	11.6
2014	7	13	6	8	18	32	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	13	6	18	18	32	0	0	0	0	0	0	0	69.44	0	0	11.6
2014	7	13	6	28	18	32	0	0	0	0	0	0	0	69.39	0	0	11.6
2014	7	13	6	38	18	32	0	0	0	0	0	0	0	69.35	0	0	11.6
2014	7	13	6	48	18	31	0	0	0	0	0	0	0	69.28	0	0	11.6
2014	7	13	6	58	18	32	0	0	0	0	0	0	0	69.24	0	0	11.8
2014	7	13	7	8	18	32	0	0	0	0	0	0	0	69.19	0	0	11.8
2014	7	13	7	18	18	33	0	0	0	0	0	0	0	69.19	0	0	11.8
2014	7	13	7	28	18	33	0	0	0	0	0	0	0	69.17	0	0	12
2014	7	13	7	38	18	32	0	0	0	0	0	0	0	69.15	0	0	12.2
2014	7	13	7	48	18	32	0	0	0	0	0	0	0	69.15	0	0	12.2
2014	7	13	7	58	18	32	0	0	0	0	0	0	0	69.15	0	0	12.4
2014	7	13	8	8	18	33	0	0	0	0	0	0	0	69.15	0	0	12.4
2014	7	13	8	18	18	32	0	0	0	0	0	0	0	69.17	0	0	12.4
2014	7	13	8	28	18	32	0	0	0	0	0	0	0	69.17	0	0	12.6
2014	7	13	8	38	18	33	0	0	0	0	0	0	0	69.19	0	0	12.6
2014	7	13	8	48	18	33	0	0	0	0	0	0	0	69.22	0	0	13
2014	7	13	8	58	18	32	0	0	0	0	0	0	0	69.24	0	0	13
2014	7	13	9	8	18	32	0	0	0	0	0	0	0	69.28	0	0	13.2
2014	7	13	9	18	18	33	0	0	0	0	0	0	0	69.33	0	0	13
2014	7	13	9	28	18	32	0	0	0	0	0	0	0	69.37	0	0	13
2014	7	13	9	38	18	33	0	0	0	0	0	0	0	69.42	0	0	13.4
2014	7	13	9	48	18	33	0	0	0	0	0	0	0	69.46	0	0	13.2
2014	7	13	9	58	18	32	0	0	0	0	0	0	0	69.53	0	0	13.2
2014	7	13	10	8	18	33	0	0	0	0	0	0	0	69.62	0	0	13.2
2014	7	13	10	18	18	33	0	0	0	0	0	0	0	69.66	0	0	13.2
2014	7	13	10	28	18	32	0	0	0	0	0	0	0	69.76	0	0	13.2
2014	7	13	10	38	18	32	0	0	0	0	0	0	0	69.84	0	0	13.2
2014	7	13	10	48	18	33	0	0	0	0	0	0	0	69.91	0	0	13
2014	7	13	10	58	18	32	0	0	0	0	0	0	0	70	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	11	8	18	33	0	0	0	0	0	0	0	70.07	0	0	13
2014	7	13	11	18	18	32	0	0	0	0	0	0	0	70.16	0	0	13
2014	7	13	11	28	18	32	0	0	0	0	0	0	0	70.25	0	0	12.8
2014	7	13	11	38	18	32	0	0	0	0	0	0	0	70.32	0	0	12.8
2014	7	13	11	48	18	33	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	13	11	58	18	33	0	0	0	0	0	0	0	70.48	0	0	13
2014	7	13	12	8	18	33	0	0	0	0	0	0	0	70.59	0	0	13
2014	7	13	12	18	18	33	0	0	0	0	0	0	0	70.68	0	0	13
2014	7	13	12	28	18	32	0	0	0	0	0	0	0	70.79	0	0	13
2014	7	13	12	38	18	33	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	13	12	48	18	32	0	0	0	0	0	0	0	70.97	0	0	13
2014	7	13	12	58	18	32	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	13	13	8	18	33	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	13	13	18	18	32	0	0	0	0	0	0	0	71.26	0	0	13
2014	7	13	13	28	18	33	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	13	13	38	18	32	0	0	0	0	0	0	0	71.44	0	0	12.8
2014	7	13	13	48	18	32	0	0	0	0	0	0	0	71.53	0	0	12.8
2014	7	13	13	58	18	32	0	0	0	0	0	0	0	71.62	0	0	12.8
2014	7	13	14	8	18	32	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	13	14	18	18	32	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	13	14	28	18	31	0	0	0	0	0	0	0	71.85	0	0	12.8
2014	7	13	14	38	18	32	0	0	0	0	0	0	0	71.92	0	0	12.8
2014	7	13	14	48	18	32	0	0	0	0	0	0	0	71.98	0	0	12.8
2014	7	13	14	58	18	32	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	13	15	8	18	32	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	13	15	18	18	33	0	0	0	0	0	0	0	72.16	0	0	12.8
2014	7	13	15	28	18	31	0	0	0	0	0	0	0	72.23	0	0	12.8
2014	7	13	15	38	18	32	0	0	0	0	0	0	0	72.27	0	0	12.8
2014	7	13	15	48	18	33	0	0	0	0	0	0	0	72.3	0	0	12.6
2014	7	13	15	58	18	32	0	0	0	0	0	0	0	72.34	0	0	12.6
2014	7	13	16	8	18	33	0	0	0	0	0	0	0	72.37	0	0	12.6
2014	7	13	16	18	18	33	0	0	0	0	0	0	0	72.41	0	0	12.6
2014	7	13	16	28	18	32	0	0	0	0	0	0	0	72.43	0	0	12.6
2014	7	13	16	38	18	33	0	0	0	0	0	0	0	72.45	0	0	12.6
2014	7	13	16	48	18	32	0	0	0	0	0	0	0	72.46	0	0	12.4
2014	7	13	16	58	18	32	0	0	0	0	0	0	0	72.48	0	0	12.6
2014	7	13	17	8	18	32	0	0	0	0	0	0	0	72.5	0	0	12.2
2014	7	13	17	18	18	32	0	0	0	0	0	0	0	72.5	0	0	11.8
2014	7	13	17	28	18	32	0	0	0	0	0	0	0	72.52	0	0	11.8
2014	7	13	17	38	18	33	0	0	0	0	0	0	0	72.52	0	0	11.6
2014	7	13	17	48	18	32	0	0	0	0	0	0	0	72.52	0	0	11.4
2014	7	13	17	58	18	32	0	0	0	0	0	0	0	72.52	0	0	11.2
2014	7	13	18	8	18	32	0	0	0	0	0	0	0	72.54	0	0	11.2
2014	7	13	18	18	18	32	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	13	18	28	18	32	0	0	0	0	0	0	0	72.54	0	0	11.2
2014	7	13	18	38	18	32	0	0	0	0	0	0	0	72.55	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	13	18	48	18	31	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	13	18	58	18	32	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	13	19	8	18	32	0	0	0	0	0	0	0	72.57	0	0	11
2014	7	13	19	18	18	32	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	13	19	28	18	33	0	0	0	0	0	0	0	72.57	0	0	11.2
2014	7	13	19	38	18	32	0	0	0	0	0	0	0	72.57	0	0	11
2014	7	13	19	48	18	32	0	0	0	0	0	0	0	72.57	0	0	11
2014	7	13	19	58	18	32	0	0	0	0	0	0	0	72.55	0	0	10.8
2014	7	13	20	8	18	32	0	0	0	0	0	0	0	72.55	0	0	11
2014	7	13	20	18	18	32	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	13	20	28	18	32	0	0	0	0	0	0	0	72.54	0	0	11.4
2014	7	13	20	38	18	32	0	0	0	0	0	0	0	72.52	0	0	11.4
2014	7	13	20	48	18	32	0	0	0	0	0	0	0	72.5	0	0	11.6
2014	7	13	20	58	18	33	0	0	0	0	0	0	0	72.46	0	0	11.4
2014	7	13	21	8	18	32	0	0	0	0	0	0	0	72.45	0	0	11.4
2014	7	13	21	18	18	32	0	0	0	0	0	0	0	72.43	0	0	11.6
2014	7	13	21	28	18	32	0	0	0	0	0	0	0	72.39	0	0	11.6
2014	7	13	21	38	18	32	0	0	0	0	0	0	0	72.37	0	0	11.4
2014	7	13	21	48	18	32	0	0	0	0	0	0	0	72.36	0	0	11.6
2014	7	13	21	58	18	32	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	13	22	8	18	32	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	13	22	18	18	33	0	0	0	0	0	0	0	72.25	0	0	11.6
2014	7	13	22	28	18	32	0	0	0	0	0	0	0	72.21	0	0	11.6
2014	7	13	22	38	18	32	0	0	0	0	0	0	0	72.18	0	0	11.6
2014	7	13	22	48	18	32	0	0	0	0	0	0	0	72.14	0	0	11.6
2014	7	13	22	58	18	32	0	0	0	0	0	0	0	72.1	0	0	11.6
2014	7	13	23	8	18	33	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	13	23	18	18	32	0	0	0	0	0	0	0	72.01	0	0	11.6
2014	7	13	23	28	18	32	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	13	23	38	18	31	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	13	23	48	18	32	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	13	23	58	18	33	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	14	0	8	18	32	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	14	0	18	18	32	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	14	0	28	18	32	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	14	0	38	18	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	14	0	48	18	32	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	14	0	58	18	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	14	1	8	18	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	14	1	18	18	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	14	1	28	18	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	14	1	38	18	31	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	14	1	48	18	33	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	14	1	58	18	32	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	14	2	8	18	33	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	14	2	18	18	32	0	0	0	0	0	0	0	71.22	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	2	28	18	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	14	2	38	18	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	14	2	48	18	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	14	2	58	18	32	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	14	3	8	18	32	0	0	0	0	0	0	0	70.99	0	0	11.6
2014	7	14	3	18	18	32	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	14	3	28	18	33	0	0	0	0	0	0	0	70.88	0	0	11.6
2014	7	14	3	38	18	32	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	14	3	48	18	32	0	0	0	0	0	0	0	70.79	0	0	11.6
2014	7	14	3	58	18	32	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	14	4	8	18	33	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	14	4	18	18	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	14	4	28	18	33	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	14	4	38	18	32	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	14	4	48	18	32	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	14	4	58	18	33	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	14	5	8	18	32	0	0	0	0	0	0	0	70.48	0	0	11.4
2014	7	14	5	18	18	32	0	0	0	0	0	0	0	70.45	0	0	11.4
2014	7	14	5	28	18	32	0	0	0	0	0	0	0	70.43	0	0	11.4
2014	7	14	5	38	18	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	14	5	48	18	32	0	0	0	0	0	0	0	70.38	0	0	11.4
2014	7	14	5	58	18	32	0	0	0	0	0	0	0	70.36	0	0	11.4
2014	7	14	6	8	18	32	0	0	0	0	0	0	0	70.34	0	0	11.4
2014	7	14	6	18	18	32	0	0	0	0	0	0	0	70.32	0	0	11.4
2014	7	14	6	28	18	33	0	0	0	0	0	0	0	70.32	0	0	11.2
2014	7	14	6	38	18	32	0	0	0	0	0	0	0	70.32	0	0	11.4
2014	7	14	6	48	18	33	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	14	6	58	18	32	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	14	7	8	18	33	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	14	7	18	18	32	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	14	7	28	18	33	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	14	7	38	18	33	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	14	7	48	18	32	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	14	7	58	18	33	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	14	8	8	18	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	14	8	18	18	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	14	8	28	18	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	14	8	38	18	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	14	8	48	18	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	14	8	58	18	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	14	9	8	18	32	0	0	0	0	0	0	0	70.47	0	0	12
2014	7	14	9	18	18	32	0	0	0	0	0	0	0	70.5	0	0	12
2014	7	14	9	28	18	32	0	0	0	0	0	0	0	70.63	0	0	12.8
2014	7	14	9	38	18	32	0	0	0	0	0	0	0	70.59	0	0	12.6
2014	7	14	9	48	18	32	0	0	0	0	0	0	0	70.63	0	0	12.8
2014	7	14	9	58	18	32	0	0	0	0	0	0	0	70.68	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	10	8	18	32	0	0	0	0	0	0	0	70.66	0	0	12.4
2014	7	14	10	18	18	32	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	14	10	28	18	32	0	0	0	0	0	0	0	70.68	0	0	12
2014	7	14	10	38	18	32	0	0	0	0	0	0	0	70.74	0	0	12.2
2014	7	14	10	48	18	33	0	0	0	0	0	0	0	70.81	0	0	12.4
2014	7	14	10	58	18	32	0	0	0	0	0	0	0	70.84	0	0	12.4
2014	7	14	11	8	18	32	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	14	11	18	18	31	0	0	0	0	0	0	0	70.9	0	0	12.2
2014	7	14	11	28	18	32	0	0	0	0	0	0	0	70.92	0	0	12.2
2014	7	14	11	38	18	32	0	0	0	0	0	0	0	70.97	0	0	12.2
2014	7	14	11	48	18	32	0	0	0	0	0	0	0	71.01	0	0	12.6
2014	7	14	11	58	18	33	0	0	0	0	0	0	0	71.22	0	0	13
2014	7	14	12	8	18	32	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	14	12	18	18	32	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	14	12	28	18	32	0	0	0	0	0	0	0	71.49	0	0	13
2014	7	14	12	38	18	32	0	0	0	0	0	0	0	71.53	0	0	13
2014	7	14	12	48	18	32	0	0	0	0	0	0	0	71.58	0	0	13
2014	7	14	12	58	18	33	0	0	0	0	0	0	0	71.58	0	0	13.2
2014	7	14	13	8	18	32	0	0	0	0	0	0	0	71.74	0	0	13
2014	7	14	13	18	18	33	0	0	0	0	0	0	0	71.8	0	0	13
2014	7	14	13	28	18	32	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	14	13	38	18	32	0	0	0	0	0	0	0	71.82	0	0	13
2014	7	14	13	48	18	33	0	0	0	0	0	0	0	71.83	0	0	13
2014	7	14	13	58	18	32	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	14	14	8	18	32	0	0	0	0	0	0	0	71.96	0	0	13
2014	7	14	14	27	0	32	0	0	0	0	0	0	0	72	0	0	12.6
2014	7	14	14	37	0	32	0	0	0	0	0	0	0	72.01	0	0	13.4
2014	7	14	14	47	0	32	0	0	0	0	0	0	0	72.09	0	0	13.4
2014	7	14	14	57	0	32	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	14	15	7	0	32	0	0	0	0	0	0	0	72.09	0	0	13
2014	7	14	15	17	0	33	0	0	0	0	0	0	0	72.12	0	0	13
2014	7	14	15	27	0	32	0	0	0	0	0	0	0	72.25	0	0	13.6
2014	7	14	15	37	0	32	0	0	0	0	0	0	0	72.34	0	0	13.6
2014	7	14	15	47	0	31	0	0	0	0	0	0	0	72.36	0	0	13.6
2014	7	14	15	57	0	32	0	0	0	0	0	0	0	72.37	0	0	13.4
2014	7	14	16	7	0	32	0	0	0	0	0	0	0	72.37	0	0	13.4
2014	7	14	16	17	0	31	0	0	0	0	0	0	0	72.37	0	0	13.2
2014	7	14	16	27	0	32	0	0	0	0	0	0	0	72.46	0	0	13.4
2014	7	14	16	37	0	32	0	0	0	0	0	0	0	72.45	0	0	13.4
2014	7	14	16	47	0	32	0	0	0	0	0	0	0	72.5	0	0	13.4
2014	7	14	16	57	0	32	0	0	0	0	0	0	0	72.54	0	0	13.2
2014	7	14	17	7	0	32	0	0	0	0	0	0	0	72.54	0	0	13.2
2014	7	14	17	17	0	32	0	0	0	0	0	0	0	72.5	0	0	12.4
2014	7	14	17	27	0	32	0	0	0	0	0	0	0	72.5	0	0	12.2
2014	7	14	17	37	0	32	0	0	0	0	0	0	0	72.5	0	0	12.2
2014	7	14	17	47	0	33	0	0	0	0	0	0	0	72.52	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	14	17	57	0	32	0	0	0	0	0	0	0	72.54	0	0	12.2
2014	7	14	18	7	0	32	0	0	0	0	0	0	0	72.54	0	0	12.2
2014	7	14	18	17	0	32	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	14	18	27	0	32	0	0	0	0	0	0	0	72.55	0	0	12
2014	7	14	18	37	0	33	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	14	18	47	0	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	14	18	57	0	32	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	14	19	7	0	31	0	0	0	0	0	0	0	72.57	0	0	12
2014	7	14	19	17	0	31	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	14	19	27	0	32	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	14	19	37	0	31	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	14	19	47	0	32	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	14	19	57	0	32	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	14	20	7	0	32	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	14	20	17	0	32	0	0	0	0	0	0	0	72.52	0	0	11.8
2014	7	14	20	27	0	32	0	0	0	0	0	0	0	72.52	0	0	11.8
2014	7	14	20	37	0	32	0	0	0	0	0	0	0	72.5	0	0	11.8
2014	7	14	20	47	0	31	0	0	0	0	0	0	0	72.48	0	0	11.8
2014	7	14	20	57	0	32	0	0	0	0	0	0	0	72.48	0	0	11.8
2014	7	14	21	7	0	33	0	0	0	0	0	0	0	72.46	0	0	11.8
2014	7	14	21	17	0	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	14	21	27	0	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	14	21	37	0	32	0	0	0	0	0	0	0	72.43	0	0	11.8
2014	7	14	21	47	0	32	0	0	0	0	0	0	0	72.41	0	0	11.8
2014	7	14	21	57	0	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	14	22	7	0	32	0	0	0	0	0	0	0	72.37	0	0	11.8
2014	7	14	22	17	0	33	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	14	22	27	0	32	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	14	22	37	0	32	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	14	22	47	0	32	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	14	22	57	0	32	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	14	23	7	0	32	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	14	23	17	0	32	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	14	23	27	0	33	0	0	0	0	0	0	0	72.23	0	0	11.8
2014	7	14	23	37	0	32	0	0	0	0	0	0	0	72.21	0	0	11.8
2014	7	14	23	47	0	32	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	14	23	57	0	32	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	15	0	7	0	32	0	0	0	0	0	0	0	72.16	0	0	11.8
2014	7	15	0	17	0	32	0	0	0	0	0	0	0	72.14	0	0	11.8
2014	7	15	0	27	0	32	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	15	0	37	0	32	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	15	0	47	0	32	0	0	0	0	0	0	0	72.09	0	0	11.8
2014	7	15	0	57	0	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	15	1	7	0	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	15	1	17	0	32	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	15	1	27	0	32	0	0	0	0	0	0	0	72.01	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	1	37	0	32	0	0	0	0	0	0	0	72	0	0	11.8
2014	7	15	1	47	0	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	15	1	57	0	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	15	2	7	0	33	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	15	2	17	0	32	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	15	2	27	0	31	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	15	2	37	0	32	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	15	2	47	0	32	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	15	2	57	0	32	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	15	3	7	0	33	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	15	3	17	0	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	15	3	27	0	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	15	3	37	0	32	0	0	0	0	0	0	0	71.74	0	0	11.8
2014	7	15	3	47	0	32	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	15	3	57	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	15	4	7	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	15	4	17	0	33	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	15	4	27	0	32	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	15	4	37	0	33	0	0	0	0	0	0	0	71.64	0	0	11.6
2014	7	15	4	47	0	31	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	15	4	57	0	32	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	15	5	7	0	32	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	15	5	17	0	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	15	5	27	0	33	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	15	5	37	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	15	5	47	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	15	5	57	0	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	15	6	7	0	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	15	6	17	0	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	15	6	27	0	33	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	15	6	37	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	15	6	47	0	32	0	0	0	0	0	0	0	71.51	0	0	11.8
2014	7	15	6	57	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	15	7	7	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	15	7	17	0	32	0	0	0	0	0	0	0	71.51	0	0	11.8
2014	7	15	7	27	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	15	7	37	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	15	7	47	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	15	7	57	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	15	8	7	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	15	8	17	0	32	0	0	0	0	0	0	0	71.51	0	0	11.8
2014	7	15	8	27	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	15	8	37	0	33	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	15	8	47	0	32	0	0	0	0	0	0	0	71.55	0	0	11.8
2014	7	15	8	57	0	32	0	0	0	0	0	0	0	71.55	0	0	11.8
2014	7	15	9	7	0	32	0	0	0	0	0	0	0	71.58	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	9	17	0	33	0	0	0	0	0	0	0	71.62	0	0	12
2014	7	15	9	27	0	32	0	0	0	0	0	0	0	71.64	0	0	12.2
2014	7	15	9	37	0	32	0	0	0	0	0	0	0	71.65	0	0	12.2
2014	7	15	9	47	0	33	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	15	9	57	0	32	0	0	0	0	0	0	0	71.71	0	0	12.8
2014	7	15	10	7	0	32	0	0	0	0	0	0	0	71.73	0	0	13
2014	7	15	10	17	0	32	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	15	10	27	0	33	0	0	0	0	0	0	0	71.8	0	0	13.2
2014	7	15	10	37	0	32	0	0	0	0	0	0	0	71.82	0	0	13.2
2014	7	15	10	47	0	32	0	0	0	0	0	0	0	71.85	0	0	13.4
2014	7	15	10	57	0	32	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	7	15	11	7	0	32	0	0	0	0	0	0	0	71.94	0	0	13.6
2014	7	15	11	17	0	32	0	0	0	0	0	0	0	72.05	0	0	13
2014	7	15	11	27	0	32	0	0	0	0	0	0	0	72.05	0	0	13.2
2014	7	15	11	37	0	32	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	15	11	47	0	32	0	0	0	0	0	0	0	72.14	0	0	13.4
2014	7	15	11	57	0	32	0	0	0	0	0	0	0	72.16	0	0	13.4
2014	7	15	12	7	0	32	0	0	0	0	0	0	0	72.36	0	0	13.6
2014	7	15	12	17	0	32	0	0	0	0	0	0	0	72.34	0	0	13.2
2014	7	15	12	27	0	32	0	0	0	0	0	0	0	72.3	0	0	13.2
2014	7	15	12	37	0	32	0	0	0	0	0	0	0	72.41	0	0	12.8
2014	7	15	12	47	0	32	0	0	0	0	0	0	0	72.37	0	0	12.6
2014	7	15	12	57	0	32	0	0	0	0	0	0	0	72.57	0	0	13.2
2014	7	15	13	7	0	32	0	0	0	0	0	0	0	72.68	0	0	13.4
2014	7	15	13	17	0	32	0	0	0	0	0	0	0	72.77	0	0	13.2
2014	7	15	13	27	0	32	0	0	0	0	0	0	0	72.86	0	0	13.4
2014	7	15	13	37	0	32	0	0	0	0	0	0	0	72.88	0	0	13
2014	7	15	13	47	0	32	0	0	0	0	0	0	0	73	0	0	13.6
2014	7	15	13	57	0	32	0	0	0	0	0	0	0	73.08	0	0	13.2
2014	7	15	14	7	0	32	0	0	0	0	0	0	0	73.15	0	0	13.4
2014	7	15	14	17	0	32	0	0	0	0	0	0	0	73.06	0	0	13.4
2014	7	15	14	27	0	32	0	0	0	0	0	0	0	73.02	0	0	13.4
2014	7	15	14	37	0	33	0	0	0	0	0	0	0	73.2	0	0	14
2014	7	15	14	47	0	32	0	0	0	0	0	0	0	73.22	0	0	13.8
2014	7	15	14	57	0	33	0	0	0	0	0	0	0	73.29	0	0	14
2014	7	15	15	7	0	32	0	0	0	0	0	0	0	73.35	0	0	13.8
2014	7	15	15	17	0	32	0	0	0	0	0	0	0	73.4	0	0	13.8
2014	7	15	15	27	0	32	0	0	0	0	0	0	0	73.47	0	0	13.8
2014	7	15	15	37	0	32	0	0	0	0	0	0	0	73.49	0	0	13.4
2014	7	15	15	47	0	32	0	0	0	0	0	0	0	73.53	0	0	13.6
2014	7	15	15	57	0	32	0	0	0	0	0	0	0	73.54	0	0	13.6
2014	7	15	16	7	0	32	0	0	0	0	0	0	0	73.56	0	0	13.6
2014	7	15	16	17	0	32	0	0	0	0	0	0	0	73.58	0	0	13.4
2014	7	15	16	27	0	32	0	0	0	0	0	0	0	73.6	0	0	13.4
2014	7	15	16	37	0	32	0	0	0	0	0	0	0	73.62	0	0	13.4
2014	7	15	16	47	0	31	0	0	0	0	0	0	0	73.58	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	15	16	57	0	33	0	0	0	0	0	0	0	73.56	0	0	13.2
2014	7	15	17	7	0	32	0	0	0	0	0	0	0	73.62	0	0	13.2
2014	7	15	17	17	0	32	0	0	0	0	0	0	0	73.63	0	0	12.6
2014	7	15	17	27	0	31	0	0	0	0	0	0	0	73.6	0	0	12.4
2014	7	15	17	37	0	32	0	0	0	0	0	0	0	73.58	0	0	12.2
2014	7	15	17	47	0	32	0	0	0	0	0	0	0	73.56	0	0	12.2
2014	7	15	17	57	0	32	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	15	18	7	0	32	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	15	18	17	0	32	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	15	18	27	0	32	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	15	18	37	0	31	0	0	0	0	0	0	0	73.53	0	0	12
2014	7	15	18	47	0	32	0	0	0	0	0	0	0	73.54	0	0	12
2014	7	15	18	57	0	31	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	15	19	7	0	32	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	15	19	17	0	32	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	15	19	27	0	32	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	15	19	37	0	32	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	15	19	47	0	32	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	15	19	57	0	32	0	0	0	0	0	0	0	73.45	0	0	11.8
2014	7	15	20	7	0	31	0	0	0	0	0	0	0	73.44	0	0	11.8
2014	7	15	20	17	0	31	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	15	20	27	0	32	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	15	20	37	0	32	0	0	0	0	0	0	0	73.4	0	0	11.8
2014	7	15	20	47	0	32	0	0	0	0	0	0	0	73.38	0	0	11.8
2014	7	15	20	57	0	33	0	0	0	0	0	0	0	73.35	0	0	11.8
2014	7	15	21	7	0	32	0	0	0	0	0	0	0	73.31	0	0	11.4
2014	7	15	21	17	0	32	0	0	0	0	0	0	0	73.29	0	0	11.8
2014	7	15	21	27	0	32	0	0	0	0	0	0	0	73.27	0	0	11.8
2014	7	15	21	37	0	32	0	0	0	0	0	0	0	73.24	0	0	11.8
2014	7	15	21	47	0	32	0	0	0	0	0	0	0	73.2	0	0	11.8
2014	7	15	21	57	0	32	0	0	0	0	0	0	0	73.18	0	0	11.8
2014	7	15	22	7	0	31	0	0	0	0	0	0	0	73.15	0	0	11.8
2014	7	15	22	17	0	32	0	0	0	0	0	0	0	73.13	0	0	11.8
2014	7	15	22	27	0	32	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	15	22	37	0	32	0	0	0	0	0	0	0	73.08	0	0	11.8
2014	7	15	22	47	0	32	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	15	22	57	0	33	0	0	0	0	0	0	0	73	0	0	11.8
2014	7	15	23	7	0	32	0	0	0	0	0	0	0	72.97	0	0	11.8
2014	7	15	23	17	0	32	0	0	0	0	0	0	0	72.93	0	0	11.8
2014	7	15	23	27	0	32	0	0	0	0	0	0	0	72.91	0	0	11.8
2014	7	15	23	37	0	32	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	15	23	47	0	32	0	0	0	0	0	0	0	72.84	0	0	11.8
2014	7	15	23	57	0	32	0	0	0	0	0	0	0	72.81	0	0	11.8
2014	7	16	0	7	0	32	0	0	0	0	0	0	0	72.79	0	0	11.8
2014	7	16	0	17	0	33	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	16	0	27	0	32	0	0	0	0	0	0	0	72.72	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	0	37	0	32	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	16	0	47	0	32	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	16	0	57	0	32	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	16	1	7	0	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	16	1	17	0	32	0	0	0	0	0	0	0	72.55	0	0	11.8
2014	7	16	1	27	0	32	0	0	0	0	0	0	0	72.52	0	0	11.8
2014	7	16	1	37	0	32	0	0	0	0	0	0	0	72.46	0	0	11.8
2014	7	16	1	47	0	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	16	1	57	0	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	16	2	7	0	32	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	16	2	17	0	32	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	16	2	27	0	32	0	0	0	0	0	0	0	72.27	0	0	11.6
2014	7	16	2	37	0	31	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	16	2	47	0	32	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	16	2	57	0	32	0	0	0	0	0	0	0	72.14	0	0	11.6
2014	7	16	3	7	0	32	0	0	0	0	0	0	0	72.1	0	0	11.6
2014	7	16	3	17	0	32	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	16	3	27	0	32	0	0	0	0	0	0	0	72.01	0	0	11.6
2014	7	16	3	37	0	32	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	16	3	47	0	32	0	0	0	0	0	0	0	71.92	0	0	11.6
2014	7	16	3	57	0	31	0	0	0	0	0	0	0	71.89	0	0	11.6
2014	7	16	4	7	0	32	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	16	4	17	0	31	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	16	4	27	0	32	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	16	4	37	0	32	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	16	4	47	0	32	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	16	4	57	0	33	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	16	5	7	0	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	16	5	17	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	16	5	27	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	16	5	37	0	31	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	16	5	47	0	32	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	16	5	57	0	33	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	16	6	7	0	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	16	6	17	0	32	0	0	0	0	0	0	0	71.33	0	0	11.6
2014	7	16	6	27	0	33	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	16	6	37	0	32	0	0	0	0	0	0	0	71.26	0	0	11.6
2014	7	16	6	47	0	32	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	16	6	57	0	32	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	16	7	7	0	32	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	16	7	17	0	32	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	16	7	27	0	32	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	16	7	37	0	32	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	7	16	7	47	0	32	0	0	0	0	0	0	0	71.15	0	0	12.2
2014	7	16	7	57	0	33	0	0	0	0	0	0	0	71.15	0	0	12.4
2014	7	16	8	7	0	32	0	0	0	0	0	0	0	71.17	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	8	17	0	32	0	0	0	0	0	0	0	71.17	0	0	12.6
2014	7	16	8	27	0	32	0	0	0	0	0	0	0	71.19	0	0	12.8
2014	7	16	8	37	0	33	0	0	0	0	0	0	0	71.2	0	0	12.8
2014	7	16	8	47	0	33	0	0	0	0	0	0	0	71.24	0	0	12.8
2014	7	16	8	57	0	32	0	0	0	0	0	0	0	71.28	0	0	12.8
2014	7	16	9	7	0	32	0	0	0	0	0	0	0	71.29	0	0	12.8
2014	7	16	9	17	0	33	0	0	0	0	0	0	0	71.35	0	0	13
2014	7	16	9	27	0	32	0	0	0	0	0	0	0	71.38	0	0	13
2014	7	16	9	37	0	31	0	0	0	0	0	0	0	71.44	0	0	13
2014	7	16	9	47	0	33	0	0	0	0	0	0	0	71.49	0	0	13.2
2014	7	16	9	57	0	32	0	0	0	0	0	0	0	71.55	0	0	13.2
2014	7	16	10	7	0	32	0	0	0	0	0	0	0	71.6	0	0	13.2
2014	7	16	10	17	0	32	0	0	0	0	0	0	0	71.65	0	0	13.2
2014	7	16	10	27	0	33	0	0	0	0	0	0	0	71.73	0	0	13
2014	7	16	10	37	0	32	0	0	0	0	0	0	0	71.78	0	0	13
2014	7	16	10	47	0	32	0	0	0	0	0	0	0	71.85	0	0	13
2014	7	16	10	57	0	32	0	0	0	0	0	0	0	71.92	0	0	13
2014	7	16	11	7	0	32	0	0	0	0	0	0	0	72	0	0	13
2014	7	16	11	17	0	32	0	0	0	0	0	0	0	72.07	0	0	13
2014	7	16	11	27	0	31	0	0	0	0	0	0	0	72.16	0	0	13
2014	7	16	11	37	0	33	0	0	0	0	0	0	0	72.23	0	0	13
2014	7	16	11	47	0	33	0	0	0	0	0	0	0	72.32	0	0	13
2014	7	16	11	57	0	32	0	0	0	0	0	0	0	72.39	0	0	13
2014	7	16	12	7	0	32	0	0	0	0	0	0	0	72.48	0	0	13
2014	7	16	12	17	0	32	0	0	0	0	0	0	0	72.55	0	0	13
2014	7	16	12	27	0	32	0	0	0	0	0	0	0	72.64	0	0	13
2014	7	16	12	37	0	32	0	0	0	0	0	0	0	72.73	0	0	13
2014	7	16	12	47	0	32	0	0	0	0	0	0	0	72.82	0	0	13
2014	7	16	12	57	0	32	0	0	0	0	0	0	0	72.91	0	0	13
2014	7	16	13	7	0	32	0	0	0	0	0	0	0	72.99	0	0	13
2014	7	16	13	17	0	32	0	0	0	0	0	0	0	73.06	0	0	13.4
2014	7	16	13	27	0	32	0	0	0	0	0	0	0	73.15	0	0	13.4
2014	7	16	13	37	0	31	0	0	0	0	0	0	0	73.22	0	0	13.4
2014	7	16	13	47	0	32	0	0	0	0	0	0	0	73.29	0	0	13.4
2014	7	16	13	57	0	33	0	0	0	0	0	0	0	73.36	0	0	13.4
2014	7	16	14	7	0	32	0	0	0	0	0	0	0	73.36	0	0	13.4
2014	7	16	14	17	0	32	0	0	0	0	0	0	0	73.4	0	0	13.4
2014	7	16	14	27	0	32	0	0	0	0	0	0	0	73.47	0	0	13.4
2014	7	16	14	37	0	33	0	0	0	0	0	0	0	73.54	0	0	13.2
2014	7	16	14	47	0	32	0	0	0	0	0	0	0	73.6	0	0	13.2
2014	7	16	14	57	0	32	0	0	0	0	0	0	0	73.65	0	0	13.2
2014	7	16	15	7	0	32	0	0	0	0	0	0	0	73.67	0	0	13.2
2014	7	16	15	17	0	32	0	0	0	0	0	0	0	73.62	0	0	13
2014	7	16	15	27	0	32	0	0	0	0	0	0	0	73.58	0	0	13
2014	7	16	15	37	0	32	0	0	0	0	0	0	0	73.71	0	0	13.2
2014	7	16	15	47	0	32	0	0	0	0	0	0	0	73.72	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	15	57	0	32	0	0	0	0	0	0	0	73.69	0	0	13.2
2014	7	16	16	7	0	32	0	0	0	0	0	0	0	73.74	0	0	12.4
2014	7	16	16	17	0	31	0	0	0	0	0	0	0	73.78	0	0	12.6
2014	7	16	16	27	0	31	0	0	0	0	0	0	0	73.71	0	0	12.2
2014	7	16	16	37	0	31	0	0	0	0	0	0	0	73.78	0	0	13.2
2014	7	16	16	47	0	33	0	0	0	0	0	0	0	73.74	0	0	11.8
2014	7	16	16	57	0	31	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	16	17	7	0	32	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	16	17	17	0	32	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	16	17	27	0	32	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	16	17	37	0	32	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	16	17	47	0	32	0	0	0	0	0	0	0	73.71	0	0	12
2014	7	16	17	57	0	33	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	16	18	7	0	32	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	16	18	17	0	32	0	0	0	0	0	0	0	73.71	0	0	11.8
2014	7	16	18	27	0	32	0	0	0	0	0	0	0	73.69	0	0	11.8
2014	7	16	18	37	0	32	0	0	0	0	0	0	0	73.67	0	0	11.8
2014	7	16	18	47	0	32	0	0	0	0	0	0	0	73.67	0	0	11.8
2014	7	16	18	57	0	32	0	0	0	0	0	0	0	73.67	0	0	11.8
2014	7	16	19	7	0	32	0	0	0	0	0	0	0	73.67	0	0	11.8
2014	7	16	19	17	0	31	0	0	0	0	0	0	0	73.65	0	0	11.8
2014	7	16	19	27	0	33	0	0	0	0	0	0	0	73.65	0	0	11.8
2014	7	16	19	37	0	32	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	16	19	47	0	32	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	16	19	57	0	32	0	0	0	0	0	0	0	73.62	0	0	11.8
2014	7	16	20	7	0	31	0	0	0	0	0	0	0	73.6	0	0	11.8
2014	7	16	20	17	0	32	0	0	0	0	0	0	0	73.6	0	0	11.8
2014	7	16	20	27	0	32	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	16	20	37	0	32	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	16	20	47	0	32	0	0	0	0	0	0	0	73.56	0	0	11.8
2014	7	16	20	57	0	32	0	0	0	0	0	0	0	73.54	0	0	11.8
2014	7	16	21	7	0	31	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	16	21	17	0	31	0	0	0	0	0	0	0	73.49	0	0	11.8
2014	7	16	21	27	0	32	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	16	21	37	0	32	0	0	0	0	0	0	0	73.45	0	0	11.8
2014	7	16	21	47	0	32	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	16	21	57	0	31	0	0	0	0	0	0	0	73.4	0	0	11.8
2014	7	16	22	7	0	33	0	0	0	0	0	0	0	73.36	0	0	11.8
2014	7	16	22	17	0	32	0	0	0	0	0	0	0	73.35	0	0	11.8
2014	7	16	22	27	0	32	0	0	0	0	0	0	0	73.31	0	0	11.8
2014	7	16	22	37	0	32	0	0	0	0	0	0	0	73.27	0	0	11.8
2014	7	16	22	47	0	32	0	0	0	0	0	0	0	73.24	0	0	11.8
2014	7	16	22	57	0	32	0	0	0	0	0	0	0	73.2	0	0	11.8
2014	7	16	23	7	0	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	16	23	17	0	31	0	0	0	0	0	0	0	73.13	0	0	11.8
2014	7	16	23	27	0	32	0	0	0	0	0	0	0	73.09	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	16	23	37	0	31	0	0	0	0	0	0	0	73.04	0	0	11.8
2014	7	16	23	47	0	32	0	0	0	0	0	0	0	73.02	0	0	11.8
2014	7	16	23	57	0	31	0	0	0	0	0	0	0	72.97	0	0	11.8
2014	7	17	0	7	0	32	0	0	0	0	0	0	0	72.93	0	0	11.8
2014	7	17	0	17	0	31	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	17	0	27	0	33	0	0	0	0	0	0	0	72.84	0	0	11.8
2014	7	17	0	37	0	32	0	0	0	0	0	0	0	72.79	0	0	11.8
2014	7	17	0	47	0	31	0	0	0	0	0	0	0	72.73	0	0	11.8
2014	7	17	0	57	0	32	0	0	0	0	0	0	0	72.7	0	0	11.8
2014	7	17	1	7	0	32	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	17	1	17	0	32	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	17	1	27	0	32	0	0	0	0	0	0	0	72.55	0	0	11.6
2014	7	17	1	37	0	31	0	0	0	0	0	0	0	72.52	0	0	11.6
2014	7	17	1	47	0	32	0	0	0	0	0	0	0	72.48	0	0	11.6
2014	7	17	1	57	0	32	0	0	0	0	0	0	0	72.43	0	0	11.6
2014	7	17	2	7	0	32	0	0	0	0	0	0	0	72.37	0	0	11.6
2014	7	17	2	17	0	33	0	0	0	0	0	0	0	72.32	0	0	11.6
2014	7	17	2	27	0	31	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	17	2	37	0	32	0	0	0	0	0	0	0	72.23	0	0	11.6
2014	7	17	2	47	0	33	0	0	0	0	0	0	0	72.19	0	0	11.6
2014	7	17	2	57	0	32	0	0	0	0	0	0	0	72.14	0	0	11.6
2014	7	17	3	7	0	32	0	0	0	0	0	0	0	72.09	0	0	11.6
2014	7	17	3	17	0	32	0	0	0	0	0	0	0	72.05	0	0	11.6
2014	7	17	3	27	0	32	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	17	3	37	0	32	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	17	3	47	0	32	0	0	0	0	0	0	0	71.89	0	0	11.6
2014	7	17	3	57	0	32	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	17	4	7	0	32	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	17	4	17	0	32	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	17	4	27	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	17	4	37	0	31	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	17	4	47	0	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	17	4	57	0	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	17	5	7	0	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	17	5	17	0	33	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	17	5	27	0	32	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	17	5	37	0	32	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	17	5	47	0	31	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	17	5	57	0	33	0	0	0	0	0	0	0	71.31	0	0	11.6
2014	7	17	6	7	0	32	0	0	0	0	0	0	0	71.28	0	0	11.6
2014	7	17	6	17	0	32	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	17	6	27	0	33	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	17	6	37	0	32	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	17	6	47	0	32	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	17	6	57	0	32	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	17	7	7	0	32	0	0	0	0	0	0	0	71.08	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	7	17	0	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	17	7	27	0	32	0	0	0	0	0	0	0	71.02	0	0	12
2014	7	17	7	37	0	32	0	0	0	0	0	0	0	71.02	0	0	12.2
2014	7	17	7	47	0	32	0	0	0	0	0	0	0	71.02	0	0	12.2
2014	7	17	7	57	0	32	0	0	0	0	0	0	0	71.02	0	0	12.4
2014	7	17	8	7	0	32	0	0	0	0	0	0	0	71.02	0	0	12.6
2014	7	17	8	17	0	32	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	17	8	27	0	33	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	17	8	37	0	32	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	17	8	47	0	32	0	0	0	0	0	0	0	71.1	0	0	13
2014	7	17	8	57	0	33	0	0	0	0	0	0	0	71.13	0	0	13
2014	7	17	9	7	0	32	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	17	9	17	0	33	0	0	0	0	0	0	0	71.2	0	0	13
2014	7	17	9	27	0	32	0	0	0	0	0	0	0	71.24	0	0	13
2014	7	17	9	37	0	33	0	0	0	0	0	0	0	71.28	0	0	13.2
2014	7	17	9	47	0	33	0	0	0	0	0	0	0	71.33	0	0	13.2
2014	7	17	9	57	0	33	0	0	0	0	0	0	0	71.38	0	0	13.2
2014	7	17	10	7	0	32	0	0	0	0	0	0	0	71.44	0	0	13
2014	7	17	10	17	0	32	0	0	0	0	0	0	0	71.49	0	0	13
2014	7	17	10	27	0	32	0	0	0	0	0	0	0	71.56	0	0	13
2014	7	17	10	37	0	32	0	0	0	0	0	0	0	71.64	0	0	13
2014	7	17	10	47	0	32	0	0	0	0	0	0	0	71.69	0	0	13
2014	7	17	10	57	0	32	0	0	0	0	0	0	0	71.76	0	0	13.4
2014	7	17	11	7	0	32	0	0	0	0	0	0	0	71.83	0	0	13.4
2014	7	17	11	17	0	32	0	0	0	0	0	0	0	71.91	0	0	13.4
2014	7	17	11	27	0	32	0	0	0	0	0	0	0	71.98	0	0	13.4
2014	7	17	11	37	0	32	0	0	0	0	0	0	0	72.05	0	0	13.4
2014	7	17	11	47	0	32	0	0	0	0	0	0	0	72.16	0	0	13.4
2014	7	17	11	57	0	32	0	0	0	0	0	0	0	72.23	0	0	13.4
2014	7	17	12	7	0	32	0	0	0	0	0	0	0	72.3	0	0	13.4
2014	7	17	12	17	0	32	0	0	0	0	0	0	0	72.39	0	0	13
2014	7	17	12	27	0	32	0	0	0	0	0	0	0	72.5	0	0	13.2
2014	7	17	12	37	0	32	0	0	0	0	0	0	0	72.57	0	0	13.4
2014	7	17	12	47	0	32	0	0	0	0	0	0	0	72.66	0	0	13.4
2014	7	17	12	57	0	32	0	0	0	0	0	0	0	72.75	0	0	13.4
2014	7	17	13	7	0	32	0	0	0	0	0	0	0	72.84	0	0	13.4
2014	7	17	13	17	0	31	0	0	0	0	0	0	0	72.95	0	0	13.4
2014	7	17	13	27	0	33	0	0	0	0	0	0	0	72.99	0	0	13.2
2014	7	17	13	37	0	31	0	0	0	0	0	0	0	73.08	0	0	13.2
2014	7	17	13	47	0	32	0	0	0	0	0	0	0	73.15	0	0	13.2
2014	7	17	13	57	0	32	0	0	0	0	0	0	0	73.2	0	0	13.2
2014	7	17	14	7	0	32	0	0	0	0	0	0	0	73.27	0	0	13.2
2014	7	17	14	17	0	32	0	0	0	0	0	0	0	73.36	0	0	13
2014	7	17	14	27	0	32	0	0	0	0	0	0	0	73.42	0	0	13.2
2014	7	17	14	37	0	32	0	0	0	0	0	0	0	73.49	0	0	13.2
2014	7	17	14	47	0	32	0	0	0	0	0	0	0	73.53	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	14	57	0	31	0	0	0	0	0	0	0	73.58	0	0	13
2014	7	17	15	7	0	32	0	0	0	0	0	0	0	73.63	0	0	13.2
2014	7	17	15	17	0	31	0	0	0	0	0	0	0	73.65	0	0	13.2
2014	7	17	15	27	0	32	0	0	0	0	0	0	0	73.69	0	0	13.2
2014	7	17	15	37	0	32	0	0	0	0	0	0	0	73.71	0	0	13.2
2014	7	17	15	47	0	31	0	0	0	0	0	0	0	73.72	0	0	13.2
2014	7	17	15	57	0	32	0	0	0	0	0	0	0	73.74	0	0	13.2
2014	7	17	16	7	0	32	0	0	0	0	0	0	0	73.76	0	0	13.2
2014	7	17	16	17	0	32	0	0	0	0	0	0	0	73.76	0	0	13
2014	7	17	16	27	0	32	0	0	0	0	0	0	0	73.76	0	0	13
2014	7	17	16	37	0	32	0	0	0	0	0	0	0	73.78	0	0	13
2014	7	17	16	47	0	31	0	0	0	0	0	0	0	73.78	0	0	13
2014	7	17	16	57	0	32	0	0	0	0	0	0	0	73.78	0	0	12.6
2014	7	17	17	7	0	31	0	0	0	0	0	0	0	73.78	0	0	12.6
2014	7	17	17	17	0	32	0	0	0	0	0	0	0	73.76	0	0	12.4
2014	7	17	17	27	0	31	0	0	0	0	0	0	0	73.74	0	0	12.4
2014	7	17	17	37	0	31	0	0	0	0	0	0	0	73.72	0	0	12.2
2014	7	17	17	47	0	31	0	0	0	0	0	0	0	73.71	0	0	12.2
2014	7	17	17	57	0	31	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	17	18	7	0	32	0	0	0	0	0	0	0	73.69	0	0	12
2014	7	17	18	17	0	31	0	0	0	0	0	0	0	73.67	0	0	12
2014	7	17	18	27	0	32	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	17	18	37	0	32	0	0	0	0	0	0	0	73.65	0	0	12
2014	7	17	18	47	0	32	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	17	18	57	0	32	0	0	0	0	0	0	0	73.63	0	0	12
2014	7	17	19	7	0	32	0	0	0	0	0	0	0	73.63	0	0	11.8
2014	7	17	19	17	0	32	0	0	0	0	0	0	0	73.62	0	0	11.8
2014	7	17	19	27	0	32	0	0	0	0	0	0	0	73.6	0	0	11.8
2014	7	17	19	37	0	32	0	0	0	0	0	0	0	73.58	0	0	11.8
2014	7	17	19	47	0	32	0	0	0	0	0	0	0	73.54	0	0	11.8
2014	7	17	19	57	0	32	0	0	0	0	0	0	0	73.53	0	0	11.8
2014	7	17	20	7	0	32	0	0	0	0	0	0	0	73.51	0	0	11.8
2014	7	17	20	17	0	32	0	0	0	0	0	0	0	73.47	0	0	11.8
2014	7	17	20	27	0	32	0	0	0	0	0	0	0	73.45	0	0	11.8
2014	7	17	20	37	0	32	0	0	0	0	0	0	0	73.44	0	0	11.8
2014	7	17	20	47	0	31	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	17	20	57	0	32	0	0	0	0	0	0	0	73.38	0	0	11.8
2014	7	17	21	7	0	32	0	0	0	0	0	0	0	73.36	0	0	11.8
2014	7	17	21	17	0	32	0	0	0	0	0	0	0	73.35	0	0	11.8
2014	7	17	21	27	0	33	0	0	0	0	0	0	0	73.33	0	0	11.8
2014	7	17	21	37	0	32	0	0	0	0	0	0	0	73.31	0	0	11.8
2014	7	17	21	47	0	32	0	0	0	0	0	0	0	73.27	0	0	11.8
2014	7	17	21	57	0	32	0	0	0	0	0	0	0	73.24	0	0	11.8
2014	7	17	22	7	0	33	0	0	0	0	0	0	0	73.2	0	0	11.8
2014	7	17	22	17	0	32	0	0	0	0	0	0	0	73.17	0	0	11.8
2014	7	17	22	27	0	32	0	0	0	0	0	0	0	73.15	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	17	22	37	0	31	0	0	0	0	0	0	0	73.09	0	0	11.8
2014	7	17	22	47	0	32	0	0	0	0	0	0	0	73.06	0	0	11.8
2014	7	17	22	57	0	32	0	0	0	0	0	0	0	73	0	0	11.8
2014	7	17	23	7	0	32	0	0	0	0	0	0	0	72.97	0	0	11.8
2014	7	17	23	17	0	33	0	0	0	0	0	0	0	72.93	0	0	11.8
2014	7	17	23	27	0	32	0	0	0	0	0	0	0	72.9	0	0	11.8
2014	7	17	23	37	0	31	0	0	0	0	0	0	0	72.86	0	0	11.8
2014	7	17	23	47	0	31	0	0	0	0	0	0	0	72.82	0	0	11.8
2014	7	17	23	57	0	32	0	0	0	0	0	0	0	72.77	0	0	11.8
2014	7	18	0	7	0	32	0	0	0	0	0	0	0	72.73	0	0	11.8
2014	7	18	0	17	0	31	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	18	0	27	0	32	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	18	0	37	0	33	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	18	0	47	0	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	18	0	57	0	32	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	18	1	7	0	32	0	0	0	0	0	0	0	72.48	0	0	11.8
2014	7	18	1	17	0	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	18	1	27	0	31	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	18	1	37	0	33	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	18	1	47	0	31	0	0	0	0	0	0	0	72.32	0	0	11.8
2014	7	18	1	57	0	32	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	18	2	7	0	32	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	18	2	17	0	33	0	0	0	0	0	0	0	72.21	0	0	11.8
2014	7	18	2	27	0	33	0	0	0	0	0	0	0	72.16	0	0	11.6
2014	7	18	2	37	0	31	0	0	0	0	0	0	0	72.12	0	0	11.6
2014	7	18	2	47	0	31	0	0	0	0	0	0	0	72.09	0	0	11.6
2014	7	18	2	57	0	32	0	0	0	0	0	0	0	72.03	0	0	11.6
2014	7	18	3	7	0	32	0	0	0	0	0	0	0	72	0	0	11.6
2014	7	18	3	17	0	32	0	0	0	0	0	0	0	71.96	0	0	11.6
2014	7	18	3	27	0	32	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	18	3	37	0	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	18	3	47	0	32	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	18	3	57	0	32	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	18	4	7	0	32	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	18	4	17	0	32	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	18	4	27	0	32	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	18	4	37	0	32	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	18	4	47	0	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	18	4	57	0	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	18	5	7	0	32	0	0	0	0	0	0	0	71.44	0	0	11.6
2014	7	18	5	17	0	33	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	18	5	27	0	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	18	5	37	0	32	0	0	0	0	0	0	0	71.29	0	0	11.6
2014	7	18	5	47	0	32	0	0	0	0	0	0	0	71.24	0	0	11.6
2014	7	18	5	57	0	33	0	0	0	0	0	0	0	71.2	0	0	11.6
2014	7	18	6	7	0	33	0	0	0	0	0	0	0	71.15	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	6	17	0	33	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	18	6	27	0	33	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	18	6	37	0	31	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	18	6	47	0	32	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	18	6	57	0	32	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	18	7	7	0	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	18	7	17	0	32	0	0	0	0	0	0	0	70.88	0	0	12
2014	7	18	7	27	0	32	0	0	0	0	0	0	0	70.86	0	0	12
2014	7	18	7	37	0	33	0	0	0	0	0	0	0	70.86	0	0	12.2
2014	7	18	7	47	0	31	0	0	0	0	0	0	0	70.84	0	0	12.2
2014	7	18	7	57	0	33	0	0	0	0	0	0	0	70.84	0	0	12.4
2014	7	18	8	7	0	32	0	0	0	0	0	0	0	70.86	0	0	12.4
2014	7	18	8	17	0	32	0	0	0	0	0	0	0	70.86	0	0	12.6
2014	7	18	8	27	0	32	0	0	0	0	0	0	0	70.88	0	0	12.6
2014	7	18	8	37	0	32	0	0	0	0	0	0	0	70.9	0	0	13.6
2014	7	18	8	47	0	32	0	0	0	0	0	0	0	70.92	0	0	13.8
2014	7	18	8	57	0	32	0	0	0	0	0	0	0	70.95	0	0	13.6
2014	7	18	9	7	0	32	0	0	0	0	0	0	0	70.97	0	0	13.8
2014	7	18	9	17	0	32	0	0	0	0	0	0	0	71.02	0	0	13
2014	7	18	9	27	0	32	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	18	9	37	0	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	18	9	47	0	32	0	0	0	0	0	0	0	71.17	0	0	13.4
2014	7	18	9	57	0	32	0	0	0	0	0	0	0	71.22	0	0	13.4
2014	7	18	10	7	0	32	0	0	0	0	0	0	0	71.28	0	0	13.4
2014	7	18	10	17	0	32	0	0	0	0	0	0	0	71.35	0	0	13.4
2014	7	18	10	27	0	32	0	0	0	0	0	0	0	71.42	0	0	13.4
2014	7	18	10	37	0	32	0	0	0	0	0	0	0	71.47	0	0	13.4
2014	7	18	10	47	0	33	0	0	0	0	0	0	0	71.56	0	0	13.4
2014	7	18	10	57	0	33	0	0	0	0	0	0	0	71.62	0	0	13.4
2014	7	18	11	7	0	32	0	0	0	0	0	0	0	71.71	0	0	13.4
2014	7	18	11	17	0	32	0	0	0	0	0	0	0	71.76	0	0	13.4
2014	7	18	11	27	0	33	0	0	0	0	0	0	0	71.85	0	0	13.4
2014	7	18	11	37	0	32	0	0	0	0	0	0	0	71.94	0	0	13.4
2014	7	18	11	47	0	32	0	0	0	0	0	0	0	72.03	0	0	13.4
2014	7	18	11	57	0	33	0	0	0	0	0	0	0	72.09	0	0	13.4
2014	7	18	12	7	0	32	0	0	0	0	0	0	0	72.19	0	0	13.4
2014	7	18	12	17	0	31	0	0	0	0	0	0	0	72.28	0	0	13.4
2014	7	18	12	27	0	32	0	0	0	0	0	0	0	72.36	0	0	13.4
2014	7	18	12	37	0	31	0	0	0	0	0	0	0	72.43	0	0	13.4
2014	7	18	12	47	0	32	0	0	0	0	0	0	0	72.52	0	0	13.4
2014	7	18	12	57	0	32	0	0	0	0	0	0	0	72.61	0	0	13.4
2014	7	18	13	7	0	32	0	0	0	0	0	0	0	72.68	0	0	13.4
2014	7	18	13	17	0	32	0	0	0	0	0	0	0	72.77	0	0	13.6
2014	7	18	13	27	0	32	0	0	0	0	0	0	0	72.84	0	0	13.6
2014	7	18	13	37	0	31	0	0	0	0	0	0	0	72.91	0	0	13.6
2014	7	18	13	47	0	32	0	0	0	0	0	0	0	72.99	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	13	57	0	32	0	0	0	0	0	0	0	73.06	0	0	13.4
2014	7	18	14	7	0	32	0	0	0	0	0	0	0	73.11	0	0	13.4
2014	7	18	14	17	0	32	0	0	0	0	0	0	0	73.17	0	0	13.4
2014	7	18	14	27	0	32	0	0	0	0	0	0	0	73.22	0	0	13.4
2014	7	18	14	37	0	32	0	0	0	0	0	0	0	73.27	0	0	13.4
2014	7	18	14	47	0	32	0	0	0	0	0	0	0	73.33	0	0	13.4
2014	7	18	14	57	0	32	0	0	0	0	0	0	0	73.36	0	0	13.4
2014	7	18	15	7	0	33	0	0	0	0	0	0	0	73.4	0	0	13.4
2014	7	18	15	17	0	32	0	0	0	0	0	0	0	73.44	0	0	13.4
2014	7	18	15	27	0	32	0	0	0	0	0	0	0	73.47	0	0	13.4
2014	7	18	15	37	0	32	0	0	0	0	0	0	0	73.49	0	0	13.4
2014	7	18	15	47	0	32	0	0	0	0	0	0	0	73.51	0	0	13.2
2014	7	18	15	57	0	31	0	0	0	0	0	0	0	73.53	0	0	13.2
2014	7	18	16	7	0	32	0	0	0	0	0	0	0	73.53	0	0	13.2
2014	7	18	16	17	0	32	0	0	0	0	0	0	0	73.54	0	0	13.2
2014	7	18	16	27	0	33	0	0	0	0	0	0	0	73.54	0	0	13.2
2014	7	18	16	37	0	32	0	0	0	0	0	0	0	73.53	0	0	13.2
2014	7	18	16	47	0	32	0	0	0	0	0	0	0	73.51	0	0	13
2014	7	18	16	57	0	32	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	18	17	7	0	32	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	18	17	17	0	32	0	0	0	0	0	0	0	73.51	0	0	12.6
2014	7	18	17	27	0	32	0	0	0	0	0	0	0	73.49	0	0	12.8
2014	7	18	17	37	0	31	0	0	0	0	0	0	0	73.47	0	0	12.4
2014	7	18	17	47	0	32	0	0	0	0	0	0	0	73.47	0	0	12.2
2014	7	18	17	57	0	32	0	0	0	0	0	0	0	73.44	0	0	12
2014	7	18	18	7	0	32	0	0	0	0	0	0	0	73.42	0	0	11.8
2014	7	18	18	17	0	32	0	0	0	0	0	0	0	73.42	0	0	11.6
2014	7	18	18	27	0	31	0	0	0	0	0	0	0	73.4	0	0	11.6
2014	7	18	18	37	0	32	0	0	0	0	0	0	0	73.4	0	0	11.6
2014	7	18	18	47	0	32	0	0	0	0	0	0	0	73.38	0	0	11.4
2014	7	18	18	57	0	32	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	18	19	7	0	32	0	0	0	0	0	0	0	73.36	0	0	11.4
2014	7	18	19	17	0	32	0	0	0	0	0	0	0	73.35	0	0	11.4
2014	7	18	19	27	0	32	0	0	0	0	0	0	0	73.33	0	0	11.4
2014	7	18	19	37	0	32	0	0	0	0	0	0	0	73.31	0	0	11.2
2014	7	18	19	47	0	31	0	0	0	0	0	0	0	73.29	0	0	11.2
2014	7	18	19	57	0	32	0	0	0	0	0	0	0	73.29	0	0	11.2
2014	7	18	20	7	0	32	0	0	0	0	0	0	0	73.27	0	0	11.4
2014	7	18	20	17	0	31	0	0	0	0	0	0	0	73.24	0	0	11.2
2014	7	18	20	27	0	32	0	0	0	0	0	0	0	73.22	0	0	11.2
2014	7	18	20	37	0	33	0	0	0	0	0	0	0	73.18	0	0	11.2
2014	7	18	20	47	0	32	0	0	0	0	0	0	0	73.17	0	0	11
2014	7	18	20	57	0	32	0	0	0	0	0	0	0	73.13	0	0	11
2014	7	18	21	7	0	32	0	0	0	0	0	0	0	73.11	0	0	11
2014	7	18	21	17	0	32	0	0	0	0	0	0	0	73.08	0	0	11.2
2014	7	18	21	27	0	32	0	0	0	0	0	0	0	73.06	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	18	21	37	0	32	0	0	0	0	0	0	0	73.02	0	0	11.2
2014	7	18	21	47	0	32	0	0	0	0	0	0	0	72.99	0	0	11.2
2014	7	18	21	57	0	32	0	0	0	0	0	0	0	72.95	0	0	11.2
2014	7	18	22	7	0	32	0	0	0	0	0	0	0	72.93	0	0	11.2
2014	7	18	22	17	0	32	0	0	0	0	0	0	0	72.9	0	0	11.8
2014	7	18	22	27	0	32	0	0	0	0	0	0	0	72.88	0	0	11.8
2014	7	18	22	37	0	32	0	0	0	0	0	0	0	72.84	0	0	11.8
2014	7	18	22	47	0	32	0	0	0	0	0	0	0	72.79	0	0	11.8
2014	7	18	22	57	0	32	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	18	23	7	0	32	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	18	23	17	0	32	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	18	23	27	0	32	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	18	23	37	0	33	0	0	0	0	0	0	0	72.61	0	0	11.8
2014	7	18	23	47	0	33	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	18	23	57	0	32	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	19	0	7	0	31	0	0	0	0	0	0	0	72.48	0	0	11.8
2014	7	19	0	17	0	32	0	0	0	0	0	0	0	72.43	0	0	11.8
2014	7	19	0	27	0	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	19	0	37	0	31	0	0	0	0	0	0	0	72.36	0	0	11.8
2014	7	19	0	47	0	32	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	19	0	57	0	32	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	19	1	7	0	32	0	0	0	0	0	0	0	72.21	0	0	11.8
2014	7	19	1	17	0	31	0	0	0	0	0	0	0	72.16	0	0	11.8
2014	7	19	1	27	0	32	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	19	1	37	0	32	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	19	1	47	0	31	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	19	1	57	0	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	19	2	7	0	31	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	19	2	17	0	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	19	2	27	0	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	19	2	37	0	32	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	19	2	47	0	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	19	2	57	0	33	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	19	3	7	0	32	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	19	3	17	0	32	0	0	0	0	0	0	0	71.65	0	0	11.8
2014	7	19	3	27	0	32	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	19	3	37	0	32	0	0	0	0	0	0	0	71.55	0	0	11.8
2014	7	19	3	47	0	33	0	0	0	0	0	0	0	71.51	0	0	11.8
2014	7	19	3	57	0	32	0	0	0	0	0	0	0	71.46	0	0	11.8
2014	7	19	4	7	0	32	0	0	0	0	0	0	0	71.42	0	0	11.8
2014	7	19	4	17	0	31	0	0	0	0	0	0	0	71.38	0	0	11.8
2014	7	19	4	27	0	32	0	0	0	0	0	0	0	71.35	0	0	11.8
2014	7	19	4	37	0	32	0	0	0	0	0	0	0	71.31	0	0	11.8
2014	7	19	4	47	0	32	0	0	0	0	0	0	0	71.26	0	0	11.8
2014	7	19	4	57	0	32	0	0	0	0	0	0	0	71.22	0	0	11.6
2014	7	19	5	7	0	33	0	0	0	0	0	0	0	71.19	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	5	17	0	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	19	5	27	0	32	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	19	5	37	0	32	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	19	5	47	0	33	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	19	5	57	0	33	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	19	6	7	0	33	0	0	0	0	0	0	0	70.93	0	0	11.8
2014	7	19	6	17	0	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	19	6	27	0	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	19	6	37	0	32	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	19	6	47	0	32	0	0	0	0	0	0	0	70.83	0	0	11.8
2014	7	19	6	57	0	33	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	19	7	7	0	33	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	19	7	17	0	32	0	0	0	0	0	0	0	70.77	0	0	12
2014	7	19	7	27	0	32	0	0	0	0	0	0	0	70.79	0	0	12
2014	7	19	7	37	0	32	0	0	0	0	0	0	0	70.77	0	0	12.2
2014	7	19	7	47	0	32	0	0	0	0	0	0	0	70.79	0	0	12.2
2014	7	19	7	57	0	32	0	0	0	0	0	0	0	70.79	0	0	12.4
2014	7	19	8	7	0	33	0	0	0	0	0	0	0	70.79	0	0	12.4
2014	7	19	8	17	0	32	0	0	0	0	0	0	0	70.79	0	0	12.4
2014	7	19	8	27	0	32	0	0	0	0	0	0	0	70.83	0	0	12.4
2014	7	19	8	37	0	32	0	0	0	0	0	0	0	70.84	0	0	12.6
2014	7	19	8	47	0	32	0	0	0	0	0	0	0	70.86	0	0	12.6
2014	7	19	8	57	0	32	0	0	0	0	0	0	0	70.9	0	0	12.6
2014	7	19	9	7	0	32	0	0	0	0	0	0	0	70.93	0	0	12.6
2014	7	19	9	17	0	32	0	0	0	0	0	0	0	70.99	0	0	12.6
2014	7	19	9	27	0	32	0	0	0	0	0	0	0	71.02	0	0	12.8
2014	7	19	9	37	0	33	0	0	0	0	0	0	0	71.06	0	0	12.8
2014	7	19	9	47	0	32	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	19	9	57	0	32	0	0	0	0	0	0	0	71.17	0	0	13
2014	7	19	10	7	0	32	0	0	0	0	0	0	0	71.22	0	0	13
2014	7	19	10	17	0	32	0	0	0	0	0	0	0	71.29	0	0	13.2
2014	7	19	10	27	0	32	0	0	0	0	0	0	0	71.35	0	0	13.2
2014	7	19	10	37	0	32	0	0	0	0	0	0	0	71.42	0	0	13.2
2014	7	19	10	47	0	32	0	0	0	0	0	0	0	71.47	0	0	13.2
2014	7	19	10	57	0	32	0	0	0	0	0	0	0	71.55	0	0	13.2
2014	7	19	11	7	0	32	0	0	0	0	0	0	0	71.64	0	0	13.2
2014	7	19	11	17	0	33	0	0	0	0	0	0	0	71.69	0	0	13.2
2014	7	19	11	27	0	32	0	0	0	0	0	0	0	71.69	0	0	13.6
2014	7	19	11	37	0	32	0	0	0	0	0	0	0	71.67	0	0	13.6
2014	7	19	11	47	0	33	0	0	0	0	0	0	0	71.76	0	0	14
2014	7	19	11	57	0	32	0	0	0	0	0	0	0	71.73	0	0	13.6
2014	7	19	12	7	0	32	0	0	0	0	0	0	0	71.73	0	0	13.6
2014	7	19	12	17	0	31	0	0	0	0	0	0	0	71.98	0	0	14
2014	7	19	12	27	0	32	0	0	0	0	0	0	0	71.96	0	0	13.8
2014	7	19	12	37	0	32	0	0	0	0	0	0	0	71.98	0	0	13.6
2014	7	19	12	47	0	32	0	0	0	0	0	0	0	72.12	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	12	57	0	32	0	0	0	0	0	0	0	72.21	0	0	14
2014	7	19	13	7	0	32	0	0	0	0	0	0	0	72.34	0	0	13.6
2014	7	19	13	17	0	33	0	0	0	0	0	0	0	72.34	0	0	13
2014	7	19	13	27	0	32	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	19	13	37	0	32	0	0	0	0	0	0	0	72.45	0	0	13.2
2014	7	19	13	47	0	32	0	0	0	0	0	0	0	72.45	0	0	12.8
2014	7	19	13	57	0	33	0	0	0	0	0	0	0	72.59	0	0	13.2
2014	7	19	14	7	0	32	0	0	0	0	0	0	0	72.63	0	0	12.8
2014	7	19	14	17	0	32	0	0	0	0	0	0	0	72.59	0	0	13
2014	7	19	14	27	0	32	0	0	0	0	0	0	0	72.68	0	0	13
2014	7	19	14	37	0	33	0	0	0	0	0	0	0	72.68	0	0	13.4
2014	7	19	14	47	0	32	0	0	0	0	0	0	0	72.68	0	0	13.6
2014	7	19	14	57	0	32	0	0	0	0	0	0	0	72.77	0	0	13.4
2014	7	19	15	7	0	31	0	0	0	0	0	0	0	72.88	0	0	13.4
2014	7	19	15	17	0	32	0	0	0	0	0	0	0	72.95	0	0	13.4
2014	7	19	15	27	0	32	0	0	0	0	0	0	0	72.91	0	0	13.2
2014	7	19	15	37	0	32	0	0	0	0	0	0	0	72.86	0	0	13
2014	7	19	15	47	0	32	0	0	0	0	0	0	0	72.9	0	0	13.2
2014	7	19	15	57	0	32	0	0	0	0	0	0	0	72.84	0	0	13.4
2014	7	19	16	7	0	32	0	0	0	0	0	0	0	72.97	0	0	13.8
2014	7	19	16	17	0	31	0	0	0	0	0	0	0	73.02	0	0	13
2014	7	19	16	27	0	32	0	0	0	0	0	0	0	73.02	0	0	13
2014	7	19	16	37	0	32	0	0	0	0	0	0	0	72.97	0	0	12.6
2014	7	19	16	47	0	32	0	0	0	0	0	0	0	72.95	0	0	12.6
2014	7	19	16	57	0	32	0	0	0	0	0	0	0	72.95	0	0	12.6
2014	7	19	17	7	0	32	0	0	0	0	0	0	0	72.97	0	0	13
2014	7	19	17	17	0	31	0	0	0	0	0	0	0	72.97	0	0	12.8
2014	7	19	17	27	0	32	0	0	0	0	0	0	0	72.95	0	0	12.6
2014	7	19	17	37	0	32	0	0	0	0	0	0	0	72.95	0	0	12.6
2014	7	19	17	47	0	32	0	0	0	0	0	0	0	72.91	0	0	12.4
2014	7	19	17	57	0	32	0	0	0	0	0	0	0	72.9	0	0	12.2
2014	7	19	18	7	0	32	0	0	0	0	0	0	0	72.88	0	0	12.2
2014	7	19	18	17	0	32	0	0	0	0	0	0	0	72.84	0	0	12
2014	7	19	18	27	0	31	0	0	0	0	0	0	0	72.84	0	0	12
2014	7	19	18	37	0	32	0	0	0	0	0	0	0	72.82	0	0	12
2014	7	19	18	47	0	32	0	0	0	0	0	0	0	72.81	0	0	12
2014	7	19	18	57	0	32	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	19	19	7	0	32	0	0	0	0	0	0	0	72.77	0	0	12
2014	7	19	19	17	0	31	0	0	0	0	0	0	0	72.75	0	0	11.8
2014	7	19	19	27	0	32	0	0	0	0	0	0	0	72.73	0	0	11.8
2014	7	19	19	37	0	32	0	0	0	0	0	0	0	72.72	0	0	11.8
2014	7	19	19	47	0	31	0	0	0	0	0	0	0	72.68	0	0	11.8
2014	7	19	19	57	0	33	0	0	0	0	0	0	0	72.66	0	0	11.8
2014	7	19	20	7	0	31	0	0	0	0	0	0	0	72.64	0	0	11.8
2014	7	19	20	17	0	32	0	0	0	0	0	0	0	72.63	0	0	11.8
2014	7	19	20	27	0	32	0	0	0	0	0	0	0	72.61	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	19	20	37	0	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	19	20	47	0	32	0	0	0	0	0	0	0	72.57	0	0	11.8
2014	7	19	20	57	0	32	0	0	0	0	0	0	0	72.54	0	0	11.8
2014	7	19	21	7	0	32	0	0	0	0	0	0	0	72.5	0	0	11.8
2014	7	19	21	17	0	32	0	0	0	0	0	0	0	72.5	0	0	11.8
2014	7	19	21	27	0	32	0	0	0	0	0	0	0	72.46	0	0	11.8
2014	7	19	21	37	0	32	0	0	0	0	0	0	0	72.45	0	0	11.8
2014	7	19	21	47	0	32	0	0	0	0	0	0	0	72.41	0	0	11.8
2014	7	19	21	57	0	32	0	0	0	0	0	0	0	72.39	0	0	11.8
2014	7	19	22	7	0	32	0	0	0	0	0	0	0	72.37	0	0	11.8
2014	7	19	22	17	0	32	0	0	0	0	0	0	0	72.34	0	0	11.8
2014	7	19	22	27	0	32	0	0	0	0	0	0	0	72.34	0	0	11.8
2014	7	19	22	37	0	32	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	19	22	47	0	32	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	19	22	57	0	32	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	19	23	7	0	32	0	0	0	0	0	0	0	72.23	0	0	11.8
2014	7	19	23	17	0	32	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	19	23	27	0	32	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	19	23	37	0	32	0	0	0	0	0	0	0	72.14	0	0	11.8
2014	7	19	23	47	0	32	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	19	23	57	0	32	0	0	0	0	0	0	0	72.07	0	0	11.8
2014	7	20	0	7	0	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	20	0	17	0	32	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	20	0	27	0	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	20	0	37	0	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	20	0	47	0	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	20	0	57	0	31	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	20	1	7	0	32	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	20	1	17	0	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	20	1	27	0	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	20	1	37	0	33	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	20	1	47	0	33	0	0	0	0	0	0	0	71.69	0	0	11.8
2014	7	20	1	57	0	32	0	0	0	0	0	0	0	71.65	0	0	11.8
2014	7	20	2	7	0	32	0	0	0	0	0	0	0	71.62	0	0	11.8
2014	7	20	2	17	0	32	0	0	0	0	0	0	0	71.58	0	0	11.8
2014	7	20	2	27	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	20	2	37	0	32	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	20	2	47	0	32	0	0	0	0	0	0	0	71.46	0	0	11.8
2014	7	20	2	57	0	32	0	0	0	0	0	0	0	71.42	0	0	11.8
2014	7	20	3	7	0	31	0	0	0	0	0	0	0	71.37	0	0	11.8
2014	7	20	3	17	0	32	0	0	0	0	0	0	0	71.31	0	0	11.8
2014	7	20	3	27	0	32	0	0	0	0	0	0	0	71.28	0	0	11.8
2014	7	20	3	37	0	32	0	0	0	0	0	0	0	71.24	0	0	11.8
2014	7	20	3	47	0	33	0	0	0	0	0	0	0	71.19	0	0	11.8
2014	7	20	3	57	0	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	20	4	7	0	32	0	0	0	0	0	0	0	71.1	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	4	17	0	32	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	20	4	27	0	32	0	0	0	0	0	0	0	71.01	0	0	11.6
2014	7	20	4	37	0	32	0	0	0	0	0	0	0	70.97	0	0	11.6
2014	7	20	4	47	0	33	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	20	4	57	0	32	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	20	5	7	0	32	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	20	5	17	0	32	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	20	5	27	0	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	20	5	37	0	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	20	5	47	0	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	20	5	57	0	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	20	6	7	0	32	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	20	6	17	0	33	0	0	0	0	0	0	0	70.61	0	0	11.6
2014	7	20	6	27	0	33	0	0	0	0	0	0	0	70.57	0	0	11.6
2014	7	20	6	37	0	32	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	20	6	47	0	33	0	0	0	0	0	0	0	70.52	0	0	11.6
2014	7	20	6	57	0	32	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	20	7	7	0	33	0	0	0	0	0	0	0	70.47	0	0	11.6
2014	7	20	7	17	0	33	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	20	7	27	0	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	20	7	37	0	33	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	20	7	47	0	33	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	20	7	57	0	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	20	8	7	0	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	20	8	17	0	33	0	0	0	0	0	0	0	70.39	0	0	11.8
2014	7	20	8	27	0	32	0	0	0	0	0	0	0	70.43	0	0	12.2
2014	7	20	8	37	0	32	0	0	0	0	0	0	0	70.48	0	0	12.6
2014	7	20	8	47	0	32	0	0	0	0	0	0	0	70.52	0	0	12.6
2014	7	20	8	57	0	32	0	0	0	0	0	0	0	70.5	0	0	12.4
2014	7	20	9	7	0	32	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	20	9	17	0	32	0	0	0	0	0	0	0	70.54	0	0	12.6
2014	7	20	9	27	0	32	0	0	0	0	0	0	0	70.59	0	0	12.8
2014	7	20	9	37	0	32	0	0	0	0	0	0	0	70.7	0	0	13
2014	7	20	9	47	0	33	0	0	0	0	0	0	0	70.72	0	0	13
2014	7	20	9	57	0	32	0	0	0	0	0	0	0	70.74	0	0	12.8
2014	7	20	10	7	0	32	0	0	0	0	0	0	0	70.75	0	0	12.8
2014	7	20	10	17	0	32	0	0	0	0	0	0	0	70.74	0	0	12.8
2014	7	20	10	27	0	33	0	0	0	0	0	0	0	70.74	0	0	12.8
2014	7	20	10	37	0	32	0	0	0	0	0	0	0	70.84	0	0	13.6
2014	7	20	10	47	0	32	0	0	0	0	0	0	0	70.95	0	0	13.6
2014	7	20	10	57	0	32	0	0	0	0	0	0	0	71.06	0	0	13.6
2014	7	20	11	7	0	33	0	0	0	0	0	0	0	71.15	0	0	13.6
2014	7	20	11	17	0	33	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	7	20	11	27	0	32	0	0	0	0	0	0	0	71.15	0	0	13.4
2014	7	20	11	37	0	33	0	0	0	0	0	0	0	71.1	0	0	13.4
2014	7	20	11	47	0	32	0	0	0	0	0	0	0	71.1	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	11	57	0	32	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	7	20	12	7	0	32	0	0	0	0	0	0	0	71.17	0	0	13.4
2014	7	20	12	17	0	32	0	0	0	0	0	0	0	71.22	0	0	13.4
2014	7	20	12	27	0	33	0	0	0	0	0	0	0	71.26	0	0	13.2
2014	7	20	12	37	0	32	0	0	0	0	0	0	0	71.22	0	0	12.6
2014	7	20	12	47	0	31	0	0	0	0	0	0	0	71.22	0	0	12.6
2014	7	20	12	57	0	33	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	20	13	7	0	32	0	0	0	0	0	0	0	71.35	0	0	13.4
2014	7	20	13	17	0	32	0	0	0	0	0	0	0	71.58	0	0	13.4
2014	7	20	13	27	0	33	0	0	0	0	0	0	0	71.6	0	0	13.2
2014	7	20	13	37	0	32	0	0	0	0	0	0	0	71.71	0	0	13.2
2014	7	20	13	47	0	32	0	0	0	0	0	0	0	71.71	0	0	13
2014	7	20	13	57	0	32	0	0	0	0	0	0	0	71.67	0	0	13.2
2014	7	20	14	7	0	33	0	0	0	0	0	0	0	71.82	0	0	13.4
2014	7	20	14	17	0	32	0	0	0	0	0	0	0	71.89	0	0	13.4
2014	7	20	14	27	0	32	0	0	0	0	0	0	0	71.78	0	0	12.8
2014	7	20	14	37	0	32	0	0	0	0	0	0	0	71.87	0	0	13
2014	7	20	14	47	0	32	0	0	0	0	0	0	0	71.96	0	0	13.4
2014	7	20	14	57	0	33	0	0	0	0	0	0	0	72.01	0	0	13
2014	7	20	15	7	0	32	0	0	0	0	0	0	0	71.92	0	0	12.6
2014	7	20	15	17	0	32	0	0	0	0	0	0	0	71.94	0	0	12.8
2014	7	20	15	27	0	31	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	20	15	37	0	32	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	20	15	47	0	32	0	0	0	0	0	0	0	71.98	0	0	12.4
2014	7	20	15	57	0	31	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	7	20	16	7	0	32	0	0	0	0	0	0	0	72.14	0	0	13.4
2014	7	20	16	17	0	31	0	0	0	0	0	0	0	72.14	0	0	12.8
2014	7	20	16	27	0	32	0	0	0	0	0	0	0	72.25	0	0	13.2
2014	7	20	16	37	0	33	0	0	0	0	0	0	0	72.28	0	0	13.2
2014	7	20	16	47	0	32	0	0	0	0	0	0	0	72.34	0	0	13.2
2014	7	20	16	57	0	32	0	0	0	0	0	0	0	72.28	0	0	12.6
2014	7	20	17	7	0	32	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	20	17	17	0	33	0	0	0	0	0	0	0	72.28	0	0	12.4
2014	7	20	17	27	0	32	0	0	0	0	0	0	0	72.25	0	0	12.4
2014	7	20	17	37	0	31	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	20	17	47	0	32	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	20	17	57	0	32	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	20	18	7	0	32	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	20	18	17	0	32	0	0	0	0	0	0	0	72.28	0	0	12.2
2014	7	20	18	27	0	33	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	7	20	18	37	0	32	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	7	20	18	47	0	32	0	0	0	0	0	0	0	72.3	0	0	12
2014	7	20	18	57	0	32	0	0	0	0	0	0	0	72.32	0	0	12
2014	7	20	19	7	0	32	0	0	0	0	0	0	0	72.32	0	0	12
2014	7	20	19	17	0	32	0	0	0	0	0	0	0	72.32	0	0	12
2014	7	20	19	27	0	31	0	0	0	0	0	0	0	72.3	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	20	19	37	0	32	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	20	19	47	0	31	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	20	19	57	0	32	0	0	0	0	0	0	0	72.28	0	0	12
2014	7	20	20	7	0	31	0	0	0	0	0	0	0	72.28	0	0	11.8
2014	7	20	20	17	0	31	0	0	0	0	0	0	0	72.27	0	0	11.8
2014	7	20	20	27	0	32	0	0	0	0	0	0	0	72.25	0	0	11.8
2014	7	20	20	37	0	33	0	0	0	0	0	0	0	72.23	0	0	11.8
2014	7	20	20	47	0	32	0	0	0	0	0	0	0	72.23	0	0	11.8
2014	7	20	20	57	0	32	0	0	0	0	0	0	0	72.21	0	0	11.8
2014	7	20	21	7	0	33	0	0	0	0	0	0	0	72.19	0	0	11.8
2014	7	20	21	17	0	32	0	0	0	0	0	0	0	72.18	0	0	11.8
2014	7	20	21	27	0	32	0	0	0	0	0	0	0	72.16	0	0	11.8
2014	7	20	21	37	0	32	0	0	0	0	0	0	0	72.12	0	0	11.8
2014	7	20	21	47	0	31	0	0	0	0	0	0	0	72.1	0	0	11.8
2014	7	20	21	57	0	32	0	0	0	0	0	0	0	72.05	0	0	11.8
2014	7	20	22	7	0	32	0	0	0	0	0	0	0	72.03	0	0	11.8
2014	7	20	22	17	0	32	0	0	0	0	0	0	0	72.01	0	0	11.8
2014	7	20	22	27	0	32	0	0	0	0	0	0	0	71.98	0	0	11.8
2014	7	20	22	37	0	32	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	20	22	47	0	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	20	22	57	0	33	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	20	23	7	0	32	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	20	23	17	0	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	20	23	27	0	32	0	0	0	0	0	0	0	71.74	0	0	11.8
2014	7	20	23	37	0	32	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	20	23	47	0	32	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	20	23	57	0	32	0	0	0	0	0	0	0	71.64	0	0	11.8
2014	7	21	0	7	0	32	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	21	0	17	0	32	0	0	0	0	0	0	0	71.56	0	0	11.8
2014	7	21	0	27	0	33	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	21	0	37	0	33	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	21	0	47	0	32	0	0	0	0	0	0	0	71.46	0	0	11.8
2014	7	21	0	57	0	31	0	0	0	0	0	0	0	71.42	0	0	11.8
2014	7	21	1	7	0	32	0	0	0	0	0	0	0	71.37	0	0	11.8
2014	7	21	1	17	0	32	0	0	0	0	0	0	0	71.33	0	0	11.8
2014	7	21	1	27	0	32	0	0	0	0	0	0	0	71.29	0	0	11.8
2014	7	21	1	37	0	32	0	0	0	0	0	0	0	71.26	0	0	11.8
2014	7	21	1	47	0	32	0	0	0	0	0	0	0	71.2	0	0	11.8
2014	7	21	1	57	0	32	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	21	2	7	0	31	0	0	0	0	0	0	0	71.13	0	0	11.8
2014	7	21	2	17	0	32	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	21	2	27	0	33	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	21	2	37	0	33	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	21	2	47	0	33	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	21	2	57	0	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	21	3	7	0	32	0	0	0	0	0	0	0	70.84	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	3	17	0	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	21	3	27	0	33	0	0	0	0	0	0	0	70.75	0	0	11.8
2014	7	21	3	37	0	32	0	0	0	0	0	0	0	70.72	0	0	11.8
2014	7	21	3	47	0	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	21	3	57	0	31	0	0	0	0	0	0	0	70.61	0	0	11.8
2014	7	21	4	7	0	32	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	21	4	17	0	31	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	21	4	27	0	32	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	21	4	37	0	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	21	4	47	0	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2014	7	21	4	57	0	32	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	21	5	7	0	32	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	21	5	17	0	32	0	0	0	0	0	0	0	70.2	0	0	11.8
2014	7	21	5	27	0	33	0	0	0	0	0	0	0	70.14	0	0	11.8
2014	7	21	5	37	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	21	5	47	0	33	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	21	5	57	0	34	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	21	6	7	0	32	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	21	6	17	0	32	0	0	0	0	0	0	0	69.89	0	0	11.6
2014	7	21	6	27	0	33	0	0	0	0	0	0	0	69.85	0	0	11.6
2014	7	21	6	37	0	32	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	21	6	47	0	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	21	6	57	0	33	0	0	0	0	0	0	0	69.71	0	0	11.8
2014	7	21	7	7	0	32	0	0	0	0	0	0	0	69.67	0	0	11.8
2014	7	21	7	17	0	33	0	0	0	0	0	0	0	69.66	0	0	11.8
2014	7	21	7	27	0	33	0	0	0	0	0	0	0	69.64	0	0	12
2014	7	21	7	37	0	33	0	0	0	0	0	0	0	69.62	0	0	12.2
2014	7	21	7	47	0	32	0	0	0	0	0	0	0	69.62	0	0	12.2
2014	7	21	7	57	0	32	0	0	0	0	0	0	0	69.6	0	0	12.4
2014	7	21	8	7	0	33	0	0	0	0	0	0	0	69.6	0	0	12.4
2014	7	21	8	17	0	32	0	0	0	0	0	0	0	69.6	0	0	12.4
2014	7	21	8	27	0	33	0	0	0	0	0	0	0	69.62	0	0	12.6
2014	7	21	8	37	0	33	0	0	0	0	0	0	0	69.62	0	0	12.6
2014	7	21	8	47	0	32	0	0	0	0	0	0	0	69.66	0	0	12.6
2014	7	21	8	57	0	32	0	0	0	0	0	0	0	69.67	0	0	12.6
2014	7	21	9	7	0	33	0	0	0	0	0	0	0	69.69	0	0	12.8
2014	7	21	9	17	0	33	0	0	0	0	0	0	0	69.75	0	0	12.8
2014	7	21	9	27	0	32	0	0	0	0	0	0	0	69.76	0	0	12.8
2014	7	21	9	37	0	32	0	0	0	0	0	0	0	69.8	0	0	13
2014	7	21	9	47	0	32	0	0	0	0	0	0	0	69.85	0	0	13.6
2014	7	21	9	57	0	33	0	0	0	0	0	0	0	69.91	0	0	13.6
2014	7	21	10	7	0	32	0	0	0	0	0	0	0	69.96	0	0	13.6
2014	7	21	10	17	0	33	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	7	21	10	27	0	33	0	0	0	0	0	0	0	70.07	0	0	13.4
2014	7	21	10	37	0	32	0	0	0	0	0	0	0	70.14	0	0	13.4
2014	7	21	10	47	0	33	0	0	0	0	0	0	0	70.21	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	10	57	0	32	0	0	0	0	0	0	0	70.27	0	0	13.4
2014	7	21	11	7	0	32	0	0	0	0	0	0	0	70.34	0	0	13
2014	7	21	11	17	0	32	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	21	11	27	0	33	0	0	0	0	0	0	0	70.5	0	0	13.4
2014	7	21	11	37	0	33	0	0	0	0	0	0	0	70.54	0	0	13.4
2014	7	21	11	47	0	33	0	0	0	0	0	0	0	70.61	0	0	13.4
2014	7	21	11	57	0	33	0	0	0	0	0	0	0	70.68	0	0	13.4
2014	7	21	12	7	0	32	0	0	0	0	0	0	0	70.77	0	0	13.4
2014	7	21	12	17	0	33	0	0	0	0	0	0	0	70.84	0	0	13.4
2014	7	21	12	27	0	32	0	0	0	0	0	0	0	70.9	0	0	13.4
2014	7	21	12	37	0	32	0	0	0	0	0	0	0	70.99	0	0	13.4
2014	7	21	12	47	0	33	0	0	0	0	0	0	0	71.06	0	0	13.4
2014	7	21	12	57	0	33	0	0	0	0	0	0	0	71.13	0	0	13.4
2014	7	21	13	7	0	33	0	0	0	0	0	0	0	71.19	0	0	13.4
2014	7	21	13	17	0	33	0	0	0	0	0	0	0	71.28	0	0	13.4
2014	7	21	13	27	0	32	0	0	0	0	0	0	0	71.35	0	0	13.4
2014	7	21	13	37	0	32	0	0	0	0	0	0	0	71.38	0	0	13.4
2014	7	21	13	47	0	32	0	0	0	0	0	0	0	71.42	0	0	13.4
2014	7	21	13	57	0	33	0	0	0	0	0	0	0	71.49	0	0	13.4
2014	7	21	14	7	0	32	0	0	0	0	0	0	0	71.47	0	0	13.4
2014	7	21	14	17	0	32	0	0	0	0	0	0	0	71.47	0	0	13.4
2014	7	21	14	27	0	32	0	0	0	0	0	0	0	71.47	0	0	13
2014	7	21	14	37	0	33	0	0	0	0	0	0	0	71.51	0	0	13.2
2014	7	21	14	47	0	31	0	0	0	0	0	0	0	71.67	0	0	13.4
2014	7	21	14	57	0	33	0	0	0	0	0	0	0	71.73	0	0	13.4
2014	7	21	15	7	0	32	0	0	0	0	0	0	0	71.78	0	0	13.4
2014	7	21	15	17	0	32	0	0	0	0	0	0	0	71.82	0	0	13.4
2014	7	21	15	27	0	32	0	0	0	0	0	0	0	71.85	0	0	13.4
2014	7	21	15	37	0	32	0	0	0	0	0	0	0	71.87	0	0	13.2
2014	7	21	15	47	0	32	0	0	0	0	0	0	0	71.91	0	0	13.2
2014	7	21	15	57	0	32	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	21	16	7	0	33	0	0	0	0	0	0	0	71.92	0	0	13.2
2014	7	21	16	17	0	31	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	7	21	16	27	0	32	0	0	0	0	0	0	0	71.94	0	0	13.2
2014	7	21	16	37	0	32	0	0	0	0	0	0	0	71.94	0	0	13
2014	7	21	16	47	0	31	0	0	0	0	0	0	0	71.96	0	0	13
2014	7	21	16	57	0	31	0	0	0	0	0	0	0	71.96	0	0	12.8
2014	7	21	17	7	0	32	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	21	17	17	0	33	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	21	17	27	0	32	0	0	0	0	0	0	0	71.96	0	0	12.6
2014	7	21	17	37	0	33	0	0	0	0	0	0	0	71.96	0	0	12.4
2014	7	21	17	47	0	32	0	0	0	0	0	0	0	71.96	0	0	12.4
2014	7	21	17	57	0	32	0	0	0	0	0	0	0	71.92	0	0	12.2
2014	7	21	18	7	0	32	0	0	0	0	0	0	0	71.92	0	0	12
2014	7	21	18	17	0	31	0	0	0	0	0	0	0	71.92	0	0	12
2014	7	21	18	27	0	32	0	0	0	0	0	0	0	71.91	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	21	18	37	0	32	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	21	18	47	0	32	0	0	0	0	0	0	0	71.91	0	0	12
2014	7	21	18	57	0	33	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	21	19	7	0	32	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	21	19	17	0	31	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	21	19	27	0	31	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	21	19	37	0	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	21	19	47	0	32	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	21	19	57	0	31	0	0	0	0	0	0	0	71.83	0	0	11.8
2014	7	21	20	7	0	32	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	21	20	17	0	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	21	20	27	0	32	0	0	0	0	0	0	0	71.78	0	0	11.8
2014	7	21	20	37	0	32	0	0	0	0	0	0	0	71.74	0	0	11.8
2014	7	21	20	47	0	32	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	21	20	57	0	32	0	0	0	0	0	0	0	71.73	0	0	11.8
2014	7	21	21	7	0	32	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	21	21	17	0	32	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	21	21	27	0	32	0	0	0	0	0	0	0	71.65	0	0	11.8
2014	7	21	21	37	0	32	0	0	0	0	0	0	0	71.64	0	0	11.8
2014	7	21	21	47	0	31	0	0	0	0	0	0	0	71.62	0	0	11.8
2014	7	21	21	57	0	33	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	21	22	7	0	32	0	0	0	0	0	0	0	71.56	0	0	11.8
2014	7	21	22	17	0	32	0	0	0	0	0	0	0	71.55	0	0	11.8
2014	7	21	22	27	0	32	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	21	22	37	0	33	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	21	22	47	0	32	0	0	0	0	0	0	0	71.44	0	0	11.8
2014	7	21	22	57	0	32	0	0	0	0	0	0	0	71.4	0	0	11.8
2014	7	21	23	7	0	32	0	0	0	0	0	0	0	71.37	0	0	11.8
2014	7	21	23	17	0	32	0	0	0	0	0	0	0	71.33	0	0	11.8
2014	7	21	23	27	0	32	0	0	0	0	0	0	0	71.31	0	0	11.8
2014	7	21	23	37	0	32	0	0	0	0	0	0	0	71.28	0	0	11.8
2014	7	21	23	47	0	33	0	0	0	0	0	0	0	71.24	0	0	11.8
2014	7	21	23	57	0	32	0	0	0	0	0	0	0	71.22	0	0	11.8
2014	7	22	0	7	0	32	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	22	0	17	0	32	0	0	0	0	0	0	0	71.15	0	0	11.8
2014	7	22	0	27	0	32	0	0	0	0	0	0	0	71.11	0	0	11.8
2014	7	22	0	37	0	33	0	0	0	0	0	0	0	71.1	0	0	11.8
2014	7	22	0	47	0	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	22	0	57	0	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	22	1	7	0	32	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	22	1	17	0	32	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	22	1	27	0	31	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	22	1	37	0	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	22	1	47	0	32	0	0	0	0	0	0	0	70.86	0	0	11.8
2014	7	22	1	57	0	32	0	0	0	0	0	0	0	70.83	0	0	11.8
2014	7	22	2	7	0	32	0	0	0	0	0	0	0	70.81	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	2	17	0	33	0	0	0	0	0	0	0	70.77	0	0	11.8
2014	7	22	2	27	0	32	0	0	0	0	0	0	0	70.74	0	0	11.8
2014	7	22	2	37	0	32	0	0	0	0	0	0	0	70.7	0	0	11.8
2014	7	22	2	47	0	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	22	2	57	0	32	0	0	0	0	0	0	0	70.61	0	0	11.8
2014	7	22	3	7	0	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2014	7	22	3	17	0	33	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	22	3	27	0	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	22	3	37	0	32	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	22	3	47	0	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	22	3	57	0	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	22	4	7	0	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	22	4	17	0	33	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	22	4	27	0	33	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	22	4	37	0	32	0	0	0	0	0	0	0	70.29	0	0	11.6
2014	7	22	4	47	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	22	4	57	0	32	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	22	5	7	0	33	0	0	0	0	0	0	0	70.16	0	0	11.6
2014	7	22	5	17	0	33	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	22	5	27	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	22	5	37	0	33	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	22	5	47	0	33	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	22	5	57	0	32	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	22	6	7	0	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	22	6	17	0	32	0	0	0	0	0	0	0	69.89	0	0	11.6
2014	7	22	6	27	0	32	0	0	0	0	0	0	0	69.85	0	0	11.6
2014	7	22	6	37	0	33	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	22	6	47	0	33	0	0	0	0	0	0	0	69.78	0	0	11.6
2014	7	22	6	57	0	32	0	0	0	0	0	0	0	69.75	0	0	11.8
2014	7	22	7	7	0	33	0	0	0	0	0	0	0	69.71	0	0	11.8
2014	7	22	7	17	0	33	0	0	0	0	0	0	0	69.69	0	0	11.8
2014	7	22	7	27	0	32	0	0	0	0	0	0	0	69.67	0	0	12
2014	7	22	7	37	0	33	0	0	0	0	0	0	0	69.66	0	0	12.2
2014	7	22	7	47	0	33	0	0	0	0	0	0	0	69.66	0	0	12.2
2014	7	22	7	57	0	32	0	0	0	0	0	0	0	69.66	0	0	12.4
2014	7	22	8	7	0	33	0	0	0	0	0	0	0	69.66	0	0	12.2
2014	7	22	8	17	0	32	0	0	0	0	0	0	0	69.66	0	0	12.4
2014	7	22	8	27	0	33	0	0	0	0	0	0	0	69.67	0	0	12.4
2014	7	22	8	37	0	32	0	0	0	0	0	0	0	69.69	0	0	12.4
2014	7	22	8	47	0	32	0	0	0	0	0	0	0	69.73	0	0	12.4
2014	7	22	8	57	0	32	0	0	0	0	0	0	0	69.76	0	0	12.4
2014	7	22	9	7	0	33	0	0	0	0	0	0	0	69.78	0	0	12.4
2014	7	22	9	17	0	32	0	0	0	0	0	0	0	69.82	0	0	12.4
2014	7	22	9	27	0	32	0	0	0	0	0	0	0	69.87	0	0	12.8
2014	7	22	9	37	0	33	0	0	0	0	0	0	0	69.91	0	0	13
2014	7	22	9	47	0	33	0	0	0	0	0	0	0	69.96	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	9	57	0	32	0	0	0	0	0	0	0	70.02	0	0	13
2014	7	22	10	7	0	32	0	0	0	0	0	0	0	70.07	0	0	13
2014	7	22	10	17	0	32	0	0	0	0	0	0	0	70.12	0	0	13
2014	7	22	10	27	0	32	0	0	0	0	0	0	0	70.2	0	0	13
2014	7	22	10	37	0	33	0	0	0	0	0	0	0	70.27	0	0	13
2014	7	22	10	47	0	32	0	0	0	0	0	0	0	70.32	0	0	13
2014	7	22	10	57	0	32	0	0	0	0	0	0	0	70.39	0	0	13.4
2014	7	22	11	7	0	32	0	0	0	0	0	0	0	70.47	0	0	13.4
2014	7	22	11	17	0	32	0	0	0	0	0	0	0	70.52	0	0	13.4
2014	7	22	11	27	0	32	0	0	0	0	0	0	0	70.59	0	0	13.2
2014	7	22	11	37	0	32	0	0	0	0	0	0	0	70.66	0	0	13.4
2014	7	22	11	47	0	33	0	0	0	0	0	0	0	70.75	0	0	13.2
2014	7	22	11	57	0	32	0	0	0	0	0	0	0	70.83	0	0	13
2014	7	22	12	7	0	32	0	0	0	0	0	0	0	70.88	0	0	13
2014	7	22	12	17	0	33	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	22	12	27	0	32	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	7	22	12	37	0	33	0	0	0	0	0	0	0	71.11	0	0	13.2
2014	7	22	12	47	0	32	0	0	0	0	0	0	0	71.19	0	0	13.2
2014	7	22	12	57	0	32	0	0	0	0	0	0	0	71.26	0	0	13.2
2014	7	22	13	7	0	32	0	0	0	0	0	0	0	71.33	0	0	13.2
2014	7	22	13	17	0	32	0	0	0	0	0	0	0	71.38	0	0	13.2
2014	7	22	13	27	0	32	0	0	0	0	0	0	0	71.46	0	0	13
2014	7	22	13	37	0	32	0	0	0	0	0	0	0	71.53	0	0	13
2014	7	22	13	47	0	33	0	0	0	0	0	0	0	71.58	0	0	13
2014	7	22	13	57	0	32	0	0	0	0	0	0	0	71.65	0	0	13
2014	7	22	14	7	0	33	0	0	0	0	0	0	0	71.71	0	0	13
2014	7	22	14	17	0	33	0	0	0	0	0	0	0	71.76	0	0	13
2014	7	22	14	27	0	32	0	0	0	0	0	0	0	71.82	0	0	13
2014	7	22	14	37	0	33	0	0	0	0	0	0	0	71.87	0	0	13
2014	7	22	14	47	0	32	0	0	0	0	0	0	0	71.89	0	0	13
2014	7	22	14	57	0	32	0	0	0	0	0	0	0	71.92	0	0	13
2014	7	22	15	7	0	33	0	0	0	0	0	0	0	71.98	0	0	13
2014	7	22	15	17	0	32	0	0	0	0	0	0	0	72	0	0	13.2
2014	7	22	15	27	0	32	0	0	0	0	0	0	0	72.03	0	0	13.2
2014	7	22	15	37	0	32	0	0	0	0	0	0	0	72.05	0	0	13.2
2014	7	22	15	47	0	32	0	0	0	0	0	0	0	72.07	0	0	13.2
2014	7	22	15	57	0	32	0	0	0	0	0	0	0	72.09	0	0	13.2
2014	7	22	16	7	0	32	0	0	0	0	0	0	0	72.1	0	0	13.2
2014	7	22	16	17	0	32	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	22	16	27	0	33	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	22	16	37	0	33	0	0	0	0	0	0	0	72.1	0	0	13
2014	7	22	16	47	0	32	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	22	16	57	0	32	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	22	17	7	0	32	0	0	0	0	0	0	0	72.09	0	0	12.6
2014	7	22	17	17	0	32	0	0	0	0	0	0	0	72.09	0	0	12.6
2014	7	22	17	27	0	32	0	0	0	0	0	0	0	72.07	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	22	17	37	0	32	0	0	0	0	0	0	0	72.07	0	0	12.4
2014	7	22	17	47	0	32	0	0	0	0	0	0	0	72.05	0	0	12.4
2014	7	22	17	57	0	31	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	22	18	7	0	32	0	0	0	0	0	0	0	72.01	0	0	12.2
2014	7	22	18	17	0	32	0	0	0	0	0	0	0	72	0	0	12
2014	7	22	18	27	0	32	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	22	18	37	0	33	0	0	0	0	0	0	0	71.98	0	0	12
2014	7	22	18	47	0	32	0	0	0	0	0	0	0	71.96	0	0	12
2014	7	22	18	57	0	32	0	0	0	0	0	0	0	71.96	0	0	11.8
2014	7	22	19	7	0	33	0	0	0	0	0	0	0	71.94	0	0	11.8
2014	7	22	19	17	0	33	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	22	19	27	0	32	0	0	0	0	0	0	0	71.92	0	0	11.8
2014	7	22	19	37	0	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	22	19	47	0	32	0	0	0	0	0	0	0	71.91	0	0	11.8
2014	7	22	19	57	0	32	0	0	0	0	0	0	0	71.89	0	0	11.8
2014	7	22	20	7	0	32	0	0	0	0	0	0	0	71.87	0	0	11.8
2014	7	22	20	17	0	32	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	22	20	27	0	31	0	0	0	0	0	0	0	71.85	0	0	11.8
2014	7	22	20	37	0	32	0	0	0	0	0	0	0	71.82	0	0	11.8
2014	7	22	20	47	0	32	0	0	0	0	0	0	0	71.8	0	0	11.8
2014	7	22	20	57	0	32	0	0	0	0	0	0	0	71.76	0	0	11.8
2014	7	22	21	7	0	31	0	0	0	0	0	0	0	71.74	0	0	11.8
2014	7	22	21	17	0	33	0	0	0	0	0	0	0	71.71	0	0	11.8
2014	7	22	21	27	0	32	0	0	0	0	0	0	0	71.67	0	0	11.8
2014	7	22	21	37	0	32	0	0	0	0	0	0	0	71.64	0	0	11.8
2014	7	22	21	47	0	32	0	0	0	0	0	0	0	71.6	0	0	11.8
2014	7	22	21	57	0	32	0	0	0	0	0	0	0	71.56	0	0	11.8
2014	7	22	22	7	0	33	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	22	22	17	0	33	0	0	0	0	0	0	0	71.47	0	0	11.8
2014	7	22	22	27	0	32	0	0	0	0	0	0	0	71.44	0	0	11.8
2014	7	22	22	37	0	32	0	0	0	0	0	0	0	71.4	0	0	11.8
2014	7	22	22	47	0	32	0	0	0	0	0	0	0	71.35	0	0	11.8
2014	7	22	22	57	0	32	0	0	0	0	0	0	0	71.31	0	0	11.8
2014	7	22	23	7	0	32	0	0	0	0	0	0	0	71.28	0	0	11.8
2014	7	22	23	17	0	33	0	0	0	0	0	0	0	71.24	0	0	11.8
2014	7	22	23	27	0	33	0	0	0	0	0	0	0	71.2	0	0	11.8
2014	7	22	23	37	0	32	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	22	23	47	0	33	0	0	0	0	0	0	0	71.11	0	0	11.8
2014	7	22	23	57	0	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	23	0	7	0	33	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	23	0	17	0	33	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	23	0	27	0	33	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	23	0	37	0	32	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	23	0	47	0	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	23	0	57	0	32	0	0	0	0	0	0	0	70.88	0	0	11.8
2014	7	23	1	7	0	32	0	0	0	0	0	0	0	70.84	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	1	17	0	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	23	1	27	0	32	0	0	0	0	0	0	0	70.75	0	0	11.8
2014	7	23	1	37	0	32	0	0	0	0	0	0	0	70.72	0	0	11.8
2014	7	23	1	47	0	32	0	0	0	0	0	0	0	70.68	0	0	11.8
2014	7	23	1	57	0	32	0	0	0	0	0	0	0	70.65	0	0	11.8
2014	7	23	2	7	0	33	0	0	0	0	0	0	0	70.61	0	0	11.8
2014	7	23	2	17	0	32	0	0	0	0	0	0	0	70.56	0	0	11.8
2014	7	23	2	27	0	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2014	7	23	2	37	0	32	0	0	0	0	0	0	0	70.47	0	0	11.8
2014	7	23	2	47	0	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	23	2	57	0	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2014	7	23	3	7	0	33	0	0	0	0	0	0	0	70.32	0	0	11.8
2014	7	23	3	17	0	33	0	0	0	0	0	0	0	70.27	0	0	11.8
2014	7	23	3	27	0	33	0	0	0	0	0	0	0	70.21	0	0	11.8
2014	7	23	3	37	0	32	0	0	0	0	0	0	0	70.16	0	0	11.8
2014	7	23	3	47	0	33	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	23	3	57	0	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	23	4	7	0	33	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	23	4	17	0	33	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	23	4	27	0	33	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	23	4	37	0	33	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	23	4	47	0	32	0	0	0	0	0	0	0	69.75	0	0	11.6
2014	7	23	4	57	0	33	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	23	5	7	0	32	0	0	0	0	0	0	0	69.62	0	0	11.6
2014	7	23	5	17	0	33	0	0	0	0	0	0	0	69.57	0	0	11.6
2014	7	23	5	27	0	33	0	0	0	0	0	0	0	69.51	0	0	11.6
2014	7	23	5	37	0	32	0	0	0	0	0	0	0	69.46	0	0	11.6
2014	7	23	5	47	0	32	0	0	0	0	0	0	0	69.4	0	0	11.6
2014	7	23	5	57	0	32	0	0	0	0	0	0	0	69.33	0	0	11.6
2014	7	23	6	7	0	33	0	0	0	0	0	0	0	69.28	0	0	11.6
2014	7	23	6	17	0	33	0	0	0	0	0	0	0	69.22	0	0	11.6
2014	7	23	6	27	0	33	0	0	0	0	0	0	0	69.15	0	0	11.6
2014	7	23	6	37	0	32	0	0	0	0	0	0	0	69.1	0	0	11.6
2014	7	23	6	47	0	32	0	0	0	0	0	0	0	69.06	0	0	11.6
2014	7	23	6	57	0	32	0	0	0	0	0	0	0	68.99	0	0	11.8
2014	7	23	7	7	0	32	0	0	0	0	0	0	0	68.95	0	0	11.6
2014	7	23	7	17	0	33	0	0	0	0	0	0	0	68.92	0	0	11.8
2014	7	23	7	27	0	32	0	0	0	0	0	0	0	68.9	0	0	12
2014	7	23	7	37	0	33	0	0	0	0	0	0	0	68.88	0	0	12.2
2014	7	23	7	47	0	33	0	0	0	0	0	0	0	68.86	0	0	12.2
2014	7	23	7	57	0	33	0	0	0	0	0	0	0	68.86	0	0	12.4
2014	7	23	8	7	0	32	0	0	0	0	0	0	0	68.85	0	0	12.4
2014	7	23	8	17	0	32	0	0	0	0	0	0	0	68.85	0	0	12.4
2014	7	23	8	27	0	33	0	0	0	0	0	0	0	68.85	0	0	12.6
2014	7	23	8	37	0	33	0	0	0	0	0	0	0	68.86	0	0	12.6
2014	7	23	8	47	0	32	0	0	0	0	0	0	0	68.88	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	8	57	0	32	0	0	0	0	0	0	0	68.9	0	0	12.6
2014	7	23	9	7	0	33	0	0	0	0	0	0	0	68.92	0	0	12.6
2014	7	23	9	17	0	32	0	0	0	0	0	0	0	68.95	0	0	12.8
2014	7	23	9	27	0	33	0	0	0	0	0	0	0	68.99	0	0	12.8
2014	7	23	9	37	0	32	0	0	0	0	0	0	0	69.04	0	0	13.2
2014	7	23	9	47	0	33	0	0	0	0	0	0	0	69.1	0	0	13.4
2014	7	23	9	57	0	33	0	0	0	0	0	0	0	69.15	0	0	13.4
2014	7	23	10	7	0	32	0	0	0	0	0	0	0	69.19	0	0	13.4
2014	7	23	10	17	0	32	0	0	0	0	0	0	0	69.24	0	0	13.4
2014	7	23	10	27	0	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2014	7	23	10	37	0	33	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	7	23	10	47	0	33	0	0	0	0	0	0	0	69.44	0	0	13.2
2014	7	23	10	57	0	32	0	0	0	0	0	0	0	69.51	0	0	13.2
2014	7	23	11	7	0	32	0	0	0	0	0	0	0	69.57	0	0	13.2
2014	7	23	11	17	0	32	0	0	0	0	0	0	0	69.64	0	0	13.2
2014	7	23	11	27	0	32	0	0	0	0	0	0	0	69.71	0	0	13
2014	7	23	11	37	0	33	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	23	11	47	0	32	0	0	0	0	0	0	0	69.85	0	0	13
2014	7	23	11	57	0	33	0	0	0	0	0	0	0	69.94	0	0	13
2014	7	23	12	7	0	32	0	0	0	0	0	0	0	70.02	0	0	13
2014	7	23	12	17	0	33	0	0	0	0	0	0	0	70.09	0	0	13
2014	7	23	12	27	0	32	0	0	0	0	0	0	0	70.16	0	0	13
2014	7	23	12	37	0	33	0	0	0	0	0	0	0	70.25	0	0	13
2014	7	23	12	47	0	33	0	0	0	0	0	0	0	70.32	0	0	13
2014	7	23	12	57	0	32	0	0	0	0	0	0	0	70.41	0	0	13
2014	7	23	13	7	0	32	0	0	0	0	0	0	0	70.48	0	0	13
2014	7	23	13	17	0	33	0	0	0	0	0	0	0	70.56	0	0	13
2014	7	23	13	27	0	32	0	0	0	0	0	0	0	70.65	0	0	13
2014	7	23	13	37	0	33	0	0	0	0	0	0	0	70.72	0	0	12.8
2014	7	23	13	47	0	32	0	0	0	0	0	0	0	70.79	0	0	12.8
2014	7	23	13	57	0	32	0	0	0	0	0	0	0	70.86	0	0	12.8
2014	7	23	14	7	0	32	0	0	0	0	0	0	0	70.95	0	0	12.8
2014	7	23	14	17	0	32	0	0	0	0	0	0	0	71.01	0	0	12.8
2014	7	23	14	27	0	32	0	0	0	0	0	0	0	71.1	0	0	12.8
2014	7	23	14	37	0	32	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	23	14	47	0	32	0	0	0	0	0	0	0	71.2	0	0	12.6
2014	7	23	14	57	0	32	0	0	0	0	0	0	0	71.26	0	0	12.8
2014	7	23	15	7	0	32	0	0	0	0	0	0	0	71.29	0	0	12.8
2014	7	23	15	17	0	32	0	0	0	0	0	0	0	71.33	0	0	12.8
2014	7	23	15	27	0	32	0	0	0	0	0	0	0	71.38	0	0	12.8
2014	7	23	15	37	0	32	0	0	0	0	0	0	0	71.4	0	0	12.8
2014	7	23	15	47	0	32	0	0	0	0	0	0	0	71.46	0	0	12.6
2014	7	23	15	57	0	32	0	0	0	0	0	0	0	71.49	0	0	12.6
2014	7	23	16	7	0	33	0	0	0	0	0	0	0	71.51	0	0	12.6
2014	7	23	16	17	0	32	0	0	0	0	0	0	0	71.53	0	0	12.4
2014	7	23	16	27	0	32	0	0	0	0	0	0	0	71.55	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	23	16	37	0	32	0	0	0	0	0	0	0	71.56	0	0	12.4
2014	7	23	16	47	0	33	0	0	0	0	0	0	0	71.56	0	0	12.4
2014	7	23	16	57	0	32	0	0	0	0	0	0	0	71.56	0	0	12.4
2014	7	23	17	7	0	32	0	0	0	0	0	0	0	71.58	0	0	12.2
2014	7	23	17	17	0	32	0	0	0	0	0	0	0	71.58	0	0	12.2
2014	7	23	17	27	0	33	0	0	0	0	0	0	0	71.56	0	0	12.2
2014	7	23	17	37	0	32	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	23	17	47	0	32	0	0	0	0	0	0	0	71.56	0	0	11.8
2014	7	23	17	57	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	23	18	7	0	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	23	18	17	0	32	0	0	0	0	0	0	0	71.53	0	0	11.4
2014	7	23	18	27	0	32	0	0	0	0	0	0	0	71.53	0	0	11.4
2014	7	23	18	37	0	33	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	23	18	47	0	31	0	0	0	0	0	0	0	71.51	0	0	11.4
2014	7	23	18	57	0	32	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	23	19	7	0	32	0	0	0	0	0	0	0	71.51	0	0	11.2
2014	7	23	19	17	0	32	0	0	0	0	0	0	0	71.49	0	0	11.2
2014	7	23	19	27	0	33	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	23	19	37	0	32	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	23	19	47	0	32	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	23	19	57	0	32	0	0	0	0	0	0	0	71.47	0	0	11.2
2014	7	23	20	7	0	33	0	0	0	0	0	0	0	71.46	0	0	11.2
2014	7	23	20	17	0	32	0	0	0	0	0	0	0	71.44	0	0	11.2
2014	7	23	20	27	0	33	0	0	0	0	0	0	0	71.42	0	0	11.2
2014	7	23	20	37	0	33	0	0	0	0	0	0	0	71.4	0	0	11.2
2014	7	23	20	47	0	32	0	0	0	0	0	0	0	71.38	0	0	11.2
2014	7	23	20	57	0	33	0	0	0	0	0	0	0	71.37	0	0	11.2
2014	7	23	21	7	0	33	0	0	0	0	0	0	0	71.33	0	0	11.2
2014	7	23	21	17	0	33	0	0	0	0	0	0	0	71.29	0	0	11.2
2014	7	23	21	27	0	32	0	0	0	0	0	0	0	71.28	0	0	11.2
2014	7	23	21	37	0	31	0	0	0	0	0	0	0	71.26	0	0	11.2
2014	7	23	21	47	0	31	0	0	0	0	0	0	0	71.22	0	0	11.2
2014	7	23	21	57	0	33	0	0	0	0	0	0	0	71.19	0	0	11.2
2014	7	23	22	7	0	33	0	0	0	0	0	0	0	71.13	0	0	11.2
2014	7	23	22	17	0	32	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	23	22	27	0	32	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	23	22	37	0	32	0	0	0	0	0	0	0	71.04	0	0	11.2
2014	7	23	22	47	0	32	0	0	0	0	0	0	0	71.01	0	0	11.2
2014	7	23	22	57	0	32	0	0	0	0	0	0	0	70.97	0	0	11.2
2014	7	23	23	7	0	33	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	23	23	17	0	32	0	0	0	0	0	0	0	70.9	0	0	11.2
2014	7	23	23	27	0	32	0	0	0	0	0	0	0	70.84	0	0	11.2
2014	7	23	23	37	0	33	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	23	23	47	0	32	0	0	0	0	0	0	0	70.77	0	0	11.2
2014	7	23	23	57	0	33	0	0	0	0	0	0	0	70.75	0	0	11.2
2014	7	24	0	7	0	33	0	0	0	0	0	0	0	70.72	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	0	17	0	32	0	0	0	0	0	0	0	70.68	0	0	11.2
2014	7	24	0	27	0	32	0	0	0	0	0	0	0	70.65	0	0	11.2
2014	7	24	0	37	0	32	0	0	0	0	0	0	0	70.61	0	0	11.2
2014	7	24	0	47	0	33	0	0	0	0	0	0	0	70.57	0	0	11.2
2014	7	24	0	57	0	32	0	0	0	0	0	0	0	70.52	0	0	11.2
2014	7	24	1	7	0	32	0	0	0	0	0	0	0	70.48	0	0	11.2
2014	7	24	1	17	0	32	0	0	0	0	0	0	0	70.43	0	0	11.2
2014	7	24	1	27	0	33	0	0	0	0	0	0	0	70.39	0	0	11.2
2014	7	24	1	37	0	32	0	0	0	0	0	0	0	70.34	0	0	11.2
2014	7	24	1	47	0	32	0	0	0	0	0	0	0	70.29	0	0	11.2
2014	7	24	1	57	0	32	0	0	0	0	0	0	0	70.23	0	0	11.2
2014	7	24	2	7	0	33	0	0	0	0	0	0	0	70.18	0	0	11.2
2014	7	24	2	17	0	33	0	0	0	0	0	0	0	70.11	0	0	11
2014	7	24	2	27	0	32	0	0	0	0	0	0	0	70.05	0	0	11
2014	7	24	2	37	0	32	0	0	0	0	0	0	0	70	0	0	11
2014	7	24	2	47	0	32	0	0	0	0	0	0	0	69.94	0	0	11.4
2014	7	24	2	57	0	32	0	0	0	0	0	0	0	69.89	0	0	11
2014	7	24	3	7	0	33	0	0	0	0	0	0	0	69.82	0	0	11
2014	7	24	3	17	0	32	0	0	0	0	0	0	0	69.75	0	0	11
2014	7	24	3	27	0	32	0	0	0	0	0	0	0	69.67	0	0	11
2014	7	24	3	37	0	32	0	0	0	0	0	0	0	69.6	0	0	11
2014	7	24	3	47	0	33	0	0	0	0	0	0	0	69.53	0	0	11
2014	7	24	3	57	0	33	0	0	0	0	0	0	0	69.46	0	0	11
2014	7	24	4	7	0	32	0	0	0	0	0	0	0	69.4	0	0	11
2014	7	24	4	17	0	32	0	0	0	0	0	0	0	69.35	0	0	11
2014	7	24	4	27	0	32	0	0	0	0	0	0	0	69.28	0	0	11.2
2014	7	24	4	37	0	32	0	0	0	0	0	0	0	69.21	0	0	11
2014	7	24	4	47	0	32	0	0	0	0	0	0	0	69.15	0	0	11
2014	7	24	4	57	0	32	0	0	0	0	0	0	0	69.1	0	0	11
2014	7	24	5	7	0	33	0	0	0	0	0	0	0	69.03	0	0	11
2014	7	24	5	17	0	32	0	0	0	0	0	0	0	68.97	0	0	11
2014	7	24	5	27	0	32	0	0	0	0	0	0	0	68.9	0	0	11
2014	7	24	5	37	0	33	0	0	0	0	0	0	0	68.86	0	0	11
2014	7	24	5	47	0	32	0	0	0	0	0	0	0	68.79	0	0	11
2014	7	24	5	57	0	32	0	0	0	0	0	0	0	68.74	0	0	11
2014	7	24	6	7	0	33	0	0	0	0	0	0	0	68.68	0	0	11
2014	7	24	6	17	0	32	0	0	0	0	0	0	0	68.63	0	0	11
2014	7	24	6	27	0	33	0	0	0	0	0	0	0	68.58	0	0	11
2014	7	24	6	37	0	33	0	0	0	0	0	0	0	68.5	0	0	11
2014	7	24	6	47	0	32	0	0	0	0	0	0	0	68.47	0	0	11
2014	7	24	6	57	0	33	0	0	0	0	0	0	0	68.41	0	0	11.2
2014	7	24	7	7	0	33	0	0	0	0	0	0	0	68.38	0	0	11.2
2014	7	24	7	17	0	33	0	0	0	0	0	0	0	68.32	0	0	11.4
2014	7	24	7	27	0	33	0	0	0	0	0	0	0	68.32	0	0	11.4
2014	7	24	7	37	0	32	0	0	0	0	0	0	0	68.31	0	0	11.6
2014	7	24	7	47	0	33	0	0	0	0	0	0	0	68.29	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	7	57	0	33	0	0	0	0	0	0	0	68.27	0	0	11.8
2014	7	24	8	7	0	33	0	0	0	0	0	0	0	68.29	0	0	12
2014	7	24	8	17	0	33	0	0	0	0	0	0	0	68.29	0	0	12
2014	7	24	8	27	0	33	0	0	0	0	0	0	0	68.29	0	0	12
2014	7	24	8	37	0	33	0	0	0	0	0	0	0	68.31	0	0	12.2
2014	7	24	8	47	0	33	0	0	0	0	0	0	0	68.32	0	0	12.2
2014	7	24	8	57	0	32	0	0	0	0	0	0	0	68.34	0	0	12.2
2014	7	24	9	7	0	33	0	0	0	0	0	0	0	68.38	0	0	12.2
2014	7	24	9	17	0	33	0	0	0	0	0	0	0	68.41	0	0	12.4
2014	7	24	9	27	0	32	0	0	0	0	0	0	0	68.43	0	0	12.6
2014	7	24	9	37	0	32	0	0	0	0	0	0	0	68.49	0	0	13.8
2014	7	24	9	47	0	32	0	0	0	0	0	0	0	68.54	0	0	14
2014	7	24	9	57	0	32	0	0	0	0	0	0	0	68.59	0	0	13.6
2014	7	24	10	7	0	32	0	0	0	0	0	0	0	68.65	0	0	13.6
2014	7	24	10	17	0	32	0	0	0	0	0	0	0	68.7	0	0	13.4
2014	7	24	10	27	0	33	0	0	0	0	0	0	0	68.77	0	0	13.4
2014	7	24	10	37	0	33	0	0	0	0	0	0	0	68.85	0	0	13.2
2014	7	24	10	47	0	32	0	0	0	0	0	0	0	68.9	0	0	13.4
2014	7	24	10	57	0	32	0	0	0	0	0	0	0	68.97	0	0	13.2
2014	7	24	11	7	0	33	0	0	0	0	0	0	0	69.06	0	0	13.2
2014	7	24	11	17	0	32	0	0	0	0	0	0	0	69.13	0	0	13.2
2014	7	24	11	27	0	33	0	0	0	0	0	0	0	69.22	0	0	13.2
2014	7	24	11	37	0	33	0	0	0	0	0	0	0	69.28	0	0	13.2
2014	7	24	11	47	0	32	0	0	0	0	0	0	0	69.37	0	0	13.2
2014	7	24	11	57	0	33	0	0	0	0	0	0	0	69.42	0	0	13.2
2014	7	24	12	7	0	32	0	0	0	0	0	0	0	69.51	0	0	13.2
2014	7	24	12	17	0	33	0	0	0	0	0	0	0	69.58	0	0	13.2
2014	7	24	12	27	0	33	0	0	0	0	0	0	0	69.62	0	0	13.2
2014	7	24	12	37	0	33	0	0	0	0	0	0	0	69.66	0	0	13.2
2014	7	24	12	47	0	32	0	0	0	0	0	0	0	69.71	0	0	13.4
2014	7	24	12	57	0	32	0	0	0	0	0	0	0	69.8	0	0	13.4
2014	7	24	13	7	0	33	0	0	0	0	0	0	0	69.85	0	0	13.2
2014	7	24	13	17	0	33	0	0	0	0	0	0	0	70.11	0	0	13.2
2014	7	24	13	27	0	33	0	0	0	0	0	0	0	70.23	0	0	13.4
2014	7	24	13	37	0	33	0	0	0	0	0	0	0	70.34	0	0	13.2
2014	7	24	13	47	0	33	0	0	0	0	0	0	0	70.41	0	0	13.2
2014	7	24	13	57	0	32	0	0	0	0	0	0	0	70.5	0	0	13.2
2014	7	24	14	7	0	33	0	0	0	0	0	0	0	70.57	0	0	13.2
2014	7	24	14	17	0	33	0	0	0	0	0	0	0	70.63	0	0	13.2
2014	7	24	14	27	0	32	0	0	0	0	0	0	0	70.7	0	0	13.2
2014	7	24	14	37	0	33	0	0	0	0	0	0	0	70.75	0	0	13.2
2014	7	24	14	47	0	32	0	0	0	0	0	0	0	70.79	0	0	13.2
2014	7	24	14	57	0	32	0	0	0	0	0	0	0	70.84	0	0	13.2
2014	7	24	15	7	0	32	0	0	0	0	0	0	0	70.92	0	0	13
2014	7	24	15	17	0	32	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	24	15	27	0	33	0	0	0	0	0	0	0	71.01	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	15	37	0	32	0	0	0	0	0	0	0	71.04	0	0	13
2014	7	24	15	47	0	33	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	24	15	57	0	32	0	0	0	0	0	0	0	71.1	0	0	13
2014	7	24	16	7	0	32	0	0	0	0	0	0	0	71.1	0	0	13
2014	7	24	16	17	0	33	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	24	16	27	0	32	0	0	0	0	0	0	0	71.13	0	0	12.8
2014	7	24	16	37	0	31	0	0	0	0	0	0	0	71.13	0	0	12.8
2014	7	24	16	47	0	32	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	24	16	57	0	32	0	0	0	0	0	0	0	71.15	0	0	12.8
2014	7	24	17	7	0	32	0	0	0	0	0	0	0	71.17	0	0	12.8
2014	7	24	17	17	0	32	0	0	0	0	0	0	0	71.17	0	0	12.4
2014	7	24	17	27	0	32	0	0	0	0	0	0	0	71.15	0	0	12.4
2014	7	24	17	37	0	32	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	24	17	47	0	32	0	0	0	0	0	0	0	71.13	0	0	12
2014	7	24	17	57	0	32	0	0	0	0	0	0	0	71.11	0	0	11.8
2014	7	24	18	7	0	32	0	0	0	0	0	0	0	71.11	0	0	11.6
2014	7	24	18	17	0	32	0	0	0	0	0	0	0	71.11	0	0	11.4
2014	7	24	18	27	0	32	0	0	0	0	0	0	0	71.11	0	0	11.4
2014	7	24	18	37	0	32	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	18	47	0	32	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	18	57	0	32	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	19	7	0	32	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	19	17	0	33	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	24	19	27	0	32	0	0	0	0	0	0	0	71.11	0	0	10.8
2014	7	24	19	37	0	32	0	0	0	0	0	0	0	71.11	0	0	10.8
2014	7	24	19	47	0	32	0	0	0	0	0	0	0	71.1	0	0	10.6
2014	7	24	19	57	0	32	0	0	0	0	0	0	0	71.08	0	0	10.6
2014	7	24	20	7	0	32	0	0	0	0	0	0	0	71.06	0	0	10.6
2014	7	24	20	17	0	32	0	0	0	0	0	0	0	71.06	0	0	11.2
2014	7	24	20	27	0	32	0	0	0	0	0	0	0	71.04	0	0	11.2
2014	7	24	20	37	0	32	0	0	0	0	0	0	0	71.02	0	0	11.2
2014	7	24	20	47	0	32	0	0	0	0	0	0	0	71.01	0	0	11.2
2014	7	24	20	57	0	32	0	0	0	0	0	0	0	70.99	0	0	11.2
2014	7	24	21	7	0	33	0	0	0	0	0	0	0	70.95	0	0	11.2
2014	7	24	21	17	0	32	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	24	21	27	0	33	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	24	21	37	0	33	0	0	0	0	0	0	0	70.86	0	0	11.2
2014	7	24	21	47	0	32	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	24	21	57	0	32	0	0	0	0	0	0	0	70.79	0	0	11.2
2014	7	24	22	7	0	33	0	0	0	0	0	0	0	70.75	0	0	11.2
2014	7	24	22	17	0	32	0	0	0	0	0	0	0	70.7	0	0	11
2014	7	24	22	27	0	32	0	0	0	0	0	0	0	70.66	0	0	11.4
2014	7	24	22	37	0	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	24	22	47	0	32	0	0	0	0	0	0	0	70.59	0	0	11.6
2014	7	24	22	57	0	33	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	24	23	7	0	32	0	0	0	0	0	0	0	70.5	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	24	23	17	0	33	0	0	0	0	0	0	0	70.47	0	0	11.6
2014	7	24	23	27	0	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	24	23	37	0	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	24	23	47	0	33	0	0	0	0	0	0	0	70.36	0	0	11
2014	7	24	23	57	0	33	0	0	0	0	0	0	0	70.32	0	0	11.2
2014	7	25	0	7	0	33	0	0	0	0	0	0	0	70.27	0	0	11.2
2014	7	25	0	17	0	32	0	0	0	0	0	0	0	70.23	0	0	11.2
2014	7	25	0	27	0	33	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	25	0	37	0	32	0	0	0	0	0	0	0	70.16	0	0	11.6
2014	7	25	0	47	0	33	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	25	0	57	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	25	1	7	0	33	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	25	1	17	0	32	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	25	1	27	0	32	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	25	1	37	0	32	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	25	1	47	0	32	0	0	0	0	0	0	0	69.91	0	0	11.6
2014	7	25	1	57	0	32	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	25	2	7	0	32	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	25	2	17	0	32	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	25	2	27	0	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	25	2	37	0	33	0	0	0	0	0	0	0	69.75	0	0	11.6
2014	7	25	2	47	0	32	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	25	2	57	0	33	0	0	0	0	0	0	0	69.66	0	0	11.6
2014	7	25	3	7	0	32	0	0	0	0	0	0	0	69.62	0	0	11.6
2014	7	25	3	17	0	33	0	0	0	0	0	0	0	69.58	0	0	11.6
2014	7	25	3	27	0	31	0	0	0	0	0	0	0	69.55	0	0	11.6
2014	7	25	3	37	0	33	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	25	3	47	0	32	0	0	0	0	0	0	0	69.44	0	0	11.6
2014	7	25	3	57	0	33	0	0	0	0	0	0	0	69.39	0	0	11.2
2014	7	25	4	7	0	32	0	0	0	0	0	0	0	69.33	0	0	11.4
2014	7	25	4	17	0	33	0	0	0	0	0	0	0	69.26	0	0	11.6
2014	7	25	4	27	0	33	0	0	0	0	0	0	0	69.21	0	0	11.6
2014	7	25	4	37	0	32	0	0	0	0	0	0	0	69.15	0	0	11.6
2014	7	25	4	47	0	32	0	0	0	0	0	0	0	69.08	0	0	11.6
2014	7	25	4	57	0	33	0	0	0	0	0	0	0	69.03	0	0	11.6
2014	7	25	5	7	0	33	0	0	0	0	0	0	0	68.95	0	0	11.6
2014	7	25	5	17	0	33	0	0	0	0	0	0	0	68.9	0	0	11.6
2014	7	25	5	27	0	33	0	0	0	0	0	0	0	68.85	0	0	11.6
2014	7	25	5	37	0	33	0	0	0	0	0	0	0	68.77	0	0	11.6
2014	7	25	5	47	0	32	0	0	0	0	0	0	0	68.72	0	0	11.6
2014	7	25	5	57	0	33	0	0	0	0	0	0	0	68.65	0	0	11.6
2014	7	25	6	7	0	33	0	0	0	0	0	0	0	68.59	0	0	11.6
2014	7	25	6	17	0	32	0	0	0	0	0	0	0	68.54	0	0	11.6
2014	7	25	6	27	0	32	0	0	0	0	0	0	0	68.49	0	0	11.6
2014	7	25	6	37	0	32	0	0	0	0	0	0	0	68.43	0	0	11.2
2014	7	25	6	47	0	34	0	0	0	0	0	0	0	68.38	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	6	57	0	33	0	0	0	0	0	0	0	68.32	0	0	11
2014	7	25	7	7	0	33	0	0	0	0	0	0	0	68.27	0	0	11.2
2014	7	25	7	17	0	33	0	0	0	0	0	0	0	68.25	0	0	11.4
2014	7	25	7	27	0	33	0	0	0	0	0	0	0	68.23	0	0	11.8
2014	7	25	7	37	0	32	0	0	0	0	0	0	0	68.23	0	0	12
2014	7	25	7	47	0	33	0	0	0	0	0	0	0	68.22	0	0	12.2
2014	7	25	7	57	0	33	0	0	0	0	0	0	0	68.22	0	0	12.2
2014	7	25	8	7	0	33	0	0	0	0	0	0	0	68.23	0	0	12.4
2014	7	25	8	17	0	33	0	0	0	0	0	0	0	68.23	0	0	12.4
2014	7	25	8	27	0	33	0	0	0	0	0	0	0	68.23	0	0	12.4
2014	7	25	8	37	0	33	0	0	0	0	0	0	0	68.27	0	0	12.4
2014	7	25	8	47	0	32	0	0	0	0	0	0	0	68.29	0	0	12.6
2014	7	25	8	57	0	32	0	0	0	0	0	0	0	68.32	0	0	12.6
2014	7	25	9	7	0	32	0	0	0	0	0	0	0	68.38	0	0	12.6
2014	7	25	9	17	0	33	0	0	0	0	0	0	0	68.41	0	0	13
2014	7	25	9	27	0	32	0	0	0	0	0	0	0	68.47	0	0	13
2014	7	25	9	37	0	32	0	0	0	0	0	0	0	68.52	0	0	13
2014	7	25	9	47	0	32	0	0	0	0	0	0	0	68.58	0	0	13.2
2014	7	25	9	57	0	32	0	0	0	0	0	0	0	68.63	0	0	13.4
2014	7	25	10	7	0	33	0	0	0	0	0	0	0	68.7	0	0	13.8
2014	7	25	10	17	0	33	0	0	0	0	0	0	0	68.74	0	0	13.8
2014	7	25	10	27	0	32	0	0	0	0	0	0	0	68.81	0	0	14
2014	7	25	10	37	0	33	0	0	0	0	0	0	0	68.86	0	0	14
2014	7	25	10	47	0	32	0	0	0	0	0	0	0	68.95	0	0	13.8
2014	7	25	10	57	0	32	0	0	0	0	0	0	0	69.04	0	0	13.4
2014	7	25	11	7	0	33	0	0	0	0	0	0	0	69.12	0	0	13.6
2014	7	25	11	17	0	33	0	0	0	0	0	0	0	69.21	0	0	13.6
2014	7	25	11	27	0	32	0	0	0	0	0	0	0	69.28	0	0	13.4
2014	7	25	11	37	0	33	0	0	0	0	0	0	0	69.33	0	0	13.6
2014	7	25	11	47	0	32	0	0	0	0	0	0	0	69.42	0	0	13.6
2014	7	25	11	57	0	32	0	0	0	0	0	0	0	69.48	0	0	13.4
2014	7	25	12	7	0	32	0	0	0	0	0	0	0	69.57	0	0	13.6
2014	7	25	12	17	0	33	0	0	0	0	0	0	0	69.66	0	0	13.6
2014	7	25	12	27	0	33	0	0	0	0	0	0	0	69.73	0	0	13.6
2014	7	25	12	37	0	32	0	0	0	0	0	0	0	69.82	0	0	13.6
2014	7	25	12	47	0	33	0	0	0	0	0	0	0	69.91	0	0	13.8
2014	7	25	12	57	0	33	0	0	0	0	0	0	0	70	0	0	13.8
2014	7	25	13	7	0	33	0	0	0	0	0	0	0	70.07	0	0	13.8
2014	7	25	13	17	0	32	0	0	0	0	0	0	0	70.14	0	0	13.8
2014	7	25	13	27	0	33	0	0	0	0	0	0	0	70.21	0	0	13.8
2014	7	25	13	37	0	32	0	0	0	0	0	0	0	70.29	0	0	13.8
2014	7	25	13	47	0	32	0	0	0	0	0	0	0	70.36	0	0	13.6
2014	7	25	13	57	0	33	0	0	0	0	0	0	0	70.43	0	0	13.6
2014	7	25	14	7	0	32	0	0	0	0	0	0	0	70.5	0	0	13.6
2014	7	25	14	17	0	33	0	0	0	0	0	0	0	70.57	0	0	13.4
2014	7	25	14	27	0	33	0	0	0	0	0	0	0	70.66	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	14	37	0	32	0	0	0	0	0	0	0	70.72	0	0	13.4
2014	7	25	14	47	0	32	0	0	0	0	0	0	0	70.77	0	0	13.2
2014	7	25	14	57	0	32	0	0	0	0	0	0	0	70.83	0	0	13.2
2014	7	25	15	7	0	32	0	0	0	0	0	0	0	70.88	0	0	13.2
2014	7	25	15	17	0	32	0	0	0	0	0	0	0	70.92	0	0	13.2
2014	7	25	15	27	0	33	0	0	0	0	0	0	0	70.97	0	0	13.2
2014	7	25	15	37	0	33	0	0	0	0	0	0	0	70.99	0	0	13.4
2014	7	25	15	47	0	32	0	0	0	0	0	0	0	71.02	0	0	13.2
2014	7	25	15	57	0	32	0	0	0	0	0	0	0	71.04	0	0	13.2
2014	7	25	16	7	0	32	0	0	0	0	0	0	0	71.06	0	0	13.2
2014	7	25	16	17	0	32	0	0	0	0	0	0	0	71.08	0	0	13.2
2014	7	25	16	27	0	32	0	0	0	0	0	0	0	71.1	0	0	13.2
2014	7	25	16	37	0	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	25	16	47	0	32	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	25	16	57	0	32	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	25	17	7	0	32	0	0	0	0	0	0	0	71.13	0	0	12.8
2014	7	25	17	17	0	33	0	0	0	0	0	0	0	71.11	0	0	12.6
2014	7	25	17	27	0	32	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	25	17	37	0	33	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	25	17	47	0	33	0	0	0	0	0	0	0	71.1	0	0	12.4
2014	7	25	17	57	0	32	0	0	0	0	0	0	0	71.08	0	0	12.4
2014	7	25	18	7	0	32	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	7	25	18	17	0	32	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	25	18	27	0	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	25	18	37	0	33	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	25	18	47	0	32	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	25	18	57	0	32	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	25	19	7	0	32	0	0	0	0	0	0	0	71.06	0	0	11.4
2014	7	25	19	17	0	32	0	0	0	0	0	0	0	71.04	0	0	11.2
2014	7	25	19	27	0	33	0	0	0	0	0	0	0	71.04	0	0	11.2
2014	7	25	19	37	0	32	0	0	0	0	0	0	0	71.04	0	0	11.2
2014	7	25	19	47	0	32	0	0	0	0	0	0	0	71.01	0	0	11
2014	7	25	19	57	0	32	0	0	0	0	0	0	0	71.01	0	0	11
2014	7	25	20	7	0	33	0	0	0	0	0	0	0	70.99	0	0	11
2014	7	25	20	17	0	33	0	0	0	0	0	0	0	70.97	0	0	11.8
2014	7	25	20	27	0	33	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	25	20	37	0	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2014	7	25	20	47	0	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2014	7	25	20	57	0	32	0	0	0	0	0	0	0	70.88	0	0	11.8
2014	7	25	21	7	0	33	0	0	0	0	0	0	0	70.84	0	0	11.8
2014	7	25	21	17	0	33	0	0	0	0	0	0	0	70.83	0	0	11.8
2014	7	25	21	27	0	33	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	25	21	37	0	32	0	0	0	0	0	0	0	70.77	0	0	11.8
2014	7	25	21	47	0	32	0	0	0	0	0	0	0	70.75	0	0	11.8
2014	7	25	21	57	0	32	0	0	0	0	0	0	0	70.72	0	0	11.8
2014	7	25	22	7	0	32	0	0	0	0	0	0	0	70.7	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	25	22	17	0	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2014	7	25	22	27	0	33	0	0	0	0	0	0	0	70.61	0	0	11.8
2014	7	25	22	37	0	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2014	7	25	22	47	0	32	0	0	0	0	0	0	0	70.54	0	0	11.8
2014	7	25	22	57	0	33	0	0	0	0	0	0	0	70.5	0	0	11.8
2014	7	25	23	7	0	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2014	7	25	23	17	0	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2014	7	25	23	27	0	32	0	0	0	0	0	0	0	70.34	0	0	11.8
2014	7	25	23	37	0	33	0	0	0	0	0	0	0	70.3	0	0	11.8
2014	7	25	23	47	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	25	23	57	0	32	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	26	0	7	0	32	0	0	0	0	0	0	0	70.14	0	0	11.6
2014	7	26	0	17	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	26	0	27	0	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	26	0	37	0	33	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	26	0	47	0	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	26	0	57	0	32	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	26	1	7	0	32	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	26	1	17	0	33	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	26	1	27	0	33	0	0	0	0	0	0	0	69.71	0	0	11.6
2014	7	26	1	37	0	32	0	0	0	0	0	0	0	69.66	0	0	11.6
2014	7	26	1	47	0	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	26	1	57	0	32	0	0	0	0	0	0	0	69.55	0	0	11.6
2014	7	26	2	7	0	32	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	26	2	17	0	32	0	0	0	0	0	0	0	69.44	0	0	11.6
2014	7	26	2	27	0	33	0	0	0	0	0	0	0	69.37	0	0	11.6
2014	7	26	2	37	0	33	0	0	0	0	0	0	0	69.31	0	0	11.6
2014	7	26	2	47	0	33	0	0	0	0	0	0	0	69.26	0	0	11.6
2014	7	26	2	57	0	33	0	0	0	0	0	0	0	69.21	0	0	11.6
2014	7	26	3	7	0	32	0	0	0	0	0	0	0	69.15	0	0	11.6
2014	7	26	3	17	0	32	0	0	0	0	0	0	0	69.1	0	0	11.6
2014	7	26	3	27	0	32	0	0	0	0	0	0	0	69.03	0	0	11.6
2014	7	26	3	37	0	31	0	0	0	0	0	0	0	68.99	0	0	11.6
2014	7	26	3	47	0	32	0	0	0	0	0	0	0	68.92	0	0	11.6
2014	7	26	3	57	0	33	0	0	0	0	0	0	0	68.86	0	0	11.6
2014	7	26	4	7	0	32	0	0	0	0	0	0	0	68.81	0	0	11.6
2014	7	26	4	17	0	32	0	0	0	0	0	0	0	68.76	0	0	11.6
2014	7	26	4	27	0	32	0	0	0	0	0	0	0	68.7	0	0	11.6
2014	7	26	4	37	0	32	0	0	0	0	0	0	0	68.63	0	0	11.6
2014	7	26	4	47	0	32	0	0	0	0	0	0	0	68.58	0	0	11.6
2014	7	26	4	57	0	33	0	0	0	0	0	0	0	68.52	0	0	11.6
2014	7	26	5	7	0	32	0	0	0	0	0	0	0	68.47	0	0	11.6
2014	7	26	5	17	0	33	0	0	0	0	0	0	0	68.41	0	0	11.6
2014	7	26	5	27	0	33	0	0	0	0	0	0	0	68.34	0	0	11.6
2014	7	26	5	37	0	33	0	0	0	0	0	0	0	68.31	0	0	11.6
2014	7	26	5	47	0	33	0	0	0	0	0	0	0	68.25	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	5	57	0	32	0	0	0	0	0	0	0	68.2	0	0	11.6
2014	7	26	6	7	0	32	0	0	0	0	0	0	0	68.16	0	0	11.6
2014	7	26	6	17	0	32	0	0	0	0	0	0	0	68.11	0	0	11.6
2014	7	26	6	27	0	32	0	0	0	0	0	0	0	68.07	0	0	11.6
2014	7	26	6	37	0	33	0	0	0	0	0	0	0	68.02	0	0	11.6
2014	7	26	6	47	0	33	0	0	0	0	0	0	0	67.98	0	0	11.6
2014	7	26	6	57	0	33	0	0	0	0	0	0	0	67.95	0	0	11.8
2014	7	26	7	7	0	33	0	0	0	0	0	0	0	67.91	0	0	11.8
2014	7	26	7	17	0	33	0	0	0	0	0	0	0	67.89	0	0	12
2014	7	26	7	27	0	33	0	0	0	0	0	0	0	67.89	0	0	12
2014	7	26	7	37	0	33	0	0	0	0	0	0	0	67.87	0	0	12.2
2014	7	26	7	47	0	33	0	0	0	0	0	0	0	67.87	0	0	12.2
2014	7	26	7	57	0	32	0	0	0	0	0	0	0	67.86	0	0	12.4
2014	7	26	8	7	0	33	0	0	0	0	0	0	0	67.87	0	0	12.6
2014	7	26	8	17	0	33	0	0	0	0	0	0	0	67.89	0	0	13
2014	7	26	8	27	0	33	0	0	0	0	0	0	0	67.87	0	0	12.6
2014	7	26	8	37	0	33	0	0	0	0	0	0	0	67.86	0	0	12.6
2014	7	26	8	47	0	32	0	0	0	0	0	0	0	67.89	0	0	13
2014	7	26	8	57	0	33	0	0	0	0	0	0	0	67.91	0	0	13.2
2014	7	26	9	7	0	32	0	0	0	0	0	0	0	67.93	0	0	13.4
2014	7	26	9	17	0	32	0	0	0	0	0	0	0	67.98	0	0	12.6
2014	7	26	9	27	0	32	0	0	0	0	0	0	0	68.04	0	0	13
2014	7	26	9	37	0	32	0	0	0	0	0	0	0	68.13	0	0	14
2014	7	26	9	47	0	33	0	0	0	0	0	0	0	68.2	0	0	14
2014	7	26	9	57	0	32	0	0	0	0	0	0	0	68.23	0	0	14
2014	7	26	10	7	0	33	0	0	0	0	0	0	0	68.27	0	0	14
2014	7	26	10	17	0	32	0	0	0	0	0	0	0	68.36	0	0	13.8
2014	7	26	10	27	0	33	0	0	0	0	0	0	0	68.43	0	0	13.8
2014	7	26	10	37	0	33	0	0	0	0	0	0	0	68.5	0	0	13.8
2014	7	26	10	47	0	31	0	0	0	0	0	0	0	68.5	0	0	13.6
2014	7	26	10	57	0	33	0	0	0	0	0	0	0	68.52	0	0	13.8
2014	7	26	11	7	0	32	0	0	0	0	0	0	0	68.68	0	0	13.8
2014	7	26	11	17	0	33	0	0	0	0	0	0	0	68.67	0	0	13.4
2014	7	26	11	27	0	32	0	0	0	0	0	0	0	68.74	0	0	13.4
2014	7	26	11	37	0	33	0	0	0	0	0	0	0	68.83	0	0	13.6
2014	7	26	11	47	0	34	0	0	0	0	0	0	0	68.92	0	0	13.4
2014	7	26	11	57	0	32	0	0	0	0	0	0	0	68.97	0	0	13.4
2014	7	26	12	7	0	32	0	0	0	0	0	0	0	69.06	0	0	13.4
2014	7	26	12	17	0	33	0	0	0	0	0	0	0	69.12	0	0	13.4
2014	7	26	12	27	0	32	0	0	0	0	0	0	0	69.24	0	0	13.2
2014	7	26	12	37	0	33	0	0	0	0	0	0	0	69.3	0	0	13.2
2014	7	26	12	47	0	32	0	0	0	0	0	0	0	69.33	0	0	13.2
2014	7	26	12	57	0	32	0	0	0	0	0	0	0	69.42	0	0	13
2014	7	26	13	7	0	33	0	0	0	0	0	0	0	69.44	0	0	12.8
2014	7	26	13	17	0	32	0	0	0	0	0	0	0	69.58	0	0	13.2
2014	7	26	13	27	0	32	0	0	0	0	0	0	0	69.67	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	13	37	0	32	0	0	0	0	0	0	0	69.75	0	0	13.2
2014	7	26	13	47	0	33	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	26	13	57	0	33	0	0	0	0	0	0	0	69.84	0	0	13.2
2014	7	26	14	7	0	32	0	0	0	0	0	0	0	69.87	0	0	13
2014	7	26	14	17	0	33	0	0	0	0	0	0	0	69.82	0	0	13.2
2014	7	26	14	27	0	32	0	0	0	0	0	0	0	69.82	0	0	13.4
2014	7	26	14	37	0	32	0	0	0	0	0	0	0	69.91	0	0	13.4
2014	7	26	14	47	0	33	0	0	0	0	0	0	0	70.07	0	0	13.2
2014	7	26	14	57	0	32	0	0	0	0	0	0	0	70.07	0	0	13
2014	7	26	15	7	0	32	0	0	0	0	0	0	0	70.18	0	0	13.2
2014	7	26	15	17	0	33	0	0	0	0	0	0	0	70.21	0	0	13
2014	7	26	15	27	0	33	0	0	0	0	0	0	0	70.27	0	0	13
2014	7	26	15	37	0	32	0	0	0	0	0	0	0	70.3	0	0	13
2014	7	26	15	47	0	32	0	0	0	0	0	0	0	70.32	0	0	13
2014	7	26	15	57	0	32	0	0	0	0	0	0	0	70.36	0	0	13
2014	7	26	16	7	0	33	0	0	0	0	0	0	0	70.38	0	0	13
2014	7	26	16	17	0	32	0	0	0	0	0	0	0	70.38	0	0	12.8
2014	7	26	16	27	0	32	0	0	0	0	0	0	0	70.39	0	0	12.8
2014	7	26	16	37	0	32	0	0	0	0	0	0	0	70.41	0	0	12.8
2014	7	26	16	47	0	33	0	0	0	0	0	0	0	70.43	0	0	13
2014	7	26	16	57	0	32	0	0	0	0	0	0	0	70.43	0	0	13
2014	7	26	17	7	0	32	0	0	0	0	0	0	0	70.43	0	0	12.4
2014	7	26	17	17	0	32	0	0	0	0	0	0	0	70.43	0	0	12.4
2014	7	26	17	27	0	33	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	26	17	37	0	32	0	0	0	0	0	0	0	70.45	0	0	12.2
2014	7	26	17	47	0	32	0	0	0	0	0	0	0	70.47	0	0	12.2
2014	7	26	17	57	0	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2014	7	26	18	7	0	32	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	26	18	17	0	32	0	0	0	0	0	0	0	70.43	0	0	11.2
2014	7	26	18	27	0	32	0	0	0	0	0	0	0	70.43	0	0	11.2
2014	7	26	18	37	0	32	0	0	0	0	0	0	0	70.43	0	0	11.2
2014	7	26	18	47	0	32	0	0	0	0	0	0	0	70.41	0	0	11.2
2014	7	26	18	57	0	33	0	0	0	0	0	0	0	70.41	0	0	11
2014	7	26	19	7	0	32	0	0	0	0	0	0	0	70.41	0	0	11
2014	7	26	19	17	0	33	0	0	0	0	0	0	0	70.39	0	0	10.8
2014	7	26	19	27	0	33	0	0	0	0	0	0	0	70.39	0	0	10.8
2014	7	26	19	37	0	31	0	0	0	0	0	0	0	70.38	0	0	10.8
2014	7	26	19	47	0	32	0	0	0	0	0	0	0	70.38	0	0	10.8
2014	7	26	19	57	0	32	0	0	0	0	0	0	0	70.36	0	0	10.6
2014	7	26	20	7	0	33	0	0	0	0	0	0	0	70.34	0	0	10.6
2014	7	26	20	17	0	32	0	0	0	0	0	0	0	70.34	0	0	10.8
2014	7	26	20	27	0	32	0	0	0	0	0	0	0	70.32	0	0	10.8
2014	7	26	20	37	0	32	0	0	0	0	0	0	0	70.29	0	0	10.6
2014	7	26	20	47	0	32	0	0	0	0	0	0	0	70.27	0	0	10.6
2014	7	26	20	57	0	31	0	0	0	0	0	0	0	70.25	0	0	10.6
2014	7	26	21	7	0	32	0	0	0	0	0	0	0	70.23	0	0	10.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	26	21	17	0	31	0	0	0	0	0	0	0	70.21	0	0	11.6
2014	7	26	21	27	0	32	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	26	21	37	0	31	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	26	21	47	0	33	0	0	0	0	0	0	0	70.14	0	0	11.6
2014	7	26	21	57	0	32	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	26	22	7	0	32	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	26	22	17	0	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	26	22	27	0	33	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	26	22	37	0	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	26	22	47	0	32	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	26	22	57	0	32	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	26	23	7	0	32	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	26	23	17	0	32	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	26	23	27	0	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	26	23	37	0	32	0	0	0	0	0	0	0	69.93	0	0	11.6
2014	7	26	23	47	0	32	0	0	0	0	0	0	0	69.89	0	0	11.6
2014	7	26	23	57	0	33	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	27	0	7	0	33	0	0	0	0	0	0	0	69.87	0	0	11.6
2014	7	27	0	17	0	32	0	0	0	0	0	0	0	69.84	0	0	11.6
2014	7	27	0	27	0	32	0	0	0	0	0	0	0	69.82	0	0	11.6
2014	7	27	0	37	0	33	0	0	0	0	0	0	0	69.8	0	0	11.6
2014	7	27	0	47	0	32	0	0	0	0	0	0	0	69.78	0	0	11.6
2014	7	27	0	57	0	32	0	0	0	0	0	0	0	69.76	0	0	11.6
2014	7	27	1	7	0	33	0	0	0	0	0	0	0	69.73	0	0	11.6
2014	7	27	1	17	0	32	0	0	0	0	0	0	0	69.69	0	0	11.6
2014	7	27	1	27	0	33	0	0	0	0	0	0	0	69.67	0	0	11.6
2014	7	27	1	37	0	33	0	0	0	0	0	0	0	69.64	0	0	11.6
2014	7	27	1	47	0	32	0	0	0	0	0	0	0	69.6	0	0	11.6
2014	7	27	1	57	0	33	0	0	0	0	0	0	0	69.57	0	0	11.6
2014	7	27	2	7	0	32	0	0	0	0	0	0	0	69.53	0	0	11.6
2014	7	27	2	17	0	32	0	0	0	0	0	0	0	69.49	0	0	11.6
2014	7	27	2	27	0	32	0	0	0	0	0	0	0	69.46	0	0	11.6
2014	7	27	2	37	0	33	0	0	0	0	0	0	0	69.42	0	0	11.6
2014	7	27	2	47	0	32	0	0	0	0	0	0	0	69.39	0	0	11.6
2014	7	27	2	57	0	32	0	0	0	0	0	0	0	69.33	0	0	11.6
2014	7	27	3	7	0	33	0	0	0	0	0	0	0	69.31	0	0	11.6
2014	7	27	3	17	0	32	0	0	0	0	0	0	0	69.28	0	0	11.6
2014	7	27	3	27	0	33	0	0	0	0	0	0	0	69.22	0	0	11.6
2014	7	27	3	37	0	32	0	0	0	0	0	0	0	69.19	0	0	11.6
2014	7	27	3	47	0	32	0	0	0	0	0	0	0	69.15	0	0	11.6
2014	7	27	3	57	0	33	0	0	0	0	0	0	0	69.1	0	0	11.6
2014	7	27	4	7	0	32	0	0	0	0	0	0	0	69.06	0	0	11.6
2014	7	27	4	17	0	33	0	0	0	0	0	0	0	69.03	0	0	11.6
2014	7	27	4	27	0	32	0	0	0	0	0	0	0	68.99	0	0	11.6
2014	7	27	4	37	0	32	0	0	0	0	0	0	0	68.94	0	0	11.6
2014	7	27	4	47	0	32	0	0	0	0	0	0	0	68.9	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	4	57	0	32	0	0	0	0	0	0	0	68.86	0	0	11.6
2014	7	27	5	7	0	32	0	0	0	0	0	0	0	68.83	0	0	11.6
2014	7	27	5	17	0	32	0	0	0	0	0	0	0	68.79	0	0	11.6
2014	7	27	5	27	0	33	0	0	0	0	0	0	0	68.77	0	0	11.6
2014	7	27	5	37	0	33	0	0	0	0	0	0	0	68.74	0	0	11.6
2014	7	27	5	47	0	32	0	0	0	0	0	0	0	68.72	0	0	11.6
2014	7	27	5	57	0	33	0	0	0	0	0	0	0	68.68	0	0	11.6
2014	7	27	6	7	0	33	0	0	0	0	0	0	0	68.67	0	0	11.6
2014	7	27	6	17	0	33	0	0	0	0	0	0	0	68.65	0	0	11.6
2014	7	27	6	27	0	33	0	0	0	0	0	0	0	68.63	0	0	11.6
2014	7	27	6	37	0	34	0	0	0	0	0	0	0	68.61	0	0	11.6
2014	7	27	6	47	0	33	0	0	0	0	0	0	0	68.59	0	0	11.6
2014	7	27	6	57	0	32	0	0	0	0	0	0	0	68.58	0	0	11.6
2014	7	27	7	7	0	33	0	0	0	0	0	0	0	68.56	0	0	11.6
2014	7	27	7	17	0	32	0	0	0	0	0	0	0	68.56	0	0	11.6
2014	7	27	7	27	0	32	0	0	0	0	0	0	0	68.54	0	0	11.6
2014	7	27	7	37	0	33	0	0	0	0	0	0	0	68.54	0	0	11.6
2014	7	27	7	47	0	33	0	0	0	0	0	0	0	68.54	0	0	11.8
2014	7	27	7	57	0	33	0	0	0	0	0	0	0	68.58	0	0	12
2014	7	27	8	7	0	34	0	0	0	0	0	0	0	68.56	0	0	11.8
2014	7	27	8	17	0	32	0	0	0	0	0	0	0	68.56	0	0	11.8
2014	7	27	8	27	0	33	0	0	0	0	0	0	0	68.54	0	0	11.8
2014	7	27	8	37	0	32	0	0	0	0	0	0	0	68.54	0	0	11.8
2014	7	27	8	47	0	33	0	0	0	0	0	0	0	68.56	0	0	11.8
2014	7	27	8	57	0	33	0	0	0	0	0	0	0	68.61	0	0	12
2014	7	27	9	7	0	33	0	0	0	0	0	0	0	68.59	0	0	12
2014	7	27	9	17	0	33	0	0	0	0	0	0	0	68.67	0	0	12.2
2014	7	27	9	27	0	33	0	0	0	0	0	0	0	68.76	0	0	12.4
2014	7	27	9	37	0	33	0	0	0	0	0	0	0	68.85	0	0	12.6
2014	7	27	9	47	0	32	0	0	0	0	0	0	0	68.77	0	0	12.2
2014	7	27	9	57	0	33	0	0	0	0	0	0	0	68.86	0	0	12.4
2014	7	27	10	7	0	33	0	0	0	0	0	0	0	68.95	0	0	12.6
2014	7	27	10	17	0	32	0	0	0	0	0	0	0	69.01	0	0	12.6
2014	7	27	10	27	0	32	0	0	0	0	0	0	0	69.06	0	0	12.6
2014	7	27	10	37	0	32	0	0	0	0	0	0	0	69.12	0	0	12.6
2014	7	27	10	47	0	33	0	0	0	0	0	0	0	69.17	0	0	12.6
2014	7	27	10	57	0	33	0	0	0	0	0	0	0	69.22	0	0	12.6
2014	7	27	11	7	0	33	0	0	0	0	0	0	0	69.3	0	0	12.8
2014	7	27	11	17	0	32	0	0	0	0	0	0	0	69.37	0	0	12.8
2014	7	27	11	27	0	32	0	0	0	0	0	0	0	69.44	0	0	12.8
2014	7	27	11	37	0	33	0	0	0	0	0	0	0	69.42	0	0	12.8
2014	7	27	11	47	0	33	0	0	0	0	0	0	0	69.57	0	0	12.8
2014	7	27	11	57	0	32	0	0	0	0	0	0	0	69.66	0	0	13
2014	7	27	12	7	0	32	0	0	0	0	0	0	0	69.73	0	0	13.2
2014	7	27	12	17	0	32	0	0	0	0	0	0	0	69.78	0	0	13.2
2014	7	27	12	27	0	33	0	0	0	0	0	0	0	69.82	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	12	37	0	33	0	0	0	0	0	0	0	69.94	0	0	13.4
2014	7	27	12	47	0	32	0	0	0	0	0	0	0	69.93	0	0	13
2014	7	27	12	57	0	33	0	0	0	0	0	0	0	70.11	0	0	13.4
2014	7	27	13	7	0	32	0	0	0	0	0	0	0	70.18	0	0	13.4
2014	7	27	13	17	0	33	0	0	0	0	0	0	0	70.27	0	0	13.4
2014	7	27	13	27	0	32	0	0	0	0	0	0	0	70.3	0	0	12.6
2014	7	27	13	37	0	32	0	0	0	0	0	0	0	70.38	0	0	13.4
2014	7	27	13	47	0	33	0	0	0	0	0	0	0	70.47	0	0	13.4
2014	7	27	13	57	0	33	0	0	0	0	0	0	0	70.36	0	0	12.8
2014	7	27	14	7	0	33	0	0	0	0	0	0	0	70.39	0	0	12.8
2014	7	27	14	17	0	32	0	0	0	0	0	0	0	70.45	0	0	13
2014	7	27	14	27	0	33	0	0	0	0	0	0	0	70.48	0	0	13
2014	7	27	14	37	0	32	0	0	0	0	0	0	0	70.59	0	0	13.2
2014	7	27	14	47	0	32	0	0	0	0	0	0	0	70.74	0	0	13.4
2014	7	27	14	57	0	33	0	0	0	0	0	0	0	70.81	0	0	13.2
2014	7	27	15	7	0	32	0	0	0	0	0	0	0	70.86	0	0	13.2
2014	7	27	15	17	0	32	0	0	0	0	0	0	0	70.9	0	0	13.2
2014	7	27	15	27	0	32	0	0	0	0	0	0	0	70.95	0	0	13
2014	7	27	15	37	0	32	0	0	0	0	0	0	0	70.99	0	0	13
2014	7	27	15	47	0	32	0	0	0	0	0	0	0	71.02	0	0	13
2014	7	27	15	57	0	32	0	0	0	0	0	0	0	71.06	0	0	13
2014	7	27	16	7	0	32	0	0	0	0	0	0	0	71.06	0	0	12.8
2014	7	27	16	17	0	32	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	27	16	27	0	32	0	0	0	0	0	0	0	71.11	0	0	12.6
2014	7	27	16	37	0	33	0	0	0	0	0	0	0	71.13	0	0	12.6
2014	7	27	16	47	0	32	0	0	0	0	0	0	0	71.11	0	0	12.2
2014	7	27	16	57	0	32	0	0	0	0	0	0	0	71.1	0	0	12.4
2014	7	27	17	7	0	32	0	0	0	0	0	0	0	71.15	0	0	12.4
2014	7	27	17	17	0	32	0	0	0	0	0	0	0	71.15	0	0	12.4
2014	7	27	17	27	0	32	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	27	17	37	0	33	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	27	17	47	0	33	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	27	17	57	0	32	0	0	0	0	0	0	0	71.15	0	0	12
2014	7	27	18	7	0	32	0	0	0	0	0	0	0	71.17	0	0	12
2014	7	27	18	17	0	32	0	0	0	0	0	0	0	71.17	0	0	11.8
2014	7	27	18	27	0	33	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	18	37	0	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	18	47	0	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	18	57	0	33	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	19	7	0	32	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	19	17	0	33	0	0	0	0	0	0	0	71.19	0	0	11.6
2014	7	27	19	27	0	32	0	0	0	0	0	0	0	71.17	0	0	11.6
2014	7	27	19	37	0	32	0	0	0	0	0	0	0	71.15	0	0	11.6
2014	7	27	19	47	0	32	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	27	19	57	0	33	0	0	0	0	0	0	0	71.13	0	0	11.6
2014	7	27	20	7	0	33	0	0	0	0	0	0	0	71.11	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	27	20	17	0	32	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	27	20	27	0	32	0	0	0	0	0	0	0	71.1	0	0	11.6
2014	7	27	20	37	0	33	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	27	20	47	0	32	0	0	0	0	0	0	0	71.08	0	0	11.6
2014	7	27	20	57	0	33	0	0	0	0	0	0	0	71.06	0	0	11.6
2014	7	27	21	7	0	33	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	27	21	17	0	33	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	27	21	27	0	33	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	27	21	37	0	32	0	0	0	0	0	0	0	71.02	0	0	11.4
2014	7	27	21	47	0	32	0	0	0	0	0	0	0	71.01	0	0	11.4
2014	7	27	21	57	0	32	0	0	0	0	0	0	0	70.97	0	0	11.4
2014	7	27	22	7	0	33	0	0	0	0	0	0	0	70.97	0	0	11.4
2014	7	27	22	17	0	33	0	0	0	0	0	0	0	70.95	0	0	11.4
2014	7	27	22	27	0	32	0	0	0	0	0	0	0	70.95	0	0	11.4
2014	7	27	22	37	0	32	0	0	0	0	0	0	0	70.93	0	0	11.4
2014	7	27	22	47	0	32	0	0	0	0	0	0	0	70.92	0	0	11.4
2014	7	27	22	57	0	32	0	0	0	0	0	0	0	70.9	0	0	11.4
2014	7	27	23	7	0	32	0	0	0	0	0	0	0	70.9	0	0	11.4
2014	7	27	23	17	0	32	0	0	0	0	0	0	0	70.9	0	0	11.4
2014	7	27	23	27	0	32	0	0	0	0	0	0	0	70.88	0	0	11.4
2014	7	27	23	37	0	32	0	0	0	0	0	0	0	70.86	0	0	11.4
2014	7	27	23	47	0	32	0	0	0	0	0	0	0	70.86	0	0	11.4
2014	7	27	23	57	0	32	0	0	0	0	0	0	0	70.84	0	0	11.4
2014	7	28	0	7	0	32	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	28	0	17	0	32	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	28	0	27	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	28	0	37	0	32	0	0	0	0	0	0	0	70.77	0	0	11.4
2014	7	28	0	47	0	32	0	0	0	0	0	0	0	70.77	0	0	11.4
2014	7	28	0	57	0	32	0	0	0	0	0	0	0	70.75	0	0	11.4
2014	7	28	1	7	0	33	0	0	0	0	0	0	0	70.75	0	0	11.4
2014	7	28	1	17	0	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	28	1	27	0	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	28	1	37	0	32	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	28	1	47	0	32	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	28	1	57	0	32	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	28	2	7	0	32	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	28	2	17	0	32	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	28	2	27	0	33	0	0	0	0	0	0	0	70.68	0	0	11.4
2014	7	28	2	37	0	32	0	0	0	0	0	0	0	70.68	0	0	11.4
2014	7	28	2	47	0	32	0	0	0	0	0	0	0	70.66	0	0	11.4
2014	7	28	2	57	0	32	0	0	0	0	0	0	0	70.65	0	0	11.4
2014	7	28	3	7	0	32	0	0	0	0	0	0	0	70.65	0	0	11.4
2014	7	28	3	17	0	32	0	0	0	0	0	0	0	70.65	0	0	11.4
2014	7	28	3	27	0	32	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	28	3	37	0	32	0	0	0	0	0	0	0	70.63	0	0	11.4
2014	7	28	3	47	0	33	0	0	0	0	0	0	0	70.61	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	3	57	0	32	0	0	0	0	0	0	0	70.59	0	0	11.4
2014	7	28	4	7	0	32	0	0	0	0	0	0	0	70.59	0	0	11.4
2014	7	28	4	17	0	32	0	0	0	0	0	0	0	70.57	0	0	11.4
2014	7	28	4	27	0	33	0	0	0	0	0	0	0	70.56	0	0	11.4
2014	7	28	4	37	0	32	0	0	0	0	0	0	0	70.54	0	0	11.4
2014	7	28	4	47	0	32	0	0	0	0	0	0	0	70.54	0	0	11.4
2014	7	28	4	57	0	33	0	0	0	0	0	0	0	70.5	0	0	11.4
2014	7	28	5	7	0	32	0	0	0	0	0	0	0	70.48	0	0	11.4
2014	7	28	5	17	0	32	0	0	0	0	0	0	0	70.47	0	0	11.4
2014	7	28	5	27	0	32	0	0	0	0	0	0	0	70.45	0	0	11.4
2014	7	28	5	37	0	32	0	0	0	0	0	0	0	70.43	0	0	11.4
2014	7	28	5	47	0	32	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	28	5	57	0	33	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	28	6	7	0	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	28	6	17	0	32	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	28	6	27	0	32	0	0	0	0	0	0	0	70.34	0	0	11.6
2014	7	28	6	37	0	32	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	28	6	47	0	32	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	28	6	57	0	33	0	0	0	0	0	0	0	70.29	0	0	11.6
2014	7	28	7	7	0	32	0	0	0	0	0	0	0	70.29	0	0	11.6
2014	7	28	7	17	0	32	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	28	7	27	0	32	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	28	7	37	0	32	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	28	7	47	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	7	57	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	7	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	17	0	33	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	27	0	33	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	37	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	47	0	32	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	8	57	0	33	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	28	9	7	0	32	0	0	0	0	0	0	0	70.23	0	0	11.8
2014	7	28	9	17	0	33	0	0	0	0	0	0	0	70.25	0	0	11.8
2014	7	28	9	27	0	32	0	0	0	0	0	0	0	70.29	0	0	11.8
2014	7	28	9	37	0	32	0	0	0	0	0	0	0	70.3	0	0	12
2014	7	28	9	47	0	32	0	0	0	0	0	0	0	70.32	0	0	12
2014	7	28	9	57	0	32	0	0	0	0	0	0	0	70.32	0	0	12
2014	7	28	10	7	0	32	0	0	0	0	0	0	0	70.36	0	0	12
2014	7	28	10	17	0	33	0	0	0	0	0	0	0	70.38	0	0	12.2
2014	7	28	10	27	0	32	0	0	0	0	0	0	0	70.43	0	0	12.4
2014	7	28	10	37	0	32	0	0	0	0	0	0	0	70.5	0	0	12.6
2014	7	28	10	47	0	33	0	0	0	0	0	0	0	70.48	0	0	12.8
2014	7	28	10	57	0	32	0	0	0	0	0	0	0	70.47	0	0	12.2
2014	7	28	11	7	0	32	0	0	0	0	0	0	0	70.5	0	0	12.4
2014	7	28	11	17	0	32	0	0	0	0	0	0	0	70.54	0	0	12.4
2014	7	28	11	27	0	33	0	0	0	0	0	0	0	70.56	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	11	37	0	33	0	0	0	0	0	0	0	70.54	0	0	12.2
2014	7	28	11	47	0	32	0	0	0	0	0	0	0	70.54	0	0	12.2
2014	7	28	11	57	0	33	0	0	0	0	0	0	0	70.59	0	0	12.4
2014	7	28	12	7	0	32	0	0	0	0	0	0	0	70.75	0	0	12.8
2014	7	28	12	17	0	32	0	0	0	0	0	0	0	70.74	0	0	12.4
2014	7	28	12	27	0	32	0	0	0	0	0	0	0	70.7	0	0	12.2
2014	7	28	12	37	0	32	0	0	0	0	0	0	0	70.72	0	0	12.4
2014	7	28	12	47	0	32	0	0	0	0	0	0	0	70.77	0	0	12.4
2014	7	28	12	57	0	32	0	0	0	0	0	0	0	70.86	0	0	12.4
2014	7	28	13	7	0	32	0	0	0	0	0	0	0	70.88	0	0	12.4
2014	7	28	13	17	0	33	0	0	0	0	0	0	0	70.84	0	0	12.2
2014	7	28	13	27	0	32	0	0	0	0	0	0	0	70.83	0	0	12.2
2014	7	28	13	37	0	33	0	0	0	0	0	0	0	70.84	0	0	12.2
2014	7	28	13	47	0	32	0	0	0	0	0	0	0	70.88	0	0	12.2
2014	7	28	13	57	0	32	0	0	0	0	0	0	0	70.92	0	0	12.4
2014	7	28	14	7	0	32	0	0	0	0	0	0	0	70.93	0	0	12.4
2014	7	28	14	17	0	32	0	0	0	0	0	0	0	71.01	0	0	12.6
2014	7	28	14	27	0	33	0	0	0	0	0	0	0	71.11	0	0	13
2014	7	28	14	37	0	32	0	0	0	0	0	0	0	71.1	0	0	12.6
2014	7	28	14	47	0	32	0	0	0	0	0	0	0	71.11	0	0	12.8
2014	7	28	14	57	0	33	0	0	0	0	0	0	0	71.08	0	0	12.4
2014	7	28	15	7	0	32	0	0	0	0	0	0	0	71.08	0	0	12.2
2014	7	28	15	17	0	32	0	0	0	0	0	0	0	71.08	0	0	12
2014	7	28	15	27	0	32	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	28	15	37	0	31	0	0	0	0	0	0	0	71.08	0	0	12
2014	7	28	15	47	0	32	0	0	0	0	0	0	0	71.06	0	0	12
2014	7	28	15	57	0	32	0	0	0	0	0	0	0	71.08	0	0	12
2014	7	28	16	7	0	33	0	0	0	0	0	0	0	71.08	0	0	11.8
2014	7	28	16	17	0	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	16	27	0	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	16	37	0	31	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	16	47	0	32	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	16	57	0	33	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	17	7	0	33	0	0	0	0	0	0	0	71.06	0	0	11.8
2014	7	28	17	17	0	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	28	17	27	0	32	0	0	0	0	0	0	0	71.04	0	0	11.8
2014	7	28	17	37	0	32	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	28	17	47	0	32	0	0	0	0	0	0	0	71.02	0	0	11.8
2014	7	28	17	57	0	32	0	0	0	0	0	0	0	71.01	0	0	11.8
2014	7	28	18	7	0	32	0	0	0	0	0	0	0	71.01	0	0	11.8
2014	7	28	18	17	0	33	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	28	18	27	0	32	0	0	0	0	0	0	0	70.99	0	0	11.8
2014	7	28	18	37	0	32	0	0	0	0	0	0	0	70.97	0	0	11.8
2014	7	28	18	47	0	32	0	0	0	0	0	0	0	70.95	0	0	11.8
2014	7	28	18	57	0	32	0	0	0	0	0	0	0	70.93	0	0	11.6
2014	7	28	19	7	0	32	0	0	0	0	0	0	0	70.92	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	28	19	17	0	33	0	0	0	0	0	0	0	70.92	0	0	11.6
2014	7	28	19	27	0	33	0	0	0	0	0	0	0	70.9	0	0	11.6
2014	7	28	19	37	0	32	0	0	0	0	0	0	0	70.88	0	0	11.6
2014	7	28	19	47	0	33	0	0	0	0	0	0	0	70.86	0	0	11.6
2014	7	28	19	57	0	31	0	0	0	0	0	0	0	70.84	0	0	11.6
2014	7	28	20	7	0	32	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	28	20	17	0	32	0	0	0	0	0	0	0	70.83	0	0	11.6
2014	7	28	20	27	0	32	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	28	20	37	0	32	0	0	0	0	0	0	0	70.79	0	0	11.6
2014	7	28	20	47	0	32	0	0	0	0	0	0	0	70.77	0	0	11.6
2014	7	28	20	57	0	32	0	0	0	0	0	0	0	70.75	0	0	11.6
2014	7	28	21	7	0	32	0	0	0	0	0	0	0	70.74	0	0	11.6
2014	7	28	21	17	0	32	0	0	0	0	0	0	0	70.72	0	0	11.6
2014	7	28	21	27	0	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	28	21	37	0	33	0	0	0	0	0	0	0	70.68	0	0	11.6
2014	7	28	21	47	0	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	28	21	57	0	32	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	28	22	7	0	32	0	0	0	0	0	0	0	70.63	0	0	11.6
2014	7	28	22	17	0	32	0	0	0	0	0	0	0	70.61	0	0	11.6
2014	7	28	22	27	0	32	0	0	0	0	0	0	0	70.61	0	0	11.6
2014	7	28	22	37	0	32	0	0	0	0	0	0	0	70.57	0	0	11.6
2014	7	28	22	47	0	32	0	0	0	0	0	0	0	70.56	0	0	11.6
2014	7	28	22	57	0	32	0	0	0	0	0	0	0	70.54	0	0	11.6
2014	7	28	23	7	0	32	0	0	0	0	0	0	0	70.52	0	0	11.6
2014	7	28	23	17	0	33	0	0	0	0	0	0	0	70.5	0	0	11.6
2014	7	28	23	27	0	33	0	0	0	0	0	0	0	70.48	0	0	11.6
2014	7	28	23	37	0	32	0	0	0	0	0	0	0	70.47	0	0	11.6
2014	7	28	23	47	0	33	0	0	0	0	0	0	0	70.43	0	0	11.6
2014	7	28	23	57	0	33	0	0	0	0	0	0	0	70.41	0	0	11.6
2014	7	29	0	7	0	32	0	0	0	0	0	0	0	70.39	0	0	11.6
2014	7	29	0	17	0	32	0	0	0	0	0	0	0	70.38	0	0	11.6
2014	7	29	0	27	0	32	0	0	0	0	0	0	0	70.36	0	0	11.6
2014	7	29	0	37	0	33	0	0	0	0	0	0	0	70.34	0	0	11.6
2014	7	29	0	47	0	31	0	0	0	0	0	0	0	70.32	0	0	11.6
2014	7	29	0	57	0	32	0	0	0	0	0	0	0	70.3	0	0	11.6
2014	7	29	1	7	0	32	0	0	0	0	0	0	0	70.29	0	0	11.6
2014	7	29	1	17	0	32	0	0	0	0	0	0	0	70.27	0	0	11.6
2014	7	29	1	27	0	33	0	0	0	0	0	0	0	70.25	0	0	11.6
2014	7	29	1	37	0	33	0	0	0	0	0	0	0	70.23	0	0	11.6
2014	7	29	1	47	0	32	0	0	0	0	0	0	0	70.21	0	0	11.6
2014	7	29	1	57	0	31	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	29	2	7	0	33	0	0	0	0	0	0	0	70.2	0	0	11.6
2014	7	29	2	17	0	32	0	0	0	0	0	0	0	70.18	0	0	11.6
2014	7	29	2	27	0	32	0	0	0	0	0	0	0	70.16	0	0	11.6
2014	7	29	2	37	0	33	0	0	0	0	0	0	0	70.16	0	0	11.6
2014	7	29	2	47	0	33	0	0	0	0	0	0	0	70.12	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	2	57	0	32	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	29	3	7	0	32	0	0	0	0	0	0	0	70.12	0	0	11.6
2014	7	29	3	17	0	32	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	29	3	27	0	32	0	0	0	0	0	0	0	70.11	0	0	11.6
2014	7	29	3	37	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	29	3	47	0	32	0	0	0	0	0	0	0	70.09	0	0	11.6
2014	7	29	3	57	0	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	29	4	7	0	31	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	29	4	17	0	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	29	4	27	0	33	0	0	0	0	0	0	0	70.07	0	0	11.6
2014	7	29	4	37	0	33	0	0	0	0	0	0	0	70.05	0	0	11.6
2014	7	29	4	47	0	33	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	29	4	57	0	32	0	0	0	0	0	0	0	70.03	0	0	11.6
2014	7	29	5	7	0	32	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	29	5	17	0	33	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	29	5	27	0	32	0	0	0	0	0	0	0	70.02	0	0	11.6
2014	7	29	5	37	0	33	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	29	5	47	0	32	0	0	0	0	0	0	0	70	0	0	11.6
2014	7	29	5	57	0	33	0	0	0	0	0	0	0	69.98	0	0	11.6
2014	7	29	6	7	0	32	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	29	6	17	0	32	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	29	6	27	0	33	0	0	0	0	0	0	0	69.96	0	0	11.6
2014	7	29	6	37	0	33	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	29	6	47	0	33	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	29	6	57	0	32	0	0	0	0	0	0	0	69.94	0	0	11.6
2014	7	29	7	7	0	32	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	29	7	17	0	32	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	29	7	27	0	33	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	29	7	37	0	33	0	0	0	0	0	0	0	69.94	0	0	11.8
2014	7	29	7	47	0	32	0	0	0	0	0	0	0	69.96	0	0	12
2014	7	29	7	57	0	33	0	0	0	0	0	0	0	69.98	0	0	12
2014	7	29	8	7	0	32	0	0	0	0	0	0	0	69.98	0	0	12
2014	7	29	8	17	0	33	0	0	0	0	0	0	0	70	0	0	12.2
2014	7	29	8	27	0	32	0	0	0	0	0	0	0	70.02	0	0	12.2
2014	7	29	8	37	0	32	0	0	0	0	0	0	0	70.03	0	0	12.4
2014	7	29	8	47	0	32	0	0	0	0	0	0	0	70.07	0	0	12.4
2014	7	29	8	57	0	33	0	0	0	0	0	0	0	70.07	0	0	12.4
2014	7	29	9	7	0	33	0	0	0	0	0	0	0	70.11	0	0	12.6
2014	7	29	9	17	0	33	0	0	0	0	0	0	0	70.14	0	0	12.8
2014	7	29	9	27	0	32	0	0	0	0	0	0	0	70.16	0	0	12.8
2014	7	29	9	37	0	33	0	0	0	0	0	0	0	70.2	0	0	12.8
2014	7	29	9	47	0	33	0	0	0	0	0	0	0	70.25	0	0	13.4
2014	7	29	9	57	0	32	0	0	0	0	0	0	0	70.29	0	0	12.2
2014	7	29	10	7	0	32	0	0	0	0	0	0	0	70.34	0	0	12.2
2014	7	29	10	17	0	33	0	0	0	0	0	0	0	70.38	0	0	12.2
2014	7	29	10	27	0	33	0	0	0	0	0	0	0	70.41	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	10	37	0	32	0	0	0	0	0	0	0	70.47	0	0	12.2
2014	7	29	10	47	0	32	0	0	0	0	0	0	0	70.5	0	0	12.4
2014	7	29	10	57	0	32	0	0	0	0	0	0	0	70.57	0	0	12.4
2014	7	29	11	7	0	32	0	0	0	0	0	0	0	70.61	0	0	12.8
2014	7	29	11	17	0	33	0	0	0	0	0	0	0	70.68	0	0	13
2014	7	29	11	27	0	32	0	0	0	0	0	0	0	70.74	0	0	13
2014	7	29	11	37	0	33	0	0	0	0	0	0	0	70.79	0	0	13
2014	7	29	11	47	0	33	0	0	0	0	0	0	0	70.86	0	0	13
2014	7	29	11	57	0	32	0	0	0	0	0	0	0	70.93	0	0	13
2014	7	29	12	7	0	33	0	0	0	0	0	0	0	71.01	0	0	13
2014	7	29	12	17	0	32	0	0	0	0	0	0	0	71.08	0	0	13
2014	7	29	12	27	0	32	0	0	0	0	0	0	0	71.15	0	0	13
2014	7	29	12	37	0	32	0	0	0	0	0	0	0	71.2	0	0	13
2014	7	29	12	47	0	32	0	0	0	0	0	0	0	71.29	0	0	13
2014	7	29	12	57	0	32	0	0	0	0	0	0	0	71.37	0	0	13
2014	7	29	13	7	0	32	0	0	0	0	0	0	0	71.42	0	0	12.8
2014	7	29	13	17	0	32	0	0	0	0	0	0	0	71.51	0	0	12.6
2014	7	29	13	27	0	32	0	0	0	0	0	0	0	71.58	0	0	12.6
2014	7	29	13	37	0	31	0	0	0	0	0	0	0	71.64	0	0	12.8
2014	7	29	13	47	0	33	0	0	0	0	0	0	0	71.69	0	0	12.8
2014	7	29	13	57	0	32	0	0	0	0	0	0	0	71.76	0	0	12.8
2014	7	29	14	7	0	32	0	0	0	0	0	0	0	71.82	0	0	12.8
2014	7	29	14	17	0	32	0	0	0	0	0	0	0	71.87	0	0	12.8
2014	7	29	14	27	0	32	0	0	0	0	0	0	0	71.92	0	0	12.8
2014	7	29	14	37	0	32	0	0	0	0	0	0	0	71.96	0	0	12.8
2014	7	29	14	47	0	33	0	0	0	0	0	0	0	72.03	0	0	12.8
2014	7	29	14	57	0	32	0	0	0	0	0	0	0	72.05	0	0	12.8
2014	7	29	15	7	0	32	0	0	0	0	0	0	0	72.1	0	0	12.8
2014	7	29	15	17	0	32	0	0	0	0	0	0	0	72.14	0	0	12.4
2014	7	29	15	27	0	33	0	0	0	0	0	0	0	72.16	0	0	12.4
2014	7	29	15	37	0	32	0	0	0	0	0	0	0	72.18	0	0	12.4
2014	7	29	15	47	0	32	0	0	0	0	0	0	0	72.23	0	0	12.4
2014	7	29	15	57	0	32	0	0	0	0	0	0	0	72.23	0	0	12.4
2014	7	29	16	7	0	32	0	0	0	0	0	0	0	72.25	0	0	12.4
2014	7	29	16	17	0	32	0	0	0	0	0	0	0	72.27	0	0	12.4
2014	7	29	16	27	0	32	0	0	0	0	0	0	0	72.28	0	0	12.4
2014	7	29	16	37	0	32	0	0	0	0	0	0	0	72.28	0	0	12.4
2014	7	29	16	47	0	31	0	0	0	0	0	0	0	72.3	0	0	12.2
2014	7	29	16	57	0	32	0	0	0	0	0	0	0	72.32	0	0	12.2
2014	7	29	17	7	0	33	0	0	0	0	0	0	0	72.3	0	0	12
2014	7	29	17	17	0	32	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	29	17	27	0	32	0	0	0	0	0	0	0	72.3	0	0	11.8
2014	7	29	17	37	0	32	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	29	17	47	0	32	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	29	17	57	0	32	0	0	0	0	0	0	0	72.3	0	0	11.6
2014	7	29	18	7	0	32	0	0	0	0	0	0	0	72.3	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	29	18	17	0	32	0	0	0	0	0	0	0	72.28	0	0	11.6
2014	7	29	18	27	0	32	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	29	18	37	0	32	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	29	18	47	0	32	0	0	0	0	0	0	0	72.28	0	0	11.4
2014	7	29	18	57	0	31	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	29	19	7	0	31	0	0	0	0	0	0	0	72.27	0	0	11.4
2014	7	29	19	17	0	32	0	0	0	0	0	0	0	72.25	0	0	11.4
2014	7	29	19	27	0	32	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	29	19	37	0	32	0	0	0	0	0	0	0	72.23	0	0	11.4
2014	7	29	19	47	0	32	0	0	0	0	0	0	0	72.21	0	0	11.4
2014	7	29	19	57	0	32	0	0	0	0	0	0	0	72.21	0	0	11.4
2014	7	29	20	7	0	32	0	0	0	0	0	0	0	72.19	0	0	11.4
2014	7	29	20	17	0	32	0	0	0	0	0	0	0	72.18	0	0	11.4
2014	7	29	20	27	0	32	0	0	0	0	0	0	0	72.16	0	0	11.4
2014	7	29	20	37	0	32	0	0	0	0	0	0	0	72.14	0	0	11.4
2014	7	29	20	47	0	32	0	0	0	0	0	0	0	72.14	0	0	11.4
2014	7	29	20	57	0	32	0	0	0	0	0	0	0	72.12	0	0	11.4
2014	7	29	21	7	0	32	0	0	0	0	0	0	0	72.1	0	0	11.4
2014	7	29	21	17	0	32	0	0	0	0	0	0	0	72.09	0	0	11.4
2014	7	29	21	27	0	32	0	0	0	0	0	0	0	72.07	0	0	11.4
2014	7	29	21	37	0	31	0	0	0	0	0	0	0	72.07	0	0	11.4
2014	7	29	21	47	0	32	0	0	0	0	0	0	0	72.05	0	0	11.2
2014	7	29	21	57	0	32	0	0	0	0	0	0	0	72.03	0	0	11.2
2014	7	29	22	7	0	33	0	0	0	0	0	0	0	72.01	0	0	11.2
2014	7	29	22	17	0	32	0	0	0	0	0	0	0	72.01	0	0	11.2
2014	7	29	22	27	0	32	0	0	0	0	0	0	0	72	0	0	11.2
2014	7	29	22	37	0	32	0	0	0	0	0	0	0	71.98	0	0	11.2
2014	7	29	22	47	0	31	0	0	0	0	0	0	0	71.98	0	0	11.2
2014	7	29	22	57	0	33	0	0	0	0	0	0	0	71.96	0	0	11.4
2014	7	29	23	7	0	32	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	29	23	17	0	33	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	29	23	27	0	32	0	0	0	0	0	0	0	71.94	0	0	11.6
2014	7	29	23	37	0	32	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	29	23	47	0	32	0	0	0	0	0	0	0	71.91	0	0	11.6
2014	7	29	23	57	0	32	0	0	0	0	0	0	0	71.89	0	0	11.6
2014	7	30	0	7	0	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	30	0	17	0	32	0	0	0	0	0	0	0	71.87	0	0	11.6
2014	7	30	0	27	0	31	0	0	0	0	0	0	0	71.85	0	0	11.6
2014	7	30	0	37	0	32	0	0	0	0	0	0	0	71.83	0	0	11.6
2014	7	30	0	47	0	32	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	30	0	57	0	31	0	0	0	0	0	0	0	71.82	0	0	11.6
2014	7	30	1	7	0	31	0	0	0	0	0	0	0	71.8	0	0	11.6
2014	7	30	1	17	0	33	0	0	0	0	0	0	0	71.8	0	0	11.6
2014	7	30	1	27	0	31	0	0	0	0	0	0	0	71.78	0	0	11.6
2014	7	30	1	37	0	32	0	0	0	0	0	0	0	71.76	0	0	11.6
2014	7	30	1	47	0	32	0	0	0	0	0	0	0	71.74	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	1	57	0	32	0	0	0	0	0	0	0	71.74	0	0	11.6
2014	7	30	2	7	0	31	0	0	0	0	0	0	0	71.73	0	0	11.6
2014	7	30	2	17	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	30	2	27	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	30	2	37	0	32	0	0	0	0	0	0	0	71.71	0	0	11.6
2014	7	30	2	47	0	32	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	30	2	57	0	32	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	30	3	7	0	31	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	30	3	17	0	32	0	0	0	0	0	0	0	71.65	0	0	11.6
2014	7	30	3	27	0	32	0	0	0	0	0	0	0	71.64	0	0	11.6
2014	7	30	3	37	0	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	30	3	47	0	32	0	0	0	0	0	0	0	71.62	0	0	11.6
2014	7	30	3	57	0	33	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	30	4	7	0	32	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	30	4	17	0	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	30	4	27	0	31	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	30	4	37	0	33	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	30	4	47	0	32	0	0	0	0	0	0	0	71.56	0	0	11.6
2014	7	30	4	57	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	30	5	7	0	32	0	0	0	0	0	0	0	71.53	0	0	11.6
2014	7	30	5	17	0	32	0	0	0	0	0	0	0	71.51	0	0	11.6
2014	7	30	5	27	0	32	0	0	0	0	0	0	0	71.49	0	0	11.6
2014	7	30	5	37	0	32	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	30	5	47	0	32	0	0	0	0	0	0	0	71.47	0	0	11.6
2014	7	30	5	57	0	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	30	6	7	0	32	0	0	0	0	0	0	0	71.46	0	0	11.6
2014	7	30	6	17	0	32	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	30	6	27	0	32	0	0	0	0	0	0	0	71.42	0	0	11.6
2014	7	30	6	37	0	32	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	30	6	47	0	32	0	0	0	0	0	0	0	71.4	0	0	11.6
2014	7	30	6	57	0	32	0	0	0	0	0	0	0	71.38	0	0	11.4
2014	7	30	7	7	0	32	0	0	0	0	0	0	0	71.38	0	0	11.6
2014	7	30	7	17	0	33	0	0	0	0	0	0	0	71.37	0	0	11.4
2014	7	30	7	27	0	32	0	0	0	0	0	0	0	71.37	0	0	11.2
2014	7	30	7	37	0	32	0	0	0	0	0	0	0	71.35	0	0	11.4
2014	7	30	7	47	0	33	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	30	7	57	0	32	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	30	8	7	0	33	0	0	0	0	0	0	0	71.35	0	0	11.6
2014	7	30	8	17	0	32	0	0	0	0	0	0	0	71.37	0	0	11.6
2014	7	30	8	27	0	32	0	0	0	0	0	0	0	71.38	0	0	11.8
2014	7	30	8	37	0	33	0	0	0	0	0	0	0	71.38	0	0	11.8
2014	7	30	8	47	0	32	0	0	0	0	0	0	0	71.4	0	0	12
2014	7	30	8	57	0	32	0	0	0	0	0	0	0	71.42	0	0	12
2014	7	30	9	7	0	32	0	0	0	0	0	0	0	71.42	0	0	12
2014	7	30	9	17	0	32	0	0	0	0	0	0	0	71.44	0	0	12
2014	7	30	9	27	0	32	0	0	0	0	0	0	0	71.46	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	9	37	0	32	0	0	0	0	0	0	0	71.47	0	0	12
2014	7	30	9	47	0	32	0	0	0	0	0	0	0	71.49	0	0	12.2
2014	7	30	9	57	0	32	0	0	0	0	0	0	0	71.49	0	0	11.8
2014	7	30	10	7	0	32	0	0	0	0	0	0	0	71.51	0	0	12
2014	7	30	10	17	0	32	0	0	0	0	0	0	0	71.53	0	0	11.8
2014	7	30	10	27	0	32	0	0	0	0	0	0	0	71.56	0	0	12
2014	7	30	10	37	0	32	0	0	0	0	0	0	0	71.65	0	0	12.2
2014	7	30	10	47	0	33	0	0	0	0	0	0	0	71.76	0	0	12.4
2014	7	30	10	57	0	32	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	30	11	7	0	32	0	0	0	0	0	0	0	71.71	0	0	12
2014	7	30	11	17	0	32	0	0	0	0	0	0	0	71.71	0	0	12
2014	7	30	11	27	0	33	0	0	0	0	0	0	0	71.73	0	0	12
2014	7	30	11	37	0	32	0	0	0	0	0	0	0	71.71	0	0	12
2014	7	30	11	47	0	31	0	0	0	0	0	0	0	71.69	0	0	11.6
2014	7	30	11	57	0	32	0	0	0	0	0	0	0	71.67	0	0	11.6
2014	7	30	12	7	0	33	0	0	0	0	0	0	0	71.65	0	0	11.4
2014	7	30	12	17	0	32	0	0	0	0	0	0	0	71.62	0	0	11.4
2014	7	30	12	27	0	32	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	30	12	37	0	32	0	0	0	0	0	0	0	71.6	0	0	11.4
2014	7	30	12	47	0	32	0	0	0	0	0	0	0	71.6	0	0	11.6
2014	7	30	12	57	0	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	30	13	7	0	33	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	30	13	17	0	32	0	0	0	0	0	0	0	71.58	0	0	11.6
2014	7	30	13	27	0	32	0	0	0	0	0	0	0	71.55	0	0	11.4
2014	7	30	13	37	0	32	0	0	0	0	0	0	0	71.55	0	0	11.6
2014	7	30	13	47	0	32	0	0	0	0	0	0	0	71.51	0	0	11.4
2014	7	30	13	57	0	32	0	0	0	0	0	0	0	71.47	0	0	11.4
2014	7	30	14	7	0	32	0	0	0	0	0	0	0	71.44	0	0	11.2
2014	7	30	14	17	0	32	0	0	0	0	0	0	0	71.4	0	0	11.2
2014	7	30	14	27	0	32	0	0	0	0	0	0	0	71.38	0	0	11.2
2014	7	30	14	37	0	32	0	0	0	0	0	0	0	71.35	0	0	11.2
2014	7	30	14	47	0	31	0	0	0	0	0	0	0	71.33	0	0	11.4
2014	7	30	14	57	0	32	0	0	0	0	0	0	0	71.33	0	0	11.4
2014	7	30	15	7	0	32	0	0	0	0	0	0	0	71.31	0	0	11.4
2014	7	30	15	17	0	32	0	0	0	0	0	0	0	71.29	0	0	11.2
2014	7	30	15	27	0	31	0	0	0	0	0	0	0	71.26	0	0	11.2
2014	7	30	15	37	0	32	0	0	0	0	0	0	0	71.24	0	0	11.2
2014	7	30	15	47	0	33	0	0	0	0	0	0	0	71.22	0	0	11.2
2014	7	30	15	57	0	32	0	0	0	0	0	0	0	71.19	0	0	11.4
2014	7	30	16	7	0	32	0	0	0	0	0	0	0	71.19	0	0	11.2
2014	7	30	16	17	0	32	0	0	0	0	0	0	0	71.15	0	0	11.4
2014	7	30	16	27	0	31	0	0	0	0	0	0	0	71.11	0	0	11.2
2014	7	30	16	37	0	32	0	0	0	0	0	0	0	71.1	0	0	11.2
2014	7	30	16	47	0	32	0	0	0	0	0	0	0	71.08	0	0	11.2
2014	7	30	16	57	0	33	0	0	0	0	0	0	0	71.06	0	0	11.2
2014	7	30	17	7	0	32	0	0	0	0	0	0	0	71.04	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	30	17	17	0	33	0	0	0	0	0	0	0	71.04	0	0	11.6
2014	7	30	17	27	0	32	0	0	0	0	0	0	0	71.02	0	0	11.6
2014	7	30	17	37	0	32	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	30	17	47	0	32	0	0	0	0	0	0	0	70.99	0	0	11.4
2014	7	30	17	57	0	32	0	0	0	0	0	0	0	70.97	0	0	11.2
2014	7	30	18	7	0	32	0	0	0	0	0	0	0	70.93	0	0	11.2
2014	7	30	18	17	0	32	0	0	0	0	0	0	0	70.92	0	0	11.2
2014	7	30	18	27	0	32	0	0	0	0	0	0	0	70.9	0	0	11.2
2014	7	30	18	37	0	32	0	0	0	0	0	0	0	70.86	0	0	11.2
2014	7	30	18	47	0	33	0	0	0	0	0	0	0	70.86	0	0	11.2
2014	7	30	18	57	0	32	0	0	0	0	0	0	0	70.84	0	0	11.2
2014	7	30	19	7	0	32	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	30	19	17	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	30	19	27	0	33	0	0	0	0	0	0	0	70.79	0	0	11.2
2014	7	30	19	37	0	32	0	0	0	0	0	0	0	70.77	0	0	11.2
2014	7	30	19	47	0	32	0	0	0	0	0	0	0	70.75	0	0	11.2
2014	7	30	19	57	0	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	30	20	7	0	32	0	0	0	0	0	0	0	70.72	0	0	11.2
2014	7	30	20	17	0	32	0	0	0	0	0	0	0	70.68	0	0	11.2
2014	7	30	20	27	0	32	0	0	0	0	0	0	0	70.66	0	0	11.2
2014	7	30	20	37	0	32	0	0	0	0	0	0	0	70.65	0	0	11.2
2014	7	30	20	47	0	33	0	0	0	0	0	0	0	70.61	0	0	11.2
2014	7	30	20	57	0	32	0	0	0	0	0	0	0	70.59	0	0	11
2014	7	30	21	7	0	32	0	0	0	0	0	0	0	70.56	0	0	11.2
2014	7	30	21	17	0	32	0	0	0	0	0	0	0	70.54	0	0	11.2
2014	7	30	21	27	0	32	0	0	0	0	0	0	0	70.5	0	0	11.2
2014	7	30	21	37	0	32	0	0	0	0	0	0	0	70.5	0	0	11.2
2014	7	30	21	47	0	32	0	0	0	0	0	0	0	70.47	0	0	11.2
2014	7	30	21	57	0	32	0	0	0	0	0	0	0	70.45	0	0	11.4
2014	7	30	22	7	0	33	0	0	0	0	0	0	0	70.41	0	0	11.4
2014	7	30	22	17	0	32	0	0	0	0	0	0	0	70.38	0	0	11.4
2014	7	30	22	27	0	33	0	0	0	0	0	0	0	70.36	0	0	11.4
2014	7	30	22	37	0	33	0	0	0	0	0	0	0	70.32	0	0	11.4
2014	7	30	22	47	0	32	0	0	0	0	0	0	0	70.3	0	0	11.4
2014	7	30	22	57	0	32	0	0	0	0	0	0	0	70.27	0	0	11.4
2014	7	30	23	7	0	33	0	0	0	0	0	0	0	70.23	0	0	11.4
2014	7	30	23	17	0	34	0	0	0	0	0	0	0	70.21	0	0	11.4
2014	7	30	23	27	0	33	0	0	0	0	0	0	0	70.16	0	0	11.4
2014	7	30	23	37	0	32	0	0	0	0	0	0	0	70.14	0	0	11.4
2014	7	30	23	47	0	32	0	0	0	0	0	0	0	70.11	0	0	11.4
2014	7	30	23	57	0	32	0	0	0	0	0	0	0	70.07	0	0	11.4
2014	7	31	0	7	0	32	0	0	0	0	0	0	0	70.05	0	0	11.4
2014	7	31	0	17	0	32	0	0	0	0	0	0	0	70.02	0	0	11.4
2014	7	31	0	27	0	32	0	0	0	0	0	0	0	69.98	0	0	11.4
2014	7	31	0	37	0	32	0	0	0	0	0	0	0	69.94	0	0	11.4
2014	7	31	0	47	0	32	0	0	0	0	0	0	0	69.93	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	0	57	0	32	0	0	0	0	0	0	0	69.89	0	0	11.4
2014	7	31	1	7	0	33	0	0	0	0	0	0	0	69.87	0	0	11.4
2014	7	31	1	17	0	32	0	0	0	0	0	0	0	69.84	0	0	11.4
2014	7	31	1	27	0	32	0	0	0	0	0	0	0	69.8	0	0	11.4
2014	7	31	1	37	0	33	0	0	0	0	0	0	0	69.76	0	0	11.4
2014	7	31	1	47	0	32	0	0	0	0	0	0	0	69.73	0	0	11.4
2014	7	31	1	57	0	33	0	0	0	0	0	0	0	69.71	0	0	11.4
2014	7	31	2	7	0	33	0	0	0	0	0	0	0	69.67	0	0	11.4
2014	7	31	2	17	0	33	0	0	0	0	0	0	0	69.66	0	0	11.2
2014	7	31	2	27	0	33	0	0	0	0	0	0	0	69.6	0	0	11.2
2014	7	31	2	37	0	32	0	0	0	0	0	0	0	69.57	0	0	11.2
2014	7	31	2	47	0	32	0	0	0	0	0	0	0	69.55	0	0	11.2
2014	7	31	2	57	0	32	0	0	0	0	0	0	0	69.51	0	0	11.4
2014	7	31	3	7	0	32	0	0	0	0	0	0	0	69.48	0	0	11.2
2014	7	31	3	17	0	32	0	0	0	0	0	0	0	69.44	0	0	11.2
2014	7	31	3	27	0	32	0	0	0	0	0	0	0	69.4	0	0	11
2014	7	31	3	37	0	33	0	0	0	0	0	0	0	69.39	0	0	11.2
2014	7	31	3	47	0	32	0	0	0	0	0	0	0	69.35	0	0	11.4
2014	7	31	3	57	0	32	0	0	0	0	0	0	0	69.31	0	0	11
2014	7	31	4	7	0	32	0	0	0	0	0	0	0	69.28	0	0	11.2
2014	7	31	4	17	0	32	0	0	0	0	0	0	0	69.26	0	0	11.2
2014	7	31	4	27	0	33	0	0	0	0	0	0	0	69.22	0	0	11.2
2014	7	31	4	37	0	33	0	0	0	0	0	0	0	69.19	0	0	11.2
2014	7	31	4	47	0	32	0	0	0	0	0	0	0	69.15	0	0	11.2
2014	7	31	4	57	0	32	0	0	0	0	0	0	0	69.12	0	0	11.2
2014	7	31	5	7	0	32	0	0	0	0	0	0	0	69.1	0	0	11.2
2014	7	31	5	17	0	33	0	0	0	0	0	0	0	69.06	0	0	11.2
2014	7	31	5	27	0	33	0	0	0	0	0	0	0	69.03	0	0	11.2
2014	7	31	5	37	0	32	0	0	0	0	0	0	0	68.99	0	0	11.4
2014	7	31	5	47	0	32	0	0	0	0	0	0	0	68.94	0	0	11.4
2014	7	31	5	57	0	33	0	0	0	0	0	0	0	68.92	0	0	11.2
2014	7	31	6	7	0	32	0	0	0	0	0	0	0	68.88	0	0	11.2
2014	7	31	6	17	0	32	0	0	0	0	0	0	0	68.85	0	0	11.4
2014	7	31	6	27	0	32	0	0	0	0	0	0	0	68.83	0	0	11.4
2014	7	31	6	37	0	32	0	0	0	0	0	0	0	68.79	0	0	11.4
2014	7	31	6	47	0	32	0	0	0	0	0	0	0	68.76	0	0	11.4
2014	7	31	6	57	0	33	0	0	0	0	0	0	0	68.74	0	0	11.4
2014	7	31	7	7	0	32	0	0	0	0	0	0	0	68.7	0	0	11.4
2014	7	31	7	17	0	32	0	0	0	0	0	0	0	68.68	0	0	11.6
2014	7	31	7	27	0	33	0	0	0	0	0	0	0	68.67	0	0	11.6
2014	7	31	7	37	0	32	0	0	0	0	0	0	0	68.67	0	0	11.8
2014	7	31	7	47	0	33	0	0	0	0	0	0	0	68.67	0	0	11.8
2014	7	31	7	57	0	32	0	0	0	0	0	0	0	68.65	0	0	12
2014	7	31	8	7	0	33	0	0	0	0	0	0	0	68.65	0	0	12.2
2014	7	31	8	17	0	32	0	0	0	0	0	0	0	68.65	0	0	12.4
2014	7	31	8	27	0	32	0	0	0	0	0	0	0	68.67	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	8	37	0	33	0	0	0	0	0	0	0	68.67	0	0	12.4
2014	7	31	8	47	0	32	0	0	0	0	0	0	0	68.68	0	0	12.6
2014	7	31	8	57	0	33	0	0	0	0	0	0	0	68.7	0	0	12.6
2014	7	31	9	7	0	32	0	0	0	0	0	0	0	68.72	0	0	12.6
2014	7	31	9	17	0	33	0	0	0	0	0	0	0	68.76	0	0	12.6
2014	7	31	9	27	0	32	0	0	0	0	0	0	0	68.79	0	0	12.6
2014	7	31	9	37	0	33	0	0	0	0	0	0	0	68.83	0	0	12.6
2014	7	31	9	47	0	33	0	0	0	0	0	0	0	68.85	0	0	12.8
2014	7	31	9	57	0	32	0	0	0	0	0	0	0	68.9	0	0	12.8
2014	7	31	10	7	0	32	0	0	0	0	0	0	0	68.94	0	0	12.8
2014	7	31	10	17	0	32	0	0	0	0	0	0	0	68.97	0	0	12.4
2014	7	31	10	27	0	32	0	0	0	0	0	0	0	69.03	0	0	12.6
2014	7	31	10	37	0	33	0	0	0	0	0	0	0	69.06	0	0	14
2014	7	31	10	47	0	32	0	0	0	0	0	0	0	69.13	0	0	13.2
2014	7	31	10	57	0	33	0	0	0	0	0	0	0	69.19	0	0	13.2
2014	7	31	11	7	0	34	0	0	0	0	0	0	0	69.24	0	0	13.2
2014	7	31	11	17	0	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2014	7	31	11	27	0	33	0	0	0	0	0	0	0	69.39	0	0	13.2
2014	7	31	11	37	0	33	0	0	0	0	0	0	0	69.44	0	0	13.2
2014	7	31	11	47	0	33	0	0	0	0	0	0	0	69.49	0	0	13
2014	7	31	11	57	0	32	0	0	0	0	0	0	0	69.57	0	0	13
2014	7	31	12	7	0	32	0	0	0	0	0	0	0	69.64	0	0	13.2
2014	7	31	12	17	0	33	0	0	0	0	0	0	0	69.73	0	0	13
2014	7	31	12	27	0	33	0	0	0	0	0	0	0	69.8	0	0	13
2014	7	31	12	37	0	32	0	0	0	0	0	0	0	69.85	0	0	13.2
2014	7	31	12	47	0	32	0	0	0	0	0	0	0	69.94	0	0	13.2
2014	7	31	12	57	0	32	0	0	0	0	0	0	0	70.02	0	0	13.2
2014	7	31	13	7	0	32	0	0	0	0	0	0	0	70.07	0	0	13.2
2014	7	31	13	17	0	32	0	0	0	0	0	0	0	70.16	0	0	12.8
2014	7	31	13	27	0	32	0	0	0	0	0	0	0	70.23	0	0	13
2014	7	31	13	37	0	32	0	0	0	0	0	0	0	70.21	0	0	13
2014	7	31	13	47	0	33	0	0	0	0	0	0	0	70.29	0	0	12.6
2014	7	31	13	57	0	32	0	0	0	0	0	0	0	70.39	0	0	13
2014	7	31	14	7	0	33	0	0	0	0	0	0	0	70.47	0	0	13
2014	7	31	14	17	0	32	0	0	0	0	0	0	0	70.43	0	0	12.6
2014	7	31	14	27	0	32	0	0	0	0	0	0	0	70.5	0	0	12.8
2014	7	31	14	37	0	32	0	0	0	0	0	0	0	70.63	0	0	12.8
2014	7	31	14	47	0	32	0	0	0	0	0	0	0	70.61	0	0	12.8
2014	7	31	14	57	0	32	0	0	0	0	0	0	0	70.65	0	0	12.8
2014	7	31	15	7	0	32	0	0	0	0	0	0	0	70.66	0	0	12.4
2014	7	31	15	17	0	32	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	31	15	27	0	32	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	31	15	37	0	33	0	0	0	0	0	0	0	70.63	0	0	11.8
2014	7	31	15	47	0	32	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	31	15	57	0	32	0	0	0	0	0	0	0	70.65	0	0	11.6
2014	7	31	16	7	0	32	0	0	0	0	0	0	0	70.66	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	16	17	0	32	0	0	0	0	0	0	0	70.66	0	0	11.6
2014	7	31	16	27	0	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	31	16	37	0	32	0	0	0	0	0	0	0	70.7	0	0	11.6
2014	7	31	16	47	0	33	0	0	0	0	0	0	0	70.74	0	0	12.2
2014	7	31	16	57	0	32	0	0	0	0	0	0	0	70.79	0	0	12.6
2014	7	31	17	7	0	32	0	0	0	0	0	0	0	70.81	0	0	12
2014	7	31	17	17	0	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2014	7	31	17	27	0	32	0	0	0	0	0	0	0	70.81	0	0	12
2014	7	31	17	37	0	32	0	0	0	0	0	0	0	70.83	0	0	11.8
2014	7	31	17	47	0	33	0	0	0	0	0	0	0	70.81	0	0	11.6
2014	7	31	17	57	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	31	18	7	0	32	0	0	0	0	0	0	0	70.81	0	0	11.2
2014	7	31	18	17	0	33	0	0	0	0	0	0	0	70.81	0	0	11.2
2014	7	31	18	27	0	33	0	0	0	0	0	0	0	70.81	0	0	11
2014	7	31	18	37	0	32	0	0	0	0	0	0	0	70.81	0	0	11
2014	7	31	18	47	0	33	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	31	18	57	0	32	0	0	0	0	0	0	0	70.83	0	0	11.2
2014	7	31	19	7	0	33	0	0	0	0	0	0	0	70.83	0	0	11
2014	7	31	19	17	0	33	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	31	19	27	0	32	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	31	19	37	0	32	0	0	0	0	0	0	0	70.83	0	0	11.4
2014	7	31	19	47	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	31	19	57	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	31	20	7	0	32	0	0	0	0	0	0	0	70.81	0	0	11.4
2014	7	31	20	17	0	32	0	0	0	0	0	0	0	70.79	0	0	11.4
2014	7	31	20	27	0	32	0	0	0	0	0	0	0	70.79	0	0	11.4
2014	7	31	20	37	0	33	0	0	0	0	0	0	0	70.77	0	0	11.4
2014	7	31	20	47	0	33	0	0	0	0	0	0	0	70.75	0	0	11.4
2014	7	31	20	57	0	32	0	0	0	0	0	0	0	70.74	0	0	11.4
2014	7	31	21	7	0	31	0	0	0	0	0	0	0	70.72	0	0	11.4
2014	7	31	21	17	0	32	0	0	0	0	0	0	0	70.7	0	0	11.4
2014	7	31	21	27	0	32	0	0	0	0	0	0	0	70.66	0	0	11.2
2014	7	31	21	37	0	32	0	0	0	0	0	0	0	70.65	0	0	11.2
2014	7	31	21	47	0	32	0	0	0	0	0	0	0	70.63	0	0	11.2
2014	7	31	21	57	0	32	0	0	0	0	0	0	0	70.59	0	0	11.2
2014	7	31	22	7	0	32	0	0	0	0	0	0	0	70.57	0	0	11.2
2014	7	31	22	17	0	31	0	0	0	0	0	0	0	70.54	0	0	11.2
2014	7	31	22	27	0	32	0	0	0	0	0	0	0	70.5	0	0	11.2
2014	7	31	22	37	0	32	0	0	0	0	0	0	0	70.48	0	0	11.2
2014	7	31	22	47	0	32	0	0	0	0	0	0	0	70.45	0	0	11.2
2014	7	31	22	57	0	32	0	0	0	0	0	0	0	70.43	0	0	11.2
2014	7	31	23	7	0	32	0	0	0	0	0	0	0	70.39	0	0	11.2
2014	7	31	23	17	0	33	0	0	0	0	0	0	0	70.38	0	0	11.2
2014	7	31	23	27	0	33	0	0	0	0	0	0	0	70.34	0	0	11.2
2014	7	31	23	37	0	31	0	0	0	0	0	0	0	70.32	0	0	11.2
2014	7	31	23	47	0	33	0	0	0	0	0	0	0	70.29	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2014	7	31	23	57	0	33	0	0	0	0	0	0	0	70.25	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	0	8	18	0.3	3.9	0.81	93.9	86.0499	66.4082
2014	7	1	0	18	18	0.3	3.9	0.84	95.4	86.0499	68.5591
2014	7	1	0	28	18	0.3	3.9	0.82	93.4	86.0499	67.2149
2014	7	1	0	38	18	0.3	3.9	0.83	94.3	86.0499	68.0215
2014	7	1	0	48	18	0.3	3.9	0.82	94.3	86.0499	67.2149
2014	7	1	0	58	18	0.3	3.9	0.84	97.2	86.0499	68.0215
2014	7	1	1	8	18	0.3	3.9	0.83	94.3	86.0499	68.0215
2014	7	1	1	18	18	0.3	3.9	0.85	96.5	86.0499	68.8281
2014	7	1	1	28	18	0.3	3.9	0.83	94.8	86.0499	67.4839
2014	7	1	1	38	18	0.3	3.9	0.83	94.1	86.0499	67.4839
2014	7	1	1	48	18	0.3	3.9	0.83	93.8	86.0499	68.0216
2014	7	1	1	58	18	0.3	3.9	0.83	96.6	86.0499	67.2151
2014	7	1	2	8	18	0.3	3.9	0.82	96	86.0499	66.9462
2014	7	1	2	18	18	0.3	3.9	0.77	93.4	86.0499	63.1822
2014	7	1	2	28	18	0.3	3.9	0.8	95.9	86.0499	65.0643
2014	7	1	2	38	18	0.3	3.9	0.8	95.6	86.0499	65.3331
2014	7	1	2	48	18	0.3	3.9	0.83	96.1	86.0499	68.0218
2014	7	1	2	58	18	0.3	3.9	0.81	98.4	86.0499	65.6021
2014	7	1	3	8	18	0.3	3.9	0.8	94.5	86.0499	65.0644
2014	7	1	3	18	18	0.3	3.9	0.85	96.5	86.0499	68.8284
2014	7	1	3	28	18	0.3	3.9	0.79	94.5	86.0499	64.5267
2014	7	1	3	38	18	0.3	3.9	0.83	95.4	86.0499	68.0219
2014	7	1	3	48	18	0.3	3.9	0.81	92.6	86.0499	66.1399
2014	7	1	3	58	18	0.3	3.9	0.82	94.8	86.0499	66.9465
2014	7	1	4	8	18	0.3	3.9	0.86	94.4	86.0499	70.1729
2014	7	1	4	18	18	0.3	3.9	0.84	94.3	86.0499	68.5597
2014	7	1	4	28	18	0.3	3.9	0.85	96	86.0499	69.3663
2014	7	1	4	38	18	0.3	3.9	0.85	95.3	86.0499	69.3663
2014	7	1	4	48	18	0.3	3.9	0.8	94.7	86.0499	65.3334
2014	7	1	4	58	18	0.3	3.9	0.85	97.5	86.0499	69.0975
2014	7	1	5	8	18	0.3	3.9	0.82	94.6	86.0499	67.2155
2014	7	1	5	18	18	0.3	3.9	0.82	95.5	86.0499	66.6778
2014	7	1	5	28	18	0.3	3.9	0.86	96.6	86.0499	69.6353
2014	7	1	5	38	18	0.3	3.9	0.83	95.4	86.0499	68.0222
2014	7	1	5	48	18	0.3	3.9	0.81	96.3	86.0499	66.1401
2014	7	1	5	58	18	0.3	3.9	0.86	95.2	86.0499	70.442
2014	7	1	6	8	18	0.3	3.9	0.8	96.1	86.0499	65.0647
2014	7	1	6	18	18	0.3	3.9	0.85	93.5	86.0499	69.6354
2014	7	1	6	28	18	0.3	3.9	0.83	94.3	86.0499	68.0223
2014	7	1	6	38	18	0.3	3.9	0.81	95.8	86.0499	66.1402
2014	7	1	6	48	18	0.3	3.9	0.85	94.2	86.0499	69.3666
2014	7	1	6	58	18	0.3	3.9	0.78	97.2	86.0499	63.7205
2014	7	1	7	8	18	0.3	3.9	0.82	92.7	86.0499	67.2157
2014	7	1	7	18	18	0.3	3.9	0.84	95.2	86.0499	68.2912
2014	7	1	7	28	18	0.3	3.9	0.81	95.1	86.0499	66.1403
2014	7	1	7	38	18	0.3	3.9	0.8	95.4	86.0499	65.6026

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	7	48	18	0.3	3.9	0.82	96.2	86.0499	66.9469
2014	7	1	7	58	18	0.3	3.9	0.81	97.2	86.0499	65.8714
2014	7	1	8	8	18	0.3	3.9	0.82	95.7	86.0499	66.9469
2014	7	1	8	18	18	0.3	3.9	0.81	95.4	86.0499	65.8714
2014	7	1	8	28	18	0.3	3.9	0.85	94.2	86.0499	69.6355
2014	7	1	8	38	18	0.3	3.9	0.86	95.2	86.0499	70.4421
2014	7	1	8	48	18	0.3	3.9	0.84	94.3	86.0499	68.2911
2014	7	1	8	58	18	0.3	3.9	0.84	95.8	86.0499	68.56
2014	7	1	9	8	18	0.3	3.9	0.82	94.4	86.0499	66.6779
2014	7	1	9	18	18	0.3	3.9	0.83	95.6	86.0499	68.0222
2014	7	1	9	28	18	0.3	3.9	0.82	94.3	86.0499	67.2156
2014	7	1	9	38	18	0.3	3.9	0.84	94.5	86.0499	68.5599
2014	7	1	9	48	18	0.3	3.9	0.82	94.3	86.1155	67.269
2014	7	1	9	58	18	0.3	3.9	0.85	95.3	86.0499	69.6353
2014	7	1	10	8	18	0.3	3.9	0.85	96.9	86.0499	69.0975
2014	7	1	10	18	18	0.3	3.9	0.85	93.1	86.0499	69.9041
2014	7	1	10	28	18	0.3	3.9	0.83	95.2	86.1155	67.8071
2014	7	1	10	38	18	0.3	3.9	0.8	95.6	86.1155	65.6544
2014	7	1	10	48	18	0.3	3.9	0.78	95.3	86.0499	63.989
2014	7	1	10	58	18	0.3	3.9	0.83	96.1	86.1155	68.0761
2014	7	1	11	8	18	0.3	3.9	0.75	96.3	86.1155	61.3491
2014	7	1	11	18	18	0.3	3.9	0.8	96.8	86.1155	65.1161
2014	7	1	11	28	18	0.3	3.9	0.79	95.7	86.1155	64.847
2014	7	1	11	38	18	0.3	3.9	0.83	96.1	86.1155	67.5377
2014	7	1	11	48	18	0.3	3.9	0.82	96.9	85.9843	66.6243
2014	7	1	11	58	18	0.3	3.9	0.79	97.2	86.0499	63.9888
2014	7	1	12	8	18	0.3	3.9	0.76	97.4	86.0499	61.8379
2014	7	1	12	18	18	0.3	3.9	0.79	96	86.0499	64.2576
2014	7	1	12	28	18	0.3	3.9	0.8	94.7	86.0499	65.0641
2014	7	1	12	38	18	0.3	3.9	0.82	97.6	86.0499	66.6772
2014	7	1	12	48	18	0.3	3.9	0.81	94.7	86.0499	65.8706
2014	7	1	12	58	18	0.3	3.9	0.77	96.6	85.9186	62.2761
2014	7	1	13	8	18	0.3	3.9	0.73	95.5	85.3281	58.6313
2014	7	1	13	18	18	0.3	3.9	0.75	95	85.9186	61.2023
2014	7	1	13	28	18	0.3	3.9	0.73	100.4	85.7874	58.6927
2014	7	1	13	38	18	0.3	3.9	0.81	96.5	85.9186	65.4971
2014	7	1	13	48	18	0.3	3.9	0.83	95.7	85.9186	67.3761
2014	7	1	13	58	18	0.3	3.9	0.75	96	85.853	60.8852
2014	7	1	14	8	18	0.3	3.9	0.8	93.8	85.853	65.1766
2014	7	1	14	18	18	0.3	3.9	0.74	96.8	85.7874	60.3005
2014	7	1	14	28	18	0.3	3.9	0.78	95.3	85.7874	63.5165
2014	7	1	14	38	18	0.3	3.9	0.74	97.7	85.853	59.8122
2014	7	1	14	48	18	0.3	3.9	0.77	95.3	85.7874	62.9805
2014	7	1	14	58	18	0.3	3.9	0.79	94.8	85.7874	64.3205
2014	7	1	15	8	18	0.3	3.9	0.79	94.5	85.7218	64.0013
2014	7	1	15	18	18	0.3	3.9	0.77	96.4	85.7218	62.3946

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	15	28	18	0.3	3.9	0.75	96.5	85.7218	61.0556
2014	7	1	15	38	18	0.3	3.9	0.78	95.6	85.6562	63.1474
2014	7	1	15	48	18	0.3	3.9	0.81	96.3	85.6562	65.288
2014	7	1	15	58	18	0.3	3.9	0.77	96.1	85.6562	62.3446
2014	7	1	16	8	18	0.3	3.9	0.78	94.8	85.5906	63.3642
2014	7	1	16	18	18	0.3	3.9	0.81	97.2	85.5906	65.7705
2014	7	1	16	28	18	0.3	3.9	0.82	96.9	85.5906	66.5725
2014	7	1	16	38	18	0.3	3.9	0.81	96.3	85.5906	65.2357
2014	7	1	16	48	18	0.3	3.9	0.77	97.1	85.5906	62.5621
2014	7	1	16	58	18	0.3	3.9	0.79	96.2	85.5906	63.6316
2014	7	1	17	8	18	0.3	3.9	0.78	96.1	85.5906	62.8295
2014	7	1	17	18	18	0.3	3.9	0.78	96.8	85.5249	63.0464
2014	7	1	17	28	18	0.3	3.9	0.81	97	85.5249	65.1835
2014	7	1	17	38	18	0.3	3.9	0.75	98.3	85.5249	60.3749
2014	7	1	17	48	18	0.3	3.9	0.8	94.2	85.4593	64.8644
2014	7	1	17	58	18	0.3	3.9	0.77	95.1	85.5249	62.7792
2014	7	1	18	8	18	0.3	3.9	0.81	95.1	85.4593	65.9321
2014	7	1	18	18	18	0.3	3.9	0.8	95.4	85.5249	65.1836
2014	7	1	18	28	18	0.3	3.9	0.83	98	85.4593	66.7329
2014	7	1	18	38	18	0.3	3.9	0.76	97.6	85.4593	61.6612
2014	7	1	18	48	18	0.3	3.9	0.8	95.9	85.4593	64.5975
2014	7	1	18	58	18	0.3	3.9	0.8	95.9	85.4593	64.5975
2014	7	1	19	8	18	0.3	3.9	0.78	95.5	85.4593	63.5298
2014	7	1	19	18	18	0.3	3.9	0.8	97	85.3937	64.8124
2014	7	1	19	28	18	0.3	3.9	0.82	94.3	85.4593	66.733
2014	7	1	19	38	18	0.3	3.9	0.83	95.9	85.4593	67.5338
2014	7	1	19	48	18	0.3	3.9	0.83	96.1	85.4593	67.2668
2014	7	1	19	58	18	0.3	3.9	0.85	94.4	85.4593	68.6015
2014	7	1	20	8	18	0.3	3.9	0.82	93.4	85.4593	66.733
2014	7	1	20	18	18	0.3	3.9	0.87	93	85.4593	70.47
2014	7	1	20	28	18	0.3	3.9	0.82	96.2	85.4593	65.9322
2014	7	1	20	38	18	0.3	3.9	0.83	96.4	85.4593	66.9999
2014	7	1	20	48	18	0.3	3.9	0.84	95.4	85.4593	68.0677
2014	7	1	20	58	18	0.3	3.9	0.84	96.2	85.4593	68.3346
2014	7	1	21	8	18	0.3	3.9	0.85	94.4	85.4593	68.6015
2014	7	1	21	18	18	0.3	3.9	0.82	95.7	85.4593	66.4661
2014	7	1	21	28	18	0.3	3.9	0.82	95	85.4593	66.7331
2014	7	1	21	38	18	0.3	3.9	0.84	95.6	85.4593	68.0677
2014	7	1	21	48	18	0.3	3.9	0.81	95.8	85.4593	65.9323
2014	7	1	21	58	18	0.3	3.9	0.85	97.8	85.4593	68.6016
2014	7	1	22	8	18	0.3	3.9	0.78	94.8	85.4593	62.9961
2014	7	1	22	18	18	0.3	3.9	0.85	95.6	85.4593	68.6017
2014	7	1	22	28	18	0.3	3.9	0.79	96	85.4593	63.7969
2014	7	1	22	38	18	0.3	3.9	0.84	93.8	85.4593	67.8009
2014	7	1	22	48	18	0.3	3.9	0.85	93.8	85.4593	68.6017
2014	7	1	22	58	18	0.3	3.9	0.84	97	85.4593	67.801

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	1	23	8	18	0.3	3.9	0.83	93.6	85.4593	67.0002
2014	7	1	23	18	18	0.3	3.9	0.8	94.5	85.4593	64.8647
2014	7	1	23	28	18	0.3	3.9	0.87	95	85.4593	70.2034
2014	7	1	23	38	18	0.3	3.9	0.85	95.3	85.4593	68.8688
2014	7	1	23	48	18	0.3	3.9	0.83	96.1	85.4593	67.2672
2014	7	1	23	58	18	0.3	3.9	0.81	96.8	85.4593	65.3987
2014	7	2	0	8	18	0.3	3.9	0.81	95.3	85.4593	65.6656
2014	7	2	0	18	18	0.3	3.9	0.84	96	85.4593	68.0681
2014	7	2	0	28	18	0.3	3.9	0.82	96.2	85.4593	66.7334
2014	7	2	0	38	18	0.3	3.9	0.84	95.2	85.4593	67.8012
2014	7	2	0	48	18	0.3	3.9	0.86	94.8	85.4593	69.4028
2014	7	2	0	58	18	0.3	3.9	0.83	94.8	85.3937	67.2135
2014	7	2	1	8	18	0.3	3.9	0.84	93.8	85.4593	68.0682
2014	7	2	1	18	18	0.3	3.9	0.8	94.5	85.3937	65.0797
2014	7	2	1	28	18	0.3	3.9	0.82	93.9	85.4593	66.7336
2014	7	2	1	38	18	0.3	3.9	0.86	94.4	85.3937	69.3473
2014	7	2	1	48	18	0.3	3.9	0.86	93.7	85.4593	69.9368
2014	7	2	1	58	18	0.3	3.9	0.86	97	85.3937	69.3474
2014	7	2	2	8	18	0.3	3.9	0.83	95	85.3937	67.2136
2014	7	2	2	18	18	0.3	3.9	0.81	97.9	85.4593	65.399
2014	7	2	2	28	18	0.3	3.9	0.83	94.5	85.3937	67.4804
2014	7	2	2	38	18	0.3	3.9	0.81	94.4	85.4593	65.3991
2014	7	2	2	48	18	0.3	3.9	0.81	93.2	85.4593	65.933
2014	7	2	2	58	18	0.3	3.9	0.84	97	85.4593	67.8016
2014	7	2	3	8	18	0.3	3.9	0.83	94.1	85.4593	67.0008
2014	7	2	3	18	18	0.3	3.9	0.84	97.8	85.4593	68.0686
2014	7	2	3	28	18	0.3	3.9	0.83	96.6	85.4593	67.0008
2014	7	2	3	38	18	0.3	3.9	0.84	94.7	85.4593	67.8017
2014	7	2	3	48	18	0.3	3.9	0.81	94.4	85.4593	65.3993
2014	7	2	3	58	18	0.3	3.9	0.84	96.5	85.4593	68.0687
2014	7	2	4	8	18	0.3	3.9	0.85	96.4	85.4593	68.6026
2014	7	2	4	18	18	0.3	3.9	0.87	94.8	85.4593	70.2042
2014	7	2	4	28	18	0.3	3.9	0.82	95.3	85.4593	66.4671
2014	7	2	4	38	18	0.3	3.9	0.79	93.6	85.4593	64.3317
2014	7	2	4	48	18	0.3	3.9	0.81	94.9	85.4593	65.9333
2014	7	2	4	58	18	0.3	3.9	0.81	95.6	85.4593	65.3995
2014	7	2	5	8	18	0.3	3.9	0.81	96	85.4593	65.9334
2014	7	2	5	18	18	0.3	3.9	0.84	95.4	85.5249	68.3906
2014	7	2	5	28	18	0.3	3.9	0.84	95	85.5249	67.8563
2014	7	2	5	38	18	0.3	3.9	0.86	94.4	85.5249	69.4593
2014	7	2	5	48	18	0.3	3.9	0.84	97.8	85.5249	67.8564
2014	7	2	5	58	18	0.3	3.9	0.82	95	85.5906	66.5739
2014	7	2	6	8	18	0.3	3.9	0.81	97.4	85.7218	65.8772
2014	7	2	6	18	18	0.3	3.9	0.81	95.1	85.7218	65.8772
2014	7	2	6	28	18	0.3	3.9	0.83	95.7	85.7218	67.2162
2014	7	2	6	38	18	0.3	3.9	0.85	95.3	85.7218	68.823

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	6	48	18	0.3	3.9	0.81	96.3	85.7218	65.8772
2014	7	2	6	58	18	0.3	3.9	0.84	95.4	85.7218	68.0196
2014	7	2	7	8	18	0.3	3.9	0.8	93.8	85.7218	64.8061
2014	7	2	7	18	18	0.3	3.9	0.84	96.5	85.7874	68.342
2014	7	2	7	28	18	0.3	3.9	0.88	96.7	85.7874	71.0221
2014	7	2	7	38	18	0.3	3.9	0.83	94.8	85.7874	67.538
2014	7	2	7	48	18	0.3	3.9	0.85	96.9	85.7874	69.146
2014	7	2	7	58	18	0.3	3.9	0.84	95.6	85.7874	68.074
2014	7	2	8	8	18	0.3	3.9	0.82	95.8	85.7874	66.4659
2014	7	2	8	18	18	0.3	3.9	0.81	96	85.7874	66.1979
2014	7	2	8	28	18	0.3	3.9	0.83	94.5	85.7874	67.806
2014	7	2	8	38	18	0.3	3.9	0.82	95.1	85.7874	66.4659
2014	7	2	8	48	18	0.3	3.9	0.82	93.4	85.7874	66.7339
2014	7	2	8	58	18	0.3	3.9	0.81	93.2	85.7874	66.1979
2014	7	2	9	8	18	0.3	3.9	0.86	97.5	85.7874	69.4139
2014	7	2	9	18	18	0.3	3.9	0.81	97	85.7874	65.9298
2014	7	2	9	28	18	0.3	3.9	0.85	94.9	85.7874	69.1459
2014	7	2	9	38	18	0.3	3.9	0.88	94.7	85.853	71.3468
2014	7	2	9	48	18	0.3	3.9	0.81	96.8	85.853	65.7142
2014	7	2	9	58	18	0.3	3.9	0.85	93.1	85.853	69.7374
2014	7	2	10	8	18	0.3	3.9	0.83	98.2	85.7874	67.0017
2014	7	2	10	18	18	0.3	3.9	0.83	93.6	85.853	67.5916
2014	7	2	10	28	18	0.3	3.9	0.77	96.2	85.7874	62.1775
2014	7	2	10	38	18	0.3	3.9	0.81	95.5	85.853	66.2504
2014	7	2	10	48	18	0.3	3.9	0.81	93.5	85.7874	65.6615
2014	7	2	10	58	18	0.3	3.9	0.82	95.3	85.853	66.7868
2014	7	2	11	8	18	0.3	3.9	0.79	95.9	85.7218	64.2701
2014	7	2	11	18	18	0.3	3.9	0.79	97.2	85.7218	63.7345
2014	7	2	11	28	18	0.3	3.9	0.8	97.8	85.7218	64.8056
2014	7	2	11	38	18	0.3	3.9	0.81	94.4	85.7218	65.6089
2014	7	2	11	48	18	0.3	3.9	0.81	96	85.7218	65.8767
2014	7	2	11	58	18	0.3	3.9	0.79	94.5	85.6562	64.4861
2014	7	2	12	8	18	0.3	3.9	0.77	95.6	85.6562	62.613
2014	7	2	12	18	18	0.3	3.9	0.78	95.8	85.7218	62.9309
2014	7	2	12	28	18	0.3	3.9	0.81	97.6	85.5906	65.7713
2014	7	2	12	38	18	0.3	3.9	0.77	96.3	85.6562	62.6129
2014	7	2	12	48	18	0.3	3.9	0.79	97.9	85.5906	63.3649
2014	7	2	12	58	18	0.3	3.9	0.78	95.6	85.5906	63.0975
2014	7	2	13	8	18	0.3	3.9	0.78	95.8	85.5906	63.6322
2014	7	2	13	18	18	0.3	3.9	0.76	96.7	85.5906	61.4933
2014	7	2	13	28	18	0.3	3.9	0.78	97.5	85.5249	63.3141
2014	7	2	13	38	18	0.3	3.9	0.78	98.9	85.5906	62.83
2014	7	2	13	48	18	0.3	3.9	0.77	96.9	85.5249	61.9783
2014	7	2	13	58	18	0.3	3.9	0.8	96.6	85.5906	64.4341
2014	7	2	14	8	18	0.3	3.9	0.8	97.8	85.5249	64.3825
2014	7	2	14	18	18	0.3	3.9	0.76	98.7	85.5249	61.1767

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	14	28	18	0.3	3.9	0.8	98.1	85.5249	64.1153
2014	7	2	14	38	18	0.3	3.9	0.79	96.5	85.5249	63.581
2014	7	2	14	48	18	0.3	3.9	0.79	98.6	85.5249	63.581
2014	7	2	14	58	18	0.3	3.9	0.77	94.1	85.5249	62.7795
2014	7	2	15	8	18	0.3	3.9	0.79	96	85.5249	63.848
2014	7	2	15	18	18	0.3	3.9	0.79	96.9	85.4593	64.0638
2014	7	2	15	28	18	0.3	3.9	0.77	94.9	85.4593	62.4622
2014	7	2	15	38	18	0.3	3.9	0.84	94.9	85.4593	68.0678
2014	7	2	15	48	18	0.3	3.9	0.76	96.2	85.4593	61.6614
2014	7	2	15	58	18	0.3	3.9	0.77	94.6	85.4593	62.4622
2014	7	2	16	8	18	0.3	3.9	0.8	97.8	85.4593	64.3307
2014	7	2	16	18	18	0.3	3.9	0.76	96.2	85.4593	61.1275
2014	7	2	16	28	18	0.3	3.9	0.8	95.6	85.3937	65.0793
2014	7	2	16	38	18	0.3	3.9	0.79	97.2	85.3937	63.479
2014	7	2	16	48	18	0.3	3.9	0.8	95.2	85.3937	64.5459
2014	7	2	16	58	18	0.3	3.9	0.82	95.5	85.3937	66.6796
2014	7	2	17	8	18	0.3	3.9	0.81	96.5	85.3937	65.6127
2014	7	2	17	18	18	0.3	3.9	0.78	97	85.3937	62.6788
2014	7	2	17	28	18	0.3	3.9	0.77	95.1	85.3281	62.362
2014	7	2	17	38	18	0.3	3.9	0.81	94.7	85.3281	65.2936
2014	7	2	17	48	18	0.3	3.9	0.79	96.4	85.3281	63.9611
2014	7	2	17	58	18	0.3	3.9	0.81	96.8	85.3281	65.2936
2014	7	2	18	8	18	0.3	3.9	0.76	95.2	85.3281	61.5625
2014	7	2	18	18	18	0.3	3.9	0.76	94.2	85.2625	61.2468
2014	7	2	18	28	18	0.3	3.9	0.8	94	85.3281	64.4941
2014	7	2	18	38	18	0.3	3.9	0.81	96.5	85.3281	65.0271
2014	7	2	18	48	18	0.3	3.9	0.8	95.9	85.3281	65.0271
2014	7	2	18	58	18	0.3	3.9	0.79	95.9	85.3281	64.2276
2014	7	2	19	8	18	0.3	3.9	0.76	94.7	85.3281	61.8291
2014	7	2	19	18	18	0.3	3.9	0.76	96.2	85.3281	61.296
2014	7	2	19	28	18	0.3	3.9	0.78	94.8	85.3281	63.1616
2014	7	2	19	38	18	0.3	3.9	0.79	99.5	85.3281	63.4281
2014	7	2	19	48	18	0.3	3.9	0.77	96.3	85.3281	62.3621
2014	7	2	19	58	18	0.3	3.9	0.85	97.5	85.3281	68.4917
2014	7	2	20	8	18	0.3	3.9	0.82	96.9	85.3281	65.8267
2014	7	2	20	18	18	0.3	3.9	0.8	97.5	85.3937	64.8126
2014	7	2	20	28	18	0.3	3.9	0.82	95.5	85.3937	66.4129
2014	7	2	20	38	18	0.3	3.9	0.8	95.9	85.3937	64.8126
2014	7	2	20	48	18	0.3	3.9	0.77	93.9	85.3937	62.4122
2014	7	2	20	58	18	0.3	3.9	0.81	97.2	85.3281	65.5602
2014	7	2	21	8	18	0.3	3.9	0.83	95.4	85.3281	67.1592
2014	7	2	21	18	18	0.3	3.9	0.81	96.5	85.3281	65.5602
2014	7	2	21	28	18	0.3	3.9	0.84	97	85.3937	67.7466
2014	7	2	21	38	18	0.3	3.9	0.8	93.5	85.3937	64.8127
2014	7	2	21	48	18	0.3	3.9	0.82	95.8	85.3937	66.1463
2014	7	2	21	58	18	0.3	3.9	0.78	97.2	85.3937	63.2124

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	2	22	8	18	0.3	3.9	0.8	98.5	85.3937	64.546
2014	7	2	22	18	18	0.3	3.9	0.8	95.7	85.3937	64.546
2014	7	2	22	28	18	0.3	3.9	0.87	95.6	85.3937	70.1472
2014	7	2	22	38	18	0.3	3.9	0.83	95.7	85.3937	66.9465
2014	7	2	22	48	18	0.3	3.9	0.79	97.1	85.3937	64.0127
2014	7	2	22	58	18	0.3	3.9	0.8	96.3	85.3937	64.8128
2014	7	2	23	8	18	0.3	3.9	0.81	97.2	85.3937	65.613
2014	7	2	23	18	18	0.3	3.9	0.74	99.1	85.3937	59.7452
2014	7	2	23	28	18	0.3	3.9	0.79	98.6	85.3937	63.746
2014	7	2	23	38	18	0.3	3.9	0.75	96.8	85.3937	60.8121
2014	7	2	23	48	18	0.3	3.9	0.8	95.9	85.3937	64.5462
2014	7	2	23	58	18	0.3	3.9	0.8	97.5	85.3937	64.5462
2014	7	3	0	8	18	0.3	3.9	0.81	94.9	85.3937	65.6131
2014	7	3	0	18	18	0.3	3.9	0.85	95.3	85.3937	68.8138
2014	7	3	0	28	18	0.3	3.9	0.83	96.6	85.3937	67.2135
2014	7	3	0	38	18	0.3	3.9	0.82	96.7	85.3937	66.1466
2014	7	3	0	48	18	0.3	3.9	0.83	96.6	85.3937	67.2135
2014	7	3	0	58	18	0.3	3.9	0.8	94.5	85.3937	64.813
2014	7	3	1	8	18	0.3	3.9	0.81	96	85.3937	65.88
2014	7	3	1	18	18	0.3	3.9	0.81	94.9	85.3937	65.88
2014	7	3	1	28	18	0.3	3.9	0.79	98.4	85.3937	63.2128
2014	7	3	1	38	18	0.3	3.9	0.83	96.8	85.4593	66.7337
2014	7	3	1	48	18	0.3	3.9	0.85	94	85.4593	68.6022
2014	7	3	1	58	18	0.3	3.9	0.82	95	85.4593	66.7337
2014	7	3	2	8	18	0.3	3.9	0.83	96.6	85.4593	67.2676
2014	7	3	2	18	18	0.3	3.9	0.82	98.1	85.4593	65.9329
2014	7	3	2	28	18	0.3	3.9	0.83	95.2	85.4593	67.0007
2014	7	3	2	38	18	0.3	3.9	0.84	96.3	85.4593	67.8015
2014	7	3	2	48	18	0.3	3.9	0.8	96.3	85.4593	64.8653
2014	7	3	2	58	18	0.3	3.9	0.81	94.9	85.4593	65.9331
2014	7	3	3	8	18	0.3	3.9	0.86	95.9	85.4593	69.4032
2014	7	3	3	18	18	0.3	3.9	0.82	96.7	85.4593	66.2
2014	7	3	3	28	18	0.3	3.9	0.84	94.7	85.4593	68.0686
2014	7	3	3	38	18	0.3	3.9	0.79	94	85.4593	64.3316
2014	7	3	3	48	18	0.3	3.9	0.82	95.5	85.5249	66.2532
2014	7	3	3	58	18	0.3	3.9	0.8	97.5	85.5249	64.9175
2014	7	3	4	8	18	0.3	3.9	0.81	97.7	85.5249	65.1847
2014	7	3	4	18	18	0.3	3.9	0.78	96.8	85.5249	62.7803
2014	7	3	4	28	18	0.3	3.9	0.82	96.7	85.5906	66.039
2014	7	3	4	38	18	0.3	3.9	0.85	95.3	85.6562	69.3028
2014	7	3	4	48	18	0.3	3.9	0.81	93.7	85.7218	66.1448
2014	7	3	4	58	18	0.3	3.9	0.85	95.8	85.7218	68.8227
2014	7	3	5	8	18	0.3	3.9	0.82	99.4	85.7874	66.4657
2014	7	3	5	18	18	0.3	3.9	0.84	96.5	85.7874	68.3418
2014	7	3	5	28	18	0.3	3.9	0.83	98.5	85.7874	66.7337
2014	7	3	5	38	18	0.3	3.9	0.81	97.9	85.7874	65.3937

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	5	48	18	0.3	3.9	0.84	97.7	85.7874	67.8058
2014	7	3	5	58	18	0.3	3.9	0.81	95.6	85.7874	65.6618
2014	7	3	6	8	18	0.3	3.9	0.79	95.7	85.7874	64.3218
2014	7	3	6	18	18	0.3	3.9	0.79	99.1	85.853	63.8367
2014	7	3	6	28	18	0.3	3.9	0.8	94.9	85.853	65.4461
2014	7	3	6	38	18	0.3	3.9	0.84	95.4	85.853	68.1283
2014	7	3	6	48	18	0.3	3.9	0.83	95.2	85.853	67.8601
2014	7	3	6	58	18	0.3	3.9	0.85	96	85.853	69.2013
2014	7	3	7	8	18	0.3	3.9	0.82	97.4	85.853	66.5191
2014	7	3	7	18	18	0.3	3.9	0.82	94.3	85.853	67.0555
2014	7	3	7	28	18	0.3	3.9	0.82	96.5	85.9186	66.3037
2014	7	3	7	38	18	0.3	3.9	0.82	95.1	85.9186	66.5721
2014	7	3	7	48	18	0.3	3.9	0.82	95.5	85.9186	67.109
2014	7	3	7	58	18	0.3	3.9	0.82	96	85.9186	66.8406
2014	7	3	8	8	18	0.3	3.9	0.85	96.7	85.9186	68.7196
2014	7	3	8	18	18	0.3	3.9	0.84	96.5	85.9186	68.4512
2014	7	3	8	28	18	0.3	3.9	0.84	98.3	85.9186	67.9143
2014	7	3	8	38	18	0.3	3.9	0.79	95.7	85.9186	64.693
2014	7	3	8	48	18	0.3	3.9	0.82	96.7	85.9186	66.3037
2014	7	3	8	58	18	0.3	3.9	0.79	97.2	85.9186	63.8877
2014	7	3	9	8	18	0.3	3.9	0.78	98.7	85.9186	63.0824
2014	7	3	9	18	18	0.3	3.9	0.84	97.9	85.9186	67.9142
2014	7	3	9	28	18	0.3	3.9	0.8	98.1	85.9186	64.4245
2014	7	3	9	38	18	0.3	3.9	0.81	95.1	85.9843	66.0878
2014	7	3	9	48	18	0.3	3.9	0.77	97.4	85.9186	62.277
2014	7	3	9	58	18	0.3	3.9	0.77	97.9	85.9186	62.0085
2014	7	3	10	8	18	0.3	3.9	0.78	98.3	85.9843	62.8639
2014	7	3	10	18	18	0.3	3.9	0.76	95.9	85.9186	62.0085
2014	7	3	10	28	18	0.3	3.9	0.79	96.2	85.9186	64.4244
2014	7	3	10	38	18	0.3	3.9	0.78	98.3	85.9843	62.8638
2014	7	3	10	48	18	0.3	3.9	0.82	96.5	85.9186	66.3034
2014	7	3	10	58	18	0.3	3.9	0.76	98.2	85.9843	61.5205
2014	7	3	11	8	18	0.3	3.9	0.79	99.8	85.9186	63.6189
2014	7	3	11	18	18	0.3	3.9	0.77	94.9	85.9843	62.595
2014	7	3	11	28	18	0.3	3.9	0.79	97.2	85.9843	63.9382
2014	7	3	11	38	18	0.3	3.9	0.79	97.9	85.9186	64.1557
2014	7	3	11	48	18	0.3	3.9	0.76	97.2	85.9843	61.789
2014	7	3	11	58	18	0.3	3.9	0.8	97.3	85.9186	64.9609
2014	7	3	12	8	18	0.3	3.9	0.79	97.1	85.9186	64.424
2014	7	3	12	18	18	0.3	3.9	0.8	96.6	85.9186	64.9608
2014	7	3	12	28	18	0.3	3.9	0.77	96.9	85.9186	62.2765
2014	7	3	12	38	18	0.3	3.9	0.79	96.4	85.9186	64.4239
2014	7	3	12	48	18	0.3	3.9	0.74	96.3	85.9186	60.3974
2014	7	3	12	58	18	0.3	3.9	0.78	97.3	85.9186	63.0817
2014	7	3	13	8	18	0.3	3.9	0.78	98.5	85.9186	63.0816
2014	7	3	13	18	18	0.3	3.9	0.81	98.2	85.853	65.177

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	13	28	18	0.3	3.9	0.73	96.4	85.853	59.5444
2014	7	3	13	38	18	0.3	3.9	0.74	93.3	85.853	60.0808
2014	7	3	13	48	18	0.3	3.9	0.78	99.2	85.853	62.763
2014	7	3	13	58	18	0.3	3.9	0.75	98.8	85.853	60.8854
2014	7	3	14	8	18	0.3	3.9	0.8	95.7	85.853	64.9087
2014	7	3	14	18	18	0.3	3.9	0.78	95.8	85.7874	62.9808
2014	7	3	14	28	18	0.3	3.9	0.78	95.3	85.7874	63.7848
2014	7	3	14	38	18	0.3	3.9	0.76	98	85.7874	61.1047
2014	7	3	14	48	18	0.3	3.9	0.8	97.1	85.7218	64.5372
2014	7	3	14	58	18	0.3	3.9	0.78	98.7	85.7218	62.9304
2014	7	3	15	8	18	0.3	3.9	0.8	96.2	85.7218	64.5371
2014	7	3	15	18	18	0.3	3.9	0.79	96	85.6562	63.6828
2014	7	3	15	28	18	0.3	3.9	0.76	95.7	85.7218	61.8592
2014	7	3	15	38	18	0.3	3.9	0.76	98.2	85.6562	61.007
2014	7	3	15	48	18	0.3	3.9	0.83	96.6	85.6562	67.4288
2014	7	3	15	58	18	0.3	3.9	0.76	96.7	85.5906	61.493
2014	7	3	16	8	18	0.3	3.9	0.77	98.8	85.6562	62.3449
2014	7	3	16	18	18	0.3	3.9	0.76	96	85.6562	61.5421
2014	7	3	16	28	18	0.3	3.9	0.79	94.8	85.6562	63.9503
2014	7	3	16	38	18	0.3	3.9	0.78	94.8	85.5906	63.3644
2014	7	3	16	48	18	0.3	3.9	0.79	95.9	85.5906	64.4339
2014	7	3	16	58	18	0.3	3.9	0.79	94.5	85.5906	63.8992
2014	7	3	17	8	18	0.3	3.9	0.8	95.6	85.5249	64.9166
2014	7	3	17	18	18	0.3	3.9	0.79	96.9	85.5249	63.5809
2014	7	3	17	28	18	0.3	3.9	0.82	93.9	85.5249	66.5195
2014	7	3	17	38	18	0.3	3.9	0.77	94.6	85.5249	62.5123
2014	7	3	17	48	18	0.3	3.9	0.79	95.9	85.5249	64.3823
2014	7	3	17	58	18	0.3	3.9	0.8	94.5	85.5249	65.1838
2014	7	3	18	8	18	0.3	3.9	0.76	95.7	85.5249	61.7108
2014	7	3	18	18	18	0.3	3.9	0.8	92.3	85.5249	65.4509
2014	7	3	18	28	18	0.3	3.9	0.82	95.8	85.5249	66.2523
2014	7	3	18	38	18	0.3	3.9	0.76	96.9	85.5249	61.7108
2014	7	3	18	48	18	0.3	3.9	0.81	96	85.5249	65.718
2014	7	3	18	58	18	0.3	3.9	0.85	96.9	85.5249	68.3895
2014	7	3	19	8	18	0.3	3.9	0.81	96.8	85.5249	65.1838
2014	7	3	19	18	18	0.3	3.9	0.83	97.9	85.5249	67.3209
2014	7	3	19	28	18	0.3	3.9	0.82	96.9	85.5249	66.5195
2014	7	3	19	38	18	0.3	3.9	0.84	96.5	85.5249	68.1224
2014	7	3	19	48	18	0.3	3.9	0.8	95.2	85.4593	64.8646
2014	7	3	19	58	18	0.3	3.9	0.8	97.1	85.5249	64.3823
2014	7	3	20	8	18	0.3	3.9	0.82	98	85.4593	66.4662
2014	7	3	20	18	18	0.3	3.9	0.81	94.4	85.5249	65.9852
2014	7	3	20	28	18	0.3	3.9	0.82	96.9	85.5249	65.9852
2014	7	3	20	38	18	0.3	3.9	0.8	94.5	85.5249	64.6495
2014	7	3	20	48	18	0.3	3.9	0.8	94.9	85.5249	65.1838
2014	7	3	20	58	18	0.3	3.9	0.78	95.5	85.5249	63.5809

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	3	21	8	18	0.3	3.9	0.82	94.4	85.5249	66.5195
2014	7	3	21	18	18	0.3	3.9	0.87	94.3	85.5249	70.7939
2014	7	3	21	28	18	0.3	3.9	0.87	95	85.5249	70.2596
2014	7	3	21	38	18	0.3	3.9	0.85	94.2	85.5249	68.9239
2014	7	3	21	48	18	0.3	3.9	0.84	96.8	85.5249	67.5882
2014	7	3	21	58	18	0.3	3.9	0.83	95.7	85.5249	67.0539
2014	7	3	22	8	18	0.3	3.9	0.84	95.4	85.5249	68.1225
2014	7	3	22	18	18	0.3	3.9	0.82	96.7	85.5906	66.0382
2014	7	3	22	28	18	0.3	3.9	0.82	95	85.5249	66.7868
2014	7	3	22	38	18	0.3	3.9	0.84	96.3	85.5249	67.8554
2014	7	3	22	48	18	0.3	3.9	0.79	96.5	85.5249	63.5811
2014	7	3	22	58	18	0.3	3.9	0.84	97	85.5249	67.5883
2014	7	3	23	8	18	0.3	3.9	0.82	96.9	85.5906	66.0383
2014	7	3	23	18	18	0.3	3.9	0.82	96	85.5906	66.3057
2014	7	3	23	28	18	0.3	3.9	0.86	96.8	85.5906	69.7814
2014	7	3	23	38	18	0.3	3.9	0.81	93.9	85.5906	66.0384
2014	7	3	23	48	18	0.3	3.9	0.79	97.4	85.5906	63.8995
2014	7	3	23	58	18	0.3	3.9	0.82	93.4	85.5906	66.8405
2014	7	4	0	8	18	0.3	3.9	0.83	94.8	85.5906	67.3752
2014	7	4	0	18	18	0.3	3.9	0.76	97.6	85.5906	61.7606
2014	7	4	0	28	18	0.3	3.9	0.84	97.6	85.5906	67.91
2014	7	4	0	38	18	0.3	3.9	0.81	96.5	85.6562	65.2886
2014	7	4	0	48	18	0.3	3.9	0.84	93.3	85.7874	68.8771
2014	7	4	0	58	18	0.3	3.9	0.82	97.4	85.7874	66.4651
2014	7	4	1	8	18	0.3	3.9	0.79	96.7	85.853	64.1042
2014	7	4	1	18	18	0.3	3.9	0.83	95.7	85.853	67.591
2014	7	4	1	28	18	0.3	3.9	0.83	95	85.853	67.8593
2014	7	4	1	38	18	0.3	3.9	0.85	95.5	85.9186	69.2556
2014	7	4	1	48	18	0.3	3.9	0.85	94.7	85.9186	68.9872
2014	7	4	1	58	18	0.3	3.9	0.86	94.2	85.9186	69.7925
2014	7	4	2	8	18	0.3	3.9	0.83	93.6	85.9186	67.3766
2014	7	4	2	18	18	0.3	3.9	0.86	94.4	85.9186	69.7926
2014	7	4	2	28	18	0.3	3.9	0.83	96.1	85.9186	67.9136
2014	7	4	2	38	18	0.3	3.9	0.82	95.1	85.9843	66.6245
2014	7	4	2	48	18	0.3	3.9	0.83	94.3	85.9843	67.9678
2014	7	4	2	58	18	0.3	3.9	0.82	93.5	85.9843	66.6245
2014	7	4	3	8	18	0.3	3.9	0.84	94.7	85.9843	68.2365
2014	7	4	3	18	18	0.3	3.9	0.84	96.5	85.9843	68.5051
2014	7	4	3	28	18	0.3	3.9	0.85	93.3	85.9843	69.3111
2014	7	4	3	38	18	0.3	3.9	0.84	93.6	85.9843	69.0425
2014	7	4	3	48	18	0.3	3.9	0.82	96.5	85.9843	66.356
2014	7	4	3	58	18	0.3	3.9	0.82	95.7	85.9843	67.162
2014	7	4	4	8	18	0.3	3.9	0.84	94.9	85.9843	68.7739
2014	7	4	4	18	18	0.3	3.9	0.84	95.6	85.9843	68.774
2014	7	4	4	28	18	0.3	3.9	0.81	97	85.9843	66.0875
2014	7	4	4	38	18	0.3	3.9	0.85	96	86.0499	69.3665

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	4	48	18	0.3	3.9	0.84	95.4	86.0499	68.8288
2014	7	4	4	58	18	0.3	3.9	0.84	95.4	86.0499	68.2911
2014	7	4	5	8	18	0.3	3.9	0.82	95.5	86.0499	67.2157
2014	7	4	5	18	18	0.3	3.9	0.82	94.8	86.0499	66.9469
2014	7	4	5	28	18	0.3	3.9	0.84	95	86.0499	68.2912
2014	7	4	5	38	18	0.3	3.9	0.87	93.5	86.0499	70.9799
2014	7	4	5	48	18	0.3	3.9	0.86	95.9	86.0499	70.1733
2014	7	4	5	58	18	0.3	3.9	0.82	94.1	86.0499	66.947
2014	7	4	6	8	18	0.3	3.9	0.83	93.8	86.0499	68.0225
2014	7	4	6	18	18	0.3	3.9	0.84	95.8	86.0499	68.5602
2014	7	4	6	28	18	0.3	3.9	0.82	96.6	86.0499	66.9471
2014	7	4	6	38	18	0.3	3.9	0.81	96	86.0499	66.4094
2014	7	4	6	48	18	0.3	3.9	0.87	95.6	86.0499	70.7112
2014	7	4	6	58	18	0.3	3.9	0.81	93.7	86.0499	66.4094
2014	7	4	7	8	18	0.3	3.9	0.84	95.6	86.1155	68.884
2014	7	4	7	18	18	0.3	3.9	0.84	94.2	86.1155	68.884
2014	7	4	7	28	18	0.3	3.9	0.83	96.8	86.1155	67.5386
2014	7	4	7	38	18	0.3	3.9	0.82	95	86.1155	67.0005
2014	7	4	7	48	18	0.3	3.9	0.86	95.5	86.1155	70.2294
2014	7	4	7	58	18	0.3	3.9	0.83	95.6	86.1155	68.0768
2014	7	4	8	8	18	0.3	3.9	0.81	96.3	86.1155	66.1932
2014	7	4	8	18	18	0.3	3.9	0.81	94.6	86.1155	66.1932
2014	7	4	8	28	18	0.3	3.9	0.81	96.5	86.1811	65.9766
2014	7	4	8	38	18	0.3	3.9	0.82	95.5	86.1811	67.0537
2014	7	4	8	48	18	0.3	3.9	0.84	93.1	86.1811	68.9388
2014	7	4	8	58	18	0.3	3.9	0.79	96.4	86.1811	64.3608
2014	7	4	9	8	18	0.3	3.9	0.83	95.6	86.1811	68.1309
2014	7	4	9	18	18	0.3	3.9	0.77	98.3	86.1811	62.745
2014	7	4	9	28	18	0.3	3.9	0.77	94.2	86.1811	63.0143
2014	7	4	9	38	18	0.3	3.9	0.79	97.9	86.1811	64.0914
2014	7	4	9	48	18	0.3	3.9	0.81	97	86.2467	65.7594
2014	7	4	9	58	18	0.3	3.9	0.81	99	86.1811	65.9764
2014	7	4	10	8	18	0.3	3.9	0.77	97.3	86.1811	63.0142
2014	7	4	10	18	18	0.3	3.9	0.76	97.2	86.2467	62.2557
2014	7	4	10	28	18	0.3	3.9	0.79	95.3	86.2467	64.4117
2014	7	4	10	38	18	0.3	3.9	0.8	97.6	86.1811	64.8991
2014	7	4	10	48	18	0.3	3.9	0.8	98.3	86.2467	64.9506
2014	7	4	10	58	18	0.3	3.9	0.82	97.1	86.2467	67.1066
2014	7	4	11	8	18	0.3	3.9	0.78	94.3	86.3123	63.9233
2014	7	4	11	18	18	0.3	3.9	0.79	95.7	86.2467	64.4115
2014	7	4	11	28	18	0.3	3.9	0.77	96.1	86.2467	63.064
2014	7	4	11	38	18	0.3	3.9	0.77	96.1	86.2467	62.7944
2014	7	4	11	48	18	0.3	3.9	0.77	96.6	86.2467	62.7944
2014	7	4	11	58	18	0.3	3.9	0.8	95.7	86.2467	65.2199
2014	7	4	12	8	18	0.3	3.9	0.8	95.9	86.2467	65.4894
2014	7	4	12	18	18	0.3	3.9	0.76	94.9	86.2467	62.2553

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	12	28	18	0.3	3.9	0.8	98.9	86.2467	65.2198
2014	7	4	12	38	18	0.3	3.9	0.76	97.7	86.2467	61.9857
2014	7	4	12	48	18	0.3	3.9	0.77	96.8	86.2467	63.0637
2014	7	4	12	58	18	0.3	3.9	0.78	94.8	86.2467	63.6027
2014	7	4	13	8	18	0.3	3.9	0.81	96.8	86.1811	65.7064
2014	7	4	13	18	18	0.3	3.9	0.77	96.1	86.2467	63.0636
2014	7	4	13	28	18	0.3	3.9	0.8	97.1	86.1811	64.8985
2014	7	4	13	38	18	0.3	3.9	0.76	96.7	86.1811	62.2056
2014	7	4	13	48	18	0.3	3.9	0.76	95.7	86.1811	62.2056
2014	7	4	13	58	18	0.3	3.9	0.75	95.3	86.1811	61.1284
2014	7	4	14	8	18	0.3	3.9	0.78	97	86.1811	63.2826
2014	7	4	14	18	18	0.3	3.9	0.78	95.5	86.1811	63.8212
2014	7	4	14	28	18	0.3	3.9	0.77	97.1	86.1811	62.744
2014	7	4	14	38	18	0.3	3.9	0.79	95.9	86.1811	64.629
2014	7	4	14	48	18	0.3	3.9	0.78	97.3	86.1811	63.2825
2014	7	4	14	58	18	0.3	3.9	0.77	97.3	86.1155	62.6941
2014	7	4	15	8	18	0.3	3.9	0.79	94.5	86.1811	64.6289
2014	7	4	15	18	18	0.3	3.9	0.79	96.5	86.1155	64.0394
2014	7	4	15	28	18	0.3	3.9	0.78	97.2	86.1155	63.7703
2014	7	4	15	38	18	0.3	3.9	0.8	96.2	86.1155	64.8466
2014	7	4	15	48	18	0.3	3.9	0.79	95.5	86.1155	64.8465
2014	7	4	15	58	18	0.3	3.9	0.85	96.2	86.1155	69.4208
2014	7	4	16	8	18	0.3	3.9	0.78	95.1	86.1155	63.5012
2014	7	4	16	18	18	0.3	3.9	0.8	95.2	86.1155	65.3847
2014	7	4	16	28	18	0.3	3.9	0.78	97.8	86.0499	63.1818
2014	7	4	16	38	18	0.3	3.9	0.79	95.2	86.0499	64.5261
2014	7	4	16	48	18	0.3	3.9	0.78	97.2	86.0499	63.4506
2014	7	4	16	58	18	0.3	3.9	0.77	97.3	85.9843	62.8628
2014	7	4	17	8	18	0.3	3.9	0.78	94.8	86.0499	63.9884
2014	7	4	17	18	18	0.3	3.9	0.79	96.5	85.9843	63.9374
2014	7	4	17	28	18	0.3	3.9	0.82	97.1	86.0499	66.9458
2014	7	4	17	38	18	0.3	3.9	0.82	96.6	86.0499	66.9458
2014	7	4	17	48	18	0.3	3.9	0.82	96.7	85.9843	66.3552
2014	7	4	17	58	18	0.3	3.9	0.8	94.5	85.9843	65.2807
2014	7	4	18	8	18	0.3	3.9	0.83	95.9	85.9843	67.4298
2014	7	4	18	18	18	0.3	3.9	0.8	94.5	85.9843	65.5493
2014	7	4	18	28	18	0.3	3.9	0.77	94.4	85.9843	62.8629
2014	7	4	18	38	18	0.3	3.9	0.79	93.8	85.9186	64.6918
2014	7	4	18	48	18	0.3	3.9	0.81	97.4	85.9186	65.7655
2014	7	4	18	58	18	0.3	3.9	0.8	95.7	85.9843	65.012
2014	7	4	19	8	18	0.3	3.9	0.82	94.4	85.9843	66.6239
2014	7	4	19	18	18	0.3	3.9	0.81	96.8	85.9843	65.5493
2014	7	4	19	28	18	0.3	3.9	0.8	94	85.9843	65.2807
2014	7	4	19	38	18	0.3	3.9	0.79	94.3	85.9843	64.7434
2014	7	4	19	48	18	0.3	3.9	0.81	96.1	86.0499	65.6015
2014	7	4	19	58	18	0.3	3.9	0.78	94.6	85.9843	63.6688

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	4	20	8	18	0.3	3.9	0.82	94.4	85.9843	66.6239
2014	7	4	20	18	18	0.3	3.9	0.84	93.6	86.0499	68.8278
2014	7	4	20	28	18	0.3	3.9	0.82	94.2	86.0499	66.677
2014	7	4	20	38	18	0.3	3.9	0.87	95.9	86.0499	70.7098
2014	7	4	20	48	18	0.3	3.9	0.79	95	86.0499	64.795
2014	7	4	20	58	18	0.3	3.9	0.84	93.8	86.0499	68.559
2014	7	4	21	8	18	0.3	3.9	0.83	95.6	86.0499	68.0213
2014	7	4	21	18	18	0.3	3.9	0.82	93.9	86.1155	67.2682
2014	7	4	21	28	18	0.3	3.9	0.82	93.9	86.1155	67.2682
2014	7	4	21	38	18	0.3	3.9	0.81	96.8	86.1155	65.6538
2014	7	4	21	48	18	0.3	3.9	0.82	94.8	86.1155	66.7301
2014	7	4	21	58	18	0.3	3.9	0.82	96.4	86.1155	66.9991
2014	7	4	22	8	18	0.3	3.9	0.86	96.4	86.1155	69.959
2014	7	4	22	18	18	0.3	3.9	0.82	96.2	86.1155	66.461
2014	7	4	22	28	18	0.3	3.9	0.83	96.1	86.1155	67.8064
2014	7	4	22	38	18	0.3	3.9	0.85	95.7	86.1155	69.6899
2014	7	4	22	48	18	0.3	3.9	0.82	96.4	86.1155	66.7301
2014	7	4	22	58	18	0.3	3.9	0.82	93.2	86.1811	67.3218
2014	7	4	23	8	18	0.3	3.9	0.83	95.7	86.1155	67.5374
2014	7	4	23	18	18	0.3	3.9	0.79	96.4	86.1155	64.5776
2014	7	4	23	28	18	0.3	3.9	0.78	99.1	86.1811	63.5518
2014	7	4	23	38	18	0.3	3.9	0.79	97.2	86.1155	64.0395
2014	7	4	23	48	18	0.3	3.9	0.82	94.6	86.1811	67.3219
2014	7	4	23	58	18	0.3	3.9	0.83	95.7	86.1811	67.8605
2014	7	5	0	8	18	0.3	3.9	0.84	94.9	86.1811	68.6684
2014	7	5	0	18	18	0.3	3.9	0.83	95	86.1811	67.8605
2014	7	5	0	28	18	0.3	3.9	0.82	96	86.1811	67.0527
2014	7	5	0	38	18	0.3	3.9	0.87	95.4	86.1811	71.3613
2014	7	5	0	48	18	0.3	3.9	0.84	94.9	86.1811	68.6684
2014	7	5	0	58	18	0.3	3.9	0.82	96.2	86.1811	67.322
2014	7	5	1	8	18	0.3	3.9	0.82	95	86.1811	67.322
2014	7	5	1	18	18	0.3	3.9	0.81	94.2	86.1811	66.5142
2014	7	5	1	28	18	0.3	3.9	0.82	96.7	86.1811	66.7835
2014	7	5	1	38	18	0.3	3.9	0.81	95.8	86.1811	65.9757
2014	7	5	1	48	18	0.3	3.9	0.82	95.1	86.2467	66.8366
2014	7	5	1	58	18	0.3	3.9	0.8	94.5	86.2467	65.7586
2014	7	5	2	8	18	0.3	3.9	0.84	95.4	86.2467	68.9927
2014	7	5	2	18	18	0.3	3.9	0.85	95.3	86.2467	69.5317
2014	7	5	2	28	18	0.3	3.9	0.83	97.9	86.2467	67.6452
2014	7	5	2	38	18	0.3	3.9	0.86	95.7	86.3123	70.6658
2014	7	5	2	48	18	0.3	3.9	0.84	96.5	86.3123	68.7778
2014	7	5	2	58	18	0.3	3.9	0.81	96.5	86.3123	65.811
2014	7	5	3	8	18	0.3	3.9	0.8	97.5	86.3123	65.5413
2014	7	5	3	18	18	0.3	3.9	0.83	94.1	86.3123	67.9688
2014	7	5	3	28	18	0.3	3.9	0.85	97.3	86.3123	69.0477
2014	7	5	3	38	18	0.3	3.9	0.84	95.2	86.378	68.8325

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	3	48	18	0.3	3.9	0.84	93.1	86.5092	69.4824
2014	7	5	3	58	18	0.3	3.9	0.86	95	86.5092	70.5639
2014	7	5	4	8	18	0.3	3.9	0.83	97.7	86.5748	68.1846
2014	7	5	4	18	18	0.3	3.9	0.84	95.4	86.5748	68.9963
2014	7	5	4	28	18	0.3	3.9	0.85	96.6	86.6404	69.8633
2014	7	5	4	38	18	0.3	3.9	0.86	96.4	86.6404	70.4049
2014	7	5	4	48	18	0.3	3.9	0.79	96	86.6404	64.4476
2014	7	5	4	58	18	0.3	3.9	0.82	95.5	86.6404	67.4263
2014	7	5	5	8	18	0.3	3.9	0.86	95	86.6404	70.9465
2014	7	5	5	18	18	0.3	3.9	0.84	95.4	86.706	68.8346
2014	7	5	5	28	18	0.3	3.9	0.86	96.3	86.706	71.0027
2014	7	5	5	38	18	0.3	3.9	0.82	96.6	86.706	67.4797
2014	7	5	5	48	18	0.3	3.9	0.85	95.8	86.706	69.6477
2014	7	5	5	58	18	0.3	3.9	0.83	94.3	86.706	68.0217
2014	7	5	6	8	18	0.3	3.9	0.84	95.4	86.706	68.8347
2014	7	5	6	18	18	0.3	3.9	0.81	97.7	86.7717	66.4482
2014	7	5	6	28	18	0.3	3.9	0.86	95.7	86.706	70.4608
2014	7	5	6	38	18	0.3	3.9	0.84	95.4	86.7717	69.1604
2014	7	5	6	48	18	0.3	3.9	0.84	96.3	86.7717	69.1604
2014	7	5	6	58	18	0.3	3.9	0.8	93.3	86.7717	66.177
2014	7	5	7	8	18	0.3	3.9	0.84	96.3	86.7717	69.1604
2014	7	5	7	18	18	0.3	3.9	0.85	97.1	86.7717	69.9741
2014	7	5	7	28	18	0.3	3.9	0.85	96.2	86.7717	69.7029
2014	7	5	7	38	18	0.3	3.9	0.84	93.8	86.7717	69.4316
2014	7	5	7	48	18	0.3	3.9	0.8	95.2	86.7717	66.177
2014	7	5	7	58	18	0.3	3.9	0.89	96.8	86.7717	72.6862
2014	7	5	8	8	18	0.3	3.9	0.8	95.9	86.7717	66.177
2014	7	5	8	18	18	0.3	3.9	0.86	95.9	86.7717	70.7877
2014	7	5	8	28	18	0.3	3.9	0.83	94.6	86.7717	68.0755
2014	7	5	8	38	18	0.3	3.9	0.84	95.4	86.8373	69.215
2014	7	5	8	48	18	0.3	3.9	0.8	92.8	86.8373	66.5006
2014	7	5	8	58	18	0.3	3.9	0.83	95	86.8373	68.1292
2014	7	5	9	8	18	0.3	3.9	0.84	95.6	86.8373	69.4864
2014	7	5	9	18	18	0.3	3.9	0.83	96.1	86.8373	68.672
2014	7	5	9	28	18	0.3	3.9	0.8	95.6	86.8373	66.2291
2014	7	5	9	38	18	0.3	3.9	0.79	96.7	86.8373	64.872
2014	7	5	9	48	18	0.3	3.9	0.79	96.2	86.8373	65.1434
2014	7	5	9	58	18	0.3	3.9	0.84	96.3	86.8373	69.2148
2014	7	5	10	8	18	0.3	3.9	0.78	98.3	86.8373	63.5147
2014	7	5	10	18	18	0.3	3.9	0.8	94.7	86.9029	66.0096
2014	7	5	10	28	18	0.3	3.9	0.77	96.6	86.9029	63.2931
2014	7	5	10	38	18	0.3	3.9	0.8	96.8	86.9029	66.0095
2014	7	5	10	48	18	0.3	3.9	0.79	95.5	86.9029	65.1945
2014	7	5	10	58	18	0.3	3.9	0.79	97.2	86.9029	64.6512
2014	7	5	11	8	18	0.3	3.9	0.79	96.7	86.9029	64.9228
2014	7	5	11	18	18	0.3	3.9	0.78	95.8	86.9029	64.6512

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	11	28	18	0.3	3.9	0.82	95.5	86.9029	67.6392
2014	7	5	11	38	18	0.3	3.9	0.78	95.8	86.9029	63.8361
2014	7	5	11	48	18	0.3	3.9	0.81	97.2	86.9029	66.2809
2014	7	5	11	58	18	0.3	3.9	0.81	97.7	86.9029	66.2809
2014	7	5	12	8	18	0.3	3.9	0.8	96.8	86.9029	65.7375
2014	7	5	12	18	18	0.3	3.9	0.8	96.6	86.9029	65.7375
2014	7	5	12	28	18	0.3	3.9	0.79	95.9	86.9029	65.1942
2014	7	5	12	38	18	0.3	3.9	0.81	98.2	86.9029	66.0091
2014	7	5	12	48	18	0.3	3.9	0.82	96.5	86.9685	67.1485
2014	7	5	12	58	18	0.3	3.9	0.77	98.3	86.9029	63.2926
2014	7	5	13	8	18	0.3	3.9	0.78	97.2	86.9685	64.4298
2014	7	5	13	18	18	0.3	3.9	0.78	95.6	86.9029	64.1074
2014	7	5	13	28	18	0.3	3.9	0.81	98	86.9685	66.0609
2014	7	5	13	38	18	0.3	3.9	0.81	96.7	86.9685	66.8764
2014	7	5	13	48	18	0.3	3.9	0.79	96.2	86.9685	64.9734
2014	7	5	13	58	18	0.3	3.9	0.82	94.6	86.9685	67.4201
2014	7	5	14	8	18	0.3	3.9	0.8	95.9	86.9685	66.3326
2014	7	5	14	18	18	0.3	3.9	0.82	97.1	86.9685	67.6918
2014	7	5	14	28	18	0.3	3.9	0.82	96	86.9685	67.6918
2014	7	5	14	38	18	0.3	3.9	0.82	97.1	86.9685	67.4199
2014	7	5	14	48	18	0.3	3.9	0.78	96.8	86.9685	64.1576
2014	7	5	14	58	18	0.3	3.9	0.82	97.5	86.9685	67.6917
2014	7	5	15	8	18	0.3	3.9	0.82	95.5	86.9685	67.9635
2014	7	5	15	18	18	0.3	3.9	0.82	94.3	86.9685	67.9635
2014	7	5	15	28	18	0.3	3.9	0.82	94.4	86.9685	67.6916
2014	7	5	15	38	18	0.3	3.9	0.81	97	86.9029	66.8234
2014	7	5	15	48	18	0.3	3.9	0.85	95.7	86.9029	70.3547
2014	7	5	15	58	18	0.3	3.9	0.8	96.2	86.9029	65.4651
2014	7	5	16	8	18	0.3	3.9	0.82	98.1	86.9029	66.8234
2014	7	5	16	18	18	0.3	3.9	0.82	96.9	86.8373	67.3136
2014	7	5	16	28	18	0.3	3.9	0.82	96.7	86.7717	66.9892
2014	7	5	16	38	18	0.3	3.9	0.78	97	86.8373	64.3279
2014	7	5	16	48	18	0.3	3.9	0.8	97.5	86.9029	65.7368
2014	7	5	16	58	18	0.3	3.9	0.84	96.1	86.7717	68.8877
2014	7	5	17	8	18	0.3	3.9	0.82	93.7	86.9029	67.9098
2014	7	5	17	18	18	0.3	3.9	0.74	95.3	86.8373	61.3421
2014	7	5	17	28	18	0.3	3.9	0.8	97	86.8373	65.9564
2014	7	5	17	38	18	0.3	3.9	0.8	94.2	86.7717	66.1755
2014	7	5	17	48	18	0.3	3.9	0.8	93.5	86.8373	65.6849
2014	7	5	17	58	18	0.3	3.9	0.81	94.2	86.7717	66.4468
2014	7	5	18	8	18	0.3	3.9	0.8	95.9	86.8373	66.2278
2014	7	5	18	18	18	0.3	3.9	0.84	96.3	86.8373	69.2135
2014	7	5	18	28	18	0.3	3.9	0.79	96.2	86.8373	64.5992
2014	7	5	18	38	18	0.3	3.9	0.84	94.5	86.7717	69.1589
2014	7	5	18	48	18	0.3	3.9	0.81	94.4	86.8373	66.7706
2014	7	5	18	58	18	0.3	3.9	0.81	94.2	86.8373	66.7706

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	5	19	8	18	0.3	3.9	0.82	93.7	86.8373	67.8563
2014	7	5	19	18	18	0.3	3.9	0.83	96.8	86.9029	68.1815
2014	7	5	19	28	18	0.3	3.9	0.76	97.2	86.7717	62.1074
2014	7	5	19	38	18	0.3	3.9	0.79	93.8	86.8373	65.4135
2014	7	5	19	48	18	0.3	3.9	0.81	94.4	86.8373	66.4992
2014	7	5	19	58	18	0.3	3.9	0.8	95.7	86.9029	65.7368
2014	7	5	20	8	18	0.3	3.9	0.79	97.2	86.9029	64.6502
2014	7	5	20	18	18	0.3	3.9	0.83	95.7	86.9029	68.1815
2014	7	5	20	28	18	0.3	3.9	0.83	94.5	86.9029	68.4532
2014	7	5	20	38	18	0.3	3.9	0.81	94.4	86.9029	66.8233
2014	7	5	20	48	18	0.3	3.9	0.79	95.2	86.9029	65.1935
2014	7	5	20	58	18	0.3	3.9	0.78	93.9	86.9029	64.1069
2014	7	5	21	8	18	0.3	3.9	0.84	95.4	86.9029	69.2681
2014	7	5	21	18	18	0.3	3.9	0.8	95.2	86.9685	65.7886
2014	7	5	21	28	18	0.3	3.9	0.86	95.9	86.9685	71.2257
2014	7	5	21	38	18	0.3	3.9	0.8	95.4	86.9685	66.0605
2014	7	5	21	48	18	0.3	3.9	0.86	93.7	86.9685	71.2257
2014	7	5	21	58	18	0.3	3.9	0.81	95.8	87.0341	67.2008
2014	7	5	22	8	18	0.3	3.9	0.82	96.9	87.0341	67.2008
2014	7	5	22	18	18	0.3	3.9	0.84	96.2	87.0341	69.6494
2014	7	5	22	28	18	0.3	3.9	0.82	96	87.0341	67.4729
2014	7	5	22	38	18	0.3	3.9	0.82	95.5	87.0341	68.017
2014	7	5	22	48	18	0.3	3.9	0.86	95.2	87.0341	71.2818
2014	7	5	22	58	18	0.3	3.9	0.81	96.8	87.0341	66.6567
2014	7	5	23	8	18	0.3	3.9	0.84	96.7	87.0341	69.1053
2014	7	5	23	18	18	0.3	3.9	0.82	93.9	87.0341	68.017
2014	7	5	23	28	18	0.3	3.9	0.83	95.2	87.0341	68.8333
2014	7	5	23	38	18	0.3	3.9	0.81	95.8	87.0341	67.2009
2014	7	5	23	48	18	0.3	3.9	0.82	94.4	87.0341	67.745
2014	7	5	23	58	18	0.3	3.9	0.83	96.6	87.0341	68.5612
2014	7	6	0	8	18	0.3	3.9	0.83	95.7	87.0341	68.2892
2014	7	6	0	18	18	0.3	3.9	0.84	95.6	87.0997	69.7043
2014	7	6	0	28	18	0.3	3.9	0.84	96.3	87.0997	68.8875
2014	7	6	0	38	18	0.3	3.9	0.84	96.5	87.0997	69.4321
2014	7	6	0	48	18	0.3	3.9	0.9	96.9	87.0997	73.7886
2014	7	6	0	58	18	0.3	3.9	0.83	95	87.0997	68.8875
2014	7	6	1	8	18	0.3	3.9	0.87	94.5	87.0997	71.8827
2014	7	6	1	18	18	0.3	3.9	0.87	94.5	87.0997	71.8827
2014	7	6	1	28	18	0.3	3.9	0.83	96.1	87.0997	68.8876
2014	7	6	1	38	18	0.3	3.9	0.84	94.1	87.1654	69.2142
2014	7	6	1	48	18	0.3	3.9	0.82	94.3	87.1654	68.1243
2014	7	6	1	58	18	0.3	3.9	0.81	94	87.1654	66.7618
2014	7	6	2	8	18	0.3	3.9	0.87	95	87.1654	71.6668
2014	7	6	2	18	18	0.3	3.9	0.86	93.9	87.1654	71.6668
2014	7	6	2	28	18	0.3	3.9	0.85	95.5	87.1654	70.3043
2014	7	6	2	38	18	0.3	3.9	0.83	96.6	87.231	68.1778

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	2	48	18	0.3	3.9	0.84	94	87.231	69.8141
2014	7	6	2	58	18	0.3	3.9	0.85	94.4	87.231	70.3596
2014	7	6	3	8	18	0.3	3.9	0.82	94.8	87.231	67.9052
2014	7	6	3	18	18	0.3	3.9	0.83	95	87.3622	69.1044
2014	7	6	3	28	18	0.3	3.9	0.82	97.6	87.4278	67.7918
2014	7	6	3	38	18	0.3	3.9	0.86	92.6	87.4934	71.6748
2014	7	6	3	48	18	0.3	3.9	0.89	95.7	87.4934	73.8634
2014	7	6	3	58	18	0.3	3.9	0.85	96.4	87.4934	70.307
2014	7	6	4	8	18	0.3	3.9	0.85	96.2	87.4934	70.8542
2014	7	6	4	18	18	0.3	3.9	0.83	95.6	87.4934	69.2128
2014	7	6	4	28	18	0.3	3.9	0.81	93	87.5591	67.3505
2014	7	6	4	38	18	0.3	3.9	0.86	97.2	87.5591	71.4572
2014	7	6	4	48	18	0.3	3.9	0.85	98	87.5591	70.3621
2014	7	6	4	58	18	0.3	3.9	0.83	94.8	87.5591	68.9932
2014	7	6	5	8	18	0.3	3.9	0.83	95.9	87.5591	68.9932
2014	7	6	5	18	18	0.3	3.9	0.83	95.4	87.6247	69.3212
2014	7	6	5	28	18	0.3	3.9	0.85	95.1	87.6247	70.4172
2014	7	6	5	38	18	0.3	3.9	0.85	95.1	87.6247	70.4172
2014	7	6	5	48	18	0.3	3.9	0.86	95.3	87.6247	71.2392
2014	7	6	5	58	18	0.3	3.9	0.82	97.8	87.6247	67.6772
2014	7	6	6	8	18	0.3	3.9	0.83	97	87.6247	69.0472
2014	7	6	6	18	18	0.3	3.9	0.87	93.5	87.6903	72.3917
2014	7	6	6	28	18	0.3	3.9	0.9	96.1	87.6903	74.5854
2014	7	6	6	38	18	0.3	3.9	0.87	95.6	87.6903	72.3917
2014	7	6	6	48	18	0.3	3.9	0.8	93.3	87.6903	66.9075
2014	7	6	6	58	18	0.3	3.9	0.81	99	87.6903	67.1817
2014	7	6	7	8	18	0.3	3.9	0.82	96.7	87.6903	67.7301
2014	7	6	7	18	18	0.3	3.9	0.83	95.9	87.6903	69.1012
2014	7	6	7	28	18	0.3	3.9	0.86	95.3	87.6903	71.2949
2014	7	6	7	38	18	0.3	3.9	0.89	95.7	87.6903	74.037
2014	7	6	7	48	18	0.3	3.9	0.84	93.4	87.6903	69.9238
2014	7	6	7	58	18	0.3	3.9	0.83	96.3	87.6903	69.1012
2014	7	6	8	8	18	0.3	3.9	0.86	94.6	87.6903	71.8433
2014	7	6	8	18	18	0.3	3.9	0.88	94.7	87.7559	73.5459
2014	7	6	8	28	18	0.3	3.9	0.83	95.2	87.7559	69.1551
2014	7	6	8	38	18	0.3	3.9	0.84	94.3	87.7559	69.9784
2014	7	6	8	48	18	0.3	3.9	0.87	94.7	87.7559	72.7226
2014	7	6	8	58	18	0.3	3.9	0.84	94.5	87.7559	69.9784
2014	7	6	9	8	18	0.3	3.9	0.88	94.1	87.7559	73.2715
2014	7	6	9	18	18	0.3	3.9	0.83	95.7	87.7559	69.1551
2014	7	6	9	28	18	0.3	3.9	0.84	95.1	87.7559	70.2528
2014	7	6	9	38	18	0.3	3.9	0.84	93.1	87.7559	69.9784
2014	7	6	9	48	18	0.3	3.9	0.87	96.5	87.8215	72.2301
2014	7	6	9	58	18	0.3	3.9	0.82	94.4	87.8215	68.1105
2014	7	6	10	8	18	0.3	3.9	0.82	94.8	87.8215	68.1105
2014	7	6	10	18	18	0.3	3.9	0.85	94.4	87.8215	70.5822

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	10	28	18	0.3	3.9	0.83	97.9	87.8215	68.9344
2014	7	6	10	38	18	0.3	3.9	0.87	95.9	87.8215	72.23
2014	7	6	10	48	18	0.3	3.9	0.85	93.7	87.8215	71.4061
2014	7	6	10	58	18	0.3	3.9	0.89	94.4	87.8215	74.4271
2014	7	6	11	8	18	0.3	3.9	0.88	95.8	87.8215	73.6032
2014	7	6	11	18	18	0.3	3.9	0.86	96.1	87.8871	71.7366
2014	7	6	11	28	18	0.3	3.9	0.85	94.4	87.8871	70.912
2014	7	6	11	38	18	0.3	3.9	0.83	94.3	87.8871	68.988
2014	7	6	11	48	18	0.3	3.9	0.88	94.7	87.8871	73.6605
2014	7	6	11	58	18	0.3	3.9	0.83	96.1	87.8871	69.5377
2014	7	6	12	8	18	0.3	3.9	0.82	96.2	87.8871	67.8885
2014	7	6	12	18	18	0.3	3.9	0.85	93.1	87.9528	71.5172
2014	7	6	12	28	18	0.3	3.9	0.86	96.4	87.9528	71.5171
2014	7	6	12	38	18	0.3	3.9	0.84	95.6	87.9528	69.8667
2014	7	6	12	48	18	0.3	3.9	0.85	96.2	87.9528	71.242
2014	7	6	12	58	18	0.3	3.9	0.81	95.6	87.9528	67.391
2014	7	6	13	8	18	0.3	3.9	0.82	95.3	87.9528	68.4912
2014	7	6	13	18	18	0.3	3.9	0.83	96.4	87.9528	69.0413
2014	7	6	13	28	18	0.3	3.9	0.82	97.6	87.9528	68.2161
2014	7	6	13	38	18	0.3	3.9	0.87	96.3	87.9528	72.6171
2014	7	6	13	48	18	0.3	3.9	0.83	96.4	87.9528	69.0412
2014	7	6	13	58	18	0.3	3.9	0.85	92.2	87.9528	71.2417
2014	7	6	14	8	18	0.3	3.9	0.88	97.1	87.9528	73.1671
2014	7	6	14	18	18	0.3	3.9	0.8	95.9	87.9528	66.5656
2014	7	6	14	28	18	0.3	3.9	0.87	95.6	87.9528	72.892
2014	7	6	14	38	18	0.3	3.9	0.87	97.4	87.9528	72.0668
2014	7	6	14	48	18	0.3	3.9	0.84	96.3	87.9528	69.5912
2014	7	6	14	58	18	0.3	3.9	0.81	97.2	87.9528	67.3906
2014	7	6	15	8	18	0.3	3.9	0.9	95	87.9528	75.3674
2014	7	6	15	18	18	0.3	3.9	0.84	96.7	87.9528	70.1412
2014	7	6	15	28	18	0.3	3.9	0.83	96.4	87.9528	69.0409
2014	7	6	15	38	18	0.3	3.9	0.85	94.9	87.9528	71.2414
2014	7	6	15	48	18	0.3	3.9	0.84	95.6	87.9528	70.1411
2014	7	6	15	58	18	0.3	3.9	0.87	94.6	87.9528	72.3416
2014	7	6	16	8	18	0.3	3.9	0.83	96.8	87.9528	69.3159
2014	7	6	16	18	18	0.3	3.9	0.85	96.7	87.9528	70.4162
2014	7	6	16	28	18	0.3	3.9	0.83	94.1	88.0184	69.6452
2014	7	6	16	38	18	0.3	3.9	0.81	97.2	87.9528	67.3905
2014	7	6	16	48	18	0.3	3.9	0.86	95.3	87.9528	71.7915
2014	7	6	16	58	18	0.3	3.9	0.81	96	87.9528	67.6656
2014	7	6	17	8	18	0.3	3.9	0.86	96.3	87.9528	72.0666
2014	7	6	17	18	18	0.3	3.9	0.82	94.6	87.9528	68.4907
2014	7	6	17	28	18	0.3	3.9	0.84	97.2	87.9528	70.1411
2014	7	6	17	38	18	0.3	3.9	0.83	94.1	87.9528	69.591
2014	7	6	17	48	18	0.3	3.9	0.84	94.9	87.9528	70.4162
2014	7	6	17	58	18	0.3	3.9	0.81	96.5	87.9528	67.6655

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	6	18	8	18	0.3	3.9	0.88	96	87.9528	73.1668
2014	7	6	18	18	18	0.3	3.9	0.87	96.5	87.9528	72.8917
2014	7	6	18	28	18	0.3	3.9	0.85	96.6	87.9528	70.9663
2014	7	6	18	38	18	0.3	3.9	0.87	95.4	87.9528	72.6167
2014	7	6	18	48	18	0.3	3.9	0.89	95.5	88.0184	74.6001
2014	7	6	18	58	18	0.3	3.9	0.87	96	88.0184	72.9485
2014	7	6	19	8	18	0.3	3.9	0.84	96.7	88.0184	70.1957
2014	7	6	19	18	18	0.3	3.9	0.85	96.2	88.0184	71.0215
2014	7	6	19	28	18	0.3	3.9	0.84	95.8	88.0184	70.471
2014	7	6	19	38	18	0.3	3.9	0.84	96.7	88.0184	70.1957
2014	7	6	19	48	18	0.3	3.9	0.81	94.4	88.0184	67.9935
2014	7	6	19	58	18	0.3	3.9	0.85	94	88.0184	71.0215
2014	7	6	20	8	18	0.3	3.9	0.86	94.2	88.0184	71.8474
2014	7	6	20	18	18	0.3	3.9	0.86	95.3	88.0184	71.8474
2014	7	6	20	28	18	0.3	3.9	0.85	96.7	88.0184	70.471
2014	7	6	20	38	18	0.3	3.9	0.86	94.8	88.0184	71.8474
2014	7	6	20	48	18	0.3	3.9	0.87	96.1	88.0184	72.398
2014	7	6	20	58	18	0.3	3.9	0.84	92.7	88.0184	70.471
2014	7	6	21	8	18	0.3	3.9	0.85	96.4	88.084	70.8013
2014	7	6	21	18	18	0.3	3.9	0.87	96.3	88.084	72.7298
2014	7	6	21	28	18	0.3	3.9	0.84	95.1	88.084	70.5259
2014	7	6	21	38	18	0.3	3.9	0.86	94.8	88.084	71.9033
2014	7	6	21	48	18	0.3	3.9	0.87	96.3	88.084	72.7298
2014	7	6	21	58	18	0.3	3.9	0.86	93.1	88.084	72.1789
2014	7	6	22	8	18	0.3	3.9	0.87	93.9	88.084	73.2808
2014	7	6	22	18	18	0.3	3.9	0.85	96	88.084	71.3524
2014	7	6	22	28	18	0.3	3.9	0.84	95.8	88.084	70.2504
2014	7	6	22	38	18	0.3	3.9	0.9	96	88.1496	75.5435
2014	7	6	22	48	18	0.3	3.9	0.89	94.2	88.1496	74.9921
2014	7	6	22	58	18	0.3	3.9	0.83	91.6	88.1496	70.0294
2014	7	6	23	8	18	0.3	3.9	0.86	95.2	88.1496	72.235
2014	7	6	23	18	18	0.3	3.9	0.86	93.3	88.2808	72.6234
2014	7	6	23	28	18	0.3	3.9	0.87	95.2	88.2152	72.5671
2014	7	6	23	38	18	0.3	3.9	0.86	95.5	88.2808	71.795
2014	7	6	23	48	18	0.3	3.9	0.86	94.2	88.3465	71.8507
2014	7	6	23	58	18	0.3	3.9	0.87	95.2	88.3465	73.2324
2014	7	7	0	8	18	0.3	3.9	0.85	94.2	88.3465	71.5743
2014	7	7	0	18	18	0.3	3.9	0.86	95.2	88.4121	72.4595
2014	7	7	0	28	18	0.3	3.9	0.85	94	88.4121	71.3533
2014	7	7	0	38	18	0.3	3.9	0.83	92.5	88.4121	69.9705
2014	7	7	0	48	18	0.3	3.9	0.84	95.4	88.4121	70.5236
2014	7	7	0	58	18	0.3	3.9	0.85	95.3	88.4121	71.6299
2014	7	7	1	8	18	0.3	3.9	0.85	96.7	88.4777	70.855
2014	7	7	1	18	18	0.3	3.9	0.84	96.2	88.4777	70.855
2014	7	7	1	28	18	0.3	3.9	0.8	95.2	88.4777	67.5337
2014	7	7	1	38	18	0.3	3.9	0.89	94.9	88.4777	75.0067

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	1	48	18	0.3	3.9	0.87	94.1	88.4777	73.6228
2014	7	7	1	58	18	0.3	3.9	0.84	93.1	88.4777	70.5783
2014	7	7	2	8	18	0.3	3.9	0.87	96.5	88.4777	73.346
2014	7	7	2	18	18	0.3	3.9	0.86	96.1	88.5433	72.2948
2014	7	7	2	28	18	0.3	3.9	0.87	93.7	88.5433	73.4028
2014	7	7	2	38	18	0.3	3.9	0.88	96.4	88.5433	73.6798
2014	7	7	2	48	18	0.3	3.9	0.87	93.2	88.5433	73.4028
2014	7	7	2	58	18	0.3	3.9	0.84	95	88.5433	70.3559
2014	7	7	3	8	18	0.3	3.9	0.86	96.1	88.5433	72.2949
2014	7	7	3	18	18	0.3	3.9	0.86	94.4	88.5433	72.5719
2014	7	7	3	28	18	0.3	3.9	0.88	95.6	88.5433	73.6799
2014	7	7	3	38	18	0.3	3.9	0.89	95.1	88.5433	74.7879
2014	7	7	3	48	18	0.3	3.9	0.91	94.3	88.6089	77.0634
2014	7	7	3	58	18	0.3	3.9	0.84	94.5	88.5433	70.633
2014	7	7	4	8	18	0.3	3.9	0.8	94.9	88.5433	67.3091
2014	7	7	4	18	18	0.3	3.9	0.9	95.4	88.6089	75.6774
2014	7	7	4	28	18	0.3	3.9	0.88	93.2	88.6089	74.0142
2014	7	7	4	38	18	0.3	3.9	0.86	93.1	88.6089	72.6281
2014	7	7	4	48	18	0.3	3.9	0.84	95.1	88.6089	70.9649
2014	7	7	4	58	18	0.3	3.9	0.88	93	88.6089	74.5686
2014	7	7	5	8	18	0.3	3.9	0.87	94.6	88.6089	72.9054
2014	7	7	5	18	18	0.3	3.9	0.81	94.9	88.6089	68.1929
2014	7	7	5	28	18	0.3	3.9	0.86	94.1	88.6089	72.6282
2014	7	7	5	38	18	0.3	3.9	0.87	94.1	88.6089	73.737
2014	7	7	5	48	18	0.3	3.9	0.86	96.3	88.6089	72.351
2014	7	7	5	58	18	0.3	3.9	0.85	93.1	88.6089	72.0738
2014	7	7	6	8	18	0.3	3.9	0.87	96.3	88.6089	73.1827
2014	7	7	6	18	18	0.3	3.9	0.88	94	88.6745	74.6263
2014	7	7	6	28	18	0.3	3.9	0.87	96.5	88.6089	72.6283
2014	7	7	6	38	18	0.3	3.9	0.82	92.5	88.6745	69.6327
2014	7	7	6	48	18	0.3	3.9	0.83	95	88.6745	70.1876
2014	7	7	6	58	18	0.3	3.9	0.84	94.1	88.6745	70.465
2014	7	7	7	8	18	0.3	3.9	0.85	91.6	88.6745	71.5747
2014	7	7	7	18	18	0.3	3.9	0.85	94	88.6745	71.5747
2014	7	7	7	28	18	0.3	3.9	0.85	96.9	88.6745	71.0198
2014	7	7	7	38	18	0.3	3.9	0.88	96.6	88.6745	73.7941
2014	7	7	7	48	18	0.3	3.9	0.85	97.3	88.7402	71.6299
2014	7	7	7	58	18	0.3	3.9	0.88	96.2	88.7402	73.851
2014	7	7	8	8	18	0.3	3.9	0.83	93.6	88.7402	70.5194
2014	7	7	8	18	18	0.3	3.9	0.86	94.2	88.7402	72.1852
2014	7	7	8	28	18	0.3	3.9	0.83	94.8	88.7402	69.6865
2014	7	7	8	38	18	0.3	3.9	0.85	93.8	88.7402	71.3523
2014	7	7	8	48	18	0.3	3.9	0.86	95.5	88.7402	72.1852
2014	7	7	8	58	18	0.3	3.9	0.88	95.3	88.7402	74.4063
2014	7	7	9	8	18	0.3	3.9	0.87	95.2	88.8058	73.3522
2014	7	7	9	18	18	0.3	3.9	0.82	94.6	88.8058	69.4623

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	9	28	18	0.3	3.9	0.85	96.2	88.8058	71.6851
2014	7	7	9	38	18	0.3	3.9	0.89	94.7	88.8058	75.0193
2014	7	7	9	48	18	0.3	3.9	0.83	94.1	88.8058	69.7402
2014	7	7	9	58	18	0.3	3.9	0.85	96.4	88.8058	71.4073
2014	7	7	10	8	18	0.3	3.9	0.85	93.5	88.8714	71.7404
2014	7	7	10	18	18	0.3	3.9	0.85	95.7	88.8714	72.0184
2014	7	7	10	28	18	0.3	3.9	0.85	95.3	88.8714	71.4623
2014	7	7	10	38	18	0.3	3.9	0.87	94.3	88.937	73.7435
2014	7	7	10	48	18	0.3	3.9	0.88	94.3	88.937	74.3
2014	7	7	10	58	18	0.3	3.9	0.9	95.9	88.937	75.9697
2014	7	7	11	8	18	0.3	3.9	0.88	94.9	89.0026	74.6357
2014	7	7	11	18	18	0.3	3.9	0.87	94.1	89.0026	73.2432
2014	7	7	11	28	18	0.3	3.9	0.86	94.6	89.0026	72.6862
2014	7	7	11	38	18	0.3	3.9	0.88	94.5	89.0683	74.6931
2014	7	7	11	48	18	0.3	3.9	0.9	95	89.0683	76.3652
2014	7	7	11	58	18	0.3	3.9	0.83	96.6	89.1339	70.2877
2014	7	7	12	8	18	0.3	3.9	0.85	98.4	89.1339	71.4034
2014	7	7	12	18	18	0.3	3.9	0.87	96.9	89.1339	73.6347
2014	7	7	12	28	18	0.3	3.9	0.84	93.6	89.1339	71.4033
2014	7	7	12	38	18	0.3	3.9	0.86	94.4	89.1339	73.0768
2014	7	7	12	48	18	0.3	3.9	0.85	94	89.1339	71.9611
2014	7	7	12	58	18	0.3	3.9	0.87	95	89.1339	73.6345
2014	7	7	13	8	18	0.3	3.9	0.87	96.1	89.1339	73.3556
2014	7	7	13	18	18	0.3	3.9	0.86	97	89.1339	72.2398
2014	7	7	13	28	18	0.3	3.9	0.85	97.1	89.1339	71.6819
2014	7	7	13	38	18	0.3	3.9	0.88	96.6	89.0026	74.0782
2014	7	7	13	48	18	0.3	3.9	0.89	95.9	89.0026	75.1922
2014	7	7	13	58	18	0.3	3.9	0.8	93.5	89.0026	67.9515
2014	7	7	14	8	18	0.3	3.9	0.84	94.5	89.0026	71.0149
2014	7	7	14	18	18	0.3	3.9	0.87	97.2	89.0026	73.2428
2014	7	7	14	28	18	0.3	3.9	0.89	94.7	89.0026	74.9137
2014	7	7	14	38	18	0.3	3.9	0.83	95.2	89.0026	70.4578
2014	7	7	14	48	18	0.3	3.9	0.88	97.7	88.937	73.7429
2014	7	7	14	58	18	0.3	3.9	0.85	96	88.937	71.5167
2014	7	7	15	8	18	0.3	3.9	0.86	95.7	89.0026	72.4072
2014	7	7	15	18	18	0.3	3.9	0.88	96.8	89.0026	74.3567
2014	7	7	15	28	18	0.3	3.9	0.79	95.5	88.937	67.0643
2014	7	7	15	38	18	0.3	3.9	0.85	98.5	88.937	70.9602
2014	7	7	15	48	18	0.3	3.9	0.85	95.6	89.0026	71.5717
2014	7	7	15	58	18	0.3	3.9	0.84	96.5	89.0026	70.7363
2014	7	7	16	8	18	0.3	3.9	0.88	95.8	89.0026	74.0781
2014	7	7	16	18	18	0.3	3.9	0.9	93.8	89.0026	76.0275
2014	7	7	16	28	18	0.3	3.9	0.82	95.9	89.0683	69.6758
2014	7	7	16	38	18	0.3	3.9	0.86	96.6	89.0683	72.7415
2014	7	7	16	48	18	0.3	3.9	0.88	96.8	89.1339	74.4709
2014	7	7	16	58	18	0.3	3.9	0.87	95.4	89.1339	73.6342

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	7	17	8	18	0.3	3.9	0.89	96.4	89.1339	75.0288
2014	7	7	17	18	18	0.3	3.9	0.86	94.1	89.1339	73.0763
2014	7	7	17	28	18	0.3	3.9	0.85	94	89.1995	72.0159
2014	7	7	17	38	18	0.3	3.9	0.89	95.1	89.1995	75.0864
2014	7	7	17	48	18	0.3	3.9	0.86	93.9	89.1995	73.1324
2014	7	7	17	58	18	0.3	3.9	0.86	95.2	89.1995	73.1324
2014	7	7	18	8	18	0.3	3.9	0.86	93.7	89.1995	73.1324
2014	7	7	18	18	18	0.3	3.9	0.85	95.8	89.1995	72.0159
2014	7	7	18	28	18	0.3	3.9	0.9	95	89.2651	76.2613
2014	7	7	18	38	18	0.3	3.9	0.88	94.9	89.2651	74.3059
2014	7	7	18	48	18	0.3	3.9	0.84	96.7	89.2651	70.9538
2014	7	7	18	58	18	0.3	3.9	0.89	95.5	89.2651	75.7026
2014	7	7	19	8	18	0.3	3.9	0.89	94.9	89.2651	75.7027
2014	7	7	19	18	18	0.3	3.9	0.82	95.3	89.2651	69.8364
2014	7	7	19	28	18	0.3	3.9	0.86	95	89.2651	73.1886
2014	7	7	19	38	18	0.3	3.9	0.87	94.1	89.2651	73.4679
2014	7	7	19	48	18	0.3	3.9	0.9	94	89.3307	76.5994
2014	7	7	19	58	18	0.3	3.9	0.88	94.3	89.3307	75.2016
2014	7	7	20	8	18	0.3	3.9	0.88	97.3	89.3307	74.3629
2014	7	7	20	18	18	0.3	3.9	0.87	95.6	89.3307	74.0834
2014	7	7	20	28	18	0.3	3.9	0.88	94.9	89.3307	74.3629
2014	7	7	20	38	18	0.3	3.9	0.88	96.4	89.3307	74.9221
2014	7	7	20	48	18	0.3	3.9	0.87	94.1	89.3307	74.363
2014	7	7	20	58	18	0.3	3.9	0.89	93.4	89.3307	75.7608
2014	7	7	21	8	18	0.3	3.9	0.89	95.7	89.3307	75.2017
2014	7	7	21	18	18	0.3	3.9	0.86	94.8	89.3307	73.2448
2014	7	7	21	28	18	0.3	3.9	0.85	93.3	89.3963	72.4616
2014	7	7	21	38	18	0.3	3.9	0.87	93	89.3963	73.8604
2014	7	7	21	48	18	0.3	3.9	0.84	94.7	89.3963	71.3425
2014	7	7	21	58	18	0.3	3.9	0.91	96	89.3963	76.938
2014	7	7	22	8	18	0.3	3.9	0.86	95.7	89.3963	73.0211
2014	7	7	22	18	18	0.3	3.9	0.88	94	89.3963	75.2594
2014	7	7	22	28	18	0.3	3.9	0.88	94.3	89.3963	74.6998
2014	7	7	22	38	18	0.3	3.9	0.87	93.2	89.3963	74.4201
2014	7	7	22	48	18	0.3	3.9	0.89	93.8	89.3963	75.5392
2014	7	7	22	58	18	0.3	3.9	0.89	92.1	89.3963	75.5392
2014	7	7	23	8	18	0.3	3.9	0.91	94.8	89.3963	76.9381
2014	7	7	23	18	18	0.3	3.9	0.87	97.2	89.3963	73.5808
2014	7	7	23	28	18	0.3	3.9	0.89	93.4	89.3963	75.819
2014	7	7	23	38	18	0.3	3.9	0.88	94.9	89.3963	74.4201
2014	7	7	23	48	18	0.3	3.9	0.86	93.9	89.3963	73.5808
2014	7	7	23	58	18	0.3	3.9	0.84	93.1	89.3963	71.9022
2014	7	8	0	8	18	0.3	3.9	0.89	95.3	89.462	75.3171
2014	7	8	0	18	18	0.3	3.9	0.86	96.4	89.462	72.5173
2014	7	8	0	28	18	0.3	3.9	0.86	94	89.462	72.7973
2014	7	8	0	38	18	0.3	3.9	0.88	94.3	89.462	74.7572

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	0	48	18	0.3	3.9	0.87	95.2	89.462	73.9173
2014	7	8	0	58	18	0.3	3.9	0.85	95.6	89.462	71.9573
2014	7	8	1	8	18	0.3	3.9	0.83	95.9	89.462	70.2774
2014	7	8	1	18	18	0.3	3.9	0.85	95.1	89.462	72.2374
2014	7	8	1	28	18	0.3	3.9	0.88	93.2	89.462	75.3173
2014	7	8	1	38	18	0.3	3.9	0.84	96.7	89.462	71.1174
2014	7	8	1	48	18	0.3	3.9	0.87	95.6	89.462	73.9173
2014	7	8	1	58	18	0.3	3.9	0.87	93.4	89.462	74.4773
2014	7	8	2	8	18	0.3	3.9	0.87	95.2	89.462	73.9174
2014	7	8	2	18	18	0.3	3.9	0.89	95.3	89.462	75.5973
2014	7	8	2	28	18	0.3	3.9	0.89	95.1	89.462	75.3173
2014	7	8	2	38	18	0.3	3.9	0.86	96.4	89.462	72.5174
2014	7	8	2	48	18	0.3	3.9	0.86	93.3	89.462	73.3574
2014	7	8	2	58	18	0.3	3.9	0.89	94.5	89.462	75.3174
2014	7	8	3	8	18	0.3	3.9	0.86	95.3	89.5276	72.8532
2014	7	8	3	18	18	0.3	3.9	0.89	95.3	89.5276	75.6552
2014	7	8	3	28	18	0.3	3.9	0.86	94.6	89.5276	73.1334
2014	7	8	3	38	18	0.3	3.9	0.87	95.2	89.5276	73.974
2014	7	8	3	48	18	0.3	3.9	0.86	94.4	89.5276	72.8532
2014	7	8	3	58	18	0.3	3.9	0.88	96.2	89.5276	74.8147
2014	7	8	4	8	18	0.3	3.9	0.9	95.7	89.5276	76.2157
2014	7	8	4	18	18	0.3	3.9	0.92	95.5	89.5276	78.4574
2014	7	8	4	28	18	0.3	3.9	0.88	95.2	89.5932	74.5915
2014	7	8	4	38	18	0.3	3.9	0.89	96.2	89.5932	75.4327
2014	7	8	4	48	18	0.3	3.9	0.89	96.8	89.5932	75.7132
2014	7	8	4	58	18	0.3	3.9	0.84	92.5	89.5932	71.7873
2014	7	8	5	8	18	0.3	3.9	0.87	94.8	89.5932	73.7503
2014	7	8	5	18	18	0.3	3.9	0.84	95.2	89.5932	71.2265
2014	7	8	5	28	18	0.3	3.9	0.93	94.6	89.5932	79.6391
2014	7	8	5	38	18	0.3	4.3	0.9	97.3	89.6588	76.3324
2014	7	8	5	48	18	0.3	4.3	0.87	94.1	89.6588	74.0873
2014	7	8	5	58	18	0.3	4.3	0.87	94.1	89.7244	74.1438
2014	7	8	6	8	18	0.3	4.3	0.86	96.3	89.79	73.3572
2014	7	8	6	18	18	0.3	4.3	0.87	93.3	89.8556	74.257
2014	7	8	6	28	18	0.3	4.3	0.87	94.1	89.8556	73.9757
2014	7	8	6	38	18	0.3	4.3	0.87	92.6	89.8556	74.5383
2014	7	8	6	48	18	0.3	4.3	0.85	95.3	89.8556	72.5694
2014	7	8	6	58	18	0.3	4.3	0.86	93.9	89.8556	73.9757
2014	7	8	7	8	18	0.3	4.3	0.89	93.6	89.9213	76.0025
2014	7	8	7	18	18	0.3	4.3	0.87	95.9	89.9213	74.0321
2014	7	8	7	28	18	0.3	4.3	0.87	93.4	89.9213	74.8766
2014	7	8	7	38	18	0.3	4.3	0.91	96.9	89.9213	77.1285
2014	7	8	7	48	18	0.3	4.3	0.89	93	89.9213	76.284
2014	7	8	7	58	18	0.3	4.3	0.87	95	89.9213	74.0321
2014	7	8	8	8	18	0.3	4.3	0.85	95.3	89.9213	72.3431
2014	7	8	8	18	18	0.3	4.3	0.86	95.9	89.9213	73.1876

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	8	28	18	0.3	4.3	0.86	95.3	89.9213	73.4691
2014	7	8	8	38	18	0.3	4.3	0.86	94.8	89.9213	73.1875
2014	7	8	8	48	18	0.3	4.3	0.86	95.3	89.9869	73.2432
2014	7	8	8	58	18	0.3	4.3	0.85	94.9	89.9869	72.6798
2014	7	8	9	8	18	0.3	4.3	0.86	93.7	89.9869	73.8066
2014	7	8	9	18	18	0.3	4.3	0.88	96.2	89.9869	74.9334
2014	7	8	9	28	18	0.3	4.3	0.88	96	89.9869	74.9334
2014	7	8	9	38	18	0.3	4.3	0.84	93.3	89.9869	72.398
2014	7	8	9	48	18	0.3	4.3	0.91	93.9	89.9869	78.0321
2014	7	8	9	58	18	0.3	4.3	0.9	96.9	89.9869	76.3418
2014	7	8	10	8	18	0.3	4.3	0.89	97.4	89.9869	75.4967
2014	7	8	10	18	18	0.3	4.3	0.82	95.5	89.9869	70.1443
2014	7	8	10	28	18	0.3	4.3	0.85	96.7	89.9869	72.1162
2014	7	8	10	38	18	0.3	3.9	0.88	96	89.9869	75.4966
2014	7	8	10	48	18	0.3	3.9	0.89	96.1	89.9869	76.06
2014	7	8	10	58	18	0.3	3.9	0.91	97.3	89.9869	77.4684
2014	7	8	11	8	18	0.3	3.9	0.84	96.8	89.9869	71.2709
2014	7	8	11	18	18	0.3	3.9	0.85	95.1	89.9869	72.9612
2014	7	8	11	28	18	0.3	3.9	0.87	96.1	89.9213	74.3131
2014	7	8	11	38	18	0.3	3.9	0.84	93.8	89.9213	71.4982
2014	7	8	11	48	18	0.3	3.9	0.86	97.5	89.9213	73.187
2014	7	8	11	58	18	0.3	3.9	0.87	94.3	89.8556	74.5377
2014	7	8	12	8	18	0.3	3.9	0.86	95.9	89.8556	73.1313
2014	7	8	12	18	18	0.3	3.9	0.84	94.9	89.8556	71.7249
2014	7	8	12	28	18	0.3	3.9	0.86	95.5	89.8556	73.6937
2014	7	8	12	38	18	0.3	3.9	0.84	96.8	89.79	71.1081
2014	7	8	12	48	18	0.3	3.9	0.84	94.3	89.79	71.6702
2014	7	8	12	58	18	0.3	3.9	0.88	94.9	89.7244	75.2666
2014	7	8	13	8	18	0.3	3.9	0.83	96.8	89.79	70.546
2014	7	8	13	18	18	0.3	3.9	0.83	97.3	89.7244	70.4922
2014	7	8	13	28	18	0.3	3.9	0.84	94.3	89.7244	71.3347
2014	7	8	13	38	18	0.3	3.9	0.81	94.4	89.79	68.8595
2014	7	8	13	48	18	0.3	3.9	0.83	93.4	89.79	70.827
2014	7	8	13	58	18	0.3	3.9	0.86	96.8	89.79	73.0755
2014	7	8	14	8	18	0.3	3.9	0.86	96.8	89.79	73.0755
2014	7	8	14	18	18	0.3	3.9	0.87	97.6	89.79	74.1997
2014	7	8	14	28	18	0.3	3.9	0.86	94.4	89.79	73.3565
2014	7	8	14	38	18	0.3	3.9	0.87	94.8	89.79	74.1997
2014	7	8	14	48	18	0.3	3.9	0.86	94.2	89.7244	73.3006
2014	7	8	14	58	18	0.3	3.9	0.89	93.4	89.79	75.886
2014	7	8	15	8	18	0.3	3.9	0.86	92.2	89.6588	73.2447
2014	7	8	15	18	18	0.3	3.9	0.89	95.5	89.6588	76.0509
2014	7	8	15	28	18	0.3	3.9	0.86	95.2	89.6588	73.5252
2014	7	8	15	38	18	0.3	3.9	0.89	95.3	89.6588	75.4896
2014	7	8	15	48	18	0.3	3.9	0.83	94.3	89.6588	70.7189
2014	7	8	15	58	18	0.3	3.9	0.83	96.1	89.6588	70.4383

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	16	8	18	0.3	3.9	0.85	94.9	89.6588	72.1221
2014	7	8	16	18	18	0.3	3.9	0.86	95.7	89.6588	72.964
2014	7	8	16	28	18	0.3	3.9	0.84	96.7	89.6588	71.5609
2014	7	8	16	38	18	0.3	3.9	0.9	96.2	89.6588	76.8928
2014	7	8	16	48	18	0.3	3.9	0.86	93.3	89.6588	73.5253
2014	7	8	16	58	18	0.3	3.9	0.86	94.4	89.6588	73.5253
2014	7	8	17	8	18	0.3	3.9	0.85	97.3	89.6588	72.4027
2014	7	8	17	18	18	0.3	3.9	0.82	91.6	89.6588	69.8771
2014	7	8	17	28	18	0.3	3.9	0.84	95.4	89.6588	71.2802
2014	7	8	17	38	18	0.3	3.9	0.85	92.4	89.6588	72.4027
2014	7	8	17	48	18	0.3	3.9	0.83	95.7	89.6588	70.4383
2014	7	8	17	58	18	0.3	3.9	0.85	94.9	89.6588	72.6833
2014	7	8	18	8	18	0.3	3.9	0.9	96.1	89.6588	76.6122
2014	7	8	18	18	18	0.3	3.9	0.85	92.2	89.6588	72.964
2014	7	8	18	28	18	0.3	3.9	0.86	95.7	89.6588	73.2446
2014	7	8	18	38	18	0.3	3.9	0.89	94	89.6588	76.0509
2014	7	8	18	48	18	0.3	3.9	0.84	93.8	89.6588	71.2802
2014	7	8	18	58	18	0.3	3.9	0.92	93.9	89.6588	78.8572
2014	7	8	19	8	18	0.3	3.9	0.84	95.2	89.6588	71.5608
2014	7	8	19	18	18	0.3	3.9	0.91	93.9	89.6588	77.7347
2014	7	8	19	28	18	0.3	3.9	0.88	94.1	89.6588	75.209
2014	7	8	19	38	18	0.3	3.9	0.86	94	89.6588	72.964
2014	7	8	19	48	18	0.3	3.9	0.84	94	89.6588	71.5608
2014	7	8	19	58	18	0.3	3.9	0.88	92.4	89.6588	75.209
2014	7	8	20	8	18	0.3	3.9	0.87	94.3	89.6588	74.0865
2014	7	8	20	18	18	0.3	3.9	0.86	95.3	89.6588	73.2446
2014	7	8	20	28	18	0.3	3.9	0.83	94.1	89.6588	70.9996
2014	7	8	20	38	18	0.3	3.9	0.84	95.2	89.6588	71.5609
2014	7	8	20	48	18	0.3	3.9	0.87	94.1	89.6588	74.3672
2014	7	8	20	58	18	0.3	3.9	0.86	94.4	89.6588	73.5253
2014	7	8	21	8	18	0.3	3.9	0.85	96.2	89.6588	72.4028
2014	7	8	21	18	18	0.3	3.9	0.92	95.1	89.6588	78.2961
2014	7	8	21	28	18	0.3	3.9	0.86	94.4	89.6588	73.5253
2014	7	8	21	38	18	0.3	3.9	0.86	96.6	89.6588	73.2447
2014	7	8	21	48	18	0.3	3.9	0.83	95.7	89.6588	70.719
2014	7	8	21	58	18	0.3	3.9	0.9	95.4	89.7244	76.6708
2014	7	8	22	8	18	0.3	3.9	0.87	95.8	89.7244	74.1432
2014	7	8	22	18	18	0.3	3.9	0.85	96.9	89.7244	72.4581
2014	7	8	22	28	18	0.3	3.9	0.87	95.8	89.7244	74.1432
2014	7	8	22	38	18	0.3	3.9	0.86	96.6	89.7244	73.0198
2014	7	8	22	48	18	0.3	3.9	0.87	95.2	89.7244	74.4241
2014	7	8	22	58	18	0.3	3.9	0.87	96.5	89.7244	74.4241
2014	7	8	23	8	18	0.3	3.9	0.89	96.5	89.7244	75.8283
2014	7	8	23	18	18	0.3	3.9	0.9	96.2	89.79	77.0104
2014	7	8	23	28	18	0.3	3.9	0.89	94.2	89.8556	76.2253
2014	7	8	23	38	18	0.3	3.9	0.91	95	89.8556	77.3504

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	8	23	48	18	0.3	3.9	0.87	92.8	89.9213	74.8759
2014	7	8	23	58	18	0.3	3.9	0.87	94.1	89.9213	74.313
2014	7	9	0	8	18	0.3	3.9	0.86	95.1	89.9869	73.2427
2014	7	9	0	18	18	0.3	3.9	0.86	94.2	89.9869	73.2427
2014	7	9	0	28	18	0.3	3.9	0.87	94.8	89.9869	74.3696
2014	7	9	0	38	18	0.3	3.9	0.89	95.1	89.9869	76.3415
2014	7	9	0	48	18	0.3	3.9	0.89	97.2	89.9869	75.7781
2014	7	9	0	58	18	0.3	3.9	0.85	95.5	89.9869	72.6794
2014	7	9	1	8	18	0.3	3.9	0.87	94.5	89.9869	74.3696
2014	7	9	1	18	18	0.3	3.9	0.87	94.1	89.9869	74.3696
2014	7	9	1	28	18	0.3	3.9	0.87	94.3	89.9869	74.6514
2014	7	9	1	38	18	0.3	3.9	0.87	94.5	90.0525	74.4262
2014	7	9	1	48	18	0.3	3.9	0.89	93.8	89.9869	76.3416
2014	7	9	1	58	18	0.3	3.9	0.89	95.7	90.0525	76.1178
2014	7	9	2	8	18	0.3	3.9	0.87	96.1	90.0525	74.1444
2014	7	9	2	18	18	0.3	3.9	0.89	95.7	90.0525	76.1178
2014	7	9	2	28	18	0.3	3.9	0.9	95.7	90.0525	76.6817
2014	7	9	2	38	18	0.3	3.9	0.86	94.6	90.0525	73.5806
2014	7	9	2	48	18	0.3	3.9	0.87	98.3	90.0525	73.5806
2014	7	9	2	58	18	0.3	3.9	0.88	95.1	90.0525	75.2721
2014	7	9	3	8	18	0.3	4.3	0.85	96.9	90.0525	72.7349
2014	7	9	3	18	18	0.3	3.9	0.85	93.5	90.0525	73.0168
2014	7	9	3	28	18	0.3	3.9	0.86	97	90.0525	73.0168
2014	7	9	3	38	18	0.3	3.9	0.9	94	90.1181	77.3042
2014	7	9	3	48	18	0.3	4.3	0.9	96.1	90.1181	77.0221
2014	7	9	3	58	18	0.3	4.3	0.89	96.4	90.1181	75.8936
2014	7	9	4	8	18	0.3	4.3	0.93	94.5	90.1181	79.5613
2014	7	9	4	18	18	0.3	4.3	0.89	96.4	90.1181	75.8936
2014	7	9	4	28	18	0.3	4.3	0.88	96	90.1181	75.0472
2014	7	9	4	38	18	0.3	4.3	0.86	96.1	90.1181	73.6366
2014	7	9	4	48	18	0.3	4.3	0.9	95.8	90.1181	77.3043
2014	7	9	4	58	18	0.3	4.3	0.9	96.9	90.1181	77.0222
2014	7	9	5	8	18	0.3	4.3	0.9	94.8	90.1181	77.0222
2014	7	9	5	18	18	0.3	4.3	0.83	92.7	90.1181	71.0974
2014	7	9	5	28	18	0.3	4.3	0.87	95.6	90.1181	74.483
2014	7	9	5	38	18	0.3	4.3	0.84	96.2	90.1181	72.226
2014	7	9	5	48	18	0.3	4.3	0.87	95.4	90.1181	74.7652
2014	7	9	5	58	18	0.3	4.3	0.83	94.3	90.1181	71.3796
2014	7	9	6	8	18	0.3	4.3	0.87	93.4	90.1181	75.0474
2014	7	9	6	18	18	0.3	4.3	0.85	96.4	90.1837	72.5632
2014	7	9	6	28	18	0.3	4.3	0.87	95.2	90.1181	74.4831
2014	7	9	6	38	18	0.3	4.3	0.88	94.7	90.1837	75.6691
2014	7	9	6	48	18	0.3	4.3	0.85	94.2	90.1837	72.5633
2014	7	9	6	58	18	0.3	4.3	0.88	94.3	90.1837	75.3868
2014	7	9	7	8	18	0.3	4.3	0.86	93.7	90.1837	74.2574
2014	7	9	7	18	18	0.3	4.3	0.88	94.1	90.1837	75.3868

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	7	28	18	0.3	4.3	0.9	94.8	90.1837	77.0809
2014	7	9	7	38	18	0.3	4.3	0.87	93.7	90.1837	74.8221
2014	7	9	7	48	18	0.3	4.3	0.87	95.2	90.1837	74.5397
2014	7	9	7	58	18	0.3	4.3	0.91	96.4	90.1837	77.9279
2014	7	9	8	8	18	0.3	4.3	0.91	93.5	90.1837	78.2103
2014	7	9	8	18	18	0.3	4.3	0.94	94.2	90.1837	80.7514
2014	7	9	8	28	18	0.3	4.3	0.92	95.8	90.1837	78.4926
2014	7	9	8	38	18	0.3	4.3	0.9	95	90.1837	77.0808
2014	7	9	8	48	18	0.3	4.3	0.89	95.1	90.2494	76.5742
2014	7	9	8	58	18	0.3	4.3	0.88	94.9	90.1837	75.6691
2014	7	9	9	8	18	0.3	4.3	0.85	97.3	90.2494	72.9009
2014	7	9	9	18	18	0.3	4.3	0.84	97.7	90.2494	71.488
2014	7	9	9	28	18	0.3	4.3	0.9	95	90.2494	77.4218
2014	7	9	9	38	18	0.3	4.3	0.88	96.2	90.2494	75.1613
2014	7	9	9	48	18	0.3	4.3	0.88	95.6	90.2494	75.1613
2014	7	9	9	58	18	0.3	4.3	0.83	95.2	90.2494	70.9228
2014	7	9	10	8	18	0.3	4.3	0.88	96.4	90.2494	75.7263
2014	7	9	10	18	18	0.3	4.3	0.85	95.1	90.2494	73.1833
2014	7	9	10	28	18	0.3	4.3	0.91	94.6	90.2494	77.7042
2014	7	9	10	38	18	0.3	3.9	0.88	94.9	90.2494	75.7262
2014	7	9	10	48	18	0.3	3.9	0.88	96.4	90.2494	75.7262
2014	7	9	10	58	18	0.3	3.9	0.86	93.9	90.2494	74.3134
2014	7	9	11	8	18	0.3	3.9	0.85	94.4	90.2494	72.618
2014	7	9	11	18	18	0.3	4.3	0.84	95.2	90.315	72.1074
2014	7	9	11	28	18	0.3	3.9	0.84	94.5	90.2494	72.0528
2014	7	9	11	38	18	0.3	3.9	0.88	95.2	90.2494	75.1609
2014	7	9	11	48	18	0.3	3.9	0.83	95.9	90.2494	70.9225
2014	7	9	11	58	18	0.3	3.9	0.84	94.7	90.2494	72.3352
2014	7	9	12	8	18	0.3	3.9	0.84	94.7	90.2494	72.3352
2014	7	9	12	18	18	0.3	3.9	0.82	97.8	90.2494	70.3572
2014	7	9	12	28	18	0.3	3.9	0.87	94.5	90.2494	74.8781
2014	7	9	12	38	18	0.3	3.9	0.85	94	90.2494	72.9002
2014	7	9	12	48	18	0.3	3.9	0.83	95.4	90.2494	71.2048
2014	7	9	12	58	18	0.3	3.9	0.86	98.1	90.2494	73.1827
2014	7	9	13	8	18	0.3	3.9	0.88	94.7	90.2494	75.1605
2014	7	9	13	18	18	0.3	3.9	0.83	94.3	90.2494	71.2047
2014	7	9	13	28	18	0.3	4.3	0.88	95.4	90.315	75.2174
2014	7	9	13	38	18	0.3	3.9	0.86	94.1	90.2494	74.0302
2014	7	9	13	48	18	0.3	3.9	0.84	97.8	90.2494	71.7697
2014	7	9	13	58	18	0.3	3.9	0.81	95.3	90.2494	69.7917
2014	7	9	14	8	18	0.3	4.3	0.86	94.2	90.315	73.8034
2014	7	9	14	18	18	0.3	3.9	0.86	96.6	90.2494	73.7475
2014	7	9	14	28	18	0.3	3.9	0.85	94.4	90.2494	72.6172
2014	7	9	14	38	18	0.3	3.9	0.86	94.6	90.2494	73.4649
2014	7	9	14	48	18	0.3	3.9	0.85	95.3	90.2494	72.6172
2014	7	9	14	58	18	0.3	3.9	0.87	97.8	90.2494	74.0299

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	15	8	18	0.3	3.9	0.81	95.1	90.2494	69.509
2014	7	9	15	18	18	0.3	3.9	0.88	97.5	90.2494	74.8776
2014	7	9	15	28	18	0.3	3.9	0.87	95	90.2494	74.3125
2014	7	9	15	38	18	0.3	3.9	0.84	95.6	90.2494	71.7695
2014	7	9	15	48	18	0.3	3.9	0.88	95.1	90.2494	75.4427
2014	7	9	15	58	18	0.3	3.9	0.88	96	90.2494	75.7252
2014	7	9	16	8	18	0.3	3.9	0.86	95.5	90.2494	73.4647
2014	7	9	16	18	18	0.3	3.9	0.84	94.5	90.2494	71.7694
2014	7	9	16	28	18	0.3	3.9	0.86	93.7	90.2494	74.3124
2014	7	9	16	38	18	0.3	3.9	0.81	97.9	90.2494	69.5089
2014	7	9	16	48	18	0.3	3.9	0.91	96.4	90.1837	77.6441
2014	7	9	16	58	18	0.3	3.9	0.89	95.7	90.1837	75.9501
2014	7	9	17	8	18	0.3	3.9	0.86	94.6	90.1837	73.409
2014	7	9	17	18	18	0.3	3.9	0.84	95	90.1837	71.715
2014	7	9	17	28	18	0.3	3.9	0.84	95.6	90.1837	72.2797
2014	7	9	17	38	18	0.3	3.9	0.88	96.2	90.1837	75.6678
2014	7	9	17	48	18	0.3	3.9	0.87	95.6	90.1837	74.8207
2014	7	9	17	58	18	0.3	3.9	0.82	95.8	90.1837	70.0209
2014	7	9	18	8	18	0.3	3.9	0.84	95	90.1837	71.715
2014	7	9	18	18	18	0.3	3.9	0.83	95.2	90.1837	71.1503
2014	7	9	18	28	18	0.3	3.9	0.84	96.9	90.1837	71.9973
2014	7	9	18	38	18	0.3	3.9	0.85	97.7	90.1837	72.8444
2014	7	9	18	48	18	0.3	3.9	0.88	94.5	90.1837	75.3854
2014	7	9	18	58	18	0.3	3.9	0.88	96	90.1837	75.3854
2014	7	9	19	8	18	0.3	3.9	0.85	97.6	90.1837	72.2797
2014	7	9	19	18	18	0.3	3.9	0.88	96.6	90.1837	75.3854
2014	7	9	19	28	18	0.3	3.9	0.89	97.2	90.1837	75.6678
2014	7	9	19	38	18	0.3	3.9	0.86	96.6	90.1837	73.6914
2014	7	9	19	48	18	0.3	3.9	0.9	96.1	90.1837	77.0795
2014	7	9	19	58	18	0.3	3.9	0.88	95.2	90.1837	75.1031
2014	7	9	20	8	18	0.3	3.9	0.92	96.2	90.1837	78.4912
2014	7	9	20	18	18	0.3	3.9	0.89	94.6	90.1837	76.5148
2014	7	9	20	28	18	0.3	3.9	0.87	95.9	90.2494	74.3124
2014	7	9	20	38	18	0.3	3.9	0.87	96.3	90.2494	74.595
2014	7	9	20	48	18	0.3	3.9	0.88	93.4	90.2494	75.7252
2014	7	9	20	58	18	0.3	3.9	0.88	93.4	90.2494	75.7253
2014	7	9	21	8	18	0.3	3.9	0.86	94.8	90.2494	73.7473
2014	7	9	21	18	18	0.3	3.9	0.84	95.6	90.2494	71.7695
2014	7	9	21	28	18	0.3	3.9	0.85	94.7	90.2494	72.8997
2014	7	9	21	38	18	0.3	3.9	0.9	95.4	90.2494	77.1381
2014	7	9	21	48	18	0.3	3.9	0.88	92.8	90.2494	75.4427
2014	7	9	21	58	18	0.3	3.9	0.93	95.5	90.2494	79.3986
2014	7	9	22	8	18	0.3	3.9	0.87	93.3	90.2494	74.5951
2014	7	9	22	18	18	0.3	3.9	0.92	94.7	90.2494	78.5509
2014	7	9	22	28	18	0.3	3.9	0.85	93.3	90.2494	73.4649
2014	7	9	22	38	18	0.3	3.9	0.87	95.8	90.2494	74.5951

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	9	22	48	18	0.3	3.9	0.89	94.4	90.2494	76.2905
2014	7	9	22	58	18	0.3	3.9	0.89	94.2	90.2494	76.2905
2014	7	9	23	8	18	0.3	3.9	0.9	95.4	90.2494	77.1382
2014	7	9	23	18	18	0.3	4.3	0.85	96.4	90.315	72.6724
2014	7	9	23	28	18	0.3	4.3	0.89	93.4	90.315	76.3484
2014	7	9	23	38	18	0.3	4.3	0.88	95.1	90.315	75.5001
2014	7	9	23	48	18	0.3	3.9	0.85	94.7	90.2494	72.8999
2014	7	9	23	58	18	0.3	4.3	0.9	94.6	90.315	76.914
2014	7	10	0	8	18	0.3	4.3	0.88	93.8	90.315	75.7829
2014	7	10	0	18	18	0.3	4.3	0.85	96.9	90.315	72.9552
2014	7	10	0	28	18	0.3	4.3	0.84	94.2	90.315	72.3897
2014	7	10	0	38	18	0.3	4.3	0.83	95.2	90.315	71.2587
2014	7	10	0	48	18	0.3	4.3	0.86	94.4	90.315	73.8036
2014	7	10	0	58	18	0.3	4.3	0.88	94.3	90.315	76.0658
2014	7	10	1	8	18	0.3	4.3	0.86	98.1	90.315	73.2381
2014	7	10	1	18	18	0.3	4.3	0.88	95.3	90.315	75.5003
2014	7	10	1	28	18	0.3	4.3	0.87	93.2	90.315	74.9348
2014	7	10	1	38	18	0.3	4.3	0.89	94	90.315	76.6314
2014	7	10	1	48	18	0.3	4.3	0.89	94.2	90.315	76.9143
2014	7	10	1	58	18	0.3	4.3	0.85	94.2	90.315	72.9554
2014	7	10	2	8	18	0.3	4.3	0.89	93.8	90.315	76.6315
2014	7	10	2	18	18	0.3	4.3	0.86	96.6	90.315	73.8038
2014	7	10	2	28	18	0.3	4.3	0.87	94.1	90.315	74.9349
2014	7	10	2	38	18	0.3	4.3	0.88	94.3	90.315	75.5005
2014	7	10	2	48	18	0.3	4.3	0.89	95.7	90.315	76.0661
2014	7	10	2	58	18	0.3	4.3	0.88	93.6	90.315	75.5005
2014	7	10	3	8	18	0.3	4.3	0.89	94.4	90.315	76.3489
2014	7	10	3	18	18	0.3	4.3	0.85	96.7	90.315	72.3901
2014	7	10	3	28	18	0.3	4.3	0.9	94	90.3806	77.2558
2014	7	10	3	38	18	0.3	4.3	0.9	94	90.3806	77.8218
2014	7	10	3	48	18	0.3	4.3	0.91	93.9	90.3806	78.6708
2014	7	10	3	58	18	0.3	4.3	0.87	94.1	90.3806	75.2749
2014	7	10	4	8	18	0.3	4.3	0.91	95	90.3806	77.8218
2014	7	10	4	18	18	0.3	4.3	0.89	94.9	90.3806	76.6899
2014	7	10	4	28	18	0.3	4.3	0.85	94.2	90.3806	72.7281
2014	7	10	4	38	18	0.3	4.3	0.87	93.4	90.3806	75.275
2014	7	10	4	48	18	0.3	4.3	0.88	95.3	90.3806	75.558
2014	7	10	4	58	18	0.3	4.3	0.89	95.3	90.3806	76.407
2014	7	10	5	8	18	0.3	4.3	0.91	96.2	90.3806	77.822
2014	7	10	5	18	18	0.3	4.3	0.88	96.4	90.3806	75.8411
2014	7	10	5	28	18	0.3	4.3	0.87	96.5	90.3806	74.1432
2014	7	10	5	38	18	0.3	4.3	0.87	95.2	90.4462	74.7658
2014	7	10	5	48	18	0.3	4.3	0.89	95.1	90.5118	76.8063
2014	7	10	5	58	18	0.3	4.3	0.91	96.4	90.5118	78.2234
2014	7	10	6	8	18	0.3	4.3	0.86	94.4	90.5774	74.3117
2014	7	10	6	18	18	0.3	4.3	0.9	95	90.5774	77.7153

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	6	28	18	0.3	4.3	0.9	92.7	90.6431	77.774
2014	7	10	6	38	18	0.3	4.3	0.91	95.2	90.6431	78.6256
2014	7	10	6	48	18	0.3	4.3	0.91	96	90.6431	78.0579
2014	7	10	6	58	18	0.3	4.3	0.88	94.1	90.7087	76.1284
2014	7	10	7	8	18	0.3	4.3	0.86	92.9	90.7087	74.14
2014	7	10	7	18	18	0.3	4.3	0.9	95.4	90.7087	77.5487
2014	7	10	7	28	18	0.3	4.3	0.88	98.3	90.7087	75.5603
2014	7	10	7	38	18	0.3	4.3	0.82	95.3	90.7087	70.7313
2014	7	10	7	48	18	0.3	4.3	0.85	94.9	90.7087	73.0037
2014	7	10	7	58	18	0.3	4.3	0.88	96.2	90.7087	76.1284
2014	7	10	8	8	18	0.3	4.3	0.86	95.7	90.7087	74.14
2014	7	10	8	18	18	0.3	4.3	0.91	95.6	90.7087	78.1168
2014	7	10	8	28	18	0.3	4.3	0.89	95.5	90.7087	76.9806
2014	7	10	8	38	18	0.3	4.3	0.87	95.4	90.7087	75.2762
2014	7	10	8	48	18	0.3	4.3	0.88	94.1	90.7087	75.8443
2014	7	10	8	58	18	0.3	4.3	0.89	97	90.7087	76.4124
2014	7	10	9	8	18	0.3	4.3	0.85	93.3	90.7743	73.343
2014	7	10	9	18	18	0.3	4.3	0.86	95.2	90.7087	74.424
2014	7	10	9	28	18	0.3	4.3	0.91	96.9	90.7087	77.8327
2014	7	10	9	38	18	0.3	4.3	0.86	94.8	90.7743	74.48
2014	7	10	9	48	18	0.3	4.3	0.87	93.9	90.7743	75.6171
2014	7	10	9	58	18	0.3	4.3	0.9	94.6	90.7743	77.8913
2014	7	10	10	8	18	0.3	4.3	0.85	95.5	90.7743	73.6272
2014	7	10	10	18	18	0.3	4.3	0.85	93.1	90.7743	73.9114
2014	7	10	10	28	18	0.3	4.3	0.83	97.2	90.7743	71.6372
2014	7	10	10	38	18	0.3	4.3	0.85	95.3	90.7743	73.0585
2014	7	10	10	48	18	0.3	4.3	0.84	96.5	90.7743	72.4899
2014	7	10	10	58	18	0.3	4.3	0.82	97.3	90.7087	70.7309
2014	7	10	11	8	18	0.3	4.3	0.88	95.8	90.7087	75.844
2014	7	10	11	18	18	0.3	4.3	0.87	97	90.6431	74.3675
2014	7	10	11	28	18	0.3	4.3	0.82	96	90.7087	70.4468
2014	7	10	11	38	18	0.3	4.3	0.83	97.5	90.6431	70.9613
2014	7	10	11	48	18	0.3	4.3	0.84	96.1	90.6431	72.0967
2014	7	10	11	58	18	0.3	4.3	0.88	95.1	90.6431	75.7867
2014	7	10	12	8	18	0.3	4.3	0.86	97.2	90.5774	74.0277
2014	7	10	12	18	18	0.3	4.3	0.87	96.3	90.5774	74.8785
2014	7	10	12	28	18	0.3	4.3	0.83	95.9	90.5774	71.1913
2014	7	10	12	38	18	0.3	4.3	0.87	94.7	90.5774	75.1621
2014	7	10	12	48	18	0.3	4.3	0.83	96.8	90.5774	71.1913
2014	7	10	12	58	18	0.3	4.3	0.9	98.6	90.5118	76.5224
2014	7	10	13	8	18	0.3	4.3	0.83	96.8	90.5774	70.9076
2014	7	10	13	18	18	0.3	4.3	0.86	95.5	90.5774	73.7439
2014	7	10	13	28	18	0.3	4.3	0.87	94.1	90.5774	75.162
2014	7	10	13	38	18	0.3	4.3	0.83	95.9	90.5118	71.1374
2014	7	10	13	48	18	0.3	4.3	0.87	96.2	90.5774	75.162
2014	7	10	13	58	18	0.3	4.3	0.8	94	90.5118	68.5866

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	14	8	18	0.3	4.3	0.86	95.7	90.5118	73.9715
2014	7	10	14	18	18	0.3	4.3	0.82	96.2	90.5118	70.5705
2014	7	10	14	28	18	0.3	4.3	0.79	95.3	90.5118	67.7363
2014	7	10	14	38	18	0.3	4.3	0.85	95.8	90.4462	73.0659
2014	7	10	14	48	18	0.3	4.3	0.8	93.8	90.5118	68.5865
2014	7	10	14	58	18	0.3	4.3	0.84	94.3	90.4462	72.2163
2014	7	10	15	8	18	0.3	4.3	0.85	95.1	90.4462	73.0659
2014	7	10	15	18	18	0.3	4.3	0.9	94.6	90.4462	77.0307
2014	7	10	15	28	18	0.3	4.3	0.85	94.9	90.4462	72.7826
2014	7	10	15	38	18	0.3	4.3	0.87	95.6	90.3806	74.4255
2014	7	10	15	48	18	0.3	4.3	0.81	95.6	90.3806	69.6147
2014	7	10	15	58	18	0.3	4.3	0.82	95.9	90.3806	70.7467
2014	7	10	16	8	18	0.3	4.3	0.87	95.6	90.3806	74.9915
2014	7	10	16	18	18	0.3	4.3	0.86	96.1	90.3806	73.8595
2014	7	10	16	28	18	0.3	4.3	0.84	95.4	90.3806	71.8786
2014	7	10	16	38	18	0.3	4.3	0.84	95.6	90.3806	71.8786
2014	7	10	16	48	18	0.3	4.3	0.89	94	90.315	76.3485
2014	7	10	16	58	18	0.3	4.3	0.86	95.9	90.3806	74.1424
2014	7	10	17	8	18	0.3	4.3	0.87	96.5	90.315	74.6519
2014	7	10	17	18	18	0.3	4.3	0.82	93.4	90.315	70.9758
2014	7	10	17	28	18	0.3	4.3	0.83	95	90.315	71.2586
2014	7	10	17	38	18	0.3	4.3	0.87	95	90.315	74.9346
2014	7	10	17	48	18	0.3	4.3	0.86	95.3	90.315	73.8036
2014	7	10	17	58	18	0.3	4.3	0.88	94.9	90.315	75.2174
2014	7	10	18	8	18	0.3	4.3	0.85	95.8	90.315	72.9552
2014	7	10	18	18	18	0.3	4.3	0.87	93.9	90.315	74.9347
2014	7	10	18	28	18	0.3	4.3	0.83	97.7	90.315	71.2586
2014	7	10	18	38	18	0.3	4.3	0.86	97.2	90.315	73.5208
2014	7	10	18	48	18	0.3	4.3	0.84	95.4	90.315	72.3897
2014	7	10	18	58	18	0.3	4.3	0.87	95.8	90.315	74.6519
2014	7	10	19	8	18	0.3	4.3	0.87	96.5	90.315	74.3691
2014	7	10	19	18	18	0.3	4.3	0.87	94.1	90.315	74.6519
2014	7	10	19	28	18	0.3	4.3	0.85	93.8	90.315	73.2381
2014	7	10	19	38	18	0.3	3.9	0.89	95.7	90.2494	76.0081
2014	7	10	19	48	18	0.3	4.3	0.87	94.1	90.315	75.2175
2014	7	10	19	58	18	0.3	4.3	0.87	93.7	90.315	75.2175
2014	7	10	20	8	18	0.3	4.3	0.85	95.3	90.315	72.6725
2014	7	10	20	18	18	0.3	3.9	0.86	94.4	90.2494	73.7477
2014	7	10	20	28	18	0.3	4.3	0.87	95.2	90.315	74.652
2014	7	10	20	38	18	0.3	3.9	0.84	95	90.2494	71.7698
2014	7	10	20	48	18	0.3	3.9	0.88	96	90.2494	75.7257
2014	7	10	20	58	18	0.3	4.3	0.85	95.3	90.315	73.2381
2014	7	10	21	8	18	0.3	4.3	0.83	93.9	90.315	70.976
2014	7	10	21	18	18	0.3	4.3	0.83	97.3	90.315	70.976
2014	7	10	21	28	18	0.3	4.3	0.86	94.4	90.315	73.8037
2014	7	10	21	38	18	0.3	3.9	0.82	93.9	90.2494	70.3571

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	10	21	48	18	0.3	3.9	0.83	94.3	90.2494	71.4874
2014	7	10	21	58	18	0.3	3.9	0.84	96.8	90.2494	71.4874
2014	7	10	22	8	18	0.3	4.3	0.85	95.1	90.315	72.9555
2014	7	10	22	18	18	0.3	4.3	0.84	91.1	90.315	72.6727
2014	7	10	22	28	18	0.3	4.3	0.87	96	90.315	74.9349
2014	7	10	22	38	18	0.3	4.3	0.81	93.7	90.315	69.2794
2014	7	10	22	48	18	0.3	4.3	0.85	94.4	90.315	72.6727
2014	7	10	22	58	18	0.3	4.3	0.83	94.6	90.315	70.9761
2014	7	10	23	8	18	0.3	4.3	0.89	96.5	90.315	76.6316
2014	7	10	23	18	18	0.3	4.3	0.82	94.1	90.315	70.6934
2014	7	10	23	28	18	0.3	4.3	0.87	94.3	90.315	74.935
2014	7	10	23	38	18	0.3	4.3	0.86	94.4	90.315	73.8039
2014	7	10	23	48	18	0.3	4.3	0.89	96.3	90.315	76.3489
2014	7	10	23	58	18	0.3	4.3	0.84	96	90.315	72.1073
2014	7	11	0	8	18	0.3	3.9	0.86	97.4	90.2494	73.748
2014	7	11	0	18	18	0.3	4.3	0.88	94.3	90.315	76.0662
2014	7	11	0	28	18	0.3	4.3	0.89	95.1	90.315	76.6317
2014	7	11	0	38	18	0.3	4.3	0.86	94.4	90.315	73.804
2014	7	11	0	48	18	0.3	4.3	0.89	96.3	90.315	76.349
2014	7	11	0	58	18	0.3	4.3	0.84	95.6	90.315	72.1074
2014	7	11	1	8	18	0.3	4.3	0.88	95.1	90.315	75.5007
2014	7	11	1	18	18	0.3	4.3	0.87	95.6	90.315	74.6524
2014	7	11	1	28	18	0.3	4.3	0.88	97.5	90.315	75.5007
2014	7	11	1	38	18	0.3	4.3	0.84	96.2	90.315	72.3902
2014	7	11	1	48	18	0.3	4.3	0.84	94.5	90.315	71.8247
2014	7	11	1	58	18	0.3	4.3	0.86	97.3	90.315	73.2385
2014	7	11	2	8	18	0.3	4.3	0.87	95.6	90.315	74.6524
2014	7	11	2	18	18	0.3	4.3	0.88	96.4	90.3806	75.275
2014	7	11	2	28	18	0.3	4.3	0.9	93.1	90.3806	77.8219
2014	7	11	2	38	18	0.3	4.3	0.88	96.4	90.315	75.218
2014	7	11	2	48	18	0.3	4.3	0.84	92.2	90.3806	72.7281
2014	7	11	2	58	18	0.3	4.3	0.89	98.9	90.3806	75.558
2014	7	11	3	8	18	0.3	4.3	0.84	94	90.3806	72.4452
2014	7	11	3	18	18	0.3	4.3	0.86	97.3	90.3806	73.2941
2014	7	11	3	28	18	0.3	4.3	0.87	94.6	90.3806	74.4261
2014	7	11	3	38	18	0.3	4.3	0.85	95.5	90.3806	73.0112
2014	7	11	3	48	18	0.3	4.3	0.87	95	90.3806	74.7092
2014	7	11	3	58	18	0.3	4.3	0.91	95	90.3806	77.8221
2014	7	11	4	8	18	0.3	4.3	0.87	94.8	90.3806	74.7092
2014	7	11	4	18	18	0.3	4.3	0.86	96.6	90.3806	73.2943
2014	7	11	4	28	18	0.3	4.3	0.85	94.9	90.3806	73.2943
2014	7	11	4	38	18	0.3	4.3	0.87	94.1	90.4462	75.049
2014	7	11	4	48	18	0.3	4.3	0.86	94.4	90.4462	73.633
2014	7	11	4	58	18	0.3	4.3	0.83	94.7	90.4462	71.6506
2014	7	11	5	8	18	0.3	4.3	0.83	92.7	90.5118	71.9882
2014	7	11	5	18	18	0.3	4.3	0.85	95.5	90.5774	73.1772

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	5	28	18	0.3	4.3	0.87	94.1	90.5774	75.4463
2014	7	11	5	38	18	0.3	4.3	0.9	93.3	90.6431	77.7741
2014	7	11	5	48	18	0.3	4.3	0.87	93.9	90.6431	75.5033
2014	7	11	5	58	18	0.3	4.3	0.89	95.1	90.6431	76.6387
2014	7	11	6	8	18	0.3	4.3	0.87	94.1	90.6431	75.5033
2014	7	11	6	18	18	0.3	4.3	0.87	95.2	90.6431	74.6518
2014	7	11	6	28	18	0.3	4.3	0.86	95.5	90.6431	73.8003
2014	7	11	6	38	18	0.3	4.3	0.86	95.5	90.6431	74.368
2014	7	11	6	48	18	0.3	4.3	0.88	94.5	90.7087	75.8444
2014	7	11	6	58	18	0.3	4.3	0.88	94.7	90.7087	75.8444
2014	7	11	7	8	18	0.3	4.3	0.85	95.3	90.7087	73.2879
2014	7	11	7	18	18	0.3	4.3	0.86	95.5	90.7087	73.856
2014	7	11	7	28	18	0.3	4.3	0.9	96.1	90.7087	77.2648
2014	7	11	7	38	18	0.3	4.3	0.86	95.3	90.7087	73.856
2014	7	11	7	48	18	0.3	4.3	0.86	94.8	90.7087	74.4241
2014	7	11	7	58	18	0.3	4.3	0.87	92.8	90.7087	75.5604
2014	7	11	8	8	18	0.3	4.3	0.88	94.9	90.7087	75.5604
2014	7	11	8	18	18	0.3	4.3	0.88	95.8	90.7087	76.1285
2014	7	11	8	28	18	0.3	4.3	0.84	94.3	90.7087	72.1516
2014	7	11	8	38	18	0.3	4.3	0.91	94.6	90.7087	78.1169
2014	7	11	8	48	18	0.3	4.3	0.85	96.4	90.7087	73.2878
2014	7	11	8	58	18	0.3	4.3	0.89	93.6	90.7087	77.2647
2014	7	11	9	8	18	0.3	4.3	0.86	94.4	90.7087	73.856
2014	7	11	9	18	18	0.3	4.3	0.88	94.9	90.7087	75.5603
2014	7	11	9	28	18	0.3	4.3	0.89	95.9	90.7743	76.4701
2014	7	11	9	38	18	0.3	4.3	0.86	94.2	90.7087	74.14
2014	7	11	9	48	18	0.3	4.3	0.88	94.5	90.7087	75.5603
2014	7	11	9	58	18	0.3	4.3	0.86	94.2	90.7087	73.8559
2014	7	11	10	8	18	0.3	4.3	0.87	95.2	90.7743	75.3329
2014	7	11	10	18	18	0.3	4.3	0.88	95.2	90.7743	75.6172
2014	7	11	10	28	18	0.3	4.3	0.82	95.7	90.7087	70.7311
2014	7	11	10	38	18	0.3	4.3	0.85	97.1	90.6431	72.9485
2014	7	11	10	48	18	0.3	4.3	0.83	95.4	90.6431	71.5292
2014	7	11	10	58	18	0.3	4.3	0.84	96	90.7087	72.4354
2014	7	11	11	8	18	0.3	4.3	0.84	94.1	90.6431	72.0969
2014	7	11	11	18	18	0.3	4.3	0.86	94.4	90.6431	73.7999
2014	7	11	11	28	18	0.3	4.3	0.85	95.1	90.5774	73.1769
2014	7	11	11	38	18	0.3	4.3	0.9	95	90.5774	77.1477
2014	7	11	11	48	18	0.3	4.3	0.83	94.1	90.6431	71.8129
2014	7	11	11	58	18	0.3	4.3	0.82	96.2	90.5774	70.9078
2014	7	11	12	8	18	0.3	4.3	0.81	93.5	90.5774	69.4896
2014	7	11	12	18	18	0.3	4.3	0.83	94.3	90.6431	71.2451
2014	7	11	12	28	18	0.3	4.3	0.81	94	90.5118	69.437
2014	7	11	12	38	18	0.3	4.3	0.87	96	90.5774	75.1621
2014	7	11	12	48	18	0.3	4.3	0.85	93.3	90.5774	73.7439
2014	7	11	12	58	18	0.3	4.3	0.79	95	90.5118	68.3033

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	13	8	18	0.3	4.3	0.83	94.6	90.4462	71.0836
2014	7	11	13	18	18	0.3	4.3	0.86	97.7	90.4462	73.6324
2014	7	11	13	28	18	0.3	4.3	0.88	95.4	90.5118	75.3885
2014	7	11	13	38	18	0.3	4.3	0.83	95.6	90.4462	71.6499
2014	7	11	13	48	18	0.3	4.3	0.84	95.6	90.5118	72.5543
2014	7	11	13	58	18	0.3	4.3	0.86	96.3	90.4462	74.1987
2014	7	11	14	8	18	0.3	4.3	0.84	97	90.5118	71.704
2014	7	11	14	18	18	0.3	4.3	0.84	95.6	90.4462	72.4994
2014	7	11	14	28	18	0.3	4.3	0.88	96	90.4462	75.3314
2014	7	11	14	38	18	0.3	4.3	0.81	95.6	90.4462	69.6673
2014	7	11	14	48	18	0.3	4.3	0.86	94.8	90.4462	74.1985
2014	7	11	14	58	18	0.3	4.3	0.83	96.8	90.3806	71.3125
2014	7	11	15	8	18	0.3	4.3	0.82	95.5	90.3806	70.4635
2014	7	11	15	18	18	0.3	4.3	0.82	94.6	90.3806	70.7465
2014	7	11	15	28	18	0.3	4.3	0.84	95.6	90.3806	72.4444
2014	7	11	15	38	18	0.3	4.3	0.85	96.7	90.3806	72.7274
2014	7	11	15	48	18	0.3	4.3	0.84	95.4	90.3806	71.8784
2014	7	11	15	58	18	0.3	4.3	0.89	95.1	90.3806	76.1232
2014	7	11	16	8	18	0.3	4.3	0.85	95.1	90.3806	73.0103
2014	7	11	16	18	18	0.3	4.3	0.84	96.3	90.315	72.1067
2014	7	11	16	28	18	0.3	4.3	0.83	96.8	90.315	70.9756
2014	7	11	16	38	18	0.3	4.3	0.82	94.8	90.315	70.6929
2014	7	11	16	48	18	0.3	3.9	0.83	97.7	90.2494	71.2044
2014	7	11	16	58	18	0.3	3.9	0.88	95.1	90.2494	75.4428
2014	7	11	17	8	18	0.3	3.9	0.82	96.4	90.2494	70.0742
2014	7	11	17	18	18	0.3	3.9	0.83	96.3	90.2494	71.2044
2014	7	11	17	28	18	0.3	3.9	0.86	94.4	90.2494	73.7475
2014	7	11	17	38	18	0.3	3.9	0.83	96.3	90.2494	71.2044
2014	7	11	17	48	18	0.3	3.9	0.85	96	90.2494	72.6172
2014	7	11	17	58	18	0.3	3.9	0.81	95.6	90.2494	69.5091
2014	7	11	18	8	18	0.3	3.9	0.85	96.9	90.2494	72.8998
2014	7	11	18	18	18	0.3	3.9	0.82	94.4	90.2494	70.3568
2014	7	11	18	28	18	0.3	3.9	0.85	95.3	90.2494	73.1824
2014	7	11	18	38	18	0.3	3.9	0.86	94.2	90.2494	73.7475
2014	7	11	18	48	18	0.3	3.9	0.9	96.7	90.2494	76.8556
2014	7	11	18	58	18	0.3	3.9	0.84	95.8	90.2494	72.0521
2014	7	11	19	8	18	0.3	3.9	0.83	95.2	90.2494	71.487
2014	7	11	19	18	18	0.3	3.9	0.85	93.8	90.2494	73.1824
2014	7	11	19	28	18	0.3	3.9	0.86	95.9	90.2494	74.0301
2014	7	11	19	38	18	0.3	3.9	0.88	95.2	90.2494	75.1603
2014	7	11	19	48	18	0.3	3.9	0.92	94.5	90.2494	78.8336
2014	7	11	19	58	18	0.3	3.9	0.85	96	90.2494	73.1824
2014	7	11	20	8	18	0.3	4.3	0.85	93.5	90.315	72.9551
2014	7	11	20	18	18	0.3	4.3	0.87	94.6	90.315	74.369
2014	7	11	20	28	18	0.3	3.9	0.91	95.6	90.2494	77.9859
2014	7	11	20	38	18	0.3	4.3	0.88	93.2	90.315	75.5001

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	11	20	48	18	0.3	3.9	0.88	94.9	90.2494	75.7255
2014	7	11	20	58	18	0.3	3.9	0.86	96.6	90.2494	73.7476
2014	7	11	21	8	18	0.3	4.3	0.88	96.2	90.315	75.5002
2014	7	11	21	18	18	0.3	4.3	0.86	95	90.315	74.0863
2014	7	11	21	28	18	0.3	4.3	0.85	95.3	90.315	72.6724
2014	7	11	21	38	18	0.3	4.3	0.88	93.6	90.315	75.5002
2014	7	11	21	48	18	0.3	4.3	0.86	94.6	90.315	74.0863
2014	7	11	21	58	18	0.3	4.3	0.88	94	90.315	76.0658
2014	7	11	22	8	18	0.3	4.3	0.85	95.5	90.315	72.9553
2014	7	11	22	18	18	0.3	4.3	0.85	94.9	90.315	73.2381
2014	7	11	22	28	18	0.3	4.3	0.88	94.9	90.315	75.2175
2014	7	11	22	38	18	0.3	4.3	0.87	93.2	90.315	75.2175
2014	7	11	22	48	18	0.3	4.3	0.89	95.9	90.315	76.6314
2014	7	11	22	58	18	0.3	4.3	0.89	95.9	90.315	76.6314
2014	7	11	23	8	18	0.3	4.3	0.86	95.7	90.315	73.521
2014	7	11	23	18	18	0.3	4.3	0.86	97	90.315	73.8038
2014	7	11	23	28	18	0.3	4.3	0.87	95	90.315	74.3693
2014	7	11	23	38	18	0.3	4.3	0.88	96.7	90.315	74.9349
2014	7	11	23	48	18	0.3	4.3	0.84	95.8	90.315	72.39
2014	7	11	23	58	18	0.3	4.3	0.89	96.3	90.315	76.6316
2014	7	12	0	8	18	0.3	4.3	0.87	94.6	90.315	74.3694
2014	7	12	0	18	18	0.3	4.3	0.88	96	90.315	75.7833
2014	7	12	0	28	18	0.3	4.3	0.84	96.7	90.315	72.1073
2014	7	12	0	38	18	0.3	4.3	0.87	93.3	90.315	74.6522
2014	7	12	0	48	18	0.3	4.3	0.9	97.1	90.315	76.9145
2014	7	12	0	58	18	0.3	4.3	0.84	94.5	90.315	71.8246
2014	7	12	1	8	18	0.3	4.3	0.87	95.4	90.315	74.9351
2014	7	12	1	18	18	0.3	4.3	0.87	94.1	90.315	75.2179
2014	7	12	1	28	18	0.3	4.3	0.86	93.5	90.315	74.3696
2014	7	12	1	38	18	0.3	4.3	0.91	96.4	90.315	78.0457
2014	7	12	1	48	18	0.3	4.3	0.89	95.3	90.315	76.0663
2014	7	12	1	58	18	0.3	4.3	0.87	95.2	90.315	74.9352
2014	7	12	2	8	18	0.3	4.3	0.89	96.5	90.315	76.3491
2014	7	12	2	18	18	0.3	4.3	0.89	95.3	90.315	76.0664
2014	7	12	2	28	18	0.3	4.3	0.87	95.8	90.315	74.9353
2014	7	12	2	38	18	0.3	4.3	0.88	93.4	90.315	75.7837
2014	7	12	2	48	18	0.3	4.3	0.87	95.4	90.315	74.9354
2014	7	12	2	58	18	0.3	4.3	0.84	95.2	90.315	71.8249
2014	7	12	3	8	18	0.3	4.3	0.86	94.8	90.315	74.0871
2014	7	12	3	18	18	0.3	4.3	0.88	95.2	90.315	75.2182
2014	7	12	3	28	18	0.3	4.3	0.87	97.1	90.315	74.6527
2014	7	12	3	38	18	0.3	4.3	0.88	94.5	90.315	75.2183
2014	7	12	3	48	18	0.3	4.3	0.82	96	90.315	70.4111
2014	7	12	3	58	18	0.3	4.3	0.84	94.7	90.315	71.825
2014	7	12	4	8	18	0.3	4.3	0.87	96.3	90.315	74.37
2014	7	12	4	18	18	0.3	4.3	0.86	95.9	90.315	73.5217

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	4	28	18	0.3	4.3	0.88	95.1	90.315	75.5012
2014	7	12	4	38	18	0.3	4.3	0.88	95.3	90.315	75.784
2014	7	12	4	48	18	0.3	4.3	0.88	93.2	90.315	75.5013
2014	7	12	4	58	18	0.3	4.3	0.86	95.2	90.3806	74.1436
2014	7	12	5	8	18	0.3	4.3	0.9	94	90.3806	77.5395
2014	7	12	5	18	18	0.3	4.3	0.86	93.7	90.4462	74.1997
2014	7	12	5	28	18	0.3	4.3	0.88	94.3	90.5118	75.9564
2014	7	12	5	38	18	0.3	4.3	0.87	97.2	90.5118	74.2559
2014	7	12	5	48	18	0.3	4.3	0.91	96.8	90.5118	78.2238
2014	7	12	5	58	18	0.3	4.3	0.87	95.4	90.5774	75.163
2014	7	12	6	8	18	0.3	4.3	0.85	96	90.5774	73.1776
2014	7	12	6	18	18	0.3	4.3	0.88	93.9	90.5774	75.7303
2014	7	12	6	28	18	0.3	4.3	0.87	93.9	90.5774	74.8795
2014	7	12	6	38	18	0.3	4.3	0.88	95.8	90.5774	75.4468
2014	7	12	6	48	18	0.3	4.3	0.86	94.1	90.5774	74.3122
2014	7	12	6	58	18	0.3	4.3	0.87	94.7	90.5774	75.1632
2014	7	12	7	8	18	0.3	4.3	0.88	96.9	90.6431	75.5038
2014	7	12	7	18	18	0.3	4.3	0.86	95.7	90.5774	74.0287
2014	7	12	7	28	18	0.3	4.3	0.86	97.3	90.6431	73.5169
2014	7	12	7	38	18	0.3	4.3	0.88	95.8	90.6431	75.5038
2014	7	12	7	48	18	0.3	4.3	0.86	97	90.6431	74.0846
2014	7	12	7	58	18	0.3	4.3	0.85	96.2	90.6431	72.9492
2014	7	12	8	8	18	0.3	4.3	0.85	98	90.6431	72.9492
2014	7	12	8	18	18	0.3	4.3	0.88	94.9	90.6431	75.5038
2014	7	12	8	28	18	0.3	4.3	0.89	94.9	90.6431	76.3554
2014	7	12	8	38	18	0.3	4.3	0.87	94.1	90.6431	75.5038
2014	7	12	8	48	18	0.3	4.3	0.92	94.7	90.6431	79.7615
2014	7	12	8	58	18	0.3	4.3	0.85	96.2	90.6431	73.5168
2014	7	12	9	8	18	0.3	4.3	0.85	95.3	90.6431	73.233
2014	7	12	9	18	18	0.3	4.3	0.86	94.6	90.6431	74.0845
2014	7	12	9	28	18	0.3	4.3	0.9	94	90.6431	77.4907
2014	7	12	9	38	18	0.3	4.3	0.87	96.5	90.6431	74.6522
2014	7	12	9	48	18	0.3	4.3	0.86	96.3	90.6431	74.3683
2014	7	12	9	58	18	0.3	4.3	0.87	92.8	90.6431	75.5036
2014	7	12	10	8	18	0.3	4.3	0.9	94.4	90.6431	77.7744
2014	7	12	10	18	18	0.3	4.3	0.85	95.1	90.6431	72.9489
2014	7	12	10	28	18	0.3	4.3	0.86	96.4	90.6431	73.8005
2014	7	12	10	38	18	0.3	4.3	0.88	95.6	90.6431	75.7874
2014	7	12	10	48	18	0.3	4.3	0.86	95.7	90.6431	74.3681
2014	7	12	10	58	18	0.3	4.3	0.87	96.3	90.6431	74.6519
2014	7	12	11	8	18	0.3	4.3	0.84	97.6	90.5774	72.0428
2014	7	12	11	18	18	0.3	4.3	0.87	96.3	90.6431	74.6518
2014	7	12	11	28	18	0.3	4.3	0.9	95.7	90.5774	77.1481
2014	7	12	11	38	18	0.3	4.3	0.86	96.8	90.5118	73.4054
2014	7	12	11	48	18	0.3	4.3	0.84	96.7	90.5774	72.3263
2014	7	12	11	58	18	0.3	4.3	0.9	93.4	90.5118	77.3731

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	12	8	18	0.3	4.3	0.89	95.3	90.4462	76.1818
2014	7	12	12	18	18	0.3	4.3	0.87	94.3	90.3806	74.9922
2014	7	12	12	28	18	0.3	4.3	0.89	95.9	90.4462	76.7481
2014	7	12	12	38	18	0.3	4.3	0.89	97	90.3806	76.124
2014	7	12	12	48	18	0.3	4.3	0.85	96.6	90.4462	73.0664
2014	7	12	12	58	18	0.3	4.3	0.87	97	90.3806	74.143
2014	7	12	13	8	18	0.3	4.3	0.88	95.5	90.3806	75.8409
2014	7	12	13	18	18	0.3	4.3	0.85	95.5	90.3806	73.294
2014	7	12	13	28	18	0.3	4.3	0.88	94.9	90.3806	75.2748
2014	7	12	13	38	18	0.3	4.3	0.84	96.7	90.3806	72.1619
2014	7	12	13	48	18	0.3	4.3	0.85	97.1	90.3806	72.7279
2014	7	12	13	58	18	0.3	4.3	0.84	95.4	90.3806	71.8789
2014	7	12	14	8	18	0.3	4.3	0.87	96.5	90.3806	74.1427
2014	7	12	14	18	18	0.3	4.3	0.81	95.1	90.3806	69.6149
2014	7	12	14	28	18	0.3	4.3	0.83	95.9	90.3806	71.5958
2014	7	12	14	38	18	0.3	4.3	0.84	95.6	90.3806	71.8787
2014	7	12	14	48	18	0.3	4.3	0.85	96.4	90.3806	72.7277
2014	7	12	14	58	18	0.3	4.3	0.84	94.3	90.3806	72.1617
2014	7	12	15	8	18	0.3	4.3	0.84	96.1	90.3806	71.8787
2014	7	12	15	18	18	0.3	4.3	0.82	95.3	90.3806	70.7467
2014	7	12	15	28	18	0.3	4.3	0.89	93.8	90.3806	76.9724
2014	7	12	15	38	18	0.3	4.3	0.86	95.2	90.315	74.0863
2014	7	12	15	48	18	0.3	4.3	0.83	94.8	90.315	71.2586
2014	7	12	15	58	18	0.3	4.3	0.86	95.1	90.315	73.5208
2014	7	12	16	8	18	0.3	4.3	0.86	95.5	90.315	73.8035
2014	7	12	16	18	18	0.3	4.3	0.87	95.4	90.315	74.6518
2014	7	12	16	28	18	0.3	4.3	0.87	94.8	90.315	74.6518
2014	7	12	16	38	18	0.3	4.3	0.84	95.8	90.315	72.1069
2014	7	12	16	48	18	0.3	4.3	0.82	94.6	90.315	70.693
2014	7	12	16	58	18	0.3	4.3	0.86	96.6	90.315	73.2379
2014	7	12	17	8	18	0.3	4.3	0.9	94.4	90.315	77.7623
2014	7	12	17	18	18	0.3	4.3	0.83	97.9	90.315	70.9758
2014	7	12	17	28	18	0.3	4.3	0.86	95	90.315	74.0862
2014	7	12	17	38	18	0.3	4.3	0.88	94.3	90.315	75.7829
2014	7	12	17	48	18	0.3	4.3	0.9	95.7	90.315	76.914
2014	7	12	17	58	18	0.3	4.3	0.83	95.9	90.315	71.5413
2014	7	12	18	8	18	0.3	4.3	0.82	96.9	90.315	70.4102
2014	7	12	18	18	18	0.3	4.3	0.8	97.8	90.315	68.148
2014	7	12	18	28	18	0.3	4.3	0.83	96.8	90.315	71.2585
2014	7	12	18	38	18	0.3	4.3	0.83	96.8	90.315	71.2585
2014	7	12	18	48	18	0.3	3.9	0.83	94.1	90.2494	71.4871
2014	7	12	18	58	18	0.3	3.9	0.84	92.5	90.2494	72.6173
2014	7	12	19	8	18	0.3	3.9	0.85	95.8	90.2494	72.8999
2014	7	12	19	18	18	0.3	3.9	0.89	97	90.1181	75.6106
2014	7	12	19	28	18	0.3	3.9	0.86	94.8	90.1837	73.6916
2014	7	12	19	38	18	0.3	3.9	0.87	94.3	90.1837	74.5387

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	12	19	48	18	0.3	3.9	0.86	93.9	90.1837	73.974
2014	7	12	19	58	18	0.3	4.3	0.9	95.9	90.315	76.914
2014	7	12	20	8	18	0.3	3.9	0.88	95.2	90.1837	75.1034
2014	7	12	20	18	18	0.3	3.9	0.88	96.4	90.2494	75.4429
2014	7	12	20	28	18	0.3	4.3	0.86	95.7	90.315	74.0863
2014	7	12	20	38	18	0.3	4.3	0.88	96.6	90.315	75.5001
2014	7	12	20	48	18	0.3	4.3	0.88	94.3	90.315	75.5002
2014	7	12	20	58	18	0.3	4.3	0.9	93.1	90.315	77.7623
2014	7	12	21	8	18	0.3	4.3	0.86	92.2	90.315	74.0863
2014	7	12	21	18	18	0.3	4.3	0.88	94.1	90.315	75.5002
2014	7	12	21	28	18	0.3	4.3	0.89	95.1	90.315	76.6313
2014	7	12	21	38	18	0.3	4.3	0.87	94.5	90.315	74.9347
2014	7	12	21	48	18	0.3	4.3	0.88	95.6	90.315	75.2175
2014	7	12	21	58	18	0.3	4.3	0.83	95.7	90.315	71.2587
2014	7	12	22	8	18	0.3	4.3	0.85	94.4	90.315	72.6725
2014	7	12	22	18	18	0.3	4.3	0.89	94.7	90.315	76.0658
2014	7	12	22	28	18	0.3	4.3	0.86	97.2	90.315	73.8037
2014	7	12	22	38	18	0.3	4.3	0.87	94.8	90.315	74.652
2014	7	12	22	48	18	0.3	4.3	0.83	95.4	90.315	71.2588
2014	7	12	22	58	18	0.3	4.3	0.88	96.4	90.315	75.5004
2014	7	12	23	8	18	0.3	4.3	0.89	92.5	90.315	76.6315
2014	7	12	23	18	18	0.3	4.3	0.82	93.9	90.315	70.4105
2014	7	12	23	28	18	0.3	4.3	0.84	94.5	90.315	71.8244
2014	7	12	23	38	18	0.3	4.3	0.92	95.3	90.315	79.1765
2014	7	12	23	48	18	0.3	4.3	0.87	96.5	90.315	74.3694
2014	7	12	23	58	18	0.3	4.3	0.89	95.7	90.315	76.0661
2014	7	13	0	8	18	0.3	4.3	0.87	95	90.315	74.935
2014	7	13	0	18	18	0.3	4.3	0.88	94.5	90.315	75.7833
2014	7	13	0	28	18	0.3	4.3	0.86	93.9	90.315	73.804
2014	7	13	0	38	18	0.3	4.3	0.87	95.2	90.315	74.6523
2014	7	13	0	48	18	0.3	4.3	0.88	97.9	90.315	74.9351
2014	7	13	0	58	18	0.3	4.3	0.89	94.4	90.315	76.6318
2014	7	13	1	8	18	0.3	4.3	0.87	95.2	90.315	74.9352
2014	7	13	1	18	18	0.3	4.3	0.89	94	90.315	76.3491
2014	7	13	1	28	18	0.3	4.3	0.85	93.5	90.315	72.9558
2014	7	13	1	38	18	0.3	4.3	0.9	94.8	90.315	77.1974
2014	7	13	1	48	18	0.3	4.3	0.9	94	90.315	77.763
2014	7	13	1	58	18	0.3	4.3	0.89	95.5	90.315	76.0664
2014	7	13	2	8	18	0.3	4.3	0.88	94.5	90.315	75.2181
2014	7	13	2	18	18	0.3	4.3	0.85	95.3	90.3806	73.2942
2014	7	13	2	28	18	0.3	4.3	0.86	95	90.3806	73.8602
2014	7	13	2	38	18	0.3	4.3	0.88	94.1	90.3806	75.5582
2014	7	13	2	48	18	0.3	4.3	0.87	93.7	90.3806	74.7093
2014	7	13	2	58	18	0.3	4.3	0.87	96.1	90.3806	74.4263
2014	7	13	3	8	18	0.3	4.3	0.9	95	90.3806	77.2562
2014	7	13	3	18	18	0.3	4.3	0.88	96.2	90.3806	75.8413

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	3	28	18	0.3	4.3	0.91	95.6	90.3806	77.8223
2014	7	13	3	38	18	0.3	4.3	0.88	95.3	90.3806	75.8414
2014	7	13	3	48	18	0.3	4.3	0.91	93.5	90.4462	78.7309
2014	7	13	3	58	18	0.3	4.3	0.9	96.9	90.4462	77.0317
2014	7	13	4	8	18	0.3	4.3	0.86	96.4	90.5118	73.6889
2014	7	13	4	18	18	0.3	4.3	0.84	94.7	90.5118	71.9884
2014	7	13	4	28	18	0.3	4.3	0.86	95	90.5774	74.312
2014	7	13	4	38	18	0.3	4.3	0.9	96.1	90.5774	77.432
2014	7	13	4	48	18	0.3	4.3	0.87	97.4	90.5774	74.5957
2014	7	13	4	58	18	0.3	4.3	0.89	95.1	90.5774	76.8648
2014	7	13	5	8	18	0.3	4.3	0.88	96.9	90.5774	75.163
2014	7	13	5	18	18	0.3	4.3	0.88	96.2	90.5774	75.4467
2014	7	13	5	28	18	0.3	4.3	0.88	95.8	90.6431	75.5037
2014	7	13	5	38	18	0.3	4.3	0.86	97	90.6431	73.8006
2014	7	13	5	48	18	0.3	4.3	0.92	96	90.6431	78.9099
2014	7	13	5	58	18	0.3	4.3	0.87	96.3	90.6431	74.6522
2014	7	13	6	8	18	0.3	4.3	0.85	97.3	90.6431	72.9491
2014	7	13	6	18	18	0.3	4.3	0.91	96	90.6431	78.0584
2014	7	13	6	28	18	0.3	4.3	0.88	94.5	90.6431	75.7877
2014	7	13	6	38	18	0.3	4.3	0.88	95.6	90.6431	75.7877
2014	7	13	6	48	18	0.3	4.3	0.92	93.9	90.6431	79.4778
2014	7	13	6	58	18	0.3	4.3	0.87	96.3	90.6431	74.9362
2014	7	13	7	8	18	0.3	4.3	0.88	95.6	90.6431	75.7878
2014	7	13	7	18	18	0.3	4.3	0.9	94.6	90.7087	77.5494
2014	7	13	7	28	18	0.3	4.3	0.86	95.2	90.7087	74.4247
2014	7	13	7	38	18	0.3	4.3	0.9	98	90.7087	77.2653
2014	7	13	7	48	18	0.3	4.3	0.86	94.6	90.7087	74.1406
2014	7	13	7	58	18	0.3	4.3	0.85	94.2	90.7087	73.0044
2014	7	13	8	8	18	0.3	4.3	0.84	95.1	90.7087	72.7203
2014	7	13	8	18	18	0.3	4.3	0.87	96.9	90.7087	74.7087
2014	7	13	8	28	18	0.3	4.3	0.88	96.2	90.7087	75.5609
2014	7	13	8	38	18	0.3	4.3	0.88	96.4	90.7087	76.1291
2014	7	13	8	48	18	0.3	4.3	0.88	95.8	90.7087	76.129
2014	7	13	8	58	18	0.3	4.3	0.89	95.1	90.7087	76.4131
2014	7	13	9	8	18	0.3	4.3	0.87	94.5	90.7087	74.9928
2014	7	13	9	18	18	0.3	4.3	0.86	97.5	90.7087	73.5724
2014	7	13	9	28	18	0.3	4.3	0.88	96.4	90.7087	75.5608
2014	7	13	9	38	18	0.3	4.3	0.88	95.8	90.7087	75.5608
2014	7	13	9	48	18	0.3	4.3	0.9	96.9	90.7087	77.2652
2014	7	13	9	58	18	0.3	4.3	0.88	94.5	90.7087	75.5608
2014	7	13	10	8	18	0.3	4.3	0.91	95.6	90.7087	78.4013
2014	7	13	10	18	18	0.3	4.3	0.84	94.2	90.7087	72.7201
2014	7	13	10	28	18	0.3	4.3	0.88	94.7	90.7087	75.5606
2014	7	13	10	38	18	0.3	4.3	0.88	96.4	90.7087	75.5606
2014	7	13	10	48	18	0.3	4.3	0.88	97.3	90.7087	75.2765
2014	7	13	10	58	18	0.3	4.3	0.89	96.1	90.7743	76.7546

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	11	8	18	0.3	4.3	0.88	94.7	90.7743	75.9018
2014	7	13	11	18	18	0.3	4.3	0.85	96.9	90.7087	73.288
2014	7	13	11	28	18	0.3	4.3	0.89	95.1	90.7087	76.6966
2014	7	13	11	38	18	0.3	4.3	0.87	96.3	90.7087	74.7082
2014	7	13	11	48	18	0.3	4.3	0.87	95.4	90.7087	75.2763
2014	7	13	11	58	18	0.3	4.3	0.9	96.7	90.7087	77.5487
2014	7	13	12	8	18	0.3	4.3	0.82	97.1	90.7087	70.4471
2014	7	13	12	18	18	0.3	4.3	0.89	94.7	90.7087	76.4124
2014	7	13	12	28	18	0.3	4.3	0.86	97.2	90.7087	74.1398
2014	7	13	12	38	18	0.3	4.3	0.9	96.1	90.7087	77.5485
2014	7	13	12	48	18	0.3	4.3	0.81	95.8	90.6431	69.8261
2014	7	13	12	58	18	0.3	4.3	0.87	95.2	90.6431	74.9353
2014	7	13	13	8	18	0.3	4.3	0.86	96.4	90.6431	73.7999
2014	7	13	13	18	18	0.3	4.3	0.83	96.8	90.5118	70.8543
2014	7	13	13	28	18	0.3	4.3	0.86	96.4	90.5118	73.405
2014	7	13	13	38	18	0.3	4.3	0.89	94.7	90.5118	76.2391
2014	7	13	13	48	18	0.3	4.3	0.84	95.8	90.4462	72.2166
2014	7	13	13	58	18	0.3	4.3	0.89	93.8	90.4462	76.7478
2014	7	13	14	8	18	0.3	4.3	0.85	96.2	90.4462	73.0661
2014	7	13	14	18	18	0.3	4.3	0.84	91.6	90.4462	72.4997
2014	7	13	14	28	18	0.3	4.3	0.85	96	90.4462	72.7829
2014	7	13	14	38	18	0.3	4.3	0.87	96.2	90.4462	75.0484
2014	7	13	14	48	18	0.3	4.3	0.88	95.2	90.4462	75.3316
2014	7	13	14	58	18	0.3	4.3	0.85	94.4	90.3806	73.2937
2014	7	13	15	8	18	0.3	4.3	0.88	96	90.4462	75.3315
2014	7	13	15	18	18	0.3	4.3	0.89	95.5	90.4462	76.4643
2014	7	13	15	28	18	0.3	4.3	0.85	97.1	90.3806	72.7276
2014	7	13	15	38	18	0.3	4.3	0.88	95.2	90.3806	75.2745
2014	7	13	15	48	18	0.3	4.3	0.86	96.1	90.3806	73.5765
2014	7	13	15	58	18	0.3	4.3	0.82	95	90.3806	70.4637
2014	7	13	16	8	18	0.3	4.3	0.86	96.3	90.3806	73.8595
2014	7	13	16	18	18	0.3	4.3	0.86	95.3	90.3806	73.8595
2014	7	13	16	28	18	0.3	4.3	0.85	95.1	90.3806	72.7275
2014	7	13	16	38	18	0.3	4.3	0.9	93.8	90.315	77.1968
2014	7	13	16	48	18	0.3	4.3	0.88	94.5	90.3806	75.8404
2014	7	13	16	58	18	0.3	4.3	0.89	93.4	90.315	76.3485
2014	7	13	17	8	18	0.3	4.3	0.87	94.3	90.315	74.6518
2014	7	13	17	18	18	0.3	4.3	0.9	96.9	90.315	76.6312
2014	7	13	17	28	18	0.3	4.3	0.89	94.9	90.315	76.3485
2014	7	13	17	38	18	0.3	4.3	0.86	94.4	90.315	74.0863
2014	7	13	17	48	18	0.3	4.3	0.85	90.7	90.315	72.9552
2014	7	13	17	58	18	0.3	3.9	0.84	95.4	90.2494	72.3348
2014	7	13	18	8	18	0.3	3.9	0.87	96.7	90.1837	74.2564
2014	7	13	18	18	18	0.3	4.3	0.87	95.4	90.315	74.6518
2014	7	13	18	28	18	0.3	4.3	0.86	95.9	90.315	73.8035
2014	7	13	18	38	18	0.3	4.3	0.89	96.2	90.315	76.0657

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	13	18	48	18	0.3	3.9	0.87	94.1	90.2494	75.1604
2014	7	13	18	58	18	0.3	4.3	0.84	95.2	90.315	72.1068
2014	7	13	19	8	18	0.3	4.3	0.91	95	90.315	77.7623
2014	7	13	19	18	18	0.3	4.3	0.9	95.6	90.315	77.4795
2014	7	13	19	28	18	0.3	4.3	0.9	94.8	90.3806	76.9723
2014	7	13	19	38	18	0.3	4.3	0.88	96	90.315	75.2173
2014	7	13	19	48	18	0.3	4.3	0.89	94.9	90.315	76.3484
2014	7	13	19	58	18	0.3	4.3	0.87	94.5	90.315	74.9346
2014	7	13	20	8	18	0.3	4.3	0.88	95.2	90.315	75.2173
2014	7	13	20	18	18	0.3	4.3	0.88	94.9	90.315	75.7829
2014	7	13	20	28	18	0.3	4.3	0.87	93.2	90.3806	74.9914
2014	7	13	20	38	18	0.3	4.3	0.86	94.4	90.3806	74.1424
2014	7	13	20	48	18	0.3	4.3	0.87	95.2	90.315	74.6518
2014	7	13	20	58	18	0.3	4.3	0.87	93.2	90.3806	74.9914
2014	7	13	21	8	18	0.3	4.3	0.91	94.1	90.3806	78.1042
2014	7	13	21	18	18	0.3	4.3	0.88	94.5	90.3806	75.8404
2014	7	13	21	28	18	0.3	4.3	0.85	95.3	90.3806	72.7275
2014	7	13	21	38	18	0.3	4.3	0.93	95.7	90.3806	79.5192
2014	7	13	21	48	18	0.3	4.3	0.88	96.2	90.3806	75.5574
2014	7	13	21	58	18	0.3	4.3	0.87	95	90.3806	74.4255
2014	7	13	22	8	18	0.3	4.3	0.88	93.2	90.3806	75.5575
2014	7	13	22	18	18	0.3	4.3	0.87	92.6	90.3806	75.2745
2014	7	13	22	28	18	0.3	4.3	0.91	98.1	90.3806	77.5384
2014	7	13	22	38	18	0.3	4.3	0.86	95.5	90.3806	73.8596
2014	7	13	22	48	18	0.3	4.3	0.88	96.4	90.3806	75.2745
2014	7	13	22	58	18	0.3	4.3	0.85	92.9	90.3806	73.0107
2014	7	13	23	8	18	0.3	4.3	0.88	94.9	90.3806	75.8406
2014	7	13	23	18	18	0.3	4.3	0.87	94.1	90.3806	75.2746
2014	7	13	23	28	18	0.3	4.3	0.87	96.9	90.3806	74.7086
2014	7	13	23	38	18	0.3	4.3	0.93	96.1	90.3806	79.5194
2014	7	13	23	48	18	0.3	4.3	0.88	94.5	90.3806	75.2746
2014	7	13	23	58	18	0.3	4.3	0.91	95.2	90.3806	78.3875
2014	7	14	0	8	18	0.3	4.3	0.9	95.4	90.3806	77.2556
2014	7	14	0	18	18	0.3	4.3	0.88	93.6	90.3806	76.1237
2014	7	14	0	28	18	0.3	4.3	0.88	95.6	90.4462	75.3317
2014	7	14	0	38	18	0.3	4.3	0.86	94.4	90.4462	74.1989
2014	7	14	0	48	18	0.3	4.3	0.87	96.5	90.4462	74.7654
2014	7	14	0	58	18	0.3	4.3	0.83	94.6	90.4462	71.0837
2014	7	14	1	8	18	0.3	4.3	0.86	93.3	90.4462	74.4822
2014	7	14	1	18	18	0.3	4.3	0.92	94.7	90.4462	78.7303
2014	7	14	1	28	18	0.3	4.3	0.87	94.1	90.4462	75.0487
2014	7	14	1	38	18	0.3	4.3	0.91	94.6	90.4462	77.8807
2014	7	14	1	48	18	0.3	4.3	0.89	96.5	90.4462	76.4647
2014	7	14	1	58	18	0.3	4.3	0.93	94.5	90.4462	79.8632
2014	7	14	2	8	18	0.3	4.3	0.88	93.6	90.4462	76.1815
2014	7	14	2	18	18	0.3	4.3	0.86	94.6	90.5118	73.9719

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	2	28	18	0.3	4.3	0.89	93.6	90.5118	76.5226
2014	7	14	2	38	18	0.3	4.3	0.88	93	90.5774	75.7296
2014	7	14	2	48	18	0.3	4.3	0.88	95.2	90.5774	75.446
2014	7	14	2	58	18	0.3	4.3	0.88	93.8	90.6431	76.0707
2014	7	14	3	8	18	0.3	4.3	0.87	94.1	90.7087	75.276
2014	7	14	3	18	18	0.3	4.3	0.88	94.7	90.7087	75.8441
2014	7	14	3	28	18	0.3	4.3	0.91	95.8	90.7087	78.4007
2014	7	14	3	38	18	0.3	4.3	0.85	95.5	90.7087	73.5717
2014	7	14	3	48	18	0.3	4.3	0.86	92.6	90.7087	74.4239
2014	7	14	3	58	18	0.3	4.3	0.89	94.7	90.7087	76.6964
2014	7	14	4	8	18	0.3	4.3	0.86	96.6	90.7087	73.8558
2014	7	14	4	18	18	0.3	4.3	0.88	93.2	90.7087	75.8443
2014	7	14	4	28	18	0.3	4.3	0.91	93.9	90.7743	78.7442
2014	7	14	4	38	18	0.3	4.3	0.91	97	90.7743	78.1757
2014	7	14	4	48	18	0.3	4.3	0.85	95.8	90.7743	73.343
2014	7	14	4	58	18	0.3	4.3	0.87	95	90.7743	74.7644
2014	7	14	5	8	18	0.3	4.3	0.9	93.1	90.7743	78.1758
2014	7	14	5	18	18	0.3	4.3	0.93	95.7	90.7743	80.45
2014	7	14	5	28	18	0.3	4.3	0.89	94.9	90.7743	76.4701
2014	7	14	5	38	18	0.3	4.3	0.87	97.1	90.7743	75.0488
2014	7	14	5	48	18	0.3	4.3	0.86	95.5	90.7743	74.4802
2014	7	14	5	58	18	0.3	4.3	0.87	96.3	90.7743	74.7645
2014	7	14	6	8	18	0.3	4.3	0.89	94.4	90.8399	77.0968
2014	7	14	6	18	18	0.3	4.3	0.88	94.3	90.8399	75.9588
2014	7	14	6	28	18	0.3	4.3	0.86	95	90.8399	74.2519
2014	7	14	6	38	18	0.3	4.3	0.9	95.2	90.8399	77.6658
2014	7	14	6	48	18	0.3	4.3	0.9	94.8	90.8399	77.6658
2014	7	14	6	58	18	0.3	4.3	0.86	95	90.8399	74.2519
2014	7	14	7	8	18	0.3	4.3	0.87	97	90.8399	74.5364
2014	7	14	7	18	18	0.3	4.3	0.88	94.7	90.8399	75.9588
2014	7	14	7	28	18	0.3	4.3	0.9	95.4	90.8399	77.9503
2014	7	14	7	38	18	0.3	4.3	0.89	95.5	90.8399	77.0968
2014	7	14	7	48	18	0.3	4.3	0.89	94.9	90.8399	77.0968
2014	7	14	7	58	18	0.3	4.3	0.89	96.3	90.8399	76.8123
2014	7	14	8	8	18	0.3	4.3	0.88	94.7	90.9055	76.3007
2014	7	14	8	18	18	0.3	4.3	0.88	93.4	90.9055	76.3007
2014	7	14	8	28	18	0.3	4.3	0.86	96.6	90.8399	73.9674
2014	7	14	8	38	18	0.3	4.3	0.88	95.6	90.9055	75.7313
2014	7	14	8	48	18	0.3	4.3	0.83	97.3	90.9055	71.176
2014	7	14	8	58	18	0.3	4.3	0.88	94.9	90.9055	75.7313
2014	7	14	9	8	18	0.3	4.3	0.9	97.7	90.9055	77.7242
2014	7	14	9	18	18	0.3	4.3	0.88	95.8	90.9055	76.3007
2014	7	14	9	28	18	0.3	4.3	0.9	96.1	90.9055	77.4394
2014	7	14	9	38	18	0.3	4.3	0.89	98.3	90.9055	76.3006
2014	7	14	9	48	18	0.3	4.3	0.86	95.7	90.9055	74.3077
2014	7	14	9	58	18	0.3	4.3	0.89	96.5	90.9055	77.1547

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	10	8	18	0.3	4.3	0.88	96.6	90.9055	75.7312
2014	7	14	10	18	18	0.3	4.3	0.89	95.7	90.9055	76.5853
2014	7	14	10	28	18	0.3	4.3	0.86	95.7	90.9055	74.3076
2014	7	14	10	38	18	0.3	4.3	0.85	95.6	90.9711	73.2239
2014	7	14	10	48	18	0.3	4.3	0.86	96.4	90.9711	74.0786
2014	7	14	10	58	18	0.3	4.3	0.89	95.7	90.9711	76.6428
2014	7	14	11	8	18	0.3	4.3	0.86	96.6	90.9711	73.7936
2014	7	14	11	18	18	0.3	4.3	0.85	96.7	90.9711	73.2238
2014	7	14	11	28	18	0.3	4.3	0.84	96	90.9711	72.654
2014	7	14	11	38	18	0.3	4.3	0.86	97.4	90.9711	74.3634
2014	7	14	11	48	18	0.3	4.3	0.89	93	90.9711	77.2126
2014	7	14	11	58	18	0.3	4.3	0.87	96.5	90.9055	74.5921
2014	7	14	12	8	18	0.3	4.3	0.84	95.4	90.9711	72.3688
2014	7	14	12	18	18	0.3	4.3	0.84	98.1	90.9055	72.3144
2014	7	14	12	28	18	0.3	4.3	0.8	98	90.9711	68.9498
2014	7	14	12	38	18	0.3	4.3	0.83	96.8	90.9711	71.514
2014	7	14	12	48	18	0.3	4.3	0.84	94.9	90.9711	72.6536
2014	7	14	12	58	18	0.3	4.3	0.87	94.1	90.9711	74.933
2014	7	14	13	8	18	0.3	4.3	0.86	93.7	90.9711	74.3631
2014	7	14	13	18	18	0.3	4.3	0.86	95.5	90.9711	74.0781
2014	7	14	13	28	18	0.3	4.3	0.87	95.2	90.9711	75.2178
2014	7	14	13	38	18	0.3	4.3	0.83	95.9	90.9711	71.5139
2014	7	14	13	48	18	0.3	4.3	0.84	96.7	90.9711	72.3686
2014	7	14	13	58	18	0.3	4.3	0.84	97.8	90.9055	72.5989
2014	7	14	14	8	18	0.3	4.3	0.87	94.6	90.9711	74.9328
2014	7	14	14	27	0	0.3	4.3	0.85	96.5	90.9055	72.8835
2014	7	14	14	37	0	0.3	4.3	0.82	96.9	90.9055	70.8906
2014	7	14	14	47	0	0.3	4.3	0.84	95.4	90.9055	72.8835
2014	7	14	14	57	0	0.3	4.3	0.86	96.6	90.9055	74.307
2014	7	14	15	7	0	0.3	4.3	0.86	94.8	90.9055	74.5917
2014	7	14	15	17	0	0.3	4.3	0.84	93.8	90.9055	72.3141
2014	7	14	15	27	0	0.3	4.3	0.85	96.4	90.9055	73.1681
2014	7	14	15	37	0	0.3	4.3	0.81	96.3	90.9055	70.0364
2014	7	14	15	47	0	0.3	4.3	0.8	95.4	90.9055	69.1822
2014	7	14	15	57	0	0.3	4.3	0.85	95.3	90.9055	73.168
2014	7	14	16	7	0	0.3	4.3	0.82	95.7	90.9055	71.1751
2014	7	14	16	17	0	0.3	4.3	0.88	97.5	90.9055	75.4456
2014	7	14	16	27	0	0.3	4.3	0.85	94.7	90.9055	73.168
2014	7	14	16	37	0	0.3	4.3	0.85	96	90.9055	73.168
2014	7	14	16	47	0	0.3	4.3	0.85	94.9	90.9055	73.7374
2014	7	14	16	57	0	0.3	4.3	0.85	96.7	90.9055	73.168
2014	7	14	17	7	0	0.3	4.3	0.86	93.3	90.9055	74.5915
2014	7	14	17	17	0	0.3	4.3	0.83	95.5	90.9055	71.4598
2014	7	14	17	27	0	0.3	4.3	0.89	96.2	90.9055	76.5844
2014	7	14	17	37	0	0.3	4.3	0.84	95.4	90.9055	72.8833
2014	7	14	17	47	0	0.3	4.3	0.88	95.6	90.9055	75.7303

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	14	17	57	0	0.3	4.3	0.87	94.8	90.9055	75.1609
2014	7	14	18	7	0	0.3	4.3	0.89	95.9	90.9055	76.8691
2014	7	14	18	17	0	0.3	4.3	0.85	93.5	90.8399	73.3974
2014	7	14	18	27	0	0.3	4.3	0.87	97	90.9055	74.5915
2014	7	14	18	37	0	0.3	4.3	0.89	95.7	90.9055	76.5844
2014	7	14	18	47	0	0.3	4.3	0.82	95	90.8399	70.837
2014	7	14	18	57	0	0.3	4.3	0.85	94.4	90.8399	73.6819
2014	7	14	19	7	0	0.3	4.3	0.87	94.1	90.7743	75.6163
2014	7	14	19	17	0	0.3	4.3	0.86	93.9	90.7743	74.7635
2014	7	14	19	27	0	0.3	4.3	0.9	95.5	90.7743	77.3219
2014	7	14	19	37	0	0.3	4.3	0.89	93.2	90.8399	77.0957
2014	7	14	19	47	0	0.3	4.3	0.88	95.1	90.8399	75.9578
2014	7	14	19	57	0	0.3	4.3	0.86	96.6	90.9055	74.3068
2014	7	14	20	7	0	0.3	4.3	0.85	96.5	90.9055	72.8833
2014	7	14	20	17	0	0.3	4.3	0.89	94.6	90.8399	77.0957
2014	7	14	20	27	0	0.3	4.3	0.86	97.7	90.8399	73.9664
2014	7	14	20	37	0	0.3	4.3	0.9	94.6	90.8399	77.3802
2014	7	14	20	47	0	0.3	4.3	0.81	95.8	90.8399	69.9836
2014	7	14	20	57	0	0.3	4.3	0.85	94.9	90.8399	73.6819
2014	7	14	21	7	0	0.3	4.3	0.89	95.1	90.8399	76.5268
2014	7	14	21	17	0	0.3	4.3	0.86	94.2	90.8399	73.9664
2014	7	14	21	27	0	0.3	4.3	0.88	94	90.9055	76.5844
2014	7	14	21	37	0	0.3	4.3	0.86	96.1	90.9055	74.3068
2014	7	14	21	47	0	0.3	4.3	0.87	94.3	90.8399	75.1044
2014	7	14	21	57	0	0.3	4.3	0.82	94.1	90.9055	71.1751
2014	7	14	22	7	0	0.3	4.3	0.85	96	90.9055	73.7374
2014	7	14	22	17	0	0.3	4.3	0.87	96.5	90.9055	74.5916
2014	7	14	22	27	0	0.3	4.3	0.86	95.5	90.9055	74.3069
2014	7	14	22	37	0	0.3	4.3	0.84	96.5	90.9055	72.314
2014	7	14	22	47	0	0.3	4.3	0.86	94.8	90.9055	74.3069
2014	7	14	22	57	0	0.3	4.3	0.86	95.5	90.9055	74.5916
2014	7	14	23	7	0	0.3	4.3	0.89	93	90.9055	77.1539
2014	7	14	23	17	0	0.3	4.3	0.86	94	90.9711	74.0779
2014	7	14	23	27	0	0.3	4.3	0.86	95.5	90.9711	74.0779
2014	7	14	23	37	0	0.3	4.3	0.84	94.2	90.9711	72.9383
2014	7	14	23	47	0	0.3	4.3	0.86	96.6	90.9711	74.3629
2014	7	14	23	57	0	0.3	4.3	0.84	93.4	90.9711	72.9383
2014	7	15	0	7	0	0.3	4.3	0.88	96	90.9711	75.7874
2014	7	15	0	17	0	0.3	4.3	0.84	95.1	90.9711	72.9383
2014	7	15	0	27	0	0.3	4.3	0.89	95.1	90.9711	76.9271
2014	7	15	0	37	0	0.3	4.3	0.84	93.4	90.9711	72.6534
2014	7	15	0	47	0	0.3	4.3	0.86	95.3	90.9711	74.3629
2014	7	15	0	57	0	0.3	4.3	0.85	94.7	90.9711	73.5082
2014	7	15	1	7	0	0.3	4.3	0.86	96.1	90.9711	74.078
2014	7	15	1	17	0	0.3	4.3	0.87	95.4	91.0368	75.2742
2014	7	15	1	27	0	0.3	4.3	0.85	93.5	91.0368	73.5635

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	1	37	0	0.3	4.3	0.89	95.7	91.0368	77.2702
2014	7	15	1	47	0	0.3	4.3	0.85	98.3	91.0368	72.7081
2014	7	15	1	57	0	0.3	4.3	0.87	93.9	91.0368	75.8445
2014	7	15	2	7	0	0.3	4.3	0.86	97.5	91.0368	73.8486
2014	7	15	2	17	0	0.3	4.3	0.86	95.3	91.0368	74.4189
2014	7	15	2	27	0	0.3	4.3	0.9	94.6	91.0368	77.5554
2014	7	15	2	37	0	0.3	4.3	0.85	95.3	91.0368	73.8487
2014	7	15	2	47	0	0.3	4.3	0.85	94.2	91.0368	73.2784
2014	7	15	2	57	0	0.3	4.3	0.88	94.3	91.0368	76.7
2014	7	15	3	7	0	0.3	4.3	0.84	96.2	91.0368	72.9933
2014	7	15	3	17	0	0.3	4.3	0.86	94.6	91.0368	74.419
2014	7	15	3	27	0	0.3	4.3	0.87	96.5	91.0368	74.9892
2014	7	15	3	37	0	0.3	4.3	0.86	95.3	91.0368	74.419
2014	7	15	3	47	0	0.3	4.3	0.86	96.4	91.0368	73.8487
2014	7	15	3	57	0	0.3	4.3	0.92	94.9	91.0368	79.2662
2014	7	15	4	7	0	0.3	4.3	0.87	95.8	91.0368	75.2744
2014	7	15	4	17	0	0.3	4.3	0.87	95	91.1024	75.6163
2014	7	15	4	27	0	0.3	4.3	0.85	97.5	91.0368	73.2785
2014	7	15	4	37	0	0.3	4.3	0.86	95.2	91.0368	74.7042
2014	7	15	4	47	0	0.3	4.3	0.87	94.1	91.0368	75.2745
2014	7	15	4	57	0	0.3	4.3	0.89	94.7	91.0368	76.9852
2014	7	15	5	7	0	0.3	4.3	0.84	96.5	91.0368	72.7083
2014	7	15	5	17	0	0.3	4.3	0.87	93.2	91.1024	75.6164
2014	7	15	5	27	0	0.3	4.3	0.83	94.1	91.1024	72.1922
2014	7	15	5	37	0	0.3	4.3	0.84	94.7	91.1024	72.7629
2014	7	15	5	47	0	0.3	4.3	0.85	94.2	91.1024	73.9043
2014	7	15	5	57	0	0.3	4.3	0.83	94.5	91.1024	71.9069
2014	7	15	6	7	0	0.3	4.3	0.87	95.6	91.1024	75.0457
2014	7	15	6	17	0	0.3	4.3	0.86	94.2	91.1024	74.475
2014	7	15	6	27	0	0.3	4.3	0.84	95.1	91.1024	73.0483
2014	7	15	6	37	0	0.3	4.3	0.88	95.3	91.1024	76.1871
2014	7	15	6	47	0	0.3	4.3	0.92	95.3	91.1024	79.3259
2014	7	15	6	57	0	0.3	4.3	0.86	97.2	91.1024	74.1897
2014	7	15	7	7	0	0.3	4.3	0.86	97.4	91.1024	74.475
2014	7	15	7	17	0	0.3	4.3	0.86	95.3	91.1024	74.475
2014	7	15	7	27	0	0.3	4.3	0.85	97.3	91.1024	73.0483
2014	7	15	7	37	0	0.3	4.3	0.82	93.4	91.168	71.3898
2014	7	15	7	47	0	0.3	4.3	0.88	94.9	91.168	76.5299
2014	7	15	7	57	0	0.3	4.3	0.88	94.9	91.168	76.5299
2014	7	15	8	7	0	0.3	4.3	0.86	92.8	91.168	75.1021
2014	7	15	8	17	0	0.3	4.3	0.86	94	91.168	74.2454
2014	7	15	8	27	0	0.3	4.3	0.88	93	91.168	76.2443
2014	7	15	8	37	0	0.3	4.3	0.88	92.8	91.168	76.5299
2014	7	15	8	47	0	0.3	4.3	0.9	92.1	91.168	78.5288
2014	7	15	8	57	0	0.3	4.3	0.86	93.3	91.2336	74.5869
2014	7	15	9	7	0	0.3	4.3	0.89	94	91.2336	77.1588

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	9	17	0	0.3	4.3	0.87	95.2	91.2336	75.7299
2014	7	15	9	27	0	0.3	4.3	0.87	94.5	91.2336	75.7299
2014	7	15	9	37	0	0.3	4.3	0.86	95.2	91.2336	74.8726
2014	7	15	9	47	0	0.3	4.3	0.89	93	91.2992	77.2166
2014	7	15	9	57	0	0.3	4.3	0.88	94.5	91.2992	76.6446
2014	7	15	10	7	0	0.3	4.3	0.88	96.4	91.2992	76.0726
2014	7	15	10	17	0	0.3	4.3	0.87	94.7	91.3648	75.8434
2014	7	15	10	27	0	0.3	4.3	0.88	95.1	91.2992	76.3586
2014	7	15	10	37	0	0.3	4.3	0.84	94.7	91.3648	72.9814
2014	7	15	10	47	0	0.3	4.3	0.89	95.1	91.3648	77.5606
2014	7	15	10	57	0	0.3	4.3	0.86	95.9	91.4305	75.0409
2014	7	15	11	7	0	0.3	4.3	0.85	95.1	91.4305	73.8952
2014	7	15	11	17	0	0.3	4.3	0.85	94.2	91.3648	74.1261
2014	7	15	11	27	0	0.3	4.3	0.87	96.1	91.3648	75.2709
2014	7	15	11	37	0	0.3	4.3	0.88	94.5	91.3648	76.1295
2014	7	15	11	47	0	0.3	4.3	0.84	95.8	91.3648	73.2674
2014	7	15	11	57	0	0.3	4.3	0.86	95.5	91.3648	74.6984
2014	7	15	12	7	0	0.3	4.3	0.86	96.6	91.3648	74.4121
2014	7	15	12	17	0	0.3	4.3	0.82	99	91.3648	70.6915
2014	7	15	12	27	0	0.3	4.3	0.86	95.7	91.3648	74.6984
2014	7	15	12	37	0	0.3	4.3	0.86	94.8	91.3648	74.9845
2014	7	15	12	47	0	0.3	4.3	0.88	94.9	91.3648	76.1293
2014	7	15	12	57	0	0.3	4.3	0.87	96.7	91.3648	74.9844
2014	7	15	13	7	0	0.3	4.3	0.88	94.9	91.3648	76.4154
2014	7	15	13	17	0	0.3	4.3	0.85	96	91.3648	73.5534
2014	7	15	13	27	0	0.3	4.3	0.85	95.5	91.2992	74.0702
2014	7	15	13	37	0	0.3	4.3	0.88	96.4	91.3648	76.1291
2014	7	15	13	47	0	0.3	4.3	0.89	97.2	91.3648	76.7014
2014	7	15	13	57	0	0.3	4.3	0.87	94.1	91.3648	75.5566
2014	7	15	14	7	0	0.3	4.3	0.86	92.4	91.3648	74.9842
2014	7	15	14	17	0	0.3	4.3	0.87	97.8	91.3648	74.9842
2014	7	15	14	27	0	0.3	4.3	0.86	95.5	91.2992	74.3561
2014	7	15	14	37	0	0.3	4.3	0.81	95.1	91.3648	70.6912
2014	7	15	14	47	0	0.3	4.3	0.88	96.7	91.2992	75.7859
2014	7	15	14	57	0	0.3	4.3	0.87	96.7	91.2992	75.2139
2014	7	15	15	7	0	0.3	4.3	0.87	94.5	91.2992	75.4999
2014	7	15	15	17	0	0.3	4.3	0.83	96.1	91.2992	72.3541
2014	7	15	15	27	0	0.3	4.3	0.83	95.2	91.2992	72.068
2014	7	15	15	37	0	0.3	4.3	0.86	96.6	91.2992	74.0699
2014	7	15	15	47	0	0.3	4.3	0.85	95.5	91.2992	73.7839
2014	7	15	15	57	0	0.3	4.3	0.84	94.9	91.2992	73.2119
2014	7	15	16	7	0	0.3	4.3	0.83	93.8	91.2992	72.354
2014	7	15	16	17	0	0.3	4.3	0.83	94.6	91.2992	71.782
2014	7	15	16	27	0	0.3	4.3	0.85	95.3	91.2992	74.0699
2014	7	15	16	37	0	0.3	4.3	0.85	94.9	91.2992	74.0699
2014	7	15	16	47	0	0.3	4.3	0.85	95.7	91.2336	74.0144

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	15	16	57	0	0.3	4.3	0.86	95.5	91.2336	74.5859
2014	7	15	17	7	0	0.3	4.3	0.85	97.1	91.2336	73.1571
2014	7	15	17	17	0	0.3	4.3	0.83	94.5	91.2336	72.014
2014	7	15	17	27	0	0.3	4.3	0.86	94.6	91.2336	74.8717
2014	7	15	17	37	0	0.3	4.3	0.85	96	91.2336	74.0144
2014	7	15	17	47	0	0.3	4.3	0.81	98.4	91.2336	69.7278
2014	7	15	17	57	0	0.3	4.3	0.84	94.5	91.2336	72.8713
2014	7	15	18	7	0	0.3	4.3	0.87	93.9	91.2336	75.4432
2014	7	15	18	17	0	0.3	4.3	0.85	96.2	91.2336	73.7286
2014	7	15	18	27	0	0.3	4.3	0.89	97.2	91.2336	76.5863
2014	7	15	18	37	0	0.3	4.3	0.85	95.3	91.2336	74.0144
2014	7	15	18	47	0	0.3	4.3	0.85	96.9	91.2336	73.4428
2014	7	15	18	57	0	0.3	4.3	0.87	95.4	91.2336	75.1575
2014	7	15	19	7	0	0.3	4.3	0.83	96.1	91.2336	71.7283
2014	7	15	19	17	0	0.3	4.3	0.87	93.7	91.2336	75.4433
2014	7	15	19	27	0	0.3	4.3	0.86	94.8	91.2336	74.586
2014	7	15	19	37	0	0.3	4.3	0.88	95.8	91.2336	76.0148
2014	7	15	19	47	0	0.3	4.3	0.85	96.7	91.2336	73.4429
2014	7	15	19	57	0	0.3	4.3	0.87	96	91.2336	75.7291
2014	7	15	20	7	0	0.3	4.3	0.89	95.3	91.2336	76.8721
2014	7	15	20	17	0	0.3	4.3	0.9	96.3	91.2336	77.7295
2014	7	15	20	27	0	0.3	4.3	0.85	93.3	91.2336	73.7287
2014	7	15	20	37	0	0.3	4.3	0.85	95.6	91.2336	73.4429
2014	7	15	20	47	0	0.3	4.3	0.86	95.5	91.2336	74.586
2014	7	15	20	57	0	0.3	4.3	0.87	94.5	91.2336	75.4433
2014	7	15	21	7	0	0.3	4.3	0.87	94.1	91.2336	75.1576
2014	7	15	21	17	0	0.3	4.3	0.86	93	91.2336	75.1576
2014	7	15	21	27	0	0.3	4.3	0.86	95.5	91.2336	74.5861
2014	7	15	21	37	0	0.3	4.3	0.87	91.1	91.2336	75.7292
2014	7	15	21	47	0	0.3	4.3	0.88	94.7	91.2336	76.0149
2014	7	15	21	57	0	0.3	4.3	0.9	94	91.2336	78.0154
2014	7	15	22	7	0	0.3	4.3	0.85	94.4	91.2336	73.443
2014	7	15	22	17	0	0.3	4.3	0.86	94.6	91.2336	74.8719
2014	7	15	22	27	0	0.3	4.3	0.89	92.9	91.2336	77.7296
2014	7	15	22	37	0	0.3	4.3	0.85	94.2	91.2336	73.7288
2014	7	15	22	47	0	0.3	4.3	0.88	94.9	91.2336	76.3008
2014	7	15	22	57	0	0.3	4.3	0.88	96	91.2336	76.3008
2014	7	15	23	7	0	0.3	4.3	0.89	93.8	91.2336	77.7297
2014	7	15	23	17	0	0.3	4.3	0.87	94.1	91.2336	76.0151
2014	7	15	23	27	0	0.3	4.3	0.88	95.8	91.2336	76.3009
2014	7	15	23	37	0	0.3	4.3	0.89	95.1	91.2336	76.8724
2014	7	15	23	47	0	0.3	4.3	0.87	94.8	91.2336	75.1578
2014	7	15	23	57	0	0.3	4.3	0.88	94.9	91.2336	76.3009
2014	7	16	0	7	0	0.3	4.3	0.88	96.4	91.2336	76.5867
2014	7	16	0	17	0	0.3	4.3	0.9	94.2	91.2336	78.0156
2014	7	16	0	27	0	0.3	4.3	0.89	95.5	91.2336	77.1583

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	0	37	0	0.3	4.3	0.87	94.5	91.2336	75.7294
2014	7	16	0	47	0	0.3	4.3	0.85	94.4	91.2336	73.4433
2014	7	16	0	57	0	0.3	4.3	0.9	92.9	91.2336	78.3014
2014	7	16	1	7	0	0.3	4.3	0.89	95.3	91.2336	77.4441
2014	7	16	1	17	0	0.3	4.3	0.87	94.8	91.2992	75.5003
2014	7	16	1	27	0	0.3	4.3	0.88	93.9	91.2992	76.3583
2014	7	16	1	37	0	0.3	4.3	0.87	96.1	91.2992	75.2143
2014	7	16	1	47	0	0.3	4.3	0.9	94.4	91.2336	77.7299
2014	7	16	1	57	0	0.3	4.3	0.92	96	91.2992	79.5042
2014	7	16	2	7	0	0.3	4.3	0.85	93.3	91.2992	74.0704
2014	7	16	2	17	0	0.3	4.3	0.91	95	91.2992	78.9322
2014	7	16	2	27	0	0.3	4.3	0.86	97.9	91.2992	74.6424
2014	7	16	2	37	0	0.3	4.3	0.9	93.8	91.2992	78.0743
2014	7	16	2	47	0	0.3	4.3	0.84	96.9	91.2992	72.9266
2014	7	16	2	57	0	0.3	4.3	0.9	95.3	91.2992	77.7884
2014	7	16	3	7	0	0.3	4.3	0.87	96.5	91.2992	75.7865
2014	7	16	3	17	0	0.3	4.3	0.88	96.8	91.3648	76.4157
2014	7	16	3	27	0	0.3	4.3	0.87	93.5	91.4305	75.9001
2014	7	16	3	37	0	0.3	4.3	0.9	96.1	91.4305	78.1914
2014	7	16	3	47	0	0.3	4.3	0.9	94.6	91.4961	78.5366
2014	7	16	3	57	0	0.3	4.3	0.91	94.3	91.5617	79.7427
2014	7	16	4	7	0	0.3	4.3	0.87	94.8	91.5617	75.7269
2014	7	16	4	17	0	0.3	4.3	0.91	93.1	91.5617	79.7428
2014	7	16	4	27	0	0.3	4.3	0.86	95.9	91.5617	74.5796
2014	7	16	4	37	0	0.3	4.3	0.87	95.2	91.5617	76.0138
2014	7	16	4	47	0	0.3	4.3	0.87	95.2	91.5617	76.0139
2014	7	16	4	57	0	0.3	4.3	0.89	95.3	91.5617	77.7349
2014	7	16	5	7	0	0.3	4.3	0.9	95	91.6273	78.0801
2014	7	16	5	17	0	0.3	4.3	0.87	95.2	91.5617	75.4402
2014	7	16	5	27	0	0.3	4.3	0.9	93.3	91.5617	78.8824
2014	7	16	5	37	0	0.3	4.3	0.88	93.2	91.6273	77.219
2014	7	16	5	47	0	0.3	4.3	0.88	95.2	91.6273	76.3578
2014	7	16	5	57	0	0.3	4.3	0.89	94.9	91.6273	77.7931
2014	7	16	6	7	0	0.3	4.3	0.89	95.9	91.6273	77.7931
2014	7	16	6	17	0	0.3	4.3	0.88	94.9	91.6273	76.932
2014	7	16	6	27	0	0.3	4.3	0.83	93.4	91.6273	72.6261
2014	7	16	6	37	0	0.3	4.3	0.88	94.3	91.6273	77.2191
2014	7	16	6	47	0	0.3	4.3	0.87	95.2	91.6273	76.0708
2014	7	16	6	57	0	0.3	4.3	0.85	92.9	91.6273	74.0614
2014	7	16	7	7	0	0.3	4.3	0.88	94.9	91.6273	76.3579
2014	7	16	7	17	0	0.3	4.3	0.87	95	91.6273	75.4967
2014	7	16	7	27	0	0.3	4.3	0.89	95.5	91.6273	77.5062
2014	7	16	7	37	0	0.3	4.3	0.86	94.4	91.6929	75.2659
2014	7	16	7	47	0	0.3	4.3	0.84	95.4	91.6929	73.2549
2014	7	16	7	57	0	0.3	4.3	0.86	94.2	91.6929	74.6913
2014	7	16	8	7	0	0.3	4.3	0.91	94.5	91.6929	79.575

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	8	17	0	0.3	4.3	0.87	95	91.6929	75.8404
2014	7	16	8	27	0	0.3	4.3	0.91	93.9	91.6929	79.8622
2014	7	16	8	37	0	0.3	4.3	0.89	93.8	91.6929	77.8513
2014	7	16	8	47	0	0.3	4.3	0.91	94.6	91.6929	79.0004
2014	7	16	8	57	0	0.3	4.3	0.9	95.2	91.6929	78.7131
2014	7	16	9	7	0	0.3	4.3	0.89	95.1	91.6929	77.564
2014	7	16	9	17	0	0.3	4.3	0.87	94.7	91.6929	76.1276
2014	7	16	9	27	0	0.3	4.3	0.86	94.6	91.6929	74.9785
2014	7	16	9	37	0	0.3	4.3	0.92	94.3	91.6929	80.7239
2014	7	16	9	47	0	0.3	4.3	0.89	94.7	91.6929	77.5639
2014	7	16	9	57	0	0.3	4.3	0.88	96	91.6929	76.4148
2014	7	16	10	7	0	0.3	4.3	0.89	93.8	91.6929	77.5638
2014	7	16	10	17	0	0.3	4.3	0.9	95	91.6929	78.4256
2014	7	16	10	27	0	0.3	4.3	0.88	94.1	91.6929	76.9892
2014	7	16	10	37	0	0.3	4.3	0.88	94.5	91.6929	76.9892
2014	7	16	10	47	0	0.3	4.3	0.87	95.4	91.6929	75.8401
2014	7	16	10	57	0	0.3	4.3	0.86	95.5	91.6929	75.2655
2014	7	16	11	7	0	0.3	4.3	0.88	94.1	91.6929	76.7018
2014	7	16	11	17	0	0.3	4.3	0.88	93.6	91.6929	76.7018
2014	7	16	11	27	0	0.3	4.3	0.88	94.1	91.6929	76.989
2014	7	16	11	37	0	0.3	4.3	0.88	94.7	91.6929	76.4144
2014	7	16	11	47	0	0.3	4.3	0.86	96.1	91.6929	74.6908
2014	7	16	11	57	0	0.3	4.3	0.85	96	91.6929	73.8289
2014	7	16	12	7	0	0.3	4.3	0.89	94.2	91.6929	77.8507
2014	7	16	12	17	0	0.3	4.3	0.86	95.1	91.6929	74.6906
2014	7	16	12	27	0	0.3	4.3	0.85	95.3	91.6929	73.8288
2014	7	16	12	37	0	0.3	4.3	0.85	96.7	91.6929	73.8287
2014	7	16	12	47	0	0.3	4.3	0.88	95.2	91.6929	76.4141
2014	7	16	12	57	0	0.3	4.3	0.83	95.7	91.6273	72.0512
2014	7	16	13	7	0	0.3	4.3	0.83	98	91.6273	71.7641
2014	7	16	13	17	0	0.3	4.3	0.87	97.2	91.5617	75.4395
2014	7	16	13	27	0	0.3	4.3	0.87	95.2	91.5617	75.7263
2014	7	16	13	37	0	0.3	4.3	0.87	96.1	91.4961	75.3831
2014	7	16	13	47	0	0.3	4.3	0.87	95.6	91.4961	75.9563
2014	7	16	13	57	0	0.3	4.3	0.87	96.5	91.4961	75.9563
2014	7	16	14	7	0	0.3	4.3	0.85	97.3	91.4961	73.6632
2014	7	16	14	17	0	0.3	4.3	0.87	95.2	91.4961	75.9562
2014	7	16	14	27	0	0.3	4.3	0.85	94.2	91.4305	74.1809
2014	7	16	14	37	0	0.3	4.3	0.84	97	91.4305	72.7488
2014	7	16	14	47	0	0.3	4.3	0.85	93.5	91.4305	74.1809
2014	7	16	14	57	0	0.3	4.3	0.88	95.8	91.3648	76.7011
2014	7	16	15	7	0	0.3	4.3	0.83	96.1	91.3648	71.8358
2014	7	16	15	17	0	0.3	4.3	0.85	97.1	91.3648	73.8392
2014	7	16	15	27	0	0.3	4.3	0.84	94.7	91.3648	72.9806
2014	7	16	15	37	0	0.3	4.3	0.86	95.5	91.3648	74.9839
2014	7	16	15	47	0	0.3	4.3	0.84	96.9	91.3648	72.9805

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	15	57	0	0.3	4.3	0.83	95	91.3648	71.8357
2014	7	16	16	7	0	0.3	4.3	0.85	94.9	91.3648	73.8391
2014	7	16	16	17	0	0.3	4.3	0.88	98.2	91.2992	75.7857
2014	7	16	16	27	0	0.3	4.3	0.89	95.3	91.2992	77.2156
2014	7	16	16	37	0	0.3	4.3	0.89	95.5	91.2992	76.9296
2014	7	16	16	47	0	0.3	4.3	0.87	95	91.2992	75.7857
2014	7	16	16	57	0	0.3	4.3	0.81	96.7	91.3648	70.4047
2014	7	16	17	7	0	0.3	4.3	0.87	94.3	91.3648	75.5563
2014	7	16	17	17	0	0.3	4.3	0.86	96.6	91.2992	74.3558
2014	7	16	17	27	0	0.3	4.3	0.85	93.3	91.2992	73.7838
2014	7	16	17	37	0	0.3	4.3	0.88	95.4	91.2992	76.0717
2014	7	16	17	47	0	0.3	4.3	0.89	95.7	91.2992	77.5016
2014	7	16	17	57	0	0.3	4.3	0.86	96.6	91.3648	74.1253
2014	7	16	18	7	0	0.3	4.3	0.9	95.2	91.3648	78.4183
2014	7	16	18	17	0	0.3	4.3	0.87	95.2	91.3648	75.2701
2014	7	16	18	27	0	0.3	4.3	0.89	93.4	91.3648	77.2735
2014	7	16	18	37	0	0.3	4.3	0.88	92.8	91.2992	76.3577
2014	7	16	18	47	0	0.3	4.3	0.89	94.2	91.2992	77.2157
2014	7	16	18	57	0	0.3	4.3	0.87	91.7	91.2992	75.7857
2014	7	16	19	7	0	0.3	4.3	0.88	94.3	91.2992	76.6437
2014	7	16	19	17	0	0.3	4.3	0.85	93.3	91.2992	73.7839
2014	7	16	19	27	0	0.3	4.3	0.9	92.1	91.3648	78.4183
2014	7	16	19	37	0	0.3	4.3	0.89	94.2	91.3648	77.5597
2014	7	16	19	47	0	0.3	4.3	0.88	96.2	91.3648	76.7011
2014	7	16	19	57	0	0.3	4.3	0.89	94.4	91.3648	77.2735
2014	7	16	20	7	0	0.3	4.3	0.88	94.7	91.3648	76.1288
2014	7	16	20	17	0	0.3	4.3	0.87	94.1	91.3648	75.2702
2014	7	16	20	27	0	0.3	4.3	0.87	95.4	91.3648	75.2702
2014	7	16	20	37	0	0.3	4.3	0.89	95.9	91.3648	77.2736
2014	7	16	20	47	0	0.3	4.3	0.87	94.8	91.3648	75.2702
2014	7	16	20	57	0	0.3	4.3	0.88	92.3	91.3648	76.9874
2014	7	16	21	7	0	0.3	4.3	0.93	95.5	91.3648	80.4218
2014	7	16	21	17	0	0.3	4.3	0.85	95.1	91.3648	73.8392
2014	7	16	21	27	0	0.3	4.3	0.85	96	91.3648	73.8392
2014	7	16	21	37	0	0.3	4.3	0.88	94.3	91.3648	76.7012
2014	7	16	21	47	0	0.3	4.3	0.92	94.9	91.3648	80.1356
2014	7	16	21	57	0	0.3	4.3	0.89	96.1	91.3648	77.5598
2014	7	16	22	7	0	0.3	4.3	0.86	94.6	91.3648	74.9841
2014	7	16	22	17	0	0.3	4.3	0.88	92.6	91.3648	76.7013
2014	7	16	22	27	0	0.3	4.3	0.87	95.6	91.3648	75.8427
2014	7	16	22	37	0	0.3	4.3	0.91	94.1	91.4305	79.6229
2014	7	16	22	47	0	0.3	4.3	0.89	95.3	91.3648	76.9875
2014	7	16	22	57	0	0.3	4.3	0.89	95.7	91.4305	77.618
2014	7	16	23	7	0	0.3	4.3	0.92	93.5	91.4305	80.4822
2014	7	16	23	17	0	0.3	4.3	0.9	94.4	91.4305	78.1909
2014	7	16	23	27	0	0.3	4.3	0.88	93	91.4305	77.0452

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	16	23	37	0	0.3	4.3	0.91	96	91.4961	79.1093
2014	7	16	23	47	0	0.3	4.3	0.91	93.3	91.4305	79.3366
2014	7	16	23	57	0	0.3	4.3	0.85	94.9	91.4961	74.2367
2014	7	17	0	7	0	0.3	4.3	0.9	94.4	91.4961	77.9629
2014	7	17	0	17	0	0.3	4.3	0.89	94.7	91.5617	77.1606
2014	7	17	0	27	0	0.3	4.3	0.87	92.6	91.6273	76.3571
2014	7	17	0	37	0	0.3	4.3	0.81	92.8	91.5617	70.8501
2014	7	17	0	47	0	0.3	4.3	0.89	95.3	91.6273	77.7924
2014	7	17	0	57	0	0.3	4.3	0.88	95.8	91.6273	76.6443
2014	7	17	1	7	0	0.3	4.3	0.89	96.2	91.6273	77.2184
2014	7	17	1	17	0	0.3	4.3	0.92	94.5	91.6929	80.1488
2014	7	17	1	27	0	0.3	4.3	0.88	95.2	91.6929	76.4143
2014	7	17	1	37	0	0.3	4.3	0.87	95.6	91.6929	75.5525
2014	7	17	1	47	0	0.3	4.3	0.89	95.3	91.6929	77.2761
2014	7	17	1	57	0	0.3	4.3	0.88	94.7	91.6929	76.7016
2014	7	17	2	7	0	0.3	4.3	0.85	93.5	91.6929	74.6907
2014	7	17	2	17	0	0.3	4.3	0.89	93.2	91.6929	77.8507
2014	7	17	2	27	0	0.3	4.3	0.87	94.3	91.7585	75.8964
2014	7	17	2	37	0	0.3	4.3	0.86	95	91.7585	75.3215
2014	7	17	2	47	0	0.3	4.3	0.87	97.2	91.6929	75.5526
2014	7	17	2	57	0	0.3	4.3	0.88	95.2	91.6929	76.4145
2014	7	17	3	7	0	0.3	4.3	0.91	94.3	91.7585	79.9213
2014	7	17	3	17	0	0.3	4.3	0.89	95.3	91.7585	77.334
2014	7	17	3	27	0	0.3	4.3	0.88	94.9	91.7585	76.4715
2014	7	17	3	37	0	0.3	4.3	0.89	93	91.7585	77.909
2014	7	17	3	47	0	0.3	4.3	0.87	93	91.7585	75.8966
2014	7	17	3	57	0	0.3	4.3	0.85	95.6	91.7585	73.8842
2014	7	17	4	7	0	0.3	4.3	0.83	92.7	91.7585	73.0218
2014	7	17	4	17	0	0.3	4.3	0.92	94.5	91.7585	80.209
2014	7	17	4	27	0	0.3	4.3	0.86	94.1	91.7585	75.3217
2014	7	17	4	37	0	0.3	4.3	0.89	93.4	91.7585	77.9091
2014	7	17	4	47	0	0.3	4.3	0.9	94.6	91.7585	78.1966
2014	7	17	4	57	0	0.3	4.3	0.9	94.8	91.7585	78.4842
2014	7	17	5	7	0	0.3	4.3	0.89	93.2	91.8242	78.255
2014	7	17	5	17	0	0.3	4.3	0.87	96.5	91.8242	76.2411
2014	7	17	5	27	0	0.3	4.3	0.89	93.6	91.7585	77.6218
2014	7	17	5	37	0	0.3	4.3	0.89	93.8	91.8242	77.9674
2014	7	17	5	47	0	0.3	4.3	0.86	92.6	91.8242	75.3781
2014	7	17	5	57	0	0.3	4.3	0.88	95.3	91.8242	76.8166
2014	7	17	6	7	0	0.3	4.3	0.87	96.3	91.8242	75.9535
2014	7	17	6	17	0	0.3	4.3	0.9	95.8	91.8242	78.8305
2014	7	17	6	27	0	0.3	4.3	0.87	91.9	91.8242	76.2412
2014	7	17	6	37	0	0.3	4.3	0.89	94.2	91.8242	77.6798
2014	7	17	6	47	0	0.3	4.3	0.89	94.7	91.8242	77.3921
2014	7	17	6	57	0	0.3	4.3	0.87	95.2	91.8242	75.9536
2014	7	17	7	7	0	0.3	4.3	0.86	93.7	91.8242	75.3782

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	7	17	0	0.3	4.3	0.93	93.4	91.8242	81.1323
2014	7	17	7	27	0	0.3	4.3	0.86	95.3	91.8242	74.8028
2014	7	17	7	37	0	0.3	4.3	0.9	93.6	91.8242	78.8306
2014	7	17	7	47	0	0.3	4.3	0.88	94.9	91.8242	76.529
2014	7	17	7	57	0	0.3	4.3	0.89	97	91.8242	77.1044
2014	7	17	8	7	0	0.3	4.3	0.92	91.8	91.8242	80.2692
2014	7	17	8	17	0	0.3	4.3	0.86	92.2	91.8242	75.3782
2014	7	17	8	27	0	0.3	4.3	0.9	93.8	91.8242	78.5429
2014	7	17	8	37	0	0.3	4.3	0.85	95.5	91.8242	74.5151
2014	7	17	8	47	0	0.3	4.3	0.85	96.9	91.8242	74.2274
2014	7	17	8	57	0	0.3	4.3	0.83	93.4	91.8242	73.0765
2014	7	17	9	7	0	0.3	4.3	0.84	97	91.8242	73.0765
2014	7	17	9	17	0	0.3	4.3	0.86	94.4	91.8242	74.8027
2014	7	17	9	27	0	0.3	4.3	0.9	94.8	91.8242	78.5428
2014	7	17	9	37	0	0.3	4.3	0.87	94.1	91.8898	76.0101
2014	7	17	9	47	0	0.3	4.3	0.88	94.9	91.8242	77.1043
2014	7	17	9	57	0	0.3	4.3	0.9	95	91.8242	78.2551
2014	7	17	10	7	0	0.3	4.3	0.86	94.6	91.8898	75.1462
2014	7	17	10	17	0	0.3	4.3	0.88	94.3	91.8898	77.4496
2014	7	17	10	27	0	0.3	4.3	0.91	94.1	91.8242	79.6935
2014	7	17	10	37	0	0.3	4.3	0.86	92.4	91.8242	75.0902
2014	7	17	10	47	0	0.3	4.3	0.88	96	91.8242	77.1041
2014	7	17	10	57	0	0.3	4.3	0.89	95.1	91.8898	77.4494
2014	7	17	11	7	0	0.3	4.3	0.87	95.6	91.8898	75.7219
2014	7	17	11	17	0	0.3	4.3	0.88	96.6	91.8898	76.5856
2014	7	17	11	27	0	0.3	4.3	0.89	94.6	91.8898	78.0252
2014	7	17	11	37	0	0.3	4.3	0.89	96.2	91.8898	77.4493
2014	7	17	11	47	0	0.3	4.3	0.87	95.2	91.8898	76.2976
2014	7	17	11	57	0	0.3	4.3	0.85	96.7	91.8898	73.7063
2014	7	17	12	7	0	0.3	4.3	0.86	95.9	91.8898	75.1458
2014	7	17	12	17	0	0.3	4.3	0.84	94.9	91.8898	73.7062
2014	7	17	12	27	0	0.3	4.3	0.89	97	91.8898	77.1612
2014	7	17	12	37	0	0.3	4.3	0.88	95.3	91.8898	76.8732
2014	7	17	12	47	0	0.3	4.3	0.84	95.6	91.8898	73.1303
2014	7	17	12	57	0	0.3	4.3	0.82	97.8	91.8898	71.1148
2014	7	17	13	7	0	0.3	4.3	0.83	95.7	91.8898	72.2665
2014	7	17	13	17	0	0.3	4.3	0.84	94.5	91.8898	73.4181
2014	7	17	13	27	0	0.3	4.3	0.83	94.3	91.8898	72.2664
2014	7	17	13	37	0	0.3	4.3	0.86	96.6	91.8242	74.5141
2014	7	17	13	47	0	0.3	4.3	0.83	97.5	91.8242	72.5002
2014	7	17	13	57	0	0.3	4.3	0.82	95.3	91.8242	71.9248
2014	7	17	14	7	0	0.3	4.3	0.82	96.4	91.8242	71.3494
2014	7	17	14	17	0	0.3	4.3	0.85	95.5	91.8242	74.2263
2014	7	17	14	27	0	0.3	4.3	0.84	96.5	91.8242	73.0755
2014	7	17	14	37	0	0.3	4.3	0.81	96	91.8242	71.0616
2014	7	17	14	47	0	0.3	4.3	0.86	95.3	91.8242	75.0893

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	14	57	0	0.3	4.3	0.84	93.8	91.8242	73.6508
2014	7	17	15	7	0	0.3	4.3	0.81	95.8	91.7585	71.0086
2014	7	17	15	17	0	0.3	4.3	0.87	96.3	91.7585	75.6083
2014	7	17	15	27	0	0.3	4.3	0.82	97.1	91.7585	71.5835
2014	7	17	15	37	0	0.3	4.3	0.86	96.1	91.6273	75.2085
2014	7	17	15	47	0	0.3	4.3	0.87	94.1	91.6929	76.4137
2014	7	17	15	57	0	0.3	4.3	0.81	94.6	91.5617	70.8497
2014	7	17	16	7	0	0.3	4.3	0.84	94.5	91.6273	73.4861
2014	7	17	16	17	0	0.3	4.3	0.8	94.5	91.6929	69.8065
2014	7	17	16	27	0	0.3	4.3	0.87	96.5	91.6273	75.2085
2014	7	17	16	37	0	0.3	4.3	0.89	94.9	91.6273	77.2178
2014	7	17	16	47	0	0.3	4.3	0.84	96.3	91.6929	72.9665
2014	7	17	16	57	0	0.3	4.3	0.84	94.1	91.6273	72.912
2014	7	17	17	7	0	0.3	4.3	0.85	97.1	91.5617	74.005
2014	7	17	17	17	0	0.3	4.3	0.81	94.9	91.6273	70.9026
2014	7	17	17	27	0	0.3	4.3	0.84	96.7	91.5617	73.1444
2014	7	17	17	37	0	0.3	4.3	0.85	94.4	91.5617	74.005
2014	7	17	17	47	0	0.3	4.3	0.83	97.1	91.5617	71.7103
2014	7	17	17	57	0	0.3	4.3	0.85	93.5	91.5617	74.5787
2014	7	17	18	7	0	0.3	4.3	0.81	96.5	91.4961	70.2236
2014	7	17	18	17	0	0.3	4.3	0.83	95.9	91.4961	72.23
2014	7	17	18	27	0	0.3	4.3	0.88	95.4	91.4961	76.2427
2014	7	17	18	37	0	0.3	4.3	0.89	95.1	91.4961	77.6759
2014	7	17	18	47	0	0.3	4.3	0.84	96.5	91.4305	72.4624
2014	7	17	18	57	0	0.3	4.3	0.88	93.9	91.4305	76.4722
2014	7	17	19	7	0	0.3	4.3	0.86	95.5	91.4305	74.7537
2014	7	17	19	17	0	0.3	4.3	0.88	96.9	91.4305	76.1858
2014	7	17	19	27	0	0.3	4.3	0.84	94.7	91.4305	72.7488
2014	7	17	19	37	0	0.3	4.3	0.89	94.2	91.4961	77.3893
2014	7	17	19	47	0	0.3	4.3	0.85	94.2	91.4961	73.9498
2014	7	17	19	57	0	0.3	4.3	0.86	95.1	91.4305	74.4673
2014	7	17	20	7	0	0.3	4.3	0.85	94.4	91.4961	73.9498
2014	7	17	20	17	0	0.3	4.3	0.89	94.9	91.4961	77.3893
2014	7	17	20	27	0	0.3	4.3	0.86	94.2	91.4305	74.7538
2014	7	17	20	37	0	0.3	4.3	0.87	94.1	91.4961	76.2428
2014	7	17	20	47	0	0.3	4.3	0.86	92.6	91.4961	74.8097
2014	7	17	20	57	0	0.3	4.3	0.9	93.6	91.4305	78.1907
2014	7	17	21	7	0	0.3	4.3	0.85	95.1	91.4961	73.9499
2014	7	17	21	17	0	0.3	4.3	0.87	96.5	91.4961	75.383
2014	7	17	21	27	0	0.3	4.3	0.85	95.3	91.4961	73.9499
2014	7	17	21	37	0	0.3	4.3	0.88	96	91.6273	76.644
2014	7	17	21	47	0	0.3	4.3	0.85	93.1	91.6273	74.3475
2014	7	17	21	57	0	0.3	4.3	0.9	92.9	91.4961	78.2493
2014	7	17	22	7	0	0.3	4.3	0.85	94.4	91.4961	73.9499
2014	7	17	22	17	0	0.3	4.3	0.88	94.3	91.6929	76.7013
2014	7	17	22	27	0	0.3	4.3	0.89	94.7	91.6929	77.2758

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	17	22	37	0	0.3	4.3	0.89	96.2	91.6929	77.2758
2014	7	17	22	47	0	0.3	4.3	0.89	93.6	91.6929	77.8504
2014	7	17	22	57	0	0.3	4.3	0.86	94.4	91.6929	74.6904
2014	7	17	23	7	0	0.3	4.3	0.9	94.8	91.6929	78.1377
2014	7	17	23	17	0	0.3	4.3	0.89	95.3	91.6929	77.2759
2014	7	17	23	27	0	0.3	4.3	0.88	94.7	91.6929	76.7014
2014	7	17	23	37	0	0.3	4.3	0.88	95.8	91.6929	76.4141
2014	7	17	23	47	0	0.3	4.3	0.91	95	91.7585	79.6335
2014	7	17	23	57	0	0.3	4.3	0.9	94.8	91.6929	78.4251
2014	7	18	0	7	0	0.3	4.3	0.88	94.5	91.6929	76.9887
2014	7	18	0	17	0	0.3	4.3	0.89	96.3	91.6929	77.5633
2014	7	18	0	27	0	0.3	4.3	0.86	93.5	91.7585	75.6088
2014	7	18	0	37	0	0.3	4.3	0.88	96.2	91.7585	76.4712
2014	7	18	0	47	0	0.3	4.3	0.84	93.1	91.7585	73.5964
2014	7	18	0	57	0	0.3	4.3	0.91	95	91.7585	79.6336
2014	7	18	1	7	0	0.3	4.3	0.87	94.1	91.7585	75.8963
2014	7	18	1	17	0	0.3	4.3	0.88	96.2	91.7585	76.4713
2014	7	18	1	27	0	0.3	4.3	0.89	95.7	91.7585	77.3338
2014	7	18	1	37	0	0.3	4.3	0.92	95.3	91.7585	79.9212
2014	7	18	1	47	0	0.3	4.3	0.9	96.2	91.7585	78.7713
2014	7	18	1	57	0	0.3	4.3	0.94	94.8	91.7585	81.9336
2014	7	18	2	7	0	0.3	4.3	0.89	95.7	91.8242	77.3915
2014	7	18	2	17	0	0.3	4.3	0.9	94.6	91.7585	78.7713
2014	7	18	2	27	0	0.3	4.3	0.94	94.6	91.8242	82.2825
2014	7	18	2	37	0	0.3	4.3	0.9	95.9	91.7585	78.4839
2014	7	18	2	47	0	0.3	4.3	0.9	96.1	91.8242	78.5424
2014	7	18	2	57	0	0.3	4.3	0.9	92.7	91.8242	79.1178
2014	7	18	3	7	0	0.3	4.3	0.89	93.2	91.8242	77.967
2014	7	18	3	17	0	0.3	4.3	0.88	96.2	91.8242	76.8163
2014	7	18	3	27	0	0.3	4.3	0.92	93.1	91.8242	80.5564
2014	7	18	3	37	0	0.3	4.3	0.9	97.9	91.8242	78.5425
2014	7	18	3	47	0	0.3	4.3	0.84	95.6	91.8242	73.6516
2014	7	18	3	57	0	0.3	4.3	0.88	95.3	91.8242	76.8164
2014	7	18	4	7	0	0.3	4.3	0.88	96	91.8242	76.5287
2014	7	18	4	17	0	0.3	4.3	0.92	95.8	91.8242	79.9811
2014	7	18	4	27	0	0.3	4.3	0.94	94.8	91.8242	81.7074
2014	7	18	4	37	0	0.3	4.3	0.86	95.3	91.8242	75.0902
2014	7	18	4	47	0	0.3	4.3	0.88	93.8	91.8242	77.1042
2014	7	18	4	57	0	0.3	4.3	0.86	94	91.8242	74.8026
2014	7	18	5	7	0	0.3	4.3	0.89	94	91.8242	78.255
2014	7	18	5	17	0	0.3	4.3	0.87	95.4	91.8242	75.9534
2014	7	18	5	27	0	0.3	4.3	0.9	94	91.8242	79.1182
2014	7	18	5	37	0	0.3	4.3	0.88	94.9	91.8242	76.5289
2014	7	18	5	47	0	0.3	4.3	0.91	95.6	91.8242	79.1182
2014	7	18	5	57	0	0.3	4.3	0.89	95.9	91.8898	77.7376
2014	7	18	6	7	0	0.3	4.3	0.91	95.6	91.8898	79.1772

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	6	17	0	0.3	4.3	0.86	94.4	91.8898	75.4343
2014	7	18	6	27	0	0.3	4.3	0.9	95.2	91.8898	78.8894
2014	7	18	6	37	0	0.3	4.3	0.86	93.5	91.8898	75.1465
2014	7	18	6	47	0	0.3	4.3	0.88	93.8	91.8898	77.1619
2014	7	18	6	57	0	0.3	4.3	0.86	96.1	91.9554	75.2024
2014	7	18	7	7	0	0.3	4.3	0.89	94	91.9554	78.3719
2014	7	18	7	17	0	0.3	4.3	0.94	94.4	91.9554	82.1176
2014	7	18	7	27	0	0.3	4.3	0.9	96	91.9554	78.9482
2014	7	18	7	37	0	0.3	4.3	0.89	95.7	91.9554	77.7956
2014	7	18	7	47	0	0.3	4.3	0.89	94.9	91.9554	77.5075
2014	7	18	7	57	0	0.3	4.3	0.89	93	91.9554	78.0838
2014	7	18	8	7	0	0.3	4.3	0.88	94.3	91.9554	76.9313
2014	7	18	8	17	0	0.3	4.3	0.85	96.2	91.9554	74.6262
2014	7	18	8	27	0	0.3	4.3	0.91	96.9	91.9554	78.9482
2014	7	18	8	37	0	0.3	4.3	0.87	94.6	91.9554	75.7787
2014	7	18	8	47	0	0.3	4.3	0.86	94.8	91.9554	74.9143
2014	7	18	8	57	0	0.3	4.3	0.9	93.8	91.9554	78.9481
2014	7	18	9	7	0	0.3	4.3	0.87	94.8	92.021	76.1234
2014	7	18	9	17	0	0.3	4.3	0.88	94.3	92.021	77.5651
2014	7	18	9	27	0	0.3	4.3	0.88	93.4	92.021	77.5651
2014	7	18	9	37	0	0.3	4.3	0.92	95.9	92.021	80.7368
2014	7	18	9	47	0	0.3	4.3	0.89	94.4	92.021	77.8534
2014	7	18	9	57	0	0.3	4.3	0.89	95.3	92.021	77.8533
2014	7	18	10	7	0	0.3	4.3	0.91	93.5	92.021	79.8717
2014	7	18	10	17	0	0.3	4.3	0.87	95.4	92.021	76.4116
2014	7	18	10	27	0	0.3	4.3	0.87	97.2	92.021	75.8348
2014	7	18	10	37	0	0.3	4.3	0.9	95.4	92.021	78.7182
2014	7	18	10	47	0	0.3	4.3	0.91	96.8	92.021	79.5832
2014	7	18	10	57	0	0.3	4.3	0.88	96.7	91.9554	76.3546
2014	7	18	11	7	0	0.3	4.3	0.84	95	92.021	73.2396
2014	7	18	11	17	0	0.3	4.3	0.85	96.7	92.021	74.1046
2014	7	18	11	27	0	0.3	4.3	0.88	97.1	92.021	76.4113
2014	7	18	11	37	0	0.3	4.3	0.86	98.5	92.021	74.9695
2014	7	18	11	47	0	0.3	4.3	0.89	95.5	92.021	77.8529
2014	7	18	11	57	0	0.3	4.3	0.85	94.9	92.021	74.1044
2014	7	18	12	7	0	0.3	4.3	0.89	95.7	92.021	78.1412
2014	7	18	12	17	0	0.3	4.3	0.78	95.5	91.9554	68.5748
2014	7	18	12	27	0	0.3	4.3	0.83	92.9	91.9554	72.8967
2014	7	18	12	37	0	0.3	4.3	0.87	95	92.021	76.411
2014	7	18	12	47	0	0.3	4.3	0.87	95.4	92.021	76.1226
2014	7	18	12	57	0	0.3	4.3	0.86	96.6	91.9554	74.6254
2014	7	18	13	7	0	0.3	4.3	0.86	95.7	91.9554	74.9135
2014	7	18	13	17	0	0.3	4.3	0.87	96.5	91.9554	75.4897
2014	7	18	13	27	0	0.3	4.3	0.82	95.3	91.9554	72.0321
2014	7	18	13	37	0	0.3	4.3	0.86	95.5	91.9554	75.2015
2014	7	18	13	47	0	0.3	4.3	0.88	96.2	91.9554	76.9302

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	13	57	0	0.3	4.3	0.85	94.4	91.9554	74.0489
2014	7	18	14	7	0	0.3	4.3	0.81	94.2	91.9554	70.5913
2014	7	18	14	17	0	0.3	4.3	0.84	94.2	91.9554	73.7607
2014	7	18	14	27	0	0.3	4.3	0.85	94.9	91.9554	74.6251
2014	7	18	14	37	0	0.3	4.3	0.85	96.2	91.9554	74.3369
2014	7	18	14	47	0	0.3	4.3	0.87	94.5	91.9554	76.0657
2014	7	18	14	57	0	0.3	4.3	0.9	95.6	91.9554	78.6588
2014	7	18	15	7	0	0.3	4.3	0.86	96.6	91.9554	74.9131
2014	7	18	15	17	0	0.3	4.3	0.86	95.7	91.8898	74.8574
2014	7	18	15	27	0	0.3	4.3	0.86	93	91.8898	75.7211
2014	7	18	15	37	0	0.3	4.3	0.86	95.1	91.8898	74.8574
2014	7	18	15	47	0	0.3	4.3	0.82	95.1	91.8898	71.4024
2014	7	18	15	57	0	0.3	4.3	0.85	94.4	91.8898	74.2815
2014	7	18	16	7	0	0.3	4.3	0.86	94.4	91.8898	74.8574
2014	7	18	16	17	0	0.3	4.3	0.89	96.4	91.8898	77.4486
2014	7	18	16	27	0	0.3	4.3	0.87	95.2	91.8242	75.9524
2014	7	18	16	37	0	0.3	4.3	0.88	95.2	91.8242	76.5278
2014	7	18	16	47	0	0.3	4.3	0.82	93.4	91.8242	71.637
2014	7	18	16	57	0	0.3	4.3	0.83	94.5	91.8242	72.5001
2014	7	18	17	7	0	0.3	4.3	0.85	95.8	91.8242	73.9386
2014	7	18	17	17	0	0.3	4.3	0.87	95.9	91.8242	75.6647
2014	7	18	17	27	0	0.3	4.3	0.85	95.5	91.8242	74.2262
2014	7	18	17	37	0	0.3	4.3	0.83	95.4	91.8242	72.7878
2014	7	18	17	47	0	0.3	4.3	0.89	94.4	91.7585	77.6208
2014	7	18	17	57	0	0.3	4.3	0.84	94.3	91.7585	73.021
2014	7	18	18	7	0	0.3	4.3	0.85	95.1	91.7585	74.171
2014	7	18	18	17	0	0.3	4.3	0.85	95.3	91.6929	74.1157
2014	7	18	18	27	0	0.3	4.3	0.87	96	91.6273	76.0698
2014	7	18	18	37	0	0.3	4.3	0.88	97.9	91.6273	76.3569
2014	7	18	18	47	0	0.3	4.3	0.85	96.7	91.6929	73.5412
2014	7	18	18	57	0	0.3	4.3	0.89	95.1	91.7585	77.3333
2014	7	18	19	7	0	0.3	4.3	0.87	95.4	91.7585	75.6084
2014	7	18	19	17	0	0.3	4.3	0.82	95.8	91.7585	71.2962
2014	7	18	19	27	0	0.3	4.3	0.87	95.2	91.6273	75.7828
2014	7	18	19	37	0	0.3	4.3	0.89	96.8	91.6929	76.9885
2014	7	18	19	47	0	0.3	4.3	0.89	94.2	91.5617	77.4473
2014	7	18	19	57	0	0.3	4.3	0.85	94.9	91.6929	74.1158
2014	7	18	20	7	0	0.3	4.3	0.9	95	91.6929	78.1376
2014	7	18	20	17	0	0.3	4.3	0.85	95.1	91.6929	73.8285
2014	7	18	20	27	0	0.3	4.3	0.83	95.7	91.6929	72.3922
2014	7	18	20	37	0	0.3	4.3	0.85	95.8	91.6929	73.8285
2014	7	18	20	47	0	0.3	4.3	0.81	97.7	91.6929	70.3813
2014	7	18	20	57	0	0.3	4.3	0.81	94.7	91.6929	70.3813
2014	7	18	21	7	0	0.3	4.3	0.86	95.9	91.6929	74.9777
2014	7	18	21	17	0	0.3	4.3	0.9	95.4	91.6929	78.4249
2014	7	18	21	27	0	0.3	4.3	0.86	94.6	91.7585	74.7461

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	18	21	37	0	0.3	4.3	0.85	94.7	91.7585	74.1712
2014	7	18	21	47	0	0.3	4.3	0.84	96.8	91.7585	72.7338
2014	7	18	21	57	0	0.3	4.3	0.83	95.5	91.7585	72.1588
2014	7	18	22	7	0	0.3	4.3	0.85	95.3	91.7585	73.8837
2014	7	18	22	17	0	0.3	4.3	0.83	97.7	91.7585	72.1588
2014	7	18	22	27	0	0.3	4.3	0.88	94.7	91.8242	76.5281
2014	7	18	22	37	0	0.3	4.3	0.86	96.1	91.7585	74.7462
2014	7	18	22	47	0	0.3	4.3	0.83	94.8	91.7585	72.4464
2014	7	18	22	57	0	0.3	4.3	0.88	94.7	91.8242	76.8159
2014	7	18	23	7	0	0.3	4.3	0.87	96.5	91.8242	75.3774
2014	7	18	23	17	0	0.3	4.3	0.85	95.6	91.8242	73.9389
2014	7	18	23	27	0	0.3	4.3	0.9	94.4	91.8242	78.5421
2014	7	18	23	37	0	0.3	4.3	0.84	94.5	91.8242	73.6513
2014	7	18	23	47	0	0.3	4.3	0.86	96.3	91.8242	75.0898
2014	7	18	23	57	0	0.3	4.3	0.89	95.9	91.8242	77.6791
2014	7	19	0	7	0	0.3	4.3	0.91	94.1	91.8242	79.9807
2014	7	19	0	17	0	0.3	4.3	0.9	95.9	91.8242	78.5423
2014	7	19	0	27	0	0.3	4.3	0.89	96.3	91.8242	77.9669
2014	7	19	0	37	0	0.3	4.3	0.86	95	91.8242	75.3776
2014	7	19	0	47	0	0.3	4.3	0.85	94.9	91.8242	74.5145
2014	7	19	0	57	0	0.3	4.3	0.85	96.4	91.8242	73.9391
2014	7	19	1	7	0	0.3	4.3	0.88	94.3	91.8242	76.5285
2014	7	19	1	17	0	0.3	4.3	0.85	92.9	91.8242	74.2269
2014	7	19	1	27	0	0.3	4.3	0.83	93.2	91.8242	73.0761
2014	7	19	1	37	0	0.3	4.3	0.92	94.7	91.8242	79.9809
2014	7	19	1	47	0	0.3	4.3	0.88	95.4	91.8242	76.5285
2014	7	19	1	57	0	0.3	4.3	0.95	97.7	91.8242	82.858
2014	7	19	2	7	0	0.3	4.3	0.9	94.6	91.8242	78.8302
2014	7	19	2	17	0	0.3	4.3	0.86	95.2	91.8242	75.3778
2014	7	19	2	27	0	0.3	4.3	0.85	94	91.8242	74.227
2014	7	19	2	37	0	0.3	4.3	0.87	95	91.8242	76.2409
2014	7	19	2	47	0	0.3	4.3	0.88	94.9	91.8242	76.5286
2014	7	19	2	57	0	0.3	4.3	0.89	93.6	91.8242	77.9672
2014	7	19	3	7	0	0.3	4.3	0.87	93.7	91.8242	75.9533
2014	7	19	3	17	0	0.3	4.3	0.9	94.6	91.8242	78.8303
2014	7	19	3	27	0	0.3	4.3	0.89	94	91.8242	77.6796
2014	7	19	3	37	0	0.3	4.3	0.93	94.1	91.8898	81.1925
2014	7	19	3	47	0	0.3	4.3	0.89	93.8	91.8898	77.7375
2014	7	19	3	57	0	0.3	4.3	0.86	94.2	91.8898	75.1462
2014	7	19	4	7	0	0.3	4.3	0.91	95	91.8898	79.465
2014	7	19	4	17	0	0.3	4.3	0.93	94.7	91.8898	81.1925
2014	7	19	4	27	0	0.3	4.3	0.87	96	91.8898	76.298
2014	7	19	4	37	0	0.3	4.3	0.88	92.1	91.8898	77.1617
2014	7	19	4	47	0	0.3	4.3	0.86	95.3	91.8898	75.1463
2014	7	19	4	57	0	0.3	4.3	0.9	97.5	91.8898	78.6014
2014	7	19	5	7	0	0.3	4.3	0.91	93.7	91.8898	80.041

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	5	17	0	0.3	4.3	0.89	94.5	91.8898	77.4497
2014	7	19	5	27	0	0.3	4.3	0.92	93.9	91.8898	80.3289
2014	7	19	5	37	0	0.3	4.3	0.89	95.1	91.8898	77.4498
2014	7	19	5	47	0	0.3	4.3	0.87	93.9	91.9554	76.3549
2014	7	19	5	57	0	0.3	4.3	0.88	94.5	91.9554	76.6431
2014	7	19	6	7	0	0.3	4.3	0.9	94.4	91.9554	78.66
2014	7	19	6	17	0	0.3	4.3	0.9	94.8	91.9554	78.9481
2014	7	19	6	27	0	0.3	4.3	0.85	94.2	92.021	74.6817
2014	7	19	6	37	0	0.3	4.3	0.88	94	91.9554	77.5075
2014	7	19	6	47	0	0.3	4.3	0.91	94.1	91.9554	79.8126
2014	7	19	6	57	0	0.3	4.3	0.9	95	91.9554	78.9482
2014	7	19	7	7	0	0.3	4.3	0.93	95	91.9554	81.5414
2014	7	19	7	17	0	0.3	4.3	0.93	94.9	91.9554	80.9651
2014	7	19	7	27	0	0.3	4.3	0.88	94	92.021	77.5652
2014	7	19	7	37	0	0.3	4.3	0.9	94.4	91.9554	78.6601
2014	7	19	7	47	0	0.3	4.3	0.84	94.3	92.021	73.24
2014	7	19	7	57	0	0.3	4.3	0.92	94.1	91.9554	80.677
2014	7	19	8	7	0	0.3	4.3	0.88	95.6	92.021	76.7002
2014	7	19	8	17	0	0.3	4.3	0.91	93.7	92.021	79.5836
2014	7	19	8	27	0	0.3	4.3	0.91	95.6	92.021	79.2953
2014	7	19	8	37	0	0.3	4.3	0.9	96.1	92.021	78.4302
2014	7	19	8	47	0	0.3	4.3	0.91	96.8	92.021	79.5836
2014	7	19	8	57	0	0.3	4.3	0.94	96.8	92.021	82.1787
2014	7	19	9	7	0	0.3	4.3	0.87	94.1	92.021	76.1234
2014	7	19	9	17	0	0.3	4.3	0.92	95.5	92.021	80.7369
2014	7	19	9	27	0	0.3	4.3	0.9	93.8	92.021	78.7185
2014	7	19	9	37	0	0.3	4.3	0.92	94.1	92.021	80.4485
2014	7	19	9	47	0	0.3	4.3	0.89	94.9	92.021	78.1417
2014	7	19	9	57	0	0.3	4.3	0.87	95.2	92.021	76.1233
2014	7	19	10	7	0	0.3	4.3	0.93	95.1	92.021	81.3135
2014	7	19	10	17	0	0.3	4.3	0.9	92.7	92.021	78.7183
2014	7	19	10	27	0	0.3	4.3	0.85	94.2	92.021	74.1048
2014	7	19	10	37	0	0.3	4.3	0.89	94.7	92.021	77.8532
2014	7	19	10	47	0	0.3	4.3	0.89	95.7	92.021	77.8532
2014	7	19	10	57	0	0.3	4.3	0.86	96.6	92.021	74.6814
2014	7	19	11	7	0	0.3	4.3	0.87	95	91.9554	75.7784
2014	7	19	11	17	0	0.3	4.3	0.88	94.5	91.9554	76.6427
2014	7	19	11	27	0	0.3	4.3	0.91	95.8	91.9554	79.524
2014	7	19	11	37	0	0.3	4.3	0.85	96.9	91.9554	74.3377
2014	7	19	11	47	0	0.3	4.3	0.87	94.7	91.9554	76.3546
2014	7	19	11	57	0	0.3	4.3	0.9	95.2	91.8898	78.889
2014	7	19	12	7	0	0.3	4.3	0.86	94.4	91.8898	75.1461
2014	7	19	12	17	0	0.3	4.3	0.85	96.6	91.9554	74.3375
2014	7	19	12	27	0	0.3	4.3	0.86	96.8	91.8898	75.146
2014	7	19	12	37	0	0.3	4.3	0.87	95.4	91.9554	76.0663
2014	7	19	12	47	0	0.3	4.3	0.88	96	91.8898	76.5855

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	12	57	0	0.3	4.3	0.87	95	91.8898	75.7217
2014	7	19	13	7	0	0.3	4.3	0.85	93.8	91.8898	74.57
2014	7	19	13	17	0	0.3	4.3	0.82	95.3	91.8898	71.4029
2014	7	19	13	27	0	0.3	4.3	0.84	95.6	91.8898	73.4184
2014	7	19	13	37	0	0.3	4.3	0.87	95.2	91.8898	76.2974
2014	7	19	13	47	0	0.3	4.3	0.83	95.5	91.8898	72.2666
2014	7	19	13	57	0	0.3	4.3	0.79	92.9	91.8898	69.3874
2014	7	19	14	7	0	0.3	4.3	0.85	96.2	91.8898	74.282
2014	7	19	14	17	0	0.3	4.3	0.85	98.2	91.8898	73.994
2014	7	19	14	27	0	0.3	4.3	0.84	93.8	91.8242	73.6512
2014	7	19	14	37	0	0.3	4.3	0.85	95.3	91.8242	73.9389
2014	7	19	14	47	0	0.3	4.3	0.87	94.3	91.8242	75.6651
2014	7	19	14	57	0	0.3	4.3	0.83	94.3	91.8242	72.5004
2014	7	19	15	7	0	0.3	4.3	0.85	93.5	91.8242	74.8019
2014	7	19	15	17	0	0.3	4.3	0.86	94.8	91.7585	75.0337
2014	7	19	15	27	0	0.3	4.3	0.84	95.8	91.7585	73.3088
2014	7	19	15	37	0	0.3	4.3	0.88	94.9	91.7585	76.7586
2014	7	19	15	47	0	0.3	4.3	0.82	96.4	91.7585	71.2964
2014	7	19	15	57	0	0.3	4.3	0.83	96.8	91.6929	71.8178
2014	7	19	16	7	0	0.3	4.3	0.82	93.2	91.6929	72.105
2014	7	19	16	17	0	0.3	4.3	0.84	96.3	91.6929	73.2541
2014	7	19	16	27	0	0.3	4.3	0.83	95.7	91.6929	72.105
2014	7	19	16	37	0	0.3	4.3	0.82	94.4	91.6929	71.5305
2014	7	19	16	47	0	0.3	4.3	0.89	95.7	91.6273	77.2182
2014	7	19	16	57	0	0.3	4.3	0.78	97	91.6273	68.0324
2014	7	19	17	7	0	0.3	4.3	0.81	98.4	91.5617	70.2764
2014	7	19	17	17	0	0.3	4.3	0.85	95.3	91.5617	74.0053
2014	7	19	17	27	0	0.3	4.3	0.83	95.7	91.6273	72.3383
2014	7	19	17	37	0	0.3	4.3	0.85	94.2	91.5617	74.2922
2014	7	19	17	47	0	0.3	4.3	0.83	95.5	91.5617	71.9975
2014	7	19	17	57	0	0.3	4.3	0.81	95.4	91.5617	70.2764
2014	7	19	18	7	0	0.3	4.3	0.86	95.1	91.5617	74.579
2014	7	19	18	17	0	0.3	4.3	0.8	94.7	91.5617	69.9896
2014	7	19	18	27	0	0.3	4.3	0.78	93.8	91.5617	68.2685
2014	7	19	18	37	0	0.3	4.3	0.85	96.7	91.5617	73.7186
2014	7	19	18	47	0	0.3	4.3	0.81	96.7	91.5617	70.5633
2014	7	19	18	57	0	0.3	4.3	0.82	95	91.5617	71.4238
2014	7	19	19	7	0	0.3	4.3	0.83	95.2	91.5617	72.5712
2014	7	19	19	17	0	0.3	4.3	0.85	95.6	91.5617	73.7186
2014	7	19	19	27	0	0.3	4.3	0.85	97.3	91.4961	73.9501
2014	7	19	19	37	0	0.3	4.3	0.85	95.5	91.4961	73.9502
2014	7	19	19	47	0	0.3	4.3	0.88	94.9	91.5617	76.5871
2014	7	19	19	57	0	0.3	4.3	0.87	96.5	91.5617	75.7265
2014	7	19	20	7	0	0.3	4.3	0.85	95.1	91.5617	73.7186
2014	7	19	20	17	0	0.3	4.3	0.85	96.7	91.5617	73.7186
2014	7	19	20	27	0	0.3	4.3	0.81	96.3	91.5617	69.9897

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	19	20	37	0	0.3	4.3	0.83	94.3	91.4961	72.2305
2014	7	19	20	47	0	0.3	4.3	0.82	94.6	91.5617	71.1371
2014	7	19	20	57	0	0.3	4.3	0.85	95.5	91.4961	74.2369
2014	7	19	21	7	0	0.3	4.3	0.86	93.3	91.4961	75.0968
2014	7	19	21	17	0	0.3	4.3	0.83	97.7	91.5617	72.2845
2014	7	19	21	27	0	0.3	4.3	0.84	93.6	91.4961	73.0904
2014	7	19	21	37	0	0.3	4.3	0.81	94.2	91.5617	70.2766
2014	7	19	21	47	0	0.3	4.3	0.85	95.6	91.5617	73.7187
2014	7	19	21	57	0	0.3	4.3	0.83	94.1	91.6273	72.3385
2014	7	19	22	7	0	0.3	4.3	0.83	92.3	91.6929	72.3925
2014	7	19	22	17	0	0.3	4.3	0.88	93.2	91.6929	76.9889
2014	7	19	22	27	0	0.3	4.3	0.85	94.4	91.6929	73.8289
2014	7	19	22	37	0	0.3	4.3	0.84	96.7	91.6929	73.2544
2014	7	19	22	47	0	0.3	4.3	0.89	95.9	91.6929	77.5635
2014	7	19	22	57	0	0.3	4.3	0.86	96.8	91.6929	74.6908
2014	7	19	23	7	0	0.3	4.3	0.86	95.5	91.6929	75.2653
2014	7	19	23	17	0	0.3	4.3	0.85	95.8	91.6929	74.1163
2014	7	19	23	27	0	0.3	4.3	0.87	96.5	91.6929	76.1272
2014	7	19	23	37	0	0.3	4.3	0.85	97.3	91.6929	74.1163
2014	7	19	23	47	0	0.3	4.3	0.9	95	91.6929	78.1381
2014	7	19	23	57	0	0.3	4.3	0.88	94.5	91.6929	76.989
2014	7	20	0	7	0	0.3	4.3	0.85	94.2	91.6929	74.1163
2014	7	20	0	17	0	0.3	4.3	0.85	97.7	91.6929	74.1163
2014	7	20	0	27	0	0.3	4.3	0.85	94	91.6929	74.1164
2014	7	20	0	37	0	0.3	4.3	0.84	93.3	91.6929	73.8291
2014	7	20	0	47	0	0.3	4.3	0.85	93.5	91.7585	74.1717
2014	7	20	0	57	0	0.3	4.3	0.85	94.9	91.7585	73.8842
2014	7	20	1	7	0	0.3	4.3	0.86	97.4	91.7585	75.0342
2014	7	20	1	17	0	0.3	4.3	0.85	94.2	91.7585	74.4592
2014	7	20	1	27	0	0.3	4.3	0.89	94.6	91.7585	77.9091
2014	7	20	1	37	0	0.3	4.3	0.88	93.8	91.7585	77.0466
2014	7	20	1	47	0	0.3	4.3	0.87	94.7	91.7585	76.1842
2014	7	20	1	57	0	0.3	4.3	0.87	93.3	91.7585	75.8967
2014	7	20	2	7	0	0.3	4.3	0.85	96.6	91.7585	74.1718
2014	7	20	2	17	0	0.3	4.3	0.88	95.2	91.7585	76.4717
2014	7	20	2	27	0	0.3	4.3	0.86	93.1	91.7585	75.0343
2014	7	20	2	37	0	0.3	4.3	0.91	95	91.7585	79.0592
2014	7	20	2	47	0	0.3	4.3	0.85	96	91.7585	73.8844
2014	7	20	2	57	0	0.3	4.3	0.86	92.2	91.7585	75.3219
2014	7	20	3	7	0	0.3	4.3	0.88	97.5	91.7585	76.1844
2014	7	20	3	17	0	0.3	4.3	0.89	95.3	91.7585	77.6218
2014	7	20	3	27	0	0.3	4.3	0.91	94.5	91.7585	79.6343
2014	7	20	3	37	0	0.3	4.3	0.9	96.9	91.7585	78.4843
2014	7	20	3	47	0	0.3	4.3	0.88	95.1	91.7585	77.0469
2014	7	20	3	57	0	0.3	4.3	0.84	95.8	91.7585	73.3096
2014	7	20	4	7	0	0.3	4.3	0.9	96.1	91.7585	78.1969

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	4	17	0	0.3	4.3	0.88	96	91.7585	77.047
2014	7	20	4	27	0	0.3	4.3	0.91	92.7	91.7585	79.9219
2014	7	20	4	37	0	0.3	4.3	0.91	94.5	91.7585	79.6344
2014	7	20	4	47	0	0.3	4.3	0.85	94	91.7585	74.1721
2014	7	20	4	57	0	0.3	4.3	0.87	94.1	91.7585	76.1846
2014	7	20	5	7	0	0.3	4.3	0.87	93.9	91.7585	75.8971
2014	7	20	5	17	0	0.3	4.3	0.86	94.2	91.7585	74.7472
2014	7	20	5	27	0	0.3	4.3	0.9	92.1	91.8242	78.8308
2014	7	20	5	37	0	0.3	4.3	0.86	93.9	91.8242	75.6661
2014	7	20	5	47	0	0.3	4.3	0.92	93.1	91.8242	80.8447
2014	7	20	5	57	0	0.3	4.3	0.87	93.3	91.8242	75.9538
2014	7	20	6	7	0	0.3	4.3	0.88	97.3	91.7585	76.1847
2014	7	20	6	17	0	0.3	4.3	0.89	92.5	91.8242	77.68
2014	7	20	6	27	0	0.3	4.3	0.88	94.5	91.7585	77.0472
2014	7	20	6	37	0	0.3	4.3	0.87	95.2	91.7585	75.6098
2014	7	20	6	47	0	0.3	4.3	0.84	94.3	91.7585	73.3099
2014	7	20	6	57	0	0.3	4.3	0.85	93.1	91.7585	74.4598
2014	7	20	7	7	0	0.3	4.3	0.87	95.6	91.7585	75.8973
2014	7	20	7	17	0	0.3	4.3	0.88	92.8	91.8242	77.3924
2014	7	20	7	27	0	0.3	4.3	0.92	92.6	91.8242	80.8449
2014	7	20	7	37	0	0.3	4.3	0.87	93	91.8242	75.9539
2014	7	20	7	47	0	0.3	4.3	0.87	93.4	91.8242	76.5293
2014	7	20	7	57	0	0.3	4.3	0.91	93.3	91.8242	79.9818
2014	7	20	8	7	0	0.3	4.3	0.87	93.9	91.8242	76.5293
2014	7	20	8	17	0	0.3	4.3	0.91	93.5	91.8242	79.6941
2014	7	20	8	27	0	0.3	4.3	0.91	94.6	91.8242	79.1187
2014	7	20	8	37	0	0.3	4.3	0.87	92.2	91.8242	75.9539
2014	7	20	8	47	0	0.3	4.3	0.9	96.1	91.8242	78.5432
2014	7	20	8	57	0	0.3	4.3	0.9	94	91.8898	79.1776
2014	7	20	9	7	0	0.3	4.3	0.9	95.4	91.8898	78.6017
2014	7	20	9	17	0	0.3	4.3	0.9	95.6	91.8898	78.6017
2014	7	20	9	27	0	0.3	4.3	0.89	93.6	91.8898	78.3138
2014	7	20	9	37	0	0.3	4.3	0.83	94.8	91.8898	72.2674
2014	7	20	9	47	0	0.3	4.3	0.88	93.8	91.8898	77.4499
2014	7	20	9	57	0	0.3	4.3	0.86	93.9	91.8898	75.1466
2014	7	20	10	7	0	0.3	4.3	0.86	93.3	91.8898	75.1466
2014	7	20	10	17	0	0.3	4.3	0.86	96.4	91.8898	74.8587
2014	7	20	10	27	0	0.3	4.3	0.87	94.8	91.8898	75.7224
2014	7	20	10	37	0	0.3	4.3	0.86	95.3	91.8898	75.1465
2014	7	20	10	47	0	0.3	4.3	0.88	94.3	91.8898	77.4498
2014	7	20	10	57	0	0.3	4.3	0.89	94.9	91.8898	77.4498
2014	7	20	11	7	0	0.3	4.3	0.85	96	91.8898	74.5706
2014	7	20	11	17	0	0.3	4.3	0.86	95.5	91.8898	75.4343
2014	7	20	11	27	0	0.3	4.3	0.85	94	91.8898	74.2826
2014	7	20	11	37	0	0.3	4.3	0.87	94.3	91.8898	76.0102
2014	7	20	11	47	0	0.3	4.3	0.89	95.1	91.8898	78.0256

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	11	57	0	0.3	4.3	0.83	95.7	91.8898	72.2672
2014	7	20	12	7	0	0.3	4.3	0.93	95.9	91.8898	81.1926
2014	7	20	12	17	0	0.3	4.3	0.86	95.5	91.8898	74.8584
2014	7	20	12	27	0	0.3	4.3	0.86	94.4	91.8898	74.8584
2014	7	20	12	37	0	0.3	4.3	0.87	95.6	91.8898	76.0101
2014	7	20	12	47	0	0.3	4.3	0.85	96.9	91.8898	74.2826
2014	7	20	12	57	0	0.3	4.3	0.84	93.3	91.8242	73.9396
2014	7	20	13	7	0	0.3	4.3	0.91	93.7	91.8898	79.465
2014	7	20	13	17	0	0.3	4.3	0.85	95.6	91.8898	73.9945
2014	7	20	13	27	0	0.3	4.3	0.87	95.2	91.8898	76.2978
2014	7	20	13	37	0	0.3	4.3	0.88	95.3	91.8898	76.8736
2014	7	20	13	47	0	0.3	4.3	0.89	95.9	91.8898	77.7374
2014	7	20	13	57	0	0.3	4.3	0.88	93.2	91.8898	76.8736
2014	7	20	14	7	0	0.3	4.3	0.87	96.5	91.8898	75.434
2014	7	20	14	17	0	0.3	4.3	0.84	94.3	91.8898	73.1306
2014	7	20	14	27	0	0.3	4.3	0.86	96.4	91.8898	74.8582
2014	7	20	14	37	0	0.3	4.3	0.84	92.5	91.8898	73.4185
2014	7	20	14	47	0	0.3	4.3	0.9	94.6	91.8898	78.8889
2014	7	20	14	57	0	0.3	4.3	0.89	95.3	91.8242	77.3916
2014	7	20	15	7	0	0.3	4.3	0.85	95.8	91.8898	74.2823
2014	7	20	15	17	0	0.3	4.3	0.86	96.6	91.8898	74.8581
2014	7	20	15	27	0	0.3	4.3	0.81	96.5	91.8898	70.5394
2014	7	20	15	37	0	0.3	4.3	0.88	93	91.8898	76.8735
2014	7	20	15	47	0	0.3	4.3	0.87	96.5	91.8898	76.2977
2014	7	20	15	57	0	0.3	4.3	0.91	94.1	91.8898	79.4647
2014	7	20	16	7	0	0.3	4.3	0.83	96.8	91.8242	72.5007
2014	7	20	16	17	0	0.3	4.3	0.83	97.9	91.7585	72.1592
2014	7	20	16	27	0	0.3	4.3	0.84	97	91.7585	72.7341
2014	7	20	16	37	0	0.3	4.3	0.85	99.3	91.8242	73.6514
2014	7	20	16	47	0	0.3	4.3	0.83	98.2	91.7585	71.8716
2014	7	20	16	57	0	0.3	4.3	0.87	98.3	91.7585	75.034
2014	7	20	17	7	0	0.3	4.3	0.82	99.2	91.7585	71.0092
2014	7	20	17	17	0	0.3	4.3	0.8	96.8	91.6929	69.5199
2014	7	20	17	27	0	0.3	4.3	0.81	98.8	91.7585	70.4342
2014	7	20	17	37	0	0.3	4.3	0.81	101	91.7585	69.5717
2014	7	20	17	47	0	0.3	4.3	0.79	99.8	91.8242	68.4728
2014	7	20	17	57	0	0.3	4.3	0.77	100.3	91.6929	66.6472
2014	7	20	18	7	0	0.3	4.3	0.77	100.5	91.6929	66.3599
2014	7	20	18	17	0	0.3	4.3	0.8	100.6	91.6273	68.8939
2014	7	20	18	27	0	0.3	4.3	0.81	100.2	91.7585	70.1467
2014	7	20	18	37	0	0.3	4.3	0.76	100.2	91.6929	65.4981
2014	7	20	18	47	0	0.3	4.3	0.87	96.1	91.6929	75.5526
2014	7	20	18	57	0	0.3	4.3	0.83	95.7	91.7585	72.4466
2014	7	20	19	7	0	0.3	4.3	0.81	95.6	91.7585	70.7217
2014	7	20	19	17	0	0.3	4.3	0.88	96.9	91.7585	76.4714
2014	7	20	19	27	0	0.3	4.3	0.86	96.3	91.7585	75.3214

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	20	19	37	0	0.3	4.3	0.85	97.3	91.7585	73.5965
2014	7	20	19	47	0	0.3	4.3	0.86	97.2	91.7585	75.034
2014	7	20	19	57	0	0.3	4.3	0.86	95.7	91.7585	75.034
2014	7	20	20	7	0	0.3	4.3	0.87	94.3	91.7585	75.8964
2014	7	20	20	17	0	0.3	4.3	0.88	95.1	91.7585	76.7589
2014	7	20	20	27	0	0.3	4.3	0.86	95.5	91.7585	75.3215
2014	7	20	20	37	0	0.3	4.3	0.9	96.2	91.7585	78.7713
2014	7	20	20	47	0	0.3	4.3	0.89	92.5	91.7585	77.9089
2014	7	20	20	57	0	0.3	4.3	0.86	93.3	91.7585	75.3215
2014	7	20	21	7	0	0.3	4.3	0.87	95.2	91.7585	75.8965
2014	7	20	21	17	0	0.3	4.3	0.84	96.2	91.8242	73.6515
2014	7	20	21	27	0	0.3	4.3	0.86	93.5	91.7585	75.3215
2014	7	20	21	37	0	0.3	4.3	0.89	97.2	91.7585	77.3339
2014	7	20	21	47	0	0.3	4.3	0.89	94.7	91.7585	77.3339
2014	7	20	21	57	0	0.3	4.3	0.83	94.3	91.8242	72.5007
2014	7	20	22	7	0	0.3	4.3	0.89	94.9	91.8242	77.6793
2014	7	20	22	17	0	0.3	4.3	0.89	98.1	91.8242	77.1039
2014	7	20	22	27	0	0.3	4.3	0.86	96.6	91.8242	75.0901
2014	7	20	22	37	0	0.3	4.3	0.89	98.2	91.7585	77.334
2014	7	20	22	47	0	0.3	4.3	0.84	95.2	91.8242	73.3639
2014	7	20	22	57	0	0.3	4.3	0.84	95.4	91.8242	73.6516
2014	7	20	23	7	0	0.3	4.3	0.88	95.1	91.7585	77.0466
2014	7	20	23	17	0	0.3	4.3	0.88	96.9	91.7585	76.1841
2014	7	20	23	27	0	0.3	4.3	0.87	95.2	91.7585	76.1842
2014	7	20	23	37	0	0.3	4.3	0.87	95.8	91.7585	75.8967
2014	7	20	23	47	0	0.3	4.3	0.92	95.5	91.7585	80.209
2014	7	20	23	57	0	0.3	4.3	0.89	95.5	91.7585	77.6217
2014	7	21	0	7	0	0.3	4.3	0.86	95.3	91.7585	75.0343
2014	7	21	0	17	0	0.3	4.3	0.87	96	91.7585	76.1843
2014	7	21	0	27	0	0.3	4.3	0.89	96.3	91.7585	77.6217
2014	7	21	0	37	0	0.3	4.3	0.88	93.2	91.7585	77.3342
2014	7	21	0	47	0	0.3	4.3	0.87	96.5	91.7585	76.1843
2014	7	21	0	57	0	0.3	4.3	0.86	96.6	91.7585	74.7469
2014	7	21	1	7	0	0.3	4.3	0.88	94.9	91.7585	77.0468
2014	7	21	1	17	0	0.3	4.3	0.88	94.3	91.7585	76.7594
2014	7	21	1	27	0	0.3	4.3	0.82	93.9	91.8242	71.9257
2014	7	21	1	37	0	0.3	4.3	0.88	94.5	91.7585	76.4719
2014	7	21	1	47	0	0.3	4.3	0.92	95.5	91.7585	80.2093
2014	7	21	1	57	0	0.3	4.3	0.88	94.1	91.7585	77.0469
2014	7	21	2	7	0	0.3	4.3	0.87	95.6	91.8242	75.9536
2014	7	21	2	17	0	0.3	4.3	0.85	94.2	91.8242	74.5151
2014	7	21	2	27	0	0.3	4.3	0.85	93.5	91.8242	74.5151
2014	7	21	2	37	0	0.3	4.3	0.91	96	91.8242	79.6938
2014	7	21	2	47	0	0.3	4.3	0.86	96.6	91.8242	75.0905
2014	7	21	2	57	0	0.3	4.3	0.88	95.8	91.8242	76.8168
2014	7	21	3	7	0	0.3	4.3	0.88	96	91.8242	77.1045

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	3	17	0	0.3	4.3	0.88	94.9	91.8242	76.5291
2014	7	21	3	27	0	0.3	4.3	0.87	96.1	91.8242	75.666
2014	7	21	3	37	0	0.3	4.3	0.92	95.3	91.8242	79.9816
2014	7	21	3	47	0	0.3	4.3	0.88	94.3	91.8242	76.8169
2014	7	21	3	57	0	0.3	4.3	0.86	97.7	91.8242	74.803
2014	7	21	4	7	0	0.3	4.3	0.85	94.9	91.8242	74.2276
2014	7	21	4	17	0	0.3	4.3	0.86	94.6	91.8242	75.0908
2014	7	21	4	27	0	0.3	4.3	0.87	95.2	91.8242	75.9539
2014	7	21	4	37	0	0.3	4.3	0.89	95.9	91.8242	77.3924
2014	7	21	4	47	0	0.3	4.3	0.89	94.5	91.8242	77.3925
2014	7	21	4	57	0	0.3	4.3	0.85	92.6	91.8242	74.8031
2014	7	21	5	7	0	0.3	4.3	0.84	94.2	91.8242	73.6524
2014	7	21	5	17	0	0.3	4.3	0.85	96.9	91.8242	74.2278
2014	7	21	5	27	0	0.3	4.3	0.87	94.7	91.8242	76.2418
2014	7	21	5	37	0	0.3	4.3	0.85	94.7	91.8242	74.2279
2014	7	21	5	47	0	0.3	4.3	0.88	96	91.8242	76.5295
2014	7	21	5	57	0	0.3	4.3	0.88	93.2	91.8242	77.1049
2014	7	21	6	7	0	0.3	4.3	0.86	95.7	91.8242	75.091
2014	7	21	6	17	0	0.3	4.3	0.91	95	91.8242	79.6943
2014	7	21	6	27	0	0.3	4.3	0.87	95	91.8242	75.9542
2014	7	21	6	37	0	0.3	4.3	0.89	95.3	91.8898	77.7383
2014	7	21	6	47	0	0.3	4.3	0.9	96.9	91.8898	78.0263
2014	7	21	6	57	0	0.3	4.3	0.84	93.6	91.8898	73.9954
2014	7	21	7	7	0	0.3	4.3	0.87	95.2	91.9554	75.7793
2014	7	21	7	17	0	0.3	4.3	0.89	95.5	91.9554	78.0844
2014	7	21	7	27	0	0.3	4.3	0.89	95.1	91.9554	77.7963
2014	7	21	7	37	0	0.3	4.3	0.84	95.4	91.9554	73.4743
2014	7	21	7	47	0	0.3	4.3	0.9	94.4	92.021	78.4308
2014	7	21	7	57	0	0.3	4.3	0.86	94.6	92.021	75.5474
2014	7	21	8	7	0	0.3	4.3	0.89	95.5	92.0866	77.6234
2014	7	21	8	17	0	0.3	4.3	0.92	94.9	92.021	80.4493
2014	7	21	8	27	0	0.3	4.3	0.9	95	92.0866	78.4891
2014	7	21	8	37	0	0.3	4.3	0.86	94.8	92.021	75.5473
2014	7	21	8	47	0	0.3	4.3	0.88	96	92.0866	76.7577
2014	7	21	8	57	0	0.3	4.3	0.92	95.9	92.0866	80.509
2014	7	21	9	7	0	0.3	4.3	0.88	94.3	92.021	76.7007
2014	7	21	9	17	0	0.3	4.3	0.9	95.7	92.0866	78.4891
2014	7	21	9	27	0	0.3	4.3	0.88	93.4	92.021	76.989
2014	7	21	9	37	0	0.3	4.3	0.87	95	92.021	76.124
2014	7	21	9	47	0	0.3	4.3	0.86	94.8	92.021	75.5472
2014	7	21	9	57	0	0.3	4.3	0.88	93.2	92.021	76.989
2014	7	21	10	7	0	0.3	4.3	0.88	96	92.021	76.7006
2014	7	21	10	17	0	0.3	4.3	0.9	96.1	91.9554	78.3723
2014	7	21	10	27	0	0.3	4.3	0.93	94.7	91.9554	81.2536
2014	7	21	10	37	0	0.3	4.3	0.86	96.8	91.8898	74.571
2014	7	21	10	47	0	0.3	4.3	0.86	95.9	91.8898	74.8589

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	10	57	0	0.3	4.3	0.84	94.7	91.8898	73.7072
2014	7	21	11	7	0	0.3	4.3	0.84	98.1	91.8898	73.1313
2014	7	21	11	17	0	0.3	4.3	0.86	97.5	91.8898	74.8588
2014	7	21	11	27	0	0.3	4.3	0.85	98.6	91.8898	73.995
2014	7	21	11	37	0	0.3	4.3	0.86	96.8	91.8898	74.5709
2014	7	21	11	47	0	0.3	4.3	0.86	98.4	91.8898	74.2829
2014	7	21	11	57	0	0.3	4.3	0.86	97.5	91.8242	74.5153
2014	7	21	12	7	0	0.3	4.3	0.86	95	91.8898	75.1466
2014	7	21	12	17	0	0.3	4.3	0.85	96.4	91.8898	73.9949
2014	7	21	12	27	0	0.3	4.3	0.83	94.5	91.8898	72.5553
2014	7	21	12	37	0	0.3	4.3	0.87	95.2	91.8242	75.6659
2014	7	21	12	47	0	0.3	4.3	0.87	95	91.8242	75.6659
2014	7	21	12	57	0	0.3	4.3	0.82	95.9	91.8898	71.9793
2014	7	21	13	7	0	0.3	4.3	0.84	95.6	91.8242	73.6519
2014	7	21	13	17	0	0.3	4.3	0.82	93.2	91.8898	71.6913
2014	7	21	13	27	0	0.3	4.3	0.86	95.1	91.8898	74.8584
2014	7	21	13	37	0	0.3	4.3	0.86	95.3	91.8242	75.0903
2014	7	21	13	47	0	0.3	4.3	0.82	97.1	91.8898	71.4033
2014	7	21	13	57	0	0.3	4.3	0.87	95.6	91.8898	75.7221
2014	7	21	14	7	0	0.3	4.3	0.8	95.6	91.8242	70.1993
2014	7	21	14	17	0	0.3	4.3	0.84	95.2	91.8242	73.3641
2014	7	21	14	27	0	0.3	4.3	0.85	94.7	91.8242	74.2272
2014	7	21	14	37	0	0.3	4.3	0.89	95.3	91.8242	77.3919
2014	7	21	14	47	0	0.3	4.3	0.81	96	91.8242	70.7747
2014	7	21	14	57	0	0.3	4.3	0.82	96.9	91.8242	71.35
2014	7	21	15	7	0	0.3	4.3	0.84	95	91.8242	73.0762
2014	7	21	15	17	0	0.3	4.3	0.88	95.2	91.8242	76.5286
2014	7	21	15	27	0	0.3	4.3	0.82	97.8	91.8242	71.0623
2014	7	21	15	37	0	0.3	4.3	0.84	96.7	91.7585	73.3092
2014	7	21	15	47	0	0.3	4.3	0.84	96.3	91.7585	72.7343
2014	7	21	15	57	0	0.3	4.3	0.86	96.1	91.7585	75.0341
2014	7	21	16	7	0	0.3	4.3	0.81	96.3	91.7585	70.7218
2014	7	21	16	17	0	0.3	4.3	0.89	93	91.7585	77.909
2014	7	21	16	27	0	0.3	4.3	0.83	95	91.6929	72.1055
2014	7	21	16	37	0	0.3	4.3	0.83	94.7	91.7585	72.7342
2014	7	21	16	47	0	0.3	4.3	0.84	97.2	91.7585	73.0217
2014	7	21	16	57	0	0.3	4.3	0.8	93.8	91.6929	69.8073
2014	7	21	17	7	0	0.3	4.3	0.83	94.6	91.6929	72.1055
2014	7	21	17	17	0	0.3	4.3	0.84	97.2	91.6929	72.9673
2014	7	21	17	27	0	0.3	4.3	0.83	94.7	91.6929	72.68
2014	7	21	17	37	0	0.3	4.3	0.87	95	91.6929	76.1273
2014	7	21	17	47	0	0.3	4.3	0.82	95	91.6929	71.5309
2014	7	21	17	57	0	0.3	4.3	0.8	96.2	91.6929	69.2327
2014	7	21	18	7	0	0.3	4.3	0.82	97.4	91.6273	70.9035
2014	7	21	18	17	0	0.3	4.3	0.83	95.4	91.6273	72.3387
2014	7	21	18	27	0	0.3	4.3	0.85	96	91.6273	73.774

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	21	18	37	0	0.3	4.3	0.84	94.3	91.6273	73.1999
2014	7	21	18	47	0	0.3	4.3	0.86	95.3	91.6273	74.9223
2014	7	21	18	57	0	0.3	4.3	0.86	97	91.6273	74.9223
2014	7	21	19	7	0	0.3	4.3	0.86	95.2	91.6273	75.2093
2014	7	21	19	17	0	0.3	4.3	0.84	97	91.6273	72.6258
2014	7	21	19	27	0	0.3	4.3	0.86	95.7	91.6273	74.9223
2014	7	21	19	37	0	0.3	4.3	0.87	95.6	91.6273	75.4964
2014	7	21	19	47	0	0.3	4.3	0.84	97.6	91.6273	73.2
2014	7	21	19	57	0	0.3	4.3	0.84	97.2	91.6273	73.2
2014	7	21	20	7	0	0.3	4.3	0.85	96.2	91.6273	74.0611
2014	7	21	20	17	0	0.3	4.3	0.82	96.9	91.6273	70.9035
2014	7	21	20	27	0	0.3	4.3	0.84	96.5	91.6273	72.9129
2014	7	21	20	37	0	0.3	4.3	0.86	94.4	91.6273	75.2094
2014	7	21	20	47	0	0.3	4.3	0.84	97.4	91.6929	73.2547
2014	7	21	20	57	0	0.3	4.3	0.82	96	91.6273	71.1906
2014	7	21	21	7	0	0.3	4.3	0.84	96	91.6273	73.2
2014	7	21	21	17	0	0.3	4.3	0.85	95.6	91.6273	73.7741
2014	7	21	21	27	0	0.3	4.3	0.85	94.2	91.6273	74.3483
2014	7	21	21	37	0	0.3	4.3	0.84	94.7	91.6929	73.2547
2014	7	21	21	47	0	0.3	4.3	0.86	98.1	91.6929	74.4038
2014	7	21	21	57	0	0.3	4.3	0.81	96.1	91.6273	70.3295
2014	7	21	22	7	0	0.3	4.3	0.83	95.7	91.6273	72.0518
2014	7	21	22	17	0	0.3	4.3	0.81	98.4	91.6273	70.3295
2014	7	21	22	27	0	0.3	4.3	0.86	96.6	91.6929	74.4039
2014	7	21	22	37	0	0.3	4.3	0.83	96.8	91.6273	72.3389
2014	7	21	22	47	0	0.3	4.3	0.81	97	91.6929	70.3821
2014	7	21	22	57	0	0.3	4.3	0.83	96.4	91.6273	71.7649
2014	7	21	23	7	0	0.3	4.3	0.84	94.9	91.6929	73.2548
2014	7	21	23	17	0	0.3	4.3	0.8	94.5	91.6929	69.8076
2014	7	21	23	27	0	0.3	4.3	0.81	95.8	91.6929	70.3821
2014	7	21	23	37	0	0.3	4.3	0.88	94.1	91.6929	76.7022
2014	7	21	23	47	0	0.3	4.3	0.84	94.7	91.6929	73.5422
2014	7	21	23	57	0	0.3	4.3	0.87	96.1	91.6929	75.8404
2014	7	22	0	7	0	0.3	4.3	0.87	94.3	91.6929	76.1277
2014	7	22	0	17	0	0.3	4.3	0.87	96.5	91.6929	75.2659
2014	7	22	0	27	0	0.3	4.3	0.84	96	91.6929	73.255
2014	7	22	0	37	0	0.3	4.3	0.86	93.3	91.6929	74.9786
2014	7	22	0	47	0	0.3	4.3	0.86	93.9	91.6929	75.5532
2014	7	22	0	57	0	0.3	4.3	0.83	94.8	91.6929	72.1059
2014	7	22	1	7	0	0.3	4.3	0.85	95.3	91.6929	73.8296
2014	7	22	1	17	0	0.3	4.3	0.89	94.9	91.6929	77.8514
2014	7	22	1	27	0	0.3	4.3	0.85	93.8	91.6929	74.4041
2014	7	22	1	37	0	0.3	4.3	0.88	95.3	91.6929	76.7023
2014	7	22	1	47	0	0.3	4.3	0.89	95.7	91.6929	77.2769
2014	7	22	1	57	0	0.3	4.3	0.9	91.9	91.6929	79.0006
2014	7	22	2	7	0	0.3	4.3	0.87	95.2	91.7585	76.1846

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	2	17	0	0.3	4.3	0.85	94.6	91.7585	74.4597
2014	7	22	2	27	0	0.3	4.3	0.88	92.8	91.7585	77.0471
2014	7	22	2	37	0	0.3	4.3	0.88	95.8	91.6929	76.7025
2014	7	22	2	47	0	0.3	4.3	0.84	94.7	91.6929	72.9679
2014	7	22	2	57	0	0.3	4.3	0.86	95	91.6929	74.9788
2014	7	22	3	7	0	0.3	4.3	0.92	95.3	91.7585	79.9221
2014	7	22	3	17	0	0.3	4.3	0.92	94.9	91.7585	79.9221
2014	7	22	3	27	0	0.3	4.3	0.87	93.7	91.7585	75.8973
2014	7	22	3	37	0	0.3	4.3	0.81	96.1	91.7585	70.1475
2014	7	22	3	47	0	0.3	4.3	0.86	94.8	91.7585	75.3223
2014	7	22	3	57	0	0.3	4.3	0.86	94.2	91.7585	75.0349
2014	7	22	4	7	0	0.3	4.3	0.87	94.1	91.7585	76.1848
2014	7	22	4	17	0	0.3	4.3	0.9	95	91.7585	78.4848
2014	7	22	4	27	0	0.3	4.3	0.85	94.2	91.7585	74.1724
2014	7	22	4	37	0	0.3	4.3	0.9	94	91.7585	78.4848
2014	7	22	4	47	0	0.3	4.3	0.86	94.8	91.7585	74.7475
2014	7	22	4	57	0	0.3	4.3	0.9	95.4	91.7585	78.4848
2014	7	22	5	7	0	0.3	4.3	0.87	94.3	91.7585	76.1849
2014	7	22	5	17	0	0.3	4.3	0.86	95	91.7585	75.3225
2014	7	22	5	27	0	0.3	4.3	0.85	94.2	91.7585	74.46
2014	7	22	5	37	0	0.3	4.3	0.88	95.1	91.7585	77.0475
2014	7	22	5	47	0	0.3	4.3	0.87	95	91.7585	75.8975
2014	7	22	5	57	0	0.3	4.3	0.83	95.7	91.7585	72.1602
2014	7	22	6	7	0	0.3	4.3	0.87	94.3	91.8242	76.2419
2014	7	22	6	17	0	0.3	4.3	0.89	95.9	91.8242	77.3927
2014	7	22	6	27	0	0.3	4.3	0.91	94.4	91.8242	79.4066
2014	7	22	6	37	0	0.3	4.3	0.88	94.1	91.8242	76.8173
2014	7	22	6	47	0	0.3	4.3	0.87	94.3	91.8242	75.6665
2014	7	22	6	57	0	0.3	4.3	0.93	94.7	91.8242	81.1329
2014	7	22	7	7	0	0.3	4.3	0.86	97	91.8242	74.8034
2014	7	22	7	17	0	0.3	4.3	0.84	95.6	91.8242	73.6526
2014	7	22	7	27	0	0.3	4.3	0.92	94.7	91.8242	79.9822
2014	7	22	7	37	0	0.3	4.3	0.87	95.2	91.8242	76.242
2014	7	22	7	47	0	0.3	4.3	0.85	94	91.8898	73.9954
2014	7	22	7	57	0	0.3	4.3	0.87	95.4	91.8898	76.2988
2014	7	22	8	7	0	0.3	4.3	0.85	94.2	91.8898	73.9954
2014	7	22	8	17	0	0.3	4.3	0.9	95.2	91.8898	78.6022
2014	7	22	8	27	0	0.3	4.3	0.85	94.2	91.8898	73.9954
2014	7	22	8	37	0	0.3	4.3	0.85	94.2	91.9554	74.3386
2014	7	22	8	47	0	0.3	4.3	0.89	95.7	91.9554	77.7962
2014	7	22	8	57	0	0.3	4.3	0.87	98.7	91.9554	75.203
2014	7	22	9	7	0	0.3	4.3	0.82	96.7	91.9554	71.4572
2014	7	22	9	17	0	0.3	4.3	0.88	95.1	91.8898	76.8746
2014	7	22	9	27	0	0.3	4.3	0.85	96.4	91.9554	74.3385
2014	7	22	9	37	0	0.3	4.3	0.84	95.1	91.9554	73.7623
2014	7	22	9	47	0	0.3	4.3	0.89	95.7	91.9554	77.7961

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	9	57	0	0.3	4.3	0.88	96	91.8898	76.5865
2014	7	22	10	7	0	0.3	4.3	0.88	95.3	91.8898	77.1624
2014	7	22	10	17	0	0.3	4.3	0.88	96.2	91.8898	76.5865
2014	7	22	10	27	0	0.3	4.3	0.85	95.5	91.8898	74.571
2014	7	22	10	37	0	0.3	4.3	0.85	94	91.8898	74.571
2014	7	22	10	47	0	0.3	4.3	0.87	96.2	91.8898	76.2985
2014	7	22	10	57	0	0.3	4.3	0.91	94.8	91.8898	79.4655
2014	7	22	11	7	0	0.3	4.3	0.9	94.2	91.8898	78.6017
2014	7	22	11	17	0	0.3	4.3	0.86	96.4	91.8898	74.8588
2014	7	22	11	27	0	0.3	4.3	0.88	95.3	91.8898	76.8742
2014	7	22	11	37	0	0.3	4.3	0.85	94.9	91.8898	74.5708
2014	7	22	11	47	0	0.3	4.3	0.87	95.2	91.8898	75.7224
2014	7	22	11	57	0	0.3	4.3	0.87	95	91.8898	75.7224
2014	7	22	12	7	0	0.3	4.3	0.84	96.5	91.8898	73.1311
2014	7	22	12	17	0	0.3	4.3	0.87	96.7	91.8898	75.7223
2014	7	22	12	27	0	0.3	4.3	0.89	96.6	91.8898	77.4498
2014	7	22	12	37	0	0.3	4.3	0.84	94.1	91.8898	73.131
2014	7	22	12	47	0	0.3	4.3	0.86	94.8	91.8898	75.4343
2014	7	22	12	57	0	0.3	4.3	0.83	96.4	91.8242	72.2134
2014	7	22	13	7	0	0.3	4.3	0.86	94.6	91.8898	75.1463
2014	7	22	13	17	0	0.3	4.3	0.86	98.1	91.8898	74.5704
2014	7	22	13	27	0	0.3	4.3	0.86	95.2	91.8898	75.4342
2014	7	22	13	37	0	0.3	4.3	0.85	96.6	91.8898	74.2825
2014	7	22	13	47	0	0.3	4.3	0.84	94.3	91.8898	73.4187
2014	7	22	13	57	0	0.3	4.3	0.81	95.5	91.8898	71.1153
2014	7	22	14	7	0	0.3	4.3	0.83	95.2	91.8898	72.8428
2014	7	22	14	17	0	0.3	4.3	0.86	95	91.8898	75.1461
2014	7	22	14	27	0	0.3	4.3	0.84	95.6	91.8898	73.4186
2014	7	22	14	37	0	0.3	4.3	0.84	96.7	91.8898	73.1306
2014	7	22	14	47	0	0.3	4.3	0.85	93.3	91.8242	74.227
2014	7	22	14	57	0	0.3	4.3	0.81	96	91.8242	70.7746
2014	7	22	15	7	0	0.3	4.3	0.86	95	91.8242	75.0901
2014	7	22	15	17	0	0.3	4.3	0.84	96	91.8242	73.6515
2014	7	22	15	27	0	0.3	4.3	0.85	94.2	91.8242	74.2269
2014	7	22	15	37	0	0.3	4.3	0.82	93.4	91.8242	71.9253
2014	7	22	15	47	0	0.3	4.3	0.81	95.8	91.8242	70.4868
2014	7	22	15	57	0	0.3	4.3	0.83	95.9	91.8242	72.7884
2014	7	22	16	7	0	0.3	4.3	0.83	95.2	91.7585	72.7342
2014	7	22	16	17	0	0.3	4.3	0.83	94.3	91.7585	72.7342
2014	7	22	16	27	0	0.3	4.3	0.84	95	91.7585	73.0216
2014	7	22	16	37	0	0.3	4.3	0.85	95.5	91.7585	74.4591
2014	7	22	16	47	0	0.3	4.3	0.85	94.9	91.6929	73.829
2014	7	22	16	57	0	0.3	4.3	0.82	96.9	91.7585	71.2967
2014	7	22	17	7	0	0.3	4.3	0.84	95.8	91.7585	73.5966
2014	7	22	17	17	0	0.3	4.3	0.82	96.6	91.7585	71.5842
2014	7	22	17	27	0	0.3	4.3	0.84	94.7	91.7585	73.5966

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	22	17	37	0	0.3	4.3	0.84	95	91.6273	72.9128
2014	7	22	17	47	0	0.3	4.3	0.85	95.8	91.6929	74.1163
2014	7	22	17	57	0	0.3	4.3	0.83	94.5	91.6929	72.3927
2014	7	22	18	7	0	0.3	4.3	0.85	96.5	91.6929	73.5418
2014	7	22	18	17	0	0.3	4.3	0.81	95.3	91.6929	70.6691
2014	7	22	18	27	0	0.3	4.3	0.84	96	91.6929	73.5418
2014	7	22	18	37	0	0.3	4.3	0.87	96.3	91.6929	75.84
2014	7	22	18	47	0	0.3	4.3	0.81	94.4	91.6929	70.9564
2014	7	22	18	57	0	0.3	4.3	0.89	94.7	91.6273	77.2187
2014	7	22	19	7	0	0.3	4.3	0.84	96.3	91.6929	73.2546
2014	7	22	19	17	0	0.3	4.3	0.89	95.1	91.6929	77.8509
2014	7	22	19	27	0	0.3	4.3	0.89	94.7	91.6273	77.2187
2014	7	22	19	37	0	0.3	4.3	0.84	96.1	91.6929	72.9673
2014	7	22	19	47	0	0.3	4.3	0.86	95.5	91.6929	75.2655
2014	7	22	19	57	0	0.3	4.3	0.86	96.3	91.6929	75.2655
2014	7	22	20	7	0	0.3	4.3	0.89	95.1	91.6929	77.2764
2014	7	22	20	17	0	0.3	4.3	0.88	94.7	91.6929	76.7019
2014	7	22	20	27	0	0.3	4.3	0.91	93.9	91.6929	79.2873
2014	7	22	20	37	0	0.3	4.3	0.89	95.9	91.6929	77.5637
2014	7	22	20	47	0	0.3	4.3	0.86	93.3	91.6929	75.2655
2014	7	22	20	57	0	0.3	4.3	0.88	94.7	91.6929	76.7019
2014	7	22	21	7	0	0.3	4.3	0.88	94.5	91.6929	76.9892
2014	7	22	21	17	0	0.3	4.3	0.85	93.3	91.6929	74.691
2014	7	22	21	27	0	0.3	4.3	0.87	95	91.6929	76.1274
2014	7	22	21	37	0	0.3	4.3	0.89	94.2	91.6929	78.1384
2014	7	22	21	47	0	0.3	4.3	0.86	94.6	91.6929	74.9784
2014	7	22	21	57	0	0.3	4.3	0.87	95.4	91.6929	76.1275
2014	7	22	22	7	0	0.3	4.3	0.86	95.3	91.6929	74.9784
2014	7	22	22	17	0	0.3	4.3	0.87	96.5	91.6929	76.1275
2014	7	22	22	27	0	0.3	4.3	0.84	95.4	91.6929	73.2548
2014	7	22	22	37	0	0.3	4.3	0.85	93.7	91.6929	74.6912
2014	7	22	22	47	0	0.3	4.3	0.86	95.5	91.6929	74.6912
2014	7	22	22	57	0	0.3	4.3	0.86	94.6	91.6929	74.9785
2014	7	22	23	7	0	0.3	4.3	0.93	94.7	91.6929	81.0113
2014	7	22	23	17	0	0.3	4.3	0.84	94.9	91.6929	73.2549
2014	7	22	23	27	0	0.3	4.3	0.86	95.5	91.6929	75.2658
2014	7	22	23	37	0	0.3	4.3	0.84	96.7	91.6929	73.2549
2014	7	22	23	47	0	0.3	4.3	0.85	95.8	91.6929	74.1168
2014	7	22	23	57	0	0.3	4.3	0.85	96.7	91.6929	73.5422
2014	7	23	0	7	0	0.3	4.3	0.87	95.2	91.6929	75.8404
2014	7	23	0	17	0	0.3	4.3	0.86	95.9	91.6929	75.2659
2014	7	23	0	27	0	0.3	4.3	0.83	93.2	91.6929	72.3932
2014	7	23	0	37	0	0.3	4.3	0.84	94.3	91.7585	73.3097
2014	7	23	0	47	0	0.3	4.3	0.87	93.9	91.6929	75.8405
2014	7	23	0	57	0	0.3	4.3	0.88	95.3	91.7585	76.7596
2014	7	23	1	7	0	0.3	4.3	0.88	95.1	91.6929	76.9896

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	1	17	0	0.3	4.3	0.85	95.3	91.7585	73.8847
2014	7	23	1	27	0	0.3	4.3	0.85	94	91.7585	74.4597
2014	7	23	1	37	0	0.3	4.3	0.89	95.9	91.7585	77.9096
2014	7	23	1	47	0	0.3	4.3	0.88	95.2	91.7585	76.4722
2014	7	23	1	57	0	0.3	4.3	0.84	94.1	91.7585	73.0223
2014	7	23	2	7	0	0.3	4.3	0.86	94.6	91.7585	75.0348
2014	7	23	2	17	0	0.3	4.3	0.89	94.7	91.7585	77.6222
2014	7	23	2	27	0	0.3	4.3	0.9	95	91.7585	78.7722
2014	7	23	2	37	0	0.3	4.3	0.87	96.5	91.7585	75.3223
2014	7	23	2	47	0	0.3	4.3	0.85	94.7	91.7585	74.1724
2014	7	23	2	57	0	0.3	4.3	0.9	95	91.7585	78.4847
2014	7	23	3	7	0	0.3	4.3	0.89	95.1	91.7585	77.9098
2014	7	23	3	17	0	0.3	4.3	0.86	94.2	91.7585	74.7474
2014	7	23	3	27	0	0.3	4.3	0.89	97	91.7585	77.6224
2014	7	23	3	37	0	0.3	4.3	0.84	95.1	91.7585	73.5975
2014	7	23	3	47	0	0.3	4.3	0.9	96.1	91.7585	78.1974
2014	7	23	3	57	0	0.3	4.3	0.89	94	91.7585	78.1974
2014	7	23	4	7	0	0.3	4.3	0.87	94.3	91.7585	76.185
2014	7	23	4	17	0	0.3	4.3	0.91	96.6	91.7585	79.6349
2014	7	23	4	27	0	0.3	4.3	0.88	97.1	91.7585	76.4726
2014	7	23	4	37	0	0.3	4.3	0.86	95.9	91.7585	75.3226
2014	7	23	4	47	0	0.3	4.3	0.92	95.3	91.7585	80.21
2014	7	23	4	57	0	0.3	4.3	0.85	94.2	91.8242	74.228
2014	7	23	5	7	0	0.3	4.3	0.85	95.5	91.8242	74.2281
2014	7	23	5	17	0	0.3	4.3	0.89	96.8	91.8242	77.6806
2014	7	23	5	27	0	0.3	4.3	0.88	94.7	91.8242	76.5298
2014	7	23	5	37	0	0.3	4.3	0.86	95.3	91.8242	75.0913
2014	7	23	5	47	0	0.3	4.3	0.88	96	91.8242	76.8175
2014	7	23	5	57	0	0.3	4.3	0.89	95.9	91.8242	77.393
2014	7	23	6	7	0	0.3	4.3	0.9	96.9	91.9554	78.6609
2014	7	23	6	17	0	0.3	4.3	0.9	96.1	92.021	78.431
2014	7	23	6	27	0	0.3	4.3	0.87	96.1	92.021	76.1243
2014	7	23	6	37	0	0.3	4.3	0.87	92.2	92.0866	76.4695
2014	7	23	6	47	0	0.3	4.3	0.83	92.5	92.0866	73.2953
2014	7	23	6	57	0	0.3	4.3	0.88	95.1	92.0866	77.0466
2014	7	23	7	7	0	0.3	4.3	0.89	95.5	92.0866	77.6238
2014	7	23	7	17	0	0.3	4.3	0.9	96.5	92.0866	78.4895
2014	7	23	7	27	0	0.3	4.3	0.9	94	92.0866	79.3552
2014	7	23	7	37	0	0.3	4.3	0.88	95.1	92.0866	77.3353
2014	7	23	7	47	0	0.3	4.3	0.91	95.8	92.0866	79.3552
2014	7	23	7	57	0	0.3	4.3	0.89	93	92.0866	78.201
2014	7	23	8	7	0	0.3	4.3	0.87	95.6	92.1522	76.2376
2014	7	23	8	17	0	0.3	4.3	0.88	95.1	92.0866	77.3353
2014	7	23	8	27	0	0.3	4.3	0.88	95.1	92.1522	77.1039
2014	7	23	8	37	0	0.3	4.3	0.87	94.1	92.1522	76.8151
2014	7	23	8	47	0	0.3	4.3	0.89	95.7	92.1522	77.9703

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	8	57	0	0.3	4.3	0.87	93.5	92.1522	76.2376
2014	7	23	9	7	0	0.3	4.3	0.89	95.5	92.1522	77.6814
2014	7	23	9	17	0	0.3	4.3	0.92	93.5	92.1522	81.1468
2014	7	23	9	27	0	0.3	4.3	0.95	96.2	92.1522	82.8794
2014	7	23	9	37	0	0.3	4.3	0.9	94.8	92.1522	79.1253
2014	7	23	9	47	0	0.3	4.3	0.92	94.7	92.1522	80.5692
2014	7	23	9	57	0	0.3	4.3	0.86	96.3	92.1522	75.3711
2014	7	23	10	7	0	0.3	4.3	0.91	92.5	92.1522	80.2803
2014	7	23	10	17	0	0.3	4.3	0.89	94.7	92.1522	77.9701
2014	7	23	10	27	0	0.3	4.3	0.87	96.2	92.1522	76.5261
2014	7	23	10	37	0	0.3	4.3	0.89	93.8	92.1522	78.5476
2014	7	23	10	47	0	0.3	4.3	0.83	94.5	92.1522	73.0607
2014	7	23	10	57	0	0.3	4.3	0.85	97.1	92.1522	74.5046
2014	7	23	11	7	0	0.3	4.3	0.87	95.4	92.1522	75.9485
2014	7	23	11	17	0	0.3	4.3	0.85	97.1	92.1522	74.5045
2014	7	23	11	27	0	0.3	4.3	0.9	93.3	92.1522	79.1249
2014	7	23	11	37	0	0.3	4.3	0.89	95.1	92.1522	77.9698
2014	7	23	11	47	0	0.3	4.3	0.88	94.7	92.1522	77.1034
2014	7	23	11	57	0	0.3	4.3	0.88	94.1	92.1522	77.1034
2014	7	23	12	7	0	0.3	4.3	0.89	94	92.1522	77.9697
2014	7	23	12	17	0	0.3	4.3	0.87	95.2	92.021	75.8355
2014	7	23	12	27	0	0.3	4.3	0.88	94.1	92.021	77.2772
2014	7	23	12	37	0	0.3	4.3	0.9	94	92.021	79.2956
2014	7	23	12	47	0	0.3	4.3	0.86	97.9	91.9554	74.6265
2014	7	23	12	57	0	0.3	4.3	0.87	96.1	91.9554	76.0671
2014	7	23	13	7	0	0.3	4.3	0.88	96.4	91.8898	76.8742
2014	7	23	13	17	0	0.3	4.3	0.84	94.5	91.8898	73.4192
2014	7	23	13	27	0	0.3	4.3	0.91	95	91.8898	79.7533
2014	7	23	13	37	0	0.3	4.3	0.87	95.2	91.8898	76.0104
2014	7	23	13	47	0	0.3	4.3	0.89	97.2	91.8898	77.4499
2014	7	23	13	57	0	0.3	4.3	0.88	96.9	91.8898	76.2982
2014	7	23	14	7	0	0.3	4.3	0.85	94	91.8898	74.2827
2014	7	23	14	17	0	0.3	4.3	0.89	95.5	91.8898	78.0256
2014	7	23	14	27	0	0.3	4.3	0.87	94.7	91.8898	76.2981
2014	7	23	14	37	0	0.3	4.3	0.87	96.5	91.8898	76.2981
2014	7	23	14	47	0	0.3	4.3	0.87	95	91.8898	76.0101
2014	7	23	14	57	0	0.3	4.3	0.85	95.5	91.9554	74.626
2014	7	23	15	7	0	0.3	4.3	0.87	95.8	91.8898	76.298
2014	7	23	15	17	0	0.3	4.3	0.85	94.2	91.8898	74.2826
2014	7	23	15	27	0	0.3	4.3	0.83	96.1	91.8898	72.555
2014	7	23	15	37	0	0.3	4.3	0.83	97.2	91.8242	72.501
2014	7	23	15	47	0	0.3	4.3	0.86	96.8	91.8898	74.8583
2014	7	23	15	57	0	0.3	4.3	0.87	93.7	91.8242	76.2411
2014	7	23	16	7	0	0.3	4.3	0.92	93.5	91.8242	80.2689
2014	7	23	16	17	0	0.3	4.3	0.89	94.9	91.8242	77.6796
2014	7	23	16	27	0	0.3	4.3	0.85	95.5	91.8242	74.2271

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	23	16	37	0	0.3	4.3	0.85	94.9	91.8898	74.5704
2014	7	23	16	47	0	0.3	4.3	0.88	94.3	91.8242	76.8165
2014	7	23	16	57	0	0.3	4.3	0.85	95.8	91.8242	74.2271
2014	7	23	17	7	0	0.3	4.3	0.82	94.6	91.8242	71.9255
2014	7	23	17	17	0	0.3	4.3	0.87	96.1	91.8242	75.6656
2014	7	23	17	27	0	0.3	4.3	0.84	95.6	91.7585	73.0219
2014	7	23	17	37	0	0.3	4.3	0.84	95.8	91.7585	73.5969
2014	7	23	17	47	0	0.3	4.3	0.87	95	91.7585	75.6093
2014	7	23	17	57	0	0.3	4.3	0.84	96.7	91.7585	73.3094
2014	7	23	18	7	0	0.3	4.3	0.84	95.6	91.7585	73.0219
2014	7	23	18	17	0	0.3	4.3	0.89	96.3	91.7585	77.6217
2014	7	23	18	27	0	0.3	4.3	0.86	96.8	91.7585	74.7468
2014	7	23	18	37	0	0.3	4.3	0.83	96.8	91.7585	71.872
2014	7	23	18	47	0	0.3	4.3	0.86	95.7	91.7585	75.0343
2014	7	23	18	57	0	0.3	4.3	0.87	95.8	91.7585	75.8968
2014	7	23	19	7	0	0.3	4.3	0.84	95.4	91.6929	73.2548
2014	7	23	19	17	0	0.3	4.3	0.87	94.1	91.6929	75.8402
2014	7	23	19	27	0	0.3	4.3	0.83	96.4	91.7585	71.872
2014	7	23	19	37	0	0.3	4.3	0.86	94.2	91.7585	75.0343
2014	7	23	19	47	0	0.3	4.3	0.89	96.1	91.7585	77.6217
2014	7	23	19	57	0	0.3	4.3	0.87	94.3	91.7585	76.1843
2014	7	23	20	7	0	0.3	4.3	0.89	95.7	91.7585	77.6217
2014	7	23	20	17	0	0.3	4.3	0.88	95.8	91.7585	76.7593
2014	7	23	20	27	0	0.3	4.3	0.9	94.6	91.7585	78.7717
2014	7	23	20	37	0	0.3	4.3	0.87	95.4	91.7585	75.8969
2014	7	23	20	47	0	0.3	4.3	0.86	95.3	91.7585	75.0344
2014	7	23	20	57	0	0.3	4.3	0.86	94.6	91.6929	74.6912
2014	7	23	21	7	0	0.3	4.3	0.91	94.8	91.7585	79.0592
2014	7	23	21	17	0	0.3	4.3	0.86	97.2	91.7585	75.0344
2014	7	23	21	27	0	0.3	4.3	0.83	94.8	91.7585	72.1596
2014	7	23	21	37	0	0.3	4.3	0.86	93.3	91.7585	75.3219
2014	7	23	21	47	0	0.3	4.3	0.89	93.2	91.7585	77.6219
2014	7	23	21	57	0	0.3	4.3	0.82	97.3	91.6929	71.5313
2014	7	23	22	7	0	0.3	4.3	0.86	96.1	91.6929	74.9786
2014	7	23	22	17	0	0.3	4.3	0.84	95.1	91.6929	73.5422
2014	7	23	22	27	0	0.3	4.3	0.9	96.1	91.7585	78.1969
2014	7	23	22	37	0	0.3	4.3	0.86	92.2	91.7585	75.6095
2014	7	23	22	47	0	0.3	4.3	0.86	95.9	91.7585	74.7471
2014	7	23	22	57	0	0.3	4.3	0.88	95.1	91.7585	77.047
2014	7	23	23	7	0	0.3	4.3	0.89	96.8	91.7585	77.3345
2014	7	23	23	17	0	0.3	4.3	0.87	93.4	91.6929	76.4151
2014	7	23	23	27	0	0.3	4.3	0.85	94.2	91.6929	73.8296
2014	7	23	23	37	0	0.3	4.3	0.85	93.7	91.7585	74.7472
2014	7	23	23	47	0	0.3	4.3	0.84	96.1	91.6929	72.9678
2014	7	23	23	57	0	0.3	4.3	0.85	93.3	91.6929	74.6915
2014	7	24	0	7	0	0.3	4.3	0.86	95	91.7585	75.0347

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	0	17	0	0.3	4.3	0.9	95.8	91.7585	78.7721
2014	7	24	0	27	0	0.3	4.3	0.89	95.1	91.7585	77.3347
2014	7	24	0	37	0	0.3	4.3	0.83	94.5	91.7585	72.4474
2014	7	24	0	47	0	0.3	4.3	0.9	94.6	91.7585	78.1972
2014	7	24	0	57	0	0.3	4.3	0.89	92.9	91.7585	78.1972
2014	7	24	1	7	0	0.3	4.3	0.88	94.9	91.7585	77.0473
2014	7	24	1	17	0	0.3	4.3	0.9	94	91.7585	78.4847
2014	7	24	1	27	0	0.3	4.3	0.91	93.3	91.7585	79.3472
2014	7	24	1	37	0	0.3	4.3	0.89	96.2	91.7585	77.3348
2014	7	24	1	47	0	0.3	4.3	0.88	93.2	91.7585	77.0474
2014	7	24	1	57	0	0.3	4.3	0.89	96.2	91.7585	77.3349
2014	7	24	2	7	0	0.3	4.3	0.88	94.5	91.7585	76.7599
2014	7	24	2	17	0	0.3	4.3	0.9	94.4	91.7585	78.4849
2014	7	24	2	27	0	0.3	4.3	0.85	94.9	91.7585	73.8851
2014	7	24	2	37	0	0.3	4.3	0.89	94	91.7585	77.6225
2014	7	24	2	47	0	0.3	4.3	0.9	95.6	91.8242	78.5435
2014	7	24	2	57	0	0.3	4.3	0.93	92.8	91.8242	81.1329
2014	7	24	3	7	0	0.3	4.3	0.86	94.8	91.7585	74.7477
2014	7	24	3	17	0	0.3	4.3	0.85	94.9	91.8242	73.9403
2014	7	24	3	27	0	0.3	4.3	0.86	94.8	91.8242	74.8035
2014	7	24	3	37	0	0.3	4.3	0.89	95.3	91.8242	77.6805
2014	7	24	3	47	0	0.3	4.3	0.89	93	91.8242	77.9683
2014	7	24	3	57	0	0.3	4.3	0.86	93.9	91.8242	75.379
2014	7	24	4	7	0	0.3	4.3	0.9	93.5	91.8242	79.1192
2014	7	24	4	17	0	0.3	4.3	0.88	96.2	91.8242	76.5298
2014	7	24	4	27	0	0.3	4.3	0.91	96	91.8242	79.1192
2014	7	24	4	37	0	0.3	4.3	0.9	95	91.8242	78.5439
2014	7	24	4	47	0	0.3	4.3	0.87	95.6	91.8242	75.9545
2014	7	24	4	57	0	0.3	4.3	0.87	94.1	91.8898	76.2991
2014	7	24	5	7	0	0.3	4.3	0.88	95.1	91.9554	77.2203
2014	7	24	5	17	0	0.3	4.3	0.92	94.3	91.9554	80.6779
2014	7	24	5	27	0	0.3	4.3	0.9	94.2	91.9554	78.661
2014	7	24	5	37	0	0.3	4.3	0.89	94	92.021	77.8545
2014	7	24	5	47	0	0.3	4.3	0.87	94.1	92.0866	76.4696
2014	7	24	5	57	0	0.3	4.3	0.91	94.6	92.0866	79.3553
2014	7	24	6	7	0	0.3	4.3	0.85	93.5	92.0866	74.7383
2014	7	24	6	17	0	0.3	4.3	0.9	94	92.0866	79.0668
2014	7	24	6	27	0	0.3	4.3	0.86	96.8	92.0866	74.7383
2014	7	24	6	37	0	0.3	4.3	0.92	95.3	92.0866	80.5097
2014	7	24	6	47	0	0.3	4.3	0.88	95.6	92.0866	77.0469
2014	7	24	6	57	0	0.3	4.3	0.92	95.1	92.0866	80.2211
2014	7	24	7	7	0	0.3	4.3	0.89	96.3	92.0866	78.2012
2014	7	24	7	17	0	0.3	4.3	0.87	94.1	92.0866	76.4698
2014	7	24	7	27	0	0.3	4.3	0.91	95.8	92.0866	79.6441
2014	7	24	7	37	0	0.3	4.3	0.89	96.2	92.0866	77.6241
2014	7	24	7	47	0	0.3	4.3	0.89	96.2	92.1522	77.6818

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	7	57	0	0.3	4.3	0.85	94.2	92.1522	74.5052
2014	7	24	8	7	0	0.3	4.3	0.87	95.6	92.1522	76.2379
2014	7	24	8	17	0	0.3	4.3	0.89	97.4	92.1522	77.6818
2014	7	24	8	27	0	0.3	4.3	0.93	96.3	92.1522	81.4359
2014	7	24	8	37	0	0.3	4.3	0.89	95.3	92.1522	77.6818
2014	7	24	8	47	0	0.3	4.3	0.87	94.8	92.1522	76.2379
2014	7	24	8	57	0	0.3	4.3	0.91	95	92.1522	79.992
2014	7	24	9	7	0	0.3	4.3	0.86	95	92.1522	75.6603
2014	7	24	9	17	0	0.3	4.3	0.91	96	92.1522	79.4144
2014	7	24	9	27	0	0.3	4.3	0.87	95.4	92.1522	75.949
2014	7	24	9	37	0	0.3	4.3	0.88	93	92.1522	77.3929
2014	7	24	9	47	0	0.3	4.3	0.87	95.2	92.1522	76.2378
2014	7	24	9	57	0	0.3	4.3	0.9	95	92.1522	78.548
2014	7	24	10	7	0	0.3	4.3	0.87	96.5	92.1522	76.5265
2014	7	24	10	17	0	0.3	4.3	0.87	94.7	92.1522	76.5265
2014	7	24	10	27	0	0.3	4.3	0.89	95.3	92.1522	77.9703
2014	7	24	10	37	0	0.3	4.3	0.89	95.7	92.1522	78.259
2014	7	24	10	47	0	0.3	4.3	0.88	94.7	92.1522	77.3927
2014	7	24	10	57	0	0.3	4.3	0.9	95.2	92.1522	78.8365
2014	7	24	11	7	0	0.3	4.3	0.84	92.5	92.1522	73.9273
2014	7	24	11	17	0	0.3	4.3	0.83	96.1	92.1522	73.0609
2014	7	24	11	27	0	0.3	4.3	0.89	93.2	92.1522	78.2589
2014	7	24	11	37	0	0.3	4.3	0.88	95.8	92.1522	76.8149
2014	7	24	11	47	0	0.3	4.3	0.89	94	92.1522	78.2588
2014	7	24	11	57	0	0.3	4.3	0.88	94.1	92.1522	77.3924
2014	7	24	12	7	0	0.3	4.3	0.88	97.3	92.1522	76.526
2014	7	24	12	17	0	0.3	4.3	0.9	95.9	92.1522	78.5475
2014	7	24	12	27	0	0.3	4.3	0.9	96.1	92.0866	78.4891
2014	7	24	12	37	0	0.3	4.3	0.81	95.8	92.1522	70.7504
2014	7	24	12	47	0	0.3	4.3	0.92	96.9	91.9554	80.3894
2014	7	24	12	57	0	0.3	4.3	0.81	98.2	91.9554	70.0166
2014	7	24	13	7	0	0.3	4.3	32767	0	92.021	85.6394
2014	7	24	13	17	0	0.3	4.3	0.88	94.7	91.8898	77.1623
2014	7	24	13	27	0	0.3	4.3	0.83	94.7	92.021	72.9519
2014	7	24	13	37	0	0.3	4.3	0.83	95.4	91.8898	72.8434
2014	7	24	13	47	0	0.3	4.3	0.85	95.5	91.8898	74.283
2014	7	24	13	57	0	0.3	4.3	0.85	95.1	91.8898	74.5709
2014	7	24	14	7	0	0.3	4.3	0.84	96.1	91.8898	73.1312
2014	7	24	14	17	0	0.3	4.3	0.86	95.2	91.8898	75.4346
2014	7	24	14	27	0	0.3	4.3	0.9	93.8	91.8898	78.8895
2014	7	24	14	37	0	0.3	4.3	0.84	95.8	91.8242	73.6521
2014	7	24	14	47	0	0.3	4.3	0.82	97.5	91.8242	71.6382
2014	7	24	14	57	0	0.3	4.3	0.86	95.2	91.8242	75.3783
2014	7	24	15	7	0	0.3	4.3	0.84	95.2	91.8242	73.0766
2014	7	24	15	17	0	0.3	4.3	0.84	96.2	91.8242	73.652
2014	7	24	15	27	0	0.3	4.3	0.83	95.4	91.8242	72.5012

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	15	37	0	0.3	4.3	0.83	95.7	91.8242	72.5012
2014	7	24	15	47	0	0.3	4.3	0.84	93.8	91.8242	73.3643
2014	7	24	15	57	0	0.3	4.3	0.83	95.6	91.8242	72.7888
2014	7	24	16	7	0	0.3	4.3	0.81	93	91.8898	71.4035
2014	7	24	16	17	0	0.3	4.3	0.82	94.8	91.8242	71.3503
2014	7	24	16	27	0	0.3	4.3	0.85	94.7	91.8242	74.2274
2014	7	24	16	37	0	0.3	4.3	0.8	94.5	91.7585	69.5722
2014	7	24	16	47	0	0.3	4.3	0.82	94.8	91.7585	71.8721
2014	7	24	16	57	0	0.3	4.3	0.85	95.3	91.7585	73.8845
2014	7	24	17	7	0	0.3	4.3	0.81	94.2	91.7585	70.7222
2014	7	24	17	17	0	0.3	4.3	0.84	93.8	91.7585	73.0221
2014	7	24	17	27	0	0.3	4.3	0.84	94.7	91.7585	73.5971
2014	7	24	17	37	0	0.3	4.3	0.81	95.3	91.7585	70.7222
2014	7	24	17	47	0	0.3	4.3	0.82	94.3	91.7585	71.8721
2014	7	24	17	57	0	0.3	4.3	0.83	95.7	91.7585	72.4471
2014	7	24	18	7	0	0.3	4.3	0.85	95.3	91.6929	74.404
2014	7	24	18	17	0	0.3	4.3	0.82	94.4	91.6929	71.5313
2014	7	24	18	27	0	0.3	4.3	0.87	95.2	91.6929	75.5531
2014	7	24	18	37	0	0.3	4.3	0.85	94.9	91.6929	74.404
2014	7	24	18	47	0	0.3	4.3	0.84	95.6	91.6929	73.5422
2014	7	24	18	57	0	0.3	4.3	0.85	93.8	91.6929	74.404
2014	7	24	19	7	0	0.3	4.3	0.84	94.7	91.6929	72.9677
2014	7	24	19	17	0	0.3	4.3	0.86	94.4	91.6929	74.6913
2014	7	24	19	27	0	0.3	4.3	0.89	96.4	91.6929	77.2768
2014	7	24	19	37	0	0.3	4.3	0.84	94.9	91.6929	73.255
2014	7	24	19	47	0	0.3	4.3	0.85	94.4	91.6929	73.8295
2014	7	24	19	57	0	0.3	4.3	0.83	94.3	91.6929	72.6804
2014	7	24	20	7	0	0.3	4.3	0.85	95.3	91.6929	73.8295
2014	7	24	20	17	0	0.3	4.3	0.85	94.2	91.6929	73.8295
2014	7	24	20	27	0	0.3	4.3	0.81	93.2	91.6929	70.9568
2014	7	24	20	37	0	0.3	4.3	0.85	92.6	91.6929	74.6914
2014	7	24	20	47	0	0.3	4.3	0.88	95.1	91.6929	76.9896
2014	7	24	20	57	0	0.3	4.3	0.87	93.2	91.6929	76.1278
2014	7	24	21	7	0	0.3	4.3	0.85	92.4	91.6929	74.1169
2014	7	24	21	17	0	0.3	4.3	0.87	96.2	91.6929	76.1278
2014	7	24	21	27	0	0.3	4.3	0.87	95.4	91.6929	76.1278
2014	7	24	21	37	0	0.3	4.3	0.92	95.1	91.6929	80.1497
2014	7	24	21	47	0	0.3	4.3	0.9	94.2	91.6929	79.0006
2014	7	24	21	57	0	0.3	4.3	0.84	95.6	91.6929	72.9678
2014	7	24	22	7	0	0.3	4.3	0.86	95.5	91.6929	74.6915
2014	7	24	22	17	0	0.3	4.3	0.86	95.5	91.6929	75.2661
2014	7	24	22	27	0	0.3	4.3	0.86	92.9	91.6929	74.9788
2014	7	24	22	37	0	0.3	4.3	0.88	94	91.6929	77.277
2014	7	24	22	47	0	0.3	4.3	0.8	96.1	91.6929	69.8079
2014	7	24	22	57	0	0.3	4.3	0.89	95.7	91.6929	77.5643
2014	7	24	23	7	0	0.3	4.3	0.85	94.2	91.6929	74.4043

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	24	23	17	0	0.3	4.3	0.85	96.2	91.6929	74.4044
2014	7	24	23	27	0	0.3	4.3	0.83	95.6	91.6929	72.6807
2014	7	24	23	37	0	0.3	4.3	0.8	97.1	91.6929	69.5207
2014	7	24	23	47	0	0.3	4.3	0.85	94.2	91.6929	73.8298
2014	7	24	23	57	0	0.3	4.3	0.85	94.4	91.6929	73.8299
2014	7	25	0	7	0	0.3	4.3	0.84	94	91.6929	73.5426
2014	7	25	0	17	0	0.3	4.3	0.85	96.9	91.6929	74.1172
2014	7	25	0	27	0	0.3	4.3	0.89	94.2	91.6929	77.5645
2014	7	25	0	37	0	0.3	4.3	0.85	94.2	91.6929	74.4045
2014	7	25	0	47	0	0.3	4.3	0.86	95.5	91.6929	74.6918
2014	7	25	0	57	0	0.3	4.3	0.89	95.9	91.6929	77.8518
2014	7	25	1	7	0	0.3	4.3	0.9	95	91.6929	78.1392
2014	7	25	1	17	0	0.3	4.3	0.83	92.9	91.6929	72.9682
2014	7	25	1	27	0	0.3	4.3	0.86	92.2	91.6929	75.5537
2014	7	25	1	37	0	0.3	4.3	0.86	93.7	91.6929	75.2664
2014	7	25	1	47	0	0.3	4.3	0.87	97.3	91.6929	75.841
2014	7	25	1	57	0	0.3	4.3	0.83	95.4	91.6929	72.681
2014	7	25	2	7	0	0.3	4.3	0.85	94.2	91.6929	74.4047
2014	7	25	2	17	0	0.3	4.3	0.86	94.2	91.6929	74.6919
2014	7	25	2	27	0	0.3	4.3	0.85	95.7	91.6929	74.4047
2014	7	25	2	37	0	0.3	4.3	0.84	96.5	91.6929	73.2556
2014	7	25	2	47	0	0.3	4.3	0.82	96.2	91.6929	71.2447
2014	7	25	2	57	0	0.3	4.3	0.89	98.3	91.6929	76.9902
2014	7	25	3	7	0	0.3	4.3	0.85	96	91.6929	73.8302
2014	7	25	3	17	0	0.3	4.3	0.87	94.8	91.6929	75.5539
2014	7	25	3	27	0	0.3	4.3	0.87	95.4	91.6929	75.5539
2014	7	25	3	37	0	0.3	4.3	0.85	94.7	91.6929	73.8303
2014	7	25	3	47	0	0.3	4.3	0.88	95.3	91.6929	76.9903
2014	7	25	3	57	0	0.3	4.3	0.88	95.2	91.6929	76.4158
2014	7	25	4	7	0	0.3	4.3	0.86	93.7	91.7585	75.6104
2014	7	25	4	17	0	0.3	4.3	0.87	93.5	91.7585	75.8979
2014	7	25	4	27	0	0.3	4.3	0.85	94.2	91.6929	74.405
2014	7	25	4	37	0	0.3	4.3	0.87	94.1	91.7585	76.1854
2014	7	25	4	47	0	0.3	4.3	0.88	95.3	91.7585	77.048
2014	7	25	4	57	0	0.3	4.3	0.87	95	91.7585	76.1855
2014	7	25	5	7	0	0.3	4.3	0.86	96.4	91.7585	74.7481
2014	7	25	5	17	0	0.3	4.3	0.87	96.5	91.7585	76.1856
2014	7	25	5	27	0	0.3	4.3	0.83	95.2	91.7585	72.4482
2014	7	25	5	37	0	0.3	4.3	0.89	97	91.7585	77.6231
2014	7	25	5	47	0	0.3	4.3	0.83	94.3	91.7585	72.7357
2014	7	25	5	57	0	0.3	4.3	0.87	96.2	91.7585	76.1857
2014	7	25	6	7	0	0.3	4.3	0.87	94.1	91.7585	75.8982
2014	7	25	6	17	0	0.3	4.3	0.89	94	91.8242	77.6811
2014	7	25	6	27	0	0.3	4.3	0.89	95.3	91.8898	77.739
2014	7	25	6	37	0	0.3	4.3	0.9	93.3	91.9554	79.2376
2014	7	25	6	47	0	0.3	4.3	0.87	92.6	91.9554	76.6444

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	6	57	0	0.3	4.3	0.87	95.2	92.021	76.1247
2014	7	25	7	7	0	0.3	4.3	0.83	93.6	92.021	72.6645
2014	7	25	7	17	0	0.3	4.3	0.88	94.7	92.021	77.2781
2014	7	25	7	27	0	0.3	4.3	0.88	95.8	92.021	76.7014
2014	7	25	7	37	0	0.3	4.3	0.9	96.7	92.021	78.1432
2014	7	25	7	47	0	0.3	4.3	0.86	95.3	92.021	74.9713
2014	7	25	7	57	0	0.3	4.3	0.85	95.7	92.021	74.683
2014	7	25	8	7	0	0.3	4.3	0.86	95	92.021	75.548
2014	7	25	8	17	0	0.3	4.3	0.89	96.4	92.021	77.5665
2014	7	25	8	27	0	0.3	4.3	0.88	92.8	92.021	76.9898
2014	7	25	8	37	0	0.3	4.3	0.88	94.9	92.021	76.9898
2014	7	25	8	47	0	0.3	4.3	0.89	94.9	92.021	77.8548
2014	7	25	8	57	0	0.3	4.3	0.87	96.3	92.021	76.1247
2014	7	25	9	7	0	0.3	4.3	0.86	96.1	92.021	74.9713
2014	7	25	9	17	0	0.3	4.3	0.87	92.8	92.021	76.413
2014	7	25	9	27	0	0.3	4.3	0.9	95	92.021	79.0081
2014	7	25	9	37	0	0.3	4.3	0.88	94.7	92.021	77.278
2014	7	25	9	47	0	0.3	4.3	0.89	95.5	92.021	77.5663
2014	7	25	9	57	0	0.3	4.3	0.9	94.4	92.021	78.4313
2014	7	25	10	7	0	0.3	4.3	0.88	95.2	92.021	76.7012
2014	7	25	10	17	0	0.3	4.3	0.85	96.5	92.021	73.8177
2014	7	25	10	27	0	0.3	4.3	0.83	95.2	92.021	72.6642
2014	7	25	10	37	0	0.3	4.3	0.87	96	92.021	76.4128
2014	7	25	10	47	0	0.3	4.3	0.89	94.7	92.021	77.8545
2014	7	25	10	57	0	0.3	4.3	0.89	94.9	91.8898	78.0266
2014	7	25	11	7	0	0.3	4.3	0.88	94.9	91.8898	76.8749
2014	7	25	11	17	0	0.3	4.3	0.88	96	91.8898	76.8749
2014	7	25	11	27	0	0.3	4.3	0.87	95.2	91.8242	75.6668
2014	7	25	11	37	0	0.3	4.3	0.85	96	91.8242	74.2282
2014	7	25	11	47	0	0.3	4.3	0.85	96.2	91.8242	74.5159
2014	7	25	11	57	0	0.3	4.3	0.88	94.3	91.8242	76.5298
2014	7	25	12	7	0	0.3	4.3	0.88	96.2	91.8242	76.8175
2014	7	25	12	17	0	0.3	4.3	0.85	94.6	91.7585	74.4602
2014	7	25	12	27	0	0.3	4.3	0.82	97.6	91.7585	71.0103
2014	7	25	12	37	0	0.3	4.3	0.85	96	91.7585	73.8852
2014	7	25	12	47	0	0.3	4.3	0.86	94.8	91.8242	75.3788
2014	7	25	12	57	0	0.3	4.3	0.84	95.1	91.7585	73.5976
2014	7	25	13	7	0	0.3	4.3	0.86	95.7	91.7585	75.3225
2014	7	25	13	17	0	0.3	4.3	0.86	95.7	91.7585	75.035
2014	7	25	13	27	0	0.3	4.3	0.86	95.7	91.7585	75.3224
2014	7	25	13	37	0	0.3	4.3	0.88	94.3	91.7585	76.7599
2014	7	25	13	47	0	0.3	4.3	0.83	95	91.7585	72.735
2014	7	25	13	57	0	0.3	4.3	0.88	94.1	91.7585	76.7598
2014	7	25	14	7	0	0.3	4.3	0.86	94.4	91.6929	75.2662
2014	7	25	14	17	0	0.3	4.3	0.89	96.2	91.6929	77.2771
2014	7	25	14	27	0	0.3	4.3	0.88	92.8	91.6929	76.9897

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	14	37	0	0.3	4.3	0.85	94.9	91.6929	73.8297
2014	7	25	14	47	0	0.3	4.3	0.91	96.6	91.6929	79.5752
2014	7	25	14	57	0	0.3	4.3	0.87	95.2	91.6929	75.8406
2014	7	25	15	7	0	0.3	4.3	0.87	94.1	91.6929	75.8405
2014	7	25	15	17	0	0.3	4.3	0.87	92.8	91.6929	75.8405
2014	7	25	15	27	0	0.3	4.3	0.87	93.2	91.6929	76.1278
2014	7	25	15	37	0	0.3	4.3	0.85	96.2	91.6929	74.4041
2014	7	25	15	47	0	0.3	4.3	0.84	95.2	91.6929	72.9677
2014	7	25	15	57	0	0.3	4.3	0.88	93.6	91.6929	76.7023
2014	7	25	16	7	0	0.3	4.3	0.87	93.2	91.6273	76.358
2014	7	25	16	17	0	0.3	4.3	0.89	94.9	91.6273	77.2191
2014	7	25	16	27	0	0.3	4.3	0.87	95.2	91.6273	75.4968
2014	7	25	16	37	0	0.3	4.3	0.9	92.7	91.4961	78.2504
2014	7	25	16	47	0	0.3	4.3	0.9	94	91.4961	78.2504
2014	7	25	16	57	0	0.3	4.3	0.89	93.4	91.4961	77.6771
2014	7	25	17	7	0	0.3	4.3	0.85	94	91.5617	74.293
2014	7	25	17	17	0	0.3	4.3	0.81	92.6	91.4961	70.5113
2014	7	25	17	27	0	0.3	4.3	0.85	92.9	91.5617	74.293
2014	7	25	17	37	0	0.3	4.3	0.87	93.9	91.4305	75.9005
2014	7	25	17	47	0	0.3	4.3	0.87	95.2	91.5617	75.7273
2014	7	25	17	57	0	0.3	4.3	0.87	94.8	91.5617	75.7273
2014	7	25	18	7	0	0.3	4.3	0.91	95	91.4961	79.1103
2014	7	25	18	17	0	0.3	4.3	0.88	94.5	91.4961	76.244
2014	7	25	18	27	0	0.3	4.3	0.88	93.8	91.4961	76.8172
2014	7	25	18	37	0	0.3	4.3	0.82	93.4	91.4961	71.6579
2014	7	25	18	47	0	0.3	4.3	0.89	94.2	91.4961	77.3905
2014	7	25	18	57	0	0.3	4.3	0.91	95.4	91.4305	79.0511
2014	7	25	19	7	0	0.3	4.3	0.9	96.7	91.4961	78.2504
2014	7	25	19	17	0	0.3	4.3	0.85	94.2	91.4961	74.2376
2014	7	25	19	27	0	0.3	4.3	0.89	94.4	91.4961	77.6771
2014	7	25	19	37	0	0.3	4.3	0.88	95.6	91.4961	76.244
2014	7	25	19	47	0	0.3	4.3	0.86	94.8	91.4961	75.0975
2014	7	25	19	57	0	0.3	4.3	0.87	94.7	91.4961	75.9574
2014	7	25	20	7	0	0.3	4.3	0.88	93.6	91.4961	77.1039
2014	7	25	20	17	0	0.3	4.3	0.83	93.2	91.4961	72.2312
2014	7	25	20	27	0	0.3	4.3	0.87	95.6	91.4961	75.6708
2014	7	25	20	37	0	0.3	4.3	0.86	94.8	91.4961	74.5243
2014	7	25	20	47	0	0.3	4.3	0.89	95.7	91.4961	77.3906
2014	7	25	20	57	0	0.3	4.3	0.92	94.7	91.4961	79.6836
2014	7	25	21	7	0	0.3	4.3	0.85	94.2	91.4961	74.2377
2014	7	25	21	17	0	0.3	4.3	0.88	93.8	91.4961	76.8174
2014	7	25	21	27	0	0.3	4.3	0.9	94.8	91.4961	78.2505
2014	7	25	21	37	0	0.3	4.3	0.87	95	91.4961	75.3842
2014	7	25	21	47	0	0.3	4.3	0.82	93.2	91.4961	71.658
2014	7	25	21	57	0	0.3	4.3	0.9	95.4	91.5617	78.3091
2014	7	25	22	7	0	0.3	4.3	0.83	93.2	91.4961	72.8046

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	25	22	17	0	0.3	4.3	0.84	95.6	91.4961	73.0912
2014	7	25	22	27	0	0.3	4.3	0.87	95.2	91.5617	76.0144
2014	7	25	22	37	0	0.3	4.3	0.89	92.9	91.4961	77.964
2014	7	25	22	47	0	0.3	4.3	0.83	95	91.5617	72.5722
2014	7	25	22	57	0	0.3	4.3	0.88	94	91.4961	77.1041
2014	7	25	23	7	0	0.3	4.3	0.93	96.5	91.5617	80.8908
2014	7	25	23	17	0	0.3	4.3	0.86	95.9	91.5617	74.5802
2014	7	25	23	27	0	0.3	4.3	0.87	95.9	91.5617	75.4408
2014	7	25	23	37	0	0.3	4.3	0.88	94.1	91.5617	76.8751
2014	7	25	23	47	0	0.3	4.3	0.84	95.8	91.5617	72.8592
2014	7	25	23	57	0	0.3	4.3	0.91	93.5	91.5617	79.4567
2014	7	26	0	7	0	0.3	4.3	0.83	92.7	91.5617	72.2856
2014	7	26	0	17	0	0.3	4.3	0.86	94.2	91.5617	74.5804
2014	7	26	0	27	0	0.3	4.3	0.88	95.1	91.5617	76.8752
2014	7	26	0	37	0	0.3	4.3	0.9	95.5	91.5617	78.0226
2014	7	26	0	47	0	0.3	4.3	0.88	95.6	91.5617	76.3015
2014	7	26	0	57	0	0.3	4.3	0.85	95.6	91.5617	73.7199
2014	7	26	1	7	0	0.3	4.3	0.85	94	91.5617	73.72
2014	7	26	1	17	0	0.3	4.3	0.83	94.8	91.5617	72.2858
2014	7	26	1	27	0	0.3	4.3	0.88	93.6	91.5617	76.8754
2014	7	26	1	37	0	0.3	4.3	0.93	96.7	91.5617	80.8912
2014	7	26	1	47	0	0.3	4.3	0.9	95.4	91.5617	78.5965
2014	7	26	1	57	0	0.3	4.3	0.85	93.3	91.6273	74.6363
2014	7	26	2	7	0	0.3	4.3	0.87	94.1	91.5617	76.3018
2014	7	26	2	17	0	0.3	4.3	0.89	94.6	91.6273	77.7941
2014	7	26	2	27	0	0.3	4.3	0.91	93.9	91.6273	79.2294
2014	7	26	2	37	0	0.3	4.3	0.92	95.9	91.6273	80.0907
2014	7	26	2	47	0	0.3	4.3	0.92	94.7	91.6273	80.0907
2014	7	26	2	57	0	0.3	4.3	0.85	94.4	91.6273	74.0624
2014	7	26	3	7	0	0.3	4.3	0.9	92.9	91.6273	78.9425
2014	7	26	3	17	0	0.3	4.3	0.85	95.3	91.6273	74.3495
2014	7	26	3	27	0	0.3	4.3	0.87	98.4	91.6929	75.5542
2014	7	26	3	37	0	0.3	4.3	0.89	93.6	91.6929	77.5651
2014	7	26	3	47	0	0.3	4.3	0.89	95.5	91.6929	77.2779
2014	7	26	3	57	0	0.3	4.3	0.93	93.2	91.7585	81.073
2014	7	26	4	7	0	0.3	4.3	0.84	96	91.7585	73.3107
2014	7	26	4	17	0	0.3	4.3	0.84	94.3	91.7585	73.0232
2014	7	26	4	27	0	0.3	4.3	0.84	93.1	91.9554	73.7628
2014	7	26	4	37	0	0.3	4.3	0.86	96.4	92.021	74.9711
2014	7	26	4	47	0	0.3	4.3	0.9	95.6	92.021	79.0081
2014	7	26	4	57	0	0.3	4.3	0.92	92.9	92.0866	80.5097
2014	7	26	5	7	0	0.3	4.3	0.87	93.2	92.1522	76.8154
2014	7	26	5	17	0	0.3	4.3	0.9	94.8	92.1522	78.548
2014	7	26	5	27	0	0.3	4.3	0.87	97.4	92.1522	75.9491
2014	7	26	5	37	0	0.3	4.3	0.94	94.6	92.2179	82.3633
2014	7	26	5	47	0	0.3	4.3	0.88	95.2	92.2179	76.8725

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	5	57	0	0.3	4.3	0.87	96.3	92.2179	76.2945
2014	7	26	6	7	0	0.3	4.3	0.89	95.9	92.2179	77.7395
2014	7	26	6	17	0	0.3	4.3	0.9	95.9	92.2835	78.6648
2014	7	26	6	27	0	0.3	4.3	0.9	95	92.2835	78.954
2014	7	26	6	37	0	0.3	4.3	0.87	93.9	92.2835	76.3512
2014	7	26	6	47	0	0.3	4.3	0.93	95	92.3491	81.9069
2014	7	26	6	57	0	0.3	4.3	0.89	95.1	92.3491	78.1444
2014	7	26	7	7	0	0.3	4.3	0.88	97.7	92.3491	76.6973
2014	7	26	7	17	0	0.3	4.3	0.92	94.7	92.4147	81.3883
2014	7	26	7	27	0	0.3	4.3	0.91	93.7	92.4147	80.5194
2014	7	26	7	37	0	0.3	4.3	0.89	95.1	92.5459	78.6081
2014	7	26	7	47	0	0.3	4.3	0.87	96.7	92.6772	76.4003
2014	7	26	7	57	0	0.3	4.3	0.9	94.2	92.7428	79.3638
2014	7	26	8	7	0	0.3	4.3	0.9	95.2	92.8084	79.4223
2014	7	26	8	17	0	0.3	4.3	0.93	95.7	92.8084	82.0406
2014	7	26	8	27	0	0.3	4.3	0.88	96.2	92.874	77.734
2014	7	26	8	37	0	0.3	4.3	0.92	94.7	92.874	80.9365
2014	7	26	8	47	0	0.3	4.3	0.9	95	92.9396	79.8307
2014	7	26	8	57	0	0.3	4.3	0.87	96	92.9396	77.2085
2014	7	26	9	7	0	0.3	4.3	0.87	94.8	92.9396	76.6258
2014	7	26	9	17	0	0.3	4.3	0.92	96.3	93.0053	81.6388
2014	7	26	9	27	0	0.3	4.3	0.91	95.8	93.0053	80.4725
2014	7	26	9	37	0	0.3	4.3	0.91	95.8	93.0053	80.4725
2014	7	26	9	47	0	0.3	4.3	0.91	96.8	93.0709	80.2398
2014	7	26	9	57	0	0.3	4.3	0.93	95	93.0709	82.574
2014	7	26	10	7	0	0.3	4.3	0.88	95.8	93.0709	78.1973
2014	7	26	10	17	0	0.3	4.3	0.87	95.9	93.1365	76.7947
2014	7	26	10	27	0	0.3	4.3	0.88	96	93.1365	77.9627
2014	7	26	10	37	0	0.3	4.3	0.9	94.4	93.2021	80.0654
2014	7	26	10	47	0	0.3	4.3	0.9	96.5	93.2021	79.4809
2014	7	26	10	57	0	0.3	4.3	0.93	96.1	93.2021	82.1108
2014	7	26	11	7	0	0.3	4.3	0.89	93.2	93.2677	78.9543
2014	7	26	11	17	0	0.3	4.3	0.89	94.4	93.2677	78.9543
2014	7	26	11	27	0	0.3	4.3	0.86	96.8	93.3333	75.7932
2014	7	26	11	37	0	0.3	4.3	0.94	94.8	93.3989	83.1699
2014	7	26	11	47	0	0.3	4.3	0.89	93.4	93.4646	79.714
2014	7	26	11	57	0	0.3	4.3	0.87	93.4	93.5958	78.0696
2014	7	26	12	7	0	0.3	4.3	0.86	93.5	93.5958	76.8956
2014	7	26	12	17	0	0.3	4.3	0.91	96.4	93.6614	80.77
2014	7	26	12	27	0	0.3	4.3	0.93	94	93.6614	83.1196
2014	7	26	12	37	0	0.3	4.3	0.85	95.1	93.727	75.5382
2014	7	26	12	47	0	0.3	4.3	0.92	95.9	93.727	82.2984
2014	7	26	12	57	0	0.3	4.3	0.88	95.8	93.727	78.7713
2014	7	26	13	7	0	0.3	4.3	0.88	94.9	93.727	78.4774
2014	7	26	13	17	0	0.3	4.3	0.88	95.2	93.7927	78.2404
2014	7	26	13	27	0	0.3	4.3	0.89	96.1	93.7927	79.4169

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	13	37	0	0.3	4.3	0.91	97.5	93.7927	80.5934
2014	7	26	13	47	0	0.3	4.3	0.92	95.9	93.8583	82.1239
2014	7	26	13	57	0	0.3	4.3	0.87	95.2	93.8583	77.4143
2014	7	26	14	7	0	0.3	4.3	0.9	95.5	93.8583	80.0634
2014	7	26	14	17	0	0.3	4.3	0.88	95.8	93.8583	78.5917
2014	7	26	14	27	0	0.3	4.3	0.84	96.3	93.8583	74.7651
2014	7	26	14	37	0	0.3	4.3	0.88	93	93.9239	78.6489
2014	7	26	14	47	0	0.3	4.3	0.85	94.4	93.9239	75.9977
2014	7	26	14	57	0	0.3	4.3	0.86	93.9	93.9239	77.4706
2014	7	26	15	7	0	0.3	4.3	0.86	95.5	93.9239	76.5868
2014	7	26	15	17	0	0.3	4.3	0.87	94.1	93.9239	77.4705
2014	7	26	15	27	0	0.3	4.3	0.93	94.7	93.9239	83.0672
2014	7	26	15	37	0	0.3	4.3	0.87	95.2	93.9239	77.765
2014	7	26	15	47	0	0.3	4.3	0.88	94.7	93.9239	78.9432
2014	7	26	15	57	0	0.3	4.3	0.9	94.2	93.9895	80.4746
2014	7	26	16	7	0	0.3	4.3	0.93	94.9	93.9895	83.1276
2014	7	26	16	17	0	0.3	4.3	0.88	95.2	93.9895	78.4111
2014	7	26	16	27	0	0.3	4.3	0.87	94.3	93.9895	78.1163
2014	7	26	16	37	0	0.3	4.3	0.89	95.9	93.9895	79.2954
2014	7	26	16	47	0	0.3	4.3	0.83	93.4	94.0551	74.3382
2014	7	26	16	57	0	0.3	4.3	0.85	97.7	94.0551	76.1082
2014	7	26	17	7	0	0.3	4.3	0.88	94.3	93.9895	79.0007
2014	7	26	17	17	0	0.3	4.3	0.88	96	94.0551	78.4681
2014	7	26	17	27	0	0.3	4.3	0.86	95.5	94.0551	76.6982
2014	7	26	17	37	0	0.3	4.3	0.87	96.3	94.0551	77.8782
2014	7	26	17	47	0	0.3	4.3	0.86	95.2	94.0551	77.2882
2014	7	26	17	57	0	0.3	4.3	0.89	96.6	94.0551	79.0581
2014	7	26	18	7	0	0.3	4.3	0.87	96.3	94.0551	77.5832
2014	7	26	18	17	0	0.3	4.3	0.9	94.4	94.0551	80.5331
2014	7	26	18	27	0	0.3	4.3	0.89	93.6	94.0551	80.2381
2014	7	26	18	37	0	0.3	4.3	0.87	95.4	94.0551	77.5832
2014	7	26	18	47	0	0.3	4.3	0.89	94.2	94.1207	79.706
2014	7	26	18	57	0	0.3	4.3	0.85	95.3	94.1207	75.8683
2014	7	26	19	7	0	0.3	4.3	0.88	93.6	94.1207	78.8204
2014	7	26	19	17	0	0.3	4.3	0.88	93.6	94.1207	79.1156
2014	7	26	19	27	0	0.3	4.3	0.86	93.7	94.1864	77.4006
2014	7	26	19	37	0	0.3	4.3	0.85	92.6	94.1864	76.8097
2014	7	26	19	47	0	0.3	4.3	0.92	94.7	94.1864	82.1273
2014	7	26	19	57	0	0.3	4.3	0.9	92.9	94.1864	80.9456
2014	7	26	20	7	0	0.3	4.3	0.9	95.7	94.1864	80.3548
2014	7	26	20	17	0	0.3	4.3	0.87	94.1	94.1864	78.5823
2014	7	26	20	27	0	0.3	4.3	0.9	95.9	94.252	80.7088
2014	7	26	20	37	0	0.3	4.3	0.86	94.8	94.252	77.4568
2014	7	26	20	47	0	0.3	4.3	0.88	93.6	94.252	79.2306
2014	7	26	20	57	0	0.3	4.3	0.87	95.2	94.3176	78.1047
2014	7	26	21	7	0	0.3	4.3	0.89	94	94.3832	79.9377

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	26	21	17	0	0.3	4.3	0.84	92.5	94.3832	75.7928
2014	7	26	21	27	0	0.3	4.3	0.86	93	94.3832	77.8653
2014	7	26	21	37	0	0.3	4.3	0.87	94.1	94.3832	77.8653
2014	7	26	21	47	0	0.3	4.3	0.88	94.9	94.4488	79.1068
2014	7	26	21	57	0	0.3	4.3	0.89	93	94.4488	79.9957
2014	7	26	22	7	0	0.3	4.3	0.9	95	94.5144	80.6466
2014	7	26	22	17	0	0.3	4.3	0.86	95	94.5144	77.6816
2014	7	26	22	27	0	0.3	4.3	0.88	92.1	94.5144	79.1641
2014	7	26	22	37	0	0.3	4.3	0.85	92.9	94.5144	76.7922
2014	7	26	22	47	0	0.3	4.3	0.85	92.4	94.58	76.8477
2014	7	26	22	57	0	0.3	4.3	0.9	93.3	94.58	81.2984
2014	7	26	23	7	0	0.3	4.3	0.89	94	94.58	80.705
2014	7	26	23	17	0	0.3	4.3	0.86	94.1	94.58	77.7379
2014	7	26	23	27	0	0.3	4.3	0.84	92.7	94.58	75.6609
2014	7	26	23	37	0	0.3	4.3	0.84	93.1	94.58	75.6609
2014	7	26	23	47	0	0.3	4.3	0.87	94.5	94.5144	78.2747
2014	7	26	23	57	0	0.3	4.3	0.89	94.4	94.58	80.4083
2014	7	27	0	7	0	0.3	4.3	0.86	92.8	94.58	78.0346
2014	7	27	0	17	0	0.3	4.3	0.9	94.4	94.58	81.2985
2014	7	27	0	27	0	0.3	4.3	0.88	94	94.58	79.8149
2014	7	27	0	37	0	0.3	4.3	0.91	94.5	94.58	82.4853
2014	7	27	0	47	0	0.3	4.3	0.86	92.2	94.58	77.738
2014	7	27	0	57	0	0.3	4.3	0.93	93.9	94.58	83.6722
2014	7	27	1	7	0	0.3	4.3	0.86	94.6	94.58	77.4413
2014	7	27	1	17	0	0.3	4.3	0.89	92.3	94.5144	80.3503
2014	7	27	1	27	0	0.3	4.3	0.9	95.2	94.5144	80.9433
2014	7	27	1	37	0	0.3	4.3	0.94	95.6	94.5144	84.2048
2014	7	27	1	47	0	0.3	4.3	0.91	93.7	94.5144	82.1293
2014	7	27	1	57	0	0.3	4.3	0.89	95.1	94.5144	79.7574
2014	7	27	2	7	0	0.3	4.3	0.89	94.2	94.5144	80.3504
2014	7	27	2	17	0	0.3	4.3	0.89	93.2	94.5144	80.0539
2014	7	27	2	27	0	0.3	4.3	0.88	94.9	94.5144	78.8679
2014	7	27	2	37	0	0.3	4.3	0.88	93.2	94.5144	79.461
2014	7	27	2	47	0	0.3	4.3	0.92	93.7	94.5144	82.7224
2014	7	27	2	57	0	0.3	4.3	0.89	96.3	94.5144	80.3505
2014	7	27	3	7	0	0.3	4.3	0.88	95.8	94.4488	78.811
2014	7	27	3	17	0	0.3	4.3	0.91	94.4	94.4488	81.7738
2014	7	27	3	27	0	0.3	4.3	0.91	94.6	94.4488	81.7738
2014	7	27	3	37	0	0.3	4.3	0.86	94.6	94.4488	77.6259
2014	7	27	3	47	0	0.3	4.3	0.87	93.9	94.4488	78.8111
2014	7	27	3	57	0	0.3	4.3	0.89	94.5	94.4488	79.6999
2014	7	27	4	7	0	0.3	4.3	0.91	96.6	94.4488	81.4776
2014	7	27	4	17	0	0.3	4.3	0.87	94.1	94.3832	77.8659
2014	7	27	4	27	0	0.3	4.3	0.85	95.3	94.4488	76.4409
2014	7	27	4	37	0	0.3	4.3	0.89	95.1	94.3832	79.9384
2014	7	27	4	47	0	0.3	4.3	0.89	94	94.3832	79.9384

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	4	57	0	0.3	4.3	0.9	95	94.3832	81.1227
2014	7	27	5	7	0	0.3	4.3	0.86	94.2	94.3832	77.2738
2014	7	27	5	17	0	0.3	4.3	0.91	93.5	94.3832	82.307
2014	7	27	5	27	0	0.3	4.3	0.86	94.6	94.3832	77.5699
2014	7	27	5	37	0	0.3	4.3	0.92	92.9	94.3832	83.1953
2014	7	27	5	47	0	0.3	4.3	0.84	95.8	94.3832	75.2014
2014	7	27	5	57	0	0.3	4.3	0.84	94.9	94.3832	75.7936
2014	7	27	6	7	0	0.3	4.3	0.92	93.5	94.3176	82.5433
2014	7	27	6	17	0	0.3	4.3	0.9	95	94.3176	80.4724
2014	7	27	6	27	0	0.3	4.3	0.91	95.8	94.3176	81.6558
2014	7	27	6	37	0	0.3	4.3	0.88	93	94.3176	78.9931
2014	7	27	6	47	0	0.3	4.3	0.87	92.8	94.3176	78.1055
2014	7	27	6	57	0	0.3	4.3	0.85	94.2	94.3176	76.0346
2014	7	27	7	7	0	0.3	4.3	0.88	93.2	94.3176	79.289
2014	7	27	7	17	0	0.3	4.3	0.93	95.1	94.3176	83.1351
2014	7	27	7	27	0	0.3	4.3	0.89	95.1	94.3176	79.8807
2014	7	27	7	37	0	0.3	4.3	0.9	92.9	94.3176	81.0641
2014	7	27	7	47	0	0.3	4.3	0.91	92.9	94.3176	81.6558
2014	7	27	7	57	0	0.3	4.3	0.89	95.1	94.3176	79.8807
2014	7	27	8	7	0	0.3	4.3	0.91	94.6	94.3832	81.4189
2014	7	27	8	17	0	0.3	4.3	0.88	93.6	94.3832	79.3465
2014	7	27	8	27	0	0.3	4.3	0.88	95.3	94.3176	79.289
2014	7	27	8	37	0	0.3	4.3	0.87	95.4	94.3176	77.8097
2014	7	27	8	47	0	0.3	4.3	0.86	93.3	94.3832	77.274
2014	7	27	8	57	0	0.3	4.3	0.93	93.2	94.3832	84.0835
2014	7	27	9	7	0	0.3	4.3	0.89	93.8	94.3832	79.9386
2014	7	27	9	17	0	0.3	4.3	0.9	95.6	94.3832	81.1228
2014	7	27	9	27	0	0.3	4.3	0.93	94	94.3832	84.0834
2014	7	27	9	37	0	0.3	4.3	0.9	95.4	94.3832	81.1227
2014	7	27	9	47	0	0.3	4.3	0.92	96.2	94.3832	82.307
2014	7	27	9	57	0	0.3	4.3	0.93	94.2	94.3832	84.0834
2014	7	27	10	7	0	0.3	4.3	0.88	95.1	94.3832	79.3462
2014	7	27	10	17	0	0.3	4.3	0.91	95.4	94.3832	82.0108
2014	7	27	10	27	0	0.3	4.3	0.86	96.3	94.3832	77.5698
2014	7	27	10	37	0	0.3	4.3	0.86	96.3	94.3832	77.2737
2014	7	27	10	47	0	0.3	4.3	0.88	93.4	94.3832	79.6422
2014	7	27	10	57	0	0.3	4.3	0.89	93.2	94.3832	79.9382
2014	7	27	11	7	0	0.3	4.3	0.93	95.4	94.4488	83.8478
2014	7	27	11	17	0	0.3	4.3	0.91	96.2	94.3832	81.7146
2014	7	27	11	27	0	0.3	4.3	0.91	95.2	94.3832	81.7145
2014	7	27	11	37	0	0.3	4.3	0.91	93.7	94.3832	82.0106
2014	7	27	11	47	0	0.3	4.3	0.9	95	94.3176	80.7677
2014	7	27	11	57	0	0.3	4.3	0.89	94	94.3832	80.5302
2014	7	27	12	7	0	0.3	4.3	0.85	93.1	94.3176	76.3299
2014	7	27	12	17	0	0.3	4.3	0.89	94.9	94.252	80.1178
2014	7	27	12	27	0	0.3	4.3	0.89	95.5	94.3176	80.1759

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	12	37	0	0.3	4.3	0.89	96.1	94.3176	79.88
2014	7	27	12	47	0	0.3	4.3	0.88	93	94.3176	79.2883
2014	7	27	12	57	0	0.3	4.3	0.87	97.4	94.252	77.7525
2014	7	27	13	7	0	0.3	4.3	0.9	95.8	94.252	81.0045
2014	7	27	13	17	0	0.3	4.3	0.88	94.7	94.252	79.2306
2014	7	27	13	27	0	0.3	4.3	0.88	94.3	94.252	79.2306
2014	7	27	13	37	0	0.3	4.3	0.86	95.2	94.252	77.4567
2014	7	27	13	47	0	0.3	4.3	0.92	95.8	94.252	82.1869
2014	7	27	13	57	0	0.3	4.3	0.86	92.9	94.252	77.1611
2014	7	27	14	7	0	0.3	4.3	0.91	95.2	94.3176	81.359
2014	7	27	14	17	0	0.3	4.3	0.91	93.7	94.252	81.5956
2014	7	27	14	27	0	0.3	4.3	0.87	93.4	94.252	78.6392
2014	7	27	14	37	0	0.3	4.3	0.91	93.3	94.252	81.5955
2014	7	27	14	47	0	0.3	4.3	0.87	92.8	94.252	78.6391
2014	7	27	14	57	0	0.3	4.3	0.92	94.3	94.252	82.4823
2014	7	27	15	7	0	0.3	4.3	0.9	94.4	94.252	81.0041
2014	7	27	15	17	0	0.3	4.3	0.94	94.6	94.252	84.5518
2014	7	27	15	27	0	0.3	4.3	0.9	95.7	94.1864	80.3545
2014	7	27	15	37	0	0.3	4.3	0.94	94.4	94.252	84.8473
2014	7	27	15	47	0	0.3	4.3	0.87	95.6	94.252	77.7521
2014	7	27	15	57	0	0.3	4.3	0.9	95.9	94.252	80.7084
2014	7	27	16	7	0	0.3	4.3	0.85	92.2	94.252	76.5695
2014	7	27	16	17	0	0.3	4.3	0.9	94	94.252	81.004
2014	7	27	16	27	0	0.3	4.3	0.89	95.5	94.252	79.8215
2014	7	27	16	37	0	0.3	4.3	0.9	97.1	94.252	80.4127
2014	7	27	16	47	0	0.3	4.3	0.87	92	94.252	78.0477
2014	7	27	16	57	0	0.3	4.3	0.89	96.1	94.252	79.8215
2014	7	27	17	7	0	0.3	4.3	0.95	95	94.3176	84.9088
2014	7	27	17	17	0	0.3	4.3	0.93	92.2	94.3832	83.7861
2014	7	27	17	27	0	0.3	4.3	0.9	95.4	94.3176	81.0628
2014	7	27	17	37	0	0.3	4.3	0.89	95.1	94.3176	79.8794
2014	7	27	17	47	0	0.3	4.3	0.87	92.2	94.3176	78.1043
2014	7	27	17	57	0	0.3	4.3	0.87	92.8	94.3176	78.4001
2014	7	27	18	7	0	0.3	4.3	0.91	93.7	94.3832	81.7136
2014	7	27	18	17	0	0.3	4.3	0.87	96.1	94.3832	78.1609
2014	7	27	18	27	0	0.3	4.3	0.9	95	94.3176	81.0627
2014	7	27	18	37	0	0.3	4.3	0.86	93.5	94.3832	77.2727
2014	7	27	18	47	0	0.3	4.3	0.89	94.7	94.3832	79.9372
2014	7	27	18	57	0	0.3	4.3	0.85	93.8	94.3832	76.6805
2014	7	27	19	7	0	0.3	4.3	0.88	93.4	94.3832	79.3451
2014	7	27	19	17	0	0.3	4.3	0.87	95.8	94.5144	78.5706
2014	7	27	19	27	0	0.3	4.3	0.85	96.6	94.4488	76.4398
2014	7	27	19	37	0	0.3	4.3	0.88	95.8	94.5144	79.1636
2014	7	27	19	47	0	0.3	4.3	0.81	94	94.5144	72.6407
2014	7	27	19	57	0	0.3	4.3	0.86	95.9	94.4488	77.0324
2014	7	27	20	7	0	0.3	4.3	0.86	96.4	94.5144	76.7917

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	27	20	17	0	0.3	4.3	0.88	94.5	94.58	79.5176
2014	7	27	20	27	0	0.3	4.3	0.88	93.2	94.6457	79.2781
2014	7	27	20	37	0	0.3	4.3	0.85	95.3	94.6457	76.9028
2014	7	27	20	47	0	0.3	4.3	0.85	91.3	94.6457	76.6059
2014	7	27	20	57	0	0.3	4.3	0.91	95	94.7113	81.7125
2014	7	27	21	7	0	0.3	4.3	0.9	93.1	94.7113	81.4154
2014	7	27	21	17	0	0.3	4.3	0.92	96.1	94.7113	83.1982
2014	7	27	21	27	0	0.3	4.3	0.98	94.4	94.7113	88.2495
2014	7	27	21	37	0	0.3	4.3	0.91	92.1	94.7113	82.0097
2014	7	27	21	47	0	0.3	4.3	0.91	93.5	94.7113	82.3068
2014	7	27	21	57	0	0.3	4.3	0.94	95	94.7113	84.3868
2014	7	27	22	7	0	0.3	4.3	0.93	94.6	94.7769	84.4477
2014	7	27	22	17	0	0.3	4.3	0.88	94.7	94.7769	79.3927
2014	7	27	22	27	0	0.3	4.3	0.91	96.6	94.7769	82.3663
2014	7	27	22	37	0	0.3	4.3	0.91	95	94.7769	82.0689
2014	7	27	22	47	0	0.3	4.3	0.91	94.3	94.7769	82.6636
2014	7	27	22	57	0	0.3	4.3	0.9	93.3	94.7769	81.4742
2014	7	27	23	7	0	0.3	4.3	0.87	91.9	94.7769	78.7981
2014	7	27	23	17	0	0.3	4.3	0.88	93.8	94.7769	79.6901
2014	7	27	23	27	0	0.3	4.3	0.92	96.1	94.7769	82.961
2014	7	27	23	37	0	0.3	4.3	0.88	93.4	94.8425	80.0452
2014	7	27	23	47	0	0.3	4.3	0.91	95.6	94.8425	81.8306
2014	7	27	23	57	0	0.3	4.3	0.91	93.3	94.8425	82.1282
2014	7	28	0	7	0	0.3	4.3	0.86	93.3	94.8425	77.9622
2014	7	28	0	17	0	0.3	4.3	0.92	93.7	94.8425	83.616
2014	7	28	0	27	0	0.3	4.3	0.89	93.6	94.8425	80.9379
2014	7	28	0	37	0	0.3	4.3	0.94	93.8	94.8425	85.1039
2014	7	28	0	47	0	0.3	4.3	0.9	92.9	94.8425	81.2355
2014	7	28	0	57	0	0.3	4.3	0.88	95.3	94.8425	79.4501
2014	7	28	1	7	0	0.3	4.3	0.88	94	94.8425	80.0452
2014	7	28	1	17	0	0.3	4.3	0.89	92.5	94.8425	80.3428
2014	7	28	1	27	0	0.3	4.3	0.95	95.4	94.8425	85.699
2014	7	28	1	37	0	0.3	4.3	0.91	94.4	94.8425	82.1282
2014	7	28	1	47	0	0.3	4.3	0.92	94.7	94.8425	82.7233
2014	7	28	1	57	0	0.3	4.3	0.89	93.2	94.8425	80.3428
2014	7	28	2	7	0	0.3	4.3	0.9	95	94.8425	80.938
2014	7	28	2	17	0	0.3	4.3	0.89	92.1	94.8425	80.3428
2014	7	28	2	27	0	0.3	4.3	0.87	93.3	94.8425	78.5574
2014	7	28	2	37	0	0.3	4.3	0.88	94	94.8425	80.0453
2014	7	28	2	47	0	0.3	4.3	0.86	92.2	94.8425	77.9623
2014	7	28	2	57	0	0.3	4.3	0.87	94.6	94.8425	78.2599
2014	7	28	3	7	0	0.3	4.3	0.9	96.1	94.8425	81.2355
2014	7	28	3	17	0	0.3	4.3	0.89	95.1	94.8425	80.3429
2014	7	28	3	27	0	0.3	4.3	0.94	94	94.8425	84.8064
2014	7	28	3	37	0	0.3	4.3	0.92	94.9	94.8425	82.7234
2014	7	28	3	47	0	0.3	4.3	0.88	93.4	94.8425	80.0453

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	3	57	0	0.3	4.3	0.87	96.1	94.8425	78.2599
2014	7	28	4	7	0	0.3	4.3	0.9	95	94.8425	81.5331
2014	7	28	4	17	0	0.3	4.3	0.9	94.6	94.8425	81.2356
2014	7	28	4	27	0	0.3	4.3	0.87	94.1	94.8425	79.1526
2014	7	28	4	37	0	0.3	4.3	0.9	95.4	94.8425	81.5332
2014	7	28	4	47	0	0.3	4.3	0.93	94.1	94.8425	83.9137
2014	7	28	4	57	0	0.3	4.3	0.95	93.8	94.8425	85.6991
2014	7	28	5	7	0	0.3	4.3	0.88	92.3	94.8425	80.0454
2014	7	28	5	17	0	0.3	4.3	0.91	96	94.8425	82.4259
2014	7	28	5	27	0	0.3	4.3	0.86	94.2	94.8425	77.3673
2014	7	28	5	37	0	0.3	4.3	0.89	95.1	94.8425	80.6405
2014	7	28	5	47	0	0.3	4.3	0.89	94	94.8425	80.6405
2014	7	28	5	57	0	0.3	4.3	0.89	94.7	94.8425	80.343
2014	7	28	6	7	0	0.3	4.3	0.89	94.9	94.8425	80.0454
2014	7	28	6	17	0	0.3	4.3	0.92	95.1	94.8425	82.7235
2014	7	28	6	27	0	0.3	4.3	0.86	94.4	94.8425	77.9625
2014	7	28	6	37	0	0.3	4.3	0.88	94.1	94.7769	79.3931
2014	7	28	6	47	0	0.3	4.3	0.9	94.2	94.8425	81.8309
2014	7	28	6	57	0	0.3	4.3	0.89	96.8	94.7769	79.6904
2014	7	28	7	7	0	0.3	4.3	0.85	95.5	94.8425	76.7722
2014	7	28	7	17	0	0.3	4.3	0.9	93.4	94.7769	81.1772
2014	7	28	7	27	0	0.3	4.3	0.84	95.4	94.7769	75.8249
2014	7	28	7	37	0	0.3	4.3	0.88	94.3	94.7769	79.6905
2014	7	28	7	47	0	0.3	4.3	0.8	93.3	94.7769	71.9593
2014	7	28	7	57	0	0.3	4.3	0.88	93.2	94.7769	79.3931
2014	7	28	8	7	0	0.3	4.3	0.86	94.1	94.7769	77.9063
2014	7	28	8	17	0	0.3	4.3	0.89	93.6	94.7769	80.2852
2014	7	28	8	27	0	0.3	4.3	0.88	93.9	94.7769	79.3931
2014	7	28	8	37	0	0.3	4.3	0.86	94.2	94.7769	77.609
2014	7	28	8	47	0	0.3	4.3	0.92	95.1	94.7769	82.664
2014	7	28	8	57	0	0.3	4.3	0.91	95	94.7769	82.0693
2014	7	28	9	7	0	0.3	4.3	0.89	95.1	94.7769	80.2852
2014	7	28	9	17	0	0.3	4.3	0.87	95	94.7769	78.2037
2014	7	28	9	27	0	0.3	4.3	0.87	95	94.7769	78.2037
2014	7	28	9	37	0	0.3	4.3	0.87	96.5	94.7769	77.9063
2014	7	28	9	47	0	0.3	4.3	0.88	94.5	94.7769	79.6904
2014	7	28	9	57	0	0.3	4.3	0.87	94.5	94.7769	78.501
2014	7	28	10	7	0	0.3	4.3	0.86	95	94.7113	77.5529
2014	7	28	10	17	0	0.3	4.3	0.85	92.2	94.7113	76.6615
2014	7	28	10	27	0	0.3	4.3	0.91	95	94.7113	81.7128
2014	7	28	10	37	0	0.3	4.3	0.89	95.1	94.7113	79.93
2014	7	28	10	47	0	0.3	4.3	0.83	93.2	94.7113	75.1758
2014	7	28	10	57	0	0.3	4.3	0.87	97.1	94.7113	78.4443
2014	7	28	11	7	0	0.3	4.3	0.86	92.4	94.6457	77.4969
2014	7	28	11	17	0	0.3	4.3	0.9	95.7	94.6457	80.763
2014	7	28	11	27	0	0.3	4.3	0.87	96.3	94.6457	78.3876

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	11	37	0	0.3	4.3	0.87	96.1	94.6457	78.0907
2014	7	28	11	47	0	0.3	4.3	0.85	93.1	94.6457	77.2
2014	7	28	11	57	0	0.3	4.3	0.92	94.7	94.6457	82.5445
2014	7	28	12	7	0	0.3	4.3	0.86	95.3	94.6457	77.4968
2014	7	28	12	17	0	0.3	4.3	0.9	95.8	94.58	81.298
2014	7	28	12	27	0	0.3	4.3	0.9	95.9	94.6457	81.0599
2014	7	28	12	37	0	0.3	4.3	0.84	94.7	94.5144	75.9024
2014	7	28	12	47	0	0.3	4.3	0.9	96.1	94.5144	80.9427
2014	7	28	12	57	0	0.3	4.3	0.87	93.9	94.5144	78.8672
2014	7	28	13	7	0	0.3	4.3	0.84	92.5	94.5144	75.9023
2014	7	28	13	17	0	0.3	4.3	0.88	95.2	94.4488	78.8102
2014	7	28	13	27	0	0.3	4.3	0.91	97.3	94.3832	81.4177
2014	7	28	13	37	0	0.3	4.3	0.91	94.4	94.3832	81.7138
2014	7	28	13	47	0	0.3	4.3	0.87	95.2	94.3832	77.8649
2014	7	28	13	57	0	0.3	4.3	0.87	95.4	94.3832	78.4571
2014	7	28	14	7	0	0.3	4.3	0.87	93.2	94.3176	78.4002
2014	7	28	14	17	0	0.3	4.3	0.85	95.5	94.3176	76.3292
2014	7	28	14	27	0	0.3	4.3	0.84	96.2	94.3176	75.7375
2014	7	28	14	37	0	0.3	4.3	0.9	96.1	94.252	80.4128
2014	7	28	14	47	0	0.3	4.3	0.9	95.4	94.252	80.7084
2014	7	28	14	57	0	0.3	4.3	0.87	94.8	94.252	78.0477
2014	7	28	15	7	0	0.3	4.3	0.87	96.1	94.252	77.752
2014	7	28	15	17	0	0.3	4.3	0.89	94.9	94.252	79.5258
2014	7	28	15	27	0	0.3	4.3	0.87	93.2	94.252	78.3433
2014	7	28	15	37	0	0.3	4.3	0.89	95.9	94.252	80.1171
2014	7	28	15	47	0	0.3	4.3	0.91	93.1	94.252	81.8909
2014	7	28	15	57	0	0.3	4.3	0.93	96.7	94.1864	83.6041
2014	7	28	16	7	0	0.3	4.3	0.94	95.2	94.252	84.5517
2014	7	28	16	17	0	0.3	4.3	0.92	93.7	94.252	82.4822
2014	7	28	16	27	0	0.3	4.3	0.9	94.8	94.252	81.004
2014	7	28	16	37	0	0.3	4.3	0.86	95.2	94.252	77.4564
2014	7	28	16	47	0	0.3	4.3	0.91	93.9	94.252	81.5953
2014	7	28	16	57	0	0.3	4.3	0.87	93.9	94.252	78.6389
2014	7	28	17	7	0	0.3	4.3	0.94	96	94.1864	84.1949
2014	7	28	17	17	0	0.3	4.3	0.89	96.3	94.1864	80.059
2014	7	28	17	27	0	0.3	4.3	0.91	93.5	94.1864	81.8316
2014	7	28	17	37	0	0.3	4.3	0.9	94	94.252	81.0041
2014	7	28	17	47	0	0.3	4.3	0.89	93.6	94.1864	80.3545
2014	7	28	17	57	0	0.3	4.3	0.84	94.3	94.1864	75.3323
2014	7	28	18	7	0	0.3	4.3	0.89	95.1	94.1864	79.4682
2014	7	28	18	17	0	0.3	4.3	0.9	95.6	94.1864	80.9453
2014	7	28	18	27	0	0.3	4.3	0.92	92.5	94.1864	82.4224
2014	7	28	18	37	0	0.3	4.3	0.87	92.8	94.252	78.3434
2014	7	28	18	47	0	0.3	4.3	0.9	92.7	94.1864	80.6499
2014	7	28	18	57	0	0.3	4.3	0.94	93.6	94.1864	84.4904
2014	7	28	19	7	0	0.3	4.3	0.85	94.2	94.1864	76.514

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	28	19	17	0	0.3	4.3	0.92	92.9	94.1864	82.4225
2014	7	28	19	27	0	0.3	4.3	0.9	96.7	94.1864	80.6499
2014	7	28	19	37	0	0.3	4.3	0.95	94.8	94.1864	85.0813
2014	7	28	19	47	0	0.3	4.3	0.9	95.3	94.1864	80.3545
2014	7	28	19	57	0	0.3	4.3	0.95	94.6	94.1864	85.0813
2014	7	28	20	7	0	0.3	4.3	0.88	95.1	94.252	78.9347
2014	7	28	20	17	0	0.3	4.3	0.92	95.5	94.252	82.4823
2014	7	28	20	27	0	0.3	4.3	0.9	95.8	94.252	81.0042
2014	7	28	20	37	0	0.3	4.3	0.88	94	94.252	79.526
2014	7	28	20	47	0	0.3	4.3	0.92	93.1	94.252	82.778
2014	7	28	20	57	0	0.3	4.3	0.9	94.6	94.252	81.0042
2014	7	28	21	7	0	0.3	4.3	0.89	95.1	94.252	79.526
2014	7	28	21	17	0	0.3	4.3	0.9	96.1	94.252	80.7086
2014	7	28	21	27	0	0.3	4.3	0.85	93.5	94.252	76.5697
2014	7	28	21	37	0	0.3	4.3	0.9	96.5	94.252	81.0042
2014	7	28	21	47	0	0.3	4.3	0.91	93.5	94.252	81.8912
2014	7	28	21	57	0	0.3	4.3	0.91	94.6	94.252	81.2999
2014	7	28	22	7	0	0.3	4.3	0.9	94.4	94.252	81.0043
2014	7	28	22	17	0	0.3	4.3	0.89	96.3	94.252	79.8217
2014	7	28	22	27	0	0.3	4.3	0.92	93.5	94.252	82.7781
2014	7	28	22	37	0	0.3	4.3	0.89	94.7	94.3176	79.8797
2014	7	28	22	47	0	0.3	4.3	0.88	93	94.3176	79.5838
2014	7	28	22	57	0	0.3	4.3	0.89	94.2	94.3832	80.5297
2014	7	28	23	7	0	0.3	4.3	0.91	95.2	94.4488	82.0694
2014	7	28	23	17	0	0.3	4.3	0.9	95	94.5144	80.9429
2014	7	28	23	27	0	0.3	4.3	0.93	94.8	94.5144	83.9078
2014	7	28	23	37	0	0.3	4.3	0.91	95	94.58	81.5949
2014	7	28	23	47	0	0.3	4.3	0.86	94.4	94.58	77.1442
2014	7	28	23	57	0	0.3	4.3	0.9	95.8	94.58	81.2982
2014	7	29	0	7	0	0.3	4.3	0.9	94.8	94.58	81.0015
2014	7	29	0	17	0	0.3	4.3	0.88	95.1	94.6457	79.5754
2014	7	29	0	27	0	0.3	4.3	0.91	92.1	94.6457	82.5447
2014	7	29	0	37	0	0.3	4.3	0.91	94.6	94.6457	81.6539
2014	7	29	0	47	0	0.3	4.3	0.89	95.5	94.6457	79.8724
2014	7	29	0	57	0	0.3	4.3	0.94	96.6	94.7113	84.9814
2014	7	29	1	7	0	0.3	4.3	0.88	94.3	94.7113	79.6329
2014	7	29	1	17	0	0.3	4.3	0.93	94.4	94.7113	84.09
2014	7	29	1	27	0	0.3	4.3	0.92	95.3	94.7769	82.664
2014	7	29	1	37	0	0.3	4.3	0.9	93.5	94.7769	81.7719
2014	7	29	1	47	0	0.3	4.3	0.93	95	94.7769	84.1508
2014	7	29	1	57	0	0.3	4.3	0.86	95.5	94.7769	77.3116
2014	7	29	2	7	0	0.3	4.3	0.87	93.9	94.8425	79.1528
2014	7	29	2	17	0	0.3	4.3	0.87	94.3	94.8425	78.8553
2014	7	29	2	27	0	0.3	4.3	0.9	96.9	94.8425	80.9382
2014	7	29	2	37	0	0.3	4.3	0.92	96.6	94.8425	82.7236
2014	7	29	2	47	0	0.3	4.3	0.9	92.9	94.9081	81.8899

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	2	57	0	0.3	4.3	0.91	93.9	94.9081	82.4855
2014	7	29	3	7	0	0.3	4.3	0.96	95.5	94.9738	86.7169
2014	7	29	3	17	0	0.3	4.3	0.96	93.7	94.9738	87.0149
2014	7	29	3	27	0	0.3	4.3	0.95	93.8	95.0394	85.8847
2014	7	29	3	37	0	0.3	4.3	0.9	94	95.2362	82.1849
2014	7	29	3	47	0	0.3	4.3	0.91	95.8	95.3018	82.5429
2014	7	29	3	57	0	0.3	4.3	0.93	94.9	95.3675	84.0986
2014	7	29	4	7	0	0.3	4.3	0.93	95.3	95.3675	84.0986
2014	7	29	4	17	0	0.3	4.3	0.91	94.4	95.4331	82.6614
2014	7	29	4	27	0	0.3	4.3	0.93	93.6	95.4331	85.0573
2014	7	29	4	37	0	0.3	4.3	0.94	94.8	95.4987	85.7177
2014	7	29	4	47	0	0.3	4.3	0.91	94.8	95.4987	82.7206
2014	7	29	4	57	0	0.3	4.3	0.91	94.6	95.5643	82.4799
2014	7	29	5	7	0	0.3	4.3	0.97	96.4	95.5643	87.8785
2014	7	29	5	17	0	0.3	4.3	0.9	94.4	95.6299	81.6384
2014	7	29	5	27	0	0.3	4.3	0.91	95	95.6299	83.1391
2014	7	29	5	37	0	0.3	4.3	0.92	94.1	95.6955	84.0996
2014	7	29	5	47	0	0.3	4.3	0.91	96	95.6955	83.1986
2014	7	29	5	57	0	0.3	4.3	0.92	94.7	95.6955	83.7993
2014	7	29	6	7	0	0.3	4.3	0.91	95.2	95.7612	82.6569
2014	7	29	6	17	0	0.3	4.3	0.91	95.6	95.8924	83.3769
2014	7	29	6	27	0	0.3	4.3	0.92	95.9	96.0236	84.0986
2014	7	29	6	37	0	0.3	4.3	0.93	92.8	96.0892	85.365
2014	7	29	6	47	0	0.3	4.3	0.93	94.9	96.1549	84.822
2014	7	29	6	57	0	0.3	4.6	0.95	94.2	96.2205	87.2989
2014	7	29	7	7	0	0.3	4.6	0.92	93.3	96.2205	84.2782
2014	7	29	7	17	0	0.3	4.6	0.92	96	96.2861	84.0357
2014	7	29	7	27	0	0.3	4.6	0.89	95.5	96.2861	81.9197
2014	7	29	7	37	0	0.3	4.6	0.91	93.7	96.2861	83.4312
2014	7	29	7	47	0	0.3	4.6	0.92	95.1	96.3517	84.7004
2014	7	29	7	57	0	0.3	4.6	0.95	95	96.3517	87.1204
2014	7	29	8	7	0	0.3	4.6	0.92	93.7	96.3517	84.3979
2014	7	29	8	17	0	0.3	4.6	0.94	94.6	96.4173	86.5767
2014	7	29	8	27	0	0.3	4.6	0.95	96	96.4173	86.8794
2014	7	29	8	37	0	0.3	4.6	0.93	93.9	96.483	85.4264
2014	7	29	8	47	0	0.3	4.6	0.95	97.2	96.483	86.6381
2014	7	29	8	57	0	0.3	4.6	0.93	95.9	96.5486	85.79
2014	7	29	9	7	0	0.3	4.6	0.93	97.7	96.5486	84.8805
2014	7	29	9	17	0	0.3	4.6	0.93	95.3	96.6798	85.6078
2014	7	29	9	27	0	0.3	4.6	0.93	97.3	96.811	85.7288
2014	7	29	9	37	0	0.3	4.6	0.94	93.6	96.8766	87.0062
2014	7	29	9	47	0	0.3	4.6	0.95	95.8	96.9423	87.372
2014	7	29	9	57	0	0.3	4.6	0.93	96.7	96.9423	85.5453
2014	7	29	10	7	0	0.3	4.6	0.94	93.2	97.0079	87.4335
2014	7	29	10	17	0	0.3	4.6	0.93	93.2	97.0079	86.5195
2014	7	29	10	27	0	0.3	4.6	0.87	96.7	97.0735	80.4832

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	10	37	0	0.3	4.6	0.94	93.8	97.0735	87.495
2014	7	29	10	47	0	0.3	4.6	0.95	95.7	97.0735	87.7999
2014	7	29	10	57	0	0.3	4.6	0.93	93.2	97.1391	86.6413
2014	7	29	11	7	0	0.3	4.6	0.92	96.7	97.1391	85.1159
2014	7	29	11	17	0	0.3	4.6	0.9	95.2	97.1391	83.5905
2014	7	29	11	27	0	0.3	4.6	0.89	96.2	97.1391	82.0651
2014	7	29	11	37	0	0.3	4.6	0.93	94.5	97.2047	86.0916
2014	7	29	11	47	0	0.3	4.6	0.93	97.7	97.2047	85.7862
2014	7	29	11	57	0	0.3	4.6	0.92	94.7	97.2047	85.1756
2014	7	29	12	7	0	0.3	4.6	0.94	95.2	97.2047	87.3126
2014	7	29	12	17	0	0.3	4.6	0.94	94.8	97.2703	87.3739
2014	7	29	12	27	0	0.3	4.6	0.95	95.6	97.2703	87.6794
2014	7	29	12	37	0	0.3	4.6	0.93	95.3	97.336	85.9067
2014	7	29	12	47	0	0.3	4.6	0.97	95.1	97.336	89.8809
2014	7	29	12	57	0	0.3	4.6	0.91	95	97.336	84.0723
2014	7	29	13	7	0	0.3	4.6	0.94	96.2	97.336	87.4351
2014	7	29	13	17	0	0.3	4.6	0.94	95	97.4016	87.1905
2014	7	29	13	27	0	0.3	4.6	0.97	96	97.4016	89.638
2014	7	29	13	37	0	0.3	4.6	0.96	93.5	97.4016	89.0261
2014	7	29	13	47	0	0.3	4.6	0.94	95.6	97.4672	87.2516
2014	7	29	13	57	0	0.3	4.6	0.97	94.7	97.4672	90.313
2014	7	29	14	7	0	0.3	4.6	0.9	95	97.4672	83.5778
2014	7	29	14	17	0	0.3	4.6	0.91	96	97.4672	84.8023
2014	7	29	14	27	0	0.3	4.6	0.91	96.8	97.4672	84.4962
2014	7	29	14	37	0	0.3	4.6	0.95	95.2	97.5328	88.2317
2014	7	29	14	47	0	0.3	4.6	0.93	94.6	97.5328	86.6999
2014	7	29	14	57	0	0.3	4.6	0.97	95.2	97.5328	90.0698
2014	7	29	15	7	0	0.3	4.6	0.89	95.7	97.5984	83.0817
2014	7	29	15	17	0	0.3	4.6	0.97	93.7	97.5984	90.746
2014	7	29	15	27	0	0.3	4.6	0.93	94.9	97.664	86.2077
2014	7	29	15	37	0	0.3	4.6	0.92	96.3	97.664	85.9009
2014	7	29	15	47	0	0.3	4.6	0.94	93.4	97.7297	87.803
2014	7	29	15	57	0	0.3	4.6	0.96	95.5	97.7953	89.4005
2014	7	29	16	7	0	0.3	4.6	0.91	95.2	97.8609	85.1588
2014	7	29	16	17	0	0.3	4.6	0.96	95.3	97.8609	89.1554
2014	7	29	16	27	0	0.3	4.6	0.92	94.9	97.8609	85.4663
2014	7	29	16	37	0	0.3	4.6	0.97	94.1	97.8609	91
2014	7	29	16	47	0	0.3	4.6	0.94	94.2	97.9265	87.6794
2014	7	29	16	57	0	0.3	4.6	0.93	94.9	97.9265	86.4488
2014	7	29	17	7	0	0.3	4.6	0.99	93.2	97.9265	92.6018
2014	7	29	17	17	0	0.3	4.6	0.94	94	97.9265	88.2947
2014	7	29	17	27	0	0.3	4.6	0.95	92	97.9265	89.2177
2014	7	29	17	37	0	0.3	4.6	0.96	95.3	97.9921	89.8956
2014	7	29	17	47	0	0.3	4.6	0.94	94.6	97.9921	88.0485
2014	7	29	17	57	0	0.3	4.6	0.93	94.8	97.9921	87.1249
2014	7	29	18	7	0	0.3	4.6	0.93	95.1	97.9921	86.5092

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	29	18	17	0	0.3	4.6	0.94	96.2	98.0577	87.8018
2014	7	29	18	27	0	0.3	4.6	0.96	93.9	98.0577	89.9583
2014	7	29	18	37	0	0.3	4.6	0.93	95.1	98.0577	86.5695
2014	7	29	18	47	0	0.3	4.6	0.92	93.9	98.0577	86.5695
2014	7	29	18	57	0	0.3	4.6	0.96	95.3	98.0577	89.3422
2014	7	29	19	7	0	0.3	4.6	0.92	94.1	98.0577	86.5695
2014	7	29	19	17	0	0.3	4.6	0.94	94	98.1234	88.1713
2014	7	29	19	27	0	0.3	4.6	0.97	94.7	98.1234	90.9459
2014	7	29	19	37	0	0.3	4.6	0.97	93.9	98.1234	91.2542
2014	7	29	19	47	0	0.3	4.6	0.98	96.1	98.1234	91.5625
2014	7	29	19	57	0	0.3	4.6	0.99	94.4	98.1234	92.4874
2014	7	29	20	7	0	0.3	4.6	0.92	95.3	98.1234	85.705
2014	7	29	20	17	0	0.3	4.6	0.97	93.7	98.1234	90.9459
2014	7	29	20	27	0	0.3	4.6	0.95	93.2	98.1234	88.7879
2014	7	29	20	37	0	0.3	4.6	0.97	97.4	98.1234	90.3294
2014	7	29	20	47	0	0.3	4.6	1	95.3	98.1234	93.104
2014	7	29	20	57	0	0.3	4.6	0.97	94.7	98.189	91.0093
2014	7	29	21	7	0	0.3	4.6	0.99	93.6	98.189	92.5518
2014	7	29	21	17	0	0.3	4.6	0.97	93.7	98.189	91.3178
2014	7	29	21	27	0	0.3	4.6	0.95	95.2	98.189	88.8498
2014	7	29	21	37	0	0.3	4.6	0.94	94.8	98.189	87.9242
2014	7	29	21	47	0	0.3	4.6	0.93	95.5	98.2546	86.7506
2014	7	29	21	57	0	0.3	4.6	0.94	94	98.2546	88.2942
2014	7	29	22	7	0	0.3	4.6	0.94	95.8	98.2546	87.9855
2014	7	29	22	17	0	0.3	4.6	0.96	93.7	98.2546	90.1465
2014	7	29	22	27	0	0.3	4.6	0.96	93.7	98.2546	89.8378
2014	7	29	22	37	0	0.3	4.6	0.95	94.7	98.3202	89.5913
2014	7	29	22	47	0	0.3	4.6	0.92	91.8	98.3202	86.193
2014	7	29	22	57	0	0.3	4.6	0.92	93.9	98.3202	86.8109
2014	7	29	23	7	0	0.3	4.6	0.95	93.7	98.3202	89.5913
2014	7	29	23	17	0	0.3	4.6	0.97	95.4	98.3858	91.1994
2014	7	29	23	27	0	0.3	4.6	0.92	93.9	98.4515	86.9316
2014	7	29	23	37	0	0.3	4.6	0.94	92.4	98.5171	88.8494
2014	7	29	23	47	0	0.3	4.6	0.94	94.8	98.5827	87.9816
2014	7	29	23	57	0	0.3	4.6	0.97	94.9	98.5827	91.0796
2014	7	30	0	7	0	0.3	4.6	0.94	93	98.6483	88.3526
2014	7	30	0	17	0	0.3	4.6	0.98	93.1	98.6483	92.3827
2014	7	30	0	27	0	0.3	4.6	0.98	93.8	98.6483	92.6927
2014	7	30	0	37	0	0.3	4.6	0.91	94.5	98.6483	85.8725
2014	7	30	0	47	0	0.3	4.6	0.95	93.6	98.7139	89.3445
2014	7	30	0	57	0	0.3	4.6	0.96	93.3	98.7139	90.5854
2014	7	30	1	7	0	0.3	4.6	0.95	95.5	98.7139	89.6547
2014	7	30	1	17	0	0.3	4.6	0.98	94.2	98.7139	92.757
2014	7	30	1	27	0	0.3	4.6	0.97	93.9	98.7139	91.5161
2014	7	30	1	37	0	0.3	4.6	0.94	94.8	98.7795	88.1646
2014	7	30	1	47	0	0.3	4.6	0.98	95	98.7795	92.8212

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	1	57	0	0.3	4.6	0.95	96.3	98.7795	89.7168
2014	7	30	2	7	0	0.3	4.6	0.93	92.6	98.7795	87.8542
2014	7	30	2	17	0	0.3	4.6	0.97	95.5	98.7795	90.9586
2014	7	30	2	27	0	0.3	4.6	0.99	95.3	98.7795	92.8212
2014	7	30	2	37	0	0.3	4.6	0.96	95.7	98.7795	90.6481
2014	7	30	2	47	0	0.3	4.6	0.96	94.7	98.7795	90.3377
2014	7	30	2	57	0	0.3	4.6	0.96	93.7	98.8452	91.0215
2014	7	30	3	7	0	0.3	4.6	0.93	96.1	98.8452	87.6043
2014	7	30	3	17	0	0.3	4.6	0.97	92.7	98.8452	91.3321
2014	7	30	3	27	0	0.3	4.6	0.96	92.9	98.8452	90.7109
2014	7	30	3	37	0	0.3	4.6	0.99	95.3	98.8452	93.1961
2014	7	30	3	47	0	0.3	4.6	0.92	93.9	98.8452	87.2937
2014	7	30	3	57	0	0.3	4.6	0.95	93.9	98.8452	90.0896
2014	7	30	4	7	0	0.3	4.6	0.95	94.9	98.8452	89.7789
2014	7	30	4	17	0	0.3	4.6	0.93	94.6	98.8452	87.915
2014	7	30	4	27	0	0.3	4.6	0.93	94.2	98.9108	88.2866
2014	7	30	4	37	0	0.3	4.6	0.94	94.8	98.9108	89.2192
2014	7	30	4	47	0	0.3	4.6	0.95	94.7	98.9108	89.841
2014	7	30	4	57	0	0.3	4.6	0.96	92.4	98.9108	90.7736
2014	7	30	5	7	0	0.3	4.6	1	95.3	98.9108	94.1932
2014	7	30	5	17	0	0.3	4.6	0.93	93	98.9108	87.6649
2014	7	30	5	27	0	0.3	4.6	0.98	93.1	98.9108	92.6388
2014	7	30	5	37	0	0.3	4.6	0.95	95.2	98.9108	89.5302
2014	7	30	5	47	0	0.3	4.6	0.96	97.4	98.9108	90.4628
2014	7	30	5	57	0	0.3	4.6	0.94	93	98.9764	89.2809
2014	7	30	6	7	0	0.3	4.6	0.95	96.3	98.9764	89.9031
2014	7	30	6	17	0	0.3	4.6	0.97	94.1	98.9764	91.4585
2014	7	30	6	27	0	0.3	4.6	1	93.8	98.9764	94.5693
2014	7	30	6	37	0	0.3	4.6	0.96	94.7	98.9764	90.5253
2014	7	30	6	47	0	0.3	4.6	0.98	94.8	98.9764	92.3918
2014	7	30	6	57	0	0.3	4.6	0.94	94.8	99.042	88.4087
2014	7	30	7	7	0	0.3	4.6	0.95	92.8	99.042	89.9652
2014	7	30	7	17	0	0.3	4.6	0.97	94.5	99.042	91.5217
2014	7	30	7	27	0	0.3	4.6	0.96	94.9	99.042	90.8991
2014	7	30	7	37	0	0.3	4.6	0.95	94.7	99.042	90.2765
2014	7	30	7	47	0	0.3	4.6	0.94	95.2	99.1076	89.0927
2014	7	30	7	57	0	0.3	4.6	0.97	94.5	99.1732	91.9596
2014	7	30	8	7	0	0.3	4.6	0.98	95	99.1732	92.8948
2014	7	30	8	17	0	0.3	4.6	0.97	95.4	99.1732	91.6479
2014	7	30	8	27	0	0.3	4.6	0.97	95.1	99.1732	91.3362
2014	7	30	8	37	0	0.3	4.6	0.94	95.8	99.2388	88.5916
2014	7	30	8	47	0	0.3	4.6	0.98	92.5	99.2388	93.2707
2014	7	30	8	57	0	0.3	4.6	0.99	94.4	99.2388	93.8946
2014	7	30	9	7	0	0.3	4.6	0.98	95	99.2388	92.9588
2014	7	30	9	17	0	0.3	4.6	0.97	95.6	99.2388	91.711
2014	7	30	9	27	0	0.3	4.6	0.99	93.4	99.2388	93.8946

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	9	37	0	0.3	4.6	0.96	94.3	99.3045	91.1498
2014	7	30	9	47	0	0.3	4.6	1.01	94.9	99.2388	95.4542
2014	7	30	9	57	0	0.3	4.6	0.96	96.9	99.3045	90.2133
2014	7	30	10	7	0	0.3	4.6	1.01	96.7	99.2388	95.4542
2014	7	30	10	17	0	0.3	4.6	0.96	97.1	99.2388	90.7751
2014	7	30	10	27	0	0.3	4.6	0.98	93.7	99.2388	92.6467
2014	7	30	10	37	0	0.3	4.6	0.95	94.9	99.2388	90.1511
2014	7	30	10	47	0	0.3	4.6	0.97	94.4	99.2388	92.3347
2014	7	30	10	57	0	0.3	4.6	0.92	95.1	99.1732	87.2835
2014	7	30	11	7	0	0.3	4.6	0.94	96.8	99.2388	88.9034
2014	7	30	11	17	0	0.3	4.6	0.96	93.9	99.1732	91.0243
2014	7	30	11	27	0	0.3	4.6	0.92	93.1	99.2388	87.3436
2014	7	30	11	37	0	0.3	4.6	0.97	95.6	99.2388	92.0228
2014	7	30	11	47	0	0.3	4.6	0.93	94.9	99.1732	87.5953
2014	7	30	11	57	0	0.3	4.6	0.97	94.7	99.1732	91.6477
2014	7	30	12	7	0	0.3	4.6	0.98	95	99.1732	92.8947
2014	7	30	12	17	0	0.3	4.6	0.98	94.6	99.1732	93.2064
2014	7	30	12	27	0	0.3	4.6	0.93	94.5	99.2388	87.9676
2014	7	30	12	37	0	0.3	4.6	0.94	95	99.2388	88.5915
2014	7	30	12	47	0	0.3	4.6	0.97	95.2	99.2388	92.0228
2014	7	30	12	57	0	0.3	4.6	0.98	94	99.2388	92.9587
2014	7	30	13	7	0	0.3	4.6	0.97	96	99.2388	91.7109
2014	7	30	13	17	0	0.3	4.6	0.99	94.4	99.3045	93.9591
2014	7	30	13	27	0	0.3	4.6	1	97.7	99.2388	94.2065
2014	7	30	13	37	0	0.3	4.6	0.97	96.6	99.2388	92.0229
2014	7	30	13	47	0	0.3	4.6	0.96	93.5	99.2388	91.399
2014	7	30	13	57	0	0.3	4.6	0.95	92.8	99.3045	90.2133
2014	7	30	14	7	0	0.3	4.6	0.98	93.6	99.2388	92.9587
2014	7	30	14	17	0	0.3	4.6	0.95	93.8	99.2388	89.8393
2014	7	30	14	27	0	0.3	4.6	0.96	93.5	99.3045	91.462
2014	7	30	14	37	0	0.3	4.6	0.97	95.4	99.3045	91.7741
2014	7	30	14	47	0	0.3	4.6	0.98	94	99.3045	93.0228
2014	7	30	14	57	0	0.3	4.6	1.01	95.2	99.3701	96.2105
2014	7	30	15	7	0	0.3	4.6	0.99	94.2	99.3045	93.6471
2014	7	30	15	17	0	0.3	4.6	1	94	99.3701	94.961
2014	7	30	15	27	0	0.3	4.6	0.97	95.7	99.3701	91.5249
2014	7	30	15	37	0	0.3	4.6	0.95	94.9	99.3701	90.2755
2014	7	30	15	47	0	0.3	4.6	0.95	93.9	99.3701	90.5878
2014	7	30	15	57	0	0.3	4.6	0.95	94.3	99.3701	90.5879
2014	7	30	16	7	0	0.3	4.6	0.96	94.5	99.3701	91.2126
2014	7	30	16	17	0	0.3	4.6	0.98	95	99.3701	93.0869
2014	7	30	16	27	0	0.3	4.6	0.98	93.3	99.3701	93.0869
2014	7	30	16	37	0	0.3	4.6	0.94	95.6	99.3701	89.3384
2014	7	30	16	47	0	0.3	4.6	0.99	94.8	99.3701	93.7116
2014	7	30	16	57	0	0.3	4.6	0.97	93.7	99.4357	92.5257
2014	7	30	17	7	0	0.3	4.6	1	93.6	99.4357	95.0264

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	30	17	17	0	0.3	4.6	0.97	94.3	99.4357	92.2132
2014	7	30	17	27	0	0.3	4.6	0.97	92.9	99.4357	92.2132
2014	7	30	17	37	0	0.3	4.6	0.94	94.4	99.4357	89.7125
2014	7	30	17	47	0	0.3	4.6	0.94	95.2	99.4357	89.3999
2014	7	30	17	57	0	0.3	4.6	0.99	95.3	99.4357	93.7761
2014	7	30	18	7	0	0.3	4.6	0.95	95	99.4357	89.7125
2014	7	30	18	17	0	0.3	4.6	0.95	95.9	99.4357	90.0251
2014	7	30	18	27	0	0.3	4.6	0.97	95.8	99.4357	92.2132
2014	7	30	18	37	0	0.3	4.6	0.94	96.9	99.4357	88.4622
2014	7	30	18	47	0	0.3	4.6	0.93	95.9	99.4357	88.1496
2014	7	30	18	57	0	0.3	4.6	0.95	96.7	99.4357	90.3378
2014	7	30	19	7	0	0.3	4.6	0.96	93.7	99.4357	91.2755
2014	7	30	19	17	0	0.3	4.6	0.98	95.4	99.4357	92.5259
2014	7	30	19	27	0	0.3	4.6	0.95	95.7	99.4357	90.0252
2014	7	30	19	37	0	0.3	4.6	0.97	95.6	99.4357	91.9007
2014	7	30	19	47	0	0.3	4.6	0.99	95.9	99.4357	93.4637
2014	7	30	19	57	0	0.3	4.6	0.97	96.8	99.4357	91.5882
2014	7	30	20	7	0	0.3	4.6	0.98	95.2	99.4357	92.8385
2014	7	30	20	17	0	0.3	4.6	0.95	96.9	99.4357	90.0253
2014	7	30	20	27	0	0.3	4.6	0.98	94	99.5013	93.5279
2014	7	30	20	37	0	0.3	4.6	0.92	93.5	99.4357	87.5246
2014	7	30	20	47	0	0.3	4.6	0.94	94.8	99.4357	89.4001
2014	7	30	20	57	0	0.3	4.6	0.95	94.6	99.4357	90.3379
2014	7	30	21	7	0	0.3	4.6	0.93	94.3	99.4357	88.1498
2014	7	30	21	17	0	0.3	4.6	0.98	95.6	99.4357	92.526
2014	7	30	21	27	0	0.3	4.6	0.94	96	99.4357	89.0876
2014	7	30	21	37	0	0.3	4.6	0.93	96.7	99.4357	88.1498
2014	7	30	21	47	0	0.3	4.6	0.98	96.4	99.4357	92.5261
2014	7	30	21	57	0	0.3	4.6	0.94	96.9	99.4357	88.4624
2014	7	30	22	7	0	0.3	4.6	0.98	94.4	99.4357	93.1513
2014	7	30	22	17	0	0.3	4.6	0.94	93.4	99.4357	89.0877
2014	7	30	22	27	0	0.3	4.6	0.95	95.1	99.4357	90.338
2014	7	30	22	37	0	0.3	4.6	0.99	95.7	99.4357	93.7765
2014	7	30	22	47	0	0.3	4.6	0.92	96.2	99.4357	86.8996
2014	7	30	22	57	0	0.3	4.6	0.92	93.7	99.4357	87.2122
2014	7	30	23	7	0	0.3	4.6	0.98	92.9	99.4357	93.1514
2014	7	30	23	17	0	0.3	4.6	0.95	94.4	99.4357	90.0255
2014	7	30	23	27	0	0.3	4.6	0.96	92.7	99.4357	91.5885
2014	7	30	23	37	0	0.3	4.6	0.97	94.7	99.4357	91.9011
2014	7	30	23	47	0	0.3	4.6	0.96	98.1	99.4357	90.3382
2014	7	30	23	57	0	0.3	4.6	0.97	96.2	99.4357	91.5885
2014	7	31	0	7	0	0.3	4.6	0.94	94	99.4357	89.713
2014	7	31	0	17	0	0.3	4.6	0.96	95.3	99.4357	90.9634
2014	7	31	0	27	0	0.3	4.6	0.93	94.8	99.4357	88.4627
2014	7	31	0	37	0	0.3	4.6	0.96	97.5	99.4357	90.6508
2014	7	31	0	47	0	0.3	4.6	0.94	96.6	99.4357	89.4005

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	0	57	0	0.3	4.6	1	94.7	99.4357	94.7145
2014	7	31	1	7	0	0.3	4.6	0.92	95.1	99.4357	87.525
2014	7	31	1	17	0	0.3	4.6	0.98	92.7	99.3701	93.0876
2014	7	31	1	27	0	0.3	4.6	0.93	97.1	99.4357	87.525
2014	7	31	1	37	0	0.3	4.6	0.92	96.2	99.3701	86.8402
2014	7	31	1	47	0	0.3	4.6	0.96	94.5	99.3701	91.5258
2014	7	31	1	57	0	0.3	4.6	0.97	96.2	99.3701	91.5258
2014	7	31	2	7	0	0.3	4.6	0.99	95.3	99.3701	94.0248
2014	7	31	2	17	0	0.3	4.6	0.97	96.4	99.3701	91.5259
2014	7	31	2	27	0	0.3	4.6	0.94	95.2	99.3701	89.3393
2014	7	31	2	37	0	0.3	4.6	0.97	94.5	99.3701	91.8383
2014	7	31	2	47	0	0.3	4.6	0.94	94.4	99.3701	89.3393
2014	7	31	2	57	0	0.3	4.6	0.95	94.7	99.3701	90.5888
2014	7	31	3	7	0	0.3	4.6	0.95	92.4	99.3701	90.5888
2014	7	31	3	17	0	0.3	4.6	0.94	92.6	99.3045	89.5901
2014	7	31	3	27	0	0.3	4.6	0.93	95.7	99.3045	88.0293
2014	7	31	3	37	0	0.3	4.6	0.94	95.8	99.3045	88.9658
2014	7	31	3	47	0	0.3	4.6	0.97	94.4	99.3045	92.3996
2014	7	31	3	57	0	0.3	4.6	0.95	94.9	99.3045	90.2145
2014	7	31	4	7	0	0.3	4.6	0.97	96.4	99.2388	91.7122
2014	7	31	4	17	0	0.3	4.6	0.98	97.1	99.2388	92.6481
2014	7	31	4	27	0	0.3	4.6	0.92	95.1	99.2388	86.7211
2014	7	31	4	37	0	0.3	4.6	0.94	95.8	99.2388	88.5928
2014	7	31	4	47	0	0.3	4.6	0.99	96.6	99.1732	93.8313
2014	7	31	4	57	0	0.3	4.6	0.95	94.5	99.1732	90.4023
2014	7	31	5	7	0	0.3	4.6	0.93	96.5	99.1732	87.5967
2014	7	31	5	17	0	0.3	4.6	0.94	95.6	99.1076	89.094
2014	7	31	5	27	0	0.3	4.6	1.01	94.1	99.1076	95.9474
2014	7	31	5	37	0	0.3	4.6	0.94	95.4	99.1076	89.094
2014	7	31	5	47	0	0.3	4.6	0.95	94.7	99.1076	90.0286
2014	7	31	5	57	0	0.3	4.6	0.95	97	98.9764	88.9712
2014	7	31	6	7	0	0.3	4.6	0.91	96.8	98.9108	85.4902
2014	7	31	6	17	0	0.3	4.6	0.96	95.1	98.8452	90.0911
2014	7	31	6	27	0	0.3	4.6	0.94	95	98.7795	88.7871
2014	7	31	6	37	0	0.3	4.6	0.94	95.6	98.7795	88.1662
2014	7	31	6	47	0	0.3	4.6	0.98	96	98.7139	92.1383
2014	7	31	6	57	0	0.3	4.6	0.91	95	98.7139	85.9337
2014	7	31	7	7	0	0.3	4.6	0.98	96	98.7139	92.1383
2014	7	31	7	17	0	0.3	4.6	0.91	96.6	98.6483	85.5642
2014	7	31	7	27	0	0.3	4.6	0.95	94.8	98.6483	89.2844
2014	7	31	7	37	0	0.3	4.6	0.91	97.9	98.6483	84.9442
2014	7	31	7	47	0	0.3	4.6	0.96	94.5	98.5827	90.152
2014	7	31	7	57	0	0.3	4.6	0.93	95.9	98.5827	87.3638
2014	7	31	8	7	0	0.3	4.6	0.92	94.3	98.5827	86.4344
2014	7	31	8	17	0	0.3	4.6	0.95	94.7	98.5171	89.4704
2014	7	31	8	27	0	0.3	4.6	0.87	94.5	98.5171	81.7307

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	8	37	0	0.3	4.6	0.93	94.6	98.5171	87.6128
2014	7	31	8	47	0	0.3	4.6	0.92	94.7	98.5171	86.6841
2014	7	31	8	57	0	0.3	4.6	0.92	93.3	98.5171	86.3745
2014	7	31	9	7	0	0.3	4.6	0.97	94.7	98.4515	90.9551
2014	7	31	9	17	0	0.3	4.6	0.93	93	98.4515	87.8614
2014	7	31	9	27	0	0.3	4.6	0.95	95.9	98.4515	89.0989
2014	7	31	9	37	0	0.3	4.6	0.96	94.9	98.4515	90.6457
2014	7	31	9	47	0	0.3	4.6	0.92	96.7	98.3858	86.5638
2014	7	31	9	57	0	0.3	4.6	0.94	95.2	98.3858	88.1095
2014	7	31	10	7	0	0.3	4.6	0.91	96.8	98.3202	84.9589
2014	7	31	10	17	0	0.3	4.6	0.92	96.3	98.2546	86.4435
2014	7	31	10	27	0	0.3	4.6	0.92	95.7	98.189	86.0749
2014	7	31	10	37	0	0.3	4.6	0.96	96.9	98.0577	89.0359
2014	7	31	10	47	0	0.3	4.6	0.95	95.7	97.9921	88.6659
2014	7	31	10	57	0	0.3	4.6	0.94	96.8	97.9921	87.4344
2014	7	31	11	7	0	0.3	4.6	0.95	96.1	97.9921	88.9738
2014	7	31	11	17	0	0.3	4.6	0.93	96.3	97.9265	86.4505
2014	7	31	11	27	0	0.3	4.6	0.9	96.7	97.9265	83.3739
2014	7	31	11	37	0	0.3	4.6	0.91	97.8	97.9265	84.9121
2014	7	31	11	47	0	0.3	4.6	0.94	95	97.8609	87.6198
2014	7	31	11	57	0	0.3	4.6	0.93	97.3	97.8609	86.6974
2014	7	31	12	7	0	0.3	4.6	0.91	96.2	97.8609	84.5453
2014	7	31	12	17	0	0.3	4.6	0.95	97.2	97.7953	87.8657
2014	7	31	12	27	0	0.3	4.6	0.94	95.8	97.7953	87.5585
2014	7	31	12	37	0	0.3	4.6	0.89	95.7	97.7953	82.9501
2014	7	31	12	47	0	0.3	4.6	0.9	96.5	97.7953	84.1789
2014	7	31	12	57	0	0.3	4.6	0.95	94.2	97.7297	88.7252
2014	7	31	13	7	0	0.3	4.6	0.92	94.3	97.7297	85.6551
2014	7	31	13	17	0	0.3	4.6	0.94	96.6	97.664	87.4359
2014	7	31	13	27	0	0.3	4.6	0.93	95.1	97.664	86.5155
2014	7	31	13	37	0	0.3	4.6	0.89	94.7	97.5984	82.7761
2014	7	31	13	47	0	0.3	4.6	0.96	94.5	97.4016	89.3327
2014	7	31	13	57	0	0.3	4.6	0.93	95.7	97.4016	86.5793
2014	7	31	14	7	0	0.3	4.6	0.92	93.9	97.336	85.2956
2014	7	31	14	17	0	0.3	4.6	0.93	96.3	97.336	85.9071
2014	7	31	14	27	0	0.3	4.6	0.88	93.6	97.2703	81.5697
2014	7	31	14	37	0	0.3	4.6	0.93	96.9	97.2703	86.1522
2014	7	31	14	47	0	0.3	4.6	0.92	94.3	97.2047	85.1758
2014	7	31	14	57	0	0.3	4.6	0.87	94.3	97.2047	80.5964
2014	7	31	15	7	0	0.3	4.6	0.9	95.9	97.2047	83.344
2014	7	31	15	17	0	0.3	4.6	0.95	95.6	97.1391	87.5565
2014	7	31	15	27	0	0.3	4.6	0.92	95.7	97.1391	85.1159
2014	7	31	15	37	0	0.3	4.6	0.89	94	97.1391	82.9804
2014	7	31	15	47	0	0.3	4.6	0.89	95.1	97.1391	82.0652
2014	7	31	15	57	0	0.3	4.6	0.9	94.8	97.1391	83.2855
2014	7	31	16	7	0	0.3	4.6	0.96	95.5	97.0735	88.7143

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	16	17	0	0.3	4.6	0.9	94.2	96.9423	83.7186
2014	7	31	16	27	0	0.3	4.6	0.92	94.7	97.0079	85.3008
2014	7	31	16	37	0	0.3	4.6	0.94	93	96.9423	87.3717
2014	7	31	16	47	0	0.3	4.6	0.97	93.5	96.9423	90.1116
2014	7	31	16	57	0	0.3	4.6	0.9	94.4	96.8766	83.3553
2014	7	31	17	7	0	0.3	4.3	0.89	95.7	96.811	81.7765
2014	7	31	17	17	0	0.3	4.6	0.9	94.6	97.0079	82.8636
2014	7	31	17	27	0	0.3	4.6	0.93	94.2	96.9423	86.4584
2014	7	31	17	37	0	0.3	4.6	0.92	94.1	96.9423	85.2406
2014	7	31	17	47	0	0.3	4.6	0.93	93	96.9423	86.1539
2014	7	31	17	57	0	0.3	4.3	0.96	95.7	96.811	88.4645
2014	7	31	18	7	0	0.3	4.3	0.9	96.1	96.7454	82.9339
2014	7	31	18	17	0	0.3	4.3	0.93	93.6	96.6798	86.2146
2014	7	31	18	27	0	0.3	4.3	0.94	96.2	96.6798	86.8217
2014	7	31	18	37	0	0.3	4.3	0.95	93.6	96.6142	87.6705
2014	7	31	18	47	0	0.3	4.3	0.89	94.2	96.6142	82.5134
2014	7	31	18	57	0	0.3	4.3	0.92	95.9	96.6142	84.6369
2014	7	31	19	7	0	0.3	4.3	0.98	95	96.6142	90.4007
2014	7	31	19	17	0	0.3	4.3	0.91	96.2	96.5486	83.3644
2014	7	31	19	27	0	0.3	4.3	0.9	93.4	96.6142	82.8167
2014	7	31	19	37	0	0.3	4.3	0.99	94.7	96.5486	91.5493
2014	7	31	19	47	0	0.3	4.3	0.92	93.3	96.5486	85.1833
2014	7	31	19	57	0	0.3	4.3	0.94	93.4	96.5486	87.0021
2014	7	31	20	7	0	0.3	4.3	0.91	93.9	96.5486	83.6676
2014	7	31	20	17	0	0.3	4.3	0.93	93.4	96.5486	85.7896
2014	7	31	20	27	0	0.3	4.3	0.86	93	96.483	79.6703
2014	7	31	20	37	0	0.3	4.3	0.93	95	96.483	85.7289
2014	7	31	20	47	0	0.3	4.3	0.92	95.5	96.483	84.2142
2014	7	31	20	57	0	0.3	4.3	0.9	93.6	96.483	83.0025
2014	7	31	21	7	0	0.3	4.3	0.95	95.7	96.483	87.2436
2014	7	31	21	17	0	0.3	4.3	0.92	93.9	96.483	84.5172
2014	7	31	21	27	0	0.3	4.3	0.95	95.4	96.483	86.9407
2014	7	31	21	37	0	0.3	4.3	0.92	92.9	96.483	84.5172
2014	7	31	21	47	0	0.3	4.3	0.88	94.3	96.483	81.4879
2014	7	31	21	57	0	0.3	4.3	0.91	94.5	96.4173	83.852
2014	7	31	22	7	0	0.3	4.3	0.94	95.2	96.4173	85.971
2014	7	31	22	17	0	0.3	4.3	0.92	93.9	96.4173	84.7601
2014	7	31	22	27	0	0.3	4.3	0.89	94.9	96.4173	81.4303
2014	7	31	22	37	0	0.3	4.3	0.87	91.9	96.4173	80.2194
2014	7	31	22	47	0	0.3	4.3	0.93	93	96.4173	85.3656
2014	7	31	22	57	0	0.3	4.3	0.95	95.5	96.4173	87.4846
2014	7	31	23	7	0	0.3	4.3	0.95	94.7	96.3517	87.7251
2014	7	31	23	17	0	0.3	4.3	0.91	94.1	96.3517	83.7926
2014	7	31	23	27	0	0.3	4.3	0.92	94.7	96.3517	84.0952
2014	7	31	23	37	0	0.3	4.3	0.88	91.9	96.3517	81.0702
2014	7	31	23	47	0	0.3	4.3	0.91	95.2	96.3517	83.7927

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2014	7	31	23	57	0	0.3	4.6	0.93	93.9	96.3517	85.3052

Alabama Gates Release

Station 0087

Date	Flow (cfs)
7/1/2014	0
7/2/2014	0
7/3/2014	0
7/4/2014	0
7/5/2014	0
7/6/2014	0
7/7/2014	0
7/8/2014	0
7/9/2014	0
7/10/2014	0
7/11/2014	0
7/12/2014	0
7/13/2014	0
7/14/2014	0
7/15/2014	0
7/16/2014	0
7/17/2014	0
7/18/2014	0
7/19/2014	0
7/20/2014	0
7/21/2014	0
7/22/2014	0
7/23/2014	0
7/24/2014	0
7/25/2014	0
7/26/2014	0
7/27/2014	0
7/28/2014	0
7/29/2014	0
7/30/2014	0
7/31/2014	0

Pumpback Station Discharge

REPORT_DATE	READING
7/1/2014	35
7/2/2014	35
7/3/2014	34
7/4/2014	34
7/5/2014	34
7/6/2014	33
7/7/2014	33
7/8/2014	34
7/9/2014	36
7/10/2014	38
7/11/2014	39
7/12/2014	38
7/13/2014	39
7/14/2014	38
7/15/2014	39
7/16/2014	40
7/17/2014	40
7/18/2014	40
7/19/2014	41
7/20/2014	40
7/21/2014	32
7/22/2014	25
7/23/2014	30
7/24/2014	26
7/25/2014	28
7/26/2014	27
7/27/2014	27
7/28/2014	25
7/29/2014	28
7/30/2014	29
7/31/2014	40

Langemann Gate to Delta

REPORT_DATE	READING
7/1/2014	8
7/2/2014	8
7/3/2014	8
7/4/2014	8
7/5/2014	8
7/6/2014	8
7/7/2014	8
7/8/2014	8
7/9/2014	8
7/10/2014	8
7/11/2014	8
7/12/2014	8
7/13/2014	8
7/14/2014	8
7/15/2014	7
7/16/2014	8
7/17/2014	8
7/18/2014	8
7/19/2014	8
7/20/2014	7
7/21/2014	16
7/22/2014	20
7/23/2014	20
7/24/2014	20
7/25/2014	20
7/26/2014	20
7/27/2014	20
7/28/2014	20
7/29/2014	20
7/30/2014	20
7/31/2014	11

Pumpback Station Weir to Delta

REPORT_DATE	READING
7/1/2014	0
7/2/2014	0
7/3/2014	0
7/4/2014	0
7/5/2014	0
7/6/2014	0
7/7/2014	0
7/8/2014	0
7/9/2014	0
7/10/2014	0
7/11/2014	0
7/12/2014	0
7/13/2014	0
7/14/2014	0
7/15/2014	0
7/16/2014	0
7/17/2014	0
7/18/2014	0
7/19/2014	0
7/20/2014	0
7/21/2014	0
7/22/2014	0
7/23/2014	0
7/24/2014	0
7/25/2014	0
7/26/2014	0
7/27/2014	0
7/28/2014	0
7/29/2014	0
7/30/2014	0
7/31/2014	1

Pumpback Station Discharge (0364)

7/1/14 0:00 == 34.1	7/1/14 3:55 == 33.6	7/1/14 7:50 == 33.8	7/1/14 11:45 == 33.4
7/1/14 0:05 == 34.1	7/1/14 4:00 == 33.5	7/1/14 7:55 == 34	7/1/14 11:50 == 33.5
7/1/14 0:10 == 34.2	7/1/14 4:05 == 33.7	7/1/14 8:00 == 34	7/1/14 11:55 == 33.7
7/1/14 0:15 == 34.1	7/1/14 4:10 == 33.6	7/1/14 8:05 == 34.1	7/1/14 12:00 == 33.6
7/1/14 0:20 == 34	7/1/14 4:15 == 33.7	7/1/14 8:10 == 34.1	7/1/14 12:05 == 33.5
7/1/14 0:25 == 34.2	7/1/14 4:20 == 33.7	7/1/14 8:15 == 34.1	7/1/14 12:10 == 33.6
7/1/14 0:30 == 34	7/1/14 4:25 == 33.6	7/1/14 8:20 == 34.1	7/1/14 12:15 == 33.6
7/1/14 0:35 == 34.2	7/1/14 4:30 == 33.8	7/1/14 8:25 == 34.1	7/1/14 12:20 == 33.4
7/1/14 0:40 == 34.1	7/1/14 4:35 == 33.7	7/1/14 8:30 == 34	7/1/14 12:25 == 33.7
7/1/14 0:45 == 34.2	7/1/14 4:40 == 33.7	7/1/14 8:35 == 34	7/1/14 12:30 == 33.7
7/1/14 0:50 == 34.1	7/1/14 4:45 == 33.8	7/1/14 8:40 == 34.1	7/1/14 12:35 == 33.7
7/1/14 0:55 == 34.2	7/1/14 4:50 == 33.5	7/1/14 8:45 == 34.3	7/1/14 12:40 == 33.6
7/1/14 1:00 == 34.2	7/1/14 4:55 == 33.7	7/1/14 8:50 == 34	7/1/14 12:45 == 33.8
7/1/14 1:05 == 34.2	7/1/14 5:00 == 33.7	7/1/14 8:55 == 34	7/1/14 12:50 == 33.6
7/1/14 1:10 == 34.2	7/1/14 5:05 == 33.8	7/1/14 9:00 == 34.1	7/1/14 12:55 == 33.8
7/1/14 1:15 == 34.1	7/1/14 5:10 == 33.7	7/1/14 9:05 == 34.1	7/1/14 13:00 == 33.7
7/1/14 1:20 == 34	7/1/14 5:15 == 33.7	7/1/14 9:10 == 34.2	7/1/14 13:05 == 33.8
7/1/14 1:25 == 34	7/1/14 5:20 == 33.8	7/1/14 9:15 == 34.1	7/1/14 13:10 == 33.7
7/1/14 1:30 == 34.1	7/1/14 5:25 == 33.8	7/1/14 9:20 == 34	7/1/14 13:15 == 33.7
7/1/14 1:35 == 34	7/1/14 5:30 == 33.7	7/1/14 9:25 == 34.1	7/1/14 13:20 == 33.7
7/1/14 1:40 == 38	7/1/14 5:35 == 33.9	7/1/14 9:30 == 33.9	7/1/14 13:25 == 33.8
7/1/14 1:45 == 47.8	7/1/14 5:40 == 33.7	7/1/14 9:35 == 34.1	7/1/14 13:30 == 33.7
7/1/14 1:50 == 48.1	7/1/14 5:45 == 33.7	7/1/14 9:40 == 34.1	7/1/14 13:35 == 33.9
7/1/14 1:55 == 48	7/1/14 5:50 == 33.8	7/1/14 9:45 == 34.2	7/1/14 13:40 == 33.7
7/1/14 2:00 == 48	7/1/14 5:55 == 33.9	7/1/14 9:50 == 34	7/1/14 13:45 == 33.8
7/1/14 2:05 == 48	7/1/14 6:00 == 33.9	7/1/14 9:55 == 37.9	7/1/14 13:50 == 33.8
7/1/14 2:10 == 47.9	7/1/14 6:05 == 33.9	7/1/14 10:00 == 47.7	7/1/14 13:55 == 33.9
7/1/14 2:15 == 48	7/1/14 6:10 == 34	7/1/14 10:05 == 48.1	7/1/14 14:00 == 33.8
7/1/14 2:20 == 48	7/1/14 6:15 == 33.9	7/1/14 10:10 == 48	7/1/14 14:05 == 33.8
7/1/14 2:25 == 37.8	7/1/14 6:20 == 33.9	7/1/14 10:15 == 47.9	7/1/14 14:10 == 33.8
7/1/14 2:30 == 33	7/1/14 6:25 == 33.9	7/1/14 10:20 == 47.9	7/1/14 14:15 == 34
7/1/14 2:35 == 32.8	7/1/14 6:30 == 33.9	7/1/14 10:25 == 48	7/1/14 14:20 == 33.9
7/1/14 2:40 == 33.2	7/1/14 6:35 == 33.9	7/1/14 10:30 == 48.1	7/1/14 14:25 == 33.9
7/1/14 2:45 == 33.2	7/1/14 6:40 == 34.1	7/1/14 10:35 == 48.2	7/1/14 14:30 == 34
7/1/14 2:50 == 33.1	7/1/14 6:45 == 33.8	7/1/14 10:40 == 37.6	7/1/14 14:35 == 33.8
7/1/14 2:55 == 33.3	7/1/14 6:50 == 34	7/1/14 10:45 == 32.9	7/1/14 14:40 == 34
7/1/14 3:00 == 33.4	7/1/14 6:55 == 33.9	7/1/14 10:50 == 32.9	7/1/14 14:45 == 34
7/1/14 3:05 == 33.4	7/1/14 7:00 == 33.9	7/1/14 10:55 == 33.1	7/1/14 14:50 == 33.9
7/1/14 3:10 == 33.4	7/1/14 7:05 == 34	7/1/14 11:00 == 33.1	7/1/14 14:55 == 33.9
7/1/14 3:15 == 33.4	7/1/14 7:10 == 33.8	7/1/14 11:05 == 33.3	7/1/14 15:00 == 34
7/1/14 3:20 == 33.5	7/1/14 7:15 == 33.9	7/1/14 11:10 == 33.2	7/1/14 15:05 == 33.8
7/1/14 3:25 == 33.6	7/1/14 7:20 == 33.9	7/1/14 11:15 == 33.3	7/1/14 15:10 == 33.9
7/1/14 3:30 == 33.5	7/1/14 7:25 == 34	7/1/14 11:20 == 33.3	7/1/14 15:15 == 33.9
7/1/14 3:35 == 33.5	7/1/14 7:30 == 33.9	7/1/14 11:25 == 33.3	7/1/14 15:20 == 33.9
7/1/14 3:40 == 33.6	7/1/14 7:35 == 33.9	7/1/14 11:30 == 33.4	7/1/14 15:25 == 33.9
7/1/14 3:45 == 33.6	7/1/14 7:40 == 33.9	7/1/14 11:35 == 33.4	7/1/14 15:30 == 34
7/1/14 3:50 == 33.7	7/1/14 7:45 == 33.9	7/1/14 11:40 == 33.4	7/1/14 15:35 == 33.9

Pumpback Station Discharge (0364)

7/1/14 15:40 == 34	7/1/14 19:35 == 34	7/1/14 23:30 == 33.8	7/2/14 3:25 == 34
7/1/14 15:45 == 33.9	7/1/14 19:40 == 34	7/1/14 23:35 == 33.6	7/2/14 3:30 == 34
7/1/14 15:50 == 33.8	7/1/14 19:45 == 33.9	7/1/14 23:40 == 33.7	7/2/14 3:35 == 34.1
7/1/14 15:55 == 33.8	7/1/14 19:50 == 34	7/1/14 23:45 == 33.7	7/2/14 3:40 == 34
7/1/14 16:00 == 34	7/1/14 19:55 == 34.1	7/1/14 23:50 == 33.7	7/2/14 3:45 == 34.1
7/1/14 16:05 == 33.9	7/1/14 20:00 == 34.1	7/1/14 23:55 == 33.8	7/2/14 3:50 == 34.1
7/1/14 16:10 == 34	7/1/14 20:05 == 34	7/2/14 0:00 == 33.7	7/2/14 3:55 == 34
7/1/14 16:15 == 33.9	7/1/14 20:10 == 33.9	7/2/14 0:05 == 33.7	7/2/14 4:00 == 34
7/1/14 16:20 == 33.8	7/1/14 20:15 == 34.1	7/2/14 0:10 == 33.7	7/2/14 4:05 == 34.2
7/1/14 16:25 == 33.7	7/1/14 20:20 == 33.9	7/2/14 0:15 == 33.6	7/2/14 4:10 == 33.9
7/1/14 16:30 == 33.8	7/1/14 20:25 == 34	7/2/14 0:20 == 33.7	7/2/14 4:15 == 34
7/1/14 16:35 == 33.9	7/1/14 20:30 == 33.9	7/2/14 0:25 == 33.6	7/2/14 4:20 == 34
7/1/14 16:40 == 33.8	7/1/14 20:35 == 34	7/2/14 0:30 == 33.7	7/2/14 4:25 == 34
7/1/14 16:45 == 33.8	7/1/14 20:40 == 39.2	7/2/14 0:35 == 33.7	7/2/14 4:30 == 34.1
7/1/14 16:50 == 33.8	7/1/14 20:45 == 47.7	7/2/14 0:40 == 33.8	7/2/14 4:35 == 34.1
7/1/14 16:55 == 33.9	7/1/14 20:50 == 47.9	7/2/14 0:45 == 33.8	7/2/14 4:40 == 34
7/1/14 17:00 == 33.9	7/1/14 20:55 == 48	7/2/14 0:50 == 33.8	7/2/14 4:45 == 34.2
7/1/14 17:05 == 33.9	7/1/14 21:00 == 47.9	7/2/14 0:55 == 33.8	7/2/14 4:50 == 34
7/1/14 17:10 == 33.9	7/1/14 21:05 == 48.1	7/2/14 1:00 == 33.8	7/2/14 4:55 == 29.4
7/1/14 17:15 == 34	7/1/14 21:10 == 48	7/2/14 1:05 == 33.8	7/2/14 5:00 == 27.9
7/1/14 17:20 == 33.9	7/1/14 21:15 == 48.2	7/2/14 1:10 == 33.7	7/2/14 5:05 == 28.1
7/1/14 17:25 == 34	7/1/14 21:20 == 47.9	7/2/14 1:15 == 33.8	7/2/14 5:10 == 27.9
7/1/14 17:30 == 33.9	7/1/14 21:25 == 36.5	7/2/14 1:20 == 33.8	7/2/14 5:15 == 28.1
7/1/14 17:35 == 33.8	7/1/14 21:30 == 32.8	7/2/14 1:25 == 33.9	7/2/14 5:20 == 28
7/1/14 17:40 == 33.9	7/1/14 21:35 == 32.7	7/2/14 1:30 == 33.8	7/2/14 5:25 == 28
7/1/14 17:45 == 34	7/1/14 21:40 == 33	7/2/14 1:35 == 33.9	7/2/14 5:30 == 28.1
7/1/14 17:50 == 33.8	7/1/14 21:45 == 33.1	7/2/14 1:40 == 33.7	7/2/14 5:35 == 28
7/1/14 17:55 == 34	7/1/14 21:50 == 33.1	7/2/14 1:45 == 33.8	7/2/14 5:40 == 28
7/1/14 18:00 == 33.9	7/1/14 21:55 == 33.2	7/2/14 1:50 == 33.8	7/2/14 5:45 == 28
7/1/14 18:05 == 34	7/1/14 22:00 == 33.3	7/2/14 1:55 == 33.8	7/2/14 5:50 == 40.2
7/1/14 18:10 == 34	7/1/14 22:05 == 33.3	7/2/14 2:00 == 33.8	7/2/14 5:55 == 47.9
7/1/14 18:15 == 33.8	7/1/14 22:10 == 33.4	7/2/14 2:05 == 33.9	7/2/14 6:00 == 48.1
7/1/14 18:20 == 34	7/1/14 22:15 == 33.3	7/2/14 2:10 == 33.9	7/2/14 6:05 == 47.8
7/1/14 18:25 == 33.8	7/1/14 22:20 == 33.4	7/2/14 2:15 == 33.8	7/2/14 6:10 == 47.8
7/1/14 18:30 == 33.9	7/1/14 22:25 == 33.4	7/2/14 2:20 == 34	7/2/14 6:15 == 48
7/1/14 18:35 == 33.8	7/1/14 22:30 == 33.5	7/2/14 2:25 == 33.9	7/2/14 6:20 == 48
7/1/14 18:40 == 33.9	7/1/14 22:35 == 33.5	7/2/14 2:30 == 34	7/2/14 6:25 == 48.1
7/1/14 18:45 == 34	7/1/14 22:40 == 33.5	7/2/14 2:35 == 33.9	7/2/14 6:30 == 47.9
7/1/14 18:50 == 33.9	7/1/14 22:45 == 33.5	7/2/14 2:40 == 34	7/2/14 6:35 == 48.1
7/1/14 18:55 == 33.8	7/1/14 22:50 == 33.5	7/2/14 2:45 == 34	7/2/14 6:40 == 48
7/1/14 19:00 == 34	7/1/14 22:55 == 33.5	7/2/14 2:50 == 34	7/2/14 6:45 == 48
7/1/14 19:05 == 34.1	7/1/14 23:00 == 33.4	7/2/14 2:55 == 34.1	7/2/14 6:50 == 48
7/1/14 19:10 == 34	7/1/14 23:05 == 33.6	7/2/14 3:00 == 34.1	7/2/14 6:55 == 36.3
7/1/14 19:15 == 34	7/1/14 23:10 == 33.5	7/2/14 3:05 == 34	7/2/14 7:00 == 33
7/1/14 19:20 == 34	7/1/14 23:15 == 33.5	7/2/14 3:10 == 34	7/2/14 7:05 == 33
7/1/14 19:25 == 34.1	7/1/14 23:20 == 33.6	7/2/14 3:15 == 34.1	7/2/14 7:10 == 33.5
7/1/14 19:30 == 34	7/1/14 23:25 == 33.6	7/2/14 3:20 == 33.9	7/2/14 7:15 == 33.3

Pumpback Station Discharge (0364)

7/2/14 7:20 == 33.3	7/2/14 11:15 == 33.9	7/2/14 15:10 == 33.3	7/2/14 19:05 == 33.6
7/2/14 7:25 == 33.3	7/2/14 11:20 == 34	7/2/14 15:15 == 33.4	7/2/14 19:10 == 33.4
7/2/14 7:30 == 33.6	7/2/14 11:25 == 33.8	7/2/14 15:20 == 33.2	7/2/14 19:15 == 33.5
7/2/14 7:35 == 33.6	7/2/14 11:30 == 33.9	7/2/14 15:25 == 33.3	7/2/14 19:20 == 33.5
7/2/14 7:40 == 33.5	7/2/14 11:35 == 33.9	7/2/14 15:30 == 33.4	7/2/14 19:25 == 33.5
7/2/14 7:45 == 33.5	7/2/14 11:40 == 33.9	7/2/14 15:35 == 33.4	7/2/14 19:30 == 33.6
7/2/14 7:50 == 33.6	7/2/14 11:45 == 34	7/2/14 15:40 == 33.4	7/2/14 19:35 == 33.7
7/2/14 7:55 == 33.6	7/2/14 11:50 == 34	7/2/14 15:45 == 33.3	7/2/14 19:40 == 33.6
7/2/14 8:00 == 33.6	7/2/14 11:55 == 34	7/2/14 15:50 == 33.3	7/2/14 19:45 == 33.7
7/2/14 8:05 == 33.7	7/2/14 12:00 == 34	7/2/14 15:55 == 33.3	7/2/14 19:50 == 33.6
7/2/14 8:10 == 33.8	7/2/14 12:05 == 34.1	7/2/14 16:00 == 33.3	7/2/14 19:55 == 33.6
7/2/14 8:15 == 33.6	7/2/14 12:10 == 33.9	7/2/14 16:05 == 33.2	7/2/14 20:00 == 33.5
7/2/14 8:20 == 33.7	7/2/14 12:15 == 34.1	7/2/14 16:10 == 33.5	7/2/14 20:05 == 33.6
7/2/14 8:25 == 33.7	7/2/14 12:20 == 34	7/2/14 16:15 == 33.4	7/2/14 20:10 == 33.6
7/2/14 8:30 == 33.9	7/2/14 12:25 == 34	7/2/14 16:20 == 33.5	7/2/14 20:15 == 33.6
7/2/14 8:35 == 33.8	7/2/14 12:30 == 34.1	7/2/14 16:25 == 33.4	7/2/14 20:20 == 33.6
7/2/14 8:40 == 33.8	7/2/14 12:35 == 33.9	7/2/14 16:30 == 33.3	7/2/14 20:25 == 33.5
7/2/14 8:45 == 33.6	7/2/14 12:40 == 34.1	7/2/14 16:35 == 33.5	7/2/14 20:30 == 33.6
7/2/14 8:50 == 33.8	7/2/14 12:45 == 34.1	7/2/14 16:40 == 33.4	7/2/14 20:35 == 33.6
7/2/14 8:55 == 33.9	7/2/14 12:50 == 34.1	7/2/14 16:45 == 33.4	7/2/14 20:40 == 33.5
7/2/14 9:00 == 33.8	7/2/14 12:55 == 34	7/2/14 16:50 == 33.4	7/2/14 20:45 == 33.5
7/2/14 9:05 == 34	7/2/14 13:00 == 33.9	7/2/14 16:55 == 33.3	7/2/14 20:50 == 33.5
7/2/14 9:10 == 33.7	7/2/14 13:05 == 34.1	7/2/14 17:00 == 33.4	7/2/14 20:55 == 33.7
7/2/14 9:15 == 33.8	7/2/14 13:10 == 34.1	7/2/14 17:05 == 33.7	7/2/14 21:00 == 33.6
7/2/14 9:20 == 33.9	7/2/14 13:15 == 34.1	7/2/14 17:10 == 33.5	7/2/14 21:05 == 33.6
7/2/14 9:25 == 33.9	7/2/14 13:20 == 33.9	7/2/14 17:15 == 33.4	7/2/14 21:10 == 33.6
7/2/14 9:30 == 33.8	7/2/14 13:25 == 40.3	7/2/14 17:20 == 33.6	7/2/14 21:15 == 33.6
7/2/14 9:35 == 34	7/2/14 13:30 == 47.8	7/2/14 17:25 == 33.5	7/2/14 21:20 == 33.6
7/2/14 9:40 == 33.9	7/2/14 13:35 == 48.1	7/2/14 17:30 == 33.5	7/2/14 21:25 == 33.6
7/2/14 9:45 == 33.9	7/2/14 13:40 == 47.7	7/2/14 17:35 == 33.4	7/2/14 21:30 == 33.5
7/2/14 9:50 == 33.9	7/2/14 13:45 == 48	7/2/14 17:40 == 33.5	7/2/14 21:35 == 33.6
7/2/14 9:55 == 33.7	7/2/14 13:50 == 48	7/2/14 17:45 == 33.6	7/2/14 21:40 == 33.6
7/2/14 10:00 == 34	7/2/14 13:55 == 47.9	7/2/14 17:50 == 33.5	7/2/14 21:45 == 33.6
7/2/14 10:05 == 33.9	7/2/14 14:00 == 48	7/2/14 17:55 == 33.5	7/2/14 21:50 == 33.9
7/2/14 10:10 == 33.9	7/2/14 14:05 == 48.1	7/2/14 18:00 == 33.5	7/2/14 21:55 == 33.4
7/2/14 10:15 == 33.9	7/2/14 14:10 == 35.4	7/2/14 18:05 == 33.5	7/2/14 22:00 == 33.8
7/2/14 10:20 == 33.8	7/2/14 14:15 == 32.7	7/2/14 18:10 == 33.5	7/2/14 22:05 == 33.8
7/2/14 10:25 == 33.9	7/2/14 14:20 == 32.7	7/2/14 18:15 == 33.4	7/2/14 22:10 == 33.6
7/2/14 10:30 == 33.8	7/2/14 14:25 == 33	7/2/14 18:20 == 33.6	7/2/14 22:15 == 33.7
7/2/14 10:35 == 33.8	7/2/14 14:30 == 32.9	7/2/14 18:25 == 33.5	7/2/14 22:20 == 33.6
7/2/14 10:40 == 33.9	7/2/14 14:35 == 33	7/2/14 18:30 == 33.4	7/2/14 22:25 == 33.8
7/2/14 10:45 == 33.8	7/2/14 14:40 == 33.2	7/2/14 18:35 == 33.5	7/2/14 22:30 == 33.6
7/2/14 10:50 == 33.9	7/2/14 14:45 == 33	7/2/14 18:40 == 33.5	7/2/14 22:35 == 33.7
7/2/14 10:55 == 33.9	7/2/14 14:50 == 33.3	7/2/14 18:45 == 33.4	7/2/14 22:40 == 33.6
7/2/14 11:00 == 33.9	7/2/14 14:55 == 33.1	7/2/14 18:50 == 33.4	7/2/14 22:45 == 33.8
7/2/14 11:05 == 34.2	7/2/14 15:00 == 33.2	7/2/14 18:55 == 33.5	7/2/14 22:50 == 33.6
7/2/14 11:10 == 33.9	7/2/14 15:05 == 33.3	7/2/14 19:00 == 33.5	7/2/14 22:55 == 33.7

Pumpback Station Discharge (0364)

7/2/14 23:00 == 33.7	7/3/14 2:55 == 33.9	7/3/14 6:50 == 34	7/3/14 10:45 == 34.1
7/2/14 23:05 == 33.7	7/3/14 3:00 == 33.8	7/3/14 6:55 == 33.8	7/3/14 10:50 == 34.2
7/2/14 23:10 == 33.7	7/3/14 3:05 == 33.8	7/3/14 7:00 == 34	7/3/14 10:55 == 34
7/2/14 23:15 == 33.7	7/3/14 3:10 == 33.8	7/3/14 7:05 == 34.1	7/3/14 11:00 == 34.2
7/2/14 23:20 == 33.8	7/3/14 3:15 == 33.8	7/3/14 7:10 == 34.1	7/3/14 11:05 == 34.1
7/2/14 23:25 == 33.7	7/3/14 3:20 == 33.8	7/3/14 7:15 == 34	7/3/14 11:10 == 34.1
7/2/14 23:30 == 33.8	7/3/14 3:25 == 33.9	7/3/14 7:20 == 34	7/3/14 11:15 == 34
7/2/14 23:35 == 33.7	7/3/14 3:30 == 33.9	7/3/14 7:25 == 33.9	7/3/14 11:20 == 34.1
7/2/14 23:40 == 33.7	7/3/14 3:35 == 33.8	7/3/14 7:30 == 34	7/3/14 11:25 == 34.1
7/2/14 23:45 == 33.7	7/3/14 3:40 == 33.9	7/3/14 7:35 == 34	7/3/14 11:30 == 34
7/2/14 23:50 == 33.8	7/3/14 3:45 == 33.9	7/3/14 7:40 == 33.9	7/3/14 11:35 == 34.1
7/2/14 23:55 == 33.7	7/3/14 3:50 == 33.8	7/3/14 7:45 == 33.9	7/3/14 11:40 == 34
7/3/14 0:00 == 33.7	7/3/14 3:55 == 33.8	7/3/14 7:50 == 33.9	7/3/14 11:45 == 34.1
7/3/14 0:05 == 33.8	7/3/14 4:00 == 33.9	7/3/14 7:55 == 34	7/3/14 11:50 == 34.2
7/3/14 0:10 == 33.6	7/3/14 4:05 == 33.7	7/3/14 8:00 == 34	7/3/14 11:55 == 34
7/3/14 0:15 == 33.6	7/3/14 4:10 == 33.8	7/3/14 8:05 == 34	7/3/14 12:00 == 34.1
7/3/14 0:20 == 33.6	7/3/14 4:15 == 33.8	7/3/14 8:10 == 34	7/3/14 12:05 == 34.2
7/3/14 0:25 == 33.7	7/3/14 4:20 == 33.9	7/3/14 8:15 == 33.9	7/3/14 12:10 == 34.2
7/3/14 0:30 == 33.6	7/3/14 4:25 == 33.9	7/3/14 8:20 == 34.2	7/3/14 12:15 == 34
7/3/14 0:35 == 33.7	7/3/14 4:30 == 33.9	7/3/14 8:25 == 33.8	7/3/14 12:20 == 33.9
7/3/14 0:40 == 33.7	7/3/14 4:35 == 33.8	7/3/14 8:30 == 33.9	7/3/14 12:25 == 34
7/3/14 0:45 == 33.8	7/3/14 4:40 == 33.9	7/3/14 8:35 == 34	7/3/14 12:30 == 34.1
7/3/14 0:50 == 33.7	7/3/14 4:45 == 33.7	7/3/14 8:40 == 34	7/3/14 12:35 == 34
7/3/14 0:55 == 33.8	7/3/14 4:50 == 33.8	7/3/14 8:45 == 34	7/3/14 12:40 == 34.1
7/3/14 1:00 == 33.8	7/3/14 4:55 == 34	7/3/14 8:50 == 33.9	7/3/14 12:45 == 34
7/3/14 1:05 == 33.6	7/3/14 5:00 == 33.8	7/3/14 8:55 == 34	7/3/14 12:50 == 34.1
7/3/14 1:10 == 33.8	7/3/14 5:05 == 33.8	7/3/14 9:00 == 33.9	7/3/14 12:55 == 34.1
7/3/14 1:15 == 33.8	7/3/14 5:10 == 33.9	7/3/14 9:05 == 34	7/3/14 13:00 == 34.1
7/3/14 1:20 == 33.7	7/3/14 5:15 == 33.9	7/3/14 9:10 == 34.2	7/3/14 13:05 == 34.2
7/3/14 1:25 == 33.8	7/3/14 5:20 == 34	7/3/14 9:15 == 34	7/3/14 13:10 == 34.1
7/3/14 1:30 == 33.7	7/3/14 5:25 == 33.9	7/3/14 9:20 == 34	7/3/14 13:15 == 34.1
7/3/14 1:35 == 33.7	7/3/14 5:30 == 33.8	7/3/14 9:25 == 33.9	7/3/14 13:20 == 34.1
7/3/14 1:40 == 33.8	7/3/14 5:35 == 34	7/3/14 9:30 == 33.9	7/3/14 13:25 == 34.1
7/3/14 1:45 == 33.7	7/3/14 5:40 == 33.8	7/3/14 9:35 == 33.9	7/3/14 13:30 == 34.1
7/3/14 1:50 == 33.8	7/3/14 5:45 == 34	7/3/14 9:40 == 34	7/3/14 13:35 == 34.1
7/3/14 1:55 == 33.7	7/3/14 5:50 == 33.9	7/3/14 9:45 == 33.9	7/3/14 13:40 == 34
7/3/14 2:00 == 33.8	7/3/14 5:55 == 33.9	7/3/14 9:50 == 34.1	7/3/14 13:45 == 34
7/3/14 2:05 == 33.7	7/3/14 6:00 == 34.2	7/3/14 9:55 == 34	7/3/14 13:50 == 34.1
7/3/14 2:10 == 33.8	7/3/14 6:05 == 33.9	7/3/14 10:00 == 34.1	7/3/14 13:55 == 34.1
7/3/14 2:15 == 33.8	7/3/14 6:10 == 33.8	7/3/14 10:05 == 34	7/3/14 14:00 == 33.9
7/3/14 2:20 == 33.7	7/3/14 6:15 == 33.9	7/3/14 10:10 == 34.1	7/3/14 14:05 == 34.1
7/3/14 2:25 == 33.6	7/3/14 6:20 == 34	7/3/14 10:15 == 34.2	7/3/14 14:10 == 34
7/3/14 2:30 == 33.7	7/3/14 6:25 == 33.8	7/3/14 10:20 == 34.1	7/3/14 14:15 == 33.9
7/3/14 2:35 == 33.9	7/3/14 6:30 == 34	7/3/14 10:25 == 34	7/3/14 14:20 == 34
7/3/14 2:40 == 33.7	7/3/14 6:35 == 33.7	7/3/14 10:30 == 34.1	7/3/14 14:25 == 34.1
7/3/14 2:45 == 33.8	7/3/14 6:40 == 33.9	7/3/14 10:35 == 34.3	7/3/14 14:30 == 33.9
7/3/14 2:50 == 33.8	7/3/14 6:45 == 33.9	7/3/14 10:40 == 33.9	7/3/14 14:35 == 33.9

Pumpback Station Discharge (0364)

7/3/14 14:40 == 33.9	7/3/14 18:35 == 33.9	7/3/14 22:30 == 33.9	7/4/14 2:25 == 34
7/3/14 14:45 == 34	7/3/14 18:40 == 33.9	7/3/14 22:35 == 33.9	7/4/14 2:30 == 34.1
7/3/14 14:50 == 34	7/3/14 18:45 == 33.9	7/3/14 22:40 == 34	7/4/14 2:35 == 34.1
7/3/14 14:55 == 33.9	7/3/14 18:50 == 33.8	7/3/14 22:45 == 34	7/4/14 2:40 == 34.1
7/3/14 15:00 == 33.9	7/3/14 18:55 == 33.9	7/3/14 22:50 == 34	7/4/14 2:45 == 34.1
7/3/14 15:05 == 33.9	7/3/14 19:00 == 33.8	7/3/14 22:55 == 34	7/4/14 2:50 == 34.1
7/3/14 15:10 == 33.9	7/3/14 19:05 == 33.9	7/3/14 23:00 == 34	7/4/14 2:55 == 34.1
7/3/14 15:15 == 33.9	7/3/14 19:10 == 33.9	7/3/14 23:05 == 33.9	7/4/14 3:00 == 34
7/3/14 15:20 == 33.9	7/3/14 19:15 == 33.7	7/3/14 23:10 == 34	7/4/14 3:05 == 33.9
7/3/14 15:25 == 33.9	7/3/14 19:20 == 33.8	7/3/14 23:15 == 33.9	7/4/14 3:10 == 34
7/3/14 15:30 == 33.9	7/3/14 19:25 == 34.1	7/3/14 23:20 == 34.1	7/4/14 3:15 == 34
7/3/14 15:35 == 33.8	7/3/14 19:30 == 33.9	7/3/14 23:25 == 33.9	7/4/14 3:20 == 34
7/3/14 15:40 == 33.8	7/3/14 19:35 == 34	7/3/14 23:30 == 34.1	7/4/14 3:25 == 34
7/3/14 15:45 == 33.9	7/3/14 19:40 == 33.9	7/3/14 23:35 == 34	7/4/14 3:30 == 34
7/3/14 15:50 == 33.8	7/3/14 19:45 == 33.9	7/3/14 23:40 == 34	7/4/14 3:35 == 34
7/3/14 15:55 == 33.9	7/3/14 19:50 == 33.9	7/3/14 23:45 == 34.1	7/4/14 3:40 == 34
7/3/14 16:00 == 33.9	7/3/14 19:55 == 33.9	7/3/14 23:50 == 34	7/4/14 3:45 == 34
7/3/14 16:05 == 33.8	7/3/14 20:00 == 34	7/3/14 23:55 == 34	7/4/14 3:50 == 34
7/3/14 16:10 == 33.9	7/3/14 20:05 == 33.8	7/4/14 0:00 == 34	7/4/14 3:55 == 34
7/3/14 16:15 == 34	7/3/14 20:10 == 34	7/4/14 0:05 == 34	7/4/14 4:00 == 33.9
7/3/14 16:20 == 33.9	7/3/14 20:15 == 33.8	7/4/14 0:10 == 34.1	7/4/14 4:05 == 34
7/3/14 16:25 == 33.8	7/3/14 20:20 == 33.8	7/4/14 0:15 == 34	7/4/14 4:10 == 34
7/3/14 16:30 == 33.8	7/3/14 20:25 == 33.9	7/4/14 0:20 == 33.9	7/4/14 4:15 == 34
7/3/14 16:35 == 33.8	7/3/14 20:30 == 33.9	7/4/14 0:25 == 34	7/4/14 4:20 == 33.9
7/3/14 16:40 == 33.9	7/3/14 20:35 == 33.9	7/4/14 0:30 == 34	7/4/14 4:25 == 34
7/3/14 16:45 == 33.8	7/3/14 20:40 == 33.9	7/4/14 0:35 == 33.9	7/4/14 4:30 == 34
7/3/14 16:50 == 33.8	7/3/14 20:45 == 33.9	7/4/14 0:40 == 34	7/4/14 4:35 == 34
7/3/14 16:55 == 33.8	7/3/14 20:50 == 33.8	7/4/14 0:45 == 34.1	7/4/14 4:40 == 33.9
7/3/14 17:00 == 33.9	7/3/14 20:55 == 33.9	7/4/14 0:50 == 34	7/4/14 4:45 == 34
7/3/14 17:05 == 33.9	7/3/14 21:00 == 33.9	7/4/14 0:55 == 33.9	7/4/14 4:50 == 33.9
7/3/14 17:10 == 33.8	7/3/14 21:05 == 33.8	7/4/14 1:00 == 34	7/4/14 4:55 == 34.1
7/3/14 17:15 == 33.8	7/3/14 21:10 == 33.9	7/4/14 1:05 == 34	7/4/14 5:00 == 34
7/3/14 17:20 == 33.9	7/3/14 21:15 == 33.8	7/4/14 1:10 == 34	7/4/14 5:05 == 34
7/3/14 17:25 == 33.8	7/3/14 21:20 == 33.8	7/4/14 1:15 == 34	7/4/14 5:10 == 34
7/3/14 17:30 == 33.9	7/3/14 21:25 == 33.8	7/4/14 1:20 == 34	7/4/14 5:15 == 34
7/3/14 17:35 == 33.9	7/3/14 21:30 == 33.8	7/4/14 1:25 == 34	7/4/14 5:20 == 34
7/3/14 17:40 == 33.8	7/3/14 21:35 == 33.8	7/4/14 1:30 == 33.9	7/4/14 5:25 == 34.2
7/3/14 17:45 == 33.9	7/3/14 21:40 == 33.8	7/4/14 1:35 == 34	7/4/14 5:30 == 34.1
7/3/14 17:50 == 33.9	7/3/14 21:45 == 33.9	7/4/14 1:40 == 34	7/4/14 5:35 == 34.1
7/3/14 17:55 == 33.9	7/3/14 21:50 == 33.9	7/4/14 1:45 == 34	7/4/14 5:40 == 34
7/3/14 18:00 == 33.9	7/3/14 21:55 == 33.9	7/4/14 1:50 == 34.1	7/4/14 5:45 == 34.1
7/3/14 18:05 == 34	7/3/14 22:00 == 34	7/4/14 1:55 == 34	7/4/14 5:50 == 33.9
7/3/14 18:10 == 33.9	7/3/14 22:05 == 34	7/4/14 2:00 == 34.1	7/4/14 5:55 == 34
7/3/14 18:15 == 33.9	7/3/14 22:10 == 33.8	7/4/14 2:05 == 33.9	7/4/14 6:00 == 34
7/3/14 18:20 == 33.9	7/3/14 22:15 == 33.9	7/4/14 2:10 == 34	7/4/14 6:05 == 34
7/3/14 18:25 == 33.9	7/3/14 22:20 == 33.9	7/4/14 2:15 == 34	7/4/14 6:10 == 33.9
7/3/14 18:30 == 33.9	7/3/14 22:25 == 33.8	7/4/14 2:20 == 34	7/4/14 6:15 == 34

Pumpback Station Discharge (0364)

7/4/14 6:20 == 33.9	7/4/14 10:15 == 34.2	7/4/14 14:10 == 34.1	7/4/14 18:05 == 33.8
7/4/14 6:25 == 33.9	7/4/14 10:20 == 34.1	7/4/14 14:15 == 34	7/4/14 18:10 == 33.8
7/4/14 6:30 == 34	7/4/14 10:25 == 34.1	7/4/14 14:20 == 34	7/4/14 18:15 == 33.9
7/4/14 6:35 == 34	7/4/14 10:30 == 34.2	7/4/14 14:25 == 33.8	7/4/14 18:20 == 33.9
7/4/14 6:40 == 34	7/4/14 10:35 == 34.1	7/4/14 14:30 == 34	7/4/14 18:25 == 33.9
7/4/14 6:45 == 34	7/4/14 10:40 == 34.1	7/4/14 14:35 == 33.9	7/4/14 18:30 == 33.8
7/4/14 6:50 == 33.9	7/4/14 10:45 == 34.1	7/4/14 14:40 == 34	7/4/14 18:35 == 33.8
7/4/14 6:55 == 34	7/4/14 10:50 == 34.1	7/4/14 14:45 == 33.9	7/4/14 18:40 == 33.9
7/4/14 7:00 == 34	7/4/14 10:55 == 34.1	7/4/14 14:50 == 33.9	7/4/14 18:45 == 33.9
7/4/14 7:05 == 34	7/4/14 11:00 == 34.1	7/4/14 14:55 == 33.8	7/4/14 18:50 == 33.9
7/4/14 7:10 == 34	7/4/14 11:05 == 34	7/4/14 15:00 == 33.9	7/4/14 18:55 == 33.9
7/4/14 7:15 == 34	7/4/14 11:10 == 34.1	7/4/14 15:05 == 33.8	7/4/14 19:00 == 33.8
7/4/14 7:20 == 33.9	7/4/14 11:15 == 34.1	7/4/14 15:10 == 33.8	7/4/14 19:05 == 33.8
7/4/14 7:25 == 34.2	7/4/14 11:20 == 34.1	7/4/14 15:15 == 33.8	7/4/14 19:10 == 33.7
7/4/14 7:30 == 34.1	7/4/14 11:25 == 34.1	7/4/14 15:20 == 33.7	7/4/14 19:15 == 33.7
7/4/14 7:35 == 34.2	7/4/14 11:30 == 34.1	7/4/14 15:25 == 33.8	7/4/14 19:20 == 33.8
7/4/14 7:40 == 34.1	7/4/14 11:35 == 34	7/4/14 15:30 == 33.8	7/4/14 19:25 == 33.8
7/4/14 7:45 == 34.1	7/4/14 11:40 == 34.1	7/4/14 15:35 == 33.9	7/4/14 19:30 == 33.8
7/4/14 7:50 == 34.1	7/4/14 11:45 == 34.1	7/4/14 15:40 == 33.8	7/4/14 19:35 == 33.8
7/4/14 7:55 == 34.1	7/4/14 11:50 == 34.2	7/4/14 15:45 == 33.8	7/4/14 19:40 == 33.8
7/4/14 8:00 == 34.2	7/4/14 11:55 == 33.9	7/4/14 15:50 == 33.7	7/4/14 19:45 == 33.7
7/4/14 8:05 == 34.1	7/4/14 12:00 == 34	7/4/14 15:55 == 33.7	7/4/14 19:50 == 33.7
7/4/14 8:10 == 34.1	7/4/14 12:05 == 34	7/4/14 16:00 == 33.8	7/4/14 19:55 == 33.8
7/4/14 8:15 == 34	7/4/14 12:10 == 34	7/4/14 16:05 == 33.8	7/4/14 20:00 == 33.8
7/4/14 8:20 == 34.2	7/4/14 12:15 == 34	7/4/14 16:10 == 33.8	7/4/14 20:05 == 33.7
7/4/14 8:25 == 34	7/4/14 12:20 == 34	7/4/14 16:15 == 33.8	7/4/14 20:10 == 33.8
7/4/14 8:30 == 34.1	7/4/14 12:25 == 33.9	7/4/14 16:20 == 33.7	7/4/14 20:15 == 33.8
7/4/14 8:35 == 34.2	7/4/14 12:30 == 34.1	7/4/14 16:25 == 33.8	7/4/14 20:20 == 33.7
7/4/14 8:40 == 34.1	7/4/14 12:35 == 34	7/4/14 16:30 == 33.7	7/4/14 20:25 == 33.8
7/4/14 8:45 == 34.2	7/4/14 12:40 == 34	7/4/14 16:35 == 33.7	7/4/14 20:30 == 33.8
7/4/14 8:50 == 34	7/4/14 12:45 == 34	7/4/14 16:40 == 33.7	7/4/14 20:35 == 33.7
7/4/14 8:55 == 34.1	7/4/14 12:50 == 33.9	7/4/14 16:45 == 33.6	7/4/14 20:40 == 33.7
7/4/14 9:00 == 34.2	7/4/14 12:55 == 34	7/4/14 16:50 == 33.7	7/4/14 20:45 == 33.8
7/4/14 9:05 == 34.1	7/4/14 13:00 == 33.9	7/4/14 16:55 == 33.7	7/4/14 20:50 == 33.8
7/4/14 9:10 == 34.2	7/4/14 13:05 == 34.1	7/4/14 17:00 == 33.8	7/4/14 20:55 == 33.8
7/4/14 9:15 == 34	7/4/14 13:10 == 34	7/4/14 17:05 == 33.8	7/4/14 21:00 == 33.8
7/4/14 9:20 == 34.1	7/4/14 13:15 == 34	7/4/14 17:10 == 33.8	7/4/14 21:05 == 33.7
7/4/14 9:25 == 34.1	7/4/14 13:20 == 34	7/4/14 17:15 == 33.8	7/4/14 21:10 == 33.8
7/4/14 9:30 == 34.2	7/4/14 13:25 == 34.1	7/4/14 17:20 == 33.8	7/4/14 21:15 == 33.7
7/4/14 9:35 == 34.1	7/4/14 13:30 == 34	7/4/14 17:25 == 33.9	7/4/14 21:20 == 33.8
7/4/14 9:40 == 34.1	7/4/14 13:35 == 34	7/4/14 17:30 == 33.8	7/4/14 21:25 == 33.8
7/4/14 9:45 == 34.1	7/4/14 13:40 == 34.1	7/4/14 17:35 == 33.8	7/4/14 21:30 == 33.7
7/4/14 9:50 == 34.2	7/4/14 13:45 == 34	7/4/14 17:40 == 33.8	7/4/14 21:35 == 33.8
7/4/14 9:55 == 34.1	7/4/14 13:50 == 34	7/4/14 17:45 == 33.9	7/4/14 21:40 == 33.8
7/4/14 10:00 == 34.1	7/4/14 13:55 == 34	7/4/14 17:50 == 33.8	7/4/14 21:45 == 33.7
7/4/14 10:05 == 34.1	7/4/14 14:00 == 34.1	7/4/14 17:55 == 33.8	7/4/14 21:50 == 33.7
7/4/14 10:10 == 34.2	7/4/14 14:05 == 33.9	7/4/14 18:00 == 33.9	7/4/14 21:55 == 33.8

Pumpback Station Discharge (0364)

7/4/14 22:00 == 33.8	7/5/14 1:55 == 33.9	7/5/14 5:50 == 33.8	7/5/14 9:45 == 33.9
7/4/14 22:05 == 33.8	7/5/14 2:00 == 33.8	7/5/14 5:55 == 33.8	7/5/14 9:50 == 33.8
7/4/14 22:10 == 33.7	7/5/14 2:05 == 33.8	7/5/14 6:00 == 33.9	7/5/14 9:55 == 33.9
7/4/14 22:15 == 33.7	7/5/14 2:10 == 33.8	7/5/14 6:05 == 33.7	7/5/14 10:00 == 33.7
7/4/14 22:20 == 33.8	7/5/14 2:15 == 33.8	7/5/14 6:10 == 33.7	7/5/14 10:05 == 33.8
7/4/14 22:25 == 33.7	7/5/14 2:20 == 33.8	7/5/14 6:15 == 33.9	7/5/14 10:10 == 33.8
7/4/14 22:30 == 33.9	7/5/14 2:25 == 33.8	7/5/14 6:20 == 33.8	7/5/14 10:15 == 33.8
7/4/14 22:35 == 33.8	7/5/14 2:30 == 33.8	7/5/14 6:25 == 33.7	7/5/14 10:20 == 33.9
7/4/14 22:40 == 33.8	7/5/14 2:35 == 33.8	7/5/14 6:30 == 33.9	7/5/14 10:25 == 33.8
7/4/14 22:45 == 33.9	7/5/14 2:40 == 33.9	7/5/14 6:35 == 33.7	7/5/14 10:30 == 33.8
7/4/14 22:50 == 33.9	7/5/14 2:45 == 33.9	7/5/14 6:40 == 33.8	7/5/14 10:35 == 33.8
7/4/14 22:55 == 33.8	7/5/14 2:50 == 33.8	7/5/14 6:45 == 33.9	7/5/14 10:40 == 33.8
7/4/14 23:00 == 33.9	7/5/14 2:55 == 33.8	7/5/14 6:50 == 33.7	7/5/14 10:45 == 33.8
7/4/14 23:05 == 33.8	7/5/14 3:00 == 33.9	7/5/14 6:55 == 33.8	7/5/14 10:50 == 33.8
7/4/14 23:10 == 33.9	7/5/14 3:05 == 33.9	7/5/14 7:00 == 33.8	7/5/14 10:55 == 33.7
7/4/14 23:15 == 33.8	7/5/14 3:10 == 33.9	7/5/14 7:05 == 33.8	7/5/14 11:00 == 33.8
7/4/14 23:20 == 33.8	7/5/14 3:15 == 33.8	7/5/14 7:10 == 33.8	7/5/14 11:05 == 33.8
7/4/14 23:25 == 34	7/5/14 3:20 == 33.8	7/5/14 7:15 == 33.7	7/5/14 11:10 == 33.8
7/4/14 23:30 == 33.7	7/5/14 3:25 == 33.8	7/5/14 7:20 == 33.8	7/5/14 11:15 == 33.8
7/4/14 23:35 == 33.9	7/5/14 3:30 == 33.9	7/5/14 7:25 == 33.8	7/5/14 11:20 == 33.9
7/4/14 23:40 == 33.8	7/5/14 3:35 == 33.9	7/5/14 7:30 == 33.7	7/5/14 11:25 == 33.8
7/4/14 23:45 == 33.8	7/5/14 3:40 == 33.8	7/5/14 7:35 == 33.7	7/5/14 11:30 == 33.9
7/4/14 23:50 == 33.8	7/5/14 3:45 == 33.7	7/5/14 7:40 == 33.7	7/5/14 11:35 == 33.8
7/4/14 23:55 == 33.8	7/5/14 3:50 == 33.8	7/5/14 7:45 == 33.8	7/5/14 11:40 == 33.9
7/5/14 0:00 == 33.8	7/5/14 3:55 == 33.7	7/5/14 7:50 == 33.9	7/5/14 11:45 == 33.8
7/5/14 0:05 == 33.8	7/5/14 4:00 == 33.8	7/5/14 7:55 == 33.8	7/5/14 11:50 == 33.8
7/5/14 0:10 == 33.8	7/5/14 4:05 == 33.8	7/5/14 8:00 == 33.8	7/5/14 11:55 == 33.8
7/5/14 0:15 == 33.7	7/5/14 4:10 == 33.8	7/5/14 8:05 == 33.8	7/5/14 12:00 == 33.9
7/5/14 0:20 == 33.8	7/5/14 4:15 == 33.8	7/5/14 8:10 == 33.8	7/5/14 12:05 == 33.8
7/5/14 0:25 == 33.9	7/5/14 4:20 == 33.9	7/5/14 8:15 == 33.8	7/5/14 12:10 == 34
7/5/14 0:30 == 33.8	7/5/14 4:25 == 33.8	7/5/14 8:20 == 33.9	7/5/14 12:15 == 33.9
7/5/14 0:35 == 33.9	7/5/14 4:30 == 33.8	7/5/14 8:25 == 33.8	7/5/14 12:20 == 33.8
7/5/14 0:40 == 33.8	7/5/14 4:35 == 33.9	7/5/14 8:30 == 33.8	7/5/14 12:25 == 33.9
7/5/14 0:45 == 33.8	7/5/14 4:40 == 33.9	7/5/14 8:35 == 33.8	7/5/14 12:30 == 33.8
7/5/14 0:50 == 33.9	7/5/14 4:45 == 33.9	7/5/14 8:40 == 33.8	7/5/14 12:35 == 33.9
7/5/14 0:55 == 33.8	7/5/14 4:50 == 33.9	7/5/14 8:45 == 33.8	7/5/14 12:40 == 33.8
7/5/14 1:00 == 33.8	7/5/14 4:55 == 33.8	7/5/14 8:50 == 33.7	7/5/14 12:45 == 33.8
7/5/14 1:05 == 33.7	7/5/14 5:00 == 33.8	7/5/14 8:55 == 33.9	7/5/14 12:50 == 33.9
7/5/14 1:10 == 33.7	7/5/14 5:05 == 33.8	7/5/14 9:00 == 34	7/5/14 12:55 == 33.8
7/5/14 1:15 == 33.8	7/5/14 5:10 == 33.9	7/5/14 9:05 == 33.8	7/5/14 13:00 == 33.7
7/5/14 1:20 == 33.8	7/5/14 5:15 == 33.8	7/5/14 9:10 == 33.9	7/5/14 13:05 == 33.8
7/5/14 1:25 == 33.9	7/5/14 5:20 == 33.8	7/5/14 9:15 == 33.8	7/5/14 13:10 == 33.8
7/5/14 1:30 == 33.8	7/5/14 5:25 == 33.8	7/5/14 9:20 == 33.9	7/5/14 13:15 == 33.8
7/5/14 1:35 == 33.9	7/5/14 5:30 == 33.9	7/5/14 9:25 == 33.8	7/5/14 13:20 == 33.7
7/5/14 1:40 == 33.9	7/5/14 5:35 == 34	7/5/14 9:30 == 33.8	7/5/14 13:25 == 33.8
7/5/14 1:45 == 33.8	7/5/14 5:40 == 33.9	7/5/14 9:35 == 33.9	7/5/14 13:30 == 33.8
7/5/14 1:50 == 33.8	7/5/14 5:45 == 33.9	7/5/14 9:40 == 33.8	7/5/14 13:35 == 33.7

Pumpback Station Discharge (0364)

7/5/14 13:40 == 33.7	7/5/14 17:35 == 33.4	7/5/14 21:30 == 33.4	7/6/14 1:25 == 33.3
7/5/14 13:45 == 33.6	7/5/14 17:40 == 33.5	7/5/14 21:35 == 33.3	7/6/14 1:30 == 33.3
7/5/14 13:50 == 33.6	7/5/14 17:45 == 33.6	7/5/14 21:40 == 33.2	7/6/14 1:35 == 33.4
7/5/14 13:55 == 33.6	7/5/14 17:50 == 33.6	7/5/14 21:45 == 33.3	7/6/14 1:40 == 33.4
7/5/14 14:00 == 33.6	7/5/14 17:55 == 33.4	7/5/14 21:50 == 33.3	7/6/14 1:45 == 33.4
7/5/14 14:05 == 33.6	7/5/14 18:00 == 33.3	7/5/14 21:55 == 33.4	7/6/14 1:50 == 33.3
7/5/14 14:10 == 33.7	7/5/14 18:05 == 33.4	7/5/14 22:00 == 33.2	7/6/14 1:55 == 33.3
7/5/14 14:15 == 33.7	7/5/14 18:10 == 33.3	7/5/14 22:05 == 33.4	7/6/14 2:00 == 33.4
7/5/14 14:20 == 33.7	7/5/14 18:15 == 33.3	7/5/14 22:10 == 33.3	7/6/14 2:05 == 33.2
7/5/14 14:25 == 33.8	7/5/14 18:20 == 33.4	7/5/14 22:15 == 33.4	7/6/14 2:10 == 33.4
7/5/14 14:30 == 33.6	7/5/14 18:25 == 33.4	7/5/14 22:20 == 33.4	7/6/14 2:15 == 33.3
7/5/14 14:35 == 33.6	7/5/14 18:30 == 33.4	7/5/14 22:25 == 33.4	7/6/14 2:20 == 33.2
7/5/14 14:40 == 33.6	7/5/14 18:35 == 33.5	7/5/14 22:30 == 33.5	7/6/14 2:25 == 33.2
7/5/14 14:45 == 33.7	7/5/14 18:40 == 33.3	7/5/14 22:35 == 33.4	7/6/14 2:30 == 33.3
7/5/14 14:50 == 33.6	7/5/14 18:45 == 33.4	7/5/14 22:40 == 33.4	7/6/14 2:35 == 33.3
7/5/14 14:55 == 33.7	7/5/14 18:50 == 33.3	7/5/14 22:45 == 33.5	7/6/14 2:40 == 33.4
7/5/14 15:00 == 33.6	7/5/14 18:55 == 33.3	7/5/14 22:50 == 33.4	7/6/14 2:45 == 33.4
7/5/14 15:05 == 33.6	7/5/14 19:00 == 33.3	7/5/14 22:55 == 33.4	7/6/14 2:50 == 33.3
7/5/14 15:10 == 33.7	7/5/14 19:05 == 33.4	7/5/14 23:00 == 33.4	7/6/14 2:55 == 33.3
7/5/14 15:15 == 33.7	7/5/14 19:10 == 33.3	7/5/14 23:05 == 33.3	7/6/14 3:00 == 33.4
7/5/14 15:20 == 33.6	7/5/14 19:15 == 33.3	7/5/14 23:10 == 33.5	7/6/14 3:05 == 33.5
7/5/14 15:25 == 33.5	7/5/14 19:20 == 33.3	7/5/14 23:15 == 33.4	7/6/14 3:10 == 33.2
7/5/14 15:30 == 33.6	7/5/14 19:25 == 33.4	7/5/14 23:20 == 33.3	7/6/14 3:15 == 33.2
7/5/14 15:35 == 33.5	7/5/14 19:30 == 33.3	7/5/14 23:25 == 33.3	7/6/14 3:20 == 33.3
7/5/14 15:40 == 33.4	7/5/14 19:35 == 33.4	7/5/14 23:30 == 33.4	7/6/14 3:25 == 33.4
7/5/14 15:45 == 33.5	7/5/14 19:40 == 33.2	7/5/14 23:35 == 33.4	7/6/14 3:30 == 33.3
7/5/14 15:50 == 33.5	7/5/14 19:45 == 33.4	7/5/14 23:40 == 33.4	7/6/14 3:35 == 33.3
7/5/14 15:55 == 33.5	7/5/14 19:50 == 33.4	7/5/14 23:45 == 33.4	7/6/14 3:40 == 33.4
7/5/14 16:00 == 33.5	7/5/14 19:55 == 33.3	7/5/14 23:50 == 33.3	7/6/14 3:45 == 33.2
7/5/14 16:05 == 33.5	7/5/14 20:00 == 33.4	7/5/14 23:55 == 33.4	7/6/14 3:50 == 33.3
7/5/14 16:10 == 33.5	7/5/14 20:05 == 33.3	7/6/14 0:00 == 33.3	7/6/14 3:55 == 33.4
7/5/14 16:15 == 33.5	7/5/14 20:10 == 33.3	7/6/14 0:05 == 33.3	7/6/14 4:00 == 33.3
7/5/14 16:20 == 33.5	7/5/14 20:15 == 33.3	7/6/14 0:10 == 33.5	7/6/14 4:05 == 33.4
7/5/14 16:25 == 33.5	7/5/14 20:20 == 33.3	7/6/14 0:15 == 33.2	7/6/14 4:10 == 33.3
7/5/14 16:30 == 33.5	7/5/14 20:25 == 33.2	7/6/14 0:20 == 33.3	7/6/14 4:15 == 33.3
7/5/14 16:35 == 33.4	7/5/14 20:30 == 33.3	7/6/14 0:25 == 33.2	7/6/14 4:20 == 33.4
7/5/14 16:40 == 33.4	7/5/14 20:35 == 33.3	7/6/14 0:30 == 33.4	7/6/14 4:25 == 33.3
7/5/14 16:45 == 33.4	7/5/14 20:40 == 33.3	7/6/14 0:35 == 33.3	7/6/14 4:30 == 33.4
7/5/14 16:50 == 33.4	7/5/14 20:45 == 33.4	7/6/14 0:40 == 33.3	7/6/14 4:35 == 33.3
7/5/14 16:55 == 33.5	7/5/14 20:50 == 33.4	7/6/14 0:45 == 33.3	7/6/14 4:40 == 33.4
7/5/14 17:00 == 33.4	7/5/14 20:55 == 33.3	7/6/14 0:50 == 33.3	7/6/14 4:45 == 33.3
7/5/14 17:05 == 33.6	7/5/14 21:00 == 33.4	7/6/14 0:55 == 33.3	7/6/14 4:50 == 33.3
7/5/14 17:10 == 33.6	7/5/14 21:05 == 33.3	7/6/14 1:00 == 33.4	7/6/14 4:55 == 33.3
7/5/14 17:15 == 33.6	7/5/14 21:10 == 33.4	7/6/14 1:05 == 33.3	7/6/14 5:00 == 33.3
7/5/14 17:20 == 33.6	7/5/14 21:15 == 33.3	7/6/14 1:10 == 33.3	7/6/14 5:05 == 33.4
7/5/14 17:25 == 33.5	7/5/14 21:20 == 33.4	7/6/14 1:15 == 33.2	7/6/14 5:10 == 33.3
7/5/14 17:30 == 33.5	7/5/14 21:25 == 33.3	7/6/14 1:20 == 33.4	7/6/14 5:15 == 33.4

Pumpback Station Discharge (0364)

7/6/14 5:20 == 33.2	7/6/14 9:15 == 33.4	7/6/14 13:10 == 33.5	7/6/14 17:05 == 33.1
7/6/14 5:25 == 33.3	7/6/14 9:20 == 33.4	7/6/14 13:15 == 33.3	7/6/14 17:10 == 33.2
7/6/14 5:30 == 33.3	7/6/14 9:25 == 33.3	7/6/14 13:20 == 33.4	7/6/14 17:15 == 33.1
7/6/14 5:35 == 33.4	7/6/14 9:30 == 33.4	7/6/14 13:25 == 33.3	7/6/14 17:20 == 33
7/6/14 5:40 == 33.4	7/6/14 9:35 == 33.3	7/6/14 13:30 == 33.4	7/6/14 17:25 == 33.1
7/6/14 5:45 == 33.4	7/6/14 9:40 == 33.3	7/6/14 13:35 == 33.3	7/6/14 17:30 == 33.1
7/6/14 5:50 == 33.3	7/6/14 9:45 == 33.4	7/6/14 13:40 == 33.3	7/6/14 17:35 == 33.1
7/6/14 5:55 == 33.3	7/6/14 9:50 == 33.3	7/6/14 13:45 == 33.4	7/6/14 17:40 == 33.1
7/6/14 6:00 == 33.3	7/6/14 9:55 == 33.3	7/6/14 13:50 == 33.4	7/6/14 17:45 == 33.1
7/6/14 6:05 == 33.4	7/6/14 10:00 == 33.4	7/6/14 13:55 == 33.4	7/6/14 17:50 == 33.1
7/6/14 6:10 == 33.3	7/6/14 10:05 == 33.4	7/6/14 14:00 == 33.3	7/6/14 17:55 == 33
7/6/14 6:15 == 33.3	7/6/14 10:10 == 33.4	7/6/14 14:05 == 33.4	7/6/14 18:00 == 33.1
7/6/14 6:20 == 33.3	7/6/14 10:15 == 33.4	7/6/14 14:10 == 33.3	7/6/14 18:05 == 33
7/6/14 6:25 == 33.4	7/6/14 10:20 == 33.3	7/6/14 14:15 == 33.3	7/6/14 18:10 == 33
7/6/14 6:30 == 33.3	7/6/14 10:25 == 33.2	7/6/14 14:20 == 33.2	7/6/14 18:15 == 33
7/6/14 6:35 == 33.3	7/6/14 10:30 == 33.3	7/6/14 14:25 == 33.2	7/6/14 18:20 == 33
7/6/14 6:40 == 33.3	7/6/14 10:35 == 33.4	7/6/14 14:30 == 33.2	7/6/14 18:25 == 33.1
7/6/14 6:45 == 33.3	7/6/14 10:40 == 33.4	7/6/14 14:35 == 33.2	7/6/14 18:30 == 33
7/6/14 6:50 == 33.2	7/6/14 10:45 == 33.3	7/6/14 14:40 == 33.2	7/6/14 18:35 == 33
7/6/14 6:55 == 33.3	7/6/14 10:50 == 33.2	7/6/14 14:45 == 33.1	7/6/14 18:40 == 33
7/6/14 7:00 == 33.4	7/6/14 10:55 == 33.3	7/6/14 14:50 == 33.2	7/6/14 18:45 == 33.1
7/6/14 7:05 == 33.4	7/6/14 11:00 == 33.4	7/6/14 14:55 == 33.2	7/6/14 18:50 == 33.2
7/6/14 7:10 == 33.3	7/6/14 11:05 == 33.3	7/6/14 15:00 == 33.1	7/6/14 18:55 == 33.1
7/6/14 7:15 == 33.2	7/6/14 11:10 == 33.3	7/6/14 15:05 == 33.1	7/6/14 19:00 == 33.1
7/6/14 7:20 == 33.3	7/6/14 11:15 == 33.3	7/6/14 15:10 == 33.1	7/6/14 19:05 == 33
7/6/14 7:25 == 33.3	7/6/14 11:20 == 33.4	7/6/14 15:15 == 33.1	7/6/14 19:10 == 33
7/6/14 7:30 == 33.3	7/6/14 11:25 == 33.4	7/6/14 15:20 == 33.1	7/6/14 19:15 == 33
7/6/14 7:35 == 33.3	7/6/14 11:30 == 33.3	7/6/14 15:25 == 33.1	7/6/14 19:20 == 33
7/6/14 7:40 == 33.4	7/6/14 11:35 == 33.4	7/6/14 15:30 == 33.2	7/6/14 19:25 == 33.1
7/6/14 7:45 == 33.3	7/6/14 11:40 == 33.3	7/6/14 15:35 == 33.1	7/6/14 19:30 == 33.1
7/6/14 7:50 == 33.4	7/6/14 11:45 == 33.3	7/6/14 15:40 == 33.1	7/6/14 19:35 == 33.1
7/6/14 7:55 == 33.3	7/6/14 11:50 == 33.4	7/6/14 15:45 == 33	7/6/14 19:40 == 33.1
7/6/14 8:00 == 33.4	7/6/14 11:55 == 33.4	7/6/14 15:50 == 33.1	7/6/14 19:45 == 33
7/6/14 8:05 == 33.4	7/6/14 12:00 == 33.3	7/6/14 15:55 == 33	7/6/14 19:50 == 33
7/6/14 8:10 == 33.4	7/6/14 12:05 == 33.4	7/6/14 16:00 == 33.1	7/6/14 19:55 == 33
7/6/14 8:15 == 33.3	7/6/14 12:10 == 33.4	7/6/14 16:05 == 33	7/6/14 20:00 == 33
7/6/14 8:20 == 33.3	7/6/14 12:15 == 33.4	7/6/14 16:10 == 33	7/6/14 20:05 == 33
7/6/14 8:25 == 33.4	7/6/14 12:20 == 33.4	7/6/14 16:15 == 33.1	7/6/14 20:10 == 33
7/6/14 8:30 == 33.4	7/6/14 12:25 == 33.4	7/6/14 16:20 == 33	7/6/14 20:15 == 33.1
7/6/14 8:35 == 33.4	7/6/14 12:30 == 33.4	7/6/14 16:25 == 33	7/6/14 20:20 == 33.1
7/6/14 8:40 == 33.4	7/6/14 12:35 == 33.5	7/6/14 16:30 == 33	7/6/14 20:25 == 33.1
7/6/14 8:45 == 33.4	7/6/14 12:40 == 33.3	7/6/14 16:35 == 33	7/6/14 20:30 == 33
7/6/14 8:50 == 33.2	7/6/14 12:45 == 33.4	7/6/14 16:40 == 33.2	7/6/14 20:35 == 33.1
7/6/14 8:55 == 33.3	7/6/14 12:50 == 33.4	7/6/14 16:45 == 33.1	7/6/14 20:40 == 33.1
7/6/14 9:00 == 33.3	7/6/14 12:55 == 33.5	7/6/14 16:50 == 33.1	7/6/14 20:45 == 33
7/6/14 9:05 == 33.3	7/6/14 13:00 == 33.4	7/6/14 16:55 == 33	7/6/14 20:50 == 33.1
7/6/14 9:10 == 33.4	7/6/14 13:05 == 33.4	7/6/14 17:00 == 33	7/6/14 20:55 == 33.1

Pumpback Station Discharge (0364)

7/6/14 21:00 == 33.1	7/7/14 0:55 == 33.1	7/7/14 4:50 == 33.3	7/7/14 8:45 == 33.3
7/6/14 21:05 == 32.9	7/7/14 1:00 == 33.2	7/7/14 4:55 == 33.1	7/7/14 8:50 == 33.3
7/6/14 21:10 == 33	7/7/14 1:05 == 33.1	7/7/14 5:00 == 33.1	7/7/14 8:55 == 33.2
7/6/14 21:15 == 32.9	7/7/14 1:10 == 33.2	7/7/14 5:05 == 33.2	7/7/14 9:00 == 33.4
7/6/14 21:20 == 33	7/7/14 1:15 == 33.1	7/7/14 5:10 == 33.1	7/7/14 9:05 == 33.4
7/6/14 21:25 == 33	7/7/14 1:20 == 33.2	7/7/14 5:15 == 33.2	7/7/14 9:10 == 33.3
7/6/14 21:30 == 33	7/7/14 1:25 == 33	7/7/14 5:20 == 33.2	7/7/14 9:15 == 33.3
7/6/14 21:35 == 33	7/7/14 1:30 == 33.1	7/7/14 5:25 == 33.3	7/7/14 9:20 == 33.4
7/6/14 21:40 == 33	7/7/14 1:35 == 33.2	7/7/14 5:30 == 33.2	7/7/14 9:25 == 33.3
7/6/14 21:45 == 33.1	7/7/14 1:40 == 33.1	7/7/14 5:35 == 33.1	7/7/14 9:30 == 33.3
7/6/14 21:50 == 33.1	7/7/14 1:45 == 33.1	7/7/14 5:40 == 33.2	7/7/14 9:35 == 33.3
7/6/14 21:55 == 33.1	7/7/14 1:50 == 33.1	7/7/14 5:45 == 33.3	7/7/14 9:40 == 33.4
7/6/14 22:00 == 33	7/7/14 1:55 == 33.1	7/7/14 5:50 == 33.1	7/7/14 9:45 == 33.4
7/6/14 22:05 == 33.1	7/7/14 2:00 == 33.1	7/7/14 5:55 == 33.1	7/7/14 9:50 == 33.2
7/6/14 22:10 == 33.1	7/7/14 2:05 == 33.1	7/7/14 6:00 == 33.2	7/7/14 9:55 == 33.4
7/6/14 22:15 == 33	7/7/14 2:10 == 33.1	7/7/14 6:05 == 33.1	7/7/14 10:00 == 33.3
7/6/14 22:20 == 33	7/7/14 2:15 == 33.2	7/7/14 6:10 == 33.1	7/7/14 10:05 == 33.4
7/6/14 22:25 == 33.1	7/7/14 2:20 == 33.2	7/7/14 6:15 == 33.1	7/7/14 10:10 == 33.3
7/6/14 22:30 == 33.2	7/7/14 2:25 == 33.2	7/7/14 6:20 == 33.1	7/7/14 10:15 == 33.5
7/6/14 22:35 == 33.2	7/7/14 2:30 == 33.2	7/7/14 6:25 == 33.1	7/7/14 10:20 == 33.3
7/6/14 22:40 == 33.1	7/7/14 2:35 == 33.4	7/7/14 6:30 == 33.1	7/7/14 10:25 == 33.3
7/6/14 22:45 == 33.1	7/7/14 2:40 == 33.2	7/7/14 6:35 == 33.1	7/7/14 10:30 == 33.4
7/6/14 22:50 == 33.1	7/7/14 2:45 == 33.2	7/7/14 6:40 == 33.1	7/7/14 10:35 == 33.3
7/6/14 22:55 == 33.1	7/7/14 2:50 == 33.1	7/7/14 6:45 == 33.2	7/7/14 10:40 == 33.3
7/6/14 23:00 == 33.2	7/7/14 2:55 == 33.2	7/7/14 6:50 == 33.2	7/7/14 10:45 == 33.4
7/6/14 23:05 == 33.2	7/7/14 3:00 == 33.2	7/7/14 6:55 == 33.3	7/7/14 10:50 == 33.2
7/6/14 23:10 == 33.2	7/7/14 3:05 == 33.2	7/7/14 7:00 == 33.3	7/7/14 10:55 == 33.3
7/6/14 23:15 == 33.1	7/7/14 3:10 == 33.3	7/7/14 7:05 == 33.1	7/7/14 11:00 == 33.4
7/6/14 23:20 == 33.1	7/7/14 3:15 == 33.1	7/7/14 7:10 == 33.1	7/7/14 11:05 == 33.3
7/6/14 23:25 == 33.1	7/7/14 3:20 == 33.2	7/7/14 7:15 == 33.4	7/7/14 11:10 == 33.3
7/6/14 23:30 == 33.1	7/7/14 3:25 == 33.2	7/7/14 7:20 == 33.3	7/7/14 11:15 == 33.3
7/6/14 23:35 == 33.2	7/7/14 3:30 == 33.2	7/7/14 7:25 == 33.2	7/7/14 11:20 == 33.2
7/6/14 23:40 == 33.2	7/7/14 3:35 == 33.1	7/7/14 7:30 == 33.3	7/7/14 11:25 == 33.3
7/6/14 23:45 == 33.2	7/7/14 3:40 == 33.2	7/7/14 7:35 == 33.3	7/7/14 11:30 == 33.3
7/6/14 23:50 == 33.2	7/7/14 3:45 == 33.2	7/7/14 7:40 == 33.3	7/7/14 11:35 == 33.4
7/6/14 23:55 == 33.1	7/7/14 3:50 == 33	7/7/14 7:45 == 33.2	7/7/14 11:40 == 33.3
7/7/14 0:00 == 33.2	7/7/14 3:55 == 33.1	7/7/14 7:50 == 33.2	7/7/14 11:45 == 33.1
7/7/14 0:05 == 33.2	7/7/14 4:00 == 33.1	7/7/14 7:55 == 33.3	7/7/14 11:50 == 33.4
7/7/14 0:10 == 33	7/7/14 4:05 == 33.2	7/7/14 8:00 == 33.3	7/7/14 11:55 == 33.3
7/7/14 0:15 == 33	7/7/14 4:10 == 33.1	7/7/14 8:05 == 33.3	7/7/14 12:00 == 33.3
7/7/14 0:20 == 33.1	7/7/14 4:15 == 33.1	7/7/14 8:10 == 33.3	7/7/14 12:05 == 33.3
7/7/14 0:25 == 33.2	7/7/14 4:20 == 33.2	7/7/14 8:15 == 33.4	7/7/14 12:10 == 33.3
7/7/14 0:30 == 33.1	7/7/14 4:25 == 33.1	7/7/14 8:20 == 33.3	7/7/14 12:15 == 33.3
7/7/14 0:35 == 33.1	7/7/14 4:30 == 33.2	7/7/14 8:25 == 33.4	7/7/14 12:20 == 33.2
7/7/14 0:40 == 33.1	7/7/14 4:35 == 33.1	7/7/14 8:30 == 33.3	7/7/14 12:25 == 33.3
7/7/14 0:45 == 33.1	7/7/14 4:40 == 33.1	7/7/14 8:35 == 33.3	7/7/14 12:30 == 33.3
7/7/14 0:50 == 33.1	7/7/14 4:45 == 33.2	7/7/14 8:40 == 33.3	7/7/14 12:35 == 33.3

Pumpback Station Discharge (0364)

7/7/14 12:40 == 33.2	7/7/14 16:35 == 33.1	7/7/14 20:30 == 33.1	7/8/14 0:25 == 33.2
7/7/14 12:45 == 33.3	7/7/14 16:40 == 33.1	7/7/14 20:35 == 33	7/8/14 0:30 == 33.3
7/7/14 12:50 == 33.4	7/7/14 16:45 == 33.1	7/7/14 20:40 == 33.1	7/8/14 0:35 == 33.2
7/7/14 12:55 == 32.9	7/7/14 16:50 == 33.1	7/7/14 20:45 == 33.1	7/8/14 0:40 == 33.2
7/7/14 13:00 == 33.2	7/7/14 16:55 == 33.2	7/7/14 20:50 == 33.2	7/8/14 0:45 == 33.2
7/7/14 13:05 == 33.3	7/7/14 17:00 == 33.2	7/7/14 20:55 == 33.2	7/8/14 0:50 == 33.2
7/7/14 13:10 == 33.2	7/7/14 17:05 == 33.1	7/7/14 21:00 == 33.2	7/8/14 0:55 == 33.3
7/7/14 13:15 == 33	7/7/14 17:10 == 33	7/7/14 21:05 == 33.2	7/8/14 1:00 == 33.2
7/7/14 13:20 == 33.2	7/7/14 17:15 == 33	7/7/14 21:10 == 33.2	7/8/14 1:05 == 33.2
7/7/14 13:25 == 33.3	7/7/14 17:20 == 33.1	7/7/14 21:15 == 33.2	7/8/14 1:10 == 33.1
7/7/14 13:30 == 33.3	7/7/14 17:25 == 33.2	7/7/14 21:20 == 33.2	7/8/14 1:15 == 33.3
7/7/14 13:35 == 33.2	7/7/14 17:30 == 33.1	7/7/14 21:25 == 33.3	7/8/14 1:20 == 33.3
7/7/14 13:40 == 33.2	7/7/14 17:35 == 33	7/7/14 21:30 == 33.2	7/8/14 1:25 == 33.2
7/7/14 13:45 == 33.3	7/7/14 17:40 == 33.1	7/7/14 21:35 == 33.3	7/8/14 1:30 == 33.2
7/7/14 13:50 == 33.3	7/7/14 17:45 == 33.1	7/7/14 21:40 == 33.3	7/8/14 1:35 == 33.2
7/7/14 13:55 == 33.3	7/7/14 17:50 == 33.1	7/7/14 21:45 == 33.2	7/8/14 1:40 == 33.3
7/7/14 14:00 == 33.2	7/7/14 17:55 == 33.1	7/7/14 21:50 == 33.3	7/8/14 1:45 == 33.1
7/7/14 14:05 == 33.3	7/7/14 18:00 == 33.1	7/7/14 21:55 == 33.2	7/8/14 1:50 == 33.3
7/7/14 14:10 == 33.2	7/7/14 18:05 == 33.2	7/7/14 22:00 == #	7/8/14 1:55 == 33.3
7/7/14 14:15 == 33.2	7/7/14 18:10 == 33.2	7/7/14 22:05 == 33.3	7/8/14 2:00 == 33.3
7/7/14 14:20 == 33.2	7/7/14 18:15 == 33.2	7/7/14 22:10 == 33.2	7/8/14 2:05 == 33.2
7/7/14 14:25 == 33.1	7/7/14 18:20 == 33.1	7/7/14 22:15 == 33.2	7/8/14 2:10 == 33.2
7/7/14 14:30 == 33.1	7/7/14 18:25 == 33	7/7/14 22:20 == 33.3	7/8/14 2:15 == 33.2
7/7/14 14:35 == 33.2	7/7/14 18:30 == 33.1	7/7/14 22:25 == 33.3	7/8/14 2:20 == 33.3
7/7/14 14:40 == 33.2	7/7/14 18:35 == 33.2	7/7/14 22:30 == 33.2	7/8/14 2:25 == 33.3
7/7/14 14:45 == 33.2	7/7/14 18:40 == 33.2	7/7/14 22:35 == 33.2	7/8/14 2:30 == 33.3
7/7/14 14:50 == 33.1	7/7/14 18:45 == 33.2	7/7/14 22:40 == 33.1	7/8/14 2:35 == 33.2
7/7/14 14:55 == 33.1	7/7/14 18:50 == 33.1	7/7/14 22:45 == 33.3	7/8/14 2:40 == 33.4
7/7/14 15:00 == 33.2	7/7/14 18:55 == 33.1	7/7/14 22:50 == 33.2	7/8/14 2:45 == 33.3
7/7/14 15:05 == 33.2	7/7/14 19:00 == 33.1	7/7/14 22:55 == 33.3	7/8/14 2:50 == 33.4
7/7/14 15:10 == 33.1	7/7/14 19:05 == 33	7/7/14 23:00 == 33.2	7/8/14 2:55 == 33.3
7/7/14 15:15 == 33.2	7/7/14 19:10 == 33.1	7/7/14 23:05 == 33.1	7/8/14 3:00 == 33.3
7/7/14 15:20 == 33.1	7/7/14 19:15 == 33.1	7/7/14 23:10 == 33.2	7/8/14 3:05 == 33.4
7/7/14 15:25 == 33.1	7/7/14 19:20 == 33.1	7/7/14 23:15 == 33.3	7/8/14 3:10 == 33.3
7/7/14 15:30 == 33.1	7/7/14 19:25 == 33.1	7/7/14 23:20 == 33.3	7/8/14 3:15 == 33.2
7/7/14 15:35 == 33	7/7/14 19:30 == 33.1	7/7/14 23:25 == 33.2	7/8/14 3:20 == 33.4
7/7/14 15:40 == 33.1	7/7/14 19:35 == 33.1	7/7/14 23:30 == 33.3	7/8/14 3:25 == 33.4
7/7/14 15:45 == 33	7/7/14 19:40 == 33.1	7/7/14 23:35 == 33.3	7/8/14 3:30 == 33.4
7/7/14 15:50 == 33.1	7/7/14 19:45 == 33.1	7/7/14 23:40 == 33.4	7/8/14 3:35 == 33.6
7/7/14 15:55 == 33.1	7/7/14 19:50 == 33.2	7/7/14 23:45 == 33.4	7/8/14 3:40 == 33.5
7/7/14 16:00 == 33.2	7/7/14 19:55 == 33	7/7/14 23:50 == 33.3	7/8/14 3:45 == 33.4
7/7/14 16:05 == 33.2	7/7/14 20:00 == 33.1	7/7/14 23:55 == 33.4	7/8/14 3:50 == 33.5
7/7/14 16:10 == 33	7/7/14 20:05 == 33.1	7/8/14 0:00 == 33.2	7/8/14 3:55 == 33.5
7/7/14 16:15 == 33.1	7/7/14 20:10 == 33.1	7/8/14 0:05 == 33.3	7/8/14 4:00 == 33.4
7/7/14 16:20 == 33.1	7/7/14 20:15 == 33.1	7/8/14 0:10 == 33.3	7/8/14 4:05 == 33.4
7/7/14 16:25 == 33.1	7/7/14 20:20 == 33.1	7/8/14 0:15 == 33.2	7/8/14 4:10 == 33.3
7/7/14 16:30 == 33.2	7/7/14 20:25 == 33.1	7/8/14 0:20 == 33.2	7/8/14 4:15 == 33.4

Pumpback Station Discharge (0364)

7/8/14 4:20 == 33.3	7/8/14 8:15 == 33.5	7/8/14 12:10 == 33.6	7/8/14 16:05 == 33.8
7/8/14 4:25 == 33.4	7/8/14 8:20 == 33.5	7/8/14 12:15 == 33.4	7/8/14 16:10 == 33.8
7/8/14 4:30 == 33.4	7/8/14 8:25 == 33.6	7/8/14 12:20 == 33.5	7/8/14 16:15 == 33.8
7/8/14 4:35 == 33.3	7/8/14 8:30 == 33.5	7/8/14 12:25 == 33.5	7/8/14 16:20 == 33.7
7/8/14 4:40 == 33.6	7/8/14 8:35 == 33.5	7/8/14 12:30 == 33.5	7/8/14 16:25 == 34.8
7/8/14 4:45 == 33.4	7/8/14 8:40 == 33.5	7/8/14 12:35 == 33.4	7/8/14 16:30 == 47.3
7/8/14 4:50 == 33.3	7/8/14 8:45 == 33.6	7/8/14 12:40 == 33.6	7/8/14 16:35 == 47.5
7/8/14 4:55 == 33.3	7/8/14 8:50 == 33.4	7/8/14 12:45 == 33.4	7/8/14 16:40 == 47.5
7/8/14 5:00 == 33.2	7/8/14 8:55 == 33.4	7/8/14 12:50 == 33.4	7/8/14 16:45 == 47.4
7/8/14 5:05 == 33.3	7/8/14 9:00 == 33.7	7/8/14 12:55 == 33.4	7/8/14 16:50 == 47.4
7/8/14 5:10 == 33.2	7/8/14 9:05 == 33.5	7/8/14 13:00 == 33.5	7/8/14 16:55 == 47.4
7/8/14 5:15 == 33.2	7/8/14 9:10 == 33.7	7/8/14 13:05 == 33.6	7/8/14 17:00 == 47.3
7/8/14 5:20 == 33.3	7/8/14 9:15 == 33.6	7/8/14 13:10 == 33.5	7/8/14 17:05 == 47.2
7/8/14 5:25 == 33.4	7/8/14 9:20 == 33.7	7/8/14 13:15 == 33.5	7/8/14 17:10 == 40.2
7/8/14 5:30 == 33.1	7/8/14 9:25 == 33.5	7/8/14 13:20 == 33.4	7/8/14 17:15 == 32.7
7/8/14 5:35 == 33.4	7/8/14 9:30 == 33.7	7/8/14 13:25 == 33.5	7/8/14 17:20 == 32.5
7/8/14 5:40 == 33.4	7/8/14 9:35 == 33.5	7/8/14 13:30 == 33.6	7/8/14 17:25 == 32.7
7/8/14 5:45 == 33.2	7/8/14 9:40 == 33.5	7/8/14 13:35 == 33.5	7/8/14 17:30 == 32.9
7/8/14 5:50 == 33.3	7/8/14 9:45 == 33.6	7/8/14 13:40 == 33.4	7/8/14 17:35 == 32.9
7/8/14 5:55 == 33.2	7/8/14 9:50 == 33.6	7/8/14 13:45 == 33.4	7/8/14 17:40 == 33
7/8/14 6:00 == 33.2	7/8/14 9:55 == 33.6	7/8/14 13:50 == 33.5	7/8/14 17:45 == 33.1
7/8/14 6:05 == 33.4	7/8/14 10:00 == 33.5	7/8/14 13:55 == 33.5	7/8/14 17:50 == 33.1
7/8/14 6:10 == 33.3	7/8/14 10:05 == 33.6	7/8/14 14:00 == 33.6	7/8/14 17:55 == 33.2
7/8/14 6:15 == 33.4	7/8/14 10:10 == 33.6	7/8/14 14:05 == 33.6	7/8/14 18:00 == 33.1
7/8/14 6:20 == 33.3	7/8/14 10:15 == 33.5	7/8/14 14:10 == 33.6	7/8/14 18:05 == 33.2
7/8/14 6:25 == 33.4	7/8/14 10:20 == 33.5	7/8/14 14:15 == 33.7	7/8/14 18:10 == 33.2
7/8/14 6:30 == 33.3	7/8/14 10:25 == 33.7	7/8/14 14:20 == 33.7	7/8/14 18:15 == 33.3
7/8/14 6:35 == 33.2	7/8/14 10:30 == 33.4	7/8/14 14:25 == 33.6	7/8/14 18:20 == 33.3
7/8/14 6:40 == 33.4	7/8/14 10:35 == 33.6	7/8/14 14:30 == 33.6	7/8/14 18:25 == 33.2
7/8/14 6:45 == 33.3	7/8/14 10:40 == 33.5	7/8/14 14:35 == 33.6	7/8/14 18:30 == 33.4
7/8/14 6:50 == 33.3	7/8/14 10:45 == 33.5	7/8/14 14:40 == 33.7	7/8/14 18:35 == 33.3
7/8/14 6:55 == 33.5	7/8/14 10:50 == 33.6	7/8/14 14:45 == 33.8	7/8/14 18:40 == 33.3
7/8/14 7:00 == 33.3	7/8/14 10:55 == 33.2	7/8/14 14:50 == 33.6	7/8/14 18:45 == 33.4
7/8/14 7:05 == 33.3	7/8/14 11:00 == 33.4	7/8/14 14:55 == 33.9	7/8/14 18:50 == 33.4
7/8/14 7:10 == 33.3	7/8/14 11:05 == 33.3	7/8/14 15:00 == 33.6	7/8/14 18:55 == 33.4
7/8/14 7:15 == 33.2	7/8/14 11:10 == 33.3	7/8/14 15:05 == 33.8	7/8/14 19:00 == 33.3
7/8/14 7:20 == 33.3	7/8/14 11:15 == 33.4	7/8/14 15:10 == 33.7	7/8/14 19:05 == 33.3
7/8/14 7:25 == 33.4	7/8/14 11:20 == 33.4	7/8/14 15:15 == 33.8	7/8/14 19:10 == 33.4
7/8/14 7:30 == 33.3	7/8/14 11:25 == 33.3	7/8/14 15:20 == 33.7	7/8/14 19:15 == 33.5
7/8/14 7:35 == 33.2	7/8/14 11:30 == 33.4	7/8/14 15:25 == 33.8	7/8/14 19:20 == 33.4
7/8/14 7:40 == 33.5	7/8/14 11:35 == 33.5	7/8/14 15:30 == 33.6	7/8/14 19:25 == 33.5
7/8/14 7:45 == 33.5	7/8/14 11:40 == 33.4	7/8/14 15:35 == 33.8	7/8/14 19:30 == 33.5
7/8/14 7:50 == 33.4	7/8/14 11:45 == 33.5	7/8/14 15:40 == 33.7	7/8/14 19:35 == 33.6
7/8/14 7:55 == 33.6	7/8/14 11:50 == 33.4	7/8/14 15:45 == #	7/8/14 19:40 == 33.5
7/8/14 8:00 == 33.5	7/8/14 11:55 == 33.5	7/8/14 15:50 == 33.8	7/8/14 19:45 == 33.5
7/8/14 8:05 == 33.6	7/8/14 12:00 == 33.5	7/8/14 15:55 == 33.7	7/8/14 19:50 == 33.6
7/8/14 8:10 == 33.3	7/8/14 12:05 == 33.5	7/8/14 16:00 == 33.9	7/8/14 19:55 == 33.5

Pumpback Station Discharge (0364)

7/8/14 20:00 == 33.7	7/8/14 23:55 == 47.4	7/9/14 3:50 == 33.8	7/9/14 7:45 == 33.8
7/8/14 20:05 == 33.6	7/9/14 0:00 == 47.4	7/9/14 3:55 == 33.8	7/9/14 7:50 == 33.8
7/8/14 20:10 == 33.6	7/9/14 0:05 == 47.4	7/9/14 4:00 == 33.8	7/9/14 7:55 == 33.9
7/8/14 20:15 == 33.6	7/9/14 0:10 == 47.3	7/9/14 4:05 == 33.8	7/9/14 8:00 == 33.9
7/8/14 20:20 == 33.6	7/9/14 0:15 == 47.4	7/9/14 4:10 == 33.7	7/9/14 8:05 == 33.9
7/8/14 20:25 == 33.5	7/9/14 0:20 == 47.4	7/9/14 4:15 == 33.6	7/9/14 8:10 == 34
7/8/14 20:30 == 33.5	7/9/14 0:25 == 39.3	7/9/14 4:20 == 33.7	7/9/14 8:15 == 34
7/8/14 20:35 == 33.7	7/9/14 0:30 == 32.7	7/9/14 4:25 == 33.8	7/9/14 8:20 == 34
7/8/14 20:40 == 33.7	7/9/14 0:35 == 32.6	7/9/14 4:30 == 33.8	7/9/14 8:25 == 34
7/8/14 20:45 == 33.7	7/9/14 0:40 == 32.7	7/9/14 4:35 == 33.7	7/9/14 8:30 == 33.9
7/8/14 20:50 == 33.7	7/9/14 0:45 == 32.9	7/9/14 4:40 == 33.9	7/9/14 8:35 == 34
7/8/14 20:55 == 33.7	7/9/14 0:50 == 32.9	7/9/14 4:45 == 33.6	7/9/14 8:40 == 34.1
7/8/14 21:00 == 33.7	7/9/14 0:55 == 32.9	7/9/14 4:50 == 33.8	7/9/14 8:45 == 34
7/8/14 21:05 == 33.7	7/9/14 1:00 == 33.1	7/9/14 4:55 == 35.7	7/9/14 8:50 == 34
7/8/14 21:10 == 33.7	7/9/14 1:05 == 33.1	7/9/14 5:00 == 47.4	7/9/14 8:55 == 34
7/8/14 21:15 == 33.7	7/9/14 1:10 == 33	7/9/14 5:05 == 47.4	7/9/14 9:00 == 34
7/8/14 21:20 == 33.7	7/9/14 1:15 == 33.1	7/9/14 5:10 == 47.5	7/9/14 9:05 == 34.1
7/8/14 21:25 == 33.8	7/9/14 1:20 == 33.1	7/9/14 5:15 == 47.4	7/9/14 9:10 == 34.1
7/8/14 21:30 == 33.7	7/9/14 1:25 == 33.1	7/9/14 5:20 == 47.4	7/9/14 9:15 == 34
7/8/14 21:35 == 33.7	7/9/14 1:30 == 33.2	7/9/14 5:25 == 47.4	7/9/14 9:20 == 34
7/8/14 21:40 == 33.8	7/9/14 1:35 == 33.1	7/9/14 5:30 == 47.4	7/9/14 9:25 == 34
7/8/14 21:45 == 33.7	7/9/14 1:40 == 33.3	7/9/14 5:35 == 47.4	7/9/14 9:30 == 34
7/8/14 21:50 == 33.8	7/9/14 1:45 == 33.2	7/9/14 5:40 == 39	7/9/14 9:35 == 34.1
7/8/14 21:55 == 33.8	7/9/14 1:50 == 33.3	7/9/14 5:45 == 32.5	7/9/14 9:40 == 36.1
7/8/14 22:00 == 33.8	7/9/14 1:55 == 33.3	7/9/14 5:50 == 32.5	7/9/14 9:45 == 47.6
7/8/14 22:05 == 33.8	7/9/14 2:00 == 33.4	7/9/14 5:55 == 32.7	7/9/14 9:50 == 47.8
7/8/14 22:10 == 33.8	7/9/14 2:05 == 33.4	7/9/14 6:00 == 32.9	7/9/14 9:55 == 47.8
7/8/14 22:15 == 33.8	7/9/14 2:10 == 33.4	7/9/14 6:05 == 32.8	7/9/14 10:00 == 47.6
7/8/14 22:20 == 33.8	7/9/14 2:15 == 33.4	7/9/14 6:10 == 33	7/9/14 10:05 == 47.8
7/8/14 22:25 == 33.7	7/9/14 2:20 == 33.5	7/9/14 6:15 == 33.1	7/9/14 10:10 == 47.6
7/8/14 22:30 == 33.8	7/9/14 2:25 == 33.5	7/9/14 6:20 == 33	7/9/14 10:15 == 47.8
7/8/14 22:35 == 33.8	7/9/14 2:30 == 33.5	7/9/14 6:25 == 33.1	7/9/14 10:20 == 47.9
7/8/14 22:40 == 33.8	7/9/14 2:35 == 33.5	7/9/14 6:30 == 33.2	7/9/14 10:25 == 39.1
7/8/14 22:45 == 33.7	7/9/14 2:40 == 33.5	7/9/14 6:35 == 33.1	7/9/14 10:30 == 32.8
7/8/14 22:50 == 33.8	7/9/14 2:45 == 33.6	7/9/14 6:40 == 33.2	7/9/14 10:35 == 32.9
7/8/14 22:55 == 33.8	7/9/14 2:50 == 33.5	7/9/14 6:45 == 33.2	7/9/14 10:40 == 32.8
7/8/14 23:00 == 33.9	7/9/14 2:55 == 33.6	7/9/14 6:50 == 33.3	7/9/14 10:45 == 33
7/8/14 23:05 == 33.7	7/9/14 3:00 == 33.6	7/9/14 6:55 == 33.4	7/9/14 10:50 == 33
7/8/14 23:10 == 33.7	7/9/14 3:05 == 33.7	7/9/14 7:00 == 33.2	7/9/14 10:55 == 33.2
7/8/14 23:15 == 33.9	7/9/14 3:10 == 33.7	7/9/14 7:05 == 33.6	7/9/14 11:00 == 33.2
7/8/14 23:20 == 33.7	7/9/14 3:15 == 33.8	7/9/14 7:10 == 33.6	7/9/14 11:05 == 33.5
7/8/14 23:25 == 33.8	7/9/14 3:20 == 33.7	7/9/14 7:15 == 33.6	7/9/14 11:10 == 33.4
7/8/14 23:30 == 33.8	7/9/14 3:25 == 33.7	7/9/14 7:20 == 33.6	7/9/14 11:15 == 33.4
7/8/14 23:35 == 33.8	7/9/14 3:30 == 33.7	7/9/14 7:25 == 33.8	7/9/14 11:20 == 33.3
7/8/14 23:40 == 35.5	7/9/14 3:35 == 33.7	7/9/14 7:30 == 33.7	7/9/14 11:25 == 33.4
7/8/14 23:45 == 47.5	7/9/14 3:40 == 33.9	7/9/14 7:35 == 33.7	7/9/14 11:30 == 33.4
7/8/14 23:50 == 47.4	7/9/14 3:45 == 33.7	7/9/14 7:40 == 33.8	7/9/14 11:35 == 33.5

Pumpback Station Discharge (0364)

7/9/14 11:40 == 33.5	7/9/14 15:35 == 33.5	7/9/14 19:30 == 33.3	7/9/14 23:25 == 33.6
7/9/14 11:45 == 33.4	7/9/14 15:40 == 33.3	7/9/14 19:35 == 33.3	7/9/14 23:30 == 33.6
7/9/14 11:50 == 33.5	7/9/14 15:45 == 33.5	7/9/14 19:40 == 33.4	7/9/14 23:35 == 33.5
7/9/14 11:55 == 33.6	7/9/14 15:50 == 33.4	7/9/14 19:45 == 33.4	7/9/14 23:40 == 33.7
7/9/14 12:00 == 33.6	7/9/14 15:55 == 33.4	7/9/14 19:50 == 33.4	7/9/14 23:45 == 33.8
7/9/14 12:05 == 33.5	7/9/14 16:00 == 33.4	7/9/14 19:55 == 33.4	7/9/14 23:50 == 33.7
7/9/14 12:10 == 33.7	7/9/14 16:05 == 33.4	7/9/14 20:00 == 33.6	7/9/14 23:55 == 33.8
7/9/14 12:15 == 33.7	7/9/14 16:10 == 33.5	7/9/14 20:05 == 33.5	7/10/14 0:00 == 33.8
7/9/14 12:20 == 33.7	7/9/14 16:15 == 33.5	7/9/14 20:10 == 33.6	7/10/14 0:05 == 33.8
7/9/14 12:25 == 33.6	7/9/14 16:20 == 33.6	7/9/14 20:15 == 33.6	7/10/14 0:10 == 33.9
7/9/14 12:30 == 33.7	7/9/14 16:25 == 33.6	7/9/14 20:20 == 33.6	7/10/14 0:15 == 33.8
7/9/14 12:35 == 33.7	7/9/14 16:30 == 33.6	7/9/14 20:25 == 33.6	7/10/14 0:20 == 33.9
7/9/14 12:40 == 33.8	7/9/14 16:35 == 33.5	7/9/14 20:30 == 33.6	7/10/14 0:25 == 37.4
7/9/14 12:45 == 33.8	7/9/14 16:40 == 33.6	7/9/14 20:35 == 33.7	7/10/14 0:30 == 47.4
7/9/14 12:50 == 33.8	7/9/14 16:45 == 33.6	7/9/14 20:40 == 33.7	7/10/14 0:35 == 47.4
7/9/14 12:55 == 33.7	7/9/14 16:50 == 33.7	7/9/14 20:45 == 33.8	7/10/14 0:40 == 47.4
7/9/14 13:00 == 33.9	7/9/14 16:55 == 33.7	7/9/14 20:50 == 33.8	7/10/14 0:45 == 47.4
7/9/14 13:05 == 33.9	7/9/14 17:00 == 33.8	7/9/14 20:55 == 33.9	7/10/14 0:50 == 47.5
7/9/14 13:10 == 33.8	7/9/14 17:05 == 33.8	7/9/14 21:00 == 33.8	7/10/14 0:55 == 47.4
7/9/14 13:15 == 33.8	7/9/14 17:10 == 33.8	7/9/14 21:05 == 33.9	7/10/14 1:00 == 47.5
7/9/14 13:20 == 33.9	7/9/14 17:15 == 33.9	7/9/14 21:10 == 37	7/10/14 1:05 == 47.4
7/9/14 13:25 == 33.9	7/9/14 17:20 == 33.7	7/9/14 21:15 == 47.4	7/10/14 1:10 == 37.6
7/9/14 13:30 == 33.8	7/9/14 17:25 == 33.7	7/9/14 21:20 == 47.4	7/10/14 1:15 == 32.8
7/9/14 13:35 == 33.8	7/9/14 17:30 == 33.8	7/9/14 21:25 == 47.4	7/10/14 1:20 == 32.6
7/9/14 13:40 == 33.8	7/9/14 17:35 == 33.7	7/9/14 21:30 == 47.4	7/10/14 1:25 == 32.8
7/9/14 13:45 == 33.8	7/9/14 17:40 == 36.5	7/9/14 21:35 == 47.4	7/10/14 1:30 == 33
7/9/14 13:50 == 33.9	7/9/14 17:45 == 47.5	7/9/14 21:40 == 47.3	7/10/14 1:35 == 33.1
7/9/14 13:55 == 36.3	7/9/14 17:50 == 47.5	7/9/14 21:45 == 47.4	7/10/14 1:40 == 33.1
7/9/14 14:00 == 47.5	7/9/14 17:55 == 47.5	7/9/14 21:50 == 47.3	7/10/14 1:45 == 33.3
7/9/14 14:05 == 47.5	7/9/14 18:00 == 47.5	7/9/14 21:55 == 38.3	7/10/14 1:50 == 33.3
7/9/14 14:10 == 47.5	7/9/14 18:05 == 47.5	7/9/14 22:00 == 32.8	7/10/14 1:55 == 33.4
7/9/14 14:15 == 47.6	7/9/14 18:10 == 47.4	7/9/14 22:05 == 32.7	7/10/14 2:00 == 33.5
7/9/14 14:20 == 47.5	7/9/14 18:15 == 47.5	7/9/14 22:10 == 32.8	7/10/14 2:05 == 33.6
7/9/14 14:25 == 47.6	7/9/14 18:20 == 47.5	7/9/14 22:15 == 33	7/10/14 2:10 == 33.5
7/9/14 14:30 == 47.6	7/9/14 18:25 == 38.5	7/9/14 22:20 == 33	7/10/14 2:15 == 33.6
7/9/14 14:35 == 47.6	7/9/14 18:30 == 32.7	7/9/14 22:25 == 33.2	7/10/14 2:20 == 33.6
7/9/14 14:40 == 38.7	7/9/14 18:35 == 32.6	7/9/14 22:30 == 33.2	7/10/14 2:25 == 33.7
7/9/14 14:45 == 32.9	7/9/14 18:40 == 32.8	7/9/14 22:35 == 33.3	7/10/14 2:30 == 33.6
7/9/14 14:50 == 32.6	7/9/14 18:45 == 32.9	7/9/14 22:40 == 33.3	7/10/14 2:35 == 33.6
7/9/14 14:55 == 33	7/9/14 18:50 == 33.1	7/9/14 22:45 == 33.4	7/10/14 2:40 == 33.9
7/9/14 15:00 == 33	7/9/14 18:55 == 33.1	7/9/14 22:50 == 33.4	7/10/14 2:45 == 33.8
7/9/14 15:05 == 33	7/9/14 19:00 == 33.1	7/9/14 22:55 == 33.5	7/10/14 2:50 == 33.8
7/9/14 15:10 == 33.2	7/9/14 19:05 == 33.2	7/9/14 23:00 == 33.5	7/10/14 2:55 == 33.8
7/9/14 15:15 == 33.2	7/9/14 19:10 == 33.2	7/9/14 23:05 == 33.5	7/10/14 3:00 == 33.8
7/9/14 15:20 == 33.1	7/9/14 19:15 == 33.3	7/9/14 23:10 == 33.5	7/10/14 3:05 == 33.8
7/9/14 15:25 == 33.3	7/9/14 19:20 == 33.3	7/9/14 23:15 == 33.6	7/10/14 3:10 == 37.4
7/9/14 15:30 == 33.3	7/9/14 19:25 == 33.3	7/9/14 23:20 == 33.5	7/10/14 3:15 == 47.3

Pumpback Station Discharge (0364)

7/10/14 3:20 == 47.6	7/10/14 7:15 == 32.6	7/10/14 11:10 == 33.9	7/10/14 15:05 == 33
7/10/14 3:25 == 47.5	7/10/14 7:20 == 32.6	7/10/14 11:15 == 34	7/10/14 15:10 == 33
7/10/14 3:30 == 47.5	7/10/14 7:25 == 32.9	7/10/14 11:20 == 34	7/10/14 15:15 == 33.2
7/10/14 3:35 == 47.3	7/10/14 7:30 == 33.1	7/10/14 11:25 == 34.1	7/10/14 15:20 == 33.2
7/10/14 3:40 == 47.5	7/10/14 7:35 == 33.1	7/10/14 11:30 == 34.1	7/10/14 15:25 == 33.4
7/10/14 3:45 == 47.5	7/10/14 7:40 == 33.3	7/10/14 11:35 == 34	7/10/14 15:30 == 33.5
7/10/14 3:50 == 47.5	7/10/14 7:45 == 33.4	7/10/14 11:40 == 38	7/10/14 15:35 == 33.5
7/10/14 3:55 == 37.6	7/10/14 7:50 == 33.4	7/10/14 11:45 == 47.5	7/10/14 15:40 == 33.6
7/10/14 4:00 == 32.9	7/10/14 7:55 == 33.4	7/10/14 11:50 == 47.9	7/10/14 15:45 == 33.6
7/10/14 4:05 == 32.8	7/10/14 8:00 == 33.4	7/10/14 11:55 == 47.8	7/10/14 15:50 == 33.5
7/10/14 4:10 == 32.9	7/10/14 8:05 == 33.5	7/10/14 12:00 == 47.9	7/10/14 15:55 == 33.5
7/10/14 4:15 == 33.1	7/10/14 8:10 == 33.6	7/10/14 12:05 == 47.9	7/10/14 16:00 == 33.6
7/10/14 4:20 == 33	7/10/14 8:15 == 33.5	7/10/14 12:10 == 47.8	7/10/14 16:05 == 33.6
7/10/14 4:25 == 33.2	7/10/14 8:20 == 33.6	7/10/14 12:15 == 48	7/10/14 16:10 == 33.6
7/10/14 4:30 == 33.4	7/10/14 8:25 == 33.7	7/10/14 12:20 == 47.9	7/10/14 16:15 == 33.8
7/10/14 4:35 == 33.2	7/10/14 8:30 == 33.7	7/10/14 12:25 == 37.9	7/10/14 16:20 == 33.7
7/10/14 4:40 == 33.4	7/10/14 8:35 == 33.8	7/10/14 12:30 == 33	7/10/14 16:25 == 33.7
7/10/14 4:45 == 33.4	7/10/14 8:40 == 34	7/10/14 12:35 == 33	7/10/14 16:30 == 33.8
7/10/14 4:50 == 33.5	7/10/14 8:45 == 34	7/10/14 12:40 == 33.4	7/10/14 16:35 == 33.8
7/10/14 4:55 == 33.5	7/10/14 8:50 == 34.2	7/10/14 12:45 == 33.2	7/10/14 16:40 == 38.2
7/10/14 5:00 == 33.6	7/10/14 8:55 == 33.9	7/10/14 12:50 == 33.3	7/10/14 16:45 == 47.4
7/10/14 5:05 == 33.6	7/10/14 9:00 == 34.1	7/10/14 12:55 == 33.5	7/10/14 16:50 == 47.7
7/10/14 5:10 == 33.6	7/10/14 9:05 == 34.2	7/10/14 13:00 == 33.6	7/10/14 16:55 == 47.5
7/10/14 5:15 == 33.7	7/10/14 9:10 == 37.8	7/10/14 13:05 == 33.6	7/10/14 17:00 == 47.4
7/10/14 5:20 == 33.7	7/10/14 9:15 == 47.7	7/10/14 13:10 == 33.6	7/10/14 17:05 == 47.4
7/10/14 5:25 == 33.8	7/10/14 9:20 == 47.9	7/10/14 13:15 == 33.7	7/10/14 17:10 == 47.5
7/10/14 5:30 == 34	7/10/14 9:25 == 47.9	7/10/14 13:20 == 33.8	7/10/14 17:15 == 47.6
7/10/14 5:35 == 33.7	7/10/14 9:30 == 47.8	7/10/14 13:25 == 34	7/10/14 17:20 == 47.4
7/10/14 5:40 == 33.7	7/10/14 9:35 == 48	7/10/14 13:30 == 33.8	7/10/14 17:25 == 37
7/10/14 5:45 == 33.9	7/10/14 9:40 == 47.8	7/10/14 13:35 == 34	7/10/14 17:30 == 32.7
7/10/14 5:50 == 33.9	7/10/14 9:45 == 47.9	7/10/14 13:40 == 34	7/10/14 17:35 == 32.8
7/10/14 5:55 == 29.6	7/10/14 9:50 == 47.9	7/10/14 13:45 == 34	7/10/14 17:40 == 32.9
7/10/14 6:00 == 27.5	7/10/14 9:55 == 37.9	7/10/14 13:50 == 34	7/10/14 17:45 == 33.1
7/10/14 6:05 == 27.6	7/10/14 10:00 == 33.1	7/10/14 13:55 == 34.1	7/10/14 17:50 == 33.1
7/10/14 6:10 == 45.1	7/10/14 10:05 == 33.1	7/10/14 14:00 == 34.2	7/10/14 17:55 == 33.2
7/10/14 6:15 == 47.5	7/10/14 10:10 == 33.3	7/10/14 14:05 == 34.1	7/10/14 18:00 == 33.3
7/10/14 6:20 == 47.3	7/10/14 10:15 == 33.4	7/10/14 14:10 == 38.1	7/10/14 18:05 == 33.4
7/10/14 6:25 == 47.4	7/10/14 10:20 == 33.5	7/10/14 14:15 == 47.8	7/10/14 18:10 == 33.5
7/10/14 6:30 == 47.6	7/10/14 10:25 == 33.6	7/10/14 14:20 == 47.7	7/10/14 18:15 == 33.4
7/10/14 6:35 == 47.4	7/10/14 10:30 == 33.5	7/10/14 14:25 == 47.9	7/10/14 18:20 == 33.6
7/10/14 6:40 == 47.2	7/10/14 10:35 == 33.5	7/10/14 14:30 == 47.9	7/10/14 18:25 == 33.5
7/10/14 6:45 == 47.4	7/10/14 10:40 == 33.7	7/10/14 14:35 == 47.5	7/10/14 18:30 == 33.7
7/10/14 6:50 == 47.4	7/10/14 10:45 == 33.7	7/10/14 14:40 == 47.9	7/10/14 18:35 == 33.7
7/10/14 6:55 == 47.6	7/10/14 10:50 == 33.8	7/10/14 14:45 == 47.7	7/10/14 18:40 == 33.7
7/10/14 7:00 == 47.4	7/10/14 10:55 == 33.7	7/10/14 14:50 == 47.8	7/10/14 18:45 == 33.7
7/10/14 7:05 == 47.5	7/10/14 11:00 == 33.8	7/10/14 14:55 == 37.7	7/10/14 18:50 == 33.7
7/10/14 7:10 == 37.5	7/10/14 11:05 == 33.9	7/10/14 15:00 == 32.9	7/10/14 18:55 == 33.8

Pumpback Station Discharge (0364)

7/10/14 19:00 == 33.7	7/10/14 22:55 == 47.5	7/11/14 2:50 == 33.6	7/11/14 6:45 == 47.3
7/10/14 19:05 == 33.8	7/10/14 23:00 == 47.5	7/11/14 2:55 == 33.7	7/11/14 6:50 == 47.5
7/10/14 19:10 == 38.3	7/10/14 23:05 == 47.5	7/11/14 3:00 == 33.7	7/11/14 6:55 == 47.6
7/10/14 19:15 == 47.3	7/10/14 23:10 == 36	7/11/14 3:05 == 33.7	7/11/14 7:00 == 47.4
7/10/14 19:20 == 47.4	7/10/14 23:15 == 32.5	7/11/14 3:10 == 33.8	7/11/14 7:05 == 47.5
7/10/14 19:25 == 47.4	7/10/14 23:20 == 32.5	7/11/14 3:15 == 33.7	7/11/14 7:10 == 35.9
7/10/14 19:30 == 47.3	7/10/14 23:25 == 32.8	7/11/14 3:20 == 33.7	7/11/14 7:15 == 32.7
7/10/14 19:35 == 47.4	7/10/14 23:30 == 32.9	7/11/14 3:25 == 33.9	7/11/14 7:20 == 32.6
7/10/14 19:40 == 47.3	7/10/14 23:35 == 33	7/11/14 3:30 == #	7/11/14 7:25 == 33
7/10/14 19:45 == 47.4	7/10/14 23:40 == 33.2	7/11/14 3:35 == 34	7/11/14 7:30 == 33.2
7/10/14 19:50 == 47.4	7/10/14 23:45 == 33.1	7/11/14 3:40 == 39	7/11/14 7:35 == 33
7/10/14 19:55 == 47.4	7/10/14 23:50 == 33.1	7/11/14 3:45 == 47.3	7/11/14 7:40 == 33.3
7/10/14 20:00 == 47.3	7/10/14 23:55 == 33.3	7/11/14 3:50 == 47.5	7/11/14 7:45 == 33.3
7/10/14 20:05 == 47.4	7/11/14 0:00 == 33.4	7/11/14 3:55 == 47.6	7/11/14 7:50 == 33.3
7/10/14 20:10 == 36.4	7/11/14 0:05 == 33.3	7/11/14 4:00 == 47.5	7/11/14 7:55 == 33.5
7/10/14 20:15 == 32.5	7/11/14 0:10 == 33.5	7/11/14 4:05 == 47.6	7/11/14 8:00 == 33.6
7/10/14 20:20 == 32.6	7/11/14 0:15 == 33.5	7/11/14 4:10 == 47.5	7/11/14 8:05 == 33.6
7/10/14 20:25 == 32.7	7/11/14 0:20 == 33.5	7/11/14 4:15 == 47.4	7/11/14 8:10 == 33.6
7/10/14 20:30 == 32.9	7/11/14 0:25 == 33.6	7/11/14 4:20 == 47.4	7/11/14 8:15 == 33.7
7/10/14 20:35 == 33	7/11/14 0:30 == 33.6	7/11/14 4:25 == 47.5	7/11/14 8:20 == 33.7
7/10/14 20:40 == 33.1	7/11/14 0:35 == 33.7	7/11/14 4:30 == 47.3	7/11/14 8:25 == 33.9
7/10/14 20:45 == 33.1	7/11/14 0:40 == 33.8	7/11/14 4:35 == 47.4	7/11/14 8:30 == 33.8
7/10/14 20:50 == 33.2	7/11/14 0:45 == 33.9	7/11/14 4:40 == 36	7/11/14 8:35 == 34.2
7/10/14 20:55 == 33.3	7/11/14 0:50 == 33.9	7/11/14 4:45 == 32.4	7/11/14 8:40 == 39
7/10/14 21:00 == 33.4	7/11/14 0:55 == 38.8	7/11/14 4:50 == 32.5	7/11/14 8:45 == 47.6
7/10/14 21:05 == 33.3	7/11/14 1:00 == 47.3	7/11/14 4:55 == 32.9	7/11/14 8:50 == 48
7/10/14 21:10 == 33.4	7/11/14 1:05 == 47.5	7/11/14 5:00 == 33	7/11/14 8:55 == 47.7
7/10/14 21:15 == 33.4	7/11/14 1:10 == 47.3	7/11/14 5:05 == 33.2	7/11/14 9:00 == 48
7/10/14 21:20 == 33.5	7/11/14 1:15 == 47.5	7/11/14 5:10 == 33.1	7/11/14 9:05 == 47.9
7/10/14 21:25 == 33.7	7/11/14 1:20 == 47.4	7/11/14 5:15 == 33.3	7/11/14 9:10 == 47.9
7/10/14 21:30 == 33.8	7/11/14 1:25 == 47.5	7/11/14 5:20 == 33.5	7/11/14 9:15 == 48
7/10/14 21:35 == 33.6	7/11/14 1:30 == 47.6	7/11/14 5:25 == 33.5	7/11/14 9:20 == 48
7/10/14 21:40 == 33.8	7/11/14 1:35 == 47.4	7/11/14 5:30 == 33.7	7/11/14 9:25 == 47.9
7/10/14 21:45 == 33.8	7/11/14 1:40 == 47.5	7/11/14 5:35 == 33.6	7/11/14 9:30 == 47.9
7/10/14 21:50 == 33.8	7/11/14 1:45 == 47.4	7/11/14 5:40 == 33.7	7/11/14 9:35 == 47.6
7/10/14 21:55 == 33.9	7/11/14 1:50 == 47.4	7/11/14 5:45 == 33.7	7/11/14 9:40 == 36.2
7/10/14 22:00 == 33.8	7/11/14 1:55 == 36	7/11/14 5:50 == 33.7	7/11/14 9:45 == 32.8
7/10/14 22:05 == 33.9	7/11/14 2:00 == 32.4	7/11/14 5:55 == 33.8	7/11/14 9:50 == 32.8
7/10/14 22:10 == 38.7	7/11/14 2:05 == 32.5	7/11/14 6:00 == 33.9	7/11/14 9:55 == 33.2
7/10/14 22:15 == 47.4	7/11/14 2:10 == 32.9	7/11/14 6:05 == 33.8	7/11/14 10:00 == 33.2
7/10/14 22:20 == 47.5	7/11/14 2:15 == 33	7/11/14 6:10 == 38.8	7/11/14 10:05 == 33.3
7/10/14 22:25 == 47.6	7/11/14 2:20 == 33.1	7/11/14 6:15 == 47.4	7/11/14 10:10 == 33.5
7/10/14 22:30 == 47.5	7/11/14 2:25 == 33.2	7/11/14 6:20 == 47.5	7/11/14 10:15 == 33.7
7/10/14 22:35 == 47.6	7/11/14 2:30 == 33.3	7/11/14 6:25 == 47.5	7/11/14 10:20 == 33.6
7/10/14 22:40 == 47.5	7/11/14 2:35 == 33.3	7/11/14 6:30 == 47.5	7/11/14 10:25 == 33.5
7/10/14 22:45 == 47.6	7/11/14 2:40 == 33.4	7/11/14 6:35 == 47.4	7/11/14 10:30 == 33.7
7/10/14 22:50 == 47.5	7/11/14 2:45 == 33.5	7/11/14 6:40 == 47.4	7/11/14 10:35 == 33.8

Pumpback Station Discharge (0364)

7/11/14 10:40 == 33.7	7/11/14 14:35 == 48	7/11/14 18:30 == 33.2	7/11/14 22:25 == 47.6
7/11/14 10:45 == 33.8	7/11/14 14:40 == 47.9	7/11/14 18:35 == 33.3	7/11/14 22:30 == 47.5
7/11/14 10:50 == 33.9	7/11/14 14:45 == 47.8	7/11/14 18:40 == 33.3	7/11/14 22:35 == 47.4
7/11/14 10:55 == 33.9	7/11/14 14:50 == 47.9	7/11/14 18:45 == 33.4	7/11/14 22:40 == 47.5
7/11/14 11:00 == 34.1	7/11/14 14:55 == 47.6	7/11/14 18:50 == 33.3	7/11/14 22:45 == 47.5
7/11/14 11:05 == 34	7/11/14 15:00 == 47.4	7/11/14 18:55 == 33.6	7/11/14 22:50 == 47.6
7/11/14 11:10 == 34.1	7/11/14 15:05 == 47.5	7/11/14 19:00 == 33.7	7/11/14 22:55 == 47.5
7/11/14 11:15 == 34	7/11/14 15:10 == 35.5	7/11/14 19:05 == 33.6	7/11/14 23:00 == 47.5
7/11/14 11:20 == 34.3	7/11/14 15:15 == 32.3	7/11/14 19:10 == 33.6	7/11/14 23:05 == 47.5
7/11/14 11:25 == 39.3	7/11/14 15:20 == 32.6	7/11/14 19:15 == 33.8	7/11/14 23:10 == 34.5
7/11/14 11:30 == 47.9	7/11/14 15:25 == 32.8	7/11/14 19:20 == 33.8	7/11/14 23:15 == 32.5
7/11/14 11:35 == 47.9	7/11/14 15:30 == 33	7/11/14 19:25 == 33.8	7/11/14 23:20 == 32.6
7/11/14 11:40 == 47.9	7/11/14 15:35 == 32.9	7/11/14 19:30 == 33.7	7/11/14 23:25 == 32.9
7/11/14 11:45 == 48	7/11/14 15:40 == 33.1	7/11/14 19:35 == 33.8	7/11/14 23:30 == 32.9
7/11/14 11:50 == 48	7/11/14 15:45 == 33.3	7/11/14 19:40 == 39.9	7/11/14 23:35 == 32.9
7/11/14 11:55 == 47.9	7/11/14 15:50 == 33.3	7/11/14 19:45 == 47.2	7/11/14 23:40 == 33.3
7/11/14 12:00 == 48	7/11/14 15:55 == 33.2	7/11/14 19:50 == 47.6	7/11/14 23:45 == 33.3
7/11/14 12:05 == 48.1	7/11/14 16:00 == 33.4	7/11/14 19:55 == 47.5	7/11/14 23:50 == 33.3
7/11/14 12:10 == 47.7	7/11/14 16:05 == 33.5	7/11/14 20:00 == 47.4	7/11/14 23:55 == 33.5
7/11/14 12:15 == 47.8	7/11/14 16:10 == 33.5	7/11/14 20:05 == 47.5	7/12/14 0:00 == 33.6
7/11/14 12:20 == 47.8	7/11/14 16:15 == 33.6	7/11/14 20:10 == 47.4	7/12/14 0:05 == 33.4
7/11/14 12:25 == 36.1	7/11/14 16:20 == 33.5	7/11/14 20:15 == 47.5	7/12/14 0:10 == 33.7
7/11/14 12:30 == 32.7	7/11/14 16:25 == 33.7	7/11/14 20:20 == 47.4	7/12/14 0:15 == 33.6
7/11/14 12:35 == 32.9	7/11/14 16:30 == 33.7	7/11/14 20:25 == 47.4	7/12/14 0:20 == 33.7
7/11/14 12:40 == 33.3	7/11/14 16:35 == 33.7	7/11/14 20:30 == 47.3	7/12/14 0:25 == 33.8
7/11/14 12:45 == 33.2	7/11/14 16:40 == 33.8	7/11/14 20:35 == 47.5	7/12/14 0:30 == 33.7
7/11/14 12:50 == 33.2	7/11/14 16:45 == 33.9	7/11/14 20:40 == 34.8	7/12/14 0:35 == 33.8
7/11/14 12:55 == 33.6	7/11/14 16:50 == 33.8	7/11/14 20:45 == 32.5	7/12/14 0:40 == 33.8
7/11/14 13:00 == 33.6	7/11/14 16:55 == 39.7	7/11/14 20:50 == 32.6	7/12/14 0:45 == 33.8
7/11/14 13:05 == 33.6	7/11/14 17:00 == 47.3	7/11/14 20:55 == 32.9	7/12/14 0:50 == 33.9
7/11/14 13:10 == 33.7	7/11/14 17:05 == 47.6	7/11/14 21:00 == 33	7/12/14 0:55 == 40.3
7/11/14 13:15 == 33.7	7/11/14 17:10 == 47.5	7/11/14 21:05 == 33	7/12/14 1:00 == 47.5
7/11/14 13:20 == 33.7	7/11/14 17:15 == 47.6	7/11/14 21:10 == 33.3	7/12/14 1:05 == 47.6
7/11/14 13:25 == 33.8	7/11/14 17:20 == 47.4	7/11/14 21:15 == 33.3	7/12/14 1:10 == 47.5
7/11/14 13:30 == 33.8	7/11/14 17:25 == 47.5	7/11/14 21:20 == 33.3	7/12/14 1:15 == 47.3
7/11/14 13:35 == 33.8	7/11/14 17:30 == 47.5	7/11/14 21:25 == 33.6	7/12/14 1:20 == 47.5
7/11/14 13:40 == 34	7/11/14 17:35 == 47.4	7/11/14 21:30 == 33.5	7/12/14 1:25 == 47.5
7/11/14 13:45 == 33.9	7/11/14 17:40 == 47.6	7/11/14 21:35 == 33.4	7/12/14 1:30 == 47.4
7/11/14 13:50 == 34	7/11/14 17:45 == 47.4	7/11/14 21:40 == 33.7	7/12/14 1:35 == 47.4
7/11/14 13:55 == 34	7/11/14 17:50 == 47.3	7/11/14 21:45 == 33.7	7/12/14 1:40 == 47.5
7/11/14 14:00 == 34.2	7/11/14 17:55 == 35.2	7/11/14 21:50 == 33.7	7/12/14 1:45 == 47.5
7/11/14 14:05 == 34.1	7/11/14 18:00 == 32.6	7/11/14 21:55 == 33.8	7/12/14 1:50 == 47.4
7/11/14 14:10 == 39.7	7/11/14 18:05 == 32.6	7/11/14 22:00 == 33.9	7/12/14 1:55 == 34.6
7/11/14 14:15 == 47.8	7/11/14 18:10 == 32.9	7/11/14 22:05 == 34	7/12/14 2:00 == 32.6
7/11/14 14:20 == 48	7/11/14 18:15 == 33	7/11/14 22:10 == 40.2	7/12/14 2:05 == 32.7
7/11/14 14:25 == 47.8	7/11/14 18:20 == 33.1	7/11/14 22:15 == 47.5	7/12/14 2:10 == 33.2
7/11/14 14:30 == 47.9	7/11/14 18:25 == 33.2	7/11/14 22:20 == 47.4	7/12/14 2:15 == 33.1

Pumpback Station Discharge (0364)

7/12/14 2:20 == 33	7/12/14 6:15 == 47.5	7/12/14 10:10 == 34	7/12/14 14:05 == 47.9
7/12/14 2:25 == 33.4	7/12/14 6:20 == 47.5	7/12/14 10:15 == 34	7/12/14 14:10 == 47.6
7/12/14 2:30 == 33.3	7/12/14 6:25 == 47.6	7/12/14 10:20 == 34.1	7/12/14 14:15 == 47.7
7/12/14 2:35 == 33.4	7/12/14 6:30 == 47.4	7/12/14 10:25 == 34.1	7/12/14 14:20 == 47.4
7/12/14 2:40 == 33.4	7/12/14 6:35 == 47.5	7/12/14 10:30 == 34.2	7/12/14 14:25 == 33.8
7/12/14 2:45 == 33.7	7/12/14 6:40 == 47.3	7/12/14 10:35 == 34.1	7/12/14 14:30 == 32.6
7/12/14 2:50 == 33.6	7/12/14 6:45 == 47.5	7/12/14 10:40 == 41.2	7/12/14 14:35 == 32.6
7/12/14 2:55 == 33.7	7/12/14 6:50 == 47.4	7/12/14 10:45 == 48	7/12/14 14:40 == 33
7/12/14 3:00 == 33.7	7/12/14 6:55 == 34.6	7/12/14 10:50 == 48	7/12/14 14:45 == 33
7/12/14 3:05 == 33.7	7/12/14 7:00 == 32.5	7/12/14 10:55 == 47.9	7/12/14 14:50 == 33
7/12/14 3:10 == 33.9	7/12/14 7:05 == 32.8	7/12/14 11:00 == 48.1	7/12/14 14:55 == 33.3
7/12/14 3:15 == 34	7/12/14 7:10 == 33.2	7/12/14 11:05 == 48	7/12/14 15:00 == 33.2
7/12/14 3:20 == 33.9	7/12/14 7:15 == 33.2	7/12/14 11:10 == 48	7/12/14 15:05 == 33.3
7/12/14 3:25 == 40.2	7/12/14 7:20 == 33.3	7/12/14 11:15 == 47.9	7/12/14 15:10 == 33.4
7/12/14 3:30 == 47.4	7/12/14 7:25 == 33.4	7/12/14 11:20 == 47.8	7/12/14 15:15 == 33.5
7/12/14 3:35 == 47.5	7/12/14 7:30 == 33.5	7/12/14 11:25 == 47.9	7/12/14 15:20 == 33.5
7/12/14 3:40 == 47.6	7/12/14 7:35 == 33.5	7/12/14 11:30 == 47.8	7/12/14 15:25 == 33.6
7/12/14 3:45 == 47.5	7/12/14 7:40 == 33.7	7/12/14 11:35 == 48	7/12/14 15:30 == 33.7
7/12/14 3:50 == 47.6	7/12/14 7:45 == 33.8	7/12/14 11:40 == 34.6	7/12/14 15:35 == 33.6
7/12/14 3:55 == 47.6	7/12/14 7:50 == 33.7	7/12/14 11:45 == 32.8	7/12/14 15:40 == 33.8
7/12/14 4:00 == 47.6	7/12/14 7:55 == 33.9	7/12/14 11:50 == 33	7/12/14 15:45 == 33.8
7/12/14 4:05 == 47.6	7/12/14 8:00 == 33.9	7/12/14 11:55 == 33.3	7/12/14 15:50 == 33.8
7/12/14 4:10 == 47.5	7/12/14 8:05 == 34	7/12/14 12:00 == 33.4	7/12/14 15:55 == 41.4
7/12/14 4:15 == 47.5	7/12/14 8:10 == 34.1	7/12/14 12:05 == 33.4	7/12/14 16:00 == 47.5
7/12/14 4:20 == 47.5	7/12/14 8:15 == 34	7/12/14 12:10 == 33.4	7/12/14 16:05 == 47.5
7/12/14 4:25 == 34.5	7/12/14 8:20 == 34.1	7/12/14 12:15 == 33.7	7/12/14 16:10 == 47.5
7/12/14 4:30 == 32.5	7/12/14 8:25 == 40.7	7/12/14 12:20 == 33.6	7/12/14 16:15 == 47.5
7/12/14 4:35 == 32.6	7/12/14 8:30 == 47.9	7/12/14 12:25 == 33.8	7/12/14 16:20 == 47.5
7/12/14 4:40 == 33	7/12/14 8:35 == 48.1	7/12/14 12:30 == 34	7/12/14 16:25 == 47.4
7/12/14 4:45 == 33	7/12/14 8:40 == 47.9	7/12/14 12:35 == 33.9	7/12/14 16:30 == 47.4
7/12/14 4:50 == 33.1	7/12/14 8:45 == 48.1	7/12/14 12:40 == 33.9	7/12/14 16:35 == 47.5
7/12/14 4:55 == 33.3	7/12/14 8:50 == 47.8	7/12/14 12:45 == 34	7/12/14 16:40 == 47.5
7/12/14 5:00 == 33.4	7/12/14 8:55 == 48.1	7/12/14 12:50 == 33.9	7/12/14 16:45 == 47.3
7/12/14 5:05 == 33.3	7/12/14 9:00 == 47.8	7/12/14 12:55 == 34.1	7/12/14 16:50 == 47.5
7/12/14 5:10 == 33.5	7/12/14 9:05 == 48.1	7/12/14 13:00 == 34.1	7/12/14 16:55 == 33.6
7/12/14 5:15 == 33.6	7/12/14 9:10 == 34.9	7/12/14 13:05 == 34.2	7/12/14 17:00 == 32.5
7/12/14 5:20 == 33.6	7/12/14 9:15 == 33	7/12/14 13:10 == 34.1	7/12/14 17:05 == 32.6
7/12/14 5:25 == 33.7	7/12/14 9:20 == 33.1	7/12/14 13:15 == 34.2	7/12/14 17:10 == 32.8
7/12/14 5:30 == 33.8	7/12/14 9:25 == 33.5	7/12/14 13:20 == 34.2	7/12/14 17:15 == 32.9
7/12/14 5:35 == 33.8	7/12/14 9:30 == 33.6	7/12/14 13:25 == 41.4	7/12/14 17:20 == 33
7/12/14 5:40 == 33.8	7/12/14 9:35 == 33.6	7/12/14 13:30 == 47.9	7/12/14 17:25 == 33.2
7/12/14 5:45 == 33.9	7/12/14 9:40 == 33.7	7/12/14 13:35 == 47.9	7/12/14 17:30 == 33.2
7/12/14 5:50 == 33.8	7/12/14 9:45 == 33.8	7/12/14 13:40 == 47.9	7/12/14 17:35 == 33.3
7/12/14 5:55 == 40.4	7/12/14 9:50 == 33.7	7/12/14 13:45 == 47.8	7/12/14 17:40 == 33.5
7/12/14 6:00 == 47.5	7/12/14 9:55 == 33.9	7/12/14 13:50 == 47.9	7/12/14 17:45 == 33.5
7/12/14 6:05 == 47.6	7/12/14 10:00 == 33.9	7/12/14 13:55 == 48	7/12/14 17:50 == 33.4
7/12/14 6:10 == 47.5	7/12/14 10:05 == 33.9	7/12/14 14:00 == 47.6	7/12/14 17:55 == 33.6

Pumpback Station Discharge (0364)

7/12/14 18:00 == 33.6	7/12/14 21:55 == 47.5	7/13/14 1:50 == 33.3	7/13/14 5:45 == 47.6
7/12/14 18:05 == 33.6	7/12/14 22:00 == 47.5	7/13/14 1:55 == 33.7	7/13/14 5:50 == 47.5
7/12/14 18:10 == 33.8	7/12/14 22:05 == 47.4	7/13/14 2:00 == 33.6	7/13/14 5:55 == 47.6
7/12/14 18:15 == 33.7	7/12/14 22:10 == 47.5	7/13/14 2:05 == 33.7	7/13/14 6:00 == 47.6
7/12/14 18:20 == 33.7	7/12/14 22:15 == 47.3	7/13/14 2:10 == 33.9	7/13/14 6:05 == 47.5
7/12/14 18:25 == 33.8	7/12/14 22:20 == 47.3	7/13/14 2:15 == 33.8	7/13/14 6:10 == 33
7/12/14 18:30 == 33.8	7/12/14 22:25 == 33	7/13/14 2:20 == 33.8	7/13/14 6:15 == 32.6
7/12/14 18:35 == 33.8	7/12/14 22:30 == 32.6	7/13/14 2:25 == 33.9	7/13/14 6:20 == 32.6
7/12/14 18:40 == 41.5	7/12/14 22:35 == 32.6	7/13/14 2:30 == 34	7/13/14 6:25 == 33.1
7/12/14 18:45 == 47.4	7/12/14 22:40 == 33	7/13/14 2:35 == 33.9	7/13/14 6:30 == 33
7/12/14 18:50 == 47.4	7/12/14 22:45 == 33	7/13/14 2:40 == 41.8	7/13/14 6:35 == 33.1
7/12/14 18:55 == 47.4	7/12/14 22:50 == 33.1	7/13/14 2:45 == 47.6	7/13/14 6:40 == 33.4
7/12/14 19:00 == 47.4	7/12/14 22:55 == 33.3	7/13/14 2:50 == 47.7	7/13/14 6:45 == 33.3
7/12/14 19:05 == 47.4	7/12/14 23:00 == 33.3	7/13/14 2:55 == 47.6	7/13/14 6:50 == 33.3
7/12/14 19:10 == 47.4	7/12/14 23:05 == 33.3	7/13/14 3:00 == 47.6	7/13/14 6:55 == 33.6
7/12/14 19:15 == 47.4	7/12/14 23:10 == 33.5	7/13/14 3:05 == 47.6	7/13/14 7:00 == 33.4
7/12/14 19:20 == 47.5	7/12/14 23:15 == 33.6	7/13/14 3:10 == 47.7	7/13/14 7:05 == 33.5
7/12/14 19:25 == 47.4	7/12/14 23:20 == 33.5	7/13/14 3:15 == 47.6	7/13/14 7:10 == 33.6
7/12/14 19:30 == 47.4	7/12/14 23:25 == 33.7	7/13/14 3:20 == 47.5	7/13/14 7:15 == 33.6
7/12/14 19:35 == 47.5	7/12/14 23:30 == 33.6	7/13/14 3:25 == 47.7	7/13/14 7:20 == 33.6
7/12/14 19:40 == 33.1	7/12/14 23:35 == 33.8	7/13/14 3:30 == 47.6	7/13/14 7:25 == 33.9
7/12/14 19:45 == 32.4	7/12/14 23:40 == 33.8	7/13/14 3:35 == 47.5	7/13/14 7:30 == 33.9
7/12/14 19:50 == 32.5	7/12/14 23:45 == 33.8	7/13/14 3:40 == 33.1	7/13/14 7:35 == 33.7
7/12/14 19:55 == 32.9	7/12/14 23:50 == 33.8	7/13/14 3:45 == 32.7	7/13/14 7:40 == 42.4
7/12/14 20:00 == 32.9	7/12/14 23:55 == 33.8	7/13/14 3:50 == 32.7	7/13/14 7:45 == 47.6
7/12/14 20:05 == 32.8	7/13/14 0:00 == 33.8	7/13/14 3:55 == 33.1	7/13/14 7:50 == 47.6
7/12/14 20:10 == 33.3	7/13/14 0:05 == 33.9	7/13/14 4:00 == 33	7/13/14 7:55 == 47.5
7/12/14 20:15 == 33.2	7/13/14 0:10 == 41.5	7/13/14 4:05 == 32.9	7/13/14 8:00 == 47.6
7/12/14 20:20 == 33.2	7/13/14 0:15 == 47.6	7/13/14 4:10 == 33.3	7/13/14 8:05 == 47.6
7/12/14 20:25 == 33.4	7/13/14 0:20 == 47.4	7/13/14 4:15 == 33.2	7/13/14 8:10 == 47.6
7/12/14 20:30 == 33.4	7/13/14 0:25 == 47.5	7/13/14 4:20 == 33.3	7/13/14 8:15 == 47.5
7/12/14 20:35 == 33.5	7/13/14 0:30 == 47.6	7/13/14 4:25 == 33.6	7/13/14 8:20 == 47.6
7/12/14 20:40 == 33.5	7/13/14 0:35 == 47.5	7/13/14 4:30 == 33.5	7/13/14 8:25 == 47.5
7/12/14 20:45 == 33.6	7/13/14 0:40 == 47.5	7/13/14 4:35 == 33.5	7/13/14 8:30 == 47.6
7/12/14 20:50 == 33.6	7/13/14 0:45 == 47.5	7/13/14 4:40 == 33.7	7/13/14 8:35 == 47.5
7/12/14 20:55 == 33.7	7/13/14 0:50 == 47.6	7/13/14 4:45 == 33.7	7/13/14 8:40 == 33.2
7/12/14 21:00 == 33.8	7/13/14 0:55 == 47.5	7/13/14 4:50 == 33.7	7/13/14 8:45 == 32.8
7/12/14 21:05 == 33.7	7/13/14 1:00 == 47.5	7/13/14 4:55 == 33.8	7/13/14 8:50 == 32.8
7/12/14 21:10 == 33.9	7/13/14 1:05 == 47.5	7/13/14 5:00 == 33.8	7/13/14 8:55 == 33.4
7/12/14 21:15 == 33.9	7/13/14 1:10 == 33	7/13/14 5:05 == 33.8	7/13/14 9:00 == 33.5
7/12/14 21:20 == 33.8	7/13/14 1:15 == 32.6	7/13/14 5:10 == 41.8	7/13/14 9:05 == 33.3
7/12/14 21:25 == 41.5	7/13/14 1:20 == 32.6	7/13/14 5:15 == 47.6	7/13/14 9:10 == 33.6
7/12/14 21:30 == 47.5	7/13/14 1:25 == 33	7/13/14 5:20 == 47.5	7/13/14 9:15 == 33.7
7/12/14 21:35 == 47.5	7/13/14 1:30 == 33.2	7/13/14 5:25 == 47.6	7/13/14 9:20 == 33.6
7/12/14 21:40 == 47.5	7/13/14 1:35 == 33.2	7/13/14 5:30 == 47.6	7/13/14 9:25 == 33.7
7/12/14 21:45 == 47.6	7/13/14 1:40 == 33.4	7/13/14 5:35 == 47.6	7/13/14 9:30 == 33.6
7/12/14 21:50 == 47.5	7/13/14 1:45 == 33.4	7/13/14 5:40 == 47.6	7/13/14 9:35 == 33.8

Pumpback Station Discharge (0364)

7/13/14 9:40 == 33.9	7/13/14 13:35 == 47.6	7/13/14 17:30 == 33.5	7/13/14 21:25 == 47.4
7/13/14 9:45 == 33.9	7/13/14 13:40 == 47.6	7/13/14 17:35 == 33.6	7/13/14 21:30 == 47.4
7/13/14 9:50 == 33.9	7/13/14 13:45 == 47.4	7/13/14 17:40 == 33.6	7/13/14 21:35 == 47.4
7/13/14 9:55 == 34	7/13/14 13:50 == 46.4	7/13/14 17:45 == 33.7	7/13/14 21:40 == 47.5
7/13/14 10:00 == 34	7/13/14 13:55 == 32.8	7/13/14 17:50 == 33.7	7/13/14 21:45 == 47.3
7/13/14 10:05 == 34	7/13/14 14:00 == 32.5	7/13/14 17:55 == 33.8	7/13/14 21:50 == 46.2
7/13/14 10:10 == 34.2	7/13/14 14:05 == 32.6	7/13/14 18:00 == 33.8	7/13/14 21:55 == 32.7
7/13/14 10:15 == 34.2	7/13/14 14:10 == 32.9	7/13/14 18:05 == 33.2	7/13/14 22:00 == 32.6
7/13/14 10:20 == 33.9	7/13/14 14:15 == 33	7/13/14 18:10 == 43.3	7/13/14 22:05 == 32.6
7/13/14 10:25 == 43.2	7/13/14 14:20 == 33	7/13/14 18:15 == 47.5	7/13/14 22:10 == 32.9
7/13/14 10:30 == 48	7/13/14 14:25 == 33.3	7/13/14 18:20 == 47.4	7/13/14 22:15 == 32.9
7/13/14 10:35 == 48	7/13/14 14:30 == 33.2	7/13/14 18:25 == 47.5	7/13/14 22:20 == 33.1
7/13/14 10:40 == 48.1	7/13/14 14:35 == 33.3	7/13/14 18:30 == 47.3	7/13/14 22:25 == 33.4
7/13/14 10:45 == 47.9	7/13/14 14:40 == 33.4	7/13/14 18:35 == 47.4	7/13/14 22:30 == 33.2
7/13/14 10:50 == 48	7/13/14 14:45 == 33.5	7/13/14 18:40 == 47.4	7/13/14 22:35 == 33.4
7/13/14 10:55 == 47.8	7/13/14 14:50 == 33.5	7/13/14 18:45 == 47.4	7/13/14 22:40 == 33.5
7/13/14 11:00 == 48.1	7/13/14 14:55 == 33.6	7/13/14 18:50 == 47.4	7/13/14 22:45 == 33.6
7/13/14 11:05 == 47.9	7/13/14 15:00 == 33.6	7/13/14 18:55 == 47.3	7/13/14 22:50 == 33.6
7/13/14 11:10 == 47.9	7/13/14 15:05 == 33.7	7/13/14 19:00 == 47.4	7/13/14 22:55 == 33.7
7/13/14 11:15 == 47.9	7/13/14 15:10 == 33.7	7/13/14 19:05 == 46.1	7/13/14 23:00 == 33.7
7/13/14 11:20 == 47.8	7/13/14 15:15 == 33.8	7/13/14 19:10 == 32.6	7/13/14 23:05 == 33.7
7/13/14 11:25 == 33.3	7/13/14 15:20 == 33.8	7/13/14 19:15 == 32.5	7/13/14 23:10 == 33.9
7/13/14 11:30 == 32.9	7/13/14 15:25 == 33.7	7/13/14 19:20 == 32.5	7/13/14 23:15 == 33.9
7/13/14 11:35 == 32.9	7/13/14 15:30 == 33.9	7/13/14 19:25 == 32.9	7/13/14 23:20 == 33.3
7/13/14 11:40 == 33.4	7/13/14 15:35 == 33.3	7/13/14 19:30 == 32.9	7/13/14 23:25 == 43.4
7/13/14 11:45 == 33.3	7/13/14 15:40 == 43.2	7/13/14 19:35 == 33	7/13/14 23:30 == 47.5
7/13/14 11:50 == 33.4	7/13/14 15:45 == 47.4	7/13/14 19:40 == 33.2	7/13/14 23:35 == 47.5
7/13/14 11:55 == 33.6	7/13/14 15:50 == 47.4	7/13/14 19:45 == 33.3	7/13/14 23:40 == 47.5
7/13/14 12:00 == 33.5	7/13/14 15:55 == 47.4	7/13/14 19:50 == 33.2	7/13/14 23:45 == 47.4
7/13/14 12:05 == 33.7	7/13/14 16:00 == 47.4	7/13/14 19:55 == 33.4	7/13/14 23:50 == 47.4
7/13/14 12:10 == 33.7	7/13/14 16:05 == 47.5	7/13/14 20:00 == 33.3	7/13/14 23:55 == 47.4
7/13/14 12:15 == 33.8	7/13/14 16:10 == 47.5	7/13/14 20:05 == 33.4	7/14/14 0:00 == 47.4
7/13/14 12:20 == 33.6	7/13/14 16:15 == 47.5	7/13/14 20:10 == 33.6	7/14/14 0:05 == 47.3
7/13/14 12:25 == 33.9	7/13/14 16:20 == 47.4	7/13/14 20:15 == 33.6	7/14/14 0:10 == 47.4
7/13/14 12:30 == 33.6	7/13/14 16:25 == 47.3	7/13/14 20:20 == 33.6	7/14/14 0:15 == 47.4
7/13/14 12:35 == 33.7	7/13/14 16:30 == 47.5	7/13/14 20:25 == 33.7	7/14/14 0:20 == 46.2
7/13/14 12:40 == 33.8	7/13/14 16:35 == 46.2	7/13/14 20:30 == 33.8	7/14/14 0:25 == 32.8
7/13/14 12:45 == 33.8	7/13/14 16:40 == 32.8	7/13/14 20:35 == 33.7	7/14/14 0:30 == 32.5
7/13/14 12:50 == 33.5	7/13/14 16:45 == 32.6	7/13/14 20:40 == 33.8	7/14/14 0:35 == 32.5
7/13/14 12:55 == 43	7/13/14 16:50 == 32.6	7/13/14 20:45 == 33.9	7/14/14 0:40 == 32.9
7/13/14 13:00 == 47.5	7/13/14 16:55 == 32.9	7/13/14 20:50 == 33.3	7/14/14 0:45 == 33
7/13/14 13:05 == 47.6	7/13/14 17:00 == 32.9	7/13/14 20:55 == 43.4	7/14/14 0:50 == 33
7/13/14 13:10 == 47.5	7/13/14 17:05 == 33.1	7/13/14 21:00 == 47.5	7/14/14 0:55 == 33.3
7/13/14 13:15 == 47.4	7/13/14 17:10 == 33.3	7/13/14 21:05 == 47.5	7/14/14 1:00 == 33.3
7/13/14 13:20 == 47.4	7/13/14 17:15 == 33.1	7/13/14 21:10 == 47.5	7/14/14 1:05 == 33.4
7/13/14 13:25 == 47.5	7/13/14 17:20 == 33.3	7/13/14 21:15 == 47.4	7/14/14 1:10 == 33.4
7/13/14 13:30 == 47.4	7/13/14 17:25 == 33.5	7/13/14 21:20 == 47.5	7/14/14 1:15 == 33.5

Pumpback Station Discharge (0364)

7/14/14 1:20 == 33.5	7/14/14 5:15 == 47.4	7/14/14 9:10 == 33.8	7/14/14 13:05 == 31.8
7/14/14 1:25 == 33.6	7/14/14 5:20 == 46.1	7/14/14 9:15 == 33.9	7/14/14 13:10 == 32.2
7/14/14 1:30 == 33.6	7/14/14 5:25 == 32.7	7/14/14 9:20 == 33.3	7/14/14 13:15 == 32.2
7/14/14 1:35 == 33.6	7/14/14 5:30 == 32.5	7/14/14 9:25 == 43.7	7/14/14 13:20 == 32.2
7/14/14 1:40 == 33.8	7/14/14 5:35 == 32.7	7/14/14 9:30 == 47.4	7/14/14 13:25 == 32.7
7/14/14 1:45 == 33.8	7/14/14 5:40 == 32.8	7/14/14 9:35 == 47.4	7/14/14 13:30 == 32.4
7/14/14 1:50 == 33.2	7/14/14 5:45 == 32.9	7/14/14 9:40 == 47.5	7/14/14 13:35 == 32.6
7/14/14 1:55 == 44	7/14/14 5:50 == 33	7/14/14 9:45 == 47.5	7/14/14 13:40 == 32.6
7/14/14 2:00 == 47.6	7/14/14 5:55 == 33.4	7/14/14 9:50 == 47.4	7/14/14 13:45 == 32.7
7/14/14 2:05 == 47.5	7/14/14 6:00 == 33.3	7/14/14 9:55 == 47.5	7/14/14 13:50 == 32.8
7/14/14 2:10 == 47.4	7/14/14 6:05 == 33.3	7/14/14 10:00 == 47.4	7/14/14 13:55 == 32.8
7/14/14 2:15 == 47.5	7/14/14 6:10 == 33.6	7/14/14 10:05 == 47.5	7/14/14 14:00 == 33.2
7/14/14 2:20 == 47.5	7/14/14 6:15 == 33.5	7/14/14 10:10 == 47.4	7/14/14 14:05 == 32.4
7/14/14 2:25 == 47.4	7/14/14 6:20 == 33.3	7/14/14 10:15 == 47.5	7/14/14 14:10 == 42.6
7/14/14 2:30 == 47.4	7/14/14 6:25 == 33.7	7/14/14 10:20 == 45.4	7/14/14 14:15 == 45.8
7/14/14 2:35 == 47.5	7/14/14 6:30 == 33.6	7/14/14 10:25 == 32.6	7/14/14 14:20 == 45.5
7/14/14 2:40 == 47.3	7/14/14 6:35 == 33.7	7/14/14 10:30 == 32.5	7/14/14 14:25 == 45.6
7/14/14 2:45 == 47.3	7/14/14 6:40 == 33.7	7/14/14 10:35 == 32.7	7/14/14 14:30 == 45.5
7/14/14 2:50 == 46.2	7/14/14 6:45 == 33.8	7/14/14 10:40 == 32.9	7/14/14 14:35 == 45.6
7/14/14 2:55 == 32.8	7/14/14 6:50 == 33.2	7/14/14 10:45 == 32.7	7/14/14 14:40 == 45.6
7/14/14 3:00 == 32.6	7/14/14 6:55 == 43.5	7/14/14 10:50 == 32	7/14/14 14:45 == 45.6
7/14/14 3:05 == 32.7	7/14/14 7:00 == 47.6	7/14/14 10:55 == 32.5	7/14/14 14:50 == 45.5
7/14/14 3:10 == 33.1	7/14/14 7:05 == 47.6	7/14/14 11:00 == 32.6	7/14/14 14:55 == 45.5
7/14/14 3:15 == 33.1	7/14/14 7:10 == 47.6	7/14/14 11:05 == 32.6	7/14/14 15:00 == 45.7
7/14/14 3:20 == 33	7/14/14 7:15 == 47.6	7/14/14 11:10 == 32.8	7/14/14 15:05 == 45.9
7/14/14 3:25 == 33.3	7/14/14 7:20 == 47.2	7/14/14 11:15 == 32.6	7/14/14 15:10 == 45.4
7/14/14 3:30 == 33.2	7/14/14 7:25 == 47.3	7/14/14 11:20 == 32.9	7/14/14 15:15 == 45.5
7/14/14 3:35 == 33.5	7/14/14 7:30 == 47.3	7/14/14 11:25 == 33	7/14/14 15:20 == 43.3
7/14/14 3:40 == 33.6	7/14/14 7:35 == 47.5	7/14/14 11:30 == 33	7/14/14 15:25 == 31.7
7/14/14 3:45 == 33.5	7/14/14 7:40 == 47.5	7/14/14 11:35 == 32.4	7/14/14 15:30 == 31.9
7/14/14 3:50 == 33.5	7/14/14 7:45 == 47.4	7/14/14 11:40 == 42.4	7/14/14 15:35 == 31.8
7/14/14 3:55 == 33.7	7/14/14 7:50 == 46	7/14/14 11:45 == 45.5	7/14/14 15:40 == 32.2
7/14/14 4:00 == 33.7	7/14/14 7:55 == 32.6	7/14/14 11:50 == 45.5	7/14/14 15:45 == 32.1
7/14/14 4:05 == 33.7	7/14/14 8:00 == 32.7	7/14/14 11:55 == 45.5	7/14/14 15:50 == 32.3
7/14/14 4:10 == 33.9	7/14/14 8:05 == 32.5	7/14/14 12:00 == 45.5	7/14/14 15:55 == 32.5
7/14/14 4:15 == 33.7	7/14/14 8:10 == 33	7/14/14 12:05 == 45.5	7/14/14 16:00 == 32.5
7/14/14 4:20 == 33.2	7/14/14 8:15 == 33	7/14/14 12:10 == 45.3	7/14/14 16:05 == 32.5
7/14/14 4:25 == 43.9	7/14/14 8:20 == 33.1	7/14/14 12:15 == 45.5	7/14/14 16:10 == 32.6
7/14/14 4:30 == 47.6	7/14/14 8:25 == 33.3	7/14/14 12:20 == 45.7	7/14/14 16:15 == 32.8
7/14/14 4:35 == 47.5	7/14/14 8:30 == 33.4	7/14/14 12:25 == 45.8	7/14/14 16:20 == 32.7
7/14/14 4:40 == 47.5	7/14/14 8:35 == 33.3	7/14/14 12:30 == 45.5	7/14/14 16:25 == 32.9
7/14/14 4:45 == 47.4	7/14/14 8:40 == 33.5	7/14/14 12:35 == 45.6	7/14/14 16:30 == 32.8
7/14/14 4:50 == 47.5	7/14/14 8:45 == 33.5	7/14/14 12:40 == 45.5	7/14/14 16:35 == 32.8
7/14/14 4:55 == 47.4	7/14/14 8:50 == 33.5	7/14/14 12:45 == 45.5	7/14/14 16:40 == 33
7/14/14 5:00 == 47.5	7/14/14 8:55 == 33.8	7/14/14 12:50 == 43.7	7/14/14 16:45 == 33
7/14/14 5:05 == 47.5	7/14/14 9:00 == 33.6	7/14/14 12:55 == 31.9	7/14/14 16:50 == 32.3
7/14/14 5:10 == 47.4	7/14/14 9:05 == 33.7	7/14/14 13:00 == 31.8	7/14/14 16:55 == 43

Pumpback Station Discharge (0364)

7/14/14 17:00 == 45.6	7/14/14 20:55 == 32.1	7/15/14 0:50 == 45.6	7/15/14 4:45 == 32.3
7/14/14 17:05 == 45.6	7/14/14 21:00 == 32.1	7/15/14 0:55 == 45.6	7/15/14 4:50 == 32.4
7/14/14 17:10 == 45.6	7/14/14 21:05 == 32.3	7/15/14 1:00 == 45.6	7/15/14 4:55 == 32.8
7/14/14 17:15 == 45.6	7/14/14 21:10 == 32.4	7/15/14 1:05 == 45.7	7/15/14 5:00 == 32.8
7/14/14 17:20 == 45.5	7/14/14 21:15 == 32.4	7/15/14 1:10 == 45.7	7/15/14 5:05 == 32.8
7/14/14 17:25 == 45.5	7/14/14 21:20 == 32.5	7/15/14 1:15 == 45.5	7/15/14 5:10 == 32.9
7/14/14 17:30 == 45.5	7/14/14 21:25 == 32.9	7/15/14 1:20 == 45.4	7/15/14 5:15 == 32.9
7/14/14 17:35 == 45.4	7/14/14 21:30 == 32.8	7/15/14 1:25 == 45.5	7/15/14 5:20 == 33.1
7/14/14 17:40 == 45.5	7/14/14 21:35 == 32.8	7/15/14 1:30 == 45.6	7/15/14 5:25 == 33
7/14/14 17:45 == 45.6	7/14/14 21:40 == 32.9	7/15/14 1:35 == 45.5	7/15/14 5:30 == 33.2
7/14/14 17:50 == 45.5	7/14/14 21:45 == 32.9	7/15/14 1:40 == 45.5	7/15/14 5:35 == 32.4
7/14/14 17:55 == 45.5	7/14/14 21:50 == 33	7/15/14 1:45 == 45.6	7/15/14 5:40 == 43.9
7/14/14 18:00 == 45.6	7/14/14 21:55 == 33.1	7/15/14 1:50 == 43.2	7/15/14 5:45 == 45.7
7/14/14 18:05 == 43.1	7/14/14 22:00 == 33	7/15/14 1:55 == 31.7	7/15/14 5:50 == 46
7/14/14 18:10 == 31.8	7/14/14 22:05 == 32	7/15/14 2:00 == 31.9	7/15/14 5:55 == 45.7
7/14/14 18:15 == 31.9	7/14/14 22:10 == 43.9	7/15/14 2:05 == 32	7/15/14 6:00 == 45.7
7/14/14 18:20 == 31.9	7/14/14 22:15 == 45.6	7/15/14 2:10 == 32.4	7/15/14 6:05 == 45.6
7/14/14 18:25 == 32.2	7/14/14 22:20 == 45.7	7/15/14 2:15 == 32.4	7/15/14 6:10 == 45.9
7/14/14 18:30 == 32.3	7/14/14 22:25 == 45.6	7/15/14 2:20 == 32.4	7/15/14 6:15 == 45.5
7/14/14 18:35 == 32.3	7/14/14 22:30 == 45.5	7/15/14 2:25 == 32.7	7/15/14 6:20 == 45.7
7/14/14 18:40 == 32.7	7/14/14 22:35 == 45.5	7/15/14 2:30 == 32.6	7/15/14 6:25 == 45.5
7/14/14 18:45 == 32.6	7/14/14 22:40 == 45.6	7/15/14 2:35 == 32.6	7/15/14 6:30 == 45.7
7/14/14 18:50 == 32.7	7/14/14 22:45 == 45.5	7/15/14 2:40 == 32.9	7/15/14 6:35 == 45.6
7/14/14 18:55 == 32.8	7/14/14 22:50 == 45.6	7/15/14 2:45 == 32.8	7/15/14 6:40 == 45.6
7/14/14 19:00 == 32.9	7/14/14 22:55 == 45.5	7/15/14 2:50 == 32.9	7/15/14 6:45 == 45.6
7/14/14 19:05 == 32.9	7/14/14 23:00 == 45.5	7/15/14 2:55 == 33.1	7/15/14 6:50 == 42.9
7/14/14 19:10 == 33	7/14/14 23:05 == 45.5	7/15/14 3:00 == 33	7/15/14 6:55 == 31.9
7/14/14 19:15 == 33	7/14/14 23:10 == 45.6	7/15/14 3:05 == 32.2	7/15/14 7:00 == 32
7/14/14 19:20 == 32	7/14/14 23:15 == 45.4	7/15/14 3:10 == 43.7	7/15/14 7:05 == 32
7/14/14 19:25 == 43.6	7/14/14 23:20 == 43.1	7/15/14 3:15 == 45.6	7/15/14 7:10 == 32.4
7/14/14 19:30 == 45.6	7/14/14 23:25 == 31.8	7/15/14 3:20 == 45.6	7/15/14 7:15 == 32.4
7/14/14 19:35 == 45.5	7/14/14 23:30 == 31.9	7/15/14 3:25 == 45.6	7/15/14 7:20 == 32.5
7/14/14 19:40 == 45.5	7/14/14 23:35 == 32.1	7/15/14 3:30 == 45.5	7/15/14 7:25 == 32.7
7/14/14 19:45 == 45.5	7/14/14 23:40 == 32.4	7/15/14 3:35 == 45.9	7/15/14 7:30 == 32.8
7/14/14 19:50 == 45.5	7/14/14 23:45 == 32.3	7/15/14 3:40 == 45.6	7/15/14 7:35 == 32.8
7/14/14 19:55 == 45.5	7/14/14 23:50 == 32.4	7/15/14 3:45 == 45.7	7/15/14 7:40 == 33
7/14/14 20:00 == 45.5	7/14/14 23:55 == 32.7	7/15/14 3:50 == 45.6	7/15/14 7:45 == 32.9
7/14/14 20:05 == 45.4	7/15/14 0:00 == 32.7	7/15/14 3:55 == 45.5	7/15/14 7:50 == 33
7/14/14 20:10 == 45.5	7/15/14 0:05 == 32.7	7/15/14 4:00 == 45.6	7/15/14 7:55 == 33
7/14/14 20:15 == 45.6	7/15/14 0:10 == 32.9	7/15/14 4:05 == 45.9	7/15/14 8:00 == 33.1
7/14/14 20:20 == 45.5	7/15/14 0:15 == 32.7	7/15/14 4:10 == 45.6	7/15/14 8:05 == 32.6
7/14/14 20:25 == 45.5	7/15/14 0:20 == 32.8	7/15/14 4:15 == 45.5	7/15/14 8:10 == 43.6
7/14/14 20:30 == 45.4	7/15/14 0:25 == 33.1	7/15/14 4:20 == 43.3	7/15/14 8:15 == 45.6
7/14/14 20:35 == 43.2	7/15/14 0:30 == 33	7/15/14 4:25 == 31.9	7/15/14 8:20 == 45.7
7/14/14 20:40 == 31.8	7/15/14 0:35 == 31.9	7/15/14 4:30 == 32	7/15/14 8:25 == 46.1
7/14/14 20:45 == 31.7	7/15/14 0:40 == 43.8	7/15/14 4:35 == 31.9	7/15/14 8:30 == 45.7
7/14/14 20:50 == 31.9	7/15/14 0:45 == 45.7	7/15/14 4:40 == 32.3	7/15/14 8:35 == 45.9

Pumpback Station Discharge (0364)

7/15/14 8:40 == 45.6	7/15/14 12:35 == 33	7/15/14 16:30 == 45.8	7/15/14 20:25 == 32.3
7/15/14 8:45 == 45.5	7/15/14 12:40 == 32.9	7/15/14 16:35 == 45.7	7/15/14 20:30 == 32.4
7/15/14 8:50 == 45.5	7/15/14 12:45 == 33.1	7/15/14 16:40 == 45.6	7/15/14 20:35 == 32.5
7/15/14 8:55 == 45.6	7/15/14 12:50 == 33	7/15/14 16:45 == 45.6	7/15/14 20:40 == 32.8
7/15/14 9:00 == 45.6	7/15/14 12:55 == 33.2	7/15/14 16:50 == 45.6	7/15/14 20:45 == 32.7
7/15/14 9:05 == 45.5	7/15/14 13:00 == 32.9	7/15/14 16:55 == 45.6	7/15/14 20:50 == 32.8
7/15/14 9:10 == 45.5	7/15/14 13:05 == 32.9	7/15/14 17:00 == 45.6	7/15/14 20:55 == 32.9
7/15/14 9:15 == 45.6	7/15/14 13:10 == 33	7/15/14 17:05 == 45.6	7/15/14 21:00 == 33
7/15/14 9:20 == 42.7	7/15/14 13:15 == 33	7/15/14 17:10 == 45.6	7/15/14 21:05 == 32.1
7/15/14 9:25 == 31.8	7/15/14 13:20 == 33	7/15/14 17:15 == 45.4	7/15/14 21:10 == 44.9
7/15/14 9:30 == 31.9	7/15/14 13:25 == 32.9	7/15/14 17:20 == 45.4	7/15/14 21:15 == 45.5
7/15/14 9:35 == 32	7/15/14 13:30 == 32.9	7/15/14 17:25 == 45.5	7/15/14 21:20 == 45.6
7/15/14 9:40 == 32.5	7/15/14 13:35 == 33.1	7/15/14 17:30 == 45.5	7/15/14 21:25 == 45.6
7/15/14 9:45 == 32.5	7/15/14 13:40 == 33	7/15/14 17:35 == 45.5	7/15/14 21:30 == 45.6
7/15/14 9:50 == 32.5	7/15/14 13:45 == 33	7/15/14 17:40 == 45.5	7/15/14 21:35 == 45.5
7/15/14 9:55 == 32.6	7/15/14 13:50 == 32.9	7/15/14 17:45 == 45.6	7/15/14 21:40 == 45.6
7/15/14 10:00 == 32.7	7/15/14 13:55 == 33	7/15/14 17:50 == 45.6	7/15/14 21:45 == 45.7
7/15/14 10:05 == 32.8	7/15/14 14:00 == 32.9	7/15/14 17:55 == 45.5	7/15/14 21:50 == 45.6
7/15/14 10:10 == 32.9	7/15/14 14:05 == 33	7/15/14 18:00 == 45.5	7/15/14 21:55 == 45.5
7/15/14 10:15 == 32.9	7/15/14 14:10 == 33	7/15/14 18:05 == 45.5	7/15/14 22:00 == 45.5
7/15/14 10:20 == 33	7/15/14 14:15 == 33.1	7/15/14 18:10 == 45.5	7/15/14 22:05 == 45.6
7/15/14 10:25 == 32.9	7/15/14 14:20 == 33.1	7/15/14 18:15 == 45.5	7/15/14 22:10 == 45.6
7/15/14 10:30 == 33.1	7/15/14 14:25 == 33	7/15/14 18:20 == 45.5	7/15/14 22:15 == 45.5
7/15/14 10:35 == 32.9	7/15/14 14:30 == 33	7/15/14 18:25 == 45.6	7/15/14 22:20 == 41.9
7/15/14 10:40 == 33.2	7/15/14 14:35 == 33.1	7/15/14 18:30 == 45.4	7/15/14 22:25 == 31.8
7/15/14 10:45 == 32.9	7/15/14 14:40 == 33	7/15/14 18:35 == 45.6	7/15/14 22:30 == 32
7/15/14 10:50 == 33	7/15/14 14:45 == 33	7/15/14 18:40 == 45.5	7/15/14 22:35 == 32.1
7/15/14 10:55 == 33	7/15/14 14:50 == 33	7/15/14 18:45 == 45.5	7/15/14 22:40 == 32.5
7/15/14 11:00 == 32.9	7/15/14 14:55 == 33	7/15/14 18:50 == 45.5	7/15/14 22:45 == 32.4
7/15/14 11:05 == 32.9	7/15/14 15:00 == 32.8	7/15/14 18:55 == 45.5	7/15/14 22:50 == 32.5
7/15/14 11:10 == 32.9	7/15/14 15:05 == 41.8	7/15/14 19:00 == 45.4	7/15/14 22:55 == 32.7
7/15/14 11:15 == 32.9	7/15/14 15:10 == 45.8	7/15/14 19:05 == 45.4	7/15/14 23:00 == 32.7
7/15/14 11:20 == 33	7/15/14 15:15 == 45.8	7/15/14 19:10 == 45.5	7/15/14 23:05 == 32.8
7/15/14 11:25 == 33	7/15/14 15:20 == 46	7/15/14 19:15 == 45.4	7/15/14 23:10 == 33
7/15/14 11:30 == 32.9	7/15/14 15:25 == 45.7	7/15/14 19:20 == 45.5	7/15/14 23:15 == 33
7/15/14 11:35 == 33	7/15/14 15:30 == 45.7	7/15/14 19:25 == 45.4	7/15/14 23:20 == 32
7/15/14 11:40 == 33.1	7/15/14 15:35 == 45.7	7/15/14 19:30 == 45.5	7/15/14 23:25 == 45
7/15/14 11:45 == 32.9	7/15/14 15:40 == 45.5	7/15/14 19:35 == 45.4	7/15/14 23:30 == 45.8
7/15/14 11:50 == 33	7/15/14 15:45 == 45.7	7/15/14 19:40 == 45.5	7/15/14 23:35 == 45.7
7/15/14 11:55 == 33.1	7/15/14 15:50 == 45.8	7/15/14 19:45 == 45.5	7/15/14 23:40 == 45.7
7/15/14 12:00 == 33.1	7/15/14 15:55 == 45.6	7/15/14 19:50 == 45.5	7/15/14 23:45 == 45.7
7/15/14 12:05 == 33	7/15/14 16:00 == 45.6	7/15/14 19:55 == 45.5	7/15/14 23:50 == 45.7
7/15/14 12:10 == 33	7/15/14 16:05 == 45.7	7/15/14 20:00 == 45.5	7/15/14 23:55 == 45.5
7/15/14 12:15 == 33	7/15/14 16:10 == 45.8	7/15/14 20:05 == 42	7/16/14 0:00 == 45.7
7/15/14 12:20 == 32.9	7/15/14 16:15 == 45.7	7/15/14 20:10 == 31.8	7/16/14 0:05 == 45.7
7/15/14 12:25 == 33	7/15/14 16:20 == 45.7	7/15/14 20:15 == 31.9	7/16/14 0:10 == 45.6
7/15/14 12:30 == 32.9	7/15/14 16:25 == 45.7	7/15/14 20:20 == 32.2	7/16/14 0:15 == 45.5

Pumpback Station Discharge (0364)

7/16/14 0:20 == 45.6	7/16/14 4:15 == 33.1	7/16/14 8:10 == 32.7	7/16/14 12:05 == #
7/16/14 0:25 == 45.5	7/16/14 4:20 == 32.4	7/16/14 8:15 == 32.8	7/16/14 12:10 == 32.9
7/16/14 0:30 == 45.6	7/16/14 4:25 == 45	7/16/14 8:20 == 32.7	7/16/14 12:15 == 33
7/16/14 0:35 == 42	7/16/14 4:30 == 46	7/16/14 8:25 == 32.7	7/16/14 12:20 == 32.8
7/16/14 0:40 == 31.9	7/16/14 4:35 == 45.7	7/16/14 8:30 == 32.9	7/16/14 12:25 == 33
7/16/14 0:45 == 32.1	7/16/14 4:40 == 45.5	7/16/14 8:35 == 32.8	7/16/14 12:30 == 32.8
7/16/14 0:50 == 32.2	7/16/14 4:45 == 45.6	7/16/14 8:40 == 32.8	7/16/14 12:35 == 32.9
7/16/14 0:55 == 32.5	7/16/14 4:50 == 45.6	7/16/14 8:45 == 32.7	7/16/14 12:40 == 32.9
7/16/14 1:00 == 32.5	7/16/14 4:55 == 45.6	7/16/14 8:50 == 32.8	7/16/14 12:45 == 33
7/16/14 1:05 == 32.5	7/16/14 5:00 == 45.6	7/16/14 8:55 == 32.8	7/16/14 12:50 == 32.9
7/16/14 1:10 == 32.6	7/16/14 5:05 == 45.7	7/16/14 9:00 == 32.8	7/16/14 12:55 == 32.8
7/16/14 1:15 == 32.8	7/16/14 5:10 == 45.6	7/16/14 9:05 == 32.8	7/16/14 13:00 == 33
7/16/14 1:20 == 32.9	7/16/14 5:15 == 45.7	7/16/14 9:10 == 32.9	7/16/14 13:05 == 33.1
7/16/14 1:25 == 32.9	7/16/14 5:20 == 45.6	7/16/14 9:15 == 32.9	7/16/14 13:10 == 32.8
7/16/14 1:30 == 32.9	7/16/14 5:25 == 45.7	7/16/14 9:20 == 32.9	7/16/14 13:15 == 32.9
7/16/14 1:35 == 32.1	7/16/14 5:30 == 45.5	7/16/14 9:25 == 32.8	7/16/14 13:20 == 32.9
7/16/14 1:40 == 45.1	7/16/14 5:35 == 45.6	7/16/14 9:30 == 32.7	7/16/14 13:25 == 33.1
7/16/14 1:45 == 45.7	7/16/14 5:40 == 46	7/16/14 9:35 == 32.8	7/16/14 13:30 == 32.9
7/16/14 1:50 == 45.7	7/16/14 5:45 == 45.5	7/16/14 9:40 == 32.8	7/16/14 13:35 == 33
7/16/14 1:55 == 45.6	7/16/14 5:50 == 41.6	7/16/14 9:45 == 32.8	7/16/14 13:40 == 32.9
7/16/14 2:00 == 45.6	7/16/14 5:55 == 31.7	7/16/14 9:50 == 33	7/16/14 13:45 == 32.9
7/16/14 2:05 == 45.6	7/16/14 6:00 == 31.8	7/16/14 9:55 == 32.8	7/16/14 13:50 == 33
7/16/14 2:10 == 45.6	7/16/14 6:05 == 32.1	7/16/14 10:00 == 32.9	7/16/14 13:55 == 37.9
7/16/14 2:15 == 45.6	7/16/14 6:10 == 32.2	7/16/14 10:05 == 33	7/16/14 14:00 == 45.9
7/16/14 2:20 == 45.5	7/16/14 6:15 == 32.4	7/16/14 10:10 == 32.8	7/16/14 14:05 == 45.9
7/16/14 2:25 == 45.7	7/16/14 6:20 == 32.6	7/16/14 10:15 == 32.8	7/16/14 14:10 == 45.9
7/16/14 2:30 == 45.6	7/16/14 6:25 == 32.7	7/16/14 10:20 == 32.8	7/16/14 14:15 == 46
7/16/14 2:35 == 45.5	7/16/14 6:30 == 32.6	7/16/14 10:25 == 32.8	7/16/14 14:20 == 46.1
7/16/14 2:40 == 45.6	7/16/14 6:35 == 32.7	7/16/14 10:30 == 32.8	7/16/14 14:25 == 45.9
7/16/14 2:45 == 45.6	7/16/14 6:40 == 32.6	7/16/14 10:35 == 32.8	7/16/14 14:30 == 45.8
7/16/14 2:50 == 45.5	7/16/14 6:45 == 32.7	7/16/14 10:40 == 33	7/16/14 14:35 == 45.7
7/16/14 2:55 == 45.6	7/16/14 6:50 == 32.7	7/16/14 10:45 == 32.9	7/16/14 14:40 == 45.7
7/16/14 3:00 == 45.6	7/16/14 6:55 == 32.7	7/16/14 10:50 == 32.9	7/16/14 14:45 == 45.9
7/16/14 3:05 == 41.7	7/16/14 7:00 == 32.7	7/16/14 10:55 == 32.7	7/16/14 14:50 == 46
7/16/14 3:10 == 31.7	7/16/14 7:05 == 32.8	7/16/14 11:00 == 32.8	7/16/14 14:55 == 45.9
7/16/14 3:15 == 31.8	7/16/14 7:10 == 32.7	7/16/14 11:05 == 32.8	7/16/14 15:00 == 45.9
7/16/14 3:20 == 31.9	7/16/14 7:15 == 32.9	7/16/14 11:10 == 32.8	7/16/14 15:05 == 46
7/16/14 3:25 == 32.3	7/16/14 7:20 == 32.7	7/16/14 11:15 == 32.9	7/16/14 15:10 == 45.6
7/16/14 3:30 == 32.3	7/16/14 7:25 == 32.7	7/16/14 11:20 == 32.8	7/16/14 15:15 == 45.8
7/16/14 3:35 == 32.6	7/16/14 7:30 == 32.7	7/16/14 11:25 == 32.8	7/16/14 15:20 == 45.7
7/16/14 3:40 == 32.6	7/16/14 7:35 == 32.7	7/16/14 11:30 == 32.9	7/16/14 15:25 == 46
7/16/14 3:45 == 32.8	7/16/14 7:40 == 32.8	7/16/14 11:35 == 32.8	7/16/14 15:30 == 45.7
7/16/14 3:50 == 32.6	7/16/14 7:45 == 32.8	7/16/14 11:40 == 32.8	7/16/14 15:35 == 45.7
7/16/14 3:55 == 32.8	7/16/14 7:50 == 32.6	7/16/14 11:45 == 32.8	7/16/14 15:40 == 45.8
7/16/14 4:00 == 33	7/16/14 7:55 == 32.8	7/16/14 11:50 == 32.8	7/16/14 15:45 == 45.7
7/16/14 4:05 == 33.1	7/16/14 8:00 == 32.8	7/16/14 11:55 == 32.9	7/16/14 15:50 == 45.7
7/16/14 4:10 == 33.1	7/16/14 8:05 == 32.8	7/16/14 12:00 == 32.9	7/16/14 15:55 == 45.8

Pumpback Station Discharge (0364)

7/16/14 16:00 == 45.6	7/16/14 19:55 == 45.7	7/16/14 23:50 == 32.8	7/17/14 3:45 == 46
7/16/14 16:05 == 45.7	7/16/14 20:00 == 45.6	7/16/14 23:55 == 32.9	7/17/14 3:50 == 45.6
7/16/14 16:10 == 46	7/16/14 20:05 == 45.7	7/17/14 0:00 == 33	7/17/14 3:55 == 45.8
7/16/14 16:15 == 45.7	7/16/14 20:10 == 45.6	7/17/14 0:05 == 33.1	7/17/14 4:00 == 45.8
7/16/14 16:20 == 45.7	7/16/14 20:15 == 45.6	7/17/14 0:10 == 32.8	7/17/14 4:05 == 45.7
7/16/14 16:25 == 45.6	7/16/14 20:20 == 45.6	7/17/14 0:15 == 45.6	7/17/14 4:10 == 45.6
7/16/14 16:30 == 45.6	7/16/14 20:25 == 45.6	7/17/14 0:20 == 45.7	7/17/14 4:15 == 45.9
7/16/14 16:35 == 45.7	7/16/14 20:30 == 45.6	7/17/14 0:25 == 45.7	7/17/14 4:20 == 45.7
7/16/14 16:40 == 45.6	7/16/14 20:35 == 45.6	7/17/14 0:30 == 45.6	7/17/14 4:25 == 40
7/16/14 16:45 == 45.7	7/16/14 20:40 == 45.6	7/17/14 0:35 == 45.7	7/17/14 4:30 == 32.2
7/16/14 16:50 == 45.7	7/16/14 20:45 == 45.6	7/17/14 0:40 == 45.7	7/17/14 4:35 == 32
7/16/14 16:55 == 45.6	7/16/14 20:50 == 45.6	7/17/14 0:45 == 45.6	7/17/14 4:40 == 32.2
7/16/14 17:00 == 45.6	7/16/14 20:55 == 45.7	7/17/14 0:50 == 45.6	7/17/14 4:45 == 32.5
7/16/14 17:05 == 45.7	7/16/14 21:00 == 45.5	7/17/14 0:55 == 45.6	7/17/14 4:50 == 32.5
7/16/14 17:10 == 45.5	7/16/14 21:05 == 45.6	7/17/14 1:00 == 45.6	7/17/14 4:55 == 32.6
7/16/14 17:15 == 45.7	7/16/14 21:10 == 45.6	7/17/14 1:05 == 45.6	7/17/14 5:00 == 32.8
7/16/14 17:20 == 45.6	7/16/14 21:15 == 45.6	7/17/14 1:10 == 45.6	7/17/14 5:05 == 32.8
7/16/14 17:25 == 45.6	7/16/14 21:20 == 45.5	7/17/14 1:15 == 45.6	7/17/14 5:10 == 32.9
7/16/14 17:30 == 45.6	7/16/14 21:25 == 45.6	7/17/14 1:20 == 45.6	7/17/14 5:15 == 33.2
7/16/14 17:35 == 45.7	7/16/14 21:30 == 45.6	7/17/14 1:25 == 45.7	7/17/14 5:20 == 33.1
7/16/14 17:40 == 45.7	7/16/14 21:35 == 45.6	7/17/14 1:30 == 45.7	7/17/14 5:25 == 33.5
7/16/14 17:45 == 45.6	7/16/14 21:40 == 45.5	7/17/14 1:35 == 45.6	7/17/14 5:30 == 45.7
7/16/14 17:50 == 45.6	7/16/14 21:45 == 45.6	7/17/14 1:40 == 45.6	7/17/14 5:35 == 45.7
7/16/14 17:55 == 45.5	7/16/14 21:50 == 45.6	7/17/14 1:45 == 45.6	7/17/14 5:40 == 45.7
7/16/14 18:00 == 45.6	7/16/14 21:55 == 45.6	7/17/14 1:50 == 45.6	7/17/14 5:45 == 45.7
7/16/14 18:05 == 45.6	7/16/14 22:00 == 45.7	7/17/14 1:55 == 40.1	7/17/14 5:50 == 45.9
7/16/14 18:10 == 45.6	7/16/14 22:05 == 45.5	7/17/14 2:00 == 31.8	7/17/14 5:55 == 45.7
7/16/14 18:15 == 45.7	7/16/14 22:10 == 45.6	7/17/14 2:05 == 31.8	7/17/14 6:00 == 45.7
7/16/14 18:20 == 45.6	7/16/14 22:15 == 45.6	7/17/14 2:10 == 32.1	7/17/14 6:05 == 46.1
7/16/14 18:25 == 45.5	7/16/14 22:20 == 45.5	7/17/14 2:15 == 32.4	7/17/14 6:10 == 45.5
7/16/14 18:30 == 45.6	7/16/14 22:25 == 45.6	7/17/14 2:20 == 32.4	7/17/14 6:15 == 45.8
7/16/14 18:35 == 45.5	7/16/14 22:30 == 45.5	7/17/14 2:25 == 32.5	7/17/14 6:20 == 45.5
7/16/14 18:40 == 45.5	7/16/14 22:35 == 45.5	7/17/14 2:30 == 32.7	7/17/14 6:25 == 45.7
7/16/14 18:45 == 45.7	7/16/14 22:40 == 45.5	7/17/14 2:35 == 32.7	7/17/14 6:30 == 45.6
7/16/14 18:50 == 45.6	7/16/14 22:45 == 45.6	7/17/14 2:40 == 32.9	7/17/14 6:35 == 45.7
7/16/14 18:55 == 45.5	7/16/14 22:50 == 45.5	7/17/14 2:45 == 33.1	7/17/14 6:40 == 45.9
7/16/14 19:00 == 45.6	7/16/14 22:55 == 45.6	7/17/14 2:50 == 33	7/17/14 6:45 == 45.6
7/16/14 19:05 == 45.6	7/16/14 23:00 == 45.6	7/17/14 2:55 == 33	7/17/14 6:50 == 45.6
7/16/14 19:10 == 45.5	7/16/14 23:05 == 45.6	7/17/14 3:00 == 45.7	7/17/14 6:55 == 39.3
7/16/14 19:15 == 45.5	7/16/14 23:10 == 40.1	7/17/14 3:05 == 45.7	7/17/14 7:00 == 32
7/16/14 19:20 == 45.6	7/16/14 23:15 == 31.9	7/17/14 3:10 == 45.5	7/17/14 7:05 == 32.1
7/16/14 19:25 == 45.6	7/16/14 23:20 == 31.9	7/17/14 3:15 == 45.7	7/17/14 7:10 == 32.1
7/16/14 19:30 == 45.7	7/16/14 23:25 == 32	7/17/14 3:20 == 45.6	7/17/14 7:15 == 32.5
7/16/14 19:35 == 45.5	7/16/14 23:30 == 32.5	7/17/14 3:25 == 45.6	7/17/14 7:20 == 32.7
7/16/14 19:40 == 45.6	7/16/14 23:35 == 32.3	7/17/14 3:30 == 45.7	7/17/14 7:25 == 32.6
7/16/14 19:45 == 45.6	7/16/14 23:40 == 32.5	7/17/14 3:35 == 45.6	7/17/14 7:30 == 32.7
7/16/14 19:50 == 45.6	7/16/14 23:45 == 32.7	7/17/14 3:40 == 45.6	7/17/14 7:35 == 32.8

Pumpback Station Discharge (0364)

7/17/14 7:40 == 32.9	7/17/14 11:35 == 45.6	7/17/14 15:30 == 32.9	7/17/14 19:25 == 45.6
7/17/14 7:45 == 32.9	7/17/14 11:40 == 45.6	7/17/14 15:35 == 32.9	7/17/14 19:30 == 45.6
7/17/14 7:50 == 32.9	7/17/14 11:45 == 45.7	7/17/14 15:40 == 33.1	7/17/14 19:35 == 45.6
7/17/14 7:55 == 33.6	7/17/14 11:50 == 45.9	7/17/14 15:45 == 33.2	7/17/14 19:40 == 45.6
7/17/14 8:00 == 46.2	7/17/14 11:55 == 45.7	7/17/14 15:50 == 33.1	7/17/14 19:45 == 45.6
7/17/14 8:05 == 45.7	7/17/14 12:00 == 45.7	7/17/14 15:55 == 33.9	7/17/14 19:50 == 45.5
7/17/14 8:10 == 45.7	7/17/14 12:05 == 45.5	7/17/14 16:00 == 46.1	7/17/14 19:55 == 38.9
7/17/14 8:15 == 45.9	7/17/14 12:10 == 39.1	7/17/14 16:05 == 45.8	7/17/14 20:00 == 31.8
7/17/14 8:20 == 45.8	7/17/14 12:15 == 31.9	7/17/14 16:10 == 45.6	7/17/14 20:05 == 31.7
7/17/14 8:25 == 45.6	7/17/14 12:20 == 31.9	7/17/14 16:15 == 45.7	7/17/14 20:10 == 32
7/17/14 8:30 == 45.6	7/17/14 12:25 == 32.1	7/17/14 16:20 == 45.5	7/17/14 20:15 == 32.4
7/17/14 8:35 == 45.7	7/17/14 12:30 == 32.4	7/17/14 16:25 == 45.5	7/17/14 20:20 == 32.4
7/17/14 8:40 == 45.6	7/17/14 12:35 == 32.6	7/17/14 16:30 == 45.6	7/17/14 20:25 == 32.5
7/17/14 8:45 == 45.6	7/17/14 12:40 == 32.5	7/17/14 16:35 == 45.7	7/17/14 20:30 == 32.5
7/17/14 8:50 == 45.7	7/17/14 12:45 == 32.7	7/17/14 16:40 == 45.6	7/17/14 20:35 == 32.6
7/17/14 8:55 == 46	7/17/14 12:50 == 32.7	7/17/14 16:45 == 45.6	7/17/14 20:40 == 32.8
7/17/14 9:00 == 45.5	7/17/14 12:55 == 32.8	7/17/14 16:50 == 45.6	7/17/14 20:45 == 33
7/17/14 9:05 == 45.9	7/17/14 13:00 == 33.2	7/17/14 16:55 == 45.5	7/17/14 20:50 == 32.9
7/17/14 9:10 == 45.6	7/17/14 13:05 == 33	7/17/14 17:00 == 45.6	7/17/14 20:55 == 33
7/17/14 9:15 == 45.6	7/17/14 13:10 == 33.8	7/17/14 17:05 == 45.5	7/17/14 21:00 == 33.1
7/17/14 9:20 == 45.7	7/17/14 13:15 == 45.8	7/17/14 17:10 == 45.5	7/17/14 21:05 == 33.1
7/17/14 9:25 == 45.6	7/17/14 13:20 == 45.8	7/17/14 17:15 == 45.6	7/17/14 21:10 == 33.8
7/17/14 9:30 == 45.7	7/17/14 13:25 == 45.6	7/17/14 17:20 == 45.6	7/17/14 21:15 == 45.9
7/17/14 9:35 == 45.8	7/17/14 13:30 == 45.7	7/17/14 17:25 == 39.1	7/17/14 21:20 == 45.9
7/17/14 9:40 == 39.2	7/17/14 13:35 == 45.7	7/17/14 17:30 == 31.9	7/17/14 21:25 == 45.7
7/17/14 9:45 == 32.1	7/17/14 13:40 == 46	7/17/14 17:35 == 31.9	7/17/14 21:30 == 45.6
7/17/14 9:50 == 31.7	7/17/14 13:45 == 45.6	7/17/14 17:40 == 32.2	7/17/14 21:35 == 45.6
7/17/14 9:55 == 32.2	7/17/14 13:50 == 45.7	7/17/14 17:45 == 32.3	7/17/14 21:40 == 45.6
7/17/14 10:00 == 32.3	7/17/14 13:55 == 45.7	7/17/14 17:50 == 32.3	7/17/14 21:45 == 45.7
7/17/14 10:05 == 32.4	7/17/14 14:00 == 45.5	7/17/14 17:55 == 32.6	7/17/14 21:50 == 45.7
7/17/14 10:10 == 32.5	7/17/14 14:05 == 45.7	7/17/14 18:00 == 32.7	7/17/14 21:55 == 45.6
7/17/14 10:15 == 32.7	7/17/14 14:10 == 45.6	7/17/14 18:05 == 32.7	7/17/14 22:00 == 45.7
7/17/14 10:20 == 32.7	7/17/14 14:15 == 45.6	7/17/14 18:10 == 32.8	7/17/14 22:05 == 45.7
7/17/14 10:25 == 32.8	7/17/14 14:20 == 45.6	7/17/14 18:15 == 33	7/17/14 22:10 == 45.6
7/17/14 10:30 == 33.1	7/17/14 14:25 == 45.5	7/17/14 18:20 == 33	7/17/14 22:15 == 45.7
7/17/14 10:35 == 33	7/17/14 14:30 == 45.6	7/17/14 18:25 == 33.7	7/17/14 22:20 == 45.7
7/17/14 10:40 == 33.7	7/17/14 14:35 == 45.5	7/17/14 18:30 == 45.9	7/17/14 22:25 == 45.8
7/17/14 10:45 == 45.8	7/17/14 14:40 == 39.1	7/17/14 18:35 == 45.7	7/17/14 22:30 == 45.7
7/17/14 10:50 == 45.8	7/17/14 14:45 == 31.9	7/17/14 18:40 == 45.7	7/17/14 22:35 == 45.8
7/17/14 10:55 == 45.8	7/17/14 14:50 == 32	7/17/14 18:45 == 45.7	7/17/14 22:40 == 45.6
7/17/14 11:00 == 45.8	7/17/14 14:55 == 32.1	7/17/14 18:50 == 45.6	7/17/14 22:45 == 45.7
7/17/14 11:05 == 45.6	7/17/14 15:00 == 32.3	7/17/14 18:55 == 45.7	7/17/14 22:50 == 45.7
7/17/14 11:10 == 45.6	7/17/14 15:05 == 32.3	7/17/14 19:00 == 45.6	7/17/14 22:55 == 38.8
7/17/14 11:15 == 45.6	7/17/14 15:10 == 32.5	7/17/14 19:05 == 45.6	7/17/14 23:00 == 31.9
7/17/14 11:20 == 45.7	7/17/14 15:15 == 32.7	7/17/14 19:10 == 45.6	7/17/14 23:05 == 31.9
7/17/14 11:25 == 45.7	7/17/14 15:20 == 32.7	7/17/14 19:15 == 45.6	7/17/14 23:10 == 32.2
7/17/14 11:30 == 45.6	7/17/14 15:25 == 32.9	7/17/14 19:20 == 45.6	7/17/14 23:15 == 32.4

Pumpback Station Discharge (0364)

7/17/14 23:20 == 32.3	7/18/14 3:15 == 45.6	7/18/14 7:10 == 38.1	7/18/14 11:05 == 45.8
7/17/14 23:25 == 32.6	7/18/14 3:20 == 45.7	7/18/14 7:15 == 31.9	7/18/14 11:10 == 45.8
7/17/14 23:30 == 32.7	7/18/14 3:25 == 45.6	7/18/14 7:20 == 31.9	7/18/14 11:15 == 45.8
7/17/14 23:35 == 32.7	7/18/14 3:30 == 45.6	7/18/14 7:25 == 32.2	7/18/14 11:20 == 45.7
7/17/14 23:40 == 32.9	7/18/14 3:35 == 45.7	7/18/14 7:30 == 32.4	7/18/14 11:25 == 45.9
7/17/14 23:45 == 33	7/18/14 3:40 == 45.9	7/18/14 7:35 == 32.4	7/18/14 11:30 == 45.7
7/17/14 23:50 == 33	7/18/14 3:45 == 45.7	7/18/14 7:40 == 32.7	7/18/14 11:35 == 45.7
7/17/14 23:55 == 34.4	7/18/14 3:50 == 45.6	7/18/14 7:45 == 32.7	7/18/14 11:40 == 45.8
7/18/14 0:00 == 46	7/18/14 3:55 == 45.8	7/18/14 7:50 == 32.7	7/18/14 11:45 == 45.7
7/18/14 0:05 == 45.7	7/18/14 4:00 == 45.7	7/18/14 7:55 == 32.8	7/18/14 11:50 == 45.9
7/18/14 0:10 == 45.7	7/18/14 4:05 == 45.7	7/18/14 8:00 == 33.3	7/18/14 11:55 == 45.7
7/18/14 0:15 == 45.6	7/18/14 4:10 == 45.6	7/18/14 8:05 == 33	7/18/14 12:00 == 45.7
7/18/14 0:20 == 45.7	7/18/14 4:15 == 46	7/18/14 8:10 == 35.1	7/18/14 12:05 == 45.6
7/18/14 0:25 == 45.7	7/18/14 4:20 == 45.6	7/18/14 8:15 == 45.9	7/18/14 12:10 == 45.6
7/18/14 0:30 == 45.7	7/18/14 4:25 == 38.1	7/18/14 8:20 == 45.7	7/18/14 12:15 == 45.5
7/18/14 0:35 == 45.6	7/18/14 4:30 == 32	7/18/14 8:25 == 45.7	7/18/14 12:20 == 45.6
7/18/14 0:40 == 45.7	7/18/14 4:35 == 31.9	7/18/14 8:30 == 46	7/18/14 12:25 == 45.9
7/18/14 0:45 == 45.6	7/18/14 4:40 == 32.2	7/18/14 8:35 == 45.7	7/18/14 12:30 == 45.6
7/18/14 0:50 == 45.6	7/18/14 4:45 == 32.4	7/18/14 8:40 == 45.6	7/18/14 12:35 == 45.8
7/18/14 0:55 == 45.7	7/18/14 4:50 == 32.4	7/18/14 8:45 == 45.6	7/18/14 12:40 == 37.8
7/18/14 1:00 == 45.6	7/18/14 4:55 == 32.6	7/18/14 8:50 == 45.6	7/18/14 12:45 == 32.2
7/18/14 1:05 == 45.5	7/18/14 5:00 == 32.8	7/18/14 8:55 == 45.5	7/18/14 12:50 == 32
7/18/14 1:10 == 45.5	7/18/14 5:05 == 32.7	7/18/14 9:00 == 45.7	7/18/14 12:55 == 32.3
7/18/14 1:15 == 45.6	7/18/14 5:10 == 32.8	7/18/14 9:05 == 45.8	7/18/14 13:00 == 32.5
7/18/14 1:20 == 45.5	7/18/14 5:15 == 33	7/18/14 9:10 == 45.6	7/18/14 13:05 == 32.5
7/18/14 1:25 == 45.5	7/18/14 5:20 == 33.1	7/18/14 9:15 == 46	7/18/14 13:10 == 32.7
7/18/14 1:30 == 45.6	7/18/14 5:25 == 34.9	7/18/14 9:20 == 45.8	7/18/14 13:15 == 32.7
7/18/14 1:35 == 45.7	7/18/14 5:30 == 46	7/18/14 9:25 == 45.5	7/18/14 13:20 == 32.7
7/18/14 1:40 == 38.5	7/18/14 5:35 == 45.7	7/18/14 9:30 == 45.5	7/18/14 13:25 == 32.9
7/18/14 1:45 == 31.9	7/18/14 5:40 == 45.7	7/18/14 9:35 == 45.6	7/18/14 13:30 == 33.2
7/18/14 1:50 == 31.8	7/18/14 5:45 == 45.7	7/18/14 9:40 == 45.5	7/18/14 13:35 == 33.1
7/18/14 1:55 == 32.1	7/18/14 5:50 == 45.8	7/18/14 9:45 == 45.5	7/18/14 13:40 == 35.1
7/18/14 2:00 == 32.4	7/18/14 5:55 == 45.7	7/18/14 9:50 == 45.8	7/18/14 13:45 == 45.9
7/18/14 2:05 == 32.4	7/18/14 6:00 == 46	7/18/14 9:55 == 37.8	7/18/14 13:50 == 45.8
7/18/14 2:10 == 32.6	7/18/14 6:05 == 45.5	7/18/14 10:00 == 32	7/18/14 13:55 == 45.8
7/18/14 2:15 == 32.6	7/18/14 6:10 == 45.7	7/18/14 10:05 == 31.9	7/18/14 14:00 == 45.6
7/18/14 2:20 == 32.7	7/18/14 6:15 == 45.8	7/18/14 10:10 == 32.4	7/18/14 14:05 == 46
7/18/14 2:25 == 33	7/18/14 6:20 == 45.5	7/18/14 10:15 == 32.4	7/18/14 14:10 == 45.7
7/18/14 2:30 == 33	7/18/14 6:25 == 45.9	7/18/14 10:20 == 32.6	7/18/14 14:15 == 46.1
7/18/14 2:35 == 33	7/18/14 6:30 == 45.6	7/18/14 10:25 == 32.6	7/18/14 14:20 == 45.5
7/18/14 2:40 == 34.8	7/18/14 6:35 == 45.7	7/18/14 10:30 == 32.8	7/18/14 14:25 == 45.6
7/18/14 2:45 == 45.9	7/18/14 6:40 == 45.9	7/18/14 10:35 == 32.8	7/18/14 14:30 == 45.7
7/18/14 2:50 == 45.8	7/18/14 6:45 == 45.7	7/18/14 10:40 == 32.9	7/18/14 14:35 == 45.8
7/18/14 2:55 == 45.7	7/18/14 6:50 == 45.5	7/18/14 10:45 == 33	7/18/14 14:40 == 45.7
7/18/14 3:00 == 45.8	7/18/14 6:55 == 45.6	7/18/14 10:50 == 33.1	7/18/14 14:45 == 45.5
7/18/14 3:05 == 45.7	7/18/14 7:00 == 45.7	7/18/14 10:55 == 35.3	7/18/14 14:50 == 45.6
7/18/14 3:10 == 45.8	7/18/14 7:05 == 45.6	7/18/14 11:00 == 46	7/18/14 14:55 == 45.6

Pumpback Station Discharge (0364)

7/18/14 15:00 == 45.8	7/18/14 18:55 == 35.6	7/18/14 22:50 == 45.6	7/19/14 2:45 == 33.2
7/18/14 15:05 == 45.7	7/18/14 19:00 == 45.8	7/18/14 22:55 == 45.7	7/19/14 2:50 == 33.1
7/18/14 15:10 == 45.7	7/18/14 19:05 == 45.7	7/18/14 23:00 == 45.6	7/19/14 2:55 == 29.3
7/18/14 15:15 == 45.9	7/18/14 19:10 == 45.8	7/18/14 23:05 == 45.7	7/19/14 3:00 == 27
7/18/14 15:20 == 45.7	7/18/14 19:15 == 45.6	7/18/14 23:10 == 36.9	7/19/14 3:05 == 27
7/18/14 15:25 == 37.7	7/18/14 19:20 == 45.7	7/18/14 23:15 == 31.9	7/19/14 3:10 == 27
7/18/14 15:30 == 31.9	7/18/14 19:25 == 45.5	7/18/14 23:20 == 32	7/19/14 3:15 == 27.1
7/18/14 15:35 == 31.9	7/18/14 19:30 == 45.6	7/18/14 23:25 == 32.3	7/19/14 3:20 == 27.2
7/18/14 15:40 == 32.2	7/18/14 19:35 == 45.6	7/18/14 23:30 == 32.5	7/19/14 3:25 == 27.1
7/18/14 15:45 == 32.4	7/18/14 19:40 == 45.5	7/18/14 23:35 == 32.5	7/19/14 3:30 == 27.1
7/18/14 15:50 == 32.3	7/18/14 19:45 == 45.5	7/18/14 23:40 == 32.6	7/19/14 3:35 == 27.1
7/18/14 15:55 == 32.6	7/18/14 19:50 == 45.8	7/18/14 23:45 == 32.7	7/19/14 3:40 == 27.1
7/18/14 16:00 == 32.7	7/18/14 19:55 == 45.6	7/18/14 23:50 == 32.9	7/19/14 3:45 == 27.2
7/18/14 16:05 == 32.7	7/18/14 20:00 == 45.6	7/18/14 23:55 == 33	7/19/14 3:50 == 27.1
7/18/14 16:10 == 32.8	7/18/14 20:05 == 45.6	7/19/14 0:00 == 33.2	7/19/14 3:55 == 27.1
7/18/14 16:15 == 32.9	7/18/14 20:10 == 45.6	7/19/14 0:05 == 33	7/19/14 4:00 == 27.1
7/18/14 16:20 == 32.9	7/18/14 20:15 == 45.6	7/19/14 0:10 == 35.9	7/19/14 4:05 == 27.1
7/18/14 16:25 == 35.1	7/18/14 20:20 == 45.6	7/19/14 0:15 == 45.8	7/19/14 4:10 == 27.2
7/18/14 16:30 == 45.8	7/18/14 20:25 == 37.8	7/19/14 0:20 == 45.8	7/19/14 4:15 == 27.2
7/18/14 16:35 == 45.9	7/18/14 20:30 == 32	7/19/14 0:25 == 45.6	7/19/14 4:20 == 27.1
7/18/14 16:40 == 45.8	7/18/14 20:35 == 32.1	7/19/14 0:30 == 45.7	7/19/14 4:25 == 27.2
7/18/14 16:45 == 45.7	7/18/14 20:40 == 32.3	7/19/14 0:35 == 45.7	7/19/14 4:30 == 27.2
7/18/14 16:50 == 45.6	7/18/14 20:45 == 32.5	7/19/14 0:40 == 45.8	7/19/14 4:35 == 27.2
7/18/14 16:55 == 45.6	7/18/14 20:50 == 32.5	7/19/14 0:45 == 45.7	7/19/14 4:40 == 27.2
7/18/14 17:00 == 45.6	7/18/14 20:55 == 32.7	7/19/14 0:50 == 45.7	7/19/14 4:45 == 27.1
7/18/14 17:05 == 45.7	7/18/14 21:00 == 32.7	7/19/14 0:55 == 45.7	7/19/14 4:50 == 27.2
7/18/14 17:10 == 45.7	7/18/14 21:05 == 32.8	7/19/14 1:00 == 45.6	7/19/14 4:55 == 27.1
7/18/14 17:15 == 45.7	7/18/14 21:10 == 33	7/19/14 1:05 == 45.7	7/19/14 5:00 == 27.2
7/18/14 17:20 == 45.7	7/18/14 21:15 == 33.1	7/19/14 1:10 == 45.8	7/19/14 5:05 == 27.2
7/18/14 17:25 == 45.6	7/18/14 21:20 == 33.1	7/19/14 1:15 == 45.6	7/19/14 5:10 == 27.2
7/18/14 17:30 == 45.6	7/18/14 21:25 == 35.7	7/19/14 1:20 == 45.8	7/19/14 5:15 == 27.2
7/18/14 17:35 == 45.6	7/18/14 21:30 == 45.9	7/19/14 1:25 == 45.6	7/19/14 5:20 == 27.1
7/18/14 17:40 == 45.6	7/18/14 21:35 == 45.8	7/19/14 1:30 == 45.7	7/19/14 5:25 == 27.2
7/18/14 17:45 == 45.6	7/18/14 21:40 == 45.8	7/19/14 1:35 == 45.7	7/19/14 5:30 == 27.1
7/18/14 17:50 == 45.6	7/18/14 21:45 == 45.9	7/19/14 1:40 == 45.7	7/19/14 5:35 == 27.2
7/18/14 17:55 == 37.7	7/18/14 21:50 == 45.7	7/19/14 1:45 == 45.7	7/19/14 5:40 == 27.2
7/18/14 18:00 == 31.8	7/18/14 21:55 == 45.7	7/19/14 1:50 == 45.6	7/19/14 5:45 == 27.1
7/18/14 18:05 == 32	7/18/14 22:00 == 45.6	7/19/14 1:55 == 36.8	7/19/14 5:50 == 27.2
7/18/14 18:10 == 32.3	7/18/14 22:05 == 45.7	7/19/14 2:00 == 32	7/19/14 5:55 == 27.2
7/18/14 18:15 == 32.5	7/18/14 22:10 == 45.7	7/19/14 2:05 == 32	7/19/14 6:00 == 27.2
7/18/14 18:20 == 32.5	7/18/14 22:15 == 45.7	7/19/14 2:10 == 32.3	7/19/14 6:05 == 27.3
7/18/14 18:25 == 32.6	7/18/14 22:20 == 45.6	7/19/14 2:15 == 32.4	7/19/14 6:10 == 27.2
7/18/14 18:30 == 32.7	7/18/14 22:25 == 45.7	7/19/14 2:20 == 32.4	7/19/14 6:15 == 27.2
7/18/14 18:35 == 32.7	7/18/14 22:30 == 45.6	7/19/14 2:25 == 32.7	7/19/14 6:20 == 27.2
7/18/14 18:40 == 32.9	7/18/14 22:35 == 45.7	7/19/14 2:30 == 32.9	7/19/14 6:25 == 27.3
7/18/14 18:45 == 33	7/18/14 22:40 == 45.6	7/19/14 2:35 == 32.8	7/19/14 6:30 == 27.2
7/18/14 18:50 == 33	7/18/14 22:45 == 45.6	7/19/14 2:40 == 32.9	7/19/14 6:35 == 27.2

Pumpback Station Discharge (0364)

7/19/14 6:40 == 27.2	7/19/14 10:35 == 45.8	7/19/14 14:30 == 45.6	7/19/14 18:25 == 45.6
7/19/14 6:45 == 27.1	7/19/14 10:40 == 45.8	7/19/14 14:35 == 45.7	7/19/14 18:30 == 45.7
7/19/14 6:50 == 27.2	7/19/14 10:45 == 45.8	7/19/14 14:40 == 45.6	7/19/14 18:35 == 45.6
7/19/14 6:55 == 27.2	7/19/14 10:50 == 45.8	7/19/14 14:45 == 45.6	7/19/14 18:40 == 45.7
7/19/14 7:00 == 27.3	7/19/14 10:55 == 45.7	7/19/14 14:50 == 45.6	7/19/14 18:45 == 45.5
7/19/14 7:05 == 27.3	7/19/14 11:00 == 45.8	7/19/14 14:55 == 45.7	7/19/14 18:50 == 45.5
7/19/14 7:10 == 27.3	7/19/14 11:05 == 45.8	7/19/14 15:00 == 45.7	7/19/14 18:55 == 45.7
7/19/14 7:15 == 27.2	7/19/14 11:10 == 45.7	7/19/14 15:05 == 45.7	7/19/14 19:00 == 45.6
7/19/14 7:20 == 32.8	7/19/14 11:15 == 45.7	7/19/14 15:10 == 45.5	7/19/14 19:05 == 45.6
7/19/14 7:25 == 46.2	7/19/14 11:20 == 45.8	7/19/14 15:15 == 45.6	7/19/14 19:10 == 45.6
7/19/14 7:30 == 45.9	7/19/14 11:25 == 45.9	7/19/14 15:20 == 45.6	7/19/14 19:15 == 45.6
7/19/14 7:35 == 45.9	7/19/14 11:30 == 45.7	7/19/14 15:25 == 45.7	7/19/14 19:20 == 45.5
7/19/14 7:40 == 46	7/19/14 11:35 == 45.8	7/19/14 15:30 == 45.7	7/19/14 19:25 == 45.5
7/19/14 7:45 == 45.9	7/19/14 11:40 == 45.8	7/19/14 15:35 == 45.6	7/19/14 19:30 == 45.6
7/19/14 7:50 == 46	7/19/14 11:45 == 45.7	7/19/14 15:40 == 45.7	7/19/14 19:35 == 45.6
7/19/14 7:55 == 45.9	7/19/14 11:50 == 45.8	7/19/14 15:45 == 45.6	7/19/14 19:40 == 45.6
7/19/14 8:00 == 45.9	7/19/14 11:55 == 45.8	7/19/14 15:50 == 45.7	7/19/14 19:45 == 45.7
7/19/14 8:05 == 46	7/19/14 12:00 == 45.8	7/19/14 15:55 == 45.6	7/19/14 19:50 == 45.5
7/19/14 8:10 == 45.9	7/19/14 12:05 == 45.7	7/19/14 16:00 == 45.5	7/19/14 19:55 == 45.5
7/19/14 8:15 == 45.9	7/19/14 12:10 == 45.9	7/19/14 16:05 == 45.7	7/19/14 20:00 == 45.5
7/19/14 8:20 == 45.9	7/19/14 12:15 == 45.8	7/19/14 16:10 == 45.7	7/19/14 20:05 == 45.6
7/19/14 8:25 == 45.8	7/19/14 12:20 == 45.8	7/19/14 16:15 == 45.8	7/19/14 20:10 == 45.6
7/19/14 8:30 == 45.9	7/19/14 12:25 == 45.8	7/19/14 16:20 == 45.6	7/19/14 20:15 == 45.6
7/19/14 8:35 == 45.9	7/19/14 12:30 == 45.9	7/19/14 16:25 == 45.7	7/19/14 20:20 == 45.6
7/19/14 8:40 == 45.9	7/19/14 12:35 == 46	7/19/14 16:30 == 45.7	7/19/14 20:25 == 45.6
7/19/14 8:45 == 45.8	7/19/14 12:40 == 45.6	7/19/14 16:35 == 45.7	7/19/14 20:30 == 45.6
7/19/14 8:50 == 45.8	7/19/14 12:45 == 45.7	7/19/14 16:40 == 45.6	7/19/14 20:35 == 45.5
7/19/14 8:55 == 45.9	7/19/14 12:50 == 45.7	7/19/14 16:45 == 45.7	7/19/14 20:40 == 45.6
7/19/14 9:00 == 46	7/19/14 12:55 == 45.6	7/19/14 16:50 == 45.7	7/19/14 20:45 == 45.5
7/19/14 9:05 == 45.9	7/19/14 13:00 == 45.6	7/19/14 16:55 == 45.7	7/19/14 20:50 == 45.6
7/19/14 9:10 == 45.8	7/19/14 13:05 == 45.6	7/19/14 17:00 == 45.6	7/19/14 20:55 == 45.6
7/19/14 9:15 == 45.9	7/19/14 13:10 == 45.7	7/19/14 17:05 == 45.6	7/19/14 21:00 == 45.5
7/19/14 9:20 == 45.8	7/19/14 13:15 == 45.8	7/19/14 17:10 == 45.7	7/19/14 21:05 == 45.5
7/19/14 9:25 == 45.7	7/19/14 13:20 == 45.7	7/19/14 17:15 == 45.6	7/19/14 21:10 == 45.6
7/19/14 9:30 == 45.9	7/19/14 13:25 == 45.7	7/19/14 17:20 == 45.6	7/19/14 21:15 == 45.6
7/19/14 9:35 == 46	7/19/14 13:30 == 45.7	7/19/14 17:25 == 45.6	7/19/14 21:20 == 45.5
7/19/14 9:40 == 45.8	7/19/14 13:35 == 45.8	7/19/14 17:30 == 45.6	7/19/14 21:25 == 35.7
7/19/14 9:45 == 45.8	7/19/14 13:40 == 45.6	7/19/14 17:35 == 45.6	7/19/14 21:30 == 31.7
7/19/14 9:50 == 45.8	7/19/14 13:45 == 45.6	7/19/14 17:40 == 45.6	7/19/14 21:35 == 31.9
7/19/14 9:55 == 45.9	7/19/14 13:50 == 45.7	7/19/14 17:45 == 45.6	7/19/14 21:40 == 32.3
7/19/14 10:00 == 45.8	7/19/14 13:55 == 45.7	7/19/14 17:50 == 45.6	7/19/14 21:45 == 32.4
7/19/14 10:05 == 46	7/19/14 14:00 == 45.7	7/19/14 17:55 == 45.7	7/19/14 21:50 == 32.3
7/19/14 10:10 == 45.8	7/19/14 14:05 == 46	7/19/14 18:00 == 45.7	7/19/14 21:55 == 32.7
7/19/14 10:15 == 45.9	7/19/14 14:10 == 45.7	7/19/14 18:05 == 45.7	7/19/14 22:00 == 32.7
7/19/14 10:20 == 45.9	7/19/14 14:15 == 45.7	7/19/14 18:10 == 45.6	7/19/14 22:05 == 32.8
7/19/14 10:25 == 45.8	7/19/14 14:20 == 45.7	7/19/14 18:15 == 45.7	7/19/14 22:10 == 32.9
7/19/14 10:30 == 45.8	7/19/14 14:25 == 45.7	7/19/14 18:20 == 45.6	7/19/14 22:15 == 33

Pumpback Station Discharge (0364)

7/19/14 22:20 == 33	7/20/14 2:15 == 45.7	7/20/14 6:10 == 35.1	7/20/14 10:05 == 33.1
7/19/14 22:25 == 37.6	7/20/14 2:20 == 45.7	7/20/14 6:15 == 32.1	7/20/14 10:10 == 37.9
7/19/14 22:30 == 45.8	7/20/14 2:25 == 45.6	7/20/14 6:20 == 32	7/20/14 10:15 == 45.8
7/19/14 22:35 == 45.7	7/20/14 2:30 == 45.7	7/20/14 6:25 == 32.4	7/20/14 10:20 == 45.6
7/19/14 22:40 == 45.9	7/20/14 2:35 == 45.7	7/20/14 6:30 == 32.5	7/20/14 10:25 == 45.8
7/19/14 22:45 == 45.7	7/20/14 2:40 == 45.7	7/20/14 6:35 == 32.5	7/20/14 10:30 == 45.7
7/19/14 22:50 == 45.9	7/20/14 2:45 == 45.7	7/20/14 6:40 == 32.8	7/20/14 10:35 == 45.7
7/19/14 22:55 == 45.8	7/20/14 2:50 == 45.7	7/20/14 6:45 == 32.9	7/20/14 10:40 == 45.8
7/19/14 23:00 == 45.7	7/20/14 2:55 == 45.6	7/20/14 6:50 == 32.9	7/20/14 10:45 == 45.8
7/19/14 23:05 == 45.7	7/20/14 3:00 == 45.7	7/20/14 6:55 == 33.1	7/20/14 10:50 == 45.6
7/19/14 23:10 == 45.7	7/20/14 3:05 == 45.6	7/20/14 7:00 == 33.1	7/20/14 10:55 == 45.6
7/19/14 23:15 == 45.7	7/20/14 3:10 == 45.7	7/20/14 7:05 == 33.2	7/20/14 11:00 == 45.6
7/19/14 23:20 == 45.7	7/20/14 3:15 == 45.5	7/20/14 7:10 == 38	7/20/14 11:05 == 45.7
7/19/14 23:25 == 45.7	7/20/14 3:20 == 45.8	7/20/14 7:15 == 45.9	7/20/14 11:10 == 45.8
7/19/14 23:30 == 45.8	7/20/14 3:25 == 35.2	7/20/14 7:20 == 45.9	7/20/14 11:15 == 45.7
7/19/14 23:35 == 45.7	7/20/14 3:30 == 31.8	7/20/14 7:25 == 45.8	7/20/14 11:20 == 45.7
7/19/14 23:40 == 45.6	7/20/14 3:35 == 31.9	7/20/14 7:30 == 45.7	7/20/14 11:25 == 45.6
7/19/14 23:45 == 45.7	7/20/14 3:40 == 32.3	7/20/14 7:35 == 45.8	7/20/14 11:30 == 45.7
7/19/14 23:50 == 45.7	7/20/14 3:45 == 32.5	7/20/14 7:40 == 45.8	7/20/14 11:35 == 45.7
7/19/14 23:55 == 45.7	7/20/14 3:50 == 32.6	7/20/14 7:45 == 45.7	7/20/14 11:40 == 45.6
7/20/14 0:00 == 45.7	7/20/14 3:55 == 32.9	7/20/14 7:50 == 45.7	7/20/14 11:45 == 45.6
7/20/14 0:05 == 45.6	7/20/14 4:00 == 32.8	7/20/14 7:55 == 45.7	7/20/14 11:50 == 45.6
7/20/14 0:10 == 45.6	7/20/14 4:05 == 32.8	7/20/14 8:00 == 45.7	7/20/14 11:55 == 35
7/20/14 0:15 == 45.6	7/20/14 4:10 == 33	7/20/14 8:05 == 45.7	7/20/14 12:00 == 32
7/20/14 0:20 == 45.6	7/20/14 4:15 == 33.1	7/20/14 8:10 == 45.7	7/20/14 12:05 == 32
7/20/14 0:25 == 35.4	7/20/14 4:20 == 33	7/20/14 8:15 == 45.6	7/20/14 12:10 == 32.4
7/20/14 0:30 == 32	7/20/14 4:25 == 37.8	7/20/14 8:20 == 45.6	7/20/14 12:15 == 32.4
7/20/14 0:35 == 32.1	7/20/14 4:30 == 45.8	7/20/14 8:25 == 45.7	7/20/14 12:20 == 32.4
7/20/14 0:40 == 32.4	7/20/14 4:35 == 45.8	7/20/14 8:30 == 45.7	7/20/14 12:25 == 32.7
7/20/14 0:45 == 32.5	7/20/14 4:40 == 45.7	7/20/14 8:35 == 45.8	7/20/14 12:30 == 32.8
7/20/14 0:50 == 32.5	7/20/14 4:45 == 45.6	7/20/14 8:40 == 45.7	7/20/14 12:35 == 32.8
7/20/14 0:55 == 32.8	7/20/14 4:50 == 45.7	7/20/14 8:45 == 45.6	7/20/14 12:40 == 33
7/20/14 1:00 == 32.7	7/20/14 4:55 == 45.7	7/20/14 8:50 == 45.6	7/20/14 12:45 == 33
7/20/14 1:05 == 32.8	7/20/14 5:00 == 45.7	7/20/14 8:55 == 45.7	7/20/14 12:50 == 33.1
7/20/14 1:10 == 33	7/20/14 5:05 == 45.7	7/20/14 9:00 == 45.6	7/20/14 12:55 == 38.1
7/20/14 1:15 == 33.1	7/20/14 5:10 == 45.8	7/20/14 9:05 == 45.6	7/20/14 13:00 == 45.7
7/20/14 1:20 == 33.2	7/20/14 5:15 == 45.8	7/20/14 9:10 == 35	7/20/14 13:05 == 45.7
7/20/14 1:25 == 37.6	7/20/14 5:20 == 45.7	7/20/14 9:15 == 31.8	7/20/14 13:10 == 45.7
7/20/14 1:30 == 45.8	7/20/14 5:25 == 45.7	7/20/14 9:20 == 31.9	7/20/14 13:15 == 45.7
7/20/14 1:35 == 45.9	7/20/14 5:30 == 45.7	7/20/14 9:25 == 32.3	7/20/14 13:20 == 45.7
7/20/14 1:40 == 45.7	7/20/14 5:35 == 45.7	7/20/14 9:30 == 32.2	7/20/14 13:25 == 45.7
7/20/14 1:45 == 45.8	7/20/14 5:40 == 45.7	7/20/14 9:35 == 32.3	7/20/14 13:30 == 45.7
7/20/14 1:50 == 45.8	7/20/14 5:45 == 45.8	7/20/14 9:40 == 32.7	7/20/14 13:35 == 45.6
7/20/14 1:55 == 45.7	7/20/14 5:50 == 45.7	7/20/14 9:45 == 32.7	7/20/14 13:40 == 45.6
7/20/14 2:00 == 45.7	7/20/14 5:55 == 45.8	7/20/14 9:50 == 32.7	7/20/14 13:45 == 45.6
7/20/14 2:05 == 45.7	7/20/14 6:00 == 45.7	7/20/14 9:55 == 32.8	7/20/14 13:50 == 45.6
7/20/14 2:10 == 45.6	7/20/14 6:05 == 45.6	7/20/14 10:00 == 33.1	7/20/14 13:55 == 45.8

Pumpback Station Discharge (0364)

7/20/14 14:00 == 45.6	7/20/14 17:55 == 32.6	7/20/14 21:50 == 45.7	7/21/14 1:45 == 31.8
7/20/14 14:05 == 45.6	7/20/14 18:00 == 32.7	7/20/14 21:55 == 45.8	7/21/14 1:50 == 31.9
7/20/14 14:10 == 45.5	7/20/14 18:05 == 32.8	7/20/14 22:00 == 45.7	7/21/14 1:55 == 32.2
7/20/14 14:15 == 45.6	7/20/14 18:10 == 32.9	7/20/14 22:05 == 45.6	7/21/14 2:00 == 32.4
7/20/14 14:20 == 45.6	7/20/14 18:15 == 33.1	7/20/14 22:10 == 45.7	7/21/14 2:05 == 32.5
7/20/14 14:25 == 45.6	7/20/14 18:20 == 33	7/20/14 22:15 == 45.6	7/21/14 2:10 == 32.7
7/20/14 14:30 == 45.7	7/20/14 18:25 == 38.5	7/20/14 22:20 == 45.8	7/21/14 2:15 == 32.8
7/20/14 14:35 == 45.5	7/20/14 18:30 == 45.8	7/20/14 22:25 == 45.6	7/21/14 2:20 == 32.9
7/20/14 14:40 == 34.8	7/20/14 18:35 == 45.8	7/20/14 22:30 == 45.6	7/21/14 2:25 == 33
7/20/14 14:45 == 32	7/20/14 18:40 == 45.9	7/20/14 22:35 == 45.8	7/21/14 2:30 == 33
7/20/14 14:50 == 31.9	7/20/14 18:45 == 45.8	7/20/14 22:40 == 45.5	7/21/14 2:35 == 33.1
7/20/14 14:55 == 32.3	7/20/14 18:50 == 45.8	7/20/14 22:45 == 45.6	7/21/14 2:40 == 39.1
7/20/14 15:00 == 32.4	7/20/14 18:55 == 45.7	7/20/14 22:50 == 45.7	7/21/14 2:45 == 45.8
7/20/14 15:05 == 32.4	7/20/14 19:00 == 45.6	7/20/14 22:55 == 33.9	7/21/14 2:50 == 45.8
7/20/14 15:10 == 32.7	7/20/14 19:05 == 45.6	7/20/14 23:00 == 31.9	7/21/14 2:55 == 45.7
7/20/14 15:15 == 32.8	7/20/14 19:10 == 45.6	7/20/14 23:05 == 31.9	7/21/14 3:00 == 45.7
7/20/14 15:20 == 32.8	7/20/14 19:15 == 45.7	7/20/14 23:10 == 32.2	7/21/14 3:05 == 45.7
7/20/14 15:25 == 32.9	7/20/14 19:20 == 45.7	7/20/14 23:15 == 32.3	7/21/14 3:10 == 45.7
7/20/14 15:30 == 33	7/20/14 19:25 == 45.7	7/20/14 23:20 == 32.3	7/21/14 3:15 == 45.6
7/20/14 15:35 == 33.1	7/20/14 19:30 == 45.7	7/20/14 23:25 == 32.7	7/21/14 3:20 == 45.7
7/20/14 15:40 == 38.2	7/20/14 19:35 == 45.7	7/20/14 23:30 == 32.7	7/21/14 3:25 == 45.7
7/20/14 15:45 == 45.8	7/20/14 19:40 == 45.7	7/20/14 23:35 == 32.7	7/21/14 3:30 == 45.7
7/20/14 15:50 == 45.8	7/20/14 19:45 == 45.7	7/20/14 23:40 == 33	7/21/14 3:35 == 45.7
7/20/14 15:55 == 45.8	7/20/14 19:50 == 45.5	7/20/14 23:45 == 33.1	7/21/14 3:40 == 46
7/20/14 16:00 == 45.8	7/20/14 19:55 == 45.6	7/20/14 23:50 == 33.1	7/21/14 3:45 == 45.8
7/20/14 16:05 == 45.7	7/20/14 20:00 == 45.6	7/20/14 23:55 == 39	7/21/14 3:50 == 45.9
7/20/14 16:10 == 45.7	7/20/14 20:05 == 45.7	7/21/14 0:00 == 45.8	7/21/14 3:55 == 45.7
7/20/14 16:15 == 45.6	7/20/14 20:10 == 34	7/21/14 0:05 == 45.7	7/21/14 4:00 == 45.7
7/20/14 16:20 == 45.7	7/20/14 20:15 == 31.8	7/21/14 0:10 == 45.7	7/21/14 4:05 == 45.6
7/20/14 16:25 == 45.6	7/20/14 20:20 == 31.9	7/21/14 0:15 == 45.7	7/21/14 4:10 == 45.8
7/20/14 16:30 == 45.7	7/20/14 20:25 == 32.3	7/21/14 0:20 == 45.7	7/21/14 4:15 == 45.8
7/20/14 16:35 == 45.6	7/20/14 20:30 == 32.4	7/21/14 0:25 == 45.7	7/21/14 4:20 == 45.8
7/20/14 16:40 == 45.6	7/20/14 20:35 == 32.3	7/21/14 0:30 == 45.6	7/21/14 4:25 == 33.6
7/20/14 16:45 == 45.5	7/20/14 20:40 == 32.7	7/21/14 0:35 == 45.7	7/21/14 4:30 == 31.9
7/20/14 16:50 == 45.6	7/20/14 20:45 == 32.7	7/21/14 0:40 == 45.7	7/21/14 4:35 == 32
7/20/14 16:55 == 45.6	7/20/14 20:50 == 32.7	7/21/14 0:45 == 45.7	7/21/14 4:40 == 32.6
7/20/14 17:00 == 45.6	7/20/14 20:55 == 33	7/21/14 0:50 == 45.6	7/21/14 4:45 == 32.3
7/20/14 17:05 == 45.6	7/20/14 21:00 == 33	7/21/14 0:55 == 45.7	7/21/14 4:50 == 32.4
7/20/14 17:10 == 45.7	7/20/14 21:05 == 33	7/21/14 1:00 == 45.6	7/21/14 4:55 == 32.7
7/20/14 17:15 == 45.6	7/20/14 21:10 == 38.7	7/21/14 1:05 == 45.6	7/21/14 5:00 == 32.8
7/20/14 17:20 == 45.6	7/20/14 21:15 == 45.8	7/21/14 1:10 == 45.6	7/21/14 5:05 == 32.8
7/20/14 17:25 == 34.5	7/20/14 21:20 == 45.8	7/21/14 1:15 == 45.7	7/21/14 5:10 == 33.1
7/20/14 17:30 == 31.8	7/20/14 21:25 == 45.8	7/21/14 1:20 == 45.6	7/21/14 5:15 == 33
7/20/14 17:35 == 31.8	7/20/14 21:30 == 45.7	7/21/14 1:25 == 45.7	7/21/14 5:20 == 33
7/20/14 17:40 == 32.3	7/20/14 21:35 == 45.7	7/21/14 1:30 == 45.6	7/21/14 5:25 == 39.2
7/20/14 17:45 == 32.3	7/20/14 21:40 == 45.8	7/21/14 1:35 == 45.6	7/21/14 5:30 == 45.9
7/20/14 17:50 == 32.3	7/20/14 21:45 == 45.8	7/21/14 1:40 == 33.7	7/21/14 5:35 == 45.8

Pumpback Station Discharge (0364)

7/21/14 5:40 == 45.7	7/21/14 9:35 == 31	7/21/14 13:30 == 30.9	7/21/14 17:25 == 31.4
7/21/14 5:45 == 45.8	7/21/14 9:40 == 31	7/21/14 13:35 == 30.7	7/21/14 17:30 == 31.4
7/21/14 5:50 == 45.9	7/21/14 9:45 == 31	7/21/14 13:40 == 30.7	7/21/14 17:35 == 31.3
7/21/14 5:55 == 45.8	7/21/14 9:50 == 30.9	7/21/14 13:45 == 30.7	7/21/14 17:40 == 31.2
7/21/14 6:00 == 45.6	7/21/14 9:55 == 30.9	7/21/14 13:50 == 30.7	7/21/14 17:45 == 31.1
7/21/14 6:05 == 45.7	7/21/14 10:00 == 31	7/21/14 13:55 == 15.8	7/21/14 17:50 == 31.2
7/21/14 6:10 == 45.8	7/21/14 10:05 == 30.9	7/21/14 14:00 == 13.2	7/21/14 17:55 == 31.1
7/21/14 6:15 == 45.7	7/21/14 10:10 == 30.9	7/21/14 14:05 == 13.2	7/21/14 18:00 == 31.1
7/21/14 6:20 == 45.8	7/21/14 10:15 == 30.9	7/21/14 14:10 == 13.9	7/21/14 18:05 == 31.1
7/21/14 6:25 == 45.7	7/21/14 10:20 == 31	7/21/14 14:15 == 14	7/21/14 18:10 == 30.9
7/21/14 6:30 == 45.7	7/21/14 10:25 == 30.8	7/21/14 14:20 == 14	7/21/14 18:15 == 30.9
7/21/14 6:35 == 45.8	7/21/14 10:30 == 30.7	7/21/14 14:25 == 29.4	7/21/14 18:20 == 30.9
7/21/14 6:40 == 45.7	7/21/14 10:35 == 30.7	7/21/14 14:30 == 31.9	7/21/14 18:25 == 30.8
7/21/14 6:45 == 45.6	7/21/14 10:40 == 30.8	7/21/14 14:35 == 31.9	7/21/14 18:30 == 30.8
7/21/14 6:50 == 45.6	7/21/14 10:45 == 30.7	7/21/14 14:40 == 31.8	7/21/14 18:35 == 30.9
7/21/14 6:55 == 45.9	7/21/14 10:50 == 30.6	7/21/14 14:45 == 31.5	7/21/14 18:40 == 30.8
7/21/14 7:00 == 45.7	7/21/14 10:55 == 30.6	7/21/14 14:50 == 31.6	7/21/14 18:45 == 30.6
7/21/14 7:05 == 45.8	7/21/14 11:00 == 30.7	7/21/14 14:55 == 31.5	7/21/14 18:50 == 30.7
7/21/14 7:10 == 33.5	7/21/14 11:05 == 30.6	7/21/14 15:00 == 31.3	7/21/14 18:55 == 15.7
7/21/14 7:15 == 31.9	7/21/14 11:10 == 16.9	7/21/14 15:05 == 31.4	7/21/14 19:00 == 13.2
7/21/14 7:20 == 31.7	7/21/14 11:15 == 13.2	7/21/14 15:10 == 31.2	7/21/14 19:05 == 13.2
7/21/14 7:25 == 31.7	7/21/14 11:20 == 13.2	7/21/14 15:15 == 31.3	7/21/14 19:10 == 14
7/21/14 7:30 == 31.7	7/21/14 11:25 == 13.9	7/21/14 15:20 == 31.1	7/21/14 19:15 == 14
7/21/14 7:35 == 31.7	7/21/14 11:30 == 13.9	7/21/14 15:25 == 31	7/21/14 19:20 == 14
7/21/14 7:40 == 31.7	7/21/14 11:35 == 14	7/21/14 15:30 == 31.1	7/21/14 19:25 == 29.8
7/21/14 7:45 == 31.7	7/21/14 11:40 == 29.4	7/21/14 15:35 == 31	7/21/14 19:30 == 31.9
7/21/14 7:50 == 31.8	7/21/14 11:45 == 31.9	7/21/14 15:40 == 31	7/21/14 19:35 == 31.8
7/21/14 7:55 == 31.5	7/21/14 11:50 == 32.1	7/21/14 15:45 == 31	7/21/14 19:40 == 31.6
7/21/14 8:00 == 31.6	7/21/14 11:55 == 31.7	7/21/14 15:50 == 31	7/21/14 19:45 == 31.6
7/21/14 8:05 == 31.7	7/21/14 12:00 == 31.7	7/21/14 15:55 == 30.9	7/21/14 19:50 == 31.5
7/21/14 8:10 == 31.3	7/21/14 12:05 == 31.6	7/21/14 16:00 == 30.8	7/21/14 19:55 == 31.4
7/21/14 8:15 == 31.4	7/21/14 12:10 == 31.3	7/21/14 16:05 == 30.8	7/21/14 20:00 == 31.4
7/21/14 8:20 == 31.5	7/21/14 12:15 == 31.4	7/21/14 16:10 == 30.8	7/21/14 20:05 == 31.4
7/21/14 8:25 == 31.4	7/21/14 12:20 == 31.4	7/21/14 16:15 == 30.7	7/21/14 20:10 == 31.1
7/21/14 8:30 == 31.3	7/21/14 12:25 == 31.2	7/21/14 16:20 == 30.8	7/21/14 20:15 == 31.2
7/21/14 8:35 == 31.5	7/21/14 12:30 == 31.2	7/21/14 16:25 == 15.8	7/21/14 20:20 == 31.3
7/21/14 8:40 == 31.2	7/21/14 12:35 == 31.2	7/21/14 16:30 == 13.2	7/21/14 20:25 == 31.1
7/21/14 8:45 == 31.4	7/21/14 12:40 == 31.1	7/21/14 16:35 == 13.2	7/21/14 20:30 == 31.1
7/21/14 8:50 == 31.3	7/21/14 12:45 == 31	7/21/14 16:40 == 14	7/21/14 20:35 == 31
7/21/14 8:55 == 31.3	7/21/14 12:50 == 31.2	7/21/14 16:45 == 14	7/21/14 20:40 == 31
7/21/14 9:00 == 31.2	7/21/14 12:55 == 31.1	7/21/14 16:50 == 14.1	7/21/14 20:45 == 31
7/21/14 9:05 == 31.3	7/21/14 13:00 == 31.1	7/21/14 16:55 == 29.5	7/21/14 20:50 == 31
7/21/14 9:10 == 31.3	7/21/14 13:05 == 31.1	7/21/14 17:00 == 31.9	7/21/14 20:55 == 30.9
7/21/14 9:15 == 31.2	7/21/14 13:10 == 30.9	7/21/14 17:05 == 32	7/21/14 21:00 == 30.8
7/21/14 9:20 == 31.1	7/21/14 13:15 == 30.9	7/21/14 17:10 == 31.6	7/21/14 21:05 == 30.8
7/21/14 9:25 == 31.1	7/21/14 13:20 == 31	7/21/14 17:15 == 31.6	7/21/14 21:10 == 30.7
7/21/14 9:30 == 31.1	7/21/14 13:25 == 30.9	7/21/14 17:20 == 31.6	7/21/14 21:15 == 30.8

Pumpback Station Discharge (0364)

7/21/14 21:20 == 30.8	7/22/14 1:15 == 18.5	7/22/14 5:10 == 45.8	7/22/14 9:05 == 18.5
7/21/14 21:25 == 30.7	7/22/14 1:20 == 18.5	7/22/14 5:15 == 45.6	7/22/14 9:10 == 18.5
7/21/14 21:30 == 30.8	7/22/14 1:25 == 18.5	7/22/14 5:20 == 45.8	7/22/14 9:15 == 18.5
7/21/14 21:35 == 30.7	7/22/14 1:30 == 18.5	7/22/14 5:25 == 45.7	7/22/14 9:20 == 18.4
7/21/14 21:40 == 15.3	7/22/14 1:35 == 18.5	7/22/14 5:30 == 45.6	7/22/14 9:25 == 18.5
7/21/14 21:45 == 13.2	7/22/14 1:40 == 18.5	7/22/14 5:35 == 45.8	7/22/14 9:30 == 18.5
7/21/14 21:50 == 13.2	7/22/14 1:45 == 18.5	7/22/14 5:40 == 45.5	7/22/14 9:35 == 18.5
7/21/14 21:55 == 13.9	7/22/14 1:50 == 18.5	7/22/14 5:45 == 45.7	7/22/14 9:40 == 18.5
7/21/14 22:00 == 13.9	7/22/14 1:55 == 18.5	7/22/14 5:50 == 45.7	7/22/14 9:45 == 18.4
7/21/14 22:05 == 14	7/22/14 2:00 == 18.5	7/22/14 5:55 == 31.9	7/22/14 9:50 == 18.5
7/21/14 22:10 == 29.5	7/22/14 2:05 == 18.4	7/22/14 6:00 == 31.6	7/22/14 9:55 == 18.4
7/21/14 22:15 == 31.8	7/22/14 2:10 == 18.5	7/22/14 6:05 == 31.5	7/22/14 10:00 == 18.5
7/21/14 22:20 == 31.9	7/22/14 2:15 == 18.4	7/22/14 6:10 == 31.7	7/22/14 10:05 == 18.4
7/21/14 22:25 == 31.6	7/22/14 2:20 == 18.5	7/22/14 6:15 == 31.8	7/22/14 10:10 == 18.4
7/21/14 22:30 == 31.5	7/22/14 2:25 == 18.5	7/22/14 6:20 == 31.9	7/22/14 10:15 == 18.4
7/21/14 22:35 == 31.6	7/22/14 2:30 == 18.5	7/22/14 6:25 == 31.6	7/22/14 10:20 == 18.4
7/21/14 22:40 == 31.3	7/22/14 2:35 == 18.5	7/22/14 6:30 == 31.7	7/22/14 10:25 == 18.5
7/21/14 22:45 == 21.3	7/22/14 2:40 == 18.4	7/22/14 6:35 == 31.8	7/22/14 10:30 == 18.4
7/21/14 22:50 == 18.4	7/22/14 2:45 == 18.5	7/22/14 6:40 == 34.8	7/22/14 10:35 == 18.5
7/21/14 22:55 == 18.4	7/22/14 2:50 == 18.4	7/22/14 6:45 == 42.5	7/22/14 10:40 == 18.5
7/21/14 23:00 == 18.4	7/22/14 2:55 == 18.4	7/22/14 6:50 == 43.9	7/22/14 10:45 == 18.4
7/21/14 23:05 == 18.4	7/22/14 3:00 == 18.4	7/22/14 6:55 == 43.8	7/22/14 10:50 == 18.4
7/21/14 23:10 == 18.5	7/22/14 3:05 == 18.5	7/22/14 7:00 == 40.5	7/22/14 10:55 == 18.4
7/21/14 23:15 == 18.5	7/22/14 3:10 == 18.5	7/22/14 7:05 == 21.6	7/22/14 11:00 == 18.5
7/21/14 23:20 == 18.4	7/22/14 3:15 == 18.5	7/22/14 7:10 == 18.4	7/22/14 11:05 == 18.5
7/21/14 23:25 == 18.5	7/22/14 3:20 == 18.5	7/22/14 7:15 == 18.4	7/22/14 11:10 == 18.5
7/21/14 23:30 == 18.5	7/22/14 3:25 == 18.5	7/22/14 7:20 == 18.4	7/22/14 11:15 == 18.4
7/21/14 23:35 == 18.5	7/22/14 3:30 == 18.5	7/22/14 7:25 == 18.4	7/22/14 11:20 == 18.4
7/21/14 23:40 == 18.4	7/22/14 3:35 == 18.5	7/22/14 7:30 == 18.4	7/22/14 11:25 == 18.4
7/21/14 23:45 == 18.5	7/22/14 3:40 == 18.5	7/22/14 7:35 == 18.4	7/22/14 11:30 == 18.4
7/21/14 23:50 == 18.5	7/22/14 3:45 == 18.5	7/22/14 7:40 == 18.4	7/22/14 11:35 == 18.5
7/21/14 23:55 == 18.5	7/22/14 3:50 == 18.4	7/22/14 7:45 == 18.5	7/22/14 11:40 == 18.4
7/22/14 0:00 == 18.5	7/22/14 3:55 == 18.5	7/22/14 7:50 == 18.5	7/22/14 11:45 == 18.5
7/22/14 0:05 == 18.5	7/22/14 4:00 == 25.2	7/22/14 7:55 == 18.4	7/22/14 11:50 == 18.5
7/22/14 0:10 == 18.4	7/22/14 4:05 == 41.2	7/22/14 8:00 == 18.5	7/22/14 11:55 == 18.4
7/22/14 0:15 == 18.4	7/22/14 4:10 == 43.9	7/22/14 8:05 == 18.4	7/22/14 12:00 == 18.5
7/22/14 0:20 == 18.5	7/22/14 4:15 == 43.5	7/22/14 8:10 == 18.5	7/22/14 12:05 == 18.4
7/22/14 0:25 == 18.5	7/22/14 4:20 == 43.4	7/22/14 8:15 == 18.5	7/22/14 12:10 == 18.5
7/22/14 0:30 == 18.5	7/22/14 4:25 == 43.7	7/22/14 8:20 == 18.5	7/22/14 12:15 == 18.4
7/22/14 0:35 == 18.5	7/22/14 4:30 == 43.5	7/22/14 8:25 == 18.6	7/22/14 12:20 == 18.5
7/22/14 0:40 == 18.5	7/22/14 4:35 == 43.5	7/22/14 8:30 == 18.4	7/22/14 12:25 == 18.5
7/22/14 0:45 == 18.5	7/22/14 4:40 == 43.4	7/22/14 8:35 == 18.4	7/22/14 12:30 == 18.5
7/22/14 0:50 == 18.5	7/22/14 4:45 == 43.4	7/22/14 8:40 == 18.4	7/22/14 12:35 == 18.4
7/22/14 0:55 == 18.4	7/22/14 4:50 == 43.4	7/22/14 8:45 == 18.4	7/22/14 12:40 == 18.5
7/22/14 1:00 == 18.4	7/22/14 4:55 == 43.4	7/22/14 8:50 == 18.5	7/22/14 12:45 == #
7/22/14 1:05 == 18.4	7/22/14 5:00 == 43.4	7/22/14 8:55 == 18.4	7/22/14 12:50 == 18.5
7/22/14 1:10 == 18.5	7/22/14 5:05 == 44	7/22/14 9:00 == 18.5	7/22/14 12:55 == 18.4

Pumpback Station Discharge (0364)

7/22/14 13:00 == 18.5	7/22/14 16:55 == 43.3	7/22/14 20:50 == 18.4	7/23/14 0:45 == 44.8
7/22/14 13:05 == 18.5	7/22/14 17:00 == 43.3	7/22/14 20:55 == 18.5	7/23/14 0:50 == 44.7
7/22/14 13:10 == 18.5	7/22/14 17:05 == 43.3	7/22/14 21:00 == 18.4	7/23/14 0:55 == 44.7
7/22/14 13:15 == 18.5	7/22/14 17:10 == 43.2	7/22/14 21:05 == 18.5	7/23/14 1:00 == 44.6
7/22/14 13:20 == 18.4	7/22/14 17:15 == 43.2	7/22/14 21:10 == 18.4	7/23/14 1:05 == 44.6
7/22/14 13:25 == 18.5	7/22/14 17:20 == 43.2	7/22/14 21:15 == 18.5	7/23/14 1:10 == 44.6
7/22/14 13:30 == 18.5	7/22/14 17:25 == 43.2	7/22/14 21:20 == 18.5	7/23/14 1:15 == 44.6
7/22/14 13:35 == 18.5	7/22/14 17:30 == 43.1	7/22/14 21:25 == 18.4	7/23/14 1:20 == 44.6
7/22/14 13:40 == 18.4	7/22/14 17:35 == 43.2	7/22/14 21:30 == 18.5	7/23/14 1:25 == 44.6
7/22/14 13:45 == 18.5	7/22/14 17:40 == 43.1	7/22/14 21:35 == 18.4	7/23/14 1:30 == 44.5
7/22/14 13:50 == 18.4	7/22/14 17:45 == 43	7/22/14 21:40 == 18.5	7/23/14 1:35 == 44.6
7/22/14 13:55 == 18.5	7/22/14 17:50 == 22.8	7/22/14 21:45 == 18.5	7/23/14 1:40 == 44.6
7/22/14 14:00 == 18.5	7/22/14 17:55 == 18.4	7/22/14 21:50 == 18.5	7/23/14 1:45 == 44.6
7/22/14 14:05 == 18.5	7/22/14 18:00 == 18.4	7/22/14 21:55 == 18.6	7/23/14 1:50 == 44.5
7/22/14 14:10 == 18.6	7/22/14 18:05 == 18.5	7/22/14 22:00 == 18.4	7/23/14 1:55 == 44.6
7/22/14 14:15 == 18.5	7/22/14 18:10 == 18.4	7/22/14 22:05 == 18.5	7/23/14 2:00 == 44.6
7/22/14 14:20 == 21.4	7/22/14 18:15 == 18.3	7/22/14 22:10 == 18.5	7/23/14 2:05 == 44.6
7/22/14 14:25 == 39.9	7/22/14 18:20 == 18.4	7/22/14 22:15 == 18.5	7/23/14 2:10 == 44.5
7/22/14 14:30 == 43.7	7/22/14 18:25 == 18.4	7/22/14 22:20 == 18.5	7/23/14 2:15 == 44.5
7/22/14 14:35 == 43.5	7/22/14 18:30 == 18.4	7/22/14 22:25 == 18.5	7/23/14 2:20 == 44.5
7/22/14 14:40 == 43.5	7/22/14 18:35 == 18.4	7/22/14 22:30 == 18.5	7/23/14 2:25 == 44.5
7/22/14 14:45 == 43.5	7/22/14 18:40 == 18.4	7/22/14 22:35 == 18.5	7/23/14 2:30 == 30.2
7/22/14 14:50 == 43.4	7/22/14 18:45 == 18.4	7/22/14 22:40 == 18.5	7/23/14 2:35 == 18.4
7/22/14 14:55 == 43.5	7/22/14 18:50 == 18.4	7/22/14 22:45 == 18.6	7/23/14 2:40 == 18.6
7/22/14 15:00 == 43.4	7/22/14 18:55 == 18.4	7/22/14 22:50 == 18.5	7/23/14 2:45 == 18.5
7/22/14 15:05 == 43.6	7/22/14 19:00 == 18.4	7/22/14 22:55 == 18.5	7/23/14 2:50 == 18.5
7/22/14 15:10 == 43.4	7/22/14 19:05 == 18.5	7/22/14 23:00 == 18.5	7/23/14 2:55 == 18.4
7/22/14 15:15 == 43.4	7/22/14 19:10 == 18.4	7/22/14 23:05 == 18.5	7/23/14 3:00 == 18.4
7/22/14 15:20 == 43.3	7/22/14 19:15 == 18.5	7/22/14 23:10 == 18.5	7/23/14 3:05 == 18.5
7/22/14 15:25 == 43.4	7/22/14 19:20 == 18.4	7/22/14 23:15 == 18.5	7/23/14 3:10 == 18.4
7/22/14 15:30 == 43.4	7/22/14 19:25 == 18.4	7/22/14 23:20 == 18.5	7/23/14 3:15 == 18.5
7/22/14 15:35 == 43.4	7/22/14 19:30 == 18.5	7/22/14 23:25 == 18.5	7/23/14 3:20 == 18.5
7/22/14 15:40 == 43.4	7/22/14 19:35 == 18.4	7/22/14 23:30 == 18.5	7/23/14 3:25 == 18.5
7/22/14 15:45 == 43.4	7/22/14 19:40 == 18.5	7/22/14 23:35 == 18.6	7/23/14 3:30 == 18.5
7/22/14 15:50 == 43.3	7/22/14 19:45 == 18.4	7/22/14 23:40 == 18.5	7/23/14 3:35 == 18.5
7/22/14 15:55 == 43.7	7/22/14 19:50 == 18.4	7/22/14 23:45 == 18.5	7/23/14 3:40 == 18.5
7/22/14 16:00 == 43.4	7/22/14 19:55 == 18.5	7/22/14 23:50 == 18.5	7/23/14 3:45 == 18.5
7/22/14 16:05 == 43.3	7/22/14 20:00 == 18.5	7/22/14 23:55 == 18.5	7/23/14 3:50 == 18.5
7/22/14 16:10 == 43.2	7/22/14 20:05 == 18.4	7/23/14 0:00 == 18.5	7/23/14 3:55 == 18.4
7/22/14 16:15 == 43.4	7/22/14 20:10 == 18.4	7/23/14 0:05 == 18.5	7/23/14 4:00 == 18.4
7/22/14 16:20 == 43.2	7/22/14 20:15 == 18.4	7/23/14 0:10 == 18.5	7/23/14 4:05 == 18.5
7/22/14 16:25 == 43.4	7/22/14 20:20 == 18.4	7/23/14 0:15 == 18.5	7/23/14 4:10 == 18.5
7/22/14 16:30 == 43.3	7/22/14 20:25 == 18.4	7/23/14 0:20 == 18.6	7/23/14 4:15 == 18.4
7/22/14 16:35 == 43.3	7/22/14 20:30 == 18.4	7/23/14 0:25 == 18.6	7/23/14 4:20 == 18.5
7/22/14 16:40 == 43.3	7/22/14 20:35 == 18.4	7/23/14 0:30 == 28.7	7/23/14 4:25 == 18.5
7/22/14 16:45 == 43.3	7/22/14 20:40 == 18.4	7/23/14 0:35 == 40.2	7/23/14 4:30 == 18.5
7/22/14 16:50 == 43.3	7/22/14 20:45 == 18.4	7/23/14 0:40 == 44.9	7/23/14 4:35 == 18.4

Pumpback Station Discharge (0364)

7/23/14 4:40 == 18.4	7/23/14 8:35 == 45.9	7/23/14 12:30 == 33.4	7/23/14 16:25 == 33.4
7/23/14 4:45 == 18.4	7/23/14 8:40 == 45.1	7/23/14 12:35 == 33.2	7/23/14 16:30 == 33.5
7/23/14 4:50 == 18.5	7/23/14 8:45 == 33.6	7/23/14 12:40 == 33.2	7/23/14 16:35 == 33.4
7/23/14 4:55 == 18.5	7/23/14 8:50 == 33.3	7/23/14 12:45 == 33.3	7/23/14 16:40 == 33.4
7/23/14 5:00 == 18.5	7/23/14 8:55 == 33.3	7/23/14 12:50 == 33.3	7/23/14 16:45 == 33.5
7/23/14 5:05 == 18.5	7/23/14 9:00 == 33.3	7/23/14 12:55 == 33.4	7/23/14 16:50 == 33.3
7/23/14 5:10 == 18.5	7/23/14 9:05 == 33.5	7/23/14 13:00 == 29.1	7/23/14 16:55 == 33.3
7/23/14 5:15 == 18.5	7/23/14 9:10 == 33.3	7/23/14 13:05 == 18.3	7/23/14 17:00 == 33.4
7/23/14 5:20 == 18.4	7/23/14 9:15 == 33.3	7/23/14 13:10 == 18.4	7/23/14 17:05 == 33.3
7/23/14 5:25 == 18.5	7/23/14 9:20 == 33.3	7/23/14 13:15 == 18.4	7/23/14 17:10 == 33.4
7/23/14 5:30 == 18.5	7/23/14 9:25 == 33.3	7/23/14 13:20 == 18.4	7/23/14 17:15 == 33.4
7/23/14 5:35 == 18.5	7/23/14 9:30 == 33.3	7/23/14 13:25 == 18.5	7/23/14 17:20 == 33.3
7/23/14 5:40 == 18.5	7/23/14 9:35 == 33.4	7/23/14 13:30 == 18.4	7/23/14 17:25 == 33.4
7/23/14 5:45 == 18.5	7/23/14 9:40 == 33.2	7/23/14 13:35 == 18.4	7/23/14 17:30 == 33.4
7/23/14 5:50 == 18.5	7/23/14 9:45 == 33.3	7/23/14 13:40 == 18.4	7/23/14 17:35 == 33.4
7/23/14 5:55 == 18.5	7/23/14 9:50 == 33.5	7/23/14 13:45 == 18.4	7/23/14 17:40 == 33.4
7/23/14 6:00 == 18.5	7/23/14 9:55 == 33.3	7/23/14 13:50 == 18.5	7/23/14 17:45 == 33.4
7/23/14 6:05 == 18.5	7/23/14 10:00 == 33.3	7/23/14 13:55 == 18.4	7/23/14 17:50 == 33.3
7/23/14 6:10 == 18.4	7/23/14 10:05 == 33.4	7/23/14 14:00 == 18.4	7/23/14 17:55 == 33.4
7/23/14 6:15 == 18.4	7/23/14 10:10 == 33.3	7/23/14 14:05 == 18.5	7/23/14 18:00 == 33.3
7/23/14 6:20 == 18.5	7/23/14 10:15 == 33.2	7/23/14 14:10 == 18.4	7/23/14 18:05 == 33.4
7/23/14 6:25 == 18.5	7/23/14 10:20 == 33.3	7/23/14 14:15 == 18.5	7/23/14 18:10 == 33.4
7/23/14 6:30 == 18.5	7/23/14 10:25 == 33.3	7/23/14 14:20 == 18.4	7/23/14 18:15 == 33.3
7/23/14 6:35 == 18.5	7/23/14 10:30 == 33.3	7/23/14 14:25 == 18.5	7/23/14 18:20 == 33.4
7/23/14 6:40 == 18.5	7/23/14 10:35 == 33.3	7/23/14 14:30 == 18.4	7/23/14 18:25 == 33.3
7/23/14 6:45 == 18.5	7/23/14 10:40 == 33.4	7/23/14 14:35 == 9.2	7/23/14 18:30 == 33.3
7/23/14 6:50 == 18.5	7/23/14 10:45 == 33.3	7/23/14 14:40 == 0	7/23/14 18:35 == 33.4
7/23/14 6:55 == 18.5	7/23/14 10:50 == 33.4	7/23/14 14:45 == #	7/23/14 18:40 == 33.4
7/23/14 7:00 == 18.5	7/23/14 10:55 == 33.3	7/23/14 14:50 == #	7/23/14 18:45 == 33.3
7/23/14 7:05 == 18.5	7/23/14 11:00 == 33.2	7/23/14 14:55 == #	7/23/14 18:50 == 33.4
7/23/14 7:10 == 18.5	7/23/14 11:05 == 33.3	7/23/14 15:00 == 0	7/23/14 18:55 == 33.4
7/23/14 7:15 == 18.5	7/23/14 11:10 == 33.4	7/23/14 15:05 == 7.5	7/23/14 19:00 == 33.3
7/23/14 7:20 == 18.5	7/23/14 11:15 == 33.3	7/23/14 15:10 == 33.2	7/23/14 19:05 == 33.3
7/23/14 7:25 == 18.6	7/23/14 11:20 == 33.2	7/23/14 15:15 == 33.5	7/23/14 19:10 == 33.3
7/23/14 7:30 == 19.3	7/23/14 11:25 == 33.5	7/23/14 15:20 == 33.5	7/23/14 19:15 == 33.4
7/23/14 7:35 == 30.1	7/23/14 11:30 == 33.3	7/23/14 15:25 == 33.6	7/23/14 19:20 == 33.4
7/23/14 7:40 == 46.1	7/23/14 11:35 == 33.5	7/23/14 15:30 == 33.5	7/23/14 19:25 == 33.3
7/23/14 7:45 == 46.4	7/23/14 11:40 == 33.3	7/23/14 15:35 == 33.4	7/23/14 19:30 == 33.3
7/23/14 7:50 == 46.1	7/23/14 11:45 == 33.3	7/23/14 15:40 == 33.5	7/23/14 19:35 == 33.3
7/23/14 7:55 == 46.1	7/23/14 11:50 == 33.4	7/23/14 15:45 == 33.5	7/23/14 19:40 == 33.4
7/23/14 8:00 == 46.1	7/23/14 11:55 == 33.3	7/23/14 15:50 == 33.4	7/23/14 19:45 == 33.3
7/23/14 8:05 == 46.1	7/23/14 12:00 == 33.4	7/23/14 15:55 == 33.4	7/23/14 19:50 == 33.4
7/23/14 8:10 == 46	7/23/14 12:05 == 33.3	7/23/14 16:00 == 33.4	7/23/14 19:55 == 33.3
7/23/14 8:15 == 46	7/23/14 12:10 == 33.3	7/23/14 16:05 == 33.4	7/23/14 20:00 == 33.3
7/23/14 8:20 == 46.1	7/23/14 12:15 == 33.2	7/23/14 16:10 == 33.5	7/23/14 20:05 == 33.3
7/23/14 8:25 == 46	7/23/14 12:20 == 33.3	7/23/14 16:15 == 33.5	7/23/14 20:10 == 33.3
7/23/14 8:30 == 45.9	7/23/14 12:25 == 33.5	7/23/14 16:20 == 33.4	7/23/14 20:15 == 33.4

Pumpback Station Discharge (0364)

7/23/14 20:20 == 33.3	7/24/14 0:15 == 32	7/24/14 4:10 == 31.1	7/24/14 8:05 == 18.5
7/23/14 20:25 == 33.4	7/24/14 0:20 == 32.1	7/24/14 4:15 == 31.2	7/24/14 8:10 == 18.6
7/23/14 20:30 == 33.3	7/24/14 0:25 == 32	7/24/14 4:20 == 31	7/24/14 8:15 == 18.6
7/23/14 20:35 == 33.3	7/24/14 0:30 == 32	7/24/14 4:25 == 31.2	7/24/14 8:20 == 18.5
7/23/14 20:40 == 33.3	7/24/14 0:35 == 32	7/24/14 4:30 == 31.1	7/24/14 8:25 == 18.5
7/23/14 20:45 == 33.4	7/24/14 0:40 == 31.9	7/24/14 4:35 == 31.1	7/24/14 8:30 == 18.5
7/23/14 20:50 == 33.3	7/24/14 0:45 == 31.9	7/24/14 4:40 == 31	7/24/14 8:35 == 18.5
7/23/14 20:55 == 33.4	7/24/14 0:50 == 31.9	7/24/14 4:45 == 31	7/24/14 8:40 == 18.5
7/23/14 21:00 == 33.4	7/24/14 0:55 == 31.8	7/24/14 4:50 == 31	7/24/14 8:45 == 18.6
7/23/14 21:05 == 33.4	7/24/14 1:00 == 31.8	7/24/14 4:55 == 30.9	7/24/14 8:50 == 18.6
7/23/14 21:10 == 33.3	7/24/14 1:05 == 31.9	7/24/14 5:00 == 31	7/24/14 8:55 == 18.5
7/23/14 21:15 == 33.3	7/24/14 1:10 == 31.7	7/24/14 5:05 == 31	7/24/14 9:00 == 18.5
7/23/14 21:20 == 33.3	7/24/14 1:15 == 31.7	7/24/14 5:10 == 30.9	7/24/14 9:05 == 18.5
7/23/14 21:25 == 33.3	7/24/14 1:20 == 31.7	7/24/14 5:15 == 30.8	7/24/14 9:10 == 21.3
7/23/14 21:30 == 33.4	7/24/14 1:25 == 31.7	7/24/14 5:20 == 30.9	7/24/14 9:15 == 18.6
7/23/14 21:35 == 33.3	7/24/14 1:30 == 31.7	7/24/14 5:25 == 30.8	7/24/14 9:20 == 18.6
7/23/14 21:40 == 33.3	7/24/14 1:35 == 31.6	7/24/14 5:30 == 30.9	7/24/14 9:25 == 18.6
7/23/14 21:45 == 33.4	7/24/14 1:40 == 31.6	7/24/14 5:35 == 30.9	7/24/14 9:30 == 18.6
7/23/14 21:50 == 33.4	7/24/14 1:45 == 31.6	7/24/14 5:40 == 30.9	7/24/14 9:35 == 18.5
7/23/14 21:55 == 33.4	7/24/14 1:50 == 31.6	7/24/14 5:45 == 26.4	7/24/14 9:40 == 18.4
7/23/14 22:00 == 33.3	7/24/14 1:55 == 31.6	7/24/14 5:50 == 18.5	7/24/14 9:45 == 18.5
7/23/14 22:05 == 33.5	7/24/14 2:00 == 31.5	7/24/14 5:55 == 18.4	7/24/14 9:50 == 18.5
7/23/14 22:10 == 33.3	7/24/14 2:05 == 31.6	7/24/14 6:00 == 18.5	7/24/14 9:55 == 18.5
7/23/14 22:15 == 33.3	7/24/14 2:10 == 31.5	7/24/14 6:05 == 18.5	7/24/14 10:00 == 18.5
7/23/14 22:20 == 33.3	7/24/14 2:15 == 31.5	7/24/14 6:10 == 18.4	7/24/14 10:05 == 18.5
7/23/14 22:25 == 33.4	7/24/14 2:20 == 31.6	7/24/14 6:15 == 18.5	7/24/14 10:10 == 18.5
7/23/14 22:30 == 33.4	7/24/14 2:25 == 31.4	7/24/14 6:20 == 18.5	7/24/14 10:15 == 18.5
7/23/14 22:35 == 33.4	7/24/14 2:30 == 31.4	7/24/14 6:25 == 18.5	7/24/14 10:20 == 18.5
7/23/14 22:40 == 33.4	7/24/14 2:35 == 31.3	7/24/14 6:30 == 18.5	7/24/14 10:25 == 18.5
7/23/14 22:45 == 33.4	7/24/14 2:40 == 31.4	7/24/14 6:35 == 18.5	7/24/14 10:30 == 18.5
7/23/14 22:50 == 33.4	7/24/14 2:45 == 31.4	7/24/14 6:40 == 18.5	7/24/14 10:35 == 18.5
7/23/14 22:55 == 33.3	7/24/14 2:50 == 31.3	7/24/14 6:45 == 18.5	7/24/14 10:40 == 18.5
7/23/14 23:00 == 33.5	7/24/14 2:55 == 31.3	7/24/14 6:50 == 18.5	7/24/14 10:45 == 18.5
7/23/14 23:05 == 33.3	7/24/14 3:00 == 31.3	7/24/14 6:55 == 18.4	7/24/14 10:50 == 18.5
7/23/14 23:10 == 33.3	7/24/14 3:05 == 31.3	7/24/14 7:00 == 18.5	7/24/14 10:55 == 18.5
7/23/14 23:15 == 33.4	7/24/14 3:10 == 31.2	7/24/14 7:05 == 18.4	7/24/14 11:00 == 18.5
7/23/14 23:20 == 33.1	7/24/14 3:15 == 31.2	7/24/14 7:10 == 18.5	7/24/14 11:05 == 18.5
7/23/14 23:25 == 32.2	7/24/14 3:20 == 31.3	7/24/14 7:15 == 18.5	7/24/14 11:10 == 18.6
7/23/14 23:30 == 32.3	7/24/14 3:25 == 31.2	7/24/14 7:20 == 18.5	7/24/14 11:15 == 18.5
7/23/14 23:35 == 32.2	7/24/14 3:30 == 31.2	7/24/14 7:25 == 18.5	7/24/14 11:20 == 18.5
7/23/14 23:40 == 32.3	7/24/14 3:35 == 31.2	7/24/14 7:30 == 18.5	7/24/14 11:25 == 18.5
7/23/14 23:45 == 32.3	7/24/14 3:40 == 31.3	7/24/14 7:35 == 18.4	7/24/14 11:30 == 18.5
7/23/14 23:50 == 32.3	7/24/14 3:45 == 31.3	7/24/14 7:40 == 18.5	7/24/14 11:35 == 18.5
7/23/14 23:55 == 32	7/24/14 3:50 == 31.1	7/24/14 7:45 == 18.6	7/24/14 11:40 == 18.5
7/24/14 0:00 == 32.1	7/24/14 3:55 == 31.2	7/24/14 7:50 == 18.4	7/24/14 11:45 == 18.5
7/24/14 0:05 == 32.1	7/24/14 4:00 == 31.1	7/24/14 7:55 == 18.5	7/24/14 11:50 == 18.6
7/24/14 0:10 == 32	7/24/14 4:05 == 31.1	7/24/14 8:00 == 18.5	7/24/14 11:55 == 18.6

Pumpback Station Discharge (0364)

7/24/14 12:00 == 18.6	7/24/14 15:55 == 18.6	7/24/14 19:50 == 28.1	7/24/14 23:45 == 28.1
7/24/14 12:05 == 18.5	7/24/14 16:00 == 19.4	7/24/14 19:55 == 28.1	7/24/14 23:50 == 28.2
7/24/14 12:10 == 18.5	7/24/14 16:05 == 28	7/24/14 20:00 == 28.2	7/24/14 23:55 == 28.1
7/24/14 12:15 == 18.5	7/24/14 16:10 == 28.2	7/24/14 20:05 == 28.1	7/25/14 0:00 == 28.1
7/24/14 12:20 == 18.6	7/24/14 16:15 == 28.2	7/24/14 20:10 == 28.2	7/25/14 0:05 == 28.2
7/24/14 12:25 == 18.5	7/24/14 16:20 == 28.1	7/24/14 20:15 == 28.1	7/25/14 0:10 == 28.1
7/24/14 12:30 == 18.6	7/24/14 16:25 == 28.2	7/24/14 20:20 == 28.2	7/25/14 0:15 == 28.2
7/24/14 12:35 == 18.6	7/24/14 16:30 == 28.1	7/24/14 20:25 == 28.2	7/25/14 0:20 == 28.2
7/24/14 12:40 == 18.5	7/24/14 16:35 == 28.1	7/24/14 20:30 == 28.1	7/25/14 0:25 == 28.1
7/24/14 12:45 == 18.5	7/24/14 16:40 == 28.2	7/24/14 20:35 == 28.1	7/25/14 0:30 == 28.1
7/24/14 12:50 == 18.6	7/24/14 16:45 == 28.2	7/24/14 20:40 == 28.2	7/25/14 0:35 == 28.1
7/24/14 12:55 == 18.5	7/24/14 16:50 == 28.1	7/24/14 20:45 == 28.1	7/25/14 0:40 == 28.2
7/24/14 13:00 == 18.6	7/24/14 16:55 == 28	7/24/14 20:50 == 28.1	7/25/14 0:45 == 28.2
7/24/14 13:05 == 18.6	7/24/14 17:00 == 28.1	7/24/14 20:55 == 28.2	7/25/14 0:50 == 28.1
7/24/14 13:10 == 20.6	7/24/14 17:05 == 28.1	7/24/14 21:00 == 28.1	7/25/14 0:55 == 28.2
7/24/14 13:15 == 28.2	7/24/14 17:10 == 28.2	7/24/14 21:05 == 28.2	7/25/14 1:00 == 28.2
7/24/14 13:20 == 28.2	7/24/14 17:15 == 28.1	7/24/14 21:10 == 28.1	7/25/14 1:05 == 28.2
7/24/14 13:25 == 28.4	7/24/14 17:20 == 28.2	7/24/14 21:15 == 28.2	7/25/14 1:10 == 28.1
7/24/14 13:30 == 28.2	7/24/14 17:25 == 28.1	7/24/14 21:20 == 28.1	7/25/14 1:15 == 28.2
7/24/14 13:35 == 28.2	7/24/14 17:30 == 28.1	7/24/14 21:25 == 28.2	7/25/14 1:20 == 28.1
7/24/14 13:40 == 28.2	7/24/14 17:35 == 28.1	7/24/14 21:30 == 28.3	7/25/14 1:25 == 28.2
7/24/14 13:45 == 28.1	7/24/14 17:40 == 28.1	7/24/14 21:35 == 28.1	7/25/14 1:30 == 28.2
7/24/14 13:50 == 28.2	7/24/14 17:45 == 28.1	7/24/14 21:40 == 28.2	7/25/14 1:35 == 28.1
7/24/14 13:55 == 28.1	7/24/14 17:50 == 28.1	7/24/14 21:45 == 28.2	7/25/14 1:40 == 28.1
7/24/14 14:00 == 28.1	7/24/14 17:55 == 28.2	7/24/14 21:50 == 28.2	7/25/14 1:45 == 28.1
7/24/14 14:05 == 28.2	7/24/14 18:00 == 28.2	7/24/14 21:55 == 28.1	7/25/14 1:50 == 28.2
7/24/14 14:10 == 28.2	7/24/14 18:05 == 28.2	7/24/14 22:00 == 28	7/25/14 1:55 == 28.1
7/24/14 14:15 == 28.1	7/24/14 18:10 == 28.1	7/24/14 22:05 == 28.1	7/25/14 2:00 == 28.1
7/24/14 14:20 == 28.2	7/24/14 18:15 == 28.1	7/24/14 22:10 == 28.2	7/25/14 2:05 == 28.2
7/24/14 14:25 == 28.2	7/24/14 18:20 == 28.1	7/24/14 22:15 == 28.1	7/25/14 2:10 == 28.2
7/24/14 14:30 == 28	7/24/14 18:25 == 28.1	7/24/14 22:20 == 28.3	7/25/14 2:15 == 28.1
7/24/14 14:35 == 28.1	7/24/14 18:30 == 28.1	7/24/14 22:25 == 28.1	7/25/14 2:20 == 28.1
7/24/14 14:40 == 28.1	7/24/14 18:35 == 28.1	7/24/14 22:30 == 28.1	7/25/14 2:25 == 28.1
7/24/14 14:45 == 28.1	7/24/14 18:40 == 28.1	7/24/14 22:35 == 28	7/25/14 2:30 == 28.3
7/24/14 14:50 == 28.1	7/24/14 18:45 == 28.2	7/24/14 22:40 == 28.1	7/25/14 2:35 == 28.2
7/24/14 14:55 == 28.1	7/24/14 18:50 == 28.2	7/24/14 22:45 == 28.1	7/25/14 2:40 == 28.2
7/24/14 15:00 == 28.1	7/24/14 18:55 == 28.1	7/24/14 22:50 == 28.2	7/25/14 2:45 == 28.2
7/24/14 15:05 == 23.3	7/24/14 19:00 == 28.1	7/24/14 22:55 == 28.2	7/25/14 2:50 == 28.2
7/24/14 15:10 == 18.6	7/24/14 19:05 == 28.1	7/24/14 23:00 == 28.2	7/25/14 2:55 == 28.2
7/24/14 15:15 == 18.6	7/24/14 19:10 == 28.1	7/24/14 23:05 == 28.1	7/25/14 3:00 == 28.2
7/24/14 15:20 == 18.5	7/24/14 19:15 == 28.1	7/24/14 23:10 == 28.1	7/25/14 3:05 == 28.2
7/24/14 15:25 == 18.5	7/24/14 19:20 == 28.2	7/24/14 23:15 == 28.2	7/25/14 3:10 == #
7/24/14 15:30 == 18.4	7/24/14 19:25 == 28.1	7/24/14 23:20 == 28.1	7/25/14 3:15 == 28.2
7/24/14 15:35 == 18.5	7/24/14 19:30 == 28.2	7/24/14 23:25 == 28.2	7/25/14 3:20 == #
7/24/14 15:40 == 18.5	7/24/14 19:35 == 28.2	7/24/14 23:30 == 28.2	7/25/14 3:25 == 28.2
7/24/14 15:45 == 18.5	7/24/14 19:40 == 28.1	7/24/14 23:35 == 28.1	7/25/14 3:30 == 28.2
7/24/14 15:50 == 18.5	7/24/14 19:45 == 28.2	7/24/14 23:40 == 28.1	7/25/14 3:35 == 28.3

Pumpback Station Discharge (0364)

7/25/14 3:40 == 28.2	7/25/14 7:35 == 32.9	7/25/14 11:30 == 30	7/25/14 15:25 == 18.5
7/25/14 3:45 == 28.3	7/25/14 7:40 == 30.9	7/25/14 11:35 == 30.1	7/25/14 15:30 == 22
7/25/14 3:50 == 28.3	7/25/14 7:45 == 29.9	7/25/14 11:40 == 30.1	7/25/14 15:35 == 27.6
7/25/14 3:55 == 28.2	7/25/14 7:50 == 30	7/25/14 11:45 == 30	7/25/14 15:40 == 27.6
7/25/14 4:00 == 28.2	7/25/14 7:55 == 30	7/25/14 11:50 == 30	7/25/14 15:45 == 27.6
7/25/14 4:05 == 28.3	7/25/14 8:00 == 30.1	7/25/14 11:55 == 30	7/25/14 15:50 == 27.6
7/25/14 4:10 == 28.3	7/25/14 8:05 == 30	7/25/14 12:00 == 30	7/25/14 15:55 == 27.6
7/25/14 4:15 == 28.2	7/25/14 8:10 == 30	7/25/14 12:05 == 30.1	7/25/14 16:00 == 27.7
7/25/14 4:20 == 28.2	7/25/14 8:15 == 30	7/25/14 12:10 == 30	7/25/14 16:05 == 27.6
7/25/14 4:25 == 28.2	7/25/14 8:20 == 30.1	7/25/14 12:15 == 30.1	7/25/14 16:10 == 27.6
7/25/14 4:30 == 28.2	7/25/14 8:25 == 30	7/25/14 12:20 == 30.1	7/25/14 16:15 == 27.6
7/25/14 4:35 == 28.2	7/25/14 8:30 == 30.1	7/25/14 12:25 == 30	7/25/14 16:20 == 27.6
7/25/14 4:40 == 28.3	7/25/14 8:35 == 30	7/25/14 12:30 == 30.1	7/25/14 16:25 == 27.6
7/25/14 4:45 == 28.3	7/25/14 8:40 == 30	7/25/14 12:35 == 29.9	7/25/14 16:30 == 27.6
7/25/14 4:50 == 28.3	7/25/14 8:45 == 30	7/25/14 12:40 == 30.1	7/25/14 16:35 == 27.6
7/25/14 4:55 == 28.2	7/25/14 8:50 == 30	7/25/14 12:45 == 30	7/25/14 16:40 == 27.5
7/25/14 5:00 == 28.2	7/25/14 8:55 == 30	7/25/14 12:50 == 30.1	7/25/14 16:45 == 27.5
7/25/14 5:05 == 28.2	7/25/14 9:00 == 30	7/25/14 12:55 == 30	7/25/14 16:50 == 27.6
7/25/14 5:10 == 28.2	7/25/14 9:05 == 30	7/25/14 13:00 == 30	7/25/14 16:55 == 27.6
7/25/14 5:15 == 28.2	7/25/14 9:10 == 30	7/25/14 13:05 == 30	7/25/14 17:00 == 27.6
7/25/14 5:20 == 28.2	7/25/14 9:15 == 30.1	7/25/14 13:10 == 29.9	7/25/14 17:05 == 27.5
7/25/14 5:25 == 28.2	7/25/14 9:20 == 30.1	7/25/14 13:15 == 30.1	7/25/14 17:10 == 27.6
7/25/14 5:30 == 28.2	7/25/14 9:25 == 30.2	7/25/14 13:20 == 30.1	7/25/14 17:15 == 27.6
7/25/14 5:35 == 28.2	7/25/14 9:30 == 30.1	7/25/14 13:25 == 30	7/25/14 17:20 == 27.6
7/25/14 5:40 == 28.3	7/25/14 9:35 == 30	7/25/14 13:30 == 30.1	7/25/14 17:25 == 27.6
7/25/14 5:45 == 28.3	7/25/14 9:40 == 30.2	7/25/14 13:35 == 29.9	7/25/14 17:30 == 27.6
7/25/14 5:50 == 28.3	7/25/14 9:45 == 30	7/25/14 13:40 == 30.1	7/25/14 17:35 == 27.5
7/25/14 5:55 == 28.3	7/25/14 9:50 == 30	7/25/14 13:45 == 26	7/25/14 17:40 == 27.6
7/25/14 6:00 == 28.4	7/25/14 9:55 == 29.9	7/25/14 13:50 == 18.5	7/25/14 17:45 == 27.6
7/25/14 6:05 == 28.2	7/25/14 10:00 == 30	7/25/14 13:55 == 18.5	7/25/14 17:50 == 27.6
7/25/14 6:10 == 28.4	7/25/14 10:05 == 30.1	7/25/14 14:00 == 18.6	7/25/14 17:55 == 27.7
7/25/14 6:15 == 27.7	7/25/14 10:10 == 30	7/25/14 14:05 == 18.5	7/25/14 18:00 == 27.6
7/25/14 6:20 == 27.6	7/25/14 10:15 == 30.1	7/25/14 14:10 == 18.6	7/25/14 18:05 == 27.6
7/25/14 6:25 == 27.5	7/25/14 10:20 == 30.1	7/25/14 14:15 == 18.6	7/25/14 18:10 == 27.6
7/25/14 6:30 == 27.9	7/25/14 10:25 == 30	7/25/14 14:20 == 18.6	7/25/14 18:15 == 27.6
7/25/14 6:35 == 32.4	7/25/14 10:30 == 30	7/25/14 14:25 == 18.6	7/25/14 18:20 == 27.6
7/25/14 6:40 == 33	7/25/14 10:35 == 30	7/25/14 14:30 == 18.6	7/25/14 18:25 == 27.7
7/25/14 6:45 == 32.9	7/25/14 10:40 == 30.1	7/25/14 14:35 == 18.6	7/25/14 18:30 == 27.6
7/25/14 6:50 == 33	7/25/14 10:45 == 30	7/25/14 14:40 == 18.6	7/25/14 18:35 == 27.7
7/25/14 6:55 == 32.9	7/25/14 10:50 == 30	7/25/14 14:45 == 18.6	7/25/14 18:40 == 27.6
7/25/14 7:00 == 32.9	7/25/14 10:55 == 30	7/25/14 14:50 == 18.6	7/25/14 18:45 == 27.6
7/25/14 7:05 == 32.9	7/25/14 11:00 == 30	7/25/14 14:55 == 18.6	7/25/14 18:50 == 27.5
7/25/14 7:10 == 32.9	7/25/14 11:05 == 30	7/25/14 15:00 == 18.6	7/25/14 18:55 == 27.6
7/25/14 7:15 == 33	7/25/14 11:10 == 30	7/25/14 15:05 == 18.6	7/25/14 19:00 == 27.7
7/25/14 7:20 == 33	7/25/14 11:15 == 30.1	7/25/14 15:10 == 18.6	7/25/14 19:05 == 27.6
7/25/14 7:25 == 32.8	7/25/14 11:20 == 30	7/25/14 15:15 == 18.6	7/25/14 19:10 == 27.7
7/25/14 7:30 == 32.8	7/25/14 11:25 == 30.1	7/25/14 15:20 == 18.6	7/25/14 19:15 == 27.6

Pumpback Station Discharge (0364)

7/25/14 19:20 == 27.7	7/25/14 23:15 == 27.6	7/26/14 3:10 == 27.6	7/26/14 7:05 == 27.8
7/25/14 19:25 == 27.7	7/25/14 23:20 == 27.6	7/26/14 3:15 == 27.7	7/26/14 7:10 == 27.7
7/25/14 19:30 == 27.6	7/25/14 23:25 == 27.7	7/26/14 3:20 == 27.7	7/26/14 7:15 == 27.7
7/25/14 19:35 == 27.6	7/25/14 23:30 == 27.7	7/26/14 3:25 == 27.6	7/26/14 7:20 == 27.7
7/25/14 19:40 == 27.6	7/25/14 23:35 == 27.7	7/26/14 3:30 == 27.6	7/26/14 7:25 == 27.8
7/25/14 19:45 == 27.6	7/25/14 23:40 == 27.6	7/26/14 3:35 == 27.8	7/26/14 7:30 == 27.7
7/25/14 19:50 == 27.6	7/25/14 23:45 == 27.7	7/26/14 3:40 == 27.7	7/26/14 7:35 == 27.8
7/25/14 19:55 == 27.6	7/25/14 23:50 == 27.7	7/26/14 3:45 == 27.7	7/26/14 7:40 == 27.7
7/25/14 20:00 == 27.6	7/25/14 23:55 == 27.7	7/26/14 3:50 == 27.7	7/26/14 7:45 == 27.7
7/25/14 20:05 == 27.5	7/26/14 0:00 == 27.6	7/26/14 3:55 == 27.7	7/26/14 7:50 == 27.8
7/25/14 20:10 == 27.6	7/26/14 0:05 == 27.7	7/26/14 4:00 == 27.7	7/26/14 7:55 == 27.7
7/25/14 20:15 == 27.6	7/26/14 0:10 == 27.7	7/26/14 4:05 == 27.8	7/26/14 8:00 == 27.7
7/25/14 20:20 == 27.5	7/26/14 0:15 == 27.6	7/26/14 4:10 == 27.7	7/26/14 8:05 == 27.7
7/25/14 20:25 == 27.6	7/26/14 0:20 == 27.6	7/26/14 4:15 == 27.7	7/26/14 8:10 == 27.8
7/25/14 20:30 == 27.7	7/26/14 0:25 == 27.7	7/26/14 4:20 == 27.7	7/26/14 8:15 == 27.7
7/25/14 20:35 == 27.6	7/26/14 0:30 == 27.7	7/26/14 4:25 == 27.7	7/26/14 8:20 == 27.7
7/25/14 20:40 == 27.6	7/26/14 0:35 == 27.6	7/26/14 4:30 == 27.7	7/26/14 8:25 == 27.8
7/25/14 20:45 == 27.5	7/26/14 0:40 == 27.6	7/26/14 4:35 == 27.8	7/26/14 8:30 == 27.7
7/25/14 20:50 == 27.7	7/26/14 0:45 == 27.8	7/26/14 4:40 == 27.8	7/26/14 8:35 == 27.7
7/25/14 20:55 == 27.6	7/26/14 0:50 == 27.6	7/26/14 4:45 == 27.7	7/26/14 8:40 == 27.7
7/25/14 21:00 == 27.6	7/26/14 0:55 == 27.6	7/26/14 4:50 == 27.7	7/26/14 8:45 == 27.7
7/25/14 21:05 == 27.7	7/26/14 1:00 == 27.6	7/26/14 4:55 == 27.7	7/26/14 8:50 == 27.7
7/25/14 21:10 == 27.5	7/26/14 1:05 == 27.7	7/26/14 5:00 == 27.7	7/26/14 8:55 == 27.7
7/25/14 21:15 == 27.6	7/26/14 1:10 == 27.7	7/26/14 5:05 == 27.7	7/26/14 9:00 == 27.8
7/25/14 21:20 == 27.6	7/26/14 1:15 == 27.6	7/26/14 5:10 == 27.8	7/26/14 9:05 == 27.8
7/25/14 21:25 == 27.7	7/26/14 1:20 == 27.6	7/26/14 5:15 == 27.7	7/26/14 9:10 == 27.8
7/25/14 21:30 == 27.6	7/26/14 1:25 == 27.6	7/26/14 5:20 == 27.7	7/26/14 9:15 == 27.7
7/25/14 21:35 == 27.6	7/26/14 1:30 == 27.7	7/26/14 5:25 == 27.7	7/26/14 9:20 == 27.8
7/25/14 21:40 == 27.7	7/26/14 1:35 == 27.6	7/26/14 5:30 == 27.7	7/26/14 9:25 == 27.7
7/25/14 21:45 == 27.6	7/26/14 1:40 == 27.6	7/26/14 5:35 == 27.7	7/26/14 9:30 == 27.7
7/25/14 21:50 == 27.7	7/26/14 1:45 == 27.7	7/26/14 5:40 == 27.7	7/26/14 9:35 == 27.7
7/25/14 21:55 == 27.6	7/26/14 1:50 == 27.6	7/26/14 5:45 == 27.7	7/26/14 9:40 == 27.7
7/25/14 22:00 == 27.6	7/26/14 1:55 == 27.7	7/26/14 5:50 == 27.7	7/26/14 9:45 == 27.7
7/25/14 22:05 == 27.6	7/26/14 2:00 == 27.6	7/26/14 5:55 == 27.7	7/26/14 9:50 == 27.8
7/25/14 22:10 == 27.6	7/26/14 2:05 == 27.5	7/26/14 6:00 == 27.8	7/26/14 9:55 == 27.7
7/25/14 22:15 == 27.6	7/26/14 2:10 == 27.7	7/26/14 6:05 == 27.7	7/26/14 10:00 == 27.8
7/25/14 22:20 == 27.6	7/26/14 2:15 == 27.6	7/26/14 6:10 == 27.8	7/26/14 10:05 == 27.8
7/25/14 22:25 == 27.6	7/26/14 2:20 == 27.6	7/26/14 6:15 == 27.7	7/26/14 10:10 == 27.8
7/25/14 22:30 == 27.7	7/26/14 2:25 == 27.7	7/26/14 6:20 == 27.7	7/26/14 10:15 == 27.8
7/25/14 22:35 == 27.6	7/26/14 2:30 == 27.6	7/26/14 6:25 == 27.7	7/26/14 10:20 == 27.7
7/25/14 22:40 == 27.6	7/26/14 2:35 == 27.6	7/26/14 6:30 == 27.7	7/26/14 10:25 == 27.7
7/25/14 22:45 == 27.6	7/26/14 2:40 == 27.6	7/26/14 6:35 == 27.8	7/26/14 10:30 == 27.8
7/25/14 22:50 == 27.6	7/26/14 2:45 == 27.7	7/26/14 6:40 == 27.7	7/26/14 10:35 == 27.7
7/25/14 22:55 == 27.6	7/26/14 2:50 == 27.7	7/26/14 6:45 == 27.7	7/26/14 10:40 == 27.8
7/25/14 23:00 == 27.7	7/26/14 2:55 == 27.6	7/26/14 6:50 == 27.7	7/26/14 10:45 == 27.7
7/25/14 23:05 == 27.5	7/26/14 3:00 == 27.7	7/26/14 6:55 == 27.8	7/26/14 10:50 == 27.7
7/25/14 23:10 == 27.7	7/26/14 3:05 == 27.7	7/26/14 7:00 == 27.8	7/26/14 10:55 == 27.7

Pumpback Station Discharge (0364)

7/26/14 11:00 == 27.8	7/26/14 14:55 == 18.6	7/26/14 18:50 == 27.8	7/26/14 22:45 == 27.8
7/26/14 11:05 == 27.7	7/26/14 15:00 == 18.7	7/26/14 18:55 == 27.9	7/26/14 22:50 == 27.8
7/26/14 11:10 == 27.8	7/26/14 15:05 == 18.6	7/26/14 19:00 == 27.9	7/26/14 22:55 == 27.8
7/26/14 11:15 == 27.7	7/26/14 15:10 == 18.6	7/26/14 19:05 == 27.8	7/26/14 23:00 == 27.9
7/26/14 11:20 == 27.7	7/26/14 15:15 == 18.7	7/26/14 19:10 == 27.8	7/26/14 23:05 == 27.8
7/26/14 11:25 == 27.8	7/26/14 15:20 == 18.7	7/26/14 19:15 == 27.8	7/26/14 23:10 == 27.8
7/26/14 11:30 == 27.8	7/26/14 15:25 == 19.4	7/26/14 19:20 == 27.8	7/26/14 23:15 == 27.8
7/26/14 11:35 == 27.8	7/26/14 15:30 == 28.3	7/26/14 19:25 == 27.8	7/26/14 23:20 == 27.8
7/26/14 11:40 == 27.8	7/26/14 15:35 == 27.8	7/26/14 19:30 == 27.7	7/26/14 23:25 == 27.8
7/26/14 11:45 == 27.7	7/26/14 15:40 == 27.8	7/26/14 19:35 == 27.8	7/26/14 23:30 == 27.7
7/26/14 11:50 == 27.7	7/26/14 15:45 == 27.8	7/26/14 19:40 == 27.8	7/26/14 23:35 == 27.8
7/26/14 11:55 == 27.7	7/26/14 15:50 == 27.8	7/26/14 19:45 == 27.8	7/26/14 23:40 == 27.9
7/26/14 12:00 == 27.7	7/26/14 15:55 == 27.8	7/26/14 19:50 == 27.8	7/26/14 23:45 == 27.8
7/26/14 12:05 == 27.7	7/26/14 16:00 == 27.9	7/26/14 19:55 == 27.8	7/26/14 23:50 == 27.7
7/26/14 12:10 == 27.7	7/26/14 16:05 == 27.8	7/26/14 20:00 == 27.7	7/26/14 23:55 == 27.7
7/26/14 12:15 == 27.8	7/26/14 16:10 == 27.8	7/26/14 20:05 == 27.7	7/27/14 0:00 == 27.7
7/26/14 12:20 == 27.7	7/26/14 16:15 == 27.8	7/26/14 20:10 == 27.8	7/27/14 0:05 == 27.8
7/26/14 12:25 == 27.7	7/26/14 16:20 == 27.8	7/26/14 20:15 == 27.7	7/27/14 0:10 == 27.7
7/26/14 12:30 == 27.7	7/26/14 16:25 == 27.8	7/26/14 20:20 == 27.8	7/27/14 0:15 == 27.7
7/26/14 12:35 == 27.7	7/26/14 16:30 == 27.7	7/26/14 20:25 == 27.7	7/27/14 0:20 == 27.7
7/26/14 12:40 == 27.7	7/26/14 16:35 == 27.9	7/26/14 20:30 == 27.9	7/27/14 0:25 == 27.7
7/26/14 12:45 == 27.7	7/26/14 16:40 == 27.8	7/26/14 20:35 == 27.8	7/27/14 0:30 == 27.8
7/26/14 12:50 == 27.7	7/26/14 16:45 == 27.8	7/26/14 20:40 == 27.8	7/27/14 0:35 == 27.8
7/26/14 12:55 == 27.8	7/26/14 16:50 == 27.8	7/26/14 20:45 == 27.7	7/27/14 0:40 == 27.9
7/26/14 13:00 == #	7/26/14 16:55 == 27.8	7/26/14 20:50 == 27.8	7/27/14 0:45 == 27.8
7/26/14 13:05 == 27.8	7/26/14 17:00 == 27.8	7/26/14 20:55 == 27.8	7/27/14 0:50 == 27.8
7/26/14 13:10 == 27.7	7/26/14 17:05 == 27.8	7/26/14 21:00 == 27.8	7/27/14 0:55 == 27.8
7/26/14 13:15 == 27.8	7/26/14 17:10 == 27.8	7/26/14 21:05 == 27.7	7/27/14 1:00 == 27.8
7/26/14 13:20 == 27.8	7/26/14 17:15 == 27.8	7/26/14 21:10 == 27.8	7/27/14 1:05 == 27.8
7/26/14 13:25 == 27.8	7/26/14 17:20 == 27.8	7/26/14 21:15 == 27.8	7/27/14 1:10 == 27.8
7/26/14 13:30 == 27.7	7/26/14 17:25 == 27.8	7/26/14 21:20 == 27.8	7/27/14 1:15 == 27.7
7/26/14 13:35 == 27.8	7/26/14 17:30 == 27.8	7/26/14 21:25 == 27.7	7/27/14 1:20 == 27.7
7/26/14 13:40 == 27.7	7/26/14 17:35 == 27.8	7/26/14 21:30 == 27.9	7/27/14 1:25 == 27.8
7/26/14 13:45 == 27.7	7/26/14 17:40 == 27.8	7/26/14 21:35 == 27.7	7/27/14 1:30 == 27.8
7/26/14 13:50 == 27.8	7/26/14 17:45 == 27.9	7/26/14 21:40 == 27.8	7/27/14 1:35 == 27.8
7/26/14 13:55 == 27.7	7/26/14 17:50 == 27.8	7/26/14 21:45 == 27.8	7/27/14 1:40 == 27.8
7/26/14 14:00 == 27.7	7/26/14 17:55 == 27.7	7/26/14 21:50 == 27.8	7/27/14 1:45 == 27.8
7/26/14 14:05 == 24.1	7/26/14 18:00 == 27.8	7/26/14 21:55 == 27.7	7/27/14 1:50 == 27.8
7/26/14 14:10 == 18.7	7/26/14 18:05 == 27.8	7/26/14 22:00 == 27.8	7/27/14 1:55 == 27.8
7/26/14 14:15 == 18.6	7/26/14 18:10 == 27.8	7/26/14 22:05 == 27.8	7/27/14 2:00 == 27.9
7/26/14 14:20 == 18.7	7/26/14 18:15 == 27.7	7/26/14 22:10 == 27.8	7/27/14 2:05 == 27.7
7/26/14 14:25 == 18.6	7/26/14 18:20 == 27.8	7/26/14 22:15 == 27.7	7/27/14 2:10 == 27.7
7/26/14 14:30 == 18.6	7/26/14 18:25 == 27.8	7/26/14 22:20 == 27.7	7/27/14 2:15 == 27.8
7/26/14 14:35 == 18.6	7/26/14 18:30 == 27.8	7/26/14 22:25 == 27.8	7/27/14 2:20 == 27.8
7/26/14 14:40 == 18.7	7/26/14 18:35 == 27.7	7/26/14 22:30 == 27.8	7/27/14 2:25 == 27.8
7/26/14 14:45 == 18.7	7/26/14 18:40 == 27.8	7/26/14 22:35 == 27.8	7/27/14 2:30 == 27.8
7/26/14 14:50 == 18.6	7/26/14 18:45 == 27.8	7/26/14 22:40 == 27.8	7/27/14 2:35 == 27.8

Pumpback Station Discharge (0364)

7/27/14 2:40 == 27.8	7/27/14 6:35 == 27.8	7/27/14 10:30 == 27.9	7/27/14 14:25 == 18.7
7/27/14 2:45 == 27.8	7/27/14 6:40 == 27.9	7/27/14 10:35 == 27.9	7/27/14 14:30 == 18.8
7/27/14 2:50 == 27.9	7/27/14 6:45 == 27.9	7/27/14 10:40 == 27.9	7/27/14 14:35 == 18.7
7/27/14 2:55 == 27.8	7/27/14 6:50 == 27.9	7/27/14 10:45 == 27.9	7/27/14 14:40 == 18.8
7/27/14 3:00 == 27.8	7/27/14 6:55 == 27.9	7/27/14 10:50 == 28	7/27/14 14:45 == 18.7
7/27/14 3:05 == 27.6	7/27/14 7:00 == 27.8	7/27/14 10:55 == 27.9	7/27/14 14:50 == 18.7
7/27/14 3:10 == 27.8	7/27/14 7:05 == 27.9	7/27/14 11:00 == 27.9	7/27/14 14:55 == 18.7
7/27/14 3:15 == 27.8	7/27/14 7:10 == 27.9	7/27/14 11:05 == 27.9	7/27/14 15:00 == 18.7
7/27/14 3:20 == 27.7	7/27/14 7:15 == 27.9	7/27/14 11:10 == 27.9	7/27/14 15:05 == 18.7
7/27/14 3:25 == 27.8	7/27/14 7:20 == 27.9	7/27/14 11:15 == 27.9	7/27/14 15:10 == 18.7
7/27/14 3:30 == 27.8	7/27/14 7:25 == 27.9	7/27/14 11:20 == 27.9	7/27/14 15:15 == 18.7
7/27/14 3:35 == 27.8	7/27/14 7:30 == 27.8	7/27/14 11:25 == 27.8	7/27/14 15:20 == 18.8
7/27/14 3:40 == 27.7	7/27/14 7:35 == 27.9	7/27/14 11:30 == 27.9	7/27/14 15:25 == 19.6
7/27/14 3:45 == 27.8	7/27/14 7:40 == 27.8	7/27/14 11:35 == 27.8	7/27/14 15:30 == 27.9
7/27/14 3:50 == 27.8	7/27/14 7:45 == 27.8	7/27/14 11:40 == 27.9	7/27/14 15:35 == 27.9
7/27/14 3:55 == 27.8	7/27/14 7:50 == 27.9	7/27/14 11:45 == 27.8	7/27/14 15:40 == 28
7/27/14 4:00 == 27.8	7/27/14 7:55 == 27.8	7/27/14 11:50 == 27.9	7/27/14 15:45 == 28
7/27/14 4:05 == 27.8	7/27/14 8:00 == 27.9	7/27/14 11:55 == 27.8	7/27/14 15:50 == 27.9
7/27/14 4:10 == 27.7	7/27/14 8:05 == 27.9	7/27/14 12:00 == 27.9	7/27/14 15:55 == 27.9
7/27/14 4:15 == 27.8	7/27/14 8:10 == 27.9	7/27/14 12:05 == 27.9	7/27/14 16:00 == 27.9
7/27/14 4:20 == 27.9	7/27/14 8:15 == 27.9	7/27/14 12:10 == 27.8	7/27/14 16:05 == 27.9
7/27/14 4:25 == 27.9	7/27/14 8:20 == 27.9	7/27/14 12:15 == 27.8	7/27/14 16:10 == 27.9
7/27/14 4:30 == 27.8	7/27/14 8:25 == 27.8	7/27/14 12:20 == 27.8	7/27/14 16:15 == 27.8
7/27/14 4:35 == 27.9	7/27/14 8:30 == 27.9	7/27/14 12:25 == 27.9	7/27/14 16:20 == 27.9
7/27/14 4:40 == 27.8	7/27/14 8:35 == 27.8	7/27/14 12:30 == 27.9	7/27/14 16:25 == 27.9
7/27/14 4:45 == 27.8	7/27/14 8:40 == 27.8	7/27/14 12:35 == 27.8	7/27/14 16:30 == 27.9
7/27/14 4:50 == 27.8	7/27/14 8:45 == 27.9	7/27/14 12:40 == 27.8	7/27/14 16:35 == 27.9
7/27/14 4:55 == 27.8	7/27/14 8:50 == 27.8	7/27/14 12:45 == 27.9	7/27/14 16:40 == 27.9
7/27/14 5:00 == 27.8	7/27/14 8:55 == 27.8	7/27/14 12:50 == 27.9	7/27/14 16:45 == 27.8
7/27/14 5:05 == 27.9	7/27/14 9:00 == 27.9	7/27/14 12:55 == 27.8	7/27/14 16:50 == 27.9
7/27/14 5:10 == 27.7	7/27/14 9:05 == 27.8	7/27/14 13:00 == 27.9	7/27/14 16:55 == 27.8
7/27/14 5:15 == 27.7	7/27/14 9:10 == 27.9	7/27/14 13:05 == 27.9	7/27/14 17:00 == 27.9
7/27/14 5:20 == 27.8	7/27/14 9:15 == 27.9	7/27/14 13:10 == 27.9	7/27/14 17:05 == 27.8
7/27/14 5:25 == 27.8	7/27/14 9:20 == 27.8	7/27/14 13:15 == 27.9	7/27/14 17:10 == 27.8
7/27/14 5:30 == 27.8	7/27/14 9:25 == 27.9	7/27/14 13:20 == 27.9	7/27/14 17:15 == 27.9
7/27/14 5:35 == 27.8	7/27/14 9:30 == 27.8	7/27/14 13:25 == 27.9	7/27/14 17:20 == 27.9
7/27/14 5:40 == 27.9	7/27/14 9:35 == 27.8	7/27/14 13:30 == 27.8	7/27/14 17:25 == 28
7/27/14 5:45 == 27.7	7/27/14 9:40 == 27.9	7/27/14 13:35 == 27.9	7/27/14 17:30 == 27.9
7/27/14 5:50 == 27.8	7/27/14 9:45 == 28	7/27/14 13:40 == 27.8	7/27/14 17:35 == 27.9
7/27/14 5:55 == 27.8	7/27/14 9:50 == 27.9	7/27/14 13:45 == 27.8	7/27/14 17:40 == 28
7/27/14 6:00 == 27.8	7/27/14 9:55 == 27.8	7/27/14 13:50 == 27.8	7/27/14 17:45 == 27.9
7/27/14 6:05 == 16	7/27/14 10:00 == 27.9	7/27/14 13:55 == 18.8	7/27/14 17:50 == 27.9
7/27/14 6:10 == 0	7/27/14 10:05 == 27.9	7/27/14 14:00 == 18.7	7/27/14 17:55 == 27.9
7/27/14 6:15 == 0	7/27/14 10:10 == 27.8	7/27/14 14:05 == 18.7	7/27/14 18:00 == 27.9
7/27/14 6:20 == 0	7/27/14 10:15 == 27.9	7/27/14 14:10 == 18.8	7/27/14 18:05 == 27.9
7/27/14 6:25 == 2.6	7/27/14 10:20 == 27.9	7/27/14 14:15 == 18.7	7/27/14 18:10 == 27.9
7/27/14 6:30 == 27.6	7/27/14 10:25 == 27.9	7/27/14 14:20 == 18.7	7/27/14 18:15 == 28

Pumpback Station Discharge (0364)

7/27/14 18:20 == 27.9	7/27/14 22:15 == 27.9	7/28/14 2:10 == 27.9	7/28/14 6:05 == 27.9
7/27/14 18:25 == 27.9	7/27/14 22:20 == 27.9	7/28/14 2:15 == 27.9	7/28/14 6:10 == 28
7/27/14 18:30 == 27.9	7/27/14 22:25 == 27.9	7/28/14 2:20 == 27.9	7/28/14 6:15 == 27.9
7/27/14 18:35 == 27.9	7/27/14 22:30 == 28	7/28/14 2:25 == 28	7/28/14 6:20 == 28
7/27/14 18:40 == 27.9	7/27/14 22:35 == 28	7/28/14 2:30 == 27.9	7/28/14 6:25 == 28
7/27/14 18:45 == 28	7/27/14 22:40 == 28	7/28/14 2:35 == 27.8	7/28/14 6:30 == 27.9
7/27/14 18:50 == 27.9	7/27/14 22:45 == 28	7/28/14 2:40 == 27.9	7/28/14 6:35 == 27.9
7/27/14 18:55 == 28	7/27/14 22:50 == 28	7/28/14 2:45 == 27.9	7/28/14 6:40 == 27.9
7/27/14 19:00 == 27.9	7/27/14 22:55 == 28	7/28/14 2:50 == 27.9	7/28/14 6:45 == 27.9
7/27/14 19:05 == 28	7/27/14 23:00 == 27.8	7/28/14 2:55 == 27.9	7/28/14 6:50 == 27.9
7/27/14 19:10 == 27.9	7/27/14 23:05 == 27.9	7/28/14 3:00 == 27.9	7/28/14 6:55 == 27.9
7/27/14 19:15 == 28	7/27/14 23:10 == 28	7/28/14 3:05 == 27.9	7/28/14 7:00 == 27.9
7/27/14 19:20 == 27.9	7/27/14 23:15 == 28	7/28/14 3:10 == 27.9	7/28/14 7:05 == 27.9
7/27/14 19:25 == 27.9	7/27/14 23:20 == 27.9	7/28/14 3:15 == 27.8	7/28/14 7:10 == 27.9
7/27/14 19:30 == 27.8	7/27/14 23:25 == 27.9	7/28/14 3:20 == 27.9	7/28/14 7:15 == 28
7/27/14 19:35 == 28	7/27/14 23:30 == 27.9	7/28/14 3:25 == 27.9	7/28/14 7:20 == 27.9
7/27/14 19:40 == 28	7/27/14 23:35 == 28	7/28/14 3:30 == 27.9	7/28/14 7:25 == 28
7/27/14 19:45 == 27.9	7/27/14 23:40 == 28	7/28/14 3:35 == 28.1	7/28/14 7:30 == 27.9
7/27/14 19:50 == 27.9	7/27/14 23:45 == 27.9	7/28/14 3:40 == 27.9	7/28/14 7:35 == 27.9
7/27/14 19:55 == 27.9	7/27/14 23:50 == 28	7/28/14 3:45 == 28.1	7/28/14 7:40 == 27.9
7/27/14 20:00 == 27.9	7/27/14 23:55 == 27.9	7/28/14 3:50 == 27.9	7/28/14 7:45 == 27.9
7/27/14 20:05 == 27.9	7/28/14 0:00 == 27.9	7/28/14 3:55 == 28.1	7/28/14 7:50 == 27.9
7/27/14 20:10 == 27.9	7/28/14 0:05 == 27.9	7/28/14 4:00 == 27.9	7/28/14 7:55 == 28
7/27/14 20:15 == 27.9	7/28/14 0:10 == 27.9	7/28/14 4:05 == 27.9	7/28/14 8:00 == 27.9
7/27/14 20:20 == 27.9	7/28/14 0:15 == 27.9	7/28/14 4:10 == 28	7/28/14 8:05 == 28
7/27/14 20:25 == 28	7/28/14 0:20 == 27.9	7/28/14 4:15 == 27.9	7/28/14 8:10 == 28
7/27/14 20:30 == 28	7/28/14 0:25 == 27.9	7/28/14 4:20 == 27.9	7/28/14 8:15 == 28.2
7/27/14 20:35 == 28	7/28/14 0:30 == 27.9	7/28/14 4:25 == 27.9	7/28/14 8:20 == 27.9
7/27/14 20:40 == 28	7/28/14 0:35 == 27.9	7/28/14 4:30 == 27.9	7/28/14 8:25 == 27.9
7/27/14 20:45 == 27.9	7/28/14 0:40 == 27.9	7/28/14 4:35 == 28.1	7/28/14 8:30 == 27.9
7/27/14 20:50 == 28	7/28/14 0:45 == 28	7/28/14 4:40 == 27.9	7/28/14 8:35 == 27.8
7/27/14 20:55 == 27.9	7/28/14 0:50 == 28	7/28/14 4:45 == 27.9	7/28/14 8:40 == 27.9
7/27/14 21:00 == 28	7/28/14 0:55 == 27.9	7/28/14 4:50 == 27.9	7/28/14 8:45 == 27.8
7/27/14 21:05 == 28	7/28/14 1:00 == 27.9	7/28/14 4:55 == 27.9	7/28/14 8:50 == 27.9
7/27/14 21:10 == 28	7/28/14 1:05 == 27.9	7/28/14 5:00 == 27.9	7/28/14 8:55 == 27.9
7/27/14 21:15 == 28	7/28/14 1:10 == 28	7/28/14 5:05 == 28	7/28/14 9:00 == 27.9
7/27/14 21:20 == 27.9	7/28/14 1:15 == 28	7/28/14 5:10 == 27.9	7/28/14 9:05 == 28
7/27/14 21:25 == 28	7/28/14 1:20 == 27.9	7/28/14 5:15 == 27.9	7/28/14 9:10 == 27.9
7/27/14 21:30 == 27.9	7/28/14 1:25 == 27.9	7/28/14 5:20 == 27.9	7/28/14 9:15 == 27.9
7/27/14 21:35 == 28	7/28/14 1:30 == 27.9	7/28/14 5:25 == 27.9	7/28/14 9:20 == 27.9
7/27/14 21:40 == 28	7/28/14 1:35 == 27.9	7/28/14 5:30 == 28.1	7/28/14 9:25 == 27.8
7/27/14 21:45 == 28	7/28/14 1:40 == 27.9	7/28/14 5:35 == 27.8	7/28/14 9:30 == 28.1
7/27/14 21:50 == 28	7/28/14 1:45 == 27.8	7/28/14 5:40 == 28	7/28/14 9:35 == 27.9
7/27/14 21:55 == 28	7/28/14 1:50 == 27.9	7/28/14 5:45 == 28	7/28/14 9:40 == 27.9
7/27/14 22:00 == 27.9	7/28/14 1:55 == 27.9	7/28/14 5:50 == 27.8	7/28/14 9:45 == 27.9
7/27/14 22:05 == 27.9	7/28/14 2:00 == 27.9	7/28/14 5:55 == 28	7/28/14 9:50 == 27.9
7/27/14 22:10 == 28	7/28/14 2:05 == 27.9	7/28/14 6:00 == 27.8	7/28/14 9:55 == 28

Pumpback Station Discharge (0364)

7/28/14 10:00 == 27.9	7/28/14 13:55 == 18.8	7/28/14 17:50 == 28.1	7/28/14 21:45 == 28.6
7/28/14 10:05 == 28	7/28/14 14:00 == 18.8	7/28/14 17:55 == 28.1	7/28/14 21:50 == 28.2
7/28/14 10:10 == 27.9	7/28/14 14:05 == 18.8	7/28/14 18:00 == 28.1	7/28/14 21:55 == 28.3
7/28/14 10:15 == 27.9	7/28/14 14:10 == 18.7	7/28/14 18:05 == 28.1	7/28/14 22:00 == 28.3
7/28/14 10:20 == 27.9	7/28/14 14:15 == 18.8	7/28/14 18:10 == 28.1	7/28/14 22:05 == 28.3
7/28/14 10:25 == 27.9	7/28/14 14:20 == 18.7	7/28/14 18:15 == 28	7/28/14 22:10 == 28.2
7/28/14 10:30 == 28.1	7/28/14 14:25 == 18.8	7/28/14 18:20 == 28.1	7/28/14 22:15 == 28.2
7/28/14 10:35 == 27.8	7/28/14 14:30 == 18.8	7/28/14 18:25 == 28	7/28/14 22:20 == 28.2
7/28/14 10:40 == 28	7/28/14 14:35 == 18.8	7/28/14 18:30 == 28	7/28/14 22:25 == 28.3
7/28/14 10:45 == 27.9	7/28/14 14:40 == 18.8	7/28/14 18:35 == 28.1	7/28/14 22:30 == 28.3
7/28/14 10:50 == 27.9	7/28/14 14:45 == 18.8	7/28/14 18:40 == 28	7/28/14 22:35 == 28.2
7/28/14 10:55 == 27.9	7/28/14 14:50 == 18.8	7/28/14 18:45 == 28.2	7/28/14 22:40 == 28.3
7/28/14 11:00 == 27.9	7/28/14 14:55 == 18.8	7/28/14 18:50 == 28.1	7/28/14 22:45 == 28.3
7/28/14 11:05 == 27.9	7/28/14 15:00 == 18.8	7/28/14 18:55 == 28.1	7/28/14 22:50 == 28.2
7/28/14 11:10 == 27.9	7/28/14 15:05 == 18.9	7/28/14 19:00 == 28	7/28/14 22:55 == 28.2
7/28/14 11:15 == 28	7/28/14 15:10 == 18.8	7/28/14 19:05 == 28	7/28/14 23:00 == 28.2
7/28/14 11:20 == 27.8	7/28/14 15:15 == 18.9	7/28/14 19:10 == 28	7/28/14 23:05 == 28.2
7/28/14 11:25 == 28	7/28/14 15:20 == 18.9	7/28/14 19:15 == 28.1	7/28/14 23:10 == 28.2
7/28/14 11:30 == 28	7/28/14 15:25 == 18.8	7/28/14 19:20 == 28.1	7/28/14 23:15 == 28.2
7/28/14 11:35 == 27.9	7/28/14 15:30 == 18.8	7/28/14 19:25 == 28.1	7/28/14 23:20 == 28.2
7/28/14 11:40 == 28	7/28/14 15:35 == 25.2	7/28/14 19:30 == 28.1	7/28/14 23:25 == 28.2
7/28/14 11:45 == 27.9	7/28/14 15:40 == 28.1	7/28/14 19:35 == 28.1	7/28/14 23:30 == 28.3
7/28/14 11:50 == 28	7/28/14 15:45 == 28.1	7/28/14 19:40 == 28.1	7/28/14 23:35 == 28.2
7/28/14 11:55 == 27.9	7/28/14 15:50 == 28.2	7/28/14 19:45 == 28	7/28/14 23:40 == 28.3
7/28/14 12:00 == 27.9	7/28/14 15:55 == 28.1	7/28/14 19:50 == 28	7/28/14 23:45 == 28.2
7/28/14 12:05 == 27.9	7/28/14 16:00 == 28.1	7/28/14 19:55 == 28.1	7/28/14 23:50 == 28.2
7/28/14 12:10 == 28.1	7/28/14 16:05 == 28.1	7/28/14 20:00 == 28.1	7/28/14 23:55 == 28.2
7/28/14 12:15 == 27.9	7/28/14 16:10 == 28.1	7/28/14 20:05 == 28	7/29/14 0:00 == 28.2
7/28/14 12:20 == 28	7/28/14 16:15 == 28.1	7/28/14 20:10 == 28.1	7/29/14 0:05 == 28.2
7/28/14 12:25 == 27.9	7/28/14 16:20 == 28.1	7/28/14 20:15 == 28	7/29/14 0:10 == 28.1
7/28/14 12:30 == 28	7/28/14 16:25 == 28.1	7/28/14 20:20 == 28	7/29/14 0:15 == 28.3
7/28/14 12:35 == 27.9	7/28/14 16:30 == 28.1	7/28/14 20:25 == 4.9	7/29/14 0:20 == 28.1
7/28/14 12:40 == 27.9	7/28/14 16:35 == 28.1	7/28/14 20:30 == 0	7/29/14 0:25 == 28.1
7/28/14 12:45 == 28	7/28/14 16:40 == 28	7/28/14 20:35 == 0	7/29/14 0:30 == 28.2
7/28/14 12:50 == 18.9	7/28/14 16:45 == 28	7/28/14 20:40 == 0	7/29/14 0:35 == 28.1
7/28/14 12:55 == 18.8	7/28/14 16:50 == 28.1	7/28/14 20:45 == #	7/29/14 0:40 == 28.2
7/28/14 13:00 == 18.8	7/28/14 16:55 == 28.1	7/28/14 20:50 == 0	7/29/14 0:45 == 28.2
7/28/14 13:05 == 18.8	7/28/14 17:00 == 28.1	7/28/14 20:55 == 0	7/29/14 0:50 == 28.2
7/28/14 13:10 == 18.8	7/28/14 17:05 == 28.1	7/28/14 21:00 == #	7/29/14 0:55 == 28.1
7/28/14 13:15 == 18.8	7/28/14 17:10 == 28.2	7/28/14 21:05 == 0	7/29/14 1:00 == 28.1
7/28/14 13:20 == 18.7	7/28/14 17:15 == 28.1	7/28/14 21:10 == 0	7/29/14 1:05 == 28.1
7/28/14 13:25 == 18.8	7/28/14 17:20 == 28	7/28/14 21:15 == 0	7/29/14 1:10 == 28.2
7/28/14 13:30 == 18.7	7/28/14 17:25 == 28.1	7/28/14 21:20 == #	7/29/14 1:15 == 28.2
7/28/14 13:35 == 18.8	7/28/14 17:30 == 28.1	7/28/14 21:25 == 0	7/29/14 1:20 == 28.3
7/28/14 13:40 == 18.8	7/28/14 17:35 == 28.1	7/28/14 21:30 == 0	7/29/14 1:25 == 28.1
7/28/14 13:45 == 18.8	7/28/14 17:40 == 28	7/28/14 21:35 == #	7/29/14 1:30 == 28.1
7/28/14 13:50 == 18.7	7/28/14 17:45 == 28.1	7/28/14 21:40 == 15.6	7/29/14 1:35 == 28.2

Pumpback Station Discharge (0364)

7/29/14 1:40 == 28.2	7/29/14 5:35 == 28.1	7/29/14 9:30 == 28	7/29/14 13:25 == 28.1
7/29/14 1:45 == 28.1	7/29/14 5:40 == 28.1	7/29/14 9:35 == 28.2	7/29/14 13:30 == 28.2
7/29/14 1:50 == 28.2	7/29/14 5:45 == 28.2	7/29/14 9:40 == 28.1	7/29/14 13:35 == 28.1
7/29/14 1:55 == 28.1	7/29/14 5:50 == 28.1	7/29/14 9:45 == 28.1	7/29/14 13:40 == 28
7/29/14 2:00 == 28.2	7/29/14 5:55 == 28.1	7/29/14 9:50 == 28.1	7/29/14 13:45 == 28.1
7/29/14 2:05 == 28.2	7/29/14 6:00 == 28.1	7/29/14 9:55 == 28.1	7/29/14 13:50 == 28.1
7/29/14 2:10 == 28.1	7/29/14 6:05 == 28.1	7/29/14 10:00 == 28.1	7/29/14 13:55 == 28.1
7/29/14 2:15 == 28.1	7/29/14 6:10 == 28.1	7/29/14 10:05 == 28.1	7/29/14 14:00 == 28.2
7/29/14 2:20 == 28.1	7/29/14 6:15 == 28.2	7/29/14 10:10 == 28.1	7/29/14 14:05 == 28.1
7/29/14 2:25 == 28.1	7/29/14 6:20 == 28.2	7/29/14 10:15 == 28.1	7/29/14 14:10 == 28.1
7/29/14 2:30 == 28.2	7/29/14 6:25 == 28.1	7/29/14 10:20 == 28.2	7/29/14 14:15 == 28.1
7/29/14 2:35 == 28.1	7/29/14 6:30 == 28.2	7/29/14 10:25 == 28.2	7/29/14 14:20 == 28.1
7/29/14 2:40 == 28.1	7/29/14 6:35 == 28.1	7/29/14 10:30 == 28.1	7/29/14 14:25 == 28
7/29/14 2:45 == 28.2	7/29/14 6:40 == 28.2	7/29/14 10:35 == 28	7/29/14 14:30 == 28.1
7/29/14 2:50 == 28.1	7/29/14 6:45 == 28	7/29/14 10:40 == 28.1	7/29/14 14:35 == 28.1
7/29/14 2:55 == 28.1	7/29/14 6:50 == 28	7/29/14 10:45 == 28.1	7/29/14 14:40 == 28.2
7/29/14 3:00 == 28.1	7/29/14 6:55 == 28.1	7/29/14 10:50 == 28.1	7/29/14 14:45 == 28
7/29/14 3:05 == 28.1	7/29/14 7:00 == 28.2	7/29/14 10:55 == 28.2	7/29/14 14:50 == 28.1
7/29/14 3:10 == 28.2	7/29/14 7:05 == 28.2	7/29/14 11:00 == 28.1	7/29/14 14:55 == 28.1
7/29/14 3:15 == 28.1	7/29/14 7:10 == 28.2	7/29/14 11:05 == 28.1	7/29/14 15:00 == 28.1
7/29/14 3:20 == 28.1	7/29/14 7:15 == 28	7/29/14 11:10 == 28.1	7/29/14 15:05 == 28.3
7/29/14 3:25 == 28.1	7/29/14 7:20 == 28.2	7/29/14 11:15 == 28	7/29/14 15:10 == 28.1
7/29/14 3:30 == 28.2	7/29/14 7:25 == 28.2	7/29/14 11:20 == 28	7/29/14 15:15 == 28.1
7/29/14 3:35 == 28.2	7/29/14 7:30 == 28.1	7/29/14 11:25 == 28.1	7/29/14 15:20 == 28.1
7/29/14 3:40 == 28.1	7/29/14 7:35 == 28.2	7/29/14 11:30 == 28.1	7/29/14 15:25 == 28.2
7/29/14 3:45 == 28.2	7/29/14 7:40 == 28	7/29/14 11:35 == 28.1	7/29/14 15:30 == 28.1
7/29/14 3:50 == 28.1	7/29/14 7:45 == 28.1	7/29/14 11:40 == 28	7/29/14 15:35 == 28.1
7/29/14 3:55 == 28.1	7/29/14 7:50 == 28.1	7/29/14 11:45 == 28.1	7/29/14 15:40 == 28.2
7/29/14 4:00 == 28.1	7/29/14 7:55 == 28.1	7/29/14 11:50 == 28.1	7/29/14 15:45 == 28
7/29/14 4:05 == 28.2	7/29/14 8:00 == 28.1	7/29/14 11:55 == 28.2	7/29/14 15:50 == 28.1
7/29/14 4:10 == 28.2	7/29/14 8:05 == 28.2	7/29/14 12:00 == 28.1	7/29/14 15:55 == 28
7/29/14 4:15 == 28.1	7/29/14 8:10 == 28.1	7/29/14 12:05 == 28.2	7/29/14 16:00 == 28.1
7/29/14 4:20 == 28.1	7/29/14 8:15 == 28.2	7/29/14 12:10 == 28.2	7/29/14 16:05 == 28.2
7/29/14 4:25 == 28.3	7/29/14 8:20 == 28.1	7/29/14 12:15 == 28.1	7/29/14 16:10 == 28.1
7/29/14 4:30 == 28.1	7/29/14 8:25 == 28.2	7/29/14 12:20 == 28.1	7/29/14 16:15 == 28
7/29/14 4:35 == 28.1	7/29/14 8:30 == 28.1	7/29/14 12:25 == 28.1	7/29/14 16:20 == 28.1
7/29/14 4:40 == 28.1	7/29/14 8:35 == 28.1	7/29/14 12:30 == 28.2	7/29/14 16:25 == 28
7/29/14 4:45 == 28.2	7/29/14 8:40 == 28.1	7/29/14 12:35 == 28.1	7/29/14 16:30 == 28.1
7/29/14 4:50 == 28.2	7/29/14 8:45 == 28.1	7/29/14 12:40 == 28.1	7/29/14 16:35 == 28
7/29/14 4:55 == 28	7/29/14 8:50 == 28.2	7/29/14 12:45 == 28	7/29/14 16:40 == 28.1
7/29/14 5:00 == 28.2	7/29/14 8:55 == 28.1	7/29/14 12:50 == 28.1	7/29/14 16:45 == 28.1
7/29/14 5:05 == 28.2	7/29/14 9:00 == 28.2	7/29/14 12:55 == 28	7/29/14 16:50 == 28.1
7/29/14 5:10 == 28.2	7/29/14 9:05 == 28.2	7/29/14 13:00 == 28	7/29/14 16:55 == 28
7/29/14 5:15 == 28.1	7/29/14 9:10 == 28.2	7/29/14 13:05 == 28.1	7/29/14 17:00 == 28
7/29/14 5:20 == 28.1	7/29/14 9:15 == 28.2	7/29/14 13:10 == 28	7/29/14 17:05 == 28.1
7/29/14 5:25 == 28.1	7/29/14 9:20 == 28.1	7/29/14 13:15 == 28.1	7/29/14 17:10 == 28.1
7/29/14 5:30 == 28.1	7/29/14 9:25 == 28.1	7/29/14 13:20 == 28.1	7/29/14 17:15 == 28

Pumpback Station Discharge (0364)

7/29/14 17:20 == 28	7/29/14 21:15 == 28.2	7/30/14 1:10 == 28	7/30/14 5:05 == 28.1
7/29/14 17:25 == 28	7/29/14 21:20 == 28.1	7/30/14 1:15 == 28	7/30/14 5:10 == 28.1
7/29/14 17:30 == 28.1	7/29/14 21:25 == 28.1	7/30/14 1:20 == 28.1	7/30/14 5:15 == 28
7/29/14 17:35 == 28.2	7/29/14 21:30 == 28.1	7/30/14 1:25 == 28	7/30/14 5:20 == 28.1
7/29/14 17:40 == 28.1	7/29/14 21:35 == 28.1	7/30/14 1:30 == 28.1	7/30/14 5:25 == 28.1
7/29/14 17:45 == 28.1	7/29/14 21:40 == 28.1	7/30/14 1:35 == 28.1	7/30/14 5:30 == 28.1
7/29/14 17:50 == 28	7/29/14 21:45 == 28	7/30/14 1:40 == 28	7/30/14 5:35 == 28.1
7/29/14 17:55 == 28	7/29/14 21:50 == 28.1	7/30/14 1:45 == 28.1	7/30/14 5:40 == 28.1
7/29/14 18:00 == 28.1	7/29/14 21:55 == 28.1	7/30/14 1:50 == 28.1	7/30/14 5:45 == 28.1
7/29/14 18:05 == 28.1	7/29/14 22:00 == 28.1	7/30/14 1:55 == 28.1	7/30/14 5:50 == 28.1
7/29/14 18:10 == 28.1	7/29/14 22:05 == 28.1	7/30/14 2:00 == 28.1	7/30/14 5:55 == 28.2
7/29/14 18:15 == 28.1	7/29/14 22:10 == 28.1	7/30/14 2:05 == 28.1	7/30/14 6:00 == 28.2
7/29/14 18:20 == 28.2	7/29/14 22:15 == 28.1	7/30/14 2:10 == 28.1	7/30/14 6:05 == 28
7/29/14 18:25 == 28	7/29/14 22:20 == 28.2	7/30/14 2:15 == 28	7/30/14 6:10 == 28.1
7/29/14 18:30 == 28.1	7/29/14 22:25 == 28.1	7/30/14 2:20 == 28.2	7/30/14 6:15 == 28.2
7/29/14 18:35 == 28	7/29/14 22:30 == 28.1	7/30/14 2:25 == 28.1	7/30/14 6:20 == 28.1
7/29/14 18:40 == 28.1	7/29/14 22:35 == 28.1	7/30/14 2:30 == 28.1	7/30/14 6:25 == 28.1
7/29/14 18:45 == 28.1	7/29/14 22:40 == 28.1	7/30/14 2:35 == 28.1	7/30/14 6:30 == 28.1
7/29/14 18:50 == 28.2	7/29/14 22:45 == 28.2	7/30/14 2:40 == 28.1	7/30/14 6:35 == 28.1
7/29/14 18:55 == 28	7/29/14 22:50 == 28.1	7/30/14 2:45 == 28.1	7/30/14 6:40 == 28.1
7/29/14 19:00 == 28	7/29/14 22:55 == 28.1	7/30/14 2:50 == 28.1	7/30/14 6:45 == 28.1
7/29/14 19:05 == 28	7/29/14 23:00 == 28	7/30/14 2:55 == 28.1	7/30/14 6:50 == 28.1
7/29/14 19:10 == 28.1	7/29/14 23:05 == 28.1	7/30/14 3:00 == 28.1	7/30/14 6:55 == 28.2
7/29/14 19:15 == 28.1	7/29/14 23:10 == 28.2	7/30/14 3:05 == 28.1	7/30/14 7:00 == 28.1
7/29/14 19:20 == 28.1	7/29/14 23:15 == 28.1	7/30/14 3:10 == 28.1	7/30/14 7:05 == 28.1
7/29/14 19:25 == 28.1	7/29/14 23:20 == 28.1	7/30/14 3:15 == 28.1	7/30/14 7:10 == 28.1
7/29/14 19:30 == 28.1	7/29/14 23:25 == 28.1	7/30/14 3:20 == 28.1	7/30/14 7:15 == 28.1
7/29/14 19:35 == 28	7/29/14 23:30 == 28.1	7/30/14 3:25 == 28.1	7/30/14 7:20 == 28.1
7/29/14 19:40 == 28.1	7/29/14 23:35 == 28.1	7/30/14 3:30 == 28.1	7/30/14 7:25 == 28.2
7/29/14 19:45 == 28.1	7/29/14 23:40 == 28.2	7/30/14 3:35 == 28.2	7/30/14 7:30 == 28
7/29/14 19:50 == 28.1	7/29/14 23:45 == 28.2	7/30/14 3:40 == 27.9	7/30/14 7:35 == 37.7
7/29/14 19:55 == 28	7/29/14 23:50 == 28.2	7/30/14 3:45 == 28.2	7/30/14 7:40 == 45.9
7/29/14 20:00 == 28	7/29/14 23:55 == 28.1	7/30/14 3:50 == 28.1	7/30/14 7:45 == 45.8
7/29/14 20:05 == 28.1	7/30/14 0:00 == 28.2	7/30/14 3:55 == 28.1	7/30/14 7:50 == 45.9
7/29/14 20:10 == 28	7/30/14 0:05 == 28.1	7/30/14 4:00 == 28.1	7/30/14 7:55 == 45.8
7/29/14 20:15 == 28	7/30/14 0:10 == 28.1	7/30/14 4:05 == 28.1	7/30/14 8:00 == 45.9
7/29/14 20:20 == 28	7/30/14 0:15 == 28.1	7/30/14 4:10 == 28.3	7/30/14 8:05 == 45.7
7/29/14 20:25 == 28	7/30/14 0:20 == 28.1	7/30/14 4:15 == 28	7/30/14 8:10 == 45.8
7/29/14 20:30 == 28	7/30/14 0:25 == 28	7/30/14 4:20 == 28.3	7/30/14 8:15 == 45.8
7/29/14 20:35 == 28.1	7/30/14 0:30 == 28.1	7/30/14 4:25 == 28.2	7/30/14 8:20 == 45.6
7/29/14 20:40 == 28.1	7/30/14 0:35 == 28.1	7/30/14 4:30 == 28.1	7/30/14 8:25 == 45.8
7/29/14 20:45 == 28.1	7/30/14 0:40 == 28	7/30/14 4:35 == 28.1	7/30/14 8:30 == 45.6
7/29/14 20:50 == 28.2	7/30/14 0:45 == 28.1	7/30/14 4:40 == 28	7/30/14 8:35 == 45.6
7/29/14 20:55 == 28.1	7/30/14 0:50 == 28.2	7/30/14 4:45 == 28	7/30/14 8:40 == 45.8
7/29/14 21:00 == 28	7/30/14 0:55 == 28	7/30/14 4:50 == 28	7/30/14 8:45 == 45.8
7/29/14 21:05 == 28.1	7/30/14 1:00 == 28	7/30/14 4:55 == 28.1	7/30/14 8:50 == 45.7
7/29/14 21:10 == 28	7/30/14 1:05 == 28.1	7/30/14 5:00 == 28.1	7/30/14 8:55 == 41.6

Pumpback Station Discharge (0364)

7/30/14 9:00 == 30.1	7/30/14 12:55 == 11.9	7/30/14 16:50 == 29.3	7/30/14 20:45 == 29.3
7/30/14 9:05 == 30.1	7/30/14 13:00 == 12	7/30/14 16:55 == 29.2	7/30/14 20:50 == 29.3
7/30/14 9:10 == 30.3	7/30/14 13:05 == 12	7/30/14 17:00 == 29.1	7/30/14 20:55 == 29.3
7/30/14 9:15 == 30	7/30/14 13:10 == 12	7/30/14 17:05 == 29.3	7/30/14 21:00 == 29.2
7/30/14 9:20 == 30.2	7/30/14 13:15 == 11.9	7/30/14 17:10 == 29.2	7/30/14 21:05 == 29.2
7/30/14 9:25 == 30.2	7/30/14 13:20 == 11.9	7/30/14 17:15 == 29.2	7/30/14 21:10 == 29.3
7/30/14 9:30 == 30.2	7/30/14 13:25 == 12	7/30/14 17:20 == 29.3	7/30/14 21:15 == 29.1
7/30/14 9:35 == 30.1	7/30/14 13:30 == 12	7/30/14 17:25 == 29.2	7/30/14 21:20 == 29.2
7/30/14 9:40 == 30	7/30/14 13:35 == 11.9	7/30/14 17:30 == 29.2	7/30/14 21:25 == 29.3
7/30/14 9:45 == 30.2	7/30/14 13:40 == 11.9	7/30/14 17:35 == 29.1	7/30/14 21:30 == 29.2
7/30/14 9:50 == 30.1	7/30/14 13:45 == 20.4	7/30/14 17:40 == 29.1	7/30/14 21:35 == 29.2
7/30/14 9:55 == 43.4	7/30/14 13:50 == 29.9	7/30/14 17:45 == 29.2	7/30/14 21:40 == 29.3
7/30/14 10:00 == 45.8	7/30/14 13:55 == 17.8	7/30/14 17:50 == 29.2	7/30/14 21:45 == 29.2
7/30/14 10:05 == 46	7/30/14 14:00 == 12	7/30/14 17:55 == 29.2	7/30/14 21:50 == 29.2
7/30/14 10:10 == 45.6	7/30/14 14:05 == 12	7/30/14 18:00 == 29.2	7/30/14 21:55 == 29.2
7/30/14 10:15 == 36.2	7/30/14 14:10 == 13.5	7/30/14 18:05 == 29.2	7/30/14 22:00 == 29.2
7/30/14 10:20 == 30.1	7/30/14 14:15 == 29.8	7/30/14 18:10 == 29.2	7/30/14 22:05 == 29.2
7/30/14 10:25 == 30.2	7/30/14 14:20 == 29.9	7/30/14 18:15 == 29.2	7/30/14 22:10 == 29.2
7/30/14 10:30 == 30.1	7/30/14 14:25 == 29.8	7/30/14 18:20 == 29.2	7/30/14 22:15 == 29.2
7/30/14 10:35 == 34.6	7/30/14 14:30 == 12.6	7/30/14 18:25 == 29.3	7/30/14 22:20 == 29.3
7/30/14 10:40 == 45.7	7/30/14 14:35 == 12	7/30/14 18:30 == 29.2	7/30/14 22:25 == 29.2
7/30/14 10:45 == 45.8	7/30/14 14:40 == 7.2	7/30/14 18:35 == 29.2	7/30/14 22:30 == 29.2
7/30/14 10:50 == 45.4	7/30/14 14:45 == 0	7/30/14 18:40 == 29.2	7/30/14 22:35 == 29.2
7/30/14 10:55 == 41.5	7/30/14 14:50 == 0	7/30/14 18:45 == 29.3	7/30/14 22:40 == 29.2
7/30/14 11:00 == 29.9	7/30/14 14:55 == 7.5	7/30/14 18:50 == 29.2	7/30/14 22:45 == 29.2
7/30/14 11:05 == 30.1	7/30/14 15:00 == 18.8	7/30/14 18:55 == 29.3	7/30/14 22:50 == 29.3
7/30/14 11:10 == 30.1	7/30/14 15:05 == 28.5	7/30/14 19:00 == 29.2	7/30/14 22:55 == 29.2
7/30/14 11:15 == 43.2	7/30/14 15:10 == 34	7/30/14 19:05 == 29.2	7/30/14 23:00 == 29.2
7/30/14 11:20 == 40.9	7/30/14 15:15 == 33.9	7/30/14 19:10 == 29.3	7/30/14 23:05 == 29.2
7/30/14 11:25 == 29.7	7/30/14 15:20 == 34	7/30/14 19:15 == 29.4	7/30/14 23:10 == 29.2
7/30/14 11:30 == 29.8	7/30/14 15:25 == 33.9	7/30/14 19:20 == 29.2	7/30/14 23:15 == 29.2
7/30/14 11:35 == 29.7	7/30/14 15:30 == 32.5	7/30/14 19:25 == 29.3	7/30/14 23:20 == 29.3
7/30/14 11:40 == 29.8	7/30/14 15:35 == 29.4	7/30/14 19:30 == 29.3	7/30/14 23:25 == 29.2
7/30/14 11:45 == 29.7	7/30/14 15:40 == 29.3	7/30/14 19:35 == 29.2	7/30/14 23:30 == 29.2
7/30/14 11:50 == 29.8	7/30/14 15:45 == 29.2	7/30/14 19:40 == 29.3	7/30/14 23:35 == 29.2
7/30/14 11:55 == 29.9	7/30/14 15:50 == 29.2	7/30/14 19:45 == 29.3	7/30/14 23:40 == 29.2
7/30/14 12:00 == 29.9	7/30/14 15:55 == 29.2	7/30/14 19:50 == 29.3	7/30/14 23:45 == 29.2
7/30/14 12:05 == 29.9	7/30/14 16:00 == 29.1	7/30/14 19:55 == 29.3	7/30/14 23:50 == 29.2
7/30/14 12:10 == 29.7	7/30/14 16:05 == 29.2	7/30/14 20:00 == 29.2	7/30/14 23:55 == 29.2
7/30/14 12:15 == 29.8	7/30/14 16:10 == 29.2	7/30/14 20:05 == 29.3	7/31/14 0:00 == 29.2
7/30/14 12:20 == 29.9	7/30/14 16:15 == 29.2	7/30/14 20:10 == 29.1	7/31/14 0:05 == 29.1
7/30/14 12:25 == 29.7	7/30/14 16:20 == 29.2	7/30/14 20:15 == 29.1	7/31/14 0:10 == 29.1
7/30/14 12:30 == 29.8	7/30/14 16:25 == 29.2	7/30/14 20:20 == 29.1	7/31/14 0:15 == 29.2
7/30/14 12:35 == 29.8	7/30/14 16:30 == 29.2	7/30/14 20:25 == 29.2	7/31/14 0:20 == 29.2
7/30/14 12:40 == 29.7	7/30/14 16:35 == 29.2	7/30/14 20:30 == 29.2	7/31/14 0:25 == 29.2
7/30/14 12:45 == 15.9	7/30/14 16:40 == 29.2	7/30/14 20:35 == 29.2	7/31/14 0:30 == 29.3
7/30/14 12:50 == 11.9	7/30/14 16:45 == 29.2	7/30/14 20:40 == 29.2	7/31/14 0:35 == 29.2

Pumpback Station Discharge (0364)

7/31/14 0:40 == 29.3	7/31/14 4:35 == 29.1	7/31/14 8:30 == 34	7/31/14 12:25 == 31.5
7/31/14 0:45 == 29.3	7/31/14 4:40 == 29.2	7/31/14 8:35 == 34	7/31/14 12:30 == 31.5
7/31/14 0:50 == 29.2	7/31/14 4:45 == 29.1	7/31/14 8:40 == 34	7/31/14 12:35 == 36.5
7/31/14 0:55 == 29.3	7/31/14 4:50 == 29.2	7/31/14 8:45 == 33.9	7/31/14 12:40 == 46.9
7/31/14 1:00 == 29.2	7/31/14 4:55 == 29.2	7/31/14 8:50 == 34	7/31/14 12:45 == 47.4
7/31/14 1:05 == 29.2	7/31/14 5:00 == 29.3	7/31/14 8:55 == 34	7/31/14 12:50 == 47.3
7/31/14 1:10 == 29.1	7/31/14 5:05 == 29.2	7/31/14 9:00 == 34	7/31/14 12:55 == 47.2
7/31/14 1:15 == 29.2	7/31/14 5:10 == 29.3	7/31/14 9:05 == 34	7/31/14 13:00 == 47.1
7/31/14 1:20 == 29.3	7/31/14 5:15 == 29.2	7/31/14 9:10 == 34	7/31/14 13:05 == 47.1
7/31/14 1:25 == 29.2	7/31/14 5:20 == 29.2	7/31/14 9:15 == 34	7/31/14 13:10 == 47.3
7/31/14 1:30 == 29.2	7/31/14 5:25 == 29.2	7/31/14 9:20 == 33.9	7/31/14 13:15 == 47.3
7/31/14 1:35 == 29.2	7/31/14 5:30 == 29.2	7/31/14 9:25 == 34	7/31/14 13:20 == 47.2
7/31/14 1:40 == 29.2	7/31/14 5:35 == 29.1	7/31/14 9:30 == 34	7/31/14 13:25 == 47.3
7/31/14 1:45 == 29.2	7/31/14 5:40 == 29.2	7/31/14 9:35 == 33.9	7/31/14 13:30 == 47.1
7/31/14 1:50 == 29.3	7/31/14 5:45 == 29.2	7/31/14 9:40 == 34	7/31/14 13:35 == 47.1
7/31/14 1:55 == 29.1	7/31/14 5:50 == 29.2	7/31/14 9:45 == 34	7/31/14 13:40 == 47.1
7/31/14 2:00 == 29.2	7/31/14 5:55 == 29.4	7/31/14 9:50 == 34	7/31/14 13:45 == 47.3
7/31/14 2:05 == 29.2	7/31/14 6:00 == 29.2	7/31/14 9:55 == 34	7/31/14 13:50 == 47
7/31/14 2:10 == 29.2	7/31/14 6:05 == 29.2	7/31/14 10:00 == 34	7/31/14 13:55 == 47.3
7/31/14 2:15 == 29.3	7/31/14 6:10 == 29.3	7/31/14 10:05 == 33.9	7/31/14 14:00 == 47.2
7/31/14 2:20 == 29.2	7/31/14 6:15 == 29.2	7/31/14 10:10 == 37.2	7/31/14 14:05 == 47.3
7/31/14 2:25 == 29.2	7/31/14 6:20 == 29.2	7/31/14 10:15 == 42.7	7/31/14 14:10 == 47.2
7/31/14 2:30 == 29.3	7/31/14 6:25 == 29.2	7/31/14 10:20 == 45.7	7/31/14 14:15 == 46.9
7/31/14 2:35 == 29.2	7/31/14 6:30 == 29.2	7/31/14 10:25 == 47.4	7/31/14 14:20 == 47.4
7/31/14 2:40 == 29.2	7/31/14 6:35 == 29.3	7/31/14 10:30 == 47.3	7/31/14 14:25 == 47.2
7/31/14 2:45 == 29.2	7/31/14 6:40 == 29.2	7/31/14 10:35 == 47.4	7/31/14 14:30 == 47.1
7/31/14 2:50 == 29.3	7/31/14 6:45 == 29.1	7/31/14 10:40 == 47.3	7/31/14 14:35 == 47.2
7/31/14 2:55 == 29.2	7/31/14 6:50 == 29.2	7/31/14 10:45 == 47.2	7/31/14 14:40 == 47.4
7/31/14 3:00 == 29.2	7/31/14 6:55 == 29.2	7/31/14 10:50 == 47.1	7/31/14 14:45 == 47.1
7/31/14 3:05 == 29.2	7/31/14 7:00 == 29.3	7/31/14 10:55 == 47.2	7/31/14 14:50 == 47.1
7/31/14 3:10 == 29.2	7/31/14 7:05 == 29.3	7/31/14 11:00 == 47.3	7/31/14 14:55 == 47.1
7/31/14 3:15 == 29.3	7/31/14 7:10 == 29.2	7/31/14 11:05 == 47.3	7/31/14 15:00 == 47
7/31/14 3:20 == 29.1	7/31/14 7:15 == 29.2	7/31/14 11:10 == 47.1	7/31/14 15:05 == 47.1
7/31/14 3:25 == 29.1	7/31/14 7:20 == 29.3	7/31/14 11:15 == 47.2	7/31/14 15:10 == 47.2
7/31/14 3:30 == 29.2	7/31/14 7:25 == 29.2	7/31/14 11:20 == 47	7/31/14 15:15 == 47.2
7/31/14 3:35 == 29.2	7/31/14 7:30 == 29.2	7/31/14 11:25 == 47	7/31/14 15:20 == 47.1
7/31/14 3:40 == 29.3	7/31/14 7:35 == 29.1	7/31/14 11:30 == 47.3	7/31/14 15:25 == 47.4
7/31/14 3:45 == 29.2	7/31/14 7:40 == 31.1	7/31/14 11:35 == 47	7/31/14 15:30 == 47
7/31/14 3:50 == 29.3	7/31/14 7:45 == 33.9	7/31/14 11:40 == 47.1	7/31/14 15:35 == 47.1
7/31/14 3:55 == 29.2	7/31/14 7:50 == 33.9	7/31/14 11:45 == 47	7/31/14 15:40 == 47.1
7/31/14 4:00 == 29.3	7/31/14 7:55 == 33.8	7/31/14 11:50 == 47	7/31/14 15:45 == 47.2
7/31/14 4:05 == 29.3	7/31/14 8:00 == 33.9	7/31/14 11:55 == 47	7/31/14 15:50 == 47.1
7/31/14 4:10 == 29.2	7/31/14 8:05 == 34	7/31/14 12:00 == 47	7/31/14 15:55 == 47
7/31/14 4:15 == 29.3	7/31/14 8:10 == 34	7/31/14 12:05 == 47.1	7/31/14 16:00 == 47
7/31/14 4:20 == 29.3	7/31/14 8:15 == 34	7/31/14 12:10 == 47.2	7/31/14 16:05 == 47
7/31/14 4:25 == 29.2	7/31/14 8:20 == 33.9	7/31/14 12:15 == 34.9	7/31/14 16:10 == 46.9
7/31/14 4:30 == 29.2	7/31/14 8:25 == 28	7/31/14 12:20 == 31.4	7/31/14 16:15 == 47

Pumpback Station Discharge (0364)

7/31/14 16:20 == 47	7/31/14 20:15 == 47
7/31/14 16:25 == 47.1	7/31/14 20:20 == 47
7/31/14 16:30 == 46.9	7/31/14 20:25 == 47.1
7/31/14 16:35 == 47.1	7/31/14 20:30 == 47
7/31/14 16:40 == 47	7/31/14 20:35 == 47
7/31/14 16:45 == 47	7/31/14 20:40 == 47
7/31/14 16:50 == 47	7/31/14 20:45 == 47.1
7/31/14 16:55 == 47	7/31/14 20:50 == 47
7/31/14 17:00 == 47	7/31/14 20:55 == 46.9
7/31/14 17:05 == 47	7/31/14 21:00 == 47
7/31/14 17:10 == 47.1	7/31/14 21:05 == 47
7/31/14 17:15 == 47	7/31/14 21:10 == 47
7/31/14 17:20 == 47	7/31/14 21:15 == 47
7/31/14 17:25 == 47	7/31/14 21:20 == 47.1
7/31/14 17:30 == 46.9	7/31/14 21:25 == 47
7/31/14 17:35 == 47	7/31/14 21:30 == 47.1
7/31/14 17:40 == 47.1	7/31/14 21:35 == 47.1
7/31/14 17:45 == 47	7/31/14 21:40 == 47
7/31/14 17:50 == 47.1	7/31/14 21:45 == 47
7/31/14 17:55 == 47.1	7/31/14 21:50 == 47
7/31/14 18:00 == 47	7/31/14 21:55 == 46.9
7/31/14 18:05 == 47	7/31/14 22:00 == 47
7/31/14 18:10 == 47	7/31/14 22:05 == 47.1
7/31/14 18:15 == 46.9	7/31/14 22:10 == 47.1
7/31/14 18:20 == 47.1	7/31/14 22:15 == 47
7/31/14 18:25 == 47.1	7/31/14 22:20 == 47.1
7/31/14 18:30 == 47	7/31/14 22:25 == 47.1
7/31/14 18:35 == 47.2	7/31/14 22:30 == 47.1
7/31/14 18:40 == 47	7/31/14 22:35 == 47.1
7/31/14 18:45 == 47.1	7/31/14 22:40 == 47
7/31/14 18:50 == 47	7/31/14 22:45 == 47.2
7/31/14 18:55 == 47	7/31/14 22:50 == 47.1
7/31/14 19:00 == 47	7/31/14 22:55 == 47.1
7/31/14 19:05 == 47	7/31/14 23:00 == 47.1
7/31/14 19:10 == 47	7/31/14 23:05 == 47
7/31/14 19:15 == 47	7/31/14 23:10 == 47.1
7/31/14 19:20 == 47	7/31/14 23:15 == 47.1
7/31/14 19:25 == 47	7/31/14 23:20 == 47
7/31/14 19:30 == 47	7/31/14 23:25 == 47.1
7/31/14 19:35 == 46.9	7/31/14 23:30 == 47
7/31/14 19:40 == 47	7/31/14 23:35 == 47.1
7/31/14 19:45 == 47	7/31/14 23:40 == 47.1
7/31/14 19:50 == 47	7/31/14 23:45 == 47
7/31/14 19:55 == 47	7/31/14 23:50 == 47.1
7/31/14 20:00 == 47.1	7/31/14 23:55 == 47
7/31/14 20:05 == 46.9	
7/31/14 20:10 == 46.9	