

06/20/20
08:02:13

NORTHERN DISTRICT DAILY REPORT

06/20/20

MONO BASIN

Rush Cr @ Dam: 30 Lee Vining Creek: Above 53 (Spill: 30, Conduit: 23)
 West Portal : 0 Mono Lake Elev: 6382.52 (USGS Datum) (Read on: 6/11)
 C Ranch Hi/Lo: 86/38 Precip(Day/Month): 0.00/0.13
 Parker Cr Abv: 20 Below: 20 Walker Cr Abv: 5 Below: 5
 Grant Lake Spill: 0
 (*) Grant Lake El: 7119.8 Outflow: 83 24hr AF Total: 164
 (7130.0 HW)AF: 36471 Diff AF: -60 Grant Lake Toe Drain: 0.22

LONG VALLEY

East Portal : 12 Below East Portal: 66
 (*) L V Resv Elev: 6774.9 Outflow: 274 24hr AF Total: 543
 (6781.5 HW)AF: 150723 Diff AF: -233
 L Vally Hi/Lo: 88/36 Precip(Day/Month): 0.00/0.08
 ORG Main Weir: 4.00 Tunnel Drain: 0.23 Toe Drain: 0.51
 Rock Crk Div : 3

NORTH OWENS

RC@OR Cur/Ave: 52/49 Gorge: UG Cur/Avg: 55/54 MG Cur/Avg: 0/ 0
 (*) P V Resv Elev: 4388.6 Outflow: 377 24hr AF Total: 694
 (4390.0 HW)AF: 2850 Diff AF: 34
 Bishop Hi/Lo: 99/47 Precip(Day/Month): 0.00/0.00
 B C @ Plant 6: 120 (avg) O R Below BP Cr: 346 Fish Sprg @ RR Brdg: 37
 BP Pwr House : 96/59 Precip(Day/Month): 0.00/0.00 BP Cr Cur/Peak: 63/90

WELLS

	North Wells		South Wells		* Total *	
Aqueduct	(18)	82.8	(12)	67.4	(30)	150.2 On:
Domestic	(3)	4.6	(3)	1.9	(6)	6.5
Enhanc./Mitig.	(2)	9.8	(6)	13.3	(8)	23.1 Off:
* Total *	(23)	97.2	(21)	82.6	(44)	179.8

SOUTH OWENS

(*) Tin Resv Elev: 3860.5 Outflow: 301 24hr AF Total: 595
 (3866.0 HW)AF: 1804 Diff AF: 0
 Tin Res Hi/Lo: 97/61 Precip(Day/Month): 0.00/0.01

LAA Intake Precip(Day/Month): 0.00/0.00
 Indep Hi/Lo: 97/66 Precip(Day/Month): 0.00/0.00
 Alab Gt Hi/Lo: 97/66 Precip(Day/Month): 0.00/0.00
 Cotw Gt Hi/Lo: 100/58 Precip(Day/Month): 0.00/0.02
 Blckrck Spill: 0.0 Thibaut Spillgates: 0.2 Lone Pine Creek: 26
 Alab Gates GA: 6.94 Flow: 343
 Cottw Gt Gage: 8.06 Flow: 377 Creek: 20 Power Plant: 0
 LORP(inflows): Intake 80, Blackrock 1.4, Goose 0.0, Billy 0.9, Locust 0.0,
 Georges 0.3, Alabama Gates 0 **Total Inflow(cfs): 83**
 (outflows): PumpSta 40, Delta(L.G.) 3, Delta(weir) 0 **Total Outflow(cfs): 43**
 Lubkin Splgt: Flow(in/out): 0/ 35 AF Total(in/out): 0/ 59 net AF: 59
 Cartago Splgt: Flow(in/out): 0/ 42 AF Total(in/out): 0/118 net AF: 118
 Owens Lk Use : (net avg cfs) PumpSta 39.6, Lubkin 30, Cartago 59 **Total: 129**

(*) N Haiwee Elev: 3756.9
 (3757.5 HW)AF: 9693 Diff AF: 0
 (*) S Haiwee Elev: 3732.5
 (3742.0 HW)AF: 19548 Diff AF: -197
 S Haiwe Hi/Lo: 99/57 Precip(Day/Month): 0.00/0.00
 Hai Pwr Plant: 250 24hr AF Total: 495
 LAA #2 S Haiw: 150 24hr AF Total: 297