

MONO BASIN	Rush Cr @ Dam:	12	Lee Vining Creek: Above 16 (Spill: 16, Conduit: 0		
	West Portal :	48	Mono Lake Elev: 6381.33; (USGS Datum) (Read on: 2/17		
	C Ranch Hi/Lo:	56/12	Precip(Day/Month): 0.00/0.00		
	Parker Cr Abv:	3	Below: 3	Walker Cr Abv: 2	Below: 2
			Grant Lake Spill: 0		
	(*) Grant Lake El:	7105.2	Outflow: 75	24hr AF Total: 157	
	(7130.0 HW)AF:	23017	Diff AF: -118	Grant Lake Toe Drain: 0.18	
LONG VALLEY	East Portal :	62	Below East Portal: 108		
	(*) L V Resv Elev:	6769.9	Outflow: 0	24hr AF Total: 0	
	(6781.5 HW)AF:	128187	Diff AF: 381		
	L Vally Hi/Lo:	48/11	Precip(Day/Month):0.00/0.00		
	ORG Main Weir:	3.50	Tunnel Drain: 0.23	Toe Drain: 0.46	
	Rock Crk Div :	0			
NORTH OWENS	RC@OR Cur/Ave:	37/36	Gorge: UG Cur/Avg: 16/16	MG Cur/Avg: 0/0	
	(*) P V Resv Elev:	4388.0	Outflow: 80	24hr AF Total: 157	
	(4390.0 HW)AF:	2791	Diff AF: -38		
	Bishop Hi/Lo:	63/19	Precip(Day/Month): 0.00/0.00		
	B C @ Plant 6:	42(avg)	O R Below BP Cr: 160	Fish Sprg @ RR Brdg: 33	
	BP Pwr House :	60/27	Precip(Day/Month): 0.00/0.00	BP Cr Cur/Peak: 9/10	
WELLS		<u>North Wells</u>	<u>South Wells</u>	<u>* Total *</u>	
	Aqueduct	(5) 26.3	(8) 50.3	(13) 76.6	On: W401,
	Domestic	(3) 4.6	(3) 1.9	(6) 6.5	
	Enhc./Mitig.	(0) 0.0	(2) 3.5	(2) 3.5	Off:
		* Total *	(8) 30.9	(13) 55.7	(21) 86.6
SOUTH OWENS	(*) Tin Resv Elev:	3864.7	Outflow: 198	24hr AF Total: 386	
	(3866.0 HW)AF:	4908	Diff AF: -67		
	Tin Res Hi/Lo:	63/22	Precip(Day/Month): 0.00/0.00		
	LAA Intake		Precip(Day/Month): 0.00/0.00		
	Indep Hi/Lo:	63/25	Precip(Day/Month): 0.00/0.00		
	Alab Gt Hi/Lo:	63/27	Precip(Day/Month): 0.00/0.00		
	Cotw Gt Hi/Lo:	61/26	Precip(Day/Month): 0.00/0.00		
	Blckrck Spill:	0.0	Thibaut Spillgates: 0.0	Lone Pine Creek: 2	
	Alab Gates GA:	5.87	Flow: 203		
	Cottw Gt Gage:	7.42	Flow: 219	Creek: 0	Power Plant: 4
	LORP(inflows):	Intake 43, Blackrock 1.1, Goose 0.0, Billy 1.1, Locust 0.0,			
		Georges 0.1, Alabama Gates 0			Total Inflow(cfs): 47
	(outflows):	PumpSta 42, Delta(L.G.) 11, Delta(weir) 0			Total Outflow(cfs): 53
	Lubkin Splgt:	Flow(in/out): 0/31 AF Total(in/out): 3/25			net AF: 22
	Cartago Splgt:	Flow(in/out): 0/46 AF Total(in/out): 0/52			net AF: 52
Owens Lk Use :	(net avg cfs) PumpSta 42.2, Lubkin 11, Cartago 26			Total: 80	
(*) N Haiwee Elev:	3757.0				
(3757.5 HW)AF:	9733	Diff AF: 0			
(*) S Haiwee Elev:	3725.4				
(3742.0 HW)AF:	14352	Diff AF: 300			
S Haiwe Hi/Lo:	69/27	Precip(Day/Month): 0.00/0.00			
Hai Pwr Plant:	0	24hr AF Total: 0			
LAA #2 S Haiw:	0	24hr AF Total: 0			