

MONO BASIN	Rush Cr @ Dam: 28	Lee Vining Creek: Above 41 (Spill: 16, Conduit: 31.3)	
	West Portal : 41	Mono Lake Elev: 6382.12; (USGS Datum) (Read on: 11/10)	
	C Ranch Hi/Lo: 45/39	Precip(Day/Month): 0.71/2.26	
	Parker Cr Abv: 9	Below: 9 Walker Cr Abv: 8 Below: 8	
		Grant Lake Spill: 0	
	(* Grant Lake El: 7122.9	Outflow: 72 24hr AF Total: 140	
(7130.0 HW)AF:	39584 Diff AF: 21 Grant Lake Toe Drain: 0.20		
LONG VALLEY	East Portal : 52	Below East Portal: 104	
	(* L V Resv Elev: 6767.9	Outflow: 36 24hr AF Total: 71	
	(6781.5 HW)AF:	120081 Diff AF: 529	
	L Vally Hi/Lo: 46/38	Precip(Day/Month):0.35/0.40	
	ORG Main Weir: 4.10	Tunnel Drain: 0.18 Toe Drain: 0.41	
	Rock Crk Div : 0		
NORTH OWENS	RC@OR Cur/Ave: 55/45	Gorge: UG Cur/Avg: 37/37 MG Cur/Avg: 0/0	
	(* P V Resv Elev: 4383.9	Outflow: 89 24hr AF Total: 175	
	(4390.0 HW)AF:	2398 Diff AF: 13	
	Bishop Hi/Lo: 56/46	Precip(Day/Month): 0.39/0.44	
	B C @ Plant 6: 76(avg)	O R Below BP Cr: 198 Fish Sprg @ RR Brdg: 26	
	BP Pwr House : 52/43	Precip(Day/Month): 0.98/1.10 BP Cr Cur/Peak: 29/40	
WELLS		<u>North Wells</u> <u>South Wells</u> <u>* Total *</u>	
	Aqueduct (5)	42.2 (4) 32.4 (9) 74.6	On: W346,
	Domestic (3)	4.6 (3) 1.9 (6) 6.5	
	Enhc./Mitig. (0)	0.0 (1) 0.3 (1) 0.3	Off:
	* Total * (8)	46.8 (8) 34.6 (16) 81.4	
SOUTH OWENS	(* Tin Resv Elev: 3862.8	Outflow: 180 24hr AF Total: 351	
	(3866.0 HW)AF:	3335 Diff AF: 62	
	Tin Res Hi/Lo: 55/46	Precip(Day/Month): 0.78/0.97	
	LAA Intake	Precip(Day/Month): 0.99/1.15	
	Indep Hi/Lo: 53/45	Precip(Day/Month): 1.18/1.38	
	Alab Gt Hi/Lo: 53/45	Precip(Day/Month): 1.15/1.18	
	Cotw Gt Hi/Lo: 53/45	Precip(Day/Month): 2.06/2.13	
	Blckrck Spill: 11.2	Thibaut Spillgates: 0.0 Lone Pine Creek: 10	
	Alab Gates GA: 5.74	Flow: 209	
	Cottw Gt Gage: 7.30	Flow: 270 Creek: 0 Power Plant: 0	
	LORP(inflows): Intake 46, Blackrock 2.3, Goose 0.0, Billy 1.4, Locust 0.0,	Georges 0.6, Alabama Gates 0 Total Inflow(cfs): 51	
	(outflows): PumpSta 47, Delta(L.G.) 8, Delta(weir) 0	Total Outflow(cfs): 55	
	Lubkin Splgt: Flow(in/out): 29/0	AF Total(in/out): 60/0 net AF: -60	
	Cartago Splgt: Flow(in/out): 16/0	AF Total(in/out): 31/0 net AF: -31	
	Owens Lk Use : (net avg cfs) PumpSta 47.1, Lubkin -30, Cartago -16	Total: 1	
	(* N Haiwee Elev: 3755.6		
	(3757.5 HW)AF:	8956 Diff AF: 444	
(* S Haiwee Elev: 3729.8			
(3742.0 HW)AF:	17534 Diff AF: 252		
S Haiwe Hi/Lo: 52/46	Precip(Day/Month): 2.63/3.08		
Hai Pwr Plant: 0	24hr AF Total: 0		
LAA #2 S Haiw: 0	24hr AF Total: 0		
SOUTHERN DISTRICT	BOUQUET RELEASE	INST: 1.0 CFS PREV DAY: 1.0 CFS	